

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 201 / TOWN I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381			.6859		.5716
2	.381			.6859		.5716
3	.381			.381		.4763
4	.4763			.4763		.4763
5	.4763			.5716		.6287
6	.4763			.381		.5239
7	.5716			.5716		.5716
8	.5716		.6668	.5716		.5716
9	.6668	.6668			.5716	.6192
10	.6668	.6668			.5716	.4572
11	.7621	.6668				.4572
12	.6668	.7145	.381		.381	.4572
13	.6668	.7621			.381	.4572
14	.6668	.6668	.4763	.7621	.381	.4572
15	.6668	.6668		.7621	.381	.4572
16	.6668	.6668	.4763	.7621	.381	.4572
17	.6668	.6668	.381	.7621	.4763	.4572
18	.6668	.6668	.4763	.7621	.4763	.4572
19	.6668	.7621	.6859	.7621	.4763	
20	.6668	.6668			.4763	
21	.6668	.6668			.381	
22	.6668	.6668			.4763	
23	.6668	.6668			.4763	
24	.381		.6668	.5716		.6859
Max	.7621	.7621	.6859	.7621	.5716	.6859
Min	.381	.6668	.381	.381	.381	.4572
Avg	.5914	.6827	.5263	.6313	.4491	.5164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 202 / TOWN2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716			.6192		.6192
2	.4763			.6192		.6192
3	.4763			.6668		.5716
4	.5716			.6668		.6859
5	.5716			.6668		.6859
6	.5716					.6192
7	.6668			.8002		.743
8	.8002		.6668	.7145		.6192
9	.8002	.9335			.6668	.6192
10	.9335	.9335			.6192	1.0669
11	.8002	.9335				1.0669
12	.8002	.8002	.4763		.5716	1.0669
13	.8002	.8002	.4287		.4763	1.0669
14	.8002	.8002	.381	1.0669	.5716	1.0669
15	.8002	.8002		1.0669	.5144	1.0669
16	.8002	.8002	.4287	1.0669	.5716	1.0669
17	.8002	.6668	.4763	1.0669	.4763	1.0669
18	.8002	.8002	.5239	1.0669	.6287	1.0669
19	.8002	.6668	.743	1.0669	.5716	
20	.8002	.6668			.5716	
21	.8002	.9145			.5239	
22	.8002	.8002			.6859	
23	.8002	.8002			.5716	
24	.5716		.6668	.6668		.6668
Max	.9335	.9335	.743	1.0669	.6859	1.0669
Min	.4763	.6668	.381	.6192	.4763	.5716
Avg	.7256	.8078	.5324	.8444	.5729	.8448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 203 / BORI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762			.381		.8573
2	.0572			.5716		1.0479
3	.0857			.6859		2.0005
4	.0857			.6192		2.0005
5	.0572			.9145		1.7337
6	.0953			.8573		1.4861
7	.1143			.0107		1.6004
8	.1905			.5716		
9	.2667	1.3717				1.2574
10	.5335	.5335			.2858	
11	.5335	.2667				
12	.5335	.2667	.1524			
13	.5335	.2667	.1905		.1429	
14	.5335	.2667	.1905		.1429	
15	.5335	.2667				
16	.5335	.2667	.0953	.4572	.1143	
17	.5335	.6097	.1429	.4572	.0762	
18	.6097	.2667	.1524	.4572	.1429	
19	.5335	.5335	.1905	.4572	.2858	
20	.5335	.2667			.2382	
21	.6097	.5335			.2858	
22	.5335	.5335			.2858	
23	.6097	.5335			.2858	
24	.0953		.8002	.2858		.9335
Max	.6097	1.3717	.8002	.9145	.2858	2.0005
Min	.0572	.2667	.0953	.0107	.0762	.8573
Avg	.3676	.4522	.2393	.5174	.2079	1.4353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 204 / GOLAPANGRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002			.1429		.2382
2	.6859			.1429		.1524
3	.6668			.1905		.1524
4	.4572			.1905		.1905
5	.6859			.1905		.1905
6	.6859			.1905		.1905
7	.8002			.1143		.1143
8	.8573			.1429		
9	.5335	.2667				.0953
10	.5335	.6668				
11	.5335	.7621				
12	.5335	.6668	.6192			
13	.5335	.6668	.5716		.381	
14	.5335	.6668	.8002		.6668	
15	.6401	.6668				
16	.5335	.6668	1.0669	1.0669	.9335	
17	.5335	.5335	.5716	1.0669	.8002	
18	.6097	.5335	.2286	.4572	.2286	
19	.5335	.5335	.1429	.4572	.2382	
20	.5335	.5335			.2858	
21	.6097	.5335			.2382	
22	.6097	.5335			.2858	
23	.5335	.6097			.3334	
24	.4763		.5335	.1429		.2382
Max	.8573	.7621	1.0669	1.0669	.9335	.2382
Min	.4572	.2667	.1429	.1143	.2286	.0953
Avg	.6022	.5894	.5668	.3459	.4392	.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 205 / SHAHAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.8002		.7621
2	.2382			.7621		1.0288
3	.2382			.7621		.8573
4	.2858			1.2574		.8573
5	.2858			1.3717		.7621
6	.2858			1.4861		.7621
7				.8573		1.0669
8			1.3336	1.3489		.5716
9		.5335				1.2193
10	.8002	.6668			.0857	
11	.9145	.6668				
12	.9145	.6668				
13	.9145	.6668	.0953		.0953	
14	.9145	.6668	.0953		.0953	
15	.8002	.6668				
16	.8002	.6668	.1905	.6097	.0762	
17	.8002	.6668	.2286	.381	.1429	
18	.7621	.6668	.1143	.6097	.2858	
19	.6668	.7621	.2858	.7621	.1905	
20	.7735	.6668				
21	.6668	.6668			.2858	
22	.7621	.6668			.2858	
23	.6668	.6668			.2858	
24	.1905		.9335	.5716		.6668
Max	.9145	.7621	1.3336	1.4861	.2858	1.2193
Min	.1905	.5335	.0953	.381	.0762	.5716
Avg	.6148	.6643	.4096	.8908	.1829	.8554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 206 / WATER SUPPLY

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905			.3429		.2382
2	.2382			.2858		.2858
3	.2858			.2858		.2858
4	.2858			.2382		.1524
5	.2858			.2382		.1524
6	.2858			.2286		.1905
7	.2382			.1429		.1905
8	.1429		.2667	.1905		.2382
9	.3048	.2667				.1905
10	.2	.2667			.1905	
11	.2667	.2667				
12	.2286	.2667	.1905			
13	.2	.2667	.2382		.1905	
14	.2667	.2667	.1429		.1524	
15	.2667	.2667				
16	.2667	.3048	.1905	.3048	1.9338	
17	.2667	.2667	.2382	.3048	.1715	
18	.2667	.2667	.0857	.3048	.1905	
19	.2667	.2667	.1429		.1429	
20	.2401	.3048		.3048	.1905	
21	.3048	.2667			.1905	
22	.2	.2667			.1905	
23	.2	.2667			.1905	
24	.2382		.3048	.1905		.2382
Max	.3048	.3048	.3048	.3429	1.9338	.2858
Min	.1429	.2667	.0857	.1429	.1429	.1524
Avg	.2474	.2718	.2000	.2587	.3395	.2163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 207 / TOWN NO-3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2382					.2858
2	.2858					.2382
3	.2858					.2382
4	.2858					.2858
5	.2858					.2858
6	.2382					.2858
7	.2382			.2858		.2858
8			.4001	.2382		.2382
9	.4001	.4001			.2382	.2382
10	.4001	.4001			.2382	.4572
11	.4001	.4001				.4572
12	.4001	.4001	.2382		.1905	.4572
13	.4001	.4572	.2382		.2382	.4572
14	.4001	.4572	.1905	.4572	.1905	.4572
15	.4001	.4001		.4572		.4572
16	.4001	.4001	.2382	.4572	.1524	.4572
17	.4001	.4001	.2858	.4572	.1905	.4572
18	.4572	.4001	.2382	.4572	.1905	.4572
19	.4001	.4001	.2858	.4572	.2382	
20	.4001	.4572			.2858	
21	.4001	.4572			.2858	
22	.4001	.4572			.2858	
23	.4001	.4001			.2858	
24	.2858		.4001			.2858
Max	.4572	.4572	.4001	.4572	.2858	.4572
Min	.2382	.4001	.1905	.2382	.1524	.2382
Avg	.3566	.4191	.2795	.4084	.2316	.3570

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 201 / TAKA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2667		.2096	
2	.2096	.2858		.2096	
3	.2286	.2858		.2286	
4	.2286	.3048		.2286	
5	.2667	.3239		.3048	
6	.3239	.3239		.3048	
7	.362	.381		.3429	
8	.4572			.4001	
9	.4954		.1524	.4572	
11					.381
12					.3429
13					.3239
14					.2858
15					.3429
16					.2667
17					.1905
24	.2096	.2667		.1905	
Max	.4954	.381	.1524	.4572	.381
Min	.2096	.2667	.1524	.1905	.1905
Avg	.2991	.3048	.1524	.2877	.3048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 202 / NALEWADI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3048			.3429
2	.3239	.3048			.3239
3	.362	.3239			.3429
4	.4572	.4001			.4001
5	.5335	.6668		.5144	.4572
6	.743	.7811		.7621	.6097
7	.8383	.9145		.8764	.8573
8	.8192		.6859	.8383	
9	.6668		.5716	.7811	
10	.381		.4191		.4954
11	.2858		.381	.5716	.381
12	.2477		.2096	.5716	.3429
13	.2477		.2096		.3048
14	.2096		.2096	6.0776	.2477
15	.1905		.2286	.362	.2286
16	.1905			.3429	.2858
17	.2477			.0191	.2667
18	.2667			.5144	
19	.381			.743	
20	.6668			.743	
21	.743			.7621	.4382
22	.6668			.6668	.381
23	.4191			.3429	.3429
24	.3429	.3048			.3048
Max	.8383	.9145	.6859	6.0776	.8573
Min	.1905	.3048	.2096	.0191	.2286
Avg	.4406	.5001	.3644	.9111	.3870

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 203 / GONDI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4001	.4001	
2	.3429		.4001	.4001	.381
3	.3429		.4572	.4572	.4763
4	.4001		.4572	.5906	.4572
5	.4763		.5525	.724	.6097
6	.743		.6859	.9335	.724
7	.7049		.724	1.0288	.8383
8	.6668		.743		.7621
9	.5525		.5335		.5906
10			.4191	.6668	.4763
11	.381	.3429	.4001	.5716	.381
12	.362	.3239		.5716	.362
13			.362	.5525	.2667
14	.4001		.3239	.5525	.3429
15	.381	.3429	.3239	.5335	
16	.4572	.4001	.3429	.5716	
17	.5335	.4763	.5335	.5906	.5335
18	.6097	.743	.7049	.743	.8573
19	.743	.9145	.8002	.8764	.743
20	.8383	.8764	.7621	.8764	.5716
21	.8383	.7811	.7049		.4954
22		.5906	.381		.4191
23		.5335	.381	.5525	.362
24	.3429		.4382	.362	.381
Max	.8383	.9145	.8002	1.0288	.8573
Min	.3429	.3239	.3239	.362	.2667
Avg	.5230	.5750	.5144	.6278	.5253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 204 / SHAHAGAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	1.0288		1.2193	
2	.8954	1.0479		1.2193	
3	.8954	1.1241		1.3146	
4	.9717	1.2384		1.448	
5	1.105	1.3146		1.5813	
6	1.1241	1.5813		1.6956	
7	1.2384	1.7528		1.8671	
8	1.5051		1.6004	1.9243	
9	1.3527		1.5242	1.7337	
10	.3048		.4191	.5525	
11	.3429		.4572	.5716	
12	.4382		.4763	.6097	1.2384
13	.4572		.4763	.724	
14	.4572		.4763	.5716	
15			.4572	.5716	
16	.4763		.4572	.5335	
17			.4382		
18			.0191		
24	.8383	1.0288		1.1622	
Max	1.5051	1.7528	1.6004	1.9243	1.2384
Min	.3048	1.0288	.0191	.5335	1.2384
Avg	.8276	1.2646	.6183	1.1353	1.2384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 205 / SHAHAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.6478		
2	.381	.6478		
3	.4001	.6668		
4	.4572	.8192		
5	.5335	.8383		
6	.6097	.9145		
7	.6668	.9717		
8		1.1241		
9		1.0669		
10				.5716
11				.743
12				.8002
13				.7621
14			.9145	.6859
15			1.0669	.724
16			1.086	
17			1.0288	
24	.4001	.5906		
Max	.6668	1.1241	1.086	.8002
Min	.381	.5906	.9145	.5716
Avg	.4787	.8288	1.0241	.7145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 206 / SHAHAPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381		.381	.5144
2	.4191	.381		.381	.5716
3	.4382	.381		.4382	.6097
4	.4382	.4382		.5716	.6859
5	.5716	.5525		.6478	.6859
6	.7049	.6287		.7811	.7811
7	.6478	.6859		.8954	.8383
8					.7811
9				.9145	.743
10	.5144			.7811	.4763
11	.381			.6097	.4572
12	.362			.4954	.4191
13	.3429				.381
14	.3048			.4572	.362
15	.3048			.4572	.4382
16	.3429			.5525	
17	.4572		.4572	.6478	
18	.5335		.5525		.5716
19	.6859		.6859		.6478
20	.743		.7811	.8764	.8764
21	.7621		.7811	.8573	.7621
22	.5906		.6668	.7621	.6097
23	.5335		.4572	.7811	.381
24	.4572	.4191		.381	.4572
Max	.7621	.6859	.7811	.9145	.8764
Min	.3048	.381	.4572	.381	.362
Avg	.4979	.4834	.6260	.6335	.5932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 207 / GONDI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.743	.8383
2			.8002	.9145
3			.8002	.9526
4			.8383	.9907
5			.8764	1.0479
6			.9526	1.105
7			1.0288	1.1812
8			1.105	1.2193
9			1.086	1.2003
10		1.0479		
11		1.1241		
12		1.105		
13		1.1622		
14		1.1241		
15		1.105		
16	.8954	1.0669		
17	.9717	1.0669		
24			.724	.8764
Max	.9717	1.1622	1.105	1.2193
Min	.8954	1.0479	.724	.8383
Avg	.9336	1.1003	.8955	1.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 208 / DONGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334		
2		.1524		
3		.1524		
4		.1524		
5		.1524		
6		.1715		
7			.3429	
8			.3429	.5335
9			.5525	.6097
10			.1143	
14	.4191			
15	.4763			
16	.5906			
17	.5906	.5525		
18		.1334		
24		.1334		
Max	.5906	.5525	.5525	.6097
Min	.4191	.1334	.1143	.5335
Avg	.5192	.1926	.3382	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 210 / p.sirasgaon (Ag)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1622	1.5623
2				1.1622	1.7147
3				1.1622	1.7528
4				1.2384	1.5242
5				1.5051	1.7147
6				1.5051	1.7909
7				1.6004	1.8861
8				1.7337	1.9052
9				1.6956	2.0957
10	.8954	1.2955	1.5051		
11	1.105	1.448	1.6004		
12	1.1622	1.5432	1.6385		
13	1.1622	1.5051	1.6956		
14	1.1241	1.5051	1.6385		
15	1.105	1.4098	1.6194		
16	1.086	1.3336			
17		1.2955	1.2003		
23				.2286	
24					1.5242
Max	1.1622	1.5432	1.6956	1.7337	2.0957
Min	.8954	1.2955	1.2003	.2286	1.5242
Avg	1.0914	1.4170	1.5568	1.2994	1.7471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 212 / Baraswda (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478			.7811	
2	.6478			.8002	
3	.7049			.9335	
4	.7049			1.0098	
5	.743			1.1241	
6	.8954			1.2193	
7	.9145			1.3336	
8	.8764		.3048	1.2193	
9	.8002		.2286	1.1622	
10	.1905		.1905	.1334	
11	.1524		.1715	.1143	
12	.1143		.0953	.0762	
13	.0953		.0762	.0762	
14	.0762		.0762		
15	.0762		.0762		
16	.0762	.1715	.0953		
17	.1905		.1143		
18	.2096		.1715		
19			.2667		
20			.2858		
21			.2858		
22			.2286		
23			.1715		.1905
24	.6859			.7811	
Max	.9145	.1715	.3048	1.3336	.1905
Min	.0762	.1715	.0762	.0762	.1905
Avg	.4633	.1715	.1774	.7689	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 201 / JAMKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.7716	.7716	1.0288	.8573	.7716
2	.6859	.6859	.7716	.7716	1.0288	.8573	.7716
3	.6859	.6859	.8573	.9088	1.0288	1.0288	.9259
4	.6859	.7716	.9431	.9259	1.0288	1.0288	1.0974
5	.8573	.8573	1.1831	1.0802	1.0288	1.3717	1.2003
6	.8573	1.0288			1.2003		
10	1.0288						1.2689
11	1.0288						
12	1.0288			.8573		1.4746	1.3717
13				.8573		1.5432	1.4575
14				.8573		1.5604	1.3546
15	.6859				1.5432	1.3717	
16	.6859			1.2003	1.5947	1.3546	1.0974
17	.8573			1.5432	1.5432	1.3889	1.3717
18	.8573			1.0288	1.0288	1.1317	1.1831
19		1.2003	1.2003	1.3717	1.0288		1.1831
20		1.0974			1.0288	1.0288	1.2003
21	.8573	.9431	1.0117			.9259	
22	1.0288	.8059	.8573	1.0288	.8573	.8573	
23	.8573	1.2003	.8059	1.0288	.8573	.823	.823
24	.6859	.6859	.7545	.8059	1.0288	.8573	.7716
Max	1.0288	1.2003	1.2003	1.5432	1.5947	1.5604	1.4575
Min	.6859	.6859	.7545	.7716	.8573	.823	.7716
Avg	.8271	.8874	.9156	1.0025	1.1237	1.1448	1.1156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 202 / ROHILAGAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0288	.8059	.8573	.8573	.9431	.8402
2	.8573	1.2003	.8573	.8573	1.0288	1.0288	.8573
3	1.0288	1.3717	.9431	1.0288	1.2003	1.0288	.9088
4	1.0288	1.3717	1.2003	1.1145	1.3717	.0154	.9431
5	1.2003	1.5432	1.4232	1.3203	1.5432	1.3717	1.0288
6	1.286	1.5432	1.8176	1.7318	1.7147	1.7147	1.3717
7	1.7147		1.1317	1.8519			
8	2.0576			1.4632			
9	2.0576			1.3032			
10							2.0405
11			1.9033				
12	.6859		2.0233	2.0576		1.749	1.8861
13				2.2805		2.2977	2.1434
14			1.869	2.4006		2.3834	2.3148
15	.5144		1.6118	2.4006	2.2291	2.3491	
16	.6859		1.9033	2.4006	2.4006	2.3663	1.6118
17	.7716			2.4006	2.572	2.0576	1.9376
18	1.0802			1.0288	1.1145	1.1317	.8459
19	1.3717	1.3717	1.166	1.2003	1.3717		1.1831
20		1.4232			1.2003	1.2346	1.3717
21	1.0288	1.286	1.046			.9602	
22	1.0288	.9774	.9431	1.0288	1.0288	.9259	1.0117
23	1.0288	.9774	.8745	1.0288	.9431	.8573	.8573
24	.8573	1.0288	.8059	.8059	.8573	.9431	.8402
Max	2.0576	1.5432	2.0233	2.4006	2.572	2.3834	2.3148
Min	.5144	.9774	.8059	.8059	.8573	.0154	.8402
Avg	1.1127	1.2603	1.3133	1.5281	1.4289	1.4088	1.333

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134026 / JAMKHED

Feeder No / Name : 203 / NANDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4287	.4287	.6859	.6001	.6001
2	.3429	.3429		.4287	.6859	.6001	.6001
3	.3429	.3429	.4287	.5144	.7716	.6859	.6859
4	.4287	.3429	.5144	.5144	.7716	.6859	.7716
5	.5144	.5144	.6001	.5487	.8573	.7716	.823
6	.6001	.5144	.6516	.6859	.8573	.9431	1.0288
7	.5144		.9259	1.2174	1.7147	1.2003	1.5947
8	.6001		1.1831	1.4232	1.7147	1.4746	1.7833
9			.9431	1.2517		.0154	1.2003
10	.6001						.3258
11	.7202		.3086				
12	.7202		.2401	.2572		.463	.2401
13				.2058		.5144	.2572
14				.2058			.2743
15	.5144		.1715	.2058	.2572		
16	.6001		.2229	.1715	.2572		.3086
17	.6859			.2572	.2572	.5487	.3772
18	.5144		.3944	.4287	.3429	.463	.4801
19	.6859	.4973	.3258	.3429	.5144		.3772
20	.6859	.4801			.6001	.3772	.4115
21	.6859	.3772	.3601			.3601	
22	.5144	.3086	.3429		.5144	.3429	
23	.3429	.3086	.3086	.3429	.4287	.3429	.3429
24	.3429	.3429	.4458	.4287	.6001	.6001	.5658
Max	.7202	.5144	1.1831	1.4232	1.7147	1.4746	1.7833
Min	.3429	.3086	.1715	.1715	.2572	.0154	.2401
Avg	.5381	.3929	.4887	.5189	.6960	.6105	.6524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 202 / SIRNER GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.0857		.1715	.1715	.1715	.1715
2	.2572	.0857		.1715	.1715	.1715	.1715
3	.3429	.1143		.1715	.1715	.1715	.1715
4	.3429	.1143		.2572	.3429	.2572	.2572
5	.3429	.1429		.2572	.4287	.4287	.3429
6	.3429	.1429	.0381	.4287	.6001	.6001	.5335
7	.5144		.0381	.3429	.5144	.6001	.5335
8	.2286		.3429	.4287	.5144	.5144	.5144
9	.0381		.3429	.3429		.3429	.4287
10	.0572		.3429			.2572	.2572
11	.0572		.2572	.0857	.1715		
12	.0572		.1715				
13	.0572		.0857			.2572	.0572
14	.0572					.2572	.0572
15	.0572				.0857	.2572	.0572
16	.0572				.0857	.2572	.0572
17	.0572					.3429	.0572
18	.1143	.1715	.1715			.3429	.1143
19	.1429	.0191	.3429	.4287	.4287	.3429	.381
20	.1429	.0286	.4287		.4287	.3429	.1143
21	.1143		.0476	.4287	.3429	.3429	.0857
22	.0857		.3429	.3429	.3429	.3429	.0857
23	.1905		.3429	.1715	.2572	.2572	.0572
24		.0572		.2572	.1715	.2572	.1715
Max	.5144	.1715	.4287	.4287	.6001	.6001	.5335
Min	.0381	.0191	.0381	.0857	.0857	.1715	.0572
Avg	.1702	.0962	.2354	.2858	.3076	.3234	.2126

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 203 / SHIRNER AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.381		.4572	.5144	.9145	.4287
2	.6859	.381		.4572	.5144	.9145	.4287
3	.6859	.381		.4572	.6097	.9145	.5144
4				.6097	.6097	1.0669	.6859
5					.6097	1.3717	.7621
6			1.3717		.9907	1.6766	.9145
7			.1715		1.3336	1.9814	1.3336
8			1.5432		1.467	2.2862	1.3717
9			1.3717			1.5242	1.3336
10	.9526						
11	1.5242						
12	1.5242						
13	1.5242						
14	1.5242						
15	1.5242						
16	1.5242						
17	1.5242						
20	.2858	.1715	.1524				.2858
21	.2858		.0191				.2858
22	.2858		.0381				.2858
23	.2858		.0191			.4287	.2858
24		.0857		.6859	.5144	.9145	.4287
Max	1.5242	.381	1.5432	.6859	1.467	2.2862	1.3717
Min	.2858	.0857	.0191	.4572	.5144	.4287	.2858
Avg	.9831	.2800	.5859	.5334	.7960	1.2722	.6675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 204 / CHINCHKHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6859			.4287	.5144	.4287
2	.6668	.6859			.4287	.5144	.4287
3	.8573	.6859			.5144	.5144	.4287
4	1.0288	.8573			.6097	.6859	.5144
5	.5716	1.0288			.9907	.8573	.6097
6	1.3717	1.3717	1.0288		1.0669	1.0288	.9907
7	1.3717		.7621		.9907	1.2003	.9145
8	1.2193		.7621		.9145	.6859	.8383
9	.3048		.8573			.8573	.7621
10	.6859		.8573			.9431	.6859
11	.5144		.5144	.3429	.5144		
12	.5144		.5144	.3429	.3429		
13			.5144	.3429		.5144	.4287
14				.3429		.4287	.4287
15				.3429	.2572	.4287	.4287
16				.3429	.2572	.5144	.4287
17		.4287		.4287		.6001	.6859
18	.5144	.6859	.6859	.6001		.6097	1.0288
19	1.0288	.6859	1.0288	.9145	.8573	.7621	1.1145
20	1.1145	.6859	1.0288		1.0288	.7621	.8573
21	1.0288		.1143	.9145	.8573	.7621	.6859
22	.8573		.6859	.6859	.6859	.6097	.5144
23	.6859		.6859	.5144		.5144	.5144
24	.6859	.6859		.8573	.4287	.5144	.4287
Max	1.3717	1.3717	1.0288	.9145	1.0669	1.2003	1.1145
Min	.3048	.4287	.1143	.3429	.2572	.4287	.4287
Avg	.8358	.7716	.7172	.5364	.6573	.6738	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 201 / TADHADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.3429	.3506	.3429	.3277	.3086	.3429
2	.5144	.3429	.3506	.3429	.4588	.3429	.3429
3	.5087	.3429	.3506	.3429	.4915	.3772	.3429
4	.5087	.3429	.3506	.3429	.4915	.4115	.4287
5	.5935	.3944	.3856	.3944	.5735	.4207	.4801
6	.6443	.4458	.3856	.4458	.3277	.4207	.5144
7	.6783	.4801	.407	.7545	.1619	.4207	.3429
8	.6783		.4557		.1638	.3506	.12
9	.6371		.3658			.3048	.12
10	.1524		.3658			.381	
11	.1524		.381		.6001	.381	
12	.1524		.381	.6687	.6859	.381	.6516
13	.1524		.381	.7045	.7042		.6001
14	.1524		.3963	.6935	.7545		.583
15	.1219		.381	.639	.7042		.5365
16	.1219		.381	.4915	.7209	.5335	.503
17	.1715		.381	.4096	.7377	.5335	.503
18	.2058	.298	.3429	.4915	.3018		.1677
19	.2401	.3506	.3429	.4915	.3018	.4458	.3429
20	.6516	.3506	.3429	.6554	.3772		.3429
21	.5144	.4207	.3429	.6226	.39		.4287
22	.5144	.4382	.3429	.4096	.3772		.4458
23	.4287	.3506	.3429	.4096	.3772	.3429	.4115
24	.503	.3429	.3429	.3429	.3277	.3772	.3429
Max	.6783	.4801	.4557	.7545	.7545	.5335	.6516
Min	.1219	.298	.3429	.3429	.1619	.3048	.12
Avg	.3961	.3745	.3688	.4998	.4708	.3961	.4043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 202 / PANGERKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	1.0288	1.0288	.8573	.9012	.9431	1.0288
2	.5487	1.0288	1.0867	.8573	.9012	.9431	1.0288
3	.583	1.2003	1.0288	1.0288	.9503	.9259	1.2003
4	.5868	1.3717	1.0288	1.2003	.9831	.9431	1.2003
5	.5935	1.4575	1.0974	1.286		1.0288	1.3717
6	.5426	1.5432	1.1317	1.4232		1.0288	1.7147
7	.5596	1.6118	1.166	1.989			1.9204
8	.5765		1.4243			.8573	1.7528
9	.503		1.2955			.7621	1.8595
10	1.1145		.4572			.3048	
11	1.0669		.4572		.3856	.3048	
12	1.0669		.381			.3048	.3944
13	1.0822		.3048	.4588			.3772
14	.9907		.3048	.4588			.373
15	.9907		.3048		.1753		.3772
16	.945		.3201	.4096	.1753	.5335	.3944
17	.9145		.381	.6226	.3856	.5335	.4115
18	.6001	.1949	.4268	.4096	.3506	.6344	.4287
19	.6859	.3506	.5487	.7373	.4908	.6687	.823
20	.8402	.4382	.6001	.8192	.4973		.4287
21	.7716	.5258	.6001	.7373	.5258		.5144
22	.7716	.5258	.6097	.8192	.4908		.4801
23	.6859	.5609	.6859	.8192	.4557	.7716	.463
24	.503	1.0288	.7716	.8573	.8192	.8573	1.0288
Max	1.1145	1.6118	1.4243	1.989	.9831	1.0288	1.9204
Min	.503	.1949	.3048	.4096	.1753	.3048	.373
Avg	.7525	.9191	.7267	.8773	.5659	.7262	.8896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134048 / TADHADGAON

Feeder No / Name : 203 / RUI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.5144	.1753	.5144	.6226	.3429	.5144
2	1.0852	.5144	.1753	.5144	.4915	.3429	.5144
3	1.0682	.5144	.2454	.5144	.5735	.3772	.5144
4	1.1022	.5144	.2454	.5487	.6554		.6001
5	1.1736	.5658	.2454	.6001	.6554		.6344
6	1.2574	.6001	.2629	.6344	.6783	.4115	.7716
7	1.4251	.6173	.2629	.6516	.3277	.3944	.5487
8	1.3077		.2804		.4096	.3963	.442
9	1.5565		.1981			.3658	.3506
10	.1753		.4572			.5335	
11	.1524		.4572		1.1022	.6859	
12	.1886		.4572	1.0852	1.2003	.7621	1.278
13	.1677		.4572	1.1633	1.1869		1.6712
14	.1677		.4572	1.0978	1.3056		1.7772
15	.1677			1.0159	1.2378		1.5927
16	.1677			1.0159		1.448	1.5089
17	.2286		.6097	.6554		1.4784	1.5089
18	.2743		.4287	.4096	.1753	.5144	
19	.4115	.1753	.4973	.4915	.3155	.583	.3429
20	.6859	.1753	.4973	.6478	.3155		.3772
21	.6001	.2103	.5144	.6226	.3258		.4458
22	.6001	.1928	.5144	.6154	.3086		.3944
23	.5144	.1753	.5144	.4915	.3429	.5144	.3772
24	1.0513	.5144	.1772	.5144	.4915	.3429	.5144
Max	1.5565	.6173	.6097	1.1633	1.3056	1.4784	1.7772
Min	.1524	.1753	.1753	.4096	.1753	.3429	.3429
Avg	.6890	.4065	.3696	.6902	.6361	.5934	.7943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 201 / WATER SUPPLY

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0347		.0347	.0171	.0347	.0171
2	.0343	.0343		.0347	.0171	.0347	.0171
3	.0343	.0343	.0343	.0347	.0171	.0347	.0171
4	.0343	.0347		.0347	.0171	.0347	.0171
5	.0343	.0347		.0347	.0171	.0347	.0343
6	.0343	.0343	.0171	.0347	.0171	.0351	.0514
7	.0343	.0343		.0351	.0171	.0347	.0514
8	.0343	.0347		.0351	.0343	.0173	.0343
9	.0343		.0343	.0175	.0343	.0173	.0171
10	.0876		.0343		.0343	.0347	
11	.0876		.0343	.0701	.0686	.0343	
12	.0701		.0343	.0686		.0171	.0343
13	.0701		.0351	.0514		.0171	.0526
14	.0701		.0701	.0686		.0343	.0351
15	.0701			.0514		.0343	.0526
16	.0693			.0686		.0343	.0526
17	.0701			.0686		.0171	.0351
18	.0693			.0686		.0171	
19	.0876		.0701	.0514	.0693	.0171	
20	.0876		.0701	.0171	.0693	.0171	.0351
21	.0693		.0701	.0171	.0693	.0171	
22	.0701		.0693	.0171	.052	.0171	.0351
23	.0686		.0347	.0171	.0526	.0171	.0526
24	.0343	.0343	.0343	.0347	.0171	.052	.0171
Max	.0876	.0347	.0701	.0701	.0693	.052	.0526
Min	.0343	.0343	.0171	.0171	.0171	.0171	.0171
Avg	.0579	.0345	.0459	.0420	.0365	.0273	.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 202 / PATHARWALA - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097					
2	.6859	.6097					
3		.6249					
4		.6249					
5		.6401					
6		.6554					
7		.6859					
8		.6706					
10						.9145	
11				.8383	1.1317	1.4575	
12				1.0288		1.5604	1.5432
13				1.0288		1.4403	1.4232
14			.7621	1.0802		1.4575	1.4685
15				1.0288		1.4575	
16				1.0631		1.4403	
17				1.0631		1.4232	
24	.6859	.6097					
Max	.6859	.6859	.7621	1.0802	1.1317	1.5604	1.5432
Min	.6859	.6097	.7621	.8383	1.1317	.9145	1.4232
Avg	.6859	.6368	.7621	1.0187	1.1317	1.3939	1.4783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 203 / S.PIMPLEGON AG 1

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.2193					
2	.9259	1.2498					
3	.9602	1.2803					
4	.9602	1.3565					
5	.9602	1.3717					
6	.9602	1.4632					
7	1.0288	1.5546					
8	1.0288	1.6309					
9	1.2346						
10						1.6766	
11			1.1584	1.829	1.989	2.1948	2.5377
12			1.1431	1.7147		2.572	
13						2.5034	
14						2.5034	
15						2.5034	2.3329
16						2.4691	2.4234
17						2.4863	2.4827
24	.8573	1.2498					
Max	1.2346	1.6309	1.1584	1.829	1.989	2.572	2.5377
Min	.8573	1.2193	1.1431	1.7147	1.989	1.6766	2.3329
Avg	.9842	1.3751	1.1508	1.7719	1.989	2.3636	2.4442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 204 / GINING

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0181	.0171	.0185	.0171	.0185	
2	.0171	.0179		.0185	.0171	.0185	.0171
3	.0171	.0179		.0185	.0171	.0179	.0171
4	.0171	.0179		.0185	.0171	.0179	.0171
5	.0171	.0181	.0171	.0181	.0171	.0185	.0171
6	.0171	.0183		.0183	.0171	.0185	.0171
7	.0171	.0183		.0173	.0171	.0179	.0171
8	.0171	.0183		.0183	.0171	.0185	.0171
9	.0171		.0171	.8764	.0171	.0185	.0171
10	.0185		.0171		.0171	.0185	
11			.0187	.0179	.0171	.0171	
12	.0185		.0185	.0171		.0171	.0171
13	.0185		.0185	.0171		.0171	.004
14	.0185		.0185	.0171		.0171	.0044
15	.0187			.0171		.0171	.004
16						.0171	.0034
17	.1524					.0171	.0032
18				.0171		.0171	
19	.0175		.0185	.0171	.0185	.0171	
20	.0175		.0185	.0171	.0185	.0171	.004
21	.0187		.0185	.0171	.0185	.0171	
22	.0187		.0183	.0171	.0185	.0171	.004
23	.0185		.0183	.0171	.0185	.0171	.0044
24	.0171	.0185	.0171	.0185	.0171	.0185	.0171
Max	.1524	.0185	.0187	.8764	.0185	.0185	.0171
Min	.0171	.0179	.0171	.0171	.0171	.0171	.0032
Avg	.0241	.0181	.0180	.0586	.0175	.0177	.0112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 205 / PATHARWALA(GAOTHAN)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.208		.2103	.2058	.1753	.2058
2	.2058	.208		.2103	.2058	.1753	.2058
3	.2058	.2774		.2454	.2229	.208	.2058
4	.2401	.3294		.3155	.2743	.2427	.2401
5	.3258	.3856		.3506	.3772	.3121	.3429
6	.3429	.4161		.3856	.4115	.3814	.4115
7	.3772	.4733		.4382	.3772	.3641	.463
8	.463	.3988		.4382	.3258	.3121	.4115
9	.3429			.3506	.2915	.3155	.3772
10	.2454					.2947	
11	.1753		.2103	.2629	.1715	.2572	
12				.1543			.2172
13				.1372			.1663
14			.1753	.1029			.168
15				.1029			.1478
16				.1372			.168
17				.1543			.2402
18	.2454			.1715		.3258	
19	.3506		.2804	.3258	.3506	.3772	
20	.4207		.4207	.2915		.3429	.3547
21	.3506		.3681	.2401		.3258	
22	.3155		.3506	.2058	.2427	.2401	.2614
23	.2103		.2427	.2058	.208	.2058	.1848
24	.2058	.2103		.208	.2058	.1753	.2058
Max	.463	.4733	.4207	.4382	.4115	.3814	.463
Min	.1753	.208	.1753	.1029	.1715	.1753	.1478
Avg	.2905	.3230	.2926	.2454	.2765	.2795	.2620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 206 / MAHAKALA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0457	.583	.8383	1.1145
2				.0457	.6173	.8383	1.2003
3				.0457	.6859	.8535	1.2346
4				.0457	.6859	.884	1.2689
5				.0457	.7202	.9145	1.3375
6				.0457		.884	1.3375
7				.0457		.945	1.3717
8				.0457			1.3375
9			.1543	.0457	.7716		1.3203
10	.6706						
11	.7621	.7716					
12	.7011	.823					
13	.6097	.8402					
14	.6097	.8573					
15		.8573					
24				.0457	.6001	.8383	1.0288
Max	.7621	.8573	.1543	.0457	.7716	.945	1.3717
Min	.6097	.7716	.1543	.0457	.583	.8383	1.0288
Avg	.6706	.8299	.1543	.0457	.6663	.8745	1.2552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 207 / SHAHAGAD GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8764	.8573		.8573	.8859	.8573
2	.8573	.8939			.8573	.8954	.8573
3	.9259	.9922	.8573		.8916	.9568	.8573
4	.9945	1.0631			.9945	1.0631	1.0288
5	1.0631	1.1283			1.0631	1.1641	1.166
6	1.1145	1.1871			1.0974	1.2894	1.2003
7	1.2003	1.3112	1.0631		1.166	1.3969	1.3375
8	1.2003	1.2757			1.0631	1.3611	1.1317
9	1.0288		1.0631	1.2269		1.2357	.9945
10	.815		.8916			1.1789	
11	.7522			.8764	1.2346	1.1145	
12	.7522			.8916		1.0631	1.0288
13	.7442					.9602	.9774
14	.7087			.7202		.9602	.8596
15	.7522			.6859		.9602	.8682
16				.7202			.8417
17				.823		.5487	1.2308
18	.0179			.8916			.8682
19	1.2269		1.0745	1.0288	1.2136	1.0974	
20	1.1218		1.2226	1.0974		1.0288	
21	1.0867		1.2536	1.0288		.9945	.905
22	1.2178		1.1283	.8573	.985	.9259	.905
23	.8859		.9465	.8916	.924	.8573	.7602
24	.8573	.8859	.8573	.9313	.8573	.8954	.8573
Max	1.2269	1.3112	1.2536	1.2269	1.2346	1.3969	1.3375
Min	.0179	.8764	.8573	.6859	.8573	.5487	.7602
Avg	.9126	1.0682	1.0196	.9051	1.0158	1.0379	.9766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 201 / SUKHAPURI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.4572				.4239
2	.6706	.4382				.4144
3	.663	.4239				.443
4	.763	.503				.4239
5	.8278	.4973				.5258
6	.9831	.5268				.6783
7	1.1288	.7526				.9335
8	1.2431					1.1088
9	.8478					.9335
10	.5544					.9945
11	.5087					
12	.4668					
13	.4668				1.4746	1.0536
14	.4572		1.1641		1.4918	1.2041
15					1.3927	.9783
16	.3734				1.4089	.9783
17	.5935				1.326	1.1393
18	.4515			.2801		.4239
19	.5735					
20	.5735				.5087	.5268
21	.5935				.5087	.5087
22	.4973				.5544	.4458
23	.4973				.4144	
24	.663	.5087				.3763
Max	1.2431	.7526	1.1641	.2801	1.4918	1.2041
Min	.3734	.4239	1.1641	.2801	.4144	.3763
Avg	.6555	.5135	1.1641	.2801	1.0089	.7257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 202 / BELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.5801			.6783
2	.4239	.5935			.6554
3	.4572	.6783			.823
4	.5087	.763			.8288
5	.5087	.8288			.8192
6	.5935	1.1022			.9116
7	.6783	1.4413			1.4089
8	.6135				1.5384
9	.5087				1.4918
10	.6401				.462
11	.823				
12	.7087				
13	.9326			.2772	.1867
14	.9116			.1848	.1848
15	.5935			.1867	.1848
16	.7545			.3734	.1848
17	.9145			.462	.1848
18	.4572		.3734		.3696
19	.5087				
20	.5087			.6468	.6468
21	.4973			.5544	.5087
22	.4144			.4973	.462
23	.4239			.4239	
24	.443	.5935			.6468
Max	.9326	1.4413	.3734	.6468	1.5384
Min	.4144	.5801	.3734	.1848	.1848
Avg	.5949	.8226	.3734	.4007	.6589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 203 / WADIKALYA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.4144			.4572
2	.3734	.4144			.4525
3	.3696	.4239			.4477
4	.3391	.4239			.4239
5	.4239	.5087			.4191
6	.5087	.5087			.4239
7	.3696	.6783			.5801
8	.2743				.6401
9	.1867				.5487
10	.3696				.1829
11	.4239				
12	.4477				
13	.4239			.0934	.1848
14	.5087			.1867	.0934
15	.3315			.1867	.0934
16	.443			.1848	
17	.5087			.1848	
18	.3734		.1867		.3734
19	.4239				
20	.4239			.4239	.4668
21	.4144			.462	.4668
22	.3315			.462	.3734
23	.3391			.3391	
24	.4748	.4239			.443
Max	.5087	.6783	.1867	.462	.6401
Min	.1867	.4144	.1867	.0934	.0934
Avg	.3926	.4745	.1867	.2804	.3928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 201 / HASNAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1684			.0572	.0572		.0343
2	.1684			.0572	.0572		
3	.1814			.0572			.0343
4	.2						
5	.2						
6	.23						
7	.2164						
8	.23						
9	.3923						
10					.381		.2984
11					.381		.4601
12							.5068
13					.5335		.5487
14				.3307			.6144
15				.447	.7716		.6602
16				.5546	.7716		.6371
17				.5898			.3839
18	.0514	.0381		.0953			.0572
19				.0762			.0762
20			.0572	.0762		.0343	.0762
21			.0572				.0762
22			.0572			.0351	
23			.0572			.0343	
24	.1278			.0381			.0343
Max	.3923	.0381	.0572	.5898	.7716	.0351	.6602
Min	.0514	.0381	.0572	.0381	.0572	.0343	.0343
Avg	.1969	.0381	.0572	.2163	.4219	.0346	.2999

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 202 / GHUNGARDE HADGAON AG
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.0762			.4287
2	.0381		.0762	.1886		
3	.0381		.0953	.2096		.567
4			.0953	.2305		
5			.1143	.2305		.6001
6			.1143	.2096		.7716
7			.1143	.1886		
8			.1143		.3414	.7716
9			.1334			
11	.4287					
13	.5487					
14	.6001					
16	.5144	.3353				
17	.4287	.3458				
18		.0381		.0381		.0381
19			.0572	.0381	.0343	.0381
20		.0381	.0572	.0381		.0381
21		.0381	.0572		.0343	.0381
22		.0381	.0572			.0381
23		.0381	.0572		.0343	
24	.0381	.0762		.1781	.0926	.4287
Max	.6001	.3458	.1334	.2305	.3414	.7716
Min	.0381	.0381	.0572	.0381	.0343	.0381
Avg	.297	.1185	.0871	.1550	.1074	.3417

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 204 / KARNJALA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086				
2	.1086				
5	.1511				
6	.1734				
7	.2202				
8	.2073				
9	.1511				
10			.2881	.4287	.4081
11		.1905	.3144		.5053
12		.2286		.5335	.7145
13		.2858			.8025
14		.3048	.2972	.8573	.9907
15			.3426		.9023
16			.643	1.1145	.9556
17			.7042		.8036
24	.0977				
Max	.2202	.3048	.7042	1.1145	.9907
Min	.0977	.1905	.2881	.4287	.4081
Avg	.1523	.2524	.4316	.7335	.7603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 201 / HARATHKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4763	.4049	.4763		.5716	.4858
2	.381	.4763	.421	.4763		.5716	.5001
3	.381	.4763	.4534	.4763		.6668	.7287
4	.4763	.4763	.5182	.4763		.7621	.8097
5	.5716	.4763	.5506	.5716		.7621	.8097
6	.7621	.4763	.6081	.5716		.9526	.7811
7	.5716	.6668	.6154	.8573	1.1431	1.1431	.8745
8	.381		.5281	.9526		1.1431	.8583
9	.381		.5441	.8573	1.1431	1.1431	.8097
10	.381				.2858	.2858	.1905
11			.1905	.0953	.1905	.1943	
12	.4763		.1905	.1905	.1905	.1619	
13	.381		.1905	.0953	.1905	.2401	.1905
14	.381		.1905	.0953	.1905	.192	.1905
15			.1905		.1905	.2721	
16	.4763		.1905		.1905	.2881	.1905
17	.381				.2858		.381
18	.381		.2858	.2858			
19	.381	.2429	.381	.4763	.4763		
20	.5716	.2591	.4763		.5716	.3521	.5716
21	.5716	.3239	.4763			.3563	.4763
22	.4763	.4049	.4763		.4763	.3401	.381
23	.4763	.4049	.4763		.4763	.3239	.381
24	.381	.4763	.4049	.4763		.5716	
Max	.7621	.6668	.6154	.9526	1.1431	1.1431	.8745
Min	.381	.2429	.1905	.0953	.1905	.1619	.1905
Avg	.4546	.4336	.3984	.4644	.4287	.5378	.5339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 202 / SHEVGA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381	.4534	.4763		.7621	.4534
2	.4763	.381	.4858	.5716		.7621	.4858
3	.4763	.4763	.5121	.6668		.7621	.5601
4	.4763	.4763	.5601	.7621		.9526	.6401
5	.5716	.5716	.6401	.7621			.8745
6	.8573	.5716	.7202	.7621			.9878
7	.7621	.7621	.8322	1.1431	1.2384		1.1174
8			.8802	1.1431		.9526	1.2631
9			.8907	1.1431	1.3336	1.1431	1.0526
10	.4763			.381	.2858	.381	.381
11	.5716		.1905	.2858	.2858	.2401	
12	.6668					.3239	
13	.7621			.1905		.3239	.1905
14	.5716			.1905		.3201	.2858
15	.5716					.3725	
16	.381					.3841	.2858
17	.4763				.2858		.381
18	.4763		.381	.381			
19	.5716	.3841	.5716	.6668	.5716		
20	.6668	.3841	.4763		.6668	.3725	.5716
21	.5716	.3521	.4763			.3725	.4763
22	.4763	.3563	.4763		.4763	.3563	.381
23	.4763	.3563	.4763		.4763	.3563	.381
24	.381	.381	.4161	.4763		.7621	.4534
Max	.8573	.7621	.8907	1.1431	1.3336	1.1431	1.2631
Min	.381	.3521	.1905	.1905	.2858	.2401	.1905
Avg	.5542	.4488	.5552	.6251	.6245	.5500	.5906

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 203 / DHANGAR PIMPRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858	.3201	.381		.1905	.3239
2	.381	.2858	.3201	.381		.2858	.3239
3	.381	.2858	.3201	.4763		.2858	.3239
4	.381	.381	.3841	.4763		.2858	.3239
5	.381	.381	.4161	.5716		.2858	.3563
6	.381	.5716	.4481	.5716		.2858	.4049
7	.4763	.7621	.4801	.5716	.6668	.381	.4534
8	.5716		.4858	.5716		.381	.502
9	.5716		.3521	.381		.1905	.4049
10	.2858			.4763	.8573		
11	.1905			.9526	1.1431	.8097	
12	.1905			1.0479	1.1431	.8745	
13	.1905		.5716	1.0479		.8097	1.1431
14	.1905		.5716	1.0479	1.3336	.9231	1.4289
15	.1905		.5716	1.0479	1.3336	.8907	
16	.1905		.6668	1.1431	1.3336	.9231	.7621
17	.1905		.5716		1.3336		1.3336
18	.381		.381	.2858			
19	.4763	.3887	.381	.4763	.2858		
20	.4763	.3201	.4763		.4763	.3563	.4763
21	.4763	.3239	.381			.3563	.381
22	.4763	.3239	.381		.381	.3239	.381
23	.4763	.3239	.381		.381	.3239	.381
24	.381	.2858	.3201	.381		.381	.3201
Max	.5716	.7621	.6668	1.1431	1.3336	.9231	1.4289
Min	.1905	.2858	.3201	.2858	.2858	.1905	.3201
Avg	.3612	.3784	.4372	.6468	.8891	.4772	.5569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134055 / SHEVGA

Feeder No / Name : 204 / DATA AGRO EXPRESS

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	25-JUL-17
HR	Load (MW)
19	.6668
Max	.6668
Min	.6668
Avg	.6668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 201 / 11 KV KARJAT-BHAYGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.5335	.6668	.6668	.4877	.5716
2		.4763	.5668	.6668	.6668	.4999	.5716
3		.4763	.5335	.6668	.6668	.5182	.5716
4		.4763	.5335	.6668	.7621	.4877	.6668
5		.5335	.5335	.6668	.7621	.703	.6668
6		.6097		.7621	.8573	.8383	.8573
7		.6668			.9907	1.0974	1.1431
8		.5335	.8383	.8573	1.2384	1.5242	1.4289
9			.9717			.3048	1.3336
10	.6668					.381	.381
11	.8573				.381	.381	
12	.9526			.381	.4191	.381	
13	.8573			.381		.381	.3429
14	.8573			.3429		.381	.3429
15	.8002				.381	.3239	.381
16	.7621			.3429	.4191	.4382	.381
17	.7621			.381	.4191	.4763	.4191
18	.4763	.4763		.4763	.4763	.5716	.4763
19	.5716	.6097		.5716	.6097	.8573	
20	.6668	.724		.6668	.724	.7621	.724
21	.724		.4763	.5716	.724	.6668	.6668
22	.6668		.4763	.5335	.6668	.5716	.5716
23	.5716		.4763	.5335	.5716	.5716	
24		.5716	.5335	.7621	.7621	.5335	.6668
Max	.9526	.724	.9717	.8573	1.2384	1.5242	1.4289
Min	.4763	.4763	.4763	.3429	.381	.3048	.3429
Avg	.7281	.5525	.5885	.5736	.6582	.5891	.6582

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 202 / 11 KV KARJAT-A

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953				
2	.0953				
3	.0953				
4	.0953				
5	.0953				
6	.1524				
7	.1905				
8	.2858				
10				.2858	
11			.1905	.2858	
12		.3429	.2286	.2858	
13		.381		.1905	.2286
14		.381		.1905	.2286
15			.2915	.1524	.2667
16		.2858	.2915	.1524	.2858
17		.3429	.2915	.1905	.2858
24	.0953				
Max	.2858	.381	.2915	.2858	.2858
Min	.0953	.2858	.1905	.1524	.2286
Avg	.1334	.3467	.2587	.2167	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134072 / KARJAT

Feeder No / Name : 203 / 11 KV DHANGAR PIMPALGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.381	.1905	.1905	.2858	.1905
2		.381	.381	.1905	.1905	.2858	.1905
3		.381	.381	.1905	.1905	.2858	.1905
4		.381	.381	.1905	.2858	.2858	.1905
5		.4191	.4191	.1905	.3429	.3429	.2858
6		.4191	.4763	.2858	.381	.381	.3429
7		.4763	.4763	.4763	.4763	.4763	.381
8		.6097	.4763	.4763	.4763	.4763	.381
9			.381			.381	.2858
10	.381					.7621	
11	.2858				.4572	.6668	
12	.1905			.5335	.4877	.6668	
13	.1524			.5716		.5716	.5716
14	.1524			.5716		.5716	.5335
15	.1524				.5182	.6668	.5716
16	.1524			.4763	.5335	.5716	.6097
17	.1905			.5335	.5182	.381	.6097
18	.2286	.1905		.2858	.381	.381	.2858
19	.2858	.2858		.3429	.4763	.381	
20	.381	.381	.1905	.381	.5335	.381	.4763
21	.4763	.4763	.1905	.381	.5335	.381	
22	.381	.4763	.1905	.2858	.4763	.2858	
23	.2858	.381	.1905	.2858	.4191	.2858	
24		.381	.381	.1905	.2858	.3429	.2858
Max	.4763	.6097	.4763	.5716	.5335	.7621	.6097
Min	.1524	.1905	.1905	.1905	.1905	.2858	.1905
Avg	.2640	.4013	.3497	.3515	.4077	.4374	.3754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409]

BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 201 / CHANDANAPURI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3018		.2572		.3258	.2614
2	.3395	.3395		.3258		.3944	.3361
3	.4108	.3772		.3601		.463	.4108
4	.4854	.4854		.3944		.5144	.4854
5	.5601	.5975		.4458		.5658	.5601
6	.7468	.7842		.583		.6173	.7842
7	.7095	.7095		.7545		.5658	.7468
8	.7095	.7095				.6516	.6722
9	.5975					.5316	
10	.3734					.4458	
11	.2801		.3086		.3258	.4854	
12	.2241		.2743		.2743	.4854	.1715
13	.2241		.2401		.2229	.2241	.1372
14	.2241				.2058	.4108	.1219
15					.1543	.4108	
16				.2401		.4481	.1543
17	.3734			.2743		.3734	.2915
18	.4108			.2915		.4481	.4115
19	.5601		.583	.463	.6173	.4108	
20	.5975		.6173	.583	.5316	.4481	.463
21	.4854		.5487	.4973	.4801	.3361	.3429
22	.3361		.4458	.3601	.3258	.2987	.2572
23	.3361		.3429	.3086	.3086	.2987	.2401
24	.3395	.2987		.3086		.2572	.2614
Max	.7468	.7842	.6173	.7545	.6173	.6516	.7842
Min	.2241	.2987	.2401	.2401	.1543	.2241	.1219
Avg	.4392	.5115	.4201	.4030	.3447	.4338	.3742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 202 / BHAMBERI-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7907
2					.9488
3					.9488
4					1.1203
5					1.2003
6					1.3123
7					1.4403
8					1.4723
10	1.1702				
11	1.4232	1.1603		1.1469	
12	1.4232	1.2003		1.2003	
13	1.3916	1.267		1.1469	
14	1.4232			1.1203	
15				1.1603	
16	1.2651		1.1603		
17	1.186		1.1869		
24					.7907
Max	1.4232	1.267	1.1869	1.2003	1.4723
Min	1.1702	1.1603	1.1603	1.1203	.7907
Avg	1.3261	1.2092	1.1736	1.1549	1.1138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 203 / CHURMAPURI-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3963	.3795
2					.442	.3795
3					.4268	.4161
4					.4572	.4111
5					.4877	.4481
6					.5182	.4801
7					.5487	.5218
8					.4877	.6722
9					.4725	
10	.4744					
11	.5376	.6401		.7468		
12	.5535	.6859		.6554		
13	.5535	.7468		.6554		
14	.5376			.6249		
15				.6706		
16	.4744		.5335			
17	.6325		.5468			
24					.442	.3795
Max	.6325	.7468	.5468	.7468	.5487	.6722
Min	.4744	.6401	.5335	.6249	.3963	.3795
Avg	.5376	.6909	.5402	.6706	.4679	.4542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 201 / 11KV BOLEGAON FDR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573		.2572	.5716	.3429	.5716	.5716
2	.8573		.2572	.5716	.3429	.381	.5716
3	.8573		.3429	.5716	.3429	.381	.5716
4	.8573		.3429	.5716	.5144	.5716	.5716
5	.8573		.3429	.5716	.5144	.5716	.5716
6	1.2003		.3429	.7621	.5144	.9526	.7621
7	1.3717		.2572	.7621	.4287	.9526	.9526
8	1.3717		.3429	.7621		.9526	.9526
9	1.3717		.3429	.5716		.7621	.5716
10	.381					1.1431	1.0288
11	.381		1.0288		1.1431		
12	.381		1.2003	.8573	1.3336		1.5242
13			1.2003	.6859		1.5432	1.5242
14			1.3717	.6859		1.3717	1.5242
15	.381		.3429	.6001	1.9052	1.3717	1.3336
16	.381		1.3717	.5144	1.5242	1.3717	1.3336
17	.381			.6859	1.7147	1.2003	1.5242
18	.5716		.5716	.2572		.381	.5716
19	.7621	.3429	.7621	.3429	.7621		.7621
20	.9526	.3429	.9526	.3429	.9526	.7621	.9526
21	.9526	.3429	.9526	.3429	.7621	.7621	.7621
22	.7621	.3429	.7621	.3429	.7621	.7621	.5716
23	.7621	.2572	.5716	.3429	.5716	.5716	.5716
24	.6859	.9526	.2572	.5716	.3429	.5716	.5716
Max	1.3717	.9526	1.3717	.8573	1.9052	1.5432	1.5242
Min	.381	.2572	.2572	.2572	.3429	.381	.5716
Avg	.7880	.4302	.6443	.5586	.8208	.8528	.8980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 202 / 11KV MCHINCHOLI FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.7716	1.0288	1.0288	.9526	1.0288
2	.7621		.8573	1.0288	1.0288	1.1431	1.0288
3	.7621		.8573	1.0288	1.1145		1.0288
4	.7621		.8573	1.0288	1.2003	1.1431	1.0288
5	.7621		.8573	1.2003	1.3717	.9526	1.2003
6	.9526		1.0288	1.3717	1.5432	1.1431	1.3717
7	1.1431		1.2003	1.7147	2.2291		2.0576
8	1.1431		1.2003	1.7147			2.4006
9			1.3717	1.7147		1.9052	2.2291
10	1.2003					.9526	1.1431
11	1.5242		.7621		.5716		
12	1.7147		.5716	.6001	.5716		.5716
13			.5716	.6001		1.1431	
14			.5716	.5144		1.0479	.5716
15	1.5242		.5716	.4287	.5716		.5716
16	1.5242		.5716	.3429	.5716	.9526	.5716
17				.3429	.7621	.9526	.7621
18			.7621	.5144		1.0479	.9526
19	.5716	1.2003	1.0479	1.0288	1.1431		.9526
20	.7621	1.2003	1.1431	1.0288	1.2384	1.1431	1.2384
21	.7621	.8573	1.1431	1.0288	1.2384	1.1431	1.2384
22	.7621	.8573	.9526	.9431	.9526	.9526	.9526
23	.5716	.7716	.7621	.8573	.9526	.9526	.9526
24	.7621	.5716	.7716	1.0288	1.0288	1.3336	1.0288
Max	1.7147	1.2003	1.3717	1.7147	2.2291	1.9052	2.4006
Min	.5716	.5716	.5716	.3429	.5716	.9526	.5716
Avg	.9857	.9097	.8729	.9587	1.0622	1.1095	1.1310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 203 / 11KV GHANSAWANGI FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288		.8573	.7621	.6859	.9526	.6668
2	1.0288		.8573	.7621	.6859	.9526	.6668
3	1.0288		.8573	.7621	.6859	.9526	.6668
4	1.0288		.8573	.7621	.6859	1.1431	.6668
5	1.0288		.8573	.9526	.8573	1.1431	.7621
6	1.3717		.9431	1.1431	1.0288	1.2384	.9526
7	1.7147		1.2003		1.1145	1.2384	1.1431
8	1.7147		1.1145	.9526		1.2384	1.3336
9	1.6289			.8573		.9526	
10	.9526					1.7147	1.5432
11	.9526		1.5432		2.0957		
12	1.1431		1.5432	1.0288	2.2862		1.5242
13			1.5432	.6859		1.8861	1.7147
14			1.3717			1.7147	1.9052
15	.9526		1.3717	1.0288	2.4768	1.7147	2.2862
16	.7621		1.5432	1.8861	2.0957	1.7147	2.2862
17	.9526			2.0576	2.0957	1.7147	1.9052
18	1.1431		.9526			.9526	.9526
19	1.1431	1.1145	1.0479	1.0288	1.1431		1.1431
20	1.1431	1.1145	1.1431	1.1145	1.2384	.9526	1.2384
21	.9526	1.0288	1.1431	1.0288	1.2384	.9526	1.2384
22	.7621	.8573	.9526	1.0288	1.1431	.7621	1.1431
23	.7621	.8573	.7621	.8573	.9526	.6668	1.1431
24	.7716	.9526	.7716	.7621	.6001	1.3336	.6668
Max	1.7147	1.1145	1.5432	2.0576	2.4768	1.8861	2.2862
Min	.7621	.8573	.7621	.6859	.6001	.6668	.6668
Avg	1.0894	.9875	1.1064	1.0243	1.2839	1.2329	1.2522

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 204 / 11KV TANUWADI FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.5144	.6859	.5144	.7621	.6859
2	.381		.5144	.6859	.5144	.7621	.6859
3	.381		.5144	.6859	.5144	.9526	.6859
4	.381		.5144	.6859	.6859	.9526	.6859
5	.381		.6859	.6859	.6859	.9526	.6859
6	.381		.6859	.8573	.6859	1.1431	.8573
7	.5716		.6859	.8573	.5144	1.1431	1.0288
8	.5716		.6859	.8573		1.3336	1.0288
9	.5716		.6859	.8573		.9526	1.0288
10	.6859						.5716
11	.9526		.381		.381		
12	.9526		.381	.3429	.5716		.5716
13			.381	.3429		.5716	.5716
14			.381	.3429		.5716	.5716
15	.9526		.381	.3429	.5716	.5716	.5716
16	.9526		.381	.3429	.5716	.5716	.5716
17	.9526			.3429	.5716	.5716	.5716
18	.5716		.5716	.3429		.7621	.5716
19	.5716	.3429	.5716	.3429	.5716		.7621
20	.5716	.3429	.5716	.4287	.5716	.7621	.7621
21	.5716		.5716	.3429	.5716	.5716	.5716
22	.5716	.3429	.5716	.2572	.5716	.5716	.5716
23	.5716	.2572	.381	.2572	.5716	.5716	.5716
24	.381	.5716	.5144	.5144	.5144	.5716	.6859
Max	.9526	.5716	.6859	.8573	.6859	1.3336	1.0288
Min	.381	.2572	.381	.2572	.381	.5716	.5716
Avg	.6027	.3715	.5239	.5183	.5642	.7812	.6900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134009 / GHANSAWANGI

Feeder No / Name : 205 / 11 KV BOLEGAON 2

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.3429	.381	.1715	.1905	.381
2	.6859		.3429	.381	.1715	.1905	.381
3	.6859		.3429	.381	.1715	.2858	.381
4	.6859		.3429	.381	.3429	.2858	.381
5	.6859		.3429	.381	.5144	.381	.381
6	.8573		.6001	.5716	.6001	.381	.5716
7	1.0288		.5144	.6668	.5144	.381	.6668
8	1.1145		.5144	.5716		.381	.5716
9	1.1145		.3429	.4763			.4763
10	.381						.8573
11	.381		.7716		1.3336		
12	.381		1.0288	1.0288	1.3336		1.1431
13			1.0288	.9431		1.0288	1.1431
14			.9431	.9431		.8573	.9526
15	.1905		1.0288	.7716	1.1431	.8573	.9526
16	.1905		.9431	.9431	1.2384	.8573	.9526
17	.381			.9431	1.2384	.8573	.9526
18	.381		.381	.2572		.381	.381
19	.5716	.3429	.7621	.3429	.381		.381
20	.5716	.3429	.7621	.3429	.381	.5716	.5716
21	.381	.3429	.7621	.3429	.381	.5716	.381
22	.2858	.3429	.5716	.2572	.381	.5716	.381
23	.2858	.1715	.381	.2572	.2858	.381	.381
24	.5144	.7621	.3429	.381	.1715	.2858	.381
Max	1.1145	.7621	1.0288	1.0288	1.3336	1.0288	1.1431
Min	.1905	.1715	.3429	.2572	.1715	.1905	.381
Avg	.5655	.3842	.6088	.5430	.5975	.5104	.6088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 201 / 11KV R.U.GAON-AG FDR
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.462	.5601
2			.462	.5601
3			.5487	.5601
4			.6219	.7468
5			.724	.8402
6				1.0269
7			1.2269	1.1203
8			1.286	1.307
9				1.4003
10	.4668	.4668		1.4937
11	.4344	.5601		
12	.5175	.7468		
13	.6348	.9335		
14	.5249	1.1203		
15		1.1203		
16	.6878	1.307		
17	.6535	1.307		
24			.4066	.3734
Max	.6878	1.307	1.286	1.4937
Min	.4344	.4668	.4066	.3734
Avg	.5600	.9452	.7173	.9081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 202 / 11KV PANEWADI-AG FDR
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.06				
2	.1494	.0686				
3	.1307	.1195				
4		.1326				
5	.1867	.1029				
6	.2427	.1139				
7	.2801	.1015				
8	.3361	.1029				
9	.3696					
10			.1494		.1867	
11			.1867	.0412	.2801	
12			.1867	.0667	.2801	
13			.2241	.0732	.2801	
14			.2801	.0734	.2801	
15			.2801	.0823	.2801	.4251
16			.2801	.1086	.3734	.4251
17			.2801	.1086	.3734	.3696
24	.1867	.0777				
Max	.3696	.1326	.2801	.1086	.3734	.4251
Min	.1307	.06	.1494	.0412	.1867	.3696
Avg	.2299	.0977	.2334	.0791	.2918	.4066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 203 / 11KVTALEGOAN-AG FDR

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.462	.5601
2			.462	.5601
3			.499	.7468
4			.5487	.9335
5			.5487	1.307
6			.6401	1.4937
7			.7164	1.6804
8			.7602	2.0538
9				1.6804
10		.7468		
11		1.1203		
12		1.2136		
13	.4668	1.2136		
14	.5068	1.2136		
15	.5041	1.1203		
16	.4887			
17	.5068			
24			.4435	.5601
Max	.5068	1.2136	.7602	2.0538
Min	.4668	.7468	.4435	.5601
Avg	.4946	1.1047	.5645	1.1576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 204 / 11KV SHINDEWADGAON-AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4477			
2	.5487	.362			
3	.5487	.4668			
4	.6767	.4409			
5	.724				
6	.7602	.8402			
7	.8145	.7655			
8	.724	.8688			
9	.6401				
10			.8145		.5601
11			.8764	.7655	.9335
12			1.1203	1.1273	1.1203
13			1.0974	.8688	1.2136
14			1.1145	.9709	1.1203
15			1.1145		1.2136
16			.9945	1.1576	1.2136
17			.9114	1.2696	1.1203
24	.4251	.3921			
Max	.8145	.8688	1.1203	1.2696	1.2136
Min	.4251	.362	.8145	.7655	.5601
Avg	.6324	.573	1.0054	1.0266	1.0619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 205 / RUGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.5121		.3696		.4668
2	.3696	.4748		.3696		.4668
3	.4251	.4409		.4251		.5601
4	.499	.5601		.499		.5601
5	.5853	.567		.6401		.6535
6	.695	.5611		.7164		.7468
7	.6584	.5068		.788		.8402
8	.5487	.6154		.695		.7468
9	.462					.7468
10	.3401	.5601			.7468	.6535
11	.3725	.4668	.5487		.5601	
12		.4668	.462		.4668	
13		.4668	.3361		.4668	
14		.4668	.3361		.4668	
15		.5601	.3696		.3734	.3361
16		.5601	.3696	.4049	.3734	.3696
17	.4525	.6535	.4251		.4668	.4251
18	.5068		.3881		.5601	.5487
19	.543				.5601	.6401
20	.5611				.4668	
21	.5415		.5853		.4854	.5487
22	.4706		.5487		.4294	.567
23			.5175		.4481	.5487
24	.4066	.4481		.462		.4668
Max	.695	.6535	.5853	.788	.7468	.8402
Min	.3401	.4409	.3361	.3696	.3734	.3361
Avg	.4893	.5228	.4443	.5370	.4908	.5733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 206 / SHINDEWADGAON GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3658		.3696		.3734
2	.4108	.39		.3696		.3734
3	.462	.4163		.4251		.4668
4	.5487	.4917		.5487		.5601
5	.6584	.6535		.6401		.5601
6	.724	.7059		.7164		.6535
7	.6401	.6878		.7164		.7468
8	.5175	.6348		.6401		.6535
9	.4251					.6535
10	.213	.4668			.5601	.5601
11	.3077	.3734	.3361		.5601	
12	.3361	.2801	.2801		.4668	
13	.3361	.2801	.2614		.4668	
14	.3174	.2241	.2614		.4668	
15	.3881	.2241	.2987		.3734	.2801
16	.3258	.2801	.3361		.3734	.3696
17	.3113	.3734	.3361		.4668	.4066
18	.3734		.462		.5601	.4805
19	.3801				.5601	.5487
20					.4668	.5853
21	.3881		.5487		.4108	.6401
22	.3439		.5853		.4108	.5487
23			.462		.4108	.462
24	.3696	.3801		.3881		.3734
Max	.724	.7059	.5853	.7164	.5601	.7468
Min	.213	.2241	.2614	.3696	.3734	.2801
Avg	.4158	.4252	.3789	.5349	.4681	.5148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 207 / TALEGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2883		.2987		.1867
2	.2987	.2328		.3361		.1867
3	.3361	.3258		.3696		.1867
4	.4066	.3761		.3696		.1867
5	.5175	.3696		.462		.2241
6	.5487	.3077		.499		.2614
7	.4805	.3077		.5487		.2801
8	4.2135	.298				.2241
9						.1867
10	.2801	.2591			.2801	.1867
11		.1867	.2801		.1867	
12		.112	.1867		.1867	
13	.213	.1867			.1494	
14	.3045	.2801	.1307			
15	.3326	.2801	.1494		.1494	.1307
16	.2915	.2801			.1867	.1867
17	.2896	.3734	.2427		.2801	.4668
18	.2374	.3734	.2801		.3734	.3361
19	.3258				.3734	.462
20	.3077				.2241	.5175
21	.2686		.462		.1494	.5487
22	.2883		.3696		.1494	.3696
23			.2987		.1307	.5487
24	.2801			.2987		.1867
Max	4.2135	.3761	.462	.5487	.3734	.5487
Min	.213	.112	.1307	.2987	.1307	.1307
Avg	.5250	.2846	.2667	.3978	.2169	.2932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 208 / PANEWADI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0091		.0373		.112
2	.056	.0309		.0373		.112
3	.056	.0095		.056		.112
4	.056	.02		.056		.1307
5	.0934	.029		.0934		.1307
6	.112	.0312		.0934		.1494
7	.0934	.0223		.056		.168
8	.0934	.016		.056		.1494
9	.0747	.0111				.0934
10		.056			.0934	.056
11	.02	.056	.056		.0934	
12	.0145	.056	.056		.0747	
13	.0166	.056	.0373		.0747	
14	.0137	.056	.0373		.0747	
15		.0373	.0373		.0747	.056
16	.02	.0373	.056		.0747	.056
17	.02	.0934	.056		.056	.0934
18	.0194	.0934	.0934		.0934	.0934
19	.0274				.0934	.112
20	.0343				.1307	.112
21	.0274		.112		.1494	.0747
22	.02		.056		.1494	.0747
23			.056		.1494	.056
24	.0747	.0095		.056		.112
Max	.112	.0934	.112	.0934	.1494	.168
Min	.0137	.0091	.0373	.0373	.056	.056
Avg	.0476	.0384	.0594	.0602	.0987	.1027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 209 / 11KV EXPRESS FEEDER UTTARA

HV Non-Express Feeder

FOO Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0053		.0373			.0187
2	.0373	.0048		.0373			.0187
3	.0373	.005		.0373			.0187
4	.0373	.0044		.0373			.0187
5	.0373	.0099		.0373			.0373
6	.0373	.0107		.0373			.0373
7	.0373	.0055		.0373			.0373
8	.0373	.0044		.0373			.0373
9	.0373	.0111			.0053		.0187
10	.0088					.0187	.0187
11	.0044	.0187	.0187			.0187	
12	.0133	.0187	.0187			.0187	
13	.0118	.0187	.0187			.0187	
14	.0118	.0187	.0373			.0187	
15	.0095	.0187	.0373			.0187	.0187
16	.0107	.0187	.0373			.0187	.0187
17	.0048	.0187	.0373			.0187	.0187
18	.0048	.0187	.0373			.0187	.0187
19	.0118					.0187	.0187
20	.0095					.0373	.0747
21	.0107		.0373			.0373	.0187
22	.0099		.0373			.0373	.0187
23	.0055		.0373			.0373	.0187
24	.0373	.0048		.0373			.0187
Max	.0373	.0187	.0373	.0373	.0053	.0373	.0747
Min	.0044	.0044	.0187	.0373	.0053	.0187	.0187
Avg	.0208	.0120	.0322	.0373	.0053	.0240	.0252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 201 / RAMASGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.3048		.8002	.9526
2		.381	.3429		.8002	.9717
3		.4382	.381		.8002	.9335
4		.4572	.4572		.8383	.9526
5		.4763	.5335		.8573	.9717
6		.5144	.5525		.9335	1.1431
7		.5335	.7049		1.0669	1.1812
8		.6097	.6668		1.2193	1.2384
9			.8002		1.2384	1.3146
15	.1143					
17	.5335					
24			.3048	.8764	.8002	.9907
Max	.5335	.6097	.8002	.8764	1.2384	1.3146
Min	.1143	.381	.3048	.8764	.8002	.9335
Avg	.3239	.4739	.5049	.8764	.9355	1.0650

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 202 / 11KV KANDARI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.9526		2.0195	1.8099
2		.9145	.9907		2.0195	1.7909
3		1.0288	1.0288		2.0195	1.8671
4		1.105	1.1431		2.0195	1.9052
5		1.105	1.1431		2.0767	1.9433
6		1.1431	1.2384		2.21	2.1338
7		1.2955	1.5242		2.4006	
8		1.3527	1.5623		2.5339	.9907
9	1.2765		1.6194		2.6673	.9907
10	1.3717					
11	1.3717					
12	1.3336					
13	.3239					
14	.5716					
15	.6859					
17	1.3336					
24			.8573	1.7909	2.0195	1.6766
Max	1.3717	1.3527	1.6194	1.7909	2.6673	2.1338
Min	.3239	.8573	.8573	1.7909	2.0195	.9907
Avg	1.0336	1.1002	1.2060	1.7909	2.1986	1.6787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 204 / 11KV Industrial FDR BALAJI HV Non-Express Feeder
OIL Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0381		.0572	.0572
2	.0572	.0762	.0381	.0381		.0762	.0762
3	.0381	.0953	.0381	.0381		.0572	.0762
4	.0762	.0953	.0572	.0381		.0762	.0953
5	.0572	.1715	.0762	.0762		.0762	.0762
6	.0762	.0953	.0953	.0953		.0953	.0953
7	.0953	.1524	.0953	.0953		.0762	.1143
8	.1524	.1334	.0953	.0953		.0953	.1334
9	.0953		.1143			.1524	.1334
10	.0953		.0762	.1715		.1143	.0953
11	.0762		.1143	.0953	.0762		.0953
12	.0762		.1143	.0762	.0762		.0762
13	.0762		.0953	.0953	.0762		.0953
14	.0572	.0762	.0953	.0762		.0762	
15	.0762	.0762	.0953	.1143		.0762	
16	.0572	.0572	.0762	.0953		.0762	.0953
17	.0762	.0572	.0762	.0953		.0762	.0953
18	.0572	.0762	.0572	.0572			.0762
19	.0572	.0953	.0572	.0381		.0762	
20	.0953	.1143	.0572	.0762		.0762	.0953
21	.0762	.0762		.0953	.0762		.0572
22	.0762	.0762	.0572	.0762	.0572	.0572	.0572
23	.0762	.0572	.0572	.0572	.0572	.0762	.0572
24	.0762	.0572	.0762	.0381	.0381	.0572	.0762
Max	.1524	.1715	.1143	.1715	.0762	.1524	.1334
Min	.0381	.0572	.0381	.0381	.0381	.0572	.0572
Avg	.0762	.0913	.0779	.0771	.0653	.0802	.0871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134027 / TIRTHPURI

Feeder No / Name : 207 / 11KV Tirthpuri Gaothan FDR
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5716	.6097	.6097		.6478	.6287
2	.6287	.6097	.6478	.6859		.6287	.6097
3	.724	.7049	.724	.8002		.6478	.6859
4	.8192	.9145	1.1431	.9717		.724	.7811
5	1.0098	1.1241	1.2955	1.1431		1.0288	1.0288
6	1.5623	1.4861	1.5242	1.2955		1.4861	1.3717
7	1.6004	1.5813	1.3336	1.5432		1.5242	1.6004
8	.5716	1.4289	1.1812	1.2955		1.5623	1.448
9	1.2003		1.0669	1.1812		1.3717	1.3527
10	.9145		.8383	1.0288		1.2193	1.086
11	.6097		.6097	.7811			.7621
12	.5716		.5906	.7621		1.0098	.6478
13			.6097	.7049		.8383	.6668
14	.6478	.6478	.6097	.6287		.7621	
15	.724	.6097	.6478	.6478		.724	
16		.724	.7049	.6478		.743	.5716
17	.8573	.8573	.8002	.743		.7811	.8764
18	.8954	1.1812	.8573	.8573			.9526
19	1.105	1.0669	1.0288	1.105		1.1812	
20	1.0288	.8383	.9717	.9907		1.0669	.9907
21	.7621	.8002	.8383	.8954	1.0288	.8573	.7811
22	.6287	.724		.7621	.8002		.6859
23	.5716	.6859	.6097	.6478	.6668	.6478	.6097
24	.5906	.5525	.6478	.5716	.6097	.6287	.6097
Max	1.6004	1.5813	1.5242	1.5432	1.0288	1.5623	1.6004
Min	.5716	.5525	.5906	.5716	.6097	.6287	.5716
Avg	.8461	.9005	.8648	.8875	.7764	.9562	.8927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 201 / 11KV Deodi Hadgaon SP FDR Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.381	.298	.381	.3506	.3506	.3856
2	.5144	.4763	.2629	.381	.3856	.3155	.4207
3	.7621	.4763	.2804	.4763	.4207	.3506	.4207
4	.8573	.4763	.3155	.4763	.4207	.4557	.4557
5	.8573	.5716	.3856	.5716	.4207	.5258	.5258
6	1.0288	.5716	.4115	.5716	.5144	.5144	.5487
7	1.0288	.5716	.4801	.5716	.583	.4801	.583
8	1.1145	.5716	.4115	.5716	.5487	.5144	.5487
9	1.2003			.4763		.5144	.5144
10	.4763					.8916	1.0288
11	.4763		.6668	.823	1.0974		
12	.381			.8573	1.2689	1.0288	1.3717
13	.2858		.9526	.9724		.9431	
14			.9526	1.0059		.9054	
15	.381		.9526	.8383	1.2071	.8048	
16	.381		.8573	.7888	1.1065	.6516	.9431
17	.2858			.8916	1.3717	.9259	1.0288
18	.2858		.381	.4207		.3772	.4801
19	.2858	.3155	.381	.4557	.5609	.3856	
20	.2858	.3856	.381	.3856	.5258	.3155	.3856
21	.2858	.3155	.381	.3506	.3856	.3506	.3856
22	.2858	.333	.381	.3506	.3856	.3856	.3506
23	.2858	.3155	.381	.3506	.3506	.3506	.3506
24	.4763	.381	.2804	.381	.3506	.3155	.3506
Max	1.2003	.5716	.9526	1.0059	1.3717	1.0288	1.3717
Min	.2858	.3155	.2629	.3506	.3506	.3155	.3506
Avg	.5562	.4387	.4897	.5804	.6450	.5501	.5831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 202 / 11KV Dhakefal SP FDR
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858	.4557	.5716	.5959	.7011	.6661
2	.381	.2858	.4908	.7621	.5959	.7011	.6516
3	.381	.381	.5609	.9526	.631	.7888	.7011
4	.381	.381	.5959	1.1431	.7011	.8764	.823
5	.4763	.4763	.6516	1.1431	.8413	.8916	1.0631
6	.4763	.4763	.7545	1.1431	1.0631	1.3717	1.4575
7	.4763	.4763	.7888	1.2384	1.2346	1.7147	1.7147
8	.4763	.381	.7202	1.2384	1.3717	1.5432	1.7147
9	.4763			1.2384		1.286	1.8519
10	.381					.6173	.6173
11			.2858	.4801	.5144		
12			.2858		.4458	.5487	
13						.5487	
14			.2858			.4694	
15	.7621		.2858		.3018	.503	
16			.2286		.5144	.6173	.5487
17	.381			.4557	.6516	.7545	.6859
18			.3429			.8573	.6516
19	.2858	.5959	.3429	.7712	.8413	.8413	.7011
20	.2858	.4557	.2858	.8063	.8413	.8063	.7011
21	.2858	.3506	.2858	.6661	.8413	.7362	.7011
22	.2286	.3506	.2858	.5959	.7011	.6661	.5959
23	.2286	.3856	.2858	.5959	.6661	.631	.6135
24	.2858	.2858	.4207	.4763	.5609	.631	.631
Max	.7621	.5959	.7888	1.2384	1.3717	1.7147	1.8519
Min	.2286	.2858	.2286	.4557	.3018	.4694	.5487
Avg	.3906	.3977	.4320	.8399	.7323	.8306	.8995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134056 / DEODI HADGAON

Feeder No / Name : 203 / 11KV Avalgaon AG FDR
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2858					
5		.5716					
6		.7621					
7		.9526					
8		.9526					
9	.7621						
10						.583	.6859
11				.823	.9602		
12				.8916	.8573	.4458	.7716
13				.8048		.4458	
14			.7621	.8383		.4862	
15			.7621	.7042	.7377	.57	
16			.6668	.7716	.8718	.6859	.7545
17				.7716	.9259	.6344	.7545
24	.1524	.2858					
Max	.7621	.9526	.7621	.8916	.9602	.6859	.7716
Min	.1524	.2858	.6668	.7042	.7377	.4458	.6859
Avg	.3683	.6351	.7303	.8007	.8706	.5502	.7416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 201 / 11 KV SADEGAON AG FDR

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4268	.503	.4877	.5304	.5898
2		.4115	.5197	.5487	.5636	.639
3		.3963	.4973		.5967	.6962
4		.3963	.5304		.6299	.7712
5		.4115	.5636			.7865
6		.5487	.3978			.8848
7		.6173	.4973			.9503
8		.6687	.5636			.9175
9			.6299			.9503
10	.5487					
11	.7716					
12	.7716					
13	.7716					
14	.7545					
15	.7545					
16	.7202					
17	.703					
24		.4268	.4973	.442	.4973	.5801
Max	.7716	.6687	.6299	.5487	.6299	.9503
Min	.5487	.3963	.3978	.442	.4973	.5801
Avg	.7245	.4782	.5200	.4928	.5636	.7766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 202 / 11KV SadegaoN Gaothan

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2439	.4694		.2743	.431	.4588
2	.3429	.2743	.4973		.3048	.4694	.4915
3	.3772	.3201	.5304			.5243	.5304
4	.463	.3963	.6299			.663	.6554
5	.6344	.5144	.8951				.7956
6	.703	.6516	1.1105				.9175
7	.7373	.7373	.7459				.9831
8	.3353	.6687	.5967				.852
9	.2743		.5304				.7209
10	.1524		.3048	.3353			
11	.1067		.2439	.1829		.4588	
12	.1524		.1829			.3932	
13			.1829		.2652	.426	
14	.1677		.1981	.1677	.2984	.4588	
15	.1829		.2286	.1524	.3812	.4915	
16			.2134	.1524	.431	.5407	.2439
17	.2286		.3086		.431	.4915	.2896
18	.3506	.5304	.5487		.6036	.5735	.4801
19	.4973	.7377	.703		.8383		.6516
20	.5316	.6706	.4458		.7042	.5243	.6001
21	.3353	.5365	.3772		.5868	.4973	.5658
22	.2743	.4694	.3429		.5365	.4973	.4801
23	.2591	.4359	.2915		.4694	.4694	.4458
24	.2915	.2439	.3978		.2896	.4024	.4475
Max	.7373	.7377	1.1105	.3353	.8383	.663	.9831
Min	.1067	.2439	.1829	.1524	.2652	.3932	.2439
Avg	.3495	.4954	.4573	.1981	.4582	.4890	.5894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134066 / SADEGAON

Feeder No / Name : 203 / 11KV Gangachincholi AG

Ag dominated/Pure Ag

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915					
2	.3258					
3	.3258					
4	.3601					
5	.4115					
6	.4458					
7	.4801					
8	.4725					
9	.503					
10		.6859	.7773		.9945	
11		.823	1.0212	.8848	1.3108	
12		.884		1.1603	1.3763	
13		.884		.9945	1.3927	
14		.884	.9297	1.1437	1.3108	
15		.8688	.9755	1.1934	1.2452	
16		.8688		1.2597	1.1469	.823
17		.9602		1.2597	1.1961	.8078
24	.2401					
Max	.503	.9602	1.0212	1.2597	1.3927	.823
Min	.2401	.6859	.7773	.8848	.9945	.8078
Avg	.3856	.8573	.9259	1.1280	1.2467	.8154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 201 / Limboni Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619						
2	.1619						
3	.1619						
4	.2429						
5	.2429						
6	.2915						
7	.3239						
8	.3239						
9	.4049						
10						.4858	.4858
11			.421	.4858	.5182	.4858	.6478
12		.1619			.583	.583	.6478
13			.3887	.3239		.4858	.7287
14			.4049	.4534		.4858	.7287
15			.4372	.4858		.583	.7287
16			.2429	.4858		.5182	
17			.4049	.4534		.5182	.7287
19						.1296	
24	.1619						
Max	.4049	.1619	.4372	.4858	.583	.583	.7287
Min	.1619	.1619	.2429	.3239	.5182	.1296	.4858
Avg	.2478	.1619	.3833	.4480	.5506	.4750	.6709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134068 / 33KV S/S SINDKHED

Feeder No / Name : 202 / Sindkhed Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5182		.7125	.0324
2				.583		.7773	.0324
3				.6478		.8745	.0324
4				.6802		.9717	.0324
5				.7125		1.0364	.0324
6				.8097		1.1984	.0324
7				.7773		1.2955	.0324
8			.5668	.9717			.0324
9			.6478	.9393			.0324
10	.4858	.5668					
11		.6478					
12		.6478					
13	.8907	.6478					
14	.8907	.6478					
15	.8907	.6478					
16	.8097	.5668					
17	.8097	.5668					
24				.4534	.5668	.6478	.0324
Max	.8907	.6478	.6478	.9717	.5668	1.2955	.0324
Min	.4858	.5668	.5668	.4534	.5668	.6478	.0324
Avg	.7962	.6174	.6073	.7093	.5668	.9393	.0324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 201 / 11 kv Banegaon Ag
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.543	.6516	.6335
2		.5068	.6335	.6878
3		.5068	.6516	.724
4		.4706	.6878	.7602
5		.543	.724	.8145
6		.5792	.7964	.8326
7		.6335	.8326	.905
8		.724	.9774	.905
9			.905	.9412
10	.3429			
15	.703			
16	.6859			
17	.6859			
24		.5792	.6335	.6154
Max	.703	.724	.9774	.9412
Min	.3429	.4706	.6335	.6154
Avg	.6044	.5651	.7493	.7819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 202 / 11 kv Bhogaon Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516				
2	.6859				
3	.6859				
4	.8573				
5	.9431				
6	.9431				
7	.8916				
8	.6859				
9	.7202				
10			.6878	.8869	.9774
11		.8326	.8326		
12		.9145	.905		
13			1.0136	1.086	
14			1.0498	1.0136	
15			1.086	.9774	1.1765
16			1.0136	.9412	1.1584
17			.905	.905	1.1222
24	.3429				
Max	.9431	.9145	1.086	1.086	1.1765
Min	.3429	.8326	.6878	.8869	.9774
Avg	.7408	.8736	.9367	.9684	1.1086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134069 / 33 kv Banegaon

Feeder No / Name : 203 / 11 kv banegaon Gaonthan

Gaonthan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1715	.1715	.1715	.1886	.1886
2	.2058		.1715	.1715	.1886	.1715	.1715
3	.2058		.1715	.1886	.2058	.1715	.1715
4	.1715		.2572	.2058	.2572	.2058	.1886
5	.3086		.2572	.3086	.3429	.3086	.2743
6	.3086		.2401	.4801	.4115	.4458	.4115
7	.3086		.1715	.4161	.3429	.3429	.4801
8	.2572		.2058	.3121	.5144	.3601	.4458
9	.2572		.2058	.2601		.3086	.4115
10	.0686					.4287	.3086
11	.0686		.2229		.2572		
12	.0686		.1886		.2401		
13	.0686				.2572	.2572	
14	.1715			.1715	.2229	.2401	
15	.1715			.1886	.2058	.2229	.2401
16	.2058			.208	.1886	.2058	.2401
17	.2401			.2572	.1715	.2401	.3086
18	.3086		.3086	.3086	.2743	.2743	.4115
19	.3086		.3601	.3429	.4458	.3772	.3772
20	.3086	.4287	.2743	.3772	.3429	.3429	.3429
21	.2743	.3429	.2572	.3429	.2743	.2572	.3086
22	.2058	.3086	.2401	.2743	.2401	.2229	
23		.2743	.2058	.2058	.2058	.2058	
24	.1372		.2572	.1715	.1886	.1886	.1886
Max	.3086	.4287	.3601	.4801	.5144	.4458	.4801
Min	.0686	.2743	.1715	.1715	.1715	.1715	.1715
Avg	.2087	.3386	.2315	.2681	.2705	.2712	.3039

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 201 / 11 KV Bhutegaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.2241					
2	.056	.2427					
3	.0747	.2427					
4	.0747	.2614					
5	.0747	.2614					
6	.0747	.2801					
7	.0747						
9	.0747						
10						.4572	.4668
11			.3547	.4481	.5906	.4668	.5041
12			.4481	.4668		.5041	.5415
13			.4668	.4854		.5228	.5415
14			.4481	.4854		.5415	.5041
15			.4294	.4108	.6097	.5601	.5228
16				.3734	.6287	.5975	.5415
17				.5601	.6287	.5601	.5228
24	.056	.1867					
Max	.0747	.2801	.4668	.5601	.6287	.5975	.5415
Min	.056	.1867	.3547	.3734	.5906	.4572	.4668
Avg	.0685	.2427	.4294	.4614	.6144	.5263	.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 202 / 11 kv Dai Anterwali ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1494	.2241	.1905	.1867
2		.1143	.168	.2241	.1905	.1867
3		.1143	.1867	.2241	.1905	.2054
4		.1524	.2054	.2427	.2286	.2241
5		.1524	.2054	.3734	.2477	.2427
6		.1524	.2241	.3361	.2667	
7		.2096	.3547	.3734	.2667	.3547
8		.2096			.3429	.3547
9		.2286			.381	.3734
10	.112					
12	.112					
17	.2241					
24		.1143	.1307	.1494	.1905	.1867
Max	.2241	.2286	.3547	.3734	.381	.3734
Min	.112	.1143	.1307	.1494	.1905	.1867
Avg	.1494	.1562	.2031	.2684	.2496	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134075 / 33 kv Bhutegaon

Feeder No / Name : 203 / 11 kv Bhutegaon Gaonthan

Gaouthan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.3048	.2801	.2987	.2858	.2801
2		.3174	.3048	.2987	.3361	.2858	.2987
3		.3734	.3048	.3361	.3734	.3048	.3174
4		.5041	.3429	.4108	.4108	.4191	.4668
5		.5601	.5335	.5228	.4668	.4763	.5228
6		.5975	.5716	.5601	.5228	.5335	.5601
7			.4954	.5788	.5601	.5906	.5415
8			.4954			.5335	.5041
9	.3921		.4763			.4763	.4481
10	.3361					.4572	.3174
11	.1867		.2241	.2427	.2286	.3921	.2241
12	.3921		.1867	.1867		.3547	.1867
13			.1867	.168		.2987	.168
14			.2054	.168		.2241	.1494
15			.168	.1867	.2286	.1867	.1867
16				.2054	.2858	.2614	.2241
17				.2241	.2858	.2987	.2614
18	.3547	.2858	.2241	.2801		.3361	.3361
19	.4668	.381	.3174	.3734	.3429	.4108	.4108
20	.4294	.4191	.4108	.4668	.5335	.3734	.4668
21	.4108	.4572		.3361	.5716	.3361	.3734
22	.3547	.4954	.2801	.3174	.4954	.2987	.3174
23	.2801	.4191	.2801	.2801	.381	.2801	.2801
24		.2801	.3048	.2801	.2801	.2858	.2801
Max	.4668	.5975	.5716	.5788	.5716	.5906	.5601
Min	.1867	.2801	.168	.168	.2286	.1867	.1494
Avg	.3604	.4145	.3309	.3192	.3884	.3625	.3384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 201 / 11 KV RANJANI GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
1	.4801	.7716
2	.4801	.7545
3	.4801	.7716
4	.583	.7202
5	.7716	.7373
6	.9602	.7888
7	1.0631	.823
8	1.0974	.8059
9	1.0631	.7888
10	.9602	.7716
11	.7545	.7202
12	.7373	.6859
13	.7202	.5144
14	.7373	.4115
15	.7202	.4458
16	.7373	.5487
17	.7716	.6859
18	.8059	.9259
19	.8402	.7202
20	.8573	.6859
21	.823	.5487
22	.8059	
23	.7888	.4458
24	.5144	.7545
Max	1.0974	.9259
Min	.4801	.4115
Avg	.7730	.6881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 202 / 11 KV RANJANI AG FDR AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
1	.0171	.0857
2	.0171	.0857
3	.0171	.1029
4	.0171	.12
5	.0514	.1372
6	.0686	.1715
7	.1029	.1715
8	.1715	.2058
9	.1715	.1543
24	.0343	.0343
Max	.1715	.2058
Min	.0171	.0343
Avg	.0669	.1269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 203 / 11 KV KRISHNAPUR AG

Ag dominated/Pure Ag

FEEDER Feeder KV- 11 /
OUTGOING

DATE	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
10	.4115	.4572
11	.3048	.6554
12	.3658	.442
13	.381	.5639
14	.442	.6401
15	.503	.6554
16	.4877	.6249
17	.4725	.6554
Max	.503	.6554
Min	.3048	.442
Avg	.4210	.5868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 204 / 11 KV CHITRAWADGAON AG. Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
1	.1829	.2286
2	.1829	.4572
3	.1829	.4725
4	.2134	.4877
5		.5335
6	.4268	.6097
7	.3963	.6249
8	.5639	.6554
9	.7011	.7468
24	.2743	.1524
Max	.7011	.7468
Min	.1829	.1524
Avg	.3472	.4969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER SHEDDABLE FEEDER HAVING WEEKLY
Ranjani Feeder KV- 11 / STAGGERING (MIDC, EQUIVALENT)
OUTGOING

DATE	28-JUL-17
HR	Load (MW)
12	.0191
20	.0286
21	.0229
22	.0152
Max	.0286
Min	.0152
Avg	.0215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 206 / PARADGAON GFS.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
1	.1029	.0857
2	.1029	.0857
3	.1029	.0686
4	.12	.0857
5	.12	.0857
6	.1543	.0686
7	.2572	.1029
8	.2572	.0857
9	.1029	.1029
10	.1886	.0857
11	.0857	.0857
12	.0857	.0686
13	.0857	.0686
14	.1029	.0686
15	.0857	.0686
16	.1029	.0686
17	.0857	.0857
18	.1029	.1715
19	.0857	.2229
20	.1029	.1715
21	.1029	.1029
22	.0857	.1029
23	.0857	.0857
24	.1029	.1029
Max	.2572	.2229
Min	.0857	.0686
Avg	.1172	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 201 / 11KV BORGAON GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2801	.168	.2241	.2614	.2801	.2801
2		.2801	.1867	.1867	.2614	.2614	.2801
3		.2987	.2054	.2801	.2801	.3361	.3361
4		.2987	.2801	.3174	.2801	.2987	.3361
5		.3174	.2801	.3734	.3174	.2987	.3547
6		.3174	.2614	.3921	.2915	.2241	.3734
7		.3174	.3174	.2801	.2286	.2241	.3734
8		.2801	.2054	.2572	.2614	.1555	.3547
9		.2614	.2427	.3361	.2241	.1867	.2896
10		.2054	.168	.2054	.2614	.1867	.1867
11		.1867		.1867	.1867	.1867	.112
12		.168		.1867	.1867	.1867	
13		.1867		.1494	.2241		
14		.1494		.112	.2054	.1867	.1494
15		.1307		.0934	.2058		.1494
16		.112	.1307	.0747			.1494
17		.1867	.1494	.1867	.1867		.1494
18		.2054	.1494	.2241			
19		.3361	.1867	.2801	.2241		
20		.2801	.2241	.2801	.2241		
21		.2614	.2427	.2801	.1867		
22	.3174	.2801	.2614	.2614	.1372		
23	.2801	.2241	.2427	.2801	.1494		
24		.2801	.1867	.2241	.2614	.2801	.2801
Max	.3174	.3361	.3174	.3921	.3174	.3361	.3734
Min	.2801	.112	.1307	.0747	.1372	.1555	.112
Avg	.2988	.2435	.2152	.2363	.2294	.2352	.2597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 202 / 11 KV KANDARI GAOTHAN Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.3086	.3734	.3361
2		.2614	.3429	.3361	.2987
3		.3174	.4108	.2987	.2801
4		.2801	.3921	.2987	.2801
5		.2614	.3734	.3361	.3361
6		.1867	.3734	.3734	.3734
7		.1494	.3734	.3361	.3734
8		.168	.3174	.2614	.3361
9		.112	.2353	.2801	.2987
10		.2241	.2056	.3361	.2801
11			.1494	.2801	.1867
12			.1867	.2241	.1494
13			.2241	.2801	.1494
14			.1867	.3048	.1867
15	.1307		.1867		.1867
16	.1307		.2241		.2054
17	.1867	.2241	.2243		.2427
18	.2054	.2801			
19	.1307	.3734	.2801		
20	.2241	.4108	.2801		
21	.2987	.4481	.3361		
22	.2614	.4108	.4108		
23	.2801	.3734	.3734		
24		.2801	.3174	.3361	.3361
Max	.2987	.4481	.4108	.3734	.3734
Min	.1307	.0187	.1494	.2241	.1494
Avg	.2054	.2656	.2919	.3104	.2687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 203 / 11 KV BORGAON AG AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.112	.1494	.3429	.0747
2		.1029	.168	.3086	.0747
3		.1029	.168	.3547	.0934
4		.1307	.2801	.3772	.4668
5		.1372	.3734	.3734	.5144
6		.1372	.4525	.3734	.5144
7		.1543	.4854	.5487	.6001
8		.1715	.5228	.6516	.6001
9		.1543	.5601	.6859	.6001
15	.3601				
16	.3734	.0514			
17	.3086	.0457	.0373		.1372
18	.0514	.1029			
19	.0514	.0857	.112		
20	.056	.1029	.1867		
21	.0686	.0934	.1867		
22	.0747	.0857	.1867		
23	.0747	.1029	.1494		
24		.1029	.1372	.3429	.0747
Max	.3734	.1715	.5601	.6859	.6001
Min	.0514	.0457	.0373	.3086	.0747
Avg	.1577	.1098	.2597	.4359	.3410

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 204 / 11 KV KANDARI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.6001	.5144	.8573
11	.7202	.5975	1.2003
12	.7716	.5975	1.0288
13	.8215	.7095	.8573
14	.8402	.6516	1.0288
15	.7202		1.1145
16	.7716		1.0974
17	.6516		1.0288
Max	.8402	.7095	1.2003
Min	.6001	.5144	.8573
Avg	.7371	.6141	1.0267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 205 / 11 KV PANGRA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1372
2				.1494
3			.2572	.1867
4			.2804	.206
5			.3429	.2058
6			.5144	
7			.823	
8			.8402	
9			.8402	
10	.2058	.2229		
11	.3086	.1372		
12	.2572	.1372		
13		.1029		
14	.2058	.0857		
15	.2572	.1029		
16	.2401			
17	.2229		.1524	
24				.0857
Max	.3086	.2229	.8402	.206
Min	.2058	.0857	.1524	.0857
Avg	.2425	.1315	.5063	.1618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 206 / 11 KV Maherjawla gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.3086	.3734	.3734
2		.2801	.4287	.4108	.4108
3		.3174	.5144	.4668	.4668
4		.3547	.5658	.4668	.4668
5		.3174	.6535	.5228	.5716
6		.4668	.6001	.5601	
7		.6348	.5487	.5228	.5316
8		.5601	.4287	.4668	.4668
9		.2614	.3429	.3429	.4668
10		.1867	.2058	.3734	.2858
11			.1372	.3361	.1905
12			.1372	.2801	
13			.1029		
14			.12	.5228	.2286
15	.1494		.12		.2286
16	.1494	.1494			.2096
17	.2987	.2427	.3734		
18	.3921	.2987			
19	.5228	.3174	.4108		
20	.3734	.3361	.4287		
21	.3547	.3547	.3734		
22	.3361	.3174	.3361		
23	.3734	.3174	.3361		
24		.2801	.2572	.3772	.3429
Max	.5228	.6348	.6535	.5601	.5716
Min	.1494	.1494	.1029	.2801	.1905
Avg	.3278	.3312	.3514	.4302	.3743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION

Feeder No / Name : 207 / 11 KV MASHEGAON AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0857					
3	.0857					
4	.0857					
5	.1029					
6	.1029					
7	.12					
8	.12					
9	.12					
10		.1886	.1715	.4287	.1715	.2572
11			.2058	.6173	.2058	.2915
12			.2241	.4801	.2572	.2241
13			.2241	.5601	.2572	.1717
14			.2229	.5144	.2241	.3429
15			.2229	.5487		.4115
16			.2058	.6516		.4763
17		.0857	.1886	.6001		.5144
Max	.12	.1886	.2241	.6516	.2572	.5144
Min	.0857	.0857	.1715	.4287	.1715	.1717
Avg	.1029	.1372	.2082	.5501	.2232	.3362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 201 / 11 KV PARADGAON AG

Ag dominated/Pure Ag

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1174		.1619	.4372	.2753
2		.1134		.1781	.4696	.2753
3		.0972		.1781	.4858	.2915
4		.1296		.2105	.583	.3239
5		.1619	.2915	.2591	.6154	.3725
6		.1943	.4534	.3563	.6478	.4372
7		.3563	.502	.6964	.664	.6478
8		.4372	.5668	.583	.8583	.6706
9		.4534	.3887		.7611	.7287
10	.3077					
11	.3353					
12	.3704					
15	.2896			1.5242		
16	.2778					
17	.2469					
24		.1677		.1457	.1943	.2591
Max	.3704	.4534	.5668	1.5242	.8583	.7287
Min	.2469	.0972	.2915	.1457	.1943	.2591
Avg	.3046	.2228	.4405	.4293	.5717	.4282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 202 / YEOLA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.2054		.1494	.2054	.1867
2	.168	.1867	.1867		.168	.2054	.1867
3	.2241	.2241	.2241		.2241	.2427	.2054
4	.2587	.2801	.2427		.2987	.2614	.2427
5	.3326	.3326	.2987	.3361	.3361	.2801	.2801
6	.462	.3696	.3174	.2987	.4066	.3174	.3547
7		.3142	.2987	.3547	.3696	.2987	.3326
8		.2987	.2801	.3734	.3361	.2614	.3174
9	.3174		.2241	.2801		.2801	.2427
10	.1867		.168	.168		.2427	
11	.1307			.081	.1867	.1867	
12	.056			.0648		.168	.0934
13				.056		.2241	.1109
14				.0747			.1109
15	.0747			.0934	.1307	.1457	.1109
16	.112			.0934	.1494	.1619	.1478
17	.112			.112	.2054	.1307	.1848
18	.1307	.1867		.0934		.1307	.2587
19	.1848	.2614	.168	.1307	.2987	.2241	.3881
20	.2218	.2987		.168	.3361	.2241	.4066
21	.2801	.2614		.2801		.2241	.4668
22	.2241	.2241		.2241	.2801	.2241	.4668
23	.2054	.2054		.1867	.2427	.2054	.4481
24	.1867	.2054	.2054		.1494	.2241	.2054
Max	.462	.3696	.3174	.3734	.4066	.3174	.4668
Min	.056	.1867	.168	.056	.1307	.1307	.0934
Avg	.2028	.2557	.2349	.1826	.2510	.2204	.2613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 203 / 11 KV BOR RANJANI AG Ag dominated/Pure Ag

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1781	.1781					
2	.1781	.1781					
3	.2267	.1943					
4	.2267	.1943					
5	.2429	.2031					
6	.2429	.2429					
7	.3401	.3725					
8		.421					
9	.421						
10			.3887	.4372		.421	.7773
11				.5668	.8745	.4534	.6802
12				.5668		.1943	.7773
13				.5992		.421	.7773
14				.5992		.6478	.7935
15				.5992	.7773	.788	.7773
16			.3887	.1943	.8097	.8551	.7935
17			.2915	.1457	.8097	.8962	.8097
24	.1943	.1619					
Max	.421	.421	.3887	.5992	.8745	.8962	.8097
Min	.1781	.1619	.2915	.1457	.7773	.1943	.6802
Avg	.2501	.2385	.3563	.4636	.8178	.5846	.7733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 201 / TALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.1145	1.0288	.8916	1.1831	1.3717	
2	1.166	1.1145	1.0631	.9602	1.2346	1.5432	1.5432
3	1.1831	1.1145	1.0974	1.0288	1.3032	1.7147	1.5432
4			1.1317	1.1488	1.3717	1.7147	1.7147
5			1.1317	1.3717	1.6461	1.7147	1.7147
6			1.166	1.4746	1.8861	1.7147	2.0576
7			1.2003	1.5089	1.9547	2.4006	2.0576
8			1.2003	1.4746		1.8861	2.2291
9	.9602		1.2003			2.0576	.4801
10	.9602						
11	.9259						
12	.9602						
13	1.0288						
16	1.0288			.6173	.823	.4115	1.2003
17	1.0288			.7545		.8573	1.2003
18	1.0974	1.0974	.8916	1.1488		1.0974	1.2003
19	1.1145	1.1317	1.0631	1.3717	.8573	1.5089	
20	1.1145	1.2003	1.3717	1.3375	1.3375	1.2003	
21	1.1145	1.3032	1.3375	1.3032	1.5089	1.406	
22	1.2003	1.3717	1.2003	1.2689	1.4403	1.3032	
23	1.0288	1.3032	1.1317	1.2003	1.3717	1.0288	1.3717
24	1.166	1.1145		.8573	1.1317	1.1317	.9602
Max	1.2003	1.3717	1.3717	1.5089	1.9547	2.4006	2.2291
Min	.9259	1.0974	.8916	.6173	.823	.4115	.4801
Avg	1.0732	1.1866	1.1477	1.1599	1.3607	1.4480	1.4825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 202 / IDOLI (ARDA)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1715	.1715	.2401	.2401	.4801	.2401
2	.2572	.1715	.2058	.2743	.2743	.4458	.3429
3	.2572	.1715	.2401	.2743	.2743	.4458	.3429
4			.2743	.3086	.3258	.6516	.3772
5			.3086	.3429	.3601	.6516	.6859
6			.3772	.3429	.5487	.6516	.6859
7			.4287	.4801	.6173	.6516	.7545
8			.4287	.4458		.6173	.6173
9			.5144			.6173	.6687
10	.3258						
11	.2572						
12	.2572						
13	.2572						
16	.2572			.1029	.1886	.2401	.1886
17	.2572			.1372	.2401	.2401	.1886
18	.12	.2915	.1886	.1715	.2572	.2401	.1886
19	.12	.2743	.2229	.2401	.2572	.2743	.1886
20	.1372	.2572	.2572	.3086	.2743	.2743	.2058
21	.1372	.2401	.2915	.2743	.3601	.3258	.2058
22	.1372	.2229	.2743	.2572	.3429	.2743	.2229
23	.1372	.2229	.2401	.2401		.2743	.2229
24	.2229	.1715	.1372	.1715	.1715	.2401	.2401
Max	.3258	.2915	.5144	.4801	.6173	.6516	.7545
Min	.12	.1715	.1372	.1029	.1715	.2401	.1886
Avg	.2111	.2195	.2851	.2713	.3155	.4220	.3649

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 203 / PATHODA (HEALS)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.3429	.6859	.6173	.583	
2	.6516	.5144	.3772	.6516	.6001	.6173	
3	.7545	.5144	.3944	.6859	.5658	.6173	
4	.8573	.6859					
5	.9259	.7716					
6	.9602	.8573					
7	.9259						
8	.8916						
9	.7545						
10			.5487				
11					.9259	.8059	
12			.6001	.8573	1.1317	.8573	
13				.7888		.8916	
14			.6001	.7888		.9431	1.0288
15				.8573	1.2346	1.0117	1.0288
16	.5144			.7202	1.2689	.9431	.9431
17	.5144			.6516	1.2003	.9088	.8573
18	.4801	.5487	.6173	.7202	.7545	.6859	.6516
19	.4287	.5144	.6516	.8402	.7545	.7545	.6173
20	.4287	.4801	.8059	.9945	.6859	.7888	.583
21	.5144	.4458	.7888	.8573	.6173	.7888	.5144
22	.5144	.3601	.7716	.7888	.6173	.7545	.4801
23	.4801	.3601	.7545	.7373	.6173	.7202	.4287
24	.4287	.4287	.3258	.7202	.6516	.583	
Max	.9602	.8573	.8059	.9945	1.2689	1.0117	1.0288
Min	.4287	.3601	.3258	.6516	.5658	.583	.4287
Avg	.6411	.5316	.5830	.7716	.8162	.7797	.7133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 204 / AMBHODA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7716	.7888	.9602	1.0288	1.0288	
2	.7545	.7716	.823	.9945	.9602	1.0288	
3	.7545	.7716	.8916	1.0631	.9945	1.0288	
4	.6859	.8573					
5	1.0288	.9431					
6	1.0288	1.0288					
7	1.0288						
8	.9945						
9	.7545						
10			.7888			.8402	
11			.8573		.7888	.8573	
12			.8573	.5144		.823	
13						.6173	
14				.4801		.6859	1.3717
15				.4458	1.2003	.9088	1.3717
16	1.0288			.5144	1.3032	.6859	1.2003
17	1.0288			1.166	.8573	.9088	1.2003
18	.8916	.7545	.9259		.6859	.9945	1.0288
19	.9431	.7888	1.0288	1.0288	1.0288	1.0288	1.0631
20	.9431	.823	1.2346	1.3717	1.2003	1.2346	1.1317
21	.9431	.7888	1.2003	1.3032	1.2346	1.3032	1.166
22	.9431	.7888	1.166	1.2346	1.1317	1.2346	1.2003
23	.8573	.7888	1.0974	1.166	1.0974	1.0974	1.2346
24	.7202	.7716	.7545	.9945	1.0631	1.0288	
Max	1.0288	1.0288	1.2346	1.3717	1.3032	1.3032	1.3717
Min	.6859	.7545	.7545	.4458	.6859	.6173	1.0288
Avg	.8936	.8191	.9549	.9455	1.0411	.9631	1.1969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 205 / MANTHA TOWN-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.1029	.0514	.0514	.1029	.1029
2	.1029	.0857	.1029	.0514	.0514	.1029	.1029
3	.1029	.0857	.1029	.0686	.0686	.1029	.1029
4	.1029	.0857	.0857	.0686	.0686	.1029	.1029
5	.1029	.0857	.0857	.0686	.0686	.1029	.1029
6	.1029	.0857	.0857	.0857	.0857	.1029	.1029
7	.1029		.1029	.0857	.1029	.1029	.1029
8	.1029		.0857	.0857		.1029	
9	.1029		.1029			.1029	.0343
10	.1029		.1029			.1029	.0343
11	.1029				.1372	.1029	.1543
12	.0857			.1029	.1372	.1029	.0686
13	.0857			.1029			.12
14	.0857		.1029	.1029		.1029	.12
15	.1029			.1029	.12	.1029	.12
16	.1029			.1029	.1029	.1029	.12
17	.1029			.1029	.1029	.1029	.12
18	.1029	.12	.1029	.1029	.12	.1029	.12
19	.1029	.1029	.1029	.1029	.1029	.1029	.12
20	.1029	.1029	.0857	.1029	.1029	.1029	.12
21	.1029	.1029	.0686	.0857	.1029	.1029	.1029
22	.1029	.1029	.0686	.0686	.1029	.1029	.1029
23	.0857	.1029	.0686	.0686	.1029	.1029	.1029
24	.1029	.0857	.1029	.0514	.0514	.1029	.1029
Max	.1029	.12	.1029	.1029	.1372	.1029	.1543
Min	.0857	.0857	.0686	.0514	.0514	.1029	.0343
Avg	.1000	.0950	.0924	.0841	.0939	.1029	.1036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 206 / INDUSTRIAL FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.0343	.0343	.0343	.0343
2	.0343	.0343	.0343	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	.0343	.0343	.0343	.0343
4	.0343	.0343	.0343	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343	.0343	.0343	.0343
7	.0343		.0343	.0343	.0343	.0343	.0343
8	.0343		.0343	.0343		.0343	.0343
9	.0343		.0343			.0343	.0343
10	.0343		.0343			.0343	.0343
11	.0343				.0343	.0343	.0343
12	.0343		.0343	.0686	.0343	.0343	.0343
13	.0343			.0343			.0343
14	.0343		.0343	.0343		.0343	.0343
15				.0343	.0343	.0343	.0343
16	.0343			.0343	.0343	.0343	.0343
17	.0343			.0343	.0343	.0343	.0343
18	.0343	.0343	.0343	.0343	.0343	.0343	.0343
19	.0343	.0343	.0343	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Max	.0343	.0343	.0343	.0686	.0343	.0343	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0343	.0343	.0343	.0359	.0343	.0343	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134012 / MANTHA

Feeder No / Name : 207 / MANTHA TOWN-II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0288	1.0974	1.0631		1.2003	
2	1.1317	1.0288	1.166	1.0631	.9945	1.2003	
3	1.2003	1.0288	1.2003	1.1317	1.0288	1.3032	
4	1.2003	1.1145	1.2689	1.166	1.0631	1.3375	
5	1.5089	1.2003	1.3032	1.2346	1.2003	1.3717	
6	1.5089	1.3032	1.3717	1.4746	1.406	1.4403	
7	1.5089		1.406	1.5432	1.5432		
8	1.3717		1.3717	1.406		1.2003	
9	1.2689		1.2003			1.3032	
10	1.1317		1.166			1.2689	
11	1.0288		1.1145		1.2346	1.3032	
12	.823		1.1145	1.0631	1.1317	1.2003	
13	.8573		1.0631	.9945			
14	.8573		1.0974	.9945		1.0288	1.2003
15					1.2689	1.0288	1.2003
16	1.0288			1.2003	1.2003	1.0974	1.2003
17	1.2003			1.3032	1.2689	1.166	1.3717
18	1.2346	1.2003	1.166	1.3375	1.3032	1.3032	1.3717
19	1.286	1.166	1.2346	1.406	1.3032	1.3032	1.3375
20	1.3717	1.1317	1.3032	1.4403	1.3032	1.2003	1.3032
21	1.3717	1.0974	1.2689	1.3717	1.3375	1.2003	1.2003
22	1.2003	1.0974	1.2003	1.3375	1.5089	1.166	1.166
23	1.0288	1.0974	1.0974	1.2003	1.3717	1.1317	1.1317
24	1.0631	1.0288	1.0631	1.0288	1.0288	1.0631	
Max	1.5089	1.3032	1.406	1.5432	1.5432	1.4403	1.3717
Min	.823	1.0288	1.0631	.9945	.9945	1.0288	1.1317
Avg	1.1846	1.1172	1.2035	1.238	1.2498	1.219	1.2483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 202 / DAHIFAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.583	.823	.5658	.7716	.823
2	.5144		.583	.823	.6173	.7716	.823
3	.5144		.583	.823	.7202	.7716	.8745
4	.6001						
5	.6001						
6	.6859						
7	.6859						
8	.6859						
9	.6859						
10			.5144		.463		
11			.463				
12			.3601	.3601	.3086		.7888
13			.4115	.3601	.3601	.8745	.7716
14			.463			.823	.7716
15			.4115		.4801	.8573	.823
16	.4115			.4115	.6516	.7716	.7202
17	.4115	.4115		.6173	.5144	.7202	.5144
18	.4115	.4115	.583	.7716		.7888	
19	.4115	.5144	.7202	1.166	.9602	.823	
20	.583	.5144	.9259	1.2346	1.0288	.9602	.9774
21	.583	.583	1.0631	1.0802	.9602	.8745	1.0288
22	.5144	.2915	.9774	.8573	.8745	.8916	.9259
23	.5144	.583	.9259	.7716	.823	.8573	.823
24	.5144		.583	.823	.5658	.7716	.823
Max	.6859	.583	1.0631	1.2346	1.0288	.9602	1.0288
Min	.4115	.2915	.3601	.3601	.3086	.7202	.5144
Avg	.5468	.4728	.6344	.7802	.6596	.8219	.8206

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 203 / KOKARSHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1029	.1543	.1543	.1543	.1543
2	.1715		.1029	.2058	.1543	.1543	.1543
3	.1715		.1029	.2058	.1543	.1543	.1543
4			.1543	.2058	.1543	.2058	.2058
5			.1543	.2572	.1543	.2572	.2058
6			.1715	.2572	.1543	.3086	.2058
7			.1715	.2743	.1543	.3086	.2058
8			.1715	.3601	.2572	.3086	.2058
9			.1715				.1543
10	.1029						
11	.1029						
12	.1029						
13	.1029	.1715					
14	.1029	.1029					
15	.1029	.1029					
16	.1029	.1029			.2058	.1886	.1029
17		.1029			.2058	.2572	.1543
18		.1029	.1715			.2743	
19		.1029	.2058	.12	.3258	.2743	
20		.1029	.3086	.2915	.3258	.3086	.2572
21			.3258	.3086	.3086	.2743	.2915
22		.1029	.2743	.2743	.2915	.2743	.2743
23		.1029	.2572	.2572	.2743	.2743	.2743
24	.1715		.1029	.1543	.1543	.1543	.1543
Max	.1715	.1715	.3258	.3601	.3258	.3086	.2915
Min	.1029	.1029	.1029	.12	.1543	.1543	.1029
Avg	.1278	.1098	.1843	.2376	.2143	.2431	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134020 / DAHIPHAL KHANDARE

Feeder No / Name : 204 / PEWA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.5144	.7716		.7716	.823
2	.5144		.5144	.823		.7716	.823
3	.5144		.5144	.823		.8745	.823
4	.6859						
5	.6859						
6	.7716						
7	.8573						
8	.6859						
9	.5144						
10			.3429		.4115		
11			.3601		.7373		
12			.3086	.463	.7202		.6687
13			.3086	.5144	.5658	.8745	.6173
14			.3086			.823	.823
15			.3601		.6687	.8745	.7202
16		.5144		.5144	.7202	.7373	.7202
17		.5144		.6173	.5144	.7716	.6001
18		.5144	.7202	.6173		.8059	.6001
19		.5144	.9259	.8059	.9431	.823	
20		.5144	.9774	1.0802	1.1145	.9602	.9259
21		.5144	.9774	.9259	.8745	.8745	.9774
22		.5144	.9259	.8745	.823	.8745	.9088
23		.5144	.823	.823	.823	.823	.823
24	.5144		.5144	.7716	.7716	.7716	.823
Max	.8573	.5144	.9774	1.0802	1.1145	.9602	.9774
Min	.5144	.5144	.3086	.463	.4115	.7373	.6001
Avg	.6259	.5144	.5873	.7447	.7452	.8288	.7784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 201 / V.WADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144	.823	.5144	.6001	.4287
24		.6001	.6001	.6001	.5144
Max	.5144	.823	.6001	.6001	.5144
Min	.5144	.6001	.5144	.6001	.4287
Avg	.5144	.7116	.5573	.6001	.4716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134050 / JAIPUR

Feeder No / Name : 202 / WAZAR S.

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4287				
24		.5144	.5144	.5144	.4287
Max	.4287	.5144	.5144	.5144	.4287
Min	.4287	.5144	.5144	.5144	.4287
Avg	.4287	.5144	.5144	.5144	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 202 / PATODA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.4344	.4163			.5138	.5014
2	.3982	.439	.4344			.5373	.5138
3	.3898	.4344	.4572			.5731	.5194
4	.4477	.5068					
5	.4835	.543					
6	.5373	.543					
7	.5847	.6154					
8	.8413	.6516					
9	.9391	.6154					
10						.8682	
11					1.0974	1.1517	
12					1.1765	1.0745	
13					1.0985		
14					1.1517		
15		.5853			1.1517		1.2851
16	.543	.5487			1.182		1.2803
17	.5068	.5068			1.2403	.8328	1.2308
18	.5068	.4706			.9036		.8688
19	.5068	.5068			.691		.724
20	.4706	.4706			.6335		.7602
21	.4344	.4344		.4344	.6089		.5792
22	.4344	.4163		.4024	.5731		.543
23	.4024	.4163		.3475	.5552	.4835	.6154
24	.3366	.362	.4024	.4525	.3292	.5194	.4656
Max	.9391	.6516	.4572	.4525	1.2403	1.1517	1.2851
Min	.3366	.362	.4024	.3475	.3292	.4835	.4656
Avg	.5068	.5000	.4276	.4092	.8852	.7283	.7605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 203 / IDOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6984	.439	.5121			1.5592	1.5939
2	.6733	.439	.5304			1.6301	1.6118
3	.691	.439	.5304			1.6832	1.7541
4			.5487			1.8625	1.9366
5			.5487			2.1262	2.3282
6			.567			2.2744	2.6932
7			.6036			2.4893	2.6684
8						1.7187	2.9412
9						2.0595	2.7759
10	1.6289	.724					
11	1.6124	1.1222					
12		.8779					
13	1.3717	.9145					
14	1.4449	.8048					
15	1.5364						
16		.8048				.9313	.9877
17		.8779			1.2536	1.5223	1.6827
18	.6219	.7682			1.4685		1.5912
19	.5487	.695			1.6118		1.5729
20	.439	.7316			1.7193		1.5364
21	.4024	.5487		1.2803	1.7372		1.5729
22	.7316	.5304		1.267	1.7372		1.5364
23	.7682	.5304		1.2803	1.6476	1.5415	1.5729
24	.6556	.7316	.5121	.4207	1.3169	1.5223	1.5415
Max	1.6289	1.1222	.6036	1.2803	1.7372	2.4893	2.9412
Min	.4024	.439	.5121	.4207	1.2536	.9313	.9877
Avg	.9216	.7046	.5441	1.0621	1.5615	1.7631	1.8832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 204 / express water supply Only one consumer of WW with HT-IV
INDUSTRIA Feeder KV- 11 /
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0175	.0175		
2		.0175	.0175		
3		.0175	.0175		
4		.0175	.0175		
5		.0175	.0175		
6		.0175	.0175		
7		.0175	.0175		
8		.0175			
9		.0175			
10		.0175			
11		.0175			
12		.0175			
13	.0175	.0175			
14	.0175	.0175			
15	.0175	.0175			.0175
16	.0175	.0175			.0175
17	.0175	.0175			.0175
18	.0175	.0175			.0175
19	.0175	.0175			.0175
20	.0175	.0175			.0181
21	.0175	.0175			.0175
22	.0175	.0175			.0175
23	.0175	.0175			.0175
24		.0175	.0175	.0175	
Max	.0175	.0175	.0175	.0175	.0181
Min	.0175	.0175	.0175	.0175	.0175
Avg	.0175	.0175	.0175	.0175	.0176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 201 / 11 KV DEVTHANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458	.4115	.3772	.4458	.4115	.4973
2		.4115	.4287	.3944	.4801	.3944	.5316
3		.3944	.4801	.463	.5144	.3601	.5316
4			.4801	.4458	.5316	.3772	.5658
5			.5658	.463	.5487	.4287	.583
6			.6173	.4973	.6001	.4458	.6001
7			.6001	.4973	.6173	.4973	.6173
8			.6173	.5144	.6516	.463	.6001
9			.5144	.4973	.6859	.4115	.5144
10	.4458	.4458					
11	.4458	.4801					
12	.3944	.463					
13	.4115	.4801					
14	.3944	.4115					
15	.4115	.4115					
16	.3944	.3944	.4458	.2401	.2743	.3086	
17	.4458	.4115	.5144	.2743	.3086	.3601	
18	.4458	.4458	.4801	.3258	.3258	.3944	
19	.4973	.4115	.463	.3772	.3772	.4115	
20	.463	.3772	.4287	.3772	.3944	.3944	
21	.4115	.3772	.4115	.3429	.4115	.4115	
22	.4115	.3429	.3944	.3429	.3944	.4458	
23	.4115	.3601	.3601	.3258	.4115	.463	.3429
24		.4458	.4115	.4115	.3772	.4458	.4801
Max	.4973	.4801	.6173	.5144	.6859	.4973	.6173
Min	.3944	.3429	.3601	.2401	.2743	.3086	.3429
Avg	.4274	.4172	.4792	.3982	.4639	.4125	.5331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134070 / Talni

Feeder No / Name : 203 / 11 KV TALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6173	.4115	.6173	.6344	.6173	.6859
2	.6173	.6173	.4115	.583	.5658	.5658	.6344
3	.7202	.6344	.4287	.5487	.5144	.5316	.6001
4	.8573	.703					
5	.9602	.8402					
6	1.046	.9088					
7	1.0288	.9259					
8	.823	.823					
9	.8573	.5487					
10			.463		.6687	.4458	.7373
11			.4973	.6344	.7202	.5658	
12			.5144	.6859	.6859	.7202	
13			.5487	.6859	.6173	.7545	.5487
14			.5144	.6173	.6344	.703	
15				.5658	.6001	.6859	
16	.4801	.4458	.4801	.5144	.6859	.703	
17	.4458	.4801	.583	.5658	.7202	.7373	
18	.6344	.463	.8402	.6344	.6859	.7716	
19	.6687	.4973	.8059	.6859	.7373	.7888	
20	.6344	.4458	.7716	.7545	.7202	.7716	
21	.583	.4458	.7545	.7202	.6859	.7373	
22	.583	.4287	.6859	.703	.6859	.7373	
23	.5487	.4287	.7373	.6859	.6516	.703	.6516
24		.5658	.4287	.6859	.6687	.6516	.7202
Max	1.046	.9259	.8402	.7545	.7373	.7888	.7373
Min	.4458	.4287	.4115	.5144	.5144	.4458	.5487
Avg	.7180	.6011	.5810	.6405	.6602	.6773	.6540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 201 / pangari 11 kv

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462		.3696	.1943
2	.432		.3696	.2429
3	.462		.3696	.2591
4	.462			
5	.462			
6	.5544			
7	.5544			
8	.5544			
12			.3353	
13			.2486	
16			.4049	
17			.3887	
18			.4862	
19			.2486	
20			.3018	
21			.3353	
22		.3696	.3077	
24	.2772		.3696	.2429
Max	.5544	.3696	.4862	.2591
Min	.2772	.3696	.2486	.1943
Avg	.4689	.3696	.3489	.2348

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 202 / wai

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772		.2772	.2429
2	.2772		.2772	.3239
3	.2772		.2772	.2429
4			.2772	.2429
5			.3326	.1943
6			.3326	.1781
7			.3326	
8			.3326	
12	.2218			
16			.1619	
17			.2429	
18			.1006	
19			.1006	
20			.1509	
21			.081	
22		.1848	.0972	
24	.2772		.2772	.2984
Max	.2772	.1848	.3326	.3239
Min	.2218	.1848	.081	.1781
Avg	.2661	.1848	.2282	.2462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134071 / pangari gosavi

Feeder No / Name : 203 / 11 kv kathala feeder
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	24-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696		.3696	.2429
2	.3696		.3696	.1943
3	.462		.3696	.1619
4	.462			
5	.5544			
6	.5544			
7	.5544			
8	.5544			
12			.2858	
13			.2984	
14			.1989	
15			.1619	
16			.1943	
17			.4858	
18			.4858	
19			.4049	
20			.3239	
21			.3563	
22		.3696	.3077	
24	.3696		.3696	.1619
Max	.5544	.3696	.4858	.2429
Min	.3696	.3696	.1619	.1619
Avg	.4723	.3696	.3321	.1903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 201 / TOWN-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.823	.823
2				.823	.823
3				.823	.8573
4				.8916	.9945
5				1.0288	1.2003
6				1.2346	1.4403
7				1.406	1.6118
8		1.5775		1.2689	1.6804
9				1.3032	1.406
10	1.3717				
11				1.2003	
12				.9945	
13				.8059	
14				.8402	
15				.8573	
16				1.046	.5316
17				1.0974	.4458
18			1.166	1.286	
19			1.0631	1.1145	1.3717
20			1.1317	1.1145	1.2003
21			1.0631	1.0288	1.0288
22			.9602	.9945	.8916
23			.9259	.8402	.8745
24				.823	.823
Max	1.3717	1.5775	1.166	1.406	1.6804
Min	1.3717	1.5775	.9259	.8059	.4458
Avg	1.3717	1.5775	1.0517	1.0281	1.0591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 202 / TOWN-II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3032	1.286
2				1.3032	1.286
3				1.3032	1.3717
4				1.3546	1.4575
5				1.4746	1.6289
6				1.7147	1.8004
7				2.0576	2.0919
8		2.0576		2.1605	2.0576
9				1.9204	1.7833
10	1.5432			1.7147	
11				1.6461	
12				1.5089	
13				1.4918	
14				1.406	
15				1.2346	
16				1.5432	1.3032
17				1.5432	1.4575
18			1.7147	1.5604	1.6289
19			1.6461	1.5947	1.7661
20			1.989	1.6118	1.6975
21			1.8519	1.5432	1.6118
22			1.5775	1.4575	1.5432
23			1.4403	1.286	1.3889
24				1.3032	1.286
Max	1.5432	2.0576	1.989	2.1605	2.0919
Min	1.5432	2.0576	1.4403	1.2346	1.286
Avg	1.5432	2.0576	1.7033	1.5432	1.5804

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 203 / SAIBABA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.4403	1.286
2				1.4403	1.286
3				1.4918	1.3717
4				1.5432	1.5432
5				1.6461	1.7147
6				1.749	1.9547
7				1.9204	1.8861
8		1.5432		1.9204	2.1643
9				1.9814	2.2862
10	1.0669			.9602	
11				.9945	
12				1.2689	
13				2.1091	
14				2.0576	
15				2.1434	
16				.8573	2.4177
17				1.9719	1.3717
18			2.4387	1.7661	2.3663
19			2.3777	1.5261	2.4691
20			2.0919	1.406	1.6766
21			2.0233	1.4232	1.6309
22			1.3375	1.3717	1.2346
23			1.4746	1.3203	1.3717
24				1.4403	1.286
Max	1.0669	1.5432	2.4387	2.1434	2.4691
Min	1.0669	1.5432	1.3375	.8573	1.2346
Avg	1.0669	1.5432	1.9573	1.5729	1.7399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 204 / KAWAJAWALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6554	.5792
2				.6554	.5792
3				.6706	.6097
4				.7164	.6401
5				.7773	.7164
6				.8688	.8078
7				.945	.945
8		.6173		1.1431	.6097
9				1.0974	.6097
10	.3772			.4763	
11				.5144	
12				.4763	
13				.5144	
14				.4763	
15				.5525	
16				.4572	.1981
17				.4572	.3506
18			.3429	.381	.3506
19			.4115	.743	.4268
20			.8573	.8002	.5335
21			.7888	.7811	.6554
22			.703	.6516	.6249
23			.6859	.7049	.5792
24				.6554	.5335
Max	.3772	.6173	.8573	1.1431	.945
Min	.3772	.6173	.3429	.381	.1981
Avg	.3772	.6173	.6316	.6738	.5750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 205 / ANANDWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1145	1.0288
2				1.1145	1.0288
3				1.0974	1.0288
4				1.0631	1.0631
5				1.0288	1.1488
6				.9602	1.2346
7				1.1317	1.2689
8		.4115		1.166	1.3375
9				1.2003	1.0631
10	.7202			1.3717	
11				1.7833	
12				1.8004	
13				1.8004	
14				1.8004	
15				1.6632	
16				1.1317	1.749
17				.7373	1.9719
18			.8916	1.0288	1.0364
19			.8916	1.0288	1.0822
20			1.3717	1.0974	1.0669
21			1.3375	1.1145	1.0669
22			1.286	1.1145	1.0059
23			1.2003	1.0631	.9145
24				1.1145	1.0288
Max	.7202	.4115	1.3717	1.8004	1.9719
Min	.7202	.4115	.8916	.7373	.9145
Avg	.7202	.4115	1.1631	1.2303	1.1736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 206 / INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1029	.0857
2				.1029	.0857
3				.1029	.0857
4				.1029	.0857
5				.1029	.0857
6				.1029	.0857
7				.1029	.1029
8		.0686		.1029	.1029
9				.0857	.1029
10	.0514			.0857	
11				.1029	
12				.0857	
13				.1029	
14				.1029	
15				.0857	
16				.0857	.0857
17				.0857	.0857
18			.0857	.0857	.0857
19			.1029	.0857	.0857
20			.1029	.0857	.0857
21			.1029	.0857	.0857
22			.1029	.0857	.0857
23			.1029	.0857	.0857
24				.1029	.0857
Max	.0514	.0686	.1029	.1029	.1029
Min	.0514	.0686	.0857	.0857	.0857
Avg	.0514	.0686	.1000	.0943	.0886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.6401
2			.6859	.6401
3			.6859	.6401
4			.7011	.6401
5			.7316	.6401
6			.7316	.6401
7			.7926	.884
8		.1543	.9145	1.0364
9			1.0364	1.1431
10	.1029			
24			.6859	.6554
Max	.1029	.1543	1.0364	1.1431
Min	.1029	.1543	.6859	.6401
Avg	.1029	.1543	.7651	.7560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 208 / 11KV water supply express Sheddable Rural/Mix Feeder
feed Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0343	.0171
2				.0343	.0171
3				.0343	.0171
4				.0343	.0171
5				.0343	.0171
6				.0343	.0171
7				.0857	.0686
8		.1029		.12	.1029
9				.12	.1029
10	.1029			.1029	
11				.1029	
12				.12	
13				.1029	
14				.1029	
15				.1029	
16				.1029	.0857
17				.0171	.12
18			.1029	.0171	.0857
19			.0686	.0171	.1029
20			.0343	.0171	.0857
21			.0343	.0171	.0686
22			.0343	.0171	.0343
23			.0343	.0171	.0343
24				.0343	.0171
Max	.1029	.1029	.1029	.12	.12
Min	.1029	.1029	.0343	.0171	.0171
Avg	.1029	.1029	.0515	.0593	.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 201 / ASHATI TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7545	.5144	.5144		.6173	.6859
2	.6516	.7545	.5487	.5316		.6173	.7202
3	.6859	.0789	.5144	.6001		.6687	.823
4	.7545	.823	.6516	.7202		.6859	.8573
5	.823	.8573	.7716	.8059		.703	.9259
6	.8573	.8916	.9259	.9088		.8059	.9431
7	.9088	.9259	1.0631	1.0631		.8573	1.046
8	.8573		.9774	.8402		.9602	.7545
9	.2743		.823	.703		.9088	.8573
10	.3048				.7888		
11					.7545		
12			.5487		.6516	.6554	.703
13	.6859		.6687		.6344	.703	.6859
14	.6516		.5658		.6516	.6687	.6516
15	.6859		.583	.583	.6859	.6001	.6173
16	.7545			.6344		.6859	.6001
17	.7202	.6859		.6859		.7373	.7716
18	.6859	.703	.8059	.8573			.7716
19	.7545	.7716	.7202	.8745	.8573	.7373	
20	.823	.7888	.6859	.823	.9774	.7202	.7202
21	.8573	.7716	.703	.703	.823	.6687	1.0117
22	.823	.7202	.6516	.6859	.7373		.6687
23	.7888	.6001	.6173	.7202	.6516	.6516	.6173
24	.6173	.7545	.5487	.5487		.6001	.6173
Max	.9088	.9259	1.0631	1.0631	.9774	.9602	1.046
Min	.2743	.0789	.5144	.5144	.6344	.6001	.6001
Avg	.7083	.7254	.6944	.7265	.7467	.7126	.7643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 202 / KARALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9088	.6097	.7621		1.0669	1.0669
2	.8573	.8916	.6401	.7926		1.1736	1.2003
3	.823	.9259	.6859	.8383		1.2193	1.0974
4	.8916	.8916	.7316	.9145		1.2498	1.3413
5	.8573	.9259	.823	1.0059		1.2498	1.5242
6		.9945	.9145	1.0974		1.2346	1.7375
7		1.0288	.945	1.1431		1.6918	1.7985
8	1.0974		.9145	.9297		1.6461	1.9509
9			.8078	.7621		1.3108	1.7528
10	.2572				.5144		
11			.3944		.5658		
12					.5144	.6344	.6173
13			.4287		.5487	.6687	.6516
14	.6687				.5144	.6859	.6516
15	.6687			.4801	.5316	.7373	.6516
16	.7202			.583	.6687	.6859	.6516
17	.5658	.6097		.6173		.823	.7716
18	.5144	.6859	.6859	.7373		.8573	.7716
19	.6859	1.0117	.7545	1.0288	.6859	.9259	
20	.7373	1.046	.823	1.0802	1.1831	.9945	1.0117
21	.9945	1.0288	.9259		1.1145	1.0288	1.0117
22	.9431	.9431	.9431	1.0288	1.0288		.9259
23	.9774	.9088	.8573	.9945	.9431	.9259	.9088
24	.9259	.9431	.5335	.6859		.9602	1.0288
Max	1.0974	1.046	.945	1.1431	1.1831	1.6918	1.9509
Min	.2572	.6097	.3944	.4801	.5144	.6344	.6173
Avg	.7840	.9163	.7455	.8601	.7345	1.0367	1.1011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 203 / WAHEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0974	.884			1.3413	1.5242
2	1.0288	1.0974	.9755			1.4784	1.6766
3	.9945	1.0974	1.0517			1.5242	1.6766
4	.9431	1.0631	1.0974			1.5546	1.829
5	1.0288	1.0974	1.1431			1.6309	2.4082
6	1.0631	1.166	1.2193			1.9357	2.5149
7	1.1488	1.166	1.3108			1.7528	2.8654
8	1.1145		1.3717	1.2346		1.6766	2.9264
9	.583		1.448	1.2803		1.1736	1.5242
10	.5144				1.286		
11			.7202		.8573		
12			.703		.7545		.823
13			.6859		.7202		.7202
14					.703	.8573	.6859
15	.5144		.5144	.6344	.8745	1.046	.6516
16	.5487			.6516		1.0288	.6687
17	.8573			.6859		.9602	.7202
18	.9945		.6859	1.0802	1.0974	.9945	
19	.9945	1.1145	.823	1.4575	1.1488	1.0288	
20	.9945	1.166	.8916	1.5432	1.5432	1.286	1.3546
21	1.0974	1.1488	.9431	.9088	1.5604	1.3375	1.2193
22	1.1145	1.166	.9945	.9431	1.5775		1.2193
23	1.1488	1.0974	.9945	1.0117	1.5261	1.2517	1.2041
24	1.1488	1.0974	.7621			1.1736	1.2041
Max	1.1488	1.166	1.448	1.5432	1.5775	1.9357	2.9264
Min	.5144	1.0631	.5144	.6344	.703	.8573	.6516
Avg	.9448	1.1211	.9610	1.0392	1.1374	1.3175	1.4708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 205 / RAIGWAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0974	.823	.7716		1.0117	.9431
2	.945	1.2193	.7716	.823		.9945	.9602
3	1.1831	1.3717	.9431	.9431		1.0288	.9602
4	1.2346	1.4937	1.0631	1.0974		1.1488	.9945
5	1.3413	.1524	1.166	1.166		1.2003	.9945
6	1.3717	1.5242				1.2174	1.0288
7	1.5546	1.829				1.2003	.9431
8	1.5699		.823			1.166	1.0631
9	.2915		.8573	.7716		.9774	.8745
10	.3086				1.9204		
11			1.1888		2.6673		
12			.9602		2.774	2.6673	2.713
13	.3772		1.6766		2.7435	2.6825	2.3624
14	.4287		1.6004		2.6673	2.7435	2.3777
15	.4458			1.6309	2.6978	2.3015	2.4082
16				2.271		2.3929	2.4844
17		.5487		1.5089		2.3777	1.829
18			.6516	.4458	.7373	.7202	.6516
19	.823		.5373	.7202	.7716	.8573	
20	1.0974		.9088	1.0288	1.1488	.9602	.9431
21	1.0974		.9945	1.0288	1.0288	.9945	.9774
22	1.0631	.8573	.9259	1.1145	1.0117		.9431
23	1.0631	.8745	.8573	1.0288	.9431	.9431	.8916
24	.8745	1.0288	.8573	.823		.9088	.9431
Max	1.5699	1.829	1.6766	2.271	2.774	2.7435	2.713
Min	.2915	.1524	.5373	.4458	.7373	.7202	.6516
Avg	.9466	1.0906	.9781	1.0733	1.7593	1.4521	1.3470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134010 / 33/11 Kv ASHTI

Feeder No / Name : 206 / 11KV BHAGAWANNAGAR FEEDER Single Phasing Feeders
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0914	.1219		.2743	.1219
2	.0514	.0343	.1067	.1067		.3048	.1524
3	.0343	.0343	.1067	.1372		.3048	.1829
4	.0514	.0514	.1219	.1524		.3506	.1829
5	.0514	.0686	.1372	.1829		.3048	.2743
6	.0686	.0686	.1524	.2134		.3353	.3353
7	.0686	.0686	.1067	.3201		.3963	.4572
8	.0686		.1372	.381		.4877	.4877
9	.0572		.1524	.4115		.1829	.4725
10					.0343		
11					.0343		
12			.0343		.0343	.0343	.0171
13			.0171		.0343	.0343	
14	.0343		.0171		.0343	.0343	
15	.2229		.0343	.0343	.0343	.0514	
16	.1981			.0343	.0343	.0686	
17	.2058	.1715		.0343	.0343	.0857	.0343
18	.1334	.0343	.0171	.0343	.0343	.0686	.0381
19	.0914	.0686	.0343	.0686	.0514	.0686	
20	.0857	.0514	.0686	.0857	.0686	.0686	.1029
21	.0686	.0514	.0686	.0857	.0857	.0857	.0857
22	.0686	.0686	.0686	.0857	.0686		.0686
23	.0686	.0686	.0857	.0686	.0686	.0686	.0686
24	.0686	.0686	.0762	.1067		.0762	.0857
Max	.2229	.1715	.1524	.4115	.0857	.4877	.4877
Min	.0343	.0343	.0171	.0343	.0343	.0343	.0171
Avg	.0874	.0640	.0817	.1403	.0465	.1755	.1864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 201 / MAPEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5868	.8048	1.1401	.9221	1.291	1.2239
2		.5868	.8383	1.1736	.9221	1.3916	1.3077
3		.6203	.8551	1.0898	.9724	1.4251	1.358
4		.6874	.8718	1.073	1.0562	1.5089	1.3413
5		.788	.9054	1.1736	1.1401	1.5592	1.3748
6		.8718	.9892	1.0059	1.2239	1.6263	1.576
7		.7712	1.0059	1.3077	.2347	1.8275	1.861
8		.5365	1.0395	1.2407		1.7269	1.8442
9	.4024		.8383	1.1736		1.7772	1.8778
10	.9724		.8718	.2683		.4862	.3353
11		1.1401	.9054	.2515		.4694	.2515
12		1.073	.8886	.2515			.2347
13		1.1401	.2683				.2515
14		1.1736	.3018				
15	1.0059	1.1401	.3018			.4024	
16	.9724	1.1736	.3688				.2347
17	.9892	1.291	.4024			.4862	.2515
18	.285	.2683	.4191			.503	.3185
19	.4694	.4694	.6036		.7545	.6036	.3353
20	.6706	.4694	.6371	.6539	.8048	.6371	.4024
21	.6371	.5365	.6539	.6874	.7377	.6371	.4359
22	.5868	.503	.6371	.6371	.6203	.6036	.3688
23	.57	.4694	.6203	.5868	.5868	.5868	.3353
24	.5868	.5868	.8215	.8215	.9054	1.0898	.788
Max	1.0059	1.291	1.0395	1.3077	1.2239	1.8275	1.8778
Min	.285	.2683	.2683	.2515	.2347	.4024	.2347
Avg	.679	.7674	.7021	.8551	.837	1.0319	.8322

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 202 / SATONA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6371		.7209	.6706	.6706	.9054
2		.6706		.8048	.6874	.6874	.8383
3		.7209		.8048	.7042	.7545	.8718
4		.8048		.8718	.7712	.7545	.9389
5		.8718		.9389	.8718	.8718	.9724
6		1.0227		1.0059	1.0227	1.0059	1.0562
7		1.0395		.9556	.6706	1.0562	1.0898
8		1.0227					1.0395
9	.8551		.8383	.7042			1.0059
10	.6036		.8718	.7042		1.073	1.0562
11		.7545	.9054	.8048	.8718	1.0395	1.1736
12		.7712	.8886	.8215	.9724	.9054	1.0059
13		.7042	.8551	.8551	1.0059	.9389	1.1736
14		.6706	.8048	.8718	1.0227	1.0059	
15	.4694	.6539	.8383	.8551	1.0562	.9724	
16	.503	.6874	.7209	.8551	1.0898	1.0898	1.3077
17	.5868	.7042	.7042	.8383		1.0562	1.0395
18	.6706	.9724	.9556	.7209		.7712	.9724
19	.8383	1.0395	.9724	.8718	.8718	.8718	.9556
20	.8215	1.073	.9054	1.0395	1.0227	1.0227	.8383
21	.7712	1.0059	.6706	.9556	.9556	.9556	.8383
22	.7042	.9724	.6036	.788	.8215	.7042	.8048
23	.6371	.8048	.6203	.6874	.7377	.7209	.788
24	.6539	.6203		.5365	.6706	.6874	.6706
Max	.8551	1.073	.9724	1.0395	1.0898	1.0898	1.3077
Min	.4694	.6203	.6036	.5365	.6706	.6706	.6706
Avg	.6762	.8284	.8104	.8266	.8683	.8916	.9701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 203 / SHELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5533	.3688	.7042	.5868	.5533	.7042
2		.5533	.4359	.5868	.6036	.5533	.7377
3		.5868	.4694	.6371	.6036	.57	.7712
4		.6036	.503	.7042	.6371	.5868	.8048
5		.6539	.5197	.8048	.7377	.6371	.8215
6		.6874	.5365	.8718	.8383	.6706	.8215
7		.7209	.5868	.9389	.7377	.6371	.788
8		.7209	.503	.9556	.6706	.6203	.8383
9	.788		.4359	.285		.6036	.8551
10	.3353		.9892	.7377		.8215	1.0898
11		.2515	.5365	.8048	1.0227	.8048	1.1904
12		.285	.5868	.8383		.788	1.2071
13		.2683	.6203	.8718		.9054	1.0562
14		.2683	.7545	.8551	1.1736	1.1065	
15	.3353	.3018	.6203	.8718	1.2239	1.073	
16	.3688	.2683	.57	.8383	1.2742		1.2574
17	.4191	.4694	.5868	.8718			1.3413
18	.4694	.5365	.6371	.503			.6706
19	.6539	.6371	.6706	.6371	.6036		.7712
20	.7209	.8048	.6874	.7545	.7209		.8048
21	.6874	.788	.6706	.7209	.7042		.7712
22	.6539	.7545	.6371	.6371	.6539	.6371	.7209
23	.5868	.7209	.6203	.6036	.6036	.788	.6706
24	.5197	.5365	.6706	.5365	.5868	.5868	.7042
Max	.788	.8048	.9892	.9556	1.2742	1.1065	1.3413
Min	.3353	.2515	.3688	.285	.5868	.5533	.6706
Avg	.5449	.5441	.5924	.7321	.7768	.7191	.8817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 205 / DEVLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3521	.1006	.1341	.1341	.1341	.1509
2		.3521	.1006	.1509	.1341	.1341	.1341
3		.3688	.1006	.1677	.1509	.1341	.1174
4		.4191	.1174	.2683	.1677	.1509	
5		.4694	.1341	.3018	.218	.1677	
6		.5365	.1174	.3185	.2515	.1677	
7		.6371	.1174	.2683	.0671	.1844	
8		.7042	.218	.2515	.0503	.2012	
9	.5197		.1677	.2012		.1677	
10	.1341		.1844	.7209		.9221	
11		.1677	.57	.7712		.8886	1.0059
12		.1341	.6874	.788		.9054	1.0395
13		.1174	.7377	.8048		.9389	
14		.1006	.7042	.8551	.9556	.9724	1.0562
15	.1006	.1174	.7377	.8886	.9221		
16	.1006	.1006	.7209	.9054	.9054		1.0395
17	.1174	.1006	.7209	.8718		.9054	1.0395
18	.1509	.1174	.1174	.1677			.1174
19	.1844	.1509	.1677	.2347	.2012		.1341
20	.2347	.1509	.218	.2347	.2347		.1677
21	.218	.1677	.1677	.2012	.218		.2012
22	.2012	.1844	.1341	.1844	.2012	.1341	.1677
23	.1677	.1509	.1174	.1677	.1677	.1174	.1509
24	.4024	.3521	.1174	.1341	.1341	.1509	.1006
Max	.5197	.7042	.7377	.9054	.9556	.9724	1.0562
Min	.1006	.1006	.1006	.1341	.0503	.1174	.1006
Avg	.2110	.2705	.3032	.4164	.3008	.4098	.4415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 206 / DEVLTA WATER SUPPLY
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)
21		.0168
24	.0168	.1341
Max	.0168	.1341
Min	.0168	.0168
Avg	.0168	.0755

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 207 / Express Kedarwakdi
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0838	.0838	.0838		.1006	.1006
2		.0838	.1006	.0838		.1006	.1174
3		.0838	.1006	.1006		.0838	.0838
4		.0838	.1006	.1006		.0838	.1174
5		.0838	.1006	.1174		.0838	.1006
6		.0838	.1006	.1006		.1006	.1006
7		.1006	.1174	.1006		.1006	.1006
8		.1006	.1006	.0838		.1006	.1006
9	.0838		.1006	.1006		.0838	.1006
10	.0838		.1174	.1174		.1006	.1174
11		.1006	.1006	.1174		.1174	.1006
12		.1174	.1006	.1174		.1174	.1174
13		.1006	.1174	.1174		.1006	.1006
14		.1006	.1006	.1006	.0838	.1006	
15	.0838	.1174	.1006	.1174	.0838	.1006	
16	.0838	.1341	.1006	.1006	.1006		.0838
17	.1006	.1006	.1174	.1174			.1006
18	.1006	.1006	.1174	.1174			.1006
19	.0838	.1174	.1006	.1006	.0838		.1174
20	.1006	.1006	.1006	.1174	.0838		.1006
21	.0838	.1006		.1174	.0838	.1006	.1174
22	.0838	.1174		.1006	.1006	.1174	.1006
23	.0838	.1006		.1006	.1006	.1006	.1006
24	.0838	.0838	.1174	.1006		.1006	.0838
Max	.1006	.1341	.1174	.1174	.1006	.1174	.1174
Min	.0838	.0838	.0838	.0838	.0838	.0838	.0838
Avg	.088	.0998	.1046	.1055	.0901	.0997	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134017 / 33/11 Kv SATONA

Feeder No / Name : 208 / 11 KV IRREGATION EXPRESS

HV LIS Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0168	.0168	.0168		.0168	.0168
2		.0168	.0168	.0168		.0168	.0168
3		.0168	.0168	.0168		.0168	.0168
4		.0168	.0168	.0168		.0168	.0168
5		.0168	.0168	.0168		.0168	.0168
6		.0168	.0168	.0168		.0168	.0168
7	.0168	.0168	.0168	.0168		.0168	.0168
8	.0168	.0168	.0168	.0168		.0168	.0168
9	.0168		.0168	.0168		.0168	.0168
10	.0168		.0168			.0168	.0168
11		.0168	.0168			.0168	.0168
12		.0168	.0168	.0168		.0168	.0168
13		.0168	.0168	.0168		.0168	.0168
14		.0168	.0168	.0168	.0168	.0168	
15	.0168	.0168	.0168	.0168	.0168	.0168	
16	.0168	.0168	.0168	.0168	.0168	.0168	.0168
17	.0168	.0168	.0168	.0168		.0168	.0168
18	.0168	.0168	.0168	.0168		.0168	.0168
19	.0168	.0168	.0168	.0168	.0168	.0168	.0168
20	.0168	.0168	.0168	.0168	.0168	.0168	.0168
21	.0168	.0168	.0168	.0168	.0168	.0168	.0168
22	.0168	.0168	.0168	.0168	.0168		.0168
23	.0168	.0168	.0168	.0168	.0168	.0168	.0168
24	.0168	.0168	.0168	.0168		.0168	.0168
Max	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Min	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Avg	.0168	.0168	.0168	.0168	.0168	.0168	.0168

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 201 / SHRISHTI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1981			
2		.1829	.2134	.5792	.3353
3		.1829	.442	.7468	.3963
4		.1829	.4877	.7926	.4572
5		.1829	.5335	.8078	.535
6		.1829	.5335	.8078	.5944
7		.2378	.5639	.8383	.7727
8		.2972	.5792	.7926	.6093
9		.2896	.4778	.6554	.6836
19	.3048				
20	.2286				
21	.2286				
22	.2134				
23	.2134				
24		.1981			
Max	.3048	.2972	.5792	.8383	.7727
Min	.2134	.1829	.2134	.5792	.3353
Avg	.2378	.2135	.4789	.7526	.5480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 202 / PATODA Ag AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2439				
10				.6984	1.4937
11					1.8595
12			.1372		1.7833
13			.2591	1.5367	1.7528
14			.2439	1.6918	1.7223
15		.5182	.2439	1.2631	1.7223
16			.2286	1.5927	
17			.2134	1.5931	
Max	.2439	.5182	.2591	1.6918	1.8595
Min	.2439	.5182	.1372	.6984	1.4937
Avg	.2439	.5182	.2210	1.3960	1.7223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 203 / DATHANA Gao

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3921	.4191		.4191	.3961
2			.3734	.4382		.4001	.3772
3			.3772	.4572		.4572	.3772
4			.3961	.5525		.5144	.4527
5			.547	.743		.7049	.6036
6			.695	.7621		.7049	.7356
7			.6584	.7811		.724	.6602
8			.6401	.743		.724	.5847
9	.2096		.4938	.5658		.4763	.5281
10	.1715			.2829	.362	.3734	.4572
11				.2452	.2858		.3048
12				.2452	.2667	.2614	.2858
13				.1698	.2667	.3174	.2667
14	.1715			.132	.2858	.2801	
15	.2096			.132	.2858		
16	.2477			.2452	.362		
17	.362		.2858		.381	.3547	
18			.381		.4001	.4108	
19		.5415	.4191		.4382	.4854	.4382
20		.5415	.4572		.4763	.4481	.4572
21		.4481	.4572		.4191	.4294	.4001
22		.4108	.4191		.4001	.4294	.381
23		.3921	.4001		.4191	.4108	.381
24			.3921	.4191		.4191	.415
Max	.362	.5415	.695	.7811	.4763	.724	.7356
Min	.1715	.3921	.2858	.132	.2667	.2614	.2667
Avg	.2287	.4668	.4579	.4314	.3606	.4640	.4475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 204 / YENORA Gao

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2427	.2229		.2572	.2801
2			.2427	.2229		.2743	.2801
3			.2427	.2229		.2743	.2987
4			.2801	.2743		.3086	.3361
5			.2715	.6001		.3086	.3734
6			.3801	.3429		.3258	.3921
7			.362	.3601		.3429	.4108
8			.362	.3944		.3601	.3547
9			.2743	.3734		.2572	.2241
10	.0857			.168		.4024	.1886
11	.0857						.1029
12					.1029		.0857
13					.12	.3361	.0857
14	.1543				.1372	.3174	
15	.1543			.168	.1543	.2241	
16	.1715			.1307	.1715	.2801	
17			.1543		.1715	.2054	
18			.2229			.2801	
19		.3361	.2915		.2229	.3174	.2572
20		.3921	.3086		.2572	.2801	.3258
21			.3086		.2743	.2801	.3429
22		.2801	.2743		.2743		.3601
23		.2614	.2401		.2401	.2614	.2572
24			.2614	.2401		.2401	.2641
Max	.1715	.3921	.3801	.6001	.2743	.4024	.4108
Min	.0857	.2614	.1543	.1307	.1029	.2054	.0857
Avg	.1303	.3174	.2776	.2862	.1933	.2921	.2748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 205 / Ashti Water Supply Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0191	.0191		.0191	.0191
2			.0191	.0191		.0191	.0191
3			.0191	.0191		.0191	.0191
4			.0191	.0191		.0191	.0191
5			.0191	.0191		.0191	.0191
6			.0191	.0191		.0191	.0191
7			.0191				.0191
8			.0191				.0191
9			.0191			.0191	.0191
10							.0191
11				.0191			
12				.0191			.0191
13				.0191			.0191
14	.0191				.0191	.0191	
15	.0191				.0191		
16	.0191						
17	.0191						
18			.0191				
19		.0191	.0191				
20		.0191	.0191		.0191		
21		.0191	.0191		.0191		
22		.0187	.0191		.0191		
23		.0191	.0191		.0191	.0191	
24			.0191	.0191		.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0187	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0190	.0191	.0191	.0191	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 201 / LONI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.6668	.381	.381		.5335	.4572
2	.7373	.5935	.4191	.3429		.6478	.4954
3	.8192	.6443	.4572	.3429		.6859	.4572
4	.9012	.7811	.4763	.381		.724	.5335
5	.9831	.7042	.5144	.4382		.6859	.6097
6	1.0159	.6783	.5716	.4763		.7621	.5716
7	1.065	.8648	.6097	.4954		.7621	.4954
8	1.1797	1.1022	.3048	.4954		.2286	.3429
9	1.1469		.2667			.3048	.1905
10	.0762					1.0669	
11			.9602	.945	1.4746	1.2146	
12			1.0623	1.0669		1.2651	2.3434
13			1.0936	1.1431	1.3108	1.3441	2.372
14			1.4706	1.1431	1.5565	1.2803	2.1872
15	.0953		1.2193	1.6004	1.8023	1.2193	2.4291
16	.0953			1.9433	2.0481	1.1431	2.5301
17	.0953				1.8023	1.0669	2.5301
18	.1524			.2858	.2667	.1905	
19	.2031	.4191		.3429		.6668	
20	.3437	.5335		.381		.6097	.381
21	.3906	.4763	.4763	.4191	.381	.5716	.4572
22	.3906	.4763	.4763	.4572	.4191	.5335	.4954
23	.3749	.4572	.4572	.4954	.4001	.4954	.4572
24	.3605	.373	.4382	.0381		.4763	.4763
Max	1.1797	1.1022	1.4706	1.9433	2.0481	1.3441	2.5301
Min	.0762	.373	.2667	.0381	.2667	.1905	.1905
Avg	.5500	.6265	.6475	.6483	1.1462	.7700	1.0406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION

Feeder No / Name : 202 / CHANGATPURI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6668	.6325	.6173		.7449	.5761
2	.7049	.6859	.7116	.7116		.7682	.6249
3	.7621	.724	.703	.7287		.8535	.6859
4	.8573	.7621	.9326	.8697		.9503	.7253
5	.9335	.8383	.9717	.9488		.9145	1.326
6	.9717	.8954	1.085	1.0595		.9995	1.6095
7	.9526	.8764	1.2431	1.0437		.9962	1.3717
8	.7045	.8764	.7865	1.186		.9907	1.5546
9	.381		.6554	.8356		1.0669	1.1736
10	.1147					.5335	
11			.3239	.4191	.4191	.571	.4572
12			.3239	.4763	.381	.6859	.381
13			.3429	.5335	.4001	.6859	.381
14	.2515		.3429	.3429	.4572	.5716	.362
15	.3688		.381	.362	.4763	.5525	.4001
16	.3018			.381	.5906	.5716	.4382
17	.1696				.5525	.6097	.5906
18	.381		.5335	.5716	.6478	.6478	
19	.6478	.8573		.6478	.9145	.6859	
20	.7621	1.0479		.6859	.9717	.724	.8002
21	.8764	.9526	.9526	.724	.7811	.7621	.6668
22	.8383	.8573	.8002	.7621	.8764	.724	.7049
23	.8002	.8002	.7811	.8002	.8002	.6859	.7049
24	.724	.6668	.6226	.5468		.6097	.5792
Max	.9717	1.0479	1.2431	1.186	.9717	1.0669	1.6095
Min	.1147	.6668	.3239	.3429	.381	.5335	.362
Avg	.6272	.8220	.6908	.6934	.6360	.7461	.7673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 201 / TAKALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0762	.0762		.1905	.2134	.2286
2	.1372	.0857	.0762	.2858		.2134	.2286
3	.1543	.0857	.0762		.2477	.2743	.2286
4	.2401	.0857	.0762	.3429		.3963	.3048
5	.3258	.1029			.4001	.4572	.4572
6	.3601	.1029	.1524	.4191	.5335	.4725	.4572
7		.1372	.1524	.5144	.1715	.5792	.6097
8		.1372	.1829	.6287		.6249	.7011
9	.2229		.1677	.6478		.5944	.6401
10	.2134					.2401	.1715
11	.1677		.1715		.1372		
12	.1981		.12	.1143	.1543		.12
13	.1829		.0857	.0953		.1715	.1029
14	.1524		.0857			.1715	.1029
15	.1524				.0857	.1715	.1029
16	.1677				.1029	.1543	.1029
17	.1524			.1143	.1029		.12
18	.0857	.1715	.1372	.1143			.1543
19	.1886	.2572	.2058	.1905	.1543		.3258
20	.3086	.2572	.2401	.2286	.2058	.2401	.3086
21	.2401	.2058	.2572	.2667	.1715	.2401	.2743
22	.2058	.1715			.1543	.2058	.2401
23	.1715	.1715	.1715	.2477	.12	.1715	.2058
24	.1372	.1219	.0762	.1334	.1905		.1829
Max	.3601	.2572	.2572	.6478	.5335	.6249	.7011
Min	.0857	.0762	.0762	.0953	.0857	.1543	.1029
Avg	.1956	.1447	.1395	.2896	.1952	.3107	.2770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 202 / KHANDVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3048	.7716		.8764	.823	.7621
2	.3353	.3048	.7716	.9526		.823	.8573
3	.3963	.3048	.7716		.8764	.8573	.8573
4	.4572	.4572		.9907		.9945	1.0288
5	.5487	.6097	.8573		1.1431	1.1317	1.2003
6	.7164	.7621	1.0288	1.448	1.4289	1.2689	1.286
7		.8383	1.0288	1.3527	.4191	1.0631	1.0288
8		.884	.9088	.8383		.9774	.823
9	.6097		.8059	.8002		.823	.6173
10	.3772					.4268	.3201
11	.4115		.2896		.8383		
12	.2743		.3048	.7621	.6097		.5182
13	.2401		.4268	.4763		.6249	.5182
14	.3429		.5182			.6249	
15	.3429				.6097	.6706	.5487
16	.3601				.6706	.6401	.6097
17	.463			.8002	.7011	.5639	.5487
18	.4801	.7716	.5144	.4954		.583	.6344
19	.7373	.9088	.6401	.8764	.8916		.9945
20	1.0117	1.0117	.9088	1.1431	1.0288	.9431	.9259
21	.9602	.9602	.8745	1.0479	.9945	.9431	.9259
22	.9602	.8916			.9602	.9431	.9088
23	.8916	.8573		.9145	.9259	.8573	.8916
24	.3048	.3429	.8573	.8764	.8764	.8573	.8573
Max	1.0117	1.0117	1.0288	1.448	1.4289	1.2689	1.286
Min	.2401	.3048	.2896	.4763	.4191	.4268	.3201
Avg	.5253	.6807	.7223	.9183	.8657	.8305	.8029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION

Feeder No / Name : 203 / USMANPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.7621		1.3336	1.1279	1.2193
2	.2401	.2572	.7621	1.105		1.1888	1.2193
3	.2743	.2572	.7621		1.5242	1.2498	1.2193
4	.3258	.3429		1.2003		1.2193	1.5242
5	.4801	.3429	.7621		1.7147	1.4327	1.6461
6	.6516	.3429	.8383	1.3717	1.6194	1.4937	1.829
7		.4287	.8383	1.4861	.2667	1.7985	1.9814
8		.4287	.8688	1.7147		1.9204	2.0576
9	.3429		.9907	1.7337		1.9814	2.0119
10	.945					.3258	.2401
11	1.0669		.1715		.2743		
12	.8688		.2058	.1715	.2229		.1886
13	1.0059		.1886	.1524			.2058
14	1.0669		.1715				.2058
15	1.1126				.1543	.3258	.1715
16	1.0517				.1715	.2915	.1715
17	.884			.2096	.2058	.2401	.2401
18	.1372	.2572	.2401	.2286		.2915	.3944
19	.2743	.4287	.3772	.5144	.463		.463
20	.3429	.4115	.2915	.5144	.4458	.3258	.4115
21	.2058	.2058	.3086	.381	.3772	.3258	.3429
22	.2058	.2743			.3429	.3258	.3258
23	.2743	.2572	.381	.381	.3086	.2572	.2915
24	.2401	.2401	.6097	.9145	1.1812	1.0364	1.0669
Max	1.1126	.4287	.9907	1.7337	1.7147	1.9814	2.0576
Min	.1372	.2058	.1715	.1524	.1543	.2401	.1715
Avg	.5562	.3155	.5294	.8053	.6629	.9031	.8447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 201 / TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6859	.6001	.6859
2	.6001	.6859	.5144	.6859
3	.5144	.6859	.5144	.7716
4		.6859	.6001	.9431
5		.6859	.7716	.9431
6		.8573	.8573	.8573
7		.8573	.9431	1.0288
8		.9431	1.0288	1.0288
9		.8573	.9431	1.0288
10	.8573			.8573
11	.8573			.8573
12	.8573			.7716
13	.8573			.6859
14	.7716			.6859
15	.7716			.6859
16	.7716			.7716
17	.7716			
18	.8573			
19	.8573			
20	.8573			.8573
21	.9431			.8573
22				.6859
23				.6859
24		.6859		
Max	.9431	.9431	1.0288	1.0288
Min	.5144	.6859	.5144	.6859
Avg	.7830	.7630	.7525	.8188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 202 / RAMKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6001	.5144	.6001
2		.5144	.5144	.5144
3		.5144	.5144	
4		.5144	.5144	
5		.5144	.5144	
6		.5144	.6001	
7		.5144	.6001	
8		.5144	.6859	
9		.5144	.6859	
10	.3429	.5144		
11	.3429	.5144		.3429
12	.3429			.3429
13	.3429			.2572
14	.2572			.2572
15	.2572			.2572
16	.2572			.3429
17	.5144			
18	.5144			
19	.6001			
20	.6859			.5144
21	.6859			.5144
22				.5144
23				.5144
24			.5144	
Max	.6859	.6001	.6859	.6001
Min	.2572	.5144	.5144	.2572
Avg	.4287	.5222	.5658	.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 203 / AMBADGAON-AG

Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUL-17	23-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
10	.5144	.5144	
11	.5144	.4287	.5144
12	.5144	.4287	.5144
13	.4287		.5144
14	.4287		.4287
15	.4287		.4287
16	.3429		.4287
17	.3429		
Max	.5144	.5144	.5144
Min	.3429	.4287	.4287
Avg	.4394	.4573	.4716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.6859	.6859
2		.8573	.6859	.6001
3		.8573	.6001	.6859
4		.8573	.7716	.6859
5		.8573	.7716	.7716
6		1.0288		.7716
7		1.0288	.8573	.3429
8		1.0288		1.1145
9		.8573	1.0288	1.0288
10				.7716
11				.5144
12				.4287
13				.4287
14				.5144
15	.3429			.5144
16	.3429			.5144
20	1.0288			1.7147
21	1.2003			1.3717
22				.9431
23				.8573
24		.9431		
Max	1.2003	1.0288	1.0288	1.7147
Min	.3429	.8573	.6001	.3429
Avg	.7287	.9259	.7716	.7630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 205 / ROSHANGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4287	.3429
2		.4287	.4287	.3429
3		.4287	.4287	.3429
4		.4287	.4287	.5144
5		.4287	.5144	.6001
6		.4287	.7716	.6859
7		.6859	.6859	.7716
8		.5144	.6859	.6859
9		.4287		
10	.2572	.4287		
11	.2572	.4287		.4287
12	.2572	.4287		.4287
13	.2572	.3429		.4287
14	.2572	.3429		.4287
15	.2572	.3429		.4287
16	.2572	.3429		
17	.3429	.4287		.4287
18	.3429	.4287		.5144
19	.4287			.5144
20	.5144			.5144
21	.6001			.5144
22				.4287
23				.4287
24			.4287	
Max	.6001	.6859	.7716	.7716
Min	.2572	.3429	.4287	.3429
Avg	.3358	.4287	.5335	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 206 / AMBADGAON (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.1715	.3429
2		.1715	.1715	.3429
3		.1715	.1715	.3429
4		.1715	.1715	.4287
5		.1715	.1715	.5144
6		.2572	.3429	.5144
7		.4287	.3429	.5144
8		.3429	.3429	.5144
9		.3429	.1715	
19	.3429			
20	.3429			.2572
21	.3429			.2572
22				.2572
23				.1715
24			.1715	
Max	.3429	.4287	.3429	.5144
Min	.3429	.1715	.1715	.1715
Avg	.3429	.2667	.2229	.3715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 207 / WARUDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1145	.5144
2			1.1145	.5144
3			1.0288	.4287
4			1.0288	.5144
5			1.2003	.5144
6			1.5432	
7			1.2003	
8			1.1145	
9			.8573	
10	1.0288			.8573
11	1.0288			.8573
12	.8573	.6859		.7716
13	.8573			.7716
14	.8573			.6859
16	.5144			
17	.6001			
18	1.3717			
19	1.4575			
20	1.5432			1.0288
21	1.7147			1.0288
22				1.1145
23				1.0288
24			1.1145	
Max	1.7147	.6859	1.5432	1.1145
Min	.5144	.6859	.8573	.4287
Avg	1.0756	.6859	1.1317	.7594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 208 / COTTEX GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	23-JUL-17
HR	Load (MW)
10	.0154
Max	.0154
Min	.0154
Avg	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 209 / BAGADIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1715
2		.1715	.1715	.1715
3		.1715	.1715	.1715
4		.1715	.1715	.1715
5		.1715	.1715	.1715
6		.1715	.1715	.1715
7		.1715	.1715	.1715
8		.1715	.0857	.1715
9		.1715	.1715	
10	.2572	.1715		
11	.3429	.1715		.2572
12	.3429	.2572		.2572
13	.3429			.2572
14	.3429			.1715
15	.3429			.1715
16	.1715			.1715
17	.1715			
18	.1715			
19	.1715			
20	.1715			.1715
21	.1715			.1715
22				.1715
23				.1715
24			.1715	
Max	.3429	.2572	.1715	.2572
Min	.1715	.1715	.0857	.1715
Avg	.2501	.1786	.1629	.1858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 201 / DABHADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.7545	.7087	.7468	.7468		.7087
2	.7888	.7202	.7087	.8402	.823		.7087
3	.7888	.7935	.7087	.8316	.924		.7087
4	1.0517	.9831	.7011	.8402	.9335		.964
5	1.286	1.2651	.8764	1.0974	1.1203		1.1393
6	1.6766	1.9271	1.1145	1.2136	1.3717		1.3717
7	2.0553	2.1348	1.286	1.6804	1.6804		1.3717
8	2.3205	2.2672	1.286	1.6804	1.4937		1.286
9	1.2003		1.1145	1.5708	1.3032		1.0402
10			.7842	1.4403	2.0957	1.0288	
11			1.406	1.8023	2.2634	1.0288	
12			1.4403	1.7394	2.2377	.9431	
13			1.5089	1.7604	1.6766	.9431	2.3205
14			1.3927	1.1568	1.6766	.8573	1.9662
15	.7682		1.5089	1.5565	2.0119	.8573	
16	.7682		1.7814	1.6766	2.0119	.8573	
17	.8316			1.8861	1.6766	.6001	
18	.3361	.924		.6468	.543	.6268	.5868
19	.924	1.0631		1.4937	.7888	.7164	1.2597
20	1.0974	1.1145		1.2883	1.0517	1.1145	
21	1.0059	1.0288	1.1203	1.1088	1.1145	1.1145	
22	.961	.7716	.7762	.9709	.8859	.8669	.7282
23	.9145	.8059	.7762	.9335	.7973	.7802	.7545
24		.763		.7468	.8402		
Max	2.3205	2.2672	1.7814	1.8861	2.2634	1.1145	2.3205
Min	.3361	.7202	.7011	.6468	.543	.6001	.5868
Avg	1.0869	1.1544	1.1052	1.2795	1.3362	.8811	1.1277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013430 / 33KV DABHADI

Feeder No / Name : 202 / CHIKHALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7973	.8402	.7265	.763	.9259		.7888
2	.7973	1.1128	.7265	.8139	1.0288		.7888
3	.7973	1.1088	.7265	.9259	1.0059		.8413
4	.9882	1.6804	.8505	.9602	1.4575		1.0288
5	1.0288		.9774	1.4575	1.9433		1.286
6			1.0288	1.4575	2.5911		1.6598
7			1.2717	1.8404	2.5606		2.2377
8			1.5261	1.8842	3.3208		2.556
9			1.1831	1.989	3.3608		2.4143
10			.5041	.3734	.5316	.6516	
11			.5601	.3658		.6516	
12			.2801	.2801	.3801	.6516	.3326
13			.2801	.2772	.3801	.6516	.3326
14			.2772	.2801		.7421	
15	.7287		.3361	.2743	.3801	.7421	
16	.7287		.3361	.2801	.4887	.8145	
17	.7202			.5601	.543	.7421	
18	.5087	.543		1.1203	.7421	.7265	
19	1.1203	.7421		1.386	1.0317	.691	
20	1.0974	1.0631		1.0974	1.1163	.8939	
21	1.1203	1.0402	1.0974	1.1203	1.0631	.8413	.8962
22	.823	.9465	1.1203	.8402	.9036	.7973	
23	.8316	.8059	.8402	.7207	.9465	.7973	.7282
24		.7842		.6859	.7716		
Max	1.1203	1.6804	1.5261	1.989	3.3608	.8939	2.556
Min	.5087	.543	.2772	.2743	.3801	.6516	.3326
Avg	.8634	.9697	.7710	.9064	1.2488	.7425	1.2224

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 201 / NANEGAON-AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1478	.0924	.0857	.0857	.0857	.0857
2	.1478	.1478	.0739	.0686	.0686	.0857	.0686
3	.1663	.1663	.0924	.0686	.0686	.0857	.0686
4	.1294	.1848					
5	.1478	.2218					
6	.1848	.2587					
7	.2587	.2957					
8	.2772	.2772					
9	.2772						
10					.2058		.2772
11			.1543	.1886	.2743		
12			.2058	.1715	.1886	.2058	.2772
13			.1886		.2058	.2401	.2772
14			.1715		.2229	.2229	.2957
15			.1543		.2229	.2572	
16	.0739		.1715	.1715		.2743	.2957
17	.0739		.2058	.1886			.3326
18	.0739		.0857	.0857			.1294
19	.1109	.1109	.0857	.1029	.0857		.1294
20	.0924	.1109	.1029		.12	.1029	.1294
21	.1294	.1294	.1029		.1029	.1029	.1294
22	.1109	.1109	.0857	.0857	.0857	.1029	
23	.1294	.1109	.0857	.0857	.0857	.0857	.0924
24	.1294	.1294	.0924	.0857	.0857	.0857	.0857
Max	.2772	.2957	.2058	.1886	.2743	.2743	.3326
Min	.0739	.1109	.0739	.0686	.0686	.0857	.0686
Avg	.1478	.1716	.1266	.1157	.1406	.1490	.1783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 202 / NANEGAON (G)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924	.0924	.0924	.0857	.1029	.1029	.0857
2	.0739	.0739	.0924	.0686	.1029	.1029	.0857
3	.0739	.0739	.0739	.0686	.1029	.1029	.0857
4	.0924	.0924	.0924	.0857	.12	.12	.0857
5	.1848	.1478	.1478	.1029	.1372	.12	.1029
6	.2218	.1848	.1848	.12	.1543	.1372	.1372
7	.1848	.1848	.2033	.1715	.1543	.1372	.1715
8	.1478	.1478	.1478	.1372	.1715	.0857	.1029
9	.1294		.1294	.12		.0857	.0857
10	.1109				.0514		.0924
11	.0924		.0514	.0343	.0343		
12	.0924		.0514	.0343	.0514	.0857	.0924
13	.0924		.0514		.0514	.0686	.0924
14			.0514		.0514	.0686	.0924
15	.0554		.0514		.0514	.1029	
16	.0924		.0514	.0343		.0857	.0739
17	.1109		.0514	.0343			.0924
18	.1109		.0857	.0343			.1109
19	.1478	.1294	.1029	.0857	.1029		
20	.1478	.1478	.1372		.1715	.1372	.1294
21	.1294	.1663	.1372		.1543	.12	.1663
22	.1109	.1294	.12	.0857	.12	.1029	
23	.0924	.0924	.1029	.0857	.1029	.1029	.0924
24	.0924	.0895	.0924	.0857	.0857	.1029	.0857
Max	.2218	.1848	.2033	.1715	.1715	.1372	.1715
Min	.0554	.0739	.0514	.0343	.0343	.0686	.0739
Avg	.1165	.1252	.1001	.0819	.1037	.1038	.1032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 203 / SAIGAON

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1848	.1543	.2058	.2058	.2058
2		.2033	.1715	.2058	.2058	.2058
3		.2033	.1715	.2401	.2229	.2401
4		.2218	.1715	.2743	.2572	.2572
5		.2218	.1886	.3086	.2572	.2743
6		.2402	.2572	.3258	.2915	.3258
7		.2587	.3772	.3258	.3601	.4287
8		.3142	.3944	.5144	.5144	.4287
9		.3511	.4115		.5144	.463
10	.1848					
11	.2378					
12	.2587					
13	.2402					
15	.2587					
16	.2743					
17	.2772					
23			.1543			.2402
24		.1848		.1543		
Max	.2772	.3511	.4115	.5144	.5144	.463
Min	.1848	.1848	.1543	.1543	.2058	.2058
Avg	.2474	.2384	.2452	.2839	.3144	.3070

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 201 / SHELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0745	.9145	1.0374	1.0288		1.1888	1.0174
2	1.2403	.9145	1.1203	1.0288		1.2803	1.0174
3	1.4022	.9145	1.307	1.1022		1.3717	1.1022
4	1.4737	1.0059	1.4003	1.1869		1.4632	1.1869
5	1.5432	1.086	1.4937	1.2717		1.5546	1.3413
6	1.5432	1.1888	1.587	1.3413		1.5384	1.326
7	1.5432	1.2803	1.307	1.1736		1.5546	
8	1.4737	1.4413	1.307	1.3717		1.4632	1.3565
9	1.2403		1.587	1.3003			
10	.6554					.9431	
11			.8573	.905	1.2717		
12	.7316		1.0174	.7316	1.4746		
13	.823		.9221	.7316	1.3927	1.1469	
14			.9431	.7316		1.0774	
15			.9326	1.0745	1.2498	1.1736	
16			.8573	1.4737	1.406	1.2431	1.2403
17				1.5432	1.406	1.2289	1.3289
18	.9831	1.307	1.1393	1.1203	1.0059	1.1603	
19	1.3108	1.4937	1.3003	1.307	1.4632	1.3565	
20	1.587	1.4937	1.387	1.587	1.5546	1.326	1.587
21	1.4937	1.4003	1.4022	1.587	1.4632	1.3565	1.587
22	1.4937	1.307	1.2136	1.4937	1.4632	1.2003	1.4003
23	1.4937	1.307	1.1145	1.307	1.3717	1.1145	1.307
24	.905	.763	1.2136	1.0288	1.1203	1.2803	1.0288
Max	1.587	1.4937	1.587	1.587	1.5546	1.5546	1.587
Min	.6554	.763	.8573	.7316	1.0059	.9431	1.0174
Avg	1.2638	1.1878	1.2021	1.1925	1.3571	1.2868	1.2734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 202 / RAJEWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.0059	.6468	.6001		.6783	.4287
2	1.1203	1.0059	.7316	.6859		.763	.4287
3	1.307	1.0059	.8145	.6706		.763	.5087
4	1.587	1.0974	.905	.7545		.8192	.5935
5		1.0974	.9955	.8288		1.0174	.5935
6		1.1888	.9955	.9116		1.1469	.6783
7		1.1888	.9955	1.1603		1.1203	.763
8		1.0974	.9955	1.3717		1.2289	1.3927
9			.905	1.0288		1.1469	1.065
10	.5487					.8573	
11	.4915			.4715	1.3717		
12	.4915			.1886	.1867		
13	.5735		.4287	.1886	.1829	.5935	
14			.3467	.1886		.6783	
15			.037	.1886	.4572	.663	
16			.3467	.1509	.2743	.7459	
17					.5487	.8192	
18	.724	.9431	.6135		.7468	.8573	
19	.9145	1.307	1.0402		1.1203	.8478	
20	1.0269	1.307	.9745	.8488	1.3717	.9431	1.307
21	1.1203	1.1203	.964	1.0374	1.0974	.8573	1.1203
22	1.1203	.9431	.8764	1.1203	1.0059	.7716	
23	1.1203	.8488	.7011	1.307	.9145	.6859	
24	.9431	1.0269	.5601	.5201	.905	.6401	.4382
Max	1.587	1.307	1.0402	1.3717	1.3717	1.2289	1.3927
Min	.4915	.8488	.037	.1509	.1829	.5935	.4287
Avg	.9355	1.0789	.7437	.7111	.7833	.8475	.7765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 203 / BAJARANG CRUSHER FEEDER

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0183	.0189	.0187		.0183	.0187
2	.0189	.0183	.0189	.0187		.0183	.0187
3	.0189	.0183	.0189	.0187		.0187	.0187
4	.0189	.0183	.0189	.0187		.0183	.0187
5	.0189	.0183	.0189	.0187		.0187	.0187
6	.0189	.0183	.0189	.0187		.0187	.0187
7	.0189	.0183	.0189	.0187		.0187	.0187
8	.0189	.0177	.0189	.0185		.0183	.0187
9	.0189		.0189	.037		.0183	.0187
10						.0187	
11			.0187	.0754			
12	.0914		.0187	.0189	.0366		
13	.0183		.0187	.1132	.0549	.0185	
14			.0373	.0377		.0187	
15			.0373	.1132	.0747	.0187	
16			.0366	.0566	.0366	.0187	.0189
17				.0377	.0366	.0185	.0189
18	.0914	.0189	.0373	.0189	.0549	.0187	
19	.0732	.0189	.0373	.0189	.0366	.0187	
20	.056		.0187	.0189	.0187	.0187	.0189
21	.0187	.0189	.0187	.0189	.0183	.0187	
22	.0187	.0189	.0187	.0189	.0183	.0187	
23	.0183	.0189	.0187	.0189	.0187	.0187	.0189
24	.0189	.0187	.0189	.0373	.0189	.0187	.0187
Max	.0914	.0189	.0373	.1132	.0747	.0187	.0189
Min	.0183	.0177	.0187	.0185	.0183	.0183	.0187
Avg	.0319	.0185	.0230	.0343	.0353	.0186	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 201 / KANDARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429	.1858	.2572		.3142	.3563	.2401
2	.2267	.2515	.2572		.2915	.3887	.2343
3	.2591	.3353	.2601		.3239	.3563	.2515
4	.2915	.3353	.3506		.3239	.3887	.2515
5	.2915	.4144	.3506		.3881	.3563	.3277
6	.4049	.4915	.5373		.4049		.4687
7	.4858	.6535	.543		.6964	.8259	.7373
8	.4696		.543		.7935	.8259	.7907
9	.3887		.4525			.6478	.6478
10	.2801					.462	.3734
11			.1867		.1663	.3696	.2772
12			.1867		.1478	.2772	.1848
13	.1867		.1867	.2218	.1848	.2801	.1848
14			.1867	.1848		.3696	.1848
15	.1886		.1886		.1478	.3696	.2772
16	.1867		.2772	.2033	.2033	.4572	.2658
17	.1867			.2402	.2218	.4572	.2801
18	.3696		.3696	.3142		.3696	.3696
19	.5601	.5658	.5601	.3326	.462	.4668	
20	.6535	.5658		.6099	.6653	.462	.5658
21	.462	.4715	.5601			.4715	.4668
22	.462	.4715	.4572	.4251	.4251	.3772	.3734
23	.3696	.3772	.3772	.3326	.4066	.3772	.3772
24	.3353	.2572	.2572	.2572	.2753	.4049	.2458
Max	.6535	.6535	.5601	.6099	.7935	.8259	.7907
Min	.1867	.1858	.1867	.1848	.1478	.2772	.1848
Avg	.3477	.4136	.3498	.3122	.3601	.4399	.3642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 202 / KHADAKWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.3772	.381	.3696	.3696	.3326	.3734
2	.4954	.462	.4763	.3696	.462	.3696	.3772
3	.5335	.5544	.4763	.462		.4066	.3772
4	.5716	.6535	.5716	.5601	.5175	.462	.3772
5	.5716	.7545	.6668		.5544	.5175	.5658
6	.8192	.9431	.8573		.7023		.8488
7	.8764	.8488	.7621		.8131	.8131	.8488
8	.6097		.5716		.7023	.5914	.7545
9	.724		.4763			.5544	.5658
10	.4334						.6602
11	.5401		.523		1.004		.7116
12	.6602		.4877	.6154	1.0688		.7811
13	.5906		.523	.6478	1.2955	.5268	.703
14			.4801	.5182		.5268	.6944
15	.5401		.4334		1.2146	.8488	.6773
16	.5401		.4725	.583	1.3765	.6097	.6859
17	.4801			.9717	1.4251	.6249	.724
18	.2801		.1886	.3326		.3772	.2829
19	.4715	.6668	.5658	.462	.5544	.3772	
20	.5601	.5716		.7392	.5175	.4715	.5658
21	.4668	.4763	.7545			.4715	.4715
22	.4668	.4763	.4572	.5544	.3696	.3772	.3772
23	.462	.381	.3772	.462	.3696	.3734	.3772
24	.3048	.3734	.381	.3772	.3696	.3326	.3734
Max	.8764	.9431	.8573	.9717	1.4251	.8488	.8488
Min	.2801	.3734	.1886	.3326	.3696	.3326	.2829
Avg	.5424	.5799	.5183	.5350	.7604	.4982	.5728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 203 / WALHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.3887	.4572		.5182	.583	.3125
2	.5182	.3829	.4572		.5668	.6154	.3953
3	.5668	.3887	.463		.6478	.5668	.3906
4	.583	.4468	.4687		.6478	.583	.4858
5	.6154	.4534	.4744		.6478	.6478	.5935
6	.9526	.5563	.6401		.8907		.7888
7	.8421	.7202	.6478		1.166	.8907	.7811
8	.8907		.8097		1.0526	1.0364	.8592
9	.8907		.6478			1.1336	.9374
10	.5601						.6602
11	.2772				.3326		.462
12	.2772		.2801	.2772	.3696		.3696
13	.3696		.3658	.2587	.1848	.6602	.3772
14			.3696	.2957		.7545	.3772
15	.3696		.3734		.2957	.6097	.3772
16	.3696		.3734	.2218	.3326	.7545	.3772
17	.4715			.3696	.4066	.5601	.5658
18	.6602		.462	.4251		.5658	.7545
19	.7468	.9526	.5601	.5544	.7392	.5658	
20	.9431	.7621		.7392	.961	.7545	.9431
21	.6535	.6668	.6535			.7545	.6602
22	.6535	.5716	.5601	.6283	.6283	.5658	.5658
23	.6602	.4763	.5487	.5544	.5544	.4668	.5658
24	.6371	.3887	.4572	.3829		.6154	.3163
Max	.9526	.9526	.8097	.7392	1.166	1.1336	.9431
Min	.2772	.3829	.2801	.2218	.1848	.4668	.3125
Avg	.6099	.5504	.5035	.4279	.6079	.6842	.5616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013445 / 33 KV KANDARI

Feeder No / Name : 204 / UJJAINPURI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3772	.4715		.4066		.462
2	.4763	.3696	.4715			.5175	.462
3	.5716	.4191	.5658		.462	.5175	.4668
4	.6097	.4973	.5658			.5544	.5601
5		.5735	.5658		.5729	.5544	.6602
6	.7621	.7373	.6602		.6468		.7545
7	.6668	.4096	.5658		.6283	.5914	.6602
8	.5335		.4715		.4805	.4066	.5658
9	.4001		.3772			.3881	.4715
10	.2515					.2486	.2515
11	.2515		.1715		.2429		.2458
12	.2515		.1715	.2429	.2591		.2458
13	.2515		.1696	.2267	.2591	.2458	.2458
14			.1715	.1296		.2458	.2429
15	.1715			.081		.2458	.1715
16	.2515		.1715	.0972	.2591	.3239	.2772
17	.2572			.1781	.1619	.2458	.2515
18	.4066		.1886	.2772		.462	.3696
19	.462	.5658	.2772	.3511	.462	.4668	
20	.462	.5658		.6099	.5729	.462	.5658
21	.462	.4715	.462			.5658	.5658
22	.462	.4715	.3658	.4435	.4805	.4668	.4715
23	.3696	.4715	.3734	.4251	.462	.462	.3696
24	.4763	.3696	.4715	.3772	.4066	.462	.462
Max	.7621	.7373	.6602	.6099	.6468	.5914	.7545
Min	.1715	.3696	.1696	.081	.1619	.2458	.1715
Avg	.4194	.4846	.3855	.2866	.4227	.4217	.4261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 201 / TADEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0288	1.0288	.8573	.8573	1.0288	.8573
2	.9431	1.0288	1.0288	.8573	.8573	1.0288	.8573
3	.8573	1.0288	1.0288	.8573	.8573	1.0288	.8573
4	.9431	1.0288	1.1145	.8573	.8573	1.1145	.8573
5	1.1145	1.1145	1.286	1.0288	1.2003	1.286	1.2003
6	1.286	1.2003	1.3717	1.1145	1.4575	1.4575	1.7147
7	1.286	1.2003	1.5432	1.2003	1.9719	1.5432	1.9719
8	1.286	1.2003	1.3717	1.1145	2.0576	1.8004	2.2291
9	.8573		1.3717	.8573			
10	.4287		.5716	.3429			
11	.3429		.381	.4287			
12	.3429		.381				.8573
13	.3429		.381				.6859
14	.3429		.4763	.3429	.5716		.5144
15	.3429			.5144	.7621		.5144
16				.6001	.7621		.5144
17	.3429			.6859			
18	1.1431		.8573	.9431	1.2003		
19	1.5242	1.5432	1.1145	1.2003	1.7147		
20	1.5242	1.4575	1.5432	1.6289	1.6289	1.5432	
21	1.3336	1.3717	1.6289	1.6289	1.5432	1.6289	
22	1.3336	1.4575	1.5432	1.4575	1.5432	1.6289	
23	1.3336	1.3717	1.286	1.286	1.4575	1.4575	1.6289
24	.9431	1.0288	.8573	.8573	.8573	.8573	.8573
Max	1.5242	1.5432	1.6289	1.6289	2.0576	1.8004	2.2291
Min	.3429	1.0288	.381	.3429	.5716	.8573	.5144
Avg	.9153	1.2186	1.0555	.9392	1.2310	1.3388	1.0745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 202 / BHOKARDAN TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.5432	1.286	1.2003	1.2003	1.3717	1.2003
2	1.2003	1.5432	1.286	1.2003	1.2003	1.3717	1.2003
3	1.2003	1.5432	1.286	1.2003	1.2003	1.3717	1.2003
4	1.2003	1.7147	1.286	1.2003	1.2003	1.3717	1.2003
5	1.3717	.1715	1.4575	1.3717	1.3717	1.4575	1.4575
6	1.7147	1.7147	1.7147	1.8861	1.8861	1.7147	1.8004
7	1.9719	1.7147	2.1434	2.0576	2.0576	1.9719	1.9719
8	1.8004	1.8861	1.8861	1.8861	1.8861	1.9719	1.8004
9	1.7147		1.8861	1.8004			
10	1.4575		1.7147	1.6289			
11	1.3717		1.5432	1.3717			
12	1.3717		1.3717	1.2003			1.7147
13	1.3717		1.2003	1.2003			1.5432
14	1.3717		1.2003	1.2003	1.0288		1.5432
15	1.3717			1.2003	1.5432		1.3717
16	1.3717			1.286	1.5432		1.3717
17	1.3717			1.4575			
18	1.5432	1.3717	1.4575	1.5432	1.7147		
19	1.7147	1.6289	1.4575	1.6289	1.7147		
20	1.7147	1.5432	1.7147	1.8004	1.6289	1.4575	
21	1.7147	1.4575	1.4575	1.6289	1.5432	1.4575	
22	1.7147	1.3717	1.3717	1.4575	1.4575	1.286	
23	1.7147	1.3717	1.286	1.3717	1.3717	1.2003	1.3717
24	1.3717	1.7147	1.286	1.2003	1.286	1.3717	1.2003
Max	1.9719	1.8861	2.1434	2.0576	2.0576	1.9719	1.9719
Min	1.2003	.1715	1.2003	1.2003	1.0288	1.2003	1.2003
Avg	1.4968	1.4860	1.4901	1.4575	1.4908	1.4904	1.4632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 203 / Sipora BZ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.1431	1.2003	1.2003	1.2003	1.2003	1.2003
2	1.1145	1.1431	1.2003	1.2003	1.2003	1.2003	1.2003
3	1.1145	1.1431	1.2003	1.2003	1.2003	1.2003	1.2003
4	1.1145	1.3336	1.2003	1.2003	1.2003	1.2003	1.2003
5	1.286	1.7147	1.286	1.286	1.286	1.286	1.286
6	1.5432	1.3336	1.4575	1.3717	1.3717	1.4575	1.3717
7	1.3717	1.3336	1.3717	1.286	1.2003	1.286	1.2003
8	1.1145	.9526	1.0288	1.1145	1.0288	1.1145	1.1145
9	.4287		1.1431	1.0288			
10	.5144		.5144	.5144			
11	.5144		.5144	.6001			
12	.6001		.5144				.6859
13	.5144		.4287	.2572			.8573
14	.5144		.3429	.2572	.5144		.8573
15	.5144			.3429	.5144		.8573
16	.5144			.5144	.4287		.8573
17	.3429			.6859			
18	1.1431	1.1145	.9431	.7716	1.0288		
19	1.3336	1.3717	1.0288	1.0288	1.2003		
20		1.3717	1.6289	1.6289	1.6289	1.3717	
21	1.3336	1.3717	1.4575	1.3717	1.4575	1.4575	
22	1.3336	1.2003	1.3717	1.286	1.3717	1.286	
23	1.1431	1.2003	1.286	1.286	1.3717	1.286	1.3717
24	1.1145	1.1431	1.2003	1.2003	1.2003	1.286	1.2003
Max	1.5432	1.7147	1.6289	1.6289	1.6289	1.4575	1.3717
Min	.3429	.9526	.3429	.2572	.4287	1.1145	.6859
Avg	.9406	1.2580	1.0628	.9841	1.1336	1.2794	1.0974

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 204 / Malkapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.6668	.6859	.5144	.5144	.6859	.5144
2	.4287	.6668	.6859	.5144	.5144	.6859	.5144
3	.4287	.6668	.6859	.5144	.5144	.6859	.5144
4	.4287	.7621	.6859	.5144	.5144	.6859	.5144
5	.6001	.9526	.7716	.6859	.5144	.7716	.7716
6	.7716	1.1431	.8573	1.2003	.5144	.9431	1.286
7	.8573	1.1431	1.0288	.7716	1.286	.8573	1.1145
8	.3429	.7621	.8573	.6859	1.1145	.6859	.9431
9	.1715		.9526	.5144			
10	.1715		.3429	.1715			
11	.1715		.3429	.1715			
12	.1715		.3429	.1715			.3429
13	.1715		.1715	.1715			.3429
14	.2572		.1715	.1715			.2572
15	.1715			.1715			.2572
16	.1715			.1715			.1715
17	.1715			.2572			
18	.5716	.6859	.5144	.3429	.6001		
19	.5716	.9431	.6001	.7716	.8573		
20	.6859	.8573	1.0288	1.0288	.9431	.7716	
21	.7621	.6859	.8573	.8573	.7716	.6859	
22	.7621	.6859	.6859		.6859	.6859	
23	.7621	.6859	.6001	.6859	.6859	.6001	.6859
24	.5144	.6668	.6859	.5144	.6001	.6859	.5144
Max	.8573	1.1431	1.0288	1.2003	1.286	.9431	1.286
Min	.1715	.6668	.1715	.1715	.5144	.6001	.1715
Avg	.4394	.7983	.6455	.5032	.7087	.7255	.5830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134002 / BHOKARADAN 33 KV

Feeder No / Name : 207 / Perjapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2858	.1715	.2572	.3429	.2572	.2572
2	.2572	.2858	.1715	.2572	.3429	.2572	.2572
3	.2572	.2858	.1715	.2572	.3429	.2572	.2572
4	.2572	.2858	.1715	.2572	.3429	.2572	.2572
5	.3429	.381	.2572	.3429	.3429	.3429	.3429
6	.5144	.381	.4287	.4287	.4287	.5144	.5144
7	.5144	.381	.6859	.4287	.5144	.6859	.5144
8	.4287	.381	.5144	.3429	.5144	.5144	.4287
9	.2572		.5144	.2572	.3429		
10	.1715		.381	.1715	.2572		
11	.1715		.1905	.2572	.2572		
12	.1715		.1905	.1715	.2572		.1715
13	.1715		.1715	.1715	.2572		.1715
14	.2572		.1715	.1715	.3429		.3429
15	.1715		.1715	.6859	.3429		.4287
16	.1715			.3429	.3429		.4287
17	.1715			.4287			
18	.381	.6001	.2572	.3429	.4287		
19	.381	.6859	.2572	.4287	.6001		
20	.381	.5144	.4287	.5144	.6859	.4287	
21	.381	.4287	.3429	.4287	.5144	.4287	
22	.381	.2572	.2572	.3429	.2572	.3429	
23	.381	.2572	.2572	.3429	.2572	.2572	.2572
24	.2572	.381	.1715	.2572	.3429	.2572	.2572
Max	.5144	.6859	.6859	.6859	.6859	.6859	.5144
Min	.1715	.2572	.1715	.1715	.2572	.2572	.1715
Avg	.2953	.3861	.2880	.3287	.3765	.3693	.3258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 201 / KHAMKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763		.4287	.6859		.5144	.3429
2	.4763		.4287	.6001		.5487	.3429
3	.381		.4287	.5144		.5144	.4287
4	.4763		.3429	.5144		.4801	.4287
5	.5716		.4287	.7202		.5487	.5144
6	.7621		.6859	.7716		.6001	.6859
7	.5716		.4287	.6173		.6859	.7716
8	.4763		.4458	.6859		.8573	.7716
9	.4382		.3772		.6001		.7716
10			.2286		.1905	.4763	
11			.1905	.1905	.2286	.381	
12				.1905	.2286	.2858	
13					.1905	.2858	
14					.1905	.381	
15	.1905				.2858	.381	
16	.1905				.1905	.381	
17	.1905			.1905	.381	.381	
18	.2858			.1905	.6668	.4763	.381
19	.2858	.381	.2858	.2858	.7621	.5335	.381
20	.2858	.381	.3429	.2858	.724	.5335	.381
21	.2858	.381	.3048	.1905	.8002	.5716	.381
22	.381	.4763	.381	.1905	.5906	.5716	.381
23	.381	.5716	.4191	.1905	.6287	.6287	.381
24	.5716	.381	.3429	.4287	.5716	.7716	.5144
Max	.7621	.5716	.6859	.7716	.8002	.8573	.7716
Min	.1905	.381	.1905	.1905	.1905	.2858	.3429
Avg	.4041	.4287	.3818	.4135	.4519	.5126	.4912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 202 / Chandai Th

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4763	.6668		.7621	
2	.3429		.4763	.5716		.6668	
3	.3429		.381	.5716		.6097	
4	.3429		.4763	.8573		.5716	
5	.4287		.5716	.7621		.4763	
6	.4287		1.0479	.8002		.5335	
7	.5144		.5716	.9526		.7621	
8	.4287		.4763	.8002		1.0098	
9	.5144		.5335		.5716		.5716
10			.5487		.5316	.5144	
11			.5144	.4763	.5144	.6001	
12				.4763	.6516	.5144	
13				.381	.7202	.5144	.5716
14				.381	.6859	.4287	.5716
15	.1905			.381	.6516	.5144	.5716
16	.1905	.1905		.4763	.5144	.5144	.5716
17	.1905	.2858	.4287	.4763	.5487	.4287	.5716
18	.2858	.6668	.4191				.381
19	.5716	.5716	.4572	.381			.381
20	.381	.5716	.381	.381	.5716		.381
21	.381	.4763	.381	.381	.6097		.381
22	.381	.4763	.5716	.381	.6668		.381
23	.381	.5716	.6097	.381	.5716		.381
24	.5144	.381	.4763	.6668	.381	.5716	
Max	.5716	.6668	1.0479	.9526	.7202	1.0098	.5716
Min	.1905	.1905	.381	.381	.381	.4287	.381
Avg	.3765	.4657	.5157	.5525	.5851	.5878	.4763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 203 / Rajur Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3429	.6001		.5144	.4287
2	.3429		.3429	.4801		.5316	.4287
3	.3429		.3429	.4287		.4801	.3429
4	.3429		.3429	.5144		.3772	.3429
5	.4287		.4287	.5487		.4287	.4287
6	.5144		.5144	.4801		.4287	.5144
7	.4287		.4287	.5144		.3601	.5144
8	.5144		.4287	.5316		.4973	.6001
9	.4287		.4115		.4287	.5144	.4287
10			.3772		.3772	.3429	
11			.4287	.2858	.3429		
12			.3944	.2858	.3429	.4287	
13				.2858	.4115	.3429	.2858
14		.3429		.2858	.3429	.3429	.2858
15	.2858	.3429		.2858	.3086	.3429	.2858
16	.2858	.3429		.2858	.2915	.4287	.2858
17	.2858	.3429	.3944	.2858	.4287	.4287	.2858
18	.4763	.4287	.4287	.381	.4115	.3429	.381
19	.4763	.3429	.3772	.381	.4801	.3772	.381
20	.381	.3429	.4801	.381	.5144	.3429	.381
21	.381	.3429	.5144	.381	.5487	.2572	.381
22	.381	.3429	.5487	.381	.4287	.3429	.381
23	.381	.2572	.4973	.381	.4801	.2572	.381
24	.4287	.381	.2572	.583	.381	.4458	.3429
Max	.5144	.4287	.5487	.6001	.5487	.5316	.6001
Min	.2858	.2572	.2572	.2858	.2915	.2572	.2858
Avg	.3921	.3464	.4141	.4076	.4075	.3981	.3851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 204 / LONGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287		.4763	1.0479		.5716	.5716
2	.5144		.381	.9526		.6097	.5716
3	.5144		.4763	.9907		.8002	.4763
4	.4287		.4763	.8573		.7811	.5716
5	.5144		.5716	1.1431		.6668	.6668
6	.7716		.6668	.9907		.8002	1.1431
7	.6859		.5716	1.1622		.7621	.7621
8	.7716		.5716	.9907		.9907	
9	.5144		.5716		.6668		
10			.6859		.6859	.4287	
11			.6516		.7716	.5144	
12					.8573	.5144	
13					.8916	.5144	.5716
14		.2858			1.0117	.4287	.5716
15	.2858	.2858		.5716	.8916	.5144	.5716
16	.2858	.381		.5716	.9431	.4287	.5716
17	.2858	.5716	.6001	.7621	.6859	.5144	.5716
18	.5716	.5716	.7621	.381	.6668	.4763	.381
19	.7621	.4763	.8002	.381	.8573	.6668	.381
20	.5716	.4763	.9145	.381	.7621	.5716	.381
21	.381	.4763	.6668	.381	.7621	.4763	.381
22	.381	.4763	.6859		.724	.4763	.381
23	.381	.5716	.9526		.5716	.4763	.381
24	.5144	.4763	.4763	.9907		.8573	.4763
Max	.7716	.5716	.9526	1.1622	1.0117	.9907	1.1431
Min	.2858	.2858	.381	.381	.5716	.4287	.381
Avg	.5034	.4590	.6294	.7847	.7833	.6018	.5465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 205 / TAPOWAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.3429	.6859		.6859	.3429
2	.4763		.3429	.7202		.5144	.3429
3	.5716		.4287	.8916		.7716	.3429
4	.5716		.4287	.9431		.8573	.3429
5	.6668		.4287	1.0288		.8573	.4287
6	.9526		.4287	.9259		.7716	.4287
7	.7621		.4287	.7716		.9431	.6001
8	.4763		.3429	.6516		1.0288	.7716
9	.5335		.4458		.6516		.7716
10					.2667	.4763	
11					.2286	.4763	
12					.1905	.4763	
13					.2096	.381	.1905
14		.3429			.1905	.381	.1905
15		.3429		.1905	.2858	.4763	.2858
16		.2572		.1905	.381	.4763	.2858
17		.3429	.2477	.1905	.5716	.4763	.381
18		.4191	.5716	.381	.4763	.4763	.381
19		.4763	.6668	.381	.4763	.5716	.381
20		.4763	.6097	.381	.5716	.4763	.381
21		.4763	.5716		.5335	.4763	.381
22		.381	.5716		.5716	.381	.381
23		.4763	.6097		.6097	.4763	.381
24	.4763			.6859		.6859	.5716
Max	.9526	.4763	.6668	1.0288	.6516	1.0288	.7716
Min	.4763	.2572	.2477	.1905	.1905	.381	.1905
Avg	.6059	.3991	.4667	.6013	.4143	.5910	.4078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 206 / CHANDAI EKKO

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.3429	.6859		.6859	.3429
2	.5716		.3429	.6001		.7202	.3429
3	.5716		.2572	.7202		.6001	.2572
4	.4763		.2572	.7716		.6516	.3429
5	.6668		.3429	.6516		.5144	.3429
6	.9526		.3429	.5144		.5144	.3429
7	.4763		.4287	.6001		.5144	.5144
8	.5716		.4287	.6344		.6001	.7716
9	.4954		.3429		.5144		.6001
10			.2858		.4763	.2858	
11			.1905			.2858	
12						.2858	
13						.2858	.1905
14		.2572				.381	.1905
15		.2572			.1905	.381	.1905
16		.2572			.2286	.381	.1905
17		.3429			.2858	.2858	.2858
18		.381		.381	.381	.381	.381
19		.381	.381	.381	.5335	.4763	.381
20		.381	.4191	.381	.5716	.381	.381
21		.381	.4763		.724	.381	.381
22		.381	.4572		.8002	.4763	.1905
23		.381	.1905		.5716	.381	.1905
24	.4763		.3429	.5487		.6001	.3429
Max	.9526	.381	.4763	.7716	.8002	.7202	.7716
Min	.4763	.2572	.1905	.381	.1905	.2858	.1905
Avg	.5830	.3401	.3429	.5725	.4798	.4543	.3406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134006 / 33 KV RAJUR

Feeder No / Name : 207 / AT&T TOWER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0829	.0829		.0829	.0829
2		.0829	.0829		.0829	.0829
3		.0829	.0829		.0829	.0829
4		.0829	.0829		.0829	.0829
5		.0829	.0829		.0829	.0829
6		.0829	.0829		.0829	.0829
7		.0829	.0829		.0829	.0829
8		.0829	.0829		.0829	.0829
9		.0829		.0829		.0829
10		.0829		.0829	.0829	
11		.0829	.0953	.0829	.0829	
12				.0829	.0829	
13				.0829	.0829	.0953
14	.0829			.0829	.0829	.0953
15	.0829		.0953	.0829	.0829	.0953
16	.0829		.0953	.0829	.0829	.0953
17	.0829	.0829	.0953	.0829	.0829	.0953
18	.0829	.0829	.0953	.0829	.0829	.0953
19	.0829		.0953	.0829	.0829	.0953
20	.0829	.0829	.0953	.0829	.0829	.0953
21	.0829	.0829	.0953	.0829	.0829	.0953
22	.0829	.0829	.0953	.0829	.0829	.0953
23	.0829	.0829	.0953	.0829	.0829	.0953
24		.0829	.0829	.0953	.0829	.0829
Max	.0829	.0829	.0953	.0953	.0829	.0953
Min	.0829	.0829	.0829	.0829	.0829	.0829
Avg	.0829	.0829	.0894	.0837	.0829	.0894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 201 / ANWA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.3429	.3429	.5601	.7164	.3429	1.086
2	.8954	.3277	.3429	.5601	.7164	.3429	1.0288
3	.8954	.3429	.3429	.5601	.7164	.3429	1.0402
4	.8954	.3429	.5144	.5601	.7164	.3429	1.2003
5	1.0745	.4334	.6859	.5601	.7164	.6859	1.7337
6	1.0745	.8573	.8573	.7164	.8954	.6859	2.13
7	1.0745	.7621	.8573	.9145	.8954	.8573	1.9814
8	.8954	.8478	.8573	.8954	1.0745	.8573	1.8652
9	.7164		.8573	.9145		.8573	1.4327
10			.7316		.8573	1.2803	1.0974
11	.4477		.7316		.6859		.7316
12	.4287		.7316	.7164	.6859	.9335	.3734
13			.5544	.7316		.9335	
14			.5601	.7164		.7468	
15	.6859		.5601	.7316	.6859		
16			.7316	.7316	.6859	1.0174	
17			.9145	.7316	.8573	1.0288	
18	1.1203		1.0745	1.0745	1.0288	1.4937	
19	1.3203	1.2003	1.2536	1.4022	1.3717		
20	1.8671	1.2003	1.4327	1.4022	1.3717	1.5089	
21	1.307	1.0288	1.2803	1.4022	1.2003	1.307	
22	1.307	1.0288	1.0745	1.0517	1.2003		
23	1.1203	.8573	1.0974	1.0745	1.2003	1.1088	1.0974
24	.5487	.3734	.3429	.3772	.7316	.3429	1.0745
Max	1.8671	1.2003	1.4327	1.4022	1.3717	1.5089	2.13
Min	.4287	.3277	.3429	.3772	.6859	.3429	.3734
Avg	.9679	.7104	.7804	.8357	.9052	.8508	1.2766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 202 / JALGAON SAPKAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.3658	.5144	.5658	.7164	.5144	.1829
2	.7164	.3429	.5144	.5658	.7164	.5144	.1829
3	.7164	.3391	.6859	.5658	.7164	.5144	.1791
4	.7164	.4572	.6859	.5658	.7164	.5144	.1753
5	.8954	1.0288	.8573	1.0974	.7164	.6859	.3429
6	1.0745	1.2136	1.0288	1.0745	.8954	1.0288	.4239
7	1.2269	1.1869	1.0288	1.0745	.8954	1.0288	.4287
8	1.0745	.9831	.8573	1.0745	.8954	1.0288	.4334
9	1.0745		.8573	.5487		.8573	.4287
10			.5487		.5144	.3582	.3772
11	.3429		.3734		.5144		.1886
12	.3467		.3734	.5487	.3429		.1867
13	.4382		.1886	.5487		.2572	
14			.1886	.5487		.2572	
15	.3048		.1886	.5487	.3429		
16	.3125		.1886	.5487	.3429	.3277	
17			.1886	.5487	.5144	.3429	
18	.4239		.5487	.5487	.8573	.4572	
19	.9335	.8573	.5487	.7164	1.0288		
20	1.1203	.8573	.8954	.7164	.8573	.5658	
21	.5601	.8573	1.0974	.7164	.8573	.5658	
22	.5601	.8573	.9145	.7316	.6859		
23	.5601	.8573	.5487	.7316	.6859	.4668	.5487
24	.7316	.3734	.5144	.5658	.7316	.5144	.1791
Max	1.2269	1.2136	1.0974	1.0974	1.0288	1.0288	.5487
Min	.3048	.3391	.1886	.5487	.3429	.2572	.1753
Avg	.7070	.7555	.5974	.6887	.6926	.5684	.3042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 203 / WAKDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.1791	.3429	.3772	.5373	.3429	.9335
2	.7164	.1715	.3429	.3772	.5373	.3429	.9335
3	.7164	.1638	.3429	.3772	.5373	.3429	1.0974
4	.7164	.16	.3429	.3772	.7164	.3429	1.0974
5	.8954	.2286	.6859	.3772	.7164	.5144	1.7528
6	.8954	.3763	.6859	.5601	.7164	.5144	1.8442
7	.8954	.724	.6859	.7164	.8954	.6859	1.6385
8	.8954	.7621	.6859	.8954	1.0745	.6859	1.3717
9	.5373		.6859	.5601		.6859	.6935
10			.1886		.6859	.6935	.3467
11	.1791		.1886		.3429		.1734
12	.1753		.1886	.1867	.3429	.1867	.1734
13	.1791		.1886	.1867		.1867	
14			.1886	.1867		.1867	
15	.1867		.3734	.1867	.3429		
16	.1867		.3734	.3658	.3429	.7316	
17			.3734	.3658	.5144	.9335	
18	.4668		.7164	.8954	.8573	1.4632	
19	.4668	.8573		1.2269	1.2003		
20	1.6975	1.0288	1.0974	1.0745	1.2003	1.1317	
21	1.1317	1.0288	1.2803	1.0745	1.0288	1.1203	
22	.9431	.8573	1.0974	.8954	1.0288		
23	.9431	.8573	.8954	.8954	.8573	.9145	.8573
24	.5487	.1829	.3429	.3772	.5487	.3429	.9431
Max	1.6975	1.0288	1.2803	1.2269	1.2003	1.4632	1.8442
Min	.1753	.16	.1886	.1867	.3429	.1867	.1734
Avg	.6709	.5413	.5345	.5698	.7154	.6175	.9897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134008 / ANWA 33 KV S/S

Feeder No / Name : 205 / HISODA BK

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.7716	.5144	.8954	.7316	.6859	.6859
2	.7164	.8573	.5144	.8954	.7316	.6859	.6935
3	.7164	.8669	.5144	.8954	.7316	.6859	.6859
4	.7164	.8573	.8573	.8954	.7316	.6859	.8192
5	.7164	1.5432	1.2003	1.3717	.7316	.8573	1.2136
6	1.0745	1.3717	1.2003	1.5604	.7316	1.2003	1.2346
7	1.0745	.9831	1.2003	1.5604	1.0745	1.2003	1.2193
8	1.0745	1.0174	.8573	1.5432	1.0745	1.0288	1.1869
9	.7164		.8573	1.4022		1.0288	1.0745
10			.5601		.6859	.3734	.8954
11	.5144		.5601		.6859		.7316
12	.6068		.5601	.5487	.5144	.2801	.5601
13	.5735		.5601	.5487		.6097	
14			.5601	.5487		.6097	
15	.4572		.5601	.5487	.5144		
16	.4915		.5601	.5487	.5144	.8192	
17			.7164	.7164	.5144	.8669	
18	.7468		1.0745	.7164	.8573	1.2803	
19	1.8671	1.0288	1.4327	.8954	1.0288		
20	1.8671	1.0288	1.5432	.7164	1.0288	1.3203	
21	1.2936	.8573	1.0402	.7164	.8573	1.1317	
22	1.307	.8573	1.0517	.7164	.8573		
23	1.307	.6859	1.0288	.7164	.8573	1.0974	1.0974
24	.7316	.823	.5144	.9145	.7316	.6859	.7011
Max	1.8671	1.5432	1.5432	1.5604	1.0745	1.3203	1.2346
Min	.4572	.6859	.5144	.5487	.5144	.2801	.5601
Avg	.9184	.9678	.8349	.9032	.7708	.8567	.9142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 201 / HASNABAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.3391	.4527	.4904	.3391	.4904
2	.2263	.2263	.3391	.4527	.4904	.3391	.4904
3	.2641	.2263	.5087	.5093	.4904	.5087	.5281
4	.2829	.2614	.6783	.6413	.6036	.6783	.5228
5	.3395	.3018	.8478	.8865	.7922	.8478	.5975
6	.4108	.439	.8817	1.0185	.9242	.9326	.9145
7	.5041	.5373	.8478	1.0829	.9808	.763	1.0608
8	.5228	.5658	.8478		.8488	.8478	.8962
9	.5041					.6783	.7655
10	.5658					.5658	.4024
11	.415		.4527		.3391	.5228	.5121
12	.3584		.415		.5935	.4481	.5487
13	.3772		.3772			.4481	.4938
14	.4527		.3772	.4572		.4108	.5853
15			.3772	.4656	.5935	.4108	
16	.4715			.439	.6274	.4108	.5853
17	.6036	.2035		.5121		.415	.6036
18	.679	.2543				.5658	.5281
19	.7922	.3391			.5935	.6036	.6979
20	.9054	.3391			.5935	.6036	.7733
21	.6413	.373	.7545		.5935	.5658	
22	.5847	.4239	.6036	.6036	.5596	.5658	
23	.5281	.4578	.5281	.5281	.5596	.5281	.5281
24	.2263	.2263	.4409	.4904	.5093	.4578	.4904
Max	.9054	.5658	.8817	1.0829	.9808	.9326	1.0608
Min	.2263	.2035	.3391	.439	.3391	.3391	.4024
Avg	.4731	.3376	.5657	.6100	.6213	.5607	.6198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 202 / LATIFPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3395	.3391	.4527	.6413	.3391	.4527
2	.2829	.3395	.3391	.4527	.6413	.3391	.4527
3	.2829	.3584	.6783	.4904	.6413	.5087	.4527
4	.3961	.3658	.763	.6413	.7167	.6783	.5228
5	.6413	.5121	.8478	.9054	.8299	.8478	.6348
6	.9896	.8954	1.0174	1.0751	1.0751	1.0174	.8596
7	1.2883	1.0288	1.0174	1.0829	1.0374	.9326	1.0608
8	1.4563	1.1218	1.0174			.9326	.8962
9	1.2696					.8478	.7282
10	.5788					.7545	1.1568
11	.4527		.811	1.0867	1.0174	.8962	1.3546
12	.3395		1.1694		1.5769	1.1763	1.4403
13	.3395		1.1317			1.3443	1.286
14	.4338		1.1317	1.2346		1.307	1.2689
15			1.094	1.2517	1.56	1.1949	
16	.4715			1.2003	1.56	1.1203	1.2517
17	.6036	.3391		1.3717		1.0185	1.3146
18	.8299	.3391				.4904	
19	.9054				.5765	.5658	.9054
20	1.0562	.3391			.5596	.5658	1.094
21	.8299	.4239	.679		.5935	.5281	.9054
22	.7545	.5087	.5658	.7922	.5935	.5093	
23	.7167	.3391	.5281	.7167	.5935	.4527	.7167
24	.2641	.3395	.4409	.4904	.679	.4239	.4527
Max	1.4563	1.1218	1.1694	1.3717	1.5769	1.3443	1.4403
Min	.2641	.3391	.3391	.4527	.5596	.3391	.4527
Avg	.6716	.5060	.7983	.8830	.8761	.7830	.9146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 203 / BORGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4904	.3391	.2641	.679	.6783	.4904
2	.4527	.4904	.3391	.2641	.6584	.8478	.5281
3	.4904	.4904	.4239	.3018	.695	1.0174	.5281
4	.5658	.5658	.5087	.4338	.7682	1.1869	.6348
5	.7733	.7167	.5087	.6224	.8413	1.2717	.7655
6	.9896	.9808	.5935	.7545	1.1043	1.3565	.8779
7	.9335	.8676	.4239	.8589	1.3321	1.1869	1.1888
8	.7468	.6224	.4239			1.1869	1.2437
9	.6535					1.0174	1.1763
10	.3584					.3772	.3018
11	.3921		.2641		.2035	.4481	.2075
12	.3658		.1886		.2035	.4481	.2075
13	.3841		.1886			.5228	.1886
14	.3292		.1886	.1698		.5601	.2075
15			.2263		.2543	.5601	
16	.3292			.132	.2543	.5975	.2641
17	.3658	.5087		.2263		.6979	.3206
18	.4527	.5087				.7167	.4527
19	.7922	.3391			.5935	.6413	.7733
20	.9054	.3391			.5935	.5658	.7922
21	.6413	.373	.7545		.5087	.5281	
22	.5658	.4239	.5847	.5658	.5087	.4715	
23	.5281	.4239	.4904	.4904	.5087	.4527	.679
24	.4527	.5093	.2713	.2641	.6036	.6274	.4527
Max	.9896	.9808	.7545	.8589	1.3321	1.3565	1.2437
Min	.3292	.3391	.1886	.132	.2035	.3772	.1886
Avg	.5618	.5406	.3952	.4114	.6065	.7485	.5848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 204 / NIMGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3206	.1696	.2263	.3018	.3391	.2641
2	.3018	.3206	.1696	.2263	.2987	.3391	.2641
3	.3395	.3206	.2713	.2452	.2987	.5087	.2641
4	.4338	.3772	.3391	.2829	.3361	.5087	.2801
5	.679	.5658	.4748	.4904	.4024	.6783	.3361
6	.7655	.7545	.4748	.6224	.5487	.763	.4938
7	.6722	.7167	.3391	.5975	.6036	.763	.695
8	.5228	.5658	.4239		.631	.763	.7133
9	.3547					.6783	.6722
10	.2641					.3772	.1886
11	.2614		.1132			.3734	.1698
12	.2427		.1132			.3361	.1132
13	.2561		.1132			.3361	.1132
14	.2012		.0943	.1132		.3361	.1132
15			.0943	.1132		.3734	
16	.2561			.1132	.0848	.4481	.6036
17	.2743	.3391		.1886		.4527	.2641
18	.3772	.3391				.4904	.3018
19	.5658	.3391			.5087	.3772	.4715
20	.679	.3391			.4239	.3772	.5281
21	.3961	.3391	.4904		.4239	.3772	
22	.3395	.3391	.4527	.3961	.3561	.3584	
23	.3395	.3391	.3772	.3961	.3391	.3395	.3395
24	.3018	.3206	.2543	.2263	.3395	.3052	.3018
Max	.7655	.7545	.4904	.6224	.631	.763	.7133
Min	.2012	.3206	.0943	.1132	.0848	.3052	.1132
Avg	.3968	.4148	.2803	.3027	.3931	.4583	.3567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 205 / KHADKI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5093	.2035	.2641	.5853	.5087	.4527
2	.4904	.5093	.2543	.2641	.6036	.6783	.5093
3	.5281	.5093	.3391	.3206	.6602	.8478	.5281
4	.5658	.5658	.3391	.4338	.7682	1.0174	.6348
5	.9054	.7922	.4239	.5847	.9114	1.1022	.9149
6	1.1203	1.1317	.4748	.6979	1.0802	1.153	1.2437
7	1.0082	1.0829	.6783	.8589	1.5249	1.2209	1.4632
8	.9335	.9619	.6783		1.5893	1.2209	1.5729
9	.6348					1.0174	1.419
10	.4294					.3772	.3772
11	.5121		.3772			.4481	.3018
12	.6219		.3395			.5228	.2829
13	.4755		.3395			.6348	.2452
14	.3658		.3018	.2452		.7282	.3018
15			.3018	.2075	.2713	.7842	
16	.4024			.2263	.2713	.8775	.3395
17	.5373	.6783		.3772		.7545	.4338
18	.5658	.6783				.6413	.547
19	.7922	.3391			.5935	.5658	.8299
20	.9431	.3391			.5935	.5658	.7922
21	.6224	.4239	.7167		.5426	.5658	.679
22	.5847	.4239	.6413	.5658	.5087	.5658	
23	.547	.4578	.5658	.5093	.5087	.5281	.5281
24	.4904	.5281	.2713	.2641	.4715	.6783	.4527
Max	1.1203	1.1317	.7167	.8589	1.5893	1.2209	1.5729
Min	.3658	.3391	.2035	.2075	.2713	.3772	.2452
Avg	.6333	.6207	.4262	.4157	.7178	.7502	.6750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134015 / HASNABAD

Feeder No / Name : 206 / RAJALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.3391	.3772	.4527	.3391	.415
2	.2263	.1886		.3772	.4527	.3391	.415
3	.2263	.1886	.3391	.4338	.4527	.5087	.415
4	.2829	.2263	.6783	.5093	.5281	.5935	.4854
5	.4338	.6219	.6783	.679	.6036	.6783	.6348
6	.6722		.7461	.8299	.7545	.6783	.695
7	.7095	.679	.5087	.7842	.6979	.5935	.7682
8	.5975	.5281	.5087			.5935	.6401
9	.4294					.5087	.4481
10	.1886					.5658	.2926
11	.1509		.3018			.5975	.3841
12	.1132		.2641			.5601	.2195
13	.1132		.2641			.5228	.3292
14	.1132		.2641	.2241		.4854	
15			.2452	.2427	.4239	.4854	
16	.1132			.2614	.4239	.4854	.3475
17	.1886	.3391		.3734		.5093	.439
18	.3018	.3391				.3395	.3584
19	.679	.3391			.5087	.3961	.5658
20	.6413	.3391			.5087	.4904	.6224
21	.547	.4239	.5658		.4239	.4904	
22	.5281	.4239	.4904	.4904	.407	.4904	
23	.5093	.4748	.4527	.4715		.4527	.4854
24	.1886	.1886	.39	.415	.4715	.373	.4527
Max	.7095	.679	.7461	.8299	.7545	.6783	.7682
Min	.1132	.1886	.2452	.2241	.407	.3391	.2195
Avg	.3540	.3659	.4398	.4621	.5078	.5032	.4707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 201 / DHAWDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3258	.3429		.6173	.583
2	.3772	.3772	.3429	.3772		.583	.6173
3	.4115		.3601			.6859	.6859
4	.4801		.3772	.5144		.7888	.7545
5	.5144		.3429	.583		.8402	.8916
6	.5658		.4973	.6173		.9088	1.0631
7			.4115	.6687		1.1145	1.0631
8				.6516		.8573	1.046
9				.463			.8916
10	.4287			.8402	.8059		.5144
11	.4458		.703	.6859	.7202	.3429	.4458
12	.4458		.5658	.6001	.6859	.3258	.3429
13	.5144		.5487	.5487	.703	.2229	.3086
14	.6173			.5487	.6516		.2743
15	.6859			.5658	.6173		.2572
16	.7202	.7888		.583	.6001	.2572	.2401
17	.8573	.8573	.5487	.7202	.583	.4973	.2743
18	.8745	.9945	.9602	.9602	.9259	.5487	.3086
19	.8573	.9088	.9259	.9259	1.0288	.6859	.3429
20	.7888	.8573	.823	.8573	.823	.7545	.4287
21	.7545	.7888	.703	.7202	.703	.6516	.6516
22		.6516	.5487	.6687			
23			.5144	.5487	.583	.5487	
24	.3086	.3258	.3772	.3086	.3086	.5487	.5487
Max	.8745	.9945	.9602	.9602	1.0288	1.1145	1.0631
Min	.3086	.3258	.3258	.3086	.3086	.2229	.2401
Avg	.5785	.6893	.5487	.6218	.6957	.62	.5697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 202 / WALSAWANGI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3717	1.2003	.7888		.583	.5487
2	1.2689		1.2346	.8573		.6173	.583
3	1.2346		1.2689	.9431		.6516	.6173
4	1.3717		1.3717	.9602		.6859	.6859
5	1.6118		1.5775	.9945		.7888	.823
6	2.0576		1.6461	1.0288		.8573	.9088
7			1.7833	1.0974		.823	.9088
8				.9431		.8573	.9259
9	.9259			.5144		1.3717	.8573
10	.5144			.4287	.5658	.8573	.823
11	.4801		.4458	.5487	.7202	1.0631	.8916
12	.4801		.4801	.4801	.7545	.8059	.703
13	.4801		.4973	.4801	.6173	.703	.7202
14	.4801		.5144	.5144	.703		.7202
15			.5144	.5658	.6344		.7202
16		.4287	.6516	.6001	.6687	1.0974	.7373
17	1.3717			.6516	.583	1.5775	.7716
18	1.5089	.1372	1.3375	1.3717	1.2003	1.4403	.8573
19	1.3717		.9431	1.286	1.5432	1.2003	.8916
20	1.3375	1.5432	.7716	.9431	1.4403	1.1488	1.0288
21	1.2689	1.5089	.6859	.7716	1.3717	1.1145	1.1831
22		1.3717	.6859	.703	1.2003		
23			.6173	.6859	1.1145	1.0288	
24	1.286	1.3889	1.3203	.6687	.7373	.5144	.5144
Max	2.0576	1.5432	1.7833	1.3717	1.5432	1.5775	1.1831
Min	.4801	.1372	.4458	.4287	.5658	.5144	.5144
Avg	1.1307	1.1072	.9774	.7845	.9236	.9422	.7919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 203 / BHORKHEDA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.12	.0857	.1029		.1543	.0857
2	.2058	.1029	.1372	.1372		.1372	.0857
3	.2401		.1543			.1029	.0857
4	.2743		.1715			.12	.1029
5	.3086		.2058	.2058		.1543	.12
6	.3772		.3429	.1715			.12
7			.3429	.1543		.1543	.1372
8				.1029		.1543	.2058
9	.0686						.1715
10	.0857			.0686	.0857		.1372
11	.1029		.0857	.0343	.12	.1029	.1029
12	.12			.1029	.12	.0857	.0343
13	.12			.12	.12	.0857	.0514
14	.12			.1029			.0514
15	.12						.0514
16	.1372	.2058				.1029	.0514
17	.1715		.0514			.0857	.0686
18	.1886	.2058			.1543	.1372	.1029
19	.1715	.2401	.1543	.0686	.3086	.1543	.12
20	.1543	.1543	.6001	.1029	.2401	.1715	.1372
21	.1543	.1372	.1029	.1372	.2058	.1543	.1543
22		.1372	.1029	.1543	.1715		
23			.12	.1543	.1543	.1029	
24	.1543	.1372	.1543	.1543	.1543	.0857	.0857
Max	.3772	.2401	.6001	.2058	.3086	.1715	.2058
Min	.0686	.1029	.0514	.0343	.0857	.0857	.0343
Avg	.1723	.1601	.1875	.1221	.1668	.1248	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134018 / DHAWDA

Feeder No / Name : 204 / JAIDEVWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.1715	.2058		.4458	.4287
2	.2401		.2058	.2401		.3772	.4458
3	.2743		.2401	.2743			.4801
4	.3086		.2058	.3086			.5144
5	.3429		.1715	.2743			.583
6	.3601		.1886	.3086			.6173
7			.1715	.2743			.6001
8				.3086		.3772	.6001
9	.2572			.3086	.3944		.5144
10	.2743			.2743	.2743	.3601	
11	.2743		.3601	.2401	.2401	.2572	.3429
12	.2743			.2572	.2401	.2401	.2058
13	.2915			.2743	.2572	.2058	.1886
14	.3086		.2572	.2572	.3086		.1715
15	.3086		.2572	.2572	.2743		.1715
16	.3086	.3601	.2915	.2915	.3258	.1886	.1715
17	.3429		.2915	.3258	.3429	.1886	.2058
18	.4801			.6859	.4458	.3086	.2572
19	.4801		.6859	.6001	.6516	.3772	.3429
20	.4458	.5487		.5144	.6001	.5144	.3772
21	.4801	.5144	.5144	.463	.5144	.463	.463
22		.4115	.4115	.463	.4801		
23			.3086	.2058	.4115	.4115	
24	.1543	.1715	.1886	.1715	.1715	.4115	.4115
Max	.4801	.5487	.6859	.6859	.6516	.5144	.6173
Min	.1543	.1715	.1715	.1715	.1715	.1886	.1715
Avg	.3189	.3658	.2895	.3244	.3708	.3418	.3854

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 201 / Relgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.3353		.442	.442	.6097	.3048
2	.6097	.3658		.4572	.4725	.5944	.3353
3	.7621	.3963		.4877	.5335	.4572	.381
4	.8383	.4268		.503	.5792	.4877	.4268
5	.9145	.4572		.5335	.6401	.5335	.4725
6	.9907	.4877		.5944	.7164	.5487	.4877
7	.7621		.5182	.5944	.7468	.6706	.5182
8	.6097			.6097	.8078	.6401	.5335
9	.4725			.6401	.503	.6554	.5944
10	.381				.2286		
11					.2286		
12	.1524						
13	.1829				.1981		
14	.2134				.2439		
15	.2439			.1981	.2134		
16	.2743			.2439	.2286		
17	.3048			.3048	.2591	.4572	
18	.3658		.3048	.3658	.7621	.5792	
19	.3658		.4572		.8383	.6249	
20	.3506		.6859		.8383	.5792	
21	.3506	.503	.6097		.4572	.5335	
22	.3353	.442	.5335		.381	.5182	
23	.3201	.442	.503		.3048	.4877	
24	.503	.3201		.2896			.2439
Max	.9907	.503	.6859	.6401	.8383	.6706	.5944
Min	.1524	.3201	.3048	.1981	.1981	.4572	.2439
Avg	.4679	.4176	.5160	.4474	.4829	.5611	.4298

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 202 / Pimpalgaon R

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.2591		.381	.3658	.381	.3658
2	.7621	.2743		.4268	.4877	.4115	.381
3	.9145	.2896			.5487	.4268	.4268
4	1.0669	.3048		.4877	.5792	.4572	.4572
5	1.2193	.3048		.5335	.6401	.4572	.4877
6	1.2955	.3353		.5335		.4725	.5182
7	1.2193			.503		.4115	.3353
8	1.0669			.4572		.4268	.3048
9	.9145			.3963		.442	.2743
10	.4572				.3963		
11	.3048						
12	.1524		.4572	.4572	.381		
13	.1524		.4725	.442	.3658		
14			.442	.442	.4268	.5487	
15	.1829		.4115	.2743	.381		
16			.3963	.2286	.4115	.5182	
17	.381		.381	.1524	.7316		
18	.5944		.3658	.3048	.7621		
19	.6097		.4572		.7773		
20	.6859		1.0822		.7621		
21	.7621	.4877	.9145		.7468	.6097	
22	.6859	.4572	.7621		.6859	.6859	
23	.5792	.4268	.6097		.6097	.5182	
24	.5944	.1981		.503			.1829
Max	1.2955	.4877	1.0822	.5335	.7773	.6859	.5182
Min	.1524	.1981	.3658	.1524	.3658	.381	.1829
Avg	.6914	.3338	.5627	.4077	.5589	.4834	.3734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 203 / LEHA/SHELUD FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.8993	.5335		.9145	.7621
2	.8383	.6859	.9145	.6859		.9755	.8383
3	.9145	.8383	.9907	.8383		.9907	.9907
4	.9907	.9907	1.0669	.9907	.8535	1.0364	1.0669
5	1.0669	1.0974	1.1431	1.1431		1.0669	1.2193
6	1.1431	1.1888	1.1888	1.2193		1.1279	1.2193
7	1.0669		1.2193	1.1431	.8993	.9145	1.2498
8	.9907			1.0669		.9907	1.2193
9	.9297		.4572	.9602	1.0059		1.1279
10	.7621		.4877		.3353		
11					.3658		
12	.3658				.2439		
13	.3506				.2591		
14	.3353				.2286		
15	.3506			.4572			
16				.5335			
17	.3353			.5792			
18	.6401		.6097	.5944			
19	.6859		.6401			.5639	
20	.7621		.6859		.6859	.5944	
21	.8993	.5792	.6401		.6706	.6097	
22	.7621	.6097	.6097		.6401	.5792	
23	.7164	.6401	.503		.6554	.5182	
24	.7621	.7011		.6706			.6706
Max	1.1431	1.1888	1.2193	1.2193	1.0059	1.1279	1.2498
Min	.3353	.5792	.4572	.4572	.2286	.5182	.6706
Avg	.7399	.7941	.8037	.8154	.5703	.8371	1.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 204 / PARADH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6097	1.0822	.6859	.7316	.9145	.6097
2	.5792	.7621	1.0974	.7621	.7926	.9907	.6401
3	.6097	.9145	1.1126	.8383	.823	1.0669	.6859
4	.6401	1.0669	1.1279	.9907	.884	1.1431	.8383
5	.6859	1.2193	1.1431	1.0669			.9907
6	.7164	1.2651	1.2041	1.2651	1.1279	1.2803	1.0974
7	.7316			.9907	1.2041	.5944	1.0669
8	.7621		.9907	.7621	.6554	.6097	.9145
9	.8383		.6097	.5182	.6249	.6249	.5182
10	.7621		.5335		.442		
11	.6859				.4572		
12	.4877				.4268		
13	.4725				.442		
14	.442				.4572		
15	.4268			.4877	.4877		
16	.4115				.7316		
17	.381			.5792	.9145	.6097	
18	.6859		.5944	.6097	.945	.6859	
19	.7011		.6859		.9755	.7468	
20	.7316		.9297		.6249	.7316	
21	.7926	.6859	.8383		.5792	.7164	
22	.7621	.6706	.7621		.5944	.6859	
23	.6859	.6554	.6706		.6097	.6554	
24	.4877	.6859		.6554			.6554
Max	.8383	1.2651	1.2041	1.2651	1.2041	1.2803	1.0974
Min	.381	.6097	.5335	.4877	.4268	.5944	.5182
Avg	.6256	.8535	.8921	.7855	.7060	.8037	.8017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV

Feeder No / Name : 205 / Awghadrao sawangi
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4572	.6706	.4572	.5335	.7926	.4572
2	.3353	.6097	.381	.6859		.823	.5335
3	.3658	.6859	.7164	.7621	.6859	.8535	.6401
4	.381	.7621	.7316	.8383	.7621	.9145	.7926
5	.381	.9907	.7621	.9145	.8688	.9145	.8383
6	.3963	1.0364	.8383	1.0059		.9755	.945
7	.3658		.9145	.9145	.9145	.6097	.7621
8	.3353		.7621	.7621	.9297	.6249	.6097
9	.2896		.6097	.6097		.6401	.6097
10	.2896		.2134				
11	.3048		.2896		.2591		
12	.3201		.3201	.1677	.2134		
13			.2743	.1372	.1981		
15	.3201			.1524			
16				.1829			
17				.1981			
18	.6097			.2896			
19	.6097		.6097		.7316		
20	.6249		.823		.7621	.6859	
21	.6401		.7621			.6097	
22	.5335	.3658	.6097		.7316	.5335	
23	.4572	.3963	.4572		.7468	.442	
24	.1372	.4572		.4572			.4268
Max	.6401	1.0364	.9145	1.0059	.9297	.9755	.945
Min	.1372	.3658	.2134	.1372	.1981	.442	.4268
Avg	.4001	.6401	.5970	.5335	.6413	.7246	.6615

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 201 / KEDARKHEDA ag1

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1505		.1219		.2658
2		.1505		.1219		.2658
3		.1806		.1219		.4458
4		.1852		.1235		.4458
5		.1543		.1543		.4744
6		.1543		.2343		.5218
7		.1562	.2286	.3437	.3086	.5601
8		.1562			.3086	.5601
9		.1235			.3241	.5601
10	.1905					
11	.1467					
12	.1486					
13	.132					
15	.1486					
16	.1486					
17	.0533					
24					.2303	
Max	.1905	.1852	.2286	.3437	.3241	.5601
Min	.0533	.1235	.2286	.1219	.2303	.2658
Avg	.1383	.1568	.2286	.1745	.2929	.4555

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 202 / DEOLGAON TAD AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2378	.1905		.2096	.2858	.3048
2		.2526	.2286		.2667	.2858	.3048
3		.2591	.2286		.2858	.2858	.3048
4		.2968					
5		.3077					
6		.4359					
7		.4359		.2286			
8	.3429	.4917					
10						.4096	.5028
11				.6249	.7291	.4096	
12				.4784	1.004	.4588	
13				.0526	.9717	.4588	.6478
14				.1303	.8907	.4915	.8905
15					.6636	.4915	.933
16	.1334			.4382	.3549	.5182	.8855
17	.2096			.4902	.3544	.5182	.9014
18	.2667			.1524	.381	.381	.2667
19	.362			.2096	.381	.3239	
20	.4191			.3429	.3429	.3239	.4001
21	.3239			.2858	.3429	.3239	.2667
22	.2667			.2286	.3048	.3048	.3048
23	.2667			.2286	.2858	.2858	.3048
24		.2378			.2858	.2858	
Max	.4191	.4917	.2286	.6249	1.004	.5182	.933
Min	.1334	.2378	.1905	.0526	.2096	.2858	.2667
Avg	.2879	.3284	.2159	.2993	.4738	.3802	.5156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 203 / KEDARKHEDA AG 2

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381		.0152	.0381	.0381
2		.0381		.0305		.0381
3		.0381		.0309		.0381
4		.0572		.0309	.0572	.0572
5		.0572		.0469	.0572	.0572
6		.0572		.081	.0953	.0953
7		.0572	.0381	.081	.1143	.1143
8		.0572			.1143	.1524
9		.0381			.1143	.1524
10	.0381					
11	.0469					
12	.0312					
13	.0463					
14	.0463					
15	.0463					
16	.0469					
17	.0305					
24					.0381	
Max	.0469	.0572	.0381	.081	.1143	.1524
Min	.0305	.0381	.0381	.0152	.0381	.0381
Avg	.0416	.0487	.0381	.0452	.0786	.0826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 204 / DEOLGAON TAD G

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.4191		.1715	.1905	.1905
2		.1524	.4763		.2286	.2477	.3048
3		.1715	.5335		.2667	.2858	.381
4		.2667	.5716		.3429	.2858	.381
5		.4191	.5716		.4191	.4763	.4191
6		.5716	.6287		.6287	.5716	.4191
7		.6287	.5716	.1905	.5525	.4763	.4572
8	.381	.5525	.5335			.4763	.4572
9			.4001			.4763	.4572
10	.381					.381	.2286
11	.0953			.0953	.0953	.2858	
12	.0953			.0953	.0953	.2858	
13	.0953			.0762		.2667	.0953
14	.0953			.0572		.2667	.0762
15	.1143				.1334	.2858	
16	.1143			.0762	.1334	.2858	
17	.1524			.1524	.2477	.381	.2858
18	.2286			.2096	.362	.381	.3429
19	.3429			.381	.4382	.2858	
20	.4001			.5335	.381	.2858	.362
21	.2477			.2667	.1905	.2858	.2286
22	.1715			.2096	.2286	.1905	.1905
23	.1524			.1905	.1905	.1905	.1715
24		.1524			.1905	.1524	
Max	.4001	.6287	.6287	.5335	.6287	.5716	.4572
Min	.0953	.1524	.4001	.0572	.0953	.1524	.0762
Avg	.2045	.3408	.5229	.1949	.2788	.3207	.3027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 205 / KEDARKHEDA G

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4572	.6287		.4954	.4763	.4191
2		.4572	.7842		.4954	.6097	.5525
3		.5335	.8402		.5335	.6668	.6859
4		.6287	1.0829		.6478	.7095	.811
5		1.0288	1.1576		.9145	.7468	.9808
6		1.3146	1.307		1.3908	.8029	1.0608
7		1.086	1.1203	.8573	1.2765	.7468	1.1888
8	.7621	.9717	.9997			.8962	1.1203
9			1.0269			1.0082	1.0082
10	.5716					.7545	.5716
11	.3239			.3429	.4763	.6287	
12	.3048			.3048	.2858	.4382	
13	.3048			.2858	.2858	.4763	.3048
14	.3048			.2858	.2858	.5716	.3429
15	.3429				.2477	.5716	.3239
16	.362			.3239	.2477	.6668	.362
17	.4954			.4191	.5335	.6668	.4572
18	.743			.5906	.7922	.5716	.5906
19	.8764			.8002	.9896	.5716	
20	1.086			1.086	.8488	.6668	.9717
21	.724			.7621	.6224	.5716	.743
22	.5716			.5716	.4763	.4191	.5716
23	.5335			.5144	.4763	.2858	.5144
24		.4572			.381	.2858	
Max	1.086	1.3146	1.307	1.086	1.3908	1.0082	1.1888
Min	.3048	.4572	.6287	.2858	.2477	.2858	.3048
Avg	.5538	.7705	.9942	.5496	.6049	.6171	.6791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 201 / Surangli AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.3944	.3601	.2401	.3429
2	.2572	.2058		.3772	.3601	.2915	.3601
3	.3429	.2401	.2743	.4287	.3601	.3086	.3601
4			.3086	.3944	.3772	.3601	.3429
5			.3429	.4115	.5144	.3772	.3772
6			.4115	.4458	.5144	.3772	.4458
7			.4458	.4973	.6516	.4287	.5487
8			.5144	.5144		.5144	.583
9			.3772	.4115		.4287	.4458
10	.2572						
11	.3086						
12	.2572						
13	.3258						
14	.2572						
15	.1886	.2401					
16	.1886	.1715			.1029	.1715	
17	.2263	.2915	.1372	.1886	.1372	.2743	
18	.2401	.4287	.2401	.2572			.2058
19	.3772	.3772	.3772	.3429		.3772	.3258
20	.3429	.3429	.4115			.2572	.3429
21	.3086	.2743	.2572	.2572	.2229	.2229	.2572
22	.2743	.2452	.2401	.2229	.2058	.2058	.2401
23	.2401	.2401	.2572	.2058	.2058	.2058	.2915
24	.5658	.2743	.2401	.2743	.1886	.2058	.2572
Max	.5658	.4287	.5144	.5144	.6516	.5144	.583
Min	.1886	.1715	.1372	.1886	.1029	.1715	.2058
Avg	.2888	.2748	.3172	.3515	.3232	.3086	.3579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 202 / KATHORA BAZAR GFSS

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.3772	.3772	.3772	.3206	.3584
2	.3772	.3961	.3961	.415	.3961	.3772	.3395
3	.3772	.3772	.415	.3961	.3772	.3772	.3584
4	.4715	.3772	.4527	.415	.415	.3961	.5281
5	.7167	.5658	.5658	.4715	.5281	.3772	.6036
6	.6602	.7922	.7733	.4904	.5658	.4527	.5658
7	.5281	.7922	.7545	.3018	.5281	.4904	.3772
8			.5658	.2452	.5281	.4715	.3206
9	.4715		.2829	.2263	.5281	.4338	.3395
10	.3395		.2452		.2829	.2829	
11	.2452					.2641	
12	.2263				.2263	.2263	.2263
13	.2075				.1886	.2452	.2452
14	.2263		.1132		.1715	.1698	.2263
15	.2452	.1886	.1132	.132	.1886	.3018	.2452
16	.3772	.1886	.1886	.3018	.2641	.3772	.2641
17	.5281	.5658	.2263	.2829		.4904	
18	.6602	.7545	.4904	.6036			
19	.7545	.7167	.5847	.7545		.4527	.4904
20	.5658	.5281	.5847			.5281	.5658
21	.4904	.4715	.5281	.3772	.4338	.2829	.4715
22	.4338	.4715	.4715	.415	.3395	.3018	.4338
23	.415	.4527	.3961	.415	.3086	.3018	.4338
24	.4338	.3772	.3772	.3961	.3772	.3584	.3584
Max	.7545	.7922	.7733	.7545	.5658	.5281	.6036
Min	.2075	.1886	.1132	.132	.1715	.1698	.2263
Avg	.4420	.4937	.4239	.3898	.3697	.3600	.3876

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 203 / Dagadwadi Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1029	.0514	.0686	.0686	.0514	.0857
2	.1029	.1029	.0514	.0686	.0686	.0686	.0857
3	.0857	.1029	.0514	.0686	.0686	.0686	.0686
4	.12	.12					
5	.1372	.1715					
6	.1543	.2743					
7	.1715						
9	.1543						
10			.1715		.1029	.1029	
11					.1029	.1372	
12				.2572	.12	.1029	.2229
13					.2915	.12	.2401
14			.1372		.2401	.1715	.1715
15			.12		.1715	.1886	.2401
16	.0343	.0514	.1715	.1886	.1715	.1715	.1715
17	.0686	.0686		.1886	.1886	.2058	.2401
18	.0857	.0686	.0514	.0686			.0686
19	.0686		.1029	.0857		.1029	.0857
20	.0857		.0857			.12	.0686
21	.0857		.0857	.0686	.0857	.0857	.0686
22	.0686		.0857	.0686	.0514	.0686	.0514
23	.0686	.0686	.0686	.0686	.0686	.0686	.0514
24	.0857	.0686	.0514	.0686	.0686	.0514	.0686
Max	.1715	.2743	.1715	.2572	.2915	.2058	.2401
Min	.0343	.0514	.0514	.0686	.0514	.0514	.0514
Avg	.0978	.1091	.0918	.1057	.1246	.1110	.1243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 204 / Express Water Supply Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343					
2		.0343				.0343	
3		.0343				.0343	
4		.0343				.0343	
5	.0343					.0343	
6	.0343			.0343		.0343	
7	.0514			.0343		.0343	
8	.0514		.0343	.0514		.0343	.0343
9	.0343		.0343	.0343		.0343	
10	.0343		.0514		.0343	.0343	
11	.0343				.0514	.0514	
12	.0343			.0514	.0514	.0514	
13	.0343				.0343		
14	.0343		.0514		.0343		
15		.0343	.0343	.0343		.0343	
16	.0343	.0343	.0514	.0343		.0514	
17	.0343	.0343	.0343	.0343		.0343	
18	.0343	.0343	.0514	.0343			
19	.0343	.0343	.0514	.0343		.0514	
20	.0343	.0343	.0514			.0343	
21	.0343	.0343		.0343		.0343	
22	.0343	.0343					
23		.0343		.0343			
24		.0343			.0343		
Max	.0514	.0343	.0514	.0514	.0514	.0514	.0343
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0363	.0343	.0446	.0372	.04	.0383	.0343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 205 / Danapur GFSS

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.415	.415	.3772	.415	.3772	.3395
2	.3395	.3961	.3961	.3961	.4527	.3772	.3584
3	.3018	.3772	.3772	.415	.4715	.3961	.3395
4	.3772	.3772	.5281	.6602	.5847	.3961	.6036
5	.5847		.6036	.9431	.6602	.4715	.6979
6	.7922	.7922	.811	1.0374	.679	.7545	.679
7	.679	.7545	.7545	.8676	.7167	.7922	.6979
8	.3772		.7167	.811	.6602	.6413	.6036
9	.3584		.4338			.5093	.4527
10	.2263		.2829		.3395	.3772	
11					.2263	.3395	
12				.2641	.1886	.3018	.1886
13					.1886	.2263	.2075
14	.1886				.1886	.2641	.2263
15	.2263	.2263	.2641	.2075	.1886	.2641	.2452
16	.2075	.2452	.2829	.2263	.2263	.3395	.2641
17	.3206	.4904		.2641	.3395	.3772	.415
18	.8299	.5847	.5093	.6602			.5658
19	.8488	.7545	.5847	.7733		.4715	.5658
20	.8488	.6602	8.4122			.4904	.6602
21	.5658	.4715	.5847	.547	.4904	.415	.4715
22	.4904	.4527	.5281	.4715	.415	.3772	.415
23	.4527	.4338	.4904	.4527		.3772	.3961
24	.3018	.415	.415	.3961	.3961		.3584
Max	.8488	.7922	8.4122	1.0374	.7167	.7922	.6979
Min	.1886	.2263	.2641	.2075	.1886	.2263	.1886
Avg	.4590	.4904	.9153	.5428	.4120	.4244	.4433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 206 / GODRI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.12					
2		.12					
3		.1372					
4		.1372					
5		.12					
6		.1715					
7		.1372					
9	.1715						
10			.1372		.1715	.12	
11					.1715	.1372	
12				.2743	.1715	.12	.2058
13					.2743	.2572	.2058
14			.12		.2401	.1543	.2229
15			.1372	.1715	.1543	.1372	.2229
16			.1372	.1715	.1372	.12	.2572
17			.1372	.1715	.1372	.12	.2572
24		.1029					
Max	.1715	.1715	.1372	.2743	.2743	.2572	.2572
Min	.1715	.1029	.12	.1715	.1372	.12	.2058
Avg	.1715	.1308	.1338	.1972	.1822	.1457	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 207 / KARKHANA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514					
2		.0686					
3		.0514					
4		.0857					
5		.12					
6		.12					
7		.12					
9	.1715						
10			.1543		.12	.0686	
11					.1029	.0857	
12				.1543	.1029	.0857	.12
13					.1543	.0857	.12
14			.1029		.1372	.0686	.1543
15			.1543	.12			.12
16			.12	.1543		.0857	.1715
17			.1372	.12		.0857	.1715
24		.0514					
Max	.1715	.12	.1543	.1543	.1543	.0857	.1715
Min	.1715	.0514	.1029	.12	.1029	.0686	.12
Avg	.1715	.0836	.1337	.1372	.1235	.0808	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 208 / KATHORA BAZAR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3601	.3429	.3772	.3601	.3429
2			.3772	.3429	.4287	.3601	.3944
3			.3086	.3429	.4287	.3429	.4115
4			.3429	.3601	.5144	.3601	.4287
5			.3429	.3601	.6001	.4115	.4287
6			.3429	.3772	.6859	.4287	.4287
7			.3429	.4287	.7202	.5487	.463
8			.3772	.5487	.6859	.5144	.6001
9			.3772	.5316	.7202	.5316	.5144
10	.3601						
11	.4801						
12	.4287						
14	.3772						
15	.3944	.5144					
16	.3772						
17	.3944						
21	.0343						
23							.3429
24			.3429	.3429	.3429	.3429	.3601
Max	.4801	.5144	.3772	.5487	.7202	.5487	.6001
Min	.0343	.5144	.3086	.3429	.3429	.3429	.3429
Avg	.3558	.5144	.3515	.3978	.5504	.4201	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 201 / NALNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.2458	.4096	.3768	.3605	.4915	.4096
2	.3277	.2458	.426	.3605	.3605	.5735	.4096
3	.3768	.2622	.4424	.3932	.3932	.6554	.426
4	.4096	.2622	.4752	.4424	.4111	.7045	.4588
5	.4915	.2622	.5735	.5735	.4588	.7373	.5735
6	.4915	.2785	.6226	.6554	.5735	.8192	.6554
7	.6226	.3277	.6554	.7373	.4915	.8192	.7701
8	.5735	.4096	.6554	.7373	.4588	.8192	.6554
9	.5407		.4424	.6226		.6554	.5735
10	.3277		.4915			.4096	
11	.1638		.4915		.8192	.5571	
12	.1638				.9831	.7373	
13	.1638				.9831	.8029	1.1633
14	.1638					.7373	1.1797
15	.1638				.8192	.7209	1.0978
16	.1638	.213		.4588	.8192	.6554	.9831
17	.2458	.2949		.5243	.852	.6226	1.065
18	.3277	.4096	.4096	.2458		.7045	
19	.4744	.4752	.6554	.4915	.4915	.6226	
20	.4915	.426	.5898	.5735	.7373	.4915	
21	.4096	.4424	.4915	.4915	.4915	.4588	
22	.3277	.4096	.4424	.4096		.426	
23	.2949	.3768	.426	.3277	.4096	.4096	.426
24	.4096	.2949	.3768	.3932	.3277	.3277	.3932
Max	.6226	.4752	.6554	.7373	.9831	.8192	1.1797
Min	.1638	.213	.3768	.2458	.3277	.3277	.3932
Avg	.3522	.3316	.5043	.4897	.5916	.6233	.7025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 202 / PIMPALGAON BARAV

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.3277	.2785	.3113	.2622	.4096	.3441
2	.4096	.4096	.2622	.3768	.2949	.4096	.3605
3	.4096	.4096	.2458	.3768	.3277	.4915	.3932
4	.4915	.4915	.2294	.4096	.4096	.4915	.4096
5	.4915	.4915	.3605	.4424	.5735	.5735	.5735
6	.5735	.6554	.4424	.5079	.6554	.6554	.7373
7	.7865	.6554	.5243	.6226	.6882	.9831	.8848
8	.7373	.4915	.5571	.6554	.9012	.9012	.9012
9	.3277		.4424	.6062		.7373	.852
10	.3277		.3277			.2458	
11	.3605		.1802		.1638	.3277	
12	.3277				.1638		
13	.3277				.1638		.1802
14	.2949						.1966
15	.3277				.2458		.213
16	.3277	.3441		.2294	.2458	.3277	.2458
17	.3277	.4096		.2622	.2785	.5735	.3441
18	.3277	.5735	.3277	.2949		.7045	
19	.4915	.5571	.6554	.5079	.4096	.6554	
20	.5735	.5735	.6882	.6882	.5735	.6062	
21	.4096	.5243	.5407	.6554	.4915	.5735	
22	.2949	.4752	.4424	.5735		.5735	
23	.2949	.426	.4096	.4915	.3277	.4915	.5407
24	.4915	.2949	.2294	.3277	.3277	.3277	.3277
Max	.7865	.6554	.6882	.6882	.9012	.9831	.9012
Min	.2949	.2949	.1802	.2294	.1638	.2458	.1802
Avg	.4226	.4771	.3969	.4633	.3950	.5530	.4690

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134060 / NALNI

Feeder No / Name : 203 / KHAPERKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2458	.3277	.2458	.2622	.2458	.3277	.4915
2	.2458	.3277	.2294	.2785	.2458	.4096	.5079
3	.2458	.3605	.1802	.3113	.2458	.4096	.5407
4	.2949	.4096	.1638	.3768	.2949	.4915	.5735
5	.2949	.4096	.2949	.426	.3605	.4915	.6062
6	.3277	.4915	.4096	.4915	.3932	.5735	.7701
7	.4588	.4915	.4424	.5735	.3605	.9012	.9175
8	.3277	.4096	.5079	.6882		.9831	1.065
9	.2458		.4096	.4915		.9831	1.0159
10	.2785				.1966	.1638	
11	.2949		.1147		.1638	.213	
12	.2949		.0819		.1966	.2458	
13	.2949				.2294	.3277	.2294
14	.3277					.3441	.2622
15	.3277				.1966	.3605	.2949
16	.3277	.4424		.1311	.1966	.3605	.2949
17	.4096	.4424		.1638	.2458	.3768	.3277
18	.3277	.2458	.1966	.1966		.4915	
19	.4096	.2622	.3277	.3605	.4096	.4424	
20	.4096	.2785	.3932	.4096	.4915	.4096	
21	.2949	.2949	.2622	.4096	.4096	.3277	
22	.2622	.2785	.2622	.3277		.3277	
23	.2458	.2458	.2458	.2458	.3277	.2785	.3113
24	.2458	.2949	.1638	.2458	.2458	.3277	.3277
Max	.4588	.4915	.5079	.6882	.4915	.9831	1.065
Min	.2458	.2458	.0819	.1311	.1638	.1638	.2294
Avg	.3099	.3537	.2740	.355	.2872	.4403	.5335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 201 / Pimpalgaon Ko

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.3018	.6468	.5973	.5721	.5853	.5721
2	.3856	.3521	.5304	.6154	.5895	.6036	.5895
3	.4024	.3978	.4805	.6516	.6415	.6401	.6241
4	.4191	.4807	.5544	.7316	.7108	.7316	.6762
5	.4694	.547	.7499	.8048	.8322	.9055	.7628
6	.6874	.7127	1.0608	.9955	.9709	1.0974	.8322
7	.9054	1.065	1.0349	.9774	.8669	.9979	.8669
8		1.2452	.7865	.823		.9511	.7108
9	1.0059		.6767	.6154		.7865	
10	.1492						
11	.2149		1.0322	1.2071			
12	.197			1.1904			
13	.181			1.3413		.9389	1.1603
14				1.4083		1.2239	
15	.1991			1.576	1.3927	1.0898	
16	.2172			1.5592	1.5402	.9389	
17	.2896	.3109		1.6263		.9054	
18	.4298	.5304	.2353	.2427		.3688	
19	.7059	.8131	.4572	.5028	.8413	.4854	.724
20	.7522	.7762	.8507	.8322	.823	.5721	.7783
21	.591	.6099	.6584	.6068		.6068	.6584
22	.6024	.6283	.6401	.6068	.6653	.5895	.6516
23	.6036	.6653	.5973	.5895	.6401	.5548	.6516
24	.3688	.2865	.6219	.5853	.5548	.6219	.5721
Max	1.0059	1.2452	1.0608	1.6263	1.5402	1.2239	1.1603
Min	.1492	.2865	.2353	.2427	.5548	.3688	.5721
Avg	.4619	.6077	.6832	.8994	.8315	.7712	.7221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO

Feeder No / Name : 203 / Vazirkheda

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.394	.1677	.2012	.218	.2622	.218
2	.4508	.4119	.2012	.218	.2515	.2949	.2515
3	.5201	.4706	.2321	.2543	.285	.3315	.2683
4	.6068	.5792	.2818	.2883	.3521	.426	.3018
5	.7108	.724	.3277	.4024	.4862	.5243	.3856
6	.7802	1.0387	.4096	.5365	.7042	.779	.6036
7	.8842	.591	.4915	.6874	.9724	.9393	.8383
8	.8322	.9036	.4862	.5967		.8259	.9556
9	.7108		.5304	.663		.6133	
10	.1677						
11	.3315		.2743				
12	.3978			.2254			.181
13	.4359					.4334	.2012
14						.5028	
15	.2652					.5201	
16	.2012					.5721	
17	.2155	.3511		.2254		.4681	
18	.4887	.3658	.2743	.3467		.5201	.2561
19	.6805	.5853	.4207	.4854	.7602	.4681	.7316
20	.788	.6584	.7499	.8669	.8413	.5721	.9328
21	.5373	.5853	.6036	.5548		.4681	.5487
22	.4784	.439	.439	.4681	.4572	.3988	.4706
23	.4163	.4024	.4024	.3814	.4024	.3641	.3801
24	.3988	.4163	.1823	.1865	.2012	.2785	.2012
Max	.8842	1.0387	.7499	.8669	.9724	.9393	.9556
Min	.1677	.3511	.1677	.1865	.2012	.2622	.181
Avg	.5093	.5573	.3809	.4216	.4943	.5030	.4545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 201 / AVANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.6661	.7922	1.1273	1.0974	.9431	.7545
2	.2829	.691	.8488	1.0791	1.0608	.9431	.8488
3	.3772	.7164	.9431	1.1946	1.2254	.9431	.9619
4	.5658	.985	1.1883	1.3937	1.3717	1.1317	1.094
5	.6602	1.1641	1.358	1.4299	1.4266	1.3203	1.1883
6	.679	1.2894		1.4299	1.4266		1.3957
7	.7167	1.2715					
8	.6979	1.2715					
9	.4904		1.094				
10	.6447						.8048
11	.4119		.6697		.5281		
12	.394		.3292	.3681	.3772	.6036	
13	.3761		.543	.5083	.2829	.547	.3439
14	.394		.4755	.3856		.5658	.3395
15			.5611	.4298	.3018	.7167	.3584
16	.6268		.4755		.5093	.7922	
17	.7164				.4904	1.0562	
18	1.0208		.7577	.9145		1.1317	1.2382
19	1.3575	1.094	1.2752	1.3535	1.1694	1.1128	
20	1.226	1.226	1.46	1.4266	1.1506	1.0751	1.46
21	1.0562	.8488	1.4415	1.2803	.9619	.9054	1.46
22	.9619	.8488	1.4045	1.2437	.9431	.9054	1.423
23	.985	.8299	1.262	1.2254	.8299	.8299	1.4045
24	.2829	.6268	.811	1.2071	1.1888	.8488	.7545
Max	1.3575	1.2894	1.46	1.4299	1.4266	1.3203	1.46
Min	.2829	.6268	.3292	.3681	.2829	.547	.3395
Avg	.6612	.9664	.9311	1.0587	.9079	.9096	.9894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134065 / MALKHEDA

Feeder No / Name : 203 / IBRAHIMPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.8059	.3772	.3658	.3224	.2641	.3961
2	.811	.8596	.3772	.439	.3224	.2641	.4338
3	.9431	.8954	.4527	.5249	.394	.2641	.4715
4	1.2826	.9313	.5281	.5552	.4835	.3772	.5281
5		1.0387	.5847	.591	.5373	.4715	.6036
6		1.182	.6413	.6805	.8059	.547	.7167
7	.8488		.547	.7964	.985	.5658	.811
8	1.2826	.7922	.6413	.695	1.0745	.6224	.9242
9	.9431		.5093	.6516		.5847	.8865
10	.3721						.5175
11	.3045		.4435		.2075		
12	.298		.4572		.2452	.4527	
13	.2686		.3475	.2328	.2829	.3772	.2218
14	.2686		.3142	.3224		.415	.2641
15	.2865			.3582	.3206	.5281	.2452
16	.2865		.499		.3018	.6602	.3326
17	.3045				.4338	1.0751	.439
18	.6447		.6099	.4938		.9808	.6838
19	.8869	.7922	.7207	.8048		.9054	
20	.9431	1.0751	.9979	1.0974	1.0374	.8299	1.1458
21	.811	.8299	.7947	1.0608	8.6933	.811	.8131
22	.8488	.7922	.7947	1.0059	.7356	.7922	.8131
23	.7701	.7545	.7316	.7316	.7356	.7545	.7392
24	.811	.788	.3584	.3109	.3475	.3018	.3584
Max	1.2826	1.182	.9979	1.0974	8.6933	1.0751	1.1458
Min	.2686	.7545	.3142	.2328	.2075	.2641	.2218
Avg	.6831	.8875	.5585	.6167	.9614	.5839	.5879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 201 / ALAND

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944		.3944	.1669	.4115	.5761	.6859
2	.4338		.3944	.1646	.4115	.6173	.6447
3	.4601		.3944	.1783	.439	.7407	.6954
4	.4601		.4601	.1783	.4801	.8345	.7232
5	.5258		.5182	.192	.6222	.8345	.751
6	.5916		.5571	.2469	.7575	.8762	.8623
7	.7099		.57	.2782	.8522	.904	.9318
8	.57		.6447	.2921	.8779	.8345	1.0014
9	.4311		.6173	.2667		.8019	.8939
10	.4311					.4146	.3155
11	.4534		.1296	.0648	.2105	.3286	.184
12	.4734			.0518		.3286	.184
13	.4938			.0648	.1619	.3812	.1578
14				.0541		.4252	.1578
15	.434				.1555		
16	.583				.1972	.547	.4858
17	.4212			.2435	.3155		.5506
18	.5344	.5761		.4115	.5127		.6154
19	.8288	.5761		.6036	.539		
20	.7611	.5441		.631	.5521	.4902	.3401
21	.6154	.4601	.4851	.5898	.4938	.5344	.5668
22	.4075	.4207	.459	.4664	.4664	.439	.4311
23	.3944	.3944	.4115	.4115	.4252	.4252	.439
24	.3812	.3574	.3812	.1783	.5624	.5487	.5702
Max	.8288	.5761	.6447	.631	.8779	.904	1.0014
Min	.3812	.3574	.1296	.0518	.1555	.3286	.1578
Avg	.5126	.4756	.4584	.2731	.4722	.5941	.5540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 202 / JANEFAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321		.3481	.3647	.4973	.4973	.4917
2	.2486		.3647	.4144	.4973	.5304	.4641
3	.2486		.4641	.4652	.547	.5801	.5304
4	.3315		.5801	.4973	.5801	.6962	.5801
5	.3315		.663	.5636	.7293	.9945	.6962
6	.3647		.7459	.5801	.9614	1.0774	.8288
7	.3978		.6133	.3315	1.0774	1.0343	1.0111
8	.4641		.3481	.779	.9116	.8951	.8288
9	.431		.1989			.7625	.5138
10						.3149	.3481
11					.3812	.3149	.5138
12	.2652		.1658	.2984	.3812	.3315	.547
13				.2652		.2984	.5304
14			.1823	.3315		.4144	.547
15			.1658				
16				.3812		.4807	
17	.3647			.3647			.4475
18				.3812	.4475		.663
19	.4973	.4973			.8122		
20	.547	.5138		.8951	.6962	.5801	.7956
21	.4807	.4144	.5801	.6274	.5801	.5636	.6299
22	.3978	.3812	.5304	.5636	.5138	.5304	.5801
23	.3481	.3481	.2984	.4641	.4641	.4641	.4807
24	.2155	.3481	.3481	.4475	.4475	.431	.4475
Max	.547	.5138	.7459	.8951	1.0774	1.0774	1.0111
Min	.2155	.3481	.1658	.2652	.3812	.2984	.3481
Avg	.3627	.4172	.4123	.4745	.6191	.5896	.5941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 203 / BHARAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973		.3978	.4239	.4191	.39	.3149
2	.547		.4144	.4578	.4527	.4409	.407
3	.5801		.4144	.5087	.4578	.4748	.4748
4	.5801		.4973	.5765	.5426	.5426	.5426
5	.663		.5801	.6274	.5365	.5935	.5935
6	.7459		.6796	.7122	.6535	.6613	.6613
7	.8288		.7459	.6783	.6443	.7291	.7291
8	.663			.6274	.763	.5765	.4748
9	.4144		.7209			.6299	.6962
10	.4024					.5304	.3812
11	.6104		.2515	.2515	.2486	.3812	.2652
12	.5636		.3315	.2347	.1989	.4641	.3149
13	.6133		.2984	.2515	.1989	.547	.2984
14			.2321	.2713		.7209	.2818
15	.3647		.3315				
16	.0829			.373	.0497	.779	.7293
17	.0663			.4024	.0829		.7293
18	.6299	.6962		.4748	.0332		.8785
19	.9614			.6613	.9116		
20	.779	.3812		.5087	.7459	.3812	.6796
21	.5801	.3978	.5636	.6203	.3561	.431	.5801
22	.5304	.5138	.5087	.5426	.3561	.4359	.5304
23	.4807	.4807	.4409	.4409	.4359	.4024	.4641
24	.4641	.3978	.3978	.4435	.373	.3561	.3222
Max	.9614	.6962	.7459	.7122	.9116	.779	.8785
Min	.0663	.3812	.2321	.2347	.0332	.3561	.2652
Avg	.5499	.4779	.4592	.4804	.4230	.5234	.5159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 204 / ASAI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652		.3481	.3688	.5365	.503	.4807
2	.2321		.3647	.3856	.5426	.503	.503
3	.2486		.4144	.4359	.57	.5365	.5596
4	.2486		.4973	.4694	.6203	.5868	.5935
5	.2652		.5801	.503	.6443	.6371	.6203
6	.3149		.8122	.57	.763	.6962	.7122
7	.3315		.6464	.5533	.8478	.3521	.7377
8	.3978		.5967	.4191	.8383	.2683	.8048
9	.2883					.4973	.4807
10	.1326					.3978	.431
11	.116		.2652	.1989	.4641	.3978	.6299
12	.1492		.2984	.2321	.547	.3647	.5967
13	.1187		.2652	.1989	.6133	.3315	.6962
14			.1823				.7625
15	.1326		.2486				
16	.1492		.2652	.2683	.3647		.7459
17	.431		.2652	.4359	.3978		.7127
18	.3978	.5801	.4973	.4862	.6133		.3978
19	.6299	.6796	.5304	.6874	.6962		
20	.779	.7293	.7293	.7042	.6299	.6133	.547
21	.663	.5967	.663	.7712	.5426	.547	.6796
22	.5967	.5967	.4641	.6539	.503	.5426	.6274
23	.5636	.431	.4359	.5365	.503	.5426	.5765
24	.2984	.547	.3481	.4239	.57	.57	.4748
Max	.779	.7293	.8122	.7712	.8478	.6962	.8048
Min	.116	.431	.1823	.1989	.3647	.2683	.3978
Avg	.3370	.5943	.4417	.4651	.5904	.4938	.6078

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 205 / TEMBHURNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953		.3429	.2858	.3429	.3429	.3239
2	.1143		.3429	.2858	.362	.3429	.3429
3	.1143		.381	.3239	.4001	.4001	.362
4	.1524		.4763	.362	.4382	.4382	.381
5	.1905		.5716	.4572	.4572	.5335	.5144
6	.2572		.8573	.5335	.5335	.5906	.724
7	.3353		.5365	.6097	.6478	.7621	.7811
8	.3185		.4748	.5335	.6478	.6097	.0648
9	.2858		.3391			.5525	.4954
10	.1715					.4191	.5335
11	.1143		.2713	.1357	.5906	.362	.7049
12	.0953		.3048	.1696		.4382	.6859
13	.1334		.2652	.1696	.5144	.5144	.7621
14				.1524		.4917	.6706
15	.1189				.5906		
16				.1905	.5525	.5525	.6287
17	.1593				.5973		.4973
18	.2858	.6097			.5335		
19	.4012	.57			.5533		
20	.3715	.5256			.4763	.3563	.2667
21	.4161	.4706	.3429	.4572	.5335	.3812	.4572
22	.4001	.362	.3048	.4001	.5906	.5335	.4001
23	.3429	.3429	.2477	.381	.3239	.362	.2858
24	.0953	.3429	.3429	.2477	.3429	.3429	.3429
Max	.4161	.6097	.8573	.6097	.6478	.7621	.7811
Min	.0953	.3429	.2477	.1357	.3239	.3429	.0648
Avg	.2259	.4605	.4001	.3350	.5014	.4663	.4869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 206 / JAFRABAD

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402		.8029	.8029	.8589	.8962	.7655
2	.8215		.8402	.8402	.8775	.8962	.6706
3	.7625		.9335	.9149	1.0456	.8962	.9709
4	.8962		1.0269	1.0082	1.2136	1.3443	1.1203
5	1.2136		1.2136	1.251	1.5684	1.4937	1.2696
6	1.4563		1.6244	1.7177	1.6804	1.531	1.7177
7	1.7737		1.7924	1.8111	1.7177	1.7364	1.8298
8	1.7177		1.6095	1.7551	1.7737	1.7924	1.9044
9	1.5684					.9709	1.7737
10	1.4563					1.5684	1.5123
11	1.307		1.0974	1.3032	1.2696	1.4003	1.4377
12	1.0456		1.1389	1.134	1.1203	1.1016	1.4003
13	.9709		.9335	1.0974	1.0269	1.0269	1.1016
14			.9149	.9709		1.0059	.8962
15	.9896		.9522		.9709		
16	1.1203		.9709		1.0082		.9896
17	1.2696		1.1576	1.3443	1.2696		1.251
18	1.2431	1.4377	1.1203	1.4003	1.5497		1.363
19	1.8298	1.4937	1.3817	1.5123	1.419		
20	1.4003	1.3817	1.5123	1.531	1.3443	1.2136	1.4003
21	1.2136	1.1389	1.1949	1.251	1.2136	1.0829	1.1763
22	.9896	.9709	1.0456	1.0456	1.0456	.8215	1.0456
23	.8962	.8402	.8962	.9335	.8962	.7842	1.0082
24	.8589	.8402	.8029	.8029	.8402	.8589	.7655
Max	1.8298	1.4937	1.7924	1.8111	1.7737	1.7924	1.9044
Min	.7625	.8402	.8029	.8029	.8402	.7842	.6706
Avg	1.2018	1.1576	1.1347	1.2214	1.2243	1.1801	1.2441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 201 / TEMBHURNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.2858		.3429	.3353	.381
2	.724		.3429		.381	.3688	.4191
3	.7811		.381		.4572	.3563	.4572
4	.9335		.4191		.5335	.3401	.5716
5	1.1812		.4572		.5716	.3239	.6668
6	1.2193		.5335		.5906	.4534	.8573
7	1.2384		.5906		.6478	.9602	1.0479
8	1.2574		.5144			.8097	.9717
9	.9526		.4763			.7611	
10	.3725			.743	.5407	.6287	
11	.3401			.4954	.3041	.5716	
12	.2949				.3441	.5335	
13	.2915					.4572	
14	.2229					.4954	
15	.2401				.2458	.5144	
16	.2229				.2949	.5716	
17	.2454		.7125	.8192	.2949	.6478	.5533
18	.6135	.8573	.8718	.9335	.4031	.6668	.7011
19	.8764	1.0288	1.046	1.0669	.6001	.6668	.8589
20	.8764	1.105	.8916	.9145	.4801	.6287	.8745
21	.7783	.8383	.8063	.6668	.3277	.5716	.6201
22	.6661	.7621	.6661	.5716	.2949	.6668	.543
23	.6697	.6859	.6344	.5335	.298	.6097	.5068
24	.6668	.6001	.2858	.2572	.2858	.2658	.381
Max	1.2574	1.105	1.046	1.0669	.6478	.9602	1.0479
Min	.2229	.6001	.2858	.2572	.2458	.2658	.381
Avg	.6813	.8396	.5833	.7002	.4119	.5502	.6507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 202 / AKOLADEO

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667		.381		.4191	.3601	.381
2	.3048		.4763		.4572	.3768	.4572
3	.3429		.5335		.4954	.4372	.5335
4	.381		.6668		.5906	.5668	.6668
5	.4191		.7621		.9145	.6316	.8383
6	.4572		.8383		1.0669	.8745	1.0288
7	.4954		.8954		.9335	.8097	.9526
8	.5335		.7049			.7611	.7377
9	.4954		.5335			.664	.6706
10	.2012			.381	.3563	.6478	.5992
11	.1509			.4572	.6836	.724	.6964
12	.1543				.6836	.7621	
13	.1402				.8063	.8002	
14	.1629				.8939	.8192	
15	.2172				.4531	.8002	.7701
16	.2353				.4843	.8383	.6796
17	.298		.2753	.5525	.6405	.8383	.6371
18	.3814	.5716	.3401	.5525	.4557	.724	.4382
19	.3772	.5716	.503	.7049	.6661	.5716	.6135
20	.583	.6287	.5487	.6668	.7537	.4763	.631
21	.4287	.5716	.4287	.5906	.5258	.4763	.4733
22	.3982	.4763	.4163	.5335	.4207	.4191	.4344
23	.3801	.4001		.4763	.4031	.381	.3982
24	.2286	.2229	.3429	.3601	.381	.3944	.381
Max	.583	.6287	.8954	.7049	1.0669	.8745	1.0288
Min	.1402	.2229	.2753	.3601	.3563	.3601	.381
Avg	.3347	.4918	.5404	.5275	.6130	.6314	.6199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 203 / PAPAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858		.381		.2858	.2401	.2858
2	.3239		.4572		.2858	.285	.381
3	.381		.5335		.381	.3239	.4763
4	.4191		.6097		.4572	.3725	.5716
5	.4954		.6668		.5525	.5182	.724
6	.4763		.7621		.743	.7449	.8954
7	.4954		.8002		.6287	.6478	.9335
8	.5144		.5906			.5693	.724
9	.4382		.4001			.5182	.503
10				.2858	.4115	.4954	.503
11				.2286	.4854	.5335	.5668
12					.4531	.5335	.5344
13					.5487	.5716	.583
14					.5721	.5716	.502
15	.1174				.3982	.5525	.4694
16	.1372				.5434	.5335	.5197
17	.2279		.2429	.4191	.5609	.5335	.503
18	.333		.3018	.5335	.3506	.381	.4908
19	.5611		.4527	.6287	.583	.4763	.4733
20	.4525		.4382	.5335	.5784	.4382	.4961
21	.3801		.3856	.4572	.4031	.4191	.3721
22	.3258		.2715	.4191	.3113	.381	.3439
23	.3077		.2804	.3429	.298	.2858	.2896
24	.2858	.2058	.3429	.2804	.2858	.2572	.2858
Max	.5611	.2058	.8002	.6287	.743	.7449	.9335
Min	.1174	.2058	.2429	.2286	.2858	.2401	.2858
Avg	.3662	.2058	.4657	.4129	.4599	.4660	.5178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 204 / BHATODI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572				.381	.4287	.5335
2	.5335				.4763	.5197	.5716
3	.6478				.5716	.6478	.6287
4	.743				.6668	.9393	.7621
5	.8954				.8383	.8592	.9145
6	.9145				.9717	1.2651	1.0479
7					1.5242	1.439	1.2765
8						1.4548	
9	.5335					1.4089	1.3527
10	.3887			.4001	.3277	.6478	
11	.2591			.2096	.208	.6668	
12	.2753				.2294	.6478	
13	.3521				.213	.6287	
14					.2347	.6097	
15	.3086				.2683	.6097	.285
16	.2804				.3222	.6097	.4115
17	.3258		.503	.4763	.703	.6097	.4908
18	.5083	.724	.6203	.724	.6516	.6287	.5847
19	.7964		.7712	.9526	.703	.6478	
20	.7011	.8192	.703	.8573	.5935	.6097	.7265
21	.6154	.743	.6135	.743	.6173	.5716	.5609
22	.5973	.6668	.5784	.6097	.583	.5335	.543
23	.5792	.6668		.5716	.6154	.4763	.5249
24	.4191	.5487		.3258	.3429	.4458	.5335
Max	.9145	.8192	.7712	.9526	1.5242	1.4548	1.3527
Min	.2591	.5487	.503	.2096	.208	.4287	.285
Avg	.5301	.6948	.6316	.587	.5474	.7461	.6911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 205 / AMBEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.2858		.3429	.3086	.3239
2	.2286		.2858		.381	.3353	.381
3	.2286		.3429		.4191	.3856	.4191
4	.2667		.381		.4954	.4359	.5335
5	.2858		.4191		.5335	.4858	.6097
6	.2858		.4191		.6287	.5506	.6668
7	.2858		.4572		.5906	.4696	.6097
8	.2858		.381			.4049	.3239
9	.2667		.2286			.2915	.2915
10				.2286	.2401	.2858	.2753
11				.3429	.4508	.3048	.4372
12					.3944	.3429	.4049
13					.4801	.381	.664
14					.4508	.4572	
15	.0648				.2601	.4763	
16	.0857				.4458	.5144	
17	.1052		.1781	.381	.4801	.5335	
18	.1402		.1509	.4572	.1543	.2858	
19	.3856		.218	.4382	.3856	.3429	.3506
20	.4163		.4557	.4191	.4287	.381	.4252
21	.3439		.3506	.4001	.3772	.381	.3366
22	.333		.3681	.362	.3801	.3429	.3439
23	.3439		.3506	.3429	.3681	.3429	.3077
24	.1905	.2058	.2858	.333	.3429	.3601	.3239
Max	.4163	.2058	.4572	.4572	.6287	.5506	.6668
Min	.0648	.2058	.1509	.2286	.1543	.2858	.2753
Avg	.2491	.2058	.3270	.3705	.4105	.3917	.4225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134021 / 33KV TEMBHURNI

Feeder No / Name : 206 / DAWARGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668		.5335		.4763	.4458	.5335
2	.724		.5716		.4954	.4694	.6097
3	.8383		.6097		.5525	.5533	.6668
4	1.2003		.6668		.6097	.5868	.7621
5	1.5242		.724		.724	.583	.8573
6	.4191		.7621		.9145	.8097	1.0288
7	.381		.8192		1.2193	1.2334	1.3908
8	.2667		.9145			1.1248	1.448
9	.2286		.7621			1.0311	.8048
10				.6287	.5182	1.0669	.6203
11				.4001	.4049	.9526	.3521
12					.3281	.9145	.3401
13					.3281	.8002	.3856
14						.8002	
15	.5992				.3506	.9145	.3688
16	.4458					.9717	.4527
17			.6203	.4001	.2031	1.0288	.7461
18		.9145	.788	.9145		.9526	.9774
19	1.2174	1.1622	1.046	1.3527		.9145	1.2269
20	1.1488	1.1431	1.0117	1.2193	1.0551	.9145	1.1568
21	.8939	.9717	.823	1.0098	.9189	.8383	.929
22	.7537	.8573	.7011	.9145	.7712	.7621	.8145
23	.7059	.6859	.631	.6859	.631	.6668	.7316
24	.6668	.6516	.5335	.3944	.4763	.4287	.4763
Max	1.5242	1.1622	1.046	1.3527	1.2193	1.2334	1.448
Min	.2286	.6516	.5335	.3944	.2031	.4287	.3401
Avg	.7459	.9123	.7364	.792	.6098	.8235	.7687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 201 / WARUD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149		.4477			.4656	.4854
2	.2328		.4835			.5014	.5228
3	.2658		.4835			.5373	.5601
4	.3155		.5373			.5731	.6468
5	.3601		.591			.6268	.7392
6	.431		.7164			.7522	.7762
7	.4588		.8596			.8954	.8316
8	.4096		.8059			.7164	.7392
9	.2947		.4835			.5731	.6468
10	.2743		.2303		.1791	.2865	
11	.2401		.197		.2328	.2686	
12	.2572		.2149		.2507	.2149	
13	.2572				.2328	.2515	
14			.2126		.2149	.2543	
15			.2126		.2149	.2374	
16			.2126		.197	.2229	
17			.2303		.2149	.2515	
18			.5228			.6535	
19		.7164	.6283		.6805	.5788	
20		.6447	.7468			.5601	
21		.6089	.5788			.5228	
22		.5014	.5093		.5731	.4904	
23		.4656	.4715		.4656	.4668	
24	.2303	.503	.4477	.4715		.4298	.4481
Max	.4588	.7164	.8596	.4715	.6805	.8954	.8316
Min	.2149	.4656	.197	.4715	.1791	.2149	.4481
Avg	.3030	.5733	.4706	.4715	.3142	.4721	.6396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 202 / ADHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0029		.4477			.5121	.4641
2	1.0387		.4525			.5014	.4807
3	1.0631		.4656			.5373	.4915
4	1.1517		.4656			.6089	.5668
5	1.1694		.5014			.6447	.5992
6	1.1694		.5373			.7164	.6478
7	1.0985		.591			.7522	.6316
8	.9492		.6268			.6805	.6316
9	.6878		.5731			.6447	.5898
10	.2743		.6154			.8507	
11	.2743		.3841			.6697	
12	.3429		.3048		.3224	.567	
13	.3601		.3239		.3224	.5304	
14			.462		.3224		
15			.3361		.3224	.7499	
16			.4805		.5014	.7421	
17			.7682		.5731	.985	
18			.8688			1.0745	
19		1.0745	.9412		1.2178	1.0566	
20		1.1104	.8688			1.1104	
21		1.1104	1.182			1.1641	
22		1.0387	1.1104		1.0745	1.2178	
23		.985	1.0745		.985	1.0029	
24	1.0208	.3353	.5014	.4475		.5014	.4641
Max	1.1694	1.1104	1.182	.4475	1.2178	1.2178	.6478
Min	.2743	.3353	.3048	.4475	.3224	.5014	.4641
Avg	.8288	.9424	.6201	.4475	.6268	.7748	.5567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 203 / WANKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149		.1791			.1254	.1791
2	.2481		.1791			.1433	.1791
3	.2804		.1791			.1612	.2303
4	.3391		.2149			.1791	.2481
5	.3521		.2507			.2195	.3155
6	.4096		.3155			.2507	.3429
7	.3688		.3856			.3582	.3391
8	.3521		.3582			.3224	.3258
9	.2774		.2149			.2865	.2629
10	.1029		.1829		.2507	.3012	
11	.1052		.1294		.2126	.2149	
12	.1052		.1294		.2172	.1791	
13	.1052		.1478		.197	.181	
14			.1294		.1791	.1791	
15			.2149		.1791	.2401	
16			.1463		.1433	.2658	
17			.2149		.2149	.3353	
18			.2658			.3086	
19		.5731	.3189		.3582	.2947	
20		.3582	.3506			.2601	
21		.2507	.3012			.2279	
22		.2328	.2835		.2149	.2103	
23		.2149	.2328		.1791	.2126	
24	.181	.2683	.1791	.2149		.1791	.2303
Max	.4096	.5731	.3856	.2149	.3582	.3582	.3429
Min	.1029	.2149	.1294	.2149	.1433	.1254	.1791
Avg	.2459	.3163	.2293	.2149	.2133	.2348	.2653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 204 / KOLEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2481		.3224			.2865	.3772
2	.2804		.3292			.3224	.3961
3	.3429		.3658			.3224	.4294
4	.3688		.3982			.3582	.4854
5	.3932		.4298			.3856	.5914
6	.4915		.4835			.4835	.6468
7	.5506		.6268			.6268	.6099
8	.583		.5014			.5731	.5914
9	.5079		.3761			.394	.4338
10	.1052		.3688		.3761	.3391	
11	.1052		.3086		.3582	.3561	
12	.1052		.3521		.3761	.3258	
13	.1052		.2401		.4298	.5079	
14			.3978		.4298	.4641	
15			.4144		.394	.4359	
16			.4144		.3403	.4694	
17			.431		.394	.4915	
18			.381			.5544	
19		.5731	.5093		.5731	.5544	
20		.5014	.4668			.499	
21		.4298	.4191			.5175	
22		.4119	.4001		.394	.462	
23		.394	.381		.3582	.4338	
24	.2481	.2374	.3582	.381		.3224	.415
Max	.583	.5731	.6268	.381	.5731	.6268	.6468
Min	.1052	.2374	.2401	.381	.3403	.2865	.3772
Avg	.3168	.4246	.4032	.381	.4021	.4369	.4976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 205 / KONAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1075			.1254	.1267
2	.2096		.1075			.1254	.1254
3	.2477		.1075			.1433	.1433
4	.3429		.1433			.1433	.1772
5	.381		.2149			.1991	.1772
6	.5601		.2507			.2149	.1928
7	.4904		.2454			.2507	.1772
8	.4715		.2743			.2149	.2601
9	.362		.2172			.2149	.2254
10	.1715		.1905		.1254	.2477	
11	.1715		.1143		.0709	.1334	
12	.1886		.0762			.1143	
13	.2058		.0953			.1143	
14			.0762			.1905	
15			.1143				
16			.1143		.1254		
17			.2477		.1433	.1905	
18						.415	
19		.4119	.381		.394	.3429	
20		.3224	.4191			.2858	
21		.2865	.2858			.2667	
22		.2149	.2286		.2507	.2286	
23		.197	.2096		.197	.2096	
24	.2096	.1715	.1433	.1433		.1433	.1448
Max	.5601	.4119	.4191	.1433	.394	.415	.2601
Min	.1715	.1715	.0762	.1433	.0709	.1143	.1254
Avg	.3002	.2674	.1898	.1433	.1867	.2052	.1750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134022 / WARUD 33/11 KV S.S

Feeder No / Name : 206 / BHARADKHEDA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.394			.5373	.4915
2	.695		.394			.5731	.5243
3	.724		.4298			.6024	.5898
4	.8145		.4656			.6447	.6154
5	.985		.5014			.6805	.6316
6	.9313		.5373			.8238	.759
7	.8507		.691			.8954	.8124
8	.7421		.6447			.8596	.8436
9	.724		.6516			.8059	.8539
10	.503		.3429		.2328	.5228	
11	.4527		.1905		.1791	.4338	
12	.4359				.1791	.3429	
13	.4191				.1791	.362	
14					.1791	.4108	
15					.197	.5041	
16					.2149	.5415	
17					.2507	.5601	
18		.6805	.4668			.4854	
19		.9313	.9955		.6661	.8145	
20		.8954	.9231			.8688	
21		.8596	.8688			.695	
22		.8059	.8145		.724	.695	
23		.7522	.7783		.6805	.6401	
24	.7059	.3429	.394	.4475		.591	.4915
Max	.985	.9313	.9955	.4475	.724	.8954	.8539
Min	.4191	.3429	.1905	.4475	.1791	.3429	.4915
Avg	.6882	.7525	.5824	.4475	.3348	.6204	.6613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 201 / 11 KV PIMPALGAON KAD Single Phasing Feeders

FEEDER Feeder KV- 11 /
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823		.3258			.3601	.2743
2	.823		.3258			.3944	.3086
3	.8402		.3944			.3944	.3429
4	.8573		.4973			.4801	.4287
5	.9088		.6516			.5316	.4801
6	.9602		.6859			.6001	.5316
7	.9945		.703			.6344	.6687
8	.8745		.6516			.6173	.703
9	.7202		.5658			.583	.7373
10	.2743			.5144		.5144	.4075
11				.5144		.4801	.2629
12				.4801		.4287	.2172
14							.2149
15	.3086			.4973	.3944		.3506
16	.3258			.6001	.6344	.7545	.4252
17	.3086	.5316		.6859	.703	.7716	.5434
18		.7373		.703	.8916	.7545	
19	1.0974	.9259		.7716	.9602	.823	
20	1.0288	.9431		.8402	.9431	.9431	
21	1.0288	.9774		.8573	.9259	.8573	
22	.9431	.9088		.8573	.9088	.8402	
23	.9259	.8059		.8916	.8745	.7888	.8688
24	.9088	.3258	.2915			.3601	.3086
Max	1.0974	.9774	.703	.8916	.9602	.9431	.8688
Min	.2743	.3258	.2915	.4801	.3944	.3601	.2149
Avg	.7869	.7695	.5093	.6844	.8040	.6148	.4486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 202 / 11 KV MAHORA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258		.5144			.4973	.5144
2	.3601		.5144			.4973	.5144
3	.3944		.5658			.6173	.6859
4	.463		.6516			.6687	.7716
5	.4973		.7373			.7373	.8573
6	.5144		.7888			.8402	.9602
7	.5487		.8059			.9088	.8573
8	.4973		.7202			.7888	.823
9	.4458		.6516			.6859	.7202
10	.4458			.3772		.2743	
11				.3944		.2915	.362
12						.3086	.3155
13				.2915		.3086	
14						.3258	.3403
15	.3429				.2229	.3258	.3544
16	.3429			.3258	.2229	.3086	.3856
17	.4287	.3429		.3429	.2058	.2915	.4075
18	.5658	.463		.4287	.6001	.9088	
19	.823	.583		.463	.7888	.8573	
20	.7716	.6344		.583	.703	.7888	
21	.7716	.6516			.6687	.6859	
22	.6859	.6001		.6001	.583	.6001	
23	.4801	.5487		.6173	.5316	.5316	.4572
24	.2572	.4801	.5144			.4973	.4801
Max	.823	.6516	.8059	.6173	.7888	.9088	.9602
Min	.2572	.3429	.5144	.2915	.2058	.2743	.3155
Avg	.4981	.5380	.6464	.4424	.5030	.5644	.5769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 203 / 11 KV WADALA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3258	.2743			.463	.2743
2	.2743	.3429	.2743			.4973	.3086
3	.3258	.3772	.3258			.4973	.3429
4	.5487		.4287			.6516	.6001
5	.823		.583			.7202	.6859
6	.9602		.6173			.7716	.7545
7	1.0288		.6344			.8059	.823
8	.8745		.6344			.703	.5316
9	.5316		.5316			.5487	.6859
10	.3429			.6859		.2572	.5316
11				.6859		.2229	.2835
12				.6001		.1715	
13				.6001		.2229	
14				.5144		.2572	.2804
15	.3429			.6859	.2572	.2743	.3189
16	.3601			.5144	.2915	.3086	.3856
17	.3429	.3086			.3258	.3772	.5014
18	.5144	.3601		.5316	.4115		
19	.6001	.3944		.5316	.4973	.6001	
20	.6859	.4115		.5487	.3944	.6001	
21	.6001	.3601		.5487	.3258	.6859	
22	.5144	.3258		.5658	.2915	.5144	
23	.5144	.2743		.583	.2572	.5144	.439
24	.2401	.2572	.2572			.2743	.2572
Max	1.0288	.4115	.6344	.6859	.4973	.8059	.823
Min	.2401	.2572	.2572	.5144	.2572	.1715	.2572
Avg	.5341	.3398	.4561	.5843	.3391	.4756	.4708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 204 / 11KV MHASARUL FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.463			.3601	.5144
2	.2058		.463			.3601	.6001
3	.2229		.4973			.463	.6859
4	.2915		.5487			.6173	.7716
5	.3944		.6001			.7373	.8573
6	.463		.6516			.823	.9945
7	.5144		.6859			.8573	.9602
8	.4458		.6173			.8059	.8745
9	.3258		.5658			.7545	.6859
10	.2572			.3086		.2572	.2103
11						.2743	.3189
12						.2743	.1052
13						.2572	
14						.2058	.2658
15	.1543			.2743	.1715		.2835
16	.1543			.2572	.1886	.2229	.3155
17	.3429	.4287		.3258		.2401	.4252
18	.5144	.3258		.3429	.5658	.4287	
19	.8402	.4458		.3601	.8745	.4973	
20	.7716	.6001		.3944	.8402	.5144	
21	.6001	.6344		.4115	.703	.6001	
22	.5658	.5658		.4287	.6173	.5144	
23	.5487	.4973		.4458	.4973	.4801	.5487
24	.2229	.5144	.463			.3772	.4287
Max	.8402	.6344	.6859	.4458	.8745	.8573	.9945
Min	.1543	.3258	.463	.2572	.1715	.2058	.1052
Avg	.4021	.5015	.5556	.3549	.5573	.4749	.5470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 205 / 11KV BELORA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086		.4287			.4287	.3429
2	.3258		.4287			.4287	.4287
3	.3258		.4973			.5316	.5144
4	.3601		.6001			.6001	.7716
5	.4115		.7202			.6687	.8573
6	.4287		.7888			.7202	.9774
7	.4458		.823			.7545	.9259
8	.3944		.6859			.703	.7545
9	.2915		.5658			.6687	.5658
10	.2058			.3429		.1715	.2629
11				.3944		.1886	.3439
12				.3944		.2058	.2658
13				.3601		.2229	
14				.3429		.2229	.2303
15	.1543			.3429	.3086	.2229	.2481
16	.1543			.3086	.3944	.2229	.2686
17	.2572	.1886		.4458	.4801	.2229	.2865
18	.3772	.3772		.3772	.5487	.4973	
19	.703	.463		.4287	.6344	.9259	
20	.6859	.4973		.463	.583	.8573	
21	.6859	.5316		.4973	.5144	.7716	
22	.6001	.4973		.5144	.4973	.6859	
23	.4973	.463		.5316	.4801	.4801	.5792
24	.2915	.5144	.4287			.4287	.4287
Max	.703	.5316	.823	.5316	.6344	.9259	.9774
Min	.1543	.1886	.4287	.3086	.3086	.1715	.2303
Avg	.3952	.4416	.5967	.4103	.4934	.4930	.5029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171			.0171	.0171
2	.0171	.0171	.0171			.0171	.0171
3	.0171	.0171	.0171			.0171	.0171
4	.0171	.0171	.0171			.0171	.0171
5	.0171	.0171	.0171	.0171		.0171	.0171
6	.0171	.0171	.0171			.0171	.0171
7	.0171	.0171	.0171	.0171		.0171	.0171
8	.0171		.0171	.0171		.0171	.0171
9	.0171		.0171	.0171		.0171	.0171
10	.0171			.0171		.0171	.0177
11				.0171		.0171	.0181
12						.0514	
13						.0171	
14						.0171	.0177
15	.0171			.0171	.0171	.0171	.0179
16	.0171				.0171	.0171	.0177
17	.0171	.0343		.0171	.0171	.0171	.0175
18	.0171	.0171		.0171	.0171		
19	.0171	.0171		.0171	.0171	.0171	
20	.0171	.0171		.0171	.0171	.0171	
21	.0171	.0171		.0171	.0171	.0171	
22	.0171	.0171		.0171	.0171	.0171	
23	.0171	.0171		.0171	.0171	.0171	.0183
24	.0171	.0171	.0171			.0171	.0171
Max	.0171	.0343	.0171	.0171	.0171	.0514	.0183
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0182	.0171	.0171	.0171	.0186	.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134042 / HIVRAKABLI

Feeder No / Name : 207 / BRAHMAPURI AG

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUL-17	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1			1.086
2			1.086
3			1.086
4			1.086
5			1.086
6		.8507	1.086
7		.8688	1.1222
8		.905	1.1584
9		.905	1.1584
10	1.0679		
11	1.0136		
12	.9955		
13	.9593		
14	.9412		
15	.9593		
16	.9774		
17	.9231		
24			1.0679
Max	1.0679	.905	1.1584
Min	.9231	.8507	1.0679
Avg	.9797	.8824	1.1023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134042 / HIVRAKABLI

Feeder No / Name : 208 / KALEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.4191	.381	.4572
2		.1334	.4191	.381	.4763
3		.1334	.4191	.381	.5144
4		.1524	.4191	.381	.5144
5		.2096	.381	.381	.5716
6		.2858	.381	.381	.5906
7		.3429	.4191	.381	.5716
8		.362	.4191	.381	.5716
9		.4001	.381	.381	
12	.362				
13	.5335				
14	.5335				
15	.4887				
16	.4887				
17	.4191				
24		.1334	.4001	3.8104	.4572
Max	.5335	.4001	.4191	3.8104	.5906
Min	.362	.1334	.381	.381	.4572
Avg	.4709	.2286	.4058	.7239	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 201 / POKHRI - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0772		.2315	.2315	.2315	.2315	.3086
2	.0772		.2315	.2315	.2315	.2315	.3086
3	.0772		.2315	.2315	.2315	.2315	.3086
4	.0772		.3086	.3086	.3086	.3858	.3858
5	.0772		.3086	.3086	.3858	.5401	.3858
6	.0772		.3086	.3858	.463	.6173	.463
7			.3086	.3858	.5864	.6173	.5401
8			.3858	.463		.6944	.6173
9			.3858	.5401		.463	.6944
10	.3858						
11	.463						
12	.463						
13	.463						
14	.3086						
15	.3086						
16	.3858	.3086	.0772			.0772	.0309
17	.3858	.3086	.0772	.0772			.0772
18	.0772	.0772	.0926	.0772			.0772
19	.0772	.0772		.0772	.0926		.0926
20	.0926	.0772		.0772	.0926	.0772	.0926
21	.0926	.0772	.0772	.0772	.0926	.0772	.0926
22	.0926	.0772	.0772	.0772	.0772	.0772	.0772
23	.0772	.0772	.0772	.0772	.0772	.0772	.0772
24	.0772		.2315	.2315	.2315	.3086	.3086
Max	.463	.3086	.3858	.5401	.5864	.6944	.6944
Min	.0772	.0772	.0772	.0772	.0772	.0772	.0309
Avg	.2006	.1351	.2132	.2270	.2386	.3138	.2744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 203 / NIVDUNGA - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.0762	.0762	.0753	.0743	.0762
2	.1524		.0762	.0762	.0753	.0743	.0762
3	.1524		.0762	.0762	.0753	.0743	.0762
4	.1524		.0762	.0762	.0753	.0743	.0762
5	.1524		.1067	.0903	.0753	.104	.0762
6	.1524		.1067	.104	.0753	.104	.0762
7	.2286						
8	.2286						
9	.2286						
10				.2286		.3048	.2286
11				.301	.5201	.301	
12					.743	.3763	.5201
13					.6687	.3763	.6687
14					.743	.4515	.5944
15						.4515	.5944
16	.0762	.0762				.3763	.5944
17	.0762	.0762		.301		.3763	.5944
18	.0762	.0762	.0762	.0753			.0743
19	.0762	.0762		.0753	.0743		
20	.0762	.0762		.0753	.0743	.0762	.0753
21	.0753	.0762	.0743	.0753	.0743	.0762	.0753
22	.0753	.0762	.0753	.0753	.0743	.0762	.0743
23	.0762	.0762	.0753	.0753	.0743	.0762	.0743
24	.1524		.0762	.0762	.0753	.0743	.0762
Max	.2286	.0762	.1067	.301	.743	.4515	.6687
Min	.0753	.0762	.0743	.0753	.0743	.0743	.0743
Avg	.1311	.0762	.0814	.1161	.2233	.2052	.2475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 201 / BORAGAON MATH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724		.4641	.6135		.5571	.4681
2	.7682		.4801	.691		.6001	.5316
3	1.0608		.5201	.7619		.5571	.6201
4	1.0974		.5658	.9214		.6036	.6836
5	1.2308		.6036	.7701		.6516	.5434
6	1.2715		.6859	.8063		.6706	.6201
7	1.0679		.5434	.7442		.7287	.5487
8	.8048		.4191	.7796		.6706	.5609
9	.5121		.39	.5493		.4694	.5083
10	.3582		.2279	.2481		.6344	.3224
11	.3681		.2713	.2328	.4024	.583	.3403
12	.2507		.3506	.2328	.2926	.5258	.2686
13	.3582		.4075	.2507	.2926	.5434	.3224
14	.2686		.3544	.2686	.2534	.6415	.3403
15	.2686		.4207	.2686	.2561	.691	.394
16	.2865			.3582	.3292	.7186	.5194
17	.3403		.4607	.4656	.5415		.8417
18	.3506	.905	.5493	.7522	.8779		.8238
19	.394	1.0974	1.0631	1.0566	1.0242		.8775
20		.8145	1.0498	.788	.7316		.9313
21		.9145		.6268	.6584		.6379
22		.6036	.6626	.5609	.6283		.5609
23		.6219	.4706	.5316	.5853		.5373
24	.7316		.5731		.2865	.3467	
Max	1.2715	1.0974	1.0631	1.0566	1.0242	.7287	.9313
Min	.2507	.6036	.2279	.2328	.2534	.3467	.2686
Avg	.6256	.8262	.5243	.5773	.5114	.5996	.5566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 202 / PASODI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3395	.3467		.3361	.3155
2			.3734	.4207		.4108	.3721
3			.4338	.5028		.5281	.4382
4			.4344	.5784		.5487	.3544
5			.5121	.6201		.5975	.4252
6			.6036	.6836		.7095	.4784
7			.547	.6201		.5975	.5201
8			.4668	.5258		.5601	.4334
9			.3734	.3681		.4668	.3898
10			.2103	.2149	.2035	.2126	.0886
11			.1734	.1791	.1886	.2454	.0895
12			.1417	.2686	.1372	.2229	.1254
13			.124	.2507	.2035	.1949	.0895
14	.0895		.1052	.2534	.1543	.1928	.0716
15	.1254		.1417	.197	.1578	.2303	.0716
16	.1433		.1052	.2149	.156	.2629	.0716
17	.1791		.124	.197	.1715		.2865
18	.2328	.3547	.0876	.2507	.2801		.2865
19	.3856	.4668	.3439	.4298	.5658		.3224
20		.4854	.4656	.4835	.5601		.4207
21		.3921	.4163	.394	.5041		.3366
22		.3547	.1433	.3582	.3547		.2865
23		.3547		.3224	.3395		.3045
24			.2774		.298	.2715	
Max	.3856	.4854	.6036	.6836	.5658	.7095	.5201
Min	.0895	.3547	.0876	.1791	.1372	.1928	.0716
Avg	.1926	.4014	.3019	.3774	.2850	.3876	.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S

Feeder No / Name : 203 / KHASAGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052		.4108	.443		.5601	.3467
2	.3086		.4854	.3681		.5281	.4252
3	.3467		.5093	.3544		.6348	.3681
4	.3429		.5601	.4075		.679	.4557
5	.3772		.6036	.4887		.7468	.5028
6	.3988		.6722	.5552		.8589	.5434
7	.4239		.6722	.5316		.7545	.6201
8	.4409		.6161	.4557		.7167	.567
9	.3429		.3961	.3681		.6722	.3641
10	.1791		.1578	.1433		.2126	.1254
11	.1433		.1595	.1612	.1543	.208	.1063
12	.1433		.1949	.1791	.2103		.197
13	.1612		.1772	.197	.2229		.2328
14	.2149		.2353	.2149	.1753		.2629
15	.2686		.197	.2328	.1753	.2658	.2865
16	.2686		.2629	.2507	.2804	.2254	
17	.2454		.2172	.2328			.394
18	.3189	.6036	.2534	.2328			.394
19	.2686	.811	.5138	.4477			.567
20		.7922	.7537	.8059	.7922		.6201
21		.6036	.6485	.6024	.6535		.5847
22		.5847	.4525	.567	.6036		.5316
23		.5281	.4163	.5493	.6535		.5068
24	.5601		.3721		.5258	.4075	
Max	.5601	.811	.7537	.8059	.7922	.8589	.6201
Min	.1433	.5281	.1578	.1433	.1543	.208	.1063
Avg	.3030	.6539	.4141	.3821	.4043	.5336	.4092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 201 / 11 KV RAM MANDIR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5068			.5068		
2	.4801	.4887			.4887		
3	.4801	.4887			.5068		
4	.4801	.5792			.5792		
5	.5658	.6878			.6878		
6	.6859	.8507			.8326		
7	.8916	.9955			.9955		
8	.7716	.9593			.9412		
9	.7421		.8402	.9231		.8573	.8869
10	.6697		.7373	.8145		.5658	.7964
11	.6154		.6001	.6697		.583	.7059
12	.5249		.4801	.5611		.6001	.6516
13	.4344		.4801	.5611		.583	.0543
14	.3982		.5144	.5611		.5487	.5611
15	.3801		.5144	.5611		.5487	.5068
16			.583	.5611		.5658	.5792
17			.6001	.5792		.6516	.6335
18	.6878		.6001	.6335		.6859	.6878
19	.8145		.6859	.7059		.7202	.7421
20	.9231		.8402	.7964			.6878
21	.8326		.6859	.7421			.6154
22	.7059		.6516	.6516			.5611
23	.5792		.5658	.543			.5068
24	.4801	.543		.5144	.5249		.4527
Max	.9231	.9955	.8402	.9231	.9955	.8573	.8869
Min	.3801	.4887	.4801	.5144	.4887	.5487	.0543
Avg	.6192	.6777	.6253	.6487	.6737	.6282	.6018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 202 / MEDICAL COMPLEX

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6859			.724		
2	.5487	.6335			.724		
3	.5487	.6335			.724		
4	.5487	.724			.8145		
5	.6859	.905			.905		
6	1.0974	1.086			1.086		
7	1.2174	1.3575			1.267		
8	1.3717	1.3575			1.3575		
9	1.267		1.166	1.267		1.286	1.086
10	1.1765		1.0288	1.1765		1.0288	.9955
11	1.086		.9431	1.086		1.0288	.905
12	.905		.8916	.905		.9774	.8145
13	.8145		.7716	.8145		.8573	.724
14	.8145		.7373	.724		.7888	.6335
15	.724		.7373	.724		.7716	.6335
16			.7202	.724		.7716	.6335
17	.905		.7373	.724		.8916	.724
18	.9955		.7716	.8145		.9431	.905
19	1.086		.9431	.905		.9602	.9955
20	1.267		1.2003	1.267			.905
21	1.086		.9088	1.086			.8145
22	.9955		.7716	.905			.724
23	.8145		.703	.8145			.724
24	.6859	.724		.6859	.724		
Max	1.3717	1.3575	1.2003	1.267	1.3575	1.286	1.086
Min	.5487	.6335	.703	.6859	.724	.7716	.6335
Avg	.9235	.9008	.8688	.9139	.9251	.9368	.8145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 203 / SATELLITE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.543			.543		
2	.4801	.543			.543		
3	.4801	.543			.543		
4	.5144	.6335			.543		
5	.583	.724			.6335		
6	.7373	.8145			.724		
7	.8059	.905			.905		
8	.7716	.905			.905		
9	.724		.6687	.724		.6859	.724
10	.6335		.6001	.6335		.6516	.724
11	.6335		.5144	.6335		.6001	.6335
12	.543		.4458	.543		.4801	.543
13	.543		.4458	.543		.4801	.543
14	.543			.543		.4801	.543
15	.543			.543		.4801	.543
16			.6001	.543		.4973	.543
17	.543		.6173	.543		.5316	.543
18	.6335		.6001	.6335		.5487	.6335
19	.724		.6001	.724		.6173	.724
20	.905		.7545	.8145			.6335
21	.8145		.6859	.724			.6335
22	.724		.6001	.6335			.543
23	.543		.5144	.543			.543
24	.4801	.543		.5144	.543		
Max	.905	.905	.7545	.8145	.905	.6859	.724
Min	.4801	.543	.4458	.5144	.543	.4801	.543
Avg	.6253	.6838	.5883	.6147	.6536	.5503	.6033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 205 / MEDICAL EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0362			.0362		
2	.0343	.0362			.0362		
3	.0343	.0362			.0362		
4	.0343	.0362			.0362		
5	.0343	.0362			.0362		
6	.0343	.0362			.0362		
7	.0343	.0362			.0362		
8	.0343	.0362			.0362		
9	.0362		.0343	.0362		.0343	.0362
10	.0362		.0514	.0362		.0343	.0362
11	.0362		.0686	.0362		.0514	.0362
12	.0362		.0686	.0362		.0514	.0362
13	.0362		.0514	.0362		.0343	.0362
14	.0362		.0514	.0362		.0171	.0362
15	.0362		.0343	.0362		.0171	.0362
16			.0343	.0362		.0171	.0362
17	.0362		.0171	.0362		.0171	.0362
18	.0362		.0171	.0362		.0171	.0362
19	.0362		.0171	.0362		.0171	.0362
20	.0362		.0171	.0362			.0362
21	.0362		.0171	.0362			.0362
22	.0362		.0171	.0362			.0362
23	.0362		.0171	.0362			.0362
24	.0343	.0362		.0171	.0362		
Max	.0362	.0362	.0686	.0362	.0362	.0514	.0362
Min	.0343	.0362	.0171	.0171	.0362	.0171	.0362
Avg	.0355	.0362	.0343	.0350	.0362	.0280	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 206 / COLLECTOR OFFICE (EXP)
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0362			.0362		
2		.0362			.0362		
3		.0362			.0362		
4		.0362			.0362		
5		.0362			.0362		
6		.0362			.0362		
7		.0362			.0362		
8		.0362			.0362		
9	.0362		.0351	.0362		.0171	.0362
10	.0362		.0514	.0362		.0514	.0362
11	.0362		.0686	.1086		.0514	.1086
12	.0362		.0857	.1086		.0686	.1086
13	.0362		.0857	.1086		.0857	.1086
14	.0362		.0857	.1086		.0857	.1086
15	.0362		.0857	.1086		.0857	.1086
16			.0857	.1086		.0857	.1086
17	.0362		.0857	.1086		.0857	.1086
18	.0362		.0857	.0362		.0514	.0724
19	.0362		.0514	.0362		.0343	.0362
20	.0362		.0343	.0362			.0362
21	.0362		.0343	.0362			.0362
22	.0362		.0343	.0362			.0362
23	.0362		.0343	.0362			.0362
24		.0362		.0343	.0362		
Max	.0362	.0362	.0857	.1086	.0362	.0857	.1086
Min	.0362	.0362	.0343	.0343	.0362	.0171	.0362
Avg	.0362	.0362	.0629	.0678	.0362	.0639	.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 208 / Railway station Express HV Express Feeder
feeder Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543			.0543		
2		.0543			.0543		
3		.0543			.0543		
4		.0543			.0543		
5		.0543			.0543		
6		.0543			.0543		
7		.0543			.0543		
8		.0543			.0543		
9	.0543		.0514	.0543		.0514	.0543
10	.0543		.0514	.0543		.0514	.0543
11	.0543		.0514	.0543		.0514	.0543
12	.0543		.0514	.0543		.0514	.0543
13	.0543		.0514	.0543		.0514	.0543
14	.0543		.0514	.0543		.0514	
15	.0543		.0514	.0543		.0514	
16			.0514	.0543		.0514	.0543
17	.0543		.0514	.0543		.0514	.0543
18	.0543		.0514	.0543		.0514	.0543
19	.0543		.0514	.0543		.0514	.0543
20	.0543		.0514	.0543			.0543
21	.0543		.0514	.0543			.0543
22	.0543		.0514	.0543			.0543
23	.0543		.0514	.0543			.0543
24		.0543		.0514	.0543		
Max	.0543	.0543	.0514	.0543	.0543	.0514	.0543
Min	.0543	.0543	.0514	.0514	.0543	.0514	.0543
Avg	.0543	.0543	.0514	.0541	.0543	.0514	.0543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 209 / 11 KV SAMRTH NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4887			.5068		
2		.4706			.4887		
3		.4887			.5068		
4		.543			.5792		
5		.6154			.6154		
6		.6878			.6516		
7		.7602			.7059		
8		.7421			.6878		
9	.5792		.5316	.5792		.6001	.6335
10	.543		.5144	.543		.5316	.5973
11	.5249		.4801	.5068		.4801	.5611
12	.5068		.4458	.4525		.4458	.4887
13	.4887		.4458	.4706		.4458	.4163
14	.4887		.4458	.4887		.4458	.3982
15	.5068		.4458	.5068		.4287	.3801
16			.4801	.543		.4287	.4163
17	.5068		.4115	.5611		.4287	.4706
18	.543		.4287	.5973		.5144	.5249
19	.5792		.5316	.6335		.5487	.5973
20	.5792		.6344	.7059			.5792
21	.543		.6344	.6516			.543
22	.543		.583	.5973			.5068
23	.543		.5144	.5611			.4887
24		.5068		.5144	.543		
Max	.5792	.7602	.6344	.7059	.7059	.6001	.6335
Min	.4887	.4706	.4115	.4525	.4887	.4287	.3801
Avg	.5340	.5893	.5018	.5571	.5872	.4817	.5068

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 210 / 11 KV TV centre New Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1629			.1629		
2	.1715	.1629			.1629		
3	.1715	.1629			.1629		
4		.181			.181		
5		.2353			.2353		
6		.2896			.2896		
7		.3801			.3982		
8		.3801			.3801		
9	.2172		.2229	.2896		.2743	.3077
10	.1991		.1715	.2534		.2401	.2715
11	.181		.1715	.2172		.2058	.2353
12	.181		.1715	.1991		.1715	.1991
13	.1629		.1372	.181		.1886	.181
14	.1629		.1715	.181		.2058	.181
15	.1629		.1886	.1629		.2058	.1629
16			.1886	.181		.2401	.181
17	.181		.1886	.1991		.2401	.2172
18	.2172		.2229	.2353		.2401	.2534
19	.2896		.2229	.2896		.2229	.2896
20			.2572	.3439			.2534
21	.362		.2058	.2896			.2172
22	.2715		.1715	.2353			.181
23	.1991		.1715	.181			.1629
24	.1715	.181		.1715	.1629		
Max	.362	.3801	.2572	.3439	.3982	.2743	.3077
Min	.1629	.1629	.1372	.1629	.1629	.1715	.1629
Avg	.2043	.2373	.1909	.2257	.2373	.2214	.2196

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 213 / 11 KV YOGESH NAGAR
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3982			.4344		
2	.3429	.3801			.4163		
3	.3429	.3982			.4163		
4	.4287	.4525			.4887		
5	.6001	.5792			.5973		
6	.703	.7783			.7602		
7	.8916	.9231			.9231		
8	.8916	.9412			.905		
9	.8326		.6344	.7964		.6001	.7964
10	.7421		.6344	.7059		.583	.6516
11	.6516		.5144	.5792		.5487	.5249
12	.543		.3944	.4706		.5144	.5068
13	.4344		.3601	.4525		.4801	.4706
14	.4163		.3429	.4344		.463	.4525
15	.3982		.3429	.4163		.4458	.4344
16			.3601	.4525		.4287	.5249
17	.4887		.4115	.5249		.4458	.6154
18			.4287	.6516		.4801	.6697
19	.6697		.5487	.7421		.5144	.7783
20	.6335		.6516	.8326			.7059
21	.5792		.5658	.7059			.6516
22	.5068		.5144	.6335			.5792
23	.4525		.5144	.5068			.4887
24	.3772	.4163		.4115	.4525		
Max	.8916	.9412	.6516	.8326	.9231	.6001	.7964
Min	.3429	.3801	.3429	.4115	.4163	.4287	.4344
Avg	.5577	.5852	.4812	.5823	.5993	.5004	.5901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 201 / 11KV Industrial, Pole
 factory Feeder KV- 11 /
 OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
 STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4338	.415	.4527		.415	.4904
2	.3772	.4338	.3772	.4527		.415	.4904
3	.3772	.4527	.415	.4715		.415	.5093
4	.3772	.4338	.4527	.4715		.5281	.5281
5	.415	.4527	.4939	.4715		.5658	.5281
6	.4527	.4715	.547	.5281		.5847	.5658
7	.4904	.4904	.6036	.5658		.6413	.6036
8	.6036	.547		.6413	.6036	.679	
9	.7167			.7545	.6413	.7545	
10	.9054				.7545	.8299	
11	.9054		.679				
12			.679		.4904		
13	.8299		.4904			.6979	
14	.7733		.4527				.9054
15	.8488		.4527		.8299	.7545	.8865
16			.4527	.9054	.7356	.7167	.9054
17				.7167	.7733	.6036	.7922
18	.6413		.4338	.7545		.5658	.6413
19	.547		.4338	.6036		.5281	.6224
20	.5281		.415	.5281	.5847	.5281	.4527
21	.4904		.4338	.415		.4904	.415
22	.415		.4338	.415			.3961
23			.4527	.415	.415	.415	.3961
24	.415	.4338	.5658	.4527	.415	.415	.4904
Max	.9054	.547	.679	.9054	.8299	.8299	.9054
Min	.3772	.4338	.3772	.415	.415	.415	.3961
Avg	.5743	.4611	.4840	.5564	.6243	.5772	.5900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 202 / 11 KV AGRESAN FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3326	.3511	.3142		.3326	.3326
2	.4066	.3326	.3511	.3206		.3326	.3326
3	.4066	.3142	.3326	.3326		.3696	.3696
4	.4066	.3511	.3511	.3142		.4066	.4066
5	.4435	.3696	.4066	.3142		.4066	.4066
6	.4435	.4066	.4251	.3881		.4251	.462
7	.4435	.4251	.499	.4805		.4435	.499
8	.4805	.4805	.5175	.5359	.3395	.4805	
9	.5175			.4435	.3395	.4435	
10	.4435		.4435		.3772	.4435	
11	.4066		.3772				
12	.3696		.3395		.3772		
13	.3326		.3326			.3511	.3511
14	.3511		.3142				.3142
15	.2218		.2957		.3326	.3018	.3142
16			.3142	.3395	.3142	.3018	.2957
17				.3395	.3326	.3395	.3326
18	.3511		.3696	.3772		.415	.3881
19	.4251		.3881	.415		.415	.3881
20	.4435		.4066	.415	.5359	.4904	.462
21	.4435		.4435			.415	.4066
22	.4251		.3881	.3772			.3696
23			.3696	.3772	.3696	.3772	.3511
24	.3326	.3326	.3696	.3142	.3772	.3326	.3395
Max	.5175	.4805	.5175	.5359	.5359	.4904	.499
Min	.2218	.3142	.2957	.3142	.3142	.3018	.2957
Avg	.4048	.3717	.3812	.3764	.3696	.3912	.3748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 201 / RLY STN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1763	1.1763	1.1389	1.134	1.2323	
2		1.1576	1.1576	1.1203	1.0829	1.2136	
3		1.1389	1.1389	1.1203	1.0242	1.1584	
4		1.0974	1.2308	1.2136	1.2437	1.1888	
5		1.2323	1.3817	1.307	1.5684	1.307	
6		1.2437	1.4563	1.4003	1.7924	1.4563	
7		1.363	1.5684	1.5684		1.531	
8		1.5123	1.5497	1.5497		1.6651	1.4632
9	1.4632		1.39		1.5708		1.7002
10	1.3717		1.39		1.386		1.4266
11			.7316	1.2803			
12	1.1888		1.2437			1.4998	1.3535
13			1.1706		1.2803	1.2936	1.2696
14			.0905	1.1765	1.3717	1.1088	1.1827
15				1.2127	1.3717		1.1706
16				1.2127	1.3575	1.2437	1.1458
17	1.2696			1.2803		1.2803	
18	1.3306		1.39	1.2803		1.3717	
19	1.3169		1.5524	1.4632	1.587	1.3717	1.3717
20	1.2803		1.5729	1.3717	1.587	1.4632	1.2803
21	1.6095		1.5364	1.2803	1.7177	1.5546	1.2803
22	1.531		1.5684		1.8298		
23	1.2803	1.2696	1.3817	1.2437	1.4563		
24	1.1949	1.1949	1.1949	1.1576	1.2071	1.251	
Max	1.6095	1.5123	1.5729	1.5684	1.8298	1.6651	1.7002
Min	1.1888	1.0974	.0905	1.1203	1.0242	1.1088	1.1458
Avg	1.3488	1.2386	1.2797	1.2830	1.4205	1.3439	1.3313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 202 / BUS STAND

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.8462	.3734	.3734	.3696	.3734	
2		.3658	.3734	.3734	.3734	.3734	
3		.3734	.362	.5041	.3734	.362	
4		.3734	.3734	.5601	.2801	.3734	
5		.3658	.3734	.3734	.4668	.362	
6		.3734	.3734	.3734	.7468	.3734	
7		.4572	.4668	.4668		.5601	
8		.5601	.4572	.4668		.5601	.6401
9	.7316		.5487		.5544		.8402
10	.7316		.6401		.6468		.8402
11			.7316	.6401			
12	.7316		.724	.7316		.8316	.5601
13			.7316		.7316	.7392	.462
14			.7316	.724	.7316	.4668	.4668
15				.8145	.6401		.4668
16				.8145	.8145	.3734	.4668
17	.8316			.9145		.4572	.6219
18	.8316		.9145	.9145		.5487	
19	1.1203		1.2012	1.0974	1.307	1.0059	.7316
20	1.0269		1.2136	1.0059	.8402	1.1888	.7316
21			.823	1.0059	.8402	1.2803	.7316
22	.7392		.5601		.7468		
23	.5601	.4668	.3734	.4668	.5601		
24	.3658	.3734	.4668	.3734	.3734	.3734	
Max	1.1203	3.8462	1.2136	1.0974	1.307	1.2803	.8402
Min	.3658	.3658	.362	.3734	.2801	.362	.462
Avg	.7670	.7556	.6102	.6497	.6332	.5891	.6300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.5041	.5228	.5601	.5601	
2		.5228	.5041	.4938	.5121	.5228	
3		.5041	.4854	.5041	.439	.4961	
4		.3734	.3734	.5601	.5175	.5601	
5		.5975	.6348	.6348	.695	.6348	
6		.7095	.7095	.7095	.7316	.7095	
7		.7655	.8029	.6161		.8029	
8		.7842	.7682	.8029		.7655	.7316
9	.7316		.5853		.7392		.7316
10	.6219		1.3535		.7023		.7095
11				.695			
12			.5487			.5914	.6584
13			.5487	.6584	.567	.5914	.5487
14			.5487	.6335	.5487	.5853	.5853
15				.6154	.5487		.5121
16				.6154	.5792	.5487	.4755
17	.6283			.6584		.6401	.5304
18	.6653		.6348	.695		.695	
19	.8871		.7842	.7499	.7842	.7316	.5853
20	.8501		.8413	.7316	.8775	.7682	.5487
21	.7762		.7392	.695	.8029	.7865	.5487
22	.6653		.6653		.7095		
23	.6161	.567	.5975	.5853	.6348		
24	.5601	.5788	.5415	.5415	.5487	.5788	
Max	.8871	.7842	1.3535	.8029	.8775	.8029	.7316
Min	.5601	.3734	.3734	.4938	.439	.4961	.4755
Avg	.7002	.5963	.6586	.6359	.6388	.6427	.5972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 204 / 11KV PWW FEEDER

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0934	.0934	.0934	.0934	
2		.0934	.0914	.0934	.0914	.0905	
3		.0934	.0934	.0934	.0934	.0934	
4		.0914	.0914	.0934	.0934	.0934	
5		.0934	.0914	.0934	.0914	.0934	
6		.0934	.0934	.0934	.0924	.0934	
7		.0934	.0934	.0934		.0934	
8		.0934	.0914	.0934		.0905	.0914
9	.0914		.0914		.0924		.0934
10	.0914		.0914		.0924		.0924
11			.0914	.0914			
12	.0914		.0905	.0914		.0934	.0934
13			.0905		.0914	.0934	.0934
14			.0905	.0905	.0914	.0934	.0934
15				.0905	.0914		.0934
16				.0905	.0905	.0934	.0914
17	.0914			.0914		.0914	.0914
18	.0934		.0934	.0914		.0914	
19	.0924		.0924	.0914	.0934	.0914	.0914
20	.0934		.0934	.0914	.0934	.0914	.0914
21	.0914		.0914	.0914	.0934	.0914	.0914
22	.0934		.0924		.0934		
23	.0938	.0934	.0905	.0934	.0934		
24	.0934	.0934	.0934	.0934	.0934	.0934	
Max	.0938	.0934	.0934	.0934	.0934	.0934	.0934
Min	.0914	.0914	.0905	.0905	.0905	.0905	.0914
Avg	.0924	.0932	.0920	.0923	.0925	.0925	.0923

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 205 / JINDAL COMPLEX INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0934	.0934	.0914	.0914	
2		.0934	.0934	.0934	.0934	.0934	
3		.0934	.0886	.0934	.0934	.0914	
4		.0934	.0934	.0934	.0914	.0914	
5		.0934	.0934	.0934	.0934	.0934	
6		.0934	.0934	.0934	.0934	.0934	
7		.0914	.0934	.0934		.0934	
8		.0934	.0934	.0938		.0934	.0914
9	.0914		.0914		.0924		.0934
10	.0914		.0914		.0924		.0934
11			.0914	.0914			
12	.0914					.0924	.0914
13			.0905		.0914	.0914	.0914
14			.0905	.0905	.0914		.0914
15				.0905	.0914		
16				.0905	.0905	1.2567	
17	.0924			.0914		.0914	
18	.0905		.0924	.0914		.0914	
19	.0934		.0934	.0914	.0934	.0914	
20	.0934		.0924	.0914	.0934	.0914	
21	.0914		.0914	.0914	.0934	.0914	
22	.0924		.0914		.0934		
23	.0934	.0934	.0934	.0914	.0934		
24	.0914	.0934	.0905	.0934	.0934	.0934	
Max	.0934	.0934	.0934	.0938	.0934	1.2567	.0934
Min	.0905	.0914	.0886	.0905	.0905	.0914	.0914
Avg	.0920	.0932	.0921	.0922	.0926	.1607	.0921

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8962	.8779	.8779	.7762	.8688	
2		.8775		.8775	.695	.8596	
3		.8962	.8962	.8962	.7468	.8589	
4		.9335	.8869	1.0269	.8871	1.0642	
5		1.0642	1.1203	1.1203	.9979	1.1576	
6		1.2696	1.3443	1.2696	1.2696	1.363	
7		1.4563	1.6244			1.4937	
8		1.5684	1.7177	1.6244		1.5684	1.2803
9	1.4632		1.4632		1.3676		1.4784
10	1.3717		1.3535		1.2567		1.6057
11			1.1888	1.0974			
12			.9145			1.1088	1.3676
13			.9511	.9145	.9694	.9979	1.1706
14			.9877	.8688	.9145		1.1088
15				.8326	.8413		1.0242
16				.8688	.905	1.1576	.8131
17	1.2936			.9877		1.1888	
18	1.3676		1.2071	1.0608		1.2803	
19	1.4045		1.3817	1.262	1.3443	1.39	1.2986
20	1.3676		1.3817	1.3535	1.4003	1.4632	1.2437
21	1.3306		1.3306	1.2803	1.251	1.5364	1.1706
22	1.2567		1.1576		1.1203		
23	1.1203	1.1203	1.0082	1.1458	1.0829		
24	.8779	.9149	.8962	.9149	.8215	.9149	
Max	1.4632	1.5684	1.7177	1.6244	1.4003	1.5684	1.6057
Min	.8779	.8775	.8779	.8326	.695	.8589	.8131
Avg	1.2854	1.0997	1.1845	1.0674	1.0360	1.1925	1.2329

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 207 / NARIMAN NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4294	.3174	.2896	.2957	.3292	
2		.4024	.3174	.2801	.2614	.3361	
3		.3921	.2987	.2801	.2241	.2926	
4		.3658	.3734	.2987	.2987	.3174	
5		.3734	.4108	.3174	.4435	.3734	
6		.3734	.4481	.4108	.5415	.4294	
7		.3921	.5041	.4854		.4854	
8		.4854	.5041	.5041		.5041	.4572
9	.4024		.4755		.462		.5175
10	.0914		.4755		.4066		.462
11			.439	.4207			
12	.4207		.4163			.4251	.4066
13			.3801		.3841	.3881	.439
14			.3439	.3801	.3658	.4108	.4207
15				.362	.3841		.3881
16				.3982	.3982	.3361	.3292
17	.037			.3841		.3475	
18	.462		.4294	.3841		.3475	
19	.4572		.462	.439	.1307	.4207	.4024
20			.499	.4938	.4668	.439	.4024
21	.439		.4251	.4755	.4481	.5487	.3658
22	.3881		.4066		.4294		
23	.4207	.3547	.3361	.3881	.3734		
24	.3292	.4481	.3361	.3174	.3326	.3547	
Max	.462	.4854	.5041	.5041	.5415	.5487	.5175
Min	.037	.3547	.2987	.2801	.1307	.2926	.3292
Avg	.3448	.4017	.4095	.3847	.3693	.3937	.4174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 208 / TULJABHWANI NAGAR FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747	.0747	.0732	.0934	.0914	
2		.0732	.0732	.0747	.0914	.0747	
3		.0747	.0747	.0747	.0732	.0747	
4		.0747	.0747	.0732	.1294	.0747	
5		.0747	.0934	.0934	.1463	.0934	
6		.0934	.0934	.112	.1646	.112	
7		.112	.112	.1307		.1307	
8		.112	.1307	.1494		.112	.1097
9	.0914		.1063		.1109		.0914
10	.0914		.1097		.1109		.0934
11			.1097	.0732			
12	.0914		.1086			.1097	.1109
13			.0905		.128	.0924	.0914
14			.0724	.1086	.1097	.0924	.0914
15				.1086	.1097		.0914
16				.1086	.1448	.0924	.0914
17	.1109			.128		.0914	
18	.1294		.1097	.128		.0914	
19	.1294		.128	.1463	.1307	.1463	.0914
20	.1478		.128	.128	.1494		.0914
21	.1294		.1307	.128	.1307	.1646	.0914
22	.1097		.1109		.1307		
23	.0934	.0747	.0934	.1097	.112		
24	.0914	.0747	.0747	.0747	.0914	.0934	
Max	.1478	.112	.1307	.1494	.1646	.1646	.1109
Min	.0914	.0732	.0724	.0732	.0732	.0747	.0914
Avg	.1105	.0839	.1	.1065	.1198	.1022	.0950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 209 / 11 KV SAMBHAJI NAGAR8

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8962	.8775	.8589	.9709	.9335	
2		.8775	.8589	.8402	.8962	.9149	
3		.8589	.8402	.9149	.8215	.8962	
4		.9335	1.0082	1.0082	1.0456	1.0082	
5		1.1016	1.1203	1.1576	1.1827	1.1203	
6		1.2883	1.2308	1.307	1.3443	1.1763	
7		1.4377	1.419	1.4003		1.251	
8		1.4563	1.4377	1.475			1.262
9	1.39		1.2803		1.3676		1.4937
10	1.3535		1.2071		1.2752		1.419
11			1.0974	1.0974			
12			1.0242			1.1827	1.2803
13			.9877	.9145	.9511	1.1827	1.2696
14			.9328	.905	.9511	1.1088	1.0829
15				.9412			1.0456
16				1.0242	.9694	1.0082	1.0829
17	1.2323			.9922	1.0498	1.0974	
18	1.2567		1.2567	1.0425		1.2437	
19	1.4415		1.3306	1.2437	1.4377	1.3535	1.3535
20	1.4045		1.4563	1.39	1.419	1.39	1.1706
21	1.2936		1.3169	1.2986	1.3443	1.4449	1.0974
22	1.2803		1.1088		1.2323		
23	1.1203	1.0791	1.0082	1.1827	1.1016		
24	.9335	.9149	.9149	.8775	1.0456	.9522	
Max	1.4415	1.4563	1.4563	1.475	1.4377	1.4449	1.4937
Min	.9335	.8589	.8402	.8402	.8215	.8962	1.0456
Avg	1.2706	1.0844	1.1293	1.0936	1.1337	1.1332	1.2325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 201 / 11 kv Sarswati Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.543	.543	.543	.5611	.5792	.543
2	.5068	.5068	.543	.543	.543	.543	.5068
3	.4887	.4887	.5068	.5249	.5068	.543	.5249
4	.6335	.5792	.5973	.5792	.6335	.543	.6335
5	.7421	.6697	.6878	.6697	.724	.6516	.8326
6	.8507	.724	.7964	.7602	.8326	.8326	.9774
7	.9593	.8326	.9412	.9955	.9774	.9231	1.0317
8	1.0317	.9231	1.0136	.9593	1.0136	.9412	1.0498
9	.8145		.905	.9231		.9593	.905
10	.7059				.7602	.7783	.8326
11	.5973		.6516		.6335		
12	.5611		.6335	.6154	.6516	.6335	
13	.4887		.543	.5068	.5792	.6154	.5611
14	.5068		.4887	.5611	.543	.5611	.543
15	.5249		.5249	.4887	.6335	.6335	.5068
16	.5792		.543	.543	.5792	.6516	.5792
17	.6335			.5792		.6335	.6697
18	.6697		.5611	.6516		.7059	.724
19	.8507	.7964	.7421	.7783	.7783		
20	.7783	.9593	.8145	.8688	.8145	.7421	.8869
21	.724	.8145	.7421	.8145	.7602		.7059
22	.6878	.6878	.6697	.6878	.7059		.6697
23	.6154	.5792	.5973	.6335	.6335	.6154	.6154
24	.5611	.5792	.5611	.5611	.5973	.5792	.5792
Max	1.0317	.9593	1.0136	.9955	1.0136	.9593	1.0498
Min	.4887	.4887	.4887	.4887	.5068	.543	.5068
Avg	.6689	.6917	.6639	.6722	.6887	.6833	.7085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134036 / 33/11 KV Rohanwadi

Substaion

Feeder No / Name : 202 / 11 KV Bholeshwar Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.2382	1.1458	1.2382	1.1827	1.1827	1.1458
2	1.0719	1.2197	1.1088	1.2012	1.2012	1.1827	1.1088
3	1.1458	1.2012	1.1088	1.2012	1.2382	1.1643	1.1458
4	1.2382	1.2567	1.2567	1.2382	1.2752	1.2012	1.2382
5	1.3306	1.3676	1.4784	1.2936	1.3121	1.2567	1.46
6	1.46	1.6263	1.6632	1.6263	1.7002	1.386	1.7187
7	1.8111	1.9035	1.8665	2.0328	1.922	1.7741	2.0698
8	1.9959	1.9589	1.9035	2.0883	2.0883	1.885	2.2361
9	1.9774		1.7741	1.922		1.848	1.9959
10	1.5893				1.6263	1.6632	1.7002
11	1.6263		1.4784		1.5708		
12	1.4969		1.3676	1.4415	1.3121		
13	1.386		1.2936	1.1827	1.2012	1.2936	1.46
14	1.2936		1.1584	1.1643	1.1827	1.1458	1.3491
15	1.2567		1.0903	1.1458	1.1827	1.2936	1.2567
16	1.423		1.3032	1.1088	1.2936	1.3491	1.3306
17	1.6078	1.5524		1.2012		1.46	1.5339
18	1.7372	1.6448	1.5565	1.6448		1.848	1.7187
19	1.7926	1.7372	1.7926	1.848	1.848		
20	1.7187	1.7556	1.8665	1.922	1.8665	1.9035	1.885
21	1.6448	1.6263	1.7002	1.7372	1.5893	1.7926	1.6263
22	1.4784	1.4045	1.5524	1.5708	1.4969	1.5708	1.4415
23	1.3213	1.2936	1.3491	1.2567	1.3306	1.3676	1.3306
24	1.2012	1.2567	1.2012	1.2382	1.1827	1.1827	1.1827
Max	1.9959	1.9589	1.9035	2.0883	2.0883	1.9035	2.2361
Min	1.0719	1.2012	1.0903	1.1088	1.1827	1.1458	1.1088
Avg	1.4881	1.5027	1.4553	1.4684	1.4573	1.4643	1.5207

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 201 / 11 KV Gokulnagari feeder Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.483	.5185	1.4784	.482	.5201	.4825
2			.4815	1.419	.482		.4815
3			.4815	1.4937	.482		.4815
4		.483	.4815	1.4937	.482		.4815
5		.5573	.5556	1.5684	.5932	.5573	.5185
6		.6316	.7778	.7762	.8157	.5944	.7778
7		.8359	.7778	.8871	.8713	.8545	.7407
8		.8545	.8148	.8131	.8157		.5185
9	.743		.8048				
10	.7059		.8048				
11	.6316		.8871		.5944		
12	.5944		.5487	.4264	.483		.5487
13	.5944		.5487	.5561	.4458		.5487
14	.5015		.5487	.6117		.6667	.4755
15	.483		.5487	.5561	.3901	.6667	.5121
16	.5201		.5121	.5191	.4087	.6296	.4755
17	.5573			.5191	.4458	.4815	.4805
18	.5944		.6283	.5191		.6667	.5914
19	.6501		.5914	.6303	.7059		.6653
20	.7802		.7762	.7971	.7988	.7778	.7762
21	.7245	.963	.7023		.7453	.7407	.7023
22	.6708	.7778	.6219	.6303	.7059	.7052	.6219
23		.5926	.5853	.5747		.5926	.5487
24		.5201	.5556	.5853	.5191	.5573	.5556
Max	.7802	.963	.8871	1.5684	.8713	.8545	.7778
Min	.483	.483	.4815	.4264	.3901	.4815	.4755
Avg	.6251	.6699	.6328	.8427	.5930	.6437	.5707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 202 / 11 KV Dukhi Nagar Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3746	1.4103		1.3375	1.3003	1.3704
2			1.3732		1.3375		1.3333
3			1.3732		1.3347		1.3333
4		1.4489	1.3732		1.3375		1.3333
5		1.5604	1.4845		1.4861	1.3746	1.4444
6		1.6718	1.7072	1.6975	1.6718	1.5604	1.7407
7		1.8576	2.0041	2.1125	2.0248	1.9504	2.0783
8		2.0433	2.2268	2.2634	2.1504		2.3753
9	2.0062		2.2405				
10	1.8204		2.2405				
11	1.6718		2.3388		1.6718		
12	1.7461		1.9418	1.4861	1.6161		1.9044
13	1.709		1.8671	1.4489	1.5604		1.8861
14	1.6718		1.4937	1.4303		2.1897	1.7551
15	1.5604		1.531	1.4303	1.5232	1.9299	1.643
16	1.709		1.531	1.4118	1.5232	1.7814	1.5684
17				1.5604	1.5604	1.8557	1.531
18	1.8576		2.1502	1.7833		2.0412	1.8107
19	2.0248		1.9616	1.9319	2.0433		1.9616
20	2.1548		1.9993	2.1176	2.1362	1.8186	2.0748
21	1.8947	2.4495	1.9616		1.8761	1.8186	2.1125
22	1.839	1.8928	1.8671	1.6718	1.7461	1.6701	1.8671
23		1.5216	1.5684	1.5046		1.5588	1.4937
24		1.3746	1.4474	1.4937	1.3746	1.3375	1.4444
Max	2.1548	2.4495	2.3388	2.2634	2.1504	2.1897	2.3753
Min	1.5604	1.3746	1.3732	1.4118	1.3347	1.3003	1.3333
Avg	1.8204	1.7195	1.7866	1.6896	1.6480	1.7277	1.7172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion

Feeder No / Name : 203 / 11 KV BACHAT BHAVAN FEEDER Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1672	.1852	.1791	.1854	.1672	.1852
2			.1852	.1791	.1854		.1852
3			.1852	.2149	.1854		.1852
4		.1858	.2227	.2507	.1854		.1852
5		.2043	.2598	.2507	.2225	.1858	.2222
6		.2415	.2963	.2507	.2966	.2229	.2593
7		.2415	.2963	.2865	.3151	.3158	.2593
8		.2229	.3333	.3224	.2966		.3333
9	.2972		.3224				
10	.2786						
11	.2415		.3224		.2229		
12	.2415		.2865	.2595	.2229		.2507
13	.2229		.2507	.2225	.2043		.2149
14	.1672		.2507	.2039		.2963	.2172
15	.1858		.2507	.2039	.2043	.2593	.2149
16	.1858		.2561	.2225	.2043	.2222	.2149
17				.2225	.2043	.2593	.2149
18	.1858		.2534	.241		.2222	.2149
19	.2229		.2149	.2595	.2601		.2507
20	.2972		.2865	.3151	.2972	.2222	.2865
21	.2786		.2865		.2972	.2593	.2507
22	.2601	.2963	.2507	.241	.2786	.2598	.2507
23		.2593	.2149	.241		.1852	.1791
24		.1858	.1852	.1791	.1854	.1858	.1852
Max	.2972	.2963	.3333	.3224	.3151	.3158	.3333
Min	.1672	.1672	.1852	.1791	.1854	.1672	.1791
Avg	.2358	.2227	.2543	.2373	.2344	.2331	.2267

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION

Feeder No / Name : 201 / NER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17
HR	Load (MW)
23	1.7737
Max	1.7737
Min	1.7737
Avg	1.7737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 202 / RAMNAGAR

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1334	.1715
2		.1715	.1524	.1715
3		.1715	.1524	.2058
4		.2058	.1334	.2401
5		.2401	.2667	.2572
6		.2401	.2667	.2915
7		.2401	.2667	.4287
8			.4001	
9			.4001	.4287
17	.1715			
24		.1715	.1524	.1715
Max	.1715	.2401	.4001	.4287
Min	.1715	.1715	.1334	.1715
Avg	.1715	.2015	.2324	.2629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 203 / EX-D'RAJA HV Non-Express Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3048	
2					.3048	
3					.3125	
4					.3048	.1543
5		.1715			.3048	.1543
6		.1715			.3048	.1543
7		.1715			.3048	.1543
8						.1543
9						.1543
16					.1715	
17	.1715				.1543	
18	.1715			.3048	.1715	
19	.1715			.3048	.1543	
20	.1715			.3048	.1715	
21	.1715			.3048	.1029	
22	.1715		.1715	.3048	.1543	
23	.1715			.3048	.1543	
24	.1524		.3048		.3048	
Max	.1715	.1715	.3048	.3048	.3125	.1543
Min	.1524	.1715	.1715	.3048	.1029	.1543
Avg	.1691	.1715	.2382	.3048	.2300	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 205 / BHATEPURI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144			.5144	.3048	.5144
2		.5144			.5144	.381	
3		.9774			.6859	.381	.8916
4		1.0288			.8059	.381	1.0288
5		1.2346			.8573	.6097	1.0631
6		1.2174			.9602	.7621	1.0802
7		1.0288		1.0669	.9431	.7621	1.046
8					.8745	.7621	1.0288
9						.7621	.9602
10						.7716	
11						.5144	
12						.5144	
14						.703	
15						.703	
16						.6687	
17	.5144				.381	.703	
18	.5658				.381	.5487	
19	.823				.381	.5487	
20	1.286				.5335	.5487	
21	.6687				.5335	.5144	
22	.6001				.5335	.3429	
23	.5487			.5144	.381	.5144	
24	.4572		.4572	.4572	.5144	.381	.5144
Max	1.286	1.2346	.4572	1.0669	.9602	.7716	1.0802
Min	.4572	.5144	.4572	.4572	.381	.3048	.5144
Avg	.6830	.9308	.4572	.6795	.6122	.5688	.9031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 206 / RAMNAGAR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.7621	.6859	.6097	.7202
2		.6859		.7202	.6097	
3		.6859		.8059	.6097	1.0288
4				.9774	.6401	1.1145
5		1.4575		1.2003	.7621	
6		1.5432		1.7661	.7621	1.5775
7		1.2346	1.0669	1.7318	.7621	1.5432
8				1.5432	.9145	1.5432
9					.9145	1.4403
10					1.0288	
11					1.0974	
12					1.0288	
13					1.0974	
14					1.0288	
15					1.0288	
16					1.1145	
17	.8573			.9145	1.0631	
18	1.046			.9145	1.0631	
19	1.166			1.0669	1.0974	
20	.8573			1.0669	1.0288	
21	.8002			.9145	1.0288	
22	1.1145		1.0288	.7621	.8916	
23	.8573		.8573	.6097	.8573	
24	.6097		.7621	.6859	.6097	.5144
Max	1.166	1.5432	1.0669	1.7661	1.1145	1.5775
Min	.6097	.5144	.7621	.6097	.6097	.5144
Avg	.9135	1.0203	.8954	1.0229	.9020	1.1853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 207 / Bajiumrad Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6859	.2667	.3429
2			.7716	.4268	.5487
3			.823	.4268	.3772
4			.8573	.3048	.4287
5			.8916	.4572	.5144
6			.9088	.5335	.7373
7		.4572	.9259	.5335	1.1145
8				.6668	1.0288
9				.6668	1.0631
17	.6687				
24		.3048	.5144	.3048	.3429
Max	.6687	.4572	.9259	.6668	1.1145
Min	.6687	.3048	.5144	.2667	.3429
Avg	.6687	.381	.7973	.4588	.6499

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 209 / SALEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1715	
2		.1715	
3		.1715	
4		.1715	
5		.1715	
6		.1715	
7		.1715	
14			.12
15			.2058
16			.2058
17			.2401
18			.2401
24	.1524	.1715	
Max	.1524	.1715	.2401
Min	.1524	.1715	.12
Avg	.1524	.1715	.2024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 201 / SAMANGAON+KAJALA

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
9	.1219
Max	.1219
Min	.1219
Avg	.1219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3048	.3048	.3048	.3048	.381	.3048
2	.3048	.3048	.3048	.3048	.3048	.381	.3048
3	.381	.3048	.3048	.3048	.3353	.381	.3048
4	.381	.3506	.381	.381	.3658	.4268	.381
5	.4572	.381	.4268	.4877	.381	.4572	.4572
6	.5335	.4572	.4877	.4572	.4572	.5335	.5335
7	.6097	.5335	.5335	.5335	.5335	.5335	.6097
8	.5335		.4877	.4572		.5335	.5335
9	.4572		.5335	.4572		.5792	.4572
10	.381		.4877	.381			.5335
11	.3506		.4572	.3506	.5792		.5335
12	.381		.4572	.381	.6097		.4572
13	.3506		.4572	.3658			.4572
14	.3048		.4572	.5335			.4268
15	.3048		.5335	.4572	.5335		.4572
16	.3353			.4877	.4877	.4572	.5335
17	.3048			.5335	.5335	.4877	.6097
18	.381		.6097	.4572		.5335	.5335
19	.4572		.6859	.5335	.5335	.6097	
20	.381	.4268	.6097	.5335	.5335	.5335	.5335
21	.3506	.4268	.4572	.4572	.4572	.4572	.4572
22	.3048	.4115	.381	.4268	.381	.381	.381
23	.3048	.381	.3353	.3048	.381	.381	.3048
24	.3048	.3048		.3048	.3048		.3353
Max	.6097	.5335	.6859	.5335	.6097	.6097	.6097
Min	.3048	.3048	.3048	.3048	.3048	.381	.3048
Avg	.3817	.3823	.4616	.4248	.4454	.4734	.4539

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 205 / mali pimpalgaon

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.381	.381		.381	.381	.3048
2	.3353		.381	.3048	.381	.381	.3048
3	.381	.381	.381	.3048	.381	.381	.3353
4	.4572	.5335	.4572	.381	.4572	.4572	.381
5	.4572	.6859	.6859	.4572	.6859	.6097	.4572
6	.6097	.9145	.884	.6097	.9145	.6859	.6097
7	.9145	.9907	1.1431	.7621	.9907	.884	.7621
8	.7621		1.2193	.6097		1.0974	.6097
9	.6097		1.0364	.5335		1.1888	.6097
10	.4572		.7621	.4572			.5335
11	.381		.6097	.381	.6097		.4572
12	.3353		.4572	.381	.5335		.381
13			.4572	.3353			.3048
14	.381		.4572	.3048			.3048
15	.3048		.4572	.3048	.381		.381
16	.3353		.4572	.3048	.3353	.4572	.4268
17	.381			.3048	.381	.5487	.4572
18	.5335		.5335	.4572		.6097	.5335
19	.8383		.6859	.8383	.6401	.7621	
20	.9145	.884	.6097	.9145	.884	.6097	.8383
21	.7621	.7164	.4572	.7621	.6097	.4572	.7621
22	.5335	.5335	.381	.5335	.5335	.381	.5335
23	.381	.381	.3048	.4572	.381	.3353	.381
24	.381	.381		.3048	.381		.3048
Max	.9145	.9907	1.2193	.9145	.9907	1.1888	.8383
Min	.3048	.381	.3048	.3048	.3353	.3353	.3048
Avg	.5122	.6166	.5999	.4784	.5478	.6016	.4771

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 207 / ROHANWDI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3048	.3048	.2743	.2743	.2591	.2743
2	.2743	.3048	.3048	.2743	.2743	.2591	.2743
3	.2743	.3048	.3048	.2743	.3048	.2743	.3048
4	.3048	.3353	.3353	.3048	.381	.3048	.3048
5	.3353	.381	.381	.3353	.4572	.381	.381
6	.4572	.4268	.503	.4572	.503	.4877	.4268
7	.5487	.4115	.4877	.5182	.4877	.4268	.4572
8	.4572		.3201	.4725		.5182	.4268
9	.4115		.3353	.3963		.4115	.3353
10	.3201		.2439	.3048			.3353
11	.2896		.2286	.2743	.2286		.3048
12	.2286		.2439	.2286	.2286		.2439
13	.2286		.1524	.2439			.2134
14	.1981		.2286	.2286			.2591
15			.1524	.1829	.1829		.2743
16	.2439			.1981	.2134	.2743	
17	.3353			.2591	.2743	.2896	.3048
18	.3506		.2286	.2896			.3506
19	.3506		.3048	.3506	.3506	.4268	
20	.3048	.3963	.4572	.4268	.503	.381	.3963
21	.3506	.381	.381	.3658	.381	.3353	.381
22	.3506	.3048	.3353	.3048	.3353	.3048	.3506
23	.3353	.3048	.3048	.2896	.2591	.2743	.3201
24	.3048	.3048		.2896	.2743		.3048
Max	.5487	.4268	.503	.5182	.503	.5182	.4572
Min	.1981	.3048	.1524	.1829	.1829	.2591	.2134
Avg	.3274	.3467	.3113	.3143	.3285	.3505	.3284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 201 / PIMPRI D - AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2096		.2915	.2858
2		.2058	.4191		.2915	.2096
3		.2058	.2096		.2915	.2096
4		.2058	.2096		.3429	.2286
5		.2572	.2096		.5144	.4763
6		.4287	.2096		.8573	.4763
7		.4287	.2096	.8573	.8573	.2858
8			.4763	.8573	.7716	.4763
9			1.105	1.0117	.7716	.2286
15	.4287					
16	.4287					
24		.2058	.2096		.2572	.4191
Max	.4287	.4287	1.105	1.0117	.8573	.4763
Min	.4287	.2058	.2096	.8573	.2572	.2096
Avg	.4287	.2680	.3468	.9088	.5247	.3296

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 202 / HIVRAROSHANGAON-AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194		.2743	1.0479		.3429	.4763
2	1.2955		.2743	.8573		.3429	.4763
3	1.4289		.2743	.6668		.3429	.6668
4	1.5242		.2743	.6668		.3429	1.0479
5	1.5242		.2743	.6668	.6001	.4287	1.2384
6	1.5242		.2743	.6668		.6859	1.1431
7	1.5242		.2743	.6668	.6001	.6859	1.4289
8	1.5242			.6668	.6001	.5487	1.1431
9	1.5242	.8573		.6668	.5144	.5487	1.0479
10	1.0479	.4801				.724	
11		.2572		1.1203	1.1145	1.105	
12		.2058			1.0288	1.0479	
13		.2743			1.0288	1.0479	
14		.2743			.2058	.6668	
15		.3429			.2058	1.0479	
16		.3429			1.0288	1.0479	
17					1.0288	1.0479	
18					.4287	1.105	
19					.6001	.6668	
20		.7716			.6001	.6668	
21		.6001			.6001	.6668	
22		.4287			.4287	.6668	
23		.4287			.4287	.6668	
24				1.0479		.3429	.2096
Max	1.6194	.8573	.2743	1.1203	1.1145	1.105	1.4289
Min	1.0479	.2058	.2743	.6668	.2058	.3429	.2096
Avg	1.4537	.4387	.2743	.7946	.6496	.6994	.8878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 204 / BAPKAL AG Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.2096		.1715	.2096
2		.1372	.2096		.1715	.2096
3		.1372	.2096		.1715	.2096
4		.1372	.2096		.1715	.2096
5		.1372	.2096		.2401	.2096
6		.2743	.2096		.2401	.2096
7		.1715	.2286	.3429	.2401	.4191
8			.4191	.4287	.2401	.4763
9			.4763	.4287	.2401	.4191
12	.1372					
13	.1372					
14	.1372					
15	.1372					
16	.1715					
24		.1372	.2096		.2572	.2096
Max	.1715	.2743	.4763	.4287	.2572	.4763
Min	.1372	.1372	.2096	.3429	.1715	.2096
Avg	.1441	.1586	.2591	.4001	.2144	.2782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 205 / PIMPRI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286		.2058	.2096	.2241	.2058	.4763
2	.2286		.2058	.2096	.2614	.2058	
3	.2858		.2058	.2096	.3734	.2058	
4	.2858		.2743	.2096	.3734	.2743	.4763
5	.4763		.3429	.4763	.4108	.3086	.4763
6	.4763		.4287	.4763	.4668		.4763
7	.4763		.4287	.4763	.4287		.4763
8	.4763			.4763	.3772	.3429	.4763
9	.4763			.4763	.3429	.4801	.4763
10	.2858				.1886		
11				.2614	.1372		
12				.1867	.1372		
13				.0934	.12		
14				.0934	.12		
15		.12		.0934	.1372		
16		.12		.112	.1372		
17		.1715		.1307	.1715		
18		.3429		.1867	.2401		
19		.3772		.2614	.2915	.4763	
20		.4287		.2987	.3086	.4763	
21		.2572		.2801	.2743	.4763	
22		.2572			.2401	.2286	
23		.2058		.2614		.2286	
24			.2058	.2096	.2241	.2058	.2286
Max	.4763	.4287	.4287	.4763	.4668	.4801	.4763
Min	.2286	.12	.2058	.0934	.12	.2058	.2286
Avg	.3696	.2534	.2872	.2586	.2603	.3166	.4453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON

Feeder No / Name : 206 / SOLGAVAN AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17
HR	Load (MW)
11	.3429
12	.3429
13	.3429
14	.3429
15	.3429
16	.3429
17	.3429
Max	.3429
Min	.3429
Avg	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 201 / HISWAN-AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486					.1619	.2429
2	.0486					.1619	.2429
3	.0486					.1619	.2429
4						.3239	.2915
5						.4049	.2915
6						.4858	.3239
7						.4858	.4049
8				.1619		.4049	.4372
9				.4858		.3239	.4372
12	.4858						
13	.3239						
14	.1619						
18						.0486	
19	.0486	.0486		.0486	.0648	.0486	.0972
20	.0486				.0486	.0486	.0486
21	.0486				.0486	.0486	.0486
22	.0486				.0486	.0486	.0486
23	.0486				.0486	.0486	.0486
24	.0486		.081		.2267	.081	.2429
Max	.4858	.0486	.081	.4858	.2267	.4858	.4372
Min	.0486	.0486	.081	.0486	.0486	.0486	.0486
Avg	.1174	.0486	.081	.2321	.0810	.2055	.2300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 202 / TANDULWADI AG FEEDER
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619			.1619		.4049	.5668
2	.1619			.1619		.4049	.5668
3	.1619			.1619		.4858	.5668
4				.1619		.4858	.6478
5				.2429		.5668	.6964
6				.3239		.6478	.7611
7				.4049		.8097	.8097
8				.4049		.8097	.8745
9				.4858		.8097	.9717
15	.1619						
16	.1619	1.6032					
17	.081						
19	.0486	.0648	.081		.2429	.1619	.2429
20	.1619	.0162		.1619	.2429	.1619	.2429
21	.081		.081		.2429	.1619	.2429
22	.1619		.081		.1619	.1619	.2429
23	.081		.081		.2429	.1619	.2429
24	.421			.1619	.3887	.3239	.5506
Max	.421	1.6032	.081	.4858	.3887	.8097	.9717
Min	.0486	.0162	.081	.1619	.1619	.1619	.2429
Avg	.1538	.5614	.081	.2576	.2537	.4372	.5484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 203 / PUNEGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429		.1619		.3239	.1619
2	.2429		.1619		.3239	.1619
3	.2429		.1619		.3239	.1619
4	.2429					
5	.3239					
6	.3239					
7	.4049					
8	.4049					
9	.4858					
10					.3239	.1619
11				.8097	.4049	
12					.4858	
13		.4858			.583	
14		.4858			.5668	
15		.3239			.5344	
16		.4049			.5182	
17		.4858			.4858	
19	.1619	.081	.3239	.2429	.1619	.3239
20	.1619			.2429	.1619	.3239
21	.1619	.2429		.2429	.1619	.3239
22	.1619			.2429	.1619	.2429
23	.1619			.2429	.1619	.2915
24	.1619		.1619	.2429	.2429	.1619
Max	.4858	.4858	.3239	.8097	.583	.3239
Min	.1619	.081	.1619	.2429	.1619	.1619
Avg	.2591	.3586	.1943	.3239	.3486	.2316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 205 / PUNEGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.4858	.4858		.4049	.3239
2	.4049	.4858	.4858		.4049	.3239
3	.4049	.4858	.4858		.4049	.3239
4	.4049	.4858	.5668		.4049	.3239
5	.4858	.6478	.5668		.3239	.4049
6	.4858	.6478	.4858		.3239	.4049
7	.4049	.4858	.3239	.2591	.3239	.3563
8	.4049	.3239	.3239	.2591	.3239	.3239
9	.4858	.2591	.3239	.2267	.4049	.2753
10		.2429		.2267		
11	.2429	.2429	.2105	.1619	.3239	
12	.2429	.2429	.1619	.2429	.3239	
13	.2429	.2429	.2267	.2429	.3563	
14	.2429	.1619	.2105	.2429	.3563	
15	.2429	.1619			.3401	
16	.2429		.2753		.3401	
17	.3239	.2429			.4372	
18	.3239	.3239	.3725			.2429
19	.4858	.3239	.4858	.5668	.4049	
20	.5668			.5668	.4049	.4858
21	.4858	.4858		.5668	.4049	.4049
22	.4858	.4858		.4049	.4049	.4049
23	.4049	.4858		.4858	.421	.4049
24	.3239		.3239	.4372	.4858	.421
Max	.5668	.6478	.5668	.5668	.4858	.4858
Min	.2429	.1619	.1619	.1619	.3239	.2429
Avg	.3802	.3786	.3715	.3493	.3784	.3617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 206 / GADE SAWARGAON

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1134		.081	.1134	.081	.1134
2	.1134		.081	.1134	.081	.1134
3	.1134		.081	.1134	.081	.1134
10		.3239		.2429	.2429	
11	.3239	.3239	.3239	.2429	.2429	
12	.3239	.3239	.3239	.2429	.2429	
13	.2429	.3239	.3077	.4049	.2915	
14	.2429	.3239	.3401	.4049	.2915	
15	.2429	.2429			.2753	
16	.2429	.2429	.2753		.2753	.3239
17	.2429	.2429			.3239	.3239
19	.081	.0648	.0648	.081	.1134	.081
20	.081			.081	.1134	.081
21	.081	.081		.081	.1134	.081
22	.081			.081	.1134	.081
23	.081	.081		.081	.1134	.081
24	.1134		.081	.1134	.081	.1134
Max	.3239	.3239	.3401	.4049	.3239	.3239
Min	.081	.0648	.0648	.081	.081	.081
Avg	.1701	.2341	.1960	.1712	.1810	.1369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 201 / DHALDI - AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5735	.5647	.5144	.5144	.5144	.4973	.4915
2	.5668	.5641	.5144	.5144	.503	.4858	.4858
3	.5801	.4973	.5144	.5144	.5144	.4687	.4858
4	.5735	.5535	.5144	.6859	.6478	.4687	.5735
5	.6401	.5201	.6859	.8573	.8697	.5401	
6	.8697	.5201					
7	1.0155						
8	1.0031						
9	1.0402						
10						.5735	.6859
11			.6001		.9374	.6401	.6859
12			.6668		.9402	.7202	.6001
13					.7907	.6401	.6859
14						.6554	.6859
15					.6554		.6001
16			.5144	.7202	.6173		.6001
17			.6859	.7811	.8002		.6001
18	.503	.5144	.4287	.4191			.5144
19	.3858	.7716	.6859	.5735	.5468		.7716
20	.6249	.6859	.7716	.7202		.6401	.7716
21	.5868	.6859	.6859	.6401			
22	.4858	.6001	.6859	.6401	.5468		
23	.5087	.5144	.6001	.5735	.5801	.4915	.5144
24	.5735	.5801	.5144	.5144	.5735	.4915	.4858
Max	1.0402	.7716	.7716	.8573	.9402	.7202	.7716
Min	.3858	.4973	.4287	.4191	.503	.4687	.4858
Avg	.6582	.5825	.5990	.6192	.6692	.5625	.6023

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 202 / WANJAR UMRAD

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1677	.2572	.2858	.2543	.2543	.1753
2	.1715	.1638	.2572	.2572	.2543	.2515	.1715
3	.1753	.1638	.2572	.2572	.2515	.2429	.1753
4	.1715	.2429	.2572	.2572	.3239	.3086	.1715
5	.3353	.3086	.2572	.3429	.4001	.381	.2515
6			.3429	.4287	.5735	.4458	.3353
7			.4287	.6001		.4744	.3277
8			.4287	.5144		.5401	.3239
9			.4287			.1619	.3239
10	.3353						
11	.2515						
12	.3239						
13	.2515						
14	.3239						
15	.3277						
16	.3277	.2572					
17	.3239	.2572					
18	.1696	.1715	.1715	.1753			.3429
19	.1581	.2572	.2572	.2543	.2486		.2572
20	.1658	.2572	.2572	.2515			.2572
21	.1715	.1715	.2572	.2572			
22	.1658	.1715	.2572	.2543	.2343		
23	.1658	.1715	.1715	.2515	.1581	.1753	.1715
24	.1753	.1658	.2572	.2572	.2515	.2401	.1753
Max	.3353	.3086	.4287	.6001	.5735	.5401	.3429
Min	.1581	.1638	.1715	.1753	.1581	.1619	.1715
Avg	.2333	.2091	.284	.3097	.2950	.3160	.2471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 203 / WAGHRUL (J)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1696	.2572	.2572	.2515	.1696	.1715
2	.1715	.1581	.2572	.2572	.2572	.1638	.1753
3	.1753	.1638	.2572	.2572	.2543	.1562	.1753
4	.1715	.188	.2572	.2572	.3239	.1543	.1715
5	.2515	.2315	.2572	.2572	.3391	.2286	.2515
6			.2058	.3429	.4144	.3086	.3239
7			.3429	.4287		.3906	.4049
8			.3429	.5144		.381	.4049
9			.3429			.1543	.4915
10	.2515						
11	.1753						
16		.1715					
17		.2572					
18	.1696	.1715	.1715	.1753			.1715
19	.1715	.2572	.2572	.2543	.2572		.2572
20	.1696	.2572	.2058	.2572			.2572
21	.1734	.1715	.2572	.2515			
22	.1734	.1715	.2572	.2543	.1543		
23	.1658	.1715	.1715	.2515	.1562	.1715	.1715
24	.1753	.1581	.1715	.2572	.2543	.2343	.1753
Max	.2515	.2572	.3429	.5144	.4144	.3906	.4915
Min	.1658	.1581	.1715	.1753	.1543	.1543	.1715
Avg	.1836	.1927	.2508	.2849	.2662	.2284	.2574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 204 / WAGHUL GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1882	.1829	.1848	.1753	.188	.1715
2	.1715	.1882	.1848	.1848	.1715	.1879	.1753
3	.1753	.188	.1848	.1848	.1753	.1871	.1715
4	.1753	.1875	.1848	.2772	.2515	.2806	.1753
5	.3391	.2821	.2743	.3696	.2572	.2801	.2515
6	.3315	.2795	.3696	.462	.2515	.3727	.3239
7	.4096		.462	.3696		.2809	.3201
8	.2515		.3696	.2772		.2806	.2515
9	.2515		.2772	.2543		.1875	.2515
10	.1753			.1753			.2772
11	.1753		.1848	.0914	.1877		.1848
12				.0905			
13					.1869		
14				.0914	.1871	.1753	
15				.1753	.1882		
16		.0924	.1848	.0914	.1871		.1848
17			.1848	.0914	.1867		.2772
18	.1875		.2772	.1753			.2772
19	.2792	.3696	.2772	.1715	.2781		.3658
20	.2824	.2772	.2058	.2515			.3696
21	.2809	.2772	.2772	.1753			
22	.2821	.1848	.1848	.1715	.2801		
23	.2815	.1848	.1848	.1753	.2818	.1753	.1848
24	.1753	.1869	.1829	.1848	.1753	.2806	.1753
Max	.4096	.3696	.462	.462	.2818	.3727	.3696
Min	.1715	.0924	.1829	.0905	.1715	.1753	.1715
Avg	.2445	.2220	.2439	.2033	.2138	.2397	.2438

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 205 / WANJAR UMRAD GAOTHAN
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1871	.1829	.1829	.1753	.1875	.1715
2	.1715	.1875	.1829	.1829	.1715	.1877	.1753
3	.1753	.188	.1829	.1829	.1753	.1873	.1715
4	.1753	.188	.1829	.1829	.1715	.1869	.1753
5	.1753	.188	.1829	.1829	.2515	.2801	.1715
6	.1715	.188	.2743	.2743	.2515	.2795	.2515
7	.2515		.2743	.1829		.2821	.1753
8	.1753		.1829	.1829		.1871	.2515
9	.1715		.1829	.1753		.1879	.2543
10	.1753			.1715		.0914	.1829
11	.0914		.0914	.1753	.0941	.0905	.1829
12	.0895			.0914	.0939	.0914	.1829
13	.0914				.094	.0905	
14	.0895				.094		
15	.0895						
16		.0914	.0914	.1753			.0914
17		.1829	.1829	.2515	.1869		.1829
18	.0941	.1829	.1829	.0914			.1829
19	.1871	.2743	.1829	.1753	.1863		.2743
20	.1869	.1829	.2743	.1715			.1829
21	.1873	.1829	.1829	.1753			
22	.1867	.1829	.1829	.0914	.188		
23	.1882	.1829	.1829	.1753	.188	.1715	.1829
24	.1753	.1879	.1829	.1829	.0914	.1869	.1753
Max	.2515	.2743	.2743	.2743	.2515	.2821	.2743
Min	.0895	.0914	.0914	.0914	.0914	.0905	.0914
Avg	.1579	.1852	.1877	.1742	.1609	.1792	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 201 / KADVANCHI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5658		.6859		
2	.4715	.5144		.6859		
3	.4715	.5658		.7716		
4	.4715	.5658		.7716		
5	.5658	.6602		.8573		
6	.5658	.7545		.8573		
7	.6602	.7545		1.0288		
8		.6602		.443		
9				.3544		
10				.3772		.3772
11				.3772		.3772
12			.2241	.3772		.3772
13				.3772		.3772
14				.3772		
15				.3772		
16				.3772		.5658
17				.4715		.6602
18	.6602			.5281		.7545
19	.7545			.4715		
20	.7545			.6602		.6602
21	.6602			.6602		.5658
22	.6602			.5658		.5658
23	.5658			.5658		.5658
24	.5658	.5658		.5316	.3921	.2054
Max	.7545	.7545	.2241	1.0288	.3921	.7545
Min	.4715	.5144	.2241	.3544	.3921	.2054
Avg	.5928	.623	.2241	.5646	.3921	.5044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 202 / NAVHA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.3772		.3544		.2241
2	.5658	.3772		.3544		
3	.5658	.3772		.3544		
4	.5658	.3772		.3544		
5	.6602	.4715		.3544		
6	.6602	.5658		.3544		
7	.7545	.5658		.3544		
8		.5658		.5144		
9				.6859		
10				.6602		.2263
11				.6602		.3772
12			.2801	.6602		.3772
13				.5658		.3772
14				.5658		
15	.3772			.3772		
16	.3772			.4715		.3772
17	.3772			.3772		.4715
18	.4715			.3772		.4715
19	.4715			.3772		
20	.4715			.4715		.4715
21	.3772			.4715		.3772
22	.3772			.4715		.3772
23	.3772			.3772		.3772
24	.3658	.3772		.3544	.2614	
Max	.7545	.5658	.2801	.6859	.2614	.4715
Min	.3658	.3772	.2801	.3544	.2614	.2241
Avg	.4930	.4505	.2801	.4550	.2614	.3754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 203 / BORKHEDI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.5658		.7716		
2	.5658	.5658		.7545		
3	.5658	.5658		.8383		
4	.5658	.5658		1.0059		
5	.6602	.6602		.9831		
6	.7545	.7545		1.065		
7	.8488	.9431		1.1069		
8	.6602	.7545		.7545		
9				.6706		
10				.5658		.2801
11				.4715		.3772
12			.2452	.4715		.3772
13				.3772		.3772
14				.3772		
15	.5658			.3772		
16	.6602			.3772		
17	.7545			.3772		.9431
18	.9431					1.1317
19	.9431					
20	.9431					1.0374
21	.7545					.9431
22	.7545					.8488
23	.5658					.7545
24	.7545	.5658		.5144	.2801	.2801
Max	.9431	.9431	.2452	1.1069	.2801	1.1317
Min	.5658	.5658	.2452	.3772	.2801	.2801
Avg	.7178	.6601	.2452	.6589	.2801	.6682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 204 / KOTHARI EXP

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.034	.0283		.0257		
2	.0321	.0283		.024		
3	.0321	.0264		.024		
4	.0302	.0245		.0257		
5	.0321	.0245		.0257		
6	.0283	.0226		.024		
7	.0264	.0245		.024		
8		.0226		.024		
9				.0429		
10				.0717		.028
11				.0924		.1169
12			.028	.0962		.1226
13				.0509		.0811
14				.0585		
15	.0547			.0736		
16	.0509			.0868		.0585
17	.0396			.049		.0377
18	.0377					.0283
19	.0321					
20	.0358					.0358
21	.034					.0264
22	.0358					.0283
23	.034					.0321
24	.034	.034		.0257	.028	.0224
Max	.0547	.034	.028	.0962	.028	.1226
Min	.0264	.0226	.028	.024	.028	.0224
Avg	.0355	.0262	.028	.0469	.028	.0515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 205 / GAWALI POKHARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658		.6001		
2	.5658	.5658		.6001		
3	.5658	.5658		.6001		
4	.5658	.5658		.6859		
5	.6602	.6602		.6859		
6	.7545	.7545		.7716		
7	.8488	.7545		.7716		
8		.7545		.7716		
9				.6859		
10				.7545		.1867
11				.6602		.8488
12			.1867	.6602		.8488
13				.4715		.8488
14				.4715		
15	.5658			.4715		
16	.4715					.5658
17	.4715			.6602		.6602
18	.5658					.6602
19	.6602					
20	.8488					.6602
21	.7545					.6602
22	.7545					.5658
23	.7545					.5658
24	.6602	.6602		.6859	.1867	.1867
Max	.8488	.7545	.1867	.7716	.1867	.8488
Min	.4715	.5658	.1867	.4715	.1867	.1867
Avg	.6491	.6497	.1867	.6475	.1867	.6048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 206 / PIRKALYAN

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.2614
12			.2241		
24	.2829	.2829		.2054	.2054
Max	.2829	.2829	.2241	.2054	.2614
Min	.2829	.2829	.2241	.2054	.2054
Avg	.2829	.2829	.2241	.2054	.2334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 201 / BAWNEPANGRI-AG Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	
2				.1715	
3				.1715	
4				.2572	
5				.2572	
6				.3429	
7				.6001	
9					.3841
10	.2572				
11	.3429				
13	.1715				
14	.2572				
15	.2572				
16	.1715				
17	.1715				
19		.2743			
20	.1848		.1715		
21			.1715		
22			.1715		
23			.1715		
24				.1715	
Max	.3429	.2743	.1715	.6001	.3841
Min	.1715	.2743	.1715	.1715	.3841
Avg	.2267	.2743	.1715	.2679	.3841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 202 / MANDEULGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17
HR	Load (MW)	Load (MW)
10	.2458	.2572
11		.3429
14		.1715
15		.1715
Max	.2458	.3429
Min	.2458	.1715
Avg	.2458	.2358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 203 / MANDEULGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429	
2				.3429	
3				.4287	
4				.6001	
5				.6859	
6				.8573	
7				.7716	
9	.6859				.7316
10	.3429	.5316	.5144		
11	.3429		.3429		
12	.3429		.2572		
13	.2572		.2572		
14			.2572		
15	.2572		.2572		
16	.2572		.2572		
17	.3429		.3429		
18	.4287		.5144		
19	.5144		.6859		
20			.7716		
21			.6001		
22			.5144		
23			.4287		
24				.4287	
Max	.6859	.5316	.7716	.8573	.7316
Min	.2572	.5316	.2572	.3429	.7316
Avg	.3772	.5316	.4287	.5573	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 201 / VIREGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4191	.4191	.4191	.4191
2			.4191	.4191	.4191	.4191
3			.4191	.4191	.4191	.4191
4			.4191	.503	.4191	.4191
5			.503	.5868	.503	.503
6			.5868		.5868	.503
7			.6706		.6706	.6706
8					.6706	.6706
9					.5868	.5868
10	.503					
11	.5868					
12	.5868					
13	.503					
14	.503					
15	.4191					
16	.4191	.3353	.3353	.3353		
17	.503	.4191	.3353	.3353		.3353
18	.5868	.503	.5868	.5868		.503
19	.5868	.6706	.7545	.5868		
20	.5868	.6706	.7545	.6706		
21	.5868	.6706		.6706		
22		.5868	.6706	.6706		
23		.5868	.5868	.5868		
24			.503	.503	.4191	.503
Max	.5868	.6706	.7545	.6706	.6706	.6706
Min	.4191	.3353	.3353	.3353	.4191	.3353
Avg	.5309	.5554	.5309	.5209	.5113	.4960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 202 / PIMPALGAON

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6706		.6706	.6706
2			.7545		.6706	.6706
3			.7545		.6706	.6706
9	.6706					
10						.5868
11		.6706	.6706	.6706		.6706
12			.6706	.6706		.7545
13			.6706	.6706		.7545
14			.5868	.5868		.7545
15			.5868	.5868		.7545
16	.503	.5868	.5868	.6706		.6706
17	.503	.6706	.6706	.6706		.6706
18	.7545	.7545	.7545	.7545		.8383
19	1.0059	.7545	.9221	.9221		
20	.9221	.7545	.8383	.8383		
21	.7545	.7545		.6706		
22		.7545	.6706	.6706		
23		.6706	.6706	.6706		
24			.6706	.5868	.5868	.6706
Max	1.0059	.7545	.9221	.9221	.6706	.8383
Min	.503	.5868	.5868	.5868	.5868	.5868
Avg	.7305	.7079	.6968	.6886	.6497	.7029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134059 / DAMBRI

Feeder No / Name : 203 / DAMBRI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2515	.2515	.2515	.2515
2			.2515	.2515	.2515	.2515
3			.2515	.2515	.2515	.2515
4			.2515	.2515	.2515	.2515
5			.3353	.3353	.2515	.2515
6			.3353	.4191	.3353	.3353
7			.3353	.4191	.3353	.4191
8				.503	.4191	.4191
9					.4191	.3353
10	.2515					
11	.2515					
12	.2515					
13	.2515					
14	.2515					
15	.1677					
16	.1677					
17	.1677					
18	.2515	.2515	.2515	.2515		.2515
19	.1677	.3353	.2515	.2515		
20	.1677	.2515	.2515	.2515		
21	.2515	.2515		.2515		
22		.2515	.2515	.2515		
23		.2515	.2515	.2515		
24			.2515	.2515	.2515	.2515
Max	.2515	.3353	.3353	.503	.4191	.4191
Min	.1677	.2515	.2515	.2515	.2515	.2515
Avg	.2166	.2655	.2708	.2962	.3018	.2972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286		.2477
2		.2286		.2477
3		.2477		.2477
15			.381	
16	.1143		.4001	
17	.1905		.4001	
18	.2477		.1334	
19	.2286		.1905	
20	.2286		.2286	
21	.1905		.2286	
22	.2286		.2477	
23	.2286		.2477	
24		.2286		.2286
Max	.2477	.2477	.4001	.2477
Min	.1143	.2286	.1334	.2286
Avg	.2072	.2334	.2731	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 203 / SAWANGI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429		.3429
2		.381		.381
3		.5716		.4572
15			1.0479	
16	.381		1.0479	
17	.5906		1.0288	
18	.5716		.6287	
19			.5716	
20			.5335	
21	.4191		.4191	
22	.381		.381	
23	.3429		.362	
24		.3429		.3429
Max	.5906	.5716	1.0479	.4572
Min	.3429	.3429	.362	.3429
Avg	.4477	.4096	.6689	.381