

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134003 / AMBAD****Feeder No / Name : 201 / TOWN I****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097		.6668	.1905		.1905	.4763
2	.6097		.6668	.1905		.1905	.4763
3	.6097		.3048	.1905		.1905	.381
4	.6097		.3334	.1905		.1905	.381
5	.7621		.3048	.1524		.1905	.381
6	.7621		.3334	.1905		.1905	.4763
7	.7621	1.1431	.4287	.1905	1.1431	.1905	.381
8	.7621	.1905	.7621	.381	.1905	.9526	.9526
9	.4763	.1905	.7621	.4763	.1905	.9526	.9526
10	.5716	.1905	.6097	.4287	.1905	.9526	.9526
11	.4763	.1905	.6097	.4763	.1905	.9526	.9526
12	.381		.6097	.4763	.1905	.9526	.9526
13	.381	.1905	.6097	.4287	.1905	.9526	.9526
14	.2858			.4763	.1905	.9526	.9145
15	.2858	.5716	.6097	.5144	.1905	.9526	.7621
16	.7621	.5716	.6097	.9526	.1905	.7621	.7621
17	.7621	.5716	.381	.9526	.1905	.4763	.7621
18	.7621	.5716	.1524	.9526	.1905	.4763	.7621
19	.9526	.4287	.1524	.9526	.1905	.4763	.7621
20	.9526	.4287	.1524	.9526	.1905	.4763	.7621
21	.9526	.4763	.1524	.9526	.1905	.381	.7621
22	.7621	.5716	.1524	.9526	.1905	.4763	.6097
23		.6859	.1524		.1905	.7621	.6097
24	.6097	.9526	.1524		.1524		.4763
Max	.9526	1.1431	.7621	.9526	1.1431	.9526	.9526
Min	.2858	.1905	.1524	.1524	.1524	.1905	.381
Avg	.6461	.4954	.4204	.5283	.2413	.5757	.6922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134003 / AMBAD****Feeder No / Name : 202 / TOWN2****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145		.5716	.1143		.2286	.7621
2	.9145			.1143		.2286	.7621
3	.9145		.5716	.1143		.2286	.6668
4	.9145		.4763	.1905		.2286	.6668
5	1.0669		.5716	.2286		.2286	.7621
6	1.0669		.5716	.2667		.2286	.6668
7	1.0669	1.5242	.7621	.2667	1.5242	.2286	.7145
8	1.0669	.3048	1.0669	.7621	.2286	.9526	1.1431
9	.6668	.2667	1.0669	.6668	.2286	.9526	1.1431
10	.6668	.2667	.9145	.5716	.2286	.9526	1.1431
11	.381		.9145		.2286	.9526	1.1431
12	.381	.2286	.9145	.4763	.2286	.9526	.9526
13	.381	.2286	.9145	.381	.2286	.9526	.9526
14	.3334	.2286	.9145	.3429	.2286	.9526	.9526
15	.3334	.381	.9145	.381	.2286	.9526	.7621
16	.7621	.381	.9145	.9145	.2286	.4763	.7621
17	.7621		.1905	1.1431	.2286	.4763	.9145
18	.7621		.1905	1.1431	.2286	.4572	.9145
19	1.1431	.4763	.1905	1.1431	.2286	.5239	.9145
20	.9526	.381	.1905	1.1431	.2286	.2286	.9145
21	1.1431	.4763	.1905	1.1431	.2286	.2286	.9145
22	1.1431	.381	.1905	1.1431	.2286	.1905	.7621
23		.4572	.1905	.2667	.2286	.1905	.7621
24	.9145	.9526	.1905		.2286	.1905	.7621
Max	1.1431	1.5242	1.0669	1.1431	1.5242	.9526	1.1431
Min	.3334	.2286	.1905	.1143	.2286	.1905	.6668
Avg	.8109	.4623	.5906	.5871	.3006	.5076	.8673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134003 / AMBAD

Feeder No / Name : 203 / BORI

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
12		3.4294	
13			3.4294
24	.6859		
Max	.6859	3.4294	3.4294
Min	.6859	3.4294	3.4294
Avg	.6859	3.4294	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD
Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]
JALNA CIRCLE[625]
JALNA DIVISION II[275]
AMBAD (R) S/DN[409] BU 2747
Substation No/ Name :- 134003 / AMBAD
Feeder No / Name : 204 / GOLAPANGRI
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8			3.8104
12		3.8104	
24	.6859		
Max	.6859	3.8104	3.8104
Min	.6859	3.8104	3.8104
Avg	.6859	3.8104	3.8104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134003 / AMBAD****Feeder No / Name : 205 / SHAHAPUR****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814			.2286		.2286	.6097
2	1.9814			.381		.2286	.7621
3	2.1338			.381		.2286	.7621
4	2.1338			.381		.2286	.7621
5	2.1338			.381		.2286	.9526
6	2.7435			.5716		.2667	1.2384
7	2.7435	3.8295		.0686		.2667	1.1431
8	.1143	.724	2.7435	1.7623		1.3336	2.2862
9	.1143	.1524	.381	.2286		2.4768	2.2862
10	.0857		.381	.1715	.2667	2.4768	3.0483
11	.0857			.0572	.1905	2.6673	3.0102
12				.1429	.6859	2.4768	2.8578
13	.1143		.381	.0953	.1905	1.9052	2.8578
14	.1429	.1524	.381	.0857	.1905	2.2862	2.8578
15	.1143	.381	.381	.1429	.1905	2.2862	2.8578
16	.2858	.5716	.381	.2858	.1905	2.0576	2.8578
17	1.5242	.9145	.2286	.2858	.1905	.5716	1.5242
18	1.7147	.5716	.2286	.1905	.1905	.9526	1.5242
19	1.7147	.5716	.2286	.1905	.1905	1.1431	1.5242
20	1.5242	.9526	.2286	.2858	.1905	.7621	1.5242
21	2.0957	.7621	.2286	.5335	.1905	.8573	.9145
22	2.0957	.7621	.2286	.5335	.1905	.7621	.9145
23		.5335	.2286		.2286	.7621	.6097
24	1.829	1.9052	.2286		.2286		.6668
Max	2.7435	3.8295	2.7435	1.7623	.6859	2.6673	3.0483
Min	.0857	.1524	.2286	.0572	.1905	.2286	.6097
Avg	1.3367	.9132	.4572	.3357	.2337	1.1936	1.6813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134003 / AMBAD****Feeder No / Name : 206 / WATER SUPPLY****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.1524	.0762		.0572	.1905
2	.3048		.1524	.0762		.1429	.1905
3	.3048		.1905	.0762		.0572	.1905
4	.3048		.1905	.0762		.0572	.1905
5	.3048		.1143	.0762		.0762	.1429
6	.3048		.1715	.0762		.0572	.1429
7	.3048	.381	.1143	.0762	.381	.0572	.1905
8	.3048	.0762	.3048	.0762	.0762	.2858	.381
9	.1429	.0762	.3048	.1429	.0762	.381	.381
10	.1429	.0762	.3048	.1429	.0762	.381	.381
11	.1429	.0762	.6097	.1429	.0762	.381	.381
12	.1524	.0762	.4268	.1143	.0762	.381	.381
13	.1429	.0762	.3048	.0953	.0762	.5335	.381
14	.1429	.0762	.3048	.1429	.0762	.381	.381
15	.1429	.1429	.3048	.1429	.0762	.381	.381
16	.381	.1429	.3048	.381	.0762	.1905	.381
17	.381	.1429	.0762	.381	.0762	.1905	.3048
18	.381	.1429	.0762	.381	.0762	.1524	.3048
19	.381	.1143	.0762	.381	.0762	.1905	.3048
20	.381	.1543	.0762	.381	.0572	.1905	.3048
21	.381	.1143	.0762	.381	.0762	.1429	.3048
22	.381	.1143	.0762	.381	.0762	.1429	.3048
23		.1143	.0762		.0572	.1429	.3048
24	.3048	.381	.0762		.0572		.1905
Max	.381	.381	.6097	.381	.381	.5335	.381
Min	.1429	.0762	.0762	.0762	.0572	.0572	.1429
Avg	.2791	.1377	.2027	.1909	.0900	.2154	.2913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134003 / AMBAD****Feeder No / Name : 207 / TOWN NO-3****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.2382	.1143		.1143	.2858
2	.381		.2858	.1143		.1143	.2858
3	.381		.3334	.1143		.1143	.2382
4	.381		.3334	.1143		.1143	.2858
5	.4572		.2382			.1143	.2382
6	.4572		.2858	.1143		.1143	.2286
7	.4572	.5716	.2858	.1143	.5716	.1143	.2858
8	.4572	.1143	.4572	.3429	.1143	.5716	.5716
9	.2382	.1143	.4572	.3429	.1143	.5716	.5716
10	.2382	.1143		.3429		.5716	.5716
11	.2382	.1143	.381	.2858	.1143	.724	.5716
12	.2382	.1143	.381	.2858	.1143	.4763	.381
13	.2382		.381	.2286	.1143	.5716	.5716
14	.1905		.381	.2858	.1143	.5716	.4763
15	.2382	.2286	.381	.4001	.1143	.5716	.5716
16	.724	.2382	.381	.5716	.1143	.2858	.5716
17	.5716	.2382	.1143	.5716	.1143	.1905	.4572
18	.5716	.2858	.1143	.5716	.1143	.1905	.4572
19	.5716	.2286	.1143	.5716	.1143	.2382	.4572
20	.5716	.1905	.1143	.5716	.1143	.2382	.4572
21	.5716	.2858	.1143	.5716	.1143	.2382	.4572
22	.5716	.2858	.1143	.5716	.1143	.2382	.381
23		.2382	.1143		.1143	.2382	.381
24	.381	.5716	.1143		.1143		.2858
Max	.724	.5716	.4572	.5716	.5716	.724	.5716
Min	.1905	.1143	.1143	.1143	.1143	.1143	.2286
Avg	.4134	.2459	.2659	.3429	.1412	.3169	.4184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 201 / TAKA AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.8002						
3	.8383						
4	.9907						
5	1.2574						
6	1.3717						
7	1.448						
8	1.5242						
9	1.6004						
11		1.3336	1.4098	1.1622	1.2384	1.3336	1.3336
12		1.448	1.9052	1.8861	1.4098	1.3336	1.6194
13		1.5242	2.0005	1.8861	1.6766	1.5242	1.6194
14		1.7909	2.0005	1.8861	1.8671	1.6385	1.5623
15		1.9052	1.9433	1.8671	1.7528	1.6766	1.5242
16		1.8671	1.9052	1.7909	1.6194	1.6385	1.3717
17		1.6385	1.6956	1.5813	1.3717		1.2574
18		1.5242	1.4861	1.448	1.2765	1.3336	1.086
Max	1.6004	1.9052	2.0005	1.8861	1.8671	1.6766	1.6194
Min	.8002	1.3336	1.4098	1.1622	1.2384	1.3336	1.086
Avg	1.2289	1.6290	1.7933	1.6885	1.5265	1.4969	1.4218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 202 / NALEWADI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2858	.2667	.2286	.2667	.2286
2	.2667	.362	.2667	.362	.3239	.3048	.2667
3	.2858	.4572	.3048	.4572	.362	.3429	.3429
4	.3429	.5716	.362	.6859	.4954	.4001	.4382
5	.4954	.6478	.4954	.7621	.6859	.5525	.5525
6	.6478	.743	.6097	.8192	.743	.6287	.6478
7	.6859	.743	.6859	.7811	.7049	.6097	.724
8	.5335	.6478	.724	.8002	.6097	.6287	.6859
9	.4572	.5716		.743	.4572	.5335	.6668
10	.3429	.4001	.4572	.4001	.381	.381	
11	.2286	.3048	.3048	.2667	.2858	.2286	.2286
12	.1905	.2096	.2667	.1715	.2286	.1905	.1334
13	.1524	.1905	.2286	.1143	.1905	.1524	.1334
14	.1524	.1905	.2096	.1524	.1524	.1524	.1143
15	.1524	.2286	.1905	.1334	.1905	.1334	.0953
16	.1905	.1905	.2096	.1715	.1905	.1524	.2477
17		.2667	.3048	.3048	.1905	.362	.5525
18		.3429	.362	.5335	.5335	.4954	.6097
19		.5335	.4572	.6097	.6097	.5525	.6478
20		.4572	.5525	.5525	.5716	.6478	.5716
21		.4572	.5716	.4382	.4954	.6859	.4954
22		.3429	.362	.381	.381	.5525	.4382
23		.3048	.3429	.3048	.3239	.5525	.381
24	.381	.3429	.2667	.3048	.2667	.2858	.4572
Max	.6859	.743	.724	.8192	.743	.6859	.724
Min	.1524	.1905	.1905	.1143	.1524	.1334	.0953
Avg	.3440	.4104	.3835	.4382	.4001	.4080	.4200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 203 / GONDI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3239	.2667	.3048	.3429	.3429	.4001
2	.3429	.362	.3239	.3429	.4191	.4191	.4572
3	.381	.4572	.362	.3239	.4763	.5335	.5716
4	.4191	.4954	.4382		.5525	.6859	.6859
5	.5525	.6478	.5335	.4572	.743	.743	.8002
6	.8383	.6859	.743	.6859	.8954	.8002	.9145
7	.9526	.743	.8383	.8192		.9145	1.0288
8	.8002	.8002	.9907	.9145	.6478	.9907	.9145
9	.724	.5335	.9526	.6859	.5335	.724	.724
10	.6478	.4191	.7811	.5335	.381	.4954	.5716
11		.3429	.5335	.4572		.4191	.4954
12	.4572		.362	.3429	.3429	.381	.381
13	.3429	.3048	.3429	.3429	.2858	.3429	.3429
14	.2667	.3429	.3429	.3048	.2858	.3048	.3048
15	.3048	.2286	.3048	.3239	.4191	.2858	.2477
16	.381	.2667	.3429	.3429	.4954	.3429	.362
17		.2858	.381	.5716	.6287	.5144	.5525
18		.7621	.4572	.8383	.724	.724	.7811
19		.6859	.4954	.8573	.7621	.8002	.724
20		.6097	.743	.7621	.6097	.7811	.724
21		.5335		.6097	.5335	.6859	.5525
22		.4954	.8002	.5335	.4572	.6859	.381
23		.381	.5525	.4191	.3429	.5716	.381
24	.3048	.362	.3429	.4954	.381	.3048	.5335
Max	.9526	.8002	.9907	.9145	.8954	.9907	1.0288
Min	.2667	.2286	.2667	.3048	.2858	.2858	.2477
Avg	.5001	.4813	.5318	.5335	.5118	.5747	.5763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 205 / SHAHAPUR AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	2.0957						
3	2.191						
4	2.2862						
5	2.3243						
6	2.4006						
7	2.4387						
10		.1524					
11		2.4577	2.4387	2.6863	2.6673	2.2862	2.0957
12		2.9531	2.6482	2.9912	3.0102	2.3624	2.3815
13		2.9912			3.0864	2.4387	2.3815
14		3.0483		2.915	3.1436	2.5149	2.3815
15		3.0483	2.8006	2.8578	3.0102	2.572	2.4196
16		2.915	2.7625		2.8578		2.4006
17		2.8197			2.4768		2.0957
18		2.4196	2.2672		2.1338		2.2862
Max	2.4387	3.0483	2.8006	2.9912	3.1436	2.572	2.4196
Min	2.0957	.1524	2.2672	2.6863	2.1338	2.2862	2.0957
Avg	2.2894	2.5339	2.5834	2.8626	2.7983	2.4348	2.3053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 206 / SHAHAPUR GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3429	.381	.362	.4191	.3429	.5716
2	.381	.4191	.3429	.4572	.362	.4572	.6478
3	.4382	.4572	.4001	.6478	.4382	.5525	.5525
4	.6097	.5144	.4572	.7621	.5525	.724	.6859
5	.9145	.5525	.5525	.8383	.6287	.8383	.8383
6		.6478	.6859	.9145	.743	.9145	.9145
7		.743	.5335	1.0288	.8954		.9335
8		.5525		.9907	.7621		.6478
9				.8192	.6859		.5525
10		.4191		.6097	.5335	.5335	.4954
11	.5525	.381	.6478	.4572	.4763	.381	.4191
12	.4572	.381	.5335	.3048	.4191	.381	.2858
13	.381	.362		.3429	.3429	.3429	
14	.381	.3429		.362		.3429	
15	.381	.3429	.4954	.4001		.3429	.2667
16	.4191	.4191	.5716				.381
17		.5525	.743	.6097	.724		.6859
18		.724	.8192	.9145	.8573	.8954	.7811
19		.9145	.8002	.9907	.8383	.9526	.743
20		.8002	.7621	.9145	.7621	.9717	.8002
21		.6859	.8192	.7621	.5906	.9335	.7621
22			.9145	.6859		.6478	.6859
23		.381	.8002	.5525	.4191		.5716
24	.4572	.4954	.381	.6478	.4572	.381	.6097
Max	.9145	.9145	.9145	1.0288	.8954	.9717	.9335
Min	.381	.3429	.3429	.3048	.3429	.3429	.2667
Avg	.4826	.5196	.6127	.6685	.5954	.6075	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 207 / GONDI AG****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5525					
2		.381	.6097	.5525	.6097	.5716	.4572
3		.6859	.6859	.6287	.6287	.6478	.5525
4		.7621	.743	.6478	.6668	.6859	
5		.8002	.7811	.724	.7049	.7049	.743
6		.9145	.8192	.7621	.7621	.6859	.8002
7		.8764	.8764	.8002	.8002	.7621	.8192
8		1.0098	.9717	.9717	.7621	.8764	.8002
9		1.0669	.9335	.9335	.7621	.9526	.6859
11	.8954						
12	1.105						
13	1.1812						
14	1.2384						
15	1.2384						
16	1.2384						
Max	1.2384	1.0669	.9717	.9717	.8002	.9526	.8192
Min	.8954	.381	.6097	.5525	.6097	.5716	.4572
Avg	1.1495	.7833	.8026	.7526	.7121	.7359	.6940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134011 / WADIGODRI

Feeder No / Name : 208 / DONGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4572	.5716	.6097	.8002	.9526	.743
3		.6478	.6287	.6859	.8764	.9907	.8192
4		.7621	.8383	.7811	.9526	.9907	.9335
5		.9335	1.3146	1.2955	1.0288	1.0669	1.1241
6		1.0288	1.4861	1.4289	1.105	1.1241	1.2193
7		1.3146	1.6956	1.6194	1.1812	1.9433	1.3908
8		1.6766	1.8671	1.6956	1.1431	2.21	1.3146
9		1.4861	1.8099	1.086	1.105	2.2862	1.2193
11	1.7147						
12	2.2481						
13	2.3624						
14	2.4768						
15	2.4387						
16	2.4006						
Max	2.4768	1.6766	1.8671	1.6956	1.1812	2.2862	1.3908
Min	1.7147	.4572	.5716	.6097	.8002	.9526	.743
Avg	2.2736	1.0383	1.2765	1.1503	1.0240	1.4456	1.0955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 209 / CANNEL AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 210 / p.sirasgaon (Ag)
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	30-NOV-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.6956	1.8861	1.9624	1.7147	1.6004
3		1.7909	2.0957	2.0767	1.848	1.7147
4		1.8861	2.21	2.0957	1.8671	1.8861
5		2.0957	2.2862	2.21	2.0195	2.0957
6		2.2481	2.4196	2.2862	2.0957	2.2481
7		2.3243	2.553	2.4006	2.4577	2.3053
8		2.4006	2.6673	2.3243	2.572	2.2481
9			2.6292	2.2862	2.6292	2.1719
11	2.553					
12	2.7435					
13	2.8197					
14	3.3913					
15	3.3913					
16	3.3532					
Max	3.3913	2.4006	2.6673	2.4006	2.6292	2.3053
Min	2.553	1.6956	1.8861	1.9624	1.7147	1.6004
Avg	3.042	2.0630	2.3434	2.2053	2.1505	2.0338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134011 / WADIGODRI****Feeder No / Name : 212 / Baraswda (G)****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905		.1715
2	.8383	.2096	.2667	.2286	.1905	.1905	.2286
3	.9526	.1715	.362	.2096	.2286	.1905	.2286
4	1.0288	.1524	.4954	.2667	.2286	.2477	.2667
5	1.1431	.2667	.5335	.2477	.2667	.2858	.3048
6	1.4861	.2477	.5716	.2858	.2858	.3048	.3429
7	1.6766	.2096	.4954	.3048	.2667	.2667	.3048
8	1.6766	.2096	.4191	.4191	.2286	.2477	.2286
9	1.6004	.3048	.2858	.381	.1905	.2286	.1524
10	.3048	.2667	.1905	.2096	.1905		.1524
11	.1905	1.3146	1.3717	1.4098	1.3717	1.0479	.7621
12	.1524	1.6956	1.4289	1.6385	1.4098	1.1812	.8764
13	.1524	1.6385	1.6956	1.8861	1.5242	1.1812	
14	.1143	1.5813	1.6766	1.8671	1.6385	1.1431	1.2384
15	.1524	1.5623	1.6385	1.7718	1.6194	1.1431	1.3336
16	.1905	1.6194	1.6004	1.7337	1.6194	1.1431	1.2955
17		1.5242	1.5242	1.5623	1.3908	1.105	1.2574
18		1.3717	1.4861	1.3908	1.2955	1.1241	1.1431
19		.4954	.3048	.3048	.3048	.3048	.3429
20		.4572	.2286	.2667	.2667	.3429	.3048
21		.381	.2667	.2286	.2286	.2667	.2477
22		.2667	.2477	.2286	.1905	.2477	.1905
23		.2286	.2286	.1905	.1905	.2096	.1905
24	.2286	.1715	.1905	.2096	.1524	.1524	
Max	1.6766	1.6956	1.6956	1.8861	1.6385	1.1812	1.3336
Min	.1143	.1524	.1905	.1905	.1524	.1524	.1524
Avg	.7105	.6890	.7375	.7263	.6446	.5707	.5256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134026 / JAMKHED****Feeder No / Name : 201 / JAMKHED****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.8573	.8573	.7545	.9431	.8573	.9088
2	.9431	.9431	.8573	.8573	.9431	.9431	.9088
3	1.1145	1.0288	.9431	1.0288	.9431	1.0974	1.0288
4	1.2517	1.2003	1.0974	1.2003	1.0288	1.2003	1.0802
5	1.4746	1.4746	1.2003	1.3717	1.2003	1.3717	1.286
6	1.5947	1.5775	1.5432	1.5947	1.3717	1.4403	1.5089
8						.1372	
11	1.6804	1.2689	1.5604	1.3717	1.6804		1.406
12	1.8861	1.2346	1.869	1.3717	1.7147	1.286	1.2003
13	1.5089	1.2003	1.6975	1.2003	1.6289	1.2003	1.4746
14	1.7147	1.1145	1.6461	1.0288	1.7147	1.1145	1.3717
15	1.7147	1.1145		1.2003	1.7147	1.0802	1.3717
16		1.0974	1.5947	1.0288	1.5775	1.0974	1.4575
17	1.8004	1.286	1.5947	1.3717	1.5432	1.1145	1.3717
18	1.4918	1.3717	1.406	1.3717	1.3717		1.0288
19	1.5775		1.4746	1.5432	1.3717	1.4575	1.2003
20	1.286	1.5089	1.2003	1.286	1.2003	1.286	1.1145
21	1.1317	1.2003		1.2003	1.0288	1.0802	.9431
22	1.0288	1.0288	.8745	1.0288	.9431	1.0288	.8916
23	.9431	1.0288	.8573	.9431	.8573	.9431	.8745
24	1.0117	.9259	.9259	.8402	.8573	.8573	.8573
Max	1.8861	1.5775	1.869	1.5947	1.7147	1.4575	1.5089
Min	.9431	.8573	.8573	.7545	.8573	.1372	.8573
Avg	1.3736	1.1822	1.2889	1.1797	1.2817	1.0838	1.1643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134026 / JAMKHED****Feeder No / Name : 202 / ROHILAGAD****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.0631	.8573	1.0117	.8573	1.0288	.8402
2	1.1145	1.0631	.8573	1.1145	.8573		2.0405
3	1.0288	1.1145	1.0288	1.2003	.8573	2.0576	2.2291
4			1.0288	1.3717	1.2003	2.2291	2.452
5						2.572	2.7435
6						2.6235	2.9492
7						3.0864	3.4122
8						3.2579	3.2579
9						3.155	2.8635
10					.1372		
11		2.7435	1.5947	2.7092	2.4691	.5144	.8573
12	2.9835	2.915	2.8292	2.7435	2.7435	.4801	.6516
13	3.2065	2.9835	2.5549	3.0864	2.915	.5144	.5658
14	3.1893	3.0178	2.1776	2.9492	2.9835	.4801	.5144
15		2.915		2.915	2.7435	.4287	.6173
16	2.7435	2.915	2.8121	2.915	2.6749	.5144	.5487
17	2.7949	3.035	2.5892	2.7435	2.572	.6344	1.1145
18	2.6235	2.915	1.7833	2.7435	2.1434		
19	3.0521	3.2579	2.0405	2.572	2.1434	2.2291	2.3148
20	2.3491	2.8464		2.4006	2.2291	2.0919	1.7147
21	2.1605	2.4863		1.1317	1.8004	2.1091	
22	1.1145	1.0288	.9431	.8573	1.7147	.9431	.8916
23	1.0288	.9431	.9259	.8573	1.0288	.9088	.8916
24	1.0288	.8916	.8916	.9088	1.0288	1.0288	.8573
Max	3.2065	3.2579	2.8292	3.0864	2.9835	3.2579	3.4122
Min	1.0288	.8916	.8573	.8573	.1372	.4287	.5144
Avg	2.1022	2.2432	1.6610	2.0128	1.8473	1.5661	1.6347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134026 / JAMKHED****Feeder No / Name : 203 / NANDI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3772	.4801	.3772	1.1145	.3086	.2915
2	1.0288	1.0288	1.3717	.9431	1.2003	.3086	.2915
3	1.286	1.2517	1.7147	1.0802	1.2003	.3429	.3429
4	1.3717	1.3717	1.8861	1.2003	1.4575	.4115	.4801
5	1.4575	1.4575	2.4006	1.3032	1.5432	.5144	.583
6	1.5775	1.6461	2.452	1.7833	1.6804	.6001	.7545
7	2.4348		2.572	2.6235	2.4006		
8	2.9835	2.6235	2.7435		2.8292		
9	2.6235	2.4348	2.572	2.4006	2.4691		
10	.4115	.2058	.5144	.3772	.2058		.3944
11			.2229			1.7147	1.989
12		.2401	.1543	.3429	.2058	2.2291	2.1948
13	.2058	.2058	.1715		.2058	2.2291	2.572
14	.2058	.2058		.2058	.2058	2.1948	2.4006
15	.1715	.2058		.2058	.2058	2.1262	2.2977
16	.2229	.2058	.2058	.2401	.2058	2.2119	2.0748
17		.3772	.3429	.3429	.3429	1.5432	1.6804
18		.3772	.7202	.5144	.5144		1.406
19		.823	.6001	.5144	.5316	.4973	.6001
20	.4287	.6344	.6001	.5144	.5144	.4458	.5144
21	.4287	.6001	.583	.5144	.5144	.4801	.5144
22	.4287	.5658	.5316	.4287	.4115	.3429	.5487
23	.4115	.5144	.4801	.4287	.3429	.3086	.5144
24	.3601	.4801	.4801	.4801	.3429	.3429	.3086
Max	2.9835	2.6235	2.7435	2.6235	2.8292	2.2291	2.572
Min	.1715	.2058	.1543	.2058	.2058	.3086	.2915
Avg	.9683	.8106	1.0818	.8010	.8976	1.0080	1.0835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134039 / CHINCHKHED****Feeder No / Name : 201 / CHINCHKHED AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						1.0669	1.4575
3						1.0669	1.5432
4						1.0669	1.7147
5						1.0669	1.8861
6						1.1431	2.0576
7						1.5242	2.572
8						1.5242	2.7435
9						1.829	2.7435
11	2.7435	1.5242	2.2862	1.6766	2.572		
12			2.6673	1.829	3.4294		
13	3.0483	2.1338	2.6673	1.9814	3.0864		
14	3.0483	1.829	2.6673	1.9814	3.2579		
15	3.0483	2.1338		1.9814	3.4294		
16	2.8959	2.1338	2.6673	1.9814	3.4294		
17	3.0483	2.1338	2.4006	1.9814	3.0864		
18	3.4294	1.829	2.4006	1.9814	3.0864		
Max	3.4294	2.1338	2.6673	1.9814	3.4294	1.829	2.7435
Min	2.7435	1.5242	2.2862	1.6766	2.572	1.0669	1.4575
Avg	3.0374	1.9596	2.5367	1.9243	3.1722	1.2860	2.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134039 / CHINCHKHED****Feeder No / Name : 202 / SIRNER GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2572	.1715	.2572	.1715	.1715	.1715
2	.2572	.2058	.1715	.2572	.1715	.1715	.1715
3	.2572	.2572	.1715	.2572	.1715	.1715	.1715
4	.2572	.2572	.4287	.2572	.3429	.2572	.2572
5	.3429	.3429		.3429	.4287	.4287	.3429
6	.5144	.5144		.5144		.5144	.4287
7				.5144		.6001	.5144
8	.5144	.5144		.3429		.5144	.5144
9		.5144		.2572		.4287	
10	.3429	.5144		.2572	.3429	.2572	.3429
11			.1715			.1715	.1715
12		.2572	.1715		.1715	.1715	.1715
13		.1715	.1715	.2572	.1715	.1715	.0857
14		.1715	.1715		.1715	.1715	.0857
15		.1715			.1715	.1715	.0857
16			.1715		.1715	.1715	.0857
17		.2572	.1715		.1715	.1715	.2572
18		.4287			.3429	.3429	
19	.5144	.4287			.4287		.4287
20	.3429	.2572	.3429	.3429	.3429	.2572	.3429
21	.2572	.2572	.2572	.2572	.2572	.1715	.2572
22	.2572	.1715	.2572	.2572	.1715	.1715	.2572
23	.2572	.1715	.2572	.1715	.1715	.1715	.2572
24		.2572	.1715	.2572	.1715	.1715	.1715
Max	.5144	.5144	.4287	.5144	.4287	.6001	.5144
Min	.2572	.1715	.1715	.1715	.1715	.1715	.0857
Avg	.3363	.3038	.2172	.3001	.2392	.2609	.2533

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134039 / CHINCHKHED

Feeder No / Name : 203 / SHIRNER AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.5242		1.1431			
2	1.7147	1.5242	1.829	1.1431	1.829		
3	1.7147	1.5242	1.9814	1.1431	1.9814		
4	1.9052	1.5242	2.1338	1.1431	2.1338		
5	1.9052	1.5242	2.0005	1.5242	2.2005		
6	1.9052	1.7147	2.6673	1.7147	2.934		
7			2.6673	1.7147	3.0674		
8	3.4294	1.9052	3.2007	2.8578	3.1341		
9	3.4294	1.9052	3.2007	2.8578	3.1341		
11						2.6578	2.2862
12						2.8959	2.6673
13				2.8578		3.1245	2.6673
14						2.1338	2.6673
15						2.2862	2.6673
16						2.2862	2.6673
17						2.21	2.4006
18						1.7528	2.4006
21		.0572					
23							.381
Max	3.4294	1.9052	3.2007	2.8578	3.1341	3.1245	2.6673
Min	1.7147	.0572	1.829	1.1431	1.829	1.7528	.381
Avg	2.2148	1.4670	2.4601	1.8099	2.5518	2.4184	2.3117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134039 / CHINCHKHED****Feeder No / Name : 204 / CHINCHKHED GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6001	.5144	.6001	.5144	5.1955	.5144
2	.6001	.6001	.5144	.6001	.5144	.5144	.5144
3	.6001	.6001	.5144	.6001	.5144	.5144	.5144
4	.6001	.6001	.6859	.6001	.5144	.6859	.6859
5	1.4575	1.0288	.8573	.6859	.8573	.9145	.9431
6	1.3717	1.2003		1.0288		1.1431	1.2003
7						1.2955	
8						1.2193	
9						1.0669	1.0288
10	.8573		.9145		.8573	.8573	1.0288
11		.6859	.6859	1.0288	.6859	.6001	.6859
12				.8573			
13		.5144		.6859			
14		.5144		.5144		.5144	
15		.5144		.5144		.5144	
16		.5144		.6859		.5144	
17		.6859	.1715	.8573		.7716	
18		.9907	.2572	.9907	.5144	1.1145	
19	1.3717	1.0669	.7716	1.0669		1.2003	1.2003
20	.8573	.7621	.7716		.9431	.7716	.8573
21	.6859	.6001	.6859	.6859	.7716	.5144	.6001
22	.6001	.5144	.5144	.6001	.6859	.5144	.6001
23	.6001	.5144	.5144	.6001	.6001	.5144	.6001
24	.6001	.6001	.5144	.6001	.6001	.6001	.5144
Max	1.4575	1.2003	.9145	1.0669	.9431	5.1955	1.2003
Min	.6001	.5144	.1715	.5144	.5144	.5144	.5144
Avg	.8309	.6899	.5925	.7265	.6595	.9796	.7659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134048 / TADHADGAON****Feeder No / Name : 201 / TADHADGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.2987	.3429	.362	.4668
2	.3429	.3429	.3018	.3429		.6468
3	.3772	.3429	.2957	.5144	.543	.7316
4	.3772	.3086	.2987	.5144	.543	.905
5	.2572	.2743	.3174	.5144	.724	.9745
6	.3429	.2743	.3142	.6859	.8145	.9536
7	.5144	.3086	.1109	.8573	.905	.9326
8	.1715	.2743	.1132	.8573	1.086	1.0059
9	.1715	.0857	.0924	.8573	1.086	1.0059
10	.1715	.0934	.1086			
11	.823	.7716	.8764			
12	.9431	.9945	.8764			
13	.9145	1.073	.964			
14	.9145	1.0322	.8764			
15	.884	.9717	.8764			
16	.9431	.8962	.8764	.0857	.1867	.2241
17	.9602	.8642	.7888	.0762	.2195	.2614
18	1.0117	.7522	.7011	.1829	.362	.3142
19	.5144	.2957	.3506	.2743	.543	.5121
20	.5144	.3734	.2629	.3429	.5487	.4938
21	.5144	.3547		.3429	.543	.4572
22	.5144	.3547	.3506	.3429	.543	.4024
23	.5144	.3174	.3506	.3429	.543	.4024
24	.3429	.5144	.3018	.3429	.362	.4668
Max	1.0117	1.073	.964	.8573	1.086	1.0059
Min	.1715	.0857	.0924	.0762	.1867	.2241
Avg	.5574	.5089	.4654	.4345	.5832	.6198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134048 / TADHADGAON****Feeder No / Name : 202 / PANGERKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.0288	1.1888	1.0288	1.086	1.6289
2	2.2291	2.0576	1.2757	1.0288	.8859	1.6289
3	2.4006	2.2291	1.4529	1.1145	.8859	1.448
4	2.572	2.572	2.0022	1.2003	.8859	1.448
5	2.915	2.915	2.1209	1.2003	.8859	1.267
6	3.0864	3.0864	2.3663	.1715	.8859	.724
7	2.572	3.2579	2.5206	.1715	.8859	.724
8	3.4294	3.6866	3.3753	.1524	.1772	.543
9	3.6008	3.3608	3.2007	.1524	.181	.543
10				.1524		.5068
11				3.2579	2.822	3.5099
12				3.6008	3.4705	3.5711
13				3.2769	3.3608	3.4145
14				3.4294	3.3265	3.2861
15				3.5361	3.3288	3.1017
16	.5144	.3772		3.4294	3.2941	2.9675
17	.5944	.5228		3.4294	3.0864	2.6322
18	.7773	.7095		2.8959	3.3484	2.3137
19	1.1831	1.6804		.8573	1.267	.9054
20		1.7187		1.0288	1.448	.9389
21	1.0288	1.6804		1.0288	2.3282	.9328
22	1.0288	1.5339		1.0288	2.3282	.8962
23	1.0288	1.3443		1.0288	2.1491	.8413
24	1.5432	1.7147	1.1888	1.0288	1.0631	1.6289
Max	3.6008	3.6866	3.3753	3.6008	3.4705	3.5711
Min	.5144	.3772	1.1888	.1524	.1772	.5068
Avg	1.8952	1.9709	2.0692	1.6346	1.8861	1.7251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134048 / TADHADGAON****Feeder No / Name : 203 / RUI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.7842	.4287	.724	.7392
2	.6859	.6859	.8215	.5144	1.267	1.6632
3	.7202	.6859	.8316	.6859	1.267	1.6461
4	.7716	.6859	.9145	.6859		1.829
5	.6859	.6859	.9511	.8573	1.267	2.1719
6	.6859	.6859	.9955	.8573	1.4022	2.3034
7	.6859	.6859	.5487		1.7528	2.332
8	.1715	.5144		2.1033	2.1033	2.4348
9	.1715	.1715	.439	2.2786	2.2786	2.431
10	.1715	.2772	.4557			
11	2.4006	1.7002	1.5775			
12	2.4006	2.0576	2.1033			
13	2.2405	2.0957	2.4006			
14	2.1338	2.0119	2.4006			
15	1.9814	1.8084	2.2291			
16	1.829	1.7284	2.1434	.2896	.1086	.2075
17	1.7528		2.0576	.3258	.1463	.2641
18	1.6613	1.8861	.8764	.543	.362	.4066
19	.6859	1.0269	.7011	.543	.543	.7392
20	.7716	1.0456	.7087	.724	.724	.7577
21	.7716	1.094	.7011	.724	.7602	.7023
22	.8573	1.0269	.5316	.724	.724	.6468
23	.8573	.8775	.5316	.724	.724	.5729
24	.8573	.6859	.7842	.3429	.724	.7392
Max	2.4006	2.0957	2.4006	2.2786	2.2786	2.4348
Min	.1715	.1715	.439	.2896	.1086	.2075
Avg	1.1099	1.0787	1.1517	.7854	.9928	1.2548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 201 / WATER SUPPLY****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0171	.0351
2	.0171	.0171	.0171	.0171	.0171	.0171	.0351
3	.0171	.0171	.0171	.0171	.0171	.0171	.0351
4	.0171	.0171	.0171	.0171	.0171	.0343	.0351
5	.0171	.0171	.0171	.0171	.0171	.0343	.0351
6	.0171	.0171	.0171	.0171	.0171	.0343	.0351
7	.0171	.0171	.0171	.0171	.0171	.0343	.0366
8	.0171	.0171	.0171	.0171	.0343	.0343	.0351
9	.0179	.0328	.0164	.0328	.0328	.0328	.0328
10	.0351	.0328	.0164	.0328	.0328	.0328	.0328
11	.0351	.0655	.0164	.0328	.0328	.0328	.0328
12	.0351	.0655	.0164	.0328	.3277	.0328	.0328
13	.0177	.0492		.0328	.0328	.0328	.0328
14	.0177	.0164	.0164	.0328		.0492	.0328
15	.0351	.0492	.0328	.0328	.0164	.0328	.0328
16	.0351	.0164	.0328	.0328	.0328	.0328	.0328
17	.0351	.0175	.0362	.0351	.0351	.0354	.0354
18	.0351	.0351	.0366	.0351	.0351	.0351	.0351
19	.0351	.0351	.0351	.0351	.0351	.0354	.0354
20	.0351	.0173	.0173	.0351	.0175	.0532	.0354
21	.0351	.0175	.0173	.0351	.0173	.0351	.0351
22	.0175	.0173	.0173	.0351	.0171	.0526	.0354
23	.0173	.0177	.0173	.0175	.0171	.0354	.0354
24	.0175	.0171	.6859	.0171	.0175		.0351
Max	.0351	.0655	.6859	.0351	.3277	.0532	.0366
Min	.0171	.0164	.0164	.0171	.0164	.0171	.0328
Avg	.0247	.0266	.0499	.0269	.0371	.0341	.0345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 202 / PATHARWALA - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.823	.9945	1.0288	.8916	.9602		
3	.9945	.9945	1.1317	.9259	1.0288		
4	1.0288	.9945	1.166	1.0288	1.0631		
5	1.0631	1.0288	1.2003	1.0631	1.1317		
6	1.0631	1.1317	1.2346	1.0974	1.166		
7	1.1831	1.2003	1.2517	1.1145	1.2346		
8		1.3032	1.3032	1.2517	1.2346		
9	1.1431	1.2407	1.1523	1.1405	1.1305		
11						1.0883	1.2654
12						1.3603	1.5893
13						1.4746	1.6409
14						1.5402	1.6549
15						1.4089	1.6385
16						1.4243	1.4899
17						1.3279	1.3904
18						1.2811	
23			.6859				
Max	1.1831	1.3032	1.3032	1.2517	1.2346	1.5402	1.6549
Min	.823	.9945	.6859	.8916	.9602	1.0883	1.2654
Avg	1.0427	1.1110	1.1283	1.0642	1.1187	1.3632	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 203 / S.PIMPLEGON AG 1

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						1.3375	1.2323
3						1.406	1.2944
4						1.5432	1.1288
5						1.6461	1.2955
6						1.6804	1.3283
7						1.6975	1.3603
8						1.7833	1.5074
9						1.7465	1.5939
11	1.8591	2.0856	2.1365	1.933	1.8991		
12	2.0309	2.1195	2.323	2.0687			
13	2.1348	2.2721	2.34	1.9669	1.9161		
14	2.1403			2.0008	1.933		
15	2.1559		2.0178	1.8652	1.9161		
16	2.0309	2.1704	2.1026	1.8313	1.8842		
17	2.0809	2.0957		1.5729	1.9662		
18		1.9845	1.8351	1.7604	1.7924		
Max	2.1559	2.2721	2.34	2.0687	1.9662	1.7833	1.5939
Min	1.8591	1.9845	1.8351	1.5729	1.7924	1.3375	1.1288
Avg	2.0618	2.1213	2.1258	1.8749	1.9010	1.6051	1.3426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 204 / GINING****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.0171	.0343	.1543	.1372	.0983
2	.1372	.1372	.0171	.0343	.1543	.1372	.1097
3	.1372	.1372	.0171	.0343	.1543	.1372	.0983
4	.1372	.1372	.0171	.0171	.1543	.1372	.1147
5	.1372	.1372	.0171	.0171	.1372	.1543	.1017
6	.1372	.1372	.0171	.0171	.1372	.1715	.1029
7	.1543	.1372	.0171	.0171	.0171	.1715	.004
8	.0171	.0514	.1543	.1543	.0171	.0171	.0886
9	.1772	.128	.1886	.2641	.008	.2195	.004
10	.1417	.1052	.1463	.2641	.004	.1829	.12
11	.1402	.1052	.1463	.2452	.1646	.1402	.1402
12	.1595	.1052	.1698	.2452	.004	.1402	.004
13	.1753	.004	.2075	.2452	.1646	.1402	.003
14	.1402	.004	.1463	.2452	.1463	.1402	.0034
15	.1433		.1463	.2641	.1417	.1402	.0034
16	.181	.004	.1463	.2452	.1402	.1402	.0034
17	.1629	.0044	.1448	.2561	.1463	.1612	.0175
18	.1448	.0044	.1254	.1417	.1448	.1629	.0177
19	.1086	.004	.1448	.1463	.0044	.1595	.0175
20	.1267	.0044	.004	.032	.0044	.1433	.0179
21	.1267	.0044	.0044	.128	.1463	.1254	.0177
22	.1463	.0044	.1267	.128	.1372	.0876	.0177
23	.1417	.004	.1629	.124	.1372	.0895	.0179
24		.1372	.0171	.12	.1463	.1372	.0857
Max	.181	.1372	.2075	.2641	.1646	.2195	.1402
Min	.0171	.004	.004	.0171	.004	.0171	.003
Avg	.1396	.0711	.0959	.1425	.1069	.1406	.0504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 205 / PATHARWALA(GAOTHAN)****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.1543	.1543	.1372	.1372	.1629
2	.1543	.1543	.1543	.1543	.1543	.1543	.1448
3	.1715	.1543	.1715	.1715	.1715	.1715	.181
4	.2058	.1715	.3258	.2058	.2058	.1715	.2172
5	.2401	.2058	.3258	.3258	.2401	.2401	.3109
6	.3429	.2743	.3429	.3772	.3429	.2401	.3841
7	.4458	.4115	.4458	.4458	.4115	.3601	.4805
8	.4115	.3601	.4287	.4287	.4458	.3086	.462
9	.3681	.3584	.3961	.3961	.415	.2926	.415
10	.333	.2561	.3109	.2926	.3292	.2561	.2743
11	.181	.1829	.2195	.2012	.1928	.1928	.1753
12	.1402		.2012	.1829	.2126	.2103	.1753
13	.1063		.1227	.1463	.1791	.12	.12
14	.1052			.1463	.1227	.1017	.1227
15	.1063			.1227	.1949	.1227	.1227
16	.124		.1829	.2195	.2149	.1578	.1578
17	.2172	.2172	.2715	.2378	.2195	.298	.1772
18	.3258	.3547	.3841	.362	.3475	.3506	.2804
19	.4024	.362	.3439	.3475	.3841	.3898	.362
20	.3077	.2686	.2715	.2743	.2743	.2172	.2804
21	.2353	.1829	.2012	.1829	.2195	.1753	.2126
22	.1646	.181	.1829	.1646	.1715	.1753	.1753
23	.1629	.1463	.1646	.1448	.1543	.1595	.1595
24	.1629	.1543	.1543	.1543	.1448	.1543	.1629
Max	.4458	.4115	.4458	.4458	.4458	.3898	.4805
Min	.1052	.1463	.1227	.1227	.1227	.1017	.12
Avg	.2320	.2395	.2617	.2433	.2452	.2149	.2382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134049 / SHAHAGAD

Feeder No / Name : 206 / MAHAKALA AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1145	1.1317	1.0631	.2743	1.0288		
3	1.1831	1.1488	1.0974	1.0631	1.0631		
4	1.2003	1.2003	1.166	1.0974	1.0974		
5	1.2346	1.2003	1.166	1.2003	1.166		
6	1.2689	1.2174	1.2003	1.2346	1.2003		
7	1.3717	1.2346	1.2003	1.2689	1.2346		
8	1.4575	1.3717	1.3375	1.2346	1.3032		
9	1.2811	1.3272	1.2944	1.1961	1.2125		
11						1.1523	1.1405
12						1.2643	1.3927
13						1.3603	1.3283
14						1.2811	1.3123
15						1.5203	1.2346
16						1.3763	1.2003
17						1.2811	1.0936
18							.7655
Max	1.4575	1.3717	1.3375	1.2689	1.3032	1.5203	1.3927
Min	1.1145	1.1317	1.0631	.2743	1.0288	1.1523	.7655
Avg	1.2640	1.229	1.1906	1.0712	1.1632	1.3194	1.1835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 207 / SHAHAGAD GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5658	.583	.6516	.6687	.5144	.5304
2	.5144	.6173	.6173	.6516	.6516	.5487	.4887
3	.6859	.6859	.6859	.6516	.6516	.6516	.724
4	.7545	.7888	.7545	.6859	.6859	.9259	.8507
5	.8573	.8916	.8573	1.0288	.7888	1.0288	1.0974
6	.9945	1.0631	1.1576	1.2346	.9945	1.2003	1.2803
7	1.0631	1.2346	1.1317	1.3032	1.2689	1.4403	1.4083
8	.9431	1.2346	1.166	1.5432	1.3203	1.3375	1.39
9	1.0517	1.3717	1.4449	1.5912	1.4632	1.3352	1.3717
10	1.0867	1.39	1.39	1.39	1.2803	1.262	1.2254
11		1.2071	1.4449	1.2254	1.0059	1.1706	.9568
12			1.2071	.9694	1.134	.8596	
13			1.134	.8596	.9145	.7796	
14	.1524		.8048	.8413	.788		
15			.9145	.9877	.9036	.9036	
16	1.3146		.9145	1.2437	1.0974	.9214	1.0608
17	1.4449			1.2308	1.2851	1.2269	1.2894
18	1.3937	1.4377	1.3937	1.3717	1.3535	1.262	1.4529
19	1.1946	1.3769	1.4661	1.0974	1.2254	1.2048	1.2254
20	1.0242	1.0242	1.2127	.8596	1.134	.8954	.9231
21	.7964	.8869	.9214	.8048	.9231	.7888	.8059
22	.724	.724	.8596	.6556	.7545	.6268	.6268
23	.6401	.695	.7682	.6219	.6859	.5609	.5731
24	.5304	.5658	.583	.6859	.6219	.5144	.543
Max	1.4449	1.4377	1.4661	1.5912	1.4632	1.4403	1.4529
Min	.1524	.5658	.583	.6219	.6219	.5144	.4887
Avg	.8832	.9867	1.0179	1.0078	.9834	.9548	.9912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 208 / S- PIPALGAO GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.8573	.583	.5487	.583	.724
2	.7545	.8916	.8916	.6173	.7202	.6516	.7783
3	.9259	.8916	.9259	.7202	.9945	.8573	.9145
4	1.0631	.9259	.9945	.6859	1.0974	.9945	1.0242
5	1.3203	1.0631	1.0631	1.2003	1.2003	1.2346	1.0425
6	1.4746	1.2346	1.2003	1.4403	1.3032	.8402	1.262
7	.7888	1.3717	1.4403	1.4403	1.3717	.9259	1.5746
8	.7888	1.3032	1.4746	1.3375	1.3032	.8573	1.4449
9	.8859	1.3575	1.3575	1.1946	1.267	1.2357	1.0924
10	.964	1.1946	.9955	1.1041	1.1041	.8954	.8238
11	.5609	.724	.724	.7164	.8059	.6447	.591
12	.5258	.5973	.5249	.5194		.4835	
13	.4557	.5792	.4887	.4477	.5731	.4477	.5014
14	.4382		.5068	.4298	.5373	.5014	.5281
15	.4252		.5249	.4298	.5552		.5658
16	.4557		.5973	.5731	.5731	.6268	.6224
17	.7421	.9328		.7964	.6878	.9816	.7442
18		1.448	1.0242	1.1706	1.1765	1.2971	1.2269
19	1.4083	1.4266	1.3213	1.0745	1.2071	1.2269	1.1517
20	1.267	1.3717	1.0454	.9145	1.0517	1.0166	1.0985
21	1.1946	1.267	.7602	.8048		.8859	.8059
22	1.0631	1.1157	.6697	.6584	.6516	.7087	.7522
23	.9412	.9412	.6283	.6335	.6173	.6201	.7164
24	.6878	.8573	.6859	.583	.567	.5658	.6335
Max	1.4746	1.448	1.4746	1.4403	1.3717	1.2971	1.5746
Min	.4252	.5792	.4887	.4298	.5373	.4477	.5014
Avg	.8616	1.0644	.9001	.8365	.9052	.8297	.8965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134049 / SHAHAGAD****Feeder No / Name : 209 / S.PIMPALGAON AG 2****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.8573	1.065
3						1.0288	1.0402
4						1.0631	1.0084
5						1.166	.9846
6						1.166	1.0595
7						1.166	1.0002
8						1.2517	1.1043
9						1.0467	1.1305
11	1.406	1.4089	1.4582	1.4255			
12	1.406	1.6549	1.491	1.3763			
13	1.3904	1.5524	1.5074	1.6057	1.3763		
14	1.3757	1.5364	1.4255	1.491	1.4255		
15	1.4074		1.491	1.5729	1.491		
16	1.3592	1.5364	1.4746	1.5402	1.4243		
17	1.2793	1.5249		1.4582	1.5074		
18		1.442	1.4118	1.1728	1.2342		
Max	1.4074	1.6549	1.5074	1.6057	1.5074	1.2517	1.1305
Min	1.2793	1.4089	1.4118	1.1728	1.2342	.8573	.9846
Avg	1.3749	1.5223	1.4656	1.4553	1.4098	1.0932	1.0491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134052 / SUKHAPURI****Feeder No / Name : 201 / SUKHAPURI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.4572	.4525	.4144	2.5339	.3696	.4382
2	.8383		.4525	.4239	2.572	1.086	.9945
3		.5487	.5258	.4096	2.6673	1.086	1.065
4		.6401	.5258	.4973	2.7435	1.086	1.1203
5		.7316	.6135	.5668	2.9531	1.5432	1.4746
6	1.0479	.905		.6773	2.8578	1.7604	1.8519
7		.823	.8413	.8278	2.9531	2.2672	2.4577
8		.823		.8278	3.0483	2.672	2.6558
9		.905	.8413	.9335	2.8578	2.5911	2.6406
10	2.3815			.7526	.4763		.7316
11	2.3815	1.9281		1.7833	.4763	.6401	.462
12	2.572		2.029	1.8404	.4763	.462	.3696
13	2.7625	2.2672	2.1691	1.8404	.4763	.3696	.3315
14	2.9531	2.0957	2.1948	1.9719	.4763	.3696	.3696
15	2.9531	2.1052	1.8404	2.0833	.4763	.3696	.4239
16	2.8578	2.1052	2.2939		.4763	.3391	.4239
17	2.3472	1.3717	2.0805			.4668	
18	2.1052	1.3527	2.0719		.7316	.6401	.6783
19	.823	.7011	.763		.7316	.6783	.6335
20	.6401	.6859	.5087		.5487	.5087	.6783
21		.6135	.5258		.5487	.4973	.6135
22	.4572	.5258	.4973		.4572	.4382	.5258
23	.4572	.3506	.5087		.3696	.4239	.5601
24		.4572	.362	.4239		.3696	.4239
Max	2.9531	2.2672	2.2939	2.0833	3.0483	2.672	2.6558
Min	.4572	.3506	.362	.4096	.3696	.3391	.3315
Avg	1.7653	1.0664	1.1049	1.0171	1.4504	.9145	.9532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 202 / BELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1148	.3658	.443	.462	.6668	.3696	.3734
2	2.191	.985	.7373	.8192	.6668	.462	.3696
3		1.0517	.8192	.9116	.6668	.462	.3734
4		1.0288	.9259	.9831	.7621	.5487	.462
5		1.1145	1.0155	1.0526	.7621	.5487	.5487
6	2.572	1.4575		1.326	.8573	.6401	.7392
7	2.5339	1.5432	1.0288	1.6385	.8573	.7316	.6535
8	2.3815	1.9281	1.1222	1.7204	.8573	.462	.7316
9	2.0957	1.9281		1.6385	.7621	.462	.6535
10	.8383	.3696	.5258	.4668	.6668	.3696	.3734
11	.5716	.1848		.362	2.0005	1.2003	1.4918
12	.2096	.1848	.1867	.1867	2.0005	1.6289	1.7204
13	.0953	.0924	.1867	.1867	2.0005	1.086	1.9062
14	.0953			.1867	2.0957	1.0745	1.9062
15	.0953			.1867	2.191	1.7604	1.6575
16	.0953				2.2862		1.8023
17	.1848				1.6289	1.7204	
18	.6401		.7392		.8907	1.4403	1.3146
19	.5487	.7011	.7392		.7316	.6468	1.166
20	.5487	.7888	.6468		.6401	.6535	.7545
21	.5487	.6135	.6535		.5487	.5544	.6068
22	.5487	.6135	.5601		.5487	.5487	.5258
23	.5487		.5544		.462	.5601	.543
24		.5487	.4525	.5601		.3658	.462
Max	2.572	1.9281	1.1222	1.7204	2.2862	1.7604	1.9062
Min	.0953	.0924	.1867	.1867	.462	.3658	.3696
Avg	.9729	.8611	.6669	.7930	1.1109	.7955	.9189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134052 / SUKHAPURI

Feeder No / Name : 203 / WADIKALYA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1148	.7316	.6001	.5544	.2858	.5544	.1867
2	2.1148	1.1641	.8097	.9326	.2858	.5487	.1867
3		1.1393	.9374	.9116	.381	.5487	.1867
4		1.2003	1.0288	.9831	.4191	.5487	.1848
5	2.191	1.3717	1.0974	1.2289	.4191	.5487	.2772
6		1.5432		1.406	.4763	.5487	.2743
7	2.191	1.6289	1.166	1.7814	.4191	.6401	.2801
8	2.3815	2.1052	1.6004	1.8623	.4191	.2772	.2801
9	2.191	2.1052		1.8023	.2858	.2772	.2801
10	.2858	.1848	.6135	.1867	.2858	.1848	
11	.1905	.0924		.1867	2.0957	1.5432	.763
12	.2096	.1848	.0934	.0934	2.0005	.6401	.9326
13	.0953	.0924	.0934	.0934	2.2862	.905	
14	.0953	.0924	.0934	.0934	2.3815	.905	.9326
15	.0953	.0924	.0934	.0934	2.5339	.905	.9012
16	.0953	.0924	.0934		2.3815	.7373	1.0174
17	.0924	.1867	.0934		1.9281	.8288	
18	.7316	.6335	.5544		1.6289	.7459	.9717
19	.905	.8192	.7468		.7316	.3734	.8383
20	.905	.7716	.7392		.7316	.3734	.5068
21	.905	.7011	.7468		.6401	.3696	.362
22	.905	.7011	.7392		.6401	.3734	.362
23	.905		.6535		.5487	.3696	.362
24		.905		.6468		.5487	.2801
Max	2.3815	2.1052	1.6004	1.8623	2.5339	1.5432	1.0174
Min	.0924	.0924	.0934	.0934	.2858	.1848	.1848
Avg	.9800	.8061	.6297	.8035	1.0524	.5957	.4936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 201 / HASNAPUR AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0381	.0572		.421	.4001
2	.0343	.0572	.0572	.0572	.0514	.631	.4184
3		.0572	.0572	.0572		.6763	.4371
4						.7305	.4561
5						.6996	.4755
6						.6763	.4954
7						.727	.8745
8						.7613	1.0364
9						.8383	.9555
11	.9587		.9717		1.0517		
12	1.0551		1.1336	1.2346	1.0974		
13	1.2037		1.4089		1.0802		
14	1.2346		1.4413	1.2689	1.0364		
15	1.2191		1.3765		1.0802		
16	1.2037		1.2631	1.2346	1.0957		
17	1.2498		1.1822		1.1265		
18			1.1012	1.2346	1.1561	.0572	.0572
19	.0572		.0191	.0343	.0572		.0572
20	.0572		.0191	.0514	.0572	.0572	.0572
21	.0572				.0572	.0572	.0572
22	.0572		.0381	.0514	.0572	.0572	.0572
23	.0572		.0381	.0514	.0572	.0572	.0572
24	.0343		.6859	.0572	.0514	.0572	
Max	1.2498	.0572	1.4413	1.2689	1.1561	.8383	1.0364
Min	.0343	.0572	.0191	.0343	.0514	.0572	.0572
Avg	.6057	.0572	.6770	.4492	.6075	.4336	.3928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134053 / GONDI****Feeder No / Name : 202 / GHUNGARDE HADGAON AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6447	.664	.8907		.5544	.2305
2	.7716	1.1393	.9555	1.0688	.8573	.6535	.2715
3		1.2536	1.0526	1.1336		.7095	.3429
4	.8573	1.2715	1.1336	1.166	1.2003	.7468	.4582
5		1.3253	1.1498	1.2146		.7655	.6001
6	1.0288	1.2894	1.1984	1.2308	1.2346	.9522	.6668
7		1.3432	1.1498	1.2308		.9896	
8	1.1145	1.3969	1.2146	1.2631	1.2346	1.0082	
9	1.1145	1.4148	1.1012		1.0715	.6573	
10			.7611	.6687	.5729	.5144	
11	.6468		.5668		.4435	.6573	
12	.5175		.4858	.4801	.3511	.743	
13	.4435		.3725		.3326	.7335	
14	.3326		.3887	.3258	.3142	.7188	
15	.3511		.4049		.3511	.5868	
16	.3881		.421	.4801	.4435	.6001	
17	.462		.4534		.5359	.8688	
18			.6478	.6859	.7468	.9145	
19	.5729		.5668	.7716	.6535	.4334	
20	.6283		.5182	.7545	.6348	.3544	
21	.6653				.5788	.3086	
22	.5544		.4049	.6859	.5359	.2858	
23	.462		.4534	.6859	.462	.2743	
24	.5144	.4435		.4534		.2401	
Max	1.1145	1.4148	1.2146	1.2631	1.2346	1.0082	.6668
Min	.3326	.4435	.3725	.3258	.3142	.2401	.2305
Avg	.6348	1.1522	.7302	.8439	.6608	.6363	.4283

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134053 / GONDI

Feeder No / Name : 203 / GONDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.337	.5668	.5668		.0381	.0381
2	.0857	.4193	.583	.6154		.0381	.0381
3		.4599	.664	.6478	.6001	.0381	.0381
4	.0343	.5357	.6802	.6478	.6859		
5		.5944	.6964	.664			
6	.1372	.6636	.7611	.6802	.8573		
7		.6944	.7773	.6802	.9431		
8	.1715	.6481	.7287	.7287	.9431		
9	.2058	.6944	.8097		.771		
11						.4087	.1619
12						.5335	.1943
13						.5898	.1943
14						.5563	.2267
15						.3715	.2429
16						.3658	.2591
17						.4087	.2591
18			.0381	.0171	.0381	.241	.2591
19	.0381		.0381	.0171	.0381	.0381	.0572
20	.0381		.0381	.0171	.0381	.0381	.0381
21	.0381				.0381	.0381	.0381
22	.0381		.0381	.0171	.0381	.0381	.0381
23	.0381		.0572	.0171	.0381	.0381	.0381
24	.0171	.0381		.0572	.0171	.0381	
Max	.2058	.6944	.8097	.7287	.9431	.5898	.2591
Min	.0171	.0381	.0381	.0171	.0171	.0381	.0381
Avg	.0766	.5085	.4626	.3838	.3882	.2246	.1326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134053 / GONDI****Feeder No / Name : 204 / KARNJALA AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.9145
2						.9259
3					.9728	.953
4					1.1265	.9962
5					1.2323	1.0526
6					1.1843	1.0814
7					1.2003	1.2146
8					1.3108	1.2631
9					1.3108	1.1984
11	1.2037	.8907	1.5432	1.2037		
12	1.2963	.9717		1.4737		
13	1.3603	1.0202	1.286	1.4529		
14	1.5844	1.1012		1.5203		
15	1.5684	1.2146	1.8004			
16	1.5524	1.2955		1.5524		
17	1.5844	1.3927	1.6289	1.4506		
18		1.3765	1.5432	1.5203		
Max	1.5844	1.3927	1.8004	1.5524	1.3108	1.2631
Min	1.2037	.8907	1.286	1.2037	.9728	.9145
Avg	1.4500	1.1579	1.5603	1.4534	1.1911	1.0666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134053 / GONDI****Feeder No / Name : 205 / HASNAPUR GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134054 / EKLAHARA****Feeder No / Name : 201 / KARANJALA AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134054 / EKLAHARA****Feeder No / Name : 202 / BHARDI AG
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134054 / EKLAHARA****Feeder No / Name : 203 / EKLAHARA AG.****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134054 / EKLAHARA****Feeder No / Name : 204 / EAKLAHARA GACTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134055 / SHEVGA****Feeder No / Name : 201 / HARATHKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.3239	.3239	.2858	.2858	.2591	.3239
2	1.085	1.1431	1.5242	1.2003	1.3336	.2753	.3239
3	1.1498	1.3336	1.5242	1.2384	1.5242	.2753	.3239
4	1.166	1.3336	1.4289	1.2574	1.0098	.3401	.381
5	1.166		1.5432	1.4289	1.7147	.421	.6478
6	1.1984		1.6766	1.4098	1.7528	.5182	.7811
7	1.2146		1.8099	1.6004	1.829	.664	.7049
8	1.1498		1.829	1.7147	1.8099		.6668
9	1.0526		1.6385	1.6385	1.3146		.5716
10	.3429		.4382	.2858	.4954		.362
11			.2858	.2858	.3239		1.6956
12	.2096		.1905	.1905	.1781		1.7718
13	.1905		.2096	.1905	.1457		1.6385
14	.1715	.2286		.2096	.1296		1.7909
15	.1715	.2286		.1905	.1457		
16	.1905	.2667		.2286	.218		1.1812
17			.3048	.3239	.3239	1.2003	1.086
18	.5335	.6668		.6478	.4534	1.4289	1.0479
19	.6668	.6668	.381	.6097	.5344	.6287	.4763
20	.5335	.4572	.4382	.5144		.5716	.4382
21	.362	.362	.4763	.4572	.3239	.381	.381
22	.3429	.362	.4763	.3239	.2591	.3429	.3239
23	.3239	.362	.381	.3239	.2591	.3239	.3429
24	.2753	.3239	.3239	.362	.2858	.2591	.3239
Max	1.2146	1.3336	1.829	1.7147	1.829	1.4289	1.7909
Min	.1715	.2286	.1905	.1905	.1296	.2591	.3239
Avg	.6260	.5756	.8602	.7049	.7239	.5260	.7646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134055 / SHEVGA****Feeder No / Name : 202 / SHEVGA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.362	.3429	.5716	.2858	.2915	.3429
2	1.3279	1.6004	1.9052	1.3336	1.9052	.2753	.3429
3		2.0957	1.9052	1.3527	2.0957	.3521	.3429
4		.3429	2.1529	1.3717	1.5242	.3887	.4191
5	1.7814		2.3053	1.5242	1.9052	.4858	.6097
6	1.9109		2.3624	1.7147	2.0957	.5182	.7621
7	2.17	.3239	2.4768	2.2862	2.2862	.6316	.724
8	2.0081		2.6673	2.3053	2.2862		.7049
9	1.9271		2.1338		2.21		.5335
10	.4191		.5525	.2858	.4191		
11	.2667		.3239	.3048	.2429		1.9052
12	.2667		.3429	.2667	.1781		2.4006
13	.1905		.2286	.2667	.1619		2.4387
14	.1905	.2667	.2286	.2667	.2105		2.2672
15	.1905	.2667		.2858	.2267		2.4006
16	.2096	.2858		.3048	.218		2.1338
17	.3239	.4382	.4191	.4382	.3887	1.6004	1.8671
18	.6287	.8002	.6668	.6859	.502	2.0576	1.7147
19	.6668	.6097	.5716	.6478	.5992	.6287	.6859
20	.5525	.4954	.4191	.5716	.3563	.5335	.4763
21	.3429	.381	.4763	.4572	.3887	.4572	.4382
22	.3239	.362	.381	.362	.2915	.4382	.3429
23		.362	.4001	.3048	.2753	.381	.3239
24	.2591	.3239	.3429	.4763	.2858	.2753	.3429
Max	2.17	2.0957	2.6673	2.3053	2.2862	2.0576	2.4387
Min	.1905	.2667	.2286	.2667	.1619	.2753	.3239
Avg	.7722	.5823	1.0730	.7994	.8891	.6210	1.0661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134055 / SHEVGA****Feeder No / Name : 203 / DHANGAR PIMPRI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.3239	.3048	.381	.2667	.2429	.2858
2	.2753	.3239	.2858	.2858	.2667	.7449	.9526
3	.2753	.3239	.2858	.2858	.2667	.7935	.9907
4	.2915	.3239		.3429	.2667	.8745	1.0288
5	.3401			.362	.3429	1.004	1.2765
6	.3887				.4763	1.3603	1.6194
7	.5182				.6097	1.4413	1.6575
8	.421				.4763		1.7147
9	.3887		.381	.2858	.3048		1.7528
10	.3239		.4382	.4763	.2477		
11	1.848		1.8671	1.9052	1.4413		
12	2.5149		2.2862	2.4006	1.6842		.2286
13	2.3434		2.1338	2.3053	2.0567		.1905
14	2.3624	2.3815		2.6292	2.1052		.1715
15	2.3624	2.6292	2.1338	2.572	1.9109		.1524
16	2.4387	2.5911		2.553	2.0243		.1715
17	2.4387	2.553	1.6385	2.3243	1.9109	.3239	
18	2.191	2.3815	1.8861	2.1529	1.7166		.4763
19	.5144	.4954	.4001	.4572	.421	.5525	.4572
20	.4763	.4001	.381	.4191	.3239	.4572	.4001
21	.3239	.3239	.3429	.381	.2915	.362	.381
22	.3239	.3239	.2858	.3048	.2753	.3429	.3048
23	.3239	.3239	.3239	.3048	.2429	.2858	.2858
24	.2753	.3239	.3239	.4001	.3048	.2429	.3048
Max	2.5149	2.6292	2.2862	2.6292	2.1052	1.4413	1.7528
Min	.2753	.3239	.2858	.2858	.2429	.2429	.1524
Avg	1.0098	1.0682	.9235	1.1204	.8431	.6449	.7049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134055 / SHEVGA****Feeder No / Name : 204 / DATA AGRO EXPRESS****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0572	.0381	.0381	.0381	.0324	.0762
2	.0648	.0572	.0381	.0381	.0381	.0324	.0762
3	.0324	.0572	.0381	.0381		.0324	.0762
4	.0486	.0572	.0381	.0381	.0381	.0324	.0762
5	.0486		.0572	.0381	.0381	.0324	.0762
6	.0486		.0572	.0381	.0381	.0324	.0762
7	.0486		.0572	.0381	.0381	.0324	.0762
8	.0486		.0381	.0381	.0381		.0762
9	.081		.0381	.0381	.0381		.0762
10			.0572	.0381	.0381		.0381
11	.0572		.0572	.0381	.0324		.0381
12	.0572		.0572	.0381	.0324		.0381
13	.0572		.0381	.0381	.0324		.0381
14	.0572	.0381		.0381	.0324		.0381
15	.0572	.0572		.0572	.0324		.0381
16	.0572	.0572		.0572	.0324		.0381
17	.0572	.0572	.0572	.1905	.0324	.0381	.0381
18	.0381	.0762	.0381	.0572	.0486	.0381	.0381
19	.0381	.0381	.0381	.0381	.0324	.0762	.0381
20	.0381	.0381	.0381	.0381	.0324	.0762	.0381
21	.0381	.0381	.0381	.0381	.0324	.0572	.0191
22	.0381	.0762	.0381	.0381	.0324	.0572	.0572
23	.0572	.0762	.0381	.0381	.0324	.0762	.0381
24	.0486	.0572	.0762	.0381	.0381	.0324	.0762
Max	.081	.0762	.0762	.1905	.0486	.0762	.0762
Min	.0324	.0381	.0381	.0381	.0324	.0324	.0191
Avg	.0500	.0559	.0463	.0468	.0356	.0452	.0540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134072 / KARJAT****Feeder No / Name : 201 / 11 KV KARJAT-BHAYGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716		.5716	.5716	.5716	.5716
2	1.3336	1.5242		2.191	1.7147	.5716	
3	1.5432	1.9052		2.6673	2.0957	.5716	
4	1.6194	2.4768		3.4294	2.4768	.6097	
5	2.7816			2.7625	2.8578	.6668	
6	3.2388			2.4768	3.4294	.7621	
7	3.7151			3.4294	3.8104	.7621	
8	3.7532			3.9057	3.9057	.6668	
9	1.7147	3.1436		3.6199	3.4294	.5716	
10	.381	.5716	.5335	.5716	.5716	.5716	1.1431
11	.4191	.5716	.5716	.4763	.4763	2.572	2.1548
12	.381	.5716	.6668	.4191	.4382	3.1436	
13	.381	.381	.381	.4191	.4191	3.3341	2.3777
14	.381		.4763	.381	.4191	3.4294	2.452
15	.4191	.381	.6668	.381	.381	3.5437	2.4383
16	.381	.381	.5716	.381	.381	3.4294	2.2878
17	.4763	.381	.5716	.4191	.4763	3.0483	2.1994
18	.6668	.381	.5716	.5335	.6097	3.0483	2.0805
19	.7621	.7621	.4763	.7621	.8002	.7621	.8573
20	.8002	.7621	.381	.7621	.7621	.6668	.8573
21	.7621	.6668	.4763	.724	.724	.5716	
22	.6668			.6668	.6668	.5716	.6668
23	.6097		.5716	.5716	.5716	.5716	.5716
24	.5716	.5716	.6859	.5716	.5716	.5716	.5716
Max	3.7532	3.1436	.6859	3.9057	3.9057	3.5437	2.452
Min	.381	.381	.381	.381	.381	.5716	.5716
Avg	1.1820	.9414	.5430	1.3789	1.3567	1.4829	1.5164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134072 / KARJAT****Feeder No / Name : 202 / 11 KV KARJAT-A****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.4763
3						.4763
4						.5716
5						.6668
6						.7621
7						.8573
8						.9526
9						.9145
11	.8573	.9907	.9526	.7621	.7621	
12	1.105	.9907	1.0479	1.105	.9907	
13	1.4289	1.0479	1.1431	1.105	1.0479	
14	1.3336		1.1431	1.0479	1.0479	
15	1.3336	1.0479	.9526	.9907	.9907	
16	1.2384	1.1431	.9526	1.0479	.9907	
17	1.2384	1.0479	1.0479	.9907	.9526	
18	1.1431	1.1431	.9526	.8954	.8573	
24			.6859			
Max	1.4289	1.1431	1.1431	1.105	1.0479	.9526
Min	.8573	.9907	.6859	.7621	.7621	.4763
Avg	1.2098	1.0588	.9865	.9931	.9550	.7097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134072 / KARJAT****Feeder No / Name : 203 / 11 KV DHANGAR PIMPALGAON SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858		.381	.2858	.2858	.2858
2	.381			.2858	.2858	.5716	
3	.4191	.2858		.381	.2858	.5716	
4	.3048	.3429		.381	.2858	.6668	
5	.3429	.381		.6668	.3429	.8573	
6	.381	.4763		.381	.381	1.0479	
7	.381	.5716		.5716	.4763	1.2384	
8	.381	.4763		.4763	.4763	1.4289	
9	.4191	.381		.381	.381	1.3336	
10	.2858	.2858	.362	.2858	.2858		
11	1.105	1.0669	.743	.9907	1.0479		.4763
12	1.4861		1.1431	1.4289	1.4289		
13	1.6194	1.4289	1.5242	1.5242	1.4289	.1905	.381
14	1.5623		1.5242	1.4861	1.4289	.1905	.381
15	1.5623	1.5242	1.3336	1.4289	1.3717	.1905	.3429
16	1.5242	1.5242	1.3336	1.4289	1.3336	.1905	.381
17	1.5242	1.5242	1.2384	1.3908	1.3336	.2858	.4763
18	1.3336	1.5242	1.4289	1.3336	1.2384	.381	.6668
19	.4191	.5716	.2858	.381	.381	.381	.6668
20	.5335		.381	.4763	.4763	.381	.6668
21	.4763	.6668	.1905	.4191	.4191	.2858	
22	.381		.1905	.381	.2858	.2858	.4763
23	.381		.2858	.381	.2858	.2858	.381
24	.3239	.3429	.6859	.2858	.3429	.2858	.2858
Max	1.6194	1.5242	1.5242	1.5242	1.4289	1.4289	.6668
Min	.2858	.2858	.1905	.2858	.2858	.1905	.2858
Avg	.7462	.7589	.8434	.7303	.6787	.5398	.4514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 134074 / Chandanapuri****Feeder No / Name : 201 / CHANDANAPURI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.2054	.2241	.2241	.3361	.2427	.5041
2	.583	.2241	.2241	.2241	.3547	.3547	.5601
3	.6516	.2614	.2987	.2614	.3921	.4481	.5975
4	.6344	.3734	.4108	.3734	.4294	.5228	.6348
5	.6516	.4481	.5975	.5975	.4854	.6161	.6722
6	.6859	.5415	.7095	.7468	.5788	.6908	.6908
7	.7202	.6535	.7468	.8962	.6348	.7842	.7468
8	.7373	.6908	.7468	.6722	.6722	.8589	.7842
9	.6859	.7095	.7282		.5788	.7468	.7282
10	.4801	.5041	.5601	.5415	.4854	.5228	.5975
11	.3361	.3361	.3734	.2801	.2987	.4481	.4854
12	.2427	.2427	.2801	.2427	.2614	.2427	.3174
13	.1867	.1867	.2241	.2241	.2054	.2241	.2987
14	.1867	.1867	.2054	.2614	.2427	.3361	.3174
15	.2241	.2241	.2241	.3361	.2614	.3734	.2427
16	.2801	.2801	.2614	.3921	.3174	.5041	
17	.3921	.3734	.4481	.5228	.4481	.5415	.5975
18	.6722	.6535	.7655	.6161	.5415	.5601	.6722
19	.6348	.6348	.6535	.7468	.6722	.6908	.6722
20	.5228	.4481	.4108	.6908	.5788	.6348	.5601
21	.4108	.3734	.2987	.5788	.5228	.5228	.3734
22	.3361	.2801	.2614	.4854	.3547	.4854	.3361
23	.2614	.2614	.2614	.3921	.2987	.3734	.3174
24		.2241	.2241	.2241	.3361	.2427	.3174
Max	.7373	.7095	.7655	.8962	.6722	.8589	.7842
Min	.1867	.1867	.2054	.2241	.2054	.2241	.2427
Avg	.4811	.3882	.4224	.4579	.4287	.4987	.5228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

AMBAD (R) S/DN[409] BU 2747

Substation No/ Name :- 134074 / Chandanapuri

Feeder No / Name : 202 / BHAMBERI-AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4572	.4877	.5182	.5792	.5335	.5182
3		.4572	.4877	.5182	.6249	.5639	.5487
4		.4572	.5182	.5182	.6859	.5944	.5944
5		.5335	.5487	.5487	.7926	.6554	.6401
6		.5335	.5639	.5792	.823	.6859	.6706
7		.5639	.5792	.6097	.884	.7316	.7164
8		.6097	.6249	.7468	.8688	.7621	.7316
9		.6249	.6249	.7621	.7773	.7773	.7011
11	.8535						
12	.884						
13	.9145						
14	.9145						
15	.9145						
16	.9145						
17	.8688						
18	.7621						
Max	.9145	.6249	.6249	.7621	.884	.7773	.7316
Min	.7621	.4572	.4877	.5182	.5792	.5335	.5182
Avg	.8783	.5296	.5544	.6001	.7545	.6630	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409] BU 2747****Substation No/ Name :- 134074 / Chandanapuri****Feeder No / Name : 203 / CHURMAPURI-AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.6097	.6401	.6706	.7011	.5792	.7164
3		.6097	.6401	.6706	.7468	.6554	.823
4		.6859	.6859	.7621	.7773	.6859	.884
5		.7316	.7621	.7621	.884	.7468	.9145
6		.7926	.7773	.7926	.945	.823	.9602
7		.8535	.884	.7926	1.0822	.884	1.0212
8		.9145	.9145	.9755	1.1279	.9602	.9907
9		.945	.8383	.9602	1.0669	.9145	.9755
11	1.0364						
12	1.1736						
13	1.1888						
14	1.1888						
15	1.1888						
16	1.1888						
17	1.1888						
18	1.0364						
Max	1.1888	.945	.9145	.9755	1.1279	.9602	1.0212
Min	1.0364	.6097	.6401	.6706	.7011	.5792	.7164
Avg	1.1488	.7678	.7678	.7983	.9164	.7811	.9107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****AMBAD (R) S/DN[409]****BU 2747****Substation No/ Name :- 137004 / 132/33 KV SUB-STATION AMBAD****Feeder No / Name : 403 / 33 KV SUTGIRNI FEEDER****NON SHEDDABLE EXPRESS HV FEEDERS****Feeder KV- 33 / OUTGOING****(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134009 / GHANSAWANGI****Feeder No / Name : 201 / 11KV BOLEGAON FDR****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3772	.381	.4763	.5716	.4715	2.4768
2	2.2291	2.0957	2.2862	.8573	1.5432	.4715	.5716
3	2.4006	2.0957	2.8578	***	1.5432	.5601	.381
4	2.4006	2.1795	2.8578	1.3336	1.5432	.8402	.381
5	2.7435	2.3472	3.0483	1.5242	1.7147	.9335	.5716
6	2.7435	2.652	3.0483	1.5242	1.8861	.9335	.5716
7	1.7147	2.652	3.2388	1.5242	1.7147	1.1088	.7621
8	1.3717	2.4863	3.4294		1.0288	.9335	.7621
9	1.2003	2.5149	2.915		1.0288	.5601	.7621
10	.5716	.4715	.5716		.381	.381	.5716
11	.3772	.381	.2858		.2829	.381	.5716
12	.2829	.381	.381		.2829	.381	.381
13	.2829	.381	.381	.2858	.2829	.381	.381
14	.2829	.381	.381	.2858	.2829	.4763	.2858
15	.2829	.381	.381	.2858	.3772	.381	.2858
16	.3772	.5716	.381	.381	.3772	.4763	.2858
17	.4715	.5716	.4763	.5716	.4715	.5716	.5716
18	.5601	.9526	.9526	.9526	.6535	2.8578	3.1436
19	.8402	.9526	.7621	.9526	.9335	3.0483	3.0483
20	.7468	.7621	.7621		.924	3.0483	2.8578
21	.7468	.7621	.7621	.7621	.7468	3.2388	2.8578
22	.5601	.5716	.7621	.7621	.7468	3.0483	2.8578
23	.3772	.5716	.5716	.5716	.5601	2.6673	2.8578
24	.5716	.3772		.5716	.5716	.4715	2.6673
Max	2.7435	2.652	3.4294	12.3838	1.8861	3.2388	3.1436
Min	.2829	.3772	.2858	.2858	.2829	.381	.2858
Avg	1.0215	1.1613	1.3858	1.4448	.8520	1.1926	1.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134009 / GHANSAWANGI****Feeder No / Name : 202 / 11KV MCHINCHOLI FDR SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7468	.7621	.7621	.7621	.7468	.7621
2	.7621	.7468	.7621	.7621	.7621	1.6766	2.2862
3	.9526	.9335	.7621	.9526	.9526	1.6766	2.2862
4	1.1431	1.1088	.9526	1.1431	1.1431	1.8442	2.8578
5	1.2384	1.2012	1.1431			2.0957	2.8578
6						2.2634	2.8578
7						2.3472	2.4768
8						2.5987	2.8578
9				.8573		2.5149	3.2388
10	2.572	2.431	2.4006	2.8578	2.4006		
11	2.5987	2.7435	2.8578	2.7435	2.5149	.7621	.7621
12	2.6825	2.7435	3.1436	2.7435	2.5149	.5716	.7621
13	2.6825	2.7435	3.1436	2.6578	2.431	.5716	.6668
14	2.6825	2.572	3.1436	2.4863	2.5149	.5716	.5716
15	2.1795	2.0576	2.6673	1.9719	2.0119	.6668	.5716
16	2.0957	2.2291	2.6673	1.9719	1.8442	.7621	.7621
17	2.1795	2.2291	2.572	2.1434	1.8442	.7621	1.0479
18	2.1795	2.2862	2.2862	1.9719	1.9281	1.1431	1.2384
19	2.0119	2.2862	2.2862	1.8861	1.6766	1.2384	1.1431
20	1.2136	1.1431	1.1431	1.1431	1.1088	1.2384	1.0479
21	.9335	1.1431	.9526	.9526	.9335	1.1431	.9526
22	.8402	1.1431	.9526	.9526	.8402	.9526	.9526
23	.7468	.9526	.8573	.9526	.7468	.7621	.7621
24	.7621	.7468	.9526	.7621	.7621	.7468	.7621
Max	2.6825	2.7435	3.1436	2.8578	2.5149	2.5987	3.2388
Min	.7468	.7468	.7621	.7621	.7468	.5716	.5716
Avg	1.6609	1.7094	1.8204	1.6337	1.5628	1.2894	1.4993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134009 / GHANSAWANGI****Feeder No / Name : 203 / 11KV GHANSAWANGI FDR SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8402	.9526	1.1431	.7621	.7468	.7621
2	1.7147	1.9281	2.2862	1.1431		.7468	.7621
3	1.8861	2.0957	2.4768	1.1431	1.7147	.9335	.9526
4	2.2291	2.0957	2.8578	1.1431	2.2291	1.0269	1.1431
5	2.2291	2.3472	2.8578	3.2388	2.2291	1.1088	1.1431
6	2.572	2.5692	3.0483	3.4294	2.572	1.2012	1.2384
7	2.6578	2.7349	3.4294	3.4294	2.4006	1.2012	
8	3.1722	2.9007	3.4294	3.5246	2.7435	1.2012	
9	3.0864	2.9835	2.915	3.2388	2.8292		
10	1.1431		1.1431	1.2384	1.1431	1.3336	1.2384
11	1.1088	1.1431	1.2384	1.2384	1.1088	1.7147	2.2862
12	1.1088	1.1431	1.2384	1.3336	1.2012	2.7435	2.4768
13	1.1088	1.1431	1.2384	1.1431	1.2012	2.7435	3.0483
14	1.1088	1.3336	1.2384	1.1431	1.2012	2.572	2.8578
15	1.1088	1.1431	1.2384	1.2384	1.2012	2.572	3.0483
16	1.2012	1.2384	1.2384	1.2384	1.2012	2.7435	3.4294
17	1.2012	1.3336	1.2384	1.2384		2.7435	2.8578
18	1.2936	1.3336	1.2384	1.3336	1.2012	2.8578	2.3815
19	1.2936	1.2384	1.2384	1.3336	1.2012	1.2384	1.1431
20	1.2936	1.2384	1.2384	1.2384	1.2012	1.2384	1.1431
21	1.2012	1.1431	1.1431	1.2384	1.1088	1.1431	1.1431
22	1.0269	1.1431	1.1431	.9526	.9335	.9526	1.1431
23	.9335	.9526	1.1431	.9526	.8402	.9526	1.0479
24	.9526	.8402	.9526	1.1431	.7621	.8402	.9526
Max	3.1722	2.9835	3.4294	3.5246	2.8292	2.8578	3.4294
Min	.7621	.8402	.9526	.9526	.7621	.7468	.7621
Avg	1.5581	1.6027	1.7568	1.6432	1.4994	1.5894	1.7238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134009 / GHANSAWANGI****Feeder No / Name : 204 / 11KV TANUWADI FDR
Feeder KV- 11 / OUTGOING****SINGLE PHASING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.3772		.4763	.381	.3772	.381
2	.2858	.3772		.381		1.5775	1.5242
3	.2858	.3772		.381	.381	1.8004	1.5242
4	.2858	.4715		.381	.381	1.9719	1.9052
5	.381	.5601		.381	.5716	2.1434	1.9052
6	.5716	.6535		.381	.5716	2.3472	2.2862
7	.7621	.7468		.381	.7621	2.3472	2.2862
8	.7621	.6535		.5716	.5716	2.431	2.2862
9	.381	.3772	.5716	.5716	.381	2.5149	2.2862
10	2.0576	2.7349	2.8578	2.8578	1.8861	.381	.5716
11	2.9835	3.0864	2.7625	2.572	2.0957	.381	.5716
12	2.6825	2.915	2.2862	2.572	2.431	.381	.381
13	2.6825	3.2388	2.2862	3.0864	2.4863	.381	.381
14	2.7349	2.7435	2.8578	2.572	2.4863		.2858
15		2.572	2.8578	2.572	2.4863		.2858
16	2.5987	2.8578	2.8578	2.572		.381	.381
17	2.6825	2.6673	2.8578	2.4006	2.4863	.5716	.5716
18	.6535	.5716	.7621	.7621	.6535	.5716	.7621
19	.7468	.5716	.7621	.7621	.8402	.7621	.7621
20	.7468	.7621	.7621	.5716	.7468	.5716	.7621
21	.5601	.5716	.7621	.5716	.5601	.5716	.5716
22	.3772	.5716	.7621	.4763	.4715	.381	.5716
23	.3772	.381	.5716	.4763	.3772	.381	.5716
24	.2858	.3772	1.829	.5716	.381	.3772	.381
Max	2.9835	3.2388	2.8578	3.0864	2.4863	2.5149	2.2862
Min	.2858	.3772	.5716	.381	.3772	.3772	.2858
Avg	1.1379	1.3007	1.7754	1.2209	1.1086	1.0729	1.0082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134009 / GHANSAWANGI****Feeder No / Name : 205 / 11 KV BOLEGAON 2****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.8442	2.2862	1.9052	1.7147	1.7147	.381
2	.381	.4715	.381	.381	.381	.4715	.381
3	.381	.3772	.381	.381	.381	.3772	.381
4	.381	.4715	.5716	.381	.381	.5658	.381
5	.5716	.5601	.5716	.381	.381	.6535	.381
6	.5716	.7468	.5716	1.7147	.5716	.7468	.381
7	.7621		.5716	.381	.7621	.7468	.381
8	.7621	.5601	.5716	.5716	.7621	.5601	.381
9	.381	.4715	.381	.5716	.381	.4715	
10	.2858		.381	.5716	.381	1.7147	1.5242
11	.2829	.381	.381	.381	.3772	1.5432	1.9052
12	.1886	.381	.381	.381	.3772	1.5432	2.2862
13	.1886	.381	.381	.2858	.2829	1.5432	2.4768
14	.1886	.381	.1905	.2858	.2829	1.5432	2.2862
15	.2829	.381	.1905	.2858	.2829	1.4575	1.9052
16	.2829	.381	.381	.2858	.3772	1.5432	
17	.3772	.381	.4763	.381	.3772	1.5432	1.9052
18	2.0119	2.2862	2.6673	1.7147	2.0957	.5716	.7621
19	2.0957	2.4768	2.2862	2.0576	2.0957	.5716	.7621
20	2.0957	2.4768	2.2862	2.0576	2.0957	.5716	.7621
21	2.0957	2.4768	1.9052	2.0576	2.0119	.381	.5716
22	2.0119	2.2862	1.9052	2.0576	2.0119	.381	.5716
23	2.0119	2.2862	1.9052	1.7147	1.8442	.381	.5716
24	1.8861	2.0119	2.2862	1.9052	1.7147	1.7147	.381
Max	2.0957	2.4768	2.6673	2.0576	2.0957	1.7147	2.4768
Min	.1886	.3772	.1905	.2858	.2829	.3772	.381
Avg	.9247	1.1123	1.0121	.9621	.9302	.9713	.9872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON**

Feeder No / Name : 201 / 11KV R.U.GAON-AG FDR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9004	1.2003	1.3717	1.0288	
2		1.9909	2.4006	2.0576	1.0288	
3		2.0165	2.7435	2.2291	1.0288	
4		2.0911	2.7435	2.4006	.8573	
5		2.0165	2.915	2.4863	.8573	
6		1.4003	2.915	2.7435		
7		1.2136	3.0864	3.0864		
8			3.0864	3.0864		
9		1.3256	3.0864	2.915		
11						2.7073
12						3.2674
13						3.3421
15						3.1741
16						3.2114
17						3.2007
18						3.2114
19	.5228					.4668
20	.4668	1.0288	1.0288	1.0288		.4854
21		1.0288	1.3717	1.2003		
22	.4481	1.2003	1.3717	1.286		.5228
23	.5041	1.2003	1.0288	1.2003		.4854
24		.5788	1.2003	1.0288	1.2003	
Max	.5228	2.0911	3.0864	3.0864	1.2003	3.3421
Min	.4481	.5788	1.0288	1.0288	.8573	.4668
Avg	.4855	1.4609	2.1556	2.0086	1.0002	2.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON****Feeder No / Name : 202 / 11KV PANEWADI-AG FDR
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2883	1.2003	1.0288	.8573	
3		.0191				
18	1.2136	1.2003	1.2003	1.286		.9709
19	1.3256	1.3717	1.2003	1.2003		.9709
20	1.3443	1.5432	1.0288	1.0288		1.0456
21	1.2883	1.5432	.9431	1.0288		
22		1.3717	.9431	1.0288		1.1203
23	1.2696	1.3717	1.0288	.8573		1.2136
24		1.3256	1.3717	1.0288	.8573	
Max	1.3443	1.5432	1.3717	1.286	.8573	1.2136
Min	1.2136	.0191	.9431	.8573	.8573	.9709
Avg	1.2883	1.2261	1.1146	1.0610	.8573	1.0643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 203 / 11KVTALEGOAN-AG FDR
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4668	.3429	1.3717	1.0288	
2		2.0165	1.3717	2.2291	1.0288	
3		2.1472	1.7147	2.2291	1.0288	
4		2.1285	2.0576	2.4006	1.0288	
5		2.3339	2.0576	2.7435	1.0288	
6			1.7147	2.7435	1.0288	
7		2.8567	1.5432	2.7435		
8		2.838	1.5432	2.6578		
9		2.8193	1.5432	2.4006		
10						1.9605
11						2.2965
12						2.4646
13						2.4459
15						2.838
16						2.8567
17						2.7073
19	.4294					.3921
20	.3921	.5144	1.2003		.8573	.3734
21		.6859	1.3717			
22		.5144	1.2003		1.0288	.4294
23	.4668	.3429	1.2003		1.0288	.4668
24		.4854	.3429	1.2003	1.0288	
Max	.4668	2.8567	2.0576	2.7435	1.0288	2.8567
Min	.3921	.3429	.3429	1.2003	.8573	.3734
Avg	.4294	1.5500	1.3717	2.2720	1.0117	1.7483

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON****Feeder No / Name : 204 / 11KV SHINDEWADGAON-AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4344	.5144	.5144	.5144	
2			.5144	.5144	1.5432	
3		.5788	.5144	.5144	1.7147	
4		.5068	.4287	.5144	1.7147	
5		.5415	.3429		1.8861	
6			.3429		1.8861	
7					2.0576	
10		2.572	2.7435	2.0576		
11		2.7435		2.2291		
12		2.7435	2.7435	2.3148		
13		2.7435	2.7435	2.4006		
14	2.4459		2.7435	2.4863		
15	2.6326		2.7435	2.4863		
16			2.7435	2.4863		
17	2.6513		2.4006	2.4863		
19	.3921					.3921
20	.4755	.5144	.5144	.5144		.4294
21		.5144	.5144	.5144		
22	.4294	.6001	.5144	.5144		
23	.4108	.6001	.5144	.5144		.4108
24		.4294	.5144	.6001	.5144	
Max	2.6513	2.7435	2.7435	2.4863	2.0576	.4294
Min	.3921	.4294	.3429	.5144	.5144	.3921
Avg	1.3482	1.1940	1.3384	1.3919	1.4789	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON****Feeder No / Name : 205 / RUGAON GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5068	.4287	.3429	.3429	
2		.5601	.5144	.3429	.3429	
3			.5144	.5144	.3429	
4				.6001	.4287	
5					.4287	
6					.5144	
7		.6535			.6001	
8		.7095				
9		.7655				
10		.6001	.6859	.6859		
11			.6859	.6001		.3921
12		.5144		.6001		.4481
13		.5144		.5144		
14	.4294		.5144	.3429		
15	.5087		.5144	.3429		
16	.5975		.5144	.4287		.4668
17			.6001	.5144		
18	.6535		.6859	.6001		.4668
19	.6348	.6859	.6001	.6859		.7468
20	.6154	.7716	.4287	.6001		.7282
21	.5788	.6859	.3429	.5144		
22		.5144	.3429	.4287		.5601
23	.5601	.5144	.3429	.3429		.5228
24		.5415	.4287	.3429	.3429	
Max	.6535	.7716	.6859	.6859	.6001	.7468
Min	.4294	.5068	.3429	.3429	.3429	.3921
Avg	.5723	.6099	.5090	.4918	.4179	.5415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134013 / RUGAON

Feeder No / Name : 206 / SHINDEWADGAON GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2241	.1715	.1372	.1715	
2		.1867	.1372	.1372	.1715	
3			.1372	.1372	.1715	
4			.1715	.1372	.1715	
5			.1715	.1715	.1715	
6			.2058	.1715	.2572	
7		.2241	.2058	.2572	.2572	
8		.2801	.3086	.1715		
9		.3174	.2572	.1715		
10		.2572	.1715	.0857		
11		.2058	.1715	.0857		.1867
12		.1372	.1715	.0857		.2054
13		.1372	.0857	.0857		
14	.2241		.0857	.0857		
15	.2172		.0857	.0857		
16	.168		.1715	.0857		
17			.1715	.1715		.1494
18	.2241	.2572	.1715	.2572		
19	.2054	.3429	.2572	.2572		.2427
20		.3429	.1715	.2572		.2241
21	.2241	.2572	.1715	.1715		
22	.1867	.2572	.1715	.1715		.2241
23	.168	.2058	.1715	.1715		.1867
24		.1867	.1715	.1715	.1715	
Max	.2241	.3429	.3086	.2572	.2572	.2427
Min	.168	.1372	.0857	.0857	.1715	.1494
Avg	.2022	.2387	.1736	.1550	.1929	.2027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON****Feeder No / Name : 208 / PANEWADI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2987	.2572	.2572	.2572	
2		.3361	.2572	.2572	.2572	
3			.2572	.2572	.2572	
4				.3429	.3429	
5					.3429	
6					.3429	
7					.3429	
8		.3734				
9		.4108				
10		.3429	.2572	.1715		
11		.3429	.2572	.1715		.3921
12		.3429		.1715		.3174
14	.2241		.1715	.1715		
15			.1715	.1715		
16	.3921		.2572	.2572		.2614
17	.4108		.3429	.3429		.2241
18	.4294	.5144	.3429	.4287		
19		.5144	.4287	.4287		.3361
20	.4854	.5144	.3429	.4287		
21	.4668	.4287	.2572	.3429		.2713
22	.4481	.3429	.2572	.2572		
23	.4668	.3429	.2572	.2572		.2801
24		.3174	.2572	.2572	.2572	
Max	.4854	.5144	.4287	.4287	.3429	.3921
Min	.2241	.2987	.1715	.1715	.2572	.2241
Avg	.4154	.3873	.2733	.2763	.3001	.2975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134013 / RUGAON**

Feeder No / Name : 209 / 11KV EXPRESS FEEDER UTTARA NON SHEDDABLE EXPRESS HV FEEDERS
F00 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0343	.0171	.0171	
2		.0187	.0343	.0171	.0171	
3			.0343	.0171	.0171	
4		.0373	.0343	.0171	.0171	
5		.0362	.0343	.0171	.0171	
6			.0343	.0171	.0171	
7		.0373	.0343	.0171	.0171	
8		.0373	.0171	.0171		
9		.0373	.0171	.0171		
10		.0343	.0343	.0171		
11		.0343	.0343	.0171		.0373
12		.0343	.0343	.0343		
13		.0171	.0343	.0343		.0373
14	.0373		.0171	.0343		
15	.0373		.0171	.0343		.0187
16	.0366		.0171	.0171		.0187
17			.0171	.0343		
18	.0187	.0343	.0343	.0343		.0373
19	.0373	.0343	.0343	.0343		.0373
20	.0373	.0343	.0343	.0171		.0187
21	.0373	.0343	.0343	.0171		
22		.0343	.0171	.0343		.0373
23	.0373	.0343	.0171	.0343		.0373
24		.0373	.0343	.0171	.0171	
Max	.0373	.0373	.0343	.0343	.0171	.0373
Min	.0187	.0171	.0171	.0171	.0171	.0187
Avg	.0349	.0336	.0286	.0236	.0171	.0311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 201 / 11KV RAJA TAKALI-AG FDR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 202 / JAMB-AG****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	1.0364
Max	1.0364
Min	1.0364
Avg	1.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 203 / 11KV MURTI-AG FDR
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	.7621
Max	.7621
Min	.7621
Avg	.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 204 / KPGAON -AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 205 / K.P.TOWN GTN****Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.3717
Max	1.3717
Min	1.3717
Avg	1.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 206 / RAJATAKLI- GAONTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 207 / 11KV JAMB- GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.5242
Max	1.5242
Min	1.5242
Avg	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 208 / 11KV MURTY-GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 209 / 11KV SINDHKHED-GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	.9145
Max	.9145
Min	.9145
Avg	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 210 / 11KV SAMRUDDHI EXPRESS
FEEDER Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	.3239
Max	.3239
Min	.3239
Avg	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134016 / KUMBHAR PIMPALGAON****Feeder No / Name : 211 / 11KV EXPRESS FEEDER
SHIVANGAON Feeder KV- 11 /
OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	.0305
Max	.0305
Min	.0305
Avg	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 201 / RAMASGAON AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.2955	1.0288	1.6194	1.5242	
3	1.3336	1.0288	1.7147	1.4861	
4	1.4289	1.1145		1.4289	
5	1.5242	1.2003		1.3717	
6	1.5813	1.286		1.4289	
7	1.7909	1.5432		1.6194	
8	1.9052	1.7147		1.7147	
9	2.0005	1.7147	2.0957	1.8099	
11					1.6289
12					2.0005
13					2.0957
14					1.9814
15					2.0005
16					1.9814
17					2.0386
Max	2.0005	1.7147	2.0957	1.8099	2.0957
Min	1.2955	1.0288	1.6194	1.3717	1.6289
Avg	1.6075	1.3289	1.8099	1.5480	1.961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 202 / 11KV KANDARI AG
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.9907
Max	.9907
Min	.9907
Avg	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 203 / BHAIGAVHAN-AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1524				1.3717
3					1.3717
4					1.3717
5					1.5432
6					1.6289
7					1.8861
8					2.1434
9					2.2291
11	2.8292	2.8578	2.191	2.6863	
12	3.1722	2.9912	2.0957	2.572	
13	3.2579	3.2198	2.1338	2.572	
14	3.0864	3.0864	2.191	2.8292	
15	3.0864	3.2007	2.2481	2.7435	
16	3.0864	3.1436	2.191	2.7435	
17	2.915	3.2007	2.0957	2.4006	
18	2.6578	2.9721	2.4768	2.1434	
Max	3.2579	3.2198	2.4768	2.8292	2.2291
Min	.1524	2.8578	2.0957	2.1434	1.3717
Avg	2.6937	3.0840	2.2029	2.5863	1.6932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI**

Feeder No / Name : 204 / 11KV Industrial FDR BALAJI NON SHEDDABLE EXPRESS HV FEEDERS
OIL Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0857		.1143	.0857
2	.0762	.0857	.0953	.0762	.0857
3	.0762	.0857	.1143	.0762	.0857
4	.0572	.0857	.1524	.0381	.0857
5	.0762	.0857	.0953	.0762	.0857
6	.0572	.0857	.0762	.0762	.0857
7	.0762	.0857	.0953	.0762	.0857
8	.0381	.0857	.0953	.4001	.0857
9	.6478	.0857	.6859	.6097	.0857
10	.6478	.1715	.0762	.6859	.1715
11	.6001	.1334	.6668	.0762	.0857
12	.6001	.1143		.5906	.1143
13	.6001	.1143	.7621	.5144	.1334
14	.6001	.1143	.7049	.6001	.0953
15	.6001	.1334	.7049	.6001	.1143
16	.6001	.381	.7049	.6001	.1334
17	.6001	.5144	.6478	.5144	.1143
18	.6001	.5335	.5525	.5144	
19	.5144	.3048	.5144	.5144	
20	.1715	.3429	.381	.1715	
21	.1715	.2286	.3429	.0857	
22	.1715	.1905	.2858	.0857	
23	.1715	.1524	.2286	.0857	
24	.0762	.0857	.1334	.1905	.0857
Max	.6478	.5335	.7621	.6859	.1715
Min	.0381	.0857	.0762	.0381	.0857
Avg	.3286	.1786	.3689	.3072	.1011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 205 / Kandhari GTN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.9907
Max	.9907
Min	.9907
Avg	.9907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 206 / BHAIGAVHAN-GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.2955
Max	1.2955
Min	1.2955
Avg	1.2955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134027 / TIRTHPURI****Feeder No / Name : 207 / 11KV Tirthpuri Gaothan FDR****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.3429	.6478	.6478	.3429
2	.4954	.3429	.6859	.6859	.3429
3	.6859	.3429	.9145	.8002	.4287
4	.7621	.8573	1.1812	1.1431	.6001
5	1.086	1.0288	1.3336	1.2955	1.0288
6	1.4289	1.2003	1.4861	1.4289	1.286
7	1.4098	1.4575	1.6194	1.5813	1.4575
8	1.5432	1.286	1.4861	1.448	1.3717
9	1.467		1.3717	1.3336	1.3717
10	.8764	1.1145	1.0288	.9526	1.286
11	.6859	.9717	.9145	.7621	
12	.5144	.7621	.6859	.6478	.5906
13	.4287	.7049	.5525	.5144	.6287
14	.4287	.6859	.5144	.5144	.5716
15	.4287	.5906	.5525	.6001	.5906
16	.5144	.724	.6478	.6001	.7049
17	.7716	.8002	.8573	.6001	.8383
18	1.0288	1.2765	1.2193	1.0288	
19	1.0288	1.3336	1.3527	1.0288	
20	.6859	1.0669	1.1241	.6001	
21	.5144	.9526	.9145	.5144	
22	.4287	.9145	.8002	.4287	
23	.3429	.8002	.7621	.3429	
24	.4763	.3429	.724	.724	.3429
Max	1.5432	1.4575	1.6194	1.5813	1.4575
Min	.3429	.3429	.5144	.3429	.3429
Avg	.7712	.8652	.9740	.8427	.8108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134056 / DEODI HADGAON****Feeder No / Name : 201 / 11KV Deodi Hadgaon SP FDR SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9044	.8215	.7621	.7621	.8589	.6348	
2	2.2405	.8139	.9526	1.5242	1.6617	.6348	.7621
3	2.6139	.8573	1.5242	1.5242	1.643	.6348	.7621
4	2.7073	1.1022	1.5242	1.5242	1.6804	.6722	.7621
5	2.7633	1.1736	1.5242	1.7147	1.7177	.7023	.7621
6	2.8006	1.6766	1.5242	1.7147	1.7551	.7842	.5716
7	2.2405	1.8442	1.307		1.7737	.8871	.7621
8	2.4272	2.3537	1.307	1.9052	1.8111	.3048	.7621
9	2.2405	2.1795	1.1203	1.5242	1.8298	.4572	.7621
10		.1905	1.1431	.1905	.1463	1.1736	1.9052
11		.1905	.1905	.1905	.1463		1.4632
12	.1905	.1905	.1905	.1829	.1905	1.8671	1.2955
13	.1905	.1905	.1905	.1829	.1905	2.0119	1.5242
14	.1905	.1905	.1905	.1463	.1905	1.8671	1.5242
15	.1905	.1905	.1905	.1463	.1905	1.3565	1.5242
16	.1905	.1905	.1905	.1463	.1905	1.326	1.5242
17	.1905	.381	.1905	.1829	.1905	1.326	1.5242
18	.9145	.7621	1.1431	.9145	.9145	.7621	.7621
19		.7621	.9526	1.2803	1.0136	.7621	.7621
20	.8413	.7621	.7621	1.0974	.695		.7621
21	.8779	.7621	.7621	1.1706	.695	.7621	.7621
22	.9335	.7621	.7621		.7468	.7621	.7621
23	.9335	.7621	.7621	1.0791	.7316	.7621	
24	.9145	.8962	.7621	.7621	.8413	.7023	.7621
Max	2.8006	2.3537	1.5242	1.9052	1.8298	2.0119	1.9052
Min	.1905	.1905	.1905	.1463	.1463	.3048	.5716
Avg	1.3570	.8336	.8304	.9030	.9085	.9615	1.0347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134056 / DEODI HADGAON****Feeder No / Name : 202 / 11KV Dhakefal SP FDR
Feeder KV- 11 / OUTGOING****SINGLE PHASING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.4954	.2858	.1905	.2012	.4572	2.6673
2	.2195	.4954	.2858	.1905	.2195	.4572	.2858
3	.2561	.5335	.2858	.1905	.2561	.4572	.2858
4	.2926	.5335	.2858	.1905	.3292	.4572	.2858
5	.3292	.7621	.2858	.1905	.3658	.4954	.2858
6	.3658	.9526	.1905	.2858	.4024	.6348	.2858
7	.4207	.9526	.1905	.2858	.4024	.9709	.2858
8	.3898	.8383	.1905	.2858	.439	.8764	.2858
9	.439	.7621	.1905	.1905	.3658	.7621	.2858
10	2.6886	2.5149	2.3777	2.652	1.4784	.5716	.2858
11	2.1376	2.3472	2.5606	2.652	1.8671		.2858
12	3.0178	2.8006	2.9264	1.8671	2.6825	.2858	.2858
13	2.915	2.5434	3.3608	1.6804	2.6825		.1905
14	2.9843		3.4751	1.5684	3.0178	.2858	.1905
15	2.7854	2.7978	3.3608	1.6804	2.9835	.2858	.1905
16	3.0803	2.9874	3.3608	1.6804	3.0178	.1905	.1905
17	2.652	2.9874	3.0521	.3109	3.0178	.2858	.1905
18	.4954	.2858	.1905	.3292	.6478	2.915	2.8178
19	.7621	.2858	.1905	.1829	.7842	2.9835	
20	.6097	.2858	.1905	.1829	.4954	3.3608	2.4768
21	.5335	.2858	.1905	.1829	.4954	2.8826	2.2862
22	.4954	.7621	.1905	.1829	.4108	2.713	2.2862
23	.4191	.2858	.1905	.2195	.4191	2.9874	
24	.1829	.4572	.2858	.1905	.2012	.4572	2.3739
Max	3.0803	2.9874	3.4751	2.652	3.0178	3.3608	2.8178
Min	.1829	.2858	.1905	.1829	.2012	.1905	.1905
Avg	1.1947	1.2153	1.1706	.7318	1.1326	1.1715	.8638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134056 / DEODI HADGAON****Feeder No / Name : 203 / 11KV Avalgaon AG FDR
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.8442	2.0005	2.2862	1.5684	1.5261	
2	1.307	.8383	1.3336	1.1869	1.1576	1.3565	1.3336
3	1.3443	.8288	1.3336	1.1869	1.1203	1.3565	1.3336
4	1.3817	.9945	1.3336	1.1869	1.0269	1.3413	1.3336
5	1.4563	.9945	1.3336	1.0174	1.0829	1.3245	1.3336
6	1.4937	1.0059	1.3336	1.0174	1.1949	1.4251	1.3336
7	1.4937	.9724	1.3336	.8288	1.1576	1.4586	1.5242
8	1.4937	1.2763	1.1431	.8097	1.1203	1.7814	1.5242
9	1.2071	1.2071	.9526	.9526	1.2323		1.7147
10						.9724	.8478
11							1.1431
12						1.4937	1.3336
13						1.5242	1.2803
14						1.3336	1.5242
15						1.1603	1.5242
16						1.1869	
17						1.1869	1.5089
18	1.9662	2.6139	2.7435	2.6139	2.2939		
19	2.1628	2.6139	2.3739	2.3152	2.0719		
20	1.9662	2.5606	2.5606	2.2405	1.6766		
21	2.1548	2.4272	2.2672	2.2779	1.6766		
22		2.2862	2.4272		1.6956		
23	2.1795	2.2862	2.4768	1.6804	1.643		
24	2.7633	2.0119	2.0538	2.2862	1.5684	1.5927	
Max	2.7633	2.6139	2.7435	2.6139	2.2939	1.7814	1.7147
Min	1.2071	.8288	.9526	.8097	1.0269	.9724	.8478
Avg	1.7056	1.6726	1.8126	1.5925	1.4555	1.3763	1.3729

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134066 / SADEGAON****Feeder No / Name : 201 / 11 KV SADEGAON AG FDR
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.6882					
2	1.1142	1.1305	.7545	.7888			
3	1.1469	1.1469	.8059	.823			
4	1.1469	1.1961	.8573	.9259			
5	1.1797	1.1961	.9602	.9602			
6	1.2452	1.2125	1.0631	1.0974			
7	1.278	1.278	1.0974	1.286			
8	1.3272	1.2944	1.3546	1.3717			
9	1.3108	1.3272	1.3889	1.3889			
11					1.3717	1.3763	1.3763
12					1.4232	1.4255	1.3599
13					1.5604	1.3763	1.3763
14					1.6289	1.3435	1.3435
15					1.5604	1.3599	1.3435
16					1.5947	1.3763	1.3599
17					1.4918	1.3272	1.4091
18					1.3889	1.3272	1.2616
Max	1.3272	1.3272	1.3889	1.3889	1.6289	1.4255	1.4091
Min	.7865	.6882	.7545	.7888	1.3717	1.3272	1.2616
Avg	1.1706	1.1633	1.0352	1.0802	1.5025	1.3640	1.3538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134066 / SADEGAON****Feeder No / Name : 202 / 11KV Sadegaon Gaothan****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.1966	.3429	.3086	.3506	.2591	.2622
2	.2949	.2622	.3086	.3429	.3963	.3201	.2622
3	.3605	.2949	.3258	.3772	.4973	.3963	.4588
4	.4588	.2949	.3772	.4973	.6173	.5316	.5735
5	.6226		.4801	.6344	.7202	.6173	.6882
6		.5079	.6344	.7888	.9602	.8573	.7865
7		.5407	.7888	.8745	.7545	.9088	.7865
8	.7537	.4752	.583	.8059	.6001	.6344	.7537
9	.5426	.4424	.583	.7202	.6687	.5144	.4915
10	.426	.3086	.4287	.4801	.3963	.2743	.4096
11	.2949	.2058	.3601	.3353	.3048		.2949
12	.2458	.1715	.2743	.2743	.2134	.2458	.2458
13	.2458	.1543	.2401	.2286	.1981	.2622	.2458
14	.213	.1372	.2743	.2439	.2286	.2622	.213
15	.2949		.3258	.2286	.2439	.2622	.3277
16	.3441	.3258	.3772	.2896	.2591	.2622	.3605
17		.463	.5316	.5144	.3506	.4588	.4424
18		.4973	.6344	.7202	.5658	.5571	.6226
19	.3768	.7716	.6173	.6344	.6516	.5571	.5735
20	.4424	.5487	.5144	.5658	.4801	.5735	.5079
21	.4424		.3772	.3963	.3353	.4915	.4915
22	.4096	.4458	.3429	.3658	.2896	.3605	.426
23	.2622	.4115	.3258	.3353	.1829	.3113	.3932
24	.2949	.1966	.3429	.3086	.3048	.1981	.2294
Max	.7537	.7716	.7888	.8745	.9602	.9088	.7865
Min	.213	.1372	.2401	.2286	.1829	.1981	.213
Avg	.3810	.3644	.4330	.4696	.4404	.4398	.4520

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134066 / SADEGAON****Feeder No / Name : 203 / 11KV Gangachincholi AG****FEEDER SEPERATION/PURE AG****FEEDER Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.9431	.8059	
3					.9945	.8402	
4					1.046	.8745	
5					1.0974	.9259	
6					1.2003	.9774	
7					1.3032		
8					1.3546		
9					1.3203		.9175
11	1.4255	1.4403	1.4403	1.5261			
12	1.5074	1.5432	1.5089	1.6461			
13	1.6385	1.6118	1.5775	1.6118			
14	1.704	1.6461	1.5775	1.6804			
15	1.6385		1.5604	1.6461			
16	1.5893	1.5775	1.6461	1.6461			
17	1.5893	1.5432	1.6975	1.5261			
18	1.4746	1.5432	1.6289	1.3717			
Max	1.704	1.6461	1.6975	1.6804	1.3546	.9774	.9175
Min	1.4255	1.4403	1.4403	1.3717	.9431	.8059	.9175
Avg	1.5709	1.5579	1.5796	1.5818	1.1574	.8848	.9175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134068 / 33KV S/S SINDKHED****Feeder No / Name : 201 / Limboni Ag****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.4534	.6478
3						.583	.9717
4						.6802	.9717
5						.9717	1.2955
6						1.1012	1.3927
7						1.2146	1.2955
8						1.2631	1.4575
9						1.3603	1.3927
11	1.4251	1.4575	1.6194		1.2955		
12	1.5546	1.6194	1.7814	1.587	1.587		
13	1.6194	1.7004		1.7814	1.6842		
14	1.587	1.7004	1.7814	1.7814	1.5546		
15	1.5546	1.7004	1.7814	1.749	1.5546		
16	1.5546	1.7004	1.4575	1.6842	1.587		
17	1.4575	1.6194	1.3927	1.5546	1.5384		
18	1.2955	1.4575	1.2955	1.3603	1.2146		
24			.9145				
Max	1.6194	1.7004	1.7814	1.7814	1.6842	1.3603	1.4575
Min	1.2955	1.4575	.9145	1.3603	1.2146	.4534	.6478
Avg	1.5060	1.6194	1.5030	1.6426	1.5020	.9534	1.1781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134068 / 33KV S/S SINDKHED****Feeder No / Name : 202 / Sindkhed Ag****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.1336	1.2955	1.2955	1.4575	1.4251		
3	1.4251	1.5546	1.3765	1.6194	1.7004		
4	1.4575	1.7814	1.6194	1.7814	1.9433		
5	1.6842	2.0081	1.7814	1.9433	1.9433		
6	1.7814	2.1052	2.0243	2.0405	2.0081		
7	2.17	2.2024	2.1862	2.1052	2.0729		
8	2.4939	2.1052	2.2672	2.3644	2.17		
9	2.332	2.1376	2.2672	2.5911	2.2024		
11						2.1052	2.1052
12						2.3644	
13						2.4291	2.1862
14						2.6558	
15						2.6882	
16						2.753	
17						2.5911	2.1052
18						2.2672	1.7004
24			.6668				
Max	2.4939	2.2024	2.2672	2.5911	2.2024	2.753	2.1862
Min	1.1336	1.2955	.6668	1.4575	1.4251	2.1052	1.7004
Avg	1.8097	1.8988	1.7205	1.9879	1.9332	2.4818	2.0243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134069 / 33 kv Banegaon****Feeder No / Name : 201 / 11 kv Banegaon Ag
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.0059		.9945	.9945		
3	1.1736		.9602	1.1145		
4	1.1736		.9431	1.2517		
5	1.1736		.9945	1.3717		
6	1.2574		1.0288	1.3717		
7	1.3413		1.2346	1.3717		
8	1.4251		1.3717	1.3375		
9	1.5424		1.4575	1.3375		
11					1.5089	1.5432
12					1.5432	1.6118
13					1.6289	1.6118
14					1.6118	1.6289
15					1.5947	1.6289
16					1.5604	1.5089
17					1.5604	1.406
18					1.406	1.406
24		.6859				
Max	1.5424	.6859	1.4575	1.3717	1.6289	1.6289
Min	1.0059	.6859	.9431	.9945	1.406	1.406
Avg	1.2616	.6859	1.1231	1.2689	1.5518	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134069 / 33 kv Banegaon****Feeder No / Name : 202 / 11 kv Bhogaon Ag
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.6516	.823
3					.9774	.8916
4					1.0288	.9259
5					1.0802	.9945
6					1.2346	1.0631
7					1.286	1.2689
8					1.286	1.3375
9					1.2003	1.2346
11	1.2136	.7621	1.2003	1.0631		
12	1.2696	1.0669	1.2517	1.166		
13	1.2696	1.1279	1.2517	1.2689		
14	1.2323	1.0974	1.286	1.2689		
15	1.307	1.1279	1.3717	1.2689		
16	1.3817	1.0974	1.0288	1.2689		
17	1.2883	1.0669	1.0288	1.2689		
18	1.3443	1.0974	.9431	1.0288		
24		.8383				
Max	1.3817	1.1279	1.3717	1.2689	1.286	1.3375
Min	1.2136	.7621	.9431	1.0288	.6516	.823
Avg	1.2883	1.0314	1.1703	1.2003	1.0931	1.0674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134069 / 33 kv Banegaon****Feeder No / Name : 203 / 11 kv banegaon Gaonthan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128		.1715	.1029	.1029	.1372
2	.1463		.1715	.1029	.1372	.1543
3	.1829		.1543	.1715	.1715	.2401
4	.1829		.1715	.1715	.3086	.5144
5	.2743		.3086	.4115	.6173	.5487
6	.439		.5144	.6001	.6516	.6516
7	.6401		.4801	.6001	.5487	.6516
8	.5853		.4458	.5144	.5144	.6001
9	.5487		.4115	.5144	.4973	.5144
10	.3475	.4572	.4287	.5144	.4801	.4458
11	.1829	.3292	.4115	.2401	.4115	.3258
12	.1463	.2195	.1886	.1715	.1715	.1715
13	.1646	.2012	.1886	.1715	.1543	.2058
14	.1646	.1829	.1715	.2058	.1543	.2058
15	.1463	.1463	.1715	.2058	.1715	.1715
16	.2561	.2012	.2572	.2572	.2572	.2058
17	.3658	.2743	.2915	.2572	.3429	.3086
18	.4572	.4755	.463	.4115	.4458	.463
19		.5853	.4287	.4458	.4801	.4801
20		.3658	.3429	.4458	.4287	.4973
21		.2195	.3086	.4287	.4458	.4973
22		.2195	.1372	.2058	.1543	.3429
23		.1715	.1372	.1372	.1543	.1715
24	.1463		.1715	.1029	.12	.1372
Max	.6401	.5853	.5144	.6001	.6516	.6516
Min	.128	.1463	.1372	.1029	.1029	.1372
Avg	.2897	.2892	.2886	.3079	.3301	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134073 / 33kv SHIVANGAON S/S****Feeder No / Name : 201 / 11KV Shivangaon AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	1.2003
Max	1.2003
Min	1.2003
Avg	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134073 / 33kv SHIVANGAON S/S****Feeder No / Name : 202 / 11KV SPARE(Gunj) AG
Feeder KV- 11 / OUTGOING****SHEDDABLE RURAL**

DATE	01-DEC-17
HR	Load (MW)
24	.8002
Max	.8002
Min	.8002
Avg	.8002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134075 / 33 kv Bhutegaon****Feeder No / Name : 201 / 11 KV Bhutegaon AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.3429	.4191
3						.4287	.4572
4						.463	.4763
5						.4801	.4954
6						.5144	.5144
7						.5144	.6097
8						.5487	.743
9						.5658	.7621
11	.9431	1.105	.7621	.6478	.6001		
12	1.1145	1.1812	.9335	.7049	.7716		
13	1.046	.9335	.9335	.8192	.7716		
14	1.0631	.8002	.9526	.8573	.823		
15	1.0288	.8764	.9145	.8573	.8573		
16		1.0479	.8573	.8383	.8745		
17	1.0631	1.2193	.8192	.7621	.8573		
18	.9431	.724	.743	.6859	.7716		
24			.5944				
Max	1.1145	1.2193	.9526	.8573	.8745	.5658	.7621
Min	.9431	.724	.5944	.6478	.6001	.3429	.4191
Avg	1.0288	.9859	.8345	.7716	.7909	.4823	.5597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134075 / 33 kv Bhutegaon****Feeder No / Name : 202 / 11 kv Dai Anterwali ag
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4191	.4287		.4763	.4572		
3	.4763	.463	.5716	.4954	.5144		
4	.5716	.4801	.6287	.5335	.5525		
5	.6097	.5144	.7049	.5716	.6668		
6	.743	.5487	.7621	.6668	.7621		
7	.8764	.6001	.8192	.7621	.8002		
8		.6859	.8383	.8192	.8383		
9	.8192	.7716	.743	.7621	.8002		
11						1.2765	.5335
12						.9145	.743
13						.9717	.724
14						.9526	.7049
15						.8573	.724
16						.8192	.6859
17						.7811	.5716
18						.5716	.4572
24			.6097				
Max	.8764	.7716	.8383	.8192	.8383	1.2765	.743
Min	.4191	.4287	.5716	.4763	.4572	.5716	.4572
Avg	.6450	.5616	.7097	.6359	.6740	.8931	.6430

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134075 / 33 kv Bhutegaon****Feeder No / Name : 203 / 11 kv Bhutegaon Gaonthan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5335	.4954	.5144	.463	.5335
2	.5144	.5487	.5335	.5144	.5335	.5144	.5335
3	.6097	.6001	.6287	.5716	.6668	.5144	.5335
4	.7621	.6516	.743	.724	.8383	.7373	.6668
5	.9526	.7716	.8002	.8954	.9907	.9774	.9526
6	1.086	1.0631	1.086	1.1431	1.1431	1.0631	1.2003
7	1.1431	1.1145	1.1431	1.0669		1.0288	1.1812
8	1.1622	1.0288	1.0288	1.086		.9945	1.0098
9	1.086	.9431	.8573	.9526		.9431	.9526
10	.7545	.8383		.8002	.9526	.7049	.6097
11	.6859	.6287	.5335	.5906	1.3717	.4763	.4763
12	.6001		.4763	.4763	1.2003	.4191	.381
13	.4287	.4001	.4001	.4001	.4287	.381	.4001
14	.3429	.362	.4191	.4572	.4115	.381	.381
15	.3429	.4382	.3429	.4001	.4115	.4191	.362
16		.5525	.4954	.4763	.5144	.4382	.4572
17	.6001	.7811	.6859	.743	.6859	.6668	.6859
18	.9945	1.0669	1.086	.9526	.8573	.9526	1.0288
19	1.0288	1.1431	1.0479	1.0479	.9945	.9145	.9907
20	.9431	.9335	.743	.8573	.9431	.8573	.8573
21	.7716	.6287	.6287	.6668	.6001	.6097	.6859
22	.5144	.5906	.5525	.5335	.5144	.5716	.5906
23		.5525	.5335	.5335	.4801	.5335	.5525
24	.5144		.4572	.5335	.5144	.463	.5335
Max	1.1622	1.1431	1.1431	1.1431	1.3717	1.0631	1.2003
Min	.3429	.362	.3429	.4001	.4115	.381	.362
Avg	.7433	.7342	.6850	.7049	.7413	.6677	.6898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134085 / ANTERWALI TEMBHI****Feeder No / Name : 201 / 11KV ANTARWALI -T AG FDR
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6766	2.0386	
2	1.6004	2.0005	2.0748
3	1.6385	2.0957	2.1125
4	1.6956	2.21	2.1125
5	1.829	2.2481	2.1691
6	2.1338	2.3243	2.1691
7	2.3243	2.4958	2.3577
8	2.7625	2.7625	2.7349
9	2.7244	2.915	2.6972
Max	2.7625	2.915	2.7349
Min	1.6004	2.0005	2.0748
Avg	2.0428	2.3434	2.3035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134085 / ANTERWALI TEMBHI**

Feeder No / Name : 204 / 11KV EXPRESS FDR MANGRUL NON SHEDDABLE EXPRESS HV FEEDERS
BARRA Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0189	.0189
2	.0191	.0191	.0189	.0189
3	.0191	.0191	.0189	.0189
4	.0191	.0191	.0189	.0189
5	.0191	.0191	.0189	.0189
6	.0191	.0191	.0189	.0189
7	.0191	.0191	.0189	.0189
8	.0191	.0762	.0189	.0189
9	.0191		.0189	.0189
10	.0191	.0191	.0189	.0189
11	.0191	.0191	.0189	
12	.0191	.0191	.0189	
13	.0191	.0189	.0189	
14	.0191	.0189	.0189	
15	.0191	.0189	.0189	
16		.0189	.0189	
17	.0191	.0189	.0189	
18	.0191	.0189	.0189	
19	.0191	.0189	.0189	
20	.0191	.0189		
21	.0191	.0189		
22	.0191	.0189	.0189	
23	.0191	.0189		
24	.0191		.0189	.0189
Max	.0191	.0762	.0189	.0189
Min	.0191	.0189	.0189	.0189
Avg	.0191	.0216	.0189	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134085 / ANTERWALI TEMBHI****Feeder No / Name : 205 / 11KV Antarwali-T Gaothan
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5144	.5281	.4715
2	.5716	.5335	.4904	.4715
3	.6097	.5906	.4904	.4904
4	.743	.724	.6036	.6036
5	1.0479	1.0288	.9808	.9054
6	1.5623	1.3717	1.6787	1.2826
7	1.4861	1.5813	1.5278	1.4146
8	1.3336	1.5432	1.3957	1.1883
9	1.3717	1.5623	1.2826	1.1128
10	1.086	1.0098		.7167
11			.7545	
12	.5335	.7049	.6413	
13	.5525	.6602	.5658	
14	.5335	.6224	.6224	
15	.5525	.6036	.6602	
16		.7733	.7545	
17	.5716	1.094	1.0751	
18	1.3908	1.5844	1.3014	
19	1.448	1.1694	1.3769	
20	.8573	.8676	1.1128	
21	.743	.811		
22	.5906	.7167	.547	
23	.5716	.6036		
24	.5525		.547	.4904
Max	1.5623	1.5844	1.6787	1.4146
Min	.5335	.5144	.4904	.4715
Avg	.8755	.9396	.9018	.8316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134085 / ANTERWALI TEMBHI****Feeder No / Name : 206 / 11KV Mangrul Gaothan
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.0566	.0566
2		.1524	.0566	.0943
3	.1334	.2096	.0754	.0943
4	.3239	.2667	.0943	.0754
5	.5144	.362	.2829	.3206
6	.5716	.4954	.5281	.4527
7	.6097	.6097	.4527	.5093
8	.6478	.4954	.3772	.415
9		.4382	.3395	.2829
10	.362	.3048	.3018	.2263
11	.2477	.1715	.132	
12	.1524	.1334	.0754	
13	.1334	.0754	.0566	
14	.0953	.0566	.0566	
15	.0953	.0754	.0754	
16		.0566	.0943	
17	.2667	.1698	.2263	
18	.4382	.4338	.2829	
19	.4001	.3961	.2452	
20	.2858	.3395	.1698	
21	.2286	.2641		
22	.1905	.1886	.132	
23	.1715	.1698		
24	.1524		.0566	.0754
Max	.6478	.6097	.5281	.5093
Min	.0953	.0566	.0566	.0566
Avg	.2931	.2616	.1895	.2366

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION****Feeder No / Name : 201 / 11 KV RANJANI GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.823	.823	.3086	.7202	.3086
2	.6859	.8573	.8402	.8573	.3086	.6859	.3429
3	.9602	.9602	.9259	.8745	.3772	.7373	.3772
4	1.166	1.1831	.9259	.8573	.5144	.9088	.4801
5	1.3889	1.3889	.9602	.8402	.703	.9774	1.046
6	1.6975	1.7147	.9945	1.3375	1.0117	1.166	1.166
7	1.8004	1.749	1.166	1.4232	1.2346	1.2346	1.2346
8	1.7147	1.7147	1.3375		1.2003	1.0288	1.2346
9	1.6632	1.6804	1.1488	1.2346	1.1317		.9259
10	1.046	1.286	.1181	.8916	1.046	.8916	.6859
11	.9431	1.1145	1.1145	.6516	.9945	.703	
12	.6859		.8573	.5144	.8916	.6173	
13		.7202	.823	.4801	.7373	.5144	.6516
14		.7716	.0819	.4458	.6516	.4458	.5487
15		.823	.7202	.4801	.7202	.4458	.4458
16	.8402	.8916	.7716	.6173	.823	.583	.5144
17	1.3546	.9259	.8059	.703	1.046	.8916	.8916
18		1.2346	1.2003				.9945
19	1.1488	1.3889	1.3375	.823	.5144	.7888	.5144
20	1.0288	1.3032	1.0631	.5144	.5487	.5144	.463
21	.8745	1.166	.9259	.4458	.7202	.4287	.4115
22	.5658	1.0288	.8916	.4458	.6859	.3772	.3772
23	.4973	.9431	.823	.3772	.7202	.3429	.3429
24	.6001	.4801	.8745	.8402	.3429	.703	.3429
Max	1.8004	1.749	1.3375	1.4232	1.2346	1.2346	1.2346
Min	.4973	.4801	.0819	.3772	.3086	.3429	.3086
Avg	1.0674	1.1235	.8971	.7490	.7492	.7139	.6500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION****Feeder No / Name : 202 / 11 KV RANJANI AG FDR SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.3086	.2743	.1543		
2	.1524	.1829	.3772	.2743	.1543		
3	.1829	.1981	.3944	.2401	.1886		
4	.2134	.2572	.4115	.2572	.2401		
5	.2439	.3658	.4287	.2915	.3086		
6	.2743	.381	.4458		.3601		
7	.3658	.3048	.4458	.3086	.3601		
8	.4572	.3963	.463	.3601	.4287		
9	.4572				.4287		
11						.3429	.3772
12							.4458
13						.463	.4287
14						.463	.4973
15		.0019				.5316	.4973
16						.5487	.4973
17						.4458	.4973
18						.3944	.4973
Max	.4572	.3963	.463	.3601	.4287	.5487	.4973
Min	.1524	.0019	.3086	.2401	.1543	.3429	.3772
Avg	.2777	.2489	.4094	.2866	.2915	.4556	.4673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION**

Feeder No / Name : 203 / 11 KV KRISHNAPUR AG FEEDER SEPERATION/PURE AG
FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0819	.1524
2						.9945	.1524
3						.9945	.1829
4						1.406	.1829
5						1.6118	.1829
6						1.6461	.2134
7						1.7833	.2134
8						1.869	.3506
9						1.8519	.3353
10			1.4746				
11	1.6309	2.332		1.4784	1.6804		
12	1.9052	2.2291	1.4918	1.6309	.2153		
13	1.9814		1.5089	1.8442	1.8347		
14	2.0119	2.1434	1.5261	1.6766	1.7661		
15	1.1736	2.0576	1.5432		1.7147		
16	1.5089	2.0919	1.3889	1.5851	1.6804		
17	1.7375	1.8519		1.4937	1.6975		
18	1.5699	1.749		1.387	1.5947		
23					.0002		
Max	2.0119	2.332	1.5432	1.8442	1.8347	1.869	.3506
Min	1.1736	1.749	1.3889	1.387	.0002	.0819	.1524
Avg	1.6899	2.0650	1.4889	1.5851	1.3538	1.3599	.2185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION****Feeder No / Name : 204 / 11 KV CHITRAWADGAON AG. FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	1.166	.823	.7316		
2	.9297	1.166	.8916	.7773		
3	1.0669	1.3032	1.166	1.0364		
4	1.1431	1.3546	1.1831	1.4937		
5	1.2193	2.0919	1.2003	1.5394		
6	1.3413	2.1262	1.4232	1.6766		
7	1.4937	2.1605		1.3717		
8	1.6156			1.6156		
9	1.6766	2.2634		.884		
11						1.5242
12						1.5394
13					1.7375	1.5242
14					1.5242	1.6156
15					1.6461	1.768
16					1.5546	1.6613
17					1.6461	1.6309
18					1.5394	1.448
24		1.3717				
Max	1.6766	2.2634	1.4232	1.6766	1.7375	1.768
Min	.5335	1.166	.823	.7316	1.5242	1.448
Avg	1.2244	1.6671	1.1145	1.2363	1.6080	1.5890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER
Ranjani Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0206	.0171			.0152
2	.0229	.0248	.0206		.0171	.0206	
3		.04	.0171		.0152	.0223	.0171
4			.0154			.024	
5			.0051			.0154	
6	.0191		.0154				
7			.0206				
8	.0191		.0206				.0229
9	.0267		.0223		.0248		.021
10		.0533	.0206	.0305	.0189	.0191	.0267
11			.0206		.0154		
12				.0324			
13	.0191		.0171			.0191	
14	.0191				.0274	.0191	.0191
15	.0171	.0171				.0248	.0191
16		.0017		.021		.0248	
17	.0248	.0017			.0206	.0267	
18	.021	.0189				.0324	.0248
19	.04			.0324		.0381	.0267
20	.04			.0324		.0191	.0381
21	.0533		.0034	.0286		.0267	.0438
22	.0553		.0309		.0326	.0267	.0191
23	.0591		.0206				.0171
24			.0206	.0171			.0152
Max	.0591	.0533	.0309	.0324	.0326	.0381	.0438
Min	.0171	.0017	.0034	.0171	.0152	.0154	.0152
Avg	.0304	.0225	.0182	.0264	.0215	.0239	.0233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134086 / 33 KV RANJANI SUB STATION****Feeder No / Name : 206 / PARADGAON GFS.****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0857	.0857	.0857	.0686	.0857	.0514
2	.12	.12	.0857	.0686	.0857	.0686	.0686
3	.0857	.1543	.1029	.0514	.0857	.1029	.0686
4	.1715	.1886	.0857	.0857	.0857	.0857	.1029
5	.2572	.2572	.12	.1372	.12	.1543	.1029
6	.3086	.3086	.1715	.2572	.1543	.1715	.1372
7	.2572	.2572	.1715		.2229	.2058	.1886
8	.3258		.2058		.2058	.1372	.1715
9	.2572		.1886		.2229	.0857	.12
10	.0857		.12	.1029	.1029	.1029	.0514
11	.0857	.0857	.0857	.1029		.1029	.0343
12	.0514	.0686	.0686	.0686	.0857	.1029	.0343
13	.0686	.0076	.0857	.0686		.0686	.0686
14	.0686	.0686	.0686	.0686	.0076	.0686	.0686
15	.0857	.0076	.0686	.0686	.0857	.0686	.0857
16	.0857	.0686	.0857	.0857	.0514	.0686	.0857
17	.1029	.12	.0686	.1543	.1029	.12	.1029
18	.3258	.1886	.0857	.1886	.1715	.1715	.1715
19	.3086	.2229	.0857	.0857	.0857	.1029	.12
20	.2058	.1543	.12	.1029	.12	.12	.0857
21	.1029	.1372	.1029	.0857	.0857	.1029	.0857
22	.0857	.1029	.0857	.0857	.1029	.0686	.0857
23	.0857	.0857	.0857	.0857	.0857	.0686	.0857
24	.1029	.0857	.0857	.0686	.0857	.0686	.0514
Max	.3258	.3086	.2058	.2572	.2229	.2058	.1886
Min	.0514	.0076	.0686	.0514	.0076	.0686	.0343
Avg	.1565	.1322	.1050	.1004	.1102	.1043	.0929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 201 / 11KV BORGAON GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.3239	.1494	.1029	.1867	.3429	.1543
2	.2614	.3239	.1494	.1307	.2241	.362	.2054
3	.2743	.3429	.1494	.12	.2241	.381	.2614
4	.3547	.381	.1867	.1867	.1867	.4572	.4115
5	.3734	.4572	.2241	.2743	.2241	.4572	.4115
6	.3258	.4001	.2801	.2915	.2801	.4382	.3944
7	.3086	.3239	.3361	.2915	.3734	.4191	.3361
8		.2858	.3361	.2572	.3361	.362	.2572
9		.2054	.3429	.2614	.2241	.2477	.1715
10		.2241		.2614		.112	.0934
11	.1715	.112		.1869	.1715	.0747	.1494
12	.1524	.0934		.0747	.1715	.0747	.1494
13	.1524	.112		.0934		.0747	.1307
14	.0953	.1494		.0934	.1524	.0747	
15	.0953	.1494		.0934		.0934	
16	.1905	.1494		.1307	.1524	.1494	
17		.2241		.1867		.2241	
18	.4001	.3734	.1715	.2801	.3429	.3174	.2801
19	.4572	.3361	.0514	.3361		.3361	.2241
20	.4001	.2801	.0747	.2801	.381	.2915	.1867
21	.3429	.1867	.0686	.2241		.2241	.1867
22	.362	.1867	.0857	.1715	.362	.1867	.1867
23	.3239	.1372	.0686	.1867	.3429	.168	.1494
24	.168		.1867	.0857	.1867		.1543
Max	.4572	.4572	.3429	.3361	.381	.4572	.4115
Min	.0953	.0934	.0514	.0747	.1524	.0747	.0934
Avg	.2736	.2504	.1788	.1917	.2513	.2552	.2247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 202 / 11 KV KANDARI GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 203 / 11 KV BORGAON AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191	.0373	.0171	.0187		.0171
2	.703	.381	.3734	.6687	.5228		.0171
3	.823	.4763	.4108	.7202	.5601		.0171
4	.8402	.5716	.5228	.6859	.7095		.0171
5	.8573	.6668	.5228	.7545	.7468		.0171
6	.8402	.7621	.7095	.6859	.8962		.0171
7	.8745	1.0479	1.0269	.9088	.9335		.0171
8	1.1145	1.2384	.8916	1.0288	.9709		.0171
9		.9709	.8573	1.0269	1.0269	.0191	.0171
10		.0187	.0343	.0187		.0171	.0187
11	.0191	.0187	.0171			.6344	.8402
12	.0191	.0187	.0171		.0191	1.0642	.8962
13	.0191	.0187		.0187	.0191	1.0829	.9335
14		.0187	.0171			.9602	.9335
15		.0187	.0171	.0187	.0191	.8059	1.0829
16		.0187	.0171	.0187		.8402	.8962
17	.0191	.0187	.0171			.7282	.7468
18	.0191	.0187	.0171		.0191	.6348	.5975
19	.0191	.0187	.0171	.0373		.0171	.0934
20	.0191	.0343	.0171	.0187		.0171	.0373
21	.0191	.0373		.0187		.0171	.0373
22		.0373		.0187	.0191	.0171	.0373
23		.0373		.0187	.0191	.0171	.0373
24	.0171		.0373	.0171	.0187		.0171
Max	1.1145	1.2384	1.0269	1.0288	1.0269	1.0829	1.0829
Min	.0171	.0187	.0171	.0171	.0187	.0171	.0171
Avg	.3670	.2812	.2789	.3527	.4074	.4582	.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 204 / 11 KV KANDARI AG****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						7.7351	
3						.9526	
4						1.0479	
11	1.5242	1.6651	1.4575	1.531	1.5242		.1524
12	1.7147	1.9909	1.9204	1.6804	1.8099		
13	2.0005	2.0911	2.0748	1.8298	1.8099		
14	2.1338	2.1472	1.9033	1.8111	1.9052		
15	2.2481	2.0911	1.9547	1.7737	1.9052		
16	2.0957	2.1472	1.9719	1.7177	1.9243		
17	2.0005	2.2405	1.9204	1.7737	1.848		
18	1.9052	1.7737	1.4918	1.4937	1.7147		
Max	2.2481	2.2405	2.0748	1.8298	1.9243	7.7351	.1524
Min	1.5242	1.6651	1.4575	1.4937	1.5242	.9526	.1524
Avg	1.9528	2.0184	1.8369	1.7014	1.8052	3.2452	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 205 / 11 KV PANGRA AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.7147	1.6804		.7468	
3	1.7528	1.9605		.9335	
4	2.0005	2.0538		1.4003	
5	2.0957	2.0538		1.6804	
6	1.9052	2.2779		1.9605	
7	2.3815	2.5206		2.4272	
8	3.0483			2.3339	
9	2.4272		2.4272	2.2405	
11					2.2405
12					2.1472
13					2.1472
14					2.0165
15					2.4272
16					2.7073
17					1.8298
18					1.531
Max	3.0483	2.5206	2.4272	2.4272	2.7073
Min	1.7147	1.6804	2.4272	.7468	1.531
Avg	2.1657	2.0912	2.4272	1.7154	2.1308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 206 / 11 KV Maherjawla gaothan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.381	.1494	.12	.1867	.381	.112
2	.1494	.4001	.1867	.1307	.1867	.4001	.1307
3	.1867	.4572	.1867	.1543	.2241	.4191	.1494
4	.4108	.4954	.2241	.2401	.2241	.4763	.1372
5	.5601	.5335	.3361	.463	.3361	.4954	.5144
6	.5601	.5716	.5228	.5144	.4668	.5716	.5144
7	.6161	.5906	.5975	.4458	.5975	.5335	.5487
8		.5716	.5144	.4287	.5601	.4382	.5144
9		.4854	.4668	.3734	.5228	.3239	.4854
10		.4668	.2229	.2427		.1543	.1867
11	.1905	.1867	.12	.1494	.2286	.0857	.1307
12	.1334	.112	.112	.112		.0747	.1494
13	.0953	.112	.0934	.112	.1334	.056	.1307
14	.0953	.1494	.0934	.0934		.0686	.1494
15	.0953	.1494		.0934	.1715	.0934	.1494
16	.2858	.1494	.1494	.0934	.1905	.168	.1494
17	.381	.2987	.2427	.2801		.2572	.2241
18	.4382	.4668	.4287	.4108	.2858	.3921	.4668
19	.4954	.4108	.3086	.3742		.3547	
20		.3734	.3547	.2801		.2614	.1867
21	.381	.1867	.0686	.2241	.5906	.1867	.1494
22	.3429	.1867	.1372	.2241	.4954	.1867	.2801
23	.3429	.1494	.1029	.1494	.381	.1372	.1867
24	.12		.0187	.112	.1867		.1029
Max	.6161	.5906	.5975	.5144	.5975	.5716	.5487
Min	.0953	.112	.0187	.0934	.1334	.056	.1029
Avg	.3015	.3428	.2451	.2426	.3316	.2833	.2500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134087 / 33 KV JIRADGAON SUB STATION****Feeder No / Name : 207 / 11 KV MASHEGAON AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.7621	1.1831
3						.9526	1.6804
4						.9526	1.8111
5						1.1431	1.6632
6						1.5242	1.5432
7						1.5242	1.5432
8						1.7147	1.5604
9						2.0957	1.5432
11	2.1338	1.6804	1.4575	1.531	1.7147		.1524
12	2.3815	1.9605	1.989	1.587	1.8099		
13	2.0005	2.1658	2.332	1.6804	1.9052		
14	1.9624	2.2405		1.7177	1.9433		
15	1.9052	2.0538		1.8298	1.9433		
16	1.829	1.643		1.9418	1.9624		
17	1.8099	1.6804	2.2977	1.7737	1.9052		
18	1.7147	1.4937	2.2291	1.531	1.8099		
Max	2.3815	2.2405	2.332	1.9418	1.9624	2.0957	1.8111
Min	1.7147	1.4937	1.4575	1.531	1.7147	.7621	.1524
Avg	1.9671	1.8648	2.0611	1.6991	1.8742	1.3337	1.4089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

GHANSAWANGI S/DN.[702] BU 4702

Substation No/ Name :- 134088 / 33kv BOR-RANJANI

Feeder No / Name : 201 / 11 KV PARADGAON AG

FEEDER SEPERATION/PURE AG

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5335		.5487	.5487		
2	.5639	.6097	.5182	.6097	.5487		
3	.6706	.6859	.5487	.6401	.5487		
4	.7773	.7621	.6554	.6859	.5792		
5	.884	.8383	.823	.7773	.6097		
6	.112	.8688	1.0517		.6401		
7	1.1584	1.0669	1.0669	1.1736	.5182		
8	1.2041	1.1888	1.2498	1.2803	1.0974		
9	1.2041	1.0059	1.3413	1.2498	1.2193		
11						1.0822	1.1279
12						1.5394	1.448
13							1.3413
14						1.448	1.5546
15						1.6156	1.4327
16						1.448	1.3108
17						1.4022	1.1888
18						1.1736	.884
Max	1.2041	1.1888	1.3413	1.2803	1.2193	1.6156	1.5546
Min	.112	.5335	.5182	.5487	.5182	1.0822	.884
Avg	.7813	.8400	.9069	.8707	.7011	1.387	1.2860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134088 / 33kv BOR-RANJANI****Feeder No / Name : 202 / YEOLA GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0934	.1307	.0934	.112	.1307	.112
2	.056	.0934	.1307	.112	.0934	.1307	.1494
3	.056	.112	.1307	.1307	.0934	.1307	.1494
4	.0747	.1307	.1494	.168	.112	.1494	.1867
5	.0934	.1494	.2054	.168	.1307	.1867	.2614
6		.168	.1867	.1307	.0934	.1867	.2614
7	.1307	.1867	.112	.0747	.0747	.1494	.2241
8	.1494	.1867	.0934	.0747	.0747	.1494	.2241
9	.168	.1867	.168	.0747	.0373	.112	.2614
10		.2054	.3174	.056	.2241	.2241	.2987
11	.0934	.112	.2801	.1307	.1867	.1494	
12	.0747	.1307	.2241	.112	.1494	.112	
13	.0747	.0747	.1307	.1307			.2241
14	.0934		.1307	.1307	.056		.1867
15	.112	.112	.0934	.2241	.1494	.112	.2054
16	.1307	.1494	.1494	.2241	.2054	.168	.2614
17	.1307	.2054	.0934	.2241	.2241	.112	.1307
18	.168	.2614	.1867	.0934	.0747	.1867	.3361
19	.168	.2427	.2987	.1307	.2801	.3361	.2801
20	.1494	.2241	.2054	.1867	.2241	.2614	.2241
21	.1307	.1867	.1867	.1867	.1867	.2427	.2054
22	.112	.1867	.1867	.1494	.1867	.1867	.1867
23	.0934	.1494	.1307	.112	.1494	.168	.1494
24	.056	.0934	.1307	.0934	.0934	.1307	.112
Max	.168	.2614	.3174	.2241	.2801	.3361	.3361
Min	.056	.0747	.0934	.056	.0373	.112	.112
Avg	.1078	.1583	.1688	.1338	.1396	.1689	.2105

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****GHANSAWANGI S/DN.[702] BU 4702****Substation No/ Name :- 134088 / 33kv BOR-RANJANI****Feeder No / Name : 203 / 11 KV BOR RANJANI AG FEEDER SEPERATION/PURE AG****FEEDER Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.5053
2						.639	.5944
3						.8029	.6241
4						.6539	.6687
5						.6836	.7282
6						.7133	.7727
7						.7579	.8619
8						.9808	1.0254
9						1.1145	1.1294
11	1.3496	1.2334	1.174	.9362	1.1145		
12	1.4861	1.4266	1.3375	1.07	1.1888		
13	1.4118	1.3937	1.2483	1.3523	1.2483		
14	1.3672	1.4266	1.3375	1.4118	1.1888		
15	1.3375	1.4861	1.3523	1.2929	1.1591		
16	1.3226	1.278	1.2037	1.1591	1.278		
17	1.3077	1.2186	1.2334	1.1443	1.174		
18	1.0402	1.1888	1.0551	.9808	.9808		
Max	1.4861	1.4861	1.3523	1.4118	1.278	1.1145	1.1294
Min	1.0402	1.1888	1.0551	.9362	.9808	.639	.5053
Avg	1.3278	1.3315	1.2427	1.1684	1.1665	.7932	.7678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 201 / TALNI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	2.2291	2.0576	2.0919	1.8176	1.7833	1.8861
2	1.1317	2.2977	1.9547	2.1605	2.0576	1.749	1.8861
3	1.1317	2.2977	1.989	2.2291	2.0576	1.749	1.8861
4	1.1317	2.332	2.0233	2.2977	2.4006	1.8861	1.8861
5	1.1831	2.4006	2.0576	2.4006	1.8861	2.0233	1.8861
6	1.3375	2.4691	2.0576	2.572	2.4006	2.4006	1.8861
7	2.1262	2.2291	1.9204	2.0233	2.4006	2.0576	1.8861
8	2.572	2.7092	2.6063	2.5377	2.2291	2.572	2.2291
9	2.6063	2.6749	2.4006	2.6406	2.4691	2.6749	2.2291
10	2.4006	2.572	2.332	2.4348	2.4006	2.7092	2.3148
11	2.5034	2.4006	2.2634	2.4006	2.2291	2.1605	2.4006
12	1.7833	1.8861	2.1948	1.406	1.989	2.1948	2.0576
13	2.2291	3.0178	2.3663	2.4691	3.0521	2.2291	2.4863
14	3.1722	2.572	2.6063	2.915	2.9492	2.4006	1.8861
15	3.1893	2.7092	2.4006	3.0178	2.7435	2.4006	2.1262
16	3.0864	2.572	2.1262	3.0178	2.7778	2.4006	2.2634
17	2.7435	2.5377	2.2291	2.572	2.572	2.4006	2.1605
18	2.4691	1.8519	1.989	2.2291	2.4006	2.3148	1.9204
19	2.5377	2.4691	2.4348	2.4006	2.4006	2.2291	2.0748
20	2.5034	2.5034	2.3663	2.4691	2.2291	2.2291	1.8519
21	2.4348	2.4348	2.4348	2.4006	2.2634	2.2291	1.8519
22	2.4006	2.332	2.3663	2.2291	2.0576	2.0576	1.7147
23	2.2291		2.2291	1.989	1.8176	1.8861	1.7147
24	1.166	2.2291	2.0919	2.1948	1.9204	1.7833	1.8861
Max	3.1893	3.0178	2.6063	3.0178	3.0521	2.7092	2.4863
Min	1.1317	1.8519	1.9204	1.406	1.8176	1.749	1.7147
Avg	2.1334	2.4229	2.2291	2.3791	2.3134	2.1884	2.0155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 202 / IDOLI (ARDA)****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.3772	.2229	.1715	.1372	.1886
2	.2058	.2058	.5487	.4458	.1715	.1715	.1886
3	.2058	.3086	.6516	.6859	.3429	.1715	.1886
4	.2743	.6516	.7202	.823	.5144	.2058	.1886
5	.8573	.6859	.7888	1.0288	.6859		
6	.8916	.9259	.8916	1.166	.8573		
7	1.2003	1.0974	1.3032	1.2689	1.2003		
8	1.3375	1.3032	1.2689	1.3717	1.2003		
9	1.1317	1.0974	.823	1.2003	1.0631		
11						.9602	.7716
12						.9945	.9259
13						.9945	1.0288
14						.9602	1.0288
15						.8573	.9088
16	.2401	.2743	.2743	.2572	.2058	.8573	.7716
17	.2058	.3429	.3772	.2401	.2743	.8573	.8916
18	.3086	.2743	.3944	.2743	.2401	.8573	
19	.3086	.1715	.3944	.2743	.1029	.2401	
20	.2743	.2058	.3429	.2743	.1029	.3772	
21	.2058	.2058	.3086	.2058	.0857	.2058	
22	.2058	.2058	.2743	.2058	.1715	.2058	
23	.2058		.2401	.2058	.1715	.1886	
24	.1715	.2058	.2058	.2229	.2058	.1372	.1886
Max	1.3375	1.3032	1.3032	1.3717	1.2003	.9945	1.0288
Min	.1715	.1715	.2058	.2058	.0857	.1372	.1886
Avg	.4668	.4902	.5658	.5763	.4315	.5211	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 203 / PATHODA (HEALS)****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.8916	.8573	.9088	.703	.6859	.7716
2	1.0288	.9259	.9259	1.0288	.703	.7202	.8573
3	1.0288	.9945	1.0288	1.0631	.703	.7202	.8573
4	1.0288	1.0288	1.0974	1.1831	.6859	.7545	1.0288
5						.9602	1.2003
6						1.2003	1.3717
7						1.6461	1.5432
8						1.749	1.7147
9						1.5089	1.8861
11	1.749	1.5775	1.4403	2.0576	1.6975		
12	1.8861	1.5432	1.9547	2.1605	1.9719		
13	1.8519	2.1948	1.9204	2.2291	2.5034		
14	2.0576	2.1262	1.6461		2.0233		
15	2.0576	2.0576	1.6461		1.8861		
16	1.8861		1.6804	1.7147	1.8861	1.2003	1.2346
17	2.0576		1.6804	1.8347	1.0974	1.2003	1.5261
18	1.2003	2.0233	1.5775	1.6632	1.3717	1.2003	1.4918
19	1.2346	1.3717	1.166	1.5432	.8916	1.1145	1.2003
20	1.0974	1.0631	1.1831	1.0974	.9945	1.0288	1.2689
21	1.0631	1.0974	1.0974	1.0288	.8573	1.0288	.9602
22	.8916	.9259	.9945	.6859	.7202	.8573	.9602
23	.823		.9259	.703	.7202	.7716	.9602
24	.9431	.8916	.823	.9088	.6516	.6516	.7716
Max	2.0576	2.1948	1.9547	2.2291	2.5034	1.749	1.8861
Min	.823	.8916	.823	.6859	.6516	.6516	.7716
Avg	1.3775	1.3809	1.3136	1.3632	1.2260	1.0555	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 204 / AMBHODA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5377	1.8861	1.2346	1.2517	1.7833	2.0576	2.0576
2	2.5377	1.9204	1.2003	1.3032	1.7147	2.0576	2.0576
3	2.5377	1.9547	1.2689	1.3375	1.7147	2.1262	2.0576
4	2.5377	1.9547	1.3375	1.3717	1.7147	2.1262	2.0576
5	2.4348	1.989	1.406	1.4403	1.7147	2.2291	2.0576
6	2.4348	2.0233	1.4746	1.6461	2.2291	2.4006	
7	2.4006	1.9204	1.5432	1.989	2.2291	1.5432	1.7147
8	3.155	2.7435	2.8807	3.0521	1.7147	2.1948	2.0576
9	3.2579	2.572	2.8807	2.7778	2.7092	2.2634	2.2291
10	3.0864	3.0864	2.8464	3.0178	2.572	2.1605	2.2291
11	3.155	2.915	2.7778	2.7435	2.6063	1.9033	2.0576
12	2.7435	2.9835	2.572	2.4691	2.4006	1.6461	1.7147
13	2.572	2.4006	1.989	2.4006	1.989	2.2291	.7545
14	2.0233	2.1262		2.4006	2.1948	2.4348	2.0576
15	2.1262	2.0576		2.0748	2.0233	2.572	2.3148
16	2.2291	2.0576	1.6118	2.3148	2.2634	2.572	2.2977
17		2.332	1.8861	2.0576	1.8861	2.4863	2.1434
18		1.8861	1.7147	1.2689	1.6118	2.4006	1.989
19		1.4403	1.5775	1.7147	1.5432	1.7147	1.989
20		1.6118	1.6118	1.8861	2.2291	2.0576	2.0576
21	2.915	1.5432	1.6289	1.8861	1.989	2.0576	2.1605
22	1.8861	1.406	1.3546	1.8861	2.4006	2.0576	2.0576
23	2.2634		1.3032	2.0062	2.2291	2.0576	1.7147
24	2.6235	1.8861	1.2689	1.286	1.9204	2.1948	2.0576
Max	3.2579	3.0864	2.8807	3.0521	2.7092	2.572	2.3148
Min	1.8861	1.406	1.2003	1.2517	1.5432	1.5432	.7545
Avg	2.5729	2.1172	1.7895	1.9826	2.0576	2.1476	1.9950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 205 / MANTHA TOWN-1****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.0514	.0514	.1029	.0686	.0686
2	.1029	.1029	.0514	.0514	.1029	.0686	.0686
3	.1029	.1029	.0514	.0514	.1029	.0857	.0686
4	.1029	.1029	.0686	.0686	.1029	.0857	.0686
5	.1029	.1029	.0857	.0857	.1029	.0857	.0857
6	.1029	.1029	.0857	.0857	.1029	.1029	.0857
7	.1029	.1029	.0857	.12	.1029	.1029	.1029
8	.1029	.1029	.1029	.1029	.1029	.1029	.1029
9	.1029	.1029	.1029	.12	.1029	.1029	.1029
10	.1029	.1029	.1029	.0857	.0857	.1029	.1029
11	.1029	.1029	.1029	.0857	.0857	.1029	.1029
12	.0686	.1029	.1029	.0857	.0857	.1029	.1029
13	.1029	.1029	.1029	.0857	.0857	.0686	.1372
14	.0686	.1029	.1029		.0686	.0686	.1372
15	.1029	.1029	.0857	.0857	.1029	.0857	.0857
16	.1029	.1029	.0857	.0857	.0686	.1029	.0857
17	.1029	.1029	.1029	.0857	.1029	.1029	.0857
18	.1029	.1029	.1029	.1029	.1029	.1029	.12
19	.1029	.1029	.1029	.1029	.1029	.0857	.5144
20	.1029	.1029	.0857	.1029	.1029	.0857	.5487
21	.1029	.1029	.0686	.1029	.1029	.0857	.1029
22	.0686	.1029	.0686	.1029	.1029	.0857	.1029
23	.0686		.0514	.1029	.0686	.0686	.1029
24	.1029	.0686	.0686	.0514	.1029	.0686	.0686
Max	.1029	.1029	.1029	.12	.1029	.1029	.5487
Min	.0686	.0686	.0514	.0514	.0686	.0686	.0686
Avg	.0972	.1014	.0843	.0872	.0957	.0886	.1315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 206 / INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3086	.2058	.1372	.583	.4115	.2401
2	.3772	.2743	.1715	.1715	.5144	.4115	.2401
3	.3772	.2743	.2058	.1372	.5144	.3772	.2401
4	.3772	.2401	.1715	.1372	.5144	.3772	.2401
5	.3772	.2401	.1715	.1372	.5144	.4115	.2058
6	.3772	.2401	.2058	.1715	.5144	.4115	.1715
7	.3429	.2401	.2058	.1715	.5144	.1715	.1372
8	.3772	.1029	.2401	.2743	.3429	.1372	.1715
9	.1372	.1715	.1715	.2743	.2401	.1372	.3429
10	.2572	.2058	.1372	.4115	.3429	.2401	.4801
11	.2572	.2401	.1029	.4115	.4115	.3086	.4801
12	.4458	.2743	.1029	.4458	.3429	.2743	.4458
13	.4115	.2401	.1372	.3772	.2743		.3772
14	.4458	.2401	.0343	.3772	.3429		.3429
15	.4115	.2058	.0343	.3429	.3429	.2401	.3429
16	.4458	.2058	.0343	.3772	.4801	.1715	.4115
17	.4115	.1372	.0343	.3429	.4115		.4115
18	.4115	.1372	.0343	.3086	.2743	.1372	.2401
19	.3429	.1372	.0343	.3429	.2401	.1372	.3429
20	.2743	.1715	.0343	.3772	.2743	.1372	.3429
21	.3429	.1715	.1372	.4801	.3429	.1715	.3429
22	.3086	.2058	.1372	.5144	.4115	.2058	.4458
23	.3086		.1372	.5144	.4115	.2401	.4458
24	.4115	.3086	.2058	.1372	.5487	.4115	.2401
Max	.4458	.3086	.2401	.5144	.583	.4115	.4801
Min	.1372	.1029	.0343	.1372	.2401	.1372	.1372
Avg	.3586	.2162	.1286	.3072	.4044	.2629	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134012 / MANTHA****Feeder No / Name : 207 / MANTHA TOWN-II****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.7545	.7545	.6859	.6516	.7716
2	.7545	.7545	.823	.823	.6859	.6516	.7716
3	.7545	.7545	.9602	.9602	.8573	.7202	.7716
4	.8573	.8573	1.0288	1.0631	.6859	.7545	.8573
5	.9602	.8916	1.1317	1.2003	1.0288	.8916	1.2003
6	1.2346	1.0288	1.3032	1.3032	1.2003	1.2346	1.3717
7	1.6804	1.6804	1.4746	1.5775	1.6118	1.5432	1.7147
8	1.3032	1.6804	1.749	1.6804	1.6118	1.6461	1.5432
9	1.6804	1.7833	1.6461	1.6804	1.6461	1.5432	1.5432
10		1.6461	1.6118	1.5775	1.3717	1.4403	1.3717
11	1.8861	1.5775	1.6118	1.4746	1.406	1.4403	
12	1.406	1.5432	1.5432	1.3375	1.3717	1.2003	1.5432
13	1.3717	1.4746	1.3717	.8573	1.2689	.7888	1.4575
14	1.2346	1.406	1.2689	1.2003	1.2689	.7202	1.3717
15	1.3032	1.3375	1.2346	1.0631	1.3717	.7716	
16	1.2346	1.406	1.2003	1.1145	1.4403	.8573	
17	1.5775	1.5089	1.4746	1.5089	1.3717	1.0288	
18	1.6804	1.5432	1.3717	1.5432	1.3889	1.2003	1.3717
19	1.2689	1.3717	1.3375	1.3717	1.1317	1.2003	1.3717
20	1.0974	1.2346	1.0974	1.0288	.9945	1.1145	1.0974
21	1.0288	.9602	.9945	1.0288	.9602	1.0288	.9259
22	.8916	.8916	.8916	.7545	.7888	.8573	.8573
23	.823		.8573	.7888	.6859	.7888	.7545
24	.7545	.7888	.7545	.823	.7202	.6516	.7716
Max	1.8861	1.7833	1.749	1.6804	1.6461	1.6461	1.7147
Min	.7545	.7545	.7545	.7545	.6859	.6516	.7545
Avg	1.1973	1.2554	1.2289	1.1881	1.1481	1.0302	1.1720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134020 / DAHIPHAL KHANDARE****Feeder No / Name : 202 / DAHIFAL****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.9431	1.1317	1.1317	1.2003	1.2003	2.0576
2	.8573	.9431	1.1317	1.1317	1.2003	1.3717	2.572
3	.8573	.9431	1.1317	1.1317	1.2003	1.3717	2.7434
4	.8573	1.0288	1.1831	1.1831	1.2003	1.5432	3.6008
5						1.7147	4.5268
6						2.0576	4.8012
7						2.2291	4.8012
8						2.572	5.487
9						2.572	5.144
11	3.0521	2.7949	1.8861	2.9492	2.7435		
12	3.1722	3.2579	1.9719	3.0864	3.0864		
13	3.1722	3.3093	2.3148	3.0864	3.2579		
14		3.4122	2.572	2.7435	3.3436		
15	3.0864	3.0864	2.692		3.3436		
16	3.1207	3.3093	2.7435	3.0864	3.0864	1.3718	1.3718
17	3.2579	3.3951	1.3717	3.0864	3.0864	1.7146	1.4404
18	2.915	2.0576	1.7147	2.572	3.0864	2.1262	1.7146
19	.7888	1.3546	1.3546	1.3717	1.3717	2.0576	1.989
20	.8573	1.3546	1.3717	1.2003	1.3717	2.0576	1.8518
21	.9259	1.286	1.286	1.3717	1.3717	2.0576	1.8518
22	1.0631	1.1831		1.3717	1.2003	2.0576	
23	1.0288	1.1317	1.1831	1.2003	1.2003	2.0576	
24	.9431	1.0288	1.1317	1.1317	1.2003	1.2003	2.0576
Max	3.2579	3.4122	2.7435	3.0864	3.3436	2.572	5.487
Min	.7888	.9431	1.1317	1.1317	1.2003	1.2003	1.3718
Avg	1.8176	1.9900	1.6572	1.9315	2.0862	1.8518	3.0007

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134020 / DAHIPHAL KHANDARE****Feeder No / Name : 203 / KOKARSHA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2572	.2572	.3429	.1715	.1715
2	1.0288	1.2003	.7716	.7716	.6859	.1715	.1715
3	1.0288	1.2003	.9774	.9774	.6859	.1715	.1715
4	1.1145	1.286	1.1317	1.2346	.8573	.1715	.1715
5	1.2003	1.286	1.3375	1.3717	1.0288		
6	1.2003	1.3717	1.5432	1.5947	1.0288		
7	1.3717	1.4403	1.6461	1.7147	1.2003		
8	1.2346	1.2346	1.5947	1.5947	1.2003		
9	1.2003	1.1317	1.2346	1.3032			
11						1.2003	1.0288
12						1.1145	1.3717
13						1.286	1.3717
14						1.3717	1.3375
15						1.2003	1.286
16	.1372	.1886	.1543	.1715	.1715	1.1145	1.3375
17	.1715	.2229	.1886	.1715	.1715	1.1145	1.2003
18	.1715	.2743	.2915	.1715	.1715	1.0288	1.2003
19	.1715	.2915	.3086	.1715	.1715	.2058	.2058
20	.1715	.3086	.3086	.1715	.1715	.2058	.2058
21	.2058	.2915	.2743	.1715	.1715	.2058	.1715
22	.1715	.2915	.2743	.1715	.1715	.1715	
23	.1715	.2743	.2572		.1715	.1715	
24	.1715	.1715	.2572	.2572	.1715	.1715	.1715
Max	1.3717	1.4403	1.6461	1.7147	1.2003	1.3717	1.3717
Min	.1372	.1715	.1543	.1715	.1715	.1715	.1715
Avg	.6164	.7021	.7116	.7222	.5043	.6249	.7234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134020 / DAHIPHAL KHANDARE****Feeder No / Name : 204 / PEWA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.5432	.823	.9774	1.2003	1.2003	.8916
2	1.0288	1.0288	.823	1.0288	1.2003	1.3717	1.5432
3	1.0288	1.0288	.8745	1.0288	1.2003	1.5432	1.8004
4	1.0288	1.0288	.8745	1.0288	1.2003	1.7147	1.8861
5						1.7147	1.9719
6						2.0576	2.2291
7						2.0576	2.572
8						2.0576	2.4006
9						2.2291	2.0576
11	2.1434	1.9719	1.9719	2.2977	2.0576		
12	2.3148	2.4006	2.4691	2.572	2.572		
13	2.3663	2.6406	2.8635	2.572	2.572		
14		2.6578	2.7949	2.572	2.0576		
15	2.1434	2.692	1.5432	2.572	2.0576		
16	2.5549	2.6235	2.452	2.6578	2.0576	.6516	.7202
17	2.2634	2.4006	2.2291	2.572	2.0576	.6859	.7716
18		1.0288	1.8004	2.572	2.0576	.7202	.8573
19	1.1145	.8745	1.0288	1.2003	1.3717	.9945	.9602
20	1.0288	.8745	1.1317	1.2003	1.3717	1.0288	.9259
21	1.0974	.8745	1.1831	1.1145	1.3717	.9259	.9259
22	1.0288	.823	1.0802	1.3717	1.2003	.8916	
23	1.0288	.823	1.0288	1.3717	1.2003	.8916	
24	1.0288	1.0288	.823	.9774	1.2003	1.2003	.8916
Max	2.5549	2.692	2.8635	2.6578	2.572	2.2291	2.572
Min	1.0288	.823	.823	.9774	1.2003	.6516	.7202
Avg	1.5143	1.5747	1.5442	1.7604	1.6670	1.3298	1.4628

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134023 / WATUR****Feeder No / Name : 201 / LAWANI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17
HR	Load (MW)
24	.5658
Max	.5658
Min	.5658
Avg	.5658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134023 / WATUR****Feeder No / Name : 203 / Dahifal****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17
HR	Load (MW)
24	1.9404
Max	1.9404
Min	1.9404
Avg	1.9404

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 204 / SHESH NARYAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	30-NOV-17
HR	Load (MW)
24	.081
Max	.081
Min	.081
Avg	.081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134023 / WATUR

Feeder No / Name : 205 / WAJODA EXPRESS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	30-NOV-17
HR	Load (MW)
24	.0301
Max	.0301
Min	.0301
Avg	.0301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134023 / WATUR****Feeder No / Name : 206 / wadhona****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17
HR	Load (MW)
24	2.652
Max	2.652
Min	2.652
Avg	2.652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134050 / JAIPUR****Feeder No / Name : 201 / V.WADGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7661	1.0288	1.4022	1.4899	1.3847	1.1218	
2	1.7661	1.3717	1.9281	1.7528	1.56	1.0517	1.2346
3	2.3148	2.0576	2.0157	1.9281	1.7528	1.0166	1.286
4	2.4863	2.572	2.2786	2.0157	2.1033	1.1568	1.3375
5	2.572	2.8292	2.8921	2.2786	2.2786		
6	3.2407	3.2579	3.2427	2.3663	2.7168		
7	3.3779	3.3951	1.2269	2.7168	2.857		
8	3.2407	3.2579	1.0517	2.9447	3.1375		
9	3.0007	3.1893		2.8921	3.155		
11						2.2436	2.3148
12						2.1262	3.0521
13						2.6578	3.1722
14						2.572	3.0007
15						2.5377	2.9492
16	1.2003	1.387	1.5249	1.5775	1.5775	3.0178	3.0864
17		1.5604	1.7353	1.9281	1.6476	3.0007	3.0007
18	1.2003	1.7337	1.7878		1.8404	2.3148	2.692
19	1.8861	1.8204	1.7002		1.7177	1.4575	1.3717
20	1.8004	1.647	1.5775	1.5424	1.4022	1.4575	1.286
21	1.5432	1.4737	1.5424	1.3146	1.1393	1.286	1.286
22	1.4403	1.387	1.4022	1.262	1.2269	1.2003	1.2003
23	1.3717	1.387	1.4022	1.2269	1.1919	1.2003	1.2003
24	1.4575	1.2174	1.4022	1.4022	1.2269	1.1568	1.2003
Max	3.3779	3.3951	3.2427	2.9447	3.155	3.0178	3.1722
Min	1.2003	1.0288	1.0517	1.2269	1.1393	1.0166	1.2003
Avg	2.0979	2.0318	1.7713	1.9149	1.8842	1.8098	2.0395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134050 / JAIPUR****Feeder No / Name : 202 / WAZAR S.****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5487	.1753	.5609	.5083	.5609	.6859
2	.583	.583	.1753	.6135	.4908	.631	.9431
3	.6001	.6516	.1753	.6661	.5083	.7011	1.0288
4	.6173	.7545	.1753	.7011	.6135	.8764	1.2003
5						1.0517	1.286
6						1.4723	1.7147
7						1.5775	1.9719
8						1.7528	2.1434
9						1.4899	2.1776
11	1.5432	1.3375		1.4198	1.2269		
12	1.7318	2.0576		1.595	1.5775		
13	1.6804	1.9071		1.7353	1.6651		
14	1.6461	1.8724		1.9281	1.4723		
15	1.6289	1.7337	1.5775	1.6651	1.3321		
16		1.595	1.7002	1.56	1.4022	.6001	
17		1.5604	1.8404	1.5249	1.262	.823	
18	1.3717		1.893	1.2971	1.2269	.9431	.5487
19	1.0288	.2774	.964	.7712	.964	.9431	.583
20	.8573	.2774	.964	.7011	.8063	.8573	.5487
21	.7545	.2601	.8764	.6661	.7011	.8573	.5144
22	.6859	.2601	.7888	.631	.631	.8573	.5144
23	.6173	.2427	.7011	.6135	.5959	.8573	.5487
24	.5487	.5487	.1753	.6135	.5959	.5609	.6859
Max	1.7318	2.0576	1.893	1.9281	1.6651	1.7528	2.1776
Min	.5487	.2427	.1753	.5609	.4908	.5609	.5144
Avg	1.0320	.9687	.8701	1.0702	.9767	.9674	1.0685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN****Feeder No / Name : 202 / PATODA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5959	.6201	.5792	.7316	.5853	.631
2	.695	.5847	.6024	.6219	.5853	.7655	.6836
3	.5853	.5959	.5847	.6154	.5487	.7316	.7442
4	.724	.6024	.6024	.5792	.5853	.7842	.7442
5						.7682	.8954
6						.7682	1.2403
7						.8779	1.5061
8						1.3535	1.6301
9						1.6461	1.6478
11				1.0974			
12	1.3575	1.1043	1.4175	1.134	1.4815		
13		1.5415	1.4842	1.3169	1.4998		
14	1.3112	1.6832	1.3756	1.4632	1.4815		
15	1.3496	1.6478	1.6118	1.4815	1.4632		
16	1.3847		1.6118	1.4632	1.4266	.3294	.5548
17	1.335		1.4632	1.4632	1.1523	.567	.7087
18	.8063	1.1517	1.39	1.4632	1.1706	.6485	.7802
19	.7537	.929	.6584	.7499	.7316	.6135	.6733
20	.7087	.7011	.6154	.7316	.7316	.5258	.6201
21	.691	.7087	.6584	.695	.7682	.5609	.567
22	.6626	.6485	.6348	.7133	.5853	.5493	.5258
23	.6626	.6379	.6283	.7316	.6219	.567	.5258
24	.6154	.6068	.5959	.5792	.724	.5853	.567
Max	1.3847	1.6832	1.6118	1.4815	1.4998	1.6461	1.6478
Min	.5853	.5847	.5847	.5792	.5487	.3294	.5258
Avg	.8892	.9160	.9738	.9711	.9582	.7348	.8470

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN****Feeder No / Name : 203 / IDOLI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.5775	1.7337	1.6827	1.5546	1.307	1.3073
2	1.4998	1.7353	2.1033	2.0119	2.1948	1.2437	1.3112
3	1.7924	1.8959	2.2502	2.3411	2.1948	1.2803	1.3112
4	2.0119	2.1033	2.5833	2.8715	2.1948	1.2803	1.3112
5	2.1948	2.5766	2.722	2.7069	2.1948		
6	2.5789	2.8349	2.8045	3.4751	2.7618		
7	2.963	2.8349	2.9473	3.3288	2.963		
8	3.1459	3.3133	2.982	3.4385	3.1276		
9	3.0727	3.3653	2.8349	3.4751	2.7149		
11	.0183					3.1459	2.826
12						3.155	3.4155
13						3.0864	3.3634
14						3.3665	2.572
15						3.4179	3.3128
16	1.6301	1.9667	1.7177	1.9204	1.6461	3.4551	3.4179
17	1.8959	2.4013	1.9071	1.9387	1.7375	2.9797	3.2941
18	2.167	2.0332	2.0271	2.0851	1.6461	2.9271	2.857
19	1.9631	1.7353	1.97	1.6461	1.5729	1.647	1.2048
20	.1753	1.4352	1.7193	1.6095	1.5364	1.5775	1.1269
21	1.773	1.4022	1.643	1.4998	1.5729	1.4737	1.1694
22	1.6301	1.2094	1.4842	1.5364	1.3169	1.4529	1.1517
23		1.134	1.4685	1.4083	1.3817	1.2934	1.1393
24	1.4632	1.5083	1.543	1.5364	1.3717	1.2803	1.2971
Max	3.1459	3.3653	2.982	3.4751	3.1276	3.4551	3.4179
Min	.0183	1.134	1.4685	1.4083	1.3169	1.2437	1.1269
Avg	1.8577	2.0590	2.1356	2.2507	1.9824	2.1872	2.0772

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

MANTHA SUB-DIVISION[796] BU 4796

Substation No/ Name :- 134057 / 33/11 KV IDOLI SSTN

Feeder No / Name : 204 / express water supply
INDUSTRIA Feeder KV- 11 /
OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0177	.0177	.0189	.0183	.0181	.0177
2	.0183	.0175	.0177	.0189	.0183	.0185	.0177
3	.0185	.0173	.0177	.0189	.0183	.0187	.0177
4	.0187	.0173	.0177	.0189	.0183	.0183	.0179
5	.0187	.0173	.0179	.0189	.0185	.0183	.0179
6	.0187	.0175	.0179	.0189	.0183	.0183	.0179
7	.0187	.0175	.0179	.0189	.0187	.0183	.0179
8	.0187	.0179	.0179	.0189	.0187	.0183	.0179
9	.0187	.0179	.0179	.0181	.0183	.0183	.0179
10	.0187	.0179	.0177	.0185	.0181	.0183	.0177
11	.0181	.0177	.0177	.0183	.0187	.0183	.0686
12	.0181	.0175	.0177	.0185	.0187	.0177	.0173
13	.0177	.0175	.0189	.0181		.0177	.0179
14	.0177	.0177	.0189	.0185	.0183	.0177	.0179
15	.0179	.0175	.0189	.0185	.0183	.0177	.0179
16	.0177	.0175	.0189	.0187	.0183	.0177	.0177
17	.0177	.0175		.0181	.0183	.0175	.0177
18	.0179	.0177	.0189	.0183	.0183	.0177	.0179
19	.0179	.0177	.0189	.0183	.0183	.0179	.0177
20	.0177	.0175	.0189	.0185	.0187	.0179	.0173
21	.0181	.0175	.0189	.0183	.0187	.0179	.0177
22	.0181	.0173	.0189		.0183	.0179	.0177
23	.0181	.0177	.0189	.0183	.0183	.0177	.0177
24	.0183	.0177	.0177	.0189	.0183	.0187	.0177
Max	.0187	.0179	.0189	.0189	.0187	.0187	.0686
Min	.0171	.0173	.0177	.0181	.0181	.0175	.0173
Avg	.0182	.0176	.0183	.0186	.0184	.0181	.0199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134070 / Talni****Feeder No / Name : 201 / 11 KV DEVTHANA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	1.4232	1.3717	.823	.8573	.8402	.4801
2	1.5261	1.4575	1.4575	1.406	1.6461	.6859	.5144
3	1.5432	1.5432	1.5775	1.5604	1.7318	.6516	.5316
4	1.5775	1.7318	1.749	1.6289	2.0062	.6516	.583
5	2.1948	2.0576	1.9719	2.0748	2.1262		
6	2.2634	2.2291	2.1948	2.1948	2.1091		
7	2.3663	2.2977	2.2634	2.2634	2.2634		
8	2.4177	2.4006	2.4863	2.4006	2.3148		
9	2.3834	1.8861	2.0919	2.2291	2.2634		
11						2.1776	.6516
13							.7373
15		.1372				.463	.6001
16	.9774	.9774	.8916	.5487	.9945	.7545	1.3375
17	1.1145	1.0631	1.046	1.0288	1.0288	.583	
18	1.2174	1.2517	1.1317	1.0802	1.0631	.7888	1.3889
19	1.1488	1.1317	1.0631	.9774	1.1145	.703	.5144
20	1.0631	1.0288	.9945	.8916	1.046	.6173	.6687
21	1.0117	.9945	.9431	.8573	.9431	.5658	.583
22	.8745	.9774	.8573	.823	.9602	.5144	.6859
23	.8573	.9088	.8402	.823	.8573	.463	.6173
24	.8916	.8059	.8745	.8402	.8402	.823	.4287
Max	2.4177	2.4006	2.4863	2.4006	2.3148	2.1776	1.3889
Min	.8573	.1372	.8402	.5487	.8402	.463	.4287
Avg	1.4613	1.3844	1.4337	1.3584	1.4537	.7522	.6882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134070 / Talni****Feeder No / Name : 203 / 11 KV TALNI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6344	.5658	.6516	.6516	.6516	.8745
2	.6173	.6344	.5658	.6516	.6687	1.3717	1.3032
3	.7202	.6687	.6516	.7202	.6516	1.5261	1.3546
4	.7373	.7202	.6859	.7716	.6344	1.8176	1.4746
5						1.9204	1.6118
6						2.0062	1.6804
7						1.8861	1.749
8						1.9547	1.8519
9						1.9204	1.8004
11	1.6289	1.3375	1.6289	1.5089	1.5775		
12	1.7318	1.5089	1.5947	1.3546	1.5775		
13	1.7147	1.2346	1.6461	1.4403	1.6289		
14		1.7833	1.6289	1.4918	1.3889		
15	1.7318	1.6975	1.4575	1.5089	1.4403		
16	1.6461	1.8004	1.5604	1.0631	1.2517	.6173	.6516
17	1.6289	1.6461	1.5775	1.6461	1.4403	.7716	.8916
18	1.6118	1.3889	1.5432	1.6289	1.5261	.9431	1.0288
19	.9945	.9088	.8916	1.046	.8745	1.0117	1.046
20	.8916	.8059	.8402	.8573	.7888	.8059	.9602
21	.7716	.7373	.7716	.7202	.6687	.7373	.7545
22	.6859	.6859	.703	.6859	.6859	.6516	.6344
23	.6687	.583	.703	.6859	.6516	.6173	.5487
24	.6173	.6344	.583	.6859	.6859	.6516	.6687
Max	1.7318	1.8004	1.6461	1.6461	1.6289	2.0062	1.8519
Min	.6001	.583	.5658	.6516	.6344	.6173	.5487
Avg	1.1176	1.0783	1.0888	1.0622	1.0441	1.2146	1.1603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134071 / pangari gosavi****Feeder No / Name : 201 / pangari 11 kv****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4287	.1696	.3944	.2572	.6516	.6173
2	.3772	.4287		.3944	.3429	.9431	.8916
3	.3429	.4287		.3944	.3772	1.1145	1.1145
4	.4115	.4287	.5087	.3944	.2572	1.286	1.286
5						1.406	1.286
6							1.3032
7						1.406	1.1145
8						1.2346	1.286
9						1.2346	1.4403
11	1.3717						
12	1.6289	1.4415		1.6289	1.5261		
13	1.5432	.9835		1.6289			
14				1.5242	1.286		
15	1.5432	1.4918		1.4575	1.2689		
16			1.3717	1.4918		.5316	.5144
17				1.6975	1.1869	.3429	
18	.8573			1.4575	1.0343	.3429	
19	.6001			.3429	.3429	.3429	.5144
20	.5144			.3772	.3429	.3048	
21	.4287		.4287	.3429	.3429	.3429	.4287
22	.4287		.4287	.3429	.3429	.4115	.4287
23	.4287	.301	.4287	.3429	.3429	.4115	.4287
24	.3429	.4287	.3429	.4287	.2572	.3429	.4287
Max	1.6289	1.4918	1.3717	1.6975	1.5261	1.406	1.4403
Min	.3429	.301	.1696	.3429	.2572	.3048	.4287
Avg	.7442	.7068	.5256	.8613	.6339	.7441	.8722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134071 / pangari gosavi****Feeder No / Name : 202 / wai****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4232	1.286	.2572	.2572
2		1.4232	1.5089	.3429	.3086
3		1.4232	1.8861	.3086	.3086
4		1.4575	1.6289	.2572	.2572
5		1.4575	1.6975		
6		1.6289	1.8861		
7		2.0576	2.0576		
8		2.0576	1.6975		
9		1.8861	1.6118		
11				1.286	1.3717
12				1.8861	1.8861
13				2.0576	1.9719
14				1.9719	1.6289
15				1.8861	1.5432
16	.5144	.1715		1.8519	1.5432
17		.1715	.2374	1.2003	
18		.1715	.2401	1.1317	
19		.2572	.2572	.3429	.4287
20		.2572	.3429	.3429	
21	1.8861	.3429	.3772	.3429	.3429
22	1.7147	.3429	.3429	.3429	.3429
23	1.7147	.3772	.3429	.3429	.3429
24		1.5432	.4115	.3429	.3772
Max	1.8861	2.0576	2.0576	2.0576	1.9719
Min	.5144	.1715	.2374	.2572	.2572
Avg	1.4575	1.0250	1.0478	.9164	.8607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****MANTHA SUB-DIVISION[796] BU 4796****Substation No/ Name :- 134071 / pangari gosavi****Feeder No / Name : 203 / 11 kv kathala feeder
Feeder KV- 11 / OUTGOING****SINGLE PHASING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	1.0288	1.4413	.3429	.1715	.6001	.6516
2	.3772	1.0288		.3429	.2572	.9431	.8916
3	.3429	1.0288		.3429	.3048	.6516	1.0631
4	.4287	1.0288	1.9669	.3429	.3772	1.1145	1.1831
5						1.286	1.286
6						1.0631	1.0117
7						1.0631	1.1145
8						1.1145	1.286
9						1.286	1.4403
11	1.2003			1.1145			
12	1.5432	1.4712		1.6632	1.6617		
13	1.5432	1.3546		1.6975			
14	1.8004			1.6289	1.6975		
15	1.5432	1.4403		1.6289	1.2548		
16			1.8004	1.5432			.5144
17				1.6289	1.2548	.3429	
18	.7716			1.6289	1.0174	.3429	
19				.2572	.3429	.3429	.4287
20	.7716			.3086	.4287		
21	.9431		.5144	.2743	.4481	.3429	.4287
22	.9431		.5144	.2572	.3429	.4287	.4287
23	1.0288	1.6108	.4287	.2572	.3429	.4287	.4287
24	.3429	1.0288	1.6108	.4287	.3429		.4115
Max	1.8004	1.6108	1.9669	1.6975	1.6975	1.286	1.4403
Min	.3429	1.0288	.4287	.2572	.1715	.3429	.4115
Avg	.9282	1.2245	1.1824	.8716	.6830	.7567	.8379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 201 / TOWN-1****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.6001	.5316	.5316	.5487	.583
2	.5144	.5144	.6001	.5316	.5316	.5487	.583
3	.5144	.5144	.6859	.6001	.6001	.6001	.6859
4	.6001	.6001	.8573	.8573	.7716	.7716	.8573
5	.823	.7202	1.0288	1.0288	1.0288	1.0288	1.1488
6	1.2174	1.2689	1.3032	1.3375	1.3375	1.3717	1.4575
7	1.5432	1.6461	1.5432	1.5604	1.6632	1.6975	1.8004
8	1.6118	1.5432	1.8004	1.5432	1.749	1.8347	1.7833
9	1.3375	1.5261	1.7147	1.4575	1.6461	1.6118	1.6461
10	1.286	1.286	1.5432	1.2174	1.3375	1.4232	1.3717
11	.9259	1.1488	1.5432	1.1831	1.3375	1.2003	1.1831
12	.8745	.9431	1.406	1.0288	1.1145	.7716	.8573
13	.9259	.8059	1.2003	.8573	.8916	.6687	.6516
14	.6859		.8573	.8059	.7545	.7373	.7202
15			.6859	.7888	.7716	.7373	.7716
16			.8745		.7545	.9088	.9431
17		1.3717	1.2174	1.2517	1.2346	1.2174	1.1831
18		1.4746	1.4403	1.5261	1.4746	1.5432	1.3375
19		1.286	1.1831	1.286	1.2003	1.286	1.1145
20		1.0288	1.0117	1.0288	.9431	1.0117	1.0117
21		.9526	.9088	.8573	.8745	.8573	.7888
22	.6687	.8573	.6687	.7202		.7202	.7373
23	.5487	.6859	.6001	.583	.6001	.6516	.6516
24	.5487	.5487	.6001	.5658	.5487	.583	.6001
Max	1.6118	1.6461	1.8004	1.5604	1.749	1.8347	1.8004
Min	.5144	.5144	.6001	.5316	.5316	.5487	.583
Avg	.8926	1.0129	1.0781	1.0064	1.0303	1.0138	1.0195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 202 / TOWN-II****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8402	.823	.7545	.7888	.7545	.7716
2	.6859	.8402	.823	.7545	.8745	.7545	.7716
3	.6859	.7716	.8573	.8573	.8745	.823	.8573
4	.7716	.8573	1.0288	1.0288	1.0288	1.0288	1.0288
5	.9088		1.2003	1.2003	1.2003	1.2003	1.286
6	1.3546	1.4403	1.4746	1.5432	1.4746	1.5432	1.6461
7	2.0919	2.0405	1.9204	1.9547	1.8347	1.9204	2.1262
8	2.0062	1.8861	2.1262	2.0062	2.0576	2.0919	2.1605
9	1.8347	1.9547	2.0576	1.749	2.0233	1.8861	1.8176
10		1.7147	1.9204	1.5089	1.8519	1.6289	1.7147
11	1.4918	1.406	1.6461		1.6289		1.5089
12	1.4232	1.2689	1.5432	1.3889	1.4403	1.406	1.2689
13	1.3032	1.2689	1.3717	1.3546	1.2346	1.2689	1.3203
14	1.2346	1.2346	1.2003	1.2346	1.0974	1.0802	1.2003
15		1.2003	1.0974	1.1831	1.2003	1.046	1.1317
16		1.3717	1.166		1.0974	1.1317	1.5775
17		1.5432	1.3546		1.3717	1.3375	1.5261
18		1.8176	1.8004	2.1776	1.6289	1.6461	1.8176
19		1.749	1.6975	1.8861	1.6118	1.6804	1.6975
20		1.4918	1.3889	1.5432	1.2689	1.4232	1.4918
21		1.2689	1.2346	1.3032	1.166	1.2174	1.2346
22	1.0974	1.1431	1.0288	1.1317		1.0802	1.0631
23	.9088	.9431	.8745	.9088	.8573	.8745	.9431
24	.8402	.8402	.823	.7888	.8573	.8059	.823
Max	2.0919	2.0405	2.1262	2.1776	2.0576	2.0919	2.1605
Min	.6859	.7716	.823	.7545	.7888	.7545	.7716
Avg	1.2132	1.3432	1.3524	1.3456	1.3248	1.2882	1.3660

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 203 / SAIBABA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118	1.5432	1.8861	1.7833	1.7147	1.4232	1.4403
2	1.7147	1.7147	2.4006	2.2291	2.3148	1.4746	1.4403
3	2.2291	.7716	2.7435	2.572	2.572	1.4746	1.5432
4	2.572	.8573	2.915	2.915	2.7435	1.7147	1.7147
5	2.692	.9088	3.2579	3.0864	3.0864	1.8861	1.8861
6	2.915	3.155	3.4808	3.3951	3.3608	2.0576	
7	1.5432	1.5261	1.8861	1.6461	1.6632	2.3663	1.8176
8	1.6289	1.5432	1.7147	1.6804	1.5775	2.5549	1.989
9	1.5604	1.6289	1.5089	1.6461	1.5432	2.5206	1.8347
10			1.4746	.5144	2.0576		1.2765
11	2.5892	2.3148	2.4006		1.869	1.3717	1.0802
12	3.155	2.9664	3.1722	.3086	2.2291	1.4575	1.046
13	3.0521	2.9664	3.2065	1.8176	2.4348	1.4918	1.0288
14	3.155	3.1207	3.0178	2.4348	2.5034	1.5261	1.0974
15		3.0178	2.8635	2.452	2.0919	2.2291	1.1145
16		.4001	1.9204		1.7147	2.4348	1.1317
17		.5144	2.7435	2.7778	2.4348	2.5549	2.2634
18		1.1317	2.0748	2.2462	1.4746	2.4863	2.6235
19		1.8519	2.1262	1.9204	1.8347	.2267	1.8861
20		2.0405	1.9376	1.8861	1.869	1.7147	1.6975
21		2.2291	1.9204	1.8861	1.8347	1.5775	1.5432
22	1.6975	2.2634	1.9376	1.8861		1.5432	1.4575
23	1.6461	1.7147	1.9204	1.8176	1.5432	1.4746	1.3546
24	1.6118	1.6461	1.6289	1.8861	1.749	1.5432	1.4403
Max	3.155	3.155	3.4808	3.3951	3.3608	2.5549	2.6235
Min	1.5432	.4001	1.4746	.3086	1.4746	.2267	1.0288
Avg	2.2109	1.8186	2.3391	2.0358	2.0964	1.7872	1.5525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 204 / KAWAJAWALA
Feeder KV- 11 / OUTGOING****SINGLE PHASING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3601	.463	.4115		.5144
2	1.2003	1.3717	.3429	.8402	1.0288	.5716	.5144
3	1.4575	1.3717	.4287	1.0288	1.2003	.5335	
4	1.5432	1.6289	.4458	1.3717	1.3717	.5335	
5	1.6804	2.0233	.4801	1.7147	1.5432		
6	1.8519	2.2119	.5144	2.0576	1.989	.6097	
7	2.4006	2.692	.823	2.2634	2.332	.6668	
8	2.7435	1.7147	.823	2.6063	2.7778	.5906	
9	2.6063	.823	.823	2.6578	2.5034	.4954	
10	.4001	.381	.2096	.3429	.3239	.3239	
11	.2858	.3239	.2667	.3429	.381		1.3375
12	.2401	.3048	.3048	.0286	.381		2.452
13	.2915	.3239	.3048	.0248	.2286		2.6749
14	.2743	.2743	.3239	.0267	.2858	1.8861	2.5034
15		.3239	.0343	.0305	.3239	2.3148	2.4863
16		.3429	.0343		.2667	2.3148	2.332
17		.381	.0457		.2096	2.2805	2.4863
18			.0419		.5716	2.2291	2.2805
19		.6097	.0648	.7621	.7621	.0781	.5316
20		.5525	.7811	.724	.724	.0781	.0819
21		.4954	.0667	.6478	.6668	.0743	.0686
22	.0476	.4763	.0572	.5716		.0648	.0724
23	.0438	.4191	.4801	.4954	.5316	.6097	.5658
24	.3772	.0419	.4001	.5144	.4287	.5716	.5906
Max	2.7435	2.692	.823	2.6578	2.7778	2.3148	2.6749
Min	.0438	.0419	.0343	.0248	.2096	.0648	.0686
Avg	1.0463	.8448	.3524	.9293	.9236	.8856	1.3433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 205 / ANANDWADI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.9259	.9431	.8573	.8573	1.0288	1.3032
2	1.3717	.9259	.9431	.9088	.6859	1.7318	1.7147
3	1.4575	.9259	1.0288	.9431	.7888	1.8861	2.0576
4	1.5432	.9259	1.0802	1.2003	.8573	2.2291	2.2291
5	1.7318	.9602	1.2003	1.286	1.0288	2.4006	2.4863
6	1.406	1.3203	1.3717	1.406	1.1317	2.572	2.8635
7	1.3375	1.3717	.9259	1.0117	.9145	2.7778	3.2922
8		.9431	1.1431	.1619	.9145	3.275	2.6406
9	1.0288	.5658	.9259	1.2346	.8954		3.1036
10	.8916			1.1145			.8383
11	3.3779	1.5432		1.7147	1.5775		.6859
12		1.6804	2.1776	2.1262	2.2805	.724	
13	2.0405	2.1434	2.452	2.332	2.2977		
14	2.0062	1.9719	1.7147	2.2634	2.3663	.583	
15		2.2462	2.1434	2.0405	2.1262	.0648	.0686
16		2.0919	2.1605		2.2291	.0705	.0572
17		2.0233	2.2291	2.1776	2.2291	.1067	.9431
18		2.0576	2.0748	2.1262	2.0062	1.4232	1.4746
19		1.0974	.1296	.9602	1.5432	.1715	.1581
20		1.0802	1.0631	.8573	1.4918	.1581	.1581
21		1.0631	.1334	1.0288	.8916	.1486	.1543
22	.1086	1.046	.1353	.9945		.1543	.1658
23	.1067	.9945	1.0117	.8745	1.0631	1.3546	1.2517
24	1.5947	.1067	.9602	.9945	.8573	1.0288	1.3203
Max	3.3779	2.2462	2.452	2.332	2.3663	3.275	3.2922
Min	.1067	.1067	.1296	.1619	.6859	.0648	.0572
Avg	1.4250	1.3048	1.2703	1.3311	1.4106	1.1945	1.3794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 206 / INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1715	.0857	.1372	.12	.1886	.12
2	.12	.1715	.0857	.1372	.12	.1715	.12
3	.1372	.2058	.0857	.1372	.1029	.1543	.12
4	.1372	.2058	.0857	.1372	.1029	.1543	.12
5	.1372	.2572	.1029	.1372	.1029	.1372	.1372
6	.12	.1886	.1372	.1372	.0857	.1372	.1543
7	.12	.1372	.12	.1372	.1372	.1372	.12
8	.0857	.1372	.12	.1886	.1372	.1029	.1543
9	.1029	.1543	.12	.2743	.1715	.1029	.2915
10	.1029	.1372	.0857	.2743	.1715	.1372	.3429
11	.1029	.2229	.0686	.2401	.2058	.12	.3429
12	.1029	.2058	.0857	.1886	.2058	.12	.3772
13	.1029	.2229	.1029	.2401	.2058		.2743
14	.1029	.2058	.0857	.1886	.1886	.12	.2743
15		.2058	.1029	.1886	.1715	.12	.2743
16		.12	.1029		.1543	.1029	.2915
17		.1372	.1029	.1886	.1715	.1029	
18		.0857	.12	.1543	.1372	.0857	.1886
19		.12	.12	.1372	.1372	.1029	.1372
20		.2058	.0857	.1372	.2229	.1029	.1372
21		.2058	.12	.12	.2229	.12	.2058
22	.1886	.1372	.1372	.1372		.12	.2058
23	.1886	.1029	.12	.12	.2229	.12	.2058
24	.12	.1715	.0857	.12	.12	.2058	.12
Max	.1886	.2572	.1372	.2743	.2229	.2058	.3772
Min	.0857	.0857	.0686	.12	.0857	.0857	.12
Avg	.1231	.1715	.1029	.1677	.1573	.1290	.2050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134004 / 33/11 KV PARTUR

Feeder No / Name : 207 / 11 KV AMBA FEEDER
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.3717	1.3717	1.286	1.3375	1.3717		
3	1.5432	1.4575	1.3717	1.3717	1.4575		
4	1.7147	1.5432	1.4746	1.4575	1.5432		
5	1.9204	1.7147	1.5947	1.5432	1.6804		
6	1.989	1.749	1.7661	1.7661	1.749		
7	2.2805	2.0233	2.0405	2.0919	1.8861		
8	2.1605	2.0576	2.1948	2.0748	1.869		
9	1.7318	1.869	2.0233	2.1605	1.749		
11						1.6804	1.406
12						1.8176	1.749
13							1.9204
14						1.989	1.7833
15						1.7833	1.8176
16						1.7147	1.6632
17						1.3717	1.6975
18						1.3375	1.3717
Max	2.2805	2.0576	2.1948	2.1605	1.8861	1.989	1.9204
Min	1.3717	1.3717	1.286	1.3375	1.3717	1.3375	1.3717
Avg	1.8390	1.7233	1.7190	1.7254	1.6632	1.6706	1.6761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134004 / 33/11 KV PARTUR****Feeder No / Name : 208 / 11KV water supply express
feed Feeder KV- 11 / OUTGOING****SHEDDABLE RURAL**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0171	.0171	.0171	.0514
2	.0514	.0514	.0514	.0171	.0171	.0171	.0514
3	.0514	.0514	.0514	.0171	.0171	.0171	.0514
4	.0514	.0514	.0514	.0171	.0171	.0171	.0514
5	.0514	.0514	.0514	.0171	.0171	.0171	.0514
6	.0514	.0514	.0686	.0343	.0171	.0171	.0514
7	.0857	.0686	.1029	.0514	.1029	.0343	.12
8	.0857	.0686	.12	.1029	.1029	.1029	.12
9	.1029	.1029	.1029	.1029	.12	.1029	.12
10	.1029	.1029	.0857	.0857	.12	.1029	.12
11	.1029	.1029	.1029	.0857	.12	.1029	.12
12	.0857	.0857	.12	.0857	.1372	.12	.12
13	.0857	.0857	.1029	.12	.1372		.12
14	.0857	.0857	.1029	.12	.1372	.1029	.0514
15		.0514	.1029	.0857	.12	.1029	.0514
16		.1029	.12		.12	.0686	.12
17		.12	.1029	.1029	.0514	.12	.12
18		.0857	.0514	.0343	.0514	.12	.12
19		.0686	.0343	.0514	.0514	.12	.1372
20		.0514	.0343	.0343	.0343	.0514	.0514
21		.0514	.0343	.0343	.0343	.0514	.0514
22	.0514	.0514	.0343	.0343		.0514	.0514
23	.0514	.0514	.0171	.0171	.0171	.0514	.0171
24	.0514	.0514	.0514	.0171	.0171	.0171	.0514
Max	.1029	.12	.12	.12	.1372	.12	.1372
Min	.0514	.0514	.0171	.0171	.0171	.0171	.0171
Avg	.0706	.0707	.0729	.0559	.0686	.0663	.0821

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 201 / ASHATI TOWN****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3772	.4458	.4706	.4801	.3772	.3944
2	.4287	.3944	.4973	.4938	.4801	.5144	.6001
3	.4801	.4801	.5658	.5068	.5144	.6001	.7545
4	.5487	.6001	.823	.543	.6173	.6859	.8745
5	.823	.7202	.8573	.7442	.7202	.8059	.9774
6	1.0631	.7716	.8745	.9036	.9945	.8402	1.0288
7	1.2689	1.2003	1.2003	1.1919	1.046	.9774	1.1317
8	1.1317	1.0288	1.166	1.1568	1.0631	1.0974	1.0974
9	.9774	1.0974	1.2346	1.1104	.9259	1.0288	1.0631
10	.823	.8916	.9945	.8059	.8916	.8573	.823
11	.6859	.7888	.8688	.7202	.8573	.7545	.905
12		.7373	.8328	.6001	.7202		.8688
13	.6687	.6344	.7602	.6001	.6859		.6556
14	.583	.6687	.6379	.5487	.6173		.6516
15	.5658	.6516	.6661	.6173	.6001		.6584
16	.6859	.7202	.7796	.6687	.6859		.6556
17	.8573	.8059	2.1125	.823	.8059	.9259	.7316
18	.9431	.9431	1.1584	.9088	.9259	1.0802	1.0498
19	.823	.823	1.0974	.9945	.7373	.8402	.8505
20	.8573	.6516	.7701	.7202	.6001	.7373	.6626
21	.6173	.5658	.443	.5316	.5144	.4973	.5144
22	.4801	.5144	.6697	.5144	.4458	.4801	.5138
23	.463	.4287	.4887	.4801	.4458	.463	.5014
24	.4458	.4115	.3772	.4784	.4801	.463	.4287
Max	1.2689	1.2003	2.1125	1.1919	1.0631	1.0974	1.1317
Min	.4287	.3772	.3772	.4706	.4458	.3772	.3944
Avg	.7239	.7044	.8467	.7139	.7023	.7382	.7664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 202 / KARALA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	1.1431	1.0517	.7011	.6173	.6344	.6687
2	1.2803	1.5242	1.5546	1.1145	1.0669	.823	.7545
3	1.4022	1.9509	1.9357	1.8442	1.4632	.8916	.8059
4	1.6766	2.2862	2.3167	2.0348	1.7071	.9774	.8573
5	2.0729	2.6216	2.4387	2.3137	2.0729	1.0631	.8573
6	2.9264	2.8197	2.5149	2.42	2.4691	1.1317	.9945
7	2.8045	2.8959	2.1948	2.7515	2.5911	1.0288	1.0288
8	2.774	2.9721	1.9357	3.0693	2.4844	.8916	.9774
9	2.6368	2.4691	1.6918	2.5549	2.2253	.9088	.9431
10	.6859	.7716	.6687	.5316	.6859	.9602	.8402
11	.6344	.5144	.5373	.4801	.583	1.6918	2.713
12	.4801	.4458	.4706	.4287	.4458		2.7664
13	.5144	.4801	.4252	.4115	.6859		2.8178
14	.463	.5144	.4477	.463	.6516		2.6189
15	.4801	.4973		.583	.4973		2.8344
16	.5487	.6344		.6344	.6344		2.8012
17	.7202	.7716	.5847	.823	.7888	1.9662	2.6825
18	.9774	.9088	1.0808	.9259	.8573	2.3929	2.3061
19	.9945	1.0288	1.0745	1.0974	.9774	1.4175	1.0166
20	.8916	.9431	.929	.9602	.8745	.9431	.9313
21	.7888	.8745	.8682	.7545	.8059	.8059	.8859
22	.6859	.7202	.724	.6859	.703	.703	.815
23	.7202	.6687	.6556	.6516	.6001	.5487	.8059
24	.8059	.6859	.6344	.6556	.6173	.5144	.6344
Max	2.9264	2.9721	2.5149	3.0693	2.5911	2.3929	2.8344
Min	.463	.4458	.4252	.4115	.4458	.5144	.6344
Avg	1.1981	1.2976	1.2152	1.2038	1.1294	1.0681	1.4732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 203 / WAHEGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.0669	1.2193	.9745	.9945	1.1831	.9088
2	1.1888	1.6766	1.5089	2.5265	1.5851	1.2517	.9945
3	1.89	2.2862	1.6461	2.5149	1.89	1.2003	1.046
4	1.89	2.3624	1.8595	2.4813	2.4387	1.1831	1.0288
5	2.1643	2.4996	2.0881	2.6189	2.0424	1.2174	1.1488
6	2.6825	2.713	2.3472	2.6852	2.7435	1.3375	1.2003
7		2.8349	1.3413	3.1295	2.5911		1.3203
8	2.0729	2.8807	1.8442	2.649		1.2346	1.2003
9	2.4539	2.6673	1.7223	3.0514		1.3203	
10	.8573	1.0288	.5144	.7087		.7716	.6516
11		.8573	.724	.823		2.2558	2.0119
12		.7716	.8507	.7202	.8402		2.34
13		.7373	.7602	.6344	.8059		2.4863
14	.8402	.703	.6805	.6516	.7716		
15	.7545	.7373	.7059	.6859	.7545		
16	.7716	.8573	.7087	.7373	.9774		2.6578
17	.9088	1.0288	.9816	1.0117	1.1317		2.4981
18		1.1145	.7783	1.0631	1.2174		2.5484
19	1.0288	1.3717	.9671	1.3032	1.3717	1.9966	
20	1.1145	1.3546	.9877	1.2689	1.3546	2.3167	1.1871
21	1.166	1.2003	.9991	1.2346	1.2003	.9602	1.2403
22	.9431	1.166	1.0387	1.1317	1.1317	1.0117	1.0867
23	.9945	1.1145	1.0679	1.0288	1.1145	1.0288	.9015
24	1.0802	1.0288	1.2174	.8954	.9945	1.166	1.0631
Max	2.6825	2.8807	2.3472	3.1295	2.7435	2.3167	2.6578
Min	.7545	.703	.5144	.6344	.7545	.7716	.6516
Avg	1.3613	1.5025	1.1900	1.5221	1.3976	1.3397	1.4760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 205 / RAIGWAN****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.6344	.6859	.5847	.5487	.5335	.5658
2	.6859	.6859	.7716	.5784	.6173	.9297	1.1431
3	.7888	.7716	.9602	.6089	.6859	1.0059	1.2651
4	.9602	.9945	1.0288	.6733	.9602	1.1431	1.3413
5	1.1488	1.1145	1.1317	.9114	1.0288	1.2193	1.3717
6		1.2346	1.2003	1.0692	1.1488	1.2498	1.4175
7				1.0923		1.2803	1.4784
8	1.046			.9709	.8916	1.2651	1.5546
9	.9774	1.166	1.1488	.815	1.1145	1.5394	1.5394
10	.8573		.6859	.7442	.7202	.6516	.6001
11	1.6766	1.2803	1.9784	1.3108	1.8138	.4458	.4706
12	1.7528	1.4327	2.4143	1.6918	2.0881		
13	2.21	1.5851	2.536	1.6918	2.1033		
14	2.2253	1.6309	2.5095	1.5851	2.1186		.3658
15	2.3624	1.4784	2.431	1.6766	2.3167		.4163
16	2.1643	1.5546	2.3205	1.7071	2.2558		.567
17	1.9052	1.5242	2.1125	1.5851	1.8747	.8573	.7442
18	1.7375	1.4175	2.1026	1.448	1.7223	.9088	.9412
19	1.0288	.9602	1.0277	1.1317	.8916	.8573	1.0387
20	.9602	.8402	.6379	.9602	.7888	.7373	.8328
21	.7888	.6859	.6335	.823	.6859	.6687	.7087
22	.6859	.6344	.6154	.7888	.6344	.6173	1.0985
23	.6516	.6001	.6036	.6516	.6173	.6001	.8859
24	.6859	.6001	.6344	.567	.5487	.6173	.6173
Max	2.3624	1.6309	2.536	1.7071	2.3167	1.5394	1.5546
Min	.6516	.6001	.6036	.567	.5487	.4458	.3658
Avg	1.2713	1.0870	1.3714	1.0695	1.2250	.9015	.9529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 206 / 11KV BHAGAWANNAGAR FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0762	.061	.0886	.0514	.0514	.0343
2	.2743	.1829	.1372	.1402	.1829	.0514	.0343
3	.2743	.2286	.2286	.1715	.2743	.0686	.0343
4	.3353	.2743	.3048	.2058	.3658	.0686	.0514
5	.3963		.3353	.2374	.4268	.0686	.0686
6	.4572	.3963	.3506	.2486	.4725	.0857	.0686
7	.4572	.5335	.4115	.4024	.503	.0686	.0857
8	.5487	.5639	.4572	.4191	.4572	.0514	.0514
9	.5182	.5335	.4877	.4144	.442	.0343	.0514
10	.0343	.0514	.0686	.0354	.0343	.0343	.0343
11	.0343	.0171	.0354	.0343	.0343	.3048	.2515
12	.0343	.0343	.0187	.0171	.0343		.2984
13	.0343	.0343	.0181	.0171	.0171		.3978
14	.0343	.0343	.0181	.0171	.0171		.5304
15	.0171	.0343	.0181	.0171	.0171		.5868
16	.0343	.0343	.0181	.0171	.0343		.5365
17	.0171	.0343	.0179	.0171	.0343	.3201	.5426
18	.0514	.0514	.0724	.0343	.0514	.3506	.5316
19	.0857	.0857	.0724	.0514	.0514	.3201	.1227
20	.1029	.0857	.0709	.0686	.0514	.0686	.1063
21	.0857	.0686	.0724	.0686	.0343	.0686	.0886
22	.0857	.0686	.0724	.0686	.0343	.0514	.0686
23	.0514	.0514	.0354	.0686	.0343	.0343	.0709
24	.0514	.0686	.0343	.0526	.0514	.0343	.0343
Max	.5487	.5639	.4877	.4191	.503	.3506	.5868
Min	.0171	.0171	.0179	.0171	.0171	.0343	.0343
Avg	.1695	.1541	.1424	.1214	.1545	.1124	.1951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134010 / 33/11 Kv ASHTI****Feeder No / Name : 207 / 11KV Surumgaon****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2401	.2743	.2629	.2572	.2401	.2401
2	.2058	.2572	.2915	.2774	.2572	.4115	.4725
3	.2401	.3086	.3258	.2947	.2743	.4572	.6401
4	.3086	.3258	.3429	.3086	.3086	.4877	.6706
5	.4115	.3772	.3772	.3772	.3429	.4877	.8688
6	.4115	.4287	.4458	.4458	.4115	.5658	.884
7	.4458			.4508	.4458	.5182	.9145
8	.3429	.2915			.2743	.5335	.9145
9	.2743	.2572	.3258		.3601	.7468	.884
10	.2401	.2743	.2915	.1991	.2401	.2058	.2058
11	1.326	1.0212		.884	1.0517	.1886	.1772
12	1.2651	1.1736	1.2742	1.0669	1.1126		
13	1.3108	1.2193	1.2887	1.0669	1.1584		
14	.6859	1.3413	1.1401	1.1584	1.2193		.1791
15	1.2193	1.0822	1.1831	1.1888	1.2193		.1949
16	1.1888	1.1279	1.2209	1.1736	1.1736		.1928
17	1.326	1.0364	.6706	.823	.8535	.2572	.2658
18	.9145	.7011	.7291	.5944	.7164	.2915	.3224
19	.3601	.3429	.3898	.3429	.3429	.3772	.3077
20	.2915		.298	.3086	.2915	.3258	.298
21	.2743	.2915	.2507	.2572	.2743	.2915	.2865
22	.2401	.2743	.2534	.2572	.2401	.3258	.3012
23	.2572	.2572	.2715	.2572	.2572	.2915	.2804
24	.2058	.2401	.2401	.2629	.2572	.2572	.2743
Max	1.326	1.3413	1.2887	1.1888	1.2193	.7468	.9145
Min	.2058	.2401	.2401	.1991	.2401	.1886	.1772
Avg	.5813	.5850	.5660	.5572	.5558	.3821	.4443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 201 / MAPEGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3688	.5868	.4359	.9389	.3521	.4527
2	.8718	.8048	.7545	1.0059	1.0227	.3856	.4862
3	1.0059	.8383	.8215	1.0395	1.0898	.4024	.4359
4	1.0562	.8718	.9221	1.0898	1.0898	.4694	.4862
5	1.2071	.9389	1.0898	1.1233	1.1736	.5197	.5365
6	1.2239	1.0227	1.1736	.9724	1.2574	.5533	.57
7	1.291	1.1568	1.3245	1.2239	1.2574	.6203	.6036
8	1.3077	1.4251	1.1736	1.2407	1.3245	.6539	.5868
9	1.2071	1.1233	1.2239	1.291	1.3413	.6874	.57
10	.285	.3688	.503	.285	.285	.6371	.5365
11	.3353	.3521	.5365	.2515	.2347		1.4083
12	.3018	.2683	.4694	.2515	.2515		1.3916
13	.2515	.2515	.3688	.2515	.2347		1.4083
14	.2515	.2347	.3185	.3353	.2012		1.358
15	.2683	.2683	.3688	.3521	.3856		1.3916
16	.3018	.3353	.4191	.3521	.4694		1.4251
17	.4024	.503	.6036	.5533	.6203	1.3077	1.3916
18	.6706	.6706	.7042	.6203	.6539	1.3748	1.073
19	.5533	.3688	.3688	.3856	.4527	.6539	.4527
20	.5365	.3856	.4024	.3688	.4359	.5533	.503
21	.4694	.3353	.4359	.3688	.4024	.4862	.5365
22	.4024	.3353	.2683	.3856	.3856	.503	.5533
23	.3856	.3521	.285	.3856	.3688	.57	.5533
24	.4862	1.166	.9431	.3018	.4191	.3521	1.3717
Max	1.3077	1.4251	1.3245	1.291	1.3413	1.3748	1.4251
Min	.2515	.2347	.2683	.2515	.2012	.3521	.4359
Avg	.6469	.6144	.6694	.6196	.6790	.6157	.8368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 202 / SATONA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4862	.4191	.5868	.6371	.4694	.5365	.503
2	.9389	.7042	.6706	.7042	.503	.5197	.5365
3	1.0898	.7209	.7545	.7042	1.0395	.57	.5533
4	1.1401	.7712	.7712	.8048	1.0562	.6036	.6036
5	1.1736	.8718	.8048	.8048	1.0898	.6371	.6203
6	1.2574	.9221	.9221	.8718	1.1568	.8718	.8048
7	1.2407	1.1065	1.0898	.8886	1.1568	.9724	
8	1.2407	1.2407	1.0395	.9221	1.1568	.6371	
9	1.0898	1.0562	1.0898	1.0227	1.0898	.6539	
10	.4862	.7377	.5365	.6036	.503	.8551	.8048
11	.3688	.5533	.5868	.4191	.5365		1.0898
12	.3856	.4359	.6036	.3688	.57		1.1065
13	.4359	.4191	.5868	.3353	.4527		1.0898
14	.4862	.4359	.4359	.503	.4024		1.0898
15	.5197	.4694	.4862	.5365	.4862		1.0562
16	.5868	.503	.5533	.57	.6706		1.0898
17	.7209	.7042	.6539	.7042	.7712	1.1401	1.073
18	.9221	.8718	.8215	.8048	.8383	1.1736	.9054
19	.9389	.6706	.6036	.5868	.6203	.7042	.6706
20	.7042	.7377	.6203	.5197	.57	.6874	.7042
21	.57	.6371	.5533	.503	.5533	.6539	.5868
22	.5197	.6371	.4191	.5365	.5197	.6203	.6371
23	.4359	.6706	.4359	.5868	.4694	.6371	.6706
24	.5365	1.1145	.9431	.3856	.6371	.5533	.6036
Max	1.2574	1.2407	1.0898	1.0227	1.1568	1.1736	1.1065
Min	.3688	.4191	.4191	.3353	.4024	.5197	.503
Avg	.7614	.7254	.6904	.6385	.7216	.7237	.8000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 203 / SHELGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4359	.503	.503	.4694	.5533	.6371
2	.503	.4359	.5365	.57	.503	2.079	2.1293
3	.5197	.4694	.5365	.57	.5365	2.3137	2.5819
4	.4862	.503	.5868	.5868	.5365	2.7999	2.7328
5	.4527	.5365	.5868	.6036	.5868	2.8334	2.9005
6	.4862	.6036	.5533	.6203	.6203	2.9508	2.9508
7	.503	.7042	.503		.6036	2.934	2.7496
8	.5365	.7545	.57	.57	.503	2.3137	2.5819
9		.8048	.6539	.5365	.5365	2.146	2.3975
10	.6539		.503	.6371	.57	.6371	.5365
11	2.7496	2.364		2.6155	2.5987		.3353
12	2.9508	3.0178		2.934	2.6658		.3521
13	3.0178	2.8166	3.0849	2.9675	2.7328		.3688
14	3.2023	3.1017	2.5819	2.6322	2.7161		.3521
15	3.1855	3.0681	3.1017	2.6825	2.7831		.3353
16	3.2023	3.1017	3.152	2.7496	2.8166		.4359
17	3.152	2.6825	2.5149	2.4143	2.2298	.57	.4694
18	2.8166	2.7328	2.2801	2.1963	2.1293	.6371	.7545
19	.7209	.5533	.6036	.5868	.5533	.5365	.6371
20	.6203	.6036	.5868	.5533	.5197	.5533	.6036
21	.5365	.5868	.5365	.5533	.503	.5197	.6371
22	.503	.5868	.4191	.5533	.4527	.4694	.6371
23	.4359	.6539	.9431	.5868	.4024	.4527	.6706
24	.4359	.9945	.9431	.3688	.6371	.5197	.4024
Max	3.2023	3.1017	3.152	2.9675	2.8166	2.9508	2.9508
Min	.4359	.4359	.4191	.3688	.4024	.4527	.3353
Avg	1.3974	1.3962	1.1946	1.2866	1.2169	1.4344	1.2162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 204 / INDUSTRIAL
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	30-NOV-17	01-DEC-17
HR	Load (MW)	Load (MW)
24	.8488	.7716
Max	.8488	.7716
Min	.8488	.7716
Avg	.8488	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 205 / DEVLA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.0671		.1341	.1174	.1006	.1341
2	.7042	.5365		.5365	.5868	.1174	.1677
3	.788	.5868		.6371	.6371	.1509	.218
4	.8215	.6371		.6371	.6371	.1844	.285
5	.8048	.6539		.6706	.6706	.2012	.3018
6	.8551	.6706		.6706	.7042	.2515	.3185
7	.8215	.7042		.6874	.7042	.2347	.3018
8	.8383	.8048		.6874	.7545	.2347	.285
9	.8215	.6706		.6706	.7042	.2683	.3018
10	.1341	.1509		.1174	.1677	.3018	.3185
11	.0671	.0838		.0671	.0838		.8048
12	.0671	.0838	.1174	.0671	.1174		.8048
13	.0671	.0838	.1341	.0671	.0671		.8215
14	.0671	.0671	.1174	.0671	.0671		.8048
15	.0838	.0838	.0671	.0671	.1174		.8551
16	.1006	.1006	.0671	.0503	.1509		.6706
17	.1341	.1677	.1677	.1677	.1677	.788	.8383
18	.1006	.218	.218	.2012	.1844	.8048	.8718
19	.1677	.1006	.1174		.218	.3856	.1174
20	.1341	.1174	.1341	.1174	.1509	.3688	.1509
21	.1006	.1509	.0838	.1006	.1006	.3688	.1677
22	.0838	.1509	.0838	.1174	.1174	.285	.2012
23	.0671	.1509	.1174	.1677	.1174	.2683	.2012
24	.1341	1.1145	1.4575	.1174	.1509	.1844	.2347
Max	.8551	1.1145	1.4575	.6874	.7545	.8048	.8718
Min	.0671	.0671	.0671	.0503	.0671	.1006	.1174
Avg	.3409	.3398	.2218	.2967	.3123	.3055	.4240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 206 / DEVLA WATER SUPPLY
Feeder KV- 11 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	30-NOV-17	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
20			.3688
24	.9602	1.4575	
Max	.9602	1.4575	.3688
Min	.9602	1.4575	.3688
Avg	.9602	1.4575	.3688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 207 / Express Kedarwakdi
Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.1341		.0838	.0838	.0671	.0838
2	.0671	.1174		.1341	.1341	.0671	.0838
3	.0503	.1174		.1509	.1174	.0838	.0838
4	.0503	.1174		.1677	.1174	.0838	.1341
5	.0671	.1677		.1844	.1174	.1006	.218
6		.2347		.1341	.1006	.0838	.2347
7	.1174	.2515		.1844	.1509	.0838	.2683
8	.1341	.1341		.1677	.1509	.1006	.285
9	.1174	.1677		.1677	.1509	.1341	.285
10	.3018	.285	.1677	.2012	.1677	.1174	.2347
11	.2683	.1341	.1844	.1677	.1509		.3185
12	.3018	.1341	.1844	.1341	.1509		.3018
13	.3018	.1844	.218	.1006	.1341		.3185
14		.1677	.1509	.1006	.1509		.285
15	.2515	.2347	.2515		.1341		.3018
16	.1341	.2347	.3018	.1174	.1677		.218
17	.1006	.0671	.0838	.1006	.1341		.2347
18	.1006	.0335	.0838	.1006	.0838		.0335
19	.1006	.0671	.1677	.1006	.0838		.0838
20	.1341	.0671	.1844	.1509	.0838		.0838
21	.1677	.1006	.1844	.1509	.0838		.0838
22	.1844	.1006	.1341				.0838
23	.2012	.0838	.1509			.0838	.0838
24	.0503	.4525	.9431	.1174	.0838	.0671	.0838
Max	.3018	.4525	.9431	.2012	.1677	.1341	.3185
Min	.0503	.0335	.0838	.0838	.0838	.0671	.0335
Avg	.1486	.1579	.2261	.1389	.1242	.0894	.1844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134017 / 33/11 Kv SATONA****Feeder No / Name : 208 / 11 KV IRREGATION EXPRESS****PURELY LIS FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.0168	.0168	.0168	.0168	.0168
2	.0168	.0168	.0168	.0168	.0168	.0168	.0168
3	.0168	.0168	.0168	.0168	.0168	.0168	.0168
4	.0168	.0168	.0168	.0168	.0168	.0168	.0168
5	.0168	.0168	.0168	.0168	.0168	.0168	.0168
6	.0168	.0168	.0168	.0168	.0168	.0168	.0168
7	.0168	.0168	.0168	.0168	.0168	.0168	.0168
8	.0168	.0168	.0168	.0168	.0168	.0168	.0168
9	.0168	.0168	.0168	.0168	.0168	.0168	.0168
10	.0168	.0168	.0168	.0168	.0168	.0168	.0168
11	.1677	.0168	.0168	.0168	.0168		.1174
12	.1677	.0168	.0838	.0168	.0168		.1006
13	.1677	.0168	.0168	.0168	.0168		.1006
14	.0168	.0168	.0168	.0168	.0168		.0168
15	.1677	.0168	.0168		.0168		.0168
16	.1677	.0168	.0168	.0168	.0168		.0168
17	.1677	.0168	.0168	.0168	.0168	.0168	.0168
18	.0168	.0168	.0168	.0168	.0168	.0168	.0168
19	.0168	.0168	.0168	.0168	.0168	.0168	.0168
20	.0168	.0168	.0168	.0168	.0168	.0168	.0168
21	.0168	.0168	.0168	.0168	.0168	.0168	.0168
22	.0168	.0168	.0168	.0168	.0168	.0168	.0168
23	.0168	.0168	.0168	.0168	.0168	.0168	.0168
24	.0168	.4287	.7716	.0168	.0168	.0168	.0168
Max	.1677	.4287	.7716	.0168	.0168	.0168	.1174
Min	.0168	.0168	.0168	.0168	.0168	.0168	.0168
Avg	.0545	.0340	.0510	.0168	.0168	.0168	.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION II[275]

PARTUR (R) S/DN[411] BU 2755

Substation No/ Name :- 134031 / 33/11 KV SHRISHTI

Feeder No / Name : 201 / SHRISHTI AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.9431	.8669	.7773	.823	.8078	
2						.8078	.4409
3						.8078	.503
4						.8078	.5636
5						.7926	.6316
6						.7468	.6718
7						.7468	.8173
8						.8383	.8716
9						.8535	.8796
18	.8478	1.2039	1.0688	1.1145	1.0212		
19	1.3226	1.1904	1.0526	1.0059	1.0517		
20	1.0513	1.0852	1.004	.9145	1.0517		
21	1.1022	1.0513	.9393	.9145	1.0364		
22	1.0343	1.0004	.8745	.8779	.9907		
23	.9774	.9496	.8259	.8962	.9602		
24	.8688	.8573	.9088	.8097	.8962	.823	
Max	1.3226	1.2039	1.0688	1.1145	1.0517	.8535	.8796
Min	.8478	.8573	.8259	.7773	.823	.7468	.4409
Avg	1.0111	1.0352	.9426	.9138	.9789	.8032	.6724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134031 / 33/11 KV SHRISHTI****Feeder No / Name : 202 / PATODA Ag
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.724	.9389	.9393	.9431	.6097	1.0686
10		1.7295			.8817		
11		2.3758	1.7078	1.7147	1.768		
12		2.332	1.9608	1.749	1.8442		
13		2.3482	2.0083	1.8004	1.8442		
14	1.6956	2.3102	1.8976	1.7147	1.829		
15	1.9281	2.359	1.9134		1.7985		
16	2.0008	2.2939	1.7394	1.8861	1.7833		
17	1.933	2.1548	1.6129	1.8861	1.7528		
18		1.0974	1.1498	1.4632	.7164	1.4413	1.6518
19	1.3565	1.046	1.1012	1.1888	.7926	1.3203	1.5223
20	.7042	1.0174	.9717	1.1403	.823	1.4083	1.4413
21	.724	1.0343	.9878	1.1041	.8383	1.2323	1.3927
22	.7108	1.0004	.9878	.9431	.8383	1.2334	1.3765
23	.6859	.9945	.9717	.9877	.823	1.2191	1.2955
24	1.0669	.6001	.9665	.9393	.8573	.6401	1.1145
Max	2.0008	2.3758	2.0083	1.8861	1.8442	1.4413	1.6518
Min	.6859	.6001	.9389	.9393	.7164	.6097	1.0686
Avg	1.2556	1.5886	1.3944	1.3898	1.2584	1.1381	1.3579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134031 / 33/11 KV SHRISHTI****Feeder No / Name : 203 / DATHANA Gao****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.2987	.3361	.3239	.2829	.4001	.3361
2	.3429	.2801	.4066	.3361	.3395	.381	.3361
3	.3429	.2801	.4805	.3361	.6036	.381	.4668
4	.3429	.6535	.4915	.4854	.7095	.381	.5975
5	.3048	.7468	.5636	.6161	.6535	.4954	.7282
6	.3429	.8215	.7127	.7095	.7316	.5144	.6722
7	.4382	.823	.8871	.7282	.8413	.6478	.7282
8	.6668	.6516	.7577	.7655	.7682	.6668	.6908
9	.5716	.6001	.7023	.6722	.695	.6287	.6348
10	.4763	.5041	.4294	.4481	.7682	.5144	.5041
11	.5041	.3734	.3921	.3361	.1334	.3734	.3547
12	.2743	.2427	.2801	.2614	.2858		.2614
13	.2801		.2801	.2801	.2477		.2427
14	.2378	.2241		.2801	.2477		.2241
15	.2241	.2241	.2427	.2427	.2667		.2241
16	.2614	.2801	.2801	.2614	.2667		.2801
17	.3361	.3361	.4294	.2572	.381	.4668	.4481
18	.4024		.6908	.3361	.5716	.6348	.6161
19	.6036	.5975	.4854	.6535	.5144	.5415	.4854
20	.2195	.4668	.3921	.6348	.5144	.3921	.4108
21	.439	.3734	.3734	.5228	.4954	.3921	.3921
22	.4024	.3547	.3361	.3361	.4572	.3734	.3921
23	.3734	.3361	.2987	.2987	.381	.3547	.3734
24	.362	.3018		.3174	.2829	.4001	.3361
Max	.6668	.823	.8871	.7655	.8413	.6668	.7282
Min	.2195	.2241	.2427	.2427	.1334	.3547	.2241
Avg	.3796	.4441	.4658	.4350	.4766	.4705	.4473

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134031 / 33/11 KV SHRISHTI****Feeder No / Name : 204 / YENORA Gao****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.1494	.1132	.1307	.1509	.12	.1132
2	.2229	.1132	.132	.1307	.112	.1372	.1132
3	.2229	.1132	.168	.1494	.2241	.1543	.2075
4	.2229	.1867	.2054	.2241	.2829	.1886	.2075
5	.2401	.2801	.2427	.2614	.2987	.2401	.2614
6	.2743	.3361	.3734	.3174	.2987	.2743	.2987
7	.3086	.3361	.3547	.3734	.2987	.2915	.3361
8	.2572	.2926	.3174	.3174	.2926	.3086	.3174
9	.2915	.2743	.2427	.3174	.2195	.2058	.2614
10	.2058	.1132		.1307	.2195	.1372	.1307
11	.1494	.1494	.1307	.112	.12	.1132	.1307
12	.112	.112	.112	.1097	.1029		.1132
13		.2241	.0934	.112	.0857		.0943
14	.2926	.0943	.0934	.112	.0857		.0943
15	.1097	.112	.112	.112	.12		.0943
16	.112		.112	.112	.12		.1307
17	.1698	.168	.1494	.1097	.12	.1886	.168
18		.2801	.2801	.1494	.2401	.2987	.1867
19	.2195	.2427	.2427	.2801	.2401	.2241	.2427
20	.2241	.1867	.1867	.2987	.2229	.168	.2054
21	.1867	.168	.168	.2801	.2229	.1509	.1867
22	.1886	.1698	.1494	.2241	.2058	.132	.1494
23	.1867	.1509	.1307	.1867	.2058		.1494
24	.2229	.1494	.132	.1307	.1509	.12	.1132
Max	.3086	.3361	.3734	.3734	.2987	.3086	.3361
Min	.1097	.0943	.0934	.1097	.0857	.1132	.0943
Avg	.2118	.1914	.1844	.1951	.1934	.1918	.1794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134031 / 33/11 KV SHRISHTI****Feeder No / Name : 205 / Ashti Water Supply
Feeder KV- 11 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0189	.0191		.0189	.0191	.0191
2		.0189	.0191		.0189	.0191	.0191
3		.0189	.0191		.0189	.0191	.0191
4		.0189	.0191		.0189	.0191	.0191
5		.0189	.0191		.0189	.0191	.0191
6	.0191	.0189	.0191		.0189	.0191	.0191
7	.0191	.0189	.0191		.0189	.0191	.0191
8	.0191	.0189			.0189	.0191	.0191
9				.0191	.0189	.0191	.0191
10		.0191		.0191	.0189	.0191	.0191
11		.0191		.0189	.0191	.0191	.0191
12		.0191		.0189	.0191		.0191
13		.0191			.0191		.0191
14		.0191			.0191		
15		.0191		.0189	.0191		
16		.0191		.0189	.0191		
17	.0189	.0191		.0189			.0191
18	.0189	.0191		.0189		.0191	.0191
19	.0189	.0191		.0189	.0191	.0191	.0191
20	.0189	.0191		.0189	.0191	.0191	
21	.0189	.0191		.0189	.0191	.0191	.0191
22	.0189	.0191		.0189	.0191	.0191	.0191
23	.0189	.0191		.0189	.0191		.0191
24		.0189	.0191		.0189	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0189	.0189	.0191	.0189	.0189	.0191	.0191
Avg	.0190	.0190	.0191	.0189	.019	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134031 / 33/11 KV SHRISHTI****Feeder No / Name : 206 / 11KV HATDI AG FEEDER
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	30-NOV-17
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION****Feeder No / Name : 201 / LONI SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0419	.4382	.4108	.0343	.4572	.3734	.0381
2	.0343	.381	.3734	.0343	.4954	1.1142	1.7772
3	.0343	.381	.4108	.0286	.5335	1.1469	1.861
4	.0381	.4191	.3921	.0362	.5716	1.2452	2.3472
5	.0514	.4382	.4668	.0419	.5335	1.3435	2.5484
6	.0553	.4572	.5601	.0476	.6097	1.6385	2.8502
7	.0457	.4954	.2614	.0495	.5716	1.9662	2.9508
8		.4382	.2241	.0495		2.2939	3.0178
9		.0305	.1867	.0495	.1905	2.2939	2.4478
10		.2614	.3361	.0381	.2241	.2241	.2667
11	2.6216	2.8837	2.649		1.3108	.0191	.2667
12	2.6558	2.9492	2.0119				.2286
13	2.7854	2.9492	2.431				.2667
14	2.8673	3.0476	2.3472		2.2939		
15	2.8673	3.1131	2.3807	.9145	2.4249		.1524
16	2.753	3.1131	2.2131	.9907	1.8023		.1905
17	2.7854	2.6216	2.0119	1.0669	1.3108	.0229	.2667
18	2.6216	2.2939	2.1125	.9907		.0343	.3429
19	.2286	.3921	.0343	.3429	.2801	.0457	.381
20	.381	.5228	.0572	.381	.3734	.0572	.4954
21	.4382	.5975	.061	.3048	.4108	.0495	.5335
22	.4763	.5601	.0457	.3429	.3734	.0495	.4763
23	.4572	.5228	.0457	.381	.3361	.0419	.4191
24	.0476	.4191	.4481	.0381	.4191	.2987	.0419
Max	2.8673	3.1131	2.649	1.0669	2.4249	2.2939	3.0178
Min	.0343	.0305	.0343	.0286	.1905	.0191	.0381
Avg	1.1565	1.2386	.9363	.3082	.7761	.7505	1.0507

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION****Feeder No / Name : 202 / CHANGATPURI SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9831	.4481	.0457	.6097	.4668	.0438
2	.8718	1.186	.9503	.9556	.945	.5975	.0438
3	.9389	1.3279	.9831	1.0395	.9145	.6535	.0438
4	1.0898	1.4232	1.065	1.1065	1.1431	.7468	.0495
5	1.1233	1.5384	1.1797	1.1736	1.326	.9335	.061
6	1.1736	1.4842	1.2452	1.2574	1.3717	1.0456	.0762
7	1.2239	1.4529	1.3435	1.2574	1.2498	.8775	.0895
8	1.2742	1.4685	1.2944	1.4419	.9145	.8402	.0895
9	1.2742	1.3603	1.1797	1.3413	.8688	.7468	.0667
10	.0286	.0457	.3734	.0495	.4481	.3921	
11	.2667	.4294	.0324	.381	.3734	.9221	1.1888
12	.2858	.3734	.0286	.2858	.2427		1.448
13	.2858	.2614	.0286	.3048			1.5546
14	.2667	.2987	.0324	.3239	.2241		1.5242
15	.2667	.2614	.0324	.3048	.3547		1.4632
16	.3048	.2987	.0362	.381	.3174		1.4022
17	.0362	.4108	.0419	.5144	.4108	1.2239	1.448
18	.6668	.8029	.0819	.8764	.6348	1.2071	1.3108
19	.8002	.7655	.0838	.7621	.8402	.0838	.8573
20	.8573	.6535	.0762	.6859	.7842	.0762	.8764
21	.6668	.5601	.061	.5525	.6535	.061	.7621
22	.6668	.5601	.0514	.5525	.5975	.0457	.724
23	.5716	.5228	.0514	.6097	.5601	.0438	.6668
24	.04	.5716	.4668	.0495	.5716	.4854	.0438
Max	1.2742	1.5384	1.3435	1.4419	1.3717	1.2239	1.5546
Min	.0286	.0457	.0286	.0457	.2241	.0438	.0438
Avg	.6258	.7934	.4653	.6772	.7111	.6026	.6884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134058 / 33KV/11KV LONI SUBSATION****Feeder No / Name : 203 / 11kv Golegaon SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17
HR	Load (MW)
20	.1524
Max	.1524
Min	.1524
Avg	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION****Feeder No / Name : 201 / TAKALI SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1543	.12	.1543	.1372	.1543	.1715
2	.1372	.1543	.12	.1372	.1372	.381	.381
3	.1372	.1543	.12	.1372	.1715	.381	.381
4	.1715	.2572	.1543	.1715	.2401	.4572	.4572
5	.2058	.2743	.2229	.1715	.2743	.5335	.6097
6	.2743	.3601	.2915	.2058		.5792	.7621
7	.3429	.463	.3601	.2058	.3601	.6097	.9145
8	.2058	.2743	.3086	.2743	.3086	.7773	.9145
9	.2572	.2229	.12	.2401	.2915	.6554	.8993
10	.2058	.1543	.0343	.1372	.1029	.1372	.1543
11	.8993	.7011	.6401	.823	.7621	.0857	.12
12	.9145	.884	.9297	.823	.8688		.0857
13	.9755	.9145	.9145	.884	.8535		.1029
14	.9297	.8993	.8383	.823	.823		.1029
15	.823	.7164	.823	.7926	.8383		.1029
16	.7011	.7621		.7621	.8383		.1029
17	.8078	.7926	.8383	.7316	.7926	.1715	
18	.6554	.7011	.7926	.5639	.6859	.2229	.2401
19	.2058	.2058	.2915	.1886	.3258	.2743	.3086
20	.2401	.1715	.1715	.2058	.2572	.2572	.2572
21	.1886	.1543	.1543	.1886	.1715	.1715	.2229
22	.1715	.12	.1372	.2058	.1543	.1543	.2058
23	.1543	.1029	.1372	.1715	.1372	.1372	.1715
24	.1543	.1543	.1029	.12	.1715	.12	.12
Max	.9755	.9145	.9297	.884	.8688	.7773	.9145
Min	.1372	.1029	.0343	.12	.1029	.0857	.0857
Avg	.4130	.4062	.3749	.3799	.4219	.3295	.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION****Feeder No / Name : 202 / KHANDVI SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.5144	.5316	.5144	.5144	.5316	.5144
2	.5144	.5144	.5144	.5144	.5487	.8383	.8383
3	.5487	.6173	.5487	.5144	.6173	.9907	.9907
4	.6859	.8573	.7716	.8573	.6859	1.1431	1.2193
5	.7716	1.0974	1.0288	1.0288		1.2955	1.2955
6	1.2003	1.2003	1.166	1.2003		1.3717	1.5242
7	1.4003	1.3375	1.3203	1.3546	1.3032	1.4784	1.829
8	1.2003	1.166	1.2346	1.1488	1.1317	1.7223	1.89
9	.9259	.9088	.9259	.9259	.7888	1.5242	1.7071
10	.5144	.5487	.7202	.5144	.5144	.5144	.6001
11	1.6766	1.6156	1.326	1.5775	1.5242	.4287	.3944
12	2.0119	1.9966	1.9509	1.4937	1.6004		.3429
13	2.1338	1.8442	1.9814	1.6309	1.5699		.3258
14	1.9814	1.9357	1.7833	1.6156	1.5394		.2743
15	1.8595	1.7528	1.8442	1.6461	1.5394		
16	1.6156	1.768	1.7985	1.6156	1.5546		
17		1.7985	1.7071	1.6461	1.6004	.583	
18	1.6004	1.6156	1.4937	1.2193	1.0364	.8059	.9088
19	.8059	.7716	.7716	.7888	.7545	.8402	.8916
20	.7202	.7373	.6859	.703	.6859	.6859	.7888
21	.6173	.6687	.6859	.6001	.6516	.6516	.703
22	.583	.583	.6859	.583	.583	.6001	.6516
23	.5658	.5144	.6001	.5487	.5487	.583	.6173
24	.5144	.5316	.5144	.5144	.5144	.5487	.5316
Max	2.1338	1.9966	1.9814	1.6461	1.6004	1.7223	1.89
Min	.463	.5144	.5144	.5144	.5144	.4287	.2743
Avg	1.0831	1.1207	1.1080	1.0315	.9912	.9020	.8971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION II[275]****PARTUR (R) S/DN[411] BU 2755****Substation No/ Name :- 134061 / 33/11 KHANDAVI SUBSTATION****Feeder No / Name : 203 / USMANPUR SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.1715	.1543	.1715	.1715	.1715
2	1.0669	1.0669	1.1431	1.2193	.884	.1715	.1715
3	1.1431	1.3108	1.2955	1.2955	1.0364	.1715	.1715
4	1.3717	1.4327	1.448	1.5242	1.1431	.1715	.1715
5	1.5242	1.4937	1.5089	1.829	1.4784	.2572	.2572
6	1.6766	1.829	1.7985	1.9052		.3429	.3429
7	1.7375	1.7071	1.9052	1.9357	1.768	.4973	.4287
8	2.0119	2.1948	2.1948	1.89	1.89	.4458	.463
9	1.9966	1.3108	1.9204	1.9357	1.829	.4115	.3086
10	.2915	.3086	.2572	.2743	.2915	.2572	.2401
11	.1886		.1886	.1543	.1543	1.4937	1.9509
12	.1715	.1715	.1543	.1372	.1372		2.1338
13	.12	.1372	.12	.1372	.12		2.3777
14	.12	.1029	.12	.1543	.12		2.2862
15	.12	.12	.1067	.1715	.12		2.1643
16	.1543	.1715	.1886	.1886	.12		2.0881
17	.2229	.2915	.1886	.2058	.1886	2.0424	1.9814
18	.3429	.3258	.3772	.3086	.3258	2.1033	1.7071
19	.3429	.3086	.3601	.3429		.3429	.3601
20	.2743	.2915	.1715	.2743	.2743	.2572	.2915
21	.2058	.2401	.2058	.1886	.1886	.1886	.2401
22	.1886	.1886	.2401	.1715	.1543	.1886	.2058
23	.1715	.1715	.1886	.1715	.12	.1543	.1886
24	.1886	.1543	.1715	.1715	.1543	.12	.12
Max	2.0119	2.1948	2.1948	1.9357	1.89	2.1033	2.3777
Min	.12	.1029	.1067	.1372	.12	.12	.12
Avg	.6585	.6732	.6844	.6975	.5759	.5152	.8676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 201 / TOWN****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4287		.3429	.4287	.4287
2		.4287	.4287		.3429	.4287	.4287
3		.5144	.4287		.3429	.4287	.4287
4		.823	.1715		.4287	.5144	.5144
5		.8573	.6001		.6001	.6859	.5144
6		.8573	.8573		.7716	.8573	.8573
7		1.1145	1.1145		.9431	1.1145	1.0288
8		1.2003	1.2003		1.1145	1.0288	1.1145
9	.4287	.9431	1.286		.9431	1.0288	
10	.9431	.8573		.9431	.9431	.7716	.9431
11	.8573	.8573		.6859	.8573	.8573	.8573
12	.6001	.7716		.7716	.8573	.7716	.7716
13	.6859	.6859		.6859	.8573	.7716	.6859
14	.7716	.6859		.6859	.7716	.8573	.6859
15	.8573	.6859		.6859	.7716	.9431	.6859
16	.8573	.7716		.6859	.7716	.9431	.6859
17	.8573	.8573		.8573	1.0288	1.0288	.9431
18	.9431	.9431		.8573	1.0288	1.0288	1.0288
19	.7716	.8573		.8573	1.0288	1.0288	.8573
20	.7716	.7716		.9431	.7716	.9431	.7716
21	.6859	.6859		.7716	.6001		
22	.6001	.6001		.5144	.5144		
23	.5144	.4287		.3429	.5144		.5144
24	.4287	.4287	.4287		.4287	.4287	
Max	.9431	1.2003	1.286	.9431	1.1145	1.1145	1.1145
Min	.4287	.4287	.1715	.3429	.3429	.4287	.4287
Avg	.7234	.7523	.6945	.7349	.7323	.8043	.7373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 202 / RAMKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5432	1.5432		1.0288	.8573	1.0288
2		1.7147	1.5432		1.2003	.8573	1.0288
3		2.0576	1.5432		1.4575	1.0288	1.286
4		2.2291	1.8004			1.2003	1.5432
5		2.2291	2.1434				
6		2.4006	2.2291				
7		2.4863	.6001				
8		2.5377	.6859				
9						.6859	
10				1.9052	2.2291	1.7147	1.6289
11				2.2862	2.4006	2.0576	1.9719
12				2.4387	2.572	2.1434	2.0576
13				2.4387	2.572	2.0576	1.8861
14				2.3624	2.572	1.8861	1.7147
15				2.21	2.4863	2.0576	
16				2.21	2.2291	2.0576	1.5432
17	.4287			1.9814	2.1434	1.8861	1.5432
18	1.4575	1.2193				1.286	1.3717
19	1.3717	1.1431		1.5432	1.0288	1.286	1.2193
20	1.2003	.9145		1.4575	1.286	1.2003	1.0669
21	.8573	.7621		1.2003	.1715	1.0288	
22	.8573	.6859		.9431	.9431	.9431	
23	.8573	.6859		.9431	.8573	.6859	
24	1.2003	.7716	.6859		.9431	.6001	
Max	1.4575	2.5377	2.2291	2.4387	2.572	2.1434	2.0576
Min	.4287	.6859	.6001	.9431	.1715	.6001	1.0288
Avg	1.0288	1.5587	1.4194	1.8400	1.6542	1.3760	1.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 203 / AMBADGAON-AG****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.3717	1.3717	1.1145
2				1.448	1.5432	1.286
3				1.5242	1.7147	1.4575
4				1.6004	1.7147	1.5432
5				1.6766	2.2291	1.5432
6				1.829	2.2291	1.8861
7				2.0576	2.2291	2.4863
8				1.448	2.572	1.7147
9		1.0288				
10	2.4863	1.7147			.2572	
11		1.4575				
12	2.3148	1.4575				
13	2.0576	1.286				
14		1.2003				
15		1.0288				
16		1.0288				
17		1.1145				
24			2.8292			
Max	2.4863	1.7147	2.8292	2.0576	2.572	2.4863
Min	2.0576	1.0288	2.8292	1.3717	.2572	1.1145
Avg	2.2862	1.2574	2.8292	1.6194	1.7623	1.6289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 204 / KUSALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.8004		.8573	.6859	.8573
2		1.5432	1.8004		.9431	.6859	.8573
3		1.7147	2.8292		1.1145	.8573	1.1145
4		1.7147	1.8861		1.2003	1.0288	1.0288
5		1.8861	1.8861		1.286		
6		2.2291	2.1434		1.4575		
7		2.7435	2.572				
8		2.6578	2.572				
9						.5144	
10				1.6766		1.3717	1.7147
11				2.1338	2.0576	1.9719	1.7147
12				2.2862	2.2291	2.1434	1.9719
13				2.3624	2.2291	2.0576	1.9719
14				2.2862	2.1434	1.7147	1.7147
15				2.1338	2.1434	1.8004	1.6289
16				2.1338	.6859	1.7147	1.5432
17				2.3624	1.8004	1.5432	1.4575
18	1.2193	1.0669		1.0288	1.0288	1.2003	1.0669
19	1.2003	1.1431		1.286	1.2003	1.1145	.9907
20	1.1145	.9145		1.3717	1.2003	1.1145	.9145
21	.9431	.8383		1.1145	1.0288		.8383
22	.8573	.6859		.8573	.8573		.6859
23	.8573	.6097		.7716	.8573		.6097
24	1.6289	2.6749	2.6578		.7716	.7716	
Max	1.6289	2.7435	2.8292	2.3624	2.2291	2.1434	1.9719
Min	.8573	.6097	1.8004	.7716	.6859	.5144	.6097
Avg	1.1172	1.5863	2.2386	1.7004	1.3546	1.3112	1.2601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 205 / ROSHANGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3048		.6859	.8573	
2		.3429	.3048		.7716	.8573	.5144
3		.3429	.3048		.8573	1.0288	.6859
4		.3429	.381		.9431	1.0288	.8573
5		.5144	.5335		1.0288	1.0288	.7716
6		.7716			1.1431	1.2003	1.2003
7		.7716			1.2193	1.3717	1.4575
8					1.2955	1.5432	1.5432
9					.6001	.3429	
10					.3429	.3429	
11					.3429	.2572	
12		1.2003			.2572		
13		1.4575			.1715		
14	1.5432	1.4575			.1715		
15	1.5432	1.4575			.1715		
16	1.6289	1.4575			.2572		
17	1.5432	1.5432			.2572		
18	.6001			.4287	.6001	.6001	.6097
19	.6001	.6097		.6001	.5144	.6001	.5335
20	.6001	.4572		.5144	.4287	.5144	.4572
21	.4287	.381		.4287	.3429	.5144	.381
22		.3048		.3429	.3429	.3429	.3048
23	.3429	.3048		.3429	.3429	.3429	.2286
24	.3429	.3429	.3048		.2572	.3429	
Max	1.6289	1.5432	.5335	.6001	1.2955	1.5432	1.5432
Min	.3429	.3048	.3048	.3429	.1715	.2572	.2286
Avg	.9173	.7581	.3556	.4430	.5561	.7287	.7342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 206 / AMBADGAON (G)****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715		.3429		
2		.3429	.1715		.3429		
3		.3429	.1715		.3429		
4		.3429	.2572		.3429		
5		.3429	.3429		.4287		
6		.4287	.4287		.5144		
7		.3772	.4287				
8		.3429	.4287				
9			.3429		.3429	.3429	
10				.1715	.2572	.2572	
11				.0857	.1715	.1715	
12				.0857	.0857		
13				.0857	.0857		
14	.0857			.0857	.0857		
15	.1715	.0857		.0857	.0857		
16	.1715	.0857		.0857	.0857		.1715
17	.2572	.0857		.1715	.2572		.2572
18	.4287	.3429		.2572	.4287	.3429	.3429
19	.3429	.3429		.3429	.4287	.3429	.3429
20	.2572	.2572		.4287	.2572	.3429	.3429
21	.2572	.1715		.3429	.1715	.2572	.2572
22	.2572	.1715		.1715	.1715	.1715	.1715
23	.1715	.1715			.1715	.1715	.1715
24	.1715	.1715	.1715		.1715	.2572	
Max	.4287	.4287	.4287	.4287	.5144	.3429	.3429
Min	.0857	.0857	.1715	.0857	.0857	.1715	.1715
Avg	.2338	.2543	.2915	.1846	.2533	.2658	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013405 / 33KV BADNAPUR****Feeder No / Name : 207 / WARUDI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.5335		.6001	.8573	.7716
2		.8573	.5335		.6859	1.0288	.6859
3		.8573	.5335		.8573	1.2003	.6859
4		.8573	.6097		.7621	1.2003	.6859
5		1.0288	.9145		.8383	1.3717	.7716
6		1.1145			.9145	1.4575	1.1145
7					1.2193	1.4575	1.0288
8					1.448	1.4575	1.5432
9		.8573			.7716	.5144	
10	1.5432	1.6289			.4287	.5144	
11	1.7147	1.7147			.3429	.4287	
12		1.8004			.3048		
13	1.8861	1.7147			.3429		
14	2.0576	1.8004			.3429		
15	2.0576	1.8004			.3429		
16	1.9719	1.7147					
17	1.5432	1.6289					
18	1.1145	.9907		.7716		1.0288	.9907
19	1.0288	.9145		1.0288	.8573	1.0288	.8383
20	1.0288	.7621		1.1145	.7716	.8573	.7621
21	.7716	.6859		.8573	.6859	.8573	.6859
22	.6859	.6097		.6001	.5144	.6859	.6097
23	.6859	.6097		.5144	.5144	.6001	.5335
24	.6859	.6859	.5335		.5144	.5144	
Max	2.0576	1.8004	.9145	1.1145	1.448	1.4575	1.5432
Min	.6859	.6097	.5335	.5144	.3048	.4287	.5335
Avg	1.3411	1.1509	.6097	.8145	.6695	.9478	.8363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013405 / 33KV BADNAPUR

Feeder No / Name : 209 / BAGADIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.1372		.1715	.0857	.0857
2		.0857	.1372		.0857	.0857	.0857
3		.0857	.1372		.0857	.0857	.0857
4		.0857	.1372		.0857	.0857	.1715
5		.0857	.1372		.0857	.0086	.0857
6		.0857	.1372		.0857	.0857	.0857
7		.1715	.1715		.0857	.1715	.1715
8		.1715	.1715		.1715	.1715	.1715
9	.1715	.2572	.1715		.1715	.1715	
10	.1715	.2572		.1715	.1715	.1715	.1715
11	.2572	.1715		.1715	.1715	.1715	.2572
12	.2572	.1715		.2572	.1715	.1715	.3429
13	.2572	.1715		.2572		.1715	.2572
14	.3429	.2572		.1715		.1715	.2572
15	.3429	.1715		.1715		.2572	.2572
16	.2572	.1715		.1715		.2572	.4287
17	.1715	.2572		.3429	.2572	.3429	.2572
18	.1715	.2572		.1715	.1715	.1715	.1715
19	.1715	.1715		.1715	.1715	.1715	.1715
20	.1715	.1715		.1715	.1715	.1715	.1715
21	.1715	.1524		.1715	.0857	.1715	.1715
22	.1715	.1715		.1715	.0857	.1715	.2572
23	.1715	.1372		.1715	.0857	.0857	.1715
24	.1715	.1715	.1372		.1715	.0857	
Max	.3429	.2572	.1715	.3429	.2572	.3429	.4287
Min	.1715	.0857	.1372	.1715	.0857	.0086	.0857
Avg	.2144	.1657	.1475	.1960	.1372	.1540	.1949

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013430 / 33KV DABHADI****Feeder No / Name : 201 / DABHADI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.7842	.8402	.7842	.8402	.7716	.9145
2	.8962	.9335	.823	.7842	.8402	.7716	1.0242
3	.9335	1.0269	.7682	.8589	.9335	.7545	1.1641
4	.9709	1.1203	.8954	.8764	1.0974	.9717	1.2536
5	1.1203	1.1576	1.086	1.1458	1.0974	.9831	1.3375
6	1.1641	1.2803	1.3717	1.4415	1.1641	1.3108	1.4998
7	1.2269	1.3535	1.5684	1.4548	1.267	1.5203	1.4255
8	1.3032	1.2254	1.2254	1.3611	1.5581	1.7814	1.5565
9	.5258	.9431	1.1765	.823	1.2883	.4854	.8802
10	1.3927	1.1203	1.7404	1.4575	.9878	.6219	.5552
11	1.8351	1.6324	1.6057		1.5043	.6219	.5552
12	1.9662	1.7204	1.5238	1.5432	1.4403	.4854	.5373
13	2.13	2.0119	1.2125	1.6118	1.4575	.4668	.4119
14	2.1628	1.8023	1.5074	1.5432	1.4899	.4668	.5014
15	1.8842	1.6385		1.4251	1.5223	.5228	.5373
16	1.7238	1.4575	1.3435	1.3413	1.278	.5975	.8417
17	1.6244	2.0119	1.3927	1.5729	1.3969	.7316	.9313
18	1.0867	1.1203	1.1888	.7316	.7468	.7682	1.2178
19	1.3146	1.3443	1.1576	1.4632	1.2883	.8413	1.1462
20	1.1919	1.1203	1.1203	1.1203	1.2136	.9694	1.0029
21	.9114	.9511	1.1203	1.0974	1.1203	.9335	.7701
22	.9145	.9335	1.0719	.9431	1.0269	.8962	.6805
23	.8402	.9145	1.0269	.8488	.8962	.7842	.6447
24	.9709	3.0007	3.5723	.9335	.8488	.7842	.6535
Max	2.1628	3.0007	3.5723	1.6118	1.5581	1.7814	1.5565
Min	.5258	.7842	.7682	.7316	.7468	.4668	.4119
Avg	1.2911	1.3585	1.3191	1.1810	1.1793	.8268	.9185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013430 / 33KV DABHADI****Feeder No / Name : 202 / CHIKHALI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2269	1.1888	.6859	.7842	.763	.3658	.3361
2	1.4022	1.2803	.8059	.8779	.763	.3658	.3361
3	1.4373	1.3146	1.0288	.9313	.7716	.4024	.4024
4	1.5432	1.4373	1.0059	1.0166	1.0059	.4525	.4755
5	1.5775	1.4575	1.5565	1.0517	.9717	.462	.5853
6	1.6385	1.5432	1.4403	1.2094	1.2003	.5228	.6661
7	1.8023	1.6461	1.5524	1.6118	1.2803	.7468	.7011
8	1.6712	.8764	1.5684	1.5249	1.4083	.6468	.695
9	.4694	.4024	.4801	.5601	.4481	.7164	.032
10	.3658	.3734	.3361	.3361	.2614	1.0341	.8223
11	.2614	.1886		.3361	.168	1.3256	1.1843
12	.2241	.1698		.1867	.168	1.5432	1.3441
13	.2241	.1867		.168	.168	1.3927	1.2191
14	.1867	.1867		.1829	.1867	1.3435	1.0279
15	.1867	.3734		.1463	.2427	.8383	
16	.1867	.2801		.1867	.3395	1.1736	
17	.2801	.2743		.1494	.3734	1.2742	
18	.4108	.3734	.3361	.3734	.4668	.4668	.6401
19	.6401	.5228	.5487	.5228	.5975	.5601	.5407
20	.4938	.4108	.5041	.5601	.5228	.4733	.439
21	.4572	.2801	.4668	.4481	.3734	.4572	.3475
22	.4024	.2801	.4108	.415	.3658		.2926
23	.3361	.2241	2.8292	.3772	.3658	.3361	.2772
24	.2987	2.8292	2.6578	.3361	.3395		.2987
Max	1.8023	2.8292	2.8292	1.6118	1.4083	1.5432	1.3441
Min	.1867	.1698	.3361	.1463	.168	.3361	.032
Avg	.7385	.7542	1.0714	.5955	.5646	.7682	.6030

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 201 / NANEGAON-AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1029	.0924	.12	.4115	.5144
2	.1029	.1029	.1029	.0924	.12	.4801	.6173
3	.12	.1372	.1029	.0739	.12	.4973	.6687
4	.1372	.1543	.1029	.1109	.12	.5487	.7545
5	.1372	.1543	.1029		.12	.583	.823
6	.1543	.1715	.12	.1478	.12	.6173	.8573
7	.1543	.1543	.12	.1663	.1372	.703	.9431
8	.1372	.1372	.12	.1848	.12	.6859	
9	.12	.2572	.1372	.1848			
10	.5144	.6687	.7343	.6859			
11	.6859	.823	.8059	.7373			
12	.823	.8573	.8954	.8916	.6516		
13	.8573	.8745	.9536	.8573	.8573		
14	.9259	.8402	.961	.8402	.8745		
15	.9945	.8573	.8145	.7716	.8573		.0686
16	.9431	.8745	1.0208	.7545	.823	.1029	.0343
17	.7545	.7888	1.0387	.7373	.7545	.1543	.0686
18						.1715	.1029
19						.1886	.1715
20							.1886
21						.2058	.2229
22						.1886	.2058
23						.1886	.1886
24	.1029	2.6578	2.6578	.1109	.0686	.1543	.1715
Max	.9945	2.6578	2.6578	.8916	.8745	.703	.9431
Min	.1029	.1029	.1029	.0739	.0686	.1029	.0343
Avg	.4315	.5897	.6052	.4376	.3909	.3676	.3883

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013438 / 33KV NANEGAON****Feeder No / Name : 202 / NANEGAON (G)****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0514	.0739	.0514	.0686	.0686
2	.0857	.1029	.0514	.0739	.0686	.0514	.1029
3	.1029	.1372	.0514	.0554	.0857	.0514	.1372
4	.1372	.1543	.0686	.0739	.1029	.0686	.1372
5		.1715	.1029	.0924	.1372	.0857	.1886
6	.1715	.2058	.1372	.1478	.1543	.1029	.2229
7	.1715	.2229	.2058	.2218	.1886	.1886	.2058
8	.1543	.1886	.12		.1886	.1372	.1886
9	.1372	.1372	.1543	.1478		.1372	.12
10	.1029	.1029	.1294	.0857		.12	
11	.0857	.0514	.1075	.0514		.1029	.0686
12	.0686	.0343	.0924	.0514	.0514	.0686	.0514
13	.0343	.0343	.0924	.0514	.0514	.0514	.0343
14	.0171	.0343	.0739	.0514	.0514	.0171	.0171
15	.0171	.0343	.0739	.0686	.0514	.0343	.0686
16	.0514	.0514	.0554	.0857	.0686	.0514	.0343
17	.0686	.0686	.0924	.1029	.0857	.0686	.0686
18	.1029	.0857	.1294	.12	.12	.1029	.12
19	.1543	.1543	.1478	.12	.1543	.1372	.1715
20		.1372	.1663	.12	.12	.1715	.2058
21	.1715	.12	.1109	.1029	.0857	.2058	.1543
22	.1372	.0857	.1109	.0857	.0857	.1886	.1372
23	.12	.0686	.0924	.0686	.0686	.1886	.1372
24	.0857	.12	1.0288	.0924	.0514	.0686	.1543
Max	.1715	.2229	1.0288	.2218	.1886	.2058	.2229
Min	.0171	.0343	.0514	.0514	.0514	.0171	.0171
Avg	.1029	.1079	.1436	.0933	.0963	.1029	.1215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013438 / 33KV NANEGAON

Feeder No / Name : 203 / SAIGAON

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6859	.6859	.3292	.3258		
2	.823	.823	.7202	.4525	.4973		
3	.8745	.9431	.823	.6805	.6001		
4	.9602	1.0288	.9088	.7522	.7202		
5	1.046	1.0974	1.0117	.8059	.8059		
6	1.1831	1.2003	1.0974	.985	.8402		
7	1.3203	1.2174	1.2689	1.0387	1.0117		
8	1.2003	1.166	1.2689	1.0924	.8745		
10						.6859	
11						.8573	
12						1.0288	
13						1.1145	
14						1.2003	
15						1.166	
16							1.1317
17							.8573
24			2.8292				
Max	1.3203	1.2174	2.8292	1.0924	1.0117	1.2003	1.1317
Min	.7716	.6859	.6859	.3292	.3258	.6859	.8573
Avg	1.0224	1.0202	1.1793	.7671	.7095	1.0088	.9945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013441 / 33 KV SHELGAON****Feeder No / Name : 201 / SHELGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.362	.4668	.6554	.8573	1.1203	.9717
2	.5316	.3506	.6535	.7287	.9326	1.1641	1.0526
3	.5316	.4973	.7468	.8097	.9221	1.1765	1.065
4	.7087	.9745	1.0269	.9717	1.0059	1.267	1.1469
5	1.2269	1.1393	1.307	1.1336	1.1736	1.4937	1.3765
6	1.4022			1.3765	1.5746	1.448	1.3765
7				1.4403	2.0957	2.2624	1.7394
8				1.4746	2.2119	2.2624	2.0309
9				1.0974	1.267	.9374	1.2136
10	1.6956	1.5089	1.6404	.8764	.9335	1.0269	.8402
11	1.7404	1.406	1.7966	.6135	.7468	.5601	.5258
12	1.8842	1.2498	1.9528	.5258	.5601	.3734	.4525
13	1.6766	1.7185	1.9528	.5258	.4668	.3658	.4382
14	1.8842	1.8747	1.7966	.5258	.4668		.3506
15	1.8023	1.8185	1.7185	.5258	.4668	.3658	.3506
16		1.7394	1.6404	.5258	.4668	.3658	.3506
17	1.6766	1.9204	1.5623	.724	.5601	.6401	.7011
18		.7621	.9145	1.0517	1.1203	1.086	1.0517
19	1.2269	1.1203	1.0974	1.0517	1.2136	1.1203	
20	.964	1.0269	.9145	.8764	.8402	1.2136	.7973
21	.7011	.9335	.823	.7011	.6535	.9335	.7011
22	.6135	.7468	.7316	.543	.5601	.7316	.543
23	.5258	.5601	.6401	.4382	.5601	.4572	.362
24	.5258	.443	2.8292	.4915	.4382	.4668	.4668
Max	1.8842	1.9204	2.8292	1.4746	2.2119	2.2624	2.0309
Min	.5258	.3506	.4668	.4382	.4382	.3658	.3506
Avg	1.1497	1.1076	1.3106	.8202	.9206	.9930	.8654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013441 / 33 KV SHELGAON****Feeder No / Name : 202 / RAJEWADI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6135	.9326	.9717	.5487	.362	.5601	.5601
2	.5935	1.0059	1.1469	.5487	.3506	.5601	.5487
3	.6706	1.1736	1.3927	.6535	.4382	.4668	.7468
4	.7545	1.4918	1.6194	.7468	.7011	.6535	.8402
5	.8383	2.13	1.8023	1.1203	.8764	.7468	.9145
6	1.1603	2.3472	1.9433	1.307	1.2269	.9335	1.1088
7	1.4918	2.753	2.1872	1.4003		1.4937	1.1888
8	1.5746	2.8121	2.3434	1.2803	1.2269	1.4003	1.2803
9	.5258	.7011	.4572	1.2803	.8764	.9335	.9012
10	.4382	.5258		1.8442	1.7909	1.5813	1.2289
11		.5487	.5487	2.1548	2.1491	2.2138	1.3565
12	.3658	.5487	.5487	2.2939	2.8006	2.2138	1.4251
13	.3544	.5487	.5487	2.3482	2.7073	2.2138	1.3413
14	.3544	.443	.5487	2.3482	2.5968	1.8976	1.3413
15	.3544	.4572	.4572	2.3482	2.5072	2.0557	1.2574
16		.5487	.6335	2.13	2.5072	2.0557	1.3413
17	.6201	.8402	.823	1.989	2.3282	1.9433	1.3413
18	.8764	1.1203	.9145		.7468	.924	.8859
19	1.0517	1.1203	1.1203	.964	.8402	.9145	.964
20	.8764	.9335	.9335	.7011	.8402	.9145	.8859
21	.4382	.7468	.8402	.6135	.7468	.823	.7164
22	.4382	.5601	.7468	.5258	.7468	.7316	.543
23	.4382	.4668	.6535	.443	.6535	.5544	.362
24	.3506	.362	2.6578	.5487	.3506	.6535	.5601
Max	1.5746	2.8121	2.6578	2.3482	2.8006	2.2138	1.4251
Min	.3506	.362	.4572	.443	.3506	.4668	.362
Avg	.6900	1.0466	1.1234	1.3104	1.3205	1.2266	.9850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BADNAPUR (R) S/DN[410] BU 2739

Substation No/ Name :- 013441 / 33 KV SHELGAON

Feeder No / Name : 203 / BAJARANG CRUSHER FEEDER
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0164	.0164	.0189	.0187	.0164
2	.0189	.0189	.0164	.0162	.0189	.0189	.0162
3	.0189	.0189	.0164	.0162	.0189	.0189	.0164
4	.0189	.0189	.0164	.0164	.0189	.0189	.0164
5	.0189	.0189	.0164	.0162	.0189	.0189	.0164
6	.0189	.0189	.0164	.0162	.0189	.0189	.0164
7	.0189	.0189	.0164	.0162	.0189	.0187	.0164
8	.0189	.0189	.8029	.0164	.0187	.0566	
9	.0187	.0747	.0164	.0164	.0185	.0566	.0164
10	.0189	.037	.0164	.0171	.0377	.0312	.0492
11	.0189	.0366	.0492	.0739	.0747	.0819	.0747
12	.0187	.1147	.0655	.0554	.0747	.0791	.0747
13	.037	.0164	.0655	.056	.0187	.0328	.037
14	.0185	.0164	.0648	.0554	.112	.0324	.056
15	.037	.0164	.1147	.0747	.1494	.0324	.0934
16		.0655	.081	.0739	.1494	.0648	.0373
17	.056	.0164	.0324		.168	.0492	.056
18	.0187	.0164	.0164	.0187	.0373	.0492	.056
19	.0187	.0164	.0164	.0187	.0187	.0164	.0189
20	.0189	.0187	.0164	.0187	.0189	.0164	.0187
21	.0187	.0187	.0164	.0189	.0187	.0164	.0189
22	.0189	.0187	.0164	.0189	.0189	.0164	.0189
23	.0187	.0183	.0164	.0187	.0189	.0164	.0189
24	.0187	.0187	.0183	.0164	.0187	.0189	.0175
Max	.056	.1147	.8029	.0747	.168	.0819	.0934
Min	.0185	.0164	.0164	.0162	.0185	.0164	.0162
Avg	.022	.0280	.0642	.0297	.0460	.0333	.0338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013445 / 33 KV KANDARI****Feeder No / Name : 201 / KANDARI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9145	.9054	.2229	.2641	.2572	.2263
2	1.226	.9145	1.0978	.2401	.3018	.2572	.2263
3	1.2936	.9907	1.2289	.2572	.415	.2572	.3772
4	1.7556	.9907	1.6766	.3258	.5281	.3429	.4715
5	2.0328	1.829	1.7772	.4458	.6602	.5144	.5093
6	2.4025		1.8107	.5792	.7545	.6859	.7356
7	2.809	2.4387	2.4813	.6554	.9431	.8573	.7167
8	2.5873	2.5911	2.4981	.5487	.7167	.6001	.679
9		.5144	.6036	.3429	.5281	.4287	.5093
10		.3395	.3395	1.6309	1.829	1.7901	
11	.1715	.1509	.1097	2.6057	1.9814	1.9559	
12	.1715	.1132	.1478	2.6981	2.1338	2.2466	
13	.1715	.132	.128	2.5688	1.2193	1.9784	
14	.0857		.1307	2.6797	1.6766		
15	.1715	.1886	.1372	2.7721	1.5242		
16	.1715	.1509	.2218	2.7536	1.6766		
17	.1715	.2075	.2587	2.4949	1.7528		
18	.5144	.547	.6224	.6036	.5144	.4715	.5847
19	.5144	.6413	.5093	.5281	.4287		.4725
20	.4287	.5093	.3921	.4715	.3429	.5658	.5281
21	.2572	.2829	.3395	.415	.2572	.3584	.3395
22	.2572	.2829	.2801	.3018		.3018	.3018
23		.2829	.2572	.3018		.3395	.2641
24	.2075	.2452	2.8292	.2401	.2829	.2572	.2829
Max	2.809	2.5911	2.8292	2.7721	2.1338	2.2466	.7356
Min	.0857	.1132	.1097	.2229	.2572	.2572	.2263
Avg	.8726	.6935	.8660	1.1118	.9423	.7614	.4516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013445 / 33 KV KANDARI****Feeder No / Name : 202 / KHADAKWADI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.2572	.415	.9755	.924	.9145	.9835
2	.415	.2572	.4108	1.0669	1.2936	1.0669	1.1869
3	.4338	.3429	.4668	1.1888	1.6632		1.291
4	.5658	.3429	.7545	1.2803	2.0328	1.3717	1.3748
5	.6602	.5144	.8299	1.4632	2.2177	1.6766	1.4754
6	.9431	.5144	1.0185	2.0576	2.4949	1.9814	1.8442
7	1.1317	.5144	.9808	2.2862	2.6797	1.9814	2.5149
8	.8059	.6001	.9431	2.4387	2.9835	2.4387	2.6825
9	.6859	.4287	.8488	.4801	.9242	.5144	.5281
10	2.0576	.8718	2.5194	.4527	.5144	.3772	.3961
11	2.7435	.8383	3.0664	.3395	.2572	.3734	.2829
12	2.7435	2.8502	3.1855	.2572	.2572	.2987	.2263
13	3.0483	2.8502	3.219	.2641	.2572	.2263	.1886
14	2.7435	2.934	3.152	.2641	.2572	.2263	.1886
15	2.2862	3.0514	2.774	.2263	.2572	.2263	.1698
16	2.5911	3.219	3.0664	.2641	.2572	.2829	.1886
17	2.5911	2.6825	2.8502	.3772	.3429	.3206	.2641
18	.5144	.7545	.8299	.6602		.7167	.6036
19	.5144	.7922	.7545	.6224	.5144	.7545	.4115
20	.5144	.5658	.5658	.6036	.3429	.6036	.5658
21	.3429	.4527	.4715	.5658	.3429	.3772	.3961
22	.3429	.3961	.3961	.415		.3429	.3395
23		.3961	.3258	.3395		.3772	.2829
24		.3429	2.6578	.2915	.2641	.3429	.3772
Max	3.0483	3.219	3.219	2.4387	2.9835	2.4387	2.6825
Min	.3429	.2572	.3258	.2263	.2572	.2263	.1698
Avg	1.3206	1.1154	1.5209	.7992	1.0037	.7736	.7818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013445 / 33 KV KANDARI****Feeder No / Name : 203 / WALHA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.0669	1.3077	.2987	.3395	.3429	.3018
2	1.848	1.0669	1.4746	.3258	.4715	.3429	.3018
3	2.0328	1.2193	1.5074	.3772	.6036	.3429	.3772
4	2.2177	1.5242	1.8442	.4287	.7545	.4287	.5658
5	2.4025	1.5242	1.9281	.5335	.8488	.5144	.6602
6	2.4006	1.6766	2.2131	.6401	.9431	.6001	.9808
7	2.572	1.8861	2.5149	.7621	1.0374	.6859	1.0185
8	2.0328	1.829	2.5987	.6859	.9431	.7716	.9054
9	.7167	.5144	.7545	.4877	.9054	.5144	.7545
10	.3429		.4854	2.1879	1.9814	2.3205	1.9281
11		.3395	.2614	2.7721	2.0576	2.4863	2.2634
12		.2075	.2452	3.2065	2.1338	2.3205	2.3472
13		.2075	.2241	2.9569	2.1338	2.0119	2.3472
14	.2572	.2075	.2075	2.7721	1.9814	2.1795	2.1795
15	.2572	.2263	.2058	2.7721	1.5242	2.4478	2.0957
16	.2572	.1886	.3361	2.8645	1.6766	2.2801	2.0119
17	.3429	.415	.3921	2.5873	1.9814	2.0454	2.0119
18	.6001	.7167		.7545	.5144	.7167	.7545
19	.5144	.7922	.811	.6602	.4287	.7545	.6001
20	.5144	.5658	.5658	.6224	.4287	.6036	.6979
21	.3429	.4527	.4715	.5658	.4287	.3772	.4527
22	.3429	.3961	.3772	.3772		.3772	.3772
23		.3961	.3584	.3018		.3772	.3206
24	.2829	2.8292	2.6578	.3395	.3018	.3429	.3772
Max	2.572	2.8292	2.6578	3.2065	2.1338	2.4863	2.3472
Min	.2572	.1886	.2058	.2987	.3018	.3429	.3018
Avg	1.0740	.8804	1.0323	1.2617	1.1100	1.0910	1.1096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BADNAPUR (R) S/DN[410] BU 2739****Substation No/ Name :- 013445 / 33 KV KANDARI****Feeder No / Name : 204 / UJJAINPURI FEEDER
Feeder KV- 11 / OUTGOING****SINGLE PHASING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3429	.4338	.6081	.6468	.6097	.6613
2	.415	.3429	.4481	.664	.7392	.6859	.763
3	.4527	.3429	.4481	.7537	.8316	.6097	.8478
4	.4527	.3429	.6602	.7956	.961	.9145	.9389
5	.4904	.4287	.6602	1.0059	1.1088	1.0669	1.073
6	.547		.8488	1.2597	1.2936	1.0669	1.1904
7	.5847	.6001	.8488	1.3927	1.5708	1.448	1.6766
8	.6413	.5144	.7356	1.2955	1.4918	1.5242	1.6263
9	.6516	.3429	.547	.4973	.5281	.5144	.5847
10	1.0669	1.0059	1.1843	.2829	.3429	.2641	.2641
11	1.5242	1.643	1.5565	.1886	.2572		.1886
12	1.448	1.7772	1.6907	.1294	.2572		.132
13	1.6766	1.8442	1.5684	.1698	.1715	.1886	.1509
14	1.6766	1.8107	1.5746	.1509	.1715	.2263	.1509
15	1.5242	1.8442	1.3717	.1886	.1715		
16	1.5242	1.8107	1.4251	.2075	.1715	.1886	.1698
17	.7621	1.6766	1.3927	.3206	.2572	.3018	.2829
18	.5144	.4527	.6602	.6036	.6001	.5658	.5281
19	.5144	.7167	.5281	.6602	.3429	.6224	.7167
20	.5144	.5093	.4715	.5847	.3429	.415	
21	.4287	.5093	.4338	.5281	.3429	.4338	.4527
22	.3429	.3772	.3772	.3772	.3429	.3772	.3772
23		.3772	.3429	.3395	.3429	.415	.3584
24	.3961	3.0007	2.8292	.3429	.3429		.415
Max	1.6766	3.0007	2.8292	1.3927	1.5708	1.5242	1.6766
Min	.3429	.3429	.3429	.1294	.1715	.1886	.132
Avg	.8063	.9832	.9599	.5561	.5679	.6219	.6159

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 201 / TADEGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4006	1.8861	1.8861	1.3717	1.5432	1.3717	1.4575
2	2.2291	1.8861	2.0576	1.3717	1.5432	1.6289	1.4575
3	2.2291	1.8861	2.4006	1.4575	1.5432	1.5432	1.7147
4	2.4863	2.0576	2.4006	1.6289	1.7147	1.7147	
5	2.7435	2.4006	2.4863		1.7147	1.7147	
6	2.915	2.572	2.7435				
7	3.4294	2.572	3.0864				
8	3.2579	2.572	3.2579				
9	3.0007	1.5432	2.572				
10		1.4575		1.9719	3.0007	1.8861	2.6578
11		.2572		2.0576	3.3436	2.0576	2.7435
12		.1715		1.9719	3.3436	1.8861	2.7435
13		.1715		1.8861	3.2579	1.8004	2.8292
14		.2572		1.8861	3.0864	1.8004	2.6578
15		.1715		1.8004	3.0007	1.8004	2.572
16		.2572		1.7147	2.915	1.7147	2.4863
17		.3429		1.6289	2.915	1.8861	2.4006
18	1.8861	1.6289	1.5432	1.7147	1.7147	1.9719	1.8861
19	1.8861	1.8861	1.8861	1.7147	1.8004	1.8004	1.8861
20	1.8861	1.8861	1.8861	1.7147	1.8004	1.8004	1.8004
21	1.7147	1.8004	1.8004	1.5432	1.8004	1.8004	1.7147
22	1.7147	1.286	1.6289	1.5432	1.5432	1.5432	1.5432
23	.6859	1.0288	1.4575	1.5432	1.4575	1.4575	1.4575
24	1.0288	.6859	3.4294	1.4575	1.5432	1.3717	1.4575
Max	3.4294	2.572	3.4294	2.0576	3.3436	2.0576	2.8292
Min	.6859	.1715	1.4575	1.3717	1.4575	1.3717	1.4575
Avg	2.2184	1.3610	2.2827	1.6831	2.2291	1.7275	2.0814

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 202 / BHOKARDAN TOWN****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.7716	.7716	.8573	.6859	.8573
2	.7716	.8573	.9431	.7716	.8573	.7716	.8573
3	.7716	.8573	1.2003	.7716	.8573	.8573	.8573
4	.9431	1.0288	1.5432	.7716	1.0288	1.0288	.8573
5	1.2003	1.2003	1.6289	.9431	1.3717	1.2003	1.0288
6	1.6289	1.5432	1.7147	1.1145	1.7147	1.7147	1.286
7	2.1434	1.8861	1.8861	1.9719	1.8861	1.8004	1.9719
8	2.0576	2.0576	1.8861		2.0576	1.8861	2.0576
9	1.8861	1.8861	2.0576	1.6289	2.0576	1.7147	1.8861
10	1.8861	1.7147	1.8861	1.5432	1.8861	1.6289	1.7147
11	1.7147	1.5432	1.7147	1.5432	1.8004	1.5432	1.5432
12	1.5432	1.4575	1.5432	1.4575	1.5432	1.4575	1.3717
13	1.3717	1.3717	1.4575	1.3717	1.3717	1.1145	1.286
14	1.3717	1.286	1.286	1.3717	1.3717	1.1145	1.286
15	1.4575	1.3717	1.286	1.3717	1.3717	1.1145	1.286
16	1.5432	1.4575	1.286	1.4575	1.4575	1.3717	1.3717
17	1.5432	1.8004	1.3717	1.7147	1.5432	1.5432	1.5432
18	1.5432	1.8861	1.7147	1.7147	1.5432	1.7147	1.8004
19	1.7147	1.7147	1.6289	1.5432	1.5432	1.6289	1.5432
20	1.3717	.9431	1.4575	1.5432	1.3717	1.3717	1.3717
21		.8573	1.2003		1.2003	1.2003	1.2003
22	1.0288	.7716	.9431	1.0288	.9431	1.0288	1.0288
23	.8573	.8573	.7716	.8573	.8573	.8573	.8573
24	.8573	.8573	.7716	.7716	.8573	.7716	.8573
Max	2.1434	2.0576	2.0576	1.9719	2.0576	1.8861	2.0576
Min	.7716	.7716	.7716	.7716	.8573	.6859	.8573
Avg	1.3941	1.3360	1.4146	1.2743	1.3896	1.2967	1.3217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 203 / Sipora BZ****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.8573	1.3717	.7716	.8573	1.4575	.6859
2	.7716	.8573	1.0288	.7716	.8573	1.5432	.6859
3	.6859	.8573	1.2003	.7716	1.0288	1.5432	.6859
4	.6859	1.0288	1.3717	.7716	1.7147	1.6289	.6859
5		1.3717	1.4575	.9431	2.4006	1.7147	.8573
6		1.3717	1.5432	1.1145	2.572	2.1434	1.0288
7			1.0288	1.286	2.7435	2.4863	1.286
8		1.3717	1.4575	1.6289	3.0864	2.572	1.1145
9			1.3717	.6859	3.2579		.6859
10	1.6289		3.0864				.5144
11	2.2291	1.0288	3.2579				.5144
12	2.1434	1.5432	3.4294				.5144
13	2.3148		3.4294				.5144
14	2.2291	1.8004	2.915				.5144
15	2.1434	1.8004	3.0007				.5144
16	2.0576	1.7147	2.8292				.6001
17	1.7147	1.8861	2.572				1.0288
18	1.7147	1.6289	1.3717	1.5432	1.286	1.1145	1.4575
19	1.5432	1.5432	1.3717	1.5432	1.2003	1.4575	1.5432
20	1.5432	1.4575	1.3717	1.3717	1.286	1.4575	1.4575
21	1.3717	1.5432	1.286	1.2003	1.286	1.3717	1.4575
22	1.3717	1.3717	.8573	1.0288	1.2003	1.286	1.286
23	1.3717	1.3717	.7716	.3429	1.1145	1.2003	1.2003
24	1.2003	1.3717	1.3717	.7716	.3429	1.286	1.2003
Max	2.3148	1.8861	3.4294	1.6289	3.2579	2.572	1.5432
Min	.6859	.8573	.7716	.3429	.3429	1.1145	.5144
Avg	1.5748	1.3889	1.8647	1.0342	1.6397	1.6175	.9181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 204 / Malkapur****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6859	.7716	.6001	.5144	.6001	.6001
2		.6859	.7716	.6001	.5144	.6859	.6001
3	.6859	.6859	.8573	.6001	.5144	.7716	.6001
4	.6859	.8573	1.0288	.7716	.8573	.8573	.6001
5		.8573	1.2003	.9431	1.0288	1.0288	.9431
6		.8573	1.286	1.1145	1.2003	1.0288	1.286
7				1.3717	1.2003	1.2003	1.8004
8				1.6289		1.1145	1.8004
9			.8573	.3429		.6001	.3429
10	.6001		.6859	.3429		.6001	.3429
11	.5144	1.3717	.2572	.2572	.2572	.2572	
12	.5144	1.9719	.2572	.2572	.2572	.2572	
13	.5144	1.9719	.2572	.2572	.2572		
14	.5144	1.286	.2572	.2572	.2572		
15	.5144	1.3717	.2572		.2572		
16	.5144	1.3717		.2572	.3429		.3429
17	.6859	1.3717	.3429	.8573	.6859		.8573
18	.8573	1.0288	1.1145	.8573	.9431	1.1145	1.286
19	.8573	1.1145	1.2003	.8573	1.0288	1.1145	1.1145
20	.8573	.9431	.9431	.8573	.9431	.9431	.7716
21	.8573	.9431	.9431	.8573	.8573	.9431	.8573
22	.8573	.8573	.7716	.6859	.7716	.8573	.6859
23	.6859	.7716	.7716	.6859	.6859	.7716	.6859
24	.7716	.6859	.7716	.7716	.3429	.6859	.6859
Max	.8573	1.9719	1.286	1.6289	1.2003	1.2003	1.8004
Min	.5144	.6859	.2572	.2572	.2572	.2572	.3429
Avg	.6859	1.0845	.7430	.6970	.6532	.8122	.8528

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 205 / Fattepur****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.0288	.7716	.6859	.5144	.7716	.6859
2	.8573	1.0288	.8573	.6859	.5144	.8573	.6859
3	1.1145	1.3717	1.0288	.6859	.5144	1.0288	.6859
4	1.2003	1.5432	1.2003	.8573	.6859	1.2003	.6859
5	1.3717	1.8861	1.3717	1.0288	1.0288	1.3717	.8573
6	1.5432	1.8861	1.3717	1.2003	1.5432	1.7147	1.0288
7	1.9719	2.0576	1.7147	1.5432	1.7147	1.6289	1.6289
8	2.0576	2.4006	1.8004	1.3717	1.5432	1.5432	1.4575
9	1.6289	.5144	1.5432	1.0288	1.2003	.7716	1.2003
10	.3429	.6001	.5144	1.8861	.1715	.2572	.3429
11	.2572	.2572	.2572	2.1434	.1715	.2572	
12	.2572	.2572	.2572	2.0576	.1715	.2572	
13	.3429	.2572	.2572	2.0576	.1715	.2572	
14	.3429	.3429	.2572	.1715	.1715	.2572	.1715
15	.3429	.4287	.2572	.1715	.1715	.2572	.1715
16	.3429	.5144	.3429	.2572	.1715	.2572	.1715
17	.6859	.6859	.5144	.6859	.2572	.2572	.3429
18	.6859	1.0288	1.2003	1.2003	.9431	1.286	1.286
19	.6859	1.2003	1.3717	1.2003	1.3717	1.3717	1.2003
20	.6859	1.0288	1.0288	1.2003	1.2003	1.0288	.8573
21	.6859	.8573	.9431	1.0288	1.0288	.8573	.7716
22	.6859	.7716	.7716	.8573	.8573	.7716	.6859
23	.6859	.6859	.7716	.8573	.7716	.7716	.6001
24	.6859	.6859	.6859	.7716	.5144	.7716	.6859
Max	2.0576	2.4006	1.8004	2.1434	1.7147	1.7147	1.6289
Min	.2572	.2572	.2572	.1715	.1715	.2572	.1715
Avg	.8395	.9716	.8788	1.0681	.7252	.8252	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 206 / W/W EXPRESS FEEDER****Feeder KV- 11 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0171	.0171	.0171	.0171	.0171
2	.0171		.0171	.0171	.0171	.0171	.0171
3	.0171		.0171	.0171	.0171	.0171	.0171
4	.0171		.0171	.0171	.0171	.0171	.0171
5	.0171		.0171	.0171	.0171	.0171	.0171
6	.0171		.0171	.0171	.0343	.0171	.0171
7			.0171	.0171	.0343	.0343	.0171
8			.0171	.0171	.0343	.0514	.0171
9			.0171	.0171	.0514	.0514	.0171
10			.0171	.0514	.0514	.0514	.0343
11	.0514	.0171	.0171	.0514	.0514	.0343	.0514
12	.0514	.0343	.0171	.0514	.0514	.0343	.0514
13	.0514	.0343	.0171	.0514	.0514	.0514	.0514
14	.0514	.0171	.0171	.0514	.0514	.0514	.0514
15	.0514	.0514	.0171	.0514	.0514	.0514	.0514
16	.0514	.0514	.0171	.0514	.0514	.0343	.0514
17	.0343	.0171	.0171	.0343	.0514	.0343	.0514
18	.0514	.0343	.0171	.0343	.0343	.0171	.0171
19	.0343	.0514	.0171	.0343	.0343	.0514	.0171
20	.0343	.0343	.0171	.0343	.0343	.0343	.0171
21	.0171	.0343	.0171	.0343	.0343	.0171	.0171
22	.0171	.0343	.0171	.0171	.0171	.0171	.0171
23	.0171	.0343	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171		.0171
Max	.0514	.0514	.0171	.0514	.0514	.0514	.0514
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0317	.0331	.0171	.0307	.0350	.0320	.0278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134002 / BHOKARADAN 33 KV****Feeder No / Name : 207 / Perjapur****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3429	.2572	.2572	.3429	.4287	.2572
2	.2572	.3429	.2572	.2572	.3429	.4287	.2572
3	.2572	.3429	.2572	.2572	.3429	.3429	.2572
4	.2572	.3429	.2572	.2572	.3429	.3429	.2572
5	.2572	.3429	.2572	.3429	.4287	.5144	.3429
6	.2572	.4287	.2572	.4287	.4287	.6001	.4287
7	.2572			.5144	.4287	.6001	.4287
8				.6001	.3429	.6001	.4287
9		.2572	.2572		.3429	.2572	.3429
10	.3429	.3429	.4287			.2572	.1715
11	.5144	.4287	.3429				.1715
12	.5144	.5144	.3429		.1715		.1715
13	.4287	.6001	.3429		.1715		.1715
14	.5144	.4287	.3429	.1715	.1715	.1715	.1715
15	.3429	.3429	.3429	.1715	.1715	.1715	.1715
16	.3429	.3429	.3429	.1715	.1715	.2572	.1715
17	.5144	.3429	.4287	.2572	.2572	.2572	.2572
18	.4287	.2572	.3429	.4287	.2572	.2572	.3429
19	.4287	.2572	.4287	.4287	.2572	.3429	.2572
20	.4287	.2572	.3429	.4287	.2572	.3429	.2572
21	.4287	.2572	.3429	.3429	.2572	.3429	.2572
22	.4287	.2572	.3429	.3429	.2572	.2572	.2572
23	.3429	.2572	.2572	.3429	.2572	.2572	.2572
24	.2572	.3429	2.7435	.2572	.3429	.2572	.2572
Max	.5144	.6001	2.7435	.6001	.4287	.6001	.4287
Min	.2572	.2572	.2572	.1715	.1715	.1715	.1715
Avg	.3663	.3468	.4326	.3294	.2884	.3470	.2644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 201 / KHAMKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5242	1.5775	1.5432	1.3717	.6668	.6668
2	1.2003	1.5242	1.7318	1.4575	1.2003	.8002	.8573
3	1.3717		1.749	1.6804	1.3717	.7621	.5716
4	1.3717	1.5242	1.8861	1.7147	1.3717	1.0479	1.0479
5	1.7147	1.7147	1.7147	1.5947	1.7147	1.2003	1.1431
6	2.0576	1.9052	1.8004	1.6289	2.1434	.5525	1.2384
7	2.572	2.6673	2.4006	2.6406	2.1434	.5525	1.4098
8	2.572	2.9531	2.6235	2.4863	2.2291	.4954	1.3527
9	.7621	.381	.7621	.4763	.6668	.5335	
10	.381	.381	.5335	.381			
11	.381	.381	.4763	.381			
12	.381	.4763	.3429	.4763			
13	.381	.4763	.362	.4763			.5716
14	.381	.5716	.381	.5716			.8573
15	.381	.5716	.4191	.5716	.5335		1.1431
16	.5716	.4763	.4954	.5716	.5906	.9774	1.3336
17	.5716	.5716	.6097	.7621	.724	.8573	
18	.7621	1.0479	1.0669	.9526	1.3336	1.0288	.7621
19	.7621	1.2574	1.1622	1.1431	1.0479	1.2003	.9526
20	.7621	.9526	1.0479	.8573	1.1431	1.1431	.9526
21	.5716	.724	.8954	.6668	1.0479	1.2384	
22	.5716	.7621	.5716	.5716	.8573	.9145	.5716
23	.5716	.6478	.6097	.6668	.5716	.9526	.5716
24	.6668	.5716	.6478	.5906	.6668	.6097	.8002
Max	2.572	2.9531	2.6235	2.6406	2.2291	1.2384	1.4098
Min	.381	.381	.3429	.381	.5335	.4954	.5716
Avg	.9621	1.0462	1.0778	1.0360	1.1963	.8630	.9336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 202 / Chandai Th****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5335	.7621	.5716	1.0288	.6516
2	.5716	.5716	.5716	.8002	.5716	.8916	.8573
3	.6668	.5716	.724	.9145	.6668	.8745	.7202
4	.8573	.9526	.7621	.9526	.5716	1.1317	.6516
5	1.0479	1.1431	1.0479	1.2765	.6668	.6859	.5144
6	1.1431		1.2193	1.2384	.9526	.5487	.7716
7			1.2384	.7621	1.2384	.4287	.6344
8	.6668		1.2193	.6668	1.0479	.3086	.6516
9	.6668		.9526	.5716	.9526	.8192	.8764
10	1.5242	1.6289	1.2003	1.8861	1.3717	.4001	.381
11	1.9052	1.6632	1.6289	1.5432	1.286		.381
12	1.9052	1.3717	1.5432	1.6289	1.5089		.2858
13	1.9052	1.1145	1.6118	1.7147	1.2346		.2858
14	1.6194	1.4575	1.2003	1.6289	1.3717	.2858	.2858
15	1.6194	1.5432	1.4746	1.5432	1.2174	.3429	.381
16	1.6194	1.4575	1.4918		1.0974	.381	.381
17	1.5242	1.3717	1.3717		1.0631		
18	.7621	1.0479	1.0479	.9526		.9907	.5716
19	.7621	1.1812	1.1431	1.2384	.7621	.9526	1.0479
20	.7621	.9526	.8573	.7621	.8573	.7811	.9526
21	.5716	.5716	.743	.4763	.6668	.7621	.9526
22	.5716	.5716	.7621	.4763	.5335	.743	.7621
23	.5716	.5716	.8002	.5716	.4191	.7621	.7621
24	.5716	.5716	.5144	.5716	.5716	.4763	.6478
Max	1.9052	1.6632	1.6289	1.8861	1.5089	1.1317	1.0479
Min	.5716	.5716	.5144	.4763	.4191	.2858	.2858
Avg	1.0603	1.0443	1.0691	1.0427	.9218	.6798	.6264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 203 / Rajur Town****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.381	.2572	.3429	.381	.3772	.4115
2	.4287	.381	.2915	.4287	.3429	.4287	.3429
3	.4287	.381	.3429	.463	.3429	.4801	.3772
4	.4287	.381	.3772	.5144	.3429	.5144	.4287
5	.6001	.5716	.6001	.5487	.3429	.4973	.5487
6	.6001	.7621	.3258	.5144	.4287	.5487	.5144
7	.6859	.7621	.5316		.5144	.583	.6001
8	.5144	.7621	.5487	.5487	.4287	.6001	.6001
9	.5144	.5716	.5487	.3258	.6001	.4801	.5335
10	.5716	.4801	.4287	.3429	.5144	.3944	.381
11	.381	.4287	.3772	.3429		.3258	.2858
12	.381	.2572	.3258	.4287	.4801	.2229	.2858
13	.381	.3429	.3429	.3429	.3772	.2401	.2858
14	.381	.3429	.3429	.3429	.3944	.2229	.2858
15	.381	.3429	.2743	.3429	.3086	.2401	.2858
16	.4763	.4287		.3429	.3086	.3086	
17	.4763	.5144		.4287	.3944	.3258	
18	.5716	.5144		.5716	.5487	.4287	.5716
19	.6668	.5144	.6001	.5144	.5144	.4801	.6668
20	.5716	.4287	.4801	.4287	.4287	.3944	.5716
21	.5716	.4287	.3601	.3429	.3429	.3772	.5716
22	.381	.3086	.3429	.3429	.2572	.2572	.5716
23	.381	.2229	.4287	.3429	.3772	.3086	.381
24	.2572	.381	.2229	.2401	.2572	.3429	.2058
Max	.6859	.7621	.6001	.5716	.6001	.6001	.6668
Min	.2572	.2229	.2229	.2401	.2572	.2229	.2058
Avg	.4775	.4538	.3976	.4080	.4012	.3908	.4412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 204 / LONGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.5242	1.6289	1.8861	1.3717	1.0479	.8573
2	1.2003	1.5242	1.7147	1.9719	1.3717	.9145	.743
3	1.3717	1.5242	1.8004	1.8519	1.2003	.9907	.7621
4	1.8861	1.9052	2.1434	2.1434	1.4575	1.2384	1.0479
5	2.0576	2.2862	1.9719	2.2634	1.7147	1.2574	
6	2.1434	2.4768	2.0233	2.0576	1.8861	1.2384	1.3336
7	2.2291	2.7625	2.4006	2.7435	2.0576	1.3336	1.2765
8	2.1434	2.9531	2.4691	2.332	1.8861	1.086	
9		.9526	.8002		1.0479	1.8861	
10		.5716	.5144		.8573	1.4575	2.2862
11		.4191	.381		.4763	1.4575	2.2862
12		.4191	.4191	.4763	.4763	1.3889	2.4768
13	.381	.381	.362	.5716	.4763	1.3203	2.2862
14	.381	.381	.381	.4763		1.4403	2.2862
15	.381	.5716	.4001			1.5775	2.2862
16	.5716	.5716				1.5775	2.2862
17	.6668	.7621		.7621			
18	1.0479	1.1431		.9526	1.2574	.9335	.7621
19	.9526	1.2384	1.1431	1.1431	1.2003	.9907	1.0479
20	.9526	.7621	.8954	.8573	.9145	.8192	.7621
21	.9526	.6668	.724	.8573	.8573	.724	.7621
22	.9526	.5716	.7621	.7621	.7621	.6668	.7621
23	.9526	.6478	.6668	.5716	.9145	.7621	.7621
24	.5716	.9526	.4763	.5144	.5716	.9526	.6287
Max	2.2291	2.9531	2.4691	2.7435	2.0576	1.8861	2.4768
Min	.381	.381	.362	.4763	.4763	.6668	.6287
Avg	1.1584	1.1654	1.1466	1.3260	1.1379	1.1766	1.3851

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 205 / TAPOWAN****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.362	.7621	.4763	.7716	1.5432
2	.6668	.5716	.5716	.8002	.5716	.8916	1.406
3	.6668	.5716	.6668	.9145	.5716	.5487	1.6289
4	.5716	.5716	.7621	.9145	.6668	.823	1.7147
5	.8573	.5716	1.0479	.9717	.6668	.6687	1.8347
6	.8573	.7621	.8002	.9526	.8573	.8745	1.7147
7	.9526	.9526	.8573	.7811	.9526	1.0631	1.9204
8	.7621	.9526	.9526	.7621	.7621	1.0288	1.7147
9	.6668	.7621	.743	.5906	.5716	.5906	.6859
10	.381	.4763	.4763	.4763	.4763	.3048	.381
11	.381	.381	.381	.5716	.3429	.3239	.381
12	.381	.381	.381	.4763	.3048	.4191	.381
13	.381	.381	.3429	.381	.381	.3429	.381
14	.2858	.2858	.381	.3429	.3429	.3429	
15	.2858	.3429	.3048		.3239	.4001	
16	.381	.381	.4191		.381		
17	2.2862	2.3148	2.0576	1.7147	1.6461	.381	
18	2.2862	2.0233	1.7318	1.3717	1.7661	.5335	.5716
19	2.2862	1.6289	1.5089	1.286	1.3717	.743	.6668
20	1.9052	1.286	1.3203	1.0288	1.0288	.6478	.5716
21	1.5242	1.406	1.0974	.8573	.9774	.5716	.381
22	1.3336	1.5432	1.2003	1.0288	.8573	.5144	.381
23	1.3336	.823	.9431	.8573	.6859	.4763	.381
24	1.0288	1.3336	.8745	.8059	.7716	.8402	.4763
Max	2.2862	2.3148	2.0576	1.7147	1.7661	1.0631	1.9204
Min	.2858	.2858	.3048	.3429	.3048	.3048	.381
Avg	.9597	.8865	.8410	.8476	.7398	.6131	.9558

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 206 / CHANDAI EKKO****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.6097	.9907	.5716	.7621	.5716
2	.6668		.9145	.7621	.4763	.724	.724
3	.6668	.7621	.7621	.9145	.5716	1.0479	.5716
4	.7621	.7621	.9907	.9526	.6668	.9145	.8573
5	.8573	.9526	.9526	.8002	.8573	.9526	1.1622
6	.8573	.9526	1.1431	1.0669	.9526	.8002	.9526
7	1.0479	1.0479	1.0479	1.0669	.9526	.724	.7811
8	.8573	.9526	.5716	.8573	.8573	.6478	.9907
9	1.3717	1.5242	1.286	1.0802	1.3336	.6287	.8573
10	1.4289	1.4575	1.4918	1.2003	1.406	.6287	.5716
11	1.4289	1.4575	1.4918	1.3717	1.406	.4001	.5716
12	1.5242	1.5432	1.4918	1.286	1.4232	.4763	.5716
13	1.5242	1.4575	1.4403	1.4575	1.3717	.4954	.5716
14	1.4289	1.3717	1.1145	1.3717	1.0288	.4382	
15	1.4289	1.406	1.166	1.2003	.9774		
16	1.4289	1.286	.9431	1.0288	1.1145		
17	.4763	.5716	.3429		.4763		
18	.8573	.8573	.8383	.8573	.7621	.6344	.381
19	.7621	.9526	.9145	.8573	.6097	.6516	.4763
20	.7621	.7621	.724	.6668	.6668	.5658	.5716
21	.7621	.6668	.6097	.5716	.6097	.4287	.381
22	.7621	.5716	.5716	.5716	.5335	.4115	.381
23	.7621	.5716	.743	.4763	.5716	.5144	.381
24	.5716	.7621	.5144	.5144	.4763	.6668	.3944
Max	1.5242	1.5432	1.4918	1.4575	1.4232	1.0479	1.1622
Min	.4763	.5716	.3429	.4763	.4763	.4001	.381
Avg	.9899	1.0179	.9448	.9532	.8614	.6435	.6361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134006 / 33 KV RAJUR****Feeder No / Name : 207 / AT&T TOWER
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.0953	.0829	.0829	.0829	.0829	.0829
2	.0829	.0953	.0762	.0829	.0829	.0829	.0829
3	.0829	.0953	.0829	.0829	.0857	.0829	.0829
4	.0829	.0953	.0829	.0829	.0829	.0829	.0829
5	.0829	.0953	.0829	.0829	.0857	.0829	.0829
6	.0829	.0953	.0829	.0829	.0829	.0829	.0829
7	.0829	.0953	.0829	.0829	.0829	.0829	.0829
8	.0829	.0953	.0829	.0829	.0829	.0829	.0829
9	.0829	.0953	.0829	.0829	.0829	.0829	.0953
10	.0953	.0829	.0829	.0829	.0829	.0829	.0953
11	.0953	.0829	.0829	.0829	.0829	.0829	.0953
12	.0953	.0829	.0829	.0829	.0829	.0829	.0953
13	.0953		.0829	.0829	.0829	.0829	.0953
14	.0953	.0829	.0829	.0829	.0829	.0829	.0953
15	.0953	.0829	.0829	.0829	.0829	.0829	.0953
16	.0953	.0829	.0829	.0829	.0829		.0953
17	.0953	.0829	.0829	.0829	.0829	.0829	
18	.0953	.0829	.0829	.0829	.0829	.0829	.0953
19	.0953	.0829	.0829	.0829	.0829	.0829	.0953
20	.0953	.0829	.0829	.0829	.0829	.0829	.0953
21	.0953	.0829	.0829	.0829	.0829	.0829	.0953
22	.0953	.0829	.0829	.0829	.0829	.0829	.0953
23	.0953	.0829	.0829	.0829	.0829	.0829	.0953
24	.0829	.0953	.1715	.0829	.0829	.0829	.0829
Max	.0953	.0953	.1715	.0829	.0857	.0829	.0953
Min	.0829	.0829	.0762	.0829	.0829	.0829	.0829
Avg	.0901	.0883	.0863	.0829	.0831	.0829	.0904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134008 / ANWA 33 KV S/S****Feeder No / Name : 201 / ANWA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.0288	.8573	.8573	.9335	.9335	.9335
2	1.0288	1.0288	1.0288	1.0288	.9335	.9335	1.1203
3	1.0288	1.0288	1.3717	1.0288	.9335	1.1203	1.1203
4	1.3717	1.2003	1.3717	1.3717	1.307	1.4937	1.307
5	1.3717	1.3717	1.3717	1.7147	1.4632	1.8671	1.4937
6	1.7147	1.8861	2.0576	1.8861	2.1262	2.2405	2.0538
7	1.7147	1.8861	2.2291	2.0576	2.2291	2.2405	2.2405
8	1.5432	1.3336	1.8861	1.7147	1.3717		
9	1.0669	1.3717		.9145	1.0288	1.0288	.8573
10	.9145	1.0669	1.3717	1.0669	1.3717	1.3717	1.2003
11	.4572	.6097	1.5432	1.0669	1.5432	1.3717	1.2003
12	.4287	.5144	2.0576	1.3336	1.5432	1.3717	1.2003
13		.3429	1.8861	1.3336	1.5432	1.3717	1.0288
14	.5144	.4287	1.5432	1.3336	1.5432	1.3717	1.0288
15	.5144	.5144	1.8861	1.2003	1.3717	1.3717	.8573
16	.5144	.5144	1.7147	1.2003	1.4575	1.3717	.8573
17	1.0288		1.2003	1.3203	1.0669	1.0669	.7621
18	1.7147	2.0538	1.3336	1.8861	1.2003	1.3717	1.3336
19	1.8861	1.8671	1.467	1.8861	1.3336	1.3336	1.3336
20	1.7147	1.4937	1.2003	1.6975	1.2003	1.0669	1.2003
21	1.7147	1.307	1.0669	1.3203	1.0669	1.0669	1.2003
22	1.3717	1.307	.9145	1.1317	.9145	.9145	1.2003
23	1.2003	1.0288	1.0288	.9431	1.1203	1.1203	1.2003
24	.8573	1.0288	.8573	.8573	.9335	1.1203	1.1203
Max	1.8861	2.0538	2.2291	2.0576	2.2291	2.2405	2.2405
Min	.4287	.3429	.8573	.8573	.9145	.9145	.7621
Avg	1.1460	1.1397	1.4454	1.3397	1.3140	1.3270	1.2109

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134008 / ANWA 33 KV S/S****Feeder No / Name : 202 / JALGAON SAPKAL****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.6859	.5144	.4287	.4287	.4287
2	.6859	.8573	.8573	1.0288	.4239	.4287	.4287
3	.6859	.8573	1.0288	1.0288	.4191	.4096	.4287
4	.6859	1.0288	1.0288	1.0288	.4191	.4572	.4287
5	.6859	1.2003	1.0288	1.3717	.6554	.7621	.5144
6	.8573	1.2003		1.3717	1.0669	1.0669	.8192
7	1.2003	1.2003	1.3717	1.5432	1.5242	1.8023	1.4403
8	1.0288	1.2193	1.5432	1.8861	1.7147	1.8023	1.5242
9	.7621	.7621		.7621	.8573	.8573	.5144
10	1.0669	.9145		.5144	.6859	.5144	.5144
11	1.0669	1.0669	.3429	.1715		.5144	.5144
12	1.2003	1.0669	.1715	.1715	.3429		.3429
13	1.2003	1.2003	.1715	.1715	.3429	.6859	.3429
14	1.0669	1.2003	.3429	.1715	.3429		
15	1.0669	1.0669	.3429		.3429	.5144	.5144
16	1.0669	1.2003	.3429	.1715	.5144		.6859
17	1.0288	.8954	.6097	.9335	.5144		.7621
18	1.0288	1.0745	.9145	1.1203	.6097		.9145
19	1.0288	1.0974	.9145	1.1203	.9145	.5144	.9145
20	1.0288	.7316	.6668	.9145	.6097	.4287	.8573
21	.8573	.4572	.5144	.5487	.3429	.3429	.6859
22	.8573	.4572	.3429	.4572	.3429	.3429	.6859
23	.8573	.5144	.5144	.4668	.3734	.3658	.6859
24	.6859	.8573	.5144	.5144	.4572	.3658	.3658
Max	1.2003	1.2193	1.5432	1.8861	1.7147	1.8023	1.5242
Min	.6859	.4572	.1715	.1715	.3429	.3429	.3429
Avg	.9328	.9577	.6786	.7819	.6194	.6634	.6658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134008 / ANWA 33 KV S/S****Feeder No / Name : 203 / WAKDI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	1.3717	1.0288	1.0288	1.1203	1.1203	.9335
2	1.0288	1.3717	1.0288	1.0288	1.1203	1.1203	1.1203
3	1.0288	1.3717	1.0288	1.0288	1.1203	1.1203	1.1203
4	1.0288	1.5432	1.0288	1.0288	1.307	1.307	1.307
5	1.0288	1.7147	1.3717	1.3717	1.6804	1.8671	1.4937
6	1.7147	1.8861	1.7147	1.7147	2.0119	2.0119	1.8671
7	1.7147	1.8861	1.8861	1.7147	1.9071	1.829	1.8671
8	1.8861	1.3717	1.5432	1.5432	1.5432		
9	1.0669	.9145		.7621	.6859	.8573	.8573
10	.3429	.5144	1.0288	.9145	1.7147	1.3717	1.0288
11	.1715	.5144	1.7147	1.0669	1.7147	1.5432	1.2003
12	.1715	.4287	2.0576	1.0669	1.7147	1.8861	1.2003
13	.2572	.3429	2.0576	1.6004	1.7147	1.7147	1.0288
14	.2572	.3429	2.0576	1.467	1.7147	1.5432	1.0288
15	.2572	.3429	2.0576	1.467	1.7147	1.3717	1.0288
16	.5144	.3429	2.0576	1.467	1.5432	1.3717	1.0288
17	1.0288	.4668	1.3336	1.1203	1.2003	1.0669	.9145
18	1.7147	2.0748	1.3336	1.8671	1.3336	1.0669	1.2003
19	1.7147	1.8861	1.3336	1.8671	1.2003	1.2003	1.0669
20	1.7147	1.6975	1.2003	1.6804	1.0669	1.3336	1.2003
21	1.7147	1.5089	1.0669	1.307	.9145		1.2003
22	1.5432	1.3203	.9145	1.1203	.9145	.9145	
23	1.3717	1.0288	1.0288	1.1203	1.1203	.9335	1.2003
24	1.0288	1.0288	3.4294	1.0288	1.1203	1.1203	.9335
Max	1.8861	2.0748	3.4294	1.8671	2.0119	2.0119	1.8671
Min	.1715	.3429	.9145	.7621	.6859	.8573	.8573
Avg	1.0411	1.1364	1.5349	1.3076	1.3833	1.3487	1.1740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134008 / ANWA 33 KV S/S****Feeder No / Name : 204 / KALYANI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.4287	.3429	.3772	.4668	.3734
2	.5144	.6859	.5144	.3429	.3772	.4668	.4668
3	.5144	.6859	.5144	.5144	.3772	.5601	.5601
4	.5144	.6859	.5144	.5144	.4668	.5601	.6535
5	.5144	.8573	.5144	.5144	.5601	.7468	.7468
6	.8573	1.2003	.5144	.5144	.7468	.7468	.9431
7	.8573	1.2003	.8573	.6859	.7468	.7468	.9431
8	1.0288	.6097	.8573	.8573	.5144		
9	.6097	.5144		.6097	.6859	.6859	.8573
10	.4287	.3429	.8573	1.1431	1.0288		.8573
11	.3429	.3429	1.2003	1.0669	1.5432		1.0288
12	.2572	.2572		1.2003	1.7147	1.2003	1.0288
13	.2572	.2572	1.5432	1.4003	1.7147	1.2003	1.0288
14	.2572	.2572	1.3717	1.3336	1.7147	1.2003	1.0288
15	.2572	.2572	1.5432	1.3336	1.7147	1.2003	.8573
16	.2572	.3429	1.5432	1.2003	1.7147	1.1145	.8573
17	.5144	.6401	1.0669	.5601	1.0669	.9907	.7621
18	.8573	1.0269	.6668	.8402	.6097	.7621	.8383
19	.8573	.8488	.7621	.8402	.4572	.6097	.6097
20	.8573	.8488	.6097	.5601	.5144	.6001	.6859
21	.5144	.6602	.5144	.4668	.5144	.5144	.6859
22	.5144	.6602	.4287	.3772	.4287	.4287	.6859
23		.5144	.4287	.3772	.4668	.3734	.6859
24	.3429	.5144		.3429	.3772	.4668	.4668
Max	1.0288	1.2003	1.5432	1.4003	1.7147	1.2003	1.0288
Min	.2572	.2572	.4287	.3429	.3772	.3734	.3734
Avg	.5409	.6207	.8215	.7475	.8514	.7448	.7675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134008 / ANWA 33 KV S/S****Feeder No / Name : 205 / HISODA BK****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8573	.8573	.8573	1.3927	1.4575	1.5432
2	.6859	.8573	1.0288	1.3717	1.5203	1.6385	1.6108
3	.6859	.8573	1.3717	1.7147	1.6766	1.6385	1.6766
4	.6859	1.2003	1.3717	1.7147	1.6004	1.6385	1.7204
5	.8573	1.7147	1.3717	1.7147	1.6766	1.8023	1.8023
6	1.0288	1.3717	1.7147	2.0576	1.9052	1.9052	2.1795
7		1.3717	2.0576	2.2291	2.0319	2.1605	2.3205
8	1.0288	1.0288	2.2291	2.2291	2.0576	2.1872	2.1605
9	1.2193	.9145			1.0288	1.0288	
10	1.3336	1.467	.7716	.5335	.8573	.3429	
11	1.4003	1.467	.5144	.5144		.3429	.4801
12	1.467	1.3336	.5144	.3429	.3429	.3429	.3429
13	1.6004	1.3336	.5144	.3429	.3429	.3429	.3429
14	1.6004	1.3336	.3429	.2572	.3429	.3429	
15		1.3336	.3429	.3429	.3429	.3429	.3429
16	1.467	1.5337	.5144	.5144	.4287	.3429	.5144
17	.8573	.9145	.6097	.5658	.6859	.6859	.6859
18	1.0288	1.587	1.0002	1.5089	.9145	.7335	1.1336
19	1.0288	1.307	1.0669	1.3203	1.0669	.9145	1.0669
20	1.0288	1.1203	.9145	1.0374	.7621	.9145	.6859
21	.8573	.9335	.7621	.9431	.6097	.7621	.8573
22	.8573	.8402	.6859	.8488		.6859	.8573
23	.8573	.6859	.8573	.7545	.7316	.8402	.8573
24	.6859	.8573	.6859	.8573	.7468	.8402	.8402
Max	1.6004	1.7147	2.2291	2.2291	2.0576	2.1872	2.3205
Min	.6859	.6859	.3429	.2572	.3429	.3429	.3429
Avg	1.0431	1.1759	.9609	1.0684	1.0484	1.0098	1.1439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 201 / HASNABAD****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.823	.3658	.2195	.1307	.415	.3772
2	.4572		.3658	.2195	.1829	.4904	.3772
3	.4572		.4024	.2195	.2012	.5658	.4527
4	.5121	1.0608	.5487	.2743	.2195	.679	.547
5	.6584	1.134	.631	.4024	.2926	.7922	.7356
6	.8059	1.134	.7011	.5487	.3856	1.094	1.0185
7	1.0517	1.1706	.9671	.6979		.9808	1.094
8	1.1744	1.262	.9991	.7316	.2629	.6224	1.0185
9		.811	.7922	.7733	.7356	.3658	.2641
10	.6413	.6224	.6036		.5658	.2743	.3734
11	.4715	.4527	.4715	.5093	.4715	.2195	.3391
12	.4338	.3584	.3772	.3772		.1867	
13	.415	.3584	.3395	.3772		.1867	.3222
14		.3584		.3395	.4715	.1867	.3052
15		.3584				.2241	.5087
16	.3772	.3584		.415	.3961	.1867	.407
17	.5093	.4527	.6036	.5093		.3395	.6783
18		.7922	.811	.811		.7545	.7461
19			.8488	.8299	.8865	.7922	
20	.8299	.7922	.679	.7167		.6413	.6104
21		.6413	.5847	.5281		.4904	.4239
22		.4527	.4338	.3584	.3961	.415	.3561
23		.415	.3584	.3395		.3772	.3391
24	.3395	.3206	.3772	.3584	.3395	.3584	.3772
Max	1.1744	1.262	.9991	.8299	.8865	1.094	1.094
Min	.3395	.3206	.3395	.2195	.1307	.1867	.2641
Avg	.5983	.6728	.5839	.4798	.3959	.4849	.5305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 202 / LATIFPUR****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4338	.4904	.4527	.3584	.3961	.3772	.3395
2	.415		.4527	.3584	.3961		.3395
3	.4338		.4904	.3772	.3961	.5658	.3772
4	.4904	.7167	.5658	.4527	.4527	.6602	.4527
5	.7167	.8488	.9242	.8676	.7167	.7545	.7733
6		1.0185	1.1317	1.0562	1.0562	.8865	1.0185
7	.9808	1.0374	1.1317			1.0374	1.1128
8	.9808	1.0185	.8488	1.0374	1.0562	.9431	1.0185
9	1.5364	1.1145	1.1317	.9694	.7133	.7356	.679
10	1.5074	1.4403	1.2269	.7865	.4938	.5093	.5281
11	1.5089	1.406	1.262		.3403	.2641	.3391
12	1.4746	1.3717	1.2971			.1886	.2543
13	1.4575	1.3375	1.1393			.1886	.2543
14		1.3032	1.134		.3292	.1886	.2204
15		1.2346	1.0608	.2743		.1886	.2035
16	1.1317	1.166	.9145	.3658	.2378	.1886	.2713
17	.415	.3395	.5281	.547		.3921	.5935
18		.9054		.9054		.5975	.6783
19			.8676	.8676	.7356	.6348	.5935
20	.9054	.7545	.6979	.679		.5228	.5935
21		.6413	.5281	.4715		.4527	.503
22		.5281	.415	.415	.3584	.415	.3391
23		.4527	.3584	.415		.3584	.3391
24	.4338	.415	.415	.3584	.4338	.3395	.3395
Max	1.5364	1.4403	1.2971	1.0562	1.0562	1.0374	1.1128
Min	.415	.3395	.3584	.2743	.2378	.1886	.2035
Avg	.9264	.9305	.8250	.6086	.5408	.4952	.5067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 203 / BORGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	1.5775		.4024	.3547	.5658
2	1.0608			.439	.4024	.6413
3	1.0974			.4572	.4024	.7167
4	1.2894	1.8861		.5487	.4755	.8488
5	1.5043	1.989		.7316	.6219	.9054
6	1.5775	2.0576		.9145	.8764	1.0562
7	2.2977	2.1605		1.0692		.9431
8	2.1605	2.2805		1.0517	.7888	.8299
9	.5847	.6602		.415	.7922	.6401
10	.3584	.3206		.2452	.4338	.4024
11	.2641		.3018	.2452	.3206	
12	.2452		.2829	.1886		
13	.2641			.1886		
14				.2263	.2829	
15				.1698		
16	.3206		.2829		.3772	
17	.415			.3772		
18			.6979	.7733		
19			.9242	1.0374	.7545	
20	.679		.6036	.7545		
21			.4904	.6224		
22			.3961	.4715	.415	
23			.5658	.4527		
24	.3772	.3961		.3584	.415	.4715
Max	2.2977	2.2805	.9242	1.0692	.8764	1.0562
Min	.2452	.3206	.2829	.1698	.2829	.4024
Avg	.9129	1.4809	.5051	.5278	.5142	.7292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 204 / NIMGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.1886	.3772	.3018	.3395	.3658	.3696
2	.3395		.415	.3018	.3018	.439	.3696
3	.3395		.415	.3395	.3018	.4755	.4207
4	.3772	.4715	.5281	.415	.3395	.5487	.5121
5	.6036	.5658	.6413	.6413	.4527	.5853	.695
6	.7922	.7733	.8299	.7922	.679	.6219	
7	.7167	.8488	.8676	.679		.6584	.8779
8	.6036	.7545	.7545	.6979	.6413	.6219	.8865
9	.5093	.6413	.6036	.5281	.6036	.4904	.5281
10	.3206	.4338	.2829	.3018	.3961	.3584	.3018
11	.2075	.2829	.2452		.2263	.1886	.1865
12	.1698	.2452	.2075			.1509	.0848
13	.132	.2263	.1698	.1509		.1509	.1696
14		.1886	.1886	.1698	.132	.1509	.1357
15		.1886	.1886	.1509		.1509	.1696
16	.1509	.1509	.1886	.2075	.2263	.1509	.1696
17	1.6975	1.8519		.4207		.1886	.373
18		2.1605		.5853			.6104
19		1.8519	1.2071	.6036	.6401	.5658	.5935
20	1.8176	1.6804	1.2437	.4755		.415	.4239
21		1.5089	1.0692	.415		.3772	.3391
22		1.4403	1.0166	.4024	.3841	.3018	.2543
23		1.3717	1.0029	.3658		.3018	.2543
24	1.4022	1.1523	1.3203	.985	.2801	.3292	.3018
Max	1.8176	2.1605	1.3203	.985	.679	.6584	.8865
Min	.132	.1509	.1698	.1509	.132	.1509	.0848
Avg	.6199	.8626	.6256	.4514	.3963	.3734	.3925

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 205 / KHADKI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.6602	.7545	.5658	.5281	.6401	.499
2	.679		.7545	.5658	.5281	.6767	.5658
3	.7167		.7922	.5847	.5093	.7316	.6219
4	.7922	.8488	.8676	.6413	.5281	.7682	.695
5	1.0185	.9431	1.0185	.8299	.8299	.823	.7783
6	1.1317	1.0562	1.1317	1.094	1.1317	.8779	1.0425
7	1.0562	1.094	1.2449	1.1317		.8596	1.1706
8	1.1317	1.0562	1.0562	1.0374	.9997	.8413	1.182
9	1.0751	.8488	1.0562	.8865	.7922	.7356	.8676
10	.7167		.5658	.4527	.6036	.547	.679
11	.3961	.3584	.4527	.3206	.3395	.3395	.3391
12		.3018		.1886		.2452	.2204
13	.2641	.3018		.1886		.2641	.1696
14		.2829		.2263	.2263		.1696
15		.3772					
16	.3584	.4527	.3584		.2452		
17	1.7661	2.6406		.6401			.6783
18		2.8121	.5487	1.0608		.8676	.8987
19		2.6749	.7499	1.0059	.6584	1.0185	.6783
20	1.869	2.4348	.695	.8596		.7733	.5935
21		2.1434	.3658	.7316		.6413	.5935
22		1.8519	.3658	.6767	.6584	.5847	.5087
23		1.7833	.3584	.6401		.5658	.5087
24	1.9982	1.2986	1.6975	.3547	.5788	.6219	.5658
Max	1.9982	2.8121	1.6975	1.1317	1.1317	1.0185	1.182
Min	.2641	.2829	.3584	.1886	.2263	.2452	.1696
Avg	.9780	1.2487	.7808	.6674	.6105	.6711	.6375

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134015 / HASNABAD****Feeder No / Name : 206 / RAJALA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5658	.5658	.5281	.5281	.415	.415
2	.5281		.5658	.5281	.5093	.4527	.415
3	.5658		.5658	.5658	.5093	.4904	.4527
4	.6413	.7167	.6413	.6036	.5281	.5658	.5658
5	.7922	.7545	.7167	.7167	.6413	.6413	.679
6	.8676	.7733	.7922	.8676	.811	.7167	.7922
7	.811	.7922	.8299	.8865		.8676	.8299
8	.679	.7167	.679	.7545	.7167	.7167	.7545
9	1.8107	1.5775	.6485	1.1157	1.0387	.5093	.4904
10	1.9204	1.6804		1.1706	1.1043	.3395	.3772
11	1.7661	1.7833		1.0791	1.1706	.2641	.2543
12	1.8004	1.8861		1.2269		.1886	.2035
13	1.8519	1.8176		1.2003		.1886	.1696
14		1.7147		1.1317	1.2437	.2263	.1696
15		1.6804		1.1568		.2641	.1696
16	1.5947	1.6461	1.1706	1.1744		.2641	.1696
17	.2829	.3395	.3772	.3772			.6783
18		.5658	.7356	2.037		1.1706	.78
19		.679	.7733	.811	.7545	1.0745	.763
20	.547	.5658	.6036	.6602		1.0387	.6783
21		.5281	.5847	.6224		1.0387	.7122
22		.5658	.6036	.6036	.547	1.0029	.6443
23		.5658	.5658	.5658		1.0059	.5935
24	.5281	.547	.5658	.5658	.547	.3772	.9877
Max	1.9204	1.8861	1.1706	2.037	1.2437	1.1706	.9877
Min	.2829	.3395	.3772	.3772	.5093	.1886	.1696
Avg	1.0303	1.0210	.6658	.8729	.7607	.6008	.5311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134018 / DHAWDA****Feeder No / Name : 201 / DHAWDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4115	.4458	.4458	.3944	.3944	.3944
2	.5487	.3944	.4287	.4801	.4287	.3944	
3	.5144	.4458	.4458	.4973	.4801	.4115	
4	.6173	.6173	.6173	.5487	.6173	.4801	
5	.583	.823	.823	.7716	.8402	.823	
6	.6516	.9774	.9431	.9945	1.0117	.9774	
7	.7202	1.046	1.046	.8573	.9945	1.0974	
8	.7888	.9602	.9945	.823	1.0117	1.046	
9	.6859	.4801	.6687	.6859	.9602	.5144	
10	.5487	.5316	.703	.6001	.6173	.5487	
11	.583	.703	.7373	.463	.6687		.5144
12	.5658	.6344	.6859	.4801	.6687	.5487	.5316
13	.5487	.6859	.6516	.5144	.6001	.583	.5144
14	.583	.7202	.6173	.5487	.6001		.4458
15	.6001	.7888	.6001	.5487	.6173		.4115
16	.6001	.7545	.6173	.5658	.6173		.4458
17	.8059	.7373	.6344	.6687	.8573		.6687
18	.8916	.7716	.6859	.9088	.9259		.9259
19	.9259	.823	.823	.8402	.9088		.8573
20	.9945	.703	.5487	.6859	.9602		.583
21	.9088	.8573	.4801	.6687	.7202		.5487
22	.703	.703	.463	.6516	.4801		
23	.583	.583	.4458	.6173	.4458		
24		.4287		.4115	.4115		.4287
Max	.9945	1.046	1.046	.9945	1.0117	1.0974	.9259
Min	.5144	.3944	.4287	.4115	.3944	.3944	.3944
Avg	.6725	.6909	.6568	.6366	.7016	.6516	.5592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134018 / DHAWDA****Feeder No / Name : 202 / WALSAWANGI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.8004	1.7661	1.8519	1.7147	2.0576	1.9719
2	1.5775	1.7318	1.7318	1.8861	1.989	2.1262	
3	1.6461	1.6975	1.7147	2.0233	2.3663	2.1262	
4	1.7147	2.0062	1.989	2.0919	2.4177	2.2634	
5	1.7833	2.1262	2.1434	2.4348	2.332	2.3834	
6	1.9547	2.2634	2.3148	2.4348	2.4006	2.4348	
7		2.3491	2.8807	2.4006	2.5206	2.4863	
8		2.452	2.4863	2.2977	2.7092	2.452	
9	1.286	1.166		1.2689	1.6975	1.0288	
10	2.7435	1.046	1.1831	.9602	1.3375	.9774	
11	2.915	.7888	.9774	.6173	.9259		.8573
12	3.035	.6516	.823	.6687	.6516	.6687	.7888
13	3.0864		.7716	.6173	.7888	.5658	.6173
14	3.0521		.6001	.6001			.6516
15	3.0864	.583	.6344				.6173
16	3.1207	1.0288	1.1145	.7888	.8745		1.0288
17	1.989	1.3032	1.3032	1.4575	1.4403		1.4403
18	2.2291	1.166	1.6118	1.9204	2.5206		2.0405
19	2.2634	1.3032	2.2634		2.7435		1.869
20	2.332	1.046	2.0576		2.9321		1.7661
21	2.1776	2.1776	1.9204	1.6632	2.6578		1.7833
22	2.0405	1.8861	1.8861	1.6461	2.0576		
23	1.9204	1.8004	1.8176	1.6804	1.869		
24	1.6289	1.8551	3.0864	1.7833	1.6632	1.8347	.6859
Max	3.1207	2.452	3.0864	2.4348	2.9321	2.4863	2.0405
Min	1.286	.583	.6001	.6001	.6516	.5658	.6173
Avg	2.2330	1.5558	1.6990	1.5759	1.9368	1.8004	1.2399

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134018 / DHAWDA****Feeder No / Name : 203 / BHORKHEDA FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.3429	.2401	.2401	.2058
2	.2401	.2229	.2401	.3772	.3086	.3429	
3	.2401	.3086	.2743	.4115	.3258	.5487	
4	.2743	.4115	.3086	.4801	.3944	.6173	
5	.3086	.463	.4115	.6173	.4973	.6173	
6	.3944	.4973	.5144	.6516	.5658	.703	
7		.5316	.6344	.6173	.6687	.703	
8		.6001	.6001	.583	.703	.8059	
9	.3258	.2572	.1372	.0857	.1372	.1715	
10	.3944	.1029	.0857	.0857	.0514	.1372	
11	.4973	.0857	.0686	.0514	.0857		.0686
12	.6687	.0686	.0686	.0343	.1372	.0514	.0686
13	.7373			.0343	.0514	.0514	.0857
14	.6859			.0514	.0857		.0857
15	.6344	.0514	.0857		.0857		.0857
16	.6001	.1372	.1372	.0343	.1029		.1543
17	.3429	.2058	.1886	.2743	.12		.1886
18	.3601	.2743	.2401	.3258	.2915		.2915
19	.4115	.3086	.2572	.2572	.2743		.2229
20	.4458	.1886	.1715	.2058	.3429		.1886
21	.3944	.3429	.1372	.2058	.2915		.1715
22	.2915	.2915	.1372	.1886	.1543		
23	.2058	.2058	.1372	.1886	.1543		
24	.1372	.1543		.1372	.12	.1372	.1372
Max	.7373	.6001	.6344	.6516	.703	.8059	.2915
Min	.1372	.0514	.0686	.0343	.0514	.0514	.0686
Avg	.3998	.2689	.2401	.2714	.2579	.3944	.1504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134018 / DHAWDA****Feeder No / Name : 204 / JAIDEVWADI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.3429	.3772	.3429	.5144	.4458	.4287
2	.7888	.3429		.3601	.5487	.4287	
3	.7202	.3601	.3429	.3772	.5144	.463	
4	.7545	.3944	.3944	.4115	.6516	.4973	
5	1.0117	.5316	.5316	.6516	.7888	.583	
6	1.0631	.6687	.583	.703	.9088	.8059	
7	1.166	.7202	.6516	.6516	.8573	.9088	
8	1.046	.583	.5144	.583	.7373	.823	
9	.5144		1.046	.5144		1.8518	
10		1.7661	1.3717	1.7147		1.406	
11		2.3148	1.6289	1.7833	1.5261		1.2517
12	.3601	2.3148	1.7147	1.749	3.2578	1.5604	1.166
13	.3429	2.1434	1.8004	1.7661	1.5775	1.6289	1.1145
14	.3429	2.0919	1.8347	1.7147	1.3203		1.1317
15		2.0748	1.7318	1.6804	1.286		1.0802
16	.3429	2.1605	1.6118	1.5947	1.2517		1.2003
17	.6516	1.9033	1.4575	1.4232	.3429		.583
18	.7888	.6001	.6859	.7202	.6344		.5144
19	.823	.7716	.583	.6516	.703		.5144
20	.7545	.6344	.5144	.5658	.7716		.3944
21	.583	.583	.3944	.5316	.6344		.3601
22	.463	.5144	.3429	.5487	.5144		
23	.4115	.4115	.3429	.5144	.463		
24	.3944	.3429		.3258	.3944	.4287	.3944
Max	1.166	2.3148	1.8347	1.7833	3.2578	1.8518	1.2517
Min	.3429	.3429	.3429	.3258	.3429	.4287	.3601
Avg	.6671	1.0683	.9298	.9116	.9181	.9101	.7795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134018 / DHAWDA****Feeder No / Name : 205 / 11kv Wadot T****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.4458	.4801	.7202	.6173	.6516	.5144
2	.823	.4287	.4458	.7545	.5487	.6344	
3	.9088	.463	.5144	.7202	.5658	.6173	
4	1.0802	.5658	.5658	.7545	.6516	.6687	
5	1.166	.6344	.6516	.8916	.6687	.8059	
6	1.3546	.6687	.6859	1.046	.703	.8745	
7	1.9376	.6859	.823	.7716	.6687	.9259	
8	2.0062	.6344	.6001	.7202	.703	.703	
9	.4801	1.166	.5316	.6859	.4287	.2229	
10	.2401	1.5432	.9088		.5144	.8402	
11	.2401	2.0062	.9088		.5487		.6173
12	.1886	1.9033	.9945		.5316	.9945	.6516
13	.2058		1.0288		.4973	1.046	.583
14	.1886		1.0974		.5316		.5487
15	.1715	.9945	1.3203	.2229			.5144
16			1.3203	.3429			.6173
17		.7716	1.3203	.7202	.5144		.6687
18	.8402	.6516	1.1317	.9088	.9431		.823
19	.8916	.3772	.9431	.8573	.8402		.7545
20	.9259	.5144	.8573	.823	.9088		.6344
21	.8745	.7716	.8402	.7888	.7888		.583
22	.7373	.7373	.823	.7716	.7202		
23	.6173	.6173	.7888	.703	.6687		
24	.4801	.4287		.703	.6687	.6344	.4115
Max	2.0062	2.0062	1.3203	1.046	.9431	1.046	.823
Min	.1715	.3772	.4458	.2229	.4287	.2229	.4115
Avg	.7794	.8100	.8514	.7319	.6469	.7399	.6094

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV****Feeder No / Name : 201 / Relgaon****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.7773	.5792	.7468	.9145	.6097	.6535
2	1.0059	.7926	.6097	.8402	.9297	.6401	.7468
3	.9145	.823	.6859	.823	.9755	.6859	.8402
4	1.0974	.945	.9907	1.0059	.9907	.7926	1.0059
5	1.2803	1.1736	1.1431	1.1888	1.0059	.9145	.9145
6	1.4266		1.2346	1.3306	1.1736	.9755	.9694
7	1.6766	1.7071	.381	1.9669	1.2346	.945	1.0608
8	2.3137	2.1338	1.9966	2.3472	1.1888	.9602	1.1523
9	2.5652	2.0119	2.21	2.6322	1.0669	.884	1.134
10	2.649		2.4691	2.6558	1.0364	.7926	.9328
11	2.4539	2.21	2.4539	2.5301		.8779	.6097
12	2.5301	2.4691	2.2558	2.5758	.6401	.9511	.6554
13	2.4234	2.652	2.6825	2.4844	.6249	1.134	.6097
14	2.3624	2.6673	2.7328	2.4691	.6097	1.0059	.4725
15		.5182	.8048	.6401	2.8197	2.4577	1.5242
16		.7773	.9145	.7773	2.9111	2.915	1.6309
17		1.0669	1.0242	1.0974	2.7435	2.5396	1.5546
18	1.2193	1.2955	1.7551	1.4632	2.5149	2.1052	1.3717
19	1.3565	1.2193	1.4632	1.0822	2.2405	1.9281	1.1431
20	1.326	1.1431	1.3535	.9907	2.1033	1.8778	1.1126
21	1.1279	1.0669	1.2803	1.0059	1.9814	1.7939	1.0669
22	.945	.9145	1.1888	.9907	1.8138	1.7604	1.0212
23	.8078	.7621	.9145	.9755	.6859	.8402	.8383
24	1.0059	.7926	1.8004	.823	.945	.6859	.7468
Max	2.649	2.6673	2.7328	2.6558	2.9111	2.915	1.6309
Min	.8078	.5182	.381	.6401	.6097	.6097	.4725
Avg	1.5906	1.3600	1.4552	1.4768	1.4413	1.2947	.9903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV****Feeder No / Name : 202 / Pimpalgaon R****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.442	.4572	.5601	.4877	.381	.7468
2	.8596	.4877	.5335	.6535	.5182	.5335	.823
3	.9877	.5335	.6097	.7655	.6249	.6859	1.0974
4	1.0974	.6249	.9145	1.0974	.6859	.9907	1.1888
5	1.2254	.7164	1.0669	1.2437	.8535		1.2803
6	1.3535	1.2041	1.2193	1.3352	1.0669	1.1279	1.4632
7	1.0974	1.0364	1.2193	1.2986	1.1279	1.1888	1.4998
8	.8029	1.0517	1.2346	1.262	.7926	1.2498	1.5708
9	1.1157	.9145	.9907	1.2071	1.326	1.1888	1.5181
10	1.0425	.4572	.6859	.8779	1.4022	1.0974	1.2803
11	.6706	.381	.5182	.5639	1.2955	1.5402	1.1584
12	.3963	.3048	.3658	.3963	1.2193	1.39	1.2803
13	.3201	.3658	.4294	.3658	1.2955	1.5364	1.0669
14	.2896	.3353	.3921	.3506	1.387	1.5364	1.1279
15	1.4937	1.5089	1.8482	1.6918	.4572	.4572	.8383
16	1.5851	1.5851	1.7804	1.5394	.4115	.5304	.5639
17	1.6309	1.5851	1.6933	1.7528	.6097	.7468	.7621
18	1.5699	1.6004	1.1706	1.5699	.7621	1.2437	.9907
19	1.448	1.4937	1.5912	1.3717	1.0212	1.2071	1.1126
20	1.4022	1.3717	1.5581	1.2803	.8383	.9511	.7621
21	1.2803	1.1431	1.5083	1.2498	.6401	.7468	
22	1.1126	1.0364	1.4969	1.2041	.4725	.5788	.503
23	.4115	.6401	.7468	.6097	.4268	.5228	.4572
24	.8402	.3963	.4115	.7468	.5182	.3963	.4668
Max	1.6309	1.6004	1.8482	1.7528	1.4022	1.5402	1.5708
Min	.2896	.3048	.3658	.3506	.4115	.381	.4572
Avg	1.0326	.8840	1.0184	1.0414	.8434	.9490	1.0243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV****Feeder No / Name : 203 / LEHA/SHELUD FEEDER SINGLE PHASING
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.9052	2.0576	1.2986	.5639	.6401	.8402
2	1.8004	1.9357	1.9814	1.1888	.5639	.6859	.9145
3	1.7147	1.9662	1.829	1.2986	.503	.7316	1.0059
4	1.7318	1.8595	1.9814	1.2803	.8078	.7621	1.0974
5	1.7804	1.9814	1.9966	1.4506	1.0059	.9907	1.2803
6	1.8143	2.0119	2.1033	1.6297	1.1279	1.0822	1.4449
7	1.1706	1.0212	.7621	1.39	.884	1.2955	1.7337
8	1.2071	.9145	.6706	1.0974		1.5699	1.8778
9	.9511	.8078	.5792	.9877		1.5546	1.6933
10	.6535	.4268	.4877		.8688	1.5089	1.8442
11	.3353	.381	.3963		.8993	1.5939	1.5242
12	.2591	.2286			1.0364	1.5023	1.5851
13	.2286	.2134			1.0669	1.5546	
14	.1829	.1981			1.0974	1.46	1.4937
15	.1981	.2134		.2743	.4268		.4572
16	.2591	.2743					.2896
17	.5639	.7621	.7499		.6859		.7621
18	.7926	.9297	1.1706		.7621		.9907
19	.884	.9145	1.2803	.823	.9145	.9145	1.0822
20	.8535	.8383	.9145	.7468	.8383	.8596	.9145
21	.7621	.6859	.823	.6554	.6859	.7842	.7621
22	.5792	.5335	.8962	.6097	.5487	.7655	.6554
23	1.89	1.2651	1.0974	.5792	.5335	.7468	.6097
24	2.0348	1.9204	2.0576	1.3717	.5487	.5335	.6908
Max	2.0348	2.0119	2.1033	1.6297	1.1279	1.5939	1.8778
Min	.1829	.1981	.3963	.2743	.4268	.5335	.2896
Avg	1.0222	1.0079	1.2545	1.0426	.7795	1.0768	1.1108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV****Feeder No / Name : 204 / PARADH****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.5639	.5335	.7655	1.0974	1.7071	1.8442
2	.9145	.5944	.6859	.8402	1.0212	1.6766	1.9113
3	1.0059	.6401	.7621	1.0059	.9907	1.6004	1.6766
4	1.1157	.7773	.9145	1.0974	.9755	1.6766	1.7924
5	1.2437	.9907	1.0669	1.2437	1.0059	1.7071	1.5546
6	1.3717	1.1736	1.2041	1.3032	1.0669	1.7223	1.4815
7	1.39	1.1888	1.2193	1.4632	1.2346	.9145	1.4632
8	1.3717	1.0669	1.2498	1.2803	1.1888	1.0669	1.262
9	1.0608	.884	.9907	1.1523	1.0059	.9145	1.0425
10	.7865	.6859	.7621	.8962	.8078	.8078	.9145
11	.5335		.6249	.5487	.6859	.7282	.4572
12	.381		.5487		.4572		.4115
13	.3658		.5601		.442		.4572
14	.3353		.5415		.4115		.3658
15	2.5911		3.1855	1.2193	.442		.4268
16		3.0483	3.2388	1.5089	.4572		.4877
17	2.1186	2.7435	3.2388	1.5546	.6097	.9694	.6859
18	2.0576	2.0576	2.0287	1.5699	.7621	1.1523	.8383
19	1.829	2.21	2.0008	1.2955	.9602	1.1523	.9907
20	1.8138	2.2862	1.9161	1.3717	.884	.9877	.8383
21	1.6309	2.1338	1.7147	1.3565	.6859	.823	.6859
22	1.4632	2.2862	1.647	1.326	.5487	.7468	.5639
23	.4725	.6097	.7655	1.2346	1.9814	2.0119	1.7528
24	.6535	.503	1.8861	.7095	1.1584	1.7375	1.9281
Max	2.5911	3.0483	3.2388	1.5699	1.9814	2.0119	1.9281
Min	.3353	.503	.5335	.5487	.4115	.7282	.3658
Avg	1.1849	1.3918	1.3869	1.1782	.8700	1.2686	1.0764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134029 / PIMPALGAON (R) 33 KV****Feeder No / Name : 205 / Awghadrao sawangi SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.2439	.442	.7316	.3506	.3048	.6348
2	.7468	.2591	.4572	.823	.3353	.3353	
3	.823	.442	.6097	.9145	.3658	.381	.8215
4	1.0059	.6859	.6859	1.0059	.381	.5335	.8402
5	1.2437	.8688	.7926	1.0974	.6706	.6859	.9145
6	1.134	.9907	.884	1.134	.945	.823	.9877
7	1.0059	.7773	.8383	.9328	.9755	.884	1.0242
8	.7655	.8383	.7621	.9145	.9145	.9145	1.0608
9	.8962	.7316	.7316	.9877	.7773	.884	.8048
10	.8029	.6706	.6859	.9511	.5335	.8383	.6722
11	.6097	.6554	.6859	.7926	.381	.4854	.4725
12	.5944	.6401	.6706	.5792	.3658	.4854	.3506
13	.5792	.6554	.8215	.6097	.3353	.4108	.3048
14	.503	.5944	.8029	.6401	.2591	.3547	.2439
15	.0914	.2743	.3547	.3658	.3048	.6535	.3048
16	.4115	.3658	.4668	.4877	.5792	.5788	.4572
17	.6859	.6859	.7282	.5944	.5944	.7865	.4725
18	.9755	.945	1.1706	.7468	.6097	.7842	.503
19	.8535	.9145	1.0974	.6859	.6401	.5975	.5335
20	.7011	.7621	.7682	.5944	.5335	.5601	.503
21	.4115		.7468	.5335	.4572	.5788	.4572
22	.2896	.3658	.7095	.4115	.3963	.4572	.3506
23	.2286	.3048	.7095	.3658	.3658	.4108	.3353
24	.5228	.2439	.2896	.5601	.3353	.2896	.3734
Max	1.2437	.9907	1.1706	1.134	.9755	.9145	1.0608
Min	.0914	.2439	.2896	.3658	.2591	.2896	.2439
Avg	.6890	.6050	.7046	.7275	.5169	.5841	.5836

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S****Feeder No / Name : 201 / KEDARKHEDA ag1****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1768	1.1142			
2	1.21	1.1633			
3	1.2597	1.1961			
4	1.3094	1.1797			
5	1.3757	1.1961			
6	1.4586	1.1961			
7	1.5912	1.5074	1.1142		
8	1.6575	1.5238	1.5581		
9				.0572	
10					.5801
11				.3812	.663
12				.4973	.7459
13				.5304	.9012
14					.8192
15				.2155	
16				.5304	.5735
17				.2321	.5935
Max	1.6575	1.5238	1.5581	.5304	.9012
Min	1.1768	1.1142	1.1142	.0572	.5735
Avg	1.3799	1.2596	1.3362	.3492	.6966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S

Feeder No / Name : 202 / DEOLGAON TAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.381	.4191		.7293	.7127
2		.381	.4001	.4763		.779	.9614
3		.4001	.4572	.4763		.8619	.9945
4		.4001	.5335	.4954		.9614	1.094
5		.4191		.4954		1.0277	1.2597
6		.4382		.4763		1.2597	1.3426
7		.4763		.4954		1.3094	1.5746
8				.4954		1.5581	1.6907
9			1.0277				
10	2.3434	1.4918	1.6907		.4382		
11	1.989	1.7736	1.8233	1.7147	1.8067		
12	2.1382	1.9227	1.9062	2.0957	1.9227		
13	2.1051	1.873	1.9062	2.191	1.8067		
14	1.8564	1.6244	1.9062		1.9227		
15	1.8399	1.5581	1.6575		1.4918	.1715	.381
16	2.0386	1.4918	1.5912	2.3624	1.5249	.1905	.381
17	1.6907	1.4918	1.2003	2.191	1.3592	.3429	.4191
18						.5335	.4191
19						.4954	.4763
20						.4191	.4763
21						.3429	.5335
22						.2858	.5335
23		.2667				.2858	.5335
24		.362	.4191				.4954
Max	2.3434	1.9227	1.9062	2.3624	1.9227	1.5581	1.6907
Min	1.6907	.2667	.381	.4191	.4382	.1715	.381
Avg	2.0002	.9854	1.2072	1.1065	1.5341	.6796	.7933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S****Feeder No / Name : 203 / KEDARKHEDA AG 2****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.5716	.373		
2	.5304	.5716	.4917		
3	.5801	.6097	.5407		
4	.6796	.6097	.6554		
5	.7459	.6287	.6554		
6	.7956	.6287	.6882		
7	.8288	.743	.6882		
8	.779	.8002	.7373		
9				.2667	
10				.3048	.3315
11				.2818	.3315
12				.3647	.3812
13				.3812	.4096
14				.2652	.4096
15				.3978	
16				.2321	.6882
17				.3481	.5735
24		1.2003			
Max	.8288	1.2003	.7373	.3978	.6882
Min	.5138	.5716	.373	.2321	.3315
Avg	.6817	.7071	.6037	.3158	.4464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134035 / 33 KV KEDERKHEDA S/S****Feeder No / Name : 205 / KEDARKHEDA G****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5716	.6287			.5144
2		.5716	.5716	.8002		.6097	.5335
3		.6287	.6287	1.0456		.743	.5716
4		.8573	.7621	1.2136		.8192	.6859
5		1.2574	1.105	1.2986		1.1812	1.1431
6		1.448	1.4861	1.2986		1.467	1.4861
7		1.6194	1.4098			1.3908	1.5432
8		1.5051	1.467			1.3336	1.4289
9		1.3146	1.4289	1.2437		.9717	
10	.6478	.9145	.9145		.8573	.6478	.9335
11	.4572	.5335	.6287	.7621	.5144	.6287	.4191
12	.4191	.362	.4191			.4382	.4001
13	.4001	.4382	.4191			.4191	.4001
14	.3048	.4382	.2858			.4001	.4001
15	.362	.4572	.2858		.5144	.4572	
16	.4763	.5144	.4001	.4954	.5716	.5906	.6097
17	.6859	.8002	1.2384	.6478	.8573	.743	.811
18	1.3146	1.4861	1.2574		1.4861	1.3146	1.1888
19	1.448	1.2765	.9907		1.3908	1.2574	.7842
20	.9335	.9717	.8573		.9717	.8764	.6161
21	.8002	.743	.6287		.8002	.6859	.4715
22	.6287	.6668	.4191		.6859	.5716	.4715
23	.5716	.5335	.4382		.5335	.5144	.4572
24		.5716	1.3717			.5335	.4572
Max	1.448	1.6194	1.4861	1.2986	1.4861	1.467	1.5432
Min	.3048	.362	.2858	.4954	.5144	.4001	.4001
Avg	.6750	.8534	.8327	.9434	.8348	.8085	.7421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

BHOKARDHAN (R) S/DN[408] BU 2763

Substation No/ Name :- 134044 / DANAPUR 33 KV S/S

Feeder No / Name : 201 / Surangli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	1.4575	.7716	.6859		
2	.7373	.7373	1.5775	1.0288	.8402		
3	.8745	.8573	1.6118	1.1317	1.1145		
4	.9088	.8745	1.6289	1.2003	1.3889		
5	.9945		1.7147	1.3717	1.6289		
6	1.286	1.2003	1.7318	1.5432	1.6632		
7	1.3032	1.6804	1.7661	1.6289	1.6804		
8	1.6118	1.5775	1.8176	1.8004	1.7318		
10						1.7147	2.1948
11						2.2119	2.3148
12						2.4006	2.2805
13						2.572	2.0405
14						2.572	2.3148
15						2.4006	2.3663
16						2.4863	2.1776
17						2.4863	1.9719
18						2.4863	
Max	1.6118	1.6804	1.8176	1.8004	1.7318	2.572	2.3663
Min	.6859	.6859	1.4575	.7716	.6859	1.7147	1.9719
Avg	1.0503	1.0876	1.6632	1.3096	1.3417	2.3701	2.2077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 202 / KATHORA BAZAR GFSS
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3584	.3584	.3772	.3584	.3961	.3772
2	.3584	.3395	.4527	.4287	.3772	.415	.3772
3	.3772	.3961	.5658	.4287	.4904	.5658	.3772
4	.5281	.5093	.7356	.5144	.5847	.679	.4287
5	.9054	.8676	.7922	.8573	.6224	.7922	.5144
6	.9619	.9431	.7356	.823	.6224	.7733	.6859
7	.7922	.6979	.7167		.6036	.6224	.9088
8	.6979	.6224	.7167	.6001	.5847	.6036	.5144
9	.5658	.7167	.9054	.3429	.6602	.4715	.5658
10	.2829	.4527	.5658	.2829	.6224	.4287	.4904
11	.3395	.3206	.4287	.1132	.415	.4287	
12	.2075	.2829		.132	.3395	.4115	
13	.1886	.2641		.1886	.3206	.3772	
14		.2452	.3086	.2075	.3206	.3086	.2263
15	.3395	.2452	.3086		.415	.3772	.3395
16	.415	.3961	.3944		.5093	.4287	.3772
17	.5658	.6979	.6001		.7167	.7202	.6413
18	1.0374	.9054	.8573	.6036	.7373	.8573	.9431
19	.9431	.679	.8573	.5847	.811	.7716	.7545
20	.6413	.5847	.5658	.5658	.679	.6001	.6602
21	.4338	.4715	.4287	.5281	.5658	.5144	
22	.3772	.3772	.3429	.4715	.4715	.3944	.415
23	.3395	.3395		.3772	.415		
24	.3395	.3395	.3395	.3429	.3584	.415	.3772
Max	1.0374	.9431	.9054	.8573	.811	.8573	.9431
Min	.1886	.2452	.3086	.1132	.3206	.3086	.2263
Avg	.5207	.5022	.5703	.4385	.5250	.5371	.5250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 203 / Dagadwadi Ag****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.12	.0343	.0857	.1715
2	.0514	.0514	.0514	.12	.0514	.1372	.1715
3	.0514	.0514	.0514	.1372	.0686	.1372	.2229
4	.0514	.0514	.0686	.1372	.0857	.1886	.2572
5	.0857	.0514	.1029	.1715	.0857	.2058	.3086
6	.0857	.0857	.1029	.1886	.12	.3086	.3429
7	.1029	.1029	.12	.1715	.1372	.3429	.3772
8	.1372	.0686	.12	.1372	.1372	.3258	.4287
9	.1029	.0514					
10	.3086	.2572	.2058	.2058	.2915		
11	.3772	.3944	.3429	.3429	.3601		
12	.5316	.3944	.3429	.3601	.4115		
13	.4115	.3258	.4287	.3429	.463		
14	.4801	.3258	.4287	.1715	.463		
15	.4287	.3086	.3429	.2743	.4115	.0686	.0514
16	.3772	.2915	.2915	.3258	.3944	.0857	.0514
17	.3429	.2572	.3086	.2743	.2572	.1372	.0857
18	.1715	.0686	.1372	.1029	.1543		
19	.1886	.1029	.1886	.12	.1372	.1715	
20	.1372	.0857	.1715	.1029	.1029	.1715	
21	.1029	.0514	.1372	.0857	.0343	.1715	
22	.0686	.0343	.1372	.0514	.0343	.1372	
23	.0686	.0514		.0343	.0343		
24	.0514	.0686	.0514	.12	.0343	.0343	.12
Max	.5316	.3944	.4287	.3601	.463	.3429	.4287
Min	.0514	.0343	.0514	.0343	.0343	.0343	.0514
Avg	.1986	.1493	.1902	.1782	.1871	.1693	.2158

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 204 / Express Water Supply
Feeder KV- 11 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.0343						
6	.0514				.0514	.0343	
7	.0343			.0514	.0514	.0514	.0514
8				.0514	.0514	.0514	.0514
9		.0343		.0514	.0514	.0514	.0514
10	.0343	.0514		.0514	.0514	.0514	.0514
11	.0343			.0514	.0514	.0514	.0514
12	.0343	.0343		.0514	.0514	.0514	.0343
13	.0343	.0514		.0514	.0686	.0514	.0343
14	.0514	.0514		.0514	.0514	.0514	.0514
15	.0514	.0514			.0514	.0514	.0514
16	.0514	.0514	.0343		.0514	.0514	.0343
17	.0514	.0514			.0514	.0514	.0514
18	.0514	.0514		.0343	.0514	.0514	.0514
19	.0514	.0514		.0514	.0686	.0514	.0514
20	.0514	.0514		.0514	.0514	.0514	
21	.0514	.0514		.0514	.0343	.0343	
22	.0514			.0514		.0343	
24			.0343				
Max	.0514	.0514	.0343	.0514	.0686	.0514	.0514
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.0450	.0486	.0343	.0501	.0525	.0484	.0475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 205 / Danapur GFSS****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3395	.3018	.4287	.3206	.2829	.3429
2	.3206	.3206	.3206		.3584	.3206	.3429
3	.3395	.3584	.4527	.5144	.4527	.3961	.4287
4	.6036		.811		.6602	.7167	.5144
5	.8299	.7922	1.2449	.8573	.8865	1.1317	.6859
6	1.094	1.1317	1.226	1.0802	1.0562	1.1506	.8573
7	1.2071	1.1506	1.1506	1.0288	1.094	1.094	1.0288
8	.9242	1.1317	1.1317	.9431	1.1317	.9808	.8573
9	.7922	.8488	.6979	.6859	.8865	.7356	.4287
10	.415	.4527	.4287	.4715	.5658	.4287	.4715
11	.3206	.3018	.3429	.2641	.3772	.3772	.3395
12	.2075	.2641	.3086	.2452	.3018	.3429	.2263
13	.3772	.2452	.2572	.2075	.2641	.3429	.2075
14	.2075	.2452	.2572	.1886	.2075	.2572	.2263
15	.3395	.1886	.3429	.2075	.2263	.2572	
16	.5281	.2641	.3772	.3018	.2641	.2572	.3584
17	.6224	.5658	.6001	.679	.6224	.5144	.8488
18	1.1317	1.1506	.823	1.094	1.0562	1.0631	1.1317
19	1.0374	.9242	.7716	1.1317	.9054		.9431
20	.7922	.6036	.5144	.6979	.6036	.5658	.6413
21	.4904	.4527	.4287	.4715	.4904	.4287	.5093
22	.415	.3395	.4287	.3584	.3395	.3772	.3395
23	.3018	.3206		.3018	.3018		
24	.3018		.3206	.3772	.3018	.2829	.3772
Max	1.2071	1.1506	1.2449	1.1317	1.1317	1.1506	1.1317
Min	.2075	.1886	.2572	.1886	.2075	.2572	.2075
Avg	.5792	.5633	.5887	.5698	.5698	.5593	.5503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 206 / GODRI AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3429
2						.3601
3						.3601
4						.3944
5						.4458
6						.8059
7						.9774
8						.9602
10	1.3717	1.0631	1.1145	.8916	.7716	
11	1.6118		1.0288	1.1145	1.0631	
12	1.4403	1.1317	1.3717	1.2517	1.166	
13	1.5432	1.5432	1.3889	1.2003	1.2003	
14	1.5432	1.5775	1.3375	1.1145	1.2689	
15	1.2003	1.2174	1.2003	1.0802	1.2003	
16	1.3717	1.4403	1.1145	1.0802	1.1317	
17		1.166	.9431	.6859	.6859	
Max	1.6118	1.5775	1.3889	1.2517	1.2689	.9774
Min	1.2003	1.0631	.9431	.6859	.6859	.3429
Avg	1.4403	1.3056	1.1874	1.0524	1.0610	.5809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 207 / KARKHANA AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1029	
2						.12	.1715
3						.2058	.2058
4						.2229	.2572
5						.3086	.2572
6						.3429	.3086
7						.3601	.3429
8						.3601	.5658
10	.5316	.2401	.3429	.3429	.2229		
11	.6001	.4115	.5144	.3601	.5487		
12	.6516		.4801	.4458	.6859		
13	.6687		.5487	.4458	.5316		
14	.6001	.3429	.4287	.4458	.3772		
15	.5487	.3601	.4287	.4287	.3772		
16	.9259	.463	.4801	.3429	.3772		
17		.3944	.4458	.1715	.2915		
Max	.9259	.463	.5487	.4458	.6859	.3601	.5658
Min	.5316	.2401	.3429	.1715	.2229	.1029	.1715
Avg	.6467	.3687	.4587	.3729	.4265	.2529	.3013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134044 / DANAPUR 33 KV S/S****Feeder No / Name : 208 / KATHORA BAZAR AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.2174	1.3546	1.0288	.4115		
2	1.2517	1.2689	1.3717	1.1145	.3944		
3	1.286	1.2174	1.4403	1.2003	.3944		
4	1.3375	1.286	1.5604	1.3717	.4115		
5	1.3717	1.3375	1.9204	1.7147	.4458		
6	1.5432	1.5432	2.2291	2.0576	.463		
7	1.7318	1.9719	2.2634	2.2977	.463		
8	1.9719	2.0748	2.3148	2.3663	.4973		
10						.6001	.703
11						.7202	
12						.7716	.7716
13						.823	
14						.8573	.7545
15						.8059	.9259
16						.8573	.9945
17						.8573	.9945
21						.8573	
Max	1.9719	2.0748	2.3148	2.3663	.4973	.8573	.9945
Min	1.2003	1.2174	1.3546	1.0288	.3944	.6001	.703
Avg	1.4618	1.4896	1.8068	1.6440	.4351	.7944	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134060 / NALNI****Feeder No / Name : 201 / NALNI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.1469	1.065	1.1469	.6554	.3277	.4915
2	1.3927	1.2289	1.1469	1.2289	.6554	.3277	.5735
3	1.4746	1.3108	1.1469	1.3763	.7373	.4096	.6226
4	1.6385	1.4746	1.2289	1.5729	.7373	.4915	.6554
5	1.8023	1.6385	1.3108	1.8023	.8192	.5735	.7373
6	1.9662	1.8023	1.7204	1.8187	.8192	.7373	.8192
7	2.13	1.9662	2.0972	2.0972	.8192	.8192	.8356
8	2.0972	2.13	2.0317	2.1136	.8192	.9012	.852
9	.4915	.6554	.9012	.4915	.8192	.4096	.4424
10	.4915	.639	.7209		.6554	.2294	.5243
11	.4915	.4915	.5243			.2294	.4915
12	.4096	.4752	.4915			.2294	.4915
13	.4096	.4752	.5407				.426
14	.4096	.4588	.5735		.3277	.3113	.5407
15	.4915	.4588	.5571		.4096	.2949	.5898
16	.4915	.4915	.5079		.4915	.3277	.5898
17	.6554	.6718	.7373		.5735	.4096	
18	.8192	.8356	.9012	.9012	.7373	.5898	.7045
19	.6554	.9175	.8684	.8192	.9012	.6554	.7045
20	.5735	.7373	.7865	.6554	.6554	.5243	.5407
21	.4915	.5079	.5079	.6226	.5735	.426	.4096
22	.4096	.4915	.4588	.5735	.4915	.3932	.3768
23	.3277	.4096	.3768	.4915	.4915	.3605	
24	.3277	.3277	.3277	.3605	.4096	.4096	.3277
Max	2.13	2.13	2.0972	2.1136	.9012	.9012	.852
Min	.3277	.3277	.3277	.3605	.3277	.2294	.3277
Avg	.9100	.9059	.8971	1.1295	.6476	.4516	.5794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134060 / NALNI****Feeder No / Name : 202 / PIMPALGAON BARAV****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.6554	.6554	.5079	.6554	.4915	.5735
2	.6226	.6554	.6554	.4915	.6554	.4915	.6554
3	.6882	.6554	.6882	.5735	.6554	.5735	.6882
4	.6882	.7373	.7537	.6226	.8192	.6554	.7373
5	.7865	.8192	.8192	.7373	.852	.7373	.7865
6	.852	.9012	.8192	.7537	.9503	.9012	.9012
7	.9012	.8192	.8192	.7373	.9012	.9012	.6554
8	.8192	.8192	.5407	.7209	.8192	.9012	.9012
9	2.1628	1.8023	1.4746	1.7532	2.0481	.6554	.6882
10	2.13	1.8842	1.7204	1.8023	1.8842	.639	.4424
11	2.0481	1.917	1.7204	1.7368	1.7204	.3932	.2785
12	1.8023	1.6876	1.8187		1.7204		.2785
13	1.8023	1.5729	1.7204		1.7204		.2458
14	1.7204	1.5238	1.8187		1.8679		.213
15	1.6385	1.5238	1.8023		1.5565	.2949	.2949
16	1.8023	1.4746	1.5893	1.6385	1.6385	.3932	.3113
17	.4915	.4915	.4588	.4915	.4915	.3932	
18	.8192	.7865	.7865	.9503	.9012	.5079	.4424
19	.9012	.9012	.7701	.9012	.9012	.5243	.5243
20	.8192	.6882	.6882	.8684	.7373	.5243	.4915
21	.7373	.6882	.5735	.8192	.7373	.426	.4096
22	.7373	.6718	.5243	.7373	.6554	.3932	
23	.6554	.6554	.4915	.6554	.5735	.3605	
24	.6226	.6554	.6226	.5079	.6554	.4915	.3605
Max	2.1628	1.917	1.8187	1.8023	2.0481	.9012	.9012
Min	.4915	.4915	.4588	.4915	.4915	.2949	.213
Avg	1.1196	1.0411	1.0138	.9003	1.0882	.5547	.5181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134060 / NALNI****Feeder No / Name : 203 / KHAPERKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4096	.3277	.3277	.2458	.2949	.3277	.2622
2	.4096	.3277	.3277	.2622	.2949	.3277	.2949
3	.4096	.4096	.4096	.2785	.2458	.3277	.2949
4	.4588	.4096	.4096	.4096	.2458	.3277	.3277
5	.4915	.4915	.4588	.5243	.2458	.3277	.3277
6	.5735	.4915	.4915	.5407	.2458	.3277	.3605
7	.6226	.5735	.4915	.6226	.2458	.4096	.3932
8	.5735	.5735	.5898	.6882	.213	.4096	.4424
9		.4915	.4096	.4096	.1638	.2458	.213
10	.4915	.4424	.2949		.1638	.1802	.1147
11	.3277	.3113	.2785		.0819	.1147	.0819
12	.3277	.3113	.3605		.0492	.0819	.0655
13		.3113	.3441		.0328	.0819	.0819
14		.3277	.3768		.0328	.0655	.0819
15	.2458	.2949	.2949		.0328	.0819	.0819
16	.2458	.1638	.1475		.0328	.0819	
17	1.9662	1.8515	.5079	.2949	.3277	.0655	
18	2.0481	1.9334	2.0481	.4096	.4096	.1966	.2785
19	1.8023	1.917	1.8679	.3277	.3277	.2949	.2949
20	1.6385	1.4091	1.8023	.3277	.3277	.1966	.2458
21	1.4746	1.4255	1.6221	.3277	.3277	.1638	.1802
22	1.3927	1.3927	1.5565	.2949	.3277	.1638	.1311
23	1.3108	1.3108	1.3927	.2949	.3277	.1311	.1311
24	1.5238	1.2289	1.2452	1.3763	.2949	.3277	
Max	2.0481	1.9334	2.0481	1.3763	.4096	.4096	.4424
Min	.2458	.1638	.1475	.2458	.0328	.0655	.0655
Avg	.8926	.7803	.7523	.4491	.2205	.2191	.2231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO****Feeder No / Name : 201 / Pimpalgaon Ko****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.1867	.1886	.2218	.2614	.168	.1646
2	.2218	.2054	.2075	.2378	.2427	.1867	.1829
3	.2402	.2987	.2263	.2561	.2801	.2218	.1829
4	.3109	.3734	.3174	.2926	.2987	.2378	.2195
5	.439	.4854	.4481	.3658	.4108	.2402	.2743
6	.6219	.4668	.5359	.4525	.5228	.2772	.3292
7	.6036	.4108	.6468	.4706	.5729	.2926	.362
8	.6036	.5601	.5729	.4163	.5175	.3326	.3439
9	.2743	.3734	.3174	.3658	.3921	.4108	.4755
10	.4973	.3391	.2347	.2543	.0848	.2427	
11	.4862	.4096	.2818	.0678	.0566		.1829
12	.5533	.426	.4096	.0509	.0754		.1294
13	.5138	.5138		.0509	.0566	.1294	.0934
14	.4527	.4807		.0509	.0943	.1294	.0934
15	.4239	.4588		.0678	.0934	.1109	.1109
16	.39	.4424		.0678	.0754	.1294	.1294
17	.3391	.3441		.0848	.1307	.2012	.2772
18	.3174	.3696		.4108	.3511	.3475	.543
19	.4854	.499		.4435	.462	.3841	.4706
20	.3361	.3174	.2012	.3174	.3547	.3658	.4344
21	.2801	.2801	.2561	.3361	.2987	.3292	.3582
22	.2241	.2241	.2561	.2241	.3174	.3658	.3439
23	.2054	.2054	.2378	.2427	.2987	.3292	.3258
24	.2033	.2054	.1867	.2195	.2241	.2772	.3109
Max	.6219	.5601	.6468	.4706	.5729	.4108	.543
Min	.2033	.1867	.1867	.0509	.0566	.1109	.0934
Avg	.3844	.3698	.3250	.2487	.2697	.2595	.2756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134064 / 33 kv Pimpalgaon KO****Feeder No / Name : 203 / Vazirkheda****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.3561	.3018	.2683	.1187	.2801	.3109
2	.5898	.39	.4024	.4191	.1187	.2987	.3292
3	.7865	.4748	.4973	.4973	.1526	.3142	.3841
4	.8848	.6036	.6133	.6226	.2035	.3475	.4755
5	1.0526	.8383	.9667	.6964	.2543	.5228	.6036
6	1.2308	1.3603	1.278	.8421	.2543	.6767	.8596
7	1.7328	1.5384	1.6356	.8907	.2713	.9231	.9511
8	1.7004	1.2431	1.5708	.7125	.2883	.8316	.823
9	.7316	.7207	.7207	.8059	.7023	.7865	.695
10	.4755	.4481	.543	.5041	.4108		
11	.3174	.3921	.362	.2427	.2427		.0924
12	.1867	.2218	.3439	.1867	.2054		.1187
13	.168	.2587	.2561		.1886		.0686
14	.1698	.2772	.3475		.168	.0739	.0857
15	.1509	.2772			.1886	.1109	.1029
16	.2054	.2987		.168	.2241	.1109	.1372
17	.3734	.462	.2957	.2801	.3734	.2012	.2058
18	.8316	.7499	.6805	.7207	.5975	.7133	.691
19	.924	.924	.7442	.7865	.7207	.7682	.6089
20	.6838	.6584	.6201	.6099	.499	.5121	.5014
21	.5729	.6099	.4607	.4108	.4481	.3841	.394
22	.3547	.3881	.3801	.3174	.3174	.3109	.2896
23	.3361	.3547	.3077	.2801	.2987	.2926	.2534
24	.3475	.3361	.3361	.2926	.2614	.2987	.3109
Max	1.7328	1.5384	1.6356	.8907	.7207	.9231	.9511
Min	.1509	.2218	.2561	.168	.1187	.0739	.0686
Avg	.6384	.5909	.6211	.5026	.3129	.4379	.4040

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134065 / MALKHEDA****Feeder No / Name : 201 / AVANA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7682	.5853	.679	.9335	.7059	1.1128	.9431
2	.8869	.7316	.6602	1.1203	.8869	1.1128	.9431
3	.9671	1.0679	.7167	1.2696	1.1403	1.3203	1.0374
4	1.2357	1.086	.7545	1.4563	1.2536	1.4146	1.226
5	1.3969	1.3032	.8676	1.5546	1.5939	1.4712	1.3203
6	1.5581	1.6289	.8676	1.7924	2.1132		1.4146
7	2.1491	2.4434	1.5089	2.19	2.3819		1.4712
8	2.2028	2.1719	2.0559	2.0485	2.2565		
9	1.3121	1.2637	1.226	.9431	1.3121	1.4632	1.1317
10	.7545	.8865	1.0374	.8686	1.2071	.1886	1.4632
11	.6036	.7545	.679	.5552	.7922	.7922	1.2986
12	.5093	.5847	.5847	.5175	.7733	1.4335	
13	.4527	.4904	.5281	.4805	.6036	1.3014	1.262
14	.4527	.4904	.415	.5359	.5281	1.3352	.9877
15	.5093	.4904	.5281	.5175	.5281	1.3169	1.0974
16	.5658	.6036	.6224	.6283	.6036	1.1523	.9511
17	.8488	.9808	.9431		1.1317	.9808	1.4146
18	1.4712	1.226	1.4146	1.46	1.4712	1.3203	1.4901
19	1.4449	1.4335	1.4901	1.46	1.4712	1.226	1.4146
20	1.358	1.1317	1.358	1.46	1.4146	1.226	1.1317
21	1.3203	1.1317	1.1883	1.4415	1.3203	1.094	1.1128
22	1.3014	1.0185	1.094	1.3676	1.2826	1.0374	.9431
23	1.2826	.9431	.9997	1.2936	1.226	.9431	.9054
24	1.3306	1.1317	.9619	.9054	1.2752	1.226	.9054
Max	2.2028	2.4434	2.0559	2.19	2.3819	1.4712	1.4901
Min	.4527	.4904	.415	.4805	.5281	.1886	.9054
Avg	1.1118	1.0658	.9659	1.1652	1.2197	1.1652	1.1757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134065 / MALKHEDA****Feeder No / Name : 202 / MUTHAD****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.6979	.6224	.7167	.6283	.6413	.5658
2	.6468	.7167	.5658	.7545	.6653	.6413	.5658
3	.7207	.7167	.7545	.811	.7023	.6602	.6602
4	.7947	.7545	.9431	.8488	.7392	.7167	.7167
5	.8316	.811	.9431	.8299	.8131	.7499	.7545
6	.9055	.8488	.9431	.8676	.8316	.7545	.7922
7	.961	.9242	.9431	.8488	.8686	.7545	.7733
8	.8131	.7733	.8488	.7545	.7577	.7167	.7733
9	2.0953	1.8804	1.8107	1.7375	1.773	.6224	.6413
10	2.0814	2.0485	1.8461		1.7528	.4715	.4715
11	2.1719	1.6827	1.8823	1.5043	1.5384	.2829	.3772
12	2.1948	1.7193	1.829	1.5939	1.7737	.2263	.3018
13	2.0302	1.6278	1.8839	1.6476	1.6832	.2641	.2263
14	2.0668	1.7924	1.6644	1.6118	1.6108	.2263	.2263
15	2.0271	2.0182	1.7741	1.5939	1.6289	.2075	.2263
16	1.828	1.6827	1.701	1.5581	1.5927	.2075	.3206
17	.5281	.4338			.5281	1.4815	1.3717
18	.7733	.5658	.679	.6653	.679	1.7353	1.3032
19	.8865	.8299	.7545	.7577	.6979	1.6975	1.2127
20	.811	.7545	.7167	.7392	.7545	1.6221	1.1222
21	.7545	.7356	.679	.7023	.7356	1.5844	1.086
22	.7356	.7356	.6979	.6653	.6979	1.4146	1.0679
23	.7356	.7167	.679	.6653	.6224	1.3769	1.0317
24	.6653	.7167	.679	.679	.6653	.6413	1.3203
Max	2.1948	2.0485	1.8839	1.7375	1.7737	1.7353	1.3717
Min	.5281	.4338	.5658	.6653	.5281	.2075	.2263
Avg	1.1953	1.0910	1.1235	1.0251	1.0308	.8207	.7462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****BHOKARDHAN (R) S/DN[408] BU 2763****Substation No/ Name :- 134065 / MALKHEDA****Feeder No / Name : 203 / IBRAHIMPUR****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.499	.6602	.5658	.5658	.5914	.3258	.5281
2	.5359	.7167		.679	.6468	.3109	.5281
3	.5544	.7167	.7545	.7545	.7577	.3658	.5658
4	.7392	.9431	.8488	.9054	.8131	.4572	.5658
5	.8131	1.2826	.9431	1.0374	.9055	.5487	.5658
6	.9425	1.4335	.9431	.9808	1.0164	.6219	.547
7	1.2567	1.3957	1.0374	1.0751	1.1273	.6401	.547
8	1.2382	1.358	1.094	1.094	1.0719	.6036	.4715
9	1.0903	1.226	.9808	.9431	1.0349	.7356	.811
10	.5658	.8488	.679	.6099	.7545	.5093	.3584
11	.415	.6036	.3961	.462		.415	.3584
12	.3584	.3961	.3206	.3881		.2829	.3018
13	.2641	.3584	.3206	.2957		.3018	.3395
14	.3395	.415	.2829	.2772		.3395	.2829
15	.3772	.3961	.3206	.2957		.3206	.3395
16	.3206	.3772	.3018	.2957	.1886	.3395	.3584
17	1.6651	1.7164	1.5181		.4525	.5658	.7545
18	1.7737	1.5089	1.2803	1.5927	.543	.9997	1.0562
19	1.2127	1.1317	.9511	1.182	.567	.9431	1.0185
20	.905	.9431	.8779	.8775	.5792	.9054	.8488
21	.8688	.7545	.6722	.7059	.543	.7922	.7922
22	.823	.6979	.5975	.6154	.5068	.7545	.679
23	.724	.6413	.5601	.6154	.3801	.6413	.6224
24	.6154	.5973	.4904	.5281	.5249	.4163	.6413
Max	1.7737	1.7164	1.5181	1.5927	1.1273	.9997	1.0562
Min	.2641	.3584	.2829	.2772	.1886	.2829	.2829
Avg	.7874	.8800	.7277	.7294	.6845	.5474	.5784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134001 / 33KV JAFRABAD

Feeder No / Name : 201 / ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.5087	.4687	.5087	.4641	.5426	.5087
2	.373	.5087	.4999	.0524	.5426	.6299	.5636
3	.4578	.5596	.5312	.6443	.5801	.6554	.663
4	.5087	.5935	.5468	.78	.7621	.8848	.8139
5					.7127		
6					.6882		
7	3.4808	3.8409	3.5208	1.3565			
8	3.8866	3.7161	3.2769	1.4582			
9	3.7609	3.2007	3.094	1.4175			
10		3.2007	3.0483	1.2651			
15					1.1431	1.0822	1.9669
16					1.4327	1.1888	2.0222
17					1.4899	1.2811	1.72
18					1.286	1.2483	1.8435
19	.7373	.7621	.78	.7682	.6154	.5502	.8097
20	.7122	.8288	.7045	.6001	.6562	.5716	.664
21	.5935	.6249	.6226	.5716	.6478	.663	.5639
22	.5935	.5468	.5426	.4578	.4915	.0497	.5256
23	.6001	.5121	.5087	.5087	.4915	.5087	.5596
24	.3155	.5609	3.6866	.5087	.5087	.5935	.5636
Max	3.8866	3.8409	3.6866	1.4582	1.4899	1.2811	2.0222
Min	.3155	.5087	.4687	.0524	.4641	.0497	.5087
Avg	1.2584	1.4260	1.5594	.7784	.7820	.7464	.9849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134001 / 33KV JAFRABAD****Feeder No / Name : 202 / JANEFAL****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6299	.5426	.5935	.5801	.5304	.4973	.5967
2	.6962	.6443	.6104	.663	.663	.5801	.7127
3	.7956	.9156	.8139	.7459	.7459	.663	.7956
4	.8951	1.0174	.9835	.9614	.8619		.8619
5					.9116		
7					2.2045	2.536	2.5857
8					2.3537	3.0994	2.7018
9					2.2542	2.3205	2.3868
10					1.9725	2.0885	2.3339
15	2.6852	2.4863		2.4366			
16	2.8178	2.5194	2.3703	2.7183			
17	2.4863	2.4366	2.4863	2.4531			
18	2.2211	.8619	2.1714	2.1879			
19	.9448	.8619	.7625	.8288	.8453	.7956	1.0111
20	.8288	.7956	.7956	.7956	.7956	.8288	.7625
21	.7127	.7127	.663	.7625	.7625	.7956	.7459
22	.5765	.5935	.5967	.5801	.5636	.5967	.5801
23	.5426	.5426	.5801	.547	.5138	.5182	.547
24	.5765		.5935	.5967	.547	.4973	.5053
Max	2.8178	2.5194	2.4863	2.7183	2.3537	3.0994	2.7018
Min	.5426	.5426	.5801	.547	.5138	.4973	.5053
Avg	1.2435	1.1485	1.0785	1.2041	1.1017	1.2167	1.2234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134001 / 33KV JAFRABAD****Feeder No / Name : 203 / BHARAJ****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0934	.056	.0995	.0663	.0829	.0332
2	.0377	.056	.056	.0829	.0663	.0829	.0663
3	.0377	.0377	.0373	.0995	.0663	.0663	.0497
4	.0566	.0377	.0373	.0995	.0497	.0663	.0332
5	.0566	.0377	.0189	.0663		.0663	.0497
6	.0566	.0377	.0189	.0332	.0332	.0663	.0497
7	.0754	.0566	.0377	.0497	.0332	.0829	.0995
8	.0943	.112	.0747	.0663	.0332	.0829	.0829
9	.0995	.0829	.1326	.1658	.0663	.1658	.116
10	.0995	.0829	.1492	.1658	.0663	.2155	.116
11	.0829	.0829	.1658	.116	.1658	.4144	.1326
12	.2267	.0829	.116	.1823	.2321		.2652
13	.2321	.0829	.2321	.1823	.2486	.2321	.2486
14		.0829	.1823	.1326	.0497	.0995	.1658
15	.2012	.0829	.3315	.1989	.1524	.2652	.1658
16	.2347	.0663	.3812	.1492	.1829	.1989	.0829
17	.2486	.1492	.3647	.3018	.2321	.1326	.1677
18	.1658	.1326	.0332	.2591	.0332	.0663	.0503
19	.0829	.1326	.1823	.1677	.0829	.081	.0829
20	.1492	.1492	.1989	.1966	.1492	.1326	.116
21	.1492	.1658	.1658	.1658	.1326	.0995	.0995
22	.112	.168	.1823	.1823	.1989	.116	.0829
23	.1886	.0747	.0995	.1326	.1823	.0995	.0829
24	.056	.132	.0747	.0995	.0332	.1658	.0829
Max	.2486	.168	.3812	.3018	.2486	.4144	.2652
Min	.0377	.0377	.0189	.0332	.0332	.0663	.0332
Avg	.1218	.0925	.1387	.1415	.1112	.1340	.1051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134001 / 33KV JAFRABAD****Feeder No / Name : 204 / ASAI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0719	1.9334	1.7204	1.5249	.6299	.4973	
2	2.1548	1.8351	1.7368	1.5746	.663	.5801	
3	2.1879	1.8023	1.8842	1.6575	.7459	.7459	
4	2.1216	1.7204	1.8023	1.989	.8619	.8453	
5	2.0056	1.5746	1.8351	1.9559	.9614		
6	1.6741	1.6575	1.7695	1.9227			
11					1.989	1.9393	1.9393
12					1.873	2.0222	1.8896
13					1.7238	1.9062	1.7404
14						1.5746	1.7404
19					.7956		.8785
20	.7625	.7956	.7293	.7956	.779		.8785
21	.779	.7625	.5801	.7625	.7459		.7956
22	.703	.7122	.6299	.6299	.6796		.6464
23	.6274	.6783	.5967	.5967	.6464		.6299
24	.7186	.6104	.6783	.5967	.5636	.6464	
Max	2.1879	1.9334	1.8842	1.989	1.989	2.0222	1.9393
Min	.6274	.6104	.5801	.5967	.5636	.4973	.6299
Avg	1.4369	1.2802	1.2693	1.2733	.9756	1.1953	1.2376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134001 / 33KV JAFRABAD****Feeder No / Name : 205 / TEMBHURNI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3395	.3395		1.1812	1.1431	1.1431
2	.3395	.3584	.3395	.4763	1.2384	1.2384	1.2384
3	.3395	.3772	.3772	.6668	1.2955	1.2384	1.3336
4	.3772	.3772	.3772		1.3336	1.2955	1.3908
5					1.4289	1.3336	1.3336
6					1.4098	1.3717	
11		1.989		1.8233			
12	1.8442	2.3205	1.757	1.9062			
13			1.8233	2.0553			
14	1.8442	2.4863	1.8233	1.9559			
19	.6668	.663	.8764	.8048	.6796	.6706	.7293
20	.5716	.5801	.8764	.6371	.6874	.7042	.4973
21	.4763	.4973	.6668	.6036	.4973	.724	.4694
22	.3772	.4715	.4954	.381	.5716	.3812	.4382
23	.3772	.4715	.4572	.3239	.381	.381	.381
24	.2829	.3395	.3772	.4763	.3048	.4001	.4572
Max	1.8442	2.4863	1.8233	2.0553	1.4289	1.3717	1.3908
Min	.2829	.3395	.3395	.3239	.3048	.381	.381
Avg	.6514	.867	.8143	1.0092	.9174	.9068	.8556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134001 / 33KV JAFRABAD****Feeder No / Name : 206 / JAFRABAD****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.811	.7655	.7842	.8029	.9709	.7842	.8962
2	.7842	.7468	.8589	.8402	1.2136	.8589	
3	.7468	.8402	1.0082	.9335	1.307	.9335	
4	.9335	.9709	1.2323	1.0456	1.5123	.9896	1.0642
5	1.4563	1.3443	1.4563	1.4003	1.6804	1.587	1.7737
6	2.0538	2.0538	2.1285	1.9044	1.9231	2.0911	2.0538
11	2.2405	1.9753	2.5972	2.3777	1.7558	1.5181	1.8858
12	2.0119	1.8107		1.6827	1.5181	1.5546	1.6057
13	1.7556	1.6278		1.4632	1.5546	1.4083	1.4377
14	1.4632	1.4815	1.6095	1.3535	1.4266	1.1706	1.2323
15			1.2696		1.3169	.9511	1.1203
16					1.2071	1.1706	1.307
17			.1494		1.531	1.39	1.6804
18	1.4937				1.7551	1.7558	1.7924
19	2.0725	1.9753	2.0538	1.7604	1.587	1.6095	1.6804
20	1.6804	1.8107	1.6991	1.5684	1.3491	1.3169	1.3817
21	1.4003	1.3535	1.4937	1.531	1.2136	1.2696	1.307
22	1.1203	1.2136	.112	1.1203	.9896	1.0082	1.0269
23	.8962	.9955	.9149	.9149	.8589	.8775	.9149
24	.8589	.8215	.8589	.8029	.7842	.7468	.7842
Max	2.2405	2.0538	2.5972	2.3777	1.9231	2.0911	2.0538
Min	.7468	.7468	.112	.8029	.7842	.7468	.7842
Avg	1.3988	1.3617	1.2642	1.3439	1.3727	1.2496	1.3858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 201 / TEMBHURNI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.4858	.4858	.6097	.5792	.7125
2	.6097	.6097	.5182	.5344	.5716	.6335	.9335
3	.6859	.6859	.583	.5668	.5716	.7602	1.0479
4	.7621	.7621	.6478	.6316	.6668	.7964	1.105
5	1.0098	.7621	.7287	.7611	.8573	.9231	1.1431
6	1.1431	1.2193	.8097	.8097	.9907	.9774	1.1812
7	1.4289	1.3336	.8907	.9231	1.105	1.1403	1.2193
8	1.4861	1.4289	.8097	.8907	1.0479	.9955	1.1622
9	1.2003	.9069	.6154	.6802	.7621	.4049	.8002
10	.9907	.7287		.7621	.583	.502	.5533
11	.7621	.6478		.6287	.4858		.57
12	.6478			.5716			.4862
13	.6097			.4763	.4534		.4527
14	.5716	.6154		.4191	.4527	.4372	.4862
15	.5335	.5992		.4001	.4049	.4268	.4973
16	.4954	.6316		.4763	.3887	.4115	.5596
17	.5335			.8573	.6964	.5487	.7545
18	.4954	.583		.8573	.7611	.6401	.9431
19	.4763	.5668	.7773	.7621	1.0098	.7011	.9431
20	.5335	.6316	.7611	.724	.905	.7287	.7377
21	.5335	.6478	.5668	.6668	.6697	.6964	.6203
22	.4763	.5668	.4858	.6097	.6335	.664	.5087
23	.4763	.4858	.3725	.5716	.5792	.6478	.4287
24	.4191	.4954	.3725	.3725	.5716	.543	.6154
Max	1.4861	1.4289	.8907	.9231	1.105	1.1403	1.2193
Min	.4191	.4858	.3725	.3725	.3887	.4049	.4287
Avg	.7272	.7371	.6283	.6433	.6860	.6742	.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 202 / AKOLADEO****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3908	1.1431	1.0364	1.0936	1.4289	.3887	.6718
2	1.5813	1.1431	1.1012	1.1248	1.6766	.4534	.6802
3	2.0957	1.4289	1.2793	1.2955	1.7147	.5668	.7287
4	1.9052	1.5813	1.643	1.2967	1.7147	.6478	.7773
5	2.0957	1.9052	2.0891	1.3927	1.6766	.7287	.8097
6	2.4768	1.9052	2.2672	1.4575	1.9052	.8097	.9069
7	2.3815	2.0957	2.5101	1.5708	2.21	.9878	.9393
8	2.3815	1.8671	2.3967	1.587	2.2291	.9231	.9069
9	.4763	.4049	.7287	.5312	.5335	1.0364	1.4575
10		.3239		.5716	.4382	1.4251	1.6518
11	.4191	.3239		.3239	.3563		1.7764
12	.381			.362	.3239	1.7166	1.9433
13	.381			.381	.3239	1.668	1.9271
14	.3429			.4191	.2915	1.4937	1.9757
15	.4382	.3725		.4191	.2915	1.4784	1.9919
16	.4763	.421		.7621		1.387	1.9757
17	.5335	.4534		.7049		.2439	.4287
18	.5716	.8097		.7621	.8507	.5182	.7202
19	.6097	.7287	.7449	.6668	.9145	.5944	.6001
20	.5144	.6154	.5344	.6097	.5992	.5668	.4458
21	.5716	.4696	.4843	.5716	.502	.4858	.3772
22	.5335	.4049	.4049	.5335	.5068	.4534	.3429
23	.4763	.3887	.3725	.4763	.4525	.4049	.3086
24	.4763	.4191	.3725	.3401	.4572	.3982	.3563
Max	2.4768	2.0957	2.5101	1.587	2.2291	1.7166	1.9919
Min	.3429	.3239	.3725	.3239	.2915	.2439	.3086
Avg	1.0222	.9145	1.1977	.8022	.9726	.8425	1.0292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 203 / PAPAL****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.4289	1.2146	1.1984	1.829	.2896	.6859
2	1.4289	1.5813	1.2955	1.3123	1.9052	.2896	.6097
3	1.6956	1.9052	1.4737	1.4899	2.0957	.3258	.5335
4	1.9052	1.9052	1.6032	1.6194	2.6673	.3258	.5716
5	2.0957	2.21	1.7814	1.7652	2.7625	.3258	.5716
6	2.2862	2.4768	2.0081	1.9433	3.0483	.362	.724
7	2.3243	2.4387	2.0729	2.0405	3.0102	.362	.9145
8	2.2862	2.4768	2.1052	2.0891	2.7625	.3982	.7621
9	.3048	.4049	.4049	.3887	.6668	1.4842	2.8578
10	.2858	.2591	.3563	.4763	.5716	2.1247	2.5101
11	.3429	.2429	.3239	.4763	.4049	2.2672	2.3482
12	.3048			.4191	.3239	2.4291	2.2672
13	.3429			.381	.2915	2.4777	1.587
14	.2858	.2429		.381	.2915	2.5911	
15	.3048			.4191	.2915	2.5301	
16	.3429	.2429		.4763	.2896	2.5911	1.5746
17	.362	.3239		.5335	.362	1.2955	.5487
18	.5335	.4534		.6668	.543	.6097	.823
19	.5716	.6478	.7125	.5716	.5601	.7164	.6241
20	.5144	.5668	.6478	.5335	.4525	.7449	.631
21	.4763	.3563	.6316	.5335	.3982	.7287	.5258
22	.5335	.3353	.5992	.4763	.362	.6718	.4207
23	.4954	.2915	.5668	.4191	.3258	.6478	.3155
24	.3048	.4191	3.4675		.381	.2896	.6097
Max	2.3243	2.4768	3.4675	2.0891	3.0483	2.5911	2.8578
Min	.2858	.2429	.3239	.381	.2896	.2896	.3155
Avg	.9026	1.0100	1.2509	.8961	1.1082	1.1199	1.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 204 / BHATODI FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5335	.4049	.6154	.5716	.6335	.5182
2		.5335	.4372	.6478	.6097	.6878	.5344
3		.5716	.4858	.6964	.6859	.7602	.5668
4		.5716	.5506	.8097	.8002	.7773	.6316
5		.6668	.6154	.8421	.9526	.9069	.7287
6		.8573	.6478	.9555	.9526	1.085	.8097
7		.9907		1.0059	1.0479	1.1041	.8259
8		.9145	.4858	.7907	1.105	.9717	.7449
9	2.0957	2.4615	2.2024	1.9528	2.8578	.7773	.6371
10	2.553	2.3967	2.2348	2.0957	2.8578	.502	.4359
11	2.8578	2.4291	2.4129	.362	2.3967	.3725	.3353
12	2.8006			2.3815	2.3482	.3077	.3856
13	2.5149			2.9531	2.2348	.2753	.3018
14	2.4768	2.3482		3.0483	2.2348	.2753	
15	2.0957	2.3158		2.8197	2.2186	.2743	
16	2.3434	2.3805		3.0483	2.0729	.3506	.2374
17	.6097	.6478		.6097	.583	2.251	1.0978
18	.9145	.9717		.7621	.8421	2.4291	1.0562
19	.8573	.8097	.8583	.8573	.8145	2.1052	1.0227
20	.8383	.7287	.7125	.7621	.724	2.0891	.9282
21	.7621	.6316	.6249	.7621	.6697	2.0567	.8453
22	.7621	.5668	.6802	.6859	.6154	2.0243	.8288
23	.6097	.5506	.6405	.6097	.5973	2.0081	.8215
24	.5335	.5716	.5668	.6562	.5716	.5792	1.9919
Max	2.8578	2.4615	2.4129	3.0483	2.8578	2.4291	1.9919
Min	.5335	.5335	.4049	.362	.5716	.2743	.2374
Avg	1.6016	1.1568	.9101	1.2804	1.3069	1.0668	.7403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 205 / AMBEGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.2429	.2429	.285	.2477	.2353	.3048
2	.4191	.2591	.2591	.2515	.2477	.2353	.2858
3	.4763	.3239	.2915	.2105	.2286	.2534	.2477
4	.5716	.3239	.3239	.1619	.2858	.2534	.2858
5	.6097	.3563	.3563	.3563	.3048	.2534	.381
6	.7621	.421	.3725	.4049	.381	.2715	.4191
7	.8002	.4049	.3887	.4372	.4954	.2715	.4382
8	.7621	.3887	.4049	.421	.4763	.2896	.4763
9	1.1812	.8097	.8097	.8583	1.0479	.1943	.381
10	1.1431	.8421	.8421	1.0479	1.1431	.1943	.3391
11	1.2384	.8907	.8907	1.0479	.8907	.1943	.2204
12	.9907			.9907	.8097	.2105	.2035
13	1.0479			.9526	.8097	.2343	.2103
14	.9526	.9393		1.2574	.8907	.2267	.1928
15	.9526	.9717		1.1431	.8907	.2187	.208
16	.8764	.8097		1.2574	.905	.2105	.2229
17	.1143	.1296		.4191	.3258	1.1336	1.3413
18	.4763	.2429		.381	.3982	1.2146	1.5089
19	.4763	.3239	.3077	.4191	.4572	1.247	1.1736
20	.4382	.2915	.2753	.381	.362	1.2631	1.0059
21	.4382	.2753	.2343	.3048	.3258	1.2955	.6371
22	.381	.2753	.218	.2858	.2896	1.3279	.5533
23	.381	.2429	.2054	.3048	.2715	1.2793	.5087
24	.2858	.2858	2.0687	.168	.3429	.2896	
Max	1.2384	.9717	2.0687	1.2574	1.1431	1.3279	1.5089
Min	.1143	.1296	.2054	.1619	.2286	.1943	.1928
Avg	.6771	.4569	.4995	.5728	.5345	.5332	.5020

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134021 / 33KV TEMBHURNI****Feeder No / Name : 206 / DAWARGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8573	.6802	.7935	.8573	1.3575	2.0957
2	.9526	.9526	.7773	.9069	.8192	1.5384	2.6673
3	.9907	.9907	.8259	.9717	1.1431	1.7556	2.6673
4	1.2574	1.1431	.9231	1.0526	1.1812	1.9004	2.8959
5	1.4289	1.2384	1.0364	1.1336	1.3336	1.9909	3.0483
6	1.5242	1.4289	1.1336	1.2631	1.3336	2.3167	3.1626
7	1.6766	1.4861	1.2631	1.2955	1.5242	2.5339	3.3341
8	1.6194	1.4861	1.0526	1.166	1.4289	2.1719	3.4294
9	.8573	.8097	.8097	1.0688	1.0479	.4534	1.2574
10	.7621	.7449		1.1431	.9145	.4858	1.1401
11	.6859	.7611		.8573	.6154	.502	.8551
12	.4191			.7621	.5668	.5668	
13	.4763			.8002	.4534	.6478	
14		.6154		.8192	.4858	.7611	.8048
15		.4858		.7621	.6154	.7449	.7628
16		.4049		.9145	.6335	.6316	.703
17	3.1817			3.7151	2.8416	.664	.7537
18	3.3913	3.1579		3.2198	3.1579	.703	1.286
19	3.3341	3.2388	3.2065	3.1626	3.7151	.7773	1.1831
20	3.0483	2.915	3.3532	2.6673	3.0769	.7125	.8063
21	3.3341	2.5911	3.1741	2.0957	2.8959	.6562	.5784
22	3.0483	2.5101	2.7206	1.6766	2.1719	.5937	.5258
23	2.9531	2.4291	2.4291	1.4289	1.5384	.5937	.4382
24	3.0483	2.7625	3.4294	2.332	1.1431	1.3575	.5668
Max	3.3913	3.2388	3.4294	3.7151	3.7151	2.5339	3.4294
Min	.4191	.4049	.6802	.7621	.4534	.4534	.4382
Avg	1.8544	1.5719	1.7877	1.5003	1.4789	1.1007	1.5892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 201 / WARUD****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0179	.0189	.0189	.0179	.0189
2	.0189	.0189	.0179	.0189	.0189	.0179	.0189
3	.0189	.0189	.0183	.0189	.0189	.0183	.0189
4	.0189	.0189	.0183	.0189	.0189	.0179	.0189
5	.0189	.0189	.0183	.0189	.0189	.0179	.0189
6	.0377	.0189	.0183	.0189	.0189	.0179	.0189
7	.0377	.0189	.0183	.0189	.0189	.0183	.0189
8	.0377	.0189	.0183	.0189	.0189	.0366	.0189
9	.112	.0187	.0732	.0934	.0189	.0358	.0189
10	.1132	.0187	.056	.0943	.0179	.0716	.0189
11	.0566	.1075	.0934	.0754	.0716	.0377	.0189
12	.0377	.0934	.056	.1132	.0537	.1307	.0189
13	.0377	.0747	.0747	.1132	.0358	.1294	.0189
14	.0566	.0716	.112	.132	.0358	.1294	.0189
15	.0566	.0537	.0747	.0754	.1097	.0924	.0189
16	.0566	.0895	.1307	.0754	.0716	.0924	.0189
17	.0566	.0716	.0747	.0943	.0732	.0924	.0189
18	.0377	.1097	.168	.1132	.0716	.0739	.0189
19	.0377	.0895	.0189	.0377	.0187	.0189	.0189
20	.0189	.0358	.0189	.0189	.0187	.0189	.0189
21	.0189	.0179	.0189	.0189	.0187	.0189	.0189
22	.0189	.0179	.0189	.0189	.0179	.0189	.0189
23		.0179	.0189	.0189	.0187	.0189	.0189
24	.0189	.0189	.0183	.0189	.0189	.0183	.0189
Max	.1132	.1097	.168	.132	.1097	.1307	.0189
Min	.0189	.0179	.0179	.0189	.0179	.0179	.0189
Avg	.0410	.0441	.0488	.0526	.0343	.0484	.0189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 202 / ADHA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7404	1.5242	1.97	1.6804	1.0059	1.1641	1.3717
2	1.8023	1.5242	1.97	1.8004	1.0898	1.2178	1.39
3	1.9006	1.6766	2.0595	1.9281	1.1401	1.2536	1.4083
4	2.0165	1.829	2.1132	1.9662	1.1736	1.2894	1.4266
5	2.2138	1.829	2.1491	2.2672	1.2574	1.379	1.4266
6	2.3403	1.9509	2.5072	2.251			
7	2.5777	2.1033	2.955	2.2348			
8	2.4194	2.21	2.6863	2.1538			
10					2.6326	2.2929	1.8343
11					2.9797	2.372	2.0399
12					2.8921	2.3403	2.1822
13					2.8654	2.2771	2.0873
14					2.6863	2.2297	1.9925
15	.4207	.4835		.5087	2.2923	2.0567	1.8623
16	.6516	.7164		.6783	2.0595	1.8244	1.4746
17	.8383	.9816	.8686	.9221	1.8088	1.7604	1.4255
18	1.1736	1.2536	1.4083	1.291	.8954	1.2254	1.0059
19	1.4419	1.4327	1.1523	1.2071	1.1283	1.262	1.2239
20	1.3413	1.4327	1.1157	1.1401	1.2894	1.262	1.1797
21	1.3077	1.2894	1.0974	1.0562	1.4327	1.3717	1.1469
22	1.2574	1.2178	1.0608	1.0802	1.3969	1.3535	1.2239
23	1.1736	1.1641	1.0242	1.0159	1.2536	1.3535	1.1904
24	1.1888	1.1401	1.0745	1.0059	1.0159	1.2803	1.3535
Max	2.5777	2.21	2.955	2.2672	2.9797	2.372	2.1822
Min	.4207	.4835	.8686	.5087	.8954	1.1641	1.0059
Avg	1.5448	1.4311	1.7008	1.4549	1.7148	1.6283	1.5123

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 203 / WANKHEDA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922		.7164	.8488	.6706	.8059	.7716
2	.9431	.7545	.8059	.9431	.8383	.8596	.8048
3	1.1203	.8383	.8954	1.0269	1.0059	.8954	.9116
4	1.386	1.0059	1.0745	1.0829	1.1336	.985	1.065
5	1.4784	1.0059	1.2536	1.2136	1.1469	1.0745	1.2289
6					1.2955	1.6118	1.5729
7					1.4575	1.8983	2.3805
8					1.4575	1.9342	2.2024
10	1.4746		1.5775				
11	1.7814	1.7528	1.5775				
12	2.1052	2.1132	1.8004		.394		
13	2.0243	2.1849	1.8442	1.4746	.4298		
14	1.9433	2.2386	1.7147	1.4746	.4835		
15	1.7814	1.97	1.6461	1.4746	.5373		
16	1.6194	1.7909	1.5432	1.4746	.5373	.6036	.503
17	1.3413	1.576	1.3146	1.4746	.7522	.811	.6706
18	1.0059	1.4327	1.3443	1.3108	.985	1.307	1.1736
19	1.0059	1.4327	1.226	1.1469	1.1641	1.3306	
20	.9389	1.3432	1.094	.9831	1.0745	1.0829	1.0059
21	.9054	1.1641	.9054	.8383	.985	.9335	.8383
22	.8383	.985	.8488	.8573	.8954	.8775	.6706
23	.8383	.8596	.7545	.823	.8596	.8402	.6706
24	.7545	.8383	.8059	.7545	.7716	.8059	.8299
Max	2.1052	2.2386	1.8442	1.4746	1.4575	1.9342	2.3805
Min	.7545	.7545	.7164	.7545	.394	.6036	.503
Avg	1.3039	1.4048	1.2371	1.1295	.8988	1.0975	1.0813

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 204 / KOLEGAON****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 205 / KONAD****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
12	2.1033
Max	2.1033
Min	2.1033
Avg	2.1033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134022 / WARUD 33/11 KV S.S****Feeder No / Name : 206 / BHARADKHEDA FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION****Feeder No / Name : 201 / 11 KV PIMPALGAON KAD SINGLE PHASING
FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.5432	1.749	1.7147	.5144	.5144	.567
2	1.7147	1.7147	1.8004	1.8861	.5144	.5487	.6024
3	1.8861	1.8861	1.8861		.5144	.6001	.631
4	1.8861	1.9719	1.9719	2.0233	.5144	.6859	.8322
5	2.0576	2.0576	2.0576	2.0576	.0514	.7716	.8764
6	2.0576	2.1605	2.1605	2.1434	.6859	.7888	.929
7	2.1434	2.2119		2.1434	.6859	.7716	.929
8	2.0576	2.2977	2.3148	2.1605	.6859	.7373	.6588
9	2.0576	.5487	.6516	2.0233	.6687	.5316	.5959
10	.2743	.3506	.463	.5144	1.0288	1.4373	1.2003
11	.2401	.3155	.463	.5144	1.286	1.3146	1.3375
12	.2229	.2947	.4801	.3429	1.3717	1.2971	1.406
13	.2058	.2774	.4973		1.3889	1.2971	1.3717
14	.2058	.2601	.5144		1.4232	1.2757	1.286
15	.2572		.5487		1.4403	1.2136	1.3375
16	.2743			.2572	1.3717		1.1145
17	.4801	.4382		.5144	1.3203		
18	.6859	.929		.6859	.6344	.5493	.4973
19	.8573	.8764		.6859	.6173	.6733	
20	.7373	.8413		.6859	.6173	.691	
21	.6859	.7362		.8573	.5658	.6556	
22	.6001	.7087		.8573	.5144	.6201	
23	.6344	.7087		.6859	.4973	.5959	
24	.8573	.6173	.6733		.5144	.5144	.5895
Max	2.1434	2.2977	2.3148	2.1605	1.4403	1.4373	1.406
Min	.2058	.2601	.463	.2572	.0514	.5144	.4973
Avg	1.0259	1.0794	1.2154	1.1976	.8095	.8220	.9312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION****Feeder No / Name : 202 / 11 KV MAHORA FEEDER SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.4287	.823	.7716	.6859	1.2003	.4908
2	.8573	.5144	.823	.4801	.8573	1.286	.5316
3	.8573	.6001	.8573	.8916	1.3717	1.3717	.567
4	.8573	.6859	.7202	.9431	1.7147	1.5432	.7362
5	1.0288	.6859	1.1145	.6744	1.7147	1.5775	.8859
6	1.0288	.7716	1.1317	1.046	1.7147	1.5432	.9816
7	1.0288	.7373	1.1145	1.0631	1.7147	1.5432	1.1517
8	.8573	.6687	1.166	1.1145	1.7147	1.7318	1.0517
9	.6859	.6687	1.2003	1.0288	.6001	.5144	.5548
10	1.9719	1.893	1.286	1.3717		.5609	.4973
11	2.1776	2.0157	1.406	1.7147	.4287		.4801
12	2.0576	1.9281	1.4403	2.0576	.5144		.3772
13	1.9719	1.8054		2.0576	.5144		.3258
14	1.7318		1.5089	2.0576	.5144	.4334	.4115
15	1.7147	1.7703	1.4918	2.0576	.5144	.3856	.4973
16	1.6975	1.5775		1.8861	.6687	.3506	.5658
17	1.6632			1.8861	.6859	.4557	.6344
18	.6001	.7537		1.0288	.8402	.7087	.6344
19	.6859	1.1393		1.0288	.4973	.8413	
20	.6687	1.2269		1.2003	.6001	.8589	
21	.6859	1.0692		1.2003	.5144	.7442	
22	.6687	.9922		1.0288	.3086	.6135	
23	.6344	.8859		.8573	.2743	.6024	
24	.8573	.6516	.8954		.6859	.2743	.6024
Max	2.1776	2.0157	1.5089	2.0576	1.7147	1.7318	1.1517
Min	.6001	.4287	.7202	.4801	.2743	.2743	.3258
Avg	1.1603	1.0668	1.1319	1.2803	.8544	.9115	.6304

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION****Feeder No / Name : 203 / 11 KV WADALA FEEDER SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.7147	1.7661	1.8861	.5144	.5144	.4075
2	1.2003	1.9719	1.8519		.6859	.6001	.4207
3	1.7147	2.0576	1.8004		.6859	.6859	.4382
4	1.7147	2.2291	1.9204	1.9719	.6859	.7716	.7011
5	1.7147	2.3148	1.9719		.6859	.8573	.929
6	2.0576	2.4006	2.2291		.6859	.9259	1.1517
7	2.572	2.5034	2.4348	2.0576	.6859	.9431	1.0454
8	2.2291	2.3491	2.5034	2.0748	.8573	.8745	.8413
9	2.1434		.6516	.6001	.8573	.6516	.5609
10	.4287	.567	.5144	.5144	1.1488	1.701	1.3375
11	.3429	.5316	.5316	.4287	1.4575	1.7718	1.4403
12	.3258	.4908	.5487	.4287	1.7147	1.8054	1.4232
13	.3086	.4207	.5487	.3429	2.0919	1.7528	1.4575
14	.2915	.4031	.5316	.3429	2.0576	1.6991	1.2003
15	.2743	.4252	.5144	.3429	2.0062	1.5775	1.2689
16	.3086	.4607		.3429	1.989	1.4373	1.3889
17	.3258	.5316		.3429	1.5432		1.3375
18	.4287	.6661		.5144	.6516	.4908	1.0631
19	.9431	.7888		.5144	.6859	.5258	
20	.7888	.7362		.5144	.5487	.6135	
21	.6859	.631		.6859	.5144	.567	
22	.6173	.6268		.6859	.4115	.4607	
23	.583	.6089		.5144	.3772	.4382	
24	.5144	.5658	2.9492		.4287	.3772	.4207
Max	2.572	2.5034	2.9492	2.0748	2.0919	1.8054	1.4575
Min	.2743	.4031	.5144	.3429	.3772	.3772	.4075
Avg	.9738	1.1302	1.4543	.7951	.9988	.9584	.9912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION****Feeder No / Name : 204 / 11KV MHASARUL FEEDER SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3429	.5487	.5144	.6859	1.2003	.6201
2	.5144	.3944	.5316	.6516	.8573	1.286	.6379
3	.5144	.4458	.5144	.3544	1.2003	1.3717	.6379
4	.5144	.463	.5316		1.2003	1.4575	.6556
5	.5144	.4801	.5144	.5144	1.2003	1.4746	.7011
6	.6859	.4801	.5316	.7716	1.2003	1.4575	.567
7	.6859	.4801	.6344	.823	1.2003	1.4403	.9214
8	.5144	.3772	.6001	.9088	1.286	1.4746	.8842
9	.5144	.2401	.4801	.5487	.5144	.4801	.5083
10	1.3717		1.2003	.8573	.3601	.3506	.3772
11	1.3889		1.286	1.3717	.3258	.2658	.3086
12	1.3889		1.2689	1.7147	.2743	.2804	.2743
13	1.3717			1.7147	.2401	.2658	.2401
14	1.3375		1.3032	1.5432	.2401		.3258
15	1.3203	1.6301	1.3032	1.3717	.2743		.3601
16	1.286	2.0111		1.2003	.3429		.3429
17	1.1145	1.4373		1.0288	.4458	.443	.3944
18	.5316	.6661		.6859	.6344	.5258	.3944
19	.6859	.7537		.6859	.583	.6135	
20	.703	.7362		.6859	.6344	.6661	
21	.5144	.6556		.6859	.6001	.6201	
22	.4973	.6135		.5144	.4458	.5784	
23	.4801	.6516		.5144	.4458	.5609	
24	.5144	.463	.5731		.5144	.4287	.5258
Max	1.3889	2.0111	1.3032	1.7147	1.286	1.4746	.9214
Min	.4801	.2401	.4801	.3544	.2401	.2658	.2401
Avg	.8116	.7012	.7881	.8937	.6544	.8210	.5093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION****Feeder No / Name : 205 / 11KV BELORA FEEDER SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.4458	.4973	.6859	1.3717	.333
2	.5144	.7716	.4801	.5487	.8573	1.5432	.3898
3	.5144	.8573		.6001	1.2003	1.7147	.4382
4	.5144	.9431	.5487		1.7147	1.7318	.5316
5	.6859	1.0288	.6859		1.7147	1.9719	.567
6	.8573	1.0288	.823		1.7147	1.989	.6135
7	.9431	1.0631	.9088		1.7147	2.0233	.6661
8	.8573	.8916	.8745		1.7147	2.0919	.5434
9	.6859	.8573	.6859	.8573	.8573	.5658	.5434
10	1.8176	1.8404	1.5432	.8573	.3944	.3856	.3086
11	1.9033	1.893	1.6289	1.0288	.4115	.3856	.2058
12	1.8861	1.8755	1.7147	1.2003	.4287	.3544	.1715
13	1.9204	1.8404		1.3717	.3772		.1715
14	1.9204	1.893	1.8347	1.5432	.3429		.2572
15	1.9204	1.7878	1.8519	1.5432	.3258		.2915
16	1.9033	1.6476	1.8004	1.5432	.5144	.2804	.4801
17	1.749	1.6651		1.4575	.5487	.333	.4973
18	.7716	.7362		1.4575	.8059	.443	.5316
19	.8916	.7973		.8573	.8402	.5258	
20	.7373	.6661		.8573	.6687	.5847	
21	.6859	.6135		.6859	.6001	.4908	
22	.6001	.5731		.6859	.4801	.4207	
23	.4973	.5014		.6859	.4458	.3856	
24	.5144	.5144	.4656		.6859	.4287	.3506
Max	1.9204	1.893	1.8519	1.5432	1.7147	2.0919	.6661
Min	.4973	.5014	.4458	.4973	.3258	.2804	.1715
Avg	1.0752	1.1238	1.0861	1.0155	.8352	.9534	.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134032 / MAHORA 33/11 KV SUBSTATION

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171		.0171	.0171	.0171	.0181
2	.0171	.0171		.0171	.0171	.0171	.0177
3	.0171				.0171		.0177
4	.0171	.0171			.0171	.0171	.0177
5	.0171	.0171		.0343	.0171	.0171	.0175
6	.0171	.0171		.0171	.0171	.0171	.0177
7	.0171	.0171		.0171	.0171	.0171	.0175
8	.0171	.0343		.0152	.0171	.0171	.0177
9	.0171		.0171	.0171	.0171	.0171	.0177
10	.0171	.0354		.0171	.0171	.0351	.0343
11	.0171	.0358		.0171	.0171	.0351	.0343
12	.0171	.0354		.0171	.0171	.0526	.0514
13	.0171			.0171	.0171	.0537	.0514
14	.0171			.0171	.0171	.0532	.0514
15	.0171	.0532	.0171	.0171	.0171	.0526	.0514
16	.0171	.0351		.0171	.0171	.0526	.0514
17	.0171	.0709			.0171	.0701	.0514
18	.0171	.0532		.0171	.0171	.0532	.0343
19	.0171	.0709		.0171	.0171	.0532	
20	.0171	.0709		.0171	.0171	.0532	
21	.0343	.0709		.0171	.0171	.0532	
22	.0343	.0724		.0171	.0343	.0526	
23	.0171	.0537		.0171	.0343	.0354	
24	.0171	.0171	.0716		.0171	.0514	.0179
Max	.0343	.0724	.0716	.0343	.0343	.0701	.0514
Min	.0171	.0171	.0171	.0152	.0171	.0171	.0175
Avg	.0185	.0406	.0353	.0179	.0185	.0389	.0310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134042 / HIVRAKABLI

Feeder No / Name : 207 / BRAHMAPURI AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)
3		1.7737
4		1.8099
5		1.8461
6		1.9004
7		1.9366
8		1.9728
24	2.6235	
Max	2.6235	1.9728
Min	2.6235	1.7737
Avg	2.6235	1.8733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134042 / HIVRAKABLI****Feeder No / Name : 208 / KALEGAON AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1812		
2		1.2193		
3		1.2574		
4		1.2955		
7		1.3336		
8		1.3527		
10			1.5242	
11			1.7147	
12			1.829	
13			1.8671	.2667
14			1.8099	.2858
15			1.7147	
16			1.6194	.2858
17			1.5623	.2667
24	1.7147			
Max	1.7147	1.3527	1.8671	.2858
Min	1.7147	1.1812	1.5242	.2667
Avg	1.7147	1.2733	1.7052	.2763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 201 / POKHRI - AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.929	1.5432	1.5432		.2315	
2	1.7284	1.8519	1.8519	1.8519		.2315	
3	1.7593	2.0833	2.0833	2.0062		.2315	
4	2.0062	2.1605	2.0833	2.0062		.2315	
5	2.0679	2.2377	2.1296	1.9814		.2315	
6	2.0988	2.1605	2.3148	2.0062		.2315	
7	2.3148	2.3148		1.8519		.2469	
8	2.284	2.4691		2.7778	.0762	.2315	
9					.0762	.2315	
10					.0772		.4572
11							.9145
12						.3395	.9145
13					.1543	.463	.7621
14					.1543	.571	.9145
15					.2315	.5401	.9145
16				.1543		.7099	.9145
17		.0926		.1543	.2315	.6173	
18	.1543	.2006	.1543	.1543	.2315	.1235	.0762
19	.2315	.1698		.1543	.2315		
20	.2315	.1698	.1852	.1543	.2315		.0762
21	.2315	.1852	.1389	.1524	.1852		.0762
22	.2315	.1543	.1389	.1372	.1852		.0762
23	.2315		.1389	.1372	.2315		.0762
24	.1698	.2315	2.572	.1389		.2315	
Max	2.3148	2.4691	2.572	2.7778	.2315	.7099	.9145
Min	.1543	.0926	.1389	.1372	.0762	.1235	.0762
Avg	1.1523	1.2274	1.2779	1.0213	.1767	.3350	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JAFARABAD(R) S/DN[568] BU 5681

Substation No/ Name :- 134047 / 33 KV DONGAON

Feeder No / Name : 203 / NIVDUNGA - AG
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.3125	.0781	.1406	.3125	.3125	
2	.1406	.3125	.0781	.1406	.3125	.3125	
3	.1406	.2343	.1562	.1406	.3125	.3906	
4	.1406	.3125	.0937	.1406	.3125	.703	
5	.1562	.3125	.0781	.1562	.3125	1.0155	
6	.1406	.3125		.1875	.3125	1.3279	
7		.2343		.1562	.3048	1.5623	
8				.1562	.3048	1.6404	
9					.4049	.6249	
10		1.6404	1.781	1.406	1.0936	.6249	
11	2.4996	1.8747	2.8121	2.0309	1.406		
12	2.4996			1.5623			
13	2.4996			.6249	.7811		
14	2.4996	.9374		.6249	1.406		
15	2.4215	2.2653		.7811			.0152
16	2.4996	1.9528		.703	1.5623		.0152
17	2.3434	1.906		.703	1.6404		
18	.2343	.0937		.3125	.703		.0152
19	.3125	.0937	.1406	.3125	.703		
20	.3125	.0937	.3125	.3906	.7811		.0152
21	.3125	.0937	.1406	.3906	.703		.0152
22	.3125	.0937	.1372				.0152
23	.3906	.0937	.1562	.3906			.0152
24	.1562	.3125	.0781	.1562	.3125		
Max	2.4996	2.2653	2.8121	2.0309	1.6404	1.6404	.0152
Min	.1406	.0937	.0781	.1406	.3048	.3125	.0152
Avg	1.0100	.6741	.4648	.5276	.6991	.8515	.0152

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S****Feeder No / Name : 201 / BORAGAON MATH SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.9313	.8589	.7716	1.3969	1.3599	1.3375
2	.8402	.985	.9313	.8573	1.4327	1.5074	1.5261
3	1.0288	1.0387	1.0059	.9088	1.4685	1.5729	1.6804
4		1.0745	1.0498	.9774	1.2894	1.6712	1.8004
5	1.1145	1.1104	1.0974	1.046	1.1641	1.8084	2.0233
6	1.166	1.182	1.1641	1.0974	1.1104	1.9498	2.1091
7	1.2003	1.1641	1.39	1.0288	1.4506	2.2447	2.5377
8	1.0631	1.2178	1.262	.9602	1.576	2.1628	2.0576
9	.9945	1.0029	.9795	.6687			
10	.6173	.9511	.4973	.5373			
15					.3475	.3601	.3224
16	1.6118				.5121	.3601	.3224
17	2.5789	2.3685	1.4746		.7316	.8059	.5731
18	2.6863	2.4966	1.4746	2.5072	1.0242	1.0631	1.0029
19	2.6326	2.1956	1.3546	2.5072	1.0059	.9774	.8954
20	2.1132	1.7695	1.046	2.3282	.823	.8059	.8059
21	1.8267	1.5684	1.0117	1.8267	.6401	.5658	.5552
22	1.576	1.3272	.9088	1.5223	.5121	.5144	.3582
23	1.5223	1.3108	.823	1.4685	.4755	.4801	.3224
24	1.3032	1.4327	1.326	.7373	1.4327	.4481	.4458
Max	2.6863	2.4966	1.4746	2.5072	1.576	2.2447	2.5377
Min	.6173	.9313	.4973	.5373	.3475	.3601	.3224
Avg	1.4823	1.3960	1.0920	1.2795	1.0219	1.1477	1.1487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S****Feeder No / Name : 202 / PASODI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.2536	1.0898	.5658	.3224	.3734	.3086
2	1.0802	1.2894	1.1469	.6516	.3582	.4108	.3429
3	1.3375	1.3253	1.2452	.703	.3761	.4481	.3944
4	1.4918	1.5939	1.3717	.7545	.394	.5175	.463
5	1.5432	1.5223	1.3748	.8059	.4298	.5601	.5316
6	1.5775	1.4327	1.442	.823	.591	.5975	.6001
7	1.6461	1.4327	1.5074	.8402	.394	.4294	
8	1.5604	1.5223	1.5074	.8573	.4298	.4481	
9					1.8625	1.5565	1.5947
10					1.7436	1.7318	1.5432
11					1.6385	1.6461	1.5043
12					1.7101	1.6289	1.4327
13					1.3592	1.5261	1.0924
14	.1075			.1075	1.358	1.3717	1.2894
15	.1612	.1494			1.3435	1.3546	1.2536
16	.2507	.1494		.2149	1.0562	1.166	1.0745
17	.3045	.4294		.394	.2987	.3772	.3582
18	.4835	.5729	.3944	.5194	.4024	.5144	.5552
19	.5194	.5228	.3772	.5014	.4668	.463	.5373
20	.4477	.4435	.3429	.4477	.3734	.4115	.4477
21	.4119	.3605	.3258	.4119	.3547	.3944	.394
22	.3403	.3547	.3086	.3582	.3361	.3772	.3582
23	.3224	.3361	.2915	.3045	.3361	.3258	.3582
24	.3086	.3224	.3361	.2743	.3224	.3174	.3086
Max	1.6461	1.5939	1.5074	.8573	1.8625	1.7318	1.5947
Min	.1075	.1494	.2915	.1075	.2987	.3174	.3086
Avg	.7809	.8341	.8708	.5297	.7607	.7895	.7610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JAFARABAD(R) S/DN[568] BU 5681****Substation No/ Name :- 134067 / BORGAON (M) 33 KV S/S****Feeder No / Name : 203 / KHASAGAON SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	1.1641		.8916	.985	1.1458	1.0802
2	1.0631	1.2178		.9602	1.0208	1.2437	1.166
3	1.1145	1.2536		1.1488	1.0745	1.3169	1.3032
4	1.1831	1.2894		1.2689	1.1999	1.3969	1.406
5	1.2174	1.3432		1.3032	1.2894	1.4842	1.5261
6		1.3611		1.3717	1.4864	1.6095	1.5432
7		1.3611			1.2715	1.4449	
8		1.6118			1.3969	1.3306	
9	2.9321	2.5072		2.3834	1.0924	.9328	1.1317
10	2.7606	2.6216	2.8292	2.2977	.8029	.6001	.8059
11	3.152	2.5446	2.5377	2.7759			
12	2.8654	2.5888	2.9835	2.6863			
13	2.955	2.5606	3.0178	2.7938			
14	3.0087	2.3266	2.572	2.6505			
15	2.955	2.4086	2.6235				
16	.6089	2.2939	2.692	2.4893			
17			1.1831	.985	2.7854	3.0864	2.561
18	1.773		1.5604	1.3969	2.7664		2.364
19					2.4905		2.2207
20					2.5232		2.1491
21				.8059	2.3703	2.8807	1.9879
22	1.1104		.9602	1.0566	2.1216	2.5892	1.8625
23	1.0745		.9088	.985	1.9006	2.1605	1.7909
24	.9774	1.0924		.8745	.9313	1.8023	1.9376
Max	3.152	2.6216	3.0178	2.7938	2.7854	3.0864	2.561
Min	.6089	1.0924	.9088	.8059	.8029	.6001	.8059
Avg	1.8603	1.8557	2.1698	1.6382	1.6394	1.6683	1.6773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 201 / 11 KV RAM MANDIR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3174	.2915	.2915		
2		.3174	.2915	.2915		
3		.3174	.2915	.2915		
4		.4668	.3429	.3772		
5		.6161	.4973	.4801		
6		1.0829	.703	.6859	.7545	.8059
7		1.1203	.9088	.8916	.9259	.9945
8			.9945	1.046	1.0288	1.0802
9						.9088
10						.8059
11						.6516
12						.5658
13						.4801
14						.3944
15						.4801
16						.4801
17	.5487					.5658
18	.7202					
19	.7888					.7888
20	.6859					
24		.7167	.2915	.2915	.2743	.2743
Max	.7888	1.1203	.9945	1.046	1.0288	1.0802
Min	.5487	.3174	.2915	.2915	.2743	.2743
Avg	.6859	.6194	.5125	.5163	.7459	.6626

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 202 / MEDICAL COMPLEX

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481	.4115	.4115		
2		.4481	.4115	.4115		
3		.4481	.4115	.4115		
4		.5601	.4458	.4287		
5		.8029	.7373	.7202		
6			.9431	.9431	1.0288	1.0288
7		1.4563	1.2689	1.1488	1.3546	1.286
8		1.2136		1.1831	1.3717	1.3375
9						.9774
11						.6516
12						.6859
13						.6516
14						.5658
15						.5658
16						.6687
17	.5658					.7888
18	.8573					
19	1.0631					1.046
20	.8573					
24		.823	.4115	.4115	.4115	.4115
Max	1.0631	1.4563	1.2689	1.1831	1.3717	1.3375
Min	.5658	.4481	.4115	.4115	.4115	.4115
Avg	.8359	.7750	.6301	.6744	1.0417	.8204

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 203 / SATELLITE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3547	.3258	.3258		
2		.3547	.3258	.3258		
3		.3734	.3258	.3258		
4		.4108	.3772	.3772		
5		.5041	.4287	.4287		
6		.9335	.6001	.6001	.6001	.6344
7		1.0829	.7545	.7716	.8573	.8916
8				.823	.9431	.9259
10						.6344
11						.6859
12						.5487
13						.4801
14						.4115
15						.4458
16						.4287
17	.5658					.5316
18	.7545					
19	.7373					.7373
20	.6687					
24		.3547	1.7833	.3258	.3086	.3086
Max	.7545	1.0829	1.7833	.823	.9431	.9259
Min	.5658	.3547	.3258	.3258	.3086	.3086
Avg	.6816	.5461	.6152	.4782	.6773	.5896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 205 / MEDICAL EXPRESS
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0171			
2		.0187	.0171			
3		.0187	.0171	.0171		
4		.0187	.0171			
5		.0187	.0171			.0171
6		.0187	.0171	.0171	.0171	
7			.0171	.0171	.0171	.0171
8				.0171	.0171	
9						.0171
11						.0171
12						.0171
13						.0171
14						.0171
15						.0171
16						.0171
17	.0171					.0171
18	.0171					
19	.0171					.0171
20	.0171					
24		.0187	.0171	.0171	.0171	.0171
Max	.0171	.0187	.0171	.0171	.0171	.0171
Min	.0171	.0187	.0171	.0171	.0171	.0171
Avg	.0171	.0187	.0171	.0171	.0171	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 206 / COLLECTOR OFFICE (EXP)
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171		
2			.0171		
3			.0171		
4			.0171		
5			.0171		
6			.0171		
7			.0171		.0171
8			.0171	.0171	.0343
11					.0514
12					.0686
17	.0686				
18	.0514				
19	.0514				.0343
20	.0514				
24		.0373	.0171	.0171	.0171
Max	.0686	.0373	.0171	.0171	.0686
Min	.0514	.0373	.0171	.0171	.0171
Avg	.0557	.0373	.0171	.0171	.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 208 / Railway station Express NON SHEDDABLE EXPRESS HV FEEDERS
feeder Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343			
2			.0343			
3			.0343			
4			.0343			
5			.0343			
6			.0343		.0343	.0514
7			.0514			.0514
8			.0514	.0514	.0514	.0514
9						.0514
10						.0343
11						.0514
12						.0514
13						.0514
14						.0514
15						.0343
16						.0343
17	.0343					.0514
18	.0514					.0514
19	.0514					.0514
20	.0514					
24		.0373	.0514		.0514	.0514
Max	.0514	.0373	.0514	.0514	.0514	.0514
Min	.0343	.0373	.0343	.0514	.0343	.0343
Avg	.0471	.0373	.04	.0514	.0457	.0480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134028 / 488-SUB STATION****Feeder No / Name : 209 / 11 KV SAMRTH NAGAR FEEDER****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3086		
2			.3086	.3086		
3			.3086	.3086		
4			.3086	.3429		
5			.3429	.4115		
6			.4458	.4801	.463	.4973
7			.5487	.5658	.6001	.6001
8			.583	.5487	.6344	.6516
9						.5487
10						.4458
11						.4458
12						.4287
13						.3601
14						.3772
16						.3772
17	.4115					.4458
18	.5487					.5487
19	.6001					.6001
20	.6001					
24		.3547	.3258	.3086	.2915	.3086
Max	.6001	.3547	.583	.5658	.6344	.6516
Min	.4115	.3547	.3086	.3086	.2915	.3086
Avg	.5401	.3547	.3867	.3982	.4973	.4740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134028 / 488-SUB STATION****Feeder No / Name : 210 / 11 KV TV centre New
Feeder KV- 11 / OUTGOING****SHEDDABLE URBAN**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372			
2		.1372			
3		.1372			
4		.1372			
5		.1715			
6		.3258	.3429	.3429	.3429
7		.4287	.4287	.4458	.4115
8		.4287	.4115	.3944	.4287
9					.3944
10					.3258
11					.2229
12					.2229
13					.1715
15					.1715
17	.2058				.2572
18	.3601				.3601
19	.3429				.3429
20	.2401				
24		.1372		.1372	.12
Max	.3601	.4287	.4287	.4458	.4287
Min	.2058	.1372	.3429	.1372	.12
Avg	.2872	.2267	.3944	.3301	.2902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134028 / 488-SUB STATION

Feeder No / Name : 213 / 11 KV YOGESH NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.3429	.3258		
2		.3734	.3429	.3258		
3		.3734	.3429	.3258		.3258
4		.4481	.3772	.3429		
5		.6908	.6001	.5144		
6		.9149	.7716	.7716	.9088	.8916
7		1.2136	1.0288	1.046	1.0288	1.0117
8		1.2136		1.0288	1.0288	1.0117
10						.8059
11						.6344
12						.5144
13						.4458
14						.3429
15						.3601
16						.3944
17	.4458					.5487
18	.7202					
19	.8573					.823
20	.7373					
24		.3734	.3429	.3258	.3429	.3258
Max	.8573	1.2136	1.0288	1.046	1.0288	1.0117
Min	.4458	.3734	.3429	.3258	.3429	.3258
Avg	.6902	.6638	.5187	.5563	.8273	.6026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134030 / Pole Factory Sub-station

Feeder No / Name : 201 / 11KV Industrial, Pole
factory Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.6602	.679	.7922	.7167	.7545	.5281
2	.8676	.6413	.6602	.7545	.6979	.7545	.5281
3	.8676	.6036	.6413	.6979	.6602	.7545	.5281
4	.7922	.5658	.679		.679	.7545	.5658
5	.8299	.6413	.7356		.7167	.7922	.5658
6	.7545	.7356	.7922		.7545	.7922	.6036
7	.7545	.7922	.9054	.8865	.7922	.8299	.6413
8	.8676	.9431	.9808	1.0185	.8299	.7545	.8299
9	1.358	1.0374	1.0374	1.1694	.8299	.7167	1.0562
10	1.4712	1.2071	1.2071	1.2449	1.0185	.7167	1.2449
11	1.3957	1.3203	1.3203	1.2449	1.2071	.6036	1.3203
12	1.358	1.2449	1.2826	1.2071	1.1694	.4527	1.2071
13	1.1694	1.2071	1.094	1.0562	1.0185	.4904	1.1694
14	1.1317	1.1694	1.0562	1.094	1.1317	.5281	
15	1.2071	1.3203	1.2071	1.2071	1.094	.5658	1.3957
16	1.2449	1.0562	1.1317	1.2449	1.1317	.4904	1.4335
17	1.1694	1.0751	1.1317	1.226	1.1317	.5658	1.2449
18	1.226	1.2071	1.0562	1.226	1.2449	.5093	1.226
19	1.2449	1.094	.9619	1.2449	1.2449	.547	1.2449
20	1.0185	.8488	.8865	1.094	.8676	.4715	1.1128
21	.8299	.7545	.8865	.9431	.8865	.4904	.7545
22		.7545	.8676	.7922	.8299	.547	.7922
23		.7167	.8676	.7733	.811		
24	.8676	.7167	.6979	.8299	.7545	.811	.5281
Max	1.4712	1.3203	1.3203	1.2449	1.2449	.8299	1.4335
Min	.7545	.5658	.6413	.6979	.6602	.4527	.5281
Avg	1.0588	.9297	.9486	1.0356	.9258	.6388	.9328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134030 / Pole Factory Sub-station****Feeder No / Name : 202 / 11 KV AGRESAN FEEDER
Feeder KV- 11 / OUTGOING****SHEDDABLE URBAN**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.4715	.3395		.2829	.3326	.3326
2	.3326	.4338	.3018	.3206	.2829	.3326	.3326
3	.3326	.415	.3206	.3395	.3018	.3326	.3326
4	.4066	.4527	.3772	.3584	.3206	.3326	.3326
5	.5544	.5281	.415	.3961	.3584	.3696	.3696
6	.7392	.6036	.4904	.4527	.4338	.4805	.4805
7	.7545	.6602	.5658	.5658	.547	.7023	.6653
8	.8501	.7545	.679		.6979	.7023	.6653
9	.7023	.679	.7733	.6653	.7023	.6653	.679
10	.5544	.4805	.6653	.5914	.6653	.5175	.5544
11	.3696	.4435	.6653	.5544	.5914	.4805	.4904
12	.4435	.4066	.4805	.4805	.4805	.3696	.415
13	.3326	.3326	.4435	.4066	.3696	.3326	.3772
14	.3326	.3326	.3696	.3696	.3696	.2957	
15	.3326	.2957	.3326	.3696	.3696	.3326	.3018
16	.3326	.3326	.3326	.3326	.3326	.2957	.3206
17	.3772	.4251	.4435	.4805	.4251	.3881	.4066
18	.6036	.5544	.5544	.5544	.6468	.499	.5359
19	.7545	.5729	.5729	.7392	.6653	.5544	.5175
20	.7733	.499	.5544	.5914	.6468	.499	.499
21	.5847	.499	.4805	.5544	.499	.4435	.462
22		.4066	.4435	.4435	.4435	.4251	.4435
23		.3696	.3696	.3881	.3881		
24	.3326	.4904	.3584	.3511	.2957	.3326	.2957
Max	.8501	.7545	.7733	.7392	.7023	.7023	.679
Min	.3326	.2957	.3018	.3206	.2829	.2957	.2957
Avg	.5059	.4766	.4721	.4684	.4632	.4355	.4459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 201 / RLY STN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.6722	.823	.7282	.5975	.7095	
2	.5853	.5975	.7316	.7095	.5914	.6908	
3	.5853	.5975	.7316	.6908	.5729	.6722	
4	.8413	.7095	.823	.7842	.5601	.6535	
5	1.0242	.8962		1.0269	.7468	.7282	
6	1.2437	1.1203		1.2136	.9335	1.0117	
7	1.39	1.531		1.4937	1.2696	1.3443	
8	1.6095	1.6804		1.6804	1.643	1.6617	
9	1.4632	1.4632	1.4045	1.5546	1.4632	1.4632	1.4632
10	1.3717	1.4632	1.3817	1.4632	1.2803	1.1888	1.2803
11	1.0974	1.2803	1.363		1.1888	1.0974	1.1888
12	1.0059	1.1888	1.3443	1.386	1.0974	1.0059	1.0059
13	.9145	1.1203	1.1203	1.2012	1.0059		.9145
14	.823	.9335	1.0269	1.0164	.9145		.823
15	.9145	.961		1.0059	.9145		.823
16	1.0059	1.0082	.9709	1.0059	.823		.823
17	1.2136	1.2136	1.086	1.1203	1.0059	1.0059	.9335
18	1.4937	1.4937	1.2803	1.2136	1.1888	1.1888	1.4003
19	1.5708	1.3717	1.386	1.4003	1.2803	1.386	1.3817
20	1.363	1.2803	1.2936	1.307	1.0974		1.3306
21			1.1888	1.2136	1.0059		1.2696
22			1.0974	.9335	.9145		
23	.8048		.8402	.7468	.8029		
24	.7316	.0934	.823	.7468	.6535	.7282	.823
Max	1.6095	1.6804	1.4045	1.6804	1.643	1.6617	1.4632
Min	.5853	.0934	.7316	.6908	.5601	.6535	.823
Avg	1.0795	1.0798	1.0903	1.1149	.9813	1.0335	1.1043

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 202 / BUS STAND

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.3734	.3658	.3734	.2801	.3734	
2	.1867	.1867	.3658	.2801	.2801	.3734	
3	.1867	.1867	.3658	.2801	.2801	.3734	
4	.0934	.1867	.2743	.2801	.2801	.3734	
5	.1867	.1867		.3734	.2801	.2801	
6	.3734	.3734		.3734	.3734	.2801	
7	.3734	.3734		.4668	.3734	.3734	
8	.3734	.4668		.4668	.5601	.4668	
9	.5487	.5487	.4668	.4572	.5487	.4572	.5487
10	.5487	.5487	.4668	.5487	.5487	.5487	.5487
11	.5487	.5487	.4668	.6468	.5487	.5487	.5487
12	.5487	.5487	.3734	.6468	.5487	.5487	.5487
13	.5487	.5601	.362	.6468	.5487		.5487
14	.5487	.4668	.4668	.5544	.4572		.5487
15	.5487	.3734		.5487	.5487		.4572
16	.4572	.3734	.4668	.5487	.5487		.4572
17	.7468	.4668	.543	.6535	.5487	.7316	.5544
18	.9335	1.0269	.7316	.7468	.6401	.9145	1.386
19	1.2012	.9145	.924	.9335	.7316	1.0164	.9335
20	1.1203	.9145	.7392	.5601	.5487		.8402
21			.5487	.5601	.5487		.7468
22			.4572	.4668	.5487		
23	.2801		.3734	.3734	.3734		
24	.2801	.1867	.4572	.3734	.3734	.2801	.4572
Max	1.2012	1.0269	.924	.9335	.7316	1.0164	1.386
Min	.0934	.1867	.2743	.2801	.2801	.2801	.4572
Avg	.4918	.4672	.4850	.5067	.4716	.4962	.6518

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 203 / KADRABAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1867	.2926	.168	.1494	.1494	
2	.2241	.1867	.2926	.1494	.1494	.1494	
3	.1867	.1867	.2743	.1494	.1307	.1494	
4	.2241	.1867	.2743	.1494	.1307	.1494	
5	.3734	.2241		.1867	.1663	.168	
6	.4854	.2614		.2801	.2033	.2241	
7	.4854	.3174		.4481	.3174	.3547	
8	.5228	.3921		.4668	.5041	.3772	
9	.4572	.3658	.4854	.439	.4755	.3841	.439
10	.439	.3658	.4668	.4207	.4572	.3658	.439
11	.3658	.3658	.4668	.4066	.439	.3658	.3841
12	.3658		.4668	.3696	.4024	.3658	.3658
13	.3292	.3734	.3734	.3696	.3658		.3658
14	.3109	.3734	.3734	.3326	.3658		.3475
15	.3292	.3734		.2926	.3658		.3292
16	.3658	.3547	.3174	.3292	.3658		.3109
17	.3921	.3734	.3258	.3734	.5304	.3658	.3361
18	.4668	.4294	.4024	.4481	.6584	.4024	.4481
19	.5175	.4024	.4435	.4854	.6401	.4805	.4108
20	.5041	.3658	.4066	.4481	.5487		.3734
21			.3658	.4294	.5121		.3174
22			.3292	.3734	.4755		
23	.3361		.2054	.2054	.2241		
24	.2241	.2241	.2926	.1867	.168	.168	.2743
Max	.5228	.4294	.4854	.4854	.6584	.4805	.4481
Min	.1867	.1867	.2054	.1494	.1307	.1494	.2743
Avg	.3695	.3155	.3608	.3295	.3644	.2887	.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 204 / 11KV PWW FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0914	.0934	.0934	.0938	
2	.0934	.0934	.0914	.0934	.0934	.0857	
3	.0934	.0934	.0914	.0934	.0934	.0934	
4	.0934	.0934	.0914	.0934	.0934	.0934	
5	.0934	.0934		.0934	.0934	.0934	
6	.0934	.0934		.0934	.0934	.0934	
7	.0934	.0934		.0934	.0934	.0938	
8	.0934	.0934		.0934	.0934	.0934	
9	.0914	.0914	.0934	.0914	.0914	.0914	.0914
10	.0914	.0914	.0934	.0914	.0914	.0914	.0914
11	.0914	.0914	.0934		.0914	.0914	.0914
12	.0914	.0914	.0934	.0924	.0914	.0914	.0914
13	.0914	.0934	.0934	.0924	.0914		.0914
14	.0914	.0934	.0934	.0924	.0914		.0914
15	.0914	.0934		.0914	.0914		.0914
16	.0914	.0934	.0934	.0914	.0914		.0914
17	.0934	.0934	.0905	.0934	.0914	.0914	.0934
18	.0934	.0934	.0914	.0934	.0914	.0914	.0934
19	.0934	.0914	.0924	.0934	.0914	.0924	.0934
20	.0934	.0914	.0924	.0934	.0914		.0934
21			.0914	.0934	.0914		.0857
22			.0914	.0934	.0914		
23	.0934		.0934	.0934	.0934		
24	.0934	.0934	.0914	.0934	.0934	.0934	.0914
Max	.0934	.0934	.0934	.0934	.0934	.0938	.0934
Min	.0914	.0914	.0905	.0914	.0914	.0857	.0857
Avg	.0927	.0928	.0923	.0929	.0922	.0922	.0916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134034 / MASTGAD 33/11 KV****Feeder No / Name : 205 / JINDAL COMPLEX INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0938	.0914	.0934	.0934		
2	.0934	.0934	.0914	.0934	.0934	.0934	
3	.0934	.0934	.0914	.0934	.0934	.0934	
4	.0934	.0934	.0914	.0934	.0934	.0934	
5	.0934	.0934		.0934	.0934	.0934	
6	.0934	.0934		.0934	.0938	.0934	
7	.0934	.0934		.0934	.0934	.0938	
8	.0934	.0934		.0934	.0934	.0934	
9	.0914	.0914	.0924	.0914	.0914	.0914	.0914
10	.0914	.0914	.0934	.0914	.0914	.0914	.0914
11	.0914	.0914	.0934	.0924	.0914	.0914	.0914
12	.0914	.0914	.0934	.0924	.0914	.0914	.0914
13	.0914	.0934	.0934	.0924	.0914		.0914
14	.0914	.0934	.0938	.0924	.0914		.0914
15	.0914	.0934		.0914	.0914		.0914
16	.0914	.0934	.0934	.0914	.0914		.0914
17	.0934	.0934	.0905	.0934	.0914	.0914	.0934
18	.0934	.0934	.0914	.0934	.0914	.0914	.0934
19	.0857	.0914	.0924	.0934	.0914	.0924	.0934
20	.0934	.0914	.0924	.0934	.0914		.0924
21			.0914	.0934	.0914		.0934
22			.0914	.0938	.0914		
23	.0934		.0934	.0934	.0934		
24	.0934	.0934	.0914	.0924	.0934	.0924	.0914
Max	.0934	.0938	.0938	.0938	.0938	.0938	.0934
Min	.0857	.0914	.0905	.0914	.0914	.0914	.0914
Avg	.0923	.0928	.0923	.0929	.0923	.0925	.0920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 206 / Mangal Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5228	.7316	.5601	.5601	.5788	
2	.5601	.4854	.695	.5228	.5415	.5601	
3	.4854	.4854	.6401	.5041	.5228	.5415	
4	.5228	.5601	.8413	.5601	.4854	.5228	
5	.8589	.5975		.6908	.6908	.6722	
6	1.307	.7716		1.1576	.8316	.8215	
7	1.419	1.2696		1.531	1.4415	1.4937	
8	1.531	1.7924		1.7551	1.6244	1.7177	
9	1.39	1.5729	1.6804	1.4632	1.4632	1.4632	1.4632
10	1.2071	1.2437	1.531	1.4632	1.2803	1.2803	1.2803
11	1.0608	1.2437	1.4563	1.2567	1.1706	1.2803	1.1706
12	.9145	1.0242	1.3443	1.0349	1.0242	.9511	1.0242
13	.8413	.9335	.9335	.9979	.9145		.9145
14	.7316	.8402	.7468	.8501	.8413		.8413
15	.8413	.8589		.8048	.7499		.7316
16	.8413	.8775	.8402	.8048	.7316		.7682
17	.9709	1.0082	.9774	1.0269	1.2071	.8779	.9335
18	1.2696	1.4563	1.2803	1.1576	1.3535	1.0974	1.3491
19	1.4045	1.2803	1.3676	1.3817	1.4083	1.3676	1.307
20	1.2323	1.0974	1.1827	1.307	1.1157		1.3256
21			.9511	1.1016	1.0242		1.2696
22			.3292	.8775	.9145		
23	.6348		.7095	.6908	.7499		
24	.5975	.5601	.7316	.5788	.5611	.5975	.695
Max	1.531	1.7924	1.6804	1.7551	1.6244	1.7177	1.4632
Min	.4854	.4854	.3292	.5041	.4854	.5228	.695
Avg	.9628	.9753	.9984	1.0033	.967	.9890	1.0767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 207 / NARIMAN NAGAR FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.2926	.1867	.1867	.1867	
2	.168	.4854	.2743	.1867	.1848	.168	
3	.1494	.1307	.2743	.1867	.168	.1494	
4	.2241	.168	.2926	.168	.1663	.1372	
5	.2801	.2054		.2241	.1867	.1867	
6	.3734	.2614		.2801	.2241	.2801	
7	.4294	.4108		.3921	.3174	.3547	
8	.4854	.5228		.4294	.4344	.4854	
9	.439	.4572	.4294	.4207	.4207	.4572	.439
10	.4024	.4207	.4668	.4024	.4207	.4572	.4572
11	.3658	.3841	.4755	.3696	.3841	.3841	.4024
12	.3292	.3475		.3511	.3475	.3841	.3658
13	.3292	.3174	.3734	.3511	.3292		.3292
14	.7316	.2987	.7468	.3142	.3292		.3109
15		.2987		.2926	.3109		.2743
16	.2743	.2987	.3142		.3109		.3109
17	.3174	.3734	.3258	.3361	.3658	.3292	.3547
18	.5415	.4668	.3658	.4108	.3841	.3658	.4294
19	.5544	.439	.4435	.4481	.4024	.4251	.4108
20	.3921	.4024	.4066	.4108	.3658		.4108
21			.3658	.3734	.3292		.5041
22			.3292	.2987	.3109		
23	.2241		.2427	.2427	.2427		
24	.2241	.2054	.3109	.2054	.2054	.2054	.2561
Max	.7316	.5228	.7468	.4481	.4344	.4854	.5041
Min	.1494	.1307	.2427	.168	.1663	.1372	.2561
Avg	.3534	.3372	.3739	.3166	.3053	.3098	.3754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 208 / TULJABHWANI NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.056	.0732	.056	.056	.0747	
2	.0549	.1494	.0732	.056	.056	.0747	
3	.0366	.056	.0549	.056	.056	.0514	
4	.0366	.0747		.056	.056	.056	
5	.0732	.0747		.056	.056	.056	
6	.0914	.168		.0747	.0747	.056	
7	.1097	.1494		.0934	.0934	.0686	
8	.1097	.1494		.112	.1307	.1029	
9	1.39	.1097	.112	.1097	.1097	.0914	.1097
10	.0914	.0914	.1086	.1097	.0914	.0914	.0914
11	.0914	.0914	.1307	.1109	.0914	.0914	.0914
12	.0914	.0914	.1307	.1109	.0914	.1097	.0914
13		.0934	.112	.1109	.0732		.0914
14	.0914	.0934	.0934	.0924	.0732		.0914
15		.0924		.0914	.0732		.0914
16	.0914	.0934	.112	.1097	.0732		.0914
17	.0934	.0934	.1086	.112	.0914	.0914	.112
18	.112	.1494	.1097	.112	.0914	.1097	.1307
19	.112	.128	.1109	.112	.0914	.1294	.1294
20	.112	.1097	.1109	.112	.0914		.1307
21			.0914	.0934	.0732		.0747
22			.0914	.0934	.0732		
23	.0732		.0747	.0747	.0747		
24	.2195	.0549	.0732	.056	.056	.0747	.0732
Max	1.39	.168	.1307	.112	.1307	.1294	.1307
Min	.0366	.0549	.0549	.056	.056	.0514	.0732
Avg	.1568	.1033	.0984	.0905	.0791	.0831	.1000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (U) S/D[406] BU 2712

Substation No/ Name :- 134034 / MASTGAD 33/11 KV

Feeder No / Name : 209 / 11 KV SAMBHAJI NAGAR8

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.7316	.5601	.5601	.5415	
2	.4481	.4481	.6584	.5415	.5415	.5228	
3	.4108	.4108	.6401	.5228	.5228	.5041	
4	.4481	.4854	.7316	.6535	.5041	.4854	
5	.7095	.5228		.7095	.7095	.6348	
6	1.0082	.9335		.7842	.7762	.7842	
7	1.1949	1.1458		1.2883	1.1763	1.2136	
8	1.419	1.3443		1.4003	1.3817	1.4377	
9	1.2803	1.262	1.4563	1.1888	1.2803	1.2803	1.262
10	1.1888	1.2437	1.4003	1.1888	1.1888	1.2437	1.2437
11	1.0974	1.1157	1.2136	1.1088	1.1706	1.1706	1.1523
12	.9328		1.1016	1.0164	1.0974	.9877	1.0974
13	.8048		.8775	.924	1.0974		.9877
14			.7655	.8131	.9328		.9145
15	.9694	1.1088		.7865	.8048		.9328
16	.9694	1.0456	.7095	.7865	.7316		.9877
17	1.0903	1.1271	.905	.9335	.9328	.9511	1.1203
18	1.2346	1.4563	1.0974	1.0269	1.2437	1.0974	1.4377
19	1.4563	1.2986	1.1643	1.2136	1.2986	1.2197	1.4003
20	1.1203	1.1706	.961	1.1203	1.1706		1.0269
21			.8596	.9335	1.0974		.9335
22			.8048	.7655	.9877		
23	.6348		.6908	.6535	.7468		
24	.5601	.5601	.7316	.5788	.5788	.5601	.0549
Max	1.4563	1.4563	1.4563	1.4003	1.3817	1.4377	1.4377
Min	.4108	.4108	.6401	.5228	.5041	.4854	.0549
Avg	.9268	.9536	.9211	.8958	.9388	.9147	1.0394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134036 / 33/11 KV Rohanwadi****Substaion****Feeder No / Name : 201 / 11 kv Sarswati Feeder****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4706	.5068	.5068	.4525	.4525	.4706
2	.4344	.4525	.5068	.543	.4706	.4344	.4706
3	.4706	.4525	.5792	.6154	.4344	.4525	.5068
4	.543	.5068	.6516	.6516	.5249	.543	.543
5	.6878	.5792	.724	.7602	.5792	.5792	.6154
6	.7602	.8145	.8688	.8688	.7964	.8869	.6516
7	1.0498	1.086	1.0136	.9412	.905	1.086	.7602
8	1.2308	1.2489	1.1584	1.1222	1.2127	1.1946	1.2308
9	1.1946	1.1765	1.2308	1.1765	1.3032	1.2489	1.1946
10	1.0136	.9955	1.0317	1.0498	1.2127	.8869	1.086
11	.8688	.9774	1.0679	.9593	1.0498	.905	1.0136
12	.8145	.9593	.8145	.9955	1.0317		.9593
13	.8145	.7421	.8326	.9774	.8507		.8869
14	.7602	.8507	.8688	.9231	.8326		.8507
15	.7783	.8507	.8869	.9231	.7602		.8145
16	.7059	.8869	.905	.9593	.724		.8145
17	.8145	.8688	.8145	.9412	.6878		.905
18	.8507	.9412	.905	.9593	.8326		.9412
19	.8869	.905	.8688	.9231	.8326	1.0498	.8869
20	.7964	.8326	.6516	.8326	.8145	.905	.7602
21	.7421	.724	.6154	.7421	.6697	.7602	.6878
22	.6878	.6878	.543	.5792	.5973	.6516	.5973
23	.5792	.5792	.4706	.5249	.5249	.5792	.5068
24	.4706	.5068	1.3822	.4344	.4706	.4887	.5068
Max	1.2308	1.2489	1.3822	1.1765	1.3032	1.2489	1.2308
Min	.4344	.4525	.4706	.4344	.4344	.4344	.4706
Avg	.7662	.7956	.8291	.8296	.7738	.7708	.7775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134036 / 33/11 KV Rohanwadi****Substaion****Feeder No / Name : 202 / 11 KV Bholeshwar Feeder****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7762	.7392	.7762	.7762	.7023	.7023	.7762
2	.7762	.5544	.8501	.8501	.7023	.7023	.7762
3	.8871	.7023	.961	.924	.7207	.6838	.8871
4	.9979	.8131	1.0719	.9979	.7762	.7207	.961
5	1.2567	.961	1.1827	1.1458	.8871		1.3306
6	1.4045	1.2752	1.3306	1.2382	1.1458	1.1643	1.4969
7	1.5524	1.5154	1.4784	1.4415	1.386	1.5708	1.6632
8	1.6817	1.6078	1.6263	1.5708	1.6448	1.7002	1.6448
9	1.3937	1.4045	1.5154	1.5154	1.5893	1.4784	1.5708
10	1.1643	1.1458	1.386	1.2567	1.3676	1.2382	1.2197
11	1.0498	1.0534	1.3121	1.0719	1.3491	1.0349	1.1643
12	.9425	.9979	1.2197	1.0164	1.0903		1.0719
13	.961	.9055	1.0719	.9795	1.0349		.961
14		.7577	.9979		.961		.924
15		.8316	.8131	.8501	.8686		.9055
16	1.0349	.9055		.924	.924		.8871
17	1.0534	1.1643	1.0349	1.0903	1.2197		1.1088
18	1.5154	1.4969	1.5154	1.4784	1.4969		1.4969
19	1.5339	1.4045	1.46	1.4415	1.3306	1.6632	1.4969
20	1.3676	1.2567	1.1088	1.2752	1.2382	1.3306	1.2567
21	1.1458	1.0903	1.0719	1.1088	1.1458	1.2197	1.1088
22	.961	.961	.961	.961	.9425	1.0719	.961
23	.8316	.8316	.8316	.8131	.8131	.9055	.8131
24	.7947	.7762	.7577	.7207	.7207	.7207	.8316
Max	1.6817	1.6078	1.6263	1.5708	1.6448	1.7002	1.6632
Min	.7762	.5544	.7577	.7207	.7023	.6838	.7762
Avg	1.1401	1.0480	1.1450	1.1064	1.0857	1.1192	1.1381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion****Feeder No / Name : 201 / 11 KV Gokulnagari feeder****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2783	.2969	.2969	.2783	.2972	.3333	.3344
2	.2783	.2969	.2969	.2783		.3333	
3	.2783	.2969	.2963	.2783		.3333	
4	.3711	.2969	.3333	.2783	.3344	.3704	.4087
5	.5196	.4825	.4074	.5196	.4458	.4444	.4458
6		.668	.5185	.6309	.5201	.5556	.5944
7	.7052	.7794	.6667	.7052	.6873	.7037	.743
8	.6866	.7423	.7407	.7052	.7616	.7423	.7616
9		.6296	.7052	.6316	.7037	.7207	.668
10	.5487	.5926	.668	.5573	.6296	.6283	
11	.4755	.4444	.5567	.5387	.5556		.4639
12	.394	.4074	.3897	.4458	.4815	.4887	.4082
13	.4163	.3704	.3711	.4087	.4074	.4706	.3526
14	.3045	.3704	.4454	.3901	.3333	.4344	
15	.2629	.3333		.3715		.4525	.2969
16	.3224	.2963	.3897	.354	.3704	.4525	.3155
17	.4458	.4074	.4454	.4458	.4444	.5201	.3704
18	.5387	.5556	.5567	.5387	.5556	.5387	.5185
19	.6316	.5556	.5938	.5944	.6296	.5758	.5926
20	.5944	.6296	.5567	.5573	.5185	.5573	.5926
21	.5387	.5185	.4825	.5201	.5185	.5015	.5185
22	.4458	.4815	.4454	.4458	.4444	.4644	.4444
23	.3711	.4074	.334		.3704		
24	.2783	.2969	.3333	.2783	.3344	.3704	.3715
Max	.7052	.7794	.7407	.7052	.7616	.7423	.7616
Min	.2629	.2963	.2963	.2783	.2972	.3333	.2969
Avg	.4403	.4649	.4709	.4675	.4926	.4996	.4843

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion****Feeder No / Name : 202 / 11 KV Dukhi Nagar****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.835	.8722	.8907	.8722	.8916	.9278	.9659
2	.835	.8722	.8536	.8722		.8907	
3	.835	.8722	.8536	.8722		.8907	
4	.9278	.8722	.9278	.8722	.9659	.9278	1.0031
5	1.1505	1.1134	1.0763	1.0948	1.1888	1.0021	1.3003
6	1.4845	1.4845	1.3361	1.3546	1.4489	1.4103	1.4861
7	1.8186	1.7443	1.7443	1.7258	1.5232	1.8557	1.8576
8	1.8928	1.9113	2.0412	1.9299	1.8761	2.0041	1.9504
9		1.6701	2.1526	1.8576	1.9299	.1943	1.8557
10	1.7177	1.5959	2.0041	1.7275	1.967	.1886	1.7072
11	1.587	1.5588	2.0227	1.7833	1.9299	1.5844	1.5959
12	1.531	1.5959	1.967	1.6347	1.7072	1.4784	1.5216
13	1.307	1.2619		1.4861	1.4845	1.307	1.3546
14	1.2323	1.2619	1.5588	1.4489	1.2247	1.2696	1.2062
15	1.1458	1.1876		1.3375	1.1876	1.1576	1.0948
16	1.1949	1.1876	1.2433	1.2446	1.1134	1.1203	1.2062
17	1.4489	1.4474	1.3546	1.3746	1.3732	1.4489	1.4845
18	1.7461	1.8928	1.6701	1.5975	1.8186	1.7833	1.7814
19	1.8576	1.7072	1.7072	1.7461	1.7443	1.6718	1.7814
20	1.6532	1.5959	1.5402	1.5975	1.6701	1.6718	1.5959
21	1.3746	1.4474	1.4103	1.3746	1.4103	1.4118	1.4474
22	1.3003	1.2247	1.1876	1.3003	1.2619	1.2631	1.2619
23	1.0021	.9649	.9649		1.1134		
24	.835	.8722	.8889	.8722	.9288	.9649	1.0774
Max	1.8928	1.9113	2.1526	1.9299	1.967	2.0041	1.9504
Min	.835	.8722	.8536	.8722	.8916	.1886	.9659
Avg	1.3353	1.3423	1.4271	1.3903	1.4436	1.2359	1.4541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 134045 / 33/11 KV Motibag Substaion****Feeder No / Name : 203 / 11 KV BACHAT BHAVAN FEEDER****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1299	.1115	.1481	.1115	.13	.1481	.13
2	.1299	.1115	.1481	.1115		.1481	
3	.1299	.1115	.1296	.1115		.1481	
4	.1485	.1115	.1111	.1113	.1672	.1852	.1486
5	.1856	.1672	.1481	.1486	.2043	.2222	.2043
6	.2227	.2229	.1852	.1858	.2415	.2593	.2229
7	.2598	.2601	.2222	.2229	.2415	.3333	.2786
8	.3155	.3158	.2963	.2601	.2601	.2593	.3158
9		.2593	.2783	.2601	.2963	.3045	.3158
10	.2835	.2222	.2969	.2415	.2963	.2865	.2601
11	.2454	.2222	.2412	.2043	.2593	.2865	.2229
12	.1928	.1852	.2415	.1858	.1852	.2279	.1858
13	.2103		.2227	.1672	.1852	.2454	.1672
14	.1753	.1852	.13	.1672	.1852	.1753	.1672
15	.1387	.1481		.1672	.1852	.1387	.1672
16	.1387	.1481	.1672	.1672	.1852	.1387	.2043
17	.2043	.2222	.1486	.2043	.1852	.1858	.2222
18	.2415	.2593	.1856	.2415	.2222	.2601	.2963
19	.2601	.2963	.2227	.2601	.2593	.2415	.2593
20	.2229	.2593	.2043	.2229	.2593	.2229	.2222
21	.2415	.2222	.1858	.2043	.2222	.2043	.1852
22	.2043	.1852	.1486	.1858	.1852	.1858	.1852
23	.1299	.1852	.13		.1481		
24	.1299	.1115	.1481	.1115	.13	.1481	.1486
Max	.3155	.3158	.2969	.2601	.2963	.3333	.3158
Min	.1299	.1115	.1111	.1113	.13	.1387	.13
Avg	.1974	.1967	.1887	.1850	.2106	.2155	.2147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA****Feeder No / Name : 201 / TOWN-4****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA****Feeder No / Name : 202 / TOWN I****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA****Feeder No / Name : 204 / TOWN-3****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA****Feeder No / Name : 206 / INDUSTRIAL****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	1.4899
Max	1.4899
Min	1.4899
Avg	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137001 / KANHAIYANAGAR 132KV JALNA****Feeder No / Name : 207 / Rural Industrial****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	.9816
Max	.9816
Min	.9816
Avg	.9816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 201 / GOVT POLYTECH****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 204 / 11KV SHAKTI FEEDER****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
23	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 205 / MOTIBAG 11KV****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 207 / SURENDRA FEEDER****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 209 / PARVATI NON EXPRESS****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	.8573
Max	.8573
Min	.8573
Avg	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 401 / KALIKA****Feeder KV- 33 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	3.0864
Max	3.0864
Min	3.0864
Avg	3.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 403 / MATSYODARI FEEDER
Feeder KV- 33 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	01-DEC-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 404 / SAPTASHRUNGI****Feeder KV- 33 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 405 / JALNA SIDDHIVINAYAK EXP. NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (U) S/D[406] BU 2712****Substation No/ Name :- 137003 / MIDC 132KV SUB-STATION****Feeder No / Name : 702 / 132 KV KALIKA****Feeder KV- 132 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	54.2982
Max	54.2982
Min	54.2982
Avg	54.2982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION****Feeder No / Name : 201 / NER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.5223
Max	1.5223
Min	1.5223
Avg	1.5223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION****Feeder No / Name : 202 / SHIVNI****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.4899
Max	1.4899
Min	1.4899
Avg	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION****Feeder No / Name : 203 / TAKARWAN SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.4899
Max	1.4899
Min	1.4899
Avg	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION****Feeder No / Name : 204 / PATHRUD SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.2971
Max	1.2971
Min	1.2971
Avg	1.2971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134007 / NER 33/11 KV SUB-STATION****Feeder No / Name : 205 / shevga SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.7973
Max	.7973
Min	.7973
Avg	.7973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134014 / SEOLI 33/11 KV S/S****Feeder No / Name : 201 / PIMPALWADI****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.4899
Max	1.4899
Min	1.4899
Avg	1.4899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134014 / SEOLI 33/11 KV S/S****Feeder No / Name : 203 / BORGAON****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
1	1.0056
Max	1.0056
Min	1.0056
Avg	1.0056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S****Feeder No / Name : 201 / SAWRGAON AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	1.4737
Max	1.4737
Min	1.4737
Avg	1.4737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 202 / RAMNAGAR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8383	.7621	.7621	.4572		
2	1.0974	.7621	.9145	.9145	.4572		
3	1.1888	.9145	.9145	1.0974	.7621		
4	1.2803	1.0669	1.0669	.9907	.7621		
5	1.3717	1.1431	1.1603	1.1431	.9145		
6	1.4632	1.2193	1.3717	1.2193	1.0669		
7	1.6461		1.2003	1.2651	1.2193		
8	1.6461	1.5089	1.3717	1.448	1.2193		
10						1.1888	1.1888
11						1.0669	1.3717
12						1.3108	1.4937
13						1.448	1.448
14						1.3108	1.3717
15						1.4327	1.3717
16						1.2651	1.2193
17						1.3108	1.2193
Max	1.6461	1.5089	1.3717	1.448	1.2193	1.448	1.4937
Min	.9145	.7621	.7621	.7621	.4572	1.0669	1.1888
Avg	1.3260	1.0647	1.0953	1.1050	.8573	1.2917	1.3355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 203 / EX-D'RAJA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.6097	.7621	.5335	.6097	.7316	.6097
2	.6401	.5335	.7621	.6097	.6097	.7316	.6859
3	.7316	.5335	.9145	.6859	.6097	.823	.7621
4	.7316	.5487	.9831	.5335	.6097	.823	.7621
5	.7316	.5487	.9145	.4877	.7621	.9145	.6859
6						.9145	.7621
7						.9145	.6859
14			.7621				
15	.9145	.9145	.7621	.9145	1.0059		
16			.7316	.9145	1.0974		
17		.9145		.9145	1.0974	.8688	.1524
18		.9145	.9145	.9145	1.0974	.9297	
19						.8383	.1524
21							.1219
24	.6401	.5944	.4572	.6401	.4572		
Max	.9145	.9145	.9831	.9145	1.0974	.9297	.7621
Min	.6401	.5335	.4572	.4877	.4572	.7316	.1219
Avg	.7185	.6791	.7964	.7148	.7956	.8490	.5380

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 204 / EX-GINNING

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.6097	.4572		.6097
2		.7621	.5335	.5716		.5335
3		.7621	.4572	.5716		.5335
4		.7621	.3048	.7621		.5335
5		.7621	.1829	.8573		.4572
6		.7621	.5335	.8573		.3048
7		.9145	.7621	.8573		.6097
8		.7621	.6859	.8573		.6097
9		.7621	.6097	.7621		.6097
10		1.0288	.4572			.8383
11	.9145		.7621		.6097	.5716
12	.9145		.9526		.6097	.4572
13	.9145		.9526		.6097	.5716
14	.7621		.8573			.5716
15	.7621		.9526			.5716
16	.9145		1.0288		.1372	.5716
17	.9145		.7621		.1524	.5716
18	.9145		.4763		.2743	
19	.4572		.4763		.3048	.381
20	.4287		.4763		.5335	.5716
21	.4572		.4763	.4287	.5335	.6668
22	.6097		.4763	.4763	.5335	.7621
23	.6097		.4763		.5335	.7621
24		.6859	.6401	.4572		.5487
Max	.9145	1.0288	1.0288	.8573	.6097	.8383
Min	.4287	.6859	.1829	.4287	.1372	.3048
Avg	.7364	.8019	.6209	.6597	.4393	.5747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S****Feeder No / Name : 205 / BHATEPURI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.381	.4572	.4572	.4572	.3658	.4572
2	.4572	.4572	.4572	.4572	.4572	.3658	.6097
3	.4572	.6097	.4572	.5335	.4572	.4572	.8383
4	.5487	.6097	.6097	.6097	.6097	.6401	.7621
5	.7316	.8383	.7621	.6706	.7621	.9145	.8688
6	.9145	.8383	.9145	.7621	.9145	1.2803	.9145
7	1.0974		.9145	.8383	.9145	1.3717	
8	1.0974	1.0059	.7621	.8383	.9145	1.1888	.945
9	1.0974	.7621		.6401	.7621	1.0059	.8383
10	.9145	.7164	.6097	.4877	.7316	.7316	
11		.4572	.3658	.3048	.5487	.3353	
12		.4572	.2743	.2286	.4572	.1981	.3048
13		.3048	.2896	.2286	.4572	.2134	.3048
14		.3048	.1981	.2286	.3658	.1981	.3048
15	.2896	.3048	.2439	.3048		.2134	.3048
16		.3048	.3048	.3048	.4572	.2439	
17		.3048	.4268	.4572	.6401		
18		.4572	.7316	.6859	1.0974		.8383
19	.6097	.5335	.6706	.6097	.9145	.6859	.7621
20	.5792	.6097	.4877	.4572	.6401	.503	.6097
21	.5182	.4572	.3658	.381	.5487	.4572	.4572
22	.3353	.3048	.3048	.381	.4572	.381	.4572
23	.3506	.3048	.3048	.381	.4572	.3353	.4572
24	.4572	.3658	.3048	.3048	.381	.3658	.3201
Max	1.0974	1.0059	.9145	.8383	1.0974	1.3717	.945
Min	.2896	.3048	.1981	.2286	.3658	.1981	.3048
Avg	.6419	.5083	.4877	.4814	.6262	.5660	.5976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S****Feeder No / Name : 206 / RAMNAGAR GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4572	.6097	.6097	.5487	.4572
2	.5487	.4572	.4572	.7621	.6097	.5487	.5335
3	.6401	.4725	.6097	.8383	.6097	.7316	.6859
4	.823	.5335	.7621	.9145	.7621	1.0059	.8383
5	1.0059	.6097	.7621	1.0212	.9145	1.0974	.9145
6	1.2803	.7621	.9145	.9907	1.0669	1.3717	1.1431
7	1.3717		.9145	.9755	1.1431	1.3717	1.0212
8	1.226	.9297			1.2193	1.0974	
9	1.1888	.7621	.7621	1.0669	1.2193	1.0974	.945
10	1.0974	.8078	.7621	.8688	1.0974	.823	.9907
11		.6097	.6249	.6097		.4572	
12		.6097	.4572	.5335	.6401	.381	.4572
13		.4572	.503	.5335	.6401	.3353	.5335
14		.4572	.4725	.5335	.5487	.3506	.5335
15	.4115		.5182	.5335	.6401	.381	.5335
16			.4877	.6097		.4115	.5335
17			.6859	.7621	1.0059	.503	.6097
18		1.0669	1.0974	1.0669	1.5546	.9145	.9907
19	.6097	.9145	1.1431	1.0669	1.2803	1.0974	.9831
20	.5792	.9145	.7621	.9145	.9145	.8383	.9145
21	.6859	.7621	.6249	.9145	.823	.6097	.6859
22	.5639	.7621	.4572	.9831	.7316	.5792	.6859
23	.442	.6097	.4725	.7621	.6401	.4572	.6097
24	.5487	.4572	.4572	.4725	.6097	.5487	.381
Max	1.3717	1.0669	1.1431	1.0669	1.5546	1.3717	1.1431
Min	.4115	.4572	.4572	.4725	.5487	.3353	.381
Avg	.7929	.6706	.6594	.7976	.8764	.7316	.7264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S****Feeder No / Name : 207 / Bajiumrad****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6859	1.2193	1.2193		
2	1.0059	.7621	1.2193	1.2955		
3	1.0974	.9145	1.2193	1.2955		
4	1.1888	1.1431	.1219	1.3717		
5	1.3717	1.3717	1.3717	1.4937		
6	1.9204	1.6004	1.5242	1.4022		
7	2.2862		1.9814	1.5851		
8	2.2862	1.9966	1.9814	1.8595		
10					2.0119	1.3717
11					1.7528	1.6766
12					1.7985	1.6004
13					1.6613	1.6004
14					1.6004	1.5242
15					1.5089	1.5242
16					1.4632	1.2193
17					1.326	1.2193
24			2.3777			
Max	2.2862	1.9966	2.3777	1.8595	2.0119	1.6766
Min	.823	.6859	.1219	1.2193	1.326	1.2193
Avg	1.4975	1.2106	1.4462	1.4403	1.6404	1.4670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134019 / RAMNAGAR 33/11 KV S/S

Feeder No / Name : 209 / SALEGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.5487	.4572
2						.5487	.6097
3						.5487	.6859
4						.7316	.8383
5						.7316	.9145
6						.823	.7621
7						1.0059	1.1584
8						1.0059	1.0974
10	1.2803		1.0669	1.0974	1.2803		
11		1.267	1.0669	1.0974	1.5546		
12		1.3717		1.3717	1.6461		
13		1.2193	1.387	1.2955	1.6461		
14		1.2193	1.4784	1.2193	1.4632		
15	1.1279	1.0669	.9907	1.2193	1.3717		
16		1.0669	.8535	1.1431	1.2803		
17		.9907	.6554	.9145	1.0974		
18	1.0364						
Max	1.2803	1.3717	1.4784	1.3717	1.6461	1.0059	1.1584
Min	1.0364	.9907	.6554	.9145	1.0974	.5487	.4572
Avg	1.1482	1.1717	1.0713	1.1698	1.4175	.7430	.8154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134025 / GOLAPANGRI****Feeder No / Name : 201 / SAMANGAON+KAJALA****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	2.2436
Max	2.2436
Min	2.2436
Avg	2.2436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134025 / GOLAPANGRI****Feeder No / Name : 202 / KAJALA
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	1.5223
Max	1.5223
Min	1.5223
Avg	1.5223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134025 / GOLAPANGRI****Feeder No / Name : 203 / BATHAN AG FEEDER
Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.9313
Max	.9313
Min	.9313
Avg	.9313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 204 / GOLAPANGHRI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591		.1524	.2286			
2	.2591		.1524	.2286			
3	.2439		.1829	.1981			
4	.2439		.1829	.1829			
5	.2439		.1829	.1829			
6	.2439						
7	.2439						.1886
8	.2134		.2743				.2058
9	.3258		.3506	.3658	.2058		
10			.4268	.4287	.2896		.1981
11			.4268		.2591		.1829
12			.3048		.3658		.1677
13			.3048		.2896		.1677
14		.2896		.5144	.4115		.1677
15				.4115	.4268		.1677
16		.381			.3963		.1677
17	.3944	.5144	.3506		.3201	.1543	.1829
18		.442	.3048		.2439	.2229	.1524
19		.381	.3048		.2439		.1219
20		.3506	.3048	.2915	.2286		.1067
21		.3201	.3429		.1981		.1067
22		.3048	.3239		.1829		.1067
23		.2286	.2591		.1677		.0914
24			.1524	.3429	.2401	.1677	
Max	.3944	.5144	.4268	.5144	.4268	.2229	.2058
Min	.2134	.2286	.1524	.1829	.1677	.1543	.0914
Avg	.2671	.3569	.2782	.3069	.2794	.1816	.1552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134025 / GOLAPANGRI****Feeder No / Name : 205 / mali pimpalgaon****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1524	.1524			
2	.1372		.1829	.1524			
3	.1524		.1829	.1829			
4	.1829		.2286	.2286			
5	.2286		.3048	.3353			
6	.3048						
7	.5639						.7716
8	.5487		.5639				.7373
9	.6516		.5944	.6859	.7373		.583
10			.4572	.5144	.5639		.3963
11			.3353		.3963		.2896
12			.2286				.3048
13			.2134		.1677		.2286
14		.1067		.1543	.1677		.1981
15		.1829		.1886	.1219		.1829
16		.2743			.1677		.2591
17	.3086	.3353	.3506		.3201	.4458	.4115
18		.5335	.3048		.4877	.6001	.5335
19		.442	.2743		.5639		.4572
20		.3201	.2286	.3772	.3506		.3201
21		.2439	.2286		.2439		.1524
22		.1829	.1905		.1829		.1524
23		.1677	.3048		.1524		.1524
24			.9587	.1715	.1715	.1372	.1715
Max	.6516	.5335	.9587	.6859	.7373	.6001	.7716
Min	.1372	.1067	.1524	.1524	.1219	.1372	.1524
Avg	.3216	.2789	.3308	.2858	.3197	.3944	.3501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134025 / GOLAPANGRI****Feeder No / Name : 206 / kajala GFS
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17
HR	Load (MW)
24	1.4922
Max	1.4922
Min	1.4922
Avg	1.4922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134025 / GOLAPANGRI

Feeder No / Name : 207 / ROHANWDI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896		.2439	.3048			
2	.2286		.2439	.2439			
3	.2591		.2743	.2743			
4	.2591		.3048	.3048			
5	.3048		.3506	.381			
6	.381		.4268				
7	.4115		.4572				.4801
8	.4115		.4268				.4115
9	.4458		.4268	.5335	.5658		.4458
10			.3658	.4458	.4572		.3353
11			.3353		.3963		.3048
12			.3048				.2743
13			.2286		.3048		.2439
14		.2743		.2915	.2743		.2286
15		.3048		.2572	.2591		.2134
16					.3201		.2439
17	.4287	.3048	.3963		.3353	.3429	.3506
18		.503	.4877		.4115		.442
19		.4268	.4572		.4572		.4115
20		.3658	.3506	.4287	.3506		.3658
21		.3048	.381		.3048		.3048
22		.2591	.3429		.3048		.2743
23		.2591	.3048		.3048		.2439
24			.2743	.2667	.3258	.2896	.3258
Max	.4458	.503	.4877	.5335	.5658	.3429	.4801
Min	.2286	.2591	.2286	.2439	.2591	.2896	.2134
Avg	.3420	.3336	.3516	.3393	.3582	.3163	.3278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 201 / PIMPRI D - AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	30-NOV-17	04-DEC-17
HR	Load (MW)	Load (MW)
1	1.6804	
2	1.6804	
3	1.9605	
4	1.9004	
5	2.2405	
6	2.4272	
8	2.5579	
10		2.0957
11		2.4768
12		2.4768
13		2.0957
14		1.9052
15		1.9052
16		1.9052
17		1.8099
Max	2.5579	2.4768
Min	1.6804	1.8099
Avg	2.0639	2.0838

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 202 / HIVRAROSHANGAON-AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	30-NOV-17	04-DEC-17
HR	Load (MW)	Load (MW)
1		1.3336
2		1.3336
3		1.3336
4		1.5242
5		1.6194
6		1.7147
7		1.7147
8		2.0005
10	2.4768	
11	2.4768	
12	2.4768	
13	2.4768	
14	2.4768	
15	2.4768	
16	2.4768	
17	2.4768	
24		1.3336
Max	2.4768	2.0005
Min	2.4768	1.3336
Avg	2.4768	1.5453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 203 / HIWARA ROSHANGAON GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.381	.381
2			.381
3			.4572
4			.4954
5			.5335
6			.5716
7			.5716
8			.5716
9	.5335		.5144
10	.4763		.381
11	.4763		.381
12	.381		.381
13	.381		.381
14	.381		.381
15	.381		.381
16	.381		.381
17	.381		.381
18	.7802		.5716
19	.5716		.7621
20	.6668		
21	.5716		
22	.5716		
23	.5716		
24		.9114	.381
Max	.7802	.9114	.7621
Min	.381	.381	.381
Avg	.5004	.6462	.462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 204 / BAPKAL AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	30-NOV-17	01-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.5601		
2	.5601		
3	.6535		
4	.7468		
5	.9335		
6	1.1203		
7	1.1203		
8	1.1203		
10			.7621
11			.7621
12			.7621
13			.9526
14			.9526
15			.7621
16			.7621
17			.7621
24		1.8781	
Max	1.1203	1.8781	.9526
Min	.5601	1.8781	.7621
Avg	.8519	1.8781	.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 205 / PIMPRI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	04-DEC-17
HR	Load (MW)	Load (MW)
1	.3734	.3429
2	.3734	.381
3	.4668	.381
4	.4668	.381
5		.4954
6		.5144
7		.5335
8	.5041	.5335
9	.4763	.4572
10	.5716	.2858
11	.2858	
12	.381	.1905
13	.381	.0953
14	.1905	.0953
15	.1905	.0953
16	.1905	.1905
17	.2858	.1905
18	.381	.381
24	.3734	.3429
Max	.5716	.5335
Min	.1905	.0953
Avg	.3682	.3271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134033 / 33KV HIWRA ROSHANGAON****Feeder No / Name : 206 / SOLGAVAN AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	30-NOV-17	04-DEC-17
HR	Load (MW)	Load (MW)
1		.7621
2		.7621
3		.9526
4		.9526
5		1.0479
6		1.1431
7		1.1431
8		1.3336
10	.9526	
11	1.0479	
12	.9526	
13	.9526	
14	.9526	
15	1.1431	
16	1.1431	
17	1.1431	
Max	1.1431	1.3336
Min	.9526	.7621
Avg	1.0360	1.0121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134037 / HISWAN****Feeder No / Name : 201 / HISWAN-AG
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	01-DEC-17
HR	Load (MW)
24	2.5317
Max	2.5317
Min	2.5317
Avg	2.5317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134037 / HISWAN

Feeder No / Name : 202 / TANDULWADI AG FEEDER
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.4575	.5668	1.2955	1.2955	
2	1.6194	1.4575	.6478	1.2955	1.2955	
3	1.6194	1.4575	.6478	1.2955	1.2955	
4	1.6194	1.4575	.8907	1.2955	1.2955	
5	1.6194		.9717	1.6194	1.6194	
6	1.6194		1.2146	1.6194	1.6194	
7	1.7814		1.2146	1.6194	1.6194	
8	1.6194	1.4575	1.3765	1.6194	1.4575	
10						.081
11						.081
12						.081
13						.081
14						.081
15						.081
16						.081
17						.081
18			.1619			
19			.1619			.0162
20			.1619			.0162
21	.081					.0162
22	.081					.0162
23	.081					.0162
24	.1619	.081	.7522			.0162
Max	1.7814	1.4575	1.3765	1.6194	1.6194	.081
Min	.081	.081	.1619	1.2955	1.2955	.0162
Avg	1.1268	1.2281	.7307	1.4575	1.4372	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134037 / HISWAN****Feeder No / Name : 203 / PUNEGAON****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.0324	.1296
2	.081		.0324	.1296
3	.081	.081	.0324	.1619
10	2.5911		1.2146	2.5911
11	2.672		1.5384	2.915
12	2.753		2.672	2.4291
13	1.2955		2.5911	
14	1.1336			1.7814
15	.9717			
16	.9717			
17				.9717
18			.1619	
19			.1619	
20			.1619	
24	.1619	.081		
Max	2.753	.081	2.672	2.915
Min	.081	.081	.0324	.1296
Avg	1.1630	.081	.8599	1.3887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134037 / HISWAN****Feeder No / Name : 204 / HISWAN+TANDULWADI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9717	.9717	.9717	.6478	.8097	.3239
2	.9717	.9717	.9717	.6478	.8097	.2429
3	.9717	.9717	.9717	.8097	.8097	.2429
4	.8097	.9717	1.0526	.8097	.8097	.3239
5	.8097		1.0526	.9717		.2429
6	.8097		.9717			.2429
7						.2429
8						.3239
9				.8097	.4858	.3239
10	.8097		.4858	.8097	1.1336	.3239
11	1.0526			.9717	.9717	.2429
12	.9717				.8097	.2429
13	.8907		.8907		.8097	.1619
14					.8097	.1619
15					.8097	.1619
16					.8097	.2429
17	.9717					.2429
18			1.1336			
19			1.1336			.5668
20			1.1336			
21			.9717			.3239
22						.4858
23						.4858
24	.9717	.9717	.9114			.3239
Max	1.0526	.9717	1.1336	.9717	1.1336	.5668
Min	.8097	.9717	.4858	.6478	.4858	.1619
Avg	.9177	.9717	.9733	.8097	.8232	.2944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134037 / HISWAN****Feeder No / Name : 205 / PUNEGAON GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	03-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3077	.4858	.2753	.4858
2	.3239	.3077	.4858	.2753	.4858
3	.3239	.3077	.5668	.2753	.4858
4	.4049	.3239	.5668	.3239	.4049
5	.4049		.4858		.4858
6	.4858		.5668		.5668
7					.5668
9		.3077		.3887	.4858
10	.4049		.2429	.3239	.4049
11				.3239	.3239
12				.3239	.2915
13			.421	.3239	
14				.3239	.2591
15				.3725	.2591
16				.3725	.3239
17					.3239
18			.4858		.2591
19			.4858		.3401
20			.4858		.3239
21					.3239
22					.3239
23					.3239
24	.4049	.3239			.4858
Max	.4858	.3239	.5668	.3887	.5668
Min	.3239	.3077	.2429	.2753	.2591
Avg	.3846	.3131	.4799	.3253	.3879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134037 / HISWAN****Feeder No / Name : 206 / GADE SAWARGAON****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.081	.0324	.081	.081	.2429
2	.081	.081	.0324	.081	.081	.2429
3	.0648	.081	.0324	.0648	.081	
4						.3239
5						.2429
6						.3239
7						.4049
8						.4858
10	.4049		.3239	.4858	.3077	
11	.4049		.3239	.5668	.3239	
12	.4858		.4858	.4858	.4049	
13	.4858		.421	.5668	.5668	
14	.3239			.583	.4049	
15	.3239			.4049	.5668	
16	.3725			.4049	.5344	
17	.4372			.3563		
18			.081			
19			.081			.0486
20			.081			.0486
21						.0486
22						.0486
23						.0486
24	.081	.081	1.5384			.081
Max	.4858	.081	1.5384	.583	.5668	.4858
Min	.0648	.081	.0324	.0648	.081	.0486
Avg	.2956	.081	.3121	.3710	.3352	.1993

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 201 / DHALDI - AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1603	1.3717	1.5604	1.326	1.2574	.5716	.5716
2	1.1603	1.3717	1.4289	1.326	1.2574	.5716	.5716
3	1.1603		1.5604	1.326	1.2574	.5716	.5716
4	1.4918	1.8861	1.5508	1.5746	1.4918	.7621	.6668
5	1.6575	2.0576	1.8776	1.9062	1.6575	.9526	.8573
6	2.2119	2.0576	1.6909	1.989	1.989	1.1431	1.0479
7	1.2384	1.2384	.9602	1.3336	1.1431	2.1548	2.0719
8	1.0479	1.1431	1.0402	1.1431	1.1431	2.3758	2.2119
9						2.753	2.3758
10						1.4918	2.2939
11						2.4577	2.3148
12						2.4577	2.1948
13						2.3758	2.0576
14						2.1548	1.9719
15			.381			.381	
16			.4763			.4763	
17			.5716	.4763		.5716	
18	.9145	.503	1.0479	1.0479	1.0479	.9526	.9907
19	.8573	.8288	.9526	.9526	1.1431	.9526	.8573
20	.7621	.7202	.8573	.8573	.8573	.7621	.7621
21	.6668	.6401	.6668	.7621	.6668	.6668	.6668
22	.6097	.5601	.6668	.6668	.5716	.5716	.6097
23	.8573	.5935	1.0059	1.0059	.5716	.5716	.5716
24	1.1603	1.0288	1.7193	1.326	1.2574	.5716	.5716
Max	2.2119	2.0576	1.8776	1.989	1.989	2.753	2.3758
Min	.6097	.503	.381	.4763	.5716	.381	.5716
Avg	1.1304	1.1429	1.1119	1.1887	1.1542	1.2197	1.2766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 202 / WANJAR UMRAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.3277	.1905	.1905	.503	.5868
2	.1905		.3391	.1905	.1905	.503	.5868
3	.1905		.2486	.1905	.1905	.503	.5868
4	.1905		.2458	.2858	.1905	.503	.7545
5	.2858		.3239	.2858	.1905	.503	.9221
6	.381		.4973	.381	.1905	.503	1.0898
7	.4763		.3315	.381	.2858	.381	.4763
8				.381	.2286	.2858	.381
15	2.0576	1.2793	1.9062	1.326	1.8233		
16	2.5377	1.2651	2.0719	1.2574	1.7404		
17	2.4006	1.6556	1.4251	1.2574	1.4918		
18	2.0576	1.5565	1.4089	1.0059	1.4089	.2858	.381
19		1.3108	1.1736	.8383	1.1736	.381	.381
20		1.0402	1.0059	.6706	1.0059	.2858	.2477
21		.8916	.9221	.503	.8383	.1905	.2096
22		.9326	.9221	.503	.503	.1905	.1905
23		.301	.1905	.1905	.503	.503	.5144
24	.1905		1.4899	.1905	.1905	.503	.5868
Max	2.5377	1.6556	2.0719	1.326	1.8233	.503	1.0898
Min	.1905	.301	.1905	.1905	.1905	.1905	.1905
Avg	.9291	1.1370	.8724	.5572	.6853	.4016	.5263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134040 / 33KV GONDEGAON

Feeder No / Name : 203 / WAGHRUL (J)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.2515	.2858		.2858	.1905
2		.381	.2458	.2858		.2858	.1905
3		.381	.2429	.2858		.2858	.1905
4		.4191	.3201	.2858		.2858	.1905
5		.4572	.4096	.3429		.2858	.1905
6		.4191	.4801	.381		.381	.1905
7	2.1548	2.2291	1.989	1.4918	1.0059	.381	.2858
8	2.672	2.7778	1.9528	2.0719	1.4089	.381	.2858
9	2.9959	2.915	2.2291	2.2939	1.5203		
10	2.834	2.5911	1.9319	2.2119	1.2955		
11		2.3482	2.13	2.2119			
12		2.1434	2.0719	2.2119	1.1888		
13		2.332	1.989	2.13	1.3279		
14	1.2003	2.1148	1.9062	1.989	1.2431		
15							.8573
16							1.1488
17						1.1736	1.0288
18	.4763	.2372	.381	.2858	.381	1.0059	.8745
19	.4763	.3125	.4763	.381	.381	.8383	.7716
20	.4191	.4191	.381	.381	.381	.6706	.6859
21	.381	.4144	.381	.2858	.2858	.503	.6859
22	.381	.3201	.381	.2858	.2858	.503	.6344
23	.381	.3429	.2858	.2858	.2858	.1905	.1905
24	.381	.381	1.4118	.2858		.2858	.1905
Max	2.9959	2.915	2.2291	2.2939	1.5203	1.1736	1.1488
Min	.381	.2372	.2429	.2858	.2858	.1905	.1905
Avg	1.2294	1.1580	1.0404	.9843	.8454	.4839	.4879

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134040 / 33KV GONDEGAON****Feeder No / Name : 204 / WAGHUL GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.2812	.1715	.1715	.1715	.1715
2	.1715	.1715	.2821	.1715	.1715	.1715	.1715
3	.1715	.2572	.2806	.1715	.1715	.1715	.1715
4	.2572	.3429	.3749	.2572	.2572	.2572	.2572
5	.3429	.4287	.3723	.3429	.3429	.3429	.3429
6	.5144	.5144	.4634	.5144	.4287	.5144	.4287
7	.6001	.5144	.4687	.6859	.5144	.4287	.4287
8	.5144		.4658	.5144	.5144	.4287	.4287
9	.4287	.3429	.2821	.4287	.4706	.4287	.3429
10	.3429	.2572	.2812	.3429	.3749	.3429	.2572
11	.1715	.1715	.2572	.1715	.2806		
12	.1715	.188	.1715	.1715	.2795		
13	.1715	.1882	.1715	.1715	.1875		.1715
14	.1715	.1875	.1715	.1715	.1715		.1715
15	.1715	.1879	.1715		.1715		.2572
16	.2572	.1875	.1715		.2572		.2572
17	.3429	.1875		.2572	.2572	.3429	.3429
18	.5144	.2824	.5144	.5144	.4287	.5144	.5144
19	.5144	.3727	.4287	.4287	.4287	.5144	.5144
20	.3429	.3719	.3429	.3429	.3429	.3429	.4287
21	.3429	.3749	.2572	.2572	.2572	.3429	.3429
22	.2572	.2821	.2572	.2572	.2572	.2572	.3429
23	.2572	.1879	.2572	.1715	.1715	.1715	.2572
24	.1715	.1715	2.4155	.1715	.1715	.1715	.1715
Max	.6001	.5144	2.4155	.6859	.5144	.5144	.5144
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.3072	.2757	.3974	.3040	.2950	.3287	.3079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134040 / 33KV GONDEGAON****Feeder No / Name : 205 / WANJAR UMRAD GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1875	.0857	.0857	.0857	.0857
2	.0857	.0857	.1877	.0857	.0857	.0857	.0857
3	.0857	.1372	.1879	.0857	.0857	.0857	.0857
4	.0857	.1715	.1871	.12	.0857	.0857	.0857
5	.1715	.2401	.2804	.1715	.1715	.1715	.1715
6	.2572	.2915	.2801	.2572	.2572	.2572	.2572
7	.2058	.2058	.2806	.2572	.2572	.2572	.2572
8	.1715	.1372	.1871	.2229	.2572	.2572	.2572
9		.1029	.188	.1715	.2818	.2058	.1715
10					.1875	.12	.1372
11	.1372	.0857			.1879	.0857	.0857
12	.1372	.0937	.1029	.1029	.188	.0857	.0514
13	.0857	.094	.1029			.0857	.0514
14	.0857					.0857	
15	.0857	.0943	.0857	.0857	.0857	.0857	
16	.0857	.0936	.0857	.0857	.0857	.1029	
17	.1715	.094	.1715	.1372	.12	.1715	.1715
18	.2229	.1879	.2572	.2572	.2058	.2572	.2401
19	.2058	.2821	.2572	.2572	.1715	.2572	.1715
20	.1715	.2806	.1715	.1715	.1715	.1715	.1372
21	.1372	.2806	.12	.12	.12	.12	.1372
22	.1029	.1877	.1029	.12	.0857	.12	.1029
23	.0857	.0937	.0857	.0857	.0857	.0857	.0857
24	.0857	.0857	.9313	.0857	.0857	.0857	.0857
Max	.2572	.2915	.9313	.2572	.2818	.2572	.2572
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0514
Avg	.1341	.1551	.2115	.1483	.1522	.1422	.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134043 / DHARKALYAN****Feeder No / Name : 201 / KADVANCHI****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5415	.6668	.7621	1.1431	1.5242	1.2384
2	.7621	.6908	.7621	.8573		1.7147	1.3336
3	.7621	.5975	.7621	.8573		1.9052	1.5242
4	.7621	.6348	.9526	.9526		2.0957	1.7147
5			.9526			2.2862	1.7147
6			1.1431			2.4768	1.9052
7					1.0456	2.6673	
8	.9526	1.251					
9		1.307					
10		1.4563					
11	1.8671						
12	1.7177						
13	2.0538						
14	1.8671						
15	2.1472						
16			1.5242	2.3339			
17			2.8578	2.4272			
18			3.2388	1.8671			
19	.4481		2.191		1.5242	.9526	
20	.5041		2.0957		1.1431	.9526	
21	.5975		2.0005		1.1431		
22			1.9052		1.1431		
23			1.7147		.9526	.8573	
24	.7621	.3361	1.4899	.7621	.8589	.8573	.9526
Max	2.1472	1.4563	3.2388	2.4272	1.5242	2.6673	1.9052
Min	.4481	.3361	.6668	.7621	.8589	.8573	.9526
Avg	1.1404	.8519	1.6171	1.3525	1.1192	1.6627	1.4833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 202 / NAVHA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.4481	.9526	.7621		.5716	.6859
2	.7621	.5041	1.2384	.8573		.6668	.6859
3	.7621	.4854	1.5242	.9526		.7621	.7621
4	.9526	.5415	1.9052	1.0479		.8573	
5			2.0957	1.1431			
6			2.0957	1.7147			
7			2.0957	2.4768			
8						1.7147	
9					1.4563	2.0957	
10					1.4937	2.191	
11					2.6673	2.191	
12					2.4768	2.0957	
13					2.3815	2.0005	
14					2.2862	1.9052	
15					2.2862	1.8671	
16	1.531						
17	1.8671						
18	2.0538						.3921
19	2.1472		1.2384		.9526	.7621	.5041
20	2.2405		1.2384		.6668	.8573	.7095
21	2.3339		1.0479		.7621	.8573	.3921
22			1.0479		.7621		.4108
23			.9526		.7621	.7621	.3547
24	.7621	.3547	1.8839	.6668	.3921	.5716	.724
Max	2.3339	.5415	2.0957	2.4768	2.6673	2.191	.7621
Min	.7621	.3547	.9526	.6668	.3921	.5716	.3547
Avg	1.4704	.4668	1.4859	1.2027	1.4881	1.3370	.5621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134043 / DHARKALYAN****Feeder No / Name : 203 / BORKHEDI****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8775	.6668	.5716		1.5242	1.1431
2	.8573	.9335	.6668	.6668		1.7147	1.3336
3	.8573	1.0082	.7621	.7621		2.0957	1.5242
4	.9526	1.0456	.7621	.8573		2.2862	1.7147
5			.8573			2.4768	1.9052
6			.9526			2.6673	2.4768
7					1.8111	2.7625	
8	1.1431	2.0725					
9		2.4086					
10		2.6513					
11	2.782						
12	2.5206						
13	2.5579						
14	2.5206						
15	2.6139						
16			1.4289	2.7446			
17			2.9531	2.8006		.7621	
18			2.4768	2.8753		.8573	.5601
19	.7468		2.191		.8573	.9526	.9149
20	.8775		2.191		1.0479		.9522
21	1.0082		1.9052		.9526		1.0185
22			1.7147		.8573	.9526	.9149
23			1.6194		.8573	.8573	.7468
24	.7621	.8215	1.8099	.5716	1.3937	1.0479	.9526
Max	2.782	2.6513	2.9531	2.8753	1.8111	2.7625	2.4768
Min	.7468	.8215	.6668	.5716	.8573	.7621	.5601
Avg	1.4973	1.4773	1.5305	1.4812	1.1110	1.6121	1.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134043 / DHARKALYAN****Feeder No / Name : 204 / KOTHARI EXP****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0189	.0191	.0191		.0191	.0191
2	.0191	.0189	.0191	.0191		.0191	.0191
3	.0191	.0189	.0191	.0191		.0191	.0191
4	.0191	.0189	.0191	.0191		.0191	.0191
5	.0191	.0189	.0191	.0191		.0191	.0191
6	.0191	.0189	.0191	.0191		.0191	.0191
7	.0191	.0189	.0191	.0191		.0191	
8	.0191	.0189	.0191	.0189		.0191	
9				.0181	.0181	.0191	
10			.0191	.0181	.0187	.0191	
11	.0189		.0191	.0181	.0191	.0191	
12	.0189		.0191	.0181	.0191	.0191	
13	.0189		.0191	.0187	.0191	.0191	
14	.0189		.0191	.0189	.0191	.0191	
15	.0189		.0191	.0189	.0191	.0191	
16	.0189		.0191	.0189		.0191	.0189
17	.0189		.0191	.0189	.0191	.0191	.0189
18	.0189		.0191	.0189	.0191	.0191	.0189
19	.0187		.0191		.0191	.0191	.0189
20	.0189		.0191		.0191	.0191	.0189
21	.0189		.0191		.0191	.0191	.0189
22			.0191		.0191	.0191	.0189
23			.0191		.0191	.0191	.0189
24	.0191	.0189	.7164	.0191	.0189	.0191	.0191
Max	.0191	.0189	.7164	.0191	.0191	.0191	.0191
Min	.0187	.0189	.0191	.0181	.0181	.0191	.0189
Avg	.0190	.0189	.0494	.0188	.0190	.0191	.0190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134043 / DHARKALYAN

Feeder No / Name : 205 / GAWALI POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3815	2.0538	1.5242	1.3336		1.1431	.9526
2	2.2862	2.0538	1.5242	1.3336		1.2384	.9526
3	2.2862	2.1472	1.6194	1.3336		1.3336	1.1431
4	2.4768	2.2405	1.6194	1.4289		1.5242	1.1431
5	2.4768	2.3577	1.7147				
6	2.572	2.4646	1.7147		.7282		
7	2.6673	2.5339					
8			2.4768	2.0538			
9				2.9874			
10			3.3341	3.1741			
11			3.1436	2.9127			
12			3.2388	3.0807			
13			3.2388	2.8006			
14			2.8578	3.4541			
15			2.8578	3.5475			
16						2.4768	.3361
17					3.1436	2.8578	.4668
18					3.2388	2.8006	1.6057
19	.6348		1.5242		2.7625	2.3815	1.4003
20	.7842		1.5242		2.572	2.2862	1.2136
21	1.0082		1.4289		2.2862	2.191	1.1506
22					2.191	1.9052	1.1576
23			1.4289		2.0005	1.829	1.307
24	2.4768	1.1222	1.5402	1.3336	1.2136	1.1431	1.1431
Max	2.6673	2.5339	3.3341	3.5475	3.2388	2.8578	1.6057
Min	.6348	1.1222	1.4289	1.3336	.7282	1.1431	.3361
Avg	2.0046	2.1217	2.1284	2.3672	2.2374	1.9316	1.0748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134043 / DHARKALYAN****Feeder No / Name : 206 / PIRKALYAN****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.8671	.2477	.2858		.2858	.2286
2	1.5242	2.0538	.2477	.2858		.381	.2858
3	1.7147	2.0538	.2858	.381		.381	.2858
4	1.7147	2.0538	.381	.381		.381	
5	1.9052	2.2218	.381				
6	1.9052	2.2405	.5335		.3547		
7	2.0957	1.9605					
8			1.7147	1.5242			
9				1.4937	.2075		
10			2.2481	2.452			
11			2.4768	2.4331			
12			2.6673	2.3954			
13			2.6673	2.3152			
14			2.6673	2.5463			
15			2.2862	2.6139			
16						1.7147	.2075
17					2.2862	1.8099	.2641
18					2.3815	1.9052	.3961
19			.381		2.191	1.7147	.0187
20	.5093		.381		2.0957	1.6194	.3584
21	.5658		.381			1.5242	.0189
22			.2858			1.4289	.2075
23			.2858		1.6194	1.2765	.0189
24	1.5242	.9242	1.5203	.2858		.2858	.2286
Max	2.0957	2.2405	2.6673	2.6139	2.3815	1.9052	.3961
Min	.5093	.9242	.2477	.2858	.2075	.2858	.0187
Avg	1.4983	1.9219	1.1600	1.4918	1.5909	1.1314	.2099

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S****Feeder No / Name : 201 / BAWNEPANGRI-AG****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	2.8959	.823	.8573	1.0974	.4706	.1848
2	1.2803	2.8959	.823	.8573	1.0974	.4706	.1848
3	1.4632	2.5339	.823	1.0288	1.0974	.362	.1848
4	1.4632	2.8959	.9145	1.3717	1.1888		
5	1.829	3.0769	1.1888	1.7147	1.2803		
6	2.0119	3.0769	1.6644	2.0576	1.4632		
7	2.1948	2.7149	2.0119	2.3148	1.6461		
8	2.5606	2.8959	2.6886	2.7435	1.6461		
9		2.7149					.6584
10						1.7375	.9511
11						1.9204	1.39
12						2.0485	1.5546
13						2.1033	1.6461
14						2.2862	1.6095
15						2.1033	1.6644
16						1.8656	1.6461
17						1.5364	
19	.7133	.1848	.2572	.1829		.1848	.1848
20	.7133	.1848	.2572	.1829	.5249	.1848	.1848
21	.6516	.1848	.2572	.2743	.3982	.1848	.1294
22	.4525	.1848	.1715	.2743	.3982	.1848	.1294
23	.4525	.1848	.1715	.2743	.4525	.1848	.1294
24	.4525		1.4899	.1829	.4525		.1848
Max	2.5606	3.0769	2.6886	2.7435	1.6461	2.2862	1.6644
Min	.4525	.1848	.1715	.1829	.3982	.1848	.1294
Avg	1.2383	1.9018	.9673	1.0227	.9802	1.1143	.7422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S

Feeder No / Name : 202 / MANDEULGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.362	.1848	.1715	.1829	2.5339	1.4632
2	.3658	.362	.1848	.1715	.3658	2.5339	1.4632
3	.3658	.543	.1848	.1715	.3658	2.7149	1.4632
4				.1715		2.9264	1.5546
5						3.2579	1.6461
6						3.2579	1.8107
7						3.0769	2.2497
8						3.1093	2.6703
9						2.8959	
10	2.8959	3.5665	2.0576		1.8099		
11	3.2922	3.4751	2.9531	2.9264	2.7149		
12	3.0769	3.3653			2.7435		
13	3.4751	3.3653			2.8959		
14	3.4389	3.3653		3.4751	2.8959		
15	3.2922	2.9813		3.2922	2.5339		
16	3.0769	2.9264			2.3529		
17	3.2922	1.9753	2.8292	3.2922	2.3777		
19	.543	.1848	.2572	.2743	.362	.1848	.1848
20	.543	.1848	.2572	.2743	.362	.1848	.1848
21	.543	.1848	.1715	.3658	.3982	.1848	.1478
22	.5487	.1848	.1715	.3658	.3982	.1848	.1478
23	.543	.1848	.1715	.3658	.4525	.1848	.1478
24	.4525		.1848	.2743	.4525		.1848
Max	3.4751	3.5665	2.9531	3.4751	2.8959	3.2579	2.6703
Min	.2743	.1848	.1715	.1715	.1829	.1848	.1478
Avg	1.7658	1.7007	.8007	1.1137	1.3920	1.9451	1.0942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S****Feeder No / Name : 203 / MANDEULGAON GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.362	.4572	.2572	.2743	.362	.462
2	.3658	.362	.4572	.2572	.2743	.362	.462
3	.4572	.4525	.4572	.2572	.2743	.3475	.462
4	.5487	.543	.5487	.4287	.3658	.5304	.462
5	.7316	.2896	.6401	.6001	.4572	.2715	.5544
6	.823		.6401	.7716	.5487	.2743	.6468
7	1.0059	.2896	.823	.7716	.7316	.4344	.823
8	.7316	.5249	.4938	.6859	.5487	.4344	.6584
9	.5487	.3801	.6036	.6001	.3658	.362	.6584
10	.362	.3292	.4287		.6401	.3696	.5487
11	.2743	.2743	.3429	.3292	.4938	.462	.3658
12	.3658	.2772	.2572	.3292	.4938	.2772	.2772
13	.2561	.2772	.1715	.3658	.4706	.2218	.2772
14	.3109	.2772		.3658	.5249	.2402	.2218
15	.3841	.2218		.2743	.2715	.2218	.2402
16	.362	.3696			.2715	.5121	.2402
17	.2715	.6036	.5144	.5487	.4887	.5121	.2402
18	.543	.823	.8573	.5487	1.086	.7865	.823
19	.543	.7316	.7716		.362	.823	.9145
20	.543	.6401	.6001	.7316	.362	.6401	.5487
21	.543	.5121	.4287	.5487	.3982	.567	.5544
22	.543	.4572	.4287	.3658	.3982	.462	.3696
23	.543	.4572	.3429	.2743	.4525	.462	.2772
24	.4525		.4572	.2743	.4572		.462
Max	1.0059	.823	.8573	.7716	1.086	.823	.9145
Min	.2561	.2218	.1715	.2572	.2715	.2218	.2218
Avg	.4948	.4298	.5106	.4565	.4588	.4320	.4812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134046 / BAWANE PANGRI 33/11 KV S/S****Feeder No / Name : 204 / BAWANE PANGHARI GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	01-DEC-17	02-DEC-17
HR	Load (MW)	Load (MW)
1		.1715
2		.1715
3		.1715
4		.1715
5		.2572
6		.3429
7		.4287
8		.3429
9	.2572	.3429
10	.1715	
11	.1715	
12	.0857	
13	.0857	
14	.0857	
15	.0857	
16	.1715	
17	.1715	
18	.3429	
19	.4287	
20	.2572	
21	.2572	
22	.1715	
23	.1715	
24		.1715
Max	.4287	.4287
Min	.0857	.1715
Avg	.1943	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134059 / DAMBRI****Feeder No / Name : 201 / VIREGAON****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.9114
Max	.9114
Min	.9114
Avg	.9114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134059 / DAMBRI****Feeder No / Name : 203 / DAMBRI****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.9114
Max	.9114
Min	.9114
Avg	.9114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134062 / MANEGAON****Feeder No / Name : 201 / MANEGAON****Feeder KV- 11 / OUTGOING****SHEDDABLE RURAL**

DATE	02-DEC-17
HR	Load (MW)
23	.1334
Max	.1334
Min	.1334
Avg	.1334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407]

BU 2721

Substation No/ Name :- 134062 / MANEGAON

Feeder No / Name : 202 / PAREGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1715	.2286	.1715	.1143	.1524
2	.1905	.1715	.1715	.2286	.1715	.1143	.1905
3	.1905	.1715	.1905	.2286	.1715	.1143	.2286
4	.1905	.1905	.1905	.2858	.1905	.1524	.2667
5	.2858	.2667	.2096	.3048	.2858	.1715	.2858
6	.3429					.2286	.3048
7	.381					.3239	.3429
8	.362						.3429
9	.362						
10	1.0669	1.0669	1.0098	1.086	.2286		
11	1.3717	1.448	1.2955	.1143	.1905		
12	1.4098	1.3336	1.3908	.1143	.1524		
13	1.3336	1.4289	1.3336	.1143	.1334		
14	1.2384	1.3717	1.1812	.1143	.1334		
15		1.2384	1.0288	.1143	.1334	.1524	
16	1.086	1.1431	1.0479	.1524	.1524	.1334	.1334
17	.9717	1.1431	.724	.1524	.1715	.1715	
18						.2096	
19						.2286	
20	.1905	.2286	.2667	.2096	.2286	.2286	.2477
21	.2096	.2286	.2667	.1905	.2286	.2286	.2096
22	.2096	.2096		.1715	.2096	.2096	.1905
23	.1905	.2096	.2667	.1715	.1905	.1905	.1715
24	.1524	.1905		.2286	.1715	.1715	.1715
Max	1.4098	1.448	1.3908	1.086	.2858	.3239	.3429
Min	.1524	.1715	.1715	.1143	.1334	.1143	.1334
Avg	.5679	.6785	.6716	.2339	.1842	.1849	.2313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134062 / MANEGAON****Feeder No / Name : 203 / SAWANGI FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2477	.2667	.381	.2667	.2286	.2858
2	.2858	.2477	.2667	.381	.2667	.2286	.2858
3	.2858	.2477	.3048	.4763	.3429	.2286	.3429
4	.2858	.2858	.3429	.5335	.5716	.2667	.381
5	.4191	.6287	.381	.6097	.6478	.3429	.4572
6	.5716					.4001	.5525
7	.724					.4191	.5906
8	.724					.3239	.5906
9	.724						
10	1.5051	1.6766	1.5242	1.6194	.4572		
11	1.7528	1.8099	1.848	.1524	.381		
12	1.9433	1.6194	1.9814	.1905			
13	1.7147	1.7147	1.9052	.1524			
14	1.7718	1.7528	1.829	.1524	.1715		
15		1.829	1.848	.1524	.1715	.2477	
16	1.7909	1.9052	1.848	.362	.1905	.362	1.6766
17	1.6766	1.7337	1.4861	.381	.3429	.4763	.4572
18						.6668	.6097
19						.5144	.6859
20	.3429	.381	.4763	.3239	.4572	.4763	.4572
21	.2667	.381	.4191	.2858	.4001	.4191	.3048
22	.2667	.3429	.381	.2286	.3048	.381	.2858
23	.2477	.3048	.381	.2286	.3048	.3429	.2858
24	.2477	.2667		.3429	.2667	.2477	.2667
Max	1.9433	1.9052	1.9814	1.6194	.6478	.6668	1.6766
Min	.2477	.2477	.2667	.1524	.1715	.2286	.2667
Avg	.8492	.9653	1.0288	.3863	.3465	.3652	.5009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407]****BU 2721****Substation No/ Name :- 134089 / Bhatepuri****Feeder No / Name : 201 / WADIWADI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1886	.1829	.1886	.1829	.0943	.1829
2	.1829	.1886	.1829	.1886	.1867	.0943	.2743
3	.1829	.1886	.2743	.1886	.2801	.0943	.2743
4	.2743	.1886	.3658	.1886	.2801	.1886	.3658
5	.3658	.2829	.3658	.1886	.3658	.1886	.3658
6	.3658	.3772	.3544	.2829	.5487	.2829	.4572
7	.2743	.2829	.3658	.2829	.3658	.2829	.3658
8	.2743	.2829	.5487	.2829	.3658	.2829	.3658
9	.2829	.2829	.2743	.2829	.2743	.1886	
10	.1886	.1886	.1867	.2743	.1829	.1829	
11	.1886	.2743	.1886	.2743	.0943	.0914	
12	.1886	.1829	.1886		.0943		
13	.0943	.1829					
14	.0943	.1829	.1886				
15	.0943	.1829	.0943	.1829	.0943		.1829
16	.0943	.2743	.0943	.2743	.0943		.1829
17		.2743	.1886	.2743	.1886		.1829
18	.2829	.4572	.2829	.4572	.1886		.1829
19	.3772	.4572	.3772	.4572	.2829	.4572	.2743
20	.2829	.3658	.2829	.3658	.1886	.3658	.3658
21	.2829	.2743	.1886	.2743	.0943	.3658	.3658
22	.1886	.1829	.1886	.1829	.0943	.2743	.2743
23	.1886	.1829	.1886	.1829	.0943	.2743	.1829
24	.2743	.1886	.1829	.1886	.1829	.0943	.1829
Max	.3772	.4572	.5487	.4572	.5487	.4572	.4572
Min	.0943	.1829	.0943	.1829	.0943	.0914	.1829
Avg	.2264	.2548	.2494	.2602	.2148	.2237	.2794

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]

JALNA CIRCLE[625]

JALNA DIVISION I[271]

JALNA (R) S/DN[407] BU 2721

Substation No/ Name :- 134089 / Bhatepuri

Feeder No / Name : 202 / WADIWAI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1391	.2782
2						.1391	.2782
3						.1391	.3477
4						.1391	.3525
5						.1391	.3525
6						.2086	.3525
7						.2782	.423
8						.3477	.4868
10	1.0717	.9412	.8459	1.1431	.2782		
11	1.2689	1.286	1.1126	1.2146	.3477		
12	1.4803	1.3575	1.3213		.4172		
13	1.1279	1.3575	1.1126				
14	1.3394	1.2146	1.0431		.4172		
15	1.3032	1.2146	1.1822	.3572	.4172		
16	1.3756	1.0717	1.1126	.3572	.4172		
17	1.3032	1.0002	.8345	.3572	.3477		
Max	1.4803	1.3575	1.3213	1.2146	.4172	.3477	.4868
Min	1.0717	.9412	.8345	.3572	.2782	.1391	.2782
Avg	1.2838	1.1804	1.0706	.6859	.3775	.1913	.3589

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

AURANGABAD ZONE[067]**JALNA CIRCLE[625]****JALNA DIVISION I[271]****JALNA (R) S/DN[407] BU 2721****Substation No/ Name :- 134089 / Bhatepuri****Feeder No / Name : 203 / BHATEPURI AG****Feeder KV- 11 / OUTGOING****FEEDER SEPERATION/PURE AG**

DATE	01-DEC-17
HR	Load (MW)
24	.9015
Max	.9015
Min	.9015
Avg	.9015