

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304009 / 33 KV PARAWA

Feeder No / Name : 201 / 11 KV Parawa Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0736	.0552	.0368		.0736	
2		.092	.0736	.0368		.0736	
3		.0736	.0552	.0368		.0736	
4		.092	.0736	.0368		.0736	
5		.092	.0552	.0368		.0736	
6		.1104	.0736	.0368		.0736	
7		.1288	.0552	.0368		.0736	
8		.1288		.0368		.0552	
9		.1104	.0736	.0552	.0736	.0552	
10	.0736	.092	.0552		.0736		
11	.0736	.2209	.0552		.0552		
12	.0736	.184	.0736		.0736	.0368	
13	.0736	.0368	.0552		.0736		
14	.092	.0736	.0552		.0736		
15	.1104	.092	.0368		.0736		
16	.1104	.1472	.0736	.0736	.0736	.0552	
17	.1472	.0736	.1104	.0736	.0736	.0368	
23							.865
24		.0552	.0552	.0368		.0552	
Max	.1472	.2209	.1104	.0736	.0736	.0736	.865
Min	.0736	.0368	.0368	.0368	.0552	.0368	.865
Avg	.0943	.1043	.0639	.0445	.0716	.0623	.865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304009 / 33 KV PARAWA

Feeder No / Name : 202 / 11 KV Jamb Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0977	.1303	.1466			
2	.0977	.0977	.1303			
3	.0977	.114	.114			
4	.114	.114	.1466			
5	.1303	.1303	.1303			
6	.1466	.1466	.1466			
7	.1955	.1466	.1629			
8	.1955	.1792	.1466			
9	.1792	.1792	.1303			
10			.2443		.2769	
11			.2606		.3095	
12			.2932		.3095	.0814
13			.3258		.3095	
14			.3421		.1303	
15			.3584		.1466	
16			.3258	.1303	.1466	.1303
17			.2932	.1303	.1792	.1303
24	.0977	.0814	.1466			
Max	.1955	.1792	.3584	.1303	.3095	.1303
Min	.0977	.0814	.114	.1303	.1303	.0814
Avg	.1352	.1319	.2136	.1303	.2260	.114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304009 / 33 KV PARAWA

Feeder No / Name : 205 / 11 KV Jamb Goathan

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.3921	.4854	.4854	.9709	.8775	.4668
2	.4294	.4108	.5041	.9522	.9709	.8402	.4481
3	.3921	.4294	.4854	.9709	.8962	.7842	.4668
4	.3921	.3921	.4668	.9709	.8589	.7468	.4481
5	.3734	.3734	.4854	.9335	.8215	.7095	.4668
6	.3547	.3734	.4668	.8215	.8029	.6535	.3361
7	.2801	.2987	.3361	.6348	.6722	.5601	.2801
8	.2614	.2614	.2801	.5228	.5415	.4854	.2427
9	.2427	.2427	.2614	.5041	.5041	.4854	.2054
10	.2241		.2427		.4108		.168
11	.2241		.2427		.3734		.168
12	.2241	.2427	.2241		.3921	.3734	.1867
13	.2241	.2054	.2427		.3547		.1867
14	.2054	.2241	.2614		.4481		.1867
15	.2241	.2987	.2614		.4481		.168
16	.2054	.2987	.2614	.4108	.4481	.168	.168
17	.2054	.2801	.2614	.4108	.4854	.168	.168
18	.3361	.3361	.3361	.5415	.5601	.2241	.3174
19	.4108	.4668	.5041	.7095	.6535	.3734	.3547
20	.4481	.5601	.5415	.9335	.8215	.4668	.5228
21	.5041	.4294		1.0829	.8589	.4668	.6161
22	.5601	.4668	.5415	1.0642	.8962	.4854	.4668
23	.5228	.5041	.5228	1.0456	.8962	.4668	
24	.4481	.5415	.5041	.5041	1.0082	.8775	.4668
Max	.5601	.5601	.5415	1.0829	1.0082	.8775	.6161
Min	.2054	.2054	.2241	.4108	.3547	.168	.168
Avg	.3384	.3649	.3791	.7499	.6706	.5375	.3263

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304009 / 33 KV PARAWA

Feeder No / Name : 206 / 11 KV Kurli Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9896	1.0269	1.0456	1.0456	.4854	.4668	.9522
2	.9896	1.0082	1.0082		.4854	.4668	.9335
3	.9522	1.0456	1.0269		.4481	.4481	.9149
4	.9335	.9896	1.0642		.3734	.3734	.9149
5	.8962	.9335	1.0456		.3361	.3361	.9335
6	.8589	.8029	1.1016		.2801	.3547	.3547
7	.7095	.7282	.7468		.1867	.2987	.7095
8	.6535	.6348	.7282	.2427	.1867	.2801	.6535
9	.5788	.6348	.7095	.2241	.1867	.2801	.5975
10	.5041	.6161	.5975		.2427		.5228
11	.4668	.5415	.5975		.2801		.5041
12	.4668	.6535	.5975		.2987	.168	.4668
13	.4668	.6722	.6161		.3734		.5041
14	.4854	.7095	.5975				.4481
15	.5228	.6908	.6161		.2801		.3547
16	.5228	.6348	.6161	.2427	.2054	.3734	.5041
17	.5601	.6908	.5975	.2801	.2427	.4481	.5601
18	.7095	.7095	.7095	.3734	.3547	.4854	.7282
19	.8215	.8962	1.0269	.4108	.3921	.8402	.8215
20	.8775	.9896	1.1389	.4854	.4668	.9709	.9149
21	.9709	1.0082	1.1203	.5601	.4481	.9335	.9896
22	1.1016	.9896	1.1203	.5415	.4668	.9335	.4854
23	1.0269	1.0456	1.0829	.5228	.4668	.9335	.4668
24	1.0082	1.0456	1.0122	1.0269	.5041	.4481	.9149
Max	1.1016	1.0456	1.1389	1.0456	.5041	.9709	.9896
Min	.4668	.5415	.5975	.2241	.1867	.168	.3547
Avg	.7531	.8208	.8551	.4963	.3474	.5179	.6729



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 201 / 11 KV Runza Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.9335	.8916			
2	.5601	.9522	.9896			
3	.6348	.9522				
4	.7095	.9709		1.1576		
5	.7468	.9709				
6	.7655	.9709				
7	.8775	1.363				
8	1.0082	1.5123				
9	.703	1.4937	1.1203			
10			1.5684	.9149		
11				.9335	.9709	.9335
12				.9149	1.1576	1.0082
13				.9335	1.1203	1.0082
14				.9709	.9896	
15			1.4563	1.0269	1.0829	
16				.9774	1.2323	1.0082
17			1.4937	1.2883	1.1949	.9896
18			1.531	.7468	1.1576	.9522
19			1.1389	.6722		.9896
21			.5601			
22			.5975			
23			.6348			
24	.4854	.9335	.9709			
Max	1.0082	1.5123	1.5684	1.2883	1.2323	1.0082
Min	.4854	.9335	.5601	.6722	.9709	.9335
Avg	.7051	1.1053	1.0794	.9579	1.1133	.9842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 202 / 11 kv Metikheda Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1867		.0373	
2			.1867		.0373	.0373
3			.2054		.0373	.0373
4			.4108		.0373	.0373
5			.2241		.0373	.0373
6			.2241		.056	.0373
7			.3174		.0747	.0373
8			.3734		.1494	.0373
9					.1307	
10	.2054	.0747				.0373
11	.2801	.2801				.0373
12	.3361	.5041		.0747		.056
13	.2801	.4108		.0934		
14	.2427	.3921		.112		.0934
15	.2054	.3734		.1494		.0934
16	.1494	.3734		.168		.1494
17	.1307	.3547		.1867		.1307
18	.1307			.1867		
19				.056		
24			.0934	.0934	.0373	
Max	.3361	.5041	.4108	.1867	.1494	.1494
Min	.1307	.0747	.0934	.056	.0373	.0373
Avg	.2178	.3454	.2469	.1245	.0635	.0613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 203 / 11 KV Loni Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2987	.3086	.0187	.0373	.0187	.0373
2	.2054	.2987	.3547	.0187	.0373	.0187	.0373
3	.2054	.2987	.3547	.0187	.0373	.0187	.0373
4	.2054	.3361	.3734	.0187	.0373	.0187	.0373
5	.2054	.3547	.3734	.0187	.0373	.0187	.0373
6	.2054	.3547	.3921	.0187	.0373	.0187	.0373
7	.3361	.5788	.3921	.0187		.0187	.0373
8	.3921	.5975	.3921	.0187	.0373	.0187	.0373
9	.3734	.5601	.5601	.0373	.0373	.0187	.0373
10		.0187	.5788		.2801	.2427	.0187
11	.0373	.0187		.2427	.4108	.1494	.0187
12	.0373	.0187		.3174	.5228	.2614	.0187
13	.0373	.0187		.4108	.0373	.4481	.0187
14	.0373	.0187		.4294	.0373		.0187
15	.0373			.4108	.4108		.0187
16	.0373			.3944	.4854	.2987	.0187
17	.0187	.0373	.3734	.4481	.5228	.2614	.0187
18	.0187	.0343	.4668	.0373	.0187	.0373	.0187
19	.0187	.0373	.3547	.0373	.0187	.056	.0187
20	.0187	.0373	.0187		.0187	.0373	.0187
21	.0187	.0373	.0187		.0187		.0187
22	.0187	.0373	.0187		.0187	.0373	.0187
23	.0187	.0373	.0187	.0373	.0187		.0187
24	.2054	.2801	.3361	.0187	.0373	.0187	.0373
Max	.3921	.5975	.5788	.4481	.5228	.4481	.0373
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.1258	.1959	.3159	.1486	.1372	.1008	.0265

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 204 / 11 KV Loni Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5601	.5601	.5228	.5601	.5041	.5228
2	.5228	.5601	.5601	.5228	.5041	.5041	.5041
3	.4668	.5228	.5601	.4668	.5041	.4854	.5041
4	.4668	.5228	.5041	.4668	.5041	.4854	.4668
5	.4108	.4854	.5041	.4294	.4668	.4481	.4668
6	.3734	.4854	.4668	.4294	.4481	.4481	.4481
7	.3734	.4668	.4294	.4108	.4294	.4108	.4108
8	.3547	.4668	.3921	.3734	.4108	.4108	
9	.3086	.4668	.3734	.3547		.3361	.3734
10	.3547	.4108	.3361	.3361		.2987	.3174
11	.3361	.4108		.3174	.2614	.2614	.2614
12	.3361	.3734		.3361	.2241	.2427	.2614
13	.3547	.3734		.3174	.2427	.2614	.2427
14	.3734	.3921		.3174	.2614		.1867
15	.4108	.3734		.3174	.2614		.2427
16	.4294	.3174		.3174	.2614	.2427	.2241
17	.3734	.3601	.3734	.3174	.3547	.2987	.2614
18	.4668	.463	.4108	.4108	.3921	.3361	.3361
19	.6161	.5415	.5041	.5415	.5041	.5228	.3547
20	.6348	.5601	.5041	.5601	.5601	.5601	.3547
21	.6348	.5788		.5788	.5601	.5975	.3734
22	.6161	.5601	.5041	.5788	.5601	.5415	.3921
23	.5788	.5788	.4854	.5788	.5228	.5415	.3921
24	.5228	.5601	.5601	.5228	.5601	.5041	.5228
Max	.6348	.5788	.5601	.5788	.5601	.5975	.5228
Min	.3086	.3174	.3361	.3174	.2241	.2427	.1867
Avg	.4516	.4746	.4723	.4302	.4252	.4201	.3661

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 205 / 11 KV Metikheda Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.4668	.3921	.3921	.4481	.4108	.3734
2	.4294	.4854	.3921	.3921	.4481	.4108	.3734
3	.4108	.4481	.3921	.3734	.4481	.3921	.3734
4	.3921	.4481	.3921	.3734	.4294	.3921	.3547
5	.3734	.4108	.3921	.3547	.4294	.3734	.3547
6	.3547	.4108	.4108	.3547	.4108	.3734	.3547
7	.3547	.3921	.3921	.3361	.4108	.3734	.3361
8	.2987	.3734	.3921	.3361	.4108	.3361	.3361
9	.3174	.3361	.3734	.3361		.3361	.2987
10	.2987	.2987	.3361	.3361		.2987	.2801
11	.3174	.2614		.3174	.2614	.2614	.2241
12	.3361	.2614		.3174	.2614	.2241	.2427
13	.3174	.2801		.3174	.2614	.1867	.2241
14	.3361	.2987		.3174	.2427		.2614
15	.3174	.2801	.2987	.3174	.2427		.2987
16	.3361	.2801	.2801	.3174	.2427	.2427	.2614
17	.2801	.2987	.2987	.3174	.3361	.2801	.2801
18	.3174	.3361	.3174	.3734	.3734	.2987	.3361
19	.4668	.3734	.3921	.4294	.4481	.3921	.3921
20	.4854	.3734	.3921	.4481	.4481	.3734	.3734
21	.5041	.3921	.3921	.4668	.4668	.3921	.3361
22	.4668	.3734	.3921	.4481	.4668	.4108	.3361
23	.4854	.3921	.3921	.4481	.4481	.3734	.3361
24	.4294	.4668	.3921	.3921	.4481	.4108	.3734
Max	.5041	.4854	.4108	.4668	.4668	.4108	.3921
Min	.2801	.2614	.2801	.3174	.2427	.1867	.2241
Avg	.3773	.3641	.3706	.3672	.3811	.3429	.3213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304015 / 33 KV MOHADA

Feeder No / Name : 206 / 11 KV Runza Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2136	1.2696	1.3256	1.1203	1.307	1.251	1.251
2	1.2136	1.2696	1.3256	1.1203	1.307	1.2323	1.251
3	1.1763	1.2323	1.3256	1.1576		1.2323	1.251
4	1.1763	1.2323	1.3443	1.1576	1.2883	1.2323	1.2136
5	1.1389	1.2696	1.3443	1.1949	1.2883	1.251	1.2136
6	1.1389	1.2883	1.363	1.2696	1.2696	1.2696	1.1389
7	1.1763	1.3817	1.419	1.1949	1.307	1.2696	1.1949
8	1.2696	1.307	1.4937		1.3256	1.251	1.2696
9	1.0631	1.2696	1.1949	1.0642		1.1576	1.1203
10	1.1016	1.1576	1.0829	.9522		.9335	1.0456
11	.9896	1.1203		.9149	.7842	.7842	.9335
12	.8962	.9522		.8029	.7468		.8962
13	.8215	.9335		.7095	.7468		.1867
14	.7842	.9335		.7468	.7842		.6348
15	.4668	.9335	.9709	.7842	.7842		.6348
16	.4481	.4294		.8215		.7095	.7842
17	.9522	.6535	.9709	.8775		.7842	.7468
18	1.0642	1.251	1.1949	1.2883	1.2696	.9335	
19	1.3817	1.3256	1.531	1.587	1.531	1.2136	.9709
20	1.587	1.4003	1.4937	1.4377	1.4937	1.3443	
21	1.4937	1.419	1.4003	1.4003	1.3817	1.4003	
22	1.2407	1.3443	1.3443	1.3443	1.3443	1.307	.5601
23	1.3256	1.3256	1.307	1.307	1.2883	1.251	.6535
24	1.2136	1.2696	1.3256	1.1203	1.307	1.251	1.251
Max	1.587	1.419	1.531	1.587	1.531	1.4003	1.2696
Min	.4481	.4294	.9709	.7095	.7468	.7095	.1867
Avg	1.0972	1.1654	1.3030	1.1032	1.1871	1.1529	.962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304054 / 33 KV KUMBHARI

Feeder No / Name : 201 / 11 KV Kumbhari Ag  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.037	.1524	.0514	.1677		
2	.0343	.037	.1505	.0514	.2012		
3	.0343		.1486	.0514	.2572		
4			.216	.0514	.2683		
5			.2469	.0514	.3429		
6			.2743	.0514	.3429		
7			.4268	.0514	.3605		
8			.431	.0514	.4096		
9			.4115	.0514	.4372		
10	.2658	.3048		.208		.2126	.0372
11	.2303	.381		.2623		.3224	.3102
12	.2686	.5468		.3277			.3462
13	.2835	.4877		.3441			
14	.3045	.4458		.3601			.3269
15	.3142	.4458		.3125			.3227
16	.2987	.4214		.2683	.0754		.3612
17	.2987	.4877		.2622	.0566	.2721	
18	.037	.0503		.0686	.0566	.3241	
19	.0373	.0686	.0671	.0686	.0566	.2439	
20	.037	.0514	.0671	.0686	.0566		
21	.0373	.052	.0671	.0492	.0754		
22	.037	.0351	.0671	.0497			
23	.0373	.0339	.0671	.0492	.037		
24	.017	.0373	.1372	.0503	.1638		
Max	.3142	.5468	.431	.3601	.4372	.3241	.3612
Min	.017	.0339	.0671	.0492	.037	.2126	.0372
Avg	.1448	.2308	.1954	.1338	.1980	.2750	.2841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304054 / 33 KV KUMBHARI

Feeder No / Name : 202 / 11 KV Pandhurna Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457		.0171	.0156	.0328		
2	.0469		.0171	.0156	.0328		
3	.0434		.0171	.0156	.0328		
4	.0594						
5	.0594						
6	.0434						
7	.0579						
8	.0572	.2054					
9	.0869	.2402					.0526
10			.3199		.0743		.0812
11			.4816	.4784	.1017		.1014
12			.4458	.4744	.3721		
13			.3715	.4915	.4656		
14			.535	.4199	.543		.0695
15			.5796	.4572	.5487		.2572
16		.0974		.4588	.4805	.104	.3475
17		.1543		.4214	.5121	.2972	
18	.0886	.1524	.5498	.0312	.0554	.3567	
19		.1355	.423	.0343	.0754	.2858	
20		.0171	.0149	.0328	.0377		
21		.017	.0149	.0324	.0189		
22		.0173	.0149	.0328			
23		.0168	.0156	.0332			
24	.0168		.017	.0156	.0332		
Max	.0886	.2402	.5796	.4915	.5487	.3567	.3475
Min	.0168	.0168	.0149	.0156	.0189	.104	.0526
Avg	.0551	.1053	.2397	.2036	.2136	.2609	.1516



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304054 / 33 KV KUMBHARI

Feeder No / Name : 203 / 11 KV Shirolgi Gaathan

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3142	.2896	.2865	.3258		.2926
2	.2926	.3109	.2715	.2865	.3292		.2926
3	.2896	.3077	.2715	.2865	.3109		.2926
4	.2715	.3109	.2743	.2686	.3077		.2743
5	.2715	.3142	.2587	.2686	.2715		.2561
6	.2172	.2801	.2614	.2686	.2686		.2378
7	.2172	.2743	.2402	.2328	.2279		.2195
8	.1829	.2587	.2534	.197	.1991		.2012
9	.181	.2561	.2328	.181	.1629	.168	.2012
10	.1646	.2149	.2402	.1629	.2012	.1478	.1663
11	.1663	.1949	.2149	.1267	.1663	.0934	.1294
12	.1867	.1753	.197	.1254	.168	.0924	.1086
13	.2218	.2126	.1267	.1267	.1463	.0924	.1097
14	.197	.2454	.1267	.1402	.1294	.0924	.128
15	.2012	.1753	.1448	.1612	.1267	.1109	.1267
16	.2033	.2303	.1629	.1629	.128	.1097	.124
17	.2054	.2507	.1267	.1829	.1478	.128	.1294
18	.2772	.2658	.2172	.2353	.1494	.1829	.2033
19	.2926	.3258	.3224	.3326	.3142	.2743	.2926
20	.3142	.4066	.3224	.3658	.3361	.3292	.2772
21	.3174	.3841	.3045	.3801	.3326	.3292	.3142
22		.3326	.3045	.3658	.3547	.3292	.3142
23	.3547	.3292	.2865	.3326	.3326	.3109	.2987
24	.3109	.3475	.3109	.2865	.3258		.3109
Max	.3547	.4066	.3224	.3801	.3547	.3292	.3142
Min	.1646	.1753	.1267	.1254	.1267	.0924	.1086
Avg	.2456	.2799	.2401	.2402	.2401	.1860	.2209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304054 / 33 KV KUMBHARI

Feeder No / Name : 204 / 11 KV Anji Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2427	.2561	.2896	.2926		.2561
2	.3292	.2402	.2378	.2715	.2957		.2561
3	.2957	.2402	.2378	.2715	.3077		.2561
4	.3142	.2402	.2402	.2715	.2865		.2561
5	.3109	.2218	.2402	.2715	.2715		.2561
6	.2561	.2218	.2218	.2715	.2715		.2378
7	.2561	.2241	.2012	.2353	.2353		.2195
8	.2172	.1867	.181	.2172	.2195		.2012
9	.197	.1663	.1629	.181	.2012	.1663	.1646
10	.1267	.1629	.1646	.1629	.1448	.1307	.1478
11	.1402	.1433	.1448	.1267	.1663	.112	.1109
12	.1433	.1612	.1267	.128	.1646	.1294	
13	.1448	.1417	.1086	.1267	.1417	.128	.128
14	.1402	.1254	.1086	.0895	.1433	.1463	.1086
15	.1372	.1612	.1086	.1254	.1417	.1463	.1086
16	.1578	.1433	.1448	.1254	.1417	.1463	.0886
17	.1526	.1433	.1267	.1463	.1578	.1463	.128
18	.1886	.1772	.1629	.1829	.1867	.1463	.1646
19	.2303	.2534	.2715	.2896	.2402	.2195	.2378
20	.2279	.2957	.3077	.3224	.2801	.2926	.2218
21	.2561	.2715	.3077	.3189	.2926	.2926	.2402
22	.2587	.2561	.2896	.3077	.3142	.2926	.2587
23	.2801	.2587	.2896	.3109	.2987	.2743	.2402
24	.3292	.2587	.2587	.2896	.2896		.2743
Max	.3292	.2957	.3077	.3224	.3142	.2926	.2743
Min	.1267	.1254	.1086	.0895	.1417	.112	.0886
Avg	.2257	.2057	.2042	.2222	.2286	.1846	.1983

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304079 / 33 KV NEW GHATANJI

Feeder No / Name : 202 / 11 KV Ghatanji Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	2.0328	2.0485	1.9605	1.9004	1.7924	1.587
2	2.0328	1.9791	2.0119	1.9605	1.9387	1.8107	1.587
3	2.0165	1.9418	1.9185	1.9605	1.922	1.773	1.4575
4	1.9004	1.9418	1.8099	1.9605	1.8671	1.6804	1.587
5	1.97	1.8671	1.7737	1.8671	1.7924	1.6804	1.587
6	1.949	1.8484	1.7737	1.8671	1.8298	1.7741	1.6057
7	1.4632	1.7737	1.848	1.7364	1.5546	1.6448	1.6244
8	1.4998	1.6078	1.8111	1.6244	1.531	1.4784	1.4937
9	1.3575	.2829	1.6632	1.5154	1.4784	1.3535	1.3817
10	1.39	.2829	1.5181	1.5339	1.39	1.3306	1.2567
11	1.5497	.2829					1.2567
12	1.5364	1.9936		1.4449	1.2437	1.1827	1.1888
13	1.6827	1.7924		1.4632	1.2567	1.1827	1.2071
14	1.7193	1.7558			1.3306	1.1706	1.2071
15	1.7193	1.7193			1.3491	1.2382	1.2071
16	1.262	1.6832			1.39	1.2567	1.1765
17	1.7002	1.7558			1.3676	1.2752	
18	1.6461	1.7924	1.5581		1.4784	1.3535	1.2894
19	1.5912	1.848	1.885	1.7375	1.6632	1.6057	1.4937
20	2.0302	2.0513	2.0513	1.9404		1.7737	
21	2.0883	2.1033	2.1285	1.9753	1.8107	1.6617	
22	2.2916	2.1948		2.0538	1.9231	1.7353	1.4003
23	2.1658	2.1399	2.0725	2.0328	1.8671	1.6975	
24	2.0698	2.0538	2.0851	1.9978	2.0165	1.8298	1.587
Max	2.2916	2.1948	2.1285	2.0538	2.0165	1.8298	1.6244
Min	1.262	.2829	1.5181	1.4449	1.2437	1.1706	1.1765
Avg	1.7768	1.6969	1.8723	1.8129	1.6319	1.5340	1.4091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304079 / 33 KV NEW GHATANJI

Feeder No / Name : 203 / 11 KV Yelabara

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0171	.0177	.0189	.0183	.0171	.0171
2	.0171	.0173	.0173	.0189	.0179	.0168	.0171
3	.017	.0175	.0175	.0189	.0179	.0168	.0171
4	.0171	.017	.0173	.0189	.0181	.017	.0171
5	.0175	.017	.0173	.0189	.0179	.017	.0171
6	.0171	.017	.0175	.0189	.0185	.0171	.0171
7	.0175	.0173	.0171	.0189	.0185	.0171	.0171
8	.0181	.0173	.0173	.0187	.0187	.0185	.0177
9	.0171	.0168	.0173	.0187	.0183	.0175	.0177
10	.0175	.0177	.0173	.0187	.0181	.0171	.0183
11	.0173	.0175					.0171
12	.0173	.0168			.0173	.0171	.0171
13	.0171	.0183				.0171	.0171
14	.0183	.017				.0171	.0173
15	.0171					.0171	
16	.0173	.0168			.0173	.0171	
17	.0173	.0183			.0171	.0171	
18	.0171	.0183			.0173	.0171	.0171
19	.0173	.0187	.0171	.0187	.0171	.0171	.0171
20	.0173	.0173	.0189	.0185	.0171	.0171	
21	.0173	.0183	.0189	.0187	.0173	.0171	
22	.0171	.0175		.0185	.0173	.0171	.0171
23	.0171	.0171	.0189	.0183	.0175	.0171	
24	.0171	.0173	.0175	.0189	.0181	.0173	.0171
Max	.0183	.0187	.0189	.0189	.0187	.0185	.0183
Min	.017	.0168	.0171	.0183	.0171	.0168	.0171
Avg	.0173	.0174	.0177	.0188	.0178	.0172	.0172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304079 / 33 KV NEW GHATANJI

Feeder No / Name : 204 / 11 KV Sakhara Ag (Ght)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1204	.1562	.2126		.0362	.0366	.0373
2	.1337	.16	.2454		.0358	.0358	.0373
3	.1486	.16	.2774		.0362	.0358	.0373
4	.1158	.16	.3155		.0366	.0358	.037
5	.1783	.1875	.3544		.0358		.037
6	.2107	.2439	.3506		.0366	.037	.037
7	.2286	.4062	.3772		.0362	.0373	.037
8	.2172	.4687	.4115	.0366	.0362	.0377	.037
9	.301	.4687	.4854	.0732	.0373	.037	.037
10	.0358	.0175	.5201	.3292	.2606	.3125	.037
11		.0351					.0366
12	.0366	.0373			.3125	.3125	.0366
13	.0377	.0373			.3125	.3125	.0366
14	.0183				.3125	.3086	.0366
15	.0366	.0335			.3086	.3125	
16	.0366	.037				.3086	
17	.037	.037			.3795	.3311	.0366
18	.037	.037	.0625		.3795	.061	.0366
19	.0377	.0366	.0625	.0362	.032	.0305	.0171
20	.0309	.0366	.0312	.037	.032	.0305	
21	.0312	.0366	.0309	.0373	.032	.0373	
22	.0312	.0366		.0373	.032	.0373	
23	.0312	.0366	.0309	.0362	.0366	.0373	
24	.1524	.1562	.1829		.037	.0366	.0373
Max	.301	.4687	.5201	.3292	.3795	.3311	.0373
Min	.0183	.0175	.0309	.0362	.032	.0305	.0171
Avg	.0976	.1314	.2469	.0779	.1270	.1255	.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304079 / 33 KV NEW GHATANJI

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0185	.0183	.0179	.0183	.0189	.0181
2	.0185	.0183	.0183	.0179	.0179	.0189	.0181
3	.0187	.0185	.0179	.0179	.0183	.0189	.0181
4	.0183	.0183	.0179	.0179	.0185	.0187	.0181
5	.0181	.0185	.0179	.0179	.0185	.0187	.0181
6	.0179	.0185	.0177	.0179	.0183	.0189	.0181
7	.0181	.0189	.0175	.0179	.0183	.0185	.0181
8	.0183	.0183	.0175	.0179	.0185	.0189	.0181
9	.0179	.0189	.0177	.0179	.0187	.0183	.0183
10	.0179	.0183	.0177	.0179	.0183	.0189	.0366
11	.0183	.0183					.0183
12	.0183	.0183			.0189	.056	.0183
13	.0183	.0183				.0171	.0183
14	.0189	.0183	.0177			.0171	.0185
15	.0189	.037	.0354			.0343	
16	.0189	.037	.0177		.0189	.0354	
17	.0183	.0183	.0177		.0189	.0351	
18	.0185	.0183	.0177		.0189	.0175	
19	.0189	.0185	.0177	.0185	.0187	.0175	.0183
20	.0185	.0183	.0177	.0185	.0187	.0175	
21	.0185	.0183	.0177	.0187	.0187	.0175	
22	.0189	.0183		.0187	.0187	.0175	.0183
23	.0185	.0183	.0177	.0185	.0185	.0175	
24	.0185	.0189	.0183	.0177	.0187	.0173	.0181
Max	.0189	.037	.0354	.0187	.0189	.056	.0366
Min	.0179	.0183	.0175	.0177	.0179	.0171	.0181
Avg	.0184	.0200	.0187	.0181	.0186	.0220	.0193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304079 / 33 KV NEW GHATANJI

Feeder No / Name : 206 / 11 KV Sakhara Gaothan  
(Ght) Feeder KV- 11 /  
OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3361	.3841	.3696	.3658	.3361	.3475
2	.3258	.3326	.3658	.3696	.362	.3326	.3475
3	.3109	.3361	.3258	.3696	.3475	.3109	.3475
4	.3326	.3142	.3258	.3696	.3547	.3109	.3475
5	.3547	.3174	.3403	.3696	.3326	.3142	.3292
6	.3658	.3142	.3582	.3696	.3439	.3174	.3292
7	.3547	.3142	.3658	.3326	.3292	.3142	.3109
8	.2587	.2772	.3292	.2957	.2957	.3326	.2743
9	.2378	.2241	.2957	.0732	.2378	.2561	.2561
10	.2054	.2195	.2587	.2033	.1848	.1829	.1829
11	.1478	.1829	.2218				.1463
12	.1478	.2012	.1829		.1463	.1463	.128
13	.1463	.2012	.2012		.1294	.1463	.1463
14	.1463	.2012	.2012		.1294	.1646	.1646
15	.1848	.2012	.2012			.1463	
16	.1829	.1829	.2195			.1646	
17	.2218	.2561	.2012		.1663	.1097	
18	.2402	.3658	.2926			.2378	.2195
19	.3326	.4207	.3841	.4024		.3475	.3475
20	.4251	.4755		.4481	.4207	.439	
21	.3881	.439		.4251	1.3169	.4024	
22	.3696	.439		.4108	.3881	.3841	.3109
23	.3696	.3841	.3881	.3696	.3511	.3696	
24	.3475	.3511	.3841	.3696	.3696	.3361	.3475
Max	.4251	.4755	.3881	.4481	1.3169	.439	.3475
Min	.1463	.1829	.1829	.0732	.1294	.1097	.128
Avg	.2812	.3036	.2965	.3468	.3459	.2784	.2713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304085 / 33/11 KV SHIROLI SUB STATION

Feeder No / Name : 201 / SHIROLI GAOTHAN FEEDER NEW

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.6221	1.2651		.8954	.8413	1.4377
2	1.5466	1.5844	1.4327	.9335	.695	.8326	1.4003
3	1.5089	1.5089	1.4175	.8316	.6661	.8238	1.3256
4	1.4563	1.419	1.3969	.8316	.7362	.8145	1.251
5	1.3443	1.3443	1.2717	.7392	.7011	.7888	1.1827
6	1.251	1.307	1.2403	.6584		.8238	1.1088
7	1.1576	1.1949	.9804	.5304		.7164	1.0349
8	1.1203	1.0082	1.1041	.4572		.4923	.9425
9	.9425	.9326	1.0829	.3048		.4877	
10	.5544	.5155	.8987		.5765	.4024	
11	.5544	.5792	.9425		.5973	.3475	.3734
12	.5487	.3368	.924		.5735	.3511	.3547
13	.5487	.6001			.6268	.3109	.3361
14	.5544	.6697	1.0349		.5765	.3109	.3361
15	.5544	.6805	1.0164		.5611	.3881	.3361
16	.5544	.6447	1.0425		.5731	.4066	.3547
17	.6099	.6283	1.0719		.5506	.4251	.4108
18	.961	1.258	1.2136	.8573	.9114	.7468	.6348
19	1.251	1.4022	1.5089	1.1765	1.1443	1.4003	.7842
20	1.8107	1.4632	1.8861	1.5775	1.5415	1.5844	.8215
21	1.475	1.6651	1.8107	1.6297	1.6817	1.5844	.8589
22	1.6787	1.6448	1.7164	1.4922	1.5947	1.5497	.8962
23	1.6787	1.5424	1.6032	1.5223	1.643	1.5466	1.0642
24	1.6221	1.6598	1.3757	1.2136	1.4373	.9335	1.4901
Max	1.8107	1.6651	1.8861	1.6297	1.6817	1.5844	1.4901
Min	.5487	.3368	.8987	.3048	.5506	.3109	.3361
Avg	1.1195	1.1338	1.2712	.9837	.9142	.7879	.8516



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304085 / 33/11 KV SHIROLI SUB STATION

Feeder No / Name : 204 / 11 KV SHIROLI AG FEEDER

Ag dominated/Pure Ag

NEW Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.1219	.16			
2	.096	.1355	.1448			
3	.096	.1355	.1423			
4	.096	.1372	.1423			
5	.096	.1372	.1638			
6	.0972	.1204	.16			
7	.1147	.1852	.1875			
8	.1311	.1852	.2056			
9	.1311	.25	.208			
10			.2294		.1638	.1562
11			.2187		.2715	.1898
12			.3201		.2896	.2241
13			.3521		.2713	.2753
14			.4001		.2591	.2214
15			.3125		.2134	.2401
16			.3593		.2343	.1698
17			.3593		.3045	.1698
18				.0762		
19				.08		
24	.096	.1204	.1524			
Max	.1311	.25	.4001	.08	.3045	.2753
Min	.081	.1204	.1423	.0762	.1638	.1562
Avg	.1035	.1529	.2343	.0781	.2509	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304085 / 33/11 KV SHIROLI SUB STATION

Feeder No / Name : 205 / NEW 11 KV GHOTI AG FEEDER Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3361		.1734	
2			.3163		.1858	
3			.3201		.1669	
4			.2968		.192	
5			.2896		.2429	
6			.2286		.2715	
7			.2315		.2408	
8			.1957		.2115	
9			.1806		.2	
10	.25	.2896			.1524	
11	.3125	.2896			.1524	.2126
12	.3125	.3001		.1067	.1543	.2126
13	.3479	.3384			.1355	.2328
14	.3521	.3292			.1524	.2328
15	.3479	.362			.1543	.2507
16	.3437				.1698	.2195
17	.3086	.3601			.1524	.2561
23				.1113		
24			.3361		.2056	
Max	.3521	.362	.3361	.1113	.2715	.2561
Min	.25	.2896	.1806	.1067	.1355	.2126
Avg	.3219	.3241	.2731	.109	.1841	.2310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304086 / 33 KV SAIKHEDA- MURLI

SUBSTATI

Feeder No / Name : 201 / 11 KV SAIKHEDA MIX FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1865	.1543	.1526	.1865		.1526
2	.1865	.1372	.1526	.1696		.1526
3	.1696	.1372	.1526	.1715		.1526
4	.1696	.1372	.1526	.1696		.1526
5	.1696	.1372	.1526	.1715		.1526
6	.1715	.1543	.1696	.1696		.1526
7	.1372	.1543	.2401	.1715		.1696
8	.1696	.2229	.2743	.2713		.1696
9	.1865	.2572	.2883	.3222		.1526
10	.2058	.3258	.3052	.3222		.1696
11	.2572	.3086	.2883			.1526
12	.2229	.3258	.3222			.1187
13	.2572	.3391	.3222			.1017
14	.2401	.3391	.3391		.12	.1029
15	.2572	.3391	.3222		.1029	.0848
16	.2572	.3429	.3222		.1372	.0857
17	.2229	.2785	.3052		.1372	.0857
18	.2915	.2543	.2915		.1715	.0848
19	.2058	.2713	.2915		.2229	.1696
20	.2572	.2915	.2915		.2058	.1696
21	.2058	.2374	.2543		.1715	.156
22	.1715	.2058	.2035		.1715	.1402
23	.1715	.1526	.2035		.1715	.1357
24	.1696	.1715	.1526	.1865		.1715
Max	.2915	.3429	.3391	.3222	.2229	.1715
Min	.1372	.1372	.1526	.1696	.1029	.0848
Avg	.2058	.2365	.2479	.2102	.1612	.1390

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304086 / 33 KV SAIKHEDA- MURLI

SUBSTATI

Feeder No / Name : 202 / 11 KV AKPURI MIX FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6274	.6516	.6443	.6104	.6516	.6001	.4917
2	.5935	.6001	.6226	.5967	.5487	.6001	.4748
3	.5596	.6344	.6299	.583	.4801	.6001	.4748
4	.6274	.6344	.6104	.5935	.4801	.6001	.0464
5	.6274	.7202	.6104	.5801	.5144	.5487	.4694
6	.6274	.8573	.6783	.5935	.5316	.5487	.4748
7	.6173	.9431	1.153	.7045	.6516	.6001	.6443
8	.663	1.1317	1.1797	1.0174	.7373	.6344	1.3603
9	.8478	1.3546	1.2163	1.1869	.823	.7373	.8139
10	.9831	1.3889	.5801	1.0852	.7716	.7373	.6882
11	1.0174	1.3717	.6274	1.1317	.7545	.7545	.7461
12	1.0802	1.3717	1.3735	1.1145	.703	.8402	.39
13	.8059	1.3056	1.3108	1.0288	.703	.583	.3944
14	1.286	1.3094	1.3413	.9945	.823	.463	.3978
15	1.3203	1.2308	1.2548	.8402	.8573	.6001	.3812
16	1.286	1.1984	1.2209	.9259	.8916	.6516	.3768
17	1.2517	1.247	1.2431	.9259	.8916	.6173	.3647
18	.9431	1.2548	1.1603	.8916	.8916	.583	.373
19	1.2346	1.065	1.0562	.7888	.8573	.6859	.4578
20	1.1831	1.0978	1.153	.8573	.6859	.6516	.463
21	.9602	.9069	.8192	.823	.6687	.5658	.4409
22	.7545	.6464	.6554	.7888	.6687	.5487	.4287
23	.7202	.5426	.6133	.7888	.6344	.4973	.4144
24	.6613	.6859	.6443	.6274	.7202	.6001	.4409
Max	1.3203	1.3889	1.3735	1.1869	.8916	.8402	1.3603
Min	.5596	.5426	.5801	.5801	.4801	.463	.0464
Avg	.8866	1.0063	.9333	.8366	.7059	.6187	.5003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525] BU 5258

Substation No/ Name :- 304086 / 33 KV SAIKHEDA- MURLI

SUBSTATI

Feeder No / Name : 203 / 11 KV DAHELI MIX FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3086	.2543	.2543	.2229	.12	.1341
2	.3222	.2915	.2543	.1886	.2058	.12	.1296
3	.3052	.2743	.3052	.2374	.2058	.12	.1174
4	.2915	.2572	.2515	.1865	.2058	.12	.1174
5	.2713	.2915	.2543	.1865	.2229	.12	.1187
6	.2713	.3429	.3018	.1865	.2229	.1543	.1187
7	.2883	.4115	.373	.2713	.2915	.1543	.1372
8	.3222	.5144	.4475	.373		.1543	.2883
9	.3391	.6173	.5487	.5087		.1543	.285
10		.5144	.5801	.4917	.2915	.1543	.2429
11	.1526	.5316	.5765	.4801	.3258	.1543	.2543
12	.3429	.6516	.5596	.4973	.3944	.1543	
13	.3258	.6133	.5596	.4973	.3944	.1886	.1696
14	.5316	.6613	.5765		.3944	.1886	.1715
15	.5658	.6706	.5087	.4973	.3944	.2401	.1865
16	.5658	.6443	.4973	.5487	.3944	.2229	
17	.5658	.5967	.5256	.4973	.3429	.1715	
18	.583	.57	.5087	.4287	.3429	.1886	
19	.5144	.5365	.5087	.3601	.3429	.2229	.1696
20	.3772	.4862	.5256	.2915	.1715	.2229	.1402
21	.4115	.3856	.2883	.2572	.2229	.1715	.1357
22	.3258	.3391	.2949	.2572	.1543	.1543	.1227
23	.3258	.2543	.2321	.2401	.1543	.1372	.1357
24	.373	.3086	.2458	.2229	.2229	.12	.1311
Max	.583	.6706	.5801	.5487	.3944	.2401	.2883
Min	.1526	.2543	.2321	.1865	.1543	.12	.1174
Avg	.3787	.4614	.4158	.3461	.2783	.1629	.1653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304087 / 33 KV RAJURWADI SUBSTATION

Feeder No / Name : 201 / 11 KV RAJURWADI GAWTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2572	.3086	.3086	.2743	.2229	.2229
2	.2743	.2401	.2915	.2915	.2743	.2229	.2058
3	.2743	.2401	.2915	.2743	.2743	.2058	.1886
4	.2743	.2401	.2743	.2743	.2743	.2058	.1886
5	.2572	.2058	.2743	.2572	.2572	.1886	.1886
6	.2401	.2229	.2572	.2401	.2229	.1886	.1715
7	.2058	.2572	.2572	.2401	.2058	.1715	.1715
8	.2058	.2572	.2743	.2427	.1886	.1715	.1372
9	.1715	.2743	.2743	.2229	.1543	.1543	.1294
10	.1715	.2743	.2743	.2058	.1372	.12	.1029
11	.1886	.2229	.2401	.2058	.12	.12	.1029
12	.1886	.2401	.2572	.1715	.12	.1029	.1029
13	.2058	.2401	.2401	.1715	.12	.1029	
14	.2058	.2229	.2572	.1715		.1029	
15	.2058	.2743	.2683	.1715		.12	
16	.1886	.2743	.2515	.1715		.12	
17	.1715	.2572	.2804	.1715		.1543	
18	.2743	.2572	.3185	.2401		.1715	.2058
19	.2743	.3086	.3185	.3086	.2401	.2572	.2229
20	.2915	.3601	.3601	.3258	.2572	.2915	.2401
21	.2915	.3601	.3506	.3429	.2572		.2572
22	.2915	.3429		.3086	.2572		.2401
23	.2743	.3086	.3258	.2915	.2401		.2229
24	.2743	.3086	.3086	.3086	.2743		.2229
Max	.2915	.3601	.3601	.3429	.2743	.2915	.2572
Min	.1715	.2058	.2401	.1715	.12	.1029	.1029
Avg	.2365	.2686	.2850	.2466	.2184	.1698	.1855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304087 / 33 KV RAJURWADI SUBSTATION

Feeder No / Name : 202 / 11 KV TITAWI AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0171	.0171	.0171	.0171	.0343
2	.0343	.0305	.0171	.0171	.0171	.0171	.0343
3	.0343	.0343	.0171	.0171	.0171	.0171	.0343
4	.0343	.0343	.0343				.0343
5	.0343	.0343	.0171				.0343
6	.0343	.0343	.0514				.0343
7	.0343	.0343	.0514				.0343
8	.0343	.0343	.0343				.0514
9	.0514	.0343	.0343				.0514
10			.0343	.0343		.0171	
11			.0514	.0514	.0171	.0343	
12			.0514	.0686	.0171	.0343	
13			.0514	.0686		.0514	
14			.0503	.0686		.0514	
15			.0503	.1372		.0686	
16		.0171	.0686	.1372	.0171	.0686	
17		.0171	.0857	.0686	.0171	.0686	
18	.0152	.0171	.0171	.0171	.0343	.0171	.0171
19	.0152	.0171	.0171	.0171	.0343	.0171	
20	.0152	.0171	.0171	.0171	.0343	.0171	
21	.0152	.0171	.0168	.0171	.0171	.0171	
22	.0152	.0171		.0171	.0171	.0171	
23	.0152	.0171	.0171	.0171	.0171	.0171	
24	.0305	.0171	.0171	.0171	.0171		.0343
Max	.0514	.0343	.0857	.1372	.0343	.0686	.0514
Min	.0152	.0171	.0168	.0171	.0171	.0171	.0171
Avg	.0280	.0255	.0356	.0448	.0208	.0322	.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

GHANTAJI S/DN.[525]

BU 5258

Substation No/ Name :- 304087 / 33 KV RAJURWADI SUBSTATION

Feeder No / Name : 203 / 11 KV MOWADA AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.1715		.12	.0686
2	.0171	.0171	.0171	.1886		.1372	.0686
3	.0171	.0171	.0171	.2058		.1543	.0716
4			.0171	.1886		.1715	
5			.0171	.2229		.1886	
6			.0171	.2401		.2058	
7			.0171	.2743	.0686	.2229	
8			.0171	.3086	.1372	.2401	
9			.0171	.3772	.2058	.2229	
10	.1715						.2401
11	.2439	.2401					.2229
12	.3201	.2915					.1715
13	.3048	.2915					
14	.2896	.2743					
15	.2896	.2572					
16	.3048	.3258	.0171	.0514		.0171	
17	.3048	.2572	.0351	.0343		.0514	
18	.0305	.2572	.0171	.0343	.2572	.0686	.1029
19	.0152	.0171	.0343	.0343	.2572	.0686	.0171
20	.0152	.0171	.0343	.0343	.1029	.0686	.0171
21	.0152	.0343	.0171	.0343	.0857	.0686	.0171
22	.0152	.0343		.0171	.1029	.0686	.0171
23	.0152	.0171	.0171	.0171	.1029	.0686	.0171
24	.0171	.0171	.1715	.1715		.1029	.0686
Max	.3201	.3258	.1715	.3772	.2572	.2401	.2401
Min	.0152	.0171	.0171	.0171	.0686	.0171	.0171
Avg	.1336	.1402	.0293	.1448	.1467	.1248	.0846



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304021 / 33 KV MAREGAON

Feeder No / Name : 201 / 11 KV Maregaon (Mar)  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.7282	.7468	.6036	.5365	.4475	.5487
2	.6036	.7282	.7468	.6161	.5365	.4475	.5121
3	.5365	.6653	.7095	.6099	.5365	.4475	.5121
4	.503	.6722	.6722	.5853	.5365	.4435	.5121
5	.503	.6283	.6348	.5853	.503	.4481	.4572
6	.503	.5975	.6348	.5729	.503	.4481	.4572
7	.4527	.5601	.5853	.5228	.4694	.4294	.4572
8	.4862	.5359	.7023	.5175	.4191	.4207	.4572
9	.5197	.5788	.5792	.3881		.4163	.4435
10	.5493	.5853	.6036			.4572	.462
11	.5083	.6335	.6401	.5415			.4887
12	.5847	.6379		.4668	.4557	.4656	.4755
13	.5731	.6516	.6219	.4854	.4557	.4344	.462
14	.6268	.6697	.7499	.5041	.3978	.4163	.4435
15	.6219	.6584	.6584	.5041	.4111		
16	.6401	.6661	.6468	.5041	.3887	.4024	.4251
17	.6036	.5973	.5544	.4854	.3978	.4024	.4251
18	.6653	.543	.6036	.5228	.5175	.4572	.462
19	.6838	.6036	.6722	.503	.5544	.5304	.5788
20	.7842	.724	.7316	.57	.5975	.6219	.5544
21	.8215	.7602	.7682	.5868	.5138	.547	.5359
22	.8402	.8145	.7316	.5868	.5788	.5792	.4805
23	.811	.7682	.695	.57	.4161	.5487	.4805
24	.6371	.7655	.7421	.6535	.5365	.4475	.5487
Max	.8402	.8145	.7682	.6535	.5975	.6219	.5788
Min	.4527	.5359	.5544	.3881	.3887	.4024	.4251
Avg	.6109	.6572	.6709	.5429	.4887	.4663	.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304021 / 33 KV MAREGAON

Feeder No / Name : 202 / 11 KV Nawargaon Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.6535	.724	.6283	.6706	.2743	.6584
2	.503	.6468	.7316	.6219	.6371	.2743	.6584
3	.4862	.6468	.695	.5853	.6036	.2534	.6154
4	.4359	.6468	.6878	.5914	.57	.2534	.6154
5	.4024	.6468	.6516	.5544	.5533	.2534	.6154
6	.4024	.6099	.6219	.5121	.5533	.2534	.6036
7	.3688	.6099	.5853	.5729	.6036	.2149	.6036
8	.4694	.6584	.7059	.7762	.6371	.1791	.567
9	.5868	.7059	.8413	.6653	.6836	.1928	.5611
10	.5847		.7964		.4681	.4938	.7316
11	.724	.8048	.695	.5975	.1389		.4755
12	.6733	.9313	.6535	.3547	.2968	.6401	
13	.6626	.9231	.6401	.5788	.3121	.6516	
14	.7164	.905	.5487	.5975	.3321	.6219	
15	.6036	.7207	.8413	.5228	.2949		
16	.7133	.4344	.7682	.5975	.4973	.4938	
17	.8316	.8688	.695	.5228	.503	.4938	.499
18	.823	.9511	.7865	.5788	.2033	.823	.5359
19	.8316	.9511	.8779	.7042	.1867	.8779	.6838
20	1.0082	1.0498	.961	.788	.5788	.8596	.6468
21	.9149	.9593	.9511	.788	.3149	.7625	.6099
22	.8215	.8869	.8871	.7209	.3149	.7682	.567
23	.7545	.823	.7577	.6874	.2984	.695	.5359
24	.6036	.7095	.7865	.6767	.6706	.2743	.695
Max	1.0082	1.0498	.961	.788	.6836	.8779	.7316
Min	.3688	.4344	.5487	.3547	.1389	.1791	.4755
Avg	.6455	.7715	.7454	.6184	.4551	.4820	.6041

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304021 / 33 KV MAREGAON

Feeder No / Name : 203 / 11 KV Kumbha

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1233	1.4752	2.0885	1.4815	1.1736	.7701	.7956
2	1.1233	1.4582	2.3525	1.4118	1.1401	.7373	.7459
3	1.1401	1.3765	2.3525	1.39	1.1065	.7287	.7459
4	1.1401	1.3765	2.0885	1.39	1.073	.7287	.7459
5	1.1568	1.2803	2.2708	1.3535	1.0395	.7287	.7459
6	1.1736	1.5524	2.6513	1.267	1.0059	.7449	.7625
7	1.1904	2.0317	2.3537	1.1157	1.1568	.7773	.7625
8	1.5089	2.2211	2.8349	1.2567	1.3748	.6716	.7956
9	1.7772	3.0498	3.0544	1.3352		.6485	.9145
10	1.7126	2.8673	3.725			.7682	.9145
11	1.3927	3.6031	.6584	1.4937	1.0985		.9328
12	2.0891	3.1901	.6401	1.531	.9991	.7316	
13	2.364	3.12	.5487	1.419		.6219	
14	2.7018	3.7209	.4344	1.5684	.7116	.7133	
15	2.7639	3.6755	3.2739	1.4937	.7449	.6154	
16	3.0727	3.5368	3.1459	1.6057	.743	.7682	
17	2.8346	3.5475	3.2007	1.643	.8002	.7316	.6468
18	2.8018	3.1699	2.5789	1.5497	.8192	.823	.7023
19	2.7854	3.2373	3.914	1.4754		.8779	.7577
20	2.5777	3.1878	3.4019	1.4419	.8775	.9511	.7499
21	2.7073	2.6863	2.9264	1.3916	.8122	.8173	.7577
22	2.3525	2.4691	.1848	1.2239		.8145	.7282
23	1.8842	2.2565	1.6278	1.2071	.7209	.823	.7023
24	1.0562	1.8484	2.2805	1.4815	1.1736	.7611	.7459
Max	3.0727	3.7209	3.914	1.643	1.3748	.9511	.9328
Min	1.0562	1.2803	.1848	1.1157	.7116	.6154	.6468
Avg	1.9346	2.5808	2.2745	1.4142	.9774	.7545	.7712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304021 / 33 KV MAREGAON

Feeder No / Name : 204 / 11 KV Vinayak Cotex  
Express Feeder KV- 11 /  
OUTGOING

HV Non-Express Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0126	.0366	.056	.0335	.0131	.0366
2	.0335	.0126	.0366	.0566	.0335	.0131	.0366
3	.0335	.012	.0366	.056	.0335	.0131	.0366
4	.0335	.012	.0366	.056	.0335	.0137	.0366
5	.0335	.0114	.037	.0554	.0335	.0137	.0366
6	.0335	.0114	.0366	.056	.0335	.0143	.0362
7	.0335	.0131	.037	.0554	.0335	.012	.0366
8	.0335	.012	.037	.056	.0335	.0091	.0366
9	.0335	.012		.0373		.0084	.0543
10	.0072	.0076	.0362			.008	.0366
11	.0069	.0366	.0373	.0373			.0366
12	.0065	.0362	.0373	.0373	.012	.0362	.0373
13	.0088	.0366	.0373	.0373	.0097	.0366	.0373
14	.008	.0366	.037	.0373	.012	.0362	.056
15	.008	.0366	.0366	.0373	.0126	.0366	
16	.008	.0366	.0549	.0373	.0126	.0366	.056
17	.008	.0373	.0373	.0373	.0114	.0366	.0373
18	.0088	.0366	.056	.0373	.0137	.0366	.0373
19	.0126	.0554	.056	.0335	.012	.0549	.0554
20	.0131	.0549	.056	.0335	.0137	.0549	.056
21	.0063	.0543	.056	.0335		.0063	.056
22	.0063	.0549	.056			.0549	.056
23	.012	.0543	.0554	.0335	.0057	.0549	.056
24	.0335	.0572	.056	.056	.0335	.012	.0549
Max	.0335	.0572	.056	.0566	.0335	.0549	.056
Min	.0063	.0076	.0362	.0335	.0057	.0063	.0362
Avg	.0190	.0309	.0434	.0442	.0219	.0266	.0441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304021 / 33 KV MAREGAON

Feeder No / Name : 205 / 11 KV Navargaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018				
2	.3185				
3	.3185				
4	.4024				
5	.4024				
6	.4359				
7	.4359				
8	.4359				
9	.4862				
11			.9149		.0366
12			.9709	.6878	
13			.0373	.7316	
14			.0373		
15			1.0082		
16		.056	1.0456		
17			1.0456		
24	.2683				
Max	.4862	.056	1.0456	.7316	.0366
Min	.2683	.056	.0373	.6878	.0366
Avg	.3806	.056	.7228	.7097	.0366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304056 / 33 KV MARDI

Feeder No / Name : 202 / 11 KV Maa Saraswati Exp HV Non-Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0183	.0183	.0179	.0183
2		.0183	.0183	.0179	.0183
3		.0183	.0183	.0179	.0183
4		.0183	.0183	.0179	.0183
5		.0183	.0183	.0179	.0183
6		.0183	.0183	.0179	.0183
7		.0183	.0183	.0179	.0183
8		.0183	.0183	.0179	.0173
9		.0183	.0183	.0179	.0183
10	.0187	.0183		.0179	.0173
11	.0187	.0181	.0181	.0179	.0164
12	.0173	.0181	.0181	.016	.0164
13	.0173	.0181	.0181	.0156	.0164
14	.0179	.0181	.0181	.016	.0164
15	.0179	.0181	.0181	.0162	.0171
16	.0166	.0181	.0181	.0162	.0181
17	.0171	.0181	.0181	.0162	.0166
18	.017	.0181		.0173	.0171
19	.0175	.0181		.0185	.0181
20	.0179	.0181		.0183	.0185
21	.0179	.0181		.0185	.0185
22	.0183	.0181		.0185	.0183
23	.0179	.0181		.0185	.0183
24		.0183	.0183	.0179	.0183
Max	.0187	.0183	.0183	.0185	.0185
Min	.0166	.0181	.0181	.0156	.0164
Avg	.0177	.0182	.0182	.0175	.0177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304056 / 33 KV MARDI

Feeder No / Name : 203 / 11 KV Kegaon Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2195	.2378	.1463	.1848	.1829
2	.1867	.2195	.2378	.1463	.1478	.1463
3	.1867	.2195	.2195	.1463	.1478	.1463
4	.168	.2195	.2195	.128	.168	.1097
5	.168	.2195	.2012	.1097	.1663	.1097
6	.1307	.1646	.1829	.1097	.1109	.1097
7	.0934		.0914	.1097	.1307	.0914
8	.112	.1097	.0914	.0914	.1294	.0867
9	.0934	.1097	.1097	.0914	.0924	.0914
10	.0934	.0914	.128	.0914	.0716	.0867
11	.0934	.128	.128	.0914	.0716	.0655
12	.104	.128	.0914		.064	.0655
13	.104	.0914	.1097		.0625	.0655
14	.1075	.2743	.0914		.064	.0819
15	.1075	.3109	.1097		.0648	.0655
16	.0995	.3292	.1097		.0648	.0819
17	.0857	.128	.1463		.0972	.0995
18	.1187	.1463	.1829		.104	.1372
19	.1928	.1829	.2561		.2772	.181
20	.2686	.2561	.2743		.2561	.2033
21	.2865	.2743	.2743		.2587	.2033
22	.2561	.2561	.1829		.2402	.2012
23	.2328	.2561	.2195		.2218	.1829
24	.2241	.2378	.2378	.1829	.1848	.2195
Max	.2865	.3292	.2743	.1829	.2772	.2195
Min	.0857	.0914	.0914	.0914	.0625	.0655
Avg	.1557	.1988	.1722	.1204	.1409	.1256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304056 / 33 KV MARDI

Feeder No / Name : 204 / 11KV Mardi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4024	.4024	.2743	.2926
2	.3734	.4024	.4207	.2561	.2926
3	.3395	.4024	.4207	.2561	.2926
4	.3174	.4024	.3841	.2378	.2561
5	.2801	.3841	.3841	.2378	.2561
6	.2241	.2743	.3292	.2195	.2012
7	.1867	.2195	.2012	.2195	.1646
8	.1867	.2012	.2378	.2195	.156
9	.2427	.2195	.2378	.1646	.1829
10	.2427	.2378	.2195	.1463	.1387
11	.2241	.2561	.2195	.128	.1147
12	.2254	.2561	.2012	.08	.1311
13	.2254	.2743	.1829	.1094	.1311
14	.2328	.2561	.2561	.112	.1147
15	.2507	.2561	.2561	.1134	.1311
16	.2155	.2378	.2378	.1296	.1147
17	.2058	.2561	.2561	.1134	.116
18	.2204	.2743		.156	.1543
19	.3155	.3658		.3511	
20	.4656	.4572		.3511	
21	.4835	.4755		.3696	.1848
22	.4572	.439		.3696	.2195
23	.4119	.439		.3511	.1829
24	.4108	.4207	.4207	.2926	.3475
Max	.4835	.4755	.4207	.3696	.3475
Min	.1867	.2012	.1829	.08	.1147
Avg	.2971	.3254	.2927	.2191	.1898



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304056 / 33 KV MARDI

Feeder No / Name : 205 / 11 KV Kegaon Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6535	.1646	.2614	.128
2			.6722	.1646	.2614	.128
3			.6722	.1829	.2427	.08
4			.6535	.2012	.2427	.128
5			.6535	.2012	.2801	.128
6			.6722	.2378	.2801	.1463
7			.5788	.567	.2614	.1829
8			.6908	.5121		.2427
9			.6535	.4755		.2561
10	.5415	.7499				.2601
11	.5601	.8413				.2622
12	.6068	.823				.3277
13	.6068	.823				.2785
14	.6268	.7865				.2949
15	.6089	.8048				.2561
16	.6299	.7865				.176
17	.6001	.7865				.1989
24			.6348	.1646	.2427	.128
Max	.6299	.8413	.6908	.567	.2801	.3277
Min	.5415	.7499	.5788	.1646	.2427	.08
Avg	.5976	.8002	.6535	.2872	.2591	.2001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

MAREGAON S/DN.[817] BU 4817

Substation No/ Name :- 304056 / 33 KV MARDI

Feeder No / Name : 206 / 11 KV KUMBHA GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0242	1.1157	.6584	.695
2		1.0242		.6401	.6584
3		.9877		.6401	.6413
4		.9877		.6219	.6219
5		.9511		.6219	.5487
6		.823		.6219	.4755
7		.7133		.4572	.443
8		1.0425		.439	.4334
9		1.1157		.4024	.4508
10	.9709	1.0608	1.1104	.3658	.4334
11	.8589	.9877	1.2178	.2743	.426
12	.6762	1.4815	1.2894	.2401	.4752
13	.7802	1.4449	1.2437	.2656	.426
14	.788	1.1157	.8413	.2561	.426
15	.6626	1.2254	.9145	.2429	.4096
16	.5138	1.4632	1.0059	.2915	.3768
17	.9088	1.39	1.0425	.3401	.431
18	1.0513	1.4449	1.0608	.5721	.5144
19	1.262	1.4083	1.1706	.8871	.6516
20	1.4327	1.4449	1.3352	.9328	.7207
21	1.4327	1.3352		.8686	.7023
22	1.1523	1.262		.8316	.6584
23	1.0566	1.2803		.7577	.6219
24		1.0608	1.1888	.6767	.7316
Max	1.4327	1.4815	1.3352	.9328	.7316
Min	.5138	.7133	.8413	.2401	.3768
Avg	.9676	1.1698	1.1182	.5377	.5405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304024 / 33 KV BORI

Feeder No / Name : 202 / 11 KV Arli

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743					.2572	.2572
2	.2743					.2572	.2572
3	.2743					.2572	.2572
4	.2572					.2572	.2572
5	.2743					.2572	.2572
6	.2572					.2572	.2401
7	.2572					.2401	.2401
8	.2401					.2401	.2229
9	.2401					.2401	.2035
10						1.286	.2204
11	.2204			.1017			.2204
12				.2204	.1865	.2572	.4748
13				.2713	.2204	.2572	.2374
14				.2374	.2035	.2058	.2374
15					.2035	.2058	.2374
16				.0343	.2204	.2058	
17		.407		.0509	.2204	.1886	
18		.3391	.2374	.0509	.2543	.2058	.1865
19					.2743	.2401	.2374
20					.3429	.2915	.2713
21					.3429	.3258	.2713
22		.0339			.3258	.3086	.2713
23					.3086	.3086	.2543
24	.2743					.2743	.2743
Max	.2743	.407	.2374	.2713	.3429	1.286	.4748
Min	.2204	.0339	.2374	.0343	.1865	.1886	.1865
Avg	.2585	.26	.2374	.1381	.2586	.2967	.2539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315] BU 1724

Substation No/ Name :- 304024 / 33 KV BORI

Feeder No / Name : 203 / 11 KV Bori Ag

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0171
2			.0171
3			.0171
4			.0171
5			.0171
6			.0171
7			.0171
8			.0171
10		.0171	
12		.0171	
13		.0171	
14		.0171	
15		.0171	
16		.0171	
17	.017	.0171	
24			.0171
Max	.017	.0171	.0171
Min	.017	.0171	.0171
Avg	.017	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304024 / 33 KV BORI

Feeder No / Name : 204 / 11 KV Dabha Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1715	.2058
2					.1543	.1715
3					.1543	.1543
4				.1543	.1543	.1543
5				.1543	.1543	.1543
6				.1543	.12	.1372
7				.1543	.1029	.12
8				.12	.12	.1029
9				.1029	.12	.0848
10				.12	.12	.0848
11				.0857		.0678
12			.0848	.0848	.0686	.0678
13			.0848	.0848	.0686	.0678
14			.0848	.0848	.0686	.0678
15				.0848	.0686	.0678
16			.0857	.0678	.0686	
17	.1017		.0848	.0678	.0857	
18	.1187	.1187		.0678	.1029	.1017
19				.2058	.1715	.1696
20				.2401	.2229	.2035
21				.2401	.2401	.2035
22				.2401	.2401	
23				.2229	.2229	
24					.2058	.2058
Max	.1187	.1187	.0857	.2401	.2401	.2058
Min	.1017	.1187	.0848	.0678	.0686	.0678
Avg	.1102	.1187	.0850	.1369	.1394	.1297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304024 / 33 KV BORI

Feeder No / Name : 205 / 11 KV Bori Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6001	.6516
2			.6001	.6516
3			.6001	.6516
4			.5487	.6001
5			.5487	.6001
6			.5487	.6001
7			.5658	.6001
8			.5144	.5144
9			.5144	.6104
10			.5144	.6104
11				.6443
12	.5087	.5087	.5658	
13	.5256	.4748	.5487	
14	.5935	.5765	.5487	.4578
15		.5765	.5487	.373
16	.4239	.5087	.5487	
17	.5256	.4917	.5658	
18	.6274	.6443	.5144	.5087
19		.6859	.6687	.78
20		.7373	.8402	.8478
21		.7716	.823	.8478
22		.7716	.8573	.7461
23		.6859	.7716	.6952
24			.6859	.6516
Max	.6274	.7716	.8573	.8478
Min	.4239	.4748	.5144	.373
Avg	.5341	.6195	.6106	.6321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304024 / 33 KV BORI

Feeder No / Name : 206 / 11 KV Express feeder for  
MBCPN Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0509	.0339			.0343	.0343
2		.0509	.0339			.0343	.0343
3		.0509	.0339			.0343	.0343
4		.0509	.0339			.0343	.0343
5	.0343	.0509	.0339			.0343	.0343
6	.0343	.0339	.0339			.0343	.0343
7	.0343	.0339	.0339			.0343	.0343
8	.0343	.0339	.0339			.0343	.0343
9	.0343	.0339	.0339			.0343	.0339
10	.0343	.0339	.0339			.0343	.0339
11	.0339		.0339				.0339
12	.0339	.0339	.0339	.0339	.0339	.0343	
13	.0339	.0339	.0339	.0339	.0339	.0343	
14	.0339	.0339	.0339		.0339	.0343	.0339
15	.0339	.0339	.0339		.0339	.0343	.0339
16	.0339	.0339	.0339	.0339	.0339	.0343	
17	.0339	.0339		.0339	.0339	.0343	
18	.0339	.0339	.0339	.0339	.0339	.0343	.0339
19	.0339	.0339			.0343	.0343	.0339
20	.0509	.0339			.0343	.0343	.0339
21	.0509	.0339			.0343	.0343	.0339
22	.0509	.0339			.0343	.0343	.0339
23	.0509	.0339			.0343	.0343	.0339
24		.0509	.0339			.0857	.0343
Max	.0509	.0509	.0339	.0339	.0343	.0857	.0343
Min	.0339	.0339	.0339	.0339	.0339	.0343	.0339
Avg	.0376	.0383	.0339	.0339	.0341	.0365	.0341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304032 / 33 KV KARANJI

Feeder No / Name : 201 / 11 KV Sawarkheda Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.061	.1372	.0152	.0286	.0297	.0305
2	.0914	.061	.1372	.0305	.0286	.0297	.0305
3	.0914	.061	.1372	.0152	.0286	.0297	.061
4	.0914	.061	.1372				.061
5	.1524	.061	.1372				.061
6	.1429	.061	.1372				.061
7	.1829	.1829	.132				.0762
8	.1829	.1829	.3048				.0914
9	.1524	.2134	.3048				.1524
10			.3048	.1852		.0152	
11			.3048	.3321			
12			.2439	.3841	.0213		
13			.2439	.3521		.1829	
14			.1829	.3201	.2347	.1829	
15			.2439	.3361	.301	.1829	
16		.0286	.2439	.3521	.301	.1829	.0305
17	.0152	.0286	.2439	.3521	.1158	.1829	.0305
18	.0152	.0286	.0152	.0297	.1158	.0152	.0305
19	.0152	.0305	.0152	.0297	.0579	.0152	.0305
20	.0152	.0305	.0152	.0297	.0892	.0152	.0286
21	.0305	.0286	.0152	.0305	.0301	.0152	.0286
22	.0152	.0286	.0152	.032	.0617	.0152	.0282
23	.0152	.0286	.0152	.0309	.0305	.0152	.0267
24	.0914	.061	.1372	.0152	.0286	.0305	.061
Max	.1829	.2134	.3048	.3841	.301	.1829	.1524
Min	.0152	.0286	.0152	.0152	.0213	.0152	.0267
Avg	.0819	.0688	.1586	.1596	.0982	.0713	.0511



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304032 / 33 KV KARANJI

Feeder No / Name : 202 / 11 KV Karanji

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4382	.503	.4557	.5658	.3978	.3982
2	.4108	.4382	.5144	.4557	.547	.3978	.3982
3	.3982	.4382	.4801	.4557	.547	.4115	.3982
4	.3801	.4382	.4801	.4557	.5281	.3772	.3982
5	.3681	.4382	.463	.3856	.5281	.3814	.3982
6	.3772	.3772	.5144	.4908	.5658		.3982
7	.6001	.5959	.5658	.5258	.6001		.4706
8	.6859	.8764	.7888	.6661	.6859		.6516
9	.7888	1.0517	.8573	.9465	.7545		.6516
10	.7888	.9488	.823	.9945		.4508	.6154
11	.8573	.9804	.7545	.9069			.6335
12	.823	.8223	.8916	.8259	.6325	.4334	.5973
13	.6859	.8322	.8573	.8421		.5487	.5144
14	.7202	.8002		.8745	.7545	.583	.3768
15	.7545	.7842	.8916	.8259	.7202	.583	.3563
16		.8322	.8573	.7773	.759		.3401
17	.8573	.7449	.7888	.7449	.4744		.3239
18	.8573	.3887	.7202	.6802	.68	.5144	.3401
19	.7888	.6154	.6859	.6478	.4435	.5144	.3277
20	.7888	.7125	.6173	.6478	.4748	.5144	.3429
21	.7202	.6706	.4458	.6173	.4578	.4801	.2743
22	.2572	.5365	.543	.5373	.4409	.4557	
23	.4458	.4973	.5281	.5087	.4239	.4115	.2572
24	.4108	.4287	.503	.4557	.5658	.407	.3982
Max	.8573	1.0517	.8916	.9945	.759	.583	.6516
Min	.2572	.3772	.4458	.3856	.4239	.3772	.2572
Avg	.6163	.6536	.6554	.6552	.5786	.4625	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304032 / 33 KV KARANJI

Feeder No / Name : 203 / 11 KV Soya Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.1867	.1307	.1867	.0934	.112	.0934
2	.1867	.1867	.1307	.1867	.0934	.112	.0934
3	.1867	.1867	.1307	.1867	.0934	.112	.0934
4	.1867	.1867	.1307	.0934	.0934	.0747	.0934
5	.1867	.1867	.1307	.0934	.0934	.0747	.0934
6	.1494	.1867	.112	.0934	.0934	.0747	.0934
7	.0934	.1867	.0934	.0934	.0934	.0747	.0934
8	.0934	.1867	.0934	.0934	.0934	.0747	.0934
9	.1867	.0934	.0934	.1494	.0934	.0747	.0934
10	.2241	.0934	.1867	.0934	.0934	.0934	.0934
11	.2801	.0934	.1307	.0934			.0934
12	.112	.0934	.0934	.0934	.0373		.0934
13	.2801	.0934	.0934	.0934		.2241	.0934
14	.2241	.1867	.0934	.0934	.0747	.2241	.0934
15	.2241	.1867	.0934	.0934	.0747	.2241	.0934
16		.0747	.0934	.0934	.0747	.0934	.0934
17	.0934	.0934	.0934	.0747	.0747	.0934	.0934
18	.0934	.0934	.0934	.0934	.0373	.0934	.0934
19	.0934	.2801	.0934	.0747	.0747	.0934	.0934
20	.2241	.2801	.0934	.0747	.112	.0934	.0934
21	.112	.1867	.0934	.0732	.112	.0934	.0934
22	.112	.1867	.0934	.0732	.0747	.0934	.0747
23	.1867	.1494	.1867	.0934	.0747	.0934	.0747
24	.2241	.1867	.1494	.1867	.0934	.1494	.0934
Max	.2801	.2801	.1867	.1867	.112	.2241	.0934
Min	.0934	.0747	.0934	.0732	.0373	.0747	.0747
Avg	.1729	.1611	.1136	.1073	.0840	.1112	.0918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304032 / 33 KV KARANJI

Feeder No / Name : 204 / 11 KV Sawarkheda Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3658	.3982	.362	.3258	.3045	.362
2	.3326	.3658	.3801	.362	.3258	.2865	.362
3	.3326	.3658	.362	.362	.3077	.2865	.362
4	.3326	.3658	.362	.362	.3077	.2507	.362
5	.2957	.3658	.362	.362	.2896	.2507	.3077
6	.2772	.2926	.3258	.2896	.2926	.197	.2353
7	.2534	.2195	.2896	.2896	.2561	.1791	.2353
8	.2353	.2561	.2896	.3258	.2195	.2195	.181
9	.2353	.2743	.2896	.2507	.2195	.2195	.2172
10	.2172	.2012	.2896	.1928		.1829	.2172
11	.2378	.2743	.2534	.1928			.1991
12		.2743	.2172	.1928	.0724	.2172	.1991
13	.2534	.3658	.181	.1928		.1991	.1928
14	.2534	.3658	.2353	.1928	.1578	.181	.1907
15	.2172	.4024	.2172	.1753	.1928	.181	.1734
16		.3109	.2172	.1753	.2534	.1448	.1734
17	.2534	.2561	.1646	.2103	.2561	.181	.1734
18	.2353	.2378	.2534	.2126	.2715	.1991	.2254
19	.3174	.3439	.362	.3189	.2865	.2896	.2774
20	.3982	.3982	.3982	.3721	.3121	.3506	.2804
21	.3856	.4119	.362	.3544	.3511	.3506	.2658
22	.3856	.4298	.362	.3734	.3292	.3506	.2686
23	.3801	.4066	.362	.3582	.2865	.3506	.2715
24	.3696	.3658	.394	.362	.3258	.3109	.362
Max	.3982	.4298	.3982	.3734	.3511	.3506	.362
Min	.2172	.2012	.1646	.1753	.0724	.1448	.1734
Avg	.2986	.3298	.3053	.2851	.2685	.2471	.2539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304032 / 33 KV KARANJI

Feeder No / Name : 205 / 11 KV Karanji Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5601		.4904	.4481	.5281	.4344
2	.5228	.5601		.4904	.4294	.5093	.3258
3	.5041	.5601		.4904	.4294	.5093	.4344
4	.5041	.5601		.5281	.4294	.4904	.4344
5	.4854	.5601		.5281	.4481	.4904	.4344
6	.4854	.4481		.3772	.5281	.4527	.4527
7	.1753	.3734		.3018	.4527	.3881	.2172
8	.1753	.3734	.3658	.2218	.3961	.2987	.2172
9	.2804	.3734	.3658	.2058	.3018	.2987	.181
10	.2103	.3206	.2926	.3018		.2987	.2058
11	.2804	.3109	.2926	.2957			.2401
12	.2804	.4024	.3658	.2957	.2865	.4525	.2591
13	.2804	.4024	.2926	.3696		.2172	.2804
14	.2804	.4207	.2926	.4435	.2804	.2534	.2865
15	.3506	.439	.2926	.4066	.298	.2896	.2865
16		.4344	.439	.3142	.3467	.2926	.2896
17	.4298	.3658	.2926	.362	.2772	.2926	.2896
18	.2804	.3696	.439	.3898	.3155	.3658	.3292
19		.5175	.4024	.4075	.415	.362	.3696
20	.4908	.5975	.3658	.4252	.3772	.4115	.362
21	.4207	.6161	.362	.4706	.5281	.4908	.362
22	.5609	.6036	.5281	.5281	.4527	.5281	.3582
23	.5121	.6036	.5175	.4481	.5281	.4287	.3439
24	.5415	.5914		.4904	.4481	.5281	.4527
Max	.5609	.6161	.5281	.5281	.5281	.5281	.4527
Min	.1753	.3109	.2926	.2058	.2772	.2172	.181
Avg	.3897	.4735	.3692	.3993	.4008	.3990	.3269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304077 / 33 KV PANDHARKAWADA

Feeder No / Name : 201 / 11 KV SUT GIRNI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.3429	.7712	.6859	.2926	.2804	.2229
2	.3506	.3429	.7545	.7202	.2926	.2743	.2229
3	.3681	.3258	.7122	.703	.2926	.2126	.2401
4	.3086	.3601	.7011	.6859	.2865	.2035	.2401
5	.3121	.3772	.6859	.6859	.2896	.2481	.2572
6	.3155	.3429	.7537	.6687	.2926	.2347	.2743
7	.3366	.3429	.8939	.7373	.3475	.2804	.2401
8	.333	.2401	.964	.703	.3658	.285	.2743
9	.2915	.2401	.8413	.703	.3292	.298	.2915
10	.362	.2534	1.0974	.7522		.3429	
11	.362	.3982	1.1317	.788		.2915	
12	.3801		1.1488	.3982	.3018	.2915	
13	.4344	.7059	.5316	.6984	.3155	.2915	
14	.3982	.8869	1.0631	.2865	.2774	.2743	.2353
15	.3944	1.0498	1.2346	.2534	.2572	.2572	.2353
16	.3429	1.1584	1.4118	.2896	.2629	.3077	.2743
17	.3944	1.086	1.3213	.2715	.3506	.2896	
18	.3772	1.0498	1.3575	.2896	.2915	.2534	.2658
19	.3601	1.086	1.267	.3012	.3506	.3086	.3077
20	.3944	.9991	.9088	.3189	.3506	.3086	.2926
21	.3772	.9362	.823	.3224	.3353	.3086	.2743
22	.3814	.8939	.7202	.362	.298	.3086	.2743
23	.3467	.8238	.7202	.3258	.3506	.2915	.2195
24	.3506	.3429	.7712	.6859	.2896	.2686	.2572
Max	.4344	1.1584	1.4118	.788	.3658	.3429	.3077
Min	.2915	.2401	.5316	.2534	.2572	.2035	.2195
Avg	.3588	.6341	.9411	.5265	.3100	.2796	.2579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304077 / 33 KV PANDHARKAWADA

Feeder No / Name : 202 / 11 KV CHALBARDI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2804	.3429
2			.2804	.3601
3			.2058	.3429
4			.2103	.3429
5			.208	.3429
6			.2012	.2743
7			.2103	.2743
8	.1372		.2835	.2058
9	.1372		.2835	.2743
10	.1387		.2743	
11	.1387		.2058	
12		.2774	.2743	
13		.2743	.2058	
14		.7545	.2572	.2804
15		.2804	.2058	.2103
16		.2804	.2103	.2835
17		.2865	.2103	
18		.2835	.2896	
19		.3582	.3429	
20		.3467	.2572	.3544
21		.3467	.3429	.4252
22		.3506	.3429	.3544
23		.3544	.3429	.362
24			.2743	.3429
Max	.1387	.7545	.3429	.4252
Min	.1372	.2743	.2012	.2058
Avg	.1380	.3495	.2583	.3161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315] BU 1724

Substation No/ Name :- 304077 / 33 KV PANDHARKAWADA

Feeder No / Name : 203 / 11 KV KARANJI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3944		.2126	.2515	.2743
2	.3155	.3944		.2126	.2454	.2743
3	.2743	.3772		.2126	.2347	.2743
4	.2401	.3601		.2126	.2254	.2743
5	.2454	.3429		.1772	.2103	.2743
6	.2743	.3429		.1753	.2058	.2743
7	.2804	.4458		.1829	.2481	.3086
8	.3155	.5144		.2126	.2401	.3086
9	.2103	.3429		.2012	.2454	.3772
10	.2804	.5959			.3086	
11	.3506				.2401	
12	.2103			.2683	.2401	
13	.4557			.3155	.3086	
14	.4908			.2743	.2572	.3121
15	.4801		.2804	.2481	.2743	.3544
16	.4458		.3189	.3155	.3155	.4252
17	.5487		.1402	.3605	.3506	
18	.5487		.2103	.4458	.3155	.3658
19	.5144		.2507	.3506	.3086	.2926
20	.583		.2561	.3353	.3429	.2896
21	.5201		.2926	.3155	.3086	.2926
22	.4508			.3052	.3086	.2561
23	.4409		.1949	.2804	.2743	.2172
24	.3121	.4115		.2126	.2804	.2743
Max	.583	.5959	.3189	.4458	.3506	.4252
Min	.2103	.3429	.1402	.1753	.2058	.2172
Avg	.3793	.4111	.2430	.2649	.2725	.3011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304077 / 33 KV PANDHARKAWADA

Feeder No / Name : 204 / 11 KV Pkd Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6993	2.7092	2.8654	2.2634	2.6797	2.167	1.989
2	2.6642	2.6578	2.7286	2.3148	2.6612	2.1262	1.9547
3	2.6292	2.572	2.572	2.3148	2.6057	2.0233	1.9204
4	2.5149	2.5377	2.5591	2.2634	2.5688	1.9547	1.8861
5		2.5034	2.5312	2.1948	2.3712	1.9376	1.9033
6	2.5591	2.2291	2.5591	2.0919	2.2916	1.9033	1.9376
7	2.2969	2.1434	2.3137	1.989	2.1807	1.8176	1.8519
8	1.893	2.1434	1.9547	1.8004	1.9589	1.5947	1.7661
9	1.8229	1.8861	1.9631	1.8176	1.885	1.6289	1.7147
10	1.9004	1.9547	1.9204	1.8473		1.6289	
11	1.9366	2.0814	1.8861	1.829		1.6118	
12	2.0814	2.3167	2.1176	1.9004	1.7147	1.5604	
13	2.1538	2.2443	2.0233	1.957	1.6827	1.5947	
14	2.1538	2.3529	2.0062	2.2314	1.7718	1.6461	1.2851
15	2.2291	2.3167	2.0233	2.0302	1.7878	1.5947	1.2437
16		2.3891	2.2081	2.0119	1.6933	1.7375	1.829
17	2.1262	2.2443	2.0814	1.8642	1.6461	1.6289	
18		2.1538	2.2986	2.0271	1.6632	1.8461	2.0119
19	2.2291	2.2443	2.4615	2.268	2.0119	1.9376	2.1622
20	2.6406	2.6326	2.6235	2.5606	2.2119	2.3148	2.2177
21	2.8172	2.9321	2.6063	2.6981	2.2291	2.2977	2.2546
22	2.9908	3.0982	2.7435		2.2119	2.2462	2.2405
23	3.0226	2.9767	2.7778	2.7905	2.3819	2.1605	2.0698
24	2.8597	2.7606	2.8704	2.1605	2.7351	2.1616	2.0919
Max	3.0226	3.0982	2.8704	2.7905	2.7351	2.3148	2.2546
Min	1.8229	1.8861	1.8861	1.8004	1.6461	1.5604	1.2437
Avg	2.3915	2.4200	2.3623	2.1403	2.1338	1.8800	1.9121



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304077 / 33 KV PANDHARKAWADA

Feeder No / Name : 205 / 11 KV KELAPUR GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5074	1.5775	1.595	1.4575	1.5364	1.2407	1.3032
2	1.4217	1.5604	1.5775	1.4403	1.4661	1.262	1.3032
3	1.4022	1.5604	1.5775	1.406	1.4998	1.2269	1.286
4	1.387	1.5432	1.5074	1.3889	1.4632	1.2178	1.286
5	1.3032	1.5261	1.4403	1.3717	1.39	1.182	1.286
6	1.2269	1.1488	1.4563	1.3375	1.3213	1.0402	1.1317
7	1.1568	1.0117	1.3375	.9602	1.2437	.964	1.0974
8	1.1568	1.0117	1.2269	1.0631	1.1523	.9745	.9774
9	1.0227	1.0517	1.2689	1.0631	1.0059	.8383	.8916
10	.8322	.8939	1.2346	.9568		.7716	
11	1.1218	1.3496	1.046	.7973		.6344	
12	1.2971	.8413	1.2174	.8238	.6687	.6173	
13	1.2269	1.4899	1.286	.6401	.7712	.5658	
14	1.335	1.4723	1.3375	.6268	.7712	.5658	.6935
15	1.2689	1.4548	1.2346	.815	.8063		.6878
16	1.286	1.5074	1.3146	.9114	.8764	.5548	.7316
17	1.1317	1.4373	1.3672	.9114	.8505	.7802	
18	1.2003	1.4899	1.0341	1.0341	.8764	.8669	.9511
19	.1886	1.6827	1.3672	1.4083	1.2934	1.2346	1.3717
20	1.8861	1.9456	1.8176	1.6278	1.5238	1.5604	1.4118
21	1.9631	1.9631	1.8004	1.8111	1.5261	1.5089	1.39
22	1.7878	1.8229	1.7147	1.7375	1.4563	1.4575	1.3352
23	1.6827	1.7364	1.5604	1.6108	1.4022	1.3889	1.2936
24	1.5424	1.5775	1.5769	1.7833	1.6095	1.382	1.3375
Max	1.9631	1.9631	1.8176	1.8111	1.6095	1.5604	1.4118
Min	.1886	.8413	1.0341	.6268	.6687	.5548	.6878
Avg	1.3056	1.4440	1.4124	1.2077	1.2050	1.0363	1.1456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304089 / 33KV PAHAPAL S/S

Feeder No / Name : 201 / 11KV PAHAPAL GAVTHAN

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.4805	.4805	.4805	.5175	.4805	.4805
2	.462	.4805	.4805	.4435	.462	.4805	.462
3	.462	.462	.462	.4435	.462	.4805	.462
4	.4435	.462	.4435	.4066	.4435	.462	.4435
5	1.7926	.4251	.4435	.4066	.4435	.4435	.4435
6	.4435	.4066	.4435	.4066	.4251	.4066	.4435
7	.4435	.3881	.4251	.3881	.4066	.3696	.4066
8	.3881	.3511	.3696	.3696	.3326	.3511	.3696
9	.3511	.2957	.3326	.3326	.3142	.2957	.2772
10		.2772	.3142			.2402	.2218
11	.2772	.3142	.2957				.1848
12	.2957	.3511	.2957	.2402	.1848	.2218	.2033
13	.3142	.3696	.3326	.2402		.2218	.1478
14	.3326	.4066	.3511			.2218	.1663
15	.3326	.4251	.3142		.1109	.2402	.1848
16	.3511	.3881	.3326			.2402	.1478
17	.3696	.4066	.3881			.2772	
18	.4066	.5544	.462	.3881	.3326	.3511	.2033
19	.5175	.5914	.6283	.5175	.5914	.4805	.2033
20	.6838	.5914	.6468	.5729	.5729	.5914	.2587
21	.6283	.5914	.6099	.5914	.5544	.5544	
22	.5914	.5359	.5359	.5729	.5175	.5359	.2772
23	.5175	.5359	.5359	.5359	.5175	.5175	.2957
24	.499	.499	.5175	.5175	.5359	.499	.4805
Max	1.7926	.5914	.6468	.5914	.5914	.5914	.4805
Min	.0554	.2772	.2957	.2402	.1109	.2218	.1478
Avg	.4765	.4412	.4351	.4363	.4292	.3897	.3074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304089 / 33KV PAHAPAL S/S

Feeder No / Name : 202 / 11KV PAHAPAL AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0366	.2195		.0488	.0894	.0503
2	.0366	.0366	.2195		.061	.0894	.0629
3	.0366	.0366	.2195		.0732	.0894	.0503
4	.0366	.0244	.2317		.061	.088	.0503
5	.0366	.0366	.2317		.061	.088	.0503
6	.0366	.0366	.2439		.061	.088	.0503
7	.0366	.0366	.2439		.061	.088	.0503
8	.0366	.0366	.3292		.0732	.1006	.0503
9	.0366	.0366	.3658		.0854	.1257	.0629
10		.2683	.0488			.0503	.0754
11	.2073	.2926	.061			.0503	.0629
12	.2195	.2926	.0488	.1219	.0383		.0754
13	.2561	.3048	.0488	.1341			.0754
14	.2804	.3292	.0488				.0629
15	.2439	.3048	.0366		.0511		.0503
16	.2561	.2926	.0537		.0511		.0503
17	.2561	.2926	.0366			.0629	.0377
18	.2317	.0488	.0366	.0854	.0638	.0377	.0377
19	.2195	.0488	.0366	.0854	.0638	.0377	.0377
20	.0244	.0488	.0554	.0366	.0638	.0377	.0377
21	.0366	.0488	.0366	.0366	.0638	.0377	.0377
22	.0366	.0488	.0366	.0366	.0638	.0377	
23	.0366	.0488	.0366	.0366	.0638	.0377	
24	.0366	.0366	.1951	.0366	.061	.0766	.0503
Max	.2804	.3292	.3658	.1341	.0854	.1257	.0754
Min	.0244	.0244	.0366	.0366	.0383	.0377	.0377
Avg	.1169	.1260	.1301	.0678	.0616	.0691	.0532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315] BU 1724

Substation No/ Name :- 304089 / 33KV PAHAPAL S/S

Feeder No / Name : 203 / 11KV BOTH AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.08	.0324	.0162	.0162	.0316	.0158
2	.0324	.096	.0324	.0162	.0162	.0316	.0158
3	.0486	.08	.0324	.0162	.0162	.0316	.0158
4	.0486	.096	.0324	.0162	.0162	.0316	.0158
5	.0648	.112	.0324	.0162	.0162	.0316	.0158
6	.0648	.128	.0324	.0162	.0162	.0158	.0158
7	.081	.144	.0324	.0162	.0162	.0158	.0158
8	.0972	.1457	.0324	.0162	.0162	.0158	.0158
9	.1134	.1457	.0324	.0162	.0162	.0158	.0158
10	.0324	.0162	.1296			.0474	.0158
11	.0324	.0324	.1781				
12	.0324	.0324	.2105	.0486	.08	.0474	.0158
13	.0324	.0324	.1619	.0648	.08	.0377	.0158
14	.0324	.0244	.1781			.0316	.0158
15	.0324	.0324	.2105			.0316	.0474
16		.0324	.2105			.0474	.0474
17	.0486	.0324	.1781			.0316	
18	.0486	.0324	.0324	.0162	.048	.0158	.016
19	.0486	.0324	.0486	.0162	.032	.0158	.016
20	.0486	.0324	.0486	.0162	.032	.0158	.016
21	.0486	.0486	.0486	.0162	.032	.0158	.032
22	.0486		.0486	.0162	.032	.0158	.032
23	.0486	.0486	.0486	.0162	.032	.0158	.048
24	.0324	.08	.0324	.0486	.0162	.032	.0158
Max	.1134	.1457	.2105	.0648	.08	.0474	.048
Min	.0324	.0162	.0324	.0162	.0162	.0158	.0158
Avg	.0500	.0668	.0857	.0225	.0294	.0271	.0216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304090 / 33KV HIWRA\_BARSA

Feeder No / Name : 201 / 11kv SHIBLA(Mix)

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2229			.1543	
2	.1715	.2229			.1372	
3	.1715	.2229			.1372	
4	.1543	.2229			.1372	
5	.1543	.2401			.12	
6	.1543	.2401			.12	
7	.12	.2401			.12	.1543
8		.2401			.12	.1372
9	.1372	.2572			.12	.1543
10	.1715	.2743			.12	.12
11	.1715	.2572			.1372	.1372
12	.1715		.2572	.12	.12	.1372
13	.2058			.12		.1372
14	.1715			.1029		.1029
15	.2058			.12		.1029
16	.2229			.1029		
17	.2229			.1029		.0857
18	.2229			.1372		.1029
19	.2229			.1543		.1543
20	.2401			.1543		.1543
21	.2401			.1715		.1543
22	.2229			.1715		.1372
23	.2229			.1543		.1543
24	.1886	.2229			.1372	
Max	.2401	.2743	.2572	.1715	.1543	.1543
Min	.12	.2229	.2572	.1029	.12	.0857
Avg	.1894	.2386	.2572	.1343	.1293	.1329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

PANDHARKAWADA[315]

BU 1724

Substation No/ Name :- 304090 / 33KV HIWRA\_BARSA

Feeder No / Name : 202 / 11KV AKOLI(Mix)

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0288		.2229	
2		1.0288		.2229	
3		1.046		.2058	
4		1.046		.2058	
5		1.0288		.1886	
6		1.0631		.1715	
7		1.046		.1372	
8		1.0631			
9				.1029	
10		1.4918			
11	1.1488	1.5947		.2572	
12	1.1145				.2743
13	1.3889				.2572
14	1.3375		.2058		
15	1.3546		.2058		
16	1.3717		.2229	.2915	
17	1.4575		.2058	.3086	.1372
18	1.3889		.2058		.1372
19	1.3203		.2915		.1029
20	1.2689		.2743		.12
21	1.1831		.2743		.1029
22	.0686		.2572		.12
23	1.0631		.2401		.12
24		1.0288		.2401	
Max	1.4575	1.5947	.2915	.3086	.2743
Min	.0686	1.0288	.2058	.1029	.1029
Avg	1.1897	1.1333	.2384	.2129	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304035 / 33 KV SHINDOLA

Feeder No / Name : 201 / 11 KV Shindola Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0789	.0606	.1867			
2	.08	.0854	.1867			
3	.08	.1143	.1894			
4	.0812	.1162	.2058			
5	.1097	.144	.2225			
6	.1286	.2286	.2429			
7	.1303	.3269	.2972			
8	.2054	.3658	.3311			
9	.208	.3763	.4344			
10			.4287			.1654
11			.4287			.144
12			.4633			.1463
13			.4344			.1707
14			.4344			.1707
15			.4344			.1829
16			.4344	.2134	.1814	.1707
17			.4199	.2195	.2172	.1463
18					.1991	
19					.1814	
20					.1532	
21					.0991	
22					.1006	
24			.184			
Max	.208	.3763	.4633	.2195	.2172	.1829
Min	.0789	.0606	.184	.2134	.0991	.144
Avg	.1225	.2020	.3311	.2165	.1617	.1621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304035 / 33 KV SHINDOLA

Feeder No / Name : 202 / 11 KV Kalamana

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.1898	.3391	.2241	.208	.1772	.2743
2	.2172	.2561	.3391	.2241	.2103	.1772	.2572
3	.2172	.2622	.3391	.192	.1949	.1772	.2458
4	.1991	.2214	.3353	.192	.1928	.1772	.213
5	.1991	.2187	.3353	.192	.1638	.1772	.1966
6	.2012	.3467	.3315	.128	.1638	.1595	.1802
7	.2713	.4694	.5344	.1311	.16	.1372	.1781
8	.3688	.6962	.8192	.1311	.1852	.1619	.2241
9	.4694	.7293	.8421	.1802	.1898	.1492	.2241
10	.3353	.7373	.8322			.1638	.2241
11	.4588	.8288	.6478			.1562	.2401
12	.5304	.6718	.7773			.1524	.2241
13	.5304	.7625	.7042			.1524	.192
14	.5636	.8619	.7042	.1783		.1524	
15	.5571	.8619	.7042	.1806		.1677	
16	.5636	.7701	.6722	.1829	.1829	.1829	
17	.5898	.8356	.6554	.1852	.1829	.1981	.2241
18	.5967	.7125	.5243	.192	.208	.2347	.2241
19	.6036	.6718	.4915	.2058	.218	.2347	.2561
20	.4481	.6133	.5571	.208	.2774	.2743	.2561
21	.3241	.4973	.4915		.2229	.2572	
22	.2812	.426	.3277		.2058	.2401	
23	.253	.373	.2561		.2058	.2572	
24	.192		.3391	.208		.1772	.2743
Max	.6036	.8619	.8421	.2241	.2774	.2743	.2743
Min	.192	.1898	.2561	.128	.16	.1372	.1781
Avg	.3827	.5658	.5375	.1844	.1984	.1873	.2282



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304035 / 33 KV SHINDOLA

Feeder No / Name : 204 / 11 KV Shindola Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1886	.1905	.2075	.1886	.1698	.1867
2	.1905	.1886	.1905	.2263	.1886	.1698	.168
3	.1715	.1698	.1886	.1886	.1698	.1698	.168
4	.1715	.1698	.1698	.1886	.1698	.1509	.1494
5	.1524	.1509	.1698	.1509	.1509	.1509	.1307
6	.1509	.1509	.1509		.1509	.132	.1307
7	.132	.132	.1509	.132	.132	.132	.1307
8	.132	.1132	.1509		.132	.1307	
9	.132	.1509	.132	.132	.1509	.112	.1307
10	.132	.1267	.132			.112	.1307
11	.132		.132	.1509		.1109	.1307
12	.132		.132	.1132		.112	.112
13	.1509		.132	.1132		.1307	.112
14	.1509		.132	.132		.1307	
15	.132		.1132	.132		.112	
16	.1132	.1307	.1132	.132	.1433	.112	
17	.1132	.1867	.132	.132	.1494	.112	.1494
18	.132	.1698	.132	.132	.1307	.1307	.1867
19	.1698	.1698	.1886	.1698	.1698	.168	.2054
20	.1886	.2096	.2263	.1698	.2075	.2054	.2054
21	.2263	.2286	.2263		.2075	.2241	.2054
22	.2263	.2096	.2075		.2075	.1867	.2054
23	.1886	.2096	.2075		.1886	.1867	.2054
24	.1886		.4191	.1886		.1698	.1867
Max	.2263	.2286	.4191	.2263	.2075	.2241	.2054
Min	.1132	.1132	.1132	.1132	.1307	.1109	.112
Avg	.1583	.1698	.1717	.1551	.1669	.1467	.1615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304035 / 33 KV SHINDOLA

Feeder No / Name : 205 / 11 KV WCL Kailas Nagar

HV Express Feeder

Express Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.2454	.3772	.12	.0937	.048	.2614
2	.3544	.2804	.3772	.12	.0926	.0453	.2614
3	.3582	.2804	.3772	.1029	.0617	.0373	.2241
4	.3582	.2454	.3772	.1029	.0617	.0347	.2241
5	.3403	.2481	.3584	.1402	.0937	.028	.2241
6	.3439	.3018	.3395	.1753	.0926	.0253	.2614
7	.362	.3395	.3395	.1753	.0926	.02	.3174
8	.3681	.3772	.3772	.1067	.0926	.0173	.2926
9	.2804	.3584	.3547	.1067	.0926	.02	.3018
10	.3506	.3584	.3734			.2427	.2641
11	.3506	.3584	.3395	.0914		.2427	.2641
12	.3155	.3584	.3584	.0777		.2241	.1886
13	.3506	.3961	.3395	.1052		.2054	.1509
14	.3467	.3961	.3584	.2103		.2054	
15	.3155	.415	.3395	.2241		.2054	
16	.3018	.415	.3395	.2241	.0373	.2241	
17	.3395	.3584	.3395	.2241	.0253	.2241	.1509
18	.2469	.3395	.3018	.2263	.0333	.2241	.1509
19	.3772	.3961	.3584	.2641	.048	.2614	.1509
20	.415	.4715	.4527	.2641	.0453	.3174	.1509
21	.4207	.4527	.415		.0549	.3361	.1509
22	.3898	.4481	.415		.0493	.2987	.1509
23	.3506	.3734	.12		.1294	.2987	.1509
24	.3086		.3734	.0926		.0493	.2614
Max	.4207	.4715	.4527	.2641	.1294	.3361	.3174
Min	.2469	.2454	.12	.0777	.0253	.0173	.1509
Avg	.3458	.3571	.3543	.1577	.0704	.1598	.2168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304042 / 33 KV RAJUR

Feeder No / Name : 201 / 11 KV Rajur Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.1783	.0282	.0131	.0145	.0145	.0629
2	.1457	.1783	.0286	.0149	.0143	.0147	.0629
3	.144	.1957	.0282	.0131	.0145	.0143	.0638
4	.1296	.1932	.0286	.0137	.0143	.0149	.0648
5	.128	.1957	.0286	.0141	.0145	.0151	.0657
6	.1372	.2378	.0282	.0145	.0143	.0152	.0629
7	.2	.2559	.032	.0118	.0145	.0152	.0743
8	.2201	.2896	.0149	.0143	.0151	.0145	.1646
9	.2286	.3048	.0139	.0274	.0154		.16
10	.0149	.0274	.2107	.2572	.2286		.0152
11	.0248	.0151	.2972	.0095	.2086		
12	.0152	.0312	.2675	.2641	.2408		
13	.0152	.0312	.2896		.2229	.0987	
14	.0143	.0156			.1858	.092	.0164
15	.0166	.0293	.4144	.3121	.1974		
16	.0158	.0297	.3658	.3374	.1947	.0766	
17	.0156	.0293		.3521	.1947	.0907	
18	.0147	.029		.0282	.0126	.1082	.0118
19	.0152	.0286		.0267	.0118	.0143	.0145
20	.0166	.0309		.0149	.0116	.0133	.0141
21	.0156	.029	.0175	.0141	.0118	.0139	.0149
22	.016	.0305	.0177	.0145	.0135	.0137	.0152
23	.016	.0309		.0133	.0143	.0133	.0131
24	.1303	.1806	.0286	.013	.0149	.0141	.0638
Max	.2286	.3048	.4144	.3521	.2408	.1082	.1646
Min	.0143	.0151	.0139	.0095	.0116	.0133	.0118
Avg	.0764	.1082	.1189	.0815	.0790	.0351	.0534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304042 / 33 KV RAJUR

Feeder No / Name : 202 / 11 KV Nimbala Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0114	.0124	.1429	.0846	.096	.0714	
2	.0118	.0126	.1467	.0834	.0934	.0695	
3	.012	.0128	.1303	.0846	.0934	.0572	
4	.0133	.0126	.132	.0834	.1052	.0533	
5	.0133	.0124	.1143	.1128	.1052	.0533	
6	.0156	.0251	.1174	.1269	.1036	.0511	
7	.016	.0145	.1257	.1252	.1217	.0366	.0105
8	.032	.0286	.1623	.1429	.1353	.0383	.0103
9	.0158	.029	.1738	.1692	.1758		
10	.2258	.2709	.013	.0109			
11	.2591	.301	.0107	.0101			
12	.2818	.3281	.0105				
13	.2818	.2778	.0105		.0093	.0147	
14	.2984	.2778			.0097	.0133	.0823
15	.2439	.2778	.0143		.0105		
16	.2201	.3125	.0143		.012	.0137	
17	.2709	.3281	.0141	.0244	.0122	.0116	
18	.0143	.0297	.0244	.0255	.0126	.0124	.0232
19	.0293	.0286	.0139	.024	.0133	.0124	
20	.0152	.0141	.0135	.0251	.0065	.0135	
21	.0133	.0143	.0145	.0112	.012	.0124	.0114
22	.0137	.0139	.013	.0105	.0128	.0124	.0122
23	.0133	.0137		.0099	.012		.0122
24	.0101	.0124	.0128	.0834	.0974	.088	
Max	.2984	.3281	.1738	.1692	.1758	.088	.0823
Min	.0101	.0124	.0105	.0099	.0065	.0116	.0103
Avg	.0972	.1109	.0648	.0657	.0595	.0353	.0232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304042 / 33 KV RAJUR

Feeder No / Name : 203 / 11 KV Nandepera

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5028	.8059	.9217	.8482	.639	.4409	.4508
2	.5028	.78	.9172	.828	.6299	.4287	.4115
3	.4854	.763	.9231	.7907	.6154	.407	.3772
4	.4681	.763	.8962	.7811	.6062	.3768	.3561
5	.4458	.7209	.8907	.759	.5921	.3563	.3391
6	.3944	.7042	.8583	.7343	.5556	.3201	.3018
7	.3812	.7209	.8482	.8333	.6718	.2778	.2751
8	.4696		1.166	1.0936	.9602	.2469	.3086
9	.4902		1.4089	.9568	1.0385	.2623	
10	.5079	.6661	1.4091	1.094	.9755	.2778	
11	.5921	.5921	1.2809	1.034	.7573	.2494	
12	.5506	1.4243	1.3441	.9602	.6622	.2378	
13	.547	1.3735	1.3123		.5944	.2317	
14	.5197	1.2742			.4512	.2195	.2008
15	.5571	1.2071	1.3603	1.1405	.4633		
16		1.2266	1.3441	1.0987	.4607	.2115	
17	.3281	1.2452	1.291	1.0059		.2317	
18	.8002	1.2431	2.3746	.9602	.5556	.3521	.3795
19	.9774	1.2452	2.687	.8749	.5487	.4409	.3978
20	1.0923	1.3565	2.8838	.9614	.5548	.5083	.4409
21	1.0402	1.2548	2.4142	.8309	.5258	.5014	.463
22	.8916	1.1065	2.3738	.7956	.4801	.3121	.4917
23	.8573	1.0277	1.7143	.6226	.463	.4557	.426
24	.5258	.823	1.0059	1.7814	.6464	.463	.4508
Max	1.0923	1.4243	2.8838	1.7814	1.0385	.5083	.4917
Min	.3281	.5921	.8482	.6226	.4512	.2115	.2008
Avg	.6055	1.0147	1.4620	.9448	.6282	.3396	.3794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304042 / 33 KV RAJUR

Feeder No / Name : 205 / 11 KV Rajur-Palsoni  
Gaothan Feeder KV- 11 /  
OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7282	.6908	.6878	.6161	.5093	.5601
2	.6413	.7023	.679	.695	.6036	.4854	.5544
3	.6413	.6283	.6602	.6516	.5788	.4904	.5415
4	.6224	.6161	.6161	.6584	.5658	.4668	.5359
5	.5658	.5601	.6036	.6219	.7356	.4527	.5175
6	.5093	.547	.5847	.543	.5228	.415	.499
7	.4527	.4527	.5093	.5487	.4382	.415	.4805
8	.4904	.4715	.5144	.5041	.4338	.4066	.5121
9	.4715	.4904	.5228	.4904	.4338	.4251	
10	.4904	.5093	.6653	.5175	.415	.4251	
11	.4904	.547	.543	.5544	.415	.362	
12	.547	.5658	.5973	.4755	.3395	.4066	
13	.5281	.5228	.5552		.3395	.3734	
14	.5281	.4904	.4715		.3395	.3018	.3772
15	.5281	.5601	.5847	.3961	.3584		
16	.5415	.5249	.5731	.415	.3772	.3584	
17	.5281	.4854	.543	.5973	.3734	.3584	
18	.5175	.5249	.567	.5729	.415	.5281	.6379
19	.5975	.5658	.6468	.547	.3772	.5281	.5601
20	.7545	.7356	.679	.6602		.5847	.5487
21	.8131	.7733	.7762	.6653	.5975	.6036	.5914
22	.8029	.7922	.7468	.6722	.6348	.6722	.6348
23	.7947	.7356	.6984	.6468	.6161	.6468	.5373
24	.6653	.7577	.7167	.7133	.6348	.5228	.5975
Max	.8131	.7922	.7762	.7133	.7356	.6722	.6379
Min	.4527	.4527	.4715	.3961	.3395	.3018	.3772
Avg	.5906	.5953	.6144	.5834	.4853	.4669	.5429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 201 / 11 KV Maregaon (Wani)

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.7712	.8063	.8048	.7087	.5144	.6516
2	.7087	.7964	.8063	.7964	.7087	.4801	.6516
3	.6733	.7602	.7712	.7316	.6733	.4801	.6447
4	.6379	.724	.7011	.7316	.6379	.4801	.6089
5	.6024	.6878	.6859	.6516	.6379	.4801	.543
6	.567	.6878	.6516	.5792	.6024	.4458	.5014
7	.4607	.6447	.7545	.5014	.4607	.4458	.4706
8	.4607	.788	.9114	.4706	.4607	.4458	.394
9	.5316	.788	.9945	.5014	.4607	.2743	.3582
10	.567	.8413	.9945	.543	.4961		.3982
11	.6154	.8916	.9465				.3772
12	.5731	.8573	.9816	.4252	.4207		.3429
13	.5731	.9945	.9945	.4607	.3506	.3506	.3429
14	.5548	.8916	.3467	.4961	.2103	.3582	
15	.5201	.8916	.6935		.2103		
16	.7164	.8916	.9015	.4607	.2103		
17	.6805	.8916	.8688	.4607	.3506	.3582	.3429
18	.2774	.8764	.7362	.6024	.4207	.4656	.4458
19	.823	1.0517	.9313	.7087	.5258	.5792	.5487
20	1.0387	1.0867	1.1222	.7087	.5487	.7602	.6859
21	1.0387	.9816	1.0136	.7796	.6173	.7522	.6859
22	.9114	.9465	.8954	.7442	.631	.7602	.6173
23	.8688	.8764		.6733	.5144	.6516	.5487
24	.7442	.7964	.8573		.6733	.5316	.6878
Max	1.0387	1.0867	1.1222	.8048	.7087	.7602	.6878
Min	.2774	.6447	.3467	.4252	.2103	.2743	.3429
Avg	.6606	.8506	.8420	.6110	.5014	.5060	.5166

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 202 / 11 KV Wani Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.7558	1.858	1.4632	1.576	1.3321	1.3169
2	1.576	1.6651	1.5775	1.4632	1.5043	1.3321	1.3169
3	1.576	1.6095	1.6126	1.39	1.5043	1.2269	1.2803
4	1.5043	1.5729	1.5775	1.39	1.4327	1.2269	1.2308
5	1.5043	1.5364	1.5432	1.3169	1.3611	1.1919	1.2437
6	1.4327	1.4632	1.5432	1.3169	1.2894	1.1919	1.2437
7	1.2178	1.3032	1.2689	1.1706	1.1462	1.1568	1.1706
8	1.1462	1.2308	1.166	1.0974	1.0029	1.0974	.9511
9	1.1462	1.3032	1.166	1.0974	1.0745	1.0288	.9412
10	1.1462	1.2894	1.3321	1.1584	1.1462	1.1218	1.0974
11	1.2437	1.3717	1.448				1.0174
12	1.3032		1.5203	1.4327	1.4022		1.153
13	1.2894	1.5775	1.6651	1.2894	.5258	1.1584	1.2887
14	1.448	1.5432	1.5043	1.3611	1.0517	1.3756	
15	1.4327	1.5089	1.5364		1.2269		
16	1.3756	1.4746	1.5203	1.3611	1.262	1.2308	
17	1.448	1.4403	1.5203	1.3611	1.2346	1.3169	1.3565
18	1.3756	1.4373	1.5927	1.4327	1.3032	1.3032	1.4403
19	1.448	1.5775	1.7375	1.6476	1.3717	1.5364	1.4243
20	1.6651	1.7528	1.9022	1.7193	1.4403	1.6827	1.4922
21	1.6827	1.893	1.829	1.6476	1.4403	1.6095	1.4922
22	1.829	1.8519	1.7558	1.576	1.3717	1.4632	1.2209
23	1.9022	1.8861	1.6095	1.576	1.4022	1.4632	1.153
24	1.7193	1.829	1.8861	1.5364	1.5043	1.3717	1.39
Max	1.9022	1.893	1.9022	1.7193	1.576	1.6827	1.4922
Min	1.1462	1.2308	1.166	1.0974	.5258	1.0288	.9412
Avg	1.4608	1.5597	1.5697	1.4002	1.2858	1.3056	1.2486



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 203 / 11 KV MIDC New

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.1341	.1029	.3353	.0686
2	.0686	.1006	.1029	.1341	.0686
3	.0686	.1006	.1029	.1006	.0514
4	.0514	.1006	.1029	.1006	.0514
5	.0514	.1006	.1029	.0671	.0514
6	.0514	.1006	.1029	.0671	.0514
7	.0514	.1341	.1029	.1372	.0514
8	.0514	.1006	.2058	.1006	.0857
9	.0514	.1006	.2058	.0671	.0514
10	.0514	.1006	.1402	.1006	.0686
11	.1341	.1029	.2683		
12	.1006	.1029	.2683	.12	.2454
13	.1341	.2058	.2012	.0857	
14	.1006	.2058	.2683	.0857	
15	.0671	.2401	.2347		
16	.0686	.1029	.1677	.0857	
17	.0671	.1029	.2012	.0857	
18	.1006	.1029	.1677	.0686	
19	.1341	.1372	.1715	.0857	
20	.1341	.1372	.2012	.0686	
21	.1341	.1372	.1341	.0857	
22	.1341	.1372	.1341	.0514	
23	.1006	.1372	.1341	.0514	
24	.0514	.1006	.1052	.1341	.0686
Max	.1341	.2401	.2683	.3353	.2454
Min	.0514	.1006	.1029	.0514	.0514
Avg	.0837	.1261	.1637	.1008	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 204 / 11 KV Water Works

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9683	3.0727	3.0864	2.6787	2.3891	2.0576	2.2443
2	2.8235	2.9683	2.915	2.6787	2.3891	2.0576	2.1357
3	2.7511	2.7511	2.7435	2.5701	2.3167	1.989	2.1357
4	2.6063	2.6787	2.6063	2.4977	2.2443	1.8861	2.0995
5	2.5339	2.6425	2.572	2.3891	2.1719	1.8519	2.0995
6	2.3891	2.6063	2.4691	2.3167	2.2443	1.8176	2.0271
7	2.1719	2.3167	2.2291	2.1719	2.0271	1.8176	1.8823
8	2.0995	2.1719	2.2291	2.0995	1.9547	1.7833	1.8099
9	2.0271	2.0058	2.0576	1.9547	1.8823	1.7833	1.8099
10	2.0995	2.2443	2.1033	2.0271	1.8823		1.8823
11	2.1948	2.1948	2.1491				1.7635
12	2.1719	2.2291	2.1491	1.9547	1.893		
13	2.3411	2.2977	2.1719	1.9547	1.7528	1.8823	2.1704
14	2.3167	2.332	2.2443	2.0271	1.5775	1.8099	1.8313
15	2.3167	2.2436	2.3167		1.7528		1.7635
16	2.3167	2.2291	2.3891	2.0271	1.7528	1.8823	1.6956
17	2.2207	2.2634	2.2923	2.0271	1.8861	1.8823	1.8991
18	2.0995	2.1735	2.3167	2.1719	1.9204	1.9547	2.0348
19	2.4143	2.572	2.7511	2.4615	2.2291	2.3167	2.2382
20	2.9683	2.7435	3.0087	2.6787	2.332	2.6787	2.3739
21	3.1131	2.915	3.1131	2.6063	2.332	2.5339	2.3061
22	3.1855	3.2236	3.0407	2.7511	2.2436	2.5339	2.1704
23	3.3653	3.2579	3.0407	2.6787	2.1735	2.3891	1.8991
24	3.0407	3.219	3.3303	2.8959	2.5339	2.1735	2.3167
Max	3.3653	3.2579	3.3303	2.8959	2.5339	2.6787	2.3739
Min	2.0271	2.0058	2.0576	1.9547	1.5775	1.7833	1.6956
Avg	2.5223	2.5564	2.5552	2.3463	2.0818	2.0541	2.0256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 205 / 11 KV Kayar (Wani)

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.9175	1.3717	.7773	.8642	.7011	.7125
2	.5556	.9175	1.3717	.7773	.8025	.7011	.7125
3	.5556	.9069	1.3032	.7449	.7407	.6661	.7125
4	.5556	.9069	1.3032	.7449	.7407	.631	.7125
5	.6173	.9069	1.2346	.7125	.8025	.631	.6478
6	.6173	.9069	1.2346	.7125	.8025	.4801	.6478
7	.8025	1.3603	1.7147	.8421	1.1111	.6859	.9717
8	1.1111	1.749	2.0576	1.2308	1.4815	.7202	1.166
9	1.2963	2.0081	2.1605	1.4251	1.5432	.8573	1.3603
10	1.2963	2.0081	2.4539	1.3603	1.5432		1.3603
11	1.3603	2.1262	2.332				1.4243
12	.8421	2.2291	2.2672	1.1111	1.4022		
13	1.6842	2.2291	2.3967	1.2346	1.2346	.7773	.9496
14	1.7814	2.332	2.3967	1.2346	1.166	.8421	.9602
15	1.8138	1.989	2.3967		1.166		1.0288
16	1.8138	2.0576	2.2672	1.2346	1.166	.8421	1.0288
17	1.8785	2.332	2.3967	1.2346	1.2346	.9717	.9602
18	1.9433	2.1735	2.0729	1.1728	1.3032	1.1012	.8916
19	1.8138	2.0576	1.8138	1.2346	1.2003	1.1012	.8916
20	1.749	2.0576	1.8138	1.2346	1.0288	.9717	.8916
21	1.5074	1.7147	1.6842	1.1111	.823	.9717	.6859
22	1.2452	1.6461	1.6194	.9259	.7712	.7773	.5487
23	.9175	1.5432	1.1012	.8333	.7712	.7377	.4801
24	.6173	.9175	1.4723	.7773	.8642	.7362	.7125
Max	1.9433	2.332	2.4539	1.4251	1.5432	1.1012	1.4243
Min	.5556	.9069	1.1012	.7125	.7407	.4801	.4801
Avg	1.2080	1.6664	1.8432	1.0303	1.0680	.7952	.8895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 206 / 11 KV Shirpur

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4588	.8413	.7712	.3582	.3277	.2743	.2804
2	.3932	.823	.7362	.3582	.3277	.2743	.2896
3	.3932	.7712	.7362	.3155	.2622	.2743	.2865
4	.3932	.7712	.7362	.3155	.2622	.2743	.2865
5	.3932	.7377	.7011	.2896	.2622	.2401	.2804
6	.3932	.7377	.7011	.2804	.2622	.2401	.2896
7	.4588	1.0136	1.0517	.2774	.1966	.2058	.208
8	.6554	1.2483	1.2269	.208	.1966	.2058	.3467
9	.7865	1.3717	1.5424	.2804	.1966	.2058	.3467
10	.852	1.5089	1.5775	.2774	.2622		.3467
11	1.086	1.3032	1.4083				.3429
12	1.0402	1.3717		.1966	.1753		
13	1.1096	1.5432	1.1142	.1966	.2103	.2012	
14	1.2308	1.3717	1.3108	.2622	.2743	.208	
15	1.2308	1.3717	1.3413		.2103		
16	1.2894	1.4746	1.073	.1966	.2103	.2103	
17	1.387	1.5089	1.0059	.1966	.2058	.2149	
18	1.2346	1.1919	.9389	.2622	.2743	.2103	
19	1.2308	1.1218	.9602	.2622	.2743	.3506	.2743
20	1.3321	1.0517	.9709	.3277		.3506	.3429
21	1.2071	.8764	.823	.3277	.2743	.3506	
22	.8718	.8063	.8322	.3277	.2743	.362	
23	.8048	.8063	.8322	.2622	.2743	.2774	
24	.4588	.8779	.7712	.4161	.2622	.2804	.2865
Max	1.387	1.5432	1.5775	.4161	.3277	.362	.3467
Min	.3932	.7377	.7011	.1966	.1753	.2012	.208
Avg	.8621	1.1042	1.0071	.2816	.2489	.2606	.3006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 207 / 11 KV Mahasoya

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6241	.6516	.6154	.5487	.6516	.6516
2	.5792	.6805	.6661	.6154	.5182	.6516	.6154
3	.5487	.6805	.6661	.6154	.5182	.6516	.6154
4	.5487	.6805	.6661	.6154	.5487	.6516	.6154
5	.5487	.6878	.6516	.6154	.5487	.6516	.6089
6	.5487	.6878	.6516	.6154	.5487	.6516	.6089
7	.5792	.6241	.6516	.6154	.5487	.6516	.6447
8	.5792	.6661	.6516	.6878	.5487	.6516	.6154
9	.5792	.6661	.6516	.6878	.5487	.583	.6154
10	.5792	.6241	.6516	.6878	.5792	.631	.6516
11	.6805	.6516	.6661				.6173
12	.6805	.6516	.6805	.5792	.6661		.6173
13	.6878	.6516	.6661	.5792	.6661	.6154	.6173
14	.6805	.6516	.6661	.5487	.6516	.5959	
15	.6805	.6516	.6878		.6661		
16	.6588	.6516	.6661	.5487	.6661	.6154	
17	.6588	.6516	.6805	.5792	.6661	.6154	.6173
18	.6516	.6661	.6805	.5792	.5258	.6154	.583
19	.6588	.6661	.6089	.5487	.6661	.6154	.583
20	.631	.6661	.6154	.5487	.6661	.6154	.583
21	.6805		.6089	.5487	.6661	.6154	.583
22	.6878		.6154	.5487	.6661	.6154	.583
23	.6447			.5182	.6661	.6154	.583
24	.5487	.6447	.6516		.5487	.6661	.6878
Max	.6878	.6878	.6878	.6878	.6661	.6661	.6878
Min	.5487	.6241	.6089	.5182	.5182	.583	.583
Avg	.6209	.6584	.6545	.5952	.6019	.6299	.6142

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 208 / 11 KV MIDC Old

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4557	.5068	.4801	.4344	.3856	.3155	.362
2	.4207	.5068	.4458	.4344	.3506	.3155	.362
3	.4207	.4706	.4458	.3982	.3506	.3155	.3658
4	.4207	.4706	.4115	.3982	.3506	.3086	.362
5	.3506	.4344	.4115	.3258	.3506	.3086	.3258
6	.3155	.4024	.3772	.3258	.3155	.2743	.3258
7	.3155	.3582	.3772	.3258	.2804	.2743	.2896
8	.3155	.3258	.3429	.2896	.2804	.2401	.2454
9	.3155	.3155	.3429	.3258	.2454	.3086	.2454
10	.3155	.362	.3506	.2896	.2454		.2534
11	.2896	.3086	.3582				.2401
12	.3258	.3086	.3582	.2454	.2454		
13	.3224	.3429	.362	.2454	.2103	.2534	.2401
14	.362	.3086	.362	.2454	.2103	.2534	
15	.362	.3429	.3506		.2103		
16	.394	.3429	.3506	.2454	.2103		
17	.394	.3086	.362	.2454	.2454	.2172	.2743
18	.3506	.3086	.362	.2454	.2401	.2534	.2743
19	.3506	.3506	.3982	.3155	.2743	.2896	.3086
20	.4656	.4557	.5068	.3856	.3086	.3982	.3429
21	.543	.4801	.5068	.3856	.3086	.3982	.3429
22	.543	.5144	.362	.4207	.3506	.4344	.3429
23	.543	.5144	.5068	.3856	.3506	.4024	.3429
24	.4557	.5068	.4908	.4344	.3856	.3506	.3982
Max	.543	.5144	.5068	.4344	.3856	.4344	.3982
Min	.2896	.3086	.3429	.2454	.2103	.2172	.2401
Avg	.3895	.3978	.4009	.3340	.2915	.3111	.3122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 209 / 11 KV Sundarnagar Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2452	.3086		.2263		.1698
2	.1886	.2452	.2743		.2075		.1886
3	.1886	.2452	.2743		.2075		.1886
4	.1886	.2263	.2401		.2075		.1886
5	.2075	.2263	.2401		.1886		.1698
6	.2263	.2263	.2058		.1886		.1698
7	.2263	.1886	.2058		.2263		.1886
8	.1886	.1886	.1715		.2263		.1698
9	.2263	.1698	.1715		.2263		.1698
10	.1886	.1698	.1715		.1886		
11	.1867	.1715	.1867				.1543
12		.1715	.1867	.1886	.1715		
13	.2241	.1715	.168	.2263	.1715	.1509	.0686
14	.2241	.2058	.168	.1886	.1372	.1509	.0686
15	.2241	.2058	.2241		.1372		.0686
16	.1867	.2058	.168	.1698	.1372	.132	.0686
17	.1867	.1715	.1867	.1886	.1372	.1509	.0686
18	.2241	.1715	.168	.2263	.1715	.1886	.0686
19	.2054	.2743	.1867	.2263		.1886	.0686
20	.2614	.2743	.2427	.2263		.2075	.0686
21	.2801	.3086	.2614	.2263		.2263	.0686
22	.3018	.3429	.2614	.2263		.2075	.0686
23	.3018	.3429		.2263		.2075	.0686
24	.2263	.2452	.3155		.2263		.1698
Max	.3018	.3429	.3155	.2263	.2263	.2263	.1886
Min	.1867	.1698	.168	.1698	.1372	.132	.0686
Avg	.2204	.2248	.2168	.2109	.1880	.1811	.1219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 210 / 11 KV MAIN I/C LALGUDA-I

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.225	4.7051		3.81	3.8855	3.3573	3.3951
2	4.0364	4.6201		3.81	3.7346	3.3196	3.3573
3	3.9609	4.4353		3.5837	3.6214	3.2065	3.3196
4	3.8477	4.3614		3.5837	3.546	3.2065	3.2442
5	3.7346	4.257		3.3196	3.4705	3.131	3.131
6	3.5837	4.145		3.2442	3.3196	3.0178	3.0933
7	3.3573	4.0657		3.0178	2.9047	2.9801	2.9047
8	3.4728	4.3896		2.8669	2.7538	2.9047	2.6783
9	3.6591	4.561		3.0178	2.7915	2.6406	2.6406
10	3.77	4.7279	5.104	3.0933	2.9874	2.4143	2.8669
11	3.9506	4.7279	4.9429				2.8669
12	4.0238	3.3311	3.6969	3.1687	3.131		2.3388
13	4.0969	5.301	4.8903	3.0556	2.6029	2.7161	2.7538
14	4.353	4.9787	4.3801	3.2065	2.6029	2.9424	
15	4.3164	4.9787	4.792		2.7161		
16	4.4887	4.8712	4.6696	3.0933	2.7538	2.7915	
17	4.6205	5.0145	4.5249	3.0994	2.9424	2.8292	2.8669
18	4.0181	4.8285	4.4163	3.3981	3.1687	2.9801	3.0178
19	4.742	4.923	4.7058	3.81	3.3951	3.5082	3.4705
20	5.2675	5.1764	5.2484	4.0364	3.2442	3.9609	3.81
21	5.3593		4.9665	4.0364	3.6214	3.8855	3.4328
22	5.0785		4.5847	3.9609	3.5837	3.7723	3.0556
23	4.9665		2.9995	3.6969	3.4705	3.546	2.9047
24	4.3004	4.7798	4.9897	2.3388	3.6969	3.4705	3.5837
Max	5.3593	5.301	5.2484	4.0364	3.8855	3.9609	3.81
Min	3.3573	3.3311	2.9995	2.3388	2.6029	2.4143	2.3388
Avg	4.2179	4.6276	4.5941	3.3749	3.2150	3.1705	3.0825



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 211 / 11 KV MAIN I/C LALGUDA-II

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4	4.4344	5.2484	3.8683	3.725	2.8959	3.2373
2	3.8009	4.3258	5.0267	3.6534	3.6355	2.8959	3.1786
3	3.7285	4.1086	4.768	3.4743	3.4564	2.7873	3.1786
4	3.5475	4.0181	4.5831	3.4389	3.3848	2.6425	3.1417
5	3.5656	3.9819	4.4723	3.2579	3.3669	2.6063	3.0807
6	3.4389	3.9457	4.3244	3.1855	3.4385	2.3998	3.006
7	3.4027	4.0752	4.5359	3.2579	3.5791	2.6147	3.2156
8	3.5757	4.2768	4.742	3.5837	3.8752	2.5869	3.2415
9	3.751	4.3995	4.7279	3.5056	3.8912	2.7286	3.4932
10	3.786	4.5597	4.8727	3.5406	3.8489	2.4451	3.4027
11	3.8912	4.6975	5.0831				3.4027
12	3.086	4.7325	4.904	3.5757	3.7159		
13	4.417	5.013	4.9004	3.6808	3.2952	2.8349	3.2236
14	4.4871	5.1882	5.0926	3.6755	2.9096	2.8349	
15	4.4871	4.7325	5.1783		3.0849		
16	4.4521	4.6975	4.9897	3.6582	3.0849	2.8881	2.8121
17	4.4521	4.9779	5.1097	3.6755	3.3303	3.0476	3.0148
18	4.6456	4.7782	4.7154	3.7449	3.4705	3.2602	3.1184
19	4.5597	5.3772	4.9238	4.217	3.5437	3.6892	3.4027
20	5.2092	5.5601	5.4041	4.4414	3.5101	4.0055	3.5848
21	5.1945	5.4138	5.2801	4.3077	3.2952	3.8775	3.2922
22	4.9954	5.7065	5.4698	4.1629	3.0803	3.6397	3.0308
23	4.742	5.3986	4.6022	3.94	3.0407	3.4202	2.6612
24	4.1335	4.5429	5.5072	4.0741	3.8683	3.0045	3.3105
Max	5.2092	5.7065	5.5072	4.4414	3.8912	4.0055	3.5848
Min	3.086	3.9457	4.3244	3.1855	2.9096	2.3998	2.6612
Avg	4.1396	4.7059	4.9359	3.7236	3.4535	3.0050	3.1919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 404 / 33 KV MAIN I/C LALGUDA

HV Non-Express Feeder

CKT-I Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.145	4.6571		3.7529	3.8089	3.3048	3.3608
2	3.9769	4.5542		3.7529	3.6969	3.2487	3.3048
3	3.9209	4.3896		3.5288	3.5848	3.1367	3.2487
4	3.8089	4.2798		3.5288	3.4728	3.1367	3.1927
5	3.6969	4.2135		3.2487	3.4168	3.0807	3.0807
6	3.5288	4.1027		3.1927	3.2487	2.9687	3.0247
7	3.3048	4.0055		2.9687	2.8567	2.9127	2.8567
8	3.4374	4.3439		2.8006	2.6886	2.8567	2.6326
9	3.6214	4.513		2.9687	2.7446	2.5766	2.5766
10	3.7311	4.6776	5.0503	3.0247	2.9687	2.3525	2.8006
11	3.9095	4.6776	4.8903				2.8006
12	3.9638	3.2956	3.6591	3.1367	3.0807		2.2965
13	4.0181	5.2092	4.8377	3.0247	2.5766	2.6886	2.6886
14	4.2896	4.8903	4.2981	3.1367	2.5766	2.9127	
15	4.2353	4.8903	4.7239		2.6886		
16	4.4056	4.784	4.6205	3.0247	2.6886	2.7446	
17	4.5713	4.9434	4.4593	3.0807	2.9127	2.8006	2.8006
18	3.9758	14.4856	4.3519	3.3265	3.1367	2.9127	2.9687
19	4.6742	4.784	4.6205	3.7529	3.3608	3.4728	3.4168
20	5.2126	5.0497	5.1578	3.9769	3.1927	3.9209	3.7529
21	5.2675	5.0497	4.8788	3.9769	3.5848	3.8089	3.3608
22	4.9897	4.9954	4.5182	3.9209	3.5288	3.6969	3.0247
23	4.8788	4.9931	2.9321	3.6591	3.4168	3.4728	2.8567
24	4.257	4.7125	4.9383	2.3137	3.6408	3.4168	3.5288
Max	5.2675	14.4856	5.1578	3.9769	3.8089	3.9209	3.7529
Min	3.3048	3.2956	2.9321	2.3137	2.5766	2.3525	2.2965
Avg	4.1592	5.0207	4.5291	3.3226	3.1684	3.1154	3.0274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304074 / 33 KV LALGUDA, WANI

Feeder No / Name : 405 / 33 KV MAIN I/C LALGUDA

HV Non-Express Feeder

CKT-II Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.922	4.3519	5.1578	3.8272	3.6677	2.8475	3.2036
2	3.7609	4.2444	4.9383	3.6145	3.5614	2.8475	3.1276
3	3.6534	4.0295	4.7188	3.4019	3.4019	2.7401	3.1276
4	3.4922	3.9758	4.4993	3.3848	3.3488	2.5789	3.0727
5	3.4922	3.922	4.3896	3.2236	3.2956	2.5789	3.0493
6	3.3848	3.8683	4.2798	3.1161	3.4019	2.3388	2.9384
7	3.3488	3.9963	4.4525	3.2236	3.5231	2.5789	3.1824
8	3.5368	4.213	4.6742	3.546	3.8152	2.5789	3.1893
9	3.6928	4.317	4.6776	3.4328	3.8489	2.7401	3.4385
10	3.7449	4.4753	4.7851	3.4848	3.8066	2.4188	3.3311
11	3.8489	4.5782	4.9931				3.3311
12	3.035	4.7851	4.8325	3.5368	3.6408		
13	4.369	4.8868	4.8285	3.6408	3.2247	2.7869	3.1539
14	4.421	5.0972	5.036	3.6008	2.8607	2.7869	
15	4.421	4.6811	5.0869		3.0167	2.6292	
16	4.369	4.6291	4.9343	3.6008	3.0167	2.8395	
17	4.321	4.8891	5.036	3.6008	3.2768	2.9973	2.9647
18	4.513	4.7279	4.6291	3.7037	3.4328	3.2247	3.0498
19	4.4753	5.3212	4.8354	4.1541	3.4705	3.6145	3.3311
20	5.1532	5.4841	5.3109	4.3587	3.4551	3.9638	3.5294
21	5.104	5.3212	5.2058	4.2444	3.2425	3.8009	3.2579
22	4.9429	5.647	5.3772	4.0832	3.0298	3.5837	2.963
23	4.6742	5.5384	4.537	3.8803	3.0087	3.3665	2.6337
24	4.0724	4.4593	5.4321	4.0329	3.8272	2.955	3.2579
Max	5.1532	5.647	5.4321	4.3587	3.8489	3.9638	3.5294
Min	3.035	3.8683	4.2798	3.1161	2.8607	2.3388	2.6337
Avg	4.0729	4.6433	4.8603	3.6678	3.3989	2.9453	3.1567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 201 / 11 KV Sawarla

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478	.8718	.8718	.8139	.5256	.6371	.6783
2	.8478	.8383	.8718	.78	.5087	.6203	.6443
3	.8139	.8048	.8383	.763	.5426	.6203	.6613
4	.78	.7712	.8383	.7122	.5765	.6371	.6613
5	.8299	.7545	.8048	.6783	.5765	.57	.6274
6	.6783	.7545	.7712	.6613	.5935	.5533	.5935
7	.6783	.7377	.788	.6613	.6783	.5197	.5087
8	.6783	.8551	.7209	.763	.763	.5868	.5765
9	.6613	.8718	.8718	.7291	.7461	.503	.5596
10	.6443		.8718		.7122	.5197	
11	.6443		.8478				.4239
12	.7712		.8139	.7545	.6371		.4748
13	.7545		.8478	.763	.5868	.5256	.4748
14	.7545			.7122	.5868	.4748	.4409
15	1.4754		.8309	.6613	.5868	.407	.4409
16	.8383			.7545	.5533	.4748	.4409
17	.8048			.6104	.5868	.4578	.5426
18			.9496	.5765	.57	.5087	.5765
19	.8886	.8718	.8987	.8309	.7377	.6613	.6104
20	.9892	1.0059	.9835	.8139	.6874	.7461	.6952
21	.9724	1.0227	.9835	.8309	.6706	.7969	.6613
22	1.0566	1.0059		.8139	.7042	.78	.6443
23	.9556	.9221	.8817	.763	.6539	.7122	.6274
24	.8817	.9054	.9054	.8139	.7291	.6371	.6952
Max	1.4754	1.0227	.9835	.8309	.763	.7969	.6952
Min	.6443	.7377	.7209	.5765	.5087	.407	.4239
Avg	.8368	.8662	.8596	.7391	.6310	.5886	.5765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 202 / 11 KV Laxminagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.7164	.6626	.5731		.394	.394
2	.6268	.6984	.6447	.5373		.3761	.394
3	.591	.6805	.6089	.5194		.3582	.3761
4	.591	.5731	.5731	.5014		.3582	.3582
5	.5373	.5373	.5373	.4835		.3761	.3761
6	.4656	.5194	.5014	.4656		.3761	.4298
7	.394	.4656	.4477	.4119		.3761	.3761
8	.3761	.4119	.394	.3761		.3224	.3224
9	.394	.394	.3582	.3582		.3224	.3403
10	.3582		.3582			.3224	
11	.3761		.3582				.2865
12	.4119		.3582	.3403	.3224		.2865
13	.4477		.394	.3582	.3224		4.8712
14	.4835			.3403	.3224	.2865	.3582
15	.4477		.394	.3582	.3045	.3045	.4477
16	.4477			.3582	.3403	.2865	.3403
17	.4298			.3761	.3403	.3045	.3582
18	.4477		.394	.394	.3403	.3403	.394
19	.4656	.4477	.4835	.4298	.394	.4119	.4119
20	.591	.5731	.5552	.4656	.4298	.4477	.4298
21	.6984	.6447	.5731	.5194	.4656	.5014	.4298
22	.8059	.788		.5731	.4477	.5014	.3582
23	.8059	.7522	.6089	.5014	.4298	.4477	.3761
24	.6805		.6984	.5731	.4784	.4119	.4477
Max	.8059	.788	.6984	.5731	.4784	.5014	4.8712
Min	.3582	.394	.3582	.3403	.3045	.2865	.2865
Avg	.5216	.5859	.4952	.4461	.3798	.3727	.5723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 203 / 11 KV Ekata Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4883	1.4529	1.5061	1.3112		.9391	1.0631
2	1.4175	1.4175	1.4352	1.2757		.9214	1.0277
3	1.3466	1.382	1.3466	1.2048		.9036	.9991
4	1.2757	1.3112	1.2757	1.1694		.8859	.964
5	1.2048	1.2757	1.1694	1.1163		.8682	.9922
6	1.134	1.1871	1.0985	1.0631		.8682	.9991
7	.9745	.9922	.9214	.8682		.8328	.8589
8	.8328	.9036	.7796	.8505		.7619	.7619
9	.8328	.9036	.815	.8328		.7442	.7442
10	.8682		1.0099			.7973	
11	.8682		.9745				.7442
12	.9391		.9391	.7973	.7619		.7442
13	.9745		.9214	.8505	.7442	.9036	.7442
14	1.0454			.815	.7265	.7796	.7087
15	1.0454		.9391	.815	.7087	.7619	.7265
16	1.0277			.815	.7619	.7973	.7619
17	.9922			.8328	.7619	.7796	.815
18	.9391		.9214	.8682	.8328	.815	.9922
19	1.1694	1.0454	1.134	1.0277	1.0099	.9922	1.0277
20	1.3466	1.3112	1.3112	1.1871	1.0808	1.134	1.0808
21	1.4529	1.4529	1.3466	1.2048	1.1163	1.1871	1.0808
22	1.6301	1.6478		1.2757	1.0985	1.1871	1.0277
23	1.6655		1.4175	1.2403	1.0277	1.1517	.9745
24	1.5238	1.5592	1.6124	1.3466	1.1517	.9568	1.0985
Max	1.6655	1.6478	1.6124	1.3466	1.1517	1.1871	1.0985
Min	.8328	.9036	.7796	.7973	.7087	.7442	.7087
Avg	1.1665	1.2745	1.1437	1.0349	.9064	.9077	.9103

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 204 / 11 KV DAYAL G&amp;P FEEDER

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566		.0566	.0566
2	.0566	.0566	.0566	.0566		.0566	.0566
3	.0566	.0566	.0566	.0566		.0566	.0566
4	.0566	.0566	.0566	.0566		.0566	.0566
5	.0566	.0566	.0566	.0566		.0566	.0566
6	.0566	.0566	.0566	.0566		.0566	.0566
7	.0566	.0566	.0566	.0566		.0566	.0566
8	.0566	.0566	.0566	.0566		.0566	.0566
9	.0566	.0566	.0566	.0566		.0566	.0566
10	.0566		.0566			.0566	
11	.0566		.0566				.0566
12	.0566		.0566	.0566	.0566		.0566
13	.0566		.0566	.0566	.0566	.0566	.0566
14	.0566			.0566	.0566	.0566	.0566
15			.0566	.0566	.0566	.0566	.0566
16	.0566			.0566	.0566	.0566	.0566
17	.0566			.0566	.0566	.0566	.0566
18	.0566		.0566	.0566	.0566	.0566	.0566
19		.0566		.0566	.0566	.0566	.0566
20	.0566	.0566	.0566	.0566	.0566	.0566	.0566
21	.0566	.0566	.0566	.0566	.0566	.0566	.0566
22	.0566	.0566		.0566	.0566	.0566	.0566
23		.0566	.0566	.0566	.0566	.0566	.0566
24	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Max	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.0566	.0566	.0566	.0566	.0566	.0566	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 208 / 11 KV MAIN I/C-II COTTON

HV Non-Express Feeder

MARKE Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	2.1384	2.1384	1.8755		1.3146	1.4548
2	2.0157	2.0858	2.0508	1.8054		1.1218	1.4198
3	1.9105	2.0157	1.9281	1.7353		1.2445	1.3672
4	1.8404	1.8404	1.8229	1.6651		1.1218	1.3321
5	1.7177	1.7878	1.6827	1.595		1.2269	1.3496
6	1.5775	1.6651	1.5775	1.4899		.8939	1.3847
7	1.3496	1.4022	1.3496	1.2445		1.1919	1.2094
8	1.1744	1.3146	1.1568	1.2269		1.0692	1.0692
9	1.1919	1.262	1.1568	1.1919		1.0517	1.0517
10	1.1744		1.3496			1.1043	
11	1.262		1.3146				1.0517
12	1.3672		1.3146	1.1043			1.0341
13	1.3672		1.2971	1.1568		1.1919	1.0692
14	1.4723			1.1218		1.0692	1.0517
15	1.4198		1.2971	1.1218	.9991	1.0867	1.1218
16	1.4198			1.1393	1.0867	1.0692	1.0692
17	1.3847			1.1568	1.0867	1.0517	1.1568
18	1.3496		1.3146	1.2269	1.1568	1.1568	1.3496
19	1.595	1.4723	1.5775	1.4373	1.3847	1.4022	1.4022
20	1.8755	1.858	1.858	1.6301	1.4899	1.5424	1.4899
21	2.1384	2.0683	1.9105	1.7002	1.56	1.6476	1.4899
22	2.3663	2.4013		1.8229	1.5249	1.6827	1.3672
23	2.3663	2.4188	1.9806	1.7353	1.4373	1.595	1.3496
24	2.191	2.2436	2.2786	1.9105	1.6126	1.3672	1.5074
Max	2.3663	2.4188	2.2786	1.9105	1.6126	1.6827	1.5074
Min	1.1744	1.262	1.1568	1.1043	.9991	.8939	1.0341
Avg	1.6513	1.8650	1.6178	1.4588	1.3339	1.2365	1.2673



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 402 / 33 KV MAIN I/C COTTON

HV Non-Express Feeder

MARKET C Feeder KV- 33 /  
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9036	.9568	.9568	.9036		.691	.691
2	.9036	.9568	.9568	.8505		.691	.691
3	.9036	.8505	.9036	.8505		.691	.691
4	.8505	.8505	.9036	.7973		.691	.691
5	.7973	.8505	.9036	.7442		.6379	.6379
6	.7442	.7973	.8505	.7442		.6379	.6379
7	.7442	.7973	.8505	.691		.5847	.5316
8	.7442	.9568	.7973	.7973		.6379	.5847
9	.7442	.9568	.9568	.7442		.5847	.5847
10	.691		.9568			.5847	.5316
11	.691		.9036				.4784
12	.9036		.8505	.7442			.4784
13	.7973		.9036	.7442		.4784	.4784
14	.7973			.7442	.6379	.5316	.4784
15	.7973		.8505	.691	.6379	.4252	.4252
16	.8505			.691	.6379	.4784	.4784
17	.8505			.691	.6379	.4784	.4784
18	.8505		1.0099	.6379	.6379	.5316	.5316
19	.9568	.9568	.9568	.8505	.7973	.691	.6379
20	1.0631	1.1163	1.0631	.8505	.7442	.7973	.7442
21	.9568	1.1163	1.0631	.8505	.7442	.8505	.691
22	1.0631	1.1163		.8413	.7973	.7973	.6379
23		1.0099	.9568	.8505	.7442	.7973	.6379
24	.9568	1.0099	.9568	.9036	.7973	.691	.7442
Max	1.0631	1.1163	1.0631	.9036	.7973	.8505	.7442
Min	.691	.7973	.7973	.6379	.6379	.4252	.4252
Avg	.8505	.9533	.9276	.7824	.7104	.6354	.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304075 / 33 KV COTTON MARKET, WANI

Feeder No / Name : 404 / 33 KV MAIN I/C COTTON

HV Express Feeder

MARKET C Feeder KV- 33 /  
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1491	2.2565	2.1491	1.9342		1.3432	1.5043
2	2.0416	2.1491	2.0953	1.8267		1.1283	1.4506
3	1.9342	2.0416	1.9342	1.773		1.2357	1.3969
4	1.8804	1.9342	1.8267	1.7193		1.1283	1.3432
5	1.7193	1.8267	1.7193	1.6655		1.2357	1.3432
6	1.6118	1.7193	1.6118	1.5043		.9134	1.4506
7	1.3432	1.5043	1.3432	1.2894		1.182	1.2357
8	1.2357	1.3969	1.182	1.182		1.0745	1.0745
9	1.2357	1.3432	1.182	1.182		1.0745	1.0745
10	1.2357		1.3432			1.1283	1.0208
11	1.2894		1.3432				1.0208
12	1.4506		1.2894	1.1283			1.0208
13	1.4506		1.2894	1.182		1.182	1.0745
14	1.6118			1.182	1.0208	1.0745	1.0745
15	1.5581		1.3432	1.182	1.0208	1.0745	1.182
16	1.5043			1.182	1.0745	1.0745	1.0745
17	1.4506			1.182	1.0745	1.0745	1.182
18	1.4506		1.3432	1.2894	1.182	1.1283	1.2894
19	1.6655	1.5043	1.6118	1.4506	1.3969	1.3969	1.3969
20	1.9879	1.8804	1.8804	1.6655	1.4883	1.5581	1.5043
21	2.2028	2.0953	1.9879	1.773	1.5581	1.6655	1.5043
22	2.4714	2.4177		1.8804	1.5581	1.7193	1.3969
23		2.4714	2.0416	1.773	1.4506	1.6118	1.3432
24	2.3102	2.4177	2.4177	1.9879	1.7193	1.3969	1.5043
Max	2.4714	2.4714	2.4177	1.9879	1.7193	1.7193	1.5043
Min	1.2357	1.3432	1.182	1.1283	1.0208	.9134	1.0208
Avg	1.6865	1.9306	1.6467	1.4970	1.3222	1.2455	1.2693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304091 / 33 KV MOHADA

Feeder No / Name : 201 / 11 KV Welabai Gaothan

Gaothan Feeder

Feeder Feeder KV- 11 /  
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.104	.12	.1543	.1029	.1029	.12
2	.1029	.1052	.12	.1029	.1052	.12	.12
3	.1029	.0867	.12	.1029	.0867	.1029	.12
4	.1029	.0857	.1029	.1029	.0867	.0857	.1372
5	.1029	.104	.12	.1372	.1029	.1029	.1372
6	.1029	.104	.12	.1029	.0857	.1029	.12
7	.0857	.104	.1029		.0857	.1029	.1029
8	.1029	.1029	.12	.1029	.104	.0857	.1029
9	.0857	.12	.12	.12	.1543	.12	.1478
10	.12	.1029	.12	.2058	.1543		.1478
11	.104	.0686	.1928				.1372
12	.1029	.0514	.2058	.156		.2263	.1372
13	.1029	.12	.1372	.1029		.112	.12
14	.0876	.1029	.12	.104		.2058	
15	.0867	.1029	.1029			.2058	
16	.104	.0857	.1372	.1214	.2401	.2058	
17	.1372	.1029	.1715	.12	.2229	.1715	.2401
18	.1214	.1029	.1543	.1052	.2229	.12	.2058
19	.1029	.12	.1372		.2401	.12	
20	.1402	.1372	.1372	.12	.1372	.12	.1372
21	.12	.1372	.1372		.1372	.12	.12
22	.12	.1372			.12	.12	.1029
23	.104	.12	.1372		.12	.12	.1029
24	.1029	.1029	.12	.1029	.1029	.1029	.1029
Max	.1402	.1372	.2058	.2058	.2401	.2263	.2401
Min	.0857	.0514	.1029	.1029	.0857	.0857	.1029
Avg	.1062	.1046	.1329	.1214	.1375	.1307	.1331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304091 / 33 KV MOHADA

Feeder No / Name : 202 / 11 KV Keshavnagar Ag  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	11-JUL-17
HR	Load (MW)
7	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304091 / 33 KV MOHADA

Feeder No / Name : 203 / 11 KV Mohada Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.4681	.2401	.4801	.4733	.3429	.463
2	.5487	.4115	.2401	.4115	.4334	.4458	.4287
3	.583	.3772	.2229	.463	.3988	.5658	.3944
4	.5144	.3121	.2229	.5144	.3429	.4973	.3429
5	.4287	.2804	.2229	.4115	.2743	.4458	.2743
6	.3086	.2229	.2229	.3429	.2454	.5658	.2401
7	.1715	.208	.1886	.2401	.1886	.3772	.3258
8	.1715	.2774	.2229	.2058	.1886	.2058	.2058
9	.1715	.2427	.2058	.2229	.2454	.1715	.2218
10	.5144	.2401	.3772	.2743	.5721		
11	.5434	.2229	.7888				.6348
12	.3294	.1886	.6859	.5434		.6224	.7095
13	.4733	.2058	.3944	.5895		.6173	
14	.2229	.2058	.2743	.2774		.2572	
15	.6241	.2229	.6344			.2572	
16	.6516	.2058	.6516	.6836	.3944	.4458	
17	.7802	.1886	.5316	.4115	.703	.5487	.7202
18	.3988	.2058	.703	.5316	.4458	.583	.4115
19	.7282	.2229	.6173		.5487	.5658	
20	.4854	.2572	.4287	.3294	.2572	.3429	.2572
21	.2947	.2572	.2915		.2229	.2915	.2915
22	.3258	.2572			.2572	.4458	.2915
23	.5201	.2401	.3429		.5316	.6001	.3772
24	.5658	.5959	.2401	.2572	.2601	.3944	.2572
Max	.7802	.5959	.7888	.6836	.703	.6224	.7202
Min	.1715	.1886	.1886	.2058	.1886	.1715	.2058
Avg	.4572	.2715	.3892	.3995	.3676	.4359	.3804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304092 / 33 KV PUNVAT

Feeder No / Name : 201 / 11 KV Naigaon Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4835	.5014	.5544	.4207	.3681	.3547	.3696
2	.4298	.5014	.5415	.3856	.3155	.3547	.3696
3	.4298	.5014	.5359	.3856	.3681	.3361	.3696
4	.4656	.5014	.5544	.3506	.3506	.2987	.3511
5	.394	.5014	.5175	.3506	.3155	.2614	.3326
6	.3045	.4298	.499	.2804	.2629	.2614	.2957
7	.3045	.4115	.462	.2454	.2629	.2054	.2033
8	.3761	.4801	.5544	.2103	.2279	.2054	.2033
9	.4298	.5426	.6283	.2279	.1052	.2241	.2218
10	.3814	.5375	.6268	.1928	.1753	.2054	.2033
11	.3814	.5548	.5784			.2075	.1753
12	.4161	.5487	.4733			.2075	.1578
13		.5658	.4908			.2263	.1753
14		.5658	.4733			.2241	
15	.4334	.583	.4733			.2241	
16	.5201	.5487				.2452	
17	.4578	.5316			.3109	.2452	.2103
18	.4359	.4973			.2896	.2641	.2103
19	.5197	.5731		.298	.3841	.3361	
20	.631	.6626		.4207	.4108	.4251	.4207
21	.6268	.6268			.4108	.4435	.4207
22	.5731	.5552		.4031	.4668	.4066	.3856
23	.5373	.5373	.4557	.3856	.3547	.3696	.3658
24	.4477	.5014	.5544	.4382	.3681	.3361	.3696
Max	.631	.6626	.6283	.4382	.4668	.4435	.4207
Min	.3045	.4115	.4557	.1928	.1052	.2054	.1578
Avg	.4536	.5317	.5278	.3330	.3193	.2862	.2906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304092 / 33 KV PUNVAT

Feeder No / Name : 203 / 11 KV Chargaon Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.6805	.6104	.5765	.407	.4031	.4115
2	.5087	.6805	.6443	.5765	.407	.3506	.3944
3	.5087	.6805	.6443	.5596	.3561	.3681	.3772
4	.5087	.6268	.6464	.5596	.373	.3506	.3601
5	.39	.6268	.5967	.5087	.3561	.333	.3601
6	.4239	.5373	.4973	.4409	.3222	.3155	.3429
7	.4409	.5144	.5868	.3222		.3258	.3258
8	.5087	.5658	.6706	.3052	.0848	.3086	.3511
9	.4578	.5426	.8139	.2883		.3086	.3326
10	.5895	.4508	.924	.2883		.2572	.2915
11	.6068	.5144	.8478				.2543
12	.5895	.5487	.7969			.2229	.2204
13		.583	.6443			.2229	.2543
14		.6516	.78			.2058	
15	.6935	.7282	.763			.2058	
16	.6588	.7108			.298	.2401	
17	.5765	.6935			.3109	.2743	.0678
18	.6371	.6859			.3439	.3086	.0848
19	.7377	.78		.373	.4938	.4458	
20	.929	.9156		.4748	.3734	.5144	.4917
21	.8596	.8951			.4854	.5316	.4239
22	.7164			.4748	.4668	.4458	.39
23	.6984	.6539		.4409	.4294	.4287	.3856
24	.5426	.6805	.5967	.5765	.407	.4207	.4287
Max	.929	.9156	.924	.5765	.4938	.5316	.4917
Min	.39	.4508	.4973	.2883	.0848	.2058	.0678
Avg	.5951	.6499	.6915	.4511	.3697	.3386	.3274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304096 / MOHORLI

Feeder No / Name : 201 / 11 KV VITHHAL NAGAR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1692	.3018	.1848	.0924	.1663	.0924	.463
2	.1808	.3018	.1463	.0924	.1663	.0924	.463
3	.1808	.3018	.1463	.0924	.1663	.0924	.463
4	.1808	.3018	.1463	.0924	.1478	.0924	.463
5	.192	.2881	.1448	.0934	.0924	.0924	.4515
6	.2195	.2881	.1463		.1294	.0732	.4344
7	.2503	.4515	.1267	.0905	.1086	.052	.6001
8	.3001	.5487	.1086	.0924	.1075	.104	
9	.3374	.5556	.0895	.0924	.1075	.1075	.695
10	.3374	.6093	.0532	.8642	.884	.6472	
11	.333	.5535	.1063	.8796	.7621	.6093	
12		.0937	.7225		.7042	.5281	
13		.1254	.9145	.9145	.6687	.5428	
14		.1307	.9602	1.0059	.7579		.0709
15		.128	.9602				.0716
16	.0886	.1254	.9145	1.0059	.8579		.0532
17	.0709	.1254	1.0059	.9145	.8128	.5281	.0514
18	.0693	.104	.9145	.9332	.8579	.535	.0895
19	.1267	.1463	1.0311	1.0031	.8796	.5944	.1254
20	.2378	.2033	1.0437	.1867	.1494	.6093	.1307
21	.2195	.2033	.9842	.1867	.168	.6093	.1494
22	.1848	.2012	.2218	.2033	.1478	.1663	.1478
23	.1478	.2012	.1663	.1848	.1478	.1629	.1478
24	.1738	.2601	.1829	.0924	.1663	.1478	.463
Max	.3374	.6093	1.0437	1.0059	.884	.6472	.695
Min	.0693	.0937	.0532	.0905	.0924	.052	.0514
Avg	.2000	.2729	.4759	.4340	.3981	.3085	.2912



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304096 / MOHORLI

Feeder No / Name : 202 / 11 KV MOHORLI GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17
HR	Load (MW)
1	.1663
2	.1478
3	.1478
4	.1478
5	.1478
6	.1478
7	.1307
8	.112
9	.0924
10	.0924
11	.0905
24	.1478
Max	.1663
Min	.0905
Avg	.1309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

WANI S DIV[314]

BU 1716

Substation No/ Name :- 304096 / MOHORLI

Feeder No / Name : 203 / 11 KV NAVEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9061	1.0669	.5792	
2			.9061	1.0669	.5639	
3			.8592	1.0669	.5716	
4			.8333	1.0669	.5639	
5			.8383	1.0669	.5716	
6			.8535		.543	
7			.9297	.9297	.5144	
8			1.142	1.1883	.5144	
9			1.3748	1.2191	.5144	
10	.8749	.8796	1.3123	1.2342	.5201	
11	1.034	1.2967	1.3748	1.2186	.5053	
12		1.3441				
13		1.3435				
14		1.3123				.4715
15		1.3441				.4572
16	.2968	1.3435				.4344
17	.6706	1.3279				.4287
18	1.0031	1.3272				.3572
19	1.0623	1.2809				.3243
20	.7316					.3243
21	.7773					
22	.7621					
23	.7621					
24			.8579	1.0669	.5792	
Max	1.0623	1.3441	1.3748	1.2342	.5792	.4715
Min	.2968	.8796	.8333	.9297	.5053	.3243
Avg	.7975	1.2800	1.0157	1.1083	.5451	.3997

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 201 / 11 KV Khadkdoh Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0381
2					.0381
3					.0381
4					.0381
5					.0381
6					.0381
7					.0381
8			.0381		.0381
9			.0381		
17	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381		.0381	.0381
19	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381
23	.0381			.0381	.0381
24					.0381
Max	.0381	.0381	.0381	.0381	.0381
Min	.0381	.0381	.0381	.0381	.0381
Avg	.0381	.0381	.0381	.0381	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 202 / 11 KV Susari P Ag  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6097	1.1622
2						.6097	1.1622
3						.6097	1.1622
4						.6097	1.1622
5						.6097	1.1622
6						.6097	1.1622
7						.463	1.0094
8						.4807	
9							1.174
10							1.2186
11							1.1591
12							1.174
13						.9061	1.2483
14						.9297	1.2037
15				1.4403			
16				1.4575			
17					.6097	1.1622	
18					.6097	1.1622	
19				1.7147	.6097	1.1622	
20				1.7147	.6097	1.1622	
21				1.7147	.6097	1.1622	
22				1.7147	.6097	1.1622	
23	.9335	1.5051	1.8671		.6097	1.1622	
24	.4382	.9335	1.5051	1.829		.6097	1.1622
Max	.9335	1.5051	1.8671	1.829	.6097	1.1622	1.2483
Min	.4382	.9335	1.5051	1.4403	.6097	.463	1.0094
Avg	.6859	1.2193	1.6861	1.6551	.6097	.8435	1.1659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 203 / 11 KV Sakhara AG (Ghonsa) Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926		.7514		.5784	.6316	.816
2	.3109		.7514		.6036	.6316	.717
3	.2926		.7493		.5868	.6605	.6805
4	.3109		.7293		.5784	.6605	.569
5	.3109				.5952	.6605	.6465
6	.3109		.7362		.5952	.6763	.5562
7						.6859	.7049
8				1.0098		.6859	
9				1.0098			
15	.4578		1.5074			.7186	
16	.5256		1.5238			.7407	
17		1.2729	1.4376	1.0808	.8383	.7637	1.0442
18		1.1235	1.3575		.8383	.8679	.9945
19		1.1381	1.2989	.8869	.8383	.9205	.7625
20		1.0183	1.1965		.6313	.8194	.7459
21		1.0687	1.0469		.5692	.8023	
22		1.0413	.9019	.8603	.6929	.8641	
23		1.0242	.6866	.5916	.5712	.8256	
24	.3077		.7625	.6866	.5868	.6605	.8266
Max	.5256	1.2729	1.5238	1.0808	.8383	.9205	1.0442
Min	.2926	1.0183	.6866	.5916	.5692	.6316	.5562
Avg	.3467	1.0981	1.0291	.8751	.6503	.7376	.7553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 204 / 11 KV Ghonsa Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6401	.567	.5487	.4409	.4607
2			.6401	.567	.5487	.4207	.4252
3			.6219	.5487	.5487	.4031	.4344
4			.6036	.5487	.5487	.4075	.4207
5				.5304	.5304	.3772	.3898
6			.4066	.4207	.439	.3681	.3721
7			.2957	.3696	.3511	.3155	.3012
8			.3696	.3189	.3511	.3366	
9	.3641	.4161		.362	.362	.3439	
10	.3121	.3988	.3467		.362	.3439	
11	.3121	.4161	.2947		.3439	.2743	
12	.3641	.4508	.2774		.3109	.2743	.2926
13	.3814	.3988	.2915		.3109	.2743	.2926
14	.2601		.2915		.2926	.2926	.2743
15	.2774	.3988	.2601		.2926	.2743	.2743
16	.2427	.3641	.2774		.3439	.2743	.2774
17		.3721	.3721	.3189	.3292	.3012	.2601
18		.3898	.4075		.3801	.3012	.2947
19		.4835	.5609	.5493	.5258	.5138	.4681
20		.7087	.6762	.6556	.5731	.6201	.5548
21		.7619	.6836	.6733	.567	.5847	
22		.7087	.6415	.6379	.5316	.567	
23		.6556	.6219	.5487	.4961	.5487	.3988
24			.6584	.5853	.567	.4784	.4784
Max	.3814	.7619	.6836	.6733	.5731	.6201	.5548
Min	.2427	.3641	.2601	.3189	.2926	.2743	.2601
Avg	.3143	.4946	.4654	.5126	.4356	.3890	.3706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 205 / SAKHARA GAOTHAN (Ghonsa)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
9	.394	.362	.3761
10	.4298	.362	.3761
11	.394	.3077	
12	.3258	.2561	
13	.2743	.2561	
14	.2926	.2743	.3109
15	.3109	.2743	.2926
16	.3109	.2561	.2743
Max	.4298	.362	.3761
Min	.2743	.2561	.2743
Avg	.3415	.2936	.326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304014 / 33 KV GHONSA

Feeder No / Name : 206 / 11 KV Khadkdoh GF

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121		1.0867	.2561	.7164	.2915	.7282
2	.4938		1.1043	.2587	.691	.2947	.6935
3	.4755		1.0867	.2218	.691	.2743	.6762
4	.4572		1.0692	.2241	.7087	.2743	.6104
5	.4572			.2054	.7087	.2601	.6068
6	.4435		.9922	.168	.7522	.2427	.5596
7			.1307	.1307	.1663	.1214	.1267
8			.168	.124	.1307	.124	
9	.1227	.1227	.1402	.1227	.1294	.1109	.1478
10	.1227	.1227	.1402		.1294	.1294	.1478
11	.1227	.1227	.1227		.1294	.1294	.1478
12	.1227	.1227	.1227	.1227	.1294		.1478
13	.1227	.1227	.1227		.1294	.1294	.1478
14	.1227		.1227	.1052	.1294	.1294	.1478
15	.1227	1.1142	.1227	.1052	.1478	.1294	.6802
16	.1227	1.2793	.1227		.1478	.1294	.7122
17	1.0631	1.3763	1.4752	.9282	.663	.7459	.78
18		1.1437	1.543		1.0004	.7461	.763
19		1.0852	1.3435	1.1361	1.0288	.8817	.763
20		1.3565	1.326	1.0852	.2543	.8648	.7716
21		1.283	1.3032	.9774	.3601	.8309	
22		1.2483	1.1437	.8478	.3467	.8059	.0876
23		1.1096	1.1744	.7522	.3222	.8402	.0876
24	.4917		1.0985	1.0985	.7343	.3086	.7373
Max	1.0631	1.3763	1.543	1.1361	1.0288	.8817	.78
Min	.1227	.1227	.1227	.1052	.1294	.1109	.0876
Avg	.3360	.8293	.7418	.4668	.4311	.3824	.4669



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304019 / 33 KV PATAN

Feeder No / Name : 201 / 11 KV Patan

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6687	.6859		.6516	.6001	.5487
2	.6687	.7373	.7202	.6001	.6344	.6001	.5487
3	.6516	.703	.6344	.6516	.6344	.5658	.5487
4		.5487	.5658	.6516	.6001	.5658	.5316
5	.6859	.5316	.5487	.6344	.6001	.5144	.5144
6	.583	.5316	.6516	.6001	.583	.4458	.463
7	.4458	.4801	.5316	.463	.4458	.3944	.3944
8	.3772	.7716	.4973	.3944	.3944	.3601	.3429
9	.3944	.5144	.5487	.3772	.3772	.3086	.3429
10	.3429	.3258	.5658	.3429	.3601	.2743	.3086
11	.4287	.4973	.4458	.3429	.3086	.2743	
12	.4287	.5316	.5144	.2915	.3086	.2572	
13	.463	.5658	.6173	.2401	.3086	.2915	
14	.4458	.4973	.6001	.2572		.2915	.3258
15	.463	.6344	.583	.2572	.2915	.3086	.3258
16	.463	.5658	.583	.2401	.3086	.2915	.3772
17	.4458	.5144	.583	.3772	.3258	.2915	.3601
18	.5316	.5144	.6001	.1372	.3429	.3258	.3772
19	.6001	.6173	.703	.6001	.5144	.3944	.5144
20	.8573	.823	.8745	.7545	.6516	.6859	.7202
21	.8573	.8573	.8402	.7716	.6859	.7202	.703
22	.7716	.8059	.7888	.7545	.6516	.6687	.703
23	.7716	.7716	.7716	.7202	.6173	.6173	.6687
24	.6859	.7716	.7716	.7545	.703	.6001	.583
Max	.8573	.8573	.8745	.7716	.703	.7202	.7202
Min	.3429	.3258	.4458	.1372	.2915	.2572	.3086
Avg	.5688	.6159	.6344	.4876	.4913	.4437	.4858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304019 / 33 KV PATAN

Feeder No / Name : 203 / 11 KV Kharbada

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2572	.2401		.2058	.2058	.1886
2	.2058	.1886	.2058	.1715	.1886	.1886	.1886
3	.2058	.1886	.1886	.1543	.1715	.1886	.1715
4		.2401	.1886	.1543	.1715	.1886	.1715
5	.2058	.2058	.2058	.1543	.1715	.1715	.1543
6	.1715	.2229	.1886	.1715	.1543	.1715	.1372
7	.1543	.1886	.2058	.12	.1372	.1372	.1372
8	.12	.1715	.2229	.12	.1372	.1029	.1029
9	.1029	.1886	.2229	.12	.12		.0857
10	.1029	.1543	.2058	.1029	.1029	.1029	.0686
11	.12	.1886	.2229	.0686	.1029	.1029	
12	.1029	.1886	.2058	.0857	.0857	.0857	.0343
13	.1543	.2401	.1715	.0857	.1029	.0857	.1029
14	.1715	.2058	.1886	.12		.1029	.1029
15	.1715	.2229	.1886	.1029	.0857	.1029	.1029
16	.1543	.2229	.2058	.1029	.1029	.0857	.0857
17	.1715	.2058	.2058	.1029	.1029	.0857	.0857
18	.1715	.1886	.2058	.1372	.12	.1029	.1029
19		.2401	.2572	.1715	.1715	.1543	.1372
20	.2743	.3086	.2915	.1886	.2229	.2058	.1372
21	.3086	.3086	.2572	.2401	.2401	.2401	.2058
22	.2743	.2401	.2401	.2229	.2401	.2058	.1886
23	.2572	.2401	.2229	.2229	.2229	.2058	.1886
24		.2229	.2401	.2229	.2058	.2058	.1886
Max	.3086	.3086	.2915	.2401	.2401	.2401	.2058
Min	.1029	.1543	.1715	.0686	.0857	.0857	.0343
Avg	.1796	.2179	.2158	.1454	.1551	.1491	.1335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304025 / 33 KV KAYAR

Feeder No / Name : 202 / 11 KV Kayar AG (Kayar)

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.5975	.7682	.462	.2241	.2218	.2801
2	.3174	.5975	.7682	.4435	.2427	.2427	.2614
3	.3174	.6161	.7316	.4435	.2614	.2452	.2614
4	.3142	.6348	.8048	.4435	.2241	.2263	.2614
5	.3361	.6348	.8413		.2427	.2614	.2614
6	.3511	.6348	.8779	.4805	.2241	.2641	.2614
7	.3696	.8589	1.0974	.4435	.2614	.2772	.3734
8	.4805	1.1203	1.5364	.4066		.2614	.4108
9	.462	1.2136	1.5729	.7468	.2987	.3547	
10	.3326	.695	1.3717	.8589	.4294	.5041	
11	.3734	.7499	.7762	.8215	.3734	.8316	.3206
12		.8048	.8131	.9522	.3734	.7468	.3018
13		.8048	.8131	.8962	.5601	.7468	
14		.8048	.7762	.8402	.5914		
15		.9145		.8589	.5914		
16		.8779	.9055		.6099	.7468	
17		.8413	.9425	.3921	.6099	.7468	
18	.5228	.7133	.924	.2614		.7842	.3921
19	.5788	.6653	.7023	.2241	.2402	.7468	.2987
20	.5415	.7207	.6468	.3174		.5975	.3018
21	.5228	.6584	.5544	.2987	.2614	.5975	.2829
22	.5975	.5853	.5359	.2614	.2614	.5975	.2829
23	.5975	.5729	.4805	.2614	.2241	.2987	.2641
24	.3326	.5788	.7865	.4805	.2427	.2241	.2801
Max	.5975	1.2136	1.5729	.9522	.6099	.8316	.4108
Min	.3142	.5729	.4805	.2241	.2241	.2218	.2614
Avg	.4269	.7457	.8708	.5270	.3499	.4784	.2998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304025 / 33 KV KAYAR

Feeder No / Name : 204 / 11 Kv Delight Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.056	.0554	.0934	.0747
2	.056	.0934	.0747	.0554	.0747	.0739
3	.056	.0373	.056	.0554	.0747	.0739
4	.056	.056	.0747	.0739	.056	.0747
5	.056	.0747	.0747	.0739	.0373	.0754
6	.056	.0747	.056	.0554	.056	.0566
7	.056	.056	.0934	.0554	.0747	.0554
8	.0187	.0187	.0187	.0185	.0187	.056
9	.0554	.0187	.0187		.0373	.0373
10	.0739	.0373	.0747		.056	.0373
11	.056	.056	.0739		.0739	.056
12		.0934	.0739		.0739	.056
13		.056	.0554		.0187	.056
14		.0187	.037		.0554	
15		.056	.037		.0554	
16		.0747	.037		.0739	
17		.0373	.037	.056	.0739	
18	.056	.056	.037	.056	.0554	
19	.0747	.056	.0554	.056	.0924	
20	.0373	.0187		.0187	.0373	
21	.0747	.0747		.0934	.0739	
22	.0747	.0934		.0747	.0754	
23	.056	.056	.0554	.0747	.0754	
24	.056	.056	.0373	.056	.056	.0754
Max	.0747	.0934	.0934	.0934	.0934	.0754
Min	.0187	.0187	.0187	.0185	.0187	.0373
Avg	.0570	.0552	.0540	.0581	.0612	.0613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304025 / 33 KV KAYAR

Feeder No / Name : 205 / 11 KV Kayar Gaothan  
(Kayar) Feeder KV- 11 /  
OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3734	.4108	.3326	.3361	.2957	.3734
2	.3734	.3734	.3734	.3326	.2987	.2987	.3734
3	.3696	.3361	.3734	.3326	.2987	.3018	.3734
4	.3326	.3361	.3734	.3326	.2614	.3018	.3361
5	.3142	.2987	.4108	.3142	.2614	.2641	.3361
6	.2801	.2987	.3361	.2957	.2614	.2641	.2987
7		.2614	.3361	.2587	.2241	.2641	.2614
8	.2241	.2614	.2614	.2218	.2241	.2241	.2614
9	.2033	.2987	.2614	.2241	.2241	.2241	
10	.2033	.2987	.2614	.2054	.2218	.2241	
11	.1867	.2987	.2033	.1494	.1867	.1867	.2263
12		.2987	.2033	.1867	.1848	.1867	.1886
13		.2987	.1848	.1494	.1494	.2241	.2241
14		.2614	.2033	.1867	.1848		
15		.2801	.1848	.1867	.2218		
16		.2614	.2218		.1848		.1867
17		.2614	.2402		.1867	.2241	.1848
18	.2987	.2987	.2772			.2614	.2241
19	.3734	.3734	.3696	.3361	.2957	.3734	.3734
20	.4481	.4668		.3734	.4108	.4108	.415
21	.4481	.4481		.4108	.4066	.4108	.415
22	.4108	.4668		.3921	.3734	.3734	.3734
23	.3734	.4108	.3734	.3734	.3361	.3734	.3361
24	.3547	.3734	.4108	.3696	.3361	.3361	.3734
Max	.4481	.4668	.4108	.4108	.4108	.4108	.415
Min	.1867	.2614	.1848	.1494	.1494	.1867	.1848
Avg	.3262	.3306	.2986	.2840	.2639	.2868	.3067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304025 / 33 KV KAYAR

Feeder No / Name : 206 / 11 KV Purad Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	1.0829	1.134	.499	.9335	.7468	.9877
2	.8686	1.0456	1.0974	.499	.8962	.7468	.9709
3	.8686	.9335	1.0974	.4805	.7468	.7468	.9709
4	.7762	.8589	1.134	.462	.6722	.6722	.9335
5	.7762	.7842	1.1706	.462	.5975	.6722	.8962
6	.7392	.7468	1.2071	.4435	.5601	.7095	.8589
7	.6838	.9335	1.2437	.4066	.5601	.7095	.6348
8	.462	1.2696	1.4266	.3696		.6722	.6348
9	.5544	1.2696	1.4266		.5228	.4854	
10	.8131	1.2803	1.39		.5228	.4854	
11	.8402	1.4998	1.423			.4668	.7545
12		1.4632	1.4969			.4854	.7762
13		1.6095	1.4784			.4854	.7762
14		1.4632	1.423				.7468
15		1.7193	1.2936				.7922
16		1.4632	1.3491		.3361	.3734	.7922
17		1.4632	1.2012	.4108	.5601	.3734	.8402
18	1.1203	1.6827	1.0349	.7095	.5914	.3734	.7762
19	1.1949	1.6095	1.1458	.6722	.7762	.7468	1.0374
20	1.307	1.2803		.8215	.8962	.8215	1.094
21	1.3443	1.5729		.9335	.924	.8215	1.0374
22	1.4937	1.4998		.9335	.9335	.8589	1.0349
23	1.2323	1.4632		.9709	.9335	.9709	.9808
24	.924	1.1203	1.0974	.5544	1.0082	.8589	1.0082
Max	1.4937	1.7193	1.4969	.9709	1.0082	.9709	1.094
Min	.462	.7468	1.0349	.3696	.3361	.3734	.6348
Avg	.9381	1.2965	1.2635	.6018	.7206	.6492	.8789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304041 / 33 KV MUKUTBAN (RUIKOT)

Feeder No / Name : 201 / 11 KV Mukutban (Mban) Sheddable Rural/Mix Feeder  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463		.4801		.4458	.3201	
2	.4801		.4801	.4268	.4458	.3201	
3	.4801		.4801	.4268	.4458	.3201	
4			.4801	.4268	.4287	.3067	
5	.4801		.4801		.4287	.3067	
6	.463		.4801		.4287	.2934	
7	.4115		.4115	.4268	.3772	.2934	
8	.3772	.3429	.4115	.4115	.3772	.2801	
9	.3772	.3772	.4115				
10	.3772	.3944	.4115				.3086
11	.3429	.3944	.4287				.2743
12		.4287	.4801			.3258	.2743
13	.4115	.4801	.4801				.3086
14	.4801	.5144	.4801				.2915
15	.4115	.4801	.4115		.3429		.2401
16	.4115	.4115	.4115	.3086	.2934	.4115	.3429
17	.3658	.4115	.4268	.3429	.2534	.3086	.3086
18	.3048	.3772	.4268	.3772	.2934	.3772	.3429
19	.3658	.4801	.4877	.4801	.3467	.4115	.4115
20	.4572	.5658	.4268	.5144	.4134	.4801	.4973
21	.4572	.6173	.4268	.5144	.4134	.4801	.4801
22	.4268	.6173	.4268	.4973	.3734	.4801	.4287
23	.4268	.5487	.4268	.4268	.3467	.4115	.4115
24	.5144		.4801		.4458	.3334	.4115
Max	.5144	.6173	.4877	.5144	.4458	.4801	.4973
Min	.3048	.3429	.4115	.3086	.2534	.2801	.2401
Avg	.4221	.4651	.4478	.4293	.3834	.3589	.3555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304041 / 33 KV MUKUTBAN (RUIKOT)

Feeder No / Name : 202 / 11 KV Ardhawan Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.04		.0514	.0152	.0133	.0133	.0171
2	.04		.0514	.0152	.0133	.0133	.0171
3	.04		.0514	.0152	.0133	.0133	.0171
4							.0171
5	.04						.0171
6	.04						.0171
7	.04						.0171
8	.04	.08					.0171
9	.0686	.08					.0171
10			.2058		.1067		
11			.2058		.08		
12			.1715		.0533	.0533	
13			.1715		.0533	.04	
14			.1029			.04	
15			.1029		.0686		
16	.0133	.0133	.1029	.08	.04		.0133
17		.0171	.1219	.0667	.04		.0133
18		.0171	.0152	.0133	.0133		.0133
19		.0171	.0152	.0133	.0133		.0133
20		.0171	.0152	.0133	.0133	.0171	.0133
21		.0171	.0152	.0133	.0133	.0171	.0133
22		.0171	.0152	.0133	.0133	.0171	.0133
23		.0171	.0152	.0133	.0133	.0171	.0133
24	.0267		.0514	.0152	.0133	.0133	.0171
Max	.0686	.08	.2058	.08	.1067	.0533	.0171
Min	.0133	.0133	.0152	.0133	.0133	.0133	.0133
Avg	.0389	.0293	.0823	.0239	.0338	.0232	.0154



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304041 / 33 KV MUKUTBAN (RUIKOT)

Feeder No / Name : 203 / 11 KV Mangali

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677		.2572		.1372	.1677	.1372
2	.1829		.2572	.2134	.1372	.1677	.1372
3	.1829		.2572	.2134	.1372	.1677	.1372
4			.2572	.2134	.1372	.1677	.1372
5	.1677		.3429		.1372	.1524	.1886
6	.1677		.3429		.1524	.1372	.1886
7	.1981		.5316	.1981	.1372	.1677	.1886
8	.1829	.4115	.5658	.1677	.1219	.1677	.2058
9	.2915	.4268	.703		.1715		.1715
10	.2743	.442	.6687		.1372		.1219
11	.1524	.4268	.6516		.1372		.1372
12	.1981	.4725	.6859		.1029	.1219	.1372
13	.2439	.4572	.703		.1029	.1219	.1677
14	.2591	.5335	.4458			.1219	.1677
15	.2591	.5487	.5487		.1029		.1372
16	.3048	.4572	.5144	.0914	.0914	.1219	.1219
17		.583	.4877	.0914		.1029	.1372
18		.5487	.4115	.1219	.1524	.1372	.1524
19		.5658	.3963	.1677	.1677	.1715	.1524
20		.4973	.3658	.1981	.2134	.1886	.1829
21		.4287	.3048	.1829	.1981	.1886	.1829
22		.4287	.2591	.1677	.1829	.1372	.1677
23		.2401	.2591	.1524	.1677	.1372	.1677
24	.1677		.2401	.2439	.1372	.1677	.1372
Max	.3048	.583	.703	.2439	.2134	.1886	.2058
Min	.1524	.2401	.2401	.0914	.0914	.1029	.1219
Avg	.2126	.4668	.4357	.1731	.1438	.1507	.1568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304041 / 33 KV MUKUTBAN (RUIKOT)

Feeder No / Name : 204 / 11 KV Express

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061		.0514		.061	.0533	.0686
2	.061		.0514	.0457	.061	.0533	
3	.061		.0514	.0457	.061	.0533	
4			.0514	.0457	.061	.0533	
5	.061		.0514		.061	.0533	
6	.061		.0514		.061	.0533	
7	.0457		.0514	.0457	.061	.0533	
8	.0457	.0305	.0514		.061	.0533	
9	.0343	.0305	.0514		.0686		
10	.0343	.0305	.0514		.0686		.061
11	.0305	.0305	.0514		.0686		.061
12	.0305	.0305	.0514		.0686	.061	.061
13	.0305	.0457	.0514		.0686	.061	.061
14	.0305	.0457	.0514			.061	.061
15	.0305	.0457	.0514		.0686		.061
16	.0305	.0457	.0514	.061	.0533	.061	.061
17		.0514	.0457	.061	.0533	.0686	.061
18		.0514	.0457	.061	.0533	.0686	.061
19		.0514	.0457	.061	.0533	.0686	.061
20		.0514	.0457	.061	.0667	.0686	.061
21		.0514	.0457	.061	.0667	.0686	.061
22		.0514	.0457	.061	.0667	.0686	.061
23		.0514	.0457	.061	.0533	.0686	.061
24	.0457		.0514	.0457	.061	.0533	.0686
Max	.061	.0514	.0514	.061	.0686	.0686	.0686
Min	.0305	.0305	.0457	.0457	.0533	.0533	.061
Avg	.0434	.0434	.0497	.0551	.0621	.0602	.0620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304041 / 33 KV MUKUTBAN (RUIKOT)

Feeder No / Name : 205 / 11 KV Ardhawan Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086		.3429		.2915	.2915	
2	.3086		.3429	.2439	.2743	.2915	
3	.3086		.3429	.2439	.2743	.2915	
4			.3429	.2439	.2743	.2915	
5	.3258		.2915		.2743	.2743	
6	.2743		.2915		.2401	.2401	
7	.2058		.2229	.0914	.2058	.1715	
8	.1715	.2229	.2401		.2058	.1715	
9	.1715	.2229	.2401		.1543		
10	.1715	.2229	.1886		.12		.12
11	.1372	.2229	.1886		.12		.1029
12	.1715	.2572	.1715		.1029	.1029	.1029
13	.1715	.2058	.2058		.12	.12	.12
14	.1886	.2572	.1715			.1372	.12
15	.2058	.2915	.1715		.12		.1372
16	.1543	.2572	.1715	.12	.1029	.12	.1029
17		.2058	.1677	.1372	.0686	.12	.12
18		.2229	.1981	.1886	.1543	.1372	.2572
19		.3086	.2743	.2743	.2572	.3258	.2743
20		.3772	.3048	.3258	.3429	.3429	.3258
21		.4115	.3048	.2915	.3429	.3429	.3258
22		.4115	.3048	.3086	.3086	.2915	.3086
23		.3429	.3048	.3086	.2915	.2915	.2915
24	.3086		.3429	.3048	.2915	.2915	.2915
Max	.3258	.4115	.3429	.3258	.3429	.3429	.3258
Min	.1372	.2058	.1677	.0914	.0686	.1029	.1029
Avg	.2240	.2776	.2554	.2371	.2147	.2323	.2000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304080 / 33 KV ZARI

Feeder No / Name : 202 / 11 KV Zari Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.3856	.3506		.3429	.2743	.333
2	.3506	.3681	.3506	.333	.2572	.2572	.3506
3	.3155	.333	.3506		.2572	.2572	.3155
4		.3681	.3506		.2572	.2572	.333
5	.2804	.3506	.3506	.3155	.2572	.2572	.3506
6	.298	.3506	.2804		.2572	.2572	.3155
7	.2629	.3155	.3155	.2804	.2915	.2743	.2804
8	.2804	.3155	.3506	.2743	.2915	.2572	.2279
9		.3155	.3681	.2915	.2229	.2401	
10	.2629	.333	.3506	.2058	.2229	.2229	.2229
11	.2454	.298	.2629	.2229	.1715		.1543
12	.2454	.298	.2629	.1886	.1715	.1928	.2058
13	.2454	.298		.1715	.2058	.2103	.12
14	.2629	.3155	.2454	.2058	.2058	.2103	.1372
15	.2103	.298	.2454		.1715	.2103	.1372
16	.2103	.298	.2454	.1886	.1715	.2103	.2058
17	.298	.3506	.3681	.1886	.2058	.2279	.2058
18	.3506	.4031	.5258	.2401	.2401	.2279	.2743
19	.4733	.4207	.5434	.2915	.3086	.3681	.2915
20	.4733	.4207	.5083	.3601	.3429	.3856	.2915
21	.4382	.4382	.4207	.3429	.3429	.3856	.2058
22	.4382	.3681	.4031	.3429	.3086	.3681	.333
23	.4031	.4207	.4031	.3429	.3086	.3506	.333
24	.4031	.3856	.3681	.3856	.3429	.2743	.3681
Max	.4733	.4382	.5434	.3856	.3429	.3856	.3681
Min	.2103	.298	.2454	.1715	.1715	.1928	.12
Avg	.3235	.3520	.3574	.2722	.2565	.2686	.2606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304080 / 33 KV ZARI

Feeder No / Name : 203 / 11 KV Jamani Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0175	.0351		.0171	.0171	.0175
2	.0175	.0175	.0351		.0171	.0171	.0175
3	.0175	.0175	.0351		.0171	.0171	.0175
4		.0175	.0351		.0171	.0171	.0175
5	.0175	.0175	.0351		.0171	.0171	.0175
6	.0175	.0175	.0343		.0171		.0175
7	.0526	.2279	.5083		.0343	.0857	.0701
8	.1052	.3155	.4908		.0343	.0686	.0351
9	.0701	.3681	.5083	.0343	.0857	.0686	.1372
10	.1753	.3681	.5609	.1372	.0686	.0514	.1372
11	.0351	.0351	.0351	.0171	.0343		.0171
12	.0351	.0351	.0351	.0171	.0343	.0351	.0171
13	.0351	.0351	.0351	.0171	.0343	.0351	.0171
14	.0351	.0351	.0351	.0171	.0343	.0351	.0171
15	.0351	.0351	.0351	.0171	.0343	.0351	.0171
16	.0351	.0351	.0351	.0171	.0343	.0351	.0343
17	.2103	.5258	.631	.0857	.1029		.0343
18	.3155	.6485	.6135	.1029	.1372	.0526	.0343
19	.1753	.5959	.6135	.1029	.0857	.0526	
20	.1753	.5784	.5959	.0857	.0514	.0351	.0171
21	.0175	.0351	.0175	.0343	.0343	.0175	.0175
22	.0175	.0175	.0175	.0343	.0343	.0175	.0175
23	.0175	.0175	.0175	.0343	.0343	.0175	.0175
24	.0175	.0175	.0175	.0175	.0171	.0343	.0175
Max	.3155	.6485	.631	.1372	.1372	.0857	.1372
Min	.0175	.0175	.0175	.0171	.0171	.0171	.0171
Avg	.0716	.1680	.2089	.0482	.0429	.0363	.0330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304094 / 33kV Adegaon SS

Feeder No / Name : 201 / 11 kV Kahatera

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.0895	.0709	.0532
2		.0905	.0924	.0724	.0532
3		.0914	.0914	.0532	.0543
4		.0924	.0914	.0537	.0537
5			.0895	.0526	.0537
6			.0739	.0532	.0532
7		.0905	.0732	.0543	.0526
8		.0543	.0732	.1063	.0354
9		.0549	.0724	.0701	.0351
10		.0537	.0739	.0354	.0358
11		.0537	.0716	.0362	.0362
12	.4207	.0554	.0554	.0354	.0358
13	.4344	.0554		.0526	.0358
14	.4066	.0537		.0358	.0358
15	.394	.0543		.0526	.0354
16	.3801	.0724	.0537	.0351	.0362
17	.3582	.0739	.0362	.0362	.0354
18	.3326	.0924	.0549	.0354	.0537
19	.3475	.0914	.0724	.0354	.0716
20	.2686	.1086	.1075	.0354	.0905
21	.181	.1109	.128	.0354	.0895
22	.124	.1086	.128	.0526	.0895
23	.0924	.0895	.0914	.0526	.0886
24		.0924	.0924	.0905	.0526
Max	.4344	.1109	.128	.1063	.0905
Min	.0924	.0537	.0362	.0351	.0351
Avg	.3117	.0788	.0815	.0518	.0528

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PANDHARKAWADA DN.[632]

ZARI-JAMANI S/DN.[818] BU 4818

Substation No/ Name :- 304094 / 33kV Adegaon SS

Feeder No / Name : 202 / adegaon mix

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3366		.2149	.3439	.1928
2	.3155		.2149	.3155	.197
3	.3224	.2686	.2218	.3077	.1991
4	.2686	.2686	.2149	.2686	.1949
5	.2686		.2172	.2534	.1991
6	.2658		.2378	.1753	.1949
7	.2507	.2587	.2353	.1629	.1949
8	.2481	.1991	.2402	.1612	.1753
9	.3012	.197	.1991	.1629	.1772
10	.3045	.1448	.2012	.1254	
11	.3761	.1433		.181	
12	.3721	.1448	.1646	.1052	
13	.3761	.1478	.1612	.1052	
14	.3721	.1448		.1267	
15	.394	.1478	.1829	.1402	
16	.4607	.1829	.1595	.181	
17		.2218	.1629	.2172	
18		.2328	.2149	.2103	
19		.2686	.2772	.2172	
20		.2896	.3439	.2195	
21		.3258	.3475	.2103	.3366
22		.3258	.3511	.1991	.3439
23	.4656	.2772	.3582	.1949	.3012
24	.3403	.2534	.2353	.362	.1949
Max	.4656	.3258	.3582	.362	.3439
Min	.2481	.1433	.1595	.1052	.1753
Avg	.3355	.2222	.2344	.2061	.2232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304010 / 33KV DHANKI

Feeder No / Name : 201 / 11kv KRISHNAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6097	1.1431	1.0288	.6478	.6097	1.0288
2	.5716	.6478	1.1622	1.0288	.6668	.6097	1.0479
3	.6478	.6859	1.2193	1.2193	.6668	.6478	1.0479
4	.6859	.8383	1.2574	1.2193	.6859	.6478	1.0479
5	.7621	1.0288	1.3336	1.3336	.6859	.6668	.9717
6	.8002	1.105	1.4098	1.4861	.6859	.6859	.9526
7	1.1431	1.1431	1.5623	1.448	.5716	.9526	.9526
8	1.1812	1.1622	1.2574	1.4861	.5144	1.0288	1.1431
9	1.2193	1.3336	1.105	1.2574	.4572	1.0288	1.0288
10	.7049	.9907	.9717	1.0669	1.0669		.7811
11	.6478	1.1431	1.4098	1.2574	1.3336		.8002
12	1.0288	1.1431	1.5242	1.3336	1.829		.743
13	1.0288	1.1622	1.6004	1.2574	1.848		.7811
14	1.0479	1.105	1.2955	1.0669	1.4861		.7621
15	1.0479	1.0479	1.4098	1.1431	1.7909	.5525	
16	.9907	1.0098	1.5051	1.1431	1.9243	.6859	
17	.9717	.9907	1.5432	1.1812	1.9243	.8764	.8002
18	.6859	.7049	.6478	.4954	1.1431	.9526	.4572
19	.724	.7621	.743	.6287	.5716	.9907	.4954
20	.724	.7621	.743	.6859	.6859	.8192	.5716
21	.724	.7621	.724	.6859	.724	1.1431	.6859
22	.724	.724	.724	.6478	.7049	.6859	.6859
23	.724	.724	.7049	.6097	.6859	.7049	.6097
24	.5716	.6097	1.1622	.9145	.6478	.6859	.9907
Max	1.2193	1.3336	1.6004	1.4861	1.9243	1.1431	1.1431
Min	.5716	.6097	.6478	.4954	.4572	.5525	.4572
Avg	.8304	.9248	1.1733	1.0677	.9979	.7882	.8357



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304010 / 33KV DHANKI

Feeder No / Name : 202 / 11kv GANJEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3336	.7621	.5716		
2			1.3336	.8002	.5716		
3			1.4289	.8764	.6097		
4			1.3908	.9145	.6478		
5			1.3717	.9526	.6478		
6			1.3336	.9907	.6668		
7			1.5813	1.2193	.6859		
8			1.6766	1.4861	.724		
9			1.7337	1.448	.8192		
10	1.3336	1.2765					.9335
11	1.4861	2.6672					1.1622
12	1.5432	2.8196					1.0479
13	1.5432	3.0484					
14	1.7147	3.2388					
15	1.6575	3.2388				1.5242	
16	1.6004	3.277				1.5623	
17	1.6004	3.1626				1.4098	.6478
24			1.2765	.7621	.6097		
Max	1.7147	3.277	1.7337	1.4861	.8192	1.5623	1.1622
Min	1.3336	1.2765	1.2765	.7621	.5716	1.4098	.6478
Avg	1.5599	2.8411	1.4460	1.0212	.6554	1.4988	.9479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304010 / 33KV DHANKI

Feeder No / Name : 203 / 11kv Dhanki Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	1.105	1.0288	1.0288	.9145	1.0288
2	1.0288	1.0669	1.105	.9907	.9907	.9145	1.0288
3	1.0669	1.105	1.0288	.9907	1.0288	.9526	1.105
4	1.105	1.1431	1.086	.9526	1.0669	1.0288	1.1431
5	1.1431	1.2193	1.1431	.9526	1.105	1.105	1.1622
6	1.2193	1.2574	1.1812	.9526	1.1431	1.1812	1.2003
7	1.2193	1.2765	1.086	1.0288	1.1431	1.2765	1.2003
8	1.1812	1.2574	1.1622	1.2574	1.1431	1.0669	1.2955
9	1.1431	1.2955	1.1812	1.1812	1.1431	1.105	1.2384
10	1.1431	1.2574	1.2384	1.086	1.0288		1.1431
11	1.0669	1.2193	1.1241	.9907	.9526		
12	1.0669	1.1812	1.0288	.9145	.9526		
13	.9907	1.1431	.9145	.8383	.7621		
14	.9335	1.0098	.9717	.8002	.7811		1.2193
15	.9717	1.0098	.8764	.8383	.8002	.7811	
16	.9335	.9907	.8383		.9145	.7811	
17	.9335	1.1622	1.0669		1.0288	.9907	
18	1.1431	1.1431	1.2193	1.3336	1.0669	1.0288	.8764
19	1.2193	1.1431	1.2193	1.2384	1.0669	1.1241	.8764
20	1.2384	1.1812	1.1431	1.2384	1.1812	1.105	
21	1.2384	1.1812	1.1431	1.2193	1.1431	1.0669	
22	1.1812	1.1431	1.105	1.1812	1.0669	1.0669	1.0288
23	1.105	1.1431	1.105	1.1431	1.0288	.9907	1.0288
24	1.0288	1.0288	1.0479	1.0288	1.0288	.9526	1.0098
Max	1.2384	1.2955	1.2384	1.3336	1.1812	1.2765	1.2955
Min	.9335	.9907	.8383	.8002	.7621	.7811	.8764
Avg	1.0971	1.1495	1.0883	1.0539	1.0248	1.0228	1.0991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304010 / 33KV DHANKI

Feeder No / Name : 204 / 11kv CHINCHOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572				.381	.6858
2	.4572	.4572				.4001	.6858
3	.4954	.4572				.4001	.6478
4	.4954	.4954				.4191	.6096
5	.5144	.5335				.4382	.5716
6	.5335	.5335				.4572	.5334
7	.6097	.5716				.4954	.4954
8	.5716	.6478				.5335	.6096
9	.6859	.5335				.4763	.3048
10			.4954	.5335	.5335		
11			.381	.6287	.6478		
12			.0953	.724	.6668		
13			.5335	.6478	.6668		
14			.6668	.5335	.5906		
15			.6478	.5335	.6097		
16			.6668	.5335	.5716		
17			.5716	.5335	.6287		
24	.4572	.4191				.381	.6287
Max	.6859	.6478	.6668	.724	.6668	.5335	.6858
Min	.4572	.4191	.0953	.5335	.5335	.381	.3048
Avg	.5278	.5106	.5073	.5835	.6144	.4382	.5773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304010 / 33KV DHANKI

Feeder No / Name : 205 / 11 KV KHARUS

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	11-JUL-17
HR	Load (MW)
1	.5716
2	.5716
3	.5716
4	.5716
5	.5716
6	.5716
7	.5716
8	.5716
9	.5716
24	.5716
Max	.5716
Min	.5716
Avg	.5716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304023 / 33KV SAKHARA

Feeder No / Name : 201 / 11kv Bramhangaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8297	.8258	1.4146	1.2068	1.3536	1.0498	.8145
2	.8288	.8267	1.3675	1.173	1.3177	1.0574	.8162
3	.8278	.8267	1.4618		1.3039	1.0517	.8162
4	.9253	.8304	1.3675		1.3489	1.0277	.9345
5	.9813	.8395	1.4209		1.3146	.9949	.9135
6	1.0311	.9965	1.4366	1.16	1.3146	1.0849	.9288
7	1.1214	.9848	1.6124	1.3398	1.3023	1.1309	.962
8	.8602	.5332	1.6369	1.3174	1.4283	1.2134	.8788
9	.679	.4321	1.5783	1.0412	1.4586	1.1746	.8334
10	1.1724	1.3148	.5929	.5464	.6219	.6365	.5573
11	1.3297	1.4801	.4969	.5647	.3869		.4354
12	1.37	1.5569	.4694	.5431	.2701	.0538	.427
13	1.3959	1.198	.4751	.5431	.3096	.0538	.3948
14	1.3765	1.4637	.4974		.1392	.0569	.421
15	1.3475	1.455		.5981	.4132	.2034	.4599
16	1.3588	1.538	.5609	.4987	.3676	.2206	.4767
17	1.37	1.5673	.5853	.6071	.4092	.3429	.4176
18	.526	.5475	.6048	.6515	.3765	.6818	.6048
19	.6413	.7567	.7718	.716	.4536	.7545	.7356
20	.8127	.8127	.8479	.7613	.8333	.759	.7922
21	.8496	.8488	.8505	.789	.8496	.7757	.7718
22	.8127	.8291		.7545	.8282	.756	
23	.7749	.7545	.7749	.7537	.793	.7182	.7182
24	.8259	.8276	1.4542	1.2153	1.3619	.9753	.7413
Max	1.3959	1.5673	1.6369	1.3398	1.4586	1.2134	.962
Min	.526	.4321	.4694	.4987	.1392	.0538	.3948
Avg	1.0020	1.0019	1.0127	.8390	.8565	.7293	.6892

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304023 / 33KV SAKHARA

Feeder No / Name : 203 / 11kv Sakhara

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.5777	1.2489	.9552	.9105	.9079	.5744
2	.4868	.5716	1.2532	.9492	.9105	.9027	.5716
3	.4881	.5685	1.2532	.929	.9259	.8957	.5601
4	.5146	.5716	1.2532	1.0745	.9593	.9044	.6081
5	.5258	.6145	1.2986	.9702	.9737	.915	.6494
6	.5243	.7444	1.3032	1.1928	.9979	.9709	.6927
7	.4962	.7229	1.3979	1.2379	.9584	1.0269	.6413
8	.3747	.6867	1.2814	1.1547	1.0743	1.0402	.6876
9	.3747	.6065	1.2028	1.0898	1.004	.9832	.5853
10	.3403	.4609	.4519	.3985	.4741	.5268	.6081
11	.3681	1.1862		.198	.4841	.4774	.5868
12	.5807	1.3123	.4612		.1083	.4557	.6008
13	.8202		.4628	.4825	.573	.5513	.5655
14	1.0702	1.2803	.4534	.4774	.5736	.5327	.6273
15	1.1107	1.3466	.4973	.5144	.6155	.548	.6116
16	1.1044	1.3241	.4856	.4463	.6547	.587	
17	1.0965	1.3336	.5127	.5144	.6398	.5898	.6508
18	.2036	.2306	.2434	.2127	.2226	.257	.2158
19	.2858	.3435	.3153	.3132		.3048	.2977
20	.3481	.3801	.3667	.3359		.3218	.3437
21	.3662	.381	.3762	.332	.3395	.3187	.3185
22	.3514	.3631		.3404	.3464	.3071	.3241
23	.3395	.3444	.3481	.3236	.3378	.3041	.3079
24	.5039	.5734	1.2467	1.064	.8625	.9284	.5281
Max	1.1107	1.3466	1.3979	1.2379	1.0743	1.0402	.6927
Min	.2036	.2306	.2434	.198	.1083	.257	.2158
Avg	.5476	.7185	.8052	.6742	.6794	.6482	.5286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304051 / 33KV CHATARI(BRAMHANGAON)

Feeder No / Name : 201 / 11KV BRAMHANGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1317	2.0405	1.989	1.4746	1.4403	1.0631
2	1.0974	1.1317	2.0405	2.0576	1.4746	1.4232	1.0631
3	1.0974	1.1317	1.989	2.1262	1.4746	1.3889	1.0974
4	1.1317	1.1317	1.9547	2.332	1.4746	1.3375	1.0974
5	1.166	1.166	2.0405	2.5377	1.5432	1.3546	1.0631
6	1.0974	1.2003	2.2119	2.572	1.7833	1.5261	1.166
7	1.0631	.9602	2.692	2.6063	1.989	2.1434	1.166
8	.7202	.8916	2.7435	2.6406	2.2634	2.2119	1.2689
9	.4801	.8573	2.6235	2.6063	2.332	2.1434	1.0288
10	2.332	2.3663	.7202		.4115		
11	2.6406	2.6749	.6859				1.8519
12	2.8807	2.8121	.5959	.583	.3772		1.6118
13	2.6063	2.5206	.6661	.5487	.4458	.4801	1.9547
14	2.6406	2.5034	.631	.6173	.4458	.4801	1.6118
15	2.572	2.1948			.4801	.5487	1.9204
16	2.5034	2.1948		.6859	.4458	.5144	2.0233
17	2.6406	2.5549		.7888	.823	.6859	
24	1.1317	1.1317	2.0748	1.989	1.5089	1.4746	1.0631
Max	2.8807	2.8121	2.7435	2.6406	2.332	2.2119	2.0233
Min	.4801	.8573	.5959	.5487	.3772	.4801	1.0288
Avg	1.7185	1.6975	1.714	1.7787	1.2204	1.2769	1.3782

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304051 / 33KV CHATARI(BRAMHANGAON)

Feeder No / Name : 202 / 11KVCHATARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5487	.6687	.6859	.6516	.6516	.4115
2	.5487	.5487	.6687	.6859	.6516	.6344	.4115
3	.5487	.5487	.6687	.7202	.6859	.6344	.4458
4	.6173	.5487	.6687	.7202	.6859	.6516	.4458
5	.6516	.6516	.7716	.7545	.823	.7545	.4801
6	.7545	.7202	.9602	.823	.7888	.9431	.5487
7	.7202	.7888	.8059	.7888	.823	.8402	.583
8	.7202	.7545	.6516	.7888	.7545	.7545	.5487
9	.6173	.7545	.583	.6516	.6687	.1886	.583
10	.4458	.4801	.6859		.6173	.5316	
11	.4458	.4458	.6859				.3086
12	.4458	.4458	.7362	.6859	.7202		.2743
13	.4115	.5144	.7362	.6516	.7545	.5144	
14	.4458	.4801	.7011	.6173	.6173	.5144	
15	.4458	.5144			.5487	.6173	
16	.4801	.5316		.583	.7202	.6516	
17	.4458	.5144		.6173	.7202	.6516	
18	.823	.8402	1.0166		1.046	.8573	.9602
19	.9602	1.0288	1.262	1.0974	1.046	1.1218	1.0631
20	1.3375	1.3375	1.3847	1.2346	1.3375	1.1919	1.2003
21	1.3375	1.3375	1.3321	1.2346	1.2689	1.1919	1.2346
22	1.3032	1.2689	1.2971	1.2003	1.2346	1.2094	1.1317
23	1.2003	1.2003	1.2971	1.0974	1.2003	1.1218	1.0631
24	.5144	.5487	.6687	.6859	.6859	.6516	.4115
Max	1.3375	1.3375	1.3847	1.2346	1.3375	1.2094	1.2346
Min	.4115	.4458	.583	.583	.5487	.1886	.2743
Avg	.6973	.7230	.8691	.8162	.8283	.7673	.6725



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304051 / 33KV CHATARI(BRAMHANGAON)

Feeder No / Name : 203 / 11KV MANKESHWAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.7202					.3429
2	.583	.7202					.3429
3	.6173	.7545					.3772
4	.6516	.7545					.3772
5	.7202	.7888					.3772
6	.7888	.8573					.4458
7	.7888	.9602					.4458
8	.823	1.0288					.4115
9	.823	.9945					.4801
10	.823		.8916			.5144	
11			.9602				
12			.9465	.823	.7888		
13			.9465	.7888	.7545	.5487	
14			.8063	.7888	.7545	.4458	
15					.7202	.5144	
16				.7888	.823	.5144	
17				.7888	.7202	.4801	
24	.5487	.6859					.3429
Max	.823	1.0288	.9602	.823	.823	.5487	.4801
Min	.5487	.6859	.8063	.7888	.7202	.4458	.3429
Avg	.7015	.8265	.9102	.7956	.7602	.5030	.3944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304072 / 33KV BITARGAON

Feeder No / Name : 202 / 11KV Jeoli

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.7023	.8583	1.0098	.8215	.8817	.4382
2	.5144	.6767	.8482	.8002	.9055	.8648	.4763
3	.5144	.6838	.8322	.7621	.8589	.8478	.5144
4	.5335	.6722	.8162	.743	.8871	.8648	.5144
5	.5525	.6516	.8322	.743	.7842	.8718	.5144
6	.5716	.6535	.8259	.743	.7762	.788	.4954
7	.7621	.6653	.6405	.743	.5228	.7545	.4382
8	.3429	.7947	.5312	.743	.5228	.6371	.4191
9	.5868	.7811	.4843		.4382	.5716	.2572
10	.2683	.5716	.5788		.4382	.4973	.3601
11	.3932	.4382	.5041		.4382	.3681	.3944
12	.3932	.4382	.5175		.4382	.3921	.3258
13	.3768	.5525	.4954			.3881	.3429
14	.4752	.5906	.5144			.3801	.3601
15	.5079	.5716	.5144		.4382	.3681	.3772
16	.4915	.5716	.5144	.333	.5716	.3734	
17	.5175	.5533	.5525	.4938	.6068	.4382	
18	.5175	.5895	.6287	.8402	.5144	.724	.5359
19	.7468	.815	.8764	.8962	.8059	.9145	.6535
20	.7468	.9259	1.0669	.9709	.9259	.9907	.8316
21	1.1273	1.0288	1.1431		1.0288	1.105	.8775
22	1.0974	.9945	1.1241		1.0277	1.0669	.8962
23	1.0608	.9602	1.0669		1.0099	1.0288	.9335
24	.5144	.7095	.8745	1.0098	.8316	.9431	.4382
Max	1.1273	1.0288	1.1431	1.0098	1.0288	1.105	.9335
Min	.2683	.4382	.4843	.333	.4382	.3681	.2572
Avg	.5886	.6913	.7350	.7736	.7088	.7109	.5179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHANKI S/DN[529]

BU 1767

Substation No/ Name :- 304072 / 33KV BITARGAON

Feeder No / Name : 203 / 11KV Bhojnagar

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.9795	.7362	1.0288	.8131	.8916	.9335
2	1.0479	1.0164	.8322	.9335	.8029	.8551	.9335
3	1.0288	.924	.8482	1.0288	.823	.8453	.9335
4	1.0669	.961	.8962	1.0669	.8501	.8619	.9335
5	1.1241	1.0164	.9069	1.105	.8402	.852	.9907
6	1.1431	1.0642	1.0883	1.1431	.8686	.8122	1.1241
7	.8764	1.0082	1.0402	1.2574	.8962	.8215	1.0479
8	.7049	.9328	1.1683	1.448	1.0719	.9221	1.0288
9	.6371	.6287	1.0883		1.1241	.5601	.7716
10	.8619	1.086	.4668		.5144	.3361	.823
11	1.0111	1.086	.743		.4191	.3696	.8669
12	.9945	1.2003	.743		.4191	.3696	.823
13	.9503	.8002	.724		.4382	.3734	.8059
14	.9503	1.3717	.743			.3696	.8573
15	.9667	1.3527	.724		.2477	.4108	.7716
16	1.0513	1.467	.4763	.2481	.3429	.3881	
17	1.1765	1.2631	.5525	.2614		.5525	.8316
18	.6161	.6104	.6859	.3921	.7373	.7621	.8413
19	.8402	.7888	.9526	.8686	.8059	.8573	.8507
20	.8316	.9945	1.0669	1.0349	.9259	.9907	.961
21	1.1389	1.046	1.1241		.9602	1.0098	.961
22	1.0903	1.0117	1.1241		.9568	1.0098	.9145
23	1.0242	.9774	1.0479	.7095	.9391	.9717	.9055
24	1.0288	.9979	.6226	1.0669	.7762	.8916	.9335
Max	1.1765	1.467	1.1683	1.448	1.1241	1.0098	1.1241
Min	.6161	.6104	.4668	.2481	.2477	.3361	.7716
Avg	.9671	1.0244	.8501	.9062	.7533	.7119	.9063

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304003 / 33KV MANKOPRA

Feeder No / Name : 201 / 11 KV BODEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.576	1.5746	1.848	1.7147
2			1.576	1.5565	1.829	1.7147
3			1.5402	1.5384	1.829	1.7147
4			1.7551	1.5203	1.829	1.7147
5			2.0774	1.8461	1.7909	1.7337
6			2.1491	2.1719	2.0957	2.0195
7			2.4177	2.3529	2.191	2.0576
8			2.4434	2.4796	1.3908	1.6194
9				2.2081	1.086	1.7147
10				1.4842	1.5623	
11			1.267	1.3908	1.5242	
12			1.3032	1.2574	1.4861	
13			1.4118	1.3146	1.4098	
14		1.5581		1.4289	.8002	
15		1.576		1.3908		
16		1.6118	1.6289	1.5623	1.5242	
17		1.7551	1.7013	.7621	1.6385	
18		1.9342	1.8461	1.9814	1.7147	
19		2.0774	1.9547	2.1529	2.1338	
20		2.0595	2.1719	2.3053	2.3243	
21		2.0416	2.0633	1.8099	2.0195	
22		2.0237	1.9909	1.9052	1.9052	
23		1.9163	1.9185	1.9243	1.848	
24	2.0386		1.6118	1.5927	1.829	1.8099
Max	2.0386	2.0774	2.4434	2.4796	2.3243	2.0576
Min	2.0386	1.5581	1.267	.7621	.8002	1.6194
Avg	2.0386	1.8554	1.8202	1.7296	1.7221	1.7814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304003 / 33KV MANKOPRA

Feeder No / Name : 203 / 11kv Tarnoli

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7619	.7796	.5716	.9335
2			.7442	.7796	.5716	.9335
3			.7442	.7619	.5716	.9145
4			.8505	.7619	.6478	.8954
5			1.0099	.8682	.6668	.9526
6			1.0454	.8859	.743	1.1241
7			.9922	.9214	.6097	1.1622
8			1.0692	.9036	.5906	1.3908
9				.9214	.5906	1.3146
10				.2126		
11			1.3643	1.2003		
12			1.2403	1.2003		
13			1.1517	.3048	.6097	
14		1.2934		1.2955	.6478	
15		1.3112		1.3336		
16		1.3289	1.2269	1.467	.724	
17		1.2757	1.2795	1.3146	.8002	
18		.0532	1.2403		.9526	
19		1.1694	1.2048		1.2003	
20		1.0631	1.1871		1.2193	
21		.9745	1.0277	1.0479	1.0479	
22		.8505	.8859	.5906	1.0479	
23		.7973	.815	.724	.8764	
24	.8954		.7619	.7796	.5716	.9335
Max	.8954	1.3289	1.3643	1.467	1.2193	1.3908
Min	.8954	.0532	.7442	.2126	.5716	.8954
Avg	.8954	1.0117	1.0301	.9073	.7631	1.0555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319] BU 3191

Substation No/ Name :- 304003 / 33KV MANKOPRA

Feeder No / Name : 204 / 11kv Manki

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8669	.9362	.743	.6859
2			.8322	.9362	.743	.6859
3			.8322	.9189	.743	.6859
4			.9709	.9189	.7621	.6668
5			1.0402	.9431	.7621	.6859
6			1.0576	.9602	.8383	.9907
7			1.0923	.9945	.8573	1.1431
8			1.0117	.9602	.8573	1.2384
9				.8149	.8383	1.086
10				.7373	.743	
11			.8669	.8954	.7621	
12			.8495	.8764	.6668	
13			.8322	.7049	.5525	
14		.9189		.8573	.5906	
15		.9465		.8573		
16		.964	.8495	.5906	.6478	
17		.9015	.8669	.7811	.6478	
18		.8322	1.0229	.9145	.743	
19		1.0802	1.2483	1.1622	1.2574	
20		1.0288	1.3176	1.1812	1.3146	
21		.9945	1.1443	1.1241	1.1241	
22		.9882	1.0402	1.086	1.0669	
23		.9536	.9709	1.0288	1.0288	
24	.7621		.9015	.9362	.743	.724
Max	.7621	1.0802	1.3176	1.1812	1.3146	1.2384
Min	.7621	.8322	.8322	.5906	.5525	.6668
Avg	.7621	.9608	.9807	.9215	.8275	.8593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304045 / 33KV MANKINHI

Feeder No / Name : 201 / 11KV MANKINHI Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.5281	.7716			
2	.3658	.5281	.8025			
3	.5182	.5281	.8179			
4	.5182	.5498	.8179			
5	.6706	.5944	.8179			
6	.6859	.639	.8796			
7	.7164	1.0623	.9568			
8	.7316	1.0802	.9722			
9	.7164	1.034	.8779			
10			1.0153	.9934	.7827	
11			1.1728	1.0059	1.25	
12			.9755	.9755	1.3279	
13			1.1111	1.1574	1.1728	
14			1.1873		1.1717	
15			1.0574		1.1561	
16			1.2651	.3749	1.0623	.2469
17			1.3125	1.3125	.9145	.8278
18				1.0686		
19				.6923		
20				.6015		
24	.16	.5281	.7253			
Max	.7316	1.0802	1.3125	1.3125	1.3279	.8278
Min	.16	.5281	.7253	.3749	.7827	.2469
Avg	.5418	.7072	.9743	.9091	1.1048	.5374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304045 / 33KV MANKINHI

Feeder No / Name : 202 / 11KV PIMPALKHUTTA Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0753	.2972	.1833
2			.1204	.2972	.1833
3			.2709	.301	.1715
4			.2709	.301	.1669
5			.2408	.3121	
6			.2439	.3227	
7			.3201	.3909	
8			.2715	.4001	
9			.2972	.4001	.0145
10	.3041	.4458			.1858
11	.3521	.3978			.16
12	.3185	.4054			.0533
13	.3668	.3961			.0533
14	.3475	.3841			.0533
15	.3102	.3948			
16	.2534	.4199			.0114
17	.3814	.4254			.0267
18					.0267
24			.0753	.2972	.1833
Max	.3814	.4458	.3201	.4001	.1858
Min	.2534	.3841	.0753	.2972	.0114
Avg	.3293	.4087	.2186	.3320	.1052



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304045 / 33KV MANKINHI

Feeder No / Name : 203 / 11KV LAKH GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.3443	1.307	1.419	1.3256		1.251
2	1.3443	1.3443	1.2696	1.3443	1.3256		1.251
3	1.3443	1.3256	1.2696	1.3443	1.3256		1.251
4	1.3817	1.419	1.2323	1.3443	1.3817		1.2696
5	1.9044	1.643	1.307	1.7924	1.6244		1.6057
6	1.9605	1.9231	1.531	2.0538	1.8111		1.9044
7	1.9978	1.9791	1.9605	1.8298	1.9791		1.9231
8	1.6991	1.7177	1.6244	1.643	1.8298		
9	1.4563	1.475	1.3443	1.251	1.5123		.8402
10	1.0082	1.1016	.9709	.8215	.9054		1.0456
11	.8131	.8402	.8029	.7468	.6161		.7682
12	.7577	.8962	.6283	.6161	.6283		.6219
13	.7682	.924	.5975	.6348	.6348		.6653
14	.7392	.924	.5041		.5601		.6653
15	.8871	.9425	.6908		.5228		.6838
16	.924	.961	.7392	.5853	.5975	.6878	.3696
17	.9979	.9709	.9055	.8779	.7207	.823	.7392
18	1.3306	1.4377	1.8111	1.1827	1.4415	1.2382	1.423
19	1.7364	1.8858	1.7737	1.8858		1.8665	1.7924
20	1.8671	1.9231	1.7551	1.9418		1.6804	1.7737
21	1.2696	1.5497	1.531	1.6057		1.5123	1.475
22	1.4377	1.4563	1.419	1.419		1.363	1.4003
23	1.363	1.363	1.419	1.3443		1.2883	1.3443
24	1.3443	1.3443	1.3256	1.419	1.3256		1.251
Max	1.9978	1.9791	1.9605	2.0538	1.9791	1.8665	1.9231
Min	.7392	.8402	.5041	.5853	.5228	.6878	.3696
Avg	1.3199	1.3621	1.2383	1.3228	1.1615	1.3074	1.1876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319] BU 3191

Substation No/ Name :- 304046 / 33KV TAPONA

Feeder No / Name : 201 / 11KV MORGAVHAN Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305					.061
2	.0305					.0457
3	.0305					.0497
4	.0305					.061
5	.0305					.048
6	.0152					.032
7	.0762	.2402				.2561
8	.0457	.2103				.3391
9	.1067	.2454				.4481
10		.2587	.6516	.6401	.5792	
11		.3429		.5792	.6516	
12		.4287		.3353	.583	
13		.462	.6081	.7377	.5487	
14		.4805	.6081		.5487	
15		.4805	.7042		.5487	
16		.4805	.6722	.6173	.5487	
17			.6882	.6173	.5487	
24	.0305					.128
Max	.1067	.4805	.7042	.7377	.6516	.4481
Min	.0152	.2103	.6081	.3353	.5487	.032
Avg	.0427	.3630	.6554	.5878	.5697	.1469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304046 / 33KV TAPONA

Feeder No / Name : 202 / 11KV GAOTHAN TAPONA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0754	.0724	.0716	.0754	.0747	.0724
2	.0747	.0754	.0724	.0716	.0754	.0747	.0724
3	.0747	.0754	.0724	.0716	.0754	.0747	.0724
4	.0747	.0754	.0724	.0709	.0754	.0747	.0724
5	.0747	.0754	.0686	.0709	.0754	.0747	.0895
6	.0747	.0754	.0724	.0709	.0754	.0747	.0895
7	.0747	.0554	.0724	.0701	.0566	.0747	.0724
8	.056	.0526	.0554	.0537	.0554	.0747	.0537
9	.056	.0526	.0554	.0554	.037	.056	.0543
10	.0373	.0554	.0537	.0377	.0362	.056	.048
11	.037	.056		.0362	.0362	.0358	.0362
12	.0362	.056		.0335	.0362	.0358	.0362
13	.0366	.0358	.0537	.0335	.0362	.0362	.0362
14	.0362	.0554	.0537		.0362	.0351	.0362
15	.0543	.0554	.0526		.0362	.0351	.0362
16	.0537	.0554	.0537	.0343	.0362	.0339	4.5972
17	.0537	.0543	.0537	.0343	.0362	.0358	
18	.0543	.0543	.0526		.0362	.0358	.037
19	.0549	.0724	.0526	.0537	.0543	.0716	.0693
20	.0732	.0724	.0709	.0724	.0857	.0716	.0739
21	.0732	.0724	.0709	.0724	.0686	.0716	.0754
22	.0739	.0724	.0709	.0739	.0905	.0716	.0754
23	.0739	.0724	.0709	.0754	.0724	.0716	.0754
24	.0747	.0754	.0724	.0709	.0754	.0724	.0724
Max	.0747	.0754	.0724	.0754	.0905	.0747	4.5972
Min	.0362	.0358	.0526	.0335	.0362	.0339	.0362
Avg	.0608	.0637	.0635	.0588	.0573	.0593	.2589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304046 / 33KV TAPONA

Feeder No / Name : 205 / 11 KV TAPONA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.8484	.5973	.5765	.6036	1.3546	1.1869
2	1.5089	1.8484	.5973	.5596	.6036	1.4299	1.0852
3	1.5089	1.8484	.5973	.5426	.6036	1.3717	1.1736
4	1.5089	1.8484	.6154	.5765	.6036	1.3717	1.1904
5	1.5089	1.8484	.6335	.5765	.6036	1.3546	1.1633
6	1.5089	1.8484	.6697	.6104	.6036	1.3717	.6241
7	1.6118	1.7372	.6697	.5765	.6413	.7059	.6241
8	1.7147	1.8229	.5914	.5373	.5914	.8596	.4862
9	1.6804	1.7177	.5359	.5544	.4805	.7537	1.4754
10	.3696	.4435		1.7695	.8326	.362	.3391
11	.3696	.4344		2.1262	1.7147	.2947	.2896
12	.3429	.4344		1.8107	1.6804	.2804	.2896
13	.4024	.4435		1.6766	1.6461	.2374	
14	.362	.462			1.6289	.2883	.2896
15	.4344	.462	1.8564		1.7147	.3052	.2896
16	.5014	.4805	1.7711	1.6461	1.7147	.3018	.3258
17	.394	.4706	1.6461	1.6804	1.869	.3561	.3391
18	.5068	.5068	.5182		.5792	.4115	.2587
19	.6219	.5792	.5792	.6447	.6878	.6036	.6859
20	.7682	.6154	.5487	.6878	.6878	.5761	.7392
21	.695	.6154	.6104	.5792	.6516		.6413
22	.6653	.6154	.57	.5914		.5441	.6036
23	.6283	.6154	.5765	.6036	.5792	.5765	.6413
24	1.5432	1.8484	.6154	.5596	.6036	1.448	1.0395
Max	1.7147	1.8484	1.8564	2.1262	1.869	1.448	1.4754
Min	.3429	.4344	.5182	.5373	.4805	.2374	.2587
Avg	.9444	1.0581	.7789	.9279	.9533	.7460	.6861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304049 / 33/11 KV S/S LOHI.

Feeder No / Name : 201 / 11KV LOHI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0642	1.0631	.567	.8954	.7316	.9107
2	1.0082	1.0456	.9745	.7087	.8954	.7316	.8761
3	1.0082	1.0082	1.0277	.815	.8059	.7392	.8688
4	1.0829	1.0082	1.0277	1.0631	.9134	.8501	.8743
5	1.1576	1.0829	1.0631	1.4175	.9313	.8871	1.0232
6	1.2696	1.251	1.3289	1.4529	1.1641	.961	1.2554
7	1.307	1.2696	1.5061	1.4883	1.1462	1.0349	1.2386
8	1.307	1.3203	1.4175	1.4529	1.1283	1.1088	1.1647
9	1.1949	1.2136	1.4352	1.2403	1.0029	1.1088	1.0564
10	.9214	1.382	.9709	.8962	.7842	.8215	1.0608
11	1.1163	1.3112	1.0829	.9149	.8589	.8589	.8196
12	.9922			.9522	.8962	.6348	.8215
13	1.0631	1.2403	1.1576	.8402	.7468	.6722	.5613
14	.9922	1.3466	1.1576	.7095	.8596	.6722	.5464
15	1.1694	1.1694	1.0456	.9335	.6348	.6348	.5963
16	1.0985	1.2757	1.1949	.8029		.6722	.708
17	1.1163	1.2757	1.1949	.7842	.8589	.5228	.9231
18	.9709	1.1576	1.1949	1.0642	1.2323	.6722	.8641
19	1.1576	1.419	1.4563	1.419	1.2323	.8589	1.2063
20	1.5123	1.5684	1.531	1.6991	1.2323	1.4563	1.2715
21	1.3443	1.4563	1.2696	1.4937	1.2323	1.2696	1.1198
22	1.2883	1.3443	1.1949	1.307	1.1949	1.1576	1.0512
23	1.1576	1.1949	1.0829	1.251	1.1203	1.0829	1.0143
24		1.0642	1.2048	.4854	.9313	.7682	.9511
Max	1.5123	1.5684	1.531	1.6991	1.2323	1.4563	1.2715
Min	.9214	1.0082	.9709	.4854	.6348	.5228	.5464
Avg	1.1471	1.2378	1.1992	1.0733	.9869	.8712	.9493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304049 / 33/11 KV S/S LOHI.

Feeder No / Name : 202 / 11KV SATEFAL FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835			.4854	.5415	.3734	.2957
2	.2896			.4481	.5228	.3734	.2926
3	.2534			.4481	.6722	.3734	.3696
4	.2926			.4481	.5788	.4108	.3326
5	.3326			.4481	.4294	.439	.4066
6	.3658			.4854	.5228	.4805	.439
7	.543		.4668	.4854	.4854	.5175	.4066
8	.543		.4481	.2987	.4668	.4805	.3658
9	.4706		.3921	.2241	.4108	.4066	.3429
10	.2614		.3898	.3658	.3077	.3361	.2987
11	.2241		.4854	.4024	.3292	.2987	.168
12	.2054		.3982	.3292	.2896	.2614	.2427
13			.3982	.3366	.2926	.2614	
14	.2614		.3658	.2172	.2172	.2614	
15	.2614		.3258	.2534	.2926	.2241	
16	.2241		.4344	.3109	.3292	.2614	
17	.2241		.3982	.3292	.3292	.2987	.2818
18	.2614		.2987	.2614	.3734	.3361	.3368
19	.4108		.4108	.4108	.5601	.4481	.3734
20	.5041		.5228	.5036	.4108	.4854	.5544
21	.3734		.5228	.4854	.4481	.4854	.5207
22	.4854		.4854	.4668	.4481	.4481	.4845
23	.4854		.4854	.4481	.4481	.3734	.462
24	.2987	.3326		.4854	.4294	.4108	.2926
Max	.543	.3326	.5228	.5036	.6722	.5175	.5544
Min	.2054	.3326	.2987	.2172	.2172	.2241	.168
Avg	.3415	.3326	.4252	.3907	.4223	.3769	.3634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304049 / 33/11 KV S/S LOHI.

Feeder No / Name : 203 / 11KV ADGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5788	.5228	.5228	.5201	.4481	.4854
2	.4706	.5601	.5228	.4854	.5207	.4481	.4845
3	.4706	.5228	.5228	.4854	.559	.4108	.4854
4	.5068	.5228	.5228	.4854	.5573	.4108	.559
5	.5792	.5975	.5228	.4854	.5578	.4481	.6283
6	.6733	.6979	.5415	.4854	.5601	.4854	.7446
7	.8859	.8962	.5415	.5228	.5228	.5601	.7392
8	.9214	.9709	.5228	.4854	.5415	.5601	.6619
9	.7796	.8865	.4854	.4854	.6722	.4481	.6646
10	.3547	.4108	.5228	.5487	.6722	.4755	.3727
11	.2987	.3734	.7842	.7059	.6516	.5121	.2422
12	.2987	.3921	.7842	.724	.6154	.3292	.2981
13	.2054	.4481	.7468	.724	.6516	.3292	.2603
14	.2241	.4854	.7468	.6516	.5975	.3292	.2987
15	.4108	.4481	.6348	.695	.5121	.3326	.3723
16	.3361	.4854	.6653	.6584	.5792	.3696	.3719
17	.3547	.4481	.8131	.7316	.5853	.4805	.2241
18	.3547	.4854	.4066	.4108	.4854	.4854	.3381
19	.5228	.6348	.5228	.5228	.4854	.6348	.5938
20	.7282	.4668	.6348	.6348	.5228	.8215	.6309
21	.6722	.6348	.5975	.6348	.5601	.7468	.5926
22	.6535	.5975	.5601	.6161	.5601	.5601	.5747
23	.6348	.5601	.5228	.5788	.5228	.5228	.5544
24		.5788	.5601	.5228	.5415	.4854	.4879
Max	.9214	.9709	.8131	.7316	.6722	.8215	.7446
Min	.2054	.3734	.4066	.4108	.4854	.3292	.2241
Avg	.5152	.5701	.5920	.5751	.5648	.4848	.4861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 201 / 11kv URBAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4403	1.4232	1.406	1.406		1.2346
2	1.3889	1.4575	1.4232	1.3717	1.406		1.2003
3	1.3717	1.4403	1.3889	1.3889	1.4918		1.2174
4	1.406	1.4232	1.5775	1.4575	1.5261		1.3717
5	1.4575	1.3717	1.6461	1.5089	1.6289		1.4575
6	1.4918	1.6461	1.6975	1.6118	1.6461		1.5947
7	1.5089	1.5775	1.7318	1.6975	1.6975		1.6461
8	1.406	1.6804	1.7147	1.6975	1.6118		1.6632
9	1.406	1.5261	1.6118		1.5775		1.7924
10	1.4232	1.5604	1.4918		1.5261		1.643
11	1.3032	1.4918	1.3032	1.2517	1.2689	1.2174	1.4937
12	1.2689	1.4403	1.2346	1.2174	1.2517	1.0802	1.3443
13	1.2517	1.3203	1.1831	1.1488	1.0974	1.0288	
14	1.2174	1.3032	1.166	1.166	1.0288	.8745	1.0642
15	1.2517	1.2517	1.1488	1.046	1.1145	.9259	1.0829
16	1.2517	1.2003	1.1831	1.1488	1.0802	.9945	1.1016
17	1.1488	1.2174	1.2174	1.1488	1.2003	.9431	
18	1.6461	1.4403	1.4403	1.406		1.1145	1.4563
19	1.4746	1.5947	1.6289	1.5947		1.4575	1.6991
20	1.7147	1.6461	1.7318	1.6118		1.5261	1.7364
21	1.5775	1.6118	1.5432	1.6461		1.406	1.5684
22	1.5775	1.6632	1.5261	1.5432		1.3546	1.4937
23	1.4746	1.5432	1.5089	1.4746		1.3375	1.419
24		1.4403	1.4575	1.4403	1.4403		1.2517
Max	1.7147	1.6804	1.7318	1.6975	1.6975	1.5261	1.7924
Min	1.1488	1.2003	1.1488	1.046	1.0288	.8745	1.0642
Avg	1.4083	1.4703	1.4575	1.4084	1.3889	1.1739	1.4333



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 202 / 11kv Saikheda AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3086	.3429		
2			.3429	.3772		
3			.3601	.3772		
4			.3601	.3772		
5			.3772	.4115		
6			.3772	.4115		
7			.6173	.5316		
8			.8059	.5487		
9				.5487		
10	.1715	.463				.5182
11	.3944	.2743				.4696
12	.3944	.3601			.3429	.3563
13	.5144	.6173			.3258	
14		.6001			.4287	.6478
15	.3601	.5658			.3601	.502
16	.2915	.6001			.3601	
17	.4458	.6001			.2743	
24			.2743	.2915		
Max	.5144	.6173	.8059	.5487	.4287	.6478
Min	.1715	.2743	.2743	.2915	.2743	.3563
Avg	.3674	.5101	.4248	.4218	.3487	.4988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 203 / 11 kV LAKH (SAIKHEDA)

Gaothan Feeder

GAONTHAN Feeder KV- 11 /  
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	1.9719	1.8176	1.989	1.9204		1.8004
2	1.8519	1.9547	1.8176	1.9376	1.8519		1.749
3	1.8176	1.9376	1.6632	1.9204	1.8519		1.7318
4	1.869	1.9376	1.6804	2.1948	2.1262		1.9719
5	1.9719	1.9719	2.0233	2.3834	2.2634		2.1091
6	2.0576	2.2291	2.2119	2.5377	2.332		2.332
7	2.1605	2.1948	2.2634	2.6063	2.4006		2.3148
8	2.0405	2.0233	2.0576	2.4348	2.4006		2.1262
9	2.0233	2.0062	1.8519		2.4348		2.2546
10	.6687	1.7147	1.7147		1.5089		1.8296
11	1.0288	1.5947	1.2346	1.3032	1.4575	1.046	1.4784
12	1.2174	1.4918	1.3375	1.4403	1.406	.9602	1.3676
13	1.406	1.4746	1.5261	1.5775	1.3717	.9431	
14	1.0974	1.4575	1.6975	1.6118	1.2174	1.0974	1.4784
15	1.0974	1.4403	1.6804	1.6461	1.2346	1.166	1.7002
16	1.5261	1.6118		1.6461	1.2517	1.2689	1.5524
17	1.6975	1.7318	1.8519	1.6118	1.2346	1.3889	
18	2.0233	1.6804	2.5549	1.8176		1.6118	2.3285
19	2.3663	1.4403	2.7949	2.0233		2.0576	2.3285
20	2.3834	1.286	2.7949	2.0576		2.3491	2.2916
21	2.2805	1.4746	2.3663	2.0748		2.1434	2.1253
22	2.1091	1.8861	2.1948	2.0748		2.0405	2.1622
23	2.0062	1.9376	2.0919	2.0576		1.9547	
24		1.9547	1.9204	2.0233	1.989		1.8861
Max	2.3834	2.2291	2.7949	2.6063	2.4348	2.3491	2.332
Min	.6687	1.286	1.2346	1.3032	1.2174	.9431	1.3676
Avg	1.7646	1.7668	1.9629	1.9532	1.7918	1.5406	1.9485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319] BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 204 / 11 KV PWW AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.6001	.7202			.4458
2	.7716	.6001	.7202			.463
3	.823	.6173	.6859			.463
4	.8916	.6001	.6516			.4458
5	1.0288	.6859	.7545			
6	1.0802	.7545	.7202			
7	1.1145	1.0631	.2743			.1372
8	1.2174	1.1317	.6859			.6173
9	1.2174	1.3032	.7888			1.085
10			1.406		1.166	
11			1.3032	1.4746	1.5775	
12			1.4746	1.5089	1.4746	
13			1.1145	1.5947	1.5089	
14			1.3032	1.5432	1.3546	
15			1.3546	1.6461	1.2517	
16			1.5604	1.6461	1.3032	
17			1.5261	1.5604	1.2517	
24		.6173	.6516			.4287
Max	1.2174	1.3032	1.5604	1.6461	1.5775	1.085
Min	.4287	.6001	.2743	1.4746	1.166	.1372
Avg	.9526	.7973	.9831	1.5677	1.3610	.5107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 205 / 11kv Talegaon Gaothan fdr

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8573	.7202	.8573	.7373		.7888
2	.8059	.8573	.7373	.8402	.7373		.7545
3	.7716	.8402	.6173	.8573	.7716		.7716
4	.823	.8402	.703	.9431	.8745		.8402
5	.8916	.9431	.9259	1.0288	1.0974		.9602
6	1.0117	1.0288	.9945	1.1317	1.1145		1.1317
7	1.0974		1.0117	1.2174	1.0974		1.166
8	1.1317	.823	1.166	1.1831	1.0974		1.1488
9	1.0974	.3429	1.0974		.9431		.7207
10	.8745				.8916		.5914
11	.8745			.8059	.8573	.6859	.5175
12	.6516	.3258		.823	.3944	.4115	.4435
13	.7202	.3944	.6687	.7716	.8059	.9774	
14	.8745	.6516	.5316	.8916	.8059	.6859	.8871
15	.6859	.6859	.9431	.583	.2572	.6687	.9055
16	.7545	.823	.9431	.6001	.9431	.6859	1.0164
17	.7545	.9259	1.0631	.583	.9945	.5487	
18	1.0974	.9945	1.0631	.9259		.7373	
19	1.1831	1.0802	1.3375	1.166			.1848
20	1.2517	1.1145	1.3546	1.2174		1.1317	.9979
21	1.1317	1.0802	1.2174	1.166		.9774	.9979
22	.9945	1.0802	1.1145	1.0802		.9431	.924
23	.9602	.9259	.9945	.8745		.8573	.8316
24		.8573	.8573	.8745	.7716		.8059
Max	1.2517	1.1145	1.3546	1.2174	1.1145	1.1317	1.166
Min	.6516	.3258	.5316	.583	.2572	.4115	.1848
Avg	.9244	.8320	.9553	.9283	.844	.7759	.8279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DHARWAH S/DN.[319]

BU 3191

Substation No/ Name :- 304081 / 33KV DARWHA S/S

Feeder No / Name : 206 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4232	1.3717	1.406	1.3717		1.1488
2	1.3375	1.406	1.3032	1.3889	1.3717		1.1145
3	1.3203	1.406	1.3032	1.3717	1.3032		1.1488
4	1.286	1.406	1.2346	1.406	1.3032		1.2003
5	1.286	1.3717	1.3203	1.4232	1.3375		1.2346
6	1.2689	1.3032	1.3546	1.4232	1.3546		1.286
7	1.286	1.3032	1.3546	1.4403	1.3889		1.3203
8	1.166	1.3032	1.3717	1.3375	1.3546		1.3032
9	1.2174	1.3032	1.2346		1.3032		1.4937
10	1.2003	1.2689	1.166		1.2003		1.4003
11	1.1317	1.2517	1.2003	1.166	1.1488	1.1488	1.3443
12	1.1488	1.2003	1.2003	1.1488	1.1145	1.0802	1.3443
13	1.1488	1.166	1.1317	1.0974	1.0117	.9945	
14	1.1488	1.166	1.1317	1.1145	1.0117	.9431	1.1203
15	1.2003	1.1488	1.1145	1.0974	.9945	.9088	1.0829
16	1.1831	1.1831	1.1145	1.1145	1.0117	.9945	1.1016
17	1.1488	1.1831	1.1831	1.1831	1.046	.9602	
18	1.1145	1.2689	1.3203	1.2346		1.1488	1.3817
19	1.286	1.5604	1.4918	1.4746		1.286	1.4003
20	1.5089	1.5775	1.5604	1.5089		1.3375	1.5497
21	1.4575	1.6461	1.5089	1.5261		1.3032	1.4377
22	1.4918	1.6461	1.5089	1.4918		1.286	1.4377
23	1.4918	1.5604	1.4918	1.4575		1.2517	1.3817
24		1.4232	1.4403	1.4403	1.3889		1.166
Max	1.5089	1.6461	1.5604	1.5261	1.3889	1.3375	1.5497
Min	1.1145	1.1488	1.1145	1.0974	.9945	.9088	1.0829
Avg	1.2696	1.3532	1.3089	1.3297	1.2232	1.1264	1.2909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304027 / 33 KV VASANT NAGAR

Feeder No / Name : 201 / 11 KV Vitholi Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0557		.0931
2				.0553		.0932
3				.0555		.0935
4				.0556		.0938
5			.0735	.0555		.0936
6			.0928	.1108		.0938
7			.1483	.1521		.1142
8			.167	.1798		.1512
9			.1679	.1658	.0276	.1507
10	.0564	.1553				.1509
11	.1316	.1555				
12	.15	.1696				
13	.3522	.1696				
14	.1478	.1269				
15	.1488	.1269				
16	.1497	.1267				
17	.1457	.1665				
24				.0697		.0934
Max	.3522	.1696	.1679	.1798	.0276	.1512
Min	.0564	.1267	.0735	.0553	.0276	.0931
Avg	.1603	.1496	.1299	.0956	.0276	.1110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304027 / 33 KV VASANT NAGAR

Feeder No / Name : 203 / 11 kv Vitholi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.6143	.6387	.6086	.618	.6105	.6143
2	.6348		.6231	.608	.6187	.6099	.6335
3	.6361	.6187	.6224	.6257	.6187		.6355
4	.6548	.7491	.6958	.6986	.6193	.668	.6568
5	.7311	1.0269	.7906	.7354	.7326	.7842	.7304
6	1.0621	1.0321	1.0374	1.0392	1.0311	1.0884	1.0134
7	.9986	1.0632	1.1016		1.1399		1.2371
8	.9896	.898	.874	1.0392	1.0664	1.0664	.9828
9	.7514	.7423	.785	.6715	.6322	.8419	.8102
10	.6958	.4294	.4472	.3913		.4518	.415
11	.3009	.3746	.3569	.3012			
12	.3187	.2545	.3395				
13	.3522	.3719	.3333	.2963	.2633	.3161	
14	.3696	.4066			.2821	.3364	
15	.4091	.422			.3		
16	.4303	.5561		.4431		.4463	
17	.5464	.703	.5413	.5376	.6887	.6005	
18	.7263	.8704	.8624	.9111	.8615	.9008	.7679
19	.9008	.8615	.9374	1.0413	.882	1.0306	.9845
20	.7476	.6243	.7484	.9307		.8462	.7818
21	.6929		.6936	.6915	.6763	.6922	.6915
22	.6381	.5682		.6742	.6575	.6735	.6708
23	.6174	.6568	.6381	.6542	.6348	.6728	.6515
24	.6335	.6143	.6374	.6092	.6361	.6099	.6348
Max	1.0621	1.0632	1.1016	1.0413	1.1399	1.0884	1.2371
Min	.3009	.2545	.3333	.2963	.2633	.3161	.415
Avg	.6447	.6572	.6852	.6754	.6821	.6972	.7595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304043 / 33 KV TIWARI

Feeder No / Name : 201 / 11 KV Tiwari

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7545	.7888	.2058	.8916	.7545	1.0288
2	.6173	.7545	.7888	.2058	.823	.7545	1.0288
3	.6173	.7545	.7888	.2058	.823	.7545	1.0288
4	.6173	.7545	.7888	.2058	.823	.7545	1.0288
5	.6859	.823	.8573	.2743	.823	.7545	1.0288
6	.6859	.8916	.8916	.3086	.823	.823	1.0288
7	.6859	1.0288	.9602	.4115	.823	.8916	
8	.6173	1.0974	1.0288	.3429	.9602	.823	.9602
9	.5487	1.0288	.8916	.4115	.823	.7545	.8916
10		.6173	.5487		.6859	.6173	.4801
11	.3429	.5487	.5487				.4115
12		.6173	.6173	.4115	.5487		.4115
13	.6173	.6859	.6859	.4115	.4801	.4115	.4115
14		.6859	.5487		.4115	.3429	.4115
15			.6173			.4115	.4801
16	.6173		.823	1.0288	.6173		.3429
17	.7545	.823	.7202	1.0288	.823	.5487	
18	.823	.8916	.9602	1.0974	1.0288	.6173	.7545
19	.8916	.9602	.9602	.9602	1.166	.6173	.9602
20	.9602	1.0288	.9602	.9602	1.0288	.8916	.9602
21	.823	.9602	1.0288	1.0288	.9602		.9602
22	.7545	.9602		.9602	.9602	1.0974	.9602
23	.7545	.8916		.9602	.8916	1.0974	.9602
24		.7545	.7888		.9259	1.0974	1.0974
Max	.9602	1.0974	1.0288	1.0974	1.166	1.0974	1.0974
Min	.3429	.5487	.5487	.2058	.4115	.3429	.3429
Avg	.6859	.8324	.7997	.6010	.8246	.7407	.8012



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304043 / 33 KV TIWARI

Feeder No / Name : 202 / 11 KV Arambhi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.0631	.6173	1.0631	1.0974	1.166
2		1.0974	1.0631	.6173	1.0631	1.0974	1.166
3		1.0974	1.0631	.6173	1.0631	1.0974	1.166
4		1.0974	1.0631	.6173	1.166	1.0974	1.166
5		1.166	1.0631	.823	1.166	1.166	1.166
6		1.4403	.9602	.8916	1.166	1.2346	1.166
7	1.2346	1.166	1.0288	.9602	1.3375	1.4403	
8	1.2346	1.4403	1.0288	.9259	1.2346	1.3032	.4801
9		1.4403	.8916	1.0974	1.166	1.2346	.4115
10		.7545	.3429		.8916	.7545	.2743
11	.6173	.7545	.2743				.2743
12	.6173	.7545	.2743	.6173	.5487		.5487
13	.6859	.7545	.2743	.6173		.4801	.5487
14		.8573	.8916		.6859	.5487	
15	.6859	.8916	.823		.6859	.6173	.6173
16	.7545	.823	.7545	.7545	.823		.6173
17	.823	.9602	.7545	1.0288	.9602	.7545	
18	.8916	1.0631	1.0288	1.0974	1.2346	1.0974	1.3032
19	1.4403	1.3032	1.0631	1.5089	1.2346	1.166	1.2346
20	1.5089	1.3717	1.0974	1.166	1.2346	1.2346	1.2346
21	1.3032	1.3717	1.0974	1.0288	1.2346		
22	1.2346	1.2346	1.0631	.9602	1.2346	1.166	
23	1.166	1.1317		.9602	1.166	1.166	
24	.9602	1.0974	1.0974		.6173	1.166	1.166
Max	1.5089	1.4403	1.0974	1.5089	1.3375	1.4403	1.3032
Min	.6173	.7545	.2743	.6173	.5487	.4801	.2743
Avg	1.0105	1.0903	.8722	.8898	1.0444	1.0460	.8726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304043 / 33 KV TIWARI

Feeder No / Name : 203 / 11 KV Wai

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.583	.583	.4287	.6516	.5487	.7888
2	.8573	.583	.583	.4458	.6516	.5487	.7888
3	.8573	.583	.583	.4458	.6859	.5144	.7888
4	.8573	.583	.583	.4458	.7545	.5144	.7888
5	.8573	.6516	.6173	.4115	.7545	.5144	.7888
6	.8573	.9945	.6516	.4458	.7545	.5487	.7888
7	.9431	.9602	.6516	.5487	.6687	.5487	1.0288
8		.9602	.7202	.6344	.6173	.6173	.7888
9	.703	.6516	.6001	.5487	.5487	.4115	.7716
10		.3772	.4115		.5487	.3772	.3086
11		.4801	.4115			.3086	.3258
12		.3772	.4458	.3601		.3086	.3772
13		.3086	.4458	.3772		.3772	.3772
14		.3086	.463			.3772	.3429
15		.4458	.463			.6001	.4115
16	.4115	.5316	.4801	.463		.3944	.3772
17	.4458	.5144	.4458	.5316		.463	.4801
18	.6173	.7716	.6687	.2915		.6687	.7888
19	.7545	.823	.6859	.3772	.7202	.6173	.8916
20	.6173	.8916	.6859	.823	.7202	.8402	.7888
21	.6516	.823	.7545	.7202	.7202	.7888	.7888
22	.6173	.823		.6344	.7202	.7716	.7545
23	.583	.7888		.6859	.7202	.7716	.7545
24	.8402	.583	.583		.6516	.6173	.7888
Max	.9431	.9945	.7545	.823	.7545	.8402	1.0288
Min	.4115	.3086	.4115	.2915	.5487	.3086	.3086
Avg	.7252	.6416	.5690	.5063	.6805	.5437	.6616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304060 / 33kv Tuptakli

Feeder No / Name : 202 / 11kv Lakh

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359		.3018	.285
2	.4694		.3185	.285
3	.503		.3018	.285
4	.5365		.3018	.3185
5	.5533		.3185	.4359
6	.5868		.3353	.503
7	.6371		.3688	.57
8	.5868		.6203	.6371
9	.5868		.5868	.5365
10		.4359	.4527	.3856
11		.2515	.4191	.3521
12		.3353	.3185	.3185
13		.3185	.2683	.2515
14		.3018	.2515	.3018
15		.3185	.285	.3018
16		.3353	.3856	.3353
17		.4024		.3688
18		.5533	.5365	.4862
19		.6203	.5533	.5533
20		.4694	.57	.57
21		.4191	.5868	.5197
22		.4694	.4527	.4527
23		.4694	.3185	.3353
24			.3353	.285
Max	.6371	.6203	.6203	.6371
Min	.4359	.2515	.2515	.2515
Avg	.5440	.4072	.3995	.4031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304060 / 33kv Tuptakli

Feeder No / Name : 203 / 11kv Chircuta

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1124	.9556		.9724	1.073
2	2.2802	1.0395		.8886	1.073
3	2.0454	1.1065		.8886	1.073
4	1.9448	1.1233		.9724	1.1401
5	2.0118	1.1568		1.0562	1.1904
6	2.1796	1.1568		1.073	1.2239
7	2.3808	1.073		1.0898	1.2574
8	2.4142			.9892	1.291
9	2.2466			.6539	1.1401
10	.6371		1.0059	.5868	
11			.6203	.6036	
12			.5533	.57	
13			.7209	.5533	.5197
14			.503	.5365	.5868
15			.5533	.7209	
16			.5868	.9389	.4527
17			.5868	1.0059	
18				1.073	1.0562
19			1.4083	.9892	1.3413
20			1.358	1.0059	1.3245
21			1.2239	1.0562	1.2574
22			1.1904	1.073	1.1065
23	1.0227		1.1736	1.0898	1.0395
24		.9221		1.0562	1.073
Max	2.4142	1.1568	1.4083	1.0898	1.3413
Min	.6371	.9221	.503	.5365	.4527
Avg	1.9341	1.0667	.8834	.8935	1.0642

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304061 / 33kv Kalgaon

Feeder No / Name : 201 / 11kv Kalgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6379	.4961	.6201	.6379		.6379	.4961
2	.567	.5316	.6201	.6201		.5316	.4961
3	.567	.5316	.6201	.6379		.5316	.567
4	.567	.567	.6556	.6733		.5316	.6379
5	.567	.6379	.6733	.691		.5316	.6379
6	.6024	.6733	.7619	.7265		.6379	.7087
7	.6024	.7265	.8328			.7087	.7442
8	.6024	.7796	.7973			.7087	.7087
9	.4961	.6379	.7619			.5316	.6379
10	.5316		.7265		.7442	.4607	.567
11	.5316		.6733		.6201	.4252	.5316
12	.5316	.7973			.5316	.3544	.4961
13	.4961	.8505	.5493		.4607	.3189	.4961
14	.4961	.8859			.2126	.3189	.4607
15	.5316	.815	.3544		.5316	.4607	.443
16	.6024	.815	.2303	.691	.5493	.567	.4961
17	.6379	.7796	.7973	.7973	.5316	.6733	.5316
18	.6379	.9745	.9568	.8682	.5316	.691	.7087
19	.6379	.9922	.9745	.7973	.7442	.7087	.7619
20	.6024	.9745		.7442	.7087	.7442	.7087
21	.6024	.8859		.7087	.6733	.7087	.7087
22	.6024	.7973		.6379	.7087	.5847	.7087
23	.567	.6379	.691	.6024	.7087	.5316	.7087
24	.6516	.4961	.6379	.6379		.6379	.4961
Max	.6516	.9922	.9745	.8682	.7442	.7442	.7619
Min	.4961	.4961	.2303	.6024	.2126	.3189	.443
Avg	.5779	.7401	.6808	.6981	.5898	.5640	.6024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304061 / 33kv Kalgaon

Feeder No / Name : 202 / 11kv Dehani

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.4961	.567	.4784		.5316	.4961
2	.4961	.4961	.567	.4607		.5316	.4961
3	.4607	.4961	.567	.4784		.5316	.567
4	.4607	.4607	.5847	.5138		.5316	.6379
5	.5316	.4607	.691	.567		.5316	.6733
6	.5316	.6379	.8505	.6379		.5316	.7796
7	.567	.7087	.9214			.6379	.8505
8	.567	.7796	.6733			.5316	.6733
9	.567	.7442	.5316			.5316	.567
10	.5316		.443		.6733	.5316	.567
11	.5316		.3898		.3898		.5316
12	.5316	.4607	.3544		.3189	.4961	
13	.4961	.4961	.3898		.3189	.3898	
14	.4961	.5316	.3898		.3189	.3544	
15		.5316	.3898		.3544	.3898	
16	.4252	.5316	.4075	.4075	.3544	.3898	
17	.4784	.567	.5847	.4075	.5316	.4252	.3544
18	.567	.6556	.7087	.5138	.7087	.4961	.5316
19	.6024	.691	.7087	.7619	.7442	.6379	.7087
20	.567	.6733		.6733	.7087	.7442	.7087
21	.567	.6379		.6201	.6201	.7442	.7087
22	.5316	.6201		.567	.6379	.5847	.7087
23	.5316	.5847	.5138	.567	.6379	.5316	.7087
24	.5068	.5316	.567	.4784		.5316	.4607
Max	.6024	.7796	.9214	.7619	.7442	.7442	.8505
Min	.4252	.4607	.3544	.4075	.3189	.3544	.3544
Avg	.5236	.5815	.5619	.5422	.5227	.5277	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304061 / 33kv Kalgaon

Feeder No / Name : 203 / 11kv Kandali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.691	.5316	.7442	.7265	.6201	.7087	.6733
2	.691	.5316	.7442	.7265	.567	.7087	.7442
3	.691	.5316	.7265	.7087	.567	.7087	.7442
4	.691	.6379	.7442	.7265	.567	.7087	.815
5	.7796	.6379	.8859	.8505	.6733	.815	.9214
6	.9214	.7442	1.134	1.0277	.7796	.815	.9922
7	.9568	.8505	1.1694		1.0277	.9922	1.0277
8	.9568	.9922	.8859			.7087	.9214
9	.9568	.9568	.7973			.6733	.9214
10	.8859		.7619			.6733	.815
11	.815		.6379		.6379		.7087
12	.7087	.5316	.567		.6024	.6379	.6201
13	.6733	.6379	.567		.5138	.6379	.5138
14	.6733	.7087	.6024		.4961	.6024	
15	.6733	.7442	.6201		.4252	.6379	.567
16	.6379	.7442	.6379	.567	.3544	.6379	.6379
17	.6379	.7619	.8682	.7087	.5316	.6733	.6733
18	.6733	.9922	1.0099	.7973	.6379	.6733	.7087
19	.815	1.0631	1.0454	.7973	.9922	.7796	.7973
20	.815	1.0277		.7796	.9568	.8505	.7087
21	.6733	.9745		.7796	.8859	.8505	.7087
22	.6733	.8859		.7087	.7087	.7619	.7442
23	.6201	.7796	.7619	.7087	.7087	.7087	.7442
24	.7059	.5493	.7619	.7265	.6201	.7087	.6733
Max	.9568	1.0631	1.1694	1.0277	1.0277	.9922	1.0277
Min	.6201	.5316	.567	.567	.3544	.6024	.5138
Avg	.7507	.7643	.7940	.7560	.6606	.7249	.7557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304088 / 33/11 KV DIGRAS SUBSTATION

Feeder No / Name : 201 / AMBIKA NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2428	2.1559	1.9721		1.9909	1.9378
2		2.0998	2.2039	1.829		1.9909	1.8986
3		2.0394	2.1849	1.8385		1.9104	1.88
4		2.0754	2.3081	2.0165		1.829	1.8614
5		1.9958	2.2565	2.0634		1.9877	
6		2.0559	2.3315	2.0475		1.9204	1.4693
7		2.0079	2.0217	2.0119		1.9713	1.8428
8		1.95	2.0224	2.0266		1.9244	2.1867
9		1.8733	1.9529			1.885	
10		1.9811	1.8201		2.0775	1.7593	
11	1.647	1.8442	1.6967	1.752			1.8569
12	1.6821	1.8428	1.6752	1.5185	1.6012	1.5107	1.7869
13	1.708	1.8204	1.6566	1.5995	1.4906	1.475	.6268
14	1.7267	1.8296	1.807	1.5811	1.4578	1.4548	.608
15	1.7942	1.8017	1.8069		1.3803	1.4177	1.8614
16	1.7284	1.7888	1.8088	1.8239	1.4708	1.4133	1.6974
17	1.7174	1.8447	1.9012	1.6827	1.6263	1.4708	1.7339
18	1.855	1.9672	2.0308	1.99	1.6296	1.6887	1.8385
19	1.9771	1.9329	2.2588	2.0475	1.8503	1.8614	2.0102
20	2.0559	2.2085	2.2546	2.2476		1.9025	2.0847
21	2.2585		2.3057	2.3341	2.1357	1.9998	2.0682
22	2.2942	2.2291	2.2965	2.4553	2.0705	1.9672	2.168
23	2.2958	2.25	2.1578	2.3349	2.0452	1.9896	2.0485
24		2.2473	2.2802			2.0924	1.9585
Max	2.2958	2.25	2.3315	2.4553	2.1357	2.0924	2.1867
Min	1.647	1.7888	1.6566	1.5185	1.3803	1.4133	.608
Avg	1.9031	1.9969	2.0498	1.9586	1.7363	1.8006	1.7821



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304088 / 33/11 KV DIGRAS SUBSTATION

Feeder No / Name : 202 / SAMBHAJI NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0185	1.8146	1.8511	1.7928	1.7194	1.8428
2		1.9024	1.8214	1.7928		1.7194	1.8037
3		1.8784	1.97	2.0287		1.6375	1.7814
4		1.9284	1.8614	1.8442		1.6827	1.839
5		1.9398	2.0873	2.0119		1.7741	1.8614
6		1.9438	2.1077	1.9721		1.822	1.9006
7		1.9004	2.0035	1.9733		1.9244	1.9418
8		1.9142	1.9856			1.8608	2.0185
9		1.855	1.8239			1.8111	
10		1.9251	1.8201			1.7407	
11	1.7194	1.9918	1.8259	1.8201			2.0797
12	1.7382	1.9917	1.6752	1.7072	1.6748	1.5476	
13	1.653	1.8385	1.6188	1.566	1.677	1.3817	1.6827
14	1.5813	1.6718	1.638		1.4952	1.3429	1.5854
15	1.5887	1.5339	1.6444	1.4739	1.3251	1.2541	1.3746
16	1.6024	1.6229	1.8055	1.4815	1.4708	1.3958	1.3394
17	1.6101	1.6598	2.0706	1.5995	1.5893	1.5138	1.532
18	1.7631	1.7834	2.0847	2.0408	1.7037	1.7205	1.7975
19	2.0704	2.0577	2.1888	2.0661	1.773	1.9958	1.829
20	2.0746	2.1165	2.1317	1.9529		1.855	1.9856
21	2.0217	2.0475	2.0661	2.0141	1.9004	1.7943	1.8839
22	2.0331	2.0619	2.0517	2.1082	1.8004	1.7303	1.7942
23	1.9652	1.8967	1.9529	1.9856	1.7737	1.7205	1.7375
24		1.955	1.9251	1.8569		1.7831	1.826
Max	2.0746	2.1165	2.1888	2.1082	1.9004	1.9958	2.0797
Min	1.5813	1.5339	1.6188	1.4739	1.3251	1.2541	1.3394
Avg	1.8016	1.8931	1.9156	1.8573	1.6647	1.6838	1.7827

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304088 / 33/11 KV DIGRAS SUBSTATION

Feeder No / Name : 203 / RURAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.434	1.869	1.6349	1.6852	1.7928	1.6289	1.4177
2	1.3803	1.7588	1.6757	1.7193		1.6108	1.5232
3	1.3689	1.7353	1.6118	1.9544		1.5829	1.5692
4	1.448	1.7448	1.9544	1.9832		1.5546	1.6465
5	1.5304	1.7346	2.0497	2.0706		1.6461	
6	1.6384	1.7756	2.0517	2.0847		1.7778	
7	1.6852	1.8286	1.7667	2.056	1.829	1.9244	
8	1.6111	1.7353	1.9121		1.829	1.8423	.2692
9	1.4784	1.6713	1.0317		1.7852	1.5708	
10	1.2331	1.4578	1.0424		1.3169	.9444	
11	1.1946	1.3278	1.0769	1.2803	1.287		.848
12	1.2896	1.2657	1.3324	1.2945	1.4355	.8659	.924
13	1.3224	1.287	1.6753	1.0608	1.2111	.9709	
14	1.3268	1.3432	1.7882	1.1888	1.1214	.9512	.1384
15	1.3083	1.4943	1.7339	1.1031	.9754	.8906	1.0393
16	1.4403	1.7357	1.7683	1.5117	1.4157	.9289	1.1168
17	1.5027	1.8252	1.7849	1.6598	1.4969	.9691	1.2936
18	1.304	1.2318	1.8442	1.4054	1.5741	1.2385	1.7104
19	1.4362	2.0869	1.8617	2.1245	1.6821	1.8614	1.9705
20	1.6634		1.8982	2.2267	1.7013	1.8614	1.9731
21	2.0217	1.9544	2.0061	1.9753	1.7556	1.8371	1.8018
22	1.9398	2.0062	1.9339	1.9529	1.7284	1.7647	1.7382
23	1.7999	1.6735	1.8018	1.9304	1.647	1.6632	1.5912
24	1.4444	1.8088	1.7382	1.7193	1.7282	1.6375	1.2856
Max	2.0217	2.0869	2.0517	2.2267	1.829	1.9244	1.9731
Min	1.1946	1.2318	1.0317	1.0608	.9754	.8659	.1384
Avg	1.4917	1.6675	1.7073	1.7137	1.5428	1.4575	1.3254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304088 / 33/11 KV DIGRAS SUBSTATION

Feeder No / Name : 204 / CHINCHOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9158	.7905	.7682	.7171	.7602	.775
2		.8435	.7832	.8596		.7059	.7538
3		.805	.8059	.8068		.7096	.7343
4	.7059	.8448	.8376	.823		.7316	.7562
5	.8282	.8953	.8971	.8596		.7316	.757
6	.8822	.8784	.8953	.8659		.7178	.7554
7	.7178	.986	.8378	.8372	.8596	.6965	.8471
8	.8519	.6977	.9744		1.0059	.5711	.8308
9	.6111	.6612	.6448		.8089	.5544	
10	.4969	.4673	.5731		.695	.4815	
11	.1448	.4979	.5753	.5205	.6986		.5194
12	.2617	.5398		.4119	.8098	.4606	.5384
13	.6244	.6435	.4758	.2689	.8385	.4639	.1939
14	.6543	.7354	.7521	.4477	.785	.5409	.2266
15	.7289	.7538	.8229	.5344	.7362	.5089	.5552
16	.6662	.913	.8663	.5293	.6986	.5725	.5564
17	.5904	.9223	.8635	.793	.462	.6288	.5904
18	.6979	.913	.9619	.753	.5556	.3936	.7538
19	.7088	1.0342	1.0154	.8779	.5981	.6268	.7742
20	.785	.9938	.9362	.8729		.6481	.905
21	.8378	.8376	.8059	.8435	.7602	.6992	.7538
22	.8393	.8545	.8551	.7133	.7202	.6984	.8224
23	.7897	.8925	.7632		.724	.6977	.823
24		.877	.785	.7171	.717	.7278	.7742
Max	.8822	1.0342	1.0154	.8779	1.0059	.7602	.905
Min	.1448	.4673	.4758	.2689	.462	.3936	.1939
Avg	.6712	.8085	.8051	.7052	.7328	.6229	.6817

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

DIGRAS S/DN.[323]

BU 1759

Substation No/ Name :- 304088 / 33/11 KV DIGRAS SUBSTATION

Feeder No / Name : 205 / EXPRESS WW

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1287	.1308	.1258	.122	.1434	.1267	.1248
2	.1288	.1256	.1275	.1274		.1267	.1254
3	.1278	.1431	.1254	.1255			.1256
4	.1267	.1469	.1303	.126			.1255
5	.126	.1492	.1316	.1425			.1252
6	.126	.1495	.1306	.141			.1248
7	.1288	.1255	.1457	.1434	.1463		.1254
8	.1296	.1431	.1287		.1463		.1437
9	.1294	.1286	.1474		.1287		
10	.1288	.1495	.1254		.1463		
11	.0543	.0738	.073	.0715	.0735		.0537
12	.0748	.0745	.0565	.0716	.0552	.0737	.0713
13	.0918	.0545	.0534	.0717	.0559	.056	.0713
14	.0727	.0745	.0541	.0529	.0561	.056	.0529
15	.0561	.0528	.0523	.0529	.0552	.0545	.0534
16	.054	.0528	.0525	.0706	.0552	.0537	.0713
17	.0537	.0521	.126	.0528	.0554	.0539	.0529
18	.0735	.0533	.1069	.0707	.1296	.0535	.0705
19	.056	.0552	.126	.0529	.1308	.0538	.0523
20	.1308	.1288	.0523	.1255	.1254	.1254	.1425
21	.1275	.1489	.1254	.1434	.1267	.1258	.1433
22	.1306	.1486	.146	.144	.126	.1262	.1495
23	.1286	.1302	.1506	.1471	.0667	.1264	.1463
24	.1296	.1279	.1495	.1254	.1471	.1274	.1254
Max	.1308	.1495	.1506	.1471	.1471	.1274	.1495
Min	.0537	.0521	.0523	.0528	.0552	.0535	.0523
Avg	.1048	.1092	.1101	.1038	.1037	.0893	.1035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 201 / 11 KV Sawana AG OLD

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1219	.1524	.0171	.0152	.0152	.0152
2	.0914	.1219	.1677	.0171	.0152	.0152	.0152
3	.0914	.1067	.1524	.0171	.0152	.0152	.0152
4	.1067	.1372	.1829	.0171	.0152	.0152	.0152
5	.1219	.1524	.1524	.0171	.0171	.0152	.0152
6	.1219	.1829	.1524	.0171	.0152	.0152	.0152
7		.2134	.2743	.0171	.0305	.0152	.0152
8	.2439	.2896	.3353	.0171	.0152	.0152	.0152
9	.3048	.2743	.3048			.0152	.0152
10		.0152	.2896			.0457	.0152
11	.0152	.0152	.2743				.0152
12	.0152	.0152	.2743		.2134		.0152
13	.0152	.0152	.2743		.2134		
14	.0152	.0152	.2896		.1981		
15	.0152	.0152	.2743		.2134		
16	.0152	.0152	.2743		.2439	.061	
17	.0152	.0171	.2743		.1524	.061	
18	.0152	.0171	.0152		.0152	.0152	.0152
19	.0152	.0152	.0305	.0152	.0152	.0152	.0152
20	.0152	.0152	.0171	.0152	.0152	.0152	.0152
21	.0152	.0152	.0171	.0152	.0152	.0152	.0152
22	.0152	.0152	.0171	.0305	.0152	.0152	.0152
23	.0152	.0152	.0171	.0152	.0152		.0152
24	.0762	.1219	.1372	.0171	.0152	.0152	.0152
Max	.3048	.2896	.3353	.0305	.2439	.061	.0152
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0651	.0808	.1813	.0175	.0705	.0220	.0152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 202 / 11 KV Factory

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	.0457	.0457	.0457	.0343	.0457	.0457
2	.0457	.0457	.0457	.0457	.0305	.0457	.0457
3	.0457	.0457	.0305	.0457	.0457	.0457	.0457
4	.0457	.0457	.0343	.0457	.0457	.0457	.0457
5	.0457	.0457	.0305	.0457	.0457	.0457	.0457
6	.0457	.0457	.0457	.0457	.0457	.0457	.0457
7	.0457	.0457	.0457	.0457	.0457	.0457	.0457
8	.0457	.0457	.0514	.0457	.0514	.0457	.0457
9	.0457	.0457	.0457			.0457	.0457
10		.0457	.0457			.0457	.0457
11	.0457	.0457	.0457				.0457
12	.0457	.0457	.0457		.0457		.0457
13	.0457	.0457	.0457		.0457		
14	.0457	.0457	.0457		.0457		
15	.0457	.0457	.0457		.0305		
16	.0457	.0457	.0457		.0457	.0305	
17	.0457	.0457	.0457		.0457	.0457	
18	.0457	.0457	.0457		.0457	.0457	.0305
19	.0457	.0457	.0457	.0305	.0457	.0457	.0457
20	.0457	.0457	.0514	.0457	.0457	.0457	.0457
21	.0457	.0457	.0514	.0457	.0457	.0457	.0457
22	.0457	.0457	.0514	.0457	.0457	.0457	.0457
23	.0457	.0457	.0514	.0457	.0457		.0457
24	.0457	.0457	.0457	.0457	.0457	.0457	.0457
Max	.0457	.0457	.0514	.0457	.0514	.0457	.0457
Min	.0457	.0457	.0305	.0305	.0305	.0305	.0305
Avg	.0457	.0457	.0451	.0446	.0440	.0449	.0449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 203 / 11 KV Kali Ag (GUNJ)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.2193	.9145	.1524	.1829
2			1.2193	.945	.1677	.1829
3			1.2955	.9755	.1677	.1829
4			1.2955	.9297	.2134	.1829
5			1.3717	1.0364	.3048	.2134
6			1.3717	1.2003	.381	.2134
7			1.5242	1.6156	.4268	.2591
8			1.5242	1.9052	.381	.4268
9						.442
10		1.0669				.381
11	.7926	1.4175				.4115
12	1.4022	1.448				.3506
13	1.4327	1.3565				
14	1.448	1.387				
15	1.5242	1.6461				
16	1.6004	2.0424				
17	1.5394	1.8595				
24	.1219		1.2193	.8535	.1372	.2134
Max	1.6004	2.0424	1.5242	1.9052	.4268	.442
Min	.1219	1.0669	1.2193	.8535	.1372	.1829
Avg	1.2327	1.5280	1.3379	1.1529	.2591	.2802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 204 / 11 kv Dhanoda Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	1.0517	1.3413	.0914	.0762		.061
2	.5487	1.0669	1.5242	.0762	.0762		.061
3	.5487	1.0822	1.5242	.0762	.0762		.061
4	.5792	1.0822	1.3413	.0762	.0914		.0762
5	.5944	1.1279	1.2346	.0762	.0914		.0762
6		1.1584	1.1584	.0762	.0914		.061
7	.8993	1.5699	1.3375	.0762	.0152		.061
8	.8535	1.5242	1.2041	.0762	.0857		.0914
9	1.0364	1.5089	1.6461				.0914
10		.0762	1.6766				.0762
11	.061	.0914	1.6004			.0762	.061
12			1.7528		2.21	.5182	.061
13		.0914	1.6766		2.0576		
14		.061			1.9509	.442	
15		.061	1.9052	2.1338	1.829	.4877	
16			1.9814	2.1033	1.9814	.503	
17			2.0576	2.0576	2.1338	.5182	
18	.1067	.0914		.0914		.0762	
19	.0914	.1219	.1067	.0762		.061	.0762
20	.1067	.1372	.12	.0914		.0762	.0762
21	.1372	.1067	.1029	.1067		.0914	.0762
22	.1219	.1067	.1029	.1219		.0914	.0914
23	.1067	.0914	.12	.1219			.0914
24	.6249	1.0212	1.2803	.0914	.1067		.0762
Max	1.0364	1.5699	2.0576	2.1338	2.21	.5182	.0914
Min	.061	.061	.1029	.0762	.0152	.061	.061
Avg	.4372	.6300	1.2180	.4234	.8582	.2674	.0737



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 205 / SAWANA GAOTHAN OLD

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0152		.0152	.3658	.0152
2	.0152	.0152	.0152		.0152	.0152	.0152
3	.0152	.0152	.0152		.0152	.0152	.0152
4	.0152	.0152	.0152		.0152	.0152	.0152
5	.0152	.0152	.0152		.0152	.0152	.0152
6	.0152	.0152	.0152		.0152	.0152	.0152
7	.0152	.0152	.0171		.0152	.0152	.0152
8			.0152		.0171	.0152	.0152
9	.0152		.0152			.0152	.0152
10			.0152			.0152	.0152
11	.0152		.0152				.0152
12	.0152	.0152	.0152		.0152		.0152
13	.0152	.0152	.0152		.0152		
14	.0152	.0152	.0152		.0152		
15	.0152	.0152	.0152		.0152		
16	.0152	.0152	.0152		.0152	.0152	
17	.0152	.0152	.0152		.0152	.0152	
18	.0152	.0152	.0152		.0152	.0152	.0171
19	.0152	.0152	.0152	.0152	.0152	.0152	.0152
20	.0152	.0152	.0171	.0152	.0152	.0152	.0152
21	.0152	.0152	.0171	.0152	.0152	.0152	.0152
22	.0152	.0152	.0171	.0152	.0152	.0152	.0152
23	.0152	.0152	.0171	.0152	.0152		.0152
24	.0152	.0152	.0152		.0152	.0152	.0152
Max	.0152	.0152	.0171	.0152	.0171	.3658	.0171
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0152	.0152	.0156	.0152	.0153	.0347	.0153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 206 / DHANODA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.442	.4268	.4572	.3963	.3353	.3658
2	.3963	.4268	.4801	.4572	.4458	.3353	.3658
3	.4268	.4268	.3353	.4572	.3658	.3506	.3963
4	.5487	.4572	.442	.4572	.4572	.3963	.4572
5	.5944	.5487	.4877	.5335	.5487	.442	.4877
6	.7164	.6401	.703	.5792	.6554	.4877	.6706
7	.6859	.6706	.6859	.7164	.7164	.4572	.7316
8	.7011	.6401	.7011	.6859	.5335	.4268	.7011
9		.6097	.5792				.5792
10	.4725	.4268	.3658				.381
11	.2896	.3963	.2896			.1829	.2743
12			.2896		.2439	.1524	.2743
13		.5144	.3048		.2286	.2439	
14	.2743	.4268	.2896		.2439	.2286	
15	.2591	.4725	.2896	.3429	.2439	.2743	
16	.2743		.3048	.3048	.2896	.2743	
17	.381		.3201	.381	.3658	.381	
18	.5182	.6401		.5335	.5182	.4877	
19	.6706	.6249	.6554	.6706	.5335	.6249	.6706
20	.7011	.6344	.7202	.6097	.4877	.5792	.5792
21	.5792	.6001	.5658	.5182	.381	.4877	.5335
22	.5335	.5182	.5658	.4877	.3658	.4572	.4572
23	.4725	.4877	.5316	.4725	.3658		.4115
24	.4725	.4572	.4725	.4572	.442	.3506	.4268
Max	.7164	.6706	.7202	.7164	.7164	.6249	.7316
Min	.2591	.3963	.2896	.3048	.2286	.1524	.2743
Avg	.4950	.5267	.4698	.5068	.4204	.3789	.4869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 207 / EXPRESS I.T.I.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.0152	.0152	.0152	.0152	.0152	.0152
2	.0152	.0152	.0152	.0152	.0152	.0152	.0152
3	.0152	.0152	.0152	.0152	.0171	.0152	.0152
4	.0152	.0152	.0152	.0152	.0152	.0152	.0152
5	.0152	.0152	.0152	.0152	.0152	.0152	.0152
6	.0152	.0152	.0305	.0152	.0152	.0152	.0152
7	.0152	.0152	.0152	.0152	.0152	.0152	.0152
8	.0152	.0152	.0152	.0152	.0152	.0152	.0152
9		.0152	.0152			.0152	.0152
10		.0152	.0152			.0152	.0152
11	.0152	.0152	.0152				.0152
12	.0152	.0152	.0152		.0152		.0152
13	.0152	.0152	.0152		.0152		
14	.0152	.0152	.0152		.0152		
15	.0152	.0152	.0152		.0152		
16	.0152	.0152	.0152		.0152	.0152	
17	.0152	.0152	.0152		.0152	.0152	
18	.0152	.0152	.0152		.0152	.0152	.0152
19	.0152	.0152	.0152	.0152	.0152	.0152	.0152
20	.0152	.0152	.0171	.0152	.0152	.0152	.0152
21	.0152	.0152	.0171	.0152	.0152	.0152	.0152
22	.0152	.0152	.0171	.0152	.0152	.0152	.0152
23	.0152	.0152	.0171	.0152	.0152		.0152
24	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Max	.0152	.0152	.0305	.0152	.0171	.0152	.0152
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.0152	.0152	.0162	.0152	.0153	.0152	.0152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304004 / 33 KV GUNJ

Feeder No / Name : 208 / KALI D. GAOTHAN (GUNJ)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859	.6401		.6401	.7316	.6706
2	.061	.6706	.6554		.6401	.7164	.6706
3	.061	.7011	.6706		.7316	.7164	.8383
4	.7926	.7773	.6097		.7926	.7468	.8993
5	.9907	.9297	.7316		.9755	.9297	
6	1.1736	1.0669	.945		1.0517	1.1431	1.1584
7	1.2193	1.1736	1.1584		1.0974	1.2498	1.3565
8		1.1126	1.2193		1.0822	1.2955	1.2803
9	.8688	.9297	1.0517			1.0364	1.0364
10		.7621	.7011			.7011	.7316
11	.4725	.5944	.5335				.4572
12	.4115	.5639	.3353		.4572		.4572
13		.6401	.3353		.442		
14		.7316			.442		
15	.5182	.823	.3658		.503		
16	.6249	.9145	.3506		.5944	.5182	
17	.7468	.945	.503		.823	.7468	
18	.9145	1.0517	.8535		1.2041	.9602	1.0517
19	1.0974	1.0364		1.2193	1.0059	1.0974	1.0974
20	1.1279	.945	1.0802	1.1279	.7011	1.0974	1.0974
21	.9297	.8383	.9259	.9145	.8535	.8688	.9145
22	.823	.7926	.7888	.7621	.7773	.7621	.7926
23	.7468	.7621	.7888	.7468	.7621		.7468
24	.7011	.7011	.7316		.7164	.7468	.7316
Max	1.2193	1.1736	1.2193	1.2193	1.2041	1.2955	1.3565
Min	.061	.5639	.3353	.7468	.442	.5182	.4572
Avg	.7484	.8396	.7261	.9541	.7759	.8925	.8882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304020 / 33 KV MAHAGAON

Feeder No / Name : 201 / 11 KV Mahagaon

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.884	.9145		.9145	.9145
2			.884	.9145		.9755	.8779
3			1.0059	.9145		1.0364	.8779
4			1.0364	1.1279		1.0364	.9511
5			1.0364	1.1584		1.0669	.9511
6			1.0669	1.1888		1.0669	1.1706
7			1.0669	1.2193		1.1584	1.2803
8			1.0974	1.2193		1.1888	1.3169
9	1.1706	1.3611	1.2803	1.2803	1.2803	.9945	1.0364
10	1.0974	1.3535	1.2071	1.182	1.2437	.823	.9755
11	.9877	1.2803	1.0974		1.2071	.7621	.8535
12	1.0242	1.134	1.2178	1.1104	1.0974	.7621	.7011
13	1.0974	1.134	1.1104	1.1104	1.0974	.7926	.7621
14	.9511	1.0745	1.0974	1.0974	1.134	.7621	.7621
15	1.1706	1.1706	1.0974	.7087	1.1694	1.0059	.8413
16	1.1706	1.1706	1.2071	1.1706	1.773	.9877	.8048
17	1.1706	1.1706	1.2803	1.1706	.9145	.9877	.8954
18	1.3169	1.2437	1.39	1.1706	1.226	1.134	1.1706
19	1.2437	1.2437	1.4266	1.2803	1.2071	1.0608	1.0974
20	1.3535	1.2803	1.3535	1.134	1.7193	.9511	1.0974
21	1.0974	1.2803	1.1706	1.0974	1.0608	.9877	1.0029
22	1.2437	1.0974	1.1706	1.0974	1.0608	.9511	.9877
23	1.0669	1.134	1.2071	.695	1.0974	.9511	.7621
24	1.0364						.7621
Max	1.3535	1.3611	1.4266	1.2803	1.773	1.1888	1.3169
Min	.9511	1.0745	.884	.695	.9145	.7621	.7011
Avg	1.1374	1.2086	1.1475	1.0892	1.2192	.9721	.9522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304020 / 33 KV MAHAGAON

Feeder No / Name : 202 / 11 KV Morath

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.3353	.5792		.3048	.3292
2			.3353	.5792		.3048	.3292
3			.3658	.6097		.3353	.3292
4			.4268	.6401		.3658	.3292
5			.4572	.7011		.3658	.3292
6			.4877	.7011		.3658	.4024
7			.6097	.8535		.3658	.4024
8			.6401	.8535		.3963	.4024
9	.7316	1.39	1.2803	1.0745	1.0242	.3658	.3353
10	.8413	1.3535	1.3169	1.2437	1.0242	.3353	.3658
11	.8779	1.4266	1.2803		1.1706	.3048	.3658
12	.8413	1.4632	1.3535	1.1462	1.2437	.3048	.3658
13	.8596	1.5043	1.3169	1.1317		.3353	.3658
14	.8048	1.5729	1.2803	1.182	1.1706	.3353	.3353
15	.695		1.2803	1.3169	1.2071	.439	.439
16	.695		1.5364	1.2803	1.2826	.439	.3658
17	.7316		1.5364	1.3169	1.2071	.439	.3292
18	.7316		1.3535	.9511	1.2071	.439	.3658
19	.8048		1.1706	.9511	.4755	.3292	.394
20	.9877		.9877	.5487	.439	.3658	.439
21	.9145		.9511	.3292	.439	.4755	.3658
22	.9145		.8413	.4024	.4024	.3292	.3224
23	.7316		.8048	.3658	.439	.3292	.3353
24	.7621						.3353
Max	.9877	1.5729	1.5364	1.3169	1.2826	.4755	.439
Min	.3048	1.3535	.3353	.3292	.4024	.3048	.3224
Avg	.7782	1.4518	.9543	.8526	.9094	.3639	.3616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304020 / 33 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mudana

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743	.3048		.1524	.2195
2			.2439	.3048		.1524	.1829
3			.2439	.3048		.1829	.1829
4			.2743	.3353		.1829	.1829
5			.2743	.3353		.1829	.1829
6			.3048	.3658		.1829	.2195
7			.3048	.3963		.1829	.2561
8			.3353	.3963		.3048	.2561
9	.3292	.3224	.3658	.3395	.3658	.1524	.2134
10	.2561	.2926	.3224	.4298	.3292	.1524	.2134
11	.2263	.2561	.3582		.3658	.1524	.1829
12	.1829	.3582	.4024	.4024	.3292	.1524	.2134
13	.1829	.2926	.3658	.3658	.3292	.1524	
14	.1829	.2561	.439	.439	.3292	.1524	
15	.1829	.2561		.3292	1.2071	.1829	.2561
16	.1829	.3658		.3292	.3292	.2195	.2195
17	.2561	.3292		.3292	.1463	.1829	.2561
18	.2561	.4024		.3292	.1463	.439	.2195
19	.1829	.4024		.3292	.2561	.2561	.2926
20	.2561	.4024		.2561	.2195	.2195	.2561
21	.2561		.2561	.2561	.2743	.2195	.2561
22	.2926		.2561	.2926	.2195	.2195	.2195
23	.2439		.2926	.3292	.2195	.2195	.2134
24	.2134						.2134
Max	.3292	.4024	.439	.439	1.2071	.439	.2926
Min	.1829	.2561	.2439	.2561	.1463	.1524	.1829
Avg	.2302	.3280	.3126	.3409	.3377	.1999	.2231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304020 / 33 KV MAHAGAON

Feeder No / Name : 204 / 11 KV Amboda

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9145	.884		1.1279	1.6095
2			.9145	.9145		1.1279	1.4632
3				.9145		1.1888	1.4632
4				1.0669		1.3375	1.4632
5				1.2193		1.3717	1.6095
6				1.3717		1.3717	1.8656
7				1.5432		1.2498	2.1216
8				1.5242		1.3717	2.1948
9	1.4632	3.658		2.6703	2.963	.8535	1.829
10	1.7193	3.6214	.9877	4.1701	3.8043	.8535	1.7147
11	1.7924	3.5117	1.182		3.8409	.8535	1.5432
12	1.0242	3.5482	1.2536	3.3288	3.8043		1.4403
13	.9877	2.4143	1.2803	3.3311		1.2193	1.3032
14	.9511	2.3411	1.3169	3.0445		.7621	
15	.9511		1.3169	3.1824	3.7311	.9145	.5487
16	.9877		4.5359	3.1824	3.7677	.9877	.7682
17	.9877		4.3896	3.8775	3.8043	1.4632	.8596
18	2.4508		4.2067	3.658	3.658	1.829	
19	1.829		4.3896	3.4019	3.5482	1.7924	
20			4.7554	2.9264	1.829	1.4632	
21	.9145		3.2922	3.5482	1.8656	1.8656	
22	1.0974		3.658	2.5606	1.6461	1.4632	
23	1.0288		1.4632	2.1948	1.6461	1.7558	1.3032
24	.8573						1.1279
Max	2.4508	3.658	4.7554	4.1701	3.8409	1.8656	2.1948
Min	.8573	2.3411	.9145	.884	1.6461	.7621	.5487
Avg	1.2695	3.1825	2.4911	2.4780	3.0699	1.2829	1.4571



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304030 / 33 KV FULSAWANGI

Feeder No / Name : 201 / 11 KV Fulsawangi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.6335	.631		.7011	.6584	.5258
2	.543	.6516	.631		.6661	.6878	.5609
3	.5792	.6697	.631		.6661	.695	.5258
4	.6154	.6878	.6661		.631	.7316	.5609
5	.724	.724	.7011		.7011	.7316	.5959
6	.7964	.7783	.7712		.8063	.7682	.7011
7	.7964	.8326	.7011			.823	.7712
8	.724	.7421	.631		.7011	.8048	.7362
9	.6154	.6661	.6697		.8145	.7682	.7362
10		.6661	.7011		.5959	.6584	.631
11	.5973	.631	.5959	.5487	.5792		.6516
12	.6335	.631	.7059	.5959	.5611	.5434	.5792
13	.6335	.631	.6335	.5959	1.0679	.543	.6516
14	.5792	.6154	.7059	.5258	.4706	.5611	.543
15	.5434	.7059	.6516	.4733	.5249	.543	.5792
16	.6219	.7059		.5609	.4525	.6335	
17	.5121	.724	.8145	.5609	.5973	.5959	
18		.7602	.8145		.724	.6661	.5611
19	.823	.7186	.8507	.7011	.7602		
20	.7602	.7602	.7964	.7011	.7522	.6661	.6697
21	.724	.6516	.8326	.7011	.7316	.631	.543
22	.724	.631	.7602	.724	.724	.6348	.4706
23		.631	.724	.7011	.6878	.5959	.5249
24	.543	.6335	.631		.7011	.6584	.5609
Max	.823	.8326	.8507	.724	1.0679	.823	.7712
Min	.5121	.6154	.5959	.4733	.4525	.543	.4706
Avg	.6509	.6868	.7066	.6158	.6790	.6636	.6038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304030 / 33 KV FULSAWANGI

Feeder No / Name : 202 / 11 KV Korta

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.7964	.7011		.5258	.4755	.5609
2	.3982	.7964	.7011		.5258	.5121	.5609
3	.362	.8326	.7011		.5609	.5121	.5258
4	.3982	.8326	.7362		.5609	.5121	.5609
5	.4344	.8326	.8063		.5609	.5487	.5258
6	.4706	.8145	.8589		.6135	.5487	.5609
7	.4344	.7964	1.0517			.6401	.5959
8	.4525	.7421	1.0517		1.0867	.5487	.5258
9	.4706	.7602	.7421		1.1218	.4572	.4733
10		.5068	.929		.7186		.4382
11		.8869	.4382		.8145		.4344
12	.6335	.8764	.362	1.1568	1.0679	.3155	
13		.9465		1.1218	.3077	.4706	.3982
14				1.0517	.8507	.5249	.4525
15	.362	1.0136		1.0692	.4525	.5611	.4163
16	.5121	1.0679		.631	.543	.543	
17	.724	1.1222	1.267		1.3575	.5792	
18		.362	1.267		.4706	.6485	.362
19	.7011	1.0166	1.3394	1.0166	.6516	.5784	.7059
20	.7602	.8962	1.1222	.9465	.6219	.6485	.6485
21	.7964	.8402	.905	.8238	.6154	.6485	.6516
22	.724	.7537	.724	.7712	.5853	.6516	.6154
23		.7362	.5611	.7712	.5487	.5959	.6335
24	.362	.7964	.7011		.5258	.4755	.5609
Max	.7964	1.1222	1.3394	1.1568	1.3575	.6516	.7059
Min	.362	.362	.362	.631	.3077	.3155	.362
Avg	.5199	.8272	.8483	.9360	.6821	.5453	.5337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304030 / 33 KV FULSAWANGI

Feeder No / Name : 203 / 11 KV Nignoor

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.724	.8413		.7011	.543	.5258
2	.543	.724	.8413		.7011	.5853	.5609
3	.5068	.7602	.8238		.7602	.5853	.5258
4	.543	.7602	.8688		.7712	.6219	.5609
5	.5611	.7964	.8589		.8326	.6335	.5959
6	.5792	.8326	.8764		.8413	.6584	.7011
7	.7421	.7964	1.2971			.7522	.7712
8	.7602	.9412	1.4198		.8764	.7316	.6836
9	.7964	.905			.929	.6584	.5784
10	.7421	.905	1.4548		.929	.5121	.4557
11	.9412	1.1946	1.4723		.905		.5068
12	.9412	1.1218	1.2127	1.4548	.6516	.4733	.5249
13	.9694		1.3937	1.4373	1.0679	.4525	.5068
14	.9774	1.4661	1.4118	1.2445	.8688	.4706	.5249
15	1.0029	1.3756	.905	1.1568	1.0136	.4887	.5249
16	1.0029	1.6108	1.5384	1.0517		.4887	
17	1.1765	1.5384		1.3496	.9774	.5434	
18	.6485	1.4299				.631	.6516
19	.8779	1.3847	1.1584	1.2269	.543	.6661	.6335
20	.905	.0905	1.1765		.5487	.6661	.6089
21	.9412	1.1041	1.086	.7186	.5853	.6485	.6154
22	.905	1.0166	1.1222	.7011	.5731	.6516	.5792
23		.9465	.9412	.7011	.5373	.5959	.5792
24	.543	.724	1.2127		1.0679	.5373	.5609
Max	1.1765	1.6108	1.5384	1.4548	1.0679	.7522	.7712
Min	.5068	.0905	.8238	.7011	.5373	.4525	.4557
Avg	.7875	1.0065	1.1387	1.1042	.7944	.5911	.5807

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304030 / 33 KV FULSAWANGI

Feeder No / Name : 204 / 11 KV RAHUR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3258	.3506		.3506	.4024	.3681
2	.3258	.3258	.3155		.3155	.4207	.3506
3	.3077	.3258	.3506		.3155	.4207	.3681
4	.3258	.362	.3155		.3506	.4119	.3506
5	.362	.3982	.3506		.3856	.439	.3982
6	.3801	.3982	.4031		.3856	.4344	.4382
7	.3801	.3258	.4733			.4024	.4908
8	.362	.4163	.4733		.3856	.3292	.4031
9	.2715	.3258	.4525		.3506	.2195	.333
10			.3681		.3155	.1463	.2804
11	.2715	.362	.3506		.3982		.2353
12	.2896	.4382	.3982	.3155		.298	.2172
13	.2658	.4382	.4344	.3155		.2715	.2715
14		.4525		.2804	.3439	.2896	.2715
15	.2743	.5068		.3506	.4525		.3258
16	.2896	.543	.5249	.3155	.4706	.2896	
17	.3258	.543	.543	.333	.5068	.362	
18	.4024	.4706	.543		.3801	.3506	.3982
19	.4207	.5258	.4344	.298	.4525	.6661	.5068
20	.362	.4344	.4344	.4207	.4572	.3681	.4572
21	.3801	.4344	.4525	.3801	.439	.3506	.3982
22	.3258	.4031	.362	.362	.439	.362	.4344
23		.3856	.3439	.3506	.4024	.3506	.362
24	.3258	.362	.3506		.3506	.4024	.3506
Max	.4207	.543	.543	.4207	.5068	.6661	.5068
Min	.2658	.3258	.3155	.2804	.3155	.1463	.2172
Avg	.3312	.4132	.4102	.3384	.3928	.3631	.3641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304030 / 33 KV FULSAWANGI

Feeder No / Name : 205 / 11 KV KALI TEMBHI FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	1.2803	1.0166	1.0136	.9114	.9511	.964
2	.8688	1.3032	.9991	1.0679	.9465	.9412	.964
3	.905	1.3535	1.0166	.9955	1.0136	.9694	.964
4	.9412	1.3535	.9991	.9774	.9816	.9774	.9465
5	1.0498	1.448	1.0517	1.086	1.086	.9774	.9816
6	1.1041	1.4815	1.0867	1.1584	1.1919	.9877	.9991
7	.9593	1.2986	1.262	1.1946		.9511	1.0166
8	.9774	.8596	1.4373	.9593	1.4548	.9877	.9816
9	1.0136	.7712	1.2127		.9816	.9877	.964
10		1.3321	1.2971	1.4118	1.4899	.8413	.7888
11		1.6476	1.4373	1.5203	1.5746		
12	.7783	1.6126	.3982	.8764	1.7013	.7964	.7421
13	1.134	1.4723	1.647	.8764	.5611		
14	1.0517	1.7556	1.0136	.8764	1.6832		.7964
15	1.0679	1.7737		1.4373			.8507
16	1.262	1.6651	1.7013	1.0517	.905		
17	1.2269	1.8099		1.6651	1.7013		
18	1.5181				1.267		
19	.9465	1.0517			1.086	1.1218	.5611
20	1.1765	1.2308	1.3394	1.3672		1.1043	.9328
21	1.2127	1.1765	1.267	1.2269	1.0974	1.0867	1.0136
22	1.1041	1.0517	1.086	1.1568	1.0498	1.086	.905
23		1.0517	1.0498	1.1568	1.0387	1.0166	.8145
24	.8688	1.2803	1.0166	1.6476	.8764	.9511	.9816
Max	1.5181	1.8099	1.7013	1.6651	1.7013	1.1218	1.0166
Min	.7783	.7712	.3982	.8764	.5611	.7964	.5611
Avg	1.0510	1.3505	1.1668	1.1773	1.1714	.9844	.9036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304050 / KALI (DAULATKHAN)

Feeder No / Name : 201 / 11 KV Kali AG KALI(DK) Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.583				.2058
2	.3429					.1715
3	.3429	.583				
4	.4115					
5	.4115	.6516				
6	.5144	.7202				
7	.6344	.823				
8	.6859	1.046				.1029
9	.6344	1.046				.1029
10		.9431	.8573	.7888	.2229	.1372
12		.8402	.9602			
13				.8916	.2401	
14		.8573	.7888			
15				.7545	.2229	
16		.8916	.6859	.7716		
17				.823	.2572	
18		.8916	.583			
24						.2058
Max	.6859	1.046	.9602	.8916	.2572	.2058
Min	.3429	.583	.583	.7545	.2229	.1029
Avg	.4801	.8231	.7750	.8059	.2358	.1544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304050 / KALI (DAULATKHAN)

Feeder No / Name : 202 / KALI GAOTHAN KALI(DK) Gaothan Feeder  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.1434	2.0576	1.8861	1.8861	1.749
2	1.8861	2.1434	2.0576	1.8861	1.8861	1.7147
3	1.8861	2.1434	2.0576	1.8861	1.8861	1.7318
4	1.9204	2.1434	2.0919	1.8861	2.0576	1.8861
5	2.0233	2.1948	2.1948	1.989	2.4006	2.0576
6	2.0233	2.4348	2.2634	2.2634	2.7435	2.3834
7	2.5206	2.7435	2.332	2.6063	2.915	2.7435
8	2.3148	2.1091	2.5549	2.4348	2.2291	2.5034
9	1.9376	2.0233	2.1434	2.0919	1.989	
10	1.3717	1.8004	1.3889	1.2689	1.2003	
11	1.1831	1.7147	1.1145	1.0974	1.1317	
12	1.0974	1.4232	1.1317	.9602	1.1317	
13	1.1317	1.3203	1.0974	1.0288	1.0631	
14	.6344	1.4918	1.166	1.0288	1.0631	
15	1.4575	1.7833		1.0288	1.2003	
16	1.9204	1.8861	1.166	1.0288	1.2003	
17	1.8519	1.9719	1.5432	1.2689	1.4403	
18	2.0233	2.1948	2.2977	1.9204	2.3148	
19	2.4348	2.5034	2.7435	.0154		
20	2.4006	2.4348	2.2977	2.5034	2.1605	
21	2.1434	2.3663	1.749	1.989	1.9547	
22	2.1091	2.1091	1.7833	2.2291	1.9204	
23	2.1434	2.0233	1.989	2.2291	1.8861	
24	1.9033	2.1434	2.0748	1.8861	2.2291	1.8519
Max	2.5206	2.7435	2.7435	2.6063	2.915	2.7435
Min	.6344	1.3203	1.0974	.0154	1.0631	1.7147
Avg	1.8418	2.0519	1.8824	1.6839	1.8213	2.0690

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304059 / ANANTWADI S/S

Feeder No / Name : 201 / HIWARA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.4115	.6097	.0152	.0152	.0152	.0152
2	.3201	.4115	.5792	.0152	.0152	.0152	.0152
3	.3658	.3658	.5335	.0152	.0152	.0152	.0152
4	.4115	.3963	.5792	.0152	.0152	.0152	.0152
5	.4572	.4572	.5792	.0152	.0152	.0152	.0152
6	.4725	.5487	.5792	.0152	.0152	.0152	.0152
7	.5944	.6097	.7621	.0152	.0152	.0152	.0152
8	.7011	.7773	.9145	.0152	.0152	.0152	
9	.7011	.8078	.9755	.0152	.0152	.0152	
10	.0152	.0152	1.0059	.8383		.0305	
11	.0152	.0152	1.0669	.7926			.0152
12	.0152	.0152	.9907	.884	1.0517		.0152
13	.0152	.0305	.884	.9755	1.0517		.0152
14	.0152	.0152	.9755	.9297	1.0059		.0152
15	.0152		1.0517	.884	.9755		.0152
16	.0152	.0152	.9907	.8535	.9755	.3048	.0152
17	.0152	.0152	.9602		.9755	.2743	
18	.0152	.0152	.0152	.0152	.0152	.2743	.0152
19	.0152	.0152	.0152	.0152	.0152	.2134	.0152
20	.0152	.0152	.0152	.0152	.0152	.0152	.0152
21	.0152	.0152	.0152	.0152	.0152	.0152	.0152
22	.0152	.0152	.0152	.0152	.0152	.0152	.0152
23	.0152	.0152	.0152	.0152	.0152	.0152	.0152
24		.4115	.6097	.0152		.0152	.0152
Max	.7011	.8078	1.0669	.9755	1.0517	.3048	.0152
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.1981	.2352	.6141	.2783	.2983	.0690	.0152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526]

BU 5266

Substation No/ Name :- 304059 / ANANTWADI S/S

Feeder No / Name : 202 / 11 KV HIWARA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6516	.6859	.6687	.6516	.6173	.6173
2	.6859	.6516	.6516	.6516	.6516	.5487	.6173
3	.6859	.6173	.6516	.6516	.6859	.5144	.583
4	.7202	.6173	.6516	.6859	.6859	.5487	.583
5	.7545	.6859	.6516	.7202	.7202	.6173	.583
6	.7888	.7202	.6516	.7888	.7545	.6859	.7202
7	.7202	.7202	.7545	.7888	.7202	.6859	.7545
8	.6516	.7202	.6859	.7545	.6859	.6859	.7545
9	.5144	.6516	.6516	.583	.5144	.583	.583
10	.4801	.4801	.4801	.4801		.4115	.4115
11	.3772	.4801	.3772	.3963		.3429	.3086
12	.4115	.4801		.4115	.3772	.3429	.3429
13	.4115	.4801	.4115	.3772	.3772	.3429	.3429
14	.4458	.4801	.4115	.4115	.3772		.3772
15		.5487	.4458	.4458	.4115		
16	.4801	.5487	.4115	.4801	.4115	.3772	
17	.4801	.583	.4801	.4801	.4115	.4115	
18	.4458	.6516	.7202	.6173	.6516	.6173	.6516
19	.6859	.7545	.7545	.7545	.6859	.7545	.6859
20	.7545	.7545	.7545	.7888	.7202	.6859	.7202
21	.6859	.7545	.7202	.7373	.7202	.6516	.6859
22	.6859	.7202	.7202	.6859	.6173	.6859	.6516
23	.6859	.6859	.6859	.6516	.6173	.6173	.6516
24		.6516	.6859	.6516		.6173	.6173
Max	.7888	.7545	.7545	.7888	.7545	.7545	.7545
Min	.3772	.4801	.3772	.3772	.3772	.3429	.3086
Avg	.6017	.6287	.6128	.6109	.5928	.5612	.583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304059 / ANANTWADI S/S

Feeder No / Name : 203 / 11 KV POHANDUL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.9259	.8916	.9259	.8059	.583	.583
2	.9774	.9259	.8573	.8916	.8402	.5658	.583
3	.9774	.9431	.8573	.8573	.8745	.5487	.5658
4	.9945	.9431	.8402	.8573	.8916	.583	.5658
5	1.0117	.9602	.8573	.8916	.9259	.6173	.583
6	1.0288	.9602	1.0117	1.046	.9602	.6516	.7716
7	1.0974	1.2003	1.3203	1.166	1.166	.5658	.7202
8	1.166	1.286	1.5947	1.0974	1.3717	.5487	.7202
9	1.2003	1.4918	1.6632	1.2689	1.2346	.4973	.6001
10	1.2003	1.3889	1.4575	.6344		.4973	.4458
11	1.0802	1.286	1.1831	.6859		.4458	.4115
12	1.166	1.1145	.6001	.7202	.6001		.3944
13	1.2517	1.2003	1.2689	.7545	.8745		.2915
14		1.4403	1.2689	.7202	.9431	.463	.4458
15	1.2517	1.4575	1.2003	.703	.9945		.2572
16	1.4403		1.286	.703	.9259	.4973	.5316
17	1.3717	1.6289	1.3889		.9259	.5144	
18	1.3203	.9602	1.4575	1.2346	.8916	.6344	.6859
19	1.2193	1.2346	1.4575	1.2517		.6516	.6344
20	1.3717	1.0631	1.2174	1.1488		.6687	.703
21	1.0288	1.0117	1.1488	1.046	.7716	.6516	.6687
22	.9259	.9602	1.0631	.823	.6173	.6173	.6516
23	.9259	.8916	.9945	.8573	.6173	.6173	.6173
24		.9259	.8916	.8059		.583	.6001
Max	1.4403	1.6289	1.6632	1.2689	1.3717	.6687	.7716
Min	.9259	.8916	.6001	.6344	.6001	.4458	.2572
Avg	1.1357	1.1391	1.1574	.9170	.9070	.5716	.5666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304059 / ANANTWADI S/S

Feeder No / Name : 204 / 11 KV KASARBHEL Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3963	.4877			
2	.2134	.3963	.4877			
3	.2134	.4115	.4877			
4	.2439	.4115	.4877			
5	.2591	.4268	.4725			
6	.2743	.442	.4877			
7	.3353	.5335	.6097			
8	.4268	.6097	.6859			
9	.3658	.5792	.7316			
10			.6859	.5487		.2591
11			.6554	.6097		.2591
12			.6097	.6554	.7621	.2439
13			.7621	.7468	.7621	.2439
14			.7468	.7316	.7468	.1981
15			.6554	.7011	.6706	
16			.6859	.6859	.6706	.1829
17			.6706	.6097	.6706	.1524
24		.3963	.4877			
Max	.4268	.6097	.7621	.7468	.7621	.2591
Min	.2134	.3963	.4725	.5487	.6706	.1524
Avg	.2915	.4603	.6054	.6611	.7138	.2199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304067 / 33 kv MUDANA

Feeder No / Name : 201 / 11 kv MUDANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	.5201	.4161	.5609	.4854	.4508	.4334
2	.4733	.4854	.3988	.5258	.4681	.4508	.4508
3	.4733	.4681	.3988	.5083	.4681	.4334	.4334
4	.5083	.4681	.4161	.5258		.4334	.4334
5	.5784	.4334	.4334	.5784	.5201	.4334	.4508
6	.6485	.6241	.6241	.6661	.5895	.5201	.5548
7	.5609	.7108	.8322	.8589	.7108	.5028	.5721
8	.5083	.7975	1.0923	1.0166	.8322	.5028	.4681
9	.7373	.9362	1.0229	.9465	.9114	.3641	.4334
10	.7716	.964	.9536	.929	.8764	.3641	.3988
11	.7455	.964	1.0402	.9362	.8764		.3641
12	.7802	.9465	1.0749	.9015	.8413		.3467
13	.8149	1.0166	.8669	.8842	.8063	.3467	.3294
14	.8322	.6661	.8842	.7975		.3467	.3641
15	.8149	.9015	.8842		.6836	.3814	.3467
16	.8495	.9259	1.0166	.7108	.6588	.4161	.3467
17	.8669	.8573	1.0166	.7108	.7282	.4161	
18	.7975	.8149	.8764	.8149	.5548	.5548	.4334
19	.6588	.6859		.7455	.5721	.5201	.5375
20	.6241	.5487		.5895	.5201	.5201	.5028
21	.5375	.5201		.5201	.4508	.5201	.4681
22	.5434	.4287		.5201	.4508	.4854	.4681
23	.5258	.4287	.631	.5028	.4508	.4681	.4508
24	.5083	.5258	.4161	.6135	.4854	.4508	.4508
Max	.8669	1.0166	1.0923	1.0166	.9114	.5548	.5721
Min	.4733	.4287	.3988	.5028	.4508	.3467	.3294
Avg	.6514	.6933	.7648	.7115	.6337	.4492	.4364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304067 / 33 kv MUDANA

Feeder No / Name : 202 / 11 KV BIJORA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3681	.3467	.4334	.298	.2254
2	.3681	.3814	.4334	.298	.1907
3	.3506	.3814	.4334	.2804	.156
4	.3681	.3814	.4508	.2629	.156
5	.3856	.3988	.4681	.298	.1734
6	.4031	.5375	.5201	.333	.1734
7	.5083	.6415	.6588	.4382	.1387
8	.4733	.6068	.6762	.5434	.1734
9	.4801	.5895	.7628	.5434	.1402
10	.4973	.6661	.7628	.4557	.1227
11	.5201	.7011	.7282	.4854	.0701
12	.4681	.7186	.7108	.4681	
13	.5028	.3856		.5548	
14	.5201	.6485		.4681	
15	.5375	.7455			
16	.1387	.7888		.4161	
17	.4508	.7888	.7537	.5375	
18	.5895	.7802	.7362	.5375	
19	.5548	.6859		.4854	
20	.5201	.5316		.3121	
21	.4334	.5028		.2947	
22	.4382	.4801		.2774	
23	.3856	.4458	.333	.2774	
24	.3856	.3506	.4508	.3155	.2601
Max	.5895	.7888	.7628	.5548	.2601
Min	.1387	.3467	.333	.2629	.0701
Avg	.4437	.5619	.5820	.3992	.1650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304067 / 33 kv MUDANA

Feeder No / Name : 203 / 11 KV KOTHARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.6588	.6588	.6135	.5895	.7975	.7802
2	.4908	.6241	.6762	.5959	.6068	.7975	.7802
3	.4733	.6588	.6415	.5784	.6241	.7282	.7628
4	.4908	.6588	.6415	.5609	.5895	.6935	.7802
5	.4908	.6588	.6415	.5784	.5721	.6935	.7628
6	.4908	.7108	.6935	.5959	.5721	.8322	.8322
7	.5609	.8149	.7628	.6135	.4854	.9015	.8322
8	.5434	.8669	.8322	.7712	.4681	.8322	.8149
9	.5487	1.0576	.9536	.7712	.4031	.6415	.7108
10	.583	.7011	.8669	.8063	.3155	.5375	.5201
11	.6762	.9816	.9015	.8149	.2804		.4508
12	.7108	1.0517	.9536	.8495	.298		.3814
13	.4681	1.1744	.9362		.298	.4334	.4161
14	.5895	1.1744	.9189			.4334	.4334
15	.6068	1.1789	.8842		.3155	.4854	.4334
16	.8149	1.166	.9465		.3121	.5028	.4508
17	.7628	1.0288		1.1096	.3814	.5028	
18	.8669	.9709	.9114	.9882	.6935	.6935	.6241
19	.8842	.8916		.8669	.7108	.7975	.8322
20	.8322	.7545		.7108	.7282	.8669	.7975
21	.7975	.7628		.7108	.7282	.9015	.8495
22	.8063	.7373		.6588	.6588	.8842	
23	.7362	.6859	.6485	.6588	.6241	.8669	.8322
24	.5434	.7011	.6762	.6135	.6241	.7975	.8149
Max	.8842	1.1789	.9536	1.1096	.7282	.9015	.8495
Min	.4681	.6241	.6415	.5609	.2804	.4334	.3814
Avg	.6358	.8613	.7971	.7234	.5165	.7100	.6769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304076 / 33 KV BHAVANI S/S

Feeder No / Name : 201 / 11 KV CHIKHALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3772	.3258	.3086	.2915	.3086	.3086
2	.3239	.3944	.3048	.3086	.3086	.3258	.3086
3	.3048	.3772	.3048	.3086	.3086	.3429	.2915
4	.3048	.3772	.3048	.3086	.3429	.3429	.2915
5	.3045	.3944	.3048	.3258	.3429	.3601	.2915
6	.298	.3601	.3403	.3772	.3944	.3429	.2915
7	.3086	.3772	.4733	.4458	.4287	.3086	.3086
8	.3086	.4763	.5335	.4973	.5182	.2915	.3086
9	.3429	.4001	.5335	.5144	.5344	.2229	.2915
10	.2134	.2214	.3048	.2229	.3239	.1334	.2229
11	.3887	.381	.463				.1791
12	.3963	.3963	.5658		.3944	.2058	.2096
13	.3688	.3963	.5316	.3761	.4115	.2401	
14	.3353	.426	.5144		.3944	.2743	
15	.4287	.57	.5144		.3944	.3086	
16	.4458	.6036	.4287	.394	.4458	.3258	
17	.4801		.5144	.5335	.4572	.3601	.1715
18	.463	.4191	.5316	.5487		.3772	.3239
19	.4706	.4191	.5487	.5068	.3772	.4287	.362
20	.4887	.4191	.4973		.3086	.3772	.3429
21	.5335	.4706	.463	.3772	.3086	.3601	.362
22	.4287	.394	.4287	.3429	.3258	.3429	.3429
23	.4287	.394	.3601	.2915	.3258	.3258	.3429
24	.3429	.4115	.3506	.3429	.2915	.3086	.3086
Max	.5335	.6036	.5658	.5487	.5344	.4287	.362
Min	.2134	.2214	.3048	.2229	.2915	.1334	.1715
Avg	.3764	.4111	.4351	.3859	.3741	.3137	.2930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304076 / 33 KV BHAVANI S/S

Feeder No / Name : 203 / 11 KV WALTUR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.4115	.3048	.2915	.3429	.2858	.3429
2	.2477	.4287	.3048	.2915	.3429	.3086	.3258
3	.2667	.3429	.0286	.2915	.3772	.3772	.3258
4	.2667	.5144	.3239	.3086	.4207	.4115	.3258
5	.2858	.5487	.4001	.3772	.4525	.4287	.3258
6	.3048	.583	.4954	.463	.4938	.4287	.3429
7	.3048	.583	.4954	.5487	.5175	1.6632	.3601
8	.3239	.7865	.5335	.6001	.6653	.4115	.3601
9	.2896	.8048	.5525	.6173	.6283	.439	.1543
10	.3077	.2587	.4572	.4458	.543	.4163	.2229
11	.4607	.6226	.7202				.2477
12	.5138	.6226	.7545		.6344		.2667
13	.5194	.583	.6001	.6401	.6516	.463	.4001
14	.5552	.6226	.5316		.6859	.4973	.0953
15	.5316	.6539	.6687			.4801	.3048
16	.5658	.3688	.7202	.4477	.4115	.5487	.381
17	.2629	1.326	.7888	.6219	.7701	.6344	.2096
18	.3944	.407	.2915	.2667	.7373	.2572	.3048
19	.3429	.4763	.4458	.3429	.5487	.3086	.2667
20	.3239	.3239	.3429		.2286	.3086	.3048
21	.2858	.381	.3429	.3429	.2477	.2743	.2858
22	.3048	.381	.3086	.3772	.2477	.2572	.3048
23	.3429	.3429	.2572	.3429	.2286	.2401	.2667
24	.2286	.381	.3048	.2743	.3601	.2286	.3429
Max	.5658	1.326	.7888	.6401	.7701	1.6632	.4001
Min	.2286	.2587	.0286	.2667	.2286	.2286	.0953
Avg	.3525	.5315	.4573	.4154	.4789	.4395	.2945



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304093 / 33 KV SAWANA

Feeder No / Name : 201 / VENI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0452	.0301	.0301	.4214	.602	.2709	.1505
2	.0452	.0301	.0452	.3311	.6321	.2709	.1505
3	.0452	.0301	.0452	.4214	.6622	.301	.1505
4				.4214	.6622	.301	
5				.3913	.6321	.301	
6				.4515	.602	.301	.1505
7				.4214	.6171	.301	.1505
8				.3763	.7375		.1505
9				.3913	.7827		.1505
10	.301	.6171					.1505
11	.4214	.8429					.1505
12	.6171	.9482					.2107
13	.602	1.0084					.1957
14	.6171	.9181					.1806
15	.7074	.9332					.1806
16	.7074	.8429	.0301	.0151	.0377	.0301	.1957
17	.5268	.9783		.0301	.0301	.0301	.1806
18	.0301	.0301		.0301	.0301	.0301	.0452
19	.0301	.0301		.0301	.0301	.0301	.0301
20	.0301	.0301		.0301	.0301	.0301	.0301
21	.0301	.0301		.0301	.0301	.0301	.0301
22	.0301	.0301	.0301	.0301	.0301	.0301	.0301
23	.0301	.0301	.0301	.0301	.0301	.0301	.0301
24	.0452	.0301	.0301	.301	.4515	.2709	.1505
Max	.7074	1.0084	.0452	.4515	.7827	.301	.2107
Min	.0301	.0301	.0301	.0151	.0301	.0301	.0301
Avg	.2701	.4106	.0344	.2308	.3683	.1599	.1293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304093 / 33 KV SAWANA

Feeder No / Name : 202 / SAWANA VILLAGE

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.7922	.8676	.7167	.7545	.679	.7545
2	.8299	.7733	.811	.679	.811	.679	.811
3	.8676	.7545	.811	.6602	.7545	.679	.9431
4	.9054	.8865	.9431	.6602	.7922	.7545	1.0374
5	.9808	1.0562	1.0562	.7922	.9431	.9054	
6	.9054	1.1317	1.094	.9054	1.094	1.0562	
7	1.0374	1.1317	1.1317	.9808	1.0562	1.1883	
8	.9997	1.094	1.0374	1.0185	1.1694	1.1317	
9	.9431	.9619	1.0185	.9431	1.094	.679	
10	.7922	.8488	.811	.8299	.8865		
11	.6979	.7733	.6413	.5847	.5658		
12	.6036	.7356	.547	.5281	.5093	.679	
13	.5658	.6979	.5281	.5093	.4904	.5281	
14	.5847	.7733	.4904	.547	.4904	.5093	
15	.5847	.7545	.4527	.5658	.5281	.5093	
16	.6224	.9431	.679	.6413	.547	.5658	
17	.679	.9808	.9431	.6224	.6224	.5847	
18	.8865	.9808	1.094	.8865		.9619	.8676
19	.9808	1.0185	1.0751	1.0185		.9054	.9619
20	.9619	1.0185	1.0751	.9431		.8676	.8676
21	1.0185	.9619	.8676	.8299	.8299	.811	.7545
22	.9431	.9431	.8299	.811	.6036	.7733	.7922
23	.8488	.9431	.8676	.8488	.7167	.7545	.7922
24	.8299	.8299	.9054	.7545	.7922	.7167	.7167
Max	1.0374	1.1317	1.1317	1.0185	1.1694	1.1883	1.0374
Min	.5658	.6979	.4527	.5093	.4904	.5093	.7167
Avg	.8307	.9077	.8574	.7615	.7643	.7690	.8453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

MAHAGAON S/DN.[526] BU 5266

Substation No/ Name :- 304093 / 33 KV SAWANA

Feeder No / Name : 203 / WAKODI AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4401	.5575	.5281	.0293	.0293	.0293	.0293
2	.4548	.5868	.5281	.0293	.0293	.0293	.0293
3	.4841	.5868			.0293	.0293	.0293
4	.4401	.6161					
5	.4254	.5868					
6	.4108	.5575					
7	.4401	.7042					
8	.4841	.7482					
9	.4841	.6895					
10			.5281	.8215	.6161		
11			.7335	.9829	.8215		
12				1.0562	.9242		
13				1.0269	.8069	.3814	
14				1.0122	.8949	.3521	
15				1.1296	.8655	.3814	
16	.0587	.0587		1.1149	.9682	.4108	.0293
17	.0293	.0587		1.0269	.9976	.3521	
18	.044	.0587		.0293	.0293	.0147	
19	.0587	.0587		.0293	.0293	.0151	.0293
20	.044	.0587		.0293	.0293	.0147	
21	.044	.0587		.0293	.0293	.0147	.0151
22	.044	.0587		.0293	.0293	.0147	.0301
23	.044	.0587		.0293	.0293	.0147	.0301
24	.4108	.5281	.4988	.0293	.0293	.0293	.0293
Max	.4841	.7482	.7335	1.1296	.9976	.4108	.0301
Min	.0293	.0587	.4988	.0293	.0293	.0147	.0151
Avg	.2690	.3684	.5633	.4962	.3993	.1389	.0279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304011 / 33 KV SAWARGAONGORE

Feeder No / Name : 201 / 11 KV Shembalpimpri Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.2477	.1524	.1524	.1372		.1509
2	.12	.2477	.1524	.1524	.1372		.1509
3	.12	.3239	.1509	.1867	.1372		.1509
4	.12	.3239	.1886	.2218	.1372		.1509
5	.12	.3239	.1886	.2218	.2058		.1886
6	.1715	.3429	.2263	.1494	.2572		.2263
7	.1715	.362	.3395	.2241	.2058		.2263
8	.1372	.3239	.2641	.1829	.2058		.1698
9		.362	.2263	.2896	.2058		.1509
10	.1905	.362	.2641		.2058		.1509
11	.1886	.4191	.2667	.3429	.2477		
12	.2075	.381		.3429	.2477	.1905	
13	.2427	.3429		.4115	.2477	.1905	
14	.2801	.4191	.1524	.4115	.2477	.1524	
15	.2667	.3429	.3048		.3048		
16	.3239	.381	.4572		.2477	.2286	
17	.2858	.3429	.381		.1905	.2263	.0914
18	.3239	.2286	.381	.2743	.2477	.2286	.1086
19	.4001	.2667	.2743	.1715	.1905	.1509	.1448
20	.381	.2286	.2058	.1372		.1698	.1433
21	.4001	.2667	.2058	.12		.1509	.1372
22	.4001	.2286	.2058	.1372		.1509	.0686
23	.5525	.2286	.2058			.1509	.0686
24	.1715	.4001	.1905	.1433	.1372		.1509
Max	.5525	.4191	.4572	.4115	.3048	.2286	.2263
Min	.12	.2286	.1509	.12	.1372	.1509	.0686
Avg	.2476	.3207	.2447	.2249	.2072	.1809	.1461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304011 / 33 KV SAWARGAONGORE

Feeder No / Name : 203 / 11 KV Water works

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1334	.1494	.2058	.1715		.1509
2	.2286	.1334	.1867	.2058	.1715		.1509
3	.2286	.1715	.1494	.1715	.1715		.1886
4	.2477	.1715	.2667	.2401	.1715		.1886
5	.2477	.2096	.2263	.2058	.1715		.1509
6	.2667	.1715	.2641	.1715	.2058		.1509
7	.2667	.1143	.2263	.2401	.2058		.1509
8	.3048	.1715	.1905	.2743	.2058		.1509
9		.1715	.2452	.2229	.2058		.1132
10	.2286	.2286	.3018		.2058		.1886
11	.2286	.1905	.2286	.2401	.2477		
12	.2477	.2096	.2286	.2401	.0953		
13	.2096	.1524	.1905	.1886	.1143		
14	.2096	.1524	.2286	.1886	.0953		
15	.2477	.1886	.1905	.1886	.1143	.1509	
16	.2477	.1494	.2477	.2058	.0572	.132	
17	.2477	.1494	.1886	.2401	.1143	.1509	.1715
18	.1905	.0934	.112	.2401		.1494	.1753
19	.2477	.112	.1524	.2401		.1867	.1791
20	.2477	.112	.1905	.2058		.1509	.1612
21	.1905	.0934	.1715	.1886		.2075	.1448
22	.2286	.112	.2096	.0857		.1509	.1463
23	.2477	.1494	.2096	.1029		.1886	.128
24	.2286	.2477	.1867	.2096	.1029		.1698
Max	.3048	.2477	.3018	.2743	.2477	.2075	.1886
Min	.1905	.0934	.112	.0857	.0572	.132	.1132
Avg	.2377	.1579	.2059	.2045	.1571	.1631	.1589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304028 / 33 KV GAUL

Feeder No / Name : 201 / 11 KV Shilona Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0686			
2		.0343	.0686			
3		.0343	.0686			
4		.0686	.0686			
5		.0686	.0686			
6		.0857	.0686			
7		.1029	.12			
8		.0514	.1372			
9	.0343	.1372	.1372			
10			.1372	.1372	.0343	
11			.12	.1715	.0857	.0343
12			.1029	.1886	.0857	.0514
13			.0857	.2058	.1029	.0343
14			.0857	.2058	.0857	.0514
15			.0857	.1886	.0514	.0514
16			.12	.2058	.0514	.1886
17			.1543	.1886	.0514	.12
24		.0514	.0514			
Max	.0343	.1372	.1543	.2058	.1029	.1886
Min	.0343	.0343	.0514	.1372	.0343	.0343
Avg	.0343	.0686	.0972	.1865	.0686	.0759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304028 / 33 KV GAUL

Feeder No / Name : 203 / GAUL GAWATHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058		.3086	.3258	.1715	.2572	.1715
2	.1886	.2229	.3086	.3429	.1886	.2229	.1715
3	.1715	.2401	.2572	.3601	.2058	.2401	.1715
4	.2058	.2743	.2572	.3601	.2229	.2572	.1715
5	.2401	.2915	.3086	.3772	.2572	.2915	.1715
6	.3429	.3086	.3429	.3772	.3086	.3429	.3258
7	.3429	.3601	.3772	.3772	.3429	.4115	.3944
8	.3772	.6001	.3944		.3772	.3429	.3086
9	.2743	.2572	.3086		.3086	.3086	.2915
10	.2058	.2058	.4287		.2743	.1886	.1372
11	.1715	.2058	.12	.1886	.2401	.1372	.0857
12	.1543	.2058	.12	.1543		.12	
13	.1372	.2058	.12	.1029	.12	.1029	
14	.1372	.2401	.12	.1372	.1029	.1372	
15	.1372	.2743	.1372	.1543	.1029	.1715	
16	.1886	.2915	.1543	.1543	.1543	.1715	
17	.1886	.2743	.2058	.1715	.1715	.2058	
18	.2915	.3086	.2572	.2058	.3601	.2401	.2572
19	.3601	.3429	.3772	.2572	.3258	.3772	.3086
20	.3944	.3601	.3258	.3258	.2915	.3429	
21	.3258	.2572	.2572	.2572	.2572	.2572	
22	.2401	.3429	.2229	.2401	.2229	.2229	.2229
23	.2229	.3429	.2058	.2229	.2229	.2058	.2058
24	.2229	.2058	.3429	.2229	.2058	.2401	.1715
Max	.3944	.6001	.4287	.3772	.3772	.4115	.3944
Min	.1372	.2058	.12	.1029	.1029	.1029	.0857
Avg	.2386	.2878	.2608	.2531	.2363	.2415	.2229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304028 / 33 KV GAUL

Feeder No / Name : 204 / SHILONA GAWTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.1715	.2572	.1715	.2743	.1715
2		.2229	.1715	.2401	.1886	.2572	.1715
3		.2743	.1715	.2058	.2058	.2401	.1715
4		.2915	.1715	.1715	.2229	.2915	.1715
5		.3086	.2572	.1886	.2572	.3258	.1715
6		.3258	.2915	.1715	.2572	.3601	.1715
7		.3772	.2743	.1715	.3086	.3772	.3086
8	.3258	.3429	.2572		.3429	.3601	.1886
9	.2572	.2915	.1715		.3086	.2401	.2058
10	.1715	.2229	.1886		.2058		.12
11	.1372	.2058	.1372	.1029	.12	.12	.12
12	.1543	.1715	.12	.1029	.12	.12	
13	.1543	.1715	.1372	.1029	.1029	.1029	
14	.1543	.1543	.1029	.12	.12	.1029	
15	.1543	.12	.1715	.1029	.1372	.0857	
16	.1715	.1372	.1886	.12	.12	.12	
17	.2058	.2572	.1886	.12	.1715	.1543	
18	.2915	.3086	.2743	.1372	.2915	.1543	.3429
19	.3429	.3086	.3429	.1715	.2915	.2572	.3601
20	.3601	.3086	.3258	.2229	.2743	.2229	.3258
21	.3086	.2058	.2401	.2401	.2572	.1886	.2743
22	.2572	.1886	.2572	.2229	.2401	.1715	.2572
23	.2401	.1715	.2401	.2058	.2401		.2229
24		.2229	.1715	.2401	.1886	.2572	.1715
Max	.3601	.3772	.3429	.2572	.3429	.3772	.3601
Min	.1372	.12	.1029	.1029	.1029	.0857	.12
Avg	.2304	.2429	.2093	.1723	.2143	.2175	.2182



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304028 / 33 KV GAUL

Feeder No / Name : 205 / SHELU GAWTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2229	.1524		.1886		.1715
2	.1543	.2401	.1715		.1543		.1715
3	.1372	.2229	.1715		.2058		.1715
4	.1715	.2743	.1715		.2229		.1715
5	.2058	.3086	.2572		.2401		.1715
6	.2229	.3258	.3086		.2743		.1715
7	.2572	.1886	.3086		.2915		.2229
8	.2743	.2743	.3086		.3429		.2058
9	.2229	.2743	.1886		.2743		.2058
10	.1715	.1543	.1715		.2401		.1543
11	.1543	.1543	.12	.1029	.2058	.12	.1029
12	.1372	.1543	.12	.0857	.1543	.12	
13		.1372	.0857	.0686	.1029	.12	
14		.1543	.1029	.0857	.1029	.12	
15	.12	.12	.12	.1029	.1029	.1029	
16	.12	.12	.0857	.12	.12	.12	
17	.1715	.2572	.12	.1543	.1715	.1715	
18	.2401	.2572	.2743	.1715	.2743	.2058	.1715
19	.2743	.2572	.4287	.2058	.2572	.2401	.2915
20	.2915	.2572	.2572	.2229	.2401	.2401	.1715
21	.2572	.1715	.1715	.2058	.2058	.2058	.2058
22	.2058	.1715	.1372	.2058	.1715	.1715	
23	.1886	.1715	.12	.1886	.1543	.1715	
24	.1886	.2058	.1715	.1372	.1715		.1715
Max	.2915	.3258	.4287	.2229	.3429	.2401	.2915
Min	.12	.12	.0857	.0686	.1029	.1029	.1029
Avg	.1972	.2115	.1885	.1470	.2029	.1622	.1833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304028 / 33 KV GAUL

Feeder No / Name : 206 / DONGARGAON WATER WORK EXP.

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	11-JUL-17
HR	Load (MW)
1	.1372
Max	.1372
Min	.1372
Avg	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304031 / 33 KV GHATODI

Feeder No / Name : 201 / 11 KV GHATODI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.7716	.6859	.6859
2	.8764	.7716	.7716	.6859
3	.8764	.7716	.7716	.6859
4	.8764	.7716	.7716	.6859
5	.8764	.7716	.8573	.6859
6	1.0402	.8573	.8573	.7545
7	1.286	.8573	.8573	.7888
8	1.2003	.8573	.6859	.8573
9	.9431			.8573
10	.4287	.5144	1.0288	1.0288
11		.5144	1.286	1.166
12		1.1145		1.166
13	.4115	1.3717	1.2003	
14	.6001	1.3717	1.2689	
15	.583	1.3717	.9602	
16	.7202	1.0288	.9945	
17	.8402	1.0288	1.0288	
18	.9259	.7716	.9431	.7202
19	.9602	.9431	.8916	.7545
20		1.0288	.8916	.7716
21	.9431	.9431	.8573	.823
22	.9431	.9431	.8573	.8573
23	.8916	.8573	.7716	.8573
24	.8764	.7716	.6859	.7716
Max	1.286	1.3717	1.286	1.166
Min	.4115	.5144	.6859	.6859
Avg	.8560	.9132	.9057	.8212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304031 / 33 KV GHATODI

Feeder No / Name : 202 / 11 kV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	10-JUL-17	11-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0876	.0857	.0343
2	.0876	.0857	.0343
3	.0876	.0857	.0343
4	.0876	.0857	.0343
5	.0876	.0857	.0343
6	.0867	.0857	.0343
7	.0857	.0857	.0343
8	.0857	.0857	.0686
9	.0857	.0857	.0857
10	.0857	.0857	.0857
11	.0857	.0857	.12
12	.1029	.0686	.12
13	.0857	.0686	.12
14	.1029	.1372	.12
15	.1029		.12
16	.1029	.0857	.1029
17	.0857	.0857	.1029
18	.0857	.0857	.0343
19	.0857	.0857	.0343
20	.0857	.0857	.0343
21	.0857	.0686	.0343
22	.0343	.0686	.0343
23		.0686	.0343
24	.0876	.0857	.0343
Max	.1029	.1372	.12
Min	.0343	.0686	.0343
Avg	.0870	.0842	.0636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304031 / 33 KV GHATODI

Feeder No / Name : 203 / 11 KV Warud

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609		.5144	.4287
2	.5609	.6001	.5144	.5144
3	.5609	.6001	.5144	.5144
4	.5609	.6173	.5144	.6001
5	.5609	.5487	.5144	.6001
6	.6068	.5144	.583	.6859
7	.6001	.6001	.6173	.5144
8	.6001	.5658	.6173	.5144
9	.5144	.583	.583	.4287
10	.3429	.4115	.4287	.5144
11	.3429	.4115	.4287	.5144
12	.3429	.4287	.5144	.5144
13	.3601	.4287	.5144	.5144
14	.3429	.3429	.5144	.5144
15	.3429	.3429	.5144	.4287
16	.4287	.3429	.6001	.4287
17	.463	.3429	.5144	.4287
18	.5144	.3429	.5144	.5144
19	.5487	.6001	.5144	.5144
20	.583	.6516	.5144	.6001
21	.6001	.6516	.5144	.6001
22	.583	.5144	.5144	.6001
23	.5658	.5144	.5144	.5144
24	.5609		.5144	.4287
Max	.6068	.6516	.6173	.6859
Min	.3429	.3429	.4287	.4287
Avg	.5020	.4980	.5251	.5180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304031 / 33 KV GHATODI

Feeder No / Name : 204 / 11 KV Moha

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.964	.8573	.9431	.6859
2	.964	.8573	.8573	.6859
3	.964	.8573	.8573	.6859
4	.964	.8573	1.0288	.6859
5	.964	.9431	1.0288	.7716
6	1.2136	1.1145	1.1145	.7716
7	1.3717	1.3032	1.2003	.8573
8	1.2003	1.3032	1.2003	.8573
9	.8573	.8573	1.1145	1.0288
10	.5144	.8573	.5144	.5144
11			.4287	.4801
12	.2572		.4287	.4801
13	.3258	.5144	.4287	
14	.3429	.5144		
15	.3601	.5144	.3429	
16	.5316	.6859	.3429	
17	.6344	.8573	.4287	
18	.9259	1.0288	.5144	.4287
19	1.0288	1.0288	.6859	.4801
20	1.2003	1.0288	.6859	.4458
21	.9945	1.0288	.6859	.9602
22	.9602	.9431	.6516	.9431
23	.9602	.8573	.6516	.9259
24	.964	.8573	.9431	.6859
Max	1.3717	1.3032	1.2003	1.0288
Min	.2572	.5144	.3429	.4287
Avg	.8462	.8940	.7425	.7039

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304031 / 33 KV GHATODI

Feeder No / Name : 205 / EXPRES FEEDER

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0343	.0343	.0343
2	.0351	.0343	.0343	.0343
3	.0351	.0343	.0343	.0343
4	.0351	.0343	.0343	.0343
5	.0351	.0343	.0343	.0343
6	.0347	.0343	.0343	.0343
7	.0343	.0343	.0343	.1715
8	.0343	.0343	.0343	.1715
9	.1715	.0343	.0343	.1715
10	.1715	.0343	.0343	.1715
11	.1715	.1715	.1715	.1715
12	.1715	.1715	.1715	.1715
13	.1372	.1715	.1715	.1715
14	.1715	.0343	.1715	.1715
15	.1715	.0343	.1715	.1715
16	.2058	.0343	.1715	.1715
17	.2229	.0343	.1715	.1715
18	.2572	.0343	.1715	.1715
19	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343
21	.0343	.0343	.0343	.0343
22	.0343	.0343	.0343	.0343
23	.0343	.0343	.0343	.0343
24	.0351	.0343	.0343	.0343
Max	.2572	.1715	.1715	.1715
Min	.0343	.0343	.0343	.0343
Avg	.0974	.0515	.0800	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304034 / 33 KV SHEMBALPIMPRI

Feeder No / Name : 201 / 11 KV Shembalpimpri

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3086	.3086	.3772
2	.4801	.3772	.2743	
3	.5144	.3429	.2743	
4	.5144	.3429	.3429	
5	.5487	.3429	.4115	
6	.5487	.3429	.5144	
7	.463	.3429	.583	
8	.3429	.2743	.5487	
9	.5487	.3429	.5144	
10	.4458	.5144	.4801	
11	.3429	.4458	.5144	
12	.3772	.4115	.4801	
13	.3429	.3086		
14	.3772	.3086	.3772	
15	.4115	.3429	.3429	
16	.3429	.3772		
17	.3429	.3429		
18	.3772	.2401	.3429	
19	.4115	.2743	.5487	
20	.3772	.2743	.4801	
21	.3429	.3086	.4115	
22	.3772	.2401	.3772	
23	.3772	.2743	.3429	
24	.4801		.3086	
Max	.5487	.5144	.583	.3772
Min	.3429	.2401	.2743	.3772
Avg	.4237	.3340	.4180	.3772



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304034 / 33 KV SHEMBALPIMPRI

Feeder No / Name : 203 / 11 KV Isapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.583	.6859	.6173
2	.583	.7202	.5487
3	.6173	.7888	.5487
4	.6173	.6173	.5487
5	.6516	.6516	.6173
6	.6516	.6687	.6516
7	.6173	.7202	.6859
8	.7202	.6859	.7545
9	.6859	.7202	.7888
10	.6516	.7545	.7202
11	.7545	.8573	.7545
12	.5144	.8916	1.0288
13	.7545	.9259	1.3032
14	.7202	.823	1.2346
15	.9945	.7202	1.3717
16	1.0288	.8573	1.3032
17	1.0631	.7888	1.2346
18	.9945	.6516	1.3032
19	.823	.5487	1.5089
20	.3772	.5144	1.4403
21	.3772	.5487	
22	.4115	.583	
23	.4115	.583	
24	.583	.6859	.6173
Max	1.0631	.9259	1.5089
Min	.3772	.5144	.5487
Avg	.6744	.7080	.9325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 304037 / 33 KV MARWADI

Feeder No / Name : 201 / 11 KV Belora

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	08-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
7	1.0029	1.4632	
9	.8779	1.0288	
14			.4801
17			.6859
18			1.0669
22			.8916
23			1.1431
Max	1.0029	1.4632	1.1431
Min	.8779	1.0288	.4801
Avg	.9404	1.246	.8535

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 304037 / 33 KV MARWADI

Feeder No / Name : 202 / 11 KV Sattarmal

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	08-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.6653	.9015	
9	.5014	.5365	
14			.3467
17			.4572
18			.6859
22			.7545
23			.7621
Max	.6653	.9015	.7621
Min	.5014	.5365	.3467
Avg	.5834	.719	.6013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 304037 / 33 KV MARWADI

Feeder No / Name : 203 / 11 kv Marwadi

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	08-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
7	.4481	.3734	
9	.3734	.3467	
13			.2713
17			.4572
18			.5335
22			.3429
23			.3048
Max	.4481	.3734	.5335
Min	.3734	.3467	.2713
Avg	.4108	.3601	.3819

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 304037 / 33 KV MARWADI

Feeder No / Name : 204 / 11 KV BELORA WW EX FEEDER

EHV Express Water works

Feeder KV- 11 / OUTGOING

DATE	14-JUL-17
HR	Load (MW)
17	.0191
18	.0191
22	.0171
23	.0191
Max	.0191
Min	.0171
Avg	.0186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304038 / 33 KV PUSAD TALAO

Feeder No / Name : 201 / 11 KV Itawa

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6297	1.7193	1.5432	1.6461	1.7924	1.6804	
2	1.5939	1.6834	1.6289	1.5089	1.6804	1.4937	
3	1.5939	1.6834	1.7147	1.5089	1.6057	1.4937	
4	1.6476	1.7193	1.8861	1.5775	1.6804	1.4937	
5	1.8983	1.7909	1.9719	1.8519	1.8671	1.7551	
6	2.2148	2.0376	2.1434	2.2291	2.0538	2.0538	2.1262
7	2.268	2.1971	2.2291	2.332	2.4272	2.4646	2.2148
8	2.1971	2.2325	2.2291	2.2634	2.4272	2.3899	2.1262
9	1.9845	2.1085	2.0919	2.0576	2.2405	1.9791	2.3034
10	1.7909	1.9845	1.8004		2.2405	1.8671	1.8099
11	1.7551	1.949	1.7147		1.8671		1.9004
12	1.6476	1.6289	1.7147	1.6804	1.7556		1.8099
13	1.6655	1.7147	1.5775	1.6804	1.6804		1.7556
14	1.6655	1.6289	1.5089		1.6057		1.448
15	1.6118	1.5432	1.3717	1.6804	1.587		
16	1.7193	1.6289	1.7147	1.7177	1.643		
17	1.8267	1.6804	1.8004	1.9418	1.7551		
18	1.949	1.8004	2.0576	2.1472	1.8671		1.773
19	2.0022	1.8861	2.0748	2.1472	2.0538		1.9521
20	2.1971	2.1434	2.1434	2.1285	2.2405		1.97
21	2.0553	2.0576	2.1434	2.0538	2.0538		1.8625
22	1.9667	1.7147	1.9204	1.9791	1.9791		1.7013
23	1.8604	1.6289	1.8519	1.8298	1.8671		1.6651
24		1.7909	1.5432	1.7147	1.7924	1.7551	
Max	2.268	2.2325	2.2291	2.332	2.4272	2.4646	2.3034
Min	1.5939	1.5432	1.3717	1.5089	1.587	1.4937	1.448
Avg	1.8583	1.8314	1.849	1.8894	1.9068	1.8569	1.8946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304047 / 33 KV KATKHEDA

Feeder No / Name : 201 / 11KV SAI BORI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4918	1.046	1.4403		.2058
2	1.4746	1.0288	1.3717		.2058
3	1.4746	1.1317	1.3203		.2058
4	1.286	1.1831	1.3717		.2058
5	1.2346	1.3717	1.4575		.2401
6	1.4918	1.6289	1.5604		.2572
7	1.8004	1.6461	1.6804		.2572
8	1.3889	1.5432	1.6118		.2572
9	1.1145	1.406	1.3717		
10	.8916	1.2346			
11	.8059	1.166	.8745	1.0117	
12	.8573	1.166	1.0974	1.0974	
13	.8916	1.1317	1.1317	.9774	
14		1.166	1.2003	.9602	
15		1.3546	1.2346	.9774	
16	1.2003	1.286	1.1488		
17	1.2346	1.4575	1.3203	1.0288	
18	1.4575	1.5261	1.4403		
19	1.6118	1.6975	1.6975		
20	1.5775	1.6804	1.6461		
21	1.6118	1.6975		.2401	
22	1.6461	1.6461	1.7918	.2058	
23	1.4746	1.5604	1.647	.2058	
24	1.5089	1.406	1.4918		.2058
Max	1.8004	1.6975	1.7918	1.0974	.2572
Min	.8059	1.0288	.8745	.2058	.2058
Avg	1.3421	1.3817	1.4049	.7450	.2267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304047 / 33 KV KATKHEDA

Feeder No / Name : 203 / 11KV MUNGASAJINAGAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	1.0631	.9259	.9431	.7202	.823
2	.8916	1.1145	1.0117	.9431	.6859	.823
3	.8916	1.1831	.9259	1.0288	.6859	.7888
4	.9088	1.3203	1.0288	1.046	.6859	.7888
5	.8745	1.3546	1.2174	1.1831	.7888	.8573
6	1.0117	1.3889	1.3546	1.286	.8916	1.0974
7	1.3032	1.406	1.3889	1.3203	.9945	1.2517
8	1.0974	1.5089	1.5261	1.4403	.9259	1.0974
9	.8916	1.3546	1.4232	1.1145		
10	.823	1.2346	1.2346	.8573		.7716
11	.7888	1.3032		.8059		.4801
12	.9602	1.3889	1.3717	.8573		.4801
13	.4801	1.406	1.4232	.8916		.5144
14	.8745	1.406	1.5089	.8573		.5487
15	.9259	1.4403	1.3375	.7716		.583
16	1.3203	1.4575	1.5432	1.1317		.7545
17	1.3546	1.4918	1.7661	1.1145		.7716
18	1.406	1.4232	1.2346	.823		.6859
19	1.5261	1.3203	1.4403	.823		.6516
20	1.2003	1.2346	1.3889	.7716		.8573
21	1.046	1.1145	1.3032	.7716		1.046
22	1.0288	1.0631	1.1831	.7716		.8745
23	1.0631	.9945	.9259	.7202		.8573
24	.8916	1.046	.9431	.8573	.7202	.823
Max	1.5261	1.5089	1.7661	1.4403	.9945	1.2517
Min	.4801	.9945	.9259	.7202	.6859	.4801
Avg	1.0181	1.2924	1.2786	.9638	.7888	.7925



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304055 / 33 KV CHONDHI

Feeder No / Name : 201 / 11KV GAHULI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.0171	.3944	.2401	.2572	.2401	.2572
2	.4458	.2915	.3944	.2572	.2572	.2401	.2572
3	.463	.2915	.4287	.2743	.2743	.2401	.2572
4	.4801	.2915	.463	.2915	.2915	.2401	.2572
5	.5144	.3086	.4973	.3086	.3086	.2572	.2915
6	.5487	.3429	.5144	.3258	.3086	.2572	.3086
7	.5487	.3429	.4801	.3086	.3086	.3258	.3086
8	.5144	.3601	.4115	.2915	.2743	.3258	.3086
9	.3944	.3429	.3086		.2229		.2743
10	.1029	.1715	.2229	.2743	.2572		.0686
11	.1029	.2058	.3429	.2743	.3086		
12	.12	.2401	.3772	.3086	.2572	.1372	
13	.1029	.2401	.4115	.3086	.2572	.1372	
14	.1029	.2401	.4287		.3601	.1543	
15	.1029	.2572	.4115		.2915		
16		.3258	.3944	.3429	.2915	.1886	
17	.0857	.3086	.463	.4115	.3944	.2229	
18	.12	.3258	.2229	.1715	.2743	.2743	
19	.2743	.3258		.2572	.2915		
20	.3086	.4115		.2572	.2915	.2401	
21	.3086	.463		.2572	.2915	.2401	
22	.3086	.463		.2572	.2572	.2401	
23	.3429	.4287	.2401	.2572	.2572	.2401	
24	.3944	.3086	.3944	.2401	.2572	.2572	.2572
Max	.5487	.463	.5144	.4115	.3944	.3258	.3086
Min	.0857	.0171	.2229	.1715	.2229	.1372	.0686
Avg	.3086	.3044	.3901	.2817	.2851	.2347	.2587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304055 / 33 KV CHONDHI

Feeder No / Name : 202 / 11KV PARADH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5144	.6516	.3601	.5144	.4287	.6001
2	.4801	.5144	.6687	.3601	.6001		.6001
3	.5144	.5144	.7202	.3772	.7716		.6001
4	.5487	.5144	.8059	.3944	.8573		.6001
5	.6001	.4801	.8573	.4115	.9088		.6859
6	.6516	.4287	.8573	.8574	.9431		.6859
7	.6687	.4115	.9945	.9665	.9259		.6001
8	.4458	.4115	1.0288	.9835	.8916		.4287
9	.2743	.4115	.823	1.0174	.3258		.3086
10	.5316	.6859	.1715	.3086			.2915
11	.5487	.6859	.1715	.1372			
12	.6001	.7202	.1715			.2572	
13	.4115	.6516	.1715			.2743	
14	.4287	.9431	.1715			.1715	
15	.4287	.9602	.1715			.3429	
16	.5487	.9088		.2915		.3601	
17	.583	.9259		.4115	.4287	.3772	
18	.2572	.4287	.463	.583		.4801	
19	.3601	.463		.583	.3772		
20	.3601	.583		.583	.4973	.5316	
21	.5144	.5658		.5658	.4801	.5144	
22	.5144	.5658		.5144	.463	.5144	
23	.5144	.5658	.5144	.5144	.4458	.5144	
24	.463	.5144	.6516	.3429	.5144	.4287	.6001
Max	.6687	.9602	1.0288	1.0174	.9431	.5316	.6859
Min	.2572	.4115	.1715	.1372	.3258	.1715	.2915
Avg	.4887	.5987	.5592	.5282	.6216	.3997	.5456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304055 / 33 KV CHONDHI

Feeder No / Name : 203 / 11 Kv Banshi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4287	.2743	.3772	.2572	.2572	.3086
2	.3258	.4287	.2743	.3772	.2572	.2572	.3086
3	.3429	.4287	.2401	.3944	.2743	.2572	.3429
4	.3601	.4287	.2401	.4115	.3086	.2743	.3429
5	.3772	.463	.2401	.4115	.3429	.2915	.3772
6	.3944	.5144	.2401	.4287	.3429	.2572	.3772
7	.3944	.5658	.3086	.3944	.3601	.2743	.3429
8	.4458	.5658	.2743	.3429	.3086	.2572	.2915
9	.4115	.5658	.2058	.3258	.2229		.2229
10	.0857	.1886	.463	.463	.4115	.1372	.1029
11	.0857	.2058	.5487	.5144	.4287	.12	
12	.12	.2058	.583	.5316		.1029	
13		.2058	.6516	.5316		.1029	
14	.1715	.1886	.6859		.3601		
15	.1715		.6173		.4115	.1372	
16	.12	.2572	.583	.4458	.4115	.2058	
17	.2058	.2743	.583	.4801	.3772	.2401	
18	.1715	.2915	.2743	.2915		.2743	
19	.3601	.3086		.3086			
20	.463	.3258		.3086		.2572	
21	.4287	.3086		.2743	.3086	.2572	
22	.3944	.3086		.2743	.3086	.2572	
23	.4115	.3086	.3772	.2572	.2915	.2572	
24	.3086	.4287	.2743	.3772	.2572	.2572	.2572
Max	.463	.5658	.6859	.5316	.4287	.2915	.3772
Min	.0857	.1886	.2058	.2572	.2229	.1029	.1029
Avg	.2982	.3564	.3970	.3874	.3285	.2254	.2977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 304057 / 33 KV WENI KOPRA

Feeder No / Name : 202 / 11KV SHELU AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	14-JUL-17
HR	Load (MW)
7	.3086
8	.3429
9	.3429
Max	.3429
Min	.3086
Avg	.3315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304057 / 33 KV WENI KOPRA

Feeder No / Name : 203 / 11KV HARSHI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	1.2517	1.2346	1.1145		1.166
2	1.0288	1.0288	1.166	1.2346	1.1145		1.0802
3	1.0288	1.2346	1.166	1.2003	1.1145		1.0802
4	1.2003	1.3032	1.2003	1.2003	1.0974		1.1145
5	1.3717	1.3203	1.4746	1.286	1.3717		1.2346
6	1.5947	1.3203	1.5432	1.4575	1.6632		1.3203
7	1.5432	1.3032	1.5089	1.5775	1.7318	1.5775	1.3717
8	1.4232	1.3032	1.3032	1.6975	1.7147		1.2174
9	1.2003	1.3032	1.2346	1.2346	1.406		1.1488
10	1.3717	1.2003	1.2689	1.2003	1.1145		
11	1.3717	1.2003	1.166	1.0288			
12	1.0288	1.1317	1.0288		1.0288	.5487	.5658
13	1.0288	1.0631	1.0802		1.0288		.5658
14	1.0117	1.046	1.0631		1.0288	.6001	.5144
15	2.0062	1.6461	1.7661		1.0288	.7716	.7545
16	2.0062	2.0233	2.2291		1.0288		.823
17	2.0062	2.2634	2.1605			1.1488	.9431
18	2.0576	2.1605	2.1262	1.989		1.2517	1.0288
19	2.0576	2.0576	1.9376		1.406	1.3375	1.2346
20	1.7147	1.9547	1.7318	1.4232	1.2003	1.3375	1.406
21	1.7147	1.8519	1.5604	1.3889	1.2346	1.286	1.2003
22	1.4403	1.6461	1.4918	1.3546	1.2003	1.286	1.1145
23	1.4403	1.6461	1.3375	1.286	1.0631	1.2346	.9945
24	1.4403		1.5089	1.3032	1.0631		1.2346
Max	2.0576	2.2634	2.2291	1.989	1.7318	1.5775	1.406
Min	1.0117	1.0288	1.0288	1.0288	1.0288	.5487	.5144
Avg	1.4632	1.4799	1.4711	1.3586	1.2264	1.1255	1.0506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304058 / NIMBI BHOJALA

Feeder No / Name : 201 / 11KV PARDI Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.4344	.5304	.2743	.2103	.2058
2	.4066		.4024	.5544	.3086	.0351	.2058
3	.4066		.4805	.567	.3086	.0351	.0343
4	.5121		.5487	.5792	.3429	.0351	.0343
5	.543	.7316	.6584	.6036	.4801	.0351	.0343
6	.5611	.724	.8688	.6805	.6173	.0351	.0343
7	.724	1.267	1.1946	1.1283	.9709	.0351	.0343
8	.905	1.6651	1.576	1.4299	1.0288	.0351	.0343
9	1.2178	1.8088	1.7013	1.647		.0351	.0343
10	1.267	1.829	1.9204			.0351	.3772
11		1.8446	1.8656			.3155	.3429
12	.8954	1.8461	1.8099	1.6655	1.2689		.2865
13	1.5927	1.8107		1.6118	1.2346		.2715
14	1.4685	1.9753	1.6651	1.6804	1.2003	.3155	.2926
15	.7164	1.9185	1.7924	1.406	1.2003	.3155	.3439
16	.7602	1.8461	1.8823	1.6461	1.166	.3506	.3439
17	.905	1.9521	1.9342	1.5775	1.0974	.3506	.3109
18	.8954	1.8656	1.828	1.5775	.0343	.3429	.2715
19	.9955	1.5565	1.5565	.5144	.0343	.3772	.2686
20	1.086	1.4083	1.4506	.4458	.3155	.3086	.2926
21	1.0498	1.0387	.7602			.2401	.2715
22	1.0059	.8145	.5487	.4115	.2454	.2401	.2743
23	.924	.6401	.5487	.3429	.2401	.2401	.2926
24	.4525	.8779	.5121	.5175	.2743	.2103	.2058
Max	1.5927	1.9753	1.9342	1.6804	1.2689	.3772	.3772
Min	.4066	.6401	.4024	.3429	.0343	.0351	.0343
Avg	.8584	1.4710	1.2148	1.0056	.6321	.1879	.2124

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304058 / NIMBI BHOJALA

Feeder No / Name : 203 / NIMBI GAWTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.9511	1.0745	.8048	1.0288	.7712	.7202
2	.8779	.924	1.0631	.8316	1.0974	.7712	.7202
3	.8871	.924	1.4529	.8779	1.3032	.7712	
4	1.0974	1.1888	1.6834	1.1706	1.3032	.7712	
5	1.4632	1.3717	1.9136	1.3394	1.406	1.0517	
6	1.7375	1.6289	1.8625	1.5402	1.4746	1.4022	
7	1.4327	1.9547	1.8461	1.8073	1.7147	1.6476	
8	1.267	1.9004	1.97		1.8176	1.4373	
9	1.1641	1.8625	1.8461		1.6461	1.2269	
10	1.2894	1.6476	1.6118		1.4403	.9114	.8573
11		1.5203	1.3466		1.3717	.6661	.6859
12	1.267	1.4842	1.2894		1.0974		.567
13	1.3394	1.6095		1.4746	1.1317		.5258
14	1.2536	1.829	1.0745	1.3032	1.166	.6661	.4961
15	1.448	1.9185	1.2308	1.3032	1.2346	.6661	.3544
16	1.4842	1.97	1.2536	1.0288	1.3032	.7011	.7164
17	1.5546	1.9547	1.8099	1.5089	1.5089	.7712	.7973
18	1.448	1.6095	1.9909	1.8861		1.0974	.985
19	1.5384	1.7737	1.97	1.7833	1.3032	1.166	1.0985
20	1.7737	1.576	1.6301	1.6118	1.262	1.0288	1.086
21	1.1104	1.3032	1.2894	1.3032	.9816	.8573	.8954
22	1.1104	1.1827	1.182	.9259	.9259	.7888	.8048
23	1.0745	1.1222	.905	1.0974	.8573	.7202	.7602
24	.905	1.0164	1.0974	.8779	1.0288	.8063	.7202
Max	1.7737	1.97	1.9909	1.8861	1.8176	1.6476	1.0985
Min	.8779	.924	.905	.8048	.8573	.6661	.3544
Avg	1.2803	1.5093	1.4954	1.2882	1.2784	.9408	.7524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304068 / 33 KV Brahmangaon

Feeder No / Name : 201 / 11 KV PARAWA/UDADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6089	.6859	.7545	.7545	.5487		.2401
2	.6241	.703	.7362	.7202	.6516		.2572
3	.6447	.7545	.7619	.7888	.6344		.2915
4	.724	.8059	.7888	.8745	.7202		.3258
5	.7802	.8745	.8688	.9431	.703		.3601
6	.905	.9431	1.0924	.9945	.7716		.5144
7	.8859	1.1488	1.0923	1.0631	.8059		.3086
8	.7716	1.1831	1.1919	1.1317	.9259		.3086
9	.6859	1.0974	1.134	1.0802	.6687		.2058
10	.6859	.7888	.9991	.7202			.12
11	.7716	.7373	.9412	.9088	.8745		.1543
12	.2058	.8916	1.0517	.9431	.823		.1543
13	.8402	.8402	.9945	.9259	.8745		.2058
14	.8573	.8596	.9945	.8745	.8059	.2229	.2058
15	.9431	1.1096	.9945	.8745	.463	.3601	.2229
16	.9431	1.1317	.9602	.9602	.5144	.3772	
17	.9602	1.1584	.9774	.9259	.5144	.4115	
18	.9945	1.2309	.9431	1.0117		.5144	.463
19	1.0117	.7888	1.046	.583		.463	
20	.8573	.9492	.9259	.5658		.4801	.3429
21	.7888	.8842	.8402	.5144		.4458	.4115
22	.7545	.8413	.6859	.4973		.3772	.4287
23	.7716	.8238	.7373	.4801		.3772	.4287
24	.5959	.7202	.7802	.7545	.5144		.2401
Max	1.0117	1.2309	1.1919	1.1317	.9259	.5144	.5144
Min	.2058	.6859	.6859	.4801	.463	.2229	.12
Avg	.7755	.9147	.9289	.8288	.6949	.4029	.2948



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304068 / 33 KV Brahmangaon

Feeder No / Name : 202 / 11 KV BRAHAMANGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3429	.3944	.3429	.3772		.3086
2	.362	.3601	.3761	.3772	.3944		.3258
3	.3856	.3944	.4207	.3772	.4287		.3429
4	.4161	.4287	.4508	.4115	.4115		.3601
5	.4525	.4801	.5138	.4458	.463		.3429
6	.4287	.5144	.5784	.4801	.463		.3944
7	.4382	.5487	.591	.4973	.4458		.4287
8	.3429	.5144	.583	.5487	.4973		.3944
9	.3258	.4801	.543	.4287	.3601		.3258
10	.3258	.4287	.3403	.3944	.2572		
11	.3258	.3944	.333	.3601	.2229	.1543	
12	.3429	.3772	.3258	.5144	.2229	.2229	.1715
13	.3429	.4115	.3429	.3601	.3429	.2743	.2058
14	.3258	.4382	.3601	.3258		.2743	.2229
15	.3601	.5014	.4115	.2743	.1886	.3086	.2915
16	.4458	.4784	.4115	.3429	.3429	.2915	
17	.5144	.5609	.4458	.3772	.3429	.3429	
18	.5487	.5847	.5316	.4287		.3944	.4458
19	.4973	.5611	.463	.4458		.463	.4801
20	.5144	.5083	.463	.4458		.3944	.2743
21	.4287	.4706	.3944	.3601		.3601	.3258
22	.3944	.4161	.3772	.3258		.3429	.3429
23	.3772	.4557	.3601	.3429		.3086	.3429
24	.362	.3772	.4382	.3601	.3601		.2915
Max	.5487	.5847	.591	.5487	.4973	.463	.4801
Min	.3258	.3429	.3258	.2743	.1886	.1543	.1715
Avg	.4005	.4595	.4354	.3987	.3601	.3179	.3309

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304078 / 33KV VIDYUT BHAVAN S/S

Feeder No / Name : 201 / 11 KV Karla gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0288	1.166	1.2003	1.2003	1.166	1.166
2	1.1317	1.0288	1.166	1.2003	1.2003	1.166	1.166
3	1.1317	1.0288	1.2003	1.5089	1.5089	1.2003	1.166
4	1.166	1.3717	1.2346	1.5775	1.7147	1.5089	1.2003
5	1.4403	1.6461	1.3032	1.7147	1.8519	1.7147	1.6975
6	1.8861	1.7147	1.5089	1.9204	1.989	1.8519	1.9204
7	1.9547	1.9204	1.989	1.989	1.989	1.989	1.989
8	1.8519	1.8861	1.7833	1.8519	1.8519	1.8519	1.989
9	1.8519	1.5775	1.4403				1.5775
10	1.8519	1.3717	1.0288				.9602
11	1.8519	1.166	.7545				.6859
12	1.8519	1.0288	.7545		.6859	.6173	.6173
13	1.8519	1.166	.7545		.6859	.583	.6859
14	1.8519	1.2003	.6859		.6859		.6859
15	.7716	1.3032			.6859		.6859
16	1.166	1.4403	.9602	.9602	.7545	.8916	.823
17	1.3032	1.5089	1.2346		1.3032	1.166	1.2346
18	1.6118	1.6461	1.7147		1.3717	1.5089	1.5775
19	1.7833	1.5432	1.9204	1.6461	1.6461	1.3032	1.7147
20	1.5432	1.3717	1.6118	1.7147	1.4403	1.3032	1.7147
21	1.3717	1.3032	1.4403	1.3717	1.3032	1.3032	1.3717
22		1.2346	1.3032	1.3717	1.2003	1.2346	1.3032
23	1.166	1.166	1.2346	1.2346	1.166	1.166	1.166
24	1.166	1.0288	1.166	1.2003	1.2003	1.166	1.166
Max	1.9547	1.9204	1.989	1.989	1.989	1.989	1.989
Min	.7716	1.0288	.6859	.9602	.6859	.583	.6173
Avg	1.5082	1.3617	1.2763	1.4975	1.3064	1.2996	1.2610

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304078 / 33KV VIDYUT BHAVAN S/S

Feeder No / Name : 202 / 11 KV TOWN 3

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.6461	1.6461	1.9547	1.7833	1.5775
2			1.6461	1.6461	1.9547	1.7833	1.5775
3			1.6461	1.6461	1.9547	1.8861	1.5775
4			1.6461	1.6461	2.2291	2.1262	1.7147
5			1.6461	1.6461	2.4348	2.2291	2.0576
6			1.6461	1.6461	2.4691	2.2634	2.332
7			1.6461	1.6461	2.5377	2.5377	2.4006
8			1.6461	1.6461	2.5377	2.4006	2.6063
9	1.6461						2.2977
10	1.6461						2.2634
11	1.6461						
12	1.6461				2.8121	1.5432	2.2291
13	1.6461				2.1948	1.5089	1.7833
14	1.6461				1.7147		1.5432
15	1.6461			1.7833	1.7147		1.3717
16	1.6461			1.7833	1.7147	1.3032	1.3717
17					1.989	1.5089	1.4403
18					2.0576	1.9204	1.9204
19				2.2634	2.1948	2.0576	1.989
20				2.4006	2.2291	2.0576	2.1262
21				2.1262	2.0576	1.8519	1.9204
22				2.0805	2.0576	1.7833	1.7147
23		1.6461	1.6461	2.0576	1.8519	1.6461	1.6461
24			1.6461	1.6461	1.9547	1.7833	1.5775
Max	1.6461	1.6461	1.6461	2.4006	2.8121	2.5377	2.6063
Min	1.6461	1.6461	1.6461	1.6461	1.7147	1.3032	1.3717
Avg	1.6461	1.6461	1.6461	1.8319	2.1246	1.8934	1.8712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304078 / 33KV VIDYUT BHAVAN S/S

Feeder No / Name : 203 / 11 KV KARLA Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.7545	.9259	1.0288	.5144	.1029
2	.2401	.2401	.7545	.9259	1.0288	.5144	.1029
3	.2401	.2401	.7545	.9259	1.0288	.5144	.1029
4	.2401	.2401	.7545	.9259	1.0288	.5144	.1029
5	.3086	.3429	.7545	.9259	1.0288	.5144	.1029
6	.3429	.5144	.7545	.9259	1.0288	.5144	.1372
7	.4801	.6859	.7545	.9259	1.0288	.5144	.1372
8	.5487	.6859	.7545	.9259	1.0288	.5144	.1715
9		.7545					.2401
10			.7202				
11	.5144		.7545				
12	.5144		.9602		.6859	.2401	
13	.5144		.823		.6516	.2401	
14			.6859		.583		
15					.583		
16	.5144		.6859	1.1317	.583	.2401	
17			.7545		.5144	.2743	
18			.9259				
22					.5144		.2401
23		.7545	.9259	1.0288	.5144	.2743	.2401
24	.2058	.2058	.7545	.9259	1.0288	.5144	.1029
Max	.5487	.7545	.9602	1.1317	1.0288	.5144	.2401
Min	.2058	.2058	.6859	.9259	.5144	.2401	.1029
Avg	.3746	.4427	.7793	.9540	.8170	.4213	.1486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304078 / 33KV VIDYUT BHAVAN S/S

Feeder No / Name : 204 / 11 KV TOWN 2

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1605	2.2634	2.4006	2.5377	2.4006	1.8861	1.7833
2	2.1262	2.1262	2.4006	2.5377	2.4006	1.8861	1.7833
3	2.1262	2.1262	2.2291	2.5377	2.4006	2.0576	1.7833
4	2.1262	2.1262	2.1948	2.572	2.4863	2.2291	1.8519
5	2.2634	2.2291	2.2634	2.572	2.5377	***	2.1262
6	2.4691	2.4691	2.4006	2.6063	2.6063	2.4006	2.4006
7	2.332	2.4006	2.4691	2.572	2.5377	2.4006	2.4006
8	2.1262	2.4006	2.2634	2.2291	2.1948	2.2291	2.1262
9	2.0576	2.4006	2.332				2.4006
10	1.989	2.1948	2.0919				1.989
11	1.989	1.989	2.0576				1.8519
12	1.9204	1.9204	.9602		1.7147	1.7147	1.7833
13	1.9204	1.989	.9602		1.7833	1.0974	1.7147
14		1.989	2.4691		1.7833		1.7147
15	1.989	2.0576	2.4006	1.989	1.8519		1.6461
16	2.0576	2.0576	2.2977	1.989	1.8861	1.5089	1.5775
17	2.0576	2.0919	2.2634		1.989	1.6461	1.7147
18	2.0576	2.0576	2.2291		2.0576	1.7147	1.7147
19	2.1262	2.332	2.4006	2.2634	2.1948	2.0576	1.989
20	2.4691	2.4691		2.4691	2.2634	2.1262	2.1262
21	2.5377	2.6063		2.6063	2.2634	2.1262	2.1948
22		2.6749		2.4691	2.2291	2.0576	1.8861
23	2.5377	2.7435	2.7435	2.4691	2.1948	1.9204	1.9204
24	2.2291	2.4691	2.6063	2.572	2.4006	2.0576	1.8519
Max	2.5377	2.7435	2.7435	2.6063	2.6063	22.428	2.4006
Min	1.9204	1.9204	.9602	1.989	1.7147	1.0974	1.5775
Avg	2.1667	2.2577	2.2111	2.4370	2.1989	3.0287	1.9305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304078 / 33KV VIDYUT BHAVAN S/S

Feeder No / Name : 206 / 11 KV KAKADDATI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.4115	.4115	.4115	.4115	.3772	.3429
2	.4115	.4115	.4115	.4115	.4115	.3772	.3429
3	.4115	.4115	.4115	.4115	.4115	.3772	.3429
4	.4115	.4115	.4115	.4458	.4801	.4115	.4115
5	.4458	.4801	.4458	.4801	.5144	.4801	.4801
6	.5144	.5144	.4801	.5487	.5487	.5144	.5144
7	.5487	.5487	.5144	.5144	.5144	.5487	.5144
8	.4458	.5144	.4801	.5144	.4801	.4801	.4801
9	.4115	.4458	.4115				.4115
10	.3772	.4115	.3772				.3772
11	.3772	.3772	.3772				.3429
12	.3086	.3429	.3086		.3086	.2743	.2743
13	.3086	.3429	.3429		.2743	.2401	.2401
14	.3086	.3429	.3429		.2743		.2401
15	.3429	.3772	.3429	.3086	.2743		.2401
16	.3429	.3772	.3086	.3086	.2743	.2743	.2401
17	.3429	.4115	.3772		.3086	.2743	.2401
18	.4115	.3429	.4115		.3429	.3086	.3086
19	.4115	.4115	.4458	.3772	.4458	.3772	.3429
20	.5144	.4115	.4801	.4458	.4458	.4115	.4115
21		.4801		.4115	.4115	.4115	.3772
22		.4801		.4115	.3772	.4115	.3429
23	.4458	.4458	.4458	.4115	.4115	.3772	.3772
24	.4115	.4115	.4458	.4458	.4115	.3772	.3429
Max	.5487	.5487	.5144	.5487	.5487	.5487	.5144
Min	.3086	.3429	.3086	.3086	.2743	.2401	.2401
Avg	.4053	.4215	.4084	.4287	.3968	.3844	.3558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321]

BU 1732

Substation No/ Name :- 304083 / 33 KV BHATAMBA PUSAD

Feeder No / Name : 202 / 11 KV New Pusad

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6708	.773	.7392	.7453	.6468	.6283	.559
2	.6521	.773	.7392	.708	.6283	.6283	.5217
3	.6335	.7546	.7762	.6894	.6099	.5914	.5217
4	.6521	.6994	.8131	.6894	.6099	.5914	.559
5	.708	.6994	.8131	.7639	.6099	.6653	.6521
6	.8571	.7794	.8501	.8385	.7023	.7577	.7639
7	.8198	.8282	.8871	.8198	.7207	.8501	.8198
8	.7826	.8131	.8131	.8198	.7023	.8316	.8571
9	.8198	.7762	.8131	.8385	.7023	.7762	.8198
10	.6894	.7392	.6653	.708	.6468	.6838	.6149
11	.6335	.7023	.6283		.6283	.5963	.5963
12	.6073	.7023	.559	.6257	.5175	.559	.5175
13		.6653	.5963	.5521	.5175	.4845	.4435
14	.5889	.7023	.5963	.6257	.5544	.4845	.2587
15	.6257	.6653	.5776	.5521	.5914	.4472	.2587
16	.6257	.7023	.5963		.5914	.4845	.2587
17	.5889	.7207	.6335	.5889	.5914	.5217	.5544
18	.6257	.6283	.6708	.6257	.5914	.559	.5544
19	.7178	.6468	.8012	.6073	.6468	.6894	.6468
20	.8098	.8316	.8198	.7362	.7392	.7453	
21	.8282	.8501	.8944	.6626	.7023	.8757	
22	.8098	.8871	.8385	.681	.7207	.6521	.6653
23	.7914	.7947	.8385	.6653	.6468	.5963	.5914
24		.7914	.7639		.6653	.559	
Max	.8571	.8871	.8944	.8385	.7392	.8757	.8571
Min	.5889	.6283	.559	.5521	.5175	.4472	.2587
Avg	.7063	.7469	.7385	.6925	.6368	.6358	.5731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 307011 / 132 KV JAMBBAZAR

Feeder No / Name : 201 / 11 KV Parwa

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23				.2572			
24	.2572	.2572	.2572	.5144	.2572	.2572	.5316
Max	.2572	.2572	.2572	.5144	.2572	.2572	.5316
Min	.2572	.2572	.2572	.2572	.2572	.2572	.5316
Avg	.2572	.2572	.2572	.3858	.2572	.2572	.5316



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 307011 / 132 KV JAMBBAZAR

Feeder No / Name : 202 / 11 KV Jambazar

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
23		.3429					
24	.2058	.3601	.3601	.3429	.3429	.3086	.3601
Max	.2058	.3601	.3601	.3429	.3429	.3086	.3601
Min	.2058	.3429	.3601	.3429	.3429	.3086	.3601
Avg	.2058	.3515	.3601	.3429	.3429	.3086	.3601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

PUSAD SUB-DN[321] BU 1732

Substation No/ Name :- 307011 / 132 KV JAMBBAZAR

Feeder No / Name : 203 / 11 KV Wanwarala

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.4287	.4801	.4287	.4287	.4287	.4287	.4801
Max	.4287	.4801	.4287	.4287	.4287	.4287	.4801
Min	.4287	.4801	.4287	.4287	.4287	.4287	.4801
Avg	.4287	.4801	.4287	.4287	.4287	.4287	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHEDE S/DN.[322] BU 1741

Substation No/ Name :- 304008 / 33 KV POPHALI

Feeder No / Name : 201 / 11 KV Palashi AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0162	1.166	.7287	.4858	.2572
2				1.2003	.7773	.4858	.2572
3				1.2174	.8097	.4858	.2572
4				1.2689	.7773	.4858	.2743
5				1.2689	.7287	.4858	.2743
6				1.3717	.7125	.502	.2743
7				1.3717	.8907	.5182	.3258
8				1.5604	1.1336		.3429
9							.3239
10	.7125	.9602					.4049
11	.8259	1.2631					.4372
12							.3401
13	1.1822	1.4413					.5344
14	1.1498	1.4575					.4696
15	1.1336	1.4089					.5182
16	1.1336	1.6118					
17	1.286	1.4575					.4115
24				.7545	.6478	.4858	.2753
Max	1.286	1.6118	.0162	1.5604	1.1336	.5182	.5344
Min	.7125	.9602	.0162	.7545	.6478	.4858	.2572
Avg	1.0605	1.3715	.0162	1.2422	.8007	.4919	.3517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHEDE S/DN.[322] BU 1741

Substation No/ Name :- 304008 / 33 KV POPHALI

Feeder No / Name : 202 / 11 KV Mulawa Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.3239	.3563	.0162	.0324	.0324	.0162
2	.2267	.3077	.3725	.0162	.0324	.0162	.0162
3	.1943	.3239	.3944	.0162	.0162	.0162	.0162
4	.2105	.3563	.4115	.0162	.0162	.0162	.0162
5	.2591	.3725	.3887	.0162	.0162	.0162	.0162
6	.2429	.3887	.421	.0162	.0162	.0162	.0162
7	.3239	.4049	.4372	.0162	.0162	.0162	.0162
8	.4372	.4696	.5506	.0162	.0162	.0162	.0162
9	.4372	.4696	.583				.0162
10	.0162	.0162	.583				.0162
11	.0162	.0162	.664	.7125	.583		.0162
12	.0162	.0162	.5506	.6478	.583	.2591	.0162
13	.0162	.0162	.5668		.583	.3239	
14	.0162	.0162	.583		.5506	.2915	.0162
15	.0162	.0162	.5992		.583		
16	.0162	.0171	.6478	.6478	.583		
17	.0171	.0171	.6859		.4287	.2267	.0162
18	.0514	.0857	.0857		.12	.1457	.0972
19	.1029	.0857	.1029	.12	.12	.1134	.0972
20	.1029	.1029	.12	.1372	.1372	.1134	.1134
21	.12	.0972	.12	.12	.12	.1029	.12
22	.0972	.1134	.1134	.12	.1296	.12	.1619
23	.1134	.1134	.1134	.1134	.1457	.0972	.1296
24	.1619	.3239	.3239	.0324	.0324	.0324	.0162
Max	.4372	.4696	.6859	.7125	.583	.3239	.1619
Min	.0162	.0162	.0857	.0162	.0162	.0162	.0162
Avg	.1419	.1863	.4073	.1636	.2210	.1038	.0458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHEDE S/DN.[322] BU 1741

Substation No/ Name :- 304008 / 33 KV POPHALI

Feeder No / Name : 203 / 11 KV Factory

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0171	.0171	.0171	.0162	.0162	.0171
2	.0162	.0171	.0171	.0171	.0162	.0162	.0171
3	.0162	.0171	.0171	.0171	.0162	.0162	.0171
4	.0162	.0171	.0171	.0171	.0162	.0162	.0171
5	.0162	.0171	.0171	.0171	.0162	.0162	.0171
6	.0162	.0171	.0171	.0171	.0162	.0162	.0171
7	.0162	.0171	.0171	.0171	.0162	.0162	.0171
8	.0162	.0171	.0171	.0171	.0162	.0162	.0171
9	.0162	.0162	.0171				.0162
10	.0162	.0162	.0171				
11	.0162	.0162	.0162	.0162	.0162		.0162
12	.0162	.0162	.0162	.0162	.0162	.0162	.0162
13	.0162	.0162	.0162		.0162	.0162	.0162
14	.0162	.0162	.0162		.0162	.0162	.0162
15	.0162	.0324	.0162		.0162	.0171	
16	.0162	.0171	.0162	.0162	.0162	.0171	
17	.0171	.0171	.0171		.0171	.0171	.0171
18	.0171	.0171	.0343		.0171	.0171	.0171
19	.0171	.0171	.0171		.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0162	.0171	.0171	.0171	.0162	.0171
22	.0171	.0162	.0162	.0171	.0162	.0162	.0171
23	.0171	.0162	.0162	.0162	.0162	.0171	.0162
24	.0162	.0171	.0171	.0171	.0162	.0162	.0162
Max	.0171	.0324	.0343	.0171	.0171	.0171	.0171
Min	.0162	.0162	.0162	.0162	.0162	.0162	.0162
Avg	.0165	.0174	.0175	.0169	.0164	.0165	.0168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHEDE S/DN.[322] BU 1741

Substation No/ Name :- 304008 / 33 KV POPHALI

Feeder No / Name : 204 / 11 KV Palashi Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4049	.4049	.4458	.4458	.4049	.3887	.3563
2	.421	.421	.4458	.4458	.4049	.3887	.3401
3	.421	.3887	.4458	.463	.4049	.3887	.3401
4	.3887	.4858	.463	.463	.4049	.3887	.3563
5	.4858	.4372	.4858	.4973	.4858	.4049	.4858
6	.5344	.4696	.5506	.5144	.5182	.421	.5182
7	.4696	.4696	.5144	.5144	.3725	.4372	.4696
8	.3887	.4372	.4458	.4801	.3239	.4372	.4973
9	.2915	.3563	.3401				.4696
10	.2591	.3239	.2915				.2753
11	.2429	.2915	.2429	.2105	.2105		.1457
12		.2429	.2429	.1943	.2105	.2591	.1619
13	.2105	.2267	.2267		.1781	.1943	.1619
14	.2267	.2915	.2267		.2105	.1943	.1781
15	.2429	.3239	.2429		.1943	.2058	.1943
16	.2591	.3601	.3239	.2267	.2267	.2401	
17	.3086	.3772	.3258		.3258	.3258	.2915
18	.3601	.4115	.4115		.3944	.3601	.3239
19	.4458	.4115	.4458	.4287	.4115	.4115	.3725
20	.5487	.4801	.4458	.4458	.463	.4458	.421
21	.5316	.4372	.12	.4801	.463	.4458	.4458
22	.4534	.421	.4458	.463	.4372	.4115	.4287
23	.4049	.4372	.4287	.4372	.4372	.3725	.3725
24	.4372	.4372	.4372	.4458	.4049	.3887	.3725
Max	.5487	.4858	.5506	.5144	.5182	.4458	.5182
Min	.2105	.2267	.12	.1943	.1781	.1943	.1457
Avg	.3799	.3893	.3748	.4209	.3585	.3576	.3469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 201 / 11 KV Umerkhed

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7293	.7468	7.6642	.7293	.6783	.6516	.583
2	.663	.7468	.7461	.7042	.6783	.6516	.583
3	.663	.7468	.8215	.7209	.6783	.6173	.5487
4	.663	.7468	.8215	.7461	.6443	.6173	.5487
5	.7468	.7468	.8962	.78	.6783	.6173	.583
6	.7956	.7842	.9335	.8139	.6783	.6859	.6859
7	.6962	.8288			.6783	.6859	.6516
8	.6908	.6962	.7293		.6443	.6516	.6516
9	.6516	.7202	.6859			.6783	.6687
10	.6687	.6516	.6859			.6104	.6173
11	.6001	.6173	.6173		.5487		.5487
12	.6687	.6173	.703	.6173	.5658	.5087	
13	.6859	.6859	.703	.6173	.6001	.4748	
14	.6859		.6859		.583	.5415	.5487
15	.6859	.6859	.6516		.583		.4801
16	.6859	.6859	.6984	.6173	.583	.5601	
17		.7621	.743		.6001	.5487	
18	.6859	.7621	.8002		.6859	.583	.6173
19	.7545	.8002	.8383	.7621	.6783	.6173	.6516
20	.823	.9145	.9907	.7716	.78	.6859	.6859
21	.823	.9907	.9907	.7969	.8589	.6859	.6859
22	.8962	.9907	.9907	.7969	.7888	.6859	.6687
23	.7625	.9335	.9709	.8215	.7202	.6173	.6173
24	.6642	.7842	.8589	.8619	.0724	.6516	.583
Max	.8962	.9907	7.6642	.8619	.8589	.6859	.6859
Min	.6001	.6173	.6173	.6173	.0724	.4748	.4801
Avg	.7126	.7672	1.0968	.7438	.6367	.6195	.6104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 202 / 11 KV Marlegaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.4937	1.3226	.8619	.4748	.8573	.6859
2	.7625	1.4563	1.2887	.8322	.4748	.823	.6859
3	.7956	1.4563	1.419		.4748	.823	.6859
4	.7956	1.4563	1.419		.4748	.823	
5	.7956	1.419	1.643		.4748	.823	
6	1.0608	1.643	1.8111		.5426	.8916	
7	1.3592	1.757			.6443	1.0974	
8	1.7375	1.5912	1.8564		.7122	1.1317	
9	1.7833	1.9204	2.4006			1.1869	
10	1.7833	2.0576	2.5034			1.0852	.6173
11	2.0233	2.2634	2.4177		1.2346		
12	2.1262	1.3717	2.6063	1.8519	1.3717	.9496	
13	2.1948	1.2346	2.6749	1.7147	1.7147	1.0852	
14	1.7147		2.6749		1.5089	1.2323	
15	2.0576	1.8519	2.6235		1.3717		.1029
16	2.0576	1.9204	3.0674	1.5775	1.5089	1.2323	
17		2.572	2.8959		1.4403	1.166	
18	2.332	2.6673	2.8578		1.4575	1.166	.6859
19	2.1262	2.2862	.4572	1.1431	1.153	.8916	.6859
20	1.7833	1.749	1.3336		1.0513	.823	.6516
21	1.6461	1.7909	1.1431	.5426	1.1203	.823	.6344
22	1.643	1.9052	1.1431	.4917	.9945	.823	.6173
23	1.3923	1.643	1.0829	.5228	.9602	.7202	.6173
24	1.0753	1.4937	1.531	1.1203	.5068	.8916	.6859
Max	2.332	2.6673	3.0674	1.8519	1.7147	1.2323	.6859
Min	.7625	1.2346	.4572	.4917	.4748	.7202	.1029
Avg	1.5699	1.7826	1.9206	1.0659	.9849	.9703	.6130



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 203 / 11 KV Sukali

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17
HR	Load (MW)
20	1.3375
Max	1.3375
Min	1.3375
Avg	1.3375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 204 / 11 KV Vidul

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3923	1.5684	1.6278	1.2266	1.3904	1.2346	1.2346
2	1.3592	1.643	1.6278	1.1843	1.3435	1.2346	1.2003
3	1.3592	1.9044	1.7551	1.2452	1.3565	1.166	1.166
4	1.3592	1.9044	1.7551	1.2887	1.3226	1.166	1.166
5	1.3592	1.8671	1.9044	1.2209	1.3226	1.166	1.166
6	1.4255	2.1285	2.0165	1.2887	1.278	1.2346	1.1317
7	1.6575	1.9559			1.153	1.3717	1.166
8	2.0633	2.5766	2.4531		1.3565	1.406	1.2689
9		2.3148	2.7435			1.2209	1.2346
10	1.989	2.4863	2.6406			1.1869	1.1488
11	1.7833	2.2977	2.1605		1.2346		1.406
12		2.8121	2.572	.583	1.5775	.8478	
13	2.2119	2.692	2.7092	.703	1.3375	.7122	
14	2.692	2.3663	2.572		1.5261	1.3756	1.6804
15	2.5034	2.8292	2.4006		1.7147		.703
16	1.406	1.8176	3.1245	2.0725	2.0062	1.4842	
17	2.6063	3.0483	1.6385		2.0919	1.5089	
18	2.6749	3.2579	2.7054		1.6461	1.3375	
19	2.3663	2.4768		1.9624	1.3735	1.2346	1.0288
20	2.1605	1.8519			1.3904	1.286	.9602
21	2.0919	2.1338	1.0669	1.5939		1.3032	1.0288
22	2.1658	2.1338	1.5623	1.5261	1.3717	1.3032	1.0288
23	1.757	1.9978	1.4937	1.643	1.3375	1.2689	.9945
24	1.3283	1.9418	1.9044	1.448	1.5684	1.2346	1.2346
Max	2.692	3.2579	3.1245	2.0725	2.0919	1.5089	1.6804
Min	1.3283	1.5684	1.0669	.583	1.153	.7122	.703
Avg	1.896	2.2503	2.1159	1.3562	1.4619	1.2402	1.1552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 205 / 11 KV Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1326	.112	.1017		.1017	.1029	.1029
2	.0995	.1127	.1017	.096	.1017	.1029	.1029
3	.0995	.1124	.112	.0983	.1017	.1029	.1029
4	.0995	.112	.112	.1017	.1017	.1029	.0686
5	.0995	.112	.1086	.1017	.1017	.1029	.0343
6	.0995	.112	.112	.1017	.1017	.1029	.0343
7	.0995	.096			.1017	.1029	.0343
8	.0983	.0995	.0995		.1017	.1029	.0343
9		.1029	.1029			.1017	.0514
10	.1029	.1029	.1029			.1017	.0686
11	.1029	.1029	.1029		.1029		.0686
12		.12	.1029	.1029	.1029	.1017	
13	.1029	.12	.1029	.1029	.1029	.1017	
14	.12	.12	.1029		.1029	.112	.0686
15	.1029	.12	.1029		.1029		.0686
16	.1029	.12	.1143	.1029	.1029	.1029	
17	.1029	.1334	.1143		.1029	.1029	
18	.1029	.1334	.1143		.1029	.1029	.0686
19	.1029	.1143	.0572	.0572	.1017	.1029	.0343
20	.1029	.1029	.0762		.0678	.0686	.0343
21	.0686	.0762	.0762	.0678	.0747	.0686	.0343
22	.0747	.0762	.0762	.0509	.0686	.0514	.0343
23	.0747	.056	.0747	.0747	.7202	.0514	.0686
24	.0949	.0747	.0747	.1086	.0747	.0686	.0514
Max	.1326	.1334	.1143	.1086	.7202	.112	.1029
Min	.0686	.056	.0572	.0509	.0678	.0514	.0343
Avg	.0994	.1060	.0976	.0898	.1248	.0937	.0583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHED S/DN.[322] BU 1741

Substation No/ Name :- 304039 / 33 KV UMERKHED

Feeder No / Name : 206 / 11 KV MIDC Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0995	.0187	.0339	.0166	.017	.0171	.0171
2	.0332	.0188	.017	.0187	.017	.0171	.0171
3	.0332	.0187	.0187	.0164	.017	.0171	.0171
4	.0332	.0373	.0187	.017	.017	.0171	.0171
5	.0332	.0373	.0187	.017	.017	.0171	.0171
6	.0332	.0375	.0187	.017	.017	.0171	.0171
7	.0332	.032			.017	.0171	.0171
8	.0543	.0362	.0166		.017	.0343	.0514
9		.0343	.0343			.0339	.0686
10	.1372	.0343	.12			.1017	.1029
11	.1029	.1029	.0686		.0857		.1372
12	.0686	.1029	.1029	.0686		.0848	
13	.1029	.0514	.0857	.0686		.1357	
14	.0686	.0686	.1029			.112	.0857
15	.12	.0686	.1029		.0171		.1372
16	.1372	.1029	.1715	.1372	.0686	.1029	
17	.0686	.1143	.1334		.0857	.0343	
18	.0686	.0953	.1143		.0686	.0514	.1372
19	.0686	.0572	.0762	.0381	.0678	.0686	.0857
20	.0343	.0343	.0762		.0678	.0514	.0686
21	.0686	.0381	.0381	.0339	.0747	.0343	.0686
22	.1494	.0572	.0381	.0339	.0343	.0686	.0686
23	.0724	.0747	.0362	.0373	.0343	.0343	.0686
24	.0316	.0373	.0373	.0373	.056	.0343	.0343
Max	.1494	.1143	.1715	.1372	.0857	.1357	.1372
Min	.0316	.0187	.0166	.0164	.017	.0171	.0171
Avg	.0718	.0546	.0644	.0398	.0419	.0501	.0617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

PUSAD DIVSION[631]

UMERKHEDE S/DN.[322] BU 1741

Substation No/ Name :- 304052 / 33 kv TIWADI PHATA TOWN

Feeder No / Name : 201 / 11 kv town feeder Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	2.0576	2.1262	1.989	1.8519	1.8176	1.6461
2	1.9547	2.0576	2.1262	1.9547	1.8519	1.8176	1.6118
3	1.9547	1.989	2.0576	1.9547	1.8176	1.749	1.5775
4	1.9204	1.9719		1.989	1.8176	1.749	1.5775
5	1.9376		2.0233	2.0062		1.8519	1.6975
6	2.1434	2.1434	2.1091	2.1605		1.989	1.9547
7	2.1262	2.2291	2.2291	2.2634		2.1434	2.0576
8	2.1091	2.2634	2.2462	2.2291		2.0576	2.1605
9	2.0233	2.0576	2.0576	1.989	2.0233	1.9719	2.0748
10		2.0405	1.9204	1.9204	1.9204	1.7147	2.0062
11	1.8861	.8916		1.8004			1.8861
12	1.7833	.1886	1.8861	1.6804	1.6804		1.8861
13	1.5947	1.9204	1.8519	1.749	1.6461	1.5775	1.9033
14	1.9719	1.8519	1.8519	1.6461	1.6289	1.406	1.6118
15		1.8519	1.7661	1.7147		1.4403	1.3717
16		1.8861	1.8519	1.7318	1.6804		1.4918
17	1.9376	1.9376		1.8519	1.8519	1.5775	
18	2.1434	1.9719		2.0405	2.1434	1.9033	
19		2.1948	2.1605	2.1948	2.2634	2.0062	1.9376
20	2.3703	2.3834	2.323	2.1605	2.2462	2.0062	2.1776
21	2.4348	2.4863	2.3491	2.1434	2.0748	1.8991	1.9204
22	2.3148	2.3663	2.2805	2.1091	2.0576	1.8347	1.8176
23	2.2634	2.2805	2.1776	2.0233	2.0062	1.7833	1.7147
24	2.0405	2.1262	2.2291	2.0576	1.9204	1.869	1.6804
Max	2.4348	2.4863	2.3491	2.2634	2.2634	2.1434	2.1776
Min	1.5947	.1886	1.7661	1.6461	1.6289	1.406	1.3717
Avg	2.0450	1.9629	2.0812	1.9733	1.9157	1.8174	1.8074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 201 / Arni Town 2

Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	10-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
11		.4572	
13	.4961		
14	.5121		
15	.5121		
16	.4572		
17	.5121		
18	.4572		
19	.4572		.443
20	.2926		.5121
21	.2195		.4572
22	.3841		.4572
23			.5121
Max	.5121	.4572	.5121
Min	.2195	.4572	.443
Avg	.4300	.4572	.4763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 202 / 11 KV Jawala AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6687	.2743	.3109		.1029	.1463	
2	.6344	.2401	.3292		.1029	.3292	.3086
3	.6516	.2743	.3292		.12	.3292	.3258
4	.6687	.3429	.3292		.12	.3292	.3601
5	.6859	.3856	1.0974		.12	.2743	
6	.6859	.3429	1.5546		.1029	.3086	.3944
7	.6859	.4382	1.5546			.3258	.4115
8	.7545	.5487	1.7741		.1029	.4115	.5144
9	.788		1.829		.12	.5144	.5144
10	1.0117	.9602	1.7147		.583		.1029
11	.9774	1.0242	1.1145	.6584	.8573		.1372
12		.9877	1.0802	.5487	.8402		.1543
13		1.0974	1.1145	.5121	.8402		.3429
14		1.0974	1.1145	.9328	.7716		.1029
15		.9877	1.1488	.823	.7716		.1029
16		1.0974	1.1831	.823	.7716		.1029
17	.9088	.9145	1.0974	.7316	.7888		.12
18	.583	.9877	1.1317	.2195	.6687		.1372
19	.6001	.9145	1.5947	.2012	.1829		.1029
20	.4973	.6584	1.5947	.1829	.1646		.12
21	.463	.5304	1.4232	.2012	.1646		.1029
22	.4287		1.286	.2378	.1646		.1029
23	.3429	.3109		.2195	.1463		
24	.703	.3086	.3109		.1886	.1463	.2572
Max	1.0117	1.0974	1.829	.9328	.8573	.5144	.5144
Min	.3429	.2401	.3109	.1829	.1029	.1463	.1029
Avg	.6705	.6693	1.1312	.4840	.3824	.3115	.2294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 203 / 11kv Borgaon AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2401	.3658		.1829	.0857	.0857
2	.2058	.2058	.3658		.2012		.0857
3	.2058	.2058	.3658		.2378		.0857
4	.2401	.1715	.3475		.2561		.0857
5		.1715	.3475		.2743		.0857
6	.1715	.2058	.3475		.2743		.0857
7	.1886	.4287	.5487		.2012		.1029
8	.2058	.6859	.7316		.4024		.1029
9	.2058		.8779		.3658		.8745
10	.2058	.9259	.1029		.0914		
11	.3601	.9694	.12	.0732	.0732		
12	.4458	.3658	.1886	.0732	.0732		
13		1.2254	.1886	.0732	.0732		.8059
14	.5658	1.2254	.1886	.0732	.9694		.583
15	.6173	1.2803	.2743	.0732	.0732		.6859
16	.703	1.3535	.0686	.0732	.0732		.7716
17	.12	1.262		.0732	.0732		.6859
18	.6687	1.2071		.1463	.0732		.7373
19	.583	1.0974		.128	.0716		
20	.3601	.8962		.0732	.0914		.1372
21	.3258	.7865		.0732	.0914		.0343
22	.3086	.6767		.0732	.0914		.0343
23	.2743	.5853		.0732	.0857		.0343
24	.1886	.2743	.5487		.5121	.0857	.1715
Max	.703	1.3535	.8779	.1463	.9694	.0857	.8745
Min	.12	.1715	.0686	.0732	.0716	.0857	.0343
Avg	.3336	.7151	.3517	.0830	.2047	.0857	.3138



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 204 / 11 KV Arni Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	1.3717	1.6095		1.262	1.39	1.166
2	1.166	1.3032	1.5729		1.2986	1.3535	
3	1.1831	1.2346	1.5729		1.2986	1.3535	1.1831
4		1.3546	1.5729		1.3717	1.3535	1.2174
5	1.2174	1.4403	1.5729		1.4632	1.39	1.3375
6	1.2003	1.4918	1.5729		1.5546	1.39	1.3546
7	1.3717	1.5203	1.4815		1.5729	1.39	1.3717
8	1.3889	1.3203	1.2986		1.4815	1.3352	1.286
9	1.3889		1.2437		1.4632	1.166	
10	1.286	1.166			1.2437		
11	1.1831	1.2803	1.2517	1.39	.2012		
12	1.2517	1.2803	1.3032	1.1888	1.2071		
13	1.2174	1.2803		1.3169			
14	1.1831	1.2803		1.2071			
15	1.0974	1.2254		1.2803	1.0059		
16	1.1488	1.2803		1.1888	1.0791		
17	1.0117	1.2071		1.134	1.0791		
18		1.262		1.2803	1.262		
19		1.4998		1.2986	1.2803		
20	1.4232	1.5364		1.3717	1.3169		
21	1.4232	1.5546		1.2803	1.3535		
22	1.4575	1.6461	1.2517	1.3717	1.4266		
23	1.5089	1.6095		1.2803	1.4266		
24	1.5261	1.4403	1.6095		1.262	1.4266	1.1831
Max	1.5261	1.6461	1.6095	1.39	1.5729	1.4266	1.3717
Min	1.0117	1.166	1.2437	1.134	.2012	1.166	1.166
Avg	1.2738	1.3733	1.4549	1.2761	1.2687	1.3548	1.2624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 205 / EXPRESS FEEDER

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0366		.0366	.0366	
2	.0343	.0343	.0366		.0366	.0366	.0343
3	.0343	.0343	.0366		.0366	.0366	.0343
4	.0343	.0343	.0366		.0366	.0351	.0343
5	.0343	.0343	.0366		.0366	.0366	.0343
6	.0343	.0343	.0366		.0366	.0366	.0343
7	.0343	.0351	.0366		.0366	.0366	.0343
8	.0343	.0343	.0366		.0366	.0366	.0343
9	.0351		.0366		.0366	.0343	.0343
10	.0343	.0343	.0343		.0366		.0343
11	.0343	.0366	.0343	.0366	.0366		.0343
12	.0343	.0366	.0343	.0366	.0366		.0343
13	.0343	.0366	.0343	.0366	.0366		.0343
14	.0343	.0366	.0343	.0366	.0366		.0343
15	.0343	.0366	.0343	.0366	.0366		.0343
16	.0343	.0366	.0343	.0366	.0366		.0343
17	.0343	.0366	.0343	.0366	.0366		.0343
18	.0343	.0366	.0343	.0366	.0366		.0343
19	.0343	.0366		.0366	.0366		.0343
20	.0343	.0366		.0377	.0366		.0343
21	.0377	.0366		.0366	.0366		.0343
22	.0343	.0366		.0366	.0366		.0343
23	.0343	.0366		.0366	.0366		.0343
24	.0343	.0343	.0366		.0351	.0366	.0343
Max	.0377	.0366	.0366	.0377	.0366	.0366	.0343
Min	.0343	.0343	.0343	.0366	.0351	.0343	.0343
Avg	.0345	.0356	.0355	.0367	.0365	.0362	.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 206 / 11 KV JAWALA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.9259	1.0608		1.0791	.9877	.8402
2	.8402	.8573	1.0242		1.0608	1.0185	.8745
3	.8745	.823	1.0242		1.0791	.9511	.8745
4	.9431	.8402	1.0242		1.1157	.9511	.9945
5	.9945	.9259	1.0974		1.0974	.9511	1.0288
6	1.166	1.0288	1.262		1.2254	.9877	1.0631
7	.9431	1.0802	1.134		1.1157	1.0586	1.0974
8	.9774	.9945	1.0974		1.1595	.9815	1.0288
9	.8573		.9694		.7316	.7373	.8573
10	.6001	.5144	.7373		.6401		.5487
11	.463	.6401	.4801	.4572	.5504		.4115
12	.5144	.6219	.4973	.439	.4207	.4115	.4115
13	.5144	.6401	.4973	.439	.4572	.3772	.3944
14	.5487	.6401	.4973	.5853	.4572	.3429	.4287
15	.5487	.6401	.4973	.567	.4024		.4458
16	.5487	.6767	.4973	.6036	.5304		.3944
17	.583	.6401	.6001	.6401	.5121	.4115	.1543
18	.6859	.9694	.8059	.8779	.8048	.3086	.4801
19	1.0679	1.2437	1.166	1.134	.8048		
20	1.166	1.2437	1.1317	1.0608	1.0608	.9774	
21	1.0802	1.1523	1.0802	.9328	1.0974		
22		1.0608	.9945	1.0974	1.0242		
23		1.0608		1.0791	.9877		
24	.8745	.9602	1.0608		1.0059	1.0242	.8745
Max	1.166	1.2437	1.262	1.134	1.2254	1.0586	1.0974
Min	.463	.5144	.4801	.439	.4024	.3086	.1543
Avg	.8007	.8774	.8799	.7626	.8509	.7799	.6949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304006 / 33 KV ARNI

Feeder No / Name : 207 / 11 kv KAPESWAR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.695		.5487	.5682
2		.7316		.6235	.5853
3		.7316		.6767	.5853
4		.7316		.695	.5487
5		.7316		.7316	.5487
6		.7316		.7682	.5487
7		.8048		.7164	.5487
8		.695		.695	.7133
9		.6036		.439	
10	.3772				
11	.4207		.2195	.4207	
12	.2743		.1829	.3109	
13	.2915		.2743	.3109	
14	.2915		.3109	.3148	
15	.4287		.2926	.3148	
16	.4458		.2926	.3292	
17	.4801		.3475	.3475	
18	.6001		.5304	.567	
19	.5487		.7499	.7865	
20	.5658		.7316	.7865	
21			.695	.7682	
22	.703		.7316	.695	
23	.695		.695	.6584	
24		.695		.6401	.6584
Max	.703	.8048	.7499	.7865	.7133
Min	.2743	.6036	.1829	.3109	.5487
Avg	.4710	.7151	.4657	.5715	.5895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304018 / 33KV LONBHEL

Feeder No / Name : 201 / 11kv kosdani

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.6344	.567		.5658	.5914	.5144
2	.583	.6344	.5729		.5658	.567	.5144
3	.5658	.6173	.5487	.5658	.5658	.567	.5144
4	.5658	.6173	.5544	.583	.5658	.567	.4973
5	.5658	.6173	.5487	.5658	.5658	.5853	.4973
6	.6173	.6173	.5853	.583	.583	.5853	.5316
7	.6001	.5487	.5853	.6001	.6001	.5853	.5316
8	.5487	.5658	.6036	.5487	.5487	.5487	.4801
9		.6001	.6036	.5487	.6001	.5304	.4801
10		.6687	.5853			.5121	.4287
11		.6687	.6859				.3944
12	.583	.695	.8059	.5144	.5544		
13	.583	.7865	.7373	.4287	.5121	.4115	.4115
14	.5658	.7682	.7716	.4458	.5853	.3944	.4287
15	.6516	.5853	.7202		.5487	.4115	.4287
16	.6859	.6401	.3944	.4973			.4287
17	.6344	.8962	.4801	.4801	.567		
18	.6516	.6584	.7202	.5487	.5729		.463
19	.703	.8413	.7716	.6687	.6401		.4973
20	.7202	.8779	.8059	.6859	.6401	.5487	.5487
21	.6859	.6767	.703	.6344	.6283	.5316	.5487
22	.6516	.6401	.6859	.6173	.6219	.5316	.5316
23	.6344	.6036	.6001	.583	.6219	.5144	.5316
24	.583	.6173	.5853	.6001	.5658	.6036	.5144
Max	.7202	.8962	.8059	.6859	.6401	.6036	.5487
Min	.5487	.5487	.3944	.4287	.5121	.3944	.3944
Avg	.6173	.6699	.6343	.5631	.5819	.5326	.4871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304018 / 33KV LONBHEL

Feeder No / Name : 202 / 11kv Sukali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4115	.5175		.4115	.439	.3772
2	.3772	.3944	.5121		.4115	.439	.3601
3	.3772	.3944	.4938	.3601	.4115	.4024	.3772
4	.3601	.3772	.499	.3429	.4115	.4024	.8745
5	.3772	.3944	.5121	.3601	.4287	.4207	.3772
6	.4458	.4458	.5853	.463	.4801	.4755	.3601
7	.4801	.5316	.6767	.4287	.5144	.4938	.3944
8	.4458	.6001	.6767	.4287	.463	.3109	.3772
9		.5487	.6584	.3772	.4115	.2561	.3429
10		.5487	.4572			.2378	.2915
11		.5144	.5316				.2401
12	.4115		.5658	.3086	.1097		
13	.4287		.5487	.3258	.0739	.3086	.2229
14		.7316	.6173	.3429	.4251	.3086	.2743
15	.4801	.4755	.5658		.5304	.3086	.2743
16	.463	.1463	.5658	.3944	.499	.3601	.2743
17	.6344	.7316	.6859	.3601	.462	.3772	
18	.6687	.5853	.6516	.463	.4938		.2229
19	.6173	.5853	.6859	.4973	.4435	.4287	.3601
20	.6173	.6584	.6516	.5316	.5121	.4115	.3772
21	.5487	.695	.6001	.463	.4572	.4458	.4973
22	.4801	.6401	.5487	.463	.4572	.4287	.463
23	.4287	.567	.463	.4287	.4572	.3944	.463
24	.3944	.4287	.4755	.4458	.4458	.439	.3772
Max	.6687	.7316	.6859	.5316	.5304	.4938	.8745
Min	.3601	.1463	.4572	.3086	.0739	.2378	.2229
Avg	.4707	.5185	.5728	.4097	.4232	.3852	.3718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304018 / 33KV LONBHEL

Feeder No / Name : 203 / 11kv Lonbhel

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1109		.1029	.0914	.1029
2	.1029	.1029	.1097		.1029	.0914	.0514
3	.1029	.1029	.0914	.1029	.1029	.0914	.0857
4	.1029	.1029	.0914	.1029	.1029	.0914	.0857
5	.1029	.1029	.0732	.1029	.1029	.0914	.0857
6	.1029	.1029	.0914	.0857	.0857	.1097	.0857
7	.0857	.1029	.1097	.0857	.0857	.0732	.0857
8	.0857	.12	.0914	.1029	.0686	.0732	.0857
9		.1029	.0732	.0857	.0686	.0549	.0857
10		.0857	.0914			.0549	.0686
11		.0343	.0514				.0343
12	.0857	.0366	.0514	.0686	.0549		
13	.0857	.1097	.0514	.0343	.0549	.0343	
14	.0686	.0732	.0514	.0343	.0366	.0343	
15	.0686	.0366	.0514		.0183	.0343	.0514
16	.0857	.0914	.0514	.0343	.037		.0514
17	.0857	.0914	.0857	.0514	.0732		
18	.0343	.1097	.0857	.0686	.0732		.0686
19	.12	.1097	.12	.1029	.1097		.0857
20	.1372	.1294	.1372	.1029	.0924	.12	.1029
21	.1372	.128	.12	.1029	.1097	.12	.12
22	.12	.128	.12	.1029	.1097	.12	.1029
23	.1029	.1097	.1029	.1029	.1097	.1029	.1029
24	.1029	.1029	.1097	.1029	.1029	.0914	.1029
Max	.1372	.1294	.1372	.1029	.1097	.12	.12
Min	.0343	.0343	.0514	.0343	.0183	.0343	.0343
Avg	.0963	.0966	.0885	.0830	.0821	.0822	.0823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304018 / 33KV LONBHEL

Feeder No / Name : 204 / 11kv Anjenkhed

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4458	.439		.3944	.4024	.3944
2	.3601	.4458	.4572		.3944	.4024	.3772
3	.3772	.4287	.439	.3944	.3944	.4024	.3944
4	.3601	.4458	.439	.3772	.3944	.3841	.3944
5	.3772	.4287	.4755	.3944	.4115	.4207	.3944
6	.4287	.4801	.5121	.4287	.4458	.4938	.463
7	.4801	.5487	.5487	.4458	.4973	.5304	.463
8	.4801	.5144	.5853	.4287	.4458	.5487	.4973
9		.5487	.6036	.3772	.4287	.4755	.4115
10		.4287	.3658			.3109	.2572
11		.3601	.3772				.1715
12	.3601	.3696		.2058	.2195		
13	.3601	.4207	.3772	.1715	.2378	.2058	.1886
14	.2743	.3658	.3944	.2229	.2378	.2229	.2058
15	.2915	.2561	.3258		.2378	.2229	.2058
16	.2915	.3475	.3772	.2572	.2561	.2572	.2915
17	.3258	.5121	.4115	.2915	.3326	.3086	
18		.5853	.5658	.4115	.4207		.3944
19	.5487	.5304	.5487	.4801	.5487	.4458	.4458
20	.4973	.5304	.5144	.463	.4805	.463	
21	.463	.5175	.463	.4458	.462	.4458	.4287
22	.4458	.499	.4458	.4287	.4572	.4287	.3772
23	.4458	.4755	.3944	.463	.4572	.4115	.3429
24		.4458	.4572	.3944	.4115	.4207	.3944
Max	.5487	.5853	.6036	.4801	.5487	.5487	.4973
Min	.2743	.2561	.3258	.1715	.2195	.2058	.1715
Avg	.3962	.4555	.4573	.3727	.3894	.3907	.3568



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304026 / 33KV LONI

Feeder No / Name : 201 / 11kv Loni

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8587	.6413	1.251	1.0365	1.0018
2		.7872	.644	1.251	1.0376	1.0018
3		.7156	.6798	1.251	1.0688	1.0018
4		.7156	.6791	1.251	1.108	1.0018
5		.7156	.7458	1.251	1.134	1.0018
6		.7156	.8194	1.251	1.2152	1.0018
7		.7156	.7872	1.251	1.2826	1.0018
8		.7156	.7514		1.3466	1.0018
9			.7125	1.2867	1.2826	1.3954
10		.6798	.7156	1.3403	1.134	1.1449
11		.7156		1.4297		.4755
12		.7156	.8587	1.5011		1.1449
13		.7872	.7872	1.1449	.9839	1.1437
14			.8229		.8587	1.1437
15	1.467		.8229			1.1437
16	1.4312	.9303	.8229	1.3538	.8945	
17	1.8248	.9661	.8408	1.3895	1.0018	
18	1.8605	.9313	.8587	1.3895	1.1449	1.0722
19	1.1807	.7872	1.5011	1.2113	1.1449	1.251
20	2.111	.8194	1.4654	1.2403	1.1449	1.7156
21	2.0394	.7514	1.4297	1.2113	1.1092	1.7156
22	2.0037	.7156	1.4297	1.134	1.0734	1.7871
23	1.789		1.251	1.1449	1.0018	1.8586
24		1.789		1.251	1.0734	1.0018
Max	2.111	1.789	1.5011	1.5011	1.3466	1.8586
Min	1.1807	.6798	.6413	1.134	.8587	.4755
Avg	1.7453	.8264	.9121	1.2755	1.0989	1.1822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304026 / 33KV LONI

Feeder No / Name : 202 / 11kv Factory

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7156	1.5758	.7004	.6653	.4552	.4902	.6653
2	.7004	1.5758	.7004	.6653	.4552	.4902	.6653
3	.7004	1.5758	.7004	.6303	.4552	.4902	.6653
4	.7004	1.5758	.7004	.6303	.4902	.5258	.6653
5	.7004	1.5758	.7004	.6646	.5253	.5953	.6653
6	.7004	1.5758	.7004	.6624	.5953	.6296	.6653
7	.7004	1.5758	.7004	.7004	.6653	.6653	.6653
8	.7004	1.7509	.7004	.7004		.6303	.5253
9	.8404	1.8209		.6653		.5953	.5603
10	.8404	1.7509	.3852	.5953		.5247	.2801
11	.7354	1.4007	.5253		.7004		.6303
12	.7354	1.2256	.6653	1.4357	.8404		.5253
13	.7704	1.2606	.7004	1.4357	.8404	.2626	.4902
14	.8404	1.3307	.4202	1.3657	.7704	.2626	.4377
15	1.8559	.8404		.9455			.3502
16	1.7859	.8404	.4902	.8404	.6996	.3502	
17	1.8209	.8054	.6646	.8054	.6653	.3502	
18	1.8209	.7704	.7004	.8404	.7704	.5603	.3502
19	1.8209	.8054		.7004	.7354	.7004	.3502
20	1.7509	.8404		.7004	.6996	.7004	.3502
21	1.7509	.8404	.6653	.7004	.6653	.7004	.3502
22	1.6108	.7004	.7004	.6303	.5953	.7004	
23	1.5758	.7004	.7004	.4377	.5603	.5953	
24	.7004	1.5758	.7004		.4552	.5253	.6653
Max	1.8559	1.8209	.7004	1.4357	.8404	.7004	.6653
Min	.7004	.7004	.3852	.4377	.4552	.2626	.2801
Avg	1.1198	1.2621	.6461	.7917	.6320	.5402	.5261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304026 / 33KV LONI

Feeder No / Name : 203 / 11kv Mahagaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6235	.6235	.6128	.5682	.6235	.5327	.6057
2	.6057	.6235	.6128	.57	.6235	.5344	.6413
3	.6057	.6235	.6653	.5344	.6413	.5344	.6413
4	.6413	.7125	.7004	.6057	.6413	.6057	.7125
5	.6591	.7125	.7004	.6392	.6413	.6769	.7482
6	.6947	.7125	.8404	.6947	.7125	.7103	.7838
7	.7304	.7304	.8404	.8194	.7482	.7482	.8551
8	.7304	.7482	.9105	.8907	.7482	.8551	.8016
9	.5878	.766		.9085		.6769	.766
10	.5522	.7125	.8194	.6591		.5493	.5878
11	.4988	.6413	.6947		.6235		.5522
12	.6057	.6769	.6413	.6057	.5166		.6591
13	.57	.6591	.6413	.5878	.4453	.3563	.4988
14	.6235	.6947	.57	.5522	.4632		.3919
15	.7125	.7125	.57	.5878			.4275
16	.6947	.8372		.6235	.5327	.4275	
17	.6413	.8551	.6413	.6769	.6057	.4988	
18	.8907	.8907	.8168	.8016	.6925	.6057	.5344
19	.8907	.9085	.8551	.8907	.7442	.7482	.5344
20	.7482	.9085	.8878	.7125	.8328	.8551	.6591
21	.7125	.8194	.7125	.6769	.6947	.7482	.6235
22	.6591	.7304	.6235	.6235	.6235	.6591	.57
23	.6235	.6591	.6057	.6413	.6063	.6235	.5522
24	.6235	.6235	.6235		.6235	.5878	.6057
Max	.8907	.9085	.9105	.9085	.8328	.8551	.8551
Min	.4988	.6235	.57	.5344	.4453	.3563	.3919
Avg	.6636	.7326	.7085	.6759	.6373	.6267	.6251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304069 / YERMAL HETI

Feeder No / Name : 201 / KOPASA FEEDER Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9				.0343		
10		.4656				.0514
11		.5014		.0185		.0857
12	.4805	.6099				
13	.4435	.6099	.0358	.0739		
14	.4251	.462		.0739	.0185	.1109
15	.4805	.4805		.0554	.0739	.0924
16	.5359	.462				.1109
17	.5544	.5175			.0739	
24			.2572			
Max	.5544	.6099	.2572	.0739	.0739	.1109
Min	.4251	.462	.0358	.0185	.0185	.0514
Avg	.4867	.5136	.1465	.0512	.0554	.0903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304069 / YERMAL HETI

Feeder No / Name : 203 / VITHOLI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0895	.3224			.0343
2	.0358	.0895	.3224			.0171
3	.1612	.0537	.3326			.0343
4	.0358	.0537	.3224			.0343
5	.3761	.0537	.3224			.0171
6	.0358	.0895	.3224			.0343
7	.0537	.1075	.3224			.0343
8	.0716	.1254	.3403			.0343
9		.1254	.3403			.0343
10			.3224			
11			.3224			
12			.3761	.0537	.0358	
13			.4119	.0358	.0739	
14			.4298	.0358	.1478	
15			.4119	.0358	.037	
16			.4656	.0358	.037	
17			.394	.0358	.0554	
24	.0358	.0895	.3224			.0171
Max	.3761	.1254	.4656	.0537	.1478	.0343
Min	.0358	.0537	.3224	.0358	.0358	.0171
Avg	.0935	.0877	.3558	.0388	.0645	.0291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304069 / YERMAL HETI

Feeder No / Name : 204 / HETI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.2328	.2328		.2058	.2058	.2058
2	.1612	.2328	.2328		.2058	.2058	.2058
3	.1612	.2328	.2328		.2229	.2229	.1715
4	.1612	.2328	.2328		.2229	.2229	.1715
5	.1612	.2328	.2328		.2229	.2058	.1715
6	.1612	.2507	.2328		.2229	.2229	.1715
7	.2149	.2507	.2328		.2058	.2229	.1715
8	.1791	.2686	.2507		.2229	.2229	.2572
9		.1791	.2149	.1029	.2229	.2058	.1715
10		.1433	.1612			.1715	.12
11		.2328	.1433				.0857
12	.1294	.1663		.0358	.1478	.1294	.1663
13	.1294	.2033	.1075	.0537	.1478	.1109	.1294
14	.1294	.1663	.1075	.0537	.1478	.1478	.1294
15	.1294	.1478	.1433	.0716	.2772	.1478	.1294
16	.1109	.2033	.1254	.0716	.2587		.1294
17	.1109	.2033	.1791		.2033	.1848	
18	.1109	.2033	.2572	.2572	.2058		.2149
19	.1791	.2149	.2915	.2401	.2572	.2572	.2149
20	.2328	.2328	.2401	.2229	.2229	.2229	.1791
21	.2507	.2507	.2229	.2058	.2058	.2058	.1791
22	.2507	.2507	.2229		.2058	.1715	.1612
23	.2507	.2328	.2229	.2058	.2058	.2058	.1612
24	.1433	.2328	.2328	.2058	.2058	.2058	.2058
Max	.2507	.2686	.2915	.2572	.2772	.2572	.2572
Min	.1109	.1433	.1075	.0358	.1478	.1109	.0857
Avg	.1676	.2166	.2066	.1439	.2112	.1952	.1697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304069 / YERMAL HETI

Feeder No / Name : 206 / KELZARA KOMATI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4835	.6089	.6626		.5487	.5487	.5316
2	.4835	.6089	.6089		.5487	.5487	.5316
3	.4835	.591	.6089		.5487	.5487	.5487
4	.5373	.591	.591		.5658	.5658	.5487
5	.5373	.591	.591		.5658	.5658	.5487
6	.5373	.6626	.591		.6001	.6001	.6001
7	.5731	.8417	.6447		.6859	.6859	.6859
8	.5373	.8775	.7522		.5487	.6001	.5487
9		.7164	.6805	.2572	.5144	.583	.4973
10		.5373	.5731			.463	.3429
11		.4119	.5373				.2572
12	.4251		.4119	.2149			.0924
13	.4066	.4805	.1433	.1791	.3696	.2957	.2033
14	.4435	.462	.1433	.1791	.3326	.3326	.3326
15	.4066	.4477	.4298	.2328	.3326	.2587	.3142
16	.3696	.4805	.4477	.2328	.1848		.3696
17	.499	.6468	.5731	.2686	.2218	.3881	
18	.5544	.7207	.703	.4287	.5487		.4835
19	.5373	.7522	.7716	.463	.7716	.7202	.6805
20	.6268	.788	.7202	.5144	.6859	.6344	.591
21	.6268	.788	.6859	.5316	.6001	.6001	.5731
22	.6468	.788	.6344	.5487	.5316	.5487	.5194
23	.6089	.7164	.6001	.5316	.5316	.5144	.5194
24	.5194	.6089	.6805	.6001	.5316	.5316	.5144
Max	.6468	.8775	.7716	.6001	.7716	.7202	.6859
Min	.3696	.4119	.1433	.1791	.1848	.2587	.0924
Avg	.5164	.6399	.5744	.3702	.5128	.5267	.4711

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304070 / KRUSHNAGAR(SAWALI)

Feeder No / Name : 201 / AYATA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4115	.3772
2		.3601	.3772
3		.3601	.3601
4		.3601	.3601
5		.3601	.3601
6		.4115	.3601
7		.4287	.3601
8		.3601	.3601
9		.2572	.3601
10		.12	.3429
11			.2401
12		.2572	.2572
13		.2229	.1715
14		.1543	.1715
15		.1543	.2058
16		.2572	
17	.3601	.2572	
18	.4458	.3772	
19	.4115	.4287	
20	.4458	.2572	
21	.463	.3944	
22	.4458	.3944	
23	.4115	.3772	
24		.4115	.3772
Max	.463	.4287	.3772
Min	.3601	.12	.1715
Avg	.4262	.3206	.3151



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304070 / KRUSHNAGAR(SAWALI)

Feeder No / Name : 202 / BELORA Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0288	1.1241	.4115	.4458
2					1.1241	.3772	.4458
3					1.1241	.3772	.4287
4	1.0631					.3772	.4287
5						.4287	.4458
6						.4973	.3601
7	1.1145					.5316	.3601
8			1.1431			.5144	.6001
9	1.1488					.4115	.5316
10				.7716		.3086	.3601
11				.7373			.3258
12	1.105	1.3336	1.3375	.703	.5716	.2572	.3086
13			1.3375	.6344	.4954	.2572	.2915
14			1.3717	.6344	.6287	.2743	.2915
15			1.6632	.6344	.743	.2572	.3086
16			1.286	.6859		.2572	
17			.823	.6859	.4763	.3601	
18			.9774	.6859	.7049	.3429	
19			1.749		.6516	.5658	
20					.4801	.583	
21				1.0117	.4801	.4973	
22			1.286	1.0117	.4458	.463	
23	1.5242	1.5242	1.286	1.0117	.4287	.4458	
24	1.1831	1.5242	1.3336	1.0288	1.1241	.4115	.4458
Max	1.5242	1.5242	1.749	1.0288	1.1241	.583	.6001
Min	1.0631	1.3336	.823	.6344	.4287	.2572	.2915
Avg	1.1898	1.4607	1.2995	.8047	.7068	.4003	.3987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304070 / KRUSHNAGAR(SAWALI)

Feeder No / Name : 203 / 11 KV SAWALI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.6001		.583	.5658
2						.5144	.5316
3						.5144	.5316
4	.6859					.5144	.5316
5						.6001	.6001
6						.6859	.7545
7	.8916					.7545	.7716
8			1.0288			.703	.703
9	.6687					.5487	.583
10				.4458		.4115	.3772
11				.4115			.3258
12	.6097		.3086	.3772	.362	.3601	
13			.3086	.3944	.381	.3601	
14			.3086	.3944	.381	.3772	.2572
15			.3429	.3944	.4001	.3601	.3086
16			.4287	.4287	.5335	.3429	
17			.5487	.5144	.5525	.4801	
18			.6859	.5144	.8002	.6687	
19			.8916		.8573	.7373	
20					.6001	.703	
21				.6516	.6516	.6173	
22			.6859	.6516	.6344	.583	
23	.7621		.6859	.6516	.6001	.5658	
24	.6859	.9907	.9526	.6001	.724	.583	.5658
Max	.8916	.9907	1.0288	.6516	.8573	.7545	.7716
Min	.6097	.9907	.3086	.3772	.362	.3429	.2572
Avg	.7173	.9907	.5981	.5022	.5752	.5465	.5291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304070 / KRUSHNAGAR(SAWALI)

Feeder No / Name : 204 / SHIVAR FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2058		.0857	.0857
2						.0857	.0686
3						.0857	.0686
4	.1029					.0857	.0857
5						.0857	.0686
6						.0867	.0857
7	.1372					.12	.12
8			.381			.12	.1372
9	.1715					.1029	.12
10				.0857		.0857	.0686
11				.0857			.0857
12	.1143	.2858	.3944	.0686	.1143	.0686	
13		.3048		.0686	.0762	.0514	
14				.0686	.0572	.0514	.0686
15				.0686	.0572	.0514	.0514
16				.0686	.0381	.0514	
17				.0686	.0381	.0686	
18				.0686	.1143	.1029	
19					.1143	.12	
20					.1029	.12	
21			.2058	.1029	.1029	.0686	
22			.2058		.1029	.0857	
23	.1905	.381	.2058	.1029	.0857	.0857	
24	.1029	.2286	.3429	.2058	.1143	.0857	.0857
Max	.1905	.381	.3944	.2058	.1143	.12	.1372
Min	.1029	.2286	.2058	.0686	.0381	.0514	.0514
Avg	.1366	.3001	.2893	.0976	.0860	.0850	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304073 / 33KV S/S BHAMB

Feeder No / Name : 201 / 11KV BORI GOSAVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2955	1.5623	1.3908	1.4289	1.3717	1.1812
2	1.1812	1.2384	1.5623	1.3908	1.448	1.3717	1.1812
3	1.1812	1.2384	1.5242	1.3908	1.448	1.3717	1.1812
4	1.1812	1.2384	1.5051	1.3908	1.448	1.3717	1.1812
5	1.2384	1.2765	1.5051	1.3908	1.5051	1.4289	1.1812
6	1.2765	1.3717	1.5813	1.3908	1.6004	1.467	1.3336
7	1.3717	1.5432	1.6956	1.7147	1.7337	1.5051	1.4098
8	1.5432	1.848	2.0957	2.0957	2.0957	1.5432	1.6766
9	1.7528			2.2862	2.21	1.7528	1.7147
10					2.0767		1.829
11	1.5623		2.0957		2.0195		1.5051
12	1.7909		2.7054				
13	1.8671	.4572	2.2481		2.0195	1.3336	
14	2.0386	2.9531			2.0005	1.1812	
15		2.7244	2.6101		1.9052	1.3336	
16	2.0005	2.9531	2.6101	1.9433	1.6575	1.2574	
17	2.0005	2.6863		2.2291	.8954	1.3336	
18	1.848	2.5149	2.6101	2.0957	1.9052	1.6385	1.3717
19	2.1338	2.3815	2.6292	2.1338	1.9624	1.7337	1.2955
20	2.0195	2.2291	2.4196	1.9624	1.9052	1.7718	1.1241
21	1.7718	1.9814	2.3624	1.829	1.6956	1.3908	1.086
22	1.6004	1.8099	2.2862	1.6575	1.5432	1.3336	1.0479
23	1.448	1.6766	2.0957	1.5242	1.3908	1.2193	1.0098
24	1.2193	1.3527	1.5623	1.4289	1.5051	1.3527	1.2003
Max	2.1338	2.9531	2.7054	2.2862	2.21	1.7718	1.829
Min	1.1431	.4572	1.5051	1.3908	.8954	1.1812	1.0098
Avg	1.5986	1.8385	2.0633	1.7359	1.7130	1.4316	1.3061

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304073 / 33KV S/S BHAMB

Feeder No / Name : 202 / CHANDAPUR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0848	.0848		
2				.0848	.1017		
3				.0848	.1017		
4				.0848	.1017		
5				.0848	.1143		
6				.1865	.2096		
7				.2374	.362		
8				.39	.4239		
9				.3391	.3561		
10		.3052					.2374
11	.407	.3391					.2374
12	.373	.3052					.2204
13	.3391	.2543				.1865	.3052
14	.2883	.2713					.2204
15		.2543				.2035	.2204
16	.3391	.3052				.2286	.1187
17	.3222	.3052				.2035	
18			.0848			.1696	
19			.2543				
20			.2543	.1696			
21			.2374	.1865			
22			.2374	.1526			
23			.2374	.1357			
24				.0678	.1187		
Max	.407	.3391	.2543	.39	.4239	.2286	.3052
Min	.2883	.2543	.0848	.0678	.0848	.1696	.1187
Avg	.3448	.2925	.2176	.1635	.1975	.1983	.2228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

ARNI S/DN.[527]

BU 5274

Substation No/ Name :- 304073 / 33KV S/S BHAMB

Feeder No / Name : 203 / CHANDAPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4572	.4382	.4382	.4001	.4382	.4191
2	.4382	.4382	.4382	.4382	.4191	.4382	.4191
3	.4382	.4382	.4382	.4382	.4382	.4191	.4191
4		.4191	.4382	.4382	.4191	.4191	.381
5	.4001	.4191	.4191	.4382	.4191	.381	.381
6	.381	.381	.4001	.4382	.4001	.381	.381
7	.2858	.2858	.3239	.3239	.3429	.3429	.3429
8	.2477	.2096	.2858	.3048	.2858	.2858	.2096
9	.2477	.2096		.2667	.2667	.2477	.2477
10					.2667		.2096
11	.2286	.2667	.2477		.2096		.1905
12	.2286	.2667	.2286		.2096		.1143
13	.2477	.2477	.2477			.1905	.1524
14	.2667	.2858			.2096	.1905	.2096
15		.3048	.2667	.2096	.2286		.2477
16	.2477	.3048	.2667	.2477	.2286	.2286	.2286
17	.2477	.2858		.2477	.2286	.2667	
18	.2477	.2858	.2477	.3048	.2286	.3048	.362
19	.4001	.3429	.4001	.4382	.4001	.4572	.4382
20	.5144	.4763	.4382	.4763	.4572	.4572	.4382
21	.4763	.4763	.4382	.4763	.4763	.4572	.4382
22	.4954	.4763	.4191	.4763	.4763	.4572	.4191
23	.4763	.4572	.4191	.4572	.4572	.4382	.4191
24	.4382	.4572	.4382	.4382	.4382	.4382	.4191
Max	.5144	.4763	.4382	.4763	.4763	.4572	.4382
Min	.2286	.2096	.2286	.2096	.2096	.1905	.1143
Avg	.3502	.3562	.3620	.3840	.3438	.3620	.3255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304007 / 33 KV BABHULAGAON

Feeder No / Name : 201 / 11 KV Karalgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8954	.6805	.7522	.7682	.6805	.5373
2	.7888	.8596	.6805	.7343	.7682	.7164	.5373
3	.7202	.8238	.6805	.7343	.7392	.7164	.5373
4	.7202	.7522	.6447	.7164	.7316	.7164	.5373
5	.6859	.7522	.6447	.7164	.7392	.4877	.5373
6	.5144	.7164	.6447				
7	.5658	.7522	.6447				
8	1.0288	1.1104	.8596				
9	1.166	1.2894	1.0029				
10	1.1488	1.4327					
11	1.3432	1.3969	1.182				
12	1.2894	1.3969	1.1999		.9313		.6584
13	1.3253	1.3253	.985		1.0029		.7095
14	1.2894	1.2894	1.0029		.8954		.4755
15	1.2894	1.2894	1.1283				.5121
16	1.1641	1.2894	1.1462		.8954		
17	1.1104	1.2894	1.0745		.7522		
18	1.0745	1.1641	.7701		.394		.5601
19	1.2536	.9671	.8059	.9511	.4298	.6984	.6219
20	1.2894	.9492	.8417	.8779	.5731	.6984	.6348
21	1.2536	.9492		.8779	.7164	.5731	.6401
22	1.2536	.9313		.8316	.7164	.5731	.7468
23	1.1104	.9313	.7522	.823	.6984	.5373	.7842
24	.9088	.9134	.788	.7522		.6805	.5373
Max	1.3432	1.4327	1.1999	.9511	1.0029	.7164	.7842
Min	.5144	.7164	.6447	.7164	.394	.4877	.4755
Avg	1.0480	1.0611	.8647	.7970	.7345	.6435	.5980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304007 / 33 KV BABHULAGAON

Feeder No / Name : 203 / 11 KV Pahur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.8954	.3224	.3582	.5121	.3224	.2507
2	.6859	.8954	.2507	.3224	.5121	.3582	.2507
3	.6516	.8775	.2507	.2865	.5121	.3582	.2401
4	.6173	.8417	.2507	.2507	.5175	.3224	.2507
5	.6001	.8238	.1791	.2149	.5121	.3224	
6	.5658	.8238	.1791				
7	.583	.8596	.1612	.2149			
8	.7716	.9313	.5373				
9	.8573	1.1104	.6984				
10	.8916	1.1641	.6984				
11	1.0745	1.1999	.7701				
12	1.0029	1.1999	.8059		.5731		.1294
13	.9313	1.1999	.788		.6984		.4481
14	.9671	1.0924	.7522		.7522		.4572
15	.8954	1.0208	.7164				.4755
16	1.0745	1.0208	.6447		.7522		
17	1.0208	1.0208	.6268	1.0608	.7164	.2507	
18	1.0745	.9671	.6805	1.1088	.2149	.2507	.4108
19	1.1641	1.0745	.5014	.8779	.2507	.2507	.4854
20	1.1104	1.0745	.5014	.8048	.3582	.2507	.5175
21	1.0745	1.0924		.8131	.394	.2507	.5228
22	1.0745	.8596		.7842	.3582	.2507	.5121
23	.9313	.5731	.4656	.695	.3761	.2507	.4854
24	.7373	.9313	.5373	.4287	.6283	.3224	.2507
Max	1.1641	1.1999	.8059	1.1088	.7522	.3582	.5228
Min	.5658	.5731	.1612	.2149	.2149	.2507	.1294
Avg	.8782	.9813	.5145	.5872	.5082	.2893	.3791



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304007 / 33 KV BABHULAGAON

Feeder No / Name : 204 / 11 KV G &amp; P

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322	1.0745	1.0387	.8573	.8779	.5194	.394
2	.8059	.9313	1.0387	1.0745	.8779	.5731	.394
3	.8322	.8954	1.1104	.985	.8048	.6447	.394
4	.8149	.8417	1.1104	.9492	.8131	.6089	.394
5	.8238	.788	1.1104	.9313	.8048	.5731	.3772
6	.7975	.788	1.1104			.0179	.0358
7	.8059	.5731	1.1462			.0179	.0358
8	1.2003	1.1104	1.0745			.0179	.0358
9	1.3003	1.4327	1.0029			.0179	.0358
10	1.3611	1.4685				.0179	.0358
11	1.4685	1.4327	1.6118				.439
12	1.4327	1.0029	1.6297		.8238		.5228
13	1.4327	.9671	1.6118		.8954		.7095
14	1.3611	1.1641	1.5223		.9313		.4024
15	1.3611	1.3969	1.4327				.4668
16	1.4327	1.4864	1.3073		.9313	.5194	
17	1.2894	1.5581	1.2536		.8954		
18	1.4327	1.4327	1.3432		.8238	.4477	.6535
19	1.4327	1.3253	1.2536	1.2803	.7164	.4477	.7095
20	1.3611	1.2894	1.0745	1.134	.7522	.4477	.7468
21	1.2894	1.2357		1.0974	.7164	.4477	.7468
22	1.2536	1.1462		1.0608	.7164	.4477	.7842
23	1.2536	1.1462	.8596	.9145	.394	.4477	.7095
24	.8402	1.1104	1.0387	.8238	.8779	.4477	.4477
Max	1.4685	1.5581	1.6297	1.2803	.9313	.6447	.7842
Min	.7975	.5731	.8596	.8238	.394	.0179	.0358
Avg	1.1757	1.1499	1.2229	1.0098	.8031	.3701	.4305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304007 / 33 KV BABHULAGAON

Feeder No / Name : 205 / BABHULGAON URBAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5731	.4298	.4458	.4755	.5373	.3224
2	.4115	.5373	.4298	.4477	.4481	.4656	.3224
3	.3944	.4835	.4298	.4477	.439	.4298	.3224
4	.3944	.4835	.4298	.4656	.4435	.394	.3224
5	.3772	.4298	.4298	.4477	.3658	.3582	.3224
6	.3429	.4298	.4298	.4298	.3658	.3582	.3224
7	.3601	.4477	.4298	.4477	.3696	.3582	.3224
8	.4287	.4477	.4298	.4656	.3841	.3582	
9	.463	.5373	.4298	.4656	.3881	.3224	.4298
10	.4801	.5373		.5014	.3696	.3582	
11	.5731	.5373	.4656				.4207
12	.5373	.5373	.4656		.4298		.4207
13	.5014	.5373	.591		.4477		.4435
14	.5014	.5373	.5731		.4477		.4207
15	.4835	.5373	.5731				.4066
16	.5373	.5373	.591		.4477		
17	.5014	.5373	.583		.4298	.394	
18	.5373	.5373	.5373		.4656	.3582	.4668
19	.6447	.5373	.5731	.499	.5373	.3582	.5228
20	.6447	.5014	.5373	.6219	.5792	.3582	.5228
21	.6447	.4298		.5853	.6447	.3582	.5228
22	.6268	.4298		.5601	.6268	.3224	.5228
23	.6089	.4298	.4835	.5175	.5731	.3224	.5228
24	.4287	.6089	.4298	.4656	.4755	.5731	.3224
Max	.6447	.6089	.591	.6219	.6447	.5731	.5228
Min	.3429	.4298	.4298	.4298	.3658	.3224	.3224
Avg	.4931	.5059	.4891	.4884	.4615	.3880	.4101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304036 / 33 KV DABHA

Feeder No / Name : 201 / 11 Kv Dabha Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1715	.2667	.1715		
2			.1715	.2667	.1905		
3			.1715	.2667	.1905		
4			.1715	.2477	.1905		
5			.1905	.2477	.2096		
6			.2286	.2477	.2667		
7			.3429	.362	.2667		
8			.3048	.4191	.2667		
9			.4001	.4191	.3048		
10		.4001				.1905	.2858
11	.381	.5716					.3429
12		.4763				.1334	.381
13	.4191	.5144				.1524	
14	.381	.4763					.1905
15	.381	.4191					.1905
16	.381	.4763					
17	.4001	.3239				.1905	
24			.1715	.2667	.1715		
Max	.4191	.5716	.4001	.4191	.3048	.1905	.381
Min	.381	.3239	.1715	.2477	.1715	.1334	.1905
Avg	.3905	.4573	.2324	.3010	.2229	.1667	.2781

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304036 / 33 KV DABHA

Feeder No / Name : 202 / 11 KV Galawi Ag

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	.5906	.381	.4954	.6668	.5144
2	1.0479	1.105	.5906	.381	.4954	.6668	.5525
3	.9526	.9907	.5906	.381	.4954	.6668	.5525
4	.9526	.9907	.5716	.3429	.4572	.6668	.5716
5	.9526	.9907	.5716	.3429	.4572	.5716	.6097
6	.8573	1.086	.5335	.3429	.4382	.5716	.6097
7	1.3336	1.3336	.4191	.3429	.4191	.5716	.6478
8	1.5242	1.4098	.4001	.3239	.362	.381	.7049
9	1.5242	1.4098	.4001	.2667	.3429	.381	.8383
10		.4001	1.5623	1.3146	1.0098	.2286	.0762
11	.3048	.381	1.6004	1.5242			.2477
12		.381		1.2384	1.2384	.2286	.2286
13	.3429	.381		1.2003	1.2384	.1905	
14	.3429	.4191	1.5242	1.1812	1.1431		.2286
15	.3429	.4191	1.4098	1.1431	1.0479		.2286
16	.3429	.4191	1.3908	1.0669	1.2384	.2667	
17	.362	.4001	1.2955	1.105	.3048	.2667	
18	.4382	.4572	1.2955	.4191	.381	.3429	.362
19	.4954	.4763		.4954	.4763	.4191	.4572
20	.6097	.6287		.6668	.5716	.5144	.4572
21	.5906	.6478		.6287	.5716	.4763	.2286
22	.5716	.6478		.6097	.5716	.4572	.4382
23	.5525	.6097	.4382	.6097	.5716		.4954
24	1.1431	1.1431	.5906	.4191	.4954	.6668	.4954
Max	1.5242	1.4098	1.6004	1.5242	1.2384	.6668	.8383
Min	.3048	.381	.4001	.2667	.3048	.1905	.0762
Avg	.7603	.7597	.8764	.6970	.6445	.4601	.4545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304036 / 33 KV DABHA

Feeder No / Name : 203 / 11 Kv Dabha Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.4001	.3048	.2858	.3429	.3048	.3048
2	.3239	.4001	.3048	.2858	.3429	.3048	.3048
3	.3239	.4001	.3048	.2858	.3429	.2858	.3048
4	.2858	.4001	.3048	.2858	.3239	.2858	.3048
5	.2858	.362	.3048	.2858	.3239	.2858	.2858
6	.2667	.2667	.2667	.2858	.2667	.2667	.2858
7	.1905	.1905	.2096	.2286	.2096	.2096	
8	.1905	.1905	.1905	.1905	.2096	.1905	.1905
9	.1715	.1905	.1715	.1905	.1715	.1715	.1905
10		.1905	.1524	.1905	.1715	.1524	.1905
11	.1524	.1715	.1334	.1524			.1905
12		.1905		.1524	.1715	.1334	.1524
13	.2096	.2096		.1334	.1715	.1524	
14	.2477	.2286		.1524	.1715		.1524
15	.2477	.2477		.1524	.1905		.1715
16	.2286	.2477	.1905	.1524	.1905	.1715	
17	.1905	.1143	.1905	.1334	.1524	.2667	
18	.1715	.1143	.1905	.1905	.2096	.1334	.1715
19	.2477	.2286		.2286	.2477	.3048	.2286
20	.3429	.3239			.3239	.3048	.362
21	.362	.3429			.3429	.3239	.362
22	.381	.362			.3429	.3239	.362
23	.381	.3429	.3239	.362	.3239		.3429
24	.3239	.381	.3239	.3048	.3429	.3048	.3239
Max	.381	.4001	.3239	.362	.3429	.3239	.362
Min	.1524	.1143	.1334	.1334	.1524	.1334	.1524
Avg	.2659	.2707	.2417	.2205	.2560	.2439	.2591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304064 / 33 KV SAWAR

Feeder No / Name : 201 / 11 KV SAWAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3258	.3439	.3077	.3429	.3086	.2743
2	.3086	.3258	.3258	.3077	.3429	.3086	.2743
3	.3086	.3258	.3439	.3077	.3429	.3086	.2915
4	.3086	.3258	.3439	.3439	.3429	.3086	.2915
5	.3429	.3429	.3982	.362	.3429	.285	.3258
12	.5487	.6516		.4458	.5316	.3429	.4115
13	.4458	.4887		.4458	.463	.2743	.3772
14	.4458	.4525		.4287	.4115	.3086	.2229
15	.4287	.4163		.4287	.3772	.2915	.2058
16	.4458	.4163		.4024	.3772	.2572	.2229
17	.463	.4525		.4287	.3601	.2743	.2401
18	.4973	.5611	.4525	.4409	.3429	.3429	.3429
19	.4801	.4887		.4801	.3561	.3944	.3429
20	.463	.4525		.4458	.3601	.3429	.3429
21	.4287	.4163		.4115	.3601	.3258	
22	.3772	.3982	.3982	.3944	.3601	.3086	
23	.3429	.362	.3439	.3772	.3429	.2915	
24	.3258	.3258	.3439	.3258	.3561	.3429	.2743
Max	.5487	.6516	.4525	.4801	.5316	.3944	.4115
Min	.3086	.3258	.3258	.3077	.3429	.2572	.2058
Avg	.4039	.4183	.3660	.3936	.3730	.3121	.2961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304064 / 33 KV SAWAR

Feeder No / Name : 203 / 11 KV GALWA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4973	.5611	.4887	.5144	.4115	.3429
2	.3772	.4973	.5792	.4706	.5144	.4115	.3429
3	.3772	.4973	.6154	.4887	.4801	.3944	.3429
4	.3772	.4973	.6154	.4887	.4801	.407	.3772
5	.4287	.5144	.6154	.4887	.4801	.3856	.3944
12		.6878		1.2003	.7122	.4287	.463
13		1.3032		1.2209	.703	.4287	.4458
14		1.2489		1.0288	.4458	.4801	.2915
15	.9431	1.267		.9431	.4287	.4801	.3601
16	.9602	1.3032		.8817	.4115	.4115	.3772
17	.9431	1.267		.8573	.4115	.3944	.3944
18	.8916	1.1584	1.1765	.8573	.407	.4287	.3772
19	.9088	1.1041		.8745	.4287	.4458	.3944
20	.7888	.9774		.8059	.4287	.4287	.4115
21	.6516	.8507		.7122	.4191	.4287	
22	.583	.6335	.5973	.6001	.4239	.4115	
23	.5487	.6154	.5068	.5765	.407		
24	.4115	.4973	.5792	.4887	.5487	.407	.3429
Max	.9602	1.3032	1.1765	1.2209	.7122	.4801	.463
Min	.3772	.4973	.5068	.4706	.407	.3856	.2915
Avg	.6390	.8565	.6496	.7485	.4803	.4226	.3772

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304082 / 33KV SARUL SUBSTATION

Feeder No / Name : 201 / 11KV FALEGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5256	.503	.6068	.8573	.5316	.503	.7628
2	.5197	.5087	.5895	.8573	.5316	.4641	.7455
3	.5375	.503	.5895	.8573	.5197	.431	.7455
4	.5087	.4917	.5721	.8573	.5316	.4024	.7455
5	.5144	.4748	.5721	.8402	.3485	.3521	.7455
6	.4024		.5548				
7	.373		.7282				
8	.5487		1.0056				
9			1.0402				
10			1.0576				
11			1.0402				
12	.8288	1.0056	1.0229	.8648	.2915	.4458	
13	.8619	1.0402	1.0288	.7712	.3353	.7716	.6859
14	.7459	.8322	1.0288	.7545		.7282	.6859
15	.7956	.7975	.8669	.6133	.5761	.823	.6859
16	.7712	.7802	.9431	.6104	.6009	.9088	.5895
17	.7377	.7108	.9774	.5533	.5693	.7282	.5895
18	.5935	.6762	1.1145	.4578	.4024	.6415	.6068
19	.6274	.6415	.8573	.5487	.57	.7628	.6588
20	.6535	.7108	.8745	.5868	.6274	.7802	.8842
21	.6371	.6935	.9431	.6001	.6226	.7628	.8842
22	.6104	.6588	.8573	.5596	.583	.7282	.8669
23	.5765	.6241	.8573	.5548	.5281	.7628	.8322
24	.5487	.6068		.8669	.5365	.7628	
Max	.8619	1.0402	1.1145	.8669	.6274	.9088	.8842
Min	.373	.4748	.5548	.4578	.2915	.3521	.5895
Avg	.6152	.6811	.8578	.7006	.5121	.6533	.7322



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304082 / 33KV SARUL SUBSTATION

Feeder No / Name : 202 / 11KV PIMPALKHUTA FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2915	.3086	.3086	.3052	.2229	.1715
2	.2743	.2915	.2915	.3086	.2915	.2058	.1715
3	.2572	.2743	.2915	.2743	.2713	.2058	.1715
4	.2572	.2743	.2915	.2743	.2743	.1886	.1886
5	.2572	.2743	.3086	.2572	.2543	.1715	.1886
6	.2058						
7	.1543						
8	.1886						
12	.2743	.4115	.3429	.3185	.0503	.0514	
13	.3086	.4287	.3429	.3391	.0983	.0514	.1029
14	.3086	.4115	.3601	.3481	.1898	.0857	.1029
15	.2915	.4115	.2743	.3086	.2688	.0857	.1029
16	.3086	.3772	.2743	.3353	.2846	.1029	.12
17	.3429	.3772	.3429	.3052	.1898	.12	.12
18	.3258	.3601	.4287	.3641	.1802	.1372	.1372
19	.3086	.3429	.2915	.2883	.1966	.1886	.2058
20	.3258	.4115	.3086	.3353	.2785	.1886	.2229
21	.3258	.4115	.3086	.3258		.1886	.2229
22	.3086	.3429	.3086	.3222		.1907	.2229
23	.2743	.3258	.3086	.3018		.1715	.2058
24	.2743	.3086		.3086	.3052	.1734	
Max	.3429	.4287	.4287	.3641	.3052	.2229	.2229
Min	.1543	.2743	.2743	.2572	.0503	.0514	.1029
Avg	.2784	.3515	.3167	.3124	.2292	.1517	.1661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

BABHULGAON S/DN.[815] BU 4815

Substation No/ Name :- 304082 / 33KV SARUL SUBSTATION

Feeder No / Name : 203 / 11KV GHARFAL FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.663	.6241	.5201	.4287	.3239	.3121
2	.3944	.6371	.6068	.5201	.4239	.3315	.3121
3	.3988	.6036	.6068	.5201	.4287	.2949	.3121
4	.407	.5765	.5895	.5201	.4191	.3018	.2947
5	.4191	.5087	.5895	.5201	.4239	.2713	.2947
6	.373						.2947
7	.4239						
8	.5144						
11							.1886
12		.8322	1.2174	.9945	.3277	.2743	
13	.8886	1.2656	1.2003	1.0288	.3768	.2427	.2058
14	.7625	1.2309	1.2174	.8886	.3361	.2401	.2229
15	.7545	1.1789			.3437	.2774	.2254
16	.8383	1.0576	1.0749	.2229	.4428	.3121	.2601
17	.9221	1.0402	1.0974	.4862	.3637	.1387	.2774
18	.8478	1.0056	1.1145	.4862	.2915	.208	.3429
19	.8309	.9362	.8573	.463	.2949	.3467	.3641
20	.788	.8149	.6859	.4748	.4096	.3467	.3988
21	.7712	.8149	.6001	.4508	.421	.3467	.3641
22	.763	.6762	.5201	.4458	.3841	.3467	.3467
23	.7042	.6241	.5144	.4191	.3637	.3294	.3467
24	.4287	.6241		.5201	.4239	.3121	
Max	.9221	1.2656	1.2174	1.0288	.4428	.3467	.3988
Min	.373	.5087	.5144	.2229	.2915	.1387	.1886
Avg	.6310	.8384	.8198	.5577	.3835	.2914	.2980

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304002 / 33KV KALAMB

Feeder No / Name : 201 / 11kv Kalamb Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063	1.2894	1.39	.1029	1.1584	1.1104	1.0974
2	.1029	1.2894	1.3717	.1029	1.1584	1.0745	1.0974
3	.1029	1.2894	1.267	.1029	1.086	1.0387	1.086
4	.1029	1.2536	1.2308	.1029	1.086	1.0029	1.086
5	.1029	1.2178	1.1946	.1029	1.0498	.9774	1.0498
6	.1029	1.1462	1.1584	.1029	.9955	.9412	1.0029
7	.096	1.0745	1.1462	.096	.9774	.9412	.9313
8	.096	1.1104	1.0745	.1029	1.0136	.8326	.9313
9	.096	1.1462	1.2048	.1166	1.0498	.8048	1.0136
10	1.0029	1.3169	.1132	.9412	1.0498	.788	.0823
11	1.1462	1.2437	.1166	.9774	.9774	.788	.0857
12	1.0745	1.086	.1149	1.0317	.9412	.7087	.0823
13	1.0745	1.39	.1097	1.0498	.9412	.788	.0754
14	1.0029	1.3169	.1097	1.1041	.9412	.724	.0754
15	1.0029	1.448	.1097	1.086	.8596	.7964	.0754
16	1.2178	1.448	.1166	1.086	.9313	.7964	.0686
17	1.1462	1.3032	.1166	1.1041	.9313	.7964	.0686
18	1.0745	1.3169	.1029	1.0679	.9412	.8688	.0754
19	1.1462	1.1706	.1132	1.1222	1.1462	1.1706	
20	1.4327	1.4784	.1132	1.3756	1.2536	1.3169	.1029
21	1.4327	1.5364	.1166	1.3937	1.2894	1.3535	.1097
22	1.2894	1.4118	.1235	1.3756	1.2178	1.1706	.1097
23	1.3466	1.3756	.12	1.3032	1.2178	1.1706	.1029
24	.1132	1.2894	1.39	.1029	1.2308	1.1462	1.0974
Max	1.4327	1.5364	1.39	1.3937	1.2894	1.3535	1.0974
Min	.096	1.0745	.1029	.096	.8596	.7087	.0686
Avg	.7255	1.2895	.5844	.7106	1.0602	.9628	.5003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304002 / 33KV KALAMB

Feeder No / Name : 202 / 11kv Kamathwada

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.036	.5249	.5138	.0377	.3582	.362	.3366
2	.036	.5249	.4961	.0343	.3224	.362	.3366
3	.0377		.4908	.0343	.3224	.3439	.3366
4	.0377	.5249	.4733	.0343	.2865	.3439	.333
5	.0343	.4706	.4458	.0343	.2865	.3258	.2804
6	.0343	.362	.4239	.0343	.2686	.3258	.2374
7	.0343	.5792	.463	.0274	.2507	.2353	.2035
8	.0343	.7964	.6154	.0429	.2686		.1865
9	.0686	.9231	.8505		.2686	.2534	.2454
10	.7059	.9412	.072	.4298	.2865	.2058	.0223
11	.724	.8688	.0754	.4656	.2561	.2601	.0223
12	.7602	.8326	.0652	.4298	.2195	.2454	.0223
13	.4656	.7164	.0652	.4298	.2378	.2543	.0223
14	.6154	.6805	.0497	.4119	.3077	.2401	.0206
15	.7059	.7865	.0497	.394	.3439	.2629	.0206
16	.7602	.5731	.0429	.4119	.362	.2572	.0137
17	.3258	.6268	.0429	.2865	.3801	.2454	.0137
18	.7421	.6805	.048	.2865	.2195	.2401	.0206
19	.6516	.6584	.0446	.3224	.2896	.2835	
20	.5611	.6036	.0514	.3582	.2896	.3582	.0291
21	.6516	.5792	.0463	.394	.362	.3582	.0291
22	.6516	.567	.0343	.4298	.3982	.3403	.0274
23	.543	.5373	.0343	.394	.3982	.3439	.0274
24	.036	.5249	.5249	.0377	.3582	.362	.3439
Max	.7602	.9412	.8505	.4656	.3982	.362	.3439
Min	.0343	.362	.0343	.0274	.2195	.2058	.0137
Avg	.3856	.6471	.2508	.2505	.3059	.2961	.1361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304002 / 33KV KALAMB

Feeder No / Name : 204 / 11KV Watkhed Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412	.5853	.5784	.0377	.4344	.439	.4477
2	.0412	.5853	.5609	.0377	.394	.4066	.4477
3	.0377	.5853	.567	.0377	.3982	.4066	.4075
4	.0377	.5853	.5316	.0377	.3982	.3696	.4031
5	.0377	.5487	.5426	.0377	.3801	.3326	.4252
6	.0377	.5121	.5316	.0377	.362	.2957	.333
7	.0291	.5487	.5609	.0463	.362	.2772	.2427
8	.0514	.7682	.7712	.06	.362		.2601
9	.0514	.8869	.8939	.0686	.3801	.2957	.2401
10	.6401	.8779	.0857	.8145	.3801	.2713	.0206
11	.6697	.9694	.0754	.724	.3142	.2374	.0223
12	.6584	.9694	.0823	.6878	.3142	.2401	.0223
13	.4251	.905	.0686	.6697	.3511	.2012	.0223
14	.6584	.8688		.6697	.3881	.2204	.0223
15	.695	.9145		.724	.4066	.2035	.0223
16	.695	.8962	.0634	.6697	.4805	.2229	.0206
17	.7421	.8145	.0634	.543	.5175	.2401	.024
18	.7059	.8145	.0549	.3801	.2402	.2454	.024
19	.5853	.6154	.0514	.4706	.3511	.3403	.0326
20	.6401	.7059	.0566	.5014	.4066	.4298	.0463
21	.6697	.7316	.0549	.543	.5304	.5068	.0463
22	.5121	.7087	.0446	.5973	.5121	.5121	.0446
23	.6036	.6201	.0446	.543	.5121	.4755	.0446
24	.0412	.5853	.6036	.0377	.4706	.4755	.4525
Max	.7421	.9694	.8939	.8145	.5304	.5121	.4525
Min	.0291	.5121	.0446	.0377	.2402	.2012	.0206
Avg	.3878	.7335	.3131	.3740	.4019	.3324	.1698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304002 / 33KV KALAMB

Feeder No / Name : 205 / 11 KV EXPRESS

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.0061	.005	.0034	.0076	.0065	.005
2	.0034	.0061	.005	.0034	.0076	.0065	.0042
3	.0034	.0061	.0046	.0034	.0076	.0065	.0038
4	.0034	.0061	.0042	.0034	.0076	.0065	.0042
5	.0034	.0061	.0046	.0034	.0076	.0065	.0046
6	.0034	.0061	.0046	.0034	.0076	.0069	.0042
7	.0034	.0111	.0053	.0034	.0076	.0072	.0046
8	.0034	.0061	.0053	.0034	.0076	.0069	.0046
9	.0034	.0042	.0042	.0034	.0076	.0065	.0042
10	.0053	.0042	.0034	.0076	.0076	.0046	.0034
11	.0061	.0046	.0034	.0076	.0065	.0046	.0034
12	.0027	.0046	.0034	.0076	.0065	.0042	.0034
13	.0057	.0042	.0034	.0076	.0065	.0042	.0034
14	.0053		.0034	.0076	.0065	.0042	.0034
15	.0053	.0046	.0034	.0076	.0076	.0038	.0034
16	.0061	.005	.0034	.0076	.0065	.0042	.0034
17	.005	.0042	.0034	.0076	.0065	.0046	.0034
18	.0061	.0046	.0034	.0076	.0065	.0042	.0034
19	.008	.005	.0034	.0076	.0065	.005	.0034
20	.0076	.0042	.0034	.0076	.0065	.005	.0034
21	.0061	.0046	.0034	.0076	.0065	.005	.0034
22	.0061	.005	.0034	.0076	.0065	.005	.0034
23	.0061	.005	.0034	.0076	.0065	.005	.0034
24	.0034	.0061	.005	.0034	.0076	.0065	.005
Max	.008	.0111	.0053	.0076	.0076	.0072	.005
Min	.0027	.0042	.0034	.0034	.0065	.0038	.0034
Avg	.0048	.0054	.0040	.0059	.0071	.0054	.0038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304002 / 33KV KALAMB

Feeder No / Name : 206 / 11 KV GALAMGAON EXPRESS

HV Express Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	14-JUL-17
HR	Load (MW)
10	.0034
18	.0034
19	.0034
20	.0034
21	.0034
22	.0034
23	.0034
Max	.0034
Min	.0034
Avg	.0034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304071 / 33 kv kotha

Feeder No / Name : 201 / 11KV DONODA-TAMBA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6097	.3681	.2835	.2429	.5144	.4954
2	.5335	.6097	.3681	.2835	.2429	.4954	.4763
3	.4954	.5716	.3506	.2804	.2591	.4954	.4572
4	.4191	.5716	.3506	.2804	.2591	.4572	.381
5	.3429	.4954	.3856	.3086	.2915	.4572	.3048
6	.2858	.381	.4908	.3856	.3563	.3239	.2286
7	.1905	.2667	.631	.6299	.3761	.1905	.1905
8	.1524	.2286	.8589	.6964	.4298	.1715	.1715
9	.1905	.1334	.8413	.664	.3761	.1905	.1905
10		.6859	.2096	.1905	.1715	.1372	.1802
11	.6859	.823	.2096				.2753
12	.3429	.703	.2477	.1905	.1715	.1372	.1006
13	.583	.7202	.3048	.2286	.2096	.1492	.1543
14	.6516	.7888		.2858	.2096	.1543	.1029
15	.6516	.7202	.3048	.2667	.2477	.1052	.1052
16	.6516	.6687	.2858	.2096	.2286	.1052	
17	.6859	.6173	.2477	.1905	.2286	.1052	.1052
18	.2477	.3048	.2667	.2477	.2667		.0876
19	.381	.4191	.4382	.4001	.381	.362	.1052
20	.5906	.6287	.5335	.5335	.5144	.4954	.1753
21	.6859	.1578	.5716	.6097	.5906	.5716	.1928
22	.6859	.2804	.5906	.6097	.5525	.5716	
23	.6097	.3506	.5525	.5716	.5335	.5335	.1791
24	.5906	.6097	.3681	.2658	.2267	.5144	.5144
Max	.6859	.823	.8589	.6964	.5906	.5716	.5144
Min	.1524	.1334	.2096	.1905	.1715	.1052	.0876
Avg	.4881	.5144	.4251	.3745	.3203	.329	.2352



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304071 / 33 kv kotha

Feeder No / Name : 202 / 11 KV KOTHA-TARODA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.2193	.5316	.499	.4694	1.0669	1.0288
2	1.1431	1.1812	.5144	.4706	.4694	1.0479	.9907
3	1.0669	1.1431	.5144	.4656	.4694	.9907	.9526
4	.8764	1.105	.5144	.4656	.4527	.9526	.8383
5	.7621	.9907	.4801	.463	.4359	.9526	.724
6	.6478	.8764	.5144	.4862	.3932	.7049	.6859
7	.4763	.6478	.4973	.5138	.3224	.4191	.4382
8	.381	.4382	.583	.547	.4298	.381	.362
9	.4001	.4763	.6344	.5344	.4298	.362	.3239
10		.6173	.4191	.362	.381	.2896	.2713
11	.5487	.6104	.4572				.2543
12		.78	.5335	.4382	.4001	.2401	
13	.6001	.6371	.5906		.4191	.2155	.2321
14	.6344	.6036	.6287		.5144	.2229	
15	.6001	.6613	.6478	.5716	.5335	.2401	.1886
16	.5487	.6274	.6478	.5144	.5335	.2401	
17	.4973	.5087	.5144	.4763	.5335	.2401	.2229
18	.5335	.5906	.5525	.5144	.5335		.2915
19	.8002	.8002	.7811	.743	.7621	.743	.2915
20	1.105	1.2193	1.086	1.0669	1.0479	1.0098	.3944
21	1.2955	.5487	1.1812	1.2384	1.1622	1.1622	.4287
22	1.3527	.5487	1.2574	1.2003	1.1622	1.1812	
23	1.2955	.5487	1.2003	1.1812	1.086	1.086	.3761
24	1.2193	1.2193	.5316	.499	.4862	1.0669	1.0479
Max	1.3527	1.2193	1.2574	1.2384	1.1622	1.1812	1.0479
Min	.381	.4382	.4191	.362	.3224	.2155	.1886
Avg	.8166	.7750	.6589	.6310	.5838	.6734	.5172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

KALAMB S/DN.[316]

BU 3166

Substation No/ Name :- 304071 / 33 kv kotha

Feeder No / Name : 203 / 11KV ASHTI-NARSAPUR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.2686	.2683	.2429	.362	.3429
2	.381	.4191	.2686	.2683	.2429	.362	.3048
3	.381	.4191	.2507	.2683	.2429	.3429	.2667
4	.3429	.381	.2149	.2515	.2429	.3429	.2286
5	.2667	.3048	.2328	.2486	.2591	.3429	.1905
6	.2096	.2667	.3045	.2949	.2105	.2286	.1905
7	.1334	.1905	.394	.4372	.1791	.1524	.1524
8	.1334	.1524	.5194	.5281	.2149	.1524	.1334
9	.1334	.1524	.5373	.5281	.2686	.1715	.1524
10		.5014	.1524		.1715	.1524	.1638
11	.4801	.5609	.1524				.1638
12	.4458	.5083	.1715	.1524	.1524	.1372	.1658
13	.4115	.4908	.1905	.1715	.1524	.1423	.1326
14	.3601	.4908	.2096	.1905	.1524	.1492	.1341
15	.3772	.4207	.2096	.1905	.1524	.1433	.1254
16	.3944	.4207	.1905	.1715	.1524	.1612	
17	.4287	.4207	.1905	.1334	.1715	.1791	
18	.1715	.1905	.1905	.2286	.2096		
19	.2667	.3048	.3048	.3239	.2667	.2667	
20	.4001		.4191	.4001	.362	.362	.197
21	.4572	.2865	.4001	.4382	.4001	.4001	.2149
22	.4382	.2686	.4382	.4572	.4191	.4001	
23	.4382	.2686	.4382	.4382	.381	.362	.2149
24	.4191	.4382	.2686	.2515	.2686	.362	.362
Max	.4801	.5609	.5373	.5281	.4191	.4001	.362
Min	.1334	.1524	.1524	.1334	.1524	.1372	.1254
Avg	.3430	.3607	.2882	.3019	.2398	.2580	.2019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304001 / 33KV LADKHED

Feeder No / Name : 201 / 11kv Ladkhed

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4111	.4111	.0373	.0316	.0373	.5601	.4744
2	.4111	.4111	.0373	.0316	.0373	.5601	.4744
3	.4111	.4428	.0373	.0316	.0373	.5544	.4744
4	.4111	.4481	.0373	.0316	.0373	.5544	.4744
5	.4111	.4801	.0373	.0316	.0373	.5601	.4744
6	.4111	.5182	.0373	.0316	.0373	.6722	.4744
7	.6009	.7773	.0373	.0316	.0373	.6722	.6958
8	.7274	.8223	.0373	.0316	.0373		.6958
9	.7499	.8223	.0373	.0316		.5228	.8223
10	.0316	.0373	.9709	1.1069		.0373	.0316
11	.0373	.0366		1.2018	1.4937		.0316
12	.0377	.0366	1.1702	1.1385	1.4045	.0316	.0316
13	.0373	.0366	1.1385	1.2018	1.1949	.0316	.0316
14	.0373	.0373	.9488	1.0883	1.2696	.0316	.0316
15	.0373	.0373	1.1385	1.1385	1.2567	.0316	.0316
16	.0373	.0373	1.1385	1.1385	1.3443	.0316	.0316
17	.0373	.0373	1.0437	1.1523	1.2567	.0316	
18	.0373	.037	.0316	.0373	.037	.0316	.0316
19	.0377	.037	.0316	.0373	.0373	.0316	.0316
20	.0373	.037	.0316	.0373	.0373	.0316	.0633
21	.0373	.037	.0316	.0373	.037	.0316	.0316
22	.0373	.037	.0316	.0377	.0373	.0316	.0625
23	.0316	.0373	.0316	.0373	.0373	.0316	.0312
24	.4111	.3795	.037	.0316	.0373	.5601	.4744
Max	.7499	.8223	1.1702	1.2018	1.4937	.6722	.8223
Min	.0316	.0366	.0316	.0316	.037	.0316	.0312
Avg	.2278	.2513	.3527	.4045	.4445	.2560	.2612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304001 / 33KV LADKHED

Feeder No / Name : 203 / 11 KV Malkhed

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0754	.5601	.506	.421		.0377
2	.0316	.0747	.5601	.506	.421		.0377
3	.0316	.0747	.5544	.506	.4656		.0377
4	.0316	.0747	.5544	.506	.4706		.0377
5	.0316	.0747	.5544	.6325	.421		.0377
6	.0316	.0747	.6348	.6958	.4588		.0377
7	.0316	.0747	.961	.7907	.6874		.0377
8	.0316	.0754	1.1458	.8855	.9602		.0377
9	.0316	.0747	1.2696	.9172			.0377
10		1.0364	.168	.0633			.2214
11	.5182	1.1706		.0373	.0373		.9172
12	.9069	1.134	.0316	.0747	.0373	.6958	.9488
13	.8962	1.1949		.0747	.0373	.6642	.8223
14	.9602	.8686		.0747	.0373	.3795	.6958
15	.9488	.3696	.0949	.0373		.506	.4428
16	.9488	.5601	.1265	.0373	.0373	.5376	.9488
17	.9488	1.0269	.1265	.0373	.0373	.6958	
18	.0671	.0747	.253	.0373	.0373	.0316	.0633
19	.0373	.0747	.1581	.1867	.0747		.0316
20	.0747	.0739	.0949	.1581	.0747	.0316	.0633
21	.0934	.0747	.0633	.1943	.0747	.0316	.0633
22	.0924	.0747		.1296	.0747	.0316	.0625
23	.0655	.0747	.0316	.0972	.0747	.0316	.0625
24	.0316	.0316	.5601	.4744	.421	.0747	.0377
Max	.9602	1.1949	1.2696	.9172	.9602	.6958	.9488
Min	.0316	.0316	.0316	.0373	.0373	.0316	.0316
Avg	.2989	.3547	.4252	.3192	.2553	.3093	.2487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304001 / 33KV LADKHED

Feeder No / Name : 204 / Ladkhed Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	1.4784	1.5684	1.6095	1.5893		1.3717
2	1.5181	1.4784	1.5524	1.6095	1.5893		1.3717
3	1.5181	1.4784	1.5524	1.6095	1.5893		1.3717
4	1.5181	1.4937	1.5524	1.6095	1.5893		1.3717
5	1.5181	1.4784	1.5524	1.6095	1.6263		1.4266
6	1.5181	1.4998	1.5524	1.6095	1.6632		1.4998
7	1.4449	1.5364	1.6632	1.5912	1.6078		1.4998
8	1.39	1.5708	1.5524	1.5912	1.5364		1.4632
9	1.4083	1.5154	1.5339	1.4632			1.2803
10	1.0791	1.0829	1.3491	1.2986			1.1706
11	1.0903	1.1706		.9425	.9335		1.0242
12	1.0719	1.2803	.9328	.8316	.7842	.823	.9511
13	.9795	1.3394	1.1157	.8686	.8402		.9328
14	1.1458	1.3817	1.1157	.8871	.8402	.7682	.695
15	1.0719	1.3352	1.1157	.8962	.8686	.8048	.7133
16	1.1643	1.307	1.0425	1.0719	.8962	.8048	.9145
17	1.0903	1.2197	1.0425	1.0242	.9795	.9511	
18	1.3121	1.4563	1.4083	1.2803	1.3443	1.1706	1.2803
19	1.6263	1.7737	1.701	1.6632	1.587	1.4815	1.3169
20	1.7187	1.8111	1.9204	1.8099	1.7364	1.6461	1.6827
21	1.7002	1.8111	1.7375	1.8111	1.7002	1.4998	1.4998
22	1.6817	1.6057		1.7372		1.4998	1.0791
23	1.5524	1.5893	1.6095	1.6461	1.307	1.4449	1.2254
24	1.5181	1.5154	1.5524	1.6095	1.5893	1.386	1.3717
Max	1.7187	1.8111	1.9204	1.8111	1.7364	1.6461	1.6827
Min	.9795	1.0829	.9328	.8316	.7842	.7682	.695
Avg	1.3814	1.4670	1.4420	1.4034	1.3427	1.1901	1.2397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304001 / 33KV LADKHED

Feeder No / Name : 206 / 11 KV SARANGPUR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5121	.5601	.6219	.6219		.5853
2	.5487	.5121	.5544	.6219	.6219		.5853
3	.5487	.5121	.5544	.6219	.6219		.5853
4	.5487	.5121	.5544	.6219	.6219		.5853
5	.5121	.5121	.5544	.6219	.6219		.5853
6	.4755	.5121	.5601	.5853	.6219		.5853
7	.4755	.5121	.5544	.5121	.543		.5121
8	.439	.5121	.5175	.5121	.5121		.5121
9	.4755	.5487	.5228	.4755			.1097
10	.4024	.5121	.4294	.5487			.1097
11	.4024	.4755		.4755	.4294		.3658
12	.362	.4755	.3292	.4024	.2987	.3292	.3292
13	.4706	.4481	.4024	.4755	.3361	.2926	.3292
14	.439	.4481	.2195	.4024	.4108	.2561	.2926
15	.3658	.4805	.2926	.3658	.4435	.4024	.3292
16	.4024	.4805	.4755	.4024	.3734		.3658
17	.4344	.4854	.439	.439	.4481	.0732	
18	.4344	.5601	.5121	.5121	.5601	.439	.439
19	.5487	.1867	.6219	.6219	.5975	.5853	.439
20	.7316	.2218	.8048	.7316	.5975	.6584	.5853
21	.6653	.6348	.695	.7682	.6348	.6584	.6219
22	.6154	.2614		.695	.6653	.6584	.6219
23	.5853	.6722	.695	.6584	.6348	.6219	.5853
24	.5487	.5487	.5544	.6219	.6219	.5914	.5853
Max	.7316	.6722	.8048	.7682	.6653	.6584	.6219
Min	.362	.1867	.2195	.3658	.2987	.0732	.1097
Avg	.4992	.4807	.5183	.5548	.5381	.4639	.4628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304013 / 33KV NER

Feeder No / Name : 201 / 11kv Ner Town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5133	2.572	2.8829	2.7109	2.524	2.2462	2.0919
2	2.4025	2.5034	2.8829	2.7109	2.3777	2.1434	2.0576
3	2.0328	2.4177	2.9264	2.6932	2.1582	2.0919	2.0576
4	1.922	2.4177	2.9127	2.6932	2.0119	2.0919	2.1262
5	2.3777	2.4348	2.894	2.6755	1.848	2.1948	2.1948
6	2.6057	2.4348	2.95	2.6755	2.5133	2.2977	2.2634
7	2.5873	2.5377	2.9127	2.6932	2.7166	2.332	2.5034
8	2.4394	2.5892		2.6755	2.4764	2.3491	2.4006
9	2.2731	2.5377	2.7069	2.5789	2.4764	2.1605	2.4348
10	2.1807	2.6235	2.6326	2.4714		1.9376	2.3663
11	2.0576	2.4006					2.2119
12	2.1262	2.5339	2.4097		1.9204		1.9521
13	2.0919	2.5431	2.2857		1.9033	1.7147	1.9728
14	2.2977	2.6244	2.2502		1.9204	1.6461	1.8839
15	2.3148	2.6703	2.073		1.9547	1.6289	2.0119
16	2.2634	2.6703	2.2857	2.2081	2.0233	1.6804	2.0485
17	2.3491	2.5873	2.392	2.2497	2.0748	1.7833	2.0851
18	2.3491	2.5953	2.5789	2.4508	2.3491	2.1434	2.1622
19	2.5549		2.8475	2.7069	2.4177	2.3491	2.2361
20	2.8464		2.758	2.7252	2.4177	2.4863	2.4874
21	2.7778	3.1642		2.7435	2.452	2.4177	2.6406
22	2.7092	3.0678		2.7435	2.4006	2.3663	2.6139
23	2.6406	2.8898	2.7168	2.7618	2.3834	2.1605	2.4579
24	2.5873	2.6063	2.8829	2.7109	2.5972	2.3491	2.1262
Max	2.8464	3.1642	2.95	2.7618	2.7166	2.4863	2.6406
Min	1.922	2.4006	2.073	2.2081	1.848	1.6289	1.8839
Avg	2.3875	2.6101	2.6591	2.6252	2.2690	2.1169	2.2245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304013 / 33KV NER

Feeder No / Name : 202 / 11kv Watfali/Lasina

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.823	.9145	.7796	.9313	.7202	.7716
2	.8501	.823	.924	.7973	.9492	.7545	.7202
3	.8131	.823	.9522	.7973	.9979	.7373	.6859
4	.7682	.7716	.961	.8063	1.0029	.7373	.6859
5	.7316	.6859	.8939	.8238	1.0517	.6859	.6516
6	.7059	.6516	.9036	.8238	1.0749	.6859	.6344
7	.543	.583	.8939	.9465	1.1317	.823	.4801
8	.4715	.4801	.8745	1.0692	.9313	.9774	.4115
9	.5041	.4287	1.073	1.0631	.9835	.9602	
10	.924	.9431	.4382	.5316		.4287	.8916
11	.7545	.6516	.2804				.8916
12		.8326	.2658		.4115	.3429	.8954
13		.8596	.4607		.3772	.3429	.9231
14	.8745	1.4266	.4607		.4458	.4115	.8779
15	.9945	1.4299	.4801		.5144	.4458	.8779
16	1.1317	1.4449	.3121	.4252	.4458	.4458	.8596
17	1.0802	1.1765	.4733	.3761	.3944	.4287	.8507
18	.8059	1.0425	.5373	.5373	.5316	.463	.8145
19	1.0631	.905	.6733	.6089	.6344	.583	.8507
20	.7888	.8238		.7164	.8402	.7888	.8596
21	.823	.7316	.8775	.8238	.8745	.7888	.8501
22	.9259	.6219		.8688	.8402	.7716	.7964
23	.8573	.6219	.9036	.905	.7888	.7888	.823
24	.924	.823	.924	.7712	.9412	.6859	.7716
Max	1.1317	1.4449	1.073	1.0692	1.1317	.9774	.9231
Min	.4715	.4287	.2658	.3761	.3772	.3429	.4115
Avg	.8283	.8502	.7035	.7616	.7770	.6434	.7772



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304013 / 33KV NER

Feeder No / Name : 203 / 11kv Mangladevi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9774	1.7558	1.2403	1.448	1.3032	.8059
2	.8962	.9431	1.6289	1.2269	1.4118	1.286	.823
3	.8962	.9088	1.5947	1.2269	1.39	1.2346	.823
4	.8501	.9259	1.2752	1.2269	1.3535	1.2003	.8059
5	.961	1.0288	.9335	1.1919	1.3306	1.1488	.8573
6	.9877	1.1317	.9522	1.1919	1.2936	1.1145	.8573
7	1.0867	1.2346	.9619	1.0341	1.2323	.8745	.8916
8	1.2431	1.4575	.8745	1.0166	1.0269	.8059	1.0802
9	1.4251	1.4575	1.1827	.9745	.9808	.823	1.1488
10	.9496	1.166	.8589			.6687	.7888
11	1.0631	1.1145	1.2934				.8573
12	.6859	1.5203	1.5769		1.0974	.8402	.9145
13	.7202	1.5364	1.3466		1.2003	.823	.905
14	.6687	1.4842	1.258		1.2689	.823	.9145
15	.7716	1.4632	1.2048		1.3032	.8745	.9425
16	1.3203	1.4632	.6733	1.1096	1.2003	.8745	.9335
17	1.3203	1.4299	.7265	1.1218	1.1317	.9945	.8676
18	.6344	1.2803	1.0745	1.0631	.8916	.8059	.8779
19	1.0974	1.448	1.2934		1.0117	1.0117	1.2382
20	1.5947	1.7013	1.1694	1.3969	1.3546	1.2689	1.6461
21	1.5947	1.7375	1.1694	1.5203	1.3717	1.2689	1.6461
22	1.6289	1.7002		1.5927	1.3717	1.3032	1.6632
23	1.6289	1.6644	1.262	1.6289	1.406	1.3375	1.4415
24	.9709	1.1145	1.7375	1.2403	1.5203	1.3717	.8059
Max	1.6289	1.7375	1.7558	1.6289	1.5203	1.3717	1.6632
Min	.6344	.9088	.6733	.9745	.8916	.6687	.7888
Avg	1.0804	1.3287	1.2089	1.2355	1.2544	1.0460	1.0223

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304013 / 33KV NER

Feeder No / Name : 204 / 11kv Mosar

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.7716	1.3535	.9816	.9412	.9259	.7716
2	.8589	.703	1.4299	1.0166	.905	.9431	.7202
3	.8589	.6687	1.4327	1.0517	.8764	.8916	.7202
4	.8501	.6173	1.3735	1.1568	.9465	.8916	.703
5	.8686	.583	1.406	1.4022	1.2003	.9431	.7202
6	.8779	.5658	1.491	1.4373	1.2742	.9431	.703
7	.7682	.5487	1.4413	1.595	1.4586	1.0288	.6173
8	.6838	.4287		1.7353	1.6118		.5487
9	.6767	.3601	1.3169		1.3108		.5316
10	.9774	1.2003	.4973	1.4352		.7545	.9088
11	.9088	1.4575	.4252				.7888
12	1.0802	1.4632	.4607		.3429		.8596
13	1.0631		.4961		.2572	.3429	.8871
14	1.1831	1.2803	.4075		.3429	.3429	.8779
15	1.0974	1.3717	.5316		.4458	.463	.7682
16	.5316	1.4632	.5493	.5373	.4115	.463	
17	.9602	1.4815	.3189	.5611	.3944	.4801	.7316
18	1.046	1.4661	.591	.6516	.3429	.583	.7343
19	1.0288	1.4632	.815	.7421	.7545	.703	.7577
20	1.0117	1.448	.9391	.7964	.823	.7888	.7316
21	.9602	1.4148	.9568	.8413	.8402	.7888	.7682
22	.9431	1.3575	.9922	.8596	.823	.7716	.7602
23	.823	1.3535	.9816	.8779	.823	.8059	.7537
24	.9335	.8059	1.3394	1.0277	.9877	.9259	.7716
Max	1.1831	1.4815	1.491	1.7353	1.6118	1.0288	.9088
Min	.5316	.3601	.3189	.5373	.2572	.3429	.5316
Avg	.9120	1.0554	.9368	1.0393	.8234	.7390	.7450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304013 / 33KV NER

Feeder No / Name : 205 / 11 KV S.G.P. Express Ner

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0099	.0343	.0343	.0343	.0343
2	.0343	.0343	.0099	.0343	.0343	.0343	.0343
3	.0343	.0857	.0301	.0343	.0343	.0343	.0343
4	.1029	.0857	.0602	.12	.0857	.12	.0343
5	.12	.12	.0812	.12	.12	.12	.12
6	.12	.12	.0934	.12	.12	.12	.12
7	.12	.12	.0934	.12	.12	.12	.12
8	.12	.12		.12	.12	.12	.12
9	.1029	.12	.0869	.12	.12	.12	.12
10	.1372	.12	.0823	.12		.12	.12
11	.12	.12					.12
12	.1029	.12	.12		.12		.12
13	.1029	.104	.12		.12	.1372	.1029
14	.1029	.1029	.124		.12	.1372	.1029
15	.1029	.1029	.124		.12	.1372	.1029
16	.0171	.0823	.12	.12	.12	.12	.1029
17	.0171	.0789	.12	.12	.0343	.12	.0343
18	.0171	.072	.0343	.12	.0343	.12	.0343
19	.0343	.0572	.0343	.12	.0343	.12	.0343
20	.0343	.008	.0354	.12	.0343	.0343	.0343
21	.0343	.008	.0343	.0343	.0343	.0343	.0343
22	.0343	.008	.0343	.0343	.0343	.0343	.0343
23	.0343	.008	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.0084	.0351	.0343	.0343	.0343
Max	.1372	.12	.124	.12	.12	.1372	.12
Min	.0171	.008	.0084	.0343	.0343	.0343	.0343
Avg	.0714	.0778	.0678	.0885	.0756	.0912	.0743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304044 / 33 KV SHIRAJGAON SUBSTATION

Feeder No / Name : 201 / 11 KV SHIRAJGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.2323	1.1647	1.0477	1.052	1.1203	1.1694
2	1.1283	1.2323	1.1635	1.0477	1.052	1.1576	1.1694
3	1.0918	1.1949	1.1647	1.0509	1.1245	1.1949	1.1694
4	1.0895	1.1925	1.1271	1.1248	1.3004	1.2696	1.1517
5	1.0884	1.118	1.126	1.1647	1.3939	1.2298	1.134
6	1.126	1.1576	1.1647	1.3525	1.4266	1.3043	1.1568
7	1.1271	1.1552	1.2023	1.5764	1.4435	1.4534	1.1218
8	1.0509	1.118	1.5404	1.4888	1.6315	1.6397	1.0402
9	.9758	1.0165	1.6155	1.3672	1.519	1.5279	.9945
10	.9658	1.5812	.789		.8232	.7095	1.166
11	1.2785	.64	.7514				1.0395
12	1.2771	.6568	.7117	.592			1.073
13	1.3817	1.4682	.7506	.6225	.7095	.503	
14	1.1925	1.6565	.7514	.6605	.7095	.5365	
15	1.4906	1.6565	.8257		.6348	.5365	1.1948
16	1.4906	1.6753	.7514	.7746	.7468	.57	
17	1.5279	1.5388	.9017	.7369	.7842	.57	
18	.9335	1.5013	.9008	.8659	1.0082	.6836	
19	1.2696	1.5013	1.2023	1.1949	1.2696	1.2048	1.1315
20	1.307	1.2774	1.1647	1.4219	1.3443	1.2048	1.28
21	1.3817	1.2761		1.307	1.307	1.2178	
22	1.3443	1.2761	.3006	1.2696	1.2323	1.2178	1.0498
23	1.2696	1.2774	.3006	1.2709	1.1949	1.1999	1.0498
24	1.2722	1.2323	1.1647	1.1271	1.052	1.0062	1.2178
Max	1.5279	1.6753	1.6155	1.5764	1.6315	1.6397	1.28
Min	.9335	.64	.3006	.592	.6348	.503	.9945
Avg	1.2179	1.2764	.9798	1.0983	1.1254	1.0481	1.1283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304044 / 33 KV SHIRAJGAON SUBSTATION

Feeder No / Name : 202 / 11 KV SAWARGAON(KALE)

Single Phasing Feeders

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3354	.3361	.3003	.1873	.3024	.3734	.2835
2	.3354	.3727	.3006	.1873	.2649	.3734	.2835
3	.3347	.3727	.3003	.1705	.2649	.3734	.2835
4	.3344	.4099	.3006	.1686	.2649	.3734	.2835
5	.332	.4472	.2627	.1707	.2649	.3734	.2835
6	.3528	.5228	.2627	.1703	.3027	.3361	.2481
7	.3346	.559	.1877	.2254	.2649	.2987	.3155
8	.5018	.5963	.1877	.2252	.2273	.2236	.3121
9	.463	.4884	.1877	.2273	.1894	.1867	.3086
10	.1894	.1882	.263		.368	.3354	.1715
11	.1892	.2252	.2627				.1006
12	.1882	.1879	.263	.3919			.1006
13	.1863	.1879	.3753	.3346	.3727	.3018	.1126
14	.2236	.1882	.3753		.3727	.2683	.1127
15	.2241	.1877	.3757		.3727	.3018	.1129
16	.2241	.1877	.3757	.4005	.3727	.3018	
17	.1863	.1877	.4321	.3668	.3354	.2683	
18	.2236	.2254	.1873	.1844	.2241	.2103	
19	.2609	.263	.206	.2266	.2614	.2804	.2273
20	.4099	.3006	.1877	.3409	.4481	.3189	.2651
21	.4472	.3003	.1877	.4141	.4108	.3224	.2651
22	.4108	.3003	.1873	.4137	.4108	.3224	.2651
23	.4099	.3003	.1873	.3761	.4099	.3189	.2651
24	.2996	.2614	.3006	.1873	.3402	.3734	.2865
Max	.5018	.5963	.4321	.4141	.4481	.3734	.3155
Min	.1863	.1877	.1873	.1686	.1894	.1867	.1006
Avg	.3082	.3165	.2690	.2685	.3203	.3107	.2327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304044 / 33 KV SHIRAJGAON SUBSTATION

Feeder No / Name : 203 / KHARADGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3285	.4108	.3006	.2247	.2646	.2614	.3544
2	.3525	.4472	.3003	.2245	.2649	.2614	.3544
3	.3528	.4481	.3006	.2252	.2651	.2241	.3544
4	.3525	.4854	.3006	.2252	.2649	.2236	.3544
5	.373	.5228	.3003	.2627	.2649	.2236	.3544
6	.4015	.559	.263	.3003	.3027	.2241	.3898
7	.4684	.5963	.1877	.3003	.303	.2241	.3856
8	.5353	.5975	.1877	.3003	.303	.2236	.4161
9	.4961	.6387	.1879	.2651	.2273	.2236	.4115
10	.2651	.1879	.3757		.5001	.4845	.2058
11	.1892	.188	.3746				.1006
12	.1882	.1877	.3757	.5207			.1006
13	.1304	.1877	.563	.5292	.4099	.4024	
14	.1494	.1501	.5993	.5292	.6335	.4024	.1501
15	.1497	.1877	.6011		.3727	.3688	
16	.1494	.1877	.5636	.5953	.708	.3353	
17	.112	.1879	.6381	.6615	.6335	.1677	
18	.1867	.2627	.1877	.1818	.1863	.2804	
19	.2241	.3381	.2247	.2263	.2609	.3189	.2651
20	.2981	.3381		.3409	.3361	.3189	.3409
21	.3354	.3378	.2254	.3385	.2987	.3224	.3409
22	.2987	.3181	.2622	.3006	.2614	.2804	.2651
23	.2609	.3003	.2622	.3009	.2614	.3224	.2651
24	.412	.2987	.3003	.2625	.3021	.2609	.3224
Max	.5353	.6387	.6381	.6615	.708	.4845	.4161
Min	.112	.1501	.1877	.1818	.1863	.1677	.1006
Avg	.2921	.3485	.3427	.3388	.3466	.2889	.3017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304062 / 33 kV Malkhed Sub-station

Feeder No / Name : 201 / 11 kV LASINA AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3563	.3401	.1966	
2			.3563	.3401	.1966	
3			.3401	.3239	.1966	
4			.3401	.3239	.213	
5			.3563	.3239	.213	
6			.3725	.421	.213	
7			.5218	.5344	.1966	
8			.5376	.5182	.2294	
9			.4744	.5182	.2785	
10	.426	.5571			.0554	.2812
11	.4588	.5407			.0655	.3281
12	.5243	.6226				.4218
13	.5243	.6062				
14	.5243	.5898				
15	.5243	.5735				.3593
16	.5571	.5407			.2949	
17	.5735	.5407			.2294	
24			.3725	.1966		
Max	.5735	.6226	.5376	.5344	.2949	.4218
Min	.426	.5407	.3401	.1966	.0554	.2812
Avg	.5141	.5714	.4028	.3840	.1983	.3476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

NER S/DN.[320]

BU 3204

Substation No/ Name :- 304062 / 33 kV Malkhed Sub-station

Feeder No / Name : 203 / 11 KV YELGUNDA AG Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8131	.8871	.8131	.9055	.8402	.8871	.7762
2	.8131	.8501	.8131	.8871	.8316	.8871	.7762
3	.8131	.8501	.8131	.8686	.8131	.9055	.7762
4	.7947	.8501	.8131	.8316	.8131	.9055	.7577
5	.7947	.8501	.8316	.8501	.8131	.924	.7577
6	.7762	.8131	.8501	.8501	.924	.924	.7392
7	.7023	.7392	.7947	.9979	.9709	.9795	.6468
8	.6468	.7392	.6653	1.0349	.8871	.924	.6653
9	.6653	.7762	.6468	.9795	.8871	.924	.5544
10	.6838	.9425	.499	.5729	.4066	.8501	.3696
11	.7023	.924				.5914	.5175
12	.7023	.8316	.4251	.3511	.3881	.5359	.6099
13	.7762	.8316		.3881	.3696		.4251
14	.7762	.8316		.3881	.4066	.4251	
15	.7392	.9979	.4066			.5359	.7023
16	.7392	.7762	.462	.4251	.4435	.6468	
17	.5914	.8501	.499	.4805	.4805	.6226	
18	.7023	.6468	.6283	.6283	.6653	.5914	.4805
19	.8131	.8316	.8501	.8686	.8131	.8131	.8871
20	1.0719	.9795	.961	1.0164	.924	.924	.9979
21	.9425	.961		.7762	.9055	.8501	.8871
22	.9795	.924		.8775	.8871	.8501	.8316
23	.9055	.9055	.8316	.7468	.8871	.8131	.8316
24	.8871		.8316	.924	.8871		.7947
Max	1.0719	.9979	.961	1.0349	.9709	.9795	.9979
Min	.5914	.6468	.4066	.3511	.3696	.4251	.3696
Avg	.7847	.8517	.7071	.7568	.7384	.7868	.7040



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816] BU 4816

Substation No/ Name :- 304005 / 33/11KV S/S RALEGAON

Feeder No / Name : 201 / 11KV RALEGAON TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.134	1.1706	1.1706	1.0791	.9877	1.0242
2	1.134	1.0974	1.134	1.134	1.0608	.9877	1.0242
3	1.1222	1.0608	1.134	1.0974	1.0608	.9694	1.0242
4	1.086	1.0242	1.134	1.0608	1.0242	.9694	1.0059
5	1.0317	1.0059	1.1157	1.0608	1.0242	.9511	1.0059
6	.9593	.9877	1.0242	1.0425	1.0059	.9328	.9877
7	.8048	.8962	.8962	.9511	.8779	.8779	.9145
8	.7316	.823	.8048	.7682	.7316	.8779	.7682
9	.7499	.8048	.8048	.7316		.823	.695
10	.6401	.8048	.8413			.8413	.7316
11	.7682	.7865	.7865	.7682			.8048
12	.8779	.7133		.7316	.8779		.8048
13	.9511	.9145			.823	.823	.8413
14	.9877	.9145		.7682	.8596	.7865	.8413
15	.9694	.9511	.9145	.7316	.8596	.8048	.8413
16	.9145	.8688		.7316	.8779		.8048
17				.7682	.8779	.8779	.7316
18	.9145	1.1222	.9145	.8596	.9145	.8962	.7316
19	.9328	1.134	1.134	.9511	1.0059	1.0608	.8596
20	1.1222	1.2437	1.2803	1.1706	1.0974	1.1706	1.0242
21	1.1765	1.2803		1.1706	1.1157	1.1706	1.0425
22	1.2308	1.3169	1.2437	1.1888	1.134	1.1888	1.0242
23	1.2254	1.2803	1.2254	1.134	1.0974	1.134	.9511
24		1.1888	1.2254	1.1888	1.0791	1.0242	1.0425
Max	1.2308	1.3169	1.2803	1.1888	1.134	1.1888	1.0425
Min	.6401	.7133	.7865	.7316	.7316	.7865	.695
Avg	.9757	1.0154	1.0436	.9627	.9754	.9598	.8970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816] BU 4816

Substation No/ Name :- 304005 / 33/11KV S/S RALEGAON

Feeder No / Name : 202 / 11KV KALAMNER FEEDER  
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3292	.2926	.3109
2		.3292	.2926	.3109
3		.3292	.2926	.0183
4		.3109	.2743	.3109
5		.3109	.2743	.2926
6		.2926	.2561	.2378
7		.2012	.2195	.2012
8		.2012	.1829	.1463
9		.2012	.1463	.1463
10			.1463	.1463
11				.1646
12		.1463		.1829
13		.1463	.1829	.1829
14		.1463	.1646	.2195
15		.1463	.1646	.1463
16		.1463		.1463
17	.0732	.1829	.1646	.1463
18	.2378	.1829	.2012	.2012
19	.3109	.2378	.2926	.2561
20	.3658	.2378	.3292	.3109
21	.3292	.3292	.3475	.3292
22	.3475	.3109	.3475	.3292
23	.3292	.2926	.3292	.2926
24		.3292	.2926	.3109
Max	.3658	.3292	.3475	.3292
Min	.0732	.1463	.1463	.0183
Avg	.2848	.2427	.2473	.2225

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304005 / 33/11KV S/S RALEGAON

Feeder No / Name : 203 / 11KV ZADGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.7316	.7682	.695	.2926	.2926	.2195
2	.695	.695	.7499	.6767	.2926	.2561	.2195
3	.6516	.695	.7421	.6584	.2926	.2195	.2195
4	.6516	.6584	.7421	.6219	.2926	.2195	.2195
5	.6154	.6584	.7421	.6219	.2926	.2195	.2926
6	.5304	.6584	.7783	.5853	.2926	.2195	.2195
7	.4024	.6219	.8596	.5487	.2195	.1829	.1463
8	.4024	.6219	.6401	.5121	.2195	.1463	.1463
9	.439	.7316	.9511	.3658	.1463	.1463	.1463
10	.6584	.8779	.6401			.1463	.1463
11	.7316	.7316	.6036	.4024			.1463
12	.8779	.8962		.439	.2195		.1463
13	1.0242	1.0242			.2195	.1463	.1463
14	.9694	1.0242		.7682	.2195	.1463	.1463
15	.9511	1.0242	.5853	.3658	.2195	.1463	.1463
16	.9328	.8048		.3658	.2195		.1463
17	.9145	.8048		.1463	.2195	.1463	
18	.3658	.5973	.6219	.2926	.2195	.2195	.2195
19	.695	.8048	.6219	.3658	.2926	.3658	.2195
20	.7316	.7316	.7316	.5121	.3658	.439	.3292
21	.7682	.8779		.5121	.3658	.2926	.3292
22	.8048	.8048	.7316	.5121	.3658	.2926	.2926
23	.7682	.7316	.7316	.439	.3292	.2926	.2561
24		.7316	.7682	.695	.2926	.2926	.2926
Max	1.0242	1.0242	.9511	.7682	.3658	.439	.3292
Min	.3658	.5973	.5853	.1463	.1463	.1463	.1463
Avg	.7077	.7725	.7227	.5046	.2677	.2299	.2083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304005 / 33/11KV S/S RALEGAON

Feeder No / Name : 204 / 11KV JALKA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5853	.4572	.5121	.8779	.3658	.5121
2	.5853	.5853	.4572	.5121	.8779	.3658	.5121
3	.5792	.6219	.5068	.4755	.8048	.3658	.5121
4	.5792	.6584	.5068	.4755	.8048	.439	.439
5	.567	.6584	.5121	.439	.7316	.439	.439
6	.695	.7316	.4938	.439	.7316	.439	.439
7	1.0059	.7682	.3658	.439	.439	.4024	.3658
8	1.0974	.8413	.4024	.439	.3658	.3658	.3658
9	1.1706	.9145	.4024	.3658		.3292	.3658
10	.439	.439	1.0425			.2926	.3658
11	.439	.4755	1.3352	.8779			.3658
12	.3658	.4755		.9511	.5121		.3658
13	.3658	.439		.9145	.3658	.2926	.3292
14	.3658	.439		.7682	.439	.2926	.3292
15	.439	.4755	1.1706	.7316	.439	.3658	.2926
16	.3658	.3982		.7316	.5121		.2926
17		.3658		.6584	.5121	.2195	.2926
18		.3658	.439	.5121	.5487	.3658	.2926
19		.3292	.439	.7316	.5487	.5853	.3658
20	.7316	.4572	.5121	.9511	.695	.8779	.439
21	.5487	.5853		.9511	.439	.5121	.439
22	.5487	.4755	.5853	.9511	.439	.439	.4024
23	.5853	.4938	.5853	.8779	.439	.439	.3658
24		.5853	.4572	.5487	.8779	.3658	.5121
Max	1.1706	.9145	1.3352	.9511	.8779	.8779	.5121
Min	.3658	.3292	.3658	.3658	.3658	.2195	.2926
Avg	.6039	.5485	.5928	.6632	.5905	.4076	.3917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304005 / 33/11KV S/S RALEGAON

Feeder No / Name : 205 / 11KV EXEPRESS FEEDER RLG

HV Express Feeder

H.P. Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0189	.0189	.0189	.0189	.0189
2	.0171	.0189	.0189	.0189	.0189	.0189	.0189
3	.0189	.0189	.0189	.0189	.0189	.0189	.0189
4	.0189	.0189	.0189	.0189	.0189	.0189	.0189
5	.0189	.0189	.0189	.0189	.0189	.0189	.0189
6	.0189	.0189	.0189	.0189	.0189	.0189	.0189
7	.0189	.0189	.0189	.0189	.0189	.0189	.0189
8	.0189	.0189	.0189	.0189	.0189	.0189	.0189
9	.0189	.0189	.0189	.0189	.0189	.0189	.0189
10	.0189	.0189	.0189			.0189	.0189
11	.0189	.0189	.0189	.0189			.0189
12	.0189	.0189		.0189	.0189		.0189
13	.0189	.0189		.0189	.0189	.0189	.0189
14	.0189	.0189		.0189	.0189	.0189	.0189
15	.0189	.0189	.0189	.0189	.0189	.0189	.0189
16	.0189	.0189	.0189	.0189	.0189		.0189
17	.0189	.0189		.0189	.0189	.0189	.0189
18	.0189	.0189	.0189	.0189	.0189	.0189	.0189
19	.0189	.0189	.0189	.0189	.0189	.0189	.0189
20	.0189	.0189	.0189	.0189		.0189	.0189
21	.0189	.0189		.0189	.0189	.0189	.0189
22	.0189	.0189	.0189	.0189	.0189	.0189	.0189
23	.0189	.0189	.0189	.0189	.0189	.0189	.0189
24		.0189	.0189	.0189	.0189	.0189	.0189
Max	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Min	.0171	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0188	.0189	.0189	.0189	.0189	.0189	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816] BU 4816

Substation No/ Name :- 304012 / 33KV WADKI S/S

Feeder No / Name : 201 / WADKI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.924	.7975	.724	.6722	.5765	.724
2	.8326	.823	.8063	.7164	.6653	.583	.6299
3	.8048	.823	.815	.6805	.6653	.5959	.6443
4	.7468	.8131	.8326	.631	.6401	.6089	.6588
5	.6283	.8131	.7947	.6024	.6219	.6283	.5487
6	.5729	.7499	.6584	.4908	.5121	.543	.4908
7	.5068	.6335	.5249	.4908	.4163	.5014	.4706
8	.5014	.788	.5138	.4656	.394	.4207	.4344
9	.5258	.8063	.5847	.4656			.4031
10	.5731	.8322	.5895	.4477			.3856
11	.5973	.8139	.567				.3944
12	.6335	.7888	.6089	.4656	.4161		.4115
13	.6335	.815	.5609	.5194	.3898	.3944	.4161
14	.7964	1.0631	.6024	.5316	.3467	.3814	.4287
15	.6626	1.0277	.5847		.3814		
16	.7442	.8505	.6556	.4961	.4207	.4161	
17	.7362	.6089	.4973	.4298	.4161	.4801	
18	.7802	.6805	.6415			.5138	.4784
19	.8145	.7865	.7682	.6036	.6154	.6401	.543
20	.9979	.9979	.9795	.7468	.7207	.8131	.695
21	1.0974	1.0534	.961	.7468	.6838	.7947	.7392
22	.9709	.961		.7023	.6722	.7947	.7023
23	.9425	.8871	.7762	.6838	.6653	.7392	.6468
24	.8589		.8501	.7762	.6722	.6219	.724
Max	1.0974	1.0631	.9795	.7762	.7207	.8131	.7392
Min	.5014	.6089	.4973	.4298	.3467	.3814	.3856
Avg	.7424	.8409	.6944	.5913	.5494	.5814	.5509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304012 / 33KV WADKI S/S

Feeder No / Name : 202 / KHAIRY

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4477	.4409	.4161	.362	.3696	.3086
2	.4024	.4477	.4409	.3856	.362	.3696	.3086
3	.39	.4477	.4409	.3772	.3403	.3696	.2865
4	.3681	.4344	.4409	.3353	.3439	.362	.2629
5	.3086	.4344	.4477	.3353	.3224	.3045	.2279
6	.2715	.3856	.3814	.3315	.2686	.2629	.2058
7	.3086	.3561	.3391	.3315	.2601	.2229	.1928
8	.4096	.5304	.4096	.3277	.2229	.1823	.1928
9	.4858	.639	.4321	.427			.218
10	.4961	.6962		.4321			.1886
11	.5304	.6706	.4748				.1865
12	.6464	.6443	.4696	.502	.2012		.2204
13	.6226	.7042	.5304	.5243	.1696	.1781	.218
14	.6133	.7377	.5079	.4372	.1715	.1658	.218
15	.5304	.78	.547		.1886		
16	.5304	.5967	.5506	.2155	.2229	.2204	
17	.6299	.407	.5636	.1823	.2374	.213	
18	.6299	.3521	.4481			.2035	.2279
19	.5426	.4508	.4801	.3189	.3077	.3045	.2507
20	.6201	.5373	.4835	.3841	.3841	.3696	.3258
21	.6201	.5611	.4887	.3881	.3841	.3841	.3801
22	.567	.5068		.3841	.362	.3801	.3582
23	.4706	.4706	.4298	.3801	.362	.3258	
24	.439	.4525	.4656	.4252	.362	.3582	.3189
Max	.6464	.78	.5636	.5243	.3841	.3841	.3801
Min	.2715	.3521	.3391	.1823	.1696	.1658	.1865
Avg	.4945	.5288	.4642	.3734	.2918	.2919	.2549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304063 / 33/11kv Zadgaon

Feeder No / Name : 202 / 11kv Saoner FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	1.0829	1.5546	.9877	.8501	.7468	.7842
2	.9328	1.1203	1.5546	.9877	.8131	.7468	.7655
3	.9145	1.0829	1.5546	.9877	.8131	.7468	.7655
4	.9145	1.1203	1.5546	.9979	.7762	.7468	.7655
5	.9511	1.1273	1.5912	.9979	.7392	.7095	.7655
6	.9511	1.1946	1.5565	.8316	.7095	.5359	.6283
7	1.0576	1.4529	1.3847	.7316	.6722	.5373	.5729
8	1.0974	1.8054	1.387	.6283	.6653	.5373	.499
9	1.0802	1.8229	1.448	.5914	.5853	.5194	.462
10	.6878	.8131	1.5927	.7209	.3982	.3511	.547
11	.7421	.8954	1.9334			.3658	.5658
12		1.0924	1.933			.3801	.4458
13	.905	1.1789	1.933	.8478		.439	.5548
14	.9326	1.2178	1.6956		.4207	.439	.5847
15	1.1222	1.086	1.6448		.439	.4024	.5493
16	.9231	1.086	1.5089	.7373	.4755	.4207	.6516
17	.905	.905	1.4922	.7545	.6154	.4525	
18	.8669	1.3169	1.3352	1.4784	1.3203	1.1317	1.2323
19	1.6448	2.1285	2.0538	1.9605	1.6975	1.7924	1.7164
20	2.5463	2.9424	2.5766	2.3712		2.2822	2.1125
21	2.7633	2.9424	2.3954	2.3739	2.4768	2.5463	2.2068
22	2.6972	2.8104	2.3954	2.3061	2.4331	2.5086	2.0748
23	2.452	2.6029	2.32	2.3954	2.3011	2.3011	1.9427
24	.9328	1.0269	1.5339	.9877	.8501	.7762	.8215
Max	2.7633	2.9424	2.5766	2.3954	2.4768	2.5463	2.2068
Min	.6878	.8131	1.3352	.5914	.3982	.3511	.4458
Avg	1.2588	1.4939	1.7471	1.2338	1.0026	.9340	.9571



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

RALEGAON S/DN.[816]

BU 4816

Substation No/ Name :- 304063 / 33/11kv Zadgaon

Feeder No / Name : 203 / 11kv Ekbhurji FEEDER  
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358	1.3676	1.0498	1.3432	1.2936	1.0829	1.2574
2	1.358	1.3676	1.0498	1.2894	1.2936	1.0829	1.2574
3	1.2715	1.3491	1.0498	1.2536	1.2437	1.0829	1.2574
4	1.2715	1.3491	1.0498	1.2536	1.2437	1.0829	1.2574
5	1.3527	1.363	1.0387	1.2536	1.2071	1.0269	1.2574
6	1.1622	1.1949	1.0277	1.335	1.1584	.8316	1.0562
7	.7733	.9055	1.1401	1.5089	1.1218	.6935	.7167
8	.7922	.9055	1.2944	1.6933	1.0802	.6762	.5658
9	.6468	.6379	1.326	1.6095	.7888	.5959	.5093
10	1.1904	1.4251	.5093	.567	.3982	.4668	.5304
11	1.6956	1.6575	.5847			.3772	.5304
12		1.7736	.6036			.3395	.5256
13	1.6787	1.7736	.6036	.6979		.4904	.5375
14	1.8347	2.0405	.8299		.5658	.5658	.567
15	1.6617	1.9719	.8299		.6224	.5847	.5373
16	1.6956	1.8861	.9054	.5847	.6413	.547	
17	1.7804	1.8107	.8488	.6413	.4338	.6224	
18	1.5249						
19	1.5249						
20					.6413		
21			2.3954				.5493
22							.5493
23	1.5249						.5493
24	1.3073	1.386	1.0608	1.3611	1.2936	1.1389	1.3146
Max	1.8347	2.0405	2.3954	1.6933	1.2936	1.1389	1.3146
Min	.6468	.6379	.5093	.567	.3982	.3395	.5093
Avg	1.3703	1.4536	1.0104	1.1709	.9392	.7382	.8066

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304016 / 33KV KOLAMBI

Feeder No / Name : 201 / 11kv Kolambi Gaonthan  
Feeder KV- 11 / OUTGOING

Gaonthan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3142	.3142	.2987	.3142	.3142	.2957
2	.3121	.3142	.3142	.2987	.3142	.3142	.2987
3	.3326	.3142	.3142	.2987	.3142	.3142	.2987
4	.3142	.3142	.3142	.2987	.3142	.2957	.2801
5	.2957	.2957	.2772	.2801	.2957	.2772	.2614
6	.2772	.2772	.2587	.2614	.2801	.2402	.2427
7	.2587	.2402	.2195	.2218	.2241	.2241	.2402
8	.2402	.2561	.2195	.2033	.2218	.2033	.2218
9	.2218	.2218	.2012	.2033	.2033	.2054	.1991
10	.1448	.2012	.1254	.1829	.1663		.1267
11	.1629	.181	.0876	.1448	.128		.1086
12	.181	.181	.1402	.1433	.128		.1086
13	.181	.1829	.1595	.1612	.1097		.1086
14	.181	.1848	.1417	.1629	.1097		.1267
15	.1991	.2012	.1595	.0716	.1294		.1267
16	.1791	.197	.1791	.1097	.1463	.1097	
17	.1772	.2126	.1791	.128	.1646	.128	.1629
18	.2103	.2534	.2481	.2195	.181	.2172	.2587
19	.3077	.3658	.362	.3109	.2587	.2534	.3326
20	.3292	.4024	.3658	.3658	.3326	.3326	.2957
21	.3658	.4024	.3696	.4024	.3326	.3326	.3326
22	.3696	.3658	.3696	.3475	.3326	.3326	.3326
23	.3511	.3658	.3511	.3292	.3326	.3142	.2772
24	.3326	.3326	.3326	.2957	.3109	.3142	.3142
Max	.3696	.4024	.3696	.4024	.3326	.3326	.3326
Min	.1448	.181	.0876	.0716	.1097	.1097	.1086
Avg	.2607	.2741	.2502	.2392	.2352	.2624	.2326

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304016 / 33KV KOLAMBI

Feeder No / Name : 202 / 11kv Akola Bazar Gaonthan  
Feeder KV- 11 / OUTGOING

Gaonthan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.2323	1.2323	1.1576	1.2197	1.2197	1.1203
2	1.1949	1.2323	1.2323	1.1576	1.2197	1.2197	1.1203
3	1.1949	1.2323	1.2323	1.1576	1.2197	1.2197	1.1203
4	1.1763	1.2136	1.2323	1.1576	1.2197	1.1827	1.1203
5	1.1576	1.1576	1.1827	1.1576	1.1458	1.1576	1.1016
6	1.1389	1.0719	1.1458	1.1389	1.1088	1.0829	1.0829
7	.9335	1.0349	1.2012	1.0164	1.0534	1.0534	.9795
8	.8131	.961	1.1458		.8316	.9425	.8871
9	.7762	.8316	.8413		.8131	.7762	.7682
10	.6653	.7392	.7133		.6653		.6036
11	.6653	.7392	.6697	.5853	.6154		.6036
12	.6468	.7023	.724	.5792	.6154		.567
13	.6283	.7392	.6767	.5792	.6036		.543
14	.6283	.7392	.6697	.5973	.5792		.5249
15	.6653	.7682	.6516	.5487	.5973		.543
16	.6468	.7865	.567	.5853	.6154	.5121	
17	.695	.7964	.6283	.5853	.6335	.5121	.823
18	.7316	.8779	.8596	.9145	.7964	.8316	.9877
19	1.0974	1.2197	1.3306	1.2936	1.1088	1.1827	1.1273
20	1.2936	1.4045	1.3676	1.3676	1.2936	1.307	1.1203
21	1.3306	1.4045	1.3306	1.3676	1.307	1.0719	1.1203
22	1.2936	1.3676	1.3306	1.3306	1.2567	1.2323	1.0829
23	1.2567	1.2936	1.2382	1.2752	1.2197	1.1706	1.0829
24	1.1949	1.2323	1.2696	1.1458	1.2567	1.2197	1.0974
Max	1.3306	1.4045	1.3676	1.3676	1.307	1.307	1.1273
Min	.6283	.7023	.567	.5487	.5792	.5121	.5249
Avg	.9592	1.0324	1.0197	.9856	.9581	1.0497	.9186

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304016 / 33KV KOLAMBI

Feeder No / Name : 203 / 11kv Karegaon Gaonthan  
Feeder KV- 11 / OUTGOING

Gaouthan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.5121	.499	.4805	.5121	.4755	.4805
2	.4805	.5121	.499	.4805	.5121	.4755	.4805
3	.4805	.5121	.499	.4805	.5121	.4755	.4805
4	.4805	.5121	.499	.4805	.5121	.4755	.4805
5	.4805	.4938	.462	.4805	.4938	.4755	.4805
6	.4805	.4755	.4251	.4805	.4755	.4572	.4572
7	.4207	.4755	.4572	.4607	.5304	.439	.4755
8	.3982	.4344	.439		.4706	.4572	.4344
9	.3761	.394	.4252		.4163	.3982	.3582
10	.2835	.3189	.298		.2835	.2279	.2658
11	.2534	.3189	.1734	.2507	.2103	.2279	.2481
12	.2534	.3045	.2774	.2507	.2126	.208	.2103
13	.2507	.2865	.2804	.2328	.2172	.208	.2103
14	.2507	.2686	.2774	.2481	.2328	.2103	
15	.2534	.3045	.2126	.2658	.2303	.2103	
16	.2715	.3544	.2126	.2629	.2254	.2279	
17	.2865	.3898	.2835	.2804	.2427	.2629	
18	.3189	.4477	.4075	.4298	.3467	.3761	
19	.5068	.5792	.5121	.5249	.4755	.5068	
20	.5487	.5853	.5792	.5792	.5121	.5487	
21	.5853	.5487	.5487	.5853	.5121	.5121	.4805
22	.5487	.5487	.5544	.5487	.5121	.5121	.462
23	.5487	.5487	.5359	.5304	.4938	.4938	.4066
24	.4607	.5304	.5359	.4805	.5175	.4755	.4805
Max	.5853	.5853	.5792	.5853	.5304	.5487	.4805
Min	.2507	.2686	.1734	.2328	.2103	.208	.2103
Avg	.4041	.4440	.4122	.4197	.4025	.3891	.4054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304016 / 33KV KOLAMBI

Feeder No / Name : 206 / 11 KV KOLAMBI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0156	.0156	.0156		.1562	.0625	.0156
2	.0156	.0156	.0156		.1562	.0625	.0156
3	.0156	.0156	.0156		.1562	.0625	.0156
4	.0156	.0156	.0156		.1562	.0625	.0156
5	.0156	.0156	.0156		.1875	.0937	.0156
6	.0156	.0156	.0156		.2187	.125	.0156
7	.0156	.0156	.0156	.0312	.25	.1562	.0156
8	.0156	.0156	.0156		.3125	.1875	.0156
9	.0156	.0156	.0156		.4687	.1562	.0156
10		.25	.0156		.0156		.1718
11	.1406	.3906	.0156	.0625	.0156		
12	.1562	.4218	.0156	.0625	.0156		
13	.1875	.4218	.0156		.0156		.125
14	.1875	.4218	.0156		.0156		.1562
15	.1875	.4062		.0312	.0156		.0937
16	.2187	.3749		.0312	.0156	.125	
17	.2187	.3437		.1562	.0156	.1562	.0937
18	.0156	.0156	.0156	.1875	.0156	.0156	.0937
19	.0156	.0156	.0156	.1875	.0156	.0156	.0781
20	.0156	.0156	.0156	.0156	.0156	.0156	.0625
21	.0156	.0156	.0156	.0156	.0156	.0156	.0156
22	.0156	.0156	.0156	.0156	.0156	.0156	.0156
23	.0156	.0156	.0156	.0156	.0156	.0156	.0156
24	.0156	.0156	.0156		.1562	.0625	.0156
Max	.2187	.4218	.0156	.1875	.4687	.1875	.1718
Min	.0156	.0156	.0156	.0156	.0156	.0156	.0156
Avg	.0672	.1367	.0156	.0677	.1015	.0781	.0513

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304033 / 33KV JODMOHA

Feeder No / Name : 201 / 11kv Jodmoha Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762				.6478	.743
2	.0762				.6478	.743
3	.0762		.3239		.5716	.743
4	.0762				.5716	.6859
5	.1143				.5716	.6668
6	.1143				.6097	.6287
7	.1143				.6478	.5906
8	.1143				.6478	.6224
9	.1132				.6097	.5847
10		.2195	.2218		.4656	.3475
11		.2126		.2218	.3224	.2957
12		.2126	.2058	.2218		
13		.2835		.1848		
14		.2865		.1829		
15		.2896		.1829	.3582	
16		.2172	.2534	.695	.3582	
17		.1829	.2534	.5601	.3761	
18		.1463	.2378	.7468	.5175	.4748
19				.8383	.7545	.7167
20				.9526	.8299	.8299
21				.8383	.8215	.7545
22				.724	.8029	.7621
23				.6859	.7545	.724
24	.0762				.6478	.743
Max	.1143	.2896	.3239	.9526	.8299	.8299
Min	.0762	.1463	.2058	.1829	.3224	.2957
Avg	.0951	.2279	.2494	.5412	.5969	.6476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304033 / 33KV JODMOHA

Feeder No / Name : 203 / 11KV JODMOHA GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144		.5281	.4954	.4954	.4572	.4572
2	.4763		.5281	.4954	.4954	.4572	.4572
3	.4763		.5281	.4572	.4954	.4191	.4572
4	.4763		.5281	.4572	.4954	.4191	.4572
5	.4382		.5281	.4572	.4954	.4572	.4763
6	.4191		.547	.4954	.499	.4954	.4954
7	.4001		.547	.4954	.4706	.4954	.4715
8	.4001		.5281	.4954		.5144	.4904
9	.415		.4938	.5335		.4763	.4527
10	.3982	.4191		.5335		.3403	.3658
11		.381	.3012		.2957	.2328	.2772
12		.362	.3012		.2587		
13		.381	.3258		.2402		
14		.4191	.3224		.2378		
15		.4191	.3258		.2561	.2149	
16		.4382	.3258	.3258	.2561	.2328	
17		.4954	.3109	.3439	.3174	.2686	
18		.4954	.3658	.439	.4108	.3696	.4294
19		.547	.547	.5906	.5716	.547	.5281
20		.6478	.6668	.6287	.5335	.5281	.5658
21		.6668	.6478	.5525	.5144	.5228	.5281
22		.6036	.5716	.5335	.4954	.5041	.4954
23		.547	.5716	.5144	.4572	.4715	.4763
24	.5144		.5281	.4954	.4954	.4572	.4572
Max	.5144	.6668	.6668	.6287	.5716	.547	.5658
Min	.3982	.362	.3012	.3258	.2378	.2149	.2772
Avg	.4480	.4873	.4725	.4915	.4184	.4229	.4632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304033 / 33KV JODMOHA

Feeder No / Name : 204 / 11KV TALEGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191		.5281	.4954	.5335	.4191	.4763
2	.381		.5281	.4954	.4954	.4191	.4763
3	.381		.5281	.4763	.4954	.381	.4763
4	.381		.5281	.4382	.4954	.381	.4572
5	.381		.5281	.4382	.4954	.4191	.4572
6	.4191		.5281	.4763	.4805	.4572	.4382
7	.4191		.4904	.5335	.4706	.4191	.3961
8	.381		.4527	.5335		.381	.3961
9	.3395		.4024	.4954		.3429	.415
10	.2896	.4954		.3696		.2149	.3475
11		.4572	.3544		.1478	.1791	.2587
12		.4191	.3544	.2572	.2218		
13		.4191	.3189	.2896	.2218		
14		.4191	.2865				
15		.4191	.3258		.2561	.2328	
16		.4191	.3258	.2534	.2561	.2328	
17		.381	.3292	.362	.2987	.2686	
18		.4066	.4024	.4572	.3734	.3511	.4854
19		.5281	.5658	.5716	.5335	.4904	.4904
20		.5716	.6097	.5716	.5716	.5281	.5281
21		.6478	.5716	.6097	.4954	.5228	.5281
22		.6036	.5335	.5716	.4572	.5041	.5335
23		.5658	.5335	.5335	.4191	.4904	.4572
24	.4191		.5281	.4954	.5335	.4191	.4763
Max	.4191	.6478	.6097	.6097	.5716	.5281	.5335
Min	.2896	.381	.2865	.2534	.1478	.1791	.2587
Avg	.3828	.4823	.4589	.4631	.4126	.3835	.4497



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304033 / 33KV JODMOHA

Feeder No / Name : 205 / 11 KV PARWA GAONTHAN GFSS

Gaathan Feeder

NCC Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192		.7545	.7621	.7621
2	.7621		.7545	.7621	
3	.7621		.7545	.724	
4	.7621		.7545	.724	
5	.6859			.6478	
6	.6097			.5906	
7	.5716			.5525	
8	.5716			.5144	
9	.5281			.4763	
10	.4706	.5716		.4251	
11		.5144	.3898		.2957
12		.5716	.3721		
13		.5716	.3898	.3439	
14		.5525	.4477		
15		.5335	.4344		
16		.5144	.3982	.4344	
17		.5335	.3475		
18		.5729	.4572	.439	
19		.6979	.7545	.6668	
20		.8573	.8573	.9907	
21		.8954	.9145	.9335	
22		.8488	.8383	.9145	
23		.7922	.8002	.8764	
24	.8192		.7545	.7621	.8192
Max	.8192	.8954	.9145	.9907	.8192
Min	.4706	.5144	.3475	.3439	.2957
Avg	.6693	.6448	.6208	.6600	.6257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304065 / 33-KV ANTARGAON

Feeder No / Name : 201 / 11-KV ANTARGAON

Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	14-JUL-17
HR	Load (MW)
4	.7282
Max	.7282
Min	.7282
Avg	.7282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YAVATMAL (R) SUB-DN.[317] BU 3174

Substation No/ Name :- 304065 / 33-KV ANTARGAON

Feeder No / Name : 203 / 11-KV NANZA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8215	.8402	.7392	.7537	.57	.7468
2	.8316	.8029	.8402	.6468	.7459	.57	.7468
3	.8316	.8029	.823	.6468	.7287	.5596	.7282
4	.8145	.7842	.788	.6468	.7291	.5087	.7282
5	.724	.7762	.788	.6653	.7202	.5144	.6535
6	.724	.7499	.7362	.6154	.6935	.4801	.5609
7	.6089	.6584	.7011	.4887	.6661	.4854	.4917
8	.583	.7947	.7373		.5847	.583	.5426
9	.6516	.9511	.7956	.4706	.6036	.4508	.5201
10	.7042	1.0566	.8421		.6274	.2743	.5144
11	.6104	1.0117	.8421		.6173		.4359
12	.8417	1.0117	.8583	.4801	.5895		.4915
13	.8505	1.0341	.8097	.4858	.5548		.5407
14	.8417	.9602	.7935	.502	.5658		.5407
15	.815	.7545	.7935		.5087		.4915
16	.6878	.9431	.7935	.763	.5087	.4696	.4915
17	.7865	.9556	.7449	.8162	.5487	.4807	.4096
18	.8962	.8916	.8642	.8223	.6036	.4961	.4915
19	.924	.8402	.8916	.8002	.6516	.6081	.6226
20	.9896	.8954	.8916	.8381	.6935	.7042	.2683
21	1.0082	.9134	.7537	.7748	.7628	.7377	.6516
22	.9335	.9425	.7701	.7748	.7716	.7209	.6516
23	.8775	.8962	.7522	.7682	.6706	.7122	.6001
24	.8501	.8215	.8589	.7602	.7362	.6371	.7392
Max	1.0082	1.0566	.8916	.8381	.7716	.7377	.7468
Min	.583	.6584	.7011	.4706	.5087	.2743	.2683
Avg	.8015	.8779	.8046	.6753	.6515	.5559	.5691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 201 / 11kv DARDA NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3394	1.3756	1.267	1.3032	1.086	1.0317
2	1.267	1.267	1.3394	1.267	1.267	1.086	1.0136
3	1.1584	1.267	1.3394	1.267	1.267	1.086	.9774
4	1.1222	1.267	1.267	1.2308	1.1946	1.0498	.9412
5	1.1222				1.1946	1.0498	.9774
6	1.1403	1.1946	1.2308		1.1765	1.0498	.9955
7		1.1403	1.1946	.114	1.1946	1.0136	
8		1.1506	1.086	1.086	1.1222	.9412	
9			1.094		.9431	.9808	
10	.9997	1.094	1.0374	.9619	1.0185	.9619	.8688
11	1.0185	1.094	.9997	.9431	.9431	.9054	.8775
12	1.0562	1.0751	.9619	.9242	.8488	.8488	.8326
13	1.094	1.094	1.0185	.9054	.8488		.8326
14	1.1317	1.094	.9997	.9054	.8676	.7733	.8145
15	1.1506	1.1041	.9774		.8688	.5792	.8145
16	1.1694	1.1041	.9955		.8688	.5973	.8326
17	1.1506	1.0679	1.0136		.905	.8326	.905
18	1.1317		1.0317		1.0679	.9231	.9412
19	1.358		1.4118	1.3032	1.2308	1.1946	1.1403
20	1.5089	1.3756	1.4661	1.4299	1.2851	1.267	1.2851
21		1.587	1.4118	1.448		1.2308	
22	1.5203		1.448			1.2127	1.3203
23						1.1222	1.1694
24	1.3575	1.4299	1.448	1.3213	1.3575	1.1222	1.0317
Max	1.5203	1.587	1.4661	1.448	1.3575	1.267	1.3203
Min	.9997	1.0679	.9619	.114	.8488	.5792	.8145
Avg	1.1979	1.2081	1.1885	1.0916	1.0845	.9963	.9801

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 202 / 11kv MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3982	.4163	.4108	.3439	.3439
2	.362	.362	.3982		.3801	.3439	.3258
3	.3258	.362	.3982	.3982	.3801	.3439	.2896
4	.3258	.3258	.362	.3982	.362	.3439	.2715
5	.3258				.362	.3439	.2715
6	.3258	.3258	.3801		.3982	.3439	.2896
7		.3439	.362	.362	.3439	.3439	
8		.3018	.362	.3258	.362	.3174	
9			.4715		.3772	.3772	
10	.4527	.4338	.547	.4715	.3584	.4338	.3982
11	.5658	.5658	.6224	.5658	.3584	.4527	.5249
12	.6224	.6602	.679	.6036	.3395	.4527	.4887
13	.6036	.6413	.5281	.4904	.3584		.4854
14	5.6584	.5281	.547	.3961	.3395	.4715	.4344
15	.5093	.4706	.5068		.3258	.4344	.5249
16	.4715	.4525	.5068		.3258	.4344	.5611
17	.5093	.3077	.5068		.3439	.4344	.5068
18	.5847		.4887		.3258	.3982	.4706
19	.5281		.4706	.3982	.362	.3801	.3982
20	.4715	.4163	.362	.3982	.362	.362	.4163
21		.362	.3801	.362		.362	
22	.3801		.3439			.3258	.415
23						.3439	.415
24	.3801	.3801	.4163	.4344	.3982	.3439	.3439
Max	5.6584	.6602	.679	.6036	.4108	.4715	.5611
Min	.3258	.3018	.3439	.3258	.3258	.3174	.2715
Avg	.7245	.4223	.4563	.4301	.3607	.3796	.4088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 203 / 11kv Bhoyar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1086	.0905	.0905	.0905
2				.1086	.0905	.0905	.0905
3				.0905	.0905	.0905	.0724
4				.1086	.0724	.0724	.0724
5					.0724	.0724	.0724
6					.0724	.0724	.0724
7				.0905	.0724	.0543	
8		.1132		.0905	.0905	.0934	
9			.132		.1698	.0754	
10	.2641	.2264	.1509	.2452	.2075	.0566	.1086
11	.6412	.1132	.1698	.3018	.2641	.2641	.2715
12	.3584	.1132	.2452	.3395	.3206	.3018	.2534
13	.3018	.132	.2829	.2452	.2452		.2353
14	2.6265	.0943	.2075	.1698	.1132	.1886	.181
15	.2452		.181		.2715	.1629	.1991
16	.2452		.1629		.2896	.1448	.2172
17	.2452		.181		.2715	.1448	.2353
18	.2452		.181		.1629	.1448	.2715
19	.1886		.1448	.2172	.1267	.1086	.1267
20	.132		.1267	.1086	.0905	.0724	.0905
21			.1267	.1267		.0724	
22			.1267			.0905	.0943
23						.0905	.0943
24				.1086	.0905	.0905	.0905
Max	2.6265	.2264	.2829	.3395	.3206	.3018	.2715
Min	.132	.0943	.1267	.0905	.0724	.0543	.0724
Avg	.4994	.1321	.1728	.1640	.1560	.1150	.1470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 204 / 11kv Global

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1629	.181	.181	.2534	.2534	.1448
2	.1448	.1629	.181	.181	.2534	.2534	.1267
3	.1448	.1629	.1629	.181	.2353	.2353	.1267
4	.1448	.1629	.1629	.1629	.2353	.2353	.1267
5	.1448				.2353	.2353	.1448
6	.1448	.1629	.1629		.2353	.2172	.1629
7		.1629	.1629	.1629	.2172	.1991	
8		.1698	.1448	.1448	.2534	.2614	
9			.5093		.3206	.3018	
10	.6224	.4338	.6602	.7922	.3584	.3206	.7602
11	.7356	.4715	.7356	.8488	.4338	.5093	.8326
12	.8299	.5093	.811	.8865	.4904	.6602	.7421
13	.7733	.547	.7922	.8865	.4527		.7783
14	.679	.4527	.6602	.7733	.547	.5847	.6154
15	.7922	.4163	.724		.5068	.6335	.6697
16	.8299	.3982	.7783		.5068	.7059	.7602
17	.7922	.2715	.7964		.4887	.724	.8326
18	.7733		.7964		.4706	.7421	.8688
19	.6979		.7602	.724	.4887	.6154	.7964
20	.5658	.2534	.6878	.5792	.5068	.4706	.6878
21		.181	.4525	.543		.3258	
22	.1991		.2172			.1629	.3961
23						.1629	.1698
24		.1629	.181	.2172	.2715	.2534	.1448
Max	.8299	.547	.811	.8865	.547	.7421	.8688
Min	.1448	.1629	.1448	.1448	.2172	.1629	.1267
Avg	.5099	.2914	.4873	.4843	.3696	.3941	.4944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 207 / 11KV RAVIRAJ

DIVISION FEEDER

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0905	.0724	.1086	.0724	.0724	.1086
2	.1086	.0905	.0724	.1086	.0724	.0724	.1086
3	.0905	.0905	.0724	.1086	.0724	.0724	.1086
4	.0905	.0905	.0724		.0724	.0724	.1086
5	.181				.0724	.0724	.181
6	.2534	.1307	.0905		.1086	.1267	.2534
7		.2987	.3077	.0271	.2353	.2353	
8		.3239	.2534	.2534	.2427	.2715	
9			.2286		.2667	.3048	
10	.1905	.2667	.2858	.3239	.2667	.2096	.1991
11	.3048	.3048	.3048	.3239	.1905	.3048	.2534
12	.3239	.3048	.3429	.2858	.2667	.3048	.2353
13	.3048	.2858	.3239	.3048	.2667		.2896
14	.2858	.3239	.3239	.3239	.3048	.3048	.2715
15	.2858	.2715	.3077		.2896	.2172	.2896
16	.2858	.2534	.3077		.2715	.1991	.3077
17	.2858	.2534	.2715		.2896	.1991	.2534
18	.2667		.2172		.2172	.181	.2172
19	.2641		.2353	.2896	.2172	.1991	.1267
20	.2667	.2353	.2353	.2715	.2172	.1991	.2172
21		.181	.1991	.2353		.181	
22	.1267		.1629			.1448	.1509
23						.1267	.1143
24	.1086	.0905	.0905	.1086	.1086	.0724	.1086
Max	.3239	.3239	.3429	.3239	.3048	.3048	.3077
Min	.0905	.0905	.0724	.0271	.0724	.0724	.1086
Avg	.2175	.2159	.2172	.2195	.1963	.1802	.1952



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 401 / 33 KV RAYMONDS

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			7.3731	7.0588	6.9502	7.4303	6.8587
2		7.5446	7.4303	7.316	7.316	7.316	6.8587
3		7.4303	7.2017	7.5446	7.4303	7.316	7.2017
4		7.316	7.4303	7.4303	7.2017	6.973	7.4303
5					7.0873	7.2017	7.2017
6		7.4303	7.4303		7.4303	7.0873	7.2017
7		7.5446	7.0873	7.316	6.973	6.8587	
8		7.316	7.316	7.6589	7.0873	6.8587	
9			7.0873		7.316	7.2017	
10	7.4303	7.5446	6.973	7.5446	7.4303	7.0873	7.0873
11	7.4303	7.6589	7.316	7.316	7.316	6.973	7.316
12	7.4303	7.6955	7.4303	6.8587	7.2017	6.973	7.4303
13	7.4303	7.5446	7.5446	7.5446	7.2017		6.973
14	7.316	7.5446	7.316	7.5446	6.973	6.8587	7.2017
15	6.7444	7.2017	7.4303	7.5446	7.0873	6.8587	7.316
16	7.7732	7.316	7.5446	7.5446	7.2017	7.316	7.2017
17	7.6589	7.4303	7.4303		7.5446	7.4303	6.8587
18	7.5446		7.2017		7.0873	7.4303	6.8587
19	7.5446		7.316	7.0873	7.2017	7.4303	6.973
20	7.4303	7.2017	7.4303	6.7444	7.2017	7.4303	6.8587
21		7.4303	6.973	6.973		7.316	
22	7.4303		6.8587			7.316	7.0873
23						7.2017	7.0873
24	7.4303	7.316	7.6017	7.5446	7.2017	7.0873	6.8587
Max	7.7732	7.6955	7.6017	7.6589	7.5446	7.4303	7.4303
Min	6.7444	7.2017	6.8587	6.7444	6.9502	6.8587	6.8587
Avg	7.4303	7.4392	7.3056	7.3277	7.2115	7.1718	7.0931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304017 / 33 KV MIDC

Feeder No / Name : 402 / 33 kv BALAJI ELECTROSMELT

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.8578	3.0293	2.9721	3.0864	2.9721	
2		2.6863	2.8578	3.0293	2.9721	3.0293	
3		2.9721	2.9721	2.8578	3.0293	3.0293	
4		2.8578	2.6863	2.9721	2.8578	2.8578	
5					2.9721	2.915	
6		2.9721	2.9721		2.915	2.8578	
7		3.0864	2.915	3.0864	2.8578	2.9721	
8		2.9721	2.8578	2.8578	2.9721	2.915	
9			2.8578		2.8578	2.915	
10	2.8578	2.8578	2.8578	2.915	2.8006	2.8578	2.6863
11	2.915	2.8578	2.915	2.9721	2.915	2.8578	2.6863
12	2.9721	2.8578	2.9721	2.9721	2.9721	2.8578	2.8006
13	2.8578	2.9721	2.9721	2.9721	2.8578		2.8578
14	2.6292	2.8006	2.8578	2.7435	2.915	2.8578	2.6863
15	2.8578	2.915					2.915
16	2.915	2.8578					2.8006
17	2.8578	2.8006					2.9721
18	2.8578						2.915
19	2.8578						2.9721
20	2.915	2.8578					2.8578
21		2.8006	2.6863	3.0293			
22	2.915		2.8578				.1715
23							.1715
24		3.0293	2.9721	2.6863	2.8578	2.8578	
Max	2.9721	3.0864	3.0293	3.0864	3.0864	3.0293	2.9721
Min	2.6292	2.6863	2.6863	2.6863	2.8006	2.8578	.1715
Avg	2.8673	2.8895	2.8900	2.9281	2.9226	2.9109	2.4225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304022 / 33 KV TALAOFAIL

Feeder No / Name : 201 / 11 KV Sarafa Bazar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974		1.2437	1.134	1.0631	.9877	.961
2	1.0608		1.2437	1.134	1.0974	.9877	.961
3	1.0608		1.2437	1.134	1.0974	.9877	.961
4	1.0608	1.0242	1.2071	1.134	1.0974	.9877	.961
5	1.0242	1.0242	1.134	1.0974	1.0974	.9511	.961
6	1.0242	1.0974	1.134	1.0608	1.0974	.9511	.961
7	1.0242	1.0242	1.0974	1.0608	1.134	.9877	1.0349
8	.9877	1.0242	1.9387	1.0608	1.134	.9511	.9979
9	1.0719	1.0719	1.1088	1.0719	1.086	.9774	.9774
10	1.0349	1.0719	1.0719	1.0349	1.086	.9412	1.0498
11	.9511	1.0719	1.0242		.9774		1.0136
12	.9877	1.0349			.905		1.0136
13	1.0242	1.0349	.9877	.8779	.905	.8688	.9774
14	.9877	1.0349	.9511	.8779	.9511	.7964	.905
15	.9774	1.0136	.9511		.8779		.8048
16	1.0136	.9774	.9511	.8779	.9511	.8048	.8048
17	.9412	.905	.9145	.8779	.9511	.8048	
18	.9774	.9774	1.0136		1.0242	.9511	.8779
19	1.086	1.086	1.2071	1.0974		1.0608	1.0242
20	1.2308	1.2308	1.3169	1.1706		1.1706	1.0974
21	1.3032	1.267	1.2437	1.1706	1.3169	1.0974	1.0974
22	1.3032	1.267	1.2437	1.1706		1.0242	1.0242
23	1.2437	1.2803	1.2071	1.1706	1.0974	1.0349	.9979
24	1.0974	1.134	1.2437	1.1706	1.134	1.0242	.961
Max	1.3032	1.2803	1.9387	1.1706	1.3169	1.1706	1.0974
Min	.9412	.905	.9145	.8779	.8779	.7964	.8048
Avg	1.0655	1.0787	1.1599	1.0692	1.0515	.9690	.9750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304022 / 33 KV TALAOFAIL

Feeder No / Name : 203 / 11 KV Estantial

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145		1.0242	.9877	.9511	.8413	.8131
2	.8779		1.0242	.9877	.9511	.8413	.8131
3	.8779		1.0242	.9877	.9511	.8413	.8131
4	.8779	.8413	1.0242	.9511	.9511	.8048	.8131
5	.8413	.8413	.8779	.8779	.8779	.7316	.8131
6	.8048	.8048	.8779	.8779	.8779	.8048	.8131
7	.8048	.8413	.8413	.8779	.8413	.8048	.8131
8	.8048	.8048	.8779	.8048	.8413	.8048	.8131
9	.8501	.924	.8131	.8131	.8145	.7964	.7964
10	.8871	.8501	.924	.8501	.8326	.8688	.8688
11	.9877	.8871	1.0608		.9412		.9412
12	1.0242	.9979	1.134	.9979	1.0136		.9412
13	1.0974	1.0349	1.1706	1.0242	1.0136	1.0136	
14	1.0974	1.0349	1.2071	.9877	1.0608	.9412	.9412
15	1.1584	1.0136	1.2437		1.0608		.9511
16	1.1584	1.0498	1.2437	1.0242	1.0608	.9511	1.0242
17	1.086	1.0136	1.2437	1.0608	1.0974	.9877	
18	1.1584	1.0136	1.2308		1.0974	1.0242	1.0608
19	1.3032	1.1946	1.39	1.1706		1.2437	1.1706
20	1.3756	1.3032	1.39	1.2071	1.3169	1.2437	1.2437
21	1.3756	1.3032	1.3169	1.1706	1.2071	1.134	1.134
22	1.3756	1.267	1.0974	1.0608	.9877	.8779	.9511
23	1.0608	1.0974	1.0608	1.0608	.9145	.8501	.8871
24	1.0242	.9877	1.0242	1.0242	.9877	.8779	.8131
Max	1.3756	1.3032	1.39	1.2071	1.3169	1.2437	1.2437
Min	.8048	.8048	.8131	.8048	.8145	.7316	.7964
Avg	1.0343	1.0051	1.0884	.9907	.9848	.9183	.9195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304022 / 33 KV TALAOFAIL

Feeder No / Name : 204 / 11 KV Cotton

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803		1.4449	1.4632	1.3535	1.0608	1.0534
2	1.2803		1.4449	1.4632	1.2986	1.0608	1.0534
3	1.2437		1.4449	1.4632	1.2986	1.0608	1.0534
4	1.2437	1.2803	1.3717	1.3717	1.2986	1.0608	1.0534
5	1.2071	1.2437	1.3717	1.3717	1.2986	1.0242	1.0534
6	1.2071	1.2254	1.2986	1.3169	.8779	1.0974	1.1273
7	1.0974	1.2071	1.2803	1.1888	1.2071	1.0242	1.1523
8	1.0974	1.1706	1.2986	1.262	1.134	1.0242	1.1273
9	1.1523	1.1523	1.2254	1.1888	1.0974	1.0974	1.0791
10	1.0608	1.134	1.1706	1.1523	.9877	.9511	1.0974
11	1.0974	1.1706	1.0974		.9511		1.0425
12	1.1523	1.0425	1.0425	.9145	.8779		.9877
13	.4755	1.0608	1.1157	.9694	.9877	.823	
14	.439	1.134	1.0608	1.0608	.8779	.8048	.823
15	1.2254	1.0974	1.0974		.9877		
16	1.3535	1.0608	1.1523	1.1706	1.0242	.823	.9328
17	1.2071	1.0425	1.0974	1.0791	1.0059	.9145	
18	1.1888	1.0242	1.0974		.9511	.8962	1.0425
19	1.1888	1.1523	1.2803	1.1523		1.1706	1.2254
20	1.4815	1.4083	1.4632	1.3352	1.2437	1.1888	1.2803
21	1.4815	1.4083	1.4449	1.3717	1.262	1.2254	1.2437
22	1.4815	1.3717	1.5364	1.4266	1.2254	1.1888	1.1888
23	1.4266	1.5364	1.5181	1.4998	1.1523	1.1157	1.0974
24	1.2986	1.3717	1.4449	1.4632	1.3717	1.0974	1.0608
Max	1.4815	1.5364	1.5364	1.4998	1.3717	1.2254	1.2803
Min	.439	1.0242	1.0425	.9145	.8779	.8048	.823
Avg	1.1820	1.2045	1.2833	1.2707	1.1205	1.0338	1.0845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304040 / 33 KV WADGAON

Feeder No / Name : 201 / 11kv Wadgaon

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.5746	.3077
2						1.5565	1.3575
3						1.5565	1.3213
4						1.5565	1.3213
5						1.5565	1.3756
6						1.5565	1.4299
7						1.4842	1.4661
8						1.5023	1.448
9			1.5432			1.448	1.4299
10			1.5432				
11	1.6804	1.6461	1.5775				1.3375
12	1.6118	1.6118	1.5432	1.3032	1.3717	1.3717	1.2003
13	1.5775	1.5775	1.5432	1.3889	1.3375	1.3717	1.2346
14	1.5432	1.6118	1.5432	1.3546		1.3717	1.2003
15	1.5775	1.5432	1.5432			1.3717	1.2003
16					1.5045	1.3603	
17					1.5045	1.0883	1.3785
18					1.6512	1.3422	1.451
19				1.8531	1.7231	1.743	
20					1.85		1.7412
21					1.8682		1.8138
22							1.7049
23				2.2207			
24					2.1312	1.6108	1.448
Max	1.6804	1.6461	1.5775	2.2207	2.1312	1.743	1.8138
Min	1.5432	1.5432	1.5432	1.3032	1.3375	1.0883	.3077
Avg	1.5981	1.5981	1.5481	1.6241	1.6602	1.4679	1.3584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304040 / 33 KV WADGAON

Feeder No / Name : 203 / 11KV PRAVIN NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.6575	1.4089
2						1.6244	1.3916
3						1.5912	1.326
4						1.5912	1.2763
5						1.5581	1.3757
6						1.4918	1.4752
7						1.5415	1.5746
8						1.5581	1.5249
9			1.6804			1.3757	1.5083
10	1.6461		1.5775				
11	1.6804	1.3717	1.5432	1.5432			1.7147
12	1.6804	1.3717	1.5432	1.4403	1.6118	1.3717	1.6461
13	1.6461	1.406	1.5432		1.5432	1.4403	1.6118
14	1.7147	1.406	1.5775		1.5089		1.6118
15	1.7833	1.4403	1.5775		1.5432	1.406	1.5432
16					1.567	1.2836	
17					1.417	1.3003	1.2336
18					1.5003	1.5003	1.4337
19				1.8838	1.6671	1.7337	
20					1.8171		1.8004
21					1.9004		1.7837
22							1.7837
23				2.3137			
24				2.1963		1.6907	1.4586
Max	1.7833	1.4403	1.6804	2.3137	1.9004	1.7337	1.8004
Min	1.6461	1.3717	1.5432	1.4403	1.417	1.2836	1.2336
Avg	1.6918	1.3991	1.5775	1.8755	1.6076	1.5127	1.5241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304040 / 33 KV WADGAON

Feeder No / Name : 207 / 11kV SHASTRINAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.1222	1.0136
2						1.1222	.9774
3						1.1041	.9412
4						1.1041	.905
5						1.1041	.9774
6						1.086	1.0317
7						1.0498	1.1041
8						1.0498	1.086
9	1.0288		1.0802			.8869	.9774
10	.9088		1.0288				
11	.9602	.823	.823				.7202
12	.9945	.9602	.8573	.823	.8573	.6516	.7545
13	.9259	.9602	.8573	.7888	.8573	.6516	.7202
14	.9602		.8059	.7888			.7716
15	.9774	.9945	.8916				.703
16					.7706	.7706	
17					.8623	.7706	
18					1.0458	.9907	.7981
19				1.2659	1.2109	1.1008	
20					1.2843		1.2109
21					1.3944		1.2843
22							1.321
23				1.6095			
24				1.5364		1.1765	1.0498
Max	1.0288	.9945	1.0802	1.6095	1.3944	1.1765	1.321
Min	.9088	.823	.8059	.7888	.7706	.6516	.703
Avg	.9651	.9345	.9063	1.1354	1.0354	.9839	.9657



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304040 / 33 KV WADGAON

Feeder No / Name : 209 / 11 kV JAM ROAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0724	.0543
2				.0724	.0543
3				.0543	.0543
4				.0543	.0362
5				.0543	.0362
6				.0362	.0362
7				.0362	.0362
8				.0362	.0362
9				.0362	.0362
13	.1029				
18			.1101	.1101	
19		.1284	.1101	.1468	
20			.1101		.1101
21			.1101		.1101
22					.1101
23		.1629			
24		.0163		.0724	.0543
Max	.1029	.1629	.1101	.1468	.1101
Min	.1029	.0163	.1101	.0362	.0362
Avg	.1029	.1025	.1101	.0652	.0588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304040 / 33 KV WADGAON

Feeder No / Name : 403 / 33 KV RAYMOND SPINNING

Sheddable Rural/Mix Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6722	.6722
2						.6722	.6722
3						.6722	.6722
4						.6722	.6161
5						.6161	.6161
6						.6161	.5973
7						.5601	.5601
8						.6161	.6161
9			.5144			.6161	.5601
10	.5144		.5658			.5658	
11	.5658	.4115	.5658			.5144	.5144
12	.6173	.5144	.5658		.5658	.5658	.5658
13	.5144	.5658	.5658		.5144	.5658	.5144
14	.5658	.6173	.5658	.5144			.5658
15	.5658	.6173	.5658				.5144
16					.6187	.2812	
17					.6187	.2812	.4499
18					.6187	.3374	.3937
19				.6749	.6187	.3937	
20					.6187		.3937
21					.6187		.5624
22							.5624
23				.6161			
24				.6161		.6722	.6722
Max	.6173	.6173	.5658	.6749	.6187	.6722	.6722
Min	.5144	.4115	.5144	.5144	.5144	.2812	.3937
Avg	.5573	.5453	.5585	.6054	.5991	.5495	.5646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304053 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV LIC

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.4024	.4435	.4024	.4024	.3475	.3696
2	.3801	.3841	.4066	.4024	.3658	.3292	.3696
3	.3658	.3292	.3696	.3658	.3658	.3292	.3326
4	.3658	.3292	.3511	.3658	.3475	.2926	.3326
5	.3475	.2926	.3326	.3292	.3292	.2926	.2957
6	.3109	.2926	.3326	.3292	.3109	.2926	.2957
7	.3077	.2926	.2957	.3109	.3109	.2926	.2772
8	.3109	.2926	.3326	.3292	.2926	.2926	.2957
9	.3326	.3258	.4207		.3658	.3292	.3292
10	.3696	.3292	.4938		.4887	.4163	.439
11	.4755	.362	.6584		.543		.5249
12	.5121	.3982	.695	.5121	.6154	.543	.6626
13	.5304	.3982	.695	.6401		.5611	.6335
14	.5487	.4024	.695	.6219		.5792	.5973
15	.567	.4024	.6767	.6767	.6154	.5611	.6154
16	.5121	.4024	.7133	.695	.6154	.5973	.6154
17	.5121	.3881	.7133	.7059	.5853	.5853	
18	.5121	.499	.6584	.6697	.6584	.567	.5792
19	.6036	.499	.7133	.6584	.6401	.6036	.6516
20	.6401	.567	.6767	.6036	.6036	.6401	.5792
21	.5853	.567	.6036	.5611	.5853	.5121	.5068
22	.4755	.4938		.5068	.439	.439	.4163
23	.4755	.4755	.4572	.4572	.4207	.4024	.3982
24	.4024	.4207	.439	.439	.439	.3841	.4066
Max	.6401	.567	.7133	.7059	.6584	.6401	.6626
Min	.3077	.2926	.2957	.3109	.2926	.2926	.2772
Avg	.4510	.3978	.5293	.5039	.4700	.4430	.4576

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304053 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV ST WORK SHOP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.695	.7316	.6697	.6767	.5487	.5487
2	.6767	.6767	.7133	.6697	.6584	.5121	.5121
3	.6335	.6154	.6767	.6516	.6401	.5121	.5121
4	.5973	.5792	.6584	.6154	.6219	.4755	.4755
5	.5853	.5792	.6219	.5792	.5853	.4755	.4572
6	.5121	.543	.567	.5792	.567	.4572	.4572
7	.567	.5249	.5304	.5249	.567	.4887	.4938
8	.5121	.5304	.5487	.5249	.4938	.4938	.4755
9	.5304	.5068	.5304		.5068	.5068	.5121
10	.567	.5121	.5853		.5973	.5792	.6036
11	.6219	.543	.6219		.5792		.5611
12	.6584	.543	.6401	.6036	.5611	.4887	.5973
13	.6584	.5068	.6036	.5853	.5611	.4706	.5792
14	.6401	.543	.6036	.5853	.5792	.5792	.5792
15	.6584	.5853	.5853	.6767	.5973	.5611	.5249
16	.6767	.6154	.6584	.695	.5973	.5611	.543
17	.5853	.5914	.6516	.6697	.6036	.5487	
18	.6036	.5487	.6697	.6584	.6036	.5487	.5611
19	.724	.6219	.7059	.695	.6767	.6219	.6697
20	.7865	.6767	.7602	.7499	.695	.6584	.6697
21	.7499	.7059	.724	.724	.6767	.6219	.5973
22	.7682	.7682		.7499	.6767	.6219	.5973
23	.7682	.8048	.724	.7499	.6401	.5792	.5792
24	.7421	.7682	.7602	.7059	.7133	.567	.567
Max	.7865	.8048	.7602	.7499	.7133	.6584	.6697
Min	.5121	.5068	.5304	.5249	.4938	.4572	.4572
Avg	.6474	.6077	.6466	.6506	.6115	.5425	.5510

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304053 / 33 KV VIDYUT BHAVAN

Feeder No / Name : 203 / 11 KV TAHSIL

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3756	1.3969	1.4661	1.3611	1.39	1.1104	1.1222
2	1.3213	1.3432	1.3575	1.3253	1.3169	1.1104	1.086
3	1.2986	1.2894	1.3032	1.2894	1.2803	1.1104	1.086
4	1.2803	1.2536	1.3032	1.2536	1.262	1.1104	1.0498
5	1.2308	1.2178	1.267	1.2178	1.2254	1.0924	1.0136
6	1.1706	1.2178	1.2489	1.1641	1.2071	1.0924	1.0136
7	1.1222	1.182	1.2308	1.1283	1.2308	1.0924	.9774
8	1.0974	1.1462	1.1584	1.0745	1.1584	1.0387	1.0317
9	1.1222	1.1765	1.1641		1.1999	1.0608	1.0387
10	1.2489	1.2437	1.2894		1.2357	1.1403	1.1641
11	1.5927	1.3394	1.4864		1.3432		1.1765
12	1.6289	1.3394	1.0566	1.4842	1.4327	1.3213	1.267
13	1.647	1.4083	1.182	1.5565	1.4327	1.3394	1.3756
14	1.6651	1.4266	1.182	1.5927	1.4327	1.3575	1.3575
15	1.647	1.4083	1.1641	1.4842	1.4506	1.2489	1.3937
16	1.5927	1.3937	1.7193	1.5023	1.4327	1.2308	1.3575
17	1.5581	1.3032	1.6655	1.5546	1.5223	1.2127	
18	1.6297	1.3394	1.7551	1.5181	1.576	1.3937	1.4661
19	1.97	1.5384	1.97	1.829	1.7372	1.5927	1.7194
20	2.0058	1.5746	2.0774	1.9387	1.7909	1.6289	1.8099
21	1.8983	1.7375	1.8804	1.7741	1.6655	1.5912	1.5023
22	1.6476	1.6651		1.5927	1.3611	1.3213	1.3032
23	1.5581	1.6651	1.5402	1.5729	1.1999	1.182	1.1946
24	1.4632	1.4864	1.4864	1.3969	1.4449	1.1999	1.1584
Max	2.0058	1.7375	2.0774	1.9387	1.7909	1.6289	1.8099
Min	1.0974	1.1462	1.0566	1.0745	1.1584	1.0387	.9774
Avg	1.4905	1.3789	1.4328	1.4577	1.3887	1.2426	1.2463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 201 / 11 KV NAVRANG FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8983	1.9163	1.9033	1.8347	1.7661	1.5089	1.3375
2	1.8461	1.8823	1.8347	1.7147	1.7318	1.4918	1.3203
3	1.8099	1.8625	1.8004	1.6804	1.7147	1.4918	1.3375
4	1.8656	1.8099	1.7661	1.6632	1.7147	1.4918	1.3717
5	1.7375	1.7551	1.749	1.6461	1.6975	1.4746	1.3889
6	1.6118	1.5775	1.7147	1.6289	1.6975	1.4575	1.4232
7	1.4883	1.4883	1.5432	1.5261	1.5775	1.4232	1.3717
8	1.387	1.4022	1.4232	1.4746	1.4746	1.3717	1.3032
9	1.3375	1.3889	1.4148	1.3375	1.3969	1.3203	1.3203
10		1.4022	1.3937	1.3611	1.2178	1.2346	1.2174
11	1.2517	1.3032	1.3443				1.1488
12	1.3957		1.2003	1.1096	1.1047		1.1317
13	1.3546	1.7661	1.1999	1.1765	.985	1.0631	
14	1.3375	1.4403	1.2357	1.1946	1.0029	1.0566	1.0631
15	1.3565	1.4582	1.2209		1.0852	1.0402	1.0974
16	1.3735	1.4243		1.2039	1.1361	.985	
17	1.3565	1.3904		1.17	1.2209	1.0229	
18	1.3056	1.4074	1.2887	1.3056	1.3904	1.1317	1.2346
19	1.6617	1.5769	1.7126	1.5261	1.4582	1.3889	1.4548
20	1.8991	1.8482	1.8313	1.7974	1.6278	1.6118	1.7013
21	1.8991	2.0348	1.8821	1.8482	1.6787	1.6289	1.6289
22	2.0595	2.0919		1.9547	1.6804	1.7164	1.6289
23	2.0953	2.0919	1.8861	1.9204	1.5947	1.4403	1.5089
24		1.9879	1.989	1.869	1.9163	1.5432	1.3717
Max	2.0953	2.0919	1.989	1.9547	1.9163	1.7164	1.7013
Min	1.2517	1.3032	1.1999	1.1096	.985	.985	1.0631
Avg	1.6058	1.6655	1.5873	1.5429	1.4726	1.3589	1.3506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 202 / 11KV BANGAR NAGAR FEEDER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.8002	.7621	.743	.6478	.5144
2	.7621	.7621	.7811	.743	.724	.6097	.4954
3	.724	.7621	.7621	.724	.7049	.6097	.4954
4	.724	.6859	.743	.6668	.6668	.6097	.4954
5	.6859	.6859	.724	.6478	.6478	.5716	.4954
6	.6668	.6668	.7049	.6287	.6287	.5525	.5144
7	.6097	.6097	.6287	.6287	.5716	.0572	.5335
8	.5716	.6097	.6859	.5906	.6097	.5525	.5144
9	.6097	.567	.6413	.6154	.5853	.5487	.5487
10	.5906	.5487	.6161	.6219	.6219	.5487	.5729
11	.6287	.5487	.6722				.5544
12	.5906	.5853	.8596	.6335	.5853		.5611
13	.724	.5304	.7282	.6401	.567	.5975	
14	.6668	.5487	.7207	.6219	.6036	.5788	.5121
15	.6859	.5906	.7621		.6287	.5601	.6859
16	.6859	.724		.6859	.6478	.5853	.6097
17	.6668	.6668		.6859	.7049	.5729	
18	.7049	.6478	.724	.7049	.7049	.5853	.5906
19	.7811	.743	.8383	.7811	.724	.6584	.724
20	.8383	.8002	.8002	.8192	.7621	.7059	.724
21	.8383	.8192	.8192	.8192	.7049	.724	.6859
22	.8383	.8764		.8573	.7049	.6287	.6668
23	.8573	.8954	.8764	.8192	.724	.6097	.5906
24		.8192	.8573	.8002	.7621	.6668	.5525
Max	.8573	.8954	.8764	.8573	.7621	.724	.724
Min	.5716	.5304	.6161	.5906	.567	.0572	.4954
Avg	.7049	.6857	.7498	.7044	.6664	.5810	.5744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 206 / 11 kV VISAWA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	2.0452	1.9719	2.0814	2.0058	1.4842	1.3032
2	1.2309	1.9909	1.97	1.9879	1.9163	1.448	1.2536
3	1.2309	1.9909	1.9185	1.97	1.8804	1.448	1.2536
4	1.2309	1.8625	1.828	1.9004	1.828	1.4842	1.2536
5	1.7737	1.828	1.7918	1.8267	1.7918	1.5364	1.2536
6	1.6651	1.7194	1.7193	1.8099	1.7556	1.4815	1.3203
7	1.5364	1.5927	1.6289	1.576	1.5581	1.4815	1.3375
8	1.4299	1.5203	1.6289	1.4506	1.5023	1.3717	1.3375
9	1.3213	1.5402	1.576	1.4299	1.3523	1.3717	1.3203
10		1.4506	1.4327	1.4118	1.262	1.3032	1.3203
11	1.2894	1.3969	1.4327			1.1888	1.2346
12	1.267	1.3611	1.5402	1.1946	1.1096	1.086	1.2308
13	1.4148	1.379	1.3611	1.2437	1.1218	1.0608	1.1765
14	1.379	1.4685	1.4685	1.2803	1.1641	1.0608	1.1765
15	1.4842	1.6108	1.5203		1.1765	1.0608	1.1765
16	1.5565	1.5746		1.3032	1.1584	1.0608	1.1765
17	1.5384	1.5203		1.2489		1.0136	1.1765
18	1.3937	1.448	1.5203	1.4842	1.4299	1.2986	1.267
19	1.9909	1.7013	1.9366	1.6832	1.5565	1.4632	1.3375
20	1.9909	2.009	2.0814	1.9004	1.6832	1.6289	1.3889
21	2.0814	2.1357	2.009	1.9547	1.7375	1.6651	1.3717
22	2.1719	2.2744		2.0595	1.7372	1.6289	1.3032
23	2.268	2.3891	2.167	2.1132	1.6289	1.4815	1.3213
24	1.2656	2.1538	2.2262	2.1399	2.0119	1.6108	1.3032
Max	2.268	2.3891	2.2262	2.1399	2.0119	1.6651	1.3889
Min	1.2309	1.3611	1.3611	1.1946	1.1096	1.0136	1.1765
Avg	1.5549	1.7485	1.7490	1.6841	1.5622	1.3633	1.2748



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 207 / 11kV NETAJI NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6219	.6036	.5853	.6219	.4207	.439
2	.6036	.6219	.6036	.5853	.5853	.4207	.4207
3	.5853	.567	.5853	.5792	.5853	.4207	.4207
4	.5853	.567	.567	.5487	.567	.439	.4207
5	.5853	.5304	.5487	.5487	.5487	.439	.4207
6	.5487	.5121	.5304	.5249	.5304	.439	.4755
7	.5487	.5121	.4755	.4938	.4938	.4755	.5121
8	.4938	.5121	.4755	.4938	.4755	.5121	.4938
9	.4755	.4938	.6161	.4755	.5121	.5121	.4755
10	.4755	.4938	.5041	.4755	.4805	.4755	.4755
11	.439	.5121	.4854			.4755	.4755
12	.4755	.5487	.499	.4572	.4024	.439	.4572
13	.439	.4938	.5175	.439	.4207	.439	.4572
14	.4938	.4755	.4854	.4572	.4207	.439	.4572
15	.5121	.4938	.4938		.4207	.439	.439
16	.5121	.5121		.4572	.4024	.439	.439
17	.4938	.4755		.4207	.439	.439	.439
18	.4755	.4938	.5121	.439	.4755	.4572	.439
19	.5304	.5853	.6219	.567	.5121	.4938	.4755
20	.6219	.6401	.6219	.6219	.5853	.4938	.4755
21	.6219	.6401	.6036	.6401	.6036	.4938	.4938
22	.6219	.6584		.6584	.4938	.4755	.4938
23	.6584	.695	.6584	.6584	.4938	.4572	.4572
24	.6036	.6219	.6447	.591	.6089	.4207	.4572
Max	.6584	.695	.6584	.6584	.6219	.5121	.5121
Min	.439	.4755	.4755	.4207	.4024	.4207	.4207
Avg	.5418	.5533	.5549	.5326	.5078	.4565	.4588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 208 / 11 KV GOVT. MEDICAL  
HOSPITAL Feeder KV- 11 /  
OUTGOING

HV Group Express Feeder

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2195	.1991	.1991	.2172	.1991	.1791
2	.2195	.2195	.1991	.1991	.1991	.181	.1646
3	.2195	.2195	.1991	.1991	.1991	.181	.1629
4	.2172	.2195	.1991	.181	.1991	.1629	.1612
5	.2012	.2012	.181	.181	.1991	.1629	.1629
6	.2012	.2012	.181	.181	.181	.181	.181
7	.2012	.2012	.1991	.181	.1991	.1698	.1629
8	.2686	.2012	.2896	.2534	.2715	.2353	.2715
9	.2896	.2054	.2987	.2743	.2926	.2561	.2561
10		.2033	.2427	.2561	.3142	.2743	.3361
11	.2743	.1848	1.448				.3511
12	.2715	.1848	.3326	.3109	.3109	.2987	.3292
13	.2743	.2012	.2987	.2561	.3475	.2772	
14	.1991	.1848	.2801	.2378	.2402	.2561	.2772
15	.2218	.2033	.3511		.3326	.2378	.2561
16	.2218	.2218		.2402	.3326	.2561	
17	.2218	.2033		.2218	.2772	.2561	
18	.2218	.1848	.2587	.2218	.2587	.2378	.2353
19	.2218	.2218	.2772	.2587	.2402	.2195	.2561
20	.2402	.2402	.2402	.2218	.2402	.2402	.2534
21	.2587	.2587	.2587	.3142	.2402	.2218	.2353
22	.2561	.2172		.2353	.2172	.1991	.2172
23	.2172	.2012	.1991	.2353	.2149	.1991	.1991
24		.2195	.1991	.1991	.2172	.1991	.1991
Max	.2896	.2587	1.448	.3142	.3475	.2987	.3511
Min	.1991	.1848	.181	.181	.181	.1629	.1612
Avg	.2335	.2091	.3015	.2299	.2496	.2218	.2308

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304066 / 33 KV PIMPALGAO SUBSTION

Feeder No / Name : 401 / 33 KV SARA

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUL-17	09-JUL-17	10-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.3014	1.3014	1.2449	1.2449	1.1883	1.1317
2	1.3014	1.3014	1.2449	1.2449	1.3014	1.1317	1.1317
3	1.3014	1.3014	1.2449	1.1883	1.3014	1.1317	1.1317
4	1.3014	1.2449	1.2449	1.1883	1.3014	1.1317	1.1317
5	1.2449	1.2449	1.2449	1.1883	1.3014	1.1883	1.1317
6	1.2449	1.2449	1.3014	1.2449	1.358	1.2449	1.1883
7	1.2449	1.2449	1.3014	1.3014	1.2449	1.1883	1.1317
8	1.1883	1.3014	1.2449	1.2449	1.2449	1.1883	1.1883
9	1.2449	1.358	1.2449	1.1317	1.3014	1.2449	1.2449
10	1.2449	1.2449	1.1883	1.1317	1.1317	1.1317	1.1883
11	1.1883	1.2449	1.1883				1.0751
12	1.2449	1.2449	.9619	1.1883	1.1883	1.1317	1.1317
13	1.3014	1.3014	1.1317	1.2449	1.1883	1.1883	
14	1.2449	1.2449	1.2449	1.2449	1.1883	1.1317	1.1883
15	1.1883	1.2449	1.2449		1.1883	1.1883	1.0751
16	1.0185	1.1883		1.2449	1.1883	1.2449	1.1883
17	1.3014	1.2449		1.1317	1.2449	1.1883	
18	1.2449	1.1317	1.2449	1.1317	1.1883	1.1317	1.2449
19	1.2449	1.2449	1.2449	1.2449	1.1883	1.2449	1.1317
20	1.1883	1.1883	1.2449	1.1883	1.1317	1.3014	1.1883
21	1.2449	1.1883	1.1317	1.2449	1.1883	1.1883	1.2449
22	1.2449	1.3014		1.3014	1.1883	1.2449	1.3014
23	1.2449	1.2449	1.2449	1.3014	1.2449	1.2449	1.1317
24	1.2449	1.3014	1.2449	1.3014	1.2449	1.1883	1.1883
Max	1.3014	1.358	1.3014	1.3014	1.358	1.3014	1.3014
Min	1.0185	1.1317	.9619	1.1317	1.1317	1.1317	1.0751
Avg	1.2378	1.2543	1.2233	1.2217	1.2301	1.1908	1.1677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304084 / 33/11 kV GPDHANI S/S

Feeder No / Name : 203 / 11 kV FILTER PLANT FEEDER

LT WW Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.547	.3961	.4527
2			.547	.3772	.4527
3			.5093	.3772	.4527
4			.5093	.3584	.4527
5			.5093	.3584	.4527
6			.4715	.3395	.4527
7			.4715	.3395	.4527
8			.4715	.3584	.4527
9	.5847		.415	.3772	.4715
10			.5093	.3961	.4715
11	.5847		.547	.4338	.4715
12			.547	.4527	.4904
13			.547	.4527	.4904
14		.4338	.5281	.4527	.4904
15			.5281	.4904	.4904
16			.5093	.4904	.4904
17			.4904	.4527	.5281
18		.4338	.4904	.4527	.5281
19			.4904	.4527	.5281
20			.4715	.4527	.4904
21			.4715	.4527	.4904
22		.5847	.4527	.4527	.4904
23			.4527	.4527	.4527
24	.3772		.5658	.4338	.4527
Max	.5847	.5847	.5658	.4904	.5281
Min	.3772	.4338	.415	.3395	.4527
Avg	.5155	.4841	.5022	.4189	.4770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 08-JUL-17 and 14-JUL-17

AMARAVATI ZONE[061]

YAVATMAL CIRCLE[630]

YAVATMAL DIVSION[170]

YEOTMAL[318]

BU 1708

Substation No/ Name :- 304084 / 33/11 kV GPDHANI S/S

Feeder No / Name : 204 / 11 kV AKASHWANI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUL-17	11-JUL-17	12-JUL-17	13-JUL-17	14-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1584	1.1584	.7602
2			1.1584	1.1403	.7602
3			1.1403	1.086	.7602
4			1.1403	1.0317	.7602
5			1.086	.9593	.7602
6			.9774	.905	.8145
7			.905	.8869	.8145
8			.8507	.8688	.8145
9	.8865		.8326	.8326	.7964
10			.7421	.7602	.7964
11	.8145		.6697	.724	.724
12			.7059	.7059	.7602
13			.724	.7059	.7602
14		.6697	.7602	.724	.7602
15			.7964	.724	.7964
16			.8326	.7602	.7964
17			.8688	.7602	.7964
18		.7602	.905	.7602	.8326
19			.9955	.7602	.9412
20			1.086	.7602	1.086
21			1.1403	.7602	1.086
22		1.1765	1.1765	.7602	1.0136
23			1.1765	.7602	.9774
24	1.1584		1.1765	1.1765	.7602
Max	1.1584	1.1765	1.1765	1.1765	1.086
Min	.8145	.6697	.6697	.7059	.724
Avg	.9531	.8688	.9585	.8530	.8303