

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084016 / 33KV KOTHARI

Feeder No / Name : 201 / 11 KV KOTHARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1097 | .1109 | .1097 | .0905 |
| 2 | | .1109 | .1109 | .1097 | .0905 |
| 3 | | .1097 | .0924 | .0914 | .0914 |
| 4 | | .0914 | .0895 | .0914 | .1097 |
| 5 | | .1109 | .0895 | .0924 | .1097 |
| 6 | | .1307 | .1086 | .112 | .1294 |
| 7 | | .1294 | .1097 | .1307 | .1294 |
| 8 | | .1267 | .1267 | .128 | .1433 |
| 9 | | .1698 | .1629 | .1448 | .0914 |
| 10 | | .168 | .168 | .1463 | .1448 |
| 11 | | .1494 | .1307 | .1509 | .128 |
| 12 | | .132 | .1509 | .1509 | .128 |
| 13 | | .112 | .1417 | .132 | .132 |
| 14 | | .1109 | .128 | .1132 | .1478 |
| 15 | | .1132 | .112 | .132 | .1109 |
| 16 | | .0943 | .1307 | .1509 | .1448 |
| 17 | | .1294 | .1417 | .1214 | .1448 |
| 18 | | .2263 | .197 | .168 | .2378 |
| 19 | | .2263 | .2378 | .2263 | .2402 |
| 20 | | .2054 | .1886 | .1886 | .2054 |
| 21 | | .168 | .1494 | .1867 | .168 |
| 22 | | .132 | .112 | .1294 | .1307 |
| 23 | .1097 | .112 | .1097 | .1109 | .1109 |
| 24 | | .1097 | .1109 | .1097 | .0914 |
| Max | .1097 | .2263 | .2378 | .2263 | .2402 |
| Min | .1097 | .0914 | .0895 | .0914 | .0905 |
| Avg | .1097 | .1366 | .1338 | .1345 | .1355 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084016 / 33KV KOTHARI

Feeder No / Name : 205 / 11 KV KALAMANA

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 8 | .6144 | .5007 | .4729 | .5007 |
| 9 | .8069 | .7095 | .7628 | .7628 |
| 10 | .8619 | .7775 | .8619 | .7876 |
| 11 | .9031 | .8619 | .7922 | .8128 |
| 12 | .9602 | 1.0974 | .9633 | .9145 |
| 13 | 1.2136 | 1.0686 | .9907 | 1.0059 |
| 14 | 1.0364 | 1.1126 | 1.0059 | .9783 |
| 15 | .9934 | 1.0385 | .9907 | .884 |
| Max | 1.2136 | 1.1126 | 1.0059 | 1.0059 |
| Min | .6144 | .5007 | .4729 | .5007 |
| Avg | .9237 | .8958 | .8551 | .8308 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084016 / 33KV KOTHARI

Feeder No / Name : 207 / 11 KV GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1886 | .168 | .1509 |
| 2 | .1886 | .1698 | .168 | .1509 |
| 3 | .1886 | .168 | .1494 | .1698 |
| 4 | .1886 | .168 | .1509 | .1698 |
| 5 | .1886 | .1886 | .1698 | .2263 |
| 6 | .2829 | | .2263 | .2452 |
| 7 | .4715 | .2614 | .2452 | .2641 |
| 8 | .3018 | .2427 | .2641 | .2641 |
| 9 | .3584 | .2987 | .4066 | .3584 |
| 10 | .3174 | .2987 | .4481 | .3361 |
| 11 | .2801 | .2801 | .3395 | .2987 |
| 12 | .2614 | .2987 | .2263 | .2614 |
| 13 | .2241 | .2987 | .2829 | .2241 |
| 14 | .2054 | .2801 | .2829 | .2614 |
| 15 | .2054 | .2614 | .3018 | .2801 |
| 16 | .2241 | .2801 | .2427 | .3174 |
| 17 | .2801 | .3018 | .3395 | .3174 |
| 18 | .5415 | .381 | .4338 | .4668 |
| 19 | .5415 | .4572 | .4527 | .4854 |
| 20 | | .3961 | .4338 | .4481 |
| 21 | .3361 | .2987 | .3206 | .2801 |
| 22 | .2452 | .2054 | .2054 | .2241 |
| 23 | .2054 | .1867 | .1698 | .1698 |
| 24 | .2075 | .1886 | .168 | .1509 |
| Max | .5415 | .4572 | .4527 | .4854 |
| Min | .1886 | .168 | .1494 | .1509 |
| Avg | .2797 | .2652 | .2748 | .2717 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 201 / 11KV JUNONA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0328 | .0648 | .0655 | .0663 |
| 2 | .0497 | .081 | .0671 | .0492 |
| 3 | .0497 | .0819 | .0671 | .0492 |
| 4 | .0497 | .0819 | .0671 | .0492 |
| 5 | .0497 | .0819 | .0671 | .0492 |
| 6 | .0497 | .0819 | .0671 | .0492 |
| 7 | .0655 | .0819 | .0671 | .0492 |
| 8 | .0655 | .081 | .0655 | .0663 |
| 9 | .0819 | .081 | .0655 | .0819 |
| 10 | .0819 | .081 | .0655 | .0983 |
| 11 | .1134 | .0671 | .0655 | .0819 |
| 12 | .0972 | .0671 | .0655 | .0819 |
| 13 | .0486 | .0671 | .0655 | .0819 |
| 14 | .081 | .0671 | .0655 | .0819 |
| 15 | .1134 | .0838 | .0655 | .0819 |
| 16 | .0972 | .1006 | .0655 | .0655 |
| 17 | .1296 | .1341 | .0655 | .0819 |
| 18 | .1296 | .1147 | .0655 | .1311 |
| 19 | .1296 | .1147 | .0655 | .1311 |
| 20 | .1134 | .0819 | .0655 | .0983 |
| 21 | .1134 | .0819 | .0492 | .0983 |
| 22 | .0972 | .0819 | .0492 | .0983 |
| 23 | .081 | .0655 | .0486 | .0655 |
| 24 | .0655 | .081 | .0655 | .0486 |
| Max | .1296 | .1341 | .0671 | .1311 |
| Min | .0328 | .0648 | .0486 | .0486 |
| Avg | .0828 | .0836 | .0638 | .0765 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 202 / 11KV BAMANI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1311 | .1134 | .1147 | .1311 |
| 2 | .1311 | .1134 | .1174 | .1311 |
| 3 | .1311 | .1147 | .1174 | .1311 |
| 4 | .1311 | .1147 | .1174 | .1311 |
| 5 | .1311 | .0983 | .1341 | .1311 |
| 6 | .1311 | .1311 | .1353 | .1311 |
| 7 | .1638 | .1638 | .1341 | .1638 |
| 8 | .1638 | .1619 | .1638 | .2294 |
| 9 | .213 | .1943 | .1802 | .2294 |
| 10 | .213 | .2105 | .1966 | .1966 |
| 11 | .2267 | .218 | .1966 | .213 |
| 12 | .1943 | .218 | .1966 | .213 |
| 13 | .1943 | .218 | .1991 | .2294 |
| 14 | .1943 | .218 | .1802 | .1802 |
| 15 | .1943 | .218 | .213 | .1966 |
| 16 | .1943 | .2347 | .213 | .1802 |
| 17 | .1943 | .2347 | .2785 | .1966 |
| 18 | .2105 | .2294 | .2753 | .2458 |
| 19 | .2105 | .1802 | .213 | .2294 |
| 20 | .1943 | .1802 | .2105 | .1966 |
| 21 | .1781 | .1638 | .1619 | .1802 |
| 22 | .1457 | .1475 | .1638 | .1638 |
| 23 | .1296 | .1311 | .1311 | .1475 |
| 24 | .1475 | .1296 | .1147 | .1311 |
| Max | .2267 | .2347 | .2785 | .2458 |
| Min | .1296 | .0983 | .1147 | .1311 |
| Avg | .1729 | .1724 | .1733 | .1796 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 203 / 11 KV DAHELI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1147 | .1457 | | .1638 |
| 2 | .0655 | .1457 | .1341 | .1638 |
| 3 | .0663 | .1475 | .1341 | .1638 |
| 4 | .0655 | .1475 | .1341 | .1475 |
| 5 | .0655 | .1475 | .1341 | .1475 |
| 6 | .0819 | .1475 | .1341 | .1638 |
| 7 | .1311 | .1802 | .1341 | .1638 |
| 8 | .1802 | .1781 | .1802 | .213 |
| 9 | .2458 | .2591 | .2294 | .213 |
| 10 | .2785 | .2753 | .2622 | .2622 |
| 11 | .2591 | .285 | .2622 | .2785 |
| 12 | .2915 | .285 | .2458 | .2785 |
| 13 | .2915 | .285 | .3113 | .3113 |
| 14 | .3239 | .285 | .3113 | .2949 |
| 15 | .3077 | .285 | .2949 | .2294 |
| 16 | .3239 | .3521 | .2915 | .2785 |
| 17 | .2915 | .3521 | .2534 | .2949 |
| 18 | .2429 | .3441 | .2294 | .2458 |
| 19 | .2267 | .1802 | .213 | .213 |
| 20 | .1943 | .1802 | .213 | .1966 |
| 21 | .1781 | .1802 | .213 | .1802 |
| 22 | .1781 | .1802 | .2353 | .1638 |
| 23 | .1619 | .1311 | .1475 | .1638 |
| 24 | .1147 | .1457 | .1311 | .1475 |
| Max | .3239 | .3521 | .3113 | .3113 |
| Min | .0655 | .1311 | .1311 | .1475 |
| Avg | .1950 | .2185 | .2100 | .2116 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 204 / 11 KV Beghar feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0492 | .0648 | .0655 | .0655 |
| 2 | .0497 | .0648 | .0671 | .0655 |
| 3 | .0497 | .0655 | .0671 | .0655 |
| 4 | .0497 | .0655 | .0671 | |
| 5 | .0497 | | .0671 | .0655 |
| 6 | .0492 | .0655 | .0754 | .0655 |
| 7 | .0819 | .0655 | .0671 | .0655 |
| 8 | .0819 | .0972 | .0655 | .0819 |
| 9 | .0819 | .0972 | .0655 | .0819 |
| 10 | .0655 | .1134 | .0655 | .1311 |
| 11 | .0648 | .1174 | .1311 | .0492 |
| 12 | .0972 | .1006 | .1311 | .0492 |
| 13 | .0972 | .1132 | .0972 | .0655 |
| 14 | .0972 | .1132 | .0983 | .0663 |
| 15 | .1296 | .1341 | .0972 | .0829 |
| 16 | .0972 | .0838 | .0983 | .0819 |
| 17 | .1296 | .0838 | .0972 | .0819 |
| 18 | .1134 | .0819 | .0983 | .0995 |
| 19 | .0972 | .0983 | .0972 | .0819 |
| 20 | .081 | .0983 | .0972 | .0983 |
| 21 | .081 | .0819 | .081 | .0983 |
| 22 | .0972 | .0655 | .081 | .0819 |
| 23 | .0486 | .0655 | .0648 | .0819 |
| 24 | .0328 | .0486 | .0655 | .0648 |
| Max | .1296 | .1341 | .1311 | .1311 |
| Min | .0328 | .0486 | .0648 | .0492 |
| Avg | .0780 | .0863 | .0837 | .0770 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 205 / 11 KV F.D.C.M feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1475 | .1296 | .1475 | .1311 |
| 2 | .1475 | .1296 | .1509 | .1311 |
| 3 | .1475 | .1311 | .1341 | .1311 |
| 4 | .1475 | .1475 | .1341 | .1475 |
| 5 | .1638 | .1475 | .218 | .1638 |
| 6 | .213 | .1802 | .218 | .1802 |
| 7 | .2622 | .2294 | .218 | .2294 |
| 8 | .213 | .1943 | .2294 | .2622 |
| 9 | .2622 | .2591 | .2622 | .2622 |
| 10 | .2949 | .2591 | .2949 | .2458 |
| 11 | .2753 | .2683 | .2915 | .2622 |
| 12 | .2753 | .2515 | .2753 | .2622 |
| 13 | .2591 | .2515 | .1966 | .1966 |
| 14 | .2429 | .2515 | .1966 | .213 |
| 15 | .1943 | .2515 | .1802 | .2294 |
| 16 | .2267 | | .1802 | .2622 |
| 17 | .2591 | .2012 | .2785 | .213 |
| 18 | .2915 | .2622 | .2785 | .3441 |
| 19 | .2915 | .2622 | .2753 | .3277 |
| 20 | .2915 | .2622 | .2753 | .2785 |
| 21 | .2429 | .1966 | .213 | .2294 |
| 22 | .1943 | .1802 | .2105 | .1802 |
| 23 | .1619 | .1475 | .1457 | .1638 |
| 24 | .1475 | .1296 | .1475 | .1475 |
| Max | .2949 | .2683 | .2949 | .3441 |
| Min | .1475 | .1296 | .1341 | .1311 |
| Avg | .2230 | .2054 | .2147 | .2164 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 401 / 33 KV KOTHARI O/G

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4298 | .3801 | .3801 | .4298 |
| 2 | .3224 | .3801 | .3961 | .4344 |
| 3 | .3224 | .3801 | .3961 | .4344 |
| 4 | .3224 | .3801 | .3961 | .4344 |
| 5 | .3224 | .4344 | .4527 | .4344 |
| 6 | .4298 | .4344 | .4527 | .4344 |
| 7 | .4835 | .4344 | .4527 | .4344 |
| 8 | 1.2357 | 1.0317 | 1.086 | 1.4506 |
| 9 | 1.4506 | 1.3575 | 1.5203 | 1.4506 |
| 10 | 1.5581 | 1.4661 | 1.5746 | 1.2357 |
| 11 | 1.5203 | 1.5089 | 1.4815 | 1.2894 |
| 12 | 1.5746 | 1.7101 | 1.4661 | 1.4506 |
| 13 | 1.6832 | 1.9239 | 1.6289 | 1.5581 |
| 14 | 1.6289 | 1.8673 | 1.6289 | 1.6118 |
| 15 | .4344 | 1.8673 | .439 | 1.6118 |
| 16 | .3801 | .503 | .4344 | .4835 |
| 17 | .543 | .503 | .7602 | .5373 |
| 18 | .7602 | .6516 | .7682 | .8059 |
| 19 | .7059 | .6516 | .7133 | .8059 |
| 20 | .6516 | .6516 | .7133 | .6984 |
| 21 | .543 | .543 | .439 | .5373 |
| 22 | .4344 | .4344 | .439 | .4298 |
| 23 | .3801 | .4344 | .3292 | .3224 |
| 24 | .4298 | .3801 | .4344 | .3258 |
| Max | 1.6832 | 1.9239 | 1.6289 | 1.6118 |
| Min | .3224 | .3801 | .3292 | .3224 |
| Avg | .7728 | .8462 | .7826 | .8184 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 402 / 33KV RAJURA FEEDER.

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6863 | 2.2497 | 2.4434 | 2.3102 |
| 2 | 2.7401 | 2.3045 | 2.5463 | 2.3891 |
| 3 | 2.7401 | 2.2805 | 2.4897 | 2.3891 |
| 4 | 2.6863 | 2.1176 | 2.4897 | 2.2805 |
| 5 | 2.7401 | 2.3348 | 2.6595 | 2.4434 |
| 6 | 2.9012 | 2.552 | 2.6595 | 2.7692 |
| 7 | 3.2236 | 2.9321 | 3.1121 | 2.9321 |
| 8 | 3.3311 | 3.1824 | 3.095 | 3.3848 |
| 9 | 3.4922 | 3.3471 | 3.2036 | 3.3848 |
| 10 | 3.4922 | 3.2922 | 2.9864 | 3.4385 |
| 11 | 3.4019 | 3.3385 | | 3.3311 |
| 12 | 3.5117 | 3.3951 | 3.2922 | 3.2236 |
| 13 | 3.4568 | 3.5972 | 3.1493 | 3.2236 |
| 14 | 3.2922 | 3.0681 | 3.1493 | 3.1699 |
| 15 | 3.3471 | 3.1687 | 3.1824 | 3.3311 |
| 16 | 3.4019 | 3.678 | 3.1824 | 3.2773 |
| 17 | 3.4019 | 3.678 | 3.6763 | 3.3848 |
| 18 | 3.8958 | 3.7466 | 3.6763 | 3.8683 |
| 19 | 3.786 | 3.5294 | 3.4208 | 3.6534 |
| 20 | 3.5117 | 3.7466 | 3.4208 | 3.546 |
| 21 | 3.1276 | 3.2036 | 2.8235 | 2.955 |
| 22 | 2.6337 | 2.8235 | 2.8235 | 2.7938 |
| 23 | 2.3045 | 2.4977 | 2.4691 | 2.5789 |
| 24 | 2.7401 | 2.1399 | 2.2805 | 2.4691 |
| Max | 3.8958 | 3.7466 | 3.6763 | 3.8683 |
| Min | 2.3045 | 2.1176 | 2.2805 | 2.2805 |
| Avg | 3.1603 | 3.0085 | 2.9666 | 3.0220 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

BALLARSHA URBAN SDN[325] BU 2127

Substation No/ Name :- 084020 / 33/11 kv BAMANI

Feeder No / Name : 403 / 33 KV BAMANI I/C

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 3.4922 | 3.0727 | 3.1493 | 3.2922 |
| 2 | 3.4385 | 3.1824 | 3.3951 | 3.2036 |
| 3 | 3.4385 | 2.9321 | 3.3385 | 3.1493 |
| 4 | 3.4385 | 2.9321 | 3.3385 | 3.095 |
| 5 | 3.4922 | 3.1493 | 3.7346 | 3.3665 |
| 6 | 3.8146 | 3.4751 | 3.7346 | 3.8009 |
| 7 | 4.2444 | 4.0724 | 4.1872 | 4.0724 |
| 8 | 5.2652 | 4.9931 | 4.8325 | 5.7488 |
| 9 | 5.9099 | 5.6516 | 5.4841 | 5.7488 |
| 10 | 5.9099 | 5.7613 | 5.4841 | 5.6413 |
| 11 | 5.9808 | 5.998 | 5.8162 | 5.6413 |
| 12 | 5.9259 | 5.3818 | 5.8162 | 5.6413 |
| 13 | 6.1454 | 5.7842 | 5.7556 | 5.7488 |
| 14 | 5.9808 | 6.3375 | 5.7556 | 5.6413 |
| 15 | 4.7188 | 6.3375 | 4.5542 | 5.7488 |
| 16 | 4.7737 | 5.3755 | 4.5068 | 4.6742 |
| 17 | 4.9383 | 5.3755 | 5.4298 | 4.8354 |
| 18 | | 5.1583 | 5.4298 | 5.7488 |
| 19 | 5.5418 | 5.1583 | 5.0497 | 5.5338 |
| 20 | 5.048 | 5.1583 | 5.0497 | 5.104 |
| 21 | 4.4993 | 4.4525 | 3.9638 | 4.4593 |
| 22 | 3.786 | 3.8552 | 3.9638 | 3.7609 |
| 23 | 3.2922 | 3.3665 | 3.2579 | 3.4385 |
| 24 | 3.4922 | 3.0178 | 3.095 | 3.2579 |
| Max | 6.1454 | 6.3375 | 5.8162 | 5.7488 |
| Min | 3.2922 | 2.9321 | 3.095 | 3.095 |
| Avg | 4.6334 | 4.5825 | 4.5051 | 4.5980 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 201 / 11 KV KODSHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6554 | .5573 | .6316 | .4999 |
| 2 | | .6472 | .5573 | .6316 | .4999 |
| 3 | | .6472 | .5573 | .6316 | .4999 |
| 4 | | .6371 | .543 | .6613 | .4999 |
| 5 | | .6472 | .5573 | .6478 | .4999 |
| 6 | | .6539 | .5716 | .6718 | .4999 |
| 7 | | .6859 | .5858 | .5668 | .5155 |
| 8 | | .695 | .6287 | .602 | .6093 |
| 9 | | .8488 | .7562 | .6226 | .6661 |
| 10 | | .8333 | .7562 | .724 | .6805 |
| 11 | | | .7407 | .7145 | .6773 |
| 12 | 2.6673 | 1.7528 | 2.4006 | 1.0479 | 1.9433 |
| 13 | | | .8179 | .7859 | .7716 |
| 14 | | | .9326 | .743 | .7977 |
| 15 | | .8642 | .8488 | .7145 | .8128 |
| 16 | | .8398 | .8796 | .6859 | .7754 |
| 17 | | .8288 | .7876 | .7002 | .719 |
| 18 | | .7145 | .6539 | .6716 | .6767 |
| 19 | | .7287 | .7042 | .7002 | .6908 |
| 20 | | .6859 | .6687 | .6573 | .6485 |
| 21 | | .6144 | .639 | .5144 | .6062 |
| 22 | | .5716 | .6241 | .4715 | .5639 |
| 23 | 2.2862 | .5716 | .6093 | .4999 | .5357 |
| 24 | 2.2862 | 1.7147 | 2.2862 | 1.1431 | 1.9052 |
| Max | 2.6673 | 1.7528 | 2.4006 | 1.1431 | 1.9433 |
| Min | 2.2862 | .5716 | .543 | .4715 | .4999 |
| Avg | 2.4132 | .8018 | .8193 | .6850 | .7331 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 202 / 11 KV KORAPANA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5895 | .5258 | .5087 | .4908 |
| 2 | .583 | .5959 | .4801 | .5258 |
| 3 | .6173 | .5959 | .4908 | .3856 |
| 4 | .6173 | .631 | .4908 | .3856 |
| 5 | .5533 | .5959 | .5258 | .4207 |
| 6 | .503 | .6661 | .5959 | .7888 |
| 7 | .5868 | .7712 | .7011 | .7888 |
| 8 | .5935 | .7362 | .7712 | .7712 |
| 9 | .6173 | .7407 | .8954 | .8322 |
| 10 | .6443 | .7461 | .7522 | .8573 |
| 11 | .5765 | .5426 | .3772 | .7122 |
| 12 | .5765 | .5765 | .4458 | .7122 |
| 13 | .4748 | .5765 | .6104 | .6299 |
| 14 | .4748 | .6443 | .5801 | .6706 |
| 15 | .4748 | .6104 | .6104 | .6539 |
| 16 | .4801 | | .6104 | .6104 |
| 17 | .5258 | .6805 | .6661 | .4999 |
| 18 | .631 | .788 | .8413 | .6874 |
| 19 | .7712 | .7602 | .8063 | .6874 |
| 20 | .6661 | .6697 | .7011 | .5937 |
| 21 | .631 | .6154 | .631 | .5624 |
| 22 | .5959 | .6154 | .5959 | .5312 |
| 23 | .5609 | .5426 | .5316 | .4999 |
| 24 | .583 | .5959 | .5258 | .5609 |
| Max | .7712 | .788 | .8954 | .8573 |
| Min | .4748 | .5258 | .3772 | .3856 |
| Avg | .5803 | .6445 | .6144 | .6191 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 203 / 11 KV KUSAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2229 | .2353 | .124 | .1578 |
| 2 | .2254 | .2353 | .124 | .1578 |
| 3 | .2254 | .2353 | .1417 | .1402 |
| 4 | .2254 | .2353 | .1949 | .1753 |
| 5 | .2279 | .2172 | .2126 | .2103 |
| 6 | .1928 | .181 | .2303 | .2279 |
| 7 | .208 | .1991 | .1772 | .2279 |
| 8 | .2374 | .2172 | .1753 | .2103 |
| 9 | .2374 | .2543 | .2303 | .1865 |
| 10 | .2543 | .2374 | .2103 | .1696 |
| 11 | .2035 | .2035 | .1696 | .1844 |
| 12 | .2035 | .1696 | .1802 | .1802 |
| 13 | .2204 | .2035 | | .1781 |
| 14 | .2204 | .1865 | | .2321 |
| 15 | .2035 | .1865 | .5967 | .213 |
| 16 | .218 | .1696 | .2347 | .2652 |
| 17 | .2353 | .1578 | .2534 | .1829 |
| 18 | .2715 | .2103 | .3077 | .2439 |
| 19 | .2896 | .2658 | .2896 | .1829 |
| 20 | .2896 | .2507 | .2896 | .2439 |
| 21 | .2715 | .2303 | .2534 | .2134 |
| 22 | .2353 | .1433 | .181 | .1981 |
| 23 | .2534 | .1357 | .5087 | .1829 |
| 24 | .2401 | .2353 | .1402 | .1578 |
| Max | .2896 | .2658 | .5967 | .2652 |
| Min | .1928 | .1357 | .124 | .1402 |
| Avg | .2339 | .2082 | .2375 | .1968 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 204 / 11 kv wansadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1462 | 1.134 | .9816 | 1.0867 |
| 2 | 1.1222 | 1.0974 | .9816 | 1.0517 |
| 3 | 1.0136 | 1.0974 | .9816 | 1.0517 |
| 4 | .9774 | 1.0974 | .9465 | 1.0517 |
| 5 | 1.0242 | 1.0974 | .8764 | 1.0166 |
| 6 | .8871 | 1.0974 | .8413 | 1.0867 |
| 7 | 1.1946 | 1.0974 | 1.1568 | 1.0867 |
| 8 | 1.1584 | .7461 | 1.2269 | 1.1919 |
| 9 | .9496 | .9835 | .7602 | .8063 |
| 10 | .9156 | 1.0513 | .6878 | 1.0867 |
| 11 | .8478 | .9496 | .663 | 1.0166 |
| 12 | .8139 | 1.0174 | .9614 | .823 |
| 13 | .8478 | .9835 | 1.0517 | .6325 |
| 14 | .8478 | 1.0174 | 1.0174 | 1.1568 |
| 15 | .7291 | 1.3565 | .7628 | 1.0288 |
| 16 | .8413 | 1.2305 | .6371 | 1.0631 |
| 17 | .8413 | 1.2757 | .6584 | 1.0056 |
| 18 | 1.1706 | 1.267 | .6516 | .9362 |
| 19 | 1.0974 | 1.2936 | .6584 | 1.0402 |
| 20 | 1.0608 | 1.1827 | .5853 | 1.2136 |
| 21 | .9511 | .924 | 1.2437 | 1.1919 |
| 22 | .9145 | 1.1088 | 1.1706 | 1.0517 |
| 23 | 1.0974 | .9816 | 1.0631 | .8764 |
| 24 | 1.086 | 1.2071 | .9816 | 1.0631 |
| Max | 1.1946 | 1.3565 | 1.2437 | 1.2136 |
| Min | .7291 | .7461 | .5853 | .6325 |
| Avg | .9807 | 1.0956 | .8978 | 1.0257 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 205 / 11KV TULSHI FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3561 | .3077 | .298 | .2374 |
| 2 | .3521 | .3077 | .3012 | .2374 |
| 3 | .3521 | .3077 | .2947 | .2204 |
| 4 | .3391 | .3239 | .3012 | .2204 |
| 5 | .3353 | .3239 | .298 | .2374 |
| 6 | .3521 | .3239 | .3086 | .2377 |
| 7 | .3688 | .3239 | .2883 | .2543 |
| 8 | .4359 | .4372 | .373 | .3052 |
| 9 | .4748 | .8139 | .4527 | .4024 |
| 10 | .4917 | .7461 | .4694 | .4191 |
| 11 | .5087 | .5426 | .4191 | .4359 |
| 12 | .5256 | .5596 | .4527 | .4527 |
| 13 | .5087 | .5895 | .4527 | .503 |
| 14 | .5426 | .5596 | .5365 | .5197 |
| 15 | .5426 | .5935 | .5197 | .57 |
| 16 | .4755 | .5765 | .503 | .503 |
| 17 | .502 | .5197 | .4372 | .4725 |
| 18 | .4858 | .4862 | .4534 | .442 |
| 19 | .4858 | .4862 | .421 | .4115 |
| 20 | .4372 | .4527 | .3725 | .381 |
| 21 | .3725 | .3688 | .2753 | .3048 |
| 22 | .3401 | .3185 | .2429 | .2896 |
| 23 | .3563 | .2915 | .2374 | .2591 |
| 24 | .3561 | .3077 | .2905 | .2374 |
| Max | .5426 | .8139 | .5365 | .57 |
| Min | .3353 | .2915 | .2374 | .2204 |
| Avg | .4291 | .4529 | .3750 | .3564 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084006 / 33 KV KORAPANA

Feeder No / Name : 401 / 33 kv pardi

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7459 | 1.0311 | 1.0682 | 1.0682 |
| 2 | .7545 | 1.0311 | 1.0174 | 1.0682 |
| 3 | .7459 | 1.0311 | 1.0174 | 1.0682 |
| 4 | .7459 | 1.0311 | 1.0174 | 1.0682 |
| 5 | .7545 | 1.0311 | 1.0174 | 1.1191 |
| 6 | .7865 | 1.0311 | 1.0682 | 1.1191 |
| 7 | .8951 | 1.1248 | 1.17 | 1.17 |
| 8 | 1.1437 | 1.1248 | 1.17 | 1.2717 |
| 9 | 1.17 | 1.4243 | 1.3123 | 1.406 |
| 10 | 1.0174 | 1.4752 | 1.4529 | 1.406 |
| 11 | 1.4752 | 1.5769 | 1.406 | 1.442 |
| 12 | 1.6278 | 1.3735 | 1.5935 | 1.4998 |
| 13 | 1.6278 | 1.17 | 1.781 | 1.6404 |
| 14 | 1.8821 | 1.5769 | 1.8027 | 1.4918 |
| 15 | 1.933 | 1.2209 | 1.7341 | 1.7695 |
| 16 | 1.6872 | 1.6787 | 1.6872 | 1.6404 |
| 17 | 1.5935 | 1.5655 | 1.5466 | 1.4815 |
| 18 | 1.406 | 1.3757 | 1.4529 | 1.2963 |
| 19 | 1.3592 | 1.3123 | 1.3592 | 1.2963 |
| 20 | 1.2654 | 1.2809 | 1.3123 | 1.2037 |
| 21 | 1.2186 | 1.1385 | 1.1717 | 1.1111 |
| 22 | 1.078 | 1.0437 | 1.078 | 1.0648 |
| 23 | 1.078 | 1.0517 | 1.1191 | 1.0185 |
| 24 | .9945 | 1.0311 | 1.0174 | 1.0682 |
| Max | 1.933 | 1.6787 | 1.8027 | 1.7695 |
| Min | .7459 | 1.0311 | 1.0174 | 1.0185 |
| Avg | 1.2077 | 1.2388 | 1.3072 | 1.2829 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084026 / 33 KV PARDI

Feeder No / Name : 201 / 11 KV PARDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0509 | .0709 | .0503 | .0503 |
| 2 | | .0503 | .0532 | .0503 | .0509 |
| 3 | | .0503 | .0526 | .0503 | .0509 |
| 4 | | .0503 | .0532 | .0509 | .0503 |
| 5 | | .0497 | .0526 | .0509 | .0503 |
| 6 | | .0503 | .0526 | .0509 | .0514 |
| 7 | | .0503 | .0532 | .0514 | .0503 |
| 8 | .0709 | .0648 | .0526 | .0514 | .048 |
| 9 | | .096 | .0709 | .0463 | .0914 |
| 10 | | .0914 | .0895 | .0617 | .0753 |
| 11 | | .1063 | .0892 | .0625 | .061 |
| 12 | | .124 | .1014 | .08 | .0724 |
| 13 | | .124 | .1014 | .0937 | .0714 |
| 14 | | .124 | .1158 | .108 | .0572 |
| 15 | | .1433 | .1158 | .0781 | .0579 |
| 16 | | .1417 | .1204 | .0633 | .0406 |
| 17 | | .124 | .1107 | .0625 | .029 |
| 18 | | .1063 | .081 | .096 | .0671 |
| 19 | | .0886 | .0819 | .096 | .0732 |
| 20 | | .0857 | .0655 | .0972 | .0554 |
| 21 | | .0693 | .0663 | .08 | .0549 |
| 22 | | .0701 | .0663 | .0648 | .0354 |
| 23 | | .0709 | .0497 | .0497 | .0526 |
| 24 | | .0503 | .0732 | .0497 | .0492 |
| Max | .0709 | .1433 | .1204 | .108 | .0914 |
| Min | .0709 | .0497 | .0497 | .0463 | .029 |
| Avg | .0709 | .0847 | .0767 | .0665 | .0561 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084026 / 33 KV PARDI

Feeder No / Name : 203 / 11 KV PARSODA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4321 | .591 | .4115 | .3841 |
| 2 | | .4428 | .5731 | .4115 | .3437 |
| 3 | | .4161 | .5609 | .3864 | .3605 |
| 4 | | .4111 | .567 | .3864 | .3201 |
| 5 | | .4481 | .567 | .4161 | .3479 |
| 6 | | .4428 | .5847 | .4214 | .3437 |
| 7 | | .3125 | .6135 | .4515 | .3704 |
| 8 | .5847 | .4687 | .6379 | .4904 | .4999 |
| 9 | | .6483 | .7164 | .5647 | .6009 |
| 10 | | .3763 | .7087 | .6539 | .6325 |
| 11 | | .5731 | .679 | .7499 | .6622 |
| 12 | | .7973 | .7407 | .7716 | .6859 |
| 13 | | .8505 | .7716 | .8436 | .7621 |
| 14 | | .9214 | .7926 | .8173 | .8179 |
| 15 | | .8954 | .823 | .8383 | .8179 |
| 16 | | .8859 | .8097 | .8025 | .8025 |
| 17 | | .8328 | .7186 | .7811 | .7468 |
| 18 | | .7796 | .6249 | .6874 | .6321 |
| 19 | | .7362 | .5792 | .6249 | .6401 |
| 20 | | .6783 | .5182 | .5851 | .6952 |
| 21 | | .6516 | .4755 | .5335 | .4988 |
| 22 | | .631 | .4843 | .4515 | .4633 |
| 23 | | .6024 | .4374 | .3668 | .4512 |
| 24 | | .4687 | .5973 | .427 | .3906 |
| Max | .5847 | .9214 | .823 | .8436 | .8179 |
| Min | .5847 | .3125 | .4374 | .3668 | .3201 |
| Avg | .5847 | .6126 | .6322 | .5781 | .5529 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084026 / 33 KV PARDI

Feeder No / Name : 204 / 11KV Rupapeth feeder-I
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3437 | .4607 | .4374 | .4111 |
| 2 | | .3201 | .4656 | .4062 | .3841 |
| 3 | | .2949 | .443 | .4062 | .3841 |
| 4 | | .3201 | .4477 | .4111 | .3593 |
| 5 | .4784 | .3239 | .4784 | .4161 | .3593 |
| 6 | .5194 | .3932 | .5138 | .4481 | .3906 |
| 7 | .5731 | .4218 | .5316 | .4961 | .4531 |
| 8 | .6024 | .5441 | .5138 | .5121 | .5155 |
| 9 | | .583 | .6379 | .5441 | .6405 |
| 10 | | .4218 | .6447 | .5761 | .6249 |
| 11 | | .5194 | .5601 | .5937 | .5468 |
| 12 | | .691 | .0648 | .6173 | .6093 |
| 13 | | .7343 | .4801 | .6944 | .6636 |
| 14 | | .7619 | .6081 | .7099 | .6718 |
| 15 | | .7796 | .7274 | .6718 | .6562 |
| 16 | | .815 | .6562 | .6718 | .6562 |
| 17 | | .7087 | .6249 | .6718 | .578 |
| 18 | | .6379 | .5921 | .5155 | .4999 |
| 19 | | .6268 | .5468 | .5218 | .4938 |
| 20 | | .5721 | .5155 | .5121 | .4687 |
| 21 | | .5316 | .4902 | .4687 | .4321 |
| 22 | | .5014 | .4801 | .4481 | .4218 |
| 23 | | .4755 | .4641 | .4372 | .4062 |
| 24 | | .3353 | .4062 | .4481 | .4218 |
| Max | .6024 | .815 | .7274 | .7099 | .6718 |
| Min | .4784 | .2949 | .0648 | .4062 | .3593 |
| Avg | .5433 | .5274 | .5147 | .5265 | .5020 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 201 / 11 kv GADCHANDUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6783 | .7522 | .6173 | .6173 |
| 2 | .6952 | .7522 | .6173 | .631 |
| 3 | .6706 | .7522 | .6173 | .631 |
| 4 | .6706 | .7522 | .6173 | .7011 |
| 5 | .7545 | .7522 | .7888 | .8063 |
| 6 | .8402 | .8417 | .8573 | .8764 |
| 7 | .9189 | .985 | .9259 | .9431 |
| 8 | .9602 | .9745 | .9602 | .9431 |
| 9 | 1.0454 | .9562 | 1.0197 | .9976 |
| 10 | .9991 | .9588 | 1.0387 | .9593 |
| 11 | | .9506 | .9691 | .9703 |
| 12 | .9114 | .9045 | .9085 | .9105 |
| 13 | .9816 | .8861 | .7975 | .8688 |
| 14 | .9114 | .8104 | .787 | .8467 |
| 15 | .8063 | .8276 | .7482 | .7845 |
| 16 | .8238 | .7733 | .8194 | .7673 |
| 17 | .8589 | .8745 | 1.1145 | .9568 |
| 18 | 1.2445 | 1.2003 | 1.2517 | 1.258 |
| 19 | 1.258 | 1.1831 | 1.2003 | 1.2048 |
| 20 | 1.134 | 1.1317 | 1.0974 | 1.1163 |
| 21 | .9922 | .9945 | .9774 | .9745 |
| 22 | .788 | .7716 | .703 | .7701 |
| 23 | .7522 | .6687 | .6344 | .7522 |
| 24 | .7042 | .7522 | .6173 | .6173 |
| Max | 1.258 | 1.2003 | 1.2517 | 1.258 |
| Min | .6706 | .6687 | .6173 | .6173 |
| Avg | .8869 | .8836 | .8619 | .8710 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 202 / 11 kv Asan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .539 | .6173 | .7202 | .5144 |
| 2 | .539 | .6173 | .7202 | .5258 |
| 3 | .539 | .6173 | .6859 | .5373 |
| 4 | .539 | .6173 | .6859 | .5731 |
| 5 | .4793 | .6173 | .6859 | .6089 |
| 6 | .4024 | .6344 | .6859 | .6447 |
| 7 | .4595 | .6687 | .703 | .631 |
| 8 | .612 | .78 | .7888 | .7545 |
| 9 | .8383 | .7539 | .7819 | .7816 |
| 10 | .8718 | .7307 | .744 | .7765 |
| 11 | .7956 | .7161 | .7278 | .7258 |
| 12 | .9116 | .6983 | .7786 | .7974 |
| 13 | .9448 | .8475 | .7971 | .8232 |
| 14 | .9945 | .8562 | .8047 | .8321 |
| 15 | 1.0111 | .8069 | .7912 | .8002 |
| 16 | .7956 | .7927 | .8183 | .7381 |
| 17 | .8453 | .8916 | .8916 | .8383 |
| 18 | .6539 | .8059 | .8402 | .7712 |
| 19 | .7042 | .823 | .7888 | .788 |
| 20 | .6952 | .7888 | .7716 | .763 |
| 21 | .6859 | .7888 | .7202 | .7202 |
| 22 | .6344 | .7202 | .6516 | .703 |
| 23 | .6173 | .7202 | .5487 | .6859 |
| 24 | .5468 | .6173 | .7202 | .5316 |
| Max | 1.0111 | .8916 | .8916 | .8383 |
| Min | .4024 | .6173 | .5487 | .5144 |
| Avg | .6940 | .7303 | .7438 | .7027 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 203 / 11 KV THUTRA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7343 | .9335 | .7545 | .8063 |
| 2 | .6097 | .9335 | .7545 | .8063 |
| 3 | .7186 | .9335 | .7545 | .8063 |
| 4 | .6944 | .9335 | .7716 | .7362 |
| 5 | .6554 | .9335 | .823 | .7362 |
| 6 | .6171 | .9335 | .8916 | .7362 |
| 7 | .6859 | .9335 | .9602 | .7186 |
| 8 | .9646 | 1.2197 | 1.0288 | 1.004 |
| 9 | 1.3032 | 1.0934 | 1.0837 | 1.0413 |
| 10 | .9955 | 1.1216 | 1.1256 | 1.0601 |
| 11 | .964 | 1.0241 | 1.1525 | .8282 |
| 12 | .2896 | .9842 | 1.1077 | .877 |
| 13 | .181 | .8551 | .9993 | 1.0544 |
| 14 | .9774 | .9674 | .905 | .9866 |
| 15 | 1.3937 | 1.008 | .96 | 1.0108 |
| 16 | 1.2851 | 1.0572 | .958 | .9913 |
| 17 | 1.086 | 1.0692 | 1.1145 | 1.1041 |
| 18 | 1.3169 | 1.1043 | 1.1488 | |
| 19 | 1.2803 | 1.1744 | 1.0517 | 1.1157 |
| 20 | 1.262 | 1.0867 | 1.1218 | 1.2012 |
| 21 | 1.1088 | .9991 | .8764 | 1.0534 |
| 22 | .9795 | .8812 | .8063 | .9425 |
| 23 | .9709 | .8238 | .6859 | .9335 |
| 24 | .6249 | .9335 | .7888 | .8059 |
| Max | 1.3937 | 1.2197 | 1.1525 | 1.2012 |
| Min | .181 | .8238 | .6859 | .7186 |
| Avg | .9041 | .9974 | .9427 | .9285 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 204 / 11 kv PIMPALGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1469 | 1.5912 | 1.6827 | 1.6476 |
| 2 | 1.1469 | 1.5912 | 1.6827 | 1.6476 |
| 3 | 1.1768 | 1.5912 | 1.6827 | 1.6476 |
| 4 | 1.1469 | 1.5912 | 1.7177 | 1.6827 |
| 5 | 1.1768 | 1.6244 | 1.7528 | 1.7177 |
| 6 | 1.2071 | 1.6575 | 1.7878 | 1.7177 |
| 7 | 1.3112 | 1.7368 | 1.8229 | 1.8229 |
| 8 | 1.4325 | 1.9662 | 1.8229 | 1.5039 |
| 9 | 1.3435 | 1.8147 | 1.7642 | 1.7412 |
| 10 | 1.8023 | 1.7836 | 1.7502 | 1.7131 |
| 11 | 1.6385 | 1.6461 | 1.6432 | 1.5201 |
| 12 | 1.8138 | 1.6164 | | 1.5781 |
| 13 | 1.9433 | 1.6827 | | |
| 14 | 1.9433 | | 1.5663 | 1.2572 |
| 15 | 1.9757 | 1.8194 | 1.894 | |
| 16 | 1.9662 | 1.8333 | 1.5746 | |
| 17 | .7865 | 2.1033 | 1.9631 | 1.6194 |
| 18 | 1.8679 | 1.9631 | 1.9631 | 1.4899 |
| 19 | 1.8679 | 1.9631 | 2.0576 | 1.5074 |
| 20 | 1.8233 | 1.9631 | 1.9631 | 1.4746 |
| 21 | 1.757 | 1.8229 | 1.8229 | 1.3435 |
| 22 | 1.6575 | 1.8229 | 1.7177 | 1.3108 |
| 23 | 1.6244 | 1.7177 | 1.6827 | 1.3108 |
| 24 | 1.1469 | 1.5912 | 1.7177 | 1.6827 |
| Max | 1.9757 | 2.1033 | 2.0576 | 1.8229 |
| Min | .7865 | 1.5912 | 1.5663 | 1.2572 |
| Avg | 1.5293 | 1.7606 | 1.7742 | 1.5684 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 205 / 11 KV L&T Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2656 | .3045 | .3086 | .3429 |
| 2 | .2656 | .3045 | .3086 | .3086 |
| 3 | .2846 | .3045 | .3086 | .3086 |
| 4 | .2656 | .3045 | .3086 | .3086 |
| 5 | .2469 | .3045 | .3086 | .309 |
| 6 | .2286 | .3403 | .3429 | .3086 |
| 7 | .3125 | .3403 | .3601 | .2915 |
| 8 | .4111 | | .4115 | .3258 |
| 9 | .5258 | .4572 | .4864 | .4887 |
| 10 | .4733 | .4881 | .4149 | .5357 |
| 11 | .0686 | .3062 | | .4502 |
| 12 | .4801 | .3949 | | .4767 |
| 13 | .4801 | .5139 | | .4316 |
| 14 | .5144 | .4819 | | .468 |
| 15 | .4973 | .492 | | .4647 |
| 16 | .4801 | .4744 | | .439 |
| 17 | .4973 | .5144 | | .4207 |
| 18 | .5258 | .463 | .4973 | .4607 |
| 19 | .5434 | .463 | .4801 | .4961 |
| 20 | .4961 | .463 | .463 | .4607 |
| 21 | .4607 | .4287 | .4115 | .4252 |
| 22 | | .3429 | .3772 | .3761 |
| 23 | .3224 | .3258 | .3601 | .3582 |
| 24 | .2656 | .3045 | .3086 | .3601 |
| Max | .5434 | .5144 | .4973 | .5357 |
| Min | .0686 | .3045 | .3086 | .2915 |
| Avg | .3875 | .3964 | .3798 | .4007 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 084044 / 33 KV GADCHANDUR

Feeder No / Name : 206 / 11 kv NANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0082 | 1.0631 | .9431 | 1.0166 |
| 2 | .8855 | 1.0631 | .9431 | 1.0166 |
| 3 | | 1.0974 | .9602 | 1.0166 |
| 4 | .2772 | 1.0974 | .9602 | 1.0517 |
| 5 | | 1.0974 | .9945 | 1.1218 |
| 6 | | 1.0974 | 1.0288 | 1.1218 |
| 7 | | 1.2003 | 1.1317 | 1.1744 |
| 8 | | 1.2378 | 1.1831 | .8063 |
| 9 | | 1.355 | 1.1584 | 1.3459 |
| 10 | | 1.3171 | 1.1927 | 1.3378 |
| 11 | .7042 | 1.2803 | 1.1859 | 1.2485 |
| 12 | 1.4586 | 1.2163 | | 1.3026 |
| 13 | 1.5927 | 1.326 | 1.3496 | 1.3599 |
| 14 | 1.576 | 1.3237 | 1.358 | 1.2696 |
| 15 | 1.576 | 1.3495 | 1.3349 | 1.2729 |
| 16 | 1.5424 | 1.3209 | 1.2813 | 1.301 |
| 17 | 1.5424 | 1.5424 | 1.4723 | 1.3245 |
| 18 | 1.576 | 1.4022 | 1.4373 | 1.3916 |
| 19 | 1.5261 | | 1.4403 | 1.3904 |
| 20 | 1.4575 | 1.3321 | 1.3496 | 1.2717 |
| 21 | 1.3032 | 1.2269 | 1.2094 | 1.17 |
| 22 | 1.1145 | 1.0341 | 1.0341 | 1.0631 |
| 23 | 1.0974 | .9774 | 1.0341 | 1.0288 |
| 24 | .9023 | | .964 | 1.0166 |
| Max | 1.5927 | 1.5424 | 1.4723 | 1.3916 |
| Min | .2772 | .9774 | .9431 | .8063 |
| Avg | 1.2435 | 1.2254 | 1.1716 | 1.1842 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 088012 / 220 KV GADCHANDUR

Feeder No / Name : 401 / 33 KV MANIKGARDH

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | .8002 | 2.0005 | 1.9433 | 2.1148 | 1.5432 |
| 24 | .5716 | 1.7147 | 1.7147 | 1.7147 | 1.4289 |
| Max | .8002 | 2.0005 | 1.9433 | 2.1148 | 1.5432 |
| Min | .5716 | 1.7147 | 1.7147 | 1.7147 | 1.4289 |
| Avg | .6859 | 1.8576 | 1.829 | 1.9148 | 1.4861 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 088012 / 220 KV GADCHANDUR

Feeder No / Name : 402 / 33 KV RAJURA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | 6.4586 | 6.4586 | 6.1728 | 5.5441 | 6.23 |
| 24 | 6.5729 | 5.7156 | 5.4298 | 5.2012 | 6.2872 |
| Max | 6.5729 | 6.4586 | 6.1728 | 5.5441 | 6.2872 |
| Min | 6.4586 | 5.7156 | 5.4298 | 5.2012 | 6.23 |
| Avg | 6.5158 | 6.0871 | 5.8013 | 5.3727 | 6.2586 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 088012 / 220 KV GADCHANDUR

Feeder No / Name : 403 / 33 KV KORAPANA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | | 4.2867 | 4.9154 | 5.6013 | 5.2584 |
| 23 | 5.0869 | | | | |
| 24 | 4.5725 | 4.0009 | 4.5725 | 5.4298 | 5.0297 |
| Max | 5.0869 | 4.2867 | 4.9154 | 5.6013 | 5.2584 |
| Min | 4.5725 | 4.0009 | 4.5725 | 5.4298 | 5.0297 |
| Avg | 4.8297 | 4.1438 | 4.7440 | 5.5156 | 5.1441 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 088012 / 220 KV GADCHANDUR

Feeder No / Name : 501 / 66 KV EXPRESS FEEDER

SHEDDABLE RURAL

MANICGARH Feeder KV- 66 /
OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | .1143 | .1143 | .1143 | .1143 | .1143 |
| 23 | | | | .1143 | |
| 24 | .1143 | .1143 | .1143 | .1143 | .1143 |
| Max | .1143 | .1143 | .1143 | .1143 | .1143 |
| Min | .1143 | .1143 | .1143 | .1143 | .1143 |
| Avg | .1143 | .1143 | .1143 | .1143 | .1143 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GADCHANDUR S/DN.[330] BU 4330

Substation No/ Name :- 088012 / 220 KV GADCHANDUR

Feeder No / Name : 801 / 220 KV Ultratech Express NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 12 | 16.3847 | 16.3847 | 14.0985 | 14.8606 | 13.7174 | 10.6691 | 8.3829 |
| 23 | | | | 13.3364 | | | |
| 24 | 17.1468 | 17.1468 | 13.3364 | 13.3364 | 11.4312 | 9.526 | 9.907 |
| Max | 17.1468 | 17.1468 | 14.0985 | 14.8606 | 13.7174 | 10.6691 | 9.907 |
| Min | 16.3847 | 16.3847 | 13.3364 | 13.3364 | 11.4312 | 9.526 | 8.3829 |
| Avg | 16.7658 | 16.7658 | 13.7175 | 13.8445 | 12.5743 | 10.0976 | 9.1450 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084045 / 33kKV CK-DONGARGAON

Feeder No / Name : 201 / 11KV DHABA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .128 | .1097 | .1463 | .128 | .0953 | .1029 | .0953 |
| 2 | .132 | .1086 | .1646 | .1267 | .0953 | .1086 | .0953 |
| 3 | .128 | .1097 | .1646 | .1267 | .0953 | .0953 | .0953 |
| 4 | .128 | .1097 | .128 | .124 | .0953 | .1143 | |
| 5 | .1097 | .1097 | .0914 | .1097 | .0953 | .0914 | .0953 |
| 6 | .1075 | .1063 | .1097 | .1097 | .1143 | .0914 | .1143 |
| 7 | .1075 | .1097 | .1097 | .1097 | .1143 | .1097 | .1334 |
| 8 | .1097 | .1097 | .1097 | .1463 | .1334 | .1097 | .1334 |
| 9 | .1097 | .128 | .1227 | .1463 | .0953 | .1097 | .1143 |
| 10 | .1029 | .1494 | .1267 | .1463 | .1143 | .1097 | .1307 |
| 11 | .0914 | .1097 | .0914 | .1086 | .128 | .1097 | .1334 |
| 12 | .0905 | .128 | .0895 | .1029 | .1463 | .1086 | .0983 |
| 13 | .1097 | .1463 | .1387 | .1017 | .1086 | .1448 | .0983 |
| 14 | .1267 | .1097 | .1463 | .0663 | .1448 | .128 | .0983 |
| 15 | .1267 | .1086 | .128 | .0829 | .1267 | .1267 | .0983 |
| 16 | .1267 | .1097 | .128 | .0819 | .0743 | .0914 | .0983 |
| 17 | .1267 | .1267 | .128 | .116 | .1267 | .1448 | .1492 |
| 18 | .1448 | .1646 | .1463 | .1823 | .1417 | .1629 | .1492 |
| 19 | .1629 | .1463 | .1448 | .1715 | .1448 | .1629 | .1526 |
| 20 | .1372 | .1463 | .1433 | .1524 | .1463 | .1448 | .1715 |
| 21 | .1463 | .0743 | .1448 | .1334 | .132 | .1267 | .1715 |
| 22 | .1086 | .1097 | .128 | .1143 | .128 | .1086 | .1715 |
| 23 | .1086 | .12 | .128 | .1143 | .1143 | .0905 | .1715 |
| 24 | .128 | .1097 | .128 | .128 | .0953 | .1086 | .0953 |
| Max | .1629 | .1646 | .1646 | .1823 | .1463 | .1629 | .1715 |
| Min | .0905 | .0743 | .0895 | .0663 | .0743 | .0905 | .0953 |
| Avg | .1207 | .1192 | .1286 | .1221 | .1169 | .1167 | .1245 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084045 / 33kKV CK-DONGARGAON

Feeder No / Name : 202 / 11KV HIWARA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .181 | .1829 | .3109 | .2172 | .181 | .2378 | .1991 |
| 2 | .1791 | .1829 | .3292 | .2195 | | .2378 | .2012 |
| 3 | .1791 | .1829 | .2926 | .181 | .181 | .2195 | .197 |
| 4 | .1829 | .1829 | .2378 | .1829 | .1791 | .2378 | .197 |
| 5 | .1991 | .1829 | .2195 | .1829 | .1772 | .2195 | .1949 |
| 6 | .2012 | .1829 | .2195 | .1991 | .1928 | .2195 | .1949 |
| 7 | .2012 | .1829 | .2561 | .2012 | .1886 | .2378 | |
| 8 | .3077 | .2534 | .2303 | .2561 | .2401 | .2195 | .2229 |
| 9 | .3109 | .3109 | .2915 | .2561 | .2883 | .2561 | .2374 |
| 10 | .3109 | .2743 | .3292 | .2561 | .2683 | .2378 | .285 |
| 11 | .3077 | .3109 | .3258 | .2401 | .2926 | .2378 | .3315 |
| 12 | .3258 | .3475 | .3189 | .2915 | .3475 | .1991 | .3315 |
| 13 | .3258 | .3658 | .362 | | .3658 | .1829 | .3315 |
| 14 | .3258 | .4024 | .362 | .2543 | .3429 | .181 | .362 |
| 15 | .3086 | .3658 | .2378 | .3086 | .3475 | .1448 | .362 |
| 16 | .2105 | .3109 | .2378 | .2915 | .3658 | .1448 | .362 |
| 17 | .2896 | .3475 | .2378 | .2267 | .3109 | .1991 | .3814 |
| 18 | .2896 | .3109 | .2561 | .2896 | .3258 | .2715 | .3982 |
| 19 | .3292 | .3292 | .2715 | .3109 | .3292 | .3292 | .3982 |
| 20 | .2926 | .3109 | .2743 | .2743 | .2926 | .2926 | .3658 |
| 21 | .2896 | .3475 | .2481 | .2172 | .2378 | .2378 | .362 |
| 22 | .1829 | .3292 | .2561 | .181 | .3109 | .2172 | .1991 |
| 23 | .181 | .2883 | .2195 | .181 | .2743 | .1991 | .1991 |
| 24 | .1791 | .1715 | .3012 | .2172 | .1829 | .2378 | .1991 |
| Max | .3292 | .4024 | .362 | .3109 | .3658 | .3292 | .3982 |
| Min | .1791 | .1715 | .2195 | .181 | .1772 | .1448 | .1949 |
| Avg | .2538 | .2774 | .2761 | .2363 | .2706 | .2249 | .2832 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084045 / 33kKV CK-DONGARGAON

Feeder No / Name : 203 / 11KV LIS TOMTA

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 3 | | | .0114 |
| 4 | | | .0145 |
| 5 | | | .0114 |
| 6 | | .0099 | .0114 |
| 7 | | .0103 | .0114 |
| 8 | | .0099 | .0114 |
| 9 | | .0114 | |
| 10 | | .0114 | .0114 |
| 11 | .0103 | .0114 | |
| 12 | .0103 | .0114 | |
| 13 | .0111 | .0114 | |
| 14 | .0103 | .0114 | |
| 15 | .0103 | .0114 | |
| 16 | .0111 | .0114 | |
| 17 | .0103 | .0114 | |
| 18 | .0099 | .0114 | |
| 19 | .0111 | .0114 | |
| 20 | .0103 | .0114 | |
| 21 | .0111 | .0114 | |
| 22 | .0099 | .0114 | |
| 23 | | .0114 | |
| 24 | | .0114 | |
| Max | .0111 | .0114 | .0145 |
| Min | .0099 | .0099 | .0114 |
| Avg | .0105 | .0112 | .0118 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084045 / 33kKV CK-DONGARGAON

Feeder No / Name : 204 / 11KV DARUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2865 | .1715 | .2534 | .1715 |
| 2 | | .2865 | .1677 | .2534 | .1753 |
| 3 | | .2896 | .1715 | .2715 | .1829 |
| 4 | | .2507 | .1734 | .2534 | .1829 |
| 5 | | .2427 | .1886 | .2353 | .1829 |
| 6 | | .2353 | .2103 | .2534 | .2172 |
| 7 | | .2378 | .2126 | .2353 | .2561 |
| 8 | | .362 | .2572 | .2353 | .2926 |
| 9 | | .0762 | .3239 | .2753 | .3113 |
| 10 | | .3658 | .4049 | .3077 | .3222 |
| 11 | | .3163 | .2915 | .4031 | .3475 |
| 12 | | .3163 | .3563 | .4119 | .3403 |
| 13 | | .3593 | .4049 | .3944 | .3475 |
| 14 | | .3593 | .3401 | .4024 | .2865 |
| 15 | | .3593 | .2915 | .3658 | .2896 |
| 16 | | .2753 | .3077 | .3544 | .2926 |
| 17 | | .2591 | .2753 | .3086 | .3258 |
| 18 | | .3801 | .3601 | .3012 | .3292 |
| 19 | | .3841 | .3429 | .3544 | .3292 |
| 20 | | .3258 | .3077 | .3109 | .3045 |
| 21 | .3109 | .2534 | .2172 | .2303 | .3077 |
| 22 | .2865 | .1823 | .2715 | .2126 | .1646 |
| 23 | .2804 | .1823 | .2534 | .1772 | .1578 |
| 24 | | .2926 | .2353 | | .1753 |
| Max | .3109 | .3841 | .4049 | .4119 | .3475 |
| Min | .2804 | .0762 | .1677 | .1772 | .1578 |
| Avg | .2926 | .2866 | .2724 | .2957 | .2622 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3155 | .3688 | .3292 | .3077 |
| 2 | | .333 | .373 | .2743 | .2865 |
| 3 | | .3294 | .4115 | .2561 | .3012 |
| 4 | | .3155 | .3856 | .2534 | .2804 |
| 5 | | .3544 | .3982 | .2561 | .298 |
| 6 | | .3544 | .3475 | .2743 | .3258 |
| 7 | | .333 | .4801 | .3475 | .3801 |
| 8 | | .2804 | .4656 | .3658 | .2686 |
| 9 | | .543 | .4835 | .3841 | .4119 |
| 10 | | .3582 | .4075 | .3353 | .407 |
| 11 | | .3801 | .4252 | .2947 | .3018 |
| 12 | | .4252 | .3475 | .3481 | .2915 |
| 13 | | .3772 | .3475 | .3041 | .39 |
| 14 | | .3544 | .439 | .3189 | .3601 |
| 15 | | .2774 | .4477 | .3761 | .443 |
| 16 | | .2947 | .3898 | .3898 | .3932 |
| 17 | | .443 | .4382 | .4207 | .2721 |
| 18 | | .5611 | .6219 | .4938 | .3801 |
| 19 | | .5914 | .4805 | .6154 | .3801 |
| 20 | | .4251 | .4435 | .5121 | .4251 |
| 21 | | .4066 | .4207 | .2715 | .439 |
| 22 | | .4298 | .3658 | .3077 | .3841 |
| 23 | .298 | .4525 | .3982 | .3544 | .3475 |
| 24 | | .3841 | | .3258 | .3224 |
| Max | .298 | .5914 | .6219 | .6154 | .443 |
| Min | .298 | .2774 | .3475 | .2534 | .2686 |
| Avg | .298 | .3883 | .4212 | .3504 | .3499 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 202 / 11 KV AASHTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3658 | .3353 | .3353 | .3353 |
| 2 | .3506 | .3506 | .3048 | .3201 |
| 3 | .3353 | .3658 | .3048 | .3048 |
| 4 | .3506 | .3506 | .2743 | .3201 |
| 5 | .3658 | .3506 | .2896 | .3353 |
| 6 | .3658 | .3506 | .2896 | .3658 |
| 7 | .381 | .3506 | .3353 | .3658 |
| 8 | .5182 | .4572 | .4725 | .5365 |
| 9 | .5792 | .4572 | .3353 | .6539 |
| 10 | .503 | .5182 | .5335 | .4725 |
| 11 | .5639 | .5335 | .5487 | .5335 |
| 12 | .6706 | .7164 | .7011 | .6706 |
| 13 | .823 | .8078 | .7468 | .7164 |
| 14 | .7316 | .823 | .7316 | .7621 |
| 15 | .7621 | .7926 | .7468 | .7468 |
| 16 | .6859 | .6097 | .7011 | .503 |
| 17 | .6097 | .5639 | .5792 | .5487 |
| 18 | .6249 | .4877 | .4877 | .442 |
| 19 | .5792 | .3506 | .442 | .4268 |
| 20 | .442 | .4268 | .4268 | .4115 |
| 21 | .3963 | .381 | .381 | .4268 |
| 22 | .3506 | .3353 | .3658 | .3963 |
| 23 | .3658 | .3201 | .381 | .4115 |
| 24 | .3506 | .3506 | .3506 | .3353 |
| Max | .823 | .823 | .7468 | .7621 |
| Min | .3353 | .3201 | .2743 | .3048 |
| Avg | .5030 | .4744 | .4611 | .4726 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 203 / 11 KV VIHIRGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0924 | .0678 | .0724 | .0732 |
| 2 | .0934 | .0678 | .0914 | |
| 3 | .0747 | .0857 | .0914 | |
| 4 | .0924 | .0724 | .0549 | .0739 |
| 5 | .112 | .0914 | .0549 | .0924 |
| 6 | .1307 | .0914 | .0914 | .128 |
| 7 | .0924 | .0924 | .128 | .1227 |
| 8 | .1075 | .1109 | .1097 | .1174 |
| 9 | .1823 | | .1463 | .1677 |
| 10 | .1526 | .1865 | .1543 | .1433 |
| 11 | .1387 | .1543 | .1406 | .1086 |
| 12 | .1823 | .2012 | .116 | .1227 |
| 13 | .2035 | .2561 | .2294 | .1928 |
| 14 | .2155 | .1865 | .1898 | .2012 |
| 15 | .1943 | .1696 | .176 | .213 |
| 16 | .1638 | .2058 | .1509 | .1989 |
| 17 | .1715 | .1734 | .1829 | .0732 |
| 18 | .2452 | .2012 | .2033 | .1867 |
| 19 | .1886 | .2012 | .2054 | .1886 |
| 20 | .1886 | .1646 | .1494 | |
| 21 | .0943 | .128 | .1478 | .1132 |
| 22 | .1109 | .0732 | .1075 | .168 |
| 23 | .0924 | .0914 | .0732 | .1494 |
| 24 | .0724 | | .0732 | .064 |
| Max | .2452 | .2561 | .2294 | .213 |
| Min | .0724 | .0678 | .0549 | .064 |
| Avg | .1414 | .1397 | .1308 | .1380 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 204 / 11 KV AKSAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0819 | .0579 | .0732 | .0648 |
| 2 | .0655 | .0743 | .128 | .0655 |
| 3 | .0663 | .0838 | .128 | .0497 |
| 4 | .0838 | .0995 | .1097 | .0857 |
| 5 | .1006 | .0838 | .1097 | .0867 |
| 6 | .1187 | .1063 | .128 | .1227 |
| 7 | .1006 | .0838 | .128 | .104 |
| 8 | .1174 | .128 | .128 | .1326 |
| 9 | .1509 | .116 | .1646 | .1509 |
| 10 | .1387 | .1581 | .1296 | .1311 |
| 11 | .1457 | .1423 | .1265 | .1147 |
| 12 | .1423 | .1463 | .1406 | .1265 |
| 13 | .1355 | .1829 | .1562 | .16 |
| 14 | .1235 | .16 | .128 | .1311 |
| 15 | .1524 | .1629 | .1107 | .128 |
| 16 | .1054 | .144 | .1326 | .1189 |
| 17 | .1189 | .1355 | .1296 | .1107 |
| 18 | .1829 | .2012 | .2195 | .2012 |
| 19 | .2033 | .2054 | .2054 | .1867 |
| 20 | .181 | .1848 | .1848 | .1829 |
| 21 | .1254 | .1075 | .1267 | .1387 |
| 22 | .1006 | .0914 | .1029 | .156 |
| 23 | .081 | .0819 | .081 | .156 |
| 24 | .0648 | | .064 | .064 |
| Max | .2033 | .2054 | .2195 | .2012 |
| Min | .0648 | .0579 | .064 | .0497 |
| Avg | .1203 | .1277 | .1306 | .1237 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 205 / 11 KV BEMBAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .333 | .3418 | .3658 | .306 |
| 2 | .3227 | .3978 | .3841 | .333 |
| 3 | .3418 | .3812 | .4024 | |
| 4 | .3612 | .3688 | .4207 | .3418 |
| 5 | .3506 | .3144 | .3658 | .3567 |
| 6 | .3437 | .3549 | .4207 | .3763 |
| 7 | .3549 | .3913 | .4024 | .3462 |
| 8 | .4816 | .4572 | .5121 | .2858 |
| 9 | .5639 | .602 | .6584 | .5268 |
| 10 | .5944 | .535 | .5135 | .5135 |
| 11 | .6327 | .5569 | .5135 | .5575 |
| 12 | .6996 | .8048 | .6321 | .602 |
| 13 | .7819 | 1.0059 | .7407 | .6859 |
| 14 | .8109 | .8124 | .7011 | .7164 |
| 15 | .6923 | .7716 | .7011 | .6773 |
| 16 | .6015 | .7011 | .6472 | .5944 |
| 17 | .5575 | .5201 | .5719 | .4755 |
| 18 | .5304 | .3481 | .5735 | .5365 |
| 19 | .5426 | .5365 | .5596 | .5316 |
| 20 | .4752 | .3277 | .4915 | .4862 |
| 21 | .4111 | .3906 | .4167 | .3637 |
| 22 | .333 | .4024 | .3429 | .4801 |
| 23 | .3243 | .2881 | | .502 |
| 24 | .3637 | | .3018 | .3199 |
| Max | .8109 | 1.0059 | .7407 | .7164 |
| Min | .3227 | .2881 | .3018 | .2858 |
| Avg | .4919 | .5048 | .5061 | .4746 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084046 / 33KV GONDPIPRI

Feeder No / Name : 206 / 11 KV WADKULI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0457 | .0594 | .0914 | .0412 |
| 2 | | .0617 | .0503 | .0914 | .0423 |
| 3 | | .0469 | .0434 | .0732 | .0434 |
| 4 | | .0633 | .0446 | .0732 | .0446 |
| 5 | | .0633 | .0503 | .0549 | .061 |
| 6 | | .081 | .0655 | .0732 | .1475 |
| 7 | | .081 | .0625 | .0732 | .0781 |
| 8 | | .0734 | .064 | .0914 | .0587 |
| 9 | | .0903 | .0724 | .0886 | .125 |
| 10 | | .0903 | .0724 | .108 | .0695 |
| 11 | | .1406 | .0869 | .0676 | .0846 |
| 12 | | .1286 | .0732 | .1204 | .1128 |
| 13 | | .1572 | .2012 | .1467 | .1429 |
| 14 | | .1932 | .1829 | .1448 | .1593 |
| 15 | | .1252 | .1656 | .0987 | .1235 |
| 16 | | .0823 | .1829 | .12 | .1429 |
| 17 | | .1158 | .1829 | .0846 | .1 |
| 18 | | .1214 | .1526 | .1052 | .1214 |
| 19 | | .1406 | .128 | .1267 | .1433 |
| 20 | | .1187 | .1063 | .1086 | .1227 |
| 21 | | .0678 | .0995 | .0829 | .0819 |
| 22 | | .0434 | .0549 | .0434 | .0983 |
| 23 | .044 | .0383 | .0394 | .0383 | .081 |
| 24 | | .0383 | | .0629 | .0389 |
| Max | .044 | .1932 | .2012 | .1467 | .1593 |
| Min | .044 | .0383 | .0394 | .0383 | .0389 |
| Avg | .044 | .0920 | .0974 | .0904 | .0944 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084052 / 33/11KV Tohogaon Substation

Feeder No / Name : 208 / 11KV TOHOGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .116 | .116 | .0995 | .0995 |
| 2 | .116 | .0995 | .0995 | .0995 |
| 3 | .116 | .0995 | .0995 | .0995 |
| 4 | .116 | .0995 | .0995 | .0995 |
| 5 | .116 | .0995 | .0995 | .0995 |
| 6 | .116 | .0995 | .0995 | .0995 |
| 7 | .116 | .116 | .116 | .116 |
| 8 | .1492 | .0995 | .1492 | .1326 |
| 9 | .1823 | .1658 | .1989 | .1658 |
| 10 | .1989 | .1823 | .1658 | .1989 |
| 11 | .2155 | .1989 | .1658 | .1989 |
| 12 | .2155 | .2486 | .1989 | .2155 |
| 13 | .2652 | .2486 | .2155 | .2321 |
| 14 | .2652 | .2458 | .2652 | .2321 |
| 15 | .2818 | .2622 | .2652 | .2652 |
| 16 | .2818 | .2622 | .2652 | .2486 |
| 17 | .2321 | .2321 | .2486 | .2155 |
| 18 | .1823 | .1492 | .1492 | .1492 |
| 19 | .1658 | .1492 | .1658 | .1658 |
| 20 | .1658 | .1326 | .1492 | .1658 |
| 21 | .1326 | .116 | .1326 | .1492 |
| 22 | .1326 | .0995 | .0995 | .1326 |
| 23 | .116 | .0995 | .0995 | .116 |
| 24 | .116 | .116 | .0995 | .0995 |
| Max | .2818 | .2622 | .2652 | .2652 |
| Min | .116 | .0995 | .0995 | .0995 |
| Avg | .1713 | .1557 | .1561 | .1582 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084052 / 33/11KV Tohogaon Substation

Feeder No / Name : 209 / 11KV KUDESAOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1492 | .1134 | .1147 | .1492 |
| 2 | | .1492 | .0995 | .1147 | .1492 |
| 3 | | .1492 | .0972 | .1147 | .1492 |
| 4 | | .1492 | .0972 | .1147 | .1492 |
| 5 | | .1492 | .0972 | .1147 | .1492 |
| 6 | | .1658 | .0972 | .1147 | .1492 |
| 7 | | .1823 | .0972 | .1475 | .1492 |
| 8 | | .1823 | .1475 | .1475 | .1492 |
| 9 | .2458 | .2486 | .1781 | .2294 | .1823 |
| 10 | | .2785 | .2105 | .2458 | .1989 |
| 11 | | .2294 | .213 | .2622 | .1658 |
| 12 | | .2785 | .2785 | .2622 | .1823 |
| 13 | | .2949 | .3277 | .3277 | .2321 |
| 14 | | .3113 | .3441 | .3441 | .2486 |
| 15 | | .2949 | .3441 | .3113 | .2785 |
| 16 | | .2949 | .3441 | .3277 | .3277 |
| 17 | | .2785 | .2949 | .2785 | .2622 |
| 18 | | .1802 | .1638 | .1966 | .1966 |
| 19 | | .1638 | .1638 | .1966 | .1475 |
| 20 | | .1638 | .1638 | .1966 | .1475 |
| 21 | | .1638 | .1311 | .1638 | .1311 |
| 22 | | .1311 | .1147 | .1475 | .1147 |
| 23 | | .1296 | .1147 | .1475 | .1147 |
| 24 | | .1492 | .1296 | .1147 | .1492 |
| Max | .2458 | .3113 | .3441 | .3441 | .3277 |
| Min | .2458 | .1296 | .0972 | .1147 | .1147 |
| Avg | .2458 | .2028 | .1818 | .1973 | .1781 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 084052 / 33/11KV Tohogaon Substation

Feeder No / Name : 210 / 11KV LATHI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1492 | .144 | .1492 | .1492 |
| 2 | .1492 | .128 | .1492 | .1492 |
| 3 | .1492 | .128 | .1492 | .1492 |
| 4 | .1492 | .128 | .1492 | .1492 |
| 5 | .1492 | .112 | .1492 | .1492 |
| 6 | .1658 | .096 | .1658 | .1492 |
| 7 | .1658 | .096 | .1326 | .1492 |
| 8 | .1989 | .112 | .1823 | .1492 |
| 9 | .2486 | .176 | .2486 | .2155 |
| 10 | .2591 | .208 | .2652 | .2486 |
| 11 | .2591 | .2458 | .2486 | .2818 |
| 12 | .3401 | .3113 | .2818 | .3481 |
| 13 | .4049 | .3932 | .4144 | .4144 |
| 14 | .4534 | .426 | .4144 | .431 |
| 15 | .3887 | .3605 | .431 | .4049 |
| 16 | .4049 | .3932 | .4475 | .3887 |
| 17 | .3725 | .3932 | .3978 | .3401 |
| 18 | .2267 | .2294 | .2155 | .1619 |
| 19 | .2105 | .2294 | .2155 | .1781 |
| 20 | .1781 | .213 | .1823 | .1619 |
| 21 | .1619 | .1638 | .1658 | .1296 |
| 22 | .1619 | .1638 | .1492 | .1296 |
| 23 | .144 | .1475 | .1492 | .1134 |
| 24 | .1492 | .144 | .1492 | .1492 |
| Max | .4534 | .426 | .4475 | .431 |
| Min | .144 | .096 | .1326 | .1134 |
| Avg | .2350 | .2143 | .2334 | .2204 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 336000 / 132 kv Ashti

Feeder No / Name : 401 / 33KV GONDPIPRI FEEDER FROM NON SHEDDABLE EXPRESS HV FEEDERS
EHV Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24 | 1.5043 | 1.4661 | 1.4815 | 1.3432 | 1.7918 |
| Max | 1.5043 | 1.4661 | 1.4815 | 1.3432 | 1.7918 |
| Min | 1.5043 | 1.4661 | 1.4815 | 1.3432 | 1.7918 |
| Avg | 1.5043 | 1.4661 | 1.4815 | 1.3432 | 1.7918 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 336000 / 132 kv Ashti

Feeder No / Name : 402 / 33KV CK.DONGARGAON FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
FROM Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24 | .6859 | .5144 | .6287 | .5144 |
| Max | .6859 | .5144 | .6287 | .5144 |
| Min | .6859 | .5144 | .6287 | .5144 |
| Avg | .6859 | .5144 | .6287 | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

GONDPIPRI S/DN.[329] BU 4329

Substation No/ Name :- 336001 / 220KV WIRUR SUBSTATION

Feeder No / Name : 405 / 33KV TOHOGAON FEEDER FROM NON SHEDDABLE EHV INDUSTRIAL FEEDERS
220K Feeder KV- 33 / INCOMING (NON CONTINOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 24 | .439 | .3841 | .3841 | .3481 |
| Max | .439 | .3841 | .3841 | .3481 |
| Min | .439 | .3841 | .3841 | .3481 |
| Avg | .439 | .3841 | .3841 | .3481 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084011 / 33 KV JIWATI

Feeder No / Name : 201 / 11 KV TEKAMANDWA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2957 | .2534 | .0739 | .2587 |
| 2 | .2957 | .2353 | .0739 | .2587 |
| 3 | .2957 | .2353 | .0739 | .2587 |
| 4 | .2957 | .2353 | .0739 | .2587 |
| 5 | .3142 | .3258 | .0739 | .3696 |
| 6 | .3326 | .362 | .0924 | .4066 |
| 7 | .3326 | .3982 | .0924 | .4251 |
| 8 | .3696 | .3801 | .0924 | .4755 |
| 9 | .3439 | .3801 | .2957 | .4481 |
| 10 | .3258 | | .3511 | .3734 |
| 11 | | .2896 | .3881 | .3361 |
| 12 | .1629 | .3077 | .3511 | .3361 |
| 13 | .362 | .3258 | .3326 | .3361 |
| 14 | .5068 | .3439 | .3511 | .2801 |
| 15 | .4344 | .3258 | | .3361 |
| 16 | .4706 | .2353 | | .3734 |
| 17 | .6878 | .2957 | | .3734 |
| 18 | .6516 | .2957 | | .3547 |
| 19 | .6516 | .3511 | .4066 | .4108 |
| 20 | .6878 | .3511 | .4066 | .4108 |
| 21 | .6516 | .3511 | .3881 | .3734 |
| 22 | .543 | | .3511 | .3734 |
| 23 | .5068 | | .2772 | .3361 |
| 24 | .3142 | .2534 | .0724 | .2772 |
| Max | .6878 | .3982 | .4066 | .4755 |
| Min | .1629 | .2353 | .0724 | .2587 |
| Avg | .4275 | .3110 | .2309 | .3517 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084011 / 33 KV JIWATI

Feeder No / Name : 202 / 11 KV WANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4251 | .5068 | .462 | .4755 |
| 2 | .4251 | .4887 | .462 | .4805 |
| 3 | .4251 | .4887 | .462 | .4755 |
| 4 | .4251 | .4887 | .4805 | .4805 |
| 5 | .4251 | .4887 | .5544 | .4755 |
| 6 | .6099 | | .6283 | .499 |
| 7 | .6283 | .4887 | .6468 | .4938 |
| 8 | .7023 | | .5175 | .6219 |
| 9 | .6335 | | .5544 | .6348 |
| 10 | .6154 | | .5359 | |
| 11 | .6335 | .5914 | | .5601 |
| 12 | .6516 | .6468 | | .5601 |
| 13 | 1.2437 | .6653 | | .5601 |
| 14 | 1.1706 | .6468 | | .6161 |
| 15 | 1.2072 | .6838 | | .6161 |
| 16 | 1.3169 | .6468 | .5729 | .5975 |
| 17 | 1.3535 | .7207 | .5544 | .6348 |
| 18 | 1.3828 | .6468 | .6468 | .6722 |
| 19 | 1.2736 | .6099 | .6838 | .6722 |
| 20 | 1.2373 | .5359 | .6468 | .6348 |
| 21 | 1.1706 | .5175 | .6099 | .5601 |
| 22 | 1.0608 | .4805 | .5544 | .5601 |
| 23 | 1.0243 | .462 | .499 | .5228 |
| 24 | .4435 | .5175 | .462 | .499 |
| Max | 1.3828 | .7207 | .6838 | .6722 |
| Min | .4251 | .462 | .462 | .4755 |
| Avg | .8535 | .5661 | .5544 | .561 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084011 / 33 KV JIWATI

Feeder No / Name : 203 / 11 KV JIVTI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1478 | .1463 | .128 | .1294 |
| 2 | .1478 | .1463 | .1294 | .1294 |
| 3 | .1478 | .1463 | .1294 | .128 |
| 4 | .1478 | .1829 | .1478 | .1478 |
| 5 | .1663 | .2561 | .2218 | .2218 |
| 6 | .2218 | .2561 | .2587 | .2587 |
| 7 | .2587 | .2743 | .2587 | .2561 |
| 8 | .2587 | .3292 | .2957 | .2402 |
| 9 | .2378 | .2926 | .3142 | .1646 |
| 10 | .2195 | .2378 | .2772 | .1646 |
| 11 | .2012 | .2378 | .2218 | .1646 |
| 12 | .2195 | .2195 | .2033 | .1646 |
| 13 | .4045 | .2012 | .2033 | .1646 |
| 14 | .439 | .1829 | .1848 | .1646 |
| 15 | .4024 | .1663 | .1478 | .1867 |
| 16 | .3658 | .1478 | .1663 | .1867 |
| 17 | .439 | .1848 | .1294 | .2241 |
| 18 | .4756 | .2402 | .1848 | .2427 |
| 19 | .4756 | .2218 | .2033 | .2614 |
| 20 | .439 | .1848 | .2033 | .2427 |
| 21 | .439 | .1663 | .1848 | .1867 |
| 22 | .2926 | .1478 | .1663 | .1867 |
| 23 | .2926 | .1294 | .1294 | .1494 |
| 24 | .1478 | .1463 | .1294 | .128 |
| Max | .4756 | .3292 | .3142 | .2614 |
| Min | .1478 | .1294 | .128 | .128 |
| Avg | .2912 | .2019 | .1925 | .1873 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084011 / 33 KV JIWATI

Feeder No / Name : 204 / YELLAPUR NEW 11KV FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1478 | .1478 | .1478 | .1463 |
| 2 | .1478 | .1478 | .1478 | .1463 |
| 3 | .1478 | .1478 | .1478 | .1478 |
| 4 | .1478 | .1478 | .1478 | .1463 |
| 5 | .1663 | .1663 | .1478 | .1463 |
| 6 | .1848 | .1848 | .1848 | .2012 |
| 7 | .2033 | .2033 | .2033 | .2218 |
| 8 | .1848 | .2033 | .1848 | .2033 |
| 9 | .1848 | .1848 | .1478 | .1867 |
| 10 | .1663 | .128 | .1478 | .168 |
| 11 | .1478 | | .1478 | .1307 |
| 12 | .1294 | .1294 | .1294 | .1307 |
| 13 | .1294 | .1267 | .1294 | .1307 |
| 14 | .1294 | .1086 | .1294 | .1307 |
| 15 | .1294 | .1086 | .1109 | .112 |
| 16 | .1294 | .1294 | .1294 | .112 |
| 17 | .1663 | .1294 | .1294 | .168 |
| 18 | .2033 | .1991 | .1663 | .2054 |
| 19 | .1848 | .2033 | .2033 | .2054 |
| 20 | .1848 | .1848 | .2033 | .2054 |
| 21 | .1663 | .1663 | .1848 | .1867 |
| 22 | .1478 | .1663 | .1848 | .1867 |
| 23 | .1478 | .1478 | .1663 | .168 |
| 24 | .1478 | .1478 | .1478 | .1663 |
| Max | .2033 | .2033 | .2033 | .2218 |
| Min | .1294 | .1086 | .1109 | .112 |
| Avg | .1594 | .1569 | .1571 | .1647 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084041 / 33KV Ambezari Substation

Feeder No / Name : 201 / Patan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2172 | .181 | .1629 | .1738 | .1646 | .1829 | .2195 |
| 2 | .2172 | .181 | .1448 | .1683 | .1646 | .1646 | .2012 |
| 3 | .2353 | .181 | .1448 | .128 | .1463 | .1646 | .2195 |
| 4 | .2534 | .181 | .1448 | .1372 | .1829 | .1829 | .2195 |
| 5 | .2353 | .1991 | .1629 | .139 | .1829 | .1829 | .2195 |
| 6 | .2172 | .2172 | .1448 | .1756 | .2012 | .2012 | .2195 |
| 7 | .2353 | .2534 | .1991 | .2122 | .2561 | .1646 | .2561 |
| 8 | .2172 | .2172 | .1629 | .1902 | .2195 | .2195 | .2378 |
| 9 | .1991 | .1991 | .1267 | .1829 | .1829 | .2012 | .2195 |
| 10 | .2172 | .1448 | .1086 | .1756 | .1646 | .1646 | .2195 |
| 11 | .1629 | .1629 | .1448 | | .1646 | .1646 | .1829 |
| 12 | .1629 | .1629 | .1448 | | .1646 | .1646 | .0914 |
| 13 | .181 | .1448 | .1448 | .1683 | .1646 | .1646 | .128 |
| 14 | .1629 | .1448 | | .1701 | .1646 | .1829 | .1463 |
| 15 | .1629 | .1448 | .1448 | .161 | .1829 | .1646 | .128 |
| 16 | .1991 | .1267 | .1448 | .1683 | .1829 | .128 | .128 |
| 17 | .1629 | .1629 | .1448 | .1701 | .1829 | .1646 | .1463 |
| 18 | .2172 | .2172 | .2534 | .2341 | .2561 | .2561 | .2561 |
| 19 | .2534 | .2353 | .2534 | .2634 | .2561 | .2743 | .2561 |
| 20 | .2534 | .2172 | .2353 | .2268 | .2378 | .2743 | .2378 |
| 21 | .2172 | .1991 | .1991 | .2122 | .2195 | .2561 | .2195 |
| 22 | .1991 | .181 | .181 | .1756 | .2195 | .2378 | .2195 |
| 23 | .181 | .181 | .181 | .1719 | .2012 | .2378 | .2378 |
| 24 | .1991 | .181 | .181 | .1629 | | .2012 | .2195 |
| Max | .2534 | .2534 | .2534 | .2634 | .2561 | .2743 | .2561 |
| Min | .1629 | .1267 | .1086 | .128 | .1463 | .128 | .0914 |
| Avg | .2066 | .1840 | .1676 | .1803 | .1940 | .1959 | .2012 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084041 / 33KV Ambezari Substation

Feeder No / Name : 202 / 11 KV SHENGOAN FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2172 | .1629 | .1629 | .128 | | .1646 | .1831 |
| 2 | | .1629 | .1629 | .128 | | .1829 | .2012 |
| 3 | .2353 | .1629 | .1629 | .128 | | .1829 | .2195 |
| 4 | .2534 | .181 | .181 | .1646 | | .2012 | .2378 |
| 5 | .2715 | .181 | .181 | .1829 | | .2195 | .2378 |
| 6 | .2896 | .2172 | .2353 | .2195 | | .2378 | .2561 |
| 7 | .3077 | .3439 | .3077 | .2012 | | .3475 | .3292 |
| 8 | .3258 | .3077 | .2353 | .2195 | | .3109 | .3475 |
| 9 | .2896 | .2534 | .2896 | .2012 | | .3109 | .3109 |
| 10 | .2172 | .2353 | .2534 | .1646 | | .3109 | .2561 |
| 11 | .1991 | .2353 | | .1463 | | .2195 | .2195 |
| 12 | .181 | .1991 | .2534 | .1646 | | .2195 | |
| 13 | .181 | .1991 | .2353 | .128 | | .2012 | .2012 |
| 14 | .1991 | .1991 | .181 | .0732 | | .2012 | .1829 |
| 15 | .181 | .1991 | .181 | .0914 | | .1646 | .1829 |
| 16 | .181 | .1991 | .1991 | .1463 | | .1646 | .1463 |
| 17 | .2172 | .1629 | .2172 | .128 | | .2195 | .1829 |
| 18 | .2534 | .2715 | .2715 | .2195 | | .2195 | .2378 |
| 19 | .2353 | .2715 | .2534 | .1829 | | .2561 | .2743 |
| 20 | .1991 | .2353 | .2172 | .2561 | | .2378 | .2561 |
| 21 | .1991 | .1991 | .181 | .2378 | | .2012 | .2195 |
| 22 | .1629 | .1629 | .1629 | .1646 | | .2012 | .2378 |
| 23 | .1629 | .1629 | .1448 | .1463 | | .1829 | .2378 |
| 24 | .1991 | .1448 | .1629 | .1267 | .1646 | .1646 | .1829 |
| Max | .3258 | .3439 | .3077 | .2561 | .1646 | .3475 | .3475 |
| Min | .1629 | .1448 | .1448 | .0732 | .1646 | .1646 | .1463 |
| Avg | .2243 | .2104 | .2101 | .1646 | .1646 | .2218 | .2322 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084041 / 33KV Ambezari Substation

Feeder No / Name : 203 / 11 KV BHARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2715 | .2172 | .2172 | .2378 | .2378 | .2378 | .2378 |
| 2 | .2896 | .2172 | .2172 | .2341 | .2378 | .2012 | .2378 |
| 3 | .2896 | .2353 | .1991 | .2195 | .2195 | .2378 | .2561 |
| 4 | .2896 | .2353 | .2353 | .2378 | .2561 | .2561 | .2561 |
| 5 | .3077 | .2715 | .2353 | .2561 | .2743 | .2561 | .2743 |
| 6 | .3077 | .2896 | .3077 | .3109 | .2926 | .2743 | .2743 |
| 7 | .3077 | .3258 | .3439 | .3475 | .3292 | .3475 | .3292 |
| 8 | .3258 | .3077 | .3258 | .3475 | .3109 | .3109 | .2926 |
| 9 | .3077 | .3258 | .3258 | .3109 | .2743 | .2926 | .3109 |
| 10 | .3077 | .2715 | .2715 | .3109 | .2743 | .2743 | .2743 |
| 11 | .181 | .2896 | .2715 | .2743 | .2561 | .2743 | .2378 |
| 12 | .2172 | .3439 | .2715 | .2378 | .2743 | .2012 | .2743 |
| 13 | .2534 | .3077 | .2896 | .2195 | .2926 | .2378 | .1463 |
| 14 | .181 | .2896 | .2715 | .2743 | .3109 | .2743 | .2561 |
| 15 | .2353 | .3077 | .2534 | .2743 | .2926 | .2378 | .2561 |
| 16 | .2534 | .2534 | .2715 | .2926 | .2743 | .2378 | .2743 |
| 17 | .2715 | .2353 | .2715 | .3475 | .2743 | .2743 | .2743 |
| 18 | .2896 | .3258 | .3439 | .3475 | .3109 | .3292 | .3109 |
| 19 | .3077 | .3439 | .362 | .3292 | .3109 | .3292 | .1463 |
| 20 | .3077 | .3077 | .3258 | .3292 | .3109 | .3109 | .3109 |
| 21 | .2715 | .2896 | .2896 | .3109 | .2926 | .2743 | .2926 |
| 22 | .2534 | .2715 | .2534 | .2561 | .2926 | .2561 | .2792 |
| 23 | .2172 | .2172 | .2353 | .2561 | .2743 | .2561 | .3109 |
| 24 | .2715 | .2172 | .2172 | .2353 | .2378 | | .2561 |
| Max | .3258 | .3439 | .362 | .3475 | .3292 | .3475 | .3292 |
| Min | .181 | .2172 | .1991 | .2195 | .2195 | .2012 | .1463 |
| Avg | .2715 | .2790 | .2753 | .2832 | .2797 | .2688 | .2654 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084041 / 33KV Ambezari Substation

Feeder No / Name : 401 / 33KV INCOMER AT AMBEZARI NON SHEDDABLE EXPRESS HV FEEDERS
 S/S Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7918 | 1.7375 | 1.5203 | | 1.3717 | 1.4266 | 1.6461 |
| 2 | 1.7375 | 1.6289 | 1.5203 | | 1.3169 | 1.1523 | 1.5912 |
| 3 | 1.8461 | 1.6289 | 1.5203 | | 1.3169 | 1.2071 | 1.5912 |
| 4 | 1.7918 | 1.5746 | 1.5746 | | 1.3717 | 1.2071 | 1.5912 |
| 5 | 1.9004 | 1.5746 | 1.5746 | 1.3717 | 1.3169 | 1.3169 | 1.6461 |
| 6 | 1.8461 | 1.6832 | 1.6289 | | 1.1523 | 1.3717 | 1.6461 |
| 7 | 1.5203 | 2.1176 | 2.1176 | | 1.5364 | 1.8656 | 1.9753 |
| 8 | 1.5746 | 2.0633 | 2.0633 | | 1.5912 | 1.701 | 2.1948 |
| 9 | 1.9004 | 2.0633 | 2.0633 | | 1.4266 | 1.701 | 1.9204 |
| 10 | 1.8461 | 1.9004 | 1.9004 | | .9328 | 1.701 | 1.3169 |
| 11 | 1.6832 | 1.9004 | 1.7375 | | 1.4266 | 1.2071 | 1.4266 |
| 12 | 1.6289 | 1.7918 | 1.7918 | | 1.7558 | .9877 | 1.7558 |
| 13 | 1.6289 | 1.6289 | 1.8461 | | 1.9204 | 1.1523 | 1.6461 |
| 14 | 1.4661 | 1.1403 | 1.2489 | | 1.7558 | 1.0974 | 1.6461 |
| 15 | 1.6289 | 1.5746 | 1.3575 | | 1.8107 | .7133 | 1.5912 |
| 16 | 1.4661 | 1.4661 | .9774 | | 1.7558 | 1.1523 | 1.6461 |
| 17 | 1.6832 | 1.4661 | 1.086 | | 1.701 | 1.3169 | 1.8107 |
| 18 | 2.009 | 1.9547 | 2.0633 | | 2.0851 | 1.7558 | 2.0851 |
| 19 | 2.009 | 1.9547 | 2.1719 | 2.1176 | 1.9753 | 2.1399 | .7682 |
| 20 | 1.9547 | 1.9004 | 2.009 | 1.9547 | 1.7558 | 1.9204 | 2.0302 |
| 21 | 1.7918 | 1.7918 | 1.7375 | 1.7918 | 1.7558 | 1.7558 | 1.8656 |
| 22 | 1.6289 | 1.6289 | 1.6289 | 1.5912 | 1.6461 | 1.701 | 1.9004 |
| 23 | 1.6289 | 1.6289 | 1.4661 | 1.5364 | 1.4815 | 1.701 | |
| 24 | 1.7918 | 1.6289 | 1.5203 | 1.4661 | 1.4815 | | 1.6461 |
| Max | 2.009 | 2.1176 | 2.1719 | 2.1176 | 2.0851 | 2.1399 | 2.1948 |
| Min | 1.4661 | 1.1403 | .9774 | 1.3717 | .9328 | .7133 | .7682 |
| Avg | 1.7398 | 1.7262 | 1.6719 | 1.6899 | 1.5684 | 1.4457 | 1.6929 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

JIWATI S/DN.[834]

BU 4834

Substation No/ Name :- 084041 / 33KV Ambezari Substation

Feeder No / Name : 402 / 33KV OUTGOING FEEDER FOR NON SHEDDABLE EXPRESS HV FEEDERS
 JIWAT Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.086 | 1.0317 | 1.0425 | .7133 | 1.0974 |
| 2 | 1.0317 | 1.0317 | .823 | .7682 | 1.0974 |
| 3 | 1.1403 | 1.0317 | .6584 | .7682 | 1.0974 |
| 4 | 1.086 | .9774 | .7682 | .7682 | 1.1523 |
| 5 | 1.1403 | .9774 | .7133 | .823 | 1.1523 |
| 6 | .9774 | 1.086 | .6036 | .823 | 1.1523 |
| 7 | .8688 | 1.3575 | .7682 | 1.1523 | 1.3717 |
| 8 | .8688 | 1.3575 | .823 | .9877 | 1.4266 |
| 9 | 1.2489 | 1.4118 | .823 | 1.0425 | 1.2071 |
| 10 | 1.2489 | 1.3575 | .3881 | 1.0974 | .7133 |
| 11 | 1.2489 | | .9328 | .7407 | .8779 |
| 12 | 1.1403 | | 1.2071 | .5487 | 1.1523 |
| 13 | 1.086 | | 1.262 | .5487 | 1.0974 |
| 14 | 1.0317 | | 1.0974 | .5487 | 1.1523 |
| 15 | 1.086 | | 1.2071 | .7682 | 1.1523 |
| 16 | .9774 | | 1.262 | .823 | 1.1523 |
| 17 | 1.1403 | | 1.1523 | 1.0425 | 1.2071 |
| 18 | 1.3575 | | | 1.4266 | 1.3717 |
| 19 | 1.3575 | | 1.3717 | 1.262 | 1.5364 |
| 20 | 1.3032 | | 1.3169 | 1.2071 | 1.3717 |
| 21 | 1.1946 | | 1.2071 | 1.2071 | 1.262 |
| 22 | 1.1403 | | 1.0425 | 1.1523 | 1.262 |
| 23 | 1.086 | | .9877 | 1.1523 | 1.2071 |
| 24 | 1.1946 | 1.086 | | .8779 | 1.0974 |
| Max | 1.3575 | 1.4118 | 1.3717 | 1.4266 | 1.5364 |
| Min | .8688 | .9774 | .3881 | .5487 | .7133 |
| Avg | 1.1267 | 1.1551 | .9754 | .9271 | 1.1820 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 201 / 11 KV DEWADA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1006 | .0732 | .0905 | .0671 |
| 2 | | .0857 | .0739 | .0886 | .0678 |
| 3 | | .0857 | .0747 | .0924 | .0648 |
| 4 | | .0857 | .0732 | .0914 | .0633 |
| 5 | | .0876 | .0686 | .0905 | .0514 |
| 6 | | .0886 | .0724 | .0876 | .052 |
| 7 | | .0857 | .052 | .0867 | .0532 |
| 8 | | .0934 | .0671 | .0829 | .0716 |
| 9 | | .0829 | .0503 | .0895 | .0686 |
| 10 | | .1227 | .1029 | .1387 | .0101 |
| 11 | | .0686 | .0142 | .0819 | .0625 |
| 12 | | .0648 | .0671 | .0914 | .0924 |
| 13 | | .0848 | .0838 | .1227 | .128 |
| 14 | | .0905 | .0838 | .0509 | .128 |
| 15 | | .1086 | .0886 | .0549 | .1402 |
| 16 | | .0934 | .064 | .0886 | .1052 |
| 17 | | .0678 | .081 | .0514 | .1214 |
| 18 | | .1494 | .2012 | .1478 | .1494 |
| 19 | | .1494 | .1867 | .1848 | .168 |
| 20 | | .1307 | .1478 | .1494 | .1294 |
| 21 | | .0914 | .1075 | .1097 | .1086 |
| 22 | .0857 | .0709 | .0867 | .0701 | .0857 |
| 23 | .0838 | .0914 | .0924 | .061 | .0762 |
| 24 | | .0829 | .0857 | .08 | .0671 |
| Max | .0857 | .1494 | .2012 | .1848 | .168 |
| Min | .0838 | .0648 | .0142 | .0509 | .0101 |
| Avg | .0848 | .0943 | .0875 | .0951 | .0888 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 202 / 11 KV POMBHURNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .112 | .0943 | | .0943 |
| 2 | | .112 | .0943 | | .0914 |
| 3 | | .112 | .0934 | | .0905 |
| 4 | | .0934 | .0934 | | .0895 |
| 5 | | .112 | .0943 | | .0934 |
| 6 | | .1132 | .1132 | | .1132 |
| 7 | | .1132 | .0943 | | .1132 |
| 8 | | .1132 | .1307 | | .1307 |
| 9 | | .1494 | .0129 | | .132 |
| 10 | | .1478 | .1294 | .128 | .112 |
| 11 | | .128 | .128 | .128 | .1646 |
| 12 | | .128 | .0934 | .1254 | .1132 |
| 13 | | .1254 | .1612 | .1612 | .112 |
| 14 | | .1267 | .1612 | .1433 | |
| 15 | | .128 | .1578 | .1109 | .1086 |
| 16 | | .1448 | .124 | .1267 | .1294 |
| 17 | | .1829 | .1227 | .1478 | .1097 |
| 18 | | .2241 | .2075 | .132 | .2263 |
| 19 | | .2263 | .2075 | .1905 | .2452 |
| 20 | | .2263 | .1886 | .1698 | .2075 |
| 21 | | .1886 | .1524 | .132 | .1698 |
| 22 | .132 | .1698 | .1132 | .1132 | .1698 |
| 23 | .1132 | .1307 | .0924 | .0943 | .1509 |
| 24 | | .112 | .112 | .0943 | .0943 |
| Max | .132 | .2263 | .2075 | .1905 | .2452 |
| Min | .1132 | .0934 | .0129 | .0943 | .0895 |
| Avg | .1226 | .1425 | .1238 | .1332 | .1331 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 203 / 11 KV UMARI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0972 | .0829 | .0848 | .0762 |
| 2 | | .0972 | .0655 | .0709 | .0781 |
| 3 | | .0972 | .0671 | .0701 | .0857 |
| 4 | | .0983 | .0671 | .0867 | .0905 |
| 5 | | .104 | .0663 | .0857 | .0886 |
| 6 | | .1052 | .1097 | .1029 | .104 |
| 7 | | .0995 | .0886 | .0995 | .1227 |
| 8 | | .1006 | .1134 | .1086 | .0972 |
| 9 | | .1326 | .0819 | .0983 | .1029 |
| 10 | | .1067 | .1029 | .1147 | .1357 |
| 11 | | .1341 | .1174 | .1017 | .1158 |
| 12 | | .1134 | .0678 | .0972 | .0625 |
| 13 | | .0781 | .1017 | .1147 | .1017 |
| 14 | | .0983 | .0102 | .1147 | |
| 15 | | .0648 | .112 | .0983 | .1187 |
| 16 | | .0819 | .0819 | .1134 | .1147 |
| 17 | | .0693 | .0838 | .1017 | .144 |
| 18 | | .1698 | .2054 | .1307 | .2241 |
| 19 | | .1867 | .1886 | .2218 | .2054 |
| 20 | | .168 | .1646 | .1629 | .168 |
| 21 | | .1214 | .1052 | .1214 | .112 |
| 22 | .0972 | .081 | .081 | .0791 | .0838 |
| 23 | .0972 | .0819 | .0772 | .0762 | .0671 |
| 24 | | .0791 | .0791 | .061 | .0753 |
| Max | .0972 | .1867 | .2054 | .2218 | .2241 |
| Min | .0972 | .0648 | .0102 | .061 | .0625 |
| Avg | .0972 | .1069 | .0967 | .1049 | .1119 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 204 / 11 KV ASHTA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1698 | .1389 | .1612 | .1635 |
| 2 | | .1718 | .1235 | .1296 | .1614 |
| 3 | | .1898 | .0914 | .125 | .2 |
| 4 | | .192 | .0914 | .1326 | .2134 |
| 5 | | .192 | .1389 | .1475 | .1718 |
| 6 | | .208 | .1619 | .1619 | .192 |
| 7 | | .176 | .1718 | .176 | .2012 |
| 8 | | .2241 | .2469 | .216 | .2429 |
| 9 | | .3479 | .2675 | .2623 | .2753 |
| 10 | | .3241 | .208 | .0253 | .2469 |
| 11 | | .3395 | .2439 | .2408 | .2656 |
| 12 | | .3906 | .3462 | .3593 | .3549 |
| 13 | | .5601 | .4115 | .4012 | .4428 |
| 14 | | .463 | .4268 | .4012 | |
| 15 | | .4687 | .4365 | .3658 | .3953 |
| 16 | | .4012 | .3913 | .3506 | .4321 |
| 17 | | .2743 | .3161 | .2623 | .3395 |
| 18 | | .2835 | .2835 | .2835 | .3366 |
| 19 | | | .2829 | .2587 | .3403 |
| 20 | | | .2454 | .2254 | .2785 |
| 21 | | | .1823 | .1619 | .2279 |
| 22 | .1635 | .1524 | .1562 | .1492 | .1677 |
| 23 | .1635 | .1475 | .1619 | .1619 | .1698 |
| 24 | | .1656 | .0134 | .1337 | .1593 |
| Max | .1635 | .5601 | .4365 | .4012 | .4428 |
| Min | .1635 | .1475 | .0134 | .0253 | .1593 |
| Avg | .1635 | .2782 | .2308 | .2205 | .2599 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 205 / 11kV CHINTALDHABA FEEDER.

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .096 | .0686 | .0886 | .0781 |
| 2 | | .1006 | .0678 | .0867 | .0848 |
| 3 | | .1017 | .0648 | .0716 | .081 |
| 4 | | .1006 | .061 | .0724 | .0857 |
| 5 | | .1017 | .0655 | .0857 | .0838 |
| 6 | | .1017 | .0905 | .12 | .0867 |
| 7 | | .1134 | .0848 | .0995 | .0838 |
| 8 | | .1265 | .0066 | .125 | .1423 |
| 9 | | .1423 | .0509 | .1406 | .1562 |
| 10 | | .128 | .0655 | .1475 | .144 |
| 11 | | .16 | .064 | .16 | .144 |
| 12 | | .1296 | .1562 | .2031 | .1875 |
| 13 | | .0412 | .2372 | .2812 | .2778 |
| 14 | | .2006 | .2372 | .1372 | |
| 15 | | .2458 | .2315 | .2031 | .1423 |
| 16 | | .2315 | .1806 | .1932 | .2778 |
| 17 | | .1107 | .1957 | .2006 | .1907 |
| 18 | | .1646 | .181 | .2033 | .2103 |
| 19 | | .1646 | .1991 | .2149 | .1829 |
| 20 | | .1448 | .1791 | .1612 | .1433 |
| 21 | | .1097 | .1372 | .1214 | .12 |
| 22 | .08 | .0328 | .1075 | .0972 | .0914 |
| 23 | .0937 | .0671 | .0937 | .1006 | .0914 |
| 24 | | .0926 | .0633 | .0772 | .0781 |
| Max | .0937 | .2458 | .2372 | .2812 | .2778 |
| Min | .08 | .0328 | .0066 | .0716 | .0781 |
| Avg | .0869 | .1253 | .1204 | .1413 | .1376 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

POMBHURNA S/DN.[833] BU 4833

Substation No/ Name :- 084014 / 33 KV POMBHURNA

Feeder No / Name : 206 / 11 KV DONGARHALDI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0286 | .032 | .0034 | .0324 |
| 2 | | .0301 | .032 | .0343 | .0332 |
| 3 | | .0301 | .0158 | .0351 | .0328 |
| 4 | | .0305 | .016 | .0351 | .0343 |
| 5 | | .032 | .016 | .0362 | .0347 |
| 6 | | .0335 | .0347 | .037 | .0351 |
| 7 | | .0332 | .0328 | .0366 | .0503 |
| 8 | | .0316 | .016 | .0486 | .0486 |
| 9 | | .016 | .0332 | .0324 | .0474 |
| 10 | | .017 | .0309 | .0324 | .0474 |
| 11 | | .0339 | .0351 | .0328 | .0469 |
| 12 | | .0339 | .0034 | .0492 | .0305 |
| 13 | | .0648 | .016 | .0937 | .0753 |
| 14 | | .064 | .032 | .0937 | |
| 15 | | .0312 | .0709 | .0602 | .0452 |
| 16 | | .0297 | .0305 | .0762 | .0469 |
| 17 | | .0316 | .0452 | .048 | .0474 |
| 18 | | .0754 | .0701 | .0732 | .0754 |
| 19 | | .0747 | .0886 | .0934 | .0754 |
| 20 | | .0554 | .0739 | .0747 | .056 |
| 21 | | .0354 | .0526 | .0537 | .0347 |
| 22 | .0312 | .0328 | .0343 | .0335 | .0332 |
| 23 | .0297 | .0166 | .0312 | .0358 | .0305 |
| 24 | | .0286 | .0164 | .0309 | .032 |
| Max | .0312 | .0754 | .0886 | .0937 | .0754 |
| Min | .0297 | .016 | .0034 | .0034 | .0305 |
| Avg | .0305 | .0371 | .0358 | .0492 | .0446 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 201 / 11 KV RAJURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6554 | .6783 | .6173 | .6036 | .5121 |
| 2 | .5898 | .6859 | .6104 | .5304 | .5182 |
| 3 | .583 | .6173 | .6104 | .5365 | .5365 |
| 4 | .6935 | .6241 | .6241 | .5426 | .5304 |
| 5 | .7712 | .6935 | .6935 | .6173 | .6173 |
| 6 | .8413 | .8413 | .7011 | .7011 | .631 |
| 7 | .9214 | .9214 | .8596 | .8322 | .9313 |
| 8 | .9816 | .9214 | .9114 | .8505 | .9313 |
| 9 | .9709 | .9709 | .9922 | .8505 | .9214 |
| 10 | .9709 | .9709 | .8322 | .9214 | .9214 |
| 11 | .9496 | .9536 | .8322 | .9015 | .8916 |
| 12 | .8817 | .8322 | .8139 | .8139 | .8322 |
| 13 | .8139 | .8139 | .7377 | .7461 | .7545 |
| 14 | .7377 | .7377 | .7293 | .6706 | .6706 |
| 15 | .8817 | .7461 | .7293 | .7377 | .6783 |
| 16 | | .8048 | .8322 | .7377 | .6554 |
| 17 | | .9175 | .852 | .7956 | .852 |
| 18 | | 1.3321 | .8421 | 1.1218 | 1.2483 |
| 19 | | 1.2894 | .9831 | 1.1462 | 1.166 |
| 20 | | 1.1462 | 1.1462 | 1.0745 | 1.134 |
| 21 | | .9114 | 1.0136 | 1.0029 | .9214 |
| 22 | | .8413 | .7628 | .7628 | .7712 |
| 23 | | .6783 | .631 | .6783 | .6104 |
| 24 | .6554 | .6783 | .6036 | .5304 | .5243 |
| Max | .9816 | 1.3321 | 1.1462 | 1.1462 | 1.2483 |
| Min | .583 | .6173 | .6036 | .5304 | .5121 |
| Avg | .8062 | .8587 | .7901 | .7794 | .7817 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 202 / 11 KV DHPOTALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.5432 | 1.4632 | 1.2643 | 1.4022 | 1.3413 |
| 2 | 1.5432 | 1.4815 | 1.2803 | 1.4198 | 1.2643 |
| 3 | 1.5432 | 1.4022 | 1.3123 | 1.358 | 1.2963 |
| 4 | 1.6248 | 1.4723 | 1.3123 | 1.4243 | 1.2803 |
| 5 | 1.6248 | 1.4998 | 1.358 | 1.4083 | 1.358 |
| 6 | 1.6248 | 1.4998 | 1.4198 | 1.4548 | 1.4198 |
| 7 | 1.7284 | 1.6872 | 1.4548 | 1.6004 | 1.5623 |
| 8 | 1.9204 | 1.9845 | 1.6446 | 1.7924 | 1.6446 |
| 9 | 2.1376 | 1.8564 | 1.7078 | 1.8564 | |
| 10 | 2.1376 | 1.7924 | 1.8343 | 1.8564 | |
| 11 | 2.2024 | 1.8343 | 1.8122 | 1.8785 | |
| 12 | 1.8976 | 2.1125 | 1.9608 | 1.8122 | |
| 13 | 2.2672 | 2.1765 | .3749 | 2.1506 | |
| 14 | 2.332 | 2.0485 | 2.1506 | 2.1765 | |
| 15 | 2.2672 | 2.1125 | 2.0873 | 2.1445 | |
| 16 | | 1.8747 | 2.0241 | 2.0241 | 1.8343 |
| 17 | | 1.8747 | 2.1125 | 1.8747 | 1.8343 |
| 18 | | 1.8351 | 2.0729 | 1.8138 | |
| 19 | | 1.7901 | 1.8785 | 1.8351 | 1.2597 |
| 20 | | 1.6194 | 1.7695 | 1.8138 | 1.3923 |
| 21 | | 1.5181 | 1.6194 | 1.6004 | 1.3603 |
| 22 | | 1.4198 | 1.4198 | 1.4198 | 1.1873 |
| 23 | | 1.3413 | 1.4198 | 1.3245 | 1.0364 |
| 24 | 1.5432 | 1.4632 | 1.2643 | 1.4022 | 1.3245 |
| Max | 2.332 | 2.1765 | 2.1506 | 2.1765 | 1.8343 |
| Min | 1.5432 | 1.3413 | .3749 | 1.3245 | 1.0364 |
| Avg | 1.8711 | 1.715 | 1.6065 | 1.7018 | 1.3998 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 203 / 11 KV GADCHANDUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2435 | | | .1972 |
| 2 | .23 | | | .1684 |
| 3 | .2332 | | | .1486 |
| 4 | .2134 | | | .1486 |
| 5 | .2134 | | | .1659 |
| 6 | .1972 | | | .1635 |
| 7 | .2195 | | .2143 | |
| 8 | .3185 | .2782 | .1974 | |
| 9 | .3715 | .3144 | .1974 | |
| 10 | .3715 | .3374 | .2256 | |
| 11 | .3864 | .3475 | .2397 | |
| 12 | .4515 | .3668 | .2679 | |
| 13 | .3506 | .3269 | .0503 | |
| 14 | .3048 | .3814 | .2715 | |
| 15 | .3506 | .333 | .3041 | |
| 21 | | | .2058 | |
| 22 | | | .1972 | |
| 23 | | | .1943 | |
| 24 | .2435 | | | .1943 |
| Max | .4515 | .3814 | .3041 | .1972 |
| Min | .1972 | .2782 | .0503 | .1486 |
| Avg | .2937 | .3357 | .2138 | .1695 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 204 / 11 KV SASTI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7628 | .7926 | .5944 | .6485 | .6287 |
| 2 | .6935 | .7811 | .6097 | .6287 | .6371 |
| 3 | .6935 | .7716 | .5792 | .6001 | .5761 |
| 4 | .7362 | .7316 | .5556 | .6161 | .6001 |
| 5 | .7362 | .7099 | .5487 | .6455 | .6455 |
| 6 | .7362 | .7499 | .5487 | .6539 | .7621 |
| 7 | .7442 | .8539 | | .7316 | .7716 |
| 8 | .9259 | .9602 | .8855 | .9465 | .8539 |
| 9 | .9259 | .9602 | .8962 | .823 | .8855 |
| 10 | .9259 | .9602 | .8855 | .7625 | .9488 |
| 11 | .9259 | .9804 | | .7407 | .9686 |
| 12 | .9709 | 1.0883 | .9686 | .9374 | 1.0437 |
| 13 | 1.0631 | 1.1203 | 1.1523 | 1.0753 | 1.1203 |
| 14 | 1.0631 | 1.1523 | 1.1523 | 1.1203 | 1.012 |
| 15 | 1.0974 | 1.1523 | 1.1385 | 1.0437 | 1.1336 |
| 16 | | 1.1069 | 1.0185 | 1.0311 | 1.0437 |
| 17 | | 1.0623 | 1.0185 | 1.0753 | 1.1069 |
| 18 | | 1.0277 | .9877 | .9717 | 1.0486 |
| 19 | | 1.0608 | .9602 | 1.0277 | 1.1065 |
| 20 | | 1.0159 | .9503 | .9393 | .9717 |
| 21 | | .8436 | .8322 | .8124 | .9172 |
| 22 | | .6836 | .7133 | .7133 | .9114 |
| 23 | | .5944 | .695 | .6573 | .7628 |
| 24 | .7888 | .7926 | .5868 | .6573 | .6203 |
| Max | 1.0974 | 1.1523 | 1.1523 | 1.1203 | 1.1336 |
| Min | .6935 | .5944 | .5487 | .6001 | .5761 |
| Avg | .8618 | .9147 | .8308 | .8275 | .8782 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 205 / 11 KV LAKADKOT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8589 | | .7762 | .5281 | .7922 | .7468 |
| 2 | .8589 | | .7842 | .4904 | .7842 | .7545 |
| 3 | .8215 | | .7842 | .4904 | .7468 | .7167 |
| 4 | .8215 | | .7922 | .5281 | .7545 | .7095 |
| 5 | .9054 | | .8299 | .5658 | .7842 | .7842 |
| 6 | .9054 | | .8676 | .6413 | .9054 | .8676 |
| 7 | .9808 | | .9431 | .6516 | .9054 | .9054 |
| 8 | 1.1203 | | .8954 | .8501 | .6161 | .9313 |
| 9 | .9774 | | .9412 | .7468 | .7316 | .9816 |
| 10 | .9774 | | .9412 | .905 | .8954 | .9816 |
| 11 | 1.0029 | | .9412 | .8505 | .8413 | .9568 |
| 12 | .8596 | | 1.0387 | 1.0277 | .9568 | .9568 |
| 13 | 1.0745 | | 1.0985 | 1.0277 | .8322 | .9922 |
| 14 | .7442 | | 1.0277 | .9465 | .9465 | .9816 |
| 15 | 1.0631 | | .9922 | .9922 | 1.0517 | .9568 |
| 16 | | .6379 | .6379 | 1.0517 | 1.0631 | .9465 |
| 17 | | | | 1.0029 | 1.0277 | .815 |
| 18 | | 1.0719 | .7023 | 1.0136 | 1.0719 | 1.0402 |
| 19 | | | 1.1203 | 1.1088 | 1.1576 | 1.1203 |
| 20 | | | .9054 | 1.1576 | 1.094 | 1.0456 |
| 21 | | | .9054 | 1.0456 | .9808 | 1.0082 |
| 22 | | | .6413 | .8962 | .7922 | .8299 |
| 23 | | 1.1203 | .6036 | .8589 | .7922 | .7922 |
| 24 | .8962 | | .7762 | .5281 | .7842 | .7468 |
| Max | 1.1203 | 1.1203 | 1.1203 | 1.1576 | 1.1576 | 1.1203 |
| Min | .7442 | .6379 | .6036 | .4904 | .6161 | .7095 |
| Avg | .9293 | .9434 | .8672 | .8294 | .8878 | .8987 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328] BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 206 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8299 | .6036 | .811 | .8299 | .5281 |
| 2 | .7545 | .5658 | .7922 | .8488 | .4715 |
| 3 | .7545 | .5847 | .7545 | .811 | .3961 |
| 4 | .679 | .5847 | .7733 | .811 | .3584 |
| 5 | .679 | .6036 | .7922 | .8299 | .3772 |
| 6 | .4251 | .6602 | .8488 | .8488 | .3395 |
| 7 | .3174 | .5281 | .5281 | .7356 | .3206 |
| 8 | .3395 | .4904 | .5658 | .5658 | .4527 |
| 9 | .3772 | .679 | .7167 | .6224 | .5658 |
| 10 | .3961 | .7356 | .679 | .6626 | .7167 |
| 11 | .3206 | .6602 | .4904 | .811 | .6602 |
| 12 | .5281 | .6979 | .7167 | .6224 | .6224 |
| 13 | | .6602 | .6602 | .4338 | .6224 |
| 14 | .5093 | .6224 | .6036 | .679 | .4904 |
| 15 | .5658 | .4527 | .6224 | .6979 | .679 |
| 16 | | .6036 | .6036 | .6979 | .6602 |
| 17 | | .6036 | .6413 | .6602 | .6979 |
| 18 | | .7922 | .6224 | .7356 | .6602 |
| 19 | | .6602 | .6413 | .7356 | .7167 |
| 20 | | .811 | .6413 | .6535 | .8676 |
| 21 | | .8299 | .7922 | .9431 | .8865 |
| 22 | | .8299 | .8676 | .8676 | .8299 |
| 23 | | .6036 | .8299 | .6413 | .8488 |
| 24 | | .6036 | .811 | .8299 | .7167 |
| Max | .8299 | .8299 | .8676 | .9431 | .8865 |
| Min | .3174 | .4527 | .4904 | .4338 | .3206 |
| Avg | .534 | .6444 | .7002 | .7323 | .6036 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084003 / 33 KV RAJURA

Feeder No / Name : 207 / 11 KV SHIVAJI NAGAR

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4409 | .4744 | .3887 | .4062 | .4012 |
| 2 | .4409 | .4801 | .4359 | .4012 | .3963 |
| 3 | .4801 | .4481 | .3841 | .3704 | .3658 |
| 4 | .4801 | .4588 | .3749 | .3795 | .3749 |
| 5 | .5087 | .4973 | .421 | .421 | .4161 |
| 6 | .5426 | .5765 | .503 | .4694 | .503 |
| 7 | .5487 | .6516 | .5967 | .5487 | .5765 |
| 8 | .5426 | .6706 | .5365 | .5365 | .5426 |
| 9 | .5765 | .5967 | .57 | .5571 | .5426 |
| 10 | .5898 | .5967 | .5571 | .5506 | .5426 |
| 11 | .583 | .5571 | .5506 | .5441 | .5243 |
| 12 | .5761 | .4534 | .5441 | .506 | .4588 |
| 13 | .5693 | .5121 | .5312 | .4938 | .4374 |
| 14 | .5376 | .506 | .5247 | 1.0311 | .4515 |
| 15 | .5693 | .506 | .4877 | .4062 | .4572 |
| 16 | | .5312 | .4572 | .4515 | .4401 |
| 17 | | .5247 | .4938 | .4938 | .4515 |
| 18 | | .7975 | .5312 | .6588 | .6859 |
| 19 | | .7796 | .6588 | .7164 | .7011 |
| 20 | | .7087 | .7087 | .7164 | .6661 |
| 21 | | .5312 | .6588 | .631 | .5609 |
| 22 | | .4748 | .4641 | .503 | .4359 |
| 23 | | .426 | .4588 | .4481 | .3658 |
| 24 | .421 | .4744 | .3841 | .4012 | .4012 |
| Max | .5898 | .7975 | .7087 | 1.0311 | .7011 |
| Min | .421 | .426 | .3749 | .3704 | .3658 |
| Avg | .5255 | .5514 | .5092 | .5268 | .4875 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328] BU 4328

Substation No/ Name :- 084015 / 33 KV WIRUR

Feeder No / Name : 201 / 11 KV WIRUR

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .5573 | .6226 |
| 2 | | | .5573 | .6226 |
| 3 | | | .3715 | .6226 |
| 4 | | | .5573 | .6226 |
| 5 | | | .5573 | .6226 |
| 6 | | | .5573 | .6371 |
| 8 | .8078 | .6335 | | |
| 9 | .8951 | .6733 | | |
| 10 | .9259 | .7011 | | |
| 11 | .9105 | .5407 | | |
| 12 | .9842 | .6274 | | |
| 13 | .9259 | .6796 | | |
| 14 | 1.0936 | .5304 | | |
| 15 | 1.0155 | .4973 | | |
| 16 | | .4915 | | |
| 21 | | .1036 | .5944 | .5075 |
| 22 | | .5573 | .5792 | .5573 |
| 23 | | .5573 | .6226 | .5716 |
| 24 | | | .5716 | .6226 |
| Max | 1.0936 | .7011 | .6226 | .6371 |
| Min | .8078 | .1036 | .3715 | .5075 |
| Avg | .9448 | .5494 | .5526 | .6009 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084015 / 33 KV WIRUR

Feeder No / Name : 203 / 11 KV TEMBHURWAHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .12 | .1509 | .1715 | .1406 |
| 2 | | .12 | .1509 | .1715 | .1406 |
| 3 | | .12 | .1509 | .1715 | .1406 |
| 4 | | .12 | .1341 | .1715 | .1406 |
| 5 | | .1227 | .1357 | .1715 | .1406 |
| 6 | | .1578 | .1187 | .2058 | .1696 |
| 7 | | .1402 | .1526 | .2058 | .1844 |
| 8 | | .1658 | .295 | .2012 | .1781 |
| 9 | | .2561 | .2591 | .25 | .2267 |
| 10 | | .2968 | .2753 | .2591 | .2591 |
| 11 | | .3401 | .2652 | .25 | .1658 |
| 12 | | .2949 | .2984 | .3353 | .2656 |
| 13 | | .2984 | .3163 | .3521 | .3441 |
| 14 | | .2785 | .2378 | .3041 | .3521 |
| 15 | | .2656 | .2107 | .2812 | .3277 |
| 16 | | .2688 | .2258 | .2241 | .2812 |
| 17 | | .2591 | .2343 | .2915 | .3239 |
| 18 | | .2204 | .2915 | .2883 | .2926 |
| 19 | | .2658 | .2601 | .3403 | .3258 |
| 20 | | .2303 | .2254 | .2865 | .3224 |
| 21 | | .1865 | .1907 | .2427 | .1753 |
| 22 | .1372 | .1619 | .1715 | .1802 | .1372 |
| 23 | .1187 | .1715 | .1677 | .144 | .1174 |
| 24 | | .1187 | .1543 | .1658 | .1406 |
| Max | .1372 | .3401 | .3163 | .3521 | .3521 |
| Min | .1187 | .1187 | .1187 | .144 | .1174 |
| Avg | .1280 | .2075 | .2114 | .2361 | .2205 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084015 / 33 KV WIRUR

Feeder No / Name : 204 / Gavathan feeder VIRUR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2587 | .2241 | .2587 | .2427 |
| 2 | | | .2241 | .2587 | .2427 |
| 3 | | .2614 | .2241 | .2587 | .2427 |
| 4 | | .2614 | .1867 | .2587 | .2427 |
| 5 | | .2987 | .1886 | .2587 | .2427 |
| 6 | | .3361 | .3018 | .2957 | .3584 |
| 7 | | .3734 | .3772 | .4066 | .4108 |
| 8 | | .3292 | .1341 | .439 | .4435 |
| 9 | | .4207 | .2591 | .4024 | .4344 |
| 10 | | .3475 | .2721 | .394 | .3658 |
| 11 | | .3801 | .2622 | .3366 | .2507 |
| 12 | | .3544 | .2743 | .2835 | .2835 |
| 13 | | .3258 | .3163 | .2658 | .2774 |
| 14 | | .2865 | .2347 | .2481 | .2454 |
| 15 | | .2865 | .2134 | .2279 | |
| 16 | | .3641 | .2286 | .181 | .2454 |
| 17 | | .3544 | .3224 | .2454 | .2454 |
| 18 | | .4854 | .4572 | .5175 | .4755 |
| 19 | | .5281 | .5544 | .5658 | .5281 |
| 20 | | .4527 | .499 | .4904 | .4854 |
| 21 | | .3772 | .3696 | .4715 | .3086 |
| 22 | .2987 | .2987 | .2772 | .3584 | .2641 |
| 23 | .2957 | .2614 | .2772 | .2801 | .2241 |
| 24 | | .2587 | .2241 | .2587 | .2427 |
| Max | .2987 | .5281 | .5544 | .5658 | .5281 |
| Min | .2957 | .2587 | .1341 | .181 | .2241 |
| Avg | .2972 | .3435 | .2876 | .3317 | .3175 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084054 / 33 KV VIHIRGAON SUBSTATION

Feeder No / Name : 201 / CHANAKA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .5487 | |
| 2 | | | | .5702 | |
| 3 | | | | .5858 | |
| 4 | | | | .5563 | |
| 5 | | | | .5335 | |
| 6 | | | | .5275 | |
| 8 | | .7649 | | | |
| 9 | | .9122 | | | |
| 10 | | .9122 | | | |
| 11 | | .8288 | | | .1943 |
| 12 | | .9846 | | | .2401 |
| 13 | 1.1288 | .9875 | | | .2366 |
| 14 | 1.0997 | .9457 | | | .3368 |
| 15 | 1.0562 | .9288 | | | .6815 |
| 16 | | | | | .6676 |
| 17 | | | | | .6584 |
| 21 | | | .4668 | .4733 | .4146 |
| 22 | | | .5411 | .5487 | .4016 |
| 23 | | | .5716 | | .4075 |
| 24 | | | .5487 | | |
| Max | 1.1288 | .9875 | .5716 | .5858 | .6815 |
| Min | 1.0562 | .7649 | .4668 | .4733 | .1943 |
| Avg | 1.0949 | .9081 | .5321 | .543 | .4239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084054 / 33 KV VIHIRGAON SUBSTATION

Feeder No / Name : 202 / 11 K V KOHAPARA GAWATHAN

GAOTHAN FEEDER

FEEDE Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1867 | .2075 | .1886 | .1698 |
| 2 | | .1867 | .2054 | .1886 | .1698 |
| 3 | | .1886 | .1867 | .168 | .2054 |
| 4 | | .1886 | | .2241 | .2241 |
| 5 | | .1886 | | .2587 | .2218 |
| 6 | | .2587 | | .2743 | .2378 |
| 7 | | .2772 | | .2772 | .2328 |
| 8 | | .2896 | .2033 | .2561 | .2896 |
| 9 | | .3224 | .2926 | .2686 | .3292 |
| 10 | | .3012 | .2772 | .2303 | .2743 |
| 11 | | .2401 | .2321 | .2126 | .2353 |
| 12 | | .2658 | | .2353 | .2279 |
| 13 | .1886 | .2601 | .2804 | .2303 | .2229 |
| 14 | .2572 | .3174 | .2915 | .2279 | .1696 |
| 15 | .285 | .2715 | .2401 | .2254 | .0686 |
| 16 | .2622 | .3475 | .2835 | .2454 | .1475 |
| 17 | .3052 | .2896 | .3045 | .2401 | .12 |
| 18 | .4344 | .439 | .3658 | .3658 | .3326 |
| 19 | .4572 | .4854 | .4108 | .3921 | .3734 |
| 20 | .3547 | .3584 | .3772 | .3395 | .3772 |
| 21 | .3018 | .2641 | .3018 | .2801 | .2641 |
| 22 | .2641 | .2054 | .1867 | .2075 | .2641 |
| 23 | .2054 | .2054 | .1829 | .1886 | .2054 |
| 24 | | .2054 | .1886 | .168 | |
| Max | .4572 | .4854 | .4108 | .3921 | .3772 |
| Min | .1886 | .1867 | .1829 | .168 | .0686 |
| Avg | .3014 | .2726 | .2641 | .2455 | .2332 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

BALLARSHAH DIVISION[648]

RAJURA S/DN.[328]

BU 4328

Substation No/ Name :- 084054 / 33 KV VIHIRGAON SUBSTATION

Feeder No / Name : 203 / 11 KV MURTI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | | .2 | .3018 |
| 2 | | | | .2 | .2934 |
| 3 | | | | .2086 | .2841 |
| 4 | | | | .2 | .2976 |
| 5 | | | | .1947 | .2921 |
| 6 | | | | .192 | .2881 |
| 8 | | .4089 | | | |
| 9 | | .4715 | | | |
| 10 | | .5001 | | | |
| 11 | | .4793 | | | |
| 12 | | .5213 | | | |
| 13 | .5944 | .5502 | | | |
| 14 | .5201 | .5563 | | | |
| 15 | .5053 | .4729 | | | |
| 21 | | | .2267 | .2366 | .2572 |
| 22 | | | .2058 | .2976 | .2503 |
| 23 | | | .2058 | .3185 | .2538 |
| 24 | | | .2086 | .3269 | |
| Max | .5944 | .5563 | .2267 | .3269 | .3018 |
| Min | .5053 | .4089 | .2058 | .192 | .2503 |
| Avg | .5399 | .4951 | .2117 | .2375 | .2798 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 201 / 11 KV MAHAKALI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4706 | .439 | .4572 | .4525 |
| 2 | .4525 | .4572 | .4572 | .4344 |
| 3 | .4887 | .4207 | .4024 | .3801 |
| 4 | .5068 | .3841 | .3801 | .3801 |
| 5 | .4525 | .4525 | .4706 | .4344 |
| 6 | .4755 | .4755 | .4207 | .4525 |
| 7 | .6401 | .5611 | .5853 | .543 |
| 8 | .6036 | .5487 | .5304 | .5304 |
| 9 | .6584 | .6401 | .567 | .6401 |
| 10 | .7421 | .7316 | .6447 | .7602 |
| 11 | .7499 | .1867 | .6984 | .7602 |
| 12 | .7682 | .1848 | .7343 | .7602 |
| 13 | .7682 | .9145 | .6626 | .7682 |
| 14 | .724 | .7682 | .6447 | .6516 |
| 15 | .6697 | .7133 | .6089 | .7059 |
| 16 | .724 | .7499 | .5731 | .7421 |
| 17 | .6805 | .7316 | .6626 | .7522 |
| 18 | .9313 | 1.1157 | .8954 | 1.0029 |
| 19 | .9313 | 1.0679 | .8954 | 1.0387 |
| 20 | .8596 | 1.0059 | .8596 | .9671 |
| 21 | .788 | .8688 | .8059 | .8688 |
| 22 | .5973 | .6878 | | .6767 |
| 23 | .543 | .543 | .5304 | .5373 |
| 24 | .4887 | .4887 | .439 | .4344 |
| Max | .9313 | 1.1157 | .8954 | 1.0387 |
| Min | .4525 | .1848 | .3801 | .3801 |
| Avg | .6548 | .6307 | .6055 | .6531 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 202 / 11 KV VIKASNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7973 | .6626 | .6089 | .691 |
| 2 | .7973 | .6984 | .6268 | .6024 |
| 3 | .7442 | .6984 | .6089 | .5847 |
| 4 | .7265 | .7164 | .567 | .6379 |
| 5 | .7619 | .7522 | .6024 | .6201 |
| 6 | .8328 | .7973 | .6379 | .7796 |
| 7 | .8775 | .8596 | .8417 | .8328 |
| 8 | .8059 | .7701 | .788 | .8059 |
| 9 | .8775 | .8596 | .8059 | .8417 |
| 10 | .8775 | .7973 | .8417 | .8505 |
| 11 | .8238 | .8238 | .8238 | .8413 |
| 12 | .7619 | .7265 | .7701 | .7442 |
| 13 | .7108 | .6268 | .6626 | .6661 |
| 14 | .6485 | .567 | .591 | .5609 |
| 15 | .631 | .6201 | .591 | .5784 |
| 16 | .7362 | .6733 | .5731 | .6556 |
| 17 | .6984 | .7164 | .6447 | .7455 |
| 18 | 1.0745 | 1.0808 | .9671 | 1.0692 |
| 19 | 1.1104 | 1.1163 | 1.0387 | 1.1517 |
| 20 | 1.0745 | 1.0631 | 1.0924 | 1.0808 |
| 21 | 1.0387 | .9922 | .9671 | .9922 |
| 22 | .8589 | .8413 | .8596 | .8328 |
| 23 | .7537 | .7011 | .7701 | .6984 |
| 24 | .815 | .6733 | .6447 | .691 |
| Max | 1.1104 | 1.1163 | 1.0924 | 1.1517 |
| Min | .631 | .567 | .567 | .5609 |
| Avg | .8264 | .7847 | .7469 | .7731 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 203 / 11 KV PATHANPURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2105 | .218 | .2204 | .2035 |
| 2 | .2105 | .2012 | .2035 | .2204 |
| 3 | .2105 | .2012 | .1696 | .1865 |
| 4 | .2105 | .2058 | .1543 | .1865 |
| 5 | .1943 | .2229 | .2058 | .2058 |
| 6 | .2614 | .2374 | .2401 | .2374 |
| 7 | .2883 | .2743 | .2915 | .2743 |
| 8 | .3086 | .2402 | .2401 | .2915 |
| 9 | .3121 | .3086 | .2915 | .3086 |
| 10 | .8097 | .2785 | .3045 | .3201 |
| 11 | .8421 | .2486 | .3224 | .2721 |
| 12 | .78 | .2429 | .2328 | .2267 |
| 13 | .7209 | .213 | .2328 | .2294 |
| 14 | .6874 | .213 | .2149 | .1966 |
| 15 | .6554 | .192 | .2149 | .1898 |
| 16 | .6642 | .208 | .2149 | .2105 |
| 17 | .2149 | .2267 | .2507 | .2486 |
| 18 | .3582 | .2591 | .2865 | .3052 |
| 19 | .3582 | .3077 | .3045 | .2949 |
| 20 | .3403 | .3391 | .3045 | .2949 |
| 21 | .3403 | .3149 | .3224 | .3018 |
| 22 | .2818 | .2818 | .2713 | .2622 |
| 23 | .2486 | .2321 | .2515 | .2686 |
| 24 | .2105 | .2374 | .2035 | .2035 |
| Max | .8421 | .3391 | .3224 | .3201 |
| Min | .1943 | .192 | .1543 | .1865 |
| Avg | .4050 | .2460 | .2479 | .2475 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 204 / 11 KV GOPALPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3189 | .2481 | .2481 | .2507 |
| 2 | .3189 | .2572 | .2303 | .2507 |
| 3 | .3012 | .2303 | .2481 | .2507 |
| 4 | .2835 | .2658 | .2328 | .2507 |
| 5 | .3012 | .2303 | .2507 | .2507 |
| 6 | .3189 | .2686 | .2658 | .2715 |
| 7 | .3224 | .3045 | .2865 | .3077 |
| 8 | .3582 | .3224 | .3403 | .3258 |
| 9 | .3258 | .2865 | .3403 | .3258 |
| 10 | .3258 | .2896 | .3045 | .3224 |
| 11 | .3045 | .2896 | .3224 | .3045 |
| 12 | .2686 | .2686 | .2865 | .2865 |
| 13 | .2865 | .2686 | .2507 | .2507 |
| 14 | .2303 | .2481 | .2328 | .2481 |
| 15 | .2481 | .2328 | .2328 | .2507 |
| 16 | .2507 | .2481 | .2328 | .2658 |
| 17 | .2865 | .3077 | .2686 | .2984 |
| 18 | .4477 | .4298 | .3582 | .4115 |
| 19 | .4656 | .4656 | .4477 | .4607 |
| 20 | .4477 | .4298 | .4477 | .4207 |
| 21 | .4298 | .4075 | .4477 | .4031 |
| 22 | .3982 | .362 | .439 | .3544 |
| 23 | .3258 | .2896 | .3077 | .3045 |
| 24 | .3544 | .2896 | .2658 | .2715 |
| Max | .4656 | .4656 | .4477 | .4607 |
| Min | .2303 | .2303 | .2303 | .2481 |
| Avg | .3300 | .3017 | .3037 | .3057 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 205 / 11 KV GEN. HOSPITAL
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0566 | .0566 | .0566 | .0566 |
| 2 | .0377 | .0566 | .0566 | .0566 |
| 3 | .0566 | .0566 | .0566 | .0377 |
| 4 | .0566 | .0377 | .0377 | .0377 |
| 5 | .0377 | .0566 | .0754 | .0566 |
| 6 | .0566 | .0566 | .0566 | |
| 7 | .0566 | .0566 | .0566 | .0566 |
| 8 | .0566 | .0566 | .0377 | .0754 |
| 9 | .0943 | .0754 | .0566 | .0754 |
| 10 | .0943 | .0754 | .0754 | .0754 |
| 11 | .0754 | .0754 | .0754 | .0754 |
| 12 | .0943 | .0943 | .0754 | .0754 |
| 13 | .0754 | .0754 | .0754 | .0754 |
| 14 | .0754 | .0754 | .0566 | .0754 |
| 15 | .0754 | .0754 | .0566 | .0566 |
| 16 | .0754 | .0566 | .0566 | .0754 |
| 17 | .0754 | .0754 | .0754 | .0754 |
| 18 | .0754 | .0754 | .0754 | .0754 |
| 19 | .0754 | .0732 | .0566 | .0754 |
| 20 | .0754 | .0754 | .0566 | .0566 |
| 21 | .0566 | .0566 | .0566 | .0566 |
| 22 | .0566 | .0566 | .0566 | .0566 |
| 23 | .0566 | .0566 | .0754 | .0566 |
| 24 | .0566 | .0566 | .0566 | .0377 |
| Max | .0943 | .0943 | .0754 | .0754 |
| Min | .0377 | .0377 | .0377 | .0377 |
| Avg | .0668 | .0651 | .0613 | .0631 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 206 / 11 KV SAMADHI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3944 | .3601 | .3429 | .3506 |
| 2 | .3772 | .3429 | .3258 | |
| 3 | .3772 | .333 | .3429 | .3506 |
| 4 | | .3506 | .3506 | .3506 |
| 5 | .3772 | .333 | .3155 | .3506 |
| 6 | .407 | .3856 | .3856 | .4031 |
| 7 | .39 | .3856 | .3681 | .3506 |
| 8 | .4031 | .4031 | .4031 | .4031 |
| 9 | .3467 | .3814 | .3681 | .3856 |
| 10 | .3772 | .3814 | | .4115 |
| 11 | .3944 | .3641 | .3761 | .3601 |
| 12 | .3506 | .3429 | .3761 | .3086 |
| 13 | .3641 | .3258 | .3582 | .3429 |
| 14 | .3641 | .3467 | .3582 | .3294 |
| 15 | .3258 | .3258 | .3045 | .3086 |
| 16 | .3258 | .3429 | .3224 | .3258 |
| 17 | .394 | .3772 | .3224 | .3601 |
| 18 | .591 | .5721 | .4656 | .5487 |
| 19 | .591 | .583 | .5731 | .583 |
| 20 | .5731 | .5487 | .5731 | .5658 |
| 21 | .5552 | .5316 | .5552 | .5258 |
| 22 | .4961 | .4733 | .5144 | .4733 |
| 23 | .4252 | .4207 | .4458 | .3761 |
| 24 | .3944 | | .3429 | .3681 |
| Max | .591 | .583 | .5731 | .583 |
| Min | .3258 | .3258 | .3045 | .3086 |
| Avg | .4172 | .4005 | .3952 | .3971 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084008 / 33 KV BABUPETH

Feeder No / Name : 207 / 11 KV LALPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3881 | .3584 | .3361 | .3174 |
| 2 | .3881 | .3395 | .3361 | .3174 |
| 3 | .3696 | .3206 | .3361 | .2987 |
| 4 | .3511 | .3174 | .3361 | .2957 |
| 5 | .4066 | .3361 | .3142 | .3142 |
| 6 | .4668 | .3921 | .3696 | .3881 |
| 7 | .5228 | .4854 | .499 | .5041 |
| 8 | .4668 | .4481 | .4854 | .4668 |
| 9 | .5601 | .5415 | .5228 | .5228 |
| 10 | .5121 | .499 | | .5175 |
| 11 | .462 | .4066 | | .4805 |
| 12 | .4024 | .3881 | .3761 | .4435 |
| 13 | .3841 | .3881 | .3761 | .4066 |
| 14 | .3658 | .3292 | .3582 | .3696 |
| 15 | .3475 | .3292 | .3403 | .3696 |
| 16 | .3696 | .3475 | .3224 | .3511 |
| 17 | .3761 | .3841 | .3403 | .4163 |
| 18 | .591 | .5914 | .5194 | .6219 |
| 19 | .6805 | .6838 | .6626 | .695 |
| 20 | .6626 | .6838 | .6268 | .6584 |
| 21 | .591 | .6099 | .591 | .6099 |
| 22 | | .4755 | .499 | .4805 |
| 23 | .4066 | .4024 | .3881 | .394 |
| 24 | .4066 | .3547 | .3361 | .3326 |
| Max | .6805 | .6838 | .6626 | .695 |
| Min | .3475 | .3174 | .3142 | .2957 |
| Avg | .4556 | .4339 | .4214 | .4405 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 201 / 11 KV ARVAT

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3222 | .1174 | .2454 | .2658 |
| 2 | | .3353 | .116 | .0175 | .2629 |
| 3 | | .3353 | .1006 | .1227 | .2658 |
| 4 | | .3391 | .0848 | .1052 | .2658 |
| 5 | | .3561 | .1174 | .0351 | .2629 |
| 6 | | .373 | .1492 | .1402 | .2947 |
| 7 | | .4161 | .1509 | .1402 | .2835 |
| 8 | | .3561 | .2035 | .1753 | .4382 |
| 9 | | .4409 | .2515 | .1928 | .5682 |
| 10 | | .0491 | .0228 | .2347 | .5087 |
| 11 | | | .2454 | .0337 | .4409 |
| 12 | .5935 | | .0263 | .014 | .3772 |
| 13 | | | | .0351 | .3561 |
| 14 | | | .0263 | .0386 | .0686 |
| 15 | | | .1402 | .0368 | .0857 |
| 16 | | | .3681 | .5258 | .4862 |
| 17 | | .0686 | .3681 | | .5533 |
| 18 | | .0876 | .4031 | .4075 | .5493 |
| 19 | | .4075 | .4031 | .443 | .5258 |
| 20 | | .0709 | .3681 | .4075 | .3721 |
| 21 | | .1595 | .3506 | .3721 | .4207 |
| 22 | | .124 | .2804 | .3012 | .3681 |
| 23 | | .0339 | .2629 | .1949 | .2915 |
| 24 | | .3185 | .1187 | .2629 | .2915 |
| Max | .5935 | .4409 | .4031 | .5258 | .5682 |
| Min | .5935 | .0339 | .0228 | .014 | .0686 |
| Avg | .5935 | .2552 | .2033 | .1949 | .3585 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 202 / 11 KV GHUTKALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6859 | .6104 | .6024 | .4115 |
| 2 | | .6371 | .6036 | .567 | .6024 |
| 3 | | .6706 | .547 | .567 | .5847 |
| 4 | | .6443 | .5426 | .5258 | .567 |
| 5 | | .6687 | .5765 | .5548 | .5959 |
| 6 | | .6859 | .6443 | .6379 | .6733 |
| 7 | | .6859 | .6783 | .6733 | .7712 |
| 8 | | .7202 | .6783 | .6661 | .7265 |
| 9 | | .7042 | .6859 | .9214 | .815 |
| 10 | | | .0701 | .8478 | .8478 |
| 11 | .9054 | | .4419 | .1701 | .9259 |
| 12 | | | | .1453 | .9362 |
| 13 | | | | .202 | .9362 |
| 14 | | | .0886 | .1963 | .9496 |
| 15 | | | .9568 | .1753 | .6706 |
| 16 | | | 1.0631 | 1.7878 | .9835 |
| 17 | | | 1.0517 | | 1.0974 |
| 18 | | 1.4175 | 1.3466 | 1.3466 | 1.382 |
| 19 | | 1.4529 | 1.382 | 1.382 | 1.387 |
| 20 | | 1.3969 | 1.3112 | 1.3466 | 1.3466 |
| 21 | | 1.134 | 1.1694 | 1.1694 | 1.3672 |
| 22 | | .8859 | .815 | .8859 | .8505 |
| 23 | | .7545 | .6661 | .6836 | .7011 |
| 24 | | .6859 | .6516 | .5959 | .631 |
| Max | .9054 | 1.4529 | 1.382 | 1.7878 | 1.387 |
| Min | .9054 | .6371 | .0701 | .1453 | .4115 |
| Avg | .9054 | .8644 | .7537 | .7239 | .8650 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 203 / 11 KV Chandrapur GANDHI
CHOWK Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6173 | .57 | .5959 | .5609 |
| 2 | .6104 | .5658 | .5493 | .5609 |
| 3 | .5935 | .5365 | .5493 | .5493 |
| 4 | .57 | .5256 | .5316 | .5434 |
| 5 | .5935 | .5087 | .567 | .5434 |
| 6 | .6104 | .57 | .5847 | .5847 |
| 7 | .6952 | .6783 | .691 | .8063 |
| 8 | .7122 | .6687 | .6485 | .7442 |
| 9 | .7042 | .8573 | .7442 | .7087 |
| 10 | | .0876 | .788 | .788 |
| 11 | | .0736 | .0771 | .7545 |
| 12 | | .0806 | .0666 | .6443 |
| 13 | | .0567 | .0578 | .5256 |
| 14 | | .0496 | .0491 | .5087 |
| 15 | | .6401 | .0508 | .4854 |
| 16 | | .6379 | .5258 | .503 |
| 17 | | .8764 | | .5596 |
| 18 | .9745 | .9391 | .8413 | .9114 |
| 19 | 1.0277 | .9922 | .9465 | .964 |
| 20 | .9922 | .9391 | .9114 | .9114 |
| 21 | .8939 | .8859 | .8764 | .8589 |
| 22 | .7973 | .7973 | .7888 | .788 |
| 23 | .6687 | .6661 | .5784 | .6062 |
| 24 | .6443 | .6036 | .5847 | .5407 |
| Max | 1.0277 | .9922 | .9465 | .964 |
| Min | .57 | .0496 | .0491 | .4854 |
| Avg | .7316 | .5753 | .5480 | .6646 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 204 / 11KV Collery

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6344 | .5935 | .6219 | .567 |
| 2 | .6173 | .57 | .6036 | .5487 |
| 3 | .6344 | .5533 | .6219 | .5853 |
| 4 | .6443 | .6344 | .6556 | .6036 |
| 5 | .7628 | .7461 | .8048 | .7087 |
| 6 | 1.0923 | .9614 | 1.0454 | 1.0059 |
| 7 | .8987 | .8478 | .9055 | .7865 |
| 8 | .7545 | .4862 | .7316 | .6767 |
| 9 | .3429 | .2713 | .2587 | .3658 |
| 10 | .0146 | .2772 | .3601 | .3086 |
| 11 | .0702 | .0384 | .7682 | .8453 |
| 12 | .0869 | .0311 | .9145 | .7888 |
| 13 | .0758 | .053 | | .4527 |
| 14 | .0647 | .0805 | | .6173 |
| 15 | .0628 | .6653 | | .57 |
| 16 | .0721 | .7023 | | .6274 |
| 17 | .7577 | .7011 | .7922 | |
| 18 | .9979 | .9979 | .9795 | 1.0242 |
| 19 | 1.0029 | 1.0534 | 1.0349 | .9745 |
| 20 | .9328 | .9425 | .8316 | .9145 |
| 21 | .8328 | .8779 | .8131 | .8962 |
| 22 | .8048 | .7762 | .7207 | .7682 |
| 23 | .6516 | .6733 | .6653 | .7095 |
| 24 | .6203 | .5935 | .6401 | .6535 |
| Max | 1.0923 | 1.0534 | 1.0454 | 1.0242 |
| Min | .0146 | .0311 | .2587 | .3086 |
| Avg | .5596 | .5887 | .7385 | .6956 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 205 / 11KV Binba Gate

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5765 | .503 | .5493 | .4908 |
| 2 | .5533 | .4917 | .4784 | .4961 |
| 3 | .5596 | .4694 | .4784 | .443 |
| 4 | .5596 | .4527 | .4607 | .4607 |
| 5 | .57 | .4527 | .4607 | .3544 |
| 6 | .6001 | .4527 | .4784 | .4961 |
| 7 | .583 | .5144 | .5493 | .5847 |
| 8 | .5596 | .5609 | .5434 | .5493 |
| 9 | .57 | .5548 | .5731 | .5316 |
| 10 | .142 | .0549 | .5426 | .5256 |
| 11 | .1455 | .0578 | .6201 | .5548 |
| 12 | .1542 | .1385 | | .5596 |
| 13 | | .1453 | | .5487 |
| 14 | .1524 | .0532 | | .5197 |
| 15 | .1506 | .5493 | | .4694 |
| 16 | .1541 | .5493 | | .5201 |
| 17 | 1.5592 | .6135 | 2.3059 | .6068 |
| 18 | .8328 | .7973 | .7712 | .8413 |
| 19 | .8505 | .8505 | .8589 | .815 |
| 20 | .788 | .7796 | .7712 | .7265 |
| 21 | .7087 | .7619 | .7362 | |
| 22 | .6733 | .6626 | .6661 | .6556 |
| 23 | .5765 | .567 | .5784 | .5365 |
| 24 | .6068 | .5316 | .5316 | .4694 |
| Max | 1.5592 | .8505 | 2.3059 | .8413 |
| Min | .142 | .0532 | .4607 | .3544 |
| Avg | .5490 | .4819 | .6818 | .5546 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR I (U)S/DN[324] BU 2119

Substation No/ Name :- 084023 / 33 KV PATHANPURA

Feeder No / Name : 402 / 33KV VK-II outgoing

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5087 | .7956 | .7802 | .7116 |
| 2 | .9259 | .823 | .7442 | .7973 |
| 3 | .8648 | .7802 | .7442 | .7442 |
| 4 | .8648 | .7042 | .7442 | .7442 |
| 5 | .9259 | .8139 | .7973 | .7522 |
| 6 | 1.0288 | .8951 | .8842 | .9036 |
| 7 | 1.0802 | 1.0174 | 1.0099 | 1.1043 |
| 8 | 1.1065 | .9774 | 1.1043 | 1.0631 |
| 9 | 1.262 | 1.0682 | 1.1568 | 1.2226 |
| 10 | .1157 | 1.0706 | 1.1568 | 1.1443 |
| 11 | .1683 | .0999 | .0999 | 1.0517 |
| 12 | .1472 | .0947 | .0947 | .9259 |
| 13 | .1472 | .0789 | .0841 | .8939 |
| 14 | .1367 | .0789 | .0789 | .823 |
| 15 | .1315 | .7888 | | .8139 |
| 16 | .1367 | .8413 | | .8139 |
| 17 | .6836 | .8745 | | 1.0402 |
| 18 | 1.4198 | 1.286 | 1.2226 | 1.3672 |
| 19 | 1.4883 | 1.4883 | 1.4352 | 1.5043 |
| 20 | 1.4883 | 1.4883 | 1.2757 | 1.4198 |
| 21 | 1.3289 | 1.382 | 1.382 | 1.3523 |
| 22 | 1.2226 | 1.0682 | 1.1694 | 1.1568 |
| 23 | .9448 | .9465 | .8848 | .8951 |
| 24 | .9991 | .8551 | .8322 | .7682 |
| Max | 1.4883 | 1.4883 | 1.4352 | 1.5043 |
| Min | .1157 | .0789 | .0789 | .7116 |
| Avg | .7969 | .8465 | .8420 | 1.0006 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084019 / 33 KV CHICHPALLI

Feeder No / Name : 201 / 11 KV MAMLA BORDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0036 | .0037 | .0019 | .0037 |
| 2 | | | .0036 | .0037 | .0019 | .0037 |
| 3 | | | .0037 | .0037 | .0019 | .0037 |
| 4 | | | .0037 | .0037 | .0019 | .0037 |
| 5 | | | .0036 | .0037 | .0037 | .0037 |
| 6 | | | .0037 | .0037 | .0037 | .0037 |
| 7 | | | .0037 | .0037 | .0037 | .0037 |
| 8 | | | .0036 | .0037 | .0056 | .0054 |
| 9 | | | .0053 | .0056 | .0037 | .0054 |
| 10 | | | .0035 | .0056 | .0056 | .0053 |
| 11 | | | .0037 | .0056 | .005 | .0018 |
| 12 | | | .0056 | .0056 | .0033 | .0055 |
| 13 | | | .0056 | .0037 | .0034 | .0037 |
| 14 | | | .0056 | .0056 | .0049 | .0056 |
| 15 | .0037 | | .0056 | .0056 | .0032 | .0054 |
| 16 | | | .0056 | .0056 | .0032 | .0055 |
| 17 | | | .0056 | .0056 | .0051 | .0053 |
| 18 | | | .0075 | .0056 | .0053 | .0074 |
| 19 | .0056 | | .0075 | .0056 | .0074 | .0075 |
| 20 | | | .0056 | .0056 | .0055 | .0057 |
| 21 | .0037 | | .0056 | .0056 | .0055 | .0057 |
| 22 | .0037 | | .0037 | .0037 | .0037 | .0037 |
| 23 | | .0037 | .0037 | .0037 | .0037 | .0038 |
| 24 | | | .0037 | .0037 | | .0037 |
| Max | .0056 | .0037 | .0075 | .0056 | .0074 | .0075 |
| Min | .0037 | .0037 | .0035 | .0037 | .0019 | .0018 |
| Avg | .0042 | .0037 | .0047 | .0047 | .0040 | .0047 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084019 / 33 KV CHICHPALLI

Feeder No / Name : 202 / 11 KV CHICHPALLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0074 | .0075 | .0075 | .0056 |
| 2 | | .007 | .0075 | .0075 | .0056 |
| 3 | | .0069 | .0075 | .0075 | .0056 |
| 4 | | .0067 | .0075 | .0075 | .0056 |
| 5 | | .0067 | .0075 | .0075 | .0075 |
| 6 | | .0084 | .0093 | .0075 | .0073 |
| 7 | | .0102 | .0093 | .0093 | .0072 |
| 8 | | .0103 | .0093 | .0112 | .0107 |
| 9 | | .0117 | .0112 | .0131 | .0113 |
| 10 | | .0119 | .0112 | .0112 | .0149 |
| 11 | | .0131 | .0112 | .0116 | .0037 |
| 12 | | .0149 | .0131 | .0116 | .0124 |
| 13 | | .0149 | .0149 | .0116 | .0163 |
| 14 | | .0149 | .0131 | .0113 | .014 |
| 15 | | .0168 | .0131 | .0112 | .014 |
| 16 | | .0168 | .0149 | .0131 | .0123 |
| 17 | | .0131 | .0131 | .0113 | .0142 |
| 18 | | .0168 | .0149 | | .0168 |
| 19 | | .0168 | .0168 | .0165 | .0168 |
| 20 | | .0149 | .0149 | .0148 | .017 |
| 21 | | .0131 | .0112 | .0111 | .0132 |
| 22 | | .0093 | .0093 | .0092 | .0093 |
| 23 | .0092 | .0075 | .0075 | .0075 | .0075 |
| 24 | | .0075 | .0075 | .0075 | .0056 |
| Max | .0092 | .0168 | .0168 | .0165 | .017 |
| Min | .0092 | .0067 | .0075 | .0075 | .0037 |
| Avg | .0092 | .0116 | .0110 | .0104 | .0106 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084019 / 33 KV CHICHPALLI

Feeder No / Name : 203 / 11 KV KOLSA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0037 | .0037 | .0019 | .0037 |
| 2 | | | .0037 | .0056 | .0019 | .0037 |
| 3 | | | .0037 | .0037 | .0019 | .0037 |
| 4 | | | .0036 | .0037 | .0019 | .0037 |
| 5 | | | .0037 | .0037 | .0019 | .0037 |
| 6 | | | .0036 | .0037 | .0037 | .0037 |
| 7 | | | .0037 | .0037 | .0037 | .0036 |
| 8 | | | .0036 | .0037 | .0037 | .0036 |
| 9 | | | .0034 | .0037 | .0037 | .0036 |
| 10 | | | .0036 | .0037 | .0037 | .0036 |
| 11 | | | .0056 | .0019 | .0034 | .0018 |
| 12 | | | .0037 | .0019 | .0033 | .0018 |
| 13 | | | .0019 | .0037 | .0017 | .0037 |
| 14 | | | .0019 | .0037 | .0032 | .0037 |
| 15 | | | .0037 | .0037 | .0049 | .0036 |
| 16 | | | .0056 | .0037 | .0048 | .0054 |
| 17 | | | .0037 | .0037 | .0032 | .0036 |
| 18 | | | .0037 | .0037 | .0053 | .0037 |
| 19 | | | .0056 | .0056 | .0055 | .0057 |
| 20 | .0037 | | .0056 | .0056 | .0055 | .0057 |
| 21 | | | .0037 | .0037 | .0055 | .0038 |
| 22 | | | | .0037 | .0037 | .0037 |
| 23 | | .0037 | .0037 | .0037 | .0037 | .0019 |
| 24 | | | .0037 | .0037 | .0019 | .0037 |
| Max | .0037 | .0037 | .0056 | .0056 | .0055 | .0057 |
| Min | .0037 | .0037 | .0019 | .0019 | .0017 | .0018 |
| Avg | .0037 | .0037 | .0038 | .0038 | .0035 | .0037 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084027 / SOLAR POWER PLANT

Feeder No / Name : 201 / POWER EVACUATION

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0739 | .0739 | .0554 | .0739 |
| 2 | .0739 | .0739 | .0554 | .0554 |
| 3 | .0739 | .0739 | .0739 | .0554 |
| 4 | .0739 | .0739 | .0739 | .0554 |
| 5 | .0739 | .0739 | .0739 | .0554 |
| 6 | .0739 | .0739 | .0739 | .0554 |
| 7 | .0924 | .0739 | .0924 | .0739 |
| 8 | .7392 | .7023 | 1.5339 | .924 |
| 9 | 1.6263 | 1.9035 | 1.5339 | 1.386 |
| 10 | 2.2177 | 2.572 | 2.1622 | 2.0513 |
| 11 | 2.7166 | 2.9721 | 2.6981 | 2.4025 |
| 12 | 2.9569 | 3.1245 | 2.7721 | 2.5503 |
| 13 | 2.9754 | 2.8769 | 2.5688 | 2.5133 |
| 14 | 2.7166 | 2.4387 | 2.3655 | 2.1068 |
| 15 | 2.1437 | 1.7372 | 1.848 | 1.6448 |
| 16 | .2218 | 1.0719 | 1.0534 | .8316 |
| 17 | .1109 | .2957 | .1848 | .1478 |
| 18 | .0762 | .0554 | .0554 | .0739 |
| 19 | .0762 | .0554 | .0554 | .0739 |
| 20 | .0762 | .0554 | .0739 | .0739 |
| 21 | .0924 | .0554 | .0739 | .0554 |
| 22 | .0739 | .0739 | .0554 | .0739 |
| 23 | .0739 | .0739 | .0554 | .0739 |
| 24 | .0739 | .0739 | .0739 | .0739 |
| Max | 2.9754 | 3.1245 | 2.7721 | 2.5503 |
| Min | .0739 | .0554 | .0554 | .0554 |
| Avg | .8127 | .8606 | .8193 | .7284 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084048 / 33KV TADALI SUBSTATION

Feeder No / Name : 201 / 11KV SONEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0876 | .0701 | .0709 | .0709 |
| 2 | .0895 | .0709 | .0709 | .0709 |
| 3 | .0895 | .0701 | .0709 | .0709 |
| 4 | .0895 | .0701 | .0709 | .0709 |
| 5 | .0895 | .0709 | .0709 | .0709 |
| 6 | .1075 | .0876 | .0709 | .0709 |
| 7 | .1433 | .0876 | .1063 | .1063 |
| 8 | .1612 | .1227 | .124 | .1417 |
| 9 | .1433 | .1052 | .1063 | .1417 |
| 10 | .1254 | .0876 | .1063 | .1063 |
| 11 | .0886 | .1063 | .1063 | .1075 |
| 12 | .1063 | .124 | .1063 | .1075 |
| 13 | .1063 | .124 | .1063 | .1433 |
| 14 | .124 | .124 | .1063 | .1254 |
| 15 | .1595 | .1063 | .124 | .1254 |
| 16 | .1063 | .124 | .1063 | .1075 |
| 17 | .124 | .1595 | .1417 | .1254 |
| 18 | .124 | .124 | .1417 | .1433 |
| 19 | .124 | .1612 | .1417 | .1433 |
| 20 | .124 | .1254 | .124 | .1433 |
| 21 | .1063 | .1075 | .1063 | .1075 |
| 22 | .0886 | .0895 | .0886 | .0895 |
| 23 | .0709 | .0716 | .0709 | .0895 |
| 24 | .0876 | .0709 | .0716 | .0709 |
| Max | .1612 | .1612 | .1417 | .1433 |
| Min | .0709 | .0701 | .0709 | .0709 |
| Avg | .1111 | .1025 | .1004 | .1063 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084048 / 33KV TADALI SUBSTATION

Feeder No / Name : 202 / 11KV NTPC II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3814 | .5083 | .567 | .4784 |
| 2 | .3814 | .4908 | .567 | .4607 |
| 3 | .3681 | | .567 | .4607 |
| 4 | .3506 | .3856 | .567 | .5316 |
| 5 | .333 | .4207 | .567 | .5138 |
| 6 | .4031 | .5083 | .567 | .5316 |
| 7 | .4733 | .4207 | .4252 | .4784 |
| 8 | .6485 | .5258 | .5847 | .691 |
| 9 | .631 | .3856 | .7442 | .7265 |
| 10 | .631 | .7537 | .7442 | .0886 |
| 11 | .7186 | .2279 | .7265 | .7537 |
| 12 | .7186 | .5784 | .7973 | .7712 |
| 13 | .6836 | | .7619 | .5609 |
| 14 | .7537 | | .6379 | .8238 |
| 15 | .7537 | .8063 | .6556 | .8063 |
| 16 | .6485 | .7362 | .6733 | .8238 |
| 17 | .7011 | .7011 | .6556 | .7186 |
| 18 | .7011 | .7712 | .7265 | .7712 |
| 19 | .7186 | .7537 | .7442 | .7888 |
| 20 | .6485 | .5434 | .7087 | .7011 |
| 21 | .5959 | .6135 | .6379 | .4908 |
| 22 | .5083 | .6485 | .5493 | .631 |
| 23 | .5083 | .5784 | .3366 | .5609 |
| 24 | .3988 | .5258 | .5609 | .5138 |
| Max | .7537 | .8063 | .7973 | .8238 |
| Min | .333 | .2279 | .3366 | .0886 |
| Avg | .5691 | .5659 | .6280 | .6116 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 084048 / 33KV TADALI SUBSTATION

Feeder No / Name : 203 / 11KV TADALI II

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0686 | .0701 | .0709 | .0678 |
| 2 | .0686 | .0701 | .0709 | .0678 |
| 3 | .0686 | .0701 | .0709 | .0678 |
| 4 | .0686 | .0701 | .0709 | .0848 |
| 5 | .0686 | .0701 | .0709 | .0848 |
| 6 | .0686 | .0701 | .0709 | .0848 |
| 7 | .0857 | .0526 | .0709 | .0678 |
| 8 | .0857 | .0876 | .0709 | .0848 |
| 9 | .12 | .104 | .0886 | .0857 |
| 10 | .0857 | .0867 | .0886 | .0857 |
| 11 | .1052 | .0867 | .0857 | .0857 |
| 12 | .1052 | .104 | .0857 | .1029 |
| 13 | .1052 | .104 | .0857 | .0857 |
| 14 | .1052 | .104 | .0686 | .0857 |
| 15 | .1052 | .1214 | .0857 | .0857 |
| 16 | .1227 | .104 | .0686 | .0686 |
| 17 | .1052 | .0867 | .0857 | .0686 |
| 18 | .1052 | .104 | .1029 | .0857 |
| 19 | .104 | .104 | .1029 | .1029 |
| 20 | .104 | .0867 | .1029 | .0857 |
| 21 | .104 | .0867 | .0857 | .0857 |
| 22 | .0693 | .0693 | .0857 | .0686 |
| 23 | .0693 | .0693 | .0686 | .0686 |
| 24 | .0857 | .0693 | .0693 | .0686 |
| Max | .1227 | .1214 | .1029 | .1029 |
| Min | .0686 | .0526 | .0686 | .0678 |
| Avg | .0910 | .0855 | .0803 | .0804 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 202 / 11 KV PADMAPUR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.7164 | 1.1883 | 1.363 | 1.7177 |
| 2 | 1.0751 | 1.1694 | 1.1576 | 1.0374 |
| 3 | 1.0374 | 1.1694 | 1.1317 | 1.1694 |
| 4 | 1.1317 | 1.1317 | 1.1506 | 1.1883 |
| 5 | 1.1694 | 1.2136 | 1.3203 | 1.4901 |
| 6 | 1.2826 | 1.4523 | 1.4146 | 1.7918 |
| 7 | 2.0936 | 1.8673 | 1.6409 | 2.0936 |
| 8 | 1.8484 | 1.8484 | 1.6975 | 1.6409 |
| 9 | 1.6975 | 1.1694 | 1.0751 | 1.1694 |
| 10 | 1.8484 | 1.7353 | 1.773 | 1.7164 |
| 11 | 1.7353 | 1.4712 | 1.6617 | 2.1313 |
| 12 | 1.6787 | 1.6598 | 1.5497 | 2.1879 |
| 13 | 1.3203 | 1.358 | 1.3203 | 1.7164 |
| 14 | 1.1883 | 1.2826 | 1.4523 | 1.6787 |
| 15 | 1.2637 | 1.1883 | 1.2826 | 1.4146 |
| 16 | 1.1506 | 1.1317 | 1.5278 | 1.3769 |
| 17 | 1.6409 | 1.4523 | 1.2826 | 1.2637 |
| 18 | 2.0559 | 1.5844 | 2.4143 | 1.7164 |
| 19 | 1.8296 | 1.6032 | 2.3577 | 1.9805 |
| 20 | 1.6787 | 1.5089 | 1.7541 | 1.6787 |
| 21 | 1.6409 | 1.3392 | 1.8484 | 1.4335 |
| 22 | 1.5089 | 1.3203 | 1.9239 | 1.3392 |
| 23 | 1.1694 | 1.1203 | 1.2637 | 1.3769 |
| 24 | 1.2449 | 1.2071 | 1.2449 | 1.2449 |
| Max | 2.0936 | 1.8673 | 2.4143 | 2.1879 |
| Min | 1.0374 | 1.1203 | 1.0751 | 1.0374 |
| Avg | 1.5003 | 1.3822 | 1.5253 | 1.5648 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 205 / 11 KV TPS-II (ACC FLY ASH) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3353 | .1844 | .0503 | .3391 |
| 2 | .3185 | .1341 | .3353 | .3391 |
| 3 | .3353 | .1006 | .3521 | .3561 |
| 4 | .3353 | .1006 | .3353 | .3561 |
| 5 | .3353 | .3734 | .3521 | .3391 |
| 6 | .3353 | .3921 | .3521 | .3561 |
| 7 | .3353 | .3521 | .3521 | .3561 |
| 8 | .3353 | .3353 | .3353 | .3353 |
| 9 | .3521 | | .3521 | .3353 |
| 10 | .3353 | .3018 | .3353 | .3353 |
| 11 | .3353 | .3353 | .3521 | .3353 |
| 12 | .3353 | .3353 | .3521 | .3353 |
| 13 | .1677 | .3353 | .3353 | .3185 |
| 14 | | .3353 | .3353 | .3353 |
| 15 | | .3353 | .3353 | .3353 |
| 16 | | .3353 | .3353 | .3185 |
| 17 | | .3185 | .3353 | .3353 |
| 18 | .3353 | .3521 | .3353 | .3521 |
| 19 | .3353 | .3521 | .3353 | .3521 |
| 20 | .3521 | .3353 | .3521 | .3353 |
| 21 | .0838 | .3521 | .3353 | .285 |
| 22 | .3353 | .3353 | .3353 | .3353 |
| 23 | .3353 | .0503 | .3353 | .3353 |
| 24 | .3185 | .3185 | .3353 | .3185 |
| Max | .3521 | .3921 | .3521 | .3561 |
| Min | .0838 | .0503 | .0503 | .285 |
| Avg | .3143 | .2913 | .3290 | .3364 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 206 / 11 KV DURGAPUR WCL NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6722 | .5601 | .3174 | .3734 |
| 2 | | .4854 | .5788 | .5788 | .3734 |
| 3 | | .5228 | .5601 | .7655 | .3174 |
| 4 | | .5228 | .5788 | .7468 | .5228 |
| 5 | | .5601 | .6161 | .3734 | .5415 |
| 6 | | .5788 | .7655 | .4108 | .5975 |
| 7 | | .4481 | .6535 | .4854 | .6161 |
| 8 | | .6908 | .6535 | .7095 | .2054 |
| 9 | | .7655 | .7282 | .7282 | .7282 |
| 10 | | .7842 | .7468 | .7095 | .6722 |
| 11 | | .8962 | .6535 | .6908 | .6722 |
| 12 | | .7095 | .7095 | .8775 | .6535 |
| 13 | | .9709 | .7468 | 1.0456 | .6722 |
| 14 | | .9149 | .6908 | .9522 | .6908 |
| 15 | | .4481 | .6161 | .6535 | .6908 |
| 16 | | .6535 | .4108 | .6908 | |
| 17 | .5228 | .6908 | .5788 | .6908 | .6161 |
| 18 | | .7095 | .8402 | .9522 | 1.2883 |
| 19 | | .7282 | .9149 | .8775 | 1.251 |
| 20 | | .7655 | .9522 | .7842 | 1.0269 |
| 21 | | .5788 | .6722 | .7095 | .7842 |
| 22 | | .3734 | .7655 | .6161 | .2427 |
| 23 | | .3734 | .3734 | .4854 | .1463 |
| 24 | | .4854 | .5788 | .4108 | .3734 |
| Max | .5228 | .9709 | .9522 | 1.0456 | 1.2883 |
| Min | .5228 | .3734 | .3734 | .3174 | .1463 |
| Avg | .5228 | .6387 | .6644 | .6776 | .6111 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 208 / 11 KV RURAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5228 | .6908 | .6908 | .7095 |
| 2 | .4854 | .7095 | .6722 | .6908 |
| 3 | .5041 | .7282 | .6722 | .6908 |
| 4 | .4854 | .7095 | .6908 | .7095 |
| 5 | .4854 | .7282 | .6722 | .6722 |
| 6 | .5788 | .5788 | .5415 | .6161 |
| 7 | .5228 | .5041 | .5601 | .5788 |
| 8 | .5601 | .5415 | .7468 | .7842 |
| 9 | .5601 | .5601 | .8402 | .8215 |
| 10 | .5415 | .5601 | .7468 | .9522 |
| 11 | .7842 | .5601 | .7468 | .5788 |
| 12 | .7842 | .5415 | .7468 | .5788 |
| 13 | .5228 | .4481 | .7655 | .5601 |
| 14 | .5415 | .4294 | .5041 | .6161 |
| 15 | .5041 | .5228 | .4481 | .5788 |
| 16 | .8029 | .8215 | .4481 | .8962 |
| 17 | .8215 | .8215 | .4668 | .8402 |
| 18 | 1.0082 | 1.0082 | .7842 | 1.0642 |
| 19 | 1.0642 | 1.1016 | .8215 | 1.0642 |
| 20 | 1.0082 | .9709 | .7655 | 1.0082 |
| 21 | .6908 | .8775 | .8215 | .6908 |
| 22 | .5601 | .5601 | .5788 | .5788 |
| 23 | .7468 | .7468 | .4854 | .5041 |
| 24 | .5041 | .7282 | .7095 | .7095 |
| Max | 1.0642 | 1.1016 | .8402 | 1.0642 |
| Min | .4854 | .4294 | .4481 | .5041 |
| Avg | .6496 | .6854 | .6636 | .7289 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 210 / 11 KV WATER SUPPLY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND

UTILITY

| DATE | 18-DEC-17 | 19-DEC-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .1132 | .0754 |
| 2 | .1132 | .0943 |
| 3 | .1132 | |
| 4 | .1132 | .1132 |
| 5 | .1509 | .1132 |
| 6 | .1509 | .1132 |
| 7 | .1509 | .1132 |
| 8 | .1132 | .1132 |
| 9 | .1132 | .1132 |
| 10 | .1132 | .1132 |
| 11 | .1132 | |
| 12 | .1132 | |
| 13 | .1132 | |
| 14 | .1132 | |
| 15 | .1132 | |
| 16 | .1132 | |
| 17 | .1132 | |
| 18 | .1132 | |
| 19 | .1132 | |
| 20 | .1132 | |
| 21 | .1132 | |
| 22 | .1132 | |
| 23 | .1132 | |
| 24 | .1132 | .1132 |
| Max | .1509 | .1132 |
| Min | .1132 | .0754 |
| Avg | .1179 | .1075 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 211 / 11 KV DURGAPUR TOWN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1494 | .0934 | .112 | .1494 |
| 2 | | .1494 | .0934 | .0747 | .1494 |
| 3 | .112 | .1494 | .0747 | .0747 | .0747 |
| 4 | .1494 | .1494 | .0747 | .112 | .0747 |
| 5 | .1494 | .1494 | .1494 | .1307 | .0934 |
| 6 | .2054 | .2054 | .112 | .2427 | .1307 |
| 7 | .1494 | .2054 | .1494 | .1494 | .168 |
| 8 | | .1494 | .1494 | .1494 | .2054 |
| 9 | | .2054 | .112 | .1494 | .2054 |
| 10 | | .2054 | .1494 | .2054 | .2054 |
| 11 | | .2427 | .2054 | .1307 | .2054 |
| 12 | | .168 | .112 | .1494 | .1494 |
| 13 | | .1494 | .112 | .112 | .1494 |
| 14 | | .1494 | .112 | .112 | .1494 |
| 15 | | .1494 | .1494 | .0747 | .1494 |
| 16 | | .168 | .112 | .1307 | .1494 |
| 17 | | .3174 | .112 | .2427 | .2054 |
| 18 | | .4854 | .4854 | .4481 | .4854 |
| 19 | | .6161 | .5788 | .5228 | .6161 |
| 20 | | .5788 | .5788 | .5228 | .5788 |
| 21 | | .4108 | .4108 | .2054 | .4481 |
| 22 | | .2054 | .2054 | .2427 | .2801 |
| 23 | | .112 | .112 | .112 | .1494 |
| 24 | | .2054 | .112 | .0747 | .1494 |
| Max | .2054 | .6161 | .5788 | .5228 | .6161 |
| Min | .112 | .112 | .0747 | .0747 | .0747 |
| Avg | .1531 | .2365 | .1898 | .1867 | .2217 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 212 / 11KV ULTRATECH FLY ASH NON SHEDDABLE EXPRESS HV FEEDERS
 FEEDER Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3361 | .3174 | .3174 | .3361 |
| 2 | .3361 | .3174 | .3361 | .3361 |
| 3 | .2987 | .3174 | .3174 | .3361 |
| 4 | .2987 | .3174 | .3361 | .6908 |
| 5 | .3734 | .7282 | .2054 | .4854 |
| 6 | .5601 | .7842 | .2054 | .3547 |
| 7 | .3361 | .3174 | .2241 | .3547 |
| 8 | .2801 | .3361 | .4668 | .3361 |
| 9 | .6161 | .6348 | .3547 | .6161 |
| 10 | .3734 | .3547 | .5601 | .3361 |
| 11 | .2987 | .4668 | .8402 | .6348 |
| 12 | .3547 | .6161 | .8215 | .5601 |
| 13 | .5228 | .4108 | .6161 | .5041 |
| 14 | .8402 | .3547 | .3174 | .6348 |
| 15 | .3547 | .3547 | .2427 | .3361 |
| 16 | .6161 | .3734 | .4668 | .6161 |
| 17 | .6161 | .3361 | .6348 | .7282 |
| 18 | .3734 | .6161 | .3547 | .4108 |
| 19 | .3734 | .8402 | .8402 | .9335 |
| 20 | .5601 | .5415 | .3921 | .9522 |
| 21 | .8029 | .3361 | .3734 | .3174 |
| 22 | .3174 | .3361 | .3361 | |
| 23 | .3547 | .4854 | .5975 | |
| 24 | .3361 | .3174 | .5788 | .6161 |
| Max | .8402 | .8402 | .8402 | .9522 |
| Min | .2801 | .3174 | .2054 | .3174 |
| Avg | .4388 | .4504 | .4473 | .5194 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 213 / 11KV AMBUJA FLY ASH FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4294 | .4481 | .4294 | .4294 |
| 2 | .4294 | .4481 | .4294 | .4294 |
| 3 | .4294 | .4481 | .4294 | .4294 |
| 4 | .4294 | .4481 | .4294 | .4294 |
| 5 | .4294 | .4294 | .4294 | .4108 |
| 6 | .4294 | .4481 | .4294 | .4294 |
| 7 | .4294 | .4481 | .4294 | .4251 |
| 8 | .4294 | .4294 | .4294 | .4294 |
| 9 | .4294 | .4294 | .4294 | .4294 |
| 10 | .4294 | .4294 | .4294 | .4294 |
| 11 | .4481 | .4481 | .4481 | .4294 |
| 12 | .4294 | .4481 | .4294 | .4294 |
| 13 | .4294 | .4481 | .4294 | .4294 |
| 14 | .4108 | .4294 | .4294 | .4294 |
| 15 | .4294 | .4294 | .4108 | .4294 |
| 16 | .4108 | .4294 | .4294 | .4294 |
| 17 | .4294 | .4294 | .4294 | .4294 |
| 18 | .4294 | .4294 | .4481 | .4481 |
| 19 | .4481 | .4481 | .4294 | .4294 |
| 20 | .4294 | .4294 | .4294 | .4294 |
| 21 | .4294 | .4294 | .4294 | .4294 |
| 22 | .4294 | .4294 | .4294 | .4294 |
| 23 | .4294 | .4294 | .4294 | .4294 |
| 24 | .4294 | .4294 | .4294 | .4294 |
| Max | .4481 | .4481 | .4481 | .4481 |
| Min | .4108 | .4294 | .4108 | .4108 |
| Avg | .4294 | .4372 | .4302 | .4292 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 085010 / 33/11 KV Chandrapur TPS

Feeder No / Name : 401 / 33 KV DURGAPUR S/STN

NON SHEDDABLE EXPRESS HV FEEDERS

INCOMER Feeder KV- 33 /

(NON-CONTINUOUS PROCESS)(NO

INCOMING

STAGGERING)

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6161 | .5601 | .5601 | .5544 |
| 2 | | .6161 | .5601 | .5601 | .499 |
| 3 | .6161 | .6161 | .5601 | .5041 | .499 |
| 4 | | .6722 | .5601 | .4481 | .499 |
| 5 | | .6722 | .5601 | .6161 | .6099 |
| 6 | | .7282 | .6722 | .6722 | .7762 |
| 7 | | .9522 | 1.0082 | .8962 | .9425 |
| 8 | .9522 | .9522 | .9522 | .8962 | .8962 |
| 9 | | 1.0082 | .8962 | .8962 | .8962 |
| 10 | | .8962 | .8402 | .9522 | .8962 |
| 11 | | .8962 | .7842 | .8962 | .8402 |
| 12 | | .7842 | .7282 | .7282 | .7282 |
| 13 | | .6722 | .6161 | .6722 | .6722 |
| 14 | | .6722 | .5601 | .5601 | .6161 |
| 15 | | .5601 | .5601 | .5601 | .5601 |
| 16 | | .6161 | .5601 | .5601 | .5601 |
| 17 | | .6722 | .6161 | .5601 | .6722 |
| 18 | | 1.0082 | .9522 | 1.0082 | 1.0082 |
| 19 | | 1.0642 | 1.0642 | 1.0642 | 1.1203 |
| 20 | | 1.0082 | 1.0082 | .9522 | 1.0082 |
| 21 | | .9522 | .8962 | .8962 | .9522 |
| 22 | | .7842 | .7842 | .8402 | .8402 |
| 23 | | .6722 | .6722 | .6722 | .6722 |
| 24 | | .6722 | .6161 | .5601 | .5601 |
| Max | .9522 | 1.0642 | 1.0642 | 1.0642 | 1.1203 |
| Min | .6161 | .5601 | .5601 | .4481 | .499 |
| Avg | .7842 | .7818 | .7328 | .7305 | .7450 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR S/DN.[327] BU 4327

Substation No/ Name :- 088016 / 220/33KV TADALI MIDC S/STN

Feeder No / Name : 401 / TADALI S/STN incomer NON SHEDDABLE EXPRESS HV FEEDERS
 feeder Feeder KV- 33 / (NON-CONTINUOUS PROCESS)(NO
 INCOMING STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5258 | .6241 | .691 | .6379 |
| 2 | .5258 | .631 | .691 | .5847 |
| 3 | .5258 | .5784 | .691 | .5847 |
| 4 | .5258 | .5258 | .691 | .691 |
| 5 | .463 | .5784 | .691 | .691 |
| 6 | .5658 | .6836 | .691 | .691 |
| 7 | .6687 | .5721 | .6379 | .6379 |
| 8 | .8745 | .7282 | .7973 | .9036 |
| 9 | .8939 | .5721 | .9568 | .9465 |
| 10 | .8413 | .9362 | .9568 | .9991 |
| 11 | .8939 | .4252 | .8939 | .9465 |
| 12 | .9465 | .7973 | .9991 | .9991 |
| 13 | .8939 | .9568 | .9465 | .7888 |
| 14 | .9882 | .9568 | .7888 | 1.0517 |
| 15 | .9882 | 1.0631 | .8413 | .9991 |
| 16 | .8842 | .9568 | .8413 | .9991 |
| 17 | .9362 | .9568 | .8939 | .8939 |
| 18 | .9465 | 1.0099 | .9465 | .9991 |
| 19 | .9362 | 1.0099 | .9991 | 1.0517 |
| 20 | .8842 | .7442 | .9465 | .9465 |
| 21 | .7802 | .7973 | .8413 | .6836 |
| 22 | .6762 | .7973 | .7362 | .7888 |
| 23 | .6241 | .7442 | .4733 | .7362 |
| 24 | .5784 | .6762 | .691 | .631 |
| Max | .9882 | 1.0631 | .9991 | 1.0517 |
| Min | .463 | .4252 | .4733 | .5847 |
| Avg | .7653 | .7634 | .8056 | .8284 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 201 / 11 KV Chandrapur GAJANAN
MANDI Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4508 | .4161 | .3988 | .4207 |
| 2 | | .4334 | .4161 | .3988 | .3814 |
| 3 | | .4161 | .4161 | .3988 | .3988 |
| 4 | | .4161 | .3988 | .3988 | .3856 |
| 5 | | .4334 | .4161 | .4334 | .4031 |
| 6 | | .4854 | .5028 | .4854 | .5258 |
| 7 | | .7011 | .6588 | .6836 | .6836 |
| 8 | | .7186 | .6935 | .7011 | .6661 |
| 9 | | .6762 | .6661 | .6089 | .7712 |
| 10 | | .6089 | .631 | .5973 | .6984 |
| 11 | | .6447 | .5609 | .6447 | .6626 |
| 12 | | .5552 | .5194 | .543 | .6089 |
| 13 | | .5194 | .5194 | .4525 | .5014 |
| 14 | | .5194 | .5014 | .4706 | .5014 |
| 15 | | .4656 | .4656 | .4525 | .5014 |
| 16 | .5316 | .5014 | .4477 | .4525 | .5373 |
| 17 | | .567 | .4298 | .4835 | .5552 |
| 18 | | .7087 | .6626 | .6984 | .7343 |
| 19 | | .7265 | .6984 | .7701 | .7011 |
| 20 | | .691 | .6154 | .6984 | .6805 |
| 21 | | .691 | .5973 | .6626 | .6447 |
| 22 | | .6024 | .5853 | .6268 | .591 |
| 23 | | .4854 | .4681 | .5083 | .4908 |
| 24 | | .4908 | .4508 | .4161 | .4207 |
| Max | .5316 | .7265 | .6984 | .7701 | .7712 |
| Min | .5316 | .4161 | .3988 | .3988 | .3814 |
| Avg | .5316 | .5629 | .5307 | .5410 | .5611 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 202 / 11 KV AKASHWANI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4733 | .4382 | .4031 | .4252 |
| 2 | .4733 | .4207 | .3856 | .4207 |
| 3 | .4557 | .4382 | .4031 | .4557 |
| 4 | .4557 | .4207 | .4031 | .4252 |
| 5 | .4733 | .4382 | .4382 | .4607 |
| 6 | .5258 | .4733 | .4908 | .4961 |
| 7 | .6733 | .631 | .6201 | .6556 |
| 8 | .6733 | .5959 | .6201 | .6379 |
| 9 | .691 | .6485 | .6516 | .7087 |
| 10 | .6447 | .6556 | .6584 | .7164 |
| 11 | .6268 | .6379 | .6805 | .6805 |
| 12 | .6089 | .6447 | .6154 | .7343 |
| 13 | .6089 | .5731 | .5973 | .591 |
| 14 | .6089 | .591 | .5853 | .6089 |
| 15 | .6089 | .5552 | .6335 | .6268 |
| 16 | .6089 | .6626 | .6219 | .6626 |
| 17 | .691 | .7522 | .6984 | .6447 |
| 18 | .9391 | .9145 | .9492 | .9134 |
| 19 | .8505 | .8962 | .9134 | .9492 |
| 20 | .7973 | .8326 | .8238 | .8238 |
| 21 | .7265 | .8145 | .7164 | .7522 |
| 22 | .6024 | .6335 | .6984 | .6447 |
| 23 | .5493 | .5083 | .6379 | .5792 |
| 24 | .4961 | .4382 | .4382 | .4784 |
| Max | .9391 | .9145 | .9492 | .9492 |
| Min | .4557 | .4207 | .3856 | .4207 |
| Avg | .6193 | .6090 | .6118 | .6288 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 203 / 11 KV Chandrapur RAMNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7802 | .7186 | .6935 | .6661 |
| 2 | .7628 | .7108 | .6762 | .6588 |
| 3 | .7373 | .6935 | .6588 | .6661 |
| 4 | .7455 | .6935 | .6415 | .6661 |
| 5 | .7802 | .7282 | .6588 | .6661 |
| 6 | .8322 | .8063 | .7282 | .7712 |
| 7 | .929 | .9015 | .964 | .9465 |
| 8 | .9465 | .8842 | .8939 | .8764 |
| 9 | .9114 | .9362 | .905 | .964 |
| 10 | .9465 | .9114 | .9231 | .9816 |
| 11 | .8764 | .8589 | .8954 | .9114 |
| 12 | .8413 | .8238 | .7964 | .8063 |
| 13 | .8063 | .7712 | .7783 | .7712 |
| 14 | .7362 | .7362 | .7499 | .7537 |
| 15 | .7537 | .7011 | .7059 | .7362 |
| 16 | .7888 | .7186 | .6805 | .7537 |
| 17 | .9036 | .8688 | .7362 | .7888 |
| 18 | 1.2048 | 1.2437 | 1.0692 | 1.1568 |
| 19 | 1.1871 | 1.2308 | 1.1043 | 1.2094 |
| 20 | 1.1163 | 1.1403 | 1.1043 | 1.1218 |
| 21 | 1.0808 | 1.0974 | 1.0517 | 1.0692 |
| 22 | 1.0099 | .9774 | .964 | .964 |
| 23 | .7011 | .7975 | .8413 | .905 |
| 24 | .8063 | .7802 | .7108 | .7186 |
| Max | 1.2048 | 1.2437 | 1.1043 | 1.2094 |
| Min | .7011 | .6935 | .6415 | .6588 |
| Avg | .8827 | .8638 | .8305 | .8554 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 204 / 11 KV NAGINABAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4252 | .3898 | .333 | .3366 |
| 2 | .4031 | .3681 | .333 | .3366 |
| 3 | .3856 | .3681 | .3155 | .333 |
| 4 | .4031 | .3681 | .3155 | .3366 |
| 5 | .4031 | .3856 | .333 | .3544 |
| 6 | .4207 | .4207 | .3681 | .3721 |
| 7 | .5847 | .5959 | .5847 | .567 |
| 8 | .5493 | .5083 | .4961 | .5138 |
| 9 | .5316 | .567 | .5373 | .5493 |
| 10 | .5194 | .5316 | .5731 | .5552 |
| 11 | .4835 | .4607 | .3801 | .5014 |
| 12 | .4835 | .4119 | .4163 | .4656 |
| 13 | .4477 | .3582 | .3258 | .4119 |
| 14 | .3761 | .3582 | .3439 | .394 |
| 15 | .3582 | .3761 | .3258 | .3045 |
| 16 | .3403 | .3582 | .3439 | .3582 |
| 17 | .3898 | .1791 | .3761 | .3761 |
| 18 | .5493 | .591 | .5373 | .6626 |
| 19 | .6379 | .6584 | .6268 | .6268 |
| 20 | .7087 | .6335 | .6089 | .6447 |
| 21 | .6201 | .5853 | .591 | .6447 |
| 22 | .5493 | .5611 | .5194 | .5731 |
| 23 | .4784 | .4207 | .443 | .5068 |
| 24 | .443 | .4031 | .3681 | .3721 |
| Max | .7087 | .6584 | .6268 | .6626 |
| Min | .3403 | .1791 | .3155 | .3045 |
| Avg | .4788 | .4524 | .4332 | .4624 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 205 / 11 KV RAMNAGAR W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1132 | .1132 | .1132 | .1132 |
| 2 | | .1132 | .1132 | .1132 | .1132 |
| 3 | | .0857 | .0857 | .0829 | .0663 |
| 4 | | .0857 | .0829 | .0848 | .0857 |
| 5 | | .0857 | .0857 | .0857 | .1132 |
| 6 | | .1132 | .1132 | .1132 | .0857 |
| 7 | | .0867 | .1132 | .1132 | .1132 |
| 8 | | .0857 | .1132 | .1132 | .1132 |
| 9 | | .1132 | .1132 | .0895 | .1132 |
| 10 | .1132 | .0762 | .1132 | .0895 | .0762 |
| 11 | | .0762 | .0857 | .0724 | .0762 |
| 12 | | .0762 | .061 | .1086 | .0762 |
| 13 | | .0762 | .0972 | .1086 | .0972 |
| 14 | | .0762 | .0972 | .1097 | .0972 |
| 15 | | .0972 | .0762 | .1086 | .0762 |
| 16 | | .0762 | .0762 | .0724 | .0762 |
| 17 | | .08 | .1086 | .0972 | .0972 |
| 18 | | .12 | .1075 | .0972 | .0762 |
| 19 | | .1029 | .0895 | .0972 | .0972 |
| 20 | | .1063 | .0905 | .0972 | .0762 |
| 21 | | .081 | .0905 | .061 | .061 |
| 22 | | .0791 | .0905 | .081 | .061 |
| 23 | | .081 | .0857 | .0857 | .0905 |
| 24 | | .1132 | .1132 | .1132 | .1132 |
| Max | .1132 | .12 | .1132 | .1132 | .1132 |
| Min | .1132 | .0762 | .061 | .061 | .061 |
| Avg | .1132 | .0917 | .0965 | .0962 | .0902 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084018 / 33 KV VISHWAKARMA

Feeder No / Name : 206 / 11 KV Chandrapur WADGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4382 | .3814 | .3681 | .3721 |
| 2 | .4207 | .3681 | .3681 | .3506 |
| 3 | .4031 | .3856 | .3506 | .3681 |
| 4 | .4207 | .3681 | .3506 | .3544 |
| 5 | .4207 | .3856 | .3681 | .3721 |
| 6 | .4207 | .4382 | .3856 | .3898 |
| 7 | .567 | .5609 | .6024 | .5847 |
| 8 | .6024 | .5784 | .5847 | .567 |
| 9 | .5721 | .5493 | .5792 | .5847 |
| 10 | .591 | .6024 | .5611 | .6154 |
| 11 | .543 | .5316 | .5014 | .5792 |
| 12 | .543 | .543 | .6089 | .543 |
| 13 | .5068 | .5249 | .4887 | .543 |
| 14 | .4706 | .5068 | .5121 | .5068 |
| 15 | .5068 | .4887 | .4344 | .4706 |
| 16 | .4887 | .5792 | .4525 | .4706 |
| 17 | .5552 | .4835 | .4525 | .5068 |
| 18 | .7701 | .7343 | .7059 | .724 |
| 19 | .6805 | .7421 | .7421 | .7421 |
| 20 | .7087 | .6335 | .6335 | .7059 |
| 21 | .6089 | .6516 | .5973 | .5973 |
| 22 | .5731 | .543 | .6154 | .543 |
| 23 | .4557 | .4382 | .5493 | .4525 |
| 24 | .443 | .4207 | .3856 | .3898 |
| Max | .7701 | .7421 | .7421 | .7421 |
| Min | .4031 | .3681 | .3506 | .3506 |
| Avg | .5296 | .5183 | .5083 | .5139 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084021 / 33 KV TUKUM

Feeder No / Name : 201 / 11 KV Shastrinagar
INDUSTRIAL Feeder KV- 11 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0564 | .0808 | .0857 | .0899 |
| 2 | .0518 | .0854 | .0789 | .0854 |
| 3 | .0488 | .0838 | .0655 | .0854 |
| 4 | .056 | .076 | .0716 | .0823 |
| 5 | .0453 | .0907 | .0884 | .0884 |
| 6 | .0547 | .0914 | .0972 | .1115 |
| 7 | .064 | .1063 | .1086 | .132 |
| 8 | .0823 | .1581 | .12 | .132 |
| 9 | .1214 | .1791 | .1052 | .1677 |
| 10 | .1865 | .2534 | .168 | .2195 |
| 11 | .2241 | .2035 | .1696 | .2587 |
| 12 | .1905 | .2477 | .2204 | .3018 |
| 13 | .2241 | .2075 | .2303 | .2641 |
| 14 | .1337 | .2054 | .2279 | .2149 |
| 15 | .1783 | .2534 | .2378 | .2641 |
| 16 | .2263 | .2263 | .2126 | .2263 |
| 17 | .1848 | .1886 | .1865 | .2263 |
| 18 | .1526 | .1829 | .2103 | .1848 |
| 19 | .1638 | .1113 | .1638 | .1715 |
| 20 | .1276 | .0793 | .1353 | .1252 |
| 21 | .1115 | .1181 | .1276 | .12 |
| 22 | .1149 | .1029 | .1132 | .0793 |
| 23 | .1046 | .096 | .1183 | .0747 |
| 24 | .0669 | .0884 | .0892 | .0975 |
| Max | .2263 | .2534 | .2378 | .3018 |
| Min | .0453 | .076 | .0655 | .0747 |
| Avg | .1238 | .1465 | .1430 | .1585 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084021 / 33 KV TUKUM

Feeder No / Name : 202 / 11 KV JATPURA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .567 | .5014 | .4835 | .5194 |
| 2 | .5373 | .5014 | .4835 | .4835 |
| 3 | .5194 | .4835 | .4656 | .4607 |
| 4 | .5373 | .4887 | .4656 | .4607 |
| 5 | .5194 | .4887 | .4656 | .4607 |
| 6 | .567 | .5249 | .5121 | .5493 |
| 7 | .6219 | .567 | .567 | .5973 |
| 8 | .6036 | .6219 | .6219 | .5853 |
| 9 | .6767 | .6283 | .6219 | .6036 |
| 10 | .6878 | .6154 | .6767 | .6767 |
| 11 | .7164 | .724 | .7059 | .6984 |
| 12 | .7796 | .6805 | .7964 | .7602 |
| 13 | .7265 | .7265 | .7619 | .7343 |
| 14 | .7888 | .691 | .7522 | .6984 |
| 15 | .7011 | .6556 | .7164 | .6626 |
| 16 | .7282 | .7087 | .7522 | .7087 |
| 17 | .7712 | .7619 | .7499 | .7164 |
| 18 | 1.0867 | 1.0631 | 1.0387 | 1.0208 |
| 19 | 1.0387 | 1.0029 | 1.0317 | 1.0029 |
| 20 | .9774 | .9593 | .905 | .9412 |
| 21 | .8417 | .8326 | .8688 | .8688 |
| 22 | .7701 | .7522 | .8059 | .7602 |
| 23 | .6447 | .6089 | .6201 | .6268 |
| 24 | .5847 | .5373 | .5194 | .5316 |
| Max | 1.0867 | 1.0631 | 1.0387 | 1.0208 |
| Min | .5194 | .4835 | .4656 | .4607 |
| Avg | .7081 | .6719 | .6828 | .6720 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084021 / 33 KV TUKUM

Feeder No / Name : 203 / 11 KV TUKUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5601 | .5228 | .499 | .4904 |
| 2 | .5729 | .5228 | .499 | .4854 |
| 3 | .5415 | .4854 | .462 | .4668 |
| 4 | .5228 | .5041 | .462 | .4668 |
| 5 | .5415 | .5041 | .4805 | .4854 |
| 6 | .5788 | .5228 | .5359 | .5415 |
| 7 | .5788 | | .5729 | .5847 |
| 8 | .5975 | .5914 | .5788 | .6161 |
| 9 | .6468 | .6283 | .6348 | .6535 |
| 10 | .7023 | .6653 | .6584 | .6653 |
| 11 | .7577 | .7392 | .7392 | .7282 |
| 12 | .7682 | .7577 | .7655 | .7468 |
| 13 | .6838 | .6653 | .6722 | .6979 |
| 14 | .6733 | .6468 | .679 | .6979 |
| 15 | .7682 | .7023 | .7207 | .7762 |
| 16 | .7602 | .7265 | .7392 | .7762 |
| 17 | .7602 | .788 | .7682 | .8413 |
| 18 | .9774 | .9055 | .9694 | .924 |
| 19 | .9145 | .8686 | .9149 | .8962 |
| 20 | .905 | .9328 | .8501 | .9055 |
| 21 | .7762 | .8326 | .8596 | .8779 |
| 22 | .7023 | .5975 | .6722 | .6908 |
| 23 | .5914 | .5601 | .5975 | .5729 |
| 24 | .5729 | .5544 | .5228 | .5281 |
| Max | .9774 | .9328 | .9694 | .924 |
| Min | .5228 | .4854 | .462 | .4668 |
| Avg | .6856 | .6619 | .6606 | .6715 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084039 / 33 KV MIDC

Feeder No / Name : 201 / 11 KV MIDC-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4954 | .4572 | .4763 | .4572 |
| 2 | .4763 | .4382 | .4572 | .4382 |
| 3 | .4763 | .4382 | .4763 | .4572 |
| 4 | .4954 | .4763 | .4763 | .4763 |
| 5 | .4954 | .5144 | .4572 | .4572 |
| 6 | .5144 | .5335 | .4763 | .4763 |
| 7 | .4763 | .4763 | .4763 | .4572 |
| 8 | .5335 | .5144 | .4763 | .4763 |
| 9 | .5525 | .5716 | .4572 | .5144 |
| 10 | .6097 | .5716 | .4572 | .5144 |
| 11 | .6287 | .6097 | .4382 | .5906 |
| 12 | .6287 | .6859 | .4572 | .5716 |
| 13 | .5906 | .6287 | .4382 | .5716 |
| 14 | .6097 | .5906 | .4572 | .5525 |
| 15 | .6287 | .6097 | .4382 | .6097 |
| 16 | .5906 | .6668 | .4572 | .5525 |
| 17 | .6478 | .5906 | .4382 | .5335 |
| 18 | .5906 | .5335 | .4572 | .5716 |
| 19 | .6097 | .5525 | .4763 | .5716 |
| 20 | .4954 | .4954 | .4763 | .5144 |
| 21 | .5335 | .5144 | .4954 | .5144 |
| 22 | .4763 | .4572 | .4954 | .4954 |
| 23 | .4763 | .4763 | .4763 | .4954 |
| 24 | .4763 | .4763 | .4763 | .4763 |
| Max | .6478 | .6859 | .4954 | .6097 |
| Min | .4763 | .4382 | .4382 | .4382 |
| Avg | .5462 | .5366 | .4652 | .5144 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084039 / 33 KV MIDC

Feeder No / Name : 203 / 11 KV Chandrapur MIDC

SHEDDABLE RURAL

PADOLI Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.0136 | .823 | .8688 | .8869 |
| 2 | .9774 | .7865 | .8326 | .8507 |
| 3 | 1.0317 | .7865 | .7783 | .8507 |
| 4 | 1.0136 | .7499 | .7783 | .8869 |
| 5 | 1.0317 | .8962 | .8507 | .9231 |
| 6 | 1.0498 | .9511 | .9955 | .9593 |
| 7 | 1.1584 | .9511 | 1.1403 | 1.0317 |
| 8 | 1.2127 | .9877 | 1.1041 | 1.086 |
| 9 | 1.262 | 1.0059 | 1.1222 | 1.1041 |
| 10 | .7865 | 1.1584 | .9877 | 1.0317 |
| 11 | .8413 | 1.1222 | 1.134 | 1.1584 |
| 12 | 1.0974 | 1.1222 | .8413 | 1.2308 |
| 13 | 1.1523 | 1.1041 | .823 | 1.6832 |
| 14 | 1.1157 | 1.1403 | .7865 | 1.5565 |
| 15 | 1.0059 | 1.0317 | .6219 | 1.5384 |
| 16 | 1.0498 | 1.1584 | .6697 | 1.5023 |
| 17 | 1.0136 | 1.2489 | .8326 | 1.6108 |
| 18 | 1.3352 | 1.5384 | 1.3575 | 1.9004 |
| 19 | 1.39 | 1.5565 | 1.4118 | 1.8461 |
| 20 | 1.2986 | 1.3394 | 1.4299 | 1.7556 |
| 21 | 1.2071 | 1.2308 | 1.2127 | 1.6108 |
| 22 | .9877 | 1.0498 | 1.1041 | 1.4661 |
| 23 | .9328 | .9231 | .9774 | 1.3394 |
| 24 | 1.0136 | .8413 | .8869 | .9231 |
| Max | 1.39 | 1.5565 | 1.4299 | 1.9004 |
| Min | .7865 | .7499 | .6219 | .8507 |
| Avg | 1.0824 | 1.0626 | .9812 | 1.2805 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084039 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV MIDC-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6478 | .6478 | .4763 | .5335 |
| 2 | | .6668 | .6097 | .4572 | .4954 |
| 3 | | .6478 | .6478 | .4954 | .5525 |
| 4 | | .6287 | .6668 | .4763 | .5906 |
| 5 | | .6859 | .743 | .5144 | .6287 |
| 6 | | .743 | .8002 | .5525 | .6859 |
| 7 | | .7811 | .743 | .6097 | .7049 |
| 8 | | .743 | .7811 | .5525 | .7049 |
| 9 | | .7811 | .8764 | .3239 | .7811 |
| 10 | | .9145 | .7049 | .4382 | .9145 |
| 11 | | .8573 | .8002 | .5525 | .9907 |
| 12 | .5906 | .9335 | .8573 | .3239 | .8573 |
| 13 | | .724 | .6478 | .4191 | .7621 |
| 14 | | .6097 | .5144 | .381 | .7811 |
| 15 | | .9145 | .6287 | .362 | .9335 |
| 16 | | .8764 | .7621 | .5144 | .8954 |
| 17 | | .8002 | .7049 | .5335 | .8764 |
| 18 | | .8954 | .8002 | .5525 | .9526 |
| 19 | | .9335 | .6859 | .5144 | .8573 |
| 20 | | .7811 | .6287 | .5144 | .6287 |
| 21 | | .7621 | .6097 | .5144 | .743 |
| 22 | | .8573 | .5906 | .5716 | .6478 |
| 23 | | .6478 | .4191 | .5335 | .6287 |
| 24 | | .6097 | .6668 | .4572 | .4954 |
| Max | .5906 | .9335 | .8764 | .6097 | .9907 |
| Min | .5906 | .6097 | .4191 | .3239 | .4954 |
| Avg | .5906 | .7684 | .6890 | .4850 | .7351 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084039 / 33 KV MIDC

Feeder No / Name : 207 / 11 KV MULTI EXP. FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1694 | 1.2071 | 1.1694 | 1.1883 |
| 2 | 1.1317 | 1.1883 | 1.1622 | 1.1317 |
| 3 | 1.094 | 1.226 | 1.1883 | 1.2071 |
| 4 | 1.094 | 1.1694 | 1.1694 | 1.1883 |
| 5 | 1.1317 | 1.2071 | 1.2071 | 1.1694 |
| 6 | 1.1694 | 1.2449 | 1.1506 | 1.1694 |
| 7 | 1.1506 | 1.226 | 1.1694 | 1.1317 |
| 8 | 1.1694 | 1.2637 | 1.1506 | 1.1506 |
| 9 | 1.2071 | 1.2071 | 1.1506 | 1.1883 |
| 10 | 1.2071 | 1.2071 | 1.1883 | 1.1694 |
| 11 | 1.2449 | 1.2449 | 1.2071 | 1.2449 |
| 12 | 1.1883 | 1.1883 | 1.2071 | 1.1883 |
| 13 | 1.2071 | 1.226 | 1.1694 | 1.2449 |
| 14 | 1.2826 | 1.1694 | 1.2071 | 1.1694 |
| 15 | 1.226 | 1.1883 | 1.1883 | 1.1694 |
| 16 | 1.2637 | 1.1883 | 1.1883 | 1.2449 |
| 17 | 1.2071 | 1.2071 | 1.1317 | 1.2637 |
| 18 | 1.1506 | 1.2071 | 1.1694 | 1.1317 |
| 19 | 1.1694 | 1.226 | 1.2071 | 1.2071 |
| 20 | 1.1506 | 1.3392 | 1.094 | 1.2637 |
| 21 | 1.1694 | 1.2637 | 1.1506 | 1.1317 |
| 22 | .8048 | 1.226 | 1.2071 | 1.1694 |
| 23 | 1.2071 | 1.3014 | 1.2071 | 1.2637 |
| 24 | 1.1694 | 1.2071 | 1.2071 | 1.1883 |
| Max | 1.2826 | 1.3392 | 1.2071 | 1.2637 |
| Min | .8048 | 1.1694 | 1.094 | 1.1317 |
| Avg | 1.1652 | 1.2221 | 1.1770 | 1.1906 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 201 / 11 kv Chandrapur indira SHEDDABLE URBAN
nagar Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5548 | .5083 | .4733 | .4908 |
| 2 | | .5375 | .5083 | .4908 | .4733 |
| 3 | | .5375 | .4908 | .4908 | .4733 |
| 4 | | .5721 | .5258 | .4733 | .4908 |
| 5 | | .5895 | .5434 | .5258 | .5258 |
| 6 | | .6588 | .6836 | .6485 | .6661 |
| 7 | | .7455 | .8238 | .8589 | .9465 |
| 8 | | .7362 | .7888 | .8238 | .8413 |
| 9 | | .7455 | .8505 | .8328 | .8589 |
| 10 | | .7362 | .7442 | .7796 | .7888 |
| 11 | | .7186 | .7265 | .6556 | .6836 |
| 12 | | .6485 | .6733 | .6379 | .7186 |
| 13 | | .631 | .6379 | .6733 | .6485 |
| 14 | | .631 | .5847 | .567 | .5609 |
| 15 | | .5784 | .5316 | .5316 | .5959 |
| 16 | | .5609 | .4961 | .5493 | .5434 |
| 17 | | .6485 | .6024 | .5609 | .7011 |
| 18 | | .964 | .929 | .8669 | .9536 |
| 19 | | 1.0517 | .9991 | 1.0229 | 1.0867 |
| 20 | | 1.0166 | 1.0517 | 1.0229 | .964 |
| 21 | | .9991 | .9991 | .9536 | .9114 |
| 22 | | .8149 | .7888 | .8505 | .7619 |
| 23 | .6762 | .6415 | .6135 | .6379 | .5847 |
| 24 | | .5721 | .5375 | .5258 | .5258 |
| Max | .6762 | 1.0517 | 1.0517 | 1.0229 | 1.0867 |
| Min | .6762 | .5375 | .4908 | .4733 | .4733 |
| Avg | .6762 | .7038 | .6933 | .6856 | .6998 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 202 / 11 KV RAYYATWARI(COLARY SHEDDABLE URBAN
II) Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4066 | .2957 | .3142 | .3696 |
| 2 | | .3467 | .3326 | .2772 | .3511 |
| 3 | | .3696 | .2772 | .2957 | .3511 |
| 4 | | .4251 | .3511 | .3142 | .3511 |
| 5 | | .4435 | .4066 | .3881 | .3696 |
| 6 | | .7207 | .3696 | .6099 | .7207 |
| 7 | | .3511 | .3511 | .2957 | .3326 |
| 8 | | .7762 | .7207 | .7023 | .499 |
| 9 | | .5175 | .443 | .4805 | .7392 |
| 10 | | .7392 | .7087 | .7023 | .7392 |
| 11 | | .6468 | .7207 | .6283 | .6838 |
| 12 | | .6283 | .6468 | .6099 | .462 |
| 13 | | .5175 | .443 | .5175 | .499 |
| 14 | | .499 | .4251 | .4066 | .4066 |
| 15 | | .4066 | .4435 | .3721 | .3881 |
| 16 | | .4435 | .4435 | .3696 | .4435 |
| 17 | | .4805 | .4805 | .4435 | .499 |
| 18 | | .6468 | .6283 | .6283 | .6653 |
| 19 | | .7023 | .6838 | .7023 | .6838 |
| 20 | | .6653 | .6653 | .6653 | .6838 |
| 21 | | .5914 | .5914 | .6283 | .6099 |
| 22 | | .5359 | .5175 | .5359 | .5359 |
| 23 | .4251 | .4066 | .4066 | .462 | .4435 |
| 24 | | .4066 | .3511 | .3696 | .3696 |
| Max | .4251 | .7762 | .7207 | .7023 | .7392 |
| Min | .4251 | .3467 | .2772 | .2772 | .3326 |
| Avg | .4251 | .5281 | .4876 | .4883 | .5082 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 203 / 11 KV ESSENTIAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0137 | .0139 | .0139 | .0139 |
| 2 | | .0137 | .0139 | .0139 | .0139 |
| 3 | | .0137 | .0139 | .0139 | .0139 |
| 4 | | .0139 | .0139 | .0139 | .0139 |
| 5 | | .0137 | .0139 | .0139 | .0139 |
| 6 | | .0137 | .0139 | .0139 | .0139 |
| 7 | | .0137 | .0139 | .0139 | .0139 |
| 8 | | .0137 | .0139 | .0139 | .0139 |
| 9 | | .0137 | .0152 | .0152 | .0139 |
| 10 | | .0139 | .0152 | .0152 | .0139 |
| 11 | | .0139 | .0152 | .0152 | .0139 |
| 12 | | .0137 | .0152 | .0152 | .0139 |
| 13 | | .0137 | .0152 | .0152 | .0139 |
| 14 | | .0137 | .0152 | .0152 | .0139 |
| 15 | | .0137 | .0152 | .0152 | .0139 |
| 16 | | .0137 | .0152 | .0152 | .0139 |
| 17 | | .0137 | .0152 | .0137 | .0137 |
| 18 | | .0137 | .0137 | .0137 | .0137 |
| 19 | | .0137 | .0137 | .0137 | .0156 |
| 20 | | .0137 | .0137 | .0137 | .0137 |
| 21 | | .0137 | .0137 | .0137 | .0137 |
| 22 | | .0139 | .0139 | .0149 | .0152 |
| 23 | .0137 | .0139 | .0139 | .0149 | .0152 |
| 24 | | .0137 | .0139 | .0139 | .0139 |
| Max | .0137 | .0139 | .0152 | .0152 | .0156 |
| Min | .0137 | .0137 | .0137 | .0137 | .0137 |
| Avg | .0137 | .0137 | .0144 | .0144 | .0140 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 206 / 11 KV Astabhuja

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4287 | .3429 | .3429 | .3429 |
| 2 | | .4115 | .3429 | .2915 | .2915 |
| 3 | | .4115 | .2915 | .2743 | .2915 |
| 4 | | .4115 | .3429 | .2572 | .2572 |
| 5 | | .4115 | .3772 | .3429 | .3086 |
| 6 | | .4458 | .4287 | .3772 | .4458 |
| 7 | | .4801 | .5658 | .4115 | .5316 |
| 8 | | .4115 | .4801 | .4115 | .4801 |
| 9 | | .5658 | .4961 | .4252 | .4458 |
| 10 | | .4801 | .4252 | .4252 | .5658 |
| 11 | | .5316 | .5493 | .6201 | .5316 |
| 12 | | .5316 | .4607 | .691 | .4801 |
| 13 | | .4115 | .4607 | .5847 | .3429 |
| 14 | | .4115 | .4252 | .4252 | .3772 |
| 15 | | .3429 | .3544 | .3544 | .4115 |
| 16 | | .4458 | .3544 | .3544 | .3772 |
| 17 | | .4801 | .4607 | .4458 | .4801 |
| 18 | | .7202 | .8059 | .7716 | .8745 |
| 19 | | .8573 | .8745 | .8059 | .8916 |
| 20 | | .7716 | .8059 | .7716 | .8402 |
| 21 | | .703 | .703 | .7202 | .7202 |
| 22 | | .5658 | .6001 | .6135 | .6201 |
| 23 | .5316 | .4458 | .4458 | .4908 | .4607 |
| 24 | | .4458 | .3772 | .3772 | .3772 |
| Max | .5316 | .8573 | .8745 | .8059 | .8916 |
| Min | .5316 | .3429 | .2915 | .2572 | .2572 |
| Avg | .5316 | .5051 | .4905 | .4827 | .4894 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 207 / 11 KV LOHARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .181 | .1267 | .1267 | .128 |
| 2 | | .1448 | .1267 | .1267 | .0905 |
| 3 | | .1448 | .1267 | .1267 | .1086 |
| 4 | | .1448 | .1267 | .1267 | .1267 |
| 5 | | .181 | .1448 | .1448 | .1267 |
| 6 | | .2534 | .1448 | .2353 | .2172 |
| 7 | | .2715 | .3258 | .2715 | .3258 |
| 8 | | .2896 | .2715 | .2715 | .2896 |
| 9 | | .3077 | .2218 | .2772 | .2353 |
| 10 | | .3077 | .3326 | .2957 | .2896 |
| 11 | | .2353 | .3326 | .3326 | .2534 |
| 12 | | .2534 | .2587 | .3511 | .2172 |
| 13 | | .2172 | .2587 | .2587 | .1086 |
| 14 | | .2172 | .2033 | .2033 | .181 |
| 15 | | .1991 | .2033 | .2402 | .1267 |
| 16 | | .2172 | .2033 | .2033 | .1267 |
| 17 | | .2896 | .2715 | .181 | .2353 |
| 18 | | .3982 | .362 | .3801 | .3982 |
| 19 | | .4525 | .4344 | .4344 | .4163 |
| 20 | | .4163 | .4163 | .4344 | .3982 |
| 21 | | .3439 | .362 | .362 | .3801 |
| 22 | | .2715 | .2715 | .3109 | .2658 |
| 23 | .2353 | .181 | .1991 | .2012 | .1848 |
| 24 | | .181 | .1267 | .1448 | .1267 |
| Max | .2353 | .4525 | .4344 | .4344 | .4163 |
| Min | .2353 | .1448 | .1267 | .1267 | .0905 |
| Avg | .2353 | .2542 | .2438 | .2517 | .2232 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 208 / 11 KV Shastrinagar PADOLI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5548 | .4908 | .4908 | .4382 |
| 2 | | .5201 | .4908 | .298 | .4382 |
| 3 | | .5028 | .4733 | .4733 | .4382 |
| 4 | | .5201 | .4733 | .4557 | .4382 |
| 5 | | .5201 | .4908 | .4908 | .4382 |
| 6 | | .5721 | .6135 | .5434 | .5784 |
| 7 | | .7282 | .6836 | .7011 | .7362 |
| 8 | | .6935 | .6661 | .7011 | .6836 |
| 9 | | .7108 | .7265 | .7265 | .7186 |
| 10 | | .7011 | .6556 | .7087 | .631 |
| 11 | | .6661 | .6379 | .6733 | .6135 |
| 12 | | .5959 | .5847 | .6201 | .5784 |
| 13 | | .5721 | .5493 | .5847 | .5609 |
| 14 | | .8149 | .5493 | .5493 | .5609 |
| 15 | | .5721 | .4607 | .5493 | .5434 |
| 16 | | .5721 | .5138 | .5493 | .5434 |
| 17 | | .6068 | .567 | .5375 | .6241 |
| 18 | | .8322 | .7628 | .7108 | .7628 |
| 19 | | .8589 | .8764 | .8149 | .8322 |
| 20 | | .8413 | .8149 | .7802 | .8149 |
| 21 | | .7455 | .7888 | .7455 | .7628 |
| 22 | | .7186 | .6661 | .7087 | .691 |
| 23 | .6241 | .6135 | .5784 | .5493 | .567 |
| 24 | | .5548 | .5258 | .5083 | .4733 |
| Max | .6241 | .8589 | .8764 | .8149 | .8322 |
| Min | .6241 | .5028 | .4607 | .298 | .4382 |
| Avg | .6241 | .6495 | .6100 | .6029 | .6028 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 209 / 11 KV Shastrinagar TADALI SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5765 | .5316 | .5316 | .4917 |
| 2 | | .5426 | .5316 | .5144 | .4748 |
| 3 | | .5426 | .5316 | .4973 | .4748 |
| 4 | | .5426 | .5316 | .4801 | .4917 |
| 5 | | .5426 | .5316 | .5144 | .5087 |
| 6 | | .6104 | .6516 | .5658 | .5765 |
| 7 | | .7461 | .7202 | .703 | .6443 |
| 8 | | .7122 | .6859 | .7087 | .6274 |
| 9 | | .7291 | .7442 | .7087 | .7202 |
| 10 | | .6859 | .7442 | .7796 | .7545 |
| 11 | | .6173 | .6379 | .6556 | .703 |
| 12 | | .6104 | .5847 | .6379 | .6344 |
| 13 | | .5426 | .6024 | .6024 | .5658 |
| 14 | | .5256 | .5316 | .5316 | .5316 |
| 15 | | .5087 | .5493 | .4961 | .5316 |
| 16 | | .5256 | .5316 | .4961 | .4801 |
| 17 | | .5426 | .6024 | .5596 | .5935 |
| 18 | | .8817 | .8648 | .6783 | .9156 |
| 19 | | .9156 | .9665 | .8309 | .9665 |
| 20 | | .8817 | .8817 | .8478 | .8478 |
| 21 | | .8139 | .7969 | .78 | .7716 |
| 22 | | .7202 | .8745 | .7282 | .7265 |
| 23 | .6443 | .6173 | .6173 | .6241 | .6024 |
| 24 | | .6104 | .5658 | .5316 | .5256 |
| Max | .6443 | .9156 | .9665 | .8478 | .9665 |
| Min | .6443 | .5087 | .5316 | .4801 | .4748 |
| Avg | .6443 | .6477 | .6588 | .6252 | .6317 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 210 / 11 KV DURGAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4508 | .3856 | .3506 | .3506 |
| 2 | | .4161 | .3856 | .3856 | .3856 |
| 3 | | .3814 | .3856 | .3856 | .3506 |
| 4 | | .4161 | .4031 | .3506 | .3506 |
| 5 | | .4508 | .4207 | .3856 | .3856 |
| 6 | | .5375 | .5258 | .4557 | .4908 |
| 7 | | .7455 | .7186 | .7186 | .7186 |
| 8 | | .6588 | .6836 | .631 | .7011 |
| 9 | | .6588 | .691 | .6733 | .6661 |
| 10 | | .6485 | .691 | .7265 | .6485 |
| 11 | | .6836 | .4961 | .6379 | .6836 |
| 12 | | .4854 | .4607 | .5493 | .6135 |
| 13 | | .3814 | .4252 | .4961 | .4557 |
| 14 | | .3467 | .3898 | .3544 | .3856 |
| 15 | | .3467 | .2658 | .2658 | .3506 |
| 16 | | .3467 | .3898 | .2658 | .298 |
| 17 | | .4508 | .4607 | .4161 | .5375 |
| 18 | | .7802 | .7802 | .7108 | .8149 |
| 19 | | .8764 | .8669 | .8495 | .8842 |
| 20 | | .8413 | .8669 | .7975 | .8322 |
| 21 | | .7888 | .7802 | .7628 | .7888 |
| 22 | | .7011 | .7186 | .7265 | .7164 |
| 23 | .6068 | .6135 | .5784 | .6201 | .5847 |
| 24 | | .4854 | .4908 | .4557 | .4207 |
| Max | .6068 | .8764 | .8669 | .8495 | .8842 |
| Min | .6068 | .3467 | .2658 | .2658 | .298 |
| Avg | .6068 | .5622 | .5525 | .5405 | .5589 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 211 / 11 KV GOPALNAGAR W/W NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .112 | .112 | .0187 | .112 |
| 2 | | .112 | .112 | .0187 | .0187 |
| 3 | | .112 | .112 | .0187 | .112 |
| 4 | | .112 | .112 | .0187 | .112 |
| 5 | | .112 | .112 | .0187 | .112 |
| 6 | | .112 | .112 | .0187 | .112 |
| 7 | | .0187 | .112 | .0187 | .112 |
| 8 | | .112 | .112 | .0187 | |
| 9 | | .112 | .0185 | .0185 | .112 |
| 10 | | .112 | .0185 | .0185 | .112 |
| 11 | | .0187 | .0185 | .0185 | .112 |
| 12 | | .0187 | .0185 | .0185 | .112 |
| 13 | | .112 | .0185 | .0185 | .112 |
| 14 | | .112 | .0185 | .0185 | .112 |
| 15 | | .112 | .0185 | .0185 | .0187 |
| 16 | | .112 | .0185 | .0185 | .0187 |
| 17 | | .0187 | .0185 | .0187 | .112 |
| 18 | | .0187 | .0187 | .0187 | .112 |
| 19 | | .112 | .0187 | .0187 | .0187 |
| 20 | | .112 | .0187 | .1307 | .112 |
| 21 | | .112 | .0187 | .112 | .112 |
| 22 | | .112 | .0187 | .1132 | .1109 |
| 23 | .112 | .112 | .0187 | .1132 | .1109 |
| 24 | | .112 | .0187 | .0187 | .112 |
| Max | .112 | .112 | .112 | .1307 | .112 |
| Min | .112 | .0187 | .0185 | .0185 | .0187 |
| Avg | .112 | .0926 | .0497 | .0351 | .0957 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 401 / 33 KV OUTGOING TUKUM

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.7193 | 1.5043 | 1.3969 | 1.5043 |
| 2 | | 1.6118 | 1.5043 | 1.3969 | 1.5043 |
| 3 | | 1.6118 | 1.5043 | 1.3969 | 1.3969 |
| 4 | | 1.6118 | 1.5043 | 1.3969 | 1.3969 |
| 5 | | 1.6118 | 1.5043 | 1.3969 | 1.5043 |
| 6 | | 1.6118 | 1.7193 | 1.5043 | 1.5581 |
| 7 | | 1.8267 | 1.7193 | 1.8267 | 1.8267 |
| 8 | | 1.9342 | 1.8267 | 1.8267 | 1.8267 |
| 9 | | 2.1491 | 2.1719 | 2.1719 | 2.0416 |
| 10 | | 2.2565 | 2.2805 | 2.2805 | 2.2565 |
| 11 | | 2.5789 | 2.4977 | 2.4977 | 2.364 |
| 12 | | 2.6863 | 2.3891 | 2.6063 | 2.5789 |
| 13 | | 2.4714 | 2.3891 | 2.4977 | 2.4714 |
| 14 | | 2.6863 | 2.2805 | 2.3891 | 2.2565 |
| 15 | | 2.4714 | 2.3891 | 2.4977 | 2.364 |
| 16 | | 2.4714 | 2.4977 | 2.4977 | 2.364 |
| 17 | | 2.5789 | 2.6063 | 2.4714 | 2.6863 |
| 18 | | 3.3311 | 3.2236 | 3.2236 | 3.3311 |
| 19 | | 3.2236 | 3.1161 | 3.1161 | 3.1161 |
| 20 | | 3.0087 | 2.9012 | 2.9012 | 3.0087 |
| 21 | | 2.6863 | 2.6863 | 2.6863 | 2.6863 |
| 22 | | 2.2805 | 2.1491 | 2.2085 | 2.1719 |
| 23 | 1.9342 | 1.8461 | 1.8267 | 1.8073 | 1.7375 |
| 24 | | 1.7193 | 1.6118 | 1.6118 | 1.6118 |
| Max | 1.9342 | 3.3311 | 3.2236 | 3.2236 | 3.3311 |
| Min | 1.9342 | 1.6118 | 1.5043 | 1.3969 | 1.3969 |
| Avg | 1.9342 | 2.2494 | 2.1585 | 2.1503 | 2.1485 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 403 / 33 KV DRC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.6886 | 2.5503 | 2.3285 | 2.4714 |
| 2 | | 3.0247 | 3.6037 | 3.4374 | 2.7343 |
| 3 | | 2.8006 | 3.6591 | 3.7146 | 3.6283 |
| 4 | | 2.8567 | 3.4374 | 3.9918 | 3.3653 |
| 5 | | 2.9127 | 3.1602 | 3.1047 | 3.2602 |
| 6 | | 3.3048 | 3.0493 | 3.9918 | 3.155 |
| 7 | | 3.1367 | 2.9384 | 3.1047 | 3.2076 |
| 8 | | 2.4646 | 2.5503 | 2.3285 | 2.6292 |
| 9 | | 2.3525 | 2.2857 | 2.384 | 2.8275 |
| 10 | | 3.9363 | 3.1893 | 2.9938 | 2.5503 |
| 11 | | 3.7146 | 3.2956 | 3.6037 | 3.1047 |
| 12 | | 3.6969 | 3.4551 | 2.9938 | 3.6037 |
| 13 | | 3.3608 | 3.5614 | 3.3122 | 3.6591 |
| 14 | | 3.5288 | 2.9767 | 2.6606 | 3.4374 |
| 15 | | 3.1927 | 3.0298 | 2.7641 | 3.3265 |
| 16 | | 2.5206 | 2.392 | 2.2325 | 2.6612 |
| 17 | | 1.9605 | 2.1794 | 2.2177 | 2.6337 |
| 18 | | 2.6326 | 3.0727 | 3.2156 | 3.6969 |
| 19 | | 3.5848 | 3.2373 | 2.6863 | 4.145 |
| 20 | | 3.0807 | 3.2922 | 3.3608 | 3.6408 |
| 21 | | 2.8006 | 2.8532 | 2.8567 | 2.9973 |
| 22 | | 3.1602 | 3.4374 | 2.7046 | 3.3488 |
| 23 | 3.1367 | 3.4928 | 3.0493 | 2.4446 | 2.7641 |
| 24 | | 2.3525 | 2.4949 | 2.5503 | 2.4188 |
| Max | 3.1367 | 3.9363 | 3.6591 | 3.9918 | 4.145 |
| Min | 3.1367 | 1.9605 | 2.1794 | 2.2177 | 2.4188 |
| Avg | 3.1367 | 3.0232 | 3.0313 | 2.9576 | 3.1361 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084047 / 33 KV SHASHTRINAGAR S/S

Feeder No / Name : 405 / 33 KV MUL (CHICHPALI) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3361 | .2715 | .2715 | .2829 |
| 2 | | .3361 | .2715 | .2715 | .2829 |
| 3 | | .2801 | .2715 | .2715 | .2263 |
| 4 | | .2801 | .2715 | .2715 | .2829 |
| 5 | | .2801 | .2715 | .2715 | .3395 |
| 6 | | .3361 | .3258 | .3258 | .3395 |
| 7 | | .3921 | .3258 | .3258 | .3961 |
| 8 | | .3921 | .3801 | .3801 | .4527 |
| 9 | | .5041 | .4887 | .4344 | .4887 |
| 10 | | .543 | .4887 | .4887 | .5973 |
| 11 | | .4887 | .4887 | .4887 | .2172 |
| 12 | | .5601 | .543 | .4344 | .4887 |
| 13 | | .4481 | .4887 | .4344 | .4887 |
| 14 | | .5601 | .543 | .4887 | .4887 |
| 15 | | .6161 | .6516 | .543 | .543 |
| 16 | | .5601 | .543 | .543 | .4887 |
| 17 | | .5041 | .543 | .499 | .5487 |
| 18 | | .6161 | .5544 | .2801 | .6161 |
| 19 | | .6722 | .6653 | .6722 | .6516 |
| 20 | | .6161 | .6161 | .6099 | .5973 |
| 21 | | .5041 | .4938 | .4435 | .4887 |
| 22 | | .3801 | .3258 | .3395 | .3801 |
| 23 | .3326 | .3258 | .2715 | .2829 | .2715 |
| 24 | | .3361 | .3258 | .2715 | .2829 |
| Max | .3326 | .6722 | .6653 | .6722 | .6516 |
| Min | .3326 | .2801 | .2715 | .2715 | .2172 |
| Avg | .3326 | .4528 | .4342 | .4018 | .4267 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084051 / 33/11 KV DURGAPUR SUB

STATION

Feeder No / Name : 201 / 11 KV CHHATRAPATI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .2205 | .2097 | .1819 | .1943 |
| 2 | | | .2228 | .1983 | .1851 | .1846 |
| 3 | | | .2196 | .195 | .1911 | .1878 |
| 4 | | | .2146 | .1917 | .1989 | .1861 |
| 5 | | | .2254 | .2006 | .2109 | .1868 |
| 6 | | | .2383 | .2479 | .241 | .2323 |
| 7 | | | .3904 | .3898 | .3958 | .3922 |
| 8 | | | .3716 | .319 | .3189 | .3597 |
| 9 | | | .3821 | .3756 | .3508 | .3756 |
| 10 | | | .3579 | .3366 | .3295 | .3331 |
| 11 | | | .3173 | .3155 | .3225 | .3121 |
| 12 | | | .2984 | .2761 | .2881 | .2594 |
| 13 | | | .2628 | .2692 | .2497 | .2692 |
| 14 | | | .2205 | .2221 | .2381 | .2083 |
| 15 | | | .2072 | .2079 | .2112 | .2001 |
| 16 | | | .217 | .1999 | .2297 | .2204 |
| 17 | | | .254 | .2257 | .2287 | .2526 |
| 18 | | | .3663 | .3348 | .3381 | .337 |
| 19 | | | .3728 | .3676 | .3821 | .3786 |
| 20 | .3537 | | .3365 | .3502 | .3418 | .3453 |
| 21 | | | .3346 | .3429 | .3329 | .3173 |
| 22 | | | .3001 | .2966 | .3018 | .3138 |
| 23 | | .2619 | .2515 | .2437 | .2414 | .2515 |
| 24 | | | .2294 | .2261 | .2204 | .2073 |
| Max | .3537 | .2619 | .3904 | .3898 | .3958 | .3922 |
| Min | .3537 | .2619 | .2072 | .1917 | .1819 | .1846 |
| Avg | .3537 | .2619 | .2838 | .2726 | .2721 | .2711 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 084051 / 33/11 KV DURGAPUR SUB

STATION

Feeder No / Name : 202 / 11 KV SUMITRA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .2317 | .2091 | .2108 | .1914 |
| 2 | | | .2364 | .2095 | .2002 | .1896 |
| 3 | | | .2221 | .2042 | .1898 | .1843 |
| 4 | .2281 | | .2281 | .2024 | .188 | .1843 |
| 5 | | | .231 | .2113 | .1991 | .1934 |
| 6 | | | .2769 | .2661 | .2335 | .2335 |
| 7 | | | .3326 | .3752 | .3197 | .3456 |
| 8 | | | .3421 | .3695 | .3294 | .3091 |
| 9 | | | .3668 | .3421 | .3329 | .3547 |
| 10 | | | .3656 | .3493 | .3294 | .3146 |
| 11 | | | .3365 | .326 | .324 | .345 |
| 12 | | | .2919 | .2711 | .2693 | .2769 |
| 13 | | | .2715 | .2605 | .2551 | .2682 |
| 14 | | | .2778 | .2521 | .2384 | .2566 |
| 15 | | | .2341 | .2261 | .2303 | .2314 |
| 16 | | | .2611 | .2462 | .2226 | .2442 |
| 17 | | | .2489 | .2418 | .2314 | .2705 |
| 18 | | | .404 | .3891 | .351 | .3904 |
| 19 | | | .4101 | .4083 | .385 | .4173 |
| 20 | | | .3761 | .3692 | .3621 | .4083 |
| 21 | | | .3421 | .3439 | .3403 | .3783 |
| 22 | | | .3113 | .2991 | .295 | .3116 |
| 23 | | .2722 | .2561 | .2498 | .2374 | .2445 |
| 24 | | | .2507 | .2197 | .2173 | .202 |
| Max | .2281 | .2722 | .4101 | .4083 | .385 | .4173 |
| Min | .2281 | .2722 | .2221 | .2024 | .188 | .1843 |
| Avg | .2281 | .2722 | .2961 | .2851 | .2705 | .2811 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 088005 / 220 KV SICOM

Feeder No / Name : 401 / 33 KV SHASHTRINAGAR FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 I Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.8073 | 4.8371 | 1.382 | 1.701 |
| 2 | | 1.5947 | 4.784 | 1.382 | 1.382 |
| 3 | | 1.8073 | 4.6776 | 1.382 | 1.5947 |
| 4 | | 1.8073 | 4.8371 | 1.382 | 1.5947 |
| 5 | | 1.8073 | 4.8371 | 1.382 | 1.5947 |
| 6 | | 2.0199 | 5.475 | 1.5947 | 1.9136 |
| 7 | | 2.0199 | 6.166 | 1.9136 | 2.2325 |
| 8 | | 2.1794 | 6.5381 | 1.8604 | 1.9136 |
| 9 | | 2.2857 | 6.2723 | 1.8604 | 2.1794 |
| 10 | | 2.2325 | 6.6444 | 1.9136 | 2.2857 |
| 11 | | 1.9136 | 6.4849 | 1.8073 | 2.1794 |
| 12 | | 1.7541 | 6.6244 | 1.8073 | 2.0199 |
| 13 | | 1.7541 | 5.9534 | 1.701 | 1.7541 |
| 14 | | 6.857 | 5.5281 | 1.4883 | 1.701 |
| 15 | | 6.0065 | 1.3289 | 1.382 | 1.4883 |
| 16 | | 6.166 | 1.4352 | 1.382 | 1.382 |
| 17 | | 6.2723 | 1.6478 | 1.5415 | 1.9136 |
| 18 | | 8.5048 | 2.4451 | 2.2325 | 2.8172 |
| 19 | | 9.1427 | 2.7109 | 2.4983 | 2.6578 |
| 20 | | 8.6111 | 2.5514 | 2.7109 | 2.7641 |
| 21 | | 7.9733 | 2.3388 | 2.6337 | 2.5514 |
| 22 | | 6.9102 | 2.0199 | 2.3137 | 2.2325 |
| 23 | 2.1262 | 5.7407 | 1.701 | 1.9982 | 1.9136 |
| 24 | | 1.9136 | 4.9434 | 1.4883 | 1.7541 |
| Max | 2.1262 | 9.1427 | 6.6444 | 2.7109 | 2.8172 |
| Min | 2.1262 | 1.5947 | 1.3289 | 1.382 | 1.382 |
| Avg | 2.1262 | 4.1284 | 4.2826 | 1.7932 | 1.9800 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 088005 / 220 KV SICOM

Feeder No / Name : 402 / 33 KV SHASHTRINAGAR FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 II Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 3.5294 | | 3.1493 | 3.1161 |
| 2 | | 3.4208 | | 3.0407 | 3.0087 |
| 3 | | 3.3665 | | 2.9321 | 2.955 |
| 4 | | 3.4751 | | 2.9864 | 2.955 |
| 5 | | 3.5294 | | 3.1493 | 3.0624 |
| 6 | | 4.0181 | | 3.6923 | 3.7609 |
| 7 | | 4.1267 | | 4.0724 | 4.137 |
| 8 | | 4.6153 | | 4.3439 | 4.2981 |
| 9 | | 4.6696 | | 4.5068 | 4.6696 |
| 10 | | 4.9411 | | 4.7782 | 5.104 |
| 11 | | 5.104 | | 4.8868 | 4.8868 |
| 12 | | 5.0497 | | 4.8868 | 4.7782 |
| 13 | | 4.6153 | | 4.561 | 4.561 |
| 14 | | | | 4.2353 | 4.181 |
| 15 | | | 4.0724 | 4.3439 | 4.3439 |
| 16 | | | 4.2353 | 4.2896 | 4.2353 |
| 17 | | | 4.6696 | 4.3439 | 4.7782 |
| 18 | | | 6.0814 | 5.8642 | 6.19 |
| 19 | | | 6.2443 | 6.19 | 6.2443 |
| 20 | | | 6.0271 | 5.8642 | 6.0271 |
| 21 | | | 5.5384 | 5.5384 | 5.5927 |
| 22 | | | 4.6153 | 4.6245 | 4.561 |
| 23 | 4.1267 | | 3.8009 | 3.774 | 3.6923 |
| 24 | | 3.6923 | | 3.3665 | 3.2773 |
| Max | 4.1267 | 5.104 | 6.2443 | 6.19 | 6.2443 |
| Min | 4.1267 | 3.3665 | 3.8009 | 2.9321 | 2.955 |
| Avg | 4.1267 | 4.1538 | 5.0316 | 4.3092 | 4.3507 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

CHANDRAPUR-II(U)SDN[326] BU 2160

Substation No/ Name :- 088015 / 220 KV MIDC

Feeder No / Name : 408 / 33 KVShastrinagar I/C -3 NON SHEDDABLE EXPRESS HV FEEDERS
 (MIDC Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 2.9012 | 2.7109 | 2.4983 | 2.7641 |
| 2 | | 3.155 | 3.7209 | 3.5614 | 3.0298 |
| 3 | | 2.955 | 3.774 | 3.8272 | 3.8803 |
| 4 | | 3.0087 | 3.5614 | 4.0929 | 3.6677 |
| 5 | | 3.0624 | 3.2956 | 3.2425 | 3.6145 |
| 6 | | 3.4922 | 3.2425 | 4.1461 | 3.5082 |
| 7 | | 3.3848 | 3.1361 | 3.2956 | 3.6145 |
| 8 | | 2.7401 | 2.8172 | 2.6046 | 3.083 |
| 9 | | 2.7401 | 2.8235 | 2.7692 | 3.1893 |
| 10 | | 4.3056 | 3.7466 | 3.4208 | 3.0298 |
| 11 | | 4.0398 | 3.8552 | 4.0181 | 3.1893 |
| 12 | | 4.137 | 4.0724 | 3.3665 | 3.9335 |
| 13 | | 3.6534 | 4.1267 | 3.7466 | 4.0398 |
| 14 | | 3.8386 | 3.5837 | 3.1493 | 3.774 |
| 15 | | 3.6923 | 3.7466 | 3.3665 | 3.7209 |
| 16 | | 2.955 | 2.9864 | 2.8235 | 3.0298 |
| 17 | | 2.364 | 2.7692 | 2.5766 | 3.1161 |
| 18 | | 3.1161 | 3.5082 | 3.3128 | 4.0929 |
| 19 | | 4.0832 | 3.7334 | 3.3311 | 4.6205 |
| 20 | | 3.546 | 3.7334 | 3.8146 | 4.0832 |
| 21 | | 3.1699 | 3.2076 | 3.1699 | 3.5837 |
| 22 | | 3.4019 | 3.6145 | 3.083 | 3.8009 |
| 23 | 3.2602 | 3.6677 | 3.1893 | 2.7641 | 3.095 |
| 24 | | 2.5514 | 2.7109 | 2.7109 | 2.7109 |
| Max | 3.2602 | 4.3056 | 4.1267 | 4.1461 | 4.6205 |
| Min | 3.2602 | 2.364 | 2.7109 | 2.4983 | 2.7109 |
| Avg | 3.2602 | 3.3317 | 3.4028 | 3.2788 | 3.5072 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084042 / 33KV RAJOLI

Feeder No / Name : 201 / 11 KV RAJOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 19-DEC-17 |
|------|-----------|
| HR | Load (MW) |
| 7 | .0017 |
| Max | .0017 |
| Min | .0017 |
| Avg | .0017 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084042 / 33KV RAJOLI

Feeder No / Name : 202 / 11 KV DONGARGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0034 | | .0017 | .0017 |
| 2 | | .0034 | | .0017 | .0017 |
| 3 | | .0034 | | | .0017 |
| 4 | | .0034 | .0017 | .0017 | .0017 |
| 5 | | .0034 | .0017 | .0017 | .0017 |
| 6 | | .0034 | .0017 | .0017 | .0017 |
| 7 | | .0034 | .0017 | .0017 | .0017 |
| 8 | | .0051 | .0017 | .0017 | .0034 |
| 9 | | .0051 | .0017 | .0017 | .0034 |
| 10 | | .0051 | .0034 | .0034 | .0051 |
| 11 | | .0051 | .0034 | .0034 | .0051 |
| 12 | | .0034 | .0051 | .0017 | .0051 |
| 13 | | | .0034 | .0017 | .0034 |
| 14 | | .0034 | .0034 | | .0034 |
| 15 | | .0034 | .0034 | .0017 | .0034 |
| 16 | | .0034 | .0034 | .0017 | .0051 |
| 17 | | .0034 | .0034 | .0034 | .0051 |
| 18 | | .0034 | .0051 | .0034 | .0051 |
| 19 | | .0017 | .0034 | .0034 | .0051 |
| 20 | .0051 | .0034 | .0034 | .0034 | .0051 |
| 21 | .0034 | .0017 | .0017 | .0034 | .0034 |
| 22 | .0034 | .0017 | .0017 | .0017 | .0034 |
| 23 | .0034 | .0017 | .0017 | .0017 | .0034 |
| 24 | | .0034 | | .0017 | .0017 |
| Max | .0051 | .0051 | .0051 | .0034 | .0051 |
| Min | .0034 | .0017 | .0017 | .0017 | .0017 |
| Avg | .0038 | .0034 | .0028 | .0022 | .0034 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084042 / 33KV RAJOLI

Feeder No / Name : 203 / 11 KV PETGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0069 | .0034 | .0034 | .0051 |
| 2 | | .0069 | .0034 | .0034 | .0051 |
| 3 | | .0051 | .0034 | .0034 | .0034 |
| 4 | | .0051 | .0034 | .0034 | .0034 |
| 5 | | .0051 | .0034 | .0034 | .0051 |
| 6 | | .0051 | .0034 | .0034 | .0051 |
| 7 | | .0051 | .0034 | .0051 | .0051 |
| 8 | | .0069 | .0034 | .0051 | .0069 |
| 9 | | .0069 | .0051 | .0069 | .0051 |
| 10 | | .0069 | .0069 | .0069 | .0051 |
| 11 | | .0086 | .0051 | .0069 | .0069 |
| 12 | | .0069 | .0069 | .0069 | .0069 |
| 13 | | .0051 | .0069 | .0051 | .0086 |
| 14 | | .0051 | .0069 | .0051 | .0069 |
| 15 | | .0069 | .0069 | .0069 | .0086 |
| 16 | | .0069 | .0034 | .0069 | .0086 |
| 17 | | .0051 | .0034 | .0069 | .0103 |
| 18 | | .0069 | .0069 | .0069 | .0069 |
| 19 | | .0069 | .0069 | .0086 | .0069 |
| 20 | .0051 | .0086 | .0051 | .0069 | .0069 |
| 21 | .0069 | .0069 | .0051 | .0051 | .0051 |
| 22 | .0069 | .0051 | .0034 | .0051 | .0051 |
| 23 | .0069 | .0051 | .0034 | .0051 | .0051 |
| 24 | | .0069 | .0051 | .0034 | .0034 |
| Max | .0069 | .0086 | .0069 | .0086 | .0103 |
| Min | .0051 | .0051 | .0034 | .0034 | .0034 |
| Avg | .0065 | .0063 | .0048 | .0054 | .0061 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084050 / 33 KV CHIROLI SUB-STATION

Feeder No / Name : 202 / 11 KV CHIROLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0066 | .0051 | .0049 | .0049 |
| 2 | .0066 | .0051 | .0049 | .005 |
| 3 | .0066 | .0051 | .0049 | .0049 |
| 4 | .0066 | .0051 | .0049 | .005 |
| 5 | .0067 | .0051 | .005 | .0068 |
| 6 | .0089 | .0072 | .007 | .0087 |
| 7 | .0083 | .0018 | .0069 | .0086 |
| 8 | .0096 | .0062 | .0079 | .0084 |
| 9 | .0081 | .0069 | .0067 | .0099 |
| 10 | .0095 | .0082 | .0099 | .0112 |
| 11 | .0081 | .0064 | .0082 | .0081 |
| 12 | .0082 | .0064 | .0083 | .0119 |
| 13 | .0099 | .0115 | .0081 | .0102 |
| 14 | .0094 | .0083 | .0062 | .0095 |
| 15 | .0116 | .0113 | .0079 | .0093 |
| 16 | .0094 | .0098 | .0099 | .0076 |
| 17 | .0019 | .0084 | .0099 | .0059 |
| 18 | .0146 | .0128 | .0143 | .0143 |
| 19 | .0148 | .0149 | .0149 | .0148 |
| 20 | .0112 | .0129 | .0129 | .0128 |
| 21 | .0091 | .0092 | .009 | .0089 |
| 22 | .0069 | .0069 | .0068 | .0084 |
| 23 | .0051 | .0049 | .0049 | .0065 |
| 24 | .0066 | .005 | .0049 | .0048 |
| Max | .0148 | .0149 | .0149 | .0148 |
| Min | .0019 | .0018 | .0049 | .0048 |
| Avg | .0085 | .0077 | .0079 | .0086 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084050 / 33 KV CHIROLI SUB-STATION

Feeder No / Name : 203 / 11 KV JANALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0053 | .0037 | .0036 | .0035 |
| 2 | .0035 | .0037 | .0036 | .0035 |
| 3 | .0035 | .0037 | .0036 | .0036 |
| 4 | .0036 | .0037 | .0036 | .0036 |
| 5 | .0036 | .0055 | .0037 | .0036 |
| 6 | .0055 | .0056 | .0037 | .0035 |
| 7 | .0037 | .0055 | .0037 | .0036 |
| 8 | .0035 | .0053 | .0035 | .0036 |
| 9 | .0051 | .0053 | .0051 | .0035 |
| 10 | .0072 | .0057 | .0072 | .0056 |
| 11 | .0054 | .0037 | .0086 | .0036 |
| 12 | .0071 | .0054 | .0072 | .0057 |
| 13 | .0054 | .0053 | .0054 | .0055 |
| 14 | .0056 | .0056 | .007 | .0055 |
| 15 | .0055 | .0054 | .007 | .0073 |
| 16 | .0055 | .0054 | .005 | .0054 |
| 17 | .0055 | .0055 | .0051 | .0053 |
| 18 | .0093 | .0075 | .0075 | .0075 |
| 19 | .0094 | .0094 | .0094 | .0094 |
| 20 | .0094 | .0075 | .0075 | .0075 |
| 21 | .0056 | .0056 | .0075 | .0056 |
| 22 | .0055 | .0037 | .0037 | .0056 |
| 23 | .0054 | .0036 | .0036 | .0055 |
| 24 | .0053 | .0036 | .0036 | .0035 |
| Max | .0094 | .0094 | .0094 | .0094 |
| Min | .0035 | .0036 | .0035 | .0035 |
| Avg | .0056 | .0052 | .0054 | .0050 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084050 / 33 KV CHIROLI SUB-STATION

Feeder No / Name : 401 / 33KV Pombhurna (Chiroli) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .005 | .0103 | .0103 | .0104 |
| 2 | .005 | .0103 | .0104 | .0104 |
| 3 | .005 | .0104 | .0104 | .0105 |
| 4 | .005 | .0104 | .0104 | .0106 |
| 5 | .005 | .0104 | .0104 | .0106 |
| 6 | .0053 | .0107 | .0107 | .0161 |
| 7 | .0051 | .0106 | .0159 | .0159 |
| 8 | .005 | .005 | .0154 | .0156 |
| 9 | .0098 | .0153 | .0154 | .0154 |
| 10 | .0208 | .0103 | .0154 | .0154 |
| 11 | .0154 | .0153 | .0153 | .0153 |
| 12 | .0151 | .0201 | .0203 | .0153 |
| 13 | .0151 | .0199 | .0201 | .0201 |
| 14 | .0199 | .0197 | .0199 | .0201 |
| 15 | .0151 | .0199 | .0199 | .0098 |
| 16 | .0201 | .0197 | .0199 | .0251 |
| 17 | .0153 | .0149 | .0151 | .0201 |
| 18 | .0222 | .0219 | .0222 | .0219 |
| 19 | .0224 | .0222 | .0224 | .0277 |
| 20 | .0222 | .0222 | .0222 | .0222 |
| 21 | .0163 | .0163 | .0165 | .0163 |
| 22 | .0106 | .0159 | .0105 | .0158 |
| 23 | .0104 | .0104 | .0103 | .0104 |
| 24 | .005 | .0103 | .0103 | .0103 |
| Max | .0224 | .0222 | .0224 | .0277 |
| Min | .005 | .005 | .0103 | .0098 |
| Avg | .0123 | .0147 | .0154 | .0159 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 201 / 11 KV GUJARI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7265 | .6653 | .695 | .4938 |
| 2 | .7087 | .6348 | .6401 | .4784 |
| 3 | .7316 | .6348 | .5853 | .5304 |
| 4 | .7133 | .5729 | .5487 | .5487 |
| 5 | .695 | .5138 | .5304 | .5853 |
| 6 | .691 | .5853 | .5853 | .6036 |
| 7 | .6401 | .6468 | .6584 | .6379 |
| 8 | .6584 | .6767 | .6219 | .6379 |
| 9 | .6733 | .6838 | .6584 | .7522 |
| 10 | .6767 | .6584 | .5853 | .567 |
| 11 | .823 | .7133 | .3475 | .4835 |
| 12 | .7421 | .6219 | .3898 | .8059 |
| 13 | .7947 | .5304 | .567 | .4115 |
| 14 | .7207 | .6584 | .443 | .3944 |
| 15 | .7133 | .5487 | .3898 | .3944 |
| 16 | .7577 | .7316 | .567 | .3944 |
| 17 | .8775 | .8413 | .567 | .4458 |
| 18 | 1.1157 | 1.0974 | .8954 | .7202 |
| 19 | 1.1016 | 1.0608 | .9313 | .8131 |
| 20 | .9149 | .8688 | .9036 | .7762 |
| 21 | .7842 | .9145 | .7973 | .7095 |
| 22 | .7468 | .7865 | .6584 | .5544 |
| 23 | .7207 | .7316 | .3475 | .4805 |
| 24 | .7087 | .6283 | .7316 | .5121 |
| Max | 1.1157 | 1.0974 | .9313 | .8131 |
| Min | .6401 | .5138 | .3475 | .3944 |
| Avg | .7682 | .7086 | .6102 | .5721 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 202 / 11 KV RAJOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0709 | .0716 | .0732 | .0886 |
| 2 | .0886 | .1075 | .0509 | .0709 |
| 3 | .0886 | .0886 | .0543 | .0709 |
| 4 | .1063 | .0876 | .0509 | .0886 |
| 5 | .1063 | .0709 | .0848 | .1063 |
| 6 | .124 | .0716 | .0678 | .1063 |
| 7 | .0709 | .124 | .0678 | .124 |
| 8 | .1595 | .1402 | .1029 | .128 |
| 9 | .1734 | .0354 | .1357 | .2126 |
| 10 | .1595 | .1387 | .1402 | .2126 |
| 11 | .1402 | .1448 | .1097 | .2149 |
| 12 | .2126 | .2401 | .1595 | .1372 |
| 13 | .2481 | .2572 | .1772 | .0686 |
| 14 | .2507 | .2926 | .124 | .0686 |
| 15 | .2686 | .2743 | .1063 | .0686 |
| 16 | .2279 | .2058 | .1063 | .0686 |
| 17 | .1595 | .1715 | .1753 | .1715 |
| 18 | .2481 | .2534 | .1753 | .2058 |
| 19 | .2835 | .2561 | .2865 | .2507 |
| 20 | .2149 | .2378 | .2835 | .2149 |
| 21 | .0724 | .1448 | .1417 | .1052 |
| 22 | .0886 | .0724 | .124 | .0362 |
| 23 | .0543 | .0686 | .0886 | .0358 |
| 24 | .0709 | .0362 | .0678 | .0886 |
| Max | .2835 | .2926 | .2865 | .2507 |
| Min | .0543 | .0354 | .0509 | .0358 |
| Avg | .1537 | .1497 | .1231 | .1227 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 203 / 11 KV GANDHI CHAUOK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3544 | .5658 | .5525 | |
| 2 | .3898 | .5228 | .6783 | |
| 3 | .3189 | .5975 | .6443 | |
| 4 | .2481 | .5415 | .6613 | |
| 5 | .2126 | .4572 | .5087 | |
| 6 | | .4954 | .407 | |
| 7 | .1829 | .6036 | .4409 | |
| 8 | .3544 | .5975 | .4024 | |
| 9 | .3121 | .6859 | .5426 | |
| 10 | .3898 | .6099 | .4572 | .4706 |
| 11 | .4904 | .4572 | .4755 | .9922 |
| 12 | .4481 | .6154 | .7087 | 1.0098 |
| 13 | .6348 | .8573 | .6201 | .9335 |
| 14 | .5658 | .695 | .2481 | 1.086 |
| 15 | .679 | .6097 | | 1.0479 |
| 16 | .5658 | .5335 | | .9335 |
| 17 | .5601 | .5975 | | .9907 |
| 18 | .5716 | .6478 | | .9907 |
| 19 | .4572 | .3429 | | .8962 |
| 20 | .2286 | .2713 | | .7545 |
| 21 | .3048 | .362 | | .679 |
| 22 | .381 | .373 | | .8299 |
| 23 | .4001 | .2195 | | .9145 |
| 24 | .3544 | .4527 | .2926 | |
| Max | .679 | .8573 | .7087 | 1.086 |
| Min | .1829 | .2195 | .2481 | .4706 |
| Avg | .4089 | .5297 | .5093 | .8949 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 204 / 11kv Akapur feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1063 | .1417 | .1715 | .124 |
| 2 | .1063 | .1417 | .1543 | .1063 |
| 3 | .124 | .1227 | .1463 | .1063 |
| 4 | .124 | .1063 | .1629 | .124 |
| 5 | .1063 | .1578 | .1829 | .1417 |
| 6 | .124 | .1772 | .1829 | .1417 |
| 7 | .1417 | .1063 | .1526 | .128 |
| 8 | .1417 | .2126 | .2743 | .1772 |
| 9 | .2427 | .2303 | .2454 | .2103 |
| 10 | .1595 | .2279 | .1715 | .2126 |
| 11 | .2507 | .3086 | .1372 | .3224 |
| 12 | .2835 | .4207 | .1417 | .3429 |
| 13 | .3403 | .3841 | .1417 | .3429 |
| 14 | .3366 | .3944 | .1595 | .2572 |
| 15 | .4207 | .3772 | .1772 | .2572 |
| 16 | .3189 | .3086 | .1949 | .3258 |
| 17 | .2481 | .275 | .1578 | .2572 |
| 18 | .3224 | .2572 | .2126 | .3258 |
| 19 | .3012 | .2561 | .2126 | .2658 |
| 20 | .3155 | .2195 | .1949 | .1928 |
| 21 | .1417 | .1829 | .1417 | .1595 |
| 22 | .1612 | .168 | .1949 | .1595 |
| 23 | .1433 | .1715 | .1417 | .1595 |
| 24 | .124 | .1063 | .1543 | .124 |
| Max | .4207 | .4207 | .2743 | .3429 |
| Min | .1063 | .1063 | .1372 | .1063 |
| Avg | .2119 | .2273 | .1753 | .2069 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 205 / 11 KV CHINCHALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2126 | .1907 | .1543 | .1595 |
| 2 | .1949 | .1753 | .1543 | .1595 |
| 3 | .1886 | .1753 | .1829 | .1417 |
| 4 | .1774 | .156 | .1715 | .1595 |
| 5 | .2126 | .2126 | .1696 | .1949 |
| 6 | .2303 | .2279 | .2035 | .2303 |
| 7 | .1949 | .2126 | .2229 | .1949 |
| 8 | .1949 | .2149 | .2058 | .2126 |
| 9 | .1907 | .2303 | .1698 | .1928 |
| 10 | .2126 | .2149 | .2058 | .2303 |
| 11 | .2328 | .2629 | .1886 | .2149 |
| 12 | .1949 | .2058 | .2126 | .2058 |
| 13 | .208 | .2401 | .2126 | .2572 |
| 14 | .3121 | .3155 | .2303 | .2743 |
| 15 | .2103 | .2743 | .1949 | .2743 |
| 16 | .2401 | .1715 | .1949 | .2572 |
| 17 | .298 | .2572 | .2481 | .2743 |
| 18 | .4161 | .3772 | .4075 | .3601 |
| 19 | .4119 | .4525 | .443 | .4557 |
| 20 | | .4032 | .3544 | .3898 |
| 21 | .2686 | .3258 | .2658 | .2896 |
| 22 | .2507 | .2172 | .2126 | .2126 |
| 23 | .1928 | .1829 | .1772 | .181 |
| 24 | .2126 | .1772 | .181 | .1772 |
| Max | .4161 | .4525 | .443 | .4557 |
| Min | .1774 | .156 | .1543 | .1417 |
| Avg | .2373 | .2447 | .2235 | .2375 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 206 / 11 KV AG SEP FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .0339 | .0305 |
| 2 | | | .0339 | .0305 |
| 3 | | | .0034 | .0305 |
| 4 | | | .0339 | .0305 |
| 5 | | | .0339 | .0305 |
| 6 | | | .0339 | .0305 |
| 8 | .0532 | | | |
| 9 | .0514 | | | |
| 10 | .0514 | | | |
| 11 | .052 | | | |
| 12 | .0514 | | | |
| 13 | .0503 | | | |
| 14 | .0514 | | | |
| 15 | .052 | | | |
| 21 | | .0339 | .0514 | .052 |
| 22 | | .0343 | .0343 | .0514 |
| 23 | | .0373 | .0343 | .0514 |
| 24 | | | .0339 | .0305 |
| Max | .0532 | .0373 | .0514 | .052 |
| Min | .0503 | .0339 | .0034 | .0305 |
| Avg | .0516 | .0352 | .0327 | .0368 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 207 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0343 | .0221 | .0328 | .0343 |
| 2 | .0343 | .0198 | .0339 | .0343 |
| 3 | .0343 | .0232 | .0339 | .0343 |
| 4 | .0343 | .0217 | .0339 | .0343 |
| 5 | .0343 | .0225 | .0328 | .0343 |
| 6 | .0343 | .024 | .0339 | .0343 |
| 7 | .0343 | .0177 | .0339 | .0343 |
| 8 | .0343 | .0155 | .0339 | .0343 |
| 9 | .0343 | .0023 | .0339 | .0343 |
| 10 | .0464 | .0259 | .0271 | .0703 |
| 11 | .1417 | .0366 | .0366 | .0134 |
| 12 | .1753 | .1086 | .0343 | .1097 |
| 13 | .1504 | .1593 | .0343 | .1235 |
| 14 | .1218 | .1086 | .1081 | .1509 |
| 15 | .1318 | .095 | .039 | .1303 |
| 16 | .1347 | .1829 | .0354 | .1235 |
| 17 | .0069 | .1593 | .0701 | .0754 |
| 18 | .1097 | .1017 | .028 | .1235 |
| 19 | .0832 | .144 | .0351 | .1248 |
| 20 | .1245 | .0339 | .0354 | .003 |
| 21 | .0823 | .0339 | .0354 | .0046 |
| 22 | .0046 | .0343 | .0343 | .0069 |
| 23 | .0053 | .0343 | .0354 | .0038 |
| 24 | .0354 | .008 | .0343 | .0343 |
| Max | .1753 | .1829 | .1081 | .1509 |
| Min | .0046 | .0023 | .0271 | .003 |
| Avg | .0693 | .0598 | .0386 | .0586 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 209 / 11 KV ATHWADI BAZAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4607 | .3982 | .39 | .2481 |
| 2 | .4607 | | .3561 | .2481 |
| 3 | .4938 | .3841 | .3391 | .2743 |
| 4 | .4961 | .3224 | .2949 | .2926 |
| 5 | .4784 | .3292 | .3052 | .3109 |
| 6 | .5121 | .2896 | .3856 | .3292 |
| 7 | .4784 | .3189 | .2926 | .2926 |
| 8 | .2926 | .2926 | .2012 | .2835 |
| 9 | .2601 | .3077 | .2374 | .2427 |
| 10 | .2835 | .3439 | .2715 | .2481 |
| 11 | .3801 | .3982 | .2926 | .3012 |
| 12 | .394 | .3292 | .3366 | .3772 |
| 13 | .2534 | .3439 | .1949 | .2915 |
| 14 | .3292 | .2353 | .1829 | .2743 |
| 15 | .3109 | .3258 | .1463 | .463 |
| 16 | .3224 | .362 | .1063 | .4458 |
| 17 | .3439 | .4344 | .1387 | .4115 |
| 18 | .3841 | .3801 | .2658 | .4115 |
| 19 | .3544 | .3801 | .2835 | .3761 |
| 20 | .3258 | .3439 | .2658 | .3898 |
| 21 | .2378 | .3628 | .3366 | .2926 |
| 22 | .3582 | .4172 | .2378 | .3547 |
| 23 | .3801 | .439 | .2926 | .3475 |
| 24 | .4784 | .362 | .4344 | .2658 |
| Max | .5121 | .439 | .4344 | .463 |
| Min | .2378 | .2353 | .1063 | .2427 |
| Avg | .3779 | .3522 | .2745 | .3239 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 084053 / 33/11 KV MUL SUBSTATION

Feeder No / Name : 212 / 11 KV CHAMORSHI ROAD

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /
OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7973 | .8326 | .7602 | .3109 |
| 2 | .7619 | .823 | .6783 | .2743 |
| 3 | .7682 | .7865 | .6226 | .2743 |
| 4 | .8048 | .7392 | .6173 | .2561 |
| 5 | .7865 | .8131 | .6859 | .2378 |
| 6 | .7796 | .823 | .6878 | .2378 |
| 7 | .5138 | .7783 | .6173 | .3109 |
| 8 | .2835 | .4835 | .4801 | .2658 |
| 9 | .2427 | .3045 | .3439 | .2835 |
| 10 | .2195 | .4835 | .3801 | .1063 |
| 11 | .9412 | .695 | .2926 | .6447 |
| 12 | 1.0425 | 1.0317 | .3898 | .8402 |
| 13 | 1.3169 | 1.0791 | .3898 | 1.0117 |
| 14 | 1.1403 | 1.0852 | .4207 | 1.046 |
| 15 | 1.1041 | 1.1946 | .3189 | 1.046 |
| 16 | 1.1403 | 1.307 | .3012 | .9088 |
| 17 | 1.1765 | 1.1946 | .3189 | .8745 |
| 18 | 1.1403 | 1.0679 | .3189 | .6687 |
| 19 | .8507 | 1.1888 | .3012 | .9231 |
| 20 | .4572 | .6104 | .3366 | .7316 |
| 21 | .8048 | .7783 | .3189 | .4251 |
| 22 | .8596 | .7059 | .3189 | .6401 |
| 23 | .9979 | .7865 | .3475 | .591 |
| 24 | .8413 | .7865 | .724 | .3292 |
| Max | 1.3169 | 1.307 | .7602 | 1.046 |
| Min | .2195 | .3045 | .2926 | .1063 |
| Avg | .8238 | .8491 | .4571 | .5516 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 401 / Chamorshi

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.8532 | 2.2325 | 2.1491 | 2.3348 | 2.2891 |
| 2 | 2.5514 | 2.2805 | 2.0953 | 2.2325 | 2.2382 |
| 3 | 2.6337 | 2.3891 | 2.0953 | 2.1491 | 2.1365 |
| 4 | 2.524 | 2.3891 | 2.0416 | 2.1262 | 2.1365 |
| 5 | 2.8532 | 2.4434 | 2.5252 | 2.073 | 2.2891 |
| 6 | 3.0727 | 2.6063 | 2.3045 | 2.6292 | 2.5434 |
| 7 | 2.7984 | 2.3891 | 2.2857 | 3.0498 | 2.696 |
| 8 | 2.7435 | 2.6063 | .463 | 4.2593 | 2.6452 |
| 9 | | 2.7149 | 2.3388 | 4.3587 | 3.0013 |
| 10 | 3.0727 | 2.7692 | 2.7109 | 4.5182 | 3.0521 |
| 11 | 3.0727 | 2.8778 | 2.6886 | 4.0489 | 3.4168 |
| 12 | 3.0178 | 2.9321 | 2.6578 | 2.7869 | 2.9001 |
| 13 | 3.1276 | 3.095 | 2.7641 | 2.8395 | 3.0181 |
| 14 | 3.1276 | 2.3348 | 2.7435 | 2.8607 | 3.3065 |
| 15 | 3.2922 | 3.2579 | 2.9081 | 2.7566 | 3.3065 |
| 16 | 3.2922 | 2.7149 | 2.8172 | 3.1727 | 3.0476 |
| 17 | 3.0727 | 3.095 | 2.8704 | 3.2407 | 2.4577 |
| 18 | 4.0604 | 4.1267 | 3.786 | 3.7037 | 3.2442 |
| 19 | 4.225 | 4.0181 | 3.7209 | 4.213 | 3.8152 |
| 20 | 3.8409 | 3.5837 | 3.6214 | 3.5757 | 3.5608 |
| 21 | 3.2922 | 3.095 | 3.2922 | 2.9767 | 3.1276 |
| 22 | 3.1276 | 2.9321 | 2.9081 | 2.6326 | 2.34 |
| 23 | 2.963 | 2.3348 | 2.3594 | 2.2565 | 1.9839 |
| 24 | | 1.7558 | 2.1719 | 2.4691 | 2.364 |
| Max | 4.225 | 4.1267 | 3.786 | 4.5182 | 3.8152 |
| Min | 2.524 | 1.7558 | .463 | 2.073 | 1.9839 |
| Avg | 3.1189 | 2.7906 | 2.5966 | 3.0527 | 2.7882 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 402 / 33 KV VYAHAD

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.9204 | 1.8461 | 1.7558 | 1.8204 | 1.4243 |
| 2 | 1.7558 | 1.9547 | 1.6461 | 1.6461 | 1.3272 |
| 3 | 1.6461 | 1.9547 | 1.6461 | 1.8073 | 1.3735 |
| 4 | 1.5364 | 2.0633 | 1.6461 | 1.5947 | 1.2289 |
| 5 | 1.2071 | 2.1719 | 1.2243 | 1.7193 | 1.2717 |
| 6 | .6379 | 2.3348 | 2.1399 | 1.8804 | 1.3272 |
| 7 | .3841 | 1.9004 | 1.8656 | 1.5415 | 1.3272 |
| 8 | .3841 | 1.9004 | 1.8107 | 1.7541 | 1.2717 |
| 9 | .3292 | 2.009 | 1.9204 | 1.8073 | 1.5261 |
| 10 | .3292 | 2.009 | 2.3594 | 2.2028 | 1.7264 |
| 11 | | 2.1719 | 2.2497 | 2.1719 | 1.9839 |
| 12 | 2.1948 | 2.2805 | 2.4143 | 2.009 | 1.933 |
| 13 | 2.3594 | 2.6606 | 2.524 | 2.1948 | 1.7804 |
| 14 | 2.4143 | 2.1176 | 2.4143 | 2.2731 | 1.7295 |
| 15 | 2.4691 | 2.0633 | 2.4143 | 1.8656 | 1.9839 |
| 16 | 2.4691 | 2.0633 | 1.8656 | 1.6289 | 2.0348 |
| 17 | 2.5789 | 2.2805 | 2.5789 | 2.0633 | 2.0348 |
| 18 | 3.3471 | 2.8235 | 3.786 | 2.7109 | 2.6452 |
| 19 | 3.2373 | 3.2579 | 3.5665 | 2.7109 | 3.103 |
| 20 | 2.9081 | 2.552 | 2.8532 | 1.9879 | 2.7469 |
| 21 | 2.4691 | 2.009 | 1.9204 | 2.0416 | 1.933 |
| 22 | 1.8656 | 1.9004 | 1.8107 | 1.6478 | 1.6787 |
| 23 | 1.4266 | 1.7375 | 1.7558 | 1.4352 | 1.5261 |
| 24 | | 1.6461 | 1.7918 | 1.7558 | 1.5203 |
| Max | 3.3471 | 3.2579 | 3.786 | 2.7109 | 3.103 |
| Min | .3292 | 1.6461 | 1.2243 | 1.4352 | 1.2289 |
| Avg | 1.8123 | 2.1545 | 2.1650 | 1.9279 | 1.7682 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 404 / 33 KV RAJOLI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2658 | .2658 | .2126 | .1612 | .2743 |
| 2 | .2149 | .3189 | .1646 | .1629 | .3086 |
| 3 | .2715 | .2658 | .1595 | .1595 | .2543 |
| 4 | .2743 | .2658 | .1595 | .1595 | .2543 |
| 5 | .3326 | .3189 | .1595 | .1629 | .2543 |
| 6 | .3292 | .3189 | .2195 | .2172 | .3052 |
| 7 | .2743 | .2126 | .2126 | .2195 | .3052 |
| 8 | .3326 | .3721 | .2658 | .3292 | .3561 |
| 9 | .4344 | .3721 | .3189 | .2743 | .2458 |
| 10 | .5487 | .3721 | .439 | .439 | .4578 |
| 11 | .4938 | .3721 | .4938 | .3841 | .3932 |
| 12 | .4887 | .2658 | .4252 | .3841 | .407 |
| 13 | .4344 | .2658 | .3292 | .3801 | .407 |
| 14 | .4835 | .3189 | .4252 | .3761 | .407 |
| 15 | .4252 | .3721 | .4252 | .3258 | .407 |
| 16 | .4784 | .4252 | .3189 | .1612 | .4578 |
| 17 | .4784 | .4252 | .3189 | .4252 | .5087 |
| 18 | .4252 | .3841 | .4252 | .4784 | .4578 |
| 19 | .4207 | .3721 | .3721 | .5316 | .3932 |
| 20 | .3681 | .4252 | .3189 | .4784 | .2543 |
| 21 | .3721 | .3189 | .2658 | .3721 | .3052 |
| 22 | .3189 | .2658 | .2126 | .3224 | .3052 |
| 23 | .2686 | .2126 | .1595 | .3189 | .2543 |
| 24 | | .2658 | .2126 | .1595 | .2686 |
| Max | .5487 | .4252 | .4938 | .5316 | .5087 |
| Min | .2149 | .2126 | .1595 | .1595 | .2458 |
| Avg | .3798 | .3239 | .2923 | .3076 | .3434 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 405 / 33kv bembal feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .8059 | .6379 |
| 2 | .8145 | .6379 |
| 3 | .6984 | .691 |
| 4 | .6447 | .691 |
| 5 | .7522 | .691 |
| 6 | .8596 | .7973 |
| 7 | .9036 | .7442 |
| 8 | .7973 | .8505 |
| 9 | .8939 | |
| 10 | .9465 | |
| 11 | .8505 | |
| 12 | .9568 | |
| 13 | .9991 | |
| 14 | 1.0631 | |
| 15 | 1.1163 | |
| 16 | 1.1283 | |
| 17 | .9774 | |
| 18 | .6984 | |
| 19 | .7973 | |
| 20 | .7522 | |
| 21 | .7522 | |
| 22 | .6984 | |
| 23 | .7602 | |
| 24 | | .6984 |
| Max | 1.1283 | .8505 |
| Min | .6447 | .6379 |
| Avg | .8551 | .7155 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 406 / 33kv chuckpiranji feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3721 | .3224 | .3189 | .3086 | .3601 |
| 2 | .3224 | .3189 | .3189 | .3086 | .3601 |
| 3 | .3224 | .3189 | .3189 | .3601 | .3086 |
| 4 | .3721 | .3189 | .3189 | .3601 | .3086 |
| 5 | .3721 | .3721 | .3721 | .3086 | .3601 |
| 6 | .4207 | .4298 | .4252 | .3601 | .463 |
| 7 | .3721 | .3721 | .3721 | .3601 | .463 |
| 8 | .3761 | .4252 | .3721 | .3601 | .4115 |
| 9 | .3721 | .3721 | .439 | .4115 | .4115 |
| 10 | .4887 | .3721 | .4784 | .463 | .4115 |
| 11 | .4784 | .3721 | .4252 | .463 | .5144 |
| 12 | .4835 | .4252 | .4252 | .4115 | .463 |
| 13 | .4887 | .4298 | .3721 | .4115 | .463 |
| 14 | .4835 | .4835 | .2743 | .4115 | .463 |
| 15 | .4938 | .4298 | .4938 | .4115 | .463 |
| 16 | .4887 | .4298 | .4252 | .4115 | .4115 |
| 17 | .5487 | .4298 | .4252 | .463 | .4115 |
| 18 | .6984 | .6984 | .7442 | .7202 | .7202 |
| 19 | .7442 | .7973 | .7442 | .7202 | .7716 |
| 20 | .6984 | .6447 | .6379 | .6687 | .7202 |
| 21 | .5316 | .5373 | .5316 | .5144 | .5144 |
| 22 | .2103 | .4252 | .4252 | .3601 | .463 |
| 23 | .3681 | .3189 | .3189 | .3601 | .3086 |
| 24 | | .3224 | .3224 | .3189 | .3086 |
| Max | .7442 | .7973 | .7442 | .7202 | .7716 |
| Min | .2103 | .3189 | .2743 | .3086 | .3086 |
| Avg | .4568 | .4319 | .4292 | .4270 | .4523 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

MUL S/DN.[335]

BU 4335

Substation No/ Name :- 087014 / 132KV MUL

Feeder No / Name : 408 / 33 KV MUL 2 FEEDER

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 2.6578 | 2.6863 | 1.5123 | 2.572 | 1.5432 |
| 2 | 2.6046 | 2.7149 | 2.2325 | 2.4691 | 1.5432 |
| 3 | 2.6337 | 2.6863 | 2.1794 | 2.4691 | 1.4918 |
| 4 | 2.5514 | 2.5789 | 2.1262 | 2.4691 | 1.3889 |
| 5 | 2.4451 | 2.6063 | 1.701 | 2.5206 | 1.3889 |
| 6 | 2.4451 | 2.5789 | 2.6337 | 2.5206 | 1.6461 |
| 7 | 2.0199 | 2.2262 | 2.6578 | 2.4691 | 1.6461 |
| 8 | 1.9136 | 2.2262 | 2.6578 | 2.2119 | 1.749 |
| 9 | 1.701 | 2.1491 | 2.392 | 2.2634 | 1.9033 |
| 10 | 2.073 | 2.1719 | 2.2857 | 1.9033 | 2.1605 |
| 11 | 2.8532 | 2.8235 | 2.9235 | 2.1091 | 3.0864 |
| 12 | 3.0727 | 3.3665 | 3.083 | 2.0062 | 3.4465 |
| 13 | 3.2373 | 3.7466 | 3.786 | 1.8519 | 3.4465 |
| 14 | 3.2922 | 3.6923 | 3.6763 | 1.6461 | 3.4465 |
| 15 | 3.1824 | 3.638 | 3.6214 | 1.3889 | 3.4979 |
| 16 | 3.1893 | 3.546 | 3.6763 | 1.5432 | 3.3436 |
| 17 | 3.4551 | 3.638 | 3.6763 | 1.5947 | 3.3436 |
| 18 | 4.225 | 4.0724 | 4.4993 | 2.1605 | 3.7037 |
| 19 | 3.9506 | 3.8009 | 3.9506 | 2.4691 | 3.858 |
| 20 | 3.3471 | 2.7149 | 3.0727 | 2.3148 | 3.2407 |
| 21 | 2.7435 | 2.7149 | 3.0178 | 2.0062 | 2.4177 |
| 22 | 2.3594 | 2.7435 | 2.7435 | 1.6461 | 2.4691 |
| 23 | 2.7984 | 2.7692 | 2.4691 | 2.4691 | 2.5206 |
| 24 | | 2.7435 | 2.4434 | 2.7984 | 1.4403 |
| Max | 4.225 | 4.0724 | 4.4993 | 2.7984 | 3.858 |
| Min | 1.701 | 2.1491 | 1.5123 | 1.3889 | 1.3889 |
| Avg | 2.8153 | 2.9431 | 2.8757 | 2.1614 | 2.4884 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084007 / Vyahad sub Station

Feeder No / Name : 201 / 11 KV KISAN NAGER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .0914 | .0924 | .1097 | .0732 |
| 2 | .0914 | .0905 | .1097 | .0732 |
| 3 | .0924 | .0724 | .112 | .0724 |
| 4 | .0924 | .0732 | .1109 | .0724 |
| 5 | .1097 | .0943 | .0943 | .0914 |
| 6 | .128 | .1132 | .112 | .0943 |
| 7 | .1086 | .1132 | .112 | .1132 |
| 8 | .128 | .1132 | .1086 | .1307 |
| 9 | .1307 | .128 | .1086 | .1294 |
| 10 | .1494 | .1578 | .1663 | .1307 |
| 11 | .1294 | .124 | .128 | .168 |
| 12 | .1294 | .1478 | .1086 | .128 |
| 13 | .1267 | .1214 | .1086 | .0886 |
| 14 | .1029 | .1227 | .124 | .0876 |
| 15 | .0905 | .0983 | .0716 | .0716 |
| 16 | .0886 | .1294 | .0693 | .0848 |
| 17 | .1075 | .1294 | .1097 | .1017 |
| 18 | .168 | .1663 | .168 | .1494 |
| 19 | .1698 | .1509 | .1509 | .1509 |
| 20 | .1509 | .1509 | .1509 | .1509 |
| 21 | .1307 | .1132 | .1132 | .1132 |
| 22 | .1109 | .112 | .0934 | .0934 |
| 23 | .0914 | .1097 | .0943 | .0739 |
| 24 | .0914 | .0914 | .1109 | .0732 |
| Max | .1698 | .1663 | .168 | .168 |
| Min | .0886 | .0724 | .0693 | .0716 |
| Avg | .1171 | .1173 | .1144 | .1048 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084007 / Vyahad sub Station

Feeder No / Name : 202 / 11 KV KERODA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1595 | .1772 | .1578 | .1075 | .1227 |
| 2 | | .1772 | .1595 | .124 | .1227 |
| 3 | | .1772 | .1612 | .1417 | .1214 |
| 4 | | .181 | .1402 | .1829 | .1372 |
| 5 | | .1829 | .1463 | .2033 | .1387 |
| 6 | | .2033 | .1848 | .1646 | .156 |
| 7 | | .181 | .1646 | .1646 | .1478 |
| 8 | | .1578 | .1417 | .1612 | .1448 |
| 9 | | .1526 | .1433 | .1612 | .1612 |
| 10 | | .2012 | .1772 | .1509 | .1417 |
| 11 | | .1991 | .1734 | .1629 | .1886 |
| 12 | | .1791 | .1433 | .1791 | .2103 |
| 13 | | .181 | .1753 | .2058 | .2427 |
| 14 | | .1612 | .1772 | .1989 | .1543 |
| 15 | | .1578 | .128 | .2303 | .1677 |
| 16 | | .1341 | .1417 | .192 | .1638 |
| 17 | | .1677 | .1578 | .1781 | .1509 |
| 18 | | .3772 | .2829 | .3547 | .3734 |
| 19 | | .3961 | .2829 | .4251 | .415 |
| 20 | | .3018 | .3018 | .3018 | .3395 |
| 21 | | .2241 | .2402 | .2427 | .2614 |
| 22 | | .1867 | .1612 | .1829 | .1448 |
| 23 | | .1595 | .1063 | .124 | .1578 |
| 24 | | .1949 | .1612 | .1075 | .1227 |
| Max | .1595 | .3961 | .3018 | .4251 | .415 |
| Min | .1595 | .1341 | .1063 | .1075 | .1214 |
| Avg | .1595 | .2005 | .1754 | .1937 | .1870 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084007 / Vyahad sub Station

Feeder No / Name : 203 / 11 KV UPARI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .8871 | .7762 | .6722 | .6653 |
| 2 | | | .8871 | .7316 | .6099 | .6653 |
| 3 | | | .8871 | .7265 | .631 | .695 |
| 4 | | | .8501 | .7947 | .5487 | .695 |
| 5 | | | .9335 | .8316 | .5792 | .7468 |
| 6 | | | .9709 | .8962 | .5041 | .7468 |
| 7 | .5487 | | .7545 | .679 | .5121 | .6908 |
| 8 | | | .6979 | .695 | .5731 | .3258 |
| 9 | | | .7655 | .7316 | .591 | .6468 |
| 10 | | | .5975 | .8048 | .5853 | .6838 |
| 11 | | | .905 | .8501 | .6268 | .8507 |
| 12 | | | 1.0679 | .8871 | .6697 | .7316 |
| 13 | | | 1.086 | .8238 | .6626 | .7602 |
| 14 | | .9774 | .823 | 1.0029 | .6485 | .7265 |
| 15 | | | .7602 | .5373 | .5731 | .6447 |
| 16 | | | .7164 | .691 | .6697 | .7186 |
| 17 | | | .7421 | .9214 | .7316 | .6767 |
| 18 | | | .9896 | 1.3352 | 1.0562 | 1.1203 |
| 19 | | | 1.0562 | 1.1949 | 1.0751 | 1.1506 |
| 20 | | | .6979 | .9054 | .6413 | .6979 |
| 21 | | | .5281 | .4527 | .8865 | .5658 |
| 22 | | | .6348 | .5487 | .8029 | .7682 |
| 23 | | | .6468 | .5853 | .6722 | .7947 |
| 24 | | | .7392 | .695 | .6584 | .6722 |
| Max | .5487 | .9774 | 1.086 | 1.3352 | 1.0751 | 1.1506 |
| Min | .5487 | .9774 | .5281 | .4527 | .5041 | .3258 |
| Avg | .5487 | .9774 | .8177 | .7958 | .6742 | .7267 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084007 / Vyahad sub Station

Feeder No / Name : 401 / 33KV INCOMER -I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

| DATE | 15-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.4671 | 1.1884 | 1.1728 | 1.1703 |
| 2 | | 1.4566 | 1.1568 | 1.1395 | 1.2163 |
| 3 | | 1.4513 | 1.2147 | 1.1445 | 1.2626 |
| 4 | | 1.4238 | 1.3041 | 1.2565 | 1.3324 |
| 5 | | 1.5312 | 1.3846 | 1.2894 | 1.3575 |
| 6 | | 1.7284 | 1.5802 | 1.2626 | 1.4443 |
| 7 | | 1.3737 | 1.4211 | 1.182 | 1.3882 |
| 8 | | 1.3236 | 1.3443 | 1.3608 | 1.0525 |
| 9 | | 1.3555 | 1.3777 | 1.2951 | 1.3501 |
| 10 | | 1.4511 | 1.6879 | 1.6744 | 1.6 |
| 11 | | 1.6655 | 1.7541 | 1.4407 | 1.8551 |
| 12 | | 1.8817 | 1.8232 | 1.4918 | 1.7169 |
| 13 | | 1.9774 | 1.7684 | 1.5718 | 1.6301 |
| 14 | | 1.6159 | 1.7901 | 1.6564 | 1.5381 |
| 15 | | 1.4776 | 1.3169 | 1.5021 | 1.5396 |
| 16 | | 1.4937 | 1.6592 | 1.4927 | 1.6091 |
| 17 | 1.77 | 1.55 | 1.732 | 1.4199 | 1.4199 |
| 18 | | 2.3469 | 2.7055 | 2.4062 | 2.5206 |
| 19 | | 2.4982 | 2.7274 | 2.6326 | 2.6102 |
| 20 | | 1.9605 | 2.1901 | 1.9239 | 1.9239 |
| 21 | | 1.4227 | 1.3749 | 1.8185 | 1.4637 |
| 22 | | 1.2357 | 1.2841 | 1.4389 | 1.2917 |
| 23 | | 1.1884 | 1.142 | 1.1884 | 1.3093 |
| 24 | | 1.3198 | 1.1674 | 1.2294 | 1.1547 |
| Max | 1.77 | 2.4982 | 2.7274 | 2.6326 | 2.6102 |
| Min | 1.77 | 1.1884 | 1.142 | 1.1395 | 1.0525 |
| Avg | 1.77 | 1.5915 | 1.5873 | 1.4996 | 1.5315 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084031 / 33KV SUB STATION BEMBAL

Feeder No / Name : 201 / 11 KV BEMBAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2699 | .2232 | .2403 | .2261 |
| 2 | | .2646 | .2178 | .2288 | .2139 |
| 3 | | .2623 | .2116 | .2244 | .1576 |
| 4 | | .2604 | .2177 | .2379 | .2141 |
| 5 | | .2614 | .2254 | .2471 | .2234 |
| 6 | | .3384 | .3182 | .3478 | .3273 |
| 7 | | .3477 | .3252 | .3417 | .3342 |
| 8 | | .3497 | | .2984 | .3235 |
| 9 | | | .3756 | .366 | .3592 |
| 10 | | .4065 | .398 | .4912 | .4713 |
| 11 | | .4138 | .3929 | .4329 | .5006 |
| 12 | | .4148 | .4719 | .4334 | .4426 |
| 13 | | .4397 | .5654 | .4408 | .4496 |
| 14 | | .4634 | .5105 | .4701 | .4698 |
| 15 | | .4308 | .4933 | .5118 | |
| 16 | | .4334 | .4893 | .4495 | .5085 |
| 17 | | .4502 | .3952 | .3638 | .4555 |
| 18 | | .4845 | .5839 | .6025 | .5962 |
| 19 | | .5589 | .5761 | .5602 | .5851 |
| 20 | | .5024 | .5116 | .4795 | .5155 |
| 21 | | .376 | .4012 | .384 | .3928 |
| 22 | | .2797 | .2787 | .3137 | .2726 |
| 23 | .2756 | .2444 | .2517 | .2629 | .2403 |
| 24 | | .2736 | .2323 | .2411 | .2478 |
| Max | .2756 | .5589 | .5839 | .6025 | .5962 |
| Min | .2756 | .2444 | .2116 | .2244 | .1576 |
| Avg | .2756 | .3707 | .3768 | .3737 | .3708 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084031 / 33KV SUB STATION BEMBAL

Feeder No / Name : 202 / 11 KV GADISURLA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0991 | .4029 | .3487 | .3939 |
| 2 | | .0972 | .3969 | .3146 | .3909 |
| 3 | | | .3931 | .2586 | .3965 |
| 4 | | | .3957 | .2543 | .4021 |
| 5 | | | .4142 | .2481 | .4046 |
| 6 | | .0781 | .4335 | .274 | .4325 |
| 7 | | .0438 | .454 | .4027 | .3552 |
| 8 | | .0781 | | .4193 | .3756 |
| 9 | | | .3674 | .3347 | .3706 |
| 10 | | .1143 | .4419 | .3974 | .3708 |
| 11 | | .0991 | .4065 | .4169 | .3661 |
| 12 | | .0095 | .3901 | .3875 | .4184 |
| 13 | | .4392 | .4227 | .3635 | .3515 |
| 14 | | .4547 | .4086 | .4126 | .3654 |
| 15 | | .5126 | .36 | .4428 | |
| 16 | | .4915 | .2714 | .4634 | .4923 |
| 17 | | .5092 | .3621 | .4096 | .5091 |
| 18 | | .6238 | .5761 | .4453 | .6029 |
| 19 | | .6019 | .561 | .4724 | .5698 |
| 20 | | .6005 | .5027 | .546 | .4854 |
| 21 | | .5497 | .4222 | .514 | .485 |
| 22 | | .4722 | .3952 | .4646 | .4052 |
| 23 | .1067 | .4357 | .3794 | .3943 | .3807 |
| 24 | | .1029 | .4198 | .3718 | .3926 |
| Max | .1067 | .6238 | .5761 | .546 | .6029 |
| Min | .1067 | .0095 | .2714 | .2481 | .3515 |
| Avg | .1067 | .3207 | .4164 | .3899 | .4225 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084031 / 33KV SUB STATION BEMBAL

Feeder No / Name : 203 / 11 KV JUNASURLA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4249 | .1459 | .1487 | .1475 |
| 2 | | .4228 | .1406 | .1442 | .1444 |
| 3 | | .4197 | .1377 | .1374 | .1417 |
| 4 | | .4176 | .1399 | .1425 | .1526 |
| 5 | | .4509 | .1419 | .1493 | .1553 |
| 6 | | .5206 | .1656 | .1722 | .1681 |
| 7 | | .5159 | .1535 | .1684 | .1586 |
| 8 | | .5543 | | .0921 | .165 |
| 9 | | | .1609 | .1804 | .1645 |
| 10 | | .5824 | .1696 | .2038 | .1736 |
| 11 | | .6013 | .1854 | .2117 | .1951 |
| 12 | | .1436 | .1643 | .2234 | .1893 |
| 13 | | .1317 | .2067 | .2366 | .1897 |
| 14 | | .1177 | .2098 | .2366 | .2088 |
| 15 | | | .2291 | .2371 | |
| 16 | | .1985 | .2075 | .1994 | .1827 |
| 17 | | .2115 | .1671 | .2192 | .1758 |
| 18 | | .2399 | .2739 | .268 | .2435 |
| 19 | | .2385 | .2592 | .2471 | .2471 |
| 20 | | .2227 | .2392 | .2323 | .2251 |
| 21 | | .1925 | .2073 | .1898 | .1912 |
| 22 | | .1709 | .1595 | .1734 | .1533 |
| 23 | .4338 | .1671 | .1602 | .149 | .1522 |
| 24 | | .4286 | .1497 | .1531 | .149 |
| Max | .4338 | .6013 | .2739 | .268 | .2471 |
| Min | .4338 | .1177 | .1377 | .0921 | .1417 |
| Avg | .4338 | .3352 | .1815 | .1882 | .1771 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084031 / 33KV SUB STATION BEMBAL

Feeder No / Name : 402 / 33KV INCOMER BEMBAL

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .8374 |
| 2 | | | .8261 |
| 3 | | | .8139 |
| 4 | | | .8069 |
| 5 | | | .7897 |
| 6 | | | .8524 |
| 7 | | | .8786 |
| 8 | | | .9268 |
| 13 | 1.1874 | | |
| 23 | | .7888 | |
| 24 | | | .8497 |
| Max | 1.1874 | .7888 | .9268 |
| Min | 1.1874 | .7888 | .7897 |
| Avg | 1.1874 | .7888 | .8424 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084049 / 33kv Check piranji sub

station

Feeder No / Name : 201 / 11KV SAOLI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0093 | .0093 | .0093 | .0092 |
| 2 | | .0094 | .0093 | .0093 | .0093 |
| 3 | | .0113 | .0093 | .0093 | .0093 |
| 4 | | .0112 | .0093 | .0093 | .0149 |
| 5 | | .0112 | .0092 | .0093 | .0112 |
| 6 | | .0113 | .0093 | .0168 | .0113 |
| 7 | | .0113 | .0094 | .0094 | .0113 |
| 8 | | .0113 | .0093 | .0094 | .0094 |
| 9 | | | .0094 | .0093 | .0113 |
| 10 | | .0094 | .0113 | .0112 | .0111 |
| 11 | | .0075 | .0131 | .0131 | .0131 |
| 12 | | .0129 | .0094 | .0129 | .0148 |
| 13 | | .0092 | .0091 | .0093 | .0129 |
| 14 | | .011 | .0092 | .0092 | .011 |
| 15 | | .0093 | .0092 | .0092 | .0129 |
| 16 | | .0127 | .0091 | .0107 | .0124 |
| 17 | | .0123 | .0109 | .0125 | .0104 |
| 18 | | .0205 | .0205 | .0187 | .0185 |
| 19 | | .0207 | .0189 | .0189 | .0189 |
| 20 | | .017 | .017 | .0189 | .0189 |
| 21 | | .0151 | .0132 | .0151 | .0151 |
| 22 | | .0112 | .0113 | .0113 | .0132 |
| 23 | .0094 | .0093 | .0093 | .0093 | .0112 |
| 24 | | .0093 | .0093 | .0093 | .0092 |
| Max | .0094 | .0207 | .0205 | .0189 | .0189 |
| Min | .0094 | .0075 | .0091 | .0092 | .0092 |
| Avg | .0094 | .0119 | .0110 | .0117 | .0125 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084049 / 33kv Check piranji sub

station

Feeder No / Name : 202 / 11KV JIBGAON FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0066 | .0046 | .0048 | .0061 |
| 2 | | .0066 | .0046 | .0049 | .0064 |
| 3 | | .0067 | .0045 | .0048 | .0066 |
| 4 | | .0067 | .0045 | .0048 | .0067 |
| 5 | | .0069 | .0046 | .0049 | .0068 |
| 6 | | .0069 | .0064 | .0066 | .0069 |
| 7 | | .0083 | .0066 | .0066 | .0083 |
| 8 | | .0065 | .0047 | .0063 | .0082 |
| 9 | | .0084 | .0099 | .0099 | .0083 |
| 10 | | .0083 | .0078 | .0083 | .0083 |
| 11 | | .0078 | .008 | .0081 | .0082 |
| 12 | | .0097 | .0081 | .0091 | .0079 |
| 13 | | .0093 | .0094 | .0091 | .0098 |
| 14 | | .0111 | .0109 | .0095 | .0097 |
| 15 | | .0108 | .0095 | .0097 | .0077 |
| 16 | | .0075 | .0096 | .0076 | .0075 |
| 17 | | .0064 | .0081 | .0081 | .0077 |
| 18 | | .0128 | .0128 | .0127 | .0109 |
| 19 | | .0128 | .0129 | .0148 | .0129 |
| 20 | | .0107 | .011 | .0127 | .011 |
| 21 | | .0088 | .007 | .0105 | .0089 |
| 22 | | .0065 | .0049 | .0065 | .0066 |
| 23 | .0065 | .0062 | .0047 | .0062 | .0047 |
| 24 | | .0064 | .0046 | .0046 | .006 |
| Max | .0065 | .0128 | .0129 | .0148 | .0129 |
| Min | .0065 | .0062 | .0045 | .0046 | .0047 |
| Avg | .0065 | .0083 | .0075 | .0080 | .0080 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

CHANDRAPUR DIVSION[641]

SAOLI S/DN.[832]

BU 4832

Substation No/ Name :- 084049 / 33kv Check piranji sub

station

Feeder No / Name : 203 / 11 KV BOTHALI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0033 | .0016 | .0016 | .0016 |
| 2 | | .0034 | .0016 | .0016 | .0017 |
| 3 | | .0034 | .0015 | .0015 | .0017 |
| 4 | | .0034 | .0016 | .0016 | .0017 |
| 5 | | .0035 | .0016 | .0016 | .0035 |
| 6 | | .0035 | .0016 | .0017 | .0035 |
| 7 | | .0017 | .0017 | .0017 | .0018 |
| 8 | | .0016 | .0017 | .0016 | .0017 |
| 9 | | .0016 | .0018 | .0016 | .0017 |
| 10 | | .0016 | .0015 | .0016 | .0016 |
| 11 | | .0016 | .0014 | .0016 | .0015 |
| 12 | | .0016 | .0015 | .0015 | .0015 |
| 13 | | .0015 | .0015 | .0015 | .0016 |
| 14 | | .0016 | .0015 | .0016 | .0016 |
| 15 | | .0016 | .0015 | .0016 | .0016 |
| 16 | | .0015 | .003 | .0015 | .0016 |
| 17 | | .0015 | .003 | .0032 | .0029 |
| 18 | | .0055 | .0055 | .0055 | .0055 |
| 19 | | .0056 | .0075 | .0075 | .0057 |
| 20 | | .0055 | .0055 | .0055 | .0056 |
| 21 | | .0036 | .0036 | .0037 | .0037 |
| 22 | | .0034 | .0017 | .0017 | .0017 |
| 23 | .0032 | .0016 | .0016 | .0016 | .0017 |
| 24 | | .0032 | .0016 | .0016 | .0016 |
| Max | .0032 | .0056 | .0075 | .0075 | .0057 |
| Min | .0032 | .0015 | .0014 | .0015 | .0015 |
| Avg | .0032 | .0028 | .0024 | .0023 | .0024 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084001 / 33 KV CHANDANKHEDA S/S

Feeder No / Name : 201 / 11 KV CHANDANKHEDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4572 | .5921 | .4999 | .5312 |
| 2 | .4572 | .5992 | .4999 | .4999 |
| 3 | .4572 | .583 | .4999 | .4999 |
| 4 | .4572 | .583 | .4999 | .4999 |
| 5 | .4572 | .5735 | 1.2811 | .4999 |
| 6 | .4321 | .5407 | .5121 | .4999 |
| 7 | .5487 | .506 | .5937 | .5864 |
| 8 | .852 | .6722 | .8025 | .7716 |
| 9 | .9282 | .8848 | 1.1111 | .9998 |
| 10 | 1.0486 | 1.0364 | 1.1248 | 1.2483 |
| 11 | 1.1797 | .9831 | 1.0494 | 1.2334 |
| 12 | 1.3108 | 1.004 | 1.1574 | 1.2176 |
| 13 | 1.2944 | 1.3108 | 1.2346 | 1.2018 |
| 14 | 1.2651 | 1.3108 | 1.2498 | 1.1702 |
| 15 | 1.2809 | 1.2651 | 1.3123 | 1.1498 |
| 16 | 1.2809 | 1.3123 | 1.3283 | 1.1012 |
| 17 | 1.1142 | 1.2803 | 1.0623 | 1.0526 |
| 18 | 1.1142 | .9602 | | 1.0159 |
| 19 | 1.0277 | .9717 | .9831 | .9614 |
| 20 | .9259 | .9069 | .9069 | .9175 |
| 21 | .8383 | .7449 | .6958 | .8259 |
| 22 | .7811 | .6478 | .6642 | .7287 |
| 23 | .6636 | .583 | .5624 | .5921 |
| 24 | .4877 | .5569 | .5312 | |
| Max | 1.3108 | 1.3123 | 1.3283 | 1.2483 |
| Min | .4321 | .506 | .4999 | .4999 |
| Avg | .8608 | .8504 | .8766 | .8611 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084001 / 33 KV CHANDANKHEDA S/S

Feeder No / Name : 202 / 11 KV TADOBA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1981 | .16 | .1715 | .1619 |
| 2 | .1875 | .1581 | .1715 | .1619 |
| 3 | .1943 | .16 | .1715 | .1619 |
| 4 | .2012 | .176 | .1715 | .1619 |
| 5 | .2012 | .1943 | .1715 | .1619 |
| 6 | .2012 | .1898 | .1734 | .2347 |
| 7 | .2058 | .2105 | .1966 | .2294 |
| 8 | .2401 | .208 | .216 | .2561 |
| 9 | .2561 | .208 | .2469 | .2915 |
| 10 | .2372 | .213 | .2469 | .2812 |
| 11 | .2372 | .2058 | .2439 | .2846 |
| 12 | .2214 | .1715 | .2591 | .2846 |
| 13 | .2374 | .2294 | .2743 | .2688 |
| 14 | .2187 | .2294 | .2743 | .2688 |
| 15 | .2214 | .2347 | .2743 | .2785 |
| 16 | .2214 | .2641 | .2439 | .2622 |
| 17 | .2652 | .2743 | .2347 | .2713 |
| 18 | .3121 | .2774 | .2865 | .2883 |
| 19 | .3506 | .2949 | .3224 | .3077 |
| 20 | .2675 | .2622 | .2481 | .2622 |
| 21 | .2408 | .2683 | .2126 | .2429 |
| 22 | .2286 | .2401 | .1715 | .213 |
| 23 | .1981 | .2058 | .1677 | .1966 |
| 24 | .2 | .1467 | .2058 | .1619 |
| Max | .3506 | .2949 | .3224 | .3077 |
| Min | .1875 | .1467 | .1677 | .1619 |
| Avg | .2310 | .2159 | .2232 | .2372 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084001 / 33 KV CHANDANKHEDA S/S

Feeder No / Name : 203 / 11 KV ASHTA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1429 | .208 | .1957 | .1981 |
| 2 | .1429 | .208 | .1957 | .1981 |
| 3 | .1486 | .2187 | .1957 | .1981 |
| 4 | .1486 | .2187 | .1957 | .1981 |
| 5 | | .2343 | .1957 | .1981 |
| 6 | | .253 | .1981 | .1957 |
| 7 | | .2688 | .208 | .2439 |
| 8 | .1486 | .3125 | .2934 | .2743 |
| 9 | .1524 | .3795 | .2934 | .3086 |
| 10 | .2688 | .3652 | .2494 | .3048 |
| 11 | .3479 | .3913 | .3064 | .2846 |
| 12 | .4161 | .3864 | .3334 | .253 |
| 13 | .4531 | .3963 | .3567 | .2214 |
| 14 | .442 | .3658 | .3292 | .1739 |
| 15 | .4365 | .3814 | .3155 | .208 |
| 16 | .4365 | .3814 | .3201 | .2543 |
| 17 | .4641 | .3567 | .3572 | .285 |
| 18 | .431 | .3567 | .4108 | .3222 |
| 19 | .4144 | .3658 | .4062 | .3467 |
| 20 | .3567 | .3048 | .3898 | .3277 |
| 21 | .3269 | .2743 | .3224 | .2785 |
| 22 | .3048 | .2439 | .2469 | .2267 |
| 23 | .2439 | .2107 | .216 | .1619 |
| 24 | .1334 | .1932 | .2107 | .2006 |
| Max | .4641 | .3963 | .4108 | .3467 |
| Min | .1334 | .1932 | .1957 | .1619 |
| Avg | .3029 | .3031 | .2809 | .2443 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084022 / 33 KV VIJASAN

Feeder No / Name : 201 / 11 KV GHODPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2713 | .2012 | .3052 | .1823 |
| 2 | | .2743 | .2012 | .2883 | .1658 |
| 3 | | .2572 | .1823 | .2683 | .1638 |
| 4 | | .2543 | .1823 | .2683 | .1802 |
| 5 | | .2543 | .2012 | .2543 | .2155 |
| 6 | | .2743 | .2374 | .2713 | .2515 |
| 7 | | .2915 | .2713 | .2543 | .3052 |
| 8 | | .3086 | .3086 | .2818 | .3429 |
| 9 | | .2883 | .2915 | .285 | .3258 |
| 10 | .3641 | .285 | .2713 | .2743 | .3052 |
| 11 | .3429 | .2713 | .2543 | .2629 | .2883 |
| 12 | .3222 | .2743 | .2515 | .2658 | .2543 |
| 13 | .3222 | .2572 | .2347 | .2454 | .2543 |
| 14 | .3429 | | .1989 | .2401 | .2683 |
| 15 | .3601 | | .2543 | .2254 | .2543 |
| 16 | .3561 | .285 | .2652 | .2229 | .2713 |
| 17 | .373 | .3018 | .3018 | .2774 | .2743 |
| 18 | .3601 | .3429 | .3018 | .3506 | .2713 |
| 19 | .3429 | .4031 | .2883 | .3721 | .2883 |
| 20 | .3601 | .3721 | .2883 | .3366 | .2683 |
| 21 | .3052 | .3544 | .2883 | .2947 | .2515 |
| 22 | .2743 | .3121 | .3086 | .2543 | .2321 |
| 23 | .2915 | .2572 | .3222 | .218 | .2155 |
| 24 | | .2743 | .2012 | .3222 | .1823 |
| Max | .373 | .4031 | .3222 | .3721 | .3429 |
| Min | .2743 | .2543 | .1823 | .218 | .1638 |
| Avg | .3370 | .2939 | .2545 | .2766 | .2505 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084022 / 33 KV VIJASAN

Feeder No / Name : 203 / 11 KV GOURALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.0174 | .7865 | .9431 | .8383 |
| 2 | | .9326 | .7537 | .9431 | .7956 |
| 3 | | .9221 | .7287 | .8573 | .7459 |
| 4 | | .9221 | .7287 | .8478 | .7865 |
| 5 | | 1.0288 | .779 | .763 | .8288 |
| 6 | | .9326 | .8478 | .8478 | .9221 |
| 7 | | 1.0059 | .9602 | .9326 | 1.0174 |
| 8 | | 1.0174 | .7186 | 1.0288 | 1.0974 |
| 9 | | .9835 | .7888 | 1.0174 | 1.0513 |
| 10 | 1.1145 | .9221 | .7975 | 1.0227 | 1.0395 |
| 11 | 1.1191 | .8718 | .7282 | 1.0562 | .9945 |
| 12 | 1.0852 | .8573 | .8573 | 1.0852 | .9831 |
| 13 | 1.1022 | 1.046 | .9536 | 1.1022 | 1.0159 |
| 14 | 1.2003 | 1.0682 | 1.0288 | 1.073 | 1.0562 |
| 15 | 1.2003 | 1.0898 | 1.0174 | 1.0774 | 1.0277 |
| 16 | 1.2003 | 1.1603 | 1.0631 | 1.0978 | 1.0562 |
| 17 | 1.286 | 1.2308 | 1.046 | 1.2071 | 1.0608 |
| 18 | 1.1869 | 1.3077 | 1.0513 | 1.3375 | 1.0774 |
| 19 | 1.1736 | 1.4217 | 1.0682 | 1.439 | 1.1603 |
| 20 | 1.1022 | 1.3643 | 1.1145 | 1.4022 | 1.1469 |
| 21 | 1.0059 | 1.2971 | 1.2003 | 1.2346 | .9831 |
| 22 | 1.0174 | 1.166 | 1.0174 | 1.073 | .8192 |
| 23 | 1.0174 | .9389 | 1.0174 | .8619 | .7865 |
| 24 | | 1.0288 | .8029 | .9431 | .8097 |
| Max | 1.286 | 1.4217 | 1.2003 | 1.439 | 1.1603 |
| Min | 1.0059 | .8573 | .7186 | .763 | .7459 |
| Avg | 1.1294 | 1.0639 | .9107 | 1.0497 | .9625 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084022 / 33 KV VIJASAN

Feeder No / Name : 205 / 11KV MOHBALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2883 | .2949 | .3429 | .2561 |
| 2 | | .2713 | .2785 | .3391 | .2401 |
| 3 | | .2683 | .2753 | .3052 | .2401 |
| 4 | | .2515 | .2591 | .3052 | .2429 |
| 5 | | .2713 | .2949 | .3391 | .2622 |
| 6 | | .2743 | .3277 | .3521 | .2818 |
| 7 | | .285 | .3768 | .3688 | .3353 |
| 8 | | .2883 | .426 | .3978 | .373 |
| 9 | | .3018 | .4096 | .4144 | .3391 |
| 10 | .3052 | .3277 | .3315 | .426 | .3018 |
| 11 | .3258 | .3725 | | .4424 | .2818 |
| 12 | .3258 | .3953 | | .4534 | .2652 |
| 13 | .3222 | .3841 | | .4696 | |
| 14 | .3391 | .3605 | .3605 | .4801 | |
| 15 | .3601 | .2486 | .5243 | .4481 | |
| 16 | .3772 | .2486 | .5087 | .4161 | .4973 |
| 17 | .3185 | .2486 | .5658 | .4424 | .4694 |
| 18 | .3391 | .3018 | .5087 | .4748 | .4694 |
| 19 | .3353 | .3772 | .5087 | .4458 | .4527 |
| 20 | .3052 | .4031 | .4917 | .4334 | .4359 |
| 21 | .3018 | .3856 | .4458 | .3944 | .4239 |
| 22 | .2883 | .3185 | .4458 | .3353 | .3149 |
| 23 | .2883 | | .4239 | .2753 | .213 |
| 24 | | .2915 | .2622 | .407 | .2561 |
| Max | .3772 | .4031 | .5658 | .4801 | .4973 |
| Min | .2883 | .2486 | .2591 | .2753 | .213 |
| Avg | .3237 | .3115 | .3962 | .3962 | .3310 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 084022 / 33 KV VIJASAN

Feeder No / Name : 403 / 33 KV vijason to PGCL
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2658 | | .3721 | .3721 |
| 2 | | .3189 | | .3224 | .3189 |
| 3 | | .3155 | | .2686 | .3155 |
| 4 | | .3155 | | .2715 | .2629 |
| 5 | | .2601 | | .2715 | .2658 |
| 6 | | .2601 | | .2715 | .3155 |
| 7 | | .3155 | | .3224 | .3189 |
| 8 | | .3121 | | .3224 | .3681 |
| 9 | | .3155 | .3681 | .3189 | .3155 |
| 10 | .2572 | .3155 | .3681 | .3189 | .3681 |
| 11 | .2601 | .3189 | .3155 | .3189 | .3721 |
| 12 | .208 | .3189 | .3189 | .3189 | .3721 |
| 13 | .208 | .3189 | .3189 | .3189 | .3721 |
| 14 | .2058 | .3189 | .3721 | .3681 | .3189 |
| 15 | .208 | .3721 | .3721 | .3721 | .3189 |
| 16 | .2629 | .3681 | .3155 | .3721 | .3761 |
| 17 | .2629 | .3681 | .3189 | .3721 | .3189 |
| 18 | .2658 | .3681 | .3189 | .3721 | .3721 |
| 19 | .2658 | .3641 | .3189 | .4207 | .3721 |
| 20 | .2686 | .3641 | .3721 | .4161 | .3721 |
| 21 | .3189 | .3681 | .3681 | .3681 | .3721 |
| 22 | .3189 | | .3681 | .3189 | .4207 |
| 23 | .3189 | | .3721 | .3189 | .3681 |
| 24 | | .2658 | .3681 | .3721 | .3681 |
| Max | .3189 | .3721 | .3721 | .4207 | .4207 |
| Min | .2058 | .2601 | .3155 | .2686 | .2629 |
| Avg | .2593 | .3231 | .3472 | .3370 | .3465 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 085002 / 66 KV BHANDAK S/S

Feeder No / Name : 202 / 11 KV BHANDAK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.1616 | .8669 | .8669 | 1.0923 | .7282 | 1.0749 | .8669 |
| 2 | 1.1443 | .8322 | .8842 | 1.0576 | .6935 | 1.0402 | .8149 |
| 3 | 1.1096 | .8149 | .8842 | 1.0402 | .7282 | 1.0056 | .7975 |
| 4 | 1.0749 | .7802 | .8495 | 1.0229 | .7628 | .9709 | .8149 |
| 5 | 1.0402 | .8669 | .8669 | 1.0056 | .8149 | .9189 | .8322 |
| 6 | .9882 | .9882 | .8842 | .9882 | .8842 | .8842 | .9015 |
| 7 | 1.1616 | 1.1269 | .9536 | 1.0923 | 1.0229 | .9882 | .9882 |
| 8 | 1.1096 | 1.0229 | 1.0749 | | 1.0229 | .9362 | 1.0749 |
| 9 | 1.0749 | 1.0749 | 1.0749 | 1.0749 | 1.0923 | 1.0229 | 1.1269 |
| 10 | 1.0749 | 1.1616 | 1.1269 | 1.0923 | 1.1269 | 1.0749 | 1.1096 |
| 11 | 1.1269 | 1.1443 | 1.1616 | 1.1096 | 1.1616 | 1.0576 | 1.0576 |
| 12 | 1.1096 | 1.0923 | 1.1269 | .9362 | .9882 | .9536 | .9709 |
| 13 | 1.0576 | 1.1096 | 1.0576 | .9536 | .9015 | .9536 | .9015 |
| 14 | 1.0229 | 1.0229 | .9536 | .9015 | .8842 | .9362 | .9189 |
| 15 | .9536 | 1.0402 | .9882 | .9709 | .8322 | .9189 | .9015 |
| 16 | 1.0402 | 1.1269 | 1.0402 | 1.0056 | 1.0056 | .9536 | .9362 |
| 17 | 1.0923 | 1.0402 | 1.1616 | 1.0923 | 1.0749 | .9536 | 1.0923 |
| 18 | 1.5083 | 1.4737 | 1.4043 | 1.4563 | 1.4217 | 1.2309 | 1.387 |
| 19 | 1.439 | 1.5604 | 1.5083 | 1.4217 | 1.439 | 1.387 | 1.4217 |
| 20 | 1.4043 | 1.4563 | 1.4217 | 1.3696 | 1.3523 | 1.387 | 1.387 |
| 21 | 1.283 | 1.3176 | 1.283 | 1.2309 | 1.2483 | 1.283 | 1.1269 |
| 22 | 1.1269 | 1.1789 | 1.1443 | 1.0402 | 1.2136 | 1.0923 | 1.0576 |
| 23 | .9882 | 1.0229 | 1.1096 | | 1.1789 | .9015 | 1.0576 |
| 24 | 1.1616 | .9362 | .9189 | 1.0923 | .7628 | 1.1269 | .8842 |
| Max | 1.5083 | 1.5604 | 1.5083 | 1.4563 | 1.439 | 1.387 | 1.4217 |
| Min | .9536 | .7802 | .8495 | .9015 | .6935 | .8842 | .7975 |
| Avg | 1.1356 | 1.0858 | 1.0728 | 1.0930 | 1.0142 | 1.0439 | 1.0179 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 085002 / 66 KV BHANDAK S/S

Feeder No / Name : 203 / 11 KV NTPC SPARE FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2445 | .8939 | .9036 | .9568 | .7087 | .9391 | .7796 |
| 2 | 1.2269 | .8589 | .9036 | .9036 | .6733 | .9214 | .7442 |
| 3 | 1.2094 | .8413 | .8859 | .8859 | .6379 | .9036 | .7087 |
| 4 | 1.1919 | .8063 | .8505 | .8682 | .6733 | .8859 | .7442 |
| 5 | 1.1744 | .8764 | .8682 | .8505 | .7087 | .8682 | .7265 |
| 6 | 1.1744 | .9465 | .9036 | .8505 | .8328 | .8328 | .7619 |
| 7 | 1.1043 | 1.0867 | .9568 | .8859 | .8328 | .8505 | .8859 |
| 8 | 1.3847 | 1.4352 | 1.2048 | 1.2757 | 1.0808 | 1.0454 | 1.0985 |
| 9 | 1.7703 | 1.5769 | 1.5061 | 1.4175 | 1.3289 | 1.1163 | .9568 |
| 10 | 1.8229 | 1.5592 | 1.6301 | 1.5415 | 1.2403 | 1.3466 | 1.5769 |
| 11 | 1.858 | 1.5238 | 1.7364 | 1.5061 | 1.2934 | 1.4883 | 1.4529 |
| 12 | 1.7002 | 1.5592 | 1.1163 | .6024 | 1.4175 | 1.4175 | 1.701 |
| 13 | 1.9982 | 1.6832 | 1.5238 | 1.1694 | .9391 | .5493 | 1.1163 |
| 14 | 2.2085 | 1.701 | 1.6655 | 1.2048 | | 1.2934 | 1.3112 |
| 15 | 2.1033 | 1.6301 | 1.8427 | 1.701 | .9922 | 1.4175 | .9568 |
| 16 | 1.9105 | 1.5061 | | 1.7541 | .7973 | 1.3466 | 1.134 |
| 17 | 1.9281 | 1.4175 | 1.5769 | 1.6655 | 1.9845 | 1.6478 | 1.5769 |
| 18 | 1.6476 | 1.2757 | 1.382 | 1.3289 | 1.3112 | 1.2757 | 1.258 |
| 19 | 1.5424 | 1.2403 | 1.3112 | 1.258 | 1.258 | 1.2048 | 1.2403 |
| 20 | 1.4198 | 1.134 | 1.2757 | 1.1163 | 1.134 | 1.1163 | 1.2048 |
| 21 | 1.1043 | 1.0808 | 1.1163 | 1.0277 | .9922 | .9568 | 1.0985 |
| 22 | 1.0166 | .9922 | .9922 | .9214 | .9745 | .8682 | .8505 |
| 23 | .9465 | .9568 | .9745 | .7973 | .9568 | .7087 | .8505 |
| 24 | 1.2445 | .9114 | .9214 | .9568 | .815 | .9568 | .7619 |
| Max | 2.2085 | 1.701 | 1.8427 | 1.7541 | 1.9845 | 1.6478 | 1.701 |
| Min | .9465 | .8063 | .8505 | .6024 | .6379 | .5493 | .7087 |
| Avg | 1.4972 | 1.2289 | 1.2195 | 1.1436 | 1.0254 | 1.0816 | 1.0624 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 085002 / 66 KV BHANDAK S/S

Feeder No / Name : 204 / 11 KV Ord. Factory-1
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .6668 | .4001 | .2858 | .4001 | .2858 | .2286 | .4572 |
| 2 | .6478 | .381 | .2477 | .4001 | .2858 | .2096 | .4001 |
| 3 | .6478 | .2477 | .2858 | .4191 | .2477 | .2096 | .3429 |
| 4 | .6287 | .1524 | .2858 | .4382 | .2858 | .2286 | .381 |
| 5 | .6097 | .2096 | .2477 | .4572 | .2477 | .2477 | .4191 |
| 6 | .5906 | .2286 | .3239 | .4763 | .2858 | .2858 | .4763 |
| 7 | .6668 | | .381 | .3239 | .3239 | .3239 | .381 |
| 8 | .743 | .4001 | .381 | .6097 | .5335 | .5335 | .5906 |
| 9 | 1.1622 | 1.0098 | .381 | 1.1812 | 1.0098 | 1.1431 | 1.2003 |
| 10 | 1.6956 | 1.848 | .4191 | 1.6004 | 1.6004 | 1.5623 | 1.7909 |
| 11 | 1.467 | 1.6766 | .381 | 1.6194 | 1.6004 | 1.3717 | 1.7528 |
| 12 | .724 | .8383 | .3239 | .9717 | .8383 | .7621 | .7811 |
| 13 | .5906 | .4191 | .2858 | .7049 | .5335 | .5335 | .5906 |
| 14 | .6287 | .4572 | .2477 | .6287 | .4954 | .6287 | .6287 |
| 15 | .9145 | .7621 | .2858 | .9717 | .8383 | .8573 | .7621 |
| 16 | .8383 | .8954 | .2477 | .9907 | .9145 | .7811 | 1.086 |
| 17 | .6287 | .5906 | .2858 | .5906 | .4954 | .6668 | .5906 |
| 18 | .4572 | .381 | .2477 | .3239 | .2858 | .4191 | .3239 |
| 19 | .4763 | .2858 | .2858 | .3239 | .2477 | .5144 | .2858 |
| 20 | .4191 | .2477 | .2477 | .2858 | .2286 | .4572 | .2477 |
| 21 | .4572 | .2858 | .2477 | .2858 | .2477 | .4763 | .2286 |
| 22 | .4954 | .3239 | .4382 | .2858 | .2477 | .5144 | .4954 |
| 23 | .4191 | .2858 | .4191 | .3239 | .2286 | .4763 | .4572 |
| 24 | .6668 | .362 | .2858 | .4001 | .2858 | .2286 | .4763 |
| Max | 1.6956 | 1.848 | .4382 | 1.6194 | 1.6004 | 1.5623 | 1.7909 |
| Min | .4191 | .1524 | .2477 | .2858 | .2286 | .2096 | .2286 |
| Avg | .7184 | .5517 | .3112 | .6255 | .5247 | .5692 | .6311 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

BHADRAVATI URBAN SDN[333] BU 2186

Substation No/ Name :- 085002 / 66 KV BHANDAK S/S

Feeder No / Name : 205 / 11 KV ORDNANCE FACTORY -II NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .8383 | .4954 | .2096 | .7621 | .2858 | .7049 | .5335 |
| 2 | .8383 | .4191 | .2858 | .8002 | .2667 | .6668 | .4572 |
| 3 | .8192 | .3429 | .2667 | .8383 | .3239 | .6097 | .4382 |
| 4 | .8002 | .3239 | .3048 | .8764 | .381 | .5906 | .4001 |
| 5 | .8002 | .4572 | .3239 | .9335 | .4572 | .5335 | .6287 |
| 6 | .8002 | .724 | .5906 | 1.0479 | .7621 | .7811 | .9145 |
| 7 | 1.2384 | 1.1812 | .6859 | 1.2384 | 1.2384 | 1.2193 | 1.2384 |
| 8 | .7811 | | .7811 | .743 | .8002 | .8192 | .8192 |
| 9 | .5906 | .6287 | .743 | .6668 | .7049 | .6859 | .8192 |
| 10 | .724 | .8192 | .8383 | .7811 | .743 | .8764 | .8954 |
| 11 | .7049 | .8573 | .8002 | .4572 | .7811 | .8573 | .8954 |
| 12 | .6287 | .7621 | .6859 | .6859 | .7621 | .743 | .6859 |
| 13 | .381 | .6859 | .6287 | .7049 | .5335 | .4572 | .5906 |
| 14 | .2858 | .4954 | .5335 | .5906 | .4191 | .4191 | .381 |
| 15 | .4191 | .4954 | .4572 | .6287 | .4954 | .3239 | .4191 |
| 16 | .381 | .4572 | .4954 | .4572 | .2858 | .381 | .6287 |
| 17 | .4954 | .4572 | .4572 | .4191 | .4572 | .4954 | .5335 |
| 18 | 1.0098 | .8002 | .8383 | .8954 | .9335 | .7811 | .9335 |
| 19 | 1.0098 | 1.0288 | .9717 | .9335 | 1.0479 | 1.105 | .9717 |
| 20 | .8383 | .8954 | .8383 | .8764 | .8573 | .9335 | .9907 |
| 21 | .7811 | .8764 | .7811 | .8383 | .8383 | .8954 | .9145 |
| 22 | .8383 | .9145 | .8002 | .7621 | .8002 | | .9145 |
| 23 | .6287 | .6859 | .8002 | .724 | .7621 | .7049 | .9145 |
| 24 | .8383 | .5906 | .3239 | .7621 | .3239 | .724 | .6097 |
| Max | 1.2384 | 1.1812 | .9717 | 1.2384 | 1.2384 | 1.2193 | 1.2384 |
| Min | .2858 | .3239 | .2096 | .4191 | .2667 | .3239 | .381 |
| Avg | .7279 | .6693 | .6017 | .7676 | .6359 | .7091 | .7303 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 201 / 11 KV NERI -U-

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1886 | .1886 | .1886 | .1886 |
| 2 | .1886 | .1886 | .1886 | .1886 |
| 3 | .1886 | .1886 | .1886 | .1698 |
| 4 | .1886 | .1698 | .1698 | .1698 |
| 5 | .2263 | .1886 | .1886 | .1886 |
| 6 | | .2263 | .1886 | .2263 |
| 7 | .2641 | .2587 | .2614 | .2241 |
| 8 | .2241 | .2218 | .2241 | .2614 |
| 9 | .2614 | .2218 | .2614 | .2614 |
| 10 | .3734 | .2561 | .2561 | .2561 |
| 11 | .3734 | .2195 | .2561 | .4024 |
| 12 | .3734 | .2561 | .2926 | .2195 |
| 13 | .2241 | .2561 | .2926 | .2195 |
| 14 | .3734 | .2561 | .2195 | .2561 |
| 15 | .3361 | .2195 | .2561 | .2561 |
| 16 | .3361 | .2561 | .2561 | .2561 |
| 17 | .3361 | .2561 | .2561 | .2195 |
| 18 | .4854 | .3326 | .3361 | .3734 |
| 19 | .3734 | .3361 | .3361 | .3734 |
| 20 | .3361 | .3361 | .2987 | .3734 |
| 21 | .2987 | .2987 | .2987 | .2987 |
| 22 | .2801 | .2614 | .2801 | .2614 |
| 23 | .1886 | .1886 | .1886 | .2195 |
| 24 | .1886 | .1886 | .1886 | .1509 |
| Max | .4854 | .3361 | .3361 | .4024 |
| Min | .1886 | .1698 | .1698 | .1509 |
| Avg | .2873 | .2404 | .2447 | .2506 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 202 / 11 KV SAWARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4382 | .4191 | .4001 | .381 |
| 2 | .4191 | .4001 | .4001 | .381 |
| 3 | .4191 | .4001 | .381 | .362 |
| 4 | .4191 | .381 | .381 | .362 |
| 5 | .4954 | .4191 | .4572 | .4191 |
| 6 | .5716 | .3429 | .5716 | .4954 |
| 7 | .4572 | .5335 | .5335 | .5335 |
| 16 | .4191 | .4191 | .4191 | .4191 |
| 17 | .4191 | .4572 | .4191 | .4572 |
| 18 | .8002 | .8002 | .9145 | .8383 |
| 19 | .9526 | .9145 | .9526 | .9526 |
| 20 | .8002 | | .8764 | .9526 |
| 21 | .6859 | .6097 | .724 | |
| 22 | .5335 | .5335 | .5906 | |
| 23 | .4572 | .4191 | .4572 | |
| 24 | .4572 | .4191 | .4191 | .4191 |
| Max | .9526 | .9145 | .9526 | .9526 |
| Min | .4191 | .3429 | .381 | .362 |
| Avg | .5465 | .4979 | .5561 | .5364 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 203 / 11 KV MAHALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .2477 | .2096 | .2096 | .2286 |
| 2 | .2286 | .2096 | .2096 | .2096 |
| 3 | .2286 | .2096 | .2096 | .2096 |
| 4 | .2286 | .1905 | .2286 | .1905 |
| 5 | .3048 | .2286 | .2286 | .2286 |
| 6 | .381 | .3429 | .3429 | .3048 |
| 7 | .3048 | .3429 | .3048 | .3048 |
| 8 | .3429 | .3429 | .2401 | .2804 |
| 9 | .4115 | .4115 | .3086 | .4207 |
| 10 | .4108 | .439 | .4024 | .439 |
| 11 | .3734 | .4024 | | .4024 |
| 12 | .4481 | .439 | .3658 | .439 |
| 13 | .4805 | .3658 | .3658 | .4024 |
| 14 | .4854 | .439 | .4024 | .439 |
| 15 | .3734 | .4024 | .3658 | .3658 |
| 16 | .1524 | .1143 | .1143 | .1524 |
| 17 | .1524 | .1524 | .1524 | .1905 |
| 18 | .4572 | .4954 | .5716 | .5335 |
| 19 | .6097 | .6097 | .6097 | .6478 |
| 20 | .4954 | .5716 | .5716 | .5716 |
| 21 | .4191 | .381 | .4572 | .2241 |
| 22 | .3048 | .3048 | .3239 | .2241 |
| 23 | .2286 | .2286 | .2286 | .1829 |
| 24 | .2667 | .2286 | .2286 | .2286 |
| Max | .6097 | .6097 | .6097 | .6478 |
| Min | .1524 | .1143 | .1143 | .1524 |
| Avg | .3474 | .3359 | .3236 | .3259 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 204 / 11 KV WADALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1698 | .1509 | .1509 | .1494 |
| 2 | .1698 | .1509 | .1509 | .1307 |
| 3 | .1509 | .1509 | .1509 | .1307 |
| 4 | .1509 | .1509 | .1509 | .1307 |
| 5 | .1698 | .1509 | .1509 | .1494 |
| 6 | | .1886 | .1886 | .168 |
| 7 | .2987 | .3142 | .2427 | .2614 |
| 8 | .2801 | .2587 | .2614 | .2427 |
| 9 | .3174 | .2587 | .2241 | .2427 |
| 10 | .2987 | .2743 | .2378 | .2012 |
| 11 | .2241 | .2012 | .2561 | .2378 |
| 12 | .2054 | .1829 | .2195 | .2195 |
| 13 | .1867 | .1829 | .1646 | .1829 |
| 14 | .1867 | .2012 | .1646 | .1463 |
| 15 | .2054 | .2195 | .1646 | .1646 |
| 16 | .2427 | .2195 | .1829 | .1646 |
| 17 | .2241 | .2012 | .2195 | .2378 |
| 18 | .2987 | .2987 | .2987 | .2801 |
| 19 | .2801 | .2801 | .2801 | .2614 |
| 20 | .2587 | .2614 | .2801 | .2614 |
| 21 | .2427 | .2241 | .2427 | .2614 |
| 22 | .2241 | .2054 | .2241 | .2241 |
| 23 | .1698 | .1494 | .1698 | .1646 |
| 24 | .1698 | .1509 | .1509 | .1494 |
| Max | .3174 | .3142 | .2987 | .2801 |
| Min | .1509 | .1494 | .1509 | .1307 |
| Avg | .2228 | .2095 | .2053 | .1985 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 205 / 11 KV CHIMUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3921 | .2263 | .3584 | .3734 |
| 2 | .3734 | .2263 | .3584 | .3734 |
| 3 | .3734 | .2075 | .3395 | .3734 |
| 4 | .3547 | .2075 | .3395 | .3547 |
| 5 | .4108 | .2263 | .3772 | .3734 |
| 6 | .4854 | .3395 | .4527 | .4481 |
| 7 | .5601 | .4024 | .5544 | .5228 |
| 8 | .5228 | .3292 | .3326 | .5601 |
| 9 | .5228 | .3292 | .4066 | .5601 |
| 10 | .4108 | .3696 | .3696 | .3696 |
| 11 | .3734 | .2957 | .3696 | .3696 |
| 12 | .3734 | .3696 | .3326 | .3326 |
| 13 | .3734 | .2957 | .3696 | .3326 |
| 14 | .3734 | .2957 | .3696 | .3696 |
| 15 | .3734 | .2957 | .4066 | .3696 |
| 16 | .3361 | .3696 | .4066 | .4805 |
| 17 | .3734 | .3326 | .3696 | .4066 |
| 18 | .4854 | .4481 | .4481 | .4854 |
| 19 | .4108 | .4481 | .4108 | .4854 |
| 20 | .3734 | .3734 | .4108 | .4481 |
| 21 | .3361 | .4854 | .4854 | .4854 |
| 22 | .2987 | .4481 | .4668 | .4481 |
| 23 | .2641 | .415 | .3772 | .4066 |
| 24 | .4108 | .2263 | .3772 | .4108 |
| Max | .5601 | .4854 | .5544 | .5601 |
| Min | .2641 | .2075 | .3326 | .3326 |
| Avg | .3984 | .3318 | .3954 | .4225 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 206 / 11 KV MASAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .3018 | .3206 | .3018 | .3018 |
| 2 | .3018 | .3206 | .2829 | .3018 |
| 3 | .2829 | .3018 | .2829 | .3018 |
| 4 | .2641 | .3018 | .3018 | .3018 |
| 5 | .415 | .3395 | .3206 | .3584 |
| 6 | .4527 | .4527 | .4527 | .415 |
| 7 | .3772 | .415 | .415 | .415 |
| 8 | .724 | .724 | .6859 | .6878 |
| 9 | .9412 | .9774 | .7888 | .8326 |
| 10 | .9979 | .439 | .961 | .8501 |
| 11 | .961 | .924 | .8131 | .7023 |
| 12 | 1.0349 | .9979 | .3696 | .8501 |
| 13 | 1.0349 | .9979 | .961 | .8871 |
| 14 | .9979 | 1.0349 | .924 | .9979 |
| 15 | .9335 | .8131 | .8871 | .8131 |
| 16 | .3326 | .3292 | .3292 | .2926 |
| 17 | .3361 | .3658 | .3292 | .3658 |
| 18 | .6348 | .6722 | .8215 | .6722 |
| 19 | | .7842 | .7842 | .8589 |
| 20 | .6283 | .6722 | .7095 | .8215 |
| 21 | .5601 | .4854 | .5601 | .6722 |
| 22 | .3921 | .4481 | .4668 | .5601 |
| 23 | .3395 | .3395 | .3395 | .4435 |
| 24 | .3395 | .3018 | .3018 | .3018 |
| Max | 1.0349 | 1.0349 | .961 | .9979 |
| Min | .2641 | .3018 | .2829 | .2926 |
| Avg | .5906 | .5733 | .5579 | .5836 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 401 / 33 KV MURPAR

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5206 | .6677 | .5376 | .679 |
| 2 | .3678 | .43 | .3621 | .679 |
| 3 | .3904 | .4979 | .4527 | .6507 |
| 4 | .4923 | .5149 | .3961 | .6337 |
| 5 | .5885 | .3621 | .4017 | .679 |
| 6 | .5545 | .6903 | .5149 | .6847 |
| 7 | .4017 | .4074 | .5206 | .4131 |
| 8 | .4017 | .4244 | .1132 | .43 |
| 9 | .5206 | .5432 | .3678 | .5545 |
| 10 | .6666 | .7114 | .5769 | .5937 |
| 11 | .6497 | .7058 | .3361 | .5993 |
| 12 | .6105 | .4089 | .5657 | .5937 |
| 13 | .7114 | .6385 | .6049 | .7226 |
| 14 | .661 | .6722 | .6273 | .5881 |
| 15 | .4089 | .3977 | .6273 | .4705 |
| 16 | .3921 | .3977 | | .5489 |
| 17 | | .3977 | .6161 | .5321 |
| 18 | .7058 | .6329 | .689 | .4425 |
| 19 | .5881 | .7394 | .6441 | .5601 |
| 20 | .4257 | .6778 | .6722 | .5657 |
| 21 | .5657 | .4089 | .5545 | .5601 |
| 22 | .5433 | .3977 | .5713 | .5209 |
| 23 | .4357 | .5319 | .4357 | .4089 |
| 24 | .5206 | .6224 | .5715 | .1132 |
| Max | .7114 | .7394 | .689 | .7226 |
| Min | .3678 | .3621 | .1132 | .1132 |
| Avg | .5271 | .5366 | .5113 | .551 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084002 / 33 KV CHIMUR S/S

Feeder No / Name : 404 / 33 kV Sinedwahi Incomer

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.4712 | 2.6312 | 2.5916 | 1.7768 |
| 2 | 1.4203 | 2.3143 | 2.2351 | 1.8107 |
| 3 | 1.3976 | 2.3483 | 2.4162 | 1.8164 |
| 4 | 1.5165 | 2.2804 | 2.3313 | 1.839 |
| 5 | 1.7371 | 2.2634 | 2.518 | 1.8786 |
| 6 | 1.856 | 2.982 | 2.965 | 2.1502 |
| 7 | 1.8277 | 2.037 | 2.2068 | 2.0936 |
| 8 | 2.286 | 2.4275 | 2.2238 | 3.8591 |
| 9 | 2.784 | 2.8462 | 2.4727 | 4.5154 |
| 10 | 2.8829 | 2.9933 | 2.9198 | 4.7305 |
| 11 | 2.8719 | 2.8745 | 2.2407 | 4.6003 |
| 12 | 2.6889 | 2.7104 | 2.7613 | 4.5324 |
| 13 | 2.8343 | 2.8009 | 2.7613 | 5.2001 |
| 14 | 2.9717 | 2.8745 | 2.8405 | 5.2906 |
| 15 | 2.578 | 2.1615 | 2.8575 | 4.7418 |
| 16 | 1.763 | 1.5957 | 1.4995 | .2999 |
| 17 | 1.6244 | 1.6013 | 1.9691 | .3452 |
| 18 | 4.8451 | 2.7838 | 3.1535 | 1.938 |
| 19 | 5.2484 | 3.1255 | 3.1647 | 2.2125 |
| 20 | 5.0748 | 2.8959 | 3.0135 | 2.1117 |
| 21 | 3.344 | | 2.6774 | 2.2853 |
| 22 | 3.0471 | 2.7838 | 2.3133 | 1.9829 |
| 23 | 2.6595 | 2.767 | 1.7315 | 1.607 |
| 24 | 1.6466 | 2.5859 | 2.6878 | 1.3184 |
| Max | 5.2484 | 3.1255 | 3.1647 | 5.2906 |
| Min | 1.3976 | 1.5957 | 1.4995 | .2999 |
| Avg | 2.5990 | 2.5515 | 2.5230 | 2.7057 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 201 / 11 KV Shankarpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3395 | .3206 | .2829 | .3018 |
| 2 | | .3395 | .3206 | .2829 | .3018 |
| 3 | | .3395 | .3206 | .2829 | .3206 |
| 4 | | .3772 | .3206 | .3018 | .3206 |
| 5 | | .3961 | .3206 | .3395 | .3206 |
| 6 | | .415 | .4527 | .415 | .4338 |
| 7 | | .4715 | .4904 | .4715 | .4527 |
| 8 | | .4531 | .502 | .4807 | |
| 9 | | | .5624 | .5735 | .4588 |
| 10 | | | .6401 | .6062 | .503 |
| 11 | | | .6154 | .5243 | .6133 |
| 12 | | | .6562 | .6133 | .5636 |
| 13 | | | .5992 | .5735 | .639 |
| 14 | | | .6478 | .4696 | .6062 |
| 15 | | | .5898 | .4915 | .5506 |
| 16 | | | .5668 | .3395 | .2829 |
| 17 | | .6325 | .5735 | .3584 | .3961 |
| 18 | | .7087 | .6602 | .6602 | .6979 |
| 19 | | .7087 | .7167 | .7356 | .7356 |
| 20 | | .5935 | .679 | .6979 | .6979 |
| 21 | | .5868 | .4715 | .5847 | .4696 |
| 22 | | .4807 | .3772 | .3961 | .4372 |
| 23 | .415 | .4534 | .3395 | .3018 | .4372 |
| 24 | | .3395 | .3206 | .2829 | .3018 |
| Max | .415 | .7087 | .7167 | .7356 | .7356 |
| Min | .415 | .3395 | .3206 | .2829 | .2829 |
| Avg | .415 | .4772 | .5027 | .4611 | .4714 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 202 / 11K.V. HIRAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2477 | .2096 | .2096 | .2477 |
| 2 | | .2477 | .2096 | .2096 | .2477 |
| 3 | | .2477 | .2096 | .2096 | .2667 |
| 4 | | .2667 | .2096 | .2096 | .2667 |
| 5 | | .3239 | .2096 | .2286 | .2667 |
| 6 | | .3429 | .3239 | .3048 | .3429 |
| 7 | | .2667 | .2858 | .3048 | .2858 |
| 8 | | .1989 | .1417 | .2058 | .2254 |
| 9 | | .2818 | .2149 | .2401 | .3185 |
| 10 | | .2818 | .2629 | .2321 | .2984 |
| 11 | | .2294 | .2401 | .2515 | .1823 |
| 12 | | .2622 | .213 | .1989 | .2785 |
| 13 | | .3163 | .2622 | .3239 | .2915 |
| 14 | | .2812 | .3018 | .3113 | .2915 |
| 15 | | .2949 | .285 | .3315 | .2915 |
| 16 | | .2622 | .2561 | .1905 | .1524 |
| 17 | | .1387 | .1966 | .2096 | .2286 |
| 18 | | .2241 | .4763 | .4763 | .5335 |
| 19 | | .2427 | .6097 | .6097 | .6097 |
| 20 | | .2587 | .5716 | .5906 | .5525 |
| 21 | | .1829 | .381 | .4382 | .1646 |
| 22 | | .1448 | .2667 | .3239 | .1612 |
| 23 | .2667 | .1433 | .2477 | .2477 | .1417 |
| 24 | | .2477 | .2096 | .2096 | .2477 |
| Max | .2667 | .3429 | .6097 | .6097 | .6097 |
| Min | .2667 | .1387 | .1417 | .1905 | .1417 |
| Avg | .2667 | .2473 | .2831 | .2945 | .2872 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 203 / 11kv AMBOLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1715 | .1524 | .1524 | .1524 |
| 2 | | .1715 | .1334 | .1524 | .1524 |
| 3 | | .1715 | .1334 | .1524 | .1715 |
| 4 | | .1905 | .1334 | .1334 | .1715 |
| 5 | | .2096 | .1334 | .1524 | .1715 |
| 6 | | .2096 | .2096 | .1905 | |
| 7 | | .1905 | .1905 | .2286 | .2286 |
| 8 | | .1109 | .8029 | .8097 | .8684 |
| 9 | | | .8322 | .8583 | .9054 |
| 10 | | | .8223 | .8745 | .8684 |
| 11 | | | .8745 | 1.1736 | .852 |
| 12 | | | .7522 | 1.0322 | .9231 |
| 13 | | | .8482 | 1.0608 | .9122 |
| 14 | | | 1.17 | 1.0978 | .08 |
| 15 | | | 1.2209 | 1.1336 | .8642 |
| 16 | | | 1.1401 | 1.1984 | .0762 |
| 17 | | | .3239 | .1143 | .1334 |
| 18 | | .779 | .3048 | .3048 | .3429 |
| 19 | | .7449 | .4191 | .4191 | .4001 |
| 20 | | .7209 | .381 | .381 | .362 |
| 21 | | .6316 | .2858 | .5906 | .7287 |
| 22 | | .5624 | .1715 | .4001 | .7287 |
| 23 | .1905 | .5761 | .1715 | .3018 | .7287 |
| 24 | | .1715 | .1524 | .1524 | .1524 |
| Max | .1905 | .779 | 1.2209 | 1.1984 | .9231 |
| Min | .1905 | .1109 | .1334 | .1143 | .0762 |
| Avg | .1905 | .3741 | .4900 | .5444 | .4772 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 204 / 11 K.V. KANPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .0914 | .0762 | .0762 | .0914 |
| 2 | | .0914 | .0762 | .0762 | .0914 |
| 3 | | .0914 | .0762 | .0762 | .0762 |
| 4 | | .0914 | .0762 | .0762 | .0762 |
| 5 | | .1067 | .0762 | .1067 | .0762 |
| 6 | | .1219 | .1219 | .1372 | .1372 |
| 7 | | .0914 | .1067 | .0762 | .1219 |
| 8 | | .5792 | .6097 | .6401 | .6859 |
| 9 | | .6249 | .6706 | .7011 | .7468 |
| 10 | | .6706 | .7164 | .6097 | .7164 |
| 11 | | .7164 | .7011 | .7316 | .7164 |
| 12 | | .7316 | | .7773 | .7011 |
| 13 | | .7468 | .7316 | .8078 | .7468 |
| 14 | | .7011 | .7621 | .8383 | .7011 |
| 15 | | .7316 | .7621 | .7926 | .7011 |
| 16 | | .061 | .0762 | .061 | .061 |
| 17 | | .0762 | .061 | .0762 | .0914 |
| 18 | | .1981 | .2286 | .1981 | .2286 |
| 19 | | .2439 | .2591 | .2439 | .2591 |
| 20 | | .2286 | .2286 | .2439 | .2134 |
| 21 | | .1524 | .1524 | .1677 | .5487 |
| 22 | | .1219 | .0914 | .0914 | .5639 |
| 23 | .1067 | .0762 | .0762 | .0762 | .5639 |
| 24 | | .0914 | .061 | .0762 | .0914 |
| Max | .1067 | .7468 | .7621 | .8383 | .7468 |
| Min | .1067 | .061 | .061 | .061 | .061 |
| Avg | .1067 | .3099 | .2956 | .3233 | .3753 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 205 / 11 K.V. SATHGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1406 | .125 | .125 | .1406 |
| 2 | | .1406 | .125 | .125 | .1406 |
| 3 | | .1406 | .125 | .125 | .125 |
| 4 | | .1562 | .125 | .1094 | .125 |
| 5 | | .1718 | .125 | .1406 | .125 |
| 6 | | .1875 | .1875 | .1718 | .1875 |
| 7 | | .1718 | .1562 | .1562 | .1718 |
| 8 | | .9686 | 1.4373 | 1.8435 | 1.7029 |
| 9 | | 1.7185 | 1.8747 | 1.9372 | 1.5623 |
| 10 | | 1.8435 | 1.7497 | 1.906 | 1.9528 |
| 11 | | 1.8122 | 1.8278 | 1.9997 | 1.9841 |
| 12 | | 1.9685 | 1.7497 | 1.8435 | 1.9685 |
| 13 | | 1.9528 | 1.8591 | 1.7497 | 1.9528 |
| 14 | | 1.9685 | 1.9841 | 1.5935 | 1.9997 |
| 15 | | 1.9528 | 1.9528 | 1.8591 | 1.8903 |
| 16 | | .0781 | .0781 | .0781 | .0781 |
| 17 | | .0937 | .0937 | .125 | .0937 |
| 18 | | .2187 | .2187 | .25 | .25 |
| 19 | | .3125 | .2968 | .3125 | .2968 |
| 20 | | .2812 | .2656 | .2812 | .2968 |
| 21 | | .2187 | .2187 | .2343 | 1.6248 |
| 22 | | .1562 | .1562 | .1406 | 1.6248 |
| 23 | .1562 | .125 | .1406 | .125 | 1.6091 |
| 24 | | .1406 | .125 | .125 | .1406 |
| Max | .1562 | 1.9685 | 1.9841 | 1.9997 | 1.9997 |
| Min | .1562 | .0781 | .0781 | .0781 | .0781 |
| Avg | .1562 | .7050 | .7082 | .7232 | .9185 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 206 / 11 K.V. MANGALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2058 | .1715 | .1715 | .1715 |
| 2 | | .2058 | .1715 | .1715 | .1715 |
| 3 | | .2058 | .1715 | .1715 | .1886 |
| 4 | | .2229 | .1715 | .1715 | .1886 |
| 5 | | .2572 | .1715 | .2058 | .1886 |
| 6 | | .2743 | .2743 | .2743 | .3086 |
| 7 | | .2229 | .2401 | .2401 | .2572 |
| 8 | | .3772 | .3772 | .3772 | .3772 |
| 9 | | .4287 | .4115 | .4115 | .4287 |
| 10 | | .4287 | .5144 | .4287 | .4287 |
| 11 | | .4801 | .4801 | .4458 | .4458 |
| 12 | | .4801 | .4973 | .4973 | .4973 |
| 13 | | .5144 | .5316 | .3601 | .5144 |
| 14 | | .5487 | .5658 | .3601 | .5316 |
| 15 | | .5144 | .3944 | .4287 | .5144 |
| 16 | | .1372 | .1372 | .1372 | .1372 |
| 17 | | .1372 | .1372 | .1543 | .1886 |
| 18 | | .4115 | .3772 | .3772 | .4115 |
| 19 | | .4801 | .4973 | .4973 | .4973 |
| 20 | | .4458 | .463 | .4458 | .4458 |
| 21 | | .3086 | .3429 | .3429 | .3258 |
| 22 | | .2058 | .2229 | 2.2462 | .2915 |
| 23 | .2229 | .1715 | .1886 | .1886 | .2915 |
| 24 | | .2058 | .1715 | .1715 | .1715 |
| Max | .2229 | .5487 | .5658 | 2.2462 | .5316 |
| Min | .2229 | .1372 | .1372 | .1372 | .1372 |
| Avg | .2229 | .3279 | .3201 | .3865 | .3322 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084005 / 33KV SHANKARPUR

Feeder No / Name : 401 / 33 KV CHIMUR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .823 | | |
| 2 | | .7773 | | |
| 3 | | .7773 | | |
| 4 | | .7773 | | |
| 5 | | .823 | | |
| 6 | | .8688 | | |
| 7 | | .4572 | | |
| 8 | | .3658 | | |
| 9 | | .3658 | | |
| 10 | | .3201 | | |
| 11 | | .3201 | | |
| 12 | | .3201 | | |
| 13 | | .2743 | | |
| 14 | | .3201 | | |
| 15 | | .3201 | | |
| 16 | | .2743 | | 1.6918 |
| 17 | | .3201 | | 1.7833 |
| 18 | | 1.5546 | | .503 |
| 19 | | 1.829 | | .5944 |
| 20 | | 1.6918 | | .5487 |
| 21 | | | .5487 | .503 |
| 22 | | | | .4115 |
| 23 | .8688 | | | .3658 |
| 24 | | .823 | | |
| Max | .8688 | 1.829 | .5487 | 1.7833 |
| Min | .8688 | .2743 | .5487 | .3658 |
| Avg | .8688 | .6859 | .5487 | .8002 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084024 / 33 KV NERI SUB-STATION

Feeder No / Name : 201 / 11 K.V.NERI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3353 | .3163 | .3281 | .3429 |
| 2 | | .3561 | .3041 | .3479 | .3429 |
| 3 | | .3121 | .2846 | .3521 | .3239 |
| 4 | | .285 | .25 | .3887 | .3239 |
| 5 | | .2721 | .3005 | .426 | .362 |
| 6 | | .3201 | .4111 | .4365 | .5525 |
| 7 | | .5906 | .5906 | .5716 | .5144 |
| 8 | | .4954 | .5144 | .5525 | .4748 |
| 9 | | .4954 | .4572 | .4191 | .5801 |
| 10 | | .4572 | .3429 | .4382 | .6401 |
| 11 | | .381 | .362 | .4191 | .6133 |
| 12 | | .381 | .381 | .4191 | .6133 |
| 13 | | .4001 | .362 | .4572 | .5898 |
| 14 | | .3429 | .3239 | .3239 | .5801 |
| 15 | | .381 | .2858 | .3048 | .4641 |
| 16 | | .4001 | .3429 | .3239 | .3048 |
| 17 | | .3239 | .362 | .4191 | .3429 |
| 18 | | .8002 | .8383 | .7049 | .8002 |
| 19 | | .9526 | .9907 | 1.0479 | .9717 |
| 20 | | .9526 | | 1.0288 | .9145 |
| 21 | .3749 | .3944 | .4801 | .8383 | .743 |
| 22 | .3353 | .3077 | .407 | .5906 | .724 |
| 23 | .3506 | .3704 | .3321 | .381 | .5716 |
| 24 | | .3418 | .3704 | .3281 | .362 |
| Max | .3749 | .9526 | .9907 | 1.0479 | .9717 |
| Min | .3353 | .2721 | .25 | .3048 | .3048 |
| Avg | .3536 | .4437 | .4178 | .4936 | .5439 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084024 / 33 KV NERI SUB-STATION

Feeder No / Name : 202 / 11 K.V.MOTEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5765 | .5601 | .5801 | .547 |
| 2 | | .5548 | .5441 | .57 | .547 |
| 3 | | .5801 | .5376 | .5636 | .5281 |
| 4 | | .5407 | .5344 | .6554 | .5093 |
| 5 | | .6104 | .5898 | .7127 | .6413 |
| 6 | | .7461 | .7537 | .7625 | .9242 |
| 7 | | .7356 | .6979 | .6979 | .7167 |
| 8 | | .5847 | .5281 | .5716 | .7956 |
| 9 | | .5281 | .5093 | .5093 | 1.0442 |
| 10 | | .4715 | .4527 | .4715 | 1.3817 |
| 11 | | .3961 | .3601 | .3772 | .2458 |
| 12 | | .3772 | .3206 | .3206 | 1.2717 |
| 13 | | .3584 | .3395 | .3206 | 1.2803 |
| 14 | | .3772 | .3584 | .3584 | 1.3748 |
| 15 | | .3584 | .3584 | .3018 | 1.291 |
| 16 | | .3772 | .3584 | .2829 | .3206 |
| 17 | | .3772 | .3961 | .415 | .4338 |
| 18 | | 1.0374 | 1.3014 | 1.0185 | 1.2449 |
| 19 | | 1.6221 | 1.6409 | 1.6221 | 1.6221 |
| 20 | | 1.4901 | | 1.5278 | 1.4901 |
| 21 | .7122 | .7373 | .7628 | 1.1317 | 1.0562 |
| 22 | .6062 | .639 | .663 | .7356 | .7545 |
| 23 | .6562 | .5761 | .5898 | .5658 | .6036 |
| 24 | | .5596 | .5601 | .5967 | .547 |
| Max | .7122 | 1.6221 | 1.6409 | 1.6221 | 1.6221 |
| Min | .6062 | .3584 | .3206 | .2829 | .2458 |
| Avg | .6582 | .6338 | .5964 | .6529 | .8821 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084024 / 33 KV NERI SUB-STATION

Feeder No / Name : 203 / 11 K.V. RAMPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1677 | .1475 | .1802 | .1715 |
| 2 | | .1562 | .1457 | .1619 | .1524 |
| 3 | | .128 | .1492 | .1658 | .1524 |
| 4 | | .1646 | .1475 | .1677 | .1905 |
| 5 | | .1372 | .1492 | .1526 | .2286 |
| 6 | | .2214 | .2241 | .16 | .362 |
| 7 | | .2858 | .2858 | .2667 | .2858 |
| 8 | | .2096 | .1905 | .2286 | .2241 |
| 9 | | .2286 | .1905 | .2096 | .2881 |
| 10 | | .1524 | .1524 | .1715 | .2743 |
| 11 | | .1524 | .1143 | .1334 | .3605 |
| 12 | | .1524 | .1334 | .1334 | .407 |
| 13 | | .1715 | .0953 | .1524 | .3768 |
| 14 | | .1524 | .1143 | .1143 | .4287 |
| 15 | | .1524 | .1334 | .1334 | .3772 |
| 16 | | .1334 | .1524 | .1334 | .1334 |
| 17 | | .1715 | .1905 | .1715 | .1905 |
| 18 | | .5335 | .5335 | .381 | .4954 |
| 19 | | 1.6221 | .6668 | .6287 | .6478 |
| 20 | | .5658 | | .5906 | .5716 |
| 21 | .2401 | .2031 | .2241 | .4191 | .381 |
| 22 | .1739 | .1581 | .1943 | .2667 | .3429 |
| 23 | .2374 | .1423 | .1739 | .1905 | .2858 |
| 24 | | .1638 | .1423 | .176 | .1905 |
| Max | .2401 | 1.6221 | .6668 | .6287 | .6478 |
| Min | .1739 | .128 | .0953 | .1143 | .1334 |
| Avg | .2171 | .2636 | .2022 | .2287 | .3133 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084025 / 33 KV BHISI SUB-STATION

Feeder No / Name : 201 / 11 K.V. BHISI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .362 | .3506 | .2743 | .5716 |
| 2 | | .362 | .3403 | .2743 | .5906 |
| 3 | | .362 | .3224 | .2743 | .5906 |
| 4 | | .362 | .2804 | .2915 | .6097 |
| 5 | | .3582 | .2715 | .3155 | .6478 |
| 6 | | .3292 | .3658 | .3681 | .6668 |
| 7 | | .7602 | .724 | .7621 | .724 |
| 8 | | .6268 | .6668 | .7049 | .4572 |
| 9 | | .5716 | .5906 | .4382 | .499 |
| 10 | | .5335 | .5525 | .5716 | .543 |
| 11 | | .4763 | .5716 | | .543 |
| 12 | | .5144 | .4908 | | .5093 |
| 13 | | .4954 | .4572 | | .6097 |
| 14 | | .5144 | | | .5601 |
| 15 | | .5335 | | | .5281 |
| 16 | | .5335 | | | .4904 |
| 17 | | .5716 | | .4763 | .5716 |
| 18 | | 1.0098 | 1.0479 | .4763 | .9907 |
| 19 | | 1.2193 | 1.1812 | 1.1812 | 1.2193 |
| 20 | | 1.1622 | 1.105 | 1.0479 | 1.105 |
| 21 | | .4031 | .4382 | .8954 | .9145 |
| 22 | | .3681 | .3856 | .7049 | .6859 |
| 23 | .3582 | .3294 | .3429 | .5716 | .6478 |
| 24 | | .3582 | .3506 | .2915 | .5716 |
| Max | .3582 | 1.2193 | 1.1812 | 1.1812 | 1.2193 |
| Min | .3582 | .3292 | .2715 | .2743 | .4572 |
| Avg | .3582 | .5465 | .5418 | .5511 | .6603 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084025 / 33 KV BHISI SUB-STATION

Feeder No / Name : 202 / 11 K.V. AMBENERI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4321 | .5937 | .5792 | .1143 |
| 2 | | .4321 | .5937 | .5792 | .1143 |
| 3 | | .4321 | .5937 | .5792 | .1143 |
| 4 | | .4321 | .578 | .571 | .1334 |
| 5 | | .4321 | .5418 | .578 | .1524 |
| 6 | | .4115 | .6097 | .5937 | .1524 |
| 7 | | .1524 | .1715 | .1334 | .1715 |
| 8 | | .0953 | .1143 | .1334 | .7045 |
| 9 | | .1143 | .1143 | .1143 | .7287 |
| 10 | | .0953 | .0953 | .0953 | .8223 |
| 11 | | .0953 | .0762 | | .7926 |
| 12 | | .0762 | .0572 | .0762 | .8002 |
| 13 | | .0762 | | .0762 | .9282 |
| 14 | | .0762 | .0572 | .0762 | .9831 |
| 15 | | .0762 | .0762 | .0762 | .8802 |
| 16 | | .0762 | .0762 | .0953 | .0762 |
| 17 | | .0762 | .0953 | .1143 | .0953 |
| 18 | | .2477 | .2667 | .1143 | .2286 |
| 19 | | .3429 | .362 | .3429 | .3429 |
| 20 | | .3239 | .3239 | .3239 | .3239 |
| 21 | | .6167 | .5864 | .2477 | .2667 |
| 22 | | .6093 | .5944 | .1715 | .1524 |
| 23 | .4218 | .6093 | .5944 | .1334 | .1334 |
| 24 | | .4321 | .5792 | .5792 | .1143 |
| Max | .4218 | .6167 | .6097 | .5937 | .9831 |
| Min | .4218 | .0762 | .0572 | .0762 | .0762 |
| Avg | .4218 | .2818 | .3370 | .2776 | .3886 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084025 / 33 KV BHISI SUB-STATION

Feeder No / Name : 203 / 11 K.V. JAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2591 | .176 | .1311 | .1334 |
| 2 | | .2591 | .1783 | .1311 | .1334 |
| 3 | | .2591 | .1656 | .1341 | .1334 |
| 4 | | .2429 | .1677 | .1372 | .1524 |
| 5 | | .2561 | .1581 | .1543 | .1524 |
| 6 | | .2286 | .1875 | .1753 | .1905 |
| 7 | | .1905 | .1334 | .1524 | .1848 |
| 8 | | .1715 | .1143 | .1334 | .2641 |
| 9 | | .1524 | .1143 | .1334 | .3018 |
| 10 | | .1524 | .1143 | .1143 | .3052 |
| 11 | | .1334 | .1143 | | .2865 |
| 12 | | .1524 | .0953 | .0953 | |
| 13 | | .0953 | .0953 | .0953 | .4298 |
| 14 | | .0953 | .0953 | .0953 | .5028 |
| 15 | | .0953 | .0953 | .0953 | .4334 |
| 16 | | .0953 | .0953 | .0953 | |
| 17 | | .1143 | .0762 | .1143 | .2286 |
| 18 | | .2477 | .2858 | .3018 | .2286 |
| 19 | | .3429 | .3429 | .381 | .3048 |
| 20 | | .3239 | .3239 | .3429 | .3239 |
| 21 | | .2667 | .1753 | .2858 | .2477 |
| 22 | | .2477 | .1781 | .1715 | .1715 |
| 23 | .2753 | .176 | .1619 | .1334 | .1143 |
| 24 | | .2753 | .1806 | .1423 | .1334 |
| Max | .2753 | .3429 | .3429 | .381 | .5028 |
| Min | .2753 | .0953 | .0762 | .0953 | .1143 |
| Avg | .2753 | .2014 | .1594 | .1629 | .2435 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084055 / KHADASANGI SUBSTATION

Feeder No / Name : 201 / 11 KV KHADASANGI TOWN SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4696 | .4973 | .4862 | .381 |
| 2 | .4917 | .4862 | .4801 | .381 |
| 3 | .5201 | .4917 | .4801 | .4001 |
| 4 | .5434 | .4915 | .5083 | .4001 |
| 5 | .5731 | .5079 | .5258 | .4191 |
| 6 | .6219 | .5079 | .5721 | .4572 |
| 7 | .4191 | .4572 | .4572 | .4763 |
| 8 | | .4382 | .4191 | .5658 |
| 9 | .4382 | .4191 | .4191 | .5658 |
| 10 | .4191 | .4191 | .4191 | .5721 |
| 11 | .4191 | .4191 | .4001 | .5487 |
| 12 | .4001 | .4191 | .4001 | .5375 |
| 13 | .4001 | .4001 | .381 | .5316 |
| 14 | .4001 | .4001 | .381 | .5144 |
| 15 | .4191 | .381 | .381 | .5083 |
| 16 | .381 | .4001 | .381 | .381 |
| 17 | .381 | .381 | .381 | .381 |
| 18 | .5144 | .4954 | .4954 | .4954 |
| 19 | .5716 | .5716 | .5525 | .5525 |
| 20 | .5144 | .5335 | .5335 | .5525 |
| 21 | .5792 | .5658 | .4763 | .4763 |
| 22 | .6371 | .5144 | .4191 | .4382 |
| 23 | .4572 | .4917 | .4191 | .4001 |
| 24 | .4586 | .4531 | .4862 | .4001 |
| Max | .6371 | .5716 | .5721 | .5721 |
| Min | .381 | .381 | .381 | .381 |
| Avg | .4795 | .4643 | .4523 | .4723 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084055 / KHADASANGI SUBSTATION

Feeder No / Name : 202 / 11 KV BOTHALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4715 | .423 | .4172 | .5906 |
| 2 | .4344 | .4344 | .423 | .5716 |
| 3 | .4108 | .423 | .4172 | .5716 |
| 4 | .4254 | .4172 | .4287 | .5906 |
| 5 | .4199 | .4033 | .4572 | .6287 |
| 6 | .4458 | .423 | .4988 | .6478 |
| 7 | .6224 | .6287 | .6036 | .6478 |
| 8 | | .5906 | .5847 | .5535 |
| 9 | .6036 | .6097 | .5716 | .6019 |
| 10 | .5716 | .5906 | .5716 | .703 |
| 11 | .5716 | .5906 | .5525 | .7274 |
| 12 | .5716 | .5716 | .5335 | .7287 |
| 13 | .5716 | .5716 | .5525 | .7625 |
| 14 | .5525 | .5716 | .5525 | .7625 |
| 15 | .5525 | .5525 | .5658 | .7045 |
| 16 | .5415 | .5525 | .5716 | .547 |
| 17 | .5335 | .5525 | .5847 | .5906 |
| 18 | .6668 | .679 | .6602 | .6859 |
| 19 | .724 | .7621 | .7049 | .724 |
| 20 | .7049 | .7167 | .7049 | .724 |
| 21 | .4934 | .4572 | .6668 | .6668 |
| 22 | .4664 | .4451 | .6097 | .6287 |
| 23 | .4729 | .4252 | .5906 | .5716 |
| 24 | .4734 | .4599 | .4115 | .5716 |
| Max | .724 | .7621 | .7049 | .7625 |
| Min | .4108 | .4033 | .4115 | .547 |
| Avg | .5349 | .5355 | .5515 | .6460 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084055 / KHADASANGI SUBSTATION

Feeder No / Name : 203 / 11 KV AMADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .1143 | .1448 | .1372 | .1334 |
| 2 | .1014 | .1467 | .1389 | .1334 |
| 3 | .1027 | .1448 | .1235 | .1143 |
| 4 | .1054 | .141 | | .1143 |
| 5 | .1219 | .1429 | .1389 | .1143 |
| 6 | .1457 | .1303 | .1698 | .1524 |
| 7 | .1524 | .1334 | .1524 | .1334 |
| 8 | | .1334 | .0953 | .1619 |
| 9 | .0572 | .0953 | .0953 | .2294 |
| 10 | .1143 | .0953 | .0953 | .2622 |
| 11 | .0953 | .0953 | .0953 | .2753 |
| 12 | .0572 | .0953 | .0762 | .2915 |
| 13 | .0572 | .0762 | .0762 | .2721 |
| 14 | .0572 | .0762 | .0762 | .2591 |
| 15 | .0572 | .0762 | .0762 | .2105 |
| 16 | .0762 | .0762 | .0762 | .0762 |
| 17 | .0762 | .0572 | .0572 | .0953 |
| 18 | .2477 | .1715 | .2286 | .2477 |
| 19 | .2858 | .2858 | .3048 | .3048 |
| 20 | .2858 | .2858 | .2858 | .3048 |
| 21 | .1581 | .1581 | .2286 | .2286 |
| 22 | .1448 | .1406 | .1524 | .1905 |
| 23 | .1372 | .1389 | .1334 | .1143 |
| 24 | .1217 | .1353 | .1372 | .1334 |
| Max | .2858 | .2858 | .3048 | .3048 |
| Min | .0572 | .0572 | .0572 | .0762 |
| Avg | .1249 | .1324 | .1370 | .1897 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

CHIMUR[337]

BU 4337

Substation No/ Name :- 084055 / KHADASANGI SUBSTATION

Feeder No / Name : 401 / 33 KV INCOMER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | 1.2752 | 1.2883 | 1.2752 | .5658 |
| 2 | 1.2197 | 1.2883 | 1.2071 | .5658 |
| 3 | 1.1317 | 1.2752 | 1.2071 | .5658 |
| 4 | 1.1568 | 1.2752 | 1.2752 | .5658 |
| 5 | 1.2357 | 1.2489 | 1.3306 | .6224 |
| 6 | 1.358 | 1.262 | 1.4712 | .6224 |
| 7 | .6287 | .6287 | .6224 | .6224 |
| 8 | | .5716 | .5658 | 1.4563 |
| 9 | .6287 | .6287 | .5658 | 1.6244 |
| 10 | .5716 | .5716 | .5658 | 1.7187 |
| 11 | .5716 | .5716 | .5658 | 1.7375 |
| 12 | .5716 | .5716 | .5093 | 1.6832 |
| 13 | .5658 | .5716 | .5658 | 1.701 |
| 14 | .5658 | .5716 | .5658 | 1.701 |
| 15 | .5716 | | .5658 | 1.5524 |
| 16 | .5658 | .5658 | .5658 | .5601 |
| 17 | .499 | .5658 | .679 | .5658 |
| 18 | .6859 | .679 | | .679 |
| 19 | .743 | .7356 | .679 | .7356 |
| 20 | .6859 | .7356 | .679 | .7356 |
| 21 | 1.4712 | 1.4146 | .679 | .679 |
| 22 | 1.4146 | 1.3443 | .6224 | .6224 |
| 23 | 1.3717 | 1.2883 | .5716 | .5658 |
| 24 | 1.3306 | 1.3443 | 1.2883 | .5658 |
| Max | 1.4712 | 1.4146 | 1.4712 | 1.7375 |
| Min | .499 | .5658 | .5093 | .5601 |
| Avg | .9052 | .9130 | .8097 | .9589 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084004 / 33 KV KHAMBADA

Feeder No / Name : 201 / 11 KV KHAMBADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .7773 | .743 | | |
| 2 | .7773 | .743 | .6173 | |
| 3 | .7526 | .7335 | .6249 | |
| 4 | .7621 | .7482 | .5796 | |
| 5 | .787 | .7482 | .5944 | |
| 6 | .8025 | .7676 | .5944 | |
| 8 | | | .7375 | .9877 |
| 9 | | | .9755 | 1.1385 |
| 10 | | | 1.0722 | 1.0402 |
| 11 | | .381 | .9962 | 1.0279 |
| 12 | | .6923 | 1.0242 | 1.0722 |
| 13 | .7316 | .7526 | 1.1523 | .9962 |
| 14 | | | 1.1843 | .9061 |
| 15 | | | 1.1843 | 1.0279 |
| 18 | | .7407 | | |
| 21 | .8179 | .7099 | | |
| 22 | .8078 | .6859 | | |
| 23 | .7926 | .6401 | | |
| 24 | .7773 | .743 | .6015 | |
| Max | .8179 | .7676 | 1.1843 | 1.1385 |
| Min | .7316 | .381 | .5796 | .9061 |
| Avg | .7805 | .7021 | .8528 | 1.0246 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084004 / 33 KV KHAMBADA

Feeder No / Name : 202 / 11 KV KOSARSAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .4001 | .3517 | .3467 | |
| 2 | .4054 | .3517 | .3517 | |
| 3 | .4458 | .3319 | .3109 | |
| 4 | .4458 | .3319 | .3064 | |
| 5 | .4694 | .3319 | .3292 | |
| 6 | .5182 | .3841 | .3246 | |
| 8 | | | .4633 | .5281 |
| 9 | | | .5647 | .7099 |
| 10 | | | .6706 | .8124 |
| 11 | | | .8333 | .7716 |
| 12 | | .3517 | .8025 | .7225 |
| 13 | .2641 | .5144 | .7407 | .7133 |
| 14 | | | .7407 | .6321 |
| 15 | | | .7407 | .6321 |
| 18 | | .4793 | | |
| 21 | .4108 | .3894 | | |
| 22 | .4287 | .3788 | | |
| 23 | .3948 | .4001 | | |
| 24 | .4172 | .3517 | .3368 | |
| Max | .5182 | .5144 | .8333 | .8124 |
| Min | .2641 | .3319 | .3064 | .5281 |
| Avg | .4182 | .3807 | .5242 | .6903 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084004 / 33 KV KHAMBADA

Feeder No / Name : 204 / 11 KV FATTAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .5647 | .4801 | .5121 | .1886 |
| 2 | .5647 | .4744 | .463 | .1886 |
| 3 | .6097 | .4973 | .4744 | .1886 |
| 4 | .6097 | .3163 | .4428 | .1886 |
| 5 | .6173 | .4111 | .4641 | .1886 |
| 6 | .5761 | .431 | .4858 | .2263 |
| 7 | .1886 | .1886 | .1509 | .1886 |
| 8 | .1509 | .1132 | .5624 | .6478 |
| 9 | .1509 | .1509 | .9145 | 1.0688 |
| 10 | .1132 | .1509 | .9602 | 1.0395 |
| 11 | .1132 | .1509 | .9282 | .9717 |
| 12 | .0754 | | 1.1523 | 1.0242 |
| 13 | | | 1.1203 | .9488 |
| 14 | .0762 | .1524 | 1.1336 | .9717 |
| 15 | .0754 | .1143 | .8745 | .8124 |
| 16 | .1509 | .1143 | .0762 | .0739 |
| 17 | .1509 | | .1509 | |
| 18 | .3772 | | .3395 | .3395 |
| 19 | .3772 | .415 | .415 | .3772 |
| 20 | .3772 | .3772 | .3772 | .3395 |
| 21 | .421 | .4915 | .3018 | .2641 |
| 22 | .6173 | .5182 | .2263 | .1886 |
| 23 | .4816 | .5761 | .1886 | .1886 |
| 24 | .5792 | .4999 | .4877 | .1886 |
| Max | .6173 | .5761 | 1.1523 | 1.0688 |
| Min | .0754 | .1132 | .0762 | .0739 |
| Avg | .3486 | .3312 | .5501 | .4697 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084004 / 33 KV KAMBADA

Feeder No / Name : 205 / 11KV Sunflag Express

Feeder Feeder KV- 11 /
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | .9431 | .3963 | .5658 | .4755 | .415 |
| 2 | .9431 | .4268 | .5658 | .5487 | .7922 |
| 3 | .9054 | .4374 | .6036 | .6516 | .8676 |
| 4 | .8299 | .4801 | .6036 | .7468 | .9054 |
| 5 | | .4744 | .7545 | .6348 | .8676 |
| 6 | | .5087 | .7922 | .6722 | .8299 |
| 7 | | .4961 | .6036 | .9431 | .8299 |
| 8 | | .4161 | .5601 | .8299 | .4401 |
| 9 | | .4641 | .543 | .8299 | .503 |
| 10 | | .815 | .7922 | .6584 | .8299 |
| 11 | | 1.086 | .8326 | 1.0719 | .8299 |
| 12 | | 1.1946 | .7842 | .9808 | 1.1576 |
| 13 | | 1.1584 | .8589 | 1.0719 | 1.1088 |
| 14 | | 1.1584 | 1.1222 | .9054 | 1.0185 |
| 15 | | 1.0974 | .8688 | 1.0719 | 1.0456 |
| 16 | | .7442 | .3795 | .4641 | .3688 |
| 17 | | .8139 | .431 | .4973 | .4252 |
| 18 | | .8299 | .9808 | .7095 | .8413 |
| 19 | | .9054 | 1.0456 | .7922 | 1.0829 |
| 20 | | .9054 | .9335 | .7545 | 1.0082 |
| 21 | | .7922 | .8299 | .7545 | 1.2071 |
| 22 | | .7922 | 1.1203 | .7167 | .9808 |
| 23 | | .8676 | .8299 | .4338 | .9431 |
| 24 | 1.0185 | .4557 | .4115 | .3856 | .4338 |
| Max | 1.0185 | 1.1946 | 1.1222 | 1.0719 | 1.2071 |
| Min | .8299 | .3963 | .3795 | .3856 | .3688 |
| Avg | .928 | .7382 | .7422 | .7334 | .8222 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084010 / 33 KV SHEGAON S/STN

Feeder No / Name : 201 / 11 KV MESA SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .6859 | .5415 |
| 2 | | | .6874 | |
| 3 | | | .6874 | .4108 |
| 4 | | | .6642 | .4294 |
| 5 | | | .7116 | .4294 |
| 6 | | | .7682 | .4481 |
| 8 | 1.0595 | .6722 | | |
| 9 | 1.0974 | .7842 | | |
| 10 | 1.1279 | .7655 | | |
| 11 | 1.1279 | 1.5074 | | |
| 12 | 1.2346 | 1.5043 | | |
| 13 | 1.2654 | 1.4685 | | |
| 14 | 1.4083 | 1.4506 | | |
| 15 | 1.2944 | 1.2803 | | |
| 21 | | .7621 | .5228 | 1.0364 |
| 22 | | .7316 | .4854 | .9804 |
| 23 | | .7074 | .4854 | .9061 |
| 24 | | | .6984 | .4481 |
| Max | 1.4083 | 1.5074 | .7682 | 1.0364 |
| Min | 1.0595 | .6722 | .4854 | .4108 |
| Avg | 1.2019 | 1.0576 | .6397 | .6256 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084010 / 33 KV SHEGAON S/STN

Feeder No / Name : 202 / 11 KV WADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | | .4161 | .5975 |
| 2 | | | .4012 | .6348 |
| 3 | | | .3864 | .6348 |
| 4 | | | .3913 | .6722 |
| 5 | | | .4365 | .7095 |
| 6 | | | .4666 | .7282 |
| 8 | .8535 | 1.0456 | | |
| 9 | .8025 | 1.1203 | | |
| 10 | .7727 | 1.0082 | | |
| 11 | .6562 | .9686 | | |
| 12 | .7968 | .9374 | | |
| 13 | .8592 | .9374 | | |
| 14 | .953 | .5624 | | |
| 15 | .9061 | .6562 | | |
| 21 | | .4816 | .6908 | |
| 22 | | .4515 | .6348 | .5937 |
| 23 | | .431 | .6348 | .5624 |
| 24 | | | .4108 | .5975 |
| Max | .953 | 1.1203 | .6908 | .7282 |
| Min | .6562 | .431 | .3864 | .5624 |
| Avg | .825 | .7818 | .4869 | .6367 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084010 / 33 KV SHEGAON S/STN

Feeder No / Name : 203 / 11 KV CHARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5658 | .2263 | .5182 | .4294 |
| 2 | | .5658 | .2263 | .5182 | .4481 |
| 3 | | .5281 | .2641 | .5155 | .4481 |
| 4 | | .5281 | .2641 | .4999 | .4481 |
| 5 | | .6036 | .2641 | .5851 | .4668 |
| 6 | | .7167 | .2641 | .6325 | .4854 |
| 7 | | .6602 | .2075 | .4715 | .2241 |
| 8 | | 1.3765 | .6348 | .415 | .2241 |
| 9 | | 1.3603 | .7655 | .3772 | .1867 |
| 10 | | 1.1843 | .7095 | .3584 | .168 |
| 11 | | 1.1843 | 1.1469 | .3018 | .2452 |
| 12 | | 1.1984 | 1.166 | .3395 | .2641 |
| 13 | | 1.2308 | 1.2125 | .3018 | .2641 |
| 14 | | 1.1984 | 1.3108 | .0754 | .2452 |
| 15 | | 1.1843 | 1.1702 | .2641 | .2452 |
| 16 | | .2263 | .2263 | .2641 | .2263 |
| 17 | | .2641 | .2829 | .2987 | .2641 |
| 18 | | .3961 | .7733 | .2987 | .7545 |
| 19 | | .3772 | .1905 | .4481 | .8676 |
| 20 | | .3018 | .9431 | .4108 | .9054 |
| 21 | .9619 | .3018 | .6401 | .4481 | .7773 |
| 22 | .8488 | .2452 | .6097 | .4481 | .7773 |
| 23 | .6602 | .2263 | .571 | .4481 | .7186 |
| 24 | | .5847 | .2263 | .5268 | .4294 |
| Max | .9619 | 1.3765 | 1.3108 | .6325 | .9054 |
| Min | .6602 | .2263 | .1905 | .0754 | .168 |
| Avg | .8236 | .7087 | .5957 | .4069 | .4380 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084010 / 33 KV SHEGAON S/STN

Feeder No / Name : 204 / 11 KV SHEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1086 | .1086 | .0905 | .1086 |
| 2 | | .1086 | .1086 | .0724 | .1086 |
| 3 | | .0905 | .1086 | .0724 | .1086 |
| 4 | | .0905 | .1086 | .0724 | .1086 |
| 5 | | .1086 | .1448 | .1086 | .1086 |
| 6 | | .1267 | .1448 | .1267 | .1267 |
| 7 | | .1267 | .181 | .1267 | .1448 |
| 8 | | .1448 | .1448 | .1448 | .1629 |
| 9 | | .1629 | .1448 | .1448 | .1448 |
| 10 | | .1991 | .1448 | .1629 | .2172 |
| 11 | | .1629 | .181 | .181 | .181 |
| 12 | | .2172 | .1991 | .181 | .1629 |
| 13 | | .1629 | .1991 | .1086 | .1448 |
| 14 | | .2172 | .1991 | .1086 | .1448 |
| 15 | | .1629 | | .1448 | .1629 |
| 16 | | .1629 | .1448 | .1086 | .181 |
| 17 | | .1629 | .1629 | .1086 | .1991 |
| 18 | | .2172 | .181 | | .2534 |
| 19 | | .181 | .1629 | .2172 | .2534 |
| 20 | | .1448 | .1448 | .181 | .181 |
| 21 | .1629 | .1448 | .1448 | .1448 | .1448 |
| 22 | .1448 | .1086 | .1267 | .1448 | .1086 |
| 23 | .1267 | .1086 | .1086 | .1086 | .1086 |
| 24 | | .1086 | .1086 | .0905 | .0905 |
| Max | .1629 | .2172 | .1991 | .2172 | .2534 |
| Min | .1267 | .0905 | .1086 | .0724 | .0905 |
| Avg | .1448 | .1471 | .1479 | .1283 | .1523 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084017 / 33 KV MADHELI S/S

Feeder No / Name : 201 / 11 KV MADHELI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6203 | .141 | .6325 | .1353 |
| 2 | | .6188 | .1445 | .6325 | .1186 |
| 3 | | .6219 | .1268 | .6401 | .1183 |
| 4 | | .6226 | .128 | .6241 | .1363 |
| 5 | | .6452 | .128 | .6241 | .1404 |
| 6 | | .6577 | .1489 | .6241 | .1622 |
| 7 | | .1734 | .1772 | .1928 | .1808 |
| 8 | | .1758 | .3953 | .1753 | .8069 |
| 9 | | .1741 | .4646 | .1753 | 1.0178 |
| 10 | | .1768 | .9437 | .1543 | 1.004 |
| 11 | | .1734 | .9669 | .1471 | .7545 |
| 12 | | .1753 | 1.0857 | .15 | .9069 |
| 13 | | .1543 | 1.1591 | .1337 | 1.004 |
| 14 | | .1526 | 1.1599 | .1151 | 1.0082 |
| 15 | | .1475 | 1.0487 | .1158 | .9602 |
| 16 | | .381 | .865 | .8471 | .7545 |
| 17 | | .3429 | .8624 | .9195 | .7733 |
| 18 | | .724 | 1.1506 | 1.1931 | 1.1128 |
| 19 | | .8573 | 1.3769 | 1.1478 | 1.1883 |
| 20 | | .8383 | 1.358 | 1.3106 | .9242 |
| 21 | | .7035 | .7202 | 1.2157 | .6081 |
| 22 | | .172 | .68 | .1892 | .5624 |
| 23 | .6791 | .1512 | .6481 | .1711 | .5182 |
| 24 | | .6413 | .1517 | .6481 | .1705 |
| Max | .6791 | .8573 | 1.3769 | 1.3106 | 1.1883 |
| Min | .6791 | .1475 | .1268 | .1151 | .1183 |
| Avg | .6791 | .4209 | .6680 | .5325 | .6278 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084017 / 33 KV MADHELI S/S

Feeder No / Name : 202 / 11 KV NAGRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6826 | .479 | .5898 | .4601 |
| 2 | | .6818 | .4204 | .5898 | .4426 |
| 3 | | .698 | .4332 | .5967 | .4241 |
| 4 | | .681 | .4097 | .5967 | .4426 |
| 5 | | .7078 | .4209 | .6133 | .4652 |
| 6 | | .7301 | .5067 | .6133 | .4733 |
| 7 | | .9186 | .5569 | .7373 | .5922 |
| 8 | | 1.2237 | .6658 | 1.1469 | .8391 |
| 9 | | 1.467 | .8991 | 1.4251 | .9415 |
| 10 | | 1.524 | .925 | 1.4586 | .8589 |
| 11 | | 1.3426 | .8391 | .9005 | .8145 |
| 12 | | 1.6766 | .8683 | 1.4154 | .9831 |
| 13 | | 1.4918 | 1.094 | 1.467 | 1.0608 |
| 14 | | 1.326 | 1.065 | 1.4353 | 1.0608 |
| 15 | | 1.0364 | .9867 | 1.2612 | .9175 |
| 21 | | | .3045 | | .2715 |
| 22 | | .5105 | .6226 | .4773 | .6478 |
| 23 | .7086 | .4766 | .5668 | .463 | .6081 |
| 24 | | .6866 | .4578 | .5668 | .463 |
| Max | .7086 | 1.6766 | 1.094 | 1.467 | 1.0608 |
| Min | .7086 | .4766 | .3045 | .463 | .2715 |
| Avg | .7086 | .9923 | .6590 | .9086 | .6719 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084017 / 33 KV MADHELI S/S

Feeder No / Name : 203 / 11 KV PANZURNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.1006 | .8565 | .9431 | 1.1039 |
| 2 | | 1.0838 | .8746 | .9431 | 1.0849 |
| 3 | | 1.0395 | .8366 | .9431 | 1.1039 |
| 4 | | 1.0195 | .8548 | .9619 | 1.142 |
| 5 | | 1.0605 | .8755 | .9619 | 1.161 |
| 6 | | 1.0995 | .9145 | .9619 | 1.1991 |
| 7 | | 1.0288 | .9145 | 1.0562 | 1.1812 |
| 8 | | 1.4075 | 1.1173 | 1.3443 | 1.2955 |
| 9 | | 1.546 | 1.5059 | 1.6057 | 1.2663 |
| 10 | | 1.4003 | 1.6514 | 1.2323 | 1.1765 |
| 11 | | 1.0349 | 1.4653 | 1.3943 | 1.3957 |
| 12 | | 1.0349 | 1.5263 | 1.4474 | 1.5466 |
| 13 | | 1.0719 | 1.6363 | 1.2631 | 1.5123 |
| 14 | | .9055 | 1.5725 | 1.3096 | 1.423 |
| 15 | | .8316 | 1.4675 | 1.4245 | 1.3256 |
| 21 | | | .7733 | | .8871 |
| 22 | | .9507 | .5228 | 1.1812 | .7922 |
| 23 | 1.2181 | .9326 | .9054 | 1.086 | .7545 |
| 24 | | 1.18 | .9127 | .9054 | 1.1622 |
| Max | 1.2181 | 1.546 | 1.6514 | 1.6057 | 1.5466 |
| Min | 1.2181 | .8316 | .5228 | .9054 | .7545 |
| Avg | 1.2181 | 1.0960 | 1.1149 | 1.1647 | 1.1849 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084017 / 33 KV MADHELI S/S

Feeder No / Name : 204 / Rajhauns express feeder

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .1107 | | .1448 | .1093 |
| 2 | | .1099 | | .1303 | .1099 |
| 3 | | .1108 | | .1143 | .1151 |
| 4 | | .1096 | | .1143 | .1146 |
| 5 | | .1099 | | .1143 | .1129 |
| 6 | | .1122 | | .1286 | .1139 |
| 7 | | .1142 | | .132 | .1152 |
| 8 | | .1158 | | .1357 | |
| 21 | | | | .1131 | |
| 22 | | | .1353 | .1128 | |
| 23 | .1113 | | .1429 | .109 | |
| 24 | | .1389 | | .1303 | .112 |
| Max | .1113 | .1389 | .1429 | .1448 | .1152 |
| Min | .1113 | .1096 | .1353 | .109 | .1093 |
| Avg | .1113 | .1147 | .1391 | .1233 | .1129 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 201 / SAI FEEDER WANI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .442 | .4268 | .503 | .4572 | .4572 | .4908 |
| 2 | | .442 | .4115 | .4725 | .4268 | .4268 | .4031 |
| 3 | | .442 | .381 | .4572 | .3963 | .4268 | .4557 |
| 4 | | .442 | .4268 | .4572 | .3963 | .3963 | .4557 |
| 5 | | .442 | .381 | .4572 | .381 | .3963 | .4557 |
| 6 | | .4572 | .4115 | .4877 | .4115 | .4268 | .4908 |
| 7 | | .4725 | .442 | .5335 | .4268 | .442 | .5258 |
| 8 | | .503 | .4877 | .5182 | .3963 | .4572 | .5258 |
| 9 | | | | | .5853 | .5721 | .5434 |
| 10 | | | | | .567 | .5201 | .5609 |
| 11 | | | | | .5853 | .5548 | .6024 |
| 12 | | | | | .6036 | .5375 | .5847 |
| 13 | | | | | .567 | .5083 | .567 |
| 14 | | | | | .5487 | .5083 | .5138 |
| 15 | | | | | .5304 | .4733 | .4755 |
| 16 | | | | | .5304 | .4908 | .5316 |
| 17 | | | | .6224 | .5256 | | .631 |
| 18 | | | | .823 | .7628 | | .7442 |
| 19 | | | | .8505 | .7537 | | .815 |
| 20 | | | | .8238 | .7701 | | .8059 |
| 21 | | | | .6984 | .6805 | | .7343 |
| 22 | | | | .6268 | .591 | | .6733 |
| 23 | .4877 | .4877 | .5487 | | | | .6268 |
| 24 | | .442 | .442 | .5182 | | | |
| Max | .4877 | .503 | .5487 | .8505 | .7701 | .5721 | .815 |
| Min | .4877 | .442 | .381 | .4572 | .381 | .3963 | .4031 |
| Avg | .4877 | .4572 | .4359 | .5900 | .5406 | .4747 | .5745 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 202 / 11 kv Warora INDUSTRIAL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5792 | .6097 | .7164 | .6097 | .7316 | .8505 |
| 2 | | .5792 | .5792 | | .5792 | .7468 | .8505 |
| 3 | | .5792 | .5639 | .6859 | .5792 | .7773 | .8505 |
| 4 | | .5639 | .5335 | .6706 | .5487 | .823 | .8505 |
| 5 | | .5487 | .4877 | .6706 | .6401 | .8688 | .8859 |
| 6 | | .6859 | .5487 | .7621 | .8383 | .9145 | .9391 |
| 7 | | .8535 | .7316 | .9907 | .9755 | .945 | 1.0631 |
| 8 | | .9602 | .8383 | .9755 | .9145 | 1.0364 | 1.0631 |
| 9 | | | | | 1.1157 | 1.1393 | 1.1694 |
| 10 | | | | | 1.0608 | 1.0692 | 1.134 |
| 11 | | | | | 1.0242 | 1.0517 | 1.0277 |
| 12 | | | | | 1.0059 | 1.0341 | .9922 |
| 13 | | | | | .9877 | .9214 | .9745 |
| 14 | | | | | .9694 | .8859 | .9745 |
| 15 | | | | | 1.0425 | .9214 | .5853 |
| 16 | | | | | .9511 | .9214 | .6024 |
| 17 | | | | .9054 | .9431 | | .8682 |
| 18 | | | | 1.3321 | 1.262 | | .8682 |
| 19 | | | | 1.182 | 1.1871 | | .8859 |
| 20 | | | | 1.0924 | 1.1041 | | .815 |
| 21 | | | | 1.0317 | .9955 | | .7619 |
| 22 | | | | .8688 | .8869 | | .7442 |
| 23 | .6859 | .6706 | .7621 | | 1.0608 | | .7087 |
| 24 | | .6249 | .6097 | .7316 | | | |
| Max | .6859 | .9602 | .8383 | 1.3321 | 1.262 | 1.1393 | 1.1694 |
| Min | .6859 | .5487 | .4877 | .6706 | .5487 | .7316 | .5853 |
| Avg | .6859 | .6645 | .6264 | .9011 | .9253 | .9242 | .8898 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 203 / 11 kv Nandori feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .6287 | .6097 | 1.0364 | .8078 | .7621 | .6405 |
| 2 | | .6097 | .5716 | 1.0364 | .7773 | .7468 | .6249 |
| 3 | | .5716 | .5716 | 1.0059 | .7773 | .7164 | .5937 |
| 4 | | .5716 | .5335 | .9907 | .7621 | .7164 | .5937 |
| 5 | | .5716 | .5335 | .9755 | .7621 | .7316 | .5468 |
| 6 | | .6668 | .6097 | 1.0059 | .7926 | .7316 | .5937 |
| 7 | | .724 | .6859 | 1.0364 | .823 | .7468 | .7499 |
| 8 | | 1.4327 | .4954 | 1.1126 | 1.0364 | 1.0974 | .8592 |
| 9 | | | | | 1.3717 | 1.2483 | 1.1717 |
| 10 | | | | | 1.4266 | 1.3283 | 1.2498 |
| 11 | | | | | 1.6644 | 1.3441 | 1.2654 |
| 12 | | | | | 1.6827 | 1.3916 | 1.2811 |
| 13 | | | | | 1.7193 | 1.4706 | 1.2809 |
| 14 | | | | | 1.7375 | 1.3757 | 1.2811 |
| 15 | | | | | 1.7558 | 1.3904 | 1.2342 |
| 16 | | | | | 1.7741 | 1.2967 | 1.1561 |
| 17 | | | | 1.3441 | 1.3283 | 1.2193 | 1.0467 |
| 18 | | | | 1.1498 | 1.0364 | .823 | .9061 |
| 19 | | | | 1.0722 | 1.0242 | .823 | .8124 |
| 20 | | | | 1.1336 | .9172 | .8383 | .8124 |
| 21 | | | | .9602 | .8583 | .7926 | .7811 |
| 22 | | | | .9231 | .7888 | .7011 | .7499 |
| 23 | .6668 | .6668 | 1.0974 | | | .6859 | .703 |
| 24 | | .6287 | .6097 | 1.0669 | | | |
| Max | .6668 | 1.4327 | 1.0974 | 1.3441 | 1.7741 | 1.4706 | 1.2811 |
| Min | .6668 | .5716 | .4954 | .9231 | .7621 | .6859 | .5468 |
| Avg | .6668 | .7072 | .6318 | 1.0566 | 1.1647 | .9990 | .9102 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 204 / 11 kv MAJARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .4268 | .4268 | .8993 | | .6859 | .7499 |
| 2 | | .4572 | .3658 | .884 | .5944 | .6859 | .7499 |
| 3 | | .442 | .3658 | .8535 | .5792 | .6706 | .6944 |
| 4 | | .442 | .3353 | .8535 | .5639 | .6706 | .679 |
| 5 | | .442 | .3353 | .8535 | .5639 | .6859 | .6481 |
| 6 | | .442 | .3658 | .8993 | .6097 | .7164 | .6481 |
| 7 | | .4877 | .4572 | .9755 | .6706 | .7621 | .6562 |
| 8 | | 1.1431 | .3963 | .9907 | .7926 | .9755 | .7907 |
| 9 | | | | | .9145 | .9998 | |
| 10 | | | | | .9694 | 1.078 | .9259 |
| 11 | | | | | .9145 | .9998 | .9414 |
| 12 | | | | | .8596 | 1.078 | 1.0185 |
| 13 | | | | | .9694 | 1.0936 | .9877 |
| 14 | | | | | 1.1706 | 1.0311 | .9877 |
| 15 | | | | | 1.2071 | 1.0311 | .9998 |
| 16 | | | | | 1.2254 | .9998 | .9722 |
| 17 | | | | 1.0623 | .9934 | .945 | 1.3125 |
| 18 | | | | .8453 | .9878 | .8993 | .9686 |
| 19 | | | | .9156 | 1.0442 | .8688 | .9105 |
| 20 | | | | .8648 | .9717 | .8535 | .8749 |
| 21 | | | | .8122 | .8951 | .823 | .8223 |
| 22 | | | | .7545 | .7291 | .8078 | .7907 |
| 23 | .503 | .4877 | .9145 | | | .7926 | .7499 |
| 24 | | .4725 | .4268 | .9145 | | | |
| Max | .503 | 1.1431 | .9145 | 1.0623 | 1.2254 | 1.0936 | 1.3125 |
| Min | .503 | .4268 | .3353 | .7545 | .5639 | .6706 | .6481 |
| Avg | .503 | .5243 | .4390 | .8919 | .8679 | .8763 | .8581 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 205 / Aanandvan SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2896 | .2286 | .2591 | .2439 | .2439 | .2835 |
| 2 | | .2743 | .2286 | .2591 | .2439 | .2439 | .2835 |
| 3 | | .2743 | .2134 | .2439 | .2439 | | .2835 |
| 4 | | .2743 | .2134 | .2439 | .2439 | .2439 | .2835 |
| 5 | | .2743 | .2134 | .2439 | .2743 | .2439 | .2835 |
| 6 | | .3353 | .3353 | .3201 | .3658 | .3353 | .3898 |
| 7 | | .4268 | .4268 | .4268 | .4572 | .381 | .4961 |
| 8 | | .3658 | .5792 | .4115 | .4572 | .381 | .3898 |
| 9 | | | | | .439 | .4251 | .4252 |
| 10 | | | | | .4024 | .4066 | .3544 |
| 11 | | | | | .3658 | .3696 | .3189 |
| 12 | | | | | .3658 | .3326 | .3189 |
| 13 | | | | | .3658 | .3174 | .3189 |
| 14 | | | | | .3658 | .3174 | .3544 |
| 15 | | | | | .3658 | .3734 | .567 |
| 16 | | | | | .3658 | .3174 | .5316 |
| 17 | | | | .2829 | .3772 | .2743 | .5316 |
| 18 | | | | .415 | .4338 | .2743 | .3189 |
| 19 | | | | .415 | .415 | .3048 | .6379 |
| 20 | | | | .3961 | .3961 | .3048 | .6024 |
| 21 | | | | .3395 | .3772 | .3048 | .567 |
| 22 | | | | .3018 | .2987 | .2439 | .5316 |
| 23 | .2743 | .2286 | .2591 | | | .2439 | .4961 |
| 24 | | .2896 | .2286 | .2591 | | | |
| Max | .2743 | .4268 | .5792 | .4268 | .4572 | .4251 | .6379 |
| Min | .2743 | .2286 | .2134 | .2439 | .2439 | .2439 | .2835 |
| Avg | .2743 | .3033 | .2926 | .3212 | .3575 | .3129 | .416 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 206 / 11 KV Warora TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7011 | .6097 | .945 | .9755 | 1.1279 | 1.1443 |
| 2 | | .7011 | .5639 | .9145 | .945 | 1.0669 | 1.1269 |
| 3 | | .6859 | .884 | .884 | .945 | .9755 | 1.0749 |
| 4 | | .6706 | .8383 | .8535 | .9145 | .9755 | 1.0402 |
| 5 | | .6706 | .7926 | .8383 | .9145 | .9145 | 1.0402 |
| 6 | | .7926 | .8078 | .8688 | .945 | .945 | 1.0923 |
| 7 | | .884 | .823 | .884 | .9755 | .945 | 1.1789 |
| 8 | | .945 | .8993 | .9145 | .945 | 1.0364 | 1.1616 |
| 9 | | | | | 1.39 | 1.3523 | 1.1963 |
| 10 | | | | | 1.3535 | 1.5083 | 1.2483 |
| 11 | | | | | 1.39 | 1.5257 | 1.3523 |
| 12 | | | | | 1.4266 | 1.4217 | 1.3176 |
| 13 | | | | | 1.2803 | 1.4198 | 1.2656 |
| 14 | | | | | 1.2437 | 1.3496 | 1.2309 |
| 15 | | | | | 1.1888 | 1.4175 | 1.1789 |
| 16 | | | | | 1.1157 | 1.2795 | 1.2136 |
| 17 | | | | 1.2071 | 1.1443 | 1.1888 | 1.283 |
| 18 | | | | 1.2795 | 1.4685 | 1.2955 | 1.491 |
| 19 | | | | 1.2178 | 1.4706 | 1.3717 | 1.4217 |
| 20 | | | | 1.3073 | 1.5939 | 1.3717 | 1.3696 |
| 21 | | | | 1.5074 | 1.6476 | 1.2803 | 1.283 |
| 22 | | | | 1.3969 | 1.5384 | 1.1888 | 1.2309 |
| 23 | .7926 | .9755 | 1.0059 | | | 1.0974 | 1.1616 |
| 24 | | .7316 | .9145 | .9907 | | | |
| Max | .7926 | .9755 | 1.0059 | 1.5074 | 1.6476 | 1.5257 | 1.491 |
| Min | .7926 | .6706 | .5639 | .8383 | .9145 | .9145 | 1.0402 |
| Avg | .7926 | .7758 | .8139 | 1.0673 | 1.2187 | 1.2198 | 1.2219 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 207 / 11 KV MANGLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .7049 | .724 | .9602 | .6097 | .7468 | .5668 |
| 2 | | .7049 | .6859 | .9145 | .5944 | .7316 | .5535 |
| 3 | | .6668 | .6478 | .9145 | .5639 | .7316 | .506 |
| 4 | | .6668 | .6097 | .884 | .5335 | .7164 | .4744 |
| 5 | | .6668 | .6097 | .884 | .5335 | .6859 | .6325 |
| 6 | | .7621 | .6668 | .945 | .6401 | .6859 | .6642 |
| 7 | | .7621 | .7049 | .9907 | .7926 | .7164 | .68 |
| 8 | | 1.2955 | .6859 | .9602 | .9907 | .945 | .759 |
| 9 | | | | | 1.1706 | 1.0364 | .7907 |
| 10 | | | | | 1.1888 | 1.0402 | .8381 |
| 11 | | | | | 1.2254 | 1.0082 | .9014 |
| 12 | | | | | 1.262 | 1.0883 | .9488 |
| 13 | | | | | 1.2437 | 1.0562 | .9804 |
| 14 | | | | | 1.262 | 1.0562 | .9804 |
| 15 | | | | | 1.2803 | 1.1043 | .9646 |
| 16 | | | | | 1.2803 | 1.1203 | .9488 |
| 17 | | | | .9922 | .9934 | 1.0364 | .9488 |
| 18 | | | | 1.0526 | .9503 | .823 | .933 |
| 19 | | | | 1.0159 | .9831 | .823 | .8697 |
| 20 | | | | .9878 | .9555 | .823 | .828 |
| 21 | | | | .7907 | .8029 | .7621 | .7907 |
| 22 | | | | .6882 | .7716 | .6859 | .8048 |
| 23 | .8002 | .8002 | 1.0059 | | | .6554 | .763 |
| 24 | | .743 | .724 | .9907 | | | .664 |
| Max | .8002 | 1.2955 | 1.0059 | 1.0526 | 1.2803 | 1.1203 | .9804 |
| Min | .8002 | .6668 | .6097 | .6882 | .5335 | .6554 | .4744 |
| Avg | .8002 | .7773 | .7065 | .9314 | .9377 | .8730 | .7830 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084028 / 33/11 KV WARORA SUB STATION

Feeder No / Name : 208 / 11 KV VIDEOCON

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .3353 | .3353 | .3353 | .3353 | .3353 | .4191 |
| 2 | | .3201 | .3201 | .3201 | .3201 | .3201 | .5144 |
| 3 | | .3353 | .3353 | .3353 | .3353 | .3353 | .5144 |
| 4 | | .3201 | .3353 | .3201 | .3353 | .3353 | .4191 |
| 5 | | .3353 | .3353 | .3353 | .3201 | .3048 | .4191 |
| 6 | | .3353 | .3201 | .3353 | .3201 | .3201 | .4191 |
| 7 | | .3353 | .3353 | .3353 | .3353 | .3353 | .4191 |
| 8 | | .3353 | .3353 | .3201 | .3353 | .3353 | .381 |
| 9 | | | | | .4024 | .4001 | .4001 |
| 10 | | | | | .4024 | .4001 | .4001 |
| 11 | | | | | .4024 | .4191 | .4191 |
| 12 | | | | | .4024 | .4001 | .4191 |
| 13 | | | | | | .381 | .4191 |
| 14 | | | | | .4024 | .381 | .4191 |
| 15 | | | | | .4024 | .381 | .4191 |
| 16 | | | | | .4024 | .4001 | .4191 |
| 17 | | | | .4572 | .381 | | .4191 |
| 18 | | | | .4382 | .4191 | | .4191 |
| 19 | | | | .4191 | .4191 | | .4191 |
| 20 | | | | .381 | .4001 | | .4191 |
| 21 | | | | .4382 | .4001 | | .4191 |
| 22 | | | | .4191 | .381 | | .4191 |
| 23 | .3353 | .3353 | .3353 | | | | .4191 |
| 24 | | .3201 | .3201 | .3353 | | | |
| Max | .3353 | .3353 | .3353 | .4572 | .4191 | .4191 | .5144 |
| Min | .3353 | .3201 | .3201 | .3201 | .3201 | .3048 | .381 |
| Avg | .3353 | .3307 | .3307 | .3683 | .374 | .3615 | .4241 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084030 / 33 kv Temburda s/s

Feeder No / Name : 201 / 11 kv TEMBURDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2591 | .2623 | .2439 | .1886 |
| 2 | | .2591 | .2591 | .2439 | .1886 |
| 3 | | .2743 | .2812 | .2258 | .1886 |
| 4 | | .3048 | .2591 | .2378 | .1698 |
| 5 | | .3048 | .2743 | .2439 | .1698 |
| 6 | | .3281 | .3005 | .2469 | .2075 |
| 7 | | .2263 | .2263 | .2075 | .2263 |
| 8 | | .2075 | .1886 | .2623 | .2688 |
| 9 | | .1886 | .2263 | .3086 | .3479 |
| 10 | | .2075 | .2075 | .3506 | .3361 |
| 11 | | .181 | .1886 | .3658 | .3281 |
| 12 | | .1886 | .1886 | .3704 | .3281 |
| 13 | | .1867 | .1509 | .3704 | .3549 |
| 14 | | .1886 | .1698 | .3506 | .3658 |
| 15 | | .2054 | .1509 | .3506 | .3395 |
| 16 | | .2075 | .1886 | .2353 | .1886 |
| 17 | | .2075 | .2075 | .1886 | .1886 |
| 18 | | .3584 | .3584 | .3395 | .3429 |
| 19 | | .3961 | .415 | .3961 | .4382 |
| 20 | .3772 | .4338 | .3961 | .415 | .4191 |
| 21 | | .3563 | .3077 | .3772 | .381 |
| 22 | | .2968 | .2881 | .2452 | .2858 |
| 23 | .3086 | .2656 | .2688 | .2263 | .2477 |
| 24 | | .2743 | .2623 | .2623 | .1886 |
| Max | .3772 | .4338 | .415 | .415 | .4382 |
| Min | .3086 | .181 | .1509 | .1886 | .1698 |
| Avg | .3429 | .2628 | .2511 | .2944 | .2787 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084030 / 33 kv Temburda s/s

Feeder No / Name : 202 / 11 KV SUMTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2559 | .2559 | .2107 | .1698 |
| 2 | | .2743 | .2591 | .2107 | .1509 |
| 3 | | .2743 | .2709 | .208 | .1509 |
| 4 | | .1905 | .286 | .176 | .1509 |
| 5 | | .3201 | .2709 | .208 | .132 |
| 6 | | .3437 | .2896 | .2408 | .1509 |
| 7 | | .132 | .132 | .1294 | .1509 |
| 8 | | .132 | .1509 | .3593 | .4167 |
| 9 | | .1715 | .1132 | .5182 | .5182 |
| 10 | | .132 | .1307 | .4999 | .3241 |
| 11 | | .112 | .0754 | .4843 | .3311 |
| 12 | | .0943 | .0747 | .4475 | |
| 13 | | .112 | .0373 | .4167 | .4268 |
| 14 | | .0747 | .0934 | .463 | .4531 |
| 15 | | .0943 | .0943 | .4784 | .4374 |
| 16 | | .0943 | .0943 | .0934 | .1143 |
| 17 | | .0943 | .1132 | .1132 | .1132 |
| 18 | | .2452 | .2452 | .2452 | .3239 |
| 19 | | .3584 | .3584 | .3584 | .3772 |
| 20 | .3584 | .3584 | .3584 | .3584 | .3584 |
| 21 | | .3041 | .2949 | .2075 | .3018 |
| 22 | | .2812 | .2753 | .2075 | .1886 |
| 23 | .3086 | .2623 | .2343 | .1698 | .1886 |
| 24 | | .2743 | .2229 | .2286 | .1698 |
| Max | .3584 | .3584 | .3584 | .5182 | .5182 |
| Min | .3086 | .0747 | .0373 | .0934 | .1132 |
| Avg | .3335 | .2078 | .1971 | .2930 | .2652 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 084030 / 33 kv Temburda s/s

Feeder No / Name : 203 / 11 KV DONGARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

| DATE | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .2107 | .2201 | .1806 | .1132 |
| 2 | | .1829 | .2107 | .1635 | .1132 |
| 3 | | .2134 | .2286 | .1572 | .1132 |
| 4 | | .2286 | .2286 | .1593 | .1132 |
| 5 | | .2286 | .2054 | .1783 | .0943 |
| 6 | | .2439 | .2709 | .1981 | .132 |
| 7 | | .1132 | .1307 | .1307 | .132 |
| 8 | | .0754 | .1075 | .2439 | .3241 |
| 9 | | .0762 | .0943 | .4167 | .3658 |
| 10 | | .1132 | .0943 | .4012 | .3462 |
| 11 | | .0943 | .0762 | .3858 | .3311 |
| 12 | | .0943 | .0747 | .3658 | .3858 |
| 13 | | .0943 | | .3658 | .442 |
| 14 | | .0943 | | .3549 | .301 |
| 15 | | .0943 | | .3704 | .3201 |
| 16 | | .0943 | .0754 | .0566 | .0953 |
| 17 | | .0754 | .0943 | .0754 | .0953 |
| 18 | | .1698 | .1698 | .1698 | .1905 |
| 19 | | .1886 | .2263 | .2075 | .2477 |
| 20 | .2075 | .1886 | .2263 | .2075 | .2286 |
| 21 | | .2315 | .208 | .1698 | .1905 |
| 22 | | .208 | .2056 | .132 | .132 |
| 23 | .2107 | .1957 | .1875 | .1132 | .132 |
| 24 | | .1806 | .1738 | .1852 | .1132 |
| Max | .2107 | .2439 | .2709 | .4167 | .442 |
| Min | .2075 | .0754 | .0747 | .0566 | .0943 |
| Avg | .2091 | .1538 | .1671 | .2246 | .2105 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 088003 / 220 KV WARORA S/S

Feeder No / Name : 403 / 33 KV SHEGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 19-DEC-17 | 20-DEC-17 |
|------|-----------|-----------|
| HR | Load (MW) | Load (MW) |
| 1 | .5716 | .5716 |
| 2 | .5716 | .5716 |
| 3 | .5716 | .5716 |
| 4 | .5716 | .5716 |
| 5 | .5716 | .5716 |
| 6 | .5716 | .5716 |
| 7 | .5716 | .5716 |
| 8 | .5716 | .5716 |
| 9 | .5716 | .5716 |
| 10 | .5716 | .5716 |
| 11 | .5716 | .5716 |
| 12 | .5716 | .5716 |
| 13 | .5716 | .5716 |
| 14 | .5716 | .5716 |
| 15 | .5716 | .5716 |
| 16 | .5716 | .5716 |
| 17 | .5716 | .5716 |
| 18 | .5716 | .5716 |
| 19 | .5716 | .5716 |
| 20 | .5716 | .5716 |
| 21 | .5716 | .5716 |
| 22 | .5716 | .5716 |
| 23 | .5716 | .5716 |
| Max | .5716 | .5716 |
| Min | .5716 | .5716 |
| Avg | .5716 | .5716 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 088003 / 220 KV WARORA S/S

Feeder No / Name : 406 / 33 KV MADHELI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 |
|------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .5716 | .5716 |
| 2 | 1.7147 | .5716 | .5716 |
| 3 | 1.7147 | .5716 | .5716 |
| 4 | .5716 | .5716 | .5716 |
| 5 | .5716 | .5716 | .5716 |
| 6 | .5716 | .5716 | .5716 |
| 7 | .5716 | .5716 | .5716 |
| 8 | .5716 | .5716 | .5716 |
| 9 | .5716 | .5716 | .5716 |
| 10 | .5716 | .5716 | .5716 |
| 11 | .5716 | .5716 | .5716 |
| 12 | .5716 | .5716 | .5716 |
| 13 | .5716 | .5716 | .5716 |
| 14 | .5716 | .5716 | .5716 |
| 15 | .5716 | .5716 | .5716 |
| 16 | .5716 | .5716 | .5716 |
| 17 | .5716 | .5716 | .5716 |
| 18 | .5716 | .5716 | .5716 |
| 19 | .5716 | .5716 | .5716 |
| 20 | .5716 | .5716 | .5716 |
| 21 | .5716 | .5716 | .5716 |
| 22 | .5716 | .5716 | .5716 |
| 23 | .5716 | .5716 | .5716 |
| Max | 1.7147 | .5716 | .5716 |
| Min | .5716 | .5716 | .5716 |
| Avg | .6755 | .5716 | .5716 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 088003 / 220 KV WARORA S/S

Feeder No / Name : 407 / 33KV MainI/C-2

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | 1.6461 | 1.829 | 2.0576 | 1.7833 | 2.1948 | 2.1491 |
| 2 | | 1.6461 | 1.7833 | 2.0576 | 1.7375 | 2.1948 | 2.1033 |
| 3 | | 1.6004 | .5716 | 2.0119 | 1.6918 | 2.1491 | 2.0576 |
| 4 | | 1.6004 | .5716 | 2.0119 | 1.6461 | 2.1491 | 2.0576 |
| 5 | | 1.6004 | .5716 | 2.0119 | .5716 | 2.1491 | 2.0576 |
| 6 | | 1.7375 | 1.7833 | 2.1491 | 1.9204 | 2.1948 | 2.1948 |
| 7 | | 2.0576 | 2.0576 | 2.332 | 2.332 | 2.2862 | 2.3777 |
| 8 | | 2.2405 | 2.332 | 2.3777 | 4.2981 | 2.4691 | 2.1948 |
| 9 | | | | | | .5716 | |
| 10 | | | | | | .5716 | |
| 11 | | | | | | .5716 | |
| 12 | | | | | | .5716 | |
| 13 | | | | | | .5716 | |
| 14 | | | | | | .5716 | |
| 15 | | | | | | .5716 | |
| 16 | | | | | | .5716 | |
| 17 | | | | 2.3388 | 2.552 | .5716 | |
| 18 | | | | 3.2773 | .5716 | .5716 | |
| 19 | | | | 3.1276 | 3.3122 | .5716 | |
| 20 | | | | 3.3122 | 3.4568 | .5716 | |
| 21 | | | | 3.0407 | .5716 | .5716 | |
| 22 | | | | 2.7435 | .5716 | .5716 | |
| 23 | 1.9204 | 2.2862 | 2.1948 | 2.3045 | .5716 | .5716 | |
| 24 | | 1.7375 | 1.8747 | 2.1033 | 2.1948 | 2.6337 | |
| Max | 1.9204 | 2.2862 | 2.332 | 3.3122 | 4.2981 | 2.6337 | 2.3777 |
| Min | 1.9204 | 1.6004 | .5716 | 2.0119 | .5716 | .5716 | 2.0576 |
| Avg | 1.9204 | 1.8153 | 1.5570 | 2.4536 | 1.8614 | 1.2081 | 2.1491 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 088003 / 220 KV WARORA S/S

Feeder No / Name : 409 / 33KV Main I/C -1

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

| DATE | 15-DEC-17 | 16-DEC-17 | 17-DEC-17 | 18-DEC-17 | 19-DEC-17 | 20-DEC-17 | 21-DEC-17 |
|------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| HR | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) | Load (MW) |
| 1 | | .8688 | .823 | 3.2922 | 2.2862 | 2.5149 | 2.332 |
| 2 | | .8688 | .823 | 3.2465 | 2.2405 | 2.5149 | 2.332 |
| 3 | | .8688 | .823 | 3.2007 | 2.2405 | 2.4691 | .5716 |
| 4 | | .823 | .823 | 3.2007 | 2.1948 | 2.4234 | 2.2862 |
| 5 | | .8688 | .823 | 3.2007 | 2.1948 | 2.4234 | 2.2862 |
| 6 | | .8688 | .9145 | 3.4294 | 2.5149 | 2.4234 | 2.4234 |
| 7 | | 1.1431 | 1.0059 | 3.7037 | 2.7892 | 2.7435 | 2.652 |
| 8 | | 4.4353 | 1.0517 | 3.7494 | 3.2465 | 3.7494 | 2.9264 |
| 9 | | 4.6639 | | .5716 | | .5716 | .5716 |
| 10 | | 4.9383 | | .5716 | | .5716 | .5716 |
| 11 | | 5.0297 | | .5716 | | .5716 | .5716 |
| 12 | | | | .5716 | | .5716 | .5716 |
| 13 | | | | .5716 | | .5716 | .5716 |
| 14 | | | | .5716 | | .5716 | .5716 |
| 15 | | | | .5716 | | .5716 | .5716 |
| 16 | | | | .5716 | | .5716 | .5716 |
| 17 | | | | .5716 | | .5716 | .5716 |
| 18 | | | | .5716 | | .5716 | .5716 |
| 19 | | | | .5716 | | .5716 | .5716 |
| 20 | | | | .5716 | | .5716 | .5716 |
| 21 | | | | .5716 | | .5716 | .5716 |
| 22 | | | | .5716 | | .5716 | .5716 |
| 23 | .9145 | | 3.4294 | .5716 | | .5716 | .5716 |
| 24 | | .8688 | .823 | 3.2922 | | | |
| Max | .9145 | 5.0297 | 3.4294 | 3.7494 | 3.2465 | 3.7494 | 2.9264 |
| Min | .9145 | .823 | .823 | .5716 | 2.1948 | .5716 | .5716 |
| Avg | .9145 | 2.1872 | 1.1340 | 1.6204 | 2.4634 | 1.2972 | 1.1471 |

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

CHANDRAPUR ZONE[064]

CHANDRAPUR CIRCLE[640]

WARORA DIVSION[642]

WARORA (U) S/DN[332] BU 2178

Substation No/ Name :- 088003 / 220 KV WARORA S/S

Feeder No / Name : 501 / 66 KV GHUGUS CKT 1 MAJARI NON SHEDDABLE EXPRESS HV FEEDERS
 WCL Feeder KV- 66 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

| DATE | 20-DEC-17 |
|------|-----------|
| HR | Load (MW) |
| 1 | 1.1431 |
| 2 | 1.1431 |
| 3 | 1.1431 |
| 4 | 1.1431 |
| 5 | 1.1431 |
| 6 | 1.1431 |
| 7 | 1.1431 |
| 8 | 1.1431 |
| 9 | 1.1431 |
| 10 | 1.1431 |
| 11 | 1.1431 |
| 12 | 1.1431 |
| 13 | 1.1431 |
| 14 | 1.1431 |
| 15 | 1.1431 |
| 16 | 1.1431 |
| 17 | 1.1431 |
| 18 | 1.1431 |
| 19 | 1.1431 |
| 20 | 1.1431 |
| 21 | 1.1431 |
| 22 | 1.1431 |
| 23 | 1.1431 |
| Max | 1.1431 |
| Min | 1.1431 |
| Avg | 1.1431 |