

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 201 / 11 kv Aurangapura Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.307	1.4146
2	1.307	1.358
3	1.2936	1.2826
4	1.4003	1.226
5	1.4146	1.3392
6	1.4784	1.6221
7	1.5497	1.7541
8	1.6804	1.6817
9	1.7187	1.7926
11	2.1216	2.0485
12	2.4508	2.5318
13	2.4764	
14	2.3777	
15	2.268	2.2546
16	2.268	2.4025
17	2.5086	2.4025
18	2.6029	2.6981
19	2.8829	2.7721
20	2.9569	2.894
21		2.8006
22	2.452	2.6139
23	1.6975	1.8298
24	1.3676	1.4712
<b>Max</b>	<b>2.9569</b>	<b>2.894</b>
<b>Min</b>	<b>1.2936</b>	<b>1.226</b>
<b>Avg</b>	<b>1.9809</b>	<b>2.0091</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 202 / 11 KV SAMARTH NAGAR FEEDR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.6804	1.7353
2	1.6804	1.6598
3	1.7556	1.6032
4	1.7737	1.6221
5	1.8861	1.7164
6	1.848	1.9239
7	2.0165	2.3011
8	2.1472	2.3285
9	2.2405	2.4025
11	2.8715	2.8715
12	2.6703	2.8829
13	2.6612	
14	2.6703	
15	2.5423	2.6427
16	2.6337	2.6242
17	2.7915	2.5873
18	2.9613	2.7536
19	3.0803	2.9754
20	3.0803	3.0807
21		3.0434
22	2.6029	2.8292
23	2.0748	2.0911
24	1.7364	1.8107
Max	3.0803	3.0807
Min	1.6804	1.6032
Avg	2.3366	2.3565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 203 / 11 kv city chowk feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		1.2071
2	1.1203	1.1694
3	1.1458	1.1694
4	1.1576	1.1317
5	1.2449	1.1506
6	1.2197	1.094
7	1.1949	1.3014
8	1.4003	1.4335
9	1.4937	1.5339
11	1.5546	1.6461
12	1.4998	1.6263
13	1.2382	
14	1.4449	
15	1.2803	1.2197
16		1.1643
17	1.3769	1.2936
18	1.5466	1.5154
19	1.6632	1.6632
20	1.7353	1.6804
21	1.6078	1.5684
22	1.5089	1.5089
23	1.3957	1.475
24	1.1763	1.2637
Max	1.7353	1.6804
Min	1.1203	1.094
Avg	1.3812	1.3722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 204 / 11 KV bus stand Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1088	1.1317
2	1.0829	1.094
3	1.0719	1.0374
4	1.1203	1.094
5	1.226	1.1317
6	1.2012	1.226
7	1.251	1.4335
8	1.307	1.4045
9	1.419	1.6263
11	1.6827	1.7741
12	1.6827	1.7187
13	1.6817	
14	1.6644	
15	1.5181	1.5708
16		1.6448
17	1.6221	1.6632
18	1.7918	1.6632
19	1.8673	1.848
20	1.8673	1.7737
21	1.5893	1.7187
22	1.4335	1.6975
23	1.3014	1.3817
24	1.1576	1.226
<b>Max</b>	<b>1.8673</b>	<b>1.848</b>
<b>Min</b>	<b>1.0719</b>	<b>1.0374</b>
<b>Avg</b>	<b>1.4385</b>	<b>1.4695</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 205 / 11 KV VASANT BHUVAN FEEDER Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1576	1.226
2	1.1576	1.1694
3	1.1827	1.1317
4	1.307	1.094
5	1.3203	1.4712
6	1.3306	1.7353
7	1.363	1.5655
8	1.4003	1.4146
9	1.4003	1.5154
11	1.5729	1.6095
12	1.6461	1.7556
13	1.4784	
14	1.4998	
15	1.4083	1.423
16		1.3121
17	1.5466	1.386
18	1.6975	1.5893
19	1.905	1.7741
20	1.9805	1.8671
21	1.848	1.9404
22	1.7918	1.7918
23	1.4146	1.5123
24	1.2323	1.2826
Max	1.9805	1.9404
Min	1.1576	1.094
Avg	1.4837	1.5032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 207 / ATM FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0185	.0189
2	.0187	.0189
3	.0185	.0189
4	.0187	.0189
5	.0189	.0189
6	.0185	
7	.0187	.0189
8	.0187	.0189
9	.0187	.0185
11	.0183	.0183
12	.0183	.0185
13	.0185	
14	.0183	
15	.0183	.0185
16		.0185
17	.0189	.0185
18	.0189	.0189
19	.0189	
20	.0185	
21	.0185	
22	.0191	
23	.0189	
24	.0187	.0189
Max	.0191	.0189
Min	.0183	.0183
Avg	.0186	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044051 / 33 / 11 KV POWER HOUSE S/S

Feeder No / Name : 208 / Medical(jublipark water works) Feeder KV- 11 / OUTGOING LT WW Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		.0189
2		.0189
3	.0373	.0189
4	.056	.0189
5	.0566	.0566
6	.0554	.0566
7	.056	.0566
8	.056	.0566
9	.056	.0566
11	.0549	.0183
12	.0549	.0554
13	.0554	
14	.0549	
15	.0549	.0554
16		.0554
17	.0566	.0566
18	.0566	.0566
19	.0554	.0566
20	.0554	.056
21	.0566	.056
22		.0566
23	.0566	.0566
24	.0373	.0566
Max	.0566	.0566
Min	.0373	.0183
Avg	.0538	.0474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 201 / UNIVERSITY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0175	.0174
2	.0175	.0173
3	.0175	.0172
4	.0175	.0172
5	.0175	.0172
6	.0175	.0171
7	.0175	.0172
8	.0175	.0172
9	.0351	.0381
10	.0918	.0762
11	.1655	.0762
12	.1653	.1524
13	.1651	.1715
14	.1466	.1524
15		.1334
16		.1143
17	.1655	.1143
18	.128	.0953
19	.0367	.0762
20	.0364	.0572
21	.0368	.0572
22	.0356	.0381
23	.0356	.0191
24	.0175	.017
Max	.1655	.1715
Min	.0175	.017
Avg	.0637	.0636



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 202 / MAQBARA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.0119	2.0224
2	1.9936	2.057
3	1.9753	2.2016
4	2.1399	2.3901
5	2.268	2.4243
6	2.3777	2.4402
7	2.5606	2.5843
8	2.524	2.7549
9	2.6337	3.0674
10	2.5739	3.0483
11	2.4427	3.1245
12	2.2958	2.8578
13	.0184	2.6482
14	2.14	2.0005
15		1.8861
16		1.9433
17	2.1674	2.3053
18	2.6382	2.7054
19	2.775	3.0483
20	2.7859	2.934
21	2.81	3.0483
22	2.6631	2.6673
23	2.3643	2.4006
24	2.0668	2.1128
<b>Max</b>	<b>2.81</b>	<b>3.1245</b>
<b>Min</b>	<b>.0184</b>	<b>1.8861</b>
<b>Avg</b>	<b>2.2830</b>	<b>2.5280</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 203 / SAI FEEDER  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1867	.1903
2	.168	.1903
3	.168	.1903
4	.168	.1711
5	.168	.1713
6	.168	.1903
7	.168	.1708
8	.2054	.2087
9	.2054	.2096
10	.2467	.1905
11	.3033	.2667
12	.3226	.3048
13	.3416	.3429
14	.3226	.3239
15		.3239
16		.3048
17	.3045	.2667
18	.2665	.2667
19	.1905	.2667
20	.2094	.2477
21	.2474	.2286
22	.2275	.2477
23	.2083	.2286
24	.2054	.1896
Max	.3416	.3429
Min	.168	.1708
Avg	.2274	.2372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 204 / LANI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3547	.3569
2	.2987	.3368
3	.2801	.3757
4	.2801	.3929
5	.3921	.4303
6	.5415	.4481
7	.5601	.4303
8	.4668	.4321
9	.3921	.4382
10	.3719	.4191
11	.2972	.4572
12	.2969	.381
13	.2783	.3048
14	.2783	.2858
15		.2667
16		.3048
17	.2755	.3048
18	.3347	.381
19	.3669	.4191
20	.4133	.4382
21	.4508	.381
22	.3881	.4001
23	.3881	.4001
24	.3547	.3533
<b>Max</b>	<b>.5601</b>	<b>.4572</b>
<b>Min</b>	<b>.2755</b>	<b>.2667</b>
<b>Avg</b>	<b>.3664</b>	<b>.3808</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044214 / UNIVERSITY

Feeder No / Name : 205 / 11 KV PANCHHKI  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8413	.8554
2	.823	.874
3	.8048	.9111
4	.8779	.9483
5	1.0974	.963
6	1.3169	.9815
7	1.2986	1.1619
8	1.1523	1.2222
9	1.1888	1.1812
10	1.1157	1.3527
11	1.0238	1.4098
12	.9959	1.2955
13	.9649	1.1431
14	.9093	.9526
15		.7811
16		.8192
17	.9018	.9145
18	1.0663	1.0288
19	1.2673	1.3146
20	1.2554	1.3717
21	1.2725	1.2955
22	1.0917	1.1431
23	.9653	1.0479
24	.8328	.8706
<b>Max</b>	<b>1.3169</b>	<b>1.4098</b>
<b>Min</b>	<b>.8048</b>	<b>.7811</b>
<b>Avg</b>	<b>1.0484</b>	<b>1.0766</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 201 / Kohinoor

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.2896	.2957
2	.2926	.2957
3	.2957	.2987
4	.2865	.2957
5	.2987	.3292
6	.3258	.3326
7	.3841	.4024
8	.394	.4066
9	.394	.3696
10		.335
11		.3395
14	.2978	
15	.2577	.2945
16	.2945	.2587
17		.2926
18	.3696	.3258
19	.3696	.3696
20	.4435	.4119
21	.3696	.3439
22	.3696	.3361
23		.2957
24	.2957	.2957
Max	.4435	.4119
Min	.2577	.2587
Avg	.3349	.3298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 202 / Ghati Medical Express  
Feeder KV- 11 / OUTGOING

HV Non-Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3658	.3734
2	.3658	.3696
3	.3361	.2957
4	.3224	.3734
5	.3696	.3696
6	.3841	.4108
7	.4298	.4435
8	.439	.4435
9	.5121	.5175
10		.5658
11		.5975
14	.6084	
15	.6348	.5313
16	.6348	.5584
17		.4298
18	.4066	.4755
19	.5175	.439
20	.4854	.439
21	.4066	.4298
22	.4108	.3881
23		.362
24	.362	.3734
Max	.6348	.5975
Min	.3224	.2957
Avg	.4440	.4375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

A'BAD POWER HOUSE[394] BU 4394

Substation No/ Name :- 044223 / 33 KV GHATI SUBSTATION

Feeder No / Name : 203 / CANCER HOSPITAL

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0554	
2	.0549	
3	.0543	
4	.0549	
5	.056	
6	.0716	
7	.0543	.0373
8	.0724	.0377
9	.0905	.1494
10		.184
11		.2259
14	.1882	
15	.1494	.1506
16	.1506	.1494
17		.1629
18	.112	.1478
19	.0377	.112
20		.0905
21		.0732
22		.0724
23		.0747
24	.0747	
Max	.1882	.2259
Min	.0377	.0373
Avg	.0851	.1191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 201 / 11 KV MIDC (SANJAWARTHA) SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1715	.1905
2	.1715	.1905
3	.1715	.1905
4	.1715	.1905
5	.1715	.1905
6	.1715	.1715
7	.1524	.1524
8	.2096	.1715
9	.2667	.1715
11	.5144	.4001
12	.5906	.381
13	.5335	.4572
14	.5716	
15	.5525	.4382
16	.4763	.381
18	.2858	.1905
19	.2096	.1905
20	.1905	.2096
21	.2096	.1905
22	.1905	.1905
23	.2477	.2096
24	.1905	.1905
<b>Max</b>	<b>.5906</b>	<b>.4572</b>
<b>Min</b>	<b>.1524</b>	<b>.1524</b>
<b>Avg</b>	<b>.2919</b>	<b>.2404</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 202 / 11 KV I.T.I Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.9052	1.9052
2	1.9052	1.9052
3	1.9052	1.9052
4	1.8099	1.848
5	2.0386	2.1148
6	2.8578	2.6673
7	3.2007	3.2388
8	3.3722	3.4865
9	3.1817	3.2198
11	2.7054	2.7816
12	2.4768	2.6673
13	2.6292	2.3434
14	2.191	
15	2.21	2.21
16	2.21	2.0576
18	3.2388	
19	3.4294	3.5437
20	3.4294	3.8104
21	2.8578	3.2388
22	2.7244	2.6673
23	2.5149	2.553
24	2.0767	2.1529
Max	3.4294	3.8104
Min	1.8099	1.848
Avg	2.5850	2.6158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 203 / 11 KV KAMAL NAYAN BAJAJ SHEDDABLE FEEDER HAVING WEEKLY  
EXPR Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3048	.3429
2	.3048	.3429
3	.3048	.3429
4	.3048	
5	.2096	.3429
6	.3048	.3429
7	.3429	.362
8	.4001	.3239
9	.362	.362
11	.4001	.4382
12	.2286	.3429
13	.362	.3429
14	.4191	
15	.4191	.381
16	.362	.362
17		.3429
18	.4191	.4191
19	.4191	.4001
20	.4191	.4382
21	.4572	.4191
22	.4191	.4191
23	.4001	.381
24	.4001	.3429
Max	.4572	.4382
Min	.2096	.3239
Avg	.3620	.3710

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 204 / 11 KV GOLWADI Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8573	.9145
2	.8573	.8573
3	.8573	.8573
4	.8192	.8573
5	.9717	.9907
6	1.2574	1.2384
7	1.3527	1.4098
8	1.4098	1.4289
9	1.3336	1.4098
11	1.3527	1.2765
12	1.1622	1.2003
13	.9335	
14	.9717	
15	.9335	1.0479
16	1.0098	1.086
17		.9526
18	1.2003	1.1431
19	1.2003	1.1812
20	1.3336	1.2955
21	1.2574	1.2574
22	1.1431	1.1812
23	1.086	1.1622
24	.9907	.9907
Max	1.4098	1.4289
Min	.8192	.8573
Avg	1.1041	1.1304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 206 / 11 KV RAHUL NAGAR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.7147	1.8099
2	1.7147	1.8099
3	1.7147	1.8099
4	1.7147	1.8099
5	1.848	1.9814
6	2.3815	2.191
7	2.4958	2.4958
8	2.7435	2.5149
9	2.7244	2.6673
11	2.3243	2.572
12	2.1529	2.4196
13	1.9624	2.2481
14	1.8861	
15	1.7147	1.6194
16	1.7337	1.6194
17		1.9052
18	2.4387	2.1338
19	2.6292	2.21
20	2.6673	2.5911
21	2.4387	2.2862
22	2.2291	2.0957
23	1.9814	2.0576
24	1.7337	1.8671
<b>Max</b>	<b>2.7435</b>	<b>2.6673</b>
<b>Min</b>	<b>1.7147</b>	<b>1.6194</b>
<b>Avg</b>	<b>2.1338</b>	<b>2.1234</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 207 / 11 KV M.I.T. EXPRESS SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0572	.0572
2	.0572	.0572
3	.0572	.0572
4	.0572	.0572
5	.0572	.0572
6	.0572	.0572
7	.0572	
8	.0572	.0762
9	.0953	.0762
11	.0762	.0953
12	.0381	.0381
13	.0572	.0762
14	.0381	
15	.0762	.0572
16	.0381	.0381
17		.0762
18	.0762	.0953
19	.0572	.0762
20	.0572	.0572
21	.0572	.0572
22	.0572	.0572
23	.0572	.0572
24	.0572	.0572
Max	.0953	.0953
Min	.0381	.0381
Avg	.0589	.0635

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044019 / 33/11 KV RAILWAY STATION

Feeder No / Name : 208 / 11kV MIDC(NIRLAP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6478	.6478
2	.6478	.6478
3	.6287	.6478
4	.6478	.6287
5	.6097	.7049
6	.8954	.724
7	.8573	.7621
8	.9526	.9335
9	1.105	1.0098
11	1.2955	1.105
12	1.086	.9526
13	1.0288	1.0098
14	1.2955	
15	1.086	.9335
16	1.0479	.8764
18	1.105	.9526
19	.9526	.7621
20	.9145	.7621
21	.8573	.7049
22	.9526	.7621
23	.8954	.7621
24	.6097	.6668
<b>Max</b>	<b>1.2955</b>	<b>1.105</b>
<b>Min</b>	<b>.6097</b>	<b>.6287</b>
<b>Avg</b>	<b>.9145</b>	<b>.8074</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 201 / 11 KV HOLYCROSS

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.4272	2.3152
2	2.3525	2.1658
3	2.3339	2.1658
4	2.4646	2.1658
5	2.6513	2.6326
6	2.6886	2.9874
7	3.0807	3.2674
8	3.006	
9	3.1741	3.035
10		3.1971
11	3.2526	3.2341
12		3.1786
13	3.0493	
14	2.7721	
15	2.5972	2.5034
16	2.809	2.6612
17	2.6578	2.9199
18	2.7435	2.7446
19	2.8464	2.9384
20	3.1207	3.2341
21	2.8807	3.0862
22	2.6578	3.0123
23		2.7446
24	2.5393	2.4646
Max	3.2526	3.2674
Min	2.3339	2.1658
Avg	2.7669	2.7931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 202 / 11 KV CANTONMENT

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.307	1.3443
2	1.2883	1.3256
3	1.2696	1.3256
4	1.2696	1.307
5	1.3817	1.419
6	1.587	1.5684
7	1.7364	1.6804
8	1.7364	
9	1.7372	1.5432
10	1.6448	1.5432
11	1.5729	1.4415
13	1.386	
14	1.3256	
15	1.46	1.2003
16	.9457	1.3306
17	1.3717	1.3491
18	1.4575	1.363
19	1.5604	1.6448
20	1.7833	1.9605
21	1.7147	1.885
22	1.6289	1.7364
23		1.6263
24	1.419	1.475
Max	1.7833	1.9605
Min	.9457	1.2003
Avg	1.4811	1.5035



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 203 / 11 KV M.E.S. EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.5316	.4607
2	.5138	.4607
3	.5138	.4607
4	.4961	.4607
5	.567	.4961
6	.6024	.5316
7	.6379	.6024
8	.6024	
9	.5083	.5487
10	.5609	.5144
11	.6661	.5258
12		.5144
13	.5935	
14	.4557	
15	.3506	.3944
16	.3681	.4207
17	.4287	
18	.5487	.5144
19	.5316	.5487
20	.6001	
21	.6344	.6173
22	.6001	.583
23		.5144
24	.5316	.4607
Max	.6661	.6173
Min	.3506	.3944
Avg	.5383	.5068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044038 / 33/11 KV CHAWANI

Feeder No / Name : 204 / MILIND COLLEGE

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6954	.6676
2	.6676	.6537
3	.6676	.6537
4	.6676	.6676
5	.6954	.7232
6	.6954	.7788
7	.7788	.8901
8	.7788	
9	.7514	1.0288
10	.6737	1.0288
11	.6638	.7404
13	.7385	
14	.6127	
15	.4595	.823
16	.5959	.6127
17	.823	.57
18	.8916	.7276
19	1.0631	.7148
20	1.2346	.6859
21	1.1317	.7659
22	1.0631	.7021
23		.6664
24	.6954	.6676
Max	1.2346	1.0288
Min	.4595	.57
Avg	.7748	.7384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 201 / 11 kV Dishanagari Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.307	1.419
2	1.307	1.419
3	1.307	1.419
4	1.4937	1.4937
5	1.6057	1.6804
6	1.8484	1.8671
7	1.8671	2.0538
8	2.0538	2.0911
9	1.8298	1.8671
10	1.6632	1.6632
11	1.4632	1.5154
12	1.3535	1.4784
13		1.2803
14		1.2437
15		1.2803
16		1.2197
17	1.6095	1.2071
18	1.6461	1.3535
19	1.6827	1.7741
20	2.0165	1.9044
21	1.8671	1.8671
22	1.6804	1.7924
23	1.531	1.5684
24	1.419	1.4563
Max	2.0538	2.0911
Min	1.307	1.2071
Avg	1.6276	1.5798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 202 / 11 kV Deolai Chowk Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.307	1.3817
2	1.307	1.3817
3	1.307	1.3817
4	1.419	1.419
5	1.4563	
6	1.4937	
7	1.6057	
8	1.6804	
9	1.5524	
10	1.5524	
11	1.5729	1.4842
12	1.5203	1.4632
13		1.3756
14		1.267
15		1.1946
16		1.2803
17	1.3169	1.1946
18	1.39	1.1946
19	1.4998	1.5893
20	1.8671	1.7551
21	1.7924	1.7177
22	1.6804	1.7924
23	1.5684	1.5684
24	1.307	1.4937
Max	1.8671	1.7924
Min	1.307	1.1946
Avg	1.5098	1.4408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044219 / 33/11 KV SATARA S/S

Feeder No / Name : 203 / 11 kV Sara Siddhi Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.4937	1.4937
2	1.4937	1.4937
3	1.4937	1.4937
4	1.6804	1.6804
5	2.1472	2.1472
6	2.3011	2.2779
7	2.2405	2.4272
8	2.2405	2.2405
9	1.885	1.9791
10	1.6632	1.7741
11	1.4632	1.6095
12	1.3032	1.5524
13		1.3756
14		1.3535
15		1.39
16		1.448
17	1.6289	1.448
18	1.6827	1.4842
19	1.7558	1.848
20	2.3152	2.2405
21	2.2405	2.1658
22	2.0538	2.0911
23	1.7002	1.8671
24	1.5524	1.6057
<b>Max</b>	<b>2.3152</b>	<b>2.4272</b>
<b>Min</b>	<b>1.3032</b>	<b>1.3535</b>
<b>Avg</b>	<b>1.8167</b>	<b>1.7703</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 202 / IRB

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1629	.1663
2	.1629	.1663
3	.1629	.1478
4	.1448	.1478
5	.1848	.1478
6	.1848	.1494
7	.1448	.1867
8	.1772	
9	.1949	
10	.1907	.1829
11	.1715	.181
12	.1844	.1463
13	.1372	.1463
14	.1417	.1448
15	.1417	.1646
16	.1865	.2172
17		.181
18	.2195	.197
19	.2195	.1829
20	.2195	.1848
21	.1848	.1848
22	.1848	.1663
23	.1848	.168
24	.1629	.1663
Max	.2195	.2172
Min	.1372	.1448
Avg	.1761	.1694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 203 / Nathvalley

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1946	1.2197
2	1.1584	1.1643
3	1.1584	1.1523
4	1.1584	1.2071
5	1.2803	1.2752
6	1.6263	1.6263
7	1.848	1.8671
8	1.7002	1.6804
9	1.4998	1.5524
10	1.5203	1.6095
11	1.4327	1.5023
12	1.3253	1.3535
13	1.382	1.4266
14	1.448	1.2308
15	1.448	1.2986
16	1.2894	
17		1.3756
18	1.4632	1.6476
19	1.5364	1.4998
20	1.6095	1.848
21	1.5364	1.5708
22	1.4784	1.5708
23	1.4045	1.4937
24	1.267	1.3306
<b>Max</b>	<b>1.848</b>	<b>1.8671</b>
<b>Min</b>	<b>1.1584</b>	<b>1.1523</b>
<b>Avg</b>	<b>1.4246</b>	<b>1.4567</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 205 / Walmi EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0469	.0366
2	.044	.037
3	.0423	.037
4	.0446	.037
5	.0463	.0373
6	.0492	.056
7	.032	.056
8	.0351	
9	.0354	
10	.0549	.0366
11	.0732	.0724
12	.0716	.0732
13	.0526	.0732
14	.0532	.0362
15	.0701	.0549
16	.056	.0543
17		.0362
18	.0366	.0358
19	.0366	.0183
20	.0549	.0554
21	.0549	.0554
22	.0554	.0554
23	.0554	.056
24	.0446	.0554
Max	.0732	.0732
Min	.032	.0183
Avg	.0498	.0484



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044221 / 33/11KV WALMI SS

Feeder No / Name : 206 / Nakshatrawadi

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8779	.9145
2	.8779	.8871
3	.8779	.8871
4	.8779	.924
5	.9979	1.0349
6	1.419	1.3817
7	1.5684	1.531
8	1.4784	
9	1.3169	
10	1.2308	1.2803
11	1.1104	1.1041
12	.9816	1.0566
13	.9313	.9134
14	1.0029	.9313
15	.8954	.9955
16	.9671	.905
17		.9412
18	1.0242	.985
19	1.1523	1.0608
20	1.3169	1.3491
21	1.2567	1.2752
22	1.1827	1.1273
23	1.0349	1.1203
24	.9145	.961
Max	1.5684	1.531
Min	.8779	.8871
Avg	1.0997	1.0712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 201 / 11 KV DEOGIRI VALLEY  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8232	.8232
2	.7858	.7858
3	.7858	.7858
4	.898	.898
5	.9729	.898
6	1.1225	1.16
7	1.16	1.2348
8	1.1225	
9	1.1225	
10		1.0562
11	.9355	1.0562
12	.898	1.0562
13	.8232	
15		.8299
16		.8299
17		.8676
18	.9768	.8606
19	1.0123	.9383
20	1.1635	1.1635
21	1.126	1.1271
22	1.0466	1.0103
23	.898	.9729
24	.8606	.898
Max	1.1635	1.2348
Min	.7858	.7858
Avg	.9755	.9626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 203 / 11 KV PRIYA COLONY  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1225	1.0103
2	1.0851	.9729
3	1.0851	.9729
4	1.2722	1.2722
5	1.4593	1.3471
6	1.5716	1.6464
7	1.5716	1.7961
8	1.4967	
9	1.4967	
10		1.358
11	1.0851	1.358
12	.9729	1.358
15		.9808
16		1.0562
17		1.0562
18	1.1925	1.0477
19	1.2761	1.2761
20	1.6498	1.6397
21	1.5764	1.578
22	1.4967	1.4967
23	1.3471	1.4262
24	1.1974	1.1974
<b>Max</b>	<b>1.6498</b>	<b>1.7961</b>
<b>Min</b>	<b>.9729</b>	<b>.9729</b>
<b>Avg</b>	<b>1.3308</b>	<b>1.2923</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 204 / 11 KV PETHE NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.0103	.7016
2	1.0103	.9729
3	1.0477	.9729
4	1.1225	1.2722
5	1.1974	1.3845
6	1.3471	1.6838
7	1.6838	1.7587
8	1.4967	
9	1.4967	
10		1.4712
11	1.0851	1.358
12	.898	1.2449
15		.9808
16		1.0185
18	1.2321	1.0509
19	1.4161	1.3498
20	1.6924	1.5764
21	1.5764	1.5388
22	1.5013	1.3845
23	1.3471	1.267
24	1.0477	1.0477
Max	1.6924	1.7587
Min	.898	.7016
Avg	1.2894	1.2650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 206 / 11 KV DARGA FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3749	.3749
2	.3374	.3374
3	.3374	.3374
4	.3749	.3374
5	.4124	.4124
6	.4499	.4499
7	.5624	.5624
8	.4874	
9	.4864	
10		.5281
11	.4124	.4904
12	.4124	.415
15		.3772
16		.3772
17		.3772
18	.4884	.4504
19	.2625	.5255
20	.5641	.563
21	.5217	.5239
22	.4879	.4879
23	.4874	.4504
24	.4124	.4124
Max	.5641	.563
Min	.2625	.3374
Avg	.4374	.4395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

CHAWANI S/DN.[578] BU 4578

Substation No/ Name :- 044222 / 33/11 KV PADEGAON

Feeder No / Name : 207 / 11 KV RAMGOPAL NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.15	.15
2	.15	.15
3	.15	.15
4	.1875	.1875
5	.1875	.1875
6	.225	1.1623
7	.3	.2625
8	.225	
9	.225	
10		.1886
11	.15	.1509
12	.15	.1509
15		.1509
16		.1509
17		.1509
18	.1873	.1877
19	.2245	.2252
20	.2625	.2254
21	.2627	.2254
22	.2619	.2627
23	.1875	.2622
24	.15	.15
Max	.3	1.1623
Min	.15	.15
Avg	.2020	.2366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 201 / 11 KV ROSHAN GATE  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.7924	1.8671
2	1.6804	1.7551
3	1.587	1.6804
4	1.643	1.7177
5	1.7551	1.8298
6	1.8858	1.8858
7	1.9791	1.9605
8	2.0538	2.2405
9	2.2405	2.3712
10	.2465	
11	.2614	.2875
12	.2521	.2987
13	.239	.3174
14	.2241	
15	.2241	.2054
16	.2091	.1979
17	2.0911	2.0351
18	2.4272	2.2032
19	2.7073	2.4832
20	2.8193	2.726
21	2.6139	2.6326
22	2.3899	
23	2.1845	2.3339
24	1.9231	2.0165
<b>Max</b>	<b>2.8193</b>	<b>2.726</b>
<b>Min</b>	<b>.2091</b>	<b>.1979</b>
<b>Avg</b>	<b>1.5596</b>	<b>1.6688</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 202 / 11 KV Nizamuddin Feeder Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.4937	1.5684
2	1.4563	1.4937
3	1.4003	1.4003
4	1.4937	1.5123
5	1.6804	1.8298
6	1.8298	2.0725
7	2.0725	2.2592
8	2.2405	2.5019
9	2.3712	2.6139
10	.2502	
11	.2371	.295
12	.2259	.2745
13	.2203	.2203
14	.1998	
15	.1774	.1699
16	.155	.1718
17	1.8671	1.7737
18	2.2592	1.8671
19	2.3152	2.2779
20	2.5019	2.4272
21	2.2405	2.2405
22	2.0538	
23	1.8671	1.9605
24	1.5684	1.6244
Max	2.5019	2.6139
Min	.155	.1699
Avg	1.4241	1.5502



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 203 / 11 KV MONDHA Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.8298	1.8298
2	1.6804	1.6804
3	1.5684	1.587
4	1.7551	1.7924
5	2.0165	2.0165
6	2.0725	2.2779
7	2.4832	2.6699
8	2.6139	2.6699
9	2.6139	2.8006
10	.2726	
11	.2633	.2838
12	.2595	.2689
13	.239	.2558
14	.2241	
15	.2147	.2166
16	.2259	.2072
17	2.4272	2.2779
18	2.726	2.4832
19	2.8567	2.726
20	2.95	2.8567
21	2.5579	2.6139
22	2.3899	
23	2.0911	2.2405
24	1.9044	1.8858
Max	2.95	2.8567
Min	.2147	.2072
Avg	1.6765	1.7924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044052 / 33 KV BAIJIPURA S/STN

Feeder No / Name : 204 / Water Works

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.112	.0747
2	.112	.0747
3	.0747	.056
4	.0747	.0747
5	.056	.0934
6	.0747	.1494
7	.0747	.0934
8	.0747	.0934
9	.0934	.056
10	.0093	
11	.0093	.0093
12	.0093	.0149
13	.0093	.0093
14	.0093	
15	.0187	.0093
16	.0093	.0131
17	.0934	.0924
18	.0934	.1663
19	.112	.0924
20	.1307	.1478
21	.0747	.1478
22	.1307	
23	.0934	.0739
24	.0747	.0747
Max	.1307	.1663
Min	.0093	.0093
Avg	.0677	.0770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 201 / 11 KV Nehru Bhavan

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3048	.3048
2	.3048	.3048
3	.2858	.2667
4	.2858	.2667
5	.2858	.2858
6	.3048	.3048
7	.3048	.3048
8	.2667	.3429
9	.3426	.3807
10	.3807	
11	.3807	.3997
12	.3426	.3997
13	.3426	.4378
14	.3426	
15	.3236	.2855
16	.3018	.2665
17		.3018
18	.1886	.3018
19	.3395	.3772
20	.3772	.3772
21	.3395	.3395
22	.3395	.3772
23	.3429	.381
24	.3429	.3429
Max	.3807	.4378
Min	.1886	.2665
Avg	.3205	.3341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 202 / 11 KV CityChowk Police station Feeder KV- 11 / OUTGOING Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.829	1.9052
2	1.6766	1.7528
3	1.6385	1.6766
4	1.6385	1.6766
5	1.6766	1.9052
6	1.7147	1.9052
7	1.9052	1.9814
8	1.9052	2.1338
9	2.1296	2.3174
10	2.2056	
11	2.4289	2.7243
12	2.5781	2.8
13	2.6513	2.8669
14	2.3577	
15	2.3577	2.2817
16	2.2634	2.1296
17		1.9616
18	2.7161	2.5463
19	3.0178	3.0178
20	3.0178	3.1121
21	2.9424	2.9874
22	2.7349	2.4143
23	2.2862	2.1338
24	1.9052	2.1338
Max	3.0178	3.1121
Min	1.6385	1.6766
Avg	2.2425	2.2893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 203 / 11KV Ganesh colony

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.829	1.9052
2	1.7528	1.7909
3	1.6766	1.7147
4	1.6766	1.7528
5	1.7147	1.829
6	1.7909	2.0576
7	1.9814	2.21
8	2.1338	2.3624
9	2.4338	2.616
10	2.4338	
11	2.5592	2.7621
12	2.5023	2.7404
13	2.2748	2.8
14	2.1676	
15	2.0155	1.9774
16	2.037	1.9014
17		1.9616
18	2.037	2.1125
19	2.2634	2.1125
20	2.6217	2.5652
21	2.3011	2.452
22	2.1125	2.2634
23	2.21	2.21
24	1.9814	2.0576
Max	2.6217	2.8
Min	1.6766	1.7147
Avg	2.1090	2.1889

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 204 / 11 KV ROJABAG FEEDER  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.7621	.7621
2	.6859	.724
3	.6478	.6859
4	.6478	.6859
5	.6859	.8002
6	.7621	.8764
7	.8764	.9145
8	.9145	.9907
9	.8755	.9897
10	.9897	
11	1.0278	1.0278
12	.9897	1.0468
13	.8565	.9897
14	.9136	
15	.9136	.9136
16	.9145	.9136
17		.8676
18	.9054	.9054
19	.9808	.9431
20	1.0185	1.0562
21	.9431	.9511
22	.9054	.9054
23	.8764	.8764
24	.8002	.8002
Max	1.0278	1.0562
Min	.6478	.6859
Avg	.8649	.8921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044218 / 33KV HIMAYAT BAG

Feeder No / Name : 205 / 11 KV Collector Office

HV Express Feeder

Express Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0381	.0381
2	.0381	.0381
3	.0381	.0381
4	.0381	.0381
5	.0381	.0381
6	.0381	
7	.0381	.0381
8	.0381	.0381
9	.0381	
10	.0761	
11	.1142	.1142
12	.1332	.1332
13	.1523	.1332
14	.1523	
15	.1142	.1332
16	.1132	.1332
17		.0943
18	.0377	.0754
19	.0377	.0377
20	.0377	.0377
21	.0377	.0377
22	.0377	.0366
23	.0381	.0381
24	.0381	.0381
Max	.1523	.1332
Min	.0377	.0366
Avg	.0636	.0655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 201 / 11 KV SUREWADI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8501	.7842
2	.8131	.7842
3	.7865	.7468
4	.7762	.7842
5	.8131	.8962
6	.8589	1.0829
7	1.1949	1.1203
8	1.0642	1.0642
9	1.0456	.9335
11	.9808	.8488
12	.8589	
13	.7842	.8131
14	.8215	
15	.8589	.7947
16	.8299	.8131
17	.8402	.8299
18	.8589	.8962
19	1.0082	.8676
20	1.1389	1.0829
21	1.1203	1.0456
22	1.0456	1.094
23	.9709	1.0456
24	.8871	.8215
Max	1.1949	1.1203
Min	.7762	.7468
Avg	.9220	.9119



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 202 / 11kv mayur park

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.7392	.7468
2	.7577	.7095
3	.7392	.7095
4	.7762	.7842
5	.8316	.8962
6	1.1203	1.1203
7	1.2136	1.1949
8	1.0456	1.0829
9	.9522	.8962
11	.7947	.7545
12	.6653	
13	.6722	.6099
14	.7023	
15	.6584	.5914
16	.6767	.6653
17	.7392	.6722
18	.8589	.7468
19	.924	.7842
20	1.0829	.9709
21	1.1949	.9335
22	1.3817	.9896
23	1.2323	.8215
24	.7762	.7468
<b>Max</b>	<b>1.3817</b>	<b>1.1949</b>
<b>Min</b>	<b>.6584</b>	<b>.5914</b>
<b>Avg</b>	<b>.8928</b>	<b>.8299</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 204 / 11kv shivneri feeder  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.9328	.9335
2	.961	.8962
3	.9335	.8962
4	.924	1.0082
5	1.0829	1.1949
6	1.7364	1.7551
7	1.8298	1.9044
8	2.0165	1.9418
9	1.8111	1.7551
11	1.307	1.4335
12	1.2567	
13	1.0829	.9795
14	1.0349	
15	.9709	.8871
16	.9335	.961
17	1.1203	1.0829
18	1.3817	1.2696
19	1.7177	1.5684
20	1.8298	1.7924
21	1.531	1.643
22	1.307	1.3443
23	1.1203	1.1203
24	.9795	1.0082
Max	2.0165	1.9418
Min	.924	.8871
Avg	1.2957	1.3036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044220 / 33KV jadhavwadi s.s

Feeder No / Name : 205 / 11kV Aarti

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.4066	.4108
2	.3696	.3734
3	.3696	.3734
4	.3326	.3361
5	.4066	.4108
6	.5228	.5228
7	.7842	.6722
8	.6908	.7095
9	.5975	.6348
11	.462	.6413
12	.4854	
13	.462	.4481
14	.3326	
15	.3326	.3881
16	.3734	.4066
17	.3361	.4108
18	.4108	.4481
19	.5601	.5601
20	.6348	.6283
21	.5601	.5914
22	.5228	.5228
23	.4481	.4854
24	.4435	.4481
Max	.7842	.7095
Min	.3326	.3361
Avg	.4715	.4963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 201 / 11KV JASWANTPURA

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1622	.1622
2	.1547	.1509
3	.1509	.1471
4	.1509	.1471
5	.1584	.1528
6	.1698	.1754
7	.1867	.2131
8	.2075	
9	.2358	
10		3.0178
11	2.4897	2.8292
12	2.3577	2.8292
13	2.1313	
14	1.9427	
15	1.7353	1.773
16		1.6975
17	1.8298	1.8298
18	2.2779	2.1658
19	2.5086	2.4331
20	2.4272	2.3954
21	2.1845	2.1845
22	.2037	.2018
23	.1943	.1962
24	.1811	.1792
Max	2.5086	3.0178
Min	.1509	.1471
Avg	1.0928	1.2441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 203 / 11 KV AZAD CHOWK

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1283	.1283
2	.1245	.1226
3	.1226	.1226
4	.1226	.1207
5	.1288	.1301
6	.1382	.1622
7	.166	.1962
8	.1811	
9	.2075	
10		2.452
11	1.9993	2.3765
12	1.8296	
13	1.7164	
14	1.5089	
15	1.3769	1.5655
16		1.4335
17		1.5123
18	1.8671	1.9044
19	2.1691	1.8861
20	2.1098	2.0936
21	1.9044	1.7924
22	.1773	.1698
23	.1603	.1622
24	.1415	.1452
Max	2.1691	2.452
Min	.1226	.1207
Avg	.8705	.9724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 044224 / 33KV ROSHAN GATE

Feeder No / Name : 204 / 11KV A'BAD TIMES COLONY  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1415	.1433
2	.1307	.1339
3	.1264	.1264
4	.1264	.1264
5	.1301	.1301
6	.132	.1396
7	.1377	.1566
8	.1509	
9	.1622	
10		2.1125
11	1.8673	2.1879
12	1.905	2.2257
13	1.7164	
14	1.6787	
15	1.5655	1.3203
16		1.6409
17		1.5684
18	1.7364	1.6804
19	1.8861	1.8861
20	1.9791	2.037
21	1.8858	1.8858
22	.1886	.1848
23	.1754	.1848
24	.1566	.1603
Max	1.9791	2.2257
Min	.1264	.1264
Avg	.8561	1.0016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 201 / Jaman Jyoti

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1905	.1524
2	.1905	.1524
3	.1905	.1524
4	.2096	.1715
5	.2477	.2096
6	.381	.3239
7	.4191	.4382
8	.4191	.4001
9	.381	.4001
10	.3429	.362
11	.3048	.3239
12	.3239	.3048
13	.3048	.2477
14	.2667	.2667
15	.2096	.2096
16	.2477	.2477
17	.2477	.2858
18	.3239	.362
19	.2667	.3239
20	.3048	.3239
21	.2477	.0572
22	.1715	.0762
23	.1715	.1334
24	.1905	.1715
Max	.4191	.4382
Min	.1715	.0572
Avg	.2731	.2540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 202 / 11 kv subhedari

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8192	.8192
2	.8192	.8002
3	.7811	.7811
4	.8002	.7811
5	.8383	.8192
6	.8383	.8002
7	.9145	.9335
8	.8764	.8764
9	.8954	.9717
10	.9335	.9526
11	.7811	.9717
12	.743	.9335
13	.9717	1.0098
14	.8383	.8764
15	.8192	.8002
16	.8383	.8192
17	.8573	.7621
18	.9717	.743
19	1.086	.9907
20	1.1241	1.1241
21	1.0288	1.0479
22	.9907	.9907
23	.9526	.9717
24	.8954	.8954
Max	1.1241	1.1241
Min	.743	.743
Avg	.8923	.8947



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 204 / 11 kv Delhi Gate

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.5432	1.5432
2	1.5051	1.5432
3	1.5242	1.5051
4	1.5432	1.6004
5	1.848	1.7909
6	2.4196	2.4577
7	2.6292	2.8578
8	2.6673	2.934
9	2.553	2.8197
10	2.3815	2.6101
11	2.0957	2.3053
12	1.9243	2.0767
13	1.7147	2.0005
14	1.5813	1.6575
15	1.5242	1.5242
16	1.6575	1.5623
17	1.829	
18	2.2672	
19	2.3434	2.4768
20	2.5339	2.6482
21	2.1529	2.2672
22	1.9814	2.1148
23	1.7718	1.8099
24	1.5813	1.5813
Max	2.6673	2.934
Min	1.5051	1.5051
Avg	1.9822	2.0767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 205 / 11 kv WATER WORKS  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.2858	.2858
2	.2858	.2858
3	.2858	.2858
4	.2858	.3048
5	.362	.381
6	.4954	.4954
7	.4954	.4954
8	.5144	.5335
9	.4572	.4954
10	.4382	.4191
11	.4191	.4382
12	.381	.3429
13	.3239	.3429
14	.3048	.3239
15	.2858	.2286
16	.3048	.3239
17	.3429	.362
18	.4001	.3239
19	.5144	.4763
20	.5144	.5144
21	.4382	.4382
22	.381	.4191
23	.3429	.3429
24	.3048	.3048
Max	.5144	.5335
Min	.2858	.2286
Avg	.3818	.3818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 207 / 11 kv Kat kat Gate  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.7718	1.8861
2	1.7337	1.8099
3	1.7147	1.7718
4	1.7718	1.8099
5	1.829	1.9243
6	2.0957	2.1529
7	2.4006	2.6673
8	2.6482	2.8197
9	2.7625	3.1055
10	2.8769	3.2198
11	2.4387	3.0293
12	2.2481	2.8959
13	2.21	2.8769
14	2.0005	2.4958
15	2.2672	2.21
16	2.1338	2.21
17	2.3624	2.2862
18	2.7244	2.4958
19	2.9721	2.8006
20	3.1055	3.0674
21	2.7435	2.8197
22	2.553	2.6482
23	2.2862	2.3434
24	1.9243	2.0576
<b>Max</b>	<b>3.1055</b>	<b>3.2198</b>
<b>Min</b>	<b>1.7147</b>	<b>1.7718</b>
<b>Avg</b>	<b>2.3156</b>	<b>2.4752</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 209 / Bhim Tekdi

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.4289	1.4861
2	1.3908	1.4289
3	1.3908	1.3908
4	1.4289	1.448
5	1.5813	1.6385
6	2.0957	2.1148
7	2.3243	2.4768
8	2.2862	2.4577
9	2.0576	2.3624
10	2.0386	2.2672
11	1.848	1.9624
12	1.6956	1.7718
13	1.4098	1.6004
14	1.3908	1.5432
15	1.4861	1.4289
16	1.467	1.467
17	1.5813	1.5813
18	1.9243	1.6956
19	2.0195	1.8861
20	2.1719	2.0957
21	2.0005	2.0386
22	1.8861	1.8861
23	1.6956	1.7528
24	1.5051	1.5432
<b>Max</b>	<b>2.3243</b>	<b>2.4768</b>
<b>Min</b>	<b>1.3908</b>	<b>1.3908</b>
<b>Avg</b>	<b>1.7544</b>	<b>1.8052</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 210 / Bhagat Singh

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8764	.8954
2	.8764	.8954
3	.8573	.8573
4	.8954	.8954
5	.9907	1.105
6	1.4861	1.6956
7	1.5242	1.5242
8	1.3527	1.3527
9	1.1431	1.1622
10	1.105	.9907
11	.8383	.9335
12	.8002	.8002
13	.8002	.8383
14	.8383	.7811
15	.8192	.8383
16	.5906	.8383
17	.8573	.8383
18	1.086	.9526
19	1.1241	.9907
20	1.4098	1.2765
21	1.3717	1.2574
22	1.2193	1.2003
23	1.0288	1.0669
24	.9145	.9145
Max	1.5242	1.6956
Min	.5906	.7811
Avg	1.0336	1.0375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

SHAHGANJ S/DN.[673] BU 4673

Substation No/ Name :- 047001 / 132 KV HARSUL S\S

Feeder No / Name : 401 / 33 kv cidco

Urban/Sheddable Urban Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	10.4595	10.8596
2	10.1166	10.4024
3	9.9451	10.1166
4	10.3452	10.3452
5	10.6882	11.0311
6	11.1454	12.1742
7	12.6886	13.7174
8	13.6603	15.4893
9	14.7462	16.6896
10	15.2035	17.0896
11	15.2607	17.3754
12	14.9177	17.2611
13	14.0604	
14	13.1459	13.6031
15	12.3457	12.0028
16	12.0028	12.0599
17	12.6315	12.3457
18	14.9177	14.0032
19	15.9465	15.2035
20	16.4038	16.2895
21	14.9177	14.3462
22	14.1175	13.7174
23	12.9173	12.8029
24	11.5455	11.6598
Max	16.4038	17.3754
Min	9.9451	10.1166
Avg	13.0887	13.5037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 004801 / 220 KV PADEGAON SUB STATION

Feeder No / Name : 710 / 132 KV SOUTH ASIA TYRE EHV Express Feeder  
 FEEDER Feeder KV- 132 /  
 OUTGOING

DATE	30-JUN-17
HR	Load (MW)
1	8.2305
2	8.2305
3	8.9163
4	8.2305
5	8.2305
6	8.2305
7	8.0018
8	7.7732
9	7.316
10	9.3736
11	7.316
12	7.0873
13	7.7732
14	7.5446
15	7.5446
16	12.8029
17	8.2305
18	8.0018
19	8.0018
21	7.7732
22	8.2305
23	14.4033
24	12.8029
Max	14.4033
Min	7.0873
Avg	8.6977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 201 / 11 KV E+H  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.7816	2.934
2	3.0102	2.8959
3	2.9721	2.8006
4	3.0102	2.6673
5	3.0102	2.5911
6	2.6863	2.4387
7	2.5911	2.2862
8	2.7435	2.3624
11	4.6677	2.2672
12	3.2388	2.1148
13	3.5627	2.0576
14	4.4772	
15	.8192	2.0576
16		2.0195
17		2.191
18	3.2579	2.0195
19	2.7244	2.0005
20	3.3341	2.0005
21		2.0576
22		2.0005
23	3.2007	2.0195
24	2.5339	2.3815
Max	4.6677	2.934
Min	.8192	2.0005
Avg	3.0345	2.2935



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 202 / 11 KV GARWARE  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.4387	2.4768
2	2.5339	2.4006
3	2.4577	2.2862
4	2.4006	2.2862
5	2.3053	2.3053
6	2.5339	1.8671
7	2.5911	1.7528
8	3.0674	1.7718
11	3.315	1.848
12	3.1626	1.6766
13	3.3341	1.6766
14	3.4294	
15	3.2388	1.7909
16		1.7718
17		1.7528
18	3.2007	1.6766
19	2.4387	1.4861
20	2.7625	1.7528
21		1.6194
22		1.6194
23	2.7244	1.6194
24	2.4958	2.4768
<b>Max</b>	<b>3.4294</b>	<b>2.4768</b>
<b>Min</b>	<b>2.3053</b>	<b>1.4861</b>
<b>Avg</b>	<b>2.8017</b>	<b>1.9007</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 203 / 11 KV KESONA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.4861	1.3908
2	1.4861	1.3336
3	1.467	1.2955
4	1.448	1.2955
5	1.4098	1.3336
6	1.448	1.2955
7	1.467	1.2003
8	2.1338	1.2955
11	2.1148	
12	2.0767	.8764
13	1.8861	
14	2.5911	
15	2.2862	1.086
16		1.0479
17		1.2384
18	2.0386	1.105
19	1.829	.9717
20	1.4861	1.1431
21		1.105
22		1.105
23	1.5813	1.0479
24	1.3527	1.4098
<b>Max</b>	<b>2.5911</b>	<b>1.4098</b>
<b>Min</b>	<b>1.3527</b>	<b>.8764</b>
<b>Avg</b>	<b>1.7549</b>	<b>1.1882</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 204 / 11 KV HIRA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.5339	2.1148
2	2.5339	1.7909
3	2.4387	1.6766
4	2.2481	1.7528
5	1.7528	1.9243
6	1.829	1.7909
7	1.8671	1.5623
8	2.3053	1.4861
11	3.2388	1.7337
12	2.5149	1.6004
13	2.553	
14	2.8197	
15	2.572	1.5242
16		1.6575
17		1.7147
18	2.934	1.4098
19	2.2672	1.467
20	1.829	1.1431
21		1.1812
22		1.3146
23	1.7528	1.3146
24	2.1148	2.0386
<b>Max</b>	<b>3.2388</b>	<b>2.1148</b>
<b>Min</b>	<b>1.7528</b>	<b>1.1431</b>
<b>Avg</b>	<b>2.3392</b>	<b>1.6099</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 205 / GANGA MAI I  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0381	.0381
2	.0381	.0191
3	.0381	.0191
4	.0381	.0191
5	.0381	.0191
6	.0381	.0191
7	.0191	.0191
8	.0762	.0381
11	.0953	.0572
12	.0762	
13	.0572	
14	.0953	
15	.0953	.0572
16		.0381
17		.0381
18	.0762	.0191
19	.0572	.0191
20	.0381	.0191
21		.0191
22		.0191
23	.0381	.0381
24	.0572	.0381
Max	.0953	.0572
Min	.0191	.0191
Avg	.0561	.0291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 207 / 11 KV ADEEP

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.9052	1.9433
2	1.8861	1.9243
3	1.8671	1.9243
4	1.8861	1.9243
5	1.8671	1.9433
6	2.3053	1.9243
7	2.4958	1.9433
8	3.0102	2.0195
11	3.5818	2.1148
12	3.2579	2.2862
13	3.3532	
14	3.2579	
15	2.8959	2.0386
16		2.0767
17		2.0005
18	3.0674	2.0005
19	2.4006	1.6766
20	2.6292	1.8861
21		1.8861
22		1.9433
23	2.3243	1.6194
24	1.8861	1.8861
<b>Max</b>	<b>3.5818</b>	<b>2.2862</b>
<b>Min</b>	<b>1.8671</b>	<b>1.6194</b>
<b>Avg</b>	<b>2.5487</b>	<b>1.9481</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 208 / 11 KV RUCHA EXP

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.3336	.6668
2	.743	.724
3	.724	.7811
4	.743	.7621
5	.743	.724
6	.7811	.7621
7	.8002	.8002
8	.9145	.8383
11	.9526	.6859
12	.8764	1.0669
13	1.0669	
14	1.1812	
15	1.1431	1.0669
16		.8383
17		.8573
18	1.0479	.724
19	.8383	.6478
20	.8383	.6859
21		.8954
22		.5716
23	.9717	.724
24	.724	.6478
Max	1.3336	1.0669
Min	.724	.5716
Avg	.9124	.7735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 413 / 33KV Mylan

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.915	2.8006
2	2.8006	2.8006
3	2.8006	2.8578
4	2.7435	2.8578
5	2.7435	2.915
6	2.8006	2.8578
7	2.8006	2.6863
8	2.9721	2.8578
11	3.2007	2.8578
12	3.1436	3.0864
13	3.0864	
14	2.9721	
15	3.0864	2.8578
16		2.9721
17		2.9721
18	2.9721	2.8578
19	3.0293	2.8578
20	3.0864	2.8578
21		2.8578
22		2.7435
23	2.915	2.6863
24	2.9721	2.9721
Max	3.2007	3.0864
Min	2.7435	2.6863
Avg	2.9467	2.8607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 414 / 33 KV Varroc ( M-191/3 )

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.6292	2.6292
2	2.9721	2.8006
3	2.9721	3.0864
4	3.0864	2.8578
5	3.0864	2.6292
6	2.7435	2.4006
7	2.0576	2.4006
8	3.7151	2.7435
11	6.1728	5.8299
12	5.3727	2.5149
13	6.0585	
14	3.0864	
15	5.3727	4.5725
16		5.2584
17		5.487
18	4.4582	3.4294
19	2.5149	2.7435
20	3.2007	2.7435
21		2.5149
22		2.5149
23	2.6292	2.4006
24	2.2862	2.4006
Max	6.1728	5.8299
Min	2.0576	2.4006
Avg	3.5786	3.1979



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044213 / 33 KV L SECTOR WALUJ

Feeder No / Name : 415 / 33 KV Endurance ( L-6)

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.6575	1.2574
2	1.6004	1.3717
3	1.6004	1.4289
4	1.6575	1.3717
5	1.6575	1.2574
6	1.6004	1.3717
7	1.6004	1.4289
8	1.8861	1.5432
11	1.8861	1.1431
12	1.4861	1.1431
13	2.0576	
14	2.1719	
15	2.0576	1.1431
16		.8573
17		.743
18	1.829	.6859
19	1.5432	.743
20	1.8861	.8573
21		.743
22		.8002
23	1.5432	.8002
24	1.6004	1.3146
Max	2.1719	1.5432
Min	1.4861	.6859
Avg	1.7401	1.1002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 201 / KAIZEN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.2574	1.1431
2	1.2193	1.1812
3	1.2574	1.105
4	1.2193	1.1431
5	1.2193	1.2193
6	1.1812	1.1812
7	1.086	1.0669
8	1.3336	1.1431
9	1.7528	1.1431
11	1.8671	1.3908
12	1.6385	1.105
13		1.086
14	1.6766	
15	1.6194	1.3336
16	1.7528	1.3908
17		1.3717
18	1.7528	1.2955
19	1.5623	1.105
20	1.4289	1.3146
21	1.448	1.2574
22	1.4098	
23	1.3717	1.1622
24	1.2574	1.3336
Max	1.8671	1.3908
Min	1.086	1.0669
Avg	1.4434	1.2130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 202 / MDS ALLOYS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1905	.2286
2	.1715	.1905
3	.1905	.2286
4	.1715	.2096
5	.1715	.1905
6	.1905	.2096
7	.1905	.1905
8	.2858	.2096
9	.362	.2286
11	.4191	.2096
12	.3429	.1905
13		.2096
14	.381	
15	.381	.2096
16	.4191	.2286
17		.2096
18	.4191	.1905
19	.1905	.2096
20	.2096	.2096
21	.1905	.2286
22	.2096	
23	.1905	.2286
24	.1715	.2286
Max	.4191	.2286
Min	.1715	.1905
Avg	.2595	.2114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 203 / NATH FORGING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.9526	.8383
2	.9907	.8002
3	.9526	.7621
4	.9145	.8002
5	.8764	.8383
6	.8002	.724
7	.9145	.6478
8	.9335	.5716
9	1.0669	.6097
11	1.2955	.6668
12	1.0669	.743
13		.6668
14	1.1431	
15	1.2384	.724
16		.743
17		.6097
18	1.0669	.4763
19	.9907	.4763
20	.8573	.5525
21	.7621	.4763
22	.724	
23	.6668	.4954
24	.9907	.724
Max	1.2955	.8383
Min	.6668	.4763
Avg	.9602	.6641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 204 / FOSTERS

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.3336	1.2193
2	1.3717	1.1812
3	1.3336	1.2574
4	1.2955	1.1812
5	1.2574	1.2193
6	1.1431	1.1431
7	1.105	1.105
8	1.6766	1.0669
9	1.8671	1.3717
11	1.829	1.2955
12	1.8671	1.1431
13		1.0669
14	1.829	
15	1.9052	1.2574
16		1.2955
17		1.2193
18	1.8099	1.105
19	1.3717	.9907
20	1.1431	.9526
21	1.105	.8764
22	1.1431	
23	1.0669	1.0669
24	1.3717	1.1431
Max	1.9052	1.3717
Min	1.0669	.8764
Avg	1.4413	1.1504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 205 / VARSA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8764	.8764
2	.9145	.9145
3	.8764	.8383
4	.8383	.9145
5	.9145	.8764
6	.9526	.8002
7	.8764	.724
8	1.1812	.8573
9	1.2574	.7621
11	1.448	.8002
12		.8383
13		.8002
14	1.3717	
15	1.3336	.8002
16		.8383
17		.7621
18	1.2955	.7621
19	1.1812	.7621
20	.9907	.8002
21	1.0288	.7621
22	.9907	
23	.9526	.743
24	.9145	.9145
Max	1.448	.9145
Min	.8383	.724
Avg	1.0629	.8165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044215 / 33/11 KV M-SECTOR WALUJ

Feeder No / Name : 206 / RUBICON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6478	.4954
2	.6859	.5335
3	.6097	.4572
4	.6097	.4954
5	.6478	.5335
6	.5906	.4572
7	.4572	.381
8	1.0669	.6097
9	1.086	.6097
11	.8764	.6859
13		.8192
14	.8764	
15	.7621	.8002
16		.8383
17		.7621
18	.8764	.7811
19	.4954	.4763
20	.6097	.5716
21	.6478	.724
22	.6668	
23	.6859	.743
24	.6859	.6478
<b>Max</b>	<b>1.086</b>	<b>.8383</b>
<b>Min</b>	<b>.4572</b>	<b>.381</b>
<b>Avg</b>	<b>.7150</b>	<b>.6211</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 201 / 11KV TTK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.9052	1.829
2	1.9052	1.7147
3	1.829	1.7909
4	1.829	1.6766
5	1.9052	1.6385
6	1.9052	1.6004
7	1.9052	1.5242
8	2.4768	1.6004
9	2.8959	
10	3.4294	
15		1.6766
16		1.448
17	3.4294	1.5242
18	2.8959	1.5242
19	2.5149	1.5242
20	1.9814	1.5242
21	1.9052	1.5242
22	1.9052	
23	1.9052	1.448
24	1.9052	1.9052
Max	3.4294	1.9052
Min	1.829	1.448
Avg	2.2460	1.6161



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 202 / 11KV G Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.0288	1.0288
2	1.0288	.9907
3	.9907	.9907
4	.9907	1.0288
5	.9526	.9526
6	.9526	.9526
7	.9526	.9526
8	1.0669	.9145
9	1.2574	
10	1.3336	
15		.7621
16		.724
17	1.5242	.724
18	1.6766	.7621
19	1.1431	.724
20	.9907	.8002
21	.9907	.9145
22	.9526	
23	1.0288	.8764
24	1.0669	1.1431
Max	1.6766	1.1431
Min	.9526	.724
Avg	1.1071	.8966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 203 / Satyam

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6097	.6287
2	.6097	.6287
3	.5716	.6859
4	.5716	.6287
5	.5716	.6859
6	.6097	.6287
7	.6097	.5716
8	.9145	.5335
9	1.1812	
10	1.2574	
15		.4572
16		.4191
17	1.1431	.4191
18	.9907	.4572
19	.9526	.4191
20	.8383	.4572
21	.6478	.4572
22	.6859	
23	.6859	.381
24	.6097	.6287
Max	1.2574	.6859
Min	.5716	.381
Avg	.7812	.5346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 204 / Niton

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8002	.8002
2	.7621	.8002
3	.7621	.8383
4	.7621	.8002
5	.724	.8002
6	.724	.7621
7	.724	.6859
8	.8764	.8002
9	1.1812	
10	1.3336	
14		.6859
15		.8002
16		.6478
17	1.3717	.8002
18	1.2574	.724
19	1.1431	.6478
20	1.0669	.724
21	.9526	.7621
22	.8383	
23	.8383	.7621
24	.8383	.8002
Max	1.3717	.8383
Min	.724	.6478
Avg	.9420	.7579

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 205 / 11KV E Sector (LIP)  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.5335	.5335
2	.5335	.5335
3	.5716	.5335
4	.5716	.5335
5	.6097	.5335
6	.6097	.4954
7	.5716	.4572
8	.6859	.4191
9	.7621	
14		.5335
15		.4572
16		.4572
17	.8764	.4572
18	.9145	.4572
19	.7621	.4572
20	.6859	.4572
21	.6097	.4572
22	.6097	
23	.6097	.4572
24	.5335	.6097
Max	.9145	.6097
Min	.5335	.4191
Avg	.6500	.4911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 206 / 11KV Ramnani

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.9907	.9145
2	.9907	.8764
3	.9526	.8764
4	.9526	.8383
5	.9526	.8764
6	.9907	.7621
7	.9907	.6097
8	1.0669	
9	1.3717	
16		.5335
17	1.3336	.6478
18	1.2193	.6859
19	1.1431	.6478
20	.9907	.8383
21	.8383	.6097
22	.9145	
23	.9145	.6859
24	.9907	.9145
<b>Max</b>	<b>1.3717</b>	<b>.9145</b>
<b>Min</b>	<b>.8383</b>	<b>.5335</b>
<b>Avg</b>	<b>1.0355</b>	<b>.7545</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 207 / IPCA EXPRESS FEEDER

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.6766	1.6385
2	1.6766	1.6766
3	1.6385	1.6004
4	1.6004	1.6385
5	1.6004	1.6385
6	1.5242	1.6004
7	1.6004	1.6004
8	1.6766	1.7528
9	1.7147	
10	1.7909	
14		.2667
15		1.7528
16		1.829
17	1.829	1.7147
18	1.829	1.6766
19	1.829	1.6004
20	1.829	1.6004
21	1.829	.1524
22	1.6766	
23	1.6385	1.6766
24	1.6766	1.6004
<b>Max</b>	<b>1.829</b>	<b>1.829</b>
<b>Min</b>	<b>1.5242</b>	<b>.1524</b>
<b>Avg</b>	<b>1.702</b>	<b>1.5009</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 208 / 11 KV NRB EXP.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1905	.1905
2	.1905	.1524
3	.1524	.1524
4	.1524	.1524
5	.1524	.1524
6	.1524	.1143
7	.1524	.1524
8	.2286	.1715
9	.3048	
10	.2667	
14		.2286
15		.2286
16		.1905
17	.3048	.1905
18	.3048	.1524
19	.2667	.1524
20	.2286	.1905
21	.2286	.1524
22	.2667	
23	.2477	.1524
24	.1905	.1905
Max	.3048	.2286
Min	.1524	.1143
Avg	.2212	.1704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 209 / 11 KV Speciality Polyfilm  
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1905	.2477
2	.1905	.2477
3	.1524	.2667
4	.1524	.2477
5	.1905	.2286
6	.1524	.2286
7	.1524	.2286
8	.2286	.2477
9	.3048	
14		.2286
15		.1524
16		.2286
17	.2667	.1905
18	.2667	.1524
19	.3048	.1524
20	.3429	.1524
21	.1905	.1524
22	.2667	
23	.2667	.1905
24	.1905	.2477
Max	.3429	.2667
Min	.1524	.1524
Avg	.2241	.2106



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 210 / 11 KV Tata Tele Services HV Express Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0953	.0953
2	.0953	.0953
3	.0953	.0953
4	.0953	.0953
5	.0953	.0953
6	.0953	.0953
7	.0953	.0953
8	.0953	.0953
9	.0953	
10	.0953	
14		.0762
15		.0953
16		.0953
17	.0953	.0953
18	.0953	.0953
19	.0953	.0953
20	.0953	.0953
21	.0953	.0953
22	.0953	
23	.0953	.0953
24	.0953	.0953
Max	.0953	.0953
Min	.0953	.0762
Avg	.0953	.0942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044216 / 33KV E SECTOR WALUJ

Feeder No / Name : 401 / NEW ENDURANCE EXP.

HV Express Feeder

FEEDER(E-92 Feeder KV- 33 /  
OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6859	.5716
2	.6859	.3429
3	.5716	.3429
4	.5716	.3429
5	.5716	.2858
6	.6287	.2858
7	.6287	.2858
8	.8573	.3429
9	1.0288	
14		.1715
15		.3429
16		.4001
17	.9145	.4572
18	.8573	.2286
19	.8002	.2858
20	.6859	.2286
21	.6287	.2286
22	.6859	
23	.6859	.3429
24	.6859	.6287
Max	1.0288	.6287
Min	.5716	.1715
Avg	.7161	.3398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 201 / Indian Tool  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.2193	1.4098
2	1.1812	1.3146
3	1.1431	1.2193
4	1.105	1.1622
5	1.105	1.086
6	1.0669	.9907
7	1.105	.8573
8	1.4098	1.1431
9	1.7909	
10	1.9052	
11	1.7528	1.0669
12	1.4098	1.0669
13	1.7528	1.2574
14	1.9052	
15		1.1812
16		1.0288
17		1.105
18	1.5623	1.0288
19	1.448	.9526
20	1.2384	.8383
21	1.3527	.8764
22	1.3908	.9526
23	1.448	1.0669
24	1.2574	1.2574
Max	1.9052	1.4098
Min	1.0669	.8383
Avg	1.4071	1.0887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 202 / D Sector

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6097	.6478
2	.5716	.6478
3	.5716	.6287
4	.5716	.6287
5	.5335	.6478
6	.5335	.6478
7	.6859	.6287
8	1.2193	
9	1.6004	.6287
10	1.5242	
11	1.6004	.6097
12	1.5242	.6097
13	1.5242	.5335
14	1.5242	
15		.6097
16		.5335
17		.5335
18	1.5242	.4572
19	.8383	.4572
20	.743	.4572
21	.6859	.4572
22	.6859	.4572
23	.6859	.4572
24	.6097	.5906
Max	1.6004	.6478
Min	.5335	.4572
Avg	.9699	.5652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 203 / RKHWAL INDUSTRIES  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8383	.8002
2	.8383	.7621
3	.7621	.7049
4	.7621	.7049
5	.7621	.6859
6	.7621	.6668
7	.8002	.724
8	.8383	.6859
9	1.0669	
10	1.2574	
11	1.0669	.7621
12	1.3336	.7621
13	1.2955	.8764
14	1.2574	
16		.7621
17		.724
18	1.2193	.8002
19	.8002	.724
20	.8383	.6478
21	.8002	.6478
22	.8002	.6478
23	.8002	.6478
24	.8764	.8764
Max	1.3336	.8764
Min	.7621	.6478
Avg	.9417	.7307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 204 / 11 KV AURANGABAD ROTOPLAST SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.724	.6097
2	.724	.6097
3	.6859	.5906
4	.6859	.6097
5	.724	.6097
6	.724	.6097
7	.7621	.6478
8	.7621	.7049
9	1.105	
11	1.5242	.9526
12	1.4098	.9145
13	1.3717	.8383
14	1.3336	
15		.9526
16		.9907
17		.8383
18	1.1431	.7621
19	.8383	.7621
20	.8383	.6097
21	.7621	.6097
22	.6859	.5716
23	.6478	.4954
24	.724	.6478
Max	1.5242	.9907
Min	.6478	.4954
Avg	.9088	.7113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 205 / 11 KV HVDS PADHARPUR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.5914	.5658
2		.5658
3	.5914	.5658
4	.5914	.5658
5	.5914	.5847
6	.5914	.6224
7	.5544	.5975
8	.5544	.5601
9	.5914	
11	.5853	.6219
12	.5487	.5853
13	.5487	.5487
14	.5121	
15		.5121
16		.5487
17		.5544
18	.5975	.5914
19	.5975	.6653
20	.7468	.7023
21	.6722	.6653
22	.6535	.6283
23	.6478	.6283
24	.5914	.5847
<b>Max</b>	<b>.7468</b>	<b>.7023</b>
<b>Min</b>	<b>.5121</b>	<b>.5121</b>
<b>Avg</b>	<b>.5978</b>	<b>.5936</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 206 / Tarraco  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.7621	.743
2	.7621	.743
3	.7621	.743
4	.724	.724
5	.724	.724
6	.724	.7049
7	.7621	.6287
8	.9526	.724
9	1.448	
11	1.5242	1.1431
12	1.0288	.724
13	1.2574	.8383
14	1.3336	
15		.6859
16		.9526
17		.6478
18	1.1431	.5716
19	.8002	.5716
20	.9145	.4191
21	.8002	.4954
22	.8002	.5335
23	.8002	.5716
24	.8002	.743
Max	1.5242	1.1431
Min	.724	.4191
Avg	.9412	.6968



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 044217 / 33 KV D SECTOR WALUJ

Feeder No / Name : 207 / 11 KV Water Works Express Only one consumer of WW with HT-IV  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.5716	.8764
2	.6478	.9145
3	.724	.9526
4	.8002	.9907
5	.8383	.9907
6	.8954	.9907
7	.9526	.9717
8	.9907	.9907
9	1.0098	
11	.8383	1.0098
12	.9907	.5335
13	.9907	.9907
14	.9907	
15		.9335
16		.9526
17		.9717
18	.9526	.6668
19	.8954	.6668
20	.8954	.5335
21	.8954	.4572
22	.8954	.381
23	.8954	.3429
24	.5716	.8764
Max	1.0098	1.0098
Min	.5716	.3429
Avg	.8621	.8093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 202 / 11 KV NIPUN  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		1.3908
2		1.3908
3		1.3908
4		1.3717
5		1.3908
6		1.3908
7		1.4289
8		1.2955
9		1.3146
10		1.3527
11		1.467
12		1.448
13		1.3336
14	2.2291	1.448
15	2.2291	1.3336
16	2.3243	1.2574
17	2.1148	1.448
18	2.0957	1.2765
19	1.5623	1.3908
20	1.4861	1.3908
21	1.448	1.4098
22	1.4098	1.4098
23	1.4098	1.4098
24		1.3908
Max	2.3243	1.467
Min	1.4098	1.2574
Avg	1.8309	1.3805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 203 / 11 KV VIJAY CO-POLYMER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		1.6194
2		1.5813
3		1.6194
4		1.6194
5		1.5813
6		1.6766
7		1.6194
8		1.6385
9		1.7909
10		1.9814
11		2.2672
12		2.0386
13		2.0005
14	2.7244	2.0195
15	2.7054	1.9814
16	3.0102	1.9243
17	2.7244	1.8671
18	2.5149	1.7718
19	1.9814	1.6385
20	1.7337	1.6956
21	1.7909	1.6385
22	1.6385	1.5813
23	1.6766	1.5623
24		1.6194
Max	3.0102	2.2672
Min	1.6385	1.5623
Avg	2.2500	1.7639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 204 / 11 KV GUPTA CONCOST  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		2.21
2		2.21
3		2.191
4		2.191
5		2.21
6		2.2291
7		1.8099
8		1.5051
9	2.5911	1.5051
10	2.9721	1.6956
11	2.9912	1.6956
12	2.5339	1.6766
13	2.6292	1.9052
14	3.4103	1.9243
15	2.8197	1.8671
16	2.8197	1.6766
17	3.2007	1.6766
18	3.1436	1.5242
19	2.8578	1.4861
20	1.829	1.4861
21	2.3815	1.3908
22	2.7244	1.5242
23	2.4387	1.6766
24		2.21
<b>Max</b>	<b>3.4103</b>	<b>2.2291</b>
<b>Min</b>	<b>1.829</b>	<b>1.3908</b>
<b>Avg</b>	<b>2.7562</b>	<b>1.8115</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 206 / 11 KV BIRLA ERICSION SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		2.2481
2		1.9052
3		2.0005
4		2.0386
5		1.9052
6		2.0195
7		1.7528
8		2.3624
9		2.2672
10		2.9912
11		2.915
12		2.1529
13		2.9531
14	2.4958	2.6292
15	3.3341	2.5339
16	3.0864	2.3243
17	3.2769	2.2862
18	3.2769	2.3815
19	2.4577	1.8099
20	2.2291	1.9243
21	2.21	1.9243
22	2.0576	1.8861
23	2.1338	1.9052
24		2.0386
Max	3.3341	2.9912
Min	2.0576	1.7528
Avg	2.6558	2.2148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 207 / 11 KV DIPER INDIA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		2.0576
2		2.0957
3		2.0005
4		2.1338
5		1.8671
6		2.1338
7		1.6766
8		1.9814
9		2.1148
10		1.9814
11		1.9433
12		1.9433
13	2.8578	1.9624
14	2.934	1.848
15	2.8387	1.8671
16	2.9531	1.7718
17	2.7054	1.829
18	2.7244	1.7718
19	2.5339	1.7337
20	2.6673	1.5432
21	2.4577	1.467
22	2.3053	1.467
23	2.4387	1.3146
24		2.0386
Max	2.9531	2.1338
Min	2.3053	1.3146
Avg	2.6742	1.8560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 208 / 11 KV ARIAN ORGO.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		1.5432
2		1.467
3		1.3908
4		1.5242
5		1.467
6		1.448
7		1.5242
8		1.5051
9		1.6004
10		1.7147
11		1.7147
12		1.448
13		1.6385
14	2.8578	1.6385
15	2.553	1.5242
16	2.3053	1.4861
17	2.1719	1.5051
18	1.9243	1.3908
19	1.3717	1.5623
20	1.7909	1.5242
21	2.0386	1.467
22	1.6575	1.5242
23	1.829	1.448
24		1.5623
Max	2.8578	1.7147
Min	1.3717	1.3908
Avg	2.05	1.5258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 211 / 11 KV RESIDENTAIL Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.4577	2.7244
2	2.4006	2.7054
3	2.4006	2.7054
4	2.4006	2.8578
5	2.3815	2.8578
6	2.6673	2.8769
7	2.7435	2.6482
8	2.5149	2.553
9	2.3624	2.4768
10	2.4196	2.4006
11	2.572	2.4196
12	2.4387	2.3815
13	2.3243	2.4958
14	2.553	2.4768
15		2.4577
16	2.553	2.5339
17	2.572	2.5911
18	2.5339	2.6292
19	2.5149	2.8578
20	2.8578	3.0483
21	3.3341	3.4484
22	3.2198	3.2579
23	2.9721	3.0674
24	2.5911	2.7244
Max	3.3341	3.4484
Min	2.3243	2.3815
Avg	2.5994	2.7165



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 212 / 11KV WALUJ MAHANAGAR Urban/Sheddable Urban Feeder  
 FEEDER Feeder KV- 11 /  
 OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.5716	.5906
2	.5525	.5906
3	.5525	.5716
4	.5525	.5525
5	.5525	.5716
6	.6287	.6668
7	.5716	.6287
8	.5716	.5525
9	.5144	.5906
10	.4382	.5335
11	.4572	.4572
12	.4382	.4382
13	.4572	.4763
14	.4572	.4763
15	.4763	.4763
16	.4954	.4954
17	.5144	.4954
18	.5144	.4763
19	.5144	.4954
20	.7049	.6478
21	.7049	.724
22	.724	.5525
23	.6478	.6668
24	.5906	.5906
Max	.724	.724
Min	.4382	.4382
Avg	.5501	.5549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 404 / Cosmo Films OLD

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		2.7435
2		2.8006
3		2.7435
4		2.7435
5		2.572
6		7.316
7		1.6575
8		2.5149
9		2.4006
10		2.6292
11		2.6863
12		2.6292
13		1.8861
14	2.6292	2.6292
15	3.2007	2.572
16	3.2579	2.7435
17	3.315	2.6863
18	2.9721	2.5149
19	2.2862	1.8861
20	3.4865	1.829
21	3.0864	2.915
22	3.658	2.5149
23	3.0864	2.5149
24		3.4865
Max	3.658	7.316
Min	2.2862	1.6575
Avg	3.0978	2.7340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 406 / E SECTOR FEEDER

HV Non-Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	9.5451	9.3164
2	9.6594	9.0878
3	9.3164	8.8592
4	8.9163	8.1733
5	8.9163	8.4591
6	9.0878	8.4019
7	8.9735	7.316
8	11.2026	7.8875
9	13.2602	7.8875
10	13.9461	7.8875
11	15.032	7.8875
12	13.6603	7.8875
13	13.0316	7.8875
14	14.3462	3.2007
15	14.8034	6.7444
16	14.4033	7.316
17	14.8606	7.4874
18	13.9461	7.316
19	11.6598	6.9159
20	11.6598	7.1445
21	9.888	6.973
22	9.8308	6.973
23	9.8308	7.0873
24	9.5451	9.4879
<b>Max</b>	<b>15.032</b>	<b>9.4879</b>
<b>Min</b>	<b>8.9163</b>	<b>3.2007</b>
<b>Avg</b>	<b>11.6384</b>	<b>7.6494</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 407 / NEW COSMO EXPREES FEEDER EHV Express Feeder  
Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		5.3155
2		5.144
3		5.2012
4		5.2012
5		5.6584
6		5.6584
7		5.3727
8		5.487
9		5.6584
10		5.3155
11		4.9154
12		5.3155
13		5.3155
14	5.9442	5.3155
15	5.7728	5.2012
16	5.8871	5.3727
17	5.9442	5.0869
18	5.8299	5.2012
19	5.487	5.7728
20	5.6584	5.6584
21	5.4298	5.6584
22	5.144	5.6013
23	4.9154	5.6013
24		5.2584
Max	5.9442	5.7728
Min	4.9154	4.9154
Avg	5.6013	5.3870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 408 / 33 KV D Sector

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.6863	2.6292
2	2.3434	2.4006
3	2.4577	2.3434
4	2.4006	2.2862
5	2.4006	2.2862
6	2.5149	2.2862
7	3.315	2.1719
8	3.315	2.4577
9	3.9438	2.8578
10	4.3439	2.915
11	4.5153	2.9721
12	4.0009	2.6292
13	3.9438	2.8006
14	4.2295	2.8578
15	4.1724	2.4577
16	4.0581	2.8006
17	4.0581	2.7435
18	3.7723	2.2291
19	2.9721	2.0005
20	2.8578	2.0576
21	2.915	1.9433
22	2.6863	1.829
23	2.7435	2.0005
24	2.5149	2.5149
<b>Max</b>	<b>4.5153</b>	<b>2.9721</b>
<b>Min</b>	<b>2.3434</b>	<b>1.829</b>
<b>Avg</b>	<b>3.2984</b>	<b>2.4363</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 409 / 33 KV BKT EXP. FEEDER

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		2.9721
2		2.8578
3		2.8578
4		2.8578
5		2.9721
6		2.9721
7		2.1719
8		2.8578
9		2.8578
10		1.7147
11		1.829
12		1.7147
13		1.829
14	3.315	1.7147
15	2.2862	1.7147
16	2.9721	1.9433
17	2.9721	2.4006
18	2.8578	1.829
19	2.2862	2.2862
20	2.0576	2.1719
21	2.8578	1.9433
22	2.9721	2.0576
23	2.9721	1.9433
24		2.9721
Max	3.315	2.9721
Min	2.0576	1.7147
Avg	2.7549	2.3101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 410 / NEW ENDURANCE (B-2) EXP. HV Express Feeder  
FEEDE Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		.8573
2		.8573
3		.8002
4		.8002
5		.743
6		.743
7		.0572
8		.0572
9		.0572
10		.0572
11		.0572
12		.0572
13		.0572
14	1.0288	.0572
15	.8002	.0572
16	.9145	.0572
17	.9145	.0572
18	.8573	.0572
19	.8573	.0572
20	.743	.0572
21	.8002	.0572
22	.8573	.0572
23	.8573	.0572
24		.8573
Max	1.0288	.8573
Min	.743	.0572
Avg	.8630	.2763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 703 / 132 KV BAJAJ CKT-1 FEEDER EHV Express Feeder  
Feeder KV- 132 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.0576	2.0576
2	1.829	1.829
3	1.829	1.829
4	2.0576	1.829
5	1.829	1.829
6	2.0576	2.0576
7	4.1152	
8	4.1152	3.4294
9	4.3439	3.2007
10	4.1152	3.4294
11	2.9721	2.7435
12	4.1152	3.2007
13	4.1152	3.2007
14	4.3439	3.2007
15	3.8866	2.9721
16	4.1152	
17	3.8866	
18	3.658	
19	3.658	
20	2.9721	
21	3.658	
22	3.658	
23	3.2007	
24	2.9721	3.2007
Max	4.3439	3.4294
Min	1.829	1.829
Avg	3.3150	2.6673



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 047009 / 132 KV SUB STATION WALUJ

Feeder No / Name : 704 / 132 KV BAJAJ CKT-2 FEEDER

EHV Express Feeder

Feeder KV- 132 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.829	1.829
2	1.6004	1.6004
3	1.6004	1.6004
4	1.6004	1.6004
5	1.6004	1.6004
6	1.829	1.829
7	3.8866	3.2007
8	3.8866	3.2007
9	3.8866	2.9721
10	3.8866	3.2007
11	2.7435	2.5149
12	3.8866	3.2007
13	3.658	2.9721
14	4.1152	
15	3.658	
16	3.8866	
17	3.658	
18	3.4294	
19	3.4294	
20	2.7435	
21	3.4294	
22	3.4294	
23	2.7435	
24	2.7435	2.7435
Max	4.1152	3.2007
Min	1.6004	1.6004
Avg	3.0483	2.4332

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 401 / 33 KV TAYO LUCID  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	5.9442	5.2012
2	5.7728	5.2584
3	5.9442	5.487
4	5.8871	5.2584
5	5.8871	5.144
6	5.487	4.6868
7	5.0297	4.3439
8	6.4015	4.8583
11	6.6301	5.4298
12	6.0014	4.8011
13	6.5158	5.2584
14	6.6873	
15	6.4586	5.7156
16		4.5725
17		4.401
18	5.9442	4.1152
19	5.6013	4.0581
20	5.4298	4.1152
21		4.1724
22		3.8295
23	5.4298	4.2295
24	6.0014	4.5725
Max	6.6873	5.7156
Min	5.0297	3.8295
Avg	5.9474	4.7385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 402 / 33 KV SIEMENCE

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	5.487	4.5153
2	5.6584	4.5725
3	5.4298	4.7439
4	5.3155	4.9726
5	5.0869	5.2584
6	5.3155	5.144
7	5.487	5.0869
8	6.1728	4.7439
11	7.4303	4.7439
12	6.6873	
13	7.1445	
14	7.6017	
16		2.8578
17		4.4582
18	7.5446	4.401
19	5.4298	4.401
20	6.0585	4.2295
21		4.401
23	5.5441	4.1724
24	5.4298	4.401
Max	7.6017	5.2584
Min	5.0869	2.8578
Avg	6.0484	4.5355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 403 / 33 KV STARLITE CKT NO I  
Feeder KV- 33 / OUTGOING

EHV Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	3.658	3.7723
2	3.7151	3.8295
3	3.7151	3.8866
4	3.7723	3.8866
5	3.8295	3.8866
6	3.7723	3.8866
7	3.6008	4.0581
8	3.7151	3.6008
11	4.1724	4.0009
12	3.8866	4.1152
13	4.0009	4.2867
14	4.3439	
15	3.6008	4.0009
16		3.7723
17		4.0009
18	4.0009	3.8295
19	4.0009	4.0581
20	4.2867	4.0009
21		4.0581
22		3.9438
23	3.6008	4.0009
24	3.8295	3.9438
Max	4.3439	4.2867
Min	3.6008	3.6008
Avg	3.8612	3.9438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 404 / 33 KV STARLITE CKT NO II

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	3.2007	3.1436
2	3.2579	3.2007
3	3.2007	3.2579
4	3.2579	3.2007
5	3.2579	3.2579
6	3.2579	3.2579
7	3.2579	3.2579
8	3.315	3.2579
11	3.2007	2.9721
12	3.2007	3.2007
13	3.2579	3.2007
14	3.2579	
15	3.315	3.2007
16		3.2007
17		3.2007
18	3.2579	3.2007
19	3.2579	3.2007
20	3.2579	3.2007
21		3.315
22		3.2007
23	3.2579	3.2579
24	3.1436	3.2007
Max	3.315	3.315
Min	3.1436	2.9721
Avg	3.2452	3.2089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 408 / 33 KV WOCKHARDT BIO EXP

EHV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.8578	2.6863
2	2.7435	2.6292
3	3.4294	2.6292
4	3.7151	2.9721
5	4.0009	3.0864
6	3.8866	2.9721
7	2.9721	2.915
8	3.0293	3.1436
11	3.4294	3.2579
12	3.2579	3.3722
13	3.315	3.3722
14	3.2579	
15	3.3722	3.2579
17		3.315
18	3.2007	3.2007
19	3.0293	3.0864
20	3.0293	3.1436
21		2.9721
23	3.1436	3.1436
24	2.915	2.915
Max	4.0009	3.3722
Min	2.7435	2.6292
Avg	3.2547	3.0563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 409 / 33KV M-SECTOR FEEDER  
Feeder KV- 33 / OUTGOING

HV Non-Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		5.0297
2		4.8011
3		4.5725
4		4.5725
5		4.5153
6		3.8866
7		3.5437
8		3.8866
11	7.316	4.5725
12	7.0302	4.3439
13	6.4015	4.2867
14	7.6017	
15	7.316	4.6296
18	6.7444	
19	5.3727	
20	5.144	
23	5.0297	
24		5.0869
<b>Max</b>	<b>7.6017</b>	<b>5.0869</b>
<b>Min</b>	<b>5.0297</b>	<b>3.5437</b>
<b>Avg</b>	<b>6.4396</b>	<b>4.4406</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 410 / 33 KV E + H EXP.

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0572	.0572
2	.0572	.0572
3	.0572	.0572
4	.0572	.0572
5	.0572	.0572
6	.0572	.0572
7	.0572	.3429
8	.4001	.3429
11	.5144	.8002
12	.5144	.9145
13	.4572	.8002
14	.4572	
15	.5144	.8002
16		.2858
17		.4572
18	.3429	.2286
19	.1143	.1715
20	.1143	.1715
21		.0572
23	.1715	.0572
24	.0572	.0572
Max	.5144	.9145
Min	.0572	.0572
Avg	.2255	.2915



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 411 / 33 KV V.A. ENGINEERS

HV Express Feeder

FEEDER Feeder KV- 33 /  
OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0572	.0572
2	.0572	.0572
3	.0572	.0572
4	.0572	.0572
5	.0572	.0572
6	.0572	.0572
7	.0572	.0572
8	.0572	.0572
11	.0572	.0572
12	.0572	.0572
13	.0572	.0572
14	.0572	
15	.0572	.0572
16		.0572
17		.0572
18	.0572	.0572
19	.0572	.0572
20	.0572	.0572
21		.0572
22		.0572
23	.0572	.0572
24	.0572	.0572
Max	.0572	.0572
Min	.0572	.0572
Avg	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 412 / 33 KV Orchid Feeder

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	3.8866	3.8866
2	3.8866	3.8295
3	3.8866	3.7723
4	3.9438	3.7723
5	4.0009	3.7723
6	3.8866	3.7723
7	3.658	3.7723
8	4.0009	3.8866
9		4.0009
11	4.2295	4.1152
12	4.2295	4.3439
13	4.1152	4.1152
14	4.1152	
15	4.2295	4.2295
16		4.2295
17		4.1152
18	2.2862	4.1152
19	4.0009	3.7723
20	4.0009	4.3439
21		3.8866
23	3.658	4.0009
24	3.7723	3.8866
<b>Max</b>	<b>4.2295</b>	<b>4.3439</b>
<b>Min</b>	<b>2.2862</b>	<b>3.7723</b>
<b>Avg</b>	<b>3.8771</b>	<b>3.9819</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN I DIVSION[221]

WALUNJ S/DN.[672] BU 4672

Substation No/ Name :- 049001 / 400KV WALUJ S/STN

Feeder No / Name : 416 / ENDURANCE EXPRESS (K-  
Sector) F Feeder KV- 33 /  
OUTGOING

HV Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.0005	3.2007
2	2.0576	3.2007
3	2.1148	3.0864
4	2.1719	3.2007
5	2.1719	3.2007
6	2.0576	2.4006
7	2.0005	1.829
8	2.1719	1.9433
11	2.4006	.8002
12	2.2862	1.0288
13	2.1719	.9717
14	2.0576	
15	2.0576	.8573
16		.8573
17		1.1431
18	4.1152	1.0288
19	4.0009	1.0288
20	3.5437	.8002
21		1.0288
23	3.315	.6859
24	1.8861	3.2007
<b>Max</b>	<b>4.1152</b>	<b>3.2007</b>
<b>Min</b>	<b>1.8861</b>	<b>.6859</b>
<b>Avg</b>	<b>2.4768</b>	<b>1.7747</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 201 / 11KV SUBHASHRI  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.9907	
2	.9526	
3	.9526	
4	.9526	
5	1.0288	
6	1.1431	
7	1.3336	
8	1.2574	
9	1.1812	
10	1.1203	
11	1.0082	.9335
12	.9709	.9709
13		.8589
14	.8589	
15	.8589	.8962
16	.8962	.8215
17		1.0456
18	.9335	.9774
19	1.1203	1.086
20	1.307	1.3394
21	1.307	1.3032
22		1.2308
23		1.1946
24	1.0288	1.307
Max	1.3336	1.3394
Min	.8589	.8215
Avg	1.0601	1.0742

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 202 / 11KV N5 CIDCO FEEDER  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1431	
2	1.0669	
3	1.0669	
4	1.0669	
5	1.1431	
6	1.3717	
7	1.7528	
9	1.448	
10	1.5684	
11	1.419	1.4563
12	1.2323	1.3817
13		1.307
14	1.2696	
15	1.1576	1.1949
16	1.1576	1.1949
17		1.1576
18	1.3203	1.1946
19	1.5089	1.4118
20	1.6975	1.6651
21	1.6975	1.5927
22		1.448
23		1.267
24	1.2193	1.5089
Max	1.7528	1.6651
Min	1.0669	1.1576
Avg	1.3320	1.3677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 203 / 11KV RAM MANDIR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.724	
2	.724	
3	.6859	
4	.6859	
5	.6859	
6	.724	
7	.7621	
8	.8764	
9	.7621	
10	.7468	
11	.6722	.7282
12	.6535	.6535
13		.6348
14	.6535	
15	.6161	.6535
16	.6535	.6348
17		.6161
18	.7468	.6154
19	.8402	.724
20	.9335	.905
21	.8962	.9955
22		.9412
23		.7783
24	.7621	.8589
Max	.9335	.9955
Min	.6161	.6154
Avg	.7402	.7492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 204 / 11KV SHARADA  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.3717	
2	1.3336	
3	1.3336	
4	1.3336	
5	1.6004	
6	1.6766	
7	2.0576	
8	1.829	
9	1.6385	
10	1.6991	
11	1.5684	1.5684
12	1.4937	1.4937
13		1.4377
14	1.475	
15	1.419	1.363
16	1.4377	1.419
17		1.419
18	1.6975	1.448
19	1.6975	1.8823
20		2.0271
21		2.1357
22		1.8099
23		1.448
24	1.448	
Max	2.0576	2.1357
Min	1.3336	1.363
Avg	1.5617	1.6210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

A'BAD CIDCO S/DN.[674] BU 4674

Substation No/ Name :- 044212 / N-7 SUB-STATION

Feeder No / Name : 205 / 11 KV WATER SUPPLY  
Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1143	
2	.1143	
3	.1143	
4	.1143	
5	.1143	
6	.1143	
7	.1143	
8	.1524	
9	.1143	
10	.112	
11	.0934	.112
12	.112	.0934
13		.0934
14	.112	
15	.112	.112
16	.0934	.0934
17		.0934
18		.1109
19		.1109
20		.1109
21		.1109
22		.1109
23		.1109
24	.1143	
Max	.1524	.112
Min	.0934	.0934
Avg	.1135	.1053



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 203 / CIDCO-N4

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.6263	1.7187
2	1.5708	1.6448
3	1.3717	1.5524
4	1.5154	1.5339
5	1.5708	1.5524
6	1.9589	2.0328
7	2.1437	2.1622
8	2.0883	2.0698
9	2.1622	2.1992
11	2.0328	1.9589
12	1.9035	1.848
14	1.8111	1.9035
15	1.7372	1.848
16	1.7741	1.922
17	1.9959	1.9589
18		1.9404
19		2.1068
20		2.6427
21		2.5318
22		2.2546
23	2.0328	2.0698
24	1.7556	1.848
<b>Max</b>	<b>2.1622</b>	<b>2.6427</b>
<b>Min</b>	<b>1.3717</b>	<b>1.5339</b>
<b>Avg</b>	<b>1.8265</b>	<b>1.9682</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 204 / MUKUNDWADI  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.848	1.885
2	1.8111	1.885
3	1.7556	1.9035
4	1.8665	1.9404
5	1.9404	2.0513
6	2.7905	2.6427
7	2.6427	2.6427
8	2.6242	2.7166
9	2.1437	2.4394
11	1.8665	1.9774
12	1.9959	1.6817
13		1.6817
14	1.9589	1.8665
15	1.8296	1.7002
16	1.5893	1.9035
17	1.922	1.848
18		1.8296
20		2.5503
21		2.5873
23	2.1437	2.1992
24	1.9589	1.885
Max	2.7905	2.7166
Min	1.5893	1.6817
Avg	2.0404	2.0865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044031 / 33 KV N-4 S/S

Feeder No / Name : 205 / High court Exp  
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0373	.0373
2	.0373	.0373
3	.0373	.0373
4	.0373	.0373
5	.0373	.0373
6	.0187	.0373
7	.0187	.0187
8	.0373	.0373
9	.0747	.0739
11	.4481	.3734
12	.3734	.4108
14	.3361	.2987
15	.3361	.3361
16	.3734	.3174
17	.4108	.3174
18		.168
19		.112
20		.0747
21		.056
23	.056	.056
24	.0373	.0373
Max	.4481	.4108
Min	.0187	.0187
Avg	.1592	.1386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 201 / MHADA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3986	.3781
2	.3608	.3986
3	.3241	.3813
4	.3616	.4158
5	.4007	.4335
6	.5865	.5095
7	.5584	.5605
8	.592	
9	.499	
10		.3921
11	.3921	.3734
12	.3921	.3772
13	.3921	.3109
14	.3921	.3174
15	.3174	.3174
16	.3584	.2987
17		.3921
18	.4435	.3361
19	.4294	.3921
20	.5212	
21	.499	.4805
22	.4755	.5228
23		.4394
24	.3999	.3781
Max	.592	.5605
Min	.3174	.2987
Avg	.4331	.4003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 202 / RAMNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.2736	1.2603
2	1.1946	1.2321
3	1.162	1.1802
4	1.2203	1.2972
5	1.5029	1.4464
6	2.2108	1.9506
7	2.2569	2.0929
8	2.1198	1.9568
9	1.7575	1.8396
10		1.6617
11	1.4449	1.3491
12	1.2437	1.2696
13	1.2254	1.251
14	1.2323	1.1763
15	1.1576	1.1576
16	1.2071	1.0269
17		1.1523
18	1.628	1.4003
19	1.9585	1.7177
20	2.134	1.9936
21	1.8258	1.7924
22	1.7577	1.7177
23		1.4311
24	1.3535	1.2816
Max	2.2569	2.0929
Min	1.1576	1.0269
Avg	1.5651	1.4848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 203 / Dhoot Exp.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.1463	.1323
2	.1276	.1326
3	.1284	.1324
4	.1475	.1326
5	.1667	.1324
6	.1679	.151
7	.2054	.1701
8	.225	.1701
9	.2829	.2268
10		.2801
11	.3206	.3395
12	.3395	.3361
13	.3395	.3174
14	.3395	.2987
15	.2829	.3174
16	.3018	.3174
17		.2801
18	.2048	.2427
19	.188	.2054
20	.185	.1867
21	.184	.1886
22	.1655	.168
23		.1646
24	.1463	.151
Max	.3395	.3395
Min	.1276	.1323
Avg	.2188	.2156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 044058 / MHADA 33 KV SUB STN

Feeder No / Name : 204 / 11 KV Chikalhana  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.6626	1.6897
2	1.5863	1.6375
3	1.6129	1.586
4	1.7466	1.6324
5	2.2085	2.2035
6	2.8733	2.7906
7	2.9874	2.975
8	2.838	2.8715
9	2.5527	2.5937
11	1.933	2.0687
12	1.6766	1.7804
13	1.576	1.7804
14	1.5775	1.6617
15	1.5604	1.6278
16	1.4243	1.6787
17		2.0165
18	2.301	1.8991
19	2.6729	2.0454
20	2.782	2.7639
21	2.3148	2.3569
22	2.1165	2.0622
23		1.9384
24	1.7228	1.754
<b>Max</b>	<b>2.9874</b>	<b>2.975</b>
<b>Min</b>	<b>1.4243</b>	<b>1.586</b>
<b>Avg</b>	<b>2.0822</b>	<b>2.0615</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 201 / GARWARE EXP.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		1.9993
2		1.8484
3		1.9427
4		1.8861
5		1.8673
6		1.8296
7		1.9427
8		1.9239
9		1.9427
10		1.9616
11		2.0182
12		1.9239
13		1.9239
14		1.9805
15		1.9427
16		1.9805
17		1.9805
18		1.9616
19		1.9616
20		1.9616
21		1.8673
22		1.9239
23	1.8673	1.9805
24	1.8111	1.9616
Max	1.8673	2.0182
Min	1.8111	1.8296
Avg	1.8392	1.9380



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 202 / CENTRON

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.4755	.4938
2	.4938	
3	.439	
4	.4715	
5	.4207	
6	.3898	
7	.5601	
8	.6133	
9	.7716	
10	1.0082	
11	1.1128	
12	1.1128	
13	.9511	
14	.9979	
15	1.1506	
16	1.1016	
17	1.0829	
18	1.1016	
19	.9694	
20	.9694	
21	.8507	
22	.7108	
23	.6718	
24	.5441	.5992
Max	1.1506	.5992
Min	.3898	.4938
Avg	.7905	.5465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 203 / MAHAVEER EXP

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0754	
2	.0762	
3	.0566	
5	.0754	
6	.0943	
7	.0953	
8	.0943	
9	.168	
10	.1132	
11	.132	
12	.132	
13	.1478	
14	.1132	
15	.132	
16	.1307	
17	.1132	
18	.1132	
19	.1132	.132
20	.1509	.132
21	.1334	.1143
22	.1334	.1143
23	.1132	.132
24	.0943	
Max	.168	.132
Min	.0566	.1143
Avg	.1131	.1249

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 204 / 11 KV CIDCO

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.7737	1.7924
2	1.7177	1.7737
3	1.7551	1.7551
4	1.8111	1.8671
5	2.32	2.3577
6	3.4517	3.4517
7	3.7723	3.7912
8	3.678	3.7346
9	3.1876	3.1687
10	2.7446	2.7349
11	2.4459	2.5463
12	1.9605	2.0725
13	1.8484	
14	1.885	.8215
15	1.8298	1.7558
16	1.9589	1.9774
17	2.1992	2.2218
18	2.3101	2.3339
19	3.0434	2.8567
20	3.1367	3.3608
21	2.9127	3.0807
22	2.5206	2.5953
23	2.0725	2.2218
24	1.8298	1.8671
Max	3.7723	3.7912
Min	1.7177	.8215
Avg	2.4236	2.4408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 205 / RAMA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.4083	1.3769
2	1.1812	1.2193
3	1.1506	1.1317
4	1.094	1.094
5	1.1128	1.1506
6	1.4861	1.5432
7	1.6598	1.7353
8	1.8673	1.8296
9	1.9805	1.9993
10	1.8099	2.0936
11	2.3712	2.3712
12	2.2634	2.3577
13	2.2257	2.2965
14	2.2634	2.4086
15	2.3388	2.4646
16	2.2822	2.5206
17	2.4086	2.3899
18	2.6513	2.3152
19	2.5953	2.6242
20	2.5953	2.6513
21	2.3899	2.4646
22	2.2032	2.1845
23	1.7737	1.8861
24	1.6032	1.4901
Max	2.6513	2.6513
Min	1.094	1.094
Avg	1.9465	1.9833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 206 / Wokhardt

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.9054	.9054
2	.8962	.8676
3	.8413	.7842
4	.7602	.6878
5	.7842	.6584
6	.8869	.5959
7	.9808	.4915
8	1.3769	.6556
9	1.3817	.788
10	1.5089	.7392
11	1.3014	.7421
12	1.4712	.8131
13	1.2193	.7133
14	1.1883	.695
15	1.2637	.6878
16	1.4146	.6447
17	1.1506	.6697
18	1.226	.5959
19	1.1128	.4858
20	1.2003	.5197
21	1.094	.4268
22	1.0562	.4012
23	.9054	.4001
24	.9997	.9997
<b>Max</b>	<b>1.5089</b>	<b>.9997</b>
<b>Min</b>	<b>.7602</b>	<b>.4001</b>
<b>Avg</b>	<b>1.1219</b>	<b>.6654</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 207 / GREAVES

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.7353	2.1313
2	1.7353	1.7164
3	1.6975	1.9052
4	1.6004	1.7909
5	1.829	1.8673
6	2.0576	2.0559
7	2.7349	2.9047
8	3.1121	2.999
9		2.9424
10	3.5662	3.0556
11	3.2114	2.7161
12	2.6029	2.2822
13	2.6783	2.2445
14	2.9313	2.3388
15	2.6972	1.9616
16	3.1554	2.2822
17	3.1741	2.3577
18	2.6406	2.1719
19	3.0434	2.6595
20	2.3243	1.8671
21	2.8858	2.4143
22	2.584	2.3011
23	2.1502	1.848
24	1.7353	1.8671
Max	3.5662	3.0556
Min	1.6004	1.7164
Avg	2.5166	2.2784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 208 / RADIANT AGRO  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.7093	.7579
2	.7287	.7676
3	.7145	.7287
4	.7049	.724
5	.719	.7628
6	.8322	.8383
7	1.3998	.8269
8	1.9418	.9431
9	2.2634	1.166
10	2.3954	1.1317
11	2.4709	1.1393
12	2.3388	.9995
13	1.905	
14	2.3577	1.1305
15		1.1789
16	2.5086	1.1616
17	2.0576	1.094
18	1.7909	.8977
19	1.3717	.8206
20	1.1105	.9191
21	1.073	
22	1.1233	.9145
23	.8179	.8916
24		.7579
Max	2.5086	1.1789
Min	.7049	.724
Avg	1.5152	.9342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 209 / IND-II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.3014	1.094
2	1.2071	1.1128
3	1.1523	1.251
4		1.1949
5	1.5684	1.2323
6	1.9616	1.6278
7	1.9616	1.7926
8	2.2481	1.8111
9	2.5274	1.6244
10	2.5766	1.5684
11	2.6513	1.46
12	2.5766	1.4377
13	2.191	1.1403
14	2.2779	1.1949
15	2.2218	1.1523
16	2.6217	1.1576
17	1.9805	1.2567
18	2.2068	1.4563
19	1.5466	1.39
20	1.7164	1.6244
21	1.6385	1.2752
22		1.0791
23		.9511
24	1.1949	1.2193
Max	2.6513	1.8111
Min	1.1523	.9511
Avg	1.9680	1.3377



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 210 / 11 KV N-1

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.7655	.7655
2	.7282	.7762
3	.7095	.7468
4	.6908	.6908
5	.6722	.679
6	.8488	.8402
7	.7922	.9335
8	.9149	1.0164
9	.9997	1.1273
10	1.1458	1.134
11	1.1827	1.1827
12	1.2254	1.2382
13	1.1523	1.0719
14	1.1088	1.0164
15	1.0642	1.0719
16	1.0642	1.0534
17	1.1016	1.1088
18	1.0903	.9979
19	1.0719	1.1088
20	1.1643	1.1203
21	1.0082	1.0082
22	.961	.9425
23	.9055	.8686
24	.8215	.8131
Max	1.2254	1.2382
Min	.6722	.679
Avg	.9662	.9714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 211 / ELLORA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.9022	1.9387
2	1.7193	1.9185
3	1.6126	1.7878
4	1.6126	1.7703
5	1.8823	1.97
6	2.3594	2.3594
7	2.7915	2.1622
8	3.1121	2.5463
9	3.8855	2.6217
10	3.81	2.5652
11	3.3951	2.3712
12	3.546	2.4272
13	2.7161	2.2177
14	3.4894	2.2405
15	3.0556	
16	2.8669	
17	2.8769	2.0485
18	2.9613	2.3339
19	2.7726	1.9366
20	2.9047	2.4025
21	2.5393	2.0851
22	2.1437	2.0538
23	1.9909	1.922
24	1.957	1.9753
Max	3.8855	2.6217
Min	1.6126	1.7703
Avg	2.6626	2.1661

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 212 / IND-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.4143	2.0698
2	2.4768	2.037
3	1.957	2.2068
4	1.8107	1.9044
5	1.3592	1.56
6	2.0538	2.1658
7	1.2934	.8356
8	2.9801	.8288
9	2.0883	1.0105
10	2.8769	1.1584
11	1.9982	1.1431
12	3.1687	.7756
13	3.0933	.7305
14	2.8959	1.1873
15	3.2442	.9998
16	3.2065	.9602
17	2.8858	.8951
18	2.8481	.9061
19	1.5741	.823
20	2.7435	.6895
21	2.3011	.6081
22	2.0165	.7225
23	2.0144	.6554
24	1.587	1.2689
<b>Max</b>	<b>3.2442</b>	<b>2.2068</b>
<b>Min</b>	<b>1.2934</b>	<b>.6081</b>
<b>Avg</b>	<b>2.3703</b>	<b>1.1726</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 213 / 11 KV Naregaon

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.2323	1.1949
2	1.1763	1.1763
3	1.1949	1.1949
4	1.2449	1.2637
5		1.5089
6		1.9616
7		2.3765
8		2.1691
9		2.0936
10		1.9418
11		1.6244
12		1.46
13		1.5154
16		1.307
17		1.419
18		1.5684
20		1.905
21		1.5655
22		1.5655
23		1.4377
24	1.2696	1.2323
Max	1.2696	2.3765
Min	1.1763	1.1763
Avg	1.2236	1.5944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 214 / INDIAN TOOL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.6398	.5144
2	.6344	.4973
3	.5952	.5171
4	.5952	.5521
5	.5489	.5462
6	.6676	.5396
7	.7186	.5881
8	.8817	.7145
9	1.1694	.7773
10	1.2826	.8551
11	1.3336	1.0317
12	1.2323	.985
13	1.3336	
14	1.3146	
15	1.3392	.2092
16	1.2637	.9779
17	1.2449	.8381
18	1.0791	.6815
19	.8619	.6068
20	.7968	.583
21	.6763	.5548
22	.591	.4668
23	.5462	.4477
24	.643	.523
Max	1.3392	1.0317
Min	.5462	.2092
Avg	.9162	.6367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 215 / Agro Exp

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.6783	2.7905
2	2.3228	2.8829
3	2.1794	2.7252
4	2.2192	2.8481
5	2.4629	2.838
6	2.6606	2.6886
7	2.652	2.9801
8	2.894	2.6063
9	3.062	3.1741
10	3.677	3.546
11	3.2253	3.3573
12	3.4168	3.3196
13	3.7723	3.4328
14	3.5848	3.8485
15	3.3951	3.2114
16	4.1152	3.4139
17	3.4705	3.3573
18	3.4139	2.9938
19	3.3573	2.9801
20	3.0862	2.6981
21	2.999	2.4714
22	3.0178	2.6886
23	2.9014	2.4356
24	2.1807	2.809
<b>Max</b>	<b>4.1152</b>	<b>3.8485</b>
<b>Min</b>	<b>2.1794</b>	<b>2.4356</b>
<b>Avg</b>	<b>3.0310</b>	<b>3.0041</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 401 / Lupin (Gade Jalgaon  
Shendre M Feeder KV- 33 /  
OUTGOING

HV Express Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.9239	1.8861
2	1.9239	1.8861
3	1.829	1.9433
4	2.037	1.9433
5	2.037	1.8861
6	2.037	2.037
7	2.0936	2.037
8	2.0936	2.2068
9	2.2068	2.2068
10		2.2634
11		2.2634
12		2.2634
13		2.0936
14		2.2634
15		2.2634
16		2.3765
17		2.32
18		2.2068
19		2.0725
20		2.0936
21		2.0936
22		2.1502
23	2.0936	2.0936
24	1.9239	1.8861
Max	2.2068	2.3765
Min	1.829	1.8861
Avg	2.0181	2.114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 403 / 33 KV Indogerman

Urban/Sheddable Urban Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	4.3896	4.8325
2	4.2798	4.561
3	4.225	4.2896
4	4.225	4.225
5	4.3799	4.4353
6	5.5441	5.5996
7	5.9877	4.2135
8	5.655	5.2669
9	5.3224	5.6516
10	5.5967	5.4321
11	4.9966	5.6516
12	4.8325	5.048
13	4.7782	4.7239
14	4.6091	4.5542
15	4.6016	4.5542
16	4.6016	14.3347
17	4.8285	4.8834
18		4.8325
19		5.7556
20		6.5158
21		6.5158
22		5.9259
23		5.3772
24	4.6639	5.4161
Max	5.9877	14.3347
Min	4.225	4.2135
Avg	4.8621	5.5248



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 404 / 33 kV Mhada

Urban/Sheddable Urban Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	10.535	10.8642
2	10.3704	10.4796
3	10.2058	10.4801
4	10.3155	10.6447
5	12.0308	12.4743
6	16.0197	16.6358
7	16.2437	16.4661
8	15.6345	15.8562
9	14.8028	15.0246
10	14.2661	14.6502
11	13.8272	12.7058
12	12.7601	11.6198
13	12.3257	10.8596
14	12.2908	13.0018
15	12.2908	12.8144
16	12.38	
17	13.2488	13.6831
18	14.3347	13.1093
19	16.0723	12.8687
20	17.7778	17.7229
21	15.8574	15.8025
22	14.5405	14.5405
23	12.5652	12.8944
24	11.2483	11.4129
<b>Max</b>	<b>17.7778</b>	<b>17.7229</b>
<b>Min</b>	<b>10.2058</b>	<b>10.4796</b>
<b>Avg</b>	<b>13.4143</b>	<b>13.3309</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

CHIKALDHANA S/DN.[395] BU 4395

Substation No/ Name :- 047002 / 132 KV CHIKALTHANA S/S

Feeder No / Name : 405 / Empire Mall

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1		.2
2		.1829
3		.1395
4		.1858
5		.1858
6		.1715
7	.2	.2058
8	.2201	.2115
9	.192	.2058
10	.7499	.7773
11	1.3032	1.3306
12	1.4563	1.4003
13	1.4563	1.4712
14	1.4712	1.4712
15	1.4712	1.4712
16	1.5278	1.5278
17	1.4563	1.5278
18	1.5278	1.5844
19	1.5844	1.5844
20	1.5844	1.9433
21	1.5278	1.829
22	.9465	1.5278
23	.3189	.5401
24		.2315
<b>Max</b>	<b>1.5844</b>	<b>1.9433</b>
<b>Min</b>	<b>.192</b>	<b>.1395</b>
<b>Avg</b>	<b>1.1173</b>	<b>.9128</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 201 / 11 KV LAXMI NGR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.5623	1.531
2	1.5623	1.531
3	1.6004	1.587
4	1.6004	1.587
5	1.6004	1.6991
6	1.9814	1.8298
7	2.191	2.0911
8	2.1529	2.0725
9	2.0538	2.1098
10	1.9605	1.7737
11	1.9231	
13		2.0725
14	1.4377	1.6244
15		1.587
16		1.531
17	1.643	1.4937
18	1.7924	1.3443
19	1.9791	1.4937
20	2.1845	2.1098
21	2.0351	1.9978
22	1.8858	1.8671
23	1.6804	1.6804
24	1.5623	1.5497
<b>Max</b>	<b>2.191</b>	<b>2.1098</b>
<b>Min</b>	<b>1.4377</b>	<b>1.3443</b>
<b>Avg</b>	<b>1.8194</b>	<b>1.7347</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 202 / 11 KV MORESHWAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.2765	1.3256
2	1.2765	1.307
3	1.3336	1.3256
4	1.3336	1.4003
5	1.4861	1.5123
6	1.6004	1.6244
7	1.6575	1.643
8	1.5242	1.6991
9	1.5497	1.6804
10	1.475	1.4937
11	1.363	1.4937
12		1.2323
14	1.1763	1.1949
15		1.1576
16		1.1763
17	1.363	1.2323
18	1.5497	1.307
19	1.7364	1.419
20	1.8484	1.7737
21	1.8111	1.7924
22	1.6991	1.6804
23	1.475	1.4937
24	1.2765	1.3256
Max	1.8484	1.7924
Min	1.1763	1.1576
Avg	1.4906	1.4474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 203 / 11 KV RENUKA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.743	.7842
2	.743	.8402
3	.7621	.8775
4	.7621	.9149
5	.9145	1.0456
6	1.0288	1.2323
7	1.1241	1.2136
8	1.1431	1.1389
9	.8775	1.0829
10	.7842	.7842
11	.7282	.7468
12		.7282
14	.6722	.6722
15		.6722
16		.6908
17	.6908	.7282
18	.9149	.7468
19	.9149	.8215
20	1.1389	1.0456
21	1.0269	.9709
22	.9522	.9335
23	.8402	.8402
24	.743	.7655
Max	1.1431	1.2323
Min	.6722	.6722
Avg	.8752	.8816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044210 / SHIVAJI NAGAR 33 KV

Feeder No / Name : 204 / 11 KV DEOGIRI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3048	.3361
2	.3048	.2987
3	.3239	.2987
4	.3239	.3174
5	.3429	.3361
6	.362	.3361
7	.362	.3547
8	.3239	.3547
9	.2987	.3547
10	.2614	.2614
11	.2427	.2614
12		.2427
14	.2427	.2427
15		.2241
16		.2241
17	.2614	.2427
18	.2614	.2614
19	.2987	.2987
20	.3921	.3547
21	.3921	.3734
22	.3547	.3734
23	.3361	.3361
24	.3048	.3174
Max	.3921	.3734
Min	.2427	.2241
Avg	.3148	.3044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 201 / 11KV CHETNA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.2779	2.2753
2	2.1472	2.1437
3	2.0538	2.0643
4	1.9605	2.0455
5	2.1472	2.2189
6	2.5206	2.9651
7	2.9313	2.8337
8	2.8753	2.8149
9	2.8064	2.8149
10	2.9088	
11	2.8149	
12	2.6273	
13	2.4396	
14	2.4021	
15	2.2519	2.6273
16	2.3809	2.4272
17		2.2405
18	2.7183	2.1285
19	3.0745	2.3525
20	3.3557	2.5393
21	3.1779	2.4272
22	2.9899	2.2405
23	2.7746	2.2405
24	2.4272	2.4159
Max	3.3557	2.9651
Min	1.9605	2.0455
Avg	2.6115	2.4114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 204 / 11 KV PAITHAN GATE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	2.2405	2.2918
2	2.1472	2.1703
3	2.0725	2.0852
4	2.0165	2.0643
5	2.0538	2.3246
6	2.4272	2.89
7	3.0434	3.1152
8	3.0247	3.1773
9	3.2278	3.4155
10	3.2841	
11	3.3779	
12	3.2841	4.3162
13	3.1903	4.0347
14	3.1527	
15	2.9088	3.3779
16		3.2861
17		3.1741
18	3.3216	3.2674
19	3.5656	3.3608
20	3.7797	3.8275
21	3.4682	3.4728
22	3.1838	3.1741
23	2.9147	2.894
24	2.4272	2.5334
Max	3.7797	4.3162
Min	2.0165	2.0643
Avg	2.9142	3.0597



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044211 / 33KV PANNALALNAGAR

Feeder No / Name : 206 / 11 KV DEVA NAGARI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.0456	1.1283
2	.9896	1.0697
3	.9335	1.0321
4	.8962	1.0134
5	.9335	1.1072
6	1.0269	1.2535
7	1.2323	1.2949
8	1.307	1.2774
9	1.3845	1.4075
10	1.4262	
11	1.3136	
12	1.2386	1.689
13	1.1635	1.3512
14	1.126	
15	1.126	1.3136
16	1.1436	1.1389
17		1.1389
18	1.2761	1.1389
19	1.315	1.307
20	1.5216	1.4003
21	1.4638	1.4003
22	1.4089	1.307
23	1.2909	1.2136
24	1.1576	1.1823
Max	1.5216	1.689
Min	.8962	1.0134
Avg	1.2052	1.2460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 201 / 11 KV INDIRA NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.3429	.3239
2	.3239	.3048
3	.3048	.3048
4	.3429	.381
5	.4191	.4572
6	.4763	.4954
7	.5525	.6097
8	.5906	.5716
9	.5335	.6097
10	.5335	
11	.5716	
12	.5716	
13	.5144	
14	.4954	
15	.4763	.5906
16	.4954	.6097
17		.5716
18	.5716	.5906
19	.6287	.5906
20	.724	.6478
21	.5906	.5906
22	.5335	.5906
23	.4382	.4572
24	.362	.362
Max	.724	.6478
Min	.3048	.3048
Avg	.4954	.5084

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 202 / 11 KV STADIUM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.0191	.0191
2	.0191	.0191
3	.0191	.0191
4	.0191	.0191
5	.0381	.0381
6	.0381	.0381
7	.0572	.0381
8	.0572	.0381
9	.0572	.0381
10	.0572	
11	.0381	
12	.0381	
13	.0381	
14	.0381	
15	.0381	.0381
16	.0381	.0381
17		.0572
18	.0572	.0572
19	.0572	.0381
20	.0762	.0572
21	.0762	.0572
22	.0381	.0381
23	.0381	.0381
24	.0191	.0191
Max	.0762	.0572
Min	.0191	.0191
Avg	.0423	.0371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 203 / 11 KV CHANAKYAPURI  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.105	1.086
2	1.0479	1.0479
3	.9907	1.0288
4	1.0288	1.0479
5	1.1431	1.105
6	1.1812	1.1431
7	1.2003	1.3146
8	1.3336	1.4289
9	1.448	1.4861
10	1.4861	
11	1.4098	1.4098
12	1.4289	1.2765
13	1.3336	1.3527
14	1.3146	
15	1.2193	1.2193
16	1.2574	1.1812
17		1.2765
18	1.5242	1.2574
19	1.5242	1.467
20	1.6194	1.5432
21	1.5051	1.4861
22	1.4861	1.4098
23	1.3527	1.3336
24	1.1431	1.1622
Max	1.6194	1.5432
Min	.9907	1.0288
Avg	1.3080	1.2756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 204 / 11 KV MUTHA COMPLEX  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8573	.8573
2	.7621	.8573
3	.8002	.9335
4	.8573	1.0288
5	.9145	1.105
6	1.0479	1.1431
7	1.2384	1.2384
8	1.1431	1.2193
9	1.086	1.1622
10	1.105	
11	1.0098	1.0288
12	.9526	.7621
13	.9145	.743
14	.8954	
15	.8954	.8764
16	.9526	.9145
17		.9145
18	.9907	.9335
19	1.1431	1.086
20	1.1241	1.1812
21	1.1431	1.1241
22	1.0669	1.0479
23	1.0479	1.0288
24	.8764	.9145
Max	1.2384	1.2384
Min	.7621	.743
Avg	.9924	1.0046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 205 / 11 KV SUHAS COLONY  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	1.1812	1.2384
2	1.1431	1.1812
3	1.2193	1.1812
4	1.3336	1.3336
5	1.4289	1.7147
6	1.5242	1.7909
7	1.6004	1.6385
8	1.4289	1.6004
9	1.4861	1.4861
10	1.4289	
11	.6668	1.4098
12		1.3336
13	1.2955	1.3336
14	1.2384	
15	1.1431	1.1431
16	1.2955	1.2193
17		1.1812
18	1.3908	1.2384
19	1.6194	1.448
20	1.829	1.7147
21	1.7528	1.7147
22	1.7147	1.6575
23	1.448	1.4861
24	1.2193	1.2955
Max	1.829	1.7909
Min	.6668	1.1431
Avg	1.3813	1.4246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-JUN-17 and 05-JUL-17

AURANGABAD ZONE[067]

AURANGABAD (U) CIRCLE[645]

AURANGABAD URBAN II.DIVSION[222]

GHARGHED S/DN.[675] BU 4675

Substation No/ Name :- 044225 / 33/11 KV SOOT GIRNI

Feeder No / Name : 206 / 11 KV GAJANAN MANDIR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	29-JUN-17	30-JUN-17
HR	Load (MW)	Load (MW)
1	.8573	.8764
2	.7811	.8573
3	.7811	.9335
4	.8192	.9526
5	.8954	1.0288
6	.9526	1.0669
7	1.0288	.9526
8	1.2193	1.0669
9	1.1812	1.1431
10	1.2193	
11	.5716	1.3146
12	1.2955	1.1812
13	1.2193	1.2955
14	1.1812	
15	1.1622	1.086
16	1.1431	1.0669
17		1.1431
18	1.2955	1.2384
19	1.3908	2.4958
20	1.448	2.4958
21	1.467	2.2862
22	1.2193	2.0576
23	1.1812	1.7909
24	.8573	.9145
Max	1.467	2.4958
Min	.5716	.8573
Avg	1.0942	1.3293