

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 201 / 11KV Thadipawani

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.266	.25	.6219	.6424	.6356	.4839	.567
2	.2622	.2477	.6104	.6333	.6379	.3178	.3018
3	.2599	.2469	.6089	.6302	.6356	.3147	.3003
4	.2599	.2416	.628	.6257	.631	.3155	.2964
5	.2545	.2385	.5982		.6211	.3102	.2934
6	.2545	.234	.583	.4786	.6074	.2995	.2873
7	.25	.2294	.4656	.3909	.4954	.269	.2873
8	.2286	.2058	.3445	.3178	.3612	.2675	.2972
9	.2103	.234	.3323	.1738	.3361	.253	.2934
10		.2492	.1417	.1959	.2545	.3513	.2789
11	.1425	.3003	.2103	.2309	.2477	.3452	.298
12	.1349	.3216	.2629	.2279	.2393	.3056	.3094
13	.1227	.3155	.2538	.2157	.2675	.2911	.2134
14	.1075	.3437	.2538	.2157	.2858	.298	.2233
15	.1227	.3551	.2515	.2103	.2904	.298	.1951
16	.128	.2919	.2126	.2012	.2446	.2987	.2507
17	.2812	.3056	.2004	.1494	.1623	.317	.2675
18	.394	.3483	.3498	.2218	.407	.3734	.3262
19	.5853	.5975	.5632	.615	.5815	.6005	.5258
20	.6356	.6409	.6211	.6386	.6112	.6264	.5388
21	.6424	.6783	.6805	.647	.6501	.6493	.554
22	.6394	.6813	.6965	.6843	.6562	.6501	.57
23	.6341	.6577	.6783	.6729	.644	.6386	.5677
24	.6142	.6272	.6523	.6432	.6371	.5784	.5617
Max	.6424	.6813	.6965	.6843	.6562	.6501	.57
Min	.1075	.2058	.1417	.1494	.1623	.253	.1951
Avg	.3231	.3684	.4509	.4201	.4642	.3939	.3585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 202 / 11 KV WADHONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17
HR	Load (MW)
1	.3376
2	.3361
3	.333
4	.3338
5	.3506
6	.3803
7	.4123
8	.4664
9	.4199
10	.3262
11	.2096
12	.1677
13	.1616
14	.1699
15	.1776
16	.1821
17	.1997
18	.3559
19	.4176
20	.4009
21	.3788
22	.3757
23	.3635
24	.3483
Max	.4664
Min	.1616
Avg	.3169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 203 / 11KV Lohari-Sawanga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3628	.3894	.3788	.4001	.4031	.3688	.3201
2	.3589	.3864	.3208	.2804	.3086	.1867	.3216
3	.3597	.3856	.2301	.2073	.1951	.1859	.3246
4	.3582	.3757	.2454	.2065	.1936	.189	.3231
5	.3688	.3772	.2088	.234	.1913	.1898	.3216
6	.3681	.3864	.1997	.4512	.1966	.1974	.3277
7	.314	.3467	.205	.1555	.2119	.1837	.2995
8	.2644	.2401	.2233	.1859	.2317	.1966	.2629
9	.2378	.1913	.2591	.1837	.2705	.2149	.2271
10	.2149	.176	.298	.1684	.2096	.1981	.2012
11	.128	.2439	.1951	.1646	.1951	.2012	.2446
12	.1943	.2804	.1867	.1456	.1814	.1707	.269
13	.1875	.2835	.1905	.1585	.1616	.157	.2568
14	.1608	.2629	.1997	.176	.2134	.1684	.2614
15	.1517	.2797	.2012	.1882	.2172	.1722	.1928
16	.1852	.2423	.192	.1882	.208	.1875	.2012
17	.2111	.208	.176	.1753	.1715	.1943	.2164
18	.2172	.2378	.1783	.1616	.2492	.2385	.2256
19	.3841	.3582	.3574	.3422	.3422	.3742	.3506
20	.4085	.4031	.3932	.4123	.3696	.3917	.3597
21	.4176	.3871	.4161	.4146	.3849	.394	.3628
22	.4199	.3993	.426	.4237	.394	.4047	.3711
23	.4138	.4024	.4176	.4291	.3879	.4077	.3688
24	.3978	.3894	.4054	.413	.381	.3765	.3666
Max	.4199	.4031	.426	.4512	.4031	.4077	.3711
Min	.128	.176	.176	.1456	.1616	.157	.1928
Avg	.2952	.3180	.2710	.2611	.2612	.2479	.2907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

JALALKHEDA[560]

BU 0560

Substation No/ Name :- 164049 / New 33KV Bharsingi

Feeder No / Name : 205 / 11 KV PARADSINGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1471	.2934	.3018	.6569	.6165	.5571
2	.144	.1478	.2888	.298	.6485	.6066	.3292
3	.1433	.1478	.2896	.2964	.647	.6028	.3178
4	.1425	.1517	.2957	.2926	.6409	.6005	.3269
5	.144	.1585	.2797		.628	.5906	.3437
6	.1501	.144	.2743	.2667	.5982	.5731	.3361
7	.1296	.1235	.1844	.2111	.4146	.0564	.3262
8	.1135	.109	.1288	.1486	.3315	.3589	.2789
9	.1219	.1425	.1174	.317	.3193	.3605	.314
10	.1273	.1372	.0937	.1273	.2469	.2553	.3025
11	.125	.1212	.1341	.1417	.3262	.2896	.2964
12	.1227	.1311	.1334	.2644	.3521	.2972	.1174
13	.1417	.1532	.1334	.2599	.3528	.2782	.1357
14	.157	.1631	.128	.2804	.3673	.2568	.1433
15	.1509	.1661	.1303	.2942	.3688	.2332	.1448
16	.1417	.1608	.1288	.2637	.3429	.2614	.1387
17	.1395	.1395	.1311	.2698	.3239	.2835	.1235
18	.1722	.157	.1768	.3719	.4321	.3856	.1608
19	.2591	.2675	.2881	.6226	.5815	.6051	.2484
20	.2766	.2934	.3064	.6638	.6241	.6447	.266
21	.2972	.3132	.3262	.695	.6584	.6661	.2667
22	.3003	.3178	.333	.7308	.6653	.6752	.266
23	.2919	.3102	.3185	.7004	.6386	.6661	.2644
24	.2835	.298	.3079	.6699	.6264	.6295	.2644
Max	.3003	.3178	.333	.7308	.6653	.6752	.5571
Min	.1135	.109	.0937	.1273	.2469	.0564	.1174
Avg	.1758	.1834	.2176	.3690	.4913	.4497	.2612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 201 / 11 KV LAXMINAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.245	.245	.2679	.2896	.2949	.2728	.2511
2	.242	.2412	.2603	.2843	.2896	.2663	.2454
3	.2401	.2355	.2564	.2846	.2843	.2652	.2446
4	.2401	.2366	.2561	.2778	.282	.2633	.2454
5	.2439	.2378	.2595	.2343	.2911	.266	.2458
6	.2404	.2439	.2442	.2401	.2858	.2724	.2503
7	.242	.2321	.2271	.2526	.266	.2679	.2526
8	.1882	.2241	.2145	.2168	.2435	.2526	.2069
9	.1818	.2218	.2119	.2183	.2321	.2583	.2301
10	.1955	.2092	.1985	.2164	.2233	.2564	.2321
11	.2023	.2092	.2267	.2241	.2244	.2435	.2538
12	.1882	.2206	.2465	.2397	.2492	.2458	.2465
13	.2035	.2054	.245	.2347	.2309	.2096	.2241
14	.2096	.2164	.2328	.245	.2618	.2195	.2294
15	.2134	.2183	.2362	.2328	.258	.2061	.2275
16	.1932	.2168	.2305	.229	.2542	.1959	.2107
17	.2039	.2088	.2347	.2073	.2263	.1905	.2191
18	.2256	.2111	.2347	.2378	.2568	.1848	.245
19	.282	.3056	.3292	.3334	.3266	.2904	.2953
20	.2896	.3269	.3521	.3509	.3353	.2991	.2968
21	.2915	.3361	.3528	.3574	.3285	.3163	.2915
22	.2858	.3349	.3513	.3475	.3338	.3178	.2839
23	.2759	.3109	.3277	.3342	.3064	.3048	.2717
24	.2618	.2816	.3003	.3045	.2835	.285	.2564
Max	.2915	.3361	.3528	.3574	.3353	.3178	.2968
Min	.1818	.2054	.1985	.2073	.2233	.1848	.2069
Avg	.2327	.2471	.2624	.2664	.2737	.2563	.2482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 202 / 11 KV BUS STAND SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7057	.692	.7956	.852	.7926	.7987	.7087
2	.6722	.663	.756	.8032	.7651	.7545	.6737
3	.6554	.6462	.7362	.7865	.7484	.7346	.6676
4	.6508	.6386	.7209	.7727	.727	.7225	.6508
5	.6462	.6386	.7179	.6615	.7209	.7118	.6523
6	.6645	.6478	.7103	.6554	.7164	.7118	.66
7	.8017	.7377	.7179	.7453	.7423	.7773	.7377
8	.7865	.7804	.7758	.759	.8002	.8566	.7788
9	.7133	.7804	.7621	.6859	.7712	.788	.7606
10	.7484	.7865	.7971	.7362	.791	.8078	.7941
11	.8962	.852	.8962	.8718	.8977	.849	.8581
12	.9084	.9206	.9435	.9267	1.0943	.8764	.9267
13	.9206	.9313	.9602	.9663	1.041	.8596	.9389
14	.9313	.8764	.9678	.9983	1.0258	.8825	.9297
15	.9404	.8535	.9465	1.0227	1.0242	.8688	.9343
16	.9389	.8612	.9023	1.0532	1.0334	.8733	.8947
17	.9267	.8779	.9206	.9968	.9846	.8429	.8962
18	.9435	.8291	.9297	.948	1.0212	.8413	.8916
19	1.0867	.9739	1.1599	1.0989	1.1385	1.0425	1.1218
20	1.1187	1.0517	1.2422	1.2239	1.1721	1.0806	1.1507
21	1.044	1.0151	1.1843	1.1507	1.1294	1.044	1.0852
22	.8886	.9541	1.0258	.9998	.9724	.9358	.9496
23	.8078	.9023	.9816	.9282	.8977	.8733	.8688
24	.7392	.8459	.8916	.8505	.8459	.8307	.7895
Max	1.1187	1.0517	1.2422	1.2239	1.1721	1.0806	1.1507
Min	.6462	.6386	.7103	.6554	.7164	.7118	.6508
Avg	.8390	.8232	.8934	.8956	.9106	.8485	.8467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 203 / 11 kV IUDP FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5746	.4458	.4954	.5289	.6249	.5075	.4603
2	.4519	.4382	.4832	.503	.5167	.49	.4489
3	.4443	.4313	.4694	.5007	.4969	.4832	.4473
4	.4435	.4283	.4694	.5007	.5007	.4824	.4451
5	.4565	.4344	.4885	.4466	.5022	.5403	.4489
6	.647	.6371	.6478	.5007	.6783	.6668	.6447
7	.628	.66	.6737	.5205	.6897	.7103	.6805
8	.5838	.6447	.6516	.4862	.6622	.6935	.6828
9	.5357	.6165	.6341	.4557	.6577	.6424	.6744
10	.5807	.6539	.6683	.4839	.708	.6371	.6676
11	.6706	.6737	.6859	.6348	.7042	.66	.6744
12	.6584	.6081	.7072	.6097	.7354	.5944	.5921
13	.6112	.6005	.6363	.6234	.6592	.5601	.5685
14	.6066	.6318	.6363	.6783	.6744	.5335	.6013
15	.4969	.5556	.5563	.6798	.6211	.4321	.5335
16	.5738	.5921	.6158	.695	.5578	.5647	.5472
17	.5929	.5921	.628	.6302	.5548	.567	.6036
18	.5998	.6226	.6485	.5975	.6722	.6432	.6531
19	.7095	.7339	.7842	.7529	.8131	.7453	.759
20	.7164	.7522	.8116	.7697	.7941	.7583	.7049
21	.6607	.6676	.6722	.7461	.7903	.6447	.5617
22	.5426	.5883	.6165	.7476	.7476	.5777	.5327
23	.519	.5517	.5929	.7103	.7064	.5472	.5106
24	.4733	.5213	.5517	.6554	.5357	.5045	.455
Max	.7164	.7522	.8116	.7697	.8131	.7583	.759
Min	.4435	.4283	.4694	.4466	.4969	.4321	.4451
Avg	.5741	.5867	.6177	.6024	.6502	.5911	.5791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 204 / 11 KV PANCHWATI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5318	1.5089	1.6766	1.7711	1.7558	1.7482	1.4556
2	1.4998	1.4876	1.6324	1.7177	1.7055	1.6751	1.4693
3	1.4815	1.4693	1.6126	1.6842	1.672	1.6415	1.4739
4	1.4403	1.4617	1.5943	2.1994	1.6766	1.6324	1.4571
5	1.4114	1.422	1.5927	1.6613	1.6491	1.6156	1.4556
6	1.4236	1.4083	1.5729		1.6156	1.6324	1.4723
7	1.291	1.3946	1.4159		1.4952	1.5364	1.4053
8	1.0501	1.1477	1.2056		1.2407	1.3062	1.1233
9	1.0029	1.0715	1.2071		1.1309	1.1843	1.1294
10	1.0959	1.0303	1.2651	1.2285	1.1172	1.2163	1.0837
11	1.102	1.0486	1.2849	1.1035	1.2102	1.1782	1.1325
12	1.0867	1.1218	1.2772	1.1492	1.2498	1.0501	1.1111
13	1.1081	1.2209	1.3687	1.1949	1.2193	.9861	1.1355
14	1.0761	1.2254	1.4007	1.2529	1.3748	.9968	1.1446
15	1.1721	1.2513	1.4434	1.2269	1.4098	.9541	1.0974
16	1.1309	1.2513	1.387	1.2849	1.358	.8825	.9602
17	1.1873	1.1675	1.3123	1.1827	1.3032	.9678	1.2955
18	1.4038	1.3672	1.2681	1.2209	1.5668	1.0761	1.3626
19	1.576	1.8016	1.7452	1.7665	1.8366	1.5897	1.6476
20	1.6842	1.8656	1.8961	1.8183	1.8991	1.7162	1.6811
21	1.736	1.9342	1.9646	1.954	1.9829	1.8	1.6293
22	1.736	1.9677	2.0134	1.9936	1.9814	1.893	1.6187
23	1.701	1.8976	1.9555	1.9403	1.9296	1.8656	1.6827
24	1.579	1.7345	1.8351	1.8153	1.832	1.7436	1.6461
Max	1.736	1.9677	2.0134	2.1994	1.9829	1.893	1.6827
Min	1.0029	1.0303	1.2056	1.1035	1.1172	.8825	.9602
Avg	1.3545	1.4274	1.5386	1.5583	1.5505	1.4120	1.3613

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 164054 / 33/11 kV R-APDRP KATOL S/S

Feeder No / Name : 205 / 11 KV PETHBUDHWAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1429	.1429	.1623	.1741	.1696	.165	.1429
2	.1406	.1406	.1566	.1703	.1646	.1616	.1425
3	.1402	.1395	.1543	.1688	.1619	.1589	.1414
4	.1387	.1387	.1551	.1677	.1608	.1593	.1414
5	.1395	.1398	.1532		.1608	.1585	.1417
6	.1471	.1429	.1528		.1597	.1581	.1448
7	.1437	.1501	.1497	.1673	.1589	.1581	.1482
8	.1292	.133	.1387	.1402	.1437	.1482	.1379
9	.1216	.1238	.1383	.1334	.1402	.1421	.1288
10	.1261	.1193	.1463	.1261	.1379	.1318	.1269
11	.1257	.1265	.149	.0476	.1543	.1265	.1185
12	.1139	.1276	.1517	.1718	.1768	.1177	.1185
13	.1204	.1307	.152	.1398	.152	.1189	.1067
14	.1231	.1364	.1536	.141	.1562	.1155	.1116
15	.1223	.136	.1547	.144	.1608	.1113	.1208
16	.1185	.1353	.1524	.1376	.1566	.1097	.1204
17	.1196	.136	.1467	.1318	.1406	.109	.1265
18	.1494	.1425	.1547	.1391	.1703	.1273	.1433
19	.1863	.1993	.1939	.2084	.2035	.1738	.1799
20	.1814	.2035	.2092	.2084	.202	.1783	.1806
21	.1806	.1985	.2073	.208	.2027	.1848	.1688
22	.1734	.197	.208	.1997	.2004	.1886	.1692
23	.1619	.1856	.2	.1959	.1913	.1787	.16
24	.149	.1715	.1833	.181	.1749	.1619	.1459
Max	.1863	.2035	.2092	.2084	.2035	.1886	.1806
Min	.1139	.1193	.1383	.0476	.1379	.109	.1067
Avg	.1415	.1499	.1635	.1592	.1667	.1477	.1403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

KATOL RURAL S/DN[351] BU 1945

Substation No/ Name :- 167013 / 132 KV KATOL

Feeder No / Name : 211 / 11 KV Citra

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0034	.003	.003	.0034	.003	.003	.0038
2	.003	.003	.003	.0034	.003	.003	.0034
3	.0034	.003	.003	.0034	.003	.003	.0034
4	.0034	.0034	.003	.0034	.003	.003	.0034
5	.0034	.0034	.003	.0034	.003	.003	.0034
6	.0034	.0034	.003	.0034	.0038	.003	.0034
7	.0034	.0034	.0034	.0034	.0038	.003	.0034
8	.0034	.0034	.0034	.0042	.0038	.003	.0034
9	.0034	.0034	.0034	.0027	.0034	.003	.0034
10	.003	.0034	.0034	.0027	.0034	.003	.0034
11	.003	.003	.0034	.0027	.003	.003	.0034
12	.003	.003	.0034	.0027	.003	.003	.0034
13	.0019	.0015	.0076	.0015	.0042	.0038	.0023
14	.0015	.0168	.0495	.0229	.0427	.0232	.0236
15	.0347	.093	.1139	.0232	.085	.0248	.1147
16	.2873	.2115	.3003	.0629	.373	.024	.218
17	.269	.2896	.5712	.1536	.4664	.024	.3506
18	.1821	.4481	.7343	.2945	.6013	.0038	.4824
19	.2717	.4854	.8756	.5384	.7106	.0015	.5982
20	.7564	.5761	.9709	.6863	.9709	.0015	.407
21	.6325	.7202	1.0479	1.0265	.9549	.0221	.3311
22	.8871	.5921	1.1248	.7087	1.0955	.0754	.5014
23	.4588	.6668	1.201	1.0818	1.1614	.0956	.7689
24	.3894	1.1881	1.217	1.1283	1.1888	.2069	.8341
Max	.8871	1.1881	1.217	1.1283	1.1888	.2069	.8341
Min	.0015	.0015	.003	.0015	.003	.0015	.0023
Avg	.1755	.222	.3439	.2403	.3206	.0226	.1947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164029 / 33/11 KV MOHGAON

Feeder No / Name : 204 / Adani express feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1113	.1143	.1265	.1166	.1151	.1193	.117
2	.112	.1151	.1265	.1132	.1155	.1181	.1151
3	.1128	.1151	.125	.12	.1135	.1322	.12
4	.1143	.1124	.1235	.1204	.1124	.1257	.1216
5	.1101	.112	.12	.117	.1128	.1147	.1135
6	.0804	.0831	.0945	.0854	.0823	.0865	.0884
7	.0693	.0686	.0735	.069	.0667	.0686	.0716
8	.0697	.0671	.0724	.0663	.0667	.0671	.0602
9	.0655	.0648	.0655	.0644	.0644	.069	.0701
10	.0754	.0701	.0587	.0747	.0655	.0774	.0701
11	.0549	.0857	.0575	.0758	.0785	.0766	.0751
12	.0644	.0667	.0553	.0739	.0667	.069	.072
13	.0678		.0526	.069	.0655	.0686	.069
14	.0655	.0579	.0553	.0674	.0667	.0732	.0686
15	.0678	.0575	.0522	.0655	.0659	.0762	.0678
16	.0613	.0613	.0556	.0796	.0659	.072	.0747
17	.0652	.0713	.0572	.0819	.0682	.0693	.0739
18	.0648	.0732	.0621	.08	.0751	.0709	.0751
19	.1086	.1063	.1116	.1109	.112	.1177	.1162
20	.1162	.1143	.1196	.1128	.1155	.1155	.1166
21	.1135	.1139	.1204	.1181	.1155	.1135	.12
22	.1139	.1143	.1162	.1151	.1151	.1139	.1029
23	.1128	.1132	.1193	.1174	.1177	.1166	.0945
24	.1135	.1276	.1196	.1105	.1166	.1147	.0911
Max	.1162	.1276	.1265	.1204	.1177	.1322	.1216
Min	.0549	.0575	.0522	.0644	.0644	.0671	.0602
Avg	.0880	.0907	.0892	.0927	.0900	.0936	.0902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 201 / 11 KV Kumari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2286	.5335	.5335	.5335	.5335	.4572
2	.4572	.2286	.4572	.5335	.4572	.5335	.4572
3	.4572	.2286	.3048	.5335	.5335	.5335	.4572
4	.4572	.2286	.3048	.5335	.5335	.5335	.4572
5	.4572	.2286	.3048	.5335	.5335	.5335	.4572
6	.4572	.2286	.3048	.4572	.5335	.5335	.4572
7	.381	.1524	.2286	.381	.381	.4572	.3048
8	.2286	.2286	.2286	.2286	.2286	.3048	.2286
9	.1524	.2286	.381	.1524	.2286	.2286	.2286
10	.1524	.2286	.3048	.1524	.1524	.2286	.2286
11	.1524	.1524	.2286	.3048	.2286	.2286	.2286
12	.1524	.0762	.2286	.2286	.3048	.2286	.2286
13	.2286	.2286	.2286	.3048	.3048	.2286	.2286
14	.1524	.2286	.3048	.3048	.3048	.2286	.1524
15	.2286	.2286	.3048	.3048	.3048	.2286	.2286
16	.2286	.2286	.3048	.3048	.3048	.2286	.2286
17	.2286	.2286	.3048	.3048	.2286	.2286	.2286
18	.1524	.1524	.2286	.2286	.2286	.1524	.1524
19	.3048	.381	.381	.381	.381	.381	.381
20	.381	.4572	.5335	.4572	.4572	.4572	.4572
21	.4572	.5335	.5335	.5335	.5335	.5335	.4572
22	.4572	.6097	.6097	.6097	.6097	.5335	.5335
23	.4572	.6097	.6097	.6097	.6097	.5335	.5335
24	.4572	.5335	.5335	.6097	.5335	.4572	.4572
Max	.4572	.6097	.6097	.6097	.6097	.5335	.5335
Min	.1524	.0762	.2286	.1524	.1524	.1524	.1524
Avg	.3207	.2858	.3620	.3969	.3937	.3779	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

MOHAPPA (R) S/DN.[354] BU 0354

Substation No/ Name :- 164059 / 33 KV Mohapa (Gadbardi)

Feeder No / Name : 203 / Mohapa Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17
HR	Load (MW)	Load (MW)
1	.381	.381
2	.381	.381
3	.381	.381
4	.381	.381
5	.381	.381
6	.381	.381
7	.381	.381
8	.3048	.3048
9	.3048	.3048
10	.3048	.3048
11	.3048	
12	.3048	.0762
13	.3048	.3048
14	.2286	.3048
15	.3048	.3048
16	.3048	.3048
17	.3048	.3048
18	.3048	.3048
19	.4572	.4572
20	.4572	.4572
21	.4572	.4572
22	.4572	.4572
23	.4572	.381
24	.381	.381
Max	.4572	.4572
Min	.2286	.0762
Avg	.3588	.3512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

NARKHED S DIV[353]

BU 0353

Substation No/ Name :- 164024 / 33/11 KV NARKHED

Feeder No / Name : 204 / 11 KV SARDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1235	.141	.2012	.2065	.2065	.2195	.192
2	.1196	.1219	.1981	.2027	.202	.1943	.192
3	.1196	.1196	.1959	.2027	.2012	.1334	.1875
4	.1181	.1166	.1936	.2027	.1989	.1402	.1859
5	.1189	.1166	.1905	.2004	.1974	.141	.1852
6	.1158	.1174	.1829	.1959	.1981	.141	.1829
7	.1242	.1265	.125	.1677	.1821	.1402	.1722
8	.1654	.1623	.0983	.125	.1204	.1524	.1997
9	.1837	.1867	.093	.1014	.1113	.1524	.2416
10	.1844	.1722	.1395	.1189	.1395	.1478	.2401
11	.0937	.0983	.1905	.1486	.1478	.1318	.1128
12	.0709	.0892	.237	.0922	.1578	.1235	.1189
13	.0892	.1067	.2545	.1738	.1806	.1212	.0069
14	.096	.1204	.2119	.1715	.1783	.1181	
15	.0953	.1135	.2157	.1677	.1463	.1044	.0145
16	.1044	.1143	.2157	.1905	.1357	.1143	.109
17	.1082	.1052	.1859	.2134	.1623	.1128	.1135
18	.1014	.0998	.1745	.1738	.1684	.1166	.1189
19	.16	.1463	.1547	.1478	.1974	.1898	.1905
20	.2149	.2195	.2119	.2134	.2301	.2332	.2324
21	.2256	.2279	.2347	.2225	.2385	.2484	.2401
22	.2301	.2286	.2515	.2378	.2446	.2545	.2385
23	.2271	.2263	.2469	.2324	.2408	.2431	.234
24	.2042	.2073	.2202	.218	.2301	.1974	.2134
Max	.2301	.2286	.2545	.2378	.2446	.2545	.2416
Min	.0709	.0892	.093	.0922	.1113	.1044	.0069
Avg	.1414	.1452	.1927	.1803	.1840	.1613	.1705

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 201 / 11 KV KACHARISAWANGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.096	.1014		.4161	.3917	.2942
2	.5136	.0983	.0076		.1936	.3849	
3	.5114	.0991	.0015		.1905	.3871	
4	.506	.0937			.1882	.3849	
5	.4938	.093			.1928	.378	
6	.4854	.0892			.1936	.3658	
7	.3193	.064	.0015		.1638	.285	.0053
8		.0305	.0701		.2058	.1776	
9		.0015	.0975		.2119		
10			.0023		.2126	.0046	
11			.0053		.2279		
12		.0434	.0198		.2431		
13		.0899	.0572		.2629		
14		.0884	.0815		.2774		
15		.0762	.0869	.0008	.285		
16		.0892	.0892		.2759		
17		.0854	.045		.2096		
18	.0008	.0617	.0015	.1814	.2934	.3467	
19	.1021	.1135	.1105	.4702	.4184	.4405	
20	.1021	.1181	.1166	.4786	.4435	.4954	
21	.1021	.1158	.1143	.4854	.4504	.4984	
22	.1044	.1105		.4885	.4557	.4908	
23	.1014	.1067		.4664	.426	.4832	
24	.0968	.1067		.4329	.4092	.4481	
Max	.5144	.1181	.1166	.4885	.4557	.4984	.2942
Min	.0008	.0015	.0015	.0008	.1638	.0046	.0053
Avg	.2824	.0850	.0561	.3755	.2853	.3727	.1498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 204 / 11 KV BAZARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5403	.4672	.5441	.5525	.5533	.4687	.5479
2	.5296	.4572	.2881	.3079	.2957	.4603	.5388
3	.5243	.4557	.2904	.2119	.298	.4572	.5281
4	.5243	.4504	.3132		.2896	.4588	.5159
5	.5258	.4534	.3246		.2789	.4534	.5182
6	.5167	.439	.2972		.2675	.4473	.5007
7	.3955	.3292	.3475	.0655	.4009	.3414	.3605
8	.3201	.3041	.3932	.2408	.4252	.2911	.2934
9	.3064	.3147	.4245	.2599	.4428	.2888	.2759
10	.2949	.2743	.2888	.2172	.2705	.1654	.2576
11	.3117	.2568	.3003	.1928	.2629	.2202	.3269
12	.3376	.2652	.3132	.1997	.3353	.2218	.3155
13	.2484	.3628	.3376	.2096	.3483	.2065	.3521
14	.3216	.4047	.3513	.1814	.3666	.1638	.3765
15	.2606	.3986	.3567	.2225	.3361	.1486	.3422
16	.1539	.3826	.349	.2119	.3117	.2446	.3041
17	.1387	.3307	.3353	.1936	.2987	.3193	.2881
18	.0945	.3239	.3384	.285	.1105	.2591	.333
19	.5258	.5883	.6112	.6142	.2896	.5784	.5685
20	.5617	.631	.6501	.6577	.474	.6318	.5883
21	.5799	.6592	.6516	.6683	.5601	.6401	.5967
22	.5731	.6653	.6249	.6592	.5594	.6341	.5937
23	.5357	.6409	.6097	.6241	.5312	.6089	.5578
24	.4999	.5815	.5822	.5845	.4999	.5777	.5144
Max	.5799	.6653	.6516	.6683	.5601	.6401	.5967
Min	.0945	.2568	.2881	.0655	.1105	.1486	.2576
Avg	.4009	.4349	.4135	.3505	.3669	.3870	.4331

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

KATOL DIVISION[653]

kondhali RURAL s/dn[352] BU 1953

Substation No/ Name :- 164022 / 33/11 KV KONDHALI

Feeder No / Name : 206 / 11KV MASOD NEW

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5944	.6722	.5685	.6828	.5274	.6462
2		.5868	.4024	.3673	.4435	.5228	.6371
3		.5838	.3887	.3826	.4298	.5167	.6142
4		.5777	.3887	.1585	.4283	.5609	.599
5		.57	.3826		.4252	.5609	.5898
6		.5624	.3871		.4207	.5456	.5548
7	.1631	.4268	.3917	.003	.4237	.4405	.4527
8	.2957	.3841	.4496		.4786	.3643	.3704
9	.3125	.3338	.4847	.0854	.4557	.3353	.346
10	.2972	.3109	.3201	.3155	.3475	.0274	.3307
11	.3079	.4298	.3643	.2789	.349	.1661	.3856
12	.2987	.3292	.3856	.3018	.3551	.2393	.3567
13	.3048	.3749	.3917	.3307	.3582	.2835	.4237
14	.3216	.4374	.3993	.3003	.4146	.1631	.2362
15	.3018	.4572	.4283	.3033	.3978	.2743	.3292
16	.2515	.4618	.4237	.3155	.3612	.2591	.4435
17	.3109	.1936	.4085	.3094	.2789	.3018	.4588
18	.3902	.1783	.4039	.314		.218	.4771
19	.6005	.7834	.7743	.7438	.0335	.7468	.5197
20	.7179	.8337	.8368	.8413	.5944	.7895	.4755
21	.7484	.8291	.6828	.8398	.6173	.8139	.791
22	.7103	.8109	.4664	.7941	.6142	.7941	.7682
23	.6447	.7514	.5853	.7484	.5426	.7575	.6767
24	.6127	.692	.5746	.7026	.5304	.6661	.599
Max	.7484	.8337	.8368	.8413	.6828	.8139	.791
Min	.1631	.1783	.3201	.003	.0335	.0274	.2362
Avg	.4217	.5206	.4747	.4288	.4340	.4531	.5034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTTEE(DRAGON

PALACE

Feeder No / Name : 201 / 11 KV Yerkheda 1

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1965	1.2833	1.3687	1.3977	1.2711	1.3047	1.2224
2	1.1614	1.2346	1.3245	1.3474	1.2483	1.2757	1.1934
3	1.137	1.2178	1.3108	1.3062	1.23	1.2651	1.166
4	1.1309	1.1949	1.2772	1.2757	1.2087	1.2422	1.1462
5	1.137	1.2071	1.2727	1.2635	1.2148	1.2391	1.1584
6	1.1873	1.2071	1.2757	1.2788	1.2178	1.2727	1.1843
7	1.2102	1.2711	1.2361	1.2803	1.1934	1.2864	1.2285
8	1.1157	1.1431	1.2056	1.1584	1.1614	1.166	.9846
9	1.1126	1.1309	1.2437	1.1431	1.1645	1.1355	1.3352
10	1.1248	1.1706	1.1934	1.1782	1.2163	1.1614	1.201
11	1.0456	1.1096	1.1309	1.0822	1.1721	1.0669	1.1081
12	1.0227	1.0715	1.105	1.0943	1.2498	.9709	.9968
13	.9663		1.2635	1.1233	1.259	.9678	1.0425
14	1.073		1.1965	1.102	1.1812	.9922	1.0105
15	1.0501	1.2529	1.2102	1.07	1.1767	.9694	.9907
16	.9389	1.1721	1.2346	1.038	1.1675	.9465	.9724
17	.9816	1.1782	1.233	1.0822	1.1401	.9526	1.0532
18	1.0547	1.1584	1.1873	1.1416	1.1477	1.0334	1.0852
19	.1936	1.3916	1.4144	1.4129	1.3199	1.2742	1.3397
20		1.4617	1.4601	1.4388	1.3565	1.3108	1.3855
21	1.544	1.4236	1.4083	1.4266	1.3382	1.3032	1.3382
22	1.5013	1.4114	1.4388	1.3748	1.3656	1.3184	1.3367
23	1.4525	1.4388	1.4601	1.355	1.387	1.3275	1.326
24	1.3611	1.4236	1.448	1.3275	1.3519	1.2849	1.2803
Max	1.544	1.4617	1.4601	1.4388	1.387	1.3275	1.3855
Min	.1936	1.0715	1.105	1.038	1.1401	.9465	.9724
Avg	1.1173	1.2525	1.2875	1.2374	1.2391	1.1695	1.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON

PALACE

Feeder No / Name : 202 / 11 KV NERI 1 Fdr

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7529	.7087	.881	.8535	.8337	.8383	.695
2	.4024	.6904	.8703	.8429	.8246	.823	.6859
3	.3978	.6783	.7621	.7423	.8246	.7346	.6813
4	.6432	.6737	.7682	.7331	.8185	.7316	.6722
5	.663	.6843	.7697	.7407	.7941	.7331	.7042
6	.6615	.6767	.7423	.4938	.7849	.7468	.6935
7	.6341	.6142	.7209		.7225	.7194	.6386
8	.5898	.5121	.7346	.5304	.6981	.6188	.4816
9	.6401	.5441	.788	.6584	.7164		.5304
10	.6523	.6066	.8169	.7209	.7499	.1555	.5197
11	.6645	.6112	.82	.6981	.7865	.378	.5898
12	.6417	.6493	.8398	.7514	.8109	.4755	.5807
13	.6508		.8535	.7545	.8124	.4542	.5533
14	.6737	.4329	.8474	.6859	.7407	.4938	.5594
15	.7179	.695	.8794	.7209	.7346	.4862	.5365
16	.7255	.6904	.8109	.628	.6554	.4832	.5335
17	.7026	.7331	.8063	.5853	.6676	.5106	.5487
18	.6935	.7804	.6615	.724	.7042	.5822	.6417
19	.7148	.9114	.9343	.9175	.8505	.7362	.788
20	.7118	.9785	.9556	.9343	.852	.7712	.7773
21	.7316	.9389	.9145	.9084	.8429	.7788	.756
22	.7636	.945	.8962	.8779	.8993	.788	.7529
23	.7148	.9206	.8886	.8581	.881	.7712	.7423
24	.7148	.8993	.8688	.8413	.8535	.7438	.7301
Max	.7636	.9785	.9556	.9343	.8993	.8383	.788
Min	.3978	.4329	.6615	.4938	.6554	.1555	.4816
Avg	.6608	.7207	.8263	.7479	.7858	.6328	.6414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON

PALACE

Feeder No / Name : 207 / 11 KV MODI 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	1.0791	1.1629	1.1446	1.0837	1.0974	1.1004
2	.9998	1.0425	1.1233	1.1126	1.041	1.044	1.0608
3	.9846	1.0197	1.0761	1.0913	1.0303	1.0364	1.0395
4	.9541	1.0105	1.0593	1.0547	1.0059	1.0197	1.0181
5	.948	1.0059	1.038	1.0334	1.0288	1.0273	1.0227
6	1.1385	1.4327	1.4342	1.3138	1.3611	1.3519	1.4403
7	1.3596	1.2163	1.1599	1.1172	1.0639	1.1538	1.2163
8	.9419	.9496	.9953	.9617	.9526	.9663	.8383
9	.8901	.9465	.9907	.9145	.9587	.9572	1.1568
10	.9023	.9236	1.0105	.913	.9617	.9023	.9922
11	.9404	.9511	1.0258	.9602	1.0075	.948	.9297
12	.9922	1.0197	1.0562	.9724	1.0197	.9587	.9892
13	1.0303		1.0486	.9861	1.0486	.9465	1.0273
14	1.0044	1.3032	1.0578	1.0852	1.0639	.9541	1.0456
15	1.0166	1.2696	1.0852	1.0578	1.0623	.98	1.0181
16	1.0197	1.1873	1.1035	1.0608	1.0684	.9556	1.0258
17	.9709	1.1431	1.0425	1.038	1.0181	.9663	1.0623
18	1.0745	1.0852	1.0852	1.0883	1.0791	1.0395	1.1218
19	1.2391	1.3032	1.259	1.3047	1.2529	1.1995	1.3382
20	1.2666	1.3245	1.2925	1.3169	1.2696	1.2269	1.355
21	1.2483	1.3306	1.2864	1.3093	1.2574	1.2422	1.3184
22	1.2071	1.2849	1.2635	1.2498	1.2056	1.2193	1.2696
23	1.1736	1.233	1.2224	1.1812	1.2254	1.1827	1.1995
24	1.1584	1.2315	1.2026	1.1538	1.1645	1.1462	1.1599
Max	1.3596	1.4327	1.4342	1.3169	1.3611	1.3519	1.4403
Min	.8901	.9236	.9907	.913	.9526	.9023	.8383
Avg	1.0628	1.1432	1.1284	1.1009	1.0929	1.0634	1.1144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 164001 / 33/11 KV KAMPTEE(DRAGON

PALACE

Feeder No / Name : 209 / 11 KV YASHODHARA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5266	.5296	.5571	.5998	.6142	.5807	.5075
2	.5152	.5098	.535	.5617	.5952	.5632	.4633
3	.4969	.5014	.5251	.5411	.5898	.5571	.4595
4	.4938	.4923	.5228	.5205	.5898	.554	.4557
5	.4946	.4946	.5418	.5136	.5883	.5472	.4542
6	.5106	.5106	.5639	.5449	.6051	.5677	.4641
7	.5235	.5266	.5091	.5304	.6226	.5601	.4748
8	.4733	.4512	.4893	.4557	.5708	.4954	.4344
9	.4702	.4473	.5106	.4565	.5426	.4664	.5632
10	.4946	.4633	.4946	.522	.567	.4344	.4984
11	.4931	.4976	.4931	.5723	.6135	.4534	.4733
12	.4763	.4915	.5106	.5959	.599	.3849	.4572
13	.4306		.487	.5563	.586	.3742	.4382
14	.4801	.4313	.4763	.5495	.5777	.4504	.4618
15	.4839	.5799	.4999	.5517	.5411	.4176	.4214
16	.4611	.554	.5114	.5731	.57	.3513	.4024
17	.029	.5243	.5426	.5152	.6005	.4184	.4169
18	.3871	.4748	.4976	.5571	.5525	.3841	.4283
19	.4108	.5121	.5868	.5959	.5304	.4976	.49
20		.5502	.6104	.6584	.5449	.5167	.5289
21	.5548	.5441	.5898	.6562	.5525	.5083	.5213
22	.5487	.5563	.583	.6417	.5731	.4923	.5213
23	.538	.5883	.6341	.6485	.6158	.5418	.567
24	.5411	.5746	.6257	.6348	.602	.5472	.5609
Max	.5548	.5883	.6341	.6584	.6226	.5807	.567
Min	.029	.4313	.4763	.4557	.5304	.3513	.4024
Avg	.4710	.5133	.5374	.5647	.5810	.4860	.4777

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 205 / 11 KV AIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4451	.506	.5243	.538	.4801	.5045	.4603
2	.4344	.4588	.5106	.4999	.4771	.4816	.4237
3	.4054	.4237	.4938	.5014	.4588	.4496	.3963
4	.3978	.4085	.4679	.3917	.439	.4329	.3917
5	.378	.3978	.4633	.3917	.4176	.4268	.381
6	.3932	.3948	.4237	.3963	.407	.4298	.3628
7	.4313	.4222	.4512	.3978	.4085	.4496	.3993
8	.4512	.4344	.4252	.4115	.442	.4816	.413
9	.407	.4024	.4252	.4085	.442	.4329	.3932
10	.3993	.4024	.4405	.3963	.4588	.3902	.4207
11	.4024	.4176	.4664	.4237	.4603	.3841	.4344
12	.3597	.4298	.439	.4191	.4359	.3719	.41
13	.3978	.4374	.4359	.4344	.4313	.3536	.4588
14	.3871	.4572	.4847	.4176	.4862	.3704	.4359
15	.3948	.442	.4679	.4252	.4755	.3749	.4009
16	.4191	.4786	.4984	.4496	.4923	.3749	.4344
17	.4603	.4481	.503	.4633	.4588	.3414	.4054
18	.4344	.4207	.4588	.4496	.4237	.3262	.3658
19	.4374	.4512	.442	.4633	.4329	.4237	.474
20	.0472	.4771	.4633	.538	.4908	.4603	.4771
21	.0122	.4832	.474	.4801	.4694	.4374	.4679
22	.5472	.4908	.4877	.5075	.4832	.4451	.4664
23	.5517	.4954	.5228	.5182	.5121	.4832	.4618
24	.5411	.5121	.5411	.5075	.5106	.4938	.4633
Max	.5517	.5121	.5411	.538	.5121	.5045	.4771
Min	.0122	.3948	.4237	.3917	.407	.3262	.3628
Avg	.3973	.4455	.4713	.4513	.4581	.4217	.4249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 206 / 11 KV NCDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3033	.4481	.4976	.6523	.6531	.4992	.4344
2	.2835	.2843	.2964	.2942	.2766	.4923	.3803
3	.2888	.2789	.3018	.2812	.2942	.4588	.2561
4	.2751	.2827	.298	.2812	.269	.3193	.25
5	.2599	.2919	.3003	.2713	.2949	.3201	.2576
6	.2629	.2911	.3003	.2484	.2964	.3307	.2553
7	.2614	.2141	.314	.2942	.298	.5022	.2629
8	.237	.2774	.2835	.2591	.298	.4603	.2332
9	.2035	.1364	.2416	.2218	.381	.0008	.2027
10	.1859		.4016	.3849	.5883	.0907	.1997
11	.1745	.3666	.4207	.3871	.5967	.1623	.2134
12	.3056	.3795	.2728	.2301	.6249	.1517	.2408
13	.4428	.2698	.2675	.2301	.5723	.1699	.2462
14	.41	.2622	.2622	.5716	.2736	.1494	.192
15	.0899	.2439	.2401	.554	.2408	.1448	.2202
16	.1181	.2385	.3003	.2385	.4588	.1654	.1707
17	.093	.2477	.3628	.3003	.4649	.157	.1943
18	.5266	.2241	.6341	.6196	.4725	.1875	.1859
19	.5609	.3109	.631	.6531	.4969	.266	.2606
20	.2942	.4039	.7278	.7049	.5281	.4123	.3948
21	.3224	.3597	.5517	.3658	.5197	.5045	.4184
22	.3216	.3528	.3452	.3521	.3208	.3231	.4679
23	.3094	.3414	.3368	.6135	.4679	.4481	.4672
24	.3254	.3231	.5799	.6737	.5106	.4512	.442
Max	.5609	.4481	.7278	.7049	.6531	.5045	.4679
Min	.0899	.1364	.2401	.2218	.2408	.0008	.1707
Avg	.2857	.2969	.382	.4035	.4249	.2987	.2853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 208 / 11 KV KAMPTEE I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9524	2.0896	2.239	2.1491	2.0759	2.0226	2.0424
2	1.9189	2.053	2.1795	2.1033	1.9403	1.9479	1.8183
3	1.9022	1.9753	2.0637	2.0515	1.9357	1.9494	1.8519
4	1.7604	1.8869	2.0027	2.0774	1.9296	1.8259	1.7711
5	1.797	1.9357	1.9433	2.0195	1.9616	1.9387	1.6949
6	1.9601	2.4249	2.0729	2.7313	2.6764	2.6398	2.1978
7	2.3685	2.5362	1.4175	2.2786	2.3015	2.4585	2.4402
8	2.0332	1.9509	2.0332	1.89	1.9555	1.957	1.832
9	1.8686	1.8595	1.9814	1.864	1.9235	1.864	1.7787
10	1.858	1.8229	2.0058	1.7177	1.9464	1.8275	1.7482
11	1.8945	1.7924	2.0332	1.8275	1.9448	1.7756	1.7253
12	1.9509	1.8153	2.1582	1.893	2.0043	1.7604	1.7391
13	1.9951	1.8793	2.0652	1.9342	2.0835	1.7223	1.8671
14	1.864	1.8839	2.0713	1.925	2.0637	1.7711	1.8168
15	1.8412	1.8519	2.0012	1.9418	2.0043	1.7132	1.8016
16	1.8488	1.9037	2.0271	1.954	2.0332	1.7147	1.797
17	1.8046	1.9936	2.0591	1.9189	2.0104	1.7467	1.8351
18	1.9082	1.922	2.111	2.0134	1.8976	1.8031	1.8503
19	2.0332	2.0713	2.1841	2.2832	2.2253	2.0546	2.1856
20		.9175	2.4158	2.6155	2.2832	2.2268	2.3198
21	.5807	.3384	2.3777	2.5438	2.3533	2.2283	2.3335
22	2.6185	2.6886	2.3579	2.4265	2.2588	2.2893	2.05
23	2.3884	2.5103	2.3914	2.2344	2.1186	2.1491	2.1384
24	2.3061	2.3396	2.3365	2.1171	2.0896	2.0393	2.0942
Max	2.6185	2.6886	2.4158	2.7313	2.6764	2.6398	2.4402
Min	.5807	.3384	1.4175	1.7177	1.8976	1.7132	1.6949
Avg	1.9328	1.9351	2.1054	2.1046	2.0840	1.9761	1.9471

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KAMTEE URBAN SDN[355] BU 1911

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 210 / 11 KV KAMPTEE II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7589	1.9357	1.9448	1.9342	1.8198	1.89	1.797
2	1.7086	1.8275	1.8808	1.8534	1.7497	1.8183	1.7162
3	1.6583	1.7528	1.797	1.8183	1.6918	1.7482	1.7162
4	1.6309	1.7147	1.7833	1.7802	1.6933	1.7421	1.6385
5	1.6263	1.6888	1.797	1.733	1.7025	1.7421	1.6324
6	1.7528	1.7817	1.9342	1.9281	1.9006	1.9204	1.7406
7	2.0241	.9206	.695	2.1247	2.1094	2.175	2.0317
8	2.0485		2.143	1.7772	1.7619	1.8412	1.8656
9	1.7238		1.7711	1.6339	1.6933	1.6187	1.6324
10	1.6827	2.0393	1.7878	1.608	1.7193	1.5912	1.5745
11	1.6903	1.7772	1.7756	1.5973	1.704	1.5104	1.5745
12	1.7223	1.6324	1.7345	1.5516	1.7071	1.4678	1.5165
13	1.7635		1.7208	1.5135	1.6217	1.4952	1.483
14	1.7695	1.8793	1.7071	1.5851	1.6964	1.5013	1.4982
15	1.6141	1.7985	1.5958	1.5623	1.6827	1.4403	1.4967
16	1.4967	1.669	1.6461	1.547	1.6385	1.3839	1.4388
17	1.4342	1.6735	1.6339	1.5242	1.5912	1.3641	1.4358
18	1.4038	1.6141	1.6248	1.5257	1.5242	1.3717	1.4342
19	1.5013	1.6202	1.576	1.6324	1.6171	1.5135	1.5348
20	1.6446	1.7147	1.8351	1.9082	1.8138	1.7208	1.7558
21		1.9875	1.8503	1.9403	1.8397	1.7467	1.8275
22		1.9143	1.832	1.9403	1.8458	1.7802	1.8214
23	1.2879	1.9265	1.8991	1.8671	1.8625	1.8016	1.829
24	1.5485	1.9646	1.9357	1.7711	1.8991	1.8366	1.8183
Max	2.0485	2.0393	2.143	2.1247	2.1094	2.175	2.0317
Min	1.2879	.9206	.695	1.5135	1.5242	1.3641	1.4342
Avg	1.6587	1.7539	1.7459	1.7357	1.7452	1.6676	1.6587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 165001 / 33/11 KV KANHAN W/W

Feeder No / Name : 204 / 11 KV KMT COLLORY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.073	1.0822	1.1134	1.0707	1.0989	1.1035	1.0745
2	1.0867	1.0829	1.1164	1.1073	1.1065	1.1073	1.0844
3	1.0783	1.0799	1.1111	1.1027	1.1058	1.1012	1.0837
4	1.0692	.8048	1.0677	1.1363	1.1408	1.1241	1.086
5	1.0357	.8543	.8383	1.1325	1.1561	1.15	1.1317
6	1.134	1.134	1.1523	1.1408	1.1645	1.1614	1.1462
7	1.1279	1.1309	1.0959	1.1172	1.1538	1.1629	1.1332
8	1.0494	1.0433	1.0715	1.0715	1.1187	1.1218	1.0639
9	1.0303	1.0448	1.0631	1.0517	1.0715	1.0783	.9267
10	1.0235	1.0433	1.0684	1.054	1.0555	1.0494	1.0532
11	1.0075	1.0425	1.0311	1.1058	1.1241	1.0486	1.0479
12	1.0105	1.057	1.009	1.1004	1.1027	1.0151	1.0181
13	1.0486	1.0608	.7926	1.0494	1.0128	.9846	1.0372
14	1.0471	1.0181	.8009	1.0547	.9709	.9457	1.0517
15	1.0486	1.012	.7796	1.0616	1.0753	1.0059	1.0532
16	1.0288	1.0608	.8002	1.0433	1.0334	1.0136	1.0547
17	.9983	1.0639	1.0639	1.0204	1.0547	.9793	1.0014
18	.9518	1.0593	1.0631	1.0463	1.0547	.9823	1.0219
19	1.0334	1.0959	1.0479	1.0921	1.0867	1.086	1.1035
20	1.0982	1.1126	1.1942	1.118	1.0806	1.1157	1.134
21	.9861	1.0768	1.1835	1.1363	1.1294	1.1195	1.1302
22	1.0463	1.0898	1.1873	1.1355	1.1264	1.1134	1.1104
23	1.0509	1.1004	1.1408	1.0829	1.0776	1.0715	1.0829
24	1.0486	1.1256	1.0768	1.0684	1.0722	1.0639	1.0753
Max	1.134	1.134	1.1942	1.1408	1.1645	1.1629	1.1462
Min	.9518	.8048	.7796	1.0204	.9709	.9457	.9267
Avg	1.0464	1.0532	1.0362	1.0875	1.0906	1.0710	1.0711

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 205 / 11 KV KANHAN R

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.282	.301	.3048	.2858	.2972	.2782
2	.2858	.2782	.2934	.3048	.2858	.2934	.2782
3	.282	.2743	.2896	.2362	.282	.2934	.2743
4	.2858	.2705	.2896	.2248	.282	.2896	.2743
5	.2896	.2705	.2934	.2286	.282	.2896	.2743
6	.3315	.301	.3048	.2477	.2858	.2972	.282
7	.3391	.301	.2972	.282	.301	.3239	.3086
8	.2515	.2591	.282	.2591	.2896	.2896	.282
9	.2324	.2629	.2896	.2324	.2705	.2667	.2591
10	.2477	.2743	.2858	.2705	.2667	.2591	.2705
11	.2553	.2705	.2896	.2743	.2896	.2667	.2667
12	.2362	.2362	.282	.2667	.2782	.2286	.2553
13	.2172	.2324	.2743	.2705	.2705	.2248	.2286
14	.221	.2286	.282	.2439	.2629	.1981	.2362
15	.221	.2172	.2743	.1867	.2629	.1753	.2248
16	.2439	.2286	.2439	.1753	.2667	.1829	.1981
17	.2324	.2324	.2439	.1753	.2439	.1867	.1905
18	.1943	.1867	.2286	.16	.221	.1943	.2096
19	.1334	.2362	.2667	.2629	.2591	.2515	.2591
20		.2858	.2934	.3125	.2743	.2743	.2705
21	.2858	.301	.301	.3277	.3125	.2705	.301
22	.3239	.3201	.3353	.3125	.3163	.2972	.301
23	.3125	.3163	.3315	.2972	.3125	.2934	.2705
24	.2934	.3086	.3125	.2934	.301	.2858	.2743
Max	.3391	.3201	.3353	.3277	.3163	.3239	.3086
Min	.1334	.1867	.2286	.16	.221	.1753	.1905
Avg	.2611	.2656	.2869	.2562	.2793	.2596	.2612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

KANHAN S/DN.[360]

BU 0360

Substation No/ Name :- 168012 / 220 KV KANHAN

Feeder No / Name : 206 / 11 KV KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.8192	1.0288	1.0555	.9221	.8116	.644
2	.7278	.8116	1.0059	1.0402	.9069	.8002	.6363
3	.7164	.8116	1.0021	.4382	.8954	.7964	.6325
4	.724	.8192	1.0021	.6554	.8916	.8002	.6287
5	.7583	.8154	1.0021	.6325	.8878	.7926	.6287
6	.8002	.823	1.0098	.6135	.884	.8002	.6249
7	.7545	.7811	.9983	.6173	.8764	.7888	.6249
8	.8192	.6935	.945	.5639	.8078	.7278	.5563
9	.865	.7849	.9526	.6363	.8192	.7164	.5373
10	.9145	.8535	1.0174	.6668	.8154	.602	.5296
11	.8878	.9069	1.0517	.7125	.7849	.5601	.503
12	.9031	.9869	1.0479	.8345	.5716	.5258	.503
13	.9031	.9983	1.0098	.8573	.6783	.4534	.5258
14	.8993	.8383	1.0098	.8497	.7164	.4344	.5144
15	.9069	.8612	1.0402	.8802	.7316	.4153	.5258
16	.8307	.884	1.0402	.8612	.7011	.4077	.5639
17	.8573	.8688	1.0745	.8573	.663	.4077	.5525
18	.8383	.9526	1.086	.8612	.6744	.4344	.5754
19	.3048	1.0021	1.0517	.8726	.7468	.5373	.5868
20		1.044	1.166	1.0021	.8345	.6783	.6973
21	.7926	1.0707	1.1622	1.0059	.8421	.6821	.724
22	.8535	1.0745	1.1241	.9869	.8421	.6973	.7392
23	.8421	1.0783	1.1164	.9107	.8383	.6859	.7278
24	.823	1.044	1.0669	.9221	.8154	.6592	.7011
Max	.9145	1.0783	1.166	1.0555	.9221	.8116	.7392
Min	.3048	.6935	.945	.4382	.5716	.4077	.503
Avg	.8023	.9010	1.0421	.8056	.7978	.6340	.6035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 201 / 11 KV GUMTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.908	.964	.9263	1.2609	1.086	1.3195	1.0562
2	.9103	.908	.9214	1.1786	1.0753	1.3066	1.046
3	.9031	.9008	.9179	.3281	1.0745	1.307	1.0463
4	.9088	.8989	.9164	1.0197	1.0749	1.3096	1.0463
5	.9076	.9027	.9194	1.0075	1.078	1.3009	1.0345
6	.9145	.9069	.9172	1.0056	1.0814	1.2952	1.0231
7	.8909	.9042	.8375	.9846	1.0692	1.2849	.9918
8	.9347	.929	.3467	1.0014	1.0452	1.2018	.9625
9	.9979	1.0738		1.0471	1.1626	1.1515	.9492
10	.9758	1.0753	.9175	1.0924	1.2201	1.0902	.9175
11	1.0094	1.121	1.0589	1.1096	1.2464	1.0543	.8863
12	1.0494	1.1477	1.3272	1.0677	1.2833	1.0269	.7804
13	1.1081	.9194	1.3862	1.1843	1.3287	1.025	.8173
14	1.1164	1.0307	1.4346	1.2056	1.3302	1.0414	.8352
15	1.1412	1.1972	1.4525	1.2136	1.3496	1.0235	.8714
16	1.1747	1.3119	1.4838	1.2323	1.3336	1.038	.908
17	1.206	1.3702	1.2883	1.2007	1.3119	1.0437	.8932
18	1.2007	1.3416	1.3721	1.1938	1.2792	1.0406	.8833
19	1.2087	1.4171	1.459	1.193	1.366	1.0745	.913
20	1.2346	1.4239	1.4422	1.1923	1.3824	1.1168	.9465
21	1.1984	.7868	1.2932	1.1827	1.3645	1.0883	.9625
22	1.2098	.9812	1.3066	1.1477	1.3546	1.0814	.9385
23	1.1915	.9408	1.2997	1.1462	1.3512	1.0791	.945
24	1.1637	.9103	1.267	1.1405	1.3306	1.065	.9286
Max	1.2346	1.4239	1.4838	1.2609	1.3824	1.3195	1.0562
Min	.8909	.7868	.3467	.3281	1.0452	1.0235	.7804
Avg	1.0610	1.0568	1.1518	1.0973	1.2325	1.1402	.9409

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 203 / 11 KV BHUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5463	1.5821	2.1407	2.1117	1.3435	1.5714	1.1157
2	1.5394	1.5242	2.1414	2.1026	1.3413	1.5722	1.1088
3	1.5341	1.5272	2.1392	.3475	1.3283	1.5646	1.1065
4	1.5211	1.5234	2.143	1.5981	1.3375	1.5668	1.1043
5	1.528	1.4952	2.1323	1.5783	1.3298	1.5569	1.0692
6	1.5295	1.4952	2.1087	1.5615	1.3405	1.5524	1.0677
7	1.483	1.5112	2.0957	1.5409	1.3047	1.531	1.0562
8	1.5714	1.5775	1.4586	1.4487	1.3176	1.4434	.9374
9	1.7093	1.6331		1.4495	1.4068	1.3115	.961
10	1.7947	1.6255	.8893	1.4891	1.4982	1.2681	.9892
11	1.7863	1.6621	1.9532	1.4777	1.5264	1.1325	.9572
12	1.9235	1.7558	2.1262	1.5021	1.608	1.1256	.8246
13	1.8961	1.8511	2.0729	1.5295	1.6537	1.012	.9236
14	1.5691	1.7055	2.2001	1.5318	1.6049	.8909	.9191
15	1.6072	1.9928	2.0782	1.6126	.9038	.9122	.9793
16	1.7436	2.0591	1.8229	1.6217	1.4198	.9206	1.0296
17	1.8016	2.1026	2.2222	1.4601	1.4365	.9229	.676
18	1.7848	2.1315	2.2177	1.4068	1.4723	.9755	.9305
19	1.6911	2.0591	2.1293	1.3748	1.48	.9579	.9816
20	1.7863	2.2093	2.2588	1.3535	1.5897	1.0692	1.0783
21	1.7924	2.226	2.2398	1.39	1.5973	1.0959	1.0783
22	1.8176	2.2184	2.2298	1.3931	1.6194	1.1195	1.1058
23	1.8153	2.1994	2.1864	1.3481	1.6126	1.1271	1.1134
24	1.8	2.1643	2.1308	1.3504	1.5958	1.1233	1.1004
Max	1.9235	2.226	2.2588	2.1117	1.6537	1.5722	1.1157
Min	1.483	1.4952	.8893	.3475	.9038	.8909	.676
Avg	1.6905	1.8263	2.0486	1.4825	1.4445	1.2218	1.0089

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 204 / 11 KV BHOWARI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2233	.2157	.2263	.25	.2507	.2759	.205
2	.2126	.2027	.2035	.2187	.192	.2454	.2027
3	.1196	.1981	.1882	.2134	.1677	.1341	.0053
4	.1029	.1021	.1067	.0061	.0472	.0122	.0061
5	.0785	.0457	.0716	.1105	.0633	.0518	
6	.0838	.1257	.1402	.0472	.1318	.0823	
7	.1395	.2149	.208	.1555	.2027	.1654	
8	.2705	.2774	.1943	.2728	.2728	.2225	
9	.2347	.2241		.2256	.2347	.2263	
10	.2515	.2858	.0876	.2759	.2507	.2149	
11	.2873	.3003	.2248	.2561	.2858	.266	
12	.2942	.2599	.2126	.2591	.2949	.282	
13	.301	.2652	.2172	.2538	.3307	.3003	.2538
14	.3064	.2865	.2004	.2332	.2583	.2545	.2896
15	.2362	.2782	.2119	.253	.2469	.2446	.2743
16	.2782	.2896	.1844	.2515	.2416	.2317	.2675
17	.2515	.3178	.1882	.3071	.2812	.3216	.2568
18	.2987	.3102	.1844	.3216	.3079	.349	.3254
19	.2919	.2858	.125	.2934	.208	.3086	.0739
20	.157	.1844	.1143	.0998	.1654	.1905	
21	.1623	.1783	.1402	.093	.157	.1966	
22	.2332	.2843	.1898	.1905	.2004	.1905	.1235
23	.2286	.2713	.2614	.2591	.2202	.253	.2721
24	.2667	.2713	.2583	.2743	.2576	.2416	.2804
Max	.3064	.3178	.2614	.3216	.3307	.349	.3254
Min	.0785	.0457	.0716	.0061	.0472	.0122	.0053
Avg	.2213	.2365	.1800	.2134	.2196	.2192	.2026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 205 / 11 KV SAWALI GARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3963	.5792	.8535	.4572	.3658	.2743
2	.3658	.3963	.5487	.8535	.4268	.3658	.3048
3	.3658	.3658	.5487		.4268	.3658	.3048
4	.3658	.3658	.5487	.3048	.4268	.3658	.2743
5	.3658	.3658	.5487		.4268	.3658	.3048
6	.3658	.3658	.5487		.4268	.3658	.2743
7	.3048	.3353	.5487		.3658	.3353	.2439
8	.3353	.3963		.4877	.3963	.3048	.2134
9	.3658	.4268		.5487	.4268	.2743	.2439
10	.3658	.3963	.5487	.5487	.4268	.2439	.2134
11	.3658	.3658	.7011	.5182	.3353	.2134	.1829
12	.3658		.7926	.5487	.3963	.2134	.1829
13	.3658	.5792	.884	.6097	.4268	.2134	.1829
14	.4268	.6401	.945	.6401	.4268	.1829	.1829
15	.4268	.6706	.945		.3963	.2134	.1524
16	.2743	.6706	.9755	.5487	.4268	.1829	.1829
17	.3963	.5487	.9145	.5792	.3963	.1829	.1524
18	.3963	.5792	.9145	.5182	.3048	.2439	.2134
19	.4268	.5792	.884	.4877	.3658	.3048	.3048
20	.4572	.6097	.9145	.4877	.3963	.3048	.3048
21	.4572	.6097	.884	.5182	.3963	.3048	.3353
22	.4572	.6097	.884	.5182	.3963	.3048	.3048
23	.4268	.5792	.8535	.4877	.3963	.3048	.3048
24	.4268	.5792	.8535	.4572	.3658	.3048	.2743
Max	.4572	.6706	.9755	.8535	.4572	.3658	.3353
Min	.2743	.3353	.5487	.3048	.3048	.1829	.1524
Avg	.3849	.4970	.7621	.5535	.4014	.2845	.2464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164008 / 33 KV GUMTHALA

Feeder No / Name : 207 / 11KV WADODA INDUSTRIAL
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.4412	.5083	.4611	.5624	.4664	.4321
2	.4893	.4374	.5548	.4435	.6203	.4489	.4298
3	.4976	.4428	.5251	.221	.6036	.4473	.4291
4	.4908	.458	.4923	.4405	.4374	.4512	.426
5	.5235	.4618	.4824	.4245	.4382	.4374	.4191
6	.4885	.4412	.4809	.4252	.4374	.4245	.4199
7	.4931	.4481	.474	.4329	.4397	.4298	.4214
8	.5159	.4496	.4451	.4534	.4618	.4146	.4329
9	.7072	.6401	.5647	.6135	.5403	.4283	.6135
10	.8787	.9221	.5891	.9038	.6828	.4123	.663
11	1.2559	1.2727	.7301	1.2132	.8756	.4169	.7301
12	1.307	1.3763	.8581	1.3428	1.3458	.407	.9442
13	1.5234	1.7032	.881	1.3504	1.4693	.4001	1.1645
14	1.4525	1.3931	.7735	1.0761	1.0547	.3902	.6066
15	.9465	1.1957	.6691	1.6888	1.342	.3864	1.3146
16	1.0623	1.4159	.8779	1.7429	1.4121	.3986	1.2292
17	1.5333	1.1347	.9389	1.7154	1.4403	.3902	1.1576
18	1.0166	1.4937	.8581	1.6743	1.3702	.4016	.4885
19	1.5562	1.3253	.7918	1.4243	1.4419	.4321	1.3306
20	1.5661	1.3413	.756	1.8153	1.0387	.4679	1.2155
21	1.0357	1.1706	.6577	1.0829	.6562	.4641	.8962
22	.7164	.9861	.4839	.6965	.5014	.4527	.791
23	.4748	.586	.4832	.6074	.4778	.4405	.4458
24	.4717	.6028	.4687	.5685	.4733	.4374	.4451
Max	1.5661	1.7032	.9389	1.8153	1.4693	.4679	1.3306
Min	.4717	.4374	.4451	.221	.4374	.3864	.4191
Avg	.8989	.9225	.6394	.9508	.8385	.4269	.7269

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 201 / 11 KV BORGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.2193	1.6004	1.7528	1.2955	1.448	.9907
2	1.1431	1.2955	1.6004	1.6004	1.2955	1.3717	.9907
3	1.1431	1.2193	1.6004	1.2955	1.2193	1.2955	.9907
4	1.1431	1.2193	.9145	1.2955	1.2193	1.2193	.9907
5	1.1431	1.2955		1.2193	1.2193	1.2955	.9907
6	1.1431	1.2955		1.2193	1.2955	1.2955	.9907
7	1.1431	1.2193		1.2193	1.2193	1.2955	.9907
8	.9907	1.2193	1.0669	1.2193	1.2193	1.1431	.9145
9	.9907	1.2193	1.448	1.0669	1.2955		.9145
10	1.0669	1.2193	1.5242	1.0669	1.2955		.9145
11		1.2955	1.5242	1.1431	1.2193		.1524
12	.9145	1.2955	1.5242	1.2193	1.2955		.6859
13	1.0669	1.3717	1.5242	1.2955	1.3717	.6097	.6859
14	1.0669	1.448	1.6004	1.2955	1.3717	.9145	.6859
15	.9145	1.448	1.6766	1.3717	1.3717	.9145	.7621
16	.9907	1.448	1.6766	1.2193	1.448	.9145	.8383
17	.9145	1.448	1.6766	1.2955	1.2193	.9145	.8383
18	1.0669	1.448	1.6004	1.2955	1.2955	.9145	.7621
19	1.2193	1.6004	1.829	1.448	1.448	1.0669	.6859
20	1.2955	1.6766	1.829	1.3717	1.5242	1.0669	.6859
21	1.2955	1.6766	1.829	1.448	1.5242	1.0669	.8383
22	1.2955	1.6766	1.829	1.2955	1.5242	1.0669	.8383
23	1.2955	1.6766	1.829	1.2955	1.448	1.0669	.7621
24	1.2955	1.6004	1.7528	1.2955	1.448	.9907	.7621
Max	1.2955	1.6766	1.829	1.7528	1.5242	1.448	.9907
Min	.9145	1.2193	.9145	1.0669	1.2193	.6097	.1524
Avg	1.1166	1.3971	1.5931	1.3019	1.3368	1.0936	.8192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164050 / 33 kV Chirwa

Feeder No / Name : 202 / NEW DHANLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	1.6766	1.7528	1.6004	1.6004	1.3717
2		1.5242	1.6766	1.2955	1.6004	1.6004	1.3717
3		1.5242	1.6766	1.5242	1.6004	1.6004	1.3717
4		1.5242	.9145	1.5242	1.6004	1.6004	1.3717
5		1.6004		1.448	1.6004	1.6004	1.3717
6		1.6766		1.9052	1.6004	1.6766	1.3717
7		1.6766		1.829	1.6004	1.6766	1.3717
8		1.448	1.1431	1.7528	1.5242	1.3717	1.1431
9		1.5242	1.5242	1.7528	1.5242	1.2193	1.0669
10		1.3717	1.3717	1.7528	1.448	1.0669	.9907
11		1.3717	1.2955	1.829	1.2193	.9145	.8383
12	1.1431	1.3717	1.448	1.7528	1.1431	.7621	.6097
13	1.0669	1.448	1.5242	1.448	1.0669	.6859	.6097
14	1.2193	1.3717	1.5242	1.2955	1.0669	.7621	.6097
15	1.2193	1.3717	1.3717	1.3717	1.2193	.7621	.6097
16	1.2193	.9145	1.2955	1.1431	1.3717	.7621	.6859
17	1.2193	.9907	1.2955	1.2955	1.1431	.9145	.7621
18	1.2193	.9907	1.5242	1.2193	1.3717	1.1431	.9145
19	1.7528	1.448	1.9052	1.829	1.7528	1.448	1.3717
20	1.829	1.9052	1.9814	1.9814	1.829	1.6004	1.5242
21	1.829	1.9052	2.0576	1.6766	1.9052	1.6004	1.5242
22	1.829	1.829	1.9052	1.6766	1.829	1.5242	1.5242
23	1.6766	1.7528	1.829	1.6766	1.7528	1.448	1.448
24	1.6004	1.6766	1.7528	1.6004	1.6766	1.3717	1.3717
Max	1.829	1.9052	2.0576	1.9814	1.9052	1.6766	1.5242
Min	1.0669	.9145	.9145	1.1431	1.0669	.6859	.6097
Avg	1.4479	1.4892	1.5568	1.5972	1.5019	1.2797	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 201 / 11 KV MOUDA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7718	1.909	2.1567	2.1834	1.9395	1.9966	1.2536
2	1.7337	1.8557	2.0995	2.1033	1.8671	1.9624	1.2041
3	1.7032	1.8099	2.0462	1.2346	1.8099	1.9319	1.1431
4	1.6842	1.7909	2.0386	1.8938	1.8061	1.9204	1.0898
5	1.7071	1.8138	2.0576	1.8328	1.8252	1.9433	1.0936
6	1.7337	1.8595	2.0805	1.8442	1.8366	1.9738	1.1279
7	1.7871	1.9243	2.0576	1.848	1.8976	1.9814	1.2384
8	1.8138	1.9433	2.0195	1.8709	1.9052	1.044	1.2727
9	1.5661	1.7375	1.8252	1.669	1.7947	1.0707	1.0707
10	1.5127	1.7032	1.9014	1.6766	1.6918	.2972	1.0212
11	1.5203	1.8176	1.9243	1.7528	1.7299	1.1965	.9755
12	1.6766	1.9166	2.0805	1.8785	1.8785	1.2765	1.0288
13	1.7223	1.9738	2.1567	1.9738	1.89	1.3375	1.0288
14	1.7833	2.0157	2.2253	2.0157	1.8976	1.3756	1.0364
15	1.8138	2.0195	2.2939	2.0767	1.9738	1.3451	1.0364
16	1.7718	2.0881	2.2443	2.0957	1.9547	1.3717	1.0593
17	1.7642	2.1072	2.1529	2.0386	1.8633	1.3794	1.0021
18	1.5242	2.111	2.1033	1.829	1.7414	1.3908	1.0326
19	1.7185	1.9966	2.2977	1.9243	1.9776	1.2231	1.2689
20	2.0881	2.332	2.633	2.4463	2.2596	1.4098	1.3603
21	2.1643	2.3777	2.6139	2.4387	2.2672	1.4289	1.3756
22	2.1757	2.3891	2.5606	1.2765	2.271	1.4251	1.3946
23	2.1186	2.3701	2.4653	.3658	2.2138	1.4022	1.3413
24	2.0195	2.2634	2.3282	2.0386	2.1224	1.3336	1.246
Max	2.1757	2.3891	2.633	2.4463	2.271	1.9966	1.3946
Min	1.5127	1.7032	1.8252	.3658	1.6918	.2972	.9755
Avg	1.7864	2.0052	2.1818	1.8462	1.9339	1.4591	1.1542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 202 / 11 KV WADODA IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2536	1.2765	1.2384	1.1088	1.1507	1.2117	.8497
2	1.1317	1.2727	1.1888	1.086	1.1431	1.2155	.8307
3	1.1774	1.2536	1.2574		1.0822	1.1965	.8307
4	1.1812	1.1927	1.1927	.2286	1.0745	1.1812	.8726
5	1.0669	1.2346	1.1927	.823	1.0936	1.1507	.8802
6	1.1622	1.2689	1.1622	.8764	1.1736	1.1203	.8916
7	1.1164	1.2155	1.1317	.8726	1.1355	1.1469	.884
8	1.0326	1.1279	1.1012	.8916	1.0974	1.0098	.8535
9	1.0631	1.2422	1.044	.9374	1.1584	.8573	.9183
10	1.2727	1.5546	1.2651	1.105	1.4594	.9602	1.0288
11	1.3756	1.5889	1.3222	1.2231	1.4632	1.0326	1.105
12	1.4899	1.4861	1.3184	1.1431	1.5508	.9602	1.1774
13	1.6232	1.4441	1.025	1.3946	1.5203	.9526	1.0631
14	1.5851	.3239	.9831	1.3032	1.5203	.9259	1.1279
15	.9297	1.5508	1.2155	1.1164	1.5242	.8421	1.1774
16	1.5051	1.5851	1.2117	1.1584	1.4937	.5563	1.2231
17	1.2498	1.5165	1.2308	1.1812	1.5966	.6325	1.1584
18	1.3298	1.4937	1.0059	1.1279	1.5089	.6249	1.1622
19	1.5318	1.2689	1.0517	1.2384	1.3451	.7316	1.1812
20	1.4784	1.3832	1.1241	1.326	1.406	.804	1.2727
21	1.3832	1.3527	1.1164	1.2612	1.3565	.8459	1.166
22	1.387	1.307	1.166	1.1126	1.2765	.9145	1.1279
23	1.3603	1.3146	1.1812	1.1507	1.2612	.9488	1.1431
24	1.2536	1.2765	1.0593	1.1241	1.2727	.9069	1.1507
Max	1.6232	1.5889	1.3222	1.3946	1.5966	1.2155	1.2727
Min	.9297	.3239	.9831	.2286	1.0745	.5563	.8307
Avg	1.2892	1.3138	1.1577	1.0778	1.3194	.9470	1.0448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 204 / 11 KV TARSA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5623	1.7071	1.669	1.1888	1.1888	1.025
2	1.4365	1.5432	1.6918	1.6537	1.1812	1.1774	1.0136
3	1.4251	1.5356	1.688	.2172	1.1698	1.166	1.0059
4	1.4213	1.5318	1.6804		.804	1.1622	1.0059
5	1.4175	1.5394	1.6842		1.1888	1.166	1.0059
6	1.5127	1.5585	1.6918		1.1927	1.1736	1.0136
7	1.89	1.5242	1.6575		1.1698	1.1888	.9983
8	1.5927	1.3146	1.5775		1.044	1.0517	.8954
9	1.7528	1.7528	1.7718		1.2155	.9069	.7468
10	1.8785	1.8214	2.0805		1.2422	.8383	.6973
11	1.9433	2.0729	2.1681		1.4327	.7621	.221
12	1.9243	2.0729	2.1643		1.4518	.804	
13	1.4708	2.13	2.0462		1.4518	.823	
14	1.5356	2.1491	2.21	.0114	1.547	.7392	.0152
15	1.7109	2.191	2.2215	.7049	1.5737	.7849	.7087
16	1.6118	2.0919	2.1948	1.5356	.0152	.7888	.8078
17	1.6804	2.1338	2.1529	.0305	.0419	.6897	.945
18	1.6042	2.1567	1.8709	.1143	.2439	.7888	.9488
19	1.627	2.069	1.9319	.3163	1.3032	1.0174	.9755
20	1.8633	2.412	1.9624	1.669	1.4822	1.2079	1.1888
21	2.2215	2.4844	1.7909	1.6461	1.4975	1.2269	1.2422
22	2.2253	1.8366	1.7909	.9907	1.4251	1.2384	1.2079
23	1.8138	1.8214	1.7871	1.2308	1.2536	1.0822	1.1012
24	1.6042	1.7528	1.7185	1.2193	1.2117	1.044	1.0555
Max	2.2253	2.4844	2.2215	1.669	1.5737	1.2384	1.2422
Min	1.4175	1.3146	1.5775	.0114	.0152	.6897	.0152
Avg	1.6921	1.8774	1.8850	.9292	1.1387	1.0007	.9012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164060 / 33 KV DCL S/STN

Feeder No / Name : 206 / 11 KV BAPDEO SUGAR FACTORY NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.08	
2				.08	
3				.08	
4				.08	
5				.08	
6				.08	
7				.08	
8				.0343	
9				.0229	
10		.0724		.0191	
11	.0419	.0724	.0457		
12	.0381	.0229	.0114		
13		.0038			
16				.0038	
17					.0038
18		.0305	.0229		
19			.0724		
20			.08		
21			.08		
22			.0838		
23			.0838		
24			.08		
Max	.0419	.0724	.0838	.08	.0038
Min	.0381	.0038	.0114	.0038	.0038
Avg	.04	.0404	.0622	.0582	.0038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164070 / 33 KV HALDIRAM AT GUMTHALA

Feeder No / Name : 202 / 11 KOMAL FDR

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.5799	.5068	.5197	.5296	.5274	.5586
2	.5868	.5617	.4938	.506	.5312	.5296	.5563
3	.5975	.5677	.4207	.4877	.4588	.5266	.5594
4	.5898	.5982	.458	.5045	.49	.538	.5434
5	.5586	.5792	.426	.4938	.5418	.5205	.4534
6	.5411	.567	.3986	.4832	.5235	.4275	.4435
7	.49	.5754	.4146	.4336	.4733	.4336	.5197
8	.5578	.5609	.4283	.4649	.5327	.5479	.5617
9	.6028	.5868	.3909	.5258	.5769	.6097	.6043
10	.5243	.6188	.3323	.4915	.5601	.6447	.5281
11	.5022	.5464	.3361	.4969	.5754	.5487	.5228
12	.5738	.4809	.3498	.3475	.5449	.5098	.3475
13	.442	.4313	.3681	.2804	.4451	.5327	.301
14	.4847	.4938	.3506	.3628	.5967	.6523	.3879
15	.5921	.519	.2949	.4451	.5472	.628	.4595
16	.5921	.5365	.2622	.5982	.6158	.6424	.5723
17	.5609	.6668	.2553	.5738	.6653	.5121	.6394
18	.5769	.6874	.234	.663	.6889	.5213	.6302
19	.5312	.6744	.1768	.6234	.5982	.538	.583
20	.5937	.4999	.2507	.583	.5312	.5235	.57
21	.6089	.4847	.3041	.5754	.5388	.5601	.5761
22	.5998	.5121	.362	.4969	.5365	.5815	.5777
23	.6112	.4992	.5045	.535	.487	.5723	.5556
24	.5807	.5068	.5083	.5319	.5228	.5716	.5662
Max	.6112	.6874	.5083	.663	.6889	.6523	.6394
Min	.442	.4313	.1768	.2804	.4451	.4275	.301
Avg	.5620	.5556	.3678	.501	.5463	.5500	.5257

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164070 / 33 KV HALDIRAM AT GUMTHALA

Feeder No / Name : 203 / 11 KV FROGEN FDR

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.3757	.3117	.1913	.3201	.1905	.3086
2	.3323	.2987	.1981	.1867	.2172	.1768	.2218
3	.189	.2141	.1913	.1699	.2202	.1707	.2187
4	.208	.2241	.2012	.1882	.2301	.1829	.2462
5	.2157	.2202	.2119	.1837	.218	.1844	.25
6	.2622	.2858	.2683	.2614	.2812	.2721	.3064
7	.439	.458	.4153	.4092	.4351	.4382	.4572
8	.6158	.6394	.4908	.5167	.5617	.66	.5388
9	.6028	.6264	.5045	.4733	.4618	.7651	.6455
10	.4085	.4565	.3902	.487	.4763	.6592	.4832
11	.413	.4405	.3513	.3666	.5106	.6729	.5746
12	.4702	.5365	.4504	.3384	.599	.5655	.4527
13	.4458	.5487	.5853	.4801	.7179	.7667	.602
14	.4138	.5639	.5639	.5525	.8772	.7994	.6539
15	.5761	.5815	.5594	.6935	.7537	.7087	.602
16	.7583	.6295	.5563	.8238	.7011	.7537	.7987
17	.6965	.8269	.5754	.7514	.8352	.7468	.82
18	.7301	.8474	.583	.6257	.8467	.6615	.8169
19	.7049	.6744	.3559	.6531	.724	.5929	.6051
20	.583	.6325	.3567	.583	.4839	.4184	.5106
21	.4359	.4527	.4298	.4694	.3224	.3307	.2774
22	.3757	.3544	.4237	.3323	.2705	.3795	.2743
23	.3909	.3932	.2942	.3376	.3338	.3292	.3871
24	.4199	.3742	.2462	.3361	.3338	.3292	.3231
Max	.7583	.8474	.5853	.8238	.8772	.7994	.82
Min	.189	.2141	.1913	.1699	.2172	.1707	.2187
Avg	.4615	.4856	.3965	.4338	.4888	.4898	.4740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164070 / 33 KV HALDIRAM AT GUMTHALA

Feeder No / Name : 204 / 11 KV KASANA FDR

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9084	.9518	.8192	.8368	.9671	.9625	.9877
2	.8878	.916	.7499	.8627	.9534	.9442	.9724
3	.8924	.9175	.7506	.4428	.9389	.9404	.98
4	.8642	.9145	.695	.8848	.9541	.8977	.9838
5	.8794	.9038	.6333	.9389	.9717	.8566	.9617
6	.9297	.9328	.5578	.9198	1.0044	1.0044	.9869
7	.8939	.9427	.3856	.8817	.8954	1.0883	.9648
8	.9	.9031	.2995	.6828	.8909	1.121	.9511
9	.9694	.8543	.2256	.4672	.6805	1.1134	.977
10	.4809	.8078	.4954	.2614	.5708	1.1073	.6211
11	.9214	.3567	.4755	.2797	.5136	.9442	.6958
12	.647	.4672	.4275	.2202	.7148	.8246	.4214
13	.3605	.3643	.4329	.2141	.5548	.8581	.4733
14	.2324	.4451	.5502	.2568	.9892	.9518	.5068
15	.4923	.2949	.3361	.6287	.8543	.8497	.4214
16	.7506	.5815	.3003	1.044	.881	.8932	.9099
17	1.0524	.7987	.1791	.9793	1.0501	1.0014	1.1347
18	1.1187	.9084	.2972	.8124	1.0791	1.0578	1.1446
19	1.0021	.9122	.3216	1.0501	1.0601	.9907	1.1096
20	.9343	.8451	.3193	.9846	.9244	.9076	1.0082
21	.9427	.8756	.3544	.9435	.9503	.9869	1.0128
22	.9998	.8482	.5784	.9358	.9663	.9968	1.0014
23	.9953	.8627	.7491	.948	.9602	.9793	1.0113
24	.9953	.8406	.8322	.9617	.9595	.9823	.9938
Max	1.1187	.9518	.8322	1.0501	1.0791	1.121	1.1446
Min	.2324	.2949	.1791	.2141	.5136	.8246	.4214
Avg	.8355	.7686	.4902	.7266	.8869	.9692	.8846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164070 / 33 KV HALDIRAM AT GUMTHALA

Feeder No / Name : 205 / 11 KV SIMPLE & CENTRAL FDR NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2408	.2515	.2614	.1997	.2545	.2667	.2797
2	.2347	.2378	.2423	.2027	.2446	.2301	.2248
3	.2286	.2263	.2416	.1974	.2507	.234	.1989
4	.2233	.2301	.2446	.2004	.2416	.2271	.2096
5	.253	.2286	.2462	.1852	.2301	.2225	.2088
6	.2522	.2454	.2553	.1974	.2416	.2279	.2126
7	.2576	.2766	.2256	.2004	.2423	.2202	.2088
8	.2827	.2736	.2865	.218	.2698	.2904	.2667
9	.301	.2812	.3307	.2865	.3262	.3041	.3246
10	.3163	.333	.3826	.3018	.3483	.3353	.3384
11	.3856	.3749	.4458	.3513	.4191	.3749	.4321
12	.3757	.4428	.4428	.3765	.4252	.4268	.4306
13	.41	.4382	.439	.362	.4001	.4245	.4252
14	.4062	.4405	.3826	.41	.4138	.4428	.4161
15	.3955	.4367	.3856	.4496	.413	.4435	.4321
16	.3986	.4138	.4351	.4435	.4275	.4009	.4138
17	.4359	.4473	.442	.4618	.439	.3833	.3887
18	.4451	.4534	.4572	.3818	.4451	.4405	.4428
19	.458	.4412	.458	.4679	.4572	.458	.4557
20	.5091	.4489	.4618	.4702	.4489	.4572	.4694
21	.4954	.4443	.4908	.4611	.471	.4992	.4694
22	.3772	.4801	.4039	.4557	.4748	.455	.4435
23	.3445	.3757	.3414	.3765	.3406	.3772	.3391
24	.2995	.317	.3033	.2942	.3094	.3688	.2858
Max	.5091	.4801	.4908	.4702	.4748	.4992	.4694
Min	.2233	.2263	.2256	.1852	.2301	.2202	.1989
Avg	.3469	.3558	.3586	.3313	.3556	.3546	.3466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

MOUDA S/DN.[359]

BU 0359

Substation No/ Name :- 164070 / 33 KV HALDIRAM AT GUMTHALA

Feeder No / Name : 206 / 11 KV HARIOMKAR FDR

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3635	.3871	.3894	.2698	.2789	.3094	.3506
2	.362	.3772	.3757	.2637	.2698	.3193	.3346
3	.3391	.3567	.3483	.2736	.2896	.33	.3452
4	.3193	.3483	.3346	.2599	.2728	.3178	.3353
5	.3155	.3224	.3056	.2896	.3025	.3414	.3109
6	.333	.3338	.2949	.2774	.285	.3353	.2949
7	.3574	.3925	.3795	.2637	.2934	.4237	.2987
8	.5639	.5868	.5914	.4633	.4992	.5022	.4854
9	.6409	.631	.6401	.5121	.6203	.5761	.5723
10	.6333	.663	.66	.567	.6165	.612	.5723
11	.7004	.6996	.6394	.567	.6089	.612	.6272
12	.7194	.6699	.6478	.6074	.6005	.6211	.5838
13	.6546	.6569	.6081	.628	.6097	.5914	.554
14	.6744	.6783	.5784	.6676	.6264	.6219	.5525
15	.6615	.6493	.487	.7148	.6287	.6668	.6005
16	.6798	.647	.3986	.708	.6302	.6219	.6394
17	.6683	.66	.2804	.7004	.6318	.5761	.6455
18	.647	.6424	.266	.5022	.6196	.4092	.6272
19	.5479	.5274	.2675	.4572	.5563	.2865	.5548
20	.4054	.4146	.2759	.314	.3925	.3254	.346
21	.3879	.4001	.2736	.3048	.3521	.3368	.3346
22	.394	.4207	.2812	.2736	.3673	.349	.3582
23	.3955	.4047	.2705	.2911	.3513	.3338	.3536
24	.3894	.3909	.2705	.2804	.314	.3498	.3856
Max	.7194	.6996	.66	.7148	.6318	.6668	.6455
Min	.3155	.3224	.266	.2599	.2698	.2865	.2949
Avg	.5064	.5109	.4110	.4357	.4591	.4487	.4610

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164002 / 33 KV NAGARDHAN

Feeder No / Name : 201 / 11 kV Chacher

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0166	.0166	.0168	.0166	.0165	.0163
2		.0167	.0166		.0166	.0167	.0161
3		.0167	.0171		.0166	.0166	.0161
4		.0167	.0171		.0167	.0165	.0159
5		.0164	.0168		.0169	.0165	.016
6		.0163	.0162		.0169	.0166	.016
7		.016	.0163		.0166	.0124	.0161
8		.0159	.0164		.0165	.016	.0141
9		.0164	.0162		.0166	.0159	.0161
10	.3048	.0161	.0168	.0088	.0165	.0158	.0151
11	1.0669	.0157	.0169	.0175	.0166	.0163	.0163
12	1.1431	.0164	.0166	.0175	.0164	.0161	.0163
13	1.2955	.0163	.0167	.0175	.0164	.0161	.0161
14	1.2193	.0164	.0167	.0177	.0164	.0159	.0159
15	1.2193	.0164	.0166	.0167	.0165	.0158	.0162
16	1.1431	.0163	.0166	.0171	.0164	.0159	.0164
17	1.1431	.0163	.0165	.0169	.0164	.0151	.0163
18	1.2193	.016	.0159	.0165	.0164	.0159	.0161
19		.0169	.0163	.0169	.017	.0168	.0165
20		.0168	.0171	.0169	.0169	.017	.0163
21		.0169	.0168	.0166	.0168	.0165	.0164
22		.0168	.0169	.0166	.0166	.0164	.0164
23		.0165		.0167	.0166	.0166	.0165
24		.0164	.0167	.0167	.0165	.0164	.0164
Max	1.2955	.0169	.0171	.0177	.017	.017	.0165
Min	.3048	.0157	.0159	.0088	.0164	.0124	.0141
Avg	1.0838	.0164	.0166	.0165	.0166	.0161	.0161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 201 / 11 KV AROLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	2.5652	1.105	3.2525	2.995	1.105	1.374
2	.9907	2.4768	1.0669	2.8944	2.5705	1.105	1.3535
3	.9907	2.4372	1.0669	2.5736	2.601	1.0669	1.3466
4	.9526	2.4608	1.0669	2.569	2.5621	1.0669	1.3413
5	.9526	2.4669	1.0288	2.5423	2.5507	1.0669	1.3748
6	.9526	2.5035	.9526	2.521	2.4966	1.0669	1.3977
7	.6478	2.5179	.6859	2.3541	2.4166	.7621	1.3778
8	.4954	2.6452	.4954	2.4158	2.6528	.6097	1.3512
9	.4954	2.6848	.5335	2.5286	2.4837	.5716	1.2757
10	.4954	2.5644	.5335	2.5789	2.3267	.4572	1.2978
11	.4954	2.1947	.5335	2.3365	2.6452	.5335	1.2117
12	.4954	2.2344	.6478	2.223	2.5515	.5335	1.2734
13	.4191	2.1208	.4954	1.7436	2.4288	.4954	1.3649
14	.4954	2.2557	.6097	2.0234	2.4273	.5335	1.438
15	.4954	2.2397	.6478	1.925	2.3899	.4954	1.4083
16	.5716	2.1376	.6859	1.8716	2.1307	.5716	1.3953
17	.5716	2.2755	.6859	1.8267	2.1368	.4954	1.3908
18	.5335	2.1864	.4191	2.0164	2.2352	.4191	1.842
19	.8002	2.8471	.8764	2.9317	2.8159	.9526	2.2055
20	.8764	3.1215	.9907	3.0925	2.9736	.9907	2.1765
21	.9526	3.1131	1.105	2.1094	3.046	1.0288	2.2519
22	1.0669	3.1535	1.2193	2.9477	3.1809	1.105	2.2573
23	1.0288	3.0818	1.1812	3.0056	3.0895	1.0669	2.21
24	1.0288	2.9873	1.1431	2.9858	2.8624	1.0288	2.1917
Max	1.0669	3.1535	1.2193	3.2525	3.1809	1.105	2.2573
Min	.4191	2.1208	.4191	1.7436	2.1307	.4191	1.2117
Avg	.7415	2.5530	.8240	2.4695	2.6071	.7970	1.5878

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 202 / 11 KV GHOTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17
HR	Load (MW)
1	1.0669
2	1.105
3	1.0669
4	1.0669
5	1.0669
6	1.0288
7	1.0288
8	1.1431
9	1.2955
10	1.1812
11	.8002
12	.8383
13	.8764
14	.8764
15	.9526
16	.9145
17	.9145
18	1.1431
19	1.4861
20	1.829
21	1.9433
22	1.9814
23	1.8671
24	1.7147
Max	1.9814
Min	.8002
Avg	1.2162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 206 / 11 KV YAWALKAR
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0381		.0953	.0191			
12	.0572	.0381	.1334	.0191	.0762		.0381
13	.0762	.1143	.1334	.0381	.0572	.0191	.0953
14	.0762	.1143	.0953	.0191	.0381	.0953	.0191
15	.0953	.1143	.0381	.0381		.0953	.0191
16	.0762	.0762	.0191	.0381		.0953	.0191
17	.0381	.0762	.0191	.0381		.0953	.0191
18	.0381	.0762	.0191	.0953		.0953	.0381
19	.0381			.0762			
Max	.0953	.1143	.1334	.0953	.0762	.0953	.0953
Min	.0381	.0381	.0191	.0191	.0381	.0191	.0191
Avg	.0593	.0871	.0691	.0424	.0572	.0826	.0354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356] BU 0356

Substation No/ Name :- 164030 / 33 KV AROLI

Feeder No / Name : 207 / 11 KV DURGA RICE MILL NON SHEDDABLE EXPRESS HV FEEDERS
 EXPRESS Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.0191
7					.0191
8					.0191
9					.0191
10	.0191				.0191
11	.0191		.0381	.0381	.0191
12	.0191		.0381	.0572	.0191
13	.0191	.0191	.0191	.0762	.0191
14	.0191	.0381	.0381	.0572	.0191
15		.0381	.0762	.1143	.0191
16		.0381	.0762	.1143	.0191
17		.0381	.0762	.1143	.0191
18		.0191	.0572	.1143	.0191
19		.0191		.0572	
20				.0191	
Max	.0191	.0381	.0762	.1143	.0191
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0300	.0524	.0762	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

MOUDA DIVISION[658]

RAMTEKE S/DN.[356]

BU 0356

Substation No/ Name :- 164058 / 33/11 KV S/stn Mansar

Feeder No / Name : 205 / 11 KV MANSAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7697	.7621	.7926	.8688	.6325	.3963	1.8519
2	.7773	.7468	.7773	.8688	.6173	.7468	1.8061
3	.7697	.7468	.7773	.7392	.6173	.7545	1.768
4	.724	.7392	.7773	.6859	.6097	.7468	1.7604
5	.7087	.6935	.7697	.7164	.6097	.7468	1.7528
6	.7468	.7087	.7849	.724	.6097	.7773	1.8442
7	.7164	.6706	.7926	.724	.602	.7773	1.8519
8	.6554	.7087	.7849	.7164	.5716	.6935	1.547
9	.6859	.7849	.8154	.7849	.6325	.6097	1.547
10	.6478	.7468	.7926	.7621	.6706	.6401	1.326
11	.5868	.724	.8612	.7773	.6097	1.3184	1.1431
12	.5487	.6935	.9678	.7468	.6859	1.4098	1.6004
13	.5258	.5868	.9983	.7849	.6173	1.3641	.884
14	.5258	.6249	.9678	.7926	.7011	.9374	1.2498
15	.4954	.6554	.9602	.8154	.7087	.9069	1.2041
16	.5335	.6706	.9678	.7468	.2439	1.2651	.8916
17	.5182	.7164	.8993	.6325	.381	1.3108	1.2803
18	.5716	.6783	.6859	.6783	.5944	1.5318	1.3413
19	.6401	.8307	.884	.9069	.7468	2.0729	1.9204
20	.823	.8612	.9297	.9526	.7621	2.1719	2.0729
21	.8154	.8612	.8993	.9145	.7468	2.1719	2.0881
22	.8307	.8535	.9069	.0229	.7773	2.1643	2.0576
23	.8154	.8383	.9069	.5335	.7697	2.0729	1.989
24	.7773	.8002	.8764	.6401	.7011	1.829	1.89
Max	.8307	.8612	.9983	.9526	.7773	2.1719	2.0881
Min	.4954	.5868	.6859	.0229	.2439	.3963	.884
Avg	.6754	.7376	.8573	.7307	.6341	1.2257	1.6112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 202 / 11 KV NAXI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.1934	1.1919	
2					1.6545	1.6537	
3					1.6392	1.6339	
4					1.6301	1.6293	
5					1.6225	1.6286	
6					1.5714	1.5927	
7					1.4662	1.4822	
8				.0701	1.5958	1.5074	
9		.3125	1.0745	1.1012	1.6789	1.4906	1.1248
10	1.0189	1.0997	1.7078	1.0075			1.2681
11	1.0311	1.2292	1.9037	1.0966			1.2719
12	1.0966	1.3458	2.018	1.1203			1.291
13	1.1439	1.3672	2.0378	1.4861			1.3032
14	1.182	1.371	2.0751	1.5333			1.2757
15	1.1881	1.5714	2.0721	1.6263			1.243
16	1.1881	1.4891	1.9425	1.5851			1.2711
17	.6752	1.5318	1.9258	1.2087			1.2704
18	.5197						
Max	1.1881	1.5714	2.0751	1.6263	1.6789	1.6537	1.3032
Min	.5197	.3125	1.0745	.0701	1.1934	1.1919	1.1248
Avg	1.0048	1.2575	1.8619	1.1835	1.5613	1.5345	1.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164007 / 33KV BHIWAPUR

Feeder No / Name : 205 / 11 KV BHIWAPUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2					.2286	.2286	
3					.2286	.2286	
4			.0381	.3429	.2286	.2286	
5		.0381	.0381	.3429	.2286	.2286	
6			.0381	.3429	.2286	.2286	
7			.0381	.3429	.2286	.2286	
8				.3429	.2667	.2286	
9				.3048	.2667	.2667	.0381
10	.1524	.1905	.3048				
11	.1905	.1905	.3429				
12	.1905	.2286	.381				
13	.2286	.2667	.1524				
14	.2286	.2667	.1905				
15	.2286	.2667	.3429				
16	.2286	.3429	.381				
17	.2286	.3429	.381				
18	.1905	.0381					
20							.1905
21							.2286
22							.2286
23							.2286
24							.2286
Max	.2286	.3429	.381	.3429	.2667	.2667	.2286
Min	.1524	.0381	.0381	.3048	.2286	.2286	.0381
Avg	.2074	.2172	.2191	.3366	.2381	.2334	.1905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 164043 / JAWALI

Feeder No / Name : 201 / JAWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1219					
2	.0914	.1219					
3	.0914	.1219	.1524				.1524
4	.0914	.1219	.1524				.1524
5	.0914	.1219	.1524				.1524
6	.0914	.1219	.1524				.1219
7	.0914	.1219	.1524				.1219
8	.0914	.1524	.1829				.0914
9	.1219	.1829	.1829				.0914
10	.1219	.1829	.1219	.1219			.061
11				.0914	.2439	.1829	
12				.0914	.2439	.2134	
13				.1219	.2439	.2134	
14				.1219	.2439	.2134	
15				.1524	.2439		
16					.2439		
17					.1829		
18				.1219	.0914	.061	
Max	.1219	.1829	.1829	.1524	.2439	.2134	.1524
Min	.0914	.1219	.1219	.0914	.0914	.061	.061
Avg	.0975	.1372	.1562	.1175	.2172	.1768	.1181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

BHIVAPURA S/DN.[358] BU 0358

Substation No/ Name :- 165002 / 33KV UMRED

Feeder No / Name : 204 / 11 kV Mangrulsirsi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9069	.807	.993	1.182	1.1698	1.1454	1.1043
2	.8985	.8916	1.1119	.2286	1.1584	1.1325	.8215
3	.8383	1.0021	1.185		1.1492	1.1248	.6493
4	.8566	.8535	1.1736		1.1477	1.118	.5746
5	.7849	.8833	1.0738		1.1523	1.1142	.7118
6	.8535	.9701	1.1622		1.1378	1.0951	.7133
7	.865	.9328	1.2155		.8756	.8733	.6424
8	.9114	.9694	1.3466	.5289	.6455	.5456	.6828
9	1.0174	1.1934	1.1881	.7689	.6203	.6234	.6859
10	.9656	1.1195	1.2346	.6988	.7979	.7019	.3673
11	.4908	.5243	.6485	.7293	.9724	.8238	.0335
12	.6866	.5495	.6325	.7453	1.2391	.8573	.4679
13	.7103	.5815	.6554	.6379	1.3375	.833	.487
14	.8238	.6074	.6638	.5304	1.3123	.8612	.4832
15	.7903	.413	.6661	.8817	1.2209	.8421	.4908
16	.7888	.6272	.6737	.9206	1.185	.7499	.5197
17	.4603	.6173	.6264	.8947	1.054	.7842	.5243
18	.5944	.5738	.6226	.8261	.8627	.6516	.6851
19	.9823	1.07	1.1332	1.0334	1.1302	1.0288	.9762
20	1.2071	1.2574	1.3161	1.2574	1.2483	1.1858	1.0966
21	1.2872	1.3306	1.3656	1.2841	1.3016	1.246	1.1797
22	1.2887	1.323	1.3656	1.3154	1.2841	1.2635	1.1797
23	1.2071	1.2551	1.2833	1.2772	1.2376	1.1523	1.1233
24	1.1325	1.1645	1.2041	1.1774	1.1622	1.1203	1.0761
Max	1.2887	1.3306	1.3656	1.3154	1.3375	1.2635	1.1797
Min	.4603	.413	.6226	.2286	.6203	.5456	.0335
Avg	.8895	.8966	1.0226	.8904	1.1001	.9531	.7198

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 202 / 11 KV CHAFEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8093	.9435	1.121	1.1767	.8947	.8147	.711
2	.8048	.9419	1.1157	1.1904	.884	.8139	.7019
3	.8032	.9366	1.1035		.8787	.8093	.6958
4	.7987	.9389	1.1073		.8772	.807	.6996
5	.7933	.9335	1.0974		.8665	.7987	.6813
6	.7621	.9396	1.0928		.8612	.804	.6798
7	.7179	.9069	1.054		.8368	.7918	.6539
8	.7727	.9747	1.1515		.7682		.5914
9	.823	1.0014	1.2292		.5319		.5937
10	.8413	.9816	1.1233		.3757		.5891
11	.6074	.6302	.6897		.455		.4969
12	.5266		.6691		.692	.0107	.5098
13	.5213		.6706		.7453		.4725
14	.5456		.6935		.7758		.5007
15	.5632		.6981		.7971	.3422	.5167
16	.5159		.6706	.7948	.7537	.3544	.5456
17	.5007		.6097	.8253	.7064	.4976	.5685
18	.5548	.4862	.6371	.7613	.7133	.5685	.5533
19	.9701	1.0311	1.0959	.993	1.0433	.6897	.9617
20	1.249	1.2125	1.2033	1.0623	1.185	.7552	1.1332
21	1.0296	1.2239	1.2361	1.0143	.8794	.7796	1.2765
22	1.0204	1.2338	1.2681	1.0014	.8855	.7834	1.3161
23	1.0014	1.1995	1.246	.9206	.8543	.7545	1.2826
24	.9663	1.1393	1.1972	.8954	.8276	.7217	1.1934
Max	1.249	1.2338	1.2681	1.1904	1.185	.8147	1.3161
Min	.5007	.4862	.6097	.7613	.3757	.0107	.4725
Avg	.7708	.9808	.9909	.9669	.7954	.6609	.7469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 203 / 11 KV DONGARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4214	.4572	.4603	.4649	.4534	.4527	.3978
2	.4298	.4534	.455	.4611	.4481	.4489	.3932
3	.4329	.4519	.4717		.4428	.4466	.394
4	.4313	.4466	.4687		.4382	.2972	.3948
5	.4153	.4451	.4672		.4329	.4054	.3902
6	.4077	.4382	.458		.4252	.4283	.3849
7	.3734	.4344	.4443		.3605	.3871	.3536
8	.3346	.4893	.5144		.2362	.0168	.3277
9	.4611	.5319	.5929		.2202		.3086
10	.5121	.5609	.6135		.269		.3231
11	.2797	.3315	.2492		.3788	.1128	.3361
12	.1776		.2172		.4611	.1242	.3262
13	.1951		.2553		.503	.3094	.3285
14	.2096		.2789		.5014	.3254	.3406
15	.2233		.2865		.4367	.3231	.3849
16	.2157		.2881	.3696	.4367	.314	.3925
17	.202		.2629	.3498	.4412	.3109	.3955
18	.2096	.192	.2492	.349	.4466	.3117	.3452
19	.3269	.333	.3742	.3414	.3643	.3666	.314
20	.4527	.4847	.5083	.4641	.4672	.4016	.3864
21	.4832	.5205	.5342	.506	.5045	.4214	.4382
22	.4832	.5182	.5396	.5152	.5129	.4184	.4466
23	.487	.4999	.5205	.487	.4923	.4161	.4283
24	.4565	.4733	.4771	.4595	.4618	.4047	.4138
Max	.5121	.5609	.6135	.5152	.5129	.4527	.4466
Min	.1776	.192	.2172	.3414	.2202	.0168	.3086
Avg	.3592	.4479	.4161	.4334	.4223	.3383	.3727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164009 / 33 KV KUHI

Feeder No / Name : 206 / 11 KV TITUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3353				.3963	
2	.3353	.3353				.3963	
3	.3353	.3353	.3658			.3963	
4	.3353	.3353	.3658			.3658	
5	.3658	.3353	.3353			.3963	
6	.3353	.3048	.3658			.3658	
7	.3353	.2743	.4572			.3658	
8	.3353	.2134	.5182			.3353	
9	.3658	.1829	.5792			.3353	
10	.3658	.1829				.3658	.1829
11					.0914	.2743	.1829
12						.2743	.1829
13					.0914	.2439	
14					.3353	.2743	.1829
15					.2743	.2439	.2134
16				.5487	.3048	.2439	.2134
17				.3963	.3048	.2134	.2134
18				.3353	.2743		.2134
23					.3658		
24					.3963		
Max	.3658	.3353	.5792	.5487	.3963	.3963	.2134
Min	.3353	.1829	.3353	.3353	.0914	.2134	.1829
Avg	.3445	.2835	.4268	.4268	.2709	.3228	.1982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 202 / 11 KV CHICHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4877		.2743	.2743	.2134
2	.4268	.4572		.2743	.3048	.2134
3	.4268	.4572		.2743	.2743	.2134
4	.4268			.2743	.2743	.2134
5	.4268			.2743	.2743	.2134
6	.4268			.2743	.3048	.2439
7	.4572			.3048	.1829	.2439
8	.4268					.3048
9	.4268					.2134
10	.4572			.2743		.1829
11				.2743		.1829
12				.3048	.5182	.2134
13				.3048		.2134
14				.3048	.5182	.2134
15				.2134	.5182	.2743
16				.1829	.5182	.2134
17					.5182	
18			.2439	.2439		.0914
19			.4268	.2439	.2743	.2134
20			.3963	.3353	.3048	
21			.3963	.3353	.2439	.2439
22			.3963	.3353	.2439	.2439
23			.3048	.3353	.2439	.2439
24			.2743	.3048	.2439	.2134
Max	.4572	.4877	.4268	.3353	.5182	.3048
Min	.4268	.4572	.2439	.1829	.1829	.0914
Avg	.4359	.4674	.3484	.2830	.3353	.2189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164010 / 33 KV PACHKHEDI

Feeder No / Name : 204 / Mandhal II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2492	.1273	.1105	.1242	.128	.1372	.1806
2	.2446	.1318	.112	.1265	.1303	.1357	.1829
3	.2416	.1341	.1181	.1311	.1288	.1387	.1837
4	.2416	.1379	.1189	.1692	.1357	.144	.1966
5	.2408	.1372	.1204	.1692	.1387	.1471	.1981
6	.2393	.1364	.1204	.1684	.1357	.1448	.1981
7	.237	.1433	.1357	.1593	.1341	.1486	.1981
8	.1425	.1311	.1204	.1387	.1196	.1501	.1776
9	.1456	.128	.1189	.1471	.1349	.1555	.1654
10	.1288	.1189	.1265	.1334	.1235	.1738	.1547
11	.1014	.0945	.1105	.1044	.1021	.1837	.1326
12	.1021	.0899	.112	.1044	.1059	.1608	.1181
13	.1082	.0937	.1044	.1341	.1212	.1699	.112
14	.1082	.1036	.1158	.1349	.1326	.1661	.1242
15	.1113	.0975	.1029	.1387	.1105	.1501	.1288
16	.1036	.0823	.1059	.1235	.1135	.1692	.1143
17	.0838	.0846	.109	.1227	.1235		.1181
18	.0983	.0762	.112	.1265	.109	.16	.1189
19	.0884	.0907	.1059	.0945	.109	.1578	.1181
20	.0945	.0884	.1044	.0907	.1036	.1402	.1212
21	.1181	.0937	.1097	.1067	.1128	.1456	.1341
22	.1166	.1014	.112	.1143	.1204	.1646	.1456
23	.1204	.1044	.1143	.1189	.128	.1684	.1509
24	.1288	.1059	.1181	.1219	.1311	.1684	.1578
Max	.2492	.1433	.1357	.1692	.1387	.1837	.1981
Min	.0838	.0762	.1029	.0907	.1021	.1357	.112
Avg	.1498	.1097	.1141	.1293	.1222	.1557	.1513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 201 / 11KV LANJALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
19		.0011	.1132	.0171	.0069	
20	.0103	.0011	.1006	.0114	.0034	.0343
21	.0091	.0011		.0023	.0309	.1189
22	.0011			.008	.0274	.0434
Max	.0103	.0011	.1132	.0171	.0309	.1189
Min	.0011	.0011	.1006	.0023	.0034	.0343
Avg	.0068	.0011	.1069	.0097	.0172	.0655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

KUHI (R) S/DN.[361] BU 0361

Substation No/ Name :- 164063 / 33/11 KV DONGARGAON

Feeder No / Name : 202 / 11 KV SASEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.5228	.5106	.4717	.3086	.3772	.4374
2	.6211	.5228	.4999	.4565	.349	.3765	.439
3	.612	.5213	.4694	.0373	.3521	.3749	.4367
4	.6028	.5205	.471		.3521	.3681	
5	.5929	.5197	.4725		.3521	.381	
6	.5876	.5068	.455		.3445	.3605	
7	.5098	.4344	.423		.2522	.3064	
8	.5144	.4473	.4946		.1867	.2515	
9	.5213	.4763	.5205		.1989	.2561	.1212
10	.5502	.3246	.5411		.1318		.1204
11	.5197	.3955	.3658	.144	.2103		.1143
12	.5289	.4306	.5921	.2713	.2286		.2218
13	.6013	.5068	.6348	.266	.205	.003	.2172
14	.615	.5609	.6379	.3025	.2538	.2241	
15	.602		.5815	.2972	.266	.221	.266
16	.4138		.5914	.2812	.2759	.2172	.2919
17	.333	.519	.5746	.3193	.2545	.2195	.298
18	.3666	.5937	.5761	.3399	.2858	.2873	.314
19	.5091	.6097	.6074	.4969	.3986	.4222	.3955
20	.5769	.6363	.6059	.5373	.426	.4854	.4062
21	.5982	.6432	.6226	.5617	.4321	.5053	.4481
22	.5876	.644	.5068	.2393	.4252	.4984	.4344
23	.5479	.5304	.4885		.397	.4626	.3749
24	.5289	.5175	.4733	.2797	.3788	.4405	.3666
Max	.6219	.644	.6379	.5617	.4321	.5053	.4481
Min	.333	.3246	.3658	.0373	.1318	.003	.1143
Avg	.5443	.5175	.5298	.3314	.3027	.3352	.3169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

NAGPUR (U) S/DN.I[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 207 / 11 kV Dhamna

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	.2797	.5662	.4893	.487	1.2551	1.3923
2	.2721	.2713	.5548	.4755	.4717	1.1523	.9556
3	.2683	.2698	.4489	.4702	.4664	.397	.237
4	.2675	.2667	.4291		.4588	.3925	.2362
5	.2652	.2652	.4344	.0023	.4534	.3955	.2477
6	.2705	.266	.4359		.4603	.2439	.253
7	.2591	.0099	.8657		.426	.3849	.253
8	.237		.9899		.6356	.3681	.2431
9	.2545		.7743		.8223	.349	.2477
10	.1974		.6744		.868	.4992	.3399
11	.285		.3445		.3727	.708	.3467
12	.2766	.2096	.362		.4054	.6714	.3277
13	.285	.3064	.3307		.3986	.6729	.3315
14	.2827	.3025	.3551		.3117	.6843	.3285
15	.266	.2942	.3727	.0716	.2789	.6935	.2858
16	.2949	.2926	.3704	.4123	.298	.7308	.3033
17	.218	.3102	.3765	.413	.25	.7522	.3094
18	.2073	.3643	.3544	.4283	.5967	.7895	.3513
19	.2629	.4626	.4572	.4847	1.2315	1.2269	.5754
20	.3125	.6234	.538	.5548	1.5455	1.4906	.6783
21	.317	.6508	.57	.5578	1.6286	1.4411	.7331
22	.317	.6607	.5883	.5662	1.6088	1.5295	.7834
23	.3079	.6462	.5578	.5418	1.5569	1.4922	.7979
24	.2911	.5929	.5136	.506	1.2902	1.4213	.7987
Max	49.9429	.6607	.9899	.5662	1.6286	1.5295	1.3923
Min	.1974	.0099	.3307	.0023	.25	.2439	.2362
Avg	2.3399	.3673	.5110	.4267	.7218	.8226	.4732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

NAGPUR (U) S/DN.I[367] BU 3905

Substation No/ Name :- 164016 / 33 KV BAZARGAON

Feeder No / Name : 209 / 11 Kv Economic Explosive NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.417	.4204	.4255	.4107	.4384	.4555	.3835
2	.4132	.4078	.435	.4024	.4418	.4618	.4387
3	.4252	.407	.431	.2735	.4401	.4675	.4367
4	.4144	.4041	.4301	.2486	.4455	.4612	.4252
5	.4167	.4152	.4238	.4138	.4347	.4658	.4338
6	.4324	.421	.4152		.4487	.4833	.4584
7	.6161	.5293	.3889		.595	.6533	.5704
8	.6596	.5307	.3638		.5178	.6804	.6164
9	.601	.5456	.3395	.4847	.5901	.6802	.6144
10	.6682	.5736	.4295	.3884	.6659	.6662	.5927
11	.7965	.7196	.3955	.7022	.8665	.7762	.7136
12	.813	.6862	.405	.8208	.8242	.7545	.7539
13	.8028	.6987	.4378	.8082	.8588	.7345	.6724
14	.7133	.6559	.3749	.787	.6967	.7673	.6659
15	.6842	.4384	.4338	.7213	.671	.787	.6664
16	.7527	.4873	.429	.7776	.7145	.8168	.6184
17	.7379	.4635	.419	.8462	.547	.8516	.667
18	.5764	.4741	.3907	.6193	.5816	.5681	.5801
19	.6507	.4441	.4484	.5307	.6227	.561	.5933
20	.687	.4787	.4438	.5713	.6096	.6067	.6413
21	.5987	.521	.4218	.541	.5764	.5601	.6053
22	.5736	.4881	.4215	.5604	.5793	.5656	.6079
23	.4915	.3995	.4167	.5187	.5487	.5284	.5141
24	.4147	.4387	.4135	.4438	.4467	.4347	.4207
Max	.813	.7196	.4484	.8462	.8665	.8516	.7539
Min	.4132	.3995	.3395	.2486	.4347	.4347	.3835
Avg	.5982	.5020	.4139	.5653	.5901	.6162	.5704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

NAGPUR (U) S/DN.I[367] BU 3905

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 202 / 11 kV Godhni town
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3382	1.2841	1.3916	1.4731	1.4205	1.3245	1.2437
2	1.3016	1.2506	1.3222	1.4137	1.3321	1.2795	1.1751
3	1.2742	1.2201	1.2925	1.3557	1.2963	1.246	1.1439
4	1.2422	1.2109	1.2711	1.3054	1.2772	1.2269	1.1195
5	1.2201	1.1858	1.243	1.2711	1.2574	1.2026	1.105
6	1.2651	1.2475	1.2727	1.3039	1.2666	1.2239	1.1469
7	1.3794	1.3428	1.2788	1.3557	1.2894	1.3778	1.3207
8	1.3184	1.3077	1.1866	1.3024	1.275	1.323	1.262
9	1.31	1.2315	1.1431	1.2018	1.2407	1.2872	1.2254
10	1.2788	1.2125	1.2186	1.1843	1.2391	1.3512	1.1218
11	1.1446	1.1622	1.2506	1.1218	1.2445	1.1477	1.1142
12	1.0654	1.1233	1.201	1.0844	1.2292	.9968	.9732
13	1.0486	1.1264	1.3138	1.0783	1.1706	.9556	.9945
14	1.0395	1.0585	1.294	1.0761	1.1233	.9282	.98
15	1.0258	1.0661	1.2811	.9983	1.1584	.9046	.9427
16	1.0669	1.0174	1.2635	1.0212	1.1797	.8612	.9587
17	1.0966	.9816	1.2315	1.0486	1.0562	.8711	.9435
18	1.0463	1.0867	1.246	1.0395	1.0928	.8954	.9145
19	1.3009	1.2971	1.4434	1.259	1.3001	1.1843	1.2681
20	1.422	1.5211	1.579	1.5455	1.3908	1.3093	1.3938
21	1.4624	1.5417	1.5234	1.5524	1.3809	1.3291	1.3611
22	1.4487	1.5173	1.5219	1.576	1.4289	1.3763	1.3367
23	1.4106	1.5196	1.5539	1.515	1.422	1.3832	1.3184
24	1.3443	1.4937	1.5264	1.4838	1.3916	1.326	1.2704
Max	1.4624	1.5417	1.579	1.576	1.4289	1.3832	1.3938
Min	1.0258	.9816	1.1431	.9983	1.0562	.8612	.9145
Avg	1.2438	1.2503	1.3271	1.2736	1.2693	1.1796	1.1514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

NAGPUR (U) S/DN.I[367] BU 3905

Substation No/ Name :- 164065 / Hudkeshwar Khurd

Feeder No / Name : 201 / chikna

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.269	.2622	.2736	.2743	.2705	.2766	.2667
2	.2606	.253	.2705	.2698	.2675	.2804	.2629
3	.2515	.2492	.2705		.2675	.2812	.2583
4	.2492	.2469	.2736		.266	.2652	.2446
5	.2484	.2538	.2698	.0084	.2705	.2591	.2446
6	.2561	.253	.2721		.2675	.269	.2522
7	.2317	.221	.2324		.2401	.2416	.2225
8	.33	.3734	.2492	.1928	.2827	.2164	.2652
9	.3429	.3605	.3719	.3231	.4504		.2911
10	.3216	.3788	.3498	.4252	.3673	.0038	.2835
11	.3422	.4214	.3963	.3765	.3147	.0069	.285
12	.2858	.3818	.3818	.3788	.2751	.048	.3102
13	.2911	.3628	.3445	.3361	.2545	.2789	.1974
14	.2721	.3765	.3292	.3521	.1029	.2804	.205
15	.202	.3628	.3628	.3033	.1006	.2446	.3125
16	.2233	.3727	.3513	.3132	.1212	.2355	.3559
17	.2058	.3483	.3483	.3376	.1699	.2111	.1966
18	.1844	.3429	.3117	.3498	.2797	.2065	.1821
19	.253	.314	.2743	.2652	.2804	.269	.2599
20	.2843	.3086	.2873	.2987	.2812	.285	.2774
21	.2835	.3041	.2904	.2919	.2888	.2812	.285
22	.2736	.3056	.2873	.2926	.2896	.285	.2865
23	.2675	.2964	.2827	.2797	.2865	.2728	.2804
24	.2667	.2789	.2743	.2698	.2812	.2736	.2743
Max	.3429	.4214	.3963	.4252	.4504	.285	.3559
Min	.1844	.221	.2324	.0084	.1006	.0038	.1821
Avg	.2665	.3179	.3065	.2969	.2615	.2292	.2625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

NAGPUR (U) S/DN.I[367] BU 3905

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 207 / Wadi U

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0652	2.0805	2.2177	2.1414	2.2786	2.1262	1.9814
2	1.9204	1.9738	2.0348	2.0424	2.1643	1.989	1.8823
3	1.8671	1.9052	2.0195	2.0043	2.1186	2.0043	1.8442
4	1.8519	1.8747	1.9738	1.9052	2.0729	1.9738	1.8214
5	1.8519	1.8747	1.9738	1.8366	2.0729	1.9433	1.7909
6	1.8976	1.8976	1.989	1.829	2.1033	1.9662	1.8138
7	2.05	2.0957	2.1033	1.9966	2.1491	2.1186	1.9738
8	2.0881	2.1262	2.431	2.05	2.111	2.1948	1.9966
9	2.0043	2.0119	2.4082	1.9814	2.1338	2.05	1.7604
10			2.7054	2.2558	2.5225	1.9357	1.5775
11	3.4675		2.873	2.4234	2.9645	1.9814	1.669
12	3.5818	2.9721	3.0712	2.7816	3.5437	2.0195	2.7892
13	2.4768	3.5361	3.0559	2.9874	4.1152	2.1872	3.0331
14	2.8807	3.7571	3.2617	3.2693	3.5665	2.1719	3.3913
15	3.5056	3.7113	2.8045	3.658	3.4903	2.1643	3.2693
16	3.3227	3.8028	2.6292	3.7952	3.7952	2.1186	3.2693
17	3.0407	2.6597	2.8045	3.9323	3.6046	2.1567	3.1779
18	3.5513		2.9721	3.6732	2.6597	2.0195	3.0483
19	3.7571	.4954	2.5606	3.3303	3.3532	2.4082	3.4522
20	3.7113	4.3134	2.713	3.5894	3.3913	2.6292	3.4903
21	2.8426	3.5589	2.492	2.9645	2.8578	2.4158	2.774
22	2.6292	2.8883	2.3777	2.6978	2.5911	2.4006	2.4691
23	2.3396	2.5606	2.3548	2.553	2.5377	2.271	2.3472
24	2.2939	2.3853	2.271	2.4387	2.3167	2.0957	2.2177
Max	3.7571	4.3134	3.2617	3.9323	4.1152	2.6292	3.4903
Min	1.8519	.4954	1.9738	1.829	2.0729	1.9357	1.5775
Avg	2.6521	2.5943	2.5041	2.6724	2.7714	2.1392	2.4517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164005 / 33 KV PACHGAON

Feeder No / Name : 203 / 11 KV Jassal Industrial NON SHEDDABLE EXPRESS HV FEEDERS
 champa Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.0065					
6	.0004						
8					.0011		
10	.0118	.013	.0069	.013	.0046		.0053
11	.0198	.0267	.0103	.0392	.0191		.021
12		.0271	.037	.037	.021		.0415
13	.0533	.0347	.0271	.0354	.0175		.0442
14	.0541	.0404	.0427	.0297	.021	.0053	.056
15	.0549	.048	.0518	.0396	.021	.005	.048
16	.0408	.0442	.0522	.0351	.0194	.0004	.0621
17	.0511	.0423	.0518	.037	.0198	.0034	.04
18	.0431	.0373	.0541	.0229	.0114	.0004	.0389
19	.0202	.0057	.0549	.016	.0019	.0004	.0149
20	.0027	.003	.0579	.0354	.008	.0061	.0373
21	.008		.0027	.0206		.0061	.0061
22	.032	.0076	.0141	.0202		.0339	.0015
23	.0286	.0232	.0137			.0145	.0027
24	.0034		.005				.0004
Max	.0549	.048	.0579	.0396	.021	.0339	.0621
Min	.0004	.003	.0027	.013	.0011	.0004	.0004
Avg	.0283	.0257	.0321	.0293	.0138	.0076	.0280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 201 / 11 KV SIRPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2492	.3033	.3628	.3841	.3894	.3772	.3056
2	.2469	.2995	.3589		.381	.3696	.301
3	.2469	.2957	.3536		.3795	.3666	.2934
4	.2446	.2919	.346		.3757	.3635	.282
5	.2385	.2888	.3292		.3673	.3574	.2759
6	.2286	.2637	.301		.3368	.3315	.2583
7	.1722	.2378	.2088		.2202	.2225	.1928
8	.176	.2317	.2058		.1966	.1776	.1936
9	.1829	.2286	.2507		.2164	.2096	.189
10	.0983	.1699	.1105		.2187	.1989	.1821
11		.1555			.2263	.1844	
12		.2218			.2317	.1684	
13		.1745			.2606	.1981	
14		.1791		.2042	.2431	.1936	
15	.1699	.1669		.2164	.2073	.2088	.1745
16	.1699	.1753		.2187	.1608	.1943	.1715
17	.1768	.1852		.2058	.1654	.1776	.1814
18	.2301	.2286		.2241	.1555	.2012	.2644
19	.33	.3658		.3757		.365	.3277
20	.3376	.3925		.4054		.3795	.3597
21	.3452	.4031	.4054	.439	.0861	.3338	.3955
22	.3422	.4009	.413	.442	.4283	.3384	.3673
23	.3208	.3833	.4024	.4062	.3978	.3216	.3437
24	.3125	.3688	.3978	.3925	.3818	.3117	.3368
Max	.3452	.4031	.413	.442	.4283	.3795	.3955
Min	.0983	.1555	.1105	.2042	.0861	.1684	.1715
Avg	.2410	.2672	.3176	.3262	.2739	.2730	.2698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 203 / 11 KV DAWWA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1959		.208	.205	.2157	.2065	.2858
2	.1928		.208		.2126	.2035	.282
3	.1905		.2058		.2096	.1981	
4	.1867		.1936		.2096		
5	.1806		.1882		.2042		
6	.1448		.1501		.1555		
7	.1135		.144		.1235		.0015
8	.112		.1425		.1227		
9	.1105		.1791		.1196		
10					.1265		
11					.1471		
12					.1364		
13		.0213			.1334		
14		.1151		.0975	.0533		
15		.1776		.1257	.0777	.0732	
16		.1852		.0312	.0907	.0991	
17		.1753		.0876	.1273	.1097	.0046
18	.1562	.2568		.1082	.0076	.2172	
19	.2484	.2538		.1814		.2545	
20	.1974	.2622	.0008	.112		.2385	
21	.0114	.2545	.003	.1936	.1989	.2614	.0008
22		.2439	.0678	.2378	.2225	.2637	
23		.2157	.1768	.2301	.2096	.2873	.0008
24		.2111	.2065	.2202	.208	.2858	
Max	.2484	.2622	.208	.2378	.2225	.2873	.2858
Min	.0114	.0213	.0008	.0312	.0076	.0732	.0008
Avg	.1570	.1977	.1482	.1525	.1505	.2076	.0959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164032 / 33 KV MAKARDHOKDA

Feeder No / Name : 205 / MIDC OLD WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	21-SEP-17
HR	Load (MW)
19	.0069
Max	.0069
Min	.0069
Avg	.0069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

S

Feeder No / Name : 201 / 11KV GANGAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4441	1.4556	1.5813	1.6484	1.5752	1.5379	1.4419
2	1.4114	1.4319	1.5417	1.7078	1.5386	1.4914	1.4198
3	1.3954	1.4121	1.5104	1.4944	1.5135	1.467	1.3817
4	1.3855	1.3931	1.4906	1.3893	1.5036	1.4548	1.3359
5	1.3695	1.387	1.4891	1.3832	1.4838	1.4495	1.3214
6	1.3443	1.3756	1.4609	1.3603	1.4586	1.4297	1.3085
7	1.1721	1.2399	1.262	1.2811	1.262	1.3047	1.2209
8	.9892	1.0044	1.0822	1.1309	1.0334	1.0448	1.0174
9	.9617	.9739	1.0296	1.1187	.9877	.9823	.9793
10	.9938	.9861	1.0684	1.0128	1.0479	.9739	.9351
11	.9503	.9785	1.0867	.9922	1.089	.9412	.9114
12	.9884	1.0601	1.1561	1.0684	1.1629	.916	.9107
13	1.0433	1.1256	1.2407	1.0943	1.2163	.9602	.9556
14	1.0776	1.1606	1.2582	1.1347	1.2163	.9884	1.0341
15	1.0974	1.1629	1.2986	1.1355	1.2026	.9419	1.0067
16	1.1088	1.1431	1.2689	1.0692	1.2087	.9198	1.0098
17	1.041	1.1591	1.2048	1.0479	1.1995	.8985	1.0014
18	1.089	1.1309	1.23	1.0799	1.2277	1.0212	1.153
19	1.5318	1.5813	1.6636	1.5455	1.5463	1.3626	1.4159
20	1.5463	1.6225	1.6895	1.5828	1.5181	1.4213	1.4411
21	1.6118	1.6659	1.7261	1.6095	1.608	1.515	1.5295
22	1.627	1.6964	1.8038	1.7223	1.672	1.5501	1.5257
23	1.5981	1.6972	1.7886	1.7253	1.6941	1.5447	1.4845
24	1.5348	1.6636	1.733	1.6171	1.6225	1.464	1.3961
Max	1.627	1.6972	1.8038	1.7253	1.6941	1.5501	1.5295
Min	.9503	.9739	1.0296	.9922	.9877	.8985	.9107
Avg	1.2630	1.3128	1.4027	1.3313	1.3578	1.2325	1.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

s

Feeder No / Name : 202 / 11KV SONEZARI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.2132	1.3283	1.3832	1.3489	1.307	1.2765
2	1.1584	1.1805	1.2849	1.2468	1.3108	1.2772	1.2483
3	1.1424	1.1645	1.2635	1.1584	1.2864	1.259	1.2132
4	1.137	1.1736	1.2536	1.1454	1.2772	1.2689	1.1789
5	1.2117	1.2353	1.2536	1.2094	1.2635	1.2803	1.1858
6	1.2262	1.2437	1.2468	1.2308	1.2567	1.3009	1.2109
7	1.1477	1.2148	1.166	1.1134	1.166	1.2544	1.1713
8	.9816	1.0258	1.0555	1.0082	1.0143	1.0654	1.0799
9	.9686	.9717	1.054	.9678	1.0303	1.0113	1.0166
10	.9991	1.0181	1.0745	1.0006	1.105	1.0105	1.0433
11	1.1203	1.1538	1.2132	1.1286	1.2772	1.1119	1.0433
12	1.1279	1.2064	1.2407	1.2109	1.3466	1.1347	1.0189
13	1.1881	1.105	1.2894	1.2651	1.3756	1.1317	1.137
14	1.2178	1.2894	1.2681	1.326	1.371	1.1492	1.153
15	1.2201	1.2704	1.3062	1.3214	1.3542	1.1279	1.2132
16	1.2018	1.259	1.2993	1.3047	1.3085	1.1294	1.2399
17	1.1309	1.2193	1.243	1.2468	1.2795	1.0829	1.2315
18	1.3131	1.2254	1.3474	1.3527	1.3634	1.1934	1.3519
19	1.5661	1.579	1.6621	1.6575	1.6133	1.4228	1.547
20	1.5295	1.5973	1.6903	1.6514	1.5394	1.438	1.4502
21	1.4556	1.5501	1.6392	1.611	1.512	1.4487	1.4121
22	1.403	1.4685	1.5851	1.5394	1.4899	1.4358	1.3687
23	1.3435	1.4472	1.5203	1.4944	1.4609	1.4159	1.291
24	1.2582	1.3984	1.4594	1.4167	1.3946	1.3268	1.2308
Max	1.5661	1.5973	1.6903	1.6575	1.6133	1.4487	1.547
Min	.9686	.9717	1.054	.9678	1.0143	1.0105	1.0166
Avg	1.2176	1.2588	1.3227	1.2913	1.3227	1.2327	1.2214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

s

Feeder No / Name : 204 / 11KV DREAM CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8017	.8017	.8985	.9305	.9054	.8794	.7994
2	.775	.7796	.8573	.977	.8581	.849	.7796
3	.7567	.7743	.836	.8642	.849	.8391	.7499
4	.7453	.7697	.8269	.7567	.8337	.823	.7346
5	.74	.7705	.82	.7567	.8284	.8162	.7362
6	.7781	.7979	.8284	.7659	.8284	.8352	.7529
7	.7712	.8093	.7895	.7468	.82	.836	.7796
8	.7346	.7171	.7567	.6744	.7644	.7476	.7392
9	.7232	.7354	.7956	.6767	.8169	.7583	.7331
10	.7598	.74	.8116	.7712	.804	.7453	.727
11	.7438	.7567	.8413	.7545	.8109	.7194	.6981
12	.7308	.7682	.8375	.7773	.8238	.692	.6866
13	.7171	.791	.8421	.8147	.8444	.6988	.6714
14	.7202	.7987	.8269	.7872	.8406	.6882	.66
15	.7133	.7484	.8352	.7979	.8398	.6501	.6935
16	.7423	.7872	.8383	.8048	.8276	.66	.6996
17	.7019	.7697	.8139	.8131	.7971	.6371	.708
18	.7468	.7613	.8238	.8185	.7926	.7179	.7819
19	.9831	.9496	1.0174	1.0044	.964	.8703	.9153
20	.9556	.98	1.0616	1.025	.9739	.8794	.8794
21	.9351	.9823	1.0288	1.0052	.9579	.8939	.8749
22	.9396	.9892	1.0349	1.0067	.9747	.8962	.8566
23	.9183	.9831	1.0288	.996	.9709	.8901	.823
24	.8558	.9366	.9877	.9435	.9297	.8314	.7766
Max	.9831	.9892	1.0616	1.025	.9747	.8962	.9153
Min	.7019	.7171	.7567	.6744	.7644	.6371	.66
Avg	.7912	.8207	.8766	.8445	.8607	.7856	.7607

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 164055 / 33/11KV New Mohpa road Umred

s

Feeder No / Name : 205 / 11KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2187	.2134	.2149	.2027	.2644	.2187	.2378
2	.2347	.2347	.1951	.1943	.2446	.1981	.2195
3	.2317	.2218	.2058	.1844	.2439	.1951	.2141
4	.2263	.2088	.1913	.157	.2484	.1966	.2233
5	.1844	.2119	.1799	.1692	.2484	.1745	.2111
6	.1532	.189	.1829	.1844	.2096	.1905	.176
7	.125	.2065	.1745	.1722	.1928	.1524	.1425
8	.3018	.4001	.1478	.3185	.3544	.1814	.2629
9	.4626	.5495	.173	.4611	.5266	.2241	.3688
10	.1539	.5251	.1928	.4999	.4633	.2256	.4862
11	.2149	.5921	.25	.5967	.5159	.2187	.5335
12	.4778	.6501	.2644	.6249	.4771	.2088	.5761
13	.4207	.5617	.2774	.5807	.4771	.173	.5296
14	.4435	.4412	.1997	.3841	.3643	.1852	.3346
15	.4611	.5144	.2423	.5655	.4748	.1707	.5007
16	.5639	.5235	.2789	.5388	.4359	.218	.5921
17	.5274	.5799	.2286	.554	.4245	.2477	.5228
18	.4885	.57	.2477	.4824	.4679	.2408	.5144
19	.4519	.4961	.2134	.4237	.3948	.2401	.4717
20	.237	.2576	.1821	.2759	.2408	.2385	.2164
21	.2157	.2408	.1898	.2919	.2073	.2347	.1997
22	.2492	.2027	.1997	.2454	.2187	.1951	.1799
23	.253	.1966	.1814	.2843	.2225	.192	.1913
24	.2195	.2141	.2042	.2858	.2233	.2202	.1654
Max	.5639	.6501	.2789	.6249	.5266	.2477	.5921
Min	.125	.189	.1478	.157	.1928	.1524	.1425
Avg	.3132	.3751	.2091	.3616	.3392	.2059	.3363

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 202 / 11 KV UMRER U II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1082	.1067	.1219	.1235	.1288	.1143	.1044
2	.1029	.1036	.1151	.1212	.1257	.109	.1021
3	.0991	.1021	.112		.1235	.1075	.1052
4	.0975	.0998	.1097		.1204	.1052	.0998
5	.0983	.0991	.1067		.1181	.1052	.0975
6	.0983	.0998	.1097		.1174	.1067	.0991
7	.096	.0983	.1044	.1067	.112	.1021	.1021
8	.0854	.0892	.0991	.1082	.1044	.0937	.0922
9	.0975	.0823	.1128	.1097	.1227	.0983	.1029
10	.1044	.0846	.1174	.1196	.1212	.1044	.1082
11	.1097	.0937	.1235	.1326	.1212	.1219	.1257
12	.1082	.0998	.1235	.1334	.1189	.1227	.1196
13	.1204	.0998	.1227	.1555	.1242	.1265	.1151
14	.1181	.0907	.1189	.1638	.1265	.1265	.1357
15	.1105	.096	.1097	.1631	.128	.1204	.1288
16	.109	.1113	.1075	.1318	.1296	.1014	.109
17	.0869	.109	.1059	.1044	.1075	.0846	.093
18	.0922	.1059	.0945	.1044	.1067	.1021	.1029
19	.1181	.1235	.1303	.1433	.1265	.1143	.1212
20	.125	.1303	.1311	.1395	.1227	.1158	.1227
21	.1273	.1311	.1357	.141	.1242	.1166	.1227
22	.125	.1357	.1318	.1463	.1318	.1166	.1219
23	.1212	.1318	.1341	.1425	.1288	.1151	.1166
24	.1166	.1273	.1311	.1387	.1235	.1097	.1113
Max	.1273	.1357	.1357	.1638	.1318	.1265	.1357
Min	.0854	.0823	.0945	.1044	.1044	.0846	.0922
Avg	.1073	.1063	.1170	.1315	.1214	.1100	.1108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR I DIVISION[654]

UMRER S/DN.[357]

BU 0357

Substation No/ Name :- 165002 / 33KV UMRER

Feeder No / Name : 207 / 11KV Express Water work
feeder Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914	.1044	.1326	.1036		.1517
2	.1349	.1875	.1821	.1859	.1821	.1296	.1837
3	.1349	.2058	.202		.1814	.1288	.176
4	.1341	.205	.1806		.1547	.1463	.1486
5	.1334	.1981	.1524		.1547	.1463	.1478
6	.0838	.1478	.16		.144	.2126	.1532
7	.1387	.1448	.1936		.1913	.2126	.1547
8	.1257	.1814	.205		.2088	.1738	.1974
9	.1364	.2073	.2111		.2035	.1844	.2027
10	.1692	.2073	.1372	.1433	.1372	.1898	.2103
11	.1288	.2065	.1821	.1882	.1882	.1684	.1943
12	.0282	.2035	.1799	.1951	.1974	.112	.1654
13	.1349	.2012	.1837	.221	.2149	.1273	.1623
14	.1372	.2103	.1814	.2134	.1905	.1265	.1547
15	.1349	.2004	.1905	.2073	.205	.1265	.1585
16	.1379	.2096	.1738	.2035	.1791	.1509	.1402
17	.1707	.1852	.1951	.1837	.1646	.1966	.1349
18	.1417	.1776	.1913	.1738	.1494	.1814	.1334
19	.1311	.1692	.16	.1707	.1242	.1882	.1341
20	.1357	.128	.1303	.1158	.125	.1341	.1227
21	.1448	.1021	.1707	.1859	.1357	.1357	.1326
22	.1296	.1014	.1707	.1928	.1044	.1036	.1562
23	.096	.1029	.128	.141	.1044	.1951	.1768
24	.0937	.109	.093	.1036	.0518	.1997	.1966
Max	.1707	.2103	.2111	.221	.2149	.2126	.2103
Min	.0282	.0914	.093	.1036	.0518	.1036	.1227
Avg	.1277	.1701	.1691	.1740	.1582	.1596	.1620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KALMESHWAR S/DN.[363] BU 0363

Substation No/ Name :- 164012 / 33 KV GONDKHAIRY SUB STATION

Feeder No / Name : 206 / 11KV GONDKHAIRY AG SEP SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1113	.0061	
2					.1067		
3					.1052		
4					.1052		
5			.0015		.1059		
6					.1014		
7	.0008				.0312	.0556	
8				.0015	.0907	.0808	.0008
9				.0061	.1014		
10			.0015		.0945		
11	.0046				.0587		.0419
12					.0739		.0633
13					.0861		.0061
14	.0015		.0793		.0876		.0069
15	.0015	.0061	.0198	.0716	.0663		.0015
16			.0655	.0922	.0556		.0175
17	.0008		.0343	.0823	.0754		
18		.0023	.0213				
19				.1006	.0793		
20				.1059	.0655		
21				.1075	.0815		
22				.1105	.077		
23				.1097	.0434		
24				.1105	.013		
Max	.0046	.0061	.0793	.1105	.1113	.0808	.0633
Min	.0008	.0023	.0015	.0015	.013	.0061	.0008
Avg	.0018	.0042	.0319	.0817	.0790	.0475	.0197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164015 / 33 KV KHAPA

Feeder No / Name : 207 / 11 KV RAMDONGRI

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1638	.1829	.0457	.1791	.1257
2	.0876	.0838	.0838	.0457	.0838	.0724
3	.1638	.1677	.1677	.0495	.1829	.1753
4	.1715	.1791	.1715	.0457	.1677	.16
5	.1562	.1677	.1753	.0457	.16	.1677
6	.16	.1562	.1638	.0457	.1638	.1562
7	.1486	.1448	.1524	.0457	.1448	.1486
8	.1296	.1257	.1257	.0419	.1448	.1562
9	.1067	.1181	.0419	.0457	.1105	.0838
10	.0419	.0724	.0381	.061	.0495	.0457
11	.0762	.0991	.0419	.0991	.0648	
12	.1562	.1486	.0381	.0991	.061	
13	.1524	.1486	.0381	.1029	.0648	
14	.0457	.0457	.0381	.0457	.0533	
15	.1486	.1372	.0381	.0953	.061	
16	.1448	.1372	.0419	.0953	.0724	
17	.141	.141	.0419	.0953	.061	
18	.1448	.1372	.0381	.0876	.061	
19		.1524	.0419	.1029	.0724	
20	.1867	.1562	.0457	.1105	.0991	
21	.1829	.1829	.0457	.16	.16	
22	.1791	.1867	.0457	.1791	.1829	
23	.1791	.1829	.0457	.1791	.1715	
24	.1791	.1791		.1829	.1753	
Max	.1867	.1867	.1829	.1829	.1829	.1753
Min	.0419	.0457	.0381	.0419	.0495	.0457
Avg	.1416	.1423	.0802	.0878	.1145	.1292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPA S/DN.[366]

BU 0366

Substation No/ Name :- 164047 / 33 KV CHARGAON S/SN

Feeder No / Name : 202 / 11 kv Sironji

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	***	***	***	***	1.0014	.9777	.9236
2	***	***	***	***	.9884	.9671	.6996
3	.9122	.929	.9717	.8863	.9777	.9518	.8756
4	***	***	***	***	.9633	.0457	.8688
5	***	***	***	***	.9579		.865
6	.8817	.9046	.9442	.7682	.9526		.8642
7	***	***	***	***	.7636		.7156
8	***	***	***	***	.5655		.5777
9	.4984	.5159	.5418	.4641	.4771		.314
10	***	***	***	***	.3414		.2911
11	***	***	***	***	.3353		.2606
12	.2522	.2873	.3254	.1501	.3079	.0335	.2157
13	***	***	***	***	.3292	.173	.221
14	***	***	***	***	.3414	.1402	.2279
15	.2378	.2553	.2759	.1981	.3064	.1875	.1768
16	***	***	***	.3025	.2683	.2058	.2439
17	***	***	***	.3201	.2865	.2248	.2721
18	.4351	.4321	.4809	.3483	.6523	.2431	.5632
19	***	***	***	1.012	1.0151	.4397	.9663
20	***	***	***	1.1416	1.0982	1.0288	1.0219
21	1.0997	1.1599	1.0814	1.1561	1.1203	1.0608	1.054
22	***	***	***	1.1416	1.0997	1.054	1.0501
23	***	***	***	1.0989	1.025	1.0143	1.0067
24	.9899	1.0288	.9877	1.0311	1.0021	.9465	.9541
Max	49.9429	49.9429	49.9429	49.9429	1.1203	1.0608	1.054
Min	.2378	.2553	.2759	.1501	.2683	.0335	.1768
Avg	33.5164	33.5250	33.5290	21.227	.7157	.5703	.6346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 202 / 11 kV Patansawangi R
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.519	.5091	.5365	.5274	.5495	.5426	.5144
2	.503	.5007	.5274	.5175	.538	.5266	.4771
3	.4832	.4946	.4519	.1684	.5182	.5014	.4458
4	.4771	.4847	.4893	.4702	.5114	.5045	.4451
5	.4702	.4847	.4847	.4451	.5075	.5091	.439
6	.4786	.4793	.4809	.4397	.506	.5114	.4656
7	.5175	.4893	.474	.4664	.4976	.5342	.4397
8	.4954	.4679	.4572	.4245	.4801	.519	.4649
9	.4786	.4252	.4512	.3849	.4504	.471	.4283
10	.4451	.3993	.4367	.4138	.3986	.4435	.413
11	.4268	.4047	.3666	.394	.3993	.4169	.3849
12	.3696	.3948	.4237	.3917	.4108	.3475	.3696
13	.3704	.3818	.4466	.3612	.4321	.3704	.3864
14	.3315	.3467	.4534	.3681	.442	.3719	.3742
15	.3117	.3315	.4016	.3818	.4351	.3376	.3185
16	.3414	.3376	.4169	.3711	.4778	.3406	.3506
17	.3338	.3483	.4557	.3818	.4153	.3841	.3849
18	.3551	.3498	.4092	.3772	.365	.3742	.3452
19	.4092	.4268	.4588	.4649	.4496	.5037	.4169
20	.5335	.6424	.5898	.6264	.5731	.6257	.5037
21	.5685	.6462	.5769	.6264	.5609	.5937	.5319
22	.5723	.6066	.5883	.6203	.5807	.583	.5441
23	.5639	.5746	.5898	.6188	.5761	.5792	.5319
24	.5235	.5441	.5434	.5624	.5517	.5601	.4626
Max	.5723	.6462	.5898	.6264	.5807	.6257	.5441
Min	.3117	.3315	.3666	.1684	.365	.3376	.3185
Avg	.4533	.4613	.4796	.4502	.4845	.4772	.4349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 203 / WCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.9145	.9145	.7926	.8535	.7926
2	1.5851	1.2193	1.5851	1.5851	1.5851	1.5242	1.1584
3	1.5851	1.5851	1.6461	1.6461	1.89	1.5851	1.5242
4	1.6461	1.5242	1.6461	1.5851	1.7071	1.7071	1.5242
5	1.6461	1.4632	1.7071	1.5242	1.7071	1.5851	1.5242
6	1.4632	1.7071	1.7071	1.5851	1.768	1.6461	1.4022
7	1.4632	1.5851	1.6461	1.5242	1.7071	1.7071	1.3413
8	.6706	.9145	.6706	.6706	.7316	1.2193	.7316
9	.6706	.7926	.8535	1.0974	.9755	.6706	.7316
10	1.2803	1.2803	1.4022	1.4022	1.3413	1.4632	1.2803
11	1.5242	1.6461	1.6461	1.6461	1.5851	1.4632	1.4632
12	1.5851	1.5851	1.829	1.6461	1.829	1.3413	1.829
13	1.4632	1.2193	1.89	1.6461	1.6461	1.4022	1.89
14	1.6461	1.5242	1.6461	1.4632	1.4632	1.4022	1.9509
15	1.829	1.829	1.7071	1.4632	1.4632	1.4022	2.0119
16	.7316	.6706	.7316	.7316	.7316	.7316	
17	.7316	.7316	.7316	.9145	.7316	.9755	1.2193
18	1.3413	1.3413	1.4022	1.4632	1.4632	1.3413	1.6461
19	1.4022	1.5242	1.5851	1.7071	1.5851	1.3413	1.768
20	1.2803	1.5242	1.6461	1.5851	1.768	1.3413	1.89
21	1.2803	1.7071	1.5851	1.7071	1.5851	1.3413	1.89
22	1.5851	1.768	1.6461	1.768	1.768	1.5242	1.89
23	1.4632	1.4022	1.6461	1.6461	1.829		1.7071
24	.7316	.6706	.7316	.7316	.6706	.7926	.7926
Max	1.829	1.829	1.89	1.768	1.89	1.7071	2.0119
Min	.6706	.6706	.6706	.6706	.6706	.6706	.7316
Avg	1.3057	1.3311	1.4251	1.4022	1.4302	1.3201	1.4765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164013 / 33 KV PATANSAWANGI

Feeder No / Name : 204 / Town APDRP SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9092	.9153	.9633	.9899	1.0235	1.0067	.9282
2	.8855	.8947	.9313	.9595	.996	.977	.865
3	.8718	.8886	.9122	.8947	.9549	.948	.8505
4	.8604	.8756	.897	.8535	.9457	.9404	.849
5	.8512	.8703	.9	.852	.9503	.9419	.8467
6	.8756	.8893	.8848	.865	.9442	.9351	.8863
7	.9084	.8947	.9061	.8688	.9236	.9625	.9236
8	.8665	.8657	.8672	.8238	.9038	.929	.9038
9	.7964	.7956	.804	.7644	.8238	.8726	.8314
10	.7705	.7484	.6379	.7522	.8276	.8131	.8116
11	.7804	.5563	.6622	.759	.8375	.7987	.7842
12	.7125	.5578	.8604	.7682	.8269	.7209	.7613
13	.6356	.7766	.8337	.836	.8467	.6874	.7567
14	.6485	.7697	.8169	.8139	.8916	.6889	.7453
15	.6645	.695	.8078	.8322	.9084	.6638	.7484
16	.6836	.7217	.8322	.7811	.8703	.6752	.7354
17	.6897	.7301	.8528	.7407	.8215	.6569	.7827
18	.7468	.6996	.8009	.7567	.7186	.6432	.7552
19	.865	.9107	.9221	.9488	.9236	.8947	.9503
20	1.0372	1.1058	1.0867	1.2193	1.0509	1.0273	1.0601
21	1.0395	1.102	1.1126	1.1972	1.0913	1.0768	1.038
22	1.0562	1.0753	1.089	1.1767	1.1111	1.0806	1.0387
23	1.0288	1.0471	1.0844	1.1271	1.1043	1.0364	1.0029
24	.9526	1.0014	1.0456	1.0677	1.0402	1.0075	.9518
Max	1.0562	1.1058	1.1126	1.2193	1.1111	1.0806	1.0601
Min	.6356	.5563	.6379	.7407	.7186	.6432	.7354
Avg	.8390	.8495	.8963	.9020	.9307	.8744	.8670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 204 / 11 kV Polefactory

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1677	.1677	.1677		.2896
2	.1524	.1524	.1677	.1677	.1524		.2896
3	.1524	.1524	.1677	.1524	.1524		.2743
4	.1524	.1524	.1677	.1524			.2743
5	.1524	.1524	.1677	.1524			.2743
6	.1524	.1524	.1524	.1524			.2591
7	.1372		.1219	.1372			.2439
8	.1067	.1067	.1219	.0914			.1981
9	.0914	.0914	.1067	.0914			.1981
10	.0914	.0914	.1219	.1067			.1981
11	.0914	.1067	.1219	.0914			.2134
12	.0762	.061	.1219	.0914			.2286
13	.1067	.0762	.1372	.1067			.2286
14	.1067	.1067	.1372	.1067			.2439
15	.1067	.0914	.1524	.1067			.2439
16	.1067	.0914	.1219	.1067			.2439
17	.1067	.0914	.1219	.0914			.2134
18	.1219	.1067	.1219	.1067		.2439	.2439
19	.1677	.1677	.1829	.1677		.3658	.3506
20	.1829	.1829	.1829	.1829		.3506	.3506
21	.1677	.1981	.1981	.1981		.3506	.3506
22	.1829	.1981	.1981	.1981		.3353	.3353
23	.1677	.1829	.1829	.1829		.3201	.3048
24	.1677	.1677	.1677	.1677		.3048	.2896
Max	.1829	.1981	.1981	.1981	.1677	.3658	.3506
Min	.0762	.061	.1067	.0914	.1524	.2439	.1981
Avg	.1334	.1319	.1505	.1365	.1575	.3244	.2642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 205 / 11 KV Ropeway

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.3048	.381	.381	
2	.381	.381	.3048	.381	.3048	
3	.381	.381	.3048	.381	.3048	
4	.381	.381	.3048	.3048	.3048	
5	.3048	.381	.3048	.3048	.3048	
6	.3048	.3048	.3048	.3048	.3048	
7	.3048	.3048	.2286	.3048	.3048	
8	.3048	.3048	.2286	.3048	.3048	
9	.3048	.3048	.2286	.3048	.2286	
10	.3048	.3048	.2286	.3048	.3048	
11	.3048	.3048	.2286	.3048	.2286	.2286
12	.3048	.3048	.3048	.3048	.3048	.2286
13	.3048	.3048	.3048	.3048	.3048	.2286
14	.3048	.2286	.3048	.3048	.0762	.2286
15	.3048	.2286	.2286	.3048		.2286
16	.2286	.2286	.2286	.3048		.2286
17	.3048	.2286	.3048	.3048		.2286
18	.381	.2286	.3048	.3048		.2286
19	.381	.381	.381	.381		.381
20	.4572	.381	.381	.4572		.381
21	.4572	.381	.381	.381		.381
22	.4572	.381	.381	.381		.381
23	.381	.381	.381	.381		.3048
24	.381	.381	.381	.381		.3048
Max	.4572	.381	.381	.4572	.381	.381
Min	.2286	.2286	.2286	.3048	.0762	.2286
Avg	.3461	.3239	.3016	.3366	.2830	.2830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164034 / 33 KV MAHADULA

Feeder No / Name : 209 / 11 kV Koradi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621	.8383	.9145	.7621	.6859
2	.7621	.6859	.7621	.7621	.8383	.7621	.6859
3	.6859	.6859	.6859	.7621	.8383	.7621	.6859
4	.6859	.6859	.6859	.7621	.8383	.7621	.6859
5	.7621	.6859	.6859	.7621	.8383	.7621	.6859
6	.7621	.7621	.6859	.7621	.8383	.7621	.6859
7	.7621	.6859	.6859	.7621	.7621	.8383	.6859
8	.6859	.6859	.6097	.6097	.7621	.7621	.6097
9	.6859	.6859	.6859	.6859	.6859	.6097	.6097
10	.6859	.6859	.6859	.6859	.7621	.6097	.6859
11	.7621	.6859	.6859	.6859	.7621	.6097	.6859
12	.6859	.6859	.6859	.6859	.7621	.5335	.6859
13	.6859	.6859	.7621	.7621	.7621	.4572	.6859
14	.6859	.6859	.7621	.7621	.7621	.4572	.6859
15	.6859	.6859	.6859	.7621	.7621	.4572	.6859
16	.6859	.6859	.7621	.7621	.7621	.5335	.6859
17	.6859	.6859	.6859	.6859	.6859	.4572	.6097
18	.7621	.6097	.6859	.6859	.6859	.5335	.6097
19	.8383	.9145	.7621	.9145	.8383	.7621	.8383
20	.8383	.9145	.8383	.9145	.9145	.7621	.8383
21	.8383	.9145	.8383	.9145	.9145	.7621	.8383
22	.8383	.8383	.9145	.9145	.9145	.7621	.8383
23	.8383	.8383	.9145	.9145	.9145	.7621	.8383
24	.7621	.8383	.8383	.9145	.8383	.7621	.8383
Max	.8383	.9145	.9145	.9145	.9145	.8383	.8383
Min	.6859	.6097	.6097	.6097	.6859	.4572	.6097
Avg	.7431	.7367	.7399	.7780	.8066	.6668	.7113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 203 / Silewara

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17
HR	Load (MW)
1	2.2862
2	3.658
3	3.4675
4	3.9247
5	3.5437
6	4.1533
7	4.039
8	2.7054
9	2.8578
10	4.6106
11	5.3346
12	5.2584
13	4.8011
14	4.763
15	4.1152
16	2.7054
17	2.5149
18	3.315
19	3.2007
20	5.4489
21	5.7537
22	5.6775
23	5.144
24	2.7435
Max	5.7537
Min	2.2862
Avg	4.0009

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 204 / Walni II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17
HR	Load (MW)
1	1.5242
2	1.5242
3	1.5242
4	1.5242
5	1.5242
6	1.829
7	1.2193
8	1.829
9	1.829
10	1.6766
11	1.6766
12	1.6766
13	1.5242
14	1.3717
15	1.3717
16	1.3717
17	.7621
18	1.2193
19	1.829
20	1.9814
21	1.9814
22	1.9814
23	1.829
24	1.6766
Max	1.9814
Min	.7621
Avg	1.5940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

KHAPARKHEDA S/DN.[364] BU 0364

Substation No/ Name :- 164036 / 33 KV ROHANA SUBSTATION

Feeder No / Name : 206 / 11 KV D point Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	15-SEP-17
HR	Load (MW)
1	.2096
2	.2096
3	.2096
4	.1905
5	.1905
6	.1905
7	.1905
8	.1905
9	.1143
10	.1143
11	.1334
12	.2096
13	.1905
14	.1524
15	.1334
16	.1143
17	.1334
18	.0572
19	.1143
20	.1524
21	.1905
22	.2096
23	.2286
24	.2286
Max	.2286
Min	.0572
Avg	.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 201 / 11KV PARSEONI URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17
HR	Load (MW)
1	.5335
2	.4572
3	.4572
4	.4572
5	.4572
6	.5335
7	.4572
10	.6859
11	.5335
12	.5335
13	.6097
14	.5335
15	.5335
16	.5335
17	.4572
18	.6097
19	.6097
20	.6097
21	.6097
22	.5335
23	.5335
24	.5335
Max	.6859
Min	.4572
Avg	.5369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 203 / 11 KV SURYLATA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3285	.3437	.349	.3589	.3346	.3506	
2	.3292	.3414	.3445	.3567	.333	.349	
3	.3285	.3406	.3437	.3178	.3338	.3498	.0038
4	.3269	.3384	.3429	.3147	.3315	.3483	
5	.3262	.3361	.3406	.3193	.3307	.3483	
6	.3368	.3376	.3414	.3216	.33	.3597	
7	.3125	.3079	.3086	.2911	.3025	.314	
8	.2477	.2606	.2622	.2195	.2385	.16	
9	.2408	.2393	.2484	.205	.2225		.0069
10	.2088	.2187	.2393	.2164	.208	.0107	
11	.2126	.2027	.2378	.205	.1974		
12	.1837	.1707	.2172	.2416	.2225		.1959
13	.2004	.1616	.2187	.2446	.2195	.2027	.1753
14	.2164	.1837	.234	.2599	.2362	.202	.1722
15	.2149	.205	.2408	.2477	.2477	.2088	.1875
16	.208	.1951	.1707	.2241	.2058	.2088	.0168
17	.1974	.1524	.1585	.2119	.0076	.205	.1837
18	.221	.1913		.2332	.2423	.2462	.2614
19	.3749	.3673	.0678	.3673	.3643	.3589	.3467
20	.3887	.3902	.3925	.4001	.3681	.3544	.3605
21	.3727	.3841	.3902	.3871	.3559	.349	.3605
22	.3734	.3788	.3818	.3216	.3612	.3521	.3551
23	.3658	.3688	.3742	.3368	.3605	.3437	.3498
24	.3498	.3544	.3681	.3376	.3528	.1997	.3376
Max	.3887	.3902	.3925	.4001	.3681	.3597	.3605
Min	.1837	.1524	.0678	.205	.0076	.0107	.0038
Avg	.2861	.2821	.2858	.2891	.2795	.2772	.2209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164017 / 33KV PARSHIONI

Feeder No / Name : 205 / 11 kV MIDC Industrial
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	15-SEP-17	16-SEP-17	17-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381
2	.381	.381	.381
3	.3048	.381	.381
4	.3048	.381	.381
5	.381	.381	.381
6	.381	.381	.381
7	.3048	.381	.381
8	.3048	.3048	.3048
9	.3048	.3048	.3048
10	.381	.381	.4572
11	.381	.381	.5335
12	.381	.381	.381
13	.381	.381	.4572
14	.381	.4572	.4572
15	.381	.381	.4572
16	.381	.381	.4572
17	.381	.381	.381
18	.3048	.381	.3048
19	.381	.4572	.381
20	.381	.4572	.381
21	.381	.4572	.381
22	.381	.381	.4572
23	.381	.4572	.4572
24	.381	.381	.381
Max	.381	.4572	.5335
Min	.3048	.3048	.3048
Avg	.3620	.3905	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 201 / Bitoli AG Separated

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0914	.1219	.0914	
2					.1219	.0914	
3				.0914	.0914	.0914	
4				.0914	.1219	.0914	
5				.0914	.1219	.0914	
6				.0914	.0914	.0914	
7				.0914	.0914	.0914	
8				.0914	.1219	.0914	
9				.0914	.1219	.0914	
10				.0914	.1219		.061
11	.0914	.1219	.0914				.061
12	.1219	.1219	.1524				.061
13	.1219	.1524	.1524				.0914
14	.1219	.1524	.1829				.0914
15	.1219	.1524	.2134				.0914
16	.1524	.1524	.1829				.0914
17	.1524	.1524	.0914				.061
18	.1219	.1524	.0914				.061
Max	.1524	.1524	.2134	.0914	.1219	.0914	.0914
Min	.0914	.1219	.0914	.0914	.0914	.0914	.061
Avg	.1257	.1448	.1448	.0914	.1128	.0914	.0745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

PARSIONI S/DN.[531] BU 0531

Substation No/ Name :- 164033 / 33 KV NAVEGOAN S/STN

Feeder No / Name : 204 / Bitoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.3429	.381	.3429	.3429	.3429
2	.3429	.3429	.3429		.3429	.3429	.3048
3	.3429	.3429	.3429	.3429	.3048	.3429	.3048
4	.3429	.3429	.3429	.3429	.3048	.3429	.3048
5	.3048	.3429	.3429	.3429	.3048	.3429	.3048
6	.3048	.3429	.381	.3429	.3429	.3429	.3429
7	.2667	.2667	.3048	.2667	.2667	.3429	.3048
8			.1524	.2286	.2286	.2667	.2286
9				.1905	.2667	.2286	.2286
10	.2286	.2667	.2667	.1905	.2286	.1905	.1905
11	.2286	.2667	.2667				.1524
12	.1905	.2286	.2286	.1143	.1524	.1143	.0762
13	.1905	.1905	.2286	.2286	.3048	.1524	.1524
14	.1524	.2286	.2667	.2286	.3048	.1905	.1524
15	.1524	.2286	.2667	.2286	.3048	.1524	.1905
16	.1524	.1524		.1905	.1524	.1524	.1905
17	.1905						.1905
18	.2667	.2286	.2286		.0381	.2667	.1905
19	.381	.4191	.4191	.4191	.381	.4191	.381
20	.4191	.4191	.4572	.4572	.381	.4191	
21	.4191	.4191	.4191	.4191	.381	.381	
22	.4191	.4191	.4191		.381	.381	
23	.381	.381	.4191		.381	.381	
24	.381	.381	.381		.3429	.3429	
Max	.4191	.4191	.4572	.4572	.381	.4191	.381
Min	.1524	.1524	.1524	.1143	.0381	.1143	.0762
Avg	.2909	.3121	.3248	.2891	.2927	.2927	.2386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 203 / patsaongi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5335	.5335	.5335	.6097	.5335	
2	.4572	.5335	.5335	.5335	.6097	.5335	.381
3	.4572	.4572	.5335	.3048	.5335	.5335	.381
4	.4572	.4572	.5335	.4572	.5335	.5335	.381
5	.4572	.4572	.5335	.4572	.5335	.5335	.381
6	.4572	.5335	.5335	.4572	.5335	.5335	.3048
7	.4572	.4572	.4572	.4572	.5335	.5335	.3048
8	.381	.381	.4572	.381	.4572	.4572	.3048
9	.381	.381	.4572	.3048	.4572	.381	.3048
10	.381	.381	.3048	.381	.4572	.381	.3048
11	.381	.381	.381	.381	.4572	.381	.381
12	.381	.381	.5335	.4572	.4572	.381	.381
13	.381	.381	.4572	.4572	.4572	.381	.3048
14	.3048	.381	.4572	.4572	.4572	.3048	.3048
15	.381	.381	.4572	.4572	.4572	.3048	.381
16	.381	.381	.4572	.381	.4572	.3048	.381
17	.3048	.381	.4572	.381	.381	.3048	.381
18	.381	.381	.3048	.381	.381	.3048	.381
19	.4572	.6097	.5335	.6097	.5335	.5335	.5335
20	.6097	.6859	.6097	.6859	.6097	.5335	.5335
21	.6097	.6859	.6097	.6859	.6097	.5335	.5335
22	.6097	.6859	.6097	.6859	.6097	.5335	.5335
23	.5335	.6097	.6097	.6097	.6097	.5335	.5335
24	.5335	.5335	.6097	.6097	.5335	.1524	.4572
Max	.6097	.6859	.6097	.6859	.6097	.5335	.5335
Min	.3048	.381	.3048	.3048	.381	.1524	.3048
Avg	.4413	.4763	.4985	.4795	.5112	.4350	.3943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 15-SEP-17 and 21-SEP-17

NAGPUR ZONE[069]

NAGPUR (R) CIRCLE[650]

NAGPUR II DIVISION[655]

SAONER[365]

BU 0365

Substation No/ Name :- 164046 / 33 KV saoner substation

Feeder No / Name : 206 / kelod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-SEP-17	16-SEP-17	17-SEP-17	18-SEP-17	19-SEP-17	20-SEP-17	21-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.5335	.5335	.5335	.5335	.4572
2	.4572	.4572	.5335	.3048	.2286	.2286	.4572
3	.4572	.4572	.5335	.0762	.2286	.2286	.4572
4	.4572	.4572	.4572	.2286	.2286	.2286	.4572
5	.4572	.4572	.4572	.1524	.2286	.2286	.4572
6	.381	.381	.381	.1524	.2286		.381
7	.3048	.3048	.3048	.1524	.2286	.2286	.3048
8	.2286	.2286	.2286	.1524	.1524	.2286	.2286
9	.1524	.1524	.1524	.2286	.1524	.1524	.1524
10	.1524	.1524	.0762	.2286	.2286	.2286	.1524
11	.1524	.1524	.1524	.2286	.2286	.2286	.1524
12	.1524	.1524	.1524	.2286	.2286	.2286	.1524
13	.1524	.1524	.1524	.2286	.3048	.2286	.1524
14	.0762	.1524	.1524	.3048	.3048	.2286	.1524
15	.1524	.1524	.1524	.3048	.3048	.1524	.1524
16	.1524	.0762	.2286	.2286	.3048	.1524	.1524
17	.0762	.1524	.1524	.2286	.2286	.1524	.1524
18	.0762	.1524	.1524	.2286	.2286	.2286	.1524
19	.1524	.381	.3048	.3048	.381	.3048	.3048
20	.4572	.4572	.4572	.4572	.4572	.4572	.381
21	.4572	.5335	.4572	.5335	.5335	.5335	.4572
22	.4572	.5335	.5335	.5335	.5335	.5335	.4572
23	.4572	.5335	.5335	.5335	.5335	.5335	.4572
24	.4572	.5335	.5335	.5335	.5335	.4572	.4572
Max	.4572	.5335	.5335	.5335	.5335	.5335	.4572
Min	.0762	.0762	.0762	.0762	.1524	.1524	.1524
Avg	.2889	.3175	.3239	.2953	.3143	.2916	.3016