

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 102001 / 11 KV Allapalli Switch Yard

Feeder No / Name : 201 / 11 KV AHERI-R- SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	1.0269	.9145	1.0829	1.0059	1.1203	1.0974
2	.9328	1.0082	.8962	1.0829	.9877	1.0829	1.0791
3	.9328	1.0082	.8779	1.0456	.9694	1.0642	1.0608
4	.9145	.9709	.8596	1.0456	.9328	1.0269	1.0425
5	.9145	.9709	.8413	1.0269	.9328	1.0082	1.0059
6	.8596	.924	.8596	.9522	.8962	.9709	1.0059
7	.8048	.8316	.8048	.9522	.8962	.499	1.0425
8	.7682	.7023	.823	.9055	.8962	.499	.9145
9	.8048	.7133	.8962	.8596	.9511	.7316	.9328
10	.7499	.8048		.4572		.7682	.8962
11	.7682	.567	.7682		.8779	.7499	.8962
12	.7682	.5487	.8596		.823	.823	.8779
13	.695		.8596	.8779	.8413	.9145	.9145
14	.7133		.8413	.8413	.8779	.9328	.9145
15	.3475	.3292	.8596	.823	.8779	.9694	.8413
16	.5853	.4207	.695	.7499	.823	.9877	.8596
17	.6219	.4938	.8048	.8048	.8316	.9328	.7682
18	.695		.7133	.8962	.924	1.0425	.8413
19	1.1203	1.0608	1.1088	1.2071	1.0534	1.2803	1.1706
20	1.3443	1.3535	1.4377	1.4815	1.4563	1.4632	1.4266
21	1.3256	1.2986	1.3817	1.4266	1.4377	1.4632	1.4266
22	1.1389	1.1888	1.251	1.2803	1.307	1.3535	1.2986
23	1.0456	1.0608	1.1389	1.134	1.1763	1.2803	1.2803
24	.9877	1.0269	.9511	1.1016	1.0974	1.1389	1.2437
Max	1.3443	1.3535	1.4377	1.4815	1.4563	1.4632	1.4266
Min	.3475	.3292	.695	.4572	.823	.499	.7682
Avg	.8662	.8719	.9323	1.0016	.9945	1.0043	1.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 102001 / 11 KV Allapalli Switch Yard

Feeder No / Name : 202 / 11 KV AHERI-T- SCHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	1.6057	1.2803	1.531	1.3717	1.307	1.3717
2		1.6057	1.262	1.4937	1.3535	1.2696	1.3535
3		1.5684	1.2254	1.4937	1.3352	1.2323	1.3352
4	1.4266	1.531	1.1888	1.419	1.3169	1.2136	1.3169
5	1.3717	1.531	1.1706	1.3817	1.2986	1.2136	1.2803
6	1.2986	1.4377	1.134	1.251	1.2803	1.2136	1.2437
7	1.1888	1.2567	1.0974	1.2696	1.262	1.1088	1.1888
8	1.0974	1.2012	1.0242	1.0903	1.2437	1.0534	1.1888
9	1.0425	1.1706	1.0791	1.0791	1.0791	1.0608	1.1706
10	1.0791	1.1888		1.0974	1.0425	1.0791	1.1523
11	1.1706	1.1157	1.134		.9145	1.0608	1.0974
12	1.1888	1.1523	1.1706		1.0974	1.0791	1.0791
13	.9145	1.134	1.2437	1.2437	1.0974	1.0608	1.0974
14	.8962	1.1157	1.2254	1.2254	1.134	1.0791	1.0974
15	.4938	.9511	1.1888	1.0974	1.0974	1.134	1.1523
16	.5121		1.1706	1.0974	1.1706	1.0425	1.0974
17	.5304	1.0791	1.134	1.0242	1.0349	1.0791	1.1157
18	1.2437	1.0425	1.0791	1.0425		1.0974	1.0425
19	1.6617	1.2986	1.3306	1.262	1.4563	1.2986	1.5729
20	1.8111	1.4998	1.5684	1.5364	1.6244	1.4998	1.5912
21	1.8858	1.5364	1.6057	1.5546	1.587	1.5546	1.5912
22	1.8484	1.5089	1.5497	1.4998	1.5497	1.5912	1.5729
23	1.6991	1.39	1.4937	1.4815	1.5123	1.5546	1.5546
24	1.5364	1.6244	1.3535	1.5497	1.4632	1.4377	1.5181
Max	1.8858	1.6244	1.6057	1.5546	1.6244	1.5912	1.5912
Min	.4938	.9511	1.0242	1.0242	.9145	1.0425	1.0425
Avg	1.2462	1.3281	1.2482	1.3055	1.2749	1.2217	1.2826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 102001 / 11 KV Allapalli Switch Yard

Feeder No / Name : 203 / 11 KV ETTAPALLI

Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1829	.2054	.2743
2		.1829	.2054	.2743
3		.1646	.1867	.2561
4		.1463	.1867	.2561
5		.1463	.1867	.2378
6		.128	.1867	.2378
7		.128	.1294	.1829
8		.128	.1663	.1829
9		.128	.1463	.1829
10		.1463	.1463	.1829
11		.1463	.1463	.1646
12		.1646	.1463	.1463
13	.1829	.1463	.1463	.1463
14	.1463	.1463	.1463	.1646
15	.1463	.1463	.1646	.1646
16	.1646	.2195	.1646	.2195
17	.1646	.1478	.1646	.1097
18	.2012	.1478	.1646	.1463
19	.2378	.2218	.2012	.1463
20	.3292	.3174	.2926	.2561
21	.3109	.2987	.3292	.2743
22	.3109	.2987	.3109	.2926
23	.2926	.2614	.3109	.2743
24		.2561	.2614	.2926
Max	.3292	.3174	.3292	.2926
Min	.1463	.128	.1294	.1097
Avg	.2261	.1833	.1957	.2111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 102001 / 11 KV Allapalli Switch Yard

Feeder No / Name : 204 / 11 KV ALLAPALLI SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.2696	.8859	1.0829	.8048	.7468	.7316
2	1.134	1.2323	.8048	1.0829	.7865	.7282	.7133
3	1.0974	1.2323	.8779	1.0456	.7682	.7095	.695
4	1.0791	1.1949	.8596	1.0456	.7499	.6908	.6767
5	1.134	1.1763	.8413	1.0269	.7316	.6908	.6584
6	.9877	1.1016	.823	.9896	.7133	.6908	.6401
7	.9328	.9979	.8048	.9149	.695	.6099	.6584
8	.8596	.8501	.7499	.7762	.6767	.6283	.695
9	.8779	.8962	.823	.7682	.6036	.5487	.7133
10	.9328	.8779		.8048	.6036	.567	.695
11	.9511	.8596	.9511		.5853	.6219	.6401
12	.9694	.8962	.8596		.6219	.6401	.6219
13	.9877	.9145	.8779	.7316	.6401	.6219	.6219
14	1.0059	.9145	.8962	.7316	.6584	.6219	.6219
15	.9877	.7682	.8962	.7133	.6036	.6401	.6584
16	.9877	.8048	.8779	.695	.6584	.7133	.6401
17	.9511	.7499	.8048	.6401	.5729	.6401	.6036
18	.9145	.7499	.823	.6401	.6283	.6219	.8413
19	1.2323	.9145	1.0164	.7133	.8402	.8048	.8413
20	1.1203	1.1157	1.2883	.7865	.9335	.9328	.8413
21	1.419	1.1157	1.3256	.9328	.9335	.9145	.8596
22	1.419	1.0974	1.251	.9511	.9335	.8779	.8596
23	1.3256	1.0608	1.1576	.8413	.8775	.823	.823
24	1.2437	1.2696	.9511	1.1203	.823	.7842	.7865
Max	1.419	1.2696	1.3256	1.1203	.9335	.9328	.8596
Min	.8596	.7499	.7499	.6401	.5729	.5487	.6036
Avg	1.0717	1.0025	.9325	.8652	.7268	.7029	.7141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 105003 / 66 KV JIMALGATTA

Feeder No / Name : 201 / 11 KV JIMALGATTA

Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-AUG-17	02-AUG-17
HR	Load (MW)	Load (MW)
1	.1829	.0594
2	.1814	
3	.1692	
4	.1646	
5	.1631	
6	.16	
7	.1661	
8	.1509	
22	.0869	
23	.0701	
24	.1799	
Max	.1829	.0594
Min	.0701	.0594
Avg	.1523	.0594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 105003 / 66 KV JIMALGATTA

Feeder No / Name : 202 / 11 KV UMANOOR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.1357
2	.1219
3	.1143
4	.1204
5	.1067
6	.1219
7	.1326
8	.0518
24	.1219
Max	.1357
Min	.0518
Avg	.1141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ALLAPALI S/DN.[343] BU 4343

Substation No/ Name :- 105003 / 66 KV JIMALGATTA

Feeder No / Name : 203 / 11 KV REPANPALLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.2241
2	.221
3	.2027
4	.1859
5	.2164
6	.1829
7	.1692
8	.1692
22	.2042
23	.2103
24	.2317
Max	.2317
Min	.1692
Avg	.2016

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

BHAMARAGAD S/DN.[828] BU 4828

Substation No/ Name :- 104007 / 33 KV BHAMRAGAD

Feeder No / Name : 201 / 11 KV BHAMRAGAD

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.2926	.3109	.2926	.2772	.1848	.2427
2	.2743	.2743	.2743	.2743	.2587	.1848	.2241
3	.2743	.2743	.2561	.2561	.2402	.1848	.2241
4	.2561	.2743	.2378	.2561	.2218	.1848	.2054
5	.2561	.2378	.2012	.2743	.2218	.1848	.2054
6	.2378	.2561	.2195	.2402	.2218	.1848	.2054
7	.2012	.2561	.2195	.2218	.2033	.1663	.2054
8	.1829	.2561	.2195	.2218	.2218	.168	.2054
9	.2012	.2195	.2561	.2587	.2033	.168	.2241
10	.2195	.2195	.2195	.2218	.1848	.2427	.2054
11	.2378	.2378	.2195	.2402	.2033	.2427	.2054
12	.2378	.2378	.2378	.2587	.2402	.2427	.1494
13	.2561	.2561	.2561	.2402	.2218	.2241	.1867
14	.2195	.2561	.2561		.2218	.2054	.1867
15	.1463	.2195	.2195		.2218	.2054	.1867
16	.1829	.2195	.2012		.2218	.168	.2054
17	.2561	.2012	.2012		.2402	.1867	.1867
18	.2561	.2012	.2012		.2587	.2427	.2054
19	.2561	.2926	.2926	.3511	.3326	.2801	.2987
20	.3292	.3658	.3475	.3696	.3142	.3174	.2987
21	.3658	.3475	.3475	.3511	.2218	.2987	.2614
22	.3475	.3292	.3292	.3326	.2033	.2801	.2614
23	.3292	.3109	.3292	.3142	.1848	.2614	.2427
24	.3109	.3109	.3109	.3109	.2957	.1848	.2614
Max	.3658	.3658	.3475	.3696	.3326	.3174	.2987
Min	.1463	.2012	.2012	.2218	.1848	.1663	.1494
Avg	.2553	.2644	.2568	.2782	.2349	.2164	.2202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

BHAMARAGAD S/DN.[828] BU 4828

Substation No/ Name :- 104007 / 33 KV BHAMRAGAD

Feeder No / Name : 202 / 11 KV PERIMILI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.298	.2279	.2629	.2601	.2254	.2601
2	.2454	.2804	.2103		.2427	.208	.2427
3	.2279	.2454	.2103	.0526	.2254	.208	.208
4	.2279	.2279	.1928	.0526	.208	.1907	.208
5	.2279	.2279	.1928	.0526	.208	.1734	.208
6	.2103	.2279	.1928	.156	.208	.1734	.208
7	.1753	.1753	.1402	.1214	.1907	.1734	.1907
8	.1578	.1578	.1402	.104	.1387	.156	.156
9	.1402	.1578	.1227	.0347	.1387	.1387	.1387
10	.1402	.1402	.1227	.0347	.1734	.1387	.1387
11	.1227	.0526	.1227	.0347	.1387	.1387	.1387
12	.1227	.0701	.1227	.1214	.1387	.1387	.156
13	.0876	.1052	.1227	.104	.1387		.1214
14	.1227		.1227		.1214	.1214	.0867
15	.1578	.0701	.1402		.1214	.1214	.0867
16	.1402	.0701	.1402		.1214	.0867	.0867
17	.1402	.1052	.1227		.1214	.1387	.0867
18	.1578	.1402	.1402		.1734	.1734	.1734
19	.2804	.2279	.2454	.3121	.3294	.3121	.2774
20	.3506	.2804	.3681	.3641	.3641	.3467	.3467
21	.3856	.2629	.3506	.3121	.3121	.3294	.3641
22	.3506	.2454	.333	.2947	.2774	.3121	.3294
23	.3506	.2454	.3155	.2774	.2601	.2947	.3121
24	.2804	.333	.2454	.2804	.2601	.2427	.2774
Max	.3856	.333	.3681	.3641	.3641	.3467	.3641
Min	.0876	.0526	.1227	.0347	.1214	.0867	.0867
Avg	.2111	.1890	.1935	.1651	.203	.1975	.2001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

BHAMARAGAD S/DN.[828] BU 4828

Substation No/ Name :- 104007 / 33 KV BHAMRAGAD

Feeder No / Name : 203 / 11kV Kothi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.132	.1097	.132	.1132	.1132	.1132
2	.132	.1132	.1132	.1132	.1132	.1132	.1132
3	.1132	.1132	.1132	.1132	.1132	.0943	.1132
4	.1097	.1132	.1132	.1132	.1132	.0943	.1132
5	.1132	.1132	.1132	.1132	.1132	.0943	.1132
6	.1132	.1132	.1132	.1132	.1132	.0943	.1132
7	.0943	.0754	.0754	.0754	.0754	.0943	.0943
8	.0943	.0566	.0019	.0754	.0566	.0943	.0566
9	.0754	.0566	.0019	.0038	.0377	.0754	.0566
10	.0151	.0038	.0019	.0038	.0754		.0566
11	.0038	.0038	.0019	.0038	.0754		.0566
12	.0038	.0038	.0038	.0038	.0038		.0754
13	.0754	.0038	.0038	.0038	.0038	.0566	.0566
14	.0754	.0038	.0038		.0057	.0566	.0566
15	.0377	.0038	.0038		.0057	.0566	.0566
16	.0377	.0038	.0754		.0057	.0057	.0566
17	.0057	.0566	.0754		.0057	.0057	.0566
18	.0075	.0566	.0754		.0094	.0075	.0754
19	.132	.132	.1132	.132	.0283	.132	.1132
20	.132	.132	.1509	.1509	.1509	.1509	.132
21	.1509	.132	.1509	.1509	.132	.132	.132
22	.1509	.132	.132	.132	.132	.132	.132
23	.132	.132	.132	.132	.132	.132	.132
24	.132	.132	.132	.132	.132	.1132	.1132
Max	.1509	.132	.1509	.1509	.1509	.1509	.132
Min	.0038	.0038	.0019	.0038	.0038	.0057	.0566
Avg	.0862	.0758	.0755	.0893	.0728	.0880	.0912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 201 / 11 KV CHAMORSHI FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3817	1.2437	1.4146	1.2437	1.2437	1.2071
2		1.3676	1.2437	1.3817	1.2437	1.2071	1.1888
3		1.3306	1.1888	1.3817	1.1888	1.1584	1.1888
4		1.307	1.1888	1.3491	1.0974	1.1157	1.0974
5		1.2696	1.1706	1.3169	1.0974	1.0608	1.0608
6		1.1016	.9694	1.363	1.0608	1.0242	1.0242
7		.8962	.8048	.9619	.8048	.8596	.8962
8		.8775	.7682	.9149	.9145	.8779	.8413
9		.9145	.9145	.9808	.9511	.9619	.8596
10		.9877	.9709	.9877	.9896	.8939	.8779
11		.9511	1.0456	1.0059	1.0642	1.0185	.7023
12		1.0242	1.0562	1.0608	.7356	1.0082	.9145
13		1.0608	1.0082	1.1157	1.0456	.9335	.8596
14		1.0974	1.0642	1.0425	1.0642	.9808	.8775
15		1.0974	1.1203	1.0974	1.134	1.0082	.8688
16		.9877	1.1203		1.0829	.9619	.9231
17	.9997	.9877	1.0829	1.0608	1.0562	.8962	.9328
18	.9335	.9511	1.0269	1.0242	.905	.8413	.8326
19	1.1016	1.0608	1.2936	1.0974	1.0642	1.0974	1.0242
20	1.3203	1.262	1.4563	1.2437	1.307	1.2437	1.1273
21	1.3443	1.3535	1.4901	1.2803	1.3957	1.2437	1.1458
22	1.4563	1.3169	1.4937	1.39	1.3894	1.3169	1.1389
23	1.4712	1.3352	1.4563	1.3169	1.3169	1.262	1.0829
24		1.4003	1.2803	1.419	1.2803	1.2803	1.2437
Max	1.4712	1.4003	1.4937	1.419	1.3957	1.3169	1.2437
Min	.9335	.8775	.7682	.9149	.7356	.8413	.7023
Avg	1.2324	1.1383	1.1441	1.1829	1.1014	1.0623	.9965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 203 / 11 KV SONAPUR FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4755	.4207	.5415	.3841	.4572	.4207
2	.3658	.439	.4207	.5304	.3658	.4572	.4024
3	.3475	.4298	.4024	.5121	.3658	.439	.4024
4	.3475	.4024	.4024	.4938	.3658	.439	.4024
5	.3292	.4024	.4024	.5121	.3292	.439	.3841
6	.3109	.3982	.4755	.3681	.3292	.4207	.3841
7	.3109	.4163	.4755	.4557	.3475	.4572	.3658
8	.3658	.4294	.4572	.4733	.4024	.4572	.439
9	.3841	.5121	.4024	.4733	.4207	.5487	.4572
10	.4477	.4207	.2149	.5121	.5611	.567	.3725
11		.439	.5121	.4207	.5434	.5552	.3932
12	.4477	.4572	.5258	.439	.1402	.5784	.443
13	.4031	.4938	.5258	.4207	.4119	.4733	.426
14	.5373	.4755	.5552	.3658	.4024	.5258	.443
15	.5788	.4755	.5609	.4024	.5601	.543	.4334
16			.4298	.3658	.5258	.4908	.3768
17	.4755	.4207	.394	.3658	.4344	.4572	.3856
18	.462	.4572	.4294	.2926	.4163	.3841	
19	.5014	.4207	.4382	.3475	.4435	.3841	.3475
20	.5544	.4572	.5975	.4207	.543	.4572	.4024
21	.5415	.4755	.5792	.5121	.543	.4572	.3658
22	.5959	.4572	.5434	.4024	.5373	.439	.4251
23	.5041	.439	.5194	.4024	.4938	.4075	.3921
24	.3658	.4854	.4024	.5304	.3841	.4755	.4207
Max	.5959	.5121	.5975	.5415	.5611	.5784	.4572
Min	.3109	.3982	.2149	.2926	.1402	.3841	.3475
Avg	.4338	.4469	.4620	.4400	.4271	.4713	.4037

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 204 / 11 KV GHOT / AMGAON FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.5068	.4938	.5975	.4572	.4572	.5121
2	.439	.4706	.4938	.5609	.4572	.439	.4755
3	.4207	.4755	.4938	.5552	.439	.4207	.4755
4	.4024	.439	.4755	.5194	.4024	.4024	.439
5	.3658	.439	.4755	.5014	.4024	.3841	.4344
6	.3475	.3982	.3292	.3658	.3658	.3658	.394
7	.2743	.3801	.3292	.3258	.2743	.3841	.3681
8	.2378	.3224	.3292	.3109	.3109	.3292	.3475
9	.3841	.3109	.3841	.3109	.3292	.3109	.4024
10	.3045	.4024		.3475	.2865	.3045	.3641
11		.3109	.3582	.2926	.2686	.394	.3155
12	.3142	.3109	.4024	.3479	.2507	.1417	.3189
13	.3174	.3658	.0543	.3658	.2865	.2454	.3544
14	.3326	.3658	.4024	.3841	.2103	.2629	.3109
15	.2972	.4024	.4382	.3841	.2534	.4119	.2454
16		.3109	.3734	.2926	.2103	.3856	.2601
17	.4755	.2378	.3547	.2743	.2172	.3841	.2279
18	.6219	.3292	.3292	.2743	.2865	.3292	1.0341
19	.6535	.3841	.4908	.4024	.4119	.5487	1.5729
20	.5544	.6219	.6135	.567	.6089	.6219	1.6817
21	.6161	.5853	.6401	.5853	.5434	.567	
22	.6722	.5487	.6335	.3658	.5258	.567	.2957
23	.5304	.4938	.5784	.5068	.4938	.567	.5041
24	.4572	.5014	.4572	.5975	.4755	.4755	.5121
Max	.6722	.6219	.6401	.5975	.6089	.6219	1.6817
Min	.2378	.2378	.0543	.2743	.2103	.1417	.2279
Avg	.4307	.4131	.4318	.4182	.3653	.4042	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 205 / 11kV Expres Feeder Sharda SHEDDABLE FEEDER HAVING WEEKLY
R.M. Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2308	.1036	.3658	.2103	.1829		.0914
2	1.2071	.1067	.3658	.1372	.1829		.1463
3	1.1888	.1067	.3658	.1372	.1829		.1463
4	1.1706	.1463	.1829	.1219	.3292		.1463
5	1.134	.1448	.1463	.125	.3258		.1463
6	1.1157	.1143	.1463	.3688	.3658		.1463
7	.823	.1372	.1646	.2824	.3658		.1646
8	.823	.1189	.1463	.2401	.3292	.1829	.1829
9	.9511	.1463	.1463	.2987	.439	.1219	.1829
10	1.0562	.1463	.1494	.2195	.4656	.1296	.1898
11		.1463	.1097	.3658	.3506	.1143	.1187
12	.7468	.1646		.4024	.181	.1562	.1509
13	1.0082	.1463	.0867	.4207	.1791	.1524	.1957
14	1.2136	.2195	.1402	.3841	.1448	.1097	.2035
15	1.4335	.2561	.0975	.1829		.1097	.2804
16		.1463	.0827	.2012		.1128	.4527
17	.1494	.1646	.2507	.1829		.1646	.4527
18	.1189	.3292	.4024	.3292		.1646	.6224
19	.1189	.4572	.4477	.3658		.1829	.6348
20	.1219	.1829	.4298	.4024		.1646	.3547
21	.1143	.3841	.4298		.1791	.1646	.3206
22	.1494	.1829	.4207	.4024	.1829	.1646	.5975
23	.1372	.2195	.3174	.3155	.3109	.1646	.2241
24	1.3717	.1448	.1829	.3045	.181	.1829	.1463
Max	1.4335	.4572	.4477	.4207	.4656	.1829	.6348
Min	.1143	.1036	.0827	.1219	.1448	.1097	.0914
Avg	.7902	.1840	.2425	.2783	.2710	.1496	.2624

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 401 / 33KV I/C CHAMORSHI

Feeder KV- 33 / OUTGOING

DATE	06-AUG-17
HR	Load (MW)
1	.5487
2	.439
3	.439
4	.439
5	.439
6	1.1523
7	.6036
Max	1.1523
Min	.439
Avg	.5801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 402 / 33KV GHOT FEEDER

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.3434	2.3045	2.4177	2.2497	2.4143	2.524
2		2.2862	2.3045	2.6029	2.1948	2.3045	2.3594
3		2.1719	2.3045	2.5463	2.0851	2.2497	2.2497
4		2.0576	2.3045	2.4646	1.9753	2.1399	2.1948
5		1.9433	2.2497	2.4086	1.9753	2.0302	2.1948
6		1.8861	1.8656	2.0725	1.9753	1.9204	2.3045
7		2.0005	1.8656	1.9605	1.7558	1.701	2.1948
8		2.0851		2.1948	1.9204	2.3045	2.4691
9				2.2965	2.0851	.9671	2.4143
10		.5487			1.7878	1.9044	1.749
11		.5487			2.0165	2.1845	1.4752
12		.2195			1.9239	2.1502	2.1365
13		.2195			2.2291	2.32	2.2634
14		.4344			2.2068	2.1719	2.2382
15		.439			2.4006	2.1719	2.0119
16		1.1523			2.0936	1.7147	1.9839
17		.3292			2.2497	2.0302	
18		.3292	2.2291		2.0936	2.1948	.2984
19			2.915	2.2497	2.4577	2.6337	.6722
20	2.8578	2.7435	3.2007	2.6886	3.0247	3.1276	1.2883
21	2.8567	2.7984	3.1436	2.5789	2.8858	3.0178	1.9605
22	2.4143	2.6337	2.8006	2.524	2.7435	2.7435	2.2965
23	2.4394	2.3594	2.6863	2.3045	2.6337	2.5789	2.1285
24		2.3525	2.3045	2.6863	2.2497	2.4143	2.6337
Max	2.8578	2.7984	3.2007	2.6886	3.0247	3.1276	2.6337
Min	2.4143	.2195	1.8656	1.9605	1.7558	.9671	.2984
Avg	2.6421	1.5401	2.4628	2.3998	2.2172	2.2246	2.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104002 / 33/11KV CHAMORSHI

Feeder No / Name : 403 / 33KV GADCHIROLI FEEDER

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.3717	1.3169	1.4712	1.3169	1.3717	1.4266
2	1.1523	1.3717	1.4266	1.4712	1.262	1.3169	1.3717
3	1.0974	1.2574	1.2757	1.4289	1.2071	1.262	1.3717
4	1.0425	1.2574	1.3169	1.4289	1.2071	1.2071	1.3169
5	.9877	1.0745	1.3169	1.4289	1.2071	1.0974	1.262
6	.9328	1.086	1.0974	1.2003	1.2071	1.0425	1.262
7	.823	1.0288	.9877	1.2003	.9991	.823	1.1523
8	.9328	1.0745	1.0425	1.3146	1.0974	1.2071	1.3169
9	1.0425		1.2071	1.2574	1.262		1.3169
10	1.1317	1.0425		1.2071	1.2574	.9145	1.1797
11		1.0974	1.1431	.9877	1.1763	.9717	1.262
12	1.1431	1.1523	1.2003	1.2071	1.1317	.9145	1.2226
13	1.086	.6584	1.2003	1.2071	1.1431	.9717	1.2071
14	1.0745	1.086	1.2003	1.2071	1.1431	.9145	1.2489
15	1.0288	1.0631	1.1431	1.0974	1.3146	1.0288	1.0517
16	.9717	1.1523	1.2574		1.2574	.9717	1.0322
17	.9145	.9877	1.2574	1.0974	1.3146	.823	
18	.9717	1.0974	1.2003	1.0974	1.2003	1.1523	
19	1.3443	1.3169	1.4289	1.3169	1.4289	1.5364	
20	1.5203	1.5912	1.8107	1.5912	1.7718	1.701	
21	1.5912	1.6461	1.829	1.5912	1.6409	1.701	.9328
22	1.5432	1.4815	1.6004	1.4266	1.6004	1.5364	1.3169
23	1.4289	1.3169	1.4861	1.3717	1.4266	1.4815	1.2323
24	1.262	1.3717	1.3169	1.4861	1.262	1.3717	1.4815
Max	1.5912	1.6461	1.829	1.5912	1.7718	1.701	1.4815
Min	.823	.6584	.9877	.9877	.9991	.823	.9328
Avg	1.1404	1.1993	1.3070	1.3084	1.2848	1.1878	1.2482

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104012 / 33 KV GHOT S/STN

Feeder No / Name : 201 / 11 KV REGDI FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.3086	.3429	.3772	.3086	.3429	.3429
2	.2572	.3086	.3086	.3772	.3086	.3086	.3429
3		.2743	.2743	.3429	.3086	.2743	.3086
4	.2401	.2743	.2743	.3429	.2743	.2743	.3086
5	.2401	.2572	.2743	.3429	.2743	.2572	.3086
6	.2058	.2572	.3086	.3258	.2743	.2572	.3086
7	.1886	.2401	.2743	.3086	.2915	.2401	.2743
8	.1372	.2572	.2743		.2572	.2401	.2743
9	.2058		.2743	.2915	.2743	.2401	.2572
10	.2401	.2743	.2743	.2915	.2229	.2401	.1886
11	.2401	.3086	.2229	.2058	.2058	.2401	.2058
12	.1886		.2743	.2743	.2401		.2058
13	.2915			.2572	.1543	.2229	
14	.2915			.2572	.2229	.2743	.2058
15	.2915			.2743	.2572	.2572	.2229
16	.2743			.2915	.2743	.2743	.2229
17	.2915		.2743	.2572	.2572	.2915	.2229
18	.2915		.3258	.2572	.2915	.2572	.2229
19	.3086	.3429	.4115	.3429	.3944	.3772	.3258
20	.4458	.463	.4973	.463	.4973	.463	.3601
21	.4458	.4458	.5144	.463	.4801	.4801	.3429
22	.3944	.3944	.463	.3772	.4287	.4115	.3086
23	.3429	.3601	.4287	.3429	.3944	.3772	.2915
24	.2743	.3429	.3429	.3944	.3429	.3601	.3429
Max	.4458	.463	.5144	.463	.4973	.4801	.3601
Min	.1372	.2401	.2229	.2058	.1543	.2229	.1886
Avg	.2758	.3193	.3318	.3243	.3015	.3027	.2781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104012 / 33 KV GHOT S/STN

Feeder No / Name : 202 / 11 KV JAGANPUR FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.2229	.2229	.0857	.2229	.2229
2	.2058	.2229	.2058	.2058	.0686	.1886	.2058
3	.2058	.2229	.2058	.2058	.0686	.1715	.2058
4	.1886	.2058		.2058	.0686	.1715	.1715
5	.1715	.1715	.1715	.1886	.0686	.1543	.1715
6	.1372	.1372		.1543	.0514	.1372	.1372
7	.1029	.1029		.1029	.0514	.12	.12
8	.12	.1029	.1029	.12	.0686	.1029	.12
9	.12		.12	.0857	.1029	.1029	.1029
10	.0857	.1029	.1029	.1029	.1029	.0857	.0857
11	.1029	.1029	.0857	.0857	.1029	.1029	.0857
12	.1029		.1029	.0686	.0857	.1029	.12
13	.12			.1029	.0857	.1029	.12
14	.12			.12	.0857	.1029	.1029
15	.12			.0857	.1029	.0857	.1029
16	.1029	.12		.1029	.1029		.1029
17	.12	.0857			.12		.1029
18	.12	.1372	.1029	.1029	.12		.0686
19	.1886	.1886	.1886	.1715	.2058	.1029	.1886
20	.2915	.2229	.2743	.2743	.2572	.2572	
21	.3086	.2915	.3086		.2743	.2743	
22	.2915	.2572	.2572		.2572	.2401	
23	.2572	.2401	.2401	.0857	.2401	.2401	.1715
24	.2229	.2401	.2229	.2229	.0857	.2229	.2229
Max	.3086	.2915	.3086	.2743	.2743	.2743	.2229
Min	.0857	.0857	.0857	.0686	.0514	.0857	.0686
Avg	.1679	.1787	.1822	.1437	.1193	.1568	.1396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104012 / 33 KV GHOT S/STN

Feeder No / Name : 203 / 11 KV GHOT FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.3086	.2743	.3086	.3086	.2915	.3086
2	.2743	.3086	.2743	.3086	.2743	.2401	.2915
3	.2572	.2743	.2743	.2915	.2743	.2401	.2743
4	.2572	.2743	.2572	.2743	.2572	.2229	.2743
5	.2401	.2743	.2401	.2572	.2401	.2058	.2743
6	.2229	.2572	.2229	.2229	.2229	.2058	.2401
7	.1715	.2229	.1886	.1715	.1886	.1886	.2058
8	.1886	.2058	.1886	.1886	.1886	.1715	.1715
9	.1886		.1886	.2058	.1886	.1715	.1886
10	.1715	.1029	.1715	.1886	.1543	.1715	.1715
11	.1886	.12	.1372	.1715	.1543	.1886	.1543
12	.2229	.1029	.1543	.1886	.1543	.1715	.1372
13	.2058	.2058		.2058	.2401	.1543	.1543
14	.2401	.2058		.2401	.1886	.1543	.1543
15	.2572			.2401	.1886	.2058	.1715
16	.1886	.2058		.2058	.2058	.1886	.1543
17	.2058	.1715	.2572	.1715	.2058	.1886	.1715
18	.2058	.1715	.2572	.1886	.1886	.1543	.1886
19	.2572	.2229	.3258	.2572	.2401	.2572	.3086
20	.3258	.3086	.3429	.3086	.2915	.3086	.2743
21	.3601	.3258	.3429	.3258	.3258	.3258	.3086
22	.3429	.3258	.3258	.3258	.3086	.3086	.2915
23	.3429	.2915	.3086	.3258	.3086	.3086	.2572
24	.2915	.3086	.2915	.3086	.3086	.2915	.3086
Max	.3601	.3258	.3429	.3258	.3258	.3258	.3086
Min	.1715	.1029	.1372	.1715	.1543	.1543	.1372
Avg	.2458	.2362	.2512	.2451	.2336	.2215	.2265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104020 / 33/11KV BHENDALA

Feeder No / Name : 201 / 11 KV GHARGAON FEEDER SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961		.6036	.6668	.6413	.5906	.5658
2	.3961		.6036	.6478	.6413	.5716	.547
3	.3961		.6224	.6287	.6602	.5716	.5847
4	.3961		.6224	.6287	.6602	.5716	.5658
5	.4338		.6224	.6287	.6602	.5906	.5658
6	.4904		.6602	.6287	.6413	.6097	.5847
7	.547		.7167	.743	.679	.5716	.5658
8	.6413		.7545	.8192	.7167	.6478	.5847
9	.6979		.7167	.8383	.7733	.7049	.6413
10	.7356	.7922	.7621	.5906	.7545	.7621	.6413
11		.7356	.6668	.6979	.6859	.743	.5847
12		.3395	.724	.7545	.7545	.724	.4715
13		.4527	.6668	.5281	.7545	.7621	.547
14		.6224	.6287	.679	.7545	.6979	.547
15		.6413	.6478	.7356	.811	.7621	.5281
16		.6036	.6859	.6224	.7733	.7049	.4715
17		.6036	.6478	.6413	.7545	.7167	.4527
18		.6036	.6478	.6413	.6036	.5847	.4527
19		.6036	.6478	.6413	.547	.5716	.415
20		.5658	.724	.6979	.5847	.6287	.4338
21		.6036	.6859	.6979	.5847	.6097	.4338
22		.5658	.6668	.6602	.5847	.5906	.415
23		.5658	.6668	.6602	.5847	.5906	.415
24	.3961		.6036	.6668	.6602	.5847	.5906
Max	.7356	.7922	.7621	.8383	.811	.7621	.6413
Min	.3961	.3395	.6036	.5281	.547	.5716	.415
Avg	.5024	.5928	.6665	.6727	.6777	.6443	.5252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104020 / 33/11KV BHENDALA

Feeder No / Name : 202 / 11 KV BHENDALA FEEDER SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.086	1.094	1.0479	1.0185
2		1.0479	1.0562	1.0479	1.0185
3		1.0479	1.0562	1.0288	.9808
4		1.0288	1.0562	1.0288	.9997
5		1.0288	1.0185	1.0288	.9997
6		1.0098	.9431	1.0288	.9808
7		1.0479	.8676	1.0098	.9619
8		1.0288	.9619	1.0288	.9242
9		1.1431	1.1317	1.0479	.8865
10		.9145	1.1506	1.1431	.9997
11		1.094	1.086	1.105	.9431
12		1.1694	1.1128	1.2384	.8488
13		1.2071	1.0751	1.2384	.8676
14		1.1883	1.2071	1.1883	
15		1.2637	1.1506	1.1622	.8488
16		.7545	1.0562	1.1812	.811
17		.9808	1.0562	1.1694	.811
18		.9431	.9242	.9808	.7545
19		1.1317	1.1128	1.1317	.9431
20		1.3014	1.2826	1.1883	1.094
21		1.3014	1.226	1.1694	1.0751
22	1.2384	1.226	1.1506	1.094	.9997
23	1.1812	1.1317	1.094	1.0374	.9431
24	1.1431	1.1431	1.1317	1.0751	.9997
Max	1.2384	1.3014	1.2826	1.2384	1.094
Min	1.086	.7545	.8676	.9808	.7545
Avg	1.1622	1.0925	1.0834	1.1000	.9439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104020 / 33/11KV BHENDALA

Feeder No / Name : 203 / 11 KV KALAMGAON/BORI SHEDDABLE RURAL

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922		.8299	.2477	.1886	.1715	.1886
2	.7922		.8299	.2477	.1886	.1715	.1886
3	.7922		.7922	.2286	.1886	.1715	.1886
4	.811		.7922	.2477	.1886	.1905	.1886
5	.7545		.7545	.2286	.1886	.1905	.1886
6	.7167		.7167	.2286	.1886	.2096	.1886
7	.6979		.7167	.2477	.2075	.1905	.1886
8	.7545		.811	.2286	.2075	.0381	.1509
9	.8488		.8865	.2286	.2263	.0381	.1509
10	.5658	.5281	.9145	.1905	.2075	.0572	.132
11		.7922	.7049	.2075	.132	.1524	.1509
12		.7922	.8573	.132	.132	.2096	.132
13		.6602	.8764	.132	.1509	.2286	.1509
14		.7922	.8192	.132	.1886	.2263	.1698
15		.7356	.8383	.2075	.1886	.1905	.1698
16		.7356	.2096	.2263	.1886	.2286	.1886
17		.7545	.2286	.2263	.2263	.2263	.1698
18		.8299	.2286	.1886	.1886	.2075	.1698
19		.8488	.2286	.1886	.1886	.2096	.1886
20		.8676	.2667	.2263	.2075	.2286	.1886
21		.8676	.2667	.2075	.2075	.2286	.1886
22		.8488	.2477	.2075	.1886	.2286	.1698
23		.7922	.2477	.2075	.1886	.2286	.1698
24	.811		.8676	.2477	.2075	.1698	.2096
Max	.8488	.8676	.9145	.2477	.2263	.2286	.2096
Min	.5658	.5281	.2096	.132	.132	.0381	.132
Avg	.7579	.7747	.6222	.2109	.1902	.1830	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104023 / 33/11 Kv Talodhi(MO) Sub-
StatiFeeder No / Name : 201 / 11 Kv Talodhi (MO) SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0229	1.1218	1.0802	1.1096	1.0802	1.1443	1.2071
2	.9882	1.1283	1.0631	1.1096	1.0631	1.1269	1.2071
3	.9882	1.134	1.0631	1.0923	1.0631	1.1269	1.2012
4	.9709	1.1163	1.0631	1.0923	1.0631	1.1269	1.2127
5	.9362	1.182	1.0631	1.0923	1.0631	1.1269	1.2437
6	.7455	.9036	.8573	.9362	.9259	.8669	1.0745
7	.6588	.8326	.7716	.9362	.8059	.6588	.9425
8	.7455	.8505	.823	1.0056	.8745	.9362	1.0867
9	.8322	.9134	.9602	1.0056	.9945		1.0692
10	.9189	.8573	.4908	.9362	.9362	.6762	1.0566
11	.8688	.9088	.9465	.8059	.9362	.6805	.9259
12	.8954	.9431	.9465	.9774	.8669	.6485	.9602
13	.8764	.8059	.9465	.9945	.9015	.6687	.9259
14	.9492	.8916	.964	.9602	.8842	.7499	.9602
15	.8596	.8745	.8413	.8573	.8669	.6984	.8573
16	.8059	.9259	.9816	.823	.9536	.691	.8916
17	.8145	.823	1.0166	.8573	.9816	.6135	
18	.7682	.8573	.9189	.8745	.9015	.8954	
19	1.0566	.9259	1.1269	.9945	1.1096	1.2536	
20	1.3611	1.2689	1.387	1.2517	1.3696	1.4449	
21	1.3432	1.2689	1.387	1.2346	1.3176	1.3969	.6516
22	1.2536	1.2003	1.2136	1.1317	1.2309	1.2934	.9945
23	1.1706	1.0974	1.1568	1.0802	1.1616	1.2489	.9259
24	1.0229	1.1462	1.0802	1.1269	1.0802	1.1443	1.1919
Max	1.3611	1.2689	1.387	1.2517	1.3696	1.4449	1.2437
Min	.6588	.8059	.4908	.8059	.8059	.6135	.6516
Avg	.9522	.9991	1.0062	1.0119	1.0180	.9660	1.0293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104023 / 33/11 Kv Talodhi(MO) Sub-
StatiFeeder No / Name : 202 / 11 Kv yedanur
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1543	.1715	.1734	.1886	.1734	.1543
2	.1417	.1433	.1715	.1734	.1886	.1734	.1578
3	.124	.1402	.1715	.156	.1886	.1734	.1578
4	.124	.1433	1.286	.156	.1715	.1734	.1629
5	.1063	.1595		.156	.1886	.156	.1772
6	.1063	.1029	.1029	.104	.1543	.1214	.1372
7	.0886	.1433	.12	.1387	.1372	.104	.1227
8	.124	.1433	.12	.1387	.1372	.1387	.1372
9	.124	.1227	.12	.1417	.12	.1214	.1791
10	.1063	.12	.1227	.104	.1387	.1387	.1463
11	.0876	.1029	.1052	.12	.1387	.1463	.1372
12	.1052	.12	.1227	.12	.1387	.1433	.1372
13	.0857	.12	.1052	.12	.1387	.1629	.1372
14	.1075	.12	.1402	.1029	.1387	.1578	.12
15	.0886	.12	.1402	.12	.1387	.1543	.12
16	.0876	.12	.1578	.1029	.1214	.1578	.1029
17	.0857	.1029	.1402	.12	.1402	.1886	
18	.12	.12	.1387	.1372	.1387	.1417	
19	.1772	.1715	.2427	.1715		.1991	
20	.2378	.2401		.2401	.2254	.2229	.1886
21	.2303	.2401	.2427	.2229	.2254	.2303	.1715
22	.1829	.2229	.2103	.2058	.1907	.197	.1543
23	.181	.1715	.1928	.1886	.1734	.1791	.1543
24	.1595	.1578	.1715	.1734	.1886	.1734	.1753
Max	.2378	.2401	1.286	.2401	.2254	.2303	.1886
Min	.0857	.1029	.1029	.1029	.12	.104	.1029
Avg	.1301	.1459	.2044	.1495	.1613	.1637	.1491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104024 / 33/11 KV Ashti S/Stn

Feeder No / Name : 201 / 11 KV ILLUR FDR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3336	1.2955	1.3717	1.3717	1.2765	1.2955
2	1.3146	1.2955	1.2384	1.3336	1.3336	1.2765	1.2384
3	1.2384	1.2955	1.2574	1.2955	1.3336	1.2384	1.2384
4	1.2193	1.2384	1.1622	1.2574	1.2955	1.2384	1.2003
5	1.1431	1.2193	1.1431	1.2003	1.2384	1.0288	1.1812
6	1.1241	1.1622	1.105	1.2193	1.105	1.0288	1.1431
7	.9907	1.105	.7811	1.1622	.9335	1.086	1.1431
8	1.1241	1.086	1.1431	1.1812	.9526	1.0288	1.1431
9	1.086		1.2193		1.0669	1.105	1.0288
10	.9335		1.2193	1.2193	1.0288	1.1431	1.086
11	1.086		1.2384	1.1812	1.0669	1.1812	1.0669
12	.9907		1.2955	1.1812	1.105	1.2384	.9526
13	.9526		1.2765	1.2384	1.1812	1.2384	1.0288
14	1.086		1.3717	1.2193	1.2003	1.2193	1.0098
15	1.0669		1.3336	1.1431	1.1812	1.2955	1.0288
16	1.0669		1.0288	.7621	1.1431	1.2193	1.0288
17	1.086		1.2574	1.0479		1.1812	.6859
18	1.0669			1.105	.9526	1.0669	.8573
19	1.2955		1.4098	1.2384	1.2574	1.2193	1.1431
20	1.6004		1.6194	1.4861	1.3717	1.4861	1.3146
21	1.6004	1.4861	1.6004	1.5242	1.3908	1.5051	1.2574
22	1.5051	1.448	1.5432	1.467	1.4098	1.448	1.2574
23	1.448	1.3527	1.448	1.448	1.2955	1.3908	1.2384
24	1.3717	1.3717	1.3146	1.4289	1.4289	1.2765	1.3336
Max	1.6004	1.4861	1.6194	1.5242	1.4289	1.5051	1.3336
Min	.9335	1.086	.7811	.7621	.9335	1.0288	.6859
Avg	1.1971	1.2828	1.2740	1.2483	1.2019	1.2257	1.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 104024 / 33/11 KV Ashti S/Stn

Feeder No / Name : 203 / 11 KV MARKANDA FDR SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2384	1.2384	1.2384	1.086	1.1241	
2	1.0479	1.2193	1.2193	1.2003	1.0669	1.105	
3	.9907	1.1622	1.2003	1.1622	1.0669	1.105	.6097
4	1.0098	1.1431	1.1812	1.1431	1.0479	1.1241	.6097
5	.9907	1.1431	1.1431	1.1431	1.0288	1.086	.5906
6	.9717	1.1622	1.086	1.1812	.9526	1.105	.5716
7	.8954	1.1241	1.2574	1.2003	.9526	1.105	.6097
8	1.105	1.1241	1.3527	1.2384	1.0479	1.1622	1.1431
9	1.2003		1.3717		.0191	1.3336	1.0288
10	.7049		1.2574	1.2574	.8383	1.3527	.9526
11	1.0288		1.3717	1.2955	1.1431	1.3717	1.0288
12	.8383		1.4098	1.4289	1.2765	1.4289	1.1431
13	.8954		1.2955	1.3336	1.2955	.9526	1.3146
14	1.105		1.3336	1.2955	1.3336	1.4289	1.2765
15	1.086		1.3908	1.3146	1.2765	1.3527	1.3146
16	1.1431		1.3908	1.2955	1.2955	1.3717	.9335
17	1.1812		1.3527	1.2193		1.3336	.4763
18	1.1812		1.467	.6668	1.1241	1.2193	.6287
19	1.467		1.5623	1.0098	1.3336	1.2765	.8573
20	1.5432		1.6004	1.1622	1.4289	1.3527	1.0479
21	1.5813	1.4861	1.6194	1.2384	1.5051	1.3336	.9526
22	1.3908	1.448	1.5813	1.1241	1.4098	1.2765	.9717
23	1.3336	1.2765	1.448	1.1431	1.2955	1.2384	1.0098
24		1.2765	1.2193	1.2765	1.105	1.1241	
Max	1.5813	1.4861	1.6194	1.4289	1.5051	1.4289	1.3146
Min	.7049	1.1241	1.086	.6668	.0191	.9526	.4763
Avg	1.1223	1.2336	1.3479	1.1986	1.1274	1.2360	.9082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

CHAMORSHI S/DN.[344] BU 4344

Substation No/ Name :- 107006 / 132 KV ASHTI S/STN

Feeder No / Name : 703 / 132KV BILTS EXPRESS NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 132 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.829	2.0576	2.0576	2.0576	1.829	2.0576
2	2.0576	2.0576	2.0576	2.0576	2.0576	1.829	2.0576
3	2.0576	2.0576	2.0576	2.0576	2.0576	1.829	2.0576
4	2.0576	1.829	2.0576	2.0576	2.0576	1.829	2.0576
5	2.0576	1.829	2.0576	2.0576	2.0576	1.829	2.0576
6	2.0576	1.829	2.0576	2.0576	2.0576	1.829	2.0576
7	2.0576	2.0576	2.0576	2.0576	2.0576	1.829	2.0576
8	2.0576	2.0576	2.0576		2.0576	1.829	2.0576
9	2.0576		2.0576	2.0576	2.0576	1.829	2.0576
10	2.0576		2.0576	2.0576	1.6004	1.829	2.0576
11	2.0576		2.0576	2.0576	1.6004	1.829	2.0576
12	1.3717		2.0576	2.0576	1.829	2.0576	2.0576
13	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
14	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
15	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
16	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
17	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
18	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
19	2.0576		2.0576	2.0576	1.829	2.0576	2.0576
20	2.0576		2.0576	2.0576	1.829	2.0576	1.829
21	1.829	1.829	1.829	2.0576	1.829	2.0576	1.829
22	2.0576	2.0576	2.0576	2.0576	1.829	2.0576	1.829
23	2.0576	2.0576	2.0576	2.0576	1.829	2.0576	1.829
24	2.0576	2.0576	2.0576	2.0576	2.0576	1.829	2.0576
Max	2.0576	2.0576	2.0576	2.0576	2.0576	2.0576	2.0576
Min	1.3717	1.829	1.829	2.0576	1.6004	1.829	1.829
Avg	2.0195	1.9624	2.0481	2.0576	1.9052	1.9433	2.0195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ETAPALLI S/DN.[345] BU 4345

Substation No/ Name :- 104025 / 33/11 KV Ettapalli S/Stn

Feeder No / Name : 201 / 11 KV ETAPALLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6097	.5335	.5906	.5716	.5716	.5525
2	.5975	.5906	.4954	.5716	.5525	.5525	.5335
3	.5975	.5906	.4763	.5525	.5525	.5335	.5144
4	.5975	.5716	.4382	.5335	.5144	.5144	.5144
5	.5601	.5335	.4191	.5144	.4954	.5144	.4763
6	.4954	.5144	.4001	.5144	.4572	.4954	.4572
7	.4191	.4191	.362	.4382	.4001	.4001	.3921
8	.362	.381	.3429	.381	.362	.362	.3734
9	.4001	.3429	.362	.3429	.4001	.362	.3547
10	.362	.3239	.3429	.3429	.3239	.4001	.3174
11	.4382		.362	.362	.3429	.381	.3174
12	.4191		.381	.4001		.4191	.2987
13	.4382		.381	.4001	.4382	.381	.3174
14	.4572		.381	.4001	.4001	.3429	.2987
15	.4572	.362	.4191	.4001	.3429	.3429	.2987
16	.4572	.4001	.3429	.381	.362	.3239	.3174
17	.4382	.4001	.362	.362	.381	.362	.3174
18	.4191	.381	.381	.362	.4763	.381	.3734
19	.5525	.5144	.5335	.5716	.6097	.5335	.5601
20	.7621	.6859	.7811	.724	.724	.7049	.6348
21	.8002	.6668	.7621	.7049	.7049	.6478	.6161
22	.743	.6287	.7049	.6859	.6668	.6287	.5601
23	.6478	.5906	.6287	.5906	.4191	.5906	.5228
24	.6161	.6287	.5716	.6097	.5716	.5906	.5716
Max	.8002	.6859	.7811	.724	.724	.7049	.6348
Min	.362	.3239	.3429	.3429	.3239	.3239	.2987
Avg	.5265	.5068	.4652	.4890	.4813	.4723	.4371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ETAPALLI S/DN.[345] BU 4345

Substation No/ Name :- 104025 / 33/11 KV Ettapalli S/Stn

Feeder No / Name : 202 / 11 KV Kasansur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.381	.3429	.0762	.381	.4191	.4382
2	.362	.381	.3239	.3429	.362	.4001	.4191
3	.362	.381	.3239	.3429	.362	.4001	.4191
4	.362	.362	.3048	.3239	.3429	.4001	.4001
5	.3239	.362	.3048	.3239	.3048	.381	.4001
6	.3048	.362	.3048		.2858	.381	.381
7	.2858	.2858	.2477	.0381	.2477	.3239	.3048
8	.2667	.1334	.2286	.0953	.2096	.2667	.2667
9	.2477	.2096	.2096	.2096	.1715	.2477	.2477
10	.2286	.2286	.1715	.1524	.0381	.2477	.2286
11	.2096	.1905	.1524	.1334	.1715	.2286	.2286
12	.2286	.1905	.0381	.1334	.1905	.2477	.2286
13	.2096	.1905	.0381	.1715	.0381	.2286	.2286
14	.2096	.2096	.0381	.1715	.0381	.0381	.1905
15	.2096		.0381	.1143	.1715		.1905
16	.2096	.0191	.0381	.2096	.2096	.0381	.1905
17	.0762		.0381	.2477	.2286	.2286	.1905
18	.2667		.0381	.2096	.2858	.2667	.3048
19	.4001	.0191	.2858	.4001	.4382	.4191	.4572
20	.5716	.0572	.5716	.5144	.5335	.5716	.5335
21	.4572	.0953	.5525	.5144	.4382	.5335	.5144
22	.4763	.381	.4954	.4382	.4572	.4954	.4572
23	.4191	.381	.4191	.4001	.4191	.4763	.4382
24	.4191	.4001	.362	.381	.381	.4191	.4572
Max	.5716	.4001	.5716	.5144	.5335	.5716	.5335
Min	.0762	.0191	.0381	.0381	.0381	.0381	.1905
Avg	.3112	.2486	.2445	.2585	.2794	.3330	.3382

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

ETAPALLI S/DN.[345] BU 4345

Substation No/ Name :- 104025 / 33/11 KV Ettapalli S/Stn

Feeder No / Name : 203 / 11 KV Bhamragad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3048	.2858	.2477	.3429	.3429	.1905
2	.3584	.3048	.2667	.2477	.3429	.3429	
3	.3584	.2858	.2667	.2286	.3429	.3239	
4	.362	.2858	.2477	.2477	.3239	.3239	
5	.3429	.2667	.2286	.2477	.2858	.3048	
6	.2858	.2667	.2286	.2667	.2667	.3048	
7	.2096	.1715	.1905	.2096	.2477	.2096	
8	.1715	.1524	.1524	.1715	.0953	.1715	
9	.1715	.1524	.1334	.1715	.1905	.2286	.0189
10	.1524	.1524	.1334	.1143	.1524	.2096	.1698
11	.1715	.1334	.0572	.1524	.2096	.2096	.132
12	.1715	.0953	.0572	.1334	.1715	.1524	.2075
13	.1715	.1143	.0762	.1143	.1524	.2096	.2075
14	.2286	.0762	.1143	.1524	.1715	.1715	.1698
15	.2096	.0572	.1143	.1524	.1334	.1143	.1698
16	.1715	.1715	.0572	.1334	.1334	.1905	.1509
17	.1524	.2096		.1524	.1524	.2096	.1509
18	.1905	.2096	.1524	.2477	.1905	.2286	.1509
19	.2667	.2858	.1334	.4001	.3239	.362	.2452
20	.5144	.362	.4191	.4763	.4382	.1905	.3395
21	.381	.381	.4191	.4572	.4382	.2286	.3206
22	.2096	.3429	.4001	.4191	.4001	.2286	.3018
23	.1715	.3239	.3429	.362	.362	.2096	.2641
24	.3772	.3239	.3048	.2858	.362	.362	.2096
Max	.5144	.381	.4191	.4763	.4382	.362	.3395
Min	.1524	.0572	.0572	.1143	.0953	.1143	.0189
Avg	.2566	.2262	.2079	.2413	.2596	.2429	.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

MULCHERA S/DN.[827]

BU 4827

Substation No/ Name :- 104013 / 33 KV MULCHERA

Feeder No / Name : 201 / 11 KV KOPARALLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1372	.1543	.1543	.1715	.2229	.1886
2	.1543	.1372	.1543	.1372	.1715	.2229	.1886
3	.1543	.1372	.1543	.1543	.1543	.2401	.1886
4	.1372	.1372	.1543	.1372	.1715	.2229	.1715
5	.1372	.1372	.1543	.1543	.1715	.2229	.1886
6	.12	.1372	.1715	.1543	.1543	.2229	.2058
7	.1886	.1886	.2743	.1715	.2572	.2401	.2058
8	.2229	.2058	.2743	.2229	.2572	.2743	.1886
9	.2401		.3086	.2058	.2743	.2572	.2058
10	.2572		.3086		.2572	.2401	.1886
11	.2572		.2743		.2572	.2401	.2229
12	.2572		.2401	.2572	.2743	.2401	.2229
13	.2229			.2572	.2572	.2401	.2229
14	.2572			.2401	.2572	.2229	.2401
15	.2401			.2572	.2743	.2058	.2401
16	.2229			.2572	.2572	.2229	.2401
17	.2401		.2401	.2401	.2401	.2229	.12
18	.2058		.2401	.1372	.2572	.2229	.12
19	.1715	.1715	.2401	.1886	.2401	.2229	.1543
20	.2058	.1886	.2572	.2058	.2572	.2229	.1715
21	.2058	.1886	.2401	.2229	.2229	.2229	.1715
22	.2058	.1715	.1886	.2058	.2401	.2229	.1543
23	.1715	.1543	.1886	.1886	.2229	.2058	.1543
24	.1543	.1372	.1543	.1886	.1886	.2229	.1886
Max	.2572	.2058	.3086	.2572	.2743	.2743	.2401
Min	.12	.1372	.1543	.1372	.1543	.2058	.12
Avg	.1993	.1592	.2186	.1972	.2286	.2293	.1893

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

MULCHERA S/DN.[827] BU 4827

Substation No/ Name :- 104013 / 33 KV MULCHERA

Feeder No / Name : 202 / 11 KV SUNDARNAGAR FEEDER SHEDDABLE RURAL
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1831	1.1488	1.1488	1.0974	1.3032	1.3717	1.4232
2	1.1831	1.1488	1.1317	1.1145	1.3203	1.3717	1.3717
3	1.1831	1.1488	1.1145	1.1145	1.3203	1.3375	1.3717
4	1.166	1.1145	1.0631	1.166	1.3375	1.3717	1.406
5	1.166	1.1145	1.0631	1.1831	1.3375	1.3717	1.3889
6	1.1488	1.166	1.2174	1.2003	1.3546	1.3717	1.3889
7	1.1317	1.166	1.2689	1.2689	1.1145	1.4575	1.5261
8	1.2346	1.2174	1.3717	1.5432	1.4918	1.4403	1.5604
9	1.1831		.9259	1.5089	1.4403	1.4403	1.4746
10	1.1317		.9945	1.4746	1.4232	1.3717	1.1317
11	1.166		1.0288	1.3203	1.4746	1.4403	1.2003
12	1.0802		1.0288	1.4403	1.4918	1.4918	1.2174
13	1.0117			1.4746	1.5604	1.3889	1.1317
14	1.1488			1.4575	1.5775	1.4575	1.2003
15	1.0974			1.3717	1.406	1.5261	.9945
16	1.0288			1.3375		1.3717	1.166
17	.7888		1.3032	1.3546	1.406	1.3375	.8402
18	1.0288		1.4403	1.0974	1.4403	1.406	.7545
19	1.3546	1.406	1.6804	1.3375	1.5261	1.6118	1.2689
20	1.5775	1.4403	1.8176	1.406	1.7661	1.7318	1.406
21	1.5432	1.4403	1.749	1.5604	1.7147	1.6804	1.3889
22	1.4403	1.3203	1.5432	1.4746	1.5947	1.6118	1.3375
23	1.3375	1.2346	1.4746	1.3889	1.5089	1.5089	1.2517
24	1.2003	1.1831	1.1831	1.3889	1.3203	1.4575	1.4575
Max	1.5775	1.4403	1.8176	1.5604	1.7661	1.7318	1.5604
Min	.7888	1.1145	.9259	1.0974	1.1145	1.3375	.7545
Avg	1.1881	1.2321	1.2774	1.3367	1.4448	1.4553	1.2774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

MULCHERA S/DN.[827] BU 4827

Substation No/ Name :- 104013 / 33 KV MULCHERA

Feeder No / Name : 203 / 11 KV MULCHERA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.3601	.3429	.3086	.3429	.3429	.3944
2	.3944	.3601	.3429	.3086	.3429	.3429	.3772
3	.3772	.3429	.3429	.3086	.3601	.3601	.3772
4	.3772	.3429	.3258	.3086	.3429	.3772	.3429
5	.3772	.3429	.3258	.3258	.3258	.3601	.3772
6	.3429	.3601	.3601	.3086	.3429	.3772	.3772
7	.3258	.3601	.3601	.3086	.3429	.3772	.3944
8	.3772	.3772	.3258	.3086	.3429	.3429	.3772
9	.2058		.3429	.3772	.3772	.4115	.4115
10	.4115		.3944	.3772	.3944	.3772	.3601
11	.3772		.4115	.3601	.3944	.3772	.3944
12	.4115		.4287	.4458	.4115	.3944	.3258
13	.3944			.3944	.4458	.3772	.3944
14	.4115			.4115	.3772	.3772	.3086
15	.3772			.4287	.3944	.4115	.3086
16	.4115			.3944	.3944	.4115	.3429
17	.3772		.4458	.3944	.3944	.4115	.1886
18	.3429		.3944	.3086	.3772	.3944	.2058
19	.3944	.463	.4801	.3772	.4115	.4287	.3258
20	.4801	.4801	.4458	.4115	.4458	.4115	.3258
21	.4458	.463	.4973	.4115	.4287	.4458	.3429
22	.4458	.3944	.4458	.4287	.4458	.4458	.3258
23	.4115	.3772	.4287	.3944	.4115	.4458	.3086
24	.3944	.3601	.3429	.4115	.3944	.4115	.4287
Max	.4801	.4801	.4973	.4458	.4458	.4458	.4287
Min	.2058	.3429	.3258	.3086	.3258	.3429	.1886
Avg	.3858	.3846	.3892	.3672	.3851	.3922	.3465

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 102002 / 11 KV Sironcha Switch Yard

Feeder No / Name : 201 / 11 KV SIRONCHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.9619	.7545	.9054	.8488	.7545	.7545
2	.8676	.9054	.7167	.9054	.8488	.7545	.7545
3	.8676	.9054	.7733	.8676	.8299	.7167	.7167
4	.8676	.8676	.7545	.8676	.8299	.7167	.7167
5	.8299	.8676	.7733	.8488	.7922	.7167	.7167
6	.811	.9054	.7356	.8299	.7922	.7167	.7545
7	.811	.9431	.7733	.7922	.8488	.6979	.7733
8		.8299	.7545	.7356	.7922	.7356	.679
9		.7545	.7545	.6602	.6979	.7545	.6224
10		.679	.6602	.6224	.6224	.7167	.5847
11		.6036	.6224	.6413	.6413	.6979	.5847
12		.6602	.6224	.4904	.6224	.6036	.5658
13		.6413	.6413	.6413	.5847	.6036	.6413
14		.6602	.6224	.6602	.6036	.6036	.6602
15		.547	.6413	.6036	.6036	.5658	.5847
16		.5281	.6036	.6036	.5658	.4904	.5847
17		.5658	.6224	.6602	.6224	.5281	.5847
18		.6224	.6224	.6224	.679	.5847	.6224
19		.8299	.7922	.811	.7545	.7733	.7733
20		.9054	.9808	.9242	.8488	.9242	.8865
21		.9054	.9997	.9431		.8865	.8865
22	1.1694	.8865	1.0185	.9054	.9054	.8865	.8488
23	1.0185	.8299	.9242	.8865	.8299	.811	.7733
24	.9054	.9619	.7922	.9431		.7733	.7733
Max	1.1694	.9619	1.0185	.9431	.9054	.9242	.8865
Min	.811	.5281	.6036	.4904	.5658	.4904	.5658
Avg	.9035	.7820	.7482	.7655	.7348	.7089	.7018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 102002 / 11 KV Sironcha Switch Yard

Feeder No / Name : 202 / 11 KV MEDARAM

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6481	1.2346	1.0802	1.5123	.8488	1.0185	1.5432
2	.6481	1.2037	.7716	1.5123	.8488	1.0185	1.5432
3	.6636	1.2037	.8179	1.4506	.8333	.9877	1.5123
4	.6944	1.1728	.8025	1.4506	.8333	1.0185	1.5123
5	.7407	1.2037	.8333	1.358	.8488	1.0494	1.5432
6	.7562	1.4352	.9259	1.3272		1.1728	1.5741
7	.8179	1.6975	1.2346	1.358	.8025	1.5123	1.8364
8		1.5021	1.2809	1.1111	.9414	1.5432	1.6975
9		1.516	1.1265	1.1574	.7407	1.6204	1.7747
10		1.2934	1.2037	1.2346		1.5586	1.6512
11		1.4047	1.3426	1.2346	1.142	1.4969	1.6667
12		1.5278	1.4506	.0926	1.2346		1.6821
13		1.7747			1.0185	1.4661	1.3735
14		1.4661	1.5278		1.2191	1.5586	1.5432
15		.9568	1.5123	.108		1.713	1.6049
16		.9722	1.4815	.2315	1.0802	1.6821	1.3117
17		1.0185	1.5895	.3241	.2469	1.3272	1.3889
18		1.0802	1.5741	.679	.2932	1.6204	1.3889
19		1.1265	1.5741	.8642	1.0031	1.7593	1.4043
20		1.0802	1.6512	.9722	1.1111	1.6821	1.3889
21		1.0802	1.6204	.9414	1.1111	1.6821	1.3272
22	1.3272	1.1265	1.5895	.9105	1.0802	1.6512	1.3272
23	1.3735	1.0957	1.5741	.8951	1.0648	1.5586	1.2963
24	.6481	1.2346	1.0494	1.5432	.8796	1.0494	1.5741
Max	1.3735	1.7747	1.6512	1.5432	1.2346	1.7593	1.8364
Min	.6481	.9568	.7716	.0926	.2469	.9877	1.2963
Avg	.8318	1.2670	1.2876	1.0122	.9134	1.4238	1.5194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 102002 / 11 KV Sironcha Switch Yard

Feeder No / Name : 203 / 11 KV ARDA SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.4115	.5428	.6859	.5487	.6173	.6584
2	.6161	.4115	.5575	.6859	.5487	.6036	.631
3	.6161	.4252	.5428	.6584	.5213	.6036	.631
4	.6308	.4252	.5281	.6584	.5213	.6036	.6173
5	.6895	.4664	.5428	.6447	.5487	.6036	.631
6	.7482	.5213	.5868	.6447	.6036	.6447	.6722
7	.8362	.6859	.7042	.7407	.7682	.7819	.8093
8			.7482	.7682	.751	.8345	.8368
9			.7232	.7371	.6537	.8345	.8067
10			.7649	.6676	.4311	.7928	.7649
11			.2782	.7788	.4868	.751	.8206
12			.3616	.7928	.612	.7788	.8206
13			.3477		.6398	.8345	.8345
14		.2606	.6398	.612	.3338	.7788	.8067
15		.4938	.4033	.7716	.5841	.7371	.8206
16		.5487	.6676	.5841	.6537	.7093	.8206
17		.5761	.8215	.5563	.6954	.727	.8362
18		.5702	.8802	.5702	.6954	.6584	.8069
19		.5563	.8215	.5841	.6537	.6859	.8069
20		.5563	.7545	.598	.6676	.6996	.8069
21		.5285	.7545	.612	.6398	.6859	.7628
22	.4115	.5285	.7407	.5761	.6398	.6584	.7482
23	.3841	.5146	.727	.5624	.6173	.6584	.7482
24	.8573	.3841	.5281	.7133	.5624	.6173	.6584
Max	.8573	.6859	.8802	.7928	.7682	.8345	.8368
Min	.3841	.2606	.2782	.5563	.3338	.6036	.6173
Avg	.6406	.4925	.6236	.6610	.5991	.7042	.7565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 102002 / 11 KV Sironcha Switch Yard

Feeder No / Name : 206 / 11 KV MADDIKUNTA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.4687	.6249	.4999	.7811	.7499	.7499
2	.7811	.4687	.6718	.4999	.7499	.7499	.7499
3	.7811	.4374	.6249	.4999	.7499	.7186	.7186
4	.8124	.4374	.6405	.4687	.6874	.7186	.7186
5	.828	.5312	.6562	.3749	.7499	.7499	.7499
6	.8436	.6249	.6874	.3749	.8124	.7811	.8124
7	.9061	.6562	.7499	.5312	.9374	.8749	.8436
8		.5624	.7499	.5624	.8436	.8749	.9061
9		.5624	.7499	.6249	.7811	.9374	.8749
10		.3749	.7186	.5937	.7186	.9061	.8749
11		.5624	.7186	.5937	.7186	.9061	.8124
12		.5624	.7811		.6249	.8749	
13		.6562	.7499	.5937	.6874	.9061	.6405
14		.7186	.7811	.5937	.7186	.7811	.7186
15		.6249	.7811	.6562	.8749	.7499	.7968
16		.6249	.7186	.6718	.8436	.6249	.7499
17		.4062	.7716		.8749	.7499	.8124
18		.5937	.8333	.6874	.8124	.8749	.8124
19		.6874	.8951	.8124	.7499	.8749	.8124
20		.6874	.9061	.8905	.8124	.8124	.8436
21		.703	.8749	.8436	.7811	.8124	.8436
22	.4999	.6874	.8749	.8124	.7499	.7811	.8025
23	.4999	.6562	.8436	.7811	.7499	.7811	.8025
24	.7811	.4999	.6405	.8592	.7811	.7499	.7499
Max	.9061	.7186	.9061	.8905	.9374	.9374	.9061
Min	.4999	.3749	.6249	.3749	.6249	.6249	.6405
Avg	.7514	.5748	.7519	.6285	.7746	.8059	.7911

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 104015 / 33KV BAMNI

Feeder No / Name : 201 / 11kv Tekada

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5316	.463	.5375	.4607	.5316	.5721
2	.5201	.5316	.463	.5144	.4607	.4973	.5201
3	.5375	.5087	.463	.5144	.4607	.5144	.5258
4	.5201	.5256	.4578	.5144	.4784	.5201	.5083
5	.5201	.5426	.463	.5028	.5258	.5201	.4908
6	.5028	.6001	.4917	.5201	.5258	.5201	.5083
7	.4024	.583	.4862	.5028	.4854	.5548	.5487
8		.5256	.4748	.4973	.5316	.5316	.5426
9		.4115	.4409	.4458	.4458	.5256	.5487
10			.2743	.3944	.3772	.4973	.3688
11		.3315	.2883		.3521	.4239	.3401
12		.3315	.2486	.2347	.3391	.407	.3768
13			.3052	.3149	.3315	.4239	.3812
14			.3315	.3315	.3605	.373	.3315
15		.2753	.3315	.285	.3605	.373	.373
16		.3688	.3315	.2984	.39	.3185	
17		.3688	.3353		.4239	.39	
18		.3856	.4144	.4287	.5028	.4287	.4287
19		.5201	.6415	.5784	.6556	.6415	.591
20		.5375	.6588	.6379	.6661	.7011	.6201
21		.5487	.6516	.6201	.6173	.6762	.6379
22	.5487	.5201	.6001	.5201	.583	.6173	.5784
23	.5316	.5028	.5658	.4908	.5487	.5895	.5847
24	.5487	.5316	.4854	.5548	.4784	.5658	.5959
Max	.5487	.6001	.6588	.6379	.6661	.7011	.6379
Min	.4024	.2753	.2486	.2347	.3315	.3185	.3315
Avg	.5181	.4754	.4445	.4654	.4734	.5059	.4988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 104015 / 33KV BAMNI

Feeder No / Name : 202 / 11kv Bamni
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3772	.2915	.3467	.3898	.4458	.5028
2	.5201	.3772	.2743	.3258	.3721	.4115	.4508
3	.5201	.3561	.2572	.3258	.3721	.4115	.3856
4	.4508	.3561	.2713	.3258	.3544	.4161	.3681
5	.3641	.3391	.2743	.3467	.4031	.4161	.3681
6	.3814		.2883	.3814	.4031	.4334	.3856
7	.2012	.0686	.4024	.3988	.4161	.4508	.5316
8		.0678	.39	.4458	.4287	.4973	.6274
9		.0514	.373	.3601	.4115	.5087	.5487
10		.0488	.2915	.4287	.2572	.463	.5365
11		.0497	.2883		.3018	.4917	.5182
12		.0497	.3149	.4748	.3391	.4578	.5407
13			.3561	.4475	.3315	.5256	.5636
14			.3647	.4144	.3113	.5765	.547
15		.2105	.3315	.4527	.4424	.5935	.5935
16		.2347	.3315	.3978	.4409	.4409	.5218
17		.2515	.3521		.4578	.5087	.2753
18		.285	.3978	.4115	.4508	.5316	.3258
19		.3121	.4508	.4908	.4784	.6068	.3582
20		.3467	.4681	.4784	.5083	.6135	.3544
21		.3258	.463	.4961	.4458	.5721	.3721
22	.3772	.3294	.3429	.4334	.4287	.5487	.3681
23	.3772	.3121	.3258	.4207	.4287	.5201	.3721
24	.5144	.3772	.3121	.3294	.4252	.4458	.5083
Max	.5201	.3772	.4681	.4961	.5083	.6135	.6274
Min	.2012	.0488	.2572	.3258	.2572	.4115	.2753
Avg	.4221	.2441	.3422	.4061	.4000	.4953	.4552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 104015 / 33KV BAMNI

Feeder No / Name : 203 / 11kv zinganoor

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.1886	.2401	.2947	.4075	.3258	.2947
2	.3988	.1886	.2229	.2572	.3898	.3086	.2947
3	.3988	.1865	.2058	.2229	.3721	.3086	.2804
4	.3294	.1865	.2035	.2229	.3544	.2947	.2804
5	.3121	.1865	.2401	.1907	.3506	.2774	.2804
6	.3988	.2058	.2204	.1734	.4031	.2947	.298
7	.1463	.2743	.2347	.1734	.3429	.3121	.2743
8		.2374	.2374	.2743	.3467	.3429	.2883
9			.2543	.2572	.3944	.3222	.3944
10		.0854	.1543	.2572	.3086	.2915	.3185
11		.1492	.1696		.285	.373	.2267
12		.1989	.2321	.3052	.3391	.3391	
13			.2543	.2155	.2984	.3391	.2486
14			.2486	.2984	.3768	.3561	.3149
15			.2818	.3521	.3605	.373	.39
16		.1006	.2652	.2155	.3561	.3391	
17		.1174	.3018		.3391	.39	.2105
18		.1341	.2652	.2572	.3294	.4115	.2572
19		.1907	.3294	.4207	.4075	.4681	.2686
20		.3121	.3294	.4252	.4382	.4681	.3012
21		.3086	.3429	.443	.3944	.3641	.3189
22	.2058	.2774	.3086	.4334	.3601	.3772	.3155
23	.2058	.2601	.2915	.4207	.3429	.3467	.3189
24	.4115	.2058	.2601	.2947	.4075	.3429	.298
Max	.4115	.3121	.3429	.443	.4382	.4681	.3944
Min	.1463	.0854	.1543	.1734	.285	.2774	.2105
Avg	.3219	.1997	.2539	.2912	.3627	.3486	.2942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 104016 / 33 KV ANKISA

Feeder No / Name : 201 / 11 KV Waddam

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.6859	.6859	.7373	1.0802	.823	1.0974
2	.5487	.6859	.6687	.703	1.0631	.8059	1.0631
3	.5487		.5487	.703	1.0631	.8059	1.0288
4	.5487	.6344	.5487	.703	1.0802	.823	.9945
5	.5316	.6687	.5316	.7202	1.0802	.8573	.9945
6	.5144	.9602	.703	.7202	1.1317	.8573	1.0288
7	.1543	.6859	.8745	.9602	1.2689	.8573	1.2689
8		.6344	.9945	1.0117	1.2517	.7888	1.2346
9		.6173	.6859	.9774	1.2346	.823	1.0288
10		.6173	.6001	.8573	1.1317	.9259	.7716
11		.7888	.6344	1.0117	.5316	.8745	.7202
12		.8745	.4973	1.166	.5658	1.0117	
13		.8402	1.046	1.166	.8059	.9945	
14		.6859	1.0802	.9431	.9088	1.0288	
15		.7202	1.1145	1.0117		.823	
16		.8402	.9945	.9945	.9602	.7716	
17		.8745	1.2003	1.0631	.9259	1.046	
18		.703	1.2346	1.1488		1.0974	1.1317
19		.703	1.2517	1.1145		1.1831	1.1488
20		.7545	1.2346	1.2003		1.1488	1.1317
21		.7373	1.1831	1.2003		1.1145	1.1317
22	.6859	.7373	1.166	1.166		1.166	1.1831
23	.6687	.7202	.7888	1.1145		1.0974	1.166
24	1.0288	.6859	.6859	.7373	1.0974	.823	1.0974
Max	1.0288	.9602	1.2517	1.2003	1.2689	1.1831	1.2689
Min	.1543	.6173	.4973	.703	.5316	.7716	.7202
Avg	.5967	.7328	.8731	.9638	1.0106	.9395	1.0679

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 104016 / 33 KV ANKISA

Feeder No / Name : 202 / 11 KV Ankisa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8347	1.7147	1.7833	1.5947	1.9033	1.7147	1.5432
2	1.6461	1.6804	1.7661	1.5432	1.8861	1.7318	1.5432
3	1.6461		1.5089	1.5432	1.8861	1.7147	1.5432
4	1.5775	1.6461	1.5089	1.5604	1.9033	1.6804	1.5775
5	1.6632	1.749	1.5432	1.5604	1.9033	1.6804	1.6118
6	1.6461	2.3834	1.7833	1.5947	2.1262	1.6804	1.6461
7	.3086	2.3148		1.8347	2.1776	1.6632	1.8004
8		2.1262	1.7147	2.0576	2.2119	2.0405	1.7147
9		1.9376	1.8861	1.7318	1.989	2.1434	1.8861
10		1.9547	1.5775	1.9033	1.9376	2.0405	1.9204
11		1.6118	1.6461	2.0919	1.5947	1.7147	2.0576
12		1.7833		2.1434	1.9033	1.5947	2.0405
13		1.6804	1.6289	2.2119	2.0576	1.8861	2.1605
14		1.5775	2.0405	2.0919	2.1776	1.9204	1.9719
15		1.7318	2.0919	2.2119	1.2003	1.9204	1.6975
16		1.8347	2.1262	2.2634	1.6632	1.1831	1.5432
17		1.8519	2.0919	2.1262	1.5604	1.406	1.5775
18		1.9204	2.0919	2.0919		1.7833	1.9547
19		2.1091	.1543	2.2119		1.9719	1.9719
20		1.989	2.0233	2.2634		1.8519	1.9204
21		2.0062	2.0233	1.9547		1.8176	
22	1.8519	1.9033	1.6632	1.989		1.6804	
23	1.7833	1.8519	1.6461	1.989		1.7147	
24	1.7147	1.7147	1.7833	1.5947	1.9204	1.7147	1.5775
Max	1.8519	2.3834	2.1262	2.2634	2.2119	2.1434	2.1605
Min	.3086	1.5775	.1543	1.5432	1.2003	1.1831	1.5432
Avg	1.5672	1.8727	1.7310	1.9233	1.8890	1.7604	1.7743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 105002 / 66 KV SIRONCHA

Feeder No / Name : 401 / 33 KV BAMANI

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	1.2346	.7716	2.4691	2.9835	.9259	1.286
2	.6687	.6173	.7716	.9259	2.572	1.2346	.8745
3	1.1317	.7716	.9259	2.4691	2.9835	.7202	2.9321
4	.9259	.9259	.9259	.9259	2.9835	.8745	1.286
5	.9259	.6173	.9259	2.4691	2.9835	2.6749	1.286
6	.9259	.7716	1.4403	.9259	2.9835	1.2346	1.286
7	1.4403	.9259	1.4403	.8745	2.9835	1.2346	1.286
8		.9259	.8745	.8745	1.2346	.7202	1.286
9		.8745	.8745	.8745	1.2346	1.2346	1.286
10		.9259	.8745	.9259	2.9835	1.2346	1.286
11		1.0288	.9259	.8745	2.9321	1.3889	1.286
12		1.4403	.9259	1.0802	1.286	1.2346	1.286
13		.9259	.9259	.8745	1.2346	.7202	1.286
14		.9259	.9259	.8745	2.7778	1.2346	1.2346
15		.9259	.5144	.8745	2.6235	1.2346	1.2346
16		.9774	2.4691	.8745	2.1605	2.6235	1.2346
17		.9259	.9259	.8745	1.2346	1.3889	2.4691
18		.9774	2.4691	.9259	2.1605	1.2346	1.286
19		2.4691	.9259	.9259	2.1091	1.2346	1.2346
20		.9259	.9259	.5144	1.2346	.8745	1.3889
21		.9259	.9259	.8745	2.1605	.7716	2.4691
22	.9259	2.4691	.9259	.8745	.8745	.7202	1.3889
23	.9259	.9259	.9259	.9259	.8745	1.2346	.0463
24	2.4691	.9259	.9259	.9259	.9259	.7202	1.4403
Max	2.4691	2.4691	2.4691	2.4691	2.9835	2.6749	2.9321
Min	.6687	.6173	.5144	.5144	.8745	.7202	.0463
Avg	1.1060	1.0567	1.0609	1.0845	2.1048	1.1960	1.3908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

ALLAPALLI DIVISION[645]

SIRONCHA S/DN.[334] BU 4334

Substation No/ Name :- 105002 / 66 KV SIRONCHA

Feeder No / Name : 402 / 33 kv Ankisa

SHEDDABLE RURAL

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.9259	2.6749	1.4403	3.0864	2.4691	2.6749
2	.9259	.9259	.9259	2.9835	1.4403	2.9835	1.4918
3	.9259	2.572	2.572	.9774	2.9835	1.286	.9259
4	.9259	2.572	2.572	.9259	2.9835	2.9835	2.9835
5	.9259	2.4691	2.4691	2.0576	2.9835	2.9835	.8745
6	.9259	2.4691	2.0576	2.9835	2.9835	2.9835	1.4403
7	1.4403	.5144	2.572	.9259	2.9835	2.9835	1.4403
8		1.4403	.9259	1.3889	2.9835	2.9835	2.9835
9		2.4691	2.4691	1.4403	2.9835	2.9835	1.0288
10		2.4691	2.572	1.4403	2.9835	2.9835	2.9835
11		.5144	.9259	2.9835	2.9835	2.9835	3.9095
12		.9259	1.4403	1.3889	2.9835	2.9835	2.4691
13		2.5206	2.572	.8745	1.4403	2.9835	1.4403
14		1.4918	2.9321	1.4403	2.1605	2.9835	2.9835
15		2.572	.9774	.9774	2.9835	2.9835	2.9835
16		2.5206	2.9835	.9259	2.9835	2.9835	2.9835
17		2.4691	1.4403	.9259	2.9835	2.9835	2.9835
18		.9259	2.9835	1.1317	1.4403	2.9835	2.572
19		.9774	2.9321	1.4403	1.4403	2.9835	2.9835
20		2.5206	1.4403	1.4403	4.1152	2.9835	2.9835
21		2.4691	.8745	1.4403	2.9835	2.9835	2.9835
22	.9259	2.4691	2.4177	1.4403	2.572	2.9835	2.572
23	.9774	2.8807	.9259	.8745	2.9321	2.9835	2.9835
24	.9774	.9259	.9259	1.3889	2.572		2.9835
Max	1.4403	2.8807	2.9835	2.9835	4.1152	2.9835	3.9095
Min	.9259	.5144	.8745	.8745	1.4403	1.286	.8745
Avg	.9876	1.8754	1.9826	1.4682	2.7070	2.8873	2.4434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 201 / 11KV AWALGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6653	.6878	.8029	.5975	.7468	.6447
2	.6516	.6653	.6516	.7842	.5975	.7468	.6653
3	.6401	.6653	.6154	.7842	.5975	.7282	.6653
4	.5973	.6653	.5973	.7468	.5975	.7282	.6653
5	.5487	.6653	.543	.6908	.6348	.7095	.6653
6	.3982	.499	.5249	.5415	.4854	.6348	.5359
7	.3475		.4938	.4481	.4294	.4854	.4435
8	.4207		.4887	.5228	.3921	.4108	.4251
9	.4344		.543	.4854	.4481	.3921	.4251
10	.3258		.5415	.4668	.3547	.4066	.3506
11	1.4118		.5041	.4108	.3921	.4066	.3506
12	1.5203		.4854	.4294	.4108	.4066	
13	1.5203		.5041	.4854	.4108	.4024	
14	1.5203		.5228	.4854	.3921	.3696	.0362
15	1.7194		.4854	.4294	.4294	.2402	.0343
16		.4525	.5228	.4481	.3921	.3511	.0351
17		.5068	.4481	.4108	.4108	.3881	.3506
18	.4706	.5973	.5228		.5228	.462	.4557
19	.6154	.8326	.7842	.0934	.7842	.7392	.6135
20	.8688	.9231	1.0269	.4108	.9335	.8501	.7964
21	.8507	.9231		.7468	.9149	.8131	.7712
22	.7421	.8145	.8215	.6908	.7842	.7392	.7011
23	.6516	.7316	.7655	.6348	.7468	.6838	.6516
24		.6516	.6878		.5975	.7468	.6653
Max	1.7194	.9231	1.0269	.8029	.9335	.8501	.7964
Min	.3258	.4525	.4481	.0934	.3547	.2402	.0343
Avg	.8051	.6839	.5986	.5432	.5524	.5662	.4976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 202 / 11KV GANGALWADI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4883	.7265	.6379	.7619	.5493	.567	.6036
2	1.4883	.7265	.6201	.7619	.5493	.567	.5853
3	1.4706	.7087	.6024	.7442	.5316	.5493	.567
4	1.4529	.7087	.5847	.7442	.5316	.5493	.567
5	1.4266	.7087	.567	.7442	.5493	.5316	.5487
6	1.2803	.6024	.5316	.6379	.4607	.443	.4572
7	1.1706		.443	.4961	.3189	.3898	.4024
8	1.1706		.4252	.4961	.3544	.3721	.439
9	1.2986		.4075	.5316	.3544	.3189	.4207
10	1.0974		.3366	.4075	.3721	.3841	.3841
11	.4656		.4607	.3721	.3898	.4755	.4207
12	.4344		.5316	.3898	.4607	.4755	.1829
13	.4755		.5493	.3721	.4607	.4755	.3841
14			.4961	.4252	.3898	.4207	.3109
15			.5493	.4252	.4252	.4755	.3475
16		.5316	.5847	.4252	.4784	.4207	.3841
17	.3982	.691	.5847	.3721	.4252	.439	.4024
18	.4298	.6024	.7265	.3544	.5847	.4207	.439
19	.695	.691	.7796	.5138	.7265	.567	.5853
20	.7499	.7442	.7973	.6379	.7087	.6767	.567
21	.7682	.7442	.7442	.6379	.6201	.6767	.5853
22	.7133	.7087	.691	.6024	.5847	.6767	.6401
23	.8048	.6379	.7087	.567	.5316	.6219	.5853
24	1.4883	.7682	.6379	.7087	.5493	.567	.5853
Max	1.4883	.7682	.7973	.7619	.7265	.6767	.6401
Min	.3982	.5316	.3366	.3544	.3189	.3189	.1829
Avg	.9889	.6867	.5832	.5471	.4961	.5026	.4748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 203 / 11KV MENDKI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.815	.7973	.7619	.7087	.691	.7167
2	.7095	.815	.7442	.7619	.7087	.6733	.7167
3	.7095	.815	.7087	.7619	.7087	.6733	.7167
4	.6908	.815	.6733	.7442	.7087	.6556	.7167
5	.6722	.815	.6379	.7265	.7265	.6379	.7545
6	.5601	.6733	.6024	.6024	.5493	.5493	.5847
7	.5788		.6201	.567	.5316	.4961	.4755
8	.6161		.6024	.567	.4607	.5138	.5281
9	.7282		.7087	.443	.4784	.5316	.547
10	.4481		.7796	.6379	.5138	.3018	.6602
11	.7468		.6379	.6908	.5138	.679	.547
12	.3921		.7087	.5975	.5138	.6036	.547
13	.3734		.691	.6348	.5138	.6036	.3961
14			.6556	.6908	.567	.6413	.6224
15			.6379	.6722	.4075	.5281	.6036
16		.7442	.6201	.6908	.4252	.6036	.5847
17	.3898	.9036	.6535	.6201	.4607	.6036	.5281
18	.3898	.7265	.6201	.7087	.567	.5658	.4715
19	.9149	.9568	.7619	.691	.7265	.7545	.679
20	.9896	.9036	.9391	.9036	.8328	.8865	.7733
21	.9568	.9214	.9036	.8682	.7973	.9054	.7545
22	.9036	.8859	.7619	.7796	.7265	.9054	.6979
23	.8328	.8328	.7442	.7265	.6733	.8413	.6602
24	.7095	.815	.8328	.7442	.7087	.691	.7545
Max	.9896	.9568	.9391	.9036	.8328	.9054	.7733
Min	.3734	.6733	.6024	.443	.4075	.3018	.3961
Avg	.6677	.8292	.7101	.6914	.6054	.6474	.6265

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 204 / 11KV AWALGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.4083
2							1.4083
3							1.4083
4							1.4083
5							1.4083
6							1.4083
7							1.8564
8							1.8244
9							1.8564
10	1.7558		1.9845	1.9524	1.4403	1.5364	
11	.9145		2.1445	2.0485	1.4403	1.8884	
12	.9694		2.3045	2.2085	1.7924	2.0485	
13	.9877		2.2405	2.1125	1.7924	1.9845	
14	1.0242		2.0165	2.0805	1.7604	1.8564	
15	1.0059		2.0165	2.1445	1.7924	1.9845	
16		1.0059	1.9845	2.0805	1.5364	1.9204	
17	1.7284	2.0119	1.9845	.8962	1.8564	1.8564	
18		2.1125					
19		2.1125					
20		1.8442					
21		1.8107					
22		1.8107					
23		1.7772					
24			1.7436				
Max	1.7558	2.1125	2.3045	2.2085	1.8564	2.0485	1.8564
Min	.9145	1.0059	1.7436	.8962	1.4403	1.5364	1.4083
Avg	1.1980	1.8107	2.0466	1.9405	1.6764	1.8844	1.5541

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 206 / 11KV Chaugan

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5312	1.2498	1.2631	1.2631	1.3146	1.3394	1.2795
2	.5312	1.2793	1.1873	1.247	1.2971	1.3394	1.2795
3	.5506	1.2631	1.2146	1.247	1.3032	1.2971	1.2795
4	.5155	1.247	1.1984	1.2308	1.267	1.2795	1.2795
5	.506	1.247	1.1336	1.2146	1.2269	1.3213	1.2795
6	.4843	1.1336	1.1012	1.1498	1.1946	1.262	1.2269
7	.4843		1.3603	1.085	1.1393	1.2445	1.2269
8	.4843		1.3441	1.1984	1.3394	1.2795	1.3203
9	.4999		1.4737	1.2955	1.2851	1.3496	1.2986
10	.4374		1.3123	1.1336	1.3672	1.3672	1.2437
11			1.3765	1.1498	1.3575	1.1744	1.2449
12			1.3435	.9374	1.3321	1.1919	1.2449
13			1.4575	1.2308	1.3756	1.2445	1.2071
14	.9717		1.3441	1.2793	1.3937	1.2094	1.4523
15	1.1336		1.4413	1.2955	1.4118	1.1568	1.3203
16	1.0936	1.2631	1.4899	1.2955	1.3496	1.2445	1.226
17	1.1336	1.4089	1.2631	1.2308	1.4661	1.2971	1.2071
18	1.1336	1.4737	1.3279	1.1498	1.4198	1.3394	1.2449
19	1.1717	1.587	1.6032	1.3496	1.5249	1.262	1.3769
20	1.2498	1.2308	1.4737	1.5203	1.4899	1.4022	1.3957
21	1.2498	1.3279	1.4575	1.5023	1.4842	1.4198	1.3392
22	1.2498	1.3603	1.3441	1.3847	1.3847	1.3496	1.2826
23	1.2498	1.2498	1.2631	1.3321	1.3213	1.3146	1.226
24	.5312	1.2498	1.2793	1.2631	1.3496	1.2971	1.3496
Max	1.2498	1.587	1.6032	1.5203	1.5249	1.4198	1.4523
Min	.4374	1.1336	1.1012	.9374	1.1393	1.1568	1.2071
Avg	.8187	1.3047	1.3356	1.2494	1.3498	1.2910	1.2846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084012 / 33 KV GANGALWADI SUBSTATION

Feeder No / Name : 404 / 33KV Gangalwadi Incomer NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.6763	3.6214	3.786	3.2373	3.4019	4.8834
2		3.6763	3.4568	3.7311	3.2373	3.3471	4.8834
3		3.6763	3.3471	3.7311	3.1824	3.3471	4.8834
4		3.6214	3.2373	3.6763	3.1276	3.2922	4.8834
5		2.9081	3.0727	3.5665	3.1824	3.2373	4.8834
6		3.0727	2.963	3.1276	2.6886	2.963	4.4445
7			3.1276	2.7435	2.4691	2.6886	4.7188
8			3.0727	2.963	2.5789	2.6337	4.7188
9			3.3471	2.963	2.5789	2.6886	4.7737
10			5.3224	5.048	4.3347	4.225	2.6337
11			5.6516	5.1029	4.3347	4.8834	2.524
12	3.3471		5.7065	4.9931	4.8285	5.048	1.9204
13	3.3471		5.9808	5.2675	4.8285	4.9931	1.9204
14	3.5665		5.5418	5.4321	4.7737	4.7737	2.3594
15	4.0055		5.6516	5.4321	4.7737	4.6639	2.2497
16	1.262	4.2798	5.6516	5.3772	4.4993	4.8285	2.1948
17	4.0604	5.9259	9.7119	3.8409	4.9383	4.8834	2.4691
18	2.5789	5.9259	3.4019	2.3594	3.1824	2.7435	2.5789
19	3.5665	6.6392	4.1701	2.7435	3.8409	3.4568	3.2373
20	4.0604	6.0357	4.4445	3.5117	4.0604	3.8409	3.4568
21	4.0604	6.1454	3.3471	3.786	3.8409	3.786	3.4019
22	3.8409	5.9808	3.8409	3.5117	3.5665	3.6763	3.2922
23	3.786	5.6516	3.6763	3.3471	3.2922	3.5117	3.1276
24		3.7311	5.5418	3.6763	3.2922	3.4019	
Max	4.0604	6.6392	9.7119	5.4321	4.9383	5.048	4.8834
Min	1.262	2.9081	2.963	2.3594	2.4691	2.6337	1.9204
Avg	3.4568	4.7298	4.4536	3.9049	3.6946	3.7632	3.4973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084033 / 33 KV DELANWADI SUBSTATION

Feeder No / Name : 202 / 11 KV PETH WARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9044	1.9231	2.0538	2.1472	2.0165	1.8671	1.6804
2	1.8671	1.8111	1.9791	2.1098	1.9791	1.7924	1.7177
3	1.8484	1.7737	1.848	2.0911	1.9418	1.7924	1.7364
4	1.8298	1.7364	1.8298	2.0538	1.9044	1.7364	1.7551
5	1.7924	1.6804	1.7924	1.9791	1.8858	1.7551	1.7737
6	1.7737	1.643	1.7924	1.7924	1.8484	1.7177	1.8016
7	1.6244	1.5123	1.531	1.6617	1.4003	1.6991	1.8111
8	1.5123	1.4563	1.5123	1.6244	1.6057	1.6804	1.6057
9	1.6057		1.587	1.6617	1.6617	1.6991	1.5076
10	1.6057		1.531	1.643	1.6057	1.6057	1.5497
11	1.6057		1.8484	1.6991	1.7551	1.7177	1.6057
12	1.6057		1.8484	1.8111	1.7551	1.6804	1.251
13	1.6783		1.9978	1.7924	1.1016	1.6057	1.4937
14	1.8298		2.0351	1.7177	1.7551	1.5684	1.4003
15	1.8484		1.9605	1.7364	1.7551	1.5497	1.4377
16	1.6804		2.0314	1.587	1.7551	1.1763	1.3817
17	1.7282	2.0725	1.9605	1.7924	1.7364	1.587	1.363
18	1.7177	1.8671	1.9231	1.6617	1.5497	1.1763	1.4937
19	1.9605	2.1807	2.1285	2.0165	2.0165	2.1098	1.8111
20	2.1472	2.2592	2.2965	2.2218	2.0538	1.9978	1.7177
21	2.2519	2.3339	2.3152	2.2032	2.0144	1.9418	1.7364
22	2.2405	2.3712	2.3712	2.2144	2.0538	1.8858	1.6804
23	2.1472	2.2405	2.2965	2.1472	2.0351	1.8391	1.6244
24	2.3152	2.0351	2.2032	2.1658	2.0911	1.9044	1.7551
Max	2.3152	2.3712	2.3712	2.2218	2.0911	2.1098	1.8111
Min	1.5123	1.4563	1.5123	1.587	1.1016	1.1763	1.251
Avg	1.8384	1.9310	1.9447	1.8971	1.8032	1.7119	1.6121

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084033 / 33 KV DELANWADI SUBSTATION

Feeder No / Name : 203 / 11 KV Kharbi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4045	.4904	.2957	.5822	.6036	.2574
2	.4854	.5148	.415	.2772	.5516	.5658	.2442
3	.5228	.3734	.415	.2957	.5228	.5658	.2206
4	.5415	.3677	.3772	.2957	.4854	.5228	.2022
5	.5601	.3566	.3018	.4251	.4481	.5658	.1879
6	.2614	.3547	.2075	1.7741	.4108	.5847	.1655
7	.3734	.3174	.3395	.4805	.2801	.4904	.1471
8	.3734	.3174	.3772	.5175	.2054	.3584	.2022
9	.5332		.2641	.2022	.2054	.3547	.1501
10	.5228		.1463	.239	.2452	.4668	.1294
11	.5148		.5249	.2427	.3018	.0919	.1663
12	.5041		.5068	.4472	.2641	.1287	.1478
13	.4294		.5729	.3354	.3772	.1103	.1478
14	.5148		.5544	.2022	.415	.1287	.3511
15	.5487		.5729	.2758	.4338	.4854	.2772
16	.3841		.4251	.1867	.5093	.4964	.4066
17	.3921	.5658	.3511	.3945	.2452	.4668	.1478
18	.1307	.6224	.2587	.5601	.5093	.5415	.1663
19	.4481	.8402	.3511	.6161	.547	.5883	.2218
20	.5041	.7356	.4066	.6011	.5281	.4884	.2033
21	.5121	.5281	.3326	.6161	.6908	.4596	.6468
22	.5255	.5093	.3696	.5442	.6413	.3309	.7577
23	.4596	.5281	.3142	.5883	.6413	.4316	.7762
24	.4755	.4229	.5281	.2957	.6435	.6036	.2801
Max	.5601	.8402	.5729	1.7741	.6908	.6036	.7762
Min	.1307	.3174	.1463	.1867	.2054	.0919	.1294
Avg	.4596	.4849	.3918	.4462	.4452	.4346	.2751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084033 / 33 KV DELANWADI SUBSTATION

Feeder No / Name : 402 / 33 KV Delanwadi Incomer NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.384	2.3525	2.5206	2.4394	2.6326	2.4646	1.9504
2	2.3285	2.0165	2.3525	2.384	2.5206	2.3525	1.9504
3	2.3285	2.1285	2.2405	2.384	2.4646	2.3525	1.9504
4	2.3285	2.1285	2.1845	2.3285	2.4086	2.2405	1.9705
5	2.3285	2.0165	2.0725	2.384	2.3525	2.2965	1.9504
6	1.9959	2.0165	1.9605	2.2731	2.2405	2.2965	1.9705
7	1.9959	1.8484	1.8484	2.0513	1.6804	2.1845	1.9504
8	1.885	1.7924	1.8484	2.0513	1.7924	2.0165	1.8016
9	2.1285		1.8484	1.8296	1.9605	1.9044	1.6804
10	2.1285		1.6632	1.9044	1.8484	2.0408	1.6632
11	2.1285		2.384	1.9605	2.0165	1.7924	1.7741
12	2.1285		2.3285	2.2291	2.0165	1.7924	1.386
13	2.1285		2.5503	2.1176	1.4563	1.7924	1.6078
14	2.3525		2.5503	1.8947	2.1285	1.6804	1.7187
15	2.4086		2.4949	2.0165	2.1845	2.0165	1.7187
16	2.3594		2.4394	1.765	2.2405	1.6804	1.7741
17	2.1285	2.6326	2.2731	2.1511	1.9605	2.0725	1.4969
18	1.8484	2.4646	2.1622	2.2177	2.0165	1.7364	1.6632
19	2.4086	2.9938	2.4394	2.6326	2.5206	2.6612	1.9404
20	2.6326	2.9687	2.6612	2.9067	2.5766	2.4394	1.885
21	2.7586	2.8567	2.6057	2.8006	2.6886	2.384	2.384
22	2.7023	2.8567	2.7166	2.8149	2.6612	2.2405	2.4394
23	2.6326	2.7446	2.6057	2.6886	2.6326	2.3082	2.384
24	2.3285	2.4646	2.6886	2.4394	2.7026	2.4646	2.0062
Max	2.7586	2.9938	2.7166	2.9067	2.7026	2.6612	2.4394
Min	1.8484	1.7924	1.6632	1.765	1.4563	1.6804	1.386
Avg	2.2824	2.3926	2.3100	2.2777	2.2376	2.1338	1.8757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 201 / 11 kv Delanwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8059	.7522	.8059	.8238	.6984	.6268	.5731
2	.788	.7522	.8059	.8059	.6447	.6268	.5731
3	.7522	.7164	.788	.8059	.6447	.591	.5552
4	.7522	.6805	.7522	.7343	.5731	.5731	.5373
5	.6984	.6626	.6805	.6984	.5373	.5552	.5373
6	.6089	.6268	.6268	.6447	.5373	.5373	.5014
7	.5194	.5373	.5373	.5014	.4835	.4835	
8	.5014	.3582	.5014	.4835	.4477	.4656	.5014
9	.5014	.5194	.4835	.4835	.4656	.4119	.4835
10	.5373	.5014	.5014	.4656	.4656	.4119	.4477
11	.5373	.5014	.394	.4835	.4835	.4477	.4656
12	.5373	.5373	.5014	.4298	.5014	.4119	.4477
13	.5552	.5552	.5552	.4835	.4835	.4119	.4119
14	.5731	.5552	.5552	.4835	.5014	.3761	.394
15	.5552	.5552	.5194	.4835	.4656	.4119	.3582
16	.5731	.5373	.5731	.5014	.4477	.394	.3582
17	.5373	.5194	.5731	.5014	.4656	.4119	.4119
18	.5373	.5552	.591	.5373	.4656	.4656	.4477
19	.6626	.6268	.6268	.6447	.6447	.6089	.5258
20	.8238	.8059	.8417	.7522	.6984	.6447	.591
21	.8417	.8417	.8417	.788	.7343	.6447	.6089
22	.8954	.8954	.8954	.788	.7343	.6805	.6089
23	.8775	.8775	.8954	.788	.7164	.6447	.5731
24	.7522	.8059	.8238	.8059	.7343	.6447	.591
Max	.8954	.8954	.8954	.8238	.7343	.6805	.6089
Min	.5014	.3582	.394	.4298	.4477	.3761	.3582
Avg	.6552	.6365	.6529	.6216	.5656	.5201	.5002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 202 / 11 Kv Pimpalgaon AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.4575
2							1.6518
3							1.9631
4						.1296	1.9433
5							1.9757
6							2.0405
8							2.3137
9							2.1052
10	2.2186	2.0729	2.4777	2.1948	2.3482	2.1052	
11	2.4615	2.5749	2.6397	2.3777	2.4291	2.2672	
12	2.4291	2.6558	2.5911	2.332	2.5101	2.4291	
13	2.4291	2.5911	2.6882	2.3482	2.2672	2.4615	
14	2.5101	2.5911	2.5749	2.4939	2.2996	2.332	
15	2.5101	2.5911	2.7044	2.5263	2.2672	2.2996	
16		2.5101	2.5911	2.5425	2.2186	2.1052	
17	2.4291	2.6235	2.4129	2.3644	2.332	2.1052	
18	2.4939						
Max	2.5101	2.6558	2.7044	2.5425	2.5101	2.4615	2.3137
Min	2.2186	2.0729	2.4129	2.1948	2.2186	.1296	1.4575
Avg	2.4352	2.5263	2.585	2.3975	2.334	2.0261	1.9314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 203 / 11 KV TILAK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.4563	1.4563	1.4937	1.363	1.4563	1.307
2	1.2136	1.3817	1.419	1.4563	1.3443	1.475	1.2323
3	1.2136	1.363	1.419	1.4563	1.307	1.4563	1.1949
4	1.1576	1.307	1.3443	1.4003	1.2696	1.4377	1.1203
5	1.2696	1.2323	1.1203	1.3443	1.1576	1.4003	1.1203
6	1.2696	1.1016	.9335	1.1576	1.1016	1.307	1.0082
7	.9896	1.0269	.7655	.9896	.9522	1.2883	
8	.9335	.9896	.9709	.9335	.6908	.9149	.7095
9	.6722	.6908	.6908	.5784	1.3256	.6348	.6722
10	1.0082	1.1389	1.363	.8029	1.3256	.9522	.6722
11	1.1389	1.307	1.4937	.9149	1.4377	1.1949	1.2696
12	1.7177	1.5684	1.6991	1.0642	1.6057	1.2883	1.2323
13	1.6804	1.307	1.5684	.6908	1.4575	1.2696	1.4563
14	1.5497	1.1949	1.363	1.0829	1.643	1.3443	1.4563
15	1.8298	1.1389	1.1576	1.1389	1.8111	1.1016	1.475
16	1.8858	1.307	1.1203	.9522	1.643	.4108	1.419
17	1.6057	1.2136	1.2696	.9522	1.8111	1.363	1.531
18	1.5684	1.2136	1.6244	.9335	1.6804	1.4003	1.5684
19	1.307	1.531	1.475	.9335	1.9231	1.6617	1.5497
20	1.307	1.5123	1.5684	1.1203	1.7364	1.0456	1.5123
21	1.1389	1.1576	1.1389	1.1203	1.0829	.9896	.9335
22	1.6057	1.307	1.4003	1.475	1.7364	1.3817	1.6244
23	1.587	1.5684	1.307	1.4377	1.6617	1.475	1.7177
24	1.419	1.5123	1.475	1.475	1.2696	1.475	1.3256
Max	1.8858	1.5684	1.6991	1.4937	1.9231	1.6617	1.7177
Min	.6722	.6908	.6908	.5784	.6908	.4108	.6722
Avg	1.3474	1.2720	1.2976	1.1210	1.4307	1.2385	1.2656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 204 / 11 kv Pimpalgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5258	.5434	.5434	.5434	.5258	.4908
2	.5258	.5258	.5258	.5258	.5258	.5258	.4908
3	.5083	.5083	.5258	.4908	.5258	.4908	.4908
4	.4908	.5083	.5083	.5434	.4733	.4733	.4733
5	.5258	.5083	.5083	.5434	.4382	.4733	.4382
6	.4908	.5083	.4207	.4908	.4207	.4557	.4207
7	.3856	.4207	.4031	.4207	.4031	.4382	
8	.3506	.3681	.3506	.3506	.3506	.3506	.3856
9	.333	.3506	.298	.3155	.333	.3155	.333
10	.3506	.2804	.2629	.298	.3155	.2629	.3155
11	.3155	.2804	.2629	.2629	.2804	.2279	.2804
12	.298	.2629	.2804	.2629	.2804	.2629	.2804
13	.3155	.298	.2804	.298	.3506	.2629	.298
14	.333	.298	.2804	.298	.2454	.2629	.2804
15	.3155	.298	.298	.2804	.2629	.2454	.2279
16		.2804	.2804	.2804	.2804	.2454	.2804
17	.2804	.2629	.2454	.2629	.2753	.2629	.3681
18	.333	.298	.3155	.3155	.3506	.3856	.3506
19	.5083	.5258	.4733	.5258	.5959	.5434	.4557
20	.6485	.6661	.6485	.631	.631	.5959	.4908
21	.6485	.6661	.6661	.6485	.6135	.5609	.5083
22	.6135	.631	.5959	.6135	.5784	.5609	.4733
23	.5434	.5784	.5609	.5609	.5609	.5434	.4382
24	.5083	.5258	.5609	.5258	.5434	.5258	.5083
Max	.6485	.6661	.6661	.6485	.631	.5959	.5083
Min	.2804	.2629	.2454	.2629	.2454	.2279	.2279
Avg	.4412	.4324	.4207	.4287	.4241	.4083	.3948

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 205 / 11 KV Khed

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.5258	.5258	.4908	.4557	2.191	1.858
2	.4733	.5083	.5258	.4908	.4557	2.0157	1.8404
3	.4733	.4908	.5083	.4733	.4382	1.7528	1.7528
4	.4382	.4908	.4908	.4733	.4207	1.6651	1.8404
5	.4382	.4908	.4382	.4908	.4207	1.5775	1.9281
6	.4382	.4908	.3506	.4207	.3856	1.4899	1.9456
7	.3681		.3155	.3506	.3506	1.3847	
8	.3856			.333	.333	1.6126	
9	.2454		.3506	.3506	.3506	1.6827	.631
10	.2279		.2804	.3681		1.7353	.7537
11	.2454	.3506		.3681	.8413	1.9105	1.2445
12	.2454	.3856	.2103	.3856	.929	1.9105	1.2094
13	.3506	.4031	.2629	.3856	.9816	1.8054	.5959
14	.3681	.4031	.2454	.3506	1.5249	1.5424	.9816
15	.4207	.4031	.333	.3681	1.5424	1.6827	1.1919
16	.3856	.3681	.3155	.3506	1.6126	.8413	.6836
17	.3506	.3506	.3506	.2804	1.8755	1.4723	.964
18	.3681	.3856	.3856	.3506	1.9281	1.6827	1.6651
19	.4382	.4908	.4908	.4382	2.1735	1.9281	1.5074
20	.6135	.5434	.5959	.5609	2.1209	1.7878	1.3496
21	.6485	.5609	.4908	.5784	2.0508	1.9456	1.4723
22	.631	.5784	.5258	.5784	2.0858	1.858	1.5074
23	.5434	.5434	.5258	.5258	2.226	1.9982	1.7177
24	.5083	.5258	.5258	.4908	.5258	2.2786	1.8755
Max	.6485	.5784	.5959	.5784	2.226	2.2786	1.9456
Min	.2279	.3506	.2103	.2804	.333	.8413	.5959
Avg	.4207	.4645	.4111	.4273	1.1317	1.7396	1.3871

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 206 / 11KV UDAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5364	1.6827	1.6827	.7682	.4938
2	1.4998	1.6461	1.6827	.7682	.4938
3	1.4998	1.5364	1.6461	.7499	.5121
4	1.4815	1.4632	.4755	.7316	.4755
5	1.3717	1.4266	.4572	.7316	.4755
6	1.0425	1.1706	.3841	.6584	.4938
7	1.0791		.2743	.7133	.5121
8	1.134			.7499	.2926
9	1.3169		.6036	.7865	
10	1.6461		1.4632	.6036	
11	1.5729	.4572	.6036	.6584	
12	1.6461	.9511	.8413	.5487	
13	1.7924	.6036	.7682		
14	1.957		1.6644	.6767	
15	1.7375		1.957	1.262	
16	.5487		1.829		
17	1.39	.5853			
18	1.5364	.823			
19	1.6095	1.3169			
20	1.2437	1.5729	.7316		
21	1.4815	1.4266	.695		
22	1.39	1.4449	.7499		
23	1.8656	1.5546	.7499	.5121	
24	1.5364	1.829	1.6827	.7499	.4938
Max	1.957	1.829	1.957	1.262	.5121
Min	.5487	.4572	.2743	.5121	.2926
Avg	1.4548	1.2642	1.0471	.7293	.4714

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084035 / 33 KV B' PURI (KHED)

SUBSTATIO

Feeder No / Name : 406 / 33 kV B'Puri Incomer
Feeder KV- 33 / INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4696	4.7851	4.8377	3.9963	3.4705	4.6799	5.7316
2	4.3644	4.6799	4.7851	3.8912	3.3653	4.5222	5.8368
3	4.2593	4.4696	4.6799	3.8386	3.3128	4.1541	5.8894
4	4.1541	4.3118	3.4705	3.7334	3.1024	4.0489	5.9945
5	4.1541	4.2067	3.1024	3.6808	2.9447	3.8912	6.0997
6	3.6283	3.7334	2.6292	3.2602	2.8395	3.6808	5.9945
7	3.2076	1.893	2.2085	2.8921	2.6292	3.4705	
8	3.155	1.6827	2.0508	2.7343	2.0508	3.2602	3.8386
9	2.9447	1.4723	2.3663	2.524	2.3137	2.9973	4.3644
10	5.9945	4.0489	6.3626	4.9954	4.5748	5.5739	2.1559
11	6.31	5.5739	5.4687	5.3109	4.7325	6.1523	3.155
12	6.8884	6.0997	6.2049	5.2584	5.9419	6.4152	3.0498
13	7.1514	5.8368	6.2049	4.3118	5.8368	6.31	2.6818
14	7.3091	5.1532	6.8359	5.4687	6.2574	5.9419	2.9973
15	7.4669	5.1006	7.0462	6.1523	6.4152	5.8894	3.155
16	3.2602		6.7833	4.7851	6.2574	4.1015	2.6818
17	6.6255		4.9429	4.5222		5.7316	3.155
18	6.8884		2.7869	2.1033	4.3118	3.8386	3.9438
19	4.3644	4.3118	2.9447	2.4714	5.2058	4.6273	3.9438
20	4.5222	4.9429	4.2067	2.9973	5.048	3.9963	3.8386
21	4.6273	4.4696	3.7334	3.0498	4.417	4.0489	3.4179
22	4.9429	4.6799	3.9963	3.3653	4.9954	4.3644	4.1015
23	5.2584	4.9429	3.8912	3.6808	4.8903	4.5748	4.3118
24	4.2593	4.9954	4.8903	3.8912	3.4705	4.8377	4.2067
Max	7.4669	6.0997	7.0462	6.1523	6.4152	6.4152	6.0997
Min	2.9447	1.4723	2.0508	2.1033	2.0508	2.9973	2.1559
Avg	5.0086	4.3519	4.4346	3.8715	4.2776	4.6295	4.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084036 / 33 KV HARDOLI SUBSTATION

Feeder No / Name : 201 / 11 KV SONEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4752	.2947	.5735	.547	.4858	.3121	.3601
2	.4752	.2915	.5735	.547	.4858	.3121	.3601
3	.4752	.2915	.5668	.5304	.4961	.3121	.3429
4	.4752	.2429	.5668	.5243	.4481	.3294	.3601
5	.4752	.5182	.5668	.5243	.4902	.3429	.3601
6	.4641	.3401	.5668	.5243	.4744	.3688	.3086
7	.4687	.4572	.4858	.5182	.4902	.426	.3481
8	.5281	.5247	.5601	.4801	.4938	.4696	.3725
9	.5441	.3749	.5601	.502	.5093	.4858	.4049
10	.5535	.506	.5601	.502	.5182	.4321	.3749
11	.5312	.5182	.5441	.5281	.5506	.4012	.3749
12	.5281	.4696	.5801	.5281	.5344	.4012	.3749
13	.5535	.4752	.5898	.5281	.5441	.4111	.3749
14	.5668	.5668	.421	.4999	.5312	.1829	.1898
15	.5601	.5668	.5344	.5218	.5281	.3353	.253
16	.5601	.427	.5571	.5121	.5441	.3858	.2778
17	.16	.4915	.5601	.5121	.5636	.4062	.3086
18		.4877	.4572	.4321	.5335	.4062	.3241
19		.5668	.5093	.4843	.5851	.4481	.3725
20	.4752	.6154	.583	.4843	.6167	.2658	.3932
21	.5079	.6316	.583	.5281	.6093	.3647	.3932
22	.4961	.6081	.5735	.5218	.5864	.3725	.3725
23	.4744	.5992	.5601	.506	.5693	.3563	.3563
24	.4915	.4696	.583	.5533	.4858	.2947	.3561
Max	.5668	.6316	.5898	.5533	.6167	.4858	.4049
Min	.16	.2429	.421	.4321	.4481	.1829	.1898
Avg	.4927	.4723	.5507	.5142	.5281	.3676	.3464

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084036 / 33 KV HARDOLI SUBSTATION

Feeder No / Name : 202 / 11 KV LADAJ AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1132	.1132	.1132	.1132	.1132	1.3592
2	.132	.1132	.1132	.1132	.1132	.1132	1.442
3	.1132	.1132	.1132	.1132	.1132	.1132	1.3757
4	.1132	.0943	.1132	.1132	.0943	.1132	1.3435
5	.1109	.1132	.0914	.1132	.0943	.112	1.4091
6	.0914	.0924	.0732	.0943	.0924	.0924	1.4091
7	.0724	.0739	.0532	.0739	.0739	.0732	1.5581
8	.0537	.0716	.0537	.0566	.0739	.0532	1.5565
9	.0537	.0532	.0537	.0543	.0747	.0532	1.4918
10	1.1984	1.0688	1.3923	1.5261	1.2929	1.1702	.0526
11	1.1012	1.5061	1.7661	1.5261	1.5927	1.1105	.0351
12	1.1633	1.6766	1.7465	1.6263	.3563	1.4922	.0351
13	1.6385	1.7465	1.7635	1.6712	1.5746	1.3592	.0343
14	1.7101	1.7772	1.576	1.6598	1.5746	1.3443	.0343
15	1.6575	1.7772	1.5083	1.7101	1.6095	1.3443	.0335
16	1.6409	1.7126	1.5927	1.7101	1.56	1.4899	.0339
17	1.6078	1.6956	1.6244	1.6385	1.56	1.4899	.0526
18		.0332	.0335	.0339	.0724	.0358	.0914
19		.112	.0934	.112	.1109	.1109	.112
20	.1509	.1509	.1509	.132	.1357	.132	.132
21	.1509	.1509	.1509	.1509	.1509	.132	.132
22	.132	.132	.132	.1132	.132	.1132	.1132
23	.132	.1132	.1132	.1132	.1132	.1132	.1132
24	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Max	1.7101	1.7772	1.7661	1.7101	1.6095	1.4922	1.5581
Min	.0537	.0332	.0335	.0339	.0724	.0358	.0335
Avg	.6023	.6085	.6056	.6117	.533	.5162	.5860

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084036 / 33 KV HARDOLI SUBSTATION

Feeder No / Name : 203 / 11 KV NAVEGAON AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.4725	.6019	.6249	.6405	.5624	
2	.3963	.4725	.5864	.6249	.6405	.578	
3	.3963	.4725	.5864	.6173	.6405	.578	
4	.442	.442	.5864	.6327	.6249	.5556	
5	.4572	.442	.5792	.6481	.6249	.5401	
6	.4725	.5487	.5487	.6481	.6718	.503	
7	.5335	.5639	.4858	.703	.7343	.6483	
8	.5693	.6401	.703	.7407	.7186	.6483	
9	.571	.5944	.703	.7499	.7253	.6483	
10							.3437
11							.4062
12							.4687
13							.4687
14							.4062
15							.4374
16							.4268
17							.442
23		.3511					
24	.3658	.4877	.5864	.578	.6093	.5247	.3201
Max	.571	.6401	.703	.7499	.7343	.6483	.4687
Min	.3658	.3511	.4858	.578	.6093	.503	.3201
Avg	.4600	.4989	.5967	.6568	.6631	.5787	.4133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084036 / 33 KV HARDOLI SUBSTATION

Feeder No / Name : 204 / 11KV Navegaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3326	.3326	.3326	.1478	.2957	.3142
2	.3142	.3326	.3326	.3326	.3326	.2957	.3142
3	.3142	.3326	.3326	.3326	.3326	.2957	.3142
4	.2957	.2957	.3326	.3326	.2587	.2957	.3142
5	.2957	.3511	.3326	.3326	.3142	.3142	.3326
6	.2957	.3326	.3326	.3326	.2772	.3326	.3326
7	.2218	.2402	.2587	.2402	.2033	.2587	.2772
8	.2033	.2033	.2033	.2033	.2218	.2218	.2402
9	.2033	.1478	.2033	.2033	.1848	.2033	.2033
10	.1478	.1848	.1663	.1663	.1663	.2033	.1478
11	.1663	.1663	.1478	.1478	.1663	.1478	
12	.1848	.1663	.1294	.1663	.1478	.1478	.1478
13	.1848	.1848	.1294	.1478	.1848	.1478	.1663
14	.2033	.1848	.1663	.1663	.2218	.1294	.1478
15	.1848	.1848	.1663	.1663	.1663	.1478	.1478
16	.1663	.1848	.1663	.1478	.1848	.1478	.1848
17	.1663	.1478	.1478	.1478	.1848	.1848	.1478
18		.2218	.1848	.1848	.2587	.2402	.2772
19		.3326	.3326	.3326	.3326	.3326	.3326
20	.4435	.4251	.4066	.3881	.3881	.3511	.3511
21	.4435	.4435	.3881	.4066	.4066	.3881	.3511
22	.3881	.3881	.3881	.3696	.3881	.3511	.3142
23	.3511	.3511	.3511	.3511	.3511	.3326	.2957
24	.3142	.3326	.3511	.3326	.3326	.3142	.3142
Max	.4435	.4435	.4066	.4066	.4066	.3881	.3511
Min	.1478	.1478	.1294	.1478	.1478	.1294	.1478
Avg	.2638	.2695	.2618	.2610	.2564	.2533	.2595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 084036 / 33 KV HARDOLI SUBSTATION

Feeder No / Name : 407 / 33 KV Hardoli Incomer NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.278	1.1797	1.6221	1.5729	1.5729	1.4289	2.2862
2	1.278	1.3717	1.5729	1.5729	1.5729	1.4861	2.4006
3	1.278	1.3717	1.5729	1.5729	1.5729	1.278	2.2862
4	1.3272	1.2574	1.5729	1.5729	1.4255	1.278	2.2862
5	1.3272	1.6575	1.5729	1.6221	1.5238	1.278	1.9685
6	1.3272	1.5432	1.5238	1.5729	1.5238	1.278	1.9216
7	1.3272	1.3763	1.4746	1.5238	1.5238	1.3763	2.0153
8	1.3763	1.4746	1.5238	1.5238	1.5238	1.3763	2.0622
9	1.3763	1.1431	1.5238	1.5238	1.5238	1.3763	1.9685
10	1.917	1.8519	2.2119	2.0645	1.9662	1.9547	.8796
11	1.6918	2.3148	2.3594	2.1125	2.1559	1.749	.787
12	1.9547	2.3663	2.4691	2.2085	.9602	2.1091	.9722
13	2.2497	2.4177	2.2965	2.3045	2.1033	1.917	1.0185
14	2.2965	2.572	2.0153	2.2028	2.1491	1.6712	.7407
15	2.2497	2.572	2.2634	2.2497	2.1033	1.781	.8333
16	2.2028	2.1559	2.1559	2.2028	2.0576	1.9685	.8796
17	1.933	2.3663	2.2028	2.4177	2.3148	2.0153	.9259
18		.6859	.8002	.6316	1.0288	.6401	.8002
19		1.1431	1.086	.8745	.9145	.8745	.9145
20	1.0059	1.3146	1.2574	.9717	1.3146	.8002	.9717
21	1.1043	1.3717	1.0059	1.2003	1.3146	.9717	.9717
22	1.1431	1.2574	1.2003	1.1431	1.2574	.9145	.8573
23	1.086	1.2003	1.1431	1.086	1.1431	.8573	.8573
24	1.4861	1.3763	1.6221	1.5238	1.5238	1.4289	1.0059
Max	2.2965	2.572	2.4691	2.4177	2.3148	2.1091	2.4006
Min	1.0059	.6859	.8002	.6316	.9145	.6401	.7407
Avg	1.5553	1.6392	1.6687	1.6355	1.5863	1.4087	1.3588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 400 / Auxiliary Supply

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5601
Max	.5601
Min	.5601
Avg	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 401 / 33 KV Nanhuri

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 402 / Nagbhid

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	7.7646
Max	7.7646
Min	7.7646
Avg	7.7646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 404 / Gangal Wadi

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	3.3848
Max	3.3848
Min	3.3848
Avg	3.3848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 407 / Hardoli NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.9722
Max	.9722
Min	.9722
Avg	.9722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 087009 / 132 KV BRAMHAPURI SUBSTATION

Feeder No / Name : 409 / Menda NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	1.3146
Max	1.3146
Min	1.3146
Avg	1.3146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 104022 / 33 KV NANHORI SUBSTATION

Feeder No / Name : 201 / 11KV NANHORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.3601	.3294	.3641	.3506	.3429	.3086
2	.2835	.3601	.3294	.3641	.3429	.3429	.3086
3	.2835	.3601	.3294	.4334	.3429	.3429	.3086
4	.2835	.3601	.3294	.3641	.3429	.3429	.3086
5	.2629	.3052	.3294	.3429	.3429	.3429	.2572
6	.2279	.218	.3018	.3052	.2743	.3052	.2229
7	.2229	.2294	.2035	.2743	.2058	.2374	.2103
8	.2229	.3149	.2486	.2713	.1844	.2347	.1865
9	.2543	.3149	.2321	.3018	.2294	.2652	.2401
10	.2713	.2713	.2374	.2883	.2883	.1943	.2254
11	.2486	.285	.2915	.3018	.3052	.2486	.1943
12	.3052	.3222	.2743	.3018	.3018	.2515	.1943
13	.2155	.3391	.2543	.1341	.3391	.2652	.1739
14	.1341	.3258	.2486	.1357	.3429	.2347	.1718
15	.1326	.2713	.3561	.1543	.3258	.2294	.1581
16	.2683	.3353	.3018	.1341	.3121	.144	.1638
17	.2785	.2984	.1823	.1326	.3052	.2429	.1638
18	.2984	.2458	.3113	.2721	.3113	.2622	.2058
19	.3772	.3294	.3688	.3467	.373	.3258	.2328
20	.4031	.3506	.4161	.3856	.3944	.3506	.2686
21	.4031	.3856	.3988	.4031	.407	.3601	.2686
22	.3814	.3641	.3814	.3772	.3688	.3429	.2686
23	.3601	.3429	.373	.3561	.3561	.3222	.2481
24	.2835	.3601	.3294	.3641	.3506	.3429	.3086
Max	.4031	.3856	.4161	.4334	.407	.3601	.3086
Min	.1326	.218	.1823	.1326	.1844	.144	.1581
Avg	.2786	.3187	.3066	.2962	.3207	.2864	.2332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 104022 / 33 KV NANHORI SUBSTATION

Feeder No / Name : 202 / 11KV TORGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7377	.8684	.852	.8333	.8619	.6554	.7956
2	.7377	.8583	.8356	.8333	.8421	.6554	.7956
3	.7377	.8583	.8356	.8333	.8421	.6554	.7956
4	.7042	.8583	.8356	.8333	.8421	.6554	.7956
5	.6554	.7811	.8356	.8124	.8421	.6478	.7373
6	.6154	.5182	.7432	.8162	.759	.664	.5407
7	.1886	.7562	.7842	.8322	.7907	.7773	.6962
8	.6154	.759	.8642	.9339	.6173	.8642	.6882
9	.7611	.8539	.828	.9503	.7968	.8482	.5761
10	.8122	.8322	.9012	1.0059	.8421	.6642	.5218
11	.8322	.8436	.8907	.9503	.9175	.7773	.4755
12	.852	.8162	.9503	.9503	.9614	.8802	.4401
13	.679	.852	.9282	.8642	.9555	.9175	.4089
14	.7274	.9012	.9069	.68	1.0486	.8907	.3948
15	.7522	.9282	.8802	.7748	.7522	.7274	.3567
16	.8259	.9231	.9282	.6958	.9069	.5401	.3144
17	.6405	.7522	.6154	.7811	.9448	.7499	.3338
18	.4668	.7621	.7827	.8162	.8535	.8002	.3395
19	.8583	.7935	.828	.8642	.9014	.8259	.3768
20	.9282	.9012	.9393	.8848	.9122	.852	.4024
21	.9448	.9012	.9012	.9012	.8697	.8642	.4024
22	.9012	.8848	.9116	.8907	.8749	.8583	.3812
23	.8421	.8421	.8907	.8436	.6562	.8162	.3768
24	.7377	.8684	.852	.8333	.8453	.6554	.7956
Max	.9448	.9282	.9503	1.0059	1.0486	.9175	.7956
Min	.1886	.5182	.6154	.68	.6173	.5401	.3144
Avg	.7314	.8297	.8550	.8506	.8515	.7601	.5309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 104022 / 33 KV NANHORI SUBSTATION

Feeder No / Name : 203 / 11KV NANDGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.0753
2							1.0753
3							1.0753
4							1.0753
5							1.0936
6							1.0936
7							1.2643
8							1.2334
9							1.0155
10	1.2452	1.2003	1.3108	1.3094	1.326	1.186	
11	1.3765	1.3927	1.5424	1.5415	1.4752	1.4255	
12	1.491	1.4918	1.5592	1.5746	1.5424	1.5074	
13	.9922	1.5927	1.6263	1.5238	1.4582	1.5238	
14		1.5592	1.5249	1.3279	1.491	1.4723	
15		1.5238	1.5592	1.4419	1.3765	1.4563	
16	1.2146	1.5249	1.5257	1.3927	1.5424		
17	1.2955	1.442	1.2308	1.4243	1.576		
18	1.3441					1.0936	
19	1.2803					1.1111	
24							.9804
Max	1.491	1.5927	1.6263	1.5746	1.576	1.5238	1.2643
Min	.9922	1.2003	1.2308	1.3094	1.326	1.0936	.9804
Avg	1.2799	1.4659	1.4849	1.4420	1.4735	1.347	1.0982

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

BRAMHAPURI S/DN.[331] BU 4331

Substation No/ Name :- 104022 / 33 KV NANHORI SUBSTATION

Feeder No / Name : 401 / 33 KV Nanhori NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.2289	1.1797	1.2574	1.1934	.9831	2.1605
2	1.0059	1.2146	1.1305	1.2574	1.1797	.9831	2.1605
3	1.0059	1.2146	1.1305	1.2574	1.1797	.9831	2.1605
4	.9556	1.2146	1.1305	1.2574	1.166	.9831	2.1605
5	.8951	1.1043	1.1305	1.1934	1.166	.9717	2.0645
6	.8356	.7407	1.0437	1.1437	1.1523	.9717	1.8501
7	.407	.9722	.9602	1.1043	.9962	1.0082	2.1125
8	.8259	1.0311	1.0911	1.166	.7968	1.1043	2.0622
9	1.0322	1.1385	1.0311	1.2289	1.0311	1.1043	1.8027
10	2.2834	2.3045	2.4291	2.556	2.4291	1.9662	.7202
11	2.4777	2.4371	2.6092	2.7206	2.6235	2.372	.6687
12	2.6235	2.5446	2.7526	2.7692	2.7206	2.5926	.6161
13	2.2028	2.7206	2.7526	2.4966	2.6886	2.6406	.5498
14	.8642	2.6886	2.6235	2.0873	2.7846	2.5309	.5498
15	.8539	2.6886	2.7526	2.3245	2.4006	2.4006	.5007
16	2.2297	2.7206	2.7035	2.1822	2.6406	.6859	.4778
17	2.1559	2.4486	1.9444	2.2965	2.7526	.9602	.4715
18	2.2862	1.0059	1.07	1.0517	1.1431	1.0311	.5155
19	2.4669	1.1305	1.186	1.2146	1.2334	2.2028	.6036
20	1.2929	1.2289	1.3426	1.3923	1.3117	1.166	.6613
21	1.358	1.2929	1.278	1.2929	1.2334	1.2146	.6613
22	1.278	1.2289	1.2929	1.2631	1.2186	1.1523	.6613
23	1.166	1.166	1.2631	1.186	.9962	1.078	.6036
24	1.0059	1.2289	1.1797	1.2574	1.2071	.9831	2.0645
Max	2.6235	2.7206	2.7526	2.7692	2.7846	2.6406	2.1605
Min	.407	.7407	.9602	1.0517	.7968	.6859	.4715
Avg	1.4381	1.6123	1.6253	1.6232	1.6352	1.4196	1.2025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084013 / 33/11KV WALNI S/STN.

Feeder No / Name : 201 / 11 KV TALODI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.8213	.7324	.7011	.6858		.6341
2	.7308	.8248	.6885	.6661	.6711		.581
3	.7148	.7722	.6502	.6733	.6619		.543
4	.6795	.7897	.6275	.6447	.6488		.5581
5	.6788	.7278	.6676	.6089	.6732		.591
6	.6994	.7066	.6516	.5792	.6516		.6255
7	.6863	.6181	.6037	.5194	.5992		.567
8	.7397	.694	.6147	.5316	.5803		.6221
9	.757	.7674	.7059	.6355	.6415		.6495
10	.8153	.8022	.8145	.7522	.6851	.6646	.6154
11	.9116	.8162	.8507	.7133	.6882	.7285	.581
12	.8543	.8596	.7522	.695	.6492	.6315	.5073
13	.8033	.8247	.7701	.7008	.6633	.6535	.5646
14	.7522	.7905	.6733	.7585	.6221	.6674	.5036
15	.8153	.8381	.7164	.6889	.6121	.6903	.5238
16	.749	.8435	.7619	.6436	.6095	.5998	.5634
17	.7296	.669	.7087	.7108	.7061	.5932	.4933
18	.728	.6683	.691	.6393	.6973	.6042	.478
19	.8679	.8334	.7164	.7304	.7626	.7506	.6481
20	.9877	.9202	.8145	.7693	.7538	.8073	.6894
21	.957	.8843	.8413	.7108	.7714	.7722	.6749
22	.8971	.8641	.8145	.7077		.7483	.6667
23	.8378	.8153	.7602	.6935		.6899	.627
24	.7483	.837	.7475	.7343	.6828		.6739
Max	.9877	.9202	.8507	.7693	.7714	.8073	.6894
Min	.6788	.6181	.6037	.5194	.5803	.5932	.478
Avg	.7863	.7912	.7240	.6753	.6690	.6858	.5909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084013 / 33/11KV WALNI S/STN.

Feeder No / Name : 202 / 11 KV BALAPUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4301	.4207	.3957	.4508	.4097	1.0365	.3789
2	.4287	.3689	.3823	.4287	.3935	1.0321	.341
3	.4102	.3366	.3456	.4287	.3944	.9933	.3059
4	.3909	.3772	.3605	.4409	.3797	.9735	.3218
5	.3891	.4448	.4088	.4239	.3983	1.0067	.3541
6	.422	.4895	.3891	.3688	.3726	.9858	.3365
7	.4673	.5316	.4955	.4372	.4249	.9741	.3996
8	.4823	.5855	.5476	.5256	.4424	.8477	.4873
9	.5203	.6516	.5117	.5444	.491		.422
10	.5733	.618	.5596	.5133	.4904	.0346	.3747
11	.5928	.5921	.5138	.5002	.458	.0445	.3145
12	.5864	.5981	.4915	.4696	.4662	.3878	.3131
13	.5408	.5389	.4527	.4613	.4678	.4296	.297
14	.5608	.5396	.3113	.4156	.4753	.465	.2649
15	.5489	.5344	.3795	.4321	.4291	.5047	.2655
16	.5245	.5164	.4161	.3716	.4196	.5186	.2567
17	.5079	.4072	.4641	.455	.4001	.4561	.2257
18	.5489	.4774	.502	.2928	.3609	.3668	.2294
19	.5207	.5224	.5087	.3773	.4207	.4377	.2993
20	.5138	.5166	.5434	.413	.4815	.4425	.3366
21	.5327	.5205	.5375	.4617	.4557	.4198	.3217
22	.4582	.4753	.5144	.4415	1.1233	.4175	.3206
23	.4377	.4892	.4801	.4202		.412	.3009
24	.4193	.4193	.4334	.4854	.4079	1.0577	.3953
Max	.5928	.6516	.5596	.5444	1.1233	1.0577	.4873
Min	.3891	.3366	.3113	.2928	.3609	.0346	.2257
Avg	.4920	.4988	.4560	.4400	.4593	.6193	.3276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084013 / 33/11KV WALNI S/STN.

Feeder No / Name : 203 / 11KV sawargaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0348	2.3872	2.1219	2.2192	2.1413	2.2983	2.1895
2	1.975	2.3663	2.0547	2.1365	2.1029	2.2891	2.146
3	1.9135	2.3663	2.0165	2.0957	2.1052	2.245	2.0814
4	1.8254	2.2634	1.9426	2.0454	2.0501	2.2181	2.0245
5	1.7878	2.2926	1.842	2.0119	2.086	2.2106	
6	1.7357	2.1919	1.8129	1.917	1.9657	2.1838	
7	1.9249	2.1196	1.9393	1.8461	1.8708	2.027	.9085
8	2.0245	2.3948	2.1338	2.0454	1.8874	2.1021	1.7456
9	2.2081	2.4898	2.1879	1.8293	2.0386	2.0293	1.9727
10	2.1628	2.3739	2.1051	1.7751	2.1514	2.0082	1.8816
11	2.2282	2.3632	2.1548	1.8138		2.0624	1.6683
12	2.146	2.5293	1.917	1.8918	2.2096	2.027	1.5656
13	2.1895	2.0199	2.3537	1.8785	2.1196	1.9566	1.4918
14	2.3061	2.3268	2.0719	2.2222	2.0862	1.9589	1.465
15	2.2853		1.9006	2.1589	2.0294	.9745	1.3907
16	1.7858	1.7858	1.9271	2.202	2.0741	.9116	1.4858
17	1.9105	1.6414	1.9595	2.2121	2.0576	2.0525	1.5729
18	2.2865	2.0506	1.9433	.2809	1.9639	2.1284	1.4486
19	2.5007	2.2169	2.1125	1.9504	2.2043	2.3765	1.654
20	2.5396	2.2737	2.5034	2.3137	2.3715	2.5262	1.8277
21	2.5918	2.1498	2.4177	2.3071	2.3387	2.3439	1.809
22	2.5029	2.1701	2.34	2.2603	2.3712	2.3452	1.7622
23	2.4321	2.1457	2.2891	2.2018		2.2282	1.7126
24	2.0973	2.4123	2.1802	2.2885	2.1631	2.3242	2.2282
Max	2.5918	2.5293	2.5034	2.3137	2.3715	2.5262	2.2282
Min	1.7357	1.6414	1.8129	.2809	1.8708	.9116	.9085
Avg	2.1415	2.2318	2.0928	1.9960	2.1086	2.0762	1.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084013 / 33/11KV WALNI S/STN.

Feeder No / Name : 204 / 11kv JNV express feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0382	.0439	.0379	.0377	.041	.0362	.0287
2	.038	.0404	.0358	.036	.0394	.0361	.0268
3	.0357	.0399	.0342	.0339	.0393	.0323	.0269
4	.039	.0452	.0337	.0339	.0376	.0322	.025
5	.037	.0464	.0368	.0352	.0358	.0338	.0275
6	.0368	.0459	.0395	.0402	.0384	.0355	.0278
7	.0487	.0525	.047	.0491	.0439	.0341	.0406
8	.0327	.0449	.0506	.0443	.0325	.0323	.0379
9	.035	.0356	.0364	.0425	.0306	.0384	.0386
10	.0259	.0339	.0291	.0311	.0376	.0397	.0356
11	.0237	.0308	.0285	.0452	.0453	.0219	.0289
12	.0307	.0411	.0315	.04	.0406	.0258	.0349
13	.026	.0391	.0377	.0367	.0343	.0263	.0368
14	.0345	.033	.0322	.0314	.0299	.0334	.033
15	.0287	.0313	.0337	.0347	.0317	.0363	.0338
16	.0249	.0375	.0312	.0331	.023	.0355	.0293
17	.0302	.031	.0381	.0326	.0236	.0296	.0271
18	.024	.0334	.0309	.0466	.0343	.0348	.0278
19	.0417	.0405	.0426	.0444	.0342	.0505	.0322
20	.0504	.0597	.0485	.0537	.0419	.0487	.0313
21	.0529	.048	.0543	.049	.0401	.0416	.0415
22	.0588	.0536	.0532	.0515	.0507	.0422	.0423
23	.0501	.0484	.0456	.0478		.0395	.0339
24	.0367	.0437	.0402	.0421	.0445	.0381	.0341
Max	.0588	.0597	.0543	.0537	.0507	.0505	.0423
Min	.0237	.0308	.0285	.0311	.023	.0219	.025
Avg	.0367	.0417	.0387	.0405	.0370	.0356	.0326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084034 / 33 KV MENDHA S/STN

Feeder No / Name : 201 / 11 KV MENDHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.3506	.333	.3366	.2743	.3121	.3045
2	.3155	.333	.333	.3189	.2947	.3121	.2835
3	.333	.3294	.333	.3189	.2743	.3012	.2835
4	.333	.3189	.333	.3189	.2947	.2835	.3045
5	.3366	.3012	.3366	.3189	.3012	.2658	.2915
6	.2601	.298	.2572	.2629	.2427	.2835	.2629
7	.218	.2658	.2204	.2347	.2035	.2279	.1907
8	.2012	.2429	.2486	.2374	.208	.1949	.1696
9	.2012	.2267	.3012	.2515	.1619	.156	.1907
10	.1865	.2155	.285	.2012	.1865	.1509	.1619
11	.2103	.2601	.3052	.208	.218	.208	.1638
12	.2279	.2572	.2883	.2267		.2204	.128
13	.2012	.2401	.3086	.2591		.2401	.1337
14	.2321	.2427	.2658	.2753		.2056	.1423
15	.2204	.2294	.2374	.2267		.1943	.1235
16	.2241	.25	.3012	.253		.208	.1406
17	.2303	.2105	.2561	.1406	.1696	.208	.1372
18	.2658	.2846	.1974	.2254	.2683	.2241	.1715
19	.3366	.2804	.3688	.2629	.3086	.2774	.2534
20	.4075	.394	.3721	.3582	.3721	.3506	.2896
21	.3749	.394	.333	.3544	.3721	.3681	.3109
22	.3681	.3721	.3641	.3366	.3506	.3429	.3077
23	.3401	.333	.3391	.3155	.3366	.3361	.2896
24	.3155	.3201	.333	.3366	.2947	.3189	.3045
Max	.4075	.394	.3721	.3582	.3721	.3681	.3109
Min	.1865	.2105	.1974	.1406	.1619	.1509	.1235
Avg	.2773	.2896	.3021	.2741	.2701	.2579	.2225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084034 / 33 KV MENDHA S/STN

Feeder No / Name : 202 / 11 KV MOUSHI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.3506	.3856	.3506	.3856	.3681	.3681
2	.4031	.3403	.3856	.3506	.3681	.3721	.3506
3	.4031	.3366	.3856	.3506	.3856	.3544	.3467
4	.3988	.3189	.3856	.3721	.3641	.3366	.3506
5	.3814	.3189	.3856	.3761	.3814	.3189	.3353
6	.3658	.3045	.3361	.3086	.3086	.2835	.3018
7	.2915	.2401	.285	.2883	.2774	.2658	.2486
8	.285	.2785	.3113	.2818	.2804	.2835	.1844
9	.2785	.3041	.3077	.2622	.208	.213	.213
10	.2949	.3113	.3315	.2374	.2652	.2267	.176
11	.2753	.3077	.3149	.2458	.2785	.2294	.144
12	.2881	.285	.2984	.213		.2429	.125
13	.3077	.2753	.3681	.2561		.2622	.125
14	.3315	.3467	.3189	.2915		.2881	.1581
15	.2652	.2458	.3052	.2753		.2439	.1423
16	.2591	.2818	.2949	.2688		.25	.1658
17	.2658		.2915		.2486	.2591	.1219
18	.3012	.3005	.2787		.1619	.2778	.1865
19	.3366	.3856	.373	.3641	.3772	.3814	.2507
20	.4252	.4656	.4477	.443	.407	.4252	.3326
21	.4706	.4656	.443	.4607	.443	.4161	.3366
22	.439	.4252	.4031	.4298	.4252	.39	.3258
23	.3982	.3856	.3641	.4163	.4075	.373	.3077
24	.4031	.3658	.3856	.3544	.3814	.3898	.3681
Max	.4706	.4656	.4477	.4607	.443	.4252	.3681
Min	.2591	.2401	.2787	.213	.1619	.213	.1219
Avg	.3447	.3322	.3494	.3271	.3345	.3105	.2486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 084034 / 33 KV MENDHA S/STN

Feeder No / Name : 203 / 11KV KOTGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7186	1.1401	1.153	1.2517	1.0814	1.2269	1.0852
2	.7186	1.17	1.153	1.2483	1.0774	1.2226	1.073
3	.7186	1.2048	1.153	1.2483	1.1065	1.2048	1.0562
4	.7186	1.1871	1.153	1.1831	1.1361	1.2094	1.073
5	.7011	1.1517	1.1401	1.1191	1.1105	1.2178	1.1218
6	.6344	1.0808	1.0486	1.0442	1.0486	1.1694	
7	.7122	1.0202	1.1105	1.094	1.0364	1.2226	1.0159
8	.8029	1.1797	1.2431	1.21	1.1736	1.3112	1.0526
9	.763	1.2452	1.1142	1.1271	1.0402	1.0322	.8962
10	1.2239	1.2266	1.1873	1.1271	1.1603	1.0402	.8025
11	1.2266	1.166	1.2574	.9555	1.0978	1.1822	.7099
12	1.2597	1.2266	1.0277	1.085		1.2452	.7202
13	1.1717	.3479	1.0814	1.0883		1.2289	
14	1.2266	1.2071	1.0442	1.1174			.5624
15	1.1437	1.1437	.6249	1.1174		.2591	.4475
16	1.1437	1.1934	1.2431	1.166		1.1523	.5851
17	1.2757	1.1934	1.1797		1.1797	1.0242	.5468
18	1.2226	1.1012	1.0467	1.1871	1.0364	1.1043	.5197
19	1.286	1.2239	1.1768	1.1616	1.1633	1.1105	.6588
20	1.3565	1.3904	1.2887	1.2757	1.2971	1.1904	.7011
21	1.3696	1.3056	1.2717	1.2445	1.2378	1.1768	.7186
22	1.3289	1.2378	1.2239	1.2136	1.2346	1.1469	.6762
23	1.262	1.1736	1.3306	1.1919	1.2986	1.065	.5959
24	.7362	1.2403	1.153	1.2378	1.1065	1.2136	1.0852
Max	1.3696	1.3904	1.3306	1.2757	1.2986	1.3112	1.1218
Min	.6344	.3479	.6249	.9555	1.0364	.2591	.4475
Avg	1.0301	1.1565	1.1419	1.1606	1.1380	1.1285	.8047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 201 / 11 KV Krushi Nagar Feeder

SHEDDABLE URBAN

(Na Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4129	.4481	.4845	.415	.3753	.5217	.3772
2	.4129	.4294	.4658	.3961	.3734	.4849	.3772
3	.3921	.4108	.4481	.3961	.3753	.4668	.3772
4	.3953	.3925	.4108	.3961	.3734	.4481	.3772
5	.4294	.3925	.4481	.3772	.3753	.4294	.3961
6	.4294	.4108	.4108	.3961	.3734	.4294	.3772
7	.3734	.3558	.3374	.415	.3003	.3378	.3584
8	.3361	.319	.3374	.3018	.3361	.3746	.3206
9	.3734	.3746	.3395	.3018	.3361	.3734	.3395
10	.4706	.415	.4715	.3584	.3547	.4108	.3206
11	.5041	.4338	.3961	.4294	.4527	.5041	.4338
12	.5228	.5281	.5041	.5573	.3584	.4854	.4527
13	.5415	.5201	.5975	.4251	.4715	.5647	.2829
14	.4854	.5561	.5082	.4481	.4904	.4668	.5281
15	.5041	.5021	.4294	.4481	.5093	.1307	.4527
16	.4854	.4658	.4527	.4294	.4904	.5228	.3772
17	.5207	.4108	.415	.4108	.547	.4668	.4527
18	.5914	.4294	.3584	.3547	.5658	.4715	.4481
19	.688	.4845	.4338	.3734	.6036	.5281	.2824
20	.4658	.4658	.4904	.4108		.4527	.3558
21	.4294	.5207	.4904	.4294	.4108	.4527	.3742
22	.4845	.5381	.4458	.3941	.5561	.4527	.3558
23	.4668	.4653	.4338	.3734	.6105	.3961	.2824
24	.4108	.4658	.4845	.415	.3753	.5741	.3772
Max	.688	.5561	.5975	.5573	.6105	.5741	.5281
Min	.3361	.319	.3374	.3018	.3003	.1307	.2824
Avg	.4636	.4473	.4414	.4022	.4354	.4478	.3782

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 202 / 11 KV Nawegaon Pandav

SHEDDABLE RURAL

feeder Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3003	.3378	.2427	.1886	.2252	.189	.3206
2	.2987	.3378	.2241	.1886	.2263	.1701	.3206
3	.2987	.3193	.2054	.1698	.2263	.1701	.3018
4	.3003	.3009	.1867	.1509	.2252	.1515	.3018
5	.3003	.3197	.2241	.1509	.2252	.1515	.3018
6	.244	.2635	.1867	.1509	.1867	.1703	.2641
7	.2627	.2614	.1867	.1509	.168	.1515	.2263
8	.2614	.2614	.2241	.1509	.1494	.1703	.2641
9	.2614	.2241	.2241	.1509	.1307	.168	.2263
10	.2427		.2241	.1509	.1501	.1494	.2263
11	.2263	.0563	.1867	.1515	.1132	.1494	.1886
12	.2826	.4294	.1867	.1701	.1132	.168	.1886
13	.3012	.2241	.2054	.1513	.132	.1867	.1886
14	.2452	.2054	.2054	.1513	.1509	.168	.2075
15	.2263	.1867	.1867	.1513	.132	.1494	.1886
16	.2824	.2054	.1886	.1513	.1509	.1494	.1886
17	.2824	.1886	.1886	.1703	.1509	.1307	.2075
18	.3012	.2054	.1698	.168	.1698	.2829	.2077
19	.3012	.2241	.2075	.2054	.2075	.3018	.2452
20	.3746	.2614	.2641	.2427	.1703	.3395	.2452
21	.3749	.2801	.2641	.2427	.2452	.3395	.2824
22	.3746	.2614	.2641	.244	.2263	.3395	.2635
23	.3374	.2427	.2452	.2241	.2077	.3206	.2452
24	.2987	.3374	.2427	.1886	.2245	.2079	.3206
Max	.3749	.4294	.2641	.244	.2452	.3395	.3206
Min	.2263	.0563	.1698	.1509	.1132	.1307	.1886
Avg	.2908	.2580	.2139	.1757	.1795	.2031	.2467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 203 / 11 Kv Kanpa Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8111	1.5775	1.8858	1.7353	1.6632	1.8176	1.749
2	1.7701	1.6301	1.8671	1.6032	1.6804	1.749	1.6552
3	1.7002	1.56	1.8111	1.5089	1.587	1.7147	1.5424
4	1.6632	1.6265	1.7364	1.358	1.4937	1.6991	1.4022
5	1.6078	1.6387	1.6804	1.3957		1.668	1.2757
6	1.6078	1.5249	1.2883	1.1128	1.2197	1.668	1.3112
7	1.2012	1.2071	1.307	1.1506	1.6617	1.2152	1.5621
8	1.2696	1.2637	1.3443	1.1694	1.1576	1.247	1.1151
9	1.7741	1.2826	1.363	1.2449	1.7924	1.7299	.8733
10	1.8296	1.3014	1.4937	1.2229	1.8298	1.6038	.7331
11	1.5592		1.7924	1.2483	1.6221	1.8519	.6626
12	1.6651	1.2346	1.7364	1.2798	1.9239	1.4175	.6626
13	1.7002	1.3375	1.4003	1.1331		1.8176	.4481
14	1.247	1.5278	1.2323	1.1641	.9619	1.8176	.4481
15	1.2483	1.8107	1.2936	1.182	.9997	1.251	.4854
16	1.7353	1.8673	1.358	1.2178	.7545	1.3466	.4527
17	1.6854	1.226	1.3769	1.2357	1.6827	1.251	.5281
18	1.5919	1.2174	1.3392	1.251	1.8004	1.2798	.5281
19	1.2648	1.4146	1.9427	1.2883	1.749	1.247	.5255
20	1.3791	1.4712	1.3957	1.3443	1.5061	1.2798	.6005
21	1.3112	1.5089	1.3957	1.307	1.4175	1.3909	1.1635
22		1.9239	.9054	1.5893	.9774	1.749	.8299
23	1.3004	1.9427	1.4523	1.4563	.9955	1.7833	.9335
24	1.7926	1.3791	1.9044	1.8861	1.5708	.9774	1.7833
Max	1.8296	1.9427	1.9427	1.8861	1.9239	1.8519	1.7833
Min	1.2012	1.2071	.9054	1.1128	.7545	.9774	.4481
Avg	1.5528	1.4989	1.5126	1.3369	1.4567	1.5239	.9696

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 204 / 11 KV Telephone Exchange

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.7339	.7842	.7545	.7095	.6348	.679
2	.6944	.7346	.7468	.6979	.7131	.6161	.679
3	.6722	.717	.7095	.6979	.6908	.5975	.6413
4	.6535	.6994	.6535	.6602	.6722	.5975	.5658
5	.6468	.6803	.6908	.6224	.6756	.5788	.6036
6	.6205	.6461	.6348	.5281	.6161	.5788	.6036
7	.5228	.5281	.5415	.4904	.5415	.4316	.5093
8	.5041	.547	.5271	.4338	.4668	.4879	.5658
9	.5041	.5281	.4481	.4904	.4481	.4481	.4527
10	.4294	.547	.4481	.4338	.4854	.4668	.4527
11	.4481	.5281	.4481	.4481	.4715	.4668	.4338
12	.5741	.6036	.5975	.4849	.4338	.4854	.4527
13	.5561	.5847	.5975	.4658	.4715	.5041	.0754
14	.5747	.5847	.5788	.5031	.5093	.4706	.2641
15	.5741	.5658	.5788	.4845	.4904	.5228	.4338
16	.4845	.5847	.6036	.4481	.3206	.5041	.4338
17	.5201	.4904	.5658	.4668	.547	.4668	.4338
18	.5944	.5281	.5093	.5041	.547	.5093	.5212
19	.6824	.679	.679	.5975	.679	.6413	.5926
20	.823	.8299	.7922	.6908	.7546	.6979	.6653
21	.7682	.8299	.7922	.7282	.7178	.7167	.5729
22	.7881	.8299	.8488	.7468	.6979	.679	.6468
23	.8048	.8299	.7545	.7468	.6842	.679	.5207
24	.7282	.8048	.7842	.7922	.7095	.6535	.679
Max	.823	.8299	.8488	.7922	.7546	.7167	.679
Min	.4294	.4904	.4481	.4338	.3206	.4316	.0754
Avg	.6191	.6515	.6381	.5799	.5856	.5598	.5199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 205 / 11 KV Ghodazari feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.2178	1.1128	1.1694	1.126	.9774	1.1317
2	1.2012	1.1641	1.094	1.1317	1.1203	.9774	1.094
3	1.1949	1.1283	1.0751	1.1317	1.0829	.9593	1.094
4	1.1925	1.1174	1.0562	1.094	1.0829	.9955	1.0751
5	1.1949	1.0994	1.0374	1.0374	1.0719	.9441	1.0751
6	1.2883	1.1343	1.0185	1.0562	1.0269	.9097	1.0562
7	1.1576	1.0269	1.1694	.9808	1.0829	1.0136	1.0751
8	1.2136	1.3443	1.1506	1.0751	1.2323	1.1307	1.1506
9	1.2883	1.3443	1.3203	1.1128	1.0829	1.2136	1.1317
10	1.3443	1.2883	1.3392	1.1506	1.1576	1.2136	1.0751
11	1.182	1.1576	1.358	.5026	1.1506	1.1576	1.0374
12	1.2331	1.0829	1.2323	.4658	1.3014	1.2323	.8676
13	1.0136	1.2323	1.1763	.9955	1.226	1.1016	.7733
14	1.0791	1.2136	1.1763	1.2178	1.1883	1.1949	.6173
15	1.1139	1.1016	1.1389	1.1641	1.226	.9709	.6979
16	1.2152	1.1389	1.2071	1.0959	1.1506	1.0269	.811
17	1.2291	.9896	1.2826	1.2331	1.226	1.0456	.7545
18	1.1938	1.0456	1.0751	1.1203	1.1317	.9242	.7865
19	1.1307	1.0269	1.1883	1.0456	1.0273	1.0374	.8048
20	1.2648	1.1949	1.358	1.0642	1.1307	1.0751	.8761
21	1.2178	1.1949	1.2174	1.1576	1.1343	1.094	.8733
22	1.2152	1.1763	1.226	1.1016	1.0971	1.1317	.8578
23	1.2648	1.1203	1.1883	1.1389	1.06	1.1317	.8213
24	1.2136	1.2456	1.1016	1.1694	1.1203	1.0317	1.1317
Max	1.3443	1.3443	1.358	1.2331	1.3014	1.2323	1.1506
Min	1.0136	.9896	1.0185	.4658	1.0269	.9097	.6173
Avg	1.2018	1.1578	1.1792	1.0588	1.1349	1.0621	.9445

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 206 / 11 KV Mindala Feeder(
Talodhi Feeder KV- 11 /
OUTGOING

SHEDDABLE RURAL

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.319	.4294	.7095	.6413	.4677	.5387	.3395
2	.319	.3746	.6908	.6602	.5228	.5561	.3772
3	.319	.3558	.6722	.6602	.563	.5914	.3772
4	.2987	.3374	.6535	.6036	.6161	.6099	.415
5	.2987	.2824	.5975	.6602	.6161	.5741	.4527
6	.2801	.2824	.5601	.679	.6193	.6468	.415
7	.2614	.2801	.6908	.679	.5415	.6099	.3395
8	.2801	.2987	.4854	.679	.5415	.6468	.2829
9	.2614	.2427	.4294	.6413	.5601	.6535	.2452
10	.2824	.2614	.5041	.7356	.5041	.6348	.2263
11	.2638	.3921	.4481	.7148	.547	.6535	.2452
12	.2824	.4294	.4854	.5926	.5847	.4481	.2452
13	.2452	.4481	.5228	.5747	.5281	.4668	.2263
14	.2824	.4854	.5041	.5914	.4904	.4854	.2075
15	.3009	.4294	.5228	.5567	.4715	.168	.4338
16	.2452	.4481		.5392	.7167		.415
17	.2824	.4668		.6099	.7167		.3395
18	.3012	.4854	.4904	.5415	.6602	.2641	.2638
19	.3012	.5228	.5093	.4879	.6036	.2829	.189
20	.2824	.5975	.5847	.5228	.5392	.3018	.2079
21	.3009	.7655	.5658	.4481	.5561	.3018	.2077
22	.2824	.7655	.5281	.4481	.5392	.2829	.2075
23	.4668	.7282	.5093	.4316	.5381	.2829	.2263
24	.3174	.4481	.7282	.5847	.4316	.5207	.2829
Max	.4668	.7655	.7282	.7356	.7167	.6535	.4527
Min	.2452	.2427	.4294	.4316	.4316	.168	.189
Avg	.2948	.4399	.5633	.5951	.5615	.4782	.2987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

NAGBHID S/DN.[336]

BU 4336

Substation No/ Name :- 104014 / 33 KV NAGBHID S/STN

Feeder No / Name : 207 / S-E RAILWAY EXPRESS FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075	.0095	.0095	.0075	.0076	.0076	.0057
2	.0056	.0095	.0095	.0075	.0057	.0076	.0057
3	.0057	.0095	.0095	.0075	.0057	.0076	.0057
4	.0056	.0095	.0095	.0057	.0057	.0057	.0057
5	.0075	.0095	.0076	.0057	.0075	.0057	.0057
6	.0075	.0095	.0076	.0075	.0075	.0057	.0057
7	.0075	.0095	.0076	.0075	.0075	.0057	.0057
8	.0056	.0095	.0076	.0057	.0056	.0057	.0057
9	.0056	.0095	.0057	.0057	.0056	.0056	.0057
10	.0056	.0094	.0051	.0057	.0056	.0056	.0057
11	.0056	.0075	.0075	.0076	.0075	.0075	.0075
12	.0056	.0075	.0075	.0076	.0075	.0056	.0075
13	.0056	.0094	.0056	.0076	.0075	.0056	.0057
14	.0075	.0075	.0056	.0095	.0075	.0056	.0057
15	.0075	.0075	.0075	.0095	.0075	.0056	.0057
16	.0056	.0075	.0075	.0095	.0075	.0056	.0057
17	.0076	.0075	.0075	.0095	.0075	.0056	.0057
18	.0095	.0095	.0075	.0056	.0094	.0057	.0057
19	.0095	.0114	.0075	.0056	.0075	.0057	.0076
20	.0095	.0114	.0094	.0075	.0095	.0075	.0076
21	.0095	.0114	.0094	.0093	.0095	.0075	.0076
22	.0095	.0114	.0094	.0094	.0076	.0075	.0076
23	.0095	.0095	.0075	.0075	.0076	.0075	.0076
24	.0056	.0095	.0095	.0075	.0075	.0076	.0075
Max	.0095	.0114	.0095	.0095	.0095	.0076	.0076
Min	.0056	.0075	.0051	.0056	.0056	.0056	.0057
Avg	.0071	.0093	.0078	.0075	.0073	.0064	.0063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084009 / 33/11KV NAWARGAON S/STN.

Feeder No / Name : 201 / 11 KV Nawargaon Town SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.6401	.5973	.6283	.543	.5611	.4755
2	.4938	.6219	.567	.5914	.543	.5487	.4706
3	.499	.6219	.5853	.6036	.543	.5138	.4525
4	.4755	.5973	.567	.5853	.5014	.5121	.4572
5	.4805	.5731	.5611	.5487	.4075	.4961	.462
6	.4207	.4656	.4382	.4477	.443	.4298	.394
7	.3841	.4075	.394	.3761	.3856	.394	.3544
8	.3801	.3506	.3982	.3366	.3506	.3121	.3403
9	.3801	.3898	.0398	.3721	.3544	.3544	.3189
10	.4252	.4706	.4477	.3544	.3801	.3544	.3544
11	.4784	.4344	.4075	.3681	.3506	.3544	.3681
12	.4382	.4344	.4344	.4252	.362	.4382	.3155
13	.4607	.4607	.4557	.4557	.394	.3721	.3506
14	.4607	.4706	.4887	.3772	.3898	.3582	.3155
15	.4252	.4252	.4607	.4075	.394	.3506	.298
16	.4252	.3681	.4656	.4075	.4075	.3544	.3222
17	.4075	.4119	.3761	.3721	.3898	.394	.3506
18	.3898	.3898	.443	.4607	.4163	.394	.3506
19	.4961	.4961	.5611	.4784	.5201	.443	.4784
20	.6584	.6268	.6697	.6036	.6219	.543	.5493
21	.695	.6697	.695	.6335	.6154	.5487	.5138
22	.6584	.6516	.695	.6036	.5973	.5487	.4557
23	.6584	.6268	.6401	.5853	.567	.5121	.4607
24	.567	.6401	.6154	.6401	.543	.5611	.4755
Max	.695	.6697	.695	.6401	.6219	.5611	.5493
Min	.3801	.3506	.0398	.3366	.3506	.3121	.298
Avg	.4865	.5102	.5002	.4859	.4592	.4437	.4035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084009 / 33/11KV NAWARGAON S/STN.

Feeder No / Name : 202 / 11 KV KV ALESUR

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7122	.852	.7164	.7045	.7125	.6773	.8048
2	.6874	.8356	.7274	.7209	.7125	.6539	.7545
3	.6952	.8356	.7011	.7042	.6964	.6602	.7956
4	.6952	.8192	.7449	.6962	.6964	.6706	.7377
5	.663	.8192	.7186	.6962	.6964	.6539	.7209
6	.6443	.7611	.6958	.6081	.6964	.5868	.6722
7	.6299	.7287	.679	.5921	.6964	.5721	.6722
8	.663	.7449	.679	.5556	.6964	.639	.7362
9	.6718	.7611	.7274	.6325	.6802	.6874	.6958
10	.664	.6859	.7522	.6964	.6874	.7682	.7125
11	.6478	.7011	.6802	.6802	.6706	.7748	.6964
12	.664	.6327	.6802	.6316	.6718	.6802	.2591
13	.6964	.6562	.6642	.6478	.6554	.6882	.2439
14	.7449	.6882	.7125	.7373	.571	.7773	
15	.7125	.6636	.6167	.7125	.679	.6483	.3593
16	.7287	.6554	.6562	.7449	.7042	.7274	.3593
17	.7611	.7499	.6562	.7287	.6481	.7449	.5312
18	.7611	.7099	.6722	.7773	.6472	.7287	.5441
19	.7701	.759	.6964	.6964	.6539	.7935	.6316
20	.8745	.7407	.8192	.7611	.6836	.8097	.664
21	.8745	.7716	.7865	.7287	.6748	.7956	.6882
22	.8583	.7865	.779	.7125	.6602	.6962	.664
23	.8684	.7865	.7293	.7125	.7011	.7545	.664
24	.7042	.852	.7343	.7127	.7125	.6859	.7373
Max	.8745	.852	.8192	.7773	.7125	.8097	.8048
Min	.6299	.6327	.6167	.5556	.571	.5721	.2439
Avg	.7247	.7499	.7094	.6913	.6794	.7031	.6237

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084009 / 33/11KV NAWARGAON S/STN.

Feeder No / Name : 203 / ANTARGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.7404	1.5893	1.6598	1.7238	1.6549	1.543
2	1.4922	1.7404	1.5729	1.6956	1.6712	1.6575	1.5261
3	1.4419	1.6907	1.5746	1.6766	1.6712	1.6385	1.4918
4	1.4255	1.6575	1.5238	1.6787	1.6385	1.6032	1.4922
5	1.3748	1.6078	1.4723	1.6956	1.6057	1.6221	1.4754
6	1.1934	1.5249	1.2809	1.5912	1.5238	1.5729	1.3763
7	1.3413	1.5546	1.3927	1.6575	1.5581	1.5565	1.3592
8	1.4074	1.6907	1.5623	1.5729	1.6385	1.6518	1.4419
9	1.5927	1.8067	1.6956	1.7532	1.4582	1.6712	1.4746
10	1.2125	1.7814	1.7238	1.7404	1.5402	1.6549	1.5074
11	1.1633	1.7695	1.4419	1.7901	1.5708	1.576	1.3272
12	1.3435	1.3927	1.6907	1.704	1.5565	1.6078	1.3435
13	1.5249	1.4746	1.8351	1.6385	1.5074	1.6095	1.278
14	1.4918	1.5565	1.7404	1.4091	1.5912	1.6766	1.278
15	1.5581	1.749	1.7101	1.5074	1.6575	1.6549	1.3108
16	1.5581	1.5729	1.6766	1.6221	1.6549	1.6244	1.3272
17	1.5729	1.6385	1.6448	1.6057	1.6057	1.5912	1.3272
18	1.5729	1.6324	1.6766	1.6385	1.5912	1.5565	1.1797
19	1.7695	1.7532	1.873	1.704	1.7465	1.5592	1.247
20	1.869	1.8515	1.9334	1.7695	1.7269	1.6575	1.3441
21	1.749	1.8313	1.7269	1.7901	1.7465	1.643	1.3435
22	1.869	1.6385	1.7436	1.7736	1.7072	1.5912	1.2955
23	1.7901	1.6575	1.6263	1.757	1.6712	1.5424	1.2944
24	1.7465	1.7736	1.6057	1.6632	1.7404	1.6907	1.5257
Max	1.869	1.8515	1.9334	1.7901	1.7465	1.6907	1.543
Min	1.1633	1.3927	1.2809	1.4091	1.4582	1.5424	1.1797
Avg	1.5195	1.6703	1.6381	1.6706	1.6293	1.6194	1.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084009 / 33/11KV NAWARGAON S/STN.

Feeder No / Name : 205 / 11 kV Nachanbhatti

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9496	1.1271	.9878	1.1401	1.0978	1.0111	.9724
2	.9221	1.1105	.9831	1.1271	1.0978	.9878	.9835
3	.8951	1.1105	.9339	1.1361	1.0814	1.0111	.9892
4	.8951	1.094	.8192	1.1105	1.0814	.9717	.9779
5	.8718	1.0774	.7865	1.1065	1.065	.9945	1.0059
6	.8478	1.0442	.7537	1.073	1.0486	.9393	.9779
7	.9282	.7865	.8535	1.0159	1.0159	.7125	.9831
8	1.0608	.8619	1.2266	1.1105	1.1142	1.0322	.9779
9	1.1736	.9614	1.3226	1.2071	1.1469	.9717	1.0322
10	1.1233	1.0322	1.1768	1.1271	1.1797	1.1271	1.0159
11	1.2071	1.1797	1.1142	1.1142	1.1961	1.1469	.9555
12	1.2071	1.1797	1.2071	1.1934	1.2289	1.1437	.9503
13	1.2431	1.1305	1.1961	1.1142	1.2308	1.1271	.9339
14	1.2431	1.1797	1.1603	1.0814	1.2631	1.073	.8848
15	1.2125	1.2483	1.1065	1.0814	1.3094	1.0608	.8421
16	1.1142	1.278	1.0608	1.1142	1.1469	1.094	.9069
17	1.0978	1.0688	1.0814	1.0978	1.1603	1.0322	.9069
18	1.1065	1.2452	1.0608	1.1469	1.073	.9779	.7611
19	1.1401	1.2308	1.2239	1.0814	1.2763	1.0111	.8259
20	1.1736	1.2452	1.1797	1.1469	1.2266	1.073	.8583
21	.852	1.2125	1.1603	1.1336	1.1174	1.0608	.8684
22	1.1469	1.2452	1.0814	1.1469	.9831	.9779	.8421
23	1.1603	1.1498	1.1437	1.1142	.9717	.9724	.8421
24	.9835	1.1271	1.1142	1.1568	1.1142	.9995	.9724
Max	1.2431	1.278	1.3226	1.2071	1.3094	1.1469	1.0322
Min	.8478	.7865	.7537	1.0159	.9717	.7125	.7611
Avg	1.0648	1.1219	1.0723	1.1199	1.1344	1.0212	.9278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084037 / 33/11 KV Pathari

Feeder No / Name : 201 / Pathari town

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.4399	.4075	.4024	.3996	.3976	.3589
2	.4294	.4382	.4004	.4024	.3936	.3946	.3571
3	.4251	.4265	.3951	.4024	.3936	.3886	.3537
4	.4294	.4242	.3898	.3881	.3953	.3827	.3485
5	.3982	.4207	.3863	.3881	.3936	.3725	.3381
6	.3734	.4022	.3774	.3475	.3476	.2977	.3051
7	.4572	.378	.4075	.3658	.345	.3101	.333
8	.5175	.4103	.4146	.3547	.3485	.3515	.3502
9	.5068	.449	.4298	.3921	.3884	.3641	.4074
10	.4835	.4161	.4435	.4207	.4126	.3676	.3866
11	.4575	.4294	.3292	.3856	.3597	.3137	.3953
12	.4803	.4382	.4024	.3295	.3366	.3936	.3475
13	.4768	.4235	.4066	.3728	.365	.3866	.2686
14	.4785	.4407	.4207	.2809	.3349	.3814	.3292
15	.4594	.4218	.4024	.2982	.3313	.3606	.3326
16	.4525	.3618	.439	.3433	.3189	.3595	.3475
17	.4334	.3807	.4207	.3658	.3819	.3241	.394
18	.4084	.3774	.4294	.3526	.3225	.3415	.3982
19	.4595	.4224	.439	.3884	.4172	.3917	.4119
20	.468	.4252	.5121	.4627	.4713	.4012	.4755
21	.4592	.4252	.4755	.4334	.4571	.3807	.4706
22	.454	.4252	.4481	.4109	.4359	.3693	.4572
23	.4172	.4199	.4251	.4031	.4209	.337	.4207
24	.4435	.4005	.4146	.4066	.3953	.4004	.3391
Max	.5175	.449	.5121	.4627	.4713	.4012	.4755
Min	.3734	.3618	.3292	.2809	.3189	.2977	.2686
Avg	.4497	.4165	.4174	.3791	.3819	.3653	.3719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084037 / 33/11 KV Pathari

Feeder No / Name : 202 / Gunjewahi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.293	.3296	.3511	.3086	.3276	.3259
2	.3292	.3086	.3278	.3361	.3051	.3172	.3278
3	.3326	.3069	.326	.3361	.3001	.3188	.3225
4	.3361	.3001	.3101	.3326	.2895	.3152	.3207
5	.3174	.3069	.2941	.3174	.267	.3098	.3207
6	.2614	.2618	.2463	.2801	.2115	.2418	.2653
7	.2614	.2618	.2463	.2534	.2063	.1988	.2185
8	.3142	.2549	.303	.2218	.2098	.2246	.2358
9	.2686	.2774	.3292	.2427	.2229	.2497	.1976
10	.2896	.3032	.3292	.2801	.2393	.3207	.2289
11	.2531	.3012	.2378	.2635	.2427	.2306	.2462
12	.2401	.3632	.3475	.312	.2622	.2966	.2896
13	.2757	.3069	.3142	.2653	.2339	.2739	.181
14	.2635	.2984	.2926	.2717	.2498	.2913	.2149
15	.3259	.3378	.2896	.2705	.2551	.293	.2353
16	.2829	.3035	.2926	.2618	.3242	.2982	.2743
17	.2982	.3361	.3326	.2314	.2817	.2966	.2507
18	.3086	.2782	.2587	.2514	.2233	.2843	.2561
19	.3015	.34	.3475	.2739	.3437	.3745	.3224
20	.3698	.3827	.4251	.3797	.3703	.3728	.3841
21	.3453	.3792	.4066	.3676	.3668	.3578	.3841
22	.0421	.3508	.3734	.3415	.3437	.3519	.3658
23	.1087	.3473	.3658	.3294	.3403	.3311	.3439
24	.3511	.2962	.342	.3475	.3138	.3242	.3277
Max	.3698	.3827	.4251	.3797	.3703	.3745	.3841
Min	.0421	.2549	.2378	.2218	.2063	.1988	.181
Avg	.2839	.3123	.3195	.2966	.2797	.3000	.2850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 084037 / 33/11 KV Pathari

Feeder No / Name : 402 / 33 kV Pathari Incomer NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.773	.7602	.7522	.7427	.7439	.6867
2	.7842	.773	.7493	.7522	.7542	.7462	.7022
3	.7762	.7594	.7385	.7682	.7572	.7199	.7022
4	.7682	.7459	.7222	.7059	.7414	.7059	.674
5	.7282	.7572	.7059	.6984	.7257	.6842	.6893
6	.6653	.7099	.6679	.6516	.6397	.6136	.6189
7	.7207	.652	.6733	.6584	.5825	.5373	.5929
8	.8402	.6866	.6842	.6036	.6224	.6205	.6276
9	.7282	.749	.7682	.6653	.6206	.6501	.6345
10	.8059	.775	.8316	.7059	.6658	.6866	.6554
11	.7204	.809	.5487	.6554	.6353	.5409	.6345
12	.7151	.8633	.7682	.6762	.657	.697	.6516
13	.7325	.751	.7682	.6783	.6299	.6762	.439
14	.7802	.751	.7602	.5513	.6136	.7282	.6036
15	.7993	.7665	.7133	.5929	.619	.6941	.5973
16	.7438	.679	.7842	.6698	.6679	.679	.6516
17	.7274	.7305	.7682	.6085	.7113	.6501	.7059
18	.7126	.7113	.6722	.6241	.6081	.6345	.7133
19	.763	.7873	.823	.7178	.8285	.827	.7682
20	.8939	.8905	.9774	.915	.9394	.8436	.9231
21	.8571	.8851	.9328	.8591	.9176	.787	.9134
22	.5316	.8525	.8779	.8062	.8633	.775	.8779
23	.5679	.8145	.8402	.7768	.8121	.7071	.8059
24	.8402	.7782	.7819	.7888	.7698	.7602	.7074
Max	.8939	.8905	.9774	.915	.9394	.8436	.9231
Min	.5316	.652	.5487	.5513	.5825	.5373	.439
Avg	.7518	.7688	.7632	.7034	.7135	.6962	.6907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 201 / SINDEWAHI TOWN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4175	1.4217	1.5384	1.5565	1.2757	1.3394	1.3032
2	1.3466	1.4685	1.5023	1.5203	1.3112	1.3032	1.3032
3	1.3466	1.4506	1.4842	1.448	1.2048	1.2308	1.267
4	1.3466	1.4327	1.4327	1.3969	1.1871	1.182	1.2536
5	1.2403	1.3611	1.3969	1.3432	1.1694	.8954	1.1999
6	1.1517	1.2894	1.3466	1.2536	1.134	1.0924	1.1462
7	1.0867	1.1919	1.262	1.1163	.7973	.9745	1.0631
8	1.1393	1.2483	1.283	1.1096	.9882	1.0341	1.0808
9	1.0562	1.2269	1.262	1.0923	1.0576	1.0692	1.1218
10	1.1919	1.3321	1.2795	1.1218	1.1269	1.1393	1.0692
11	1.1963	1.4043	1.3496	1.1096	1.0749	.9816	1.1218
12	1.2656	1.4198	1.3672	1.1871	1.1789	1.1568	1.1517
13	1.3146	1.4723	1.2971	1.1488	1.2094	1.1919	1.2048
14	1.3321	1.4373	1.2795	1.1443	1.262	1.1568	1.1568
15	1.262	1.4198	1.262	1.0576	1.2269	1.1789	1.0402
16	1.2269	1.4022	1.3496	1.1269	1.2136	1.0923	1.0402
17	1.2309	1.2136	.1283	1.1269	1.1963	1.1269	.9922
18	1.2346	1.1789	1.2136	1.0288	1.0402	1.0867	.964
19	1.5061	1.4506	1.4352	1.262	1.3611	1.2894	1.1919
20	1.6289	1.6278	1.701	1.39	1.5546	1.4449	1.3146
21	1.6832	1.7924	1.3169	1.3523	1.5364	1.4632	1.3352
22	1.647	1.8473	1.2127	1.3847	1.5023	1.4118	1.2986
23	1.6655	1.5947	1.6651	1.379	1.4118	1.3535	1.2127
24	1.4842		1.6289	1.6108	1.3112	1.3756	1.3032
Max	1.6832	1.8473	1.701	1.6108	1.5546	1.4632	1.3352
Min	1.0562	1.1789	.1283	1.0288	.7973	.8954	.964
Avg	1.3334	1.4211	1.3331	1.2611	1.2222	1.1904	1.1723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 202 / SIVANI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0229	1.3592	1.1694	1.0277	1.0117	.9391	1.0517
2	1.0229	1.326	1.1218	.9922	1.0631	.9214	1.0517
3	.9709	1.326	1.1218	.9568	1.0802	.9214	1.0517
4	.9709	1.2597	1.0867	.9114	.9945	.8764	1.0517
5	.9189	1.2266	1.0402	.8413	.9774	.8764	.9816
6	.7975	1.0608	1.0056	.7362	.9602	.8413	.8063
7	.9391	1.0631	.9496	.8745	.9945	.8745	.8764
8	1.0425	1.2136	1.1317	.9835	1.0749	1.0174	.7202
9	1.1568	1.1789	1.2094	1.1317	1.0692	1.0749	.929
10	1.2795	1.3146	1.2094	1.166	1.0341	1.1096	.9465
11	1.1963	1.2483	1.1919	1.1317	.9602	1.1022	.9465
12	1.2094	1.2136	1.166	1.0974	1.0749	1.0852	
13	1.1641	.8149	1.0117	1.0402	1.0749	1.0802	.7545
14	1.1568	1.2269	.9665	1.0852	1.0631	1.046	.823
15	1.1393	1.1789	.9496	1.0174	1.0576	1.0343	.8478
16	1.0576	1.2003	1.0174	.8817	.9835	1.0513	.8551
17	1.0576	.8139	.8987	.9389	.9835	1.0174	.8987
18	1.0631	1.0631	1.0117	.9665	.9774		.8573
19	1.3466	1.182	1.0454	1.1462	1.0985	1.0277	.9259
20	1.5043	1.4506	1.2226	1.2536	1.182	1.182	1.0288
21	1.448	1.4148	1.2894	1.2715	1.0498	1.182	1.0566
22	1.379	1.2795	1.1999	1.2178	1.0387	1.1163	1.0099
23	1.2934	1.2048	1.0631	1.1462	.9568	1.0631	.9465
24	1.0566	1.258	1.1871	1.0631	1.0802	.9568	1.0517
Max	1.5043	1.4506	1.2894	1.2715	1.182	1.182	1.0566
Min	.7975	.8139	.8987	.7362	.9568	.8413	.7202
Avg	1.1331	1.2033	1.0944	1.0366	1.0350	1.0173	.9334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 203 / 11 KV Nawargaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.543	.4805	.4557	.2526	.4572	.5121
2	.5258	.5249	.462	.4656	.2429	.439	.5121
3	.4908	.5249	.462	.4656	.2378	.4344	.5121
4	.4908	.5068	.4251	.4656	.2279	.4163	.4755
5	.4733	.4706	.4066	.4344	.2235	.3982	.4525
6	.4031	.4344	.3696	.4344	.2138	.3801	.4344
7	.3856	.3189	.3224	.3898	.1943	.3582	.3761
8	.3506	.3641	.3506	.3988	.1981	.3681	.3898
9	.333	.3544	.3544	.4115	.1981	.3681	.4075
10	.333	.3721	.3544	.298	.3814	.4075	.3721
11	.3814	.3721	.2481	.4733	.3856	.3856	.3721
12	.3856	.3898	.3721	.3544	.3681	.3898	.333
13	.3544	.0326	.362	.2835	.4031		.3045
14	.3403	.3506	.3801	.3224	.3898	.3403	.3045
15	.3544	.3224	.394	.3189	.2534	.3224	.2835
16	.3366	.3045	.3544	.3366	.2481	.333	.2835
17	.3155	.3155	.3467	.3467	.3681	.3506	.3189
18	.3467	.4207	.3681	.3366	.3721	.3761	.3403
19	.5304	.4435	.4887	.5121	.499	.499	.3761
20	.6468	.4481	.5973	.5914	.5601	.5914	.5373
21	.6468	.6099	.5914	.5729	.5544	.5914	.5544
22	.5304	.5544	.5853	.5359	.5359	.5487	.5359
23	.0519	.5175	.5487	.4268	.4938	.5121	.4755
24	.543		.499	.5121	.2675	.4755	.5121
Max	.6468	.6099	.5973	.5914	.5601	.5914	.5544
Min	.0519	.0326	.2481	.2835	.1943	.3224	.2835
Avg	.4198	.4129	.4218	.4226	.3362	.4236	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 204 / PATHRI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155	.1492	.2058	.2035	.1372	.2058	.1802
2	.2155	.1492	.2058	.2035	.1372	.2058	.1802
3	.1989	.1326	.2058	.2035	.128	.1886	.1802
4	.1989	.1326	.2058	.2035	.2155	.1886	.1638
5	.1989	.1326	.1865	.2012	.1989	.1886	.1638
6	.1823	.1492	.1865	.2012	.1802	.2058	.1677
7	.1823	.1658	.1823	.218	.1989	.1865	.1638
8	.1802	.1658	.2155	.2012	.1174	.2012	.1823
9	.1966	.1823	.2204	.2204	.1372	.2012	.1802
10	.1966	.2012	.2374	.1966	.1989	.218	.1802
11	.2155	.2155	.2713	.1989	.1989	.2012	.1619
12	.213	.2035	.285	.2155	.1696	.1989	.1619
13	.213	.218	.2883	.2321	.2204	.2012	.1781
14	.213	.2155	.2915	.2374	.2204	.1966	.1823
15	.2241	.1492	.2743	.2374	.218	.2374	.1802
16	.208	.1966	.2683	.2543	.218	.2347	.1638
17	.1739	.1619	.285	.1966	.2012	.1781	.1638
18	.1844	.1475	.1943	.1619	.1823	.1619	.144
19	.2012	.2035	.218	.1844	.1886	.1696	.1638
20	.1635	.2427	.2347	.2204	.2279	.2058	.1802
21	.1684	.2254	.2427	.2204	.2254	.2035	.2058
22	.1635	.2254	.2401	.2204	.208	.2012	.1865
23	.1463	.2229	.2229	.2543	.2058	.2012	.1844
24	.2204	.1734	.2058	.2204	.1943	.2058	.1844
Max	.2241	.2427	.2915	.2543	.2279	.2374	.2058
Min	.1463	.1326	.1823	.1619	.1174	.1619	.144
Avg	.1947	.1817	.2323	.2128	.1887	.1995	.1743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 205 / NAWARGAON AG GFSS FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0513	.8122	.9614	.9503	.8048	.9389	
2	1.0513	.8288	.9282	.9339	.8987	.9221	
3	1.0513	.8951	.9282	.9175	.9326	.8951	
4	1.0174	.9116	.9221	.9175	.8951	.8684	
5	1.0174	.9448	.9054	.9116	.8785	.852	
6	.9835	.9448	.9054	.9116	.8785	.8356	
7	1.1361	1.1105	.9724	1.0111	1.0277	1.0059	
8	1.1401	1.1105	1.1022	.9779	1.0608	1.0562	
9	1.1361	1.0562	1.0227	.9614	1.0111	1.0227	
10							.8048
11							1.1022
12							.9665
13							.8951
14							.9054
15							.9496
16							.8718
17							.8192
24	.8215	.779	.7459	.7701	.7377	.788	.6882
Max	1.1401	1.1105	1.1022	1.0111	1.0608	1.0562	1.1022
Min	.8215	.779	.7459	.7701	.7377	.788	.6882
Avg	1.0406	.9394	.9394	.9263	.9126	.9185	.8892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

BRAMHAPURI DIVISION[644]

SINDEWAHI S/DN.[346] BU 4346

Substation No/ Name :- 085007 / 33/11 KV SINDEWAHI S/STN.

Feeder No / Name : 403 / 33 kV Sindewahi Incomer NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3056	4.417	4.265	4.2067	3.8272	3.6717	2.9321
2	4.3056	4.3644	4.161	4.1015	4.0929	3.6214	2.9321
3	4.1461	4.465	4.161	3.9963	3.9335	3.4808	2.8807
4	4.0929	4.3644	3.9609	3.9009	3.8272	3.3813	2.8292
5	3.9335	4.2524	3.858	3.6928	3.6808	3.2819	2.7263
6	3.6145	3.9438	3.7134	3.4465	3.6677	3.1459	2.4691
7	3.8272	3.9866	3.6626	3.6008	3.4551	3.3196	2.4177
8	3.9335	4.2524	4.0638	3.7037	3.774	3.7037	2.3405
9	4.0695		4.0124	3.9335	3.8272	3.8272	2.6006
10	.2932	3.1379	3.035	2.8172	2.6452	2.8921	3.3808
11	2.9321	3.0864	2.9835	2.9767	2.6235	2.7046	3.7334
12	3.1024	3.1893	3.1379	2.9235	2.7778	2.8607	2.6006
13	2.9321	2.7778	2.9321	2.7641	2.8807	2.8921	3.4179
14	2.9321	3.1539	2.8807	2.8395	2.8807	2.7566	3.4551
15	2.9321	3.035	2.8807	2.6818	2.7263	2.8086	3.4019
16		3.0864	2.9504	2.6578	2.6452	2.7566	3.3488
17	2.696	2.4926	2.7664	2.6818	2.696	2.7046	3.2602
18	3.0807	2.7778	2.8395	2.5514	2.572	1.6301	2.2634
19	3.5231	3.2076	3.155	2.9973	3.1024	2.9447	2.6818
20	3.8912	3.7071	3.8958	3.4019	3.4922	3.3488	3.1024
21	3.8386	4.0604	3.8552	3.3653	3.3311	3.3488	3.0498
22	3.7334	3.9095	3.6677	3.3128	3.2773	3.2425	2.9767
23	3.6283	3.638	3.4551	3.2425	3.0298	3.083	2.7869
24	4.1461	4.2067	4.161	3.3128	3.9438	3.6214	3.6928
Max	4.3056	4.465	4.265	4.2067	4.0929	3.8272	3.7334
Min	.2932	2.4926	2.7664	2.5514	2.572	1.6301	2.2634
Avg	3.4735	3.6310	3.5189	3.2962	3.2796	3.1262	2.9700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104003 / 33/11 KV ARMORI SUB/STN

Feeder No / Name : 201 / 11 KV ARMORI URBAN FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6886	2.2634	2.3777	2.0058	1.7924	2.037	1.7558
2	2.6513	2.2032	2.1216	1.97	1.7737	1.9993	1.7372
3	2.6406	2.1658	2.1216	1.8625	1.7551	1.9418	1.7002
4	2.6139	2.1502	1.829	1.7909	1.6975	1.8861	1.6632
5	2.4897	2.0538	1.829	1.7013	1.6975	1.8484	1.6263
6	2.0936	2.0538	1.829	1.5203	1.5278	1.5844	1.5524
7	1.8861	1.6409	1.4266	1.3032	1.358	1.3443	1.4045
8	1.6409	1.2637	1.386	1.2308	1.2826	1.3203	1.4784
9	1.6032	1.1203	1.3535	.4163	1.1317	1.2449	1.4784
10	1.6598	1.39	.6516	.547	1.5089	1.6095	1.6632
11	2.2445	1.4784	1.8625	1.9616	1.8861	1.7741	1.5912
12	2.1879	1.3817	1.9342	1.8107	1.8107	1.8296	1.5339
13	2.1125		2.0774	2.037	1.7353	1.7926	1.39
14	1.9616		1.8625	1.8861	1.5089	1.4998	1.3756
15	2.037		1.8983	1.8107	1.5089	1.4083	1.1765
16	2.037		1.9547		1.5844	1.4998	1.5181
17	2.1125	1.7375	1.9547	1.4335	1.4335	1.4083	1.4632
18	1.4712	1.8656	2.0595	1.5089	1.5203	1.7193	1.3169
19	2.3011	1.9547	2.1849	1.8484	1.828	1.9753	1.6095
20	2.6217	2.1948	2.0953	1.9004	1.9185	1.9936	1.5364
21	2.2218	2.2131	2.1132	1.9547	1.9404	1.9753	1.6827
22	2.3577	2.3777	2.1491	1.8099	2.0883	2.0485	1.7193
23	2.1538	2.3594	2.0595	1.7375	1.9728	1.9022	1.6095
24	2.6063	2.2405	2.3777	2.0774	1.7924	2.0165	1.829
Max	2.6886	2.3777	2.3777	2.0774	2.0883	2.0485	1.829
Min	1.4712	1.1203	.6516	.4163	1.1317	1.2449	1.1765
Avg	2.1831	1.9054	1.8962	1.6576	1.6689	1.7358	1.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104003 / 33/11 KV ARMORI SUB/STN

Feeder No / Name : 202 / 11 KV DEULGOAN FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.7759	1.5043	2.2405	2.6595	2.3891
2			2.7759		2.2634	2.6406	2.3167
3		2.2624	2.6863	2.2923	2.1285	2.6139	2.2443
4		2.2081	2.6863	2.2207	2.0911	2.6029	2.2081
5		2.1719	2.5968	2.0774	2.0748	2.5019	2.1357
6		1.828	2.5968	2.1491	2.0538	2.4143	2.1719
7		1.7556	2.4893	2.2565	2.0182	2.3577	2.4356
8		1.7918	2.7149		2.1879	2.5086	2.5789
9		2.1691	2.733	2.6244	2.0748	2.7349	2.0774
10		2.0513	2.7221	2.8006	2.1879	2.4253	2.3348
11		2.3461	2.5789	2.6139	2.1879	2.5158	2.1765
12		2.392	2.6505	2.6406	1.9616	2.5701	2.0119
13			2.5789	2.6406	2.037	2.5701	1.9521
14			2.4356	2.6406	2.1879	2.6063	1.9163
15				2.7915	2.2634	2.4977	1.6655
16			2.4356	.5281	2.3152	2.4796	1.8446
17		2.4356	2.6147		2.2634	2.4615	1.7909
18		2.6147	2.7692		2.3891	2.4434	1.8823
19		3.0624	2.1132	1.8484	2.7873	2.733	2.2923
20	3.1367	3.4027	3.3848	2.1538	3.1674	3.0407	2.5072
21	3.0862	3.349		2.5339	2.8532	2.9683	2.4356
22	2.8829	3.0266	2.3461	2.3167	2.7618	2.7873	2.3102
23	2.5882	2.9012	2.2565	2.1719	2.552	2.5339	2.1491
24			2.8654	2.2923	2.2405	2.6326	2.4615
Max	3.1367	3.4027	3.3848	2.8006	3.1674	3.0407	2.5789
Min	2.5882	1.7556	2.1132	.5281	1.9616	2.3577	1.6655
Avg	2.9235	2.4570	2.6276	2.2549	2.3037	2.5958	2.1787

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104003 / 33/11 KV ARMORI SUB/STN

Feeder No / Name : 204 / 11 KV JOGISAKHARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8567	1.5565	1.6289	1.2536	.6722	1.1203	1.0608
2	2.8275	1.5565	1.5384	1.2308	.6722	1.1317	1.0242
3	2.809	1.5203	1.5384	1.1462	.6602	1.0456	.9877
4	2.8006	1.5203	1.5384	1.1104	.6535	1.0562	.9145
5	2.7633	1.5203	1.5927	1.1222	.6602	1.0456	.9511
6	2.6139	1.5203	1.6289	1.0387	.6602	1.0185	.9877
7	2.6326	1.5746	1.647	.8954	.7733	1.0185	1.1523
8	2.6595	1.6108	1.829	1.086	.8299	1.0374	1.2071
9	3.2442	1.8484	1.9387	1.2178	.8865	1.1128	1.4632
10	3.2065	1.7558	1.8446	1.2449	.8488	.9694	
11	2.7538	1.701	1.828	.9619	.8299	1.0974	.1463
12	1.8673	.9694	1.4506	1.2071	.6602	1.0608	
13	.6224		1.5939	1.226	.9808	1.1827	.6154
14	2.9613		1.576	1.0562	.9997	1.1523	.6089
15	2.999		.8326	1.0374	1.0374	1.1041	.5611
16	3.3008		.985	.3395	.8299	1.0974	.6697
17	3.3385	1.6651	.8596		.5658	1.1706	.7059
18	.679	1.7909	.9231		.9774	1.0136	.7133
19	1.0751	1.8625	1.1462	.7421	1.1765	1.2308	.7964
20	1.1389	1.9342	1.5939	.7783	1.2489	1.3756	.8688
21	1.4563	1.7909	1.5023	.7964	1.2567	1.3575	.8507
22	1.6991	1.7013	1.4148	.724	1.2012	1.2803	.7964
23	1.6108	1.647	1.379	.6878	1.086	1.1888	.7682
24	2.7692	1.448	1.6289	1.3253	.6722	1.1203	1.0974
Max	3.3385	1.9342	1.9387	1.3253	1.2567	1.3756	1.4632
Min	.6224	.9694	.8326	.3395	.5658	.9694	.1463
Avg	2.3619	1.6247	1.4766	1.0104	.8683	1.1245	.8612

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104003 / 33/11 KV ARMORI SUB/STN

Feeder No / Name : 401 / 33 KV DELANWADI FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.3258	.4481	1.7558	2.1285	2.037	1.6804
2	.7922	.3258	.4481	1.7558	2.1285	2.0165	1.5684
3	.7842	.3258	.3361	1.6289	2.0165	1.9239	1.4563
4	.679	.3258	.3361	1.6632	2.037	1.9239	1.3443
5	.6722	.3258	.3361	1.5524	1.9239	1.7924	1.4563
6	.679	.3258	.3361	1.7558	1.9239	1.7924	1.5684
7	.679	.3258	.3361	1.885	1.9239	1.8107	1.7924
8	.7922	.3258	.3361	1.7741	1.8107	1.9239	2.5766
9	.7922	.3395	.3361	2.0165	1.9239	1.9239	1.0082
10	1.0185	.2241	.3361	1.0185	1.9239	1.7924	.8962
11	.679	.3361	.3361	1.358	1.8107	1.6804	.4481
12	.679	.3361	.3361	1.0185	1.2449	1.6804	1.1203
13	.679		.3361	.1132	1.4712	1.6804	.5544
14	.679			.7922	1.4118	1.7924	1.2197
15	.7922		1.7924	.679	1.3032	1.6804	1.2197
16	.6722		1.9547	1.5844	1.6289	1.6804	1.3306
17	.7922	.3361	.9774	1.358	1.5203	1.6804	1.3306
18	.9054	.3361	1.8267	1.5844	1.8461	1.7924	1.4563
19	.9054	.4481	2.1285	2.4897	2.1719	2.1285	2.0165
20		.5601	2.2405	2.4977	2.3891	2.5503	2.2405
21	.4527	.4481	2.2805	2.3891	2.3285	2.5503	2.1285
22	.4527	.4481	1.9547	2.1719	2.1285	2.2177	1.9044
23	.3258	.4481	1.8461	2.0633	1.9547	2.0165	1.7924
24	.7602	.3258	.4481	1.7375	2.1285	2.037	1.7924
Max	1.0185	.5601	2.2805	2.4977	2.3891	2.5503	2.5766
Min	.3258	.2241	.3361	.1132	1.2449	1.6804	.4481
Avg	.7151	.3596	.9584	1.6101	1.8783	1.9210	1.4959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104003 / 33/11 KV ARMORI SUB/STN

Feeder No / Name : 402 / 33 KV Incomer Gadchiroli NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.4975	4.3439	7.4846	7.0919	7.2428	8.1482	7.6509
2	6.5072	4.3439	7.4846	5.8025	7.1296	8.035	7.3183
3	6.4506	6.6244	7.2074	7.3068	7.1296	7.9218	7.0965
4	6.2734	6.6244	7.2074	7.0919	6.7901	7.5823	6.7638
5	6.1614	6.6244	6.653	6.9845	6.677	7.356	6.9856
6	5.6584	5.647	6.653	6.877	6.3375	7.0165	7.2074
7	5.4321	5.647	6.2094	6.6621	5.8848	6.7901	7.3183
8	5.4321	5.2126	6.4312	3.4385	6.4506	.679	7.9836
9	5.8848	8.1482	6.5844	6.4472	6.1111	7.2428	7.7618
10	11.3169	9.9909	5.8025	5.6584	6.5638	7.0965	5.1006
11	5.6584	10.4253	7.0919	7.4691	7.0165	7.2428	4.6571
12	5.6584	9.2181	6.6621	6.5638	5.6584	7.54	5.1006
13	3.6214		7.0919	7.9218	6.5638	7.54	4.4525
14	5.6584		6.5158	6.5638	5.4298	7.3183	5.487
15	5.8848		4.513	6.5638	3.9095	6.8747	4.8285
16	5.6584		7.5217	4.5268	6.5158	7.0965	5.7065
17	6.5638	6.4312	6.4472	2.9424	6.2986	6.8747	5.487
18	3.8477	7.0233	8.1664	3.3608	6.733	7.0965	5.5441
19	4.3004	7.7618	9.241	7.0165	8.2533	8.4271	6.8039
20	7.0165	8.5597	9.5565	7.6017	9.1221	9.2181	7.4623
21	7.3937	8.2053	6.2323	7.9275	8.8272	9.2181	7.4623
22	7.6178	7.9836	8.1664	7.3846	8.514	8.5597	7.0233
23	6.9502	7.7618	7.9515	6.9502	.7922	7.9836	6.653
24	6.2986	4.3439	7.7618	7.9515	7.2428	8.1482	7.7618
Max	11.3169	10.4253	9.5565	7.9515	9.1221	9.2181	7.9836
Min	3.6214	4.3439	4.513	2.9424	.7922	.679	4.4525
Avg	6.1560	7.0460	7.1099	6.4210	6.5497	7.3753	6.4840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104009 / 33/11 KV DELANWADI

Feeder No / Name : 201 / 11 KV WAIRAGAD FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.4338	.4338	.8215	1.1694	1.0374	1.0082
2	.7655	.4338	.4338	.8029	1.1694	1.0374	.9896
3	.7545	.4338	.415	.8299	1.1694	.9997	.9709
4	.7655	.4338	.415	.8402	1.1694	.9997	.9709
5	.7468	.3772	.3772	.8029	1.1694	.9431	.9522
6	.7468	.3772	.3772	.7655	1.1128	.9242	.9619
7	.7468	.3772	.415	.8589	1.0562	.9619	.9709
8	.8589	.3772	.4338	.8215	1.1694	.9997	1.0829
9	.9431	.3206	.415	.9896	1.1128	.9997	.9896
10	.9997	.3206	.4108	.2987	.9431	.9431	.9149
11	.4904	.3772	.4294	.4904	.9431	.9054	.2801
12	.7167	.415	.3734	.7733	.547	.8589	.547
13	.7167		.4108	.9431	.8299	.9425	.547
14	.7167				.7733	.9149	.6602
15	.8865		.9896		.8299	.8775	.6602
16	.7545		1.0642	1.094	.8676	.9149	.7167
17	.8299	.3772	1.0456	1.1694	.8299	.9896	.7167
18	.9431	.415	1.0269	.7356	.9997	1.0185	.8299
19	.7733	.547	.9896	1.4335	1.2826	1.2136	1.094
20		.6602	1.0082	1.4523	1.2826	1.3256	1.226
21	.547	.6036	1.0082	1.3392	1.226	1.2826	1.1694
22	.4904	.547	.9522	1.226	1.1317	1.1389	1.0562
23	.4338	.4904	.8775	1.1694	1.0562	1.0456	1.0562
24	.8029	.4338	.4527	.8402	1.1694	.9808	1.0269
Max	.9997	.6602	1.0642	1.4523	1.2826	1.3256	1.226
Min	.4338	.3206	.3734	.2987	.547	.8589	.2801
Avg	.7484	.4376	.6415	.9317	1.0421	1.0106	.8916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104009 / 33/11 KV DELANWADI

Feeder No / Name : 401 / 33 KV DELANWADI-KURKHEDA NON SHEDDABLE EXPRESS HV FEEDERS
 LL Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056		.8962	.9619	.9054	1.0082
2	.056		.8962	.9619	.9054	.9522
3	.056		.9522	.9619	.9054	.9522
4	.056		.9522	.9054	.9054	.8962
5	.056		.9425	.9054	.9619	.8962
6	.0554		1.0082	.8488	.9619	.8962
7	.056		1.0082	.9054	.9619	.8962
8	.056		1.0082	.7922	1.0185	.7282
9	.0566		1.0288	.9054	.9619	
10	.0566		1.0082	.9054	1.0185	
11	.0566		.9619	.9054	.9054	.2772
12	.0566		.4527	.8488	.8402	.7356
13	.0566		.7922	.7922	.8402	.7356
14	.0566		.7922	.7922	.8962	.679
15	.0566	.8962	.7356	.7922	.8402	.679
16	.0566	1.0082	.679	.8488	.7842	.7356
17	.0566	.056	.679	.8488	.7282	.7356
18	.0566	.8871	.7922	.9054	.8402	.8488
19	.0566	1.2323	1.1883	1.2449	1.1203	1.0751
20		1.2323	1.1883	1.2449	1.3443	1.1317
21		1.2883	1.1883	1.1883	1.2323	1.0751
22		1.1203	1.0751	1.0751	1.1203	.9619
23		1.0642	.9619	.9619	1.0082	.9619
24	.0988		1.0082	.9619	.9054	.9979
Max	.0988	1.2883	1.1883	1.2449	1.3443	1.1317
Min	.0554	.056	.4527	.7922	.7282	.2772
Avg	.0584	.9761	.9248	.9360	.9547	.8571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

ARMORI S/DN.[339]

BU 4339

Substation No/ Name :- 104009 / 33/11 KV DELANWADI

Feeder No / Name : 402 / 33 KV Incomer Armori

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.4527	.5093	2.0165	2.2068	2.037	2.0725
2	.7282	.4527	.5093	1.9044	2.2068	2.037	2.0725
3	.7282	.4527	.5093	1.7924	2.2068	2.037	2.037
4	.7282	.4527	.5093	1.7924	2.1502	1.9805	2.037
5	.6722	.3961	.4527	1.8484	2.1502	1.9805	1.9605
6	.6722	.3961	.4527	1.9044	2.037	1.9805	1.9605
7	.7282	.3961	.5093	1.9044	2.037	1.9805	2.037
8	.8402	.3961	.5093	1.9605	2.037	2.0936	1.8484
9	1.0185	.3395	.5093	1.9547	2.0936	2.037	1.1763
10	1.0751	.3395	.5041	1.5684	1.9239	2.037	1.0642
11	.5658	.4527	.5041	1.4712	1.9239	1.8673	.6722
12	.7922	.5093	.3961	1.2449	1.4712	1.7924	1.3014
13	.7922		.4481	1.7541	1.6975	1.8484	1.3014
14	.7922			.7922	1.6409	1.9239	1.358
15	.9619		1.8484	.7356	1.6975	1.8484	1.358
16	.8488		2.0165	1.8107	1.8107	1.8107	1.4712
17	.9054	.4527	1.0642	1.8673	1.6975	1.8484	1.4712
18	1.0185	.4527	1.9605	1.5844	1.9805	1.8484	1.6975
19	.8488	.5658	2.2405	2.7161	2.5463	2.4646	2.1502
20		.679	2.3525	2.7161	2.6029	2.6886	2.3765
21	.5658	.679	2.3285	2.6029	2.4897	2.5766	2.2634
22	.5093	.6224	2.1845	2.3765	2.32	2.3525	2.037
23	.4527	.5658	1.8519	2.2068	2.037	2.1285	2.037
24	.7922	.4527	.5093	2.0165	2.2068	2.037	2.1285
Max	1.0751	.679	2.3525	2.7161	2.6029	2.6886	2.3765
Min	.4527	.3395	.3961	.7356	1.4712	1.7924	.6722
Avg	.7748	.4753	1.0730	1.8559	2.0488	2.0515	1.7454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 201 / 11KV MURUMGAON ROAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.168	.1663	.1478	.1494	.168	.1867
2	.168	.168	.1663	.1478	.1494	.168	.1867
3	.168	.168	.1478	.1478	.1494	.168	.1867
4	.168	.168	.1478	.1494	.1494	.168	.1867
5	.168	.168	.1663	.1494	.1494	.168	.1867
6	.1663	.1494	.1294	.1294	.1494	.1494	.1663
7	.1663	.1448	.1629	.1448	.1463	.1494	.1663
8	.1448	.1448	.1448	.1448	.1097	.1663	.1663
9	.1086	.0543	.1267	.1433	.0716	.1294	.0739
10	.1086	.0905	.1086	.1254	.128	.1478	.0549
11	.1086	.0876	.1063	.0895	.1267	.0924	.0905
12	.0905	.0876	.1086	.1052		.1109	
13	.0905	.1075		.0895	.0739	.1294	.0362
14	.1267	.1075	.1267	.1075	.128	.1109	.0914
15	.1254	.1052	.1214	.1075	.1086	.1109	.1097
16	.1086	.0895	.1214	.0543	.1097	.1109	.0914
17	.1075	.1267	.1267	.0716	.1267	.1478	.1063
18	.1227	.1417	.128	.1433	.1646	.1463	.0514
19	.2054	.2241	.1829		.2427	.2054	.1867
20	.2641	.2614	.2614		.2427	.2427	.2452
21	.2614	.2427	.2614		.2427	.2241	.2054
22	.2054	.2033	.1867		.2054	.2054	.1867
23	.1867	.1848	.1478		.1867	.1867	.1494
24	.168	.168	.1848	.1478	.1494	.1867	.1867
Max	.2641	.2614	.2614	.1494	.2427	.2427	.2452
Min	.0905	.0543	.1063	.0543	.0716	.0924	.0362
Avg	.1544	.1484	.1535	.1235	.1504	.1580	.1434

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 202 / 11KV DHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108	.4066	.4066	.3921	.3921	.3734
2	.4108	.4108	.4066	.4066	.3921	.3734	.3734
3	.3921	.4108	.4066	.4066	.3921	.3734	.3734
4	.3921	.4108	.3881	.3881	.3921	.3734	.3734
5	.3696	.3734	.3696	.3881	.3734	.3547	.3547
6	.3142	.3174	.3142	.3326	.3547	.3174	.2957
7	.2587	.2715	.2534	.2534	.2561	.2801	.2402
8	.2534	.2353	.2715	.2534	.2743	.2587	.2402
9	.2896	.2896	.2715	.2507	.2507	.2587	.2561
10	.2715	.2896	.3077	.2507	.2561	.2587	.2561
11	.2715	.2804	.2658	.2686	.2534	.2033	.2896
12	.3258	.2804	.3258	.2454	.2896	.2402	.2534
13	.3439	.2865	.3258	.2507	.2772	.2772	.2378
14	.3439	.2865	.3077	.2507	.2743	.2241	.2743
15	.3045	.2804	.3121	.2865	.2896	.2218	.2561
16	.3258	.2686	.3121	.2896	.2561	.2587	.2561
17	.2865	.2896	.2896	.2686	.2353	.2218	.2303
18	.333	.2658	.2743		.2561	.2561	.2401
19	.4481	.4294	.1829		.4481	.3547	.4108
20	.5281	.4854	.5228		.4668	.4668	.4527
21	.5228	.4854	.5228		.4668	.4481	.4481
22	.4854	.4805	.4854		.4481	.4294	.4294
23	.4481	.4435	.4435		.4108	.3921	.3921
24	.4108	.4294	.4066	.4251	.3921	.3921	.3734
Max	.5281	.4854	.5228	.4251	.4668	.4668	.4527
Min	.2534	.2353	.1829	.2454	.2353	.2033	.2303
Avg	.3642	.3505	.3489	.3123	.3374	.3178	.3200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 203 / 11KV CHATGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5228	.5729	.5544	.5041	.5041	.5228
2	.4854	.5228	.5544	.5544	.4854	.5041	.5228
3	.4854	.5041	.5544	.5544	.4854	.4854	.5228
4	.4668	.5041	.5544	.5544	.4854	.4854	.5228
5	.462	.4854	.5359	.5359	.4668	.4668	.5041
6	.4066	.4668	.462	.499	.4481	.3921	.462
7	.3696	.4525	.4887	.4887	.4024	.3361	.462
8	.3439	.4163	.3982	.4344	.3658	.2957	.462
9	.2896	.362	.3982	.4119	.3761	.2772	.4066
10	.3077	.3258	.3258	.3761	.2743	.2587	.3658
11		.3155	.3012	.2507	.2896		.3258
12	.4344	.3681	.3982	.333	.2896	.2033	.3258
13	.4163	.2865	.3982	.3224	.2957		.2896
14	.4163	.3224	.3801	.4298	.2926	.2218	.3109
15	.4477	.3506	.4161	.4119	.2896	.2033	.2743
16	.3982	.3403	.3641	.4163	.2926	.037	
17	.394		.3077	.3761	.3077		.3189
18	.4382	.3366	.4458		.4024	.3841	.3772
19		.5975	.5853		.6535	.6908	.6535
20	.7545	.8215	.8215		.7282	.7842	.7545
21	.7282	.7842	.8029		.6908	.7282	.7095
22	.6535	.6653	.7095		.6348	.5975	.6161
23	.5975	.6283	.6283		.5228	.5228	.5415
24	.5041	.5601	.5914	.5544	.5041	.5228	.5228
Max	.7545	.8215	.8215	.5544	.7282	.7842	.7545
Min	.2896	.2865	.3012	.2507	.2743	.037	.2743
Avg	.4675	.4756	.4998	.4477	.4370	.4239	.4684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 204 / 11KV RANGI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2427	.2957	.2402	.2241	.2614	.2801
2	.2427	.2427	.2772	.2402	.2241	.2614	.2801
3	.2427	.2427	.2772	.2402	.2241	.2614	.2614
4	.2241	.2241	.2587	.2402	.2241	.2614	.2614
5	.2033	.2241	.2402	.2218	.2241	.2427	.2614
6	.1478	.2054	.2218	.2033	.2054	.2241	.2218
7	.1663	.2172	.181	.2218	.2012	.2054	.2033
8	.181	.2715	.0543	.2353		.2218	.1848
9	.181		.2353	.2865		.2587	.2587
10	.1629	.1629	.181	.2149		.2033	
11	.1629	.1753	.2303	.2328	.2172	.1663	.1267
12	.1629	.1753	.2353	.2279	.2172	.2033	.1267
13	.1629	.1791	.2353	.2149	.2218	.1848	.1448
14	.1629	.197	.2534	.2149	.2378	.1663	.1646
15	.1791	.1753	.2427	.197	.1991	.1848	.2012
16	.1629	.2149	.2254	.181	.2012	.2033	.1829
17	.197	.181	.2353	.197	.181	.2218	.1595
18	.2103	.2126	.2378		.2195	.2195	.1715
19	.2614	.2987	.2195		.2987	.2987	.2427
20	.3174	.3921	.3361		.3361	.3361	.3018
21	.3174	.3734	.3547		.2801	.3361	.2801
22	.2801	.3511	.2801		.2801	.2987	.2614
23	.2614	.3142	.2587		.2614	.2801	.2427
24	.2427	.2614	.2957	.2402	.2241	.2054	.2801
Max	.3174	.3921	.3547	.2865	.3361	.3361	.3018
Min	.1478	.1629	.0543	.181	.181	.1663	.1267
Avg	.2115	.2406	.2443	.2250	.2334	.2378	.2217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 401 / 33KV Murumgaon Feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3921	.3326	.3881	.3361	.3921	.4481
2	.2801	.3361	.3326	.3881	.3361	.3921	.4481
3	.2801	.3361	.3326	.3881	.3361	.3361	.4481
4	.2801	.3361	.3326	.3881	.3361	.3361	.4481
5	.2772	.3361	.2772	.3881	.3361	.3361	.4481
6	.2218	.2801	.2218	.3326	.3361	.2801	.3921
7	.2218	.2172	.2172	.2772	.2743	.2241	.2801
8	.1663	.1629	.2172	.2772	.2195	.2218	.2772
9	.1629	.1086	.1629	.2686	.1075	.2218	.1663
10	.1629	.1629	.1086	.2686	.1097	.2218	.2195
11	.1086	.1578	.1063	.2686	.1086	.1663	.1629
12	.1086	.1578	.1086	.1578	.1629	.2218	.1629
13	.0543	.1612	.1086	.1075	.1663	.1663	.1646
14	.1086	.1612	.1629	.1612	.2195	.2218	.1646
15	.2149	.1578	.156	.1612	.2172	.1663	.2195
16	.1629	.2149	.156	.1629	.1646	.1663	.2195
17	.1612	.2715	.1646	.1612	.1629	.2218	.2126
18	.1578	.2658	.1646		.2743	.2195	.2058
19	.2801	.2801	.3292		.4481	.4938	.5041
20	.3961	.2801	.4938		.4481	.5041	.5658
21	.4481	.3361	.4938		.4481	.4481	.5601
22	.3921	.3326	.439		.3921	.5041	.5041
23	.3361	.3326	.3881		.3921	.4481	.4481
24	.2801	.3361	.2772	.3881	.3361	.3921	.4481
Max	.4481	.3921	.4938	.3881	.4481	.5041	.5658
Min	.0543	.1086	.1063	.1075	.1075	.1663	.1629
Avg	.2310	.2547	.2535	.2741	.2779	.3043	.3383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104004 / DHANORA

Feeder No / Name : 402 / 33KV incommer dhanora

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	1.9044	1.9404	1.9404	1.7924	1.8484	1.8484
2	1.8484	1.8484	1.885	1.9404	1.7364	1.7924	1.8484
3	1.8484	1.8484	1.885	1.9404	1.7364	1.7364	1.7924
4	1.7924	1.8484	1.8296	1.885	1.7364	1.7364	1.7924
5	1.7924	1.7364	1.7187	1.885	1.6804	1.6804	1.7924
6	1.4003	1.5684	1.5524	1.7187	1.5912	1.4563	1.6244
7	1.2752	1.4118	1.4118	1.5912	1.4266	1.2883	1.4415
8	1.2197	1.2489	1.1946	1.4661	1.0974	1.2197	1.4415
9	1.1403	1.086	1.3032	1.5581	.9671	1.2752	1.2752
10	1.1403	1.1403	1.1946	1.4506	.8779	1.1643	.9328
11	.7059	1.1043	1.1694	1.2357	1.1403	.7207	1.086
12	1.2489	1.1568	1.2489	1.2094	1.0317	.9979	.9774
13	1.2197	1.0745	1.2489	1.1283	1.1088	.9425	.9774
14	1.2489	1.1283	1.3575	1.2894	1.2071	.9425	.9877
15	1.3432	1.1568	1.4043	1.2894	1.1403	.9425	1.0974
16	1.2489	1.182	1.3523	1.2489	1.0974	.7762	1.1523
17	1.2894	1.086	1.4266	1.2357	1.086	.8316	1.1163
18	1.4198	1.2757	1.4266		1.3717	1.3169	1.1831
19	1.3443	1.9605	1.8107		2.1285	2.5206	2.0725
20	2.3765	2.4086	2.6606		2.4086	2.3525	2.3765
21	2.5206	2.3525	2.6886		2.3525		2.2965
22	2.2405	2.2177	2.3045		2.1285	2.1845	2.0725
23	2.0165	2.0513	2.1068		1.9044	1.9044	1.8484
24	1.7924	1.9605	1.9959	1.9404	1.7924	1.8484	1.8484
Max	2.5206	2.4086	2.6886	1.9404	2.4086	2.5206	2.3765
Min	.7059	1.0745	1.1694	1.1283	.8779	.7207	.9328
Avg	1.5551	1.5732	1.6715	1.5530	1.5225	1.4556	1.5367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104011 / MURUMGAON

Feeder No / Name : 201 / 11KV KATEZARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0094	.0283	.0283	.0095	.0283	.0283
2	.0189	.0094	.0283	.0283	.0095	.0283	.0283
3	.0189	.0094	.0283	.0283	.0095	.0283	.0283
4	.0189	.0094	.0283	.0283	.0095	.0283	.0283
5	.0189	.0094	.0283	.0283	.0095	.0283	.0283
6	.0189	.0038	.0187	.0187	.0038	.0283	.0283
7	.0189	.0038	.0187	.0187	.0038	.0283	.028
8	.0189	.0038	.0094	.0187	.0038	.0183	.0185
9	.0189	.0038	.0094	.0185		.0185	.0183
10	.0094	.0038	.0095	.0185		.0183	.0185
11	.0093		.0095	.0095		.0183	.0185
12	.0093	.0095	.0095	.0095		.0181	.0185
13	.0093	.0095	.0095	.0095		.0095	.0094
14	.0093	.0095	.0095	.0095		.0095	.0094
15	.0093	.0095	.0095	.0095	.0187	.0095	.0094
16	.0093	.0095	.0095	.0095	.0185	.0095	.0094
17	.0094	.0191	.0095	.0095	.0185	.0095	.0183
18	.0038	.0187	.0191	.0187	.0187	.0185	.0185
19	.0038	.0283	.0377	.0377	.0283	.0377	.0277
20	.0095	.0377	.0377	.0377	.0377	.0377	.028
21	.0094		.0377	.0377	.0377	.0377	.028
22	.0094	.0283	.0377	.0377	.0377	.0377	.0283
23	.0094	.0283	.0283	.0283	.0283	.0283	.0283
24	.0283	.0094	.0283	.0283	.0283	.0283	.0283
Max	.0283	.0377	.0377	.0377	.0377	.0377	.0283
Min	.0038	.0038	.0094	.0095	.0038	.0095	.0094
Avg	.0133	.0129	.0208	.0220	.0184	.0235	.0222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104011 / MURUMGAON

Feeder No / Name : 202 / 11 KV SAWARGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3734	.3961	.3678	.3678	.3772	.3584
2	.4108	.3734	.3961	.3678	.3678	.0283	.3584
3	.3921	.3547	.3961	.3678	.3678	.3772	.3584
4	.3921	.3547	.3867	.3395	.3678	.3772	.3584
5	.3734	.3547	.3867	.3395	.3678	.3584	.3584
6	.3734	.3454	.3772	.3206	.3489	.3395	.3395
7	.3361	.2987	.3206	.2924	.3206	.3206	.3206
8	.3049	.2587	.2735	.2452	.2641	.3018	.3112
9	.2957	.2641	.0934	.2169	.2263		.2641
10	.2402	.2169	.2263	.2169	.2075	.2452	.2452
11	.2103	.198	.2452	.1886	.2263	.2263	.2358
12		.198	.2735	.1698	.2075	.2263	.2263
13	.0823	.198	.2924	.1886	.2169	.2075	.2169
14	.2012	.2358	.2829	.198	.2263	.3018	.2075
15	.2033	.2924	.2263	.1886	.2075	.198	.2075
16	.2033	.2075	.2169	.1886	.2075	.198	.2075
17	.2054	.2075	.1886	.1886	.2263	.198	.2075
18	.2801	.2546	.2452	.2452	.2452	.2452	.2829
19	.3921	.4055	.415	.4055	.4055	.415	.3867
20	.4904	.4432	.415	.4621	.4621	.4338	.415
21	.4715	.481	.4621	.4527	.4527	.4432	.4055
22	.4294	.4527	.4244	.4244	.4244	.415	.3772
23	.4244	.415	.3961	.4055	.3867	.3772	.3489
24	.415	.3772	.4055	.3772	.3867	.3772	.3678
Max	.4904	.481	.4621	.4621	.4621	.4432	.415
Min	.0823	.198	.0934	.1698	.2075	.0283	.2075
Avg	.3279	.3150	.3226	.2982	.312	.3038	.3069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104011 / MURUMGAON

Feeder No / Name : 203 / 11KV MURUMGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.14	.1307	.1509	.14	.14	.14	.132
2	.1386	.1307	.1494	.14	.14	.14	.132
3	.1386	.1214	.1494	.14	.14	.14	.132
4	.1294	.1201	.14	.1307	.14	.14	.132
5	.1294	.1109	.1307	.1294	.14	.1307	.132
6	.1294	.0924	.112	.1201	.1201	.1201	.1214
7	.1006	.0832	.0924	.1109	.1016	.1016	.1109
8	.1006	.0647	.0924	.0934	.0924	.1006	.1016
9	.0823	.064	.0924	.0934	.0832		.0924
10	.0724	.0832	.0832	.0832	.1027	.0732	.0823
11	.0724	.0362	.0832	.0732	.0934	.0566	.0732
12	.0806	.0271	.0732	.0732	.0934	.0566	.0732
13	.0895	.0271	.0732	.064	.0832	.0754	.0732
14	.0797	.0362	.0732	.064	.0832	.0754	.0633
15	.0806	.0362	.0823	.0823	.0832	.0754	.0633
16	.0814	.0924	.0732	.0823	.0653	.0754	.0732
17	.0732	.0832	.064	.084	.084	.0849	.0732
18	.0823	.1016	.0924	.1226	.0924	.0832	.112
19	.1571	.1587	.168	.198	.1698	.1698	.168
20	.2054	.2169	.196	.2147	.198	.1886	.1698
21	.196	.198	.2075	.1867	.1886	.1792	.1792
22	.1774	.1792	.1774	.1587	.1698	.1509	.1509
23	.1494	.1587	.1587	.1494	.14	.132	.1509
24	.14	.1307	.1494	.14	.14	.14	.132
Max	.2054	.2169	.2075	.2147	.198	.1886	.1792
Min	.0724	.0271	.064	.064	.0653	.0566	.0633
Avg	.1178	.1035	.1194	.1198	.1202	.1143	.1135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104017 / 33KV GATTA

Feeder No / Name : 201 / 11KV GATTA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0037	.0037	.0037	.0019	.0038	.0038	.0019
2	.0038	.0037	.0037	.0019	.0038	.0038	.0019
3	.0019	.0037	.0037	.0019	.0038	.0038	.0019
4	.0019	.0037	.0037	.0019	.0019	.0019	.0038
5	.0038	.0037	.0037	.0019	.0038	.0019	.0019
6	.0038	.0037	.0037	.0019	.0038	.0019	.0019
7	.0019	.0019	.0018	.0019	.0019	.0019	.0019
8	.0019	.0019	.0019	.0019	.0038	.0019	.0019
9	.0019	.0038	.0019	.0019	.0019	.0019	.0019
10	.0019	.0019	.0019	.0019		.0019	.0019
11		.0019	.0019	.0018		.0019	.0019
12		.0019	.0019	.0018		.0019	.0019
13		.0019	.0019	.0018		.0019	.0019
14		.0019	.0019	.0018		.0019	.0019
15		.0019	.0019	.0019	.0017	.0019	.0018
16		.0019	.0019	.0019	.0018	.0019	.0018
17	.0019	.0019	.0019	.0019	.0018	.0019	.0018
18	.0019	.0019	.0019	.0018	.0019	.0019	.0018
19	.0037	.0037	.0038	.0037	.0038	.0038	.0037
20	.0037	.0037	.0037	.0038	.0038	.0038	.0037
21	.0037	.0037	.0037	.0038	.0038	.0037	.0037
22	.0037	.0037	.0038	.0038	.0038	.0037	.0037
23	.0037	.0037	.0019	.0038	.0038	.0038	.0037
24	.3326	.0037	.0037	.0019	.0038	.0038	.0038
Max	.3326	.0038	.0038	.0038	.0038	.0038	.0038
Min	.0019	.0019	.0018	.0018	.0017	.0019	.0018
Avg	.0212	.0029	.0027	.0023	.0031	.0026	.0024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

DHANORA S/DN.[341]

BU 4646

Substation No/ Name :- 104017 / 33KV GATTA

Feeder No / Name : 202 / 11KV PENDHARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0057	.0113	.0113	.0113	.0114	.0113	.0113
2	.0057	.0113	.0113	.0113	.0114	.0113	.0113
3	.0056	.0113	.0113	.0113	.0114	.0113	.0095
4	.0075	.0113	.0113	.0113	.0114	.0113	.0095
5	.0075	.0132	.0113	.0094	.0114	.0113	.0095
6	.0094	.0113	.0112	.0094	.0114	.0094	.0092
7	.0094	.0094	.0093	.0094	.0095	.0094	.0092
8	.0093	.0094	.0093	.0075	.0075	.0094	.0092
9	.0075	.0094	.0075	.0057	.0076	.0093	.0094
10	.0075	.0057	.0075	.0038		.0074	.0074
11		.0055	.0075	.0057		.0075	.0053
12		.0055	.0075	.0057		.0055	.0054
13		.0056	.0075	.0057		.0054	.0054
14		.0056	.0075	.0037		.0056	.0053
15		.0075	.0075	.0038	.0075	.0055	.0054
16		.0075	.0057	.0057	.0075	.0055	.0055
17	.0075	.0056	.0038	.0057	.0075	.0054	.0055
18	.0075	.0057	.0075	.0093	.0094	.0092	.0092
19	.0132	.0132	.0132	.0152	.0133	.0113	.0151
20	.0189	.017	.017	.0171	.017	.017	.017
21	.017	.0171	.017	.0151	.0151	.0132	.017
22	.0151	.0152	.0133	.0151	.0132	.0113	.0151
23	.0132	.0133	.0114	.0133	.0132	.0113	.0132
24	1.1643	.0132	.0113	.0114	.0133	.0113	.0113
Max	1.1643	.0171	.017	.0171	.017	.017	.017
Min	.0056	.0055	.0038	.0037	.0075	.0054	.0053
Avg	.0740	.0100	.01	.0093	.0111	.0094	.0096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104010 / 33/11 KV SAWELA

Feeder No / Name : 201 / 11 KV POTEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.112	.1132	.112	.1132	.1172	.112
2	.132	.112	.1132	.112	.1132	.1136	.112
3	.1132	.112	.1132	.112	.1132	.1116	.112
4	.1132	.112	.1132	.112	.1132	.1102	.112
5	.132	.112	.132	.112	.1132	.1154	.112
6	.0754	.0747	.0754	.056	.0943	.0832	.0747
7	.0566	.0747	.0754	.056	.0754	.0797	.0747
8	.0754	.056	.0754	.056	.0717	.0637	.056
9	.056	.0566	.056	.0566	.0717	.0747	.0566
10	.056	.0566	.0373	.0566	.0733	.056	.0566
11	.056	.0566	.056	.0377	.0604	.056	.0566
12	.056	.0566	.056	.0377	.0536	.056	.0566
13	.0373		.056	.0377	.0621	.056	.0566
14	.0373		.0373	.0566	.066	.056	.0566
15	.0373		.056	.0566	.0738	.0373	.0566
16	.056	.0754	.056	.0377	.0696	.0373	.0566
17	.0709	.0754	.0373	.0754	.0664	.056	.0566
18	.056	.0754	.056	.0566	.0914	.056	.0566
19	.112	.1132	.0934	.1509	.1462	.1307	.132
20	.168	.1698	.168	.1698	.1542	.1494	.1698
21	.168	.1698	.168	.1509	.1532	.1494	.1509
22	.1494	.1509	.112	.132	.1358	.1307	.132
23	.1307	.132	.112	.132	.1254	.112	.1132
24	.1132	.112	.132	.112	.1132	.1169	.112
Max	.168	.1698	.168	.1698	.1542	.1494	.1698
Min	.0373	.056	.0373	.0377	.0536	.0373	.056
Avg	.0912	.0984	.0875	.0869	.0968	.0885	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104010 / 33/11 KV SAWELA

Feeder No / Name : 202 / 11 KV GURWALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1307	.132	.1307	.132	.1353	.1307
2	.132	.1307	.132	.1307	.132	.1326	.1307
3	.132	.1307	.132	.1307	.132	.1351	.1307
4	.132	.1307	.132	.1307	.132	.1366	.1307
5	.1509	.1494	.1509	.1307	.1509	.1448	.1307
6	.0943	.112	.0943	.0934	.1132	.1085	.112
7	.0566	.056	.0754	.056	.0754	.0817	.0747
8	.0754	.056	.0754	.056	.0564	.0742	.0747
9	.0747	.0754	.0747	.0754	.0699	.0747	.0754
10	.056	.0754	.0747	.0754	.0701	.0747	.0754
11	.056	.0566	.056	.0566	.066	.0747	.0566
12	.056	.0566	.056	.0566	.0699	.056	.0754
13	.0747	.0566	.0037	.0566	.0772	.056	.0754
14	.056	.0754	.0747	.0754	.0641	.056	.0566
15	.056	.0566	.056	.0566	.0674	.056	.0566
16	.0747	.0566	.056	.0754	.0845	.056	.0566
17	.0523	.0566	.056	.0754	.0791	.0373	.0754
18	.0747	.0754	.0934	.0754	.1021	.056	.0754
19	.1307	.132	.1494	.1509	.1653	.1494	.1509
20	.1867	.1886	.1867	.1886	.1941	.1867	.1886
21	.1867	.2075	.1867	.1886	.1816	.168	.1698
22	.168	.1698	.168	.1509	.1573	.1494	.1509
23	.1307	.1509	.1307	.1509	.1391	.1307	.132
24	.132	.1307	.132	.1307	.132	.1372	.1307
Max	.1867	.2075	.1867	.1886	.1941	.1867	.1886
Min	.0523	.056	.0037	.056	.0564	.0373	.0566
Avg	.1030	.1049	.1033	.1041	.1102	.1028	.1049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104018 / 33/11KV Kotgal SubStation

Feeder No / Name : 201 / 11KV Complex Feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9035	2.0328	1.9959	1.9589	1.8111	1.8111	1.6632
2	1.9035	1.9959	1.9589	1.922	1.8111	1.7741	1.6632
3	1.8484	1.9791	1.9605	1.9231	1.7926	1.7364	1.6632
4	1.7741	1.9605	1.9044	1.8671	1.7551	1.7364	1.6278
5	1.7372	1.885	1.8296	1.8111	1.7002	1.6448	1.6095
6	1.5893	1.6448	1.6095	1.6078	1.5524	1.5339	1.4118
7	1.4449	1.5546	1.4266	1.4266	1.39	1.2752	1.3213
8	1.39	1.4449	1.2803	1.267	1.2803	.8962	1.3717
9	1.4083	1.4998	1.3717	1.3169	1.39	1.2803	1.39
10	1.448	1.4632	1.5181	1.39	1.3717	1.2986	1.39
11	1.5364	1.5364	1.5181	1.448	1.3535	1.3352	1.3937
12	1.5546	1.4969	1.5364	1.4118	1.4118	1.2567	1.2986
13	1.6095	1.6095	1.6827	1.4815	1.423	1.0974	1.2986
14	1.6095	1.6804	1.5364	1.4632	1.39	1.1157	1.2437
15	1.6289	1.701	1.6461	1.4632	1.4415	1.1403	1.2254
16	1.647	1.6461	1.5364	1.4449	1.4083	1.086	1.2986
17	1.6263	1.4815	1.5893	1.3937	1.3032	1.1706	1.2851
18	1.5524	1.4998	1.4815	1.4327	1.3575	1.2308	1.2382
19	1.829	1.7556	1.9035	1.7924	1.6632	1.5729	1.5708
20	2.1033	2.1068	2.1622	1.8473	1.8111	1.7558	1.7187
21	2.2405	2.1807	2.1437	1.9035	1.9035	1.8111	1.701
22	2.2177	2.2177	2.1948	1.9978	1.9589	1.848	1.7556
23	2.1437	2.1253	2.1437	1.922	1.8473	1.8111	1.7002
24	1.9404	2.0328	2.0328	1.9959	1.8296	1.8111	1.7002
Max	2.2405	2.2177	2.1948	1.9978	1.9589	1.848	1.7556
Min	1.39	1.4449	1.2803	1.267	1.2803	.8962	1.2254
Avg	1.7369	1.7721	1.7485	1.6454	1.5815	1.4596	1.4808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104018 / 33/11KV Kotgal SubStation

Feeder No / Name : 202 / 11 KV KOTGAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.724	.6401	.724	.6036	.6878	.5853
2	.6219	.7316	.6401	.695	.5853	.6219	.5853
3	.6099	.7316	.6283	.7023	.5853	.6219	.5853
4	.6099	.7499	.6099	.6653	.5544	.6099	.5853
5	.6036	.7865	.6036	.6401	.5487	.6036	.543
6	.5487	.567	.543	.6401	.4024	.5249	.4835
7	.4525	.6584	.4525	.5194	.3982	.4572	.4525
8	.4119	.543	.5373	.4477	.4525	.4887	.3258
9	.4706	.5973	.5853	.4835	.4938	.5121	.3898
10	.4755	.5792	.5611	.4938	.4477	.5487	.3801
11	.4572	.5068	.567	.4755	.4755	.5138	.4668
12	.4755	.4938	.6099	.6036	.6516	.5487	.394
13	.5068	.439	.5792	.4706	.695	.5138	.4163
14	.4887	.4938	.6219	.4755	.5487	.4477	.4298
15	.4938	.5121	.7392	.4572	.4938	.4755	.4024
16	.5068	.2328	.6584	.4938	.4755	.5792	.3841
17	.4706	.4525	.6584	.2561	.5068	.5249	
18	.4733	.6219	.6401	.4525	.567	.543	.4024
19	.5792	.7682	.6219	.5792	.724	.7059	.6401
20	.7011	.8779	.823	.6767	.823	.7602	.7316
21	.7602	.8048	.7133	.6584	.8048	.7316	.7059
22	.724	.8145	.6697	.5729	.7682	.7316	.6767
23	.695	.7602	.6335	.6335	.7164	.6036	.6584
24	.6089	.6697	.6767	.724	.5487	.724	.6219
Max	.7602	.8779	.823	.724	.823	.7602	.7316
Min	.4119	.2328	.4525	.2561	.3982	.4477	.3258
Avg	.5570	.6299	.6256	.5642	.5780	.5867	.5151

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104018 / 33/11KV Kotgal SubStation

Feeder No / Name : 203 / 11 KV INDUSTRIAL FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1494	.1478	.1494	.1509	.1307	.132
2	.132	.1509	.1494	.1509	.1509	.132	.132
3	.132	.1509	.1509	.1509	.1509	.132	.132
4	.132	.1509	.132	.1509	.1509	.132	.132
5	.1307	.1494	.1307	.1132	.1509	.1307	.1307
6	.0914	.1132	.0934	.112	.1132	.1307	.1109
7	.0716	.1132	.0739	.0934	.0924	.0943	.0914
8	.0886	.1867	.0724	.1097	.112	.0905	.0914
9	.181	.2378	.1147	.1326	.1254	.5068	.1254
10	.1478	.2507	.2347	.1543	.2328	.104	.1267
11	.1663	.2507	.2401	.2402	.2561	.0876	.12
12	.2103	.1629	.208	.2507	.2195	.1097	.1147
13	.2229	.1595	.181	.1463	.2218	.124	.1267
14	.2058	.2058	.1791	.1097	.1991	.0914	.0905
15	.2267	.2347	.2058	.208	.1578	.1307	.0914
16	.2105	.2012	.2378	.2303	.156	.0914	.0732
17	.1886	.2172	.2561	.2507	.1663	.0924	.0732
18	.1715	.1629	.1448	.2126	.128	.112	.0934
19	.1372	.1294	.168	.2427	.1509	.128	.1132
20	.1715	.1698	.1867	.168	.2075	.1433	.132
21	.1663	.168	.1698	.1867	.1698	.1698	.128
22	.1698	.1663	.1629	.1698	.1494	.1509	.132
23	.168	.1307	.1509	.1509	.1307	.132	.1132
24	.1494	.1509	.1478	.1494	.1509	.1307	.132
Max	.2267	.2507	.2561	.2507	.2561	.5068	.132
Min	.0716	.1132	.0724	.0934	.0924	.0876	.0732
Avg	.1584	.1735	.1641	.1681	.1623	.1366	.1141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104019 / 33/11 KV AMIRZA S/STN

Feeder No / Name : 201 / 11 KV AMIRZA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.1886	.1923	.1886	.181	.1715	.2058
2	.181	.1865	.192	.1886	.1629	.1715	.2058
3	.181	.1928	.1946	.1886	.1629	.1715	.2058
4	.1629	.1928	.1925	.1886	.181	.1696	.2058
5	.1629	.1734	.1943	.1715	.181	.1734	.2058
6	.1448	.1715	.1932	.1543	.1629	.1696	.1715
7	.181	.1907	.2105	.1715	.1595	.1886	.1886
8	.2353	.2204	.2597	.2572	.1433	.2035	.2058
9	.181	.2572	.3077	.2543	.1578	.2229	.1928
10	.1631	.2229	.2534	.1734	.1372	.1949	.1734
11	.1625	.2229	.2126	.1907	.1372	.1595	.1907
12	.1959	.2401	.156	.2103	.1372	.1772	.156
13	.1943	.2229	.1772	.208	.1372	.1991	.1372
14	.1982	.2572	.181	.2279	.12	.1949	.1372
15	.2105	.2229	.1772	.2254	.12	.1492	.1734
16	.1786	.2572	.1772	.208	.12	.1658	.156
17	.2229	.1723	.1886	.2353	.1387	.1886	.181
18	.1886	.1786	.1715	.2353	.1326	.1543	.1372
19	.2229	.2286	.2743	.2534	.2204	.2229	.2103
20	.2454	.2759	.2915	.2172	.2401	.2401	.2715
21	.2515	.2591	.2915	.2195	.2229	.2401	.2534
22	.2204	.2463	.2229	.2195	.1886	.2229	.2353
23	.2058	.2108	.1991	.2172	.12	.2229	.1991
24	.2012	.1865	.1948	.1991	.1991	.1029	.2058
Max	.2515	.2759	.3077	.2572	.2401	.2401	.2715
Min	.1448	.1715	.156	.1543	.12	.1029	.1372
Avg	.1955	.2158	.2127	.2085	.1610	.1866	.1919

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104019 / 33/11 KV AMIRZA S/STN

Feeder No / Name : 203 / 11 KV MOUSHIKHAMB

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.3856	.3239	.3467	.3658	.3561	.3467
2	.3658	.3641	.2925	.3467	.3841	.3561	.3467
3	.3292	.3561	.2922	.3467	.3658	.3561	.3467
4	.2926	.3561	.2603	.3467	.3475	.3601	.3467
5	.2743	.3561	.2579	.3467	.3292	.3429	.3467
6	.2743	.3641	.2597	.2947	.2926	.3601	.2601
7	.2534	.3258	.2267	.2774	.2561	.3086	.2601
8	.3077	.2374	.2756	.2774	.2715	.2743	.2774
9	.2534	.2543	.3109	.2883	.2896	.2883	.2915
10	.2273	.208	.3077	.3391	.2774	.2715	.2601
11	.1134	.156	.2534	.2947	.0173	.2715	.2254
12	.2135	.156	.1753	.2204		.2715	.2254
13	.1946	.1907	.3258	.2572	.208	.2303	.2254
14	.2418	.208	.2715	.2743	.208	.2481	.2427
15	.2115	.1907	.2896	.2804	.2427	.1949	.208
16	.2132	.208	.2353	.2774	.2254	.2353	.2058
17	.1886	.2273	.208	.2926	.2427	.2254	.2561
18	.2629	.2492	.2254	.2926	.2543	.2254	.2926
19	.3561	.3777	.3294	.4024	.3988	.3814	.3841
20	.4917	.3559	.4508		.4681	.4508	.4572
21	.4748	.4285	.4681	.4207	.4557	.4161	.4207
22	.4239	.4424	.3814	.3801	.39	.3988	.4024
23	.3988	.3563	.3467	.3658	.3561	.3814	.3658
24	.3841	.3601	.3579	.3641	.3658	.3561	.3641
Max	.4917	.4424	.4681	.4207	.4681	.4508	.4572
Min	.1134	.156	.1753	.2204	.0173	.1949	.2058
Avg	.2971	.2964	.2969	.3188	.3049	.3150	.3066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 104019 / 33/11 KV AMIRZA S/STN

Feeder No / Name : 401 / 33 KV AMIRZA INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.6787	1.5711	1.6832	1.5604	1.5769	1.7918
2	1.5947	1.6644	1.4678	1.6832	1.5604	1.6301	1.7918
3	1.4883	1.6278	1.4832	1.6832	1.5083	1.5769	1.7918
4	1.3289	1.6278	1.3827	1.6832	1.4752	1.5947	1.7918
5	1.2757	1.6461	1.3763	1.6289	1.4243	1.5947	1.7918
6	1.2226	1.5769	1.3747	1.4118	1.2717	1.6124	1.3575
7	1.2757	1.5261	1.3256	1.4118	1.1437	1.4563	1.4118
8	1.5947	1.4723	1.5185	1.6832	1.1831	1.4563	1.5746
9	1.2757	1.5432	1.7353	1.6827	1.3003	1.5083	1.4243
10	1.1687	1.3575	1.6301	1.5432	1.2209	1.3672	1.3077
11	.8278	.5267	1.3672	1.4563	.4207	1.262	1.1934
12	1.2231	.4941	.9774	1.3523	.407	1.3146	1.1317
13	1.1783	.4995	1.4723	1.3735	.9882	1.262	1.1317
14	1.3272	.543	1.3146	1.5083	.9774	1.3146	1.1317
15	1.2661	.5267	1.3672	1.5604	1.0402	1.0288	1.1317
16	1.1756	.5321	1.1963	1.4243	1.0402	1.2094	1.1443
17	1.2346	1.236	1.1946	1.5083	1.1831	1.3575	1.262
18	1.3735	1.2661	1.2489	1.4752	1.1317	1.2489	1.262
19	1.6787	1.7976	1.8461	1.8313	1.8313	1.9004	1.2094
20	2.1628	1.8992	2.3348	.6173	2.0805	2.2262	2.1719
21	2.2611	2.0477	2.3891	1.8004	1.9839	2.1176	2.009
22	1.9765	2.0405	1.8461	1.6975	1.7295	1.9004	1.9004
23	1.8204	1.7384	1.7375	1.6278	1.4403	1.8461	1.701
24	1.7375	1.6787	1.6693	1.7375	1.6278	1.4043	1.7918
Max	2.2611	2.0477	2.3891	1.8313	2.0805	2.2262	2.1719
Min	.8278	.4941	.9774	.6173	.407	1.0288	1.1317
Avg	1.4669	1.3561	1.5344	1.5444	1.3138	1.5319	1.5086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 201 / 11 KV NAGAR PARISHAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9936	2.1807	1.829	2.0119	1.5893	1.829	1.701
2	1.9936	2.1807	1.829	2.0119	1.5893	1.829	1.701
3	1.9936	2.1807	1.829	2.0119	1.5893	1.829	1.701
4	1.9936	2.1807	1.6461	2.0119	1.4937	1.6461	1.701
5	1.7924	1.848	1.6461	1.7375	1.4937	1.5729	1.5364
6	1.5729	1.5893	1.4998	1.5181	1.46	1.4083	1.39
7	1.39	1.4784	1.3352	1.262	1.2936	1.4083	1.2437
8	1.3169	1.3306	1.2382	1.2437	1.3491	1.2071	1.2437
9	1.3535	1.3306	1.2197	1.2986	1.2567	1.2254	1.2437
10	1.4045	1.423	1.3169	1.3306	1.2803	1.1523	.9795
11	1.423		1.3535	1.3306	1.3256	1.262	.9795
12	1.4415		1.4083	1.4045	1.3352	1.2437	1.0719
13	1.6263	1.848	1.5181	1.386	1.3717	1.2437	1.2752
14	1.5893	1.7002	1.5546	1.4045	1.3535	1.262	1.1827
15	1.6263	1.6632	1.5729	1.419	1.4083	1.2254	1.2012
16	1.6078	1.5708	1.5181	1.5154	1.4266	1.1706	1.2197
17	1.5339	1.3676	1.5181	1.4969	1.3169	1.2071	1.1827
18	1.5339	1.4784	1.4815	1.3676	1.419	1.3352	1.2567
19	1.9774	1.8656	1.8839	1.8665	1.39	1.6461	1.6448
20	2.2916	2.1253	2.2314	1.9404	1.9387	1.829	1.7741
21	2.2546	2.1437	2.1948	1.9589	1.9022	1.7558	1.7372
22	2.3285	2.2361	2.1948	1.9774	1.9204	1.829	1.7556
23	2.2916	2.1622	2.2131	1.9404	1.9204	1.7375	1.6817
24	1.9936	2.1807	2.0302	2.0851	1.848	1.829	1.701
Max	2.3285	2.2361	2.2314	2.0851	1.9387	1.829	1.7741
Min	1.3169	1.3306	1.2197	1.2437	1.2567	1.1523	.9795
Avg	1.7635	1.8211	1.6693	1.6471	1.5113	1.4868	1.4210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 202 / 11 KV PORLA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.1088	.8779	1.1888	.924	1.0608	1.0791
2	.9145	1.1088	.8779	1.1888	.924	1.0608	1.0791
3	.9145	1.1203	.8779	1.1888	.924	1.0608	1.0791
4	.9145	1.1088	.8962	1.1888	.8402	1.0608	1.0791
5	.8413	1.0164	.8962	1.1523	.8316	1.0242	1.0059
6	.7865	.8871	.9328	1.0608	.8501	.9145	.9694
7	.7316	.924	1.0059	.9511	.7762	.8402	.8596
8	.9511	1.0534	1.1458	.8596	.8686	.8962	.9694
9	.9511	1.1273	1.2012	1.134	.8871	.9145	1.0242
10	1.0349	1.2012	1.1523	1.0534	.9145	.9694	.9979
11	1.0164	.9425	.3658	1.0349	.8048	1.0059	.924
12	1.0349	.9877	1.0242	1.0534	.8596	.9694	.961
13	1.1273	1.0534	1.134	.9979	.9145	.9145	.924
14	1.0903	1.1458	1.0974	1.0719	.9145	.9877	.9055
15	1.0903	1.1888	1.1888	1.1458	.9328	.7133	.9055
16	1.1273		1.1523	1.0903	.6767	.9511	.9425
17	1.0164	.924	.8779	1.0719	.6036	.9328	.8501
18	1.0164	.9425	1.0242	.9795	.8589	.9145	.7499
19	1.2012	1.2437	1.2437	.961	.823	1.134	1.0534
20	1.3676	1.423	1.4083	1.1088	1.2803	1.2803	1.1458
21	1.3306	1.3121	1.3717	1.1458	1.2254	1.2803	1.1458
22	1.2197	1.1827	1.3169	1.0164	1.2254	1.1523	1.0719
23	1.1273	1.1203	1.2254	.9979	1.0974	1.0974	.9979
24	.9145	1.1088	1.0974	1.1888	.9795	1.0608	1.0791
Max	1.3676	1.423	1.4083	1.1888	1.2803	1.2803	1.1458
Min	.7316	.8871	.3658	.8596	.6036	.7133	.7499
Avg	1.0264	1.0970	1.0580	1.0763	.9140	1.0082	.9916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 203 / 11 KV BODHALI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3326	.2402	.3475	.1848	.2926	.2926
2	.3475	.3326	.2402	.3475	.1848	.2926	.2926
3	.3475	.3361	.2587	.3475	.1848	.2926	.2926
4	.3109	.3361	.2561	.3475	.2033	.2926	.2926
5	.3109	.2772	.2587	.3109	.2033	.2926	.2926
6	.2561	.2033	.2743	.2195	.2033	.2195	.2743
7	.2195	.2402	1.0059	.2012	.1848	.1829	.2195
8	.2561	.2402	.2957	.2561	.1829	.128	.2378
9	.2926	.2772	.3142	.3109	.1848	.2012	.2378
10	.2587	.2743	.2743	.2218	.1463	.2195	.1848
11	.2587	.2772	.2012	.2587	.128	.1829	.1463
12	.2772	.2561	.2378	.2587	.1463	.2012	.1829
13	.2587	.2378	.2561	.2402	.0183	.1829	.2033
14	.2587	.2218	.2561	.2402	.1829	.1829	.1478
15	.3326	.2402	.2378	.2402	.1829	.1829	.1478
16	.3511	.3109	.2743	.2587	.1829	.1829	.1663
17	.2957	.2218	.2378	.2402	.1829	.1829	.1463
18	.2957	.2587	.2378	.2195	.2054	.1829	.2033
19	.4251	.3658	.3658		.2012	.3109	.3511
20	.4805	.4251	.439		.3841	.3658	.3881
21	.4435	.4066	.4207	.2561	.3658	.3658	.3696
22	.3881	.3696	.3841	.2926	.3658	.3475	.3326
23	.3511	.3326	.3658	.2926	.3109	.2926	.3142
24	.3475	.3326	.3326	.3475	.2772	.2926	.2926
Max	.4805	.4251	1.0059	.3475	.3841	.3658	.3881
Min	.2195	.2033	.2012	.2012	.0183	.128	.1463
Avg	.3213	.2961	.3194	.2753	.2082	.2446	.2504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 204 / 11 KV YEOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.7762	.5487	.7682	.7392	.7682	.823
2	.6767	.7762	.5487	.7682	.7392	.7682	.823
3	.6767	.7762	.5487	.7682	.7392	.7682	.823
4	.6767	.7762	.4755	.7682	.6468	.7682	.823
5	.6036	.7392	.4755	.7682	.6468	.7682	.823
6	.567	.6653	.4938	.6401	.7023	.695	.7316
7	.5304	.6722	.4755	.6401	.6283	.695	.6219
8	.2743	.7023	.1478	.695	.7023	.6584	.7682
9	.5304	.7392	.6653	.6219	.6838	.7682	.8779
10	.6838	.6468	.6219	.6838	.5853	.7682	.8962
11	.6283	.6838	.6219	.6584	.5853	.7682	.7207
12	.6283	.7316	.7682	.6468	.7316	.7865	.7577
13	.6653	.6653	.8413	.6653	.7682	.7499	.7577
14	.6283	.7023	.823	.7023	.7316	.7865	.5914
15	.5729	.7023	.8596	.5914	.6767	.8413	.5729
16	.6838	.6283	.7682	.6099	.6584	.8596	.567
17	.7023	.4805	.7865	.6653	.6036	.7316	.5175
18	.6468	.5175	.7316	.6838	.6584	.6767	.6468
19	.8501	.695	.9145	.7392	.8413	.9145	.8686
20	.961	.7947	1.0059	.9425		.9877	.8871
21	.9425	.7947	.9694	.961	.8962	.9511	.8871
22	.7577	.7023	.9145	.8501	.8962	.8962	.7865
23	.7762	.6468	.8413	.8131	.8962	.8413	.7392
24	.6767	.7762	.6401	.823	.8131	.7682	.823
Max	.961	.7947	1.0059	.961	.8962	.9877	.8962
Min	.2743	.4805	.1478	.5914	.5853	.6584	.5175
Avg	.6674	.6996	.6870	.7281	.7204	.7910	.7556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 205 / 11KV POST OFFICE SHEDDABLE URBAN
GADCHIROLI Feeder KV- 11 /
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.4415	1.0974	1.2071	1.0164	1.0608	1.0425
2	1.3717	1.4415	1.0974	1.2071	1.0164	1.0242	1.0425
3	1.3717	1.4415	1.0974	1.2071	1.0164	1.0242	1.0425
4	1.3717	1.4563	.9145	1.2071	.8962	1.0059	1.0425
5	1.262	1.2936	.9145	1.0791	.9979	.9511	.9511
6	1.0608	1.0534	.9511	.9328	.924	.8779	.8596
7	.9145	.924	.8316	.8048	.7947	.823	.8048
8	.8413	.8501	.7947	.7499	.7762	.7682	.7682
9	.8962	.8501	.7762	.7499	.7577	.7499	.8048
10	.9522	.8686	.8413	.7762	.7316	.7499	.7392
11	.8501	.8131	.8299	.7392	.7316	.7316	.7023
12	.8871	.8596	.7316	.7392	.7316	.695	.7023
13	.924	.8871	.7865	.7762	.7499	.6767	.6838
14	.9795	.4572	.8413	.7762	.695	.7133	.7023
15	.9795	.8871	.8413	.8131	.7499	.695	.6838
16	.9795	.8501	.8596	.7762	.7316	.695	.7023
17	.9425	.8316	.8413	.7577	.7316	.6767	.7207
18	.961	.8871	.8596	.8131	.8413	.7499	.7392
19	1.2012	1.0974	1.0242	1.0349	1.0059	.9328	.9055
20	1.386	1.2382	1.2254	1.0719	1.0608	1.0059	.9979
21	1.423	1.2936	1.2437	1.1643	1.1157	1.0242	1.0349
22	1.5154	1.3676	1.39	1.2012	1.1157	1.0608	1.0164
23	1.4969	1.3121	1.3535	1.1643	1.134	1.0791	.9979
24	1.3717	1.4415	1.2437	1.2437	1.1088	1.0608	1.0425
Max	1.5154	1.4563	1.39	1.2437	1.134	1.0791	1.0425
Min	.8413	.4572	.7316	.7392	.695	.6767	.6838
Avg	1.1380	1.0768	.9745	.9580	.8930	.8680	.8637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 206 / 11 KV GOKULNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.7468	.695	.7499	.5544	.6584	.6584
2	.6584	.7392	.695	.7499	.5544	.6584	.6584
3	.6584	.7392	.695	.7682	.5544	.6584	.6584
4	.6584	.7392	.5487	.7499	.5175	.6584	.6584
5	.6036	.6838	.5487	.695	.5175	.6036	.6036
6	.5487	.5914	.6036	.5853	.5729	.5487	.5487
7	.439	.5175	.4938	.4755	.462	.5487	.4755
8	.4207	.4251	.4435	.439	.4435	.4572	.439
9	.4572	.4251	.462	.4024	.4066	.4572	.4207
10	.4805	.4805	.567	.499	.4572	.439	.4435
11	.499	.4805	.5487	.499	.4755	.4755	.462
12	.5729	.5121	.5853		.5487	.5041	.4572
13	.5914	.5544	.6401	.5729	.5601	.5121	.5175
14	.6099		.6219	.5544	.4755	.5487	.5175
15	.6283		.6219	.5175	.5487	.567	.5175
16	.6099		.0549	.5914	.5487	.5121	.5544
17	.6099	.1478	.5853	.5544	.4938	.5121	.5175
18	.5914	.5914	.6401	.5914	.6036	.5853	.5121
19	.7947	.7316	.8048	.7577	.7316	.7316	.7023
20	.8316	.8131	.8413	.7762	.7316	.7316	.7207
21	.7762	.7947	.823	.7499	.7316	.695	.7023
22	.7577	.7947	.823	.7023	.7316	.6767	.6468
23	.7392	.7577	.8048	.7023	.7316	.6767	.6283
24	.6584	.7392	.7499	.7682	.6838	.6584	.6584
Max	.8316	.8131	.8413	.7762	.7316	.7316	.7207
Min	.4207	.1478	.0549	.4024	.4066	.439	.4207
Avg	.6189	.6193	.6207	.6283	.5682	.5865	.5700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 209 / 11 KV HOSPITAL EXPRESS

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	.128	.128	.128	.1109	.128	.1097
2	.128	.112	.128	.1294	.112	.128	.1097
3	.128	.128	.1294	.1294	.1109	.128	.1097
4	.128	.1294	.128	.1294	.1109	.128	.1097
5	.128	.112	.128	.1097	.112	.1097	.1097
6	.128	.1097	.128	.1097	.1109	.9511	.1097
7	.1294	.1109	.128	.128	.128	.0914	.1097
8	.1097	.1294	.1097	.1097	.1097	.0914	.1097
9	.128	.1663	.1646	.1646	.1478	.128	.128
10	.1829	.1867	.1829	.2012	.1867	.128	.1663
11	.2195	.1867	.2195	.1829	.1867	.128	.1646
12	.1829	.1867	.2195	.2195	.1867	.1097	.1848
13	.2033	.2195	.2195	.2012		.1097	.1829
14	.1829	.2378	.2195	.1646	.1829	.1097	.1663
15	.2033	.1848	.2195	.1646	.1646	.128	.1478
16	.1829	.2033	.2012	.1829	.1646	.0914	.1463
17	.1848	.2218	.1646	.1848	.1463	.0914	.1478
18	.128	.1646	.1294	.1646	.128	.1097	.1463
19	.1646	.1463	.1294	.1848	.1463	.128	.1294
20	.128	.1463	.1478	.1463	.1463	.1097	.1294
21	.1463	.128	.1463	.1294	.128	.1097	.1294
22	.1463	.1294	.128	.1294	.128	.128	.1294
23	.1463	.128	.128	.1109	.128	.1097	.128
24	.128	.128	.128	.1294	.1109	.128	.1097
Max	.2195	.2378	.2195	.2195	.1867	.9511	.1848
Min	.1097	.1097	.1097	.1097	.1097	.0914	.1097
Avg	.1527	.1552	.1565	.1514	.1386	.1501	.1339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 210 / 11 KV PWW EXPRESS

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1848	.1829	.1829	.1848	.1829	.1829
2	.1829	.1848	.1829	.1829	.1848	.1829	.1829
3	.1829	.1848	.1829	.1829	.1848	.1829	.1829
4	.1829	.1848	.1829	.1646	.1867	.1829	.1646
5	.1829	.1848	.1829	.1829	.1848	.1829	.1829
6	.1829	.1663	.1829	.1829	.1663	.1646	.1646
7	.128	.1663	.1097	.128	.1109	.1646	.1097
8	.0183	.0185	.0366	.0183	.0183	.0183	.0183
9	.0366	.0924	.0914	.0732	.0739	.0183	.0914
10	.0185	.0549	.0914	.1109	.0914	.1097	.0924
11	.0924	.1848	.1829	.1848	.2012	.0914	.1848
12	.1848	.2012	.2012	.2033	.2075	.2012	.1848
13	.2033	.2195	.2012	.2033	.2378	.1829	.1848
14	.1848	.1646	.1829	.0739	.1867	.2378	.1848
15	.1663	.1646	.1829	.0554	.1829	.1829	.2033
16	.1848	.1646	.1829	.1848	.1829	.1829	.1663
17	.1848	.1663	.1646	.1848	.1829	.1829	.1646
18	.1848	.1663	.1646	.1646	.1646	.1646	.1646
19	.0185	.0183	.0183	.0185	.0183	.0732	.1109
20	.0739	.0183	.0183	.0183	.0183	.0183	.0185
21	.0739	.0549	.0732	.0739	.0732	.0732	.0732
22	.1848	.1829	.1829	.1848	.0732	.0732	.1848
23	.1848	.1848	.1829	.1867	.1829	.2012	.1848
24	.1829	.1848	.1829	.1829	.1848	.1829	.2012
Max	.2033	.2195	.2012	.2033	.2378	.2378	.2033
Min	.0183	.0183	.0183	.0183	.0183	.0183	.0183
Avg	.1418	.1458	.1478	.1387	.1452	.1433	.1493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 401 / 33 KV GADCHIROLI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.834	9.3141	7.7063	8.6146	7.3183	8.626	8.2305
2	8.834	9.3141	7.7063	8.6146	7.3183	8.626	8.2305
3	8.834	9.3141	7.7063	8.6146	7.3183	8.626	8.2305
4	8.834	9.3141	7.2628	8.6146	6.5421	8.626	8.2305
5	8.1756	8.3162	7.2628	8.3951	6.5421	8.0659	7.7366
6	7.2428	7.0965	7.2628	7.2977	6.9856	6.9456	7.1331
7	6.0905	6.9302	6.3855	6.4198	6.2649	6.5535	6.31
8	5.7065	6.4312	5.7659	6.2003	5.9322	5.8253	6.6392
9	6.31	6.5421	6.5421	6.749	5.7105	6.0905	6.6392
10	6.4866	6.8193	6.3649	6.5421	5.6013	6.0905	5.9322
11	6.3203	5.1006	5.8711	6.4312	5.8253	5.7613	5.7659
12	6.5421	5.3772	6.9136	6.154	6.2243	5.8711	5.8768
13	6.9856	7.1519	7.2977	6.5975	6.1614	5.7065	5.9877
14	6.653	5.9877	7.3525	6.653	6.2734	6.0357	5.8213
15	7.2074	6.653	7.6269	6.5421	6.4415	5.8162	5.7659
16	7.2628	5.3224	7.5172	6.7638	6.1054	5.8162	5.9322
17	7.0965	5.8213	6.7776	6.653	5.8253	5.7693	5.655
18	7.2074	6.3758	7.2257	6.9302	6.8336	6.6095	6.0985
19	8.5934	8.9621	9.0181	8.3162	9.2981	8.3951	8.3716
20	10.6424	9.9794	10.4744	7.8727	9.8583	9.5222	9.1478
21	10.7545	10.3121	10.6985	9.3141	9.5782	9.4662	9.1478
22	10.2012	9.9794	10.096	8.7597	9.5782	8.9986	8.6488
23	9.8131	9.425	9.7668	8.538	9.1301	8.4499	8.0944
24	8.834	9.3141	9.0924	9.1632	8.1499	8.626	8.2853
Max	10.7545	10.3121	10.6985	9.3141	9.8583	9.5222	9.1478
Min	5.7065	5.1006	5.7659	6.154	5.6013	5.7065	5.655
Avg	7.8942	7.7147	7.7373	7.5313	7.1174	7.2883	7.1630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 402 / 33 KV GATTA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3326	.2743	.2743	.2772	.2801	.2743
2	.3292	.3361	.2772	.2743	.3361	.2801	.2743
3	.3292	.3326	.2743	.2743	.2772	.2801	.2743
4	.3292	.3361	.2772	.2743	.2772	.2801	.2743
5	.3292	.3361	.2772	.2743	.2772	.3361	.2743
6	.2743	.2772	.2743	.2743	.3326	.2801	.2743
7	.2743	.2772	.2801	.2195	.2772	.2801	.2743
8	.2195	.2218	.2218	.2195	.2743	.2241	.2195
9	.2195	.2218	.2218	.2195	.2218	.2241	.2195
10	.2218	.2218	.2195	.2195	.056	.2195	.1663
11	.2218	.2218	.1646	.1646	.056	.2195	.168
12	.1663	.2241	.2195	.1646	.0566	.1097	.1663
13	.0554	.2195	.2195	.1663	.112	.1646	.1646
14	.0554	.1646	.2195	.1663	.112	.2195	.1663
15	.0554	.2195	.2195	.1663	.2241	.2195	.1663
16	.0554	.2263	.2195	.1646	.2241	.2195	.1646
17	.2218	.2195	.168	.2218	.2241	.168	.1646
18	.2218	.2218	.2241	.2218	.2801	.2241	.2195
19	.3326	.3361	.2801	.3326	.3361	.2801	.3326
20	.3881	.3292	.4481	.3326	.4481	.3361	.4435
21	.4435	.439	.3921	.2743	.3921	.3292	.3841
22	.3881	.3881	.3292	.2772	.3921	.3292	.3326
23	.3326	.3292	.3292	.2743	.2801	.2743	.3326
24	.3292	.3326	.3292	.2743	.2218	.2801	.2743
Max	.4435	.439	.4481	.3326	.4481	.3361	.4435
Min	.0554	.1646	.1646	.1646	.056	.1097	.1646
Avg	.2551	.2819	.2650	.2386	.2486	.2524	.2502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 403 / 33 KV DHANORA FEEDER
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9753	1.885	1.5524	1.9204	1.5524	1.9044	1.8107
2	1.9753	1.9044	1.5524	1.9204	1.9044	1.9044	1.8107
3	1.9753	1.885	1.5524	1.9204	1.5524	1.9044	1.8107
4	1.9753	1.885	1.6632	1.9204	1.386	1.9044	1.8107
5	1.8107	1.6804	1.6632	1.8656	1.6804	1.7924	1.701
6	1.6461	1.3306	1.6632	1.6461	1.4969	1.4563	1.5912
7	1.1523	1.4415	1.2449	1.4815	1.4563	1.2323	1.4266
8	1.1523	1.3306	1.2197	1.4815	1.1088	1.1203	1.4815
9	1.3169	1.2197	1.2752	1.5912	.9979	1.2323	1.4266
10	1.1088	1.3306	1.0974	1.3306	.8962	1.1523	1.1088
11	.9979	1.1643	1.3169	1.262	1.1203	.7682	1.2197
12	1.0534	1.1763	1.3717	1.3306	1.1203	.9328	1.0974
13	1.2197	1.0974	1.3717	1.2752	1.1203	.8779	.9979
14	1.386	1.0974	1.4266	1.3306	1.2323	.9328	1.1763
15	1.4415	1.2752	1.5912	1.3306	1.1203	.9328	1.1088
16	1.3306	1.2752	1.5364	1.2752	1.0082	.823	1.1643
17	1.3306	1.1643	1.2071	1.2197	1.0974	.8962	1.1523
18	1.4969	1.4415	1.4563	1.5524	1.4563	1.4563	1.3169
19	1.386	2.0165	1.9044	2.1399	2.4646	2.0165	2.0513
20	2.3285	2.3285	2.2405	1.2197	2.4646	2.4646	2.3285
21	2.4394	2.6057	2.5766	2.2177	2.2405	2.4646	2.3285
22	2.2177	2.3285	2.1399	1.885	2.2405	2.1948	2.1622
23	2.0513	2.1622	2.0851	1.8296	1.9044	1.9204	1.885
24	1.9753	1.885	1.9959	1.9204	1.7741	1.9044	1.8107
Max	2.4394	2.6057	2.5766	2.2177	2.4646	2.4646	2.3285
Min	.9979	1.0974	1.0974	1.2197	.8962	.7682	.9979
Avg	1.6143	1.6213	1.6127	1.6194	1.5165	1.5079	1.5741

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 105004 / 33/11 KV GADCHIROLI

Feeder No / Name : 404 / 33 KV SAWELA

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2241	.2195	.2195	.1663	.112	.2743
2	.2743	.2218	.2195	.2195	.1663	.112	.2195
3	.2743	.2218	.2218	.2195	.1663	.112	.2195
4	.2743	.2241	.2218	.2195	.1663	.112	.2195
5	.2743	.1663	.2218	.2195	.1663	.168	.2195
6	.2195	.1663	.2218	.1097	.1663	.2241	.2195
7	.1646	.1663	.168	.1097	.1663	.2241	.1646
8	.1097	.1663	.1646	.1097	.1097	.168	.1646
9	.1646	.1109	.1646	.1646	.1109	.168	.1646
10	.1663	.1109	.1646	.1097	.112	.1646	.1646
11	.1109	.1097	.1097	.1109	.112	.1097	.1097
12	.1109	.112	.1097	.1097	.168	.1097	.1097
13	.1109	.1097	.1097	.1097	.112	.1097	.1097
14	.1109	.1097	.1097	.1097	.112	.1097	.1109
15	.1109	.1097	.1097	.1109	.168	.1097	.1097
16	.1109	.1109	.1097	.1097	.168	.1097	.1097
17	.1109	.1109	.112	.1097	.168	.112	.1097
18	.1663	.1663	.168	.1663	.168	.112	.1097
19	.2218	.3361	.2801	.2772	.2801	.2801	.2218
20	.3326	.3292	.3361	.3326	.3361	.2801	.2772
21	.3326	.3841	.3361	.3292	.3361	.2801	.3326
22	.2772	.3292	.2743	.2743	.3361	.2743	.2218
23	.2218	.2772	.2743	.2218	.2241	.2195	.2218
24	.2743	.2218	.2743	.2195	.1663	.112	.2743
Max	.3326	.3841	.3361	.3326	.3361	.2801	.3326
Min	.1097	.1097	.1097	.1097	.1097	.1097	.1097
Avg	.2000	.1915	.1959	.1788	.1813	.1622	.1858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 400 / S/Stn T/F

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.5601
Max	.5601
Min	.5601
Avg	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 401 / 33kV Gadchiroli

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)
12	5.3772	5.9808
16	6.5975	6.4072
Max	6.5975	6.4072
Min	5.3772	5.9808
Avg	5.9874	6.194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 402 / 33KV Armori

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	5.647	6.4506	7.1519	7.4846	5.9728	6.9633	7.2977
8	5.0497	5.2669	6.653	3.0178	6.2003	6.8587	8.011
12	5.4841	9.4805	6.9136	6.19	5.7065	7.276	4.8354
16	5.4321		15.096	4.2981	6.0431	6.8959	5.3498
20	7.0731	8.4499	19.2445	7.3303	9.1478	9.2033	6.3272
24	6.3649	4.1993	7.572	5.2126	6.6392	7.5172	7.5217
Max	7.0731	9.4805	19.2445	7.4846	9.1478	9.2033	8.011
Min	5.0497	4.1993	6.653	3.0178	5.7065	6.8587	4.8354
Avg	5.8418	6.7694	10.4385	5.5889	6.6183	7.4524	6.5571

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 403 / 33kV Kotgal Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.0953	2.6337	2.552	2.6057	2.0851	2.4143	2.1948
8	1.8656	2.0633	1.8656	1.7375	1.7918	1.4118	1.7924
12	2.1719	1.9547	2.3594	2.0953	2.2497	1.8461	1.6461
16	2.2805	2.0851	4.6777	2.1399	1.885	1.8107	1.6461
20	2.8475	2.8292	5.9534	2.5789	2.6886	2.2177	2.3663
24	2.4977	2.7692	2.8532	3.1276	2.4691	2.524	2.4143
Max	2.8475	2.8292	5.9534	3.1276	2.6886	2.524	2.4143
Min	1.8656	1.9547	1.8656	1.7375	1.7918	1.4118	1.6461
Avg	2.2931	2.3892	3.3769	2.3808	2.1949	2.0374	2.01

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 404 / 33 KV AMIRZA FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.4344	.6516	.5973	.6036	.4835	.439	.5487
8	.5487	.4298	.5316	.543	.4344	.463	.4887
9							.6099
12	.4115	.4344	.4344	.439	.1663	.3841	.3601
16	.4207	.4344	.3086	.4887	.3292	.3841	.2572
17		.439					
20	.7682	.7059	.7802	.543	.7059	.7842	.6687
24	.6036	.6036	.6516	.5258	.6036	.4835	.5973
Max	.7682	.7059	.7802	.6036	.7059	.7842	.6687
Min	.4115	.4298	.3086	.439	.1663	.3841	.2572
Avg	.5312	.5284	.5506	.5239	.4538	.4897	.5044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

GADCHIROLI S/DN.[338] BU 4338

Substation No/ Name :- 108007 / 220 MIDC-EHV Sub-station

Feeder No / Name : 405 / 33 KV VYAHAD FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	3.4568	4.4353	4.4993	4.4993	4.1152		4.3347
8	3.6763	3.8958	3.9638	3.8009	3.1824		3.9506
12	4.0604	3.9638	4.1152	2.1399	3.1824		3.3436
16	3.5294	3.8958	2.4177	2.1399	3.8552	4.3347	1.0288
20	5.487	5.5418	4.8868	2.5789	5.156	4.7817	4.5782
23				3.1893			
24	4.0724	4.7737	4.6696	4.6639	4.6153	4.6091	4.3439
Max	5.487	5.5418	4.8868	4.6639	5.156	4.7817	4.5782
Min	3.4568	3.8958	2.4177	2.1399	3.1824	4.3347	1.0288
Avg	4.0471	4.4177	4.0921	3.2874	4.0178	4.5752	3.5966

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KORCHI S/DN.[826]

BU 4826

Substation No/ Name :- 104006 / 33/11 KV SUBSTATION KORCHI

Feeder No / Name : 201 / 11 KV KORCHI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4715	.5093	.4715	.4527	.4904	.4904
2	.4904	.4715	.5093	.4715	.4527	.4904	.4715
3	.4904	.4715	.5093	.4715	.4527	.4904	.4715
4	.4904	.4715	.5093	.4715	.4527	.4904	.4715
5	.4904	.4715	.5093	.4904	.4715	.4715	.4715
6	.4338	.415	.4527	.4527	.4527	.4715	.4527
7	.415	.415	.3961	.415	.3961	.4338	.3961
8	.3772	.3772	.3961	.3584	.3395	.394	.3772
9	.3734	.3395	.3772	.3584	.3403	.3439	.3584
10	.2641	.2402	.362	.3206	.2896	.3475	.3395
11	.3361	.2587	.3439	.2865	.2926	.2957	.3018
12	.2801	.2801	.3475	.2896		.3734	.3018
13	.2987	.2987	.3292	.2743		.3395	.2829
14	.3174	.2987	.3511	.2686	.3326	.2452	.2829
15	.3174	.3174	.2686	.2896	.3224	.3206	.2829
16	.3174	.3361	.2715	.2561	.3258	.3206	.2829
17	.3361	.2829	.2715	.2957	.3658	.3206	.3206
18	.3841	.3547	.2987	.3361	.3547	.3584	.3584
19	.5281	.5487	.5281	.4904	.3772	.547	.5093
20	.6413		.6602	.6224	.6036	.5847	.547
21	.6224		.6036	.547	.5847	.5658	.5281
22	.5847		.5658	.5093	.547	.5281	.5093
23	.5093		.5281	.4904	.5281	.4904	.5093
24	.5093	.4715		.4904	.4715	.5093	.4904
Max	.6413	.5487	.6602	.6224	.6036	.5847	.547
Min	.2641	.2402	.2686	.2561	.2896	.2452	.2829
Avg	.4291	.3796	.4304	.4053	.4185	.4260	.4087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KORCHI S/DN.[826]

BU 4826

Substation No/ Name :- 104006 / 33/11 KV SUBSTATION KORCHI

Feeder No / Name : 202 / 11 KV KOTARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3206	.3206	.3584	.3206	.3584	.3395
2	.3206	.3206	.3206	.3584		.3584	.3395
3	.3206	.3206	.3206	.3584		.3584	.3395
4	.3206	.3206	.3206	.3584		.3584	.3395
5	.3206	.3206	.3206	.3772		.3395	.3395
6	.3206	.3018	.3018	.3395	.3206	.3395	.3395
7	.2829	.2829	.3018	.2829	.3018	.3584	.3206
8	.1886	.2452	.2641	.2452	.2328	.2686	.3018
9	.168	.2075	.2328	.2263	.2353	.2534	.2829
10	.1132	.1848	.2172	.2075	.1109	.2378	.2075
11	.112	.1848	.2172	.197	.2378	.2033	.2641
12	.112	.1867	.2195	.1991		.168	.2263
13	.112	.1867	.2033	.1829	.197	.1886	.2263
14	.2054	.1867	.1991	.1791	.2218	.2075	.2075
15	.1867	.168	.197	.1991	.1254	.1886	.1132
16	.1867	.1867	.2012	.1829	.1448	.2263	.132
17	.1867	.181	.2218	.1848	.1478	.2075	.1509
18	.2195	.2195	.2427	.2614	.2054	.2452	.1698
19	.3395	.3547	.3772	.3584	.3772	.3772	.2829
20	.415		.4715	.415	.4338	.415	.3206
21	.3772		.4527	.3961	.3961	.3772	.3018
22	.3772		.415	.3584	.3772	.3772	.2829
23	.3206		.3961	.3395	.3772	.3395	.2829
24	.3395	.3206		.3772	.3206	.3584	.3395
Max	.415	.3547	.4715	.415	.4338	.415	.3395
Min	.112	.168	.197	.1791	.1109	.168	.1132
Avg	.2569	.2500	.2928	.2893	.2676	.2963	.2688

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KORCHI S/DN.[826]

BU 4826

Substation No/ Name :- 104006 / 33/11 KV SUBSTATION KORCHI

Feeder No / Name : 203 / 11 KV BETHKATHI FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.3584	.3772	.415	.3584	.3961	.3772
2	.4715	.3584	.3584	.415	.3584	.3961	.3772
3	.4715	.3584	.3584	.415	.3584	.3961	.3772
4	.4715	.3584	.3584	.415	.3584	.3961	.3772
5	.4715	.3584	.3584	.4338	.3772	.415	.3772
6	.415	.3395	.3395	.415	.415	.415	.3772
7	.3772	.3206	.3018	.3961	.3961	.415	.3772
8	.3772	.3018	.3403	.3961	.3761	.3403	.3395
9	.3547	.2829	.3961	.3772	.362	.3439	.3584
10	.3395	.2587	.362	.3584	.3475	.3658	.3395
11	.0747	.2957	.3658	.3403	.3511	.3326	.3395
12	.2801	.2987	.3772	.3439		.3361	.3018
13	.2614	.3174	.3439	.0366	.3439	.3395	.3018
14	.2427	.3361	.3582	.3224	.3511	.3584	.3018
15	.2614	.3361	.3582	.3439	.3045	.3206	.3018
16	.3361	.3174	.3658		.2896	.3206	.3206
17	.2987	.3045	.3881	.037	.3292	.3018	.3584
18	.3109	.3077	.3734	.112	.3361	.3395	.3584
19	.4904	.439	.5093	.4904	.4715	.4338	.4338
20	.5658		.547	.4904	.5281	.4904	.4715
21	.4904			.4904	.5093	.4338	.4527
22	.4527		.4715	.3961	.4338	.415	.415
23	.3961		.4527	.3772	.4338	.3772	.3961
24	.4715	.3584		.4338	.3584	.415	.3772
Max	.5658	.439	.547	.4904	.5281	.4904	.4715
Min	.0747	.2587	.3018	.0366	.2896	.3018	.3018
Avg	.3814	.3303	.3846	.3587	.3803	.3789	.3670

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 201 / 11 KV KADHOLI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	1.2136	1.2254	1.3717	.8215	.9709	.9877
2	.8215	1.1949	1.2437	1.3717	.7842	.9149	.9877
3	.8029	1.1949	1.2437	1.3717	.7842	.9149	.9694
4	.8029	1.1949	1.2803	1.3717	.8029	.8962	.9694
5	.8029	1.1763	1.2803	1.4083	.8215	.8962	.9511
6	.8775	1.2323	1.3352	1.4083	.8775	.8775	.9511
7	1.0269	.9335	1.4632	1.4815	.8589	.9335	.567
8	1.0456	1.251	1.4266	1.4449	.9709	1.0269	
9	1.0269		1.4449	1.39	.9709	1.0269	
10			1.3169	1.39	.9522	.9709	
11	.9709		1.4266	1.262	.9896	.9335	.7682
12	.9896		1.3352	1.1949	1.0269	.7316	.8779
13			1.39	1.307	.9709	.695	1.0059
14	.7842		1.4083	1.0082	.8589	.823	.9511
15	1.0456		1.2803	.9709	.8402	.9145	.8962
16	1.0269	1.134	1.39	.9522	.9709	.9328	.9145
17	1.0269	1.3352	1.3169	.8589	.8589	.8048	.8962
18	1.0082	1.1706	1.2382	.8962	.8775	.9694	.8962
19	1.1016	1.5364	1.6263	.9522	.9709	1.134	.9896
20	1.251	1.5181	1.7002	1.1203	1.1763	1.1888	1.2567
21	1.531	1.4815		1.0829	1.1203	1.0974	1.2197
22	1.419		1.4083	.9709	.9896	1.0608	1.1088
23	1.3256	1.3352	1.4083		.9709	1.0425	.5544
24	.8215	1.2136	1.2254	1.2803	.8215	.9709	.9877
Max	1.531	1.5364	1.7002	1.4815	1.1763	1.1888	1.2567
Min	.7842	.9335	1.2254	.8589	.7842	.695	.5544
Avg	1.0150	1.2573	1.3658	1.2116	.9203	.9470	.9384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 202 / 11 KV GEWARDHA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.384	2.0144	2.1132	2.1948	1.7741	1.7741	1.8604
2	2.384	1.9774	2.0774	2.1948	1.7556	1.7741	1.8604
3	2.3655	1.9774	2.0774	2.1948	1.7372	1.7556	1.8427
4	2.347	1.848	2.0774	2.1948	1.7372	1.7372	1.8427
5	2.3655	1.8296	2.1132	2.1948	1.7372	1.7741	1.8427
6	2.4025	1.8665	2.2386	2.1948	1.7556	1.7926	1.8959
7	2.4394	1.8665	2.1491	2.2862	1.7556	1.7556	1.9136
8	2.5133	2.0144	2.0416	2.4874	1.7002	1.8296	
9	2.6057		1.97	1.5684	1.7556	1.7741	
10			2.1312	2.1948	1.7741	1.7372	
11	2.2731		1.8804	2.1262	1.7556	1.6817	1.4685
12	2.2546		1.8625	2.1437	1.7926	1.56	1.4352
13			1.8804	2.1437	1.6448	1.7364	1.4175
14	2.4394		1.8446	1.9774		1.6478	1.4352
15	1.8665		2.0485	1.9589	1.0349	1.6478	1.3466
16	1.9404		1.9418	1.9035	.6283	1.7541	1.382
17	1.7372	1.8625		1.7187	.961	1.7364	1.4175
18	2.0351	1.97		1.7002	1.6448	1.8461	1.4529
19	2.1992	2.167	2.2497	1.7372	1.922	1.9547	1.6478
20	2.384	2.4177	2.5423	1.8665	2.0328	2.0908	.124
21	2.347		2.3891	1.922	1.9774	2.0022	1.701
22		2.1491	2.3777	1.8111	1.9035	1.949	1.6124
23	2.0144	2.1132			1.7926	1.9136	1.5947
24	2.3655	2.0144	2.1357	2.2131	1.7741	1.7926	1.9387
Max	2.6057	2.4177	2.5423	2.4874	2.0328	2.0908	1.9387
Min	1.7372	1.8296	1.8446	1.5684	.6283	1.56	.124
Avg	2.2697	2.0059	2.1020	2.0403	1.6673	1.7924	1.5730

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 203 / 11 KV TALEGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987		.3292	.2926	.3174	.2987	.3109
2	.2987		.3109	.2926	.2987	.2987	.2926
3	.2801		.3109	.2926	.2801	.2801	.2926
4	.2801		.2926	.3109	.2987	.2614	.2926
5	.2987		.2926	.3109	.3174	.2987	.2926
6	.3547		.2801	.3292	.3361	.3174	.3109
7	.3921		.2926	.3292	.2987	.3547	.3109
8	.3174	.168	.2743	.3292	.3361	.3547	
9	.3361		.3109	.3109	.2987	.3361	
10			.2561	.2926	.2987	.3361	
11	.2801		.2378		.2614	.2987	.2743
12	.2241		.2378	.1867	.2614	.1829	.2561
13			.2378	.1867	.2614	.2378	.2195
14	.168		.2195	.1494	.2614	.2378	.2378
15	.1307		.2195	.1494	.2614	.2195	.2195
16	.2987		.2378	.1494	.2241	.2195	.2195
17	.3174	.2378	.2303	.2241	.2241	.2378	.2743
18	.3361	.2378	.2561	.2614	.2614	.2743	.8962
19	.3921	.3292	.3658	.3361	.3547	.3881	.3841
20	.4854		.3841	.3734	.3921	.3658	.3881
21	.4481	.4207	.439	.3734	.3361	.3475	.3696
22	.4294	.3841	.3658	.3361	.3361	.3292	.3142
23	.3547	.3292	.3109		.3174	.3292	.2957
24	.2987		.3292	.2926	.3174	.3174	.3292
Max	.4854	.4207	.439	.3734	.3921	.3881	.8962
Min	.1307	.168	.2195	.1494	.2241	.1829	.2195
Avg	.3191	.3010	.2926	.2777	.2980	.2968	.3229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342]

BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 204 / 11 KV KURKHEDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.7095	.7133	.695	.5975	.5975	.567
2	.6535	.6908	.7133	.6767	.5975	.5975	.567
3	.6535	.6535	.695	.6767	.5788	.5601	.5487
4	.6348	.6535	.695	.6584	.5788	.5601	.5487
5	.6348	.6348	.695	.6401	.5415	.5415	.5121
6	.5975	.6348	.7316	.6401	.5601	.5228	.5121
7	.5975	.5601	.823	.6219	.5601	.5041	.5121
8	.5601	.5788	.6036	.6219	.5228	.5415	.5853
9	.5788		.6584	.5121	.5228	.4854	
10		.6722	.5853	.6036	.5415	.5228	
11	.6348	.6535	.5853	.5853	.5601	.4854	.4938
12	.6161	.567	.6767	.4108	.5601	.4207	.5487
13			.6401	.4108	.5415	.4755	.4572
14	.6348		.6401	.5601	.5788	.4207	.439
15	.5975		.6767	.5601	.5415	.4755	.4755
16	.6161	.7133	.6584	.5228	.5041	.4755	.4938
17	.6535	.7316	.5853	.5975	.5041	.4572	.5121
18	.6161	.695	.6036	.5788	.4854	.5121	.5304
19	.7095	.7499	.6838	.6535	.5788	.567	.547
20	.7468	.7865	.7682	.6348	.6348	.5853	.5729
21	.7842	.7682	.7865	.6348	.6348	.5853	.5544
22	.8215	.7865	.8048	.6535	.6161	.5853	.5487
23	.7655	.7133	.7499		.6161	.5853	.5544
24	.6722	.7095	.7133	.7316	.6161	.5975	.567
Max	.8215	.7865	.823	.7316	.6348	.5975	.5853
Min	.5601	.5601	.5853	.4108	.4854	.4207	.439
Avg	.6569	.6831	.6869	.6035	.5656	.5276	.5295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 205 / 11KV PURADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.6241	.7964	.9593	.6241	.8322	.8688
2	.7282	.6241	.7964	.9412	.6068	.8149	.8507
3	.7108	.6068	.8048	.9412	.5895	.7975	.8507
4	.7108	.6068	.7964	.9412	.6241	.8149	.8326
5	.7628	.6241	.8048	.9412	.6762	.8322	.8145
6	.8322	.6415	.8048	.9955	.7628	.8495	.8507
7	.9362	.6935	.9328	1.0317	.7802	.8669	.823
8	.9362	.6762	.9593	1.0317	.7975	.8842	
9	.9362		.9774	1.0974	.8322	.8842	
10			.8869	1.0136	.7282	.8322	
11	.7455		.8326	.8869	.7628	.4681	.7964
12	.8322		.9774	.8669	.8322	.5068	.7865
13			.8869	.8322	.8149	.4706	.7602
14	.7802		.7059	.8322	.7802	.8145	.7602
15	.7975		.9412	.7455	.5201	.8507	.7783
16	.8669	.6697	1.0242	.7282	.5201	.8507	.7783
17	.8149	.7783	.6584	.6068	.5375	.7964	.7783
18	.8669	.8326	.9774	.6415	.7455	.7421	.823
19	.9709	.9955	1.134	.7628	.9189	.905	.9145
20	1.0923	1.0136		.8322	.9882	1.0136	.9145
21		.9955	1.0974	.8149	.9362	.9774	.8962
22	.8669	.9231	1.0791	.7628	.8669	.905	.8326
23	.7282		.9511		.8322	.8688	.8048
24	.7282	.6415		.9694	.6241	.8322	.8688
Max	1.0923	1.0136	1.134	1.0974	.9882	1.0136	.9145
Min	.7108	.6068	.6584	.6068	.5201	.4681	.7602
Avg	.8272	.7467	.9012	.8772	.7376	.8088	.8278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342]

BU 4342

Substation No/ Name :- 104005 / 33/11 KV KURKHEDA

Feeder No / Name : 206 / 11 KV Ghati Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3856	.788	.8097	.9391	.6371	.6706	.7087
2	.3856	.788	.8097	.9391	.6203	.6539	.7087
3	.3688	.7545	.7773	.9214	.6415	.6371	.691
4	.3688	.7377	.7773	.9214	.6036	.6371	.691
5	.4024	.7209	1.3765	.9391	.6203	.6539	.691
6	.4527	.7209	.8097	.9922	.6539	.6706	.7442
7	.503	.8215	.8421	1.0454	.6371	.7209	.7442
8	.4694	.8551	.7449	1.0808	.6706	.7545	
9	.4862		.5992	1.0059	.7712	.788	
10			.9555	.9745	.7545	.7377	
11	.4024		.8745	.9214	.6874	.6706	.6201
12	.4527		.8421	.8383	.7209	.6733	.6201
13			.8097	.8048	.6706	.7087	.5847
14	.4527			.7042	.6539	.7087	.6024
15	.3856		.7373	.7712	.6371	.7087	.5847
16		.6802	.8413	.5197	.6203	.7265	.5847
17	.3018	.8356	.7059	.5365	.6706	.7087	.7619
18	.3353	.8421	.9036	.6706	.6539	.691	.5847
19	.7545		1.0242	.6874	.7042	.7265	.6556
20		.9717	1.0985	.7377	.7545	.7973	.691
21	.8048	.8259		.7209	.7377	.7619	.6733
22	.788	.8421	1.0277	.6706	.7042	.7265	.9745
23	.8048	.8097	.9214		.6706	.7087	.6024
24	.3856	.8048	.8192	.9745	.6371	.6706	.7087
Max	.8048	.9717	1.3765	1.0808	.7712	.7973	.9745
Min	.3018	.6802	.5992	.5197	.6036	.6371	.5847
Avg	.4845	.7999	.8685	.8399	.6722	.7047	.6775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104008 / 33/11 KV MALEWADA

Feeder No / Name : 201 / 11 KV MALEWADA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.4338	.4715	.5228	.4024	.4527	.4481
2	.2987	.4338	.4715	.5228	.4024	.4338	.4481
3	.2987	.4338	.4715	.5228	.4066	.4338	.4481
4	.2987	.4338	.4904	.5228	.4066	.415	.4481
5	.2987	.415	.4904	.5228	.3841	.415	.4481
6	.3206	.415	.4527	.4854	.4066	.3961	.4108
7	.3734	.4338	.4904	.5228	.4024	.415	.4108
8	.4108	.4294	.4668	.4755	.3547	.415	.4481
9	.3734		.4715	.5228	.3961	.4108	
10			.6348	.5228	.4108	.4294	
11	.3921		.3734	.4938	.3734	.3734	.3658
12	.4108		.4108		.3696	.3547	.3841
13			.4108	.3881	.3734	.3734	.2957
14			.4294	.4066	.3361	.3547	.3696
15	.3395		.4108	.2926	.3174	.3696	.3475
16	.3361	.4066	.4108	.3658	.3361	.3142	.3658
17	.3921	.3734	.3734	.3439	.3361	.3174	.3511
18	.3961	.3734	.4481	.3696	.415	.3174	.3734
19		.6036	.5601	.5093	.5658	.4904	.4715
20	.5658	.6224	.6036	.547	.5847	.5281	.5093
21	.5847	.6224	.5658	.5281	.5093	.5228	.4904
22	.5093	.5847	.5658	.4338	.4715	.4854	.4338
23	.4527	.4904	.5281	.415	.4338	.4854	.4108
24	.3018	.4338	.4904	.5228	.415	.415	.4481
Max	.5847	.6224	.6348	.547	.5847	.5281	.5093
Min	.2987	.3734	.3734	.2926	.3174	.3142	.2957
Avg	.3826	.4670	.4789	.4678	.4087	.4133	.4149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104008 / 33/11 KV MALEWADA

Feeder No / Name : 202 / 11 KV ANGARA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1867	.1867	.2241	.1848	.2218	.2241
2	.1509	.1867	.1867	.2241	.1848	.2218	.2172
3	.1509	.1867	.1867	.2241	.1829	.2218	.2241
4	.1509	.1867	.1867	.2241	.1829	.2033	.2172
5	.1509	.1494	.1867	.2241	.1848	.2033	.2241
6	.1509	.1478	.1848	.1867	.1848	.2172	.2054
7	.1494	.1478	.2033	.2241	.1829	.2353	.2241
8	.1494	.1478	.2012	.1734	.1829	.2172	.1478
9	.1494		.1829	.2195	.197	.181	
10			.2241	.2195	.1791	.2149	
11	.1294		.1867	.1829	.2195	.2241	.1075
12	.0724		.1867	.1753	.1753	.2054	.1075
13			.1867	.1463	.1753	.2241	.1372
14			.1867	.1829	.1829	.2241	.1227
15	.1494		.1829	.1578	.181	.1867	.104
16		.181	.1829	.1214	.1772	.2195	.1052
17	.1448	.1829	.1829	.12	.1949	.2218	.1267
18	.1448	.128	.2218	.1886	.2149	.2218	.1829
19		.2614	.2614	.2402	.2957	.2641	.2427
20	.2641	.2987	.2614	.2263	.3174	.2641	.2427
21	.2452	.2801	.2452	.2263	.2587	.2614	.2427
22	.2075	.2427	.2263	.2054	.2402	.2427	.2033
23	.1886	.1867	.2263	.1867	.2195	.2241	.1848
24	.0943	.1886	.1867	.2263	.1867	.2195	.2241
Max	.2641	.2987	.2614	.2402	.3174	.2641	.2427
Min	.0724	.128	.1829	.12	.1753	.181	.104
Avg	.1576	.1935	.2023	.1971	.2036	.2225	.1826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104008 / 33/11 KV MALEWADA

Feeder No / Name : 203 / 11 KV SURSUNDI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.2263	.2241	.2454	.2263	.2614
2	.1886	.1886	.2263	.2241	.2401	.2263	.2614
3	.1886	.1886	.2263	.2241	.2454	.2263	.2614
4	.1886	.1886	.2263	.2241	.2454	.2054	.2614
5	.1886	.1886	.2263	.2241	.2195	.2054	.2241
6	.1886	.2075	.2075	.2241	.1715	.2427	.2054
7	.1867	.2218	.2263	.2241	.2058	.1886	.1886
8	.2054	.2218	.2587	.2218	.2254	.2263	.1494
9	.1886		.2402	.2402	.2454	.2241	
10			.2427	.2218	.1715	.2241	
11	.1698		.2241	.1829	.2195	.1867	.1494
12	.1307		.2241	.1663	.2715	.1867	.1478
13			.2054	.1646	.1463	.1867	.128
14	.1698		.2054	.1848	.1867	.2054	.1629
15	.168		.2241	.1267	.2926	.2012	.1463
16		.2195	.2241	.1715	.2561	.1663	.1663
17	.1494	.2241	.1867	.1448	.2195	.168	.1494
18		.2263	.2075	.1629	.1886	.168	.1698
19		.3206	.2641	.2835	.2641	.2641	.2452
20	.1524	.3584	.3395	.3121	.2829	.3018	.2452
21	.1886	.3395	.3018	.2715	.2641	.2987	.2452
22	.2075	.3018	.2829	.2915	.2452	.2614	.2241
23	.1886	.2452	.2452	.2401	.2263	.2614	.1886
24	.1886	.1698	.2263	.2427	.2743	.2263	.2614
Max	.2075	.3584	.3395	.3121	.2926	.3018	.2614
Min	.1307	.1698	.1867	.1267	.1463	.1663	.128
Avg	.1803	.2341	.2362	.2166	.2314	.2199	.2019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

KULKHEDA S/DN.[342] BU 4342

Substation No/ Name :- 104008 / 33/11 KV MALEWADA

Feeder No / Name : 401 / 33 kV MALEWADA I/C

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.8488	.9054	.9522	.9328	.9774	.9522
2	.679	.8488	.8962	.9522	.9328	.9774	.9522
3	.6722	.8488	.8962	.9522	.9425	.9231	.9522
4	.6722	.8488	.9054	.9522	.9425	.9231	.9522
5	.679	.7922	.9054	.9522	.9425	.9231	.9522
6	.679	.7842	.8488	.8871	.8316	.9231	.8402
7	.7282	.7842	.9425	.9522	.8779	.9425	.8402
8	.7842	.8402	.9425	.9568	.823	.9425	.7842
9	.7282		.9425	.9979	.8688	.9425	
10			1.0642	.9979	.9134	.9328	
11	.7282		.7842	.9328	.8145	.7842	.6447
12	.6161		.8402	.3721	.7888	.7842	.6984
13			.8402	.8145	.7362	.7842	.5973
14	.6722		.8402	.8688	.7682	.7762	.6984
15	.679		.8402	.6516	.7602	.7842	.6447
16		.8779	.8402	.7716	.7682	.7282	.7059
17	.7207	.7682	.7842	.6836	.7442	.7207	.7059
18	.5601	.7133	.9054	.7522	.8871	.7133	.7682
19		1.1763	1.1317	1.0425	1.1883	1.0751	1.0642
20	.9054	1.3014	1.2449	1.2071	1.2323	1.1317	1.0974
21	1.0751	1.2883	1.1317	1.2071	1.1763	1.1317	1.0642
22	1.0185	1.1763	1.0751	1.086	1.0082	1.0642	.9522
23	.8402	.9522	1.0082	.9328	.9522	1.0082	.8871
24	.7356	.8488	.8962	1.0082	.9231	.8962	.9522
Max	1.0751	1.3014	1.2449	1.2071	1.2323	1.1317	1.0974
Min	.5601	.7133	.7842	.3721	.7362	.7133	.5973
Avg	.7426	.9235	.9338	.9118	.9065	.9079	.8503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 201 / 11 KV WADSA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3152	2.6513	2.809	2.7633	2.8006	2.4272	2.1098
2	2.2779	2.6139	2.7721	2.6513	2.7633	2.4086	2.0936
3	2.2177	2.5579	2.7166	2.6139	2.6139	2.3899	2.0182
4	2.1845	2.5206	2.6427	2.5953	2.4272	2.3339	1.8671
5	2.1285	2.4459	2.6057	2.5766	2.3339	2.2405	1.7737
6	2.0911	2.3899	2.5503	2.3339	2.0911	2.1472	1.6804
7	1.8665	1.8473	1.922	1.5684	1.8671	1.8671	
8	1.7741	1.6263	1.6057	1.8858	1.5497	1.6617	
9	1.6448	1.7372	1.587	1.4969	1.46	1.5154	1.9791
10	1.6078	1.4045	1.9605	1.6817	1.7741	1.4415	1.5684
11	1.7187	1.46	1.9427	1.6817	1.9204	1.5339	1.531
12	1.7741	1.6263	1.9231	1.8656	2.0302	1.6448	1.587
13	1.9204		1.9616	1.9404	2.0668	1.4784	1.5497
14	1.7002		1.8858	1.9753	2.0668	1.5497	1.531
15	1.8296		1.9418	2.0748	1.7177	1.6057	1.4937
16	1.8484	2.32	1.9978	1.9993	1.7551	1.4937	1.5123
17	1.8671	2.037	1.9616	1.8671	1.8671	1.363	1.531
18	2.2405	2.0165	2.0182	1.8858	1.7737	1.643	1.5123
19	2.4272	2.3525	2.2965	2.3152	2.1658	1.9978	1.6817
20	2.6139	2.6699	2.5206	2.4272	2.3339	2.1472	1.829
21	2.782	2.8753	2.7073	2.5766	2.3899	2.3339	1.9753
22	2.8753	2.9313	2.838	2.5953	2.1262	2.1845	1.9022
23	2.7633	2.894	2.95		2.4086	2.1472	1.7926
24	2.4272	2.6886	2.8645	2.782	2.8193	2.4832	2.1098
Max	2.8753	2.9313	2.95	2.782	2.8193	2.4832	2.1098
Min	1.6078	1.4045	1.587	1.4969	1.46	1.363	1.4937
Avg	2.1207	2.2698	2.2909	2.1806	2.1301	1.9183	1.7559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 202 / 11 KV KONDHALA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.7187	1.7002	1.8858	1.643	1.6057	1.6804
2	1.3306	1.7002	1.6817	1.9231	1.6057	1.587	1.6617
3	1.3121	1.7002	1.6632	1.8858	1.587	1.587	1.643
4	1.3256	1.6817	1.6448	1.8298	1.531	1.5684	1.6057
5	1.307	1.6632	1.5893	1.8484	1.4937	1.531	1.5684
6	1.4045	1.6632	1.5893	1.8298	1.4377	1.4937	1.4937
7	1.6448	1.7741	1.8111	1.7551	1.4937	1.531	
8	1.6632	1.4784	1.9605	1.9044	1.419	1.5684	
9	1.7187	1.4784	2.0165	1.9022	1.3306	1.4415	
10	1.4969	1.5154	1.8673	1.829	1.5154	1.3491	1.1203
11	1.5154	1.423	1.9231		1.386	1.4045	1.1022
12	1.6263	.8316	1.587		1.423	1.363	1.1763
13	1.6632		1.6804	1.8107	1.4969	1.419	1.2136
14	1.7187		1.8111	1.7558	1.5524	1.4563	1.1949
15	1.6078		1.7737	2.0559	1.5497	1.5123	1.1949
16	1.848	.9709	1.7364	1.9231	1.7177	1.5123	1.1203
17	1.4784	1.8298	1.8858	1.7541	1.5684	1.531	1.1763
18	1.6632	1.8671	1.9791	1.8107	1.8671	1.5684	1.2883
19	1.9404	1.8858		1.9239	1.8858	1.7177	1.423
20	2.1098	2.0538	2.1472	1.9418	1.7551	1.7924	1.4784
21	2.0911		2.0911	1.9605	1.7177	1.6804	1.4784
22	1.7551			1.9044	1.6787	1.7177	1.4045
23	1.7177	1.7177	1.8298		1.6221	1.6991	1.3491
24	1.3443	1.7187	1.7002	1.8858	1.643	1.6057	1.6804
Max	2.1098	2.0538	2.1472	2.0559	1.8858	1.7924	1.6804
Min	1.307	.8316	1.587	1.7541	1.3306	1.3491	1.1022
Avg	1.6095	1.6143	1.8031	1.8724	1.5800	1.5518	1.3835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 204 / 11 kv Wadsa Urban II

SHEDDABLE URBAN

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2752	.9055	1.1706	.9709	1.0456	.8402	.9896
2	1.2382	.8686	1.134	.9335	1.0082	.8215	.9896
3	1.2323	.8316	1.0974	.9522	1.0082	.7842	.9709
4	1.1088	.7947	.9877	.9522	.9335	.7468	.9522
5	.9979	.7392	.924	.9149	.9335	.7282	.9431
6	.8871	.7023	.823	.7655	.8962	.6722	.9149
7	.8501	.6653	.6584	.7095	.6535	.6348	
8	.5914	.6099	.7095	.6908	.6348	.5788	
9	.5544	.4805	.6535	.6099	.6099	.6653	
10	.7023	.5729	.7655	.8501	.8131	.8316	.7842
11	1.0164	.6653	1.0562	.8316	.924	1.0349	1.0185
12	1.2382	.7947	1.1389	1.1088	1.0164	1.2696	1.2136
13	1.2012		1.226	.9979	1.1827	1.3256	1.5497
14	1.0719		1.3817	.8501	1.0349	1.2136	1.475
15	1.2567		1.2323	.9335	1.2323	1.1203	1.307
16	1.1389	1.4377	1.0456	1.0269	1.3443	1.1203	1.3443
17	.8779	1.1763	1.0829	.9242	1.4563	1.1389	1.1949
18	.9431	1.2323	1.0829	.9054	1.3817	.8029	.8402
19	.9709	1.2323	1.1389	.9242	1.307	.9896	1.0349
20	1.0534	1.4003	1.1203	1.0456	1.0642	.8962	.9055
21	.8962	1.307	1.0642	1.0829	.961	.8962	.8316
22	.7468	1.251	.9709	1.0829	.8488	.9149	.7947
23	.8402	1.251	.9149		.8299	.8962	.7762
24	1.1763	.9055	1.1706	.9709	1.0456	.8589	1.0269
Max	1.2752	1.4377	1.3817	1.1088	1.4563	1.3256	1.5497
Min	.5544	.4805	.6535	.6099	.6099	.5788	.7762
Avg	.9944	.9440	1.0229	.9145	1.0069	.9076	1.0408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 205 / 11 KV WADSA U-III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.499	.5175	.4805	.3881	.5359	.4294
2	.4668	.4805	.4805	.462	.4066	.5359	.3921
3	.4435	.4805	.4435	.462	.4251	.5175	.3921
4	.4435	.462	.4066	.462	.4251	.5175	.3961
5	.4251	.4435	.3696	.4435	.4435	.5359	.3696
6	.4251	.4435	.3326	.462	.4435	.5175	.3696
7	.462	.5175	.5175	.4066	.3881	.4435	
8	.3326	.3696	.3696	.3142	.3734	.4435	
9	.3326	.2772	.3326	.3696	.2957	.4066	
10	.3142	.3326	.5228	.499	.5175	.5175	.2957
11	.3696	.3142	.5041	.2402	.5914	.7023	.4435
12	.5175	.3511	.5228	.2402	.6653	.7023	.4251
13	.5175		.5415	.2957	.6099	.6283	.462
14	.6099		.5228	.5914	.5914	.6099	.4435
15	.6283		.7842	.6099	.6283	.6099	.4435
16	.7392	.4715	.7842	.6838	.6283	.5914	.4435
17	.6653	.7023	.7095	.7947	.5914	.5544	.4066
18	.4854	.7655	.7733	.7023	.5544	.2957	.3696
19	.3772	.5228	.2801	.5359	.3326	.2957	.3326
20	.2957	.3881	.2987	.5175	.3142	.3142	.3326
21	.4805	.4108	.499	.462	.4904	.3881	.5175
22	.4805	.462	.4805	.462	.5601	.4066	.5359
23	.499	.5175	.462		.5359	.4066	.5175
24	.5175	.499	.5544	.4805	.3881	.5359	.4294
Max	.7392	.7655	.7842	.7947	.6653	.7023	.5359
Min	.2957	.2772	.2801	.2402	.2957	.2957	.2957
Avg	.4704	.4624	.5004	.4773	.4828	.5005	.4165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 206 / New Water Filter Plant

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0554	.0554	.0549	.0549	.0549	.0537
2	.0543	.056	.0549	.0732	.0549	.0732	.0537
3	.0543	.056	.0554	.0549	.0732	.0549	.0543
4	.0549	.0747	.0549	.0549	.0549	.0549	.0549
5	.0549	.056	.0554	.0732	.0549	.0549	.0354
6	.0554	.056	.0549	.0732	.0549	.0549	.0537
7	.0739	.056	.0366	.0549	.0732	.0549	
8	.0754	.056	.0732	.0549	.0732	.0549	
9	.056	.0566	.0732	.0732	.0747	.056	.0362
10	.0185	.0373	.0747	.0732	.056	.0747	.0724
11	.0189	.0373	.056	.0549	.0366	.0934	.0549
12	.0189	.0187	.0373	.0183	.0183	.0183	.0724
13	.0373		.0187	.0183	.0183	.0183	.0362
14	.0373		.0189	.0183	.0549	.0183	.0358
15	.0377		.0373	.0183	.0366	.0183	.0366
16	.0754	.0189	.0747	.0183	.0732	.0183	.0543
17	.0549	.0549	.056	.0183	.0549	.0183	.0537
18	.0549	.0549	.056	.0549	.0732	.0732	.0724
19	.0566	.0732	.0747	.0549	.0549	.0549	.0537
20	.056	.0549	.056	.0549	.0732	.0732	.0732
21	.0549	.0549	.0549	.0549	.0549	.0366	.0543
22	.0549	.0549	.0549	.0549	.0739	.0549	.0716
23	.0549	.0732	.0732		.0566	.0732	.0549
24	.0549	.0373	.0549	.0549	.0366	.0549	.0543
Max	.0754	.0747	.0747	.0732	.0747	.0934	.0732
Min	.0185	.0187	.0187	.0183	.0183	.0183	.0354
Avg	.0516	.0521	.0547	.0493	.0559	.0505	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 402 / 33 KV ARMORI-WADSA LL
FEEDER Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-AUG-17	02-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
9		4.1152	2.2405
10	5.6013	4.8171	
11		4.6491	
12		5.0972	
Max	5.6013	5.0972	2.2405
Min	5.6013	4.1152	2.2405
Avg	5.6013	4.6697	2.2405

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 403 / 33 KV SHANKARPUR FEEDER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	9.6342	10.072	10.3064	10.4184	7.8418	8.626	8.7706
2	9.6342	9.9589	10.4184	10.4744	7.8418	8.626	8.714
3	9.5782	9.8023	10.3624	10.5304	7.8087	8.4019	8.626
4	9.4662	9.7891	10.3624	10.5864	7.8087	8.4019	8.514
5	9.3696	9.5062	10.2504	10.6424	7.6738	8.4579	8.4579
6	9.6468	9.5222	10.3064	10.6945	7.9218	8.2899	8.626
7	10.0903	9.6194	11.3146	11.4826	7.8464	8.2305	
8	9.7462	10.072	11.3146	11.4826	8.0659	8.5048	
9	9.8023		11.2586	10.1509	8.2853	8.3951	
10	1.262	.7133	11.2603	11.3032	8.4499	7.9012	2.0165
11	9.9143	.6584	11.4826	9.5473	8.5048	7.572	7.2817
12	9.9703	.6173	10.6985	9.7668	8.834	5.6013	6.7215
13			10.072	9.8766	8.2305	7.6738	7.1696
14	9.0021		8.57	9.3827	6.3649	7.4497	7.1136
15	9.0535		9.7891	9.393	7.0233	8.1219	7.1696
16	9.0535	5.9934	6.9456	8.57	6.4198	8.0659	6.8896
17	9.0741	11.1471	7.3937	7.7858	7.1879	8.0659	7.1136
18	10.6945	9.6902	7.9538	7.8087	7.9561	8.2899	7.1136
19	10.5864	10.5813	10.3624	8.738	9.0535	9.2981	8.0659
20	9.9143	9.8583	7.2257	8.9621	9.6022	9.9143	8.4499
21	9.5782	11.2586	9.1301	9.2233	9.5222	9.6342	8.2305
22	9.2981	10.4744	9.2421	8.85	9.2421	9.2421	7.7915
23	10.3624	10.0823	9.2981		8.738	8.738	7.5172
24	9.7462	9.9703	9.5222	10.2984	8.2047	8.682	8.8272
Max	10.6945	11.2586	11.4826	11.4826	9.6022	9.9143	8.8272
Min	1.262	.6173	6.9456	7.7858	6.3649	5.6013	2.0165
Avg	9.3251	8.4694	9.7850	9.8247	8.1012	8.3410	7.58

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104001 / 33/11 KV WADSA S/STN

Feeder No / Name : 404 / LAHARI 33 KV FEEDER

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0532	.3921	.3189	.439	.439	.056
2	.1075	.0514	.3841	.3258	.3326	.439	.056
3	.1086	.0526	.3841	.3224	.4207	.3841	.056
4	.1086	.0514	.3841	.3721	.3801	.3841	.056
5	.1097	.0526	.3841	.4344	.3841	.3841	.0566
6	.0537	.0532	.3292	.2743	.3841	.3841	.0566
7	.0537	.052	.2743	.0549	.056	.056	
8	.056	.0532	.056	.0549	.056	.056	
9	.056	.0532	.0549	.056	.056	.056	.056
10	.056	.0514	.0566	.056	.056		.056
11	.056	.0549	.0566	.112	.112	.056	.1132
12	.112	.0543	.3921	.056	.3361	.4887	.4527
13	.168		.5041	.2241		.5487	.3921
14	.168		.3921	.3361	.168	.3761	.4938
15	.2241		.3961	.168	.112	.4344	.439
16	.1097	.1698	.5601	.3395	.3361	.3761	.3292
17	.1097	.2263	.3361	.1698	.3361	.3841	.5487
18	.1097	.056	.2241	.3361	.2801	.0537	.3841
19	.1097	.056	.056	.4481	.2241	.0532	.168
20	.1097	.0549	.112	.2629	.056	.0543	.056
21	.0549	.1646	.0549	.1543	.0549	.0543	.056
22	.0549	.2195	.0549	.1029	.0549	.0532	.2801
23	.0549	.4938	.1097		.0549	.0532	.2801
24	.1086	.0514	.3841	.3155	.1109	.4938	.056
Max	.2241	.4938	.5601	.4481	.439	.5487	.5487
Min	.0537	.0514	.0549	.0549	.0549	.0532	.056
Avg	.0987	.1012	.2639	.2302	.2087	.2636	.2045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104021 / 33/11 KV SHANKARPUR (WADSA)

S/

Feeder No / Name : 201 / 11 KV POTGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.2427	.3391	.3326	.1865	.2374	.2454
2	.2543	.2427	.3086	.3326	.1696	.2374	.2103
3	.2374	.2401	.3086	.3511	.1696	.2374	.2103
4	.2374	.2774	.2915	.3326	.1526	.2204	.2279
5	.2374	.2774	.298	.3511	.1696	.1865	.2279
6	.2543	.2774		.3511	.1865	.1865	.2103
7	.3391	.3294	.4334	.4887	.1865	.2204	.2218
8	.3052	.3467	.4973	.543	.2035	.2601	
9	.3222		.5144	.4409	.1696	.2401	
10	.3052		.285	.4748	.2035	.1307	.1646
11	.2947		.4191	.39	.2254	.1867	.1526
12	.3506		.4694	.373	.2229	.2241	.1696
13			.4862	.4578	.2229	.2353	.1526
14	.3121		.5121	.407	.2254	.1991	.1357
15	.3294		.4938	.373	.2254	.2353	.1526
16	.3506	.3772	.4024	.373	.298	.2743	.1696
17	.3294	.3944	.4887	.2543	.2774	.2587	.1526
18	.3856	.4801	.543	.2374	.2374	.2587	.1526
19	.2804		.4525	.2543	.2774	.2957	.2035
20	.3721	.2743	.4525	.2713	.298	.2804	.2035
21	.3856	.3601	.4409	.2543	.2601	.2629	.2035
22	.3681	.3814		.2374	.2601	.2454	.1696
23	.2601	.3601	.3511		.2401	.2481	.1696
24	.2543	.2427		.3326	.1865	.2374	.2454
Max	.3856	.4801	.543	.543	.298	.2957	.2454
Min	.2374	.2401	.285	.2374	.1526	.1307	.1357
Avg	.3052	.3190	.4185	.3571	.2189	.2333	.1887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104021 / 33/11 KV SHANKARPUR (WADSA)

S/

Feeder No / Name : 202 / 11 KV VISORA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.985	1.0808	1.307	.8402	.9214	.8779
2	.9054	.985	1.0631	1.2883	.823	.9214	.8779
3	.8886	.9671	1.0631	1.251	.823	.9214	.8596
4	.8886	.9671	1.0277	1.2883	.7888	.9036	.8596
5	.8718	.9313	1.0277	1.251	.7888	.9214	.8962
6	.8718	.8775		1.2323	.7716	.7265	.8413
7	.7377	.8059	.9036	1.1523	.6859	.7265	.8402
8	.7712	.7796	.9391	1.1222	.6859	.7619	
9	.7461		1.0099	1.1946	.7373	.7442	
10	.788		1.0642	1.1065	.7545	.6401	
11	.8328		1.0719	.9054	.7442	.695	.5375
12	.8238		1.0642	.9221	.8328	.6401	.5721
13			1.134	.9602	.8505	.695	.5548
14	.9134			.8916	.7973	.6584	.5721
15	.8954		.9671	.8402	.7973	.6697	.5548
16	.8775	.8417	1.0745	.7202	.815	.6767	.5721
17	.591	.9036	1.0425	.7373	.7973	.7316	.5895
18	.8417	.9671	1.134	.7619	.8328	.8131	.6241
19	.9671	1.182	1.2803	.9114	.9922	.9425	.8149
20		1.2226		.9214	1.0277	.9145	.8413
21	1.134	1.2048	1.4003	.9362	.9922	1.0242	.8413
22	1.0924	1.1218	1.2795	.8745	.9745	.9694	.8238
23	1.0277	1.0985	1.307		.9391	.8962	.8238
24	.9389	1.0208	1.0808	1.307	.8573	.9214	.8779
Max	1.134	1.2226	1.4003	1.307	1.0277	1.0242	.8962
Min	.591	.7796	.9036	.7202	.6859	.6401	.5375
Avg	.8777	.9918	1.0960	1.0384	.8312	.8098	.7454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104021 / 33/11 KV SHANKARPUR (WADSA)

S/

Feeder No / Name : 203 / 11 KV KOREGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.3432	1.2269	1.5181	1.286	1.382	1.262
2	1.1568	1.3253	1.1919	1.5181	1.286	1.382	1.2254
3	1.1568	1.4506	1.1919	1.5364	1.2346	1.3643	1.2382
4	1.1233	1.4327	1.2094	1.5729	1.2346	1.382	1.2567
5	1.1233	1.3969	1.2094	1.5364	1.2174	1.3643	1.2403
6	1.0898	1.2715		1.5729	1.2003	1.1871	1.2567
7	1.1065	1.2357	1.2094	1.5043	1.1488	1.1871	1.2136
8	1.2071	1.2178	1.262	1.5223	1.2517	1.2403	
9	.9496		1.3321	1.5939	1.2174	1.2048	
10			1.3253	1.576	1.4746	1.0867	1.0425
11	1.3535		1.576	1.4083	1.5592	1.2795	1.1222
12	1.3432		1.576	1.4918	1.6655	1.1568	1.1584
13				1.4918	1.4175	1.3443	1.0029
14	1.4327		1.4632	1.4232	1.4506	1.419	.8954
15	1.4148		1.5546	1.4746	1.4864	1.286	1.0208
16	1.3756	.3856		1.4403	1.4685	1.419	1.0387
17	1.5023	1.262	1.363	1.1317	1.2357	1.267	.8954
18	1.3575	1.3672	1.5684	.9882	1.2226	1.1765	.788
19	1.5181	1.3146	1.643	1.2309	1.2934	1.267	.9134
20	1.6461	1.2548	1.7177	1.3003	1.3643	1.386	.9671
21		1.3496	1.5947	1.2689	1.3253	1.3676	.9671
22	1.5565	1.3146	1.6827	1.3546	1.4175	1.2936	.9313
23	1.4864	1.258	1.6095		1.3643	1.2752	.8954
24	1.1904	1.3611	1.2403		1.3032	1.382	1.2489
Max	1.6461	1.4506	1.7177	1.5939	1.6655	1.419	1.262
Min	.9496	.3856	1.1919	.9882	1.1488	1.0867	.788
Avg	1.2983	1.2671	1.4165	1.4298	1.3386	1.2958	1.0718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

CHANDRAPUR ZONE[064]

GADCHIROLI CIRCLE[655]

GADCHIROLI DIVISION[643]

WADSA S/DN.[340]

BU 4340

Substation No/ Name :- 104021 / 33/11 KV SHANKARPUR (WADSA)

S/

Feeder No / Name : 401 / 33 KV KURKHEDA NEW

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.4072	6.3935	6.166	7.0588	5.2126	5.3687	5.7013
2	6.2986	6.286	6.3397	7.1674	5.1583	5.3687	5.5927
3	6.2443	6.0597	6.877	7.0588	5.1583	5.3155	5.5384
4	6.2443	6.166	6.9307	7.276	5.104	5.3189	5.7013
5	6.4072	6.2191	6.9845	7.0588	5.104	5.3155	5.7013
6	6.5158	6.3255		7.0588	5.1583	5.4264	5.8768
7	6.9502	6.8233	7.7366	7.6509	5.3755	5.5876	5.7013
8	7.1674	6.8233	7.5755	7.4846	5.5384	5.7488	
9	7.276		7.2291	6.4312	5.5927	5.5813	
10		.6447	7.8189	7.1674	5.4298	5.7105	.6516
11	6.4849	.6173	7.3846	6.3529	5.3687	4.9897	4.8868
12	6.7696	.6173	7.3303	6.0814	5.5813	4.6571	4.9954
13			7.276	6.0814	5.1029	4.4696	4.9954
14	6.2323		6.0814	5.7013	3.3488	4.8377	4.8868
15	5.9099		6.5701	5.7013	3.8272	4.9954	4.7782
16	5.695	5.0497	6.5158	4.5068	3.2956	5.048	4.561
17	5.695	7.3068	4.768	4.9411	4.0398	5.2126	4.7782
18	5.6344	6.1248	6.5421	5.2126	5.1029	5.3727	4.9954
19	6.5009	8.5048	7.8727	5.7013	5.9002	6.19	5.647
20	7.3525	6.1248	7.4291	6.0814	6.4318	6.8336	6.0271
21	7.3605	6.1128	5.0497	6.0271	6.286	6.6095	5.8642
22	5.5338	6.5009	7.6017	5.647	5.8471	6.1614	5.5384
23	6.6975	6.7696	4.7782		5.5281	5.9322	5.2126
24	6.4072	6.3935	6.166	7.0588	5.2126	5.4218	5.9322
Max	7.3605	8.5048	7.8727	7.6509	6.4318	6.8336	6.0271
Min	5.5338	.6173	4.768	4.5068	3.2956	4.4696	.6516
Avg	6.4448	5.5932	6.7402	6.3699	5.1544	5.4781	5.1620