

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 201 / 11 KV irri

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	1.1546	1.2155	1.3908	.5982	.8002	1.4822
2	.8878	1.1317	1.2841	1.3984	.583	.7392	1.5051
3	.945	1.0593	1.2765	1.4022	.6478	.6973	1.5089
4	1.0326	1.0707	1.1965	1.3984	.5525	.6744	1.5051
5	1.044	1.0669	1.1965	1.4365	.503	.6554	1.4861
6	1.0288	1.0745	1.1965	1.4632	.4801	.6592	1.467
7	1.0174	1.0593	1.2003	1.4137	.4725	.6783	1.4975
8	.9793	1.0631	1.185	1.1622	.5639	.663	1.3908
9	.9869	1.0669	1.2041	1.2308	.5449	.5411	1.3984
10	.9564	1.0021	1.2231	1.2536	.5411	.4954	1.387
11	1.0174	1.0098	1.2155	1.2803	.5106	.5639	1.387
12	1.0174	1.0059	1.185	1.2689	.4687	.5525	1.387
13	.9945	.9374	1.1393	1.2612	.4611	.5068	1.4137
14	.9831	.9374	1.1317	1.2498	.4382	.5525	1.5356
15		.9069	1.1507	1.1203	.3734	.6897	1.5585
16	.6516	.9717	1.1507	1.1507	.4687	.7125	1.3984
17	.8269	.9945	1.1698	1.2041	.4877	.7049	1.467
18	.9297	.9069	1.1774	1.2346	.4763	.724	1.4899
19	.9412	.8383	1.1622	1.2841	.4572	.6554	1.5089
20	.9335	.8192	1.1241	1.2917	.3582	.6478	1.6232
21	.9717	.8688	1.0631	1.2765	.3506	.6325	1.608
22	.9831	.9069	1.1965	1.307	.362	.6744	1.5889
23	.964	.964	1.1888	1.3679	.4496	.724	1.1812
24	.9945	1.0288	1.1584	1.3527	.4801	.7888	1.2231
Max	1.044	1.1546	1.2841	1.4632	.6478	.8002	1.6232
Min	.6516	.8192	1.0631	1.1203	.3506	.4954	1.1812
Avg	.9553	.9936	1.1830	1.3000	.4846	.6556	1.4583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 204 / 11 KV Salekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0593	1.1546	1.3641	1.2879	1.2422	1.326	1.2193
2	1.0021	1.1622	1.3603	1.2803	1.2003	1.2803	1.2384
3	1.0059	1.1241	1.2993	1.2803	1.1584	1.307	1.2841
4	1.0021	1.1736	1.3032	1.2803	1.1546	1.3222	1.307
5	1.0212	1.185	1.2993	1.2612	1.1431	1.3222	1.326
6	1.025	1.1393	1.2841	1.2612	1.1622	1.2993	1.3184
7	1.025	1.1431	1.3184	1.1698	1.1622	1.2955	1.3184
8	.9869	1.1469	1.3413	1.1622	1.1584	1.2803	1.3146
9	.9983	1.1431	1.3298	1.1622	1.166	1.1012	1.2727
10	.5754	1.1584	1.3184	1.1126	1.1088	1.2003	1.2765
11	.5754	1.1546	1.307	1.1965	1.0212	1.0555	1.2574
12	.5601	1.1317	1.2498	1.1698	.9983	1.0136	1.2308
13	.4839	1.0059	1.1355	1.1698	.8878	.8802	1.1164
14	.4344	.9564	1.1279	1.0936	.8421	.8878	1.1012
15		.9069	1.086	1.0936	.8192	.8269	1.0936
16	.5296	.9297	1.1012	1.0707	.7926	.7811	1.0898
17	.7697	.9259	1.0974	1.0479	.804	.9183	.6097
18	.804	.8802	1.105	1.0479	.823	.964	.5639
19	.7773	.8573	1.1203	1.0326	.8802	.9183	.6668
20	.7545	.823	1.1507	1.0517	.8573	.865	.8154
21	.7392	.724	.7087	.9488	.8307	.8688	.6935
22	.6859	.7049	.7697	.7773	.7506	.7621	.5601
23	.7125	.724	.9945	.804	.7621	.7849	.602
24	.7849	.5068	1.1736	.884	.8078	.8802	.6744
Max	1.0593	1.185	1.3641	1.2879	1.2422	1.326	1.326
Min	.4344	.5068	.7087	.7773	.7506	.7621	.5601
Avg	.7962	.9901	1.1811	1.1103	.9805	1.0475	1.0396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 201 / 11 KV Chichgad

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5689	.6546	.6287	.7678	.7785	.7918	.6093
2	.5689	.6413	.6203	.7548	.7579	.7819	.61
3	.5617	.6379	.6108	.7499	.7537	.7781	.6055
4	.5578	.6321	.6085	.7453	.7453	.7716	.6043
5	.5563	.6337	.6108	.7484	.7526	.7705	.6032
6	.5548	.6314	.62	.7548	.7476	.767	.6074
7	.4896	.5601	.6017	.6581	.7004	.655	.5853
8	.4809	.5426	.6173	.6455	.6775	.6882	.6188
9	.4736	.5449	.5224	.6767	.6558	.6958	.6459
10	.4786	.5449	.5693	.6619	.6527	.7205	.647
11	.4858	.5407	.6401	.6859	.6897	.7068	.5925
12	.4816	.5933	.6775	.6626	.6927	.7891	.5342
13	.4656	.6241	.6424	.6562	.7373	.7167	.5277
14	.4946	.6299	.644	.6398	.732	.719	.4877
15	.4755	.6158	.6451	.4641	.5697	.4191	.4683
16	.431	.6729	.6581	.4466	.6142	.4089	
17	.4401	.6558	.6253	.5487	.6382	.4915	
18	.5392	.5293	.6866	.6203	.66	.5742	.1646
19	.756	.823	.8928	.8493	.9118	.716	.5697
20	.8204	.8924	.9294	.9069	.9633	.7735	.6645
21	.8303	.8855	.9259	.9118	.9484	.7693	.6859
22	.7868	.7461	.9042	.8943	.913	.7297	.6516
23	.7129	.6935	.8581	.8512	.8501	.6695	.6081
24	.6763	.647	.7975	.7929	.8112	.6207	.5746
Max	.8303	.8924	.9294	.9118	.9633	.7918	.6859
Min	.431	.5293	.5224	.4466	.5697	.4089	.1646
Avg	.5703	.6489	.6890	.7122	.7481	.6885	.5757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 202 / 11 KV Ganutola Feeder

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4813	.5136	.5197	.5018	.535	.5056	.4298
2	.4809	.5091	.514	.4988	.53	.506	.4252
3	.4763	.5075	.5121	.4969	.5281	.5045	.423
4	.4729	.5056	.5117	.4927	.5258	.5056	.4203
5	.4767	.5034	.5117	.4988	.5342	.5095	.4291
6	.4618	.4927	.487	.4755	.5155	.4801	.4028
7	.3807	.405	.3929	.378	.3894	.3624	.3205
8	.3403	.3578	.3559	.3426	.3467	.3406	.2961
9	.3018	.3437	.2804	.3166	.3227	.3311	.2808
10	.2896	.322	.3105	.3159	.3414	.306	.2663
11	.2846	.346	.3212	.3403	.3376	.2919	.2976
12	.2782	.3201	.3166	.3357	.3692	.2934	.3083
13	.2854	.3349	.2881	.3311	.3868	.314	.2926
14	.2892	.341	.2888	.2904	.3285	.3033	.2587
15	.2709	.3311	.2938	.2675	.3166	.1467	.2492
16	.2694	.2839	.3064	.3045	.3208	.2138	.2103
17	.3125	.3014	.3296	.3151	.3784	.2324	.2999
18	.4138	.3342	.4001	.4104	.458	.37	.314
19	.6668	.6683	.6542	.6718	.6893	.5548	.4317
20	.6958	.7023	.6744	.7034	.7038	.5845	.4889
21	.6969	.6943	.6379	.6615	.6592	.5639	.4809
22	.6207	.6367	.6131	.6234	.6051	.5129	.4321
23	.5723	.575	.554	.5754	.551	.4721	.3921
24	.527	.5376	.5148	.551	.5079	.4367	.3723
Max	.6969	.7023	.6744	.7034	.7038	.5845	.4889
Min	.2694	.2839	.2804	.2675	.3166	.1467	.2103
Avg	.4311	.4528	.4412	.4458	.4659	.4017	.3551

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 201 / 11KV AMGAON

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.2849	1.7535	1.9517	2.2657	2.0713	2.1445
2	1.1119	1.2734	1.7284	1.9174	2.2154	2.0485	2.1346
3	1.1035	1.2711	1.7147	1.9037	2.1963	2.0325	2.1033
4	.9793	1.2582	1.6895	1.8778	2.1849	1.9951	2.0835
5	.9694	1.2506	1.6933	1.8747	2.2024	2.0012	2.1155
6	.9556	1.2399	1.6621	1.8435	2.1872	1.9913	2.0904
7	.9701	1.3268	1.6164	2.098	2.1986	2.0911	2.1201
8	1.0974	1.4259	1.7985	2.2489	2.2268	2.1689	2.4554
9	1.2323	1.5493	1.9509	2.2916	2.1879	2.2954	2.6162
10	1.2582	1.592	2.0012	2.063	2.1369	2.4326	2.5575
11	.961	1.6019	2.1399	2.2123	2.1483	2.3701	1.768
12	1.1584	1.6484	2.0439	1.9989	2.3906	2.5995	2.0104
13	1.2361	1.7101	2.0454	1.544	2.3967	2.6101	2.2664
14	1.3367	1.6423	1.8755	1.656	2.207	2.1559	2.2603
15	1.3489	1.7467	1.8854	1.5745	2.1376	2.1803	2.2763
16	1.374	1.7787	1.6232	1.7772	2.1506	2.2077	1.6552
17	1.2498	1.7856	1.5577	1.9601	2.2055	1.8762	.1783
18	1.4563	1.7055	1.813	2.1483	2.2283	2.2458	2.3785
19	1.7756	2.0919	2.2649	2.5316	2.4501	2.5842	2.5621
20	1.8023	2.0485	2.332	2.5713	2.4943	2.5835	2.6863
21	1.7574	2.0157	2.2611	2.5652	2.4059	2.4859	2.6337
22	1.6331	1.9189	2.1597	2.4844	2.2885	2.3914	1.9022
23	1.3161	1.8298	2.0393	2.3777	2.162	2.2634	1.8808
24	1.2978	1.7741	1.9753	2.2931	2.1064	2.1506	1.8351
Max	1.8023	2.0919	2.332	2.5713	2.4943	2.6101	2.6863
Min	.9556	1.2399	1.5577	1.544	2.1064	1.8762	.1783
Avg	1.2704	1.6154	1.9010	2.0735	2.2406	2.2430	2.1131

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 202 / 11 KV DEORI

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4205	1.5745	1.6499	1.6888	1.6408	1.7909	1.5798
2	1.3222	1.5318	1.6232	1.6545	1.5729	1.7452	1.5272
3	1.3047	1.4922	1.563	1.6248	1.5539	1.7154	1.5211
4	1.2963	1.467	1.5539	1.5988	1.5264	1.6827	1.4944
5	1.2551	1.4434	1.5127	1.5775	1.5127	1.6514	1.4784
6	1.2719	1.4297	1.5104	1.563	1.4929	1.6522	1.4647
7	1.2209	1.3359	1.3855	1.5158	1.4518	1.5516	1.4167
8	1.1713	1.2925	1.3192	1.4281	1.3695	1.2887	1.3748
9	1.1911	1.3481	1.371	1.4594	1.3618	1.371	1.467
10	1.2559	1.323	1.4205	1.464	1.3862	1.4396	1.5043
11	1.3207	1.4495	1.5623	1.5828	1.4403	1.6743	1.6057
12	1.4137	1.5173	1.64	1.6324	1.4883	1.6949	1.576
13	1.4556	1.4746	1.72	1.5798	1.579	1.7497	1.5882
14	1.4472	1.4426	1.6225	1.5554	1.6697	1.7482	1.56
15	1.3024	1.2803	1.6088	1.5615	1.717	1.5569	1.5211
16	1.3687	1.3954	1.6415	1.5661	1.7436	1.4548	1.6415
17	1.3588	1.4434	1.5341	1.4922	1.6949	1.4601	.4611
18	1.3329	1.3344	1.5036	1.4693	1.6674	1.48	1.2765
19	1.4678	1.438	1.6347	1.6065	1.733	1.7208	1.7589
20	1.8298	1.8092	1.9464	1.893	1.9502	1.8968	1.9174
21	1.8077	1.7962	1.9121	1.8983	1.9669	1.9128	1.9197
22	1.7825	1.7817	1.8435	1.8267	1.8922	1.8305	1.8801
23	1.6888	1.7566	1.8153	1.7932	1.877	1.8099	1.8587
24	1.6438	1.7071	1.7558	1.672	1.8549	1.6728	1.7711
Max	1.8298	1.8092	1.9464	1.8983	1.9669	1.9128	1.9197
Min	1.1713	1.2803	1.3192	1.4281	1.3618	1.2887	.4611
Avg	1.4138	1.4944	1.6104	1.6127	1.6310	1.6480	1.5485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 204 / 11 KV KOHAMARA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.845	2.7549	3.4789	3.3867	2.7435	2.9218	2.4006
2	1.858	2.713	3.4423	3.3867	2.7061	2.8921	2.3906
3	1.8473	2.6978	3.3638	3.3653	2.6917	2.8776	2.3754
4	1.829	2.7008	2.2603	3.3547	2.6688	2.8509	2.3845
5	1.8374	2.6962	2.982	3.36	2.6772	2.8372	2.367
6	1.8442	2.7115	2.9576	3.3547	2.6856	2.8319	2.3609
7	2.1872	2.8288	3.3501	3.4271	2.7176	2.9515	2.46
8	2.46	2.9447	3.4812	3.7159	2.9111	3.1634	2.5057
9	2.463	3.1299	3.3112	3.8218	2.7625	3.3242	2.6376
10	2.713	3.3158	3.5307	3.8363	2.8433	3.1413	2.7534
11	2.8227	3.2084	3.8752	3.8828	2.7557	3.1375	2.7343
12	1.8122	2.3983	3.9643	3.2587	2.899	3.2183	2.7351
13	2.5377	3.2625	3.9575	2.8502	3.1085	3.3318	2.7572
14	2.6917	3.3227	3.7014	3.0041	3.1474	2.8738	2.7625
15	2.8128	3.6054	3.8607	2.4844	3.0285	2.6376	2.553
16	2.838	3.6702	3.8554	2.5934	2.9797	2.5149	2.5484
17	2.9851	3.7083	3.9392	2.9119	2.886	2.5088	
18	2.9515	3.2846	3.5178	2.8997	2.8669	2.5133	2.8189
19	3.2602	3.7952	3.9971	3.0125	3.1344	2.6292	2.9858
20	3.2259	3.8637	3.991	2.9614	3.2266	2.5606	2.886
21	3.2053	3.7929	3.9087	2.9752	3.1756	2.5735	2.8677
22	3.0796	3.6923	3.8112	2.9226	3.1161	2.5194	2.7892
23	2.9211	3.546	3.6366	2.8342	2.995	2.4638	2.6429
24	2.7664	3.4537	3.4057	2.7618	2.9332	2.4066	2.6231
Max	3.2602	3.8637	3.9971	3.8828	3.2266	3.3318	2.9858
Min	1.8122	2.3983	2.2603	2.4844	2.6688	2.4066	2.3609
Avg	2.5331	3.2124	3.5658	3.1818	2.9025	2.8200	2.6235

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER MBCP NON SHEDDABLE EXPRESS HV FEEDERS  
 SIRP Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.0613	.069	.0663	.0693	.0682	.0655
2	.0617	.0591	.0671	.0625	.0648	.0648	.0652
3	.0602	.0583	.0621	.0617	.0636	.064	.0617
4	.0602	.0587	.0621	.0617	.0636	.0636	.061
5	.0575	.0579	.0598	.061	.0629	.0621	.0617
6	.0549	.0526	.0545	.056	.0594	.0591	.0526
7	.04	.0221	.04	.048	.0484	.0514	.045
8	.0381	.0408	.0472	.0469	.0469	.0503	.048
9	.0434	.0404	.0488	.0503	.0431	.0495	.0484
10	.0427	.0514	.048	.0423	.0408	.0476	.0469
11	.0419	.0461	.0434	.0446	.0415	.0465	.0461
12	.0423	.0415	.0461	.0438	.0469	.0495	.045
13	.0461	.0419	.0465	.0419	.0453	.0511	.045
14	.0362	.048	.0431	.0427	.0499	.0442	.0419
15	.045	.0465	.0453	.0434	.0461	.0412	.0438
16	.0453	.0453	.0457	.0431	.0442	.0358	.0419
17	.0453	.0484	.0453	.0442	.0442	.0358	.0438
18	.0457	.04	.0472	.0461	.045	.0415	.045
19	.0594	.0625	.0671	.0659	.0709	.0602	.069
20	.0705	.0754	.0751	.0686	.0747	.0693	.0735
21	.0697	.0743	.0713	.0629	.0678	.0629	.0678
22	.0625	.0739	.0678	.0629	.0671	.069	.064
23	.0598	.0663	.0652	.064	.0682	.0671	.0655
24	.0625	.0686	.0674	.0655	.0667	.064	.0644
Max	.0705	.0754	.0751	.0686	.0747	.0693	.0735
Min	.0362	.0221	.04	.0419	.0408	.0358	.0419
Avg	.0523	.0534	.0556	.0540	.0559	.0549	.0547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 202 / 11 KV Mahagaon Feeder From SHEDDABLE RURAL  
33k Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.6097	.8535	1.0669	1.0669	.9755	.823
2	.4877	.6097	.823	1.0669	1.0669	1.0059	.823
3	.4877	.6097	.823	.9145	1.0669	1.0059	.7926
4	.4877	.6097	.7926	.9145	1.0669	1.0059	.7926
5	.4877	.5792	.7926	.9145	1.0669	1.0059	.7926
6	.4572	.5792	.7621	.884	.945	1.0059	.7926
7	.3963	.4877	.6706	.884	.823	.945	.7316
8	.3963	.5182	.7011	.9755	.945	.9755	.7316
9	.4572	.5792	.8535	1.0974	1.0364	1.0059	
10	.4877	.6097	.945	1.1584	1.0669	1.1279	.823
11	.5182	.6706	.945	1.1888	1.0974		.884
12	.5487	.7316		1.2193	1.1279		.8535
13	.5792	.7316	.884	1.1888	1.1279	1.1888	
14		.7621	.884	1.1279	1.1584	1.2193	.9145
15		.7926	.9145	1.0974	1.1888	1.2498	.945
16	1.4327	.8535	.9755	1.1279	1.0669		1.0059
17	1.4022	.884	1.0059	1.0059	1.0669		
18	1.3413	.884	1.0059	.9755	1.0364	.6706	
19		.9755	1.1279	1.0669	1.0974	.7621	1.0364
20	.7011	.9145	1.1584	1.1279	1.1888	.823	1.0364
21	.7011	.945	1.1584	1.1584	1.1888	.9145	1.0364
22	.6706	.945	1.1279	1.1584	1.1584	.884	1.0364
23	.6401	.9145	1.1279	1.1279	1.1279	.8535	.9755
24	.6097	.884	1.0974	1.0974	1.0974	.823	.9755
Max	1.4327	.9755	1.1584	1.2193	1.1888	1.2498	1.0364
Min	.3963	.4877	.6706	.884	.823	.6706	.7316
Avg	.6561	.7367	.9317	1.0644	1.0783	.9724	.8901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 201 / 11KV ARJUNI MOR FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4022	1.3794	.7735	1.5508	1.5508	1.528	1.5432
2	1.2269	1.3641	.7506	1.4556	1.5242	1.5203	1.528
3	1.3108	1.307	.7468	1.4899	1.467	1.5585	1.4822
4	1.3679	1.0974	.743	1.547	1.467	1.5737	1.4899
5	1.3489	1.0669	.7468	1.4937	1.2574	1.5394	1.4975
6	1.2993	1.2193	.7354	1.4632	1.2536	1.4822	1.3298
7	1.2955	1.2269	.6744	1.387	1.166	1.1431	1.105
8	1.185	1.1279	.644	1.4098	1.1012	1.0288	1.0593
9	1.2155	1.2422	.6859	1.4403	1.1164	1.1355	1.0288
10	1.0593	1.3908	.7583	1.2117	1.0936	1.2765	1.1507
11	1.0326	1.2346	.8726	1.1203	1.0136	1.3146	1.2422
12	1.2422	1.0593	.9374	1.1203	1.0974	1.1393	1.2727
13	1.1888	1.0593	.9335	.9831	1.1164	1.0174	1.3222
14	1.0288	.8764	.9259	1.1164	1.1355	1.1698	1.2422
15	1.0021	1.0593	1.1241	1.1203	.9488	1.0669	1.1203
16	.9983	.9945	1.1546	1.1698	.9945	1.0364	1.2269
17	.9755	.7583	1.1203	1.1469	.9717	.9259	1.2231
18	.8497	.8002	1.025	1.0059	.9412	.964	1.1812
19	.964	.8383	1.0059	1.0745	1.025	1.0021	1.0822
20	.9945	.9488	1.0326	1.0822	1.0707	1.0783	1.2346
21	.9183	.9031	.9945	1.0517	1.0555	1.1279	1.2041
22	1.1736	.8688	1.4899	1.5851	1.6423	1.5813	1.406
23	1.1888	.865	1.6004	1.5927	1.6499	1.5356	1.5432
24	1.3832	.8383	1.5623	1.547	1.5737	1.5165	1.6004
Max	1.4022	1.3908	1.6004	1.5927	1.6499	1.5813	1.6004
Min	.8497	.7583	.644	.9831	.9412	.9259	1.0288
Avg	1.1522	1.0636	.9599	1.2986	1.2181	1.2609	1.2965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 202 / 11 KV Gothangaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4306	.5639	.6897	.6706	.5906	.663	.5982
2	.4306	.5563	.6821	.663	.5906	.6592	.5982
3	.423	.522	.5601	.6592	.5868	.6554	.5944
4	.4191	.4992	.5563	.6554	.5868	.6554	.5944
5	.4153	.4915	.5563	.6478	.583	.644	.5944
6	.4039	.4801	.5411	.6401	.5754	.6363	.5792
7	.301	.3734	.5068	.5868	.4954	.5677	.4801
8	.2934	.3887	.5868	.6592	.5296	.5754	.5106
9	.3506	.4954	.6554	.7087	.5677	.6592	.5754
10	.3658	.583	.6783	.6554	.6135	.7468	.6249
11	.3467	.5563	.1257	.7392	.6363	.2934	.5944
12	.3696	.5868	.6973	.7392	.6478	.2934	.5487
13	.3925	.5258	.7506	.6783	.6135	.5754	.5411
14	.3391	.5792	.7316	.6935	.602	.6592	
15	.3772	.602	.5868	.6401	.6363	.7011	.583
16	.3315	.6097	.6516	.6211	.6325	.5068	.6287
17	.3391	.6211	.6744	.6173	.4839	.4153	.4801
18	.3658	.4877	.6706	.5639	.5258	.5411	.6325
19	.5525	.7278	.7621	.6287	.6859	.6744	.8688
20	.6173	.7773	.7926	.6859	.7316	.7164	.9107
21	.644	.8078	.7964	.6973	.7468	.7164	.9107
22	.644	.7849	.7735	.663	.7316	.6859	.8802
23	.6097	.7278	.724	.6363	.6935	.663	.8192
24	.583	.7087	.7011	.6211	.6783	.6249	.7888
Max	.644	.8078	.7964	.7392	.7468	.7468	.9107
Min	.2934	.3734	.1257	.5639	.4839	.2934	.4801
Avg	.4311	.5857	.6438	.6571	.6152	.6054	.6494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 203 / 11 KV Sangadi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7718	1.7109	1.7071	1.7604	1.7414	1.9281	1.7642
2	1.7795	1.7109	1.7032	1.7642	1.7337	1.9128	1.768
3	1.7795	1.7109	1.7109	1.7604	1.7261	1.9128	1.7642
4	1.7756	1.7109	1.7071	1.7566	1.7223	1.9052	1.7566
5	1.7756	1.7032	1.7071	1.7566	1.7185	1.8976	1.7566
6	1.7756	1.6994	1.7032	1.7528	1.7185	1.8861	1.7528
7	1.7414	1.6232	1.5889	1.5927	1.5966	1.6994	1.6118
8	1.7223	1.5813	1.5394	1.105	1.4403	1.7071	1.627
9	1.688	1.5851	1.5203	1.2993	1.4784	1.8176	1.7071
10	1.6766	1.5356	1.5242	1.5813	1.5051	1.8785	1.829
11	1.6194	1.5356	1.5394	1.5318	1.5699	1.6956	1.9966
12	1.608	1.5394	1.5585	1.547	.5373	1.6575	1.9243
13	1.5966	1.5318	1.3032	1.5699	1.768	1.6804	2.0195
14	1.608	1.5356	1.5889	1.5737	1.7909	1.7604	1.9966
15	1.6042	1.5318	1.5737	1.5356	1.8442	1.7718	2.1224
16	1.5813	1.5242	1.3756	1.547	1.7185	1.5966	1.989
17	1.5623	1.4975	1.4213	1.528	1.7147	1.547	2.0424
18	1.5546	1.4632	1.5127	1.5089	1.6956	1.5661	2.0043
19	1.6042	1.6575	1.5165	1.6918	1.6575	1.8404	2.0805
20	1.8328	1.8138	1.7909	1.8633	1.9319	1.9662	2.2481
21	1.8557	1.8252	1.8252	1.8823	1.9281	1.9738	2.2367
22	1.8214	1.7985	1.7909	1.8214	1.8747	1.9319	2.1338
23	1.7604	1.7375	1.7414	1.7604	1.8176	1.829	1.9319
24	1.7375	1.7147	1.7299	1.749	1.8138	1.7871	1.9738
Max	1.8557	1.8252	1.8252	1.8823	1.9319	1.9738	2.2481
Min	1.5546	1.4632	1.3032	1.105	.5373	1.547	1.6118
Avg	1.7013	1.6366	1.6116	1.6350	1.6685	1.7979	1.9182

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 201 / 11KV KOKANA FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.2439	.3048	.3201	.2439	.3048	.2743
2	.1219	.2439	.2896	.3201	.2439	.2896	.2591
3	.1219	.2439	.2896	.3201	.2439	.3048	.2591
4	.1219	.2439	.2896	.3201	.2439	.2896	.2591
5	.1219	.2439	.2896	.3201	.2439	.2896	.2591
6	.1219	.2439	.3048	.3201	.2439	.2896	.2591
7	.1067	.2286	.2896	.3048	.2896	.2743	.2591
8	.1067	.2134	.2743	.3048	.2591	.2743	.2591
9	.1219	.2286	.3048	.2896	.2743	.2743	
10	.1524	.2286	.3353	.3048	.2743	.2896	.2896
11	.1677	.2439	.3506	.2743	.2896		.2743
12	.1677	.2591	.3201	.2896	.3201	.2743	.2743
13	.1981	.2743	.2743	.3048	.2896		.2896
14	.2134	.2743	.2896	.2896	.3201	.3048	.2286
15	.2134	.2591	.2743	.3048	.3201	.2896	.3658
16	.1981	.2591	.2896	.2896	.3048	.2896	.3658
17		.2743	.3506			.2896	
18	.2134	.2591	.3201	.2439	.2591	.2743	
19	.2439	.3048	.3201	.2439	.3048	.3048	
20	.2591	.3048	.3353	.2439	.3048	.3048	
21	.2591	.3048	.3353	.2591	.3048		.3506
22	.2439	.3048	.3201	.2439	.2896	.2743	.3353
23		.2896	.3201	.2439	.2896	.2743	.3201
24	.2439	.3048	.3201	.2439	.3048	.2743	.3201
Max	.2591	.3048	.3506	.3201	.3201	.3048	.3658
Min	.1067	.2134	.2743	.2439	.2439	.2743	.2286
Avg	.1746	.2616	.3080	.2869	.2810	.2874	.2896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 202 / 11 KV Tirkhedi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1888	1.1888	1.4632	1.3108	1.0974	1.3108
2	1.0974	1.1888	1.1888	1.4327	1.2803	1.0669	1.2803
3	.945	1.1888	1.1888	1.4327	1.2803	1.0059	1.2498
4	.9145	1.1584		1.4022	1.2803	1.0059	1.2498
5	.945	1.1584	.6706	1.4022	1.2803	1.0059	1.2498
6	.945	1.1584	1.0364	1.4022	1.2803	.9755	1.2498
7	.884	1.0364	1.0974	1.2803	1.2193	1.0364	1.1584
8	.945	1.0364	1.0974	1.0059	1.2193	1.0669	1.0974
9	.9755	1.1279	1.2193	1.1279	1.1279	1.0974	1.1584
10	.884	1.1584	1.2193	1.2498	1.1888	1.0364	1.1584
11	.9145	.9755	1.2803	1.2803	1.2498	1.1279	1.1584
12	.823	1.0364	1.2803	1.3108	1.3413	1.0669	1.1279
13	.945	1.0974	1.2803	1.3413	1.3413	1.0059	1.1888
14	.945	1.1279	1.3413	1.1584	1.3108	.7926	
15	.945	1.1584	1.2498	1.1888	1.3108	.8535	.945
16	1.0059	1.1279	1.2193	1.2498	1.0059	.945	1.0669
17	.945	1.0669	1.2498	1.2193	.9145	1.0364	
18	.9755	1.1279	1.2498	1.2193	.945	1.0364	
19	1.2803	1.4632	1.5546	1.5546	1.2498	1.4327	1.6156
20	1.4022	1.2803	1.6156	1.6461		1.4937	1.6461
21	1.4022	1.2803	1.5546	1.4022	1.3413	1.4632	1.5851
22	1.4022	1.3108	1.5546	1.4022	1.2803	1.4327	1.5242
23	1.2803	1.2803	1.5242	1.3717	1.1888	1.4022	1.4632
24	1.2193	1.2498	1.4937	1.3413	1.0974	1.3108	1.3717
Max	1.4022	1.4632	1.6156	1.6461	1.3413	1.4937	1.6461
Min	.823	.9755	.6706	1.0059	.9145	.7926	.945
Avg	1.0466	1.1660	1.2763	1.3286	1.2193	1.1164	1.2788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 203 / 11 KV Darekasa

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4268		.4268	.4877	.3658	.061
2	.3353	.4268		.4268	.4877	.3658	.061
3	.3353	.4268		.4268	.4877	.3658	.061
4	.3353	.4268	.3658	.4268	.4877	.3658	.061
5	.3353	.3963	.3658	.4268	.4877	.3658	.061
6	.3353	.3963	.3658	.4268	.4877	.3658	.061
7	.3353	.3658	.3658	.3658	.4572	.3048	.061
8	.3048	.3353	.3658	.3658	.4572	.3048	
9	.2743	.3353	.3658	.3658	.4268	.2743	.3353
10	.2439	.3048	.3658	.3658	.3963	.2743	.3353
11	.2439	.2743	.3658	.3353	.3963	.3048	.3048
12	.2439	.2743	.3658	.3353	.3658	.3048	.3048
13	.2439	.3048	.3353	.3353	.3658	.2743	.3048
14	.2439	.3048	.2743	.3658	.3048	.2743	.3353
15	.2439	.3353	.3048	.3658	.2743	.2743	.3353
16	.2743	.2743	.3048	.3658	.3048	.2743	.3048
17	.2743	.2743	.3353	.3658	.3048	.2743	
18	.3048	.3048	.3658	.3963	.3048	.3048	
19	.4268	.4572	.4877	.4877	.4877	.4572	.5182
20	.4877	.4877	.5182	.5487		.5182	.5487
21	.4877	.4877	.5182	.5487	.4268	.5182	.5792
22	.4572	.4877	.4877	.5487	.3963		.5487
23	.4572	.4877	.4877	.5182	.3658		.5182
24	.4268		.4572	.4877	.3658	.061	.4877
Max	.4877	.4877	.5182	.5487	.4877	.5182	.5792
Min	.2439	.2743	.2743	.3353	.2743	.061	.061
Avg	.3328	.3737	.3890	.4179	.4055	.3270	.2947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 204 / 11 KV Water Works  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.061	.0305	.0457	.061	.061	.0457
2	.061	.061	.0457	.0457	.061	.061	.061
3	.0762	.061	.0457	.0457	.061	.061	.061
4	.0762	.0762	.0457	.0457	.061	.0762	.061
5	.0762	.061	.0457	.0457	.0762	.0762	.061
6	.1067	.061	.061	.061	.0762	.0762	.061
7	.1524	.1372	.1372	.0914	.1524	.1524	.1372
8	.1524	.1524	.1524	.1524	.1524	.1524	.1372
9	.1524	.1372	.1372	.1372	.1524	.1524	.1372
10	.1524	.1524	.1372	.1372	.1372	.1524	.1372
11	.1524	.1372	.1372	.1372	.1524	.1372	.1372
12	.1524	.1372	.1372	.1372	.1372	.1372	.1372
13	.0762	.0762	.0762	.0914	.0762	.1524	.0762
14	.1524	.1372	.1372	.1372	.1372	.0762	.1372
15	.1524	.1372	.1524	.1524	.1524	.1372	.1524
16	.1524	.1524	.1524	.1524	.1524	.1372	.1524
17	.1372	.1524	.1524	.1524	.1524	.1524	.1981
18	.1372	.1372	.1524	.1524	.1524	.1524	.1981
19	.1372	.1524	.1524	.1524		.1372	.1524
20	.1524	.1372	.1524	.1372		.1524	.1372
21	.1372	.1372	.0762	.1524	.1524	.1372	.1372
22	.061	.0457	.0457	.061	.1524	.1372	.0305
23	.061	.0457	.0457	.061	.1524	.0762	.0305
24	.061	.0457	.061	.061	.0762	.061	.0305
Max	.1524	.1524	.1524	.1524	.1524	.1524	.1981
Min	.061	.0457	.0305	.0457	.061	.061	.0305
Avg	.1162	.1080	.1029	.1061	.1199	.1169	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 201 / Fulchur

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3108	1.3108	1.2193	1.2803	1.3108	1.1888	1.2803
2	1.1888	1.1584	1.1279	1.1584	1.1584	1.1279	1.2193
3	1.1584	1.1584	1.1888	1.1279	1.1584	1.0974	1.1584
4	1.1279	1.0974	1.1584	1.1279	1.1584	1.0974	1.1584
5	1.1279	1.0974	1.1584	1.0974	1.1279	1.0669	1.1888
6	1.1279	1.0669	1.0974	1.0974	1.1279	1.0669	1.1888
7	1.1279	.9755	.945	1.0364	1.0669	1.0669	1.1279
8	1.0059	.9145	.9145	.9755	.9755	1.0059	1.0364
9	1.0364	.9145	.884	.9755	1.0059	.945	.9755
10	.945	.884	.884	.884	1.0059	.945	.945
11	1.0669	1.1584	1.0364	1.0059	1.1584	1.1279	1.3108
12	.2743	1.2498	1.0974	1.0974	1.2803	1.1584	1.3413
13	.3658	1.2498	.2743	1.0669	1.2803	1.1888	1.4022
14	1.4022	1.1279	1.1888	1.0059	1.1888		1.4327
15	1.3108	1.0669	1.0364	1.0364	1.2193	1.3108	1.3108
16	1.2498	1.2498	1.1584	1.0974	1.1584	1.3717	1.3717
17	1.2193	1.2193	1.1279	1.0974	1.1888	1.3717	1.3413
18	1.2498	1.1279	1.0364	1.0669	1.2498	1.3108	
19	1.3413	1.2803	1.2193	1.2803	1.2498	1.5242	1.5546
20	1.3413	1.2498	1.2193	1.2803	1.2803	1.5242	1.5546
21	1.3108	1.2498	1.3108	1.3108	1.2803	1.4327	1.4022
22	1.3717	1.3413	1.3413	1.4022	1.3413	1.4937	1.4937
23	1.4327	1.3717	1.3413	1.4022	1.3413	1.4632	1.4632
24	1.3717	1.3108	1.3717	1.3108	1.3108	1.3413	1.4632
Max	1.4327	1.3717	1.3717	1.4022	1.3413	1.5242	1.5546
Min	.2743	.884	.2743	.884	.9755	.945	.945
Avg	1.1444	1.1596	1.0974	1.1342	1.1927	1.2273	1.2922

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 203 / 11kv Adasi  
Feeder KV- 11 / OUTGOING

SHEDDABLE RURAL

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.9755	1.0059	1.2803	1.2498	1.3108	1.3717
2	.7011	.9755	1.0059	1.2803	1.2193	1.3108	1.3717
3	.7011	.9755	.9755	1.2803	1.2193	1.3108	1.3717
4	.6706	.9755	1.0059	1.2803	1.2193	1.3413	1.3717
5	.6706	.9755	.9755	1.2803	1.2193	1.3413	1.4022
6	.7011	.9755	1.0059	1.2803	1.1584	1.3717	1.3717
7	.6401	.884	.945	1.0669	1.0974	1.3108	1.3108
8	.5487	.823	.945	1.0364	1.0669	1.2803	1.2803
9	.5792	.7926	.9755	1.1279	1.0669	1.2803	1.3108
10	.5792	.8535	1.0669	1.0059	1.0669	1.2498	1.3413
11	.6401	.8535	1.0974	1.0669	1.0974	1.1279	1.3413
12	.6706	.7621	1.0974	1.0059	1.0669	1.1888	1.4327
13	.6706	.5182	1.0974	.9145	1.0974	1.2193	1.4632
14	.7011	.823	1.1279	.9755	1.1584	1.1888	1.4327
15	.6706	.823	1.1279	1.0059	1.1584	1.2193	1.4022
16	.6706	.8535	1.1279	1.0669	1.0059	1.2498	1.3717
17	.6706	.823	1.0974	1.0364	1.0364	1.2803	
18	.6706	.823	1.0974	1.0974	1.1584		
19	1.0364	1.1584	1.2803	1.2498	1.4632	1.4022	1.768
20	1.0669	1.1279	1.3413	1.3108	1.5242	1.4937	1.7071
21	1.0974	1.1279	1.3717	1.3108	1.5242	1.5242	1.768
22	1.0669	1.1584	1.4022	1.3413	1.5242	1.5242	1.7375
23	1.0364	1.0364	1.3717	1.3108	1.4632	1.4632	1.6766
24	1.0059	1.0059	1.3108	1.2803	1.4632	1.4022	1.6156
Max	1.0974	1.1584	1.4022	1.3413	1.5242	1.5242	1.768
Min	.5487	.5182	.945	.9145	1.0059	1.1279	1.2803
Avg	.7570	.9208	1.1190	1.1622	1.2219	1.3214	1.4646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 201 / 11KV Dasgaon

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0204	1.1721	1.342	1.4586	1.5417	1.6339	1.9616
2	1.0021	1.1385	1.3314	1.4449	1.5143	1.6316	1.9547
3	1.0075	1.1416	1.3154	1.4548	1.5089	1.6232	1.9502
4	1.0181	1.1378	1.1546	1.4601	1.5097	1.6209	1.9433
5	1.0098	1.1264	1.1637	1.4609	1.5127	1.6187	1.9372
6	.9983	1.1225	1.198	1.4617	1.5318	1.6293	1.9319
7	.8238	.9122	1.0219	1.2978	1.3435	1.4815	1.7452
8	.6882	.7689	.916	1.2132	1.2018	1.2445	1.6049
9	.6501	.7545	.9633	1.198	1.2308	1.2955	1.5402
10	.6508	.7598	.9861	1.028	1.2948	1.3382	1.6248
11	.6851	.7499	1.0547	1.1408	1.323	1.5958	
12	.7606	.8551	1.1218	1.2109	1.2902	1.6171	1.3672
13	.8154	.9435	1.2094	1.249	1.3679	1.7314	1.5767
14	.8131	1.0197	1.182	1.2475	1.3085	1.7055	1.2193
15	.7575	1.0067	1.086	1.246	1.31	1.7086	.9282
16	.7926	1.0059	1.0822	1.1957	1.2452	1.7383	
17	.7888	.9831	1.1241	1.2239	1.243	1.7345	
18	.852	1.0326	1.1271	1.2506	1.262	1.8488	.5266
19	1.2285	1.3961	1.4868	1.5219	1.4982	1.9982	2.3137
20	1.3192	1.4937	1.627	1.611	1.6926	2.1056	2.3137
21	1.3275	1.5158	1.6484	1.6751	1.7779	2.1994	2.3152
22	1.3291	1.5005	1.6392	1.6469	1.7574	2.1719	2.3785
23	1.2559	1.4319	1.5508	1.6095	1.7223	2.0797	1.6011
24	1.1797	1.3664	1.5082	1.5676	1.6751	1.9852	1.5699
Max	1.3291	1.5158	1.6484	1.6751	1.7779	2.1994	2.3785
Min	.6501	.7499	.916	1.028	1.2018	1.2445	.5266
Avg	.9489	1.0973	1.2433	1.3698	1.4443	1.7224	1.7288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 202 / 11KV Dangurli Express NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1844	.192	.1814	.1821	.0937	.0934
2	.1856	.1707	.1844	.1738	.1818	.0926	.0934
3	.096	.0934	.096	.093	.0926	.0926	.0922
4	.0949	.0937	.0945	.0922	.0918	.0922	.093
5	.0968	.0934	.0972	.0934	.093	.0926	.0926
6	.0953	.0945	.0964	.093	.0934	.0926	.093
7	.0956	.093	.0956	.0926	.0922	.0251	.0914
8	.0347	.0023		.0312	.0111	.0099	.08
9	.0476	.0114	.0156	.0088	.0545	.0914	.0236
10	.0945	.0945	.0953	.0922	.0922	.0926	.0934
11	.0953	.0964	.096	.0926	.0907	.0922	.0922
12	.0953	.1452	.1879	.0914	.0911	.0903	
13	.1848	.1882	.1879	.1779	.0914	.093	.0941
14	.1619	.1886	.1692	.1703	.0907	.093	.0918
15	.096	.104	.0968	.0907	.093	.093	.0934
16	.0941	.0964	.0956	.0899	.0907	.0926	.0899
17	.0941	.0953	.0979	.0911	.0922	.0926	.0873
18	.093	.0953	.0956	.0911	.0926	.0914	.0888
19	.0953	.0953	.0956	.0907	.0903	.0899	.0941
20	.0838	.0918	.0846	.0644	.093	.04	.0541
21	.0431	.0404	.0503	.0701	.093	.0419	.0953
22	.0941	.0949	.0922	.093	.0922	.0941	.0968
23	.0941	.0972	.0922	.0945	.0926	.093	.0968
24	.1017	.101	.0914	.104	.093	.0918	.0972
Max	.1856	.1886	.192	.1814	.1821	.0941	.0972
Min	.0347	.0023	.0156	.0088	.0111	.0099	.0236
Avg	.1022	.1026	.1087	.0985	.0946	.0818	.0877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 203 / 11kv Birsola

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	1.2231	1.3314	1.4076	1.5447	1.6667	1.454
2	1.1302	1.217	1.3237	1.4083	1.5432	1.6811	1.4609
3	1.1271	1.2102	1.3131	1.4068	1.5409	1.6842	1.4586
4	1.1271	1.2033	1.3093	1.4045	1.5341	1.6941	1.4632
5	1.1233	1.1942	1.3161	1.4098	1.5524	1.7048	1.4777
6	1.1164	1.1919	1.31	1.3992	1.5798	1.7231	1.4883
7	1.1462	1.1591	1.3047	1.4045	1.6781	1.8572	1.5219
8	1.1713	1.2414	1.3154	1.4152	1.7032	1.9121	1.6446
9	1.1789	1.2628	1.3527	1.2673	1.64	1.9319	1.6324
10	1.1805	1.2772	1.4784	1.358	1.7619	1.4053	1.6606
11	1.1172	1.262	1.6911	1.3862	1.4502	1.3824	
12	1.2734	1.3062	1.7543	1.4396	1.5165	1.3938	1.3024
13	1.3344	1.3314	1.8389	1.4815	1.5577	1.438	1.5104
14	1.3176	1.3207	1.7703	1.5226	1.5912	1.4617	1.595
15	1.339	1.5912	1.8305	1.5173	1.5935	1.4373	1.5927
16	1.1629	1.5364	1.8496	1.4792	1.4723	1.4213	
17	1.105	1.6088	1.8176	1.4518	1.4952	1.4556	
18	1.4083	1.6735	1.7063	1.451	1.4883	1.4975	.5815
19	1.2818	1.4838	1.499	1.6209	1.6194	1.5676	1.8122
20	1.3214	1.512	1.544	1.653	1.6568	1.6545	1.7619
21	1.3222	1.4518	1.5455	1.6385	1.6522	1.6545	1.7589
22	1.3093	1.4228	1.5295	1.6263	1.3977	1.6225	1.6659
23	1.2651	1.3961	1.4822	1.547	1.3893	1.5813	1.6293
24	1.2361	1.3458	1.4281	1.5104	1.6034	1.4868	1.6049
Max	1.4083	1.6735	1.8496	1.653	1.7619	1.9319	1.8122
Min	1.105	1.1591	1.3047	1.2673	1.3893	1.3824	.5815
Avg	1.2179	1.3509	1.5267	1.4669	1.5651	1.5965	1.5275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 205 / 11kv Tumkheda Industrial SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.8855	.9556	.6051	.6843	.8596	.7285
2	.759	.8794	.9389	.663	.7316	.8383	.724
3	.8124	.8307	.9023	.6737	.7529	.8169	.7087
4	.8413	.7727	.852	.6904	.759	.8261	.7621
5	.8429	.8063	.8307	.6843	.7346	.7682	.8048
6	.7606	.8383	.9267	.6737	.7575	.791	.8139
7	.6691	.727	.82	.57	.6584	.695	.7514
8	.4893	.5914	.6828	.567	.5853	.57	.7575
9	.6508	.5182	.5472	.6523	.5777	.5639	.7026
10	.6112	.5152	.5258	.631	.4877	.506	.6539
11	.6859	.6981	.5807	.7423	.7392	.5106	.7438
12	.849	.6981	.8718	.8002	.8581	.6508	.9496
13	.9175	.7545	.8718	.9877	.7255	.7407	1.1309
14	.7773	.8322	.8459	.9709	.7179	.7255	1.1767
15	.6828	.7727	.7849	.8672	.6935	.7042	1.2224
16	.6722	1.0075	.7895	.8322	.8459	.6767	1.2711
17	.7042	.9953	.8063	.8048	.7621	.628	1.1767
18	.8017	.8932	.8139	.8078	.823	.6478	1.1767
19	.7712	.7865	.6904	.5777	.759	.5655	1.0014
20	.791	.6264	.5441	.7026	.788	.5838	.823
21	.6264	.5578	.5197	.602	.6493	.5426	.7865
22	.6493	.5563	.506	.538	.5838	.5411	.7087
23	.9267	.8551	.5533	.6859	.8703	.6142	.9175
24	.9145	.9389	.6005	.7026	.8505	.7285	.9252
Max	.9267	1.0075	.9556	.9877	.8703	.8596	1.2711
Min	.4893	.5152	.506	.538	.4877	.506	.6539
Avg	.7497	.7641	.7400	.7097	.7248	.6706	.8924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 206 / 11kv Kuradi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3106	2.6764	2.6795	3.0194	3.0742	2.4524	2.588
2	2.2405	2.5804	2.6459	2.9477	2.7191	2.4387	2.5789
3	2.2695	2.6155	2.6536	2.995	2.7389	2.4188	2.5606
4	2.2527	2.6155	2.649	2.966	2.7709	2.4234	2.556
5	2.2695	2.6139	2.6764	3.0041	2.8014	2.4508	2.5652
6	2.3	2.6216	2.6917	3.0133	2.8319	2.4661	2.6749
7	2.0805	2.4524	2.4905	2.7755	2.4493	2.2664	2.5072
8	1.6964	2.1521	2.2756	2.4356	2.3	1.7314	2.3213
9	1.7208	2.1171	2.1308	2.3777	2.3198	1.8701	2.2786
10	1.6583	1.7924	2.0393	2.2756	2.332	1.8961	2.2405
11	1.579	1.8793	2.1795	2.2634	2.1491	1.8442	2.2314
12	1.5973	2.0119	2.0866	2.2314	2.3304	1.9799	2.2878
13	1.6049	2.0469	1.9311	2.2832	2.3762	1.7878	2.3152
14	1.6674	2.1003	1.9631	2.1994	2.1049	1.9875	2.3213
15	1.6933	2.0561	2.1978	2.2542	2.0332	1.989	2.2466
16	1.6415	1.9357	2.3442	2.3335	1.547	1.9707	2.2131
17	1.7314	1.9281	2.3564	2.3884	1.733	1.9616	
18	1.8077	1.6537	2.2481	2.4066	1.8442	2.0713	2.6719
19	2.7481	2.7968	3.0636	3.0971	2.5591	2.6947	3.5101
20	2.9127	2.9645	3.2266	3.2312	2.6749	2.8822	3.6199
21	2.899	2.9843	3.2465	3.2998	2.7191	2.905	3.5848
22	2.9462	2.9935	3.3074	3.3699	2.6947	2.8548	3.565
23	2.8441	2.9279	3.1855	3.2236	2.5911	2.7877	3.405
24	2.7313	2.7572	3.062	3.1123	2.4935	2.6277	3.283
Max	2.9462	2.9935	3.3074	3.3699	3.0742	2.905	3.6199
Min	1.579	1.6537	1.9311	2.1994	1.547	1.7314	2.2131
Avg	2.1334	2.3864	2.5554	2.7293	2.4245	2.2816	2.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 402 / 33 kv Gondia ckt-1

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.9442	5.9442	5.9442	6.4015	6.4015	6.4015	6.4015
2	5.487	5.487	5.9442	5.9442	5.9442	5.9442	5.9442
3	5.0297	5.487	5.487	5.9442	5.9442	5.9442	5.9442
4	5.0297	5.487	5.487	5.487	5.487	5.487	5.9442
5	5.0297	5.0297	5.487	5.487	5.487	5.487	5.487
6	5.0297	5.0297	5.0297	5.487	5.487	5.487	5.487
7	5.0297	5.0297	5.0297	5.0297	5.487	5.487	5.487
8	5.0297	5.0297	5.0297	5.0297	5.487	5.487	5.487
9	5.0297	5.487	5.0297	5.487	5.9442	5.0297	5.0297
10	5.0297	5.0297	5.0297	5.0297	5.487	5.0297	5.0297
11	5.487	5.487	5.487	5.487	5.9442	5.9442	5.9442
12	5.9442	5.9442	5.487	5.9442	6.4015	6.4015	6.4015
13	5.9442	5.9442	5.487	6.4015	6.8587	5.9442	6.4015
14	5.9442	5.9442	5.487	5.9442	6.8587	6.8587	6.8587
15	5.9442	5.9442	5.487	5.9442	6.4015	6.4015	6.8587
16	6.4015	5.9442	5.487	6.4015	4.1152	6.8587	6.8587
17	6.4015	5.9442	5.487	6.4015	6.8587	6.8587	6.8587
18	6.4015	5.9442	5.0297	6.4015	6.4015	6.4015	6.4015
19	7.316	7.316	5.9442	7.316	7.316	7.7732	7.316
20	7.316	7.316	6.4015	7.316	7.316	7.7732	7.7732
21	6.8587	6.8587	5.9442	7.316	7.316	7.7732	7.7732
22	6.4015	6.4015	6.4015	6.8587	6.8587	7.316	6.8587
23	6.4015	6.4015	6.8587	6.8587	6.8587	7.316	7.316
24	6.4015	6.4015	6.8587	6.8587	6.8587	7.316	6.8587
Max	7.316	7.316	6.8587	7.316	7.316	7.7732	7.7732
Min	5.0297	5.0297	5.0297	5.0297	4.1152	5.0297	5.0297
Avg	5.8680	5.8680	5.6394	6.1157	6.2300	6.3634	6.3634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 203 / 11 KV Gangazari

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3262	.4405	.4496	.4428	.4626	.4603	.4443
2	.3262	.4351	.4473	.4412	.4595	.458	.4412
3	.3269	.4313	.4443	.4397	.4572	.458	.4405
4	.3246	.4329	.4298	.4397	.458	.4565	.439
5	.3285	.4298	.4047	.439	.4588	.4557	.4382
6	.3262	.4252	.3986	.4428	.4641	.4565	.4405
7	.3239	.4092	.394	.4306	.4603	.4534	.4489
8	.314	.3795	.4146	.4199	.4557	.4374	.4412
9	.3155	.3765	.3643	.4077	.4557	.4153	.4512
10	.3277	.3528	.3871	.4138	.4405	.3841	.4489
11	.3307	.3536	.4047	.3993	.4092	.41	.4458
12	.3521	.3071	.4062	.4001	.41	.3422	.4214
13	.3513	.2934	.4016	.4115	.4443	.2126	.3628
14	.2987	.3086	.3551	.4016	.3826	.2157	.3765
15	.298	.2698	.381	.4016	.3963	.2195	.3757
16	.3338	.3048	.3399	.4146	.2408	.4336	.1326
17	.3788	.3193	.3528	.4283	.3338	.4443	
18	.3856	.3795	.378	.4176	.4458	.458	
19	.4047	.407	.3894	.4115	.4725	.4824	.4679
20	.4496	.4893	.4557	.4687	.4893	.5396	.5289
21	.4466	.4748	.458	.4656	.4832	.5335	.5266
22	.4481	.4748	.4519	.4755	.4862	.519	.5327
23	.442	.4534	.4496	.4725	.4793	.4572	.5228
24	.442	.4557	.4451	.4702	.4672	.4519	.5106
Max	.4496	.4893	.458	.4755	.4893	.5396	.5327
Min	.298	.2698	.3399	.3993	.2408	.2126	.1326
Avg	.3584	.3918	.4085	.4315	.4380	.4231	.4381

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 401 / 33 KV RAWANWADI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4577	2.7892	3.1207	2.2291	2.1605	2.1148	1.989
2	2.3548	2.7092	2.995	2.2177	2.0805	2.0119	1.8976
3	2.2634	2.6635	2.9264	2.1834	2.0348	1.9547	1.8404
4	2.2519	2.7549	2.8349	2.1376	1.9433	1.8404	1.7604
5	2.2291	2.7549	2.8235	2.0005	1.8861	1.8404	1.7375
6	2.1605	2.7664	2.8692	2.1033	1.8404	1.909	1.749
7	2.332	2.7206	2.8578	2.0348	1.8976	1.8633	1.7261
8	2.2748	2.6177	2.7778	1.9319	1.829	1.8176	1.6461
9	2.1719	2.5949	2.6635	1.7718	1.6918	1.7375	1.5661
10	2.1719	2.5377	2.6635	1.6575	1.7375	1.6575	1.4175
11	2.1262	2.5034	2.6978	1.7147	1.8176	1.7718	1.5889
12	2.2177	2.3777	2.7549	1.7261	1.8519	1.7375	1.6232
13	2.1605	2.3891	1.749	1.7261	1.8519	1.8747	1.6004
14	1.6804	1.9776	1.8061	1.7032	1.8976	1.829	1.6461
15	2.1719	2.2977	1.7147	1.7261	1.8061	1.7147	1.6347
16	2.2977	2.5149	1.8747	1.8404	1.6232	1.7604	1.6232
17	2.332	2.4691	1.8976	1.909	1.6918	1.7718	2.1148
18	2.3205	2.5377	1.8519	1.909	1.7147	1.749	2.2177
19	2.4806	2.6749	1.7718	1.8747	1.7718		2.332
20	3.0407	3.155	2.0233	2.0233	2.1262		2.7092
21	2.995	3.075	2.1376	2.0805	2.1719	2.0462	2.8578
22	3.0636	3.1664	2.3091	2.2062	2.2977	2.1834	2.995
23	3.0407	3.3608	2.3205	2.2748	2.2519	2.2519	3.0407
24	2.9721	3.2922	2.2862	2.2634	2.2291	2.1605	3.0064
Max	3.0636	3.3608	3.1207	2.2748	2.2977	2.2519	3.0407
Min	1.6804	1.9776	1.7147	1.6575	1.6232	1.6575	1.4175
Avg	2.3987	2.6959	2.4053	1.9685	1.9252	1.8908	2.0133

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 201 / Town - I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.893	1.9387	2.0058	2.0576	2.0759	1.9966	2.1445
2	1.7101	1.8031	1.8595	1.9433	1.9098	1.8823	1.9418
3	1.6339	1.7116	1.7604	1.8244	1.8336	1.7985	1.8717
4	1.6126	1.6735	1.7101	1.7543	1.7817	1.7482	1.7802
5	1.6049	1.6491	1.6583	1.7147	1.7253	1.7238	1.7513
6	1.6095	1.6339	1.6446	1.7025	1.7436	1.6735	1.7635
7	1.6065	1.6263	1.5973	1.6811	1.7635	1.7269	1.7391
8	1.6583	1.6568	1.6339	1.6964	1.7589	1.7284	1.733
9	1.6354	1.5546	1.6171	1.6217	1.669	1.6857	1.6446
10	1.7604	1.8823	1.6857	1.7726	1.7955	1.7269	1.6933
11	2.1353	1.861	1.8077	2.0896	2.178	2.0774	2.1902
12	2.5484	2.3609	2.0866	2.5179	2.6703	2.7069	2.6932
13	2.62	2.463	2.146	2.7496	2.8304	2.777	2.7481
14	2.6764	2.4691	2.1277	2.7846	2.902	2.8807	2.8837
15	2.6566	2.4265	2.0591	2.7374	2.8075	2.7831	2.9828
16	2.6978	2.4097	1.9845	2.7953	2.7145	2.8365	3.0026
17	2.6322	2.4173	1.9387	2.7465	2.7328	2.841	2.9188
18	2.6033	2.4066	1.8046	2.6871	2.6947	2.7404	2.8166
19	2.8502	2.7709	1.9128	2.934	2.9157	2.9889	3.0636
20	3.0819	3.0514	2.0774	3.12	3.0437	3.1763	3.1596
21	2.9081	2.9005	1.9906	2.9416	2.8487	3.0788	3.0986
22	2.5499	2.4783	1.8762	2.5194	2.4783	2.6764	2.6139
23	2.0972	2.1171	2.1049	2.1826	2.1338	2.2893	2.2283
24	2.0774	2.1064	2.0911	2.1917	2.1216	2.268	2.2527
Max	3.0819	3.0514	2.146	3.12	3.0437	3.1763	3.1596
Min	1.6049	1.5546	1.5973	1.6217	1.669	1.6735	1.6446
Avg	2.2025	2.1404	1.8825	2.2819	2.2970	2.3255	2.3632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 202 / Town - II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5286	2.6444	2.71	2.7664	2.774	2.7999	2.9401
2	2.3243	2.4508	2.6246	2.6017	2.5819	2.5819	2.6368
3	2.1171	2.3533	2.4326	2.4326	2.4021	2.4356	2.4722
4	2.0805	2.2908	2.396	2.396	2.3213	2.3167	2.428
5	2.0454	2.2466	2.3045	2.3335	2.2893	2.2619	2.3533
6	2.0424	2.1994	2.2253	2.2542	2.2558	2.2436	2.2588
7	2.0698	2.1155	2.1795	2.2603	2.2375	2.2329	2.2573
8	2.1293	2.1277	2.1155	2.2253	2.2451	2.2542	2.2177
9	2.0851	2.1033	2.0942	2.1735	.8048	2.1887	2.1917
10	2.0424	2.0317	2.0027	2.1262	2.6185	2.0287	2.1064
11	1.9631	2.0287	1.9875	2.0729	2.3487	2.0866	2.0637
12	2.0409	2.1994	2.1567	2.0957	2.3289	2.1323	2.2222
13	2.1567	2.1917	2.2039	2.1689	2.3472	2.1856	2.2603
14	2.1994	2.0881	2.2253	2.1506	2.3396	2.1338	2.3243
15	2.1628	2.0911	2.178	2.1902	2.3304	2.4097	2.3609
16	2.1582	2.1445	2.2253	2.2009	2.2969	2.3198	2.431
17	2.2908	2.1628	2.1536	2.2024	1.8839	2.463	2.4905
18	2.2695	2.1201	2.1277	2.1521	2.5682	2.4036	2.3564
19	2.2832	2.1323	2.0835	2.1978	2.3746	2.3304	2.332
20	2.6322	2.6185	2.5301	2.6444	2.6581	2.6353	2.6642
21	2.6048	2.6017	2.5103	2.6886	2.6475	2.6414	2.5911
22	2.5514	2.5743	2.4478	2.6109	2.5682	2.5697	2.6231
23	2.5789	2.6109	2.5484	2.6978	2.7039	2.7633	2.7145
24	2.6658	2.6856	2.7816	2.8014	2.806	2.9645	2.8502
Max	2.6658	2.6856	2.7816	2.8014	2.806	2.9645	2.9401
Min	1.9631	2.0287	1.9875	2.0729	.8048	2.0287	2.0637
Avg	2.2509	2.2839	2.3019	2.3518	2.3639	2.3910	2.4228

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 203 / Town - III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9983	1.0562	1.0974	1.0867	1.0974	1.0898	1.1172
2	.977	1.0197	1.0471	1.0654	1.0517	1.0471	1.0684
3	.9556	.9938	1.0044	1.0425	1.038	1.0303	1.0364
4	.9465	.9785	.9877	1.0258	1.0197	1.0242	1.0319
5	.9526	.9694	.9861	1.0227	1.0136	1.0166	1.0273
6	.9587	.9892	1.0014	1.0425	1.0425	1.0471	1.0578
7	1.0197	.9983	1.0014	1.0776	1.07	1.0715	1.0593
8	1.0151	1.0105	.9983	1.0517	1.0517	1.0425	1.0593
9	.9861	.9968	.9678	.9953	1.012	.9602	.9998
10	.9572	1.0044	.9892	.977	.9892	.9465	1.0044
11	.9038	.9922	.9541	.9054	.9114	.8993	.948
12	.8459	.9313	.9054	.8398	.8749	.8551	.8398
13	.8124	.8993	.9099	.8109	.8581	.849	.8535
14	.7849	.8749	.8871	.7834	.8596	.8169	.8322
15	.7788	.8581	.8688	.7773	.8505	.8307	.8429
16	.8017	.8718	.8657	.8322	.8337	.8505	.8703
17	.8185	.8383	.8566	.8139	.8352	.8657	.8444
18	.8429	.8215	.8444	.82	.8307	.8566	.8459
19	1.0989	1.0776	1.0456	1.0562	1.0928	1.0822	1.0943
20	1.1782	1.1584	1.1645	1.1629	1.1553	1.2026	1.1767
21	1.134	1.1477	1.1355	1.1706	1.1782	1.2315	1.1843
22	1.1599	1.1736	1.1492	1.2041	1.2285	1.2711	1.2315
23	1.1888	1.1904	1.1904	1.2239	1.2407	1.294	1.2407
24	1.1294	1.1568	1.1706	1.1645	1.1843	1.2148	1.1965
Max	1.1888	1.1904	1.1904	1.2239	1.2407	1.294	1.2407
Min	.7788	.8215	.8444	.7773	.8307	.8169	.8322
Avg	.9685	1.0004	1.0012	.9980	1.0133	1.0165	1.0193

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 204 / Town - IV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0278	3.152	3.3742	.0518	.0495	1.8503	2.9237
2	2.9279	3.0323	3.1074	.0518	.0507	1.7276	2.827
3	2.8257	2.8555	3.1077	.0507	.0488	1.6583	2.6794
4	2.5297	2.5727	2.9569	.0495	.0488	1.6293	2.7511
5	2.4638	2.6924	2.9168	.0492	.048	1.5783	2.8052
6	2.5191	2.5141	2.8947	.0465	.0488	1.5638	2.7903
7	2.7081	2.7382	2.9207	.0396	.0461	1.5394	3.0122
8	2.6909	2.8532	2.8811	.0168	.0057	1.4586	2.9275
9	2.8238	2.9614	2.9367	.003		1.3801	2.8883
10	2.769	2.7633	2.8783	.0027	.0027	1.3519	2.8235
11	2.833	2.7504	2.9896	.0415	.032	1.3588	3.0122
12	2.7489	2.7763	3.014	.0431	.0427	1.3504	2.8776
13	2.6776	2.883	2.958	.0484	.0412	1.3824	2.8223
14	2.6391	2.6231	2.7339	.0434	.0434	1.2856	3.025
15	2.8601	2.7237	2.9478	.0461	.0442	1.3786	3.1048
16	2.8883	2.7976	2.9279	.0412	.0419	1.4464	3.169
17	2.8601	2.7611	2.8354	.0305	.0412	1.4914	3.0746
18	2.9149	2.7999	2.9733	.0366	.0404	1.4594	2.862
19	3.0293	2.8693	2.9858	.0404	.0453	1.643	2.9523
20	3.2975	3.1131	3.086	.045	.0499	1.9319	3.203
21	3.1234	2.9355	2.9782	.0492	.0533	2.0226	3.2194
22	3.0529	3.0354	2.87	.0572	.0553	2.127	3.0887
23	3.3044	3.2793	3.3028	.0568	.0545	2.1956	3.3958
24	3.2685	3.2846	3.3898	.0572	.0526	2.1818	3.5002
Max	3.3044	3.2846	3.3898	.0572	.0553	2.1956	3.5002
Min	2.4638	2.5141	2.7339	.0027	.0027	1.2856	2.6794
Avg	2.8660	2.8653	2.9986	.0416	.0429	1.6247	2.9890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 202 / Urban industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.3384	.125	.2865	.3559	.2964	.1943
2	.4252	.3429	.1097	.2911	.3582	.2172	.141
3	.4298	.3125	.3079	.2926	.314	.2126	.1402
4	.4428	.3269	.3094	.2919	.2843	.2157	.0671
5	.3955	.2789	.3193	.1181	.2675	.2088	.0541
6	.3788	.202	.3041	.1189	.2583	.1044	
7	.33	.157	.3117	.1227	.1456	.1036	
8	.1943	.1135	.3262	.1189	.1052	.109	.0259
9	.1829	.077	.1799	.0663	.093		.0709
10	.1357	.1029	.202	.0229	.109	.0747	.1494
11	.2736	.2362	.2065	.2088	.189	.1486	.2119
12	.3086	.3048	.3795	.3559	.3239	.1791	.3056
13	.423	.3528	.3658	.5677	.298	.2919	.5418
14	.5182	.3521	.3323	.5952	.333	.3033	.5708
15	.4915	.2751	.3132	.5784	.3612	.2873	.5815
16	.586	.3932	.3262	.5449	.3704	.3818	.5845
17	.5807	.4169	.333	.519	.4656	.4001	.5624
18	.5586	.3795	.3208	.4824	.4626	.349	.49
19	.4565	.3704	.269	.3201	.4138	.285	.3978
20	.3871	.2843	.1837	.2141	.3582	.032	.2355
21	.3429	.2286	.1532	.1821	.1547		.1417
22	.2835	.208	.1456	.1654	.1661		.0686
23	.2865	.2149	.2705	.2812	.1753	.0937	.1326
24	.2995	.1509	.2858	.2522	.3224	.1859	.1379
Max	.586	.4169	.3795	.5952	.4656	.4001	.5845
Min	.1357	.077	.1097	.0229	.093	.032	.0259
Avg	.3777	.2675	.2658	.2916	.2786	.2133	.2639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 203 / Manohar Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6059	.6257	.6379	.66	.6447
2		.5799	.5868	.615	.6097	.6043
3		.5586	.5556	.5784	.5799	.5799
4		.5365	.5335	.5685	.5624	.5685
5		.5251	.5182	.5533	.5456	.5609
6		.519	.5258	.5449	.5396	.5563
7		.5152	.5121	.5396	.5632	.5601
8		.5502	.5456	.567	.5472	.5655
9		.5197	.522	.5243	.519	.519
10		.5312	.5304	.5007	.4931	.5121
11		.503	.5213	.4801	.487	.5014
12		.5274	.5136	.4733	.503	.5083
13	.4435	.4938	.5312	.5037	.5426	.4946
14	.4877	.5007	.5296	.4847	.5159	.4816
15	.4702	.5083	.5213	.503	.5441	.4793
16	.4999	.5152	.5083	.4938	.5022	.5289
17	.5136	.5121	.4954	.4763	.4915	.519
18	.4649	.4809	.4611	.4793	.4786	.7141
19	.5479	.4824	.5296	.535	.5449	1.7147
20	.6043	.5944	.5929	.5914	.5982	1.7772
21	.5944	.5693	.5876	.6059	.612	
22	.6257	.6287	.6554	.6539	.7064	
23	.6584	.6912	.7057	.7049	.7453	
24	.6577	.6973	.6943	.7064	.7125	
Max	.6584	.6973	.7057	.7064	.7453	1.7772
Min	.4435	.4809	.4611	.4733	.4786	.4793
Avg	.5474	.5478	.5543	.5551	.5668	.6695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 201 / Chotta Gondia

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1151	.0457	.1166	.1478	.1029	.0175
2	.1052	.1128	.0351	.1196	.1463	.1006	.0122
3	.1052	.1158	.0343	.1204	.1463	.1036	.0122
4	.1036	.1143	.0373	.1196	.1456	.1014	.0122
5	.1059	.1196	.0572	.1212	.1463	.1029	.013
6	.0511	.1189	.032	.1219	.1235	.1105	.0373
7	.0587	.1158	.0267	.1151	.1166	.1067	.0297
8	.109	.0221	.0038	.0412	.1052	.0998	.0061
9	.1075	.0084		.0221	.1006	.0953	.0084
10	.1006	.0053			.0968	.0145	
11	.0975				.0495	.093	
12	.1044				.0732	.0861	
13	.0914	.0343			.0465	.0213	
14	.0991	.0861		.0069	.0114	.0015	
15	.0556			.0168			
16	.0968	.109		.0922		.0008	
17	.0991	.1075		.0945		.0046	.0008
18	.1052	.1044		.1082		.0023	.0053
19	.1189	.1174		.1189	.0823		.0579
20	.1189	.1257	.0282	.1242	.1082	.0191	.0762
21	.1158	.1181	.1227	.1547	.1128	.0831	.048
22	.1166	.125	.1212	.16	.1189	.0823	.045
23	.1174	.125	.1235	.1578	.1143	.0648	.0671
24	.1135	.0739	.1181	.1471	.1044	.0259	.0869
Max	.1189	.1257	.1235	.16	.1478	.1105	.0869
Min	.0511	.0053	.0038	.0069	.0114	.0008	.0008
Avg	.1001	.0940	.0604	.1040	.1048	.0647	.0315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 202 / Govindpur

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6621	1.0562	1.1835	1.1934	1.23	1.2155	1.8023
2	1.5874	1.0128	1.1241	1.1949	1.1767	1.1446	1.7162
3	1.5463	1.0471	1.1027	1.1812	1.1431	1.1119	1.6507
4	1.5341	1.0867	1.0098	1.134	1.1043	1.0319	1.5859
5	1.4845	1.0989	1.0418	1.0265	1.0425	1.0235	1.6019
6	1.4518	1.0943	1.0913	1.1203	1.0288	1.086	1.5546
7	1.6049	1.0959	1.0844	1.1088	1.0905	1.0943	1.5546
8	1.5562	1.0722	1.0395	1.1401	.9732	1.0631	1.4792
9	1.4518	1.0791	.916	.9785	.8893	.9335	1.3717
10	1.438	1.038	.9061	.8901	.8939	.8878	1.31
11	1.3535	.9838	.9465	.9175	.9549	.8939	1.4792
12	1.4335	.9122	.9701	.8893	.9549	.8665	1.4723
13	1.1119	.9107	.9404	.9084	1.0181	.9968	1.5051
14	.9579	.948	.9595	.8924	1.0692	.8993	1.5135
15	.9419	.9884	.9938	.9793	.9694	.881	1.5051
16	.9777	1.0189	1.0219	.9877	.8924	.9061	1.5524
17	.9838	.9945	1.0235	1.0128	.9678	.9191	1.5485
18	.9259	.9678	.9785	1.0425	.9854	.8939	1.5181
19	1.0235	1.1035	1.0219	1.0822	1.1485		1.6728
20	1.1134	1.1713	1.089	1.1195	1.1736	.6622	1.7939
21	1.0966	1.0837	1.1081	1.1233	1.1789	1.8328	1.8435
22	1.1294	1.1378	1.2186	1.2445	1.2651	1.9456	1.9433
23	1.1591	1.249	1.2536	1.3062	1.3032	1.9997	1.9669
24	1.1149	1.2407	1.2247	1.307	1.2803	1.9326	1.9067
Max	1.6621	1.249	1.2536	1.307	1.3032	1.9997	1.9669
Min	.9259	.9107	.9061	.8893	.8893	.6622	1.31
Avg	1.2767	1.0580	1.0521	1.0742	1.0723	1.1401	1.6187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 203 / Vijaynagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5929	1.48	1.5889	.6996	.6569	.6485	
2	.5815	1.4487	1.5379	.6767	.6432	.6302	
3	.5487	1.4281	1.4982	.66	.6394	.6142	
4	.5365	1.4198	1.48	.6432	.583	.5914	
5	.5556	1.4137	1.4769	.6363	.5906	.5754	
6	.5624	1.4304	1.4899	.6508	.5883	.6036	
7	.5624	1.3999	1.4655	.6348	.5799	.554	
8	.5327	1.3535	1.4388	.5792	.5472	.538	
9	.5708	1.3176	1.4167	.5944	.6036	.567	
10	.5868	1.2872	1.4586	.6097	.6226	.5617	
11	.6569	1.3344	1.4662	.6706	.7095	.6889	
12	.6607	1.2803	1.4853	.7339	.7285	.679	
13	.66	1.2841	.5975	.7011	.7042	.7468	
14	.5898	.8162	.6325	.6798	.6661	.7727	
15	1.0341	1.0494	.5548	.631	.6775	.6783	
16	1.1858	1.3077	.6394	.6683	.5784	.695	
17	1.2087	1.2452	.6447	.6813	.6074	.6851	.5274
18	1.2216	1.3466	.6417	.6668	.5807	.6615	.7133
19	1.3161	1.3763	.6615	.6584	.5639	.4306	.7263
20	1.6453	1.6331	.6683	.6836	.6904	.0236	.7758
21	1.611	1.6042	.7156	.695	.7316		.8139
22	1.6636	1.6415	.7613	.7179	.7453		.8825
23	1.627	1.7025	.7346	.7125	.724		.8772
24	1.5889	1.6674	.7232	.6821	.6851		.8429
Max	1.6636	1.7025	1.5889	.7339	.7453	.7727	.8825
Min	.5327	.8162	.5548	.5792	.5472	.0236	.5274
Avg	.9292	1.3862	1.0741	.6653	.6436	.5973	.7699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810]

BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 202 / 11 KV Mundipar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9938	1.2163	1.6949	1.9692	1.9662	1.9098	2.3472
2	.9739	1.214	1.7147	1.9738	1.9845	1.9166	2.3602
3	.9717	1.2148	1.704	1.957	1.9723	1.8953	2.3556
4	.9351	1.2026	1.6872	1.9532	1.9715	1.9128	2.3518
5	.9381	1.1919	1.6811	1.954	1.9646	1.906	2.3548
6	.9305	1.1759	1.6773	1.7894	1.9494	1.8907	2.1895
7	.7804	1.0677	1.528	1.7383	1.8618	1.7977	2.1742
8	.7247	.98	1.3344	1.7688	1.7917	1.8877	2.0767
9	.676	1.1142	1.4236	1.8176	1.4861	1.9791	2.13
10	.7369	1.1629	1.6324	1.874	1.576	2.0652	2.242
11	.7308	1.1911	1.6987	1.9326	1.5943	2.0942	2.3
12	.7354	1.1698	1.7002	1.8801	1.797	2.1437	2.4425
13	.8284	1.1995	1.7261	1.6156	1.9098	2.2481	2.508
14	.8741	1.2856	1.4693	1.6956	1.906	2.2626	2.5332
15	.5822	1.2277	1.6263	1.7215	1.6949	2.2984	2.5377
16	.6104	1.2651	1.6453	1.5775	1.7208	2.2794	
17	.8383	1.2955	1.7116	1.5722	1.6583	2.319	
18	.865	1.3123	1.7589	1.6933	1.7063	2.3762	
19	1.2422	1.5897	1.9601	1.9913	1.9441	2.4204	2.9439
20	1.403	1.7772	2.0866	2.0881	1.9845	2.5111	3.0194
21	1.371	1.7917	2.1155	2.0881	2.0134	2.524	2.9698
22	1.3489	1.797	2.1178	2.0835	2.0088	2.4851	2.9523
23	1.2841	1.7535	2.0622	2.0279	1.9791	2.4425	2.8418
24	1.2361	1.7238	1.9959	1.9936	1.9326	2.3762	2.7824
Max	1.403	1.797	2.1178	2.0881	2.0134	2.524	3.0194
Min	.5822	.98	1.3344	1.5722	1.4861	1.7977	2.0767
Avg	.9421	1.3300	1.7397	1.8648	1.8489	2.1642	2.4959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 201 / 11KV Dhapewada

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.4937	1.6766	1.9814	1.768	1.89	1.9204
2	1.0669	1.4937	1.6766	1.9509	1.8595	1.8595	1.89
3	1.0669		1.6766	1.9509	1.829	1.8595	1.89
4	1.0669		1.6766	1.9509	1.829	1.8595	1.89
5	1.0669	.4268	1.6766	1.9509	1.829	1.89	1.768
6	1.0669	.3658	1.6766	1.9509	1.829	1.8595	1.768
7	.9145	.3353	1.5851	1.768	1.6156	1.7375	1.7071
8	.9145	1.2193	1.3717	1.7071	1.5242	1.5242	1.768
9	.9145	1.2803	1.4327	1.6461	1.5546	1.5242	1.7375
10	.945	1.3717	1.4632	1.6766	1.6156	1.5242	1.829
11	.9755	1.3717	1.7071	1.7071	1.5242		
12	1.0974	1.2498	1.7375	1.6461	1.5851	.823	
13	1.1888		1.7375	1.6461	1.6461	1.4327	
14	1.1584	1.3717	1.6461	1.6156	1.4937	1.6156	1.8595
15	1.0974	1.4632	1.7071	1.6156	1.6156	1.5851	1.7985
16	1.1279	1.4937	1.6156	1.6461	1.5546	1.6156	
17	1.1584	1.4022	1.5546	1.5546	1.5546	1.5546	
18	1.2498	1.3717	1.6766	1.6461	1.7071	1.7071	
19	1.5851	1.768	1.9814	1.9814	1.8595	2.2558	2.4691
20	1.5851	1.768	2.0729	1.9509	1.9204	2.2558	2.4082
21	1.5851	1.768	2.0729	1.9204	1.9814	2.3472	2.4082
22	1.6156	1.7375	2.0424	1.89	1.89	2.2862	2.4082
23	1.4937	1.7071	1.9509	1.89	1.9509	2.1948	2.2862
24	1.4937	1.6766	1.9509	1.8595	1.89	2.1033	2.2558
Max	1.6156	1.768	2.0729	1.9814	1.9814	2.3472	2.4691
Min	.9145	.3353	1.3717	1.5546	1.4937	.823	1.7071
Avg	1.1876	1.3398	1.7236	1.7960	1.7261	1.7959	2.0034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 203 / 11kv MIDC jackwell water  
works Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	02-SEP-17
HR	Load (MW)
17	.0015
Max	.0015
Min	.0015
Avg	.0015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 204 / 11 KV AGP Dhapewada  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1524	.1524	1.0669	1.1431	1.0669	1.1431
2	.0762	.1524	.1524	1.0669	1.1431	1.0669	1.1431
3	.0762	.1524	.1524	.9907	1.1431	1.0669	1.1431
4	.0762	.1524	.1524	.9907	1.1431	1.0669	1.1431
5	.0762	.1524	.1524	.9907	1.1431	1.0669	1.1431
6	.0762	.1524	.1524	1.0669	1.1431	1.1431	1.1431
7	.0762	.0762	.1524	1.0669	1.2193	1.1431	1.2193
8	.0762	.0762	.1524	1.0669	1.2193	1.2193	1.2193
9	.0762	.0762	.1524	1.1431	1.2193	1.2193	1.2193
10	.6097	.9145	1.0669	.8383	.9145	.9145	.9145
11	.6097	.9907	1.1431	.1524	.2286	.2286	
12	.8383	.9145	1.1431	.1524	.2286	.2286	.1524
13	.8383	.4572	.6859	.1524	.2286	.1524	.2286
14	.8383	.9907	1.0669	.1524	.2286		.1524
15	.9145	.9907	.6859	.1524	.2286		.1524
16	.9145	.9907	1.1431	.1524	.2286	.0762	.2286
17	.9145	.9907	1.0669	.0762	.2286	.1524	.2286
18	.6859	.8383	.8383	.1524	.2286	.2286	.2286
19	.1524	.1524	.1524	.2286	.1524	.2286	.2286
20	.1524	.1524	.1524	.2286	.1524	.2286	.2286
21	.1524	.1524	.1524	.2286	.1524	.2286	.2286
22	.1524	.1524	.1524	.2286	.1524	.2286	.2286
23	.1524	.1524	.1524	.2286	.1524	.2286	.2286
24	.1524	.1524	.6859	1.1431	1.0669	1.1431	1.0669
Max	.9145	.9907	1.1431	1.1431	1.2193	1.2193	1.2193
Min	.0762	.0762	.1524	.0762	.1524	.0762	.1524
Avg	.3652	.4223	.4858	.5715	.6287	.6512	.6527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 203 / 11KV Mandvi

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0775	.0835	.103	.1149	.1245	.1087	.116
2	.0773	.083	.0956	.1141	.1231	.1076	.1094
3	.077	.0825	.0952	.113	.1226	.1075	.1111
4	.0761	.0824	.0941	.1125	.1222	.1069	.112
5	.0757	.0813	.0971	.1146	.1218	.1074	.1132
6	.0751	.0827	.0955	.1136	.1215	.1067	.1122
7	.064	.0675	.0788	.1043	.1018	.1014	.1008
8	.0473	.0569	.0639	.0797	.0894	.0987	.1088
9	.0462	.0578	.0649	.0841	.0945	.1151	.0892
10	.0465	.0666	.0793	.0811	.0992	.1072	.1023
11	.0536	.064	.0834	.0776	.0938	.1082	.1041
12	.0545	.063	.077	.0801		.0984	.1074
13	.0566		.0852			.1218	.1121
14	.0456		.0837			.0935	.0954
15	.0525		.0826			.064	.1006
16	.0536	.0568	.0827		.0605	.0575	
17	.0525		.0783	.0565	.0829	.0416	
18	.0498	.0739	.0762	.0763	.0918	.0484	.0927
19	.0886	.1165	.1207	.1222	.1206	.0917	.1617
20	.0957	.1108	.1286	.13	.1227	.1042	.1632
21	.0981	.1131	.1291	.1362	.1181	.1203	.1556
22	.1	.1135	.1353	.1416	.1199	.1272	.1385
23	.0928	.1113	.1256	.1334	.1154	.125	.1356
24	.0867	.1047	.1179	.1267	.1118	.1185	.1343
Max	.1	.1165	.1353	.1416	.1245	.1272	.1632
Min	.0456	.0568	.0639	.0565	.0605	.0416	.0892
Avg	.0685	.0836	.0947	.1056	.1079	.0995	.1171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 204 / 11 Kv Tirora Urban AG

FEEDER SEPERATION/PURE AG

Feeder Feeder KV- 11 /  
OUTGOING

DATE	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762			.0762	.0762
2		.0762			.0762	.0762
3		.0762			.0762	.0762
4		.0762			.0762	.0762
5		.0762			.0762	.0762
6		.0762			.0762	.0762
7	.0762	.0762			.0762	.0762
8	.0762	.0762	.0762		.0762	.0762
9	.0762	.0762		.0762	.0762	.0762
10	.0762	.0762	.0762	.0762	.0762	.0762
11		.0762	.0762	.0762	.0762	.0762
12		.0762	.0762	.0762	.0762	.1524
13		.0762	.0762	.0762	.0762	.1524
14		.0762	.0762	.0762	.1524	.1524
15	.0762	.0762	.0762	.0762	.0762	.1524
16	.0762	.0762	.0762	.0762	.0762	.1524
17	.0762	.0762	.0762	.0762	.0762	.1524
18	.0762	.0762	.0762	.0762	.0762	.0762
19	.0762	.0762	.0762	.0762	.0762	.0762
20	.0762	.0762	.0762	.0762	.0762	.0762
21	.0762	.0762	.0762	.0762	.0762	
22	.0762	.0762	.0762	.0762	.0762	
23	.0762	.0762	.0762	.0762	.0762	.0762
24	.0762	.0762	.0762	.0762	.0762	.0762
Max	.0762	.0762	.0762	.0762	.1524	.1524
Min	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.0762	.0762	.0762	.0762	.0794	.0970

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-SEP-17 and 07-SEP-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 204 / 11 KV AGP Paraswada  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17	05-SEP-17	06-SEP-17	07-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.2286	.9907	1.0669	1.0669	1.2955
2	.0762	.0762	.2286	.9907	1.0669	1.0669	1.2955
3	.0762	.0762	.2286	.9907	1.0669	1.0669	1.2955
4	.0762	.0762	.2286	.9907	1.0669	1.0669	1.2955
5	.0762	.0762	.2286	.9907	1.0669	1.0669	1.2193
6	.0762	.0762	.2286	.9907	1.0669	.9907	1.2955
7	.0762	.0762	.2286	.9907	.5335	1.0669	1.2193
8	.1524	.0762	.2286	1.0669	1.1431	1.1431	1.2955
9	.1524	.0762	.2286	1.0669	1.1431	1.2193	1.3717
10	.4572	.4572	.7621	.9907	1.0669	1.2955	1.2955
11	.4572	.6097	.8383	.3048	.3048	.381	.381
12	.4572	.5335	.9145	.381	.381	.381	.381
13	.4572	.5335	.8383	.2286	.381	.381	.381
14	.4572	.5335	.9145	.3048	.381	.5335	.4572
15	.381	.6097	.9145	.3048	.381	.381	.4572
16	.381	.7621	.9907	.3048	.381	.381	.4572
17	.381	.6097	1.0669	.381	.381	.381	.381
18	.381	.7621	1.0669	.381	.381	.381	.4572
19	.0762	.381	.3048	.3048	.3048	.381	.4572
20	.0762	.2286	.3048	.3048	.3048	.381	.381
21	.0762	.2286	.3048	.3048	.3048	.381	.381
22	.0762	.2286	.3048	.3048	.3048	.381	.381
23	.0762	.2286	.3048	.3048	.3048	.3048	.381
24	.0762	.2286	.3048	1.0669	1.0669	1.2955	1.1431
Max	.4572	.7621	1.0669	1.0669	1.1431	1.2955	1.3717
Min	.0762	.0762	.2286	.2286	.3048	.3048	.381
Avg	.2127	.3175	.5080	.6350	.6604	.7240	.8065