

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 201 / KATTIPAR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.823	.8326	.6687	.6401	.5441	.583
2	.4864	.7865	.7888	.6588	.4668	.5792	.5533
3	.4801	.724	.7461	.6379	.4582	.4601	.5658
4	.5243	.7316	.7202	.6024	.4016	.4582	.5365
5	.4858	.6539	.7265	.5636	.4252	.5312	.439
6	.3839	.4744	.5658	.5087	.3601	.4075	.3549
7	.4054	.4372	.4801	.3913	.3944	.3658	.4161
8	.3765	.4854	.4748	.4409	.4915	.3414	.3334
9	.3765	.5083	.4527	.4287	.3715	.3944	.4111
10	.4917		.5201	.463	.4075	.4793	.4321
11	.4001	.5959	.6036	.5304	.4572	.6379	.5201
12	.591	.4995	.5201	.6283	.3807	.4572	.591
13	.6379	.7011	.6584		.3467	.6401	.6089
14	.6516	.4954	.7133		.4268	.6081	.6173
15	.6485	.3344	.6516		.4115		.5895
16	.4961	.5144	.3749		.3887	.6154	.5144
17	.4915	.4287			.3681	.5729	.5256
18	.5611	.4458	.3315		.5601	.5975	.5914
19	.6733	.6068	.4334		.4582		.7207
20	.8507	.815	.6249		.6716		.9425
21	.8859	.8939	.6952	.5697	.6348		.9979
22	.9055	.8962	.7282	.5784	.7935	.4988	.9709
23	.8507	.7316	.7011	.5916	.5609	.5053	.9431
24	.6036	.823	.8413	.6687	.539	.5609	.57
Max	.9055	.8962	.8413	.6687	.7935	.6401	.9979
Min	.3765	.3344	.3315	.3913	.3467	.3414	.3334
Avg	.5797	.6263	.6167	.5582	.4756	.5128	.5970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 202 / SITEPAR

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5243	.6036	.6068	.583	.4858	.6001	.5365
2	.3812	.6154	.6089	.6135	.3549	.5731	.5316
3	.5079	.5853	.5721	.5895	.4816	.4915	.5197
4	.5441	.5853	.57	.5784	.583	.4973	.4858
5	.4858	.5316	.6068	.5365	.5243	.6089	.4961
6	.4696	.4807	.5138	.4862	.4641	.5316	.4428
7	.543	.5365	.8316	.463	.4748	.6081	.6068
8	.695	.8002	.7167	.4694	.4588	.6859	.7733
9	.6762	.7811	.6722	.631	.4409	.7522	.7545
10	.679	.8059	.7922	.8596	.5243	.6783	.8865
11	.9015	.639	.9054	.5611	.7343	1.0562	
12	.8865	.6401	.9431	.6584	.5258	1.0185	.6836
13	.9997	.6447	.7545		.8309	.9619	.905
14	.6767	.5498	.5973		.4696	.5658	.4207
15	.8316	.4725	.9808		.8954		.7392
16	.9808	.4001	.7922		.9259	.8488	.9896
17	.7655	.3467			.6697	.9526	.8589
18	.9431	.4321	.5258		.7316	.5083	.905
19	.6722	.5365	.583		.8048		.5914
20	.6767	.6805	.5668		.6516	.381	.6908
21	.6878	.6588	.6104	.6335	.6767	.5344	.5601
22	.6767	.6878	.6173	.5506	.6697	.547	.5544
23	.6516	.6767	.6135	.5144	.6173	.5243	.5415
24	.5335	.6335	.6447	.6001	.4967	.6104	.5304
Max	.9997	.8059	.9808	.8596	.9259	1.0562	.9896
Min	.3812	.3467	.5138	.463	.3549	.381	.4207
Avg	.6829	.5969	.6794	.5830	.6039	.6607	.6524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314016 / 33/11KV KALIMATI

Feeder No / Name : 203 / BHOSA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5533	.4877	.4287	.4858	.4915	.4115
2	.4321	.5426	.5552	.4268	.4534	.4973	.3868
3	.4696	.5487	.4115	.4374	.4475	.4096	.3628
4	.4321	.5197	.4134	.4115	.431	.373	.3868
5	.4287	.4858	.4311	.4064	.5087	.3749	.3544
6	.3418	.3963	.2477	.3814	.426	.463	.2625
7	.3605	.2892	.3064	.3572	.2477	.3932	
8	.3024	.2606	.2936	.2149	.4409	.4588	.241
9	.3506	.2515	.2936	.2191	.4207	.39	.2926
10	.298	.3064	.2972	.2279	.3932	.4525	.3155
11	.3201	.3239	.3572	.2515	.4119	.3064	
12	.3864	.3334	.4001	.2469	.4115	.4062	.503
13	.3961	.4733	.4641		.439	.4062	.5087
14	.4214	.4801	.4641		.4477	.4062	.4902
15	.4268	.3812	.4424		.0716		.4161
16	.3239	.3353	.3593		.394	.3246	.3841
17	.2881	.3506			.3944	.3155	.3887
18	.2804	.2717	.4557		.4409	.298	.4481
19	.4001	.3292	.463		.4064		.4572
20	.5898	.4715	.4694		.5487		.4902
21	.6036	.5001	.4572	.5658	.5571	.378	.583
22	.6036	.5376	.4489	.5609	.5973	.4016	.5967
23	.5868	.6099	.4572	.4973	.5079	.3944	.6001
24	.4572	.5407	.4999	.423	.5079	.5731	.4001
Max	.6036	.6099	.5552	.5658	.5973	.5731	.6001
Min	.2804	.2515	.2477	.2149	.0716	.298	.241
Avg	.4161	.4205	.4120	.3785	.4330	.4054	.4218

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 201 / 11 KV irri

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.4854	.3982	.5228	.6219	.2804	.415
2	.5487	.4481	.4298	.5041	.5853	.2743	.3961
3	.5121	.3734	.439	.4854	.567	.3109	.3772
4	.4755	.3584	.4344	.4668	.5487	.3224	.3584
5	.4572	.3206	.4252	.4854	.5359	.4607	.3395
6	.439	.2829	.394	.499	.5175	.5194	.3206
7	.499	.2263	.4344	.462	.499	.4961	.3395
8	.499	.3772	.3898	.3511	.2452	.4163	
9	.4435	.4251	.3982	.3582	.2452	.3658	.197
10	.2614	.4435	.462	.4024	.2452	.3475	.2926
11	.3174	.5175	.4755	.5121	.2263	.462	.4075
12	.4668	.3511	.5121	.3898	.3961	.439	.4298
13	.4668	.4435	.5304	.4477	.4715	.1829	.4938
14	.4108	.5914	.3326	.394	.3018	.5121	.3224
15	.3584	.5487	.4294			.4805	.3721
16	.3921	.5304			.3206	.4572	.4163
17	.4294		.3326		.2835	.4572	.4344
18	.5041	.3582	.3921	.1463	.5373	.3881	.2561
19	.499	.5731	.4854	.3898	.543		.4435
20	.5175		.5041		.4755	.0754	.5914
21	.462		.4481		.5121	.0943	.7023
22	.567	.1612	.5788		.4252	.132	.5544
23	.567	.3658	.4668	.567	.3658	.2452	.6838
24	.5304	.5121	.3658	.5487	.6401	.3109	.4338
Max	.567	.5914	.5788	.567	.6401	.5194	.7023
Min	.2614	.1612	.3326	.1463	.2263	.0754	.197
Avg	.4648	.4140	.4373	.4407	.4396	.3492	.4164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 202 / Anjora

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2437	1.3253	1.0974	.5175	.9145	1.2403	.5544
2	1.2071	1.2178	1.1218	.4805	.9145	1.2894	.6283
3	1.0974	1.1946	1.1096	.4435	.8779	1.2803	.6584
4	1.0277	1.1222	1.1462	.4435	.9145	1.134	.6584
5	.9877	.9412	1.0631	.4755	.9511	1.0745	.695
6	.9511	.8413	.8596	.4755	.9511	.8505	.6584
7	.6219	.8779	.8048	.3292	.8131	.7164	.6219
8	.8131	.7316	1.0029	.3292	.7762	.5853	
9	.6283	.7468	.4706	.3582	.5914	.5487	
10	.6653	.7392	.3361	.1417	.4854	.5487	1.2757
11	.8048	.7682	.695	.5792	.4805	.6653	.9877
12	.905	.8779	.8131	.5316	.4854	.8131	1.4883
13	.8688	.9145	.961	.7522	.8048	.8779	1.0136
14	.905	.8871	.8501	.0716	.8413	.8413	.7442
15	.905	.8238	.8501				.7796
16	.905		.961		.6653	.8501	.8688
17	.6653	.5853			.6733	.7392	.905
18	.7392	.567			.8596	.7392	.9709
19	.9877	.8779			.9671		.8048
20	1.0242	1.0608	.3658		1.1462		1.2197
21	1.267	1.1104	.4755		1.0985		1.1706
22	1.3032		.5487		1.1919		1.134
23	1.2308	1.0985	.5487	.9412	1.0631		1.1088
24	1.4632	1.576	1.1218	.5544	.8779	1.1104	.5281
Max	1.4632	1.576	1.1462	.9412	1.1919	1.2894	1.4883
Min	.6219	.567	.3361	.0716	.4805	.5487	.5281
Avg	.9674	.9493	.8192	.4640	.8411	.8836	.8852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 203 / Amgaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3411	2.2443	2.4356	2.0698	1.6827	1.8427	1.7002
2	.439	2.0271	2.268	1.848	1.5364	1.8229	1.7002
3	2.1719	1.9753	2.1719	1.7741	1.39	1.7909	1.6263
4	1.8099	1.829	2.3411	1.7002	1.39	1.7558	1.5524
5	1.7375	1.7558	1.9342	1.4784	1.3306	1.2894	1.4784
6	1.5203	1.6263	1.5203	1.3306	1.2567	1.0631	1.1827
7	1.2567	1.2567	1.2437	1.1706	1.1088	1.0631	1.1827
8	1.1827	1.2567	1.2178	1.0974	1.0974	1.0974	
9	1.1827	1.2567	1.086	1.1462	1.1088	1.1706	1.4632
10	1.3306	1.4045	1.2567	1.1584	1.1827	1.1706	1.2757
11	1.5364	1.6827	1.4632	1.2437	1.2567	1.4045	1.3466
12	1.6095	1.9022	1.7002	1.4327	1.2567	1.4784	1.4883
13	1.829	2.0485		1.448	1.3169	1.6095	1.5592
14	1.9753	2.2177	1.8665	1.4175	1.39	1.6827	
15	2.1216	1.7909	1.9959			1.7558	1.7193
16	2.1216	1.701		1.0631	1.4632	1.7558	1.8099
17	1.922	1.576			1.448	1.6263	1.9753
18	1.7741	1.5592	1.2567		1.5364	1.4784	1.7177
19	1.848	1.7718			1.576		2.1658
20	2.0698	1.9342			1.576	1.1317	1.9753
21	2.1948	2.0332			1.6476	1.6263	2.1658
22	2.3411	2.268	2.3152		1.829	1.7741	2.1948
23	2.5339	2.5606	2.2177	1.829	1.9136	1.7741	.5914
24	2.5606	2.4615	2.4097	2.1658	1.7558	1.9342	1.7741
Max	2.5606	2.5606	2.4356	2.1658	1.9136	1.9342	2.1948
Min	.439	1.2567	1.086	1.0631	1.0974	1.0631	.5914
Avg	1.8088	1.8392	1.8167	1.4926	1.4370	1.5260	1.6202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 314022 / 33kv amgaon sub station

Feeder No / Name : 204 / 11 KV Salekasa

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	1.0387	.9671	.4805	.6697	.9816	.7499
2	.905	1.0387	.9671	.4435	.6516	.9816	.7316
3	.8688	.9671	.9877	.462	.6154	.985	.7316
4	.8326	.9313	.9145	.4435	.5792	.8954	.7682
5	.7964	.8688	.8869	.462	.5544	.8859	.8048
6	.7602	.8145	.7164	.4572	.5175	.6878	.7865
7	.7947	.5973	.695	.4207	.5729	.6089	
8	.7947	.5487	.6805	.3109	.5544	.5973	
9	.6584	.5544	.4706	.197	.462	.5853	.5493
10	.5487	.5914	.4938	.2658	.3734	.567	.4908
11	.695	.7392	.5853	.5847	.4108	.567	.4298
12	.8048	.7023	.7762	.6447	.2641	.7133	.4298
13	.9412	.7392	.8048	.724	.4294	.8048	.7783
14	.8688	.7842	.8131	.6201	.5729	.823	.7133
15	.8048	.7087	.7655			.7207	.823
16	.8507	.6036	.7023		.5359	.6767	.7602
17	.823	.5493			.567	.6767	.7316
18	.6401	.5552			.5731	.6584	.6468
19	.8048	.5731			.6584		.8686
20	.905	.8413	.2402		.7522	.1143	.924
21	.7964	.9134	.2957		.7442	.1509	.9425
22	.8869	.905	.2772		.7973	.679	.9425
23	1.0924	.9391	.4066	.6154	1.0208	.7316	1.1462
24	.9877	1.0745	.9671	.499	.6878	1.0099	.7499
Max	1.0924	1.0745	.9877	.724	1.0208	1.0099	1.1462
Min	.5487	.5487	.2402	.197	.2641	.1143	.4298
Avg	.8255	.7741	.6864	.4769	.5898	.7001	.7500

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 207 / 33/11 kv 10 MVA T/R

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.77	4.0604	3.7146	2.8275	2.6612	2.9938	2.3045
2	3.6037	3.9363	3.6591	2.6886	2.6612	2.9938	2.2731
3	3.6591	3.8409	3.7146	2.5206	2.7721	2.8275	2.1622
4	3.5482	3.6037	3.3265	2.5503	2.6057	2.9384	2.1622
5	3.2156	3.3819	3.2156	2.384	2.6057	2.6326	2.2731
6	2.6612	2.5503	2.2497	1.8296	2.3285	2.3285	2.524
7	1.7918	2.1948	2.2497	1.5746	2.0851	2.0302	2.4434
8	2.0851	2.0851	1.8656	1.5746	1.9204	1.773	.0326
9	1.8461	2.0633	1.6655	1.5364	1.8107	1.7375	
10	2.0851	2.2262	2.1176	1.5364	1.6461	1.7918	
11	2.3348	2.524	2.3594	1.9204	1.9753	1.8656	
12	2.5789	2.8532	2.4949	1.9959	1.9204	2.4143	2.4434
13	2.7435	3.0727	2.6886	2.3045		2.3285	2.6606
14	2.8532	3.1276	2.7692	1.5912		2.6886	.8688
15	3.1602	2.7149	2.8532			2.6886	2.6337
16	3.0493	1.701	.9877	1.0534	2.4691	2.3285	
17	2.6886	2.1719	.0075	1.1523	2.4143	2.4691	2.552
18	2.6063	2.1719	.8413	1.2489	2.3348	2.2805	2.6326
19	2.8829	2.4714	.0202	1.5912	2.6612	.0079	2.7435
20	3.2156	3.2487	.2263	2.4646	2.8567	.9991	3.2487
21	3.6037	3.3608	.5093	5.3772	3.1367	1.6078	3.3608
22	3.8255	3.6591	2.8829	5.3772	3.1927	1.7741	3.5082
23	3.9918	3.7071	2.8829		3.2156	1.7741	3.5482
24	3.8809	4.225	3.8255	2.8275	2.7166	3.1602	2.2177
Max	3.9918	4.225	3.8255	5.3772	3.2156	3.1602	3.5482
Min	1.7918	1.701	.0075	1.0534	1.6461	.0079	.0326
Avg	2.9867	2.9563	2.2136	2.2694	2.4757	2.1848	2.4297

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 208 / 33/11 KV 5 MVA T/R

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.701	1.262	.9877	1.1203	1.2197	1.0534
2	1.3575	1.5364	3.0087	1.0082	1.2323	1.2197	1.1643
3	1.1946	1.6461	1.2489	.9979	.9619	1.2071	1.1523
4	1.2894	1.4266	1.2489	.691	.9054	1.2883	.9774
5	1.1088	1.4815	1.3032	.691	1.0534	1.358	1.1088
6	1.1403	1.0317	1.0745	.8596	1.1088	1.2323	.9877
7	1.2357	1.0317	.9671	.8939	.9877	1.1088	.5487
8	1.1568	.9877	1.0174	.6447	.7207	.9328	.008
9	1.0099	.9877	.9134	.6516	.7207	.8316	.8145
10	.8059	1.0425	.9774	.6516	.5847	.8871	.8596
11	.9774	1.0974	1.0099	.9671		1.2071	5.7407
12	1.2489	.9979	1.1963	1.0402		1.1523	1.0517
13	1.3169	1.1643	1.1946	1.1163		1.2197	1.1283
14	1.3169	1.3443	1.262	.9671		1.262	1.0425
15	1.2197	.0566	1.1283	.6613		1.1946	1.1946
16	1.2197		.9362		1.1523	1.1403	
17	1.1643	1.0745		.1966	.9231	.9877	1.1403
18	1.0745	.9774	.3189	.691	.9877	.8316	.7802
19	1.1283	1.1523	.499	.7762	1.6632	.0273	1.4506
20	1.4563	.8779	.7842	.7356	1.2323	.499	1.386
21	1.4415	.9425	.8962	1.2197	1.2883	.5544	1.6244
22	1.4003	1.1088	.9425	1.2894	1.1043	.6653	1.5278
23	1.6632	1.3169	.9425		1.2357	1.1203	1.8296
24	1.4661	1.5912	1.3032	1.0425	1.2752	1.3306	1.1203
Max	1.6632	1.701	3.0087	1.2894	1.6632	1.358	5.7407
Min	.8059	.0566	.3189	.1966	.5847	.0273	.008
Avg	1.2448	1.1554	1.1059	.8536	1.0662	1.0199	1.2909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 401 / 33 KV SALEKASA FDR

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9547	1.8461	1.6832	1.5581	1.4661	1.7193	1.1283
2	1.5043	1.7918	1.6832	1.5043	1.4661	1.701	1.1283
3	1.2894	1.773	1.5581	1.2757	1.4506	1.6478	1.1163
4	1.8267	1.773	1.5043	1.4506	1.3575	1.5947	1.1163
5	1.7193	1.773	1.5043	1.4506	1.3969	1.6478	1.1694
6	1.4043	1.4403	1.2071	1.2209	1.262	1.4752	1.1317
7	1.278	1.5083	1.2071	1.0322	1.1065	1.1174	1.0682
8	1.3117	1.6118	1.1043	1.0082	1.0562	1.3283	.9122
9	1.2963	1.3443	1.186	1.1385	1.1043	1.3117	1.0202
10	1.3923	1.4918	1.2483	1.1385	1.078	1.3923	1.0202
11	1.5769	1.6278	1.3426	1.278		1.4575	1.0688
12	1.5769	1.6644	1.4752	1.1797		1.5729	1.0082
13	1.6461	1.8724	1.5432	1.4083		1.6907	1.2209
14	1.5947	1.6301	1.6301	1.4586		1.6095	1.3735
15	1.6124	.0566	1.4243	.9831		1.5261	1.3735
16	1.5432	.3658	1.0082	.8951	1.3077	1.5912	
17	1.4752	.7287	.9842	1.0682	1.2631	1.5061	1.2289
18	1.4918	.8139	1.1523	1.1568	4.177	.4424	1.2289
19	1.893	.503	1.5415	1.4883	1.701		1.6907
20	2.1948	1.9204	1.7918	1.7558	2.1176	1.0631	.9877
21	2.1948	2.0302	1.8267	1.6289	2.009	1.4118	1.9753
22	2.1719	1.9204	1.6655	1.6289	1.9547	1.2489	1.9959
23	1.9547	1.701	1.6655		1.8267	1.1403	1.9004
24	1.9547	1.8804	1.6832	1.5581	1.5203	1.773	1.1946
Max	2.1948	2.0302	1.8267	1.7558	4.177	1.773	1.9959
Min	1.278	.0566	.9842	.8951	1.0562	.4424	.9122
Avg	1.6608	1.4612	1.4425	1.3159	1.6116	1.4334	1.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 402 / 33 KV DEORI feeder

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.2994	7.4126	6.4415	5.9414	5.8282	6.5072	5.3189
2	7.1862	6.9159	1.2489	5.7716	5.715	6.2809	5.2624
3	6.9599	7.2994	6.2243	5.715	5.6019	6.2809	5.2624
4	6.8467	7.2588	5.9414	5.6584	4.8663	5.8562	5.2058
5	6.7901	7.0302	5.8282	5.5453	5.4321	5.3755	5.2624
6	5.2058	4.6399	3.7346	3.9043	4.2438	4.5833	4.145
7	4.5268	4.5268	3.7346	3.1121	3.5648	4.0741	4.0175
8	4.2438	4.1307	3.6969	3.2407	3.5648	3.8649	3.5082
9	4.1307	4.357	3.5848	3.8089	3.5648	4.0741	2.8778
10	4.5153	4.1307	3.6591	3.8089	3.5848	4.145	3.095
11	5.0869	4.6965	3.7529	3.9769		4.1307	2.2565
12	5.5441	5.7716	4.7051	4.537		4.0741	2.4714
13	5.7156	6.3375	4.8097	4.9851		4.0889	3.6923
14	5.9442	6.394	4.9228	4.8171		4.4702	4.1872
15	6.4586	3.8477	5.036	3.3665		4.9794	4.8097
16	5.7156	3.1121	4.357	2.9012	3.9609	4.6399	
17	5.3727	3.3048	3.6037	3.4517	4.1872	4.6868	4.5931
18	5.3189	3.8089	3.0556	3.4517	4.145	4.7439	4.5833
19	6.4015	4.6399	4.0741	5.1492	5.2624	4.5931	6.7901
20	8.4877	.8871	5.3755	6.6204	7.2428	1.2003	7.8652
21	8.714	1.6409	6.5072	6.394	7.3731	4.201	7.8652
22	8.4877	7.0576	6.1677	6.5072	7.0302	4.4353	7.5057
23	7.8087	6.7901	6.1677		6.7444	5.6019	7.1862
24	7.4126	7.5257	6.5535	5.998	5.9414	6.4506	5.4321
Max	8.714	7.5257	6.5535	6.6204	7.3731	6.5072	7.8652
Min	4.1307	.8871	1.2489	2.9012	3.5648	1.2003	2.2565
Avg	6.2572	5.1465	4.7160	4.7245	5.1502	4.7224	4.9215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 403 / 33 KV Tedha feeder

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0407	3.1699	3.095	1.7741		2.2405	2.0165
2	2.9864	3.1699	.9522	1.6461		1.2197	2.0165
3	3.0087	3.1361	2.955	1.5364		2.1845	2.0165
4	2.955	3.083	2.7938	1.4969		2.1285	1.9605
5	2.8778	3.0087	2.7938	1.4969		2.1285	1.8004
6	2.3388	2.5206	2.2365	1.086		1.7558	1.6289
7	2.0856	2.4417	2.0622			1.5581	1.5775
8	2.0622	2.3594	1.9393	1.3003		1.3969	1.5947
9	1.9616	2.4366	1.7901	1.3146		1.4661	1.5769
10	2.2119	2.6658	1.9839	1.3146		1.5043	1.6644
11	2.3148	2.572	2.2634	1.5043		1.7375	1.2717
12	2.6006	2.8086	2.3405	1.6118		1.8604	1.7164
13	2.7343	3.1727	2.4188	1.7918		1.9342	2.1033
14	2.8395	3.1727	2.2325	.583		1.7375	1.7684
15	2.9235	2.2325	3.6523	.4458		1.6832	.8505
16	2.4691	.9522	2.3137	2.915	1.3575	1.7878	
17	2.34	1.1174			1.4352	1.6461	2.2382
18	2.5857	2.8235		5.1852	1.5775	1.8313	1.7101
19	3.0498	3.4751	.7682		1.9959		3.0407
20	3.6923	3.7346	.9979		2.4331	.4841	3.5665
21	3.7466	3.5665	1.7187		2.6595	1.9044	3.4374
22	3.5837	3.3122	1.9959		2.5206	2.1845	3.2156
23	3.3311	3.1493	1.9959		2.3525	2.0725	2.9081
24	1.4661	3.2773	3.095	1.8656		2.2965	2.0165
Max	3.7466	3.7346	3.6523	5.1852	2.6595	2.2965	3.5665
Min	1.4661	.9522	.7682	.4458	1.3575	.4841	.8505
Avg	2.7169	2.8066	2.1998	1.6981	2.0415	1.7714	2.0737

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 405 / 33/0.4 KV substation

Station Trasformer Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1568	1.1191	1.1523	.6167	1.0174	1.1523	1.0202
2	.9882	1.0174	1.1523	.5967	1.0288	1.166	.9717
3	.9568	1.0288	1.1523	.5407	.9882	1.1191	.9665
4	.7716	.9882	1.1797	.5533	.9465	1.1797	.9259
5	.7202	.9362	1.1523	.4115	.9036	1.1797	.9259
6	.6687	.9425	1.1523	.4287	.8145	1.1797	1.0288
7	.5796	.6944	.7865		.8596	.8642	.7973
8	.5075	.6321	.7865	.4515	.823	.8539	.7682
9	.5596	.6859	.8259	1.2483	.8745	.7773	.6722
10	.6036	.7407	.7042	1.1797	.8453	.7373	.6562
11	.5898	.8436	.7459	.9831		.7956	1.0688
12	.5898	.9122	.8048	.9831		.7956	.7682
13	.639	1.4403	.8648	.8642		.8551	.7499
14	.6802	1.4575	.9259	.8642		.9156	.759
15	.6241	1.1523	.8648	1.1797		.8551	.4801
16	.7459	1.1523	.9259	.9831	.9774	.8139	
17	.8648	1.1797	1.0288	.8642	1.1797	.9156	.5344
18	1.3443	1.1523	1.1568	.7499	1.0562	.9231	.5898
19	.8573	1.1523	1.0288	.759	1.1523	.9374	.7042
20	.9962	1.0814	.9156	.7202	1.1523	1.0185	.8048
21	1.0562	1.1523	.8048	1.1797	1.1385	1.0974	.8648
22	1.1174	1.1797	.7042	.9831	1.3169	1.0837	.9259
23	1.2003	1.1523	.7545	1.2071	1.1797	1.0517	.9259
24	1.2346	1.2483	1.1523	.6882	1.1065	1.1797	1.0311
Max	1.3443	1.4575	1.1797	1.2483	1.3169	1.1797	1.0688
Min	.5075	.6321	.7042	.4115	.8145	.7373	.4801
Avg	.8355	1.0434	.9468	.8276	1.0190	.9770	.8235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 406 / 33 KV KALIMATI

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4563	1.5844	1.5844	1.2894	1.4003	1.5844	1.0317
2	1.4563	1.5844	1.5844	1.2489	1.3306	1.5844	1.0317
3	1.4563	1.5844	1.5844	1.1088	1.3306	1.5278	1.0317
4	1.4003	1.5844	1.4712	.9522	1.2752	1.5278	5.0503
5	1.4003	1.5278	1.4003	1.1203	1.2752	1.4712	1.0099
6	1.0317	1.1088	1.1088	.7888	1.0317	1.1763	.8413
7	.9877	1.1883	1.1088	1.262	.9328	1.1317	.9036
8	1.8633	2.4795	1.8736	1.5861	2.1674	1.7627	2.1056
9	.9877	1.358	1.1883	.9328	.823	1.166	2.3988
10	2.1284	1.4712	1.3014	1.0082	.3858	1.4712	.1358
11	1.3014	1.5278	1.5278	.8505		1.5278	1.1883
12	1.3014	1.5844	1.5844	1.1203		1.5844	1.6409
13	1.4146	1.4712	1.6409	1.2323	1.3014	1.6244	1.8107
14	1.5123	1.6975	1.3443	1.0425	1.358	1.6975	1.5844
15	1.6244	.7059	1.4712	.7973	1.4146	1.6975	1.6409
16	3.0326	.8145	1.1883	.691	2.6921	3.1007	1.4403
17	1.3014	.823	1.2106	.9877	1.1883	1.5844	1.5278
18	1.2449	1.9936	.7545	1.1403	1.4146	1.4289	1.6804
19	1.4146	1.2323	.703	1.1043	1.3014	.9425	1.8673
20	3.7346	1.7541	1.2226	1.4266	1.7541	.7207	2.1502
21	3.7346	1.8673	1.4815	2.7046	1.8673	.9425	
22	3.5134	3.2905	2.672	1.3169	1.7541	2.5514	3.7397
23	1.6975	1.6409	1.386		1.6409	1.086	1.8673
24	2.8886	3.0812	3.1773	2.4451	2.58	2.9607	2.1291
Max	3.7346	3.2905	3.1773	2.7046	2.6921	3.1007	5.0503
Min	.9877	.7059	.703	.691	.3858	.7207	.1358
Avg	1.8285	1.6231	1.4821	1.2242	1.4645	1.5772	1.7308

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

AMGAON S/DN.[388]

BU 0388

Substation No/ Name :- 317007 / 132/33 KV AMGAON S/S

Feeder No / Name : 407 / 33 KV KAWARABANDH

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.1643	1.0642	.9522	.9522	1.1763	2.0165
2	1.1763	1.0642	1.0425	.9522	1.0082	2.2405	.9054
3	1.2883	1.0082	1.0082		.9522	1.0682	.8488
4	1.2323	1.0534	.9522	.8488	.9054	1.0082	.8488
5	1.1763	1.1203	.8962	.8488	.9054	.9979	.8488
6	.8962	.7842	.7842	.6722	.8402	.823	.8871
7	1.9239	.7762	.6722	.7207	.7762	.8779	.823
8	.8402	.7133	.6516	.5973	.8316	.8596	.7133
9	.6036	.7682	.5847	1.3146	.7682	.9231	.6653
10	.8316	.7133	.5544	.6447	.7059	.8779	.7682
11	.8871	.8779	.5487	.6984		.9425	.7682
12	.9522	.8779	.7207	.4835		1.0425	.9328
13	.9522	1.0974	.7842	.8688		1.1317	.9328
14	.8871	1.0974	.8488	.8145		.9979	.9328
15	.8316	.3961	.7133	.5847		.8688	.9877
16	.7133	.4527	.691	.4481	.8145	.7442	
17	.6516	.6099	.6241	.5487	.7522	.8413	.7133
18	.7602	.7602	.6653	.6653	.4938	.8939	2.2634
19	.9774	.6722	.8962	.8488	1.0534		1.0208
20	1.2883	1.2449	.9619	1.0185	1.1763	.8002	1.2323
21	1.3014	1.3443	1.0751	1.0082	1.2323	.3961	1.2323
22	1.3443	1.2883	.9619	3.4728	1.1763	.3921	1.3014
23	1.1763	1.0082	.9619		1.2323	.6224	1.3306
24	1.4003	1.1763	1.0082	.9522	.8962	1.2323	.8962
Max	1.9239	1.3443	1.0751	3.4728	1.2323	2.2405	2.2634
Min	.6036	.3961	.5487	.4481	.4938	.3921	.6653
Avg	1.0598	.9196	.8197	.9075	.9196	.9460	1.0378

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 201 / 11 KV Chichgad

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4338	.3921	.4294	.415	.3961	.3772
2	.4904	.415	.3734	.4108	.4382	.3772	.3395
3	.4854	.415	.3584	.4108	.4191	.3584	.2987
4	.4904	.4481	.3547	.3921	.4382	.3584	.2587
5	.4854	.4805	.3361	.3734	.4001	.3734	.2772
6	.3547	.3734	.3361	.2801	.2614	.2772	.2587
7	.2987	.2987	.2614	.2054	.2218	.2587	.2614
8	.2641	.2957	.2241	.2241	.1848	.2427	.2614
9	.3018	.2987	.2241	.2054	.1905	.2033	.2263
10	.3018	.3439	.2427	.2427	.2096	.2587	.2641
11	.3584	.3511	.2957	.2743	.2286	.2587	
12	.4108	.3921	.3475	.2641		.3395	
13	.4527	.4108	.4024	.3395		.3174	.3475
14	.4481	.4108	.4207	.3772		.3174	.3292
15	.415	.2865	.4108	.2987		.2987	
16	.4527	.1991	.3258	.2987	.3174	.2987	
17	.4108	.2587	.3109	.2427	.2614	.2987	.3292
18	.3772	.3142	.3326		.2801	.2957	.3772
19	.4338	.3696	.4108		.4191	.4435	.4572
20	.5658	.5658	.4805		.4854		.5658
21	.5914	.5658	.5415		.5093	.4668	.5658
22	.6036	.5658	.4938	.4527	.4715	.4338	.5544
23	.5415	.4904	.4668	.4338	.4338	.4338	.4854
24	.5228	.4854	.3921	.4481	.4108	.3961	.415
Max	.6036	.5658	.5415	.4527	.5093	.4668	.5658
Min	.2641	.1991	.2241	.2054	.1848	.2033	.2263
Avg	.4403	.3945	.3640	.3302	.3498	.3349	.3625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 202 / 11 KV Ganutola Feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.4338	.3547	.4108	.4954	.4382	.3772
2	.4854	.3961	.3395	.4108	.4954	.4001	.3206
3	.5041	.3961	.3174	.3921	.5144	.381	.2801
4	.4715	.4481	.3174	.3921	.4572	.381	.2801
5	.4527	.5175	.2957	.4108	.4572	.415	.2957
6	.2987	.4481	.2587	.3174	.3239	.3361	.2957
7	.2427	.4108		.2054	.2667	.2614	.2241
8	.2263	.3326	.1848	.2801	.2033	.2241	.1867
9	.2452	.3361	.1867	.3174	.2096	.2033	.2263
10	.3395	.2195	.1867	.2987	.2286	.2561	.1886
11	.3174	.2772	.2033	.2614	.2477	.2195	
12	.3584	.3292	.2195	.2614		.2926	
13	.4715	.3511	.2561	.2614		.2378	.2743
14	.4481	.2772	.3475	.3018		.3881	.2743
15	.4527	.1448	.3361	.2641		.4066	
16	.4481	.1294	.2743	.1886	.2801	.3696	
17	.4108	.2587	.2561	.2075	.3174	.3696	.2218
18	.3734	.2957	.2587		.3734	.3696	.2987
19	.5041	.4435	.4066		.5359	.4854	.3772
20	.6722	.5281	.4805		.6348		.5847
21	.6653	.5281	.5415		.6161	.4854	.4715
22	.5658	.4904	.4938	.5601	.5415	.5281	.5228
23	.5041	.4338	.4481	.5228	.5093	.4904	.5228
24	.5601	.4481	.3921	.4294	.5041	.4715	.415
Max	.6722	.5281	.5415	.5601	.6348	.5281	.5847
Min	.2263	.1294	.1848	.1886	.2033	.2033	.1867
Avg	.4392	.3698	.3198	.3347	.4106	.3657	.3319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314004 / 33/11 KV CHICHGAD

Feeder No / Name : 203 / 11 KV Palandur

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2829	.1698	.2427	.2667	.2858	.2427
2	.2987	.2452	.1698	.2427	.2477	.2667	.2263
3	.3018	.2241	.1509	.2452	.2667	.2477	.2054
4	.2987	.2614	.1509	.2427	.2477	.2452	.168
5	.2987	.3142	.132	.2614	.2477	.2641	.1848
6	.2054	.2054	.132	.168	.3048	.1886	.1663
7	.168	.168	.1109	.112	.1905	.1478	.1494
8	.1886	.1848	.1097	.112	.1494	.1307	.168
9	.1698	.1307	.0934	.112	.1334	.0934	.1698
10	.2075	.1448	.0747	.0934	.1143	.1307	.1132
11	.1829	.1097	.1075	.1307	.1143	.1478	
12	.1646	.1886	.1463	.1494		.128	
13	.2012	.2263	.0914	.1867	.1509	.1646	.2195
14	.2012	.2263	.0914	.1886	.1698	.1478	.1829
15	.1829	.1612	.0914	.1886		.1478	
16	.1867		.1848	.1494	.1307	.0739	
17	.168	.0754	.1097	.1307	.1307	.1478	.1663
18	.1829	.1132	.1663		.112	.1646	.1867
19	.2587	.0377	.2427		.3018	.2772	.2829
20	.3881	.2075	.3174		.3584		.415
21	.3881	.2641	.3174		.3584	.2957	.3961
22	.3292	.2452	.2987	.2801	.3048	.2829	.3547
23	.3174	.2263	.2801	.2614	.2858	.2641	.2987
24	.2987	.2987	.1886	.2427	.2614	.2858	.2641
Max	.3881	.3142	.3174	.2801	.3584	.2957	.415
Min	.1646	.0377	.0747	.0934	.112	.0739	.1132
Avg	.2446	.1975	.1637	.1870	.2204	.1969	.2280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 201 / 11KV AMGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.1506	1.1317	.8779	1.0208	1.094	1.0349
2	1.1203	1.1203	1.1317	.8871	1.0387	.823	1.0349
3	1.1317	1.1317	1.094	.8871	1.0277	.8488	.9145
4	1.1317	1.1203	1.0829	.8686	1.0277	.8488	.823
5	1.1317	1.1088	1.0719	.8131	1.0566	1.094	.823
6	.9896	.9896	.9997	.8131	.9593	.9808	.9511
7	.9709	.9431	.9145	.9425	.961	.9619	.9511
8	.9619	.5121	.9619	.961	.9425	.9522	.9511
9	.9511	.5121	.9242	.905	.9328	.9149	
10	.9808	.5121	.9619	.9231	.9145	.9619	
11	.9997	.439	.9619	.8954	.9145	.9619	
12	.9877	.7133	.9997	.9134	.9328	.9335	
13	1.0269	.7865	1.0164	.9412	.9877		
14	1.0642	.7865	1.0374	.9593	.9877		
15	.9877	.567	1.0456	.905			.9593
16	.9694	.4024	.9431	.8131	.9808	.9328	
17	.9522	.9242	.8962	.961	.9619	.9145	.9808
18	.9896	.9619	.9328		.9431	.9145	.9619
19	1.0374	1.094	1.1041		1.0059	1.0242	1.0829
20	1.2696	1.2071	1.1763		1.1883		1.2826
21	1.2826	1.226	1.1157		1.1949		1.251
22	1.226	1.1203	1.0974		1.1317		1.1506
23	1.1273	1.1317	1.0791	1.0679	1.094	1.0425	1.1506
24	1.1389	1.1506	1.0974	.8779	1.0679	1.1128	1.0242
Max	1.2826	1.226	1.1763	1.0679	1.1949	1.1128	1.2826
Min	.9511	.4024	.8962	.8131	.9145	.823	.823
Avg	1.0650	.9005	1.0324	.9059	1.0119	.9621	1.0193

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 202 / 11 KV DEORI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.6598	1.5364	1.2936	1.2178	1.4712	1.1706
2	1.5384	1.5844	1.5123	1.2803	1.2178	1.3957	1.1706
3	1.5708	1.531	1.3957	1.2936	1.1403	1.3169	1.1706
4	1.4937	1.475	1.3352	1.1827	1.1584	1.358	1.1706
5	1.3957	1.358	1.3014	1.1827	1.0498	1.2449	1.0974
6	1.1506	1.1506	1.1317	.9425	.9145	1.0751	.8962
7	.9997	.9896	.9054	.8501	.7865	.9242	.8779
8	.8962	.823	.811	.7392	.7865	.8299	.8048
9	.8962	.8507	.8589	.8413	.8413	.9431	.8326
10	1.0829	1.0791	1.0164	.9511	.9145	1.1317	1.0059
11	1.2449	1.2071	1.0562	1.1041	1.0242	1.2826	1.1643
12	1.3203	1.4266	1.1016	1.134	1.1157	1.3769	1.1827
13	1.4146	1.3535	1.0269	1.1706	1.1458		1.1827
14	1.3756	1.3394	1.094	1.1458	1.1523		1.1706
15	1.3643	1.4266	1.2449	1.1523			1.2936
16	1.4712	1.0974	1.1694	.9795	1.2826	1.2803	
17	1.3014	1.1128	.9328	1.0082	1.0642	1.2071	1.1389
18	1.226	1.0562	.9145		1.1317	1.4632	1.0642
19	1.2696	1.0608	.9877		1.2826	1.2437	1.2449
20	1.4937	1.4901	1.0608				1.3957
21	1.6221	1.5089	1.262		1.3203	1.2803	1.4712
22	1.7164	1.6221	1.39		1.4377	1.2986	1.5466
23	1.7364	1.6032		1.3352	1.5123	1.3352	1.6032
24	1.6975	1.6975	1.5912	1.2803	1.2489	1.4937	1.1706
Max	1.7364	1.6975	1.5912	1.3352	1.5123	1.4937	1.6032
Min	.8962	.823	.811	.7392	.7865	.8299	.8048
Avg	1.3703	1.3126	1.1581	1.0983	1.1248	1.2476	1.1664

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 204 / 11 KV KOHAMARA FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.9242	.8299	.7316	.567	.7545	.4207
2	.823	.8962	.7499	.7316	.567	.7545	.4207
3	.8488	.9054	.7316	.6838	.5493	.679	.439
4	.7865	.8865	.7316	.6767	.4557	.6219	.439
5	.7733	.8589	.811	.6468	.5316	.6201	.439
6	.6722	.6908	.679	.5975	.4887	.6219	.439
7	.6979	.7167	.6602	.5914	.4572	.679	.4207
8	.6979	.7842	.6224	.6584	.5304	.6979	.5121
9	.7682		.679	.6154	.3658	.6653	.5068
10	.8299	.8775	.7545	.5973	.3658	.5975	.5304
11	.8865	.8962	.7356	.6805	.3841		.5304
12	.9431	.8962	.7545	.6984	.3841		.6401
13	.6224	.8779	.8299	.724	.4572		.6697
14	.6036	.8962	.8589	.6268	.6219		.6154
15	.9619	.7602	.8029	.5792			.5249
16	.8865	.4572	.7167	.5487	.6413	.5121	.6468
17	.8215	.679	.6401	.439	.6584	.695	.679
18	.8501	.6413			.6908	.695	.7095
19	.9808	.8299			.7545	.7316	.8299
20	1.1506	1.0562	.4572		.9997		.9997
21	1.1016	1.0374	.7499		.9054		.9619
22		.8299	.7682		.7922	.5853	.8589
23	.9808	.811	.7316	.6154	.7545	.4572	.811
24	.8775	.9431	.8779	.7316	.5973	.7733	.4207
Max	1.1506	1.0562	.8779	.7316	.9997	.7733	.9997
Min	.6036	.4572	.4572	.439	.3658	.4572	.4207
Avg	.8429	.8327	.7351	.6407	.5878	.6554	.6027

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 205 / 11 KV EXPRESS FEEDER MBCP

HV Express Feeder

SIRP Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.0566	.0566	.0566	.0566	.0566
2	.0549	.0566	.056	.0566	.056	.0566	.0566
3	.0377	.0566	.0566	.0566	.0566	.0377	.0566
4	.0377	.0566	.056	.0566	.0566	.0366	.0566
5	.0377	.056	.0377	.0377	.0566	.0373	.0566
6	.0377	.0373	.0377	.0189	.0377	.0366	.0377
7	.0377	.0377	.0377	.0189	.0377	.0373	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0373	.0377	.0187	.0377	.0377	.0189	.0377
10	.0377	.0377	.0373	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377	.0377	.0189
12	.0377	.0377	.037	.0377	.0377	.0377	.0377
13	.0377	.0373	.0377	.0377	.0377		.0373
14	.0377	.0377	.0377	.0377	.0377		.0377
15	.0377	.0377	.0377	.0373		.0377	.0377
16	.037	.0377	.037	.0377	.0373	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0187	.056	.0187		.0366	.0373	.0377
19	.0339	.0566	.0373		.0366	.0373	.0377
20	.056	.0566	.0747		.056	.0373	.0566
21	.056	.0566	.0747		.0566	.0566	.056
22	.0566	.0566	.056		.0549	.056	.0566
23	.056	.0566	.0566	.0566	.0566	.056	.0566
24	.0566		.0754	.0566	.056	.0566	.0566
Max	.0566	.0566	.0754	.0566	.0566	.0566	.0566
Min	.0187	.0373	.0187	.0189	.0366	.0189	.0189
Avg	.0420	.0466	.0453	.0417	.0457	.0418	.0448

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

DEORI S/DN.[389]

BU 0389

Substation No/ Name :- 314008 / 33/11 KV DEORI SUB STATION

Feeder No / Name : 403 / 33KV OUTGOING KORCHI

HV Non-Express Feeder

FEEDER Feeder KV- 33 /
INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5463	2.5206	1.8107	2.0165	2.1502	2.32	2.2634
2	2.5206	2.4646	1.8107	2.0165	2.1502	2.3525	2.2634
3	2.5206	2.4897	1.701	1.9044	2.1502	2.32	2.0851
4	2.5463	2.4646	1.7541	1.9239	2.0936	2.32	2.1502
5	2.5463	2.4086	1.4146	1.6975	2.0936	2.3765	1.9239
6	1.9239	2.0165	1.1317	1.358	1.4712	1.8107	1.7541
7	1.358	1.6244	.8488	1.0185	1.0751	1.1883	1.1883
8	1.5278	1.5684	.9054	1.0185	1.0751	1.1317	1.1883
9	1.4146	1.5123	.8488	1.0185	1.0751	.9522	1.0751
10	1.5278	1.5123	.8316	1.0751	1.0751	1.0642	1.1317
11	1.5684	1.6244	.6161	.679	1.1317	1.0642	
12	1.7541	1.8107	1.1643	1.1883	1.1203	1.2449	
13	1.9239	1.9239	1.5684	1.358	.6722	1.5123	1.358
14	1.9805	1.9044	1.6409	1.4712	.7356	1.5278	1.7541
15	1.9805	1.1763	1.5844	1.5844		1.4712	1.5278
16	1.8484	.3395	1.5684	1.1883	1.3014	1.4563	1.4563
17	1.7541	.679	.8962	1.2449	1.0751	1.5123	1.4146
18	1.7541	1.0185	1.2883		1.2449	1.5684	1.6244
19	2.2405	1.4712	1.7364		1.8673	2.0725	2.32
20	3.0556	1.1883	2.2634		2.7161		2.9687
21	3.1367	1.8673	2.1285		2.6595	2.4086	2.8567
22	2.9127	1.8673	2.1845		2.3765	2.2405	2.7161
23	2.6595	1.7541	1.9044	2.2634	2.2405	2.2405	2.5463
24	2.6595	2.5766	1.6975	2.037	2.1502	2.1502	2.2405
Max	3.1367	2.5766	2.2634	2.2634	2.7161	2.4086	2.9687
Min	1.358	.3395	.6161	.679	.6722	.9522	1.0751
Avg	2.1525	1.7410	1.4708	1.4769	1.6392	1.7524	1.9003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 201 / 11 KV Keshori

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.6004	1.6032	1.5844	1.6221	.3018	1.6032
2	1.5655	1.6004	1.6032	1.5844	1.6221	.2829	1.6032
3	1.5655	1.6004	1.6032	1.5844	1.6221	.2829	1.6032
4	1.5655	1.6004	1.5844	1.5844	1.6032	.2452	1.6032
5	1.5655	1.6004	1.5655	1.5844	1.6032	.2452	1.6032
6	1.5278	1.5432	1.5655	1.5466	1.5655	.2452	1.5844
7	1.4901	1.4861	1.5278	1.5278	1.5089	.2263	1.5655
8	1.4712	1.4861	1.5278	1.5278	1.5278	.2263	1.5655
9	1.4712	1.467	1.5089	1.4901	1.5089	.2641	1.5278
10	1.4712	1.467	1.5278	1.4901	1.5089	.2829	1.5844
11	1.5089	1.4712	1.5466	1.5089	1.5466	.3206	.5658
12	1.5089		1.5278	1.5278	1.5466	.2829	.5847
13	1.5278	1.5089	1.5466	1.5278	1.5466	.3018	.6036
14	1.5089	1.5089	1.5466	1.5278	1.5089	1.5089	1.5466
15	1.4901	1.5089	1.5089	1.5466	1.5278		1.5655
16	1.4712	1.4523	1.4901	1.5278	1.5089	1.4901	
17	1.4335	1.4901	1.4712	1.5089	1.5466	1.4712	1.5089
18	1.4335	1.5466	1.5089		1.5089	1.5089	1.4901
19	1.5466	1.6221	1.5844		1.6221	1.5466	1.5655
20	1.6385	1.6975	1.6409		1.6975	1.5844	1.6598
21	1.6194	1.6975	1.6409		.3206	1.5655	1.6409
22	1.6194	1.6221	1.6221		.3206	1.6032	1.6409
23	1.6004	1.6221	1.6032		.3206	1.5844	1.6032
24	1.5655	1.6004	1.6221	1.5844	1.6221	.3018	1.6032
Max	1.6385	1.6975	1.6409	1.5844	1.6975	1.6032	1.6598
Min	1.4335	1.4523	1.4712	1.4901	.3206	.2263	.5658
Avg	1.5313	1.5565	1.5616	1.5425	1.4099	.7684	1.4531

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 202 / 11 KV Mahagaon Feeder From Sheddable Rural/Mix Feeder
33k Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.1341		1.4083	
2	.1509	.1341	.1341	.1174		1.4083	
3	.1509	.1341	.1341	.1174		1.4083	
4	.1509	.1341	.1174	.1174		1.3916	
5	.1341	.1174	.1174	.1174		1.3916	
6	.1174	.1006	.1174	.1006		1.3916	
7	.1174	.1006	.1006	.1006		1.3748	
8	.1006	.1006	.1006	.1006		1.3916	
9	.1174	.1174	.1006	.1174		1.358	.0838
10	.1341	.1174	.1677	.1174		1.3748	
11	.1341	.1174	.1677	.1341		1.358	.1006
12	.1341	.1174	.1341	.1341		1.3748	.1006
13	.1677	.1341	.1509	.1341		1.3748	.1006
14	.1677	.1341	.1509	.1341	.0838	.1341	.1006
15	.1844	.0838	.1174	.1509	.1677		.1006
16	.1509	.1006	.1174	.1341	.1509	.1509	
17	.1509	.1006	.1174	.1341	.1509	.1341	.1174
18	.1509	.1174	.1006		.1509	.1174	.1341
19	.1677	.1509	.1006		.218	.1006	.1509
20	.1844	.1844	.1509		.218	.1677	.2012
21	.218	.1677	.1341		.218	.1341	.1844
22	.2012	.1677	.1341		.4527		.1677
23	.1844	.1677	.1341		.9054		.1509
24	.1509	.1677	.1677	.1341		.8886	
Max	.218	.1844	.1677	.1509	.9054	1.4083	.2012
Min	.1006	.0838	.1006	.1006	.0838	.1006	.0838
Avg	.1530	.1299	.1299	.1239	.2716	.9445	.1303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314010 / 33/11KV KESHORI

Feeder No / Name : 203 / 11 KV Bondgaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4706	.394	.4298	.3582	.4119	.394
2	.4887	.4706	.3761	.4298	.3582	.3761	.3761
3	.4887	.4706	.3761	.4119	.3403	.3582	.3761
4	.4887	.4525	.3582	.4119	.3403	.3582	.3761
5	.4706	.4525	.3224	.3761	.3224	.3224	.3403
6	.362	.362	.3045	.2865	.2507	.3224	.3045
7	.362	.2896	.2865	.2865	.197	.2865	.2686
8	.362	.3258	.2865	.2865	.2149	.2328	.2686
9	.3801	.362	.2865	.3045	.2149	.3045	.2686
10	.362	.362	.3045	.3224	.2149	.3045	.2865
11	.3982	.3801	.3403	.3403	.2149	.3224	.2865
12	.4163	.4344	.3772	.3582	.2149	.3403	.3045
13	.4344	.4525	.394	.3761	.197	.3403	.3403
14	.4344	.4706	.4298	.394	.2865	.3582	.3761
15	.4344	.4525	.3721	.394	.3403		.3761
16	.4344	.362	.3224	.394	.3403	.3224	
17	.4163	.1991	.3045	.3224	.3224	.2865	1.6834
18	.3258	.3761	.3045		.3045	.3045	.3224
19	.362	.394	.3761		.3582	.3403	.3403
20	.4784	.4119	.4477		.4298	.394	.4656
21	.4961	.4477	.4835		.4477	.3403	.4477
22	.5249	.4477	.4835		.4477	.3761	.4298
23	.4887	.4298	.4656	.3761	.4119	.394	.3761
24	.5068	.4706	.394	.4477		.394	.394
Max	.5249	.4706	.4835	.4477	.4477	.4119	1.6834
Min	.3258	.1991	.2865	.2865	.197	.2328	.2686
Avg	.4343	.4061	.3663	.3657	.3099	.3387	.4088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 201 / 11 KV BHIVKHIDKI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.7164	.695	.6219	.6201	.631	.5895
2	.695	.691	.7023	.6401	.6089	.6201	.5721
3	.6767	.6805	.6838	.6219	.5973	.6201	.5959
4	.6767	.691	.6401	.6036	.5611	.591	.5784
5	.6584	.6836	.6036	.5487	.5373	.5493	.567
6	.6036	.6379	.4938	.4572	.4298	.5258	.5959
7	.5973	.6379	.4755	.4287	.3982	.5609	.6379
8	.5973	.6379	.4805	.4706	.4477	.4973	.7059
9	.5973	.6201	.4251	.439	.4887	.5375	.691
10	.6154	.4382	.3881		.4835	.5434	.6516
11	.5792	.3856	.4755	.5611	.5138	.5801	.7455
12		.4031	.5304	.6268		.6274	.7186
13		.6516	.6335	.5847	.6089	.6706	.7537
14	.3801	.703	.6516	.5959	.6805	.6133	.7973
15	.4572	.6001	.6335	.4733	.5014		.7712
16	.4706	.4115	.6268	.5493	.5138	.6036	.7888
17	.4755		.3582		.5014	.6613	.8669
18	.4801	.3521	.3353	.4191	.4374	.703	.6944
19	.5304	.4938	.5658		.5601	.7888	.8383
20	.8869	.8215	.6268		.7682	.7619	.9536
21	.8238	.8316	.2561		.7421	.7186	.9362
22	.788	.7947	.6584		.7202	.6588	.8402
23	.7522	.7207	.6219		.6415	.6068	.8059
24	.7059	.7164	.7133	.6401	.6201	.631	.6068
Max	.8869	.8316	.7133	.6401	.7682	.7888	.9536
Min	.3801	.3521	.2561	.4191	.3982	.4973	.567
Avg	.6247	.6226	.5531	.546	.5644	.6218	.7209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314015 / 33/11 KV NAVEGAON/BANDH

Feeder No / Name : 203 / 11 KV NAVEGAON/BANDH
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.9955	.9593	.695	.7164	.8954	.7796
2	.9877	.9774	.9231	.695	.7059	.8869	.788
3	.9877	.9694	.8779	.6767	.724	.8688	.7701
4	.9511	.9511	.823	.6584	.6805	.8048	.7522
5	.9145	.9328	.7865	.5853	.6697	.724	.7421
6	.7682	.6878	.6154	.5304	.5487	.6268	.7164
7	.695	.6878	.5731	.5304	.6154	.6268	.695
8	.695	.7343	.5973	.5611	.4938	.6379	.6154
9	.6878	.7701	.5973	.567	.5853	.6661	.6268
10	.8962	.9412	.6878		.724	.7619	.8682
11	.9145	.8238	.7499	.5973	.8954	.9036	.8859
12		1.0985	.6697	.6626		.8048	.8954
13		1.1443	.7783	.815	.8145	.8328	
14	1.1458	1.0288	.8145	.7343	.7964	.788	
15	1.0719	1.0631	.8326	.8417	.6335		.7087
16	1.1576	1.0288	.6984	.724	.4835	.6335	.8859
17	1.0642		.5373		.543	.6154	.929
18	.8063	.6516	.583	.5721	.7442	.6836	.9326
19	.9015	.8596	.631		.788	.7888	1.0099
20	1.1041	.9511	.6268		.9214	.7964	1.0566
21	1.1403	.9877	.7133		.9511	.8238	1.0566
22	1.1157	1.0242	.7316		.9593	.8238	1.0277
23	1.0242	.9877	.695		.8775	.8059	.9745
24	1.0242	1.0242	.9774	.695	.724	.8954	.7973
Max	1.1576	1.1443	.9774	.8417	.9593	.9036	1.0566
Min	.6878	.6516	.5373	.5304	.4835	.6154	.6154
Avg	.9572	.9270	.7283	.6554	.7215	.7694	.8415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 201 / 11KV ARJUNI MOR FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.7926	1.8111	1.6632	1.6632	1.5708	1.5708
2	1.7002	1.7556	1.7187	1.6263	1.6817	1.5524	1.5339
3	1.4784	1.6632	1.6817	1.5708	1.5708	1.5154	1.5524
4	1.6078	1.6448	1.6632	1.5154	1.4969	1.4969	1.5154
5	1.5154	1.6263	1.6263	1.386	1.4045	1.3491	1.2936
6	1.1827	1.4045	1.2936	1.2197	1.2012	.8316	1.0534
7	1.1643	1.2567	1.2936	1.0719	1.0534	1.0349	1.0534
8	1.0903	1.2382	1.2567	1.0349	1.1643	1.0719	1.0903
9	1.0534	1.2567	1.2382	.8871	1.0903	1.0903	1.1827
10	1.1458	1.3491	1.2567	.961	1.2936	1.2012	1.2012
11	1.1088	1.386	1.1088	1.3306	1.46	1.4784	1.3491
12	2.2916	1.423	1.2012	1.2936			1.2752
13	2.6427	1.3676	1.2567	1.0349	1.0534		1.2012
14	1.3676	1.3676	1.1458	1.0719	1.0534		1.3306
15	1.3491	1.2752	1.2752	1.0534		1.2382	1.5154
16	1.2567	1.386	1.2382	1.1458	.8871	1.2012	1.2567
17	1.1088	.924	.8316	1.0164	.8686	1.0534	1.2012
18	1.0534	1.0164	.7577		.8686	.8686	1.1643
19	1.0903	1.1643	.9795		.8871	1.0349	1.0903
20	1.3676	1.5339	1.0349		.9979	1.0534	1.1827
21	1.4415	1.3676	1.7002		1.2752	.924	1.2936
22	1.848	1.8665	1.7556		1.7187	1.6632	1.8665
23	1.885	1.8665	1.7187		1.6448	1.5893	1.8665
24	1.7002	1.7926	1.848	1.6448	1.7002	1.5893	1.5893
Max	2.6427	1.8665	1.848	1.6632	1.7187	1.6632	1.8665
Min	1.0534	.924	.7577	.8871	.8686	.8316	1.0534
Avg	1.4630	1.4469	1.3622	1.2515	1.2743	1.2575	1.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 202 / 11 KV Gothangaon Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.5121	.4938	.4572	.439	.4572	.4938
2	.4024	.5121	.4572	.4572	.4207	.4755	.5121
3	.4024	.4938	.439	.4207	.3841	.439	.4755
4	.3658	.4938	.4207	.3841	.3292	.439	.4572
5	.3475	.439	.3658	.3475	.2926	.4024	.3841
6	.3109	.3475	.3109	.2743	.2378	.2926	.2926
7	.2743	.2561	.2743	.2561	.1829	.2378	.2743
8	.3109	.2561	.2926	.2561	.1646	.2195	.2926
9	.2926	.2561	.3109	.2561	.2012	.2378	.2926
10	.2926	.2926	.4024	.2743	.2743	.3475	
11	.3292	.3475	.3475	.3109	.2926		.3292
12	.3841	.3292	.4024	.3292			.3475
13	.3841	.439	.3841	.3658	.3841		.439
14	.4207	.439	.3841	.4207	.3292		.5121
15	.439	.3841	.3292	.3841		.3658	.4755
16	.3475	.2561	.3109	.3475	.2926	.3292	.439
17	.3475	.2743	.2926	.3292	.2378	.3292	.4024
18	.3475	.2743	.3292		.2743	.3109	.3475
19	.4024	.3658	.4024		.4024	.4024	.4572
20	.5487	.5121	.4755		.4572	.4938	.4572
21	.5487	.5487	.5304		.4572	.4572	.4938
22	.5853	.5304	.4938		.4755	.5304	.5487
23	.5304	.4938	.4938		.4938	.5121	.567
24	.439	.5304	.5121	.4938	.4755	.4572	.5121
Max	.5853	.5487	.5304	.4938	.4938	.5304	.567
Min	.2743	.2561	.2743	.2561	.1646	.2195	.2743
Avg	.3948	.3993	.3940	.3536	.3408	.3868	.4262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 203 / 11 KV Sangadi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.5844	1.5655	1.6032	1.6221	1.6032	1.5278
2	1.5655	1.5844	1.5278	1.6221	1.6032	1.6032	1.5089
3	1.5466	1.5844	1.5466	1.5844	1.6221	1.6032	1.5089
4	1.5655	1.5844	1.5278	1.5655	1.5844	1.6032	1.5278
5	1.5466	1.5844	1.5278	1.5655	1.5278	1.6032	1.4712
6	1.5278	1.5278	1.5089	1.5655	1.5466	1.5466	1.4335
7	1.4712	1.5089	1.5089	1.5278	1.5844	1.5278	1.4146
8	1.4712	1.5278	1.4712	1.5655	1.5089	1.4712	1.4146
9	1.5089	1.4712	1.6975	1.5089	1.5089	1.4523	1.3957
10	1.5089	.9619	1.4712	1.5278	1.5089	1.4335	1.4146
11	1.4523	1.1883	1.4712	1.5089	1.6032	1.4335	1.3957
12	1.5466	1.5278	1.5089	1.5089			1.3957
13	1.5655	1.5466	1.5278	1.5466	1.5278		1.4335
14	1.5655	1.5278	1.5655	1.5278	1.5466		1.4523
15	1.5278	1.4712	1.5655	1.5278		1.4712	1.4712
16	1.5089	1.4335	1.6221	1.4712	1.4523	1.4146	1.4335
17	1.4712	1.4335	1.4335	.9619	1.4523	1.4146	1.4146
18	1.4335	1.4712	1.5278		1.4335	1.4335	1.3392
19	1.5466	1.5844	1.6032		1.5466	1.5278	1.4523
20	1.6598	1.6221	1.6975		1.6598	1.6409	1.6409
21	1.6221	1.6975	1.6598		1.6598	1.6221	1.6409
22	1.6221	1.6221	1.4523		1.6409	1.6787	1.6032
23	1.6032	1.6032	1.6598		1.6032	1.6787	1.5844
24	1.6032	1.5844	1.6032	1.5893	1.6221	1.6032	1.5466
Max	1.6598	1.6975	1.6975	1.6221	1.6598	1.6787	1.6409
Min	1.4335	.9619	1.4335	.9619	1.4335	1.4146	1.3392
Avg	1.5427	1.5097	1.5521	1.5155	1.5621	1.5412	1.4759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 204 / 11 KV Mahagaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.4207	.4024	.3658	1.2803	.3841	.3658
2	.3109	.4207	.3841	.3841	1.1888	.3658	.3475
3	.3109	.4024	.3841	.3475	1.1157	.3475	.3109
4	.2926	.3841	.3475	.3109	.9877	.3475	.2743
5	.2378	.3841	.2926	.2926	.8779	.3475	.2378
6	.2012	.2561	.2012	.2195	.7499	.2561	.2012
7	.1646	.2195	.1646	.1829	.695	.2012	.1463
8	.2012	.2012	.1829	.1463	.695	.2012	.1829
9	.2195	.2012	.2195	.1463	.7865	.2012	.2012
10	.2378	.2195	.2561	.1646	.7499	.2012	.2378
11	.2561	.2743	.1463	.2012	.9328		.2378
12	.2926	.2926	.2926	.2378			.2926
13	.3475	.3841	.3109	.3109	.9145		.3292
14	.3475	.3658	.3292	.3292	.2561		.3292
15	.3475	.3475	.2195	.3292		.2926	.3292
16	.3292	.2195	.2561	.2561	.1829	.2561	.2743
17	.2743	.1463	.1829	.1829	.2012	.1463	.2743
18	.2743	.1646	.1829		.1829	.2195	.2561
19	.3292	.2743	.2926		.2743	.2743	.3292
20	.4572	.4024	.4024		.3658	.4207	.4207
21	.4755	.439	.4207		.4207	.3841	.4938
22	.4755	.4207	.4207		.439	.3658	.4572
23	.439	.4207	.4024		.4024	.3658	.4755
24	.3841	.4207	.4024	.3841	1.3169	.4024	.3658
Max	.4755	.439	.4207	.3841	1.3169	.4207	.4938
Min	.1646	.1463	.1463	.1463	.1829	.1463	.1463
Avg	.3147	.3201	.2957	.2662	.6826	.2990	.3071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

MORGAON ARJUNI S/DN.[565] BU 0565

Substation No/ Name :- 314027 / 33/11 KV Arjuni/Morgaon

Feeder No / Name : 205 / 11 KV SANGADI AGP

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324		.0972		.081		.0648
2	.0324		.1134		.0972		.0648
3	.0324		.1134		.0972		.081
4	.0324		.0972		.1134		.0648
5	.0486		.1134		.1296		.081
6	.0486		.1296		.1296		.081
7	.0486		.1134		.1134		.081
8	.0486		.1296		.1134		.0972
9	.0486		.0972		.0972		.081
10		.0324		.0324			
11		.0324		.0972			
12		.0648		.081			
13		.081		.0972			
14		.0972		.1296			
15		.0972		.1296		.1296	
16		.0972		.1296		.1134	
17		.081		.081		.1296	
24			.0324		.0486		.0648
Max	.0486	.0972	.1296	.1296	.1296	.1296	.0972
Min	.0324	.0324	.0324	.0324	.0486	.1134	.0648
Avg	.0414	.0729	.1037	.0972	.1021	.1242	.0761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA SUB-STATION

Feeder No / Name : 202 / 11KV SADAK ARJUNI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.7133	.6335	.3239		.4572	.4763
2	.6516	.7059	.6154	.3239		.4572	.4763
3	.6335	.695	.5973	.3048		.4572	.4572
4	.6722	.6878	.5973	.3048		.4382	.4572
5	.6722	.6878	.5792	.2858		.4382	.4435
6	.5611	.583	.5028	.2286		.381	.439
7	.5201	.547	.4854	.2126		.3658	.4252
8	.5201	.5898	.4458	.2303		.2957	.4458
9	.4854	.6464	.4801	.2096		.3475	.4656
10	.5083	.6706	.4458	.2477		.3841	.4681
11	.5609	.7186	.4854	.3841		.4458	.5256
12	.6556	.7537	.4854	.4024		.4656	.5609
13	.6516	.7888	.4854	.439		.4656	.6201
14	.691	.8495	.4527			.5014	.6379
15	.6733	.823			.3292	.4024	.5973
16	.6001		.5609		.3658	.4656	
17	.583				.4607	.4252	.5959
18	.6464	1.1283			.3658	.5028	.6274
19	.7164	1.2803			.4805		.7522
20	.8048	.7316			.5335		.7865
21	.8048	.7133	.3429		.5335	.5175	.7468
22	.8048	.6767	.3429		.4954	.4954	.7133
23	.7316	.6516	.3239		.4763	.4763	.6584
24	.6722	.7316	.6335	.3429		.4572	.4763
Max	.8048	1.2803	.6335	.439	.5335	.5175	.7865
Min	.4854	.547	.3239	.2096	.3292	.2957	.4252
Avg	.6447	.7443	.4998	.3029	.4490	.4383	.5588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314003 / 33/11KV DAWWA SUB-STATION

Feeder No / Name : 203 / 11KV PANDHRI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6908	.6859	.5525		.5906	.5716
2	.6859	.7049	.6348	.5359		.5906	.5716
3	.6722	.6722	.6161	.5175		.5906	.5335
4	.6668	.6722	.6097	.5144		.5716	.5525
5	.6478	.6722	.6097	.4954		.5335	.5335
6	.4763	.4805	.4382	.4001		.381	.4382
7	.3841	.4075	.3658	.3109		.3239	.381
8	.4024	.4252	.3658	.3258		.3239	.362
9	.3658	.443	.4024	.2896		.3239	.3658
10	.4024	.439	.3841	.3077		.362	.3841
11	.439	.5175	.439	.3658		.4024	.3841
12	.4954	.5914	.462	.362		.462	.4001
13	.5914	.5914	.5544	.4191		.5175	.4001
14	.5729	.6283	.5544			.4805	.4001
15	.5729	.5544	.5175		.4207	.3841	.4763
16	.4805	.4428	.499		.4191	.4191	
17	.462				.362	.4207	.4207
18	.499	.3841			.3658	.4191	.4251
19	.6348	.5716			.5335		.5914
20	.7621	.724	.1905		.5716		.7811
21	.7811	.7621	.5335		.6287	.6097	.7621
22	.7468	.724	.5716		.6668	.6097	.7468
23	.7282	.6859	.5525		.6097	.5716	.6535
24	.7049	.7095	.6859	.5335		.6097	.5716
Max	.7811	.7621	.6859	.5525	.6668	.6097	.7811
Min	.3658	.3841	.1905	.2896	.362	.3239	.362
Avg	.5775	.5867	.5082	.4236	.5087	.4772	.5090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 201 / 11KV KOKANA FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5853	.4854	.4108	.462	.6602	.543
2	.499	.5914	.463	.4161	.4525	.6348	.5249
3	.5041	.5914	.463	.362	.4525	.6287	.4887
4	.4938	.5729	.4359	.3475	.4435	.6287	.4706
5	.4854	.5175	.4024	.3292		.6224	.4477
6	.4854	.5041	.39	.2766	.4338	.6036	.4938
7	.4715	.5041	.394	.2601		.5906	.6089
8	.5281	.5281	.3982	.306	.4251	.6097	.7545
9	.5041		.4207	.3353	.5093	.6478	.8215
10	.5415	.7167	.5359	.3391	.5658	.7621	.8215
11	.6161	.7733	.5359	.4572			.8501
12	.743	.811	.6036	.4938	.7545	.8215	.9149
13	.7621	.7922	.6224	.4854	.811	.8316	.9522
14	.4251	.724	.6224	.5041	.7922	.7545	.8488
15	.5415	.679	.6036	.4854			
16	.5359	.4344	.5601	.5281	.7842	.7316	
17	.6097		.4298	.4108	.7947	.7655	.8962
18	.6097	.3467	.1698	.4527	.7164	.7282	.961
19	.6413	.4508	.421		.7733	.6859	.9335
20	.6908	.4854	.4012		.7811		.8871
21	.6908	.4801	.3961		.7621	.0655	.8779
22	.6535	.4557	.3961	.4904	.7049	.5611	.7947
23	.5975	.4287	.3864	.4668	.6668	.5304	.7842
24	.5415	.5914	.4917	.4108	.4904	.6602	.543
Max	.7621	.811	.6224	.5281	.811	.8316	.961
Min	.4251	.3467	.1698	.2601	.4251	.0655	.4477
Avg	.5698	.5711	.4595	.4080	.6288	.6440	.7372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 202 / 11KV TIDKA FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.1692	.1475	.0867	.0734	.1423	.125
2	.208	.1715	.1389	.0867	.0714	.1406	.125
3	.2054	.1715	.1337	.0867	.0734	.1389	.125
4	.1932		.1355	.0914	.0059	.128	.125
5	.2054	.16	.1562	.0924	.0587	.1265	.125
6	.208	.1555	.1989	.104	.0587	.125	.1158
7	.1635	.0153	.2012	.0693		.1252	.1315
8	.1783	.1509	.2374	.0671	.0556	.104	.1669
9	.176	.1734	.2294	.08	.0429	.1054	.1858
10	.176	.1669	.2172	.0564	.061	.1219	.1858
11	.1783	.1957	.2172	.0572			.2
12	.1783	.1981	.2229	.1054	.2328	.1739	.2172
13	.1738	.1858	.2201	.1094	.2328	.1718	.2027
14	.1692	.1858	.2172	.7545	.2507	.1543	.2027
15	.1833	.1806	.2347	.0663			
16	.1738	.1572	.2201	.0335	.2715	.1677	
17	.2172		.1391		.2507	.1758	.2439
18	.176	.1149		.0133	.1646	.1446	.2778
19	.2027	.1149	.0191		.1612	.1562	.2439
20	.1907	.1781	.0191		.1619		.2439
21	.2	.1619	.0953		.1781	.1372	.2469
22	.1738	.1638	.0953	.0686	.1823	.1357	.253
23	.1692	.1492	.0867	.0667	.1509	.125	.2286
24	.1932	.1692	.1457	.0867	.0724	.1406	.125
Max	.2172	.1981	.2374	.7545	.2715	.1758	.2778
Min	.1635	.0153	.0191	.0133	.0059	.104	.1158
Avg	.1868	.1586	.1621	.1091	.1339	.1400	.1862

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314019 / 33/11KV SOUNDAD SUB-STATION

Feeder No / Name : 203 / 11KV FUTALA FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5729	.7133	.6099	.5544	.6154	.5914	.7343
2	.5544	.6697	.5853	.5525	.567	.5853	.6733
3	.5249	.7095	.5853	.5335	.543	.5847	.5973
4	.5304	.5914	.5175	.4805	.4706	.5788	.6283
5	.5228	.4755	.4207	.4763	.4805	.5335	.5853
6	.3881	.3982	.3841	.3429	.4706	.4572	.5601
7	.3361	.3601	.3475	.3239		.4191	.5041
8	.3366	.3658	.3292	.2926	.4854	.3734	.5249
9	.3511	.4024	.3475	.2865	.415	.4108	.4115
10	.4481	.4251	.5359	.4119	.3841	.4251	.5121
11	.5359	.4251	.5359	.5121			.5068
12	.5729	.5729	.4854	.5544		.5729	.5487
13	.6219	.6335	.4854	.5121	.5973	.5788	.5853
14	.6283	.5914	.5914	.5544	.6154	.6099	.6099
15	.5914	.6283	.5729	.567			
16	.567	.3856	.4887	.567	.5959	.5729	
17	.4656		.3658	.5228	.5201	.5487	.5228
18	.4298	.4024	.362	.462	.4557	.5256	.4854
19	.5973	.499	.4191		.4508	.6733	.5544
20	.7095	.5716	.4954		.5258	.5973	.5973
21		.6287	.5144		.5729	.6805	.6447
22	.7655	.6097	.5716	.567	.5493	.7343	.6379
23	.7207	.5853	.5906	.6219	.6089	.7343	.6268
24	.5975	.695	.6161	.5373	.6201	.5487	.7522
Max	.7655	.7133	.6161	.6219	.6201	.7343	.7522
Min	.3361	.3601	.3292	.2865	.3841	.3734	.4115
Avg	.5378	.5365	.4899	.4873	.5272	.5608	.5820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 202 / 11KV DUGGIPAR FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7865	.7059	.5792	1.7147
2	.7202	.7682	.6878	.5792	1.7147
3	.7421	.7499	.6516	.5792	1.5775
4	.724	.7316	.5792	.5792	1.5089
5	.6878	.695	.5068		1.5432
6	.6154	.5853	.5068	.4706	1.3717
7	.5611	.5487	.4887	.4525	1.2269
8	.5611	.5304	.4163	.4525	.4973
9	.5487	.5304	.4344	.4344	.703
10	.583	.6401	.4525	.4706	.7373
11	.6344	.7716	.5249	.5658	
12	.8596	.7716	.6878	.6001	
13	.8413	.7888	.7059	.6859	
14	.8596	.8059	.6335	.6687	
15	.8413	.7888	.6516	.6859	
16	.7499		.5973	.6001	.5973
17	.7316		.5792	.4908	.6335
18	.6584				.5068
19	.7133	.009	.5611		
20	.8048	.724	.6154		
21	.8596	.7602	.6335		
22	.8413	.7602	.6516		
23	.823	.7421	.6335	1.8404	
24	.7545	.8048	.724	.6154	1.7147
Max	.8596	.8059	.724	1.8404	1.7147
Min	.5487	.009	.4163	.4344	.4973
Avg	.7279	.6806	.5926	.6306	1.1463

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 203 / 11KV SAWANGI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2427	.2058	.1886	.1928	.7802	.7537
2	.2204	.2427	.2058	.1886	.1949	.823	.7362
3	.2254	.2427	.2058	.1886	.1715	.7125	.7362
4	.2254	.2427	.2058	.1886	.1753	.7316	.7362
5	.208	.2427	.1715		.1448	.7316	.7186
6	.2254	.208	.1715	.1214	.1417	.695	.5959
7	.208	.208	.0154	.1214	.1227		.5959
8	.208	.208	.1886	.1214	.12	.5847	.5959
9	.2374	.208	.1886	.0867	.1417	.5895	.6485
10	.2543	.2254	.1886	.12	.1227	.6762	.7186
11	.2374	.2204	.2229	.1578			.5784
12	.2601	.2204	.2058	.1372		.9114	.5959
13	.2601	.2374	.2401	.1715		.929	.6485
14	.2774	.2374	.2229	.1543		.8589	.9882
15	.2427	.2374	.1715	.1595			1.0166
16	.2254		.2229	.1543	.1734	.8939	.9816
17	.2427		.1907	.1063	.1907	.1052	.9362
18	.2601	.1715	.1387		.1907	.7712	.8322
19	.2427	.1886	.156		.1734	.8063	.8505
20	.2774	.2229	.1907		.8145	.7186	1.0166
21	.2774	.2229	.208		.8842	.7712	.9945
22	.2774	.2229	.208		.8669	.7888	1.0402
23	.2601	.2058	.1907	.1928	.8322	.7888	.9991
24	.2374	.2427	.2058	.1907	.1886	.7975	.7712
Max	.2774	.2427	.2401	.1928	.8842	.929	1.0402
Min	.208	.1715	.0154	.0867	.12	.1052	.5784
Avg	.2428	.2228	.1884	.1528	.3075	.7364	.7952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 204 / 11KV CHIKHLI NEW FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2107		.2481	.2126	.3012	.3467	.3605
2	.2107	.3315	.2481	.2126	.3077	.3467	.3605
3	.1054	.3113	.2481	.2126	.298	.3467	.3563
4	.2204	.3113	.2481	.1949	.3012	.3467	.3563
5	.2204	.3113	.2481		.2896	.3294	.3563
6	.2204	.2778	.1898	.2058	.3012	.3294	.3281
7	.2543	.2972	.1898	.2229	.3086	.3467	.3864
8	.2713	.3041	.2214	.2058	.3366	.4161	.4755
9	.3142	.2934	.2126	.2614	.3681	.4161	.4548
10	.2957	.2743	.2835	.2658	.3506	.4854	.286
11		.2559	.2658	.2683	.3801		.6068
12		.2408		.25	.4508	.3125	.6135
13		.2559	.2656	.2896	.4508	.4268	.6344
14		.2559	.2968	.3429	.4508	.463	.5375
15		.2408		.3506			.5784
16			.25	.3429	.3601	.4515	.4973
17			.2374	.5316	.3429	.4401	.583
18		.1581	.2374		.3641	.4401	.5895
19	.3812	.2056	.1865		.4161	.4372	.5895
20	.4161	.2688	.1865		.4344	.3978	.583
21	.4115	.253	.2035		.3814	.4191	.5487
22	.3772	.2372	.2035		.3641	.3768	.4681
23	.3521	.2056	.1865	.3012	.3467	.3768	.4458
24	.2107	.3521	.2481	.1865	.2915	.3467	.3768
Max	.4161	.3521	.2968	.5316	.4508	.4854	.6344
Min	.1054	.1581	.1865	.1865	.2896	.3125	.286
Avg	.2795	.2687	.2321	.2699	.3564	.3908	.4739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SADAK ARJUNI S/DN.[811] BU 4811

Substation No/ Name :- 314030 / 33/11KV KOHMARA SUB-STATION

Feeder No / Name : 205 / 11KV BAMNI KHADKI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.1097	.1109		.0876	.0886	.0914
2	.1147	.1097	.1109		.0857	.0886	.0914
3	.1147	.1097	.1109		.0905	.0886	.0905
4	.116	.1097	.1109		.0857	.1063	.0895
5	.0995	.1086	.1109		.0701	.0886	.0895
6	.0819	.0995	.0739		.0709	.0709	.0678
7	.0655	.081	.0055		.0709	.0709	.0819
8	.0819	.0949	.0554		.0876	.0709	.0734
9	.0819	.1107	.0554		.0857	.0886	.0772
10	.0082	.1134	.0739		.0876	.0886	.096
11	.0101	.1311	.037		.0886		.1006
12	.104	.1147	.0185		.0709	.112	.1006
13	.1063	.1311	.017		.0709	.0895	.1174
14	.1227	.1311		.061	.0895	.0914	.1134
15	.1052	.1147	.1294	.0343			.1067
16	.0886		.1294	.12	.0829	.0753	.0838
17	.0983		.0819	.0686	.0663	.096	.12
18	.108	.0037	.0819		.0886	.0949	.1417
19	.1254	.1294	.0819		.0886	.124	.1417
20	.1663	.1478			.1267	.112	.1715
21	.1663	.1478			.1063	.1109	.1619
22	.1402	.1294			.1063	.1097	.1417
23	.1294	.1294		.0876	.104	.0914	.12
24	.1147	.1109	.1109		.0857	.1063	.0914
Max	.1663	.1478	.1294	.12	.1267	.124	.1715
Min	.0082	.0037	.0055	.0343	.0663	.0709	.0678
Avg	.1027	.1122	.0793	.0743	.0869	.0938	.1067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 201 / 11 KV Salekasa

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3353	.2753	.362	.3353	.3401	.1619
2	.3658	.3601	.2753	.362	.3222	.3401	.1619
3	.3326	.3521	.2753	.3475	.3052	.3239	.1619
4	.2587	.3353	.2753	.3475	.285	.3239	.1619
5	.2772	.3391	.2591	.3109	.2652	.3077	.1619
6	.2926	.2683	.2105	.2957	.2543	.2915	.1619
7	.2534	.2683	.1943	.1848	.2204	.3077	.1457
8	.2926	.3018	.1296	.2587	.2035	.2429	.1457
9	.2915	.3077	.2012	.181	.2267	.2561	.1844
10	.2591	.362	.2713	.1829	.2105	.2896	.1509
11	.2753	.362	.3018	.2561	.2591		.1696
12	.2915	.362	.3856	.2378	.2915	.4525	.1357
13	.3077	.3982	.373	.2561	.2915	.4163	
14	.2753	.3841	.4115	.2402	.3563	.3258	
15	.2753		.3018	.2561	.1943		
16	.2429	.1097	.2515	.2561	.2591	.3439	
17	.2347	.0972	.2378		.2915	.2915	.2926
18	.3185	.1457	.3292		.3239	.3239	.3077
19	.4239	.2591	.362	.3185	.3887		.362
20	.4191	.3401	.4525	.3521	.4372	.1134	.4706
21	.4359	.3563	.4344	.3561	.4049	.1943	.4887
22	.4359	.3239	.4163	.3353	.4049	.1619	.4525
23	.373	.3239	.3982	.3353	.3887	.1619	.4344
24	.3801	.3353	.2915	.4024	.3353	.3401	.1619
Max	.4359	.3982	.4525	.4024	.4372	.4525	.4887
Min	.2347	.0972	.1296	.181	.1943	.1134	.1357
Avg	.3198	.3055	.3048	.2925	.3023	.2928	.2437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 202 / 11 KV Tirkhedi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.0174	.8745	.8326	.7545	.8745	.583
2	1.086	.9724	.8421	.8145	.7461	.8745	.583
3	1.0679	.9496	.8421	.8145	.7042	.8097	.583
4	.9955	.9326	.8421	.7602	.6783	.7935	.583
5	.8688	.9054	.7773	.724	.5935	.7611	.583
6	.7421	.6859	.664	.6516	.5596	.6316	.5344
7	.7059	.6706	.5992	.5792	.4973	.6316	.502
8	.6878	.7042	.6478	.6516	.5365	.6154	.5182
9	.4534	.7602	.6203	.5792	.5182	.6516	.5197
10	.6316	.7964	.6539	.695	.4534	.724	.5426
11	.7125	.8688	.6371	.7059	.5344		.5365
12	.7611	.905	.6874	.7783	.5344	.7783	.5533
13	.8097	1.0498	.788	.7421	.5506	.8688	
14	.8745	.8145	.8048	.7602	.5344		
15	.7611		.788	.543	.5668		
16	.7611	.362	.5197	.4344	.5344	.724	
17	.7545	.3563	.5611		.5182	.6478	.543
18	.8048	.5506	.6154		.583	.7287	.724
19	.8886	.7287	.7602	.6203	.7611		.8869
20	1.1568	.9717	.8688	.8048	.9393	.6478	1.086
21	1.153	1.0202	.9231	.8139	.9878	.6478	.9412
22	1.17	.9717	.9231	.8048	.9717	.6316	1.1584
23	1.1022	.9717	.905	.7969	.9555	.6154	1.1222
24	1.1403	1.0395	.9231	.8688	.7712	.8907	.5992
Max	1.17	1.0498	.9231	.8688	.9878	.8907	1.1584
Min	.4534	.3563	.5197	.4344	.4534	.6154	.502
Avg	.8823	.8263	.7528	.7171	.6577	.7274	.6841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 203 / 11 KV Darekasa

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2347	.1457	.1848	.2012	.2105	.1619
2	.2218	.2374	.1457	.168	.1865	.2105	.1619
3	.2218	.218	.1457	.1663	.1865	.2105	.1619
4	.2218	.2204	.1457	.1646	.1865	.2267	.1619
5	.1867	.218	.1457	.1478	.1696	.1943	.1619
6	.168	.1509	.0972	.1307	.1526	.1457	.1296
7	.112	.1174	.081	.0972	.1187	.1134	.0972
8	.0924	.1174	.081	.0924	.1017	.0972	.0648
9	.0972	.1294	.1174	.056	.081	.1109	.1006
10	.1134	.1109	.1017	.0934	.0648	.0924	.0838
11	.1134	.1109	.1006	.1109	.0648		.1006
12	.1134	.1494	.1187	.1294	.0648	.112	.1174
13	.1296	.1663	.1341	.1478	.0648	.1494	
14	.1296	.1478	.1174	.1663	.081		
15	.1296		.1174	.1478	.0648		
16	.1134	.0754	.0678	.1663	.0486	.1478	
17	.1187	.0648	.0924		.0972	.0972	.1294
18	.1187	.0648	.0934		.1134	.1296	.0373
19	.1696	.1134	.1307	.2012	.1781		.2033
20	.2515	.1781	.2218	.2515	.2429		.3109
21	.2683	.1943	.2241	.2374	.2429	.1781	.3109
22	.2713	.1781	.2054	.2204	.2429	.1781	.2957
23	.2347	.1619	.2054	.2204	.2429	.1619	.2587
24	.2402	.2374	.1619	.1867	.2012	.2105	.1619
Max	.2713	.2374	.2241	.2515	.2429	.2267	.3109
Min	.0924	.0648	.0678	.056	.0486	.0924	.0373
Avg	.1699	.1564	.1332	.1585	.1416	.1567	.1606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 204 / 11 KV Water Works

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0149	.0168	.0162	.0633	.0168	.0162	.0162
2	.0149	.0168	.0162	.0305	.0166	.0162	.0162
3	.0301	.017	.0162	.0305	.017	.0162	.0162
4	.0301	.017	.0162	.0309	.0168	.0162	.0162
5	.0305	.017	.0162	.0324	.0168	.0162	.0162
6	.0781	.1174	.081	.032	.0848	.081	.1134
7	.1094	.1174	.1134	.1094	.1174	.1134	.1134
8	.1094	.1174	.081	.1067	.1174	.1134	.1134
9	.1134	.1067	.1174	.1067	.1134	.1067	.1174
10	.1134	.1067	.1174	.1067	.1134	.1067	.1174
11	.1134	.1067	.116	.1067	.1134		.1174
12	.1134	.0625	.1187	.1067	.0648	.0762	.1174
13	.1134	.1067	.0663	.1067	.1134	.1067	
14	.1134	.1067	.1174	.1067	.1134		
15	.1134			.1067	.1134		
16	.1134	.0469	.0339	.1067	.1134	.1067	
17	.1187		.1067		.1134	.1134	.1067
18	.1174		.1094		.1134	.1134	.1067
19	.1174	.0324	.1067	.1174	.1134		.108
20	.1187	.081	.1094	.1174	.1134	.081	.1067
21	.0503	.1134	.1067	.0838	.0324	.081	.0457
22	.017	.1134	.1067	.1006	.0324	.0324	.0309
23	.0171	.0324	.1067	.0339	.0324	.0162	.0297
24	.0151	.0168	.0162	.1067	.0168	.0162	.0162
Max	.1187	.1174	.1187	.1174	.1174	.1134	.1174
Min	.0149	.0168	.0162	.0305	.0166	.0162	.0162
Avg	.0790	.0700	.0788	.0841	.0762	.0673	.0721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314005 / 33/11 KV SALEKASA

Feeder No / Name : 211 / 11 kv Salekasa AGP Feeder AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0686	.0486			.0324	.0324
2	.0324	.0678	.0486				.0324
3	.0332	.0671	.0486			.0324	.0324
4	.0332	.0678	.0486			.0486	.0324
5	.0324	.0671	.0486			.0324	
6	.0857	.1187	.081			.0972	.0324
7	.12	.1357	.0972			.1457	.0324
8	.1372	.1341	.1134			.1619	.0324
9	.1457	.12	.1174			.12	.0335
10	.1457	.1372	.1017	.0924	.1134	.1715	
11	.1134	.1543	.1357	.1715	.1134		.0335
12	.1457	.1543	.1017	.1029	.1457	.2058	.0335
13	.1296	.1372	.1006	.0686	.1457	.2058	
14	.1134	.0686	.1006	.0594	.1296		
15	.1134		.1029		.1457		.0848
16	.1134	.0497			.1457	.2572	.0838
17	.1326	.0648			.1134	.2591	.1029
18	.0335	.0486			.0324	.0486	.0343
19	.0678	.0324			.0486		.0351
20	.0838	.0324			.0486	.0324	.0686
21	.0678	.0486			.0486	.0324	.0686
22	.0671	.0486			.0486	.0324	.0446
23	.0671	.0486			.0503	.0324	.0503
24	.0486	.0671	.0486			.0324	.0324
Max	.1457	.1543	.1357	.1715	.1457	.2591	.1029
Min	.0324	.0324	.0486	.0594	.0324	.0324	.0324
Avg	.0880	.0843	.0840	.0990	.0950	.1042	.0466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 205 / 11KV SAKHRITOLA FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.6268	.591	.5014	.5373	.5014	.3403
2	.6447	.6089	.5552	.4656	.5373	.4656	.3403
3	.6268	.5731	.5014	.4656	.5014	.4298	.3224
4	.6089	.5731	.4656	.4298	.5014	.4119	.3045
5	.5373	.5373	.4119	.4298	.4656	.3761	.3045
6	.4119	.3761	.3761	.3224	.3582	.3582	.2686
7	.3582	.3403	.3045	.3045	.2686	.3403	.2507
8	.3045	.3224	.3403	.3045	.2686	.3582	.2865
9	.3366	.3224	.2686	.3224	.2686	.3403	.2865
10	.3403	.4119	.394	.3582	.2865	.3582	.3045
11	.3403	.1612	.197	.4119	.3224	.4477	.2865
12	.3582	.197	.3403	.4477	.1791	.4477	.4119
13	.5373	.4477	.3582	.4298	.1791	.5194	.394
14	.5373	.5373		.4298			.4119
15	.5194		.5014	.2149			.3582
16	.4119	.1791	.3403	.1829	.394	.4835	
17	.4477	.197	.2507		.3582	.394	.3224
18	.4298	.2149	.2686		.3761	.3761	.3224
19	.2507	.2507	.4477		.5373		.4656
20	.5731	.6268	.4298		.5194		.6089
21	.6805	.3761	.5194		.591	.3403	.6447
22	.6626	.6984	.5373		.5731	.4119	.6268
23	.6447	.6626	.5194		.5552	.3582	.591
24	.6447	.6447	.6447	.5014	.5373	.5373	.3403
Max	.6805	.6984	.6447	.5014	.591	.5373	.6447
Min	.2507	.1612	.197	.1829	.1791	.3403	.2507
Avg	.4938	.4298	.4158	.3837	.4144	.4128	.3823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 206 / 11KV SONEKHARI FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.6219	.4755	.3582	.3881	.4066	.3109
2	.5121	.5973	.4525	.3506	.3696	.3881	.3077
3	.4706	.6036	.4344	.3544	.3696	.3658	.3109
4	.4706	.5792	.4119	.3544	.3658	.3475	.3142
5	.4525	.5121	.394	.3403	.3658	.3258	.3142
6	.4119	.4207	.3721	.3045	.3109	.3258	.2772
7	.3688	.3521	.3052	.2481	.2835	.3224	.2507
8	.3353	.3277	.2652	.2035	.2126	.2658	.2454
9	.3222	.3563	.2622	.2155	.2126	.2229	.1928
10	.3391	.407	.3353	.116	.2149	.2629	.2328
11	.39	.4239	.3561	.3077	.2561	.2804	.2103
12	.4287	.4508	.3988	.3012	.2195	.2835	.2543
13	.4557	.4908	.3506	.333	.2126	.3189	
14	.4557	.4908	.3511	.2947			.2587
15	.4382	.2321	.3561	.1844			.2614
16	.4287	.213	.1595		.2481	.3045	
17	.3561	.2486	.1928		.2629	.2601	.2507
18	.4024	.3429			.2229	.3052	.2774
19	.5014	.462					.499
20	.6653	.5788			.547	.3326	.5228
21	.6653	.6099	.4108		.547	.3734	.6036
22	.6401	.5544	.4066		.4854	.2957	.5792
23	.6401	.5121	.3696		.4435	.3109	.5175
24	.5121	.6468	.4938	.3582	.3881	.4251	.3109
Max	.6653	.6468	.4938	.3582	.547	.4251	.6036
Min	.3222	.213	.1595	.116	.2126	.2229	.1928
Avg	.4656	.4598	.3597	.2890	.3298	.3202	.3319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812] BU 4812

Substation No/ Name :- 314018 / 33/11KV SAKHRITOLA S/Stn.

Feeder No / Name : 207 / 11KV HETI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2804	.2715	.2865	.2172	.2667	.1734
2	.2896	.298	.2507	.2804	.2172	.2477	.1753
3	.2686	.2947	.2328	.2835	.2172	.2286	.1772
4	.2686	.2683	.2303	.2481	.2172	.2096	.1629
5	.2686	.2515	.2126	.2507	.2172	.1905	.1715
6	.1949	.1865	.2103	.197	.181	.1905	.1715
7	.1543	.1949	.1753	.1562	.1578	.1715	.1433
8	.1509	.208	.2515	.1107	.1267	.125	.1357
9	.1475	.1619	.1823	.1581	.128	.125	.1417
10	.1638	.1734	.1581	.1296		.1524	.1372
11	.1638	.1886	.144	.1715	.128	.1715	.1372
12	.2012	.2229	.1457	.1715		.1734	.1463
13	.218	.2427	.1802	.1928	.128	.1907	.1417
14	.213	.2229	.2155	.1928			.1791
15	.1966	.1509	.1802				.181
16	.1696	.12	.1372		.1991	.1543	
17	.1949		.1578		.1267	.1402	.1254
18	.1928	.1543	.1402		.181	.156	.1463
19	.2507	.2254	.298		.2507		.2402
20	.333	.3155	.3048		.3045	.1612	.3326
21	.3841	.3294	.2713		.3239	.2103	.3439
22	.3439	.2947	.2896		.3239	.2033	.3292
23	.3258	.3077	.2804		.3048	.197	.2865
24	.2896	.3155	.2896	.2865	.2172	.2858	.1928
Max	.3841	.3294	.3048	.2865	.3239	.2858	.3439
Min	.1475	.12	.1372	.1107	.1267	.125	.1254
Avg	.2364	.2351	.2171	.2077	.2084	.1882	.1901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 208 / 11kv kawarabandh

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.4954	.4763	.362	.4191	.5525	.5716
2	.6859	.4001	.3239	.3429	.4763	.5716	.5335
3	.6478	.4191	.381	.2667	.4382	.5525	.5335
4	.6859	.4382	.3429	.2667	.3429	.4763	.4954
5	.6859	.4382	.3429	.3239	.381	.4382	.4572
6	.5716	.381	.381	.3048	.4001	.381	.5906
7	.3239	.2858	.3429	.2477	.4191	.4191	.4191
8	.6097	.2858	.3048	.2477	.4382	.4191	.4191
9	.2286	.4382	.2667	.2667	.2477	.4763	.4001
10	.5716	.3429	.362	.3048	.2858	.5525	.4001
11	.5144	.5335	.2286	.3048	.3048	.5716	.4191
12	.6097	.4382	.381	.2477		.5716	.5144
13	.5144	.5716	.3048	.4191	.2858	.4763	.5716
14	.381	.4382	.3239	.4001	.4001		.5144
15	.381	.4382	.3292	.2286			.6097
16	.4001	.381	.381	.1334	.381	.3429	
17	.3429		.3429	.1715	.381	.381	.4382
18	.3239	.4435	.3048		.3048	.381	.5716
19	.4572	.4382	.362		.4572		.5716
20	.5716	.5525	.381		.4191	.3429	.5906
21	.5716	.5716	.4001		.4763		.5906
22	.6097	.5906	.381		.4954		.8002
23	.6287	.3239	.381		.5525	.1905	.7621
24	.8764	.5335	.5144	.362	.381	.5525	.5525
Max	.8764	.5906	.5144	.4191	.5525	.5716	.8002
Min	.2286	.2858	.2286	.1334	.2477	.1905	.4001
Avg	.5438	.4426	.3558	.2890	.3949	.4552	.5359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 209 / 11kv sonpuri

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.381	.3239	.3224	.3258	.3658	.2286
2	.2858	.362	.3239	.3045	.3077	.3511	.2286
3	.2667	.362	.3239	.2686	.3077	.3475	.2286
4	.2477	.362	.3239	.2686	.3077	.3475	.2286
5	.2477	.3048	.2804	.2507	.2715	.3258	.2286
6	.2286	.2286	.2012	.2328	.2328	.2481	.1715
7	.1372	.1928	.1509	.2012	.2353	.2865	.1949
8	.1372	.2126	.1406	.1844	.2896	.2896	.2126
9	.1905	.1949	.1629	.218	.2534	.1991	.1143
10	.1905	.1595	.2172	.2012	.2378	.2353	.1991
11	.1905	.2126	.0358	.2012	.2347	.2172	.181
12	.1753	.2481	.1267	.1509		.2534	.2374
13	.2507	.3045	.1448	.2012	.2543	.3258	.2374
14	.2686	.3109	.1646	.2374	.2058		.2515
15	.2481	.2865	.3077	.1991			.2515
16	.2126	.0834	.2303	.1791	.2543	.2534	
17	.181		.2303	.1829	.2347	.2353	.1174
18	.2353	.1638	.2481		.1928	.3121	.218
19	.3239	.2858	.2658		.2865		.2515
20	.4207	.3429	.3189		.3841	.2286	.2683
21	.4207	.381	.3544		.3982	.2096	.3258
22	.3881	.3429	.3366		.4024	.2096	.3258
23	.381	.3429	.3224		.362	.2286	.3086
24	.3048	.381	.3239	.3224	.3258	.3658	.2286
Max	.4207	.381	.3544	.3224	.4024	.3658	.3258
Min	.1372	.0834	.0358	.1509	.1928	.1991	.1143
Avg	.2591	.2803	.2441	.2293	.2866	.2779	.2277

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

DEORI DIVISION[657]

SALEKASA S/DN.[812]

BU 4812

Substation No/ Name :- 314021 / kawarabandh 33kv/11kv

Feeder No / Name : 210 / 11KV NAVEGAON FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2858	.3292	.2543	.2534	.3475	.2096
2	.2477	.2858	.3109	.2572	.2534	.3292	.2096
3	.2477	.2858	.2896	.2229	.2534	.3224	.2286
4	.4001	.2858	.2715	.2401	.2149	.3045	.2286
5	.2096	.2286	.2534	.2058	.2353	.2774	.2096
6	.1715	.1905	.2149	.1886	.1578	.2481	.1905
7	.1341	.1296	.197	.1791	.1387	.2204	.1543
8	.1341	.1638	.1638	.197	.1734	.2572	.1543
9	.1578	.1638	.1886	.2149	.1928	.2572	.2058
10	.1578	.1638	.1753	.1791	.1578	.2401	.2229
11	.1402	.213	.2126	.1753	.1753	.2743	.1886
12	.1595	.2286	.2103	.1402		.2743	.1734
13	.1928	.2347	.2303	.2103	.1753	.3258	.1907
14	.2103	.2515	.2715	.2279	.1949		.2035
15	.1928		.2229	.1715			.2035
16	.1578		.1966	.1387	.1928	.2401	
17	.1595		.1966	.1595	.2629	.3258	.1865
18	.2149	.1334	.1966		.1578	.2785	.1865
19	.2195	.2667	.213		.3012		.2035
20	.3045	.4001	.2458		.4024	.2286	.3155
21	.3239	.4191	.2622		.4024	.2096	.333
22	.3429	.4191	.2439		.362	.2286	.3155
23	.3048	.3841	.2543		.3475	.2286	.2804
24	.2477	.2858	.3658	.2374	.2353	.3475	.2096
Max	.4001	.4191	.3658	.2572	.4024	.3475	.333
Min	.1341	.1296	.1638	.1387	.1387	.2096	.1543
Avg	.2200	.2581	.2382	.2000	.2382	.2746	.2176

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 201 / 11kv Kamtha Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7783	.8682	.8859	.6348	.6154	.7343	.6089
2	.7602	.8505	.8328	.6348	.6154	.7164	.591
3	.724	.8413	.8238	.6161	.5973	.6805	.5847
4	.6984	.7888	.7522	.6099	.5973	.6805	.567
5	.6626	.7362	.7011	.5792	.5731	.6201	.567
6	.591	.6836	.6661	.5434	.5552	.6024	.4961
7	.4607	.4748	.6135	.4382	.5493	.567	.4908
8	.4961	.5731	.5028		.5493	.5258	.5548
9	.5083	.6447	.5144				
10	.5083	.6024	.6661	.2058			
11	.5784	.7316	.7186	.4733			
12	.0686	.7701	.7712	.4557		.5493	
13	.631	.7522	.0876	.4656		.5316	
14	.7011	.7964	.1052	.5258		.6556	
15	.691	.8326	.6836			.691	
16	.6024			.3155	.5552	.6556	.7122
17	.6447	.4287			.5434	.4862	.6783
18	.591	.5194	.5544		.631	.4694	.2374
19	.6556	.7522	.3326		.6379		.8842
20	.8682	.9492	.7023		.6733	.2103	1.0517
21	.9671	.9816	.5975		.7619	.6556	1.0808
22	.9391	.964	.6908		.7442	.6626	1.0454
23	.9214	.9036	.6722	.6767	.7442	.6447	.9745
24	.7964	.9036	.9036	.6535	.6401	.7343	.6268
Max	.9671	.9816	.9036	.6767	.7619	.7343	1.0808
Min	.0686	.4287	.0876	.2058	.5434	.2103	.2374
Avg	.6602	.7543	.6263	.5219	.6226	.6037	.6913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 202 / 11kv Rawanwadi Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.6263	1.3717	1.2323	1.2012	1.2308	1.1222
2	1.4415	1.5546	1.3535	1.1949	1.1706	1.2308	1.086
3	1.3717	1.4632	1.3535	1.1883	1.1706	1.1765	1.086
4	1.3169	1.3535	1.267	1.1576	1.1523	1.0924	1.0425
5	1.2254	1.262	1.2127	1.0642	1.086	1.0566	.9694
6	1.0608	1.2071	1.086	.8686	1.0317	.9671	.8596
7	.8869	.964	.8869	.7577	.788	.788	.8048
8	.8507	.788	.6687	.7023	.7164	.7421	.8596
9	.8326	.6154	.7545	.6154			.7783
10	.8413	.8869	.8589	.6268			
11	.9231	.985	.964	.6805			
12	.6201	1.0029	.9114	.6984		.8505	
13	1.1041	1.0679	1.0631	.7343		.8682	
14	1.1765	1.0974	1.0277	.4477		.9036	
15	1.1765	.9694	1.0208	.5144		.8954	1.1269
16	1.1041			.567	.7537	.788	1.1096
17	1.0791	.7011			.8059	.8326	.9259
18	1.0059	.9231	.3511		.8413	.8063	1.0288
19	1.2071	1.0242	.7655		1.0059	.7537	1.2309
20	1.6108	1.4083	1.1203		1.2936	1.0517	1.5769
21	1.7013	1.5364	1.2883		1.3032	1.1163	1.6124
22	1.7741	1.5181	1.307		.823	1.1641	1.6297
23	1.6827	1.4815	1.307	1.2382	1.2986	1.1946	1.5043
24	1.5339	1.6632	1.4266	1.2696	1.2197	1.2803	1.1462
Max	1.7741	1.6632	1.4266	1.2696	1.3032	1.2803	1.6297
Min	.6201	.6154	.3511	.4477	.7164	.7421	.7783
Avg	1.2086	1.1782	1.0621	.8643	1.0389	.9900	1.1316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 203 / 11kv Kati Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.4525	.4024	.3734	.3582	.3681	.4031
2	.394	.439	.394	.3734	.3403	.3506	.3898
3	.3761	.439	.3761	.3511	.3366	.3155	.3898
4	.3582	.4207	.362	.3511	.3189	.3121	.3898
5	.3582	.4024	.362	.3077	.3189	.2743	.3898
6	.3403	.3582	.362	.2279	.3012	.2374	.3681
7	.3366	.3086	.362	.2103	.2481	.2012	.3506
8	.2835	.3109	.2204	.1928	.2103	.2713	.3121
9	.3045	.3544	.1174	.2629			
10	.2865	.4075	.1886	.2865			
11	.3982	.4477	.2279	.3045			
12	.4706	.6089	.2804	.3045		.3155	
13	.5068	.5194	.4031	.2835		.3681	
14			.3856	.3189		.3681	
15	.3681		.3856			.3856	
16	.394			.0543	.2149	.4031	.39
17	.3224	.3467			.2686	.3185	.407
18	.1372	.3898	.2772		.3439	.3561	.373
19	.3801	.4344	.3511		.4163	.3052	.4973
20	.4706	.5249	.3511		.3761	.3641	.5721
21	.4755	.5068	.3734		.362	.3681	.4733
22	.5373	.4572	.4481		.3982	.4382	.4557
23	.4656	.439	.4294	.3801	.3801	.4252	.4733
24	.4119	.4525	.3841	.3921	.362	.3801	.3988
Max	.5373	.6089	.4481	.3921	.4163	.4382	.5721
Min	.1372	.3086	.1174	.0543	.2103	.2012	.3121
Avg	.3823	.4295	.3384	.2926	.3267	.3394	.4137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 204 / 11KV Banther

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6697	.6447	.6805	.5847	.6154	.6661	.5792
2	.6154	.6379	.6447	.5658	.5973	.6485	.5792
3	.5792	.6201	.6024	.5658	.5792	.6201	.5611
4	.5611	.6201	.5434	.5601	.5792	.5847	.567
5	.543	.5959	.5258	.5359	.5373	.567	.567
6	.5249	.5784	.4961	.4938	.5194	.5083	.5611
7	.4656	.4458	.4607	.4755	.4835	.4784	.4706
8	.394	.5249	.2012	.4024	.4477	.4334	.4835
9	.4163	.4805	.2713	.3439			.4835
10	.3294	.499	.2743	.3403			
11	.4075	.5121	.3121	.2507			
12	.4755	.5853	.3641	.4075		.2658	
13	.5487	.5121	.4252	.4207		.3721	
14	.5434	.6584	.6201	.4161		.5138	
15	.4908	.439	.6089	.4161		.5138	
16	.5194			.3155	.3856		
17	.4706	.3189			.4031	.3403	
18	.4119	.4477	.3326		.443	.4252	
19	.4733	.5194	.5041		.5316	.4298	
20	.691	.6878	.5228		.6733	.591	
21	.7796	.7522	.6348		.6485	.6697	
22	.7164	.724	.6348	.7133	.6485	.6335	
23	.6805	.6878	.6161	.6584	.6836	.5973	
24	.6767	.6626	.6984	.5975	.6401	.6661	.5792
Max	.7796	.7522	.6984	.7133	.6836	.6697	.5792
Min	.3294	.3189	.2012	.2507	.3856	.2658	.4706
Avg	.5410	.5719	.4988	.4771	.5539	.5262	.5431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314001 / 33/11KV Rawanwadi S/stn.

Feeder No / Name : 205 / 11KV Katangi Industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.132	.1886	.2263	.1886	.1698	.1698
2	.1886	.132	.1698	.2263	.2075	.1509	.1698
3	.1886	.1509	.168	.2263	.1886	.1494	.1698
4	.1698	.168	.168	.2075	.1698	.168	.1698
5	.1509	.2241	.1886	.2075	.2075	.168	.1886
6	.2263	.2614	.1886	.1886	.2075	.1886	.1509
7	.1886	.112	.1886	.1698	.2263	.2075	.1886
8	.1698	.1886	.0934	.132	.2263	.1886	.132
9	.2641	.2452	.0934	.1509			.132
10	.2427	.2263	.2452	.132			
11	.2801	.2452	.2263	.1494			
12	.3174	.2829	.3395	.2241		.2829	
13	.3018	.3395	.3206	.2241		.2641	
14	.3547	.2829	.2263	.112		.3206	.2452
15	.3547	.1509	.2263	.2427		.2641	.1132
16	.3361			.2075	.2829	.1886	.2075
17	.3584	.1307			.2801	.2829	.2075
18	.3174	.2263	.2075		.2614	.2263	.2263
19	.1886	.2641	.1886		.2614	.1886	.1132
20	.2263	.2829	.2263		.1886	.1886	.1132
21	.1886	.2829	.2263		.1509	.1509	.1132
22	.132	.2263	.2075		.1698	.1509	.1132
23	.1509	.1509	.1886	.2075	.2263	.0943	.1886
24	.2263	.1509	.2075	.2075	.2075	.2075	.132
Max	.3584	.3395	.3395	.2427	.2829	.3206	.2452
Min	.132	.112	.0934	.112	.1509	.0943	.1132
Avg	.2388	.2112	.2038	.1912	.2148	.2001	.1622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 201 / Fulchur Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7926	1.8111	1.6078	1.3817	1.4415	1.4377	1.475
2	1.6632	1.8111	1.3491	1.3306	1.4045	1.4003	1.307
3	1.6263	1.6817	1.2567	1.307	1.2936	1.3443	1.3817
4	1.386	1.5893	1.2012	1.2883	1.2012	1.307	1.363
5	1.2567	1.5154	1.2012	1.2136	1.1088	1.2382	1.3443
6	1.2197	1.2752	1.1273	1.1203	1.1088	1.0349	1.1203
7	1.0719	1.0349		1.0082	1.0349	.9709	.9709
8	.8779	1.0349	1.0164	.9709	.9425	.8775	.9149
9	.8871	1.0903	.924	.9709	.8871	.8962	.9335
10	.924	1.1706	1.1273	.8686		1.0269	1.0719
11	1.2752	1.3306	1.3491	1.2136		1.251	1.1827
12	1.423	1.4969	1.3306	1.2012		1.3256	1.3306
13	1.4784	1.7556	1.4784	1.2567		1.4377	1.423
14	1.423	1.6263	1.3491	1.1643		1.363	1.1458
15	1.5524	1.5893	1.4415	1.1458		1.0456	1.6078
16	1.7187	1.6263	1.46	.9979	1.3443	1.4563	
17	1.5524	1.2567		.9979	1.4377	1.3256	1.3491
18	1.4415	1.2567	1.3256	1.0349	1.251	1.1576	1.2567
19	1.4415	1.2752	1.4377		1.3306	1.0082	1.4563
20	1.5339	1.5154	1.2323		1.419	1.0082	1.5708
21	1.5708	1.6263	1.3121		1.4003	1.307	1.4415
22	1.7002	1.6632	1.3817		1.5154	1.3817	1.7002
23	1.8111	1.7187	1.475	1.4415	1.5684	1.4937	1.7556
24	1.8111	1.7741	1.7372	1.4377	1.4784	1.5123	1.4937
Max	1.8111	1.8111	1.7372	1.4415	1.5684	1.5123	1.7556
Min	.8779	1.0349	.924	.8686	.8871	.8775	.9149
Avg	1.4349	1.4802	1.3237	1.1676	1.2871	1.2336	1.3303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 203 / 11kv Adasi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.8048	.8048	.6401	.5853	.6767	.567
2	.7499	.8048	.7865	.6219	.5853	.6767	.5853
3	.695	.8048	.7682	.6219	.5487	.6767	.5853
4	.695	.8048	.695	.5853	.5121	.6401	.567
5	.695	.7499	.695	.567	.4572	.6036	.567
6	.5487	.6219	.5487	.4755	.439	.5304	.4755
7	.5304	.4755		.3658	.3658	.4207	.4024
8	.439	.4938	.4755	.3292	.3292	.4024	.4294
9	.4572	.4755	.4572	.3109	.3292	.4024	.4024
10	.439	.4755	.4755	.3109		.4207	.4572
11	.4938	.5853	.5487	.3292		.3841	.4755
12	.5487	.5853	.5487	.439		.4755	.5304
13	.4938	.6401	.6036	.439		.4938	
14	.5487	.6036	.6838	.4207		.4207	.6219
15	.5304	.567	.6653	.2926		.439	.5853
16	.5853	.5487	.6036	.3109	.4207	.4572	
17	.5487	.5121		.2926	.3841	.4572	.5304
18	.5304	.4207		.2926	.3841	.4207	.4938
19	.6767	.6036	.3841		.5304		.6219
20	.8596	.7865	.5304		.6767	.0732	.823
21	.8962	.823	.6767		.7316		.8779
22	.9145	.8779	.695		.7133	.6401	.8779
23	.8779	.8413	.6584	.6401	.7133	.6036	.8413
24	.8048	.823	.8048	.6584	.6036	.6584	.6036
Max	.9145	.8779	.8048	.6584	.7316	.6767	.8779
Min	.439	.4207	.3841	.2926	.3292	.0732	.4024
Avg	.6379	.6554	.6243	.4472	.5172	.4988	.5873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 204 / 11 KV Bambleshwari

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2263	.3734	.4294	.5228	.4481	.4481
2	.2801	.2829	.3547	.3772	.4854	.4527	.4481
3	.2614	.1867	.3734	.3547	.4668	.4481	.4854
4	.2801	.1307	.3921	.3734	.4481	.4481	.4294
5	.2987	.1307	.3361	.4668	.4668	.4108	.3921
6	.2987	.1494	.2614	.3772	.4481	.415	.4108
7	.2801	.112		.2452	.4294	.4527	.4108
8	.2054	.1509	.1494	.2096	.4481	.2477	.3734
9	.2987	.168	.168	.1886	.3547	.2452	.2614
10	.4854	.4338	.3174	.3206	.1494	.2241	.3361
11	.4481	.4108	.4572	.3206	.1307	.2987	.3734
12	.4668	.5788	.3547	.3734	.168	.3921	.4294
13	.4668	.4481	.2614	.5228		.3547	.4108
14	.3734	.3547	.3395	.5601		.3547	.5228
15	.4207	.2987	.3174	.4481		.3361	.4668
16	.3841	.3174	.415	.4294	.3361	.4481	
17	.4108	.3174		.5788	.4338	.4668	.4854
18	.4481	.5415	.1905	.5847	.3772	.3547	.3395
19	.4481	.5975	.5093		.3772	.168	.3961
20	.4294	.5788	.3584		.3921	.3921	.3547
21	.168	.3361	.3584	.3921	.4338	.5601	.3361
22	.1494	.2987	.4108	.4294	.415	.4854	.4481
23	.2096	.3174	.3921	.5228	.4338	.5415	.5041
24	.2427	.1886	.3547	.4294	.5601	.4527	.4481
Max	.4854	.5975	.5093	.5847	.5601	.5601	.5228
Min	.1494	.112	.1494	.1886	.1307	.168	.2614
Avg	.334	.3148	.3384	.4061	.3942	.3916	.4135

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 205 / 11KV Maheshwari industrial SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.1905	.0762	.2096	.2096	.2286
2	.0762	.0762	.1715	.0762	.2096	.2096	.2096
3	.0762	.0762	.1905	.0762	.2096	.2096	.2096
4	.0572	.0762	.1905	.0762	.1905	.2096	.2096
5	.0572	.1334	.1905	.0762	.2096	.2096	.2096
6	.0572	.0762	.1715	.0762	.1905	.1715	.1905
7	.0572	.0572		.0762	.1905	.1905	.1905
8	.0572	.0754	.1905	.0762	.2096	.1143	.2096
9	.0572	.0762	.1905	.0953	.2096	.1143	.2286
10	.0953	.1143	.2096	.0953	.2286	.2286	.2667
11	.1715	.2286	.2096	.1905	.3048	.3048	.3048
12	.1905	.3239	.0572	.1715	.3048	.381	.3239
13	.1905	.3239	.2096	.1715		.362	.3239
14	.1905	.3239	.2096	.2096		.3429	.3239
15	.1905	.3239	.1905	.2096		.362	.3239
16	.1905	.3239	.1905	.168	.2858	.3239	
17	.1524	.2858		.1905	.3239	.3239	.3239
18	.1334	.2667	.1524	.2096	.2667	.2667	.2477
19	.0953	.2286	.0762		.2096	.2096	.2096
20	.0762	.1905	.0762		.1524	.1905	.2096
21	.0762	.1905	.0762		.1905	.1334	.2286
22	.0762	.1905	.0762		.2286	.0762	.2096
23	.0762	.1905	.0953	.2096	.2096	.2286	.2096
24	.0762	.0762	.1905	.0953	.2096	.2096	.2096
Max	.1905	.3239	.2096	.2096	.3239	.381	.3239
Min	.0572	.0572	.0572	.0762	.1524	.0762	.1905
Avg	.1064	.1794	.1593	.1313	.2259	.2326	.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 206 / Saha Industrial feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.6535	.7095	.7655	.8402	.8962	.743
2	.6722	.6348	.7842	.7095	.7655	.7468	.7811
3	.7655	.6859	.7468	.5975	.7842	.6535	.5335
4	.7095	.7621	.7095	.6535	.8402	.6161	.5335
5	.6348	.7621	.7655	.7282	.7468	.5788	.5335
6	.5975	.7811	.7468	.7655	.7468	.6535	.5335
7	.6348	.4382		.8962	.7655	.6535	.5335
8	.6161	.5788	.5788	.8962	.5601	.6036	.4191
9	.6161	.5906	.3921	.8029	.6908	.6535	.4001
10	.6161	.6161	.5415	.8215	.7167	.8402	.5228
11	.8402	.7842	.9522	1.587	1.0185	1.1812	.6535
12	.8962	.9709	1.1203	1.251	1.3203	1.1949	.8029
13	.9896	.8962	1.3014	1.0456		1.2323	.6908
14	1.0082	.9522	.9522	1.0642		1.0642	.8775
15	.9522	1.0829	1.1389	.9709		1.1883	.8775
16	.9335	.9522	1.0456	1.0269	1.226	1.2637	
17	.9709	.8029		.9896	1.1949	1.0288	.8775
18	.8775	1.0082	.2263	.9709	1.0269	.9145	.7655
19	.9149	.9149	1.0456		1.0456		.6722
20	.8215	.7842	1.0642		.9335	.6287	.6348
21	.8029	.7655	.8589		.8962	.6097	.6348
22	.9149	.7468	1.0269		.9149	.6859	.6722
23	.7842	.7842	.9335	.9335	.8775	.8002	.6722
24	.7468	.6535	.7468	.8402	.9149	.8589	.7621
Max	1.0082	1.0829	1.3014	1.587	1.3203	1.2637	.8775
Min	.5975	.4382	.2263	.5975	.5601	.5788	.4001
Avg	.7927	.7751	.8358	.9158	.8965	.8499	.6577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314006 / 33/11KV Fulchur S/stn.

Feeder No / Name : 207 / Civil Line Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	1.6278	1.5912	1.386	1.2437	1.3676	1.3306
2	1.6095	1.5729	1.4937	1.2936	1.1706	1.2936	1.2567
3	1.4632	1.4998	1.3169	1.2382	1.0608	1.2567	1.2012
4	1.3717	1.4632	1.1888	1.1949	1.0242	1.2136	1.1458
5	1.3169	1.3169	1.134	1.1088	.9145	1.1763	1.1088
6	1.1157	1.1458	1.0608	.961	.8962	.9795	.961
7	.9328	1.0164		.8402	.8596	.8589	.8686
8	.8962	.9328	.8596	.8402	.7865	.8029	.8131
9	.8413	.9145	.8413	.7947	.7865	.8402	.7762
10	.8596	.9145	.8962	.8131	.7392	.8501	
11	.8779	1.0059	.9328	.823	.7762	.8596	
12	.9694	.9877	.8779	.8413	.8316	.8962	.8779
13	1.0974	1.1523	1.0608	.9145		.9694	
14	1.2803	1.3169	1.1523	.9328		1.0059	1.1157
15	1.2437	1.2803	1.1706	.9145		1.0791	1.0974
16	1.2254	1.2254	1.1088	.8048	.8871	1.0903	
17	1.0608	1.0608		.8048	.8686	.9795	1.0059
18	1.0242	.8779		.7762	.823	.8871	.9795
19	1.134	1.0269	1.2936		.8686	.8316	1.0164
20	1.262	1.2254	1.1458		1.0719	.8686	1.2382
21	1.3535	1.4632	1.134		1.1458	.961	1.3491
22	1.5546	1.6095	1.2567		1.2936	1.2012	1.5364
23	1.4632	1.6095	1.423	1.2803	1.3717	1.3491	1.7187
24	1.6827	1.701	1.6278	1.4415	1.2803	1.423	1.3491
Max	1.6827	1.701	1.6278	1.4415	1.3717	1.423	1.7187
Min	.8413	.8779	.8413	.7762	.7392	.8029	.7762
Avg	1.2201	1.2478	1.1698	1.0002	.9857	1.0434	1.1373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 201 / 11KV Dasgaon Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.9335	.8501	.9991	.7762	.8238	.7783
2	.6661	.8962	.7762	.9816	.7392	.8063	.7421
3	.6485	.8962	.7207	.964	.7392	.7362	.7059
4	.631	.8962	.6653	.964	.7577	.7011	.6878
5	.6135	.7842	.5959	.964	.6838	.6661	.6697
6	.5959	.6908	.5609	.7888	.6468	.631	.6516
7	.4207	.5041	.4557	.7011	.5359	.4382	.5068
8	.4733	.5175	.4382	.5258	.462	.4382	.5175
9	.4557	.6653	.4733	.7186	.4435	.4207	.5359
10	.4557	.6653	.6135	.7973	.4066	.4908	.462
11	.5975	.7207	.631	.8131	.4207	.6697	.6335
12	.5415	.8316	.6661	1.0903	.3856	.6878	.7499
13	.7468	.8871	.6836	1.1827	.4733	.6878	.7682
14	.7468	.8871		1.1273	.4557	.6878	.8413
15	.6722	.7207	.6836		.5258	.6154	.8048
16	.6348	.6283	.631		.5784	.5792	.7865
17	.4108	.4066	.7537	.1848	.5784	.5792	.7499
18	.5975	.4066	.7362	.3326	.5959	.5973	.823
19	.6535	.7023	.8238	.3511	.7362	.7783	.8048
20	.9709	.924	.8589	.4805	.8413	.7783	1.0608
21	.9709	.9979	1.1043	.5729	.8589	.7602	1.1706
22	1.0456	1.0164	1.1393	.6653	.8764	.9412	1.134
23	.9522	.961	1.0517	.7762	.8764	.8507	1.0242
24	.7362	.9335	.9055	1.0166	.7762	.8413	.8145
Max	1.0456	1.0164	1.1393	1.1827	.8764	.9412	1.1706
Min	.4108	.4066	.4382	.1848	.3856	.4207	.462
Avg	.6641	.7697	.7312	.7726	.6321	.6753	.7677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 202 / 11KV Dangurli Express Only one consumer of WW with HT-IV
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1526	.3391		.3185	.1848	.3391
2	.1848	.1526	.3391		.3353	.1848	.3391
3	.1848	.1526	.1865		.3353	.1848	.3391
4	.1848	.3391	.2033		.1677	.1848	.1696
5	.1848	.3391	.2033		.1844	.1848	.1696
6	.1848	.1865	.1848		.1677	.1848	.1526
7		.1865					.1526
8							.0339
9		.1526	.1848			.1848	.1696
10	.1848	.1526	.1848		.1677	.1848	.1696
11	.1526	.1526	.1848		.1848	.1696	.1677
12	.1696	.3561	.1848		.1848	.1526	.1677
13	.1526	.3561	.3696		.1848	.1526	
14	.1526	.3391	.3696		.3696	.3391	.1677
15	.1526	.1696			.3696	.3391	.3353
16	.1526	.1696		.1677	.3511	.1526	.3353
17	.1357	.1696		.1677	.1848	.1696	.3353
18	.1526	.1696		.1677		.1526	
19	.1357	.0339		.1677		.0339	
20	.1357	.0339				.0339	
21	.1357	.0339		.1844		.1526	.1677
22	.1357	.1696		.1677	.1848	.1696	.1677
23	.1357	.1696		.1677	.1848	.1696	.1844
24	.1848	.1357	.1865		.1677	.1848	.1696
Max	.1848	.3561	.3696	.1844	.3696	.3391	.3391
Min	.1357	.0339	.1848	.1677	.1677	.0339	.0339
Avg	.1608	.1858	.2401	.1701	.2378	.1750	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 203 / 11kv Birsola

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.6024	.4784	.4075	.4607	.443	.4592
2	.4961	.6024	.4784	.4075	.4252	.4252	.4414
3	.4784	.567	.4607	.3544	.4252	.4252	.4237
4	.4607	.567	.443	.3544	.4252	.4075	.4237
5	.4784	.5493	1.2048	.3366	.4607	.4075	.406
6	.4607	.443	.4252	.3366	.3544	.3898	.406
7	.4252	.443	.3189	.3012	.3544	.3544	.4399
8	.4252	.4607	.333	.2835	.3544	.3883	.406
9	.4252	.5478	.3544	.3012	.3012	.4222	.4237
10	.4414	.5478	.4237	.4045	.3189	.3544	.4252
11	.53	.5478	.4414	.3883	.3544	.4252	.4784
12	.6186	.6009	.4769	.4237	.3544	.4607	.7265
13	.5655	.6718	.4592	.4414	.3898	.4784	.815
14	.5994	.6541	.3706	.5108	.3721	.4961	.8505
15	.5817	.0162	.5316		.3544	.4607	.8328
16	.6171	.4414	.3883	.2805	.3721	.443	.4961
17	.564	.3706	.3883	.3721	.3898	.4607	.4784
18	.4607	.484	.3012	.3366	.3898	.4252	.5138
19	.5316	.4784	.4252	.4075	.4607	.4252	.4961
20	.7087	.5847	.4607	.5138	.4607	.4961	.6024
21	.7087	.567	.4784	.5316	.5316	.4748	.6379
22	.7087	.5316	.4961	.5316	.4784	.4961	.5847
23	.6379	.567	.4607	.4607	.4607	.4607	.5493
24	.5316	.6024	.4961	.4252	.4607	.4784	.4592
Max	.7087	.6718	1.2048	.5316	.5316	.4961	.8505
Min	.4252	.0162	.3012	.2805	.3012	.3544	.406
Avg	.5404	.5187	.4623	.3961	.4046	.4375	.5323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314011 / 33/11KV Dasgaon S/Stn.

Feeder No / Name : 204 / 11KV Dasgaon AGP

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0162
2						.0162
3						.0162
4						.0162
5						.0162
6						.0162
7						.0324
8					.0162	.0162
9		.0162			.0324	.0162
10	.0162	.0162	.0162	.0324		
11	.0162	.0162	.0162	.0162		
12	.0162	.0162	.0162	.0162		
13	.0162	.017	.0162	.0162		
14	.0324	.0162	.0162	.0324		
15	.0324	.0162				
16	.0324	.0162	.0162	.0324		
17	.0324	.0162	.0162			
24						.0162
Max	.0324	.017	.0162	.0324	.0324	.0324
Min	.0162	.0162	.0162	.0162	.0162	.0162
Avg	.0243	.0163	.0162	.0243	.0243	.0178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 201 / Kamtha-Birsi Feeder Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7577	.8402	.7545	.7316	.695	.8063	.6805
2	.7621	.8029	.7377	.743	.6722	.7362	.6878
3	.743	.7577	.6962	.7049	.6838	.724	.695
4	.743	.7316	.663	.6668	.6584	.7059	.6584
5	.6859	.7316	.6226	.6097	.6584	.695	.6335
6	.6287	.7023	.6104	.5716	.6468	.7282	.6268
7	.5914	.6653	.5935	.5906	.6287	.7865	.591
8	.6838	.7655	.5487	.5359	.7095	.4961	.6733
9	.695	.8507	.7122	.6036	.6516	.8059	.8326
10	.7421	.9231	.788	.6767	.7421	.8238	.8413
11	.8413	.9015	.8507	.5906	.7783	.8682	.6878
12	.7316	.9088	.8869	.6099	.7522	.8939	.8596
13	.8589	.9945	.9134	.6838	.8326	.9816	1.0208
14	.9896	.631	.9922	.6161	.8507	.9536	.905
15	.9522	.543	.9465	.5175	.8413	.9709	.9979
16	.8962	.6516		.5359	.8962	.9214	1.0059
17	.823	.695		.499	.8507	.9313	1.0029
18	.7865	.7682	.4763	.5906	.7796	.8962	.8413
19	.8962	.8238	.2858		.929		.9593
20	1.0456	.9991	.6653		.9709	.7362	1.086
21	1.0269	.9774	.8413		.9835	.8059	1.1222
22	1.0082	.961	.7964		.8916	.7455	1.0642
23	.8962	.8478	.8002	.7468	.8669	.7186	1.0082
24	.7655	.8686	.7969	.7811	.7392	.8413	.6984
Max	1.0456	.9991	.9922	.7811	.9835	.9816	1.1222
Min	.5914	.543	.2858	.499	.6287	.4961	.591
Avg	.8146	.8059	.7263	.6303	.7796	.8075	.8408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 202 / 11kv Girola Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.1886	.2667	.2865	.2353	.2096
2	.2858	.2667	.1907	.2477	.2686	.2378	.1715
3	.2477	.2667	.1734	.2477	.2715	.2012	.1524
4	.2096	.2286	.1543	.2286	.2353	.2286	.1524
5	.1905	.2286	.1715	.2286	.2172	.2096	.1334
6	.1905	.2096	.1227	.1715	.1991	.2286	.1143
7	.1334	.1524	.1227	.1334	.1928	.1753	.1334
8	.1524	.1578	.0514	.1524	.1524	.208	.0953
9	.1715	.1928	.1357	.2096	.0381	.1629	.0953
10	.2096	.1753	.1734	.0953	.0381	.2534	.1143
11	.1928	.1865	.1928	.0953	.2103	.2686	.1753
12	.1928	.2204	.2481	.0953	.1928	.2865	.1753
13	.2149	.218	.3077	.1143	.2149	.2865	.1905
14	.2477	.1715	.2715	.1143	.2328	.2587	.2286
15	.2286	.1402	.2507	.156	.2126	.2686	.2286
16	.1949	.1029		.1387	.1753	.2303	.1905
17	.1595	.1433		.1619	.1907	.2103	.1334
18	.1753	.1612	.0572	.1949	.1886	.2303	.1715
19	.2286	.2172	.0953		.2035		.2477
20	.3239	.2715	.2667		.2683	.0381	.362
21	.3429	.298	.2858		.2984	.2477	.4001
22	.3239	.3012	.2858		.3086	.2477	.362
23	.3048	.2374	.2667	.3077	.2804	.2096	.3429
24	.3048	.2858	.2667	.2667	.2896	.2534	.2096
Max	.3429	.3012	.3077	.3077	.3086	.2865	.4001
Min	.1334	.1029	.0514	.0953	.0381	.0381	.0953
Avg	.2305	.2133	.1945	.1813	.2153	.2251	.1996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314017 / 33/11KV Zilmilli S/stn.

Feeder No / Name : 203 / 11kv Sirpur Feeder Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.5121	.4424	.4805	.4251	.4207	.4557
2	.4477	.4755	.4424	.4763	.3841	.4066	.4508
3	.443	.4525	.407	.4572	.3506	.3801	.4557
4	.4607	.439	.407	.4382	.3429	.3921	.4382
5	.4908	.4207	.3772	.4191	.3222	.394	.3944
6	.4908	.3881	.3681	.362	.2949	.3898	.3856
7	.3155	.3658	.2947	.3048	.3258	.3294	.39
8	.2686	.333	.2947	.2865	.2915	.2481	.4239
9		.3721	.3222		.2543	.3294	.4287
10	.1524	.3856	.1629		.2915	.3761	
11	.1581	.4207	.4066	.3641	.2915	.4477	.3932
12	.1772	.4835	.4024	.39	.3294	.4525	.5197
13	.3681	.5434	.4887	.4075	.394	.5316	.5596
14	.4252	.3258	.2587	.3856	.5731	.5258	.5434
15	.443	.362	.3982	.2947	.4382	.4784	.5434
16	.4075	.1372		.2713	.3681	.4527	.5258
17	.3294	.2572		.2743	.3258	.4917	.4915
18	.3561	.2818	.2772	.2572	.3391	.5197	.547
19	.4805	.3812	.3142		.463		.5609
20	.6099	.4915	.4298		.5256	.4239	.6836
21	.5175	.5243	.4961		.5533	.4527	.6661
22	.5729	.4961	.5014		.5197	.4748	.6697
23	.5359	.4752	.4954	.4805	.5087	.463	.6201
24	.4805	.5359	.4534	.4755	.4668	.4458	.4557
Max	.6099	.5434	.5014	.4805	.5731	.5316	.6836
Min	.1524	.1372	.1629	.2572	.2543	.2481	.3856
Avg	.4088	.4108	.3837	.3792	.3908	.4272	.5045

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 201 / I-Green Fibrex Indu.

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17
HR	Load (MW)
13	.1517
Max	.1517
Min	.1517
Avg	.1517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 205 / 11KV Kudwa Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.2136	1.1949	.9709	1.0642	1.251	1.1949
2	1.0829	1.1949	1.0829	.9709	1.0456	.9709	1.1203
3	1.0829	1.1203	1.1203	.9522	.9335	.9709	1.1203
4	1.0082	1.0829	1.0269	.9335	.9335	.9335	.9709
5	1.0082	.9709	.8589	.8962	.8775	.9335	.8962
6	.5601	.7282	.6348	.7468	.7468	.8402	.8215
7	.5601	.6348	.5228	.559	.5415	.6722	.7468
8	.4481	.6161	.5041	.5404	.4481	.5975	.5601
9	.4854	.5788	.5601	.5228	.5041	.5975	.5601
10	.6722	1.5684	.6722	.5788	.5415	.5788	.9335
11		.8402	.9709	.7842	.7655	.8589	1.0269
12	1.0829	.9709	1.0269	.9896	.7655	.8962	
13	1.1016	1.0082	.9896	1.0269	.7095		
14	1.1389	1.1203	.9896	.9149	.7095		
15	1.0082	.9896	.9335	.8589	.6722		
16	.8775	.7655	.7468	.7468	.8029		
17	.8215	.7282	.6535	.7468	.7468		
18	.7095	.5601	.7655	.9335	.7468	.8775	.9335
19	.8029	.7095	.7655	.8402	.6722	.8215	1.0082
20	.9335	.9149	.8402		.9335	.8215	1.1203
21	1.0082	1.0269	.9709		1.0456	1.0082	1.1949
22	1.307	1.1576	1.0269		1.1203	1.1203	1.2323
23	1.251	1.1763	1.0269	1.0829	1.1949	1.1203	1.2323
24	1.2323	1.2136	1.1949	.9896	1.0642	1.251	1.1949
Max	1.307	1.5684	1.1949	1.0829	1.1949	1.251	1.2323
Min	.4481	.5601	.5041	.5228	.4481	.5788	.5601
Avg	.9311	.9538	.8783	.8374	.8161	.9011	.9927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 206 / 11KV Pandharabadi Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0965	1.1393	1.1393	.8459	.9693	1.1043	1.0166
2	1.03	1.1393	1.1218	.8283	.9164	1.0166	1.0166
3	1.03	1.1218	1.1218	.8283	.9516	1.0166	.9465
4	.9968	1.1043	1.0867	.8107	.9516	.9114	.9465
5	.9968	1.0517	1.0867	.793	.8988	.9114	.9114
6	.9968	.9465	.9114	.7225	.8283	.8764	.8764
7	.8971	.7888	.8063	.5816	.7225	.7362	.7011
8	.6645	.7011	.6661	.5287	.6168	.7011	.7712
9	.6335	.7537	.7362	.4743	.5992	.7011	.5258
10	.7502	.8413	.7233	.4582	.5609	.7537	.8063
11		.9465	.7586	.6344	.631		.8413
12	.5835	1.1218	.8283	.7578	.631		
13	.6668	1.0692	.6175	.7754	.7011		
14	.6135	1.0692	.8635	.7402	.7011		
15	.8063	.8413	1.0574	.6521	.6661		
16	.8939	.8413	.9693		.6135		
17	.8764		.2467	.5463	.6661		
18	.8764	.7011	.423	.6521	.8764	.9114	1.1218
19	1.1919	1.1043	.6697	.8107	.964	.9816	1.4723
20	1.3146	1.2795	.8812		1.2269	.9816	1.5775
21	1.3672	1.3146	1.0221		1.1568	1.0517	1.5775
22	1.3496	1.2971	.9164		1.1919	1.0517	1.4373
23	1.2094	1.2269	.8812	1.0221	1.0867	1.0692	1.3496
24	1.0965	1.1744	1.1919	.8459	.9693	1.1043	1.0692
Max	1.3672	1.3146	1.1919	1.0221	1.2269	1.1043	1.5775
Min	.5835	.7011	.2467	.4582	.5609	.7011	.5258
Avg	.9538	1.025	.8636	.7154	.8374	.9341	1.0536

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 314024 / 33/11KV Hiwra S/stn.

Feeder No / Name : 402 / 33 kv Gondia ckt-1

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	21.6856	21.5593	13.8043	14.3336	10.8996	12.0605	11.9502
2	19.9452	22.3389	13.4408	13.7534	10.5825	11.9553	10.8494
3	19.3564	19.6937	12.6017	12.9618	10.255	11.0088	9.9577
4	18.7643	18.2722	12.0256	12.1468	10.0498	10.2726	9.8902
5	17.5904	17.368	11.0814	11.9611	9.5782	9.7451	9.1559
6	15.5172	14.8777	8.93	10.6979	8.6334	9.3227	8.9981
7	13.3493	13.7128	8.6694	9.2221	7.7823	8.4796	7.6904
8	12.1245	13.1762	7.8349	8.6951	7.3782	8.203	7.6378
9	12.2788	12.8143	12.0702	8.235	7.1811	8.2282	7.4931
10	13.3225	13.7494	12.4497	8.4454	6.2049	7.8624	6.8107
11	16.2677	10.1795	14.7313	9.717	7.3617		5.3109
12	19.5513	11.4426	16.5232	10.555	7.6772	1.1831	1.3375
13	18.9496	12.3925	17.4737	11.2351	7.7824	1.3889	
14	19.4914	10.9019	18.2454	9.5371	7.9927	1.3889	
15	20.3389	12.9218	18.7798	7.6584	8.5185	1.4403	
16	20.6641	11.078	17.8018	5.5378	8.7289	1.4403	
17	19.3902	4.3118	8.3608	5.7338	9.6891	1.358	
18	17.6549	5.3315	6.2174	5.4138	9.269	10.6721	5.699
19	18.8008	12.1788	11.9061	9.1998	8.6922	9.936	13.0602
20	20.2373	13.0659	11.7993	1.4918	11.0591	10.7488	13.5883
21	20.1144	13.1642	13.0144	1.6461	11.3752	11.1506	13.8506
22	20.7865	13.6351	13.65	1.6975	12.1137	11.7639	14.3799
23	22.6012	13.6923	14.7565	11.3718	12.3771	12.0302	14.5382
24	22.0096	22.1834	14.0604	14.7885	11.478	12.2714	12.0016
Max	22.6012	22.3389	18.7798	14.7885	12.3771	12.2714	14.5382
Min	12.1245	4.3118	6.2174	1.4918	6.2049	1.1831	1.3375
Avg	18.3663	13.9184	12.9262	9.0015	9.2775	7.9961	9.6947

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 203 / 11 KV Gangazari

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.112	.112	.1109	.0747	.0914	.0754
2	.0895	.1307	.112	.1109	.0747	.0914	.0754
3	.0895	.112	.112	.112	.0747	.0732	.0754
4	.0709	.1097	.112	.1097	.0732	.0724	.0754
5	.0709	.1097	.1109	.0732	.0732	.0724	.0754
6	.0709	.1097	.0924	.0549	.056	.0709	.056
7	.0716	.0732	.0724	.0549	.0549	.0549	.0554
8	.0532	.0914	.0914	.0732	.0549	.0549	.0549
9	.0526	.0732	.0732	.0732	.0366	.0732	.0543
10	.0532	.0914	.0914	.0914		.0549	
11	.0549	.0914	.0732	.0914		.0732	
12	.0724	.0914	.0914	.0724		.1097	.1097
13	.0914	.1097	.0732	.0724		.0914	.0914
14	.0724	.1097	.0914	.0724		.0914	.1097
15	.0732	.1097	.0905	.0549		.0914	.0914
16		.0914	.0732	.0549	.0366	.0549	.0732
17	.0549	.0732	.0914	.0914	.0549	.0732	.0914
18	.0914	.0543	.0549		.0543	.0549	.1097
19	.128	.1097	.1097		.1086	.0914	.128
20	.1646	.1478	.124		.1267	.0914	.1463
21	.1463	.1463	.1075	.1086	.1254	.0914	.128
22	.1463	.128	.1075	.0905	.1075	.0914	.128
23	.128	.1086	.1086	.0724	.0905	.0905	.1097
24	.1097	.1097	.1086	.1109	.0724	.0914	.0732
Max	.1646	.1478	.124	.112	.1267	.1097	.1463
Min	.0526	.0543	.0549	.0549	.0366	.0549	.0543
Avg	.0898	.1039	.0952	.0836	.0750	.0791	.0903

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 204 / 11KV TOWN - V

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	1.2567	1.2826	1.1458	.9979	1.134	.9979
2	1.0903	1.2197	1.1827	1.1458	.9709	1.0974	1.0082
3	1.0534	1.1827	1.1088	1.134	.9425	1.0974	.9335
4	.961	1.1203	1.0829	1.0974	.8962	.9979	.9335
5	.924	.9979	1.0456	.961	.8589	.8962	.8589
6	.7682	.8775	.8215	.6653	.7468	.7207	.7762
7		.7762	.6653	.6468	.6401	.6283	.6283
8	.6468	.6838	.6653	.6468	.6219	.6099	.5914
9	.6584	.7392	.6653	.5914	.6219	.6653	.6468
10	.7499	.8871	.8048	.7023		.7682	
11	.7499	.9694	.8962	.7023		.7499	
12	.8669	.9774	.8779	.7392		.8413	.7499
13	.8507	.9979	.8413	.7545		.7682	.7499
14	1.0924	1.0974	1.0059	.7392		1.0608	.8596
15	1.1888	1.2437	1.1157	.7762		.9877	.8413
16	1.1765	.9979	1.134	.6468	.7316	1.0242	.8596
17	1.0242	.7499	.6219	.6283	.7023	.7316	.8413
18	.8779	.8402	.7865		.6653	.8589	.7316
19	1.0425	.9335	.8316		.8316	.8215	2.3777
20	1.0608	1.0642	.924		.9145	.8402	2.5972
21	1.0608	1.0829	.9979	.8316	.8686	.8402	2.652
22	1.1706	1.2696	1.0534	.924	.9425	.9709	2.8532
23	1.3535	1.3443	1.2012	1.0349	1.0608	1.0719	3.1093
24	1.2071	1.3535	1.2936	1.1706	1.0164	1.0974	1.0719
Max	1.3535	1.3535	1.2936	1.1706	1.0608	1.134	3.1093
Min	.6468	.6838	.6219	.5914	.6219	.6099	.5914
Avg	.9865	1.0276	.9544	.8421	.8350	.8867	1.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3014	1.7353	1.6032	1.6409	1.5466	1.3014	1.6221
2	1.1694	1.6598	1.8107	1.6975	1.3957	1.4335	1.6975
3	1.1694	1.4335	1.8861	1.6975	1.4523	1.3769	1.6598
4	1.1694	1.5466	1.6975	1.6221	1.4146	1.1694	1.5466
5	1.1317	1.4712	1.5844	1.5466	1.2826	1.2637	1.6598
6	1.1128	1.3014	1.4335	1.3392	1.3014	1.3014	1.4335
7	1.094	1.4712	1.3203	1.3014	1.094	1.3957	1.1317
8	1.0185	1.4712	1.2826	1.0562	1.1317	1.3769	1.0562
9		1.5089	1.1694	1.1317	.9054	1.6975	1.094
10	.9242	1.6975	1.5655	1.4289		2.1125	
11	1.773	2.3954	2.1502	1.5623		2.4143	
12	2.037	2.2634	1.9427	1.8673		2.4143	1.3203
13	2.0936	2.3577	1.8673	1.7541		1.905	1.4146
14	1.9616	2.2822	2.0182	1.6975		2.0559	1.4335
15	2.0559	2.1502	2.1125	2.1502		2.3011	1.2449
16	2.0936	1.9805	2.1125	1.905	2.2445	2.0936	
17	2.0559	1.8861	2.3388		2.3954	1.7918	1.4146
18	1.4146	1.773	1.6975	1.4146	1.7541	1.6598	1.358
19	1.4335	1.6975	1.7164		1.7541	1.358	1.4146
20	1.4146	1.5466	1.4523	1.3203	1.1883	1.2637	1.3203
21	1.1317	1.358	1.4901	1.3203	1.4335	1.358	1.2449
22	1.358	1.358	1.4335	1.4146	1.4335	1.4712	1.0751
23	1.3392	1.358	1.3769	1.4712	1.5278	1.358	1.5278
24	1.226	1.5089	1.6975	1.6032	1.4335	1.2637	1.3957
Max	2.0936	2.3954	2.3388	2.1502	2.3954	2.4143	1.6975
Min	.9242	1.3014	1.1694	1.0562	.9054	1.1694	1.0562
Avg	1.4556	1.7172	1.6983	1.5428	1.4827	1.6307	1.3841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 206 / 11KV Water Works

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.2402	.2054	.1829	.1524	.1463	.1478
2	.181	.2241	.1848	.1646	.1524	.1463	.1478
3	.1791	.197	.1848	.1663	.1524	.1463	.1494
4	.181	.1848	.1848	.1448	.1524	.1267	.1494
5	.1595	.1848	.1848	.1267	.1524	.1267	.1307
6	.1417	.1448	.1463	.1097	.1334	.1254	.1294
7	.1254	.1448	.128	.1086	.1086	.0895	.1109
8	.128	.1402	.1086	.1075	.0905	.1075	.1097
9	.1075	.1417	.1097	.1086	.0905	.1254	.1254
10	.12	.1417	.1372	.1063		.1227	
11	.1235	.1844	.1526	.1417		.1417	
12	.12	.1734	.104	.1612		.1772	.0848
13	.156	.1227	.0857	.1433		.1402	.1029
14	.1214	.1907	.0857	.1433		.1402	.0709
15	.1029	.1928	.1387	.1433		.1492	.1772
16	.1696	.156	.1402	.1086	.0678	.1174	.1017
17	.1029	.0701	.1254	.0905	.1357	.1526	.1715
18	.1734	.128	.1254		.1372	.0886	.12
19	.1907	.1646	.1417		.1578	.124	.156
20	.2378	.2195	.1612		.1612	.1612	.1734
21	.2402	.2195	.1629	.1663	.1791	.1646	.1753
22	.2402	.1991	.181	.1698	.1612	.1646	.2012
23	.2218	.1991	.1646	.1509	.1612	.1433	.1886
24	.1991	.2218	.1791	.2012	.1509	.1463	.1463
Max	.2402	.2402	.2054	.2012	.1791	.1772	.2012
Min	.1029	.0701	.0857	.0905	.0678	.0886	.0709
Avg	.1627	.1744	.1468	.1403	.1387	.1364	.1396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 401 / 33 KV RAWANWADI

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	15.8013	16.5444	17.0365		4.7657	5.2412	5.0297
2	15.5807	16.1065	16.2151		4.5942	5.0766	4.92
3	15.0829	15.6687	15.6121		4.5942	5.0212	4.7565
4	14.8634	15.1212	14.7908		4.4856	4.8565	4.7028
5	14.0226	14.6605	14.2987		4.3747	4.6365	4.6331
6	11.6741	12.7006	12.2714		4.1003	4.2501	4.173
7	10.5338	10.4938	1.6289		4.0112	3.7186	3.7471
8	9.5793	10.5481	9.3639		3.3311	3.2922	3.6077
9	9.5467	10.3338	3.9112		3.0625	.5373	2.664
10	24.3798	11.3483	10.5338	2.0285	3.4619	.6984	.6447
11	12.2171	12.76	12.6514	2.1033	3.6214		.7522
12	12.1628	14.5519	12.5371	2.0633	3.5688	.8059	1.6655
13	13.9678	15.1492	14.0089	2.3891	4.2445	.9134	
14	14.6062	15.3921	14.1878	2.5514	3.6535	.7522	.0478
15	15.1738	15.0949	14.7691	2.4577	3.658	4.4056	1.3432
16	15.3121	14.4227	8.7963	3.0447	4.2627	3.6768	
17	14.4433		.2172	.7059	4.2627	4.0684	4.5942
18	12.9229	12.2673	1.6832	2.9373	4.0146	4.1381	4.4502
19	13.3573	13.423	2.5789		4.537	3.0064	5.0503
20	15.2298	15.3669	4.7188		4.964	4.297	6.3957
21	15.7505	15.9145	4.3439	4.1581	5.2949	4.4045	6.6124
22	16.7078	17.2542	3.4208	4.3244	5.068	5.1932	6.5575
23	17.1582	17.3091	3.2579	5.1481	5.5133	5.0823	6.6106
24	16.4089	16.3243	17.256		4.82	5.3503	5.2458
Max	24.3798	17.3091	17.256	5.1481	5.5133	5.3503	6.6124
Min	9.5467	10.3338	.2172	.7059	3.0625	.5373	.0478
Avg	14.4368	14.2937	9.5871	2.8260	4.2610	3.6271	4.0093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 402 / 33 KV GONDIA CKT-I

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.7148	14.7691	14.4433	13.3562	11.7827	12.0662	12.2714
2	13.9003	14.1718	13.9003	12.883	11.4569	11.8536	11.7284
3	13.2705	13.6831	13.466	12.62	11.0768	11.3752	11.4026
4	13.0556	13.1945	12.923	12.3851	10.8053	11.1094	11.1854
5	12.2497	12.5183	12.0542	11.641	10.3167	10.7453	10.6424
6	9.9394	10.6379	9.0364	10.5247	9.2307	9.4559	9.0364
7	9.0261	9.0895	8.7289	8.6237	8.8769	7.9515	8.0979
8	7.5194	***	7.8349	7.7824	7.3886	7.3068	7.6246
9	6.8416	8.6237	7.9401	7.8875	7.3886	7.6012	7.5194
10	8.8769	9.249	8.2556	8.3608	7.7824		
11	1.4883	10.631	10.0995	9.5702	8.7174		
12	12.5675	12.2497	11.0563	10.3121	9.4616		
13	12.9167	13.1093	11.5512	10.9499	9.7245		
14	12.9481	12.3034	12.0885	10.9499	9.9394		
15	13.4317	13.5545	12.6795	8.6237	10.5841	12.1422	
16	13.5928	12.8635	11.8004	5.9945	10.7453	12.0885	
17	12.6509	6.0334	8.5048		10.2624	10.9499	
18	11.4815	9.3101	8.5048	5.8471	12.38	10.0435	3.9169
19	12.4109	12.4383	9.5679		8.9723	10.2058	4.5771
20	13.846	13.5746	11.8736		12.5429	10.8053	12.6258
21	13.7374	13.846	12.8944	10.8596	11.5655	10.8053	12.5183
22	14.2661	14.4433	13.514	11.6741	11.9456	11.6198	12.7332
23	15.2046	15.0406	13.6466	12.2908	12.5972	12.3571	13.4854
24	14.6502	14.936	14.7748	13.9003	12.0542	12.38	12.3571
Max	15.2046	329.3358	14.7748	13.9003	12.5972	12.38	13.4854
Min	1.4883	6.0334	7.8349	5.8471	7.3886	7.3068	3.9169
Avg	11.8578	25.4003	11.2975	10.3351	10.3166	10.6770	10.1076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 403 / 33 KV DHAPEWADA

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4143	2.4434	2.4977	2.4143	3.3722	2.8235	2.9012
2	2.5789	2.4434	2.6063	2.6326	2.5463	2.8235	3.0087
3	2.524	2.3891	2.4977	2.5789	2.2805	2.8532	3.0087
4	2.3594	2.5252	2.2805	2.3102	2.0851	2.5789	3.0087
5	2.2805	2.4714	2.2805	2.3102	2.0851	2.5789	2.6863
6	1.7918	1.7878	1.7353	1.8804	1.701	2.0508	2.3137
7	1.4118	1.4586	1.2574	1.3432	1.2894	1.4506	2.0622
8	1.1831	1.2929	1.0442	1.3717	1.0402	1.4506	1.8187
9	1.3889	1.4083	1.3923	1.3969	.9882	1.7684	2.1879
10	1.6598	1.7295	1.6598	1.3923	1.2346		
11	1.7604	1.5604	1.8004	.9774	1.0682		
12	2.0062	1.9982	2.0285	2.2634	1.5592		3.1727
13	1.8404	2.5486	2.1845	2.2634	2.1605		3.2602
14	1.9136	2.4714	1.6301	2.1874	1.9982		3.5231
15	1.8073	1.4918	2.1325	.5596	2.1091	2.2365	3.3288
16	1.8107	.7362	1.5729	.9448	2.0348	1.8519	
17	1.3226	.9831	1.4746	.6464	1.4243	1.4883	2.8669
18	1.6907	1.17	1.5769		2.0856	1.5061	2.7161
19	2.1559	1.6832	1.9113		2.1605	1.8073	1.1523
20	2.7984	2.384	2.0576	1.8656	2.7641	2.5789	4.1872
21	2.7984	2.4949	2.2325	2.2497	2.8532	2.5789	4.4136
22	2.7984	2.6337	2.2325	2.1176	2.7149	3.1493	3.9609
23	2.552	2.524	2.3102	3.2579	2.5252	3.0087	3.9609
24	2.2565	2.4714	2.4977	2.364	3.1687	2.5252	2.955
Max	2.7984	2.6337	2.6063	3.2579	3.3722	3.1493	4.4136
Min	1.1831	.7362	1.0442	.5596	.9882	1.4506	1.1523
Avg	2.046	1.9625	1.9539	1.8785	2.0520	2.2689	2.9759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 404 / 33 KV GONDIA CKT-II

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.0961	10.5898	6.0357	5.487	3.9506	5.5418	5.048
2	10.096	10.6447	5.9259	5.4321	3.8255	5.6516	5.048
3	9.9315	10.3155	5.8162	5.2126	5.1029	5.7065	4.9383
4	9.4924	10.0412	5.7065	5.1578	4.9931	5.5967	4.8285
5	8.9403	10.0366	5.5967	5.104	4.7737	5.487	4.8285
6	6.7335	8.5139	4.0832	4.3982	4.1701		3.9758
7	6.2117	7.2257	3.5757	3.3122	4.0181	3.4551	3.3653
8	5.535	6.9136	3.2247	2.3891	3.2425	3.3311	3.3288
9	5.7516	6.534	5.567	2.524	3.083	3.155	3.4705
10	6.5638	6.957	6.3546	3.155	3.1893	3.3653	
11	6.7335	4.3056	7.1056	3.0298	3.1361	3.9866	
12	5.8059	4.6742	7.6629	3.8803	3.6145	3.9866	3.7969
13	7.5926	4.9966	8.4728	4.6245	3.7071	4.2524	6.8884
14	7.7492	5.1578	8.7958	4.2524	3.5997	3.9758	11.4283
15	8.0201	3.4922	7.9864	2.6046	3.7071	4.0832	10.4767
16	7.9167	4.4696	7.5606	2.6292	3.5757	4.0398	
17	7.1623	2.8607	2.7343	2.4714	3.5757	3.9438	10.8436
18	6.6918	3.155	3.2602		3.4705	2.6818	10.2058
19	6.0031	4.561	3.1161		4.213	1.5043	11.6741
20	9.7171	5.7105	3.3848		5.2675	4.5462	5.5996
21	10.2675	6.0431	4.3118	4.9897	4.9931	4.5462	5.9808
22	10.9191	6.286	5.156	5.2115	5.3772	5.1029	6.0905
23	11.1934	6.1454	5.3727	5.3224	5.5967	5.2675	6.1454
24	9.9223	10.9088	6.0905	5.487	5.2126	5.4321	5.3224
Max	11.1934	10.9088	8.7958	5.487	5.5967	5.7065	11.6741
Min	5.535	2.8607	2.7343	2.3891	3.083	1.5043	3.3288
Avg	8.1269	6.6891	5.5374	4.1274	4.1415	4.2887	6.3469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 405 / 33 KV GOREGAON

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.1797	6.4998	6.606	15.6533	3.2819	15.9306	15.2864
2	5.9539	6.4495	6.322	15.7756	3.1121	16.0432	15.1201
3	5.8414	6.2781	5.8671	15.3264	2.999	15.2126	14.5136
4	5.643	5.895	5.6973	14.9326	2.8858	14.3845	13.4094
5	5.4052	5.9037	5.4132	14.6931	2.8858	14.2661	13.4117
6	4.6268	5.1487	4.4702	12.9252	2.8292	12.3457	11.1671
7	4.1833	4.3759	2.6578	11.2529	13.203	10.695	10.3166
8	3.8832	3.1161	3.5625	10.6396	11.13	9.7497	9.3393
9	3.9129	4.0478	3.8031	9.86	8.1664	9.8217	9.5844
10	4.3381	4.2884	4.1633	10.6504	8.2739	2.2177	1.7541
11	5.0789	5.2578	4.7948	12.2771	8.7037	2.6057	2.2068
12	5.8779	5.8425	5.1298	13.4266	9.0261	2.8829	2.4331
13	6.2637	5.8968	4.8674	13.6437	12.0531	3.1602	11.5009
14	6.106	6.2249	4.489	11.9062	12.1022	3.3265	13.6322
15	6.1374	5.8602	5.3858	11.7387	12.8727	14.1849	13.5631
16	6.1008	5.6653	4.828	10.7807	12.7595	14.6725	
17	5.5402	3.1379	.2172	11.0871	12.8675	13.7483	13.2522
18	5.2727	5.3092	7.9076	2.9424	12.5943	12.2417	12.0645
19	6.0551	5.6636	11.9291	2.999	13.8867	8.8706	13.4706
20	6.6873	6.3941	12.8847	2.8858	14.6971	11.0094	15.6001
21	6.4643	6.1677	14.0609	15.0864	14.8092	11.1757	16.0528
22	6.7335	6.5523	15.1212	15.6453	15.5344	13.8049	15.7339
23	7.1863	6.5507	16.0786	16.286	16.0202	14.844	17.2588
24	5.9676	6.6759	6.7764	15.8059	15.6842	15.9865	15.1675
Max	7.1863	6.6759	16.0786	16.286	16.0202	16.0432	17.2588
Min	3.8832	3.1161	.2172	2.8858	2.8292	2.2177	1.7541
Avg	5.6433	5.5501	6.7930	12.0092	10.0991	10.9659	11.9930

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA (R) S/DN.[390] BU 0390

Substation No/ Name :- 317014 / 132 KV GONDIA

Feeder No / Name : 406 / 33 KV GAYATRI AIPL

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.369	4.3347	4.369	4.537	4.3896	4.369	4.3347
2	4.481	4.5462	4.0329	4.6491	4.3799	3.9209	4.4353
3	4.537	4.3244	3.9918	4.537	4.537	4.768	4.225
4	4.481	4.4993	4.4353	4.7051	4.3347	4.7125	4.5268
5	4.3244	4.3244	4.6571	4.9343	4.3244	4.7737	4.313
6	4.4907	4.5542	4.313	4.7125	4.4353	4.369	4.3347
7	4.269	4.4445	3.0493	3.8958	4.2135	4.3244	3.8409
8	4.2798	4.269	4.181	4.3799	4.2798	4.4353	4.225
9	4.1581	4.3347	4.3347	4.3244	4.2798	4.4907	4.3244
10	4.3799	4.4993	4.269	4.1581	4.1701		
11	4.269	4.561	4.5542	4.5462	4.257		
12	4.5462	4.4445	4.5542	4.1581	4.269		4.4907
13	4.5462	4.4525	4.4993	4.3244	4.3896		4.4993
14	4.3799	4.4056	4.4993	4.3347	4.0472		4.3347
15	4.4907	4.181	4.6571	4.6091	4.4445	4.4907	4.269
16	4.1907	4.225	4.5462	3.9506	4.3799	4.225	
17	4.3244	4.225		4.0472	3.9918	4.481	4.3896
18	4.5725	4.181	4.425		4.6016	4.257	4.3799
19	4.3347	4.3439	3.9769		4.6016	2.9081	4.2798
20	4.5462	4.3347	3.9769		4.5462	4.3896	4.3244
21	4.5542	4.4525	4.425	4.3896	4.481	4.3896	4.4907
22	4.6091	4.6153	4.369	4.4907	4.481	4.4993	4.4353
23	4.4907	4.481	4.481	4.225	4.425	4.4445	4.3347
24	4.4907	4.6153	4.269	4.4353	4.4907	4.481	4.3799
Max	4.6091	4.6153	4.6571	4.9343	4.6016	4.7737	4.5268
Min	4.1581	4.181	3.0493	3.8958	3.9918	2.9081	3.8409
Avg	4.4215	4.4020	4.2985	4.3973	4.3646	4.3542	4.3413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 201 / Town - I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	2.7166	2.809	
2	2.7905	2.7073	
3	2.6057	2.5873	
4	2.4764	2.3529	
5	2.2546	2.2862	
6	2.0513	2.009	
7	1.922	1.9387	
8	1.7187	1.8839	
9	1.7741	1.957	1.7558
10	2.1992	2.1807	1.9404
11	2.1437		2.5972
12	3.77		3.1047
13	3.77		3.308
14	3.7515		3.2895
15	3.8462		3.4189
16	3.9022		3.4558
17	3.7342		
18	3.4374		
19	3.7146		
20	3.6591		
21	3.2861		
22	2.846		
23	3.0308		
24	2.733	2.9569	
Max	3.9022	2.9569	3.4558
Min	1.7187	1.8839	1.7558
Avg	2.9222	2.3335	2.8588

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 202 / Town - II
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	4.0657	3.9918	
2	3.8624	3.6961	
3	3.6961	3.5848	
4	3.4558	3.3653	
5	3.2156	3.2487	
6	2.7721	2.809	
7	2.5318	2.4615	
8	2.2546	2.2624	
9	2.0814	2.2262	2.1216
10	2.19	2.3167	2.1582
11	2.1719		2.4326
12	3.3846		2.6337
13	3.0769		2.8166
14	3.0045		2.8349
15	3.1824		2.963
16	3.4019		3.0727
17	3.1786		
18	2.7984		
19	2.8532		
20	3.1047		
21	3.1971		
22	3.4743		
23	4.1211		
24	4.0905	4.1766	
Max	4.1211	4.1766	3.0727
Min	2.0814	2.2262	2.1216
Avg	3.1319	3.1036	2.6292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 203 / Town - III
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5912	1.6632	
2	1.5729	1.6095	
3	1.5181	1.5524	
4	1.4083	1.4784	
5	1.2803	1.3756	
6	1.134	1.2437	
7	1.0608	1.1041	
8	.9694	1.0136	
9	.9145	1.0136	.8596
10	.9511	.9774	.9313
11	.8869		.8954
12	.8326		.9492
13	1.0317		1.0566
14	1.0498		1.1104
15	1.1222		1.1462
16	1.1222		1.1999
17	1.0029		
18	.9671		
19	1.1403		
20	1.3169		
21	1.4083		
22	1.5364		
23	1.6827		
24	1.6827	1.701	
Max	1.6827	1.701	1.1999
Min	.8326	.9774	.8596
Avg	1.2160	1.3393	1.0186

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314012 / 33 KV SURYATOLA S/STN

Feeder No / Name : 204 / Town - IV
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.724	.8131	
2	.6516	.7392	
3	.6516	.6584	
4	.5792	.5487	
5	.5068	.4755	
6	.4344	.4805	
7	.4344	.4024	
8	.362	.4024	
9	.362	.3658	.3658
10	.362	.4344	.3658
11	.5068		.4024
12	.5068		.4755
13	.5068		.5121
14	.6154		.5853
15	.6516		.5914
16	.6516		.5853
17	.5853		
18	.5487		
19	.5487		
20	.6219		
21	.6653		
22	.7602		
23	.8779		
24	.7682	.8048	
Max	.8779	.8131	.5914
Min	.362	.3658	.3658
Avg	.5785	.5568	.4855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 202 / Urban industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2629	.3921	.4668	.2614	.362	.2829
2	.2427	.2454	.3174	.4481	.2427	.3475	.3206
3	.2241	.1928	.1867	.4481	.2427	.3292	.3018
4	.1867	.1753	.1494	.4294	.2054	.2926	.2452
5	.168	.1578	.1307	.3921	.2241	.3475	.2075
6	.112	.1227	.0934	.3361	.2241	.3761	.2075
7	.0934	.1052		.3921	.7468	.362	.1886
8	.056	.0351	.0747	.2241	.1494	.3292	.0754
9	.0747	.0526	.0747	.168	.1494	.1848	.056
10	.0934	.1867	.2987	.1494		.1509	.0373
11	.2801	.4251	.3921	.3174		.2263	.0934
12	.4481	.4251	.4668	.3921		.2829	.4108
13	.5228	.4805	.5228	.3734	.4481	.4527	.3921
14	.5975	.5175	.4668	.3734	.5228	.547	.3734
15	.6348	.6283	.4108	.3921	.5601	.5281	.2614
16	.6535	.6653	.3734	.3921	.4108	.4904	
17	.5601			.5228	.4481	.5093	.1867
18	.4294	.6348	.3921	.5601	.4668	.2452	.1867
19	.168	.2241	.5041	.4668	.2241	.2263	.1307
20	.112	.2241	.3547	.3921	.1698	.2263	.0747
21	.0747	.1867	.3921	.3734	.2263	.2263	.0373
22	.1494	.168	.3921	.3547	.3584	.2263	.0373
23	.3361	.2054	.3547	.2801	.3584	.2263	.0747
24	.2801	.298	.4668	.3921	.2614	.3582	.2263
Max	.6535	.6653	.5228	.5601	.7468	.547	.4108
Min	.056	.0351	.0747	.1494	.1494	.1509	.0373
Avg	.2816	.2878	.3276	.3765	.3286	.3272	.1917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314025 / 33/11 kv Parwatigath

Feeder No / Name : 203 / Manohar Chowk

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9593	1.0082	2.3899	2.1098	2.3101	2.3777
2	.9522	.905	1.0082	2.2592	1.9605	2.2177	2.3411
3	.8775	.8688	.9335	2.2032	1.8671	2.1472	2.1765
4	.8402	.7421	.8589	2.1098	1.8111	1.9231	2.0668
5	.7655	.7964	.7468	2.0165	1.7737	2.0725	1.9753
6	.6535	.6516	.6535	1.7177	1.6804	1.7177	1.5729
7	.5788	.5973		1.5497	1.7737	1.6804	1.4632
8	.5415	.5611	.4668	1.4003	1.4937	1.643	1.3535
9	.5601	.543	.4854	1.363	1.4937	1.4937	1.4377
10	.5601	.543	.5041	1.3443		1.3817	1.307
11	.5975	.6283	.5415	1.6057		1.587	1.5497
12	.6348	.7207	.5975	1.7177		1.6804	1.5497
13	.6908	.7577	.6535	1.6804	1.4937	1.7177	1.6244
14	.7655	.7947	.7095	1.6991	1.5497	1.7551	1.7551
15	.7468	.7947	.7282	1.6057	1.5844	1.7737	1.643
16	.7468	.7762	.7282	1.4377	1.5339	1.7737	
17	.7095			1.419	1.5524	1.7551	1.7924
18	.6161	.5601	1.587	1.363	1.587	1.5023	1.6617
19	.7095	.6161	1.9044	1.6804	1.7551	1.5746	1.7924
20	.7468	.7282	1.8671	1.7364	1.8673	1.7737	2.1285
21	.7842	.7655	1.9231	1.9605	1.905	1.8642	2.2405
22	.9149	.9335	2.1845	2.0725	2.037	1.9366	2.3899
23	1.0269	.9896	2.4832	2.1285	2.2634	2.009	2.6699
24	1.0269	.9955	1.0269	2.5206	2.1472	2.2218	2.1765
Max	1.0269	.9955	2.4832	2.5206	2.2634	2.3101	2.6699
Min	.5415	.543	.4668	1.3443	1.4937	1.3817	1.307
Avg	.7523	.7491	1.0727	1.7909	1.7733	1.813	1.8715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 201 / Chotta Gondia Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1132	.1886	.132	.0566	.0754	.1132
2	.132	.0943	.1698	.1132	.0566	.0754	.1132
3	.0943	.0943	.1509	.1132	.0377	.0754	.0943
4	.0943	.0943	.1509	.1132	.0377	.0566	.0943
5	.0943	.0943	.132	.0943	.0566	.0377	.0754
6	.0754	.0754	.1132	.0754	.0377	.0377	.0754
7	.0566	.0566	.1132	.0566	.0377	.0377	.0754
8	.0566	.0566	.0943	.0566	.0377	.0377	.0566
9	.0377	.0566	.0754	.0566	.0377	.0377	.0566
10	.0377	.0377	.0377	.0566	.0377	.0377	.0377
11	.0754	.0377	.0377	.0566	.0377		.0566
12	.0943	.0754	.0377		.0943	.0754	.0754
13	.1132	.1132	.0377		.0943	.1132	
14	.1132	.0754	.0566		.0754	.1132	
15	.1132	.1132	.0566	.0377	.0754	.0754	
16	.1132	.1132		.0566	.0943	.0943	
17	.0754			.0566	.0943	.132	.0943
18	.0943	.0943			.1132	.132	.0943
19	.1132	.0566	.0377		.0943	.0943	.0754
20	.0943	.0754	.0754		.1132	.132	.1132
21	.0754	.0754	.0754		.1132	.1132	.132
22	.1132	.1509	.0754		.0943	.1132	.1132
23	.1132	.1698	.132	.0566	.0943	.1509	.1509
24	.1509	.1132	.1886	.132	.0566	.0943	.132
Max	.1509	.1698	.1886	.132	.1132	.1509	.1509
Min	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0943	.0886	.0970	.0790	.0699	.0845	.0915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 202 / Govindpur
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6095	1.5203	1.5927
2	1.5546	1.4842	1.5203
3	1.5384	1.448	1.4661
4	1.448	1.4118	1.3575
5	1.3575	1.3756	1.2489
6	1.1946	1.2489	1.1403
7	.9412	1.0136	.9774
8	.905	1.0498	.7783
9	.8688	.9955	.8869
10	.9412	.9955	.905
11	.9774	1.0136	1.0317
12	1.1765	1.267	1.0136
13	1.2489	1.3213	1.1946
14	1.3032	1.448	1.4299
15	1.3394	1.4661	1.3575
16	1.3575	1.3032	1.1584
17	1.2308		
18	1.0498	.9955	
19	1.1946	1.1222	
20	1.3575	1.2489	
21	1.3756	1.3213	
22	1.5023	1.5203	
23	1.6108	1.5927	
24	1.6644	1.5746	1.5927
Max	1.6644	1.5927	1.5927
Min	.8688	.9955	.7783
Avg	1.2811	1.2930	1.2148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314028 / Civiline (Bhimghat)

Feeder No / Name : 203 / Vijaynagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8779	.8779	.1097	.7316	.7499	.7682
2	.8962	.823	.823	.0914	.6767	.7133	.7499
3	.8596	.7499	.823	.0914	.6767	.695	.7316
4	.8596	.6767	.7682	.0732	.6401	.6767	.695
5	.8596	.6767	.7316	.0732	.6401	.6219	.695
6	.7682	.6401	.6767	.0549	.6767	.5853	.6767
7	.6401	.567	.567	.0549	.6036	.567	.567
8	.567	.5853	.6036	.0362	.4938	.5304	.5853
9	.6036	.6767	.5304	.0366	.5304	.5487	.567
10	.7682	.7316	.6401	.0366	.6401	.6584	.6219
11	.8962	.8048	.7682	.0366	.6401		.7316
12	1.0425	.823	.7316		.6401	.7682	.7499
13	.9511	.823	.7865		.8596	.823	
14	.8962	.9511	.7682		.8413	.6401	
15	.9328	.9511	.7865	.5853	.823	.7499	
16	.9877	.8962		.6401	.8962	.8048	
17	.9145			.6767	.8962	.7865	.8413
18	.7865	.6036			.7682	.823	.823
19	.7133	.7133			.6219	.4572	.7865
20	.8413	.8596			.7133	.7133	.9694
21	.9694	1.0974	.0732		.7865	.8962	1.0425
22	1.0059	1.1888			.9694	.823	1.1157
23	1.0608	1.0974	.1097	.9328	.9145	.8596	1.1706
24	.9328	.8779	.9145	.1097	.7682	.7865	.823
Max	1.0608	1.1888	.9145	.9328	.9694	.8962	1.1706
Min	.567	.567	.0732	.0362	.4938	.4572	.567
Avg	.8604	.8127	.6656	.2275	.7270	.7077	.7856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314029 / Katangtola

Feeder No / Name : 201 / 11 KV GAJANAN COLONY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2403	1.1694	1.0029	1.0745	1.0029	.9745	.9945
2	1.2403	1.0277	.9492	1.0745	.9134	.9745	.9088
3	1.2403	1.1517	.9492	1.0208	.8596	.9745	.8402
4	1.0631	.9036	.9134	.8954	.7522	.9745	.7888
5	.8859	.7796	.9134	.8596	.7522	.8859	.7716
6	.8328	.7265	.8775	.8059	.6984	.788	.7545
7	.7087	.691	.7701	.7164	.6626	.7087	.6516
8	.6556	.7087	.6626	.6447	.6626	.6379	.6173
9	.6379	.691	.6805	.6447	.6089	.6447	.6173
10	.6556	.7442	.6984	.6805		.5194	.6516
11	.7087	.8059	.7164	.6984			
12	1.0277	.8954	.7343	.7164			.7202
13	.9214		.8596	.788		.7522	
14	.9745		.9313	.6984		.788	
15	1.0099	1.0208	.9313			.8417	
16	1.0099	.9671	.9313	.6805		.8059	
17	.8859		.6984		.7186	.8059	
18	.8505	.7619	.7164		.7888	.6687	1.0692
19	.8328	.8505	.7522		.8238	.6687	1.0692
20	.9568	.9568	.8238		.8238	.7545	1.0692
21	1.0631	1.0808	.8596	.9671	.8413	.8059	1.1393
22	1.2757	1.0808	1.0029	.985	.964	.9259	1.2445
23	1.2757	1.0277	1.1462	1.0566	1.0277	1.046	1.3146
24	1.258	1.2048	1.0387	1.1462	1.0387	1.0099	1.0288
Max	1.2757	1.2048	1.1462	1.1462	1.0387	1.046	1.3146
Min	.6379	.691	.6626	.6447	.6089	.5194	.6173
Avg	.9671	.9165	.8567	.8502	.8200	.8162	.9028

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GONDIA URBAN S/DN[387] BU 1937

Substation No/ Name :- 314029 / Katangtola

Feeder No / Name : 203 / 11KV Angurbagicha
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.985	.985	.8238	1.8267	.7522	.8059	.788
2	.9313	.9313	.788	1.6834	.7343	.8059	.7343
3	.8954	.8775	.7343	1.4685	.7343	.788	.6984
4	.8954	.788	.6984	1.4327	.6984	.8059	.6984
5	.8059	.7522	.6447	1.4327	.6447	.7164	.6626
6	.7164	.6984	.591	1.3969	.6447	.6447	.6447
7	.6268	.6626	.6447	1.1462	.5731	.591	.5373
8	.6268	.6626	.5731	1.1462	.5014	.5373	.5552
9	.5552	.6089	.5731	1.0924	.4835	.5373	.5731
10	.5373	.6089	.5373	1.0745			.5194
11	.5194	.6268	.5373	1.2894			
12	.7164	.7522	.6089	1.3611		.5731	.6268
13	.7164	.7522	.6984	1.3969		.6984	
14	.7522	.788	.7343	.8417		.6626	
15	.788	.788	.7522	.5731		.6626	
16	.7522	.7164	.7343	.4298		.6805	
17	.7343		.4298		.5373	.6268	
18	.7164		.4835		.5373	.5731	.8238
19	.7164	.8417	1.3432		.6805	.5552	.8059
20	.8596	.9313	1.1283		.7164	.6447	.9671
21	.9671	.9671	1.6297	.7343	.7522	.7164	.8238
22	1.0387	.985	1.8804	.788	.8238	.8059	1.0387
23	1.0745	.9671	1.9521	.788	.8596	.8238	1.0387
24	1.0387	1.0387	.9492	1.9163	.7522	.8238	.8238
Max	1.0745	1.0387	1.9521	1.9163	.8596	.8238	1.0387
Min	.5194	.6089	.4298	.4298	.4835	.5373	.5194
Avg	.7902	.8059	.8529	1.1909	.6721	.6854	.7422

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 201 / 11 KV GOREGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.8145	.8596	.7207	.6036	.7095	.6653
2	.7762	.7682	.8596	.7133	.5792	.695	.6468
3	.7392	.724	.8413	.7023	.567	.6584	.6468
4	.7392	.695	.8413	.6584	.5487	.6401	.6099
5	.7023	.6516	.7865	.6219	.5175	.5487	.5544
6	.543	.567	.5601	.4755	.4805	.4755	.4938
7	.4784	.5068	.4668	.4163	.4207	.4477	.4344
8	.4287	.4755	.4481	.4163	.3841	.4075	.4163
9	.4557	.5121	.4294	.4075	.362	.4252	.4163
10	.4961	.5373	.4784	.4607	.3801	.4607	.4755
11	.5792	.6268	.5493	.5068		.5068	.5304
12	.6516	.6805	.567	.5304	.4961	.543	.5611
13	.7499	.7164		.5249		.5973	.5792
14	.7421	.7964	.5731	.5853		.5611	.5552
15	.7602	.7602	.5973	.5249		.5731	.6516
16	.7316	.6697	.567		.543	.5611	.5792
17	.6516	.5973			.5121	.5249	.6154
18	.5731	.543			.4835	.4961	.6219
19	.7602	.6335	.567		.5853	.5359	.6268
20	.7362	.724	.7023		.6161	.5228	.7499
21	.7796	.8688	.6838		.6722	.5975	.8048
22	.823	.8507	.7392		.6908	.6584	.8145
23	.8596	.8507	.7421	.6516	.7023	.6838	.8413
24	.7865	.8413	.8507	.7392	.6584	.7023	.6908
Max	.8596	.8688	.8596	.7392	.7023	.7095	.8413
Min	.4287	.4755	.4294	.4075	.362	.4075	.4163
Avg	.6804	.6838	.6529	.568	.5402	.5639	.6076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 202 / 11 KV Mundipar

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0498	1.134	1.0802	.8686	.6859	.9036	.7602
2	1.0208	1.0867	1.0288	.8686	.6516	.8859	.7602
3	1.0029	1.0402	1.0288	.8316	.6241	.8859	.7783
4	.985	.9536	.9945	.8048	.6068	.815	.788
5	.9134	.8573	.8573	.8048	.5609	.7087	.7164
6	.7011	.7888	.7716	.6154	.5144	.6201	.5552
7	.6379	.6859	.7373	.5249	.5316	.567	.5847
8	.5316	.5847	.6859	.5138	.463	.567	.6201
9	.5868	.6859	.6859	.4961	.4801	.5847	.631
10	.663	.8505	.7373	.5375	.5144	.6135	.6024
11	.6203	.8764	.4854	.5847	.5028	.6173	.6485
12	.703	.8573	.5784	.631	.5316	.703	.7373
13	.7545	.8916	.6762	.6201		.7202	.7716
14	.7545	.9088	.5847	.6516		.6485	.823
15	.7716	.8573	.9568	.5658		.691	.7888
16	.763	.8059	.6135		.6173	.6379	.7108
17	.7888	.8059			.6068	.631	.7712
18	.9465	.7373			.6068	.6556	.8573
19	1.258	.9774	.1307		.8775	.6584	.9602
20	1.2986	1.1488	.2926		.9568	.7095	1.2003
21	1.3394	1.1317	.5487		1.0099	.8029	1.2346
22	1.2403	1.1317	.9145		.9745	.8145	1.1317
23	1.2254	1.1145	.8869	.703	.9214	.7865	1.0974
24	1.086	1.1765	1.0802	.8779	.7202	.9036	.7682
Max	1.3394	1.1765	1.0802	.8779	1.0099	.9036	1.2346
Min	.5316	.5847	.1307	.4961	.463	.567	.5552
Avg	.9018	.9204	.7435	.6765	.6647	.7138	.8041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 203 / 11 KV Industrial Milltoli SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8402	.547	.4763	.5853	.7682	.8215
2	.6097	.7842	.5281	.5335	.5973	.7682	.8488
3	.5716	.7655	.5281	.5716	.6401	.7316	.7356
4	.6413	.7468	.4904	.5144	.695	.7316	.6535
5	.6908	.7468	.4904	.5335	.7207	.7095	.6908
6	.7468	.7468	.4527	.5525	.7316	.6535	.7545
7	.8029	.695	.5281	.5906	.695	.6161	.8131
8	.7655	.6379	.4715	.4954	.7316	.5228	.6722
9	.7947	.7316	.415	.381	.724	.5415	.6468
10	.8962	.7023	.7095	.5975	.7059	.6287	.7023
11	1.1016	.7392	.8686	.9328	1.0242	.8402	1.3032
12	1.1157	.7842	.9709	1.086		1.0829	1.1403
13	.905	.8488	.8871	.9694		.961	1.0498
14	.9328	.9242	.924	.1294		.7762	.9774
15	.8779	1.0269	.7133	.9709		.9145	.8417
16	.8688	1.1203	.7095		1.0059	1.0082	.8688
17	.7499	.9709			1.1946	.8962	.8413
18	.823	.9431			.9877	.9149	.823
19	1.0059	1.094	.2667		.9877	.6097	.7602
20	1.0059	.8299	.5144		.961	.5335	.8316
21	.8507	.7545	.6478		.7023	.7621	.6036
22	.9145	.679	.6287		.7023	.8954	.6161
23	.9335	.5658	.5716	.6401	.7682	.7621	.7577
24	.743	.8413	.547	.2858	.543	.7682	.7842
Max	1.1157	1.1203	.9709	1.086	1.1946	1.0829	1.3032
Min	.5716	.5658	.2667	.1294	.543	.5228	.6036
Avg	.8347	.8133	.6096	.6036	.7852	.7665	.8141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 205 / 11KV Hirdamali

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.905		.7865	.695	.7783	.7682
2	.8779	.8779		.7682	.6584	.7783	.7392
3	.8871	.8145		.7499	.6697	.7602	.7468
4	.8507	.8048		.7133	.6584	.7316	.7468
5	.8145	.7682		.6516	.6767	.7023	.7095
6	.6379	.7316		.5731	.6154	.6535	
7	.567	.5973		.4784	.4938	.5975	.1867
8	.5028	.567		.443	.4344	.4854	.1463
9	.5144	.5068		.443		.5041	.5731
10	.5548	.5487	.4938		.4207	.4572	
11	.543	.6516	.5249	.4706	.4163	.5249	.5552
12	.631	.7059	.5552	.5373		.543	.5014
13	.6733	.724	.6379	.543		.5731	.5731
14	.6805	.724	.6661	.4938		.5611	.6154
15	.6878	.5792	.6135	.4344		.5373	.5611
16	.6767	.5611	.5721		.4887	.5249	.591
17	.5973	.5228			.4477	.4207	.5731
18	.6878	.5068	.567		.4344	.5194	.7682
19	.9694	.7059	.6838		.6722	.4572	.7865
20	.9694	.7602	.7842		.8029	.6653	.9593
21	.9955	.8688	.8402		.8775	.7655	.985
22	.8916	.9774	.8316		.8402	.8048	.9877
23	.929	.905	.8501	.7421	.8029	.7762	.9412
24	.9425	.8764		.7865	.7316	.7783	.7842
Max	.9955	.9774	.8501	.7865	.8775	.8048	.9877
Min	.5028	.5068	.4938	.4344	.4163	.4207	.1463
Avg	.7499	.7163	.6631	.6009	.6230	.6208	.6727

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314002 / 33 KV GOREGAON

Feeder No / Name : 206 / 11 KV Katangi Feeder
Feeder KV- 11 / OUTGOING

Sheddable Rural/Mix Feeder

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.9511		.8686	.7316	.7802	.7783
2	.9145	.9145		.8501	.6878	.7802	.7682
3	.9145	.8688		.8413	.6584	.7628	.7762
4	.905	.8413		.8048	.6335	.7011	.7762
5	.8775	.7682		.7682	.5853	.7023	.7468
6	.6805	.695		.6154	.6219	.6099	.6908
7	.5609	.543		.4656	.4938	.5544	.5175
8	.4557	.3734		.4477	.4163	.462	.4572
9	.4161	.4706		.4252	.5121	.462	.4938
10	.5083	.3658	.4656	.5083	.4755	.4938	.5853
11	.567	.724	.5068	.5121	.3224	.4298	.5304
12	.6173	.724	.6154	.543		.5847	.5792
13	.6935	.724	.6516	.4755		.6024	.6516
14	.7011	.7421	.7087	.362		.5373	.7499
15	.7087	.724	.6836			.443	.7133
16	.6447	.5973	.5784		.567	.4784	.6767
17	.5611	.5068			.5249	.5258	.5914
18	.5792	.4344	.5415		.5068	.591	.7316
19	1.0608	.7602	.8215		.7602	.5121	.8688
20	1.0498	1.0136	.9149		.8682	.8029	1.1523
21	1.0791	1.0136	.9522		.9391	.8402	1.1584
22	1.0498	.9955	.9149		.8859	.8413	1.0791
23	1.0059	.9955	.8859	.7865	.815	.7865	1.0082
24	.9511	.9593		.8413	.7602	.7888	.7762
Max	1.0791	1.0136	.9522	.8686	.9391	.8413	1.1584
Min	.4161	.3658	.4656	.362	.3224	.4298	.4572
Avg	.7681	.7378	.7108	.6322	.6383	.6280	.7441

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314009 / 33KV TEDHA

Feeder No / Name : 201 / 11KV Tedha

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7373	.7701	.6882	.503	.3593	.5243	.421
2	.7373	.7537	.6718	.4862	.3593	.5243	.421
3	.7202	.7537	.6718	.4807	.3593	.5079	.4049
4	.6859	.7537	.6554	.4807	.3437	.4915	.4049
5	.6001	.7209	.6554	.4534	.3437	.5079	.4049
6	.6371	.639	.5735	.421	.3125	.4915	.3725
7	.6299	.6062	.5735	.4372	.2812	.4588	.3563
8	.6226	.6554	.5407	.4372	.2968	.4424	.3887
9	.6226	.6249	.5735	.3795	.3125	.3932	.3887
10	.6554	.6249	.5243	.4062	.3437	.4424	.4049
11	.6718	.7274	.6226	.3749	.3281	.4858	.4534
12	.6882	.7116	.5898	.4858	.3479	.506	.5182
13	.6882	.6958	.6226	.4858	.2656	.5281	.4858
14	.6554	.7362	.6226	.4858	.4096	.5441	.4534
15	.6062	.5121	.639	.3401	.4096		.4696
16	.5735	.2785	.6226	.3401	.426	.4744	
17	.6062	.5898		.3725	.3932	.4902	.4858
18	.6554	.5898		.3239	.4424	.4915	.5668
19	.7865	.6718	.4973		.4752		.6874
20	.852	.7373	.5365		.5407	.421	.8505
21	.852	.8029	.5365		.5898	.4372	.8505
22	.852	.9175	.5197		.5571	.4534	.7973
23	.8029	.6882	.503		.5243	.3887	.7973
24	.7545	.7701	.7045	.503	.3593	.5243	.421
Max	.852	.9175	.7045	.503	.5898	.5441	.8505
Min	.5735	.2785	.4973	.3239	.2656	.3887	.3563
Avg	.6956	.6805	.5975	.4314	.3909	.4786	.5133

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

GOREGAON S/DN.[810] BU 4810

Substation No/ Name :- 314009 / 33KV TEDHA

Feeder No / Name : 202 / 11KV Chopa

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4115	.3429	.3361	.285	.3258	.2347
2	.4706	.4115	.3258	.3361	.285	.3258	.2347
3	.4706	.3944	.3258	.3361	.285	.3086	.2347
4	.4525	.3944	.3429	.3361	.2683	.3086	.2347
5	.4525	.3772	.3258	.3174	.285	.3258	.2267
6	.3544	.2743	.2572	.2427	.2347	.2572	.2012
7	.3155	.3258	.2572	.2218	.2012	.2229	.1844
8	.298	.2401	.2058	.1848	.1844	.2058	.2012
9	.2947	.2515	.1886	.1448	.1509	.1886	.1844
10	.2915	.285	.1715	.1991	.1677	.1886	.1844
11	.2915	.3109	.2058	.1991	.1341	.1734	
12	.3601	.3292	.2743	.1991	.1509	.2328	
13	.3772	.3658	.2572	.1991	.1677	.2686	.3856
14	.3772	.362	.2915	.2172	.1886	.2865	.2683
15	.3601	.1402	.1543	.2172	.1715		.3185
16	.3086	.2103	.2743	.1629	.1886	.2454	
17	.3018	.2629		.1629	.2058	.2629	.3185
18	.3018	.2229		.2058	.2572	.1543	.3086
19	.3944	.3086	.2804		.2915		.439
20	.4458	.4115	.3547		.3772	.2515	.5788
21	.463	.4115	.3921		.3944		.5601
22	.463	.3772	.3547		.3772	.2515	.5228
23	.4115	.3601	.3734		.3429	.2515	.4668
24	.4706	.4115	.3601	.3734	.285	.3258	.2347
Max	.4706	.4115	.3921	.3734	.3944	.3258	.5788
Min	.2915	.1402	.1543	.1448	.1341	.1543	.1844
Avg	.3832	.3271	.2871	.2417	.2450	.2553	.3106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 201 / 11KV Dhapewada

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	.5014	.6805	.567	1.448	.8764	1.2178
2	.4656	.5014	.5014	.567	.9156	.8589	1.2178
3	.4656	.5014	.5014	.5493	.8987	.8764	1.2178
4	.4607	.4835	.5014	.5493	.8987	.8589	1.1462
5	.443	.4961	.5014	.5138	.8916	.8413	1.1104
6	.3429	.3561	.3601	.39	.703	.7377	.929
7	.2949	.2721	.3041	.3041	.503	.5693	.9088
8	.2286	.2561	.1296	.3321	.407	.4816	.8718
9	.2721	.2881	.3315	.3437	.4024	.5624	.9556
10	.2846	.3315	.3932	.3887	.3812	1.286	.8684
11	.3605		.431	.3768	.0191	.8356	.8951
12	.373		.4239	.4144	.5304	.7956	1.283
13	.4287	.4508	.4287	.4748	.9015	.5967	1.4899
14	.12	.3944	.4748	.4748	1.0517	.5967	1.387
15	.1187	.4115	.3978	.3681			1.3375
16	.0848	.2818	.3637	.3395	.5868	.4534	1.1869
17	.0791		.3704	.3321	.5376	.4374	1.2548
18	.3563	.2343	.3841	.3768	.6964	.3241	1.3717
19	.4733	.4031	.4854	.3944	.8916	.4458	1.8088
20	.5611	.4835	.5194		1.0056	1.086	2.1033
21	.5792	.4887	.591		1.0277	1.0242	2.0851
22	.543	.5014	.5847		.9465	1.2715	1.9185
23	.5194	.5014	.567		.9114	1.2357	1.8099
24	.4656	.5194	.4961	.567	1.448	.8764	1.2178
Max	.5792	.5194	.6805	.567	1.448	1.286	2.1033
Min	.0791	.2343	.1296	.3041	.0191	.3241	.8684
Avg	.3661	.4123	.4468	.4312	.7828	.7795	1.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 202 / 11KV Navegaon

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2715	.2957	.2715	.2534	.2534	.2507
2	.2561	.2715	.2957	.2715	.2534	.2534	.2507
3	.2561	.2715	.2957	.2715	.2353	.2534	.2507
4	.2561	.2715	.2957	.2715	.2353	.2534	.2534
5	.2195	.2534	.2957	.2353	.2353	.2353	.2172
6	.1448	.1595	.1848	.1734	.1595	.1595	.1734
7	.1214	.1326	.1433	.1219	.1214	.1296	.1372
8	.0848	.116	.1417	.16	.116	.1296	.1296
9	.1187	.156	.1433	.1475	.1311	.16	.1638
10	.1187	.156	.2229	.1658	.1311	.1658	.1638
11	.1402	.1753	.1753	.1715	.12	.1844	.2012
12	.1791	.2172	.197	.1715	.1029	.1214	.2204
13	.1991	.2172	.2149	.208	.1402	.2103	.2254
14	.2328	.2172	.2328	.2229	.156	.2103	.2629
15	.2149	.197	.2126	.1543		.2058	.2103
16	.1949	.1595	.1715	.0995	.1387	.1865	.2035
17	.1543		.1526	.1227	.1492	.1696	.213
18	.1677	.0857	.1311	.1417	.1658	.1296	.1966
19	.2149	.1307	.1991	.2012	.2126	.1772	.2658
20	.2926	.1494	.2743		.2743	.2195	.3582
21	.3109	.1867	.2926		.2743	.2561	.3582
22	.3109	.1848	.2896		.2715	.2534	.3403
23	.2896	.2957	.2896		.4525	.2534	.3189
24	.2561	.2715	.2957	.2715	.2534	.2534	.2534
Max	.3109	.2957	.2957	.2715	.4525	.2561	.3582
Min	.0848	.0857	.1311	.0995	.1029	.1214	.1296
Avg	.2079	.1977	.2268	.1927	.1993	.2010	.2341

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 203 / 11kv MIDC jackwell water Only one consumer of WW with HT-IV
works Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0829	.0848	.0838	.0983	.0983	.0995	.0995
2	.0829	.0848	.0838	.0983	.0983	.1006	.0995
3	.0829	.0838	.0838	.0995	.0983	.1006	.0995
4	.0829	.0838	.0838	.0983	.0983	.1006	.0983
5	.0829	.0838	.0838	.0995	.0972	.1006	.0983
6	.0829	.0543	.0829	.0983	.0972	.0693	.0983
7	.0819	.0532	.0829	.0983	.0671	.0693	.0829
8	.0819	.0532	.0829	.0983	.0671	.0983	.0829
9	.0838	.0829	.0829	.0983	.0671	.0983	.0838
10	.0995	.0838	.0838	.0983	.0972	.0995	.0829
11	.0983	.0848		.0983	.0972	.0995	.0838
12	.0995	.0848	.0857	.0983	.0972	.0693	.0838
13	.1006	.0857	.1006	.0995	.0983	.1006	.0848
14	.1006	.0848	.1017	.0983	.0549		.0549
15	.1006	.0848	.1006	.0983			
16	.1006	.0838	.0995	.0972	.0848	.0848	.0549
17	.0701		.0693	.0678	.0995	.0848	.0549
18	.0549	.0543	.0686	.0678	.0995	.0983	.0549
19	.0549	.0543	.0693	.0678	.0995	.0972	.0549
20	.0549	.0549	.0693		.0995	.0983	.0549
21	.0848	.0838	.0693		.0995	.0983	.0543
22	.0848	.0848	.0701		.0995	.0995	.0549
23	.0848	.0848	.0709		.0995	.0995	.0549
24	.0895	.0848	.0848	.0709	.0972	.1006	.0995
Max	.1006	.0857	.1017	.0995	.0995	.1006	.0995
Min	.0549	.0532	.0686	.0678	.0549	.0693	.0543
Avg	.0843	.0765	.0824	.0925	.0918	.0940	.0770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314007 / 33KV DHAPEWADA

Feeder No / Name : 204 / 11 KV AGP Dhapewada

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0019	.0019	.0019	.0019	.0019	.0152
2	.0019	.0019	.0019	.0019	.0019	.0019	.0152
3	.0019	.0019	.0019	.0019	.0019	.0019	.0152
4	.0019	.0019	.0019	.0019	.0019	.0019	.0114
5	.0019	.0019	.0019	.0095	.0019	.0019	.0114
6	.0019	.0019	.0019	.0019	.0019	.0019	.0114
7	.0019	.0019	.0019	.0019	.0019	.0019	.0114
8	.0019	.0019	.0019	.0019	.0019	.0019	.0119
9	.0019	.0019	.0019	.0019	.0019		.0152
10	.0019	.0019	.0019	.0019	.0019		.0038
11	.0019	.0019	.0076	.0019	.0019		.0038
12	.0019	.0019		.0019	.0019		.0038
13	.0019	.0019	.0019	.0019	.0019		.0038
14	.0019	.0019	.0019	.0019	.0019		.0095
15	.0019	.0019	.0019	.0019			
16	.0019	.0377	.0019	.0019	.0019	.0019	
17	.0019		.0019	.0019	.0019	.0019	.0095
18	.0019	.0019	.0019	.0019	.0019	.0076	.0019
19		.0019	.0019	.0019	.0019	.0019	.0019
20	.0019	.0019	.0019		.0019	.0019	.0019
21	.0019	.0019	.0019		.0019	.0019	.0019
22	.0019	.0019	.0019		.0019	.0019	.0019
23	.0019	.0019	.0019		.0019	.0019	.0019
24	.0019	.0019	.0019	.0019	.0019	.0019	.0152
Max	.0019	.0377	.0076	.0095	.0019	.0076	.0152
Min	.0019	.0019	.0019	.0019	.0019	.0019	.0019
Avg	.0019	.0035	.0021	.0023	.0019	.0022	.0081

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 201 / 11KV Tirora-U-

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9864	2.8704	2.8959	2.5692	2.4434	2.4806	2.1033
2	2.7511	2.8349	2.7692	2.516	2.4072	2.3565	2.0683
3	2.5339	2.7641	2.5701	2.4806	2.19	2.1033	2.0332
4	2.2986	2.6578	2.3891	2.2786	2.0271	2.0157	2.0157
5	2.19	2.5869	2.1357	2.2436	1.9004	1.7878	1.9281
6	1.9728	1.9281	1.9547	1.7878	1.7556	1.5947	1.5604
7	1.6289		1.5746	1.4403	1.448	1.4746	1.3523
8	1.4842	2.0022	1.5927	1.2717	1.2851	1.3032	1.2346
9	1.4899	1.6289	1.4232	1.3937	1.166	1.286	
10	1.5592	1.7918	1.5604	1.5023	1.2517	1.4746	
11		1.9105	1.7528	1.3937	1.3717	1.6461	
12		2.2085	2.0332	1.8099	1.5604	1.8204	
13		2.5158	2.3211	2.0271	1.7337	2.0683	
14	2.9767	2.552	2.4451	2.19	1.7164	2.1384	
15	2.9058	2.4796	2.1971	2.2624	1.7318	2.1735	
16	2.6578	2.3529	1.7337	1.9004	1.7684	2.2085	
17	2.2502	1.9547	1.5947	1.6651	1.8204	1.9418	2.2786
18	1.9281	1.8642	1.7164	1.086	1.6289		
19	2.1735		1.9982		2.0157		
20	2.4806	2.5339	2.226		2.2436		
21	2.6578	2.733	2.3487		2.2611	1.7337	
22	2.8881	2.8597	2.5692		2.4097	2.0458	
23	2.9767	3.0226	2.6863		2.5869	2.226	2.8654
24	3.0407	2.9058	2.9864	2.6505	2.4796	2.5869	2.1033
Max	3.0407	3.0226	2.9864	2.6505	2.5869	2.5869	2.8654
Min	1.4842	1.6289	1.4232	1.086	1.166	1.286	1.2346
Avg	2.3729	2.4072	2.1448	1.9194	1.8835	1.9270	1.9585

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 202 / 11KV Mangezari

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6697	.6379	.6697	.6201	.5249	.5792	
2	.6697	.6201	.6335	.5959	.5068	.543	
3	.6335	.6201	.5611	.5959	.4706	.5068	
4	.5792	.6201	.5249	.5609	.4344	.4706	
5	.5068	.6024	.4706	.5258	.3982	.4163	
6	.4344	.4382	.4344	.3856	.3439	.362	
7	.2715	.2774	.3258	.2915	.2534	.3077	
8	.2715	.2774	.3258	.2572	.2353	.2896	.208
9	.3155	.3077		.3077	.2172	.2401	.2172
10	.3189	.3801	.3467	.3077	.1448	.2774	.2534
11	.3544	.4525	.3814	.3077	.2172	.2915	.2172
12	.443	.4887	.3856	.3258	.2172	.3294	.2353
13	.4607	.5249	.4382	.3982	.2534	.4161	.3258
14	.5138	.543	.4557	.4344	.2896	.3988	.4525
15	.5138	.4706	.3988	.3801	.2896	.3467	.4344
16	.4207	.4163	.2401		.362	.3467	.362
17	.3506		.2229	.2172	.3258	.2743	.362
18	.3681	.3077	.3467	.2715	.3077		.3801
19	.4557	.5611	.4557		.4706		.543
20	.6379	.6878	.6024		.6154	.2601	.7783
21	.7619	.7602	.6661	.5973	.6516	.1715	.8688
22	.7619	.7602	.691	.5973	.6516	.2629	.8688
23	.631	.724	.6733	.543	.6154	.4031	.8145
24	.7059	.6379	.724	.6201	.5249	.6154	.4207
Max	.7619	.7602	.724	.6201	.6516	.6154	.8688
Min	.2715	.2774	.2229	.2172	.1448	.1715	.208
Avg	.5021	.5268	.4771	.4353	.3884	.3686	.4554

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 203 / 11KV Mandvi

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6024	.6135	.5784	.6024	.4557	.4908	.3856
8	.3988	.3681	.4508	.3814	.298	.2947	.2601
12	.5258	.5083	.6135	.4508	.2601	.3467	.1543
16	.4382	.4207	.2804		.2254	.3155	.2572
20	.6201	.6485	.5959	.5316	.5258	.3856	.6201
23	.6661	.7442	.7265	.567	.6135	.4557	.6485
24	.7186	.6556	.7265	.6733	.5847	.6024	.443
Max	.7186	.7442	.7265	.6733	.6135	.6024	.6485
Min	.3988	.3681	.2804	.3814	.2254	.2947	.1543
Avg	.5671	.5656	.5674	.5344	.4233	.4131	.3955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 204 / 11KV Paldongri

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.2481	.2353	.2279	.2172	.2172	.1734
2	.2172	.2481	.2172	.2279	.1991	.1991	.1734
3	.2172	.2303	.1991	.2279	.1991	.1991	.156
4	.181	.2303	.181	.2103	.181	.181	.156
5	.1629	.2279	.1629	.2103	.1629	.1448	.1372
6	.1448	.1402	.1448	.1227	.1448	.1267	.1029
7	.1086	.0876	.1086	.0857	.0905	.0905	.0686
8	.0905	.0867	.1086	.0857	.0724	.0905	.0686
9		.1086	.0686	.1086	.0905	.0857	.0905
10			.0686	.1086	.0724	.0857	.0905
11			.0686	.1267	.0724	.1029	.0905
12			.0686	.1267	.0905	.1372	.1448
13			.1387	.1448	.1086	.1387	.1086
14			.1387	.1629	.1086	.1387	.1448
15	.1417		.1029	.1629	.1086	.1372	.1448
16	.1402	.1086	.0686	.1267	.1086	.1029	.1086
17	.1402	.1086	.0686	.0724	.0905	.1029	.0905
18	.1052	.1086	.1029		.0905		.0905
19	.1402		.1753	.0905	.1448		.1448
20	.2303	.2172	.2126		.1991	.1543	.2172
21	.2658	.2353	.2454	.2172	.2172	.1753	.2534
22	.2658	.2715	.2481	.2353	.2353	.1928	.2534
23	.2481	.2534	.2481	.2172	.2353	.1928	.2353
24	.2353	.2481	.2353	.2303	.2172	.2172	.1753
Max	.2658	.2715	.2481	.2353	.2353	.2172	.2534
Min	.0905	.0867	.0686	.0724	.0724	.0857	.0686
Avg	.1817	.1858	.1507	.1604	.1440	.1461	.1425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314013 / 33KV TIRORA S/STN

Feeder No / Name : 205 / 11 kv mandvi AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	10-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0019
2				.0019
3				.0038
4				.0038
5				.0038
6				.0038
7				.0038
8				.0038
9			.0038	
10	.0037	.0038		
11	.0038	.0038		
12	.0038	.0019		
13	.0038	.0019		
14	.0037	.0019		
15	.0037	.0019		
16	.0037	.0037		
17	.0038	.0038		
24				.0038
Max	.0038	.0038	.0038	.0038
Min	.0037	.0019	.0038	.0019
Avg	.0038	.0028	.0038	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 201 / 11KV DAWNIWADA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.463	.4801	.4801	.3944	.4525	.3772
2	.4458	.463	.4115	.4458	.3944	.4525	.3429
3	.4287	.4458	.3772	.4458	.3772	.4525	.3429
4	.4287	.4458	.3429	.4287	.3429	.4163	.3772
5	.3772	.3772	.3429	.3772	.3086	.3439	.3772
6	.3258	.3086	.3086	.2915	.2743	.2896	.2743
7	.2572	.2572	.2229	.2401	.2229	.2534	.2743
8	.2058	.2401	.2229	.2743	.2229	.2353	.2572
9	.2401	.2572	.3601	.3086	.2926	.362	.3258
10	.2915	.3801	.3944	.3258	.2534	.2743	.3086
11	.3258	.4115	.3944	.3772	.2534	.3944	.3601
12	.3772	.463	.463	.3772	.2534	.1029	.4344
13	.3944	.4801	.4801	.463	.3077	.1372	.4887
14	.4525	.463	.4801		.3258	.128	.4887
15	.4525	.4458	.463				.4706
16	.3982	.4115	.3429		.3258	.1029	.4525
17	.3439	.2743	.3429		.4163	.4973	.4525
18	.362	.3086	.3601		.3439		.4163
19	.3801	.3601	.3944		.3982	.3086	
20	.543	.5316	.463		.5068	.4287	.6516
21	.6154	.5658	.4801		.5249	.463	.6878
22	.5611	.5487	.5144		.5068	.4973	.6697
23	.5249	.5144	.5144	.4287	.4706	.4458	.5973
24	.463	.5068	.5144	.4801	.4115	.4706	.4115
Max	.6154	.5658	.5144	.4801	.5249	.4973	.6878
Min	.2058	.2401	.2229	.2401	.2229	.1029	.2572
Avg	.4017	.4135	.4029	.3829	.3534	.3413	.4278

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 202 / 11KV DONGARGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.7545	.6859	.7202	.6344	.6878	.5658
2	.7202	.7545	.6516	.7202	.6344	.6516	.5487
3	.703	.7373	1.4232	.703	.6173	.6516	.5487
4	.6859	.703	.583	.6859	.6001	.6154	.5144
5	.6173	.6001	.5487	.6001	.5144	.543	.5487
6	.4973	.5144	.5487	.4801	.463	.4706	.463
7	.4287	.4287	.463	.3429	.3772	.3439	.4287
8	.4287	.4458	.4801	.3944	.3429	.3801	.4458
9	.4287	.5316	.4287	.3944	.4572	.4525	.4458
10	.4287	.5611	.463	.4801	.3982	.4458	.4801
11	.4801	.6173	.5487	.5144	.3982	.5144	.5487
12	.5316	.6344	.583	.5316	.4525	.5316	.6154
13	.583	.6859	.6516		.4887	.6516	.6697
14	.6335	.703	.6687	.583	.5068	.6001	.6154
15	.6878	.6173	.6516		.4887		.6516
16	.6335	.5658	.5144		.4706	.4973	.6154
17	.5611	.4458	.463		.4706	.5316	.5792
18	.5973	.463	.5144		.5068		.5792
19	.6697	.5487	.6001		.6335	.5316	.7964
20	.905	.8059	.703		.7421	.6001	.905
21	.9412	.8402	.7373		.8326	.6687	.9412
22	.9231	.823	.7716		.7783	.6516	.905
23	.8326	.7888	.7545	.6687	.724	.6173	.8145
24	.7373	.7964	.7545	.7373	.6516	.724	.583
Max	.9412	.8402	1.4232	.7373	.8326	.724	.9412
Min	.4287	.4287	.4287	.3429	.3429	.3439	.4287
Avg	.6406	.6403	.6330	.5704	.5493	.5619	.6171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314020 / 33KV EKODI SUBSTATION

Feeder No / Name : 203 / 11KV KACHEWANI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2915	.2743	.2572	.2572	.2534	.2058
2	.2743	.2743	.2572	.2401	.2572	.2534	.2058
3	.2572	.2743	.2572	.2401	.2401	.2353	.2058
4	.2572	.2572	.2401	.2229	.2401	.2172	.1886
5	.2058	.2229	.2401	.1886	.2058	.1991	.1886
6	.1886	.1715	.2229	.12	.1886	.181	.1372
7	.1715	.1372	.1543	.1029	.1543	.1448	.1029
8	.1715	.1267	.1543	.12	.1372	.1448	.12
9	.1715	.1267	.1715	.1543	.128	.1372	.1029
10	.2058	.1991	.1886	.1372	.1267	.1715	.1372
11	.2058	.1886	.2058	.1715	.1448	.1886	.1543
12	.2229	.2572	.1886	.2058	.1448	.2058	.1629
13	.2572	.2572	.2229	.2229	.181	.1886	.181
14	.2353	.2572	.2058		.0905	.1715	.1629
15	.2353	.2229	.1715		.0724		.181
16	.2172	.1715	.1372		.0724	.1715	.1629
17	.181	.1372	.1715		.1991	.1372	.1448
18	.181	.1372	.1715		.1991		.1448
19	.1991	.1886	.2058		.2172	.0857	.2353
20	.3077	.2915	.2743		.2896	.1715	.2715
21	.3439	.3086	.2915		.3077	.2058	.2896
22	.3439	.3258	.2915		.2896	.2229	.2896
23	.3258	.3086	.2743	.2743	.2896	.2229	.2715
24	.2915	.3077	.2915	.2572	.2572	.2715	.2058
Max	.3439	.3258	.2915	.2743	.3077	.2715	.2896
Min	.1715	.1267	.1372	.1029	.0724	.0857	.1029
Avg	.2386	.2267	.2193	.1943	.1954	.1901	.1855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 201 / 11 KV Sukadi (Dak)

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8461	1.7718	1.97	1.5746	1.4899	1.6289	1.3352
2	1.8099	1.7177	1.9342	1.5927	1.5061	1.5775	1.2986
3	1.8099	1.7364	1.9185	1.5424	1.4175	1.5432	1.1888
4	1.7194	1.6651	1.828	1.5089	1.387	1.4575	1.0974
5	1.6289	1.6301	1.6827	1.4251	1.2403	1.3717	1.0242
6	1.267	1.1616	1.3169	1.0631	.964	1.1568	.9412
7	.9955	1.0517	1.0791	.9465	.9114	.9745	.823
8	.724	1.0166	1.0791	.8122	.8764	.929	.8413
9	1.0498	1.1517	1.0774	.9326	.9036	.9114	.8048
10	1.0692	1.3352	1.203	1.0985	.8413	1.0242	.9214
11	1.2445	1.4815	1.1797		.9088		.9922
12	1.4175	1.6644	1.3599		.9259	1.2536	
13	1.56	1.7375	1.5223	1.4175	.9602		
14	1.6827	1.6289	1.5729	1.4198	1.0513		
15	1.5364	.9328	1.2597	1.382			.9214
16	1.3496	1.3756	.2374		1.0513	1.1403	.9036
17	1.134	1.2254	.4578	.1772	.9835	1.0791	1.283
18	1.0985	1.1157	.6443	.1646	.9614		1.1744
19	1.4022	1.4299	1.0117	1.2803	1.1934		1.3321
20	1.949	1.957	1.0852	1.7737	1.6278		1.9667
21	2.0553	2.1176	1.6956	1.7878	1.7635		1.9806
22	1.9765	2.1176	1.6933	1.7187	1.7604		1.9281
23	1.8959	2.0271	1.6598	1.6301	1.6766	1.1946	1.8604
24	1.8461	1.8427	1.9879	1.6244	1.5947	1.6263	1.3169
Max	2.0553	2.1176	1.9879	1.7878	1.7635	1.6289	1.9806
Min	.724	.9328	.2374	.1646	.8413	.9114	.8048
Avg	1.5028	1.5372	1.3524	1.2797	1.2172	1.2579	1.2350

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 203 / 11 KV Gangla Navezari

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955	1.0631	1.0498	.8916	.6661	.8764	.1791
2	.9412	1.0867	1.0498	.8573	.6661	.8764	.1595
3	.905	1.0985	1.0317	.8322	.7186	.8238	.1595
4	.905	1.0517	.9955	.8322	.6836	.7973	.1417
5	.8145	.9391	.905	.7888	.7537	.7087	.124
6	.6878	.5784	.6401	.5959	.5493	.567	.1063
7	.5611	.5784	.567	.5068	.4508	.5014	.0886
8	.543	.5609	.5552	.5487	.4031	.4835	.4298
9	.5792	.6135	.5935	.631	.4382	.5973	.4031
10	.5784	.7164	.703	.6335	.4607	.5068	.4525
11	.6661	.788	.7373		.6344		.5548
12	.8505	.8688	.8916		.6485	.7796	
13	.8939	.8954	.9326	.5258	.5658		
14	.9568	.8417	.9156	.8495	.7373		
15	.9412	.788	.8478	.9114			.7108
16	.7796	.724	.0905	.8859	.6859	.7522	.7011
17	.6024	.7059	.5935	.9145		.6154	.5784
18	.6379	.6335	.7011	.9568	.463		.5434
19	.7442	.788	.7202	.1829	.6687		.6485
20	.9991	.9955	.7716	.8962	.8573		.9709
21	1.0166	1.0745	.9602	.9745	.9431		.9816
22	1.1517	1.0745	1.0174	.9465	.9431		1.0692
23	1.1041	1.0924	.9602	.9391	.9431	.1791	1.0229
24	1.0317	.9991	1.0679	.9326	.9036	.9088	.1791
Max	1.1517	1.0985	1.0679	.9745	.9431	.9088	1.0692
Min	.543	.5609	.0905	.1829	.4031	.1791	.0886
Avg	.8286	.8565	.8041	.7743	.672	.6649	.4859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314023 / 33 KV Birsi (Satona)

Feeder No / Name : 204 / 11 Kv Tirora Urban AG

Ag dominated/Pure Ag

Feeder Feeder KV- 11 /

OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0191	.0171		.0381	.037	.0171
2	.0181	.0191	.0171		.0381	.0343	.0171
3	.0181	.0191	.0171		.0381	.0343	.0171
4	.0181	.0191	.0171		.0381	.0343	.0171
5	.0181	.0191	.0171	.0189	.0572	.0343	.0171
6	.0181	.0191	.0171	.0189	.0572	.0171	.0343
7	.0181	.0191	.0171	.0187	.0572	.0171	.0343
8	.0181	.0191	.0171	.0187	.0572	.0171	.0343
9	.0181	.0191	.0739	.0187		.0171	.0351
10	.1052	.0514	.0343	.0572	.0191	.0185	.0191
11	.0549	.0343	.0343		.0187		.0191
12	.0532	.0514	.0343			.0171	
13	.0532	.0686	.0343	.0572		.0171	
14	.0549	.0514	.0343	.0572	.0187		
15	.0549	.0514	.0343	.0572			
16	.0549	.0686	.0343	.0354	.0187	.0171	.0191
17	.0572	.0686	.0343	.0381	.0187	.0171	.0191
18	.0191	.0171	.0373	.0191	.037		.0191
19	.0191	.0171	.0373	.0191	.0185		.0191
20	.0191	.0171	.0189	.0191	.0185		.0191
21	.0191	.0171	.0187	.0191	.0185		.0191
22	.0191	.0171	.0187	.0191	.0185		.0191
23	.0191	.0171	.0187	.0191	.0185	.0171	.0191
24	.0181	.0191	.0171	.0187	.0191	.0185	.0171
Max	.1052	.0686	.0739	.0572	.0572	.037	.0351
Min	.0181	.0171	.0171	.0187	.0185	.0171	.0171
Avg	.0327	.0308	.0272	.0294	.0312	.0228	.0216

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 201 / KARTI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5028	.5344	.333		.4908
2	.5258	.5028	.535	.333		.4908
3	.5258	.5028	.5344	.333		.4382
4	.5083	.4854	.4636			.4453
5	.5083	.4334	.4632	.2103		.4453
6	.3681	.3467	.3567	.2103		.3028
7	.298	.2601	.3206	.1753		.285
8	.298	.2774	.3028	.1578		.3385
9	.3155	.2591	.3206	.1753		.3563
10	.3052	.3919	.3506	.1086		
11	.3222	.3741	.3155	.1448		
12	.373		.4031			
13	.4409		.4557	.1991		.4275
14	.407	.3745	.4733	.4887		.4632
15	.39	.3741	.2454	.4298		.4632
16	.3561	.3741			.3155	.4453
17	.2713	.285	.2629		.3506	.3563
18	.2883	.321			.333	
19	.4161	.3919	.4207	.4477	.4207	
20	.5375	.3919		.5731	.5083	
21	.5895	.57		.5373	.5434	
22	.5895	.5344		.5194	.5434	
23	.5201	.5344	.298		.5434	
24	.5434	.5028	.5258	.333		.4908
Max	.5895	.57	.535	.5731	.5434	.4908
Min	.2713	.2591	.2454	.1086	.3155	.285
Avg	.4260	.4087	.3991	.3172	.4448	.4160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 202 / ARJUNI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3315	.3239	.3563	.3258		.3385	
2	.3429	.3239	.3563	.3258		.3385	
3	.3429	.3239	.3567	.3258		.2672	
4	.3258	.3239	.3563			.2672	
5	.3258	.2915	.3388	.2058		.2672	
6	.2401	.2429	.2675	.2058		.2494	
7	.1886	.2267	.2672	.1886		.2138	
8	.2058	.2267	.1781	.1715		.2138	
9	.2229	.2267	.2316	.1372		.1781	
10	.2267	.3028	.2401	.1457			
11	.2429	.285	.2743	.1619			.1427
12	.2591	.285	.2915			.2494	
13	.2591	.3374	.3429	.2591		.285	
14	.2753	.2494	.3086	.2591		.3206	
15	.2429	.2131	.2743	.1943		.2672	
16	.2429	.2494			.2229	.2494	
17	.2429	.1781	.2229	.1296	.1886	.2138	
18	.2591	.2138	.2401		.2572		
19	.2915	.2853	.3601	.2429	.3086		
20	.3563	.3563	.3601	.3077	.3429		
21	.3887	.4275	.3601	.3077	.3601		
22	.3725	.3919	.3601	.3077	.3258		
23	.3401	.4045	.3429		.3258		
24	.3601	.3239	.3563	.3258		.3385	
Max	.3887	.4275	.3601	.3258	.3601	.3385	.1427
Min	.1886	.1781	.1781	.1296	.1886	.1781	.1427
Avg	.2869	.2922	.3062	.2383	.2915	.2661	.1427

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 203 / SONEGAON

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	13-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2818	.2915	.2853	.2486	
2	.2818	.2915	.2853	.2486	
3	.2818	.2753	.285	.2486	
4	.2652	.2753	.2841		
5	.2652	.2429	.2663	.1989	
6	.1989	.2105	.2308	.1989	
7	.1658	.1943	.1781	.1658	
8	.1658	.1943	.1781	.1492	
9	.1658	.1943	.1781	.1658	
10	.1802	.2138	.1989	.1943	
11	.1781	.2138	.2005	.1781	
12	.2105	.2494	.2486	.1943	
13	.2429	.285	.2818	.2105	.285
14	.2267	.2316	.2818	.2267	.285
15	.2267	.2316	.1658	.1943	.2672
16	.1943	.2138			.2494
17	.2105	.1783	.1658		.2138
18	.1943	.2138	.1658		
19	.2267	.2318	.2321	.1943	
20	.3077	.2316	.2321	.2591	
21	.3239	.3028	.2486	.2591	
22	.3239	.3028	.2652	.2591	
23	.2915	.285	.2486		
24	.2818	.2915	.285	.2486	
Max	.3239	.3028	.2853	.2591	.285
Min	.1658	.1783	.1658	.1492	.2138
Avg	.2372	.2436	.2344	.2128	.2601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 314026 / PARASWADA S/STN

Feeder No / Name : 204 / 11 KV AGP Paraswada

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	08-JUN-17	10-JUN-17	11-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0166		.0166
2	.0166		.0166
3	.0166		.0166
4	.0166		
5	.0166		.0166
6	.0166		.0166
7	.0166		.0166
8	.0166		.0166
9	.0166		.0166
10	.0594	.0829	.0143
11	.0594	.0829	.0143
12	.0602	.0829	.0143
13	.0602	.0663	
14	.0594	.0497	.029
15	.0753	.0497	
16	.0602		
17	.0602	.0663	
18		.0166	
19		.0166	
20		.0166	
21		.0166	
22		.0166	
23		.0166	
24	.0166		.0166
Max	.0753	.0829	.029
Min	.0166	.0166	.0143
Avg	.0367	.0446	.0170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 402 / 33KV LIS Dhapewada

HV LIS Feeder

Feeder KV- 33 / OUTGOING

DATE	11-JUN-17
HR	Load (MW)
7	.0543
Max	.0543
Min	.0543
Avg	.0543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 403 / 33 KV Tirora

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17	14-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.5474	7.656	7.7366	6.9502	6.4072		4.3439
2	7.0382	7.4389	7.2291	6.0814	6.1357		4.2353
3	6.6084	7.2217	6.6255	5.5384	5.647		4.1267
4	5.9534	7.0045	6.1523	4.8868	5.2092		3.9638
5	5.475	6.6975	5.4613	4.3587	4.8903		3.8009
6	4.9954	5.0497	4.9931	4.2067	4.5182		3.2036
7	4.0489	2.5206	4.0124	3.8272	3.5757		2.6578
8	3.5757	4.2221	4.0124	3.4705	2.8607		2.8807
9	3.9529		4.0124		3.3122	3.638	3.2036
10	4.1015		4.4753		3.3122	3.7466	3.4751
11	2.8921		4.8891		3.6923	4.5068	3.8009
12	3.2247		5.5653		3.9095		2.2262
13	3.5888		6.2574		4.2353		2.6606
14	6.6781	4.4525	6.5204		4.5068		2.8778
15	6.5381	4.7239	4.421		4.561		2.8235
16	6.0597	5.5213	2.7566		4.4056		2.4451
17	4.9954	4.6811	3.1207	2.1176			4.9966
18	4.7782	4.321	3.3808	2.8235			4.0489
19	5.8642	3.7551	3.6408	4.181			5.1006
20	7.2217	7.0696	4.0569	5.2669		.8145	7.1514
21	7.8189	7.7075	5.048	6.6787		2.6606	7.3886
22	8.0904	7.9201	6.31	6.8959		3.095	7.6012
23	7.9818	8.059	7.0988	6.6787		3.3665	7.548
24	7.7103	7.656	7.8441	7.1674	6.6244		4.7782
Max	8.0904	8.059	7.8441	7.1674	6.6244	4.5068	7.6012
Min	2.8921	2.5206	2.7566	2.1176	2.8607	.8145	2.2262
Avg	5.6975	5.9831	5.2342	5.0706	4.5767	3.1183	4.2225

Feederwise Load Information for **All Feeders**

From 08-JUN-17 and 14-JUN-17

GONDIA ZONE[065]

GONDIA CIRCLE[664]

GONDIA DIVISION[652]

TIRORA S/DN.[392]

BU 0392

Substation No/ Name :- 318002 / 220KV KAWALEWADA S/STN

Feeder No / Name : 407 / 33 KV Paraswada

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	08-JUN-17	09-JUN-17	10-JUN-17	11-JUN-17	12-JUN-17	13-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4344	.4904	.423	.2601		.1303
16	.6241	.695	.2229		.3601	
24	.7602	.7099	.7202	.439		.483
Max	.7602	.7099	.7202	.439	.3601	.483
Min	.4344	.4904	.2229	.2601	.3601	.1303
Avg	.6062	.6318	.4554	.3496	.3601	.3067