

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 204 / 11 KV Dhargaon Feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9955	1.086	1.0631	1.1517	1.2536	1.2403	1.1145
2	.9955	1.086	.9745	1.1393	1.2536	1.2403	1.0288
3	.9955	1.086	.9745	1.0402	1.2536	1.1517	1.0288
4	.9955	.9955	.9745	1.0288	1.2536	1.1517	.9431
5	1.0059	.905	.9745	.9326	1.2403	1.0517	.9431
6	.7973	.7164	.8859	.8478	.8669	.8573	.9326
7	.7087	.6859	.7802	.763	.6201	.7373	.7373
8	.6783	.6859	.7802	.6554	.8288	.8097	.7907
9	.6783	.6783	.8764	.7459	.9221	.8097	.8002
10	.6859	.763	.8669	.8192	.9326	.7287	.8002
11		.8478	.9326		1.0174	.7287	.8802
12		.7973		.4144	1.1145	.8383	.9221
13	.8669	.7973	2.0328	.8478		.9831	1.0898
14	.8859	.7973	2.0328	1.2403	.8288	.9221	.9326
15	.8764	.8764	2.1253	1.1517	.5468	.8383	.9221
16	.6706	.8669	1.9404	1.1641	.5601	.8288	.7716
17	.6706	.763	1.7375	1.0174	.6401	.8002	.6249
18	.763	.8288	1.7194	.9945	.7202	.8697	.7907
19	.8859	1.0174	1.0174	1.2136	1.0402	1.1022	1.0059
20	1.0974	1.2536	1.3432	1.448	1.2536	1.3289	1.3289
21	1.2936	1.3432	1.448	1.448	1.3432	1.3289	1.4175
22	1.267	1.3575	1.3432	1.3432	.124	1.3289	1.4175
23	1.2012	1.2536	1.3432	1.2536	1.2403	1.2269	1.3146
24	1.086	1.086	1.2403	1.2536	1.2536	1.2403	1.2269
Max	1.2936	1.3575	2.1253	1.448	1.3432	1.3289	1.4175
Min	.6706	.6783	.7802	.4144	.124	.7287	.6249
Avg	.9137	.9406	1.2786	1.0397	.9612	1.0060	.9902

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 205 / 11 KV MIDC II feeder SHEDDABLE FEEDER MIDC EQUIVALENT
Feeder KV- 11 / OUTGOING HAVING WEEKLY STAGGERING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.8488	.6859	.7316	.9431	.9431	.8764
2	.3429	.8488	.6935	.724	.9431	.9431	.8764
3	.2172	.8488	.6935	.724	.8316	.9335	.8859
4	.2172	.823	.6935	.7164	.8316	.8402	.8859
5	.2172	.8402	.7087	.7164	.7164	.8402	.8059
6	.3953	.8859	.924	.7087	.8316	.8145	.8059
7	.3477	.7087	.8573	.6401	.7973	.7973	.6478
8	.3277	1.0374	.8859	.8573	1.0374	.9431	.5258
9	.4239	1.1317	1.0269	.724	1.0374	1.0164	.4858
10	.8488	1.4146	1.1317	1.4784	1.3203	1.0374	.381
11	.7164		.8488	1.587	1.0164	.924	.2
12	.9431	1.226	1.226	1.3203	1.4146	1.3203	.2401
13	.6401	1.226	.9335	1.3203		1.0374	.2715
14		1.226	1.1317	1.3203	.9431	1.1317	.362
15	.6068	1.226	.7011	1.1317	.905	1.0974	.2667
16	1.0374	1.226	.9335	1.1317	1.1317	1.1317	.2905
17	1.1317	1.0374	.9431	1.226	1.1317	1.1317	
18	.8488	1.226	.9335	1.0374	1.1317	1.1317	
19	.5668	.9145	.7316	.3239	.8059	.924	
20	.6201	.8402	.6201	.924	.9335	.9145	
21	.9145	.5487	.6535	.905	.905	1.0164	.3286
22	.924	.4858	.7164	.924	1.0164	.9145	.3525
23	.9145	.4801	.7164	.9335	.905	.8764	.3715
24	.4525	.9431	.5087	.7392	1.0374	1.0374	.8764
Max	1.1317	1.4146	1.226	1.587	1.4146	1.3203	.8859
Min	.2172	.4801	.5087	.3239	.7164	.7973	.2
Avg	.6086	.9562	.8291	.9519	.9812	.9874	.5368

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 207 / 11KV COBRA BN.

HV Express Feeder for Colony

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0554	.0924	.112	.112	.0934
2	.0934	.0934	.0554	.0554	.112	.112	.0934
3	.0934	.0934	.0373	.0739	.0934	.0934	.0934
4	.0934	.056	.056	.0554	.0934	.0934	.0934
5	.0934	.0373	.0373	.0554	.0934	.056	.0934
6	.0373	.0373	.0366	.0554	.056	.056	.0377
7	.0373	.0373	.056	.056	.056	.0373	.0377
8	.056	.056	.056	.056	.056	.0373	.0566
9	.056	.056	.0747	.0566	.056	.0373	.0514
10	.056	.056	.0747	.0754	.056	.0373	.0566
11	.056	.056	.0747	.0934	.056	.056	.056
12	.056	.056	.056	.0747	.056	.056	.056
13	.056	.056	.0747	.0747	.056	.056	.056
14	.0747	.056	.0747	.0747	.056	.056	.056
15	.0747	.056	.0747	.0747	.056	.056	.0747
16	.056	.056	.0747	.0747	.056	.056	.0754
17	.056	.056	.056	.056	.056	.056	.0754
18	.056	.056	.0554	.056	.056	.056	.0754
19	.112	.056	.1109	.112	.112	.112	.132
20	.1307	.112	.1294	.1307	.1307	.1307	.132
21	.112	.112	.1294	.1307	.1307	.1307	.1132
22	.1132	.112	.1109	.112	.1307	.1307	.132
23	.112	.112	.1109	.112	.112	.1307	.1132
24	.1132	.112	.056	.1109	.112	.112	.1307
Max	.1307	.112	.1294	.1307	.1307	.1307	.132
Min	.0373	.0373	.0366	.0554	.056	.0373	.0377
Avg	.0787	.0700	.0720	.0800	.0817	.0778	.0827

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 401 / 33 KV Ashok Leyland Feeder

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5206	2.4949	2.1948	2.4434	2.0062	2.8006	2.7435
2	2.5206	2.5206	2.1948	2.3405	2.0062	2.8006	2.7435
3	2.2405	2.5463	2.1948	2.0348	1.7833	2.4949	2.7435
4	2.2405	2.5206	2.1948	1.8747	1.7833	2.4949	2.4691
5	2.2405	2.3148	2.1948	1.7833	1.669	2.0576	2.4691
6	1.8061	2.5149	1.4403	1.669	1.6232	1.7147	1.9547
7	2.8292	2.3148	1.6004	1.669	2.8292	3.3951	3.1121
8	2.5463	2.8292	2.1033	1.286	2.8292	2.5463	2.8292
9	3.1121	3.1121	3.3608	1.7804	3.1121	3.3951	2.8292
10	3.1121	3.1121	2.8292	1.8004	2.8292	2.8292	3.1121
11	2.2634	2.2405	2.5463	1.8004	2.5463	2.2405	1.4146
12	3.1121	2.5463	3.1121	1.8976	3.3951	3.1893	2.8292
13	2.8292	2.8292	3.1121	1.8976	3.3951	3.3951	2.8292
14	2.5463	2.8292	2.5463	1.5404	2.8292	3.1121	2.572
15	2.2405	2.8292	2.5463	1.0602	2.5206	3.1121	3.1121
16	2.5206	2.8292	2.5463	.1572	2.5206	3.1121	3.1121
17	2.8292	3.678	2.8292	1.3803	3.3951	3.1121	2.8292
18	3.678	3.3951	2.8292	2.1348	3.3951	3.1121	3.3951
19	3.678	3.1121	2.8292	1.7604	3.3951	3.1121	3.1121
20	3.1121	2.8292	2.8292	1.6232	2.8292	3.3951	3.678
21	3.1121	2.8006	3.1121	1.669	2.8292	3.3951	3.3951
22	2.5463	2.5206	3.1121	1.7604	3.3951	2.8292	3.1121
23	3.1121	2.5206	3.1121	1.6461	3.1121	3.0807	3.1121
24	2.8006	2.4949	2.5206	2.8292	2.0062	2.8006	3.0807
Max	3.678	3.678	3.3608	2.8292	3.3951	3.3951	3.678
Min	1.8061	2.2405	1.4403	.1572	1.6232	1.7147	1.4146
Avg	2.7312	2.7390	2.5788	1.7433	2.6681	2.8970	2.8579

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 403 / 33 KV LAKHORI FEEDER
Feeder KV- 33 / INCOMING

HV Non-Express Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.2323	.8488	1.386	1.9404	1.6461	1.4415
2	1.1763	1.2323	.8488	1.3306	1.885	1.6461	1.3306
3	1.1203	1.2323	.8488	1.2197	1.8296	1.5364	1.2197
4	1.0642	1.1203	.8488	1.1088	1.7187	1.5364	1.1088
5	1.0082	.8962	.8488	.9979	1.6632	1.3717	1.0534
6	.7842	.7282	.7922	.8871	.8871	.9877	.9979
7	.6722	.6722		.7207	1.1643	.823	.9522
8	.6722	.6722		.7207	1.1088	.823	.8871
9	.6161	.6722		.6653	1.3306	.823	.9425
10	.7842	.7842		.8316	1.4266	.9328	.9979
11	.8402	.8962		.9425	1.701	1.0425	1.1203
12	.9522	.9522		.9979	1.701	1.1163	1.2752
13	1.0642	1.0082		1.2752	1.6461	1.0631	1.3306
14	1.1203	1.0642	1.1088	1.3306		1.1694	1.3575
15	1.0642	1.1763	1.2752	1.2752	.7682	1.1694	1.3443
16	.8871	1.1203	1.2197	1.2752	.7133	1.1163	1.1203
17	.7762	1.0082	1.1643	1.4969		1.0631	1.1203
18	.8316	.9522	.9979	1.4969		1.0317	1.0082
19	.8871	1.0082	.9979	1.6632	1.2071	1.2489	1.2323
20	1.0534	1.2323	1.2752	1.885	1.3717	1.4118	1.5278
21	1.1643	1.2883	1.3306	1.9404	1.4266	1.5746	1.6409
22	1.2883	1.2883	1.4415	1.9404	1.6461	1.6832	1.7541
23	1.0911	1.2449	1.4415	2.1068	1.0974	1.6832	1.8673
24	1.2883	1.2883	1.1317	1.386	2.0513	1.6461	1.6289
Max	1.2883	1.2883	1.4415	2.1068	2.0513	1.6832	1.8673
Min	.6161	.6722	.7922	.6653	.7133	.823	.8871
Avg	.9766	1.0321	1.0836	1.2867	1.4421	1.2561	1.2608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064004 / 33 KV GADEGAON

Feeder No / Name : 404 / 33 KV Varam Power
Feeder KV- 33 / OUTGOING

HV Express Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1109	.1086	.1097	.112
2				.1109	.1086	.1097	.112
3				.1109	.1086	.1097	.112
4				.1109	.1086	.1097	.2801
5				.1109	.1086	.1097	.112
6				.1109	.1086	.1097	.1097
7				.1109	.1086	.1097	.1097
8	8.5934			.1109	.1086	.1097	.1097
9				.1109	.1086	.1097	.1097
10				.08	.1097	.1097	.1097
11			.056	.064	.1097	.1097	.1097
12			.056	.064	.1097	.1097	.1097
13			.056	.064	.1646	.1097	.1097
14			.056	.064	.1097	.1097	.1097
15			.056	.1086	.1097	.1097	.1097
16	8.8706		.3361	.1086	.1097	.1097	.1086
17			.112	.1086	.1097	.1097	.1097
18			.112	.1086	.1097	.1097	.1086
19			.112	.1086	.1097	.1097	.1086
20			.112	.2715	.1097	.1097	.1086
21			.112	.1086	.1097	.1097	.1086
22			.112	.1086	.1097	.1097	.1086
23			.112	.1086	.1097	.1097	.1086
24	9.1478	8.8706	8.0098	.112	.1086	.1097	.1097
Max	9.1478	8.8706	8.0098	.2715	.1646	.1097	.2801
Min	8.5934	8.8706	.056	.064	.1086	.1097	.1086
Avg	8.8706	8.8706	.6721	.1078	.1115	.1097	.1169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 201 / 11 KV SHAHAPUR AGP AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0914	.0857	.1372	.2286	.1372	.1677
2	.0857	.0914	.0857	.1372	.1905	.1372	.1677
3	.0857	.0914	.0857	.1372	.1905	.1372	.1677
4	.0857	.0914	.1029	.12	.2096	.1372	.1677
5	.0953	.0914	.1029	.12	.2096	.1524	.1829
6	.0953	.1067	.1029	.1372	.2286	.1677	.1943
7	.0953	.1067	.1029		.2667	.1524	.2429
8	.1029	.0914	.1029		.2477	.1981	.2429
9	.12	.0762	.12	.1543	.2667	.2134	.2591
10	.12	.1143	.1334	.1677	.1296	.1334	.1677
11	.0857	.1334	.1143	.2134	.1457	.1715	.1372
12	.1219	.1905	.2096	.2134	.1457	.1715	.1372
13	.1219		.1905	.2134		.1715	.1524
14		.1715	.2096	.2134		.1715	.1524
15	.1524	.1905	.2096	.2286	.1029	.1715	.1524
16	.1372	.2096	.2667	.2286	.0914	.1715	.1524
17	.1372	.1524	.2058	.2858		.1543	.1334
18	.1372	.1524	.1886	.1524	.1067	.1543	.1334
19	.1372	.1524	.2477	.1524	.0914	.1372	.1715
20	.1372	.1372	.1372	.1524	.0914	.1372	.1715
21	.1067	.1372	.1372	.1524	.0762	.1372	.1715
22	.1067	.1372	.1372	.1524	.0762	.1372	.1715
23	.1067	.1219	.1372	.1334	.0762	.1372	.1715
24	.0857	.0914	.0857	.1372	.1905	.1372	.1781
Max	.1524	.2096	.2667	.2858	.2667	.2134	.2591
Min	.0857	.0762	.0857	.12	.0762	.1334	.1334
Avg	.1107	.1274	.1459	.17	.1601	.1553	.1728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 202 / 11 KV MUJABI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	2.4768	2.553	2.4768	2.4768	2.4577	2.4387
2	2.3815	2.3815	2.4958	2.4196	2.5149	1.9357	2.3815
3	2.3815	2.2862	2.4387	2.3815	2.4006	2.3053	2.3815
4	2.3053	2.1148	2.2291	2.3815	2.2862	2.21	2.2862
5	2.2481	2.0005	1.9814	2.2862	2.2672	2.0005	2.191
6	1.7147	1.7337	1.8099	1.8671	1.7337	1.387	1.7718
7	1.6385	1.5051	1.5813	1.6004	1.5623	1.448	1.4861
8	1.5623	1.5623	1.6004	1.467	1.5623	1.448	1.4861
9	1.5432	1.6194	1.6956	1.5051	1.6385	1.4289	1.4289
10	1.6385	1.7718	1.7909	1.7147	1.7147	1.448	1.2574
11	1.7337	1.8861	2.0195	1.8671	1.6004	1.6194	1.5051
12	2.0005	1.9624	2.191	1.9814	1.8861	1.6385	1.8861
13	2.191	2.0005	2.1529	2.2291	1.9052	1.7909	1.9624
14		2.1338	1.6194	2.2862		1.7528	1.9814
15	.8002	2.1148	1.6385	2.2291	1.4098	1.6385	1.9243
16	1.3336	2.0005	1.5242	2.1148	1.3908	1.7528	1.5813
17	1.7337	1.9624	1.3717	1.8671	1.5051	1.7147	1.448
18	1.5432	1.848	1.9624	1.7528	1.5432	1.5813	1.448
19	1.9814	1.9243	1.9624	2.0005	1.7147	1.7528	1.5432
20	2.1338	2.2862	2.3053	2.3434	2.0576	2.21	1.9814
21	2.5911	2.5339	2.5339	2.4768	2.2672	2.3434	2.1529
22	2.6101	2.7054	2.7054	2.572	2.4577	2.572	2.5339
23	2.572	2.6673	2.7054	2.6673	2.4768	2.4768	2.6101
24	2.3434	2.553	2.6101	2.4768	2.553	2.4768	2.4958
Max	2.6101	2.7054	2.7054	2.6673	2.553	2.572	2.6101
Min	.8002	1.5051	1.3717	1.467	1.3908	1.387	1.2574
Avg	1.9748	2.0846	2.0616	2.1235	1.9533	1.8912	1.9235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064020 / 33 KV MUJABI S/STN

Feeder No / Name : 203 / 11KV SATONA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.6287	.6287	.7049	.6478	.6097	.6287
2	.6668	.6097	.5716	.6859	.6097	.5716	.6287
3	.6668	.5716	.5144	.6859	.5716	.5525	.6097
4	.6668	.5525	.4763	.6668	.5335	.5144	.6097
5	.6287	.5144	.4382	.6097	.5525	.4763	.5716
6	.4191	.4572	.4001	.4572	.4001	.4572	.381
7	.381	.2858	.3239	.3239	.2858	.2667	.3239
8	.4001	.3429	.3239	.3429	.362	.3048	.4191
9	.2858	.362	.3429	.3429	.4572	.3048	.4954
10	.5525	.5144	1.5623	.4191	.5144	.4572	.4191
11	.4001	.5716	2.0195	.4954	.5144	.4954	.5335
12	.6287	.5525	1.9814	.5144	.5335	.5335	.5716
13	.5716	.6478	2.0195	.6478	.4763	.6097	.5525
14	.5716	.6287	1.8861	.6668		.5906	.4954
15	.0381	.5716	2.0767	.6097		.4763	.4191
16	.0762	.4572	1.8861	.5525		.5906	.3429
17	.0762	.4382	1.9814	.4382		.5144	.3239
18	.3048	.4001	.4191	.4001	.3429	.4382	.3429
19	.5335	.5906	.4763	.4763	.381	.5716	.5716
20	.6478	.5525	.6287	.5906	.6097	.5906	.5335
21	.6859	.7049	.6859	.5906	.6478	.6097	.6478
22	.6859	.7049	.724	.6668	.6668	.6478	.6859
23	.6859	.7049	.7049	.6478	.6478	.6668	.6287
24	.7049	.6668	.6859	.7049	.6478	.6287	.6478
Max	.7049	.7049	2.0767	.7049	.6668	.6668	.6859
Min	.0381	.2858	.3239	.3239	.2858	.2667	.3239
Avg	.4977	.5430	.9899	.5517	.5201	.5200	.516

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 201 / 11kv korambhi (GAOTHAON)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1849	2.2805	2.3167	2.0416	2.2207	2.1849	2.1719
2	2.1849	2.2443	2.3167	2.1132	2.2565	2.1132	2.1719
3	2.1491	2.1849	2.3167	2.1491	2.2207	2.0774	2.1357
4	2.0774	2.0595	2.2805	2.1491	2.1849	2.0058	2.0633
5	1.8267	1.9909	1.7737	1.949	1.97	1.8267	1.8983
6	1.4373	1.448	1.5402	1.4883	1.6301	1.382	1.5043
7	1.2346	1.3032	1.262	1.2003	.7202	1.1317	1.1568
8	1.3176	1.2071	1.2971	1.2209	1.0056	1.1317	1.1568
9	1.0517	1.2269	1.387	1.2346	1.2757	1.0974	
10	1.4022	1.2136	1.4373	1.3321	1.3032	1.1568	1.0288
11	1.4373	1.3672	1.5592	1.4373	1.643	1.283	1.0631
12	1.701	1.6301	1.6476	.1734	1.7878	1.4022	1.0974
13	1.7909	1.8073	1.0136	1.6827		1.4529	1.2894
14	2.0416	1.8781	1.1222	1.8427	1.406	1.4529	1.5402
15	1.6126	1.848	1.858	1.8427	.5144	1.2757	1.4529
16	1.2483	1.7718	1.701	1.6644	.7377	1.1694	1.0867
17	1.2071	1.5074	1.4529	.7282	.9835	1.1443	.9945
18	1.2407	1.4373	1.2483	.7545	1.0174	.8421	1.2269
19	1.3969	1.7909	1.5592	.8954	1.3112	1.4883	1.4327
20	1.9909	2.1582	2.2314	1.5364	1.9909	1.9845	1.9909
21	2.3167	2.4508	2.4143	1.6095	2.1719	2.3529	2.1491
22	2.4253	2.5339	1.9136	2.4874	2.2565	2.0814	2.2805
23	2.3282	2.4615	2.1491	2.364	2.2207	2.4253	2.2923
24	2.1971	.2572	2.3891	2.1132	2.2207	2.1849	2.3167
Max	2.4253	2.5339	2.4143	2.4874	2.2565	2.4253	2.3167
Min	1.0517	.2572	1.0136	.1734	.5144	.8421	.9945
Avg	1.7417	1.7524	1.7578	1.5838	1.6108	1.6103	1.6305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 203 / 11 KV Salebardi (AGP)

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2572	.3227	.5053
2					.2858	.3227	.5053
3					.2572	.3102	.5053
4					.2572	.3384	.5053
5					.2	.3384	.5647
6					.2027	.4512	.6241
7					.3715	.5281	.6923
8					.4054	.602	.7225
9					.4458	.6173	.6874
10				.4401			
11				.5182			
12	.3963	.463	.301	.3311			
13	.4816	.5376	.6325	.3395			
14	.4374	.5693	.6325	.3353			
15	.4374	.4012	.6401	.3395			
16	.4374	.5376	.7125	.4012			
17	.4858	.5937	.3963	.4268			
18	.4515	.6249	.759				
19	.4515	.6249	.6562				
20	.4214	.4572					
21	.4214	.4214					
22	.4214	.4214					
23	.4268	.4214					
24					.2743	.3227	.2743
Max	.4858	.6249	.759	.5182	.4458	.6173	.7225
Min	.3963	.4012	.301	.3311	.2	.3102	.2743
Avg	.4392	.5061	.5913	.3915	.2957	.4154	.5587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064029 / 33KV KARDHA

Feeder No / Name : 204 / 11 KV MIDC Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.415	.415	.415	.3734	.1334	.0743
2	.0514	.415	.415	.415	.3315	.1334	.0743
3	.06	.4527	.3772	.4066	.3315	.1257	.0663
4	.0514	.415	.3772	.415	.2934	.1219	.1036
5	.0869	.415	.415	.4191	.2054	.1353	.1097
6	.1265	.4527	.4191	.4572	.176	.1082	.1372
7	.0926	.415	.4527	.4527	.184	.1143	.1417
8	.2286	.5281	.4904	.5658	.2561	.1097	.104
9	.3395	.6413	.5658	.5975	.2164	.1638	.125
10	.5658	.7922	.5975	.6036	.3189	.2195	.0686
11	.6413	.679	.6413	.6859	.3292	.1082	.0492
12	.2263	.7468	.6722	.6413	.3856	.1036	.0655
13	.679	.5658	.679	.4954	.3052	.1113	.0625
14	.7842	.5975	.7167	.6097	.3155	.1619	.0625
15	.8299	.6036	.7167	.7545	.381	.1658	.0503
16	.6413	.6348	.6036	.6036	.2286	.3395	.088
17	.679	.6722	.6413	.5658	.3018	.1372	.0869
18		.6036	.6413	.5281	.1387	.0869	.0869
19	.4904	.5716	.6097	.5335	.2103	.0914	.0377
20	.4954	.4527	.415	.415	.1296	.0732	.04
21	.3696	.4954	.4527	.4527	.1467	.0762	.04
22	.4527	.4191	.4527	.415	.1486	.0732	.0377
23	.415	.3772	.4904	.4527	.1429	.1052	.0354
24	.0514	.415	.415	.415	.4572	.1334	.0899
Max	.8299	.7922	.7167	.7545	.4572	.3395	.1417
Min	.0514	.3772	.3772	.4066	.1296	.0732	.0354
Avg	.3656	.5323	.5280	.5132	.2628	.1305	.0766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 202 / 11 KV Rajola Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0149			
2				.0152			
3				.0151			
4				.0151			
5				.0301			
6			.013	.0452			
7		.0151	.0133	.0602			
8		.0457	.0267	.0602			
9		.032	.0452	.0983			
10	.0145	.0328	.0452		.16	.0151	.08
11	.0145	.0328	.0594		.048	.0301	.2134
12					.0655	.0452	.1858
13					.0492	.0452	.2572
14					.0655	.0716	.2572
15						.0753	.2572
16					.016	.0753	
17						.0452	
24	.6401			.0151			
Max	.6401	.0457	.0594	.0983	.16	.0753	.2572
Min	.0145	.0151	.013	.0149	.016	.0151	.08
Avg	.2230	.0317	.0338	.0369	.0674	.0504	.2085

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 203 / 11 KV Shahapur Feeder Gaathan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8839	1.701	1.848	1.7909	1.8671	1.6991	1.6476
2	1.9231	1.5947	1.7924	1.773	1.8484	1.6632	1.6297
3	1.8839	1.5769	1.7924	1.7193	1.7926	1.643	1.6297
4	1.829	1.2048	1.6991	1.6118	1.7737	1.587	1.576
5	1.6278	1.1871	1.6617	1.576	1.6804	1.5154	1.3969
6	1.262	1.2048	1.3256	1.2894	1.3817	1.419	1.1462
7	1.0791	1.0208	1.1763	1.1641	1.251	1.1016	1.1104
8	1.2986	.985	1.0164	1.0745	1.1128	1.0456	.9313
9	1.0867		1.0566	1.1576	1.1763	.9465	.985
10	1.0867	1.251	1.1283	1.307	1.2696	.9816	.985
11	1.1744	1.1949	1.3253	1.419	1.3676	1.0341	.0179
12	1.2971	1.363	1.4148	1.4415	1.5497	1.1744	1.3756
13	1.4548	1.4969	1.5223	1.587	1.2936	1.2357	1.3575
14	1.4563	1.531	2.2386	1.6991	1.0642		1.3937
15	.8589	1.5655	2.2386	1.6632	.8501	1.2894	1.3717
16	.9465	1.4937	2.0595	1.4784	1.0082	1.1999	1.2986
17	.9816	1.3256	1.8267	1.4523	1.0349	1.1283	1.0425
18	1.0341	1.226	1.3969	1.3443	1.1203	1.0745	1.0791
19	1.2445	1.587	1.3432	1.5684	1.2197	1.1999	1.262
20	1.4022	1.587	1.6476	1.7737	1.4969	1.4685	1.5729
21	1.5746	1.7177	1.773	1.905	1.6632	1.5402	1.6827
22	1.7556	1.9616	1.9521	1.9418	1.7551	1.6834	1.8656
23	1.7737	1.9231	1.9547	2.0182	1.7372	1.773	1.9204
24	1.8839	1.7364	1.9044	1.8088	1.9231	1.7177	1.773
Max	1.9231	1.9616	2.2386	2.0182	1.9231	1.773	1.9204
Min	.8589	.985	1.0164	1.0745	.8501	.9465	.0179
Avg	1.4083	1.4537	1.6289	1.5652	1.4266	1.3531	1.3355

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 205 / 11 KV Explosive - I Feeder HV Express Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3121	1.307	1.423	1.4003	1.307	1.1016	1.1389
2	1.3256	1.2136	1.363	1.251	1.3443	1.1088	1.1203
3	1.307	1.2323	1.3121	.8962	1.4377	1.2012	1.3256
4	1.2323	1.2883	1.3392	.9335	1.419	1.2323	1.307
5	1.0642	1.3256	1.3256	.7468	1.3817	1.0456	.9709
6	1.0269	1.3443	.9896	.7282	1.1643	.7842	.7468
7	.6468	.7468	.4527	.5788	.6653	.6099	.7282
8	.2829	.6161	.7655	.3174	.5228	.4481	.9709
9	.112	.2054	.8775	.4108	.8962	1.4937	1.1317
10	.3734	.1509	.8029		1.3443	1.0829	1.1317
11	.0373	.0747	.7655		1.1389	1.0642	.8488
12	.4108	.8029	.4108		1.5684	1.0642	.6224
13	.8215	.3174	.4481		1.5278	1.0642	.811
14	.8589	.4854	.6161		1.4415	.7282	.811
15	1.2696	.6979	.2801		1.2936	1.5684	.9431
16	.9149	.8589	1.5497		1.475	1.4003	1.1883
17	.9522	1.587	1.587		.961	1.2136	1.5278
18	1.251	1.5154	1.1763		.6535	.7282	1.4937
19	.8402	1.0269	.9522	.0229	.8131	.8775	1.6244
20	.9335	1.0374	.9896		.7468	.9896	1.7924
21	.9522	1.0642	.9896		.961	1.0269	1.6804
22	.9896	1.0269	1.0082	1.2308	1.0269	1.0456	1.6804
23	1.251	1.1763	1.2136	1.3443	1.0269	1.1763	1.6804
24	1.3256	1.3256	1.4563	1.4377	1.363	1.0456	1.1576
Max	1.3256	1.587	1.587	1.4377	1.5684	1.5684	1.7924
Min	.0373	.0747	.2801	.0229	.5228	.4481	.6224
Avg	.8955	.9345	1.0039	.8691	1.145	1.0459	1.1847

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 206 / 11 KV Bhandara Feeder AG Feeder with SDT
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0469	.112	.2187			
2	.061	.0469	.1294	.216			
3	.061	.0469	.1294	.2134			
4	.0457	.0469	.128	.2286			
5	.0457	.0469	.128	.2286			
6	.0463	.0469	.1966	.2439			
7	.1235	.0457	.213	.2896			
8	.0305	.2075	.3041	.3658			
9	.1981	.1311	.3048				
10	.2187	.547	.3048		.3315		.4287
11	.1875	.5898	.3048		.547		.5182
12					.5801		.5792
13					.426	.4572	.6249
14					.4862	.4572	.6249
15	.1524				.3812	.503	.6097
16	.1067				.3521	.5335	.5792
17	.1094				.3506	.5975	.6401
18	.1067						
19	.1094						
20	.2134						
21	.2031						
22	.1875						
24	.061	.1875	.112	.2134			
Max	.2187	.5898	.3048	.3658	.5801	.5975	.6401
Min	.0305	.0457	.112	.2134	.3315	.4572	.4287
Avg	.1164	.1658	.1972	.2464	.4318	.5097	.5756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 208 / 11 KV Explosive - II

HV Express Feeder

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.9808	.9522	1.226		1.1763	.6722
2	.2096	.811	.9149	1.094		1.1203	.6602
3	.1715	.8299	.8775	.9619		1.0642	.679
4	.1334	.8488	.924	.9242		.9709	.5658
5	.1143	.8488	1.0164	.3206		.9149	.679
6	.1143	.8676	.8029	.2075		.7762	.2075
7		.679	.4481			.6838	.1494
8		.9997	.7356			.5281	.2054
9		.6722	.8775			.8299	.0943
10	.0381	.6838	.7095	.3142		.7167	.0377
11	.0381	.8589	.6161	.2033		.679	
12		1.0642	.3206	.3174	.6036	.6979	
13		.7392	.3206	.5788	.6767	.2075	
14		.9896	.4527	.3174	1.0534	.811	
15	.6287	.961	.7733	.7392	1.0164	1.0829	
16	.9335	.7655	.9619	.8775	1.0829	.9522	.0377
17	.2096	1.1088	1.1694	.8962	1.0456	1.1203	.5281
18	.743	1.531	1.1317	.9896	.9896	1.0642	
19	1.0479	1.5154	1.0374	1.307	1.0642	1.0642	
20	.9717	1.587	1.0751	1.3817	1.1203	1.1016	
21	.9431	1.423	1.1317	1.2696	1.1203	1.0642	
22	.8865	1.1016	.8299		1.1763	.9896	
23	.9431	1.094	.8962		1.2696	.7655	
24	.2096	1.0374	1.0269	1.2826		1.2323	.7655
Max	1.0479	1.587	1.1694	1.3817	1.2696	1.2323	.7655
Min	.0381	.6722	.3206	.2033	.6036	.2075	.0377
Avg	.4748	.9999	.8334	.8005	1.0182	.9006	.4063

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 209 / 11 KV Awarmara Gaothan

Gaothan Feeder

Feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.543	.5788	.5731	.5788	.5788	.5611
2	.5731	.5487	.5729	.5731	.5729	.5847	.5611
3	.5731	.5611	.5729	.5975	.5788	.5601	.5611
4	.5373	.543	.5601	.5373	.5788	.5544	.543
5	.4656	.4525	.5601	.4477	.5601	.5228	.5068
6	.4119	.3982	.4108	.4298	.4481	.4338	.3801
7	.3403	.3475	.3734	.3439	.1867	.3395	.3439
8	.3224	.3077	.3734	.362	.3547	.3174	.3258
9	.394		.3761	.3361	.3547	.3077	.3292
10	.3761		.4477	.3772	.3547	.3582	.3475
11	.4119	.3326	.4477	.4668	.4805	.362	.0183
12	.4298	.3734	.4835	.5228	.4805	.4119	.439
13	.394	.4108	.5014	.5175	.3734	.4656	.4572
14	1.2787	.4904	.5014	.5359	.3174	.4477	.4755
15	.394	.0373	.4656	.4805	.2054	.394	.4572
16	.2149	.4066	.394	.4805	.1867	.3403	.3292
17	.2686	.3547	.362	.4481	.2427	.3224	.2926
18	.3403	.3511	.3982	.3734	.3174	.3045	.2743
19	.4298	.5788	.4163	.5658	.4108	.4119	.3841
20	.5373	.5788	.5973	.6535	.5041	.5611	.5487
21	.6036	.6161	.6516	.6348	.5975	.6154	.6219
22	.6219	.6908	.6335	.6099	.6161	.5973	.6036
23	.6036	.6283	.6154	.6161	.6161	.5792	.6036
24	.5853	.5611	.5975	.591	.5975	.5975	.5792
Max	1.2787	.6908	.6516	.6535	.6161	.6154	.6219
Min	.2149	.0373	.362	.3361	.1867	.3045	.0183
Avg	.4867	.4597	.4955	.5031	.4381	.4570	.4393

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station

Feeder No / Name : 401 / 33 KV SAINATH

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0672	.0509	.0952	.0887	.0728	.0952
2	.0887	.084	.0566	.0896	.084	.0832	.0896
3	.0832	.0952	.0566	.0896	.0896	.0887	.0672
4	.0537	.0896	.0672	.0672	.0784	.0943	.0616
5	.0554	.0784	.0721	.056	.0721	.0896	.0616
6	.0554	.0616	.0566	.0504	.0721	.0672	.0616
7	.0388	.0622	.0566	.0896	.0784	.0721	.0224
8	.0896	.0616	.0784	.084	.0554	.0728	.0336
9	.0952	.0622	.0784	.0896	.0504		.0566
10	.084	.028	.084	.0728	.061		.0566
11	.084	.0336	.084	.0784	.0672		.0566
12	.0784	.061	.0616	.0784	.056		.0509
13	.084	.056	.0509	.0616	.0566		.0453
14	.0336	.056	.0566	.0616	.0388		.0509
15	.0336	.0499	.0566	.0616	.0554	.0616	.0509
16	.0616	.0952	.0962	.0333	.0784	.0728	.0566
17	.0728	.1019	.0849	.028	.0776	.0616	.0453
18	.0056	.1008	.0672	.056	.0784	.056	.0283
19	.0112	.0784	.056	.0504	.084	.0336	.0622
20	.0112	.0504	.0336	.0509	.0784	.056	.056
21	.0113	.0336	.0504	.0504	.061	.056	.0616
22	.0113	.0336	.034	.0333	.0665	.0952	.0784
23	.0112	.0392	.0728	.0998	.0554	.0336	.056
24	.0943	.0616	.0448	.1008	.0952	.0672	.0728
Max	.0952	.1019	.0962	.1008	.0952	.0952	.0952
Min	.0056	.028	.0336	.028	.0388	.0336	.0224
Avg	.0559	.0642	.0628	.0679	.0700	.0686	.0574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 402 / 33 KV Gadegaon Feeder HV Non-Express Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	3.1607	2.1491	6.1054	5.036	7.6738	6.4415	6.6204
16	1.2243	.6401	9.3696	7.5257	6.5535	6.9456	6.677
24	1.1003	.6161	.3944	9.8583	8.802	7.8087	8.8838
Max	3.1607	2.1491	9.3696	9.8583	8.802	7.8087	8.8838
Min	1.1003	.6161	.3944	5.036	6.5535	6.4415	6.6204
Avg	1.8284	1.1351	5.2898	7.4733	7.6764	7.0653	7.3937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 403 / 33 KV Pahela Feeder

HV Express Feeder

INCOMER Feeder KV- 33 /

INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2071	1.2209	1.3146	1.4083	1.3289	1.0517	1.3003
16	1.0208	1.6118		1.773	1.5261	1.262	1.7164
24	1.8107	1.8804	1.9204	2.0302	1.9753	1.6804	1.7364
Max	1.8107	1.8804	1.9204	2.0302	1.9753	1.6804	1.7364
Min	1.0208	1.2209	1.3146	1.4083	1.3289	1.0517	1.3003
Avg	1.3462	1.5710	1.6175	1.7372	1.6101	1.3314	1.5844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 404 / 33 KV KarachKheda Feeder HV LIS Feeder
Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0034	.0079	.0056	.0003	.0005	.0005
16	.679	.0057	.0457	.0098	.0081	.0514
Max	.679	.0079	.0457	.0098	.0081	.0514
Min	.0034	.0057	.0056	.0003	.0005	.0005
Avg	.3412	.0068	.0257	.0051	.0043	.0260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 405 / 33KV SAHULI KARDHA INCOMER HV Group Express Feeder
Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.086	1.8484	1.8484	1.2883	.6099	.9145	.8316
16	1.5278	1.6975	2.0005	1.2757	2.037	2.1285	1.4563
24	1.4289	1.9239	2.037	2.5463	.8596	1.8861	1.6975
Max	1.5278	1.9239	2.037	2.5463	2.037	2.1285	1.6975
Min	1.086	1.6975	1.8484	1.2757	.6099	.9145	.8316
Avg	1.3476	1.8233	1.9620	1.7034	1.1688	1.6430	1.3285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION

Feeder No / Name : 406 / 33 KV TAKALI HV Group Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0048	.0062	.0068	.0058	.0051	.0062	.0055
10	.0048						
14		4.3347					
16	2.5252	3.7466	3.8146	4.0724	2.7401	2.9864	3.1493
23					.0051		
24	4.181	4.3347	4.5068	4.7188	4.6153	4.2896	4.181
Max	4.181	4.3347	4.5068	4.7188	4.6153	4.2896	4.181
Min	.0048	.0062	.0068	.0058	.0051	.0062	.0055
Avg	1.6790	3.1056	2.7761	2.9323	1.8414	2.4274	2.4453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 202 / 11 KV Sunflag Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1372	.1886	.2229			
2	.12	.1543	.1715	.2229			
3	.1372	.1543	.1715	.2229			
4	.1543	.1543	.1886	.2401			
5	.1715	.1715	.2058	.3086			
6	.1715	.1715	.2915	.3772			
7	.1715	.1543	.3258	.3772			
8	.2743	.2058	.4115	.4115			
9	.2572	.2058	.4287	.3944			
10	.2915	.3429	.4458		.3944	.4115	.3944
11	.3086	.7442	.4458		.5487	.5316	.6001
12		.415			.5658	.6173	.4973
13		.3601			.6344	.6173	.5658
15						.583	.6173
16						.5658	.1132
17					.2229	.6001	.5487
24	.1029	.1372	.2058	.2401			
Max	.3086	.7442	.4458	.4115	.6344	.6173	.6173
Min	.1029	.1372	.1715	.2229	.2229	.4115	.1132
Avg	.1900	.2506	.2901	.3018	.4732	.5609	.4767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 203 / 11 KV DABHA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.6413	.6413	.6602	.6602	.6413	.6036
2	.6036	.6036	.6036	.6224	.6224	.6036	.6036
3	.5658	.5658	.6036	.5847	.6224	.5658	.5847
4	.5281	.5658	.5658	.5658	.6036	.5281	.5658
5	.4904	.4904	.5281	.547	.5281	.5281	.547
6	.4527	.4338	.4715	.3961	.4904	.415	.4338
7	.2829	.3584	.4338	.3772	.4527	.3772	.3395
8	.3018	.3018	.3395	.2075	.3584	.3395	.2641
9	.3772	.3584	.3772	.2263	.3206	.3395	.3772
10	.3961	.3395	.3961	.3018	.3961	.2641	.3772
11	.3772	.3584	.3961		.4715	.3018	.415
12	.4527	.3961	.4527	.5093	.5281	.3961	.4715
13	.5093	.4527	.5093	.5658	.5281	.3584	1.1506
14		.4715	.547	.6036			.5093
15	.2829	.4338	.4715	.5658		.3395	.415
16	.3206	.3961	.4338	.4715	.1698	.3206	.132
17	.3018	.3584	.3772	.4338	.3961	.3018	.3584
18	.3584	.415	.3018	.4715	.4338	.3395	.3395
19	.4338	.4904	.3961	.547	.5093	.5093	.4338
20	.6036	.547	.5847	.7356	.5847	.5847	.4715
21	.679	.679	.6602	.7545	.6602	.6413	.6413
22	.6979	.7545	.679	.7545	.7545	.6602	.6979
23	.679	.679	.6602	.7545	.679	.679	.6979
24	.6602	.679	.6602	.679	.679	.6602	.6224
Max	.6979	.7545	.679	.7545	.7545	.679	1.1506
Min	.2829	.3018	.3018	.2075	.1698	.2641	.132
Avg	.4781	.4904	.5038	.5363	.5204	.4650	.5022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384]

BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 205 / Sahakar Nagar Feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2263	.2263	.2641	.2452	.2263	.2263
2	.1886	.2263	.2075	.2263	.2452	.2075	.2075
3	.1886	.2075	.1886	.2075	.2263	.1886	.1886
4	.1698	.1886	.1886	.1886	.2263	.1886	.1886
5	.1509	.1698	.1698	.2075	.2452	.1698	.2263
6	.1509	.1509	.1698	.2452	.2452	.1509	.3206
7	.1509	.1509	.1698	.1886	.3018	.1698	.3206
8	.1509	.1509	.1698	.1698	.2829	.1698	.3018
9	.3395	.3584	.3772	.3395	.3772	.3395	.3206
10	.3584	.3772	.4527	.3584	.4338	.3584	.3395
11	.415	.415	.4904	.4338	.4715	.415	.3961
12	.4527	.4715	.4527	.4527	.4715	.415	.3772
13	.4904	.4715	.415	.4904	.4715	.4338	.4338
14	.4527	.5281	.4715	.5281		.415	.3961
15	.415	.4338	.4527	.4527		.4338	.3772
16	.3961	.4715	.415	.415	.0566	.4527	.1886
17	.3584	.3772	.3772	.3961	.2829	.3772	.3584
18	.3395	.3772	.3772	.3584	.3018	.3206	.3584
19	.3395	.3206	.3206	.2452	.2829	.3018	.3206
20	.3395	.3206	.3018	.2263	.2641	.3206	.3018
21	.3206	.3206	.3395	.2263	.2641	.3395	.3018
22	.3206	.2452	.3395	.2641	.3395	.3206	.3395
23	.2641	.2263	.3395	.2452	.3584	.3206	.3206
24	.2263	.2452	.2452	.2641	.2641	.2452	.2263
Max	.4904	.5281	.4904	.5281	.4715	.4527	.4338
Min	.1509	.1509	.1698	.1698	.0566	.1509	.1886
Avg	.2994	.3096	.3191	.3081	.3026	.3034	.3057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 206 / 11 KV MMKD Feeder

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.6221	1.4712	1.5466	1.5278	1.6975	1.5466
2	1.773	1.5844	1.4523	1.6221	1.5844	1.6975	1.4712
3	1.6975	1.5278	1.3957	1.5089	1.5278	1.6598	1.5844
4	1.6221	1.5466	1.358	1.4712	1.4901	1.5844	1.5278
5	1.5089	1.4335	1.3203	1.4146	1.4712	1.5466	1.5466
6	1.3957	1.3957	1.226	1.4335	1.4712	1.5089	1.4146
7	1.4523	1.358	1.1694	1.4335	1.5655	1.5655	1.5278
8	1.4523	1.3203	1.1883	1.3014	1.4523	1.4712	1.4712
9	.5281	1.4523		1.226	1.4146	1.6221	1.4712
10	.679	1.1506		1.3203	1.1883	1.3203	.9431
11	.679	1.3203		1.4146	1.4335	1.4335	1.0751
12	1.358	1.2826		1.3957	1.3769	1.5844	1.0562
13	1.2071	1.3203		1.2449	1.3203	1.5089	1.1506
14	1.2071	1.226		1.3203			.9997
15	1.3014	1.1506		1.4712		1.3392	.9997
16	1.4901	1.3203		1.4146		1.3769	1.0562
17	1.4901	1.094		1.4523	1.0185	1.4712	.9997
18	1.5844	1.3957	1.4523	1.4901	1.3203	1.3203	1.1694
19	1.3203	1.4712	1.3392	1.4712	1.2637	1.1506	1.2826
20	1.4335	1.4523	1.4901	1.5278	1.4901	1.2449	1.3392
21	1.2826	1.3769	1.3769	1.4712	1.4901	1.226	1.3769
22	1.5655	1.4901	1.3769	1.5466	1.6221	1.6787	1.6032
23	1.6221	1.5655	1.5655	1.5655	1.6975	1.5844	1.6409
24	1.8296	1.6409	1.4712	1.5655	1.4523	1.6598	1.6221
Max	1.8296	1.6409	1.5655	1.6221	1.6975	1.6975	1.6409
Min	.5281	1.094	1.1694	1.226	1.0185	1.1506	.9431
Avg	1.3871	1.3958	1.3769	1.4429	1.4371	1.4892	1.3282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 401 / 33KV BHANDARA

HV Group Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4136	4.0175	4.9794	5.2624	4.9794	4.5268	4.5833
2	3.9609	4.4136	4.8097	3.3385	4.8663	4.0741	4.4702
3	3.7346	4.2438	4.5268	4.7531	4.6399	3.8477	4.3004
4	3.5082	4.0741	4.0741	4.3004	4.4702	3.6214	3.8477
5	3.2819	3.8477	3.8477	3.8477	4.4136	3.3951	3.5648
6	3.1687	3.2253	3.5082	3.5648	3.7346	3.2253	3.2253
7	.0566	.0566	2.999	3.1121		2.8292	
8	3.2253	.7922	.0566		.0566	.0566	2.3765
9	2.8292	1.0185	3.3951	3.2819	3.5648	2.8292	2.6029
10	2.7726	2.8292	3.3951	3.2819	3.4517	2.6595	2.4897
11	2.8292	3.2253	3.4517	3.3951	3.2819	2.7726	2.6029
12	3.1121	3.3951	3.4517	3.7912	3.8477	2.7161	1.8107
13	3.4517	3.4517	4.1872	4.0741	4.0175	2.9424	3.1687
14	3.7912	4.0741	4.1872	4.5833			3.5082
15	3.0556	4.1872	4.5833	4.9228	2.999	3.1121	3.2819
16	2.7726		4.3004	4.9228	2.7161	2.9424	2.999
17	2.6595	3.6214	3.8477	4.2438	2.7726	2.7726	2.4897
18	2.4897	3.083	3.2253	3.3951	2.7726	2.6595	2.3765
19	2.6595	3.3385	3.5648	3.8477	2.9424	2.9424	2.6029
20	3.5082	3.678	3.8477	4.1872	3.5648	3.5082	3.3951
21	3.678	3.9609	4.4136	4.357	3.8477	3.5082	3.6214
22	4.3004	4.1872	4.6965	4.6965	4.4136	4.1307	4.357
23	4.9794	5.2058	5.4887	5.4321	4.9228	4.7531	4.8663
24	4.6399	4.9228	5.0926	5.3755	5.3189	4.8097	4.6399
Max	4.9794	5.2058	5.4887	5.4321	5.3189	4.8097	4.8663
Min	.0566	.0566	.0566	3.1121	.0566	.0566	1.8107
Avg	3.2866	3.4282	3.9138	4.1725	3.7089	3.2450	3.3557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 402 / 33KV Mohadi

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6214	3.1687	3.1687	3.7346	3.9043	3.3951	2.9424
2	3.5082	2.999	3.0556	3.7346	3.8477	3.2819	3.0556
3	3.2819	2.8858	2.9424	3.678	3.678	2.9424	3.1121
4	2.7161	2.7161	2.8292	3.5082	3.6214	2.7161	3.1121
5	2.2634	2.6029	2.6029	3.2819	3.5082	2.4897	3.1687
6	2.037	2.2068	2.3765	3.0556	2.8858	2.32	1.9239
7	.5658	.6224	.8488	2.037	2.4897	1.6409	1.0751
8	1.2449	1.1317	1.6409	2.3765	2.8858	1.8107	1.1317
9	1.2449	1.1317	1.4146	2.3765	3.0556	2.2634	1.8107
10	1.1883	1.4146	1.7541	2.2068	2.2634	1.9805	2.1502
11	2.2068	1.5278	1.9805	2.3765	2.7161	2.2068	2.6029
12	2.9424	2.9424	3.3951	2.6595	3.0556	1.5844	2.7726
13	3.1687	3.2253	3.3951	2.9424	3.3385	2.037	3.2253
14	2.6595	3.2253	3.6214	3.3385			2.999
15	2.1502	3.0556	3.5648	3.2253	1.0751	2.1502	2.5463
16	2.2068	3.0556	3.2819	2.3765	3.0556	1.8107	2.2634
17	2.037	2.4331	2.8858	1.9239	1.5278	1.7541	2.2634
18	1.9805	2.7161	2.6029	1.9239	1.358	1.6409	1.6975
19	2.32	2.6595	2.8858	1.9239	2.1502	2.3765	1.9805
20	2.8858	3.2819	2.8858	3.2819	1.9805	2.6029	2.4897
21	3.2253	3.3951	3.7912	3.678	3.5648	2.7726	3.4517
22	3.3385	3.7346	3.8477	3.7346	2.9424	2.999	3.5648
23	3.3385	3.5648	2.4331	4.1307	3.6214	3.6214	3.7912
24	6.7472	3.4517	3.3385	3.8477	4.0741	3.5648	2.999
Max	6.7472	3.7346	3.8477	4.1307	4.0741	3.6214	3.7912
Min	.5658	.6224	.8488	1.9239	1.0751	1.5844	1.0751
Avg	2.6200	2.6312	2.7726	2.9730	2.8957	2.4331	2.5887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 403 / 33 KV MUJABI

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0556	3.2819	3.2819	3.2819	3.4517	2.7161	3.3951
2	2.8292	3.1687	3.0556	3.0556	3.2819	2.6595	3.2253
3	2.7161	3.1687	2.9424	2.7726	3.2819	2.6029	3.1121
4	2.4897	2.9424	2.8292	2.7161	3.1687	2.4897	3.0556
5	2.3765	2.7726	2.6029	2.6029	2.9424	2.3765	2.6595
6	2.2068	2.4331	2.4331	2.4331	2.6029	2.32	2.037
7	1.9239	1.8673	1.9239	1.9805	2.2068	1.9239	1.7541
8	2.037	2.0936	1.9805	1.9805	1.8107	1.6975	2.1502
9	2.037	2.0936	2.1502	1.9805	2.4331	3.1121	2.2068
10	2.2634	2.32	3.2253	2.32	2.3765	1.9239	2.1502
11	2.2068	2.4331	3.9043	4.2438	2.2068	2.0936	2.4897
12	2.8292	2.8292	4.1307	2.7726	2.8292	2.2634	2.3765
13	2.8858		3.9043	2.8858	1.8107	2.4331	2.6595
14		2.9424	2.037	3.2819			2.6029
15	.679	2.999	3.8477	3.1687	1.358	2.32	2.4331
16	1.7541	2.7161	3.6214	3.0556	1.4712	.6224	2.037
17	1.9239		3.2819	3.1121	1.5844	2.32	1.9239
18	2.0936	2.4897	2.3765	2.2068	1.358	1.9805	1.8673
19	2.3765	2.7161	2.7161	2.2068	2.2068	2.5463	1.9805
20	2.9424	3.1687	3.2253	3.1687	2.7161	2.6595	2.6029
21	3.2253	3.4517	3.3951	3.3385	2.999	2.7726	2.8858
22	3.4517	3.7346	3.678	3.4517	3.1687	2.999	3.2819
23	3.5082	3.678	3.3951	3.5082	2.999	3.2819	3.4517
24	3.7957	3.4517	3.5082	3.5082	7.1656	2.8292	3.5082
Max	3.7957	3.7346	4.1307	4.2438	7.1656	3.2819	3.5082
Min	.679	1.8673	1.9239	1.9805	1.358	.6224	1.7541
Avg	2.5047	2.8524	3.0603	2.8764	2.6709	2.3889	2.5770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA S/DN.[384] BU 0384

Substation No/ Name :- 068015 / 220 KV BHANDARA S/S

Feeder No / Name : 802 / 220 KV SUNFLAG

EHV Express Feeder

Feeder KV- 220 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	19.9932	23.7655	29.3401	23.011	41.9144	37.723	21.8793
2	18.671	20.3704	22.2565		20.9115	22.6338	23.7655
3	18.671	28.6694	36.5913	28.2922	21.1249	21.1249	22.6338
4	18.671	27.915	22.6338	19.6159	19.6159	29.3401	24.0055
5	17.1468	25.2744	38.1002	44.8903	21.5021	22.6338	22.8624
6	11.6941	26.8862	27.2596	22.4814	35.8482	26.2918	23.3882
7	10.8596	35.9511	21.1249	44.5245	18.8615	21.1249	40.9694
8	16.8039	26.2232	25.1486	21.5021	19.9932	31.8549	23.7655
9	15.3102	23.7655	22.6338	36.9685	19.9932	25.0191	30.9938
10	17.3526	18.8615	22.6338	26.0288	24.1427	22.2565	38.4088
11	16.9753	21.7193	21.5021	23.7655	22.2565	23.7655	38.1002
12	17.9089	26.7833	21.8793	26.0288	21.5021	21.8793	19.052
13	19.052	24.1427	22.6795	46.3992	25.9107	22.8624	17.5278
14	19.6159	23.3882	27.4349	19.6159	18.671		23.3882
15	18.8615	32.3884	25.6516	23.3882	25.1334	32.819	22.2565
16	18.4843	21.5021	25.6516	19.2387	22.4814	29.8011	24.1427
17	18.8615	36.5913	25.2744	20.7476	19.8141	34.385	33.9126
18	18.4843	36.5913	18.8615	21.5021	22.2565	23.3882	25.8726
19	18.8615	33.9507	22.1003	29.0467	20.9572	25.5297	25.0191
20	19.2387	21.8793	41.4953	28.2922	22.6338	27.1605	28.6694
21	19.433	22.6338	26.0288	24.1427	22.1003	28.959	23.011
22	20.3704	23.011	39.1404	29.4239	23.3882	21.8793	23.011
23	19.9932	20.7476	38.485	41.9144	31.6263	26.7833	25.2744
24	21.8793	20.3704	22.7786	41.4953	21.6583	33.5734	23.011
Max	21.8793	36.5913	41.4953	46.3992	41.9144	37.723	40.9694
Min	10.8596	18.8615	18.8615	19.2387	18.671	21.1249	17.5278
Avg	18.0497	25.9742	26.9452	28.7963	23.5124	26.6430	26.0384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 201 / 11 KV Ambedkar ward

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.6097	.6097	.6668	.6287	.6097	.5716
2	.6036	.5716	.5335	.6097	.6287	.5335	.5525
3	.6097	.5716	.5335	.6097	.6097	.5335	.5525
4	.5716	.5335	.5335	.5716	.6097	.5335	.5335
5	.5525	.5335	.5335	.5906	.5716	.5144	.5335
6	.5525	.5335	.5335	.5716	.5335	.5144	.5335
7	.5335		.5144	.5525	.5335	.5144	.5335
9	.5093	.5144	.5335	.381	.5144	.5144	.5093
10	.4904	.4954	.5144	.5144	.5144	.4954	.5093
11	.4854	.5144	.5144	.5144	.4954	.4954	.4854
12	.4904	.5144	.5144	.5335	.5144	.5144	.4854
13	.4904	.5144	.5335	.5525	.5144	.5144	.4854
14	.4854	.4954	.5525	.5525		.4954	.5041
15	.4854	.5335	.5525	.5716	.4954	.5144	.5041
16	.4904	.5525	.5716	.5906	.4954	.5144	.4854
17	.4904	.5335	.5281	.5525	.4954	.5144	.4954
18	.4904	.5335	.5144	.5144	.4954	.5144	.4954
19	.4715	.5144	.5144	.5335	.5144	.5335	.4954
20	.5093	.5335	.5335	.5525	.5335	.5335	.5144
21	.547	.5716	.5335	.6097	.5335	.5525	.5335
22	.5906	.6097	.5906	.5906	.5716	.5525	.5525
23	.6097	.6287	.6668	.6287	.5716	.5906	.5906
24	.6287	.6036	.6668	.6668	.6478	.6287	.5716
Max	.6287	.6287	.6668	.6668	.6478	.6287	.5906
Min	.4715	.4954	.5144	.381	.4954	.4954	.4854
Avg	.5352	.5462	.5490	.5666	.5465	.5318	.5229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 202 / 11KV Sahakar Nagar Urban/Sheddable Urban Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.452	2.652	2.8645	3.1436	3.315	2.9531	2.7435
2	2.6595	2.5606	2.7721	3.0483	3.2388	2.8578	2.6292
3	2.4331	2.5606	2.4949	2.8578	3.0864	2.6406	2.4768
4	2.3011	2.4691	2.4025	2.6673	2.934	2.6406	2.3243
5	2.1691	2.1948	2.1719	2.5911	2.572	2.2634	2.1338
6	1.9993	1.9022	1.9004	2.2862	2.3624	1.848	1.9433
7	1.6975		1.7002	1.9243	2.191	1.848	1.8099
9	1.7551		2.3624	2.1338	2.3765	1.9243	1.643
10	1.7551	1.8107	2.3434	2.1719	2.2445	1.7909	1.643
11	1.7737	1.9433	1.9052	2.2862	2.1125	1.7528	1.6804
12	1.9418	2.0957	2.2862	2.4006	2.3577	1.7909	.8488
13	2.0538	2.4768	2.553	2.553	2.6972	2.0005	1.8671
14	2.3152	2.553	2.7054	2.8578		2.1338	2.2731
15	2.0538	2.6292	2.934	3.315	2.1313	2.1719	2.1658
16	1.6817	2.553	2.6292	3.2769	1.8673	2.0576	1.8858
17	1.6787	2.2634	2.3525	2.7435	1.9433	1.848	1.6975
18	1.6032	2.0182	1.9805	2.2481	1.9243	1.9433	1.5655
19	1.6598	2.0182	2.838	2.4768	1.9814	2.0576	1.905
20	2.0748	2.2257	2.4025	2.7435	2.3243	2.1719	2.1879
21	2.1719	2.3577	2.6139	2.8578	2.4387	2.4768	2.3388
22	2.6292	2.7538	2.838	3.0293	2.915	2.7054	2.7915
23	2.9531	3.0556	3.2156	3.4103	3.0674	2.934	3.0556
24	2.7538	2.8006	3.0293	3.1554	3.3722	3.0293	2.8578
Max	2.9531	3.0556	3.2156	3.4103	3.3722	3.0293	3.0556
Min	1.6032	1.8107	1.7002	1.9243	1.8673	1.7528	.8488
Avg	2.1116	2.3759	2.4911	2.7034	2.5206	2.2539	2.1073

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 204 / 11 KV Kham Talao (Takiya Urban/Sheddable Urban Feeder
Ward) Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.985	.9877	1.086	1.1104	1.1104	1.0269	.8954
2	.9492	.9511	1.0498	1.0745	1.1104	.9896	.8596
3	.9134	.9145	.9955	.985	1.0387	.9335	.8238
4	.8417	.823	.8145	.8954	1.0387	.8316	.7522
5	.788	.7316	.724	.9492	.9313	.7392	.7164
6	.6984	.7316	.724	.8059	.788	.7392	.6447
7	.6268	.7316	.6335	.6805	.6984	.6348	.6268
9	.6722	.6584	.6908	.6089	.6984	.5731	.5975
10	.6722	.6767	.6089	.5731	.7164	.5731	
11	.6722	.6805	.7164	.6805	.8059	.6089	.6908
12	.8029	.6984	.8238	.7522	.8775	.6447	.7207
13	.811	.8238	.9313	.8238	.9134	.6805	.8686
14	.3547	.9313	.9671	.8596		.7343	.8775
15	.3395	.9671	1.0029	.9671	.7164	.788	.8501
16	.3018	.9313	.9134	.9671	.7343	.6805	.7947
17	.7545		.8596	.8954	.7922	.6805	.7164
18	.7733	.8059	.7701	.7701	.6979	.7164	.6447
19	.7733	.8059	.8238	.8238	.811	.7522	.7343
20	.8865	.8596	.8775	.8954	.8676	.788	.8238
21	.8865	.8775	.9313	.9671	.9054	.8954	.8417
22	.9997	1.0029	1.0387	.985	1.0269	.9671	.9492
23	1.1128	1.1104	1.1641	1.1283	1.1128	1.0029	1.0566
24	1.0029	1.0456	1.134	1.1641	1.1462	1.0829	.9671
Max	1.1128	1.1104	1.1641	1.1641	1.1462	1.0829	1.0566
Min	.3018	.6584	.6089	.5731	.6979	.5731	.5975
Avg	.7660	.8521	.8818	.8853	.8881	.7854	.7933

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 205 / 11 KV Nashik Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5606	2.7073	2.7435	2.8349	2.7435	2.7625	2.5606
2	2.524	2.6139	2.652	2.7435	2.5606	2.6673	2.4143
3	2.4326	2.4272	2.5606	2.5606	2.4691	2.572	2.2862
4	2.3045	2.2405	2.2405	2.5606	2.2862	2.2862	2.1033
5	2.1765	2.0538	2.0538	2.524	2.1033	2.0957	1.829
6	1.829	1.9605	1.829	2.1948	2.0119	1.8099	1.6827
7	1.4998		1.6827	1.701	1.701	1.5813	1.5181
9	1.7177	1.8111	1.8111	1.7558	1.7741	1.5623	1.4415
10	1.7737	1.848	1.8656	1.7193	1.8839	1.4998	
11	1.848	1.9022	2.1582	1.9753	2.1216	1.6032	1.7364
12	2.0936	1.9753	2.2862		2.2862	1.6787	
13	2.1125	2.1948	2.4143	2.3777	2.2862	1.8861	2.0328
14	2.452	2.4143	2.4874	2.5423		1.9616	2.2731
15	2.2634	2.4508	2.5423	2.6337	1.701	2.0576	2.1948
16	1.9616	2.3102	2.2131	2.5606	1.7193	1.9052	1.9978
17	1.8296	2.1033	2.1765	2.2862	1.7364	1.8099	1.7193
18	1.7918	1.9204	1.9753	1.9387	1.5844	1.8671	1.5729
19	1.7918	2.1948	2.1033	2.1948	1.9978	1.9814	1.829
20	2.2257	2.3228	2.4508	2.3777	2.2592	2.1529	2.1216
21		2.5057	2.5968	2.4874	2.3525	2.3777	2.2497
22	2.5393	2.7252	2.7984	2.6155	2.7633	2.5606	2.4874
23	2.9424	2.9447	2.963	2.8532	2.7633	2.6703	2.7252
24	2.6703	2.8006	2.8349	2.9081	2.8532	2.7349	2.6337
Max	2.9424	2.9447	2.963	2.9081	2.8532	2.7625	2.7252
Min	1.4998	1.8111	1.6827	1.701	1.5844	1.4998	1.4415
Avg	2.1518	2.2922	2.3234	2.3794	2.1799	2.0906	2.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

BHANDARA URBAN S/DN[381] BU 1929

Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN

Feeder No / Name : 206 / 11KV Station Road

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5914	.5914	.6602	.6348	.6097	.5601
2	.5304	.5544	.5544	.6097	.6348	.5716	.5601
3	.5121	.5544	.5544	.6097	.5975	.4668	.5228
4	.4805	.462	.462	.5335	.5975	.4763	.4854
5	.4435	.3696	.462	.5525	.5228	.4763	.4481
6	.3511	.2298	.3658	.4763	.4481	.381	.3734
7	.2743		.3142	.362	.3734	.3239	.3361
9	.3772	.3696	.3921	.362	.415	.3239	.2641
10	.3772	.3696	.3734	.381	.4024	.3174	
11	.3772	.4108	.4294	.4191	.4755	.362	.2987
12	.4338	.4294	.4854	.4572	.462	.3429	
13	.4527	.4854	.5228	.5335	.462	.381	
14	.5281	.5121	.5228	.5906		.4382	
15	.4715	.5041	.5601	.6097	.3142	.4572	
16	.3961	.4854	.5228	.5906	.3142	.381	.4338
17	.3206	.4251	.4481	.4854	.3361	.362	.3511
18	.3395	.3511	.3547	.3921	.2987	.381	.2957
19	.3361	.4251	.3921	.4481	.3547	.4191	.3511
20	.4668	.462	.5041	.5041	.4854	.4763	.4435
21	.5415	.5359	.5601	.5228	.5041	.5716	.5175
22	.6036	.6468	.6348	.5788	.5788	.6097	.5729
23	.6413	.6468	.6908	.6722	.6602	.6287	.6283
24	.567	.6036	.6348	.6668	.6535	.6478	.5975
Max	.6413	.6468	.6908	.6722	.6602	.6478	.6283
Min	.2743	.2298	.3142	.362	.2987	.3174	.2641
Avg	.4512	.4738	.4927	.5225	.4784	.4524	.4467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 201 / 11 KV Jamb Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.7802	.8413	.7888	.7716	.7133	.7202
2	.7282	.7802	.8413	.7888	.7716	.7059	.7202
3	.7362	.7362	.8413	.7888	.7716	.7133	.6935
4	.7362	.7362	.7682	.7712	.7545	.7133	.6935
5	.6556	.7087	.695	.7011	.7628	.6335	.6661
6	.4656	.5014	.4887	.5138	.5434	.4163	.443
7	.4163	.4163	.4477	.4252	.5138	.4207	.4075
8	.4344	.4525	.4298	.4252	.4961	.3982	.4075
9	.4525	.4656	.5014	.443	.5194	.3898	.4207
10	.4525	.443	.4382	.4252	.5194	.4887	.4557
11	.5194	.5373	.4908	.443	.5792	.4477	.4733
12	.5493	.5731	.0561	.5895	.7316	.4656	.4908
13	.6201	.6878	.6485	.6588	.6878	.4961	.5434
14	.6733	.6516	.6661	.6762			.4733
15	.4835	.6335	.5784	.6516		.5316	.4382
16	.4835	.5552	.5258	.4733	.0686	.4119	.3506
17	.5014	.4961	.4207	.4252	.3012	.4163	.3856
18	.4525	.4477	.4382	.4252	.2804	.4163	.3506
19	.5847	.543	.5959	.5316	.362	.6024	.4908
20	.6201	.695	.7537	.6859	.6584	.6588	.6485
21	.7282	.8501	.8328	.763	.7207	.6935	.7186
22	.7888	.8871	.8954	.8048	.7577	.7628	.7888
23	.7716	.8596	.8596	.779	.7392	.7628	.7712
24	.7455	.7802	.8413	.8063	.7716	.7133	.7373
Max	.7888	.8871	.8954	.8063	.7716	.7628	.7888
Min	.4163	.4163	.0561	.4252	.0686	.3898	.3506
Avg	.5970	.6341	.6207	.6160	.5947	.5640	.5537

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 202 / 11 KV Andhalgaon Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8417	.8059	.8501	.8596	.8573	.7545	.8059
2	.8417	.7888	.8501	.8596	.8495	.7545	.8059
3	.8417	.7888	.8501	.8596	.8495	.7628	.7975
4	.8059	.7455	.8316	.8596	.8238	.7628	.7802
5	.6984	.7011	.7682	.7343	.7619	.6485	.7537
6	.4887	.4656	.5249	.5373	.4961	.5258	.4784
7	.4298	.4119	.4477	.4298	.4119	.4163	.4252
8	.4298	.3801	.4477	.4119	.4119	.3801	.394
9	.4607	.3982	.4656	.4344	.4835	.3801	.3801
10	.5316	.443	.5014	.4344	.5194	.3982	.5068
11	.5493	.5194	.5552	.5014	.5792	.4298	.5249
12	.6135	.6335	.6268	.6201	.7421	.4607	.6268
13	.7108	.7316	.7164	.7712	.7602	.4835	.6626
14	.5847	.7059	.7343	.7712		.5138	.5973
15	.4656	.6697	.6447	.703		.4656	.5194
16	.4163	.5611	.4835	.5434		.443	.4298
17	.3801	.4835	.4656	.4961	.0358	.4525	.2353
18	.4163	.3721	.4298	.4607	.362	.4887	.394
19	.5552	.543	.6268	.6241	.5014	.5138	.5249
20	.6485	.7392	.8059	.7455	.7316	.6762	.7343
21	.7888	.8871	.9231	.8573	.8029	.7373	.8145
22	.8495	.9522	.9412	.905	.8589	.8402	.905
23	.8322	.9055	.9231	.8916	.8316	.823	.8954
24	.8596	.8059	.8871	.8775	.8573	.7545	.823
Max	.8596	.9522	.9412	.905	.8589	.8402	.905
Min	.3801	.3721	.4298	.4119	.0358	.3801	.2353
Avg	.6267	.6433	.6792	.6745	.6442	.5778	.6173

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 203 / 11 KV Dhop Gaothan Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2401	.2801	.2587	.2572	.2534	.2229
2	.2587	.2401	.2772	.2587	.2401	.2587	.2229
3	.2587	.2401	.2801	.2587	.2572	.2587	.2229
4	.2587	.2254	.2587	.2587	.2572	.2587	.2254
5	.2427	.2254	.2218	.2402	.2427	.2195	.2254
6	.1494	.1595	.1629	.1663	.1772	.1629	.1595
7	.1494	.1417	.1075	.112	.1086	.1448	.2103
8	.1294	.1086	.1075	.1307	.1433	.1267	.1063
9	.124	.1086	.1063	.1063	.1448		.1307
10	.1307	.1254	.1478	.124	.1448		.1307
11	.1417	.1629	.1663	.124	.1646	.1063	.1494
12	.1254	.2012	.1663	.1753	.2218	.1063	.1494
13	.1928	.2172	.2218	.2254	.2427	.1254	.168
14	.1907	.2378	.2218	.2254		.1254	.1663
15	.124	.1991	.1663	.1949		.124	.1307
16	.1086	.1433	.1109	.1227	.0895	.124	.112
17	.1086	.1063	.1109	.1254	.0701	.124	.112
18	.1254	.0716	.1109	.1086	.0876	.1075	.112
19	.1753	.1629	.2427	.1907	.1753	.1772	.168
20	.2303	.2587	.2801	.2454	.2561	.2229	.2427
21	.2601	.3174	.3174	.2915	.2641	.2229	.2957
22	.2629	.2987	.2926	.2915	.2641	.2572	.2957
23	.2601	.2801	.2926	.2774	.2641	.2427	.2801
24	.2587	.2401	.2801	.2801	.2572	.2534	.2279
Max	.2629	.3174	.3174	.2915	.2641	.2587	.2957
Min	.1086	.0716	.1063	.1063	.0701	.1063	.1063
Avg	.1885	.1963	.2054	.1997	.1968	.1819	.1861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 204 / 11kv JAMB AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.2372	.2294	.381			
2	.1677	.2372	.2267	.381			
3	.1677	.2372	.2267	.381			
4	.176	.2343	.2267	.381			
5	.1781	.2401	.2458	.3963			
6	.2105	.253	.2458	.442			
7	.2429	.2968	.2753	.5247			
8	.3041	.3395	.4096	.4843			
9	.3277	.4115	.4372	.4915			
10	.3277	.4287	.4268		.4534	.0905	.1219
11	.3239	.3563	.3963		.7935	1.166	
12					.6964	1.2809	.0937
13					.5668	.9555	.0914
14						1.0322	
15						1.1174	.1372
16						1.1269	.1524
17					.0972	1.4232	.1372
24	.1718	.2429	.2267	.381	.2932		
Max	.3277	.4287	.4372	.5247	.7935	1.4232	.1524
Min	.1677	.2343	.2267	.381	.0972	.0905	.0914
Avg	.2305	.2929	.2978	.4244	.4834	1.0241	.1223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 205 / 11kv Andhalgaon AG Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3544	.3982	
2					.3544	.3982	
3					.3366	.3982	
4					.3403	.3982	
5					.3224	.3982	
6					.3224	.3982	
7					.3189	.3982	
8					.3224	.3982	.3982
9					.3439		.3761
10				.3189			.3801
11				.3189			.3801
12	.3439	.3439	.3439	.333			.3856
13	.362	.3439	.3439	.333			.3801
14	.3366	.3439	.3439	.333			.3801
15	.3366	.3439	.3439	.3544			.3801
16	.333	.3258	.3439	.3224			
17	.3475	.3439	.3841	.3366			
18	.3506	.3258	.3403				
19	.3506	.3439	.3403				
20	.362	.3439					
21	.3506	.3403					
22	.3506	.3439					
23	.3506	.3439					
24						.3982	
Max	.362	.3439	.3841	.3544	.3544	.3982	.3982
Min	.333	.3258	.3403	.3189	.3189	.3982	.3761
Avg	.3479	.3406	.3480	.3313	.3351	.3982	.3826

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064003 / 33 KV JAMB S/S

Feeder No / Name : 207 / 11kv Dhop Agp

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3479	.3944	.4024			
2	.4024	.3437	.3944	.4024			
3	.4024	.3479	.3944	.4024			
4	.3978	.3593	.3944	.4024			
5	.3978	.3593	.4115	.3856			
6	.3978	.3749	.4557	.3688			
7		.3749	.4382	.3856			
8	.4475	.3637	.4382	.5533			
9	.4111	.3795	.4733	.3887			
10	.4111	.4287	.4527		.4287	.3401	.3688
11	.4161	.4287	.4527		.4458	.3239	.3856
12					.4458	.3321	.3856
13	.3887				.4973	.3437	.3688
14						.3479	.3688
15						.3361	.3856
16					.1372	.3479	.3688
17					.3601	.3563	.3688
24	.4024	.3479	.3944	.4024	.3637		
Max	.4475	.4287	.4733	.5533	.4973	.3563	.3856
Min	.3887	.3437	.3944	.3688	.1372	.3239	.3688
Avg	.4065	.3714	.4245	.4094	.3827	.341	.3751

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 206 / 11 KV Chichkheda Feeder

Single Phasing Feeders

SP Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6935	.6135	.3944	1.0288	1.1163	.7973	.6516
2	.6661	.6135	.5487	1.0117	1.0808	.7973	.5144
3	.6661	.5847	.583	.9945	1.0808	.7442	.4973
4	.6485	.5847	.6173	.9774	1.0692	.7011	.4801
5	.6241	.5014	.6516	.9431	1.0576	.6661	.4287
6	.4024	.3801	.4287	.9259	1.0117	.5201	.3772
7			.3086	.8059	.9326	.4694	.2572
8			.2401	.6344	1.0852	.4588	.2743
9			.2229	.7888	1.1022	.4359	.2987
10	.3361	.0509	.3429	.3086	.3772	.2204	.7202
11	.3395	.5144	.4115	.3467	.4287	.2743	.583
12	.7537	.7545	.8402	.4578	.5144	.2915	1.0166
13	.8413	.8059	.9602	.4578	.4973	.3294	.7628
14	.5487	.7888	1.0117	.4458		.333	.7108
15	.426	.7545	1.0288	.4115		.3155	.5434
16	.5365	.6344	.6859	.3315	.12	.2572	.4287
17	.4807	.8505	.7202	.2818	.1715	.2401	.463
18	.426	.6805	.7888	.3149	.0838	.2229	.2229
19	.567	.6805	.9088	.5201	.394	.4287	.3544
20	.8417	.8326	.6859	.691	.6516	.6173	.3366
21	.9231	.9671	.7545	.7712	.7265	.7655	.7087
22	.8326	.9214	.7373	.7455	.6935	.7842	.7186
23	.7964	.8688	.703	.6935	.6588	.7282	.7011
24	.6935	.6344	.463	1.0631	1.1462	.8962	.6687
Max	.9231	.9671	1.0288	1.0631	1.1462	.8962	1.0166
Min	.3361	.0509	.2229	.2818	.0838	.2204	.2229
Avg	.6211	.6675	.6266	.6646	.7273	.5123	.5300

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 207 / 11 KV Pardi Feeder SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4508	.4382	.4458	.6859	.6201	.5847	.4287
2	.4334	.4382	.4287	.6516	.5847	.567	.4287
3	.4382	.4252	.4115	.5658	.5847	.5138	.3944
4	.4207	.3544	.4115	.5144	.5609	.5083	.3429
5	.3988	.3045	.3944	.4801	.4854	.5083	.3258
6	.1829	.1991	.2058	.3944		.4508	
7	.1254	.1448	.1543	.3086	.3561	.3018	
8	.12	.1254	.2058	.3086	.4578	.2294	.1715
9	.2214	.2058	.1715	.4294	.4239	.3688	.1715
10	.2241	.2204	.2058	.3086	.2229	.1526	.3944
11	.2315	.2401	.2401	.208	.2401	.1543	.4801
12	.4382	.3601	.463	.2543	.2915	.1886	.5083
13	.4908	.4458	.5144	.2543	.2915	.1907	.4854
14	.4458	.4801	.6173	.2572		.2103	.5375
15	.3277	.5316	.5487	.2572	.1715	.2103	.4733
16	.3353	.4801	.5144	.2652	.12	.1886	.3944
17	.2984		.4458	.2155	.1543	.1715	.4287
18	.3113	.443	.3258	.2155	.1509	.1372	.1372
19	.4252	.5373	.7373	.3294	.2686	.2229	.2126
20	.5731	.5973	.4287	.4607	.3982	.3944	.3898
21	.6335	.6805	.5144	.5083	.4607	.5041	.4784
22	.6878	.6556	.463	.5201	.4854	.5228	.4908
23	.6516		.4287	.4854	.4508	.4854	.4908
24	.4681	.463	.4458	.703	.6626	.6268	.4458
Max	.6878	.6805	.7373	.703	.6626	.6268	.5375
Min	.12	.1254	.1543	.208	.12	.1372	.1372
Avg	.3889	.3987	.4051	.3992	.3838	.3497	.3914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 208 / 11 KV Express Feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.3734	.3921	.4854	.3547	.5228	.4294
2	.5041	.3734	.3921	.4668	.3547	.4668	.4108
3	.4854	.3921	.3921	.4294	.3547	.4668	.3734
4	.4481	.3734	.3921	.4108	.3361	.4294	.3734
5	.4481	.3547	.3921	.4108	.3174	.4294	.3547
6	.3921	.3547	.3921	.4294	.2987	.3547	.3547
7	.3734	.3361	.4481	.4108	.2987	.4668	.3547
8	.3174	.3734	.4294	.3734	.3174	.4294	.3734
9	.3734	.3547	.4294	.4108	.2987	.4108	.3921
10	.3734	.3174	.4294	.4481	.3547	.4108	.4108
11	.3547	.2401	.4108	.5228	.4108	.3921	.3547
12	.3547	.2229	.3734	.3734	.3734	.3734	.3734
13	.333	.2401	.3734	.3734	.3734	.4108	.3547
14	.3547	.2614	.3734	.3921		.4294	.3921
15	.3174	.2801	.3547	.3734	.4108	.3547	.3734
16	.3174	.4294	.3734	.3547	.3734	.3734	.3174
17	.3361	.5228	.3547	.2987	.3547	.3734	.3547
18	.3361	.4108	.3921	.3361	.3547	.3734	.3921
19	.3174	.3582	.3547	.3174	.3547	.3734	.3174
20	.3361	.3921	.3361	.3734	.3734	.3921	.2987
21	.3547	.3547	.3547	.3734	.3734	.3734	.3361
22	.3361	.2987	.4108	.3547	.3921	.3921	.3734
23	.3361		.5041	.3547	.5041	.3734	.3547
24	.5601	.4108	.3921	.4854	.3734	.5601	.4108
Max	.5601	.5228	.5041	.5228	.5041	.5601	.4294
Min	.3174	.2229	.3361	.2987	.2987	.3547	.2987
Avg	.3842	.3489	.3936	.3983	.3612	.4139	.3680

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 209 / 11 KV Mohadi Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4294	.4481	.4481	.4481	.4108	.8962
2	.4108	.4294	.4481	.4108	.4294	.4108	.8402
3	.3921	.4108	.4481	.3921	.4294	.3734	.8029
4	.4108	.3734	.4294	.3734	.4108	.3361	.7468
5	.4294	.3547	.4294	.3734	.4108	.3174	.6908
6	.3174	.3361	.3361	.3547	.3921	.2987	.6348
8	.3174	.3174		.2987	.2987	.2987	.5601
9	.2801	.2801		.2987	.2801	.6535	.5228
10	.2987	.2427	.4854	.3174	.2801	.6908	.5975
11	.3174	.3086	.3921	.3174	.3734	.8402	.7282
12	.3547	.3258	.3921	.3734	.3921	.7655	.7282
13	.4108	.3601	.4294	.3921	.4294	.7655	.9522
14	.3734	.3734	.4294	.3734		.7282	.9522
15	.2241	.3921	.4108	.3734	.2054	.7095	.8589
16	.2427	.3361	.3547	.3547	.2241	.7095	.7282
17	.2054	.3361	.3174	.3174	.2427	.7095	.6535
18	.1867	.3174	.2987	.2614		.6348	.6161
19	.2801	.3045	.3361	.3734		.6348	.5975
20	.3921	.4108	.5415	.4108	.3921	.7655	.8029
21	.4108	.4668	.4481	.4481	.4108	.8029	.8775
22	.4668	.5228	.4294	.5228	.4481	.9149	.9709
23	.4668		.5041	.5041	.4481	.9335	.9709
24	.4108	.4668	.4854	.4668	.4668	.4481	.9149
Max	.4668	.5228	.5415	.5228	.4668	.9335	.9709
Min	.1867	.2427	.2987	.2614	.2054	.2987	.5228
Avg	.3483	.3680	.4188	.3807	.3706	.6153	.7671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 210 / 11kv Kanhalgaon SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1907	.1753	.2058	.3086	.2835	.2303	.2058
2	.1928	.1753	.2058	.2915	.2835	.2303	.1886
3	.1753	.1772	.2058	.2572	.2658	.2303	.1543
4	.1928	.1417	.2058	.2401	.2629	.2103	.1372
5	.1907	.1433	.2058	.2229	.2427	.1928	.12
6	.128	.1267	.12	.2229	.2401	.1734	.1029
7	.0895	.0905	.1029	.2058	.2374	.1677	.112
8	.0857	.0895	.0857	.1715	.2374	.1311	.1029
9		.0857	.0857	.1886	.2374	.1341	.0934
10	.048	.0848	.0857	.0857	.1029	.0678	.1372
11	.0463	.1029	.1029	.104	.1029	.0857	.1886
12	.1928	.3086	.1886	.1187	.12	.0857	.2103
13	.2454	.1715	.2058	.1187	.1372	.104	.2427
14	.1715	.2058	.2058	.12		.1052	.2427
15	.1311	.2401	.2915	.12	.12	.1052	.2103
16	.1341	.1715	.2401	.0829	.1029	.0857	.12
17	.1326	.1772	.2743	.0829	.0686	.0857	.1715
18	.1311	.2126	.2058	.0829	.0671	.0857	.0686
19	.1949	.2149	.2401	.1387	.1254	.1029	.1063
20	.2507	.2715	.1886	.1949	.181	.1543	.1595
21	.2534	.2865	.2058	.2279	.1949	.1886	.1949
22	.2715	.2835	.2058	.2254	.1907	.2058	.2103
23	.2715	.2353	.2058	.208	.1907	.2058	.2103
24	.208	.1886	.2058	.3086	.3045	.2507	.2058
Max	.2715	.3086	.2915	.3086	.3045	.2507	.2427
Min	.0463	.0848	.0857	.0829	.0671	.0678	.0686
Avg	.1708	.1817	.1865	.1804	.1869	.1508	.1623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 212 / 11kv Dongargaon SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2427	.2801	.5041	.5041	.2614	.2427
2	.2614	.2427	.2801	.5041	.4481	.2241	.2054
3	.2427	.2427	.2614	.4668	.4481	.2241	.1867
4	.2614	.2241	.2614	.4481	.4294	.2241	.168
5	.2427	.1867	.2614	.4481	.4294	.1867	.168
6	.1494	.1494	.112	.4294	.4294	.1307	.1494
7	.0747	.112	.112	.2614	.4108	.2241	.112
8	.112	.0934	.0934	.3921	.4294	.2241	.0934
9	.1307	.112	.0934	.4108	.4108	.2801	.112
10	.1307	.1307	.0934	.112	.1494	.2987	.2614
11	.1494	.1372	.1307	.1307	.1867	.2614	.3174
12	.4668	.3601	.4294	.1867	.2054	.2801	.3174
13	.4294	.4115	.4668	.1867	.2241	.2614	.3734
14	.4108	.3921	.4668	.1867		.2614	.3361
15	.3174	.3921	.4668	.168	.0934	.2427	.3174
16	.3547	.3174	.4108	.1307	.0747	.2614	.7282
17	.3734	.3012	.4108	.112	.0747	.0934	.3547
18	.3734	.3189	.3174	.112	.0747	.0934	.0747
19	.4108	.3045	.3361	.168	.1307	.1307	.1307
20	.4481	.4481	.2614	.2614	.2427	.2241	.2427
21	.4668	.4668	.2987	.2987	.2614	.2614	.2801
22	.4854	.4668	.2987	.2987	.2614	.2801	.2987
23	.4854		.2801	.2801	.2614	.2801	.2987
24	.2614	.2614	.2801	.5228	.4668	.2614	.2614
Max	.4854	.4668	.4668	.5228	.5041	.2987	.7282
Min	.0747	.0934	.0934	.112	.0747	.0934	.0747
Avg	.3042	.2745	.2793	.2925	.289	.2280	.2513

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064009 / 33 KV MOHADI S/S

Feeder No / Name : 401 / 33 KV MIDC

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8882	.8368	.9368	.8311	.7542	.3361	.0725
2	.8322	.7582	.9316	.8311	.7542	.3361	.1285
3	.7773	.7542	.9316	.7202	.7542	.3361	.0725
4	.7773	.7542	.9316	.7751	.7542	.3361	.0725
5	.6664	.6852	.8311	.7202	.7542	.3361	.0725
6	.6664	.6434	.7659	.6653	.7202	.3361	.1285
7		.0549	.1612	.0549	.0165		.0725
8	.6653	.7016	.6585	.0549	.6653		.0882
9	.6818	.6653	.7122	.1097	.6982		.0721
10	.6653	.6982	.6585	.6653	.3361		.1109
11	.864	.8871	.8871	.7366	.5041		.1109
12	.9211	.8871	.8871	.7202	.5041		.1109
13	.8871	.9316	.8871	.7762	.6161		.1109
14	.9035	.9911	.8882	.8322		.1097	.1109
15	.7542	.9911	.8322	.8486	.3361	.1097	.1109
16	.7762	.9911	.8882	.7378	.3361	.2206	.0549
17	.7202	.8825	.7213	.6653	.3361	.1663	.0549
18	.6434	.7722	.7202	.7202	.3361	.1449	.0549
19	.6434	.7162	.6104	.7202	.3361	.1449	.0549
20	.7213	.7722	.7202	.7762	.7842	.1449	.0549
21	.7762	.9316	.7762	.8662	.7842	.0889	.0549
22	.8368	.9928	.7762	.8102	.7842	.1285	.0549
23	.7802	.9368	.8322	.8333	.3921	.0725	.0549
24	.9431	.8486	.9419	.9431	.8368	.3921	.0725
Max	.9431	.9928	.9419	.9431	.8368	.3921	.1285
Min	.6434	.0549	.1612	.0549	.0165	.0725	.0549
Avg	.7735	.7952	.7870	.6839	.5693	.2200	.0815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 201 / 11kv Kardi AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.0174	1.0343	1.1022			
2	.9362	1.0898	1.0059	1.073			
3	.9945	1.1437	1.0343	1.0852			
4	1.0174	1.1736	1.0631	1.0898			
5	1.0395	1.073	1.0852	1.17			
6	1.0576	1.0174	1.1022	1.2071			
7	1.1218	1.1437	1.1736	1.2431			
8	1.1269	1.1736	1.17	.8718			
9	.823	1.153	.9892	.8288			
10	1.1065	1.1022	.9945		.8745	1.2136	1.2071
11	1.094	1.1022	1.1022		.8886	1.286	1.4255
12					.9665	1.286	1.3748
13					.9431	1.3176	1.4575
14						1.2689	1.3904
15						1.3203	1.4243
16						1.1218	.8059
17					1.0974	1.3466	.9156
24	.8573	.9724	1.0004	1.0974	.7716		
Max	1.1269	1.1736	1.1736	1.2431	1.0974	1.3466	1.4575
Min	.823	.9724	.9892	.8288	.7716	1.1218	.8059
Avg	1.0055	1.0968	1.0629	1.0768	.9236	1.2701	1.2501

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 202 / Koka Feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.439	1.0395	1.166	1.3395	1.6244	1.5424	1.595
2	1.4373	.9945	1.1361	1.3077	1.6244	1.4922	1.5432
3	1.3176	.9054	1.1361	1.3395	1.6575	1.3413	1.5089
4	1.2346	.9774	1.0898	1.2239	1.576	1.326	1.4243
5	1.166	.8573	1.0288	1.1934	1.5261	1.3226	1.3748
6	1.2174	.7969	1.0056	1.1904	1.5432	1.2742	1.2887
7	1.1963	.763	.9536	1.2763	1.5089	1.2689	1.3847
8	1.1831	.7545	.9259	1.1568	1.4586	1.4243	1.3176
9		.7969	.8648	1.1271	1.3916	1.4575	1.2574
10	.7545	.9431	.8048	1.1934	1.5769	1.491	1.3413
11	1.2929	1.0056	.7545	1.2742	1.5604	.9709	1.4575
12	1.2407	1.1145	1.4243	1.442	1.2407	.9114	1.5083
13	1.17	1.6108	1.3077	1.4089	1.2378	1.4217	1.5238
14	1.0774	1.3717		1.3592		1.3717	1.4918
15	1.1401	1.3226	1.4922	1.3413	1.1271	1.439	1.4918
16	1.0562	1.2689	1.5089	1.4083	1.1736	1.3717	1.4419
17	1.1934	1.1789	1.56	1.1401	1.2209	1.4563	1.3923
18	1.3413	1.1145	1.326	1.2071	1.4232	1.3203	1.3056
19	1.4586	1.4232	1.1568	1.326	1.6766	1.5257	1.3546
20	1.5581	1.4582	1.5091	1.7404	1.7295	1.56	1.4413
21	.6661	1.4922	1.4586	1.6598	1.6617	1.595	1.5424
22	.4557	1.4922	1.5089	1.6766	1.6095	1.6118	1.5249
23	1.0059	1.17	1.4074	1.6244	1.6448	1.5604	1.5089
24	1.4232	1.0442	1.046	1.3748	1.5927	1.6263	1.5432
Max	1.5581	1.6108	1.56	1.7404	1.7295	1.6263	1.595
Min	.4557	.7545	.7545	1.1271	1.1271	.9114	1.2574
Avg	1.1750	1.1207	1.1988	1.3471	1.4950	1.4034	1.4402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064033 / 33 KV Kardi

Feeder No / Name : 203 / Kardi Gavthan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6241	.5868	.6173	.6173	.5868	.6001	.6661
2	.631	.5636	.6068	.5895	.6203	.5596	.7011
3	.6024	.5365	.6068	.6135	.5304	.5197	.6588
4	.5373	.5144	.5784	.591	.503	.4917	.631
5	.4477	.4161	.5316	.4961	.4239	.4854	.5316
6	.3294	.3506	.4207	.3944	.4115	.3944	.4477
7	.298	.298	.3544	.3155	.3121	.333	.333
8	.3189	.2835	.362	.2915	.2915	.2865	.2947
9	.1907	.3189	.298	.2804	.3155	.2804	.2915
10	.3012	.3224	.3467	.2915	.3641	.2658	.3222
11	.1928	.3721	.3944	.3506	.4239	.3366	.3601
12	.4287	.4557	.4854	.4287	.463	.333	.3944
13	.463	.4854	.4973	.3772		.3467	.4239
14	.4287	.4973	.5434	.4207		.3772	.3944
15	.3506	.4681	.5028	.3988	.156	.3121	.4115
16	.2658	.4207	.4334	.3429	.2401	.333	.3391
17	.2743	.3641	.3772	.3429	.3155	.3366	.3429
18	.3391	.3681	.4161	.3814	.3429	.3294	.3121
19	.4359	.6516	.4835	.4115	.4191	.583	.3429
20	.4973	.6001	.5959	.5868	.5087	.6068	.4239
21	.5868	.6687	.6805	.6274		.6661	.57
22	.6274	.703	.6762	.6539		.6836	.6371
23	.5935	.6859	.6836	.6274	.6415	.6588	.6104
24	.6173	.6173	.6588	.6516	.6274	.6344	.6516
Max	.631	.703	.6836	.6539	.6415	.6836	.7011
Min	.1907	.2835	.298	.2804	.156	.2658	.2915
Avg	.4326	.4812	.5063	.4618	.4249	.4481	.4622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 201 / 11 kv Mohadi Gaothan
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3475	.3696	.3841	.3292
2	.3292	.3292	.3696	.3841	.3292
3	.2926	.3292	.3475	.3658	.3292
4	.2561	.3292	.2926	.3841	.3292
5	.2195	.3109	.2743	.3292	.3292
6	.2195	.2743	.2561	.2926	.3658
8	.2195	.2378	.176		.2743
9	.2743	.2561	.2378		.3292
10	.3109	.0373	.2743	.3109	
11	.4024	.3475	.3841	.3475	
12	.3658	.3292	.3841	.3475	
13	.3841	.3696	.3841	.3475	
14	.4024	.3841	.3658	.3475	
15	.3475	.3658	.3658	.3658	
16	.3109	.3475	.3841	.3292	
17	.3292	.3475	.3109	.3109	
18	.2926	.0366	.3292	.3475	
19	.2926	.3109	.2743	.3475	
20	.2926	.2957	.3292	.3475	
21	.3475	.3658	.3475	.3475	
22	.3658	.3696	.3658	.3475	
23	.3658	.3881	.3841	.3292	
24	.3475	.3658	.3696	.3841	.3292
Max	.4024	.3881	.3841	.3841	.3658
Min	.2195	.0366	.176	.2926	.2743
Avg	.3173	.3076	.3294	.3475	.3272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

MOHADI S/DN.[383]

BU 0383

Substation No/ Name :- 064040 / MIDC MOHADI

Feeder No / Name : 202 / 11 KV MOHADI MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0183	.0185	.0183	.0185		.0185
2	.0732	.0183	.0185	.0183	.0185		.0185
3	.0549	.0183	.037	.0183	.0185		.0185
4	.0549	.0183	.037	.0183	.0185		.0185
5	.0366	.0183	.0366	.0183	.0185		.0185
6	.0549	.0183	.037	.0183	.0185		.0185
7		.0373	.037	.0183	.0187		.0185
8	.1097	.0187	.0185	.0366	.037		.037
9	.0732	.0373	.037	.0549	.0185		.0185
10	.0187	.0373	.0185	.0183			.0183
11	.0732	.0747	.0366	.0549		.0739	.0366
12	.0549	.0187	.0732	.0366		.0366	.0366
13	.0549	.0187	.0366	.0366			.0366
14	.0549	.0739	.0183	.0366		.0732	.0183
15	.0183	.0554	.0183	.0366		.0732	.0183
16	.0732	.037	.0183	.0183		.0732	.0366
17	.0549	.037	.0366	.0183		.0183	.0549
18	.0183	.037	.0366	.0366		.0366	.0366
19	.0183	.0185	.0183	.0366		.037	.0366
20	.0366	.0185	.0366	.0366		.037	.0366
21	.0366	.037	.0183	.0183		.037	.0366
22	.0183	.037	.0183	.0183		.0185	.0366
23	.0183	.0185	.0183	.0183		.0185	.0183
24	.0732	.0183	.0185	.0366	.0183		.0185
Max	.1097	.0747	.0732	.0549	.037	.0739	.0549
Min	.0183	.0183	.0183	.0183	.0183	.0183	.0183
Avg	.0501	.0309	.0291	.0282	.0204	.0444	.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 201 / 11 KV BHAVAD FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5281	.547	.5093	.4359	.4359	.4191
2	.5281	.5093	.547	.4578	.4359	.4359	.4191
3	.5281	.5281	.547	.4578	.4359	.4359	.4191
4	.5281	.5093	.547	.4409	.4359	.4191	.4359
5	.4904	.4527	.5093	.4409	.4359	.4321	.4024
6	.2829	.3018	.3206	.4024	.4024	.4321	.3856
7	.2263	.2263	.2641	.3688	.5365	.4531	.3353
8	.2075	.1886	.2641	.3688	.4359	.4374	.4024
9	.2452	.2452	.2263	.4024	.503	.4374	.4191
10	.2452	.2452	.3018	.2641	.2452	.1886	.1886
11	.2452	.132	.3206	.3018	.2829		.2263
12	.3521	.2778	.3688	.3772	.3206	.2829	.2263
13	.3353	.3086	.4578	.4338	.3206	.3206	.2452
14	.4024	.4062	.39	.4527	.2263	.3206	.3018
15	.4191	.3906	.407	.4338	.2075	.3018	.2452
16	.2896	.3125	.4239	.3206	.1698	.2641	.1886
17	.3353	.3281	.407	.2829	.2075	.2263	.1509
18	.3125	.3549	.4409	.2641	.2075	.1886	.1132
19	.3725	.3395	.3206	.3584	.3018	.3584	.2829
20	.3315	.4012	.5093	.5281	.5093	.4527	.4715
21	.3481	.4167	.547	.5281	.5658	.547	.5281
22	.4694	.4167	.5847	.5658	.5658	.5658	.547
23	.4694	.4167	.5658	.547	.5847	.547	.5281
24	.547	.5281	.547	.4409	.4694	.4359	.4359
Max	.547	.5281	.5847	.5658	.5847	.5658	.547
Min	.2075	.132	.2263	.2641	.1698	.1886	.1132
Avg	.3774	.3652	.4319	.4145	.3851	.3878	.3466

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 202 / 11 KV GOSE FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7186	.7602	.788	1.7918	1.7541	1.6975	1.6975
2	.7011	.7164	.7796	1.773	1.7164	1.6787	1.6975
3	.7011	.7011	.7796	1.7541	1.7164	1.6787	1.6975
4	.7011	.7011	.7442	1.7353	1.6975	1.6409	1.6975
5	.6485	.6588	.7265	1.6221	1.6032	1.5089	1.5844
6	.5434	.5721	.6201	1.0185	1.1694	1.0374	1.0751
7	.4908	.5201	.547	.8299	.9431	.7922	.6224
8	.5258	.5365	.6796	.811	.9431	.7733	.5093
9	.5609	.6371	.6874	.9808	.9242	.8299	.547
10	.57	.6203	.691	.5426	.362	.5197	.503
11	.6036	.6371	.7442	.6783	.4344		.6952
12	1.1883	1.2449	1.3769	.7291	.7964	.7701	.8322
13	1.3957	1.4146	1.5278	.8309	.905	.8238	.8495
14	1.4335	1.4523	1.6032	.8939	.7783	.8596	.8764
15	1.3203	1.3014	1.3957	.8413	.6335	.7522	.7545
16	.8865	1.094	1.2637	.7712	.6154	.7701	.6859
17	.8488	.8676	.9619	.7888	.6154	.6447	.6344
18	.7922	.8676	.8299	.5658	.4527	.4715	.415
19	1.1883	1.3014	1.2826	1.5466	1.2071	1.4146	1.1128
20	1.6787	1.8861	1.9239	1.9993	1.7918	1.8107	1.7541
21	1.9427	2.0182	1.9616	1.905	1.9993	2.0182	1.9805
22	1.905	1.9427	1.9805	1.8673	1.8861	1.9239	1.9427
23	1.7918	1.8484	1.8673	1.8107	1.8861	1.7918	1.8107
24	.7186	.7602	.8145	1.8107	1.7541	1.7353	1.7353
Max	1.9427	2.0182	1.9805	1.9993	1.9993	2.0182	1.9805
Min	.4908	.5201	.547	.5426	.362	.4715	.415
Avg	.9940	1.0442	1.1074	1.2458	1.1910	1.2149	1.1546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 203 / 11 KV KONDHA FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3765	2.4331	2.3011	.985	.9492	.985	.985
2	2.32	2.2445	2.2634	.9671	.9134	.9955	.985
3	2.2068	2.2257	2.2445	.9671	.9134	.9671	.985
4	2.1879	2.1879	2.1879	.9492	.8954	.9671	.9671
5	2.0748	1.9239	2.1125	.8954	.8417	.8954	.8954
6	1.3769	1.4712	1.5278	.6447	.7164	.7455	.8299
7	1.1317	1.1317	1.2449	.5552	.6626	.6001	.6984
8	1.0562	.6979	1.1128	.5014	.7343	.703	.6805
9	1.1128	.7545	1.2449	.5194	.7343	.7042	.788
10	1.3392	1.3769	1.5089	1.3392	1.4901	1.2071	1.3203
11	1.5655	1.6409	1.6409	1.8107	1.3014		1.5466
12	.7545	.7975	.8648	1.9805	1.8484	1.5655	1.6975
13	.8383	.9015	.9362	2.1502	1.8484	1.8296	1.6975
14	.8383	.9088	.9189	2.1691	1.5278	1.9239	1.9427
15	.788	.9431	.8669	2.1691	1.2826	1.6975	1.7353
16	.6859	.9431	.7975	1.8673	1.1317	1.4523	1.5278
17	.6859	.823	.788	1.5844	1.0374	1.3203	1.0562
18	.6001	.6133	.591	1.3957	1.2071	1.1506	.9997
19	.7108	.7127	1.5466	1.7918	1.5466	1.6409	1.4523
20	.8505	.8551	2.2068	2.32	2.1691	2.1313	2.1125
21	.9391	.8886	2.3577	1.3014	2.32	2.32	2.32
22	1.0099	.9724	2.5086	2.4143	2.4897	2.3954	2.4331
23	.964	.9724	2.4143	2.4143	2.452	2.32	2.3765
24	2.3765	2.2822	2.32	.985	.9492	1.0029	.985
Max	2.3765	2.4331	2.5086	2.4143	2.4897	2.3954	2.4331
Min	.6001	.6133	.591	.5014	.6626	.6001	.6805
Avg	1.2829	1.2792	1.6045	1.4449	1.3318	1.3704	1.3757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 204 / 11 KV Virlee Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8299	.8488	.8676	.8299	.811	.8676
2	.8488	.8299	.8488	.8676	.8299	.811	.8488
3	.8299	.811	.8488	.8676	.8299	.7922	.8488
4	.8299	.7922	.8488	.8488	.811	.7545	.8488
5	.7733	.7545	.7922	.7545	.7356	.6979	.811
6	.4338	.5093	.5093	.4527	.4904	.5093	.4904
7	.3772	.3584	.4338	.415	.4527	.3584	.3961
8	.3584	.3584	.415	.3772	.415	.3395	.3772
9	.3772	.3772	.4338	.4338	.4715	.3584	.3772
10	.415	.3961	.4715	.2915	.2926	.2347	.2347
11	.415	.4527	.547	.3086	.3109		.2683
12	.2785	.2774	.3429	.3429	.3109	.2713	.3121
13	.3768	.3467	.4435	.3772	.3109	.2883	.3121
14	.3688	.3467	.3881	.3681	.2743	.2883	.3898
15	.3353	.2947	.3511	.3506	.2195	.3052	.3155
16	.2486	.2743	.3881	.3155	.2012	.2713	.298
17	.2486	.2572	.3439	.2804	.2195	.2543	.2279
18	.2515	.2372	.2896	.415	.2829	.3018	.2829
19	.3121	.2846	.5658	.7167	.5281	.7545	.547
20	.3856	.4207	.9619	1.0374	.8865	.9619	.9054
21	.4031	.439	.9619	.9619	.9619	.9619	.9997
22	.4031	.439	.9619	.8299	.9242	.9619	.9431
23	.3681	.3944	.8865	.8676	.8865	.9054	.8299
24	.8676	.8488	.8299	.8488	.8299	.8299	.8865
Max	.8676	.8488	.9619	1.0374	.9619	.9619	.9997
Min	.2486	.2372	.2896	.2804	.2012	.2347	.2279
Avg	.4739	.4721	.6130	.5915	.5544	.5662	.5675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 205 / 11 KV Palora Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5935	.5083	.503	.9242	.8865	.8676	.9242
2	.5935	.5258	.503	.9054	.8865	.8676	.9054
3	.5765	.5083	.503	.9054	.8865	.8488	.8865
4	.5765	.463	.4915	.8865	.8676	.8299	.8865
5	.5256	.463	.4588	.8299	.7733	.7545	.8299
6	.4748	.4458	.426	.5281	.4904	.5281	.5093
7	.5087	.3772	.4607	.3961	.4527	.3584	.415
8	.5087	.4641	.4904	.3584	.415	.3772	.3395
9	.4917	.4801	.5155	.3772	.4527	.3206	.1886
10	.503	.5197	.5636	.3353	.4239	.3681	.2321
11	.4694	.3353	.5636	.4359	.5256		.5304
12	.4904	.6224	.7545	.5197	.6274	.5765	.5935
13	.6036	.7167	.811	.6203	.5765	.5935	.6344
14	.7167	.7356	.811	.6464	.5256	.5765	.6299
15	.6602	.6224	.6602	.5967	.4239	.5426	.583
16	.4904	.5093	.5847	.5636	.463	.5596	.5344
17	.4527	.3961	.415	.547	.4115	.5087	.5243
18	.3395	.3961	.3395	.3961	.3395	.3018	.3018
19	.5281	.6036	.5847	.6224	.547	.6224	.547
20	.7922	.8488	.8676	.9054	.8299	.8676	.8299
21	.9054	.9431	.9242	.9242	.9431	.9431	.9431
22	.9808	.9808	.9997	.9619	.9619	.9808	.9431
23	.9619	.9808	.9431	.9431	.9431	.9431	.9431
24	.5935	.5258	.4973	.9242	.8865	.9054	.9242
Max	.9808	.9808	.9997	.9619	.9619	.9808	.9431
Min	.3395	.3353	.3395	.3353	.3395	.3018	.1886
Avg	.5974	.5822	.6113	.6689	.6475	.6540	.6491

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064005 / KOSRA SUB STATION

Feeder No / Name : 206 / 11 KV Pimpalgaon Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8865	.8488	.8488	.5375	.4908	.4733	.5375
2	.8676	.8488	.8488	.5028	.4908	.4733	.5028
3	.8676	.8676	.8676	.5028	.4908	.4557	.5548
4	.8488	.8299	.8299	.5028	.4733	.4733	.5548
5	.7545	.7545	.8002	.4681	.4908	.4144	.5201
6	.3961	.4527	.4715	.3725	.3856	.3605	.4161
7	.3395	.3772	.3961	.3401	.4031	.3768	.3277
8	.3018	.2829	.4001	.3239	.3856	.3932	.3768
9	.3772	.3584	.4338	.3077	.4382	.4096	.3768
10	.3395	.3772	.5281	.4338	.5093	.3206	.3018
11	.415	.3961	.6036	.5658	.567		.415
12	.3185	.373	.4359	.679	.6811	.4715	.4715
13	.4024	.4409	.463	.7545	.6224	.5658	.4715
14	.4024	.4409	.463	.7922	.4715	.5847	.5658
15	.3688	.4578	.4458	.7545	.3395	.5093	.4527
16	.3185	.373	.3772	.5658	.3018	.3772	.3772
17	.3018	.3561	.3978	.3961	.3206	.3206	.2641
18	.285	.3018	.3812	.415	.3584	.3018	.2263
19	.3429	.3688	.4904	.6224	.5281	.547	.4715
20	.4458	.4527	.8299	.8676	.8488	.8299	.7356
21	.4458	.4694	.9242	.8488	.9431	.9054	.8865
22	.4681	.4527	.9997	.8865	.9619	.9431	.9054
23	.4458	.4694	.9431	.8676	.9431	.8865	.8865
24	.8865	.8676	.8954	.5658	.4908	.4908	.5375
Max	.8865	.8676	.9997	.8865	.9619	.9431	.9054
Min	.285	.2829	.3772	.3077	.3018	.3018	.2263
Avg	.4928	.5091	.6281	.5781	.5390	.5167	.5057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 201 / 11 KV ADYAL FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.7087	.7265	.7442	.691	.7087	.691
2	.631	.6556	.7265	.7442	.691	.6733	.691
3	.5959	.6556	.7087	.7265	.691	.6733	.691
4	.5609	.6379	.691	.7087	.691	.6024	.691
5	.5609	.6201	.6201	.6733	.6556	.5493	.6201
6	.4557	.4607	.4961	.5138	.5316	.4607	.4784
7	.4031	.4075	.443	.4961	.4784	.3721	.3898
8	.3856	.4075	.443	.4252	.4252	.4252	.4252
9	.3856	.4607	.5138	.4252	.5138	.4607	.443
10	.4382	.4961	.567	.5138	.567	.4961	.443
11	.6201	.567	.6201	.567	.5316		.4961
12	.567	.6201	.7186	.6556	.6379	.4961	.5493
13	.5493	.6556	.7087	.6556	.6379	.567	.567
14	.6379	.6733	.7087	.6556	.3544		.6379
15	.7087	.6201	.6556	.7265	.443	.5138	.567
16	.6201	.5847	.6201	.6556	.4784	.5493	.5138
17	.5493	.6024	.6024	.5847	.5138	.4784	.4784
18	.5138	.5138	.5493	.5138	.4961	.5138	.4607
19	.5847	.5493	.5847	.6024	.5493	.5138	.443
20	.6733	.6379	.691	.7619	.6201	.6201	.6733
21	.7087	.7087	.7442		.691	.7087	.6201
22	.7442	.7796	.7796	.7087	.7796	.7087	.7265
23	.7619	.7619	.7973	.7087	.7442	.7442	.7442
24	.6485	.7265	.7442	.7619	.7087	.7265	.7265
Max	.7619	.7796	.7973	.7619	.7796	.7442	.7442
Min	.3856	.4075	.443	.4252	.3544	.3721	.3898
Avg	.5806	.6046	.6442	.6317	.5884	.5710	.5736

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 203 / 11 KV Nerala Feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1791	.1595	.2012	.197	.197	.1791
2	.1492	.1791	.1595	.1844	.197	.1791	.1791
3	.1492	.1791	.1595	.1844	.197	.1791	.1772
4	.1492	.197	.1595	.1677	.197	.1791	.1791
5	.1492	.2149	.1595	.1677	.2149	.1612	.1791
6	.116	.1612	.1595	.1341	.1612	.1433	.1433
7	.116	.1433	.1417	.1341	.1254	.1075	.1433
8	.0995	.1254	.124	.1341	.1433	.1254	.1433
9	.116	.1612	.1417	.1174	.1433	.1433	.1612
10	.116	.1433	.1595	.1612	.1612	.1254	.1612
11	.116	.1433	.1595	.1791	.1791	.1433	.1612
12	.1492	.1612	.1949	.1791	.1612	.1612	.1791
13	.1658	.1612	.1772	.197	.1612	.1612	.1791
14	.1989	.1612	.1772	.1791	.1433		.197
15	.1658	.1612	.1772	.197	.1075	.1433	.197
16		.1433	.1595	.1791	.1075	.1254	.1254
17	.1326	.1254	.1417	.1433	.1254	.1433	.1433
18	.1326	.1612	.124	.1433	.1254	.1254	.1433
19	.1658	.1791	.1772	.1791	.1791	.1791	.1433
20	.2155	.2328	.2126	.2507	.2149	.2149	.2149
21	.2486	.2507	.2481	.2328	.2328	.2507	.2328
22	.2321	.2507	.2303	.2303	.2328	.2507	.2149
23	.2321	.197	.2279	.2149	.197	.2328	.2149
24	.1823	.2328	.1949	.1844	.197	.197	.1791
Max	.2486	.2507	.2481	.2507	.2328	.2507	.2328
Min	.0995	.1254	.124	.1174	.1075	.1075	.1254
Avg	.1593	.1769	.1719	.1781	.1709	.1682	.1738

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 204 / 11 KV KABARA FEEDER

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.144	.144	.144	.144	.144	.144
2	.144	.144	.144	.16	.144	.144	.144
3	.144	.144	.144	.192	.144	.144	.144
4	.096	.144	.144	.2881	.144	.144	.144
5	.2881	.144	.16	.2721	.192	.144	.112
6	.128	.2561	.2401	.192	.096	.16	.208
7	.2401	.144	.2721	.176	.112	.128	.176
8	.144	.128	.144	.16	.144	.144	.208
9	.2241	.128	.176	.16	.112	.176	.176
10	.144	.208	.16	.2721	.176	.2401	.16
11	.208	.2561	.2561	.208	.192	.2241	.144
12	.2561	.208	.208	.16	.192	.144	.144
13	.192	.128	.192	.16	.128	.128	.144
14	.144	.128	.16	.112	.176		.128
15	.176	.128	.144	.2721	.144	.144	.208
16	.192	.2401	.128	.208	.2241	.144	.176
17	.16	.192	.208	.176	.144	.176	.144
18	.144	.192	.2241	.144	.144	.128	.144
19	.144	.112	.144	.16	.16	.176	.144
20	.16	.144	.144	.144	.144	.144	.144
21	.144	.144	.144	.144	.144	.144	.144
22	.144	.144	.144	.144	.144	.144	.144
23	.144	.144	.144	.144	.144	.144	.144
24	.144	.144	.144	.128	.144	.144	.144
Max	.2881	.2561	.2721	.2881	.2241	.2401	.208
Min	.096	.112	.128	.112	.096	.128	.112
Avg	.1687	.1620	.1714	.1800	.1513	.1544	.1547

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 206 / 11 KV Tirri Gaothan Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0953	.0953	.0953	.0762	.0953
2	.0953	.1143	.0762	.0953	.0953	.0762	.0953
3	.0953		.0762	.0953	.0953	.0762	.0953
4	.0953		.0762	.0953	.0953	.0572	.0953
5	.0762		.0762	.0953	.0953	.0572	.0953
6	.0572		.0762	.0762	.0572	.0572	.0762
7	.0572	.0381	.0762	.0762	.0572	.0572	.0572
8	.0572	.0381	.0572	.0572	.0381	.0572	.0381
9	.0572	.0572	.0572	.0572	.0762	.0572	.0572
10	.0572	.0572	.0572	.0762	.0572	.0572	.0572
11	.0572	.0762	.0762	.0762	.0572	.0381	.0572
12	.0762	.0572	.0953	.0762	.0762	.0381	.0572
13	.0762	.0762	.0953	.0762	.0572		.0572
14	.0953	.0762	.0953	.0953	.0762		.0572
15	.0762	.0762	.0762	.0953	.0953	.0762	.0572
16	.0572	.0762	.0762	.0762	.0572	.0572	.0572
17	.0381	.0762	.0572	.0762	.0572	.0762	.0572
18	.0381	.0572	.0762	.0762	.0572	.0762	.0572
19	.0762	.0762	.0762	.0953	.0762	.0762	.0762
20	.1143	.1143	.0953	.1143	.0762	.0953	.0953
21	.1334	.1143	.0953	.1143	.0953	.1143	.1143
22	.1143	.1143	.1143	.1143	.0762	.1143	.0953
23	.1143	.0953	.1143	.0953	.0762	.1334	.0953
24	.1143	.1143	.0953	.0953	.0953	.0762	.1143
Max	.1334	.1143	.1143	.1143	.0953	.1334	.1143
Min	.0381	.0381	.0572	.0572	.0381	.0381	.0381
Avg	.0802	.0810	.0818	.0873	.0746	.0728	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 207 / 11 KV ASHOK NAGAR FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.0857	.1543			
2	.0857	.1029	.0857	.1543			
3	.0857	.1029	.0857	.1543			
4	.0857	.1029	.0857	.1543			
5	.1029	.1029	.0857	.1543			
6	.1029	.1029	.1029	.1543			
7	.1029	.1029	.12	.1715			
8	.2401	.0857	.1543	.1543			
9	.12	.0857	.1543	.1543			
10	.3086	.0857	.1715		.1543	.1886	.1543
11	.12	.1372	.1543		.1029	.2058	.1715
12					.0857	.1886	.1715
13					.1886		.2058
14					.1886		.2058
15					.1715	.1886	.2058
16					.1715	.1886	.2058
17					.2229	.1715	.2058
24	.1029	.1029	.0857	.1543	.12		
Max	.3086	.1372	.1715	.1715	.2229	.2058	.2058
Min	.0857	.0857	.0857	.1543	.0857	.1715	.1543
Avg	.1300	.1015	.1143	.1560	.1562	.1886	.1908

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 201 / 11 KV PAUNI-I Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9055	.8686	.8871	.8871	.8501	.7762	.8871
2	.924	.8686	.8871	.8686	.8131	.7762	.8686
3	.924	.8316	.8501	.8686	.7762	.7762	.8501
4	.8686	.8131	.8131	.8686	.7392	.7762	.7762
5	.8686	.7392	.7392	.6468	.6653	.7392	.7392
6	.6099	.6099	.6099	.5914	.5729	.6653	.6099
7	.6099	.5359	.5544	.5175	.5544	.499	.5175
8	.6099	.5544	.5729	.5175	.5544	.499	.5175
9	.5914	.7207	.5729	.6283	.5175	.5359	
10	.8871	.9425	.5914	.7207	.9055		.5544
11	.9795	.9979	1.0903	.8501	1.0349	.9425	.5914
12	1.0719	.9425	1.1273	.9795	.9425	.9979	1.0534
13	1.2012	1.1088	1.0349	.9795	.9979	.9979	1.0903
14	1.1458	1.1458	1.2936	.961	1.0566	.9979	1.1458
15	1.1643	1.1458	1.2382	.9979	.9492	.9425	.9055
16	1.1643	1.0534	.8316	.9425	.924	.961	.6838
17	.8686	.8775	.924	.961	.924	.6838	.5359
18	.8686	.5359	.9055	.7577	.8501	.961	.4251
19	.9795	1.0534	.9979	.8131	.9795	1.0719	.5731
20	.9795	1.1458	.9055	.924	1.1643	1.1273	.7207
21	.9425	.8501	.924	.8131	.8316	.8316	.7207
22	1.0719	.924	.924	.8316	.8871	.8871	.8871
23	.924	.924	.961	.924	.8316	.9055	.9055
24	.924	.8871	.9055	.924	.8871		.9055
Max	1.2012	1.1458	1.2936	.9979	1.1643	1.1273	1.1458
Min	.5914	.5359	.5544	.5175	.5175	.499	.4251
Avg	.9202	.8782	.8809	.8239	.8420	.8341	.7593

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 202 / 11 KV Sawarla Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2403	.6935	1.2403	.3544	.3814	.3544	.3544
2	1.2403		1.2403	.3544	.3814	.3544	.3544
3	1.2403	.3467	1.2403	.3544	.3814	.3544	.3544
4	1.2403	.3467	1.1517	.3544	.3814	.3544	.3544
5	1.1871	.3467	1.1517	.3544	.3814	.3544	.3544
6	.6024	.3467	.7087	.3544	.3467	.3544	.2658
7	.443	.3467	.567	.3544	.3467	.2658	.2658
8	.443	.3467	.5316	.3898	.3467	.3544	.2658
9	.443	.3467	.5316	.3898	.3814	.3544	
10	.5316	.3814	.6379	.443	.4161	.5316	.443
11	.8669	.567	.7442	.7282	.6201	.6201	.5316
12	.3121	.3544		.9362	.6733	.7087	.7087
13	.4334	.443	.4961	1.0056	.8859	.7973	.7442
14	.4334	.443	.4961	1.0056	.9214	.8859	.7442
15	.4508	.443	.4961	1.0056	.5316	.6201	.7442
16	.4508	.443	.4961	.8669	.3544	.5316	.7087
17	.4508	.443	.3544	.6588	.3189	.5316	.3544
18	.4334	.3544	.4961	.6935	.3544	.3544	.3544
19	.4334	.3544	.7087	.6935	.7087	.6733	.7087
20	.3467	.3544	1.2403	1.3523	1.2403	1.2403	.7442
21	.4161	.3544	1.2403	1.2136	1.4175	1.2403	1.382
22	.4334	.443	1.4175	1.1789		1.382	1.3643
23	.4508	.5316	1.2757	.3814	1.2403	1.2403	1.2048
24	1.2403	.4161	1.3289	.5316	.3814	.3544	.3544
Max	1.2403	.6935	1.4175	1.3523	1.4175	1.382	1.382
Min	.3121	.3467	.3544	.3544	.3189	.2658	.2658
Avg	.6568	.4107	.8605	.6648	.5823	.6172	.5940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 203 / 11 KV Amgaon Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975	1.4582	1.4582	.7969	.8478	.8817	.8916
2	1.6787	1.4582	1.4243	.7969	.8478	.8817	.9362
3	1.3565	1.4582	1.3904	.7969	.8478	.8817	.9088
4	1.3565	1.4413	1.3565	.8596	.8478	.8817	.8916
5	1.2717	1.0174	1.3565	.7969	.8139	.8478	.8916
6	.9665	.8817	.9496	.7969	.7969	.8139	.8745
7	.8478	.7122	.78	.78	.8817	.8817	.8573
8	.8478	.7291	.7461	.763	.8987	.8817	.8573
9	.8648	.7291	.8817	.763	1.0174	.763	.8745
10	.852	.5596	.8987	.78	.8139	.6443	.7122
11	.9835	.763	1.0174	1.0343	1.0174	.8478	.8817
12	.6783	.5426	.763	1.2717	.9496	.9835	1.0974
13	.8478	.8817	.9326	1.3395	1.0852	1.0174	1.0852
14	.8817	.9156	.9326	1.3904	1.2209	1.0174	1.0852
15	.8817	.7969	.9156	1.4752	.8648	1.0174	1.153
16	.9156	.78	.9326	1.2887	.9496	1.0004	1.1361
17	.8817	.763	.9326	1.0174	.6952	1.0004	.6783
18	.8478	.763	.8817	1.0513	.7461	.7291	.5765
19	.8478	.7969	1.153	1.0852	1.0343	.9835	.8478
20	.8817	.8648	1.6448	1.6278	1.6108	1.5769	.8817
21	.8648	.8817	1.6448	1.56	1.6956	1.6297	1.7295
22	.8648	.8478	1.7295	1.4922		1.6817	1.6787
23	.8139	.8648	1.5261	1.3904	1.4413	1.5261	1.4582
24	1.5261	1.5091	1.4243	.8478	.8648	.9326	.823
Max	1.6975	1.5091	1.7295	1.6278	1.6956	1.6817	1.7295
Min	.6783	.5426	.7461	.763	.6952	.6443	.5765
Avg	1.0190	.9340	1.1530	1.0751	.9908	1.0126	.9920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 204 / 11 KV KHAPRI(REHAPADE)

Single Phasing Feeders

Feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.2561	.1562	.2343	.192	.1562	.16
2	.1562	.2561	.1562	.2343	.192	.1562	.192
3	.1562	.2561	.1562	.2343	.192	.1562	.192
4	.1562	.2561	.1562	.2343	.192	.1562	.192
5	.1562	.2561	.1562	.2343	.192	.1562	.192
6	.1562	.16	.1562	.2343	.192	.1562	.16
7	.1562	.16	.1562	.2343	.192	.1562	.192
8	.1562	.2561	.16	.2187	.2401	.1562	.192
9	.1562	.192	.16	.2187	.2401	.1562	.192
10	.1562	.192	.192	.1562	.16	.1562	.16
11	.16	.1562	.1875	.192	.1562	.1562	.1875
12	.192	.1875		.192	.1562	.1562	.1562
13	.2561	.1875	.2343	.192	.1772	.1562	.1875
14	.2561	.1875	.2343	.192	.2035	.1562	.1875
15	.2561	.1875	.2343	.192	.2035	.1562	.1875
16	.2561	.2343	.2343	.192	.1543	.1562	.1875
17	.2561	.2343	.2343	.16	.1562	.1562	.1562
18	.2561	.2343	.2343	.192	.1562	.1562	.1562
19	.2561	.2343	.1875	.192	.1562	.1562	.1875
20	.2561	.1875	.2343	.2561	.2343	.1562	.1875
21	.2561	.1875	.2343	.3201	.2343	.16	.1875
22	.2561	.1562	.1875	.3201		.16	.1875
23	.2561	.1562	.2343	.3201	.2343	.16	.1875
24	.1875	.2561	.1562	.2343	.192	.1562	.192
Max	.2561	.2561	.2343	.3201	.2401	.16	.192
Min	.1562	.1562	.1562	.1562	.1543	.1562	.1562
Avg	.2062	.2095	.1927	.2242	.1912	.1567	.1817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 205 / 11 kv Pauni - II FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.985	1.0029	.9671	1.0387	1.0029	.8954	1.0745
2	.985	1.0029	.9492	.9671	.9671	.8954	1.0566
3	.985	.9979	.9313	.9671	.9313	.8954	.985
4	.9313	.9313	.9313	.9492	.8954	.8775	.9671
5	.8954	.8501	.8954	.8954	.8238	.6626	.8954
6	.6805	.6626	.6805	.7164	.7164	.6447	.7164
7	.7164	.6089	.6268	.6089	.6626	.5552	.591
8	.6089	.5731	.6626	.5731	.591	.5731	.591
9	.6268	.5552	.6447	.5731	.6089	.5731	.5014
10	.6984	.6626	.6805	.6268	.6805	.6268	.5552
11	.7701	.7343	.7522	.8238	.788	.6805	.6447
12	.788	.7701	.8596	.8238	.8238	.7701	.7343
13	.8238	.8775	.8775	.9492	.8775	.788	.7947
14	.8954	.9313	1.0029	.985	.8238	.8775	.8238
15	.8775	.9134	.9671	1.0029	.6984	.8417	.8417
16	.7522	.8417	.8596	.9313	.5373	.788	.7701
17	.8059	.788	.7522	.9492	.6984	.7522	.6447
18	.7164	.7522	.6984	.7701	.6268	.6805	.5729
19	.8059	.8059	.1433	.788	.7522	.8238	.6447
20	.8596	.9134	.8596	.8954	.8954	.8954	.8059
21	.9313	.8954	.985	.8596	.9313	.9134	.8059
22	1.0387	1.0029	.8954	.9134	.985	1.0387	1.1104
23	1.0745	1.0029	1.0566	1.0566	.9671	1.0208	
24	.985	1.0208	1.0208	1.0566	1.0208	.9492	1.0745
Max	1.0745	1.0208	1.0566	1.0566	1.0208	1.0387	1.1104
Min	.6089	.5552	.1433	.5731	.5373	.5552	.5014
Avg	.8432	.8374	.8208	.8634	.8044	.7925	.7914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 206 / 11 KV SVK MILK PLANT

HV Group Express Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1612	.128	.1463	.1254	.128	.128
2	.1463	.1254	.128	.1097	.1254	.128	.1463
3	.128	.1254	.128	.128	.1254	.128	.128
4	.128	.1254	.128	.1097	.1254	.128	.128
5	.128	.1254	.128	.1075	.1254	.1097	.128
6	.0732	.1254	.0732	.128	.1254	.1097	.1097
7	.1097	.1433	.0732	.128	.0716	.1097	.0732
8	.0914	.1075	.0914	.0914	.0895	.0914	.0732
9	.0914	.1075	.0914	.0914	.0716	.0914	.0732
10	.1646	.1612	.1646	.128	.1075	.1097	.0914
11	.1791	.1829	.2195	.1907	.1463	.1463	.128
12	.197	.2012	.2012	.197	.2195	.1463	.1097
13	.1791	.1646	.1646	.1612	.1646	.1829	.2012
14	.1791	.1646	.1646	.1791	.1829	.1829	.1646
15	.1612	.1463	.1646	.1612	.1646	.1463	.1829
16	.1612	.128	.1646	.1612	.1646	.1463	.1646
17	.1612	.1646	.1463	.1612	.1646	.1463	.128
18	.1433	.1463	.1463	.1433	.1097	.1463	.1463
19	.1433	.1463	.1463	.1387	.0732	.128	.1097
20	.1075	.128	.128	.1433	.128	.1463	.128
21	.1433	.1463	.128	.1254	.1463	.1463	.1829
22	.1433	.1463	.1463	.1433	.1646	.1829	.128
23	.1791	.1463	.1463	.1791	.1463	.128	.1463
24	.1463	.1254	.1646	.128	.1433	.1463	.1463
Max	.197	.2012	.2195	.197	.2195	.1829	.2012
Min	.0732	.1075	.0732	.0914	.0716	.0914	.0732
Avg	.1430	.1435	.1402	.1409	.1338	.1356	.1311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 207 / 11 KV SHINDHPURI AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4108	.3475	.3658			
2	.3658	.3734	.3475	.3658			
3	.3658	.3361	.3475	.3475			
4	.3658	.3361	.3292	.3475			
5	.3658	.3361	.3292	.3475			
6	.5121	.3361	.3292	.3475			
7	.3292	.3361	.3292	.3109			
8	.3292	.3361	.1829	.3475			
9	.3292	.3547	.3658	.3475			
10	.3475	.3547	.3658		.2772	.3292	.3475
11	.3547	.3292	.3658		.3292	.3658	.3841
12					.3841	.3841	.4572
13					.3658	.4207	.4938
14					.0914	.4207	.4572
15					.0914	.439	.4572
16					.3475	.4024	.439
17					.4024	.4024	.4207
24	.3658	.4108	.3475	.3658			
Max	.5121	.4108	.3658	.3658	.4024	.439	.4938
Min	.3292	.3292	.1829	.3109	.0914	.3292	.3475
Avg	.3664	.3542	.3323	.3493	.2861	.3955	.4321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 201 / 11 KV PAHELA-GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.3801	.3681	.3761	.3801	.3601
2	.3429	.2743	.3801	.3681	.3761	.3801	.3429
3	.3258	.2743	.3801	.3681	.3761	.3801	.3429
4	.3086	.2572	.362	.3681	.3582	.3258	.3258
5	.3086	.2229	.3439	.3506	.3224	.2896	.3086
6	.2401	.1715	.2353	.2534	.2865	.2534	.2401
7	.2058	.1715	.2172	.2218	.2507	.2172	.2058
8	.1715	.1715	.2172	.2195	.2328	.2172	.1886
9	.1715	.1991	.2534	.1991	.2686	.2058	.2353
10	.2058		.2835	.3292	.2865	.1886	.2507
11	.2229		.3189	.3224	.3045	.2058	
12	.2572	.4163	.3772	.2865	.2865	.2058	.2835
13	.2743	.4163	.3429	.3224	.2865	.2401	.2804
14	.2743	.362	.3121	.3045	.2865	.2743	.2804
15	.2572	.3258	.298	.2865	.2328	.2572	.2804
16	.2229	.3077	.2835	.2686	.1791	.2743	.2658
17	.2058	.2715	.2835	.2686	.197	.2743	.2172
18		.2353	.3012	.2865	.2149	.2743	.2353
19	.2401	.3292	.3189	.3439	.2865	.3086	.3189
20	.3258	.3658	.3544	.3761	.3403	.3258	.333
21	.3772	.4024	.3856	.394	.3582		.3801
22	.3772	.3982	.3856	.4119	.394		.3982
23	.3601	.3982	.3688	.4119	.394	.3429	.362
24	.3601	.3429	.3801	.3601	.3761	.3801	.3772
Max	.3772	.4163	.3856	.4119	.394	.3801	.3982
Min	.1715	.1715	.2172	.1991	.1791	.1886	.1886
Avg	.2773	.3010	.3235	.3204	.3030	.2819	.2962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 202 / 11 KV Wakeshwar Gaothan
feeder Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4024	.3772	.3658	.4066	.3429
2	.3086	.3086	.4024	.3772	.3658	.4066	.3086
3	.3086	.3086	.4024	.3772	.3658	.3696	.3086
4	.2915	.2915	.4024	.3772	.3658	.3326	.3258
5	.2743	.2743	.3841	.3429	.3292	.2587	.2915
6	.2401	.2401	.3109	.2686	.3109	.2402	.2572
7	.2401	.2058	.2743	.1867	.2561	.1829	.2058
8	.2058	.2401	.2378	.2378	.2195	.2195	.1886
9	.2058	.2561	.2865	.2561	.2378	.2058	.2353
10	.2229	.2378	.3045	.3109	.2743	.2229	.2686
11	.2229	.2926	.3045	.3582	.3292	.2743	
12	.3086	.3292	.4024	.362	.3658	.3258	.2534
13	.3258	.3292	.3688	.3841	.3475	.3086	.3429
14	.3429	.3292	.3688	.3841	.3292	.2915	.3429
15	.2743	.3109	.373	.3658	.2926	.2743	.3429
16	.2229	.2926	.3601	.3292	.2195	.2572	.2658
17	.2058	.2561	.2658	.3292	.2378	.2401	.2353
18		.2378	.3189	.3109	.2378	.2229	.2328
19	.2915	.2926	.3224	.3658	.3292	.3258	.3467
20	.4115	.3658	.3772	.4572	.4024	.3772	.3601
21	.4287	.4755	.4144	.439	.4024	.3944	.439
22	.4287	.439	.4144	.439	.4024	.4115	.4207
23	.3601	.4207	.3561	.4207	.4024	.3601	.4024
24	.3601	.3772	.4024	.3772	.3658	.4024	.3601
Max	.4287	.4755	.4144	.4572	.4024	.4115	.439
Min	.2058	.2058	.2378	.1867	.2195	.1829	.1886
Avg	.2967	.3106	.3524	.3514	.3231	.3046	.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 203 / 11 kv Nimgaon Feeder

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.1006	.1134	.1017	.116	.1372
2	.0857	.0857	.1006	.1134	.0995	.116	.12
3	.0686	.0857	.1006	.1134	.0995	.116	.12
4	.0686	.0686	.1006	.1134	.0995	.0995	.12
5	.0686	.0514	.0838	.1134	.0995	.0995	.12
6	.0686	.0514	.0671	.0983	.0829	.0995	.1029
7	.0686	.0514	.0724	.0663	.0829	.0838	.1029
8	.0686	.0514	.0671	.0819	.0663	.0838	.1029
9	.0686	.0671	.0819	.1006	.0829	.0686	.1067
10	.0686	.0838	.081	.1006	.0838	.0857	.1094
11	.0686	.0838	.0972	.1075	.0838	.0857	
12	.0686	.0838	.1107	.1075	.0838	.1029	.081
13	.0857	.0838	.112	.3521	.0838	.1029	.081
14	.0857	.0838	.112	.1006	.0838	.0857	.081
15	.0686	.0671	.112	.0838	.0838	.0857	.081
16	.0686	.0671	.112	.0671	.0671	.0857	.081
17	.0514	.0838	.0972	.0671	.0838	.0857	.0972
18		.0838	.081	.0838	.0838	.0857	.081
19	.0686	.0838	.1107	.1006	.1006	.1029	.096
20	.0857	.1006	.1107	.1006	.1174	.12	.1094
21	.0857	.1174	.125	.1006	.1341		.1174
22	.0857	.1174	.125	.1006	.1341		.1174
23	.0857	.1006	.125	.1006	.1341	.12	.1174
24	.0686	.1029	.1006	.112	.1006	.1174	.1372
Max	.0857	.1174	.125	.3521	.1341	.12	.1372
Min	.0514	.0514	.0671	.0663	.0663	.0686	.081
Avg	.0738	.0809	.0995	.1083	.0947	.0977	.1052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 204 / 11 kv WAKESHWAR-AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0171	.0312	.1029	.1107		
2	.0343	.0171	.0312	.1029	.1107		
3	.0343	.0171	.0312	.1029	.1107		
4	.0343	.0171	.0312	.1029	.1265		
5	.0343	.0171	.0469	.1029	.1265		
6	.0343	.0171	.0469	.1029	.1265		
7	.0343	.0171	.1524	.1638	.1581		
8	.0343	.0171	.0469	.1781	.1898		
9	.0343	.0156	.1509	.1875	.1581		
10	.0343	.0168	.1509		.1562	.0686	.0335
11	.0171	.0156	.1509		.1406	.12	
12					.0937	.12	.0671
13					.1094	.1372	.0671
14					.125	.12	.0671
15					.125	.1372	.0671
16					.125	.1372	.1134
17					.125	.12	.1619
24	.0343	.1524	.0312	.1017	.0937		
Max	.0343	.1524	.1524	.1875	.1898	.1372	.1619
Min	.0171	.0156	.0312	.1017	.0937	.0686	.0335
Avg	.0329	.0281	.0752	.1249	.1284	.1200	.0825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 205 / 11 KV PAHELA-AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0171	.0164		.0328
2	.0343	.0171	.0158		.0328
3	.0343	.0171	.0158		.0328
4	.0343	.0171	.0158		.0492
5	.0343	.0171	.0158		.0492
6	.0343	.0171	.0316		.0492
7	.0343	.0171	.0328		.0492
8	.0343	.0171	.0328		.0492
9	.0343	.0164	.0343		.0328
10	.0343	.0164	.0171		.0328
11	.0171	.0164	.0171		.0328
12					.0328
13					.0328
14					.0328
15					.0328
16				.0328	.0328
17				.0492	.0328
18				.0492	
19				.0492	
20				.0328	
21				.0328	
22				.0328	
23				.0328	
24	.12	.0171	.0164		.0328
Max	.12	.0171	.0343	.0492	.0492
Min	.0171	.0164	.0158	.0328	.0328
Avg	.0400	.0169	.0218	.0390	.0374

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 401 / 33 KV Adyal feeder INCOMER

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0802	1.1203	1.1831	1.0425	.9877	.9774
2	.9774	1.0288	1.2071	1.1831	1.0425	.9877	.9774
3	.9774	1.0288	1.2071	1.1831	1.0425	.9877	1.0288
4	.9774	.9774	1.262	1.2226	1.0425	.9877	.9774
5	.9259	.9774	1.3169	1.286	.9979	.9328	1.0288
6	.823	.8745	1.0974	1.1317	.9425	.8779	.823
7	.7716	.6173	.9877	1.1317	.7762	.9425	.7202
8	.7202	.7202	.7682	1.0425	.7133	.7133	.8745
9	1.0288	1.0425	.9671	.823	.823	.8745	.9522
10	.9774	1.1203	1.0802	1.0974	1.262	1.0802	.9328
11	1.0802	1.2883	1.1191	1.086	1.3169	1.1317	1.1831
12	1.0288	1.2883	1.1163	1.1403	1.2489	1.0288	1.0288
13	.9259	1.2883	1.0288	1.0317	1.1088	.9774	1.1163
14	.8745	1.2323	1.0562	1.0974	.9774	.9774	1.1043
15	1.1317	1.1763	1.0802	1.0974	1.0425	1.0288	1.1043
16	.7202	1.1763	.9991	1.2071	1.0974	1.0802	1.0517
17	.8745	.9774	.9882	.9328	.9328	1.0802	.8688
18	.823	.8145	.9665	.7133	.7133	.7202	.6836
19	.7716	.8779	.9665	.7682	.823	.9259	.9134
20	1.0802	.9877	1.0059		.8779	.9774	.9671
21	1.1317	1.0974	1.0682	1.1523	.9522		.9568
22	1.1317	1.1763	1.1065	1.1523	1.0082		.9134
23	1.0288	1.1763	1.1065	1.1523	1.0082	.8745	.9231
24	1.0288	1.0802	1.1763	1.2357	1.0974	.9877	.9259
Max	1.1317	1.2883	1.3169	1.286	1.3169	1.1317	1.1831
Min	.7202	.6173	.7682	.7133	.7133	.7133	.6836
Avg	.9516	1.0460	1.0749	1.0892	.9954	.9619	.9597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 200 / Station T/F

Station Trasformer Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0732	.0934	.2534	.0716	.0905	.0934	.2172
Max	.0732	.0934	.2534	.0716	.0905	.0934	.2172
Min	.0732	.0934	.2534	.0716	.0905	.0934	.2172
Avg	.0732	.0934	.2534	.0716	.0905	.0934	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 201 / 11 KV MANGLI FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0198	.0217	.0834	.6219		.6089
2	.0179	.0179	.0213	.0686	.6036		.5609
3		.0179	.0213	.0676	.5973		.5609
4	.0179	.0179	.021	.0686	.591		.5493
5	.0168	.0187	.0206	.0495	.4656		.5138
6	.0257	.0194	.0514	.0975	.3721		.3898
7		.0213	.0914	.1219	.3294		.333
8	.0297	.0187	.1029	.1858	.3086		.2713
9	.0198	.0137	.16	.1115	.2883		.2743
10			.1623	.3258	.1532	.1907	.2362
11	.0286		.1783	.3856	.2713	.2229	.2934
12		.4075		.5138	.1947		
13		.443		.5316	.2462	.2494	.2934
14		.4961		.3544	.153	.2526	.2972
15		.4607		.333	.2115	.2641	.2972
16		.3988		.298	.2559	.2347	.3374
17		.3222		.3944	.2559	.2494	
18		.3391		.3812		.3077	
19		.4298		.4477		.3681	
20		.6036		.5853		.5611	
21		.6401		.6036		.5973	
22		.6697		.6401			
23		.6516		.6401		.6516	
24	.0267	.0194	.0229		.0554		.6335
Max	.0297	.6697	.1783	.6401	.6219	.6516	.6335
Min	.0168	.0137	.0206	.0495	.0554	.1907	.2362
Avg	.0224	.2749	.0729	.3169	.3319	.3458	.4032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 202 / 11 KV DHAMNI- AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0514	.029	.0594			
2	.0663	.0526	.0434	.0579			
3	.0829	.0526	.0434	.0587			
4	.0663	.0526	.0434	.0743			
5	.0671	.0701	.0434	.0753			
6	.0995	.0671	.0579	.0924			
7	.0995	.0829	.0434	.0753			
8	.0829	.116	.0724	.0892			
9	.0995	.0995	.1014	.0869			
10	.1014	.1326	.0587		.0446	.0579	.0293
11	.1014	.0663	.0743		.0594	.1014	.0625
12					.0587	.1014	.0926
13					.0594	.1158	.1094
14					.0594	.0869	.128
15					.0579	.1158	.1341
16					.0587	.029	.1658
17					.088	.0869	
24	.0663	.0543	.029	.0594	.0446		
Max	.1014	.1326	.1014	.0924	.088	.1158	.1658
Min	.0663	.0514	.029	.0579	.0446	.029	.0293
Avg	.0834	.0748	.0533	.0729	.0590	.0869	.1031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 203 / 11 Kv Dholsar Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0221	.0221	.0373	.037			
2	.0217	.0213	.0377	.0377			
3	.021	.0213	.0373	.0377			
4	.021	.0206	.0377	.0377			
5	.0206	.0198	.0377	.0347			
6	.0217	.0213	.0377	.0373			
7		.021	.0554	.0366			
8	.0191	.0202	.0549	.0373			
9	.0183	.0217	.0549	.0366			
10	.0225	.128	.0503		.0373	.0373	.0332
11	.0251	.021	.056		.0366	.0358	.0332
12					.029		.0366
13					.0377	.0537	.0362
14					.0373	.0537	.0532
15					.0366	.0358	.0343
16					.037	.0358	.0358
17					.0366	.0358	.0358
24	.021	.0221	.0377	.0434	.0366		
Max	.0251	.128	.056	.0434	.0377	.0537	.0532
Min	.0183	.0198	.0373	.0347	.029	.0358	.0332
Avg	.0213	.0300	.0446	.0376	.0361	.0411	.0373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 204 / 11 KV ASGAON GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5792	.6268	.5316	.6219	.6154	.6089
2	.5144	.5611	.6089	.5316	.6036	.6154	.5792
3	.4973	.5611	.6089	.5258	.5973	.6154	.5609
4	.4854	.5611	.6089	.5201	.5973	.5973	.5493
5	.4382	.5249	.5731	.4854	.4656	.5611	.5316
6	.2774	.3721	.3856	.3772	.3721	.3721	.3898
7	.2401	.3506	.3086	.2629	.3294	.3086	.0175
8	.2204	.2883	.3258	.2279	.3086	.3292	.2713
9	.2401	.3018	.2915	.2279	.2883	.285	.2743
10	.2743	.2347	.333	.3258	.2915	.2507	.2629
11	.2774	.2012	.3721	.3856	.3258	.2865	.3467
12	.4207	.3988	.4887	.5138	.4161		.3988
13	.4477	.443	.5249	.5316	.208	.3582	.4557
14	.4835	.4961		.3544	.2254	.3224	.4382
15	.4477	.4607		.3366	.2572	.3224	.3506
16	.3988	.3988	.4607	.298	.2543	.2454	.333
17	.3258	.3222	.3506	.3944	.3772	.2229	.3121
18	.3018	.3391	.3121	.3812	.3113	.3077	.333
19	.4119	.4298	.4031	.4477	.4252	.3681	.4161
20	.5068	.6036	.5434	.5853	.5853	.5611	.4973
21	.5853	.6401	.5784	.6036	.5853	.5973	.5548
22	.6335	.6697	.6135	.6401	.6516	.6516	.5784
23	.6268	.6516	.5959	.6401	.6516	.6335	.5895
24	.5426	.5973	.6335		.6036	.6516	.6335
Max	.6335	.6697	.6335	.6401	.6516	.6516	.6335
Min	.2204	.2012	.2915	.2279	.208	.2229	.0175
Avg	.4216	.4578	.4795	.4404	.4314	.4382	.4285

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 205 / 11 KV KHAIRY-AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0777	.0869	.0846	.0834			
2	.0892	.0823	.0823	.0823			
3	.088	.0846	.0823	.0974			
4	.0903	.08	.0823	.096			
5	.0892	.0766	.0812	***			
6	.1158	.0777	.1067	.1204			
7	.1189	.0907	.1353	.1286			
8	.1303	.1036	.1353	.1448			
9	.1448	.1012	.1488	.1448			
10	.1296	.1166	.1353		.1054	.0892	.0206
11	.1353	.1276	.1269		.104	.0947	.12
12					.104		.1467
13					.104	.0777	.1488
14					.1014	.0789	.1509
15					.0293	.096	.1623
16					.0297	.1217	.1783
17					.0446	.1082	.1113
24	.0638	.088	.0869	.096	.104		
Max	.1448	.1276	.1488	11.2679	.1054	.1217	.1783
Min	.0638	.0766	.0812	.0823	.0293	.0777	.0206
Avg	.1061	.0930	.1073	1.2262	.0807	.0952	.1299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 207 / 11 KV ASGAON AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561		.2926	.39			
2	.3353		.2926	.4115			
3	.373		.2926	.407			
4	.3688		.2926	.407			
5	.39		.3109	.407			
6	.3856	.2614	.2402	.4755			
7	.4252	.2218	.2743	.4805			
8	.407	.2402	.3475	.4938			
9		.3142	.3841	.4755			
10	.3142	.4251			.4525	.362	.3658
11	.2427	.4251	.3511		.5121	.5121	.3696
12							.3881
13					.4435	.5792	.4066
14					.4435	.5973	.4066
15					.4251	.5792	.3696
16					.439	.5068	.4066
17					.4755	.4938	.3658
24	.3944	.2195	.2743		.4191		
Max	.4252	.4251	.3841	.4938	.5121	.5973	.4066
Min	.2427	.2195	.2402	.39	.4191	.362	.3658
Avg	.3629	.3010	.3048	.4386	.4513	.5186	.3848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST

Feeder No / Name : 208 / 11 KV DHAMNI - G feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	.5611	.543	.5611	.5487	.5487	.5487
2	.543	.5487	.5249	.5373	.5304	.5487	.5304
3	.5249	.5487	.5249	.5373	.5304	.5487	.5304
4	.5249	.5487	.5068	.5194	.5304	.5487	.5304
5	.4656	.4755	.4887	.3582	.4706	.5121	.4887
6	.2865	.2715	.3077	.2957	.2865	.3045	.3077
7	.2149	.2172	.2715	.2328	.2572	.2035	.2454
8	.2172	.2534	.2534	.181	.2254	.2254	.208
9	.2172	.2353	.2507	.197	.2454	.2534	.2347
10	.2896	.2172	.2686	.2481	.2865	.2896	.2507
11	.3077	.2715	.3224	.3224	.3045	.2896	.2896
12	.362	.3258	.362	.3982	.3582	.2896	.2715
13	.3982	.3801	.4572	.4344	.3761	.362	.362
14	.3801	.3801	.4525	.4344	.3582	.3801	.362
15	.3439	.3258	.3475	.3982	.2149	.3258	.3258
16	.2686	.3077	.2715	.3045	.2149	.2534	.2534
17	.218	.208	.2507	.2601	.2149	.2561	
18	.218	.2572	.2686		.2058	.2458	.2507
19	.3582	.362	.3403	.3761	.3721	.3681	.4477
20	.462	.5175	.5194	.5304	.5304	.499	.5014
21	.5544	.5729	.5973	.5359	.5544	.5729	.5552
22	.5853	.5853	.591	.5853	.567	.5853	.5373
23	.5853	.567	.5731	.567	.5304	.567	.5552
24	.5087	.543	.5611	.543	.5487	.5487	.567
Max	.5853	.5853	.5973	.5853	.567	.5853	.567
Min	.2149	.208	.2507	.181	.2058	.2035	.208
Avg	.3852	.3951	.4106	.4069	.3859	.3969	.3980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 201 / 11 KV PAUNA KH -AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0953	.0572	.0366	.0511	.0286
Max	.0953	.0572	.0366	.0511	.0286
Min	.0953	.0572	.0366	.0511	.0286
Avg	.0953	.0572	.0366	.0511	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 202 / 11 KV SHIVNALA-AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0316	.0316	.016	.0328	.0305
Max	.0316	.0316	.016	.0328	.0305
Min	.0316	.0316	.016	.0328	.0305
Avg	.0316	.0316	.016	.0328	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 203 / 11 KV BHENDALA-GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.8413	.8048	.8048	.8413	.8048	.7316	.8048
Max	.8413	.8048	.8048	.8413	.8048	.7316	.8048
Min	.8413	.8048	.8048	.8413	.8048	.7316	.8048
Avg	.8413	.8048	.8048	.8413	.8048	.7316	.8048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064039 / 132 KV GOSE KH SUBSTATION

Feeder No / Name : 401 / 33 KV PAUNI FEEDER

HV Express Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	3.4517	3.6008	3.7346	4.2798	3.8683	3.8009	3.9638
Max	3.4517	3.6008	3.7346	4.2798	3.8683	3.8009	3.9638
Min	3.4517	3.6008	3.7346	4.2798	3.8683	3.8009	3.9638
Avg	3.4517	3.6008	3.7346	4.2798	3.8683	3.8009	3.9638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 401 / 33 KV Lakhandur Feeder

HV Express Feeder

INCOMER Feeder KV- 33 / INCOMING

DATE	01-JUN-17
HR	Load (MW)
24	.9425
Max	.9425
Min	.9425
Avg	.9425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 402 / 33 KV Gose feeder INCOMER HV Group Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2768	3.1207	3.1727	3.7449	3.4328	3.1207	3.4328
2	3.2768	3.1207	3.1727	3.0167	3.2768	3.1207	3.4848
3	3.2247	2.8607	3.0687	3.0167	3.2247	3.1207	3.3288
4	3.1207	2.8086	3.0167	2.9647	3.1207	3.1207	3.2247
5	3.0167	2.4966	2.9127	3.3288	2.9647	2.8086	3.1207
6	2.1845	2.1325	2.2365	3.1207	2.7046	2.7046	2.7046
7	2.1845	1.9765	2.0285	2.8607	2.7046	2.4446	2.4446
8	2.0285	1.9244	2.0805	2.8607	2.7046	2.3405	2.4446
9	2.0805	2.0805	2.1325	2.9647	2.8086	2.4446	1.6124
10	2.5486	2.3926	2.2885	1.8724	2.3405	1.4563	1.9244
11	2.8607	2.6526	2.9647	2.4446	2.7566	2.6006	2.1845
12	3.1727	2.9127	3.4328	2.8607	2.8086	2.8086	2.8607
13	3.6928	3.5888	3.6408	2.8607	2.9647	2.9127	3.0687
14	3.7449	3.6928	4.0049	2.9127	2.8607	3.0687	2.9127
15	3.6928	3.5368	3.9009	2.9647	2.3405	2.8607	2.9647
16	3.6408	3.4328	3.4328	2.7566	2.3405	2.7566	2.6006
17	3.3808	3.2247	3.2768	2.6006	2.4446	2.4446	2.0285
18	3.2247	2.7566	3.2768	2.2365	1.9244	2.1325	1.4043
19	3.4328	3.3288	2.4966	2.3405	2.3926	2.5486	1.8724
20	3.3808	3.5368	2.8086	2.9647	3.1207	3.0687	2.1845
21	3.4848	3.2768	2.9647	2.7566	2.9127	2.8086	2.9127
22	3.7449	3.4328	3.1207	2.8086	3.0687	3.0687	3.0167
23	3.6408	3.5368	3.0687	3.0167	2.8607	2.9127	2.9647
24	3.2768	3.1727	2.9647	4.0049	3.4328	3.2768	3.4328
Max	3.7449	3.6928	4.0049	4.0049	3.4328	3.2768	3.4848
Min	2.0285	1.9244	2.0285	1.8724	1.9244	1.4563	1.4043
Avg	3.1381	2.9582	2.9777	2.8867	2.8130	2.7480	2.6721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 404 / 33 KV Kosara Feeder

HV Express Feeder

INCOMER Feeder KV- 33 /

INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1493	3.3665	3.5082	3.1361	3.0624	3.1699	3.083
2	3.2579	3.3665	3.4517	3.1161	3.0087	3.1699	3.0298
3	3.1493	3.3665	3.4865	3.0624	2.955	3.0624	2.7401
4	3.1493	3.3122	3.4865	3.0087	2.6606	3.0087	2.7401
5	2.9321	3.2036	3.3385	2.9012	2.6063	2.955	2.6578
6	2.4983	2.364	2.4394	2.0805	2.3388	2.1325	2.0805
7	1.9244	1.9244	2.1068	1.7804	1.4403	1.8313	1.7101
8	1.9033	1.5432	1.9033	1.6598	2.1091	1.989	1.6907
9	1.8004	1.6787	2.0805	1.7295	2.1874	2.0388	1.7695
10	1.9765	1.9765	2.4714	1.8724	1.8204	1.7295	1.5947
11	.7442	1.9982	2.4714	2.4714	2.0805	2.0576	2.2365
12	2.3663	2.0508	2.7869	3.0298	2.7869	2.4446	2.6006
13	2.7343	2.7869	2.9973	3.2956	2.7343	2.7046	2.8921
14	2.7343	2.7869	2.9973	3.4294	2.2634	2.7869	2.9447
15	2.6006	2.3663	2.8921	3.2579	1.7101	2.7343	2.6006
16	2.0856	2.2885	2.6006	2.8578	1.6598	2.4714	2.3663
17	1.933	2.1365	2.2634	2.572	1.7295	2.0348	1.7404
18	1.7404	1.9839	1.989	1.4563	1.1763	1.1088	.9522
19	2.2611	2.3663	1.8484	2.1845	1.8484	1.7364	1.9044
20	2.955	3.0624	2.8567	2.5766	2.7446	2.6886	2.6326
21	3.1699	3.3311	2.7349	2.3525	2.6326	2.9384	2.9384
22	3.2425	3.2425	2.9938	2.8829	2.9938	2.9384	2.6612
23	3.1361	3.1361	2.8829	2.5503	2.5503	2.8275	2.5503
24	3.5837	3.4751	3.2579	2.8475	2.8235	2.7938	2.8475
Max	3.5837	3.4751	3.5082	3.4294	3.0624	3.1699	3.083
Min	.7442	1.5432	1.8484	1.4563	1.1763	1.1088	.9522
Avg	2.5428	2.6297	2.7436	2.5880	2.3301	2.4730	2.3735

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION

Feeder No / Name : 405 / 33 KV Walni Feeder INCOMER

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.7842	.7762	.7865	.7282	.7842	.6722
2	.823	.7762	.7762	.7682	.7282	.7842	.7207
3	.8059	.7842	.7762	.823	.7282	.7842	.7842
4	.763	.7842	.7762	.7682	.7842	.7842	.7842
5	.7602	.7282	.7762	.7762	.7842	.7282	.7842
6	.6099	.5544	.0457	.6241	.499	.4887	.5601
7	.5693	.3801	.4784	.5087	.3801	.543	.4252
8	.547	.4887	.5487	.5533	.5373	.4252	.439
9	.6687	.439	.591	.5784	.5487	.4835	.5373
10	.6984	.4784	.631	.5847	.6722	.547	.6984
11	.7442	.4887	.691	.6447	.8688	.6516	.7059
12	.6516	.3258	.6584	.823	.8596	.8145	.7442
13	.7133	.6653	.7133	.8779	.9328	.9231	.8413
14	.6653	.6516	.7133	.7762	.7522	.8688	.7973
15	.7207	.6584	.6653	.7282	.5973	.7133	.7442
16	.591	.5784	.6099	.6722	.691	.7602	.5847
17	.499	.4481	.439	.5601	.691	.691	.5658
18	.5316	.4887	.3801	.4938	.4938	.5973	.3721
19	.5487	.6653	.5487	.6722	.6653	.6099	.5601
20	.7207	.7842	.7282	.9522	.8402	.8316	.679
21	.7207	.7842	.7545		.7842	.7762	.7282
22	.7842	.7842	.7842	.7842	.7842	.7842	.8402
23	.8316	.7762	.7762	.8402	.8402	.7762	.7842
24	.9568	.8779	.7762	.8871	.8871	.7282	.7842
Max	.9568	.8779	.7842	.9522	.9328	.9231	.8413
Min	.499	.3258	.0457	.4938	.3801	.4252	.3721
Avg	.6862	.6323	.6423	.7167	.7116	.7033	.6724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN

Feeder No / Name : 401 / 33kv Sihora

HV LIS Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3148	2.1605	2.364	3.1893	3.1893	3.0864	2.3663
2	2.3148	2.1605	2.364	3.0864	3.1893	3.0864	2.3663
3	2.3148	2.0576	2.3663	3.0864	3.1893	3.0864	2.3663
4	2.3148	1.8004	2.3137	3.0864	3.1893	3.0864	2.3663
5	2.1605	1.8004	2.1091	3.0864	3.1893	2.8292	2.1605
6	1.286	1.6461	1.2209	2.572	2.6749	2.4691	1.5947
7	1.0802	1.1317	1.2209	2.2634	2.572	2.2634	1.286
8	.5658	.6687	1.2346	2.2634	2.6749	2.3663	1.1831
9	.5144	.7716	1.2346	2.3663	2.6749	2.4691	1.1831
10		.823	1.3889	1.2226	1.3889	1.0802	2.1605
11		1.1191	1.5432	1.2757	1.749	1.0802	2.572
12	.823	2.0348	2.6749	1.7541	1.9547	1.0802	2.572
13	1.5432	2.34	2.9835	2.073	2.1605	1.1317	2.7778
14	2.572	2.9172	3.0864	2.2325		1.286	2.9835
15	2.3663	2.8166	2.8807	2.1794	1.0802	1.286	2.7778
16	.823	2.6155	2.6749	1.8073	1.0288	1.286	2.6749
17	1.3375	2.4417	2.572	1.4352	.9774	1.1831	2.0576
18	2.0576	2.2131	2.4691	1.382	1.1317	1.0802	1.286
19	2.4691	2.572	2.6749	2.1262	1.8004	1.5432	1.5432
20	2.8807	3.0864	2.572	2.6046	2.3663	2.2634	2.2634
21	2.0576	3.4328	2.6749	2.8172	2.5206	2.4177	2.572
22	2.8807	3.3288	2.7263	2.8172	2.5206	2.5206	2.572
23	2.8807	3.1207	2.572	2.6046	2.3663	2.4177	2.4691
24	5.1154	2.2634	2.364	3.2922	3.1893	3.0864	2.3663
Max	5.1154	3.4328	3.0864	3.2922	3.1893	3.0864	2.9835
Min	.5144	.6687	1.2209	1.2226	.9774	1.0802	1.1831
Avg	2.0306	2.1384	2.2619	2.3593	2.2947	2.0619	2.1884

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN

Feeder No / Name : 404 / 33 KV Nakadongari feeder

HV LIS Feeder

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8059	.8413	.823	1.4352	1.5415	1.4403
2	.7202	.8059	.8505	.7716	1.4198	1.5415	1.4403
3	.7202	.7522	.8505	.7802	1.4198	1.5249	1.4403
4	.7122	.7522	.7973	.7802	1.4352	1.5249	1.4403
5	.7122	.7522	.7973	.7802	1.4352	1.4723	1.4403
6	.4578	.4733	.5258	.5658	1.3289	1.3375	1.3889
7	.3561	.4207	.4115	.4161	1.262	1.3672	1.3889
8	.3601	.3681	.4161	.4115	1.3003	1.4198	1.4563
9	.3561	.4207	.4161	.4115	1.4198	1.4198	1.7164
10	.4115	.4733	.5201	.9882	.4733	.4207	.4115
11	.4161	.4681	.5201	.7442	.631	.4115	.463
12	.8059	.7716	.7202	1.2346	.7362	.4115	
13	.9568	.8745	.8505	1.5083	.7202	.463	.6173
14	.9568	.9671	.9362	1.4918	.5144	.4578	.6173
15	.9568	.9362	.9259	1.5432	.2572	.5087	.6173
16	.9568	.823	.8842	1.2483	.3601	.4578	.463
17	.7442	.8322	.9774	.7716	.4115	.407	.4115
18		.823	.9259		.4115	.4578	.4115
19	.631	.9568	1.0402	.7202	.6613	.6104	.6836
20	.7762	1.1694	.8842	.823	.763	.763	.8413
21	.8779	1.2226	.9259	.9259	.7716	.7122	
22	.8779		.9362	.9328	.763	.763	.8939
23	.8145	1.1694	.823	.8688	.763	.6613	.8322
24	3.2408	.8145	.8413	.8322	1.4352	1.5249	1.4243
Max	3.2408	1.2226	1.0402	1.5432	1.4352	1.5415	1.7164
Min	.3561	.3681	.4115	.4115	.2572	.407	.4115
Avg	.8082	.7762	.7757	.8858	.9220	.9242	.9927

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 207 / 11 KV Bagheda

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8145	.7619	.7701	.6805	.8238	.6268	.6984
2	.7421	.7701	.7522	.788	.8059	.6089	.6984
3	.724	.7701	.7522	.7701	.788	.5731	.6805
4	.7059	.7522	.6268	.7701	.7164	.5373	.6984
5	.7421	.7343	.5014	.788	.6626	.4656	.6089
6	.5611	.5194	.5194	.591	.591	.394	.4656
7	.4706	.4656	.4835	.4477	.5373	.3045	.4298
8	.4784	.4477	.4477	.5014	.5194	.2865	.394
9	.5493	.4656	.5373	.5014	.6089	.3224	.4477
10	.6379	.6268		.6089	.6626	.2507	.5552
11	.6344	.6626		.6984	.7343	.3761	.6268
12	.6687	.7343	.8596	.8059	.7701	.4298	.591
13	.7373	.7701	.9313	.8596	.8059	.4298	.6805
14	.7202	.7701	.8775	.8775		.4656	.5552
15	.3944	.788	.8238	.8954		.4119	.5552
16	.4287	.7164	.6984	.6984	.0716	.3403	.4477
17	.4115	.7164	.7343	.6626	.3045	.5731	.4835
18	.4207	.5194	.6268	.6984	.4298	.5552	.591
19	.6556	.591	.6268	.7164	.591	.6089	.6089
20	.7619	.7888	.8775	.9134	.7164	.7343	.788
21	.8328	.8596	.9134	.9313	.7164	.788	.8417
22	.815	.8596	.8954	.8954	.7522	.7701	.8238
23		.8059	.8059	.8596	.6626	.7343	.7701
24	.7888	.7619	.788	.788	.8238	.6447	.7164
Max	.8328	.8596	.9313	.9313	.8238	.788	.8417
Min	.3944	.4477	.4477	.4477	.0716	.2507	.394
Avg	.6390	.6941	.7204	.7395	.6407	.5097	.6149

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 208 / 11 KV Nakadongri G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	03-JUN-17
HR	Load (MW)
7	.5194
Max	.5194
Min	.5194
Avg	.5194

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 209 / 11 KV Dongri bz

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4377	1.4003	1.4377	1.475	1.4377	1.3817	1.4377
2	1.2346	1.3817	1.4563	1.4563	1.419	1.3443	1.3817
3	1.2696	1.363	1.3817	1.4377	1.3817	1.3256	1.363
4	1.1949	1.3443	1.307	1.4563	1.307	1.2696	1.3256
5	1.0829	1.3256	.9335	1.4377	1.2323	1.1576	1.2696
6	1.0082	.9709	1.0456	1.1763	1.1203	1.0456	1.1016
7	.8775	.9335	.9149	.9335	.9896	.9149	1.0456
8	.8962	.7282	.4668	.8589	1.0082	.5601	.9709
9	.9149	.8029	.5415	.7468	1.0082	.6161	.7095
10	.9896	.961		1.0082	1.1203	.6161	1.1203
11	.8131	1.1016	1.1389	1.1763	1.1763	.6219	1.1088
12	.8316	1.2883	1.4003	1.2323	1.307	.9511	1.2323
13	.961	1.419	1.3443	1.1016	1.3817	.823	1.251
14		1.3443	1.3817	1.3817	.6161	1.0269	1.1576
15	1.3491	1.6617	1.4563	1.363		1.1763	1.1203
16	1.2382	1.251	1.1949	1.0642	.8775	1.1949	1.0829
17	.8871	1.1763	1.1949	1.0082	.8962	1.1203	1.0829
18	.8686	.9335	1.1576	1.0269	.9149		1.1203
19	1.251	1.1203	1.5123	1.307	1.363		1.4563
20	1.531	1.531	1.7364	1.6804	1.587	1.5497	1.6991
21	1.587	1.6617	1.7551	1.6804	1.6244	1.587	1.7924
22	1.531	1.531	1.6057	1.6617	1.4003	1.643	1.7551
23			1.587	1.5684	1.419	1.5123	1.643
24	1.4784	1.4563	1.4563	1.5123	1.4937	1.4003	1.475
Max	1.587	1.6617	1.7551	1.6804	1.6244	1.643	1.7924
Min	.8131	.7282	.4668	.7468	.6161	.5601	.7095
Avg	1.1470	1.2473	1.2786	1.2813	1.2209	1.1290	1.2793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 210 / 11 KV Chikhala

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5281	.2829	.3772	.5847	.4715	.5658
2	.3772	.4904	.2829	.4527	.5281	.5281	.5093
3	.3584	.415	.2829	.3772	.5281	.3961	.4715
4	.3206	.3772	.2829	.3961	.4715	.3772	.4338
5	.2829	.3584	.2829	.3772	.3961	.3584	.3584
6	.2263	.3961		.3772	.3018	.3018	.3018
7	.3018	.2641	.2829	.3772	.3961	.3961	.2641
8	.2263	.2829	.3584	.3018	.3206	.3772	.3206
9	.5281	.2452	.8299	.7545	.6413	.7545	.6224
10	1.1317	.3018	.8865	1.094	1.0374	1.2637	1.1694
11	.6413	.3772	.7545	.5281	.547	.547	.4904
12	.8488	.3772	.7356	.8865	.7922	.8299	.4715
13	.8488	.3772	.811	1.094	.7167	.8299	1.0562
14		.2641	.6036	.8676	.5658	.7733	.6979
15	.3403	.3018	.3395	.2829		.3584	.2263
16	.2829	.3584	.3584	.3206	.3206	.3961	.3206
17		.2452	.7167	.811	.7733	.8676	.7167
18	1.094	.2829	.7922	.9619	1.0185	.9431	.8865
19	.8865	.2641	.7922	.6413	.8488	.7356	.6413
20	.4338	.2641	.7356	.3961	.3961	.3772	.5281
21	.5093	.2641	.6602	.547	.6602	.6413	.7167
22	.3772	.3206	.2641	.3395	.3772	.3772	.3206
23		.2263	.415	.3961	.3584	.3772	.3772
24	.3395	.3772	.3395	.3206	.3258	.3018	.3395
Max	1.1317	.5281	.8865	1.094	1.0374	1.2637	1.1694
Min	.2263	.2263	.2641	.2829	.3018	.3018	.2263
Avg	.5147	.3317	.5257	.5533	.5611	.5658	.5336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN

Feeder No / Name : 211 / 11 KV Nakadongari AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0133	.0128	.0137
2					.0133	.0128	.0137
3					.0133	.0128	.0137
4					.0133	.0131	.0137
5					.0133	.0131	.0137
6					.013	.0131	.0137
7					.0128	.0131	.0137
8					.0128	.0128	
9					.0128	.0135	.0137
10				.013			
11				.0133			
12	.0139	.0111		.0133			
13	.0191	.0111	.013	.0133			
14	.0114	.0111	.013	.0133			
15	.0118	.0011	.013	.0133			
16	.012	.0111	.013	.0135			
17		.0111	.013	.0135			
18	.0111	.0111	.013				
19	.012	.0111					
20	.0109	.0111					
21	.0112	.0095					
22	.0111	.0111					
23		.0111					
24					.0133	.0128	.0137
Max	.0191	.0111	.013	.0135	.0133	.0135	.0137
Min	.0109	.0011	.013	.013	.0128	.0128	.0137
Avg	.0125	.0101	.013	.0133	.0131	.0130	.0137

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 201 / 11 KV EMD

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0377	.0377	.0566
2	.0566	.0566	.0566	.0566	.0566	.0377	.0566
3	.0566	.0566	.0514	.0566	.0377	.0377	.0566
4	.0566	.0566	.0377	.0566	.0377	.0377	.0566
5	.0377	.0377	.0377	.0377	.0377	.0377	.0566
6	.0189	.0377	.0377	.0189	.0377	.0377	.0377
7	.0189	.0189	.0377	.0377	.0189	.0189	.0189
8	.0189	.0377	.0189	.0377		.0377	.0189
9	.0377		.0754	.0377	.0189	.0377	.0189
10	.0189	.0566	.0377	.0377	.0189	.0377	.0377
11	.0377	.0566	.0377	.0566		.0377	.0377
12	.0189	.0566	.1132	.0377			.0377
13	.0377	.1132	.0566	.1132		.0377	.0377
14	.0566	.0566	.0754	.0566		.0377	.0377
15	.0566	.0566	.0566	.132		.0377	.0377
16	.0377	.0754	.0754	.1132		.0189	.0943
17	.0377	.0377	.0377	.0566	.0189	.0943	.1132
18	.0189	.0377	.0189	.0566	.0943	.0189	.0943
19	.0566	.0377	.0377	.0566	.0943	.0377	.0377
20	.0566	.0377	.0566	.0377	.0377	.0377	.0377
21	.0566	.0377	.0566	.0377	.0377	.0377	.0377
22	.1509	.0377	.132	.1132	.0377	.0377	.0377
23	.132	.1132	.0566	.1132	.0377	.0377	.0377
24	.0566	.0943	.0566	.0566	.0377	.0377	.0566
Max	.1509	.1132	.132	.132	.0943	.0943	.1132
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0495	.0549	.0548	.0613	.0410	.0377	.0479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)

Feeder No / Name : 202 / 11kv Balapur

HV Group Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.3018	.2829	.3018	.2829	.2452	.2452
2	.2452	.3018	.2829	.3206	.2829	.2452	.2452
3	.2641	.2452	.2263	.2641	.2641	.2452	.2452
4	.2452	.2263	.2263	.2452	.2452	.2452	.2263
5	.2263	.2075	.1886	.2075	.2263	.1886	.2263
6	.1132	.1132	.132	.1132	.132	.0943	.132
7	.1132	.132	.1132	.1132	.1132	.0943	.0943
8	.0943	.0943	.0943	.1886	.1132	.132	.0943
9	.1132		.1132	.1886	.132	.1509	.0943
10	.1132	.1698	.1698	.1886		.1132	.0943
11	.1132	.1886	.1132	.1132		.1509	.1132
12	.1132	.2075	.2075	.1132			.132
13	.1509	.1698	.2263	.2452		.1698	.132
14	.1886	.1886	.1886	.1886			.1698
15	.1886	.1698	.1698	.1886		.132	.1509
16	.0943	.3395	.1698	.1132		.132	.1886
17	.1698	.3584	.1132	.1132		.0943	.1698
18	.132	.2829	.1509	.132	.1132	.1132	.132
19	.2263	.2075	.2075	.2263	.2263	.1509	.1698
20	.2829	.2829	.3206	.2829	.2452	.2075	.2641
21	.3018	.3018	.3206	.2829	.2829	.2263	.2829
22	.2641	.2641	.2641	.2641	.2829	.2641	.2452
23	.2641	.2641	.2829	.2641	.2641	.2452	.2452
24	.2829	.2829	.3018	.3206	.2452	.2452	.2452
Max	.3018	.3584	.3206	.3206	.2829	.2641	.2829
Min	.0943	.0943	.0943	.1132	.1132	.0943	.0943
Avg	.1894	.2304	.2028	.2075	.2157	.1766	.1808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 211 / 11 KV Sihora SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6118	1.5432	.8775	.8939	.8059	1.5432
2	1.5089	1.6118	1.5089	.8417	.8939	.8059	1.5432
3	1.5089	1.5223	1.5089	.8417	.8764	.8059	1.5432
4	1.406	1.5223	1.5089	.8059	.8413	.8059	1.5432
5	1.3717	1.3432	1.4232	.8059	.7888	.6859	1.3717
6	1.0288	1.2178	1.0288	.6447	.6836	.6344	1.166
7	.8573	.985	.9259	.5373	.631	.5658	.9602
8		.9313	.9259	.4973	.5784	.5316	.8745
9		.985	.8916	.5487	.5959	.6001	.8596
10		1.0974	.9945	1.1568	1.2483	.8402	.4835
11			1.0631	1.2445	1.5775	1.046	.6447
12		.6001	.6173	1.595	1.7661	1.0974	.6984
13	.9671	.8063	.7888	1.9105	1.9376	1.2174	.7164
14	.9492	.7802	.7716	1.9281		1.2174	.7522
15	.985	.8322	.7373	1.9456	1.2346	1.2346	.7164
16		.7975	.7164	1.2094	1.0288	1.2174	.6626
17	.6089	.6173	.6447	1.0692	1.0974	1.2517	.6268
18	.5194	.6001	.6268	1.0692	1.046	1.0802	1.0208
19	.6089	.6135	.6447	1.2445	1.5947	1.3375	1.4685
20	.8059	.8063	1.6118	1.595	1.989	1.8347	1.7013
21	.8954	.8939	1.7013	1.7002	2.0919	2.0062	2.1849
22	.8596	.823	1.7013	1.6827	2.1948	2.1776	2.1491
23	.8775	.823	1.6834	1.6827	2.0919	2.0748	2.1491
24	1.5089	1.6118	1.5432	.8775	.8939	.8402	1.5432
Max	1.5089	1.6118	1.7013	1.9456	2.1948	2.1776	2.1849
Min	.5194	.6001	.6173	.4973	.5784	.5316	.4835
Avg	1.0431	1.0188	1.1296	1.1797	1.2424	1.1131	1.2051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 212 / 11 KV Bapera SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9765	2.0595	2.1616	1.0924	.9745	.9214	2.0376
2	1.9765	1.7013	2.1616	1.0745	.9745	.9214	2.0376
3	1.9765	1.7013	2.1616	1.0745	.9745	.9214	2.0376
4	1.9071	1.5223	2.1262	1.0566	.9745	.9214	2.0376
5	1.647	1.3432	2.0199	1.0566	.9922	.8859	1.825
6	1.1269	.8954	1.0985	.8238	.7973	.7973	1.2757
7	.8322	.6805	.9568	.788	.7973	.7442	.8859
8	.4681		2.1826	.7973	.8505	.815	.9214
9	.3224		1.0277	.7973	.8764	.8859	.9671
10			.9568	.9745	1.1871	.6733	.7343
11			1.3112	1.1584	1.4529	.8328	.8775
12		.8764	.815	1.4661	1.7364	.8859	.9492
13		.815	.9745	1.6651	1.8427	.9745	.985
14	.788	.8682	.9745	1.7194		1.0099	1.0208
15	.7716	.7796	.9745	1.7896		1.0454	1.0029
16		.7265	.8954	1.3466	.7087	.9745	.8954
17		.695	.823	1.0631	.8328	.9568	.8596
18		.6024	.9492	.8505	.9036	.8328	.8059
19	.7343	.7265	.985	1.6301	1.6832	.9745	1.4864
20	1.0029	.9922	2.4177	2.3034	2.1262	2.1176	1.7551
21	.9134	1.0454	2.4177	2.4274	2.3211	2.2081	2.364
22	.8954	1.0099	2.3282	2.3388	2.1439	2.1616	2.2386
23	.8238	.9745	2.2207	2.1794	2.0199	2.0553	2.1491
24	1.9765	2.1132	2.1616	1.0924	.964	.9214	2.0376
Max	1.9765	2.1132	2.4177	2.4274	2.3211	2.2081	2.364
Min	.3224	.6024	.815	.788	.7087	.6733	.7343
Avg	1.1847	1.1064	1.5459	1.3569	1.2788	1.1016	1.4245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 213 / 11 KV Gondekhari SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	07-JUN-17
HR	Load (MW)
20	.8954
21	1.0029
22	.985
23	.9492
Max	1.0029
Min	.8954
Avg	.9581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 214 / 11 KV Silegaon SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.6447	.8573	.4835	.443	.4207	.8413
2	.8573	.6268	.823	.4656	.4252	.4207	.8413
3	.8573	.6268	.823	.4656	.4075	.4207	.8413
4	.7716	.5731	.823	.4656	.3898	.4207	.8505
5	.6859	.5373	.7545	.4656	.4252	.4031	.7442
6	.4458	.5014	.4287	.4298	.443	.4031	.4961
7	.3944	.394	.3772	.4298	.4607	.5609	.4075
8		.3582	.3856	.4031	.443	.5609	.3544
9		.3761	.3506	.3681	.4961	.5609	.394
10		.3761	.3506	.4075	.4908	.298	.3045
11		.3544	.4908	.4607	.5487	.3155	.2865
12		.443	.4382	.5493	.6001	.2804	.3045
13		.3544	.4908	.7087	.7202	.333	.3224
14		.4382	.4908	.6201		.3506	.394
15		.4115	.4908	.567	.3086	.4031	.394
16		.4031	.4477	.567	.3086	.3681	.4119
17	.3582	.3721	.4656	.443	.3155	.3856	.4298
18	.3403	.3155	.4298	.443	.2229	.3155	.3224
19	.3582	.4207	.4298	.7265	.6135	.5434	.5552
20	.4298	.4557	.5552	.8505	.7712	.7888	.5731
21	.4656	.4733	.5731	.8505	.8413	.8589	.9492
22	.4298	.4961	.5731	.8505	.8939	.8939	.9313
23	.4477	.4557	.5373	.8859	.8413	.8413	.8954
24	.8573	.6447	.8383	.4835	.443	.4557	.8413
Max	.8573	.6447	.8573	.8859	.8939	.8939	.9492
Min	.3403	.3155	.3506	.3681	.2229	.2804	.2865
Avg	.5704	.4605	.5510	.5579	.5154	.4835	.5703

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 215 / 11 KV Karkapur SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.5784	.5765	.4477	.3898	.3721	.5792
2	.5365	.5609	.5765	.4477	.3898	.3721	.567
3	.5365	.5609	.5765	.4298	.3898	.3721	.5792
4	.503	.4908	.5765	.4298	.3898	.3721	.5792
5	.4191	.4382	.463	.4298	.3898	.3544	.543
6	.2515	.3856	.2401	.4119	.3898	.3721	.362
7	.218	.298	.2401	.4031	.4252	.3544	.3012
8		.298	.2401	.3601	.4607	.3544	.2715
9		.2454	.2401	.3601	.4656	.3721	.2865
10		.2149	.2401	.2686	.3544	.2303	.3403
11		.2486	.2915	.3045	.3944	.2835	.4119
12	.1402	.3366	.2743	.394	.4733	.2303	.4656
13	.3155	.3898	.3944	.4656	.5487		.4298
14	.3681	.4252	.3772	.4835		.2658	.3224
15	.3155	.4075	.3601	.4835		.298	.4477
16	.2804	.4382	.3856	.3582	.2743	.2835	.4477
17	.2454	.4207	.4031	.3224		.2835	.4119
18	.3506	.333	.4207	.3224	.3189	.2835	.2328
19	.3155	.3506	.4207	1.379	.5316	.443	.4119
20	.3856	.3681	.5784	.6805	.5493	.5847	.4477
21	.3856	.4382	.5731	.7164	.6556	.5847	.6805
22	.4733	.4207	.5731	.6805	.6201	.6024	.6805
23	.4031	.4031	.5731	.6024	.5847	.567	.7164
24	.5365	.5784	.6001	.4477	.3898	.4075	.5792
Max	.5365	.5784	.6001	1.379	.6556	.6024	.7164
Min	.1402	.2149	.2401	.2686	.2743	.2303	.2328
Avg	.3758	.4012	.4248	.4846	.4469	.3758	.4623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064014 / 33 KV SIHORA S/STN

Feeder No / Name : 216 / 11 KV Chandpur SP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.3721	.362	.905
2	.3721	.362	.905
3	.3721	.362	.905
4	.3721	.362	.905
5	.3544	.3258	.7964
6	.2303	.2353	.5792
7	.2126	.1991	.4344
8	.1949	.1448	.3982
9	.2149	.1629	.4119
10	.5068	.3077	.1791
11	.6154	.3258	.2865
12	.7059	.3801	.2686
13	.724	.4525	.2686
14		.4525	.2507
15	.3801	.4706	.2686
16	.2896	.4344	.2149
17	.3439	.3801	.2149
18	.362	.3801	.3403
19	.7602	.6154	.6626
20	.9231	.8688	
21	.9593	.9593	
22	.9231	.9774	
23	.8688	.9231	
24		.3801	.905
Max	.9593	.9774	.905
Min	.1949	.1448	.1791
Avg	.5026	.4510	.5050

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 201 / 11KV Pathari G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8413	.8316	.8962	.924	.8596	.8145	.5914
2	.823	.8316	.8779	.9145	.8413	.7964	.5729
3	.823	.8048	.8688	.8869	.8589	.7783	.5487
4	.7865	.8048	.8326	.8779	.8589	.7602	.5544
5	.7865	.8048	.8413	.823	.8589	.7421	.5544
6	.5068	.5552	.5611	.6036	.6154	.5487	.4251
7	.4119	.4477	.4706	.4887	.5304	.4706	.3018
8	.3982	.4119	.4656	.4755	.4706	.4656	.2534
9	.4163	.4656	.4706	.4887	.5304	.4075	.4115
10	.4706	.5068	.5611	.5083	.5611	.4904	.5014
11	.4706	.543	.6154		.6335	.4706	.5552
12	.6584	.6516	.6447	.6089	.7602	.5249	
13	.7133	.6697	.724	.7265	.8048	.543	.7059
14	.7499	.7682	.6626	.788	.5973	.543	.6805
15	.7133	.6767	.5973	.7865	.4024	.5552	.6268
16	.6401	.567	.4656	.5304	.3898	.5552	.5552
17	.4525	.5487	.4656		.4382	.4075	.4656
18		.5487	.4163		.4733	.5028	.4458
19	.6154	.6626	.5434	.8145	.7545	.691	.6556
20	.7947	.8779	1.3575	.961	.8962	.8871	.9231
21	.8962	.9522	1.0164	1.0425	.9149	.8962	.9774
22	.8962	.9795	.9877	1.0059	.8688	.8869	
23	.8589	.9145	.924	.9328	.8596	.5853	.8775
24	.8413	.8589	.8869	.9145	.8326	.8145	.6099
Max	.8962	.9795	1.3575	1.0425	.9149	.8962	.9774
Min	.3982	.4119	.4163	.4755	.3898	.4075	.2534
Avg	.6767	.6952	.7147	.7668	.6922	.6307	.5815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064026 / 33/11 Nakadongari

Feeder No / Name : 203 / 11KV KAWALEWADA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6325	.7116	.8381
2					.6249	.7116	.828
3					.6249	.7343	.8436
4					.6009	.7253	.8436
5					.5792	.7407	.8436
6					.6401	.828	1.0082
7					.7099	.8592	1.1174
8					.8124	.933	1.247
9					.8223	1.0202	1.2793
10				.463			
11				.6401			
12	.2347	.2347	.1311	.7274			
13	.285	.3149	.1677	.8162			
14	.285	.3185	.3978	.8223			
15	.3185	.3353	.4191	.8421			
16	.3185	.3688	.4694	.7042			
17	.3149	.3768	.547	.7343			
18		.3768	.5533				
19	.0537	.3768	.5426				
20	.0412	.3277					
21	.0412	.3185					
22	.0417	.3185					
23	.0434	.3185					
24					.6554	.703	.8381
Max	.3185	.3768	.5533	.8421	.8223	1.0202	1.2793
Min	.0412	.2347	.1311	.463	.5792	.703	.828
Avg	.1798	.3322	.4035	.7187	.6703	.7967	.9687

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 201 / 11 KV SIHORA G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7095	.7468	.7207	.7095	.6767	.7095
2	.6908	.7095	.7468	.695	.6908	.6584	.7095
3	.6722	.6838	.695	.7095	.6838	.6584	.6653
4	.6535	.6653	.695	.6908	.6838	.6348	.6584
5	.6348	.6535	.6602	.6722	.6653	.6283	.6161
6	.4108	.4108	.3658	.3921	.4251		.4108
7	.2896	.3109	.3109	.2241	.3475	.1949	.2241
8	.2587	.2743	.3258	.2614	.3109	.1928	.2353
9	.3696	.3224	.3142	.3142	.3475	.2865	.2587
10	.3658	.3696	.3511	.3326	.4251	.2353	.2561
11	.3696	.3881	.4207	.3734	.499	.3258	.3881
12	.499	.4805	.5041	.4251	.4298	.3506	.4066
13	.5544	.5729	.5853	.5175	.5014	.3982	.4668
14	.5544	.5415	.5729	.5544		.3982	.462
15	.3403	.5175	.499	.5487		.362	.4066
16	.2054	.4251	.3696	.3881	.1307	.3109	.3734
17	.1791	.362	.2957	.2743	.2629	.2715	.3547
18	.2353	.3077	.2926	.2534	.2454	.1791	.2957
19	.462	.5041	.5175	.4854	.4938	.499	.439
20	.5601	.6036	.6979	.6535	.6283	.6224	.6036
21	.6767	.7733	.7545	.7095	.6653	.6979	.7023
22	.7207	.7842	.7655	.7682		.7842	.7392
23	.7282	.7468	.7468	.7392	.7392	.7468	.7655
24	.7095	.7095	.7468	.7468	.7468	.695	.7095
Max	.7282	.7842	.7655	.7682	.7468	.7842	.7655
Min	.1791	.2743	.2926	.2241	.1307	.1791	.2241
Avg	.4938	.5344	.5409	.5188	.5063	.4699	.4940

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 202 / 11 KV MOHADI G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7762	.8131	.8316	.8215	.7392	.7947
2	.7655	.7577	.7842	.8316	.811	.7207	.8029
3	.7468	.7577	.8215	.8215	.811	.7207	.7762
4	.7468	.7392	.8215	.8215	.7922	.7023	.7577
5	.6979	.7023	.7655	.7655	.7922	.6653	.7023
6	.5093	.4938	.5121	.5415	.5415	.4938	.462
7	.4108	.3658	.3801	.4668	.4294	.3841	.3292
8	.3547	.3506	.4477	.4668	.4294	.3403	.362
9	.3921	.3801	.4207	.4435	.4854	.3292	.3326
10	.4938	.5601	.4481	.4706	.4435	.3658	.5175
11	.4251	.5415	.6161	.5729	.5544	.499	
12	.5788	.5847	.6535	.5729	.6908	.6535	
13	.6602	.6838	.7655	.6838	.7655	.6722	
14	.7167	.679	.7468	.7023		.6161	.8686
15		.6468	.6908	.6838		.547	.6099
16			.5729	.5658	.3921	.4904	.5228
17	.2218	.4938	.5601	.5415	.3772	.4108	.4481
18	.4938	.4835	.5121	.499	.2829	.4066	.5788
19	.5601	.6219	.6219	.6224	.499	.5487	.7282
20	.6653	.7468	.7392	.7545	.5228	.6722	.8686
21	.7207	.8686	.823	.8865	.7207	.7207	.8962
22	.8402	.9055	.8686	.8962		.8316	.8775
23	.8215	.8589	.8589	.8962	.7762	.8131	.8686
24	.7842	.8029	.8316	.8316	.8589	.7577	.8131
Max	.8402	.9055	.8686	.8962	.8589	.8316	.8962
Min	.2218	.3506	.3801	.4435	.2829	.3292	.3292
Avg	.6087	.6435	.6698	.6738	.6094	.5875	.6627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 203 / 11 KV TUMSAR town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788	.788	.8238	.815	.8417	.7343	.7343
2	.7164	.7343	.8238	.7888	.8059	.6733	.7164
3	.6805	.7087	.7964	.7701	.7701	.6556	.6733
4	.6626	.6733	.7522	.7343	.7522	.6379	.6556
5	.6024	.6379	.6733	.6984	.7265	.631	.6024
6	.5375	.5784	.6201	.6447	.6135	.5375	.5548
7	.463	.5258	.5375	.5731	.5784	.4854	.4854
9	.583	.6001	.6241	.6201	.6661	.5487	.631
10	.7202	.6661	.788	.6135		.6068	.6733
11	.6935	.815	.8764	.7186	.8495	.6836	.7973
12	.9214	.9036	.9568	.7712	1.0029	.8238	.9114
13	.9492	.8954	.823	.8775	1.1104	.8063	.9036
14	1.0136	.9134	1.0099	.9412		.8505	.7545
15	.8764	.929	.9922	.9412	.7628	.815	.9492
16	.9114	.9189	.9568	.8954	.7712	.7265	.8505
17	.8495	.8328	.9214	.8596	.7362	.7888	.8775
18	.823	.7975	.8764	.8238	.7362	.7186	.7545
19	.8682	.8328	.9568	.8775	.8596	.8505	.8417
20	.8596	.8059	.9671	.9231	.8596	.8869	.9134
21	.7202	.7164	.8775	.8596	.7783	.7602	.8417
22	.7186	.7522	.7716	.8238	.7164	.7522	.8059
23	.7545	.8507	.8238	.8507	.7164	.8059	.7973
24	.788	.8238	.8417	.8059	.8417	.7522	.788
Max	1.0136	.929	1.0099	.9412	1.1104	.8869	.9492
Min	.463	.5258	.5375	.5731	.5784	.4854	.4854
Avg	.7609	.7696	.8300	.7925	.7855	.7188	.7614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 204 / 11 KV JAMB town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646	2.4646	2.6057	2.6886	2.4086	2.3285	2.3525
2	2.3712	2.3525	2.5766	2.6139	2.4272	2.2177	2.2131
3	2.2405	2.2361	2.5019	2.5133	2.4646	2.0883	2.1622
4	2.1472	2.1658	2.3655	2.4209	2.4272	2.0165	2.1098
5	1.9231	1.9605	2.8645	2.2218	2.2405	1.8298	1.8484
6	1.587	1.6632	1.7737	1.7924	1.8298	1.587	1.6244
7	1.2936	1.6244	1.5123	1.6617	1.4937	1.4377	1.419
9	1.4937	1.4969	1.6078	1.5181	1.643	1.2567	1.4937
10	1.5524	1.4937	1.5912	1.5123	1.7372	1.363	1.4003
11	1.6804	1.643	1.7364	1.587	1.8839	1.386	1.5497
12	1.848	1.7741	1.9418	1.9035	2.1068	1.4937	1.8858
13	2.0513	1.9959	2.3152	2.1658	2.384	1.4937	1.7741
14	2.1068	2.2361	2.4272	2.3339		1.5708	2.0538
15	1.6817	2.2731	2.3712	2.4025		1.46	1.9231
16	1.4969	2.1765	2.0538	2.2177		1.5339	1.7924
17	1.4784	1.885	1.8111	1.8111	1.1458	1.4969	1.531
18	1.3717	1.6644	1.6632	1.7372	1.5708	1.386	1.4003
19	1.5708	1.9231	2.0165	1.9044	1.8298	1.643	1.643
20	1.9231	2.1658	2.2405	2.2032	2.0538	1.9418	2.0351
21	2.0538	2.4459	2.4691	2.4459	2.2405	2.0182	2.5393
22	2.4326	2.6699	2.7633	2.6886	2.4646	2.3339	2.5393
23	2.6513	2.8193	2.8275	2.809	2.4646	2.5579	2.6337
24	2.5393	2.5503	2.6886	2.7905	2.7073	2.4832	2.4832
Max	2.6513	2.8193	2.8645	2.809	2.7073	2.5579	2.6337
Min	1.2936	1.4937	1.5123	1.5123	1.1458	1.2567	1.4003
Avg	1.9113	2.0730	2.2054	2.1714	2.0762	1.7793	1.9307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 205 / 11kv Sihora AGP

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3241	.3185	.3567
2					.3048	.3185	.3475
3					.2972	.3144	.3384
4					.2896	.3144	.3477
5					.3185	.333	.3338
6					.4089		.4172
7					.4001	.4755	.4633
8					.0572	.4572	.4344
9					.5093	.4458	.4967
10				.3269		.4515	
11				.4372			
12	.3121	.4161	.3715	.5155			
13	.4214	.4481	.4161	.5468			
14	.4254	.4428	.431	.5376			
15	.3948	.4428	.4607	.5468			
16	.4475	.4843	.4755	.463			
17	.4064	.4652	.4725	.5268			
18		.4311	.4666				
19	.2968	.3807					
20	.3125	.3715					
21	.3125	.3292					
22	.3125	.3384					
23	.3125	.3681					
24						.3437	.3506
Max	.4475	.4843	.4755	.5468	.5093	.4755	.4967
Min	.2968	.3292	.3715	.3269	.0572	.3144	.3338
Avg	.3595	.4099	.4420	.4876	.3233	.3773	.3886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 207 / 11kv HASARA

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5487	.5373	.5975	.5544	.5121	.5014
2	.4805	.5487	.5601	.5487	.5601	.4755	.5121
3	.4805	.5121	.5658	.5487	.5601	.4805	.4755
4	.4854	.5121	.5601	.5487	.5601	.439	.4706
5	.4481	.5121	.5281	.5228	.5228	.439	.439
6	.3292	.3326	.3224	.3734	.4066	.3292	.3292
7	.2614	.2957	.2454	.2987	.3361	.2561	.2534
8	.2957	.2957	.2835	.2987	.3361	.1829	.2507
9	.2926	.3326	.3155	.2987	.3326	.0732	.2926
10	.2957	.3326	.3582	.3361	.3696	.2561	.2896
11	.3734	.4252	.2896	.3361	.4066	.2481	.0724
12	.3982	.3982	.3258	.4805	.5228	.2804	.2587
13	.3982	.4706	.4108	.4805	.5014		.3696
14	.3982	.4706	.4024	.4805			.362
15		.439	.4481	.4854		.2835	.2926
16		.4024	.3734	.4481	.2614	.2804	.2957
17	.2172	.3658	.362	.2987	.1829	.3582	.1867
18	.2896	.2804	.3696	.3734	.2561	.2865	.2561
19	.4344	.4656	.4706	.4435	.4024	.4298	.3658
20	.543	.5014	.5975	.5544	.5121	.439	.4706
21	.5975	.5853	.543	.5914	.5853	.5121	.5121
22	.5914	.5853	.5853	.6283		.5175	.5544
23	.5975	.5601	.5975	.5975	.5487	.5121	.5121
24	.5228	.5601	.5487	.5853	.5914	.5121	.5487
Max	.5975	.5853	.5975	.6283	.5914	.5175	.5544
Min	.2172	.2804	.2454	.2987	.1829	.0732	.0724
Avg	.4189	.4472	.4417	.4648	.4433	.3683	.3697

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 208 / 11 kv GANDHINAGAR town

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.7372	1.885	1.8484	1.848	1.6632	1.7551
2	1.7002	1.7372	1.8671	1.9044	1.8111	1.5893	1.6975
3	1.6632	1.7002	1.8298	1.7924	1.7924	1.5524	1.643
4	1.6057	1.5893	1.773	1.7193	1.7177	1.4784	1.5524
5	1.4937	1.531	1.643	1.6263	1.6804	1.419	1.4415
6	1.2696	1.2323	1.2567	1.3443	1.3676	1.2197	1.2071
7	.9979	.9877	1.134	1.1576	1.1203	.9979	.9877
9	1.0719	1.0242	1.0974	1.0719	1.1458	.924	1.0082
10	1.0829	.9877	1.0608	1.0082		.924	1.0242
11	1.0082	1.0974	1.1203	1.1203	1.1458	.9145	1.0349
12	1.1706	1.1203	1.2696	1.2323	1.307	.9145	1.1946
13	1.2803	1.4266	1.4563	1.4563	1.4998	.9511	
14	1.4266	1.5154	1.5364	1.6057		1.0349	
15	1.134	1.4784	1.5154	1.6263		1.0242	1.4563
16	1.0242	1.4045	1.2936	1.4632	1.0456	1.0498	1.2936
17	1.0242	1.2936	1.1458	1.2323	.961	.9774	1.1458
18	.9877	1.0608	1.1203	1.1458	.961	.9511	.9979
19	1.0974	1.2437	1.307	1.2197	1.1088	1.1088	1.134
20	1.3169	1.39	1.4937	1.4415	1.2936	1.307	1.3817
21	1.4266	1.6057	1.5524	1.6263	1.4045	1.3817	1.5154
22	1.6804	1.8111	1.8111	1.8671		1.6221	1.7193
23	1.8298	1.9791	1.9959	1.9993	1.6263	1.8111	1.9044
24	1.848	1.7741	1.922	1.9791	1.885	1.7002	1.8107
Max	1.848	1.9791	1.9959	1.9993	1.885	1.8111	1.9044
Min	.9877	.9877	1.0608	1.0082	.961	.9145	.9877
Avg	1.3441	1.4229	1.4820	1.4995	1.4064	1.2398	1.3764

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 064034 / 33 KV TUMSAR

Feeder No / Name : 401 / 33 KV GOBARWAHI Feeder

Only one consumer of WW with HT-IV

Feeder KV- 33 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0807	3.0247	2.8235	3.2156	3.3265	2.7446	2.9081
2	3.0807	3.0807	2.9127	3.1602	3.1367	2.6886	2.9127
3	3.0807	2.9127	2.8292	3.1121	3.0247	2.5766	2.8275
4	2.9127	2.6886	2.7726	3.0556	2.9687	2.4646	2.7446
5	2.6326	2.5766	2.5789	2.9687	2.8567	2.4086	2.6886
6	1.9605	1.7924	1.7918	1.9805	2.1285	1.7924	1.9239
7	1.5684	1.5684	1.5746	1.6078	1.8296	1.4415	1.7541
8	1.6804	1.4563	1.3032	1.7741	1.9404	1.2323	1.7741
9	2.4949	1.5123	2.1176	1.6804	2.9938	2.1845	2.0302
10	3.1047	2.1845	2.6886	3.271	2.9384	2.2405	3.0178
11	2.4646	2.4143	1.8296	2.6337	5.156	2.0633	2.5503
12	2.7446	2.7692	3.2373	3.3048	2.8829	2.3594	2.6326
13	2.9127	2.7984	3.5288	3.77	3.1047	2.4143	3.1047
14	3.2156	2.4394	3.271	3.4374		2.4646	1.9605
15	1.7924	2.5206	2.7721	1.5684		2.0725	2.1068
16	2.2177	2.6612	2.4143	2.3525	1.2323	2.1948	2.1068
17	1.6804	2.6886	2.9938	2.7446	2.1068	1.6244	2.8006
18	2.0513	1.7375	2.9938	3.2487	2.8006	1.7193	2.9384
19	2.9127	2.4434	3.271	3.3265	3.3048	1.9204	.823
20	3.2487	2.9081	3.6037	3.4019	2.4646	2.9687	3.3265
21	3.2373	3.0727	4.0329	3.9363	3.5482	3.5288	3.9209
22	2.3594	3.1367	3.3265	3.4374		3.1121	3.1276
23	2.7984	1.7364	2.9938	3.1367	2.9127	2.8292	3.0247
24	3.0247	2.9081	2.7984	3.0247	3.0493	2.7446	2.9081
Max	3.2487	3.1367	4.0329	3.9363	5.156	3.5288	3.9209
Min	1.5684	1.4563	1.3032	1.5684	1.2323	1.2323	.823
Avg	2.5940	2.4597	2.7692	2.8812	2.8432	2.3246	2.5797

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 203 / 11 KV Betala G Feeder

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.1145	1.2003	.6201	.5658	.5847	.6001
2	1.0288	1.0288	1.2003	.6201	.5658	.5658	.5144
3	1.0288	1.0288	1.2003	.6201	.5487	.5658	.5144
4	1.0288	1.0117	1.2003	.6201	.583	.5658	.5144
5	1.0288	1.0117	1.2003	.6201	.5487	.547	.5144
6	.8573	.9774	1.2003	.6135	.3944	.3772	.3429
7	.9431	.9431	1.2003	.9745	.2743	.3018	.2572
8	.8573	.9945	1.2003	.8859	.3086	.2829	.2572
9	1.0288	1.0974	1.3146	1.0631	.2915	.2743	.2572
10	1.0631	1.1831	1.3146	1.3546	.3772	1.0117	1.2003
11	1.0802	1.2003	1.286	.9774	.4527	1.0288	1.4575
12	.3772	.4287	.4287	.4115	1.358	1.2003	
13	.4801	.4287	.5258	.4287	1.5278	1.2003	
14	.4287	.4287	.5144	.4973			
15	.3258	.4287	.4382	.4801	1.0374	1.3717	1.4022
16	.2229	.4115	.3429	.4115	1.1506	1.3717	1.3717
17	.2572	.3429	.3429	.3086	1.1694	1.286	1.4022
18	.2743	.3429	.3506	.3429	1.2449	.2572	.2572
19	.3944	.4287	.443	.4115	.415	.3429	.3506
20	.5316	.6001	.6135	.5487	.547	.5144	.5258
21	.5658	.6859	.6135	.6173	.5847	.5144	.5258
22		.6001	.6201	.6001	.5847	.6001	.6001
23	.5487	.6001	.6135	.583	.6036	.6001	.6001
24	1.6823	1.0974	1.2003	1.3146	1.2003	.5611	.6001
Max	1.6823	1.2003	1.3146	1.3546	1.5278	1.3717	1.4575
Min	.2229	.3429	.3429	.3086	.2743	.2572	.2572
Avg	.7419	.7673	.8569	.6636	.7102	.6924	.6698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 205 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	1.166	1.2403	1.2269	1.2003	1.3203	1.2003
2	.6001	1.1145	1.2269	1.267	1.2517	1.358	1.2003
3	.6001	1.1145	1.1393	1.1393	1.046	1.358	1.2003
4	.6001	1.1317	1.1393	1.1393	.9945	1.358	1.2003
5	.6001	1.0802	1.1393	1.1765	.9945	1.226	1.2003
6	.6001	1.0974	1.1393	1.1517	.9431	1.3203	1.1145
7	.6001	.9431	1.2269	1.2403	.9259	1.2637	.8573
8	.6001	1.0802	1.1765	1.086	.9431	1.1506	1.0288
9	.6001	1.2003	1.2269	1.0517	1.1831	1.2003	1.2003
10	.5316	1.2003	1.4899	1.1488	1.4146	1.3032	1.448
11	.5658	1.3717	1.4022	1.2346	1.4901	1.286	1.3146
12	.5658	1.2003	1.267	1.2174	1.3203	1.3717	1.086
13	.583	1.286	1.2403	1.2689	1.094	1.3717	1.1393
14	.6859	1.3717	1.3575	1.2689			1.4022
15	.9945	1.2003	1.3289	1.0802	.7545	1.1145	1.2403
16	1.0288	1.1145	1.448	1.2689	.7545	1.286	1.267
17	.5658	1.3717	1.4175	1.3032	1.226	1.286	1.2403
18	1.2003	1.1145	1.4022	1.3375	1.094	1.286	1.1393
19		1.2003	1.3289	1.3375	1.3957	1.286	.964
20	.9945	1.1145	1.3146	1.0974	1.3203	1.1145	.964
21	1.0288	1.0288	1.1765	1.2174	1.4146	1.1145	1.0517
22	1.2003	1.0288	1.1393	1.166	1.4712	1.2003	1.2003
23	.9945	1.0288	1.1393	1.0974	1.4901	.9431	1.1393
24	1.5336	1.166	1.2403	1.267	1.1488	1.358	1.2003
Max	1.5336	1.3717	1.4899	1.3375	1.4901	1.3717	1.448
Min	.5316	.9431	1.1393	1.0517	.7545	.9431	.8573
Avg	.7771	1.1553	1.2645	1.1996	1.1683	1.2555	1.1666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 206 / 11 KV UFIL

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.9774	.8573	.6135	.9774	.9242	.9431
2	.4287	.9431	.8573	.7973	.7545	1.094	.8573
3	.4287	.6859	.6859	.7973	.8059	1.094	.6859
4	.4287	.6859	.6859	.7011	.6516	.9054	.6859
5	.4287	.5658	.6859	.7011	.8573	.8676	.6859
6	.2572	.4973	.6001	.7087	1.0631	.7545	.4287
7	.6859	1.0288	.964	.964	1.2003	1.2637	.6001
8	.6001	1.0117	.9955	.8859	1.1488	1.2071	.4287
9	.7716	.9602	.964	1.0517	1.0974	.2401	.6001
10	.6344	1.2174	1.2403	1.3375	1.0374		.5258
11	.5658	1.0288	.964	1.3889	1.2637		.3506
12	.823	1.1145	1.1517	1.0974	1.094		.5258
13	.823	1.2003	1.0631	1.2517	1.3392	.8573	.2658
14	.7716	.7716	.6201	.6344	.7545		.3506
15	1.2517	1.1145	1.0517	1.1831	.6602	1.1145	.3506
16	.9774	1.2003	1.0517	1.0631	1.1128	.9431	.3506
17	.7202	.8573	.8764	.7888	.9997	1.2003	.3544
18	1.2689	1.286	1.0517	.8916	1.2449	1.0288	.362
19	1.0802	.9431	1.0517	.9945	1.2071	1.286	.6135
20	1.046	1.0288	.8764	.4458	1.1506	1.1145	.4382
21	1.1488	.6859	.8764	.9088	1.0185	.9431	.7011
22	.7716	.7716	1.0517	.9088	.9619	.7716	.6135
23	1.2003	1.1145	1.0517	1.0631	1.3014	1.0288	.8764
24	.2572	1.0117	1.0288	.6201	.9088	.8865	1.1145
Max	1.2689	1.286	1.2403	1.3889	1.3392	1.286	1.1145
Min	.2572	.4973	.6001	.4458	.6516	.2401	.2658
Avg	.7345	.9459	.9293	.9083	1.0255	.9763	.5712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 401 / 33 kv tumsar

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	10.5304	10.3624	10.7545	11.0345	11.5387	10.3064	10.3064
2	10.1943	10.1383	10.8076	10.6447	11.2026	9.8583	9.9703
3	9.8583	9.8023	10.4681	10.5864	10.8105	9.4662	9.8583
4	9.3542	9.2981	10.0154	10.3064	10.4681	9.1301	9.7022
5	8.7706	8.794	9.1478	9.9589	10.0154	8.514	8.7597
6	6.5535	6.653	7.0233	7.356	7.9784	7.0576	7.0965
7	5.5453	5.8253	5.7556	5.9877	6.9456	5.9934	6.0431
8	2.5766	2.3525	2.2565	2.8006	3.4728	2.5766	3.1047
9	6.9456	5.8253	6.4746	6.0985	8.1779	6.2174	6.5844
10	7.7298	6.6095	7.4291	8.0659	8.0659	6.7084	7.2074
11	7.4497	7.1879	6.9136	8.0659	8.738	6.5009	6.4866
12	8.7792	8.906	9.5222	3.271	9.425	7.0233	
13	9.4102	9.5359	10.8665	11.0345	10.4184	7.1136	
14	10.1943	9.7462	10.8111	11.1466	1.0534	7.0576	
15	6.4312	9.6342	10.1943	9.4496	.8962	6.7776	
16	6.7084	8.85	8.9621	9.3542	3.9769	6.5844	
17	6.31	8.5597	9.2421	8.906	6.0494	7.5057	
18	6.7776	7.1131	8.738	8.3459	7.0016	5.8162	
19	8.4019	8.6488	9.3696	9.2421	8.57	6.9856	
20	9.6342	9.7022	10.7545	10.1458	8.4019	8.738	
21	10.1383	10.8111	11.31	11.2546	10.0903	9.7325	
22	11.2026	11.6564	11.3146	11.4266	9.9143		
23	10.8105	11.4826	11.1991	11.3706	9.7577	10.3064	
24	13.443	10.5864	10.5899	11.2026	11.4266	10.4744	10.6424
Max	13.443	11.6564	11.3146	11.4266	11.5387	10.4744	10.6424
Min	2.5766	2.3525	2.2565	2.8006	.8962	2.5766	3.1047
Avg	8.4896	8.6701	9.1633	9.0440	8.0998	7.6715	7.9802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 402 / 33kv Jamb

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6292	2.6235	2.524	2.8395	2.3148	2.009	1.9982
2	2.6292	2.572	2.4691	2.8704	2.2634	1.9547	1.9982
3	2.6292	2.572	2.3663	2.9767	2.2119	1.9004	1.9456
4	2.524	2.3663	2.1033	3.083	2.2634	1.9004	1.9456
5	2.3137	2.1091	1.9982	3.1024	2.2119	1.7918	1.893
6	1.9982	1.9547	1.7878	2.524	1.8519	1.3032	1.4198
7	1.4198	1.8519	1.893	2.1033	1.3375	1.086	1.0517
8	1.9456	1.8519	1.893	1.8404	.9259	.9774	.9991
9	2.0508	2.0062	2.0508	2.073	1.4403	.9991	.9991
10	2.572	2.1033	2.1559	1.2346	2.2805	1.7878	1.3672
11	2.1605	2.1559	2.2325	1.3375	2.7692	1.2094	1.5775
12	1.5947	1.6301	1.701	1.6461	3.3665	1.3146	1.7878
13	1.9033	1.893	1.8604	2.1091	3.1493	1.4198	1.8404
14	1.8519	1.9456	1.9982	2.0576			1.5775
15	1.286	1.8404	1.8404	1.9547		1.4723	1.5249
16	1.286	1.5775	1.4883	1.286		1.3672	1.262
17	1.2346	1.4198	1.3672	1.3375	.6516	1.3672	1.1043
18	1.0802	.8413	1.3146	1.1831	.9231	1.1043	.9465
19	1.3889	1.3672	1.6478	1.4403	.8688	1.3672	1.3672
20	1.8004	1.893	2.0508	2.0062	1.7375	1.7353	1.8404
21	2.1091	2.2085	2.2857	2.1605	2.009	2.1033	2.0508
22	2.2634	2.3663	2.1559	2.2634	2.1176	2.1559	2.2085
23	2.2119	2.2085	2.2857	2.2634	2.009	2.1033	2.1794
24	5.4167	2.572	2.6818	2.9767	2.8292	2.009	2.0508
Max	5.4167	2.6235	2.6818	3.1024	3.3665	2.1559	2.2085
Min	1.0802	.8413	1.3146	1.1831	.6516	.9774	.9465
Avg	2.0958	1.9971	2.0063	2.1112	1.9777	1.5843	1.6223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 403 / 33 KV Kardi feeder

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8921	2.9321	2.7343	3.2956	2.2634	2.3348	2.2085
2	2.8921	2.8292	2.7343	3.2602	2.2634	2.3348	2.1033
3	2.8921	2.8292	2.7343	3.155	2.2119	2.2805	2.1033
4	2.8921	2.6749	2.6292	3.0498	2.2119	2.2262	2.1033
5	2.8395	2.4691	2.524	2.9767	2.1605	2.2262	2.0508
6	2.524	2.1605	2.4714	2.8704	1.8004	1.7918	1.7353
7	2.5766	2.1605	2.4714	2.8395	1.6461	1.6289	1.6301
8	2.6292	2.1605	2.3663	1.5775	1.8519	1.7375	1.3146
9	.9465	2.2119	2.3388	2.3137	1.8519	1.7353	1.6301
10	2.0576	2.3137	2.1559	1.4403	2.8778	1.7353	2.7869
11	2.572	2.4188	2.2085	1.5947	3.095	2.4714	3.3128
12	1.6975	1.5249	1.9136	1.749	2.7149	2.8921	3.2076
13	1.5947	2.1033	1.7353	1.9547	2.3891	2.9973	3.5231
14	1.6975	1.893	.5316	2.0576		2.9973	3.4179
15	1.4918	1.7878	2.073	1.9033	1.0317	2.9973	3.4705
16	1.3375	1.6827	1.9456	1.8004	1.4118	2.7263	2.6292
17	.3086	1.4918	1.8404	1.4918	2.4977	2.6818	2.6292
18	1.5432	1.4723	1.8404	1.4403	1.8461	1.6301	1.8604
19	1.9547	1.893	1.5249	1.6975	2.1176	1.6301	1.7541
20	2.1091	2.0508	2.1033	2.3663	2.3348	1.9982	2.1033
21	2.2634	2.2085	.631	2.4177	2.4434	2.0508	2.2085
22	.6687	2.2085	2.0199	2.3663	2.3891	2.3137	2.2611
23	1.6975	1.7878	2.2085	2.3148	2.4434	2.2085	2.3137
24	5.6899	2.5206	2.7343	3.5757	2.2634	2.3891	2.2085
Max	5.6899	2.9321	2.7343	3.5757	3.095	2.9973	3.5231
Min	.3086	1.4723	.5316	1.4403	1.0317	1.6289	1.3146
Avg	2.1570	2.1577	2.1029	2.3129	2.1790	2.2506	2.3569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

TUMSAR S/DN[382]

BU 2020

Substation No/ Name :- 067006 / 132 KV MADGI S/S

Feeder No / Name : 404 / 33kv sahuli

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4179	3.2602	3.4179	3.5757	3.035	3.095	3.155
2	3.4179	3.1893	3.4179	3.6145	2.9835	2.8778	3.155
3	3.4179	3.155	3.155	3.1024	3.2922	3.095	3.155
4	3.4179	2.9973	3.155	2.9447	3.2922	3.0407	3.1024
5	3.4705	2.8921	2.8921	2.7641	3.2407	2.8778	2.9973
6	2.4188	2.7343	2.5766	2.7869	3.1379	2.3348	2.1559
7	1.893	1.6827	1.8404	2.3663	1.6461	1.7375	1.9456
8	1.9982	1.8404	1.9456	1.7353	2.3663	1.8461	2.524
9	1.8404	.5784	2.4188	1.9136	2.6749	2.1033	2.2085
10	1.1043	1.7353	2.4188	1.2346	3.1493	1.7878	2.524
11	1.7353	1.893	2.4714	1.3375	3.3122	2.7869	1.262
12	2.2085	2.4714	2.5514	1.6461	3.9095	2.7343	2.7343
13	2.4714	2.2085	2.4714	1.8519	3.4751	2.6818	3.0498
14	2.7343	2.3137	3.5231	2.0576	3.3122	3.0498	3.3128
15	2.4714	2.1033	2.9767	1.9547	1.6832	3.2076	3.5082
16	2.0508	2.4714	3.9866	1.9547	2.9321	3.155	2.7343
17	2.1559	3.155	3.6808	1.5947	3.095	3.0498	2.6818
18	2.3663	2.9447	2.8921	1.5432	1.4118	1.9982	2.7343
19	2.2085	2.524	2.524	1.6975	2.2262	2.2085	3.2076
20	2.5766	2.8395	2.9973	2.1605	2.6063	2.8395	3.6283
21	2.7869	2.9973	3.1361	3.2407	2.9321	2.8921	3.6283
22	2.9973	3.3128	3.4551	3.2407	3.095	3.0498	3.786
23	3.5231	3.7334	3.7334	2.3148	3.2036	3.2602	3.7334
24	3.3653	3.4179	3.6283	3.7334	3.1379	3.1493	3.2602
Max	3.5231	3.7334	3.9866	3.7334	3.9095	3.2602	3.786
Min	1.1043	.5784	1.8404	1.2346	1.4118	1.7375	1.262
Avg	2.5854	2.6021	2.9694	2.3486	2.8813	2.7024	2.9243

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 201 / 11 KV LAKHANDUR FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.5975	.6097	.6287	.6287	.5906
2	.6097	.5716	.5975	.5716	.6287	.6287	.5716
3	.6097	.5335	.5975	.5716	.6097	.6097	.5525
4	.5716	.5144	.5975	.5716	.6097	.6097	.5335
5	.5335	.4954	.5415	.5335	.5716	.5144	.4954
8	.4382	.362	.4108	.4001	.4191	.4382	.362
9	.381	.4001	.3921	.362	.381	.362	.362
10	.4382	.4001	.4382	.4382	.4191	.381	.3772
11	.4763	.4382	.5144	.4763	.4382	.4382	.4572
12	.4954	.5716	.5525	.5716	.5525	.5144	.4715
13	.5525	.5716	.5906	.5906	.5906	.4954	.5281
14	.5716	.5906	.5906	.6097	.5716	.5525	.4904
15	.5716	.5716	.5906	.6287	.5525	.5525	.5415
16	.5716	.5335	.5525	.5906	.4572	.4763	.4668
17	.4954	.4763	.4954	.5335	.4572	.4191	.4294
18	.4954	.4527	.4763	.4954	.4763	.4191	.3921
19	.5335	.5601	.5525	.5525	.5716	.5144	.4763
20	.5716	.6097	.6287	.6287	.6097	.5525	.547
21	.5906	.5975	.6478	.6287	.6097	.5906	.5788
22	.6287	.6348	.6478	.6287	.6478	.6478	.6161
23	.6097	.6161	.6478	.5906	.6478	.6287	.6348
24	.6097	.5906	.5093	.6097	.6097	.6287	.6097
Max	.6287	.6348	.6478	.6287	.6478	.6478	.6348
Min	.381	.362	.3921	.362	.381	.362	.362
Avg	.5439	.5302	.5532	.5543	.5482	.5274	.5038

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 202 / 11 KV TEMBHARI AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381	.2801				.1715
2	.4763	.4001	.2801				.1905
3	.4763	.4001	.2801				.1905
4	.4763	.4191	.2801				.2096
5	.4382	.381	.3361				.2286
6	.4954	.4001	.4108				.2286
7	.4954	.4382	.5228				.2858
8	.5906	.4954	.5228				.3239
9	.381	.4001	.5601				.2477
10				.3048	.3048	.2477	
11				.4191	.4191	.4191	
12				.5144	.3429	.4382	
13				.5144	.4001	.4763	
14				.5335	.4191	.4763	
15				.5335	.4382	.4572	
16				.5335	.4382	.4572	
17				.5525	.4572	.4572	
24		.3429	.2829	.2477			
Max	.5906	.4954	.5601	.5525	.4572	.4763	.3239
Min	.381	.3429	.2801	.2477	.3048	.2477	.1715
Avg	.4784	.4058	.3756	.4615	.4025	.4287	.2307

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 203 / 11 KV PERSODI AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0934				.0762
2	.0381	.0572	.0934				.0762
3	.0381	.0762	.0934				.0762
4	.0381	.0762	.0934				.0762
5	.0381	.0953	.0934				.0762
6	.0953	.1334	.0747				.0762
7	.1524	.1524	.1494				.0762
8	.1524	.1905	.1494				.0754
9	.1524	.0572	.1509				.0762
10				.0953	.1143	.1334	
11				.1524	.1143	.1334	
12				.1524	.1334	.1524	
13				.1524	.1524	.1524	
14				.1524	.1524	.1524	
15				.1524	.1524	.1524	
16				.1905	.1524	.1524	
17				.1715	.1905	.1143	
24			.0373	.0381			
Max	.1524	.1905	.1509	.1905	.1905	.1524	.0762
Min	.0381	.0381	.0373	.0381	.1143	.1143	.0754
Avg	.0826	.0974	.1029	.1397	.1453	.1429	.0761

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 204 / 11 KV BARWA AG FEEDER (Ag dominated/Pure Ag
CHICHO Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0191	.0191	.0191	
2				.0191	.0191	.0191	
3				.0191	.0191	.0191	
4				.0191	.0191	.0191	
5				.0191	.0191	.0191	
6				.0191	.0191	.0191	
7				.0191	.0191	.0191	
8				.0191	.0191	.0381	
9				.0191	.0191	.0381	
10	.0381	.0191	.0381				.0191
11			.0381				
12			.0191				
13		.0191	.0191				
14		.0191	.0191				
15		.0191	.0191				
16		.0191	.0191				
17		.0191	.0381				
24	.0381				.0191	.0191	.0191
Max	.0381	.0191	.0381	.0191	.0191	.0381	.0191
Min	.0381	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0381	.0191	.0262	.0191	.0191	.0229	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 205 / 11 KV REST HOUSE Feeder Gaathan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.3429	.3239	.3239	.3239	.3048
2	.3429	.3048	.2858	.3239	.3239	.3239	.3048
3	.3429	.3048	.2801	.3048	.3048	.3048	.2858
4	.3239	.3048	.2801	.3048	.3048	.3048	.2858
5	.3048	.2858	.2829	.2667	.3239	.2858	.2667
6	.2286	.2286	.2427	.2286	.2477	.2286	.2286
7	.2286	.1905	.2241	.1905	.2096	.1905	.2096
8	.2096	.2096	.2054	.1715	.1905	.1334	.1905
9	.2286		.2241	.2286	.2096	.1524	.2096
10	.2286		.2477	.2286	.2096	.1524	.2096
11	.1905	.2477	.2096	.2096	.1524	.1143	.1905
12	.2096	.2858	.2286	.2286	.2286	.1524	.1143
13	.2286	.2858	.2477	.2477	.2667	.2096	.2096
14	.2477	.2286	.2477	.2667	.2667	.2096	.1905
15	.2286	.2096	.2477	.2477	.2477	.1905	.2286
16	.1905	.1715	.2096	.2286	.1524	.1524	.1905
17	.1715	.1715	.1715	.1905	.1715	.1334	.1905
18	.1524	.1698	.1715	.1905	.1715	.1524	.1334
19	.2286	.2641	.2477	.2667	.2667	.2286	.2286
20	.3048	.3239	.3239	.3429	.3239	.3048	.3048
21	.3429	.3174	.3429	.362	.3429	.3429	.3429
22	.362	.3361	.3429	.362	.3239	.3239	.3429
23	.3239	.3361	.3429	.3429	.3239	.3239	.3395
24	.3429	.3239	.3361	.3239	.3239	.3239	.3048
Max	.362	.3361	.3429	.362	.3429	.3429	.3429
Min	.1524	.1698	.1715	.1715	.1524	.1143	.1143
Avg	.2627	.2648	.2619	.2659	.2588	.2318	.2420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 206 / 11 KV SONI AG Feeder Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0953	.0762	.0762	
2				.0953	.0762	.0762	
3				.0953	.0762	.0953	
4				.0953	.0953	.0953	
5				.1334	.1143	.0762	
6				.1524	.1143	.0953	
7				.0953	.1524	.0953	
8				.1143	.1524	.1143	
9				.1524	.1334	.1143	
10	.0953	.1143	.0953				.0191
11	.1143	.1334	.0762				.0953
12	.1524	.1524	.0762				.1143
13	.1524	.1334	.1143				.1143
14	.1524	.1524	.1143				.1143
15	.1334	.1334	.1143				.1143
16	.1524	.1524	.1334				.1143
17	.1524		.1334				.1334
24	.0762				.0762	.0762	.0191
Max	.1524	.1524	.1334	.1524	.1524	.1143	.1334
Min	.0762	.1143	.0762	.0953	.0762	.0762	.0191
Avg	.1312	.1388	.1072	.1143	.1067	.0915	.0932

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 207 / 11 KV Parsodi Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1307	.1334	.1334	.1334	.1334
2	.1524	.1524	.1307	.1334	.1334	.1334	.1334
3	.1334	.1334	.1307	.1334	.1334	.1334	.1143
4	.1334	.1334	.1307	.1334	.1143	.1143	.1143
5	.1143	.1334	.1307	.1143	.1143	.1143	.1143
6	.0381	.0381	.056	.0381	.0572	.0572	.0572
7	.0572	.0381	.0747	.0381	.0572	.0572	.0572
8	.0572	.0381	.056	.0381	.0572	.0381	.0377
9	.0381	.0572	.056	.0572	.0572	.0572	.0572
10	.0572	.0381	.0381	.0762	.0381	.0572	.0572
11	.0762	.0572	.0762	.0762	.0381	.0762	.0762
12	.0762	.0953	.0953	.0762	.0762	.0762	.0762
13	.0953	.0953	.1143	.0953	.0953	.0762	.0762
14	.0953	.0953	.0953	.1143	.0762	.0572	.0762
15	.0762	.0762	.0762	.0953	.0572	.0572	.0762
16	.0381	.0572	.0762	.0762	.0381	.0381	.0572
17	.0381	.0381	.0381	.0762	.0572	.0381	.0381
18	.0381	.0566	.0572	.0572	.0381	.0572	.0381
19	.0762	.1334	.1334	.1143	.0953	.0953	.0762
20	.1334	.1524	.1524	.1524	.1334	.1334	.1143
21	.1524	.168	.1524	.1524	.1524	.1524	.1524
22	.1524	.168	.1524	.1524	.1524	.1334	.1524
23	.1524	.1494	.1143	.1334	.1334	.1334	.1524
24	.1524	.1524	.1494	.1334	.1334	.1334	.1334
Max	.1524	.168	.1524	.1524	.1524	.1524	.1524
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0377
Avg	.0953	.1004	.1007	.1000	.0905	.0897	.0905

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 208 / 11 KV Barwha Gaothan Gaothan Feeder
 (CHICHOLI Feeder KV- 11 /
 OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2241	.2286	.2286	.2286	.2286
2	.2286	.2286	.2286	.2286	.2286	.2286	.2286
3	.2286	.2096	.2263	.2286	.2286	.2096	.2286
4	.2096	.2096	.2263	.2096	.2096	.2096	.2096
5	.2096	.1905	.2054	.1905	.2096	.1905	.2096
6	.1334	.1143	.1307	.1143	.1143	.1143	.1334
7	.0572	.0953	.112	.0953	.1143	.1143	.1143
8	.0762	.0953	.1132	.0762	.1143	.1143	.1143
9	.1334	.0762	.0934	.0953	.1143	.0762	.1143
10	.1143	.0572	.1143	.0953	.0953	.0762	.1132
11	.1334	.0572	.1334	.1143	.0953	.1143	.1132
12	.1334		.1334	.1524	.1334	.1143	.1334
13	.1143		.1524	.1715	.1524	.1143	.1334
14	.1334	.1334	.1524	.1905	.1334	.1143	.132
15	.1143	.1334	.1524	.1524	.1143	.1143	.1334
16	.1143	.1143	.0953	.1334	.0953	.1334	.1143
17	.0953	.1143	.0762	.1143	.1143	.1334	.0754
18	.0953	.112	.1143	.1143	.1143	.1143	.0953
19	.1334	.1871	.1715	.1905	.1905	.1715	.1715
20	.1905	.2452	.2286	.2286	.2477	.2096	.2096
21	.2477	.2427	.2286	.2286	.2477	.2477	.2096
22	.2477	.2427	.2286	.2286	.2477	.2477	.2286
23	.2286	.2241	.2286	.2286	.2286	.2286	
24	.2286	.2286	.2241	.2286	.2286	.2286	.2286
Max	.2477	.2452	.2286	.2286	.2477	.2477	.2286
Min	.0572	.0572	.0762	.0762	.0953	.0762	.0754
Avg	.1596	.1609	.1664	.1683	.1667	.1604	.1597

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 209 / 11 KV Soni Gaothan Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4763	.4481	.4763	.4572	.4572	.4572
2	.4572	.4572	.4481	.4572	.4572	.4572	.4572
3	.4572	.4382	.4481	.4572	.4572	.4382	.4382
4	.4572	.4382	.3547	.4572	.4763	.4382	.4191
5	.4191	.4191	.3547	.4191	.4572	.4191	.4191
6	.2286	.2286	.2241	.2096	.2286	.2286	.2477
7	.2096	.1715	.1867	.1715	.1905	.1715	.2096
8	.1905	.1715	.1867	.1715	.1905	.2096	.1905
9	.1905	.1905		.1905	.1524	.2096	.1905
10	.2667	.1715	.2286	.2858	.1715	.2096	.2801
11	.3239	.2477	.2858	.3429	.2667	.2477	.3018
12	.3048	.381	.3429	.4191	.4382	.2667	.3547
13	.362	.4191	.381	.4191	.4001	.2667	.3584
14	.381	.381	.381	.4191	.381	.2858	.3772
15	.3429	.3429	.362	.4954	.381	.2286	.4108
16	.3429	.3429	.2858	.381	.2096	.2096	.3734
17	.381	.2667	.2858	.381	.2096	.1905	.3734
18	.2286	.2829	.3048	.3429	.2286	.2096	.2241
19	.362	.4108	.4382	.4572	.4191	.3239	.3361
20	.4572	.4954	.5335	.5144	.5144	.5335	.4854
21	.5335	.4854	.5144	.5144	.5525	.5716	.4854
22	.4954	.4904	.4954	.5144	.4954	.5335	.4854
23	.4763	.4854	.4954	.4954	.4763	.4954	.2241
24	.4572	.4763	.4481	.4763	.4572	.4572	.4954
Max	.5335	.4954	.5335	.5144	.5525	.5716	.4954
Min	.1905	.1715	.1867	.1715	.1524	.1715	.1905
Avg	.3659	.3613	.3667	.3945	.3612	.3358	.3581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 210 / TEMBHERI GAUTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0187	.0191	.0191	.0191	.0191
4	.0191	.0191	.0189	.0191	.0191	.0191	.0191
5	.0191	.0191	.0189	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191		.0191	.0191	.0191
7		.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0187	.0191	.0191	.0191	.0187
9	.0191	.0191	.0187	.0191	.0191	.0191	.0187
10	.0191	.0191	.0191	.0191	.0381	.0191	.0191
11	.0572	.0191	.0191	.0191	.0191	.0191	.0191
12	.0572	.0191	.0191	.0191	.0572	.0191	.0191
13	.0381	.0191	.0191	.0191	.0191	.0572	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.0191	.0191	.0191
16	.0381	.0191	.0191	.0191	.0572	.0191	.0191
17	.0191	.0191	.0572	.0191	.0191	.0191	.0191
18	.0191	.0377	.0381	.0191	.0191	.0191	.0191
19	.0191	.0187	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0189	.0191	.0191	.0191	.0191	.0191
22	.0191	.0189	.0191	.0191	.0191	.0191	.0191
23	.0191	.0189	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0189	.0191	.0191	.0191	.0191
Max	.0572	.0377	.0572	.0191	.0572	.0572	.0191
Min	.0191	.0187	.0187	.0191	.0191	.0191	.0187
Avg	.0241	.0198	.0214	.0191	.0231	.0207	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 201 / 11 KV VIRLEE AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.216	.2134		
2				.216	.2134		
3				.216	.2286		
4				.2281	.2286		
5				.2401	.2572		
6				.2401	.3001		
7				.2641	.3286		
8				.2761	.1334	.1063	
9				.2761	.1334	.1299	
10	.161	.1684	.1991				.3269
11	.1829	.1814	.2172				.2298
12	.1981	.2073	.2172				.2462
13	.2229	.2202	.2515				.1684
14	.2477	.2332	.2629				.1787
15	.2724	.2332	.2401			.2267	.176
16	.2724	.2462	.2401			.2267	.2332
17	.2724	.2601	.2743				.2462
24	.1505				.1943		.161
Max	.2724	.2601	.2743	.2761	.3286	.2267	.3269
Min	.1505	.1684	.1991	.216	.1334	.1063	.161
Avg	.2200	.2188	.2378	.2414	.2231	.1724	.2185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 202 / 11 KV GOURALA AG FEEDER Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4475		.253				.2229
2	.4475		.25				.2229
3	.4475		.253				.2229
4	.4475		.2347				.2229
5			.2347				.2378
6	.5155		.3311				.2559
7	.5312	.3041	.3913				.2896
8	.5468	.3121	.4515				.2591
9	.5624	.3121	.4877				.2743
10		.3311		.3185	.4012	.3144	
11		.3311		.4607	.3506		
12				.5535	.5182		
13				.5376	.4049		
14				.5218	.4534		
15	.3795			.5535	.4534	.5937	
16				.5535	.4049	.4687	
17				.5761	.4218	.4531	
24		.3161	.2949	.2858			
Max	.5624	.3311	.4877	.5761	.5182	.5937	.2896
Min	.3795	.3041	.2347	.2858	.3506	.3144	.2229
Avg	.4806	.3178	.3182	.4846	.4261	.4575	.2454

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 203 / 11 KV Kiramati AG Feeder Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1067	.0533	.0257				.0777
2	.1067	.0533	.0257				.08
3	.1067	.0495	.0257				.08
4	.1067	.0495	.0257				.08
5	.1067	.0619	.0343				.08
6	.0934	.0619	.0343				.0934
7	.1067	.0581	.0429				.1143
8	.1067	.0581	.0629				.1286
9	.1067	.0581	.0734				.1143
10				.0884	.1067		
11				.1036	.1867		
12				.1143	.16		
13				.1286	.1334		
14				.1286	.1467		
15				.1429	.1467	.0934	
16				.1572	.1334	.1067	
17				.1572	.1334	.12	
24		.0533	.0372	.0619			
Max	.1067	.0619	.0734	.1572	.1867	.12	.1286
Min	.0934	.0495	.0257	.0619	.1067	.0934	.0777
Avg	.1052	.0557	.0388	.1203	.1434	.1067	.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 204 / 11 KV Kiramti Gaothan

Gaothan Feeder

Feeder Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.1494	.132	.1509	.132	.132
2	.1509	.132	.1494	.132	.1509	.132	.132
3	.1509	.132	.1494	.132	.132	.132	.132
4	.1494	.132	.1509	.132	.132	.132	.132
5	.132	.1132	.1307	.1132	.132	.132	.1132
6	.0754	.1132	.0934	.0754	.0943	.0943	.0934
7	.0566	.0566	.0747	.0566	.0566	.0566	.0566
8	.0566	.0566	.0566	.0566	.0566	.0566	.0566
9	.0566	.0566	.056	.0566	.0566	.0566	.0377
10	.0566	.0566	.0754	.0566	.0566	.0566	.0377
11	.0747	.0566	.0754	.0754	.0566		.0566
12	.0934	.0754	.0943	.0943	.0754		.0754
13	.0934		.0943	.1132	.0943		.0943
14	.0934	.0943	.1132	.1132	.0943		.0943
15	.0943	.0943	.0943	.0747	.0566	.0566	.0754
16	.0747	.0754	.0754	.0754	.0377	.0189	.0566
17	.0566	.056	.0566	.0566	.0566	.0377	.0566
18	.0566	.0566	.0566	.0566	.0566	.0566	
19	.0943	.0754	.0943	.0754	.0943	.0754	
20	.1132	.1509	.132	.1132	.132	.1132	.1132
21	.132	.1494	.132	.132	.1509	.1132	.132
22	.1509	.1509	.1509	.1494	.1509	.132	.1509
23	.1509	.1494	.1509	.1509	.132	.132	.1509
24	.1509	.132	.1494	.1509	.1509	.132	.132
Max	.1509	.1509	.1509	.1509	.1509	.132	.1509
Min	.0566	.056	.056	.0566	.0377	.0189	.0377
Avg	.1027	.0999	.1065	.0989	.0982	.0924	.0960

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 205 / 11kv virli Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.4108	.5041	.4108	.5041	.4108	.4854
2	.5041	.4108	.5041	.4108	.4854	.4108	.4668
3	.5041	.3734	.5041	.3921	.4854	.3734	.4668
4	.5041	.3734	.4668	.3734	.4668	.3734	.4294
5	.4481	.3361	.4294	.3361	.4481	.2987	.3921
6	.2614	.3361	.2614	.2614	.2987	.2427	.2987
7	.2241	.1494	.2427	.2241	.1698	.1494	.168
8	.2801	.1494	.2614	.1867	.2058	.1867	.2241
9	.2987	.2241	.2614	.2614	.2614	.2614	.1867
10		.2614	.3734	.3361	.3395	.2987	.2427
11	.3734	.2987	.3547	.4108	.3547		.2987
12	.4294	.3361	.3361	.4854	.3547		.3734
13	.3921	.3361	.3547	.4481	.3921		.3547
14	.1494	.3361	.3921	.4481	.3734		.3734
15	.3361	.3174	.3921	.3921	.2987	.3174	.2987
16	.3734	.2987	.3921	.3734	.2241	.2987	.2987
17	.3734	.2987	.3174	.3734	.2801	.3361	.3547
18	.2801	.2987	.3547	.3361	.3174	.2614	
19	.3921	.3734	.4108	.3921	.3361	.4108	
20	.5228	.5041	.4668	.4481	.4294	.5041	.4481
21	.5228	.5228	.5228	.4854	.4854	.5041	.5228
22	.5041	.5228	.5228	.5041	.5228	.5228	.5228
23	.4854	.5041	.5041	.5228	.4854	.5228	.5228
24	.5041	.4668	.5041	.4481	.5041	.4668	.4854
Max	.5228	.5228	.5228	.5228	.5228	.5228	.5228
Min	.1494	.1494	.2427	.1867	.1698	.1494	.168
Avg	.3986	.3516	.4014	.3859	.3760	.3576	.3734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385]

BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 206 / GAWARADA GAUTHAN

Gauthan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734		.3734	.3361	.3547	.3361	.3547
2	.3734		.3734	.3361	.3547	.3361	.3547
3	.3734		.3734	.3361	.3547	.3361	.3547
4	.3734	.2241	.3734	.2987	.3547	.2987	.2987
5	.3361	.2241	.3361	.2614	.3361	.2614	.2614
6	.2054	.1867	.2054	.2241	.2427	.2241	.2241
7	.1867	.112	.168	.1867	.168	.1494	.1494
8	.1307	.112	.1494	.1494	.1494	.1307	.112
9	.112	.112	.1494	.1307	.1494	.0934	.0747
10	.1307	.1494	.168	.2054	.168	.0934	.0747
11	.1494	.1867	.2427	.2427	.168		.1307
12	.2614	.2427	.2801	.2801			.2614
13	.2801		.2801	.2987	.2427		.2614
14	.2614	.2427	.2614	.3174	.2801		.2614
15	.2614	.2241	.2987	.2427		.168	.2054
16	.2241	.2054	.2427	.2241	.1494	.112	.1494
17	.1494		.168	.1867	.168	.0934	.2241
18	.168	.2054	.2241	.1867	.2241	.112	
19	.2614	.2614	.2801	.2427	.2614	.2614	
20	.3174	.4108	.3734	.3174	.3547	.3547	.3734
21	.3547	.4294	.3921	.3547	.3921	.3547	.3921
22	.3734	.4294	.4108	.3734	.4108	.3734	.4108
23	.3547	.3921	.3734	.3734	.3734	.3734	.3921
24	.3734	.3361	.3734	.3547	.3547	.3547	.3547
Max	.3734	.4294	.4108	.3734	.4108	.3734	.4108
Min	.112	.112	.1494	.1307	.1494	.0934	.0747
Avg	.2661	.2467	.2863	.2692	.2733	.2409	.258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 201 / 11 KV Barwaha Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0154	.0151	.0579				.0139
2	.0156	.0147	.0282				.0137
3	.0156	.0147	.0282				.0137
4	.0158	.0149	.0282				
5	.0162	.0141	.0282				
6	.0162	.0137	.0724				
7	.0162	.0564	.0549				
8	.0158	.0556	.0541				
9	.016	.0869	.0549				
10		.092		.0587	.0149	.0139	
11		.092		.0587	.0286		
12		.0974		.0587	.0143	.0143	
13		.1158		.0147	.0143	.0139	
14		.1097		.0147	.0145		
15		.1097		.029	.0143	.0139	
16		.0846		.029	.0143	.0417	
17		.1082		.0282	.0143	.0417	
24	.2343	.0152	.1303	.0339			
Max	.2343	.1158	.1303	.0587	.0286	.0417	.0139
Min	.0154	.0137	.0282	.0147	.0143	.0139	.0137
Avg	.0377	.0617	.0537	.0362	.0162	.0232	.0138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 203 / 11 KV Chikana AG Feeder Ag dominated/Pure Ag
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0137		.0857	.1217	.08	.0139
2	.0137		.0974	.1217	.08	.0139
3	.0137		.1113	.1334	.0777	.0139
4	.0139		.1252	.1334	.1036	.0141
5	.0135		.1334	.1467	.1296	.0133
6	.0158		.16	.1467	.1555	.0259
7	.0139		.1509	.1734	.1734	.0244
8	.0274		.1623	.2164	.1734	.0248
9	.0423		.1833	.2058	.16	.0255
10	.1166	.1036	.029		.0139	.1425
11	.1488	.1235	.0564	.0278		.1646
12	.2086	.1252	.0987	.0274	.013	.1429
13	.1974	.1833	.0987	.0274	.013	.1593
14	.1833	.1572	.0987	.16		.1572
15	.153	.1572		.1425	.0282	.141
16	.1646	.1833	.1	.1555	.0141	.1448
17	.1758	.2256	.0974	.1467	.0141	.1551
24	.1149		.0572	.1217	.0533	.0141
Max	.2086	.2256	.1833	.2164	.1734	.1646
Min	.0135	.1036	.029	.0274	.013	.0133
Avg	.0906	.1574	.1086	.1299	.0802	.0773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385]

BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 204 / 11KVCHIKANA (GAOTHAN)

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1494	.1494	.1867	.1478	.1494	.1663
2	.168	.1109	.1494	.1848	.1478	.1307	.1494
3	.168	.1294	.128	.1663	.1294	.112	.1307
4	.168	.1307	.128	.1463	.1109	.1307	.1294
5	.1478	.0549	.1097	.128	.0924	.1307	.1294
6	.0924	.0732	.1097	.0905	.0739	.0934	.1478
7	.0905	.0716	.0724	.0716	.0724	.0739	.0716
8	.0549	.0526	.0724	.0537	.0724	.0724	.0724
9	.0924	.0716	.0537	.0554	.0886	.0554	.0549
10	.0895	.0532	.0867	.0724	.0895	.1063	.0739
11	.0754	.0537	.1052	.0905	.1063		.0905
12	.0886	.0895	.1052	.1254	.1227	.0747	.1294
13	.1086	.128	.128	.1294	.1063	.0747	.1075
14	.128	.1075	.128	.1254	.0934		.1075
15	.0732	.1075	.1267	.1254	.0739	.0934	.1075
16	.0724	.0914	.0905	.1254	.0739	.056	.0886
17	.0554	.0709	.0724	.0709	.0554	.056	.0693
18	.0663	.0716	.0543	.112	.0549	.0716	.0693
19	.1494	.112	.112	.1494	.1478	.132	.1294
20	.1478	.132	.168	.1867	.168	.1886	.1698
21	.1886	.1867	.2075	.1867	.1886	.1886	.1886
22	.168	.168	.1307	.168	.168	.1698	.1509
23	.1478	.1494	.168	.1478	.1663	.1698	.1494
24	.168	.1494	.1494	.168	.1478	.1494	.1663
Max	.1886	.1867	.2075	.1867	.1886	.1886	.1886
Min	.0549	.0526	.0537	.0537	.0549	.0554	.0549
Avg	.1199	.1048	.1169	.1278	.1124	.1127	.1187

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 205 / BARWHA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4251	.4435	.4066	.4066	.4481	.4163
2	.462	.4108	.4066	.3696	.3696	.3881	.3982
3	.4435		.3696	.3361	.3292	.3326	.3801
4	.4251	.3658	.2801	.2987	.2926	.3142	.3658
5	.3881	.2926	.2241	.2614	.2561	.3696	.3658
6	.2561	.2402	.2402	.2427	.2378	.2561	.2303
7	.2012	.1772	.2195	.1991	.2149	.2033	.181
8	.181	.1753	.1949	.1907	.181	.1612	.181
9	.2507	.1734	.2658	.2328	.1991	.112	.2172
10	.2743	.2658	.2743	.2507	.2772	.2587	.2402
11	.3045	.3292	.3012	.3189	.3258	.2957	.2507
12	.3012	.3403	.3582	.3898	.3544	.2218	.3224
13	.2865	.3258	.362	.3761	.3155	.2481	.2896
14	.3258	.3258	.4066	.3582	.3189	.2507	.2896
15	.3292	.3258	.3475	.3224	.3189	.2686	.2715
16	.3224	.2926	.3045	.3403		.2149	.2427
17	.2587	.2353	.2658	.2774	.2401	.2587	.197
18	.2058	.2629	.2957	.3547	.2229	.2279	.2328
19	.3881	.3547	.3696	.4294	.3982	.3841	.2926
20	.4435	.4668	.4668	.5041	.4481	.4572	.4481
21	.5228	.5041	.5041	.4668	.5041	.4755	.4854
22	.499	.5041	.4805	.462	.4854	.4755	.4435
23	.4755	.462	.462	.462	.4854	.4572	.4435
24	.462	.4435	.4435	.462	.4435	.4668	.4251
Max	.5228	.5041	.5041	.5041	.5041	.4755	.4854
Min	.181	.1734	.1949	.1907	.181	.112	.181
Avg	.3529	.3347	.3453	.3464	.3315	.3144	.3171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385]

BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 206 / Murmadi Gaothaon

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2033	.2054	.1867	.1867	.168	.1663
2	.2033	.1867	.1867	.1867	.168	.168	.1663
3	.2033	.168	.132	.168	.1494	.1307	.168
4	.2033	.168	.132	.1478	.1307	.1307	.1494
5	.1663	.1307	.132	.1294	.112	.168	.1494
6	.1109	.0914	.1132	.1109	.0934	.0943	.1132
7	.0924	.0914	.0924	.0739	.0924	.0943	.0732
8	.0532	.0905	.1097	.0732	.0914	.0739	.0895
9	.0747	.0716	.0924	.0754	.0754	.0924	.0895
10	.0905	.0934	.0924	.0943	.056	.0747	.0905
11	.112	.0943	.112	.1109	.0747	.0543	.0739
12	.1307	.112	.112	.1478	.0934	.0724	.0739
13	.112	.1307	.168	.1494	.0924	.0732	.0924
14	.1494	.132	.1663	.1494	.0905	.0876	.0924
15	.1307	.1132	.0566	.1307	.0724	.0876	.0924
16	.112	.1109	.0747	.1307	.0905	.0876	.1294
17	.0724	.0934	.0934	.1109	.1097	.0739	.0739
18	.0716	.0914	.0914	.1494	.1097	.0895	.0709
19	.1063	.1509	.1463	.1867	.1848	.1698	.128
20	.1629	.2263	.2054	.2263	.2427	.2263	.2263
21	.2263	.2263	.2452	.2263	.2427	.2263	.2263
22	.2054	.2054	.2241	.1867	.2241	.2263	.2241
23	.2054	.2054	.2054	.1867	.1867	.2075	.2054
24	.2033	.2054	.2054	.1867	.1867	.1867	.1848
Max	.2263	.2263	.2452	.2263	.2427	.2263	.2263
Min	.0532	.0716	.0566	.0732	.056	.0543	.0709
Avg	.1417	.1414	.1414	.1469	.1315	.1277	.1312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 201 / kudegaon

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3696	.4251	.2957	
2				.4066	.4251	.2957	
3				.4066	.4251	.3142	
4				.4066	.4251	.3142	
5				.4251	.4251	.3696	
6				.4435	.499	.4066	
7				.4805	.4805	.4435	
8				.4805	.499	.4435	
9				.499	.4066	.4805	
10	.4066	.4251	.4207				.2587
11	.4251	.439	.4805				.4066
12	.499	.462	.5175				.4251
13	.5359	.499	.5175				.2772
14	.5544	.499	.5359				.3881
15	.5729	.4805	.5359				.3881
16	.5914	.499	.5359				.4066
17	.5914	.4435	.5544				.4435
24	.4251				.3475	.2772	.1848
Max	.5914	.499	.5544	.499	.499	.4805	.4435
Min	.4066	.4251	.4207	.3696	.3475	.2772	.1848
Avg	.5113	.4684	.5123	.4353	.4358	.3641	.3532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 202 / 11 KV PAHUNGAON(AGP)+11 KV Ag dominated/Pure Ag
BHA Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4382	.439				.2667
2	.4207	.4382	.439				.2667
3	.4207	.4382	.439				.2667
4	.4207	.4382	.439				.2667
5	.4024	.4382	.439				.2286
6	.4024	.4382	.4024				.2286
7	.4191	.4382	.4207				.2286
8	.4191	.4382	.439				.2477
9	.4191	.4191	.4207				.2667
10				.4763	.3048	.3048	
11				.4382	.3239	.3429	
12				.4191	.362	.3429	
13				.3239	.362	.381	
14				.3239	.381	.3429	
15				.3239	.2667	.3239	
16				.3429	.2858	.2667	
17				.4191	.2286	.3429	
24		.381	.4435	.4572			
Max	.4207	.4382	.4435	.4763	.381	.381	.2667
Min	.4024	.381	.4024	.3239	.2286	.2667	.2286
Avg	.4161	.4306	.4321	.3916	.3144	.331	.2519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064017 / PARSODI

Feeder No / Name : 203 / 11 KV KUDEGAON GAOTHAN Gaothan Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.4572	.4805	.4435	.4207	.439	.4207
2	.4954	.4572	.4805	.4435	.4207	.439	.4207
3	.4954	.4572	.4805	.4435	.4207	.4024	.4207
4	.4954	.4572	.4805	.4435	.4207	.4024	.4207
5	.381	.3292	.3696	.4251	.3841	.3292	.4207
6	.3048	.2743	.2402	.2743	.2743	.2561	.2743
7	.2378	.2195	.2218	.2012	.2195	.2012	.2012
8	.2378	.2012	.2218	.2195	.2561	.1829	.1829
9	.2195	.2195	.2587	.2195	.2195	.2012	.1829
10	.3292	.1463	.2957	.2561	.2012	.2195	.2378
11	.3292	.2378	.3696	.3109	.2743	.2378	.2561
12	.3292		.3881	.3841	.2561	.2926	.2743
13	.3292	.3475	.4066	.4207	.3109	.2926	.2926
14	.3292	.3658	.4066	.439	.3109	.2561	.3292
15	.3292	.3109	.3921	.4024	.2378	.2195	.2743
16	.2195	.3109	.3142	.3109	.1646	.1829	
17	.2012	.2195	.2587	.2743	.1646	.1646	.1829
18	.2195	.2561	.2587	.3841	.2195	.1829	.2012
19	.3841	.4024	.3696	.3841	.3658	.3109	.3658
20	.4938	.5487	.5544	.5304	.4938	.4938	.4435
21	.5304		.5729	.5487	.5304	.567	.5359
22	.4755	.5304	.5544	.4755	.5121	.4938	.5175
23	.4572	.5121	.5175	.4207	.4572	.439	.4805
24	.4755	.4572	.499	.4435	.4207	.439	.4207
Max	.5304	.5487	.5729	.5487	.5304	.567	.5359
Min	.2012	.1463	.2218	.2012	.1646	.1646	.1829
Avg	.3664	.3508	.3913	.3791	.3315	.3186	.3373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385]

BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 201 / 11 KV DHOLSAR FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532		.0709	.0701	.0686	.0537	.0678
2	.0532	.0351	.0709	.0693	.0686	.0537	.0671
3	.0549	.0351	.0701	.0526	.0686	.0532	
4	.0549	.0351	.0701	.0526	.0678	.0709	
5	.0554	.0343	.0514	.052	.061	.0343	
6	.0328	.017	.0503	.048	.044	.0343	
7	.0312	.0152	.0474	.0301		.0316	.0328
8	.0316	.0152	.0173	.0301	.0452	.0305	.0316
9	.044	.0309	.017	.0297	.044	.0301	.0305
10	.0309	.0158	.0181	.0301	.0452	.0457	.0324
11	.0328	.0324		.0474	.0452	.0312	.0514
12	.0486	.0358	.0335	.0655		.0309	.0686
13	.0617	.0693	.0514	.0678	.0497	.0343	.0701
14	.0625	.0532	.0509	.0686	.0328		.0701
15	.032	.0514	.0503	.0663	.0339	.0301	.0332
16	.029	.0469	.032	.048	.017	.0309	.0332
17	.0282	.0332	.0463	.0446	.0168	.0305	.0297
18	.0271	.0328	.0469	.0417	.0316	.0434	.0463
19	.0497	.052	.0503	.0655	.0514	.0492	.0514
20		.0732	.0701	.0848	.0716	.0701	.0724
21	.0532	.0724	.0701	.0693	.0549	.6379	.0709
22	.0693	.0716	.0701	.0686	.0716	.0693	.0532
23	.0693	.0716	.0701	.0686	.0716	.0701	.0526
24	.0532	.0693	.0709	.0701	.0686	.0716	.0693
Max	.0693	.0732	.0709	.0848	.0716	.6379	.0724
Min	.0271	.0152	.017	.0297	.0168	.0301	.0297
Avg	.0460	.0434	.0520	.0559	.0514	.0712	.0517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 202 / 11 KV MASAL FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5533		.5959	.6485	.631	.5365	.6241
2	.5596	.5365	.5895	.6133	.5658	.5365	.583
3	.5533	.5636	.5596	.5868	.5658		.5304
4	.547	.5636	.547	.5868	.5533	.5243	.5304
5	.5304	.463	.4458	.5533	.4344	.3841	.503
6	.2848	.2926	.3286	.4064	.3567	.3155	.3109
7	.1928	.4024	.2235	.3447		.2263	.2012
8	.3144	.2389	.2835	.2431	.3201	.2848	.2766
9	.2926	.2629	.3018	.2724	.3199		.2557
10	.3467	.2389	.3765	.3292	.4167	.3155	.3382
11	.3814	.3814	.4062	.3668	.4111		.3477
12	.4534	.4475	.4858	.4641	.4801	.3864	.3616
13	.4374	.4902	.5079	.4801	.4696	.3814	.3961
14	.4696	.4531	.502	.5138	.4012		.4214
15	.4696	.4572	.4641	.4915	.3338	.3668	.3765
16			.3858	.4012	.285	.3418	.3064
17	.3593		.3913	.3795	.2976	.3144	.3201
18	.3395	.3429	.381	.3725	.2936	.2961	.3024
19	.4534	.4641	.4409	.4641	.4374	.4062	.3858
20	.5571	.5868	.57	.6068	.547	.5243	.5407
21	.6104	.6104	.6173	.5868	.5935	.6241	.5407
22	.6173	.6173	.7095	.6068	.5898	.6415	.5533
23	.6344	.6068	.6485	.6485	.5935	.6173	.5658
24	.583	.6104	.6024	.6485		.57	.6241
Max	.6344	.6173	.7095	.6485	.631	.6415	.6241
Min	.1928	.2389	.2235	.2431	.285	.2263	.2012
Avg	.4583	.4586	.4735	.4840	.4499	.4297	.4248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 203 / 11 KV BELATHI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0452		.061				.0695
2	.044	.0434	.0602				
3	.044	.0274	.0594				
4	.044	.0541	.0579				
5	.044	.0533	.0579				
6	.0429	.0533	.0579				
7	.044	.0686	.0714				.0695
8	.0434	.0572	.0572				.0714
9	.0429	.0564	.0579				.0695
10				.0587	.0724	.0705	.0857
11				.0579	.0892		.0892
12				.0617	.0753	.0714	.0743
13				.0617	.0724	.0846	.0579
14				.0625	.0724		.0579
15				.061	.0714	.0846	
16				.0772	.0714	.0846	
17				.0753	.0714	.0846	
24		.029	.0617	.0457			
Max	.0452	.0686	.0714	.0772	.0892	.0846	.0892
Min	.0429	.0274	.0572	.0457	.0714	.0705	.0579
Avg	.0438	.0492	.0603	.0624	.0745	.0801	.0717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION

Feeder No / Name : 204 / 11 KV Tai Gaothan Feeder Gaothan Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587		.2829	.2829	.2452	.2218	.2452
2	.2587	.1663	.2829	.2829	.2452	.2218	.2641
3	.2587	.1663	.2641	.2801	.2452	.2218	.1886
4	.2587	.1663	.2641	.2427	.2452	.2218	.1886
5	.2402	.1663	.2263	.2452	.1886	.1646	.1698
6	.1402	.0895	.1509	.1494	.132	.128	.1294
7	.128	.0867	.1307	.1307		.12	.112
8	.124	.1478	.1509	.132	.1698	.1214	.112
9	.1254	.1254	.1509	.1132	.1494	.1227	.0914
10	.1267	.1052	.1478	.1494	.1494	.1254	.1097
11	.1448	.1595	.1698	.168	.2172		.128
12	.2195	.1886	.2054	.2263	.2033	.1629	.1663
13	.2012	.2402	.2241	.2263		.1663	.1663
14	.2012	.2012	.2561	.2452			.1949
15	.1829	.1646	.2218	.2452		.1448	.1463
16		.132	.1433	.1867	.1147	.0924	.1254
17	.1187	.1307	.1494	.1463	.12	.1478	.104
18	.1543	.1478	.112	.1478	.1387	.1075	.1372
19	.2241	.2452	.2054	.2641	.2427	.2033	.2263
20	.2987	.3395	.3018	.3174	.3206	.2987	.3018
21	.2987	.3206	.3174	.2987	.3174	.2987	.3018
22	.2957	.3018	.3206	.2829	.2772	.2801	.2614
23	.2772	.3018	.2801	.2641	.2402	.2427	.2587
24	.2587	.2027	.2829	.2829	.2641	.2402	.2427
Max	.2987	.3395	.3206	.3174	.3206	.2987	.3018
Min	.1187	.0867	.112	.1132	.1147	.0924	.0914
Avg	.2085	.1868	.2184	.2213	.2113	.1843	.1822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 402 / 33 KV Parsodi Feeder
Feeder KV- 33 / INCOMING

HV Express Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	1.2574	1.829	1.8861	1.9433	1.6004	1.9433
2	2.1719	1.2574	1.3146	1.829	1.9433	1.6004	1.9433
3	2.1719	.6859	1.8861	1.829	1.9433	1.5432	1.9433
4	2.1148	1.4289	1.7718	1.9433	1.9433	1.5432	1.6575
5	1.9433	1.3717	1.7147	1.829	1.8861	1.4861	1.6575
6	1.6004	.9717	1.3146	1.3146	1.6004	1.1431	1.4289
7	1.4289	1.0288	1.2449	1.2003	1.4861	.8573	1.2003
8	1.6004	1.1431	1.3146	1.1431	1.2574	1.086	1.2003
9	1.6575	1.1431	1.4861	1.4289	1.1431	1.1431	1.1431
10	1.2003	1.2003	1.3146	1.3146	1.4861	1.3146	.9717
11	1.3717	1.6575	1.6004	1.6575	1.6004	1.6004	1.4289
12	1.7147	1.5432	1.829	1.829	1.7147	2.1148	1.6575
13	1.7718	1.4289	2.0005	2.2291	1.8861	2.1719	1.0288
14	1.6004	1.6575	1.9433	2.2862	1.9433	2.1148	1.6004
15	2.1719	1.6575	1.8861	2.1719	1.3717	2.0005	1.4861
16	1.7147	1.6004	1.7147	2.0576	1.3717	1.7718	1.3717
17	1.5432	1.1431	1.4289	2.0576	1.4861	1.5432	.1715
18	.4572	.5144	.6287	.8002	.5716	.4572	.5716
19	1.086	1.1431	1.086	1.086	1.0288	1.086	.743
20	1.4289	1.5432	1.4861	1.4861	1.3717	1.4289	1.4289
21	1.4861	1.6004	1.6004	1.4289	1.4861	1.6004	1.5432
22	1.4861	1.6004	1.5432	1.4861	1.4861	1.5432	1.5432
23	1.4289	1.6004	1.4289	1.4289	1.3146	1.4289	1.4861
24	1.7147	1.8861	1.8861	1.8861	1.8861	1.6004	1.8861
Max	2.2291	1.8861	2.0005	2.2862	1.9433	2.1719	1.9433
Min	.4572	.5144	.6287	.8002	.5716	.4572	.1715
Avg	1.6290	1.3360	1.5522	1.6504	1.5480	1.4908	1.3765

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 403 / 33 KV Lakhandur Feeder HV Express Feeder
Incomer Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3434	2.1719	2.2291	1.9433	1.8861	1.8861	2.0576
2	2.2862	2.1719	2.2291	1.9433	1.8861	1.8861	2.0576
3	2.2291	2.1719	2.2291	1.8861	1.829	1.829	2.0005
4	2.1719	2.1148	2.1719	1.829	1.829	1.829	2.0005
5	2.1719	2.1148	2.1148	1.8861	1.7718	1.7718	1.9433
6	1.4289	1.2574	1.3146	.9145	.9717	.9717	1.2003
7	1.3717	1.2574	1.3717	.8002	.9717	.8573	
8	1.829	1.7147	1.829	1.1431	1.3146	1.2574	1.4861
9	1.3146	1.6004	1.829	1.2003	1.086	1.2003	1.4289
10	1.3717	1.0288	1.2003	1.5432	1.6004	1.5432	1.2574
11	1.4289	1.3717	1.4289	1.9433	1.6575	1.7147	1.3146
12	1.6004	1.5432	1.5432	2.1719	2.0005	1.7718	1.4289
13	1.6575	1.6575	1.6575	2.2862	2.1148	1.8861	1.3146
14	1.7147	1.6575	1.7147	2.3434	2.2291	1.9433	1.6575
15	1.6575	1.5432	1.7147	2.3434	1.9433	1.829	1.7147
16	1.6004	1.4861	1.4861	2.1719	1.7147	1.7147	1.4861
17	1.5432	1.2003	1.4289	2.0005	1.7718	1.6004	1.1431
18	1.1431	1.2574	1.2574	1.3146	1.2574	1.1431	1.086
19	.9717	1.4861	1.5432	1.6004	1.5432	1.5432	1.4289
20	1.7147	1.8861	1.8861	1.8861	1.9433	1.829	1.829
21	1.8861	2.0005	2.0005	1.829	2.0005	1.9433	1.9433
22	1.9433	2.0005	2.0005	1.8861	2.0005	1.9433	1.9433
23	1.8861	1.9433	1.8861	1.8861	1.9433	1.8861	1.9433
24	1.9433	2.2291	2.0576	2.1719	1.8861	1.9433	1.8861
Max	2.3434	2.2291	2.2291	2.3434	2.2291	1.9433	2.0576
Min	.9717	1.0288	1.2003	.8002	.9717	.8573	1.086
Avg	1.7171	1.7028	1.7552	1.7885	1.7147	1.6551	1.6327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385]

BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
Station

Feeder No / Name : 404 / 33 KV BARWA FEEDER

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8002	1.6004	.8573	.9145	.8002	.743
2	.8002	.1715	.8002	.8573	.9145	.8002	.8002
3	.8002	.3429	.8002	.8573	.9145	.8002	.743
4	.8002	.743	.743	.8573	.8573	.8002	.743
5	.743	.6859	.743	.8002	.8573	.743	.6859
6	.4572	.4572	.4572	.5716	.5716	.5716	.4001
7	.3429	.4001	.4001	.5144	.5716	.5144	.3429
8	.3429	.4001	.4572	.5144	.6287	.4572	.2858
9	.4572	.3429	.5144	.5144	.5716	.4001	.4001
10	.5716	.5144	.5716	.4572	.4572	.4572	.5144
11	.5716	.5716	.6287	.6859	.5144	.3429	.5716
12	.743	.6287	.743	.8002	.5716	.4001	.4572
13	.743	.6859	.8573	.8573	.6287	.4572	.1715
14	.8002	.6859	.8573	.8573	.5716	.4572	.6287
15	.743	.6859	.6859	.743		.4572	.6859
16	.6859	.5716	.743	.743	.1715	.4572	.6287
17	.5716	.5144	.6859	.6287	.5144	.4572	.3429
18	.3429	.4572	.4001	.4572	.4572	.3429	.3429
19	.6287	.5716	.6287	.6287	.6859	.6287	.2858
20	.743	.8573	.8573	.9145	.8002	1.829	.8002
21	.8573	.8573	.8573	.8002	.8573	.8573	.8573
22	.8002	.8573	.8002	.8002	.8002	.8002	.8573
23	.8002	.8002	.743	.8002	.743	.743	.8002
24	.8002	.8002	.8573	.8573	.9145	.8573	.743
Max	.8573	.8573	1.6004	.9145	.9145	1.829	.8573
Min	.3429	.1715	.4001	.4572	.1715	.3429	.1715
Avg	.6644	.6001	.7263	.7240	.6734	.6430	.5763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-
StationFeeder No / Name : 405 / 33 KV KESHORI FROM
LAKHANDUR Feeder KV- 33 /
INCOMING

HV Express Feeder

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578		2.6292	2.6863			1.6575
2	2.8006		2.6292	2.6863			2.572
3	2.8006		2.572	2.6292			2.5149
4	1.6575		2.572	2.6292			2.5149
5	1.8861		2.4577	2.572			2.4577
6	1.5432		2.0576	2.0576			2.0576
7	1.2574		2.0576	1.8861			1.2574
8	1.7718		.4001	1.829			1.8861
9		1.4861		.9717			1.9433
10		1.4861		1.086			1.6004
11		1.5432		1.0288			1.6575
12		1.5432		1.6575			1.7718
13		2.2862		2.572			1.829
14		2.3434		2.6863			1.3146
15		2.3434					1.7147
16		2.2291					1.4861
17		2.1719					2.0576
18		2.1719			1.9433		2.0576
19		2.2862			2.4577		2.4577
20		2.8006			2.8006		2.8578
21		2.8578			2.8578		2.915
22		2.8578			2.7435		2.8006
23		2.8006			2.6292		2.7435
24			2.7435			2.6292	
Max	2.8578	2.8578	2.7435	2.6863	2.8578	2.6292	2.915
Min	1.2574	1.4861	.4001	.9717	1.9433	2.6292	1.2574
Avg	2.0719	2.2138	2.2354	2.0699	2.5720	2.6292	2.0924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 201 / 11 KV Palandur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.462	.4207	.4572	.462	.4344	.4024
2	.3761	.462	.439	.4572	.4435	.3982	.3658
3	.3403	.4435	.439	.4024	.4435	.3982	.3475
4	.2865	.4435	.3841	.4024	.4066	.362	.3109
5	.2686	.3696	.3292	.3658	.3881	.2896	.2743
6	.2328	.2402	.2561	.2561	.3881	.2195	.2378
7	.2149	.1848	.2012	.2033	.2033	.1829	.1829
8	.2149	.2218	.2195	.2033	.2033	.181	.1463
9	.2149	.2218		.2218	.2402	.1991	.1097
10	.4298	.4557	.5544	.4656	.462	.3841	.2195
11	.5359	.4557	.6283	.5731	.5359	.4755	.5853
12	.5914	.4908	.6283	.6089	.6099	.4938	.5853
13	.6468	.5434	.6653	.7522	.6283	.4938	.6036
14	.6283	.5258	.6722	.7164	.5121	.4755	.5121
15	.6283	.5434	.7282	.6805	.4251	.4755	.439
16	.5359	.5434	.5601	.6626	.4024	.4572	.4207
17	.4435	.4557	.5228	.5083	.3841	.3841	.3841
18	.2218	.2103	.1867	.2629	.3077	.2012	.1734
19	.3142	.3155	.3174	.3506	.3258	.2926	.3121
20	.4251	.4207	.462	.4207	.3982	.4207	.3467
21	.462	.4557	.4805	.3506	.4298	.439	.3988
22	.4805	.4733	.4805	.4656	.4477	.4572	.4334
23	.462	.4755	.4755	.4656	.4298	.439	.4334
24	.4298	.462	.4572	.4572	.462	.4344	.439
Max	.6468	.5434	.7282	.7522	.6283	.4938	.6036
Min	.2149	.1848	.1867	.2033	.2033	.181	.1097
Avg	.4089	.4115	.4569	.4463	.4141	.3745	.361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 202 / 11 KV Maregaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3521	.394	.3982	.4119	.4298	.4298
2	.3688	.3353	.3582	.3982	.4298	.4298	.4119
3	.3353	.3353	.3582	.362	.4477	.4119	.4119
4	.3018	.3353	.3224	.362	.4656	.4119	.394
5	.285	.285	.3224	.362	.591	.4119	.394
6	.2515	.2515	.3045	.3439	.591	.394	.4119
7	.285	.2515	.3224	.3224	.394	.5014	.4298
8	.2683	.2683	.2865	.3582	.4119	.5014	.4119
9	.285	.2683		.394	.4119	.4119	.4119
10	.1174	.1006	.2534	.0914	.1433	.0895	.1075
11	.1174	.1174	.2534	.1463	.1433	.1254	.1254
12	.1509	.1509	.2172	.2012	.197	.1254	.1612
13	.2012	.1174	.2172	.2378	.2149	.1254	.1612
14	.2012	.1677	.2172	.2195	.1612	.1075	.1612
15	.1844	.1509	.197	.2195	.1075	.1254	.1254
16	.1174	.1174	.1433	.1612	.1075	.1075	.0895
17	.0671	.0838	.0895	.1075	.1075	.1075	.0716
18	.0838	.0838	.1254	.1254	.1075	.0895	.0895
19	.1677	.1844	.1791	.2149	.1991	.1612	.1791
20	.4251	.2515	.2507	.2686	.2507	.2328	.2149
21	.2515	.2515	.2865	.2507	.2686	.2507	.2507
22	.2347	.2347	.2865	.2149	.2507	.2507	.2149
23	.2347	.2507	.2507	.2507	.2149	.2328	.2328
24	.3856	.3521	.394	.3982	.394	.4298	.4298
Max	.4251	.3521	.394	.3982	.591	.5014	.4298
Min	.0671	.0838	.0895	.0914	.1075	.0895	.0716
Avg	.2385	.2207	.2622	.2670	.2926	.2694	.2634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 203 / 11 KV Gondegaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7011	.7164	.7362	.9425	.8842	.9134	.8413
2	.6836	.7343		.924	.8669	.8596	.8063
3	.631		.6964	.924	.8495	.8417	.7888
4	.5609	.5373	.6401	.8871	.8669	.8059	.7712
5	.5083	.4835	.5921	.7865	.9015	.8059	.7362
6	.4557	.4477	.5441	.7865	.8495	.6722	.7011
7	.4557	.5243	.6154	.6874	.3521	.6081	.6135
8	.5083	.5571	.6316	.7042	.7042	.6722	.6661
9	.3856	.5735		.7545	.7202	.7202	.7011
10		.168	.2458	.1612	.2328	.1509	.1698
11	.2241	.2241	.2458	.2328	.2328	.1509	.2241
12		.2427	.2949	.2865	.2328	.1886	.2641
13	.2987	.2801	.2949	.3045	.2507	.1698	.2829
14	.2987	.2801	.2785	.3224	.197	.1698	.3018
15	.2987	.2427	.2622	.3224	.1433	.1509	.2075
16	.168	.2054	.213	.2641	.1254	.1698	.1698
17	.1307	.168	.1475	.2241	.1433	.1509	.132
18	.1307	.168	.1638	.1867	.1494	.132	.1509
19	.2801	.2987	.2294	.3734	.2054	.2829	.3772
20	.4294	.4481	.3725	.4481	.4294	.415	.3961
21	.4481	.4668	.3887	.4481	.4338	.4527	.4527
22	.4294	.4481	.3932	.4294	.415	.415	.4338
23	.3921	.4108	.3932	.3921	.3961	.3961	.415
24	.7011	.7343	.8417	.9425	.8842	.9114	.8589
Max	.7011	.7343	.8417	.9425	.9015	.9134	.8589
Min	.1307	.168	.1475	.1612	.1254	.132	.132
Avg	.4145	.4070	.4191	.5306	.4778	.4669	.4776

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 205 / 11 KV MURMADI GAOTHON

Gaothan Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4656	.4835	.4755	.4835	.4755	1.0974	.5121
2	.4298	.5014	.4755	.4477	.4572	1.0974	.4938
3	.3761		.4572	.4477	.439	1.0242	.4572
4	.3224	.2149	.4024	.3982	.439	.9877	.439
5	.2865	.2149	.3841	.3258	.4207	.8413	.3841
6	.2507	.2328	.3109	.2715	.2926	.6036	.3292
7	.2149	.2328	.1097	.2378	.2378	.5304	.2743
8	.2149	.2507		.2378	.2195	.5853	.2561
9	.2328	.2686		.2561	.2195	.567	.2195
10	.2507	.1612		.3258	.2743	.6219	.2378
11	.2686	.2686		.3439	.3475	.7316	.2926
12	.3403	.3224	.2195	.4344	.439	.6584	.4024
13	.3761	.3224	.2195	.4344	.3658	.6584	.4572
14		.4119	.3801		.3292	.6401	.3658
15	.3582	.3761	.4344	.4525	.7133	.6401	.3475
16	.2686	.3224	.362	.3258	.6767	.6219	.3109
17	.2507	.3045	.3077	.2715	.695	.5487	.2926
18	.2686	.2507	.3439	.3292	.6584	.6036	.3109
19	.4298	.4477	.3801	.5487	.9694	.4572	.4938
20	.5373	.5373	.5373	.5853		.567	.5487
21	.5552	.5552	.5731	.567	1.2437	.5853	.5853
22	.5373	.5373	.5731	.5487	1.2071	.567	.5487
23	.5014	.4938	.5014	.5121	1.1706	.5487	.5121
24	.4656	.4835	.4938	.4835	.4755	1.134	.5304
Max	.5552	.5552	.5731	.5853	1.2437	1.134	.5853
Min	.2149	.1612	.1097	.2378	.2195	.4572	.2195
Avg	.3566	.3563	.3971	.4030	.5551	.7049	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 403 / 33 KV PALANDUR (Incomer)

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9033	2.0199	2.0062	2.1794	2.1794	2.6452	2.1794
2	1.8004	2.0199	1.9547	2.1262	2.1794	2.5434	2.073
3	1.6461	.7973	1.9033	2.073	2.1262	2.4417	1.9667
4	1.4918	1.4883	1.6975	1.9667	2.1262	2.34	1.9136
5	1.3375	1.2757	1.5947	1.7541	2.2857	2.1365	1.7541
6	1.1317	1.1163	1.3889	1.5947	1.7541	1.7804	1.6478
7	1.0802	1.2226	1.2346	1.4352	1.6478	1.7295	1.4883
8	1.1317	1.3289	.823	1.4883	1.5947	1.6787	1.4883
9	1.0288	1.382	1.2226	1.6478	1.6478	1.7804	1.4352
10	.7973	.9036	1.0099	1.0099	1.0288	1.1191	.691
11	1.0099	1.0174	1.1163	1.2757	1.1831	1.4352	1.1694
12	1.2757	1.1191	1.3289	1.4883	1.3889	1.4352	1.4883
13	1.4883	1.17	1.4883	1.701	1.3375	1.382	1.4352
14	1.0631	1.3226	1.0631	1.701	1.1317	1.3289	1.2757
15	1.4352	1.2209	1.5947	1.6478	1.286	1.3289	1.0631
16	1.0631	1.1191	1.2226	1.382	1.2346	1.3289	.9568
17	.8505	.9665	1.0099	1.1163	1.2346	1.1694	.8505
18	.691	.6687	.8505	.8505	1.0288	1.0099	.691
19	1.3289	1.1831	1.0631	1.4352	1.1831	1.1694	1.3289
20	1.5415	1.5947	1.701	1.6478	2.1091	1.5947	1.4352
21	1.701	1.6461	1.701	1.5415	2.2119	1.6478	1.6478
22	1.6478	1.5947	1.701	1.5947	2.1605	1.6478	1.5947
23	1.5415	1.4918	1.5947	1.5415	2.0576	1.5415	1.5415
24	1.9033	2.0199	2.0062	2.1794	2.1794	2.696	2.2325
Max	1.9033	2.0199	2.0062	2.1794	2.2857	2.696	2.2325
Min	.691	.6687	.823	.8505	1.0288	1.0099	.691
Avg	1.3287	1.3204	1.4282	1.5991	1.6790	1.7046	1.4728

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 201 / 11 KV SINDHIPAR AGP FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0637	.0832	.0851				.0223
2	.0634	.0814	.0793				.0223
3	.0666	.0734	.0793				.0219
4	.0681	.0751	.0741				.0213
5	.0654	.078	.0768				.0213
6	.0645	.0791	.0771				.0207
7	.0693	.0751	.089				.0271
8	.0758	.0767	.096				.028
9	.0821	.0687	.0943				.0347
10				.1042	.114	.0302	
11				.1029	.1315	.0268	
12				.1043	.1229	.0213	
13				.1071		.023	
14				.1071		.0243	
15				.0974	.0357	.0229	
16				.0974	.0366	.0332	
17				.1152	.0297	.0285	
24		.0869	.0899	.0872			
Max	.0821	.0869	.096	.1152	.1315	.0332	.0347
Min	.0634	.0687	.0741	.0872	.0297	.0213	.0207
Avg	.0688	.0778	.0841	.1025	.0784	.0263	.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 202 / 11 KV RENGEPAR FEEDER AGP

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3725	.4725		
2				.365	.4687		
3				.365	.4649		
4				.3768	.4706		
5				.3786	.4782		
6				.3725	.3925		
7				.3909	.5715		
8				.3896	.5734		
9				.3958	.5773		
10	.202	.3219	.3554				
11	.341	.3256	.4097				
12	.341	.2747	.4398				
13	.341	.275	.1005				
14	.1905	.1768	.3268				.4435
15	.3342	.3137	.4195				.4167
16	.3267	.1631	.4444				.4572
17	.1987	.1613	.4885				.4108
24	.1998				.482	.2035	.3841
Max	.341	.3256	.4885	.3958	.5773	.2035	.4572
Min	.1905	.1613	.1005	.365	.3925	.2035	.3841
Avg	.2750	.2515	.3731	.3785	.4952	.2035	.4225

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 203 / 11 kv lakhori AG feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3094	.3957	.4585				.3115
2	.3152	.3895	.3581				.3115
3	.3224	.3773	.3519				.3101
4	.3237	.3812	.3477				.3115
5	.3282	.3934	.3581				.3115
6	.3237	.423	.3772				.3073
7	.3597	.423	.2798				.4257
8	.3998	.4557	.5377				.3414
9	.4024	.4161	.5658				.3499
10				.59	.5731	.3417	
11				.3881	.4812	.3417	
12				.4854	.4694	.3492	
13				.596		.3214	
14				.6262		.3227	
15				.4102		.3128	
16				.6111		.3353	
17				.6111		.3084	
20				.1524			
24		.407	.2375	.4286			
Max	.4024	.4557	.5658	.6262	.5731	.3492	.4257
Min	.3094	.3773	.2375	.1524	.4694	.3084	.3073
Avg	.3427	.4062	.3872	.4899	.5079	.3292	.3312

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 204 / 11 KV LAKHORI GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.239	.2509	.2185	.2427	.207	.2166
2	.225	.2329	.2452	.2244	.2347	.2033	.2054
3	.2244	.2085	.2358	.2286	.2262	.1975	.2054
4	.1846	.2091	.2128	.2081	.214	.1939	.1867
5	.1317	.1962	.2056	.1433	.1998	.196	.1886
6	.1158	.1195	.1139	.1231	.1325	.1195	.109
7	.1043	.0988	.1079	.0841	.1218	.1046	.0933
8	.105	.1213	.1158	.0931	.1023	.0784	.0985
9	.1146	.1097	.1146	.111	.1152	.0988	.101
10	.1079	.132	.128	.1176	.0878	.0988	.1116
11	.1317	.1288	.1456	.1518	.1397	.0914	.111
12	.139	.1866	.149	.1626	.1682	.1068	.1213
13	.1557	.1939	.1886	.1977	.0977	.1061	.1376
14	.1738	.1952	.2131	.2177		.1027	.1463
15	.1463	.1904	.1942	.2067	.0448	.0934	.1303
16	.0914	.1736	.1438	.1645	.0961	.0906	.1285
17	.0806	.1666	.1068	.1303	.1069	.0832	.0923
18	.1099	.1087	.0695	.1249	.0671	.0788	.1097
19	.1923	.1792	.1923	.2476	.17	.1497	.1866
20	.2414	.2763	.2726	.267	.2297	.2245	.2358
21	.2584	.2678	.2773	.2763	.2446	.2414	.2465
22	.2577	.2773	.2698	.2634		.2409	.2465
23	.2446	.2565	.2446	.2569	.2218	.2278	.2402
24	.2427	.2409	.249	.2395	.2384	.2122	.2185
Max	.2584	.2773	.2773	.2763	.2446	.2414	.2465
Min	.0806	.0988	.0695	.0841	.0448	.0784	.0923
Avg	.1672	.1879	.1853	.1858	.1592	.1478	.1611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 205 / 11 KV RENGEPAR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.316	.3073	.3345	.3331	.3237	.2769	.2963
2	.3146	.2986	.3234	.3225	.3167	.2782	.2926
3	.3091	.2812	.3091	.3085	.3009	.2658	.2835
4	.257	.2835	.3018	.2635	.2865	.2597	.2772
5	.2149	.2643	.2994	.2339	.2798	.2507	.268
6	.1738	.1719	.1756	.2221	.2009	.161	.1756
7	.1701	.15	.1737	.1595	.1902	.1423	.1404
8	.163	.1573	.1293	.1541	.1719	.1552	.13
9	.1864	.1591	.1249	.1648	.203	.1439	.1385
10	.1469	.1683	.161	.1628	.2045	.1478	.1525
11	.1665	.1807	.1738	.1955	.2299	.1469	.1843
12	.1792	.1846	.1774	.2195	.2772	.1719	.0876
13	.2146	.2167	.2689	.267	.109	.1593	.1975
14	.2503	.2418	.3348	.2835	.1016	.154	.2012
15	.2109		.2624	.2735	.0924	.1376	.1846
16	.1423	.1902	.2027	.2396	.0961	.124	.1488
17	.1315	.1666	.163	.1792	.0972	.1377	.1355
18	.1612	.1803	.1701	.1878	.1525	.137	.1455
19	.267	.2458	.2769	.3547	.2579	.2286	.2323
20	.3201	.353	.3641	.3772	.3249	.3062	.3025
21	.3512	.379	.3676	.3859	.3435	.3379	.331
22	.3329	.3696	.3658	.3585		.3363	.3292
23	.3182	.3419	.3493	.3493	.3018	.3179	.3197
24	.3179	.3146	.3256	.3439	.331	.3	.3036
Max	.3512	.379	.3676	.3859	.3435	.3379	.331
Min	.1315	.15	.1249	.1541	.0924	.124	.0876
Avg	.2340	.2438	.2556	.2642	.2258	.2115	.2191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S

Feeder No / Name : 401 / 33 KV Salebhata Incomer

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1015	2.1776	2.4926	2.3756	2.8006	1.8519	2.2862
2	2.079	2.1548	2.4671	2.34	2.7778	1.7375	2.2634
3	1.8415	2.1319	2.4463	2.5835	2.7263	1.7032	2.2291
4	1.9808	2.0862	2.3834	2.4977	2.6978	1.6747	2.1719
5	1.8825	2.0005	2.3148	2.4806	2.6692	1.4746	2.1319
6	1.4719	1.5775	1.8061	2.1033	2.4063	1.246	1.7833
7	1.5203	1.4918	1.8176	1.9147	2.412	1.1203	1.6975
8	1.3236	1.4918	1.8919	1.8633	2.5206	1.5146	1.6747
9	1.3608	1.5489	1.9547	2.0119	2.4463	1.4632	1.7204
10	1.2679	1.6975		2.1891	2.4691	2.0976	1.9262
11	1.3163	1.8461	1.9719	1.9319	2.7092	2.1376	1.829
12	1.4506	2.0062	2.1776	2.5949	2.8121	2.1948	1.8118
13	1.5312	2.069	2.2977	2.6718	1.4175	1.7947	1.7833
14	1.3086	1.7718	2.3605	2.8455	1.206	2.2005	1.6632
15	1.5889	2.0519	2.2291	2.8062	1.1603	2.2062	2.029
16	1.2117	1.9719	1.7947	2.6102	1.4746	2.1491	1.8233
17	1.206	1.5889	2.1491	2.5149	1.1717	1.7375	1.7604
18	.9431	1.1888	1.2517	1.3889	1.0402	1.0974	1.0802
19	1.4518	1.4232	1.5604	2.0005	1.4518	1.4403	1.6232
20	1.7204	1.9719	2.0805	2.1091	1.7661	1.7947	1.8233
21	1.7947	2.0519	2.1491	2.1719	1.7768		1.9262
22	1.7718	2.0233	2.0805	2.0519		1.8747	1.8861
23	1.7147	1.8673	1.9719	1.989	1.6975	1.8118	1.8576
24	1.8804	2.2291	2.5206	2.5048	2.8692	1.9918	2.3948
Max	2.1015	2.2291	2.5206	2.8455	2.8692	2.2062	2.3948
Min	.9431	1.1888	1.2517	1.3889	1.0402	1.0974	1.0802
Avg	1.5717	1.8508	2.0943	2.2730	2.1078	1.7528	1.8823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV MANEGAON FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.4372	.4887	.5469	.6133	.4305	.4874
2	.4287	.4321	.4733	.5399	.547	.4257	.481
3	.4287	.4304	.463	.5161	.4973	.4225	.4793
4	.4115	.427	.4458	.5058	.4578	.4145	.4761
5	.3772	.4081	.439	.4555	.4409	.3713	
6	.3222	.3206	.3704	.3687	.373	.3345	.3547
7	.3052	.3224	.3138	.3109	.3391	.3201	.3401
8	.3052	.2915	.3309	.3174	.373	.3057	.3466
9	.3052	.3584	.3378	.3466	.3391	.2657	.3401
10	.4047	.3789	.3344	.4032	.407	.2993	.3628
11	.3429	.3849	.583	.4243	.4392	.4	.3812
12	.3824	.4376	.4458	.4372	.4663	.3621	.431
13	.4424	.4275	.4801	.4372	.2798	.3773	.4807
14	.3927	.4407	.4938	.481	.2272	.3498	.4641
15	.3858	.4338	.463	.4874	.3425	.3547	.4475
16	.2915	.4527	.439	.4437	.3086	.3304	.4144
17	.2798	.4115	.3772	.4194	.2103	.3466	.4144
18	.3171	.3635	.4146	.431	.351	.3838	.4074
19	.4053	.4767	.4389	.5138	.4375	.4113	.4493
20	.451	.5058	.5466	.547	.4612	.4599	.5214
21	.4544	.523	.5562	.547	.4731	.4745	.5382
22	.4816	.5418	.5744	.5304	.4833	.4907	.5693
23	.468	.5144	.5607	.5304	.4816	.4923	.5504
24	.4561	.4612	.5041	.5539	.6464	.4646	.4891
Max	.4816	.5418	.583	.5539	.6464	.4923	.5693
Min	.2798	.2915	.3138	.3109	.2103	.2657	.3401
Avg	.3869	.4242	.4531	.4623	.4165	.3870	.4446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV PATACHI TOLI FEEDER Sheddable Rural/Mix Feeder
Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2239	.2271	.2471	.2303	.189	.239
2	.2378	.2221	.2254	.2463	.2303	.189	.239
3	.2378	.2221	.2271	.2445	.2233	.189	.2371
4	.2378	.2203	.2254	.2349	.2179	.182	.2222
5	.2195	.2185	.2254	.2226	.2126	.1786	.2147
6	.1463	.1469	.1647	.168	.1595	.1404	.1867
7	.1214	.1522	.1456	.1492	.1772	.13	.1904
8	.1052	.111	.1682	.1442	.1772	.1422	.1643
9	.1372	.12	.1474	.1593	.1417	.1335	.1624
10	.1543	.1025	.1716	.1475	.1595	.13	.196
11	.1543	.1543	.0555	.223	.1807	.1389	.2103
12	.1903	.1611	.052	.2146	.1896	.1303	.1928
13	.1903	.1645	.0693	.228	.1683	.144	.1928
14	.1783	.1814	.052	.2247	.1258	.1458	.2103
15	.1852	.204	.0693	.2247	.1081	.156	.2279
16	.1526	.189	.1372	.2029	.1364	.1645	.1753
17	.1463	.1699	.1886	.1928	.1293	.1406	.125
18	.1774	.1491	.174	.2126	.1435	.1663	.12
19	.3091	.1855	.2171	.2481	.2108	.2075	.1557
20	.2776	.2687	.2932	.2835	.2215	.2486	.2196
21	.2686	.2843	.2932	.3012	.2215	.2534	.2146
22	.2471	.2531	.2726	.2658	.2055	.2463	.2143
23	.2257	.2375	.2469	.2481	.1949	.2465	.2028
24	.2378	.2257	.2289	.2489	.2303	.1949	.239
Max	.3091	.2843	.2932	.3012	.2303	.2534	.239
Min	.1052	.1025	.052	.1442	.1081	.13	.12
Avg	.1990	.1903	.1782	.2201	.1832	.1745	.1980

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 204 / 11 KV NILAGONDI GAOTHAN

Gaothan Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2726	.2926	.2662	.2957	.2791	.2726
2	.2561	.2707	.2908	.2692	.2957	.2735	.2707
3	.2561	.2689	.2872	.2623	.2957	.2717	.2707
4	.2561	.2595	.2835	.2623	.2987	.2698	.2689
5	.2378	.2483	.2798	.2566	.2801	.2495	.1886
6	.1629	.1755	.1683	.192	.2241	.1885	.1662
7	.0886	.1438	.1591	.181	.2054	.1423	.1158
8	.124	.1438	.1555	.1502		.1164	.1232
9	.1595	.1643	.1683	.1665		.1645	.1363
10	.2126	.1664	.1811	.2231	.2402	.1386	.14
11	.1931	.2255	.2195	.2552	.2587	.1512	.1698
12	.2321	.2414	.2378	.2805	.2717	.1475	.1886
13	.2374	.2414	.2743	.2968	.2181	.1419	.2054
14	.2286	.2476	.2743	.3041	.1645	.1531	.2427
15	.2321	.2569	.2743	.3149	.1552	.1568	.2241
16	.1311	.2144	.2195	.2697	.1589	.1441	.168
17	.128	.1628	.1829	.2534	.1737	.1475	.1478
18	.1024	.1536	.1441	.2378	.1571	.1363	.1566
19	.2162	.2323	.215	.3361	.2633	.2072	.2016
20	.2643	.331	.3069	.3734	.3099	.2763	.2763
21	.2938	.3439	.3225	.3734	.3137	.3043	.3263
22	.2846	.331	.3121	.3511	.2987	.3062	.3131
23	.2782	.3091	.2906	.2818	.2857	.2857	.2867
24	.2652	.2745	.3	.2709	.2957	.2819	.2726
Max	.2938	.3439	.3225	.3734	.3137	.3062	.3263
Min	.0886	.1438	.1441	.1502	.1552	.1164	.1158
Avg	.2131	.2366	.2433	.2679	.2482	.2056	.2139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 205 / MANEGAON AGP

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.3585	.3973	.4253	.4382	.3285	.4214
2	.3973	.3567	.3862	.4145	.4382	.3285	.4177
3	.3881	.3548	.3881	.409	.4382	.3299	.4158
4	.3921	.353	.3844	.4152	.4382	.3299	.4249
5	.3921	.3493	.3752	.4225	.4382	.3299	.4191
6	.3921	.3511	.3918	.4207	.4382	.3299	.402
7	.3961	.3456	.3936	.4353	.4572	.3271	.4414
8	.3921	.4639	.4195	.4298	.4572	.3257	.4451
9	.3921	.3419	.4417	.4262	.4382	.3257	.4715
10	.4294	.4335	.4251	.4953	.6859	.3511	.4361
11	.435	.4406	.4251		.7413	.4953	.4338
12	.4238	.4287	.4207	.5396	.7035	.4435	.4294
13	.422	.4269	.4207	.5396		.4565	.4294
14	.422	.4287	.4251	.5652	.579	.4953	.4294
15	.4238	.4294	.4251	.5396	.5093	.4957	.4294
16	.4238	.4332	.4024	.545	.5055	.4842	.3812
17	.4225	.4313	.4066	.5432	.5149	.4509	.3812
24	.414	.3604	.4052	.4798	.4382	.4332	.4195
Max	.435	.4639	.4417	.5652	.7413	.4957	.4715
Min	.3881	.3419	.3752	.409	.4382	.3257	.3812
Avg	.4092	.3938	.4074	.4733	.5094	.3923	.4238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 401 / 33 KV Pimpalgao S/S

HV Express Feeder

Incomer Feeder KV- 33 /

INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	1.142	1.4861	1.1888	.9979	1.4689	1.5089
2	.9774	1.1111	1.4803	1.0745	.9928	1.4632	1.4975
3	.9516	1.1111	1.4403	1.0688	.9619	1.4518	1.4918
4	.9671	1.07	1.4232	1.046	.9781	1.4175	1.4632
5	.9259	1.0597	1.4003	.9945	.9623	.9374	1.2346
6	.7665	.8025	1.1431	.7602	.815	.7316	1.1774
7	.607	.7305	1.0745	.6459	.7467	.6459	1.1488
8	.6173	.7356	1.1088	.6116	.7782	.623	1.1603
9	.6584	.8282	1.1831	.663	.7204	.6116	1.166
10	.5658	.5453	.6802	1.3889	1.4249	1.1431	.7659
11	.5556	.7316	.5761	1.0574	1.7147	1.1546	1.2094
12	.6533	.8002	.6224	1.6461	1.7718	1.1431	1.0096
13	.7356	.9374	.7665	1.7718	.8173	1.1946	1.2515
14	.6533	.8573	.7613	1.789	1.2003	1.2289	.9097
15	.6842	.8802	.7202	1.8061	1.1717	1.2174	.8519
16	.4938	.7888	.7562	1.6575	1.2117	1.1946	.6994
17	.4527	.7316	.6739	1.5661	1.2117		.6468
18	.5761	.8002	.9145	.9568	.7716	.7945	.8002
19	.8128	.9717	1.0117	1.1934	1.0288	.9488	.9259
20	1.0134	1.2289	1.3089	1.25	1.1603	1.1488	1.2003
21	1.0391	1.2917	1.3375	1.2963	1.206	1.1831	1.2803
22	1.07	1.2631	1.3375	1.1883	1.5375	1.2174	1.2631
23	1.034	1.2117	1.246	1.1626	1.1431	1.4803	1.206
24	.8128	1.178	1.5203	1.6575	1.0442	1.0631	1.0802
Max	1.07	1.2917	1.5203	1.8061	1.7718	1.4803	1.5089
Min	.4527	.5453	.5761	.6116	.7204	.6116	.6468
Avg	.7729	.9504	1.0822	1.2267	1.0987	1.1071	1.1229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 201 / 11 KV Adarsh Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.5914	.567
2		.5487	.5601	.567
3		.5121	.5415	.5068
4		.5121	.4805	.4656
5		.4572	.4251	.3475
6		.3841	.3326	.3439
7		.3475	.2926	.3258
8		.2926	.2715	.2926
9		.362	.2561	.3109
10		.3841	.2987	.3258
11		.4572	.3658	.3439
12		.4805	.4481	.4024
13			.3961	.4572
14			.415	.4435
15		.1991	.4294	.462
16		.1646	.4108	.4024
17		.2353	.3881	.3326
18	.3658	.2241	.2987	.3109
19	.4435	.3326	.4108	.3841
20	.5729	.3921	.4715	.5093
21	.5544	.4481	.543	.5601
22	.5729	.499	.5973	.6348
23	.5914		.6036	.6468
24		.5729	.6036	.567
Max	.5914	.5729	.6036	.6468
Min	.3658	.1646	.2561	.2926
Avg	.5168	.3981	.4347	.4379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 202 / 11 KV Alesur Gaothan
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	03-JUN-17	05-JUN-17	06-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)
11		.056	
12		.0347	
13			.5916
15	.037		
16	.0152		
Max	.037	.056	.5916
Min	.0152	.0347	.5916
Avg	.0261	.0454	.5916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 203 / 11 KV Sanjay Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3213	1.3756	1.379	1.4118	1.4266	.567	1.134
2	1.3213	1.3535	1.379	1.4118	1.4083	1.1157	1.0974
3	1.267	1.2986	1.2403	1.3432	1.3575	1.1203	1.0974
4	1.1641	1.1403	1.1641	1.2894	1.3213	1.0791	1.0059
5	.985	1.0136	1.086	1.0745	1.2308	.9145	.9145
6	.8869	.8596	.905	.8954	1.0136	.8048	.7865
7	.7265	.7343		.8059	.905	.6516	.6878
8	.7619	.7186		.7619	.8507	.6335	.6626
9	.7619	.7522		.7619	1.0136	.6697	.695
10	.8417	.8682		.8859	.9593	.7059	.7602
11	.9134	.8954		.9671	1.1222	.7522	.8145
12	.985	1.0924		1.0317	1.2308	.8145	.8507
13	1.1104	1.0924		1.2489		.8145	.9877
14	1.1946	1.1041	1.3394	1.3213		.8596	.9955
15	1.1765	1.1584	1.2851	1.3032	.6733	.8507	1.0317
16	1.0029	1.1403	1.2489	1.2851	.6626	.8238	.9231
17	.929	1.0924	1.1041	1.1584		.7783	.8145
18	.8939	1.0029	1.0566	1.1222	.7973	.8326	.7164
19	.9492	1.1041	1.1041	1.1765	.8869	.9328	.8507
20	1.086	1.2437	1.2803	1.3575	1.0425	1.0349	1.0349
21	1.2254	1.2986	1.3535	1.4266	1.0974	1.1403	1.1458
22	1.3535	1.4118	1.5181	1.4449	1.2437	1.267	1.262
23	1.4266	1.4118	1.4998	1.5364	1.2803	1.267	1.3169
24	1.3213	1.3756	1.3937	1.4661	1.4632	1.2254	1.134
Max	1.4266	1.4118	1.5181	1.5364	1.4632	1.267	1.3169
Min	.7265	.7186	.905	.7619	.6626	.567	.6626
Avg	1.0669	1.1058	1.2551	1.1870	1.0946	.9023	.9467

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S

Feeder No / Name : 401 / 33 KV Lakhori (Incomer)

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3032	1.3717	1.3969	1.4118	1.9547	1.7375	1.773
2	1.3032	1.3032	1.382	1.4118	1.9547	1.6461	1.7918
3	1.2489	1.2489	1.2226	1.3432	1.8461	1.6289	1.5912
4	1.182	1.1523	1.1568	1.2894	1.8267	1.5364	1.4815
5	.9671	.9774	1.0631	1.0745	1.6655	1.3169	1.3169
6	.8596	.8596		.9134	1.3432	1.1523	1.1523
7	.7362	.7442		.7973	1.2357	.9231	1.0425
8	.7362	.7362		.7362	1.1283	.9231	.9134
9	.7442	.7442		.7442	1.3575	.9134	.9774
10	.8505	.8413		.9036	1.3575	.9774	1.0745
11	.8939	.8939		.9568	1.6289	1.1403	1.1283
12	.9568	1.0745		1.0745	1.7375	1.262	1.2489
13	1.1283	1.0745		1.1963		1.2071	1.4118
14	1.1694	1.0745	1.3432	1.2894		1.262	1.4118
15	1.1694	1.1283	1.3032	1.3575	.8505	1.262	1.4661
16	1.0099	1.1283	1.2489	1.3032	.8059	1.2752	1.3032
17	.9362	1.0745	1.0745	1.6289	.2126	1.1523	1.1283
18	.8745	.9465		1.5043	1.0099	1.1523	1.0208
19	.9568	1.1163	1.0517	1.5746	1.1946	1.3169	1.262
20	1.086	1.2489	1.262	1.8461	1.4266	1.4815	1.5524
21	1.1946	1.3032	1.3575	1.9547	1.5364	1.701	1.701
22	1.3575	1.3969	1.5203	1.9547	1.7558	1.8656	1.8656
23	1.4118	1.3969	1.4661	2.0633	1.2489	1.8461	1.9753
24	1.3032	1.3575	1.3432	1.4118	2.009	1.7918	1.7918
Max	1.4118	1.3969	1.5203	2.0633	2.009	1.8656	1.9753
Min	.7362	.7362	1.0517	.7362	.2126	.9134	.9134
Avg	1.0575	1.0914	1.2795	1.3226	1.4130	1.3530	1.3909

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064038 / 33/11 KV POHORA S/S

Feeder No / Name : 201 / 11 KV Shivni AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1412			.2267	.3183		
2	.16			.2332	.3051		
3	.1915			.2364	.315		
4	.2			.2641	.3183		
5	.2201			.2572	.3171		
6	.2172			.3144	.3678		
7	.2462			.2858	.4445		
8	.2429			.2	.4166		
9				.3715	.4562	.3213	
10		.2846	.2559			.3418	.4054
11		.289	.2896			.3492	.503
12		.286	.2972			.3432	.503
13		.2649	.3161			.3414	.5093
14		.2393	.3161				.463
15		.2077	.2378			.3536	.4572
16		.2303	.2896			.3582	
17		.2559	.3311				.4515
24					.3251		.3241
Max	.2462	.289	.3311	.3715	.4562	.3582	.5093
Min	.1412	.2077	.2378	.2	.3051	.3213	.3241
Avg	.2024	.2572	.2917	.2655	.3584	.3441	.4521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 201 / 11 KV SASRA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.8299	.811	.443	.4557	.4607	.7922
2	.7922	.8215	.7545	.443	.4458	.4557	.7545
3	.7922	.8299	.7545	.4382	.4287	.4557	.7733
4	.7922	.7545	.7356	.4207	.4239	.4334	.7545
5	.7545	.5847	.7167	.3944	.4191	.3814	.6979
6	.381	.3239	.3584	.3201	.3479	.3321	.415
7	.3048	.2641	.2829	.2812	.3201	.2709	.2667
8	.2858	.2858	.3584	.3125	.3353	.3481	.3018
9	.3584	.3772	.3429	.3005	.3479	.3605	.2829
10	.3315	.2241	.2622	.3772	.3772	.2641	.3795
11	.3521	.2949	.3391	.4904	.4527	.3018	.4321
12	.4641	.3222	.3467	.6036	.547	.3961	.4372
13	.5138	.3641	.4115	.6908	.6161	.415	.4527
14	.4807	.3641	.3856	.7095		.415	.4588
15	.3978	.3772	.3988	.6722	.3395	.3395	.4096
16	.3201	.2883	.3688	.5228	.2641	.2858	.3841
17	.286	.2652	.3041	.4294	.3018	.2263	.3462
18	.2641	.2641		.3841	.2667	.3361	.2641
19	.4904	.5658	.5525	.7049	.5658	.5906	.547
20	.7733	.8488	.8488	.8865	.7922	.7621	1.5089
21	.8865	.8488	.9149	.9431		.8865	.8865
22	.8962	.8488	.8962	.8299		.8676	.8676
23	.8402	.7655	.8589	.811	.8488	.811	.8488
24	1.0288	.8299	.8299	.8402	.4607	.4607	.4557
Max	1.0288	.8488	.9149	.9431	.8488	.8865	1.5089
Min	.2641	.2241	.2622	.2812	.2641	.2263	.2641
Avg	.5670	.5226	.5580	.5521	.4456	.4524	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 202 / 11KV SANGADI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7372	1.7002	1.7556	.724	.7682	.7522	1.6263
2	1.7372	1.6078	1.7364	.724	.724	.7362	1.5497
3	1.7177	1.587	1.6632	.7164	.724	.7282	1.531
4	1.6804	1.0829	1.6244	.6805	.6697	.7186	
5	1.587	1.0829	1.5684	.6089	.6024	.7011	1.3443
6	.9709	.8215	.9896	.4801	.5375	.5868	.8962
7	.7947	.6348	.8215	.4588	.4973	.5281	.7023
8	.7947	.6767		.4641	.4641	.5468	.6653
9	.7577	.7762		.4752	.5801	.5636	.7499
10	.3353	.4973	.5365	.8501	1.0164	.7762	.4588
11	.5487	.5765	.6485	1.0534	1.1458	.8131	.5426
12	.6415	.6443	.631	1.3676	1.423	.9795	.6588
13	.6588	.7108	.7087	1.4045	1.6448	1.1088	.7202
14	.7537	.7802	.7442	1.5893	1.6078	1.1273	.7628
15	.7362	.6935	.7011	1.46	1.1827	.7842	.6687
16	.5533	.6783	.7108	1.2567	.9522	.7762	.5967
17	.4534	.4862	.5765	1.1157	.7468	.7947	.5761
18	.9145	.8686		1.0974	.8316	.724	.7499
19	1.3256	1.3817	1.307	1.587	1.4335	1.2071	1.3014
20	1.6057	1.8858	1.8111	1.9978	1.6975	1.6057	1.6032
21	1.7187	1.9978	1.9418	2.0538		1.7551	1.7737
22	1.8296	1.9589	1.922	1.922		1.8296	1.8296
23	1.7741	1.848	1.8296	1.8665	1.8111	1.7372	1.7002
24	1.0288	1.7372	1.7926	1.7741	.7865	.7522	.7701
Max	1.8296	1.9978	1.9418	2.0538	1.8111	1.8296	1.8296
Min	.3353	.4862	.5365	.4588	.4641	.5281	.4588
Avg	1.1106	1.1131	1.2391	1.1553	.9930	.9430	1.0338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 203 / 11KV DIGHORI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8865	1.3203	.4075	.4031	.4252	.4715
2	.8488	.8488	1.1694	.4075	.3856	.4207	.4481
3	.8488		1.1317	.4031	.3814	.4115	.5788
4	.7545		1.0751	.3681	.3467	.3772	.7545
5	.7922		.7392	.3258	.3121	.3467	.6979
6	.4954		.4294	.2591	.2947	.253	.4527
7	.3772	.3961	.3361	.2591	.2743	.1943	.3395
8	.381	.3961	.3734	.2812	.3052	.3481	.3361
9	.415	.3856	.415	.2743	.3005	.3185	.3547
10	.3222	.2743	.2915	.6413	.4904	.3584	.2987
11	.3201	.3086	.3258	.5281	.547	.3961	.3222
12	.3647	.2915	.3814	.679	.6602	.4338	.39
13	.3812	.3601	.3988	.7545	.7282	.5228	.4458
14	.3647	.3429	.4161	.7922	.6535	.5281	.3944
15	.3563	.2915	.4334	.7356	.3961	.4904	.39
16	.3326	.3429	.3601	.5847	.3961	.415	.3521
17	.2591	.2743	.3258	.4904	.3961	.3772	.2515
18	.2641	.1715		.2263	.415	.3395	.1509
19	.6602	.583	.5906	.7356	.6036	.547	.6224
20	.8299	.7969	.8299	.9054	.8299	.7733	.811
21	.9242	.9335	.9335	.9242		.8764	.9431
22	.7356	.8865	.9149	.9054		.9054	.9054
23	.9242	.8865	.8775	.9054	.8402	.8573	.8865
24	.8775	.9054	1.4146	.8402	.4031	.4252	.4338
Max	.9242	.9335	1.4146	.9242	.8402	.9054	.9431
Min	.2591	.1715	.2915	.2263	.2743	.1943	.1509
Avg	.5704	.5281	.6732	.5681	.4710	.4725	.5013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON

Feeder No / Name : 401 / 33 KV DONGARGAON FEEDER

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.262	1.6289	1.6832	1.6832	1.6632	1.6289
2	1.4815		1.6289	1.6832	1.5746	1.6632	1.6118
3	1.4815	1.0082	1.5746	1.6832	1.4661	1.6804	1.5581
4	1.4969	1.0082	1.6289	1.6289	1.2489	1.5746	1.5581
5	1.4815	1.0082	1.6461	1.4661	1.1946	1.5581	1.5043
6	1.1163	.8962	1.0099	1.2346	1.0802	1.3575	1.182
7	.9877		.9665	.9556	1.1305	1.1065	1.2357
8	.9465		.8145	.8413	1.0682	.9556	1.094
9	.9036	.9991	.8842	1.0517	1.2094	1.0802	.9339
10	1.0534	1.1568	1.0402	1.1403	1.3146	1.2346	1.1317
11	1.1203	1.2752	1.2357	1.3575	1.3969	1.3375	.9774
12	1.2883	1.2197	1.5364	1.4118	1.773	1.4723	1.3575
13	1.3717	1.5203	1.6461	1.5746	1.773	1.1523	1.1403
14	1.7924	1.5746	1.3717	1.8267	1.8804	1.3032	1.1946
15	1.7558	1.3969	1.6632	1.7918	1.7353	1.2894	1.086
16	1.3432	1.2894	1.5524	1.6478	1.5043	1.2094	1.0317
17	1.1443	1.262	1.3523	1.5415	1.3432	1.1694	1.5203
18	.8413	1.2346		1.7741	1.5043	1.1443	1.3735
19	1.3672	1.3375	1.5364	1.7541	1.5775	1.4043	1.5261
20	1.6632	.8316	1.5364	2.0633	1.7353	1.7558	1.701
21	1.7558	1.701	1.8461	2.0633		1.8656	1.9204
22	1.6478	1.7558	1.773	1.8461		1.7375	1.9044
23	1.5912	1.7918	1.7375	1.7918	1.6804	1.701	1.885
24	1.5912	1.3717	1.7375	1.6832	1.7375	1.6804	1.6289
Max	1.7924	1.7918	1.8461	2.0633	1.8804	1.8656	1.9204
Min	.8413	.8316	.8145	.8413	1.0682	.9556	.9339
Avg	1.3627	1.2810	1.4499	1.5623	1.4823	1.4207	1.4036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 201 / 11 KV KINHI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3417	.3533	.4607				.3628
2	.3462	.3503	.4562				
3	.3433	.3598	.4577				
4	.3433	.3494	.5082				
5	.3433	.3727	.4993				
6	.3462	.372	.5396				.0488
7	.3658	.3628	.535				.317
8	.3873	.3731	.5039				.3292
9	.3715	.3896	.535				.4572
10				.5121	.5601	.5112	
11				.5121	.5647	.5304	
12				.5152	.5242	.5426	
13				.5365	.5213	.5469	
14				.4999	.4887	.5528	
15				.4993		.5539	
16				.5171	.4287	.5731	
17				.5588	.4858	.5853	
24		.3282	.4755	.503			
Max	.3873	.3896	.5396	.5588	.5647	.5853	.4572
Min	.3417	.3282	.4562	.4993	.4287	.5112	.0488
Avg	.3543	.3611	.4971	.5171	.5105	.5495	.303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 202 / 11 KV SATALWADA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0518	.061	.059	
2				.0488	.0579	.0645	
3					.0549	.0549	
4				.0446	.0549	.059	
5				.0476	.0579	.0564	
6				.049	.0732	.0584	
7				.0639	.0747	.0695	
8					.0732	.0649	
9				.0505	.0793	.0695	
10	.0372	.0416	.0431				.0608
11	.0398	.0431	.0401				.0654
12	.0348	.0461	.0476				.0768
13	.0445	.0416	.049				.0822
14	.0373	.0401	.0476				.0807
15	.0413	.0476	.052				.07
16	.0384	.0476	.0505				.068
17	.037	.0446	.0535				.0744
24	.0286				.0625	.0541	.0594
Max	.0445	.0476	.0535	.0639	.0793	.0695	.0822
Min	.0286	.0401	.0401	.0446	.0549	.0541	.0594
Avg	.0377	.0440	.0479	.0509	.0650	.0610	.0709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 204 / 11 KV KINHI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.481	.4108	.3868	.476	.4633	.4243
2	.4277	.4376	.4108	.3734	.4585	.4426	.3728
3	.4207	.4036	.3529	.3563	.438	.4047	.371
4	.4242	.3885	.3164	.3429	.3403	.3743	.3294
5	.4172	.3452	.3146	.3353	.3258	.3366	.2896
6	.2739	.3056	.2955	.3185	.312	.3253	.2722
7	.2229	.2942	.2651	.2787	.287	.2883	.2384
8	.2366	.2452	.2317	.2615	.2804	.2624	.2126
9	.234	.2244	.2257	.2418	.2734	.2314	.2138
10	.2448	.2561		.2622	.2572	.1984	.192
11	.2515	.2606		.283	.3018	.1984	.2524
12	.3118	.286	.1846	.3296	.332	.2173	.2734
13	.3085	.3224	.1807	.3827	.3387	.2303	.2835
14	.3353	.3224	.2353	.3786	.3348	.2384	.3118
15	.3018	.3116	.2233	.3615	.2146	.2629	.2454
16	.2263	.2615	.1701	.3473	.2146	.2445	.2445
17	.2332	.2722	.295	.3367	.2146	.3045	.241
18	.2804	.2906	.3403	.3188	.2818	.3786	.2516
19	.3765	.3873	.3792	.438	.3745	.4607	.3437
20	.4682	.4887	.5103	.5249	.4879	.4607	.4609
21	.5041	.4682	.5174	.5466	.5064	.4764	.513
22	.5055	.5191	.4997	.5176	.4879	.4656	.5055
23	.5055	.5004	.4871	.5068	.4682	.4513	.4753
24	.4382	.4942	.4817	.4992	.5144	.4572	.4572
Max	.5055	.5191	.5174	.5466	.5144	.4764	.513
Min	.2229	.2244	.1701	.2418	.2146	.1984	.192
Avg	.3495	.3569	.3331	.3720	.3550	.3406	.3240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064018 / 33KV SATALWADA

Feeder No / Name : 205 / 11 KV SATALWADA GT.

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5276	.6111	.6325	.6401	.6511	.606	.5975
2	.521	.5847	.583	.6325	.6572	.5959	.59
3	.5112	.5451	.5563	.6211	.6535	.5953	.556
4	.5079	.5394	.5392	.6059	.6219	.5749	.5158
5	.5145	.5168	.5335	.583	.5615	.5599	.481
6	.4359	.4929	.5085	.5527	.5068	.5373	.3958
7	.4091	.4556	.5004	.5265	.5394	.4465	.4902
8	.4177	.4426	.4887	.5231	.5014	.4678	.4609
9	.4728	.4609	.4835	.5341	.5245	.4382	.4742
10	.4225	.4489	.5121	.5085	.5825	.4749	.4873
11	.4627	.4742	.5104	.4609	.5281	.4678	.4973
12		.487	.548	.4814	.5867	.4997	.559
13	.4948	.5213	.5982	.5946	.5453	.5245	.5418
14	.456	.5357	.6045	.6237	.5324	.5174	.5281
15	.4124	.5377	.5611	.6414	.4476	.443	.4938
16	.389	.5011	.4907	.6166	.4627	.4242	.4458
17	.3968	.4426	.4887	.5828	.4728	.45	.43
18	.4382	.4633	.4749	.5683	.4632	.4678	.4784
19	.5457	.6045	.5679	.7271	.5636	.5946	.5847
20	.6796	.695	.7164	.8131	.6871	.6914	.7499
21	.6796	.7316	.6984	.7819	.6626	.6914	.7468
22	.6535	.7011	.6449	.7389	.6311	.6834	.7281
23	.63	.6668	.6304	.6877	.6033	.6348	.6979
24	.5243	.6262	.6478	.6478	.6859	.6131	.6348
Max	.6796	.7316	.7164	.8131	.6871	.6914	.7499
Min	.389	.4426	.4749	.4609	.4476	.4242	.3958
Avg	.5001	.5453	.5633	.6122	.5697	.5417	.5485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 201 / 11 KV CHANDORI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.5093	.6722	.6859	.6979	.6908	.6859
2	.6668	.4938	.6348	.6668	.7049	.6722	.6478
3	.6478	.4784	.6535	.6287	.679	.6535	.6287
4	.5906	.463	.6348	.5906	.679	.6348	.5906
5	.5335	.4321	.6348	.5716	.679	.5975	.5716
6	.4763	.3858	.4668	.5335	.5281	.5041	.4954
7	.4572	.3704	.4481	.4763	.4904	.4668	.4763
8	.4572	.3704	.4096	.4572	.5281	.4481	.4763
9	.4763	.3395	.4096	.5144	.547	.4481	.4954
10	.4572	.3704	.4763	.5525	.5847	.4668	.4763
11	.5041	.4012	.4954	.5716	.5847		.5525
12	.5415	.4424	.5335	.6287	.6413		.5716
13	.5788	.4917	.5906	.6287	.6413	.5144	.5906
14	.5601	.4748	.5906	.7049	.4904	.4763	.5144
15	.4481	.4578	.5525	.6859	.3961	.5144	.4763
16	.4108	.4239	.4954	.6287	.415	.5144	.5335
17	.3734	.4239	.4954	.5525	.4527	.5335	.381
18	.4854	.4409	.5335	.5525	.4338	.5144	.4954
19	.5601	.6348	.6668	.7049	.6224	.6859	.6859
20	.6161	.7282	.8002	.7811	.7356	.743	.7811
21	.6722	.7095	.8002	.8002	.7356	.7621	.7811
22	.6722	.6722	.743	.7621	.7356	.743	.7621
23	.6535	.6348	.724	.743	.7167	.724	.743
24	.6478	.5247	.6348	.7049	.6979	.6908	.7049
Max	.6722	.7282	.8002	.8002	.7356	.7621	.7811
Min	.3734	.3395	.4096	.4572	.3961	.4481	.381
Avg	.5481	.4864	.5874	.6303	.6007	.5909	.5882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 202 / 11 KV PITEZARI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4457	.4854	.5754	.5487	.5359	.5182
2	.5296	.4457	.4854	.5754	.5449	.5322	.5068
3	.5182	.4391	.4854	.5601	.5449	.5322	.4992
4	.4763	.4326	.4817	.5525	.5411	.499	.4839
5	.4611	.4194	.4817	.5335	.5563	.4842	.4763
6	.442	.3932	.4257	.4954	.4954	.4583	.4725
7	.4649	.3539	.4182	.4496	.4725	.4361	.4572
8	.4191	.3474	.3688	.4496	.4877	.4361	.4725
9	.4268	.3474	.3756	.4572	.4877	.4657	.4572
10	.4344	.367	.4268	.4649	.5106	.4287	.4725
11	.4451	.3736	.4649	.4649	.5182		.4877
12	.4527	.3867	.4801	.5182	.5335	.4344	.5106
13	.4753	.3998	.5258	.5182	.5182	.4572	.5182
14	.4678	.4063	.5335	.5335	.4465	.4572	.5335
15	.4678	.3867	.5182	.5335	.3827	.4572	.4954
16	.3923	.3932	.4649	.503	.3898	.4191	.4801
17	.4074	.3539	.4268	.4801	.4111	.4268	.4801
18	.43	.367	.4725	.5258	.4465	.4268	.4268
19	.4829	.5004	.5639	.5639	.5316	.5792	.5106
20	.5093	.5303	.6173	.6173	.567	.5944	.6173
21	.5357	.5303	.6097	.6173	.5528	.5792	.6249
22	.5055	.5153	.6059	.5792	.5245	.5487	.6097
23	.513	.4929	.5906	.5639	.5245	.5487	.5792
24	.503	.4391	.4929	.583	.5487	.5396	.5335
Max	.5357	.5303	.6173	.6173	.567	.5944	.6249
Min	.3923	.3474	.3688	.4496	.3827	.4191	.4268
Avg	.4698	.4195	.4917	.5298	.5036	.4903	.5093

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 203 / 11 KV BODRA

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.4208	.4929	.4649	.4014	.3906	.4572
2	.362	.4175	.4892	.4572	.3996	.3856	.4496
3	.362	.4124	.4817	.4458	.3958	.3823	.442
4	.3372	.4024	.4798	.4382	.3958	.3756	.4382
5	.3144	.3823		.4287	.394	.3521	.4363
6	.2953	.332		.402	.3734	.3336	.4249
7	.2934	.3085	.0803	.4115	.4276	.337	.4115
8	.3239	.3269	.2097	.3563	.4462	.3605	.4477
9	.3277	.3336	.1917	.4287	.4668	.3705	.442
10	.3506	.3734		.4249	.4294	.3504	
11	.3487	.342	.4382	.4553	.45	.4058	.3353
12	.3448	.28	.4496	.4915		.3734	.4249
13	.4058	.2766	.4534	.4325		.3868	.4306
14	.4096	.2867	.4572	.4115	.353	.4191	.442
15	.421	.285	.4287	.4115	.3401	.3125	.4401
16	.3277	.2548	.3677	.3982	.2332	.3429	.3772
17	.3677	.2565	.3391	.402	.2316	.3506	.3753
18	.3715		.3582	.3982	.2559	.4096	.4153
19	.4401	.562	.4077	.4344	.4	.482	.5125
20	.4896	.59	.5182	.4973	.4113	.5144	.5677
21	.5182	.5695	.5182	.4858	.4162	.5144	.5563
22	.5087	.5303	.4782	.4553	.387	.5106	.5239
23	.4915	.5022	.4763	.4325	.3822	.4782	.5049
24	.3429	.4208	.4929	.4725	.4052	.3957	.463
Max	.5182	.59	.5182	.4973	.4668	.5144	.5677
Min	.2934	.2548	.0803	.3563	.2316	.3125	.3353
Avg	.3791	.3855	.4099	.4349	.3816	.3973	.4486

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064019 / 33 KV PARASTOLA

Feeder No / Name : 411 / 33 kV Salebhata

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.7433	2.1091	2.1148	2.4291	1.4861	1.9433
2	1.6632	1.7204	2.0976	2.0748	2.4063	1.4518	1.8976
3	1.6861	1.7032	2.0862	2.0233	2.4063	1.4346	1.8461
4	1.6575	1.6575	2.0576	1.9547	2.3548	1.3603	1.6289
5	1.4289	1.4689	1.949	1.8747	2.332	1.2574	1.4289
6	1.2003	1.1317	1.5089	1.6461	2.0576	.9259	1.2803
7	1.1031	.9431	1.4689	1.5318	2.0919	.8116	1.2574
8	1.0517	1.1717	1.5375	1.5489	2.1605	1.2631	1.2631
9	.9488	1.2346	1.6861	1.6747	2.1891	1.166	1.3489
10	.8688	1.2289	1.5032	1.7718	2.1776	1.5718	1.5089
11	.9186	1.5089	1.5203	1.6975	1.6461	1.6861	1.6918
12	1.0979	1.6061	1.7433	2.332	2.5835	1.669	1.5947
13	1.2323	1.6918	1.9833	2.4691	.8745	1.3032	1.7776
14	1.2211	1.1946	2.029	2.5777	1.2517	1.7604	1.5375
15	1.1875	1.6404	1.8747	2.492	1.2289	1.7375	1.5718
16	.8514	1.5432	1.3832	2.3605	1.3489	1.7261	1.3432
17	.801	1.1145	1.7776	2.2177	1.0117	1.2346	1.3317
18	.913	1.046	1.1145	1.2631	.9831	1.1603	.9259
19	1.2771	1.3375	1.3832	1.5889	1.4118	1.4575	1.2574
20	1.4899	1.709	1.8633	1.8976	1.6118	1.5775	1.6232
21	1.6524	1.8404	1.909	1.9776	1.709	1.749	1.749
22	1.5348	1.789	1.8633	1.8747	1.6118	1.749	1.7547
23	1.5964	1.7147	1.7776	1.7776	1.5832	1.7032	1.6575
24	1.4518	1.8461	2.1434	2.1719	2.4691	1.5146	2.0176
Max	1.6861	1.8461	2.1434	2.5777	2.5835	1.7604	2.0176
Min	.801	.9431	1.1145	1.2631	.8745	.8116	.9259
Avg	1.2705	1.4827	1.7654	1.9547	1.8304	1.4482	1.5515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 201 / 11 KV GONDUMRI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381	.362	.3521	
2				.381	.362	.3521	
3				.381	.362	.3688	
4				.381	.362	.373	
5				.362	.362	.373	
6				.362	.4001	.373	
7				.362	.4191	.373	
8				.362	.4001	.373	
9				.362	.4001	.373	
10	.362	.3772	.3734				.3544
11	.362	.3584	.3921				.4024
12	.362	.3547	.3921				.4108
13	.362	.3547	.3734				.4108
14	.362	.3547	.3921				.4108
15	.362	.3734	.3921				.4108
16	.362	.3547	.3921				.3921
17	.362	.3734	.3734				.3734
24	.3658				.362	.3658	.3439
Max	.3658	.3772	.3921	.381	.4191	.373	.4108
Min	.362	.3547	.3734	.362	.362	.3521	.3439
Avg	.3624	.3627	.3851	.3704	.3791	.3677	.3899

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 202 / 11 KV WADAD AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.381	.362	.3294	
2				.381	.362	.3294	
3				.381	.362	.3294	
4				.381	.362	.3366	
5				.362	.362	.3366	
6				.362	.362	.3366	
7				.362	.4572	.3366	
8				.362	.381	.3366	
9				.362	.362	.3366	
10	.3982	.394	.362				.3721
11	.3982	.3761	.3439				.3403
12	.3801	.3761	.362				.3224
13	.362	.3761	.3801				.3439
14	.362		.362				.3258
15	.362	.3761	.3439				.3258
16	.3801	.3582	.3439				.3258
17	.3801	.3582	.362				.3258
24	.4024				.362	.3475	.3439
Max	.4024	.394	.3801	.381	.4572	.3475	.3721
Min	.362	.3582	.3439	.362	.362	.3294	.3224
Avg	.3806	.3735	.3575	.3704	.3734	.3355	.3362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 203 / 11 KV KHANDALA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1629	.1629				.2374
2	.1097	.1629	.1629				.2374
3	.1097	.1629	.181				.2543
4	.128	.1629	.1629				.2543
5	.128	.181	.181				.2543
6	.1463	.1991	.181				.2543
7	.1646	.1991	.181				.2543
8	.1463	.2172	.181				.2713
9	.1829	.1991	.2172				.2543
10				.2427	.3185	.2774	
11				.2601	.3185	.2947	
12				.2774	.3185	.2947	
13				.2947	.3185	.3121	
14				.3121	.3185	.3366	
15				.3121	.3018	.3544	
16				.2947	.2753	.3544	
17				.3121	.2753	.3544	
24		.1629	.1629	.1991			
Max	.1829	.2172	.2172	.3121	.3185	.3544	.2713
Min	.0732	.1629	.1629	.1991	.2753	.2774	.2374
Avg	.1321	.181	.1774	.2783	.3056	.3223	.2524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 204 / PALASGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
17	.4763						
24	.9907	.2835	.3582	.3109	.2926	.2743	.2896
Max	.9907	.2835	.3582	.3109	.2926	.2743	.2896
Min	.4763	.2835	.3582	.3109	.2926	.2743	.2896
Avg	.7335	.2835	.3582	.3109	.2926	.2743	.2896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 205 / SUKALI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2543	.2774	.2715	.2543	.1949	.2149
2	.2172	.2035	.2774	.2715	.2204	.1949	.2149
3	.181	.2035	.2601	.2481	.2204	.1595	.1791
4	.181	.2035	.2427	.2481	.2035	.1629	.1791
5	.1448	.2204	.2254	.2126	.2204	.1629	.1791
6	.1448	.1526	.156	.1715	.1526	.1448	.1433
7	.1267	.1357	.1387	.1326	.1357	.1448	.1433
8	.1267	.1187	.1526	.116	.1357	.1448	.1433
9	.1267	.1187	.1526	.1326	.1526	.1629	.1254
10	.1448	.1357	.1696	.1492	.1734	.1629	.1612
11	.1448	.1372	.1696	.1526	.208	.181	.1791
12	.1696	.1543	.2035	.1696	.208	.181	.1791
13	.1865	.1715	.2204	.2204	.208	.1448	.1791
14	.1696	.1715	.2035	.2374	.2254	.1448	.1772
15	.1526	.1715	.1865	.2374	.1734	.1448	.1595
16	.1187	.1543	.1696	.1526	.156	.1448	.1417
17	.1187	.1543	.1526	.1696	.156	.1629	.124
18	.1526	.1715	.1526	.1949	.1387	.1448	.1595
19	.2204	.2427	.2534	.2303	.208	.1991	.2126
20	.2543	.2601	.2715	.2835	.2561	.2353	.2481
21	.2543	.2601	.2715	.3012	.2743	.2534	.2658
22	.2713	.2774	.2715	.2835	.2561	.2534	.2658
23	.2713	.2774	.2896	.2543	.2561	.2534	.2835
24	.2715	.2713	.2774	.2896	.2543	.2743	.2534
Max	.2715	.2774	.2896	.3012	.2743	.2743	.2835
Min	.1187	.1187	.1387	.116	.1357	.1448	.124
Avg	.1842	.1926	.2144	.2138	.2020	.1814	.188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 206 / SAWARBANDH GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.3658	.3326	.3439	.2195	.2126
2	.3258	.362	.3658	.3326	.3439	.2172	.2126
3	.2715	.3439	.3475	.2957	.3077	.181	.1949
4	.2715	.3077	.3475	.2926	.2715	.181	.1949
5	.2172	.3258	.3109	.2561	.2896	.1791	.1949
6	.2172	.2353	.2195	.2172	.2353	.1612	.1772
7	.181	.2353	.2012	.181	.2172	.1612	.1772
8	.1991	.1991	.2195	.181	.2534	.197	.1949
9	.2353	.1612	.2561	.2172	.2534	.2149	.1772
10	.2534	.181	.2743	.2353	.2715	.2172	.1949
11	.1991	.2172	.3292	.2715	.3077	.2172	.2507
12	.1991	.1991	.3109	.3077	.3077	.181	.2686
13	.1991	.3077	.3475	.181	.2926	.2172	.2896
14	.2534	.3077	.3475	.3439	.3109	.2353	.2534
15	.3077	.3077	.3658	.362	.2378	.2172	.2715
16	.1267	.2896	.3109	.3258	.2378	.2172	.2715
17	.1448	.2534	.2195	.2715	.2195	.1991	.1991
18	.1448	.2534	.2012	.2715	.2012	.2353	.2534
19	.3077	.3292	.3326	.3258	.2926	.2534	.2896
20	.3982	.439	.3881	.4525	.3841	.362	.362
21	.4163	.439	.4435	.4706	.3841	.362	.4024
22	.3982	.4207	.4066	.4163	.3658	.362	.3841
23	.3801	.3841	.3511	.3801	.3475	.3439	.3475
24	.362	.3801	.3658	.3696	.362	.3475	.2534
Max	.4163	.439	.4435	.4706	.3841	.362	.4024
Min	.1267	.1612	.2012	.181	.2012	.1612	.1772
Avg	.2655	.3017	.3178	.3038	.2933	.2367	.2512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 201 / 11 KV S'Wafa AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509				.2629
2		.1989				.2498
3		.2012				.2366
4		.1486				.1972
5		.1829				.1943
6		.2126				.2462
7		.2591				.2629
8	.144	.1006				.2782
9	.2892	.301				.2896
10			.2782	.2681		
11				.2921		
12			.192	.2961	.1286	
13			.2201	.3001	.3001	
14			.212	.3001	.3241	
15			.212		.3281	
16			.2248	.088	.3161	
17			.2629	.1027	.3321	
24		.1362	.2705			.2629
Max	.2892	.301	.2782	.3001	.3321	.2896
Min	.144	.1006	.192	.088	.1286	.1943
Avg	.2166	.1892	.2341	.2353	.2882	.2481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 203 / 11KV SAKOLI FEEDER

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5384	1.5203	1.5546	1.5565	1.5043	1.448
2		1.5384	1.448	1.4632	1.5203	1.4864	1.3575
3		1.448	1.3756	1.3717	1.448	1.4327	1.267
4		1.448	1.267	1.267	1.3611	1.4327	1.1765
5		1.1765	1.182	1.1765	1.2536	1.3611	1.0745
6	1.0387	.9671	1.0387	1.0745	1.0745	1.0029	.9313
7	.9214	.8859	.9671	.9214	.985	.9425	.8859
8	.9568	.8505	.9214	.9036	.9036	.8328	.7973
9	.9745	.8859	.9391	.9214	.9745	.8596	.8764
10	1.0631	1.0454	1.0208	1.0277	1.134	.9214	.9391
11	1.1641	1.182	1.1765	1.2536	1.3466	1.0277	1.1104
12	1.2894	1.2894	1.2851	1.267	1.4148	1.0277	1.1462
13	1.3969	1.3394	1.3756	1.3213	1.5203	1.1462	1.267
14	1.5023	1.3756	1.4661	1.4842	1.4661	1.1283	1.2894
15	1.5023	1.4118	1.4661	1.4661	1.3213	1.0387	1.0498
16	1.2971	1.3394	1.247	1.4661	1.2308	1.0745	1.0029
17	1.1568	1.2178	1.2894	1.3253	1.1694	1.0631	.8775
18	1.1043	1.0985		1.2178	1.0692	.9882	1.0867
19	1.1919	1.2757	1.2536	1.4148	1.1999	1.0985	1.1694
20	1.3937	1.4118	1.4118	1.5384	1.3032	1.267	1.258
21	1.3937	1.4661	1.4815	1.5927	1.3756	1.3032	1.4506
22	1.4661	1.5565	1.6461	1.647	1.5203	1.4661	1.5203
23	1.6108	1.6108	1.6461	1.7013	1.5043	1.5203	1.5023
24		1.5384	1.5565	1.6095	1.6289	1.5043	1.4661
Max	1.6108	1.6108	1.6461	1.7013	1.6289	1.5203	1.5203
Min	.9214	.8505	.9214	.9036	.9036	.8328	.7973
Avg	1.2458	1.2874	1.3035	1.3328	1.3034	1.1846	1.1646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 204 / 11 KV LAKHANDUR FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5223	.0362	.0362	.0543	.0543	.0362	.0362
2	1.4327	.0362	.0362	.0543	.0543	.0362	.0362
3	1.3432	.0362	.0362	.0543	.0543	.0362	.0362
4	1.2536	.0362	.0362	.0543	.0543	.0362	.0362
5	1.0745	.0362	.0362	.0543	.0543	.0362	.0362
6	.0655	.0362	.0366	.0543	.0543	.0362	.0905
7	.0362	.0362	.0362	.0362	.0543	.0362	.0362
8	.0362	.0362	.0362	.0362	.0543	.0362	.0362
9	.0362	.0362	.0362	.0362	.0543	.0362	.0362
10	.0362	.0362	.0362	.0362	.0532	.0362	.0362
11	.0362	.0543	.0362	.0362	.0537	.0362	.0362
12	.0362	.0362	.0362	.0362	.0537	.0362	.0362
13	.0362	.0362	.0362	.0362	.0537	.0362	.0362
14	.0362	.0362	.0362	.0362	.0543	.0362	.0362
15	.0362	.0362	.0362	.0362	.0362	.0362	.0362
16	.0362	.0362	.0362	.0362	.0362	.0362	.0362
17	.0362	.0362	.0362	.0362	.0362	.0362	.0362
18	.0362	.0362		.0543	.0362	.0362	.0362
19	.0362	.0362	.0362	.0362	.0362	.0362	.0362
20	.0362	.0362	.0543	.0362	.0543	.0362	.0362
21	.0362	.0362	.0724	.0543	.0543	.0362	.0362
22	.0362	.0362	.0362	.0543	.0543	.0362	.0362
23	.0362	.0362	.0362	.0543	.0543	.0362	.0362
24	1.6118	.0362	.0362	.0362	.0543	.0543	.0362
Max	1.6118	.0543	.0724	.0543	.0543	.0543	.0905
Min	.0362	.0362	.0362	.0362	.0362	.0362	.0362
Avg	.3716	.0370	.0386	.0437	.0504	.0370	.0385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 205 / 11 KV EKODI FEEDER

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.2804	.2947	.4031	.4161	.3721	.3814
2	.3155	.2804	.2743	.3772	.3814	.3681	.3429
3	.3155	.2572	.2743	.3772	.3772	.3467	.3429
4	.2601	.2572	.2572	.3429	.3391	.3294	.3429
5	.2601	.2401	.2543	.3086	.3018	.3086	.3052
6	.2058	.1844	.3052	.2713	.2683	.2374	.2515
7	.2155	.176	.2486	.2321	.2622	.2347	.2401
8	.2591	.144	.2785	.2105	.2721	.208	.253
9	.2155	.1619	.2622	.2458	.2949	.2294	.2214
10	.2515	.176	.2915	.2591	.2949	.2561	.2429
11	.2785	.192	.2883	.2683	.3481	.2591	.2915
12		.2241	.3222	.3018	1.3413	.2881	.3239
13	.1052	.2204	.3429	.3429	.3353	.3239	.3149
14	.1509	.2374	.3814	.3814	.2984	.2915	.3149
15	.2401	.2683	.3814	.3681	.2818	.3077	.3277
16	.1966	.2321	.3647	.3467	.2267	.2429	.3239
17	.2031	.208	.3277	.3353	.2458	.2721	.3125
18	.1619	.1898		.3149	.7287	.2688	.2968
19	.1989	.2155	.3086	.3391	.2865	.2785	.3201
20	.2572	.2947	.3721	.4382	.3121	.3506	.3944
21	.2774	.3121	.4298	.4557	.3544	.3898	.4508
22	.3155	.3155	.4252	.4557	.3898	.4207	.4557
23	.2804	.3155	.4207	.4557	.3721	.3467	.4382
24	.3544	.2804	.2947	.4207	.4207	.3721	.3814
Max	.3544	.3155	.4298	.4557	1.3413	.4207	.4557
Min	.1052	.144	.2486	.2105	.2267	.208	.2214
Avg	.2467	.2360	.3218	.3438	.3812	.3043	.3280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 065004 / 33 KV SAKOLI

Feeder No / Name : 206 / 11 KV SHENDURWAFI GT.

Gaothan Feeder

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.4712	1.4335	1.4146	1.4712	1.5278	1.4712
2	1.2936	1.4712	1.3957	1.358	1.3957	1.5278	1.4146
3	1.2567	1.4146	1.3203	1.2696	1.307	1.5089	1.3203
4	1.1523	1.4003	1.2323	1.1763	1.2449	1.4937	1.226
5	1.0974	1.2803	1.1088	1.0719	1.1203	1.4003	1.1203
6	.8869	.8688	.9425	.9795	1.0269	.9979	.9979
7	.7442	.7701	.8326	.9709	.9335	.924	.8501
8	.7442	.7602	.7964	.8048	.8871	.8501	.8326
9	.823	.7682	.8688	.8316	.9055	.7577	.8589
10	.7712	.8316	.9335	.9149	.9896	.8402	
11	.9425	.6154	.9709	1.094	1.094	.9808	
12	1.0829	.6516	1.1883	1.226	1.1317	.9149	
13	1.1506	.7316	1.3203	1.3203	1.2449	.9709	
14	1.226	.7964	1.3392	1.3769	1.1576	1.0185	1.3908
15	1.2637	1.086	1.3203	1.3957	.9896	.8962	1.1883
16	.8589	1.0269	1.1506	1.2637	.9149	.8501	1.1128
17	.0347	.9709	.9709	1.1128	.9149	.8962	1.0185
18	1.1317	.9335		1.1128	.9619	.9054	.9242
19	1.2071	1.1883	1.226	1.2826	1.1576	1.1694	1.1506
20	1.4523	1.4901	1.5089	1.6032	1.4712	1.4335	1.4712
21	1.5089	1.5466	1.6221	1.6975	1.5278	1.5089	1.5466
22	1.5655	1.5844	1.6975	1.6221	1.5988	1.5655	1.6409
23	1.5466	1.5466	1.5466	1.6409	1.5655	1.5623	1.5844
24	1.4335	1.4712	1.4901	1.4712	1.5466	1.5466	1.5089
Max	1.5655	1.5844	1.6975	1.6975	1.5988	1.5655	1.6409
Min	.0347	.6154	.7964	.8048	.8871	.7577	.8326
Avg	1.1049	1.1115	1.2268	1.2505	1.1899	1.1687	1.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 401 / SAKOLI -I

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.4115	.6722	.5658	.6104	.5144	.8488
2	.4681	.407	.6099	.5658	.5533	.5144	.5533
3	.4681	.407	.407	.5658	.5533	.5087	.3561
4	.4681	.2486	.4024	.5658	.5533	.4578	.3521
5	.4733	.3521	.463	.5144	.5533	.4578	.3481
6	.3521	.2915	.6224	.4475	.4321	.3441	.2846
7	.3361	.2743	.6859	.3841	.3749	.3241	.5041
8	.3401	.5041	.6859	.4218	.4218	.3241	.5658
9	.3401	.2709	.7356	.427	.4321	.3281	.5093
10	.3795	.2778	.4858	.7356	.6859	.427	.2743
11	.4372	.2812	.4973	.4915	.7356	.427	.5344
12	.144	.3441	.503	.679	.7922	.5556	.5344
13	.2543	.3481	.5533	.7922	.8002	.743	.547
14	.3052	.4344	.6104	.7922	.7922	.7356	.4915
15	.3932	.4527	.5533	.7356	.4321	.7356	.5344
16	.3241	.3978	.5533	.7356	.4687	.743	.5596
17	.2709	.3841	.4321	.7922	.5218	.7922	.4687
18	.2709	.3749	.4218	.5344	.4321	.5155	.4687
19	.3441	.4475	.4973	.6173	.4321	.5281	.5281
20	.4115	.5201	.5784	.6762	.5258	.5658	.6104
21	.4161	.5201	.631	.6762	.5201	.6762	.6173
22	.463	.5721	.6241	.6687	.5721	.6687	.6173
23	.4161	.5201	.6173	.6173	.5144	.6104	.6104
24	.5258	.4161	.6722	.8573	.6104	.5144	.7356
Max	.5258	.5721	.7356	.8573	.8002	.7922	.8488
Min	.144	.2486	.4024	.3841	.3749	.3241	.2743
Avg	.3803	.3941	.5631	.6191	.5550	.5422	.5189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 402 / 33 KV WADAD

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9638	3.8009	4.2896	4.7051	4.7125	4.6571	4.0832
2	3.9638	2.4143	3.9758	4.7611	4.369	4.6016	4.0295
3	3.9095	2.8778	4.137	4.6491	4.369	4.4907	3.9758
4	3.8958	2.7692	4.0832	4.5931	4.313	4.9343	3.083
5	3.6763	2.6606	3.9095	4.369	4.201	4.2135	3.7071
6	2.6578	2.1033	2.6046	3.5288	3.4751	3.5837	2.7046
7	2.1559	1.5432	2.2885	3.0727	3.4385	.3721	2.3868
8	2.2365	.8505	1.9982	2.9864	3.4385	3.2956	2.4366
9	2.2365	2.2365	2.3405	3.2922	3.638	3.4385	2.1136
10	3.0178	2.9938	3.3048	3.0624	3.0167	2.5943	4.8868
11	3.2373	3.4168	3.8255	3.1699	3.3653	2.7469	3.5117
12	3.6763	3.5848	4.313	3.5837	3.8146	3.0498	4.181
13	4.0604	4.257	4.5462	3.922	4.1907	2.9767	4.1701
14	4.4353	4.181	4.369	4.3519	4.1993	3.083	4.2798
15	4.3244	4.1027	4.6571	4.137	3.3288	2.7869	4.1267
16	3.4374	3.77	4.2798	3.7071	2.8995	2.6526	3.638
17	3.0407	3.2922	3.7311	3.3288	2.5652	2.6235	3.7209
18	2.0285	2.4446	2.572	3.1024	2.5943	2.3663	2.4143
19	3.2922	3.4208	3.546	3.7071	3.4751	3.2036	3.2236
20	3.9918	4.3244	4.4445	4.8834	4.1152	4.0472	4.1152
21	4.2798	4.4907	4.5542	4.8834	4.225	4.2798	4.3896
22	4.2798	4.5542	4.4445	4.4525	4.1267	4.2353	4.3439
23	4.1152	4.3982	4.2353	3.9095	4.0181	4.0724	4.1267
24	4.2438	3.8552	4.4525	3.8683	4.8234	4.4696	4.417
Max	4.4353	4.5542	4.6571	4.8834	4.8234	4.9343	4.8868
Min	2.0285	.8505	1.9982	2.9864	2.5652	.3721	2.1136
Avg	3.5065	3.2643	3.7876	3.9178	3.7797	3.4490	3.6694

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 403 / SAKOLI II

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9127	2.9127	2.9687	3.0247	3.0807	2.9127	2.8567
2	2.8006	2.8567	2.9127	2.9687	3.0247	2.8006	2.8006
3	2.7446	2.7446	2.8006	2.9127	2.9127	2.6886	2.6886
4	2.7161	2.6886	2.7446	2.8006	2.8567	2.6326	2.5766
5	2.5463	2.4897	2.6029	2.6595	2.6326	2.4897	2.4086
6	.9522	1.8673	2.037	2.0936	2.037	1.9805	1.9805
7	1.7541	1.6409	1.7541	1.9605	1.8484	1.6804	1.7364
8	1.6975	1.5684	1.7541	1.6804	1.7364	1.5684	1.6244
9	1.7364	1.6804	1.7924	1.7924	1.9044	1.4712	1.6804
10	1.9239	1.8484	1.9605	1.9605	2.1845	1.7924	.9156
11	2.1285	1.7878	2.0936	2.2405	2.4086	1.9404	1.1568
12	2.3525	1.9667	2.4646	2.4646	2.6886	1.9605	1.1568
13	2.5766	2.1262	2.8006	2.6886	2.7446	2.0725	1.2757
14	2.7446	2.2028	2.8006	2.8567	2.5766	2.1285	2.6612
15	2.8006	2.5766	2.8006	2.8006	2.2965	1.9805	2.1845
16	2.2177	2.3525	2.5766	2.7446	2.0725	2.0165	2.0725
17	1.2209	2.2405	2.2405	2.4086	2.1285	2.0165	1.8484
18	2.2405	2.0725	1.9959	2.2965	1.9959	1.9404	1.9959
19	2.4086	2.4646	2.3525	2.6612	2.3525	2.2405	2.3285
20	2.8567	2.8567	2.8858	3.1927	2.7161	2.6886	2.6886
21	2.9127	3.0247	3.0807	3.3048	3.1927	2.8006	3.1927
22	3.0247	3.1367	3.1927	3.2487	3.0247	3.0247	3.1927
23	3.1367	3.1367	3.1927	3.3608	3.0807	3.0807	3.1367
24	2.9687	3.0247	3.0247	3.0247	3.1367	2.9687	3.0247
Max	3.1367	3.1367	3.1927	3.3608	3.1927	3.0807	3.1927
Min	.9522	1.5684	1.7541	1.6804	1.7364	1.4712	.9156
Avg	2.3906	2.3861	2.5346	2.6311	2.5264	2.2865	2.2160

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 404 / 33 KV PARASTOLA

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4517	3.6008	3.9609	4.1872	4.3004	3.2253	3.7346
2	3.4517	3.6008	3.9043	4.1307	4.2438	3.1687	3.678
3	3.3951	3.7151	3.8477	4.0741	4.1872	3.1121	3.6214
4	3.3385	3.4865	3.4294	4.0741	4.1872	3.0556	3.6008
5	3.2819	3.3385	3.2819	3.9609	4.1307	2.999	3.4865
6	2.6029	2.6595	2.6595	3.2819	3.5848	2.3765	2.915
7	2.4331	2.3525	2.6292	2.9424	3.5482	2.1502	2.6595
8	2.3765	2.3525	2.7726	2.8292	3.7146	2.0936	2.7161
9	2.2405	2.4331	2.7726	3.1927	3.6969	2.4897	2.7726
10	2.3285	2.6029	2.915	3.3608	3.8089	3.1121	2.3765
11	2.4394	2.915	3.2007	3.0807	4.0329	3.0556	2.9687
12	2.6326	3.0864	3.4517	3.9209	3.8477	3.1121	3.0807
13	2.9424	3.2579	3.678	4.0889	2.1502	2.9721	3.3048
14	2.9424	2.6863	3.7912	4.257	2.4331	3.2253	2.8292
15	2.6326	3.1121	3.5648	4.201	2.2291	3.0556	3.1436
16	1.8604	3.0293	2.9721	3.8649	2.2634	3.1121	2.8578
17	1.9753	2.5463	3.2253	3.6969	2.1148	2.7435	2.7435
18	2.0005	1.8107	2.2731	2.6326	2.037	2.1845	2.037
19	2.6863	2.8292	2.8567	3.0807	2.8858	2.8292	2.8292
20	3.2579	3.6214	3.7346	3.7912	3.3385	3.3951	4.6965
21	3.2253	3.6214	3.7912	3.8477	.3961	3.4517	3.6214
22	3.2819	3.5648	3.678	3.6214	3.2819	3.4517	3.6214
23	3.1687	3.3385	3.5082	3.678	3.1687	3.3385	3.4168
24	3.3385	3.658	4.0175	4.357	4.357	3.3951	3.7346
Max	3.4517	3.7151	4.0175	4.357	4.357	3.4517	4.6965
Min	1.8604	1.8107	2.2731	2.6326	.3961	2.0936	2.037
Avg	2.8035	3.0508	3.3298	3.6730	3.2475	2.9627	3.1853

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 405 / 33 KV ARJUNI MORGAON

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4728	3.5848	3.5848	3.8477	3.4374	3.7912	3.6969
2	3.4728	3.3048	3.6408	3.8649	3.6408	3.4728	3.5848
3	3.4168	2.3285	3.6408	3.7529	3.5848	3.4374	3.5848
4	3.271	3.271	3.4374	3.7346	3.4728	3.3265	3.4168
5	2.9321	3.1602	3.2922	3.5848	3.3819	3.2156	3.271
6	2.3148	2.2365	2.3663	2.5514	2.2634	2.4983	2.524
7	1.989	1.9204	2.2382	2.1559	2.1125	1.8679	2.0388
8	1.7341	1.0288	2.2634	1.9393	2.0388	1.8896	1.9393
9	1.8947	2.0885	2.2634	2.3137	2.0153	2.1845	2.0062
10	2.1874	2.2365	2.3405	2.4983	2.3148	2.4177	1.0974
11	2.364	2.0885	2.5514	3.083	2.3663	2.1091	1.1694
12	2.4983	2.3102	2.4177	2.8778	3.2156	2.3663	1.2934
13	2.5514	1.9959	3.1602	3.0178	2.9081	2.4188	2.5789
14	2.7692	2.9864	3.4168	3.1276	3.3048	2.5789	2.9384
15	3.1602	3.0178	3.5848	3.1276	2.7984	2.2885	2.5252
16	2.7984	2.6326	2.9938	2.8532	2.4983	2.2857	1.9959
17	2.4177	2.1285	2.4451	2.4451	1.6804	2.0576	2.1559
18	2.2565	2.0513	2.2857	2.364	1.4415	2.0285	2.0805
19	2.8235	2.8475	2.9081	2.9081	2.7149	2.7149	2.8235
20	3.095	3.4568	3.6969	3.5482	2.9864	3.2922	3.4374
21	3.3819	3.6591	3.7529	3.4928	3.1276	3.3819	3.4928
22	3.8089	3.8089	3.9209	3.6408	3.6969	3.9609	3.9609
23	3.8089	3.5848	3.8477	3.9043	3.8089	3.9043	3.8477
24	3.5848	3.678	3.5848	3.9043	3.6969	3.7529	3.7912
Max	3.8089	3.8089	3.9209	3.9043	3.8089	3.9609	3.9609
Min	1.7341	1.0288	2.2382	1.9393	1.4415	1.8679	1.0974
Avg	2.8335	2.7253	3.0681	3.1058	2.8545	2.8018	2.7188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 409 / 33KV SOUNDAD FEEDER

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4331	3.2253	2.5463	1.4289	1.5123	1.4289	1.4289
2	2.3594	2.8006	2.6595	1.3717	1.5278	1.3717	1.4289
3	2.3765	2.8006	2.5463	1.4289	1.4712	1.3717	1.3717
4	2.3765	2.7435	2.6029	1.358	1.358	1.3146	1.3146
5	2.2634	2.6029	2.4897	1.3146	1.3146	1.1883	1.3146
6	1.8673	2.0936	2.037	1.0751	1.1431	1.1883	1.1431
7	1.6244	.691	1.8107	.9054	1.0751	1.0288	1.0185
8	1.6244	1.9433	1.5278	.9054	1.0185	.9717	.9619
9	1.5844	2.1502	1.9044	.9619	.9619	.8488	1.0288
10	1.6409	2.1148	2.0725	1.086	1.2449	.9145	.5373
11	2.0936	2.2291	2.3765	1.0751	1.2574	.9619	.6036
12	2.4897	2.2634	2.5206	1.2574	1.4146	1.086	.7133
13	2.6292	2.4331	4.5931	1.4146	1.4861	1.2449	.7522
14	2.6863	2.4331	.9979	1.4712	1.2574	1.1431	.7522
15	2.5463	2.4331	1.3014	1.4146	1.0751	1.1883	1.3014
16	2.0005	2.2068	1.0751	1.358	.9619	1.086	.5721
17	1.9239	1.9805	1.1883	1.2883	1.4146	1.0185	.4681
18	2.0005	2.1622	1.1763	1.2323	.9717	1.0751	.4527
19	2.2068	2.2634	1.2574	1.358	1.1317	1.3146	1.2883
20	2.915	2.7726	4.6868	1.6004	1.358	1.4289	1.4712
21	2.9424	2.8292	1.6975	1.6004	1.3014	1.3443	1.4712
22	3.0293	2.8292	1.358	1.6004	1.4146	1.4289	1.4712
23	2.9721	2.7161	1.3443	1.5278	1.358	1.4861	1.4146
24	2.4331	2.915	2.6029	1.5844	1.4712	1.358	1.4289
Max	3.0293	3.2253	4.6868	1.6004	1.5278	1.4861	1.4712
Min	1.5844	.691	.9979	.9054	.9619	.8488	.4527
Avg	2.2925	2.4014	2.0989	1.3175	1.2709	1.1997	1.0712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-JUN-17 and 07-JUN-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 067010 / 132 KV SAKOLI

Feeder No / Name : 410 / 33 KV SATALWADA

HV Express Feeder

Feeder KV- 33 / INCOMING

DATE	01-JUN-17	02-JUN-17	03-JUN-17	04-JUN-17	05-JUN-17	06-JUN-17	07-JUN-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5043	1.5746	1.7187	1.3443	1.3443	1.3014	1.8107
2	1.4506	1.5203	1.6632	1.3443	1.3443	1.3014	1.2323
3	1.4506	1.5203	1.6632	1.3443	1.3443	1.2323	1.2323
4	1.4506	1.4661	1.6632	1.3443	1.3443	1.2323	1.2197
5	1.382	1.4506	1.6461	1.2883	1.2883	1.2323	1.1643
6	1.1317	1.1443	1.4266	1.0642	.9425	1.0082	.9979
7	1.0288	1.5604	1.3169	.823	.9522	.9054	1.1431
8	1.0402	1.0402	1.262	.8316	.9522	.8402	1.1883
9	1.2752	1.0402	1.262	.8871	1.0082	.8402	1.3014
10	.8253	.7613	.3887	1.358	1.5278	1.4146	.9619
11	.9602	.8916	.7305	1.4712	1.5844	1.4146	1.0185
12	.5418	.9722	.7442	1.4712	1.8107	1.4712	1.1883
13	1.1043	.9602	.9979	1.7541	1.7541	1.5844	1.1883
14	1.0437	.9482	1.0534	1.8107	1.4415	1.3014	1.1883
15	.8688	.9362	1.0534	1.8107	1.0534	1.4146	.8488
16	.651	.9031	.9328	1.7541	.8573	1.4146	.8962
17	.7305	.7928	.8871	1.6975	1.4146	1.4712	.9054
18	.7928	.8579	.9425	1.0642	.8779	.8871	.9054
19	1.0517	1.1523	1.1763	1.3443	1.2197	1.3306	1.2449
20	1.3117	1.4083	1.5684	1.7541	1.5123	1.386	1.5844
21	1.3117	1.4083	1.5684	1.6409	1.4563	1.4003	1.5278
22	1.278	1.3735	1.5123	1.5123	1.3443	1.4563	1.4712
23	1.2146	1.3077	1.3443	1.5684	1.2883	1.2883	1.4146
24	1.166	1.5203	1.3077	1.8107	1.3443	1.3443	1.358
Max	1.5043	1.5746	1.7187	1.8107	1.8107	1.5844	1.8107
Min	.5418	.7613	.3887	.823	.8573	.8402	.8488
Avg	1.1069	1.1880	1.2429	1.4206	1.2920	1.2697	1.208