

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 204 / 11 KV Dhargaon Feeder****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.7202	.6859	.7373	.7716	.7537	.7202
2	.6249	.7202	.6859	.7373	.7716	.7373	.7373
3	.6478	.7202	.6859	.7373	.7716	.7537	.7373
4	.6478	.7202	.6859	.763	.7716	.7537	.7545
5	.6478	.7202	.6859	.763	.7716	.7459	.7545
6	.7459	.8288	.7373	.7888	.8764	.7373	.8478
7	.8383	.8288	.7373	.7802	.8764	.8192	.8478
8	.8288	.8288	.8288	.8669	.9745	.9012	.9012
9	.9221	.9116	.9116	.9431	1.0631	.9012	.9831
10	.9221	.9116	.9221	.9221	.8916	.9012	.9831
11	.9221	.9221	1.0174	1.0059	1.2003	1.0402	.9488
12	1.0059	.9602	.9717	1.1022	1.2003	.9602	.9602
13	.9831	.9602	.9717	1.1022	1.2003	1.065	.9602
14	.9831	.9602	1.065	1.0898		1.065	.9488
15	.9717	.9602	1.0526	1.0279	1.2717	.9945	.8697
16	.9831	.8802	1.065	1.1203	1.2289	1.0936	.9488
17	.9602	.9602	.8097	1.0402	1.2717	1.0936	.9488
18	1.2269	1.1393	1.2403	1.2003	1.3565	1.286	1.286
19	1.2269	1.1393	1.2403	1.2136	1.1469	1.3003	1.2003
20	1.1517	1.0517	1.1517	1.2136	1.065	1.2003	1.1145
21	1.0631	.964	.9745	1.0402	.9831	1.0288	1.1145
22	.8002	.7802	.8573	.8573	.8192	.8764	.8573
23	.7202	.6935	.8573	.7716	.7459	.7888	.7373
24	.6249	.7202	.6859	.7116	.7716	.7459	.7202
Max	1.2269	1.1393	1.2403	1.2136	1.3565	1.3003	1.286
Min	.6249	.6935	.6859	.7116	.7459	.7373	.7202
Avg	.8781	.8751	.8970	.9390	.9914	.9393	.9118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 205 / 11 KV MIDC II feeder
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.4801	.7468	.724	.8488	.5258	.7468
2	.8402	.4801	.7468	.7011	.8488	.6001	.7468
3	.8145	.4801	.7316	.6859	.8488	.6001	.7468
4	.8145	.4801	.7316	.6783	.8488	.6706	.6783
5	.8145	.4801	.7316	.6706	.8488	.6554	.6783
6	.5601	.6401	.7316	.7545	.5087	.5735	.5868
7	.5068	.3887	.6859	.6783	.5735	.5335	.5868
8	.6201	.5868	.4334	.8402	.8488	.7545	.9431
9	.5668	.6859	.5258	.905	.8316	.9145	.905
10	.5935	1.226	.8402	1.0374	1.1317		1.4146
11	.5935	.924	.7392	1.1317	.8402	1.0974	1.0974
12	.5801	1.226	1.0374	1.4146	1.226	1.4146	1.3203
13	.5535	.9431	.7392	1.0374	1.226	1.1317	1.1088
14	.5601	1.1317	1.3203	1.0374		1.3203	1.307
15	.4858	.6268	.8402	.8316	1.0974	1.1088	1.1317
16	.5935	1.0374	1.226	.8316	1.1317	1.226	1.4146
17	.6068	1.0374	1.226	1.1317	1.1317	1.1317	1.3203
18	.4687	1.1317	1.226	1.1317	1.1317	1.1317	1.1317
19	.4515	1.0269		.9431	.9955	.924	.9145
20	.3572	.7973	.905	.9431	.7087	.6859	.7545
21	.463	.823	.8059	.8402	.7087	.7716	.7545
22	.3953	.7392	.7087	.8488	.7164	.8954	.5668
23	.301	.7468	.7011	.924	.5373	.5935	.5258
24	.8402	.4801	.7468	.724	.8488	.5316	.7468
Max	.8402	1.226	1.3203	1.4146	1.226	1.4146	1.4146
Min	.301	.3887	.4334	.6706	.5087	.5258	.5258
Avg	.5926	.7750	.8316	.8936	.8886	.8605	.922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 207 / 11KV COBRA BN.****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.0572	.0572	.0572	.0572
2	.0762	.0572	.0572	.0572	.0572	.0572	.0572
3	.0762	.0572	.0572	.0381	.0572	.0572	.0572
4	.0762	.0572	.0572	.0381	.0572	.0572	.0572
5	.0572	.0572	.0572	.0381	.0572	.0572	.0572
6	.0381	.0381	.0381	.0381	.0381	.0572	.0381
7	.0381	.0572	.0572	.0381	.0381	.0572	.0381
8	.0381	.0572	.0572	.0381	.0381	.0572	.0381
9	.0572	.0572	.0572	.0381	.0381	.0572	.0381
10	.0381	.0381	.0572	.0381	.0381	.0572	.0381
11		.0381	.0381	.0381	.0572	.0381	.0381
12		.0381	.0381	.0381	.0377	.0381	.0381
13	.0572	.0381	.0381	.0191	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381		.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0191	.0191
16	.0381	.0381	.0381	.0381	.0381	.0381	.0191
17	.0381	.0381	.0381	.0381	.0572	.0381	.0572
18	.0762	.0566	.0762	.0572	.0754	.0572	.0572
19	.0953	.0953	.0762	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0762	.0953
22	.0762	.0762	.0762	.0762	.0953	.0762	.0762
23	.0762	.0762	.0762	.0762	.0762	.0572	.0762
24	.0762	.0762	.0762	.0572	.0572	.0572	.0572
Max	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Min	.0381	.0381	.0381	.0191	.0377	.0191	.0191
Avg	.0624	.0572	.0580	.0508	.0580	.0556	.0532

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 401 / 33 KV Ashok Leyland Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1121	2.5463	3.3951	2.8006	3.3951	2.8006	
2	2.8292	2.5463	3.3951	2.8006	3.1121	2.8006	2.8292
3	2.8292	2.5463	3.1121	2.8006	3.1121	2.8006	2.8292
4	2.8292	2.5463	3.1121	2.5206	2.5463	2.8006	2.8292
5	2.8292	2.5463	3.1121	2.5206	2.6029	2.4949	2.8292
6	2.5463	2.5463	2.5463	2.5206	2.2634	2.5503	2.8292
7	3.3951	3.3951	3.678	2.8006	2.8292	3.678	3.678
8	2.8292	2.8292	2.5463	2.8006	3.1121	2.8292	3.678
9	3.678	3.3951	3.6037	2.8006	2.8292	3.3951	3.9609
10	3.678	3.678	3.1121	3.0807	2.5463	3.3951	3.678
11	2.5463	2.8292	3.1121	3.1121	1.9404	2.5463	3.678
12	3.3951	3.1121	3.1121	3.1121	2.4949	3.3951	3.3951
13	3.1121	3.1121	3.1121	3.678	1.9404	3.1121	3.3951
14	2.8292	2.8292	3.0807	3.1121		2.8292	3.3951
15	2.2634	2.8292	3.0807	2.2634		2.8292	3.3951
16	3.678	3.3951	3.0807	3.9609	1.8004	3.9609	3.9209
17	3.678	3.9609	2.8006	4.2438	2.8292	3.9609	4.2438
18	3.9609	4.2438	3.6408	4.2438	2.8292	4.2438	3.9209
19	3.1121	3.1121	3.3608	3.9609	2.2405	3.3951	3.9209
20	3.3951	3.3951	3.0807	3.3951	2.6029		3.9209
21	3.3951	3.3951	3.0807	3.9609	2.6029	3.9609	3.6408
22	3.1121	3.3951	3.0807	3.678	2.5206	3.4259	3.6408
23	3.1121	2.8292	3.0807	3.1121	2.5206	2.8292	3.3608
24	3.1121	2.8292	2.8292	3.0807	3.3951	2.5206	2.8292
Max	3.9609	4.2438	3.678	4.2438	3.3951	4.2438	4.2438
Min	2.2634	2.5463	2.5463	2.2634	1.8004	2.4949	2.8292
Avg	3.1357	3.0768	3.1311	3.1817	2.6394	3.1545	3.4695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 403 / 33 KV LAKHORI FEEDER
Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3395	.3961		.3361	.3961	.2829
2	.3326	.3395	.3961	.3921	.3361	.3961	.2829
3	.3326	.3395	.3961	.3921	.3361	.3961	.2829
4	.3881	.3395	.3961	.4481	.3258	.3961	.2829
5	.4435	.3961	.3961	.4481	.3361	.3961	.3961
6	.499	.4527	.3961	.4481	.3921	.5093	.5093
7	.6099	.6224	.5093	.6161	.5601	.679	.679
8	.6099	.5973		.6722	.6161	.6224	.679
9	.6099	.6224	.6224	.6722	.6722	.679	.6224
10	.6653	.6224	.7356	.6722	.6722	.7922	.679
11	.679		.7922	.6722	.8779	.7922	.7922
12	.5658		.7356	.7282	.7842	.7922	.679
13	.4527		.679	.6722		.5658	.5041
14	.4527		.6224	.4481		.5093	.5041
15	.5093		.6722	.6161	1.0185	.6224	.5601
16	.5658	.5658	.5601	.6722	.7922	.679	.7282
17	.679	.7922	.8402	.7282	.7356	.6224	.8962
18	1.0185	1.0185	1.1203	1.0642	1.1317	1.0751	1.1203
19	1.0185	.9054	1.0082	.9522	1.0751	1.0751	1.0082
20	.9054	.8488	.9522	.9522	1.0185	.8488	.9522
21	.8488	.7356	.7282	.6722	.7922	.7922	.7842
22	.5658	.5093	.5601	.5041	.5658	.5658	.5601
23	.3961	.3961	.3921	.3361	.3961	.4527	.4481
24	.3326	.3395	.3961		.3361	.3961	.3395
Max	1.0185	1.0185	1.1203	1.0642	1.1317	1.0751	1.1203
Min	.3326	.3395	.3921	.3361	.3258	.3961	.2829
Avg	.5756	.5675	.6219	.6263	.6412	.6271	.6072

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064004 / 33 KV GADEGAON****Feeder No / Name : 404 / 33 KV Varam Power
Feeder KV- 33 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	8.1207	8.4499	8.5048	.439	.2743	.1097	.0549
2	7.9561	8.3951	8.3402	.4938	.2743		.0549
3	8.1756	8.3402	8.2305	.439	.2743	.1097	.0549
4	8.3402	8.2853	8.2305	.4938	.2743	.1097	.0549
5	8.5048	8.3951	8.3402	.439	.2743	.1097	.0549
6	8.6694	8.7792	8.3402	.4938	.1646	.1097	.1097
7	8.5597	.9328	8.4499	.2195	.1646	.1097	.0549
8	8.7243	.6584	8.7792	.1646	.1097		.0549
9	7.7915	6.0357	8.9438	.1097	.1097	.0514	.0549
10	8.7792	8.5048	7.9561	.1097	.3292	.1097	.0549
11	8.7792	8.2305	9.0535	.1646	.1029	.0549	.0532
12	8.834	9.3279	9.0535	.1646	.0549	.0549	.0514
13	9.1084	9.2181	8.7792	.1646	.0514	.0549	.0549
14	8.2853	9.0535	8.9438	.1097		.0549	.5487
15	8.834	9.1084	9.0535	.0549	.0514	.0549	.5487
16	8.8889	6.4746	8.9438	.1097	.0514	.0549	.5487
17	8.834	7.8464	8.2305	.1646	.1646	.0549	.7682
18	6.8587	9.0535	8.7792	.2195	.1029	.1097	8.7792
19	8.5048	7.6818	8.9438	.2195	.1097	.1097	8.7792
20	8.3402	7.4074	8.9438	.2195	.1543	.1646	9.0535
21	8.5597	8.6146	7.9561	.2195	.1543	.1097	
22	8.2305	8.3402	8.2305	.2743	.1646	.1097	8.6146
23	8.2305	8.6146	5.2126	.2743	.1646	.0549	8.5048
24	8.011	8.5048	8.5048	7.572	.2743	.1097	.0549
Max	9.1084	9.3279	9.0535	7.572	.3292	.1646	9.0535
Min	6.8587	.6584	5.2126	.0549	.0514	.0514	.0514
Avg	8.4134	7.6772	8.4477	.5556	.1674	.0896	2.0419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064020 / 33 KV MUJABI S/STN****Feeder No / Name : 201 / 11 KV SHAHAPUR AGP****Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2915	.3077	.2743	.6001		.4458
2	.2801	.2915	.3077	.2743	.6001		.4458
3	.2801	.2915	.3077	.2743	.6001		.4287
4	.2801	.2915	.3077	.2743	.6001		.4287
5	.2801	.2915	.3077	.2743	.6173		.4287
6	.2987	.2915	.3077	.2915	.6001		.4458
7	.3174	.2915	.362	.3086			
8	.4458		.583	.6173			
9	.7373	.7373		.7373		.583	
10	.7373	.7888	.7716	.7545		.6687	
11	.8059	.8059	.8573	.7545		.703	
12	.8402	.8573	.823	.8402		.7202	
13	.8573	.8402	.8402	.8402	.2915	.7716	.3077
14	.8059	.8059	.823	.8573	.3258	.8059	.3982
15	.7888	.823	.823	.8573	.3601	.8059	.4887
16		.8059			.3772	.7716	.4525
17					.4115	.3258	.3982
18					.3429	.2743	.3077
19					.3086	.2572	.3048
20					.3258	.2401	.2715
21					.3086	.2229	.2715
22	.3086	.3077	.2743	.3077	.2915	.2229	.2715
23	.2915	.3077	.2572	.3077		.4458	.5144
24	.4458	.2915	.3077	.2743	.3077		.4458
Max	.8573	.8573	.8573	.8573	.6173	.8059	.5144
Min	.2801	.2915	.2572	.2743	.2915	.2229	.2715
Avg	.5045	.5229	.5040	.5067	.4276	.5213	.392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064020 / 33 KV MUJABI S/STN****Feeder No / Name : 202 / 11 KV MUJABI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.1431	1.086	1.2193	1.0288	.9526	.9526
2	1.0669	1.1431	1.086	1.2193	1.0288	.9526	.9526
3	1.0669	1.1431	1.086	1.2193	1.0288	.9526	.9526
4	1.0669	1.1431	1.086	1.2193	1.0479	.9526	.9717
5	1.0669	1.1431	1.1241	1.2193	1.0479	.9526	1.0669
6	1.2193	1.105	1.2193	1.2384	1.0669	1.0669	1.1241
7	1.2193	1.2193	1.2003	1.2765	1.1241	1.1241	1.2003
8	1.1812		1.105	1.1622	1.0479	1.0479	1.086
9	1.1431	1.086	1.2384	1.105	.9907	1.086	1.0479
10	1.1812	1.1622	1.1812	1.105	1.0479	1.086	1.1812
11	1.2765	1.2384	1.3717	1.086	1.086	1.105	1.105
12	1.2003	.9145	1.1622	1.0479	1.086	1.1431	
13	1.105	1.0098		.9907	1.086	1.0098	1.0098
14	1.1241	1.0098	1.0288	1.0479	1.0288	1.0288	.9526
15	1.1241	1.105	.9907	1.086	1.0098	1.0479	.9717
16	.7621	1.0479	1.086	1.0288	.9907	1.0479	1.0288
17	.8573	1.1622	.8383	1.1241	.9335	1.1241	1.0669
18	1.467	1.448	1.4861	1.4289	1.3527	1.3908	1.3908
19	1.4289	1.4861	1.467	1.4289	1.3527	1.4098	1.3908
20	1.448	1.4289	1.4289	1.4289	1.2955	1.3717	1.3717
21	1.3146	1.2955	1.3146	1.3336	1.2574	1.1431	1.2384
22	1.1812	1.1812	1.2003	1.1622	1.2574	1.0479	1.1431
23	1.1812	1.0669	1.2193	1.105	.9335	.9907	1.0098
24	1.0669	1.1431	1.086	1.2193	1.0288	.9526	.9526
Max	1.467	1.4861	1.4861	1.4289	1.3527	1.4098	1.3908
Min	.7621	.9145	.8383	.9907	.9335	.9526	.9526
Avg	1.1590	1.1663	1.1779	1.1876	1.0899	1.0828	1.0943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064020 / 33 KV MUJABI S/STN****Feeder No / Name : 203 / 11KV SATONA GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.3048	.2286	.3048	.2096		.2096
2	.2286	.3048	.2286	.3048	.2096	.2286	.2096
3	.2286	.3048	.2286	.3048	.2096	.2286	.1905
4	.2286	.3048	.2286	.3048	.2096	.2286	.1905
5	.2667	.3048	.2667	.3239	.2477	.2667	.2286
6	.3048	.3239	.4763	.3048	.2858	.3048	.2667
7	.2858	.2858	.2858	.3048	.2667	.2477	.2858
8	.2858		.2286	.2286	.2286	.3048	.2858
9	.2096	.4572	.2286	.3048	.362	.2667	.3429
10	.3429	.3239		.3429	.381	.4191	.5144
11	.2477	.381	.381	.362	.4954	.381	.5144
12	.2286	.1905	.3239	.4001	.381	.3239	.3429
13	.2858	.4191	.362	.5906	.362	.2858	.362
14	.362	.3239	.3048	.5906	.3429	.2858	.2286
15	.2858	.3239	.381	.5525	.3239	.3239	.2858
16	.3048	.381	.3239	.5716	.381	.2858	.3429
17	.2477	.4382	.4191	.1905	.4001	.2858	.4001
18	.4572	.6097	.6097	.4954	.5716	.4763	.6097
19	.4191	.4954	.5906	.5144	.4763	.4763	.6287
20	.4191	.4001	.4191	.4382	.4191	.4572	.4572
21	.3429	.3429	.3239	.3429	.3239	.3429	.381
22	.2667	.2858	.2858	.2858	.2858	.2477	.2858
23		.2667	.3048	.2477	.1905	.2477	.2096
24	.2286	.3048	.2286	.3048	.2096	.2286	.1677
Max	.4572	.6097	.6097	.5906	.5716	.4763	.6287
Min	.2096	.1905	.2286	.1905	.1905	.2286	.1677
Avg	.2916	.3512	.3330	.3715	.3239	.3106	.3309

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064029 / 33KV KARDHA****Feeder No / Name : 201 / 11kv korambhi (GAOTHAON)****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.7392	.7602	.7316	.6653	.6584	.6653
2	.7316	.7392	.7602	.695	.6653	.695	.6653
3	.7682	.7762	.7602	.7023	.6653	.7023	.6653
4	.7762	.8215	.7602	.7682	.6283	.7762	.6653
5	.8131	.8962	.7964	.8589	.7842	.8871	.7023
6	.961	.9709	.924	.9709	.8589	.9335	1.0349
7	.924	.961	.961	.9709	.905	1.0136	1.0498
8	.9511	.9709	.9313	.961	.905	1.134	1.0242
9	.9709	1.1203	.961	.9979	.961	1.0498	1.0719
10	.8779	.9431	.924	.8871	1.0456	1.0608	1.0136
11	.8688	.8871	.8238	.9054	.9511	.905	1.0631
12	.7545	.9145	.7522	.8501	.8131	.7316	.5121
13	.7023	.8048	.7164	.7964	.6516	.7522	.695
14	.6653	.7023	.6805	.6447	.6516	.6241	.7087
15	.6584	.7468	.7023	.6653	.6447	.7164	.6379
16	.6878	.7796	.7545	.6805	.7796	.7202	.7975
17	.8413	.9465	.9259	.7975	.9568	.9259	.8413
18	1.4415	1.419	1.5893	1.4415	1.5524	1.5364	1.5154
19	1.5684	1.5524	1.5684	1.531	1.5684	1.4784	1.531
20	1.419	1.3443	1.4784	1.419	1.4563	1.3306	1.4563
21	1.1576	1.1827	1.1576	1.0829		1.1458	1.2071
22	.9335	.9145	.924	.8501	.9145	.8413	.905
23	.7842	.7762	.7682	.7023	.695	.7392	.7164
24	.724	.7762	.7682	.7316	.6653	.6584	.6653
Max	1.5684	1.5524	1.5893	1.531	1.5684	1.5364	1.531
Min	.6584	.7023	.6805	.6447	.6283	.6241	.5121
Avg	.9044	.9452	.9228	.9018	.8863	.9173	.9088

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064029 / 33KV KARDHA****Feeder No / Name : 203 / 11 KV Salebardi (AGP)****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6081	.6455
2					.3521		.6748
3					.3521	.6539	.6748
4					.3567	.6539	.7042
5					.3612	.6836	.7335
6					.3521	.6836	.7827
8	.8749	.583	.9602	.5716			
9	.9922	.9069	1.1012	.9145			
10	1.0688	.663	1.1336	.9393			
11	1.2289	1.1271	1.1469	1.004			
12	1.1797	1.2266	1.2125	.9717			
13	1.1797	1.2266	1.278	1.0364			
14	1.1797	1.1271	1.2125	1.1336			
15	1.1469	1.1271	1.1469	1.2146			
23					.4287	.7042	.6573
24	.4321					.5792	.6748
Max	1.2289	1.2266	1.278	1.2146	.4287	.7042	.7827
Min	.4321	.583	.9602	.5716	.3521	.5792	.6455
Avg	1.0314	.9984	1.1490	.9732	.3672	.6524	.6935

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064029 / 33KV KARDHA****Feeder No / Name : 204 / 11 KV MIDC Feeder****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.0701	.4024	.4108	.4435	.4904	.5335
2	.4904	.0671	.4024	.4066	.4527	.4904	.724
3	.4527	.0716	.4024	.4066	.4904	.4954	.5716
4	.3982	.0732	.4066	.4066	.4954	.5335	.5716
5	.3582	.0747	.4108	.4066	.4954	.5335	.5716
6	.2423	.0747	.4481	.4854	.4572	.5658	.6097
7	.1311	.1174	.4481	.4481	.4954	.5716	.6478
8	.1219	.1204	.5175	.5175	.5335	.4904	.7095
9	.1372	.2303	.6413	.6036	.7167	.5658	.7468
10	.2187	.5914	.6859	.6478	.6859	.6097	.7922
11		.6283	.8002	.6859	.6478	.6859	.8589
12	.2926	.679	.7545	.8299	.7621	.6413	.8215
13	.2507	.5658	.679	.6859	.7167	.724	.7167
14	.2401	.679	.679	.7621	.7167	.724	.7842
15	.2926	.6478	.6859	.7922	.7167	.7545	.7922
16	.2957	.6413	.6859	.7922	.7167	.724	.7167
17	.3326	.679	.6413	.6859	.679	.7167	.7545
18	.1623	.5228	.5281		.679	.7545	.679
19	.0488	.4805	.4435	.5335	.7167	.7167	.6036
20	.0412	.4252	.4066	.4854	.5658	.6036	.5658
21	.0419	.4024	.4066	.5281	.5716	.5716	.4527
22	.0671	.3696	.4066	.5335	.4904	.4954	.4904
23	.0686	.4024	.4066		.4954	.4954	.4527
24	.4854	.0701	.4024	.4108	.4527	.4904	.5335
Max	.4904	.679	.8002	.8299	.7621	.7545	.8589
Min	.0412	.0671	.4024	.4066	.4435	.4904	.4527
Avg	.2459	.3618	.5288	.5666	.5914	.6019	.6542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 202 / 11 KV Rajola Feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.5242	1.491	1.4022
2					1.5394	1.4746	1.4022
3					1.5394	1.4582	1.6289
4					1.5394	1.4419	1.448
5					1.5546	1.4582	1.5851
6					1.5546	1.491	1.6613
8		1.6194	1.6876	.0152			
9	.9907	1.8187	1.9334	.0152			
10	1.439	1.9498	1.9662	.0152			
11	2.1464	2.0809	2.0645	1.448			
12	1.8351	1.917	1.9662	1.9662			
13	2.0481	1.9989	1.917	1.7833			
14	1.917	2.13	1.9662	1.9052			
15	1.9006	2.13	2.0317	1.8442			
23				.0953	1.5083	1.387	1.326
24			.1524		1.5242	1.491	1.387
Max	2.1464	2.13	2.0645	1.9662	1.5546	1.491	1.6613
Min	.9907	1.6194	.1524	.0152	1.5083	1.387	1.326
Avg	1.7538	1.9556	1.7428	1.0098	1.5355	1.4616	1.4801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 203 / 11 KV Shahapur Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5228	.5544	.5144	.5316	.4481	.5144
2	.4854	.5041	.5228	.4973	.5316	.4481	.5316
3	.4854	.5041	.5228	.4973	.5316	.4668	.5658
4	.5041	.5228	.5601	.4801	.5487	.4668	.6001
5	.5228	.5415	.5601	.4268	.5487	.5788	.6687
6	.6722		.7095	.583	.5658	.7095	.703
7	.7842	.8962	.7842	.7716	.6344	.8962	.823
8	.6722	.6838	.7468	.7373	.7202	.7842	.7545
9	.6584	.6908	.6859	.7545	.8215	.703	.7202
10	.695	.6722	.6859	.7716	.7842	.6344	.703
11	.7133	.7468	.6173	.6859	.8029	.7545	.6859
12	.7577	.6161	.5487	.6687	.7468	.6516	.6687
13	.6838	.5788	.4973	.583	.6722	.5658	.6344
14	.5544	.6348	.4458	.5487	.6161		.5316
15	.499	.6722	.3772	.5487	.6161	.463	.5144
16	.6036	.5228	.0171		.5788	.4973	.5316
17	.7392	.8029	.1029	.583	.6722	.583	.6173
18	1.0164	.9709	1.0288	.8745	1.0082	.8916	.9945
19	1.0719	.9522	.9602	.9259	.9896	.9774	1.0631
20	.9979	.9522	.8573	.8745	.9149	.8916	1.0288
21	.9055	.8775	.8059	.823	.8775	.8402	.8745
22	.7762	.8402	.7202	.6687	.6535	.6859	.7373
23	.6099	.6722	.6173	.6001	.5228	.5658	.5658
24	.4854	.5788	.5729	.5144	.5316	.4854	.5144
Max	1.0719	.9709	1.0288	.9259	1.0082	.9774	1.0631
Min	.4854	.5041	.0171	.4268	.5228	.4481	.5144
Avg	.6825	.6938	.6042	.6493	.6842	.6517	.6894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 205 / 11 KV Explosive - I Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8299	.8215	.9709	.5944	.7316
2	.9054	.8383	.9709	.5792	.7468
3	.9242	.8383	.9997	.5487	.7316
4	.9242		1.0185	.6097	.7164
5	.9335	.8718	.9808	.7926	.7011
6	.8402		.7356	.7164	.7011
7	.7655	.6874	.7468	.6097	
8	.6535	.8215	.9149	.7164	
9	.6001	.6722	.7373	.5944	
10		.4668	.6062	.503	
11	.298	.2801	.2785	.5335	
12	.4908	.6908	.3932	.5944	
13	.631	.6908	.6062	.5639	
14	.5493	.7468	.5735	.5335	
15		.7655	.5407	.4268	
16	.631	.7095	.6062	.5792	
17	.8145	.5788	.6554	.7164	
18	.7421	.7922	.6882	.6249	
19	.7602	.7922	.7209	.6706	
20	.7783	.7922	.6882	.6401	
21	.6097	.7655	.6882	.6249	
22	.6249	.7468	.6554	.6249	
23	.5992	.7133	.639	.6097	
24	.7922	.5992	.9522	.5792	.7316
Max	.9335	.8718	1.0185	.7926	.7468
Min	.298	.2801	.2785	.4268	.7011
Avg	.7135	.7128	.7236	.6078	.7229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 206 / 11 KV Bhandara Feeder
Feeder KV- 11 / OUTGOING****SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					1.0822	1.0322	.8688
2					1.0974	1.0159	.8688
3					1.2346	1.0442	.884
4					1.2346	1.0442	.8993
5					1.2517	1.0562	.9145
6					1.2517	1.073	.9297
8	1.2597	1.5565	1.4255	1.4175			
9	1.4373		1.4175	1.4632			
10	1.5729		1.5604	1.5394			
11	1.6385		1.6975	1.5394			
12	1.7204		1.7147	1.5394			
13			1.5394	1.5089			
14	1.6385		1.5546	1.5089			
15	1.6549		1.5546	1.4327			
23					1.0322	.8383	.7621
24					1.2174	1.0322	.8535
Max	1.7204	1.5565	1.7147	1.5394	1.2517	1.073	.9297
Min	1.2597	1.5565	1.4175	1.4175	1.0322	.8383	.7621
Avg	1.5603	1.5565	1.5580	1.4937	1.1752	1.0170	.8726

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 208 / 11 KV Explosive - II****Feeder Feeder KV- 11 /
OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.4335	1.0185	1.1317	.5658	1.358	1.1831
2	1.1317	1.4146	1.0185	1.0974	.5658	1.3203	1.1831
3	1.0374	1.3769	1.0374	1.1317	.583	1.3203	1.166
4	1.0185	1.3203	1.0562	1.1145	.5658	1.2826	1.1831
5	.9997	1.3203	1.0751	1.1317	.5658	1.226	1.166
6	.9431	1.2449	.9808	.9774	.5658	1.1883	1.166
7	.8676	1.2826	.8865	.8573	.8916	1.1694	1.1145
8	.8488	1.094	.7733	.703	.8402	1.1694	1.1317
9	.8488	1.1506	.8059	.703	.7733	.9602	.8573
10	.7922	1.1317	.5316	.6173	.5847	.8916	.7545
11	.3772	1.1317	.4458	.6687	.415	1.0288	.0686
12	.3772	1.0751	.2743	.6859	.7545	.2915	.4115
13	.2829	.811	.1029		.8299	.4115	.463
14	.679	.2829	.2229	.6859	.8299	.4801	.5316
15	.7356	1.0374	.4458	.6173	.8865	.6516	.8916
16	.9808	.8865	.703	.5658	1.226	.8916	.8745
17	1.3957	1.1317	.8573	.9088	1.226	1.2174	1.406
18	1.3203	.9431	.9088	.7545	1.2449	1.166	1.2689
19	1.5089	.9619	.9431	.8059	1.2449	1.2689	1.2517
20	1.2637		1.0117	.6859	1.226	1.2003	1.2003
21	1.4146	.9808	1.0288	.6859	1.226	1.1831	1.1488
22	1.3957	.9431	1.0631	.5316	1.3203	1.2003	1.0802
23	1.4146	.8865	1.0974	.5144	1.3769	1.2003	1.3717
24		1.3769	.9997	1.1145	.5658	1.3769	1.2003
Max	1.5089	1.4335	1.0974	1.1317	1.3769	1.3769	1.406
Min	.2829	.2829	.1029	.5144	.415	.2915	.0686
Avg	.9926	1.0964	.8037	.8126	.8698	1.0606	1.0031

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 209 / 11 KV Awarmara Gaothan****SEPARATED GAOTHAN FEEDERS****Feeder Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2614	.2801	.2915	.2401	.2218	.2058
2	.1867	.2614	.2241	.2743		.1848	.2058
3	.1867	.2614	.2241	.2915	.2401	.2054	.2058
4	.2241	.2987	.2801	.3086	.2743	.2801	.2401
5	.3361	.3734	.3361	.3258	.3086	.3734	.2915
6	.4108	.3921	.3921	.3601	.3429	.3734	.4115
7	.4108	.3921	.4108	.3772	.3601	.3734	.3944
8	.4294	.3921	.4108	.3772	.4287	.4481	.4287
9	.3696	.3921	.3429	.0171	.4108	.3429	.3086
10	.2587	.1867	.2401	.0171	.2987	.2401	.2058
11	.2033	.2054	.1886	.1029	.2614	.1886	.1372
12	.1478	.1478	.1886	.1886	.1886	.1886	.1715
13	.1848	.1494	.1715	.1543	.1886	.1715	.1715
14	.1478	.168	.1715	.1886	.1867		.1715
15	.1109	.1848	.1715	.1715	.2054	.1886	.12
16	.1478	.1867	.1715	.1886	.2427	.1715	.1886
17	.2033	.2987	.2572	.2058	.2587	.2401	.1715
18	.4435	.4108	.4287	.463	.4805	.463	.4287
19	.4805	.3921	.4115	.4458	.4854	.4287	.3944
20	.4435	.4481	.3944	.3944	.4481	.3944	.3601
21	.3696	.3734	.3429	.3429	.3696	.3429	.3258
22	.2957	.3547	.3258	.2743	.3142	.2743	.2401
23	.2587	.2801	.461	.2572	.2402	.2401	.2229
24	.2241	.2801	.2801	.2915	.2401	.2218	.2229
Max	.4805	.4481	.461	.463	.4854	.463	.4287
Min	.1109	.1478	.1715	.0171	.1867	.1715	.12
Avg	.2775	.2955	.2961	.2629	.3050	.2851	.2594

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 064032 / 33 KV Sahuli Sub-Station****Feeder No / Name : 401 / 33 KV SAINATH****Feeder KV- 33 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0784	.0504	.0566	.0514	.0224	.0514
2	.056	.0728		.0566	.0463	.0224	.0514
3	.0616	.0728	.0448	.0514	.463	.0224	.0514
4	.056	.0672	.0392	.0463	.0412	.0168	.0463
5	.0616	.0616	.0392	.0412	.0412	.0168	.0463
6	.0672	.0728	.0392	.036	.036	.0112	.0463
7	.0728	.0672	.0336	.0309	.036	.0112	.0463
8	.0672	.0672	.061	.0257	.0463	.0168	.0566
9	.0832	.0665	.0566	.0103	.0499	.0309	.0566
10	.0832	.061	.0617	.0103	.0444	.0463	.0514
11	.0776	.0665	.0617	.0206	.0554	.0772	.0514
12	.0665	.056		.0463	.0504	.072	.0669
13	.0776	.061		.036	.0448	.0669	.0617
14	.0776	.056		.036	.0448	.0566	.0566
15	.0776	.056		.0412	.0448	.036	.0566
16	.0665	.056		.0412	.056	.0257	.0617
17	.0554	.056	.0514	.0463	.0504	.0669	.0669
18	.061	.056	.0514	.0463	.0554	.0463	.072
19	.0721	.056	.0514	.0463	.0444	.0514	.0669
20	.0776	.0448	.0463	.0463	.0336	.0617	.0669
21	.0728	.0504	.0514	.0463	.0336	.0617	.072
22	.0672	.0504	.0566	.0463	.0333	.0617	.0669
23	.0784	.0499	.0566	.0463	.0222	.0617	.0617
24	.056	.0896	.0504	.0617	.0514	.0222	.0514
Max	.0832	.0896	.0617	.0617	.463	.0772	.072
Min	.0554	.0448	.0336	.0103	.0222	.0112	.0463
Avg	.0687	.0622	.0502	.0405	.0615	.0411	.0577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION**

Feeder No / Name : 402 / 33 KV Gadegaon Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.6063	7.1296	2.5926	7.6738	5.9414	7.1696	7.2817
16	2.2634	.1652	1.6221	7.3525	6.7901	7.4291	8.2305
24	5.0823	3.1784	2.9412	.4001	5.9934	5.6584	5.998
Max	5.0823	7.1296	2.9412	7.6738	6.7901	7.4291	8.2305
Min	2.2634	.1652	1.6221	.4001	5.9414	5.6584	5.998
Avg	3.3173	3.4911	2.3853	5.1421	6.2416	6.7524	7.1701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION**

Feeder No / Name : 403 / 33 KV Pahela Feeder NON SHEDDABLE EXPRESS HV FEEDERS
INCOMER Feeder KV- 33 / (CONTINOUS PROCESS)(NO STAGGERING)
INCOMING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.6118	1.8073	1.8404	1.5249	1.1403	.8402	.9425
16	.9328	1.3014	.9882	1.2489	1.182	.9328	.9774
24	.9877	.6722	.7362	.6224	.6224	1.0402	.679
Max	1.6118	1.8073	1.8404	1.5249	1.182	1.0402	.9774
Min	.9328	.6722	.7362	.6224	.6224	.8402	.679
Avg	1.1774	1.2603	1.1883	1.1321	.9816	.9377	.8663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION****Feeder No / Name : 404 / 33 KV KarachKheda Feeder PURELY LIS FEEDERS****Feeder KV- 33 / OUTGOING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343				
8	.0286	.0343	.0343	.04	.0457	.04
16	.0248	.0251	.0265	.0256	.027	.027
Max	.0286	.0343	.0343	.04	.0457	.04
Min	.0248	.0251	.0265	.0256	.027	.027
Avg	.0267	.0312	.0304	.0328	.0364	.0335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION****Feeder No / Name : 405 / 33KV SAHULI KARDHA INCOMER****Feeder KV- 33 / INCOMING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.7692	3.1493	2.8235	2.6063	.6401	1.3032	1.7741
16	1.7147	1.358	.8002	1.3014	1.7193	1.3969	1.9605
24	1.8673	2.3434	1.5278	1.7541	1.2449	2.4577	2.009
Max	2.7692	3.1493	2.8235	2.6063	1.7193	2.4577	2.009
Min	1.7147	1.358	.8002	1.3014	.6401	1.3032	1.7741
Avg	2.1171	2.2836	1.7172	1.8873	1.2014	1.7193	1.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067009 / 132 KV KARDHA SUBSTATION****Feeder No / Name : 406 / 33 KV TAKALI****Feeder KV- 33 / INCOMING**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0004	1.5278	1.5684	1.5123	1.5123	1.5524
16	1.3003	1.3575		1.3306	1.2894	1.2757
18					1.2894	
24		1.4415	1.386	1.3443	1.2197	1.4003
Max	1.3003	1.5278	1.5684	1.5123	1.5123	1.5524
Min	.0004	1.3575	1.386	1.3306	1.2197	1.2757
Avg	.6504	1.4423	1.4772	1.3957	1.3277	1.4095

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384] BU 0384****Substation No/ Name :- 067013 / 132 KV TEKEPAR****Feeder No / Name : 703 / 132 KV TEKEPAAR****PURELY LIS FEEDERS****Feeder KV- 132 / OUTGOING**

DATE	01-DEC-17
HR	Load (MW)
24	.4344
Max	.4344
Min	.4344
Avg	.4344

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 202 / 11 KV Sunflag Feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5121	.6009	.4877
2					.5601	.5851	.4843
3					.5601	.5921	.4843
4					.5601	.5761	.4843
5					.5601	.5761	.4999
6					.5851	.5761	.4877
8	.602	.7375	.6773	.5944	.1265		
9	.7225	.8278	.7375	.6706			
10	.7827	.8278	.7316	.7164			
11	.7827	.7926	.7621	.7842			
12	.6923	.8383	.7926	.8162			
13	.7676	.7926	.7526	.8322			
14	.7827	.8078	.7526	.7842			
15	.7676	.8025	.7375	.7842			
23					.5376	.4877	.4475
24	.4725					.5693	.4877
Max	.7827	.8383	.7926	.8322	.5851	.6009	.4999
Min	.4725	.7375	.6773	.5944	.1265	.4877	.4475
Avg	.7081	.8034	.7430	.7478	.5002	.5704	.4829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 203 / 11 KV DABHA****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.1791	.2172	.2241	.2353	.2378	.1646
2	.2926	.2149	.1991	.2172	.2353	.2378	.1463
3	.3109	.2263	.197	.1991	.2353	.2172	.1463
4	.3224	.2241	.1791	.197	.2686	.2353	.1494
5	.3045	.2507	.2743	.2686	.2686	.2534	.2054
6	.3224	.3142	.2926	.2865	.2896	.2715	.2614
7	.3403	.2865	.3109	.3045	.3045	.2865	.2987
8	.4904	.2865	.2865	.2865	.3258	.2865	.3109
9	.3224	.2865	.2865	.3045	.3077	.2686	.2378
10	.2686	.2641	.2328	.2858	.2865	.2149	.2561
11	.2477	.2263	.2149	.2715	.2507	.2378	.2378
12	.197	.2241	.2149	.2454	.2149	.2195	.2353
13	.197	.2054	.2279	.2353	.2149	.2195	.1991
14	.2096	.2012	.2103	.1991	.2149	.1991	.1646
15	.2096	.2012	.2454	.2477	.2149	.2172	.128
16	.2286	.1646	.197	.2286	.2328	.197	.1524
17	.2286	.2012	.2328	.2477	.197	.197	.2667
18	.4001	.3292	.3582	.3982	.3582	.3761	.381
19	.3582	.4572	.3582	.3258	.3403	.3761	.381
20	.3582	.3841	.3224	.3429	.3045	.3403	.3439
21	.3224	.3841	.2686	.362	.2926	.3012	.2896
22	.2667	.2926	.2427	.2667	.2012	.2481	.2353
23	.2328	.2534	.1867	.2328	.1829	.1949	.1905
24	.2743	.1791	.2172	.2054	.2353	.1829	.1612
Max	.4904	.4572	.3582	.3982	.3582	.3761	.381
Min	.197	.1646	.1791	.197	.1829	.1829	.128
Avg	.2916	.2599	.2489	.2660	.2588	.2507	.2310

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 205 / Sahakar Nagar Feeder
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.2561	.2772	.3142	.2801	.2402	.3142
2	.2957	.2561	.2587	.2957	.2801	.2402	.2957
3	.2772	.2561	.2561	.2743	.2801	.2218	.2218
4	.2772	.2561	.2743	.2743	.2772	.2402	.1848
5	.2587	.2561	.2926	.2561	.2772	.2218	.1663
6	.2801	.2587	.2926		.2801	.2033	.168
7	.2801		.2772	.2926	.2801	.2987	.168
8		.3142	.2957	.2033	.3174	.2987	.2987
9	.0924	.3511	.3326	.2743	.4108	.3734	.3142
10	.3696	.4251		.4207	.5415	.4108	.5415
11	.462	.5788	.0924	.4668		.4108	.5975
12	.499	.5228	.4435	.4294	.5601	.3696	.5544
13	.4805	.5041	.499	.4481	.5544	.3881	.5914
14	.5544	.547	.567	.3921	.6283	.4066	.5914
15	.5359	.5658	.5487	.3921	.5544	.3841	.6099
16	.4805	.5914	.5121	.5788	.5544	.4207	.6099
17	.499	.5175	.3475	.4854	.499	.3881	.5544
18	.499	.4572	.3881	.5415	.5175	.4066	.5175
19	.4805	.4572	.462	.4668	.3881	.4066	.5175
20	.4938	.4435	.3881	.4668	.3547	.3326	.5359
21	.4755	.4066	.5175	.4481		.2957	.4435
22	.3292	.2772	.3142	.4294	.2987	.2743	.2957
23	.2926	.2772	.3142	.2614	.2987	.2743	.1848
24	.3142	.2743	.2772	.3326	.2801	.2772	.3142
Max	.5544	.5914	.567	.5788	.6283	.4207	.6099
Min	.0924	.2561	.0924	.2033	.2772	.2033	.1663
Avg	.3844	.3935	.3578	.3802	.3960	.3244	.3996

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 206 / 11 KV MMKD Feeder****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5281	.6036	.3206	.2858	.3961	.4108
2	.6036	.5281	.5906	.3018	.2858	.4001	.3921
3	.5847	.547	.5716	.3018	.2858	.381	.3961
4	.5658	.547	.5658	.3206	.2858	.3395	.3772
5	.547	.5525	.547	.3206	.3048	.3429	.4001
6	.5281	.5658	.5228	.3018	.3048	.3206	.4191
7	.547	.5281	.5093	.2829	.3048	.3772	.3961
8	.4904	.547		.3018	.2858	.3206	.3772
9	.6413	.5281	.4338	.3018	.2829	.3772	.3395
10	.6036	.3772	.4904	.3048	.2829	.3584	.415
11	.6097	.3772	.5281	.3239	.3018	.2987	.4191
12	.6979	.5041	.4527	.2858	.2829	.3174	.3429
13	.679	.5975	.4527	.2858	.3018	.3174	.3429
14	.6668	.6224	.4527	.2858	.3018	.3206	.362
15	.5906	.6036	.4338	.2858	1.1694	.3772	.4001
16	.5335	.5847	.4338	.2858	.3584	.3584	.5144
17	.5906	.4481	.4527	.3048	.3584	.3921	.6287
18	.5847	.6161	.3772	.3048	.3772	.4294	.5144
19	.6036	.6348	.3772	.3429	.3395	.3734	.4191
20	.6224	.6036	.3206	.3048	.3395	.3734	.5144
21	.547	.6224	.3018	.3048	.3429	.4024	.5525
22	.5716	.6224	.3206	.3048	.3584	.3475	.6097
23	.5658	.5847	.3018		.415	.4024	.7621
24	.6224	.5281	.6036	.3206	.2858	.415	.4024
Max	.6979	.6348	.6036	.3429	1.1694	.4294	.7621
Min	.4904	.3772	.3018	.2829	.2829	.2987	.3395
Avg	.5917	.5499	.4628	.3043	.3518	.3641	.4462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 401 / 33KV BHANDARA****Feeder KV- 33 / INCOMING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7161	2.4897	1.1883	1.5278	1.1317	1.358	1.1317
2	2.7161	2.5463	1.1317	1.5278	1.1317	1.358	1.0751
3	2.8858	2.5463	1.0082	1.4712	1.1883	1.3014	1.0751
4	2.8292	2.6863	1.0082	1.4712	1.1883	1.3014	1.0185
5	2.7726	2.9424	1.2003	1.4146	1.1883	1.3014	1.1431
6	2.8292	3.1121	1.358	1.4712	1.2197	1.3014	1.3146
7	3.2819	3.2819	1.5844	1.8107	1.6975	1.9805	1.9239
8	3.3385	3.3385	1.9805	1.9239	1.9239	1.9805	2.0936
9	3.2253	3.4517	2.0936	2.037	1.9805	1.9239	1.9239
10	3.0556	3.6214	2.0936	1.8673	2.2068	1.8673	1.8107
11	2.8292	3.2487	1.8673	1.6975	1.9805	1.9239	1.8673
12	2.6292	3.1121	1.8673	1.3014	1.8107	1.6975	1.829
13	2.3765	2.6029	1.7541	1.358	1.5844	1.5278	1.5278
14	2.2634	2.8292	1.4146	1.1763		1.4563	1.5278
15	2.2068	1.2449	1.358	1.0425	1.3014	1.4003	1.4712
16	1.9605	1.2449	1.4146	1.3014	1.1883	1.358	1.4146
17	1.1763	1.358	1.4146	1.6409	1.4146	1.5278	1.6975
18	3.8295	1.9605	1.9805	2.2634	2.2068	1.9239	1.9805
19	3.7912	1.9044	1.9805	1.8673	1.8107	1.8673	1.8673
20	3.678	1.6975	1.7541	1.8107	1.6975	1.8107	1.7541
21	3.5082	1.6975	1.6975	1.7541	1.6409	1.7541	1.6409
22	3.1687	1.5844	1.6975	1.5278	1.5844	1.5278	1.4146
23	2.7161	1.358	1.5278	1.358	1.2449	1.2449	1.1883
24	2.5463	2.4897	1.1883	1.4712	1.1317	1.358	1.1317
Max	3.8295	3.6214	2.0936	2.2634	2.2068	1.9805	2.0936
Min	1.1763	1.2449	1.0082	1.0425	1.1317	1.2449	1.0185
Avg	2.8471	2.4312	1.5651	1.5872	1.5415	1.5855	1.5343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 402 / 33KV Mohadi****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8673	1.8673	1.7541	4.8097	3.1121	3.2253	2.6029
2	2.037	2.0005	1.7541	1.8673	3.1121	3.2819	2.5463
3	2.037	2.0005	1.6975	1.9239	3.1121	3.2819	2.8006
4	2.0936	1.9805	1.5684	1.8673	3.1121	3.3385	3.2819
5	2.0936	2.037	1.6804	1.9239	3.2253	3.2819	3.3951
6	2.1502	2.0936	1.829	2.037	3.095	3.3385	
7	2.1502	2.037	2.1502	2.0936	1.9805	2.0936	2.037
8	4.0741	4.6399	3.9609	4.1872	2.2405	2.4897	2.037
9	4.7531		4.1307	4.3004	2.2068	2.2634	1.9239
10	4.4696	4.7531	4.3004	4.5268	1.9805	1.9805	2.0936
11	4.5748	4.7611	4.4136	3.9769	1.8673	1.8673	2.0936
12	5.0497	4.0329	4.2438	4.425	2.0936	1.9044	2.2068
13	5.0497	4.201	4.3004	4.3004	1.9239	1.9044	2.037
14	3.155	4.481	4.2438	4.0741	1.8673	1.7364	1.9805
15	3.9963	3.7912	3.9609	3.9043	1.8107	1.5684	1.6975
16	1.701	1.8107	1.5278	1.8673	1.8107	1.7924	1.8107
17	1.8073	1.7541	1.6975	2.037	1.9805	1.7924	2.2068
18	2.7726	2.8292	2.7161	3.0556	2.8292	2.8858	3.5082
19	2.8292	2.8858	2.5463	2.7726	2.9424	2.4331	2.8292
20	2.7435	2.7446	2.5463	2.5463	2.6029	2.7726	2.6595
21	2.2634	2.3765	2.0936	2.037	1.8107	1.9805	2.2634
22	1.9239	1.8673	1.7541	1.5844	1.6975	1.5844	1.9805
23	1.8673	1.8107	1.5278	1.2449	2.7726	2.3765	2.037
24	1.6975	1.8673	3.4739	1.4712	2.6595	2.9424	2.6029
Max	5.0497	4.7611	4.4136	4.8097	3.2253	3.3385	3.5082
Min	1.6975	1.7541	1.5278	1.2449	1.6975	1.5684	1.6975
Avg	2.8815	2.8097	2.7447	2.8681	2.4102	2.4215	2.3753

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 403 / 33 KV MUJABI****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6409	1.358	1.358	1.5278	1.3014	1.1883	1.4712
2	1.5844	1.358	1.3014	1.5278	1.3014	1.1883	1.4146
3	1.5844	1.4712	1.2574	1.5278	1.3014	1.1317	1.4146
4	1.6409	1.4712	1.2574	1.5844	1.3014	1.1883	1.4861
5	1.5844	1.5278	1.4146	1.5278	1.3014	1.1883	1.5844
6	1.5844	1.5684	1.5844	1.5844	1.1643	1.2449	1.6975
7	1.5278	1.5278	1.5844	1.5278	1.2752	1.358	1.4289
8	1.8673	.0566	1.7541	1.8107	1.1088	1.3014	1.2323
9	2.037	2.2634	2.1285	1.9805	1.3014	1.2449	1.2449
10	2.1845	2.2634	2.0936	2.2634	1.4146	2.0936	1.5844
11	.5041	2.4897	2.5463	2.32	1.4712	2.0165	1.5278
12	2.2965	2.4646	2.4331	2.32	1.4146	2.1285	.3429
13	2.3765	2.2405	2.2068	2.3765	1.5278	1.9605	1.4712
14	2.2068	2.1845	2.0936	2.3285	1.5278	2.1502	1.4712
15	2.2068	2.32	2.0936	2.384	1.4712	2.0936	1.4146
16	.9522	2.2634	1.4146	1.5278	1.5278	2.1502	1.4712
17	1.0642	1.4146	1.1317	1.2449	1.5278	1.5278	1.5844
18	1.8673	1.9605	1.8673	1.8673	1.6975	1.9605	2.1502
19	1.8107	1.9605	1.9239	1.9239	1.9239	1.9605	2.037
20	1.7541	1.6804	2.5463	1.8107	1.8107	1.8673	1.8673
21	1.5844	1.5844	1.5844	1.5844	1.6975	1.5278	1.6975
22	1.4712	1.4712	1.5278	1.4712	1.4146	1.3014	1.4712
23	1.4146	1.358	1.4146	1.358	1.1317	1.4712	1.6409
24	1.6409	1.358	1.358	1.4712	1.3014	1.2449	1.4712
Max	2.3765	2.4897	2.5463	2.384	1.9239	2.1502	2.1502
Min	.5041	.0566	1.1317	1.2449	1.1088	1.1317	.3429
Avg	1.6828	1.7340	1.7448	1.7855	1.4257	1.6037	1.5074

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA S/DN.[384]****BU 0384****Substation No/ Name :- 068015 / 220 KV BHANDARA S/S****Feeder No / Name : 802 / 220 KV SUNFLAG****Feeder KV- 220 / OUTGOING****NON SHEDDABLE EHV INDUSTRIAL FEEDERS****(CONTINUOUS PROCESS)(NO STAGGERING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	29.5001	32.9523		13.6755	23.7655	18.85	20.8505
2	28.5094	24.539	25.503	13.4431	27.5378	24.6457	24.9657
3	21.9479	26.8862	23.2815	13.3059	26.1393	23.0453	20.1189
4	20.7286	24.6152	29.9383	13.6755	22.2908	22.4433	24.0589
5	25.3773	27.7207	24.7638	13.6755	22.0432	21.4983	18.6557
6	24.1884	25.2401	26.5128	14.1899	30.8033	20.6981	21.5821
7	23.2815	23.0453	27.633	13.1687	25.5144	19.4178	21.3001
8	30.8033	26.7833	28.2922	12.0713	21.9479	30.4451	25.1486
9	38.9956	25.1334	26.1393	10.9397	19.2387	26.6118	23.2434
10	22.0851	33.9811		12.5743	23.3882	32.5256	23.6245
11	21.5592	26.9814	17.1773	11.4312	30.247	27.1605	31.2453
12	23.4111	25.1334	14.712	16.5981	23.3882	20.3704	22.4052
13	24.3942	27.4349	13.203	19.052	28.0064	32.0074	25.5297
14	25.8726	24.9962	17.3526	18.8615	22.2565	21.8793	25.0191
15	23.152	24.2722	15.8436	14.0985	22.9157	22.6338	30.1784
16	35.0214	24.1427	15.3635	14.7844	29.7973	20.7476	24.8972
17	25.7659	26.0288	16.2209	15.4664	22.9958	24.8972	25.5297
18	25.9107	25.6516	15.4664	15.0892	19.2387	20.7476	21.8793
19	24.8972	36.9685	13.203	14.712	20.1646	20.7476	21.1249
20	26.0288	28.7533	15.8436	17.9241	23.8988	21.2849	27.915
21	29.6297	25.2744	13.8165	19.2197	16.6553	23.9979	22.6795
22	23.655	26.5128	14.712	20.458	22.8052	19.8446	26.5051
23	24.0246	33.2648	14.1899	25.8726	25.0191	22.4052	24.0246
24	39.0566	26.0631	26.2422	14.1899	24.2722	22.1765	21.2849
Max	39.0566	36.9685	29.9383	25.8726	30.8033	32.5256	31.2453
Min	20.7286	23.0453	13.203	10.9397	16.6553	18.85	18.6557
Avg	26.5748	27.1823	19.7914	15.3532	23.9304	23.3784	23.9069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA URBAN S/DN[381] BU 1929****Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN****Feeder No / Name : 201 / 11 KV Ambedkar ward****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.5281	.5335	.5144	.5281
2	.5144	.5144	.5525	.5093	.5335	.5144	.5281
3	.5144	.5144	.5525	.5093	.5144	.5144	.5281
4	.5144	.4954	.5335	.5093	.5144	.5335	.5281
5	.5144	.4954	.5335	.5281	.5144	.5144	.5281
6	.5144	.5144	.5335	.547	.5144	.5335	.5093
7	.5144	.4954	.5144	.5281	.5144	.5144	.5093
8	.5144	.5144	.5144	.5281	.5144	.5144	.5281
9	.5144	.5281	.5335	.5335	.5525	.5335	.5335
10	.5144	.4904	.5335	.5335	.5144	.5335	.5525
11	.5144	.4904	.5144	.5335	.5144	.5144	.5144
12	.5144	.4904	.5144	.5335	.5335	.5144	.5144
13	.5144	.5093	.5335	.5144	.4954	.5335	.5144
14	.4954	.5093	.5335	.4954	.5144	.5335	.4954
15	.5144	.4904	.5144	.4954	.5144	.5144	.5144
16	.5144	.5093	.5335	.5335	.5144	.5144	.5144
17	.5144	.5144	.5093	.5144	.5144	.5093	.5335
18	.5144	.5144	.5281	.5144	.5144	.5093	.5335
19	.5335	.5144	.5281	.5335	.5144	.5093	.5144
20	.5335	.5144	.5281	.5525	.5335	.5281	.5335
21	.5335	.5335	.5281	.5335	.5335	.5281	.5144
22	.5335	.5335	.5281	.5335	.5335	.5281	.5144
23	.5335	.5335	.5281	.5335	.5144	.5093	.5144
24	.5144	.5335	.5335	.5281	.5335	.5335	.5281
Max	.5335	.5335	.5525	.5525	.5525	.5335	.5525
Min	.4954	.4904	.5093	.4954	.4954	.5093	.4954
Avg	.5176	.5111	.5280	.5251	.5208	.5208	.5220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA URBAN S/DN[381] BU 1929****Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN****Feeder No / Name : 202 / 11KV Sahakar Nagar****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.8002	.7059	.7842	.7133	.6584	.7282
2	.7133	.8002	.724	.7655	.7133	.6154	.7095
3	.695	.8002	.695	.7842	.695	.6036	.6908
4	.695	.7811	.7133	.8402	.695	.5792	.6722
5	.7316	.8192	.724	.9149	.7316	.6154	.6722
6	.9145	1.0288	.7964	.9522	.9145	.8048	1.0269
7	1.134	1.1622	.9877	1.2136	1.1157	1.3169	1.307
8	1.1888	1.1812	1.3032	1.251	1.2437	1.3575	1.363
9	1.0974	1.2136	1.4998	1.4098	1.2308	1.262	1.3336
10	.9511	1.2323	1.3352	1.3336	1.448	1.2851	1.3527
11	.9145	1.1016	1.2254	1.3336	1.4632	1.3352	1.4098
12	.8413	1.1389	1.2071	1.1241	1.086	1.1765	1.4098
13	.7316	.8215	1.0425	1.1431	1.086	1.086	1.3336
14	.7133	1.0082	1.0425	1.1431	.7964	1.0425	1.2955
15	.7316	.8589	.9328	1.1431	.8688	1.0791	1.2574
16	.7621	.8402	1.0242	1.1431	.7964	1.1157	1.1431
17	.8383	.9511	1.0082	1.0974	1.0242	1.1389	1.2254
18	1.105	1.2437	1.3256	1.4632	1.1584	1.3443	1.3535
19	1.2003	1.1888	1.1949	1.1706	1.086	1.2136	1.2308
20	1.1431	1.0242	1.1576	1.0974	1.0791	1.1576	1.1584
21	1.105	1.0242	1.0642	1.0242	1.0136	1.1016	1.0136
22	.9907	1.0242	1.0082	.9511	.9694	.9709	.905
23	.8573	.8048	.8215	.8779	.7964	.8029	.7783
24	.7316	.8383	.7682	.7842	.7316	.6878	.7282
Max	1.2003	1.2437	1.4998	1.4632	1.4632	1.3575	1.4098
Min	.695	.7811	.695	.7655	.695	.5792	.6722
Avg	.8958	.9870	1.0128	1.0727	.9774	1.0146	1.0874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA URBAN S/DN[381] BU 1929****Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN****Feeder No / Name : 204 / 11 KV Kham Talao (Takiya
Ward) Feeder KV- 11 / OUTGOING****SHEDDABLE URBAN**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2896	.2804	.3206	.2507	.2507	.2829
2	.2715	.2715	.2601	.3206	.2534	.2328	.2641
3	.2534	.2715	.2658	.3018	.2353	.2172	.2641
4	.2715	.2534	.2804	.3206	.2353	.2353	.2641
5	.2896	.2715	.2601	.3395	.2715	.2534	.2641
6	.3258	.2896	.2947	.3395	.2865	.3045	.3395
7	.362	.362	.333	.3584	.3224	.3403	.3584
8	.362	.362	.3439	.3772	.3224	.3403	.3772
9	.362	.3961	.3801	.3982	.3582	.3582	.3439
10	.3258	.3395	.3439	.3801	.3582	.3224	.3439
11	.3077	.3772	.4163	.362	.394	.3403	.3258
12	.2896	.3395	.362	.3258	.3224	.3045	.3258
13	.2865	.3395	.3224	.3077		.2865	.3258
14	.2896	.3206	.3045	.2896	.2865	.2686	.3077
15	.2715	.2829	.2686	.2715	.2534		.3077
16	.2896	.3206	.2865	.362	.2715	.2865	.2896
17	.3258	.2896	.3584	.2865	.2865	.3395	.3045
18	.4344	.4706	.4715	.4298	.4298	.4338	.4477
19	.4525	.4706	.4715	.4477	.4119	.4904	.4298
20	.4706	.4344	.4715	.4119	.394	.4527	.4298
21	.3982	.4163	.415	.394	.3761	.415	.394
22	.362	.362	.3772	.3403	.3439	.3961	.3582
23	.3439	.3258	.3395	.3045	.2865	.3206	.3045
24	.2896	.3077	.2896	.3206	.2686	.2686	.3018
Max	.4706	.4706	.4715	.4477	.4298	.4904	.4477
Min	.2534	.2534	.2601	.2715	.2353	.2172	.2641
Avg	.3294	.3402	.3415	.3463	.3139	.3243	.3315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA URBAN S/DN[381] BU 1929****Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN****Feeder No / Name : 205 / 11 KV Nashik Nagar****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9425	.8131	.9328	.8775	.8131	.7762	.8402
2	.9425	.8131	.8962	.8589	.8131	.7865	.7468
3	.924	.8131	.8238	.8589	.7947	.7392	.7468
4	.924	.8316	.8596	.8589	.7947	.7762	.7468
5	.9425	.8871	.8962	.8775	.8316	.8131	.7468
6	.9795	.9425	.9145	.9149	.924	.9055	.8962
7	.9979	1.0534	.9328	.9522	.9979	1.0164	.9709
8	.924	.9795	.9694	.9896	1.0534	1.7556	1.0269
9	.961	1.0269	1.1273	1.0903	1.0719	1.0349	1.0534
10	.924	1.1389	1.0719	1.0903	1.0903	1.0903	1.0903
11	.8596	1.0642	1.0719	1.0534	1.0719	1.0903	.9979
12	.8316	1.0082	.9795	.961	.9795	.924	.8686
13	.7964	.8962	.8686	.924		.7947	.8501
14	.7392	.8775	.8501	.8686	.8131	.9425	.8316
15	.7207	.8589	.8131	.8501	.8131	.8686	.8131
16	1.6448	.8962	.8316	.924	.9055	.8501	.9425
17	.8501	.9795	.9149	.961	.961	1.0456	.9795
18	1.2567	1.3676	1.3256	1.386	1.2936	1.419	1.2936
19	1.2936	1.3306	1.363	1.3306	1.3121	1.3443	1.2567
20	1.2567	1.3491	1.2883	1.2382	1.2382	1.1763	1.1643
21	1.1458	1.2936	1.2696	1.2012	1.1643	1.1016	1.0903
22	.9979	1.1088	1.1016	1.0903	.9955	.9709	.961
23	.924	.9795	.9709	.924	.8686	.8962	.8316
24	.961	.8501	.961	.8775	.8316	.7762	
Max	1.6448	1.3676	1.363	1.386	1.3121	1.7556	1.2936
Min	.7207	.8131	.8131	.8501	.7947	.7392	.7468
Avg	.9892	1.0066	1.0014	.9983	.9753	.9956	.9455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****BHANDARA URBAN S/DN[381] BU 1929****Substation No/ Name :- 064022 / 33 KV BHANDARA TOWN****Feeder No / Name : 206 / 11KV Station Road****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2075	.1867	.2263	.1886	.1886	.2075
2	.1698	.2075	.1867	.2263	.1698	.168	.2075
3	.1698	.2075	.1848	.2263	.1698	.168	.2075
4	.1886	.1886	.168	.2263	.1698	.1886	.2075
5	.2075	.2075	.2054	.2452	.1886	.2075	.2075
6	.2452	.2263	.2427	.2452	.2075	.2263	.2075
7	.2829	.2641	.2477	.2452	.2263	.2641	.1886
8	.2452	.2263	.2241	.2452	.2075	.2452	.2452
9	.2075	.3018	.2829	.2829	.2452	.2641	.3018
10	.2452	.2641	.3772	.3018	.2641	.3206	.2641
11	.1886	.2452	.2829	.2452	.2641	.2829	.2641
12	.1698	.2452	.2452	.2263	.2641	.2263	.2452
13	.132	.1698	.1886	.2452		.1886	.2263
14	.1509	.2641	.2452	.2587	.2075	.2075	.2075
15	.1509	.1886	.2452	.2452	.2075	.2075	.1886
16	.1509	.2263	.2452	.3961	.2452	.2075	.1886
17	.1886	.2263	.2452	.2075	.1867	.2075	.2075
18	.2641	.3018	.3395	.3018	.3206	.3395	.3018
19	.3018	.2614	.3395	.3018	.3206	.3018	.3395
20	.3018	.2829	.3395	.3018	.3206	.3206	.3206
21	.2829	.2829	.3018	.2829	.3018	.3018	.3018
22	.2452	.2263	.2829	.2452	.2829	.2641	.2641
23	.2263	.2075	.2058	.2075	.2263	.2263	.2263
24	.1886	.2075	.2075	.2263	.1886	.1886	.2075
Max	.3018	.3018	.3772	.3961	.3206	.3395	.3395
Min	.132	.1698	.168	.2075	.1698	.168	.1886
Avg	.2122	.2349	.2508	.2568	.2336	.2380	.2389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 201 / 11 KV Jamb Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2835	.2715	.2865	.2865	.2658	.2481	.2378
2	.2835	.2715	.2865	.2865	.2658	.2481	.2378
3	.2804	.2715	.2896	.2865	.2658	.2481	.2378
4	.298	.2896	.3077	.2865	.2835	.2658	.2378
5	.3224	.2926	.3258	.3077	.3189	.2686	.2715
6	.3403	.3189	.3475	.362	.3366	.3403	.3258
7	.362	.3366	.3403	.3841	.3721	.3258	.362
8	.3439	.3224	.3475	.3475	.2835	.3439	.3292
9	.3475	.2896	.3982	.3012	.3189	.3475	.3224
10	.3258	.3658	.362	.3012	.3189	.362	.2835
11	.2534	.2957	.4525	.2835	.2896	.3258	.3189
12	.2686	.4251	.4163	.2658	.2896	.3439	.2835
13	.2835	.2801	.3439	.3189	.3109	.3292	.2658
14	.3012	.3361	.3077	.3012	.3045	.3077	.2835
15	.3189	.3544	.3439	.3012	.3045	.2534	.2835
16	.3224	.3681	.3292	.3582	.3224	.3439	.2715
17	.3224	.394	.3475	.3045	.3544	.4024	.3403
18	.5552	.6653	.5249	.5249	.5914	.5175	.5249
19	.591	.5847	.5068	.5249	.5601	.5487	.5249
20		.5601		.4835	.5415	.5304	.5249
21	.4163	.4251	.4344	.4525	.4066	.4024	.4525
22	.3439	.3224	.3439	.3439	.2926	.3109	.362
23	.3258	.2804	.3077	.3077	.2481	.2561	.2835
24	.2865	.2715	.2865	.2926	.2715	.2303	.2353
Max	.591	.6653	.5249	.5249	.5914	.5487	.5249
Min	.2534	.2715	.2865	.2658	.2481	.2303	.2353
Avg	.3381	.3580	.3581	.3422	.3382	.3375	.3250

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 202 / 11 KV Andhalgaon Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2075	.2263	.1867	.1867	.2263	.2054
2	.2263	.2263	.2263	.1867	.1867	.2263	.2054
3	.2641	.2075	.2263	.1867	.2054	.2263	.2054
4	.2614	.2075	.2452	.1867	.2054	.2452	.2801
5	.2801	.2427	.2641	.2054	.2241	.2641	.3734
6	.3174	.2801	.2957	.3547	.2614	.2829	.2987
7	.2641	.2614	.2926	.3547	.2772	.3018	.2987
8	.3018	.2402	.2987	.2801	.2957	.3142	.3174
9	.2801	.2402	.2772	.2561	.2926	.2452	.3077
10	.2402	.3142	.2614	.2378	.3109	.2241	.3326
11	.2402	.2987	.2427	.2195	.2987	.2614	.2926
12	.1991	.2452	.2054	.2012	.2801	.1867	.2743
13	.1791	.2614	.2241	.2012	.2427	.2054	.2926
14	.197	.2402	.1867	.1829	.2427	.1848	.2378
15	.1791	.1715	.2241	.1646	.1886	.2033	.1829
16		.1663	.2801	.1848	.3224	.1848	.2218
17	.2218	.2328	.2801	.2402	.2353	.2218	.2743
18	.4251	.4904	.4668	.4294	.4904	.4668	.4854
19	.462	.4715	.4572	.4481	.4715	.4854	.4668
20	.4668	.4763	.4207	.4108	.4572	.4668	.4294
21	.3961	.3584	.3326	.3206	.3395	.3734	.3547
22	.3018	.2641	.2614	.2614	.3174	.2801	.2987
23	.2452	.2263	.2054	.2263	.2075	.2241	.2054
24	.2263	.2075	.2263	.1867	.1886	.2075	.2054
Max	.4668	.4904	.4668	.4481	.4904	.4854	.4854
Min	.1791	.1663	.1867	.1646	.1867	.1848	.1829
Avg	.2783	.2724	.2761	.2547	.2804	.2712	.2936

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 203 / 11 KV Dhop Gaothan Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0943	.0739	.0934	.0934	.0739	.0732
2	.0739	.0943	.0747	.0934	.0934	.0739	.0732
3	.0747	.0943	.0747	.0934	.0934	.0747	.0732
4	.112	.112	.0747	.0934	.0934	.0747	.0914
5	.112	.1307	.0924	.112	.112	.0934	.1097
6	.1307	.1294	.1132	.1307	.1294	.132	.1478
7	.1307	.1086	.1478	.112	.1109	.1509	.1109
8	.112	.0914	.1294	.112	.0934	.112	.1294
9	.1097	.0924	.1109	.1097	.1109	.112	.1097
10	.0739	.0914	.0924	.1097	.1097	.0934	.1097
11	.0739	.0924	.0924	.0914	.0924	.0934	.1097
12	.0716	.0747	.1109	.0914	.0934	.0716	.1097
13	.0716	.0566	.0924	.0914	.1294	.0934	.0732
14	.0724	.0747	.0739	.0732	.0934	.0934	.0924
15	.0732	.0739	.0739	.0732	.0934	.0747	.0732
16	.0924	.0732	.0739	.0739	.0953	.0747	.0914
17	.0924	.1086	.0924	.0924	.0953	.0934	.1109
18	.1848	.1867	.2054	.1867	.2075	.1867	.168
19	.2033	.2075	.2054	.2054	.2075	.1867	.2054
20	.1867	.1886	.1867	.168	.1886	.1867	.168
21	.1509	.132	.1307	.132	.1294	.1494	.112
22	.1132	.0924	.112	.1132	.0924	.0934	.1132
23	.0943	.0739	.0934	.0943	.0924	.0747	.0934
24	.0739	.0943	.0739	.0914	.0943	.0924	.0732
Max	.2033	.2075	.2054	.2054	.2075	.1867	.2054
Min	.0716	.0566	.0739	.0732	.0924	.0716	.0732
Avg	.1066	.1070	.1084	.1099	.1144	.1065	.1092

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 204 / 11kv JAMB AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5182	.5639	.5719
2					.5182	.5639	.5719
3					.5182	.5792	.5719
4					.5487	.5792	.5117
5					.5792	.6097	.5719
6					.5944	.6554	.6773
8	.7011	.6481	.6249	.7621			
9	.8025	.7682	.8796	.8535			
10	.8124	1.0402	.9374	.8993			
11	.8855	1.1043	1.0311	.9602			
12	.8993	1.1043	1.0467	1.0059			
13	.945	.5851	1.0155	1.0669			
14	.9065	1.0911	1.078	1.0669			
15	.9145		.9998	.9602			
23					.5487	.5944	.5487
24	.5093					.5639	.5719
Max	.945	1.1043	1.078	1.0669	.5944	.6554	.6773
Min	.5093	.5851	.6249	.7621	.5182	.5639	.5117
Avg	.8196	.9059	.9516	.9469	.5465	.5887	.5747

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 205 / 11kv Andhalgaon AG Feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.5228	.4854			
2		.5601	.5228	.4854			
3		.5601	.5228	.4854			
4		.5601	.5601	.4854			
5		.5544	.5544	.4854			
6		.5487	.5544	.5041			
8	.6767				.5544		.7421
9	.7207				.7316	.6283	.8596
10	.7682				.7865	.7023	.9145
11	.823				.9149	.8501	.9511
12	.7701				.9149	.9055	.9511
13	.788				.8589	.9425	1.0059
14	.7964				.8192	.9694	.905
15	.823				.8764	.9145	.9145
23		.4938	.4755	.3696			
24			.5041	.4755	.3696		
Max	.823	.5601	.5601	.5041	.9149	.9694	1.0059
Min	.6767	.4938	.4755	.3696	.3696	.6283	.7421
Avg	.7708	.5482	.5271	.4720	.7585	.8447	.9055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064003 / 33 KV JAMB S/S****Feeder No / Name : 207 / 11kv Dhop Agp****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5729	.5731	.5493
2					.5544	.5731	.5493
3					.5544	.5731	.5493
4					.5914	.5792	.5493
5					.6036	.5792	.567
6					.6036	.5792	.6024
8	.7522	.6984	.7164	.7343			
9	.8326	.7602	.7522	.8596			
10	.8507	.8059	.788	.8962			
11	.8688	.8596	.8596	.905			
12	.8413	.8505	.8954	.8688			
13	.8775	.8859	.8059	.8596			
14	.8954	.8505	.8059	.8507			
15	.7522	.7888	.7522	.8779			
23					.5731	.5914	.5359
24	.6036					.5731	.5493
Max	.8954	.8859	.8954	.905	.6036	.5914	.6024
Min	.6036	.6984	.7164	.7343	.5544	.5731	.5359
Avg	.8083	.8125	.7970	.8565	.5791	.5777	.5565

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 206 / 11 KV Chichkheda Feeder****SINGLE PHASING****SP Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2772	.2772	.3018	.8063	.815	.7316
2	.2743	.2801	.2772	.2829	.7888	.8145	.7499
3	.2926	.2801	.2772	.2829	.8063	.8145	.7682
4	.2926	.2801	.2957	.2829	.8589	.8413	.7865
5	.3292	.3018	.3142	.2829	.929	.8869	.8779
6	.3658	.3772	.3547	.3772	1.0517	1.0425	.9492
7	.3109	.2987	.3174	.3361	.298	.3206	.3292
8	1.0517	1.286	1.2449	1.0056	.2957	.2829	.2743
9	1.2346	1.2003	1.3392	1.1883	.2801	.2402	.2378
10	1.3032	1.3717	1.3336	1.3392	.2241	.1991	.2012
11	1.3904	1.4146	1.3957	1.3957	.0732	.1791	.1463
12	1.5089	1.3957	1.262	1.1506	.1463	.1254	.128
13		1.3392	1.2254	1.3392	.1463	.1254	.128
14	1.4712	1.2449	1.2071	1.2449	.1267	.1254	.1097
15	1.3392	1.1883	1.0974	1.1128	.1254	.1254	.1029
16	.1294	.1063	.1254	.1402	.1227	.1254	.1227
17	.1595	.1612		.1612	.1629	.1829	.1715
18	.4294	.462	.4435	.462	.4854	.4207	.4755
19	.5041	.5041	.5041	.5228	.463	.4755	.4755
20	.4668	.462	.5041	.4854	.4239	.4572	.4755
21	.3881	.3881	.3921	.3734	.3921	.3658	.3761
22	.3142	.3142	.3174	.3734	.2801	.2743	.2686
23	.2772	.2957	.3174	.7628	.7619	.6767	.2507
24	.2743	.2772		.2987	.8063	.8063	.7133
Max	1.5089	1.4146	1.3957	1.3957	1.0517	1.0425	.9492
Min	.1294	.1063	.1254	.1402	.0732	.1254	.1029
Avg	.6253	.6461	.6738	.6460	.4523	.4468	.4104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 207 / 11 KV Pardi Feeder SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1663	.1478	.1509	.4733	.3721	.4024
2	.1829	.168	.1478	.1509	.4557	.3801	.4024
3	.2012	.168	.1478	.1509	.4557	.3801	.4207
4	.2012	.1494	.1478	.1509	.4557	.4024	.439
5	.2012	.1698	.1663	.1698	.4382	.3982	.4572
6	.2012	.2075	.2054	.2054	.4908	.4207	.4835
7	.1646	.2054	.1867	.2054	.1867	.1509	.1463
8	.5434	.6344	.6224	.5548	.2033	.1132	.1097
9	.6485	.6516	.7356	.6413	.1494	.1848	.128
10	.6173	.6173	.7621	.6602	.1494	.1448	.1463
11	.5935	.6979	.695	.7733		.1254	.1097
12	.6001	.6979	.695	.811		.0895	.0914
13	.6173	.5847	.7316	.8299	.0914	.0895	.0914
14	.6602	.7356	.7133	.6979	.0905	.0716	.0914
15	.6224	.7167	.7499	.6413	.1075	.0716	.0857
16	.0739	.1063	.0895	.0876	.1052	.0895	.0876
17	.124	.1075	.1254	.1075	.1086	.1086	.1372
18	.2614	.2587	.2772	.2772	.2801	.2561	.2743
19	.2987	.2987	.2801	.2801	.2572	.2743	.2926
20	.2801	.2957	.2241	.2801	.2374	.2561	.2686
21	.2402	.2402	.2241	.2054	.2241	.2012	.2149
22	.1663	.1848	.168	.168	.1494	.1463	.1612
23	.1663	.1478	.168	.4508	.3721	.3658	.1254
24	.1829	.1663	.1478	.168	.4733	.3681	.3841
Max	.6602	.7356	.7621	.8299	.4908	.4207	.4835
Min	.0739	.1063	.0895	.0876	.0905	.0716	.0857
Avg	.3347	.3490	.3566	.3674	.2707	.2275	.2313

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 208 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.3547	.3326	.2427	.2427	.2587	.2378
2	.2378	.3547	.3326	.2614	.2427	.2587	.2561
3	.2378	.3547	.2957	.2241	.2427	.2402	.2561
4	.2561	.3734	.2957	.2241	.2614	.2427	.2743
5	.2743	.3921	.3174	.2241	.2614	.2614	.2743
6	.2926	.3734	.3734	.2427	.2427	.2402	.2743
7	.3109	.4108	.4481	.2427	.2427	.462	.2561
8	.3292	.4481	.4294	.5788	.4668	.5914	.3109
9	.4024	.2801	.4527	.4481	.6348	.6099	.2195
10	.3475	.3734	.7468	.6161	.4854	.5487	.4207
11	.3696	.3734	.4572	.6161	.5175	.6401	.5228
12	.4435	.2987	.3292	.5975	.5544	.567	.6161
13	.5975	.3547	.2926	.4108	.5359	.4755	.6722
14	.6535	.5415	.3292	.4108	.4294	.3841	.2987
15	.6535	.3174	.3841	.4481	.4805	.4024	.5228
16	.6767	.3921	.4207	.5788	.4066	.439	.5415
17	.5041	.3361	.4572	.5041	.4435	.4207	.4668
18	.2614	.2926	.2241	.3547	.2801	.2743	.695
19	.2987	.2926	.2427	.2054	.2402	.2195	.2926
20	.3174	.2957	.2427	.2427	.2587	.2195	.2865
21	.2987	.2926	.2427	.2427	.2614	.2195	.3045
22	.3174	.2743	.2427	.2241	.2427	.2195	.3403
23	.3361	.3511	.2427	.2427	.2427	.2195	.4119
24	.2195	.3361	.3511	.2427	.2427	.2561	.2378
Max	.6767	.5415	.7468	.6161	.6348	.6401	.695
Min	.2195	.2743	.2241	.2054	.2402	.2195	.2195
Avg	.3690	.3527	.3535	.3594	.3525	.3613	.3746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 210 / 11kv Kanhalgaon SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0739	.0739	.0754	.2279	.2126	.2378
2	.0914	.0747	.0739	.0754	.2103	.2172	.2378
3	.0914	.0747	.0739	.0754	.2279	.2172	.2378
4	.0914	.0747	.0739	.0754	.2279	.2195	.2378
5	.1097	.0943	.0924	.0754	.2279	.2172	.2561
6	.1097	.1132	.0934	.1132	.2658	.2561	.2686
7	.0914	.112	.0934	.112	.112	.1132	.1097
8	.3109	.3086	.2829	.2947	.0924	.1132	.0732
9	.3258	.3086	.3395	.3395	.0934	.0924	.0732
10	.3429	.3086	.3429	.3206	.0934	.0724	.0549
11	.2883	.3206	.3584	.3395	.0732	.0537	.0549
12	.3944	.3206	.3395	.3395	.0549	.0537	.0366
13	.3944	.3961	.3584	.3018	.0549	.0537	.0366
14	.3584	.3584	.3206	.3961	.0543	.0537	.0366
15	.3206	.3206	.3292	.3584	.0537	.0537	.0343
16	.0554	.0354	.0537	.0351	.0526	.0537	.0351
17	.0532	.0358	.0537	.0358	.0724	.0537	.0343
18	.112	.1109	.1294	.1294	.1307	.128	.128
19	.1307	.1307	.1307	.1307	.3258	.128	.128
20	.1307	.1294	.1307	.1307	.0848	.128	.1254
21	.1109	.1109	.112	.112	.112	.0914	.0914
22	.0924	.0739	.0934	.0747	.0747	.0732	.0716
23	.0739	.0739	.0934	.2254	.2303	.2378	.0716
24	.0732	.0739	.0739	.0934	.2279	.2103	.2378
Max	.3944	.3961	.3584	.3961	.3258	.2561	.2686
Min	.0532	.0354	.0537	.0351	.0526	.0537	.0343
Avg	.1761	.1681	.1715	.1775	.1409	.1293	.1212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 212 / 11kv Dongargaon SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0739	.0739	.0747	.6099	.5601	.4755
2	.0914	.0739	.0739	.0747	.6099	.5601	.4938
3	.0914	.0739	.0739	.0747	.6283	.5544	.4938
4	.1097	.0924	.0739	.0747	.6283	.5914	.5121
5	.1097	.0924	.0934	.0747	.6099	.6283	.5487
6	.1097	.1097	.112	.112	.6283	.6653	.567
7	.0914	.0914	.0934	.0934	.0924	.0924	.0914
8	.6401	.8501	.7655	.6908	.0739	.0739	.0732
9	.7888	.9145	.7922	.8215	.0739	.0739	.0549
10	.8596	.7947	.8402	.8501	.0554	.0554	.0549
11	.8316	.7947	.7682	.8501	.0554	.0549	.0554
12	.8501	.7392	.7865	.8316	.056	.0366	.037
13	.8775	.7577	.7865	.7762	.037	.0366	.037
14	.9522	.7947	.8596	.7762	.056	.0366	.037
15	.8215	.7023	.7316	.7392	.037	.0366	.037
16	.0366	.037	.0549	.037	.037	.0366	.037
17	.0554	.0554	.0549	.0549	.0554	.0549	.0554
18	.1294	.1478	.168	.1663	.1494	.1463	.1463
19	.1663	.1663	.1307	.1478	.1478	.1433	.1646
20	.1663	.1478	.1494	.1478	.1478	.1433	.1463
21	.1294	.128	.112	.1109	.0747	.1075	.1097
22	.0924	.0914	.0934	.0924	.0747	.0732	.0732
23	.0739	.0739	.0934	.6283	.5601	.4656	.0732
24	.0914	.0739	.0739	.0934	.6283	.5601	.4755
Max	.9522	.9145	.8596	.8501	.6283	.6653	.567
Min	.0366	.037	.0549	.037	.037	.0366	.037
Avg	.3441	.3282	.3273	.3497	.2553	.2411	.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064009 / 33 KV MOHADI S/S****Feeder No / Name : 401 / 33 KV MIDC****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5437	1.4346	1.3791	1.1151	1.2752	1.4266	1.4266
2	1.5432	1.4346	1.3791	1.1151	1.1643	1.4815	1.4266
3	1.5432	1.4346	1.3717	1.0596	1.1643	1.4907	1.4815
4	1.5432	1.3866	1.4815	1.0036	1.2198	1.8656	1.5364
5	1.6535	1.4426	1.5363	1.1145	1.2814	1.6558	1.7558
6	1.7644	1.6009	1.6461	1.2826	1.5604	1.701	1.9205
7	.9877	1.6009	1.4814	1.6169	1.4969	1.6461	1.8107
8	1.8748	1.7672	1.701	1.6164	1.7741	1.9318	2.0302
9	2.1508	1.7672	1.5912	1.8947	1.6553	1.9862	2.0851
10	2.1508	1.7661	1.5998	1.7187	1.5998	1.7107	2.0302
11	2.3285	2.0422	1.9307	1.3306	1.8107	1.8656	2.0965
12	2.4257	1.8758	1.8748	2.0616	2.0302	1.8656	2.1513
13	2.2605	1.7661	1.7639	1.9404	1.8204	1.8656	1.9959
14	1.985	1.7661	1.7644	1.7742	1.7559	1.9754	1.7742
15	1.6546	1.2105	1.7644	1.7278	1.7009	1.7558	1.7742
16	1.4637	1.8764	1.5444	1.7833	1.7655	1.8107	2.1067
17	1.4814	1.7101	1.4895	1.885	1.7107	1.8656	2.1068
18	1.9867	2.152	2.0621	2.1622	2.0416	2.5789	2.5914
19	1.9982	1.9753	1.8953	2.1176	1.9318	2.2497	2.1502
20	1.9867	1.9753	1.8953	1.9507	1.8107	2.0851	1.8199
21	1.5455	1.8753	1.6718	1.6078	1.49	1.7558	1.7095
22	1.49	1.4266	1.3381	1.3929	1.4346	1.262	1.6546
23	1.4895	1.4414	1.2266	1.1088	1.4346	1.3168	1.6546
24	1.4889	1.4346	1.3791	1.2266	1.2198	1.4358	1.4266
Max	2.4257	2.152	2.0621	2.1622	2.0416	2.5789	2.5914
Min	.9877	1.2105	1.2266	1.0036	1.1643	1.262	1.4266
Avg	1.7642	1.6735	1.6153	1.5669	1.5895	1.7744	1.8548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064033 / 33 KV Kardi****Feeder No / Name : 201 / 11kv Kardi AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						1.3565	1.3717
2						1.3413	
3						1.3226	
4						1.3077	
5						1.3565	
6						1.3226	
8		1.6448	1.595	1.543	1.5424		
9	1.5261	1.8107	1.6787	1.5432	1.6278		1.3395
10	1.8991	1.9669	1.6289	1.6956	1.7772		1.4403
11	1.9951	1.9951	1.6617	1.7295	1.7974		1.543
12	2.0222	2.0178	1.7101	1.7635	1.8442		1.4403
13	2.0622	1.9669	1.7436	1.7772	1.7635		
14	1.8233	1.643	1.7939	1.7635	1.8519		
15	1.8442	1.6617	1.5769	1.6598	1.8724		
23						1.3375	1.387
24							1.3565
Max	2.0622	2.0178	1.7939	1.7772	1.8724	1.3565	1.543
Min	1.5261	1.643	1.5769	1.543	1.5424	1.3077	1.3395
Avg	1.8817	1.8384	1.6736	1.6844	1.7596	1.3350	1.4112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064033 / 33 KV Kardi****Feeder No / Name : 202 / Koka Feeder****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8745	.8842	.7888	.6935	.6588	.6859
2	.7282	.8842	.9114	.8059	.703	.6516	.6661
3	.7537	.8478	.9189	.6836	.703	.6935	.7087
4	.7455	.8573	.8745	.6556	.7282	.6859	.7455
5	.7362	.8842	.9259	.6733	.7455	.6706	
6	.7628	.8916	.9015	.6836	.7716	.7122	.763
7	.8059	.9088	.964	.6661	.8573	.7455	.7373
8	.8495	.8309	.9259	.7802	.7969	.7108	.7282
9	.8573	.8718	.8745	.7282	.8573	.7202	.703
10	.6661	.9496	.8745	.8402	.8916	.7373	.7455
11	.8842	.9892	.9015	.9259	.8648	.7802	.823
12	.8573	1.0343	.9088	.9259	.8916	.7975	.8238
13	.9015	.9892	.8478	.8987	.9015	.6935	.9362
14	.9015	1.0174	.8916	.8059	.8648	.7545	.8573
15	.6173	1.0059	.8589	.8669	.8478	.8478	.9015
16	.9882	.9892	.9774	.8745	.8383	.9156	.8764
17	1.0288	.9835	1.0174	.929	.6036	.9431	.8916
18	1.153	1.1065	1.1191	.9431	.6104	1.0227	.9362
19	1.1831	1.0562	1.0174	.9431	.7545	.9326	.9774
20	1.0974	1.0682	.9774	.8916	.8383	.9602	.9015
21	1.0229	.9835	.8817	.8149	.763	.8916	.823
22	.9088	.9054	.8573	.7291	.7377	.8573	.6859
23	.8916	.8619	.8495	.7202	.7122	.7802	.6588
24	.7545	.8745	.8718	.8149	.6952	.6371	.6836
Max	1.1831	1.1065	1.1191	.9431	.9015	1.0227	.9774
Min	.6173	.8309	.8478	.6556	.6036	.6371	.6588
Avg	.8687	.9444	.9180	.8079	.7780	.7833	.7939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064033 / 33 KV Kardi****Feeder No / Name : 203 / Kardi Gavthan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.2629	.3086	.2804	.2804	.2401	.2629
2	.2947	.2774	.3086	.2804	.3012	.2427	.2601
3	.2743	.2743	.298	.2658	.3045	.2254	.2427
4	.2804	.2658	.2947	.2835	.2865	.2454	.2454
5	.3012	.2658	.3086	.3121	.2835	.2629	.2804
6	.298	.2804	.3086	.2947	.298	.2774	.2658
7	.2915	.2804	.298	.3086	.3155	.2947	.2658
8	.3155	.2774	.2774	.2454	.2629	.3086	.2481
9	.2601	.2572	.3086	.2303	.2804	.2915	.2481
10	.2629	.3258	.3086	.2629	.2835	.2947	.2454
11	.2454	.1715	.373	.2481	.2601	.3121	.2601
12	.3155	.1734	.2401	.3045	.2572	.3086	.2058
13	.2507	.2743	.2454	.2427	.3121	.2774	.2629
14	.3403	.2601	.2303	.2454	.2279	.2629	.208
15	.2328	.2629	.3155	.2835	.3189	.2774	.2401
16	.2534	.2103	.3258	.3155	.3189	.2804	.3121
17	.3506	.3681	.3429	.298	.3366	.3086	.3944
18	.5083	.4854	.4694	.5316	.4854	.4694	.4382
19	.5083	.5144	.4409	.5201	.463	.407	.4681
20	.4557	.5144	.4239	.4801	.3988	.407	.4801
21	.4784	.3772	.373	.3681	.3086	.3944	.4334
22	.333	.3294	.3429	.3121	.2743	.373	.3681
23	.3189	.3258	.3086	.2835	.2572	.3155	.3294
24	.298	.2629	.3086	.2804	.2804	.2229	.2658
Max	.5083	.5144	.4694	.5316	.4854	.4694	.4801
Min	.2328	.1715	.2303	.2303	.2279	.2229	.2058
Avg	.3233	.3041	.3233	.3116	.3082	.3042	.3013

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064040 / MIDC MOHADI****Feeder No / Name : 201 / 11 kv Mohadi Gaothan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2195	.2195	.1829	.1829	.1829	.1829
2	.2012	.2195		.1829	.1646	.1829	.2012
3	.2012	.2195	.2195	.1646	.1646	.1829	.2012
4	.1829	.2195	.2378	.1646	.1829	.1829	.2012
5	.2012	.2378	.2561	.2012	.2012	.2012	.2195
6	.2378	.2378	.2561	.2378	.2378	.2195	.2561
7	.2743	.2743	.2743	.2926	.2743	.2378	.3109
8	.2926	.2743	.2743	.2561	.3109	.2926	.2926
9	.3292	.2926	.3109	.3658	.2926	.2743	.3109
10	.3658	.2926	.3841	.2743	.3292	.2926	.4024
11	.4207	.4024	.3841	.3292	.3292	.3109	.3841
12	.4024	.4024	.3658	.3292	.4207	.3475	.3841
13	.2926	.3658	.3292	.3109	.3658	.3658	.3475
14	.3292	.3841	.2926	.2926	.3658	.3292	.3292
15	.3658	.3841	.3475	.3109	.3841	.3658	.3292
16	.3292	.4024	.3475	.3658	.4024	.3475	.3475
17	.3292	.3841	.2926	.4207	.3658	.4024	.4207
18	.4755	.3841	.4024	.4024	.3658	.4024	.4938
19	.439	.3841	.3658	.4024	.3658	.3658	.439
20	.3658	.3658	.3658	.3658	.3109	.3292	.3841
21	.3109	.3292	.3292	.3109	.2926	.2926	.3841
22	.2561	.2926	.2378	.2561	.2378	.2561	.3109
23	.2012	.2195	.1829	.2012	.1829	.2012	.2378
24	.2012	.2195	.2012	.1829	.1829	.1829	.1829
Max	.4755	.4024	.4024	.4207	.4207	.4024	.4938
Min	.1829	.2195	.1829	.1646	.1646	.1829	.1829
Avg	.3003	.3086	.299	.2835	.2881	.2812	.3147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****MOHADI S/DN.[383]****BU 0383****Substation No/ Name :- 064040 / MIDC MOHADI****Feeder No / Name : 202 / 11 KV MOHADI MIDC
Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0362	.0362	.0716	.0537	.0181	.0543
2	.0537	.0366	.0181	.0358	.0537	.0181	.0543
3	.0537	.0366	.0181	.0358	.0537	.0181	.0543
4	.0537	.0549	.0181	.0179	.0358	.0181	.0543
5	.0537	.0549	.0181	.0179	.0358	.0181	.0543
6	.0537	.0732	.0181	.0537	.0537	.0181	.0543
7	.0179	.0183	.0181	.0179	.0358	.0181	.0362
8	.0358	.0543	.0181	.0358	.0716	.0366	.0543
9	.0358	.0181	.0549	.0716	.0716		.0724
10	.0179	.0549	.0179	.0179	.0183	.0183	.0362
11	.0537	.0732	.0716	.0716	.0724	.0543	.0543
12	.0537	.0732	.0358	.0716	.0905	.0543	.0716
13	.0537	.0362	.0537	.0716	.0362	.0543	.0716
14	.0537	.0543	.0716	.0537	.0362	.0724	.0358
15	.0537	.0181	.0179	.0179	.0181	.0362	.0179
16	.0716	.0543	.0358	.0716	.0724	.0543	
17	.0537	.0543	.0358	.0716	.0362	.0724	.0537
18	.0537	.0362	.0716	.0716	.0724	.0724	.0716
19	.0181	.0362	.0179	.0537	.0181	.0543	.0179
20	.0732	.0543	.0537	.0537	.7059	.0543	.0716
21	.0366	.0366	.0537	.0358	.7059	.0543	.0537
22	.0366	.0183	.0358	.0358	.0362	.0362	.0537
23		.0181	.0358	.0179	.0181	.0362	.0537
24	.0366	.0362	.0724	.0716	.0537	.0181	.0362
Max	.0732	.0732	.0724	.0716	.7059	.0724	.0724
Min	.0179	.0181	.0179	.0179	.0181	.0181	.0179
Avg	.0469	.0432	.0375	.0477	.1023	.0394	.0517

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 201 / 11 KV BHAVAD FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.1132	.132	.1132	.3605	.2915	.2896
2	.3201	.1132	.132	.1132	.3605	.2915	.2896
3	.3201	.1132	.132	.1132	.3768	.3077	.3048
4	.3201	.132	.1132	.1132	.3605	.3395	.3048
5	.3521	.132	.1698	.1886	.3768	.3239	.3353
6	.4481	.2075	.2075	.2263	.4424	.3887	.3906
7	.176	.1886	.2075	.132	.1509	.1509	.2075
8	.2263	.5921	.7969	.7209	.1509	.1886	.132
9	.1132	.8162	.9665	.852	.132	.132	.1132
10	.0943	.9282	.9835	.9393	.1132	.0943	.132
11	.1132	.8642	1.0513	.9717	.0943	.0754	.0943
12	.1132	.8322	1.0004	.9069	.1132	.0943	.0943
13	.0943	.8322	.8987	.7748	.1132	.0566	.0943
14	.0943	.8322	.8309	.7274	.1132	.0566	.0943
15	.0943	.7682	.7461	.6642	.0943	.0566	.0943
16	.1132	.0943	.0754	.0754	.0943	.0566	.0943
17	.1132	.1886	.1886	.132	.0943	.1132	.1132
18	.3018	.2829	.3018	.3018	.2829	.3206	.2263
19	.3206	.3206	.3018	.3206	.3018	.3206	.3206
20	.3206	.2829	.2641	.2829	.2829	.2829	.3018
21	.2452	.2263	.2263	.2075	.1886	.2452	.2452
22	.1698	.1886	.1132	.132	.132	.1132	.1509
23	.132	.1132	.1132	.3605	.2915	.301	.3041
24	.3201	.1132	.1132	.1132	.373	.2915	.2743
Max	.4481	.9282	1.0513	.9717	.4424	.3887	.3906
Min	.0943	.0943	.0754	.0754	.0943	.0566	.0943
Avg	.2182	.3865	.4194	.3951	.2248	.2039	.2084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 202 / 11 KV GOSE FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.7773	.7545	.6783	.4904	.4904	.4715
2	.5658	.7611	.7545	.6783	.4715	.4904	.4527
3	.5658	.7449	.7545	.7545	.4715	.5093	.4527
4	.6224	.7499	.823	.6783	.5093	.4904	.4338
5	.6602	.8097	.9259	.763	.6036	.6413	.5847
6	.8676	.9393	1.0288	.9835	.7545	.7922	.7545
7	.811	.8299	.7922	.7733	.7167	.8676	.7733
8	1.335	.7733	.7545	.6979	1.2517	1.1831	1.21
9	1.491	.6979	.7733	.6979	1.4403	1.5432	1.442
10	1.4918	.6602	.679	.7167	1.4918	1.4918	1.4918
11	1.3717	.5658	.5847	.6224	1.4918	1.4419	1.5083
12	1.3735	.4715	.4904	.5281	1.3889	1.4083	1.4752
13	1.2346	.4527	.4338	.4338	1.406	1.4754	1.3904
14	1.2742	.4338	.4338	.415	1.4575	1.4251	1.3735
15	1.1568	.4338	.415	.4338	1.4575	1.2887	1.2548
16	.4338		.415	.4338	.4338	.2641	.3772
17	.4527	.5847	.6224	.5281	.5093	.3206	.5281
18	1.1128	1.094	1.2071	1.1694	1.1694	1.1506	1.0751
19	1.226	1.2071	1.2449	1.1694	1.1694	1.1694	1.2071
20	1.1128	1.1128	1.1883	1.0751	1.0562	1.0562	1.0562
21	.9619	.8676	1.0185	.7733	.9431	.7733	.8488
22	.679	.7733	.7733	.5658	.6036	.5658	.6224
23	.7209	.7488	.6783	.5281	.5093	.5093	.5093
24	.5847	.7773	.7373	.6783	.4904	.4914	.4715
Max	1.4918	1.2071	1.2449	1.1694	1.4918	1.5432	1.5083
Min	.4338	.4338	.415	.415	.4338	.2641	.3772
Avg	.9454	.7507	.7618	.6990	.9286	.9100	.9069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 203 / 11 KV KONDHA FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7122	.6413	.6224	.5847	.6859	.6613	.5247
2	.7291	.6224	.6224	.5847	.6687	.6443	.5093
3	.7461	.6036	.6036	.5847	.703	.6443	.5247
4	.78	.5847	.6413	.6036	.7716	.6443	.5556
5	.7969	.7356		.679	.8916	.7122	.6249
6	.9326	.8488	.8676	.9808	.9259	.8309	.7287
7	.9808	.9054	.8299	.9808	.8488	.9054	.8676
8	.8865	1.0682	1.3937	1.3003	.8676	.8299	.8488
9	.7461	1.2548	1.5565	1.439	.8488	.8488	.8488
10	.7167	1.3056	1.5023	1.3916	.7356	.7545	.6979
11	.6602	1.2039	1.1584	1.3916	.679	.6224	.5847
12	.679	1.3056	1.4299	1.3413	.6224	.5093	.4715
13	.415	1.3056	1.3937	1.2597	.6036	.2075	.4715
14	.5658	1.3056	1.3394	1.2431	.547	.5281	.4715
15	.5281	1.3056	1.3575	1.2431	.5281	.5093	.4715
16	.547	.4904	.4904	.5281	.547	.4904	.547
17	.5658	.6602	.7167	.6413	.679	.3584	.679
18	1.1506	1.2071	1.1506	1.1694	1.1506	1.226	1.1128
19	1.2637	1.2071	1.1694	1.1506	1.1694	1.226	1.1694
20	1.1694	1.1317	1.0751	1.094	1.0751	1.0374	1.0562
21	1.0562	.9242	.9242	.8488	.9054	.8676	.8488
22	.7733	.8299	.7167	.679	.679	.6602	.679
23	.679	.679	.6413	.703	.6783	.5468	.5426
24	.7122	.6413	.6413	.5847	.6859	.6613	.5247
Max	1.2637	1.3056	1.5565	1.439	1.1694	1.226	1.1694
Min	.415	.4904	.4904	.5281	.5281	.2075	.4715
Avg	.7830	.9487	.9932	.9586	.7707	.7053	.6817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 204 / 11 KV Virlee Feeder****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2915	.3018	.2715	.2263	.2452	.2263
2	.2641	.2915	.2715	.2534	.2263	.2263	.2263
3	.2641	.2401	.2896	.2715	.2263	.1886	.2263
4	.2829	.2915	.2896	.2715	.2263	.2075	.2263
5	.3018	.3086	.3258	.3258	.2829	.2452	.2829
6	.3772	.3429	.3258	.3801	.3584	.3206	.3206
7	.3018	.3018	.2641	.3018	.3018	.2829	.3395
8	.3982	.2829	.2829	.3018	.3077	.3582	.4239
9	.4163	.2829	.2832	.2829	.4163	.4477	.407
10	.3898	.2452	.2829	.2641	.4163	.4477	.5087
11	.3721	.2075	.2641	.2452	.1267	.4382	.4409
12	.2804	.1886	.2075	.2263	.4344	.4382	.4119
13	.3366	.1886	.2075	.2075	.4527		.394
14	.3155	.1698	.1886	.1886	.4706		.4904
15	.3155	.1886	.1509	.1886	.3801	.3944	.3761
16	.1886	.1886	.2075	.1886	.1991	.2075	.0754
17	.1886	.2452	.2452	.2075	.2263	.2452	.2263
18	.5847	.6036	.5847	.6224	.6036	.6224	.6224
19	.6413	.679	.679	.6602	.6979	.679	.6979
20	.6036	.6224	.5847	.6036	.6413	.6224	.6224
21	.4904	.4715	.4715	.415	.5093	.4715	.4904
22	.3395	.3772	.3206	.3018	.3206	.3018	.3395
23	.2058	.2353	.2715	.2641	.2641	.2641	.2829
24	.2641	.3086	.2896	.2715	.2452	.2452	.2452
Max	.6413	.679	.679	.6602	.6979	.679	.6979
Min	.1886	.1698	.1509	.1886	.1267	.1886	.0754
Avg	.3495	.3147	.3163	.3131	.3567	.3591	.3710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 205 / 11 KV Palora Feeder****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.5376	.6413	.4531	.2641	.2263	.2263
2	.2829	.5535	.5636	.4531	.2641	.2195	.2075
3	.2829	.5535	.547	.4531	.2641	.2263	.2075
4	.3206	.5535	.5967	.4374	.3018	.2452	.1886
5	.3584	.5851	.6464	.4687	.3395	.2829	.3206
6	.3772	.6325	.6796	.5312	.3772	.3584	.3772
7	.3772	.3772	.3772	.3395	.3772	.3206	.3395
8		.3206	.3018	.2641	.6874	.9602	.8322
9	1.0202	.2263	.2829	.2452	.8436	1.1523	1.1043
10	1.166	.2641	.2829	.2075	.8905	1.2003	.9442
11	1.1336	.2263	.2263	.1886	.9686	1.186	1.2003
12	1.1469	.1698	.1886	.1132	.5468	1.1544	1.2125
13	1.1336	.1698	.2075	.1886	.8592	1.1227	1.0978
14	.9555	.1509	.2075	.1886	1.0467	1.1227	1.0978
15	.8907	.1509	.1886	.1886	.9686	1.1012	.9667
16	.2263	.1886	.2452	.2641	.2452	.1886	.1886
17	.1886	.2075	.2829	.2641	.2452	.3772	.2641
18	.5093	.3961	.5281	.547	.547	.4527	.415
19	.5847	.547	.5281	.5658	.5281	.4904	.5093
20	.5093	.4904	.4715	.5093	.4715	.4527	.4715
21	.415	.3961	.3772	.3772	.3961	.3584	.3772
22	.3395	.3206	.3018	.3206	.3206	.2641	.2829
23	.5155	.4475	.3906	.2829	.2263	.2452	.2641
24	.5847	.5376	.5304	.4531	.2641	.2263	.2263
Max	1.166	.6325	.6796	.5658	1.0467	1.2003	1.2125
Min	.1886	.1509	.1886	.1132	.2263	.1886	.1886
Avg	.5914	.3751	.3997	.3460	.5101	.5806	.5551

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064005 / KOSRA SUB STATION****Feeder No / Name : 206 / 11 KV Pimpalgaon Feeder****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3125	.2263	.1886	.1698	.4062	.427	.4111
2	.3125	.2075	.1509	.1698	.4062	.3795	.427
3	.3125	.2075	.1509	.1698	.4062	.3795	.427
4	.3593	.1886	.1698	.1698	.4374	.3795	.4111
5	.3749	.2263	.2263	.2263	.4687	.3953	.427
6	.3906	.3395	.2829	.3584	.4999	.427	.4475
7	.2263	.2829	.2452	.2641	.2263	.2641	.2452
8	.1886	.6062	.6325	.6009	.2263	.2195	.2263
9	.2263	.7209	.7116	.6167	.2452	.2452	.2641
10	.132	.7209	.7274	.6325	.2263	.1886	.2263
11	.132	.6412	.7116	.7127	.2263	.1886	.2012
12	.1698	.7045	.7116	.6962	.1886	.1886	.1509
13	.1509	.6554	.7116	.6796	.1886	.1886	.1509
14		.6062	.68	.6796	.1509	.1886	.1509
15		.5898	.6325	.6299	.1698	.1886	.1509
16		.1698	.1509	.1886	.1698	.1886	.1886
17	.2075	.2075	.2075	.2263	.1509	.1886	.1886
18	.5093	.4715	.4527	.4715	.4715	.4715	.3772
19	.5658	.547	.4904	.547	.5093	.5281	.5281
20	.5093	.4715	.4338	.4715	.4904	.4715	.4715
21	.415	.3395	.3395	.3584	.3772	.3206	.3584
22	.2641	.2641	.2263	.2263	.2378	.2263	.2452
23	.2263	.2075	.2075	.4062	.3637	.3906	.4805
24	.3125	.2075	.1886	.1698	.4062	.427	.3795
Max	.5658	.7209	.7274	.7127	.5093	.5281	.5281
Min	.132	.1698	.1509	.1698	.1509	.1886	.1509
Avg	.2999	.4087	.4013	.4101	.3187	.3109	.3140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064006 / ADYAL SUB STATION****Feeder No / Name : 201 / 11 KV ADYAL FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.3012	.3189	.2481	.1772	.2454	.2454
2	.1949	.3012	.3189	.2481	.1772	.2454	.2454
3	.1949	.3012	.3012	.2481	.1595	.2103	.2279
4	.2126	.2481	.3012	.2481	.1949	.2103	.2279
5	.2303	.2481	.3012	.2481	.2303	.2103	.2279
6	.2303	.2835	.3189	.2658	.2835	.2454	.2454
7	.2658	.3366	.3366	.2835	.3366	.298	.298
8	.3189	.3012	.3012	.3012	.3189	.2804	.298
9	.2658	.3012	.2835	.3189	.3012	.2629	.3506
10		.3721	.3189	.3012	.3721	.298	.3856
11		.3544	.3012	.3189	.3721	.2804	.333
12		.3012	.3012	.3366	.3012	.2629	.298
13	.3366	.3898	.2835	.3544	.3366	.2454	.333
14		.3721	.2658	.3189	.3012	.2279	.2804
15		.3721	.2658	.2835	.2835	.2454	.2629
16		.3366	.2658	.2481	.3189	.2804	.298
17	.3544	.3721	.2835	.3366	.3189	.3155	.333
18	.4784	.4961	.4252	.4252	.4607	.4382	.4908
19	.443	.4607	.3898	.3721	.443	.4207	.4733
20	.443	.4252	.3721	.3366	.3721	.3856	.3681
21	.3366	.4075	.3189	.3012	.3366	.3681	.333
22	.3189	.3544	.2658	.2658	.3189	.3506	.3155
23	.3012	.3189	.2481	.2303	.2835	.2454	.2804
24	.2126	.3189	.3366	.2481	.1949	.2804	.2454
Max	.4784	.4961	.4252	.4252	.4607	.4382	.4908
Min	.1949	.2481	.2481	.2303	.1595	.2103	.2279
Avg	.2973	.3448	.3093	.2953	.2997	.2856	.3082

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064006 / ADYAL SUB STATION****Feeder No / Name : 203 / 11 KV Nerala Feeder****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0724	.1267	.0709	.0886	.0537	.1267
2	.1086	.0724	.1267	.0709	.0709	.0537	.1086
3	.0905	.0724	.1267	.0709	.0709	.0537	.1086
4	.1086		.1267	.0709	.0886	.0537	.1086
5	.1267	.0543	.1267	.0709	.1063	.0537	.1086
6	.1448	.1086	.1448	.1417	.0886	.1075	.0905
7	.1086	.181	.1448	.1772	.1595	.1254	.1448
8	.0905	.1991	.1448	.1772	.1595	.1433	.1629
9	.1448	.1991	.1629	.1772	.0886	.1433	.1629
10	.181	.181	.1448	.0886	.1595	.1254	.1448
11	.1629	.1086	.1448	.1417	.1772	.1254	.1448
12	.1267	.1629	.1448	.1063	.1772	.1254	.1267
13	.1448	.1448	.1448	.1417	.124	.1254	.1267
14		.1448	.1448	.3189	.1063	.1254	.1075
15		.1448	.1448	.1595	.1063	.1075	.1612
16	.1086	.1629	.1629	.124	.1063	.1254	.1075
17	.1267	.1991	.1267	.1772	.124	.1433	.1075
18	.1629	.2172	.1753	.2126	.1772	.1612	.1791
19	.1629	.1991	.1578	.1949	.1772	.1612	.1433
20	.1629	.1991	.1578	.1595	.1595	.1612	.1433
21	.1267	.181	.1578	.1063	.124	.1433	.1254
22	.0905	.1448	.1227	.124	.0895	.1075	.1075
23	.0724	.1267	.0876	.1063	.0716	.0895	.1075
24	.1086	.0724	.1267	.0886	.0886	.0716	.1267
Max	.181	.2172	.1753	.3189	.1772	.1612	.1791
Min	.0724	.0543	.0876	.0709	.0709	.0537	.0905
Avg	.1259	.1456	.1406	.1366	.1204	.1119	.1284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064006 / ADYAL SUB STATION****Feeder No / Name : 204 / 11 KV KABARA FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.144	.144	.144	.144	.144	.128
2	.144	.144	.144	.144	.16	.144	.128
3	.16	.144	.144	.144	.16	.144	.112
4	.192	.144	.144	.144	.144	.144	.096
5	.208	.16	.144	.144	.16	.192	.096
6	.208	.16	.16	.144	.176	.16	.096
7	.16	.208	.192	.192	.144	.112	.096
8	.192	.208	.16	.176	.176	.112	.096
9	.112	.112	.144	.112	.16	.112	.064
10	.2241	.2721	.192	.144	.176	.128	.144
11	.208	.176	.176	.16	.2561	.128	.128
12	.192	.176	.144	.192	.144	.112	.128
13	.176	.096	.2401	.144	.2241	.112	.144
14		.112	.112	.128	.112	.112	.144
15		.144	.144	.2401	.192	.112	.144
16	.176	.2241	.2401	.2401	.2561	.112	.112
17	.2881	.144	.176	.1612	.16	.112	.112
18	.16	.192	.3041	.112	.16	.112	.112
19	.176	.16	.176	.1791	.16	.096	.128
20	.128	.144	.128	.1433	.16	.096	.128
21	.144	.144	.144	.1612	.16	.112	.144
22	.1629	.144	.144	.16	.16	.128	.144
23	.144	.144	.1526	.144	.16	.128	.144
24	.144	.144	.144	.144	.144	.144	.144
Max	.2881	.2721	.3041	.2401	.2561	.192	.144
Min	.112	.096	.112	.112	.112	.096	.064
Avg	.1747	.1600	.1664	.1582	.1687	.1253	.1213

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064006 / ADYAL SUB STATION****Feeder No / Name : 205 / 11 kv GOSE(Adyal) FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.032	.0373	.0373	.0373	.0373
2	.0373	.0373	.032	.0373	.0373	.0373	.0373
3	.0373	.0373	.032	.0373	.0373	.0373	.0373
4	.0373	.0373	.0373	.0373	.0373	.0373	.0373
5	.0373	.0373	.0373	.0373	.0373	.0373	.0373
6	.0373	.0373	.0373	.0373	.056	.0373	.056
7	.0373	.0373	.0373	.0373	.0373	.0373	.0373
8	.0373	.0373	.032	.0373	.0373	.0373	.0373
9	.0373	.056	.032	.0373	.0373	.0373	.0747
10	.0373	.056	.0747	.0373	.0373	.0747	.056
11	.0373	.0373	.0373	.0373	.0373	.056	.056
12	.0373		.0373	.0373	.0373	.056	.056
13	.0373		.0373	.0373	.0373	.056	.0373
14			.0373	.0373	.0373	.0373	.056
15			.0373	.0373	.0373	.056	.056
16	.0373	.0373	.0373	.0373	.0373	.056	.0373
17	.0373	.0373	.0373		.0373	.056	.056
18	.0747	.0747	.0747	.0747	.0747	.112	.056
19	.0747	.0747	.0747	.0747	.0747	.112	.0747
20	.0747	.0747	.0747	.056	.0747	.112	.0747
21	.056	.056	.056	.0747	.056	.0934	.056
22	.056	.0373	.056	.0373	.0373	.0747	.056
23	.0373	.0373	.0373	.0373	.0373	.0373	.0373
24	.0373	.0373	.0373	.0373	.0373	.0373	.056
Max	.0747	.0747	.0747	.0747	.0747	.112	.0747
Min	.0373	.0373	.032	.0373	.0373	.0373	.0373
Avg	.0441	.0457	.0440	.0430	.0435	.0568	.0505

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064006 / ADYAL SUB STATION

Feeder No / Name : 207 / 11 KV ASHOK NAGAR FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1886	.2229	.2058
2					.1715	.2229	.2058
3					.1715	.2058	.2058
4					.1715	.2058	.2229
5					.1886	.2229	.2229
6					.2229	.2401	.2401
8	.1886	.3258	.3944	.2743			
9	.2572	.3429	.4287	.3429			
10	.3086	.3772	.4287	.2572			
11	.3601	.3944	.4115	.3258			
12	.3601	.3944	.4115	.2915			
13	.3772		.4115	.3429			
14			.3944	.3174			
15			.3601	.2915			
23					.2229	.1715	.1886
24	.1543					.0373	.2058
Max	.3772	.3944	.4287	.3429	.2229	.2401	.2401
Min	.1543	.3258	.3601	.2572	.1715	.0373	.1886
Avg	.2866	.3669	.4051	.3054	.1911	.1912	.2122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 201 / 11 KV PAUNI-I Feeder****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2772	.2402	.2587	.2218	.2402	.2402
2	.2402	.2587	.2587	.2402	.2402	.2402	.2402
3	.2402	.2328	.2587	.2218	.2402	.2402	.2218
4	.2587	.2587	.2772	.2587	.2587	.2402	.2218
5	.2772	.2772	.2772	.2772	.2772	.2402	.2402
6	.2957	.2957	.2772	.2957	.2772	.2772	.2772
7	.3511	.3326	.3326	.3696	.3511	.3696	.3696
8	.3881	.3696	.3881	.4066	.3881	.3696	.3881
9	.3658	.3696	.3696	.3511	.3696	.3511	.3696
10	.3326	.4251	.3881	.3881	.3881	.3696	.3881
11	.3142	.3881	.3881	.3511	.3696	.3696	.3696
12	.3142	.3511	.499	.1109	.3696	.2957	.3142
13	.3326	.3142	.4805	.1294	.3511	.3326	.2957
14	.2957	.3326	.2033	.3511	.2957	.2772	.3142
15	.2218	.3326	.3142	.2957	.2957	.2402	.3326
16	.2218	.3881	.462	.3326	.3326	.4066	.3511
17	.2957	.4066	.2957	.3142	.3142	.3696	.3142
18	.462	.5544	.499	.462	.4435	.499	.5544
19	.4805	.4805	.462	.462	.462	.4805	.4805
20	.5914	.462	.4435	.4805	.462	.462	.462
21	.4251	.4251	.4066	.4435	.4066	.4066	.4435
22	.3326	.3511	.3326	.3326	.3142	.2957	.3326
23	.2957	.2957	.2772	.2957	.2772	.2772	.2772
24	.2402	.2772	.2587	.2743	.2402	.2402	.2218
Max	.5914	.5544	.499	.4805	.462	.499	.5544
Min	.2218	.2328	.2033	.1109	.2218	.2402	.2218
Avg	.3263	.3524	.3496	.3210	.3311	.3288	.3342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 202 / 11 KV Sawarla Feeder****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.2126	.2263	.1772	.2126	.2372	.2126
2	.1772	.2126	.2263	.1772	.2126	.2372	.2126
3	.1772	.2126	.2126	.2126	.2126	.2372	.2126
4	.1772	.2481	.2126	.2481	.2126	.2214	.2126
5	.2658	.2835	.2126	.3012	.2126	.2481	.2126
6	.3189	.3189	.2126	.3544	.2126	.2835	.2126
7	.2658	.2481	.2126	.443	.2126	.2835	.2126
8	.443	.3898	.3544	.5316	.2126	.2126	.2126
9	.7087	.7087	.6201	.443	.2126	.2126	.2126
10	.7442	.7087	.691	.5316	.2126	.2126	.2126
11	.7087	.7087	.6556	.443		.2126	.1772
12	.7442	.7087	.6733	.5316			.1772
13	.7265	.7087	.6733	.6733		.2126	.1772
14	.7087	.7087	.6201	.5316		.2126	.1772
15	.6556	.1772	.6733	.3544		.2126	.1772
16	.2126	.1772	.2126	.2126		.1772	.1772
17	.2126	.2126	.2126	.2012		.1772	.1772
18	.2481	.7087	.7087	.7442		.7087	.7087
19	.8505	.8505	.8505	.7442		.7973	.7973
20	.7973	.7973	.7442	.7973	.7442	.5316	.7973
21	.6201	.6201	.6201	.5316	.4961	.2658	.6201
22	.2835	.3189	.2658	.2126	.2658	.2126	.2658
23	.2126	.1772	.2126	.2126	.2658	.2126	.1772
24	.1772	.2126	.2263	.1772	.1772	.2658	.2126
Max	.8505	.8505	.8505	.7973	.7442	.7973	.7973
Min	.1772	.1772	.2126	.1772	.1772	.1772	.1772
Avg	.4422	.4429	.4388	.4078	.2717	.2863	.2894

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 203 / 11 KV Amgaon Feeder****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5658	.5487	.5316	1.3889	1.4403	1.2003
2	.5144	.5487	.6173	.5144	1.406	1.4575	1.286
3	.4801	.5316	.6173	.5144	1.4403	1.4232	1.286
4	.5144	.6001	.6859	.6001	1.4403	1.4575	1.3375
5	.6001	.6859	.6859	.6859	1.4575	1.4746	1.3889
6	.7373	.7716	.7545	.7716	1.4746	1.5432	1.4575
7	.583	.6516	.6001	.5658	.5658	.6001	.6687
8	1.5089	1.8347	1.7661	1.6289	.5144	.583	.5316
9	1.869	1.9547	1.8347	1.869	.5144	.583	.5316
10	1.749	1.9204	1.9033	2.0405	.4801	.4458	.4801
11	1.8176	1.8861	1.989	1.9376	.4801	.463	.4458
12	1.7833	1.869	1.9719	1.9033	.4801	.4458	.3429
13	1.8004	1.9033	1.989	1.9204	.4115	.3601	.3258
14	1.8004	1.869	1.9547	1.8861	.4115	.3429	.3429
15	1.7833	1.8519	1.8004	1.8004	.3944	.3429	.3429
16	.3944	.463	.3429	.3601	.4287	.4287	.4287
17	.463	.463	.463	.4801	.4287	.4458	.5144
18	1.0974	1.0288	1.0631	1.0288	1.0631	1.0117	1.1145
19	1.2346	1.166	1.166	1.0288	1.1145	1.0974	1.2003
20	1.0974	1.1317	1.046	1.0802	1.046	.9431	1.1317
21	.9431	.8573	.8745	.8573	.6859	.8402	.8916
22	.7202	.6687	.6687	.6516	.6173	.4287	.6516
23	.5487	.6001	.5658	.6344	1.4575	1.3032	1.166
24	.5487	.5316	.5487	.5316	1.3375	1.3717	1.166
Max	1.869	1.9547	1.989	2.0405	1.4746	1.5432	1.4575
Min	.3944	.463	.3429	.3601	.3944	.3429	.3258
Avg	1.0453	1.0981	1.1024	1.0760	.8766	.8681	.8431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 204 / 11 KV KHAPRI(REHAPADE)****SINGLE PHASING****Feeder Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1581	.1581	.1886	.1581	.1581	.1581	.1581
2	.1581	.1581	.1886	.1581	.1715	.1581	.1581
3	.1581	.1581	.1581	.1581	.1581	.1581	.1581
4	.1581	.1581	.1581	.1581	.1581	.1581	.1581
5	.1581	.1581	.1581	.1581	.1581	.1581	.1581
6	.1581	.1581	.1581	.1581	.1581	.1581	.1581
7	.1581	.1581	.1581	.1581	.1581	.1581	
8	.1898	.253	.1581	.1581	.1581	.1581	.1581
9	.2372	.253	.3163	.3163	.1581	.1581	.1581
10	.1581	.2846	.4744	.2214	.1581	.1581	.1581
11	.1581	.3163	.4744	.2214	.1581	.1581	.1581
12	.1581	.3163	.4744	.2214	.1581	.1581	.1581
13	.2372	.3163	.4744	.2214	.1581	.1581	.1581
14	.2846	.3163	.4744	.2214	.1581	.1581	.1581
15	.2846	.3163	.4744	.2214	.1581	.1581	.1581
16	.1581	.1581	.1581		.1581	.1581	.1581
17	.16	.1581	.1581	.1581	.1581	.1581	.1581
18	.16	.1581	.1581	.1581	.1581	.1581	.1581
19	.1581	.1581	.1581	.1581	.1581	.1581	.1581
20	.1581	.1581	.1581	.1581	.1898	.1581	.1581
21	.1581	.1581	.1581	.1581	.1581	.1581	.1581
22	.1581	.1581	.1581	.1581	.1581	.1581	.1581
23	.1581	.1581	.1581	.1581	.1898	.1581	.1581
24	.1581	.1581	.1886	.1581	.1734	.1581	.1581
Max	.2846	.3163	.4744	.3163	.1898	.1581	.1581
Min	.1581	.1581	.1581	.1581	.1581	.1581	.1581
Avg	.1767	.2042	.2476	.1815	.1619	.1581	.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 205 / 11 kv Pauni - II FEEDER****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3292	.3475	.3475	.3292	.3109	.3658
2	.3658	.3109	.3475	.3292	.3475	.3109	.3658
3	.3658	.2926	.3658	.3109	.3658	.3109	.3475
4	.3841	.3292	.3658	.3658	.3841	.2926	.3475
5	.4207	.3475	.3841	.4024	.4207	.2926	.3292
6	.439	.3841	.3841	.4207	.439	.3658	.4207
7	.4024	.4024	.3841	.4024	.4572	.4024	.439
8	.4207	.4207	.4572	.3841	.4572	.3841	.3658
9	.439	.4207	.439	.3292	.4572	.4207	.4572
10	.4024	.4024	.3475	.4024	.567	.3658	.4207
11	.439	.3841	.4207	.4207	.3841	.3658	.4572
12	.3841	.4024	.4024	.4024	.3841	.4024	.4755
13	.3841	.4572	.4755	.4207		.4572	.3109
14	.3658	.4207	.3475	.4572	.3292	.4572	.3696
15	.3658	.3475	.4024	.3841	.3658	.439	.4251
16	.4024	.4207	.3475	.4207	.3841	.4938	.499
17	.4572	.4755	.4207	.3841		.5487	.5544
18	.6219	.6036	.5487	.5853	.5853	.7133	.6838
19	.567	.567	.5487	.5487	.6219	.5853	.6219
20	.6036	.4938	.4938	.4755	.5304	.4755	.5304
21	.4755	.439	.4755	.439	.439	.4024	.4755
22	.4024	.3841	.3841	.4572	.4024	.3841	.3475
23	.3658	.3109	.3658	.3475	.3109	.4024	.3109
24	.3475	.3326	.3658	.3511	.3841	.3109	.3658
Max	.6219	.6036	.5487	.5853	.6219	.7133	.6838
Min	.3475	.2926	.3475	.3109	.3109	.2926	.3109
Avg	.4245	.4033	.4092	.4079	.4248	.4123	.4286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064013 / 33 KV PAONI S/STN

Feeder No / Name : 206 / 11 KV SVK MILK PLANT

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0943	.132	.1132	.1132	.1132	.1132
2	.1132	.0943	.1132	.0943	.0943	.1132	.1132
3	.0943	.0943	.1132	.0943	.0943	.1132	.0943
4	.0754	.0732	.1132	.0943	.0943	.0943	.0943
5	.0754	.0754	.1132	.0732	.0754	.0754	.0754
6	.0566	.0754	.0754	.0754	.0754	.0754	.0732
7	.0943	.0943	.0754	.0754	.0754	.0754	.0943
8	.1132	.0943	.0754		.0754	.0943	.1132
9	.0566	.0943	.1132	.0943	.0943	.132	.132
10	.1509	.1509	.1698	.132	.1132	.132	.1698
11	.2075	.1698	.1509	.1886	.1698	.1698	.1509
12	.2075	.1509	.1509	.1698	.1886	.1698	.1698
13	.1886	.1509	.1509	.1698	.1509	.1509	.1509
14	.1698	.1509	.132	.1509	.1698	.1509	.132
15	.1886	.1698	.1509	.1509	.1698	.1509	.132
16	.1698	.1509	.1509	.1509	.1509	.132	.1509
17	.1509	.1509	.1509	.1509	.132	.1509	.1698
18	.1509	.132	.132	.132	.132	.132	.132
19	.132	.1132	.132	.1132	.132	.1132	.132
20	.132	.1132	.1132	.0754	.132	.132	.132
21	.1132	.1132	.1132	.1132	.0943	.132	.132
22	.1132	.1132	.1132	.1509	.132	.132	.132
23	.132	.132	.132	.132	.132	.132	.132
24	.1132	.1132	.1132	.1132	.1132	.1132	.1132
Max	.2075	.1698	.1698	.1886	.1886	.1698	.1698
Min	.0566	.0732	.0754	.0732	.0754	.0754	.0732
Avg	.1297	.1194	.1242	.1221	.1210	.1242	.1264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064013 / 33 KV PAONI S/STN****Feeder No / Name : 207 / 11 KV SHINDHPURI AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3961	.3734	.3772
2						.3734	.3772
3						.3734	.3772
4						.3547	.3772
5						.3547	.3772
6						.3547	.3772
8	.5228	.7545	.679	.6348			
9	.7733	.9431	.9242	.7922			
10	.8962	.9808	.9619	.8488			
11	.8775	.9997	1.0185	.811			
12	.9709	.9808	1.0349	.7922			
13	.8962	.9808	.9425	.9242			
14	.9149	.9808	.8871	.8488			
15	.8962	.9431	.8871	.6979			
23						.3772	.3547
24					.3772	.3734	.3772
Max	.9709	.9997	1.0349	.9242	.3961	.3772	.3772
Min	.5228	.7545	.679	.6348	.3772	.3547	.3547
Avg	.8435	.9455	.9169	.7937	.3867	.3669	.3744

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064016 / 33 KV PAHELA S/STN****Feeder No / Name : 201 / 11 KV PAHELA-GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1646	.1463	.1372	.1372	.12	.1463
2	.1715	.1646	.1463		.1543	.12	.1463
3	.1543	.1463	.1463	.1372		.12	.1463
4	.1715	.128	.128	.1372	.1715	.1372	.128
5	.1715	.128	.128	.1543	.1715	.1543	.128
6	.1715	.1463	.1463	.1715	.1715	.1715	.1829
7	.1715	.1463	.1646	.1886	.1372	.1715	.1829
8	.1715	.2012	.1829	.1715	.1886	.1543	.1646
9	.2058	.2012	.2195	.1886	.2058	.1886	
10	.2561	.2926	.2915	.2058	.2401	.2561	.2915
11	.3292	.2561	.2915	.2058	.2572	.2195	.2915
12	.2561	.2743	.2915	.2572	.1715	.2378	.2915
13		.2012	.2572	.2572	.2058	.3109	.2401
14	.2195	.2012	.2915	.1886	.2058	.2561	.2743
15	.1829	.2195	.2058	.2572	.2058	.2195	.2572
16	.3292	.2378	.2058	.2572	.2401	.2195	.1886
17	.2561	.2743	.1715	.2572	.2058	.2195	.2572
18	.3292	.2926	.2401	.3429	.2743	.3109	.3086
19	.2926	.3292	.2401	.2743	.2401	.2926	.3086
20	.2926	.3292	.2229	.2743	.2058	.2561	.2572
21	.2561	.1646	.2058	.1886	.1715	.1646	.2058
22	.2012	.1646	.1715	.1543	.1372	.1646	.1715
23	.1829	.1646	.1372	.1372	.12	.1463	.1543
24	.1543	.1646	.1463	.1372	.1372	.12	.1463
Max	.3292	.3292	.2915	.3429	.2743	.3109	.3086
Min	.1543	.128	.128	.1372	.12	.12	.128
Avg	.2224	.2080	.1991	.2035	.1894	.1971	.2117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064016 / 33 KV PAHELA S/STN****Feeder No / Name : 202 / 11 KV Wakeshwar Gaothan
feeder Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1097	.128	.12	.12	.1029	.1097
2	.1543	.128	.128	.12	.1372	.1029	.128
3	.1543	.128	.128	.12	.1372	.1029	.128
4	.1543	.128	.128	.1372	.1543	.1029	.128
5	.1543	.1463	.128	.1715	.1715	.1029	.128
6	.1886	.1646	.128	.1886	.2058	.1029	.2012
7	.1886	.1829	.1463	.1886	.1886	.2058	.2743
8	.1886	.2012	.2012	.1886	.1886	.1715	.2012
9	.2058	.2012	.2012	.1715	.2058	.1886	
10	.2378	.2561	.1715	.1886	.1886	.1646	.1886
11	.2926	.1646	.2058	.1886	.1715	.2378	.1715
12	.2012	.2195	.2058	.2058	.1715	.2926	.1543
13		.2195	.1886	.2229	.2058	.1829	.1715
14	.1829	.2012	.1886	.1715	.2058	.1829	.3086
15	.2195	.2743	.1372	.2229	.2743	.2743	.2401
16	.2012	.2012	.1372	.2572	.2572	.2378	.1715
17	.2195	.2743	.1715	.2572	.1543	.3658	.2743
18	.2926	.3658	.2915	.3258	.2743	.4024	.3429
19	.2743	.3292	.2915	.2743	.2743	.3475	.3601
20	.2743	.2926	.2572	.2572	.2401	.2378	.3429
21	.2195	.2012	.2058	.1886	.1543	.1829	.2572
22	.2012	.1646	.1715	.1372	.12	.128	.1715
23	.128	.128	.12	.12	.1029	.1097	.1029
24	.1029	.1097	.128	.12	.12	.1029	.1097
Max	.2926	.3658	.2915	.3258	.2743	.4024	.3601
Min	.1029	.1097	.12	.12	.1029	.1029	.1029
Avg	.1981	.1997	.1745	.1893	.1843	.1931	.2029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064016 / 33 KV PAHELA S/STN****Feeder No / Name : 203 / 11 kv Nimgaon Feeder****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1006	.1174	.0857	.0514	.0686	.0671
2	.0857	.0838	.1174	.0686	.0514	.0686	.0671
3	.1029	.0838	.1006	.0686	.0686	.0686	.0671
4	.1029	.0671	.1006	.0686	.0686	.0686	.0671
5	.0857	.0671	.1006	.0686	.0686	.0686	.0671
6	.0857	.0671	.1174	.0857	.0686	.0686	.0671
7	.0857	.0671	.1174	.0857	.0686	.0686	.0838
8	.0857	.0838	.1341	.0857	.12	.0857	.1006
9	.1029	.1006	.1341	.0857	.1029	.1029	
10	.1006	.1174	.1715	.12	.12	.1006	.1029
11	.1341	.1174	.1543	.12	.1372	.128	.1029
12	.0838	.1341	.1543	.12	.0857	.1341	.12
13		.1509	.1543	.1372	.1372	.1174	.12
14	.1006	.1341	.1543	.1372	.1372	.1341	.12
15	.0838	.1509	.1372	.0857	.1372	.1174	.12
16	.1006	.1006	.12	.1372	.1029	.0671	.12
17	.1006	.0838	.1029	.1372	.1715	.0838	.1029
18	.1341	.1006	.1029	.1372	.1029	.1006	.1029
19	.1341	.1509	.1029	.1029	.1029	.1006	.12
20	.1341	.1341	.1029	.1029	.0857	.1006	.1029
21	.1006	.1341	.1029	.0857	.0857	.0838	.0857
22	.0838	.1174	.0857	.0686	.0686	.0671	.0686
23	.1006	.1006	.0857	.0686	.0686	.0671	.0686
24	.0857	.1006	.1174	.0857	.0514	.0686	.0671
Max	.1341	.1509	.1715	.1372	.1715	.1341	.12
Min	.0838	.0671	.0857	.0686	.0514	.0671	.0671
Avg	.1	.1062	.1204	.0979	.0943	.0892	.0918

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064016 / 33 KV PAHELA S/STN****Feeder No / Name : 204 / 11 kv WAKESHWAR-AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2401	.2058	.1802
2					.2401	.2058	.1802
3						.2058	.1966
4					.2401	.2058	.1966
5					.2572	.2058	.1966
6					.2401	.2058	.213
8	.2229	.2785	.2949	.2401			
9	.2915	.2785	.3441	.3086			
10	.2949	.3277	.3601	.3429			
11	.3113	.3277	.3258	.3258			
12	.3113	.3441	.2915	.3772			
13		.3441	.3258	.3086			
14	.3441	.3441	.3258	.3601			
15	.3605	.3277	.3086	.3258			
23					.1886	.1802	.0343
24	.12				.2572	.2058	.1638
Max	.3605	.3441	.3601	.3772	.2572	.2058	.213
Min	.12	.2785	.2915	.2401	.1886	.1802	.0343
Avg	.2821	.3216	.3221	.3236	.2376	.2026	.1702

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064016 / 33 KV PAHELA S/STN

Feeder No / Name : 205 / 11 KV PAHELA-AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0343	.0686	.048
2					.0343		.048
3					.0343	.0686	.048
4					.0343	.0686	.048
5					.0343	.0686	.048
6					.0343	.0686	.048
8	.0514	.08	.08	.0686			
9	.0686	.096	.08	.0857			
10	.08	.0819	.1029	.0857			
11	.08	.08	.1029	.1029			
12	.08	.08	.1029	.0857			
13		.08	.1029	.0857			
14	.08	.08	.1029	.0686			
15	.096	.08	.0857	.0686			
23					.0514	.048	.0514
24	.0343					.0686	.048
Max	.096	.096	.1029	.1029	.0514	.0686	.0514
Min	.0343	.08	.08	.0686	.0343	.048	.048
Avg	.0713	.0822	.0950	.0814	.0367	.0657	.0484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064016 / 33 KV PAHELA S/STN****Feeder No / Name : 401 / 33 KV Adyal feeder INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.439	.4938	.3086	.823	.6173	.5487
2	.463	.439	.4938	.3086	.9774	.6173	.5487
3	.463	.3841	.439	.3601	.8745	.6173	.5898
4	.5144	.3841	.439	.3601	.9259	.6687	.6584
5	.5658	.439	.5487	.3601	.9259	.7202	.6036
6	.5144	.6584	.6584	.5144	.9259	.7716	.7133
7	.5658	.7682	.7682	.7716	.5144	.7202	.7133
8	.8745	1.1523	.9877	.9259	.7202	.5144	.5487
9	.7716	1.0425	1.0425	.9774	.6173	.5144	
10	.7682	1.3169	1.1317	.6687	.5658	.6036	.6687
11	.7133	1.2071	.8745	.9259	.7716	.5487	.5658
12	.7682	.9877	.8745	.9774	.7202	.5487	.5144
13	1.0425	.7682	1.0802	.7716	.6173	.439	.5144
14	.439	.6036	.7716	.6173	.5144	.439	.463
15	.3841	.7682	.9259	.9774	.5658	.3841	.4115
16	.2743	.6584	.6173	.6687	.6687	.4938	.463
17	.7682	.7133	.463	.7202	.4115	.4938	.5144
18	.7682	.8779	.9259	.7716	.5658	.823	.7716
19	.823	.9877	.6687	.7716	.6687	.7682	.7202
20	.7133	.7133		.5658	.6173	.7133	.6173
21	.5487	.6036	.5144	.463	.463	.4938	.5144
22	.4938	.4938	.4115	.4115	.3601	.439	.463
23	.439	.4938	.3086	.3601	.5144	.5487	.5658
24	.4115	.3841	.4938	.3086	.3086	.6173	.4938
Max	1.0425	1.3169	1.1317	.9774	.9774	.823	.7716
Min	.2743	.3841	.3086	.3086	.3086	.3841	.4115
Avg	.6063	.7202	.6927	.6194	.6516	.5881	.5733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 201 / 11 KV MANGLI FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2012	.2	.161
2					.2012	.2	.161
3					.2073	.2	.161
4					.2073	.2	.161
5					.2073	.2	.176
6					.2401	.2401	.2134
8	.4923	.6327	.6401	.5944			
9	.602	.8905	.7164	.8124			
10	.787	.9602	.7621	.8333			
11	.8592	.9922	.8592	.8436			
12	.8539	.9282	.8436	.7811			
13	.7977	.9442	.9374	.7316			
14	.8128	.8802	.8951	.6859			
15	.7225	.8322	.7773	.5719			
23					.1867	.144	.1349
24	.1124					.2	.1486
Max	.8592	.9922	.9374	.8436	.2401	.2401	.2134
Min	.1124	.6327	.6401	.5719	.1867	.144	.1349
Avg	.6711	.8826	.8039	.7318	.2073	.1980	.1646

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 202 / 11 KV DHAMNI- AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1326	.1027	.0777
2					.1189	.1027	.0777
3					.1189	.1027	.0777
4					.1189	.1174	.0777
5					.1189	.1174	.0777
6					.1486	.1174	.0934
8	.2317	.2526	.2675	.2526			
9	.3269	.3418	.3374	.3121			
10	.3715	.4012	.3668	.3715			
11	.3864	.3418	.431	.3269			
12	.381	.4012	.3715	.3121			
13	.381	.4458	.3269	.301			
14	.3506	.3269	.3418	.2896			
15	.3201	.3567	.3121	.3018			
23					.0743	.0732	.0648
24	.0869					.1027	.0777
Max	.3864	.4458	.431	.3715	.1486	.1174	.0934
Min	.0869	.2526	.2675	.2526	.0743	.0732	.0648
Avg	.3151	.3585	.3444	.3085	.1187	.1045	.0781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 203 / 11 Kv Dholsar Feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0282	.0423	.0259
2					.0282	.0423	.0259
3					.0282	.0423	.0259
4					.0282	.0423	.0259
5					.0282	.0282	.0259
6					.0423	.0423	.04
8	.1143	.104	.1189	.1143			
9	.1286	.1486	.1907	.1467			
10	.208	.1635	.1214	.176			
11	.1932	.1635	.1981	.1467			
12	.1486	.1337	.1981	.1656			
13	.1932	.1189	.1677	.1829			
14	.1635	.1486	.1932	.1524			
15	.1635	.1635	.1932	.1372			
23					.0282	.0259	.0248
24	.0457					.0282	.0259
Max	.208	.1635	.1981	.1829	.0423	.0423	.04
Min	.0457	.104	.1189	.1143	.0282	.0259	.0248
Avg	.1510	.1430	.1727	.1527	.0302	.0367	.0275

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 204 / 11 KV ASGAON GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1949	.1753	.1791	.1791	.1772	.1791	.1595
2	.1949	.1753	.1791	.1791	.1772	.1791	.1595
3	.1949	.1791	.1791	.1793	.1772	.1791	.1595
4	.1772	.1791	.1791	.1791	.1772	.197	.1791
5	.2126	.2353	.2149	.197	.2172	.2149	.1991
6	.3045	.2715	.2507	.2896	.2957	.2507	.2772
7	.3142	.2896	.2896	.3109	.3012	.2865	.2896
8	.2896	.2926	.2896	.2926	.2865	.2658	.2172
9	.2865	.2926	.3258	.3109	.3224	.2835	.2353
10	.2353	.2865	.3982	.3292	.2865	.2481	.2507
11	.181	.2686	.3403	.3292	.2865	.2303	.3258
12	.181	.3045	.3292	.3012	.3045	.2658	.3439
13	.181	.2865	.2172	.2279	.2865	.2481	.3258
14	.181	.2865	.2534	.2454	.2686	.208	.3258
15	.1578	.2507	.3258	.2454	.2686	.2743	.3077
16	.1629	.2686	.333	.2957	.1791	.2629	.3077
17	.2035	.3224	.3841	.2835	.2507	.2543	.2915
18	.3696	.4477	.5121	.4668	.394	.3982	.462
19	.3696	.4119	.4435	.4668	.394	.3658	.4481
20	.3326	.3224	.3511	.3142	.2865	.3326	.4108
21	.2715	.2686	.2614	.2561	.2507	.2743	.2378
22	.2126	.197	.2402	.2103	.1791	.2149	.197
23	.197	.197	.1791	.1928	.1791	.2149	.1753
24	.2103	.1928	.197	.1791	.1772	.1791	.1595
Max	.3696	.4477	.5121	.4668	.394	.3982	.462
Min	.1578	.1753	.1791	.1791	.1772	.1791	.1595
Avg	.234	.2668	.2855	.2692	.2551	.2503	.2686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 205 / 11 KV KHAIRY-AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1219	.0743	.08
2					.1219	.0743	.08
3					.1372	.0743	.08
4					.1372	.0743	.08
5					.1524	.0743	.0934
6					.1981	.1189	.1097
8	.3155	.3418	.4012	.3567			
9	.431	.4458	.4904	.4515			
10	.5182	.4755	.5201	.503			
11	.4877	.4755	.5639	.4572			
12	.4938	.4904	.5487	.4725			
13	.5093	.4904	.5487	.463			
14	.5093	.4458	.5487	.4374			
15	.463	.4458	.4725	.3749			
23					.0762	.0667	.0686
24	.0914					.0743	.08
Max	.5182	.4904	.5639	.503	.1981	.1189	.1097
Min	.0914	.3418	.4012	.3567	.0762	.0667	.0686
Avg	.4244	.4514	.5118	.4395	.1350	.0789	.0840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 207 / 11 KV ASGAON AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4239	.4458	.4458	.3944			
2	.4409	.4458	.463	.3944			
3	.4409	.463	.463	.3944			
4	.4578	.463	.463	.3944			
5	.5087	.4973	.4801	.3944			
6	.5256	.5316	.5316	.463			
8					.7545	.9214	.7202
9					1.0288	1.1871	.8745
10					1.2174	1.5061	.8916
11					1.2346	1.2003	1.2209
12					1.1488	1.1831	1.1831
13					1.1488	1.1317	1.1145
14					1.0974	.5658	1.1145
15					1.0974	.6516	1.0802
23	.407	.4115	.3601	.3772			
24		.4458	.4115	.3944	.3944		
Max	.5256	.5316	.5316	.463	1.2346	1.5061	1.2209
Min	.407	.4115	.3601	.3772	.3944	.5658	.7202
Avg	.4578	.4630	.4523	.4008	1.0136	1.0434	1.0249

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064028 / 33/11 kv ASGAON S/ST****Feeder No / Name : 208 / 11 KV DHAMNI - G feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1294	.1478	.1307	.1109	.1478	.1109
2	.1294	.1294	.1478	.1294	.1294	.1478	.1109
3	.1294	.1294	.1478	.1294	.1294	.1478	.1109
4	.1478	.1294	.1478	.1294	.1294	.1478	.1294
5	.1848	.1663	.2033	.1848	.1294	.1478	.1663
6	.2218	.2402	.2218	.2772	.2402	.2218	.2218
7	.2427	.2218	.2402	.2218	.2033	.1848	.2218
8	.2241	.2218	.2033	.2033	.2033	.2033	.2218
9	.2402	.2957	.2587	.2218	.2218	.2033	.2033
10	.2033	.2218	.1848	.1848	.1663	.1848	.2402
11	.1663	.1478	.1663	.1848	.2587	.1848	.1663
12	.1478	.1294	.1848	.1848	.2218	.1294	.2033
13	.1294	.1109	.1478	.1848		.1109	.1478
14	.0924	.1478	.0914	.1848	.0924	.1294	.1494
15	.1478	.1478	.0914	.1663	.1848	.1109	.1097
16	.1478	.1848	.1612	.2033	.1478	.1294	.1663
17	.1663	.2033	.1646	.2402	.2772	.1663	.3174
18	.3142	.3881	.3174	.3856	.4066	.3511	.3921
19	.3142	.3696	.3174	.3511	.3326	.3511	.3395
20	.2587	.2772	.2801	.2804	.2587	.2957	.3018
21	.2033	.2033	.1867	.1848	.2402	.2033	.2427
22	.1478	.1663	.1478	.1478	.1294	.1663	.1478
23	.1478	.1478	.1478	.1294	.1478	.1109	.1294
24	.1478	.1294	.1478	.1294	.1294	.1478	.1109
Max	.3142	.3881	.3174	.3856	.4066	.3511	.3921
Min	.0924	.1109	.0914	.1294	.0924	.1109	.1097
Avg	.1827	.1933	.1857	.1988	.1953	.1802	.1942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

BHANDARA DIVSION[651]

PAONI S/DN.[386]

BU 0386

Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST

Feeder No / Name : 201 / 11 KV PAUNA KH -AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0914	.1067	.1067
2					.1132	.1067	.1067
3					.0914	.1067	.1067
4					.1067	.1219	.1067
5					.1372	.1219	.1067
6					.1524	.1219	.1219
8		.3353	.3418	.2743			
9	.4161	.4572	.4365	.3506			
10	.4725	.3963	.4572	.381			
11	.503	.3913	.442	.381			
12	.4877	.4666	.4725	.381			
13	.503	.4515	.4572	.3506			
14	.4572	.4572	.4115	.3506			
15	.442	.4115		.3201			
23					.0914		.061
24					.0914	.1067	.0914
Max	.503	.4666	.4725	.381	.1524	.1219	.1219
Min	.4161	.3353	.3418	.2743	.0914	.1067	.061
Avg	.4688	.4209	.4312	.3487	.1094	.1132	.1010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST****Feeder No / Name : 202 / 11 KV SHIVNALA-AG FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0457	.0457	.0305
2					.0457	.0457	.0305
3					.0457	.061	.0305
4					.0457	.061	.0305
5					.0457	.061	.0305
6					.0762		.0457
8	.1932	.1981	.1806	.1829			
9	.2675	.2591	.2559	.2439			
10	.2896	.2286	.2743	.2591			
11	.3048	.2258	.2896	.2439			
12	.2896	.2709	.2743	.1981			
13	.2743	.2559	.2896	.1981			
14	.2591	.2591		.1829			
15	.2439	.2439	.1524	.1524			
23					.0457		.0457
24					.0457	.0457	.0457
Max	.3048	.2709	.2896	.2591	.0762	.061	.0457
Min	.1932	.1981	.1524	.1524	.0457	.0457	.0305
Avg	.2653	.2427	.2452	.2077	.0495	.0534	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064035 / 33/11 KV WALNI S/ST****Feeder No / Name : 203 / 11 KV BHENDALA-GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2829	.3326	.2772	.2641	.2957	.2641
2	.2772	.2641	.3326	.2957	.2641	.2957	.2641
3	.2772	.3018	.3326	.2957	.2641	.3326	.2829
4	.2772	.3395	.3326	.3142	.2641	.3048	.3206
5	.3326	.3772	.3326	.3326	.3395	.3881	.3584
6	.3881	.3961	.3881	.3696	.3961	.4066	.3961
7	.4805	.4527	.3881	.3881	.4527	.462	.4338
8	.5544	.3772	.462	.499	.4805	.4066	.4904
9	.4805	.462	.4805	.5175	.5175	.4066	.4715
10	.462	.3881	.6283	.4251	.6413	.3881	.5359
11	.4066	.3881	.5544	.4805	.4251	.4251	.499
12	.415	.462	.4805	.3511	.4435	.4805	.4251
13	.3511	.499	.4066	.2957	.4066	.5093	.4251
14	.3206	.499	.3511	.2402	.3881	.5093	.3511
15	.3206	.499	.1663	.3018	.499	.4527	.3696
16	.2587	.499	.3511	.3395	.4066	.3584	.3696
17	.2829	.499	.3511	.4066	.5544	.3772	.4805
18	.5544	.6283	.5914	.499	.7392	.4805	.6468
19	.5281	.5175	.5175	.4527	.5544		.4805
20	.5093		.4066	.4715	.499	.3881	.4435
21	.3142	.3326	.3326	.3326	.3696	.3142	.3511
22	.3511	.2772	.3511	.3206	.3142	.3018	.3511
23	.3018	.2772	.3142	.3018	.2587	.2641	.2587
24	.2957	.2772		.2772	.2641	.2587	.2587
Max	.5544	.6283	.6283	.5175	.7392	.5093	.6468
Min	.2587	.2641	.1663	.2402	.2587	.2587	.2587
Avg	.3757	.4042	.3993	.3661	.4169	.3829	.3970

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064039 / 132 KV GOSE KH SUBSTATION****Feeder No / Name : 401 / 33 KV PAUNI FEEDER****Feeder KV- 33 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.5149	1.1431	1.1431	1.0082	2.7938	2.8235
Max	2.5149	1.1431	1.1431	1.0082	2.7938	2.8235
Min	2.5149	1.1431	1.1431	1.0082	2.7938	2.8235
Avg	2.5149	1.1431	1.1431	1.0082	2.7938	2.8235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 064039 / 132 KV GOSE KH SUBSTATION****Feeder No / Name : 701 / 132 kV Mahati Hydro
Express Fe Feeder KV- 132 /
OUTGOING****NON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING**

DATE	01-DEC-17
HR	Load (MW)
24	2.6886
Max	2.6886
Min	2.6886
Avg	2.6886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION****Feeder No / Name : 401 / 33 KV Lakhandur Feeder NON SHEDDABLE EXPRESS HV FEEDERS
INCOMER Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	.3961
Max	.3961
Min	.3961
Avg	.3961

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION****Feeder No / Name : 402 / 33 KV Gose feeder INCOMER****Feeder KV- 33 / INCOMING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	2.0959	1.0317	1.0208	2.4977	2.955	2.7149
2	1.0317	2.1554	1.0317	.9671	2.552	2.955	2.8235
3	.9774	1.9422	1.086	.9134	2.6063	2.955	2.7692
4	1.0317	1.9925	1.1403	1.0745	2.6606	2.9012	2.8235
5	1.1403	2.2176	1.1403	1.1283	2.7149	2.9012	2.8778
6	1.1946	2.4834	1.1403	1.2357	2.7149	3.1161	3.0407
7	1.1946	2.3319	1.1403	1.182	1.4661	1.182	1.2489
8	7.5606	4.1907	2.1719	3.8683	1.1946	1.182	1.1403
9	9.2918	4.7817	4.7239	4.2444	1.1946	1.2357	1.2489
10	8.9821	3.9095	5.0497	4.6696	1.3432	1.1403	1.4661
11	9.0936	3.8552	5.1578	4.4525	1.1283	1.1946	1.2357
12	9.4576	4.8868	5.3189	4.2353	1.1283	1.086	1.182
13	9.1478	4.9411	5.2652	4.561	.6447	1.2489	.9671
14	9.3987	4.8868	4.7279	4.561	.9134	1.1403	1.0208
15	9.1369	4.2353	4.7817	4.0181	1.0208	1.086	1.0745
16	2.0496	1.7375	1.182	1.1403	1.0745	1.3032	1.182
17	2.5263	1.3032	1.1283	1.1403	.6447	1.3032	1.2894
18	3.5979	1.9547	1.8267	1.8461	1.5581	1.9547	1.9879
19	4.0278	1.9004	1.8804	1.7918	1.6118	1.9004	1.9342
20	4.0815	1.7918	1.7193	1.7375	1.773	1.6289	1.773
21	3.3688	1.5203	1.4506	1.5203	1.3969	1.3575	1.6118
22	2.6646	1.2489	1.182	1.3032	1.182	1.086	1.182
23	2.3319	1.0317	1.0745	1.1403	3.0624	2.9321	.9671
24	.9774	2.2782	.9231	1.0208	2.8778	2.9012	2.6606
Max	9.4576	4.9411	5.3189	4.6696	3.0624	3.1161	3.0407
Min	.9774	1.0317	.9231	.9134	.6447	1.086	.9671
Avg	4.3874	2.7364	2.3864	2.2822	1.7067	1.8603	1.7592

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION****Feeder No / Name : 404 / 33 KV Kosara Feeder****NON SHEDDABLE EXPRESS HV FEEDERS****INCOMER Feeder KV- 33 /****(CONTINOUS PROCESS)(NO STAGGERING)****INCOMING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6221	1.7695	1.7695	1.5912	1.6324	1.5238	1.5238
2	1.6518	1.9662	1.7204	1.7901	1.6518	1.5061	1.5061
3	1.7004	2.1948	1.9662	1.7404	1.6324	1.5061	1.5061
4	1.6518	2.0153	1.5655	1.8107	1.7284	1.5061	1.5729
5	1.8399	2.384	1.7695	1.9839	1.989	1.7101	1.7604
6	2.1874	2.4417	2.572	2.3926	2.34	1.9839	2.1091
7	1.1883	1.1317	2.6452	1.1883	.9145	2.0119	1.1431
8	3.0013	2.6355	2.8344	2.8018	2.6452	3.0013	2.7978
9	3.3065	3.0967	3.2819	3.1824	3.0521	3.5848	3.4082
10	3.2156	3.2819	3.4808	3.2065	1.8724	3.0493	3.271
11	3.0807	3.0967	3.0333	3.255	2.9424	3.271	3.4374
12	2.8292	3.083	3.195	3.0727	2.6595	3.1602	3.1602
13	2.6326	2.9635	3.0121	2.8327	3.1367	2.6326	2.9938
14	2.5766	2.915	2.8807	2.7366	3.2156	2.6326	2.9938
15	2.3805	2.7692	2.7846	2.6406	3.0807	2.6326	2.7446
16	.4572	.4527	.5658	.5601	.5658	.5093	.5093
17	.7922	.7922	.7282	.7282	.6224	.5093	.7922
18	1.5844	1.5844	1.5844	1.6004	1.3717	1.3146	1.6409
19	1.6975	1.6004	1.6975	1.6409	1.6975	1.6975	1.6975
20	1.4861	1.4289	1.4712	1.5278	1.3717	1.5278	1.5278
21	1.2449	1.2003	1.358	1.1317	1.1431	1.2003	1.1317
22	.9619	.9145	.8573	.9054	.8573	.9054	.9054
23	1.8461	.4572	1.3226	1.7004	.7802	1.5729	1.4529
24	1.6712	2.0153	1.9393	1.5912	1.6324	1.4746	1.5238
Max	3.3065	3.2819	3.4808	3.255	3.2156	3.5848	3.4374
Min	.4572	.4527	.5658	.5601	.5658	.5093	.5093
Avg	1.9419	2.0079	2.0848	1.9838	1.8556	1.9343	1.9629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****PAONI S/DN.[386]****BU 0386****Substation No/ Name :- 067011 / 132/33 KV ASGAON SUBSTATION****Feeder No / Name : 405 / 33 KV Walni Feeder INCOMER NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.2263	.3641	.3521	.3601
2	.2263	.2263	.2263	.2263	.3681	.3521	.3601
3	.2263	.2263	.2263	.2263	.3641	.3521	.3561
4	.2263	.2743	.2263	.2286	.3641		.3641
5	.3395	.3395	.2858	.2829	.4784	.4207	.4207
6	.3395	.3961	.3395	.3961	.591	.5201	.5258
7	.4344	.3721	.3921	.3429	.4435	.439	.4344
8	.9465	.8048	.9259	.8939	.3961	.3841	.4481
9	1.1831	1.0814	1.1568	1.0682	.499	.3921	.4481
10	1.1934	1.0682	1.3077	.9665	.5601	.3961	.499
11	1.1797	1.1934	1.2209	1.0562	.4001	.3921	.499
12	1.2209	1.1437	1.17	.9054	.3841	.4481	.499
13	1.1174	1.1174	1.1568	.7956	.3881	.439	.4298
14	.9945	1.094	.9448	.7773	.4481	.3761	.3361
15	.9448	1.0322	.2858	.7373	.4938	.3761	.2263
16	.2801	.4115	.2829	.2715	.439	.3326	.3801
17	.2801	.4252	.3395	.2686	.5144	.3881	.4252
18	.5601	.5544	.6224	.5093	.6984	.5041	.4344
19	.5093	.4527	.5093	.4527	.499	.4527	.4527
20	.5093	.4527	.3961	.3961	.5093	.3961	.4527
21	.3361	.3395	.3395	.3395	.3326	.3395	.3361
22	.3292	.3361	.3361	.3326	.3258	.3292	.3292
23	.2772	.2829	.2263	.2829	.3561	.3121	.3361
24	.3224	.2772	.2263	.2263	.2263	.3521	.3086
Max	1.2209	1.1934	1.3077	1.0682	.6984	.5201	.5258
Min	.2263	.2263	.2263	.2263	.2263	.3121	.2263
Avg	.5918	.5887	.5571	.5087	.4352	.3933	.4026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN****Feeder No / Name : 401 / 33kv Sihora****PURELY LIS FEEDERS****Feeder KV- 33 / INCOMING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.679	.679	.6722	1.3763	1.278	1.5203
2	.5041	.679	.6722	.6722	1.278	1.1797	1.5203
3	.4481	.679	.6722	.6722	1.278	1.1797	1.5203
4	.4481	.7922	.7842	.7842	1.278	1.278	1.5203
5	.5041	.9054	1.0082	1.0082	1.4255	1.3763	1.6289
6	.499	1.1088	1.1203	1.1203	1.6712	1.6712	1.9753
7	1.2071	1.1088	1.1203	1.2323	.7842	1.0974	1.2071
8	2.0645	2.3045	2.1948	2.0576	.8962	.9877	.9877
9	2.3594	2.524	2.6886	2.3663	.8779	.9877	.9877
10	2.3594	2.6337	2.6292	2.1879	.9877	.7682	.7865
11	2.5149	2.6337		2.1879	.8779	.7682	.7865
12	2.4143	2.4394	2.524	2.1628	.8779	.6584	.7373
13	2.4143	2.3285	2.524	2.1628	.439	.439	1.0288
14	2.332	2.4394	2.4188	2.0645	.6584	.4435	1.0288
15	2.2634	2.2177	2.3137	1.8896	.6584	.4435	.631
16	.7922	.5601	.6722	.6516	.6584	.3361	.631
17	.7922	.7842	.7842	.7602	.8779	.7842	.8413
18	1.9239	1.7741	1.5684	1.7375	1.7558	1.9044	1.7558
19	1.9239	1.9044	1.9239	1.9239	1.7558	1.7924	1.8656
20	1.6975	1.6804	1.6975	1.6804	1.6461	1.6804	1.6804
21	1.2449	1.2323	1.2323	1.2449	1.2071	1.2323	1.2323
22	.9054	.8871	.8962	.9054	.8779	.7842	.8962
23	.679	.6653	.6722	1.5364	1.278	1.4563	.7842
24	.5601	.679	.6722	.6722	1.3763	1.278	1.5203
Max	2.5149	2.6337	2.6886	2.3663	1.7558	1.9044	1.9753
Min	.4481	.5601	.6722	.6516	.439	.3361	.631
Avg	1.3898	1.485	1.4552	1.4314	1.1166	1.0752	1.2114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 006813 / 220 KV KAWLEWADA SUBSTN****Feeder No / Name : 404 / 33 KV Nakadongari feeder****PURELY LIS FEEDERS****Feeder KV- 33 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	2.1068	.2772	.2743	1.1065	.9717	1.0631
2	.2629	2.4394		.2743	1.1065	.9717	1.0631
3	.2629	2.1068	.2772	.2715	1.094	.9717	1.0099
4	.2658	2.0725	.3326	.2715	1.094	.9717	1.0099
5	.2629	2.3525	.3326	.3258	1.1065	.9831	1.0631
6	.4252	2.5766	.439	.4435	1.1934	1.1568	1.1946
7	.4207	2.6326	.439	.499	.4733		.3921
8	.7042	3.6037	.6447	1.3889	.4733		.3921
9	.7042	4.6016	.7888	1.4403	.4207	.2829	.3841
10	.8048	1.6632	.691	1.4918	.4161	.3921	.3841
11	.823	1.2094	.7362	1.5089	.4344	.3292	.2743
12	3.2693	1.2226	.6836	1.5415	.3801	.3292	.3881
13	3.3436	1.4723	.6241	1.4918	.3224	.3258	
14	3.3951	1.4723	1.3523	1.4918	.2686		.3881
15	2.8487	1.4723	1.3523	1.442	.2715		.3841
16	2.2891	.3292	.3292	.3681	.3681	.3841	.3292
17	2.8166	.439	.3841	.3681	.3258	.3841	.4887
18	3.7357	.7282	.6099	.631	.679	.6722	.6516
19	3.219	.6722	.6653	.631	.679	.6722	.7059
20	3.5608	.6161	.6036	.5316	.6161	.5601	.543
21	2.9647	.439	.439	.4161	.4435	.3921	.4298
22	2.0508	.3292	.3292	.3121	.3258	.3361	.3224
23	1.9404	.3292	.3258	.2629	1.0202	1.0631	1.0631
24	.5658	2.2177	.2772	.2715	.2629	.9717	.9991
Max	3.7357	4.6016	1.3523	1.5415	1.1934	1.1568	1.1946
Min	.2103	.3292	.2772	.2629	.2629	.2829	.2743
Avg	1.7144	1.6294	.5623	.7479	.6201	.6561	.6488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN****Feeder No / Name : 207 / 11 KV Bagheda****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3077	.3439	.2896	.2454	.2481	.124
2	.3077	.3077	.3439	.2896	.2454	.2481	.124
3	.3077	.3258	.3258	.3077	.2454	.2481	.124
4	.3077	.3258	.3258	.3258	.2629	.2835	.124
5	.362	.3439	.3439	.3258	.2804	.2835	.124
6	.3801	.3801	.3801	.362	.3155	.3366	.1417
7	.362	.3982	.3801	.3544	.3155	.3366	.1417
8	.362	.4887	.3801	.3544	.3012	.3189	.1307
9	.362	.5611	.4525	.4252	.3898	.3721	.1772
10	.3439	.6516	.5973	.567	.6379	.4607	.6556
11	.5973	.6878	.6878	.6379	.567	.4784	.5847
12	.5792	.6516	.7059	.6379	.4607	.443	.567
13	.5973	.5611	.6878	.6379	.567	.4607	.4607
14	.4344	.543	.5068	.567	.5493	.3898	.443
15	.4706	.7059	.6697	.6024	.4961	.3721	.3544
16	.5792	.7059	.6154	.7712	.5847	.4961	.6379
17	.5973	.6154	.4163	.6661	.5316	.443	.7282
18	.6154	.6697	.6335	.631	.5493	.567	.7265
19	.6516	.6516	.5973	.5959	.5493	.5316	.691
20	.5973	.5973	.5249	.4908	.4961	.4961	.6733
21	.4525	.5068	.4344	.4031	.3898		.4075
22	.3982	.3982	.3439	.3155	.2835		.3366
23	.3258	.362	.3012	.2629	.2481	.124	.3189
24	.3258	.3077	.3439	.2835	.2454	.2303	.124
Max	.6516	.7059	.7059	.7712	.6379	.567	.7282
Min	.3077	.3077	.3012	.2629	.2454	.124	.124
Avg	.4427	.5023	.4726	.4627	.4066	.3713	.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN****Feeder No / Name : 209 / 11 KV Dongri bz****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.3206	.3206	.3395	.2801	.3174	.3584
2	.3206	.3206	.3018	.3361	.2801	.3174	.3395
3	.3018	.3018	.3018	.3395	.2614	.3174	.3395
4	.3018	.3206	.3018	.3584	.2987	.3174	.3584
5	.3961	.3395	.3584	.3584	.3174	.3547	.3584
6	.4338	.4715	.4527	.4904	.4108	.4715	.4715
7	.4338	.4527	.4527	.4668	.4108	.4715	.4715
8	.415	.4904	.3584	.5041	.3547	.4527	.415
9	.5281	.5281	.3018	.5975	.3961	.5093	.4715
10	.5658	.6036	.4527	.5975	.4715	.4904	.547
11	.4904	.6413	.6224	.5228	.4904	.4715	.4527
12	.4338	.6036	.5847	.5975	.547	.4527	.5093
13	.5658	.5281	.5847	.5601	.4668	.5281	.5093
14	.4527	.5093	.547	.5228	.5041	.4527	.4904
15	.547	.5847	.5847	.5041	.5601	.5093	.4904
16	.5847	.6224	.5658	.4854	.5601	.5093	.5093
17	.6036	.6036	.5847	.5415	.5788	.5093	.4904
18	.6979	.7167	.7167	.7655	.7282	.7545	.7167
19	.6224	.7167	.7356	.7095	.7468	.7733	.7733
20	.6979	.6413	.679	.6348	.5975	.7167	.6979
21	.547	.4904	.5281	.5228	.4854	.5658	.547
22	.3206	.3772	.415	.4108	.4108	.4527	.4338
23	.3395	.3206	.3361	.3174	.3547	.3772	.3772
24	.3395	.3206	.3206	.3174	.2987	.3174	.3584
Max	.6979	.7167	.7356	.7655	.7468	.7733	.7733
Min	.3018	.3018	.3018	.3174	.2614	.3174	.3395
Avg	.4692	.4927	.4753	.4917	.4505	.4754	.4786

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN****Feeder No / Name : 210 / 11 KV Chikhala****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.4904	.3961	.3206	.4338	.5281	
2	.3206	.547	.3772	.3206	.415	.3961	.4715
3	.3395	.5281	.3772	.3018	.3772	.3961	.415
4	.3584	.415	.3395	.3206	.3361	.3772	.3961
5	.3395	.3584	.3395	.3206	.3584	.3772	.3961
6	.3395	.3018	.3018	.3206	.3961	.415	.3772
7	.3584	.4527	.2829	.3961	.3961	.415	.415
8	.2829	.4904	.3206	.3772	.415	.3584	.4527
9	.8299	.7733	.3395	.9242	.6224	.7167	.6224
10	1.1317	1.2071	.2641	1.0185	1.2637	1.1317	1.1317
11	.7733	.6979	.2829	.5847	.6413	.6413	.679
12	.8676	.679	.2829	.7167	.811	.8676	.7356
13	.7922	.7733	.3018	.811	.9997	.7167	.8299
14	.7922	.4904	.2641	.547	.5847	.7167	.4527
15	.3395	.2263	.2641	.2829	.2452	.3018	.2641
16	.3584	.3584	.3018	.3772	.3395	.3395	.3961
17	.6224	.9054	.2829	.8299	.7733	.9054	.9431
18	.9808	1.0185	.2829	.9054	.9242	.7922	1.1128
19	.3206	.3772	.3961	.415	.3584	.3395	.7733
20	.7167	.6224	.3772	.7167	.7167	.8676	.8676
21	.7167	.5658	.415	.6036	.4904	.5847	.811
22	.3584	.3206	.415	.3206	.3206	.2829	.3206
23	.3395	.3018	.2641	.4338	.3018	.3018	.3395
24	.3206	.3961	.3584	.2858	.3772	.3961	.3961
Max	1.1317	1.2071	.415	1.0185	1.2637	1.1317	1.1317
Min	.2829	.2263	.2641	.2829	.2452	.2829	.2641
Avg	.5501	.5541	.3262	.5188	.5374	.5486	.5913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064010 / 33 KV GOBARWAHI S/STN****Feeder No / Name : 211 / 11 KV Nakadongari AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.3174	.3174	.2801	.3206	.3206	.3018
2	.2427	.3174	.3174	.2987	.3206	.3206	.2829
3	.2427	.2987	.3174	.2987	.3206	.3395	.3018
4	.2614	.3174	.2987	.3174	.3018	.3584	.3206
5	.3547	.3361	.3361	.3361	.3395	.3584	.3395
6	.4108	.4294	.3734	.4108	.415	.415	.415
7	.4294	.4294	.3547	.415	.415	.415	.3961
8	.3921	.3734	.4108	.3961	.3772	.3584	.3584
9	.4294	.4668	.4108	.4338	.3584	.3395	.3734
10	.3547	.4108	.4854	.415	.4527	.3395	.3961
11	.4108	.3547	.4481	.4338	.3961	.3206	.3361
12	.3547	.3921		.3584	.3206	.3395	.3921
13	.4108	.3734	.3547	.3584	.3772	.3361	.3584
14	.3734	.3547	.3174	.3395	.3018	.3206	.3206
15	.3921	.4108	.3174	.3361	.3206	.3018	.3018
16	.3174	.3174	.3361	.3772	.3584	.3206	.3584
17	.4108	.4108	.3547	.3772	.3961	.3921	.3921
18	.5975	.6161	.6348	.6224	.6224	.6224	.5975
19	.5975	.6161	.6161	.6224	.6224	.6224	.5975
20	.5601	.5975	.5975	.5658	.5847	.6036	.5415
21	.5041	.5041	.5041	.5093	.4904	.4784	.4668
22	.4108	.4294	.4294	.3961	.3961	.415	.3921
23	.3547	.3547	.3395	.3584	.3584	.3206	.3547
24	.2987	.3174	.3361	.3018	.3772	.3395	.3206
Max	.5975	.6161	.6348	.6224	.6224	.6224	.5975
Min	.2427	.2987	.2987	.2801	.3018	.3018	.2829
Avg	.3898	.4061	.4003	.3983	.3977	.3874	.3840

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)****Feeder No / Name : 201 / 11 KV EMD****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4904	.415	.5093	.4715	.0377
2	.4527	.4527	.5281	.4338	.4904	.4527	.0377
3	.4338	.4715	.5281	.4338	.4904	.4527	.0377
4	.4338	.4715	.4527	.4527	.4904	.4715	.0189
5	.4527	.4715	.4527	.4338	.4715	.4527	.0189
6	.4338	.4715	.3772	.4527	.0754	.4527	.0189
7	.4338	.4715	.4527	.4527	.0754	.4527	.0189
8	.4338	.4527	.3772	.4715	.5093	.0943	.0189
9	.3584	.4904	.5093	.4904	.5093	.0943	.0377
10	.1132	.0943	.5093	.4715	.5093	.1132	.1132
11	.415	.4527	.5093	.5093		.0377	.1132
12	.3772	.4527	.5281	.5658	.4904	.0377	.0377
13	.5658	.4904	.1698	.5658	.1509	.0377	.0377
14	.547	.4904	.4527	.5093	.1509	.0189	.0377
15	.4715	.4904	.5281	.5093	.1509	.0754	.0377
16	.4338	.6224	.5281	.4904	.4715	.0189	.0377
17	.4904	.5658	.5281	.5093	.4527	.0189	.0377
18	.4904	.5281	.5093	.547	.5658	.0189	.0377
19	.547	.4904	.5281	.5281	.547	.0566	.0377
20	.4904	.4904	.5093	.5281	.4904	.0566	.0754
21	.4904	.4904	.5658	.5093	.4904	.0377	.0566
22	.4338	.547	.5093	.5093	.4715	.0377	.0566
23	.4527	.547	.0943	.5093	.4715	.0377	.0566
24	.4527	.4527	.4904	.3584	.5093	.4715	.0377
Max	.5658	.6224	.5658	.5658	.5658	.4715	.1132
Min	.1132	.0943	.0943	.3584	.0754	.0189	.0189
Avg	.4440	.4755	.4637	.4857	.4150	.1863	.0440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064011 / 33 KV DONGRI (BZ)****Feeder No / Name : 202 / 11kv Balapur****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452		.2452	.2075	.2263	.2263	.1886
2	.2452	.2263	.2452	.1886	.2263	.2452	.1886
3		.2452	.2075	.1886	.2075	.2452	.132
4	.2641	.2452	.2075	.1886	.2075	.2452	.132
5	.2641	.2452	.1698	.2452	.2075	.2075	.1698
6	.2829	.2452	.1698	.2641	.2075	.2263	.1698
7	.1886	.1886	.132	.132	.132	.1509	.1509
8	.1886	.1698	.1698	.1509	.1698	.1509	.1509
9	.2641	.1886	.1886	.3018	.2829	.1509	.1886
10	.2075	.1698	.3395	.1509	.1886	.1509	.2075
11	.3018	.3018	.2075	.2075	.2075	.1698	.2829
12	.1698	.1509	.2263	.1698	.1698	.2263	.3395
13	.1698	.1509	.1509	.1698	.1698	.2452	.132
14	.1509	.132	.1509	.1509	.132	.132	.132
15	.1509	.132	.132	.132	.0943	.132	.1132
16	.1509	.1509	.2263	.1698	.0943	.132	.3584
17	.3206	.2829	.3018	.1698	.2075	.132	.3206
18	.2641	.2641	.2263	.2452	.3206	.2263	.2829
19	.2829	.3018	.3018	.3018	.2829	.2263	.3018
20	.3961	.3961	.2829	.415	.4338	.2452	.3961
21	.2829	.2829	.2641	.2641	.2829	.2263	.2829
22	.2452	.2452	.2452	.2641	.2641	.1886	.2452
23	.1886	.2452	.1886	.2263	.2075	.1886	.2452
24	.2452	.2263	.2452	.2075	.2075	.2263	.1886
Max	.3961	.3961	.3395	.415	.4338	.2452	.3961
Min	.1509	.132	.132	.132	.0943	.132	.1132
Avg	.2378	.2255	.2177	.2130	.2138	.1957	.2208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 211 / 11 KV Sihora SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.5792	.547	.5658	.3048	.2658	.415
2	.4854	.5792	.547	.5658	.2896	.2658	.415
3	.4854	.6335	.5415	.5658	.2896	.2658	.415
4	.4668	.6154	.5415	.6602	.2743	.3189	.415
5	.6535	.6878	.5601	.6602	.3281	.3721	.4338
6	.8316	.7522	.7095	.7167	.3637	.4784	.4527
7	.8688	.8775	.8215	.8865	.7655	.8775	.9808
8	.5316	.4298	.5601	.5014	.7865	.8589	.7545
9	.5344	.5731	.6722	.5731	.7973	.8402	.8299
10	.5281	.5014	.5441	.4578	.7796	.7655	.8131
11	.6036	.5249	.5281	.5087	.7087	.6535	.7023
12	.5487	.5068	.4961	.5365	.6556	.6348	.6283
13	.5853	.4706	.4961	.5493	.5493	.5788	.3326
14	.5121	.3801	.4321	.5316	.5493	.5281	.4805
15	.4572	.439	.4001	.4752	.5316	.5228	.4435
16	.5487	.5487	.547	.5784	.6024	.5788	.5914
17	.6401	.6767	.6602	.6556	.6024	.6908	.7392
18	1.3352	1.3073	1.358	.8764	1.258	1.3817	1.3352
19	1.3717	1.3717	1.4146	1.3321	1.3112	1.3443	1.2269
20	1.2803	1.262	1.2696	1.0374	1.2226	1.251	1.1789
21	1.0059	.9709	1.0185	1.0185	.9568	.9522	.8669
22	.695	.7095	.7545	.5975	.6733	.6348	.6979
23	.5914	.5601	.6602	.3163	.2801	.3547	.5658
24	.5228	.5792	.5415	.5658	.2824	.2801	.415
Max	1.3717	1.3717	1.4146	1.3321	1.3112	1.3817	1.3352
Min	.4572	.3801	.4001	.3163	.2743	.2658	.3326
Avg	.6904	.6890	.6925	.6555	.6318	.6540	.6721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 212 / 11 KV Bapera SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.2172	.2033	.2033	.1478	.1478	.1478
2	.1612	.2172	.2033	.2033	.1478	.1478	.1478
3	.1433	.2172	.2054	.2033	.1478	.1478	.1478
4	.1433	.2172	.2033	.2402	.1478	.1478	.1663
5	.2149	.2353	.2218	.2587	.1478	.1663	.1663
6	.3475	.2715	.2587	.2772	.2033	.1848	.1848
7	.3109	.3077	.3142	.3142	.3109	.3189	.3511
8	.1463	.1646	.1463	.1478	.2481	.2303	.2957
9	.1478	.1646	.1829	.1478	.2481	.2481	.2402
10	.1463	.1463	.1848	.168	.2126	.1848	.1663
11	.1433	.1463	.1478	.168	.2126	.2033	.1663
12	.1612	.1463	.1478	.1494	.2303	.1663	.1478
13	.1433	.1463	.1478	.1478	.2303		.1463
14	.1433	.1463	.1478		.1595	.1867	
15		.1463	.1478		.1772	.1867	
16	.1433	.2012	.1478	.1663	.1417	.168	
17	.2507	.2561	.2772	.2218	.1949	.2427	.2218
18	.591	.6767	.5729	.4066	.567	.6348	.5729
19	.6447	.695	.7207	.6283	.6201	.6535	.5601
20	.5552	.567	.5544	.5601	.5316	.5415	.5544
21	.394	.3841	.4066	.3921	.3721	.415	.462
22	.1433	.2561	.2957	.2402	.2658	.2427	.2402
23	.2172	.2218	.2587	.1478	.1478		.1867
24	.1612	.2172	.2033	.2033	.1478	.1478	.1478
Max	.6447	.695	.7207	.6283	.6201	.6535	.5729
Min	.1433	.1463	.1463	.1478	.1417	.1478	.1463
Avg	.2441	.2652	.2625	.2543	.2484	.2597	.2581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 213 / 11 KV Gondekhari SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3326	.3109	.3189	.3012	.2481	.3224
2	.2614	.3326	.3109	.3189	.2835	.2303	
3	.2614	.3326	.3109	.3189	.2835	.2303	.3224
4	.2427	.3696	.3475	.3544	.2835	.2658	.3582
5	.3361	.4435	.3658	.4252	.3544	.3189	.4298
6	.6722	.6283	.439	.4961	.4607	.4784	.4477
7	.6733	.6838	.6401	.6379	.6024	.6344	.6805
8	.4607	.4755	.439	.4607	.5487	.5487	.6447
9	.5194	.5853	.5121	.5316	.463	.5487	.5552
10	.567	.5121	.5493	.5552	.5316	.4435	.443
11	.4607	.567	.4784	.5373	.5144	.4435	.4252
12	.4938	.3475	.4784	.4477	.4287	.3881	.3544
13	.4435	.3439	.5316	.691			.3012
14	.4784	.4706	.4784	.443	.3429	.2686	.3045
15	.4784	.4163	.4252	.443	.3601	.2507	.3224
16	.3012	.3077	.3189	.3439	.3429		.3403
17	.4784	.4024	.3898	.439	.4115		.4024
18	.9745	.905	.8859	.7392	.9088	1.0208	.905
19	.9745	.9955	.9745	.9922	.8916	.9955	1.0164
20	.8505	.9145	.7973	.924	.8059	.8596	.8775
21	.6024	.6626	.5847	.6348	.5487	.6516	.7095
22	.4252	.4119	.443	.3544	.3772	.3982	.4108
23	.3366	.3582	.3898	.3109	.2481	.2715	.3734
24		.3326	.3045	.3189	.3012	.2481	.3224
Max	.9745	.9955	.9745	.9922	.9088	1.0208	1.0164
Min	.2427	.3077	.3045	.3109	.2481	.2303	.3012
Avg	.5031	.5055	.4877	.5015	.4606	.4640	.4900

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 214 / 11 KV Silegaon SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2427	.2195	.2263	.2688	.2591	.2715
2	.168	.2427	.2172	.2263	.2688	.2591	.2715
3	.168	.2427	.2195	.2263	.253	.2591	.2715
4	.168	.2801	.2195	.2452	.253	.2915	.2715
5	.2241	.2987	.2561	.2641	.2721	.2915	.2896
6	.4024	.3361	.2926	.3018	.3113	.3239	.3258
7	.3475	.3547	.3475	.3395	.2949	.3601	.3982
8	.3772	.4784	.4668	.4801	.2721	.2572	.3439
9	.4161	.5316	.5228	.4458	.2429	.2743	.3077
10	.4961	.5373	.5087	.4359	.2572	.2534	.2614
11	.6468	.5552	.5087	.4191	.2401	.2353	.2614
12	.6283	.5611	.5087	.431	.2229	.181	.2614
13	.6283	.5611	.4917	.3768	.1886	.181	.2957
14	.5729	.5611	.4748	.3978	.1886	.1629	.1848
15	.5544	.5068	.4409	.3321	.1886	.1448	.1478
16	.1663	.1629	.1509	.168	.1886	.181	.1663
17	.2218	.1991	.2829	.2033	.2229	.2353	.2772
18	.5914	.5249	.547	.3292	.5144	.5792	.5544
19	.6099	.5973	.6036	.6036	1.3112	.543	.5138
20	.5914	.5068	.5281	.543	.4801	.4572	.4961
21	.4251	.3658	.3961	.3921	.3429	.3801	.4075
22	.2772	.2743	.3018	.3547	.2401	.2561	.2772
23	.2402	.2378	.2641	.2656	.253	.2896	.2427
24	.1867	.2427	.2195	.2263	.253	.2591	.2715
Max	.6468	.5973	.6036	.6036	1.3112	.5792	.5544
Min	.1663	.1629	.1509	.168	.1886	.1448	.1478
Avg	.3873	.3917	.3745	.3431	.3137	.2881	.3071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 215 / 11 KV Karkapur SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1867	.1772	.1886	.2458	.2458	.2507
2	.1494	.1867	.1772	.1886	.2458	.2458	.2507
3	.1494	.1867	.1772	.1886	.2458	.2622	.2507
4	.1494	.2241	.1772	.2075	.2458	.2949	.2507
5	.1867	.2427	.1772	.2263	.2785	.3277	.2865
6	.2743	.2801	.2126	.2452	.3201	.3605	.3045
7	.2743	.2614	.2481	.2641	.2458	.2572	.2686
8	.4115	.4075	.5121	.5068	.2401	.2572	.2507
9	.5079	.5316	.567	.543	.2401	.2401	.2686
10	.5182	.567	.5243	.5243	.2229	.2507	.2126
11	.5975	.567	.5243	.4915	.2058		.1949
12	.5975	.5847	.5735	.5243	.1886	.1791	.1772
13	.6161	.5316	.5407	.5138	.1715	.1433	
14	.5601	.5138	.4915	.4428	.1715	.1829	
15	.5415	.5493	.4588	.4218	.1886	.1829	
16		.1791	.1698	.1372	.1715	.1829	
17	.1867	.197	.2641	.1715	.2229	.181	.2149
18	.5041	.3224	.4715	.4024	.4287	.4887	.439
19	.5041	.4706	.4904	.4854	.4458	.439	.3982
20	.4481	.4344	.4338	.415	.2743	.4207	.4207
21	.3174	.3224	.3206	.3018		.2926	.3109
22	.2054	.2149	.2452	.2829	.2058	.2012	.2012
23	.1867	.1791	.2075	.2591	.2458	.2587	.168
24	.1494	.1867	.1791	.1886	.2458	.2458	.2507
Max	.6161	.5847	.5735	.543	.4458	.4887	.439
Min	.1494	.1791	.1698	.1372	.1715	.1433	.168
Avg	.3559	.3470	.3467	.3384	.2477	.2670	.2685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064014 / 33 KV SIHORA S/STN****Feeder No / Name : 216 / 11 KV Chandpur SP****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2561	.2427	.2427	.1494	.1494	.1494
2	.2012	.2561	.2427	.2427	.1494	.1494	.1494
3	.1829	.2561	.2427	.2427	.1494	.1494	.1494
4	.1829	.2561	.2427	.2427	.1494	.1494	.168
5	.2772	.2926	.2772	.2801	.168	.1494	.168
6	.4668	.3658	.3326	.3174	.1867	.1494	.1867
7	.4066	.3475	.4066	.3547	.3292	.3012	.3921
8	.1848	.1663	.1478	.1867	.2835	.2658	.3547
9	.2054	.1829	.1848	.168	.2835	.2658	.3174
10	.1663	.1663	.2054	.1829	.2481	.2587	.3361
11	.1991	.2033	.2054	.1829	.2481	.2957	.3361
12	.1629	.1663	.168	.1463	.1772	.2218	.3174
13	.1629	.1478	.2054	.1463			.2587
14	.181	.1478	.1867	.1463	.2658		.2614
15	.1629	.1663	.168		.2835		.2801
16	.2715	.2587	.2241	.2561	.3012		.2987
17	.3077	.2772	.3734	.3109	.3544	.4024	.4668
18	.7059	.6099	.6908	.3696	.6556	.7499	.7095
19	.724	.6468	.7468	.7655	.6556	.7316	.6447
20	.6335	.6468	.6348	.7095		.6219	.6379
21	.4163	.4344	.4481	.4904	.3721	.4572	.5316
22	.2896	.3109	.3547	.2801	.2835	.3109	.3189
23	.2534	.2587	.3174	.1494	.1494		.2658
24	.2195	.2561	.2402	.2427	.1494	.1494	.1494
Max	.724	.6468	.7468	.7655	.6556	.7499	.7095
Min	.1629	.1478	.1478	.1463	.1494	.1494	.1494
Avg	.2986	.2949	.3120	.2894	.2724	.3120	.3270

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064026 / 33/11 Nakadongari****Feeder No / Name : 203 / 11KV KAWALEWADA****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2772	.2926	.3142	1.2071	1.0526	1.065
2	.298	.2587	.2743	.3174	1.2071	1.0364	1.073
3	.3189	.2587	.2926	.3142	1.1934	1.0364	1.0562
4	.3258	.2801	.3109	.3109	1.1934	1.0526	1.0513
5	.3258	.3734	.3475	.3292	1.1797	1.0814	1.0852
6	.443	.4481	.4251	.4706	1.3203	1.2407	1.17
7	.4706	.4854	.4805	.4706	.4961		.3921
8	.8322	1.46	.6104	1.4918	.4961		.3881
9	.8495	1.7002	.763	1.5604	.4706	.3395	.4066
10	.9088	1.6278	.7282	1.5604	.4706	.4572	.4525
11	.9189	1.2717	.8322	1.6289	.4706	.3439	.3258
12	.8573	1.2717	.7282	1.6263	.4344	.3439	.3801
13	.5375	1.5091	.6733	1.6289	.3761	.3109	
14	1.3203	1.5261	1.4352	1.647	.3403		.3658
15	1.2239	1.5261	1.4706	1.5604	.3439		.4024
16	.3544	.3544	.3772	.3988	.4207	.3681	.3841
17	.2427	.4572	.3841	.4525	.362	.4163	.5304
18	.6154	.7023	.679	.7059	.6602	.6413	.6283
19	.6838	.6979	.7167	.7059	.7356	.6908	.7167
20	.5847	.6224	.6602	.5914	.6535	.5601	.5847
21	.4251	.4435	.4715	.4527	.5175	.4108	.4251
22	.3475	.3511	.3584	.3584	.362	.3077	.3326
23	.2957	.3142	.3326	.3206	1.1012	1.0486	1.0526
24	.631	.2772	.2926	.3142	.2896	1.0688	1.0322
Max	1.3203	1.7002	1.4706	1.647	1.3203	1.2407	1.17
Min	.2427	.2587	.2743	.3109	.2896	.3077	.3258
Avg	.5868	.7706	.5807	.8138	.6793	.6904	.6653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064026 / 33/11 Nakadongari****Feeder No / Name : 401 / 33 KV DongariBz feeder****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17
HR	Load (MW)	Load (MW)
2		2.3434
3		2.1148
4		1.8861
5		1.9433
6		2.2862
7		2.2862
8		2.2862
9		3.315
12	2.915	
13	3.4294	
14	2.572	
15	2.0576	
16	2.4006	
17	3.0864	
18	3.7151	
19	3.0864	
20	3.4865	
21	2.915	
22	1.9433	
23	1.7718	
Max	3.7151	3.315
Min	1.7718	1.8861
Avg	2.7816	2.3077

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 201 / 11 KV SIHORA G****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1509	.1132	.1509	.0943	.0566	.0754
2	.1132	.132	.1132	.132	.0943	.0754	.0943
3	.1132	.0934	.1132	.132	.0943	.0754	.0943
4	.132	.1132	.1132	.1698	.0943	.0754	.0943
5		.1509	.1509	.1494	.12	.1509	.132
6	.2263	.2452	.2452	.2641	.2641	.2241	.2075
7	.1698	.1867	.2263	.2241	.3395	.1867	.2075
8	.1848	.1848	.2033	.1829	.2012	.2033	.1509
9	.1848	.1294	.1463	.2012	.128	.1791	.1478
10	.1478	.1307	.1867	.128	.1848	.1595	.112
11	.2012	.128	.1646	.1463	.1227	.1227	.1848
12	.1848	.1448	.181	.1848	.124	.0876	.1478
13	.1097	.1448	.1075	.0934	.1097	.0543	
14	.1109	.1254	.0373	.0924	.0732	.1097	.1829
15	.0914	.181	.0924	.0924	.0739	.1097	.1829
16	.128	.1448	.1448	.1267	.0709	.1086	.1063
17	.1109	.1086	.1307	.1267	.1417	.197	.1307
18	.5121	.4904	.4668	.462	.4854	.4904	.4904
19	.4904	.4715	.5093	.4715	.4715	.4715	.4527
20	.4715	.4338	.4715	.4338	.4338	.415	.4338
21	.3584	.3395	.3584	.3395	.3018		.3395
22	.1509	.1698	.2263	.1509	.1494	.0934	.132
23	.1509	.132	.1494	.1509	.0754	.1132	.1132
24	.1132	.1478	.1132	.1698	.1132	.0566	.0754
Max	.5121	.4904	.5093	.4715	.4854	.4904	.4904
Min	.0914	.0934	.0373	.0924	.0709	.0543	.0754
Avg	.1987	.1950	.1985	.1990	.1817	.1659	.1865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 203 / 11 KV TUMSAR town****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1372	.1187	.12	.12	.1174	.0848
2	.1357	.1372	.1006	.1029	.1029	.1006	.0857
3	.1715	.1063	.1006	.12	.1029	.1017	.0857
4	.1715	.1052	.1029	.12	.1017	.1006	.0857
5	.1543	.1402	.1227	.1214	.12	.1372	.1052
6	.1886	.1928	.1227	.1402	.1402	.1753	.1227
7	.2835	.2454	.2103	.3189	.1907	.1928	.2303
8	.3294	.333	.2835	.333	.3294	.3189	.3366
9	.3366	.333	.2454	.3012	.2804	.3012	.3086
10	.3544	.333	.3155	.3467	.3224	.3506	.333
11	.3856	.3641	.3258	.3641	.3429	.3681	.3641
12	.4031	.3688	.3086	.3391	.3315	.3688	.373
13	.3506	.3353	.3086	.3086	.3052	.1715	.3315
14	.3155	.3258	.2155	.3391	.2347	.3222	.2949
15	.3544	.3185	.2753	.3658	.2683	.3113	.3258
16	.3506	.3353	.2372	.3239	.3149	.3201	.3353
17	.3856	.3315	.3077	.3812	.3605	.3932	.4161
18	.5373	.5434	.4681	.4961	.4961	.5201	.5609
19	.4961	.5138	.4557	.5138	.4607	.4733	.5316
20	.4557	.443	.3898	.4656	.4252	.4607	.4784
21	.3506	.3544	.3121	.3366	.3429	.3258	.3544
22	.2401	.2601	.2629	.2774	.2401	.2058	.2601
23	.1715	.2058	.1907	.2058	.1886	.1372	.1715
24	.1677	.1372	.1715	.12	.1715	.1174	.0848
Max	.5373	.5434	.4681	.5138	.4961	.5201	.5609
Min	.1357	.1052	.1006	.1029	.1017	.1006	.0848
Avg	.3024	.2875	.2480	.2859	.2622	.2663	.2775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 204 / 11 KV JAMB town****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9431	.9149	.9808	.8402	.9054	.8402
2	.8865	.8865	.8775	.9431	.811	.8962	.8215
3	.8215	.8865	.8865	.9431	.811	.8589	.8215
4	.8775	.9054	.8962	.9054	.8299	.8589	.8215
5	1.0374	1.0185	.9522	.9522	.9335	.9709	.9522
6	1.1694	1.1949	1.0374	1.0269	1.0185	1.0562	1.0562
7	1.4098	1.4289	1.2574	1.4289	1.2384	1.448	1.3336
8	1.448	1.5242	1.448	1.4289	1.3717	1.448	1.5242
9	1.3527	1.3769	1.4523	1.3336	1.4289	1.3717	1.3717
10	1.2384	1.3527	1.4289	1.2574	1.3336	1.2384	1.3527
11	1.2574	1.3014	1.3769	1.2826	1.3957	1.2384	1.2449
12	1.1576	1.1883	1.1883	1.1506	1.2449		1.1241
13	.9997	1.1128	1.1241	1.0751	1.1317	1.0374	1.0562
14	.9431	1.0185	1.0374	1.0185	1.0374	.9526	.9619
15	.9808	.9619	.9335	.9717	1.0288	1.8671	.9907
16	.9997	1.094	.9717	1.0374	.9431	.9619	.9717
17	1.0349	1.1883	1.0562	1.1317	1.094	1.1317	1.1128
18	1.6032	1.6032	1.5278	1.6787	1.5278	1.5655	1.5466
19	1.5655	1.5466	1.448	1.5432	1.5432	1.5089	1.5278
20	1.5278	1.467	1.4712	1.5242	1.467	1.448	1.5051
21	1.448	1.3717	1.3717	1.3717	1.3717	1.3527	1.3908
22	1.2765	1.1883	1.2193	1.1883	1.2003	1.1506	1.1812
23		1.0185	1.272	.9808	1.0185	.9431	.9808
24	.9997	.9997	.9709	.9808	.9149	.9242	.8402
Max	1.6032	1.6032	1.5278	1.6787	1.5432	1.8671	1.5466
Min	.8215	.8865	.8775	.9054	.811	.8589	.8215
Avg	1.1713	1.1907	1.1717	1.1723	1.1473	1.1798	1.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 205 / 11kv Sihora AGP****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5117		.431
2					.5053		.4458
3					.5053		.4401
4					.5053		.4401
5					.5053		.4607
6					.5117		.4904
8	.703	.7202	.6882	.6636		.3005	
9	.7748	.7935	.7773	.6958		.6325	
10	.8322	.8162	.8259	.6958		.6009	
11	.8259	.7968	.8381	.7682		.664	
12	.7449	.7682	.8223	.7682		.6636	
13	.7611	.7682	.8065	.8322		.6405	
14	.7748	.8002	.7499	.7842		.6481	
15	.7287	.7116	.7099	.7907			
23					.5182	.4666	.3666
24	.4401				.4755		.4515
Max	.8322	.8162	.8381	.8322	.5182	.664	.4904
Min	.4401	.7116	.6882	.6636	.4755	.3005	.3666
Avg	.7317	.7719	.7773	.7498	.5048	.5771	.4408

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 207 / 11kv HASARA****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1848	.1886	.1867	.1886	.1867	.1867
2	.1463	.1848	.1886	.1886	.1867	.1867	.1867
3	.1829	.1848	.1886	.1886	.1867	.1867	.1886
4	.181	.1848	.1886	.1886	.1867	.1867	.1886
5	.2172	.1848	.2263	.1867	.1867	.2241	.1886
6	.2641	.2218	.2263	.2241	.2263	.2641	.2241
7	.2561	.2218	.2587	.2614	.2241	.2241	.2241
8	.2561	.2218	.1867	.1867	.2218	.2172	.2587
9	.2534	.2587	.1848	.2241	.2561	.2218	.2218
10	.2195	.2218	.1848	.1867	.2561	.2534	.2957
11	.2218	.2865	.2865	.2534	.3224	.2534	.2926
12	.1848	.2149	.2149	.2534	.2587	.181	.2561
13	.1478	.2149	.2218	.1509	.2587	.1848	.2835
14	.1848	.2195	.2149	.2172	.2896	.2218	.2507
15	.1478	.2172	.2534	.2149	.2149	.2218	.2241
16	.1848	.181	.208	.2454	.2149	.4066	.2614
17	.1848	.2149	.3224	.2507	.2454	.2218	.2957
18	.4066	.4108	.4435	.4108	.4481	.3696	.415
19	.4066	.4108	.4108	.4108	.4108	.4066	.415
20	.3696	.3395	.3772	.3772	.3772	.3696	.3734
21	.2957	.3018	.2926	.3361	.3018	.2587	.3361
22	.1848	.2241	.2614	.2241	.2218	.2218	.2195
23	.1848	.1867	.1829	.1886	.2241	.1848	.2218
24	.1867	.1848	.4058	.1867	.1886	.1867	.1867
Max	.4066	.4108	.4435	.4108	.4481	.4066	.415
Min	.1463	.181	.1829	.1509	.1867	.181	.1867
Avg	.2271	.2366	.2549	.2393	.2540	.2434	.2581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 208 / 11 kv GANDHINAGAR town****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4854	.4527	.4904	.415	.415	.3361
2	.4108	.4481	.415	.4904	.3772	.3772	.3361
3	.4527	.4481	.415	.4527	.3772	.3772	.3734
4	.4904	.4481	.415	.4527	.3772	.3772	.3734
5	.4904	.4481	.4904	.4481	.4527	.4527	.4108
6	.6036	.5228	.4904	.5601	.5281	.4904	.4904
7	.7095	.6283	.5658	.7023	.5658	.6036	.6348
8	.6722	.6348	.6348	.6722	.6722	.6348	.5601
9	.5601	.5228	.5601	.5544	.5601	.5601	.5228
10	.5228	.5601	.6348	.5228	.5281	.5601	.5601
11	.4854	.5175	.5914	.4805	.5914	.5228	.5975
12	.5544	.4755	.5487	.5175	.5175	.4481	.5544
13	.4854	.4805	.4854	.4755	.4805	.4527	.5544
14	.4108	.4435	.4755	.4024	.4435	.3734	.439
15	.4108	.4024	.4854	.4755	.3658	.3734	.4108
16	.3734	.4024	.5175	.439	.394	.4108	.439
17	.4066	.4805	.4805	.5068	.4298	.5228	.543
18	.7842	.7842	.7762	.7468	.7762	.7842	.7762
19	.7468	.7842	.8215	.7842	.7468	.7468	.7468
20	.7468	.7842	.7842	.7095	.6584	.7095	.7468
21	.6722	.7095	.7468	.7545	.6348	.6722	.7468
22	.5601	.6348	.6722	.6413	.5975	.5601	.6036
23	.5228	.5281	.5228	.5658	.4854	.4481	.4527
24	.4481	.4481	.4527	.4904	.4527	.415	.3361
Max	.7842	.7842	.8215	.7842	.7762	.7842	.7762
Min	.3734	.4024	.415	.4024	.3658	.3734	.3361
Avg	.5404	.5426	.5598	.5557	.5178	.5120	.5227

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 064034 / 33 KV TUMSAR****Feeder No / Name : 401 / 33 KV GOBARWAHI Feeder
Feeder KV- 33 / OUTGOING****NON SHEDDABLE WATER SUPPLY AND
UTILITY**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.037		2.037	1.7741	2.0576	2.037	1.4415
2	1.9239		2.037	1.7741	2.037	2.037	1.4415
3	1.9605		2.037	1.6632	2.037	1.9239	1.386
4	1.9044		1.9239	1.6078	1.9239	1.8673	1.3306
5	1.9044		1.8673	1.6632	1.7541	1.4003	1.3306
6	2.0936		2.037	2.1285	1.5912	2.0725	1.4969
7	2.1502		1.8673	2.0165	1.4563	1.8484	1.2489
8	2.2068		1.9239	2.0725	1.9805	1.6975	1.5524
9	2.8858		2.1502	2.9687	2.9127	2.2068	2.3765
10	2.9127	3.6969	2.7161		3.5848	2.7161	3.0407
11	3.1602	3.4568	2.8858	3.2487	3.2819	2.1502	2.5206
12		3.4374	2.32	3.0807	3.0247	2.2405	2.8829
13		3.1602	2.2965	3.1927	2.6886	2.2965	2.4086
14		2.7166	2.0165	2.8858	2.037	2.1285	1.6409
15		2.5503	2.2965	2.2068	2.1502	1.6004	1.7541
16		2.7149	2.6326	2.7446	2.4086	1.9044	2.0936
17		3.1493	2.4086	3.2819	3.1367	2.2405	2.6057
18		3.9209	3.0247	3.8089	3.7346	3.3048	3.5648
19		3.1687	2.9687	3.3385	3.1121	2.7726	2.8858
20		3.4517	2.7721	3.5082	3.1121	2.8858	3.3951
21		3.0247	2.5206	2.8858	2.9424	1.9239	2.7161
22		2.1845	2.0513	2.0936	2.1148	1.3014	1.6409
23		1.9239	1.2883	1.8107	1.7541	1.2489	1.4712
24	2.1502		2.037	1.6078	1.9805	2.1502	1.5123
Max	3.1602	3.9209	3.0247	3.8089	3.7346	3.3048	3.5648
Min	1.9044	1.9239	1.2883	1.6078	1.4563	1.2489	1.2489
Avg	2.2741	3.0398	2.2548	2.4941	2.4506	2.0815	2.0724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 203 / 11 KV Betala G Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.2543	.1865	.1753	1.0852	.9619	.9808
2	.1696	.2543	.1696	.1753	1.1022	.9619	.9808
3	.1696	.2543	.1696	.1753	1.1022	.9808	.9808
4	.1696	.2543	.1865	.1753	1.0852	.9997	1.0185
5	.1865	.2543	.2204	.1753	1.0513	1.0374	1.0751
6	.2543	.2543	.2374	.2629	1.0513	1.1317	1.1506
7	.2204	.2543	.2374	.2629	.2035	.2641	.2641
8	1.3565	1.4413	1.3904	1.3146	.2035	.2829	.3018
9	1.4922	1.5261	1.5091	1.4022	.2543	.2641	.2883
10	1.5261	1.6108	1.5261	1.4413	.3018	.3018	.2883
11	1.6108	1.6278	1.5775	1.3904	.3584	.2263	.2204
12	1.5261	1.6617	1.5775	1.4074	.2452	.2263	.2204
13	1.5261	1.3904	1.5775	1.4243	.2829	.1698	.2543
14	1.5261	1.4752	1.6651	1.3565	.3018	.2075	.1696
15	1.5261	1.3735	1.5775	1.3565	.2075	.2641	.2374
16	.1696		.1753	.2713	.2641	.2829	.1865
17	.1696	.2543	.1753	.2204	.1886	.2829	.2035
18	.3391	.4409	.4382	.39	.4715	.4338	.3391
19	.4239	.4409	.3506	.4578	.4715	.4715	.4239
20	.4239	.4239	.3506	.3561	.3772	.4527	.3561
21	.3391	.39	.2629	.2713	.2829	.3018	.2713
22	.2543	.2374	.1753	.2035	.2075	.2263	.2035
23	.2543	.2204	.1753	.1865	.9808	.9808	.8309
24	1.0004	.2543	.5655	.1753	.9835	.9808	.9431
Max	1.6108	1.6617	1.6651	1.4413	1.1022	1.1317	1.1506
Min	.1696	.2204	.1696	.1753	.1886	.1698	.1696
Avg	.7002	.7195	.6865	.6262	.5443	.5289	.5079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 205 / 11 KV MIDC****Feeder KV- 11 / OUTGOING****SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.0374	1.3336	1.1393	1.1622	1.3769	1.2071
2	1.2574	1.1317	1.2384	1.1393	1.1431	1.1883	1.0562
3	1.3527	1.1317	1.2384	1.1393	1.1622	1.2071	1.1694
4	1.1622	1.1317	1.1431	1.1393	1.2003	1.2071	1.4335
5	1.1431	1.0374	1.105	1.1393	1.1431	1.2826	1.1506
6	1.105	1.3203	1.0669	1.2269	1.3146		1.2826
7	1.0669	1.0374	1.0669	1.1393	1.0479	.9808	1.094
8	1.1431	.6602	1.1431	1.0517	1.0479	1.0185	1.1694
9	.9526	.6602	1.3717	1.0517	1.2003	1.1883	1.2003
10	.7621	1.2384	1.2384	1.4098	1.3769	1.0374	1.3146
11	.7621	1.5242	1.2269	1.2887	.8865	1.2826	1.3717
12	.5716	1.1431	1.0517	1.2955	.8488	1.1694	1.1622
13	.6602	1.4098	1.1393	1.1812	1.2071	1.3014	1.3336
14	.5658	1.4098	1.3146	1.448	1.2826	1.4712	1.467
15	.5087	1.4289	1.2269	1.3527	1.1128	1.4335	1.0669
16	.5087	1.1241	1.3146	1.3908	1.4335	1.4146	1.5051
17	.5658	1.3146	1.2269	1.4098	1.3203	1.4712	1.5051
18	.5087	1.2955	1.2269	1.2003	1.3203	1.3769	1.5242
19	.6602	1.3527	1.2269	1.1812	1.3769	1.3203	1.0669
20	.5658	1.0479	.964	1.0288	1.1506	1.0751	1.2193
21	.5658	1.2765	.964	.9526	1.2637	1.3392	1.0479
22	.5658	1.1431	1.1393	1.3336	1.1317	1.3957	1.1622
23	.6602	1.0479	1.1393	1.0288	1.2449	1.0562	1.105
24	1.2574	.6602	1.3908	1.1393	1.1241	1.2637	1.2637
Max	1.3527	1.5242	1.3908	1.448	1.4335	1.4712	1.5242
Min	.5087	.6602	.964	.9526	.8488	.9808	1.0479
Avg	.8379	1.1485	1.1874	1.2003	1.1876	1.2547	1.2449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 206 / 11 KV UFIL****Feeder KV- 11 / OUTGOING****NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINOUS PROCESS)(NO
STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.7545	1.3014	1.1393	.8488	1.0562	1.0185
2	1.2071	.8488	1.4146	1.1393	.8488	1.0562	1.1694
3	1.2071	.8488	1.4146	1.1393	.8299	1.0185	1.0562
4	1.1128	.8488	1.3014	1.1393	.811	.9997	.9431
5	1.1128	.9431	.9242	1.1393	.5281	.8865	.7922
6	.5093	.8488	1.1317	.964	.547	.7922	.7733
7	.3961	1.1317	1.3203	1.0517	.9997	1.0185	.9054
8	.3772	1.1317	.9054	.964	1.3769	1.3392	1.1694
9	.415	1.226	.7356	1.0517	1.358	1.1883	1.3203
10	.3772	1.3203	.4715	1.1506	1.3392	1.3014	1.0185
11	.2829	.4527	.8764	1.1694	1.2071	1.1317	1.226
12	.3772	.9808	.8764	1.3392	1.1694	1.2449	1.2449
13	.2829	1.226	.7888	1.0185	1.1506	1.1694	1.226
14	.3772	.9242	.7011	.4527	.8676	.9619	.6224
15	.1886	1.2071	1.0517	1.1128	1.1317	.9431	1.1317
16	.5658	1.1506	.7888	1.1506	1.3203	1.3203	1.3203
17	.5658	.679	1.0517	1.1883	1.1317	1.4523	1.3014
18	.5658		.964	1.2071	1.4146	1.0185	.9431
19	.3772	1.4335	1.0517	1.3392	1.1694	1.226	1.1128
20	.2829	.9808	.964	1.0374	1.1128	1.1128	.8488
21	.3772	1.0185	.8764	.8299	1.2826	.9997	.9242
22	.4715	.8676	.7888	.9054	.9242	1.0185	.6979
23	.5658	1.0631	1.1393	1.3014	.9808	.9808	.6224
24	1.0374	.5658	1.226	1.1393	.811	.9619	1.1883
Max	1.2071	1.4335	1.4146	1.3392	1.4146	1.4523	1.3203
Min	.1886	.4527	.4715	.4527	.5281	.7922	.6224
Avg	.5863	.9762	1.0027	1.0862	1.0484	1.0916	1.0240

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 402 / 33kv Jamb****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.7442	1.1317	1.3146	2.0062	1.9004	1.9004
2	.6173	.8413	1.1317	1.3146	2.0062	1.8461	1.9547
3	.6173	1.0517	1.1317	1.3146	1.9547	1.8461	1.9547
4	.6173	1.1568	1.0288	1.3146	1.9547	1.8461	1.9547
5	.6687	1.262	1.1317	1.3146	1.8519	2.009	2.0633
6	.8745	1.4723	1.1831	1.4723	2.0576	2.2805	2.3348
7	.8745	.8413	1.3375	.9465	.823	.8688	.8688
8	3.035	1.9982	2.572	2.524	1.3375	.8688	1.6832
9	3.3436	2.4714	2.7263	2.6818	1.4403	1.3032	1.4403
10	3.5082	3.1379	2.2634		1.5203	1.4118	1.6975
11	3.5757	3.1379	3.2602	2.9321	1.6289	1.4118	1.5947
12	6.8359	3.1379	3.2076	2.8292	1.7918	1.5746	1.9547
13	6.8884	3.5082	2.5766	3.035	1.6832	1.6832	1.6975
14	6.8039	3.1893	3.155	2.8807	1.5203	1.6832	1.5432
15	6.4849	.7202	2.8921	2.8292	1.5203	1.5203	1.4403
16	2.7149	.7202	.7888	.6173	.8145	.7602	.5658
17	2.7343	.7716	.8413	.6687	.8145	.8688	.823
18	1.3672	1.3889	1.3672	1.2346	1.3575	1.3575	3.1379
19	1.4883	1.3889	1.4198	1.3375	1.4118	1.4118	1.3889
20	1.4198	1.286	1.3146	1.2346	1.4118	1.3575	1.286
21	.9991	1.0288	1.1043	1.0288	1.086	1.086	1.0802
22	.8413	.823	.8413	.7202	.8145	.8145	.7716
23	.7362	1.1317	1.2094	.9774	1.9547	2.009	1.749
24	1.749	.7888	2.2748	1.2094	.6173	1.8461	1.9547
Max	6.8884	3.5082	3.2602	3.035	2.0576	2.2805	3.1379
Min	.6173	.7202	.7888	.6173	.6173	.7602	.5658
Avg	2.4755	1.5833	1.7455	1.6405	1.4741	1.4819	1.6183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 403 / 33 KV Kardi feeder****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	01-DEC-17
HR	Load (MW)
24	1.2071
Max	1.2071
Min	1.2071
Avg	1.2071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****BHANDARA DIVSION[651]****TUMSAR S/DN[382]****BU 2020****Substation No/ Name :- 067006 / 132 KV MADGI S/S****Feeder No / Name : 404 / 33kv sahuli****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.5249	1.4403	1.3146	2.9835	2.3891	2.4434
2	1.3889	1.5249	1.4918	1.3146	3.035	2.2805	2.3891
3	1.3375	1.5775	1.4918	1.3146	3.035	2.2805	2.3891
4	1.3375	1.6478	1.4918	1.3146	2.9835	2.2262	2.3891
5	1.3889	1.6301	1.4918	1.3146	2.9835	2.2262	2.552
6	1.4918	1.4723	1.5432	1.4198	3.1379	2.552	2.7149
7	1.4918	1.5775	1.4918	1.5249	.9259	1.1403	1.1946
8	1.5432	3.6808	1.8004	1.9456	1.0288	1.086	1.1403
9	2.5206	3.4705	3.858	1.6301	.9774	.9774	.9774
10	2.7343	3.4465	3.7037	3.0864	1.0317	.9619	.8745
11	3.8803	3.5494	3.7334	3.9095	1.0317	.9231	.9259
12	3.774	3.5494	3.9438	3.9095	.9231	.8688	.9259
13	3.7334	3.5494	3.7334	3.9095	.8145	.7602	.7716
14	3.5757	3.6523	3.8912	3.8066	.8145	.7059	.6687
15	3.2076	4.0638	3.6283	3.858	.8145	.6516	.6687
16	1.4352	1.2346	.9465	1.4403	.8145	.7059	.6687
17	1.8107	1.749	.8413	1.5432	.8145	.7602	.823
18	2.073	1.9547		1.8519	1.3032	1.3575	1.3889
19	1.9982	2.0576	1.9982	1.9033	1.4661	1.5203	1.4403
20	1.893	1.9033	1.893	1.8004	1.3032	1.3575	1.286
21	1.701	1.749	1.6827	1.6461	1.1946	1.1946	1.1831
22	1.5249	1.4918	1.4723	1.4918	.9231	.9231	.9259
23	1.4883	1.3375	1.3672	1.3375	.7602	2.3891	2.3148
24	1.5432	1.4723	1.0802	1.262	2.9835	2.3891	2.3891
Max	3.8803	4.0638	3.9438	3.9095	3.1379	2.552	2.7149
Min	1.3375	1.2346	.8413	1.262	.7602	.6516	.6687
Avg	2.0964	2.2861	2.1746	2.0771	1.5868	1.4428	1.4769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 201 / 11 KV LAKHANDUR FEEDER****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1715	.1524	.1334	.1524	.1334
2	.1524	.1524	.1715	.1524	.1334	.1334	.1334
3	.1334	.1524	.1715	.1334	.1334	.1524	.1334
4	.1524	.1524	.1715	.1524	.1334	.1334	.1334
5	.1715	.1524	.1905	.1715	.1715	.1524	.1334
6	.2096	.2096	.2286	.2096	.1715	.2096	.1334
7	.0191	.2477	.2286	.2286	.2096	.2286	.2096
8	.2286	.2477	.2286	.2096	.2096	.2286	.2477
9	.2477	.2667	.2286	.2286	.2286	.2477	.2477
10	.2286	.2667	.2286	.2096	.2286	.2286	.2477
11	.2286	.2477	.2667	.2667	.3048	.2477	.2286
12	.1905	.2477	.2286	.2477	.2667	.3048	.2667
13	.2096	.2286	.2286	.2096	.2477	.2667	.2667
14	.2096	.2477	.2096	.2096	.2096	.2858	.2096
15	.2286	.2096	.1715	.1905	.2286	.2477	.2286
16	.2286	.1905	.2096	.1905	.2286	.2667	.2096
17	.2477	.2096	.2477	.2286	.2477	.2286	.2286
18	.362	.4191	.3429	.3429	.3429	.381	.381
19	.3429	.381	.3239	.3239	.3239	.3429	.362
20	.3048	.3048	.3048	.2858	.3048	.3048	.3239
21	.2667	.2477	.2477	.2477	.2477	.2286	.2667
22	.2096	.2096	.1905	.1905	.1905	.1715	.2096
23	.1715	.1905	.1715	.1524	.1524	.1524	.1715
24	.1524	.1715	.1715	.1524	.1524	.1524	.1334
Max	.362	.4191	.3429	.3429	.3429	.381	.381
Min	.0191	.1524	.1715	.1334	.1334	.1334	.1334
Avg	.2104	.2294	.2223	.2120	.2167	.2270	.2183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 202 / 11 KV TEMBHARI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1715	.1334			
2		.1905	.1715	.1334			
3		.1905	.1715	.1143			
4		.1905	.1715	.1143			
5		.2096	.1715	.1524			
6		.2096	.1715	.1715			
8	.362				.3239	.4191	.4191
9	.4382				.4572	.5335	.5335
10	.4572				.5335	.5716	.5525
11	.4954				.5144	.5716	.5525
12	.5335				.5716	.5716	.5525
13	.4954				.5716	.5335	.5335
14	.4572				.5335	.5144	.381
15	.4191				.4191	.4382	.381
23		.1524	.1143	.0762			
24			.1524	.1334	.0762		
Max	.5335	.2096	.1715	.1715	.5716	.5716	.5525
Min	.362	.1524	.1143	.0762	.0762	.4191	.381
Avg	.4573	.1905	.1620	.1286	.4446	.5192	.4882

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 203 / 11 KV PERSODI AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0953	.1143			
2		.0572	.0953	.1143			
3		.0572	.0953	.0953			
4		.0762	.0953	.0953			
5		.0762	.1143	.1143			
6		.0762	.1143	.1334			
8	.1905				.1524	.1905	.2286
9	.2286				.2286	.2477	.2286
10	.2477				.2286	.1905	.2286
11	.2667				.2667	.2667	.3048
12	.2667				.3048	.2667	.2667
13	.2667				.3048	.2667	.2667
14	.2286				.3429	.2858	.2286
15	.2286				.3048	.1905	.2286
23		.0762	.0953	.0572			
24			.0762	.1143	.0572		
Max	.2667	.0762	.1143	.1334	.3429	.2858	.3048
Min	.1905	.0572	.0762	.0572	.0572	.1905	.2286
Avg	.2405	.0708	.0977	.1048	.2434	.2381	.2477

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 204 / 11 KV BARWA AG FEEDER (FEEDER SEPERATION/PURE AG
CHICHO Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191				.0572	.0381	.0381
2	.0191				.0381	.0381	.0191
3	.0191				.0381	.0381	.0191
4	.0191				.0381	.0381	.0191
5	.0381				.0381	.0381	.0191
6	.0191				.0572	.0381	.0381
8		.0572	.0953	.0381			
9		.0762	.0953	.0381			
10		.0762	.1143	.0953			
11		.0762	.1143	.1143			
12		.0762	.0953	.0953			
13		.1524	.0762	.1143			
14		.1143	.0762	.1143			
15		.0953	.0762	.0953			
23	.0381				.0381	.0381	.0191
24	.0191	.0191				.0381	.0572
Max	.0381	.1524	.1143	.1143	.0572	.0381	.0572
Min	.0191	.0191	.0762	.0381	.0381	.0381	.0191
Avg	.0239	.0826	.0929	.0881	.0436	.0381	.0286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 205 / 11 KV REST HOUSE Feeder****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0953	.0762	.0762	.0762
2	.0762	.0572	.0762	.0953	.0762	.0762	.0762
3	.0953	.0572	.0762	.0762	.0762	.0572	.0762
4	.0953	.0762	.0953	.0762	.0762	.0762	.0762
5	.1143	.0953	.1524	.0762	.1334	.0762	.0953
6	.1334	.1715	.1715	.1905	.1715	.1524	.1715
7	.1715	.1905	.1715	.1905	.1715	.1715	.1524
8	.1524	.1524	.1524	.1715	.1334	.1524	.1524
9	.1334	.1905	.1524	.1524		.1334	.1524
10	.1334	.1715	.1334	.1715	.1143	.1334	.1715
11	.0762	.1143	.1334	.1524	.1143	.1334	.1143
12	.0762	.1143	.1334	.1334	.0953	.1524	.0953
13	.0572	.0953	.1334	.0953	.0762	.0572	.0762
14	.0762	.0953	.0762	.0762	.0762	.0762	.0953
15	.0762	.0953	.0762	.0762	.0762	.0953	.0762
16	.0953	.0953	.0762	.0953	.0953	.0572	.1143
17	.0953	.1143	.1143	.1143	.1524	.1143	.1143
18	.1715	.2286	.1905	.1715	.2096	.1715	.1905
19	.2096	.1905	.1905	.1905	.1905	.1715	.2096
20	.1905	.1715	.1715	.1715	.1524	.1715	.1905
21	.1334	.1524	.1334	.1334	.1143	.1143	.1334
22	.1143	.0953	.0953	.0953	.0762	.1143	.0953
23	.0953	.0762	.0953	.0953	.0572	.0762	.0762
24	.0762	.0762	.0762	.0953	.0762	.0762	.0762
Max	.2096	.2286	.1905	.1905	.2096	.1715	.2096
Min	.0572	.0572	.0762	.0762	.0572	.0572	.0762
Avg	.1135	.1231	.1231	.1246	.1127	.1119	.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION

Feeder No / Name : 206 / 11 KV SONI AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381				.0762	.1334	.0953
2	.0381				.0762	.1334	.0953
3	.0381				.0762	.1524	.0953
4	.0572				.0762	.1334	.0953
5	.0762				.1715	.1524	.1334
6	.0953				.1905	.1524	.1524
8		.1715	.3048	.2858			
9		.3048	.3429	.3429			
10		.3429	.381	.4001			
11		.4191	.381	.4191			
12		.4954	.4191	.4382			
13		.4572	.4191	.4572			
14		.4191	.4191	.4382			
15		.381	.3048	.381			
23	.0381				.1143	.1143	.1143
24	.0191	.0191				.1143	.1143
Max	.0953	.4954	.4191	.4572	.1905	.1524	.1524
Min	.0191	.0191	.3048	.2858	.0762	.1143	.0953
Avg	.0500	.3345	.3715	.3953	.1116	.1358	.1120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 207 / 11 KV Parsodi Gaothan SEPARATED GAOTHAN FEEDERS**
Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0381	.0381	.0381	.0381	.0191
2	.0381	.0191	.0381	.0381	.0381	.0381	.0191
3	.0381	.0191	.0381	.0381	.0191	.0381	.0191
4	.0381	.0191	.0572	.0381	.0191	.0381	
5	.0381	.0381	.0572	.0381	.0381	.0381	.0381
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0381
9	.0381	.0381	.0381	.0381	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381	.0381	.0381
11	.0381	.0381	.0381	.0381	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0191	.0381
15	.0381	.0381	.0381	.0191	.0381	.0381	.0381
16	.0381	.0381	.0381	.0191	.0381	.0381	.0381
17	.0381	.0381	.0572	.0381	.0381	.0381	.0381
18	.0572	.0953	.0762	.0762	.0953	.0953	.0572
19	.0381	.0762	.0762	.0953	.0762	.0762	.0762
20	.0572	.0572	.0762	.0572	.0572	.0762	.0762
21	.0381	.0572	.0381	.0381	.0381	.0381	.0572
22	.0381	.0381	.0381	.0191	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0191	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0191
Max	.0572	.0953	.0762	.0953	.0953	.0953	.0762
Min	.0381	.0191	.0381	.0191	.0191	.0191	.0191
Avg	.0397	.0405	.0453	.0405	.0413	.0421	.0398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 208 / 11 KV Barwha Gaothan
(CHICHOLI Feeder KV- 11 /
OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0953	.0572	.0572	.0762
2	.0572	.0762	.0762	.0953	.0572	.0381	.0762
3	.0762	.0762	.0762	.0762	.0572	.0381	.0762
4	.0762	.0762	.0953	.0762	.0572	.0572	.0762
5	.0762	.0762	.0953	.0762	.0572	.0572	.0953
6	.0953	.0953	.1143	.1143	.0953	.0953	.0953
7	.0762	.0953	.0953	.0953	.0953	.0953	.0953
8	.0762	.0762	.0762	.0762	.0762	.0953	.0953
9	.0762	.0572	.0572	.0762	.0762	.0762	.0572
10	.0572	.0572	.0381	.0572	.0381	.0572	.0381
11	.0381	.0381	.0381	.0572	.0381	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0191	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0572	.0572	.0381	.0572	.0381
17	.0953	.0572	.0762	.0572	.0572	.0762	.0572
18	.1334	.1334	.1524	.1334	.1524	.1524	.1143
19	.1524	.1334	.1524	.1524	.1334		.1524
20	.1334	.1334	.1524	.1334	.1143		.1524
21	.1143	.1143	.1143	.1143	.0953	.0953	.1143
22	.0762	.0953	.0953	.0762	.0762	.0762	.0762
23	.0762	.0762	.0953	.0762	.0572	.0762	.0572
24	.0762	.0762	.0762	.0953	.0572	.0572	.0762
Max	.1524	.1334	.1524	.1524	.1524	.1524	.1524
Min	.0191	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0754	.0754	.0818	.0810	.0683	.0658	.0754

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 209 / 11 KV Soni Gaothan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1334	.1334	.1334	.1143	.0953
2	.0953	.1334	.1334	.1334	.1334	.0953	.0953
3	.0953	.1334	.1334	.1143	.1334	.0953	.0953
4	.1143	.1334	.1524	.1143	.1334	.1143	.0953
5	.1334	.1334	.1715	.1334	.1334	.1143	.1524
6	.1905	.1905	.1905	.1905	.1524	.1715	.1715
7	.1524	.1715	.1715	.2096	.2477	.1334	.1524
8	.1524	.1905	.2667	.2096	.2667	.1524	.1334
9	.1143	.2096	.2667	.2096	.2667	.1524	.2477
10	.1905	.2286	.2858		.2858	.1905	.2667
11	.2286	.2858	.2477		.3239	.2096	.3239
12	.3048	.3048	.2096		.362	.1524	.2477
13	.3239	.2667	.2096	.2286	.3048	.1905	.2858
14	.2477	.3239	.2667	.2477	.2667	.2286	.2477
15	.2667	.2858	.1143	.2477	.2286	.2477	.1715
16	.2667	.3048	.2096	.2667	.2286	.2477	.1334
17	.3048	.3429	.2286	.381	.2667	.2286	.1524
18	.381	.4572	.381	.4572	.381	.4954	.3239
19	.381	.3429	.3048	.4191	.3429	.3239	.3429
20	.2858	.3048	.2667	.2667	.2667	.2667	.3048
21	.1905	.2858	.1905	.1905	.1905	.1905	.2286
22	.1524	.1524	.1524	.1334	.1524	.1143	.1524
23	.1524	.1524	.1143	.1334	.1143	.0953	.1334
24	.1143	.1334	.1334	.1334	.1334	.1143	.0953
Max	.381	.4572	.381	.4572	.381	.4954	.3429
Min	.0953	.1334	.1143	.1143	.1143	.0953	.0953
Avg	.2064	.2334	.2056	.2168	.2270	.1850	.1937

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064001 / 33 KV LAKHANDUR SUB STATION****Feeder No / Name : 210 / TEMBHERI GAUTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0381	.0381	.0191	.0191	.0191	.0191
2	.0191	.0381	.0381	.0191	.0191	.0191	.0191
3	.0191	.0381	.0381	.0191	.0191	.0191	.0191
4	.0191	.0381	.0381	.0191	.0191	.0191	.0191
5	.0191	.0381	.0381	.0191	.0191	.0191	.0191
6	.0191	.0381	.0381	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8		.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0572	.0572	.0572	.0572	.0572	.0572
11	.0191	.0762	.0572	.0572	.0572	.0762	.0572
12	.0191	.0572	.0381	.0762	.0953	.0572	.0762
13	.0191	.0762	.0381	.0953	.0762	.0572	.0762
14	.0191	.0572	.0381	.0762	.0572	.0572	.0572
15	.0191	.0762	.0572	.0953	.0762	.0381	.0381
16	.0381	.0953	.0191	.0953	.0762	.0381	.0191
17	.0381	.0762	.0191	.0381	.0381	.0381	.0191
18	.0381	.0381	.0191	.0381	.0191	.0191	.0191
19	.0381	.0191	.0191	.0191	.0191	.0191	.0191
20	.0381	.0191	.0191	.0191	.0191	.0191	.0191
21	.0381	.0191	.0191	.0191	.0191	.0191	.0191
22	.0381	.0191	.0191	.0191	.0191	.0191	.0191
23	.0381	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0381	.0381	.0191	.0191	.0191	.0191
Max	.0381	.0953	.0572	.0953	.0953	.0762	.0762
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0257	.0429	.0318	.0381	.0350	.0302	.0294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 201 / 11 KV VIRLEE AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.285				.2675	.2401	.1463
2	.285				.3121	.2401	.1463
3	.3109				.3121	.2401	.1486
4	.3109				.3121	.2667	.161
5	.3239				.3121	.2667	.1858
6	.3549				.4607	.3067	.2012
8		.7522	.8482	.7621			
9		1.0322	1.1305	.8535			
10		1.1797	1.1142	.945			
11		1.2125	1.1336	.9145			
12		1.2289	1.1336	.8993			
13		1.1797	1.1919	.884			
14		1.1469	1.1336	.8535			
15		1.065	1.0526	.7468			
23	.208				.2202	.132	.1875
24	.285	.208				.2366	.1463
Max	.3549	1.2289	1.1919	.945	.4607	.3067	.2012
Min	.208	.208	.8482	.7468	.2202	.132	.1463
Avg	.2955	1.0006	1.0923	.8573	.3138	.2411	.1654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION****Feeder No / Name : 202 / 11 KV GOURALA AG FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734	.3921	.3734			
2		.3921	.3921	.3734			
3		.3921	.3921	.3734			
4		.4108	.4108	.3734			
5		.4108	.3921	.3921			
6		.4294	.3921	.3921			
8	.5975				.5788	.5544	.5415
9	.7095				.6161	.7023	.6535
10	.7468				.7655	.7655	.7095
11	.7842				.8402	.8029	.7842
12	.7842				.8299	.8215	.7468
13	.7468				.8488	.7842	.7095
14	.7468				.7356	.7095	.6722
15	.7095				.679	.6348	.5601
23		.3734	.3734	.3801			
24			.3921	.3734	.3734		
Max	.7842	.4294	.4108	.3921	.8488	.8215	.7842
Min	.5975	.3734	.3734	.3734	.3734	.5544	.5415
Avg	.7282	.3974	.3921	.3789	.6964	.7219	.6722

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION****Feeder No / Name : 203 / 11 KV Kiramati AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1219	.0686			
2		.1372	.1372	.0686			
3		.1372	.1372	.0686			
4		.1524	.1219	.0686			
5		.1524	.1219	.0686			
6		.1524	.1067	.08			
8	.208				.1981	.1894	.1286
9	.2559				.2439	.2195	.2172
10	.2743				.2469	.2469	.2378
11	.3547				.2623	.3161	.2526
12	.2896				.2439	.2606	.2229
13	.2743				.2343	.2675	.2229
14	.2591				.2229	.2408	.2229
15	.2286				.2172	.1974	.208
20			.08				
23		.1219	.0686	.0686			
24			.1219	.0686	.0686		
Max	.3547	.1524	.1372	.08	.2623	.3161	.2526
Min	.208	.1219	.0686	.0686	.0686	.1894	.1286
Avg	.2681	.1415	.1130	.0700	.2153	.2423	.2141

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION

Feeder No / Name : 204 / 11 KV Kiramti Gaothan

SEPARATED GAOTHAN FEEDERS

Feeder Feeder KV- 11 /
OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0373	.0373	.0377	.0377
2	.0377	.0377	.0377	.0373	.0373	.0377	.0189
3	.0377	.0377	.0377	.0373	.0374	.0377	.0189
4	.0377	.0377	.0377	.0373	.0373	.0377	.0189
5	.0377	.0377	.0377	.0373	.0373	.0377	.0377
6	.0566	.0566	.0566	.056	.0373	.0566	.0566
7	.0566	.0377	.0566	.0373	.056	.0566	.0566
8	.0377	.0377	.0377	.0373	.0373	.0566	.0566
9	.0377	.0377	.0377	.0373	.0373	.0377	.0377
10	.0377	.0377	.0373	.0373	.0373	.0189	.0377
11	.0187	.0377	.0187	.0373	.0187	.0189	.0189
12	.0189	.0189	.0187	.0187	.0187	.0189	.0189
13	.0189	.0189	.0187	.0187	.0187	.0189	.0189
14	.0189	.0189	.0187	.0187	.0189	.0191	.0189
15	.0189	.0189	.0187	.0187	.0189	.0189	.0189
16	.0189	.0189	.0187	.0187	.0189	.0189	.0189
17	.0377	.0377	.0373	.056	.0377	.0377	.0377
18	.0754	.0566	.0747	.0747	.0762	.0754	.0754
19	.0754	.0754	.0943	.0747	.0762	.0754	.0754
20	.0754	.0754	.0747	.0747	.0754	.0754	.0566
21	.0566	.0566	.056	.056	.0566	.0566	.0566
22	.0566	.0377	.0373	.0373	.0377	.0377	.0377
23	.0377	.0377	.0373	.0373	.0377	.0377	.0377
24	.0377	.0377	.0377	.0373	.0373	.0377	.0377
Max	.0754	.0754	.0943	.0747	.0762	.0754	.0754
Min	.0187	.0189	.0187	.0187	.0187	.0189	.0189
Avg	.0409	.0393	.0407	.0404	.0391	.0401	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION****Feeder No / Name : 205 / 11kv virli Gaothan****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1886	.1307	.1307	.112	.1307	.1307
2	.1494	.1698	.1307	.1307	.112	.1307	.112
3	.1494	.1698	.1494	.1307	.112	.1307	.112
4	.1494	.1886	.1494	.1307	.112	.1307	.112
5	.1494	.1886	.168	.1494	.112	.1494	.1494
6	.2054	.1886	.1867	.1867	.1307	.2054	.168
7	.1867	.1867	.1867	.168	.1867	.1867	.168
8	.168	.2054	.2054	.168	.2241	.1867	.1867
9	.2427	.1867	.1867	.2241	.2614	.2241	.1867
10	.2054	.2054	.1867	.2801	.3174	.2987	.1867
11	.2054	.2241	.168	.2054	.3734	.2801	.2054
12	.1867	.2241	.1494	.1867	.3361	.2427	.2054
13	.1867	.2054	.168	.168	.3174	.1867	.1867
14	.1867	.2054	.1867	.1494	.2614	.168	.1867
15	.168	.2054	.3734	.2241	.2241	.112	.168
16	.1867	.2054	.3361	.2241	.2427	.1494	.1867
17	.2241	.2427	.2987	.2241	.2241	.1867	.2241
18	.2801	.3174	.3174	.2987	.3142	.2772	.2987
19	.3018	.2987	.2987	.2801	.3326	.2772	.2987
20	.2829	.2614	.2427	.2801	.2402	.2772	.2614
21	.2452	.2054	.1867	.1867	.2033	.2033	.2241
22	.2263	.1867	.1494	.1494	.1478	.1848	.1867
23	.1886	.1494	.1307	.1307	.1294	.1478	.1494
24	.1494	.1886	.1307	.1307	.112	.1307	.1307
Max	.3018	.3174	.3734	.2987	.3734	.2987	.2987
Min	.1494	.1494	.1307	.1307	.112	.112	.112
Avg	.1989	.2083	.2007	.1891	.2141	.1916	.1844

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064002 / 33 KV VIRLEE SUB STATION****Feeder No / Name : 206 / GAWARADA GAUTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.112	.0934	.112	.0934	.0934	.0747
2	.0934	.112	.112	.112	.0934	.0934	.056
3	.0934	.112	.112	.112	.0934	.0934	.056
4	.0934	.112	.112	.112	.0934	.0934	.0934
5	.112	.1307	.112	.112	.0934	.112	.1307
6	.1494	.1494	.1307	.1307	.112	.1494	.1494
7	.1307	.1307	.1307	.1307	.1307	.1307	.1494
8	.0934	.112	.112	.1307	.112	.112	.1307
9	.0934	.112	.0934	.0934	.0934	.0934	.112
10	.0934	.112	.0747	.0747	.0934	.0934	.112
11	.0747	.0934	.0747	.0934	.0934	.0747	.0934
12	.0747	.0934	.0747	.112	.0747	.0934	.0747
13	.0747	.0934	.0747	.0934	.0934	.0747	.0747
14	.0934	.112	.0747	.0747	.0747	.0747	.0747
15	.0747	.112	.0747	.0934	.0747	.0934	.0934
16	.0934	.1307	.0934	.112	.0934	.112	.112
17	.112	.168	.1307	.1494	.1307	.112	.1494
18	.2427	.2427	.2241	.2427	.2427	.2427	.2427
19	.2614	.2614	.2427	.2241	.2427	.2427	.2427
20	.2241	.2241	.2054	.2054	.2427	.2241	.2054
21	.1867	.168	.168	.1494	.2054	.1494	.1494
22	.1494	.1494	.1494	.112	.112	.112	.112
23	.112	.112	.112	.0934	.112	.0747	.0934
24	.0943	.112	.0934	.112	.0934	.0934	.0747
Max	.2614	.2614	.2427	.2427	.2427	.2427	.2427
Min	.0747	.0934	.0747	.0747	.0747	.0747	.056
Avg	.1214	.1361	.1198	.1245	.1206	.1183	.1190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064012 / 33 KV BARWHA S/STN****Feeder No / Name : 201 / 11 KV Barwha Feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0602	.0602	.0594			
2		.0602	.0602	.0594			
3		.0602	.0602	.0594			
4		.0602	.0602				
5		.0602	.061	.0594			
6		.0903	.0914	.0892			
8	.1581				.1235	.2031	.061
9	.253				.2214	.2187	.1829
10	.2622				.2372	.2187	.253
11	.253				.2591	.2343	.2561
12	.2688				.2591	.2343	.2469
13	.2561				.2439	.253	.2229
14	.2343				.2439	.2372	.208
15	.1852				.2134	.1829	.1593
23		.0602	.0282	.0301			
24			.0602	.0594	.029		
Max	.2688	.0903	.0914	.0892	.2591	.253	.2561
Min	.1581	.0602	.0282	.0301	.029	.1829	.061
Avg	.2338	.0645	.0602	.0595	.2034	.2228	.1988

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064012 / 33 KV BARWHA S/STN****Feeder No / Name : 202 / 11 KV Murmadi AG Feeder FEEDER SEPERATION/PURE AG**
Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1094	.1094	.0914			
2		.1094	.1094	.0914			
3		.1094	.1094	.0914			
4		.1094	.0937	.0914			
5		.0937	.0937	.0914			
6		.1067	.0937	.0914			
8	.1898				.1219	.125	.061
9	.1898				.1718	.125	.0914
10	.1943				.1718	.1406	.1067
11	.1898				.1981	.1406	.1094
12	.1875				.218	.1406	.1389
13	.1619				.1829	.1406	.1372
14	.1524				.1677	.1406	.1189
15	.1389				.1486	.0914	.1337
23		.1094	.0762	.0762			
24			.1094	.0914	.0762		
Max	.1943	.1094	.1094	.0914	.218	.1406	.1389
Min	.1389	.0937	.0762	.0762	.0762	.0914	.061
Avg	.1756	.1068	.0994	.0895	.1619	.1306	.1122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKHANDUR S/DN.[385] BU 0385

Substation No/ Name :- 064012 / 33 KV BARWHA S/STN

Feeder No / Name : 203 / 11 KV Chikana AG Feeder FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.176				.2408	.2439	.1715
2	.176				.0256	.2286	.1858
3	.176					.2286	.2143
4	.176					.2286	.2143
5	.132				.2462	.2256	.2143
6	.208				.2675	.2286	.2286
7					.2934		
8		.2778	.4915	.3749			
9		.4111	.5079	.4321			
10		.4481	.5155	.4666			
11		.442	.5693	.4816			
12		.5312	.5556	.4843			
13		.5556	.4938	.4843			
14			.4938	.4843			
15		.5182	.4938	.4999			
23	.2107					.1524	.1738
24	.176					.2439	.1715
Max	.2107	.5556	.5693	.4999	.2934	.2439	.2286
Min	.132	.2778	.4915	.3749	.0256	.1524	.1715
Avg	.1788	.4549	.5152	.4635	.2147	.2225	.1968

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064012 / 33 KV BARWHA S/STN****Feeder No / Name : 204 / 11KVCHIKANA (GAOTHAN)****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0377	.0566	.0377	.0377	.0377
2	.0566	.0377	.0566	.0566	.0377	.0377	.0377
3	.0566	.0377	.0566	.0566	.0377	.0377	.0377
4	.0566	.0377	.0566	.0566	.0377	.0377	.0377
5	.0566	.0377	.0566	.0566	.0566	.0377	.0377
6	.0943	.0572	.0566	.0566	.0739	.0566	.0754
7	.0566	.0566	.0566	.0754	.0754	.0566	.0566
8	.056	.0377	.0566	.0566	.056	.0566	.0377
9	.056	.056	.0373	.037	.056	.0566	.056
10	.0554	.0554	.0549	.0532	.0549	.0543	.0373
11	.0554	.0358	.0739	.0377	.0716	.0373	.0554
12	.0362	.0537	.0554	.037	.0366	.0362	.0554
13	.0373	.0362	.0554	.0366	.0347	.0554	.037
14	.037	.0358	.0537	.0366	.0732	.037	.0724
15	.0373	.0354	.0362	.037	.0732	.037	.0762
16	.0373	.0366	.0543	.0362	.0732	.0554	.056
17	.0373	.0373	.0724	.0377	.0373	.0554	.0373
18	.132	.132	.1132	.1132	.1132	.1132	.132
19	.132	.132	.132	.132	.132	.132	.1334
20	.1143	.0953	.1132	.1132	.0754	.1132	.0943
21	.0943	.0754	.0943	.0754	.056	.0754	.0762
22	.0566	.0537	.0739	.0566	.056	.0566	.0572
23	.0566	.0362	.0566	.0566	.0377	.0566	.0566
24	.0566	.0566	.0377	.0566	.0377	.0377	.0377
Max	.132	.132	.132	.132	.132	.132	.1334
Min	.0362	.0354	.0362	.0362	.0347	.0362	.037
Avg	.0634	.0551	.0645	.0593	.0596	.0570	.0595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064012 / 33 KV BARWHA S/STN****Feeder No / Name : 205 / BARWHA GAOTHAN****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.132	.1307	.132	.1307	.1294	.1307
2	.1494	.132	.132	.132	.1307	.1294	.1307
3	.1494	.112	.132	.132	.1307	.1109	.1307
4	.1494	.1132	.1509	.132	.1307	.1307	.1307
5	.1494	.1132	.1509	.132	.1307	.1294	.1307
6	.168	.1698	.1698	.1698	.1509	.1307	.168
7	.168	.1307	.1698	.1698	.1478	.1307	.168
8	.1307	.132	.1698	.1509	.1307	.1307	.1494
9	.2033	.2172	.2218	.1143	.1829	.1307	.1463
10	.2772	.2507	.197	.1478	.2686	.1307	.1829
11	.2328	.1791	.2328	.1433	.2454	.1463	.1829
12	.2126	.2279	.2149	.2241	.2378	.2012	.1848
13	.1848	.2572	.2149	.1848	.1907	.1698	.208
14	.1132	.2572	.197	.1387	.1402	.1509	.2058
15	.1829	.2543	.1791	.2103	.1307	.1509	.2058
16	.1907	.1802	.2149	.2801	.1075	.1886	.2149
17	.2801	.2263	.2149	.2218	.1307	.1698	.2279
18	.2987	.2829	.3326	.4066	.3174	.3395	.3921
19	.3584	.3584	.3326	.3142	.2801	.3584	.3772
20	.2402	.2641	.3018	.2402	.1867	.3206	.3018
21	.1886	.2263	.2263	.1867	.1867	.2263	.2075
22	.1509	.1509	.1698	.1494	.1886	.1509	.1509
23	.1509	.1307	.1509	.1307	.1509	.132	.132
24	.1494	.1509	.1307	.132	.1307	.1294	.1307
Max	.3584	.3584	.3326	.4066	.3174	.3584	.3921
Min	.1132	.112	.1307	.1143	.1075	.1109	.1307
Avg	.1929	.1937	.1974	.1823	.1733	.1716	.1913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064012 / 33 KV BARWHA S/STN****Feeder No / Name : 206 / Murmadi Gaothaon****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0566	.0377	.0373	.0377
2	.0566	.0055	.0754	.0566	.0377	.0377	.0377
3	.0566	.0566	.0754	.0566	.0377	.0566	.0377
4	.0566	.0566	.0754	.0566	.0377	.0566	.0377
5	.0566	.0566	.0754	.0566	.0566	.0566	.0377
6	.0754	.0762	.0754	.0754	.0754	.0566	.0566
7	.0747	.0566	.0566	.0754	.0566	.056	.0566
8	.056	.0377	.0566	.0754	.056	.056	.0566
9	.0373	.0377	.0566	.056	.056	.0554	.0566
10	.0554	.0381	.0373	.0373	.056	.0554	.0377
11	.037	.0377	.0566	.0377	.037	.0554	.0572
12	.037	.0377	.0549	.0566	.0377	.0366	.0381
13	.037	.0377	.0549	.0377	.0377	.0366	.0377
14	.0377	.0377	.0732	.0377	.0373	.0366	.0377
15	.0377	.0347	.0549	.0381	.0549	.0373	.0377
16	.0351	.0362	.0549	.0554	.0549	.0377	.0373
17	.056	.0358	.0549	.0566	.052	.0566	.0554
18	.132	.0905	.132	.132	.132	.1509	.132
19	.1334	.1086	.1509	.1478	.1509	.1509	.132
20	.132	.1086	.132	.1143	.1132	.132	.1132
21	.0943	.1132	.1132	.0754	.0724	.0754	.0754
22	.0739	.0566	.0754	.0566	.0566	.0566	.0566
23	.0566	.0377	.0566	.0377	.0377	.0566	.0566
24	.0566	.0566	.0377	.0566	.0377	.0377	.0377
Max	.1334	.1132	.1509	.1478	.1509	.1509	.132
Min	.0351	.0055	.0373	.0373	.037	.0366	.0373
Avg	.0641	.0545	.0726	.0643	.0591	.0617	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064017 / PARSODI****Feeder No / Name : 201 / kudegaon****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.2629	.1928	.2103	.2107	.2107	.1957
2	.2804	.2629	.1928	.2103	.2107	.2107	.1806
3	.2804	.2629	.1928	.2103	.2107	.2107	.1806
4	.298	.2629	.1928	.2103	.2107	.2107	.1806
5	.298	.2629	.2279	.2103	.2408	.2107	.2107
6	.298	.298	.2279	.2454	.2559	.2258	.2408
8	.4207	.5258	.5959	.4557	.3161	.3763	.4816
9	.5083	.6485	.6661	.5434	.4365	.5569	.5569
10	.5784	.7186	.7186	.5959	.5487	.6171	.5719
11	.5959	.7888	.631	.5959	.5959	.6321	.5719
12	.4733	.7362	.7011	.4572	.5487		.5117
13	.4557	.7537	.7011	.4666	.5335	.5268	.4816
14	.4908	.7011	.7011	.4515	.4877	.4967	.4214
15	.4557	.6485	.631	.3913	.4725	.4816	.2408
23	.2103	.1928	.2103	.1543	.1806	.1806	.1372
24	.2454	.1753	.1928		.1204	.1957	.1806
Max	.5959	.7888	.7186	.5959	.5959	.6321	.5719
Min	.2103	.1753	.1928	.1543	.1204	.1806	.1372
Avg	.3856	.4689	.436	.3606	.3488	.3562	.3340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064017 / PARSODI****Feeder No / Name : 203 / 11 KV KUDEGAON GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.112	.1307	.112	.112	.112	.112
2	.1307	.112	.1307	.112	.112	.112	.112
3	.1307	.112	.1307	.112	.112	.112	.112
4	.1307	.112	.1307	.112	.112	.112	.112
5	.1307	.1867	.1494	.1307	.1307	.1867	.1494
6	.2054	.2241	.2054	.2241	.2054	.2241	.2241
7	.1867	.1867	.1867	.1867	.1494	.1867	.1867
8	.168	.168	.1494	.1494	.1494	.168	.1494
9	.168	.1494	.168	.168	.1867	.1867	.1307
10	.168	.2054	.1867	.1867	.1867	.168	.1307
11	.168	.1867	.1494	.2054	.1867	.1867	.1867
12	.112	.1307	.1494	.1867	.2054	.0747	.1494
13	.0934	.1494	.168	.1494	.1867	.112	.0934
14	.1494	.1867	.112	.1494	.1867	.168	.112
15	.1494	.1494	.112	.1867	.0934	.112	.0648
16		.2054	.112	.1494	.1307	.168	.0934
17		.2614	.1494	.168	.2054	.1494	.1307
18	.4108	.4294	.3734	.3361	.3734	.3734	.3547
19	.3547	.3734	.3734	.3361	.3547	.3361	.3547
20	.3174	.2987	.3174	.2801	.2987	.2801	.2987
21	.2241	.2241	.1867	.2241	.2054	.2054	.2054
22	.1307	.1494	.1494	.1494	.1494	.1307	.1494
23	.112	.1307	.1307	.112	.112	.112	.112
24	.1307		.1307	.112	.112	.112	.112
Max	.4108	.4294	.3734	.3361	.3734	.3734	.3547
Min	.0934	.112	.112	.112	.0934	.0747	.0648
Avg	.1774	.1932	.1743	.1766	.1774	.1704	.1598

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION****Feeder No / Name : 201 / 11 KV DHOLSAR FEEDER
Feeder KV- 11 / OUTGOING****SHEDDABLE RURAL**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0743	.0629	.0581	.0556	.0579	.0533
2	.0533	.0743	.0629	.0581		.0579	.0947
3	.0533	.0743	.0629	.0581	.0556	.0579	.0541
4	.0533	.0743	.0657	.0591	.0417	.0587	.0541
5	.0533	.0743	.0676	.061	.0412	.0587	.0556
6	.0564	.0743	.0695	.0638	.0417	.0587	.0579
7	.0705		.0686	.0754	.0705	.0743	.0564
8	.1027	.0892	.1	.1067	.0987	.1303	.0695
9	.1303	.0892	.0987	.1097	.1235	.1269	.1269
10	.1467	.1286	.1334	.1646	.1353	.1572	.1391
11	.1448	.1252	.141	.1783	.141	.1646	.1551
12	.1269	.1252	.1334	.1783	.1269	.1669	.1509
13	.141	.1334	.1372	.1783	.1235	.1808	.153
14	.1551	.1334	.1446	.1808	.12	.1623	.153
15	.1593	.1067	.1446	.1669	.1372	.1623	.1646
16	.1509	.1115	.1383	.153	.1372	.1296	.16
17	.1315	.1183	.1404	.1509	.1372	.1425	.1276
18	.1486	.0857	.1113	.1303	.0743	.1	.1
19	.1027	.0857	.0934	.104	.0892	.088	.1027
20	.0869	.08	.096	.0834	.0914	.0743	.0724
21	.0857	.0676	.0732	.0834	.0762	.0695	.0743
22	.0705	.0638	.0581	.0686	.0541	.0533	.0503
23	.0695	.0648	.0581	.0667	.0572	.0526	.0564
24	.0526	.0743	.0638	.0581	.0526	.0579	.0533
Max	.1593	.1334	.1446	.1808	.141	.1808	.1646
Min	.0526	.0638	.0581	.0581	.0412	.0526	.0503
Avg	.0999	.0925	.0969	.1082	.0905	.1018	.0973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION****Feeder No / Name : 202 / 11 KV MASAL FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5415	.5041	.5525	.4938	.5093	.4656
2	.5281	.5281	.5041	.5525	.4938	.5121	.4706
3	.5281	.5093	.5093	.5525	.5281	.5121	.4854
4	.5281	.5281	.4854	.5525	.5175	.5121	.4854
5	.5281	.547	.4854	.5525	.5228	.5304	.4508
6	.5658	.5601	.5304	.5847	.5228	.5304	.4961
7	.5658	.5658	.547	.5847	.5228		.5121
8	.6036	.6224	.6097	.6036	.5601	.5847	.547
9	.6908	.6224	.6722	.6535	.5228	.6224	
10	.724	.6535	.6908	.7922		.6348	.7167
11	.7922	.7282	.7282	.8299	.7842	.6722	.7282
12	.8299	.7207	.7865	.8488	.8048	.679	.7023
13	.7842	.8316	.7133	.8402	.7392	.7133	.6626
14	.7095	.7133	.7316	.7842	.7023	.6767	.7682
15	.6908	.7316	.7842	.7392	.7095	.7316	.7392
16	.7095	.8779	.7133	.7316	.7095	.6805	
17	.7023	.6908	.6767	.6767	.695	.6468	.6838
18	.7167	.7207	.7733	.6908	.6722	.6979	.7621
19	.724	.7282	.7545	.7167	.7095	.724	.7167
20	.3018	.6602	.7356	.6653	.7167	.6602	.6722
21	.6224	.5975	.6478	.5914	.6348	.5914	.5853
22	.5658	.5304	.5906	.5487	.5415	.5121	.5544
23	.547	.5228	.5716	.4938	.5175	.5041	.5228
24	.547	.5415	.5175	.5525	.4938	.5093	.4656
Max	.8299	.8779	.7865	.8488	.8048	.7316	.7682
Min	.3018	.5093	.4854	.4938	.4938	.5041	.4508
Avg	.6272	.6364	.6360	.6538	.6137	.6064	.5997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION****Feeder No / Name : 203 / 11 KV BELATHI****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1204	.1027	.1			
2		.1204	.1027	.1			
3			.1067	.1			
4		.1204	.1067	.1014			
5		.1204	.108	.1027			
6		.1204	.1067	.1128			
8	.1235				.0892	.1189	.132
9	.1406				.1158	.1486	.1334
10	.1581				.1189	.1677	.1467
11	.1581				.1486	.1486	.1524
12	.1581				.1635	.1614	.1635
13	.1543				.1486	.1467	.1486
14	.1505				.1467	.1286	.0987
15	.1486				.1486	.1448	.1143
23			.0705	.0429			
24		.0903	.0974	.1			
Max	.1581	.1204	.108	.1128	.1635	.1677	.1635
Min	.1235	.0903	.0705	.0429	.0892	.1189	.0987
Avg	.1490	.1154	.1002	.0950	.1350	.1457	.1362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385]****BU 0385****Substation No/ Name :- 064025 / 33 KV MASAL SUB STATION****Feeder No / Name : 204 / 11 KV Tai Gaothan Feeder****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.112	.132	.0754	.0747	.1109	.056
2	.1109	.112	.132	.0754	.0747	.1109	.056
3	.1109	.112	.132	.0754	.0747	.1109	.056
4	.112	.1494	.1132	.0754	.112	.1109	.0566
5	.112	.1494	.132	.0934	.112	.1109	.0566
6	.1494	.1494	.132	.1307	.112	.1294	.112
7	.112	.1307		.1109	.0934	.112	.0747
8	.128	.112	.112	.0934	.112	.1307	.0747
9	.1267	.1307	.1132	.1063	.1307	.132	.0754
10	.1829	.2241	.132	.1417	.1307	.1494	.1509
11	.1646	.1886	.1132	.1595	.1494	.1698	.1494
12	.1267	.168	.1646	.1595	.168	.1698	.2054
13	.1463	.1307	.1629	.1417	.1478	.1867	.1886
14	.1463	.1132	.1646	.1478	.1307	.1132	.336
15	.1463	.1132	.0914	.1494	.1509	.0732	.1828
16	.1463	.1867	.1715	.1494	.1509	.0554	.3018
17	.1463	.1698	.1829	.1307	.1307	.0876	.336
18	.2195	.3174	.2801	.2427	.1867	.2075	.6036
19	.2926	.2801	.2614	.2829	.1867	.2263	.6096
20	.1867	.2263	.2452	.1867	.2054	.2075	.4904
21	.1663	.1698	.1509	.1509	.1829	.1524	.336
22	.1294	.1509	.112	.1494	.1097	.0934	.2264
23	.1109	.1132	.0934	.1132	.1109	.0754	.2264
24	.1097	.1097	.1132	.0754	.0747	.1109	.0549
Max	.2926	.3174	.2801	.2829	.2054	.2263	.6096
Min	.1097	.1097	.0914	.0754	.0747	.0554	.0549
Avg	.1455	.1591	.1495	.1341	.1297	.1307	.2090

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-Station****Feeder No / Name : 402 / 33 KV Parsodi Feeder
Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0288	.9145	.8002	.9145	.8573	.743
2	1.086	1.0288	.9145	.8573	.9145	.8002	.743
3	1.086	.9717	.9145	.8573	.9145	.8573	.743
4	1.086	1.0288	.8573	.8573	.9145	.8573	.8002
5	1.1431	1.086	.9717	.9717	1.1431	1.0288	.8573
6	1.3146	1.3717	1.1431	1.2003	1.3717	1.2574	1.086
7		.5144	.5144	.5716	.4572	.5144	1.086
8	1.7147	1.829	2.0576	1.829	1.6004	1.6575	1.5432
9	2.0005	2.2862	2.3434	1.9433	2.1719	2.0005	1.9433
10	2.1148	2.4577	2.4577	2.2862	2.1719	2.3434	2.1719
11	2.0576	2.6292	2.3434	2.2862	2.3434	2.3434	2.2862
12	1.9433	2.572	2.3434	2.1148	2.2862	1.4289	2.0576
13	1.8861	2.572	2.4577	2.0005	2.2291	1.9433	1.829
14	1.829	2.5149	2.4006	1.829	2.0576	1.8861	1.6004
15	1.7718	2.3434	2.2862	1.8861	1.7718	1.7147	1.3146
16	.2858	.5716	.5144	.5716	.4572	.4001	.4001
17	.3429	.6859	.6287	.6287	.5144	.4572	.5144
18	1.0288	1.086	1.0288	1.0288	.9717	.9717	.9717
19	.9717	.9717	.9717	.9717	.9717	.9717	.9717
20	.8573	.8573	.8002	.8002	.8002	.8002	.8573
21	.6287	.5716	.5716	.5716	.5716	.6287	.6287
22	.4572	.4572	.4572	.4001	.4001	.4001	.4001
23	.8002	.8573	.8002	.6859	.8002	.6859	.6859
24	.9145	.5716	.8573	.8002	.8573	.8002	.743
Max	2.1148	2.6292	2.4577	2.2862	2.3434	2.3434	2.2862
Min	.2858	.4572	.4572	.4001	.4001	.4001	.4001
Avg	1.2326	1.3694	1.3146	1.1979	1.2336	1.1503	1.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-Station****Feeder No / Name : 403 / 33 KV Lakhandur Feeder NON SHEDDABLE EXPRESS HV FEEDERS
Incomer Feeder KV- 33 / INCOMING (CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.9145	1.0288	.8573	.743	.6859	.743
2	.6859	.9145	1.0288	.8573	.743	.6859	.6859
3	.6859	.9145	1.0288	.8573	.743	.6859	.743
4	.6859	.9717	1.0288	.8573	.8002	.743	.6859
5	.6859	.9717	1.086	.9145	.8002	.743	.743
6	.8573	1.1431	1.2003	1.1431	.9717	.9717	.9717
7	.743	.8002	.8573	.8573	.8573	.8002	.8002
8	1.1431	1.0288	1.2003	1.0288	1.2574	1.3717	1.3146
9	1.3146	1.1431	1.2003	1.086	1.4861	1.4861	1.4861
10	1.3717	1.3146	1.3146	1.0288	1.5432	1.4289	1.6004
11	1.3717	1.3717	1.2574	1.086	1.6004	1.5432	1.6575
12	1.2003	1.3717	1.2574	1.1431	1.7718	1.6004	1.5432
13	1.4289	1.4861	1.2574	1.2574	1.5432	1.4861	1.6004
14	1.4289	1.3717	1.2003	1.2574	1.6004	1.5432	1.3146
15	1.3146	1.2574	1.0288	1.2003	1.4861	1.4289	1.3146
16	.8573	1.0288	.6859	.9145	.9145	.8002	.6287
17	.8573	1.086	.9145	.9717	.9717	.9145	.743
18	1.2574	1.4861	1.2003		1.2574	1.3717	1.1431
19	1.3146	1.4289	1.2003	1.3146	1.1431	1.3146	1.2003
20	1.086	1.086	1.086	1.3146	.9717	1.0288	1.1431
21	.9145	.9717	.9145	.9145	.8002	.8573	.8573
22	.8002	.8573	.8002	.8002	.6859	.743	.743
23	.743	.9717	.9145	.8002	.743	.743	.743
24	.6859	.743	1.0288	.9145	.8573	.743	.6859
Max	1.4289	1.4861	1.3146	1.3146	1.7718	1.6004	1.6575
Min	.6859	.743	.6859	.8002	.6859	.6859	.6287
Avg	1.0050	1.1098	1.0717	1.0164	1.0955	1.0717	1.0455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-Station****Feeder No / Name : 404 / 33 KV BARWA FEEDER
Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429	.4001	.4001	.4572	.4572	.4572
2	.3429	.3429	.4001	.3429	.4572	.4572	.4572
3	.4001	.3429	.4001	.3429	.1715	.4572	.4572
4	.4001	.3429	.4001	.3429	.1715	.4572	.4572
5	.4572	.3429	.4572	.4001	.4572	.4572	.4572
6	.5144	.3429	.5144	.4572	.5716	.5716	.5716
7	.4001	.2286	.2286	.2858	.5716	.2858	.2858
8	.5716	.4572	.6859	.6287	.4001	.4572	.4572
9	.743	.6859	.8002	.6859	.743	.5144	.5716
10	.8002	.8573	.9145	.8002	.8573	.6287	.6287
11	.743	.8573	1.0288	.2286	.9145	.6859	.6859
12	.8573	.9145	1.0288	.9145	.9145	.6859	.5144
13	.6859	.9717	.9717	.8573	.8573	.5716	.6287
14	.6287	.8573	.9717		.6859	.6287	.743
15	.6287	.9145	.9717	.8573	.6859	.5716	.6859
16	.2858	.3429	.2858	.3429	.1715	.2286	.2858
17	.2858	.2286	.3429	.2858	.1715	.2286	.3429
18	.6287	.6859	.6287	.6859	.5716	.6287	.6287
19	1.7147	.5716	.6287	.6287	.6287	.6287	.6287
20	1.3146	.5144	.5144	.5144	.5144	.5144	.5144
21	1.086	.3429	.3429	.4001	.4001	.3429	.4001
22	.8002	.2286	.4572	.2858	.2858	.2286	.2286
23	.6859	.4001	.3429	.3429	.4572	.4572	.4001
24	.4001	.6859	.4001	.3429	.5144	.4572	.4572
Max	1.7147	.9717	1.0288	.9145	.9145	.6859	.743
Min	.2858	.2286	.2286	.2286	.1715	.2286	.2286
Avg	.6549	.5334	.5882	.4945	.5263	.4834	.4977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKHANDUR S/DN.[385] BU 0385****Substation No/ Name :- 067017 / 132 KV Lakhandur Sub-Station****Feeder No / Name : 405 / 33 KV KESHORI FROM LAKHANDUR Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6287	.6287	.6287	.6859	.6287	.5144
2	.743	.6287	.6287	.6287	.6859	.6287	.5144
3	.743	.6287	.6287	.6287	.6859	.6287	.5144
4	.743	.6859	.6287	.6287	.6859	.6287	.5144
5	.8002	.743	.6859	.6859	.743	.6859	.6287
6	.9145	.9717	.9145	.8573	.9145	.9145	.8002
7	.9145	.6287	.9145	.8573	.9145	.9145	.8573
8	.9717	1.0288	.9717	.9145	.9145	1.0288	.8573
9	1.0288	1.2003	1.1431	1.1431	1.3717	1.0288	.9717
10	1.1431	1.2003	1.1431	1.3146	1.3146	1.1431	1.1431
11	.5716	1.0288	1.086	.8573	1.3146	1.2003	1.3146
12	.743	1.086	.743	.8573	1.2574	1.3146	1.2003
13	1.0288	1.086		1.2003	1.4289	1.2003	1.2003
14	1.2003	1.1431	1.3717	1.2574	1.2574	1.2574	1.3146
15	1.1431	.8002	1.3146	1.4289	1.2574	1.1431	1.3146
16	1.0288	1.2003	1.3717	1.3146	1.3717		1.3717
17	1.3146	1.4289	1.3146	1.4861	1.2003	1.1431	1.3717
18	1.7147	1.829	1.7147	1.7718	1.6004	1.1431	1.7147
19		1.6004	1.7147	1.829	1.4861	1.5432	1.7147
20		1.3717	1.3717	1.3146	1.3146	1.3146	1.4289
21		1.0288	1.086	1.0288	.9717	.8573	1.1431
22		.8002	.8002	.8002	.743	.6287	.743
23		.6859	.6859	.6287	.6287	.5716	.6859
24	.5716		.6287	.6287	.6287	.6287	.5144
Max	1.7147	1.829	1.7147	1.829	1.6004	1.5432	1.7147
Min	.5716	.6287	.6287	.6287	.6287	.5716	.5144
Avg	.9506	1.0189	1.0214	1.0288	1.0574	.9642	1.0145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s****Feeder No / Name : 201 / 11 KV Palandur****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.3224	.2835	.3292		.0905	.0895
2	.0876	.3224	.2835	.3109	.1075	.0905	.0895
3	.0876	.3224	.3012	.3109	.1075	.1086	.0895
4	.0876	.3658	.3189	.3292	.1075	.1086	.0895
5	.1052	.4024	.3366	.3658	.1254	.1267	.1075
6	.1227	.4024	.3544	.3841	.1254	.1267	.1254
7	.1063	.124	.124	.1254	.1254	.1267	.1254
8	.4252	.1063	.1063	.1075	.3721	.4706	.4119
9	.4961	.124	.1063	.1109	.4525	.5068	.4298
10	.4784	.1063	.1063	.1075	.4706	.5068	.4835
11	.4784	.1063	.1075	.1075	.543	.4887	.4835
12	.4607	.0886	.1075	.1086	.5249	.543	.5194
13	.4961	.1063	.1075		.5249	.5316	.4835
14	.4784	.1063	.1075		.4887	.5138	.4835
15		.0709	.0895		.4706	.4075	.4477
16	.0886	.0886	.1075	.1448	.0905	.1063	.0895
17	.1063	.1063	.1075	.1267	.1086	.124	.1075
18	.2427	.2303	.2328	.2353	.2353	.2303	.2561
19	.2427	.2481	.2328	.2534	.2353	.2303	.2743
20	.2054	.1949	.2149	.2172	.1991	.2126	.2195
21	.168	.1417	.1612	.1629	.1448	.1595	.1646
22	.112	.124	.1267	.1086	.1086	.1063	.1097
23	.3361	.3012	.3292		.0905	.0886	.0914
24	.0876	.3224	.3012	.3292		.0905	.0886
Max	.4961	.4024	.3544	.3841	.543	.543	.5194
Min	.0876	.0709	.0895	.1075	.0905	.0886	.0886
Avg	.2429	.2014	.1939	.2138	.2618	.2540	.2442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s****Feeder No / Name : 202 / 11 KV Maregaon****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3988	.0686	.052	.0514		.4917	.407
2	.3988	.0686	.052	.0514	.5144	.4748	.4024
3	.3988	.0686	.0693	.0514	.5144	.4748	.4024
4	.4161	.0857	.0693	.0686	.5144	.4917	.4527
5	.4161	.0857	.0867	.0857	.5487	.5087	.4862
6	.4161	.0857	.0867	.1029	.583	.5087	.5197
7	.1029	.0857	.0693	.0686	.0709	.0848	.0838
8	.12	.4334	.6415	.6001	.0709	.0848	.0671
9	.0514	.4161	.7802	.7716	.0671	.0848	.0838
10	.0343	.7628	.7975	.7373	.0671	.0678	.0671
11	.0343	.8322	.8149	.823	.0671	.0678	.0671
12	.0514	.9189	.8669	.8309	.0671	.0678	.0503
13	.0514	.9015	.8478		.0503	.0709	.0503
14	.0686	.8842	.8139		.0503	.0709	
15	.0514	.8669	.78		.0671		
16	.0857	.0693		.6274	.0671	.0532	
17	.0686	.0693		.5935	.0848	.0709	.0663
18	.1543	.156	.1734		.1526	.1696	.1677
19	.1543	.156	.1734	.1543	.1696	.1357	.1677
20	.1372	.1387	.1214	.1372	.1526	.1357	.1341
21	.12	.0867	.0867	.0857	.1017	.1017	.0838
22	.0686	.0693	.0686	.0686	.0848	.0678	.0747
23	.0686	.052	.0514	.5144	.4748	.407	.3601
24	.3988	.0686	.052	.0514		.4917	.407
Max	.4161	.9189	.8669	.8309	.583	.5087	.5197
Min	.0343	.052	.0514	.0514	.0503	.0532	.0503
Avg	.1778	.3096	.3434	.3238	.2064	.2254	.2191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s****Feeder No / Name : 203 / 11 KV Gondegaon****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6405	.0905	.0754	.0819		.6401	.502
2	.6562	.0914	.0754	.0819	.7973	.6401	.5182
3	.6562	.0914	.0943	.0655	.7973	.6562	.5182
4	.6562	.0914	.0943	.0655	.8505	.6882	.5243
5	.6874	.1097	.1132	.0983		.7042	.5898
6	.7186	.1463	.132	.1311	.9391	.7202	.6718
7	.0934	.1097	.1132	.1307	.1097	.1132	.0934
8	.0934	.8122	.9831	1.0029	.1097	.1132	.112
9	.0934	.8951	1.1305	.9671	.0934	.1132	.0934
10	.0934	1.0774	.9667	.9488	.0934	.0943	.0934
11	.0934	1.0774	1.0814	.9488	.1132	.0754	.0663
12		1.094	1.0526	.8962	.0754	.0754	.0663
13	.0747	1.094	1.0279		.0566	.0754	.0663
14	.0934	1.094	1.0911		.0754	.0754	.0663
15	.0747	.9779	1.0279		.0754	.0754	.0663
16	.056	.0754	.0754	.9393	.0754	.0566	.0663
17		.0943	.0943	.9231	.1132	.0566	.0829
18	.2801	.2829	.3018	.2686	.2829	.3018	.2652
19	.3174	.3018	.3018	.2865	.3018	.2829	.2652
20	.2801	.2641	.2452	.2507	.2452	.2641	.2321
21	.2172	.1698	.1698	.1791	.1698	.1886	.1492
22	.1267	.1132	.0995	.1075	.1132	.1132	.1132
23	.0905	.0943	.0829	.7209	.631	.502	.57
24	.6405	.0905	.0943	.0838		.6562	.4902
Max	.7186	1.094	1.1305	1.0029	.9391	.7202	.6718
Min	.056	.0754	.0754	.0655	.0566	.0566	.0663
Avg	.3061	.4308	.4385	.4371	.2914	.3034	.2618

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s****Feeder No / Name : 204 / 11 KV Murmadi Tupkar AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4161	.4161	.3715			
2		.4161	.4161	.3715			
3		.4458	.431	.3715			
4		.4458	.431	.3715			
5		.4607	.4458	.3864			
6		.4607	.4458	.3864			
8	.5376				.4548	.5624	.5093
9	.6167				.578	.5937	.571
10	.9659				.6405	.578	.6327
11	.9922				.6249	.6009	.6327
12	.6882				.6874	.6167	.6481
13	.6882				.703	.7202	.6481
14	.3841				.6562	.7842	.6327
15	.192				.6249	.6562	.5864
23	.4161	.431	.3864				
24		.4161	.4161	.3715			
Max	.9922	.4607	.4458	.3864	.703	.7842	.6481
Min	.192	.4161	.3864	.3715	.4548	.5624	.5093
Avg	.609	.4365	.4235	.3758	.6212	.6390	.6076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s

Feeder No / Name : 205 / 11 KV MURMADI GAOTHON

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /
OUTGOING

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554	.2772	.2957	.2957		.2587	.2772
2	.0554	.2772	.3142	.2772	.2772	.2772	.2772
3	.0554	.3326	.3142	.2772	.2772	.2772	.2772
4	.0739	.3511	.3326	.3142	.3696	.2957	.2957
5	.0924	.4066	.3696	.4251	.3881	.3511	.3326
6	.1109	.4066	.3881	.4435	.3881	.4066	.3881
7	.1109	.4066	.4251	.4251	.3881	.3881	.3696
8	.1109	.3881	.4066	.3881	.3881	.3696	.3881
9	.1109	.4435	.4251	.3696	.4251	.3696	.3696
10	.1294	.5359	.4251	.4435	.4805	.4435	.4435
11	.1848	.4805	.5359	.4805	.4805	.3881	.4435
12	.3326	.4066	.4435	.4435	.4435	.3696	.4435
13	.2957	.4251	.4435		.4066	.3142	.462
14	.2957	.4435	.3696			.3511	.4435
15	.3142	.4066	.4435		.4435	.3696	.4066
16	.3696	.462	.3326	.5729	.4066	.3511	.5359
17	.4251	.5544	.499	.5729	.4251	.4805	.5359
18	.7947	.9055	.8871	.9425	.7762	.8501	.7947
19	.7762	.8871	.8316	.7762	.7947	.7947	.8686
20	.6653	.6653	.6653	.6653	.6283	.7207	.6468
21	.462	.4805	.4805	.4706	.462	.4805	.4805
22	.3326	.3696	.3511	.3326	.3326	.3142	.3511
23	.2957	.3142	.2772		.2772	.2587	.2957
24	.037	.2772	.2957	.2957		.2587	.2772
Max	.7947	.9055	.8871	.9425	.7947	.8501	.8686
Min	.037	.2772	.2772	.2772	.2772	.2587	.2772
Avg	.2703	.4543	.4397	.4606	.4409	.4058	.4335

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064008 / 33/11 KV PALANDUR S/s****Feeder No / Name : 403 / 33 KV PALANDUR (Incomer) NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / INCOMING (CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2071	1.1568	1.1065	1.1065		1.4752	1.2574
2		1.1568	1.1568	1.1065	1.6461	1.4752	1.2574
3	1.2071	1.2431	1.2071	1.0562	1.6461	1.5261	1.2574
4	1.2574	1.2929	1.2574	1.1568	1.749	1.5769	1.358
5	1.3077	1.3923	1.358	1.358	1.8519	1.6787	1.4586
6	1.4083	1.442	1.4083	1.4083	1.9547	1.7804	1.6598
7	.4024	.6464	.6539	.7042	.6173	.6613	.6036
8	1.2574	1.6598	2.1125	1.9616	1.3889	1.5769	1.4586
9	1.358	1.8107	2.4143	2.1125	1.5947	1.6278	1.5089
10	1.7604	2.4143	2.2634	2.2131	1.7295	1.6787	1.5089
11	1.7604	2.4143	2.4646	2.3137	1.7804	1.5769	1.7101
12	1.5592	2.4646	2.4143	1.7804	1.7804	1.6278	1.7101
13	1.5592	2.4646	2.3594		1.7295	1.6787	1.6598
14	1.2574	2.4646	2.3594		1.6787	1.7804	1.6095
15	1.0059	2.2634	2.364		1.6787	1.5769	1.4586
16	.5533	.6539	.4527	2.2382	.6104	.5087	.6036
17	.5533	.7545	.6539	2.1874	.6613	.6613	.7042
18	1.3077	1.4586	1.4586	1.4752	1.3226	1.4243	1.358
19	1.358	1.4586	1.4083	1.3735	1.3735	1.3735	1.4586
20	1.1568	1.1568	1.1568	1.17	1.1191	1.2209	1.1568
21	.8551	.8048	.8048	.8745	.8139	.8648	.8048
22	.5533	.6036	.6036	.5658	.6104	.5596	.5533
23	1.1568	1.2071	1.1065	1.5947	1.4243	1.2717	1.2431
24	1.2071	1.1568	1.1568	1.1065		1.5261	1.2574
Max	1.7604	2.4646	2.4646	2.3137	1.9547	1.7804	1.7101
Min	.4024	.6036	.4527	.5658	.6104	.5087	.5533
Avg	1.1743	1.4809	1.4876	1.4697	1.3982	1.3629	1.2757

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 201 / 11 KV SINDHIPAR AGP FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1646	.1334	.1467			
2		.1646	.1315	.1509			
3		.1646	.1296	.1372			
4		.1646	.1276	.1372			
5			.1315	.1391			
6		.1488	.1334	.1372			
8	.1833				.1882	.2143	.2086
9	.2229				.2462	.2286	.2317
10	.2225				.2572	.2526	.2317
11	.2397				.2787	.2526	.2429
12	.2256				.2787	.2709	.2462
13	.2058				.2824	.2378	.2286
14	.2195				.2787	.2494	.2429
15	.2029				.2787	.2526	.2364
23		.1334	.1467	.1593			
24			.1166	.1467	.1448		
Max	.2397	.1646	.1467	.1593	.2824	.2709	.2462
Min	.1833	.1334	.1166	.1372	.1448	.2143	.2086
Avg	.2153	.1568	.1313	.1443	.2482	.2449	.2336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 202 / 11 KV RENGEPAR FEEDER AGP****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108				.5601	.381	.3921
2	.415				.5415	.381	.3881
3	.415				.5359	.381	.3696
4	.4108				.5175	.381	.3658
5	.5601				.5121	.381	.3734
6	.5975				.567	.362	.3734
8		1.0608	1.0242	.9335			
9		1.1157	1.0791	.9511			
10		1.2071	1.1222	.9877			
11		1.1888	1.0974	1.0059			
12		1.1706	1.0791	1.0242			
13		1.1946	.9231	.9877			
14		1.134	.9774	.9328			
15		1.0608	.8686	.8326			
23	.6535				.3734	.3921	.4294
24	.3921	.6535				.381	.3734
Max	.6535	1.2071	1.1222	1.0242	.567	.3921	.4294
Min	.3921	.6535	.8686	.8326	.3734	.362	.3658
Avg	.4819	1.0873	1.0214	.9569	.5154	.3800	.3832

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 203 / 11 kv lakhori AG feeder****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4904		.4294			
2		.4904		.4251			
3		.4904		.4066			
4		.4715		.4066			
5		.4715		.4251			
6		.4715		.4481			
8	.567				.547	.5847	.4755
9	.679				.6979	.6413	.5068
10	.6979				.7468	.6224	.5415
11	.7167				.7922	.6602	.5847
12	.6602				.8299	.6413	.5847
13	.679				.7922	.6348	.6413
14	.4075				.7468	.6036	.679
15	.3814				.6602	.5847	.6602
16			.5093				
23			.4481	.4908			
24				.4294	.4031		
Max	.7167	.4904	.5093	.4908	.8299	.6602	.679
Min	.3814	.4715	.4481	.4066	.4031	.5847	.4755
Avg	.5986	.4810	.4787	.4326	.6907	.6216	.5842

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 204 / 11 KV LAKHORI GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0373	.0373	.0377	.0373
2	.0377	.0377	.0377	.0373	.0373	.0381	.0373
3	.0377	.0377	.0377	.0377	.0185	.0191	.0366
4	.0377	.0373	.0377	.0189	.0185	.0191	.0183
5	.0566	.0373	.0377	.0373	.0549	.0377	.0183
6	.0566	.0373	.0377	.0377	.0549	.0377	.056
7	.0377	.0373	.0377	.0373	.0377	.0381	.0373
8	.037	.0377	.0377	.0381	.0377	.0381	.0373
9	.0377	.056	.0377	.0566	.0566	.0373	.0373
10	.0381	.0377	.0373	.0566	.0377	.0381	.0377
11	.0381	.0377	.0377	.0381	.0377	.0554	.037
12	.0381	.0377	.0377	.0381	.0377	.0377	.037
13	.0381	.0377	.0377	.0381	.0377	.0377	.0377
14	.0381	.0377	.0377	.0377	.0377	.0377	.0377
15	.0381	.0377	.0377	.0381	.0377	.0373	.0377
16	.0373	.0377	.0377	.0377	.0377	.0377	.0377
17	.0532	.0566	.0373	.037	.0566	.0373	.0566
18	.0943	.0943	.0943	.0943	.0943	.0943	.0754
19	.0754	.0754	.0739	.0943	.0943	.0934	.0943
20	.0754	.0754	.0754	.0754	.0754	.0747	.0754
21	.0754		.0566	.056	.0566	.056	.0566
22	.0566	.0377	.056	.0373	.0377	.0373	.0377
23	.0377	.0377	.0377	.0377	.0377	.0373	.0377
24	.0373	.0377	.0377	.0373		.0377	.0373
Max	.0943	.0943	.0943	.0943	.0943	.0943	.0943
Min	.037	.0373	.0373	.0189	.0185	.0191	.0183
Avg	.0478	.0450	.0447	.0455	.0465	.0439	.0437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 205 / 11 KV RENGEPAR GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1063	.0914	.0732	.1075	.0924	.0543
2	.112	.1063	.0905	.0739	.0905	.0924	.0549
3	.112	.1075	.0905	.0554	.0905	.0732	.0549
4	.112	.1254	.0914	.0554	.0724		.0724
5	.128	.1463	.1294	.0943	.0732	.1109	.1097
6	.1463	.1478	.128	.132	.1463	.1463	.1463
7	.1307	.1254	.1294	.1307	.1463	.1097	.1463
8	.1307	.128	.0934	.1307	.1267	.0366	.128
9	.1478	.1494	.0934	.1478	.1478	.1463	.1294
10	.1463	.1267	.1294	.1417	.156	.1629	.132
11	.128	.1448	.1294	.1663	.1433	.1463	.1254
12	.128	.1463	.128	.1663	.1433	.1267	.1433
13	.1463	.1063	.1227	.1478	.1433	.1267	.1509
14	.128	.1075	.124	.1463	.1433	.1267	.124
15	.1097	.1227	.1017	.1463	.1214	.1433	.1387
16	.1097	.1448	.104	.1646	.1214	.1174	.1402
17	.1463	.1646	.1494	.1629	.2172	.1753	.2012
18	.2641	.2641	.2427	.2829	.2801	.2614	.2378
19	.2801	.2263	.2427	.2987		.2427	.2641
20	.2218	.2075	.2263	.2427	.2195	.2033	.2427
21	.1848	.1494	.1478	.2054	.1478	.128	.1867
22	.1294	.128	.128	.1629	.1109	.0895	.1494
23	.1097	.0739	.1097	.1254	.1097	.0716	.0934
24	.1097	.104	.1109	.0732	.1075	.1097	.0543
Max	.2801	.2641	.2427	.2987	.2801	.2614	.2641
Min	.1097	.0739	.0905	.0554	.0724	.0366	.0543
Avg	.1447	.1400	.1306	.1470	.1376	.1321	.1367

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064021 / 33/11 KV SALEBHATA S/S****Feeder No / Name : 401 / 33 KV Salebhata Incomer****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.8578	2.0576	2.6292	2.2862	1.6575	1.7718
2	2.0576	2.8578	2.0576	2.6292	2.1719	1.5432	1.7718
3	2.0576	2.8578	2.0576	2.5149	1.6575	1.5432	1.7718
4	2.0005	2.8578	2.0005	2.5149	1.6004	1.5432	1.6575
5	2.1148	2.8578	2.1719	2.7435	1.5432	1.829	1.7718
6	2.2291	2.9721	2.3434	2.8578	1.8861	1.9433	1.9433
7	.9145	.9145	.9717	1.086	.9145	.9717	.9145
8	3.3722	2.7435	2.6863	2.5149	2.0005	3.658	3.2579
9	3.8866	3.0293	3.0293	2.8578	3.7151	4.0009	3.7723
10	4.0581	2.8018	3.2579	3.0293	3.7151	3.8295	3.3196
11	3.658	2.7526	3.1436	2.6292	4.1152	4.2867	3.4202
12	3.8866	2.8018	3.1436	2.9721	4.2295	4.2295	3.4705
13	3.9438	3.0293	3.0864	2.8006	4.4582	3.3722	3.4705
14	2.6863	2.915	2.9721	2.6863	4.401	3.8866	3.3488
15	3.315	2.915	2.6863	2.6292	4.1152	3.658	3.4705
16	.9717	1.086	1.5432	1.086	1.0288	1.086	.9054
17	1.1431	1.2003	1.6004	1.2574	1.1431	1.1431	1.0562
18	1.4289	1.6575	1.4289	1.5432	1.7147	1.5432	1.3523
19	1.4861	1.4861	1.6004	1.4861	1.5432	1.4289	1.382
20	1.3717	1.3146	1.3717	1.3146	1.2574	1.2574	1.262
21	1.2003	1.086	1.0288	1.1431	1.0288	.9717	.9568
22	.9145	.8002	.9145	.9145	.8573	.8573	.7973
23	1.829	2.1148	2.6863	2.4006	1.7147	1.7718	1.7147
24	2.0576	1.7718		2.6292	2.2862	1.7147	1.7718
Max	4.0581	3.0293	3.2579	3.0293	4.4582	4.2867	3.7723
Min	.9145	.8002	.9145	.9145	.8573	.8573	.7973
Avg	2.2767	2.2367	2.1670	2.2029	2.3077	2.2386	2.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S****Feeder No / Name : 201 / 11 KV RAJEGAON AGP FEEDER****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6546	.7167	.5705			
2		.6452	.6979	.569			
3		.6405	.6979	1.3509			
4		.6421	.6979	.5676			
5		.6405	.7167	.5676			
6		.6358	.7545	.5589			
8	.733				.7984	.9145	.9796
9	.7862				.948	.9907	1.0387
10	.9059				.7674	1.2127	1.0781
11	.8951				.9746	1.2036	1.1157
12	.9105				1.0138	1.1819	1.1157
13	.8642				1.2071	1.1276	1.1408
14	.8025				1.2641	1.1656	1.1336
15	.7716				1.2123	1.0805	1.0835
23		.5944	.5705	.5472			
24			.7167	.5719	.5312		
Max	.9105	.6546	.7545	1.3509	1.2641	1.2127	1.1408
Min	.733	.5944	.5705	.5472	.5312	.9145	.9796
Avg	.8336	.6362	.6961	.6630	.9685	1.1096	1.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S****Feeder No / Name : 202 / 11 KV MANEGAON FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.204	.2051	.1578	.1955	.1578	.2033	.18
2	.2058	.1998	.1595	.1903	.1594	.2033	.1783
3	.2092	.1946	.1595	.1852	.1576	.1848	.1766
4	.2178	.1946	.1595	.1869	.161	.1848	.1732
5	.2212	.2051	.1791	.1852	.1683	.2218	.2212
6	.2229	.2486	.197	.2075	.2024	.2957	.2366
7	.2195	.2611	.2507	.2521	.2203	.2772	.2503
8	.2589	.2442	.2507	.2623	.2381	.2957	.2532
9	.274	.3258	.2721	.2625	.2548	.3142	.2733
10	.2686	.373	.3401	.2758	.2783	.2572	.332
11	.2686	.3493	.3336	.3315	.3205	.3515	.3236
12	.3077	.3048	.3838	.3149	.3781	.3172	.3353
13	.2715	.2474	.3304	.3149	.3412	.3601	.3253
14	.3258		.3287	.2347	.332	.2949	.3051
15	.2896	.3113	.3273	.2984	.3219	.3927	.2864
16	.3258	.3244		.2652	.2884	.3909	.3806
17	.3304	.3326	.3756	.3277	.2966	.3961	.3239
18	.389	.3768	.3957	.4435	.4435	.4921	.5156
19	.3841	.3768	.4108	.3936	.3881	.3807	.4583
20	.3475	.3441	.3286	.3567	.3696	.3241	.3622
21	.3054	.2683	.2716	.2787	.3326	.2692	.3216
22	.2542	.218	.233	.2244	.2772	.216	.255
23	.1992	.1677	.1962	.1727	.2402	.1903	.2218
24	.2006	.2045	.1677	.1972	.1576	.2402	.1818
Max	.389	.3768	.4108	.4435	.4435	.4921	.5156
Min	.1992	.1677	.1578	.1727	.1576	.1848	.1732
Avg	.2709	.2730	.2700	.2649	.2702	.2939	.2863

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S****Feeder No / Name : 203 / 11 KV PATACHI TOLI FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1281	.1665	.1423	.1492	.1221	.1094	.1218
2	.1281	.1647	.1457	.1492	.1204	.0937	.1218
3	.1297	.1593	.1457	.1475	.1187	.0983	.1202
4	.1297	.1542	.1475	.1475	.1153	.0983	.1202
5	.1312	.163	.1638	.1576	.1204	.1174	.1376
6	.1328	.1102	.1802	.1593	.1343	.1543	.1439
7	.155	.1294	.1966	.1693	.1558	.1372	.1613
8		.1638	.1966	.1827	.1619	.1715	.1518
9	.2103	.1475	.2056	.1851	.1717	.2058	.1834
10	.2069	.1671	.2056	.2125	.183	.1715	.2024
11		.1051	.1834	.1875	.166	.1869	.2008
12	.1715	.1471	.2024	.1875	.1787	.1968	.1976
13	.2229	.0727	.1882	.1718	.1733	.1872	.1668
14	.2229		.2198	.2031	.1834	.1824	.1945
15	.1543	.1154	.2027	.1875	.2024	.1712	.1895
16	.2401	.1502	.2392	.2187	.2099	.1856	.1471
17	.2203	.2562	.1933	.2294	.2314	.1984	.1518
18	.2638	.2743	.254	.2647	.2601	.2225	.2481
19	.2664	.2743	.2441	.2471	.2601	.2196	.2534
20	.2471	.2347	.231	.2279	.2254	.1978	.2268
21	.2121	.218	.1983	.1794	.1907	.1677	.1949
22	.1875	.1865	.1753	.1559	.1387	.1492	.1736
23	.1594	.1696	.1491	.1294	.108	.1265	.1595
24	.1265	.1619	.1372	.1492	.1196	.108	.1218
Max	.2664	.2743	.254	.2647	.2601	.2225	.2534
Min	.1265	.0727	.1372	.1294	.108	.0937	.1202
Avg	.1839	.1692	.1895	.1833	.1688	.1607	.1704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S****Feeder No / Name : 204 / 11 KV NILAGONDI GAOTHAN****GAOTHAN FEEDER****FEEDER Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1288	.1238	.1132	.1301	.066	.1494	.1312
2	.1288	.1433	.1132	.1301	.0622	.1307	.1294
3	.127	.1716	.0943	.1113	.0622	.112	.1257
4	.127	.1848	.0754	.1113	.0641	.112	.1238
5	.127	.1641	.0934	.1301	.1083	.132	.1201
6	.1326	.2018	.1307	.1566	.1774	.1698	.1146
7		.1307	.1848	.1377	.1774	.1509	.1201
8		.1774	.1294	.1773		.132	.1127
9	.1075	.1245	.1109	.1379		.112	.0906
10	.1301	.1471	.1478	.139	.1626	.1494	.0906
11	.112	.2035	.1448	.2012	.183	.2054	.0941
12	.1478	.2463	.1249	.1463	.2107	.1846	.114
13	.1848	.2197	.1864	.128	.1793	.152	.0905
14	.1478		.1882	.1646	.2236	.152	.0869
15	.1294	.1435	.1252	.1646	.146	.0905	.1176
16	.1478	.1754	.1368	.1848	.1792	.1394	.1205
17	.1919	.1914	.1663	.2303	.2054	.1683	.1347
18	.3167	.2328		.3169	.3174	.2624	.2565
19	.3131	.2534	.2791	.2754	.2987	.2565	.2848
20	.3018	.2353	.2452	.249	.2427	.2282	.2697
21	.2641	.2033	.1735	.1886	.1494	.2961	.2131
22	.198	.1478	.1377	.1438	.168	.1552	.1127
23	.1939	.1307	.1301	.0869	.1478	.1349	.1534
24	.1288	.1201	.1132	.1301	.1195	.1478	.1312
Max	.3167	.2534	.2791	.3169	.3174	.2961	.2848
Min	.1075	.1201	.0754	.0869	.0622	.0905	.0869
Avg	.1721	.1771	.1454	.1655	.1660	.1635	.1391

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S****Feeder No / Name : 205 / MANEGAON AGP****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5288				.2591	.3155	.356
2	.5288				.2591	.3155	.3574
3	.5288				.2591	.3155	.356
4	.5271				.259	.3155	.3574
5	.5254				.259	.3292	.3588
6	.5089				.255	.3429	.3602
8		.2954	.7087	.6148			
9		.6414	.779	.5405			
10		.6449	.703	.5674			
11		.6568	.64	.5639			
12		.6385	.6139	.5357			
13		.6588	.6023	.5075			
14			.5995	.5075			
15		.627	.5773	.4938			
23	.2201				.3067	.3525	.3361
24	.5288	.2186				.3155	.3498
Max	.5288	.6588	.779	.6148	.3067	.3525	.3602
Min	.2201	.2186	.5773	.4938	.255	.3155	.3361
Avg	.4871	.5477	.6530	.5414	.2653	.3253	.3540

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

LAKNI S/DN.[719]

BU 4719

Substation No/ Name :- 064023 / 33/11 KV PIMPALGAON S/S

Feeder No / Name : 401 / 33 KV Pimpalgao S/S

Incomer Feeder KV- 33 /
INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.709	1.5261	1.6804	.7487	.9031	.7552
2	1.1031	1.6975	1.5318	1.7375	.743	.9031	.7552
3	1.1031	1.6804	1.5146	1.7147	.743	.6687	.7469
4	1.1145	1.6518	1.4746	1.7147	.7373	.6644	.7427
5	1.1203	1.6975	1.5375	1.7318	.7487	.6944	.7969
6	1.1031	1.8061	1.7032	1.7718	.9145	.7673	.7302
7	.4001	.5658	.6173	.5887	.5716	.4501	.4089
8	2.1091	.9602	1.0961	1.246	1.8633	1.669	1.909
9	2.5034	1.4803	1.3911	1.4118	2.2177	1.8198	2.029
10	2.6235	1.5489	1.3911	1.4289	2.0976	2.3834	2.2577
11	2.3434	1.4918	1.337	1.3812	2.452	2.5606	2.3262
12	2.492	1.3861	1.3517	1.337	2.6635	2.5091	2.4577
13	2.4863	1.2583	1.3173	1.165	2.452	2.4806	2.3148
14	2.4806		1.3517	1.1748	2.5091	2.2462	2.3148
15	2.1719	1.219	1.2977	1.2338	2.3777	2.1491	2.1605
16	.663	.5997	.7888	.5701	.5316	.8002	.5487
17	.7888	.6488	.8002	.6773	.5744	.7659	.5401
18	1.0631	.698	.9945	1.0402	1.046	1.0574	1.0402
19	1.0002	.9044	1.0517	1.0117	.9831	.9602	1.046
20	.8973	.8061	.8631	.8745	.8631	.8288	.9431
21	.7659	.5997	.6916	.6973	.6973	.6459	.7316
22	.6344	.5259	.5773	.5601	.5944	.583	.5144
23	.7373	1.4234	1.4687	1.4575	.6859	.7416	1.046
24	1.0917	.7487	1.358	1.6804	1.4403	.9145	.7287
Max	2.6235	1.8061	1.7032	1.7718	2.6635	2.5606	2.4577
Min	.4001	.5259	.5773	.5601	.5316	.4501	.4089
Avg	1.4122	1.1786	1.2097	1.2453	1.3023	1.2569	1.2435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S****Feeder No / Name : 201 / 11 KV Adarsh Nagar****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1698	.1448	.128	.1294	.112	.1509
2	.1646	.1698	.1448	.128	.128	.112	.1509
3	.1646	.1509	.1448	.128	.128	.112	.1509
4	.1448	.1509	.1433	.128	.128	.112	.1509
5	.1448	.1509	.1612	.1494	.128	.1307	.1509
6	.1463	.1698	.1612	.1509	.132	.132	.168
7	.1991	.168	.1791	.1848	.1829	.1829	.2054
8	.181	.1867	.1991	.2054	.168	.1848	.2054
9	.2195	.2012	.2033	.1867	.2054	.2054	.2054
10	.2303	.1848	.2353	.2218	.2054	.2218	.197
11	.2058	.2172	.2587	.2587	.2561	.2353	.2012
12	.2058	.1478	.2353	.2715	.2303	.2195	.1772
13	.1612	.1595	.2195	.2033	.1949	.1494	.1132
14	.1629	.1294	.1991	.1629		.1663	.128
15	.2204	.1646	.2601	.2172	.2126	.2149	.1829
16	.2303	.2126	.2126	.2103	.2229	.2149	.1753
17	.2543	.208	.2321	.2279	.2601	.1646	.2743
18	.3326	.3292	.3142	.2987	.2987	.2561	.3292
19	.2987	.2801	.3142	.2987	.3206	.3018	.2957
20	.2987	.2614	.2772	.2801	.2641	.2829	.2743
21	.2427	.2402	.2427	.2241	.2241	.2452	.2353
22	.1867	.1848	.1848	.1867	.1867	.2075	.1991
23	.1867	.1448	.1646	.1494	.1294	.168	.181
24	.1646	.1867	.1448	.128	.1294	.1294	.132
Max	.3326	.3292	.3142	.2987	.3206	.3018	.3292
Min	.1448	.1294	.1433	.128	.128	.112	.1132
Avg	.2046	.1904	.2074	.1970	.1941	.1859	.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S****Feeder No / Name : 202 / 11 KV Alesur Gaothan****SEPARATED GAOTHAN FEEDERS****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0185	.0343	.0362	.0532	.0554
2		.0566	.0185	.0351	.0366	.0532	.056
3		.0566	.0185	.0351	.0366	.0354	.056
4	.037	.0566	.037	.0362	.0362	.0354	.0549
5	.037	.0566	.037	.0362	.0362	.0537	.0549
6	.0373	.0754	.037	.0549	.056	.0724	.0739
7	.0543	.0943	.0554	.0549	.0543	.0709	.0732
8	.0537	.0554	.0543	.0537	.0543	.0732	.0732
9	.0532	.0537	.0366	.0549	.0732	.0943	.0914
10	.0486	.0532	.037	.0537	.0732	.0943	.0747
11	.0324	.0354	.037	.0526	.0732	.112	.0886
12	.0351	.0347	.0358	.0358	.0532	.112	.132
13	.0347	.0354	.0362	.0373	.0543	.0754	.0373
14	.0343	.0339	.0362	.0373		.0686	.0543
15		.0503	.0526	.0373	.0549	.0732	.128
16	.0339	.0179	.0492	.0503	.0526	.0754	.0943
17	.0339	.0532	.0486	.0663	.0693	.0549	.0934
18	.0934	.1109	.128	.1097	.1097	.1791	.1075
19	.132	.112	.1109	.112	.1294	.132	.1132
20	.1132	.0943	.1097	.0934	.112	.0943	.0943
21	.1132	.0566	.0724	.0732	.0739	.0754	.0914
22	.0566	.0373	.0537	.0543	.0537	.0566	.0549
23	.0566	.037	.0351	.0354	.0526	.0366	.0554
24		.0566		.0343	.0179	.0526	.037
Max	.132	.112	.128	.112	.1294	.1791	.132
Min	.0324	.0179	.0185	.0343	.0179	.0354	.037
Avg	.0574	.0575	.0502	.0533	.0608	.0764	.0769

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S****Feeder No / Name : 203 / 11 KV Sanjay Nagar****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224	.362	.3012	.3045	.2926	.3258	.2829
2	.3224	.3658	.3012	.3045	.2926	.3258	.2743
3	.3224	.3658	.3012	.3077	.2926	.3292	.2801
4	.3544	.362	.3012	.3077	.2926	.3292	.2801
5	.3721	.362	.3189	.3475	.2926	.3292	.2743
6	.3982	.3801	.3544	.4066	.3547	.3475	.3326
7	.4706	.462	.4252	.4435	.4668	.4938	.4481
8	.4887	.4805	.4887	.4805	.4668	.4572	.4481
9	.4887	.4755	.5014	.462	.4854	.462	.4715
10	.5068	.5121	.5611	.499	.5175	.4755	.4527
11	.4572	.5611	.6036	.5068	.6908	.4887	.5415
12	.4572	.5853	.5611	.5121	.5729	.567	.462
13	.3982	.4887	.5068	.4938		.4805	.4481
14	.3982	.439	.4656	.4066		.4251	.4024
15	.3814	.5083	.5121	.4251	.695	.4108	.4108
16	.4287	.4477	.443	.4525	.5138	.439	.462
17	.4733	.5609	.5144	.5121	.4961	.439	.5552
18	.6283	.6584	.7207	.6838	.7133	.7023	.7133
19	.6099	.5914	.6283	.6767	.6653	.6413	.6584
20	.5729	.5544	.5729	.5847	.5914	.5281	.6219
21	.5121	.5121	.499	.5093	.5175	.4904	.5487
22	.4163	.4163	.4024	.3921	.3841	.3921	.439
23	.4024	.3403	.3403	.3174	.3439	.3174	.3721
24	.3224	.3801	.3012	.3045	.2987	.3439	.2829
Max	.6283	.6584	.7207	.6838	.7133	.7023	.7133
Min	.3224	.3403	.3012	.3045	.2926	.3174	.2743
Avg	.4377	.4655	.4552	.4434	.4653	.4392	.4360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064037 / 33/11 KV LAKHORI S/S****Feeder No / Name : 401 / 33 KV Lakhori (Incomer)****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4835	.6036	.4835	.4784	.439	.4938	
2	.4835	.6036	.4835	.4835	.4298	.4938	.5041
3	.4835	.5487	.4835	.4887	.439	.4938	.5041
4	.5316	.5487	.4784	.4938	.439	.4938	.5041
5	.5316	.5487	.5316	.5487	.439	.4938	.5041
6	.5973	.6036	.5373	.6099	.543	.5544	.5601
7	.7059	.7207	.6379	.6653	.7207	.7133	.7282
8	.6984	.7207	.7522	.7207	.6653	.7682	.7282
9	.7602	.7059	.7522	.7207	.7842	.7207	.7842
10	.7973	.7682	.8145	.7682	.7682	.7602	.7282
11	.691	.8059	.8688	.8145	.9979	.8145	.823
12	.691	.7522	.8145	.8145	.8402	.8688	.7682
13	.5847	.6984	.7522	.7207	.2715	.7207	.6036
14	.591	.5973	.7059	.6036		.6584	.6036
15	.6173	.7362	.7973	.6584	.9465	.7133	.7282
16	.6687	.691	.6762	.691	.6762	.7059	.7282
17	.7802	.8322	.763	.7973	.7802	.6653	.9036
18	1.0534	1.0974	1.1523	1.1088	1.0974	1.1643	1.1523
19	1.0642	.9979	1.0534	1.1203	1.1088	1.0751	1.0534
20	1.0082	.8871	.9425	.9522	.9522	.9054	.9877
21	.8871	.823	.7682	.7842	.7762	.7842	.8779
22	.6584	.6516	.5973	.6161	.6036	.6722	.7059
23	.6584	.5373	.5373	.5041	.543	.4481	.591
24	.4835	.6036	.4298	.4835	.4481	.543	.4481
Max	1.0642	1.0974	1.1523	1.1203	1.1088	1.1643	1.1523
Min	.4835	.5373	.4298	.4784	.2715	.4481	.4481
Avg	.6879	.7118	.7006	.6936	.683	.6969	.7183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064038 / 33/11 KV POHORA S/S****Feeder No / Name : 201 / 11 KV Shivni AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281	.5281	.5281			
2		.5093	.5281	.5281			
3		.5093	.5281	.5281			
4		.5093	.5281	.5281			
5		.5093	.5281	.547			
6		.5281	.5658	.547			
8	.6413				.5658	.6036	.5847
9	.6979				.6413	.6413	.6413
10	.7167				.6979	.7733	.7356
11	.7733				.7545	.7733	.7842
12	.7545				.7922	.7922	.7655
13	.7733				.7922	.7733	.7282
14	.7545				.7733	.679	.7282
15	.679				.7167	.6224	.6413
23		.547	.547	.4298			
24			.5281	.5281	.4298		
Max	.7733	.547	.5658	.547	.7922	.7922	.7842
Min	.6413	.5093	.5281	.4298	.4298	.6036	.5847
Avg	.7238	.5201	.5352	.5205	.6849	.7073	.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****LAKNI S/DN.[719]****BU 4719****Substation No/ Name :- 064038 / 33/11 KV POHORA S/S****Feeder No / Name : 202 / 11 KV Dhabetekadi Gaothan
Feeder KV- 11 / OUTGOING****SEPARATED GAOTHAN FEEDERS**

DATE	29-NOV-17
HR	Load (MW)
1	.1698
2	.1698
3	.1698
4	.1698
5	.1886
6	.2263
7	.2263
8	.2263
9	.2614
10	.2263
11	.2075
24	.1886
Max	.2614
Min	.1698
Avg	.2025

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON****Feeder No / Name : 201 / 11 KV SASRA****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.3041	.3338	.306	.1214	.1417	.1402
2	.1991	.3041	.3338	.306	.12	.1417	.1402
3	.1991	.3001	.3243	.306	.12	.1448	.1402
4	.2054	.3144	.3525	.3429	.1187	.1629	.1595
5	.2614	.3338	.3948	.3814	.1753	.1991	.1772
6	.2926	.3864	.4515	.4725	.2587	.2957	.2772
7	.2241	.1848	.2241	.2427	.2195	.1753	.2263
8	.4967	.1848	.2054	.2241	.5117	.5647	.6859
9	.5624	.2263	.1867	.2054	.6327	.6472	.7811
10	.6173	.1848	.168	.1698	.7375	.7316	.8179
11	.6401	.1478	.1663	.1886	.6859		.7968
12	.6249	.112	.1478	.1448		.8436	.7968
13	.6019	.0895	.168	.1307	.6718	.8436	.8025
14	.5117	.1334	.1905	.1524	.679	.8179	.7926
15	.5117	.1334	.1715	.1509	.7316	.7621	.6923
16	.1867	.132	.1715	.0953	.2934	.1543	.1715
17	.2641	.1905	.1663	.2075	.1509	.2263	.1886
18	.5281	.5093	.547	.5281	.5281	.5281	.547
19	.547	.6036	.5658	.547	.547	.547	.547
20	.4527	.4481	.415	.4338	.4338	.4527	.4668
21	.2987	.2957	.2801	.2801	.2801	.2772	.2987
22	.1848	.2033	.1829	.181	.2054	.1829	.1829
23	.1646	.3338	.306	.2705	.1433	.1417	.1629
24	.1991	.1629	.3338	.306	.2534	.1417	.1402
Max	.6401	.6036	.5658	.547	.7375	.8436	.8179
Min	.1646	.0895	.1478	.0953	.1187	.1417	.1402
Avg	.3739	.2591	.2828	.2739	.3747	.3967	.4222

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON****Feeder No / Name : 202 / 11KV SANGADI FEEDER****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.282	.3429	.3584	.3395	.3567	.3814	.3668
2	.301	.3429	.3395	.3206	.3429	.3864	.3668
3	.301	.3395	.3395	.3206	.3429	.3864	.3715
4	.301	.3584	.3584	.3584	.3338	.431	.4161
5	.381	.3772	.3961	.3961	.4254	.5182	.4877
6	.4744	.4715	.4715	.547	.5155	.5506	.6009
7	.5093	.4904		.5144	.5144	.4904	.5658
8	.5335	.4321	.5155	.4696	.5281	.5658	.5144
9	.5525	.5693	.6401	.5376	.5093	.4904	.5335
10	.4715	.68	.6882	.6325	.4715	.4572	.5658
11	.415	.6093	.6964	.6964	.5281	.4527	.4338
12	.3961	.5761	.7362	.6802	.4904	.3961	.4668
13	.3961	.6554	.6958	.68	.4527	.3772	.4251
14	.415	.6481	.6958	.6173	.4338	.4435	.3584
15	.3361	.6481	.4268	.5792	.415	.3395	.3547
16	.362	.4755	.4207	.4338	.4668	.4251	.4344
17	.4938	.5175	.5359	.5359	.4715	.5304	.5041
18	1.0562	1.0288	1.0479	1.0098	.9907	1.0374	1.0288
19	1.0098	1.0098	.9907	1.0098	.9717	1.0098	1.0288
20	.8764	.8573	.8954	.8383	.8573	.8383	.8573
21	.6413	.6224	.6478	.6036	.6036	.5906	.6224
22	.4904	.4715	.4382	.4338	.4338	.4338	.4382
23	.2494	1.3872	.3772	.362	.3814	.3429	.362
24	.282	.2317	.3584	.3395	.3429	.3814	.4001
Max	1.0562	1.3872	1.0479	1.0098	.9907	1.0374	1.0288
Min	.2494	.2317	.3395	.3206	.3338	.3395	.3547
Avg	.4803	.5893	.5683	.5523	.5075	.5107	.5210

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON****Feeder No / Name : 203 / 11KV DIGHORI****SINGLE PHASING****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2214	.2225	.1829	.156	.2075	.2075
2	.2096	.2214	.2225	.1829	.1578	.1886	.1886
3	.2075	.2187	.2115	.1829	.1629	.1886	.1886
4	.2075	.2343	.1974	.2187	.1526	.1886	.1886
5	.2641	.2439	.2397	.25	.1928	.2075	.2075
6	.2667	.2688	.286	.2753	.2587	.2801	.2641
7	.2241	.1524	.1307	.132	.2195	.2241	.2452
8	.3161	.2829	.1867	.2075	.3763	.3906	.39
9	.3812	.2452	.2614	.2452	.3549	.4049	.39
10	.4578	.2263	.2614	.2075	.3913	.3887	.3725
11	.4475	.2075	.2263	.2075	.427	.4372	.4001
12	.3978	.2054	.2263	.2715	.4534	.4062	.4161
13	.431	.197	.2075	.2054	.4534	.4062	.4372
14	.4049	.2286	.1886	.2096	.4588	.3704	.4696
15	.3321	.2096	.2075	.2075	.4049	.3506	.3605
16	.1886	.1886	.1886	.2096	.2075	.2058	.2033
17	.1509	.2286	.2075	.2263	.132	.132	.1509
18	.4904	.4715	.5093	.4527	.4715	.5093	.4904
19	.5281	.5281	.5093	.5093	.5281	.5281	.5281
20	.5093	.4668	.4527	.4527	.4527	.4527	.5093
21	.3772	.3326	.3018	.3174	.3395	.3206	.3772
22	.2452	.2402	.2263	.2172	.2452	.2452	.2614
23	.2075	.2225	.1981	.1488	.2075	.2075	.2263
24	.2075	.2054	.2225	.1829	.16	.2075	.2075
Max	.5281	.5281	.5093	.5093	.5281	.5281	.5281
Min	.1509	.1524	.1307	.132	.132	.132	.1509
Avg	.3193	.2603	.2538	.2460	.3068	.3104	.3200

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 043167 / 33 KV S/S DONGARGAON****Feeder No / Name : 401 / 33 KV DONGARGAON FEEDER****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6722	.6722	.6161	.6584	.7207
2		.6161	.6161	.6161	.6036	.6653
3		.6161	.5658	.6161	.6099	.6722
4		.5601	.5658	.6161	.6099	.7282
5		.6161	.5093	.6722	.6722	.7282
6		.7842	.6287	.7356	.7356	.8402
7		.8316	.7282	.8871	.7207	.8779
8		.4938	.7842	.7762	.8316	.8779
9		.9774	.8316	.9425	.8505	.9328
10		1.3575	1.3306	1.2071	1.1403	1.1523
11	1.0082	1.6118	1.4969	1.5249	1.1403	1.3169
12	1.1088	1.4403	1.4415	1.4563	1.3169	1.5123
13	1.2894	1.3375	1.4815	1.4198	1.262	1.3169
14	1.2357	1.6644	1.2071	1.3672	1.1403	1.2071
15	1.2894	1.2071	1.3717	1.3672	1.1946	1.1317
16	1.3672	1.3603	1.3117	1.3289	1.5203	1.3014
17	1.4723	1.2929	1.4118	1.2094	1.4003	1.4266
18	1.386	1.4352	1.4118	1.262	1.3014	1.3717
19	1.3443	1.3306	1.3306	1.1883	1.1883	1.262
20	1.2323	1.0642	1.1088	1.0185	1.0185	1.1203
21	1.0082		.8871	.7762	.8488	.8779
22	.7602	.8596	.7602	.7682	.7356	.9054
23	3.0728	.7282	.6722	.7133	.7762	.7682
24		.6722	.6722	.6653	.6584	.7207
Max	3.0728	1.6644	1.4969	1.5249	1.5203	1.5123
Min	.7602	.4938	.5093	.6161	.6036	.6653
Avg	1.3519	1.0230	.9916	.9896	.9556	1.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064018 / 33KV SATALWADA****Feeder No / Name : 201 / 11 KV KINHI AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0667	.3102	.3506	.3374	.096	.0987	.0892
2	.0789	.3243	.3658	.3521	.096	.0705	.0743
3	.08	.3155	.3658	.3668	.1128	.0823	.0753
4	.0667	.3155	.3668	.3668	.1128	.096	.0594
5	.0657	.3292	.3521	.3668	.1128	.0987	.0743
6	.08	.3292	.3567	.3814	.1097	.0846	.0743
8	.3125	.0846	.0987	.088	.3567	.3666	.3906
9	.3437	.1128	.1143	.1174	.4252	.3788	.4062
10	.4062	.1128	.1143	.1174	.439	.3909	.421
11	.4062	.1128	.1128	.1128	.439	.3807	.4428
12	.3841	.1143	.1128	.1269	.4115	.3765	.427
13	.4801	.1128	.1269	.1269	.4115	.4199	.4428
14	.4801	.0987	.1128	.1269	.4115	.3948	.4321
15	.4374	.0846	.0846	.1269	.3841	.4161	.3479
22			.3227				
23	.0695	.3227	.3227	.3243	.0846	.0892	.0869
24	.0667	.0705	.3374	.3521	.2881	.0823	.0892
Max	.4801	.3292	.3668	.3814	.439	.4199	.4428
Min	.0657	.0705	.0846	.088	.0846	.0705	.0594
Avg	.2390	.1969	.2363	.2369	.2682	.2392	.2458

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064018 / 33KV SATALWADA****Feeder No / Name : 204 / 11 KV KINHI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1433	.1463	.1791	.1612	.1848	.1612
2	.1463	.1791	.128	.1791	.1448	.1663	.1753
3	.1646	.1791	.1463	.1928	.1663	.1791	.2126
4	.1829	.2149	.2195	.1753	.1478	.197	.1772
5	.2012	.1791	.2378	.1928	.1848	.1791	.2103
6	.2012	.2149	.2378	.2172	.2012	.197	.197
7	.2195	.197	.2012	.1991	.2012	.197	.2103
8	.1829	.1646	.1829	.2012	.2012	.197	.2103
9	.2561	.2012	.2012	.2012	.2012	.2012	.2058
10		.1646	.1612	.1646	.2033	.181	.1886
11	.2378	.1646	.1254	.1829	.1663	.1791	.1753
12	.1463	.1646	.1254	.1646	.1663	.1267	.1372
13	.1646	.1294	.1254	.1646	.1663	.1267	.1372
14	.1663	.1663	.1663	.181	.1478	.1448	.1928
15	.1663	.1848	.1478		.1448	.1646	.1753
16	.1848	.1848	.1629	.181	.1646	.1772	.2103
17	.2353	.2149	.2172	.1991	.2012	.1595	.1949
18	.3439	.3439	.3258	.3511	.3292	.3326	.3544
19	.3258	.3475	.3439	.3326	.3475	.3292	.3224
20	.2957	.2743	.2715	.2772	.3109	.2658	.2715
21	.2033	.2195	.2149	.2033	.2402	.197	.1991
22	.1848	.1829	.1791	.1663	.1848	.181	.1612
23	.1663	.1646	.1612	.1478	.1663	.1629	.1086
24	.1463	.1433	.1463	.1612	.1433	.1663	.1448
Max	.3439	.3475	.3439	.3511	.3475	.3326	.3544
Min	.1463	.1294	.1254	.1478	.1433	.1267	.1086
Avg	.2030	.1968	.1906	.2007	.1955	.1914	.1972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064018 / 33KV SATALWADA****Feeder No / Name : 205 / 11 KV SATALWADA GT.****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.4066	.4572	.4344	.4344	.4119	.4344
2	.1646	.4066	.4207	.4525	.4163	.4298	.4207
3	.2012	.4435	.462	.4656	.4298	.4298	.4344
4	.2561	.4344	.4805	.4835	.4298	.4477	.4477
5	.2926	.4706	.499	.4835	.4477	.462	.4477
6	.3109	.4887	.499	.5175	.4681	.499	.4372
7	.3109	.4525	.4805	.462	.4334	.462	.4656
8	.2926	.4572	.4755	.4525	.4525	.4572	.4656
9	.3109	.4572	.4435	.4163	.4344	.4252	.4252
10		.4207	.4251	.4525	.4344	.4163	.4207
11	.4477	.439	.4525	.4163	.4525	.4525	.4252
12	.4298	.439	.4525	.4477	.462	.4525	.4252
13	.4477	1.4114	.4525	.4298	.462	.4298	.4382
14	.4382	.4572	.4525	.4298	.4251	.4344	.443
15	.4382	.439	.4344	.4656	.4066	.4024	.4252
16	.4119	.439	.462	.4706	.4163	.4119	.4075
17	.4477	.439	.4805	.4887	.4525	.4435	.4477
18	.6268	.6036	.6099	.6335	.5973	.5975	.5792
19	.591	.6036	.6099	.6335	.5973	.6161	.5853
20	.5611	.5487	.5359	.5552	.5249	.5415	.4961
21	.4525	.5121	.5068	.4835	.4835	.5121	.4656
22	.4525	.4755	.4706	.4477	.4477	.4706	.4607
23	.4525	.4572	.4525	.4344	.4298	.4706	.4706
24	.1829	.4435	.4572	.4525	.4344	.4298	.4344
Max	.6268	1.4114	.6099	.6335	.5973	.6161	.5853
Min	.1646	.4066	.4207	.4163	.4066	.4024	.4075
Avg	.3784	.5061	.4780	.4754	.4572	.4628	.4543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064019 / 33 KV PARASTOLA****Feeder No / Name : 201 / 11 KV CHANDORI****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5716	.5716	.5716	.5906	.6097	.4763
2	.5906	.5716	.5716	.5716	.5906	.6097	.4763
3	.5906	.5716	.5716	.5716	.5906	.6097	.4763
4	.6097	.5716	.5716	.5716	.5906	.6097	.4763
5	.6097	.5906	.5716	.5906	.5906	.6097	.4763
6	.6478	.6287	.5716	.6287	.6287	.6478	.5144
7	.6478	.6097	.5906	.6287	.6478	.6478	.5525
8	.6859	.6478	.6287	.6478	.6478	.6668	.5716
9	.7049	.7621	.7049	.7049	.743	.8002	.724
10	.724	.8383	.8192	.8383	.8383	.7811	.8002
11	.7621	.8573	.8573	.8002	.8764	.743	.8002
12	.743	.8002	.8573	.7621	.9717	.7621	.7621
13	.8002	.7049	.743	.8573	.8573	.4763	.8383
14	.8192	.724	.7811	.8764	.9335	.8192	.8383
15	.8192	.7621	.7621	.8383	.9717	.7621	.8192
16	.8383	.8192	.8954	.8192	.9717	.8192	.8573
17	.8002	.8002	.9717	.8192	.8573	.8192	.8002
18	.8573	.8764	.9145	.8764	.9717	.8002	.8002
19	.8192	.8192	.8573	.8764	.8383	.7811	.7621
20	.743	.7621	.8002	.743	.7811	.6668	.6859
21	.6478	.6668	.7049	.6668	.7049	.5906	.6097
22	.6097	.5906	.6097	.6097	.6478	.5335	.6478
23	.5906	.5716	.5906	.5906	.6287	.4763	.4954
24	.5906	.5716	.5716	.5906	.5906	.6097	.4763
Max	.8573	.8764	.9717	.8764	.9717	.8192	.8573
Min	.5906	.5716	.5716	.5716	.5906	.4763	.4763
Avg	.7018	.6954	.7121	.7105	.7526	.6771	.6557

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064019 / 33 KV PARASTOLA****Feeder No / Name : 203 / 11 KV BODRA****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.381	.381	.381	.381	.381	.381
2	.381	.381	.381	.381	.381	.381	.381
3	.381	.381	.381	.381	.381	.381	.381
4	.381	.381	.381	.381	.381	.381	.381
5	.381	.4001	.4001	.4001	.381	.4001	.4001
6	.4191	.4572	.4191	.4572	.4191	.4001	.4191
7	.4191	.4382	.4001	.4191	.4001	.4191	.4191
8	.4382	.4382	.4191	.4191	.4382	.4382	.4191
9	.4763	.4382	.4191	.4382	.4763	.4382	.4572
10	.4763	.4382	.4191	.4382	.4191	.4382	.4382
11	.4954	.4382	.4191	.4572	.4382	.4382	.4572
12	.4763	.4382	.4382	.4572	.4382	.4382	.4572
13	.4763	.4382	.4191		.4382	.4191	.4382
14	.4572	.4382	.4382	.4382	.4382	.4191	.4382
15	.4572	.4382	.4001	.4382	.4382	.4191	.4382
16	.4572	.4191	.4191	.4763	.4572	.4382	.4191
17	.4763	.4191	.4191	.4382	.4572	.4572	.4382
18	.5335	.4954	.4954	.5144	.4954	.4954	.4763
19	.5144	.4954	.4954	.4954	.4954	.4954	.4763
20	.4763	.4763	.4763	.4572	.4572	.4572	.4572
21	.4382	.4191	.4191	.4191	.4191	.4191	.4191
22	.4001	.4001	.4001	.381	.381	.4001	.4001
23	.4001	.381	.381		.381	.381	.381
24	.381	.381	.381	.381	.381	.381	.381
Max	.5335	.4954	.4954	.5144	.4954	.4954	.4763
Min	.381	.381	.381	.381	.381	.381	.381
Avg	.4406	.4255	.4167	.4295	.4239	.4215	.4231

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064019 / 33 KV PARASTOLA****Feeder No / Name : 411 / 33 kV Salebhata****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.829	2.572	1.8861	2.4006	1.2003	1.4861	1.4289
2	1.829	2.572	1.8861	2.3434	1.2003	1.5432	1.4289
3	1.8861	2.5149	1.9433	2.3434	1.1431	1.5432	1.4289
4	1.9433	2.5149	1.9433	2.3434	1.2003	1.5432	1.4289
5	1.9433	2.572	2.0005	2.4006	1.3717	1.6004	1.5432
6	2.0576	2.8006	2.2291	2.6292	1.5432	1.7147	1.6575
7	.743	.8002	.743	.8002	.743	.743	.743
8	3.1436	2.1719	2.4577	2.2862	2.8578	3.1436	2.8006
9	3.5437	2.8578	2.8578	2.572	3.4294	3.4865	3.0864
10	3.7723	2.9721	3.0293	2.6863	3.4294	2.3434	3.315
11	3.6008	2.8006	2.8006	2.8006	3.8866	3.8295	3.3722
12	3.658	3.0293	2.8578	2.7435	4.0009	3.7151	3.4865
13	3.658	2.8006	2.8578	2.6292	3.9438	2.8578	3.4294
14	3.2579	2.6863	2.7435	2.4577	3.8866	3.4865	3.4294
15	3.0293	2.6863	1.3717	2.4577	3.658	3.2579	3.315
16	.8002	.9145	1.4289	.9145	.8573	.9717	.9145
17	1.086	1.086	1.4289	1.086	.9717	1.0288	.8573
18	1.4289	1.4289	1.3717	1.4289	1.4289	1.4289	1.3717
19	1.3717	1.3717	1.3717	1.3717	1.3146	1.3146	1.3717
20	1.1431	1.1431	1.086	1.1431	1.1431	1.086	1.2003
21	.9717	.8573	.9717	.9145	.8573	.743	.9717
22	.8002	.6859	.743	.743	.743	.6859	.6859
23	1.6575	1.9433	2.5149	2.2291	1.4861	1.4861	1.3717
24	1.829	2.6292	1.9433	2.5149	1.2003	1.4861	1.4861
Max	3.7723	3.0293	3.0293	2.8006	4.0009	3.8295	3.4865
Min	.743	.6859	.743	.743	.743	.6859	.6859
Avg	2.1243	2.1005	1.9362	2.0100	1.9790	1.9386	1.9219

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 201 / 11 KV GONDUMRI AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908				.4191	.4144	.4287
2	.4908				.4694	.4144	.4287
3	.5068				.4694	.4144	.4287
4	.543				.503	.4287	.4287
5	.543				.503	.4572	.443
6	.5611				.5197	.4858	.4715
8		.583	.5498	.6405			
9		.7449	.578	.6718			
10		.7773	.6626	.7499			
11		.5502	.6626	.703			
12		.5647	.6767	.7343			
13		.5573	.6767	.7343			
14		.7145	.6626	.703			
15		.6716	.6626	.6718			
23	.4807				.4144	.4287	.3841
24	.4908	.4641				.4144	.4287
Max	.5611	.7773	.6767	.7499	.5197	.4858	.4715
Min	.4807	.4641	.5498	.6405	.4144	.4144	.3841
Avg	.5134	.6253	.6415	.7011	.4711	.4323	.4303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 202 / 11 KV WADAD AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189				.2543	.2667	.3506
2	.3189				.2543	.2667	.333
3	.3189				.3052	.2667	.333
4	.2896				.3121	.2667	.333
5	.2896				.3121	.2667	.333
6	.2896				.3294	.2667	.333
8		.2915	.3113	.3681			
9		.3239	.3441	.3856			
10		.4696	.3768	.4031			
11		.3761	.3932	.4207			
12		.4119	.3768	.4382			
13		.4207	.3605	.4382			
14		.3982	.3768	.4031			
15		.3721	.3768	.4031			
23	.3439				.2667	.3506	.3113
24	.3544	.3439				.2667	.3506
Max	.3544	.4696	.3932	.4382	.3294	.3506	.3506
Min	.2896	.2915	.3113	.3681	.2543	.2667	.3113
Avg	.3155	.3787	.3645	.4075	.2906	.2772	.3347

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 203 / 11 KV KHANDALA AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4858	.3517	.4089			
2		.4858	.3517	.4089			
3		.4858		.4089			
4		.4696	.3517	.4089			
5		.4696	.3704	.4089			
6		.4696	.3755	.4089			
8					.5426	.535	.6154
9					.6613	.5502	.7287
10					.78	.6371	.6802
11					.6836	.6661	.5506
12					.7282	.5647	.7611
13					.7282	.6371	.7449
14					.6984	.6144	.7935
15	.5668				.5944	.6226	.7449
16	.6154						
17	.6154						
18	.5344						
19	.5182						
20	.5344						
21	.5344						
22	.5344						
23		.3467	.4144	.4508			
24			.3467	.4144	.4681		
Max	.6154	.4858	.4144	.4508	.78	.6661	.7935
Min	.5182	.3467	.3467	.4089	.4681	.535	.5506
Avg	.5567	.4590	.3660	.4148	.6539	.6034	.7024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 204 / PALASGAON GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1109	.1029	.1017	.0754	.1075	.1063
2	.1109	.0924	.1029	.0848	.0754	.0895	.1063
3	.1086	.0924	.0867	.0848	.0724	.0895	.0886
4	.1448	.0924	.0867	.0848	.0905	.0895	.0886
5	.1448	.0924	.0867	.1063	.1086	.1075	.1063
6	.1629	.1478	.1227	.1417	.1267	.1463	.1267
7	.1629	.1463	.1417	.1417	.1646	.1463	.1629
8	.128	.1267	.1448	.124	.1509	.1267	.1448
9	.1097	.1086	.1448	.1063	.1132	.1075	.1063
10	.1463	.1134	.1086	.0886	.132	.1387	.1063
11	.0543	.104	.1629	.1063	.1448	.156	.1063
12	.1086	.3467	.1267	.2033	.1991	.1387	.0886
13	.1086	.1402	.1267	.1478	.1254	.1214	.0886
14	.1086	.1595	.1448	.1478	.1075	.1387	.0886
15	.1086	.1612	.1267	.1478	.1448	.104	.1063
16	.0905	.1612	.1086	.1848	.181	.0867	.1543
17	.1829	.2353	.181	.0739	.2149	.2172	.1543
18	.2195	.2957	.2926	.2218	.2957	.2801	.216
19	.2218	.2957	.2561	.2452	.2987	.2987	.216
20	.1848	.2587	.2195	.1886	.2452	.2241	.2353
21	.1478	.1791	.1463	.132	.1886	.1463	.2172
22	.1294	.124	.128	.1132	.1097	.1086	.1629
23	.1109	.1052	.1017	.0943	.0895	.1063	.1448
24	.1109	.1109	.1029	.1017	.0943	.1075	.1063
Max	.2218	.3467	.2926	.2452	.2987	.2987	.2353
Min	.0543	.0924	.0867	.0739	.0724	.0867	.0886
Avg	.1340	.1584	.1397	.1322	.1479	.1410	.1345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 205 / SUKALI GAOTHAN****GAOTHAN FEEDER****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.1086	.0838	.081	.0732	.0867	.0848
2	.0732	.0905	.0838	.0648	.0732	.0693	.0848
3	.0724	.0905	.0848	.0648	.0732	.0693	.0848
4	.0724	.0905	.0678	.0648	.1109	.0693	.0848
5	.0724	.0905	.0848	.0857	.1109	.0867	.1017
6	.0895	.1086	.104	.1029	.1109	.1227	.1227
7	.0895	.0905	.1227	.104	.1086	.1052	.1052
8	.0895	.1063	.1075	.0867	.1017	.1052	.1052
9	.0732	.1063	.1063	.0867	.1017	.1052	.1029
10	.0716	.0886	.1063	.0867	.1017	.116	.1029
11	.0537		.1017	.104	.104	.0995	.081
12	.0537	.0701	.1187	.0829		.0995	.0648
13	.0716	.0693	.0848	.0829	.0867	.0829	.0648
14	.0716	.0693	.0848	.0663	.0867	.0829	.0648
15	.0716	.052	.0848	.0995	.104	.0663	.0648
16	.1075	.0693	.0848	.0995	.104	.1017	.0564
17	.1267	.1063	.104	.1326	.1052	.1214	.0846
18	.181	.1663	.181	.1658	.1646	.1791	.1269
19	.1829	.1663	.1629		.1848	.1791	.1269
20	.1463	.1478	.1448	.1463	.1478	.1433	.128
21	.128	.1075	.1086	.1097	.1109	.1254	.0914
22	.1086	.0886	.0905	.1097	.0819	.1063	.0914
23	.1097	.0857	.081	.0914	.0867	.0848	.0732
24	.0732	.1086	.0838	.081	.0914	.0867	.0848
Max	.1829	.1663	.181	.1658	.1848	.1791	.128
Min	.0537	.052	.0678	.0648	.0732	.0663	.0564
Avg	.0943	.0990	.1028	.0956	.1054	.1039	.0910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 064024 / 33/11 KV WADAD****Feeder No / Name : 206 / SAWARBANDH GAOTHAN
Feeder KV- 11 / OUTGOING****GAOTHAN FEEDER**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.0754	.0762	.0754	.0754	.0754
2	.0754	.0943	.0747	.0762	.0754	.0754	.0754
3	.0754	.0943	.0747	.0762	.0754	.0754	.0754
4	.0943	.0943	.0747	.0762	.0914	.0754	.0754
5	.0943	.0943	.0754	.1132	.0914	.1132	.0943
6	.132	.132	.1132	.1509	.128	.132	.132
7	.1214	.1132	.1509	.1509	.128	.132	.132
8	.1214	.1097	.1132	.1132	.132	.1132	.1132
9	.104	.0914		.1132	.1509	.112	.1086
10	.104	.0914	.1886	.1132	.132	.1267	.1267
11	.0867	.1097	.1132	.132	.132	.0905	.1543
12	.1214	.1463	.0943	.132	.1132	.1086	.12
13	.052	.0732	.1132	.132	.1494	.1086	.0857
14	.0693	.0732	.1132	.0943	.0934	.0724	.0857
15	.1214	.1097	.1886	.132	.0934	.0905	.0686
16	.1387	.1097	.1509	.132	.0934	.0905	.125
17	.1402	.1646	.2263	.2452	.1494	.1886	.1406
18	.2829	.2829	.2829	.2829	.2829	.2829	.2829
19	.2641	.2829	.2641	.2829	.2829	.2641	.2641
20	.2263	.2263	.2075	.2263	.2452	.2263	.2477
21	.1698	.1509		.1509	.1698	.1509	.1524
22	.1132	.0943	.0943	.1698	.0943	.1132	.0953
23	.0943	.0943	.0762	.0943	.0754	.0905	.0762
24	.0754	.0943	.0754	.0762	.0943	.0754	.0724
Max	.2829	.2829	.2829	.2829	.2829	.2829	.2829
Min	.052	.0732	.0747	.0762	.0754	.0724	.0686
Avg	.1231	.1259	.1337	.1393	.1312	.1243	.1241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]

BHANDARA CIRCLE[665]

SAKOLI O&M DIVISION[656]

SAKOLI S/DN.[391]

BU 0391

Substation No/ Name :- 064024 / 33/11 KV WADAD

Feeder No / Name : 401 / Dongargaon

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17
HR	Load (MW)
24	1.4255
Max	1.4255
Min	1.4255
Avg	1.4255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 065004 / 33 KV SAKOLI****Feeder No / Name : 201 / 11 KV S'Wafa AG****FEEDER SEPERATION/PURE AG****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5281	.5093	.5093			
2		.5281	.5093	.5093			
3		.5281	.5093	.5093			
4		.5281	.5093	.5281			
5		.5281	.4715	.5228			
6		.5281	.4904	.5228			
7					.5281		
8	.6097				.6224	.6602	.6224
9	.7167				.7922	.7356	.7545
10	.7922				.8029	.7545	.7922
11	.7922				.8871	.7922	.7922
12	.6668				.8402	.8029	.7468
13	.6478				.8215	.7922	.7468
14	.6478				.7842	.7545	.7167
15	.547				.7655	.7167	.6602
23		.4904	.5093	.4904			
24		.5281	.5093	.5093	.4904		
Max	.7922	.5281	.5093	.5281	.8871	.8029	.7922
Min	.547	.4904	.4715	.4904	.4904	.6602	.6224
Avg	.6775	.5234	.5022	.5127	.7335	.7511	.7290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 065004 / 33 KV SAKOLI****Feeder No / Name : 203 / 11KV SAKOLI FEEDER****SHEDDABLE URBAN****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4298	.4382	.547	.443	.4252	.362	.3898
2	.4298	.443	.547	.443	.4252	.3582	.3898
3	.4298	.443	.547	.443	.4298	.3881	.3721
4	.4298	.4477	.5281	.443	.4298	.3982	.3721
5	.4477	.4477	.5093	.4961	.4477	.4163	.4298
6	.4835	.543	.4656	.5316	.4656	.4344	.5014
7	.4477	.5194	.5552	.567	.5434		.5552
8	.5544	.6036	.6036	.6154	.6154	.5493	.6219
9	.6468	.6516	.6447	.6556	.6036	.6089	.6219
10	.6089	.6805	.6805	.7265	.691	.6626	.6401
11	.6733	.7282	.5014	.7712	.7282	.6984	
12	.6068	.7282	.5373	.7628	.6836	.6241	.7186
13	.5895	.6516	.6335	.6935	.5375	.6268	.6687
14	.5721	.6516	.6036	.5548	.5144	.6024	.6001
15	.5548	.6626	.6001	.6173	.5487	.6135	.6173
16	.6613	.6613	.6415	.6415	.5895	.6516	.6104
17	.6299	.7377	.6836	.6588	.5895	.7122	.7282
18	.8688	.8869	.7973	.8869	.7602	.7712	.8596
19	.4191	.7865	.7865	.7133	.7499	.7682	.7682
20	.7059	.7865	.8779	.6878	.7059	.7316	.6154
21	.6335	.6516	.6516	.5792	.6154	.6878	.6089
22	.5316	.5731	.5373	.5373	.543	.5014	.4733
23	.4557	.4961	.4607	.4607	.443	.443	.4207
24	.4298	.4382	.5083	.443	.4252	.3506	.4075
Max	.8688	.8869	.8779	.8869	.7602	.7712	.8596
Min	.4191	.4382	.4607	.443	.4252	.3506	.3721
Avg	.5517	.6107	.6020	.5988	.5629	.5635	.5648

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 065004 / 33 KV SAKOLI****Feeder No / Name : 204 / 11 KV LAKHANDUR FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0474	.0332	.0189	.4744	.0328	.0158	.0474
2	.0474	.0332	.0377	.0474	.0328	.0316	.0316
3	.0474	.0332	.0189	.0474	.0328	.0158	.0316
4	.0474	.0332	.0377	.0474	.0328	.0316	.0316
5	.0474	.0332	.0189	.0474	.0328	.0316	.0474
6	.0474	.0332	.0354	.0474	.0328	.0316	.0474
7	.0158	.0332	.0526	.0474	.0328	.0316	.0474
8	.0166	.0332	.0351	.0474	.0164	.0316	.0474
9	.0497	.0332	.0175	.0474	.0328	.0158	.0474
10	.0497	.0166	.0791	.0474	.0328	.0158	.0474
11	.0497	.0497	.0474	.0474	.0316	.0316	.0474
12	.0497	.0497	.0474	.0497	.0316	.0474	.0316
13	.0166	.0497	.0474	.0829	.0316	.0474	.0158
14	.0497	.0166	.0474	.0492	.0316	.0474	.0316
15	.0497	.0166	.0474	.0492	.0316	.0474	.0316
16	.0497	.0166	.0474	.0164	.0158	.0474	.0316
17	.0497	.0332	.0474	.0328	.0158	.0474	.0158
18	.0166	.0497	.0474	.0328	.0316	.0474	.0316
19	.0497	.0829	.0474	.0328	.0158	.0474	.0316
20	.0497	.0497	.0474	.0492	.0158	.0474	.0316
21	.0497	.0497	.0474	.0492	.0316	.0474	.0316
22	.0497	.0497	.0474	.0492	.0158	.0474	.0316
23	.0166	.0497	.0474	.0492	.0316	.0474	.0316
24	.0474	.0497	.0566	.0474	.0492	.0158	.0474
Max	.0497	.0829	.0791	.4744	.0492	.0474	.0474
Min	.0158	.0166	.0175	.0164	.0158	.0158	.0158
Avg	.0421	.0387	.0427	.0641	.0289	.0362	.0362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 065004 / 33 KV SAKOLI****Feeder No / Name : 205 / 11 KV EKODI FEEDER****SHEDDABLE RURAL****Feeder KV- 11 / OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3048	.2932	.286	.3201	.2494	.2743
2	.3506	.3125	.2932	.3048	.3201	.2439	.2743
3	.3506	.3201	.2968	.3048	.3281	.2753	.2439
4	.3549	.3277	.3163	.3201	.3321	.2915	.2439
5	.3749	.3277	.3239	.3561	.3361	.3149	.2439
6	.4049	.3647	.3441	.4001	.3563	.3315	.3163
7	.4481	.4096	.3841	.4424	.3795	.3953	.3887
8	.4641	.4144	.3932	.431	.4372	.4588	.3768
9	.4973	.4161	.4586	.4111	.4588	.4428	.4807
10	.4858	.421	.4572	.4843	.4902	.4531	.4973
11	.4744	.4687	.506	.4938	.4902	.4167	.4973
12	.5093	.4666	.4938	.4938	.4816	.3858	.463
13	.4999	.4268	.4877	.4572	.3704	.4012	.463
14	.4877	.4816	.4755	.4515	.381	.4115	.4458
15	.4515	.4816	.4755	.4458	.3963	.442	.4401
16	.4694	.4715	.4694	.4666	.4115	.4515	.4489
17	.4548	.4841	.4715	.4572	.4268	.4967	.4531
18	.5721	.5375	.5533	.5895	.5375	.583	.5201
19	.5258	.5258	.5434	.5434	.5316	.5434	.5138
20	.4801	.4681	.5144	.4973	.4801		.3812
21	.4144	.3932	.4748	.426	.3768	.4287	.3812
22	.3437	.3241	.3506	.3549	.3201	.373	.3163
23	.3048	.286	.3048	.3161	.2934	.3315	.2709
24	.3462	.2972	.2896	.286	.3121	.2641	.2743
Max	.5721	.5375	.5533	.5895	.5375	.583	.5201
Min	.3048	.286	.2896	.286	.2934	.2439	.2439
Avg	.4340	.4055	.4155	.4175	.3987	.3907	.3837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 065004 / 33 KV SAKOLI****Feeder No / Name : 206 / 11 KV SHENDURWAFI GT.****GAOTHAN FEEDER****FEEDER Feeder KV- 11 /
OUTGOING**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.6447	.6135	.6379	.6379	.6447	.631
2	.7133	.6984	.6135	.6379	.6379	.6154	.631
3	.7133	.6447	.6135	.6379	.6447	.6584	.6135
4	.7133	.6447	.7011	.6379	.6447	.7316	.6201
5	.7023	.7682	.7537	.6878	.724	.7499	.6335
6	.7023	.8871	.823	.7602	.8326	.8316	.7316
7	.9313	.8775	.8871	.9055	.924	.8962	.8871
8	.924	.8686	.9055	.8871	.924	.8779	.9149
9	.8871	.8871	.7964	.8501	.8871	.924	.8775
10	.7947	.8048	.8596	.8871	.924	.8779	.9149
11	.8501	.7964	.7762	.8596	.4988	.8596	.8413
12	.8048	.7947	.6401	.8686		.8048	.823
13	.7499	.8131	.6767	.4344	.8413	.5853	.823
14	.7947	.8048	.8048	.8596	.8779	.8682	.8413
15	.7682	.7682	.823	.905	.8779	.7888	.8507
16	.7783	.7783	.8507	.9412	.8779	.7973	.8505
17	.8869	.8779	.8779	.9015	.8962	.8413	.9979
18	1.1949	1.1763	1.1576	1.2323	1.2136	1.2012	1.2136
19	1.1576	1.1016	1.1763	1.1949	1.1763	1.1576	1.2323
20	1.0456	1.0349	1.0903	1.0456	1.0608	1.0269	.924
21	.8686	.8596	.8596	.8871	.9055	.9412	.9145
22	.7316	1.7452	.7783	.7421	.8507	.7164	.8326
23	.6447	.6379	.6626	.6733	.7164	.6556	.6878
24	.7133	.6447	.6135	.6379	.6379	.6089	.631
Max	1.1949	1.7452	1.1763	1.2323	1.2136	1.2012	1.2323
Min	.6447	.6379	.6135	.4344	.4988	.5853	.6135
Avg	.8243	.8566	.8064	.8214	.8353	.8192	.8299

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 401 / SAKOLI -I****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4841	1.0099	.9465	.9991	.4287	.3807	.3807
2	.4841	1.0099	.9568	.9568	.4287	.3755	.3807
3	.4778	.9465	.9568	.9568	.4287	.3755	.3755
4	.4778	.9328	.9568	.9568	.4344	.3961	.3858
5	.4967	.535	.9568	1.0099	.4515	.3961	.3961
6	.5693	.5693	1.0745	1.086	.5218	.4687	.427
7	.6481	.6019	.6401	.6481	.5556	.5487	.5218
8	1.2357	.6241	.6167	.6642	1.182	1.2226	1.1403
9	1.3969	.6093	.6859	.6481	1.382	1.3146	1.3432
10	1.5203	.6962	.7133	.7225	1.4563	1.4198	1.382
11	1.8604	.7133	.7773	.7316	1.5604	1.4198	1.382
12	1.7541	.787	.7579	.7579	1.5261	1.3523	1.386
13	1.7353	.7968	.7579	.7133	1.4043	1.3672	1.3523
14	1.6827	.7968	.7482	.7133	1.4918	1.3672	1.2346
15	1.2226	.8333	.7385	.7133	1.4403	1.3003	1.2346
16	.6859		.719	.7042	.6241	.6344	.5921
17	.695	.751	.7613	.6773	.7545	.6081	.587
18	.8551	.8036	.8745	.8139	.763	.7122	.763
19	.8139	.8139	.8048	.7716	.7459	.7202	.7922
20	.7373	.7373	.7373	.6962	.6093	.6539	
21	.6642	.6481	.6562	.5007	.5281	.5155	.4744
22	.6104	.5721	.535	.4212	.4401	.4401	.4458
23	.5213	1.0099	1.0099	.9036	.3858	.3909	.3807
24	.4904	.4715	.9991	1.0099	.9036	.3755	.3807
Max	1.8604	1.0099	1.0745	1.086	1.5604	1.4198	1.386
Min	.4778	.4715	.535	.4212	.3858	.3755	.3755
Avg	.9216	.7508	.8075	.7823	.8520	.7815	.7712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 402 / 33 KV WADAD****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1443	1.3203	1.9204	1.8947	1.9456	1.9456	1.9244
2	1.1831	1.3203	1.8724	1.8947	1.9456	1.9244	1.9244
3	1.1568	.9556	1.8724	1.8724	1.9456	1.9244	1.9244
4	1.1568	1.3032	1.8947	1.8461	1.9667	1.9244	1.9456
5	1.286	1.3998	2.0405	1.9393	2.0953	2.2325	2.2325
6	1.6478	1.6032	2.4691	2.3663	2.3891	2.6063	2.6063
7	.7602	.7059	1.6461	1.5364	1.6118	1.5364	1.6832
8	.9339	1.5581	2.7938	1.1694	2.7664	2.9001	3.1824
9	1.5261	1.9765	3.1207	2.9127	3.1184	2.9635	3.3699
10	1.5769	2.0805	3.6928	3.4848	3.5391	3.4808	3.722
11	1.5729	2.8475	3.9529	3.6408	3.9323	2.4446	3.5803
12	1.5238	3.2076	3.7551	3.7449	3.3813	3.5803	3.9323
13	1.4089	3.5494	3.7037	3.7551	3.8832	3.7294	3.5951
14	1.3443	3.1893	3.866	3.6008	3.7409	3.5803	3.3208
15	1.8027	3.3288	3.3196	3.3951	3.4494	3.4008	3.2167
16	1.1111	2.0062	1.9685	1.9765	2.1605	2.0119	1.8313
17	1.174	2.3148	2.0388	2.2365	1.9765	2.1125	2.4331
18	1.9879	2.9687	2.9864	3.0247	2.8275	2.9938	2.4646
19	1.9547	2.9127	2.8567	2.9127	2.4086	2.7726	4.5931
20	1.701	2.5206	2.4086	2.4086	2.1845	2.2965	2.384
21	1.3226	1.8656	1.8107	1.8107	1.701	1.7558	1.5524
22	1.0562	1.3969	1.4883	1.4506	1.4352	1.3672	1.5043
23	1.0923	1.917	2.0153	1.8244	2.1033	1.9982	2.1033
24	1.1443	1.0288	1.8724	1.9433	1.8244	1.9982	1.9982
Max	1.9879	3.5494	3.9529	3.7551	3.9323	3.7294	4.5931
Min	.7602	.7059	1.4883	1.1694	1.4352	1.3672	1.5043
Avg	1.3570	2.0532	2.5569	2.4434	2.5138	2.4784	2.6260

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 403 / SAKOLI II****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9465	.8145	.8059	.7602	.8059	.7973	.7973
2	.8413	.8145	.8059	.7602	.7522	.7802	.7522
3	.8842	.8059	.7602	.7602	.7973	.7888	.7442
4	.8413	.8059	.8145	.7602	.7522	.7362	.7133
5	.9568	.8688	.8688	.823	.823	.8145	.823
6	1.086	1.0534	.9425	1.0534	.9425	.9877	.9425
7	1.182	1.1523	1.0745	1.2071	1.1946	1.1403	1.1523
8	1.2197	1.2323	1.2197	1.1643	1.2197	1.3169	1.2752
9	1.2323	1.3306	1.0974	1.2489	1.1643	1.3575	1.3306
10	1.2071	1.1694	1.2489	1.3432	1.4352	1.3575	1.3032
11	1.3032	1.3289	1.0425	1.4352	.7207	1.4352	1.2757
12	1.2357	1.4506	1.3032	1.5249	.7373	1.2894	1.4198
13	1.1283	1.2757	1.182	1.3146	1.2226	1.0425	1.2094
14	1.1283	1.2757	1.262	1.2483	1.262	1.2357	1.2483
15	1.1283	1.2757	1.1694	1.3523	1.2483	1.2094	1.286
16	1.2209	1.3077	1.2431	1.3672	1.1163	.703	1.2929
17	1.2346	1.3923	1.3077	1.4352	1.2226	1.3375	1.4352
18	1.7187	1.6409	1.7375	1.7187	1.6632	1.7741	1.8484
19	1.6632	1.6632	1.6804	1.6244	1.6632	1.6244	1.6632
20	1.4969	1.5123	1.4969	1.4969	1.5684	1.4969	1.5364
21	1.262	1.262	1.3169	1.2489	1.3432	1.2489	1.3575
22	1.086	1.0745	1.0317	1.1163	1.0517	1.0099	1.0631
23	.9568	.9231	.9231	.9134	.8939	.8688	.8939
24	.9568	.8505	.8596	.8145	.8413	.8413	.7602
Max	1.7187	1.6632	1.7375	1.7187	1.6632	1.7741	1.8484
Min	.8413	.8059	.7602	.7602	.7207	.703	.7133
Avg	1.1632	1.1784	1.1331	1.1871	1.1017	1.1331	1.1718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 404 / 33 KV PARASTOLA****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3102	3.2487	2.5206	3.0807	1.9204	1.9959	1.9753
2	2.3102	3.2487	2.5206	3.1436	1.9204	2.0302	1.9753
3	2.3102	3.1927	2.4646	3.0864	1.9204	2.0302	1.9547
4	2.3102	3.1927	2.4646	3.0864	1.8656	2.0302	1.9753
5	2.4434	3.3048	2.4086	3.2007	2.0513	2.0513	2.0851
6	2.7435	3.6408	2.8292	3.5082	2.2731	2.1622	2.384
7	1.6244	1.5524	1.5123	1.6244	1.5524	1.6244	1.5123
8	4.0329	2.9321	3.095	3.0087	3.6969	3.9769	3.6037
9	4.4907	3.4705	3.3288	3.2076	4.3799	4.3799	3.8409
10	4.7125	3.6808	3.5888	3.3128	4.3347	3.3265	4.1267
11	4.5462	3.5757	3.5231	3.4179	4.7239	4.7125	4.2353
12	4.4993	3.6928	3.5231	3.4705	4.9411	4.6571	4.2444
13	4.4525	3.4705	3.4179	3.3128	4.7817	3.3665	4.2981
14	4.1701	3.3653	3.3808	3.2247	4.7308	4.2353	4.2444
15	3.9918	3.3808	2.1125	3.2247	4.5713	4.0181	4.137
16	1.7353	1.7353	2.3891	1.9342	1.9136	1.9136	1.8404
17	1.893	1.893	2.4434	2.0416	1.9342	1.9879	1.8107
18	2.1285	2.5206	2.4949	2.5766	2.5766	2.5463	2.4331
19	2.5206	2.4897	2.4897	2.5206	2.3525	2.4331	2.4331
20	2.1719	2.2068	2.1845	2.1845	2.0725	2.037	2.1502
21	1.8484	1.7364	1.7924	1.7924	1.4003	1.5684	1.7364
22	1.5524	1.4003	1.4415	1.4969	1.3717	1.3306	1.2752
23	2.2805	2.6326	3.1927	2.8475	2.1399	2.0851	1.9204
24	2.3891	2.6057	2.5206	3.1367	2.8292	2.0851	2.0302
Max	4.7125	3.6928	3.5888	3.5082	4.9411	4.7125	4.2981
Min	1.5524	1.4003	1.4415	1.4969	1.3717	1.3306	1.2752
Avg	2.8945	2.8404	2.6516	2.8100	2.8439	2.6910	2.6759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 405 / 33 KV ARJUNI MORGAON
Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7918	1.9959	1.1317	1.0642	1.1203	1.0642	1.0751
2	1.8461	2.1068	1.1317	1.0082	1.1203	1.0642	1.0751
3	1.6461	2.0513	.9619	1.1763	1.1763	1.0642	.9619
4	1.5524	2.0513	.9619	1.1763	1.1763	.9522	.9619
5	1.7364	2.1845	1.0751	1.1883	1.2323	1.1763	1.0751
6	2.0165	2.4646	1.3014	1.5844	1.4146	1.2449	1.3014
7	1.7364	2.384	1.4563	1.3014	1.2883	1.3443	1.3014
8	2.2731	2.7166	1.4712	1.358	1.3014	1.4969	1.4712
9	2.3594	3.1493	1.6078	1.6078	1.4415	1.4266	1.6804
10	2.8532	3.3122	1.8484	1.7187	1.6078	1.8296	1.8296
11	3.2922	1.4661	1.9959	1.1317	1.7741	1.8296	1.8107
12	3.1602	2.0851	1.9753	.9717	1.5524	1.6632	1.6632
13	3.0727	2.0851	1.7558	1.386	1.4415	1.7741	1.5364
14	3.3471	1.8461	1.5912	1.5364	1.0974	1.7741	1.6078
15	3.271	1.9342	1.6461	1.6632	1.8296	1.8656	1.4415
16	3.2036	1.8204	1.6655	1.6461	1.6461	1.5912	1.6289
17	2.7566	1.6644	1.6655	1.6461	1.6632	1.4969	1.5581
18	3.4928	2.2965	2.1068	2.5766	2.1845	2.2634	2.0165
19	3.3608	2.2634		2.037	2.1502	2.1502	2.0936
20	3.0807	2.037	1.9239	1.8673	1.8673	1.9805	2.037
21	2.5206	1.5844	1.6409	1.4146	1.5844	1.6409	
22	2.2731	1.358	1.358	1.0751	1.3443	1.3014	
23	2.1399	1.1317	1.2323	.9522	1.2323	1.2449	
24	1.7918	2.0513	1.1317	1.2323	1.1203	1.1203	1.1883
Max	3.4928	3.3122	2.1068	2.5766	2.1845	2.2634	2.0936
Min	1.5524	1.1317	.9619	.9522	1.0974	.9522	.9619
Avg	2.5239	2.0850	1.5059	1.4300	1.4736	1.5150	1.4912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 409 / 33KV SOUNDAD FEEDER
Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.679	.9054	.7207	.7922	.7888	.7282
2	.8002	.679	1.086	.7207	.7922	.8413	.7282
3	.8002	.679	.8573	.7207	.7922	.6962	.6653
4	.8002	.679	.8002	.5973	.7282	.6562	.6653
5	.8488	.7356	.8573	.6584	.7282	.6882	.679
6	.9717	.9054	.9145	.7762	.8402	.7716	.8402
7	.9717	.9145	.9619	.7842	.9054	.8779	.8488
8	.9145	.9619	.9145	.8488	.8488	.9145	.9145
9	1.0185	1.0185	1.0642	.9054		1.0185	.9145
10	.8962	1.2323	.5596	1.0082	.9619		1.0082
11		1.4969	1.1643	1.0751	1.1763	1.0642	1.0185
12		1.4815	.6687	1.2449	1.2323	1.1763	1.0751
13		.8316	1.4415	1.2883	1.2752	.8962	1.2323
14		1.3575	1.262	1.2883	1.2197	1.2197	1.1088
15	.2743	1.3575	1.2323	1.1643	1.262	1.1203	1.1763
16	.3155	1.262	1.3032	1.1643	1.3306	1.1283	1.2197
17	.9054	1.2226	1.2197	1.2883	1.2883	1.1088	1.1203
18	1.2003	1.358	1.1883	1.4146	1.3014	1.1883	1.1431
19	1.2003	1.3014	1.1883	1.2574	1.2003	1.0751	1.1317
20	1.0288	1.1431	1.0751	1.0288	1.0185	.9619	1.0185
21	.9145	.9619	.8402	.9145	.9054	.8488	.8488
22	.7356	.8488	.7356	.7356	.7282	.7922	.7356
23	.743	3.8204	.6653	.9054	.9054	.7282	.8488
24	.8573	.679	.9054	.7282	.8488	.9054	.7282
Max	1.2003	3.8204	1.4415	1.4146	1.3306	1.2197	1.2323
Min	.2743	.679	.5596	.5973	.7282	.6562	.6653
Avg	.8527	1.1503	.9921	.9683	1.0036	.9333	.9332

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 29-NOV-17 and 05-DEC-17

GONDIA ZONE[065]**BHANDARA CIRCLE[665]****SAKOLI O&M DIVISION[656]****SAKOLI S/DN.[391]****BU 0391****Substation No/ Name :- 067010 / 132 KV SAKOLI****Feeder No / Name : 410 / 33 KV SATALWADA****Feeder KV- 33 / INCOMING****NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)**

DATE	29-NOV-17	30-NOV-17	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5373	.8356	.7773	.8162	.8065	.6316	.5538
2	.5373	.8356	.8065	.8162	.5927	.6316	.5344
3	.5316	.8356	.7676	.8065	.6024	.6316	.5538
4	.5316	.8356	.7968	.8539	.5927	.4572	.5538
5	.591	.8951	.8436	.9339	.6687	.4687	.6173
6	.7762	1.0802	.9831	1.1317	.8459	.5967	.8116
7	.7762	.7819	.7659	.8116	.8116	.4967	.7888
8	1.0099	.8362	.8362	.8362	1.1043	.8488	1.1694
9	1.1163	.7716	.8688	.8688	1.2071	1.086	1.1163
10	.4915	.8333	.8905	.9014	1.2197	1.2071	.8488
11	1.1317	.8333	.9014	.9122	1.3443	1.262	1.262
12	1.0751	.8259	.8796	.8916	1.262	1.2071	1.182
13	.8573	.8796	.9339	.8848	1.3169		1.1946
14	1.1523	.9339	.8436	.9231	1.2071	1.2071	1.1523
15	1.2197	.9014	.8539	1.0288	1.086	1.1403	1.1283
16	.823	.7287	.823	.8905	.8539	.7287	.9156
17	.8333	.6996	.7819	.9014		.7819	.8471
18	1.2431	1.1574	1.278	1.2483	1.2334	1.1111	1.286
19	1.1717	1.1288	1.2186	1.2186	1.2186	1.174	1.1431
20	1.0122	.9859	.9991	.9991	1.0562	.9465	.9596
21	.7493	.743	.743	.7659	.7659	.6973	.743
22	.5927	.5761	.5864	.6516	.4532	.5144	.5973
23	.6316	.787	.8259	.8745	.6584	.5538	.6121
24	.5373	.5538	.7773	.8539	.787	.6121	.5441
Max	1.2431	1.1574	1.278	1.2483	1.3443	1.262	1.286
Min	.4915	.5538	.5864	.6516	.4532	.4572	.5344
Avg	.8304	.8448	.8659	.9092	.9432	.8258	.8798