

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 201 / 11 KV SAJAPUR FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0503	.0543	.0377
2	.0566	.0503	.0724	.0377
3	.0754	.0663	.0905	.0566
4	.0943	.0995	.1267	.0943
5	.132	.1802	.1646	.132
6	.2829	.2949	.2534	.2263
7	.3772	.3605	.2896	.2829
8	.3584	.2984	.3077	.3018
9	.3018	.2622	.2715	.2263
10	.1696	.1509	.1543	.1829
11	.1017	.0924	.0343	.0914
12	.1372	.1612	.1017	.0983
13	.12	.0724	.1372	.0983
14	.1715	.1433		.1017
15	.1543	.1448	.1865	.0655
16		.1867	.1715	.0492
17	.1147	.1296	.1966	.1612
18	.0829	.0905	.1341	.0905
19	.2012	.2353	.2829	.2614
20	.1677	.1991	.1886	.1867
21	.116	.128	.132	.132
22	.0838	.0724	.1132	.1132
23	.0829	.0543	.0754	.0754
24	.0747	.0503	.0566	.0373
Max	.3772	.3605	.3077	.3018
Min	.0566	.0503	.0343	.0373
Avg	.1528	.1489	.1563	.1309

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 202 / 11KV DAULATABAD FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.9282	.8507	.9619
2	.9997	.9503	.905	.9808
3		.9831	.9511	1.094
4	1.0374	1.0159	1.2127	1.226
5	1.3203	1.2631	1.2851	1.5123
6	1.9965	1.704	1.7924	1.7737
7	2.1502	1.8351	2.009	2.0182
8	2.32	1.8623	1.9909	1.905
9	2.0936	1.7814	1.829	2.1125
10	1.6956	1.7924	1.6289	1.8823
11	.8745	.788	.7291	.7682
12	.9088	.8048	.8131	.7059
13	.8573	.8048	.703	.6062
14	.7545	.7042	.6908	.6226
15	.7373	.7377	.6516	.5898
16	.8059	.6874	.6687	.639
17	.7611	.7611	.6882	.6783
18	.7293	.6802	.6718	.763
19	1.7901	1.8461	2.0748	2.0119
20	1.5581	1.7194	1.8673	1.7375
21	1.3108	1.4815	1.5655	1.5893
22	1.1271	1.2489	1.3203	1.3817
23	1.0277	1.0317	1.094	1.0082
24	1.0751	.852	.8688	.9896
Max	2.32	1.8623	2.0748	2.1125
Min	.7293	.6802	.6516	.5898
Avg	1.2595	1.1777	1.2026	1.2316

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 203 / 11KV FATIYABAD FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2321	.2374	.218
2	.213	.2347	.2374	.2347
3	.2515	.2515	.2715	.2683
4	.3395	.2818	.3052	.3353
5	.3688	.3149	.362	.4191
6	.4563	.431	.4752	.5079
7	.6371	.7127	.7287	.7865
8	.9724	1.065	1.1191	1.1305
9	.9389	1.085	1.1065	1.1469
10	.7373	.8619	.7956	.9012
11	.373	.4668	.4144	.3932
12	.3429	.3361	.4287	.3475
13	.3429	.3734	.373	.3658
14	.3086		.3601	.3658
15	.3086		.3544	.3801
16	.3944	.3734	.3601	.3841
17	.5138	.5121	.4904	.4854
18	.7045	.8326	.7167	.7468
19	.8122	.8869	.9619	
20	.663	.7602	.811	.7468
21	.5636	.6878	.7167	.6722
22	.4588	.4706	.5093	.5601
23	.4144	.3982	.4338	.4108
24	.2012	.2103	.2035	.1844
Max	.9724	1.085	1.1191	1.1469
Min	.2012	.2103	.2035	.1844
Avg	.4813	.5354	.5322	.5214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 204 / PARAS INDUSTRIAL Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	20-DEC-17
HR	Load (MW)
22	.9709
Max	.9709
Min	.9709
Avg	.9709



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 205 / ASEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1311	.1696	.1677
2	.1509	.1638	.1696	.1802
3	.1677	.1802	.1802	.213
4	.2241	.1966	.2035	.2458
5	.2683	.2458	.2401	.2949
6	.3185	.3725	.39	.3932
7	.4904	.4915	.4915	.4915
8	.4191	.5898	.6706	.5898
9	.4862	.5898	.5992	.5898
10	.3772	.4801	.4641	.5407
11	.3429	.4108	.3429	.4338
12	.3258	.3921	.3086	.3429
13	.2743	.3547	.2401	.2858
14	.2915	.3361	.2743	.2858
15		.3361	.2804	.3239
16	.3601	.3361	.2915	.3429
17	.3605	.4001	.4338	.4294
18	.6554	.6668	.6224	.6161
19	.7377	.8573	.8676	.8215
20	.6299	.6859	.7922	.7095
21	.4973	.5335	.5847	.5415
22	.3978	.4191	.4373	.4481
23	.3605	.3239	.3584	.3547
24	.1341	.4024	.1753	.1509
Max	.7377	.8573	.8676	.8215
Min	.1341	.1311	.1696	.1509
Avg	.3654	.4123	.3995	.4081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 206 / 11 KV JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.663	.8299	.7922
2	.7922	.6962	.7922	.7922
3	.8488	.7209	.7964	.9054
4	.9431	.8848	1.1694	1.094
5	1.0374	1.2125	1.3717	1.3957
6	1.2449			
7	1.2449	1.1469		1.3443
8	1.1694	1.1142		1.4003
9	.9054	1.1797	1.1317	1.2136
10	.5087	.9335	.6796	.8383
11	.7202	.6706	.6516	.3932
12	.7545	.6706	.703	.6478
13	.6859	.6706	.583	.639
14	.6962	.5765	.2743	.6226
15	.7202	.6104	.567	.5407
16	.7888	.6371	.4748	.6226
17	.6882	.6964	.6706	.7377
18	.663	.6226	.7042	.7042
19	1.1401	1.3717	1.3957	
20	1.094	1.2574	1.2449	1.1203
21	.8848	1.105	1.094	1.1203
22	.7625	.9145	.9808	.9709
23	.7042	.9145	.7922	.8215
24	.7167	.6706	.8383	.7922
Max	1.2449	1.3717	1.3957	1.4003
Min	.5087	.5765	.2743	.3932
Avg	.8529	.8670	.8450	.8868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 207 / SHAHAPUR BANJARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1844		.1753	.2012
2	.1966	.2105	.1638	.218
3	.213	.2294		.2458
4	.213	.2294	.1886	.2622
5	.2347	.213	.1966	.285
6	.2829	.2458	.2713	.2949
7	.3521	.3441	.5087	.4424
8	.3277	.3812	.5344	.5735
9	.3395	.426	.6226	.5243
10	.2401	.3601		.4915
11	.2035	.2241	.12	.1715
12	.1372		.0686	.1143
13	.1543		.1543	.1143
14	.1543	.1867	.12	.1132
15	.1543	.1698	.1417	.1524
16	.1886	.2054	.1372	.1715
17	.2785	.2477	.2263	.2241
18	.3647	.4191	.3206	.3921
19	.5533	.6287	.6535	.6161
20	.4973	.4954	.5658	.5228
21	.431	.4954	.4338	.4294
22	.3978	.4001	.3772	.4108
23	.3315	.3395	.3206	.3734
24	.1844	.3688	.1715	.218
Max	.5533	.6287	.6535	.6161
Min	.1372	.1698	.0686	.1132
Avg	.2756	.3248	.2942	.3151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 208 / Paper Mill (Saptashrungi) SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2622	.3547	.3395
2	.2662	.2458	.3258	.3547
3	.3042	.2458	.3222	.3734
4	.2829	.2915	.3439	.3921
5	.3206	.3401	.3361	.3734
6	.3584	.3887	.3982	.4294
7	.3961	.4096	.4938	.4527
8	.3734	.3978	.407	.3734
9	.3734	.4588	.3258	.4294
10	.3429	.3258	.4144	.4163
11	.5144	.4344	.3944	.4163
12	.4115	.3982	.2572	.4163
13	.2058	.2715	.2229	.4294
14	.3052	.4344	.3258	.4024
15	.4287	.3982	.333	.3077
16		.3258	.3772	.3109
17	.3605	.3018	.3584	.4668
18	.3978	.3439	.3174	.3734
19	.3353	.3258	.2801	.4108
20	.3353	.3439	.2829	.4163
21	.1989	.3258	.3584	.3982
22	.3149	.3077	.3361	.3841
23	.2949	.3292	.3961	.4024
24	.2614	.3688	.3439	.3547
Max	.5144	.4588	.4938	.4668
Min	.1989	.2458	.2229	.3077
Avg	.3332	.3448	.3461	.3927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 201 / 11KV Chowka Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1524	.1905	.2096
2		.1905	.1524	.1905	.2096
3		.1905	.2667	.2858	.2286
4		.2858	.4001	.381	.2858
5		.381	.4954	.4763	.362
6		.5716	.5906	.5716	.5716
7		.6668	.7621	.7621	.724
8		.6668	.5906	.6668	.6287
9		.5716	.4572	.5716	.5716
10		.381	.4001	.381	.4191
11		.2286	.3048	.2667	.2667
12		.2477	.2096	.2096	.1905
13		.1905	.1334	.2096	.1905
14		.2286		.1905	.1715
15		.1334		.1715	.1905
16		.1334	.1524	.1334	.1905
17		.2477	.2858	.1905	.2286
18		.4954	.4763		.4382
19		.5525	.6668	.6287	.5335
20		.381	.5716	.5144	.381
21		.3048	.381	.362	.3429
22		.2286	.2858	.2286	.2858
23	.1905	.1905	.2858	.2286	.2286
24		.1905	.1524	.1905	.2096
Max	.1905	.6668	.7621	.7621	.724
Min	.1905	.1334	.1334	.1334	.1715
Avg	.1905	.3271	.3715	.3479	.3358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 202 / 11 KV SAWANGI Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.3429	.381	.4191
2		.381	.3429	.381	.4191
3		.381	.4001	.381	.4382
4		.381	.4572	.4763	.4763
5		.4763	.5335	.4763	.5335
6		.4763	.5716	.5716	.5716
7		.5716		.5716	.5716
8		.5716		.5716	
9		.5716			
10		.5716			
11		1.2384	1.4861	1.5623	1.5432
12		1.8671	2.0957	2.0957	1.9243
13		2.0767	1.7718	2.2481	2.0576
14		2.0957	1.7147	2.1338	1.8671
15		2.0767	1.7147	2.0957	1.8099
16		1.9243	1.6194	1.9052	1.9243
17		1.2955	1.9052	1.9052	1.7147
18			1.5242		1.4861
19		.5716	.5716	.5716	.5716
20		.5525	.5716	.5716	.5716
21		.5144	.4763	.5335	.5525
22		.4763	.381	.4763	.5335
23	.381	.4001	.381	.4191	.4572
24		.381	.3239	.381	.4191
Max	.381	2.0957	2.0957	2.2481	2.0576
Min	.381	.381	.3239	.381	.4191
Avg	.381	.8797	.9593	.9862	.9934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 203 / 11 KV CHOWKA Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
7		.6668
8	.6668	
Max	.6668	.6668
Min	.6668	.6668
Avg	.6668	.6668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 204 / Lingdari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0572	.0953	.0953
2		.0953	.0572	.0953	.0953
3		.0953	.0572	.0953	.0953
4		.1905	.0953	.0953	.1143
5		.1905	.1334	.1905	.1524
6		.2858	.1905	.1905	.1715
7		.2858	.2286	.1905	.2096
8		.2858	.1715	.1905	.1524
9		.1905	.1524	.1524	.1143
10		.1143	.1143	.1334	.1143
11		.1905	.1524	.2286	.1524
12		.2096	.2286	.2667	.1905
13		.1905	.2858	.2477	.2096
14		.1715		.2096	.2667
15		.2096		.2286	.1905
16		.1905	.1524	.2096	.2096
17		.2477	.1905	.2096	.3048
18		.2477	.2858		.2667
19		.1524	.1905	.1715	.2286
20		.1334	.1905	.1905	.2096
21		.0953	.0953	.1143	.1905
22		.0572	.0953	.0953	.1715
23	.0953	.0572	.0953	.0762	.1524
24		.0953	.0572	.0953	.0762
Max	.0953	.2858	.2858	.2667	.3048
Min	.0953	.0572	.0572	.0762	.0762
Avg	.0953	.1699	.1490	.1640	.1723



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 205 / Sawangi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.6859	.6668	.8002
2		.7621	.6668	.7621	.8002
3		.8573	.9526	.9526	.8573
4		1.0479	1.2384	1.2384	1.1431
5		1.3336	1.5432	1.7147	1.4289
6		1.7147	1.7337	1.9624	1.6766
7		2.0005	2.0957	2.0005	2.0386
8		2.0005	2.0195	1.9052	1.9624
9		1.6194	1.7337	1.7909	1.6766
10		1.2193	1.3717	1.2193	1.4098
11		.9526	.9907	1.1431	1.0098
12		.8192	.8383	.9145	.8764
13		.6287	.724	.8002	.7621
14		.5716		.7621	.8002
15		.6668		.8383	.7049
16		.8192	.7621	.8573	.8954
17		1.1431	1.1431	1.105	1.2955
18		1.7147	1.7147		1.7147
19		1.7337	1.9052	1.8099	1.829
20		1.3717	1.5242	1.5242	1.4861
21		1.1622	1.1431	1.1622	1.2955
22		.9907	.9526	.8573	1.105
23	.8573	.8573	.8573	.8002	.9145
24		.7621	.7049	.7621	.8002
Max	.8573	2.0005	2.0957	2.0005	2.0386
Min	.8573	.5716	.6668	.6668	.7049
Avg	.8573	1.1463	1.2410	1.1978	1.2201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 206 / 11 KV Tuljapur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.2477	.2858	.2286
2		.2858	.2286	.2858	.2096
3		.2858	.2096	.2858	.2096
4		.2858	.2286	.2858	.2096
5		.2858	.2286	.2858	.2286
6		.2858	.2286	.2858	.2286
7		.2858	.2286	.2858	.2286
8		.2858	.3048	.2858	.3048
9		.2858	.381	.3429	.4954
10		.8764	.7811	.7621	.9145
11		1.1431	1.3336	1.1431	1.2955
12		1.2384	1.3717	1.105	1.3336
13		.7621	.6097	.9526	.9526
14		1.1622	1.0669	1.2955	.8764
15		.6478	1.1812	.9145	1.0288
16		1.1622	1.3336	.7621	.9907
17		1.1622	1.1431	.9526	1.3717
18		.4572	1.0479		1.1431
19		.2858	.381	.2858	.4382
20		.3048	.381	.2858	.362
21		.2858	.2858	.2477	.3239
22		.2858	.2858	.2096	.3048
23	.2858	.2667	.2858	.2286	.2858
24		.2858	.2667	.2858	.2286
Max	.2858	1.2384	1.3717	1.2955	1.3717
Min	.2858	.2667	.2096	.2096	.2096
Avg	.2858	.5374	.5850	.5244	.5914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 207 / 11 KV Unique Stone crusher SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.0191
2		.0191	.0191	.0191	.0191
3		.0191	.0191	.0191	.0191
4		.0191	.0191	.0191	.0191
5		.0191	.0191	.0191	.0191
6		.0191	.0191	.0191	.0191
7		.0191	.0191	.0191	.0191
8		.0191	.0191	.0191	.0191
9		.0191	.0191	.0191	.0191
10		.0191	.0191	.0572	.0191
11		.0191	.0191	.0572	.0191
12		.0191	.0191	.1334	.0191
13		.0191	.0191	.1524	.0191
14		.0191	.0191	.1334	.0191
15		.0191	.0191	.0762	.0191
16		.0191	.1715	.1334	.0191
17		.0191	.1524	.1905	.0572
18		.0191	.0953		.0381
19		.0191	.1143	.0381	.0191
20		.0191	.1143	.0191	.0191
21		.0191	.0953	.0191	.0191
22		.0191	.0572	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191
24		.0191	.0191	.0191	.0191
Max	.0191	.0191	.1715	.1905	.0572
Min	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0469	.0539	.0215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 201 / 11KV GROWTH CENTRE I

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4382	.4557	.4572
2	.5959	.5609	.5959	.4572
3	.631	.6661	.6661	.4763
4	.6661	.7011	.7011	.5335
5	.7011	.7362	.7362	.6859
6	.7362	.7888	.7712	.8002
7	.9816	.964	.9114	1.0669
8	.9816	.9816	.9816	1.1812
9	.8063	.7888	.9526	1.1431
10	.9145	.6859	.724	.8192
11		.5906	.5716	.6859
12	.4572	.5144	.4954	.4572
13		.4382	.4191	.4572
14		.4954	.4382	.4191
15		.4572	.4954	.4191
16		.4191	.4572	.4382
17	.4763	.2286	.4207	.4763
18	.6859	.6859	.6767	.5906
19	.7811	.7621	.7499	.8002
20	.6859	.7811	.7682	.8383
21	.6859	.6859	.6767	.6859
22	.6478	.6668	.5853	.6668
23	.4382	.4557	.4954	.4954
24	.4382	.4382	.4207	.4572
Max	.9816	.9816	.9816	1.1812
Min	.4382	.2286	.4191	.4191
Avg	.6738	.6221	.6319	.6462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 202 / 11KV A.S.CLUB FEEDER Ag SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0381
2	.0377	.0377	.0377	.0381
3	.0377	.0377	.0377	.0381
4	.0377	.0566	.0377	.0381
5	.0377	.0754	.0351	.0572
6	.0377	.0943	.0377	.0762
7	.0943	.0943	.0351	.0953
8	.0566	.0943	.0377	.1143
9	.132	.0351	.0381	.1334
10	.1097	.1334	.1143	.0953
11	.5487	.5906	.5716	.6097
12	.6219	.6668	.6478	.6478
13		.4954	.6859	.0762
14		.6478	.6097	.0381
15		.6097	.5716	.5716
16		.5906	.6668	.2858
17	.2858	.5716	.567	.362
18	.3429	.5716	.2561	.3429
19	.0953	.1334	.0732	.0762
20	.0572	.0953	.0732	.0762
21	.0572	.0762	.0366	.0762
22	.0572	.0762	.0366	.0381
23	.0566	.0377	.0381	.0381
24	.0377	.0377	.0377	.0381
Max	.6219	.6668	.6859	.6478
Min	.0377	.0351	.0351	.0381
Avg	.1390	.2457	.2217	.1667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 203 / 11KV P.M.CHORDIA FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0351	.0351	.0572
2	.0526	.0351	.0526	.0572
3	.0526	.0351	.0526	.0572
4	.0526	.0526	.0526	.0572
5	.0526	.0526	.0526	.0572
6	.0526	.0526	.0526	.0572
7	.0701	.0701	.0701	.0762
8	.0701	.0701	.0526	.0762
9	.0526	.0701	.0762	.4954
10	.0732	.2477	.1524	.2477
11	.2378	.2477	.1715	.2286
12	.2378	.3048	.0762	.1334
13		.1143	.0762	.1143
14		.1524	.1905	.1524
15		.1905	.1715	.1334
16		.2286	.1524	.1143
17	.1334	.1905	.1646	.0572
18	.2096	.1524	.2378	.1143
19	.0953	.1143	.1097	.0762
20	.1143	.1143	.1097	.0762
21	.1143	.1143	.1097	.0762
22	.1143	.0953	.1097	.0572
23	.1052	.1052	.0953	.0953
24	.0701	.0701	.0701	.0762
Max	.2378	.3048	.2378	.4954
Min	.0526	.0351	.0351	.0572
Avg	.1007	.1215	.1039	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 204 / 11KV Growth Center II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2279	.2103	.2667
2	.1928	.1928	.1928	.2667
3	.2103	.2103	.1928	.2477
4	.2279	.2279	.2103	.2667
5	.2454	.2454	.2279	.2858
6	.2629	.2629	.2454	.2858
7	.2629	.2454	.2279	.3048
8	.2629	.298	.2629	.3048
9	.2454	.2454	.2477	.2858
10	.2561	.2286	.2286	.2286
11	.2378	.2286	.2477	.2096
12	.2012	.2286	.2286	.1905
13		.1334	.1905	.1334
14		.1143	.1143	.1524
15		.1524	.1334	.1334
16		.2096	.1143	.1143
17	.1905	.2286	.1646	.1143
18	.2858	.2667	.2926	.2667
19	.3048	.3429	.3475	.3239
20	.3429	.3429	.3292	.3429
21	.3239	.3048	.2926	.3048
22	.3048	.3048	.2743	.3048
23	.2454	.2454	.2858	.2667
24	.2629	.2454	.2279	.2477
Max	.3429	.3429	.3475	.3429
Min	.1905	.1143	.1143	.1143
Avg	.2538	.2389	.2287	.2437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 205 / 11KV Sara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9114	.9114	.9114	.8764
2	.9465	.9465	1.3321	.8764
3	1.3321	1.3321	1.7177	.9526
4	1.7177	1.7177	2.1033	1.6004
5	2.1033	2.2786	2.3663	2.0576
6	2.2786	2.5941	2.5766	2.6673
7	2.6818	2.6642	2.6993	2.9912
8	2.6818	2.6993	2.7168	2.915
9	2.1384	2.2961	2.6292	2.5911
10	1.9204	2.0005	1.9624	1.9624
11	1.6644	1.6956	1.5623	1.5432
12	1.2986	1.3527	1.086	1.4098
13		1.2384	1.086	1.2574
14		1.2574	1.2193	1.1812
15		1.2193	1.1622	1.1241
16		1.2003	1.2384	1.2193
17	1.4861	1.6004	1.4632	1.5051
18	2.0005	2.0195	1.8839	1.9624
19	2.2291	2.2291	2.2497	2.191
20	1.9814	1.8861	1.8839	
21	1.7718	1.6575	1.6644	1.6766
22	1.467	1.4098	1.2803	1.3336
23	.9991	.9465	1.0669	1.086
24	.9465	.929	.8063	.8954
Max	2.6818	2.6993	2.7168	2.9912
Min	.9114	.9114	.8063	.8764
Avg	1.7278	1.6701	1.6945	1.6468



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 206 / 11KV South City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2454	.2629	.2477
2	.2804	.298	.298	.2477
3	.3155	.3155	.3155	.2667
4	.3506	.3506	.3506	.3048
5	.3856	.3856	.3856	.381
6	.4031	.4031		.4382
7	.4557	.4908	.4908	.5144
8	.4557	.4733	.5258	.5525
9	.3681	.4382	.5144	.4954
10	.439	.4191	.4763	.4382
11	.3841	.362	.4191	.3429
12	.3658	.381	.3429	.362
13		.3239	.3239	.4191
14		.2477	.3239	.3239
15		.2667	.3048	.3239
16		.2858	.3429	.3429
17	.362	.3429	.3292	.3239
18	.4382	.4001	.3841	.4001
19	.4382	.4382	.439	.4382
20	.4382	.4191	.4572	.4572
21	.381	.381	.3475	.3429
22	.3429	.3239	.2926	.3239
23	.2629	.2279	.2667	.2667
24	.2279	.2279	.2103	.2477
Max	.4557	.4908	.5258	.5525
Min	.2279	.2279	.2103	.2477
Avg	.3670	.3520	.3654	.3667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 209 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6661	.6661	.631	1.086
2		.7011	.6661	.7011	1.086
3		.7362	.7011	.7362	1.0669
4		.7712	.7712	.8063	1.086
5		.8413	.8413	.8413	1.105
6		.8764	.8589	.8764	1.105
7		.929	.929	.929	1.1812
8		1.1919	1.1919	.9816	1.1812
9		1.3321	1.3321	1.2193	1.829
10		1.9204	1.9814	1.3527	2.0576
11		1.9022	2.1338	2.0005	1.9433
12		1.9753	1.7147	1.7147	1.6575
13			1.448	1.5623	1.5813
14			2.0005	2.0767	1.9052
15			1.9433	2.0957	2.1338
16			1.829	2.0386	2.0957
17		1.2765	1.3717	1.8839	2.1338
18		1.1812	1.2003	1.6278	1.0669
19		1.3527	1.2955	1.5181	1.3527
20		1.1812	1.0479	1.0059	1.2955
21		1.0288	.9526	1.0425	1.0669
22		.8764	.8954	.8048	1.086
23	.7712	.9465	.7011	.7621	1.105
24		.7362	.9816	.7888	1.105
Max	.7712	1.9753	2.1338	2.0957	2.1338
Min	.7712	.6661	.6661	.631	1.0669
Avg	.7712	1.1211	1.2273	1.2499	1.4297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 201 / 11 KV Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.208	.1949	.1907	.1928
2		.2254	.1928	.208	.1928
3		.2686	.2103	.2229	.2454
4		.3258	.2279	.2915	.3294
5		.3898	.3467	.3561	.5028
6		.4382	.4973	.4239	.5144
7		.5083	.5375	.5197	.6274
8		.5548	.5144	.7209	.7122
9		.703	.4917	.6783	.6613
10		.631	.4239	.6516	.4239
11		.5784	.3086	.3988	.3506
12		.3189	.5375	.333	.3012
13		.2658	.5201	.3155	.3224
14		.3012	.5083	.3012	.3077
15		.3189	.1402	.3189	.3292
16		.3189	.1063	.3189	.362
17		.3898	.1402	.3544	.4477
18		.4607	.4207	.4961	.4961
19		.5194	.3814	.6733	.5258
20		.5373	.3641	.443	.443
21		.4477	.3155	.3045	.3856
22		.2686	.2629	.3012	.3045
23	.2534	.2149	.2103	.2149	.2715
24		.2172	.197	.1907	.197
Max	.2534	.703	.5375	.7209	.7122
Min	.2534	.208	.1063	.1907	.1928
Avg	.2534	.3921	.3354	.3845	.3936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 202 / 11 KV Patoda Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5258	.6379	.5548	.6836
2		.5721	.6661	.5895	.7362
3		.6588	.6836	.6173	.7537
4		.6935	.7186	.6859	.7628
5		.7282	.7975	.7461	.8322
6		.7716	.9259	.8139	.7888
7		.8573	.9709	.9221	.9835
8		.9259	.9602	1.0227	1.0513
9		.9259	.9835	.9496	1.0059
10		.964	.9665	.9774	1.0174
11		.1949	.1886	.2254	.2801
12		.2126	.2254	.2303	.2427
13		.2303	.208	.2454	.2507
14		.2303	.2103	.2454	.2801
15		.2303	.2279	.2658	.2987
16		.2303	.2658	.2658	.3174
17		.2658	.2629	.3012	
18		.3189	.2804	.3544	.2987
19		.3012	.2774	.3721	.3361
20		.2865	.2601	.3366	.2987
21		.2686	.2103	.2835	.2801
22		.2507	.1753	.2481	.2427
23	.2801	.2149	.1402	.2507	.2241
24		.2614	.197	.1387	.2328
Max	.2801	.964	.9835	1.0227	1.0513
Min	.2801	.1949	.1402	.1387	.2241
Avg	.2801	.4633	.4767	.4851	.5304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 203 / WALDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.3898	.3988	.3506
2	.4334	.4207	.4334	.4207
3	.4733	.4908	.4801	.4161
4	.6068	.5258	.5144	.5201
5	.7202	.6241	.5765	.583
6	.823	.7888	.6443	.6173
7	.9431	.9362	.7712	.8139
8	1.0802	.9602	.9054	.8817
9	1.0288	1.0174	.9835	1.0059
10	.9602	.9496	.9259	.9496
<b>Max</b>	<b>1.0802</b>	<b>1.0174</b>	<b>.9835</b>	<b>1.0059</b>
<b>Min</b>	<b>.4031</b>	<b>.3898</b>	<b>.3988</b>	<b>.3506</b>
<b>Avg</b>	<b>.7472</b>	<b>.7103</b>	<b>.6634</b>	<b>.6559</b>

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 201 / Adgaon(Sarak)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3113	.426	.4424	.3605
2	.3277	.4752	.4752	.4096
3	.3277	.5407	.4915	.4915
4	.3441	.7373	.5898	.5735
5	.4588	.9831	.6718	.7373
6	.5407	1.1305	.8848	.9012
7	.7537	1.2289	1.6712	1.5402
8	1.1797	1.6385	1.9662	2.1628
9	.9012	1.5565	1.6057	1.9498
10	.9012	1.1469	1.2289	1.278
11	.1311	.1147	.1311	.1311
12	.1147	.1147	.1147	.1147
13	.0983	.0819	.1147	.0983
14	.0819	.0819	.1147	.0819
15	.0819	.0983	.0983	.0983
16	.0819	.1147	.0983	.0983
17	.1147	.1311	.1147	.0983
18	.1638	.1802	.1638	.0983
19	.1966	.1966	.213	.213
20	.2294	.1966	.1802	.213
21	.1638	.1638	.1638	.1966
22	.1475	.1475	.1638	.1802
23	.1475	.1311	.1475	.1802
24	.1802	.1475	.1311	.1475
Max	1.1797	1.6385	1.9662	2.1628
Min	.0819	.0819	.0983	.0819
Avg	.3325	.4902	.4991	.5148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 202 / Mandki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0655	.0686	.0762
2	.1132	.0655		.0762
3	.1132	.0655	.0686	.0762
4	.1132	.0819	.0686	.0953
5	.132	.0983	.0686	.0953
6	.1509	.1147	.1052	.1143
7	.1886	.1147	.1595	.1143
8	.1509	.0983	.1753	.1143
9	.0983	.1402	.0953	.0943
10	.0655	.12	.0953	.0943
11	.852	.9259	.7956	.7202
12	1.2289	1.3717	1.1012	1.1488
13	1.3108	1.3375	1.1768	1.3375
14	1.2452	1.286	1.2597	1.1401
15	1.1469	1.2517	1.1797	.9556
16	.9667	1.166	1.1568	
17	.8192	.9774	1.073	
18	.7209	.9945	.8551	
19	.1475	.197	.1143	.2075
20	.1638	.1829	.0953	.1698
21	.1638	.1829	.0953	.1698
22	.1475	.1402	.0953	.132
23	.1475	.1227	.0953	.1509
24	.1132	.1475	.1227	.0762
Max	1.3108	1.3717	1.2597	1.3375
Min	.0655	.0655	.0686	.0762
Avg	.4339	.4687	.4400	.3409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 203 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.3841	.3258	.3801
2	.4207	.3841	.3429	.3801
3	.4207	.3841	.3772	.4163
4	.5487	.6584	.4557	.5359
5	.7316	.823	.691	.7468
6	1.0608	1.134	1.0164	1.0374
7	1.2254		1.2637	1.2071
8	1.0608	.9511	1.0719	1.0456
9	.823	.7602	.9335	.8413
10	.6219	.5784	.6653	.7316
11	.695	.5609	.5544	.5121
12	.5487	.4287	.4525	.4572
13	.439	.3772	.4344	.3841
14	.4024	.3601	.362	.3658
15	.439	.3601	.4344	.3841
16	.4755	.5258	.4163	
17	.6584	.691	.5487	
18	.8962	.691	.7392	
19	.9511	1.0059	.9619	1.0974
20	.9145	.8145	.8029	.8048
21	.6219	.6485	.6099	.6584
22	.5487	.463	.5249	.5487
23	.439	.4207	.3982	.4207
24	.4024	.4207	.3258	.3801
Max	1.2254	1.134	1.2637	1.2071
Min	.4024	.3601	.3258	.3658
Avg	.6569	.6011	.6129	.6350



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 204 / 11 KV Jatwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3887	.4115	.3563
2	.3086	.3932	.4115	.3725
3	.3086	.3887	.5144	.4372
4	.3086	.4915	.6173	.5344
5	.3601	.5898	.9774	.7611
6	.463	.9717	1.2174	1.0202
7	.9774	1.6032	1.989	1.6518
8	1.6975	2.1628	2.572	2.5101
9	.8779	2.1262	2.4086	2.6658
10	.823	1.8004	1.9989	2.1125
11	.6584	.1457	.1943	.1629
12	.6036	.5316	.1619	.2172
13	.6036	.6173	.1619	.1629
14	.7682	.6173	.1457	.1629
15	.7133	.6173	.1619	.1629
16	.6584	.6173	.1619	.1629
17	.6584	.6173	.1781	.1629
18	.6584	.6687	.5344	.1629
19	.5407	.6516	.6802	.8145
20	.4424	.5658	.6478	.5973
21	.3441	.3944	.421	.543
22	.2915	.3086	.3725	.3801
23	.2622	.3086	.2753	.3258
24	.2715	.2429	.2572	.2267
Max	1.6975	2.1628	2.572	2.6658
Min	.2622	.1457	.1457	.1629
Avg	.5795	.7425	.7280	.6945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 201 / 11 Kv Sajapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6344	.5975	.5658	.6001
2	.6687	.5601	.5658	.6344
3	.703	.5601	.5487	.6173
4	.7373	.5415	.6344	.6516
5	.7716	.7095	.7545	.703
6	.8059	.7842	.823	.7716
7	.8573	.8402	.8745	.8402
8	.7716	.8215	.7888	.7202
9	.7655	.7468	.6859	.6516
10	.7282	.6516	.6859	.6516
11	.6348	.4572	.4801	.4458
12	.5415	.442	.4572	.463
13	.5788	.4572	.5182	.4475
14	.5975	.4572	.5182	.4578
15	.5975	.4877	.5335	.463
16	.5228	.4725	.4572	.463
17	.5228	.4572	.3963	.4481
18	.5041	.3048	.2915	.4481
19	.7095	.823	.7202	.6908
20	.8029	.7202	.7888	.7842
21	.7655	.703	.703	.7655
22	.7095	.6001	.6516	.7282
23	.6535	.5658	.583	.6535
24	.6001	.6348	.5487	.5658
Max	.8573	.8402	.8745	.8402
Min	.5041	.3048	.2915	.4458
Avg	.6743	.5998	.6073	.6111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 202 / 11kv Karodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2614	.2058	.2229
2	.2401	.2427	.2401	.2572
3	.2572	.2801	.2743	.2915
4	.3258	.3174	.3429	.3429
5	.4115	.3547	.5144	.3601
6	.6001	.7282	.6173	.4115
7	.6001	.7282	.6516	.4115
8	.5487	.6722	.6001	.3944
9	.5601	.5788	.5487	.3601
10	.3734	.4973	.3086	.3258
11	.4854	.3048	.3258	.3258
12	.5415	.3963	.4801	.3772
13	.5975	.4572	.4877	.39
14	.6722	.4572	.503	.4755
15	.5788	.4572	.5182	.4239
16	.5975	.442	.4572	.4115
17	.5415	.4268	.3963	.4481
18	.4481	.3658	.4115	.3734
19	.3734	.5144	.3258	.3921
20	.3547	.3601		.4108
21	.3326	.2915	.2229	.2772
22	.2614	.2229	.2401	.2614
23	.2427	.2229	.1886	.2427
24	.2915	.2427	.2058	.2401
Max	.6722	.7282	.6516	.4755
Min	.2401	.2229	.1886	.2229
Avg	.4379	.4093	.3942	.3512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 203 / 11 kv INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.5228	.5144	.6097
2	.4458	.5041	.4973	.5639
3	.463	.4854	.4973	.503
4	.4572	.5041	.5144	.4877
5	.442	.5228	.4973	.4572
6	.4877	.5788	.5316	.4801
7	.6001	.6535	.5144	.5335
8	.6001	.6722	.6344	
9	.9896	.8962	.9431	.8535
10	1.4937	1.3032	1.0669	1.1584
11	1.3256	1.406	1.2346	1.3203
12	1.1203	1.1317	1.0059	1.3889
13	1.307	1.0288	.823	.703
14	1.6244	1.2174	1.0669	1.0642
15	1.4563	1.4746	1.5242	1.5432
16	1.6991	1.3203	1.5394	.9945
17	1.5123	1.2689	1.5394	1.4377
18	1.6804	.9602	1.3717	.8775
19	1.0903	.8573	.9602	.7655
20	.8962	.7888	.5792	.6722
21	.7842	.6173	.6097	.6535
22	.6535	.583	.6401	.6161
23	.5788	.5144	.7011	.5601
24	.4973	.5415	.5316	.6401
Max	1.6991	1.4746	1.5394	1.5432
Min	.442	.4854	.4973	.4572
Avg	.9452	.8481	.8474	.8210

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 201 / 11 KV SUKHNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.1524
2	.1905	.1524	.1905	.1524
3	.1905	.1905	.1905	.1524
4	.1905	.2286	.2858	.1905
5	.2858	.2858	.2858	.2858
6	.381	.381	.381	.4191
7	.4763	.4763	.4763	.4191
8	.4763	.381	.381	.4001
9	.381	.381	.381	.2858
10	.381	.381	.3048	.2667
11	.2286	.1905	.2286	.2096
12		.1905	.1524	.1905
13	.1524	.1905	.1524	.0762
14	.1905	.1905	.1143	.1143
15	.381	.381	.4572	.381
16	.5716	.4763	.381	.4572
17	.5716	.381	.5335	.4954
18	.381	.4763	.4954	.4572
19	.2858	.2858	.381	.381
20	.2858	.2858	.3239	.2858
21	.2858	.2858	.2667	.2286
22	.1905	.2858	.2477	.2286
23		.1905	.1334	.1334
24	.1905	.1524	.1905	.1524
Max	.5716	.4763	.5335	.4954
Min	.1524	.1524	.1143	.0762
Avg	.3118	.2905	.2969	.2715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 202 / 11 KV KHODEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1524
2	.1905	.1905	.1905	.1524
3	.2858	.1905	.2858	.2286
4	.1905	.2858	.381	.362
5	.381	.381	.381	.4572
6	.4763	.4763	.5716	.5335
7	.4763	.4763	.4763	.5144
8	.4763	.381	.381	.4954
9	.381	.381	.2858	.4191
10	.2286	.381	.1715	.381
11	.1905	.1905	.2096	.3048
12		.1905	.1524	.1715
13	.0762	.1905	.1334	.1905
14	.1905	.1905	.1334	.1524
15	.3048	.2858	.4001	.4382
16	.381	.381	.4572	.381
17	.381	.381	.4001	.362
18	.381	.381	.4572	.3429
19	.2858	.381	.3429	.2858
20	.2858	.2858	.2477	.1905
21	.1905	.2858	.2477	.1905
22	.1905	.2858	.2096	.1524
23		.1905	.1524	.1524
24	.1905	.1905	.1905	.1524
Max	.4763	.4763	.5716	.5335
Min	.0762	.1905	.1334	.1524
Avg	.2875	.2977	.2937	.2985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 203 / 11 KV MURADABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.9526	.6668
2	.5716	.5716	.7621	.6668
3	.5716	.5716	.5716	.724
4	.5716	.5716	.7621	.7621
5	.5716		.7621	.8954
6	.5716		.9526	.9145
7	.9526		1.1431	.9526
8	.9526		1.0479	.9335
9	.7621		.7621	.8192
10	.5716		.7811	.724
11	.4763		.4763	.4191
12			.3429	.3239
13	.381	.381	.3239	.2667
14	.381	.381	.2667	
15	.381	.381	.2667	.3429
16	.381	.381	.3048	.381
17	.7621	.5716		.5525
18	1.1431	1.1431	.8764	1.0288
19	1.1431	.9526	1.3336	1.2384
20	.8573	.8573	.9526	.9145
21	.5716	.7621	.743	.7621
22	.5716	.5716	.6287	.5906
23		.7621	.8002	.7621
24	.5716	.5716	1.1431	.724
Max	1.1431	1.1431	1.3336	1.2384
Min	.381	.381	.2667	.2667
Avg	.6495	.6252	.7372	.7115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 204 / 11 KV RAJAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9526	.9526	.8573
2	1.1431	.9526	.9526	.8573
3	1.2384	1.1431	1.3336	1.0479
4	1.5242	1.5242	1.7147	1.3336
5	1.9052	2.2862	2.2862	2.0767
6	3.0483	3.0483	3.0483	3.1245
7	1.9052	2.2862	2.2862	2.2481
8	2.8578	3.2388	2.191	2.6863
9	3.0483	2.0005	2.7625	2.7435
10	2.9531	2.0957	2.2862	2.553
11		2.191	2.3243	2.3815
12		2.191	2.4006	2.3815
13	2.6673	1.9052	2.1719	2.3243
14	2.6673	1.8099	1.8861	1.9624
15		1.7147	1.0288	
16		1.5242	1.3717	1.2765
17	1.9052	2.0957	1.7528	1.9814
18	3.0483	3.0483	2.6292	2.9531
19	2.6673	2.4768	2.934	2.7054
20	2.2862	2.0957	2.1148	2.0576
21	1.5242	1.7147	1.5813	1.5623
22	1.3336	1.3336	1.2955	1.2574
23		.9526	1.0288	1.0288
24	1.1431	.9526	.9526	.9145
Max	3.0483	3.2388	3.0483	3.1245
Min	1.1431	.9526	.9526	.8573
Avg	2.1592	1.8973	1.8869	1.9267



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 205 / 11 KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.5716	.4763
2	.5716	.5716	.5716	.4763
3	.5716	.5716	.7621	.5716
4	.5716	.9526	.9526	.8002
5	1.2384	1.3336	1.3336	1.1241
6	1.7147	1.9052	1.6194	1.6956
7	1.2384	1.5242	1.7147	1.467
8	1.7147	1.7147	1.9052	1.7147
9	1.9052	1.7147	1.9052	1.6385
10	1.7147	1.7147	1.7909	
11	1.3336	1.5242	1.5432	1.2765
12	1.3336	1.5242	1.3336	1.467
13	1.3336	1.3336	1.2955	1.1812
14		1.2384	1.1812	1.0669
15	.5716	.9526	.4954	
16	.7621	.6668	.5716	.6097
17	1.1431	1.1431	.9145	.8954
18	1.5242	1.5242	1.4098	1.5813
19	1.5242	1.3336	1.6766	1.5623
20	1.1431	1.2384	1.1622	1.0288
21	.8573	.9526	.8192	.7811
22	.7621	.6668	.6478	.6668
23		.5716	.4954	.5144
24	.5716	.5716	.5716	.4954
Max	1.9052	1.9052	1.9052	1.7147
Min	.5716	.5716	.4954	.4763
Avg	1.1215	1.1590	1.1352	1.0496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 206 / EHV THAPTI TANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2858	.5716	.4191
2	.381	.2858	.381	.381
3	.381	.2858	.381	.381
4	.381	.381	.5716	.4191
5	.5716	.5716	.5716	.4954
6	.7621	.8764	.6668	.6097
7	.9526	.8573	.7621	.8002
8	.9526	.7621	.9526	1.0669
9	.9526	.6668	1.1431	1.2193
10	.5716	.5716	1.1812	1.2193
11	.381	.381	1.2193	
12		.2858	1.2574	
13	.381	.2858	1.2574	.1905
14	.381	.9526	1.1431	.3048
15	.381	1.1431	1.1812	.381
16	.381	1.3336	1.105	.4191
17	.5716	1.3336	1.2955	.5335
18	.7621	1.1431	1.1431	.724
19	.6668	.9526	.8764	
20	.5716	.7621	.6478	.6097
21	.381	.5716	.6097	.4954
22	.4763	.6668	.6097	.4572
23		.6668	.4954	.4191
24	.381	.2858	.5716	.4572
Max	.9526	1.3336	1.2955	1.2193
Min	.381	.2858	.381	.1905
Avg	.5456	.6795	.8581	.5715

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 207 / ANTERWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.6668	.9526	.7621
2	.381	.5716	.7621	.7621
3	.381	.5716	.5716	.7621
4	.381	.5716	.7621	.7621
5	.4763	.5716	.9526	.8954
6	.4763	.6668	1.0479	1.1431
7	1.3336	1.3336	1.1431	1.1431
8	1.1431	1.0479	1.1431	1.105
9	.9526	.8573	.8573	.8573
10		.7621	.5525	.6478
11		.5716	.2858	.3429
12		.381	.2667	.4572
13		.381	.3239	.4382
14		.381	.4382	.5525
15	.381	.4763	.4382	.7049
16	.4763	.4763		.6668
17	.7621	.6668	.6478	.7621
18	1.0479	1.0479	.9526	1.1431
19	.9526	.9526	.9907	1.0479
20	.7621	.7621	.7049	.7621
21	.5716	.5716	.4763	.4763
22	.4763	.4763	.4191	.4191
23	.6668		.8764	.8764
24	.4763	.6668	.9526	.9526
Max	1.3336	1.3336	1.1431	1.1431
Min	.381	.381	.2667	.3429
Avg	.6568	.6710	.7182	.7684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 201 / 11 KV KARMAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0754	.0377	.0943
2		.0754	.0754	.0377	.0754
3		.0754	.0943	.0754	.0377
4		.0943	.0754	.0943	.0754
5		.1132	.0943	.0943	.0943
6		.1509	.1509	.1132	.0754
7		.2263	.2452	.1886	.1886
8		.2263	.2263	.132	.2263
9		.1698	.1698	.1886	.1886
10		.1698	.132	.1509	.1509
11		.5533	.4191	.4359	.503
12		.5197	.503	.4694	.4694
13		.5533	.5868	.5365	.4694
14		.57	.5533	.57	.6413
15		.6036	.503	.503	.5365
16		.57	.57	.503	.503
17		.5868	.5365	.503	.4694
18		.5365	.4694	.4024	.4359
19		.1509	.1886	.1509	.1698
20		.132	.2263	.132	.1509
21		.1132	.1509	.1132	.1132
22		.0943	.0943	.0943	.0943
23	.0754	.0754	.0754	.0754	.0943
24		.0754	.0754	.0566	.0754
Max	.0754	.6036	.5868	.57	.6413
Min	.0754	.0754	.0754	.0377	.0377
Avg	.0754	.2713	.2621	.2358	.2472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 202 / 11 KV GADHE JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545		.7712	.8383	.7042	.7545
2				.7545	.7545	.8048	.8383
3				.8048	.8383	.8718	.7545
4				.8383	.7545	1.0395	.8383
5				1.1065	.9389	1.2071	1.3077
6				1.3748	1.3748	1.3413	1.5927
7				1.6766	2.0454	1.9281	2.0119
8				1.8778	2.5987	2.5149	2.7161
9				2.0119	2.4981	2.7999	2.7664
10				2.0119	2.1628	2.2801	2.2634
11				.6602	.7733	.7922	.6036
12				.6224	.7922	.5281	.5281
13				.6413	.547	.3395	.5658
14				.6036	.3961	.3772	
15	2.1293				.5281	.4904	.5658
16				.6413	.6036	.6036	.5658
17				.7356	.9619	.9431	.9808
18				1.2826	1.6032	1.358	1.5089
19	1.4712			1.6032	1.6409	1.6975	1.6221
20	1.2071			1.2449	1.4712	1.358	1.3203
21				.9431	.9808	.9431	.9808
22				.7545	.9808	.7167	.7167
23			.7545	.7922	.6224	.6413	.6036
24				.679	.679	.5847	.6036
Max	2.1293	.7545	.7545	2.0119	2.5987	2.7999	2.7664
Min	1.2071	.7545	.7545	.6036	.3961	.3395	.5281
Avg	1.6025	.7545	.7545	1.0623	1.1410	1.1194	1.1743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 203 / 11 KV SHEKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658		1.0059	1.0898	.8048	.8383
2				1.0059	1.1736	.8718	.9221
3		.5658		1.0059	1.1401	.9221	.8383
4				.9724	1.1736	1.0898	.9221
5				1.073	1.0898	1.4251	1.3077
6				1.3077	1.2574	1.5089	1.5927
7				1.6766	2.0957	2.431	2.5987
8				2.0119	2.431	2.6825	2.7664
9				2.2131	2.431	2.9508	2.934
10				2.2131	1.9784	2.4143	2.431
11				.679	.7922	.7167	.5658
12				.7356	.7167	.6413	.6036
13				.6036	.4715	.5658	.5658
14				.7356	.2829	.4904	.6036
15	2.6825			.6602	.1132	.6036	.5658
16				.6224	.4527	.6036	.6036
17				.7356	.8488	.679	.8676
18				1.358	1.0374	1.1317	1.2449
19				1.1317	1.5466	1.3769	1.3203
20				1.0374	1.4335	1.0185	1.0185
21				.9431	1.0562	.9054	.9054
22				.7167	.7922	.7545	.7545
23			.6979	.7545	.6602	.6036	.6413
24				.6036	.6036	.5281	.5658
Max	2.6825	.5658	.6979	2.2131	2.431	2.9508	2.934
Min	2.6825	.5658	.6979	.6036	.1132	.4904	.5658
Avg	2.6825	.5658	.6979	1.0751	1.1112	1.1550	1.1657

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 205 / 11 KV GOLATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9242	.9242	.8488	.7922
2	1.0059		.9054	.9431	.8488	.8488
3			1.0185	1.1694	1.226	1.0374
4			1.1317	1.5466	1.4712	1.2826
5			1.5089	1.7918	1.6221	1.6221
6			1.8861	1.9239	2.0748	2.0748
7			1.9993	2.0559	2.3577	2.4143
8			1.9616	2.2634	2.1313	2.1691
9			1.3957	1.6221	1.6975	1.6221
10			1.2071	1.0185	1.3203	1.358
11			2.4813	1.9448	1.8442	1.4922
12			2.7831	2.6825	2.5149	1.2574
13			2.7831	2.5484	2.5819	1.3077
14			2.6825	2.7664	2.4478	
15	.7545		2.5149	2.4143	1.8107	
16			2.3137	2.3975	2.0119	2.6155
17			2.3472	2.2131		2.4813
18			2.5149	1.8945	1.6766	2.0454
19			1.8484	1.8861	1.9239	1.6975
20			1.5089	1.9805	1.358	1.3203
21			1.358	1.5466	1.1694	1.094
22			1.1883	1.094	.9431	.9808
23		1.0185	1.0374	.7545	.8299	.8676
24			.9431	.9431	.7733	.7922
Max	1.0059	1.0185	2.7831	2.7664	2.5819	2.6155
Min	.7545	1.0185	.9054	.7545	.7733	.7922
Avg	.8802	1.0185	1.7601	1.7636	1.6297	1.5079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 206 / 11 Kv Mirza industrial SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0377	.0377	.0377	.0377
2			.0377	.0377	.0377	.0377
3			.0377	.0377	.0377	.0377
4			.0377	.0377	.0377	.0377
5	.0377		.0377	.0377	.0377	.0377
6			.0377	.0377	.0377	
7			.0377	.0377	.0377	.0377
8			.0377	.0377	.0377	.0377
9			.0377	.0754	.0377	.0377
10			.0377	.0377	.0377	.0377
11			.0377	.0377	.0377	.0377
12			.0377	.0377	.0377	.0377
13			.0377	.0377	.0377	
14			.0377	.0377	.0377	.0377
15			.0377	.0377	.0377	.0377
16			.0377	.0377	.0377	.0377
17			.0377	.0377	.0377	.0377
18			.0377	.0377	.0377	.0377
19			.0377	.0377	.0377	.0377
20			.0377	.0377	.0377	.0377
21			.0377	.0377	.0377	.0377
22			.0377	.0377	.0377	.0377
23		.0377	.0377	.0377	.0377	.0377
24			.0377	.0377	.0377	.0754
Max	.0377	.0377	.0377	.0754	.0377	.0754
Min	.0377	.0377	.0377	.0377	.0377	.0377
Avg	.0377	.0377	.0377	.0393	.0377	.0394



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 201 / 11 KV SHENDRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6859	.4287	.5144
2	.5144	.6859	.4287	.5144
3	.5144	.6859	.4287	
4	.6859	.7716	.6001	.8573
5	.8573	.9431	.8573	1.0288
6	1.1145	1.1145	1.2003	1.2003
7	1.286	1.3717	1.4575	1.3717
8	1.6289	1.8004	1.9719	2.1434
9	1.0288	1.8861		2.1434
10	1.2003	1.5432	.1543	1.6289
11	.9431	1.0288	.1372	1.1145
12	.8573	.8573	.1029	
13	.7716	.8573	.1029	.8573
14	.7716	.7716	.0686	.8573
15	.7716	.7716		.8573
16	.8059	.7716	.0789	.8573
17	.8916	1.0288	.1029	1.0288
18	1.6289	1.4575		1.5432
19		1.8004		1.7147
20	1.5432	1.4575	1.9204	1.5432
21	1.3375	1.286	1.5089	1.2003
22	1.1145	1.1145	1.1145	1.1317
23	.9431	.9431	.9431	.9774
24	.9431	.9088	.8573	
Max	1.6289	1.8861	1.9719	2.1434
Min	.5144	.6859	.0686	.5144
Avg	.9856	1.1060	.7233	1.1946

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 202 / 11 KV MAHALPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6859	.6001	.6001
2	.6001	.6859	.6001	.6001
3	.6001	.6859	.6001	.6001
4	.7716	.8573	.8573	.6001
5	1.0288	1.0288	1.2003	.9431
6	1.286	1.2346	1.3717	1.3717
7	1.5432	1.5432	1.5432	1.5432
8	1.3717	1.5432	1.3717	1.4918
9	1.0288	1.1145	.1029	1.1145
10	.8573	.8573	.0857	.9431
11	1.3717	1.286	.12	1.2003
12	1.5432	1.5432	.1372	1.4575
13	1.9719	1.8004	.1715	1.8004
14	1.7147	1.8861	.1543	1.7147
15	1.7147	1.7147	1.5432	1.7147
16	1.7147	1.2003	.1629	1.6289
17	1.5432	1.286	.1629	1.5432
18	.6859	1.286		.8573
19	1.286	1.286		1.2003
20	1.0288	1.0288	1.5432	1.0288
21	.8573	.8573	1.2003	.8573
22	.7716	.6859		.823
23	.6859	.6001	.6001	.6859
24	.6001	.6001	.6001	.6001
Max	1.9719	1.8861	1.5432	1.8004
Min	.6001	.6001	.0857	.6001
Avg	1.1324	1.1374	.7014	1.1217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 203 / 11 KV BHALGAON FEEDER SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0631	.7716	.7716
2	1.0288	1.0288	.7716	.7716
3	1.0288	1.1145	.7716	.7716
4	1.2003	1.286	1.0288	.8573
5	1.4575	1.5089	1.5432	1.2003
6	1.8004	1.8004	1.8861	1.7147
7	1.8861	2.0576	2.3148	
8	2.0576	2.1434	2.4006	2.572
9	1.8861	2.4006	.2401	2.8292
10	1.5432	1.8861	.2143	2.4863
11	1.2003	1.2003	.1372	1.286
12	.8916	.8573	.1029	.9431
13	.823	.7716	.1029	.8573
14		.7716	.0686	.7716
15				.7716
16		.8573	.1115	.8573
17		1.2003	.12	1.286
18	2.1434	1.7147		1.8861
19	2.2291	2.3148		2.1434
20	2.0576	1.8861	2.2291	1.8861
21	1.6289	1.5432	1.5432	1.5432
22	1.3375	1.286	1.286	1.3717
23	1.2003	1.1145	1.1145	1.166
24	1.1145	1.0631	1.0288	1.0288
Max	2.2291	2.4006	2.4006	2.8292
Min	.823	.7716	.0686	.7716
Avg	1.4772	1.4291	.9423	1.3814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 205 / 11KV Om Gajanan Industrial SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0857	.0686
2	.0686	.0514	.0857	.0514
3	.0343	.0514	.0343	.0514
4	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0343
8	.0514	.0686	.0686	.0686
9	.1029	.0686	.0103	.3429
10	.1543	.2743	.0257	.3429
11	.1372	.2572	.0257	
12	.1029	.3772	.0223	.2058
13	.12	.3086	.024	.2058
14	.7202	.2229	.2572	.4458
15	.2572	.3601	.2572	
16	.2743	.3086	.0257	
17	.1715	.2743	.0257	.3086
18	.1715	.2401	.2572	.2915
19	.1372	.12	.1715	.0857
20	.0857	.1543	.1886	.1372
21	.0686	.12	.1715	.1372
22	.0857	.1029	.1543	.1372
23	.0686	.0686	.0514	.1029
24	.0686	.0686	.0857	.0686
Max	.7202	.3772	.2572	.4458
Min	.0343	.0343	.0103	.0343
Avg	.1286	.1543	.0902	.1519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 206 / 11 Kv R. K. Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	
2	.0343	.0343	.0343	.0343
3	.0343	.0343	.0343	
4	.0343	.0343	.0343	.0343
5	.0343	.0343	.0343	.0343
6	.0343	.0343	.0343	.0343
7	.0343	.0343	.0343	.0686
8	.0686	.0343	.0686	.0686
9	.0514	.0514	.0686	.0514
10	.0514	.0514	.0686	.0514
11	.0514	.0686	.0069	.0514
12	.0514	.0686	.0069	
13	.0514	.0514	.0069	.0343
14	.0686	.0514	.0686	.0514
15	.0686	.0514	.0514	
16	.0686	.0514	.0051	
17	.0514	.0686	.0051	.0343
18	.0514	.0686		.0514
19	.0514	.0514		.0514
20	.0514	.0686		.0514
21	.0514	.0514		.0514
22	.0343	.0343		.0343
23	.0343	.0343		.0343
24	.0343	.0343	.0343	
Max	.0686	.0686	.0686	.0686
Min	.0343	.0343	.0051	.0343
Avg	.0471	.0471	.0351	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 208 / 11 kv Omicron

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17
HR	Load (MW)
15	.0686
Max	.0686
Min	.0686
Avg	.0686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 201 / 11KV HARMAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.6859	1.1431	1.2193
2			.6478	1.086	1.2384
3			.6478	1.0098	1.2003
4		.6097	.6859	.9145	1.2193
5		.6097	.6859	.8002	1.2003
6		.6097	.7621	.724	1.2193
7		.9526	.8764	1.0479	1.2193
8		1.1622	1.105	1.467	1.5051
9		1.2384	1.2193	1.448	1.5242
10		1.4098	1.3717	1.4098	1.5432
11		1.4098	1.3717	1.4861	1.5242
12		1.4098	1.448	1.2574	1.448
13		1.5242	1.2193	1.105	1.467
14		1.5242	1.5242	1.4098	1.4098
15		1.448	1.7147	1.6385	1.448
16		1.7528	1.5623	1.6385	1.6194
17		1.7337	1.6194	1.5242	1.6004
18		1.7147	1.5623	1.3336	1.6004
19		1.5242	1.3717	1.2765	1.5623
20		1.3336	1.0479	1.2574	1.3336
21			1.3908	1.2574	1.448
22		1.2574	1.2765	1.2003	1.2574
23	.6668	.6859	1.2384	1.2193	1.3336
24		.6668	.6859	1.2003	1.2384
Max	.6668	1.7528	1.7147	1.6385	1.6194
Min	.6668	.6097	.6478	.724	1.2003
Avg	.6668	1.2012	1.1550	1.2439	1.3908

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 202 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192	.7621	.724	.8192
2		.8002	.7621	.7621	.8002
3		.7621		.7811	.7621
4		.7621	.724	.7811	.8002
5		.743	.7049	.8002	.7621
6		.743	.6859	.8002	.7621
7		.743	.6859	.8002	.743
8		.743	.5716	.8002	.8192
9		.7811	.8002	.9526	.9717
10		1.2574	1.105	1.0479	1.0669
11		1.2574	1.1431	1.2193	1.105
12		1.2574	1.1431	1.0669	1.1241
13		1.0098	.9526	1.0288	1.105
14		.9526	1.1431	1.1241	1.2384
15		.9526	1.1431	1.1241	1.1812
16		1.0269	1.1431	1.2574	1.3146
17		1.0479	1.0098	1.0669	1.105
18		.9526	.9526	.9907	1.0669
19		.9526	.8764	.8573	1.0288
20		.8954	.7621	.8573	.8383
21		.8383	.724	.8002	.8383
22		.7811	.7621	.7811	.8002
23	.8383	.7621	.7621	.8002	.7621
24		.8383	.7621	.743	.8002
Max	.8383	1.2574	1.1431	1.2574	1.3146
Min	.8383	.743	.5716	.724	.743
Avg	.8383	.9033	.8731	.9153	.9423



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 203 / 11KV KUMBHEPHAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3547	.3174	.2987	.3734
2		.3734	.3734	.3429	.3734
3		.4108	.5228	.3921	.3734
4		.4668	.5228	.4668	.3547
5		.5415	.5975	.4668	.4481
6		.6348	.7468	.5975	.5601
7		.6722	.8402	.5601	.5975
8		.7095	.8402	.5228	.6161
9		.7468	.7842	.6979	.6161
10		.5601	.6722	.7167	.6161
11		.6908	.7468	.8299	.6348
12		.6908	.7468	.6979	.6535
13			.5601	.8488	.6908
14		.8383	.6722	.9054	.6722
15		.8192	.7468	.8954	.6722
16		.8764	.7468	.6979	.7468
17		.8589	.7468	.7842	.7545
18		.7049	.6535	.6348	.6602
19		.6859	.5415	.5788	.5658
20		.5601	.4294	.4481	.4294
21		.4481	.381	.3921	.3547
22		.3174	.3174	.3361	.2987
23	.3734	.3239	.3174	.3361	.2801
24		.3547	.3174	.2987	.3361
Max	.3734	.8764	.8402	.9054	.7545
Min	.3734	.3174	.3174	.2987	.2801
Avg	.3734	.5930	.5892	.5728	.5283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 204 / 11KV BALIRAJA  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9145	.8764	1.0098	.8764
2		.9526	.8764	.9526	.8764
3		.9526	.8764	.9145	.8573
4		.9335	.8764	.8573	.9145
5		.9145	.7621	.8002	.8002
6		.9145	.7811	.743	.7621
7		1.0669	.7811	.8192	.7621
8		1.2193	1.1431	.9145	.8383
9		1.3146	1.3717	1.2955	1.2765
10		1.848	1.4861	1.4289	1.6575
11		2.0957	1.5242	1.2955	1.6385
12		2.0005	1.6004	1.6385	1.6004
13			1.7147	1.6004	1.3717
14		2.191	1.7147	1.9052	1.7718
15		2.0957	1.6766	1.7528	1.5432
16		2.3815	1.7909	1.8671	1.7909
17		2.2862	1.2955	1.4098	1.7909
18		1.9052	1.1431	1.2384	1.2955
19		1.7147	1.1812	1.0479	1.2574
20		1.5242	1.2003	1.0479	1.0288
21		1.3336	1.105	1.0098	1.2574
22		1.105	1.1241	.9526	1.448
23	.8573	.8573	1.105	.9907	1.5242
24		.8764	.8764	1.0669	.9145
Max	.8573	2.3815	1.7909	1.9052	1.7909
Min	.8573	.8573	.7621	.743	.7621
Avg	.8573	1.4521	1.2035	1.1900	1.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 205 / 11KV VAISHNAVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348	.6413	.7655	.5658
2		.6161	.6413	.7733	.6224
3		.5975	.6413	.811	.547
4		.5601	.6413	.8299	.5093
5		.5601	.5658	.8299	.5093
6		.5601	.6602	.8676	.5281
7		.5228	.6602	.811	.5093
8		.4854	.5658	.6979	.5658
9		.5228	.679	.7922	.6161
10		.8865	.9242	.811	.6908
11		.8573	.9054	.6413	.6161
12		.8573	.8488	.6979	.5228
13		.8573	.7922	.8488	.5601
14		.8573	.8488	.6979	.5601
15		.8573	.8299	.811	.5975
16		.8573	.8488	.9619	.7922
17		.8573	.9717	.8488	.7733
18		.8954	.9145	.8488	.6224
19		.6668	.811	.5658	.6224
20		.7621	.7167	.679	.3961
21		.7621	.7167	.8299	.5281
22		.7621	.7167	.7922	.5658
23	.6722	.6859	.7095	.7356	.4715
24		.6348	.6413	.7468	.5658
Max	.6722	.8954	.9717	.9619	.7922
Min	.6722	.4854	.5658	.5658	.3961
Avg	.6722	.7132	.7455	.7790	.5774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 206 / 11KV SUSHMA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5144	.5335	.5335	.8002
2		.4954	.5335	.5525	.724
3		.5144	.5335	.5906	.7621
4		.4954	.5335	.6287	.724
5		.4763	.5525	.6478	.724
6		.4763	.5716	.6859	.7621
7		.5716	.5716	.8383	.7621
8		.6478	.6668	.9526	.7811
9		.743	.5716	1.3146	1.0479
10		.8002	1.086	1.3527	1.2574
11		.9907	1.1622	1.1812	1.2765
12		.9526	1.3717	1.2955	1.2765
13		.7621	1.3336	.7621	.9335
14		.7621	1.3336	.9145	1.0288
15		.7621	1.2384	1.0669	1.1622
16		.8573	1.2003	1.2574	1.105
17		.8573	1.1812	.9526	1.3336
18		.8383	.9526	.8954	.7621
19		.8002	.8764	.7049	.724
20		.7621	.7811	.6859	.5716
21		.6859	.6668	.6287	.5335
22		.6097	.5906	.6859	.6097
23	.5335	.5335	.5716	.6859	.4763
24		.5144	.5335	.5335	.7621
Max	.5335	.9907	1.3717	1.3527	1.3336
Min	.5335	.4763	.5335	.5335	.4763
Avg	.5335	.6843	.8312	.8478	.8708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 207 / 11KV Aurangabad Jalna  
TollWays Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0739	.061	.1267	.0543
2		.0543	.061	.1294	.0343
3		.0514	.0457	.1097	.0324
4		.0486	.0457	.1086	.0305
5		.0457	.0457	.0905	.0305
6		.0434	.0457	.0537	.0305
7		.0457	.0457	.04	.0305
8		.044	.0457	.0286	.0305
9		.04	.0305	.0566	.056
10		.0554	.0305	.0566	.0754
11		.056	.0305	.0377	.1132
12		.056	.0305	.0377	.1132
13		.056	.0457	.0566	.1132
14		.056	.0305	.0377	.0213
15			.0305	.0377	.0566
16			.0191	.0566	.0747
17		.056	.0343	.0305	.0566
18		.056	.0358	.0267	.0566
19		.056	.0732	.0301	.0566
20		.056	.1109	.0343	.0566
21		.056	.1097	.0377	.0566
22		.056	.1029	.0566	.0566
23	.112	.0747	.1086	.0457	.0566
24		.0934	.0305	.128	.0514
Max	.112	.0934	.1109	.1294	.1132
Min	.112	.04	.0191	.0267	.0213
Avg	.112	.0559	.0521	.0606	.0560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 201 / LADSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3801	.4973	.6154	.4144
2		.5792	.4144	.5792	.5801
3		.6154	.4001	.6516	.4973
4		.724	.4973	.724	.5801
5		.7602	.5801	.8326	.663
6		.8507	.5801	.905	.7459
7		.9231	.8288	.9955	.9116
8		1.0317	.9116	1.3032	.9945
9		1.086	.7459	1.267	1.0774
10		.6335	.663	1.0136	.9116
11		.6516	.5801		
12			.543		
13			.4525		.5249
14			.4706	.4144	.4887
15			.5068		.4163
16			.5792		.5249
17			.7059		.6878
18		.9116		.8288	.905
19		.9945	.9955	.9116	1.0317
20		1.0774	.8688	.9945	.7602
21		.9945	.7602	.5801	.5973
22		.8288	.724	.4973	.4163
23	.3801	.663	.6878	.4144	.3801
24		.5801		.4144	
Max	.3801	1.086	.9955	1.3032	1.0774
Min	.3801	.3801	.4001	.4144	.3801
Avg	.3801	.7936	.6360	.7746	.6719

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 202 / 11 KV ANJANDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8507	.5801	.6516	.4973
2		.9231	.663	.724	.5801
3		1.5927	.7459	.7602	.663
4		1.7194	.9116	.8326	.7459
5		1.8461	.8288	.7783	.9116
6		1.9728	.9945	.724	.9945
7		2.1176		.905	1.0774
8		2.1538	1.1603	.905	1.2431
9		1.7737	1.4089	.7059	1.4089
10		1.8099	.543	.6516	1.4918
11		.5068	.4525		.6335
12			.362		.3982
13			.3258		.3801
14			.3439	.3315	.3439
15			.362		.2896
18		.4144	.3801	.5801	.3801
19		.9945	.362	.7459	.4887
20		1.0774	.543	.8288	.4525
21		.9945	.5068	.663	.4163
22		.8288	.4706	.5801	.3439
23	.4344	.663	.4344	.4973	.3258
24		.4973		.4144	
Max	.4344	2.1538	1.4089	.905	1.4918
Min	.4344	.4144	.3258	.3315	.2896
Avg	.4344	1.2631	.6190	.6822	.6698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 203 / 11 KV PIMPALKHUTTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3077	.2486	.362	.2486
2		.3258	.2486	.3258	.3315
3		.3801	.3315	.2896	.4144
4		.4525	.4144	.362	.4144
5		.5249	.4973	.4163	.4973
6		.6697	.663	.5792	.4973
7		.724	1.0774	.7059	.5801
8		.6335	.663	.6878	.4973
9		.5249	.4973	.5249	.4144
10		.3258	.3315	.4163	.3315
11		.9774	.9945		1.086
12			1.2489		1.2308
13			1.4842		1.3575
14			1.6278	1.326	1.2127
15			1.448		1.2489
16			1.4266		1.267
17			1.3535		1.1946
18		.9945	1.1041	.9945	1.1584
19		.4973	.5973	.5801	.6154
20		.5801	.5792	.4973	.4887
21		.4144	.543	.3315	.3258
22		.3315	.5068	.3315	.3258
23	.2715	.2486	.4706	.2486	.3439
24		.1658		.2486	
Max	.2715	.9945	1.6278	1.326	1.3575
Min	.2715	.1658	.2486	.2486	.2486
Avg	.2715	.5044	.7981	.5127	.6992



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 204 / SAYYAIDPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258	.4973	.543	.3315
2		.3258	.4973	.5792	.3315
3		.3801	.5801	.6154	.4144
4		.5249	.663	.6516	.5801
5		.7602	.8288	.724	.7459
6		1.0317	.9945	.8326	.9116
7		1.2851	1.0774	1.2489	1.0774
8		1.1946	.9945	1.267	.9945
9		1.0498	.8288	1.0679	.8288
10		.7059	.663	.6335	.4973
11		1.8099	1.989		2.0814
12			1.9909		2.552
13			1.9022		1.1765
14			2.1719		2.9321
15			2.3167		2.8416
16			2.4615		2.7873
17			2.552		2.8416
18		1.989	2.4615	2.2377	2.552
19		.8288	1.1041	.9945	.8688
20		.9945	.9412	1.0774	.6335
21		.9116	.8326	.4973	.4344
22		.8288	.724	.4144	.3439
23	.3439	.663	.6878	.3315	.3077
24		.5801		.3315	
Max	.3439	1.989	2.552	2.2377	2.9321
Min	.3439	.3258	.4973	.3315	.3077
Avg	.3439	.8994	1.2939	.8263	1.2637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 205 / 11 KV Hatmali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4525	.4973	.4706	.9116
2		.4525	.5801	.4344	.4973
3		.4344	.663	.4706	.5801
4		.6878	.8288	.5228	
5		.7602	.9945	.543	.8288
6		.9955	1.0774	.724	.9945
7		1.1946	.9945	1.1389	1.0774
8		1.0136	.8288	1.3032	.7459
9		.7602	.663	.8145	.5801
10		.5973	.543	.4887	.4144
11		1.1403	.905		1.086
12			1.1765		1.5746
13			1.267		1.448
14			1.4118	1.4089	.6154
15			1.3032		1.4118
16					1.4118
17			1.3756		1.448
18		1.2431	1.3394	1.0774	1.267
19		.9116	1.0498	.7459	.9412
20		.9945	.8326	.663	.6697
21		1.0774	.6878	.5801	.4525
22		.663	.6516	.4973	.3258
23	.3801	.4973	.543	.4144	.3077
24		.4144		.3315	
Max	.3801	1.2431	1.4118	1.4089	1.5746
Min	.3801	.4144	.4973	.3315	.3077
Avg	.3801	.7939	.9188	.7016	.8904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 206 / BHAKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5792	.3315	.5068	.1658
2		.6516	.4144	.6516	.2486
3		.6516	.4973	.8326	.2486
4		.6878	.663	.905	.3315
5		.7602	.8288	.9774	.4144
6		.905	.9116	1.1222	.4973
7		.9774	.9945	1.2308	.5801
8		1.1403	.8288	1.3032	.9116
9		1.086	.9116	1.3575	1.1603
10		.9593	.8288	1.2489	1.267
11		.0724	.1658		.181
12			.1629		.0724
13			.0543		.0362
14			.1086	.0829	.0724
15			.1629		.0724
16			.181		.1267
17			.1991		.1629
18		.2486	.2353	.2486	.2715
19		.4144	.4163	.3315	.362
20		.4973	.543	.4144	.2715
21		.4144	.4706	.3315	.1629
22		.3315	.4163	.3315	.1267
23	.181	.2486	.3258	.2486	
24		.3315		.1658	
Max	.181	1.1403	.9945	1.3575	1.267
Min	.181	.0724	.0543	.0829	.0362
Avg	.181	.6087	.4631	.6828	.3520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 201 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.0514	.06	.4287
2	.2572	.0514	.06	.4287
3	.2572	.0514	.0686	.4287
4	.3429		.0772	.5144
5	.4287	.06	.0772	.6001
6	.4287	.06	.0857	.6859
7	.6859	.0686	.0772	.6859
8	.6001	.06	.0686	.6001
9	.5144	.0514	.0429	.4287
10	.3429	.0343	.0257	.3429
11	.0257	.0171	.1715	.2572
12		.0171	.1715	.2572
13	.0171	.0257	.1715	.1715
14	.0171		.0857	.2572
15	.0171	.0257	.1715	.2572
16	.0171	.0257	.1715	
17		.0343		.3429
18	.06	.0514	.6001	.6001
19	.0686	.06	.6001	.6001
20	.06	.06	.4287	.5144
21	.0514	.0429	.5144	.5144
22	.0343	.0429	.4287	.4287
23	.0514	.06	.4287	.6859
24	.2572	.0514	.06	.4287
Max	.6859	.0686	.6001	.6859
Min	.0171	.0171	.0257	.1715
Avg	.2178	.0456	.2020	.4548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 202 / EKLAHARA SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857
2	.0857	.0086	.0086	.0857
3	.0857	.0086	.0086	.0857
4	.0857	.0086	.0086	.0857
5	.0857	.0171	.0086	.1715
6	.2572	.0257	.0257	.2572
7	1.1145	.1286	.12	1.1145
8	1.286	.1286	.1629	1.4575
9	1.5432	.1629	.1543	1.4575
10	1.5432	.1543	.1715	1.3717
11	.1457	.1715	1.7147	1.286
12		.1543	1.4575	1.286
13	.1457	.1629	1.4575	1.286
14	.1457	.1715	1.3717	1.2003
15	.0086	.0086	.0857	.0857
16			.0857	
17	.0086	.0086	.0857	
18	.0171	.0171	.1715	.1715
19	.0171	.0171	.1715	.1715
20	.0086	.0171	.1715	.1715
21	.0086	.0034	.0857	.0857
22	.0086	.0086	.0857	.0857
23	.0086	.0086	.0857	.0857
24	.0857	.0086	.0086	.0857
Max	1.5432	.1715	1.7147	1.4575
Min	.0086	.0034	.0086	.0857
Avg	.3082	.0613	.3215	.5534

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 203 / CHITEPIMPALGOAN SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.1029	.1115	1.0288
2	.8573	.1029	.1115	1.1145
3	.9431	.1029	.12	1.1145
4	.9431	.1115	.12	1.2003
5	1.0288	.1115	.1286	1.2003
6	1.0288	.1115	.1286	1.3717
7	1.3717	.12		
8	1.2003	.1372		1.286
9	1.1145	.1029		1.1145
10	.9431	.0943	1.1145	.9431
11	.0686	.0686	.7716	.6859
12			.6001	.5144
13	.0686	.0514	.6001	.6001
14	.0514	.0514	.5144	.6001
15	.06		.5144	.5144
16	.06	.0686	.6001	.5144
17	.0686		.7716	.6001
18		.12	1.0288	1.1145
19	.0943	.1115	1.2003	1.2003
20	.0857	.0943	1.0288	.9431
21	.0686	.0772	.6859	.7716
22	.0514	.06	.6001	.5144
23	.1115	.1115	1.2003	1.2003
24	.8573	.1115	.1115	1.1145
Max	1.3717	.1372	1.2003	1.3717
Min	.0514	.0514	.1115	.5144
Avg	.5425	.0964	.5744	.9244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 204 / pachod SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.0343	.0343	.3429
2	.3429	.0343	.0343	.3429
3	.4287	.0429	.0429	.5144
4	.6001	.06	.06	.6859
5	.7716	.0857	.0686	.7716
6	.8573	.1029	.0772	.9431
7	1.286	.12	.12	.7716
8	1.4575		.1629	1.2003
9	1.8004	.18	.1543	.9431
10	1.5432	.1629	.18	1.2003
11	.1543	.1543	1.7147	1.2003
12		.1543	1.5432	1.0288
13	.1543	.1715	1.5432	1.1145
14	.1457	.1457	1.3717	.8573
15	.0343	.0257	.2572	.2572
16	.0343		.2572	.2572
17	.0429	.0686	.5144	.4287
18	.0686	.0772	.7716	.6859
19	.0686	.0772	.7716	.8573
20	.06	.0686	.6859	.6859
21	.0514	.0514	.5144	.5144
22	.0429	.0343	.4287	.3429
23	.0343	.0343	.3429	.3429
24	.3429	.0343	.0343	.3429
Max	1.8004	.18	1.7147	1.2003
Min	.0343	.0257	.0343	.2572
Avg	.4637	.0873	.4869	.6930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 205 / Pimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.0429	.0429	.4287
2	.4287	.0429	.0514	.4287
3	.5144	.0514	.06	.5144
4	.6001	.06		.5144
5	.7716	.0772	.0857	.6859
6	.9431	.1029	.0943	.6001
7	.5144	.06	.06	.5144
8	.6001	.0686	.0514	.5144
9	.6001	.06	.0514	.4287
10	.6001	.06	.0429	.4287
11	.06	.0514	.4287	.4287
12		.0514	.6001	.4287
13	.0514	.0514	.4287	.4287
14	.06	.0429	.3429	.3429
15	.0429	.0429	.5144	.5144
16	.0429	.06	.5144	.5144
17	.0943	.0686	.7716	.6001
18	.0943	.0857	.9431	.8573
19	.0943	.0772	.9431	.8573
20	.0857	.0772	.7716	.8573
21	.0686	.06	.6001	.6859
22	.0514	.0514	.5144	.5144
23	.0429	.0429	.4287	.3429
24	.4287	.0429	.0429	.4287
Max	.9431	.1029	.9431	.8573
Min	.0429	.0429	.0429	.3429
Avg	.3139	.0597	.3646	.5358



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 206 / Bafana feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857
2	.0857	.0086	.0086	.0857
3	.0857	.0086	.0086	.0857
4	.0857	.0086	.0086	.0857
5	.0857	.0086	.0086	.0857
6	.0857	.0086	.0086	.0857
7	.0857	.0171	.0086	.0857
8	.1715	.0086	.0086	.0857
9	.1715	.0086	.0086	.0857
10	.1715	.0086	.0086	.1715
11	.0171	.0086	.0857	.1715
12		.0086	.0857	.1715
13	.0171	.0086	.0857	.1715
14	.0171	.0086	.0857	.1715
15	.0171	.0086	.0857	.1715
16	.0171	.0086	.0857	.1715
17	.0171	.0086	.0857	.1715
18	.0171	.0086	.0857	.1715
19	.0171	.0086	.0857	.1715
20	.0171	.0086	.0857	.1715
21	.0086	.0086	.0857	.0857
22	.0086	.0086	.0857	.0857
23	.0086	.0086	.0857	.0857
24	.0857	.0086	.0086	.0857
Max	.1715	.0171	.0857	.1715
Min	.0086	.0086	.0086	.0857
Avg	.0600	.0090	.0504	.1250

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 207 / Ambikarpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0086	.0086	.0857
2	.0857	.0086	.0086	.0857
3	.0857	.0086	.0086	.0857
4	.0857	.0086	.0086	.0857
5	.0857	.0086	.0086	.0857
6	.0857	.0086	.0086	.1715
7	.1715	.0171	.0171	.1715
8	.0857	.0086	.0171	.1715
9	.0857	.0086	.0086	.1715
10	.0857	.0086	.0086	.0857
11	.0086	.0086	.0857	.0857
12		.0086	.0857	
13	.0086	.0086	.0857	
14	.0086	.0086	.0857	.0857
15	.0514	.0514	.3429	.3429
16	.06	.06	.3429	.4287
17	.0429	.06	.3429	.4287
18	.0343	.06	.1715	.5144
19	.0343	.06	.1715	.3429
20	.0257	.06	.0857	.2572
21	.0343	.0514	.0857	.2572
22	.0171	.0514	.0857	.1715
23	.0086	.0086	.0857	.0857
24	.0857	.0086	.0086	.0857
Max	.1715	.06	.3429	.5144
Min	.0086	.0086	.0086	.0857
Avg	.0593	.0250	.0904	.1948

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 201 / GANDHELI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.6878	.6401	.6767
2	.7545	.695	.7059	.695
3	.7888	.7133	.8145	.7059
4	.9431	.8962	1.086	.8507
5	1.166	1.1523	1.3213	1.3352
6	1.3717	1.5746	1.6289	1.647
7		1.647		
8		1.3756		1.6278
9	1.6461		1.4998	
10	1.4083		1.4266	1.6644
11	1.0242	1.0974	1.0608	1.2803
12	1.0608	1.2071	1.0059	1.1706
13	1.0974	1.1706	.9877	1.1523
14	.7316	1.2803	.9694	1.0974
15	1.0242	1.0059	.9877	1.0608
16	1.0974		.8596	1.0608
17	1.2384		.9945	.8402
18	1.0288	1.086	.9602	.7716
19	1.6004	1.6385	1.5432	1.5089
20	1.2955	1.4289	1.2689	1.1831
21	.8916	1.0479	1.0631	1.0974
22	.8192	.8573	.8402	.823
23	.7049	.743	.6859	.8779
24	.7621	.743	.6859	.6584
Max	1.6461	1.647	1.6289	1.6644
Min	.7049	.6878	.6401	.6584
Avg	1.0534	1.1024	1.0471	1.0812

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 202 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2715	.2715	.3292
2	.3429	.2896	.3982	.3841
3	.3772	.3439	.4887	.4755
4	.4115	.3841	.5249	.567
5	.4973	.4887	.5973	.7059
6	.6173	.7133	.8326	.8688
7	.6687	1.0498	1.2851	1.2894
8	.9602	1.1946	1.4299	1.4266
9	.9694	1.1888	1.4632	1.2803
10	.8413	.9694	1.1706	1.2071
11	.5304	.4755	.4938	.4755
12	.3658	.4207	.3658	.4024
13	.3841	.4572	.3658	.4024
14	.4024	.3658	.3475	.4024
15	.4024	.3841	.3292	.4024
16	.4207	.439	.3841	.3658
17	.6668	.5525	.4973	.463
18	.8954	.9145	.6859	.7716
19	.9717	1.0479	1.0288	1.0117
20	.7049	.7621	.7716	.7716
21	.4001	.6097	.7202	.7202
22	.0191	.4572	.4458	.463
23	.0762	.381	.3772	.4024
24	.362	.3429	.3429	.3658
Max	.9717	1.1946	1.4632	1.4266
Min	.0191	.2715	.2715	.3292
Avg	.5263	.6043	.6507	.6648

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 203 / SINDHON BINDHON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.7783	.7133	.695
2	.3772	.8688	.724	.7133
3	.4115	.905	.8326	.8145
4	.5487	1.0317	.8869	.8326
5	.6173	1.0679	.9412	.8688
6	.6516	1.1765	1.0679	1.0679
7	.6859	1.267	1.3575	1.3073
8	1.1488	1.5023	1.5203	1.5746
9	1.0608	1.4815	1.5181	1.4632
10	1.0425	1.2803	1.262	1.2437
11	.2926	.2012	.3292	.2926
12	.2195	.2012	.1829	.2561
13	.2561	.2195	.1829	.2561
14	.2926	.2195	.2561	.2378
15	.3658	.3475	.2561	
16	.3475	.3475	.3658	
17	.5144	.4382	.4973	
18	.8383	.8002	.6859	.6173
19	.7621	.7621	.7888	.6516
20	.5335	.5716	.5144	.5144
21	.4001	.4001	.4115	.4801
22	.3429	.3429	.3429	.3772
23	.3239	.3048	.3086	.4024
24	.3429	.3048	.3048	.3109
Max	1.1488	1.5023	1.5203	1.5746
Min	.2195	.2012	.1829	.2378
Avg	.5300	.7009	.6771	.7132

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 204 / 11 KV EXP.MAHANANDA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0362	.0362	.0732
2	.0857	.0366	.0362	.0549
3	.0857	.0366	.0362	.0366
4	.0686	.0366	.0362	.0362
5	.0514	.0362	.0362	.0362
6	.0343	.0366	.0362	.0362
7	.0343	.0362	.0362	.0358
8	.0343	.0543	.0362	.0543
9	.0914	.0732	.1097	.1097
10	.0914	.128	.1097	.1097
11	.1097	.128		.1097
12	.1097	.128		.0914
13	.1097	.0549		.1097
14	.0914	.1097	.0732	.1097
15	.0732	.1097	.0914	.1097
16	.0732	.0457	.1097	.0732
17	.0953	.1143	.12	.0857
18	.0953	.0762	.0686	.1029
19		.0572	.0514	.0343
20	.0572	.0572	.0514	.0514
21	.0572	.6097	.0514	.0514
22	.0572	.0762	.0514	.0514
23	.0762	.0762	.0514	.0732
24	.0381	.0572	.0381	.0732
Max	.1097	.6097	.12	.1097
Min	.0343	.0362	.0362	.0343
Avg	.0742	.0921	.0603	.0712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 205 / PRATIK METAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1629	.128	.1829
2	.1543	.1463	.1448	.1829
3	.1029	.1463	.1448	.181
4	.1372	.1463	.1448	.181
5	.1543	.1463	.1448	.181
6	.1543	.1448	.1448	.181
7	.1372	.1629	.1448	.1791
8	.5144	.1646	.1629	.1991
9	.6036	.1646	.5981	.3603
10	.439	.1829	.6584	.5853
11	.8413	.1829	.5487	.567
12	.7682	.3475	.5121	.567
13	.7499	.823	.3658	.5853
14	.6767	.7316	.2743	.5853
15	.6767	.823	.2926	.3658
16	.4207	.4938	.5853	.4938
17	.4001		.4458	.6001
18	.4572	.743	.2572	.4115
19		.1677	.2743	.3429
20	.1429	.0572	.1543	.1543
21	.1334	.0762	.1543	.1372
22	.0171	.1677	.1543	.1715
23	.1791	.1753	.1543	.1646
24	.16	.1677	.1715	.181
Max	.8413	.823	.6584	.6001
Min	.0171	.0572	.128	.1372
Avg	.3547	.2837	.2817	.3225

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 206 / 11 KV MGM FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0181	.0183	.0183
2	.0171	.0183	.0181	.0183
3	.0171	.0183	.0181	.0181
4	.0171		.0181	.0181
5	.0171	.0183	.0181	.0181
6	.0171		.0181	.0181
7	.0171	.0181	.0181	.0179
8	.0171	.0362	.0181	.0181
9	.0128	.0329	.0329	.0274
10	.0366	.0366	.0219	.0274
11	.0439	.0366	.0366	.0366
12	.0366	.0366	.0274	.0421
13	.0183	.0329	.0183	.0366
14	.0366	.0348	.0238	.0366
15	.0329	.0366	.0256	.0366
16	.0274	.0171	.0219	.0329
17	.0229	.8573	.0171	.0171
18	.0152	.0229	.0171	.0171
19		.0171	.0171	.0171
20	1.6766	.0152	.0171	.0171
21	.0114	.0171	.0171	.0171
22	.0114	.1715	.0171	.0171
23	.0114	.0114		.011
24	.0114	.0114	.0114	.0183
Max	1.6766	.8573	.0366	.0421
Min	.0114	.0114	.0114	.011
Avg	.0931	.0689	.0203	.0230



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 201 / Khodegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5624	.823	.6964	.8817
2		.5851	.8402	.6783	.8718
3		.6081	.8916	.6539	.9221
4		.6062	.9259	.6952	.9221
5		.6952	.9259	.7042	1.0174
6		.7127	.9259	.7042	1.1191
7		.9808	1.1128	.9242	.9242
8		.9997	.9808	1.0374	.9808
9		.8865	.8865	.9431	.9808
10		.6602	.7922	.679	.9054
11		.5658	.547	.6602	.5281
12			.4527	.6036	.4527
13		.4527	.4527	.6413	
14		.415	.4805	.4715	
15		.4904	.5175	.4715	.5281
16		.4904		.5093	.4715
17		.7356		.7167	.7733
18	1.1069	1.0185		.9054	
19		.7922	.9808	.9054	.8299
20		.7733	.8299	.9054	.9054
21		.7545	.7922	.7545	.6036
22		.679	.5658	.6979	.4715
23	.571	.7373	.7122	.8478	.6562
24		.578	.7716	.7377	.8648
Max	1.1069	1.0185	1.1128	1.0374	1.1191
Min	.571	.415	.4527	.4715	.4527
Avg	.8390	.6861	.7718	.7310	.7910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 202 / Kachner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4715	.547	.415	.3772
2		.5093	.4527	.415	.3961
3		.5847	.415	.415	.415
4		.6224	.4904	.415	.5658
5		.8488	.8299	.4715	.9619
6		1.2071	1.3203		1.1506
7		1.3014	1.2826		1.2826
8		1.3203	1.2449		1.358
9		1.1694	1.1317	.9242	1.1317
10		.811	.9431	.7545	.8488
11		.5847	.6602	.4904	.6036
12			.5658	.415	.6036
13		.4904	.4715	.3772	.5658
14		.4527	.4715	.5658	.3584
15		.7811	1.1203	.9762	.703
16		.8697	.9221	.9962	.9442
17		.9175	.8383	.9878	.9231
18		.7373	.9878	.8356	.8886
19		.6935	.8192	.8048	.7282
20		.5258	.639	.6443	.5087
21		.4115	.5868	.4694	.4588
22		.3601	.4359	.4191	.3647
23	.4715	.5093	.3772	.3961	.4338
24		.4715	.5093	.4338	.4904
Max	.4715	1.3203	1.3203	.9962	1.358
Min	.4715	.3601	.3772	.3772	.3584
Avg	.4715	.7240	.7526	.6010	.7109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 203 / Gadiwat

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.5281	.4715	.4904
2		.4715	.5658	.5093	.4715
3		.5281	.5847	.5281	.4715
4		.6413	.6036	.5658	.4904
5		.7922	.8676	.8488	.4904
6		.9808	1.0185	1.0185	.5281
7		1.1869	1.6244	1.2209	1.0852
8		1.5402	1.704	1.4251	1.3077
9		2.1502	1.6324	1.4403	1.2803
10		.9907	1.6804	1.3763	1.3279
11		1.656	1.6575	1.3927	1.3763
12			1.6766	1.2498	1.3748
13		1.6004	1.5927	1.2346	1.5089
14		1.5935	1.6108	1.2146	.5426
15		.2263	.3506	.2263	.1886
16		.2263	.2263		.2641
17		.4527		.3395	.4715
18		.7733	.3395	.7167	.679
19		.7356	.7167	.6036	.7545
20		.6602	.7167	.5281	.6413
21		.6036	.6036	.5281	.5281
22		.5093	.4904	.4904	.4904
23	.4527	.5093	.4715	.4904	.4527
24		.4527	.5281	.4904	.4904
Max	.4527	2.1502	1.704	1.4403	1.5089
Min	.4527	.2263	.2263	.2263	.1886
Avg	.4527	.8580	.9474	.8222	.7378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 204 / 11 Kv Power Grid

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1698	.1715	.1524	.1524
2		.1677	.1753	.1698	.1524
3		.1677	.197	.1718	.1486
4		.1656	.197	.0953	.1429
5		.1389		.0762	.1048
6		.1423			.0762
7		.0724			.0714
8		.0686			.0412
9		.0549			
10		.061			
11		.0633			
18				.2075	
19			.1524	.1677	.1562
20			.1562	.1718	.16
21			.1739	.1739	.1562
22		.1581	.1581	.1619	.1581
23	.1718	.1715	.1562	.1524	.1406
24		.1698	.1715	.1524	.1524
Max	.1718	.1715	.197	.2075	.16
Min	.1718	.0549	.1524	.0762	.0412
Avg	.1718	.1265	.1709	.1544	.1295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 201 / 11KV Hiwara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.583	.583
2	.4458	.4239	.5487	.5596
3	.4801	.5087	.583	.5935
4	.5144	.6001	.6516	.6104
5	.5426	.8573	.5316	.6783
6	.5765	.9326	.8573	.8817
7	.7461	1.0288	.9945	1.0898
8	1.0343	1.2209	1.3546	1.358
9	1.0682	1.0802	1.4918	1.6118
10	1.0288	.9774	1.3565	1.3226
11	.2713	.1886	.2035	.1715
12	.1543	.1372	.1526	.1715
13		.12	.1357	.1372
14		.1715		.1543
15	.1357			.1526
16	.1715			.1543
17	.2883		.2012	.1886
18	.5144	.3772	.4239	.4801
19	.5316	.6173	.6173	.6516
20	.463	.4973	.5144	.5087
21	.4458	.463	.4287	.4801
22	.4115	.3944	.3772	.3258
23	.3258	.4287	.3772	.3052
24	.3429	.3086	.463	.3429
Max	1.0682	1.2209	1.4918	1.6118
Min	.1357	.12	.1357	.1372
Avg	.4964	.5601	.6118	.5630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 202 / 11KV KARMAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6687	.6443	.6001	.6173
2		.6859	.6859	.6173	.6104
3		.6859	.6859	.583	.6443
4		.7545	.763	.7716	.763
5		.9835	.9326	.9088	.8817
6		1.2887	1.286	1.286	1.3226
7		1.543	1.5432	1.5604	1.576
8		1.4752	1.5947	1.5432	1.4586
9		1.3735	1.3226	1.3203	1.286
10		1.1488	1.1145	1.1022	1.1145
11		.5658	.6173	.5765	.6274
12		.5658	.4801	.6443	.6173
13		.6443	.6173	.6371	.6443
14		.5596	.6001	.57	.5765
15		.5426	.5658	.6203	.5256
16		.5316	.583	.57	.583
17		.5487	.583	.57	.5935
18		.5935	.6173	.6443	.6001
19		1.17	1.1488	1.1488	1.2346
20		1.0802	1.0802	1.0974	1.1145
21		1.0288	.9602	.9088	.9431
22		.8573	.7888	.8059	.8309
23	.7202	.7202	.5487	.7716	.7122
24		.6859	.6687	.6173	.6859
Max	.7202	1.543	1.5947	1.5604	1.576
Min	.7202	.5316	.4801	.57	.5256
Avg	.7202	.8626	.8513	.8531	.8568

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 201 / 11KV DUDHAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3521	.3239	.3277	.3401
2		.3944	.4049	.3441	.3563
3		.4359	.4372	.4588	.3887
4		.5571	.5668	.6226	.5668
5		.6718	.7773	.7373	.6802
6		1.0774	1.0688	1.065	1.0202
7		1.2125	1.2308	1.2125	1.2146
8		1.0898	1.0688	1.065	1.0526
9		.8916	.8259	1.0814	.8745
10		.6874	.5898	.5868	.421
11	.3401	1.2289	1.5074	1.5432	1.5708
12		1.704	1.917		2.079
13		1.9006	2.0481		2.2634
14		1.8351	2.1464	1.3889	2.332
15		1.8842	1.9989	2.2634	2.079
16		1.9662	1.9334	2.1136	2.1136
17		1.9334	1.9662	2.13	2.0972
18		1.7166	1.6385	1.8842	1.7901
19		.8192	.8192	.8259	.7701
20		.6554	.6554	.6802	.7042
21		.5407	.5243	.5182	.5487
22		.5243	.4915	.4049	.4359
23		.3725	.3277	.3563	.3601
24		.3521	.3563	.3277	.3401
Max	.3401	1.9662	2.1464	2.2634	2.332
Min	.3401	.3521	.3239	.3277	.3401
Avg	.3401	1.0335	1.0677	.9972	1.1000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 202 / 11KV GEORAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788	.8288	.7545	.9724
2	.8059	.8619	.788	1.0898
3	.8886	.9116	.9724	1.1904
4	.9503	1.0774	1.0898	1.3077
5	1.1305	1.2929	1.1904	1.4754
6	1.3757	1.4089	1.5089	1.7436
7	1.5729	1.9227	2.0119	2.4143
8	2.0287	2.1714	2.5149	2.7496
9		2.0885	2.5149	2.5484
10	1.3916	1.7604	2.1628	2.2131
11	.3688	.2515	.3086	.3315
12	.218		.1844	.2683
13	.218	.2347		.2515
14	.218			.4973
15	.218	.218		.3018
16	.2515	.3018		.2949
17	.4191	.3856	.4191	.426
18	.7625	.7712	.6539	.7459
19	.9724	1.0059	1.1568	
20	.8383	.8383	.9054	.8886
21	.7042	.6706	.7042	.7716
22	.6706	.6706	.6203	.6371
23	.6299	.5533	.57	.6173
24	.6371	.6299	.5197	.6036
Max	2.0287	2.1714	2.5149	2.7496
Min	.218	.218	.1844	.2515
Avg	.7852	.9480	1.0775	1.0583



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 201 / BIDKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.5658	.4858	.5426	.583
12	.6859	.6535		.6859
13	.8059	.7468	.7461	.6859
14	.7716	.6478	.8139	.583
15	.7373	.4858	.8478	.5144
16	.6859	.4687	.6783	.6173
17	.6516	1.0269	.6783	.6516
18	.4287	.5668	.5765	.5487
Max	.8059	1.0269	.8478	.6859
Min	.4287	.4687	.5426	.5144
Avg	.6666	.6353	.6976	.6087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 202 / INDUSTRIAL STONE CRUSHER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	.12	.3734	.4748
2	.1696	.12	.3734	.4409
3	.2374	.1715	.3734	.3391
4	.3052	.2743	.3734	.2713
5	.3052	.3601	.3734	.1357
6	.0678	.2915	.0934	.3052
7	.0339	.2401		.1696
8	.1017	.0857	.0934	.0678
9	.1017	.1543	.0934	.1696
10	.5144	.1867	.1696	.2058
11	.6173	.6535	.3391	.2401
12	.6516	.5601	.373	.2058
13	.6859	.4668	.407	.2401
14	.583	.0934	.0678	.1715
15	.4801	.0934	.5426	.2058
16	.583	.0934	.407	.2401
17	.6859	.3734	.4578	.1715
18	.4801	.5601	.4748	.2058
19	.3772	.0951	.3391	.1715
20	.2401	.1867	.1357	.2058
21	.12	.2801	.1696	.2401
22	.12	.3734	.3391	.1715
23	.12	.4668	.3052	.3772
24	.2543	.12	.4668	.407
Max	.6859	.6535	.5426	.4748
Min	.0339	.0857	.0678	.0678
Avg	.3321	.2675	.3105	.2431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 203 / LAKHEGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.7716	.8097	.6783	.6859
12	1.0802		.5087	.823
13	1.406		.9835	.8573
14	1.3203	.6478	.9156	.6859
15	1.2346	.6535	.8817	.6516
16	1.0631	.5668	.9326	.6859
17	.9088	1.0526	1.0174	.7202
18	.8745	.9717	.78	.6859
Max	1.406	1.0526	1.0174	.8573
Min	.7716	.5668	.5087	.6516
Avg	1.0824	.7837	.8372	.7245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 204 / PANGRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.3944	.6478	.6783
2	.6443	.4458	.9335	.78
3	.6443	.5144	.8097	.8478
4	.6443	.5487	.9717	1.0513
5	.6226	.583	1.2146	1.0852
6	.3052	.5144	1.3203	.9835
7	.3052	.4458		1.3904
8	.407	.4287	1.3765	1.5261
9	.4409	.5658	1.4937	1.2887
10	.4458	.6535	.6783	1.2003
17			.6783	
Max	.6443	.6535	1.4937	1.5261
Min	.3052	.3944	.6478	.6783
Avg	.5104	.5095	1.0124	1.0832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 205 / NILAJGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2713	.1372	.4858	.6783
2	.2713	.1715	.5668	.8478
3	.3052	.1715	.5668	.8817
4	.3391	.2229	.6478	.9496
5	.373	.2572	.8164	.9835
6	.373	.5316		.8478
7	.4409	.823		1.2548
8	.6783	.7716	1.307	1.3226
9	.7122	.8402	1.4937	1.3565
10	.7888	.9717	1.1869	1.1317
13			1.1869	
Max	.7888	.9717	1.4937	1.3565
Min	.2713	.1372	.4858	.6783
Avg	.4553	.4898	.9176	1.0254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 207 / INDUSTRIAL BIDKIN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.1715	.2801	.2035
2	.373	.1715	.2801	.2035
3	.3391	.1886	.2829	.2374
4	.2713	.2058	.2801	.2713
5	.3391	.2229	.2829	.2713
6	.3052	.2915	.2801	.2374
7	.2713	.3429		.3391
8	.5426	.4458	.3734	.4748
9	.4748	.5487	.5601	.5765
10	.6001	.6535	.4409	.3429
11	.583	.7468	.4748	.4115
12	.4973	.7468	.3052	.3772
13	.4115	.7468	.3391	.3429
14	.463	.5658	.3391	.2401
15	.5144	.5601	.407	.3772
16	.4973	.5601	.407	.4115
17	.463	.4668	.3391	.3772
18	.4458	.4668	.3052	.4115
19	.3944	.3734	.2713	.3429
20	.3944	.3734	.2713	.3086
21	.3772	.2801	.2374	.3429
22	.3086	.2801	.3391	.2058
23	.2401	.2801	.3052	.2401
24	.2713	.2401	.2801	.2713
Max	.6001	.7468	.5601	.5765
Min	.2401	.1715	.2374	.2035
Avg	.4063	.4137	.3340	.3258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 209 / BIDKIN Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9326	1.0288	1.0269	.8478
2	.9835	1.0288	1.0269	1.0174
3	1.0513	1.2346	1.1203	1.2209
4	1.2548	1.6461	1.4937	1.5939
5	1.8991	2.0062	2.1472	2.34
6	2.6791	2.452		2.8826
7	2.6452	2.915		1.8652
8	2.6113	2.0405	3.1741	1.5939
9	2.2043	2.4177	2.1866	1.3565
10	1.0117	2.0748	1.7804	1.8519
11	.9088		1.1869	.823
12	.8745	1.0269	.8478	.6516
13	.8573	.9335	.8817	.6859
14	.7202	.9335	.8817	.583
15	.583	1.0269	.9496	.5144
16	1.1145	1.0269	1.3226	.7202
17	1.6632	1.6804		1.3717
18	2.2462	2.6139	1.6956	2.4691
19	2.2805	2.6139	***	1.8861
20	1.9033	2.0538	1.933	1.6804
21	1.5432	1.307	1.6617	1.4403
22	1.4746	1.1203	1.2209	1.2003
23	1.3717	1.0269	.9156	1.0631
24	.9326	1.2003	.9335	.8478
Max	2.6791	2.915	19.4828	2.8826
Min	.583	.9335	.8478	.5144
Avg	1.4894	1.6265	2.2795	1.3545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 210 / Bidkin Town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6554	.7716	.7468	.6443
2	.6783	.7716	.7468	.6783
3	.7461	1.0974	.7468	.7122
4	.8139	1.1488	.9335	.7461
5	1.1869	1.1831	1.2136	1.1869
6	1.8991	1.869	2.1472	2.0517
7	1.933	2.5549		
8	1.8652	2.3663		
9	2.3061	2.1605		
10	1.8861	1.9605		
11	1.3375	1.4937	2.0008	2.8806
12	1.2174	1.4003	1.6278	2.675
13	1.0974	1.307	1.2209	2.4006
14	1.0117	1.0269	1.0513	1.0974
15	.9259	.9335		2.0576
16	.9259	1.2136	1.2548	2.332
17	.9259	1.4937	1.4582	2.8806
18	1.8519	2.1472	1.8991	3.978
19	2.0233	2.1472	2.1026	2.7434
20	1.6118	1.9605	1.5261	2.4006
21	1.2174	1.2136	1.2887	2.4692
22	1.0288	.9335	.9835	2.0576
23	.9602	.7468	.7461	1.7832
24	.7461	.8573	.7468	.6783
Max	2.3061	2.5549	2.1472	3.978
Min	.6554	.7468	.7461	.6443
Avg	1.2855	1.4483	1.2864	1.9227



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 201 / BARANAGAR I  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	20-DEC-17
HR	Load (MW)
1	.1867
2	.1867
3	.1867
4	.2801
5	.2801
6	.4294
7	.5658
8	.8962
9	.7545
10	.6036
Max	.8962
Min	.1867
Avg	.4370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 202 / BARANAGAR II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.4572	.2801	.2427
2	.5975	.2801	.2614
3	.6348	.2801	.2427
4	.5335	.2614	.2614
5	.5487	.2614	.2614
6	.6097	.2427	.2427
7	1.3256	.2427	.2614
8	1.2955	.2427	.2614
9	.7621	.2241	.2427
10	1.0669	.2241	.2427
11	.884	1.0642	2.3339
12	1.3717	2.1098	2.2405
13	1.6004	2.2779	2.7633
14	1.5546	2.3339	2.8006
15	1.6004	2.4272	2.4272
16	1.4784	2.2405	2.3899
17	1.0669	2.0351	.8402
18	.8383	1.5089	.5601
19	.2641	.2614	.2801
20	.2829	.2614	.2614
21	.2829	.2614	.2801
22	.2829	.2614	.2801
23		.2614	.2614
24	.2641	.2801	.2427
Max	1.6004	2.4272	2.8006
Min	.2641	.2241	.2427
Avg	.8523	.8385	.8534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 203 / 11 KV KAPUS WADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0754	.3734	.3734
2	.0754	.3734	.3734
3	.0754	.4294	.4294
4	.0754	.4668	.4668
5	.0754	.5601	.5601
6	.0754	.8402	
7	.0943	.8775	.9335
8	.0754	.9335	1.2136
9	.0566	1.0456	1.2136
10	.0566	1.0269	1.1203
11	.0566	.0934	.0934
12	.0754	.056	.0934
13	.0943	.056	.0747
14	.0566	.056	.0934
15	.0566	.056	.0934
16	.0566	.056	.0934
17	.0566	.056	.0934
18	.0566	.0747	.0934
19	.0754	.0934	.112
20	.0943	.0943	.112
21	.0943	.0943	.0934
22	.0754	.0754	.0934
23	.0566	.0754	.0934
24	.0754	.0934	.0934
Max	.0943	1.0456	1.2136
Min	.0566	.056	.0747
Avg	.0715	.3315	.3483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 204 / 11 kv Balanagar Gaothan  
feeder Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6535	.6535
2	.7282	.7468	.7468
3	.8029	.9335	.9335
4	1.1203	1.1203	1.2136
5	1.6057	1.4937	1.587
6	2.1098	2.4272	2.4272
7	2.5953	2.5206	2.5206
8	2.4646	2.4272	2.0538
9	2.0165	2.0165	1.4937
10	1.419	1.531	1.363
11	.9522	.7842	.9335
12		.6535	.7468
13	.6535	.5975	.6535
14	.4668	.5601	.6535
15	.6348	.6722	.6535
16	.7282	.8402	.9335
17	1.4377	1.3443	1.2136
18	1.9978	2.0538	2.1658
19	1.7364	1.9978	2.0911
20	1.1949	1.363	1.4003
21	1.0269	.9335	.9335
22	.7842	.7922	.9335
23	.7282	.6908	.9335
24	.6908	.6722	.6535
Max	2.5953	2.5206	2.5206
Min	.4668	.5601	.6535
Avg	1.2428	1.2427	1.2455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 205 / Ginning  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2829	.5041	.4481
2	.3018	.5041	.4294
3	.3018	.4854	.4481
4	.3018	.4854	.4668
5	.3206	.4854	.4481
6	.3772	.4854	.4668
7	.4338	.4854	.4668
8	.6036	.4854	.4481
9	.547	.4108	.4668
10	.4904	.3547	.4668
11	.6036	.4854	.5228
12	.6036	.5415	.5601
13	.6224	.4294	.4668
14	.6036	.4668	.6535
15	.5658	.5415	.4854
16	.6036	.4668	.4668
17	.547	.3921	.4854
18	.547	.3734	.4108
19	.4527	.3547	.3361
20	.7356	.5228	.3547
21	.5093	.4668	.3734
22	.4904	.4854	.3361
23	.4527	.5658	.3547
24	.2829	.5041	.4481
Max	.7356	.5658	.6535
Min	.2829	.3547	.3361
Avg	.4825	.4701	.4504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 206 / kherda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.381		
2	.381		
3	.381		
5	.381		
6	.3201		
7	.503		
8	.6706		
9	.7011		
10	.7621		
11	.8383	1.1203	.5601
12	1.1279	1.4003	.8402
13	1.1584	1.4377	1.2136
14	1.1431	1.4003	1.307
15	1.1584	1.307	1.0456
16	1.0212	1.1203	1.1203
17	.8383	.9709	1.1576
18	.6859	.8402	.8962
Max	1.1584	1.4377	1.307
Min	.3201	.8402	.5601
Avg	.7325	1.1996	1.0176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 201 / 11 KV LOHAGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
5	.8669	
10	.8669	
11		1.2955
12		1.4575
13		1.6194
14		1.2498
15		1.6194
16		1.6194
17		1.6194
Max	.8669	1.6194
Min	.8669	1.2498
Avg	.8669	1.4972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 202 / 11 KV DHAKEPHAL FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1		.7287
2		.7287
3		.8097
5		.8097
6		.8907
7		.9717
8		.9717
9		1.0526
10	1.0526	1.0526
Max	1.0526	1.0526
Min	1.0526	.7287
Avg	1.0526	.8907



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 203 / 11 KV TONDOLI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	20-DEC-17
HR	Load (MW)
1	.8097
2	.8097
3	.9717
4	.9717
5	1.0526
6	1.1336
7	1.2955
8	1.2955
9	1.2955
Max	1.2955
Min	.8097
Avg	1.0706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 204 / 11 KV BRAMHAGAWAN FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	19-DEC-17
HR	Load (MW)
11	1.2955
12	1.3765
13	1.3765
14	1.4575
15	1.5223
16	1.4575
Max	1.5223
Min	1.2955
Avg	1.4143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 205 / 11 KV VIJAYPUR FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1		.8097
2		.8097
3		.8097
4		.8097
5		1.0526
6		1.0526
7		.9717
8		1.1336
9		.9717
10	1.1336	.9717
<b>Max</b>	<b>1.1336</b>	<b>1.1336</b>
<b>Min</b>	<b>1.1336</b>	<b>.8097</b>
<b>Avg</b>	<b>1.1336</b>	<b>.9393</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 206 / 11 kv Lohgaon Gaothan  
feeder Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1		.6478
2		.7287
3		.7287
4		.9717
5		.9717
6		1.3765
7		1.7814
8		1.6194
9		1.2955
10	1.1736	.9717
11	.8097	
12	.6478	
13	.6478	
14	.6478	
16	.5668	
17	.5668	
18	.6478	
19	1.2955	
20	1.2955	
21	.9717	
22	.8097	
23	1.3441	
24		.6478
Max	1.3441	1.7814
Min	.5668	.6478
Avg	.8788	1.0674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 207 / 11 KV Segenta  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)
1		.0972
2		.0972
3		.0972
4		.0972
5		.1006
6		.0972
7		.1296
8		.3239
9		.3239
10	.3239	.3887
11	.3887	
12	.421	
13	.4372	
14	.3887	
15	.421	
16	.4534	
17	.3887	
18	.1781	
19	.1619	
20	.0972	
21	.0972	
22	.0972	
23	.0972	
24		.0972
Max	.4534	.3887
Min	.0972	.0972
Avg	.2822	.1682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 208 / 11 KV Gadegaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	19-DEC-17
HR	Load (MW)
11	.5344
12	.5668
13	.583
14	.5668
15	.5868
16	.5668
17	.6478
18	.5506
Max	.6478
Min	.5344
Avg	.5754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 201 / 11 KV HARSHI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0381	.0754	.0943	.0572
2			.0381	.0754	.0754	.0762
3			.0572	.0754	.0754	.0953
4			.0572	.0566	.0754	.0762
10	.2652					
11			.5571	.4588	.724	
12			.639	.6226	.8192	.8573
13			.7045	.639	.8192	.8002
14			.7865	.6316	.8573	.7621
15			.7611	.6154	.8954	.7621
16			.6802	.6316	.8192	.9145
17			.6154	.5182	.743	.9145
18			.4858	.4752	.6478	.8383
19			.0754	.0754	.0381	.0381
20			.0754	.0754	.0572	.0381
21			.0754	.0754	.0572	.0381
22		.0572	.0754	.0754	.0572	.0572
23		.0381	.0754	.0943	.0762	
24			.0381	.0754	.0943	.0572
Max	.2652	.0572	.7865	.639	.8954	.9145
Min	.2652	.0381	.0381	.0566	.0381	.0381
Avg	.2652	.0477	.3242	.2970	.3903	.3989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 203 / 11KV KUTUBKHEDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0754	.0754	.0953
2		.0381	.0754	.0754	.0762
3		.0572	.0754	.0754	.0762
4		.0762	.0754	.0754	.0572
11		.639	.6062	.7621	.5906
12		.7373	.7209	.9145	.7621
13		.8421	.7045	.6478	.7621
14		.8259	.7125	.724	.724
15		.8097	.7287	.8002	.6668
16		.7449	.6964	.7621	.724
17		.7209	.6154	.724	.7049
18		.5735	.4858	.6859	.6668
19		.0566	.0754	.0572	.0191
20		.0566	.0754	.0381	.0381
21		.0566	.0754	.0572	.0381
22	.0572	.0754	.0754	.0762	.0762
23	.0381	.0754	.0754	.0953	.0572
24		.0381	.0754	.0754	.0762
Max	.0572	.8421	.7287	.9145	.7621
Min	.0381	.0381	.0754	.0381	.0191
Avg	.0477	.3590	.3347	.3734	.3451



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 204 / 11KV DAWARWADI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.1802	.213	.2667
2		.4108	.213	.2458	.3048
3		.3239	.3277	.2785	.3048
4		.2812	.3605	.3113	.381
5		.2743	.4424	.3768	.5144
6		.2439	.4588	.4534	.7621
7		.3521	.4752	.5182	.9526
8		.4572	.4915	.6316	1.0479
9		.5312	.6316	.7811	1.2384
10		.5487	.6154	.8383	1.1812
16		.0189	.0189	.0191	.0762
17		.0189	.0189	.0381	.0762
18		.0377	.0377	.0381	.1144
19		.0566	.0566	.0191	.1144
20		.0566	.0566	.0381	.1144
21		.0566	.0566	.0381	.1144
22	.0572	.0566	.0566	.0381	.0572
23	.0572	.0566	.0566	.0381	.0762
24		.0381	.0566	.0566	.0381
Max	.0572	.5487	.6316	.8383	1.2384
Min	.0572	.0189	.0189	.0191	.0381
Avg	.0572	.2041	.2427	.2617	.4071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 205 / 11 KV NANDAR AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0754	.0754	.0762
2		.0566	.0754	.0754	.0762
3		.0572	.0754	.0754	.0762
4		.0572	.0754	.0754	.0953
11		.6062	.639	.8764	.8573
12			.8745	1.1241	1.0098
13		.8192	.8421	.9145	.9717
14		.8356	.4588	1.0479	1.0288
15		.8097	.7865	1.1812	1.0669
16		.9069	.8745	1.1812	1.867
17		.9555	.8259	1.105	1.5622
18		.8259	.7125	.9907	1.3336
19		.0566	.0754	.0381	.1144
20		.0566	.0754	.0572	.1144
21		.0566	.0754	.0572	.0762
22	.056	.0566	.0754	.0572	.0762
23	.056	.0566	.0754	.0762	.0953
24		.0566	.0566	.0754	.0572
Max	.056	.9555	.8745	1.1812	1.867
Min	.056	.0566	.0566	.0381	.0572
Avg	.056	.3721	.3749	.5047	.5864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 206 / 11 KV GFSS-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.3113	.2949	.2667
2		.3361	.3277	.3441	.3048
3		.4161	.4096	.3768	.4001
4		.5312	.5243	.639	.6097
5		.6401	.7373	.6802	.9717
6		1.0364	1.1469	.9231	1.448
7		1.0848	1.1498	1.2631	1.3717
8		1.0997	1.166	1.3603	1.2955
9		1.0486	1.0688	1.1812	1.2003
10		.6316	.6802	.9145	.9335
11		.3605	.4588	.6668	.6859
12		.3113	.2949	.4382	.5716
13		.2785	.2785	.4001	.4382
14		.2622	.2458	.362	.381
15		.2622	.2949	.362	.381
16		.4096	.3768	.4763	.6097
17		.5571	.6226	.743	1.0098
18		.852	.8356	1.0669	1.3527
19		.9995	1.004	1.2193	1.1241
20		.639	.7287	.9145	.8192
21		.4424	.4915	.4954	.9908
22	.3887	.3605	.4588	.3429	.4191
23	.2915	.3113	.3605	.3048	.3429
24		.2801	.2949	.3113	.2667
Max	.3887	1.0997	1.166	1.3603	1.448
Min	.2915	.2622	.2458	.2949	.2667
Avg	.3401	.5605	.5945	.6700	.7581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 207 / 11 KV GFSS-II FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2012	.2785	.2785	.2286
2		.2347	.3113	.2949	.2667
3		.2915	.3605	.3441	.3048
4		.3201	.5243	.4588	.4572
5		.4374	.639	.5407	.743
6		.583	.8421	.639	1.0098
7		.7362	.8259	.7209	.9717
8		.7621	.8745	.7935	.9335
9		.7865	.6882	.743	.8002
10		.4862		.5525	.7621
11		.2458	.2785	.4001	
12		.1966	.213	.2096	
13		.1638	.1966	.1905	.1715
14		.1802	.1638	.1715	.1715
15		.1966	.1802	.1715	.2096
16		.2949	.213	.381	.4001
17		.3605	.4588	.4954	.743
18		.6226	.6226	.6097	.8573
19		.6478	.5898	.7621	.6097
20		.5182	.4588	.4954	.4572
21		.3277	.3277	.4001	.9336
22	.2622	.3113	.2949	.2667	.4191
23	.2321	.2949		.2667	.362
24		.2012	.2785	.2785	.2286
Max	.2622	.7865	.8745	.7935	1.0098
Min	.2321	.1638	.1638	.1715	.1715
Avg	.2472	.3917	.4373	.4360	.5473

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 201 / 11KV NATH MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4334	.5304		.4458
2	.5258	.4938		.4334
3	.5609	.4755		.4287
4	.6024	.5853		.4287
5	.691	.6767		.5373
6	.9134	.8962		.8413
7	1.086	1.1523		1.0456
8	1.1888	1.0791		.9671
9	.9511	.9328	.9922	.9671
10	.8775	.8779	.8764	.9036
11	.7362	.7865	.7362	
12	.7011	.7316	.6241	
13	.6241	.6767	.6415	
14	.5959	.6036	.4458	
15	.4733		.5201	
16	.5258		.5487	
17	.7265		.6661	
18	.9568		1.0317	
19	1.0924		1.0566	
20	.9492		.9214	
21		.8596	.8842	
22		.695	.6859	
23		.6401		
24	.5609	.5304		.4961
Max	1.1888	1.1523	1.0566	1.0456
Min	.4334	.4755	.4458	.4287
Avg	.7511	.7346	.7594	.6813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 204 / 11 KV OPEN JAIL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7282	.056	.0055	.056	.056
2			.7827	.056	.0549	.056	.056
3			.7676	.056	.0549	.056	.056
4			.823	.056	.0549	.056	.056
5			.8688	.056	.0549	.056	.0747
6			.8383	.056	.0549	.056	.0747
7			.8796	.056	.056	.056	.0747
8			.9633	.056	.0377	.056	.0373
9			1.186	.056	.0549	.056	.056
10			.9217	.056	.0732	.056	.056
11			.037	1.2308	1.587	1.749	1.7976
12			.037	1.2955	1.7328	1.9271	2.2592
13			.037	1.4737	1.7652	2.0809	1.9919
14			.0187	1.4575	1.7814	2.3339	2.0243
15			.0187	1.704	1.7976	2.0809	2.0243
16			.0187	1.7166	1.7976	2.1052	2.0729
17			.0187	1.6194	1.704	2.1628	
18			.0187	1.4575	1.6385	1.8947	
19			.0187	.0943	.0934	.0934	
20			.0373	.056	.0934	.0739	
21			.0373	.0549	.056	.0747	.0747
22			.056	.0549	.056	.056	.0747
23		.0373	.056		.056	.056	.0747
24	.0373	.0373		.056	.0732	.056	.056
Max	.0373	.0373	1.186	1.7166	1.7976	2.3339	2.2592
Min	.0373	.0373	.0187	.0549	.0055	.056	.0373
Avg	.0373	.0373	.3987	.5579	.6139	.7210	.6524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 205 / 11 KV CHANGATPURI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.6687		.5792	.5868
2	.0747	.6241		.5796	.5792
3	.0934	.6097		.5647	.5868
4	.0934	.6097		.5944	.6241
5	.0934	.6249		.6321	.6836
6	.0747	.6019		.6622	.7727
7	.112	.6327		.6859	.9145
8	.0747	.7562		.823	1.1443
9		.7225		.8278	1.1591
10		.679		.8429	1.1584
11		.0362		.0924	.0905
12	.9214	.0181	.0549	.0171	.0905
13	1.1443	.0373	.0549	.0191	.0934
14	1.174			.0171	.0747
15	1.1736	.0366	.056	.0187	.0747
16	1.2041	.0366	.056	.0187	
17	1.1736		.0739	.0187	.0724
18	1.1736		.0554	.0716	.0724
19	.0747		.056	.0905	.0724
20	.0747	.0543	.0739	.0905	.0724
21	.0934	.0549	.0739	.0709	.0905
22	.056	.0549	.0739	.0532	.0914
23	.0747	.0549	.0739	.056	.0724
24		.0549	.0549	.0739	.0537
Max	1.2041	.7562	.0739	.8429	1.1591
Min	.056	.0181	.0549	.0171	.0537
Avg	.4512	.3484	.0631	.3125	.4013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 206 / 11kV Telwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0732		.0934
2	.0934	.0914		.0934
3	.112	.0914		.0934
4	.1307	.0914		.112
5	.1307	.0914		.1307
6	.1307	.1097		.1494
7	.1307	.1097		
8	.1307	.1097		.112
9	.112	.0732	.0924	.0934
10	.112	.0914	.0934	.0934
11	.7926		1.2498	
12	1.0936	1.5432	1.5813	
13		1.4251	1.7004	
14		1.3927	1.7976	
15			1.186	
16			1.6194	
17			1.7976	
18			1.4899	
19			.128	
20			.0934	
21			.0934	
22			.112	
23			.112	
24	.0934			.0934
Max	1.0936	1.5432	1.7976	.1494
Min	.0934	.0732	.0924	.0934
Avg	.2428	.4072	.8764	.1065



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 207 / 11kV Nath Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0183		.0171
2	.0171	.0183		.0171
3	.0171	.0183		.0171
4	.0171	.0183		.0171
5	.0171	.0183		.0171
6	.0171	.0183		.0171
7	.0171	.0183		.0171
8	.0171	.0183		.0171
9	.0171	.0183	.0175	.0171
10	.0171	.0189	.0171	.0171
11	.0171	.0183	.0171	
12	.0171	.0183	.0171	
13	.0171	.0019	.0171	
14	.0171	.0183	.0171	
15	.0171		.0171	
16	.0171		.0171	
17	.0171		.0171	
18	.0171		.0171	
19	.0171		.0171	
20	.0171		.0171	
21			.0171	
22			.0171	
23			.0171	
24	.0171	.0183		.0171
Max	.0171	.0189	.0175	.0171
Min	.0171	.0019	.0171	.0171
Avg	.0171	.0172	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 208 / 11kV Urban Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3475		.2926
2	.3258	.3772		.2926
3	.3982	.3841		.3142
4	.5853	.5487		.5415
5	1.0082	.9694		.9522
6	1.5466	1.5364		1.4937
7	1.6975	1.7741		1.7353
8	1.7353	1.7924		1.6804
9	1.5466	1.4998	1.1317	1.363
10	1.1389	1.1888	1.0082	1.1576
11	.5788	.7682	.6838	.7316
12	.5228	.6219	.499	.567
13	.4668	.4572	.3841	.5068
14	.4207	.4207	.4163	.4887
15			.439	.5068
16	.6036		.4572	.567
17	.8962		.7392	.9328
18	1.3256			1.3306
19	1.251		1.531	1.386
20	.8402		1.0829	1.0269
21	.5304		.6908	.7468
22	.4024		.4435	.6535
23	.3292		.3475	.547
24	.3361	.3475		.3142
Max	1.7353	1.7924	1.531	1.7353
Min	.3258	.3475	.3475	.2926
Avg	.8184	.8689	.7039	.8387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 209 / 11KV GHARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8749	.8764	.743	.8025
2			.8592	.8939	.743	.8025
3				.9114	.7133	.7628
4				.9114	.7133	.7628
5			.8488	.9114	.8025	.7727
6			.8749	.9465	.8471	.823
7			.9568	1.0692	1.0385	.9145
8			1.0595	1.2146	1.1431	1.1888
9			1.1227	1.3496	1.1279	1.2654
10			1.078	1.2795	1.142	1.1873
11			.0373	.0549	.056	.0934
12			.0373	.0732	.056	.0747
13			.0373	.0732	.0747	.0747
14			.0373	.0732	.0187	.0747
15		1.491		.0747	.0187	.0747
16		1.4373	.056	.0747	.0187	.0747
17		1.4413	.056	.056	.0373	.0747
18		1.3117	.056		.056	.0747
19		.112	.056	.0747	.056	.0747
20		.0934	.056	.0747	.0934	.0747
21		.0747	.0549	.0747	.0747	.0747
22		.0747	.0549	.0747	.056	.0747
23		.056	.056	.0747	.056	.0747
24	.0934		.056	.0549	.0747	.056
Max	.0934	1.491	1.1227	1.3496	1.1431	1.2654
Min	.0934	.056	.0373	.0549	.0187	.056
Avg	.0934	.6769	.3965	.4901	.4067	.4303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 201 / 11KV DHORKIN GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1867	.1867
2	.1867	.1886	.1867	.1867
3	.1867	.1886	.2241	.2241
4	.2801	.2829	.3361	.4108
5	.4668	.3734	.5601	.6722
6	.6535	.6535	.7095	.811
7	.7468	.7468	.7842	.8865
8	.6535	.6908	.7842	.811
9	.4668	.5658	.6348	.7842
10	.3734	.3772	.4668	.6535
11	.3361	.3361	.2801	.2772
12	.2241	.2614	.2427	.2218
13	.2427	.2402	.2054	.1848
14	.1867	.2587	.168	.1848
15	.1867	.2402	.1867	.1848
16	.2427	.2957	1.4377	.1848
17	.3361	.4108	.4481	.1848
18	.5601	.5601	.5601	.4668
19	.6535	.6722	.679	.5601
20	.4668	.3734	.5041	.3734
21	.2801	.2987	.3174	.2801
22	.2241	.2241	.2241	.1867
23	.1867	.2054	.2054	.1867
24	.1867	.1867	.1867	.1867
Max	.7468	.7468	1.4377	.8865
Min	.1867	.1867	.168	.1848
Avg	.3548	.3675	.4383	.3871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 202 / 11KV DHORKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.2378	.2286
2	.1524	.1524	.2378	.2591
3	.1524	.1524	.2675	.3048
4	.1981	.2286	.2824	.3549
5	.2286	.3506	.2972	.3858
6	.081	.3963	.3715	.4062
7	.3077	.4725	.4458	.5937
8	.3921	.664	.6984	.759
9	.4668	.6401	.6836	.7432
10	.4115	.6097	.4458	.6874
11	.0572			.0191
12	.0381		.0381	.0381
13	.0381	.0381	.0381	.0191
14	.0381	.0572	.0381	.0381
15	.0191	.1143	.0572	.0381
16	.0572	.0953	.1143	.0381
17	.1143	.1524	.1143	.1524
18	.0953	.1143	.1143	.1715
19	.1307	.1524	.1524	.1905
20	.0762	.1334	.1143	.1905
21	.0762	.1143	.1143	.1867
22	.0762	.1143	.1143	.1524
23	.0747	.0953	.1143	.1867
24	.0747	.0762	.0953	.0572
Max	.4668	.664	.6984	.759
Min	.0191	.0381	.0381	.0191
Avg	.1462	.2308	.2255	.2584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 203 / 11KV KARKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0943	.1132	.056
2	.0943	.0943	.1132	.056
3	.0943	.0943	.0943	.0747
4	.0943	.0943	.0943	.0747
5	.0943	.0934	.0943	.0943
6	.056	.112	.0943	.0943
7	.056	.0934	.1132	.0943
8	.0934	.112	.1132	.0943
9	.0934	.1132	.1132	.0943
10	.0934	.0732	.0566	.0943
11	.4999	.5535	.6249	.5601
12	.9602	.6405	.9061	.9602
13	1.0722	.8124	1.0595	1.0402
14	.381	.9686	1.0437	1.1203
15	1.0402	1.0753	1.0279	1.0402
16	.9762	1.0753	1.0402	1.0526
17	.9122	.9172	.8436	.8962
18	.8002	.7716	.7164	.8002
19	.112	.1494	.1646	.2427
20	.0934	.1494	.1463	.2427
21	.0934	.1463	.128	.2241
22	.1132	.1463	.128	.2054
23	.112	.128	.1097	.2054
24	.112	.112	.128	.0747
Max	1.0722	1.0753	1.0595	1.1203
Min	.056	.0732	.0566	.056
Avg	.3392	.3592	.3778	.3955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 204 / 11KV DHANGAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	.8002	.6562	.7316
2	.8002	.8002	.6562	.7926
3	.8482	.8802	.7186	.8179
4	.8907	.8802	.7811	.8333
5	.8907	1.1949	.9842	.9061
6	1.0642	1.307	.9374	.9842
7	1.004	1.1431	1.1984	1.2176
8	1.3256	1.6057	1.3765	1.4723
9	1.4003	1.3927	1.5043	1.5364
10	1.1203	.9762	1.012	1.4083
11	.0747	.0373	.0377	.056
12	.0554	.0373	.0377	.0373
13	.037	.0377	.0377	.0373
14	.0549	.0377	.0377	.0373
15	.0554	.0377	.0377	.0373
16	.056	.0377	.0377	.0373
17	.056	.0377	.0377	.0187
18	.056	.0377	.0377	.0373
19	.056	.0566	.0566	.056
20	.056	.0566	.0566	.056
21	.056	.0566	.0566	.056
22	.056	.0566	.0566	.056
23	.056	.0566	.0377	.056
24	.056	.056	.0566	.0377
Max	1.4003	1.6057	1.5043	1.5364
Min	.037	.0373	.0377	.0187
Avg	.4552	.4842	.4353	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.132	.1905	.1509
2	.0373	.132	.1715	.1509
3	.0373	.132	.1494	.1509
4	.056	.132	.1448	.1509
5	.056	.1307	.0886	.1509
6	.056	.1494	.1307	.1886
7	.056	.1494	.1494	.1886
8	.056	.1494	.1494	.1132
9	.0934	.1698	.2096	.2096
10	.056	.1886	.1307	.2096
11	.056	.1905	.2075	.1886
12	.056	.2096	.2286	.1886
13	.0373	.1905	.1905	.2054
14	.1886	.2096	.2096	.2075
15	.1886	.1905	.2096	.2054
16	.1886	.1905	.2096	.2054
17	.1886	.2286	.1905	.2054
18	.1698	.1698	.1698	.1867
19	.1307	.1509	.1715	.1494
20	.1307	.1509	.1143	.1494
21	.168	.1509	.1143	.1494
22	.1267	.1905	.1143	.1494
23	.1307	.1905	.1143	.168
24	.056	.168	.1905	.1524
Max	.1886	.2286	.2286	.2096
Min	.0373	.1307	.0886	.1132
Avg	.0982	.1686	.1646	.1740



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 211 / NANDALGAON AG FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.3715	.3241	.4321	.4877
12	.5639	.4321	.5864	.5639
13	.6401	.4938	.4475	.6097
14	.6173		.6173	.6401
15	.6097	.5335	.6481	.6554
16	.6097	.5639	.679	.6554
17	.4572	.3506	.4938	
18	.3506	.3201	.3858	.4321
Max	.6401	.5639	.679	.6554
Min	.3506	.3201	.3858	.4321
Avg	.5275	.4312	.5363	.5778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 212 / 11KV KARKIN GAOTHAN FEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1886	.1307	.1494
2	.1867	.1886	.1307	.1494
3	.1867	.2829	.168	.1867
4	.3734	.2829	.2241	.3174
5	.5601	.4668	.2614	.4481
6	.7095	.6908	.4854	.7733
7	.8029	.8029	.6535	.8676
8	.6908	.7655	.5601	.7655
9	.5041	.6036	.4854	.5975
10		.4715	.2801	.3734
11	.3547	.2614	.1867	.2801
12	.2241	.2241	.1494	.1867
13	.1867	.2218	.1494	.1867
14	.1867		.1494	.1494
15	.2054	.2218	.1867	.1478
16	.2614	.2587	.2614	.1867
17	.3734	.3174	.3921	
18	.5975	.3734	.5975	.5975
19	.7095	.4481	.5658	.6908
20	.4668	.3361	.3921	.4294
21	.3547	.168	.2801	.3361
22	.2241	.1307	.1494	.2241
23	.168	.1307	.1307	.2054
24	.1867	.168	.1307	.1494
Max	.8029	.8029	.6535	.8676
Min	.168	.1307	.1307	.1478
Avg	.3783	.3480	.2959	.3651

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 201 / 11KV Ranjangaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.1715	.1543	.1715
2		.2058	.2058	.1543	.1524
3		.2401	.2058	.1543	.1715
4		.3086	.3086	.2572	.2439
5		.7202	.5316	.463	.5182
6		.9602	.7202	.6335	.9259
7		1.0288	.9945	.9055	.9602
8		.7888	.8916	.8871	.9088
9		.7716	.703	.6697	.5944
10		.5487	.5249	.463	.5144
11		.3601	.3429	.3258	
12		.2572	.2229	.2743	.2058
13		.2229	.2058	.2401	.1886
14			.1715	.2229	.1886
15		.2229	.1886	.2229	.2401
16		.2915	.3086	.2401	.3086
17		.5144	.4525	.4115	.4287
18		.823	.5973	.5144	.6859
19	.7716	.8059	.8589	.7202	.7716
20	.6516	.6173	.6697	.6173	.6859
21	.4458	.3258	.3086	.3086	.4115
22	.2743	.2401	.2572	.2572	.2229
23	.1886	.2058	.2058	.2058	.2058
24		.1886	.1886	.1543	.1524
Max	.7716	1.0288	.9945	.9055	.9602
Min	.1886	.1886	.1715	.1543	.1524
Avg	.4664	.4719	.4265	.3941	.4286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 202 / Marhola

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.1219	.12	.1067
2		.1067	.1219	.12	.1067
3		.1067	.1219	.12	.1067
4		.1219	.1524	.1372	.1067
5		.1372	.1524	.1715	.1219
6		.1677	.1829	.2058	.1829
7		.1829	.1981	.2743	.2286
8		.1829	.2134	.2743	.2134
9		.1677	.1981	.2058	.2134
10		.1067	.1372	.1677	.1524
11		1.0669	1.1405	1.0669	.945
12		.0914	1.4883		1.0669
13		1.4175	1.4403	1.1584	1.1584
14			1.3443	1.1888	1.2346
15		1.2955	1.2163	1.1888	1.2651
16		1.2498	1.2186	1.2193	1.2498
17		1.387	1.2803	1.2346	1.2346
18		1.1126	1.1092	1.0669	1.0364
19	.1219	.2134	.2401	.1981	.0914
20	.1067	.1829	.1715	.1524	.1067
21	.0914	.1372	.1372	.1219	.0914
22	.0914	.1372	.1372	.1067	.0914
23	.0914	.1219	.12	.1067	.0914
24		.0762	.1067	.12	.1067
Max	.1219	1.4175	1.4883	1.2346	1.2651
Min	.0914	.0762	.1067	.1067	.0914
Avg	.1006	.4301	.5313	.4664	.4712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 203 / Shekta

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2134		.1524
2	.1524	.1829		.1524
3	.1677	.1829		.1524
4	.1829	.1829		.1829
5	.1829	.1981		.2134
6	.1981	.1981		.2439
7	.1829	.3048		.3506
8	.2134	.381		.4801
9	.2134	.3963	.1981	.2743
10	.2439	.3658	.4115	.3048
12			.0191	
Max	.2439	.3963	.4115	.4801
Min	.1524	.1829	.0191	.1524
Avg	.189	.2606	.2096	.2507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 204 / AURANGPURWADI AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.8993	.7655	.823
2		.7011	.9145	.7811	.823
3		.7011	.945	.8124	.823
4		.6706	.945	.9061	.9145
5		.7468	.9755	1.0155	1.0059
6		.823	1.0364	1.1523	1.1126
7		.7926	1.2498	1.3763	1.3413
8		.9145	1.4632	1.6004	1.7985
9		1.1568	1.5242	1.6804	1.7375
10		1.0517	1.4243	1.4784	1.4784
11		.0457		.0572	.0305
12		.0457		.0572	.0305
13				.0572	.0305
14				.0381	.0305
15				.0381	.0305
16				.0381	.0305
17		.0152	.0152	.0381	.0305
18		.0152		.0381	.0305
19	.0152	.061	.0305	.0191	.0305
20	.0305		.0305	.0381	.0305
21	.0305		.0305	.0381	.0305
22	.0305		.3353		.0152
23	.0305		.0305	.0381	.0152
24	.0305	.0305		.0305	.0152
Max	.0305	1.1568	1.5242	1.6804	1.7985
Min	.0152	.0152	.0152	.0191	.0152
Avg	.0280	.5286	.7406	.5258	.5100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 205 / DARGHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152	.0152	.0152	.0191
2		.0152	.0152	.0152	.0191
3		.0152		.0152	.0191
4		.0152	.0152	.0152	.0191
5		.0152	.0152	.0152	.0191
6		.0152	.0152	.0152	.0191
7		.0152	.0152	.0152	.0191
8		.0152	.0152	.0152	.0191
9		.0152	.0152	.0152	.0191
10		.0152	.0152	.0191	.0152
11		.945	1.2963	1.2651	1.1736
12		1.1736	1.5364	1.5242	1.4937
13		1.2041	1.4723	1.5546	1.5546
14			1.4403	1.5546	1.6004
15		1.2193	1.3923	1.5851	1.6156
16		1.0669	1.4403	1.4937	1.5851
17		1.1584	1.5203	1.2803	1.5851
18		1.0364	1.3763	1.2346	1.1584
19	.0152	.0152	.0152	.0152	.0152
20	.0152	.0152	.0152	.0191	.0152
21	.0152	.0152	.0152	.0191	.0152
22	.2134	.0152	.0152	.0191	.0152
23	.0152	.0152	.0152	.0152	.0152
24		.0152	.0152	.0152	.0191
Max	.2134	1.2193	1.5364	1.5851	1.6156
Min	.0152	.0152	.0152	.0152	.0152
Avg	.0548	.3499	.5088	.4896	.5020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 201 / UDYOGMITRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1157	1.1462	1.0745
2	1.0631	1.0974	1.1641	1.0631
3	1.0631	1.0974	1.1462	1.0631
4	1.0631	1.134	1.1104	1.0631
5	1.0631	1.1706	1.1104	1.0631
6	1.0631	1.2012	1.2178	1.1462
7	1.1104	1.2197	1.2894	1.1462
8	1.2178	1.3443	1.182	1.2536
9	1.2178	1.419	1.379	1.3253
10	1.643	1.4327	1.2715	1.286
11	1.5684	1.3169	1.3575	1.3432
12	1.6617	1.39	1.0029	1.3672
13	1.4937	1.4632	1.1999	1.2003
14	1.531	1.6461	1.3432	1.286
15	1.5684	1.4632	1.4118	1.286
16	1.587	1.5729	1.5384	1.286
17	1.5684	1.7558	1.3575	1.2346
18	1.363	1.4998	1.3394	1.2003
19	1.1389	1.2536	1.2178	1.0631
20	1.1273	1.0631	1.1462	.9431
21	1.1273	1.2357	1.0745	1.0631
22	1.1157	1.1641	1.0387	1.1641
23	1.1157	1.1641	1.0745	1.0974
24	1.0631	1.1157	1.1641	1.0277
Max	1.6617	1.7558	1.5384	1.3672
Min	1.0631	1.0631	1.0029	.9431
Avg	1.2749	1.3057	1.2201	1.1686



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 202 / NAIGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.815	.7316	.7087	.7619
2	.815	.7316	.7087	.7619
3	.8505	.7316	.7442	.7796
4	.9036	.8413	.8505	.8505
5	1.0277	.9877	.9745	1.0029
6	1.3969	1.531	1.4883	1.5223
7	1.7194	1.6804	1.6478	1.7194
8	1.5203	1.643	1.4175	1.7013
9	1.4327	1.643	1.3998	1.448
10	1.3443	1.4632	1.3253	1.2536
11	1.3443	1.3169	1.3575	1.2536
12	1.0719	.9877	1.2178	1.1145
13	.9511	1.0059	1.0387	.9431
14	.823	1.0974	1.0387	1.0166
15	1.0974	1.0974	1.1462	1.1104
16	1.1827	1.2254	1.2536	1.1145
17	1.363	1.1888	1.3575	1.2346
18	1.531	1.4632	1.448	1.4575
19	1.3817	1.3432	1.448	1.3611
20	1.0974	1.0631	1.1462	1.1462
21	.8779	.9134	.9568	.985
22	.8413	.7164	.8954	.9313
23	.8048	.7011	.815	.8596
24	.7973	.7316	.7087	.7796
Max	1.7194	1.6804	1.6478	1.7194
Min	.7973	.7011	.7087	.7619
Avg	1.1246	1.1182	1.1289	1.1295

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 203 / 11 KV CHITEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.6447	.4908	.5258
2	.5258	.6089	.5083	.5201
3	.5959	.5373	.5258	.5548
4	.7011	.7522	.6661	.6588
5	.9114	.8954	.9114	.9362
6	1.4373	1.4632	1.4373	1.4373
7	1.6124	1.6095	1.6126	1.6126
8	1.5592	1.6095	1.6126	1.6655
9	1.4175	1.4998	1.5775	1.6301
10	1.3535	1.4175	1.382	1.3969
11	1.2071	1.2178	1.2757	1.3611
12	.9877	1.1462	.9214	1.0166
13	.7682	.9313	.7011	.9671
14	.8145	1.0029	.9465	.9313
15	.8688	1.0029	.7362	.9465
16	.905	1.1104	1.1568	.9259
17	1.2071	1.2536	1.0867	1.1104
18	1.39	1.4327	1.4175	1.3969
19	1.4266	1.5074	1.5238	1.4327
20	1.0974	1.0402	1.0631	1.182
21	.8238	.8063	.8063	1.0029
22	.7522	.6241	.6661	.788
23	.7164	.5201	.5609	.6805
24	.5258	.6805	.5258	.5258
Max	1.6124	1.6095	1.6126	1.6655
Min	.5201	.5201	.4908	.5201
Avg	1.0052	1.0548	1.0047	1.0502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 205 / 11 KV CHITEGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7087	.7316	.7011	.7619
2	.7087	.7682	.7011	.7619
3	.7087	.8779	.7011	.7442
4	.7087	.8779	.7712	.7265
5	.7442	.924	.8238	.7265
6	.7619	.8779	.8238	.7442
7	.8505	.8413	.8413	.7442
8	.8505	.823	.9816	.7973
9	1.0387	1.0456	1.0517	1.0924
10	1.1949	1.379	1.3253	1.4022
11	1.419	1.5729	1.448	1.4899
12	1.643	1.4632	1.6289	1.1919
13	1.307	1.4449	1.448	1.3375
14	1.4937	1.6461	1.448	1.5947
15	1.5684	1.4632	1.5746	1.4575
16	1.587	1.5364	1.829	1.4918
17	1.6804	1.4632	1.4118	1.3717
18	1.3443	1.2803	1.3032	1.2689
19	.823	.8149	.8417	.7125
20	.823	.7802	.7701	.7716
21	.823	.8149	.7796	.7522
22	.8048	.6762	.7087	.8059
23	.7316	.6935	.6733	.7545
24	.7087	.7316	.7011	.7619
Max	1.6804	1.6461	1.829	1.5947
Min	.7087	.6762	.6733	.7125
Avg	1.0430	1.0637	1.0537	1.0110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 201 / RAPDRP NEW KAWSAN SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2896	.2715	.2534
2		.2926	.2896	.2715	.2534
3		.3109	.2715	.3077	.2715
4		.3109	.362	.3439	.362
5		.4572	.4344	.3982	.4163
6		.7316	.7059	.6878	.6878
7		.7865	.8145	.7888	.7059
8		.6767		.7186	.6516
9	.6584	.5853	.5611	.6135	.6335
10	.4572	.543	.4706	.4557	.543
11	.4755	.4706	.3982	.3982	.4706
12	.4572	.4344	.3439	.3439	.362
13	.3658	.3475	.3258	.3439	.2896
14	.3658	.3475	.3077	.2896	.3439
15		.3292	.3439	.2896	.3258
16	.3841	.3475	.3439	.362	.3077
17	.439	.4024	.4525	.4163	.3982
18	.5853	.4887	.543	.5973	.5611
19	.6036	.5611	.5611	.6154	.6335
20	.5487	.5068	.5068	.5068	.543
21	.4572	.4525	.4119	.4706	.4525
22	.3841	.3841	.3801	.4344	.362
23	.3475	.3511	.3258	.3982	.3077
24		.2926	.2957	.2715	.362
Max	.6584	.7865	.8145	.7888	.7059
Min	.3475	.2743	.2715	.2715	.2534
Avg	.4664	.4452	.4235	.4415	.4374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 202 / RAPDRP POWER HOUSE SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4755	.4887	.4525	.4525
2		.4938	.4706	.4525	.4525
3		.4938	.4706	.4706	.5068
4		.5487	.543	.5792	.543
5		.7499	.6878	.6485	.6697
6		1.0242	1.0679	.929	.9774
7		1.2254	1.1584	1.1765	1.2308
8		1.3169	1.3575	1.2445	1.3394
9	1.1888	1.1145	1.1403	1.1393	1.2308
10	.9877	1.0288	.9955	.9816	.9774
11	.9877	.9114	.8869	.905	.8688
12	.9145	.8413	.7964	.8326	.8145
13	.823	.7888	.724	.7602	.724
14	.6767	.6697	.6516	.724	.6697
15	.6036	.5973	.6878	.6335	.6154
16	.6401	.6335	.6878	.724	.6154
17	.8048	.6697	.8145	.7964	.8145
18	1.134	.5792	1.0679	.7602	1.0498
19	1.134	.6697	1.267	1.1222	1.2308
20	1.0974	.929	1.1403	1.1041	1.086
21	.8779	.8063	.8145	.905	.905
22	.695	.724	.6516	.5792	.724
23	.5487	.5611	.543	.543	.543
24		.5121	.499	.4525	.5068
Max	1.1888	1.3169	1.3575	1.2445	1.3394
Min	.5487	.4755	.4706	.4525	.4525
Avg	.8743	.7652	.8172	.7882	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 004709 / 132 KV WALUJ MIDC SUB- ST

Feeder No / Name : 401 / 33 KV COLGATE

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	20-DEC-17
HR	Load (MW)
8	10.8539
9	10.8025
10	10.8025
11	10.8025
12	8.7449
13	8.7449
Max	10.8539
Min	8.7449
Avg	10.1252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11 KV JAMGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5487	.5316	.5335
2		.6478	.5144	.6173	.6097
3		.724	.6516	.6516	.6478
4		.8002	.8745	.703	.724
5		.8764	.9945	.7545	.7621
6		.9526	.8745	.8402	.9526
7		1.0479	.8745	.9774	1.0669
8		1.4098	1.2346	1.1317	1.3336
9			1.2689	1.3203	1.3032
10		.0343	.0377	.0377	.0543
11			.0362	.0377	.0377
12	1.086		.0377	.0189	.0566
13			.0377	.0189	.0566
14			.0377	.0189	.0377
15			.0189	.0189	.0377
16				.0362	.0543
17				.0381	
18					.0343
19				.0572	.0343
20					.0514
22		.0343			.0343
23				.0381	.0343
24		.5335	.5144	.4287	.4954
Max	1.086	1.4098	1.2689	1.3203	1.3336
Min	1.086	.0343	.0189	.0189	.0343
Avg	1.086	.6939	.5348	.4138	.4069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11 KV MANJARI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1029	
2			.1029	
3	.0762		.1029	.0762
4			.1029	
5			.12	.1143
6			.12	
7	.1524		.12	.1524
8	.0953		.1372	.1524
9		.1132	.0943	.0943
10	.0343	.1132	.0754	.0377
11	1.7147	2.3167	2.2805	2.2443
12	1.9033	2.6787	2.4796	2.5339
13	2.2634	2.6425	2.6787	2.5034
14		2.552	2.3577	1.6108
15		2.5701	2.4253	2.0995
16		2.4977	2.4072	2.0814
17			2.553	2.1357
18	.0171		2.1529	1.7661
19			.1334	.0686
20	.0514			.0857
21	.1029		.1143	.1029
22	.1029			.1029
23	.0857		.1143	.1029
24	.0953	.0686	.1029	.0953
Max	2.2634	2.6787	2.6787	2.5339
Min	.0171	.0686	.0754	.0377
Avg	.5150	1.7281	.9490	.9080



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11 KV MALUNJA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	.6516	1.0288	.9907
2	1.4098	.6859	1.0802	1.0669
3	1.5623	.703	1.2003	1.1431
4	1.7147	.703	1.3375	1.2193
5	1.7909	.6516	1.5261	1.2955
6	1.9052	.703	1.5261	1.5242
7	1.9814	.823	1.989	1.7147
8	2.21	.6344	2.1434	2.0195
9		.6878	2.0405	1.8099
10	.1029	.1132	.132	
11	.0857	.0754		
12			.0943	.1886
13			.0754	.1886
14			.0754	.1509
15			.0754	
16			.0754	
17	.1372		.0953	.2172
18			.1334	.2058
19			.1524	.2058
20	.0857		.0953	.2058
21	.1372		.1524	
22	.1372			.2058
23			.1143	1.166
24	1.1431	.8573	.9431	.9526
Max	2.21	.8573	2.1434	2.0195
Min	.0857	.0754	.0754	.1509
Avg	1.0428	.6074	.7312	.8669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / TOWN I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.5144	.543	.6478
2		.8002	.5316	.679	.724
3		.9526	.4801	.7602	.7621
4		1.0669	.5316	.7716	.8383
5		1.1431	.6344	.8916	.9526
6		1.2574	.823	1.2517	1.2765
7		1.4861	1.046	1.4746	1.6385
8		1.6004	1.406	1.4575	1.5813
9		1.3032	1.267	1.3756	1.3032
10		.9945	.9593	1.1584	1.1222
11		.9774	1.0498	.8688	
12		.8745	.9593	.7964	.9412
13		.7202	.8326	.8326	.8507
14		.6859	.724	.724	.724
15		.6001	.724	.6516	.6878
16		.823	.724	.6878	.7602
17		.823		.9145	.9412
18		.9088		1.1431	1.166
19		1.046		1.3908	.9774
20		.9945		1.1812	.703
21		.823		.9526	.8059
22		.6516		.8002	.6516
23	.7049	.583		.6478	.6001
24		.6287	.5144	.463	.5906
Max	.7049	1.6004	1.406	1.4746	1.6385
Min	.7049	.583	.4801	.463	.5906
Avg	.7049	.9362	.8071	.9341	.9237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 205 / TOWN II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3086	.3086	.3429
2	.4954	.3086	.3086	.381
3	.5716	.3258	.3429	.381
4	.6478	.2572	.3601	.4191
5	.7621		.4115	.4572
6	.8383	.703	.6344	.724
7	.9145	.7202	.823	.9907
8	.8954	.8402	.7716	.9907
9	.7202	.8145	.7059	.8507
10	.6001	.7059	.6154	.7059
11	.5658	.6335	.5792	.6335
12	.5316	.5611	.5792	.5068
13	.4458	.5249	.4706	.5068
14	.4801	.4163	.3982	.3982
15	.3944	.3982	.3982	.4163
16	.3944	.4887	.4525	.4525
17	.4458		.5335	.5249
18	.6516		.6859	.6001
19	.5316		.7621	.6173
20	.5144		.6668	.5316
21	.463		.5335	.4973
22	.3601		.4382	.3601
23	.3258		.3239	.3258
24	.3429	.2743	.2915	.3048
Max	.9145	.8402	.823	.9907
Min	.3258	.2572	.2915	.3048
Avg	.5531	.5176	.5165	.5383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 206 / TOWN III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1629	.1715	.1905
2	.1334	.1629	.2229	.1524
3	.2286	.1991	.2572	.1905
4	.2667	.2896	.2743	.2477
5	.3429	.2715	.2915	.3239
6	.4572	.3395	.3601	.4191
7	.5335	.3584	.463	.5144
8	.5144	.4527	.4115	.4572
9	.3772	.3801	.3801	.4344
10	.3772	.2896	.362	.2896
11	.2743	.2896	.2715	.2353
12		.2715	.2896	.2353
13	.2572	.2534	.2353	.2172
14	.1886	.2353	.2534	.2172
15	.3258	.2715	.2534	.2172
16	.2915	.2715	.2896	.2896
17	.2743		.2667	.3077
18	.3772		.4191	.3086
19	.3429		.4191	
20	.3086		.3429	
21	.2572		.2858	.2229
22	.1715		.2286	.1715
23	.1715		.1905	.1543
24	.1715	.1698	.1715	.1905
Max	.5335	.4527	.463	.5144
Min	.1334	.1629	.1715	.1524
Avg	.2946	.2746	.2963	.2721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 207 / 11 KV WARKHED FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.4575	1.4118	1.2308	1.3375
12	1.5261	1.448	1.3756	1.5089
13	1.5432	1.448		1.5089
14	1.5604	1.3756	1.5023	1.5775
15	1.6118	1.6651	1.4842	1.5604
16	1.6461	1.5565	1.5927	1.5432
17	1.6804		2.1338	1.2308
18			1.3717	.8916
Max	1.6804	1.6651	2.1338	1.5775
Min	1.4575	1.3756	1.2308	.8916
Avg	1.5751	1.4842	1.5273	1.3949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 208 / 11 kv NAWABPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.3772	.3601	.4954
2	.6478	.3601	.4115	.6097
3	.9145	.3772	.6344	.7621
4	1.0479	.3772	.703	.8573
5	1.1431		.9774	
6	1.2765		1.2346	
7	1.4289		1.286	
8			1.1488	
9			.905	
10	.6859		.724	
11	.4287	.3982		
12			.362	.3801
13		.4525		.3258
14			.2715	.2896
15			.3258	
16		.5068	.3801	
17			.5716	.5792
18			.8383	.7888
19	.703		1.3717	.5316
20	.823		1.0669	.6516
21	.6687		.6859	.4287
22	.5144		.6097	
23	.4287		.381	.3601
24	.381	.3772	.3429	.381
Max	1.4289	.5068	1.3717	.8573
Min	.381	.3601	.2715	.2896
Avg	.7725	.4033	.7087	.5315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 209 / 11KV NEW INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1715	.1372	.1143
2	.2286	.0905	.1372	.1524
3	.1905	.181	.2572	.1905
4	.1524	.1991	.2572	.2286
5	.1334	.1629	.2572	.2667
6	.2286	.1991	.2572	.2286
7	.2858	.181	.2572	.2667
8	.2286	.2353	.1886	.2286
9	.1715	.3439	.2715	.362
10	.2229	.362	.362	.362
11	.2743	.3439	.2896	.181
12	.2572	.2715	.2896	.181
13	.2058	.2172	.2353	.1629
14	.1715	.2534	.1629	.1629
15	.1715	.2534	.1448	.1629
16	.1029	.1448	.1629	.2715
17	.0857		.1905	.181
18	.0857		.1905	.1372
19	.0686		.1905	.1543
20	.0857		.1334	.1715
21	.1372		.1715	.1372
22	.1372		.1334	.1372
23	.1372		.1334	.1372
24	.1715		.1372	.1524
Max	.2858	.362	.362	.362
Min	.0686	.0905	.1334	.1143
Avg	.1679	.2257	.2062	.1971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 201 / 11KV TURKABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1463	.4572		
2		.1311	.4572		
3		.1638	.5335		
4		.1829	.5716		
5		.1638	.6097		
6		.2195	.583		
7		.2561	.6173		
8		.2294	.7888		
9		.2561	.8764		1.0974
10		.2667	.0732	.1619	
11		.2286	.0732	.1966	
12				.1943	.0983
13		.2286		.1966	.0983
14		.2286	.0655	.1966	.0655
15			.0549	.1638	.0655
16		.1905	.0732	.1619	.0655
17		.2286	.0655	.1696	.0655
18		.2667		.1696	.0655
19	.1865	.2667		.1696	.0914
20	.1966	.2286		.1638	
21	.1638	.2286		.1638	
22	.1619	.1905		.1638	
23	.1696	.1905		.1638	
24		.1311	.4191		
Max	.1966	.2667	.8764	.1966	1.0974
Min	.1619	.1311	.0549	.1619	.0655
Avg	.1757	.2102	.3950	.1740	.1903



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 202 / 11 KV SHIVRAI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0655	.1905		
2		.0655	.1905		
3		.0732	.1905		
4		.0819	.1905		
5		.0819	.2286		
6		.0655	.2667		
7		.0655	.2667		
8		.0655	.2286		
9		.0655	.2096		.0983
10		.0762	.0983	.0838	.0983
11		1.5775	1.7375	1.5384	1.4632
12		1.6118		1.5546	1.4632
13		1.6289	1.6461	1.5384	1.5181
14		1.6804	1.829	1.5074	1.5181
15		1.5775	1.8839	1.4413	1.5364
16		1.5432	1.829	1.4083	1.5729
17		1.1317	1.7193	1.2955	1.5729
18	.0335	1.2517	1.5729	1.1797	1.1797
19	.0486	.2096		.0848	.0655
20	.0486	.2096		.0819	
21	.0486	.2096		.0819	
22	.0486	.1905		.0819	
23	.0655	.1905		.081	
24		.0655	.1905		
Max	.0655	1.6804	1.8839	1.5546	1.5729
Min	.0335	.0655	.0983	.081	.0655
Avg	.0489	.5743	.8038	.8542	1.0988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 203 / 11 KV DAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2195	.1905		
2		.2195	.1905		
3		.1966	.1905		
4		.1638	.1905		
5		.2195	.2286		
6		.2378	.2667		
7		.2195	.2667		
8		.2195	.2286		
9		.1966	.1334		.1966
10		.2286	.128	.1696	.1966
11		.6859		.6783	.695
12		.703	.5853	.6554	.7316
13		.7202	.7133	.7042	.8048
14		.7545	.9145	.6706	.8413
15		.7202	.9145	.6962	.8413
16		.6859	.9145	.763	.6584
17		.6135	.8962	.7373	.6584
18		.6154	.4572	.7537	.1311
19	.0838	.1905		.0678	.1311
20	.0819	.1905		.0655	
21	.0655	.1905		.0671	
22	.0648	.1905		.0848	
23	.0655	.1905		.0848	
24		.1638	.1905		
Max	.0838	.7545	.9145	.763	.8413
Min	.0648	.1638	.128	.0655	.1311
Avg	.0723	.3640	.4222	.4427	.5351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 204 / 11 KV MANGEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6584	.7621		
2		.695	.8002		
3		.695	.8002		
4		.8779	.8002		
5		1.0242	.7888		
6		1.2803	.823		
7		1.4266	.9602		
8		1.2437	1.2517		
9		1.3535	1.3032		1.4632
10		.0381	.0328	.0162	.0164
11		.0191	.0492	.0162	.0164
12		.0191	.0164	.0164	.0164
13		.0191	.0164	.0162	.0164
14		.0191	.0164	.0162	.0164
15		.0191	.0164	.0162	.0164
16		.0191	.0164	.0164	.0164
17		.0572	.0164	.017	.0164
18		.0572	.0164	.0164	.0164
19	.0164	.0762		.0164	.0164
20	.0164	.0762		.0164	
21	.0164	.0572		.017	
22	.0328	.0572		.0164	
23	.0328	.0572		.0164	
24		.5121	.724		
Max	.0328	1.4266	1.3032	.017	1.4632
Min	.0164	.0191	.0164	.0162	.0164
Avg	.0230	.4316	.4848	.0164	.1479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 205 / 11 kv DAHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6584	.5335		
2		.7316	.5335		
3		.7682	.6097		
4		.9694	1.0288		
5		1.2071	1.2765		
6		1.4266	1.6289		
7		1.6461	1.5775		
8		1.7193	1.5604		
9		1.4632	1.2346		1.2803
10		1.0669	1.1523		1.0242
11		.7621	.7499		.695
12		.6287	.5487		.6584
13		.6287	.5304	.7373	.5853
14		.4191	.5853	.7773	.5487
15		.4191	.5853	.6882	.4424
16		.4763	.8413	.6554	.6584
17		.9907	.9145	.9339	.8596
18		1.448	1.3352	1.1191	1.39
19	1.278	1.3908		1.2146	1.6827
20	1.3435	1.0669		1.1469	
21	1.3108	.8002		1.0526	
22	1.1469	.6478		1.0174	
23	1.0159	.5716		.9339	
24		.5853	.5335		
Max	1.3435	1.7193	1.6289	1.2146	1.6827
Min	1.0159	.4191	.5304	.6554	.4424
Avg	1.2190	.9372	.9347	.9342	.8932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 206 / 11 KV TURKABAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6584	.5335		
2		.695	.5335		
3		.8413	.6097		
4		1.0242	.6478		
5		1.4266			
6		1.6461	1.7528		
7			1.8861		
8		1.6827	1.6575		
9		1.4266	1.3717		1.3352
10	.8478	.9145	1.1523	1.065	1.0974
11	.6882	.6097	.7682		
12	.4752		.5487		
13	.4915	.4763		.763	.4755
14	.5243	.6097	.4755	.7701	.4755
15	.5898		.439	.6706	.4207
16	.5735	.5716	.695	.6104	.6584
17	.6882	.8764	.8413	.7373	.8779
18	1.065	1.3717		.9555	1.3169
19	1.278	1.5242		1.2616	1.701
20	1.3927	1.0288		1.1797	
21	1.3565	.5716		1.1012	
22	1.166	.5716		.9831	
23	.9831	.5716		.9012	
24		.6584	.5335		
Max	1.3927	1.6827	1.8861	1.2616	1.701
Min	.4752	.4763	.439	.6104	.4207
Avg	.8657	.9408	.9029	.9166	.9287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 207 / 11 KV YESGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0328	.0191		
2		.0328	.0191		
3			.0191		
4		.0328	.0191		
5		.0328	.0191		
6		.0328	.0191		
7		.0328	.0191		
8			.0191		
9		.0328	.0191		
10		.0572	.0164		
11		.5487	.695		
12			.7316		
13		.5658	.8779	.9326	1.0608
14		.5487	.8779	.9831	1.2803
15		.5487	.8596	1.0526	1.3169
16			.7316	1.1361	1.2437
17		.3772	.567	.9717	1.1523
18		.543		.8421	.8356
19	.017	.0191		.0324	.0177
20	.0164	.0191		.0328	
21	.0164	.0191		.0339	
22	.0164	.0191		.0328	
23	.0164	.0191		.0328	
24		.0328	.0191		
Max	.017	.5658	.8779	1.1361	1.3169
Min	.0164	.0191	.0164	.0324	.0177
Avg	.0165	.1774	.3082	.5530	.9868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 208 / 11KV ARYANSH IND FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5898	.3429		
2		.7133	.3429		
3		.6584	.3429		
4		.5853	.3429		
5		.7316	.3429		
6		.7682	.362		
7		.8413	.724		
8		.6584	.743		
9		.9511	.9526		.8413
10		.9526	.7316	.7545	.9145
11		.9526	.3292	.7373	1.2803
12		.9335		.788	.8859
13		.9145		.7459	.9511
14		.9145	.3658	.7122	1.0974
15		.9145	.3658	.6554	1.3169
16		.9335	.3658	.6783	.7316
17		.9526	.3292	.6554	.8779
18		.8002	.3292	.6371	.7316
19	.7373	.362		.6154	.7865
20	.7209	.3429		.6226	
21	.7122	.3429		.6783	
22	.6882	.3429		.6554	
23	.6554	.3429		.6718	
24		.5853	.3429		
Max	.7373	.9526	.9526	.788	1.3169
Min	.6554	.3429	.3292	.6154	.7316
Avg	.7028	.7119	.4503	.6863	.9468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 209 / SAVERA IND FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	.9526		
2		.9511	.9526		
3			.9526		
4		1.0242	.9335		
5		1.0974	.9907		
6		.9511	.9717		
7		.8413	.9717		
8		.9511	1.0479		
9		1.1706	1.1622		1.0974
10		1.2193	1.0974	.8907	1.134
11		1.2193	1.2437	.852	1.1888
12		1.2003		.852	1.1888
13		1.2003		.8478	1.1706
14		1.2003	.9877	.8139	1.2803
15		1.1812	.9877	.9835	1.3169
16		1.1622	1.0974	.9831	1.0974
17		1.1622	1.0974	.9835	1.2071
18		1.1622	.9145	.9326	1.2071
19	.7701	1.1431		.9326	1.0974
20	.7449	1.1431		.852	
21	.78	1.1622		.8817	
22	.763	1.1241		.8192	
23	.6882	1.105		.7865	
24		.9511	1.0479		
Max	.78	1.2193	1.2437	.9835	1.3169
Min	.6882	.8413	.9145	.7865	1.0974
Avg	.7492	1.1052	1.0241	.8865	1.1805



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 201 / 11 KV SHENDURWADA 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.8488	.6602	.6413
2		.7545	.8488	.6602	.7545
3		.8488	.9431	.6602	.8488
4		.9431	1.1317	1.0269	.9335
5		1.1317	1.3203	1.4563	1.0269
6		1.4937	1.5089	1.4937	1.4377
7		1.5089	1.5089	1.5364	1.587
8		1.4335	1.4146	1.307	1.4003
9		.9431	.9431	.9431	1.1883
10		.7733	.7545	.6602	.9054
11	1.6289	.7545	.7167	.5658	.6036
12	1.5565		.7545	.5093	.5281
13	1.5203		.7922	.4715	.4338
14	1.448	.6602	.811	.4715	.415
15	1.448	.6602	.7922	.4904	.3772
16	1.448	.6602	.811	.547	.415
17	.9431	1.7013	1.6651	1.6301	1.6118
18	.9431	1.7372	1.6832	1.7318	1.6834
19	1.1317	1.7372	1.5947	1.7353	1.6118
20	1.1203	1.6289	1.5947	1.5415	1.5061
21	.9431	1.448	1.4327	1.3969	1.4685
22	.9431	1.2851	1.3432	1.3432	1.379
23	.8488	1.267	1.1641	1.2536	1.3032
24		.7545	1.1765	1.0745	1.2178
Max	1.6289	1.7372	1.6832	1.7353	1.6834
Min	.8488	.6602	.7167	.4715	.3772
Avg	1.2248	1.1309	1.1481	1.0486	1.0533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 202 / 11 KV SAWAKHEDA 1 SINGLE PHASING  
 PHASHING Feeder KV- 11 /  
 OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.2263	.1886	.1886
2		.1886	.2263	.1886	.1886
3		.1886	.2263	.1886	.1886
4		.1886	.2263	.1886	.1886
5		.2829	.2829	.1886	.2263
6		.2829	.3395	.1886	.2263
7		.2829	.2829	.1829	.2263
8		.2829	.2829	.2263	.2452
9		.2829	.2263	.2263	.2641
10		.1886	.1886	.2075	.2263
11	.9955	.1886	.1886	.1886	.2075
12	.9955	.1886	.1886	.1886	.2829
13	1.086	.1886	.1886	.1509	.2829
14	1.0498	.1886	.1886	.1509	.2263
15	1.086	.1886	.1886	.1132	.1886
16	1.086	.1509	.1886	.1132	
17	.1886	1.086	.8954	1.0745	1.0745
18	.2829	1.0498	1.0387	1.1517	1.1462
19	.2829	1.0498	1.0631	1.2048	1.1222
20	.2829	1.0317	1.1641	1.2226	1.086
21	.2829	1.0317	1.0985	1.2536	1.086
22	.1886	1.0317	.8954	1.1641	1.0679
23	.1886	.9955	.8954	1.1283	1.0679
24		.1886	.9955	.8954	.985
Max	1.086	1.086	1.1641	1.2536	1.1462
Min	.1886	.1509	.1886	.1132	.1886
Avg	.6151	.4548	.4869	.4990	.5214

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 203 / 11 KV MAHALAXMIKHEDA(LIS- SINGLE PHASING

I) 1 Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7194	1.8099	1.1641	1.2178
2		1.7194	1.8099	1.1641	1.5061
3		1.7194	1.9909	1.1641	1.6651
4		1.7909	1.97	1.5947	1.7147
5		2.0595	2.1262	2.191	1.8861
6		2.1262	2.3034	2.2786	2.1704
7		2.2386	2.4006	2.6292	2.4756
8		2.3034	2.4006	2.5206	2.431
9			2.2177	2.4025	
10			1.848	1.4937	2.1879
11	1.3203	.9431	.9054	1.1203	1.6032
12		.7545	.8488	.8488	.9431
13	.8488	.7545	.8488	.7545	.8865
14	.9431	.7545	.8488	.6602	.9431
15	.9431	.7545	.7922	.679	.9997
16	1.0374	.8488	1.0374	.9808	1.0751
17	2.3034	1.1317	1.1317	1.3817	1.8861
18	2.4539	1.6975	1.226	2.2361	2.3011
19	2.3034	2.2405	1.848	2.5688	2.452
20	2.1491	1.6975	2.2177	2.5873	1.8861
21	1.8099	1.3203	2.1253	1.6991	1.5089
22	1.8099	1.094	1.4937	1.4003	1.1317
23	1.7194	1.094	1.4003	1.307	1.0374
24		1.7194	1.0562	2.1253	.9619
Max	2.4539	2.3034	2.4006	2.6292	2.4756
Min	.8488	.7545	.7922	.6602	.8865
Avg	1.6368	1.4764	1.6107	1.6230	1.6031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 204 / 11KV MUKTESHWAR HT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747	.0566	.0566	.0566
2		.0747	.0566	.0566	.0566
3		.0747	.0566	.0566	.0754
4		.0747	.0566	.0566	.0754
5		.0747	.0747	.0754	.0754
6		.0747	.0747	.0943	.0754
7		.0747	.0754	.0724	.0754
8		.0747	.0747	.0754	
9		.0924	.0754	.0754	.0943
10		.0924	.0754	.0754	.0943
11	.1307	.0924	.0754	.0943	.1886
12	.1509	.0924	.1132	.112	.1132
13	.1478	.0924	.1132	.0943	.1132
14	.1294	.0747	.1132	.0943	.1132
15	.1307	.0747	.0943	.0943	.1132
16	.1307	.0747	.0754	.0943	.1132
17	.112	.0747	.0754	.112	.0943
18	.0934	.0747	.0754	.1307	.0754
19	.0934	.0747	.0754	.0943	.0754
20	.0934	.0747	.0566	.0754	.0754
21	.0747	.0747	.0566	.0754	.0566
22	.0747	.0747	.0566	.0754	.0566
23	.0747	.0747	.0566	.0566	.0566
24		.0754	.0754	.0566	.0566
Max	.1509	.0924	.1132	.1307	.1886
Min	.0747	.0747	.0566	.0566	.0566
Avg	.1105	.0784	.0746	.0814	.0861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 205 / 11KV LIS II 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4118	1.3937	1.4175	1.1104
2		1.3756	1.3937		1.1641
3		1.3937	1.379		1.1641
4		1.3937	1.379		1.2536
5		1.3937	1.379		1.2894
6		1.3937	1.4175		1.3253
7		1.3937	1.448	1.448	1.382
8		1.4118	1.4352		1.3289
9		.1509	.1698	.2263	.2263
10		.1509	.1698	.2075	.2452
11	.132	.132	.1509	.1886	.1886
12	.132	.132	.1509	.132	.132
13	.132	.132	.1509	.0943	.0943
14	.1132	.132	.1509	.0943	.0943
15	.1132	.132	.0943	.0943	.0943
16	.1132	.1698	.0943	.0943	.0943
17	1.448	.1886	.0943	.1132	.2195
18	1.448	.2829	.0943	.2452	.2829
19	1.4842	.3772	.0943	.3361	.2263
20	1.448	.2829	.1509	.2614	.1829
21	1.4118	.1886	.1886	.2263	.1509
22	1.4118	.1698	.1886	.1886	.1509
23	1.4118	.1698	.1886	.0943	.132
24		1.4118	.1698	.1698	.0943
Max	1.4842	1.4118	1.448	1.448	1.382
Min	.1132	.132	.0943	.0943	.0943
Avg	.8307	.6405	.5636	.3129	.5261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 206 / 11KV GURUDHANORA 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2829	.1886	.1886	.1698
2		.2829	.1886	.1886	.1886
3		.2829	.2829	.1886	.2829
4		.3772	.3772	.6602	.4715
5		.6602	.5658	.7468	.8488
6		.8488	.8488	.8402	.9709
7		.8488	.9431	.9145	.9522
8		.7545	.7545	1.4175	.8676
9		1.5384	1.5947	1.5061	1.379
10		1.647	1.6651	1.5061	1.3998
11	.2263	1.647	1.7337	1.5592	1.4175
12	.1886	1.6297	1.7337	1.5775	
13	.1886	1.6297	1.6832	1.6126	
14	.1509	1.6655	1.6832	1.5775	1.448
15	.1509	1.6289	1.5947	1.5775	1.4327
16	.1509	1.5384	1.5947	1.4148	1.4685
17	.1886	.2829	.6535	.2263	.2263
18	.2263	.5658	.6535	.5601	.2829
19	.2829	.7545	.5601	.8589	.2829
20	.3395	.5658	.3772	.5601	
21	.3772	.3772	.2829	.4481	.2263
22	.2829	.2452	.2829	.3395	.2075
23	.2829	.1886	.2829	.1698	.1886
24		.2829	.1886	.2452	.1509
Max	.3772	1.6655	1.7337	1.6126	1.4685
Min	.1509	.1886	.1886	.1698	.1509
Avg	.2336	.8552	.8631	.8702	.7078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 207 / 11 KV DHAMORI (BK) SINGLE PHASING  
 1PHASING Feeder KV- 11 /  
 OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0943	.1886	.1132
2		.0943	.0943	.1886	.1132
3		.1132	.0943	.1886	.132
4		.1509	.0943	.1886	.1886
5		.1509	.1132	.2241	.2263
6		.1886	.1132	.2241	.2829
7		.1886	.1132	.2926	.3018
8		.132	.1132	1.5061	.2829
9		1.086	1.4327	1.5415	1.4148
10		1.1765	1.5947	1.5775	1.3969
11		1.1765	1.5947	1.6297	1.2894
12		1.1222	1.4327	1.647	1.4327
13		1.1222	1.3432	1.2894	1.7718
14		1.1222	1.3432	1.3998	1.7718
15		1.1222	1.3432	1.4175	1.7541
16		1.1765	1.3432	1.4175	1.7718
17			.2241	.132	
18	.3018	.1509	.1886	.1698	
19	.3018	.2641	.1886	.1886	.2263
20	.2452	.1886	.1886	.2263	.1886
21	.1132	.1509	.1509	.2263	.1509
22	.1132	.132	.1509	.1698	.1509
23	.1132	.0943	.1509	.132	.1509
24		.0943	.0943	.1509	.1132
Max	.3018	1.1765	1.5947	1.647	1.7718
Min	.1132	.0943	.0943	.132	.1132
Avg	.1981	.4910	.5664	.6799	.6920

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 201 / 11 KV SAWANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1431	.8383
2			1.3336	.7468
3			1.5242	.8215
4			1.7147	.9145
5			1.8099	1.0288
6		1.5242	1.9052	1.2346
7			1.9433	1.2209
8	1.1431		1.8861	1.1603
9			1.829	1.0486
10	.9526	.8573	1.2574	1.0669
11		.9526	1.0669	
12		1.0479	.8764	
13		.9907	.8764	
14		1.0479	.8383	
15		1.1431	.8299	
16		1.2384		
17		1.2384	.9526	
18		1.3336	1.3336	
19		1.5242	1.2574	1.2384
20		1.6194	1.0669	
21		1.4861	.9526	
22		1.3336	.9526	
23		1.1431	.8383	
24	.8002	.7621	.9526	.8383
Max	1.1431	1.6194	1.9433	1.2384
Min	.8002	.7621	.8299	.7468
Avg	.9653	1.2027	1.267	1.0132



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 202 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.4854
2			.5716	.5228
3			.6668	.5544
4			.7621	.6584
5			.8573	.905
6		.9526	.9526	.905
7			1.1812	1.0136
8	1.1431		1.0669	1.086
9			1.0288	1.0029
10	.9526	.9526	.8779	.8596
11		.7621	.6516	
12		.7621	.6154	
13		.6478	.6154	
14		.6478	.6154	
15		.7621	.6447	
16		.7811	.724	
17		.8002	.8688	
18		1.1431	.9511	
19		1.0479	1.0242	1.086
20		.9526	.8779	
21		.8383	.7468	
22		.6859	.6722	
23		.5716	.5601	
24	.7621	.6859	.5335	.4854
Max	1.1431	1.1431	1.1812	1.086
Min	.7621	.5716	.5144	.4854
Avg	.9526	.8121	.7742	.7970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 203 / 11 KV RAIPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6668	.3048
2			.7621	.381
3			.905	.5731
4			1.0456	.6173
5			.9496	.8573
6		.4763	1.0174	.9496
7			1.0486	.9496
8	.743		1.3108	1.0486
9			1.3904	1.1469
10		.381	.6478	
11			.1524	
13			.1524	
14			.1143	
15		.3048	.1143	
16		.3239	.1524	
17		.3048	.1905	
18		.4191	.381	
19		.7621	.7621	.4763
20		.6859	.6859	
21		.5335	.5716	
22		.4572	.4954	
23		.381	.4572	
24	.4572	.4763	.6668	
Max	.743	.7621	1.3904	1.1469
Min	.4572	.3048	.1143	.3048
Avg	.6001	.4588	.6365	.7305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 204 / 11 KV MALIWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5716	.6097
2			.6668	.6478
3			.7621	.6859
4			.8573	.9145
5			.9526	1.0562
6		1.5242	1.1431	1.5242
7			1.448	1.3717
8	1.3336		1.3336	1.1431
9			1.0669	.9907
10	.6478	.9526	.5068	.6097
11		.7049	.6401	
12		.6859	.6154	
13		.8383	.5761	
14		.7621	.5243	
15		.7049	.5506	
16		.6859	.5898	
17		.724	.6783	
18		.6859	.6173	
19		1.1431	1.0669	1.0288
20		1.0669	.9907	
21		.8764	.8764	
22		.6478	.8383	
23		.5335	.7621	
24	.6478	.6859	.4763	.679
Max	1.3336	1.5242	1.448	1.5242
Min	.6478	.5335	.4763	.6097
Avg	.8764	.8264	.7963	.9384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 206 / 11 kv GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572	.0381
2			.0572	.0381
3			.0572	.0381
4			.0572	.0381
5			.0572	.0572
6		.0572	.0572	.0572
7			.0572	.0572
8	.0572		.0572	.0572
9			.0572	.1463
10	.1715	.0572	.0572	.1372
11		.0572	.0549	.1905
12		.0572	.0572	.1905
13		.0572	.0572	.3048
14		.0572	.0572	.3048
15		1.5813	.0572	.3048
16		.0572	.0572	.3048
17		.0572	.0572	.3239
18		.0572	.0572	.381
19		.0572	.0572	.381
20		.0572	.0572	
21		.0572	.0572	
22		.0572	.0572	
23		.0572	.0381	
24	.0572	.0381	.0572	.0381
Max	.1715	1.5813	.0572	.381
Min	.0572	.0381	.0381	.0381
Avg	.0953	.1513	.0563	.1694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 201 / 11 KV SILLEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0476	.0953	.0953	.0953
2		.0476	.0953	.0953	.0953
3		.0476	.0953	.0953	.0953
4		.0953	.0953	.0953	.0953
5		.0953	.0953	.0953	.0953
6		.0953	.0953	.0953	.0953
7		.0953	.0953	.0953	.0953
8		.0953	.0953	.0953	.0953
9		.0476	.0476	.0476	.0476
10		.0476	.0476	.0476	.0476
11		1.4575	1.3717	.1905	1.2803
12		1.4575	1.5384	1.2003	1.2136
13		1.3717	1.3289	1.4575	***
14		1.3717	1.2803	1.3717	1.3289
15		1.3717	1.0974	1.3717	
16		1.3146	1.1888	1.3717	1.3289
17		1.286	1.2536	1.3717	1.4737
18		1.0745	1.2803	1.4022	.0953
19	.0476	.0953	.0953	.0953	.0953
20	.0476	.0953	.0953	.0953	.0953
21	.0476	.0953	.0953	.0953	.0953
22	.0476	.0953	.0953	.0953	.0953
23	.0476	.0476	.0953	.0953	.0953
24		.0476	.0953	.0953	.0953
Max	.0476	1.4575	1.5384	1.4575	13.2686
Min	.0476	.0476	.0476	.0476	.0476
Avg	.0476	.4957	.4904	.4653	.9312

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 202 / 11KV MALUNJA (BK) AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3391	.5601	.543	
2		.503	.5601	.5316	.6401
3		.5868	.6401	.6268	.7316
4		.7459	.8059	.7716	.985
5		.9221	.985	.964	1.1393
6		1.0059	1.2269	1.1269	1.3146
7		1.2717	1.3717	1.3717	1.5432
8		1.6108	1.4575	1.6766	1.8442
9		1.6108	1.6766	1.9938	2.0119
10		.0476	.0953	.0953	.0476
11		.0476	.0476	.0476	.0476
12		.0476	.0476	.0476	.0476
13		.0476	.0476	.0476	.0476
14		.0476	.0476	.0476	.0476
15		.0476	.0476	.0476	.0476
16		.0476	.0476	.0476	.0476
17		.0476		.0476	.0476
18		.0953	.0953	.0476	.0476
19	.0476	.0953	.0476	.0953	.0953
20	.0476	.0953	.0476	.0953	.0953
21	.0476	.0476	.0476	.0476	.0953
22	.0476	.0476	.0476	.0476	.0953
23	.0476	.0476	.0476	.0476	.0953
24		.2743	.5601	.5487	.5601
Max	.0476	1.6108	1.6766	1.9938	2.0119
Min	.0476	.0476	.0476	.0476	.0476
Avg	.0476	.4033	.4591	.4568	.5076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 203 / 11 KV GAJGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.3715	.3906	.2896
2		.3858	.3715	.3906	.2896
3		.4572	.3715	.3858	.3715
4		.5201	.4572	.381	.4458
5		.5944	.5335	.4572	.5335
6			.6401	.463	.6249
7			.7202	.602	.8002
8			.9831	.8173	1.1736
9			.9831	.9145	1.065
10			.0953	.0953	.0953
11			.0953	.0953	.0953
12			.0953	.0953	.0953
13			.0953	.0953	.0953
14			.0953	.0953	.0953
15			.0953	.0953	.0953
16		.0953	.0953	.0953	.0953
17		.0953	.0953	.0953	.0953
18		.1905	.0953	.0953	.0953
19	.0953	.1905	.1905	.1905	.1905
20	.0953	.1905	.1905	.1905	
21	.0953	.0953	.1905	.0953	.1905
22	.0953	.0953	.1905	.0953	.1905
23	.0953	.0953	.1905	.0953	.1905
24		.2286	.362	.3163	.2896
Max	.0953	.5944	.9831	.9145	1.1736
Min	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.2528	.3168	.2768	.3262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 204 / 11 KV KATEPIMPALGAON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.6687	.7621	.6687
2		.463	.743	.7716	.743
3		.6173	.7621	.8383	.7621
4		.8488	.8592	.9488	.9907
5		1.0402	1.0402	1.0669	1.1717
6		1.1145	1.3108	1.1288	1.4403
7		1.406	1.5565	1.4563	1.7204
8		1.7966	1.8842	1.829	2.13
9		1.7528	1.8842	1.7528	2.13
10		.1905	.1905	.0953	.1905
11			1.1717	.0953	.1905
12		.0953	.0953	.0953	.1905
13		.0953	.0953		.0953
14		.0953	.0953		.0953
15		.0953	.0953	.0953	.1905
16		.0953	.0953	.0953	.1905
17		.0953	.0953	.0953	.1905
18		.1905	.1905	.1905	.1905
19	.1905	.2858	.381	.2858	.2858
20	.1905	.2858	.381	.2858	.2858
21	.1905	.1905	.381	.2858	.2858
22	.1905	.1905	.381	.1905	.2858
23	.1905	.1905	.381	.2858	.2858
24		.2343	.6687	.6859	.6687
Max	.1905	1.7966	1.8842	1.829	2.13
Min	.1905	.0953	.0953	.0953	.0953
Avg	.1905	.5076	.6420	.6062	.6408



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 205 / 11 KV SHILLEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.4287		.4287
2		.5144	.6001	.7011	.5144
3		.763	.7164	1.1145	.7011
4		1.2717	1.1641	1.3717	1.1641
5		1.3413	1.587	1.5261	1.5546
6		1.6766	1.8861	1.6766	1.8861
7		1.829	1.8861	1.7604	2.0748
8		1.5432	1.7737	1.6108	1.8861
9		1.1869	1.4937	1.3717	1.4003
10		.823	.985	.985	1.0059
11		.6268	.5373	.6268	.6135
12		.5144	.5487	.5144	.543
13		.4287	.5487	.4287	.4572
14		.4287	.5487	.4287	.3582
15			.5544	.4287	
16		.5144	.5487	.5144	.5373
17		.7011		.6001	.6068
18		1.4003	1.3575	1.1888	.8764
19	1.0974	1.6804	1.5223	1.6804	1.4899
20	.9745	1.4003	1.2536	1.2803	.9145
21	.7716	.9145	1.0517	.8954	.8596
22	.6859	.7164	.823	.6135	.5316
23	.6201	.5258	.6468	.5144	.543
24		.5601	.4287	.4525	.4287
Max	1.0974	1.829	1.8861	1.7604	2.0748
Min	.6201	.4287	.4287	.4287	.3582
Avg	.8299	.9528	.9953	.9689	.9294

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 206 / 11 KV Shahapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.1429	.1429	.1429
2		.0953	.1429	.1429	.1429
3		.0953	.1429	.1429	.1429
4		.0953	.1429	.1429	.1429
5		.0953	.1429	.1429	.1429
6		.0953	.1905	.1905	.1905
7		.1905	.1905	.1429	.1905
8		.1429	.1905	.1429	.1429
9		.1429	.1429	.1429	.1429
10		.0953	.0953	.0953	.0953
11		.9431	.985	.8573	.8669
12		1.0288	.8859	.8573	.8859
13		1.0288	.9955	.7716	.8669
14		.9431	1.0745	.7716	.9745
15			1.0631	.6859	.8764
16		.8764	1.086	.9431	.8669
17		1.2003	.9431	.9431	1.0288
18		1.0517		.8764	1.1269
19	.0953	.1429	.1429	.1429	.1905
20	.0953	.1429	.1429	.1429	.1429
21	.0953	.2858	.1429	.1429	.1429
22	.0953	.1429	.1429	.1429	.1429
23	.0953	.1429	.1429	.1429	.1429
24		.0953	.1429	.1429	.1429
Max	.0953	1.2003	1.086	.9431	1.1269
Min	.0953	.0953	.0953	.0953	.0953
Avg	.0953	.3986	.4093	.3747	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 207 / 11 KV Wadali AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0476	.0476	.0476	.0476
2		.0953	.0476	.0476	.0476
3		.0953	.0476	.0476	.0476
4		.0953	.0476	.0476	.0476
5		.0953	.0953	.0476	.0953
6		.0953	.0953	.0953	.0953
7		.0953	.0953	.0953	.0953
8		.0953	.0953	.0953	.0953
9		.0476	.0476	.0476	.0476
10		.0476	.0476	.0476	.0476
11		.9431	1.1393	.8573	.7973
12		1.2003	.9145	.9431	.8859
13		1.2003	.924	1.0288	.964
14		1.286	.9955	1.0288	
15		1.1145	.9745	1.0288	
16		1.0288	.9145	1.1145	1.0631
17		1.286	.905	1.1145	1.0517
18		1.1393	.8954	.8764	1.0631
19	.0953	.0953	.0476	.0953	.0953
20	.0953	.0953	.0476	.0953	.0953
21	.0953	.0476	.0476	.0476	.0953
22	.0953	.0476	.0476	.0476	.0953
23	.0953	.0476	.0476	.0476	.0953
24		.0953	.0476	.0476	.0476
Max	.0953	1.286	1.1393	1.1145	1.0631
Min	.0953	.0476	.0476	.0476	.0476
Avg	.0953	.4349	.3590	.3747	.3189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 208 / 11 KV Katepimpalgaon  
Gaothan Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3696	.2572	.2801	.2572
2		.362	.2572	.3658	.2572
3		.4525	.4382	.4572	.4382
4		.6001	.5373	.8059	.6268
5		.763	.7316	.7888	.7316
6		.905	.9335	.9536	.9335
7		.8478	.9335	.8573	.9335
8		.6706	.8402	.8145	.8402
9		.6468	.6401	.724	.7468
10		.462	.4572	.4287	.4525
11			.2715	.1715	.2715
12		.1715	.2743	.1715	.2658
13		.1715	.2772		.2601
14		.1715	.1848		.3506
15		.1715	.1867	.1715	
16		.1715	.2801	.2572	.2743
17		.2572	.362	.2572	.3582
18		.7468	.724	.5487	.7888
19	.7716	.7468	.7316	.9335	.7973
20	.8859	.6401	.6335	.7468	.3734
21	.5144	.4477	.5258	.5373	.3734
22	.4525	.3582	.5316	.3506	.2772
23	.3391	.3506	.4525	.2572	.2772
24		.2743	.2572	.2801	.2572
Max	.8859	.905	.9335	.9536	.9335
Min	.3391	.1715	.1848	.1715	.2572
Avg	.5927	.4678	.4883	.5072	.4845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 201 / 11KV JAMGAON 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	1.166	.695	1.226
2	.9431	1.307	.9492	1.2826
3	.9945	1.3375	1.0277	1.2826
4	1.1831	1.5432	1.0277	1.2826
5	1.5089	1.9376	1.1145	1.3203
6	1.7147	1.8519	1.7147	1.4146
7	1.869	1.869	1.869	1.5278
8	1.8861	1.9033	2.0351	1.8107
9	1.989	1.9605	1.8671	1.6991
10	.9709	1.1389	1.1389	1.0082
11	.6535	.9709	.7842	.6722
12	.5601	.5601	.5601	.5415
13	.4481	.4481	.4854	.5601
14	.5041	.5228	.4715	.4481
15	.5415	.5601	.5041	.5228
16	.5788	.6535	.5975	.679
17	.9896	1.0829	.9149	.8865
18	1.6057	1.6991	1.4377	1.5278
19	1.8298	1.9978	2.0538	2.1313
20	1.6057	1.7924	1.6057	1.9605
21	1.3817	1.419	1.2136	1.3817
22	1.2696	1.251	1.0642	1.1694
23	1.1949	1.1016	1.0456	1.1317
24	.8573	1.1523	.695	1.2826
Max	1.989	1.9978	2.0538	2.1313
Min	.4481	.4481	.4715	.4481
Avg	1.1676	1.3011	1.1197	1.1979

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 202 / 11KV L.I.S. FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6602	.5281	.5601	.7545
2		.6516	.5487	.5601	.7545
3		.7167	.5373	.5853	.7922
4		.6859	.543	.695	.8676
5		.811	.6201	.7888	.9431
6		.811	.7373	.7716	.9431
7		.7888	.823	.7888	.9619
8		.8962	.8745	1.0829	.9808
9		1.1576	.8745	1.0642	1.1389
10		.2427	.1307		.168
11		.1867	.168	.1867	.2427
12		.1867	.168	.112	.2054
13		.1867	.1867	.112	.168
14		.1867	.1867	.1867	.168
15		.2241	.1867	.2241	.168
16		.2241	.2054	.2614	.2075
17	1.0117	.168	.2241	.2241	.2829
18		.2614	.2987		.3395
19		.2987	.2987	.2427	.3772
20		.2614	.2241	.1494	.3395
21		.1867	.168	.1494	.2829
22		.168	.1494	.1494	.2452
23		.1494	.1494	.1494	.1886
24		.6602	.5121	.5228	.6859
Max	1.0117	1.1576	.8745	1.0829	1.1389
Min	1.0117	.1494	.1307	.112	.168
Avg	1.0117	.4488	.3893	.4349	.5086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 203 / 11KV NEVARGAON 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.4668	.4854	.4904
2		.5093	.5041	.5601	.4904
3		.5093	.5041	.5601	.5281
4		.6602	.5601	.5975	.5281
5		.7733	.6535	.7095	.6602
6		.9054	.7282	.8402	1.1317
7				.9522	1.1883
8				.8775	.9431
9	1.419				.7842
10				.5228	.3361
11		1.363	1.4937	1.6244	1.4003
12		1.5684	1.5497	1.643	
13		1.6244	1.5684	1.6804	
14		1.5684	1.6057	1.643	1.4563
15		1.3889	1.643	1.6804	1.5123
16		1.406	1.6617	1.6991	1.4712
17		1.3717	1.3717	1.6461	1.4335
18		1.3203	1.3717	1.587	1.5278
19		.7373	1.1016	.9896	.9808
20		.6722		.8029	.9054
21		.6348	.7468	.6722	.7167
22		.5228	.5788	.5228	.5847
23		.4854	.5041	.4854	.5658
24		.4527	.4668	.4854	.4904
Max	1.419	1.6244	1.6617	1.6991	1.5278
Min	1.419	.4527	.4668	.4854	.3361
Avg	1.419	.9463	1.0042	1.0116	.9148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	15-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0566	.0934	.0373	.0377
2		.0943	.0934	.0373	.0943
3		.0377	.1494	.0373	.0943
4		.0377	.1494	.056	.0754
5		.0343	.056	.0373	.0377
6		.0377	.0373	.0373	.0377
7		.0566	.0373	.0747	.0377
8		.0373	.0373	.056	.0377
9		.112	.0373	.0373	.0373
10		.2054	.1494	.0934	.112
11		.112	.1494	.1494	.0373
12	.056	.1307	.0373	.1867	.0373
13		.1494	.112	.056	.0373
14		.0373	.0373	.056	.0373
15		.0747	.0373	.1307	.0373
16		.1307	.0373	.1307	.0377
17		.2427	.112	.1494	.1886
18		.0373	.0373	.056	.0377
19		.168	.0934	.0373	.0381
20		.1307	.112	.0373	.1509
21		.056	.1307	.0373	.1029
22		.056	.0373	.0373	.0943
23		.056	.0373	.0373	.1132
24		.0754	.0934	.0373	.0377
Max	.056	.2427	.1494	.1867	.1886
Min	.056	.0343	.0373	.0373	.0373
Avg	.056	.0903	.0793	.0684	.0662



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 205 / 11Kv KANADGAON 1PHASING SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2263	.2801	.2263
2	.2829	.2829	.2801	.2829
3	.2572	.2829	.3361	.3395
4	.3395	.4527	.4481	.3395
5	.4973	.6602	.5041	.4338
6	.7356	.7545	.6535	.7545
7	.9431	.9054	.7095	.8676
8	.8865	.8299	.7468	.8299
9		.6535	.6161	.7282
10		.3734		.3174
11	1.251	1.3717	1.4563	1.5123
12	1.3443	1.3203	1.5684	1.2883
13	1.448	1.3375	1.6991	1.6617
14	1.4003	1.3717	1.6991	1.6804
15	1.3546	1.3889	1.6244	1.6617
16	1.3375	1.3889	1.643	1.6827
17	1.406	1.3375	1.5261	1.8107
18	1.4232	1.4403		1.7737
19	.6348	.6535	.7282	.5847
20	.5228	.5041	.4481	.5281
21	.3361	.3921	.3547	.3772
22	.2987	.2614	.2427	.3018
23	.2987	.1867	.2241	.3018
24	.2452	.2241	.1867	.2263
Max	1.448	1.4403	1.6991	1.8107
Min	.2229	.1867	.1867	.2263
Avg	.7939	.7750	.8171	.8546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 206 / 11 KV NEW LIS SHANTAI

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.0943	.056	.0943
2	.3361	.0943	.056	.0943
3	.3395	.0953	.0934	.0943
4	.3258	.1132	.0934	.1132
5	.3086	.1132	.0747	.1132
6	.3086	.1132	.0747	.0943
7	.3361	.1132		.0943
8	.362	.1132	.112	.1143
9	.3547	.1307	.0934	.1494
10	.3547	.3734	.1307	.168
11	.3734	.3547	.112	.1307
12	.3734	.3361	.112	.3547
13	.3734	.2987	.112	.3734
14	.3547	.3174	.0934	
23	.0934		.0934	.132
24	.3395	.0934		.0943
Max	.3734	.3734	.1307	.3734
Min	.0934	.0934	.056	.0943
Avg	.3296	.1836	.0934	.1476

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 207 / 11KV BAGADI Ag 1-PHASING SINGLE PHASING  
FEEDER Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.2987	.2987	.3395
2	.3395	.2987	.3361	.3395
3	.3772	.3361	.3361	.3772
4	.3772	.3734	.3734	.4527
5	.6036	.4294	.4481	.5093
6	.6516	.5041	.7468	.7545
7	.703	.5041	.7842	.7545
8	.6687	.5601	.7282	.679
9	.5228		.5415	.5041
10	.3772			.5415
11	.7655	.7655	.7655	.9149
12	.7842	.8589	.7842	.9522
13	.8029	.8589	.8962	.9522
14	.7655	.8215	.7282	.9149
15	.7202	.7842	.8215	.7468
16	.7888	.7842	.8029	.8865
17	.8402	.823	.8402	1.0185
18	.7545	.583	.6001	.7545
19	.5975	.6722	.5788	.6036
20	.5228	.4854	.4854	.5281
21	.4294	.4108	.4481	.415
22	.3361	.3734	.3734	.3395
23	.3174	.2987	.3361	.3018
24	.3086	.2987	.2987	.3395
Max	.8402	.8589	.8962	1.0185
Min	.3086	.2987	.2987	.3018
Avg	.5706	.5510	.5805	.6217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 201 / 11 KV BHENDALA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0762	.0572
2	.0953	.0953	.0762	.0572
3	.0953	.0953	.0572	.0572
4	.0953	.0762	.0572	.0572
5	.0953	.0762	.0953	.0572
6	.0953	.0953	.0953	.0762
7	.0953	.0762	.0953	.0762
8	.0953	.0762	.0762	.0953
9	.0953	.0762	.0762	.0953
10	.0953	.0953	.0762	.0762
11	1.448	1.7147	1.9052	1.8099
12	1.7337	1.7718	1.9052	1.9052
13	1.6956	1.7909	1.9814	1.9052
14	1.7909	1.7718	2.0576	1.9052
15	1.6956	1.7909	2.0957	1.9052
16	1.7718	1.7718	2.0576	1.9052
17	1.6956	1.7909	1.9052	1.9052
18	1.4861	1.6004	1.8861	1.8099
19	.0762	.0381	.0191	.743
20	.0762	.0762	.0762	.8002
21	.0953	.0953	.0762	.0953
22	.0762	.0953	.0762	.0953
23	.0953	.0762	.0762	.0953
24	.0953	.0953	.0572	.0762
Max	1.7909	1.7909	2.0957	1.9052
Min	.0762	.0381	.0191	.0572
Avg	.6160	.6390	.7065	.7359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 202 / 11 DHOREGAON FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4382	.2096	.2286
2	.4191	.4382	.2286	.2286
3	.4191	.4382	.2667	.2667
4	.4191	.4001	.2667	.2667
5	.4763	.381	.362	.3048
6	.5335	.4191	.4572	.381
7	.5335	.4001	.4954	.4191
8	.5525	.4572	.5335	.4191
9	.5335	.381	.381	.3429
10	.5335	.3048	.3048	.2667
11	1.7528	1.9814	1.8671	
12	1.829	1.7147	1.9433	1.6194
13	2.0195	1.5432	2.0195	1.6385
14	1.5242	1.9433	2.1338	1.6385
15	1.9052	2.0767	2.21	1.7147
16	1.9052	1.9814	2.21	1.6194
17	1.9814	2.0005	2.1719	1.6194
18	1.6194	2.0576	1.5242	1.5242
19	.4572	.381	.381	.4191
20	.4572	.4572	.381	.5335
21	.4572	.381	.381	.381
22	.4763	.3429	.2667	.381
23	.4572	.3048	.2667	.381
24	.381	.4572	.2286	.2286
Max	2.0195	2.0767	2.21	1.7147
Min	.381	.3048	.2096	.2286
Avg	.9193	.9034	.8954	.7314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 203 / 11 KV AMALNER FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5144	.5335	.6097
2	.7621	.5144	.5906	.6097
3	.7621	.5716	.6097	.6478
4	.7621	.8002	.6859	.6859
5	.7621	.7621	.6668	.724
6	.7811	.7811	.7621	.7621
7	.8002	.8192	.7811	.8002
8	.8192	.8383	.8764	.8383
9	.8192	.7621	.8764	.8764
10	.0381	.0762	.0762	.0762
11	.0381		.0381	.0762
12	.0191		.0381	.0381
13	.0191		.0381	
14	.0191		.0381	.0381
15	.0191		.0381	.1143
16	.0381	.0381	.0381	.1143
17	.0191	.0572	.0762	.1143
18	.0381	.0762	.0572	.1143
19	.1143	.0762	.0762	.1143
20	.1334	.0953	.0762	.1143
21	.1334	.1143	.0762	.0953
22	.1143	.1143	.0762	.0953
23	.1334	.0953	.0762	.0953
24	.7621	.5335	.4572	.5716
Max	.8192	.8383	.8764	.8764
Min	.0191	.0381	.0381	.0381
Avg	.3612	.4021	.3191	.362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 204 / 11 KV GANESHWADI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.381	.2286	.2286
2	.2858	.381	.2667	.2667
3	.2858	.381	.3048	.2667
4	.4191	.4382	.4001	.3048
5	.8573	.6668	.5144	.4572
6	.9145	.8764	.743	.6859
7	.9145	.8954	.8192	.7621
8	.9526	.9335	.8383	.8573
9	.8764	.7049	.6097	.724
10	.6097	.5906	.5335	.5335
11	.4382	.4382	.3048	
12	.362	.381	.2667	.381
13	.3239	.3239	.2667	.2858
14	.2286	.2667	.2286	.2286
15	.2858	.2858	.1905	.2858
16	.3048	.3239	.2858	.2858
17	.5335		.4001	.4191
18	.5525	.6287	.6287	.724
19	.8192	.7811	.8002	.9335
20	.5906	.6478	.6859	.8002
21	.4191	.4572	.4001	.5716
22	.381	.3429	.3429	.381
23	.3429	.2286	.3048	.2477
24	.2858	.4001	.2477	.2667
Max	.9526	.9335	.8383	.9335
Min	.2286	.2286	.1905	.2286
Avg	.5112	.5111	.4422	.4738

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 205 / 11kv Kokan agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.4001	.4191
2	.4191	.381	.4191	.4191
3	.4191	.381	.4572	.4001
4	.4763	.381	.4572	.4001
5	.5335	.4763	.4954	.381
6	.5335	.4001	.4954	.4191
7	.5716	.381	.5144	.4191
8	.5716	.4001	.5525	.5144
9	.6097	.6859	.7621	.8764
10	.8002	1.2193	1.2384	1.2955
11	.9335	1.2003	1.2574	1.1241
12	.7811	1.5432	1.2955	1.1812
13	.9907	1.2193	1.2193	1.2574
14	.9717	.9717	1.1812	1.3527
15	1.0479	1.1241	.9526	1.1431
16	.743	1.1622	1.0479	1.0479
17	.6478	1.0288	1.2955	.8573
18	.8383	1.0479		.8573
19	.5335	.7811	.5335	.8002
20	.362	.5906	.5335	.7621
21	.3239	.5335	.4954	.4763
22	.362	.4954	.4954	.4001
23	.381	.4572	.381	.4001
24	.4191	.4001	.4001	.381
Max	1.0479	1.5432	1.2955	1.3527
Min	.3239	.381	.381	.381
Avg	.6121	.7351	.7339	.7327



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 206 / 11 KV GALNEEMB AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.6668	.5906	.5716
2	.9526	.6668	.6097	.6097
3	.9526	.6668	.6097	.6097
4	.9526	.6859	.6859	.6859
5	.9526	.724	.743	.6859
6	.9526	.6668	.7811	.724
7	.9526	.7049	.7621	.7621
8	.9526	.7621	.8002	.8002
9	.9907	.8192	.8192	.8764
10	.0381	.0191	.0381	.0381
11	.0381	.0191	.0191	.0191
12	.0191	.0191	.0191	.0381
13		.0191	.0191	.0381
14		.0191	.0191	.0381
15	.0191	.0191	.0191	.0381
16	.0191	.0191	.0191	.0381
17	.0191	.0191	.0191	.0381
18	.0191	.0191	.0191	.0381
19	.0191	.0191	.0381	.0381
20	.0191	.0191	.0381	.0381
21	.0191	.0191	.0381	.0953
22	.0191	.0191	.0191	.0953
23	.0191	.0191	.0191	.0381
24	.9526	.6478	.4001	.6097
Max	.9907	.8192	.8192	.8764
Min	.0191	.0191	.0191	.0191
Avg	.4469	.3033	.2977	.3152

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 207 / 11Kv Lakhmapur Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7621	.4191	.6097
2	.6097	.7621	.4572	.5716
3	.6097	.7621	.4954	.6287
4	.6097	.7621	.4954	.6287
5	.6668	.7621	.5335	.6478
6	.6668	.724	.5525	.6478
7	.6478	.6668	.6097	.6859
8		.5716	.6478	.6859
9	.6478	.4954	.6097	.7621
10	.0762	.0572	.0762	.1143
11	.0762		.0762	.0762
12	.0381		.0762	.0762
13	.0381		.0762	.0762
14	.0381		.0572	.0762
15	.0381		.0381	.0953
16	.0381	.0381	.0572	.1143
17	.0762		.0572	.0953
18	.0953	.0953	.0572	.0762
19	.1524	.0762	.0762	.0762
20	.1524	.1524	.0953	.0762
21	.1524	.1334	.0762	.1524
22	.1524	.1524	.0762	.1524
23	.1334	.1143	.0762	.1524
24	.6097	.5716	.4001	.4954
Max	.6668	.7621	.6478	.7621
Min	.0381	.0381	.0381	.0762
Avg	.3015	.4255	.2580	.3239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 208 / 11 kv MAUJABAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	1.1431				
10	1.1431				
11	1.1431		1.1241	1.1431	1.0288
12		1.1431	1.1431	1.1812	1.1431
13		1.3336	1.1622	1.2193	1.1431
14		1.467	1.2955	1.2574	1.1431
15		1.3336	1.3146	1.2765	1.1431
16		1.1812	1.2193	1.2765	1.1431
17		1.2003	1.1812	1.2003	1.1431
18		1.1241	1.1431	1.105	1.1431
Max	1.1431	1.467	1.3146	1.2765	1.1431
Min	1.1431	1.1241	1.1241	1.105	1.0288
Avg	1.1431	1.2547	1.1979	1.2074	1.1288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 209 / 11 KV BHIVDHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.743	.5906	.724
2	.6859	.743	.6478	.7621
3	.7621	.7811	.743	.8002
4	.8573	.8764	.9335	.8764
5	1.5242	1.5623	1.086	1.105
6	1.8861	1.9052	1.7337	1.9052
7	1.9433	1.9624	1.9814	1.9814
8	2.0005	1.9814	2.0386	2.0005
9	1.9052	1.6385	1.6766	1.6766
10	1.5242	1.2193	1.1431	1.5242
11	.8954	.8573	.8383	1.0479
12	.7049	.724	.743	.7621
13	.5906	.362	.6859	.7621
14	.6097	.5335	.6287	.6097
15	.4191	.5525	.6097	1.0479
16	.5144	.6478	.6859	1.1431
17	1.1812	.9145	.7049	1.4289
18	1.0288	1.467	1.3336	1.7528
19	1.8671	1.5813	1.9052	1.9624
20	1.2955	1.3336	1.5623	2.0005
21	1.0288	1.1241	.9907	1.1431
22	.7621	.724	.8764	1.0479
23	.7621	.6478	.7621	.6668
24	.6859	.7621	.6097	.6859
Max	2.0005	1.9814	2.0386	2.0005
Min	.4191	.362	.5906	.6097
Avg	1.0883	1.0685	1.0629	1.2257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 201 / NARAYANPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.112	.0934	.0762
2			.112	.0934	.0914
3		.1067	.112	.112	.0914
4		.1067	.1294	.112	.0914
5		.1219	.1478	.1494	.1067
6		.1372	.1663	.168	.1219
7		.1372		.1867	.1372
8		.1219	.1494	.1307	.1219
9		.1067		.1307	.1067
10		.0747		.0914	.0762
11	.0914	2.2708	2.8753	1.1984	2.73
12		2.2708	3.0247	1.5546	2.8147
13		2.3205		1.8138	2.8487
14		2.3868	2.4832		
15		2.3266	2.8753		2.696
16		2.2834	2.9687		2.6452
17		2.1862	2.7446	1.9433	2.7618
18		2.0405	2.5019	2.0729	2.6155
19	.1219	.168	.1494	.1067	.1646
20	.1219	.1494	.1494	.1067	.128
21		.1307	.128	.0914	.1307
22		.112	.128	.0914	.128
23	.0762	.112	.112	.0914	.1097
24		.0762	.112	.112	.0762
Max	.1219	2.3868	3.0247	2.0729	2.8487
Min	.0762	.0747	.112	.0914	.0762
Avg	.1029	.8619	1.0591	.4976	.9074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 202 / RANJANGAON S.P. GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4937	1.307	1.1203	1.2696
2		1.6057		1.2883	1.3443
3		1.7924		1.419	1.419
4		2.0165	1.531	1.8298	1.4937
5		2.1658	1.8298	2.0538	1.531
6		2.3899	2.2634	2.2779	2.1658
7		2.2779	2.2634	2.3525	2.0911
8		2.2032	2.1125	2.2779	2.0911
9		2.0911	1.9993	1.9418	1.7924
10		1.7924	1.7353	1.7551	
11	1.9418	1.643	1.419	1.6804	1.5684
12	1.7924	1.5684	1.2696	1.5684	1.2883
13	1.7177	1.4937	1.2696	1.4563	1.1203
14	***	1.3817	1.1949	1.3443	1.1949
15	1.531	1.3443	1.307	1.4563	1.1949
16		1.3817	1.2323	1.531	1.307
17		1.7924	1.7551	1.7551	1.4937
18	1.9418	2.1125	1.9044	1.9044	1.8671
19	2.4272	2.1125	2.1658	1.8099	1.9418
20	2.2405	1.9418	1.8671	1.8671	1.9616
21		1.8861	1.643	1.6804	1.7177
22		1.5684	1.307	1.4563	1.4937
23		1.475	1.1576	1.3443	1.1949
24		1.3817	1.0974	1.1203	1.2696
Max	16.5798	2.3899	2.2634	2.3525	2.1658
Min	1.531	1.3443	1.0974	1.1203	1.1203
Avg	3.7715	1.7880	1.6196	1.6788	1.5570

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 203 / PIMPARKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2054	.1698	.2241	.2054
2		.2427	.1509	.2614	.2241
3		.2801	.1698	.3361	.2427
4		.3361	.2075	.4108	.2614
5		.3921	.3239	.4481	.2801
6		.4481	.4382	.4668	.4481
7		.5415	.5716	.5228	.5228
8		.5041	.5335	.4481	.5601
9		.4854	.4954	.3921	.5415
10		.4294	.4763	.4294	
11	.4481	.381	.3475	.3921	.4108
12	.4108	.3239	.3475	.3547	.3361
13	.3361	.2987	.3109	.3232	.2801
14	.2987	.2614	.2987		.2614
15	.2614	.2427	.2801		.2241
16		.2614	.2743		.2801
17		.3361	.3734	.4108	.3547
18	.3361	.3961	.4481	.5601	.439
19	.4854	.4338	.4024	.4668	.4668
20	.3921	.3395	.3361	.3921	.3292
21		.3018	.2427	.3174	.2801
22		.2263	.2054	.2427	.2195
23	.2054	.2075	.1829	.2054	.1829
24		.2054	.1698	.1867	.2054
Max	.4854	.5415	.5716	.5601	.5601
Min	.2054	.2054	.1509	.1867	.1829
Avg	.3527	.3367	.3232	.3710	.3285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 204 / JOGESHWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	.9149	1.0374	1.0082
2	1.419	.8686	1.2883	1.1203
3	1.8298	.8871	1.6804	1.2696
4	2.2032	1.2382	1.9791	1.419
5	2.5019	1.9418	2.2405	1.587
6		2.4897	2.3899	
7		2.32	2.3339	2.7073
8	2.3899	2.3577	1.9978	
9	2.3339		1.7364	1.2136
10	1.8111	1.7924	1.5497	
11	1.419	1.1888	1.4937	1.4003
12	1.2136	1.0269	1.3817	1.307
13	1.1576	1.0269	1.307	1.2136
14	1.0903	1.0269	1.2696	1.0269
15	1.0719	1.0269	1.2696	1.0456
16	1.1088	1.0642	1.3817	1.1157
17	1.3817	1.1763	1.4563	1.363
18	1.6598	1.587	1.587	1.587
19	1.6975	1.7364	1.587	1.7364
20	1.5844	1.7737	1.587	1.6244
21	1.4523	1.4003	1.307	1.5497
22	1.2071	1.2136	1.1389	1.1763
23	1.0829	1.0269	1.0829	1.0269
24	1.1763	.9896	.9145	1.0456
Max	2.5019	2.4897	2.3899	2.7073
Min	1.0719	.8686	.9145	1.0082
Avg	1.5398	1.3946	1.5416	1.3592



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 205 / 11 kv NANDEDA gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.823	.9145	.7842
2	1.1949	.823	1.2323	1.0456
3	1.5684	.8507	1.4937	1.3443
4	2.0165	1.1827	1.7924	1.6057
5	2.0911	1.6448	2.0538	1.7924
6		2.0725	2.2779	
8		2.1472	1.7551	2.0911
9		2.037	1.7558	1.9044
10	1.6991	1.7364	1.475	
11	1.363	1.6057	1.2696	1.2323
12	1.1203	1.1203	1.1949	1.1203
13		1.0829		.8775
14	1.0082	.9522		.8402
15	1.1016	1.0082	.9709	.8402
16	1.251	1.1576	1.2696	.9511
17	1.4335	1.4377	1.4045	
18	1.8298	1.7551	1.6244	1.5684
19	1.8107	1.9605	1.4937	1.5684
20	1.4712	1.4937	1.4003	1.3256
21	1.2449	1.2696	1.1203	1.1949
22	1.0269	.9709	.9709	.9896
23	.9522	.8589	.8962	.8402
24	.7842	.8589		.7842
Max	2.0911	2.1472	2.2779	2.0911
Min	.7842	.823	.8962	.7842
Avg	1.3612	1.3413	1.4183	1.2350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 206 / 11 KV Waluj Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7468	.8402	.7514
2			.7059	1.1203	1.2323
3			.7059	1.419	1.4563
4			1.0164	1.8484	1.5684
5			1.8111	2.2405	1.7924
6			2.3577	2.5766	2.7073
7			2.3577	2.9313	3.006
8			2.2822	2.6337	2.9127
9		1.363	2.0748	2.4709	2.3712
10		1.6991	1.8298	1.9791	
11	1.9418	1.6244		1.7551	1.6057
12		1.4563	1.0456	1.531	1.307
13		1.3443		1.419	1.1576
14		1.2696	1.1389	1.2696	1.0269
15	1.1949	1.2323	1.1203	1.1949	1.1016
16			1.4377		
17		1.6244	1.7364		1.7364
18	1.6804	1.9231	2.1285	2.2218	2.1098
19	2.5766	1.9993	2.2592	2.0165	2.2032
20	2.0538	1.4901	1.8484	1.8298	1.8111
21		1.2826	1.419	1.4563	1.475
22		1.0269	1.0456	1.0829	1.0829
23		.8676	.8775	1.0456	.9149
24		1.1576	.7733	.8589	.9709
Max	2.5766	1.9993	2.3577	2.9313	3.006
Min	1.1949	.8676	.7059	.8402	.7514
Avg	1.8895	1.4240	1.4872	1.7155	1.6500

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 207 / 11 KV Ghanegaon Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6802	.8215	1.1203	.6154
2	.1715		.8745	.788	1.2323	.7186
3	.1715		1.1012	.8453	1.307	.8421
4	.2096		1.166	.9503	1.419	.9717
5	.2641		1.2308	1.1469	1.5089	1.1012
6	.4001		1.2955	1.531	1.4937	1.2955
7	.5093		1.6194	1.7814	1.9978	1.8299
8	.4954		1.587	1.9662	2.2965	1.8138
9	.4001		1.5546	1.9006	2.1845	1.8461
10	.2858		.2614		.1981	
11		1.0364	.1905		.1981	.168
12		1.2631	.1307		.1829	.1494
13		1.3927	.1307			.1307
14		1.6032	.1143			.1307
15		.6802	.1334	.1646		.1307
16			.1334	.168		.1307
17			.2286	.1867		.1307
18		.2439	.2667	.2241	.1829	.2427
19		.2743	.3429	.3174	.1829	.3361
20		.2439	.2858	.2987	.2134	.2801
21			.2477	.2427	.1829	.2241
22			.2096	.1867	.1524	.168
23		.1829	.1905	.1463	.1524	.168
24			.6316	.7291	.9335	.5506
Max	.5093	1.6032	1.6194	1.9662	2.2965	1.8461
Min	.1715	.1829	.1143	.1463	.1524	.1307
Avg	.3230	.7690	.6086	.7577	.9021	.6076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 208 / 11 KV East West Industri SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286			.1867	.1829	.1867
2	.1886			.1829	.2241	.1867
3	.1867			.181	.2241	.1867
4	.1867			.181	.1867	.1867
5	.1509			.1772	.1494	.1867
6	.1509			.1867	.1494	.1867
7	.1524			.1494	.1494	.1494
8	.1524			.1509	.1494	.1494
9	.2286				.2987	.2241
10	.2286			.3429	.3734	
11		.4108	.6348	.5975	.4108	.5601
12			.6348	.5228	.4481	.5228
13			.5975	.3734	.4481	.3734
14			.5975	.3734	.3734	.5228
15			.5601	.5487	.2987	.5975
16			.4481	.4854		.5975
17			.5228	.3734		.4481
18			.2241	.2614	.2241	.2987
19			.2614	.2241	.1867	.2614
20			.2286	.1867	.1867	.2195
21			.2241	.1867	.1867	.2614
22			.2286	.2241	.1867	.2241
23			.2286	.2614	.1867	.2241
24				.2263	.1867	.1867
Max	.2286	.4108	.6348	.5975	.4481	.5975
Min	.1509	.4108	.2241	.1494	.1494	.1494
Avg	.1854	.4108	.4147	.2863	.2460	.3018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 201 / 11 KV GAJGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1143	.1524	.1646
2		.1334	.1143	.1524	.1829
3		.1524	.1334	.1715	.2012
4		.1524	.1524	.1905	.1886
5		.1715	.1715	.2096	.2012
6		.1905	.1905	.2096	.1886
7		.1905	.2096	.1905	.1829
8		.1334	.1334	.1524	.1509
9		.0762	.0953	.1334	.1132
10		.0762	.0762	.128	.0953
11		1.0669	.6554	.9145	.8764
12		1.105	.9069	.9694	1.0479
13		1.1431	.8592	.9877	.9907
14		1.1812	.8436	1.0242	.9907
15			.8697	.9877	.9526
16		.9717	.8688	1.0059	.9526
17		.9526	.9172	.9145	.9907
18		.8002	.8259	.9242	.9145
19	.1334	.1143	.0953	.1132	.1524
20	.1524	.1334	.1143	.128	.1524
21	.1524	.1334	.1334	.1132	.1715
22	.1334	.1524	.1334	.1463	.1715
23	.1334	.1524	.1524	.1698	.1524
24		.1334	.1524	.1524	.1463
Max	.1524	1.1812	.9172	1.0242	1.0479
Min	.1334	.0762	.0762	.1132	.0953
Avg	.141	.4109	.3716	.4267	.4305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 202 / 11 kv RANJANGAON POL AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.9145	.5973	.8962
2		.6287	.9526	.6001	1.0242
3		.6859	1.0479	.6859	1.0974
4		.743	1.0479	.7716	1.2437
5		.8192	1.0669	.8573	1.3203
6		.8573	1.1431	.9054	1.39
7		.9145	1.5242	1.0059	1.4523
8		.9717	1.4289	1.2651	1.9387
9		1.0479	1.3717	1.3748	1.9313
10		.0953	.2858	.1646	.2858
11		.1715	.2263	.2012	.2286
12		.1524	.1905	.2012	.2286
13		.1524	.1524	.1698	.2096
14		.1524	.1524	.1463	.1524
15			.1334		.1524
16		.1715	.1524	.2075	
17			.1905	.2926	.1905
18		.1715	.2858	.2743	.3048
19	.4763	.3429	.4763	.2926	.4763
20	.5335	.381	.5335	.3658	.5335
21	.5716	.4191	.5335	.4024	.5144
22	.5335	.4191	.5144	.439	.4763
23	.4763	.5716	.4763	.4338	.4763
24		.5716	.5716	.4572	.7316
Max	.5716	1.0479	1.5242	1.3748	1.9387
Min	.4763	.0953	.1334	.1463	.1524
Avg	.5182	.5006	.6405	.5266	.7502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 203 / 11 KV GAWALI SHIVARA

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3048	.3292	.2926	.2561
2		.3429	.3658	.3658	.3658
3		.4191	.4572	.3658	.5304
4		.5335	.5121	.5487	.6219
5		.6668	.6401	.724	.695
6		.8573	.695	.7682	.6401
7		.7621	.7865	.8145	.567
8		.6668	.7316	.7964	.6036
9		.5716	.6401	.5973	.4572
10	.3658		.5487	.3658	.381
11		.3475	.4572	.439	.2858
12		.2743	.2926	.2012	.2858
13		.2743	.2743	.1646	.2858
14		.2743	.2561	.1509	.2667
15			.2561	.1646	.2667
16		.3109	.3109	.2012	.3048
17		.4024	.4207	.3292	.4191
18		.6219	.5973	.3841	.6097
19	.4763	.6401	.6401	.4755	.5335
20	.4191	.6767	.5487	.4527	.4763
21	.4001	.5487	.4572	.3658	.381
22	.381	.3109	.3658	.3189	
23	.3429	.3109	.3292	.2012	.3048
24		.3048	.3109	.2926	.2012
Max	.4763	.8573	.7865	.8145	.695
Min	.3429	.2743	.2561	.1509	.2012
Avg	.3975	.4738	.4676	.4075	.4234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 204 / 11 KV RAJANGAON POL

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2743	.2614	.1886
2		.2667	.2743	.2772	.3584
3		.3048	.2743	.3326	.3772
4		.381	.3658	.3658	.439
5		.4763	.5487	.5487	.6219
6		.724	.6401	.6401	.7316
7		.724	.6401	.6584	.7865
8		.6287	.5175	.7316	.5853
9		.4954	.4572	.567	.4938
10		.1463	.3658	.3658	.381
11		.1097	.1848	.2075	.2096
12		.128	.1294	.132	.1715
13		.128	.128	.1509	.1524
14		.1097	.1463	.1463	.1524
15			.1463		.1524
16		.1097	.1663	.1646	
17		.3292	.1829	.3658	.3429
18		.4938	.4024	.3772	.4572
19	.4001	.5487	.4763	.439	.4191
20	.3429	.5121	.4066	.4755	.381
21	.3048	.3658	.3658	.3658	.3429
22	.2858	.2195	.3109	.2926	.3048
23	.2667	.2195	.2772	.1886	.2667
24		.2286	.2195	.2427	.1829
Max	.4001	.724	.6401	.7316	.7865
Min	.2667	.1097	.128	.132	.1524
Avg	.3201	.3425	.3292	.3607	.3695



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.6668	.362	.1829
2		.6097	.6668	.3982	.1829
3		.6668	.9145	.443	.2012
4		.724	.9526	.5144	.2195
5		.7811	.9526	.6001	.2012
6		.8383	.9526	.7373	.2195
7		.9145	1.0669	.8802	.2195
8			1.1431	.9717	.2926
9		1.1812	1.2574	1.0722	.2926
10		.0381	.0572	.0366	.0191
11		.0381	.0381	.0366	.0191
12		.0381	.0381	.0366	.0191
13		.0381	.0381	.0366	.0191
14		.0572	.0381	.0377	.0191
15		.0572	.0381	.0549	.0191
16		.0572	.0381	.0366	.0191
17		.0572	.0381	.0549	.0191
18		.0953	.0381	.0377	.0953
19	.1143	.0953	.0762	.0732	.0953
20	.1143	.0953	.0953	.0914	.0953
21	.1143	.0953	.0953	.1097	.0953
22	.1143	.0953	.0953	.1097	.0953
23	.1143	.0953	.0953	.1097	.0953
24		.5716	.2858	.1829	.1463
Max	.1143	1.1812	1.2574	1.0722	.2926
Min	.1143	.0381	.0381	.0366	.0191
Avg	.1143	.3396	.4033	.2927	.1201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 206 / 11 KV GAWALI SHIWARA AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 FEEDER Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0762	.0953	.1097
2		.0572	.0762	.1143	.0914
3		.0572	.0762	.1143	.1132
4		.0762	.0762	.1143	.132
5		.0762	.0762	.1143	.1097
6		.0953	.0762	.0953	.1097
7		.0762	.0762	.0953	.1097
8		.0762	.0762	.0754	.0549
9		.0762	.0762	.0381	.0549
10		.0762	.0572	.0549	.0572
11		.5716	.3429	.3658	.4191
12		.6097	.4458	.439	.5335
13		.6097	.4115	.4755	.4763
14		.5716	.3772	.3772	.4572
15			.3429	.3658	.4191
16		.5716	.3429	.4024	.4191
17		.4763	.3601	.3292	.381
18		.2858	.2058	.3109	.3429
19	.0762	.0572	.0762	.0732	.0953
20	.0953	.0572	.0953	.0914	.0953
21	.0953	.0762	.0953	.1097	.0953
22	.0762	.0762	.0953	.1097	.0953
23	.0572	.0762	.0953	.1097	.0953
24		.0572	.0762	.0953	.1097
Max	.0953	.6097	.4458	.4755	.5335
Min	.0572	.0572	.0572	.0381	.0549
Avg	.0800	.2096	.1711	.1903	.2074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 207 / 11KV KBS INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.0183
2		.0191	.0191	.0191	.0183
3		.0191	.0191	.0191	.0183
4		.0191	.0191	.0191	
5		.0191	.0191	.0191	
6		.0191	.0191	.0191	.0183
7		.0191	.0191	.0191	.0183
8		.0191	.0191	.0191	.0183
9		.0191	.0191	.0191	.0183
10		.0191	.0191	.0183	.0191
11	.0191	.0191	.0191	.0183	.0191
12		.0191	.0191	.0183	.0191
13		.0191	.0191	.0183	.0191
14		.0191	.0191	.0189	.0191
15		.0191	.0191	.0183	.0191
16		.0191	.0191	.0183	.0191
17		.0191	.0191	.0177	.0191
18		.0191	.0191	.0183	.0191
19	.0191	.0191	.0191	.0183	.0191
20	.0191	.0191	.0191	.0183	.0191
21	.0191	.0191	.0191	.0189	.0191
22	.0191	.0191	.0191	.0183	.0191
23	.0191	.0191	.0191	.0183	.0191
24		.0191	.0191	.0191	.0183
Max	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0177	.0183
Avg	.0191	.0191	.0191	.0187	.0188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 208 / Dhananjay auto

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0381	.1334	.1829
2		.0953	.0381	.1334	.1829
3		.0953	.0572	.1143	.2012
4		.0953	.0572	.1143	.1829
5		.0953	.0572	.1524	.1829
6		.0953	.0762	.1524	.1829
7		.0953	.0953	.1524	.1829
8		.0953	.0953	.1143	.1646
9		.0953	.1524	.1143	.1097
10		.0572	.1143	.128	.1524
11		.0381	.1143	.128	.1524
12		.0381	.1143	.1646	.1334
13		.0572	.1143	.1463	.1334
14		.0762	.1143	.1463	.1334
15		.0572	.0953	.1463	.1334
16		.0381	.0953	.1646	.1334
17		.0572	.1524	.1509	.1334
18		.0572	.1334	.1463	.1715
19	.0762	.0572	.1334	.1595	.1905
20	.0762	.0572	.1334	.1646	.1905
21	.0762	.0572	.1524	.1829	.1905
22	.0762	.0381	.1524	.2012	.1905
23	.0762	.0381	.1524	.2012	.1905
24		.0762	.0381	.1524	.1829
Max	.0762	.0953	.1524	.2012	.2012
Min	.0762	.0381	.0381	.1143	.1097
Avg	.0762	.0691	.1032	.1485	.1660

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 201 / 11 KV AMINABAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6706	.9568	.9431	.788
2		.7545	1.0277	1.0898	.8954
3		.8215	1.0517	1.2574	1.0517
4		1.0059	1.1443	1.4918	1.166
5		1.2574	1.3523	1.6575	1.3077
6		1.3413	1.4575	1.8023	1.5074
7		1.8442	1.9281	1.989	1.9524
8		2.1795	2.2377	2.4006	2.2405
9		2.0957	2.3472	2.3122	2.3403
10		.2263	.1886	.5658	.2263
11		.124	.1886	.1698	.1886
12		.1063	.1886	.132	.1886
13		.0886	.1886		.1698
14		.0886	.1886	.1509	.132
15		.0886	.1886	.1509	.132
16		.0709		.1509	.1132
17		.1052	.1886	.1509	.0943
18		.1844	.2263	.1886	.2452
19		.3155	.2263		.3772
20		.2507	.1886	.2263	.3018
21		.2507	.1886	.2263	.2641
22	.2829	.2172	.1886	.1886	.2641
23	.2829	.1991	.1509	.1886	.2452
24		.5868	.9114	.7716	.7316
Max	.2829	2.1795	2.3472	2.4006	2.3403
Min	.2829	.0709	.1509	.132	.0943
Avg	.2829	.6197	.7350	.8275	.7051

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 202 / 11 KV WARKHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1132	.1402	.1509	.1509
2		.1132	.1372	.1509	.1509
3		.132	.1629	.1509	.1698
4		.132	.1578	.1886	.1698
5		.132	.1772	.1886	.1886
6		.1509	.1772	.1886	.1886
7		.1509	.1612	.1886	.1698
8		.1132	.1433	.1886	.1698
9		.0754	.0895	.0943	.132
10		.0566	.0886	.0566	.132
11		1.1043	1.278	1.1603	1.1904
12		1.4243	1.4586	1.4419	1.1736
13		1.56	1.491	1.4918	1.4922
14		1.3904	1.5424	1.5074	1.5257
15		1.56	1.3927	1.5546	1.4419
16		1.4419	1.6766	1.5074	1.5424
17		1.5089	1.6244	1.4575	1.358
18		.6379		1.4251	1.2071
19		.1791	.2263	.1886	.1886
20		.1629	.2075	.1886	.1886
21		.1791	.1886	.1698	.1886
22	.1132	.181	.1698	.1698	.1698
23	.1132	.1629	.1698	.1698	.1698
24		.1132	.1543	.1509	.1509
Max	.1132	1.56	1.6766	1.5546	1.5424
Min	.1132	.0566	.0886	.0566	.132
Avg	.1132	.5323	.5659	.5888	.5671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 203 / 11 KV WAHEGAON AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0886	.0943	.0943
2		.1132	.0886	.0943	.0943
3		.132	.0886	.0943	.1132
4		.132	.1063	.1132	.1132
5		.1698	.1267	.1509	.132
6		.1886	.1433	.1509	.1509
7		.1949	.1949	.1886	.1886
8		.2075	.1372	.1698	.1698
9		.1698	.1029	.1132	.132
10		.0943	.0886	.0943	.0754
11		.9326	.8551	.9614	.6371
12		1.153	.9945	1.0486	.7377
13		1.1191	1.0322	1.0814	.8551
14		1.2071	1.0562	1.065	1.0395
15		1.073	.9831	1.0322	.7712
16		1.1568	1.0059	1.0486	1.0395
17		1.0852	.9831	.9945	1.0227
18		.9221		.8684	.9054
19		.1086	.1132	.0943	.1509
20		.0905	.1132	.132	.1509
21		.1086	.1132	.132	.1509
22	.132	.1075	.0943	.1132	.1509
23	.1132	.0895	.0943	.0943	.1509
24		.0943	.0876	.0943	.0943
Max	.132	1.2071	1.0562	1.0814	1.0395
Min	.1132	.0895	.0876	.0943	.0754
Avg	.1226	.4477	.3779	.4177	.3800

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 204 / 11KV GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.415	.394	.3772	.3734
2		.4527	.4607	.4715	.3734
3		.5658	.567	.5281	.4066
4		.8299	.7011	.7167	.4805
5		1.1128	.9114	.8871	.7392
6		1.1883	1.0749	1.1643	1.0349
7		1.1506	1.0745	1.1458	1.1222
8		.9619	.9313	.9709	.8779
9		.8676	.7522	.6802	.7392
10		.6413	.543	.4715	.6722
11		.3086	.2772	.2957	.415
12		.2481	.2218	.2587	.3395
13		.2481	.1886		.3206
14		.2149	.1886	.2241	.2641
15		.3189	.1886	.2587	.2829
16		.2481		.3326	.1698
17		.4656	.2829	.4066	.3772
18		.788		.5853	.7167
19		.9593	.8962		1.0751
20		.6516	.7577	.695	.7733
21		.439	.5658	.6036	.5281
22	.4527	.3982	.4715	.4108	.4527
23	.3772	.3801	.415	.4108	.415
24		.3772	.3582	.3772	.3734
Max	.4527	1.1883	1.0749	1.1643	1.1222
Min	.3772	.2149	.1886	.2241	.1698
Avg	.4150	.5930	.5556	.5578	.5551



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 205 / 11KV MUDDESH WADGAON AG FEEDER SEPERATION/PURE AG  
FEEDER Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5868	.9114	.6859	.6878
2		.6874	.9156	.7545	.7964
3		.7712	.9724	.9221	.8859
4		.8551	1.0227	.9945	.9389
5		.9054	1.0442	.9945	1.0059
6		.9724	1.0608	1.2289	1.1105
7		1.291	1.3426	1.4419	1.3765
8		1.576	1.643	1.6518	1.7284
9		1.4754	1.6933	1.643	1.6324
10			.0686	.0754	.0943
11		.0351	.0566	.0566	.0566
12		.0351	.0566	.0566	.0566
13		.0514	.0377	.0566	.0377
14		.0354	.0566	.0566	.0566
15		.0351	.0566	.0566	.0566
16		.0354	.0566	.0566	.0566
17		.0339	.0566	.0566	.0377
18		.0358	.0754	.0754	.0943
19		.1086	.1509	.1132	.132
20		.1086	.1509	.132	.132
21		.0732	.1132	.132	.1132
22	.1132	.0724	.1132	.1132	.1132
23	.1132	.0724	.0943	.0943	.0943
24		.503	.8745	.6001	.5853
Max	.1132	1.576	1.6933	1.6518	1.7284
Min	.1132	.0339	.0377	.0566	.0377
Avg	.1132	.4503	.5260	.5020	.4950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 201 / 11 KV DONGAON AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.2401	.3521	.2743
2		.1715	.2572	.3978	.2743
3		.2374	.2543	.3978	.3086
4		.2543	.3052	.421	.3052
5		.285	.3688	.421	.3222
6		.3647	.4024	.5281	.3688
7		.4641	.4748	.547	.5138
8		.4641	.503	.4481	.5365
9		.4424	.4862	.502	
10			.2075	.2829	.2452
11			.2263	.2829	.3018
12		.2263	.1886	.2452	.1886
13		.2075	.1698	.1886	.1698
14			.1698	.1886	.1698
15		.2452	.1886	.1698	.1509
16		.2829	.2263	.2263	.1886
17		.3395	.3772	.2829	.3018
18		.6224	.5093	.415	.3961
19		.547	.5658	.4527	.5093
20		.4715	.6036	.5281	.6413
21		.3772	.4527	.4338	.5658
22	.3584	.3772	.3772	.415	.3584
23	.3395	.3772	.3772	.415	.3206
24		.1715	.2229	.3086	.2743
Max	.3584	.6224	.6036	.547	.6413
Min	.3395	.1715	.1698	.1698	.1509
Avg	.3490	.3389	.3398	.3688	.3342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 202 / 11 KV RAIPUR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3258	.4287		.4287
2		.2915	.463	.5304	.4287
3		.3258	.4527	.5304	.463
4		.3052	.4862	.5506	.4917
5		.3856	.57	.6154	.5087
6		.4973	.7042	.6478	.57
7		.8192	.6962	.664	.779
8		.852	.9945	.7042	.8288
9		.8356	1.094	1.0688	
10		.3395	.3395	.3018	.3395
11		.3584	.3961	.3018	.3206
12			.3206	.2829	.2452
13		.2452	.2829	.2641	.2641
14			.2641	.2641	.2829
15		.3206	.2641	.2263	.3018
16		.3772	.2452	.2452	.2641
17		.4338	.3395	.3206	.3395
18		.7733	.7356	.5093	.5281
19		.7356	.7356	.6979	.8676
20		.7356	.9054	.7545	.9808
21		.6413	.7356	.7545	.9431
22	.6413	.6224	.679	.6979	.6413
23	.5847	.6036	.6413	.6224	.5847
24		.3429	.3944	.3429	.4287
Max	.6413	.852	1.094	1.0688	.9808
Min	.5847	.2452	.2452	.2263	.2452
Avg	.613	.5076	.5487	.5173	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 203 / 11 KV PADALSA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5847	.7167	.6413	.7167
2		.6602	.7167	.7356	.7733
3		.7545	.7356	.7922	.9808
4		.8676	.7922	.8488	1.1317
5		1.1128	.8865	.9619	1.3203
6		1.3769	1.2071	1.1317	1.4523
7		1.3203		1.2449	1.3203
8		1.226	1.2637	1.3392	1.2826
9		1.0562		1.1128	1.1694
10		.9326	.7045	.7293	.5658
11		1.0395	.7773	.8383	.663
12		.9448	.8676	.8122	.663
13		.8886	.7449	.7545	.6464
14		.8619	.8488	.6796	.6299
15		.8718	.7209	.6371	.5601
16		.8383	.7045	.6706	.5304
17		.8309	.8488	.6962	.7127
18		.7122	.8865	.8573	.6687
19		.8676	.9242	.8865	1.1694
20		.811	1.0562	1.1317	1.2826
21		.7733	.9619	.9997	1.226
22	.7545	.7545	.8488	.7922	.7545
23	.6602	.7545	.7167	.7167	.6602
24		.5658	.7167	.6413	.7167
Max	.7545	1.3769	1.2637	1.3392	1.4523
Min	.6602	.5658	.7045	.6371	.5304
Avg	.7074	.8919	.8476	.8605	.8999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 204 / 11 KV M.S. ginning express NON SHEDDABLE EXPRESS HV FEEDERS  
 fee Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0181	.0189	.0177
2		.0171	.0183	.0189	.0183
3		.0171	.0181	.0189	.0175
4		.0171	.0179	.0189	.0175
5		.017	.0175	.0189	.0175
6		.0166	.0175	.0189	.0175
7		.0166	.0175	.0189	.0175
8		.0166	.0175	.0189	.0175
9		.0166	.0173	.0189	.0177
10		.0179	.0189		.0166
11		.0177	.0189		.016
12		.0175	.0189		.016
13		.0177	.0189		.0166
14		.0181	.0189	.0183	.0166
15		.0175	.0189	.0179	.016
16		.0183	.0189	.0175	.0166
17		.0175	.0189	.0177	.0166
18		.0183	.0189	.0177	.0166
19		.0183	.0189	.0179	.0171
20		.0181	.0189	.0175	.0171
21		.0177	.0189	.0181	.0181
22	.0177	.0183	.0189	.0179	.0171
23	.0179	.0175	.0189	.0175	.0183
24		.0171	.0181	.6413	.0175
Max	.0179	.0183	.0189	.6413	.0183
Min	.0177	.0166	.0173	.0175	.016
Avg	.0178	.0175	.0184	.0495	.0171

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 201 / 11 KV ZANZARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0686	.1509	.0732	.0732
2			.0686	.1509		.0732
3			.0693	.1457	.0732	.0732
4			.0876	.1341	.0732	.0914
5			.1052	.1341	.0924	.1294
6			.1463	.1341	.1109	.1494
7			.1311	.1174	.1509	.1886
8			.1629	.1174	.1698	.1698
9			.0895	.1006	.1307	.1509
10			.0716	.0732	.0914	.0914
11			2.3807	2.0241	1.6129	
12			2.2801	2.0873	2.0873	2.5692
13			2.3137	2.2455	2.2455	
14			2.3472	2.3758	2.3403	
15			2.4143	2.2455	2.372	2.4249
16			2.3807	2.2138	2.2455	2.42
17			2.6155	.2378	2.0873	2.4863
18			2.079	.2378	1.7711	2.2939
19			.1006	.112	.0914	.181
20			.1174	.1307	.128	.1075
21			.1341	.0914	.1509	.104
22		.0716	.1174	.0549	.1097	.0876
23		.0724	.1341	.0549	.0732	.0543
24	1.1736		.0514	.1509	.0732	.0732
Max	1.1736	.0724	2.6155	2.3758	2.372	2.5692
Min	1.1736	.0716	.0514	.0549	.0732	.0543
Avg	1.1736	.072	.8528	.6467	.798	.6663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 202 / 11 KV PENDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963	.503	.4572	.4515
2	.463	.5365		.4515
3	.5093	.57	.4877	.4515
4	.5401	.6371	.5182	.5117
5	.6173	.7377	.5792	.5792
6	.7042	.7712	.6401	.6401
7	.7682	.9054	.823	.7316
8	1.0159	1.0059	.884	1.0059
9	.7287	1.1065	1.0031	.945
23				.3658
24	.381	.4024	.4214	.4458
Max	1.0159	1.1065	1.0031	1.0059
Min	.381	.4024	.4214	.3658
Avg	.6124	.7176	.6460	.5981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 203 / 11KV BABARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5182	.6036	.535	.5182
2	.5487	.6036		.5182
3	.5864	.9054	.7316	.5792
4	.6562	1.073	.9145	.6401
5	.7287	1.1401	1.1584	.884
6	.9069	1.1736	1.2963	1.2346
7	1.3763	1.5424	1.6288	1.5123
8	1.9719	1.7436	1.7711	2.0873
9	1.326	1.7814	2.0557	2.0557
24	.4877	.5506	.4755	.4877
<b>Max</b>	<b>1.9719</b>	<b>1.7814</b>	<b>2.0557</b>	<b>2.0873</b>
<b>Min</b>	<b>.4877</b>	<b>.5506</b>	<b>.4755</b>	<b>.4877</b>
<b>Avg</b>	<b>.9107</b>	<b>1.1117</b>	<b>1.1741</b>	<b>1.0517</b>



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 204 / 11KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0149	.0168	.0149	.0149
2		.0143	.0168		.0149
3		.0152	.0168	.0149	.0149
4		.0152	.0335	.0149	.0149
5		.0152	.0335	.0149	.0149
6		.0154	.0335	.0149	.0149
7		.0168	.0503	.0149	.0149
8		.0747	.0671	.0149	.0149
9		.0934	.0671	.0532	.0149
10		.0924	.0724	.0532	.0149
11		.0671	.0724	.0914	
12		.0838	.0724	.0724	.0175
13		.0838	.0537	.0532	.0358
14		.0838	.0335	.0532	
15		.0838	.0335	.0532	.0181
16		.0838	.0335	.0335	.0179
17		.081	.0335	.0914	.0179
18		.0671	.0335	.0914	.017
19		.0671	.0149	.0532	.0143
20		.0503	.0149	.0532	.0145
21		.0503	.0149	.0335	
22	.0309	.0503	.0149	.0335	.0124
23	.0305	.0335	.0149	.0335	.0124
24		.0152	.0335	.0149	.0149
Max	.0309	.0934	.0724	.0914	.0358
Min	.0305	.0143	.0149	.0149	.0124
Avg	.0307	.0529	.0367	.0423	.0163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 201 / 11KV KHULTABAD-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.4801	.4458	.4801
2			.5658	.5144	.4458	.4801
3			.583	.5487	.4801	.5144
4			.6687	.6173	.5487	.583
5			.7202		.6173	.6516
6			.7888		.7716	.7202
7			.8059	.6859	.8573	.9259
8			.8059	.8745	.7888	.823
9	.7545		.8573	.7716	.823	.8745
10			.9054	.8299	.7545	.8299
11			.8299	.7545	.7922	.7545
12			.7545	.8299	.6859	
13			.7545	.7545	.679	.6413
14			.679	.6413	.6413	.6413
15			.6413	.679	.6413	.679
16			.6036	.5658	.679	.7545
17			.703	.6173	.6344	.6036
18			.8402	.7716	.8059	.9054
19			.9431	.9431	.8573	1.0425
20			.8745	.823	.8402	.9145
21			.7373	.7545	.6859	.8779
22			.6344	.6173	.6516	.7356
23		.6173	.5144	.5316	.583	.6036
24			.5316	.4801	.4458	.4801
Max	.7545	.6173	.9431	.9431	.8573	1.0425
Min	.7545	.6173	.5144	.4801	.4458	.4801
Avg	.7545	.6173	.7190	.6857	.6732	.7181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 202 / 11 KV KHULTABAD II  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.442	.6516	.6859	.6859
2			.5944	.7202	.6859	.6859
3			.6401	.7716	.823	.823
4			.7316	1.0631	1.1145	1.1145
5			.945	1.3375	1.3375	1.3375
6			.945	1.4403	1.5432	1.5775
7			1.5699	2.332	2.4006	2.7263
8			2.1795	2.9492	3.1722	3.0693
9	.2915		1.9662	3.0521	2.9492	3.0864
10			.1509	.1886	.2641	.2263
11			.1132	.1509	.1886	.1886
12			.1132	.0377	.1509	.1886
13			.0754	.0377	.1509	.1509
14			.0754	.0377	.1509	.1509
15			.0377	.1132	.1509	.1509
16			.1029	.2263	.1509	.1509
17			.1372	.1372	.1543	.1844
18			.2401	.2572	.2229	.2515
19			.2915	.2743	.2401	.3353
20			.2743	.2743	.2401	.3292
21			.2401	.2401	.2743	.2829
22			.2058	.2229	.1715	.2347
23		.1829	.1886	.1886	.1715	.2378
24			.2286	.6516	.6859	.6859
Max	.2915	.1829	2.1795	3.0521	3.1722	3.0864
Min	.2915	.1829	.0377	.0377	.1509	.1509
Avg	.2915	.1829	.5204	.7232	.7533	.7856

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 203 / 11 KV T. V. Centre  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343	.0343	.0514
2			.0343	.0343	.0514
3			.0343	.0343	.0514
4		.0343	.0343	.0514	.0514
5		.0686	.0686	.0514	.0686
6		.0857	.0857	.0686	.0857
7		.0857	.0857	.0857	.0857
8		.0857	.0857	.0857	.0857
9		.0857	.0857	.0857	.1029
10		.0943	.1132	.1132	.0943
11		.0943	.1132	.1132	.1132
12		.0943	.1132	.1132	.1132
13		.0943	.1132	.1132	.1132
14		.0943	.1132	.1132	.1132
15		.0943	.1132	.1132	.1132
16		.1132	.1132	.1132	.1132
17		.1029	.1029	.1029	.1097
18		.0857	.0857	.1029	.1006
19		.0857	.1029	.1029	.1097
20		.0857	.1029	.1029	.1097
21		.0857	.1029	.1029	.1097
22		.0857	.0857	.1029	.0838
23	.0857	.0857	.1029	.0857	.0914
24		.0514	.0343	.0343	.0514
Max	.0857	.1132	.1132	.1132	.1132
Min	.0857	.0343	.0343	.0343	.0514
Avg	.0857	.0854	.0859	.0859	.0906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 204 / 11KV ELLORA MANDIR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.3086	.2572	.3086
2		.3601	.3086	.2572	.3086
3		.3772	.3429	.2743	.3772
4		.4115	.4115	.3086	.4115
5		.4458	.4801	.4115	.5144
6		.6687	.6173	.6173	.6516
7		.8573	.8573	.8573	.7888
8		.4801	.7716	.8402	.7545
9		.6859	.6687	.6516	.6001
10		.5658	.5658	.679	.5658
11		.4904	.4527	.4527	.4527
12		.3772	.3772	.3772	.3772
13		.3395	.3395	.3772	.3772
14		.2263	.3018	.3772	.3018
15		.3018	.2641	.3772	.3018
16		.3018	.3772	.3772	.3018
17		.4801	.4287	.5144	.4938
18		.5658	.6344	.5658	.6767
19		.583	.6344	.5658	.7133
20		.5144	.5316	.5658	.5304
21		.4287	.4287	.4458	.4755
22		.3429	.3258	.3772	.3841
23	.3429	.3258	.2743	.3429	.2926
24		.3429	.3086	.2572	.3086
Max	.3429	.8573	.8573	.8573	.7888
Min	.3429	.2263	.2641	.2572	.2926
Avg	.3429	.4507	.4588	.4637	.4695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 205 / 11 KV KASABKHEDA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1524	.1886	.1715	.1715
2			.1524	.1886	.1715	.1715
3			.1677	.2058	.2058	.1886
4			.1829	.2401	.2401	
5			.2134	.2743	.2743	.2401
6			.2439	.3086	.2915	.2743
7			.2743	.3429	.3086	.3086
8			.2591	.2915	.2743	.2743
9			.3353	.2229	.2058	.2401
10			.2641	.2641	.2263	.1886
11			1.1694	1.3203	1.2449	1.3203
12			1.2826	1.2449	1.1317	1.2449
13			1.3203	1.2071	1.0185	1.2071
14			1.3203	1.142	.9431	.9431
15			1.2449	.9431	.9431	.7545
16			1.1694	1.1317	1.0185	.9431
17			1.0117	1.0117	.9602	.8551
18			.8916	.7888	.823	.7377
19	.3601		.2572	.2743	.2058	.2683
20	.2743		.2572	.2401	.2572	.2347
21			.2229	.1886	.2058	.2012
22			.2058	.1886	.2058	.2012
23		.1524	.2058	.1715	.1715	.1844
24			.1524	.1886	.1715	.1715
Max	.3601	.1524	1.3203	1.3203	1.2449	1.3203
Min	.2743	.1524	.1524	.1715	.1715	.1715
Avg	.3172	.1524	.5399	.5237	.4863	.4924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 206 / 11 KV PALASWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.1886	.1715	.1886
2		.3353	.1886	.1715	.1886
3		.3658	.2743	.2058	.2401
4		.3963	.3086	.2743	.3086
5		.4268	.3601	.4115	.4458
6		.4572	.5487	.6173	.5487
7		.4877	.703	.7373	.8402
8		.6554	.9774	.8745	1.0631
9		.6401	1.0288	.9945	1.0974
10		.1132	.1886	.1509	.2641
11		.1029	.1509	.1509	.1509
12		.1132	.1886	.1509	.1509
13		.1521	.1509	.1132	.1509
14		.1715	.1886	.1132	.1509
15		.1509	.1886	.1132	.1886
16		.1132	.1886	.1132	.1886
17		.0514		.1715	.2054
18		.1029	.2058	.2229	.2347
19		.2572	.2572	.2401	.285
20		.2229	.1886	.2572	.2347
21		.2058	.1886	.2401	.2012
22		.1886	.1886	.2401	.2012
23	.1524	.1715	.1715	.1886	.1829
24		.1524	.1886	.1715	.1886
Max	.1524	.6554	1.0288	.9945	1.0974
Min	.1524	.0514	.1509	.1132	.1509
Avg	.1524	.2629	.3136	.2957	.3292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 208 / 11KV CAVES

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.061	.0343	.0343	.0343
2		.061	.0343	.0343	.0343
3		.061	.0343	.0343	.0343
4		.0457	.0343	.0343	.0343
5		.061	.0343	.0514	.0343
6		.061	.0343	.0514	.0514
7		.061	.0514	.0514	.0514
8		.0457	.0343		.0514
9		.0457	.0171	.0343	.0343
10		.0566	.0377	.0754	.0566
11		.0566	.0377	.0754	.0754
12		.0566	.0377	.0754	.0754
13		.0566	.0377	.0754	.0754
14		.0566	.0377	.0754	.0754
15		.0566	.0377	.0754	.0754
16		.0377	.0377	.0754	.0754
17		.0514	.0514	.0686	.0671
18		.0857	.0514	.0686	.0671
19		.0686	.0686	.0686	.0671
20		.0514	.0514	.0686	.0503
21		.0514	.0514	.0343	.0335
22		.0514	.0343	.0343	.0335
23	.061	.0343	.0343	.0343	.0366
24		.0457	.0343	.0343	.0343
Max	.061	.0857	.0686	.0754	.0754
Min	.061	.0343	.0171	.0343	.0335
Avg	.061	.0550	.0396	.0550	.0524



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 209 / 11kv kagzipura

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1372	.1543	.1543
2		.1715	.1372	.1543	.1543
3		.2229	.1715	.2058	.2058
4		.2572	.2058	.2401	.2743
5		.3086	.2743	.3086	.3772
6		.3429	.3772	.3944	.4458
7		.4801	.4458	.4801	.4973
8		.463	.3258	.4458	.3258
9		.3772	.4287	.4115	.4287
10		.415	.415	.3772	.3772
11		.3018	.3772	.3395	.3018
12		.2641	.3018	.2641	.3018
13		.2263	.2641	.2263	.2263
14		.2263	.2641	.1886	.2263
15			.2641	.1886	.2263
16			.2641	.1886	.2263
17			.2743	.2915	.297
18			.4115	.3772	.439
19		.4287	.3772	.3601	.439
20		.3601	.3429	.3429	.3475
21		.2572	.2743	.2572	.2743
22		.2058	.2058	.2058	.2195
23	.1886	.1543	.2058	.1715	.2012
24		.1715	.1372	.1543	.1543
Max	.1886	.4801	.4458	.4801	.4973
Min	.1886	.1543	.1372	.1543	.1543
Avg	.1886	.2903	.2868	.2803	.2967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 201 / 11KV BAZAR SAWANGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4001	.1905	.5716
2	.5335	.4191	.1905	.7621
3	.6097	.4763	.2286	.8501
4	.743	.5716	.2477	.8871
5	.8764	.7621	.2667	1.1458
6	1.0288	.9145	.2858	1.4632
7	1.2765	1.5242	.2858	1.957
8	.9335	1.7528	1.8861	2.2314
9	.8192	1.8099	2.0767	2.1765
19	.3239	.2096	.2477	.1905
20	.2286	.1715	.2286	.1905
21	.1905	.0953	.1905	.1715
22	.2286	.0762	.1524	.1524
23	.0762	.0762	.1334	.1334
24	.4001	.381		.4191
Max	1.2765	1.8099	2.0767	2.2314
Min	.0762	.0762	.1334	.1334
Avg	.5830	.6427	.4722	.8868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 202 / 11 KV. Bodkha AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1143	.1143
2	.1524	.1524	.1143	.1143
3	.1524	.1524	.1524	.1143
4	.1715	.1715	.1905	.1524
5	.2096	.2096	.1905	.1524
6	.2286	.2286	.2286	.2286
7	.2286		.2286	.2858
10		1.086		
11	2.1338	1.848	1.957	1.9052
12	2.2291	2.1148	2.2177	2.2672
13	2.4006	2.2291	2.1948	2.0386
14	2.1262	2.21	1.829	
15	1.9909	1.9814	1.6095	2.0957
16	1.7661	2.0195	1.9204	2.0386
17	1.3717	1.8861	1.6095	1.8861
18	1.4289	1.3717	1.4266	1.5242
19	.1715	.2477	.1905	.2096
20	.1524	.1905	.1715	.1715
21	.1524	.1524	.1715	.1715
22	.1143	.1143	.1524	.1524
23	.1143	.1143	.1143	.1143
24	.1524	.1524		.1143
Max	2.4006	2.2291	2.2177	2.2672
Min	.1143	.1143	.1143	.1143
Avg	.8381	.8945	.8392	.7926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 203 / 11 KV. KANATGAON. AG.      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762		
2		.0762		
3		.0762	.0381	
4	.0191	.0762	.0381	
5	.0381	.0762	.0762	
6		.1143	.0762	.0381
7	.0762		.0762	.0953
10		.1905		.362
11	.5716	.4763	.5041	
12	.6287	.5335	.4382	.362
13	.5335	.4763	.4001	.4191
14	.4954	.4191	.2858	.381
15	.3696	.381	.2477	.4001
16	.3734	.4001	.2286	.2667
17	.2858	.3048	.3048	.2858
18	.2858	.3048	.2096	.2667
19	.0762	.1524	.0572	.0572
20	.0762	.0572	.0572	.0381
21	.0762	.0381	.0381	.0381
22	.0572			.0191
23	.0381			
24		.0762		
Max	.6287	.5335	.5041	.4191
Min	.0191	.0381	.0381	.0191
Avg	.2501	.2266	.1923	.2164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 204 / 11KV YESGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3429	.5716	.381
2	.5716	.381	.5716	.381
3	.6097	.4001	.6668	.4191
4	.743	.4191	.7621	.4572
5	.8764	.4763	.8573	.4954
6	.9717	.724	.9145	.5716
7	1.0669	1.2193	.9145	.8501
8	1.2003	1.3336	1.3336	1.134
9	1.0669	1.3336	1.3146	1.2567
19	.1143	.1334	.0953	.1143
20	.1143	.1334	.3048	.1334
21	.1143	.1143	.0762	.0953
22	.0953	.1143	.0762	.0953
23	.1143	.0953	.0762	.1143
24	.4382	.3048		.381
Max	1.2003	1.3336	1.3336	1.2567
Min	.0953	.0953	.0762	.0953
Avg	.5741	.5017	.6097	.4586

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 205 / 11KV TAJNAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.3429	.3239	.3429	.381	.381	.4191
2	.2667	.3429	.3239	.4382	.381	.5716	.4763
3	.2858	.362	.3429	.5525	.4001	.5716	.5144
4	.2858	.381	.3429	.6097	.4191	.7621	.5906
5	.3048	.381	.3429	.7049	.4763	.9526	.6668
6	.3239	.4382	.381	.8002	.4763	.9907	.7621
7		.4763		.9145		1.0098	1.0098
8				1.0479		1.4289	1.3146
9				.9145	1.1431	.724	1.3146
11	.4001		.8002				
12	.7621		1.1431				
13	.7621	.7811	.8002				
14	.7621	.8192	1.2955				
15	.724	.8192	.8954				
16	.6097	.724	.8002				
17	.6097	.9907	.8002				
18	.6859	.8573	.6668				.4954
19		.362	.381	.4763			.4572
20	.381	.362	.4001	.4191	.4763	.4954	.4572
21	.362	.362	.362	.3048	.3429	.4382	.381
22	.3429	.3429	.2667	.2477	.2858	.3048	.3048
23	.3429	.3429	.2667	.2667	.2286	.2477	.3048
24	.2667	.3429	.3429	.2858	.3048	.362	.381
Max	.7621	.9907	1.2955	1.0479	1.1431	1.4289	1.3146
Min	.2667	.3429	.2667	.2477	.2286	.2477	.3048
Avg	.4603	.5174	.5639	.5550	.4429	.6600	.6156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 206 / 11KV Yesgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.2096	.3429
2	.2096	.2286	.2286	.3429
3	.2477	.2286	.381	.4191
4	.2858	.2286	.7621	.5716
5	.4954	.381	.9526	.6668
6	.8002	1.0098	1.0479	.7621
7	.9717	1.0288	1.0669	1.0269
8	.8954	.9717	.9717	.9335
9	.8002	.8383	.8573	.7655
10	.6287	.5906	.4763	.4001
11	.3048	.4191	.2286	.2858
12	.2286	.2096	.1905	.2667
13	.2667	.1715	.1715	.2096
14	.2096	.2096	.1715	.1905
15	.3361	.1524	.1905	.1715
16	.3881	.3239	.4001	.4001
17	.3239	.4572	.4572	.4572
18	.8002	.6478	.5144	.6287
19	.8002	.7621	.7655	.743
20	.5716	.6287	.5335	.5335
21	.4001	.4763	.4191	.4191
22	.2477	.2858	.3429	.3429
23	.2477	.2286	.3048	.2096
24	.2096	.2286		.2858
Max	.9717	1.0288	1.0669	1.0269
Min	.1905	.1524	.1715	.1715
Avg	.4525	.4557	.5063	.4740

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 207 / 11KV VIKAS GINNING EXP  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381		.1143	.0381
2	.0381		.0762	.0381
3	.0381		.0762	.0381
4	.0381		.0572	.0381
5	.0381		.0572	.0381
6	.0572		.0381	.0381
7	.0572	.0762	.0381	
8		.0762	.0953	
9	.1524	.0762	.2096	.0953
10	.1143	.1334	.1524	
11	.0762	.0953	.2286	
12	.0572	.1334	.0953	
13	.1524	.0572		
14	.1143	.0953	.0762	
15	.0943	.1334	.0953	
16	.0747	.1334	.0762	
17	.1905		.1715	.0191
18	.2286	.0953	.1524	.0572
19	.1715	.0191	.1524	.0381
20	.0762		.0381	
21		.0762	.0381	
22	.0191	.0762	.0381	
23	.0381	.0762	.0381	
24	.0572			.0381
Max	.2286	.1334	.2286	.0953
Min	.0191	.0191	.0381	.0191
Avg	.0874	.0902	.0961	.0433



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 208 / Bodhaka Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.1905	.2667
2	.2286	.2286	.1905	.3048
3	.2286	.2096	.381	.3429
4	.2858	.2286	.7621	.381
5	.4572	.381	.9145	.4572
6	.6859	.8383	.9526	.6668
7	.8764	.9145	1.0098	.8962
8	.8002	.7621	.8764	.8402
9	.6287	.6097	.724	.6478
10	.4001	.4191	.4572	.2477
11	.2858	.2477	.2477	.2096
12	.1715	.2096	.2096	.2477
13	.1715	.2096	.2286	.1905
14	.1524	.2286		
15	.1867	.1905		.1905
16	.2054	.2667		.2477
17	.3429	.3239	.4001	.362
18	.5716	.4001	.5525	.5906
19	.7621	.743	.7468	.7049
20	.5716	.5716	.5788	.4954
21	.3429	.3429	.4191	.381
22	.2667	.2858	.3429	.3429
23	.2286	.2096	.2096	.2286
24	.2096	.2286		.1905
Max	.8764	.9145	1.0098	.8962
Min	.1524	.1905	.1905	.1905
Avg	.3863	.3866	.5197	.4101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 209 / 11 kv BAZARSAWANGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.1143		.1524
2		.1143	.1143	.1143	.1905
3		.1524	.1143	.1524	.2286
4		.1524	.1143	.3429	.3048
5		.2286	.1905	.4191	.3429
6		.3239	.4763	.4954	.381
7		.4763	.4572	.5144	.4954
8		.4001	.381	.4001	.4382
9	.2858	.3239	.2858	.3429	.2858
10		.1905	.2096	.2286	.1905
11		.0953	.1334	.1334	.1143
12		.0762	.1143	.1143	.0953
13		.0762	.1143	.1143	.0953
14		.0762	.0762	.0953	.0953
15		.0754	.0953	.0953	.0953
16		.0943	.0953	.0953	.1334
17		.1524	.1524	.1715	.2096
18		.3239	.2286	.2667	.3429
19		.362	.4001	.4763	.381
20		.3048	.362	.3429	.3239
21		.2477	.2286	.2286	.2477
22		.1334	.1143	.1905	.1905
23		.1143	.1143	.1143	.1334
24		.0953	.1143		.0762
Max	.2858	.4763	.4763	.5144	.4954
Min	.2858	.0754	.0762	.0953	.0762
Avg	.2858	.1952	.2000	.2477	.2310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 201 / 11 KV Bhadji AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	1.1279	1.1568	1.3108	1.17
12	1.5089	1.6741	1.491	1.1361
13	1.6309	1.5257	1.595	1.4575
14	1.4632	1.5424	1.3717	1.4403
15	1.448	1.5249	1.283	1.2483
16	1.2955	1.4586		1.1789
17	1.2041	1.3717	1.1218	1.2795
18	.9755	1.3375	1.1163	.9214
Max	1.6309	1.6741	1.595	1.4575
Min	.9755	1.1568	1.1163	.9214
Avg	1.3318	1.4490	1.3271	1.229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 202 / 11KV GADANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.5335	.6516	.6556
2		.463	.5792	.7373	.6733
3		.5144	.6401	.9774	.7265
4		.6001	.884	1.046	.8682
5		.7545	1.0212	1.2003	.9922
6		.9088	1.0822	1.4403	1.1871
7		1.5261	1.3108	1.6804	1.701
8		1.8176	1.6918	2.2462	2.2436
9		1.6289	1.6613	1.8176	2.1085
10		.1219	.132		.1886
11		.0762	.0943	.0943	.0943
12		.061	.0566	.0754	.0943
13		.061	.0566	.0762	.0754
14		.061	.0566	.0762	
15		.0457	.0566	.0754	
16		.061	.0566		
17		.0762	.0286	.0762	.0953
18		.1219	.0762	.1143	.1524
19		.1981	.1334	.2477	.2667
20		.1829	.1334	.2477	.2477
21		.1829	.1238	.2286	.2286
22	.1238		.1238	.1905	.1905
23	.1143	.1372	.1238	.1715	.1715
24		.3429	.4877	.583	.5735
Max	.1238	1.8176	1.6918	2.2462	2.2436
Min	.1143	.0457	.0286	.0754	.0754
Avg	.1191	.4502	.4643	.6388	.6445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 203 / 11 KV Bhandegaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1238		.2401	.1414
2		.1238		.1334	.1414
3		.1238		.1334	.1515
4		.1238		.1334	.1515
5		.1429		.1334	.1616
6		.1429		.1429	.1717
7		.1429		.1238	.1313
8		.1886		.0953	
9		.0857		.0857	.0808
10			.1132		.1132
11			.6952	.8848	.8309
12				1.0111	1.046
13			1.1736	1.1963	1.1317
14			1.0277	.8842	.8573
15			.9556	.8669	.8573
16			.8886	.8745	.8573
17			.9259	.7442	.8859
18			.7373	.7087	
19			.1143	.1212	.1189
20			.2058	.1111	.1212
21			.1334	.1387	.1387
22	.1238		.1334	.1486	.1414
23	.1238		.1334	.1288	.1387
24		.1238		.1334	.1414
Max	.1238	.1886	1.1736	1.1963	1.1317
Min	.1238	.0857	.1132	.0857	.0808
Avg	.1238	.1322	.5567	.3989	.3869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 204 / 11KV GADANA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0457	.0514	.0732
2		.0857	.0457	.0514	.0732
3		.0857	.0762	.0686	.0732
4		.12	.1219	.1029	.0905
5		.1372	.1677	.1543	.128
6		.2058	.1829	.2058	.2481
7		.2058	.2286	.2572	.2658
8		.2058	.1524	.2058	.2126
9		.1886	.1219	.1543	.1595
10		.0914	.0754		.1698
11		.0914	.0754	.1132	.0943
12		.0762	.0943	.0754	.0754
13		.0457	.0754	.0754	.0754
14		.061	.0377	.0754	.0754
15		.061	.0377	.0754	.0754
16		.0762	.0566	.0943	.1132
17		.0914	.1029	.1463	.1463
18		.1524	.1886	.1063	.2561
19		.2591	.2572	.3012	.2835
20		.1829	.1715	.1829	.2012
21		.1219	.12	.124	.1463
22	.1029		.0857	.0914	.1097
23	.0686	.061	.0686		.0732
24		.1029	.0457	.0514	.0732
Max	.1029	.2591	.2572	.3012	.2835
Min	.0686	.0457	.0377	.0514	.0732
Avg	.0858	.1200	.1098	.1257	.1372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 205 / 11 KV Takali R.R.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.2134	.1334	
2		.1334	.2134	.1334	.2667
3		.1334	.2286	.1334	.2667
4		.1334	.2286	.1334	.2667
5		.1334		.1429	.2667
6		.1334		.2743	.2858
7		.1334	.2286	.1524	.2858
8		.1429	.2286	.1715	.2858
9		.1334	.2134	.1429	.2667
10		.2134	.2452		.2452
11		1.448	1.2407	1.668	1.326
12		1.6766	2.0287	2.1052	1.6741
13		2.0881	2.1879	2.3834	1.8679
14		1.8595	2.3922	2.0405	1.861
15		2.3777	2.4086	2.2119	1.8442
16		2.3167	2.251	2.1776	
17		2.1338	2.2634	1.6872	1.4998
18		1.4784	1.6632	1.4842	1.3748
19		.2134	.1429	.2858	.2858
20		.2286	.1429	.3239	.2858
21		.2286	.1429	.2858	.2858
22	.1334		.1429	.2667	.2858
23	.1334	.2286	.2401	.2667	.2667
24		.1334	.2134	.1334	.2667
Max	.1334	2.3777	2.4086	2.3834	1.8679
Min	.1334	.1334	.1429	.1334	.2452
Avg	.1334	.7801	.8755	.8147	.7073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 206 / 11 KV TAKALI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.1829	.1715	.2096
2		.0857	.1677	.1543	.2096
3		.0667	.1981	.1543	.2286
4		.1372	.2743	.1886	.362
5		.1715	.381	.3601	.4954
6		.2058	.5792	.5144	.578
7		.2058	.7011	.7202	.6718
8		.1886	.5792	.6344	.6859
9		.12	.4725	.4973	.5335
10		.2439	.3772		.3584
11		.2286	.3018	.1509	.1886
12		.1524	.1886	.1509	.2263
13		.1067	.1886	.1509	.2075
14		.1067	.132		.2263
15		.1067	.1132		.1886
16		.1372	.1698	.1886	.2263
17		.2591	.2743	.3239	.381
18		.5487	.4801	.5525	.5716
19		.5944	.5487	.6859	.6478
20		.4877	.4801	.6478	.5716
21		.3353	.3429	.4763	.4001
22	.12		.3086	.3239	.3048
23	.0514	.2286	.2572	.2286	.2096
24		.0514	.1981	.1715	.2096
Max	.12	.5944	.7011	.7202	.6859
Min	.0514	.0514	.1132	.1509	.1886
Avg	.0857	.2096	.3291	.3546	.3705



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 207 / 11 KV Viramgaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.2286	.2058	.2926
2		.3601	.2743	.2572	.2743
3		.4115	.3353	.3601	.3258
4		.4287	.4725	.6859	
5		.463	.5944	.8916	.57
6		.6001	.7011	1.0288	.6483
7		.9945	.884	1.2174	.9998
8		1.4403	1.1431	1.6118	1.5154
9		1.2689	1.4175	1.5261	1.3123
10		.1524	.1886		.1509
11		.1067		.1132	.1132
12		.0762	.0754	.0754	.0943
13		.061	.1132	.0754	.0754
14		.061	.0754	.0754	.0754
15		.061	.0754	.0754	.0754
16		.0762	.0754	.0566	.0754
17		.0914	.0572	.0953	.0953
18		.1524	.0953	.1524	.1524
19		.1829	.1048	.2286	.2286
20		.1677	.0953	.1905	.1905
21		.1524	.0857	.1715	.1334
22	.0857		.1715	.1524	.1143
23	.0762	.0914	.0953	.1334	.1143
24		.2572	.1829	.1543	.2378
Max	.0857	1.4403	1.4175	1.6118	1.5154
Min	.0762	.061	.0572	.0566	.0754
Avg	.0810	.3463	.3279	.4145	.3420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 208 / 11KV NAKODA GINNING  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0038	.0305	.0038	.0122
2		.0038	.0305	.0038	.0122
3			.0305	.0038	.0122
4		.0038	.0305	.0038	.0122
5		.0038	.0305	.0038	.0122
6		.0038	.0305	.0038	.0122
7		.0038	.0305	.0038	.0122
8		.0038	.0305	.0038	.0122
9		.0038	.0305	.0038	.0126
10		.0305	.0126		.0377
11		.0305	.0377	.0126	.0377
12		.0305	.0126	.0126	.0126
13		.0305	.0126	.0126	.0126
14		.0305	.0126	.0126	.0126
15		.0305	.0377	.0126	.0114
16		.0305	.0126	.0126	.0114
17		.0305	.0038	.0122	.0122
18		.0305	.0038	.0122	.0122
19		.0305	.0038	.0122	.0122
20		.0305	.0038	.0122	.0122
21		.0305	.0038	.0122	.0122
22	.0038		.0038	.0122	.0122
23	.0038	.0305	.0038	.0122	.0122
24		.0038	.0305	.0038	.0122
Max	.0038	.0305	.0377	.0126	.0377
Min	.0038	.0038	.0038	.0038	.0114
Avg	.0038	.0196	.0196	.0087	.0143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 209 / 11KV LODHA STONE CRUSHER      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0686	.061	.0686	.0189
2		.0686	.061	.0686	.0189
3		.0857	.061	.0686	.0189
4		.0686	.061	.0686	.0189
5		.0686	.061	.0686	.0189
6		.0686	.061	.0686	.0189
7		.0686	.061	.0686	.0189
8		.0686	.061	.0686	.0189
9		.0686	.061	.0686	.0189
10		.061	.0754		
11		.061	.0943	.0377	
12		.0914	.0943	.0943	.0189
13		.0457	.0754	.0754	.0189
14		.061	.0377	.0754	.0189
15		.061	.0754	.1132	.1886
16		.0762	.0754	.0189	.1132
17		.0914	.0686	.0189	.0189
18		.061	.0686	.0189	
19		.061	.0686	.0189	.0189
20			.0686	.0189	.0189
21			.0686	.0189	.0189
22	.0857		.0686	.0189	.0189
23	.0857	.061	.0686	.0183	.0189
24		.0857	.061	.0686	.0189
Max	.0857	.0914	.0943	.1132	.1886
Min	.0857	.0457	.0377	.0183	.0189
Avg	.0857	.0691	.0674	.0536	.0315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 210 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0457	.0686	.0572
2		.0857	.0457	.0857	.0572
3		.12	.0457	.0857	.0572
4		.1543	.0762	.1029	.1143
5		.1715	.1067	.1372	.1646
6		.2058	.1372	.1886	.1905
7		.2401	.1524	.2572	.2286
8		.2572	.1524	.1715	.2477
9			.1372	.1886	.2286
10		.1524	.1132		.1698
11		.0914		.1132	.1132
12		.0762	.132	.0943	.0754
13		.061	.0943	.0754	.0754
14		.061	.0754	.0566	.0566
15		.0457	.0754	.0754	.0566
16		.0762	.0754	.1132	.0943
17		.1067	.12	.1143	.1334
18		.1981	.1715	.1524	.1334
19		.1829	.1886	.2096	.1905
20		.1524	.1715	.1715	.1905
21		.1067	.1372	.1334	.1334
22	.1029		.1029	.0762	.0762
23	.0857	.061	.0857	.0572	.0572
24		.0514	.061	.0686	.0572
Max	.1029	.2572	.1886	.2572	.2477
Min	.0857	.0457	.0457	.0566	.0566
Avg	.0943	.1231	.1088	.1216	.1233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 201 / 11 KV GALLE BORGAEON AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.1509	.1334
2		.1524	.1715	.1509	.1334
3		.1715	.2096	.1509	.1334
4		.1905	.2477	.1886	.1524
5		.2096	.2858	.2452	.1715
6		.2477	.3048	.3048	.1905
7		.3239	.3048	.3395	.2667
8		.2667	.3048	.3239	.3048
9		.2286	.2096	.1886	.2286
10		.1334	.2286	.2477	.1905
11		.4687	.4475	.5344	.5624
12		.5182	.4973	.57	.6478
13		.6154	.5801	.5182	.6036
14		.5571	.5967	.4687	.6299
15		.381	.431	.4999	.5735
16		.4268	.5801		.6226
17		.4694	.5636	.57	.4999
18		.3353	.4144	.431	.4111
19		.2096	.2667	.2667	.2477
20		.1905	.2263	.2477	.2477
21		.1905	.1886	.2096	.1905
22	.1715	.1905	.1698	.1905	.1715
23	.1715	.1715	.1698	.1715	.1715
24		.1524	.1524	.1509	.1715
Max	.1715	.6154	.5967	.57	.6478
Min	.1715	.1334	.1524	.1509	.1334
Avg	.1715	.2897	.3210	.3096	.3190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 202 / 11 KV Akhatwada AG. SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1875	.0914	.1294	.1326
2		.2031	.1107	.1646	.1326
3		.2401	.1457	.1629	.1492
4		.2591	.1619	.2149	.2155
5		.3239	.1802	.2743	.2652
6		.4096	.3277	.3521	.4144
7		.547	.4359	.4862	.7459
8		.6874	.8029	.7625	.8785
9		.7042	.6964	.5487	.8785
10		.1334	.1143	.1334	.0953
11		.0572	.0762	.0953	.0572
12		.056	.1143	.0762	.0572
13	.506	.0572	.0953	.0572	.0381
14		.0572	.0953	.0953	.0381
15		.0747	.0762	.1143	.0381
16		.0747	.0762		.0762
17		.0953	.1334	.0953	.0953
18		.1905	.1524	.1905	.1715
19		.2477	.2286	.2286	.2096
20		.1715	.1886	.2096	.1715
21		.1715	.1698	.1524	.1524
22	.1524	.1334	.1509	.1524	.1143
23	.1524	.1524	.1132	.1524	.1143
24		.1524	.0762	.1307	.1326
Max	.506	.7042	.8029	.7625	.8785
Min	.1524	.056	.0762	.0572	.0381
Avg	.2703	.2245	.2006	.2165	.2239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 203 / 11 KV Tisgaon Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1307	.1433	.1372
2		.1372	.1494	.1433	.1372
3		.1715	.1494	.1433	.1372
4		.208	.2743	.1791	.1715
5		.2686	.3258	.2507	.2058
6		.3841	.3982	.394	.2229
7		.5228	.4344	.5068	.3086
8		.4251	.4108	.4287	.4458
9		.3658	.3292	.3582	.3601
10		.3077	.2058	.2915	.2279
11		.1715	.0857	.1991	.1907
12		.1791	.1029	.0934	.1907
13		.1715	.1029	.1086	.1715
14		.1715	.1715	.1097	.1715
15		.1075	.1715	.1341	.1715
16		.1715	.1886		.1543
17		.2303	.2572	.2454	.2229
18		.4344	.3601	.3772	.4525
19		.439	.4458	.4458	.3898
20		.2801	.3403	.3258	.3361
21		.2801	.2195	.2743	.2229
22	.1734	.168	.1663	.1715	.1715
23	.1387	.1494	.1478	.1029	1.0802
24		.1543	.1307	.1433	.12
Max	.1734	.5228	.4458	.5068	1.0802
Min	.1387	.1075	.0857	.0934	.12
Avg	.1561	.2515	.2375	.2422	.2667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAON

Feeder No / Name : 204 / 11 KV Galleborgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0953	.0953	.1143	.0953
2			.0953	.0953	.1143	.0953
3			.1143	.1143	.1143	.1143
4			.1524	.1715	.1715	.1143
5	.1905		.1905	.2054	.2096	.1334
6			.2477	.2667	.2858	.1905
7			.3429	.3048	.3429	.2477
8			.3239	.3048	.2858	.2858
9			.2286	.2096	.2286	.2286
10			.1905	.1524	.1905	.1334
11	.1334		.1334	.1143	.1334	.1143
12			.1334	.0953	.1334	.1143
13			.1524	.1143	.1334	.1143
14			.1524	.1143	.1334	.1143
15			.1143	.1143	.1143	.1334
16			.1524	.1334	.1334	.1334
17			.1524	.1524	.1524	.1143
18			.1715	.2096	.1715	.1715
19			.2096	.2667	.2667	.2286
20			.1905	.2096	.2286	.2286
21			.1715	.1715	.1524	.1905
22		.1334	.1143	.1524	.1334	.1524
23		.1143	.1143	.1143	.0953	.1524
24			.0953	.0953	.1143	.0953
Max	.1905	.1334	.3429	.3048	.3429	.2858
Min	.1334	.1143	.0953	.0953	.0953	.0953
Avg	.1620	.1239	.1683	.1657	.1731	.1540



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 205 / 11 KV Palasgaon AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2587	.2105	.2715	.2486
2		.2896	.2429	.3045	.2818
3		.3506	.2915	.298	.2984
4		.3772	.3239	.3856	.3315
5		.5197	.3605	.583	.547
6		.6226	.6371	.8048	.8122
7		.8259	.8684	1.0395	.9945
8		1.0562	1.0898	1.2431	1.1768
9		.9069	1.0159	.9614	.9945
10		.0762	.0381	.0762	.0572
11		.0572	.0191	.0381	.0381
12		.0381	.0191	.0381	.0381
13		.0381	.0191	.0381	.0381
14		.0572	.0191	.0381	.0381
15		.0572	.0191	.0381	.0381
16		.0572	.0191	.0762	.0381
17		.0572	.0381	.0381	.0381
18		.0953	.0572	.0572	.0762
19		.1334	.1334	.1334	.0953
20		.1143	.1143	.1334	.1143
21		.1143	.1143	.1143	.0953
22	.1334	.0953	.0762	.0762	.0762
23	.1143	.0762	.0762	.0572	.0572
24		.2286	.1943	.2614	.1658
Max	.1334	1.0562	1.0898	1.2431	1.1768
Min	.1143	.0381	.0191	.0381	.0381
Avg	.1239	.2710	.2499	.2961	.2787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044065 / 33/11 KV GALLEBORGAEON

Feeder No / Name : 206 / 11 KV Pimpri AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2949	.3658	.3353
2		.298	.3353	.4024	.3856
3		.3601	.3856	.4119	.3887
4		.4527	.4862	.4382	.4096
5		.5365	.5868	.6516	.6464
6		.6796	.7712	.9088	.8951
7		.9503	.9724	1.1488	1.0774
8		1.2308	1.2929	1.2763	1.3757
9		1.1142	1.3426	1.094	1.4089
10		.1143	.0953	.1143	.1334
11		.0762	.0762	.0953	.0953
12		.0572	.0762	.0572	.0572
13		.0572	.0572	.0572	.0381
14		.0572	.0572	.0381	.0381
15		.0572	.0762	.0572	.0381
16		.0572	.0762	.0572	.0381
17		.0572	.0762	.0762	.0572
18		.1334	.1143	.1334	.1524
19		.2286	.1715	.2096	.2096
20		.1905	.1905	.1905	.1715
21		.1334	.1334	.1905	.1715
22	.1143	.1143	.0762	.1715	.1715
23	.0953	.0953	.0762	.1715	.1524
24		.2427	.2785	.3361	.2818
Max	.1143	1.2308	1.3426	1.2763	1.4089
Min	.0953	.0572	.0572	.0381	.0381
Avg	.1048	.3154	.3375	.3606	.3637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 202 / 11KV KANADGAON GAOTHAN FEEDER SEPERATION/PURE AG  
FEEDER Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2075	.2241	.1738	.1738
2			.2075	.2241	.1738	.1808
3			.2075	.2241	.1738	.1808
4			.4715	.4108	.1738	.2029
5			.5658	.5228	.2976	.9198
6			.5658	.5228	.4016	.3715
7			.5093	.5601	.3887	.3536
8			.4527	.3921	.3246	.3368
9	.2397		.3206	.3361	.2606	.257
10			.2241	.2829	.1882	.2641
11			.2241	.2263	.1738	.1886
12			.2241	.2263	.1635	.1886
13			.2241	.2075	.1486	.1886
14			.2241	.1132	.1738	.1886
15			.2241	.1886	.1486	.1698
16			.2427	.2263	.1337	.1886
17		.2075	.2427	.2641	.1614	.2452
18			.3734	.3961	.2029	.3395
19			.4854	.4527	.3788	.4904
20			.4294	.3772	.3382	.415
21			.3174	.3018	.2225	.3018
22			.2241	.1738	.1635	.2263
23		.2075	.2241	.1738	.1738	.2075
24			.2075	.2241	.1738	.1635
Max	.2397	.2075	.5658	.5601	.4016	.9198
Min	.2397	.2075	.2075	.1132	.1337	.1635
Avg	.2397	.2075	.3166	.3022	.2214	.2810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 201 / GINNING AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1715	.1829	.181
2	.1848	.1715	.1848	.1848
3	.2772	.1715	.1829	.2801
4	.3734	.2572	.2772	.3734
5	.3734	.3429	.4715	.4715
6	.5658	.5144	.5658	.5658
7	.5658	.5144	.5658	.5658
8	.5658	.5601	.5658	.5658
9	.4668	.4668	.4668	.4287
10	.3734	.3734	.3696	.2572
11	.3858	.3353	.4001	.3429
12	.5335	.3572	.3201	.3429
13	.3525	.4572	.3201	.5144
14	.4049	.4191	.4191	.4287
15	.4191	.4191	.4858	.4287
16	.3353	.3048	.4191	.3715
17	.4287	.381	.3582	.3715
18	.4287	.381		.3715
19	.4287	.4715	.5544	.4715
20	.3429	.3734	.3734	.3734
21	.2572	.2772	.3696	.3734
22	.2572	.2772	.2772	.2772
23	.2572	.2772	.2772	.2772
24	.2772	.1715	.1848	.1848
Max	.5658	.5601	.5658	.5658
Min	.1829	.1715	.1829	.181
Avg	.3766	.3519	.3736	.3752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 202 / 11 KVV- PAL-AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2572	.2286	.2686
2	.2286	.2572	.2286	.3582
3	.3048	.2572	.2286	.3544
4	.3048	.3429	.3086	.443
5	.381	.4287	.3858	.4477
6	.463	.5144	.4687	.6335
7	.5401	.7716	.6249	.8145
8	.6249	.8383	.703	.8954
9	.6783	.6706	.6706	.6859
10	.3734	.4668	.2772	.3429
11	.2743	.3734	.1791	.1715
12	.2801	.1867	.1848	.3429
13	.2801	.1867	.2801	.2572
14	.2772	.2429	.1848	.2572
15	.181	.16	.1848	.2572
16	.2801	.1848	.1791	.2772
17	.3429		.1867	.462
18	.4287	.2772		.5601
19	.3429	.4715	.4668	.5658
20	.3429	.4715	.3734	.5658
21	.2572	.2801	.3734	.5658
22	.1715	.2801	.3734	.3772
23	.1715	.2772	.3734	.3772
24	.2286	.2572	.2772	.2686
Max	.6783	.8383	.703	.8954
Min	.1715	.16	.1791	.1715
Avg	.3328	.3676	.3366	.4396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 203 / 11KV PHULAMBRI GAONTHAN SHEDDABLE URBAN  
FEEDER Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2572	.3429	.3506
2	.3429	.2572	.2572	.2658
3	.3429	.2572	.2572	.2686
4	.3506	.2572	.3467	.2686
5	.4525	.3429	.4477	.462
6	.6468	.6859	.6468	
7	.9431	.8573	.9431	.9431
8	1.0374	.9145	1.0374	1.0374
9	.924	.8954	.9335	.8573
10	.7392	.6268	.7164	.7716
11	.6401	.7164	.7164	.6001
12	.5316	.5373	.6268	.6001
13	.5487	.6401	.5373	.5144
14	.4334	.5544	.4477	.5144
15	.4382	.5373	.4477	.5144
16		.543	.443	.5373
17	.6001	.6401	.5373	.6268
18	.6859	.7392		.8402
19	.6859	.8402	.823	.8402
20	.6001	.7392	.7468	.7468
21	.5144	.6401	.6401	.5373
22	.4287	.4477	.4525	.4477
23	.3429	.3429	.3506	.3582
24	.3429	.2572	.3429	.3506
Max	1.0374	.9145	1.0374	1.0374
Min	.3429	.2572	.2572	.2658
Avg	.5615	.5636	.567	.5762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 205 / 11 KV DEOGIRI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.0857	.0876
2	.0857	.1715	.0857	.0895
3	.1791	.1715	.0857	.1848
4	.1848	.1715	.181	.1848
5	.2801	.2572	.2801	.2801
6	.3772	.3429	.3772	.2829
7	.4715	.3429	.4715	.4715
8	.4715	.4668	.3734	.4715
9	.3734	.3734	.2801	.3429
10	.2772	.2801	.181	.3429
11	.6944	.643	.7287	.6859
12	.7621	.643	.6687	.6859
13	.6944	.5716	.6687	.6859
14	.6773	.5268	.5201	.6859
15	.5792	.5335	.5944	.6001
16	.5935	.5468	.4515	.5716
17	.6001	.5468	.4401	.5201
18	.5144	.4687		.503
19	.2572	.3772	.3658	.3734
20	.2572	.2829	.2801	.2801
21	.1715	.1848	.1829	.181
22	.1715	.1848	.1791	.1867
23	.1715	.1848	.0867	.181
24	.1791	.1715	.0857	.0895
Max	.7621	.643	.7287	.6859
Min	.0857	.1715	.0857	.0876
Avg	.3796	.3590	.3328	.3737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 206 / 11KV BILDA AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3858	.4287	.3858	.3953
2	.3858	.5144	.4687	.4801
3	.463	.5144	.4687	.5601
4	.5335	.6001	.5468	.6554
5	.6173	.6859	.6249	.7716
6	.703	.8573	.7811	.9431
7	1.0936	1.286	1.2651	1.5061
8	1.5203	1.4861	1.4861	1.7337
9	1.3279	1.3717	1.3717	1.5432
10	.3696	.2801	.3734	.2572
11	.2801	.1867	.2629	.2572
12	.1829	.1867	.2686	.1715
13	.1867	.1867	.2829	.1715
14	.1867	.1886	.1867	.1715
15	.1867	.1886	.1867	.1715
16	.1867	.1715	.2801	
17	.2572	.2715	.2801	.2801
18	.3429	.3696		.3734
19	.4287	.4668	.4525	.4668
20	.3429	.3734	.3734	.3734
21	.2572	.2772	.2801	.2801
22	.1715	.2743	.2801	.1867
23	.1715	.2686	.1886	
24	.2286	.3429	.3906	.4049
Max	1.5203	1.4861	1.4861	1.7337
Min	.1715	.1715	.1867	.1715
Avg	.4504	.4907	.4994	.5525



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 207 / 11KV DARI-GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.1715	.1715	.2543
2	.2572	.1715	.1715	.2572
3	.3582	.1715	.1715	.2743
4	.4525	.2572	.3467	.3658
5	.5601	.4287	.4525	.6602
6	.8488	.7716	.7545	.9431
7	.9431	.8573	.9431	1.1317
8	.8488	.9335	.9335	.9431
9	.7468	.7468	.7392	.7716
10	.543	.4525	.4668	.6001
11	.362	.362	.2715	.3429
12	.2686	.2686	.2715	.2572
13	.2572	.181	.2715	.2572
14	.1696	.181	.1677	.2572
15	.2515	.1696	.1791	.3429
16	.2515	.2572	.1715	.2715
17	.2572	.3582	.3582	.4525
18	.6001	.6535		.7468
19	.6859	.8402	.8316	.8402
20	.5144	.5544	.6535	.6535
21	.3429	.4525	.4525	.362
22	.2572	.2572	.3429	.2715
23	.2572	.2572	.2515	.2715
24	.2572	.1715	.1715	.2543
Max	.9431	.9335	.9431	1.1317
Min	.1696	.1696	.1677	.2543
Avg	.4395	.4136	.4150	.4909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 208 / 11 KV WAREGAON- AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0867
2	.0857	.0857	.0857	.0876
3	.0857	.0857	.0857	.1753
4	.1848	.1715	.1772	.1753
5	.1848	.1715	.1867	.1753
6	.2829	.3429	.2829	.3429
7	.4715	.3429	.3772	.4382
8	.3772	.3734	.3734	.3506
9	.2572	.1715	.2572	.2572
10	.1715	.1715	.1715	.1715
11	.3467	.3048	.2629	.2572
12	.3906	.3048	.2286	.2572
13		.3048	.1524	.1715
14	.3391	.2343	.2286	.1715
15	.301	.1467	.2286	.1715
16	.3506	.1524	.1524	.2286
17	.2572	.1524	.1753	.2286
18	.3429	.2286		.1715
19	.2572	.2801	.2743	.2572
20	.1715	.2829	.1753	.2572
21	.1715	.1829	.181	.1715
22	.0857	.1848	.1753	.1715
23	.0857	.0876	.0876	.1715
24	.0857	.0857	.0857	.0867
Max	.4715	.3734	.3772	.4382
Min	.0857	.0857	.0857	.0867
Avg	.2336	.2056	.1953	.2097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 209 / 11 KV GADEKAR INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0914
2	.0857	.0857	.0857	.0924
3	.0857	.0857	.0857	.0886
4	.0857	.0857	.0857	.0886
5	.0857	.0857	.0857	.0876
6	.0857	.0857	.0857	.0934
7	.0857	.0857	.0857	.0762
8	.0857	.0934	.0934	.1867
9	.1867	.0943	.2686	.2572
10	.1753	.0943	.3582	.3429
11	.1829	.0943	.2743	.2572
12	.2686	.0943	.2686	.2572
13	.2686	.0686	.0943	.1715
14	.181	.0943	.2743	.0857
15	.362	.0943	.2829	.1715
16	.3582	.0857	.2686	.2829
17	.2572	.0895	.2686	.2829
18	.1715	.0876		.1886
19	.1715	.0857	.2601	.1886
20	.1715	.0857	.1772	.1886
21	.0857	.0857	.0914	.0943
22	.0857	.0857	.0867	.1886
23	.0857	.0857	.0857	.0857
24	.0857	.0857	.0857	.1829
Max	.362	.0943	.3582	.3429
Min	.0857	.0686	.0857	.0762
Avg	.1576	.0877	.1669	.1680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 202 / 11 KV BORGAON ARJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486	.1677	.1658	.4191
2	.2486	.1677	.1658	.4191
3	.2486	.1677	.1658	.4191
4	.3315	.1677	.2486	.503
5	.4973	.503	.3315	.503
6	.5735	.5868	.4973	.6706
7	.7373	.7545	.6554	.7545
8	.7373	.8383	.8192	.8383
9	.5735	.7545	.6554	.8383
10	.1886	.1886	.1886	.1886
11	.1886	.132	.1886	.1886
12	.0754	.0943	.1886	.1886
13	.0566	.0943	.0943	
14	.0943	.0943	.0943	.1886
15	.0943	.0943	.0943	.1886
16	.1132	.132	.1886	.1886
17	.132	.1886	.1886	.1509
18	.3206	.2829	.2829	.2263
19	.3206	.3772	.3772	.3772
20	.3206	.2829	.3772	.2829
21	.1886	.2829	.3772	.1886
22	.1886	.1886	.2829	.1886
23	.1886	.1509	.2829	.1886
24	.1658	.1677	.1658	.4191
Max	.7373	.8383	.8192	.8383
Min	.0566	.0943	.0943	.1509
Avg	.2847	.2858	.2949	.3704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 203 / 11 KV ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1886	.1509	.2829
2	.1509	.1886	.1509	.2829
3	.1509	.1886	.1509	.2829
4	.1886	.1886	.2263	.3772
5	.2829	.3206	.2829	.3772
6	.3772	.3772	.3961	.3772
7	.3772	.4715	.4715	.3772
8	.3772	.3772	.4715	.2829
9	.2829	.3206	.3772	.1886
10	.1886		.1886	.1886
11	.8718	.7545	.0381	.5868
12	.4191	1.2574	.503	.5868
13		.5868	.6706	.6706
14	.4191	.5868	.6706	.6706
15	.4191	.503		.6706
16	.4191	.503	.6706	.503
17	.4191	.4144	.5868	.4973
18	.9221	.4144	.503	.4973
19	.3206	.3772	.3772	.3772
20	.3206	.2829	.3772	.2829
21	.1886	.2829	.3772	.1886
22	.1886	.1886	.2829	.1886
23	.1509	.1509	.2829	.1886
24	.1509	.132	.1509	.2829
Max	.9221	1.2574	.6706	.6706
Min	.1509	.132	.0381	.1886
Avg	.3364	.3938	.3634	.3837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 204 / 11 KV PEDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.503	.4144	.4191
2	.4973	.503	.4144	.4191
3	.4973	.4191	.4144	.4191
4	.4973	.4191	.4144	.4191
5	.5801	.503	.4973	.503
6	.5735	.503	.5801	.503
7	.5735	.503	.5735	.503
8	.5735	.6706	.5735	.5868
9	.5735	.6706	.5735	.5868
10	.132	.1886	.1886	.1886
11	.132	.132	.1886	.1886
12	.0566	.0943	.1886	.1886
13	.0566	.0943	.0943	
14	.0943	.0943	.0943	.1886
15	.0943	.0943	.0943	.1886
16	.0566	.0943	.1886	.1886
17		.132	.1886	.132
18	.2829	.1886	.2829	.1886
19	.2829	.3206	.3772	.2829
20	.1886	.2829	.3772	.1886
21	.1886	.2829	.3772	.1886
22	.1886	.1886	.2829	.1886
23	.132	.1509	.2829	.1509
24	.4973	.5365	.4144	.4191
Max	.5801	.6706	.5801	.5868
Min	.0566	.0943	.0943	.132
Avg	.3151	.3154	.3365	.3143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 206 / 11 KV LOANEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.132	.132	.2829
2	.1509	.132	.132	.2829
3	.1509	.132	.132	.2829
4	.1886	.0943	.1886	.3772
5	.2829	.1886	.2829	.3772
6	.3772	.3206	.3772	.3772
7	.3772	.3772	.3772	.3772
8	.3772	.3772	.3772	.2829
9	.2829	.2452	.2829	.1886
10	.1698	.1886	.1886	.1886
11	1.0898	.9221	.8383	1.1736
12	1.3077	1.1736	1.0059	1.1736
13	1.2574	1.1736	1.0059	1.1736
14	1.0898	1.0898	1.0059	1.1736
15	1.0898	1.0059	1.0059	1.1736
16	.9221	.9221	.8383	.9221
17	.5868	.7459	.8383	.7459
18	.6706	.663	.6706	.663
19	.2829	.3772	.3772	.3772
20	.2452	.2829	.3772	.2829
21	.132	.2829	.3772	.1886
22	.1886	.1886	.2829	.1886
23	.1509	.1509	.2829	.1886
24	.1509	.132	.132	.2829
Max	1.3077	1.1736	1.0059	1.1736
Min	.132	.0943	.132	.1886
Avg	.4864	.4708	.4795	.5302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 201 / 11 kv Bodhegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.9335	.6687	.823
2	.2858	1.0288	.7373	.9431
3	.3429	1.1812	.8402	.9945
4	.3429	1.3146	.9259	1.1145
5	.3772	1.286	1.0117	1.2517
6	.4801	1.3717	1.1145	1.3717
7	.7716	1.406	1.166	1.4746
8	1.0288	1.4403	1.3889	1.406
9	.8573	1.3717	1.2689	1.2174
10	.4115	.3239	.4973	.4572
11	.2229	.2286	.3258	.2572
12	.2058		.2058	.2572
13	.1715	.2229		.2401
14	.2229	.2229	.2572	.2286
15	.2401	.2743	.3258	.2096
16	.2572	.3086	.2915	.3048
17	.4458	.2572	.4287	
18	.6173	.6001	.5144	.6173
19	.6516	.6173	.6687	.7545
20	.6859	.6516	.7373	.6173
21	.6668	.5144	.7888	.5144
22	.5335	.4801	.4973	.4115
23	.4763	.4287	.4115	.3944
24	.2286	.381	.4287	.3772
Max	1.0288	1.4403	1.3889	1.4746
Min	.1715	.2229	.2058	.2096
Avg	.4488	.7324	.6740	.7060



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 202 / 11 KV Babra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.4287	.3086	.3258
2	.1905	.4115	.3086	.3772
3	.2096	.3944	.3429	.4458
4	.2058	.3772	.3772	.4287
5	.2229	.3429	.3944	.4458
6	.3258	.3772	.4115	.4287
7	.5487	.4287	.4287	.4973
8	.5658	.4287	.4973	.463
9	.5658	.4287	.3944	.5487
24	.1143	.3772	.2572	.2743
Max	.5658	.4287	.4973	.5487
Min	.1143	.3429	.2572	.2743
Avg	.3102	.3995	.3721	.4235

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 203 / 11 Kv Nidhona SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4191	.3429	.4973
2	.5716	.4763	.3772	.5487
3	.6668	.5335	.4287	.6001
4	.7202	.5716	.4458	.6859
5	.9259	.6516	.4801	.823
6	1.0631	.7545	.5144	.8573
7	1.0288	.823	.5658	.9431
8	.8916	.8745	.5316	1.0288
9	.7545	.823	.3601	.823
10	.4973	.5658	.3944	.6478
11	.7202	.7888	.7373	.6097
12	.823	.823	.9088	.7621
13	.8573	.7716	1.0631	.8764
14	.9088	.7716	.9431	.703
15	.9431	.8573	.9945	.724
16	.9602	.7888	.9088	.6478
17	.8059	.8745	.7373	.583
18	.703	.703	.6687	.5144
19	.8002	.7202	.823	.9431
20	.8383	.7373	.8573	.7716
21	.724	.6859	.6859	.6516
22	.6097	.6173		.4973
23	.4763	.583	.5658	.4458
24	.4954	.4191	.5144	.4973
Max	1.0631	.8745	1.0631	1.0288
Min	.4763	.4191	.3429	.4458
Avg	.7633	.6931	.6456	.6951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 204 / 11KV LEHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4801	.5144	.4458
2	.4954	.5144	.6516	.4973
3	.5335	.5487	.6859	.5144
4	.5487	.6001	.7202	.5658
5	.6344	.6516	.823	.6516
6	.8916	.6859	.8573	.7373
7	.9259	.7545	.9431	.823
8	.8745	.7888	.9431	.7716
9	.703	.583	.6859	.5487
10	.4115	.4382	.4973	.4763
11	.2058		.3258	.1334
12	.1029		.1886	.1905
13		.1886	.3258	.1524
14	.1029	.1886	.2572	.1715
15	.1372	.1715	.2058	.2096
16	.1715	.1886	.12	.2667
17	.1886	.1715		.2058
18	.1543	.2572		.1886
19	.1715	.3086	.3086	.7202
20	.2572	.3429	.3429	.8573
21	.3429	.4287	.3944	.5658
22	.3772	.3772	.4973	.4458
23	.3601	.3601	.4458	.3772
24	.4191	.3429	.3429	.3772
Max	.9259	.7888	.9431	.8573
Min	.1029	.1715	.12	.1334
Avg	.4116	.4260	.5035	.4539

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 205 / 11KV NAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.5144	.5144	.4458
2	.1524	.5487	.5487	.5658
3	.1715	.6001	.583	.6516
4	.1715	.6516	.6173	.7373
5	.1715	.6859	.6516	.8402
6	.2572	.7202	.6859	.9431
7	.5487	.7716	.7202	.8573
8	.583	.8059	.8573	.823
9	.6516	.8059	.7373	.8745
10	.2229	.2229	.3429	.2858
11	.1029	.1905	.1886	.1334
12	.0686	.0514	.0686	.1143
13	.0857	.0686	.12	.0953
14	.0686	.0514	.0857	.1143
15	.0514	.0686	.1029	.1143
16	.0686	.1029	.0857	.0762
17	.1715	.12	.2229	.1372
18	.3944	.3944	.3086	.4115
19	.4115	.4115	.3429	.6516
20	.4287	.4801	.4458	.5487
21	.3772	.3429	.5144	.3772
22	.3429	.3772	.4287	.2743
23		.3086	.3772	.2572
24	.1334	.3429	.3429	.3086
Max	.6516	.8059	.8573	.9431
Min	.0514	.0514	.0686	.0762
Avg	.2508	.4016	.4122	.4433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 206 / 11KV KHAMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.4763	.3772	.6001
2	.3048	.5335	.3772	.6687
3	.3429	.5716	.4287	.823
4	.4191	.6097	.4801	.9431
5	.4572	.6001	.4973	1.1145
6	.5487	.6516	.4973	1.3546
7	.6173	.6859	.4973	1.4232
8	.6173	.703	.5144	1.286
9	.4801	.6859	.5487	1.2003
10	.4801	.4801	.5658	.4954
11	.4287	.381	.3772	.3086
12	.1715	.2915	.2572	.2858
13	.1715	.2572	.3086	.2229
14	.1372		.3429	.1905
15	.1715			.1143
16	.2572	.2058	.3772	.3048
17	.381	.703	.4801	.3772
18	.6859	.7202	.5658	.6859
19	.8002	.7545	.6001	.9602
20	.7545	.5144	.7095	.7545
21	.6001	.4801	.7373	.5487
22	.5716	.4287	.5144	.4115
23	.5335	.3429	.4801	.3772
24	.2286	.4763	.3429	.4287
Max	.8002	.7545	.7373	1.4232
Min	.1372	.2058	.2572	.1143
Avg	.4345	.5252	.4729	.6617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 201 / 11 kv Shevata SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	.1029	.0886	.0876
2	.0876	.0857	.0886	.0876
3	.0867	.0857	.1063	.0867
4	.1029	.1029	.1227	.1029
5	.1357	.1372	.1402	.1526
6	.1844	.1543	.1753	.1989
7	.1989	.1886	.2103	.3315
8	.1989	.2058	.2454	.2294
9	.2155	.1715	.2103	.1966
10	.6859	.2743	.2829	.3018
11	.1715	.2263	.1698	.1509
12	.1372	.1132	.0943	.0943
13	.0857	.0943	.0754	.0754
14	.0686	.132	.0943	.0566
15	.0514	.132	.0943	.0754
16	.1029	.1132	.132	.0566
17	.1715	.1698	.2075	
18	.4287	.5093	.4715	.3206
19	.3772	.5658	.4904	.4715
20	.2915	.4527	.3961	.3475
21	.2572	.3395	.3206	.2641
22	.2058	.2641	.2641	.3395
23	.1715	.1886	.2263	.2075
24	.0876	.1372	.0886	.0876
Max	.6859	.5658	.4904	.4715
Min	.0514	.0857	.0754	.0566
Avg	.1914	.2061	.1998	.1880

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 202 / 11 kv NARLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0514	.0532	.0526
2	.0526	.0514	.0532	.0526
3	.0693	.0686	.0709	.052
4	.0857	.0857	.1052	.0686
5	.1187	.12	.1402	.1187
6	.1677	.1372	.2279	.1677
7	.2155	.1543	.3155	.2321
8	.1658	.1543	.3155	.2622
9	.1823	.2058	.298	.213
10	.1543	.1372	.0943	.2075
11	.0857	.0566		.0886
12	.0686	.0566		.0754
13	.0686	.0566	.0566	.0566
14	.0514		.0566	.0566
15	.0514		.0754	.0566
16	.12	.0943	.0754	.0732
17	.1029	.1509	.1509	.1132
18	.1943	.3206	.3395	.2743
19	.2915	.4338	.3772	.3361
20	.2401	.3395	.3018	.2829
21	.1715	.1886	.2075	.1886
22	.0857	.1132	.0943	.1132
23	.0857	.0754	.0943	.0943
24	.0526	.0514	.0532	.0526
Max	.2915	.4338	.3772	.3361
Min	.0514	.0514	.0532	.052
Avg	.1223	.1411	.1617	.1371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 203 / 11 kv Pathri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.3772	.4572	.4338
2	.4527	.4115	.4527	.4338
3	.547	.4801	.5281	.4715
4	.811	.7202	.7922	.811
5	1.2071	1.1317	1.226	1.2826
6	1.4901	1.406	1.5497	1.6032
7	1.6598	1.5089	1.6057	1.6598
8	1.5655	1.406	1.6221	1.6221
9	.7167	1.3032	1.2449	1.3769
10	.3429	.3772	.8488	.8488
11	.4801	.5083	.3932	.3856
12	.4458	.3721	.3113	.3641
13	.3772	.333	.2881	.3155
14	.3258	.333	.2561	.2515
15	.3086	.3721	.2267	.2374
16	.3086	.3429	.3113	.3086
17	.3258	.4207		.439
18	.5144	.4908	.5144	.5487
19	1.2517	1.4901	1.6221	1.4523
20	1.0288	1.1317	1.2637	1.1022
21	.7202	.9054	.8865	.7865
22	.4801	.679	.6036	.6413
23	.4458	.4715	.4527	.4755
24	.4527	.4115	.4572	.4338
Max	1.6598	1.5089	1.6221	1.6598
Min	.3086	.333	.2267	.2374
Avg	.6963	.7243	.7789	.7619



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 204 / 11kv Wadod Bazar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1886	.1402	.1417
2	.1753	.1715	.1595	.1417
3	.2103	.2058	.1772	.1753
4	.2572	.2401	.2103	.2401
5	.3222	.3258	.3189	.3222
6	.4024	.4115	.4557	.4191
7	.5304	.5487	.5609	.5636
8	.5636	.6859	.6661	.6962
9	.5304	.5487	.5258	.5407
10	.7373	.6344	.3772	.7922
11	.4801	.4338	.5281	.4338
12	.4287	.3772	.415	.4024
13	.3944	.3772	.415	.3052
14	.3601	.3772	.415	.3772
15	.3772	.3772	.3772	.3772
16	.4801	.4715	.4527	
17	.5658	.6413	.6036	.567
18	.8573	.8865	.8299	.7545
19	.7888	.8865	.8488	.7356
20	.5658	.7545	.679	.6413
21	.4458	.6036	.547	.5281
22	.3258	.4527	.4338	.415
23	.2743	.2829	.2829	.3395
24	.1595	.2058	.1402	.1417
Max	.8573	.8865	.8488	.7922
Min	.1595	.1715	.1402	.1417
Avg	.4337	.4620	.44	.4370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 205 / 11 KV RAJENDRA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.3429	.4904	.679
2	.6224	.3772	.5281	.6413
3	.6036	.4115	.5093	.6036
4	.6224	.4115	.5281	.5658
5	.5281	.3429	.5281	.5093
6	.415	.4115	.5601	.415
7	.3961	.3944	.5041	.3018
8	.2641	.3086	.3206	.2641
9	.7545	.583	.7356	.2641
10	.6859	.583	.679	.2829
11	.6859	.6602	.6602	.6767
12	.6687	.6413	.679	.6539
13	.6344	.5093	.4715	
14	.6516	.3584		.567
15	.6516	.7167	.679	.6661
16	.6173	.6979	.679	.7619
17	.583	.6979	.6979	.7973
18	.5658	.679	.6413	.7087
19	.4801	.547	.4715	.5218
20	.3601	.5281	.4527	.4527
21	.3772	.4904	.6602	.811
22	.3944	.4904	.6602	.8299
23	.4973	.4715	.7922	.811
24	.6979	.4458	.4904	.7356
Max	.7545	.7167	.7922	.8299
Min	.2641	.3086	.3206	.2641
Avg	.5591	.5042	.5834	.5878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 201 / 11KV JATEGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.0934	.1494	.1494
2		.1307	.0934	.1494	.168
3		.1307	.0934	.1494	.168
4		.1494	.0934	.168	.1867
5		.168	.112	.1867	.1867
6		.1867	.1307	.2054	.2054
7		.168	.1307	.2241	.2241
8		.1307	.0934	.168	.168
9		.0934	.0934	.1494	.1494
10		.056	.0934	.0747	.0373
11		.4854	.1829	.3462	.2241
12		.4854		.4064	.3174
13		.3734	.2591	.3462	.3174
14		.3734	.3258	.3161	.3174
15		.3174	.2743	.2559	
16		.3174		.2258	
17	.0747	.3734	.3353	.2559	.3734
18	.1307	.3174	.2743	.2559	.3547
19		.112	.112	.1307	.112
20	.1307	.1307	.1307	.1494	.112
21	.1307	.0934	.1494	.1307	.112
22	.1307	.0934	.1494	.1307	.0934
23	.1307	.0934	.1494	.1494	.0934
24		.1307	.0914	.1494	.1494
Max	.1307	.4854	.3353	.4064	.3734
Min	.0747	.056	.0914	.0747	.0373
Avg	.1214	.2100	.1573	.2031	.1918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 202 / 11KV DHAMANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1486	.1494	.1715	.1505
2		.1505	.1867	.1715	.1656
3		.1806	.1867	.1886	.1957
4		.1957	.3734	.2058	.1981
5		.2408	.3734	.2915	.2134
6		.2896	.5601	.3429	.2591
7		.3906	.7095	.5243	.4365
8		.506	.6535	.6226	.5268
9		.5601	.5228	.5792	.4668
10		.056	.056	.0373	.0747
11		.056	.056	.0373	.056
12		.056	.056	.0187	.056
13		.056	.0373	.0187	.056
14		.0373		.0187	.056
15		.0373	.0373	.0187	.0373
16		.0373	.0373	.0187	.0373
17	.4064	.0373	.0373		.0373
18	.4064	.0366	.0373	.0373	.0373
19	.056	.056	.056	.056	.056
20	.056	.0934	.056	.0373	.056
21	.0373	.0934	.0373	.056	.056
22	.0373	.0934	.0373	.0373	.056
23	.0373	.0934	.0373	.0373	.056
24		.1189	.1494	.1543	.1355
Max	.4064	.5601	.7095	.6226	.5268
Min	.0373	.0366	.0373	.0187	.0373
Avg	.1481	.1509	.1932	.1601	.1448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 203 / 11KV BABHULGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0373	.0373	.056
2		.0373	.0373	.0373	.056
3		.056	.0373	.0373	.056
4		.056	.056	.056	.056
5		.056	.056	.056	.056
6		.0747	.0747	.0747	.056
7		.0747	.0747	.0747	.0747
8		.0747	.0373	.056	.0747
9		.0373	.0373	.056	.056
10		.3361	.0373	.0373	.056
11		.5228	.5601	.4268	.5601
12		.7468	.3353	.4967	.5601
13		.8402	.3048	.5268	.5601
14		.724	.2591	.4877	.3734
15		.6535	.2896	.4365	.3734
16		.6401	.3048	.4365	.3734
17	.0373	.6535	.4572	.4214	.3734
18	.056	.7468	.2743	.4214	.3361
19	.056	.056	.0373	.056	.0373
20	.056	.0373	.056	.056	.0373
21	.0373	.0373	.056	.056	.0373
22	.0373	.0373	.0373	.056	.0373
23	.0373	.0373	.0373	.056	.0373
24		.0373	.0373	.0373	.056
Max	.056	.8402	.5601	.5268	.5601
Min	.0373	.0373	.0373	.0373	.0373
Avg	.0453	.2754	.1472	.1872	.1812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 204 / 11 KV JATEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2218	.2241	.2195	.2054
2		.2218	.2241	.2195	.2241
3		.2427	.2241	.2378	.2614
4		.3772	.2801	.4066	.3921
5		.6722	.6535	.6348	.7282
6		.8962	.9709	.9709	.9522
7		1.0269	1.0082	1.1203	1.0642
8		.8775	.9335	.8775	.8589
9		.7468	.7468	.7468	.7655
10		.5601	.5121	.4481	.3734
11		.2743	.3361	.2587	.2801
12		.2241	.2801	.181	.2614
13		.2241	.1829	.181	.1867
14		.2241	.0914	.1629	.1494
15		.1867	.1646	.1448	.112
16		.1829	.2012	.1629	.1494
17	.3921	.4108	.3292	.1646	.1867
18	.8402	.5601	.7282	.2801	.6722
19	.9149	.5601	.7468	.9896	.7842
20	.6161	.5228	.6161	.6348	.6535
21	.3734	.3361	.4294	.3921	.3734
22	.2587	.2801	.2987	.2801	.2801
23	.2218	.2058	.2195	.2241	.2241
24		.2218	.2241	.2195	.2054
Max	.9149	1.0269	1.0082	1.1203	1.0642
Min	.2218	.1829	.0914	.1448	.112
Avg	.5167	.4274	.4427	.4233	.431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 205 / 11KV SULTANWADI

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1286	.0934	.12	.1337
2		.1486	.1494	.1372	.1505
3		.1486	.1867	.1372	.1505
4		.1505	.1867	.1543	.1505
5		.1656	.2801	.1715	.1806
6		.2258	.0373	.2401	.2559
7		.3462	.3734	.4096	.3763
8		.4666	.5228	.4915	.6171
9		.4668	.5788	.5335	.7095
10		.0187	.0187	.0181	.0187
11		.0187	.0187	.0181	.0187
12		.0187	.0187	.0179	.0187
13		.0187	.0189	.0181	.0187
14		.0187		.0181	.0187
15		.0187	.0187	.0181	.0187
16			.0189	.0181	.0187
17	.2709	.0187	.0189		.0187
18	.2709	.0187	.0189	.0179	.0187
19	.0179	.0187	.0187	.0181	.0187
20	.0181	.0373	.0187	.0181	.0187
21	.0181	.0187	.0187	.0181	.0187
22	.0181	.0187	.0187	.0181	.0187
23	.0181	.0187	.0187	.0181	.0187
24		.1337		.12	.1189
Max	.2709	.4668	.5788	.5335	.7095
Min	.0179	.0187	.0187	.0179	.0187
Avg	.0903	.1149	.1206	.1196	.1294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 201 / 11KV KINGAON AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2126	.1966	.2915	.2454
2		.2658	.2675	.3401	.3086
3		.3429	.3041	.3795	.3521
4		.3601	.3418	.3906	.3647
5		.4409	.4923	.5155	.431
6		.57		.8905	.5967
7		.8097		1.0311	.9069
8		.7773		1.1883	1.085
9		.8745		1.0059	1.085
10		.2075		.2829	.2075
11		.1715		.2075	.1867
12		.1387		.1886	.1307
13		.12			.1307
14		.12		.1509	.1494
15		.1387	.2263	.1509	.1867
16		.1372	.1509	.1886	.1867
17		.1715	.2075	.1886	.2054
18		.1886	.2829	.132	.2402
19		.2743	.3772	.4527	.3511
20		.2601	.2829	.3961	.2218
21		.2229	.2452	.3086	.1867
22		.1734	.2263	.3018	.1886
23	.1698	.156	.1886	.2641	.1698
24		.1791	.1715	.2949	.1928
Max	.1698	.8745	.4923	1.1883	1.085
Min	.1698	.12	.1509	.132	.1307
Avg	.1698	.3047	.2641	.4148	.3463



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 202 / 11KV PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0943	.0743	.0943	.056
2		.0754	.0869	.0943	.056
3		.112	.1014	.112	.0934
4		.1867	.1429	.1463	.0934
5		.2378	.1882	.2195	.1867
6		.3077	.2172	.2865	.2801
7		.3439	.2317	.2629	.2987
8		.362	.2751	.2835	.2614
9		.2743	.2317	.2772	.2614
10		.1663	.2054	.168	.1848
11		.0914	.1307	.056	.1478
12		.0762	.0754	.0934	.112
13		.0579	.0934		.056
14		.0446	.056	.0754	.056
15		.0594		.0934	.0747
16		.0743		.0934	.0934
17		.0892		.1494	.1294
18		.1635	.1646	.1494	.2033
19		.2317	.1829	.2241	.2743
20		.2229	.1848	.168	.1478
21		.1738	.1132	.1307	.1109
22		.0892	.1132	.112	.0934
23	.0934	.0743	.0934	.0747	.0754
24		.0943	.0743	.0943	.056
Max	.0934	.362	.2751	.2865	.2987
Min	.0934	.0446	.056	.056	.056
Avg	.0934	.1543	.1446	.1504	.1418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 203 / 11KV GANORI AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1355		
2		.1698	.1543		
3		.1867	.1715		
4		.1867	.208		
5		.2054	.2743		
6		.2218			
7		.2743			
8		.2957			
9		.2427			
10		.2427			
11		.7385		.8907	
12		.9808		1.186	.5144
13		.9846		1.1227	.8097
14		1.0551		1.0526	.8802
15		.7964	1.2483	1.1984	1.5278
16		.9214	1.3125		1.4842
17		1.0425	1.078	1.1469	1.0936
18		.7876	1.0467	1.1305	.7449
19		.1886		.3395	.3658
20		.2427		.2829	.3511
21		.2572		.2641	.2772
22		.2058		.2452	.2427
23	.1886	.1715		.2075	.2452
24		.1509	.1204		.2263
Max	.1886	1.0551	1.3125	1.1984	1.5278
Min	.1886	.1509	.1204	.2075	.2263
Avg	.1886	.4458	.5750	.7556	.6741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 204 / 11 KV DONGERGAON-SHIRODI      SEPARATED AG FEEDERS HAVING SPECIAL  
 AG      Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0724	.1543	.1619	.2103
2		.0905	.1448	.1875	.2012
3		.0905	.1882	.2429	.2321
4		.1075	.2675	.3239	.2347
5		.1075	.2896	.4111	.373
6		.1075	.4489	.5535	.4973
7		.1417	.6805	.6554	.8421
8		.1417	.9122	.8592	.8583
9		.1772	.6287	.1781	.8192
10		.168	.1132	.0189	.132
11		.1029	.0943	.0189	.0747
12		.0693	.0566	.132	.0566
13		.0514	.0377	.0754	.0566
14		.052	.0566	.0754	.0754
15		.0686	.0377	.0754	.1509
16		.0867	.0566	.0566	.0754
17		.0857	.0754	.0943	.0934
18		.1734	.132	.1509	.1867
19		.1715	.2263	.2263	.2241
20		.1734	.2075	.1886	.1867
21		.1543	.1698	.1698	.1698
22		.1029	.1509	.1509	.1132
23	.1132	.1029	.132	.1509	.0943
24		.1448	.1372	.1619	.2126
Max	.1132	.1772	.9122	.8592	.8583
Min	.1132	.0514	.0377	.0189	.0566
Avg	.1132	.1143	.2249	.2217	.2571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 205 / 11 KV WAREGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1663	.1303	.1886	.3361
2		.1663	.1303	.2241	.3734
3		.2195	.1715	.2987	.3921
4		.4024	.1715	.4938	.4294
5		.6516	.5213	.6135	.6348
6		.7716	.6093	.7362	.7842
7		.7716	.724	.8589	.8402
8		.7164	.5213	.5121	.5788
9		.5731	.4054	.5788	.5975
10		.3801	.4668	.5228	.3547
11		.1882	.2829	.2241	.1829
12		.1448	.2075	.2054	.1663
13		.104	.1867	.1494	.1478
14		.104	.1494	.1307	.1494
15		.0579	.168	.168	.168
16		.0724	.1867	.2054	.2218
17		.2824	.3174	.2801	.362
18		.4904	.567	.4668	.5552
19		.5213	.8413	.8029	.6984
20		.6093	.6984	.6348	.6447
21		.5053	.567	.5975	.439
22		.2172	.4572	.5228	.3696
23	.2012	.1738	.3395	.4294	.2587
24		.1848	.1448	.2241	.3174
Max	.2012	.7716	.8413	.8589	.8402
Min	.2012	.0579	.1303	.1307	.1478
Avg	.2012	.3531	.3736	.4195	.4168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 206 / 11 KV WANEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3018	.2743	.2452	.3018
2		.2829	.2947	.2641	.3018
3		.3018	.2743	.3018	.3395
4		.3395	.3294	.3395	.3395
5		.3696	.3429	.3961	.3961
6		.4024	.3601	.3749	.4904
7		.462	.4458	.4715	.4527
8		.3881	.3944	.3772	.4338
9		.2987	.3018	.3018	.3018
10		.1509	.2075	.2075	.3018
11		.5937	.4534	.5847	
12		.543	.5218	.6413	.6203
13		.5502	.4843	.6554	.3155
14		.6093	.4374	.6154	.3155
15		.4633	.4062	.6554	.3121
16		.4755	.5121	.6464	.3772
17		.3909	.5937	.639	.4115
18		.4054	.5921	.6299	.463
19		.2401	.3395	.3772	.3206
20		.2774	.3206	.3395	.3018
21		.2915	.3206	.3395	.3018
22		.2401	.3018	.3395	.3018
23	.2829	.2601	.2829	.3395	.3018
24		.2829	.2743	.2641	.3018
Max	.2829	.6093	.5937	.6554	.6203
Min	.2829	.1509	.2075	.2075	.3018
Avg	.2829	.3717	.3777	.4311	.3610

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 201 / 11 KV PIRBAWADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1848	.1905	.1905	.181
2		.1715	.1524	.2096	.2058
3		.2374	.1905	.2667	.2374
4		.2652	.1905	.3258	.2458
5		.2972	.2858	.4115	.2812
6		.3506	.4191	.5144	.3658
7		.4108	.6348	.583	.4755
8		.4755	.6516	.5898	.4694
9		.4531	.5068	.5716	.4214
10		.3961	.4191	.3429	.3772
11	.2241	.2035	.2477	.2641	.3429
12	.218	.1265	.1905	.2452	.3048
13		.16	.2477	.2263	.2096
14		.1562	.1905	.2075	.2286
15	.3201	.1898	.2096	.2075	.2096
16	.4321	.1875	.2477	.2641	.2667
17	.3506	.2812	.3048	.3395	.3429
18	.3658	.567	.6097	.6036	.6097
19	.6224	.7049	.8002	.7356	.743
20	.4904	.4382	.5716	.5093	.4954
21	.3772	.4191	.4382	.415	.4382
22	.3206	.3048	.4191	.3429	.3429
23	.2829	.2667	.4191	.2667	.2858
24		.1524	.1905	.1715	.1867
Max	.6224	.7049	.8002	.7356	.743
Min	.218	.1265	.1524	.1715	.181
Avg	.3640	.3083	.3637	.3669	.3445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 202 / 11 KV RANJANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1509	.1143	.1334	.1132
2			.1509	.1524	.1334	.1698
3			.1886	.1905	.1524	.2452
4			.2452	.1905	.1905	.3206
5			.3395	.3048	.4572	.4338
6			.4904	.5716	.5716	.5658
7			.6224	.7095	.6478	.6979
8			.6036	.543	.6287	.4904
9	.1326		.3772	.362	.4763	.3961
10			.2263	.2286	.2477	.2263
11		.1132	.0678	.0686	.0819	.0953
12		.0943		.0572	.0838	.0686
13		.0754	.064	.0686	.0914	.1006
14		.0754	.0469	.1029	.0625	.1134
15		.0754	.0633	.0762	.0648	.0829
16		.0566	.0625	.0686	.0339	.0838
17		.2263	.0625	.1143	.0503	.0819
18		.4338	.1063	.1143	.1132	.1696
19		.5093	.4954	.5525	.5658	.5525
20		.3584	.3048	.4001	.3772	.362
21		.2452	.2286	.2667	.2452	.2667
22		.1886	.1334	.2096	.1524	.1905
23		.132	.1143	.1715	.1143	.1334
24			.1334	.1143	.1334	.0953
Max	.1326	.5093	.6224	.7095	.6478	.6979
Min	.1326	.0566	.0469	.0572	.0339	.0686
Avg	.1326	.1988	.2295	.2397	.2420	.2523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 203 / 11 KV GEOVRAI PAIGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2263	.2667	.2667	.2641
2		.2641	.3048	.2858	.3018
3		.3395	.381	.3429	.3206
4		.4527	.5335	.4572	.3584
5		.5658	.6859	.6859	.3772
6		.7167	.8764	.8383	.7095
7		.9431	1.0456	1.0288	1.0456
8		.8299	.8688	.9145	.9335
9		.6413	.6516	.7621	.1886
10		.3395	.4572	.4191	.4904
11	.2263	.4748	.2915	.2812	.4656
12	.1886	.6009	.4572	.4268	.5144
13	.1132	.7362	.6316	.535	.5365
14	.1132	.6249	.5182	.4108	.5182
15	.1509	.6325	.4191	.4755	.4641
16	.1886	.6562	.6154	.5335	.4694
17	.3018	.5312	.6154	.4531	.426
18	.679	.567	.5506	.5281	.407
19	.7922	.8383	.8383	.8676	.7621
20	.6413	.4954	.6097	.5658	.6097
21	.415	.381	.4954	.4527	.4572
22	.3772	.3048	.381	.3584	.2667
23	.2263	.2667	.3048	.2286	.2667
24		.2263	.2667	.2667	.2286
Max	.7922	.9431	1.0456	1.0288	1.0456
Min	.1132	.2263	.2667	.2286	.1886
Avg	.3395	.5273	.5444	.5160	.4742



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 201 / 11KV GEVRAE GUNGI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1341	.3353	.0838	.1677
2		.1677	.4191	.1677	.2515
3		.1677	.4191	.2515	.503
4		.2515	.503	.4191	.503
5		.4191	.503	.5868	.5868
6		.3353	.4191	.5868	.5868
7		.503	.503	.503	.6706
8		.5868	.5868	.6706	.6706
9		.503	.503	.503	.4191
10		.2829	.2829	.2829	.2829
11		.2829	.1886	.1886	.1886
12		.1886	.132	.1886	.2829
13		.1886	.1132	.1886	.1886
14		.2829	.1132	.1886	.1886
15		.1886	.1132	.1886	.1886
16		.2829	.1132	.1886	.1886
17		.3772	.1886	.1886	.2829
18		.4715		.3772	.3772
19	.4715	.3772		.5658	.4715
20	.3772	.2829	.3772	.2829	.2829
21	.2829	.1886	.2829	.2829	.1886
22	.1886	.2829	.1886	.1886	.1886
23	.1132	.1886	.0943	.0943	.2829
24		.2515		.0838	.3353
Max	.4715	.5868	.5868	.6706	.6706
Min	.1132	.1341	.0943	.0838	.1677
Avg	.2867	.2994	.3038	.3021	.3449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044107 / GEVRAI GUNGI S/S

Feeder No / Name : 202 / kolte takli

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.4191	.2515	.4191
2		.3353	.3353	.3353	.503
3		.4191	.503	.4191	.6706
4		.503	.5868	.503	.7545
5		.6706	.5868	.6706	.7545
6		.503	.6706	.7545	.8383
7		.6706	.7545	.6706	.9221
8		.7545	.9221	.8383	.9221
9		.6706	.8383	.6706	.6706
10		.5658	.4715	.4715	.4715
11		.1886	.2829	.2829	.3772
12		.2829	.1886	.1886	.2829
13		.1886	.1886	.1886	.1886
14		.2829	.1886	.1886	.1886
15		.1886	.1886	.1886	.1886
16		.2572	.1886	.2829	.1886
17		.5658	.3772	.3772	.3772
18		.9431	.7545	.7545	.5658
19	.9431	.7545	1.0374	.8488	.8488
20	.7545	.6602	.7545	.7545	.7545
21	.5658	.5658	.5658	.5658	.5658
22	.4715	.4715	.4715	.4715	.3772
23	.3772	.3772	.3772	.3772	.2829
24		.3353		.2515	.3353
Max	.9431	.9431	1.0374	.8488	.9221
Min	.3772	.1677	.1886	.1886	.1886
Avg	.6224	.4718	.5066	.4711	.5187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 201 / FARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6219			.3734
2		.6722			.4024
3		.6584			.4024
4		.695			.5304
5		.7468			.6584
6		.8048			.7682
7		.8779			.8962
8	1.0288	.8573	.7545	.9877	.9259
9	1.0288	.8573	.7888	.9145	.8916
10	.8573	.823	.7202	.8215	.6859
11	.8916	.7545	.583	.7316	.823
12	.9259	.6859	.5487	.6447	.8573
13	.9945	.6516	.5487	.5373	.9259
14	.9602	.6516	.583	.5373	.8916
15	.823	.5487	.583	.5731	.8573
16	.8779			.5853	
17	.8048			.6447	
18	.8779			.7095	
19	.9877			.8048	
20	.9145			.7316	
21	.8413			.6722	
22	.5853			.5853	
23	.5853			.4481	
24		.6219			.4024
Max	1.0288	.8779	.7888	.9877	.9259
Min	.5853	.5487	.5487	.4481	.3734
Avg	.8741	.7206	.6387	.6831	.7058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 202 / 11KV JANGLA GAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5121			.1463
2		.5487			.1097
3		.5487			.1097
4		.5853			.1097
5		.6219			.1831
6		.6219			.3292
7		.695			.439
8	.1715	.2401	.2401	.1791	.3429
9	.2058	.2058	.1372	.1463	.3086
10	.583	.1372	.1029	.1097	.583
11	.7202	.1029	.0686	.0366	
12	.823	.0686	.0686	.0366	.823
13	.823	.0686	.0686	.0366	.7888
14	.8573	.0686	.0686	.0366	.7202
15	.8573	.0686	.0686	.0732	.6859
16	.8063			.1097	
17	.6584			.1463	
18	.2195			.1829	
19	.2561			.2195	
20	.2195			.2614	
21	.1829			.2241	
22	.4755			.1829	
23	.4755			.1829	
24		.5121			.1494
Max	.8573	.695	.2401	.2614	.823
Min	.1715	.0686	.0686	.0366	.1097
Avg	.5209	.3504	.1029	.1353	.3886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 203 / 11 K V PALASKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6584			.8048
2		.6584			.8954
3		.695			.9877
4		.7316			1.0974
5		1.0608			1.2437
6		1.2071			1.3535
7		1.0974			1.3535
8	.9945	.8916	1.0631	.9511	1.0288
9	.8573	.8573	1.0288	.9145	.9945
10	.4801	1.2689	1.5089	1.4998	.6173
11	.4801	1.6804	1.6118	1.6118	.4801
12	.4801	1.749	1.5775	1.6827	.4115
13	.4458	1.7147	1.4403	1.6834	.3772
14	.4801	1.6118	1.3717	1.6461	.3772
15	.4801	1.5775	1.3032	1.5729	.3772
16	.4908			1.4998	
17	.6805			1.3253	
18	.7522			.7468	
19	.8063			.8413	
20	.7712			.8048	
21	.7316			.7682	
22	.695			.7316	
23	.6584			.7682	
24		.6219			.8048
Max	.9945	1.749	1.6118	1.6834	1.3535
Min	.4458	.6219	1.0288	.7316	.3772
Avg	.6428	1.1301	1.3632	1.1905	.8253

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 206 / MJP EXPRESS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0343			
2			.0351			.0366
3			.0351			
4			.0351			
5			.0351			.0343
6			.0351			.0366
7			.0351			
8	.0038	.0343	.0038	.0038	.0328	.0038
9	.0038	.0038	.0038	.0038	.0328	.0038
10	.0038	.0038	.0038	.0038	.032	.0038
11	.0038	.0038	.0038	.0038	.0328	.0038
12		.0038	.0038	.0038	.0335	.0038
13		.0038	.0038	.0038	.0328	.0038
14		.0038	.0038	.0038	.0328	.0038
15		.0038	.0038	.0038	.032	.0038
16		.0328			.0328	
17		.0343			.0335	
18		.0351			.0351	
19		.0351			.0351	
20		.0351			.0358	
21		.0351			.0366	
22		.0351			.0328	
23		.0351				
24			.0343			.0351
Max	.0038	.0351	.0351	.0038	.0366	.0366
Min	.0038	.0038	.0038	.0038	.032	.0038
Avg	.0038	.0212	.0194	.0038	.0335	.0144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 207 / AJANTHA CAVES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0351			
2			.0358			
3			.0351			.0343
4			.0351			
5			.0351			
6			.0351			
7			.0351			.0351
8	.0038	.0038	.0038	.0038	.0328	.0038
9	.0038	.0038	.0038	.0343	.0335	.0038
10	.0076	.0076	.0038	.0076	.0655	.0038
11	.0076	.0076	.0038	.0076	.0983	.0076
12	.0076	.0076	.0038	.0076	.1006	.0076
13	.0076	.0076	.0038	.0076	.1006	.0076
14	.0076	.0076	.0038	.0076	.0983	.0076
15	.0076	.0076	.0038	.0076	.0983	.0076
16		.0625			.0983	
17		.0686			.0671	
18		.0343			.0351	
19		.0351			.0351	
20		.0351			.0358	
21		.0351			.0351	
22		.0351				
23		.0343			.0328	
24			.0351			.0366
Max	.0076	.0686	.0358	.0343	.1006	.0366
Min	.0038	.0038	.0038	.0038	.0328	.0038
Avg	.0067	.0246	.0195	.0105	.0645	.0141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 209 / Tondapur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	2.2977	2.2977	2.6543	2.4006
11	3.0521	2.5034	2.8502	2.572
12	3.155	2.7092	2.7199	
13	3.0864	2.6749	2.5926	2.6063
14	3.0521	2.5377	2.556	2.572
15	2.915	2.4006	2.5149	2.4691
16			2.3922	
17			2.13	
Max	3.155	2.7092	2.8502	2.6063
Min	2.2977	2.2977	2.13	2.4006
Avg	2.9264	2.5206	2.5513	2.524



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 201 / 11KV BANOTI-AG- FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	1.3717	1.1431	1.5051
2	1.3336	1.3336	1.1431	1.5242
3	1.3336	1.3336	1.2193	1.5242
4	1.3717	1.3717	1.2574	1.5242
5	1.3717	1.3717	1.4861	1.5623
6	1.448	1.4861	1.7147	1.6385
7	1.6385		1.829	1.829
22	1.3336	1.448	1.4289	1.3336
23	1.3717	1.3336	1.4289	1.3146
24	1.2955	1.3717	1.2574	1.4861
Max	1.6385	1.4861	1.829	1.829
Min	1.2955	1.3336	1.1431	1.3146
Avg	1.3793	1.3802	1.3908	1.5242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 202 / 11 KV NANDGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.3336	1.0669	1.2193	1.1431
11	1.8099	1.3336	1.3717	1.4098
12	2.0957	1.6385	1.2955	1.5623
13	1.9052	1.7528	1.448	1.6004
14	1.7147	1.4861	1.6766	1.5242
15	1.6766	1.2955	1.7337	1.6004
16	1.6004	1.6004	1.6766	1.6004
17	1.4861	1.2955	1.5242	1.6194
22			.1334	
Max	2.0957	1.7528	1.7337	1.6194
Min	1.3336	1.0669	.1334	1.1431
Avg	1.7028	1.4337	1.3421	1.5075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 203 / 11 K V WAKADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2667	.1905	.4191
2	.3429	.2286	.2286	.4572
3	.381	.2286	.2286	.4572
4	.381	.2667	.2667	.4954
5	.381	.3429	.3048	.4954
6	.4954	.381	.4572	.5716
7	.6097		.6478	.5335
22	.2286	.381	.381	.362
23	.2286	.4191		.3429
24	.3429	.2286	.3048	.4191
Max	.6097	.4191	.6478	.5716
Min	.2286	.2286	.1905	.3429
Avg	.3734	.3048	.3344	.4553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 204 / 11 KV BANOTI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524
2	.1524	.1524	.1524	.1524
3	.1905	.1905	.1905	.1905
4	.3048	.4001	.3048	.3048
5	.724	.6287	.6859	.5906
6	.724	.8192	.9145	.8764
7	.8764		.9526	1.0288
8	.7049		.9145	.9526
9	.6859	.4001	.7811	.8192
10		.381	.4191	.4191
11	.2286	.2096	.1905	.2096
12	.1905	.1524	.1334	.1524
13	.1524	.1143	.1334	.1334
14		.1334	.1334	.1334
15	.1143	.1334		.1334
16	.2096	.1905		.2096
17	.362	.2286	.381	.3048
18	.743	.7621	.8002	.6859
19	.6859	.8192	.8383	.6478
20	.4191	.4954	.4763	.4954
21	.3048	.3429	.3239	.2667
22	.2286	.1905	.1715	.1715
23	.1524	.1715	.1524	.1524
24	.1905	.1524	.1524	.1524
Max	.8764	.8192	.9526	1.0288
Min	.1143	.1143	.1334	.1334
Avg	.3862	.3282	.4252	.3890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 205 / Hanumantkheda gaothan  
 feeder Feeder KV- 11 /  
 OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1334	.1334	.0762
2	.1905	.1143	.1334	.1334
3	.2286	.1334	.1715	.1715
4	.2667	.2096	.2286	.2286
5	.362	.3048	.2667	.3239
6	.5144	.4191	.4191	.4572
7	.5335		.381	.4382
8	.4382		.3429	.3048
9	.3429	.3239	.2858	.381
10	.2286	.1905	.1524	.1905
11	.1905	.1334	.1524	.1143
12		.1143	.0953	.1143
13	.1143	.0953	.0953	.1143
14	.0953	.1334	.0762	.0953
15	.0953	.1143	.0762	.1334
16	.1334	.1334	.1334	.1334
17	.2096	.1905	.1715	.0953
18	.2667	.2286	.2096	.2096
19	.3239	.3429	.3429	.3429
20	.2477	.3048	.3048	.2477
21	.1905	.1905	.2096	.1905
22	.1715	.1524	.1715	.1334
23	.1334	.1334	.1334	.1143
24	.1334	.1334	.1143	.1334
Max	.5335	.4191	.4191	.4572
Min	.0953	.0953	.0762	.0762
Avg	.2435	.1923	.2001	.2032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 206 / Wakdi Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191
3	.0381	.0381	.0381	.0381
4	.1143	.0762	.1143	.0762
5	.1524	.1143	.1524	.1334
6	.2858	.2667	.3048	.2667
7	.3429		.2858	.2858
8	.2858		.2667	.2667
9	.2096	.1905	.1905	.2096
10	.0762	.1143	.0572	.0953
11	.0381	.0572	.0191	.0381
12	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0381
14	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191
16	.0191	.0381	.0381	.0381
17	.0381	.0762	.0572	.0381
18	.1334	.1905	.1334	.1524
19	.1905	.2286	.2096	.1905
20	.1334	.1905	.1143	.1143
21	.0953	.1143	.0572	.0762
22	.0381	.0381	.0191	.0191
23	.0191	.0381	.0191	.0191
24	.0191	.0191	.0191	.0191
Max	.3429	.2667	.3048	.2858
Min	.0191	.0191	.0191	.0191
Avg	.0977	.0866	.0921	.0921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 207 / 11 KV GONDEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.4954	.7621
2	.6859	.724	.4954	.8002
3	.724	.724	.5335	.8002
4	.724	.724	.6097	.8383
5	.7621	.7621	.6478	.8764
6	.8383	.9145	.8764	.9145
7	1.1431		.8383	1.2193
22	.6859	.4954	.6859	.7621
23	.7621	.5335	.724	.7621
24	.6859	.7621	.4572	.7621
<b>Max</b>	<b>1.1431</b>	<b>.9145</b>	<b>.8764</b>	<b>1.2193</b>
<b>Min</b>	<b>.6859</b>	<b>.4954</b>	<b>.4572</b>	<b>.7621</b>
<b>Avg</b>	<b>.7697</b>	<b>.7113</b>	<b>.6364</b>	<b>.8497</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 208 / 11 K V HANUMANT KHEDA SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	1.1812	1.2955	1.105	1.1431
11	1.7528	1.4861	1.5242	1.5242
12		1.8671	2.0195	1.7528
13	2.0005	1.9814	1.6766	1.829
14	2.1338	1.9433	1.5623	1.8671
15	2.0957	1.6004	1.7909	1.7909
16	1.9052	1.7147	1.7528	1.8671
17	1.829	1.5242	1.5242	1.6766
Max	2.1338	1.9814	2.0195	1.8671
Min	1.1812	1.2955	1.105	1.1431
Avg	1.8426	1.6766	1.6194	1.6814



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 209 / 11 KV GONDEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1715	.1715
2	.1715	.1524	.1715	.1715
3	.2286	.1715	.2286	.2286
4	.3429	.2667	.3429	.3429
5	.4572	.4191	.4191	.4191
6	.724	.6859	.6478	.6859
7	.7621		.724	.7621
8	.6859		.7621	1.448
9	.4954	.5716	.4954	.4954
10	.381	.4572	.381	.3048
11	.2667	.3048	.2667	.2096
12	.2286	.2667	.1905	.1905
13	.1905	.2286	.1905	.1905
14	.1905	.1905	.1905	.1905
15	.2286	.2286	.2286	.1524
16	.2286	.2286	.2286	.1905
17	.3048	.2667	.3048	.2286
18	.4572	.4954	.4572	.381
19	.5335	.6097	.4954	.5335
20	.381	.4572	.4572	.381
21	.2667	.3429	.3048	.2858
22	.1905	.2286	.2286	.1905
23	.1524	.1905	.1905	.1524
24	.1905	.1524	.1715	.1524
Max	.7621	.6859	.7621	1.448
Min	.1524	.1524	.1715	.1524
Avg	.3429	.3213	.3437	.3525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 201 / 11 K V SOYEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164				.6401
10					.4024
24		.6584	.2865	.2987	
Max	.7164	.6584	.2865	.2987	.6401
Min	.7164	.6584	.2865	.2987	.4024
Avg	.7164	.6584	.2865	.2987	.5213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 202 / 11 K V GALWADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853		.2374		.5487
6			.7164		
9		.5281	.4481		
10		.4801	.6081		.4588
12		.7362	.8848		
15		.852			
17		.7362			
20		.394			
21		.3658			
23					.5312
24		1.1706	.2507	.2507	
Max	.5853	1.1706	.8848	.2507	.5487
Min	.5853	.3658	.2374	.2507	.4588
Avg	.5853	.6579	.5243	.2507	.5129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 203 / JARANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2241	.2195	.1829	.1875
6			.394	.2614	
7				.2614	
9		.2641	.439		
10		.4801			.4915
12		.7209	.7727		
17		.7682		.7682	
20		.3582		.3582	
21		.2926			
24		.2263	.2149	.1829	
Max	.2195	.7682	.7727	.7682	.4915
Min	.2195	.2241	.2149	.1829	.1875
Avg	.2195	.4168	.4080	.3358	.3395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 205 / 11KV LIHA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	21-DEC-17
HR	Load (MW)
1	.032
10	.0339
Max	.0339
Min	.032
Avg	.0330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 203 / 11 kv MOLKHEDA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	16-DEC-17	17-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
24	1.3336	1.2955	1.2574
Max	1.3336	1.2955	1.2574
Min	1.3336	1.2955	1.2574
Avg	1.3336	1.2955	1.2574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 204 / 11 KV SAWALADBARA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Max	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Avg	.0953	.0762	.0762	.0762	.0762	.0762	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 201 / 11 KV KINHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572	.0381	.0381
2			.0572	.0381	.0381
3		.0572	.0572	.0381	.0381
4		.0572	.0572	.0381	.0381
5		.0572	.0572	.0381	.0381
6		.0572	.0762	.0381	.0381
7		.0572		.0572	.0381
8		.0572		.0572	.0381
9		.0381	.0572	.0572	
10		1.0395	1.1142	1.1498	
11		1.1405	1.4098	1.2308	
12		1.3125	1.7147	1.3927	
13		1.5339	1.7337	1.6194	
14		1.6404	1.848	1.4998	
15		1.4842	1.6956	1.5023	
16		1.5154	1.7147	1.4089	
17		1.4529	1.7528	1.3927	
18		.0762	.0572	.0381	
19		.0953	.0572	.0381	
20		.0953	.0572	.0381	
21		.0953	.0572	.0381	
22	.0381	.0953	.0381	.0381	
23	.0381	.0953	.0381	.0381	.0191
24		.0381	.0762	.0381	.0381
Max	.0381	1.6404	1.848	1.6194	.0381
Min	.0381	.0381	.0381	.0381	.0191
Avg	.0381	.5282	.6266	.4943	.0362



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 202 / 11 KV KINHI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	15-DEC-17	16-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2477	
2	.2477		
3	.2858		
4	.362		
5	.4954		
6	.6668		
7	.6478		
8	.5144		
9	.5144		
10	.3429		
11	.2477		
12	.2096		
13	.1905		
14	.2096		.2286
15	.2286		
16	.2096		
17	.3429		
18	.5144		
19	.5335		
20	.381		
21	.3429		
22	.3239		
23	.2858		.3048
24	.2667	.2477	
Max	.6668	.2477	.3048
Min	.1905	.2477	.2286
Avg	.3588	.2477	.2667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 203 / 11 KV WADGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	21-DEC-17
HR	Load (MW)
14	.0381
23	.5335
Max	.5335
Min	.0381
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 201 / 11Kv Ghosla new  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3239	.2286
2		.362	.3429
3		.4382	.4001
4		.5144	.4763
5		.5906	.5906
6		.6859	.724
7		.724	.8002
8		.6859	
9	.5144		
10	.8954	1.0479	
11	1.3908	1.2574	
12	1.6004	1.3146	
13	1.7337	1.3908	
14	1.5432	1.2193	
15	1.5051	1.2003	
16	1.4289	1.1622	
17	1.2193	1.1241	
18	.5906	.4382	
19	.6097	.5906	
20	.4382	.4954	
21	.362	.362	
22	.2286	.2286	
23	.1905	.1715	
24		.2667	.1715
Max	1.7337	1.3908	.8002
Min	.1905	.1715	.1715
Avg	.9501	.7215	.4668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 202 / 11Kv Bahulkheda new  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.4382	.4954
2		.4763	.5525
3		.5144	.6097
4			.6668
5			.7621
6			.8764
7			.9335
9	.5525		
10	1.1241	1.086	
11	1.2574	1.2384	
12	1.6575	1.3908	
13	1.848	1.6385	
14	1.7909	1.5623	
15	1.6385	1.448	
16	1.6575	1.3908	
17	1.3527	1.3336	
18	.6478	.5144	
19	.5716	.6859	
20	.5144	.5525	
21	.4572	.4763	
22	.4191	.4191	
23	.381	.381	
24		.4763	.4382
Max	1.848	1.6385	.9335
Min	.381	.381	.4382
Avg	1.0580	.8902	.6668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 203 / 11Kv Jarandi new  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	18-DEC-17	19-DEC-17	20-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.8002	.8954
2		.8764	.9526
3		.8192	.8764
4		.9145	.9335
5		.9526	.9717
6		.9907	1.0098
7		1.1241	1.2765
8		.5144	
9	.4382		
10	.2858	.3048	
11	.1905	.2286	
12	.2096	.2286	
13	.1905	.2096	
14	.2286	.2096	
15	.2096	.2096	
16	.2286	.2477	
17	.2667	.2667	
18	.4954	.3429	
19	.5144	.4954	
20	.4382	.4001	
21	.3239	.3048	
22	.7049	.8383	
23	.7049	.8954	
24		.743	.8573
Max	.7049	1.1241	1.2765
Min	.1905	.2096	.8573
Avg	.3620	.5616	.9717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 201 / 11 KV WADALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4431	.4596	.5169	.6251
2	.4431	.4412	.5169	.6653
3	.6092	.5516	.5908	.7762
4	.8677	1.0112	.8677	1.0903
5	1.0708	1.2686	1.1815	1.1827
6	1.4031	1.4157	1.5138	1.2752
7	1.44	1.3973	1.44	1.3306
8	1.1815	1.2502	1.3292	1.2567
9	.9231		1.2923	1.0164
10	2.9169	3.1071	2.4738	2.7721
11	3.299	3.2861	3.1623	3.4743
12	3.5373	3.6923	3.4374	3.308
13	3.8122		3.3265	3.2526
14	3.8306	3.7292	2.7536	3.5113
15	4.0138	3.9507	3.3634	3.4004
16	3.8425	3.8769	3.1786	3.4374
17	3.7572	3.7661	3.1786	3.2526
18	.9897		.8131	.8871
19	1.3196	1.3661	1.3676	1.4045
20	1.0997		1.2197	1.1399
21	.8064	1.0338	.924	.8089
22	.5883	.7015	.7023	.5516
23	.5132	.5538	.6468	.478
24	.4431	.4765	.5169	.6251
Max	4.0138	3.9507	3.4374	3.5113
Min	.4431	.4412	.5169	.478
Avg	1.7980	1.8668	1.6797	1.7301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 202 / 11KV NIMDONGRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3309	.3299	.3309	.3241
2	.3309	.3299	.3309	.3421
3	.4596	.4765	.4229	.3961
4		.6232	.5699	.5041
5		.7148	.7354	.6662
6		.7514	.8273	.8462
7		.7698	.9376	.9362
8		.7148	.8273	.8642
9		.4949	.5516	.6301
10	1.9304	2.0894	2.1878	2.6684
11	2.5109	2.8497	2.8086	3.0266
12	2.6576	3.199	3.2047	3.0787
13	2.7309		3.1687	3.0247
14	2.7492		3.0803	3.0247
15	2.8775	3.0152	3.1341	2.8807
16	2.8225	3.2358	2.8654	2.4486
17	2.6026	2.8865	2.8117	2.7366
18	.6048	.4964	.4656	.5041
19	.6598	.7722	.7701	.7022
20	.5865	.6986	.6268	.5401
21	.5132	.6067	.5373	.4681
22	.4215	.4412	.4656	.3781
23	.3677	.3493	.3403	.2881
24	.3309	.3493	.3309	.3421
Max	2.8775	3.2358	3.2047	3.0787
Min	.3309	.3299	.3309	.2881
Avg	1.4160	1.1907	1.3472	1.3175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 203 / 11 KV NANDGIRWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.6097	.7621	.703
2	.5716	.6097	.8002	.6588
3	.6097	.6478	.8383	.6935
4	.6478	.724	.8954	.7282
5	.6859	.7621	.9717	.7802
6	.8764	.8192	1.086	.9588
7	1.2193	1.1431	1.3908	1.1854
8	.8954	.7621		.7845
9	.743	.5716	.6668	.5927
10	.4572	.4382	.4763	.3429
11	.3239	.2477	.333	.3086
12	.2858		.2615	.2774
13	.3048	.3048	.208	.2427
14	.2667	.2477		.2229
15	.2477	.2477	.2427	.2401
16	.3048	.2858	.2427	.2229
17	.3429	.362	.2915	.2743
18	.6478	.6097	.5144	.5487
19	.7621	.8192	.7282	.6859
20	.6859	.7049	.6588	.6001
21	.6287	.6287	.4854	.5316
22	.5144	.6668	.6588	.6344
23	.5716	.6859	.6859	.6516
24	.5716	.5906	.724	.6859
Max	1.2193	1.1431	1.3908	1.1854
Min	.2477	.2477	.208	.2229
Avg	.5724	.5865	.6328	.5648



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 204 / 11KV HIWARKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7019	.7545	1.1756	1.2336
2	.7545	.7896	1.2283	1.2512
3	.7896	.8423	1.3336	1.2865
4	.8247	.8773	1.4038	1.4098
5	.8598	.9651	1.4739	1.5156
6	1.0177	1.0879	1.6494	2.1148
7	1.5617	1.8424	2.246	2.3086
8	1.1405	1.105	.7545	.934
9	1.0879	.8773	.8773	.793
10	.8247	.7896	.5089	.6344
11	.5966	.5264	.3919	.4406
12	.4913	.4387		
13	.544	.4387	.4961	
14	.4738	.4211		.423
15	.579	.4211	.4758	.423
16	.6492	.4562	.4934	.4758
17	.7896	.6317	.6344	.5992
18	.93		.934	.8283
19	1.0177	1.0704	1.1279	.8988
20	.9124	.8598	.9516	.793
21	.7721	.7896	.6873	.7225
22	.7019	1.0002	.6697	1.258
23	.7194	1.1055	1.216	1.4627
24	.6492	.737	1.1405	1.1984
Max	1.5617	1.8424	2.246	2.3086
Min	.4738	.4211	.3919	.423
Avg	.8079	.8186	.9941	1.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 205 / 11KV BAHIRGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5623	1.829	1.5089
2	1.5242	1.5813	1.829	1.5278
3	1.5242	1.6194	1.8671	1.5655
4	1.5623	1.7147	1.9052	1.6032
5	1.6004	1.7528	1.9814	1.6221
6	1.8671	1.829	2.0957	2.2445
7	2.4387	2.2481	2.553	2.4897
8	1.4098	1.2384		1.1506
9	1.086	.9145	1.1622	.9054
10	.8002	.8002	.9145	.679
11	.4382	.3429	.5308	.4338
12	.381	.3239	.4338	.4715
13	.4001	.3429	.3772	.4715
14	.3239	.2858	.3772	.415
15	.3048	.381	.3772	.4527
16	.4382	.3429	.4715	.5281
17	.6859	.6478	.7167	.7545
18	1.1241	.8764	1.0751	1.0562
19	1.2574	1.3527	1.358	1.2826
20	1.0669	1.1622	1.0562	1.0562
21	.9907	1.0669	.9099	.8488
22	1.4861	1.6766	1.6871	1.6787
23	1.5242	1.7909	1.6032	1.6598
24	1.4861	1.5242	1.829	1.6032
Max	2.4387	2.2481	2.553	2.4897
Min	.3048	.2858	.3772	.415
Avg	1.1352	1.1407	1.2583	1.1671

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 201 / 11 KV WADNER AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.853	.9431	.853	.854
2		.853	.9774	.853	.854
3		.853	1.2003	.853	.854
4		.9305	1.4575	.9305	.854
5		1.0856	1.8004	1.008	.854
6		1.1631	1.8861		.854
7		1.1631	1.5432		.9316
8		.0775	.0857		.0776
9		.0775	.0857		.0776
10		.0775	.0857		.0311
11		.0775	.0857		.0311
12		.0857	.0465		.0343
13		.0857	.0465	.0311	.0343
14		.0857	.0465	.0466	.0343
15		.0857	.0465	.0466	.0343
16		.0857	.0465	.0466	
17		.0857	.0465	.0466	.0857
18		.0857	.0775	.0776	.0857
19		.0857	.0775	.0776	.0857
20		.0857	.0876	.0776	.0857
21		.0857	.0876	.0776	.0857
22		.8573	.8764	.854	.8573
23	.853	.8573	.853	.854	.9431
24		.853	.8573	.853	.854
Max	.853	1.1631	1.8861	1.008	.9431
Min	.853	.0775	.0465	.0311	.0311
Avg	.853	.4432	.5561	.4463	.4127

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 202 / 11 KV AMBA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.5144	.8645	.9831
2		.9431	.6001	.8645	
3		.9431	.6859	.8645	
4		.9431	.8573	.9431	.9831
5		1.1003	.9431	1.0217	1.065
6		1.1788	1.2003	1.1003	1.1469
7		1.2574	1.5432	1.2574	1.065
8		.0786	.0857	.0786	.0983
9		.0786	.0857	.0786	.0819
10		.0786	.0857	.0786	.0819
11		.0786	.0857	.0786	.0328
12			.0472	.0819	.0343
13			.0472	.0819	.0343
14		.0857	.0472	.0819	.0343
15		.0857	.0472	.0328	.0343
16		.0857	.0472	.0328	
17		.0857	.0472	.0492	.0857
18		.0857	.0786	.0983	.0857
19		.0857	.0786	.0983	.0857
20		.0857	.0876	.1147	.0857
21		.0857	.0876	.0983	.0857
22		.4287	.8764	.9012	.9431
23	.8645	.4287	.8645	.9831	.9431
24		.9431	.463	.8645	.9831
Max	.8645	1.2574	1.5432	1.2574	1.1469
Min	.8645	.0786	.0472	.0328	.0328
Avg	.8645	.4595	.3961	.4479	.4273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 203 / 11 KV KOLWADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0774	.0857	.0774	.0465
2		.0774	.0857	.0774	.0465
3		.0774	.0857	.0774	.0492
4		.0774	.0857	.0774	.0774
5		.0774	.0857	.0774	.0774
6		.0774	.0857	.0774	.0774
7		.0774	.0857	.0774	.0774
8		.0774	.0857	.0774	.0774
9		.0774	.0857		.0465
10		.9282	1.286	.9282	1.0068
11		1.8564	1.8861	1.7017	1.5489
12		2.4006	1.9338	2.0885	2.1434
13		2.3148	2.0885	2.1658	2.4006
14		1.8861	1.547	2.2587	2.0233
15		1.9719	1.7017	2.1658	1.8861
16		2.1434	1.8564	2.0885	
17		2.2291	1.8564	2.0111	1.6289
18		.0857	.0774	2.0111	.0857
19		.0857	.0774	.0774	.0857
20		.0857	.0876	.0774	.0857
21		.0857	.0876	.0774	.0857
22		.0857	.0876	.0774	.0857
23	.0774	.0857	.0876	.0774	.0857
24		.0774	.0857	.0774	.0774
Max	.0774	2.4006	2.0885	2.2587	2.4006
Min	.0774	.0774	.0774	.0774	.0465
Avg	.0774	.7091	.6466	.8045	.6002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 204 / 11 KV MUNDWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0701		.0526	.0876
2		.0701	.0857	.0526	.0876
3		.0739	.1543	.0526	.0876
4		.0701	.2572	.0701	.0876
5		.0876	.3429	.0876	.1052
6		.1052	.4115	.0876	.1052
7		.1052	.3772	.0876	.0876
8		.0701	.2401	.0876	.1052
9		.0701	.1715	.0701	.1052
10		1.262	1.5604	1.3321	1.2795
11		1.8755	1.8004	1.7528	1.6301
12		2.0576	2.0508	2.0683	1.6461
13		2.2119		2.1384	1.749
14		2.4006	2.3487	2.1033	1.6289
15		2.3148	2.2786	1.9281	1.5604
16		2.1605	2.1033	1.8229	
17		2.0748	2.0157	1.8229	1.5947
18		.3086	.0876	.1402	.1372
19		.3429	.0876	.1402	.2058
20		.3429	.0876	.1227	.1715
21		.3258	.0701	.1227	.1886
22		.2743	.0701	.1052	.1715
23	.0701	.2743	.0701	.0876	.1715
24		.0701	.2743	.0526	.0876
Max	.0701	2.4006	2.3487	2.1384	1.749
Min	.0701	.0701	.0701	.0526	.0876
Avg	.0701	.7925	.7703	.6829	.5687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 205 / 11KV WADNER GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2273	.2058	.2462	.2841
2		.2273	.2058	.2462	.2651
3		.2841	.2572	.3788	
4		.4734	.463	.6818	
5		.9469	.7888	.9279	
6		.909	1.0288	1.0416	
7		.8143	.9602		
8		.7196	.9431	.8522	
9		.6628	.583	.5871	
10		.4356	.2915	.4734	
11		.2462	.2572	.2841	.2462
12		.1543	.2083	.1704	.2058
13		.12	.1894	.1704	.1715
14		.0857	.1136	.2083	.1715
15		.1715	.2083	.1894	.2058
16		.2572	.2462	.1894	
17		.5316	.303	.3788	.3772
18		.7545	.9279	.6818	.703
19		.7888	.9658	.7954	.8573
20		.6001	.6859	.6249	.6687
21		.4973	.5434	.5113	.5487
22		.2915	.333	.3409	.3429
23	.2841	.2572	.2462	.2841	.2915
24		.2273	.2401	.2462	.2841
Max	.2841	.9469	1.0288	1.0416	.8573
Min	.2841	.0857	.1136	.1704	.1715
Avg	.2841	.4451	.4665	.4570	.3749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 206 / 11KV KOLWADI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.095	.0686	.095	.057
2		.095	.0857	.095	.057
3		.133	.12	.152	.057
4		.1899	.2058	.2469	.152
5		.2849	.3258	.3229	
6		.3419	.4287	.3989	.3039
7		.3419	.3429	.3989	.2849
8		.2849	.2743	.4369	.2659
9		.1899	.1715	.171	.133
10		.114	.0857	.133	.095
11		.057	.0857	.076	.057
12		.0514	.057	.038	.0343
13		.0514	.038	.038	.0343
14		.0343	.038	.038	.0343
15		.0343	.057	.038	.0343
16		.0686	.076	.038	
17		.0857	.095	.076	.0857
18		.2572	.3229	.133	.2058
19		.2915	.3419	.2469	.2743
20		.2058	.2804	.1899	.1886
21		.1372	.1753	.133	.1715
22		.0857	.1402	.076	.12
23	.095	.0857	.1052	.057	.0857
24		.095	.0686	.095	.057
Max	.095	.3419	.4287	.4369	.3039
Min	.095	.0343	.038	.038	.0343
Avg	.095	.1505	.1663	.1551	.1268



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 207 / 11KV AMBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.0857	.0924	.0924
2		.0924	.0857	.0924	.0924
3		.1294	.12	.1663	.0924
4		.1848	.1715	.2402	.1478
5		.2772	.2229	.3326	.2218
6		.3881	.3429	.4251	.4066
7		.3696	.3772	.4435	.4251
8		.3326	.3258	.3696	.2957
9		.2957	.1886	.2587	.1848
10		.1478	.1029	.1478	.1109
11		.0739	.0857	.0924	.0739
12		.0343	.0554	.0554	.0514
13		.0343	.0554	.0554	.0514
14		.0343	.0554	.0554	.0514
15		.0514	.0554	.0554	.0514
16		.0686	.0739	.0924	
17		.1715	.1294	.1478	.1715
18		.2915	.3511	.2587	.2915
19		.2743	.3142	.2772	.2915
20		.2058	.2279	.2218	.1886
21		.1372	.1578	.1478	.1372
22		.1029	.1052	.1109	.0857
23	.0924	.0857	.0876	.0924	.0686
24		.0924	.0857	.0924	.0924
Max	.0924	.3881	.3772	.4435	.4251
Min	.0924	.0343	.0554	.0554	.0514
Avg	.0924	.1653	.1610	.1802	.1598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 208 / 11KV KALIMATH GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0171	.0377	.0377
2		.0377	.0171	.0377	.0377
3		.0566	.0343	.0377	.0377
4		.0754	.0686	.0754	.0754
5		.1132	.1029	.132	.1132
6		.1509	.1372	.1698	.1698
7		.1509	.1543	.1698	.1886
8		.1509	.1543	.132	.1698
9		.132	.12	.1132	.132
10		.0754	.0686	.0566	.0754
11		.0377	.0514	.0377	.0189
12		.0171	.0377	.0189	.0171
13		.0171	.0189	.0189	.0171
14		.0171	.0189	.0189	.0171
15		.0171	.0189	.0189	.0171
16		.0343	.0189	.0377	
17		.0686	.0377	.0566	.0514
18		.1029	.132	.1132	.12
19		.1372	.1698	.1698	.12
20		.0857	.1227	.1132	.0857
21		.0514	.0701	.0754	.0686
22		.0171	.0351	.0377	.0343
23	.0377	.0171	.0351	.0377	.0171
24		.0377	.0171	.0377	.0377
Max	.0377	.1509	.1698	.1698	.1886
Min	.0377	.0171	.0171	.0189	.0171
Avg	.0377	.0683	.0691	.0731	.0721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 201 / 11KV HATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4344	.3982	.4527	.724
2		.4706	.3721	.4527	.7164
3		.543	.4706	.6036	.7522
4		.7522	.724	.9054	.8596
5		1.0387	1.267	1.1694	1.1104
6		1.1462	1.1946	1.3203	1.3112
7		1.1104	1.2178	1.1317	1.262
8		1.0745	1.1827	1.2071	1.2403
9		1.1462	.9774	.9054	1.0387
10		.6882	.9069	.9175	1.1469
11		1.1603	1.1271		1.1797
12		1.2616	1.1271		.2715
13		1.2944	1.1142	1.4419	.1991
14		1.1797	1.1142	1.3763	.2353
15		1.1797	1.1142	1.4419	1.0486
16		1.1142	1.0364	1.3763	1.1142
17		1.1934	1.1336	1.2929	1.0486
18		1.2936	1.1317	.9671	1.1946
19		1.3169	1.3203	1.0387	1.0498
20		1.0164	1.1317	1.0745	1.0208
21		.7964	.8299	.8954	1.0136
22		.5731	.6036	.8596	.5544
23	.5373	.4656	.4527	.788	.4435
24		.4298	.3982	.4527	.7602
Max	.5373	1.3169	1.3203	1.4419	1.3112
Min	.5373	.4298	.3721	.4527	.1991
Avg	.5373	.9450	.9311	1.0032	.8873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 202 / 11 KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.4915	.3795	.503
2		.2572	.5243	.3749	.4973
3		.3222	.5407	.4374	.5304
4		.4239	.6226	.4481	.6062
5		.5935	.6562	.4915	.6882
6		.6874	.852	.8886	.9012
7		.9724	1.3272	1.3889	1.3272
8		.5611	.695	.6036	.7522
9		.5068	.6468	.679	.6805
10		.3258	.4527	.4527	.2865
11		.2957	.3206		.3258
12		.2195	.3018		.2743
13		.197	.3018	.2715	.2012
14		.1829	.2829	.2715	.2328
15		.2033	.2641	.2715	.2481
16		.2149	.2452	.2896	.2715
17		.3582		.3077	.3142
18		.7442	.6413	.5068	.7421
19		.7577	.8299	.5373	.5731
20		.5914	.6036	.4887	.4887
21		.3696	.4904	.4525	.3856
22	.2204	.3547	.3361	.3988	.4908
23	.2035	.4835	.3593	.4287	.4755
24		.1715	.4752	.3749	.4527
Max	.2204	.9724	1.3272	1.3889	1.3272
Min	.2035	.1715	.2452	.2715	.2012
Avg	.2120	.4167	.5331	.4884	.5104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 203 / 11 KV TAPARGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.6078	1.6057	1.4842	1.4746
2		1.6575	1.5893	1.5023	1.5238
3		1.7204	1.5339	1.5684	1.5746
4		1.7695	1.6057	1.6004	1.5402
5		1.8023	1.5893	1.7204	1.5074
6		1.7695	1.7976	1.7204	1.6876
7		1.8842	2.0645	2.1464	1.9989
8		.8596	.7442	.6413	.8238
9		.5611	.6447	.4527	.5373
10		.3511	.415	.3018	.3292
11		.2743	.2829		.2957
12		.2378	.2641		.2149
13		.2402	.2641		.3189
14		.1829	.2263		.2957
15		.2507	.2263	.2896	.2561
16		.2926	.3584	.3258	.2686
17		.3403	.3961	.3582	.4251
18		.6838	.6413	.5792	.6767
19		.6697	.7545	.6154	.6135
20		.5373	.5658	.543	.6584
21		.443	.4904	.5373	.4887
22		1.5893	1.4842	1.4419	1.5074
23	1.6057	1.5565	1.4327	1.5402	1.491
24		1.5565	1.5893	1.4842	1.5074
Max	1.6057	1.8842	2.0645	2.1464	1.9989
Min	1.6057	.1829	.2263	.2896	.2149
Avg	1.6057	.9516	.9403	1.0427	.9173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 204 / 11 KV JAITAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.2126	.3018	.3077
2		.2715	.2534	.3395	.3439
3		.3258	.2896	.3395	.3982
4		.4119	.362	.415	.3982
5		.4525	.4887	.5658	.4298
6		.4835	.5249	.6602	.5249
7		.5014	.5611	.3772	.5014
8		.3439	.2926	.3206	.3439
9		.2195	.2033	.1886	.1629
10		1.6356	1.7814	1.8187	1.9826
11		1.8842	2.0553		2.0481
12		1.917	2.0317		1.8679
13		1.9498	2.0645	1.9826	1.9498
14		1.9498	2.0719	2.0243	2.0056
15		1.8515	2.0243	2.1214	1.917
16		1.8842	1.8461	1.9989	1.9498
17		1.8187	1.7814	1.917	1.9334
18		.543	.4904	.5792	.3881
19		.5544	.5658	.543	.5304
20		.4525	.5658	.5792	.4706
21		.3582	.4904	.4525	.4251
22		.3109	.3395	.4163	.2957
23	.2686	.2402	.3206	.3801	.2801
24		.2561	.2172	.3018	.3258
Max	.2686	1.9498	2.0719	2.1214	2.0481
Min	.2686	.2195	.2033	.1886	.1629
Avg	.2686	.8703	.9098	.8465	.9075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 201 / 11KV JEHUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4954	.4191	.5144	.381
2		.5144	.381	.5335	.381
3		.5716	.381	.5144	.4191
4		.6287	.4191	.5906	.5335
5		.6859	.5716	.8954	.6097
6		.7049	.8192	1.0288	.7621
7		.6287	.9526	.9335	.8764
8		.7049	.8192	.9145	.7811
9		.4954	.6478	.6668	.7049
10		.8802	.5281	.8029	.6874
11			.9804	1.0279	1.0227
12		.7407	.9442	1.0279	.9665
13			.8642	.9842	.7712
14		.9503	.8482	.9172	.7202
15		.7811	.8223	.9646	.6964
16		.8025	.7748	.9014	
17		.6316	.9172	.8951	.9835
18		.6859	.6097	.6097	.6668
19		.7811	.8764	.8383	.8764
20		.6097	.6478	.7049	.7621
21		.5525	.5335	.5716	.6668
22		.4954	.5144	.4954	.5716
23	.4763	.4572	.4763	.4572	.5335
24		.4763	.4191	.4763	.4191
Max	.4763	.9503	.9804	1.0288	1.0227
Min	.4763	.4572	.381	.4572	.381
Avg	.4763	.6488	.6736	.7611	.6867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 202 / 11 KV CHIWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6697	.6478	.8097	.7811
2		.7059	.6722	.8421	.8223
3		.788	.7499	.9282	.8907
4		.8328	.8025	.9831	1.004
5		.8764	.9831	1.0774	1.1633
6		.9709	1.1233	1.2887	1.3077
7		1.2887	1.2597	1.326	1.0059
8		.5144	.5906	.724	.6478
9		.362	.4382	.5525	.4763
10		.2858	.3048	.2477	.3048
11		.1715	.2096	.1334	.1715
12		.1334	.1905	.1143	.1334
13		.1334	.2096	.0953	
14		.1334	.2096	.1143	.1905
15		.1905	.2096	.1715	.1905
16		.2096	.2286	.2096	
17		.3429	.3048	.2667	.2858
18		.5716	.5335	.5525	.5525
19		.7811	.7621	.6668	.6668
20		.5335	.6287	.5335	.5716
21		.4382	.4191	.4763	.5144
22		.6481	.6964	.7748	1.086
23	.5853	.6249	.7274	.7907	.9717
24		.6401	.663	.7842	.7499
Max	.5853	1.2887	1.2597	1.326	1.3077
Min	.5853	.1334	.1905	.0953	.1334
Avg	.5853	.5353	.5652	.6026	.6586



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 203 / 11KV NIPANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3109	.2105	.3121	.216
2		.3258	.192	.3601	.2187
3		.3582	.2056	.4161	.2343
4		.3582	.2343	.4681	.2846
5		.4207	.3361	.5434	.3563
6		.39	.4807	.631	.6036
7		.6539	.6226	.8745	.5487
8		.362	.2096	.2667	.3239
9		.3048	.3239	.2667	.3239
10		.2286	.2667	.2286	.2858
11		.1143	.1715	.1715	.1524
12		.1905	.1715	.1524	.1334
13		.1715	.1334	.1905	.1524
14		.1524	.1334	.1715	.1334
15		.1334	.1334	.1905	.1715
16		.1524	.1334	.1715	
17		.1524	.2477	.3048	.2477
18		.4191	.3239	.4191	.362
19		.4001	.381	.381	.3429
20		.4001	.381	.381	.362
21		.4191	.362	.3429	.381
22		.2429	.3086	.2214	.3048
23	.2772	.2321	.2601	.2056	.285
24		.3109	.2294	.2572	.2187
Max	.2772	.6539	.6226	.8745	.6036
Min	.2772	.1143	.1334	.1524	.1334
Avg	.2772	.3002	.2688	.3303	.2888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 201 / 11KV CHAPANER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2347	.2096	.2075	.2058
2				.2347	.2477	.2229	.2058
3				.2683	.2858	.2572	.2743
4				.3018	.3429	.2572	.9619
5				.3734	.4001	.3429	.3429
6					.4572	.3772	.4287
7					.5144	.6602	.5281
8				1.0829	.9335	1.0185	.9619
9				.6722	.6287	.7356	.6602
10			.3258	.4382	.4715	.415	.4108
11	.2858	.2915		.362	.4715	.415	.3361
12	.2477			.2477	.3018	.3206	.2614
13	.2667	.2915		.2096	.2829	.2829	.2427
14	.2096			.2286	.1886	.2829	.2427
15	.2667			.2477	.2829	.2829	.2614
16	.3429			.2858	.2829	.2829	.2987
17	.3429			.3429	.2075	.3772	.3174
18	.5144			.5335			.5281
19	.7621		.5228	.8383	.7733	.7922	.5601
20	.6478		.4854	.724	.679	.6224	.6908
21	.4572		.4668	.6287	.5093	.4715	.5228
22	.362		.1174	.2096			.4359
23	.3239		.1509	.2477			.4527
24			.2683		.2286	.1886	.4527
Max	.7621	.2915	.5228	1.0829	.9335	1.0185	.9619
Min	.2096	.2915	.1174	.2096	.1886	.1886	.2058
Avg	.3869	.2915	.3339	.4149	.4143	.4197	.4410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 202 / 11KV SIRAJGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241			.4694	.6287	.5144	.5144
2	.2054			.503	.743	.6001	.6001
3	.2801			.6706	.9717	.5658	.6001
4	.3361			.7712	1.2003	.6859	
5	.4108			1.0059	1.448	1.0288	.9242
6	.4481				1.6956	1.0288	
7	.5228				1.848	1.5775	
8	.7468			.6535	.6287	.5144	
9	.6535			.2987	.4954	.4715	.5093
10				.3048	.3961	.4338	.3174
11				.2858	.1509	.3395	.1867
12	1.5242			.2667		.2075	.1494
13	1.4289	1.1831		.2858	.1509	.1509	
14	1.4098			.2477	.1698		
15	1.5242			.2286	.132		.1494
16	1.6004			.2667	.1698		.1494
17	1.6575			.3048	.2075	.2829	.1494
18	.743			.4954			.4294
19	.5906		.3734	.7049			.4668
20	.4572		.4108	.6478	.6036	.6602	.5975
21	.362		.4294	.6097	.3772	.4338	.3921
22	.3048		.4481				.285
23	.2477		.4481	.5335			.3018
24			.4024		.5716	.5144	.2683
Max	1.6575	1.1831	.4481	1.0059	1.848	1.5775	.9242
Min	.2054	1.1831	.3734	.2286	.132	.1509	.1494
Avg	.7466	1.1831	.4187	.4777	.6626	.5888	.3884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 203 / 11KV TAKLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562		.7468	.6859	.5658	.5658
2	.7282		.8215	.724	.6001	.6602
3	.7468	.7716	.8962	.8192	.7545	.6602
4	.8215		1.1203	1.0288	.7545	.6602
5	.8589		1.4937	1.1431	.7545	.7545
6	.8962					
7	.9335					
8	1.0269		.8029			
9	.8962			.9717	.7545	.8676
10	.4294		1.2384		.4904	.8718
11	.3429		1.5051	1.3769	1.4335	.9389
12	.2286		1.4861	1.4146	1.4335	1.0898
13			1.448	1.286	1.3203	1.0898
14			1.4098		1.1317	1.073
15			1.4289	1.2449	1.2449	1.0898
16			1.3336	.2829		1.1065
17			1.2765	1.046	1.1317	1.1233
18			.6478			.6371
19	1.1241	.6535	1.1622			.8215
20	.9526	.6722	1.1241	1.0374	1.1506	.9709
21	.7621	.6908	.8764	.8488	.9808	.8775
22	.9335	.6908	.7049			.7468
23	1.0288	.7468	.6668			.8029
24		.7282		.6478		.7468
Max	1.1241	.7716	1.5051	1.4146	1.4335	1.1233
Min	.2286	.6535	.6478	.2829	.4904	.5658
Avg	.8098	.7077	1.1095	.9705	.9668	.8645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 204 / Banshendra SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168		.1307	.2096	.2058	
2	.1867		.1494	.2477	.2263	
3	.2241		.1494	.3048	.2229	
4	.2241		.1494	.3239	.2058	
5	.2614		.112	.362	.2058	
6	.2987			.4001	.2058	
7	.3361			.4763	.4115	
8	.3547		.4294	.381	.3772	
9	.3361		.2801	.2096	.3018	
10	.168		.1494		.1886	.168
11	.1715		.1143	.0943		.0747
12	.1524		.0953			.0934
13	.1334		.0762	.0566	.1132	.056
14	.1524		.0953	.0754		.056
15	.1715		.1143	.0754		.0747
16	.2096		.1334	.0943		.0747
17	.1905		.1715	.132	.0754	.0934
18	.4001		.2477	.4338	.3584	.1867
19	.3048	.1867	.381	.4338	.4715	.2614
20	.2667	.1867	.3429		.3206	.2987
21	.2286	.1494	.3048	.2263	.3206	.1844
22	.1905	.0838	.1715			.1677
23	.1524	.1174	.1905			.1677
24		.1006		.2096		.1509
Max	.4001	.1867	.4294	.4763	.4715	.2987
Min	.1334	.0838	.0762	.0566	.0754	.056
Avg	.2297	.1374	.1899	.2498	.2632	.1406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 205 / 11 KV GUDAMA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168			.0934	.3429	.2572	.1905
2	.1867			.112	.381	.2572	.2858
3	.1867			.1307	.4572	.2829	.2858
4	.2054	.2096		.12	.5525	.3772	.381
5	.2614	.2667		.0747	.7049	.4715	.4191
6	.2987	.3048			.8002	.6979	.8192
7	.3174	.3429			.8764	.9619	1.0479
8	.3174	.2858			.362	.4715	.4001
9	.2987	.1524		.1867	.1905	.3018	.2858
10	.4668			.1494		.1886	.168
11	.743			.1143		.1509	.112
12	.9907			.0953	.0566	.0857	.1494
13	1.105			.0572	.0566	.0943	.0747
14	1.1622			.0572	.0943	.0754	.0747
15	1.105			.0762	.1132	.0754	.0747
16	1.0098			.1143	.0754	.0686	.0747
17	.8383			.1905	.132	.1698	.112
18	.4382			.2667			.4294
19	.3429			.381			.3361
20	.2667		.1867	.3239	.3206		.2987
21	.1715		.1494	.2858	.2263	.2452	.2012
22	.1524		.112	.1334		.1905	.1677
23	.1143		.0747	.1715		.1905	.1677
24			.1307		.2667	.1715	.1509
Max	1.1622	.3429	.1867	.381	.8764	.9619	1.0479
Min	.1143	.1524	.0747	.0572	.0566	.0686	.0747
Avg	.4847	.2604	.1307	.1567	.3339	.2755	.2795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 201 / 11kv ANDHANER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.7918	1.6194	1.8099	1.8861
2			1.7918	1.5242	1.9909	1.905
3			1.8484	1.4861	1.9909	2.1879
4			1.8861	1.5242	2.1719	2.3011
5			2.5652	1.6194	2.3529	2.4897
6			2.5652	1.7147	2.5339	2.584
7			2.6217	2.4196	2.5339	2.6217
8			2.1125	1.5242	1.448	2.0748
9			1.773	1.6194	1.448	1.7918
10			1.1128	1.086	1.086	1.086
11			.7545	.905	.6602	.7545
12			.5658	.2058	.5144	.6859
13				.4287	.4715	.3772
14			.583	.3772	.4715	.4287
15	1.6632		.724	.362	.4715	.4954
16			.7811	.463	.9054	.4287
17				.8402	.9054	
18				1.4746	1.8861	1.7147
19			1.9805	1.8099	2.037	2.1148
20			1.5432	1.8099	1.7918	1.7147
21			1.5623	1.267	1.226	1.5242
22			1.5623	1.448	1.4146	1.9052
23		1.6975	1.4861	1.448	1.6221	1.9814
24			1.7353	1.6194	1.6289	1.6975
Max	1.6632	1.6975	2.6217	2.4196	2.5339	2.6217
Min	1.6632	1.6975	.5658	.2058	.4715	.3772
Avg	1.6632	1.6975	1.5879	1.2748	1.4739	1.5979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 203 / 11KV GARADA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2641	.3048	.2896	.3018
2			.2641	.3048	.3258	.3018
3			.2641	.3048	.362	.3395
4			.3395	.3429	.3982	.415
5			.415	.5335	.5068	.4904
6			.415	.4191	.543	.5281
7			.4338	.4954	.5068	.5281
8			.4527	.4191	.4525	.5281
9			.415	.381	.4525	.4715
10			1.773	1.4118	1.9004	1.8099
11			1.9033	2.5339	2.6217	2.1776
12	.5093		2.4177	2.3491	2.4691	2.9835
13	.3772		2.4768	2.2291	2.6217	3.1207
14	.3395		2.0576	2.3834	2.6217	3.3608
15	.2858		2.4768	2.7149	2.6406	2.3102
16			2.553	2.452	2.6029	2.3148
17			2.4577	2.3663	2.6029	2.8509
18				.583	.4904	.381
19			.4191	.4706	.4904	.4001
20			.3239	.4525	.4338	.381
21			.3048	.4525	.3772	.3239
22			.3048	.3982	.3772	.2858
23		.2263	.2858	.362	.3395	.2667
24			.2263	.2858	.3258	.3395
Max	.5093	.2263	2.553	2.7149	2.6406	3.3608
Min	.2858	.2263	.2263	.2858	.2896	.2667
Avg	.3780	.2263	1.0106	1.0396	1.1147	1.1338



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 204 / 11KV KALIMATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7915		.6413	.4763	.543	.679
2	2.5606		.679	.4763	.6335	.7167
3			.679	.6478	.6878	.7167
4	2.572		.7167	.724	.724	.8488
5			.7922	.7621	.8145	.8488
6			.8299	.8192	.905	.9619
7			.8299	.8764	.724	.9619
8			.7167	.7621	.6335	.8299
9			.4904	.4191	.543	.5093
10			2.5463	1.8099	2.3529	2.3529
11			2.572		2.9424	2.6406
12			3.3265	2.7263	2.8292	3.1036
13			3.2579	3.0007	3.1121	3.1207
14	.2075		3.2407	2.9321	3.1121	3.0864
15			3.5246	3.1131	3.1121	2.9001
16			1.3527	2.6749	2.6972	3.1722
17			2.915	2.7606	2.7161	2.8509
18				.6173	.7167	.8573
19			.6344	.724	.7545	.8954
20			.6668	.724	.7922	.8383
21			.6859	.6335	.8299	.7621
22			.7049	.543	.7922	.724
23		.6413	.4382	.543	.7865	.6668
24			.6413	.4382	.543	.811
Max	2.7915	.6413	3.5246	3.1131	3.1121	3.1722
Min	.2075	.6413	.4382	.4191	.543	.5093
Avg	2.0329	.6413	1.4297	1.2697	1.4291	1.4940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 205 / 11KV GARADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1509	.1524	.2614	.1509
2			.1509	.1524	.3361	.1509
3			.1886	.1524	.3734	.2263
4			.2263	.1905	.4481	.3395
5			.2263	.381	.5228	.5658
6			.4904	.4763	.6161	.6036
7			.5658	.5906	.5975	.6224
8			.4527	.4763	.5228	.4904
9			.3772	.3429	.4668	.3584
10			.2641	.2614	.2801	.2801
11		.3395	.1715	.1867	.2075	.1372
12		.1698	.12	.1715	.1543	.1543
13			.1029	.12	.132	.1715
14			.12	.1543	.132	.1372
15	.1543		.1524	.1867	.132	.1524
16			.1715	.1543	.2452	.1543
17			.3048	.2572	.2452	.2667
18				.3772	.415	.3429
19			.2477	.4481	.4527	.4191
20			.3048	.3547	.3395	.3239
21			.2229	.2987	.2263	.2477
22			.1524	.2241	.1509	.1905
23		.1509	.1334	.1494	.1509	.1334
24			.1509	.1334	.1307	.132
Max	.1543	.3395	.5658	.5906	.6161	.6224
Min	.1543	.1509	.1029	.12	.1307	.132
Avg	.1543	.2201	.2369	.2664	.3141	.2813

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 206 / 11KV Rail Single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.0374	1.0479	.2353	1.0562
2			1.0374	.9526	.2353	1.226
3			1.094	.8573	.2534	1.3203
4			1.1317	1.0479	.2715	1.4712
5		.3395	1.1883	1.2384	.2896	1.5466
6			1.226	1.3336	.2896	1.5466
7			1.226	1.5623	.3439	1.6787
8			.3961	.4001	.2715	.3206
9			.3206	.2477	.2353	.2452
10			.1886	.1991	.1448	.1448
11			.1715	.1629	.0943	.0857
12			.1886	.1372	.0686	.0857
13				.1372	.0754	.0857
14			.1715	.1372	.0754	.12
15	2.1502		.1524	.0905	.0754	.1143
16			.1334	.1029	.1886	.0857
17				.1372	.1886	
18				.2229	.2641	.1524
19			.4382	.2353	.3206	.1715
20			.4001	.2534	.2829	
21			.9526	.2353	.2829	.381
22			.9526		.3206	1.2384
23		1.0374	.9526	.362	.7316	1.3908
24			1.0374	1.0479	.2353	.7922
Max	2.1502	1.0374	1.226	1.5623	.7316	1.6787
Min	2.1502	.3395	.1334	.0905	.0686	.0857
Avg	2.1502	.6885	.6856	.5282	.2406	.6936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 201 / 11 KV Deogaon Urban SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2955	1.1576	.9297	1.3717
2		1.2955	1.3817	1.0212	1.3717
3		1.2955	1.4003	1.0974	1.448
4		1.3336	1.8298	1.5432	1.6766
5		2.1338	2.0911	2.1691	2.21
6					2.553
7			2.2405	2.0957	2.4387
8			2.0538	2.4387	2.2862
9			1.6244	2.0005	1.8671
10		1.0802	1.0364	1.3575	1.2517
11		1.2517	1.2174	1.3321	1.2003
12		1.3375	1.2517	1.4198	1.4232
13		1.3203	1.2689	1.4548	1.3375
14		1.286	1.046	1.4022	1.286
15		1.1831	1.0212	1.3672	1.0288
16		1.0974	1.3546	1.3717	1.0631
17		1.1145	1.2174	1.3032	1.0631
18		1.8298	1.5432	1.7528	1.6617
19		2.0911	1.9719	2.2481	1.9791
20		1.9044	1.749	1.9624	1.8298
21		1.8858	1.6804	1.7528	1.7737
22		1.5497	1.3889	1.6194	1.4937
23	1.2574	1.2883	1.3889	1.5242	1.2136
24		1.2574	1.1763	1.0822	1.3717
Max	1.2574	2.1338	2.2405	2.4387	2.553
Min	1.2574	1.0802	1.0212	.9297	1.0288
Avg	1.2574	1.4416	1.4822	1.5759	1.5917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 202 / 11KV Mategaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6805	.8063	.4287	.8383
2		.6805	.7888	.6859	.8002
3		.6335	.8238	.6859	.7602
4		.724	.8413	.381	.8573
5		.9745	.8939	.7621	1.0631
6		1.0631	1.1218	1.0517	1.2346
7		1.3321	1.3321	1.3146	1.3717
8		.381	.3547	.4001	.3429
9		.2858	.2987	.3429	.2241
10		.2614	.1429	.1905	.1494
11		.2614	.0953	.1905	.1494
12		.2241		.1905	.1494
13		.2241	.0953	.1524	.1307
14		.2241	.0953	.1524	.1307
15		.1867	.0953	.1905	.1494
16		.1867	.0953	.1524	.1867
17		.1867	.0953	.1524	.1867
18			.1905		.3547
19		.4481	.2382	.4763	.4108
20		.3921	.1905	.4572	.4108
21		.3361	.1715	.381	.2987
22		.631	.4287	.6878	.7011
23	.724	.7011	.6706	.8145	.7888
24		.6516	.7888	.6554	.8145
Max	.724	1.3321	1.3321	1.3146	1.3717
Min	.724	.1867	.0953	.1524	.1307
Avg	.724	.5074	.4633	.4738	.5210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 203 / 11KV Dhondalgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.724	.8939	.7621	.5792
2		.7011	.8764	.7773	.6154
3		.6661	.8764	.7773	.583
4		.7888	.929	.7621	.6661
5		.9259	.964	.823	.7202
6		1.1145	1.1568	1.2308	.905
7		1.2003	1.3146	1.4723	.9945
8			.6161	.724	.6478
9		.4954	.4481	.5525	.4294
10		.3361	.1715	.2286	.2987
11		.2241	.1048	.2286	.1867
12		.1494	.1048	.1715	.168
13		.168	.0762	.1715	.168
14		.1307	.0762	.1524	.1494
15		.1494	.0762	.1524	.1494
16		.2054	.0857	.1715	.1867
17		.3174	.1334	.2858	.2801
18			.2191	.4191	.4668
19		.6535	.3144	.6287	.5228
20		.4854	.2667	.5525	.5415
21		.3734	.2191	.4572	.4294
22		.7964	.8078	.6154	.8764
23	.6859	.905	.8078	.6154	1.0341
24		.7602	.8764	.8078	.5973
Max	.6859	1.2003	1.3146	1.4723	1.0341
Min	.6859	.1307	.0762	.1524	.1494
Avg	.6859	.5578	.5173	.5642	.5082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 205 / 11KV Deogaon Rural SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.105	1.0829	.884	1.1431
2		1.105	1.1203	.945	1.1431
3		1.0669	1.1203	.9145	1.1431
4		1.3336	1.4937	1.2003	1.7147
5		1.6385	1.7364	1.4575	1.8642
6		1.8671	1.8298	1.848	1.9624
7		1.7528	1.8298	1.9243	1.6194
8		1.7147	1.5497	1.6575	
9		1.2193		1.4861	
10		1.5432	1.4746	1.6118	1.5432
11		1.869	1.7147	1.5775	1.406
12		1.7833	1.7147	1.6118	1.5261
13		1.7318	1.8861	1.6289	1.3717
14		1.7147	1.5432	1.5432	1.3717
15		1.5775	1.5089	1.3717	1.0288
16		1.4746	1.4575	1.4232	1.3203
17		1.4232	1.4575	1.3146	1.3203
18			.9259	1.1431	1.251
19		1.7551	1.3717	1.5242	1.3817
20		1.4937	1.2346	1.448	1.4563
21		1.3256	1.1488	1.3336	1.307
22		1.2136	.945	1.2193	1.1949
23	1.1812	1.0829	.945	1.1431	1.1203
24		1.0479	1.0456	.8535	1.0669
Max	1.1812	1.869	1.8861	1.9243	1.9624
Min	1.1812	1.0479	.9259	.8535	1.0288
Avg	1.1812	1.4713	1.3972	1.3777	1.3753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 201 / Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2058	.2401	.0217
2		.7202	.2058	.2058	.0253
3		.2401	.2401	.2058	.0253
4		.2743	.2743	.2401	.0326
5		.3772	.4115	.3772	.0434
6		.5144	.5144	.4458	.0543
7		.5487	.583	.6173	.5792
8		.583	.6516	.6516	.0622
9		.4801	.6516	.5144	.5487
10		.4755	.0579	.4458	.4458
11		.4024	.0402	.3772	.3086
12		.3734	.0344	.1715	.3429
13		.3361	.0326	.2058	.2743
14		.2957	.0326	.2058	.2401
15		.2614	.0271	.2774	.2058
16		.2987	.0274	.2401	.2058
17		.3429	.3086	.0329	.3772
18		.5144	.4801	.0476	.3395
19		.5144	.5144	.0549	.5914
20		.4801	.5144	.053	.4805
21		.4115	.4115	.0402	.4435
22		.3429	.3429	.0329	.3658
23	.2743	.2401	.2743	.0256	.3292
24		.2058	.2058	.2401	.0253
Max	.2743	.7202	.6516	.6516	.5914
Min	.2743	.2058	.0271	.0256	.0217
Avg	.2743	.3933	.2934	.2479	.2654



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 202 / Town-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.6859	.6859	.0776
2		.6859	.6859	.6859	.0758
3		.7202	.6859	.7202	.0758
4		.7545	.7202	.823	.085
5		1.0288	1.2346	1.1317	.1238
6		1.6804	1.3717	1.3032	.146
7		1.8519	1.6804	1.749	.194
8		1.749	1.749	1.749	.1848
9		1.4403	1.406	1.406	1.4403
10		1.1576	.1294	1.2003	1.0974
11		1.1706	.8871	1.0631	.9945
12		1.1576	.0739	.9259	1.0288
13		.9511	.0776	.8573	.823
14		.9145	.0813	.7373	.7545
15		.8413	.0832	.7202	
16		.9145	.0887	.823	.8573
17		1.0288	1.0288	.1238	1.1203
18		1.3717	1.3717	.1589	1.5497
19		1.4746	1.4746	.1996	1.6632
20		1.3032	1.3032	.1552	1.4969
21		1.0974	1.2003	.1183	1.2936
22		.9602	.9259	.0961	1.4937
23	.823	.7545	.7545	.085	.7842
24		.7202	.6859	.6859	.0788
Max	.823	1.8519	1.749	1.749	1.6632
Min	.823	.6859	.0739	.085	.0758
Avg	.823	1.1006	.8494	.7585	.7582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 204 / Town 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3086	.2743	.0256
2		.3086	.2743	.2401	.0293
3		.3086	.2743	.2743	.0256
4		.3086	.2743	.3429	.0384
5		.4115	.4458	.3772	.0439
6		.4801	.5144	.4458	.0549
7		.583	.5487	.5487	.0658
8		.5487	.5487	.6173	.0658
9		.5144	.5487	.583	.583
10		.5853	.0554	.583	.583
11		.6348	.053	.5487	.5487
12		.5228	.0512	.5144	.5144
13		.4755	.0476	.4801	.4115
14		.5228	.0421	.4458	.4115
15		.5544	.0476	.4458	.4115
16		.5544	.0512	.4801	.4801
17		.4458	.5487	.053	.6348
18		.6516	.6516	.0622	.7316
19		.6516	.6859	.0768	.7392
20		.5487	.5487	.0658	.6036
21		.4801	.4801	.0512	.5121
22		.3772	.4115	.0384	.4338
23	.3429	.3429	.3429	.0329	.3547
24		.3086	.3086	.2743	.0293
Max	.3429	.6516	.6859	.6173	.7392
Min	.3429	.3086	.0421	.0329	.0256
Avg	.3429	.4762	.3360	.3273	.3472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 205 / Ritthi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2498	1.5089	1.3375	.1317
2		1.2498	1.5089	1.3375	.1289
3		1.2803	1.5432	1.3717	.1323
4		1.3108	1.3717	1.4403	.139
5		1.4632	1.4327	1.2803	.1719
6		1.6156	1.4937	1.4746	.2001
7		1.7375	1.6766	1.989	.212
8		.3048	.3086	.3429	.0356
9		.2743	.2743	.3429	.3429
10		.3658	.0271	.3429	.3086
11		.3361	.0271	.3429	.3429
12		.3142		.3429	.3772
13		.3292	.0305		.3429
14		.3475	.0271	.3048	.4115
15		.3696	.0305	.3772	.3772
16		.3658	.3561	.3353	.3048
17		.3658	.3353	.0441	.5544
18		.3963	.4115	.0492	.5228
19		.3963	.4801		.6348
20		.2743	.4458	.0577	.547
21		.2743	.3353	.0373	.4066
22		1.1584	1.2689	.1051	1.6991
23	1.1888	1.1584	1.1888	.1153	1.8484
24		1.2193	1.2803	1.1888	.1289
Max	1.1888	1.7375	1.6766	1.989	1.8484
Min	1.1888	.2743	.0271	.0373	.0356
Avg	1.1888	.7566	.7549	.6618	.4292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 206 / Industrial SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1372	.0514	.0092
2		.1372	.1029	.0514	.0092
3		.1372	.1029	.0514	.0129
4		.1372	.1029	.0686	.0185
5		.1715	.1029	.0686	.0222
6		.1715	.1372	.0857	.0259
7		.2058	.1715	.1029	.024
8		.2401	.1715	.1715	.0259
9		.2743	.1715	.2401	.2572
10		.2241	.0185	.3086	.2743
11		.2561	.0111	.2743	.2401
12		.2452	.0111	.2401	.2743
13		.2641	.0111	.2743	.2401
14		.2587		.2058	.2401
15		.2561	.0166	.2401	.2401
16		.2587	.128	.2401	.2401
17		.2401	.1372	.0277	.2987
18		.2743	.1372	.0296	.2195
19		.3086	.1715	.0296	.2614
20		.2743	.1715	.0222	.1867
21		.2058	.1372	.0166	.1867
22		.1715	.1029	.0129	.0549
23	.1372	.1715	.0514	.0111	.0934
24		.1372	.1715	.0514	.0111
Max	.1372	.3086	.1715	.3086	.2987
Min	.1372	.1372	.0111	.0111	.0092
Avg	.1372	.2149	.1077	.1198	.1444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 201 / 11KV NAGAD AG(WITH SDT)

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.9907	1.1431	1.105
2		.6478	1.0288	1.1622	1.105
3		.724	1.0669	1.2003	1.086
4		.7621	1.1431	1.1812	1.105
5		.8002	1.2003	1.2003	1.1431
6		.8573	1.2384	1.3146	1.1622
7		.8383	1.3336	1.3717	1.5242
8		.2667	.4191	.362	.3429
9		.2286	.4001	.4763	.381
10	.3048	.1905	.3429	.381	.4763
11	.3048	.1524		.362	.4001
12	.3239	.0953		.381	.4001
13	.3429	.0762		.381	.362
14	.362	.0762		.4191	.3048
15	.4001	.381	.3048	.3429	.3239
16	.4572	.4191	.2858	.381	.4572
17	.5906	.5335	.362		.5716
18	.9145	.5525	.4954		.6668
19	.2858	.5716	.5525	.5335	.724
20	.2667	.5335	.4001	.5144	.6668
21	.2286	.5144	.4382	.4572	.6287
22	.7621	.7621	1.0669	1.0479	1.2765
23	.6097	.8573	1.1431	1.0669	1.3146
24		.6287	.9526	1.1622	1.105
Max	.9145	.8573	1.3336	1.3717	1.5242
Min	.2286	.0762	.2858	.3429	.3048
Avg	.4396	.5057	.7583	.7655	.7764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 202 / 11KV SAIGAWN AG (WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1812		1.1812	1.0288
2		1.2193		1.2193	1.0669
3		1.2574		1.2003	1.0669
4		1.2955		1.2765	1.1431
5		1.3336		1.1431	1.2003
6		1.5242		1.1622	1.4098
7		1.6385		1.3908	1.7909
8		.4191		.381	.4572
9		.4763		.3429	.4763
10		.4954	.381	.4191	.4572
11	.4572	.5335	.4763	.5335	.5716
12	.6478	.5335	.4382	.5335	.6097
13		.5335	.5144	.5525	.6478
14		.5335	.5525	.5335	.7049
15		.5716	.4191	.5144	.6859
16		.5525	.4954	.5335	.8002
17		.5335	.5716	.5525	.9335
18	.5335	.5716	.5335	.4191	.724
19	.4191	.6097	.381	.4572	.5716
20	.381	.6097	.4191	.4763	.5335
21	.3429	.5335	.3239	.4191	.4572
22	.6859	.5335	.8954	.9526	1.2574
23	1.0288	.7621	1.2003	.9907	1.2955
24		1.1431	.8383	1.2003	.9907
Max	1.0288	1.6385	1.2003	1.3908	1.7909
Min	.3429	.4191	.3239	.3429	.4572
Avg	.5620	.8081	.5627	.7660	.8700

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 203 / 11 KV BELKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524		.1905	.1524
2		.1524		.1905	.1524
3		.1524		.2286	.1334
4		.1905		.2667	.1905
5		.2286		.2858	.3048
6		.2667		.2477	.381
7		.2858		.3048	.4191
8		.2667		.3429	.381
9		.2477		.2667	.381
10		1.3336	.6287	1.0479	1.3717
11		2.2862	2.1338	2.0195	1.8099
12		2.553	2.4958	2.2862	1.9624
13		2.4768	2.0957	2.3624	2.21
14		2.3434	1.848	1.9052	2.191
15		2.4768	2.2481	2.2862	2.1529
16		2.4006	2.0576	2.4768	2.0005
17		2.21	2.0957	2.0767	1.7909
18	.1905	.4954	.381	.3048	.2477
19	.2286	.4954	.3048	.3048	.2858
20	.2286	.4382	.2667	.2667	.2858
21	.1905	.4191	.2096	.2477	.2286
22	.1715	.381	.1905	.2096	.1715
23	.1524	.381	.2858	.1905	.1715
24		.1524	.362	.3429	.1905
Max	.2286	2.553	2.4958	2.4768	2.21
Min	.1524	.1524	.1905	.1905	.1334
Avg	.1937	.9494	1.1736	.8605	.8153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 204 / 11kv Nagad gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1905	.1334	.1334
2		.1524	.1905	.1524	.1334
3		.1715	.1524	.1524	.1905
4		.2286	.1905	.1905	.2096
5		.3429	.381	.2858	.3048
6		.381	.4382	.4191	.4763
7		.4572	.4191	.4382	.4382
8		.381	.4191	.4763	.381
9		.3239	.381	.4001	.2858
10	.2667	.2858	.2667	.2667	.2096
11	.2286	.2096	.2096	.1715	.1715
12	.2096	.1715	.1715	.1524	.1143
13	.1905	.1524	.1524	.1143	.1143
14	.1715	.1334	.1334	.1524	.1143
15	.1524	.1524	.1524	.1524	.1143
16	.1905	.1905	.1524	.1143	.1715
17	.2286	.2286	.1905	.1715	.2286
18	.2667	.381	.3239	.3239	.2667
19	.3429	.362	.381	.381	.3429
20	.3048	.3048	.3429	.381	.2286
21	.2667	.1905	.2477	.2477	.1905
22	.2286	.1715	.1715	.2096	.1334
23	.1524	.1524	.1334	.1905	.1334
24		.1524	.1524	.1524	.1715
Max	.3429	.4572	.4382	.4763	.4763
Min	.1524	.1334	.1334	.1143	.1143
Avg	.2286	.2429	.2477	.2429	.2191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 205 / 11kv Belkheda gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1715	.1334	.1334
2		.1334	.1715	.1524	.1334
3		.1524	.1905		.1524
4		.2286	.2096	.2286	
5		.3048	.2667	.2667	.2477
6		.4191	.3048	.4001	.4763
7		.5335	.5335	.5144	.5335
8		.4572	.4191	.5335	.4954
9		.3048	.362	.381	.3048
10		.2096	.1715	.1715	.1143
11		.1905	.0953	.0953	.0953
12		.1334	.0953	.0762	.0762
13		.1143	.1334	.0953	.0762
14		.1143	.1143	.0762	.0953
15		.1143	.0953	.0762	.0953
16		.1143	.1334	.0953	.1334
17		.1905	.1524	.1905	.1715
18	.2667	.362	.3048	.4001	.3429
19	.3429	.4191	.381	.381	.381
20	.2667	.381	.362	.3048	.3429
21	.2286	.1905	.2096	.2096	.2286
22	.1715	.1715	.1524	.1524	.1524
23	.1334	.1715	.1334	.1334	.1524
24		.1334	.1715	.1334	.1334
Max	.3429	.5335	.5335	.5335	.5335
Min	.1334	.1143	.0953	.0762	.0762
Avg	.2350	.2366	.2223	.2261	.2203

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 206 / 11kv saigawan gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1905	.1715
2		.1905	.1905	.2286	.1715
3		.2096	.1905	.2667	.2096
4		.2667	.2286	.3239	.2667
5		.381	.2667	.362	.3048
6		.4572	.381	.4382	.4954
7		.5716	.5525	.5335	.4954
8		.4954	.4763	.4954	.4763
9		.4191	.381	.4382	.2667
10		.3048	.2477	.2667	.1715
11		.2286	.1715	.1905	.1715
12		.1905	.1524	.1905	.1715
13		.1524	.1715	.1905	.1715
14		.1524	.1334	.1524	.1715
15		.1715	.1524	.1905	.1905
16		.1905	.1715	.1905	.1905
17		.2667	.1905	.2667	.2096
18	.3048	.381	.3429	.4954	.381
19	.381	.4191	.4382	.4572	.4191
20	.3429	.362	.3048	.381	.381
21	.2667	.2667	.2667	.2477	.3429
22	.2286	.2477	.2286	.1905	.2286
23	.1905	.2286	.1905	.1905	.2096
24		.1905	.2096	.1715	.1905
Max	.381	.5716	.5525	.5335	.4954
Min	.1905	.1524	.1334	.1524	.1715
Avg	.2858	.2889	.2596	.2937	.2691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 201 / 11 KV NADARPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
5	.724		1.2003
7	1.7337		
8	.4001		
9			.3048
11	.1646		.1646
15	.1463		
17			.2195
18		.2286	
21	.1886		
23	.6344		.7888
24		.8573	.8002
<b>Max</b>	<b>1.7337</b>	<b>.8573</b>	<b>1.2003</b>
<b>Min</b>	<b>.1463</b>	<b>.2286</b>	<b>.1646</b>
<b>Avg</b>	<b>.5702</b>	<b>.5430</b>	<b>.5797</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 202 / 11 KV PISHOR Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.8954
6	1.2193		
9			.8383
11	.5144	.5335	.5335
15	.3429		
17			.5906
18		.8573	
21	.6859		
23	.4191		.4001
24	.4001	.4001	.4191
<b>Max</b>	<b>1.2193</b>	<b>.8573</b>	<b>.8954</b>
<b>Min</b>	<b>.3429</b>	<b>.4001</b>	<b>.4001</b>
<b>Avg</b>	<b>.5970</b>	<b>.5970</b>	<b>.6128</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 203 / 11kv KOLAMBI AG WITH SDT      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.362
7	.4572		
8	.4191		
9			.362
11	2.4078	2.6673	2.1792
15	2.6216		
18		.3429	
21	.2743		
23	.2743		
24	.3429	.1905	.2667
<b>Max</b>	<b>2.6216</b>	<b>2.6673</b>	<b>2.1792</b>
<b>Min</b>	<b>.2743</b>	<b>.1905</b>	<b>.2667</b>
<b>Avg</b>	<b>.9710</b>	<b>1.0669</b>	<b>.7925</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 204 / 11 KV RAMNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
5		.6478
7	.8192	
8	.4191	
9		.362
11	.2263	.1646
15	.1886	
21	.2195	
23	.3658	
24	.4763	.4763
<b>Max</b>	<b>.8192</b>	<b>.6478</b>
<b>Min</b>	<b>.1886</b>	<b>.1646</b>
<b>Avg</b>	<b>.3878</b>	<b>.4127</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 205 / 11kv Nadarpur gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.0572
7	.1905		
8	.1905		
9			.1143
11	.0572	.0572	.0572
13	.0381		
15	.0381		
18		.0953	
21	.0381		
23	.0191		
24		.0381	.0381
Max	.1905	.0953	.1143
Min	.0191	.0381	.0381
Avg	.0817	.0635	.0667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 207 / 11KV KOLAMBI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
5			.2858
7	.5716		
8	.3239		
9			.3429
11	.1524		.1524
13	.1334		
15	.1334		
18		.2286	
21	.1905		
23	.1334		
24	.1334	.0762	.1334
Max	.5716	.2286	.3429
Min	.1334	.0762	.1334
Avg	.2215	.1524	.2286



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 201 / 11 KV CHINCHOLI (LI)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7301	.6783	.6783	.9126
2			.7301	.6783	1.0174	.9126
3			.9126	1.0174	1.2003	1.0951
4			.9126	1.5261	1.3565	1.0951
5			1.4601	1.6956	1.5261	1.4601
6			1.4601	1.8652	1.7128	1.4601
7			2.1902	1.8652	1.6956	1.8252
8			2.0077	1.6956	1.6956	2.0077
9			1.4601	1.5261	1.5261	1.2069
10			1.0951	.8478	1.0951	.8621
11			.7301	.8564	.9126	.5173
12			.5476	.6783	.9126	.3448
13			.5087	.6783		.3448
14			.5087	.6783		.3448
15			.5087	.5087	.365	.3448
16			.6783	.5087	.7301	.5173
17			.6783		1.0951	.8621
18		1.0951	1.3717	1.6956		1.2932
19		1.2776	1.3717	1.5261	2.0077	1.8252
20		2.0077	1.2003	1.0174	1.8252	2.0077
21		1.4601	1.0174	.6783	1.4601	1.4601
22	.6874	1.2776	.8478	.6783	1.2776	1.0951
23		1.0951	.8478	.6783	.7301	1.0951
24			.7301	.6783	.6783	.9126
Max	.6874	2.0077	2.1902	1.8652	2.0077	2.0077
Min	.6874	1.0951	.5087	.5087	.365	.3448
Avg	.6874	1.3689	1.0211	1.0546	1.2142	1.0751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 202 / 11 KV WAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5173	.6783	.6859	.5173
2		.5173	.6783	.6783	.5173
3		.6874	.8478	.8573	.5173
4		.6874	1.0174	.8478	.6897
5		.8621	1.0174	1.0174	.6897
6		.8592	1.1869	1.0277	.9031
7		1.0345	1.1869	1.0174	.8621
8		.8621	1.1869	1.0174	1.0345
9		.6897	1.0174	1.0288	.7725
10		.6897	2.0348	1.0345	2.0485
11		1.3794	2.0348	1.0345	2.2192
12		1.3794	1.8652	1.3794	2.1338
13		1.8652	1.95	1.8966	2.2192
14		1.8652	1.8652	2.069	2.3899
15		1.6956	1.8652	2.2415	2.3899
16		1.8652	1.8652	1.8061	2.2192
17		1.6956	2.0348	1.3794	2.1338
18	.6897	1.0174	1.0174	.6897	.6866
19	.8621	1.0174	1.0174	1.0345	.8621
20	1.0345	.8573	.8573	1.0345	1.0345
21	.8621	.6783	.8573	.8621	.6897
22	.6897	.5144	.6843	.6874	.6897
23	.6897	.5144	.6859	.6897	.6866
24		.5173	.5144	.6843	.5418
Max	1.0345	1.8652	2.0348	2.2415	2.3899
Min	.6897	.5144	.5144	.6783	.5173
Avg	.8046	1.0112	1.2486	1.1126	1.227

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 203 / 11 KV GANESHPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)
1		.3612
2		.8276
3		.9211
4		1.0122
5		1.1017
6		1.463
7		1.6436
8		1.9867
9		.5138
10	.3612	.3426
11	.2586	.2569
12	.2529	.2569
13	.3251	.2569
14	.4696	.2569
15	.4515	.3426
16	.6863	.3426
17	.8669	.5138
18	.9031	.6851
19	.8669	
20	1.0476	
21	1.1017	
22	.9031	
23	.5057	
24		.3793
Max	1.1017	1.9867
Min	.2529	.2569
Avg	.6429	.7087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 204 / 11 KV TAKLI (A)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	19-DEC-17
HR	Load (MW)	Load (MW)
1		.5087
2		.5256
10	.2578	
24		.5087
Max	.2578	.5256
Min	.2578	.5087
Avg	.2578	.5143

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 205 / 11 KV Wadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5418	.6443	.7015	.6502
2		.578	.7461	.7699	.6502
3		.578	.8648	.8897	.6863
4		.6502	.9835	.9665	.7947
5			1.0174	1.0343	.8669
6		.6863	1.1191	1.0852	1.0476
7		.7405	1.1022	1.1145	1.1017
8		1.0114	1.0174	.9835	1.0669
9		1.1017	.6952	.78	
10		.8489	2.4078	1.77	1.866
11		.6863	2.4417	1.9867	2.198
12		2.2757	2.4417	2.1312	2.4352
13		2.5434	2.4756		2.4036
14		2.6113	2.3061		1.8818
15		2.8826	2.2721	2.5828	2.0873
16		2.8656	2.1874	2.4563	2.2771
17		2.3739	1.9839	2.0951	2.1506
18	1.0476	.8745	1.0343	.885	.8502
19	1.0476	.8573	.9156	.9211	1.0476
20	1.1017	.6783	.823	1.0476	1.1017
21	1.0114	.6516	.6274	.8669	.8669
22	.6863	.5256	.5256	.6863	.6863
23	.6502	.4748	.5087	.6502	.6863
24		.5418	.6443	.5765	.6502
Max	1.1017	2.8826	2.4756	2.5828	2.4352
Min	.6502	.4748	.5087	.5765	.6502
Avg	.9241	1.1991	1.3244	1.2264	1.3067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 206 / 11 KV NEW NEVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.815	1.8652	2.4417	1.9197
2		1.8499	2.1365	2.6621	2.0593
3		1.9895	2.2721	2.7374	2.1965
4		2.0244	2.4078	2.8487	2.3385
5		2.0593	2.4926		2.4607
6		2.0942	2.5434	2.9334	2.7225
7		2.2687	2.5434	2.9334	2.5398
8		1.1693	1.0343	1.153	1.05
9			.9326	1.0802	.5409
10			.2035	.6632	
11			.2374	.5235	.2545
12			.3052	.4537	.2386
13		.4409	.2713	.3141	.2068
14		.5256	.1696	.2792	.2068
15			.2374	.2443	.2545
16		.5596	.2374	.3141	.35
17		.5596	.4578	.349	.4136
18	.541	.9259	.9259	.7504	.9704
19	.6632	.8916	1.0288	.9773	1.0122
20	.8377	.8221	.8573	1.0645	.9773
21	.89	.703	.583	.7679	.7155
22	.6632	1.0974	1.6278	.6632	.6276
23	.6283	1.1869	1.6956	.541	.5235
24		1.7452	1.8482	2.4006	1.7452
Max	.89	2.2687	2.5434	2.9334	2.7225
Min	.541	.4409	.1696	.2443	.2068
Avg	.7039	1.3015	1.2048	1.2650	1.1445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 201 / 11 KV NACHANWEL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2572	.1715	.1715
2		.2572	.2572	.1715	.2572
3		.2572	.2572	.1715	.2572
4		.2572	.3429		.2572
5		.3429	.3429	.2572	.3429
6		.4287	.4287	.4287	.3429
7		.4287	.4287	.4287	.4287
8		.4287	.4287	.4287	
9		.3429	.5144	.3429	.2572
10		.6001	.6859	.6001	.6001
11		.9431	.8573	.8573	.7716
12		1.286	.8573		.9431
13		1.5432	.8573	1.286	1.0288
14		1.5432	.8573	1.2003	1.286
15		1.4575	.8573	1.2003	
16		1.1145	.9431	1.1145	1.0288
17		.8573	.9431	1.0288	1.0288
18		.2572		.2572	.2572
19		.1715	.3429	.3429	.1715
20		.2572	.3429	.2572	.1715
21		.2572	.2572	.1715	.1715
22		.2572	.1715	.1715	.2572
23	.2572	.1715	.1715	.2572	.1715
24		.1715	.2572	.1715	.1715
Max	.2572	1.5432	.9431	1.286	1.286
Min	.2572	.1715	.1715	.1715	.1715
Avg	.2572	.5751	.5069	.5144	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 202 / 11 KV DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.2572	.1715	.2572
2			.2572	.2572	.3429
3		.3429	.3429	.3429	.4287
4		.3429	.5144		.5144
5		.4287	.5144	.6859	.5144
6		.6001	.6001	.7716	.6859
7		.6001	.6859	.7716	.7716
14		.1715	.0857	.1715	.0857
15		.1715	.0857	.1715	.0857
16		.1715	.1715	.2572	.1715
17		.1715	.1715	.1715	.1715
18		.1715	.1715	.1715	.1715
19		.2572	.2572	.3429	.2572
20		.1715	.2572	.1715	.2572
21		.1715	.1715	.1715	.1715
22		.2572	.0857		.2572
23	.1715	.3429	.0857	.1715	.2572
24		.1715	.2572	.1715	.2572
Max	.1715	.6001	.6859	.7716	.7716
Min	.1715	.1715	.0857	.1715	.0857
Avg	.1715	.2794	.2763	.3108	.3144



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 203 / 11 KV SAROLA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.2572	.2572	.1715
2			.3429	.3429	
3		.3429	.3429	.4287	.3429
4		.4287	.4287	.4287	.5144
5		.4287	.5144		.6001
6		.5144	.5144	.6001	.6859
7		.5144	.6859	.6001	.7716
14		.0857	.0857	.1715	.0857
15		.0857		.1715	.0857
16		.0857		.2572	.0857
17		.1715		.2572	.1715
18		.1715	.2572	.3429	.1715
19		.2572	.4287	.4287	.2572
20		.2572	.4287	.3429	.2572
21		.1715	.3429	.2572	.2572
22		.2572	.2572	.1715	.2572
23	.2572	.2572	.1715	.2572	.1715
24		.2572	.2572	.1715	.1715
Max	.2572	.5144	.6859	.6001	.7716
Min	.2572	.0857	.0857	.1715	.0857
Avg	.2572	.2673	.3544	.3228	.2975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 204 / 11KV DONGARGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.0857	.0857
2		.0857	.0857	.0857	.0857
3		.1715	.1715	.1715	.0857
4		.2572	.1715	.1715	.1715
5			.2572		.1715
6		.3429	.2572	.3429	.2572
7		.3429	.3429	.3429	
8		.2572	.2572	.3429	.2572
9		.1715	.2572	.2572	.2572
10		.0857	.0857	.1715	.0857
11		.0857	.0857	.0857	.0857
12		.0857	.0857	.0857	.0857
13		.0857	.0857	.0857	.0857
14		.0857	.0857	.0857	.0857
15		.0857	.0857	.0857	.0857
16		.0857	.0857	.0857	.0857
17		.0857	.0857	.0857	.0857
18		.1715	.2572	.1715	.1715
19		.2572	.3429	.3429	.2572
20		.1715	.2572	.2572	.2572
21			.1715	.1715	.1715
22			.0857	.0857	.0857
23	.0857		.0857	.0857	.0857
24		.0857	.0857	.0857	.0857
Max	.0857	.3429	.3429	.3429	.2572
Min	.0857	.0857	.0857	.0857	.0857
Avg	.0857	.1543	.1607	.1640	.1379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 205 / 11 kv NACHANWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.3429	.1715	
2			.5144	.2572	.2572
3		.3429	.6001	.3429	.3429
4		.4382	.7716	.4287	.6001
5		.5144	.6859	.6001	.6859
6		.6001	.7716		.6859
7		.7716	.8573	.8573	.8573
8			.7716	.7716	.7716
9		.6001	.6001	.6001	
10		.4287	.4287	.4287	.4287
11		.3429	.2572	.3429	.2572
12		.2572	.2572	.2572	.1715
13		.1715	.1715	.1715	.1715
14		.1715	.1715	.1715	.1715
15		.1715	.1715	.1715	.1715
16		.2572	.1715	.1715	.1715
17		.3429	.2572	.2572	.2572
18		.6001	.6001	.5144	.4287
19		.6859	.6859	.7716	.6001
20		.4287	.6001	.6001	.5144
21			.4287	.3429	.4287
22			.2572	.2572	.3429
23	.1715		.1715	.1715	.2572
24		.1715	.2572	.1715	.1715
Max	.1715	.7716	.8573	.8573	.8573
Min	.1715	.1715	.1715	.1715	.1715
Avg	.1715	.3931	.4501	.3839	.3975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 206 / 11 kv SAROLA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2572	.0857	.2572
2		.2572	.2572	.0857	.2572
3		.2572	.2572	.1715	.3429
4		.3429	.3429	.2572	
5			.5144		.5144
6			.5144	.4287	.6001
7		.6516	.6001	.4287	
8			.4287		.4287
9		.4287	.3429	.3429	
10		.2572	.2572	.2572	.1715
11		.1715	.1715	.1715	.1715
12		.1715	.1715	.0857	.0857
13		.0857	.0857	.0857	.0857
14		.0857	.0857	.0857	.0857
15		.1715		.0857	.0857
16		.1715		.0857	.0857
17		.2572		.0857	.1715
18		.3429	.4287	.1715	.2572
19		.4287	.5144	.2572	.4287
20		.3429	.4287	.4287	.3429
21		.1715	.1715	.1715	.1715
22		.1715	.0857	.1715	.1715
23	.1715	.1715	.0857	.1715	.2572
24		.1715	.1715	.0857	.2572
Max	.1715	.6516	.6001	.4287	.6001
Min	.1715	.0857	.0857	.0857	.0857
Avg	.1715	.2515	.2939	.1910	.2490

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 207 / MOHADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.1715	.1715	.1715
2		.2572	.2572	.2572	.2572
3		.2572	.2572	.2572	.2572
4		.2572	.3429	.3429	.2572
5		.3429	.3429	.3429	.3429
6		.3429	.4287	.4287	.4287
7		.3429	.6001	.4287	.5144
14		.0857	.0857	.1715	.1715
15		.0857	.0857	.0857	.0857
16		.0857	.0857	.0857	.0857
17		.0857	.0857	.1715	.0857
18		.0857	.0857	.0857	.0857
19		.1715	.0857	.0857	.0857
20		.0857	.0857	.0857	.0857
21		.0857	.0857	.0857	.0857
22		.1715	.0857	.0857	.0857
23	.1715	.1715	.0857	.0857	.0857
24		.1715	.1715	.1715	.1715
Max	.1715	.3429	.6001	.4287	.5144
Min	.1715	.0857	.0857	.0857	.0857
Avg	.1715	.1857	.1905	.1905	.1857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 210 / MOHRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.1715	.2572
2			.2572	.1715	.2572
3		.2572	.2572	.2572	.2572
4		.2572	.2572		
5		.3429	.3429	.3429	.3429
6		.4287	.4287	.3429	.4287
7		.4287	.5144	.3429	.4287
8		.2572	.4287	.3429	.4287
9		.1715	.4287	.2572	.2572
10		.2572	.4287	.3429	.2572
11		.5144	.4287		.3429
12		.6859	.6001	.7716	.5144
13		.9431	.6859	.8573	.5144
14		.8573	.6859	.7716	.5144
15		.8573	.6859	.6859	.4287
16		.7716	.6001	.6859	.3429
17		.7716	.5144	.5144	.3429
18		.2572	.3429	.4287	.2572
19		.1715	.3429	.4287	.2572
20		.2572	.3429	.3429	.3429
21		.1715	.2572	.1715	.1715
22		.1715	.1715	.1715	.2572
23	.1715		.0857	.1715	.2572
24		.1715	.1715	.1715	.1715
Max	.1715	.9431	.6859	.8573	.5144
Min	.1715	.1715	.0857	.1715	.1715
Avg	.1715	.4170	.3930	.3975	.3318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 201 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.5601	.6401	.7202
2		.6859		.6401	.7202
3		.8573		.7202	.8002
4		.9431		.8002	1.0082
5		1.0288	.381	.8802	1.1203
6		1.0631	.8642	1.0402	1.1683
7		1.8176	1.5203	1.6164	1.7124
8		.4801	.6287	.583	
9		.5144	.4481	.5144	.4954
10		.3429	.2881	.3086	.381
11		.1886	.16	.2058	.2286
12			.128	.1715	.1905
13		.0857	.096	.1715	.1905
14		.0343		.0686	.1905
15		.0381	.064	.2572	.1905
16		.1143	.064	.2058	.2058
17	1.3717	.0381	.2286	.3201	.2401
18	.12	.4763	.5525	.4801	.4801
19	.1715	.6287	.6287	.5761	.5144
20	.1715	.5144	.5716	.4801	.5144
21	.0857	.4001	.4954	.3361	.3429
22	.0857	.4801	.5716	.7811	.703
23	.0857	.4801	.4801	.6562	.703
24		.0857	.5601	.5601	.7202
Max	1.3717	1.8176	1.5203	1.6164	1.7124
Min	.0857	.0343	.064	.0686	.1905
Avg	.2988	.5210	.4646	.5422	.5887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 202 / 11KV NIMBHORA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1143	.1905	.1524
2		.1143	.1143	.1905	.1524
3		.1143	.1524	.1905	.1905
4		.1715	.2286	.2286	.2477
5		.1715	.2858	.2858	.3048
6		.2229	.2858	.3239	.3429
7		.2096	.2286	.3048	.3429
8		.2667	.2858	.1715	.3239
9		.0762	.2286	.1715	
10		1.0364	1.8099	1.4918	1.2955
11		1.0688	2.2862	1.9376	1.8623
12		1.3279	2.1285	2.0576	2.1214
13		1.5432	2.0485	2.1091	2.0805
14		1.6289	2.0805		2.0645
15			2.1285	2.1948	2.1214
16		1.7147	2.1052	.1886	2.3148
17	1.3717		2.1052	.0953	2.1605
18	.12	.2286	.1781	.1905	.1886
19	.1715	.2858	.2667	.3048	.1715
20	.1715	.2858	.2858	.2286	.1715
21	.0857	.2858	.2477	.1905	.1715
22	.0857	.2286	.2096	.1524	.1372
23	.0857	.1905	.1905	.1524	.1372
24		.1524	.1524	.1905	.1524
Max	1.3717	1.7147	2.2862	2.1948	2.3148
Min	.0857	.0762	.1143	.0953	.1372
Avg	.2988	.5199	.8395	.5888	.8351



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 203 / 11KV DEVPUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.1143	.0572	.128
2		.2096	.1143	.0572	.128
3		.2096	.1143	.0953	.144
4		.2858	.1524		.16
5		.3048	.1524	.1905	.192
6		.3048	.2286	.2286	.192
7		.3048	.2286	.2286	.192
8		.381	.1905	.2058	.2286
9		.381	.192	.2743	.192
10		.3048	.9122	.9602	.6478
11		1.2955	.9762	1.286	.8002
12		1.2498	.9602	1.3717	
13		1.2003	.9602	1.3717	
14			1.0402	1.3717	.9602
15		.381	.9602	1.3717	1.2163
16		.381	1.2955	1.3032	1.3717
17	1.2955	1.3336	.144	.8802	1.3032
18	.3048	.2858	.2286	.16	.2743
19		.2858		.192	
20	.2858	.2286	.1715	.192	.2058
21	.2096	.1715	.1334	.144	.1543
22	.2096	.1715	.0762	.144	.1372
23	.2096	.1715	.0572	.144	.1372
24		.2096	.1715	.0572	.128
Max	1.2955	1.3336	1.2955	1.3717	1.3717
Min	.2096	.1715	.0572	.0572	.128
Avg	.4192	.4461	.4163	.5342	.4235

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 204 / 11 KV MEHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.381	.4763	.3239
2		.381	.4763	.3239
3		.4191	.5716	.4115
4		.4763	.5716	.5075
5		.6097	.6668	.5716
6		.743	.7811	.6706
7		1.086	1.1431	.8962
8		.1334	.0857	.1524
9		.0953	.0857	.1334
10		.0762		.1334
11		.0762		.1143
12		.0953		.0762
13		.0762		.0572
14		.0762		.1143
15		.0762		.0953
16	.0953	.0762		
17	.0762	.1143		
18	.1143	.1524	.1524	
19	.1524	.1334	.1143	
20	.1143	.0953	.1143	
21	.0572	.381	.0953	
22	.2858	.4763	.285	
23	.381	.4763	.3109	
24		.381	.4763	.3109
Max	.381	1.086	1.1431	.8962
Min	.0572	.0762	.0857	.0572
Avg	.1596	.2953	.4004	.3058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 205 / 11KV NIMBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0953	.0953	.0762
2		.0953	.0953	.0953	.0762
3		.0953	.0953	.1334	.0953
4		.1905	.1715	.1905	.1143
5		.1905	.1715	.2286	.1524
6		.2286	.2477	.1715	.1524
7		.3429	.2477	.3048	.0953
8		.3239	.1715	.2572	.1715
9		.2858	.2096	.2229	.1143
10		.2096	.1334	.1029	
11		.1143	.1143	.0514	.1143
12		.0953	.1143	.0514	.0762
13		.0514	.0762	.0514	.0572
14		.0514	.0762		.0762
15		.0762	.0762	.0514	.0572
16		.0762	.0953	.0514	.0857
17	.1334		.1334	.0762	.12
18	.2667	.2286	.2096	.1143	.1715
19	.2858	.2286	.2667	.1334	.2401
20	.2096	.1715	.1905	.0953	.1715
21	.1524	.0953	.1524	.0953	.1372
22	.0953	.0953	.0953	.0953	.0686
23	.0953	.0953	.0953	.0762	.0686
24		.0953	.0953	.0953	.0762
Max	.2858	.3429	.2667	.3048	.2401
Min	.0953	.0514	.0762	.0514	.0572
Avg	.1769	.1536	.1429	.1235	.1117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 206 / 11KV WASADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0953	.0572	.0762	.0762
2		.0953	.0572	.0762	.0762
3		.0953	.0953	.0762	.1143
4		.2096	.1334	.1143	.1334
5		.1905	.1524	.1524	.1715
6		.2477	.2286	.2286	.1905
7		.2667	.1905	.2477	.1905
8		.2286	.2286	.1886	.2667
9		.2096	.1715	.1715	.1905
10			.1143	.1029	.1143
11		.0953	.0953	.0514	.0953
12		.0953	.0953	.0514	.0762
13		.0514	.0762	.0514	.0572
14		.0514		.0686	.0762
15			.0762	.0514	.0572
16			.1524	.0514	.1372
17	.1143	.0953	.1905	.1334	.1715
18	.2096	.2096	.2096	.2286	.2058
19	.2477	.2096	.2667	.2477	.2229
20	.1905	.1334	.1715	.2477	.2229
21	.0953	.0953	.1334	.1905	.1715
22	.0953	.0762	.0762	.1334	.0857
23	.0953	.0762	.0762	.0953	.0686
24		.0953	.0762	.0762	.0762
Max	.2477	.2667	.2667	.2477	.2667
Min	.0953	.0514	.0572	.0514	.0572
Avg	.1497	.1392	.1359	.1297	.1354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 207 / 11KV MEHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2096	.0953	.1143	.1143
2		.2096	.1143	.1524	.1143
3		.2096	.2286	.2286	.1905
4		.2858	.3048	.3048	.381
5		.381	.4191	.381	.4572
6		.5144	.5144	.4954	.5716
7		.5335	.5525	.5716	.5716
8		.5335	.4191	.4801	.5525
9		.4001	.3048	.3772	.4191
10		.2667	.2477	.1715	.2858
11		.1334	.1143	.1029	.1524
12		.0953	.0953	.0857	
13		.0857	.0762	.0686	
14			.0762	.0514	.0953
15			.0762	.0686	.0953
16		.0953	.1143		.0857
17	.2096	.1524	.1715		.1372
18	.381	.362	.3239	.3429	.3429
19	.4763	.4572	.4954	.4763	.4287
20	.2858	.2667	.3429	.3429	.3429
21	.2096	.1524	.3048	.2477	.2229
22	.2096	.1143	.2286	.1143	.1029
23		.0953	.1905	.1143	.1029
24		.2096	.0953	.1143	.1143
Max	.4763	.5335	.5525	.5716	.5716
Min	.2096	.0857	.0762	.0514	.0857
Avg	.2953	.2620	.2461	.2458	.2673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 201 / 11 KV KARANJKHEDA AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0686	.1029	.0953
2		.0762	.0686	.1029	.0953
3		.0762	.0686	.12	.0953
4		.0762	.0686	.12	.0953
5		.0762	.0686	.1029	
6		.0762	.0686	.0857	.0953
7		.0762	.0686	.0686	.0953
8		.0762	.0514	.0514	.0572
9		.0381	.0514	.0514	.0171
10		.9878	.8745	1.085	1.4575
11		1.2631	1.3717	1.7814	1.9757
12		1.4251	1.7147	1.7166	2.1538
13		1.3603	2.0062	1.9433	2.0405
14		1.6518	1.9204	2.1538	2.1538
15		1.5223	1.9547	2.251	2.1052
16		1.6518	2.0405	2.1214	2.2186
17		1.6842	2.0405	1.668	2.1862
18		.0343	.0686	.0762	.0514
19		.0686	.0686	.1143	.1029
20		.0686	.0857	.0953	.1029
21		.0686	.0857	.0953	.1029
22		.0671	.0686	.0953	.1029
23	.0762	.0686	.0686	.0953	.081
24		.0762	.0686		.0953
Max	.0762	1.6842	2.0405	2.251	2.2186
Min	.0762	.0343	.0514	.0514	.0171
Avg	.0762	.5269	.6259	.6999	.7642

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 202 / 11 KV NAGAPUR AG ( WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1494	.1372	.1372	.168
2		.1494	.1372	.1543	.1867
3		.168	.1543	.1543	.2054
4		.1867	.1715	.1543	.2054
5		.2054	.1886	.1715	.2054
6		.2241	.2058	.1715	.2241
7		.2427	.2058	.1715	.2241
8		.2054	.1886	.1372	.1867
9		.1494	.0514	.12	.0857
10		1.0526	1.1336	1.2793	1.1822
11		1.4251	1.3717	1.6842	1.5708
12		1.5384	1.7318	1.8299	1.7814
13		1.6032	1.9719	1.8299	1.8299
14		1.6356	1.8861	1.749	1.7166
15		1.2631	1.8347	1.7652	1.6518
16		1.3279	1.8347	1.7166	1.7328
17		1.3603	1.8004	1.668	1.6518
18		.2058	.1372	.2054	.2058
19		.2058	.12	.2427	.2229
20		.1715	.12	.2241	.2058
21		.1715	.12	.2054	.1543
22		.1494	.12	.168	.1543
23	.1307	.1372	.12	.1494	.1543
24		.1307	.1372	.12	.168
Max	.1307	1.6356	1.9719	1.8299	1.8299
Min	.1307	.1307	.0514	.12	.0857
Avg	.1307	.5858	.6617	.6754	.6698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 203 / 11 KV PURANWADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2136	1.0526	.8573	1.2146
2		1.0688	1.1336	.9431	1.2955
3		1.085	1.166	1.1145	1.2955
4		1.1012	1.2308	1.286	1.3765
5		1.1336	1.2955	1.5432	1.4413
6		1.2631	1.3765	1.7833	1.6356
7		1.587	1.7814	1.8861	1.9757
14			.0171		.0514
15			.0343		.0514
16		.0343	.0514		.0514
17		.0514		.0747	.1029
18		.1029	.12	.112	.1372
19		.112	.12	.1307	.1029
20		.1029	.1543	.1307	.1029
21		.1029	.1543	.1307	.12
22		.8907	.6001	1.0526	1.0688
23	1.0202	.9717	.8573	1.1336	1.1336
24		1.0202	1.0364	.9431	1.1822
Max	1.0202	1.587	1.7814	1.8861	1.9757
Min	1.0202	.0343	.0171	.0747	.0514
Avg	1.0202	.7401	.7166	.8748	.7966



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 204 / 11kv KARANJKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2614	.2614	.3429	.2801
2		.3361	.3361	.3772	.3361
3		.4108	.5228	.3772	.4294
4		.5228	.5228	.5316	.5041
5		.6348	.6348	.7545	.6348
6		.8775	.8962	.823	.8589
7		1.0269	1.0456	.9945	1.0082
8		1.0269	1.0642	1.0631	1.1203
9		.8962	.9335	.8916	.8962
10		.7095	.7468	.7842	.7095
11		.4668	.4287	.4108	.5228
12		.3921	.3601	.3547	.4294
13		.3547	.3258	.3547	.2987
14		.3174	.2915	.3361	.3547
15		.3361	.2743	.3734	.3174
16		.4668	.4287	.4108	.2987
17		.5601	.5316	.5975	.5975
18		.9335	.583	.8589	.8215
19		.8775	.6173	.9522	.8775
20		.7468	.5144	.7468	.6908
21		.5601	.3429	.5415	.4854
22		.4854	.2743	.3921	.3921
23	.2987	.3547		.2987	.2987
24		.2241	.2427	.2743	.2614
Max	.2987	1.0269	1.0642	1.0631	1.1203
Min	.2987	.2241	.2427	.2743	.2614
Avg	.2987	.5741	.5295	.5768	.5593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 206 / CHIMNAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1867	.1372	.1494
2		.2241	.2241	.1543	.1867
3		.2987	.2614	.1715	.2614
4		.3734	.3361	.2572	.3361
5		.4481	.4481	.4458	.4854
6		.5975	.5228	.5658	.6348
7		.5601	.5601	.5144	.5975
8		.5228	.5228	.4801	.5415
9		.3734	.3734	.3772	.3921
10		.2241	.2614	.2614	.2614
11		.1307	.1543	.1867	.1307
12		.112	.1543	.112	.0934
13		.112	.1372	.0934	.0747
14		.0934	.0857	.112	.0934
15		.0934	.1543	.112	.0934
16		.1307	.12		.0934
17		.2429	.2572	.2987	.2054
18		.4854	.3429	.4481	.4854
19		.4294	.4287	.4481	.4481
20		.3361	.463	.3361	.3174
21		.2427	.3772	.2801	.2801
22		.1494	.2915	.168	.168
23	.1494	.1494	.2401	.1494	.1494
24		.1494	.1494	.1715	.1494
Max	.1494	.5975	.5601	.5658	.6348
Min	.1494	.0934	.0857	.0934	.0747
Avg	.1494	.2777	.2939	.2731	.2762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 200 / 11 kv Narmada Express NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
OUTGOING

DATE	20-DEC-17
HR	Load (MW)
12	1.2967
Max	1.2967
Min	1.2967
Avg	1.2967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 201 / 11 Kv Deulgaon(Bz) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.168	.1494	
2	.1132	.1867	.168	.0914
3	.1509	.2054	.1698	
4	.1509	.2263	.1886	.1109
5	.1886	.1509	.1886	
6	.1886	.1698	.2075	.1867
7	.1886	.2075	.2263	
8	.5281	.2075	.5281	.5658
9	.415	.3772	.4338	.4409
10	.2713	.2641		.3391
11	.2058	.1886		.3052
12	.2058	.132	.1132	.2713
13	.1132	.1132		.2543
14	.1357	.0943	.1132	.1696
15	.1494	.1132		.1844
16		.1509	.132	.2012
17		.2263	.1886	
18		.3584		.2374
19		.4715		
20		.415	.3395	.218
21		.1526		.2713
22		.1802	.1867	.2543
23		.1943	.0943	.2713
24	.0943	.2591	.1509	.0934
Max	.5281	.4715	.5281	.5658
Min	.0943	.0943	.0943	.0914
Avg	.2008	.2172	.2105	.2481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 202 / 11 Kv Kotnandra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	.5087	1.1317	
2	1.2449	.6036	1.2449	.8676
3	1.3203		1.3203	
4	1.4712	.78	1.4146	1.1317
5	1.6975	.7122	1.5089	
6	1.8107	.6783	1.6975	1.6975
7	1.5089	.7167	1.7918	
8	1.6598	.7545	1.8296	1.5089
9	1.4335	.679	1.5089	1.2289
10	.9724	.5304		.9995
11	.6478	.5571	.6642	
12	.7122	.583	.8002	1.1142
13	.7461	.6401		1.0159
14	.7865	.7282	.7537	.9995
15	.39	.7011		
16	.8907	.6401	.663	1.0159
17	1.004	.852	.8048	1.0814
18	1.0513	1.3769		
19	1.1191	1.773		1.2887
20	1.153	1.6975	1.1317	1.2887
21	1.1336			
22	1.2887		.9431	.7865
23	.9831		.8488	.9995
24	1.1317	1.0174	1.1317	.7922
Max	1.8107	1.773	1.8296	1.6975
Min	.39	.5087	.663	.7865
Avg	1.1370	.8265	1.1772	1.1135

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 203 / 11 Kv Ghatnandra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.9522	1.1203	
2	.7762	1.1458	1.2323	1.086
3	1.0059	1.2071	1.2936	
4	1.086	1.1222	1.39	1.3717
5	1.1946	1.1222	1.4632	
6	1.2178	1.046	1.7375	1.56
7	1.749	1.406	1.7551	
8	1.8298	1.1576	1.7737	1.8107
9	1.6057	1.6057	1.531	
10	1.2378	1.4003		1.3904
11	.9259	1.2323	1.3203	
12	.8417	1.0456		
13	.583	.8402	.6602	
14	.5087	.7207		.6443
15	.6344	.7468	.7545	.6104
16	.6952	.9149	.8488	.5426
17	.7122	1.3443	1.1694	.6783
18	.7461	1.8111		
19	.78	1.419		.8478
20	1.0343	1.307	1.6032	
21	.8139			1.0513
22	.8139		.6401	1.153
23	1.0159		.7087	1.1869
24	.5658	1.0322	.9335	.7682
Max	1.8298	1.8111	1.7737	1.8107
Min	.5087	.7207	.6401	.5426
Avg	.9603	1.1704	1.2186	1.0501

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 204 / 11 Kv Shindephal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.5658	.5281	
2	1.0562	.7167	.5658	.4904
3	1.1317	.7545	.679	
4	1.2449	.8676	.7545	.8488
5	1.3203	.9054	.9431	
6	1.4335	.9431	1.0562	1.4146
7	1.1506	.9808	1.094	
8	1.2826	1.1694	.7922	1.1317
9	.9431	1.1317	.7733	.9496
10	.6062	.4024		.7537
11	.4999	.4588		.7865
12	.463	.4801	.2458	.8192
13	.4588	.4744		1.0159
14	.5624	.4687	.6478	.9831
15	.4268			.5243
16	.6226	.2187	.7122	
17	.7865	.6874	.5935	.6226
18	.8139	1.0374		
19	.8139	1.4146		.8139
20	.78	1.2449	1.1317	
21	.5935			.78
22	.78		.8488	.7373
23	.8478		.679	.6554
24	.9431	.8648	.6036	.5658
Max	1.4335	1.4146	1.1317	1.4146
Min	.4268	.2187	.2458	.4904
Avg	.8559	.7894	.7440	.8172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 205 / 11 Kv Charner SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	1.0159	1.1203	
2	.7392	1.0814	1.2197	.985
3	.9145	1.0159	1.2803	
4	1.0745	.881	1.3756	1.1145
5	1.0852		1.4327	
6	1.0814	1.2209	1.5074	1.166
7	1.5364	1.1736	1.5089	
8	.7922	1.2826	.7922	.679
9	.6036	.4715	.7733	.5935
10	.4409	.3772		.2713
11	.3391	.3018		.2543
12	.2374	.2054	.2829	.3052
13	.1865	.2241		.3391
14		.3326		.3561
15		.3395		.2713
16	.2713	.3206	.3018	.2883
17	.3052	.4294	.415	.3052
18	.3391	.8215		.3052
19	.5087	.7167		
20	.6104	.5658	.679	
21	.4287			.373
22	.6554		.695	.5087
23	.7537		.8316	.6104
24	.5658	.8139	1.1203	.8779
Max	1.5364	1.2826	1.5089	1.166
Min	.1865	.2054	.2829	.2543
Avg	.6428	.6796	.9585	.5336



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 202 / 11Kv Undengaon feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.5959	.3155	.6661	.4961
2	.3681	.6661	.3681	.7537	.5316
3	.4207	.7011	.5434	.8589	.567
4	.5609	.7712	.6661	1.0166	1.0454
5	.8939	.8589	.8413	1.1393	1.1517
6	1.262	.9991	1.2971	1.262	1.2757
7	1.6476	1.6651	1.5074	1.595	1.382
8	1.0692	1.3146	1.1744	1.262	.9568
9	.7362	1.0341	.7888	1.1043	
10	1.2094	1.0425	1.1744	.7796	.7209
11	.8413	.823		1.1163	.8383
12	.7011			1.0277	1.0442
13		.7316	.8764	1.258	.9389
14	.5959	.6219	.631	1.2757	1.0227
15	.5434	.6584	.6485	1.382	1.1233
16	.6485	.6036		1.2757	1.0395
17	.9114	.823	.929	1.2226	.9389
18	.8764	.0914	.929	.9391	1.0631
19	.9991	.9877	.9991	1.0631	1.0608
20	.9114	.8779	.8589	1.1517	.7796
21	.8238	.5847	.7186	.8682	.6767
22	.7362	.3155	.6836	.6733	.4572
23	.6661	.2804	.6485	.6201	.4024
24		.631	.2454	.6135	.5316
Max	1.6476	1.6651	1.5074	1.595	1.382
Min	.3506	.0914	.2454	.6135	.4024
Avg	.8079	.7686	.8021	1.0385	.8715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 203 / 11Kv Khedi feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.4607	.4252	.4961	.4075
2	.3366	.5138	.5138	.5493	.4784
3	.3721	.567	.5493	.6201	.4252
4	.5316	.6556	.6024	.6733	.567
5	.7442	.7265	.6733	.7265	.8682
6	.8859	.7973	.7796	.7087	.9568
7	.8505	.815	.8859	.9036	1.0808
8	.7442	.7619	.7796	.7973	.7973
9	.691	.567	.5847	.6201	.6733
10	.8682	.7377	.7442		.2561
11	1.0454	.9389	.9745		.2195
12	1.2934	.7042			.1646
13	1.258	1.0562	1.0099	.1595	.1612
14	1.2403	1.0227	.9036	.1772	.1463
15	1.1871	.9892	.815	.1417	.124
16	.9922	.8551	.8859	.1595	
17	.9214	.8215	.8505	.3258	.567
18	.7442	.695	.691	.7442	.6036
19	.8328	.7164	.7973	.8764	.567
20	.7796	.6089	.7265	.9391	.567
21	.691	.5304	.6556	.6201	.4961
22	.6379	.4784	.6024	.2126	.4961
23	.567	.4252	.567	.2279	.5197
24		.4961	.443	.5316	.2658
Max	1.2934	1.0562	1.0099	.9391	1.0808
Min	.3189	.4252	.4252	.1417	.124
Avg	.8058	.7059	.7157	.5338	.4960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 204 / 11Kv Khandala feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1612	.2507	.1254	.197	.1772
2	.197	.3224	.1612	.1612	.2658
3	.1791	.3582	.1612	.1433	.3189
4	.3224	.394	.2507	.2149	.3544
5	.3403	.4656	.3224	.197	.4252
6	.4656	.6089	.5194	.1791	.5258
7	.6089	.6447	.6626	.4119	.6201
8	.3224	.5014	.5194	.5194	.3506
9	.2507	.2507	.2686	.4119	.3012
10	.1433	.1174	.1097	.1595	.0934
11	.197	.1509	.2149	.0532	.0732
12	.394	.2347	.1612	.0354	.0362
13	.2686	.1341	.197		.0366
14	.4477	.1677	.1663	.0709	.4024
15	.2328	.1844	.1433	.0532	.056
16	.394	.2347	.1612	.1063	.0732
17	.2328	.2012	.2328	.1772	.1254
18	.3224	.4252	.3582	.4207	.5304
19		.4024	.4656	.3189	.439
20	.3761	.2561	.3761	.3721	.3292
21	.3403	.1829	.3403	.3506	.1949
22	.3045	.1612	.3045	.1063	.0709
23	.2865	.1433	.2507	.124	.0914
24		.2686	.1075	.1791	.1417
Max	.6089	.6447	.6626	.5194	.6201
Min	.1433	.1174	.1075	.0354	.0362
Avg	.3085	.2942	.2742	.2158	.2514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 201 / 11Kv Sirsala Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1543	.081	.1543
2	.1715	.1543	.081	.1543
3	.1715	.1543	.081	.1543
4	.1715	.1715	.081	.1543
5	.1715	.1715	.0781	.1543
6	.1886	.2058	.081	.1543
7	.1886	.1715	.0953	.1543
8	.1886	.1715	.0953	.1372
9	.1886	.1715	.0686	.12
10	.6859	.8059	.583	.6687
11	.9945	.8059	.8059	.7373
12	1.0288	.8916		.7716
13	1.0631	.7773	.8402	.6859
14	.8573	.5668	.8916	.583
15	.8573	.4049	.8059	.6516
16	.8916	.4049	.7888	.6001
17	.703	.4049	.703	.6001
18	.1715	.0162	.1372	.1372
19	.2058	.0648	.1543	.1543
20	.2058	.0678	.1543	.1543
21	.1886	.0905	.1543	.1543
22	.1886	.081	.1543	.1543
23	.1715	.081	.1543	.1543
24	.1886	.1715	.0953	.1543
Max	1.0631	.8916	.8916	.7716
Min	.1715	.0162	.0686	.12
Avg	.4172	.2984	.3115	.3208

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 202 / 11Kv Hatti Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.081	.0857
2	.1029	.1029	.081	.0857
3	.1029	.1029	.081	.0857
4	.1029	.12	.081	.1029
5	.1029	.1372	.081	.1372
6	.12	.1372	.1134	.1372
7	.1372	.1372	.081	.1372
8	.1372	.12	.125	.1029
9	.1372	.1029	.0857	.0857
10	.3772	.6001	.4115	.463
11	.8573	.703		.5487
12	.823	.7545		.6859
13	.8916	.6478	.9088	.6859
14	.5144	.7773	.9431	
15	.823	.5668	.7888	.6516
16	.8745	.5668	.703	.6001
17	.6516	.4858	.5487	.3772
18	.1029	.0814	.12	.1029
19	.1029	.081	.1372	.1372
20	.12	.0857	.12	.1372
21	.12	.0857	.1029	.1029
22	.1029		.1029	.1029
23	.1029	.081	.1029	.1029
24	.1029	.1029	.081	.0857
Max	.8916	.7773	.9431	.6859
Min	.1029	.081	.081	.0857
Avg	.3172	.2906	.2673	.2498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 203 / 11Kv Ambhai Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0191	.0171
2	.0171	.0171	.0191	.0171
3	.0171	.0171	.0191	.0171
4	.0171	.0171	.0191	.0171
5	.0171	.0171	.0191	.0171
6	.0171	.0171	.0191	.0171
7	.0171	.0171	.0191	.0171
8	.0171	.0171		.0171
9	.0171	.0171	.0171	.0171
10	.1715	.1372	.0514	.0686
11	.3086	.1372	.1715	.1372
12	.3086	.2915	.2229	.1715
13	.3601	.2591	.1715	.2058
14	.3429	.2429	.1715	.2229
15	.2743	.2429	.12	.1543
16	.1886	.2105	.12	.1372
17	.1372	.1619	.1029	.1029
18	.0171	.0162	.0171	.0171
19	.0171	.0162	.0171	.0171
20	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171
22	.0171	.0162	.0171	.0171
23	.0171	.0162	.0171	.0171
24	.0171	.0171	.0191	.0171
Max	.3601	.2915	.2229	.2229
Min	.0171	.0162	.0171	.0171
Avg	.0986	.0814	.0611	.0614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 204 / 11Kv Chinchpur feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1886	.2429	.2401
2	.1715	.1886	.2429	.2401
3	.1715	.2058	.2429	.2401
4	.2058	.2058	.3239	.2572
5	.2401	.3944	.4858	.2058
6	.3429	.583	.6478	
7	.5144	.9088	.8097	
8	.0171	.0171	.0162	
9	.0171	.0171		
10	.0171	.0171		
11	.0171	.0171		.0171
12		.0171		
13	.0171	.0162		
14	.0171	.0162		
15	.0171	.0162		.0171
16	.0171	.0162	.0171	.0171
17	.0171	.0168	.0171	.0171
18	.0171	.0162	.0171	.0171
19	.0171	.0162	.0171	.0171
20	.0171	.0191	.0171	.0171
21	.0171	.0191	.0171	.0171
22	.1372	.2429	.2401	.2915
23	.1372	.2429	.2401	.2743
24	.1715	.1715	.2429	.2401
Max	.5144	.9088	.8097	.2915
Min	.0171	.0162	.0162	.0171
Avg	.1081	.1488	.2258	.1329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 205 / 11Kv Ambhai Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2429	.2229
2	.2401	.2401	.2429	.2229
3	.2572	.2572	.2429	.2229
4	.2915	.3429	.3239	.3429
5	.4973	.463	.4049	.4458
6	.6173	.583	.4049	.6344
7	.3429	.3772	.2429	.3772
8	.5144	.1543	.1619	.3772
9	.6344	.703	.5144	.4458
10	.4801	.3944	.5487	.3772
11	.4115	.3086	.4115	.3258
12	.3086	.2743	.3772	.3086
13	.2572	.2429	.3086	.2401
14	.2572	.2591	.2401	.2229
15	.3086	.3239	.2401	.3086
16	.3772	.3239	.3429	.3258
17	.5658	.4858	.463	.3086
18	.6001	.4858	.583	.5144
19	.4801	.4858	.5316	.4801
20	.4115	.4763	.4287	.3772
21	.3258	.3239	.2743	.3086
22	.3086	.2429	.2229	.2572
23	.3086	.2429	.2229	.2572
24	.2401	.2401	.2429	.2229
Max	.6344	.703	.583	.6344
Min	.2401	.1543	.1619	.2229
Avg	.3865	.3530	.3425	.3386



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 206 / 11Kv Nanegaon feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.081	.0857
2	.1029	.1029	.081	.0857
3	.1029	.1029	.081	.0857
4	.1029	.1029	.0857	.0857
5	.1029	.1029	.0857	.1029
6	.12	.1029	.081	.1029
7	.12	.1029	.081	.0857
8	.12	.1029	.081	.0857
9	.12	.1029	.0857	.0857
10	.6859	.7545	.5144	.6173
11	.8573	.823	.8402	.7545
12	.9431	.6344		.8573
13	1.1145	.5668	.9088	.823
14	1.046	.4858	.7716	.7716
15	.823	.8097	.7545	.6001
16	.8402	.8097	.6687	.6687
17	.6859	.6478	.4458	.6001
18	.1029	.081	.0857	.1029
19	.1029	.081	.1029	.1029
20	.1029	.0953	.1029	.1029
21	.1029	.0953	.1029	.12
22	.1029	.081	.0857	.6173
23	.1029	.081	.0857	.1029
24	.1029	.1029	.081	.0857
Max	1.1145	.823	.9088	.8573
Min	.1029	.081	.081	.0857
Avg	.3629	.2948	.2736	.3222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 207 / 11Kv Ghatambri Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1715	.1619	.1372
2	.12	.1715	.1619	.1372
3	.12	.2058	.1619	.1372
4	.12	.2058	.1619	.1372
5	.1372	.2229	.1943	.1543
6	.1715	.3086	.2429	.1543
7	.2743	.3429	.3239	.4801
8	.0171	.0171	.0162	.0171
9	.0171	.0171	.0171	.0171
10	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171
12	.0171	.0171		.0171
13	.0171	.0162	.0171	.0171
14	.0171	.0162	.0171	.0171
15	.0171	.0162	.0171	.0171
16	.0171	.0162	.0171	.0171
17	.0171	.0162	.0171	.0171
18	.0171	.0162	.0171	.0171
19	.2058	.0162	.0171	.0171
20	.0171	.0191	.0171	.0171
21	.0171	.0191	.0171	.0171
22	.1029	.1619	.1372	.12
23	.1029	.1619	.1372	.12
24	.12	.1029	.1619	.1372
Max	.2743	.3429	.3239	.4801
Min	.0171	.0162	.0162	.0171
Avg	.0757	.0955	.0898	.0814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 208 / 11Kv Hatti Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.2572	.2229
2	.2401	.2401	.2572	.2229
3	.2743	.2572	.2572	.2229
4	.3772	.3086	.381	.3086
5	.6001	.5144	.5144	.4287
6	.7373	.823	.6001	.6173
7	.7202	.8402	.6668	.6516
8	.6516	.7202	.463	.583
9	.3944	.5487	.5144	.4287
10	.3429	.2743	.2572	.3772
11	.2229	.2229		.2058
12	.1715	.2229		.1715
13	.1543	.1296	.1543	.1715
14	.12	.1296	.1372	
15	.1372	.1457	.1715	.1372
16	.1543	.1457	.1886	.1715
17	.4287	.2429	.3086	.3086
18	.6687	.5668	.5487	.5487
19	.583	.6478	.5144	.5144
20	.4115	.5716	.3429	.4115
21	.3086	.3772	.2572	.2401
22	.3086	.2572	.2229	.1886
23	.2401	.2858	.2229	.1372
24	.2229	.2401	.2572	.2229
Max	.7373	.8402	.6668	.6516
Min	.12	.1296	.1372	.1372
Avg	.3622	.3730	.3407	.3258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 201 / 11Kv Jalki Bazar Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6268	1.2003	.985	1.1576
2		.6556	1.3032	1.0631	1.2696
3		.691	1.5432	1.134	1.307
4		.8328	1.5432	1.1744	1.307
5		.9214	1.8861	1.3466	1.3817
6		1.0164	1.989	1.4373	1.419
7		.8063	1.989	1.7147	1.419
8		.6783	1.6057	1.2883	1.307
9		.5041	1.2696		.5914
10		.4481	.4854	.5975	1.4198
11		.4294	.3734	.3734	1.3672
12		.3734	.3395	.3361	1.6651
13		.3361	.2452	.2987	1.5257
14		.2987	.3018	.2614	1.3717
15		.2801	.4668	.2427	1.3889
16		.3361	.5601	.2801	1.3546
17		.7842	.6348		.1578
18	1.7187	.8962	1.307		1.2936
19	1.6461	.9335	1.4415	.7842	1.46
20	1.4415	.9709	1.2197	.9335	1.5154
21	1.386	.9709	.9709	1.0082	1.386
22	.8954	.8573	.8145	1.0082	1.3535
23	.724	.7545	.8688	.9709	1.251
24		.6859		.8962	
Max	1.7187	1.0164	1.989	1.7147	1.6651
Min	.724	.2801	.2452	.2427	.1578
Avg	1.3020	.6703	1.0591	.8635	1.2900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 202 / 11Kv Shivna Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4415	1.307	1.1317	.9945
2		1.4784	1.4937	1.1883	1.0288
3		1.3169	1.5684	1.2323	1.0631
4		1.386	1.6804	1.307	1.0974
5		1.423	1.8298	1.531	1.1317
6		1.4632	1.9418	1.8111	1.1831
7		1.3491	1.9418	2.1216	1.1831
8		1.2752	1.8298	2.0328	1.4937
9		.9945	1.7372	1.6804	1.2567
10		1.0631	.9036	.9945	
11		1.166	.929	1.0631	1.2382
12		1.166	.9536	1.0631	1.3306
13		1.0288	1.0056	1.0288	1.2323
14		.9945	1.0631	1.0288	1.1203
15		.9945	1.0402	.9259	1.1458
16		1.0802	1.0166	.9602	1.1088
17		1.0974	.964	1.0117	1.5708
18	1.6632	1.1949	1.7926	1.7924	1.6263
19	1.3306	1.1576	1.9387	1.4937	1.6804
20	1.2936	1.0829	1.7002	1.1576	1.6632
21	1.2752	.9335	1.4415	1.0082	1.3676
22	1.3169	.8962	1.2323	.9259	.7682
23	1.3717	.8589	1.1949	.9945	.724
24		.8215		.9945	
Max	1.6632	1.4784	1.9418	2.1216	1.6804
Min	1.2752	.8215	.9036	.9259	.724
Avg	1.3752	1.1527	1.4133	1.2700	1.2277

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 203 / 11Kv Amsari Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6838	.7095	.3584	.6584
2		.7282	.7468	.3772	.7682
3		.8686	.7842	.415	.8048
4		.924	.8215	.5281	.8413
5		.9328	.9335	.6413	.9145
6		.9979	.9709	.8215	.9511
7		.8686	.9709	.9522	.9511
8		.7655	.6348	.5658	.6722
9		.439	.5658	.6348	.5975
10		.7316	.5552	.7095	.2801
11		.8048	.6268	.7316	.2801
12		.8048	.691	.7316	.2801
13		.7682	.7888	.7682	.2772
14		.7682	.8413	.7682	.2587
15		.7499	.7442	.8048	.2587
16		.7545	.6733	.7316	.2772
17		.583	.5731	.6219	.2772
18	.4435	.6348	.5847	.5975	.8686
19	.5228	.5601	.6535	.5601	.7842
20	.5544	.4854	.5601	.5228	.7392
21	.4938	.3921	.415	.4481	.6838
22	.4066	.3921	.3961	.439	.4887
23	.5175	.3734	.3772	.4854	.5249
24		.3734		.5487	
Max	.5544	.9979	.9709	.9522	.9511
Min	.4066	.3734	.3772	.3584	.2587
Avg	.4898	.6827	.6791	.6151	.5843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 204 / 11Kv Pimpaldari Feeder SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823	.8916	.6036	1.3443
2		.7602	.9259	.6413	1.3443
3		.7164	.9259	.7095	1.4563
4		.7164	1.0974	.7468	1.4937
5		.8238	1.1203	.8215	1.4937
6		.8596	1.134	.9335	1.6057
7		.9114	1.134	1.1203	1.6057
8		1.5893	1.7924	1.9589	1.5684
9		1.0829	1.7002	1.307	1.6263
10		.9335	1.4937	1.1203	.9231
11		.7842		1.0269	1.0498
12		.8215		.9335	.8596
13		.8962		.8962	.9134
14		1.0082	1.2323	.8215	.7186
15		1.1203	1.2696	.7842	.788
16		1.2323	1.3443	.9335	.8328
17		1.531	1.419	1.0829	.8688
18	1.4415	1.531	1.6804	1.419	1.0349
19	1.423	1.3443	1.885	1.2323	1.2382
20	1.4415	1.1576	1.6263	1.1203	1.4415
21	1.46	.8962	1.3443	.9335	1.386
22	.7023	.823	.4755	.9335	1.307
23	.7316	.7545	.5228	.8589	1.1763
24		.6859		.8215	
Max	1.46	1.5893	1.885	1.9589	1.6263
Min	.7023	.6859	.4755	.6036	.7186
Avg	1.2000	.9918	1.2507	.9900	1.2207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 205 / 11Kv Halda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1203	1.307	.7167	1.0288
2		.9709	1.4563	.7356	1.0288
3		1.1203	1.7177	.7922	1.0631
4		1.2883	1.8298	.8488	1.0631
5		1.3443	2.0538	.9054	1.1317
6		.9431	2.2405	1.0269	1.1317
7		1.0719	2.2405	1.1203	1.1145
8		1.1317	2.3152	.9431	2.2032
9		1.406	1.2071	.7842	.7922
10		.8916	.7122	.9945	.547
11		.9945	.763	1.046	.5228
12		.9945	.8551	1.0288	.3772
13		1.0288	.8951	1.0288	.3734
14		1.0288	1.0174	1.0117	.3584
15		1.0631	.9556	1.0117	.3921
16		1.0802	.9326	.9602	.4481
17		.9088	.9259	.7716	.5658
18	.9242	1.0082	1.0374	1.4937	1.4712
19	1.2637	1.1203	1.1576	1.419	1.4146
20	1.5278	1.1949	1.0456	1.307	1.4901
21	1.4563	1.2323	.9431	1.2136	1.3443
22	1.3443	1.2323	.7922	1.0288	.6697
23	1.3203	1.1576	.7545	.9259	.7164
24		1.1203		.9259	
Max	1.5278	1.406	2.3152	1.4937	2.2032
Min	.9242	.8916	.7122	.7167	.3584
Avg	1.3061	1.1022	1.2676	1.0017	.9238



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 206 / 11Kv Digras feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5194	.7682	.4108	1.1203
2		.5487	.8048	.4294	1.1203
3		.5249	.8413	.4668	1.1949
4		.4961	.8779	.5041	1.1949
5		.5731	.5761	.5601	1.2323
6		.543	.8962	.5975	1.2696
7		.6626	.8962	.8316	1.2696
8		1.4415	1.3817	1.6057	1.3817
9		1.251	1.3443	1.3443	1.1576
10		1.1576	1.2696	1.1949	.7207
11		1.0269	1.1203	1.1016	.8145
12		.9335	.9709	.9335	.6767
13		.8215	.8215	.8215	.823
14		.7468	.8676	.7468	.7602
15		.6722	.9054	.6908	.7947
16		.8029	.9709	.8589	.7947
17		1.1389	1.1203	1.0269	.7207
18	1.1088	1.1203	1.531	.9709	.9709
19	1.4563	.9709	1.6632	.8962	1.1763
20	1.386	.7842	1.4563	.8215	1.3443
21	1.3306	.6722	1.0829	.7468	1.4415
22	.8501	.6173	.2896	.7468	1.3121
23	.543	.6219	.3361	.6722	1.2382
24		.6219		.6348	
Max	1.4563	1.4415	1.6632	1.6057	1.4415
Min	.543	.4961	.2896	.4108	.6767
Avg	1.1125	.8029	.9910	.8173	1.0665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 207 / Water Supply FDR

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.017			
7		.0339		.0173	.0171
8		.0339	.0343	.0173	.0343
9		.0339	.0343	.0347	.0347
10		.0339	.0343	.0347	.0347
11		.0339	.0343	.0171	.0347
12		.0339	.0343	.017	.0347
13		.0339	.0347	.0339	.0347
14		.017	.0171	.0339	.0347
15			.0171	.0339	.0347
16			.0171	.0343	.0347
17			.0171	.0171	.0173
18	.017		.0173		.0173
Max	.017	.0339	.0347	.0347	.0347
Min	.017	.017	.0171	.017	.0171
Avg	.017	.0301	.0265	.0265	.0303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 201 / 11KV BHAVAN (NILLOD) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.421	.6539	.6516	.679
2		.4696	.6874	.6516	.7167
3		.5182	.7127	.7545	.7842
4		.5571	.7459	.823	.8402
5		.6226	1.0486	1.0288	.9808
6		.8029	1.1797	1.3375	1.2071
7		.7449	1.3763	1.7147	1.3306
8		.7537	.9831	.583	1.1203
9		.7537	.9619	1.166	.6224
10		.4904		.6226	.6224
11		.4904	.3086	.3932	.4715
12		.3584	.3086	.3605	.3961
13		.3395	.3601	.4715	.3772
14		.3206	.3086	.5093	
15		.3018	.2401	.4481	
16		.3772		1.0562	
17		.6413		.6722	.7167
18		1.1506		1.0269	1.094
19		1.2449	.7888	1.3443	1.3014
20		.8488	.6516	1.0751	.8676
21	.6154	.6036	.4801	.7282	.6979
22	.3441	.6371	.583	.6036	.5658
23	.3768	.6203	.6516	.6413	.5093
24		.421	.6371	.6516	.6722
Max	.6154	1.2449	1.3763	1.7147	1.3306
Min	.3441	.3018	.2401	.3605	.3772
Avg	.4454	.6037	.6834	.8048	.7892

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 202 / 11 KV BORGAON KH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1142	1.1694	1.1317	1.2382
2		1.1797	1.1883	1.1317	1.2567
3		1.2125	1.226	1.166	1.307
4		1.278	1.358	1.2346	1.3676
5		1.3763	1.5466	1.4232	1.6598
6		1.5402	1.8111	1.5775	1.9418
7		1.5729	1.307	1.2346	1.5123
8		1.1469	1.2136	1.2689	1.3817
9		.9503	1.2449	.9431	1.1883
10		1.643	1.6766	1.8842	1.7772
11		2.1548	2.3663	2.9127	2.3472
12		2.4478	2.5034	2.7035	2.536
13			2.5377	2.9938	2.652
14		2.7999		2.6513	2.4577
15		2.7018	2.5892	2.7073	2.1628
16		2.7183	2.7778	2.5274	2.0645
17		1.9559	2.5377	2.3712	1.6712
18		1.5497	1.166		1.531
19		1.643	1.5775	1.7741	1.6991
20		1.3817	1.5089	1.6448	1.419
21	1.3599	1.3817	1.3375	1.5339	1.3256
22	1.1469	1.2826	1.286	1.2752	.9556
23	1.1012	1.226	1.2346	1.251	.9389
24		1.0814	1.1883	1.166	1.251
Max	1.3599	2.7999	2.7778	2.9938	2.652
Min	1.1012	.9503	1.166	.9431	.9389
Avg	1.2027	1.6234	1.6675	1.7612	1.6518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 203 / 11 KV PALASHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8192	.9054	1.0288	
2		.8684	.9221	1.0974	
3		.9175	1.0395	1.1317	1.2136
4		1.1142	1.0395	1.166	1.2637
5		1.166		1.3375	1.363
6				1.5775	1.6991
7				2.1262	2.2779
8			1.3203	.9945	1.1088
9			1.226	.8745	1.358
10			.9997	.5506	1.0185
11			.823	.5735	.9054
12			.823		.9242
13		.7733	.8916		.9054
14		.9054	.8916	.9425	.9431
15		1.0185	.9431	1.0642	.9997
16		1.0374	.9431	1.1203	
17		1.2323	1.2003	1.1203	1.419
18		1.6991	1.5089	1.419	1.7364
19		1.7551	1.6118	1.8484	1.8858
20		1.475	1.3717	1.587	1.6804
21	1.1142	1.2696	1.2689	1.3014	1.419
22	.6802	.8718	.9259	1.0456	1.307
23	.7449	.8886	.9945	1.094	1.2637
24		.7773	.5716	.9945	1.1203
Max	1.1142	1.7551	1.6118	2.1262	2.2779
Min	.6802	.7733	.5716	.5506	.9054
Avg	.8464	1.0935	1.0582	1.1816	1.3244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 204 / 11Kv Bhagawati Agro  
Express Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0162	.011	.0171	.0174
2			.011	.0171	.0174
3		.0328	.011	.0171	.0173
4		.0328	.011	.0171	.0174
5		.0164	.011	.0171	.0173
6		.0164	.011	.0171	.0172
7		.033	.011	.0171	.0172
8			.011	.0171	.0173
9		.0165	.015	.0171	.015
10		.015	.015	.0341	.015
11		.015	.0171	.0341	.015
12		.0148	.0171	.0342	.015
13		.0148	.0171	.0173	.0151
14		.015	.0171	.0173	.0151
15		.015	.0171	.0173	.0151
16		.015	.0171	.0174	.0151
17		.015	.0171	.0173	.0151
18		.015	.0171	.0172	.0151
19		.0112	.0171	.0173	.0151
20		.015	.0171	.0173	.012
21		.015	.0171	.0172	.015
22	.0325	.015	.0171	.0173	.015
23	.0165	.015	.0171	.0173	.015
24		.0328	.015	.0171	.0173
Max	.0325	.033	.0171	.0342	.0174
Min	.0165	.0112	.011	.0171	.012
Avg	.0245	.0183	.0148	.0193	.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 205 / 11Kv Nillod Dharan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.055	.044	.0512	.033
11		.0686	.0853	.033
12	.077	.12	.0682	.066
13	.077	.12	.0786	.0724
14	.066	.0857	.1094	.0724
15	.0895	.0686	.0781	.06
16	.066	.1029	.0472	
17	.044	.0686	.0625	.06
22				.0359
23				.0239
Max	.0895	.12	.1094	.0724
Min	.044	.044	.0472	.0239
Avg	.0678	.0848	.0726	.0507

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 201 / 11 KV PALOD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.788	.7712	.3018	.2829
2		.788	.8048	.3206	.2829
3		.8048	.8383	.3395	.3018
4		.8383	.9054	.3772	.3772
5		.9054	1.0059	.4904	.4904
6		1.0059	1.0898	.679	.6413
7		1.2574	1.1736	.811	.8299
8		.7167	.7545	.7733	.7545
9		.5658	.6036	.6224	.6224
10		.3772	.3961	1.004	1.3279
11		.2829	.1886	1.2955	1.3927
12		.2075	.1509	1.4899	1.5223
13		.2075	.1132		1.7166
14		.1886	.0943	1.8138	1.587
15		.1886	.1509	1.8138	
16		.2829	.1886	1.7814	
17		.3584	.3584	1.587	1.4251
18		.5093	.5281	.6036	.6602
19		.6602	.679	.6602	.7545
20	.5658	.5658	.5281	.4904	.5281
21	.415	.415	.4715	.3772	.4527
22	.7712	.7042	.4527	.3395	.3772
23	.8048	.7377	.415	.3395	.3395
24		.8048	.7712	.3772	.3395
Max	.8048	1.2574	1.1736	1.8138	1.7166
Min	.415	.1886	.0943	.3018	.2829
Avg	.6392	.5900	.5597	.8125	.7730



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 202 / 11 KV ANWI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.5365	.3018	.2829
2		.4359	.57	.3018	.2829
3		.4694	.6036	.3395	.3018
4		.503	.6706	.3584	.3395
5		.57	.7377	.4904	.4527
6		.6706	.8383	.679	.679
7		.9054	.9221	.7922	.7922
8		.679	.679	.6979	.6602
9		.5658	.5281	.5847	.3772
10		.3206	.3018	.7773	.8583
11		.3018	.2452	1.085	.9393
12		.1132	.1886	1.3117	
13		.132	.1698	1.2631	1.2631
14		.1509	.1698		1.3603
15		.1886	.1886		1.3117
16		.2641	.2263	1.3927	1.2955
17		.3018	.2452		
18		.3395	.547	.6224	.6036
19		.5658	.6413	.6036	.6413
20	.5281	.5281	.4904	.5093	.4338
21	.3772	.3395	.3772	.3772	.415
22	.4694	.4191	.3395	.3018	.3772
23	.4359	.4694	.3018	.3018	.3395
24		.4191	.5365	.3018	.3018
Max	.5281	.9054	.9221	1.3927	1.3603
Min	.3772	.1132	.1698	.3018	.2829
Avg	.4527	.4197	.4606	.6378	.6504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 203 / RAHIMABAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.8383	.3772	.3772
2		.8048	.8718	.3772	.3772
3		.8383	.9054	.415	.4527
4		.9389	1.0059	.4715	.6036
5		1.1401	1.1401	.8488	.7545
6		1.2407	1.2574		1.0562
7		1.5927	1.4419	1.0562	
8		.9431		.9431	1.0374
9		.7545	.9431	.9054	.8676
10		.3395	.4715	.7449	1.2631
11		.2829	.2452	1.1984	1.3603
12		.2263	.1886	1.2308	1.7166
13		.1886	.1698	1.2955	
14		.1509	.1698	1.6032	
15		.1886	.2263	1.5384	1.7004
16		.2829	.3018		1.8623
17		.415	.4338	1.3603	1.749
18		.8676	.8488	.9997	.8488
19		.9431	1.0374		.9431
20	.6413	.6602	.8488	.6979	.5658
21	.4527	.4338	.4715	.5658	.415
22	.7712	.8048	.4527	.3961	.415
23	.788	.8383	.415	.3772	.3772
24		.7545	.8718	.3772	.3772
Max	.788	1.5927	1.4419	1.6032	1.8623
Min	.4527	.1509	.1698	.3772	.3772
Avg	.6633	.6827	.6764	.8467	.9105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 204 / ASADI AG MIX SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3688	.4024	.1698	.1698
2		.3688	.4191	.1698	.1698
3		.4024	.4359	.1886	.1886
4		.4694	.4694	.2263	.2263
5		.5365	.5365	.3018	.3018
6		.57	.6371	.415	.4527
7		.7712	.6874	.4904	.5093
8		.4904	.3772	.4715	.4527
9		.3772	.3018	.415	.3206
10		.1886	.132	.583	.5668
11		.1509	.0566	.8097	.7773
12		.0943	.0566	.9717	.8421
13		.0754		1.004	
14		.0754		.9717	
15		.0943	.0754	.8097	.8097
16		.1132	.1132	.8421	.8745
17		.132	.132	.7449	.8097
18		.3018	.3206	.3772	.3395
19		.3772	.3772	.3961	.3772
20	.3018	.3018	.3018	.3018	.3018
21	.2641	.1886	.2263	.2641	.2263
22	.3521	.3353	.1886	.1886	.2263
23	.3521	.3688	.1698	.1886	.1886
24		.3688	.4024	.1698	.1886
Max	.3521	.7712	.6874	1.004	.8745
Min	.2641	.0754	.0566	.1698	.1698
Avg	.3175	.3134	.3100	.4780	.4236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 201 / 11 kv Dhawda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715		.1886	.1509
2		.1886		.2075	.1715
3		.2286		.2263	.1886
4		.2641		.2829	.2452
5		.3395		.3395	.2641
6		.4715		.3961	.3961
7		.4715		.4904	.4338
8		.4904		.4904	.3395
9		.3961		.3961	.2858
10		.5506		.6325	.6562
11		.6241		.9231	.8745
12		.7842		.9442	.8802
13		.7362		.9282	
14		.7362		.8583	
15		.7202		.7682	
16		.6882	.333	.7611	.8619
17		.6483	.5375	.7449	.9762
18		.3772	.415	.3395	.3772
19		.415	.4715	.4715	.415
20		.3206	.3584	.3584	.3772
21		.2641	.3395	.3018	.3395
22		.2263	.2641	.2263	.2881
23	.2096	.1886	.2263	.2096	.3185
24		.1886	.1886	.1886	.1715
Max	.2096	.7842	.5375	.9442	.9762
Min	.2096	.1715	.1886	.1886	.1509
Avg	.2096	.4371	.3482	.4864	.4291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 202 / 11 kv Jambhai SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6602	.6413	.6602	.743
2		.6478	.6602	.6979	.7922
3		.6602	.7167	.7356	.8954
4			.9619	1.0185	1.094
5		1.2071	1.226		1.4335
6			1.4712	1.5497	1.7164
7			1.5278		1.6975
8			1.1694	1.2826	1.4146
9		1.4146	.9054	.9808	1.094
10		.3988	.4024	.3429	.4527
11		.503	.4527	.4973	.4191
12		.5921	.502	.4862	.4359
13		.6154	.5068	.4641	.4527
14		.5801	.5434	.4862	.4715
15		.5304	.6241	.4641	
16		.4973	.5144	.4191	.2241
17		.4641	.2915	.285	.3481
18		1.531	1.2883	1.358	1.0185
19		1.4563	1.0751		1.3014
20		1.3014	1.3392	1.3957	1.0374
21		1.1506	1.0751	1.094	.9808
22		.8676	.9054	.9808	.1829
23	.7733	.6979	.7167	.8488	.2353
24		.724	.6602	.679	.7545
Max	.7733	1.531	1.5278	1.5497	1.7164
Min	.7733	.3988	.2915	.285	.1829
Avg	.7733	.8250	.8407	.7965	.8346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 203 / 11 kv Amthana SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5426	.4458	.4835	.4477
2		.5596	.5014	.5249	
3		.6001	.5611	.6036	.5194
4		.6344	.6878	.7011	.5493
5		.7011	.7602	.8238	.6089
6		.8417	.8059	.8842	.8688
7		1.1393	1.0808	1.1831	1.0566
8			1.2826	1.4146	
9		1.2071	1.1128	1.1694	1.0562
10		.7167	.7356	.7922	.6036
11		.415	.4338	.547	.4338
12		.3018	.3395	.4527	.3584
13		.3018	.3772	.362	.2829
14		.3206	.3961	.3584	.3584
15		.3584	.4527	.3429	.3206
16		.5658	.6036	.4572	.4338
17		.5658	.6602	.547	.5847
18		1.2071	1.0185	1.094	1.1694
19		1.2449	1.226	1.2826	1.1506
20		.9431	1.0562	1.1128	.9431
21		.7356	.679	.7733	.8299
22		.3978	.4207	.3439	.5093
23	.4694	.4024	.4477	.3801	.4715
24		.5197	.4191	.4477	.3982
Max	.4694	1.2449	1.2826	1.4146	1.1694
Min	.4694	.3018	.3395	.3429	.2829
Avg	.4694	.6618	.6877	.7118	.6343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 204 / 11 kv JOGESHWARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8065	.9556	1.0679	.852
2		.8381	1.0166	1.0631	.8848
3		.8697	1.0692	1.1104	.9339
4		.9122	1.0749	1.1744	.9555
5		.9602	1.0974	1.2136	1.0202
6		.9326	1.166	1.2517	1.1768
7		1.3916	1.3413	1.3916	1.4083
8			.9054	1.1317	1.1128
9		1.1694	.7922	.7922	.9997
10		.8676	.7545	.6036	.7167
11		.6224	.4527		.5847
12		.547	.547		.5093
13		.4715	.5847	.415	.4338
14		.4338	.6413		.3961
15		.415	.6602	.5525	.415
16		.4904	.679	.6979	.4527
17		.6979	.679	.8573	.6979
18		1.1128	1.1128	1.094	1.1883
19		1.0751		1.0374	1.1128
20		.7733	.811	.7922	
21		.6224	.6602	.6413	.679
22		.7907	.9511	.6962	.5281
23	.6718	.8539	1.0029	.7293	.5281
24		.7343	.8907	1.0454	.8122
Max	.6718	1.3916	1.3413	1.3916	1.4083
Min	.6718	.415	.4527	.415	.3961
Avg	.6718	.7995	.8629	.9218	.7999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 205 / Kelgaon murdeshwar SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4904	.547	.5281	.6097
2		.5335	.5658	.6036	.6224
3		.6036	.6036	.6413	.6602
4		.6859	.7356	.7733	.724
5		.7733	.9242	.9808	.9054
6		1.1128	1.1506	1.0374	1.1694
7		1.1883	1.2637	1.2071	1.2826
8		1.2826	1.1694	1.1506	1.2637
9		.9431	.8488	.9431	.9808
10		.4973	.5552	.5487	.5668
11		.5365	.8309	.6687	.6962
12		.5967	.7956	.7377	
13		.5636	.7716	.7712	
14		.5636		.7127	
15		.5533		.663	
16		.547	.7209	.57	.9116
17		.57	.7202	.503	.8322
18		1.2637	1.1128	1.1506	1.1694
19		1.1128	1.0751	1.226	1.2826
20		.8488	.9242	1.0374	.9619
21		.7356	.7167	.7922	.8676
22		.6224	.6413	.7356	.3403
23	.5525	.5658	.5847	.724	.3544
24		.5093	.547		.6413
Max	.5525	1.2826	1.2637	1.226	1.2826
Min	.5525	.4904	.547	.503	.3403
Avg	.5525	.7375	.8093	.8133	.8421



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 201 / 11 KV LONAWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5729	.5788	.7282	.7282
2		.5914	.5975	.7468	.7468
3		.8686	.8775	.8029	.8029
4		.9795	.9335	1.1203	1.1203
5		1.134	1.0082	1.4003	1.4003
6		.8116	1.0082	1.6991	1.6991
7		1.262	1.1949	1.643	1.643
8			1.1203	1.5684	1.4937
9		.3547	.9326	1.251	1.251
10		.381	.7842	.6161	
11		.5415	.8962	.7468	
12		.5228	.9522	.8402	
13		.4108	.9896	.9896	
14		.4481	.9522	.9522	
15		.4854	.8962	.8962	
16		.6348	.8589	.8589	
17		.7095	.8962	.8962	
18		.7842	1.307	.9335	
19		.8402	1.8671	1.0082	
20		.7842	1.5497	1.1949	.8962
21		.7468	1.1576	1.1949	.6908
22		.7468	.8029	.8029	.9709
23	.5415	.6348	.7655	.7655	.7468
24		.5041	.5601	.7282	.7282
Max	.5415	1.262	1.8671	1.6991	1.6991
Min	.5415	.3547	.5601	.6161	.6908
Avg	.5415	.6848	.9786	1.0160	1.0656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 202 / 11 KV ANDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.2987	.2987	.2987
2		.3077	.3361	.3361	.3361
3		.4163	.4481	.3734	.3734
4		.4706	.5601	.3921	.4294
5		.5194	.5975	.4294	.4668
6		.5014	.5601	.4668	.5601
7		.4887	.6535	.5041	.8402
8		1.0269	.8029	.8215	.7468
9		.9149	.6535	.7095	.6348
10		.7655	.4481	.5601	
11		.5601	.3174	.5228	
12		.5228	.2801	.3547	
13		.4481	.2801	.3361	
14		.4108	.2987	.3361	
15		.1867	.3361	.3547	
16		.3734	.3734		
17		.4481	.4854		
18		.5601	.6722	.6348	
19		.6535	.7282	.8589	
20		.7095	.6908	.7468	.7468
21		.6535	.6161	.6722	.6161
22		.5228	.2987	.2987	.2587
23	.2172	.3932	.2896	.2987	.2801
24		.2534	.3361	.2987	.2987
Max	.2172	1.0269	.8029	.8589	.8402
Min	.2172	.1867	.2801	.2987	.2587
Avg	.2172	.5158	.4734	.4820	.4919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 203 / 11 KAV ANDHARI - I SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.2801	.2614	.2614
2		.3258	.3361	.2987	.2987
3		.4525	.4668		.3361
4		.5552	.5788	.4294	.4294
5		.6984	.7468	.6535	.6535
6		.8059	.7842	.8589	.8589
7		.8238	.8402	.9896	.9896
8		1.1016	.6348	1.1389	1.1389
9		.9522	.5975	.8215	.8215
10		.5788	.4706	.5788	
11		.3734	.4108	.3361	
12		.2987		.2427	
13		.2614	.3547	.2614	
14		.2801	.3734	.3174	
15		.2801	.4108	.3361	
16		.3018	.4481		
17		.3361	.6161		
18		.4481	.9522	.7095	
19		.6535	1.2323	1.1949	
20		.7468	1.0269	1.0082	.8402
21		.7655	.8962	.6348	.5228
22		.4481	.2614	.3361	.4108
23	.3439	.3361	.2614	.2614	.5228
24		.3077		.2614	.2614
Max	.3439	1.1016	1.2323	1.1949	1.1389
Min	.3439	.2614	.2614	.2427	.2614
Avg	.3439	.5168	.5900	.5681	.5961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 201 / 11 KV INDUSTRIAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEED Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7167	.6722	.5601
2	.6722	.7167	.6535	.5601
3	.7095	.7545	.7095	.543
4	.7842	.7095	.7842	.543
5	.7468	.7842	.8589	.5601
6	.7468	.7842	.7842	.6335
7	.7095	.7842	.8215	.6135
8	.7842	.8962	.7468	.5068
9	.8402	.8215	.7468	.6335
10	.8962	.9709	.7468	.7468
11	.961	.8962	.7468	.7577
12	1.0349	.8402	.6535	.7023
13	.8131	.9709	.905	.823
14	.961	1.0269	.905	1.0164
15	.8316	.9709		1.0164
16	.961	1.0082	.905	.9979
17	.924	1.0269	.905	.9979
18	1.0903	1.0269	1.086	.9979
19	1.1203	1.0269	.8145	.7468
20	.5415	1.0082	.4668	.4715
21	.7545	.8488	.6722	.7545
22	.7545	.7468	.6722	.7545
23	.7356	.7095	.6535	.7545
24	.6722	.7167	.6535	.543
Max	1.1203	1.0269	1.086	1.0164
Min	.5415	.7095	.4668	.4715
Avg	.8231	.8651	.7636	.7181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 202 / TILAKNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4527	.4527	.362
2	.4527	.3772	.4338	.3734
3	.4904	.3772	.415	.3734
4	.5601	.415	.5281	.3734
5	.6535	.4481	.6722	.5601
6	.7282	.6535	.7842	.6535
7	.8402	.8316	.8215	.7468
8	.8215	.8589	.7842	.8402
9	.8215	.7655	.7468	.7468
10	.7468	.7842	.7842	.6535
11	.6468	.6535	.543	.6838
12	.6099	.543	.543	.7023
13	.5544	.5415	.5601	.5853
14	.462	.4108	.4525	.4435
15	.462	.415	.4525	.4805
16	.5729	.5281	.4382	.5359
17	.6099	.5975	.543	.6401
18	.7468	.6722	.6535	.6838
19	.7282	.7468	.724	.6722
20	.6413	.7842	.543	.6413
21	.5601	.5601	.543	.547
22	.5281	.415	.4481	.4527
23	.4904	.3772	.3734	.415
24	.415	.4527	.3772	.362
Max	.8402	.8589	.8215	.8402
Min	.415	.3772	.3734	.362
Avg	.6081	.5692	.5674	.5637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 203 / NEW TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.415	.415	.362
2	.415	.415	.3772	.362
3	.415	.415	.5093	.3734
4	.4904	.4527	.5975	.3734
5	.5281	.5601	.7468	.5601
6	.5975	.6535	.7468	.6535
7	.6161	.7577	.8215	.8402
8	.8962	.8029	.7842	.9335
9	.9335	.8589	.7468	.9335
10	.9335	.8402	.8402	.8145
11	.8686	.8299	.7468	.7023
12	.7023	.6335	.6535	.5544
13	.5788	.6161	.543	.5544
14	.4805	.6535	.543	.5175
15	.4435	.4904	.4382	.5359
16	.4805	.5281	.543	.5544
17	.6838	.6722	.543	.5914
18	.4854	.8402	.724	.8215
19	.8215	.7468	.724	.7468
20	.6036	.7095	.543	.6036
21	.5281	.5601	.543	.5281
22	.5281	.415	.4344	.415
23	.4527	.3772	.3734	.3772
24	.3772	.415	.3772	.362
Max	.9335	.8589	.8402	.9335
Min	.3772	.3772	.3734	.362
Avg	.5948	.6108	.5965	.5863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 204 / TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.415	.3734
2	.4338	.3772	.415	.362
3	.415	.3772	.415	.362
4	.415	.415	.4904	.3734
5	.4527	.4668	.6535	.5601
6	.7167	.5975	.7095	.6335
7		.7577	.7468	.724
8	.7842	.7842	.7468	.7468
9	.7468	.7655	.7468	.6535
10	.5601	.7468	.6908	.845
11	.7392	.6535	.6135	.6468
12	.6036	.543	.5601	.7023
13	.5731	.5415	.5601	.5914
14	.5544	.5601	.543	.499
15	.5175	.4904	.4382	.5544
16	.5359	.5658	.543	.5729
17	.6653	.7842	.543	.6401
18	.7842	.8215	.724	.7842
19	.7095	.7468	.724	.7468
20	.6036	.7095	.5258	.6036
21	.4904	.5601	.5068	.5093
22	.4527	.3772	.4481	.415
23	.415	.3772	.3734	.3772
24	.415	.3772	.3772	
Max	.7842	.8215	.7468	.845
Min	.415	.3772	.3734	.362
Avg	.5652	.5739	.5629	.5772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 206 / 11 KV BALAJINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3395	.4338	.2801
2	.2829	.3395	.415	.2801
3	.2829	.3395	.4904	.2801
4	.4338	.3772	.5228	.2801
5	.5281	.4715	.5975	.3734
6	.6036	.5975	.6722	.4525
7	.6161	.7392	.7468	.6535
8	.5601	.6535	.7095	.7468
9	.5601	.5975	.5975	.543
10	.5601	.5658	.5228	.6335
11	.4294	.4715	.3628	.4066
12	.3658	.3506	.3734	.2926
13	.2957	.3361	.2715	.2772
14	.2587	.3772	.2629	.2587
15	.2957	.2641	.2715	.2772
16	.2772	.2641	.2715	.2957
17	.3881	.4715	.362	.3511
18	.4854	.5601	.543	.5228
19	.5228	.5601	.543	.4854
20	.5281	.5975	.4382	.4904
21	.415		.4344	.415
22	.3772		.3506	.3584
23	.3772	.3772	.2801	.3395
24	.2829	.3395	.3772	.2715
Max	.6161	.7392	.7468	.7468
Min	.2587	.2641	.2629	.2587
Avg	.4171	.4541	.4521	.3986



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 202 / YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0543	.056	.056	.0572
2		.0543	.056	.056	.0572
3		.0543	.0747	.0747	.0762
4		.0724	.1307	.1307	.1334
5		.1086	.1867	.1867	.1867
6		.1448	.2241	.2241	.2218
7		.1629	.1867	.1867	.2743
8		.181	.2054	.1867	.1448
9		.181	.0934	.168	.1715
10		.1867	.0934	.1109	.1307
11		.0934	.0934	.128	.112
12		.0373	.0747	.0905	.0747
13		.0373	.056	.0732	.0686
14		.0373	.056	.0549	.0373
15		.056	.0747	.0732	.0514
16		.056	.1307	.0724	.168
17		.112	.1307	.0914	.1307
18		.1307	.1494	.1524	.1307
19		.112		.1143	.112
20		.0934	.0934	.0953	.0934
21		.0747	.0747	.0762	.0747
22		.056	.0747	.0572	.056
23	.0543	.056	.056	.0572	.056
24	.0543		.056	.056	.0572
Max	.0543	.1867	.2241	.2241	.2743
Min	.0543	.0373	.056	.0549	.0373
Avg	.0543	.0936	.1055	.1072	.1115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 204 / MAHADEV MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4706	.5041	.5041	.4763
2		.4706	.5415	.5415	.5525
3		.543	.5975	.5975	.6478
4		.6516	.6722	.6722	.743
5		.905	.7282	.7282	.8131
6		.9955	1.0269	1.0269	.9774
7		1.3756	1.2136	1.3817	1.1999
8		1.4842	1.4937	1.5123	1.4373
9		1.4118	1.363	1.4003	1.4861
10		1.4563	1.363	1.3756	1.3443
11		1.1576	1.1576	1.1393	1.1763
12		.9709	1.0269	.8764	.9335
13		.7282	.8215	.7164	.703
14		.6161	.5788	.5658	.6348
15		.5788	.6161	.5609	.6161
16		.6722	.6535	.6379	.6535
17		.8589	.9522	.9492	.8402
18		1.2136	1.1949	1.2574	1.0829
19		1.0456	1.1203	1.1431	1.1203
20		.8215	.7468	.8954	.8775
21		.6908	.6722	.6859	.6722
22		.6535	.5601	.5716	.5601
23	.543	.5601	.5041	.5335	.5228
24	.4887		.5041	.4668	.5144
Max	.543	1.4842	1.4937	1.5123	1.4861
Min	.4887	.4706	.5041	.4668	.4763
Avg	.5159	.884	.8589	.8642	.8577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 205 / AURANGABAD NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3982	.4481	.4481	.4382
2		.3982	.4668	.4668	.4763
3		.4344	.5228	.5228	.5525
4		.543	.5601	.5601	.6287
5		.724	.6161	.6161	.6908
6		.8145	.8215	.8215	.823
7		.8326	.7842	.9335	.8417
8		.9593	.9896	1.0456	1.0679
9		1.0498	.8962	1.0829	1.086
10		1.0829	.8962	.9694	.9709
11		.8402	.8059	.8869	.8962
12		.8029	.7095	.8238	.7842
13		.6908	.6535	.5731	.6535
14		.5601	.5415	.5258	.5601
15		.5228	.4668	.4961	.5041
16		.6161	.5788	.591	.5788
17		.6908	.7095	.724	.6535
18		.8589	.9149	.9231	.7842
19		.7842	.8402	.9145	.8962
20		.7468	.7095	.7621	.7468
21		.5601	.6161	.6287	.6161
22		.4668	.5041	.5144	.5041
23	.4344	.4481	.4481	.4954	.4854
24	.4163		.4294	.4294	.4572
Max	.4344	1.0829	.9896	1.0829	1.086
Min	.4163	.3982	.4294	.4294	.4382
Avg	.4254	.6881	.6637	.6981	.6957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 201 / BHAGOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.4115		.3772	.5144	.583	.5487
2	.3086	.4458		.4115	.5487	.6173	.5144
3	.4115	.4801		.6173	.6584	.583	.4801
4	.5144	.5487		.6516	.6516	.6859	.5144
5	.583	.823		.7202	.7202	.7202	.583
6	.6516	.8745		.7888	.7716	.8573	.823
7	.7202	.8573		.9431	.823	.7888	.8916
8	.7888	.823		.8916	.7373	.823	.8573
9	.6859	.7545	1.2346	.6859	.6173	.4458	.6173
10	.7888	.8916	1.2003	.4973	.4287	.4287	.3429
11	.7716		1.166	.3772	.1886	.4458	.2058
12	.7888		1.166	.3601	.1715	.4458	.2572
13	.823		1.1317	.3429	.2229	.2058	.2572
14	.8573			.3429	.2401	.2401	.2401
15	.823			.2743	.2743	.2401	
16	.823			.2401	.3601	.2614	
17	.3086			1.286	1.4403	.2572	1.3203
18	.6173		.823	1.3032	1.3717		1.3546
19	.8573		.7888	1.0802	1.3717	1.4746	1.1317
20	.6344		.7202	.9259	1.0288	1.4575	1.0631
21	.4458		.6516	.823	.7888	1.0974	.7888
22	.4115		.583	.6344	.7888	1.0631	.6516
23	.4115		.4801	.5487	.6859	1.1317	.5487
24	.3429	.4115		.3429	.5144	.5487	1.1869
Max	.8573	.8916	1.2346	1.3032	1.4403	1.4746	1.3546
Min	.3086	.4115	.4801	.2401	.1715	.2058	.2058
Avg	.6116	.6656	.9041	.6444	.6633	.6697	.6899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 202 / JATEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.4922		.9431	1.166	1.0288	.823
2	1.4746	1.5249		.9602	1.166	1.0631	
3	1.6617	1.6057		.9945	1.2346	1.166	
4	1.8991	1.6712		.9945	1.3032	1.3032	
5	2.1262	1.8023		1.0974	1.3032	1.3375	
6	2.1365	1.704		1.5432	1.3375	1.3717	
7	2.2291	1.9006			1.0631		
8	2.1948	1.9662			.9259		
9	1.2689	.9602	1.0974	2.1262	1.8351		
10	.8573		.9945	1.8679	2.0687	1.3717	
11				1.3904	2.0233	1.4746	
12				1.7695	2.0233		
13				1.8679	1.989	2.1605	1.9006
14				1.8351	1.8861	2.2291	2.2283
15				1.8351		2.1605	2.2939
16				1.8679			2.6871
17	.4801		.823	.7888	1.0288	1.0288	.823
18	1.3375		1.3717	1.3717	1.2003	1.2689	1.3717
19	1.406		1.3032	.9945	1.2003	1.3375	1.0288
20	1.406		1.2689	.823	1.166	1.3717	.9945
21	1.2346		1.0974	.823	1.0974	1.2689	.9602
22	1.2346		1.0631	.823	1.0288	1.2346	.8916
23	1.2346		1.0288	.823	1.0288	1.166	.7888
24	1.166	1.2346		.9259	1.166	1.0288	.8916
Max	2.2291	1.9662	1.3717	2.1262	2.0687	2.2291	2.6871
Min	.4801	.9602	.823	.7888	.9259	1.0288	.7888
Avg	1.4825	1.5862	1.1164	1.2939	1.3746	1.3880	1.3602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 203 / MAHALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.6516		1.5089	.823	1.166	1.4403
2	.9259	.7202		1.4403	1.0631	1.3717	1.4582
3	.9602	.7202		1.0117	1.3375	1.7147	1.5261
4	.9945	.823		1.3375	1.4746	1.7147	1.749
5	1.2689	1.2209		1.6118	1.5402	1.7147	1.7635
6	1.3375	1.3904		1.6804	1.6385	1.6461	2.0008
7	1.3375	1.3904		1.6975	1.7695	2.1605	2.0348
8		1.3904		1.5089	1.8023	2.4006	2.0687
9	1.166	.8916	.8573	1.0288	1.0631	1.0974	1.166
10	1.166		.7202	.7545	.823	.9945	.9602
11	.7545		.583		.6001	.7888	.5487
12			1.1145		.5487	.4801	
13			.5487			.4801	.5487
14	.5144		.5487			.6173	.4801
15	.5487		.5144				.4115
16	.5487		.5144	.6173	.3086		.5487
17	1.166		1.8861	.8573	.6859	.6516	.7545
18	1.2887		1.7833	1.0974			
19	1.4083		1.9784	1.0974	1.0288	1.2689	1.2689
20	1.5074		2.079	1.0974	1.0288	1.3375	1.166
21	1.2887		1.9204	1.0631	.9602	1.2689	.9259
22	1.2003		1.6118	1.0631	.9259	1.2689	.6173
23	1.166		1.5775	.7202	.8916	1.4746	.6516
24	1.3717	1.166		1.5089	.6859	1.0288	1.3226
Max	1.5074	1.3904	2.079	1.6975	1.8023	2.4006	2.0687
Min	.5144	.6516	.5144	.6173	.3086	.4801	.4115
Avg	1.0830	1.0365	1.2158	1.1949	1.0500	1.2689	1.1551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 204 / KATE PIMPLGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3429		.3772	.3772	.2058	.4115
2	.4115	.3429		.3429	.3772	.2058	.3772
3	.4115	.3772		.3429	.3772	.2401	.4115
4	.4458	.4458		.3772	.3772	.2743	.4458
5	.5144	.4458		.4115	.3772	.4115	.4801
6	.4458	.4801		.4458	.4115	.4458	.5144
7	.4115	.4801		.5144	.4115	.4458	.5144
8	.4458	.4115		.5144	.4115	.4801	.5144
9	1.3904	1.3904	1.6712	.3086	.4115	.3429	.4458
10	1.4922		1.6617	.2743	.2743	.3086	.3086
11	1.4922		1.6095	.2743	.2572	.2743	.2058
12	1.4243		1.6095		.2058	.2401	.2743
13	1.4243		1.6095	.1372	.1715	.1715	.2743
14	1.4243		1.6095		.1715	.1715	.2743
15	1.4243		1.643	.2058	.2058	.1715	
16			1.576	.1372	.1017	.2058	
17			.2401	1.6712	1.6766	2.13	.9602
18			.4458	1.8351	1.8442	1.9662	
19			.4801	1.5074	1.7147	2.0317	1.8351
20			.5487	1.3565	1.5432	1.9334	1.8351
21	.2743		.4458	1.3108	1.3717	1.7368	1.6057
22	.3429		.4115	1.2346	1.3717	1.6057	1.4243
23	.3429		.3429	1.2346	1.1317	1.6278	1.2209
24	.2743	.3429		.3086	1.0174	.9945	1.576
Max	1.4922	1.3904	1.6712	1.8351	1.8442	2.13	1.8351
Min	.2743	.3429	.2401	.1372	.1017	.1715	.2058
Avg	.7738	.5060	1.0603	.6874	.6913	.7759	.7576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 206 / PANVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.823		.9259	.583	1.3717	1.5074
2	.7888	.823		.9602	.7888	1.3717	1.5939
3	.823	.823		1.5089	1.166	1.5432	1.6095
4	.823	.8916		.9945	1.2346	1.7147	1.8023
5	.9259	.9259		1.0974	1.3032	1.7147	1.8351
6	.9602	.9945		1.1317	1.3375	1.7147	2.0645
7	.9945	1.2346		1.0974	1.7859	1.8861	2.13
8	1.0288	.9259		1.1317	1.8351	2.0576	2.0317
9	.9602	.7716		.4115	.9602	.823	.9945
10	.7202			.2915	.7545	.7202	.8916
11	.6344		.2401		.463	.6859	.7888
12	.5487		.2401		.6344	.6859	
13	.5487		.2401		.6344	.6859	.7373
14	.4973		.2401		.6173	.6859	.7545
15	.5144		.2401		.5658	.7202	.7545
16			.2401	.4287	.6173	.7545	.823
17	.9602		1.4403	.823	.823	1.0974	.9945
18	1.6617		1.2346	1.2003	1.0288	1.2346	
19	1.6712		1.3375	.8916	1.0288	1.3375	1.1488
20	1.4746		1.3032	.7716	.9602	1.3717	1.1145
21	1.3565		1.2346	.7202	.9945	1.3032	.823
22	1.2717		1.166	.6344	.8916	1.5074	.7545
23	1.2548		1.0974	.6173	.8573	1.5402	.823
24	1.0974	1.2209		.823	.5487	1.0288	1.5089
Max	1.6712	1.2346	1.4403	1.5089	1.8351	2.0576	2.13
Min	.4973	.7716	.2401	.2915	.463	.6859	.7373
Avg	.9668	.9434	.7888	.8664	.9339	1.2315	1.2494



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 207 / MALISAGAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.56	1.0631		1.0974	1.0631	.8573	.9259
2	1.7295	1.2003		1.1317	1.0974	.8573	.9602
3	1.7974	1.3375		1.166	1.166	.9602	.9945
4	2.0008	1.3904		1.3375	1.2346	1.0288	1.0974
5	2.0233	1.3904		.9945	1.2689	1.0974	1.1317
6	2.1026	1.4413		1.3375	1.3032	1.0631	1.166
7	2.3061	2.2283			1.166	1.0974	1.1317
8	2.34				.8916	1.2003	1.0288
9	1.0059	1.1488	.823	1.8519	1.4243	2.0576	1.3226
10	.823		.583	1.8023	1.5775	1.9204	1.4582
11	.823		.6173	1.7368	1.6461	1.8519	1.4074
12	.5487		.6173	1.6876	1.8519	1.749	1.643
13	.4458		.6173	1.7204	1.8004	1.749	1.3226
14			.6173	1.6712	2.1434	1.7635	1.4582
15			.6516	1.6385	1.7661	1.7635	
16			.6859	1.6385	1.8107	1.6956	1.4091
17	.6859		.9945	.6001	1.0288	.9945	.8916
18	1.3375		1.3375	1.0802	1.0974	1.0974	1.286
19	1.406		1.3717	1.286	1.0631	1.166	.8573
20	1.3546		1.3032	1.166	1.0288	1.3032	.823
21	1.1831		1.2346	1.166	.9259	1.2689	.7888
22	1.1145		1.166	1.1317	.9259	1.2346	.7373
23	1.3032		1.0974	1.0631	.8573	1.0974	.7202
24	1.4746	1.3032		1.0288	1.0631	.8573	.9602
Max	2.34	2.2283	1.3717	1.8519	2.1434	2.0576	1.643
Min	.4458	1.0631	.583	.6001	.8573	.8573	.7202
Avg	1.3984	1.3893	.9145	1.3334	1.3001	1.3222	1.1096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 208 / SIRASGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9156	.823		1.5089	.7545	1.2003	1.3375
2	.9945	.8916		2.1434	.7545	1.2003	1.4243
3	1.0288	.9602		1.4746	.823	1.3717	1.5939
4	1.0974	1.0974		.9945	.9602	1.5432	1.8652
5	1.1317	1.166		1.0117	1.2346	1.8861	1.8519
6	1.166	1.2003		1.9033	1.3375	1.7147	1.7635
7	1.166	1.3375		1.6804	1.704	2.1605	1.7974
8	1.166	1.2346		1.6461	1.7859	2.4006	1.8991
9	1.0974	.9602	1.166	1.6975	1.0974	.9945	1.2346
10			.9945	.7373	.7545	.5487	1.0288
11				.5487	.6516	.5144	
12				.5487			
13				.5658		.9945	.7373
14				.4801		.9602	.8916
15				.4287		1.0631	.9774
16				.4973		1.0288	
17	1.5074		2.2291	.7545	1.0288	.9945	
18	1.5074		2.0576	.9259	1.0974	1.166	.9602
19	1.5729		2.1262	1.166	1.1317	1.0974	.9088
20	1.6221		1.989	1.2003	1.0288	1.166	.8916
21	1.5415		1.9204	1.166	.9088	1.0974	.823
22	1.3763		1.8861	.9431	.8573	1.4403	.7888
23	1.3904		1.5432	.823	.8573	1.4746	.9259
24	1.6118	1.3904		1.4403	.7545	.8573	1.3375
Max	1.6221	1.3904	2.2291	2.1434	1.7859	2.4006	1.8991
Min	.9156	.823	.9945	.4287	.6516	.5144	.7373
Avg	1.2878	1.1061	1.7680	1.0953	1.0275	1.2554	1.2519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 209 / CHINCHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9259	.823		.7888	.9259	1.0288	1.0631
2	.9945	.823		.823	.9602	1.0288	1.0288
3	.9945	.9602		.9259	.9945	1.0974	.9945
4	1.0974	.9945		.9259	1.0974	1.166	1.0974
5	1.166	1.0974		1.0974	1.166	1.2003	1.166
6	1.1317	1.2174		1.0974	1.2346	1.2346	1.2003
7	1.0974	1.2346		1.0974	1.2689	1.2003	
8	1.0974	1.0974			1.2346	1.1317	1.0288
9	1.3717	.7545	2.2634	1.0288	.8402	.9945	.9945
10	1.4243		2.1262	.6173	.6173	.7888	.9945
11	1.3226			.4801	.5144	.7202	
12	1.166		2.0576	.5487			
13	1.4243			.5487		.583	.3429
14			.823	.5487		.5487	.3429
15			2.0576	.5487		.5487	.3429
16	.9602		2.1948	.4115		.6173	
17	.4801		.823	2.13	2.332	2.2283	
18	.7202		1.166	1.9662	2.1795	2.13	1.8351
19	1.166		1.2689	1.7204	2.0576	2.2283	1.6385
20	.9945		1.2346	1.4582	1.7147	2.0317	1.6385
21	.8573		1.0288	1.3904	1.2003	1.8023	1.4582
22	.823		1.0288	1.1488	1.0802	1.6712	1.1869
23	.823		.9602	.9945	1.0802	1.6057	1.166
24	.9602	.823		.2058	.9259	1.0631	1.3375
Max	1.4243	1.2346	2.2634	2.13	2.332	2.2283	1.8351
Min	.4801	.7545	.823	.2058	.5144	.5487	.3429
Avg	1.0454	.9825	1.4641	.9784	1.2329	1.2456	1.0978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 210 / LAKSHMI AGRO FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	20-DEC-17
HR	Load (MW)
1	.0171
2	.0171
3	.017
4	.0171
5	.0171
6	.017
7	.0171
8	.0335
9	.0171
24	.0191
Max	.0335
Min	.017
Avg	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 201 / LADGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3734	1.0774	1.2289
2	.3734	.3734	1.0898	1.2289
3	.3734	.3734	1.1736	1.2289
4	.4572	.5601	1.1736	1.3108
5	.5373	.5601	1.1736	1.3927
6	.6201	.5601	1.326	1.3927
7	.5316	.5601	1.5565	1.5565
8	.362	.3734	.3734	
9	.3734	.2829	.3734	.2801
10	1.3108	1.2574	.1867	.2801
11	1.3108	1.5746	.1867	
12	1.3927	1.2574	.0189	
13	1.3927	1.6385	.0943	
14	1.3108		.1867	.2801
15	1.3108	1.4918	.1867	.1848
16	1.3927	1.2574	.1867	.1867
17	1.3927	1.5089	.1867	.2801
18	.3734	.2829	.2801	.2772
19	.4668		.5601	.462
20	.4668	.4668	.4668	.4525
21	.3734	.3772	.3734	.3696
22	.3734	.8573	1.2289	.2572
23	.3734	1.0059	1.2289	.9717
24	.3734	.3734	1.0059	1.2289
Max	1.3927	1.6385	1.5565	1.5565
Min	.362	.2829	.0189	.1848
Avg	.7340	.7894	.6540	.7425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 202 / SAWKHED GANAGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.5735	.2829	.2801
2		.6478	.6401	.2829	.2801
3		.6478	.6401	.2829	.2801
4		.8097	.6401	.2829	.3734
5		.7621	.7316	.2829	.4668
6		.7621	.7373	.5658	.5735
7		1.1431	1.065	.5601	.6554
8		.543	.5601	.4668	
9		.3696	.3772	.4668	.3734
10		.2801	.2829	.9831	1.0669
11		.1867	.1886	1.3108	1.2193
12			.1886	1.4746	1.2955
13		.1867	.0943	1.3108	1.3717
14		.0953	.0943	1.3927	1.3717
15		.0953	.0943	1.3108	.9717
16		.0953	.0943	1.3927	.9145
17		.1867	.0943	1.3108	.9145
18		.3734		.2801	.3658
19		.3734	.4668	.4668	.4525
20		.3734	.4668	.4668	.4525
21		.2801	.3772	.3734	.362
22		.5735	.3772	.2801	.2743
23	.6478	.5735	.2829	.2801	.2772
24		.6478	.5735	.2829	.2801
Max	.6478	1.1431	1.065	1.4746	1.3717
Min	.6478	.0953	.0943	.2801	.2743
Avg	.6478	.4632	.4192	.6829	.6467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 203 / PURANGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.2862	2.1348	.7392	.6554
2		2.2862	2.1348	.7392	.6554
3		2.2862	2.1348	.7392	.6554
4		2.2862	2.2138	.7392	.8192
5		2.3624	2.2929	.9145	.9831
6		2.3624	2.5301	1.1765	1.1469
7		2.7435	2.6092	1.0974	1.2289
8		1.1517	.9831	.9012	
9		.823	.8316	.6554	.5601
10		.4668	.5601	2.372	1.5242
11		.3734	.2829	3.0836	2.5149
12		.3734	.2829	2.7673	2.8197
13		.2801	.1886	3.0836	2.8959
14		.2801	.1886	2.9254	2.9721
15		.2801	.1886	2.9254	2.1338
16		.2801	.1886	3.0045	2.8959
17		.3734	.1886	3.0045	2.9721
18		.7373	.6468	.7468	.8145
19		.8192	1.0059	.9012	.964
20		.7373	1.0059	.9012	.964
21		.7373	.905	.8192	.8859
22		2.1348	.7392	.6554	.724
23	2.2862	2.1348	.7392	.6554	.724
24		2.2862	2.1348	.7392	.6554
Max	2.2862	2.7435	2.6092	3.0836	2.9721
Min	2.2862	.2801	.1886	.6554	.5601
Avg	2.2862	1.2868	1.1296	1.5119	1.4419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 204 / 11KV KAPUS WADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2801	.5144	.7316
2	.2801	.2801	.5144	.6554
3	.2801	.2801	.5144	.6554
4	.3696	.2801	.5144	.8192
5	.4525	.3734	.6001	.8192
6	.5373	.4668	.6783	.8192
7	.4477	.5601	.9945	1.1469
8	.3658	.3734	.2829	
9	.2801	.2829	.2801	.2801
10	.9831	.8478	.2801	.2801
11	.9831	.8383	.1867	
12	1.1022	1.0774	.1867	
13	.9831	1.1736	.2801	
14	.8192	1.1736	.2801	.0943
15	.9012	1.0898	.2801	.1867
16	.9012	1.0059	.2801	.1867
17	.9831	1.1736	.2801	.2801
18	.2801	.2829	.2801	.3658
19	.4668	.4668	.4668	.4525
20	.4668	.3734	.3734	.4525
21	.3734	.3734	.2801	.4572
22	.2801	.5144	.5735	.5868
23	.2801	.5144	.5735	.5801
24	.2801	.2801	.5144	.6554
Max	1.1022	1.1736	.9945	1.1469
Min	.2801	.2801	.1867	.0943
Avg	.5575	.5984	.4171	.5253



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 205 / 11KV BABHULGAON GANGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.9814	1.8976	.3772	.2801
2		1.9814	1.8976	.3772	.2801
3		1.9814	1.8976	.3772	.3734
4		2.1338	1.8976	.4668	.4668
5		2.1338	1.8185	.5601	.5601
6		2.1338	1.8976	.8316	.7316
7		2.2862	2.2138	.7392	.6554
8		.7316	.6535	.5601	
9		.5487	.4668	.5601	.4668
10		.3734	.3734	2.2929	
11		.2801	.2829	2.9254	2.4387
12		.1867	.1886	2.9254	2.7435
13		.1867	.1886	2.9254	2.8959
14		.1867	.1886	2.9254	2.9721
15		.2801	.1886	2.9254	2.9721
16		.1867	.1886	2.8464	2.9721
17		.1867	.1886	2.8464	2.8959
18		.5601		.4668	.4572
19		.6554	.6468	.5601	.7087
20		.5735	.6468	.5601	.6268
21		.4915	.5601	.5601	.543
22		1.9662	.4668	.3734	.4525
23	2.1338	1.8976	.3772	.3734	.4525
24		2.1338	1.8976	.3772	.2801
Max	2.1338	2.2862	2.2138	2.9254	2.9721
Min	2.1338	.1867	.1886	.3734	.2801
Avg	2.1338	1.0857	.9141	1.2806	1.2375

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 206 / BHAOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.6554	1.5089	1.4746
2	.905	.6554	1.5089	1.4746
3	.905	.8192	1.4918	1.4746
4	1.0631	.9831	1.4918	1.6385
5	1.2003	1.1469	1.6385	1.8976
6	1.3413	1.1469	1.8023	1.8976
7	1.3413	.9012	2.1052	2.372
8	1.2003	.9831	.9145	
9	.985	1.086	.8192	.9831
10	1.8976	1.8233	.5601	.8316
11	1.8976	2.3758	.5601	.5544
12	2.2138	2.5911	.5601	.5544
13	2.2929	2.4577	.4668	.5544
14	2.1348	2.5911	.4668	.5601
15	2.1348	2.5911	.3734	
16	2.0557	2.5911	.5487	
17	2.1348	2.5396	.5601	.5544
18	1.065	1.086	.8192	1.1517
19	1.065	1.4175	1.3108	1.3717
20	.9831	1.3432	1.3108	1.3717
21	.9831	1.086	1.1469	1.3717
22	.7373	1.1736	1.3108	1.3765
23	.7373	1.3413	1.3108	1.5242
24	.905	.7373	1.3413	1.4746
Max	2.2929	2.5911	2.1052	2.372
Min	.7373	.6554	.3734	.5544
Avg	1.3785	1.5051	1.0803	1.2602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 201 / 11KV PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7392	.6535	.6535	.6535
2		.7392	.6535	.7468	.7468
3		.8316	.8316	.8316	.8316
4		.9145	1.0164	.924	.924
5		1.0974	1.0974	1.1888	1.1888
6		1.3575	1.2803	1.2936	1.134
7			1.3717	1.2936	1.1317
8		1.0059	1.3203	1.1203	1.1317
9		.9145	1.1869	.9431	.9496
10		1.0745		1.2803	1.2574
11		1.0974		1.5364	1.3077
12		1.2803	.5601	1.8099	1.7604
13		1.6461	.5601	1.8099	
14		1.4632	1.0974	1.6461	
15		1.2803	1.6461	1.6827	.6706
16		1.3169	1.9909	1.5729	.8383
17		1.2803	1.9909	1.4998	2.2298
18		.128	.924	1.2803	.679
19		1.2803	1.0164	1.1888	1.6598
20		1.134	1.0974	1.0974	1.2803
21		1.0974	.924	.961	1.1888
22	.823	1.0349	.924	.924	.8316
23	.8145	.7577	.8402	1.4083	.7392
24		.823	.6535	.7392	.7468
Max	.823	1.6461	1.9909	1.8099	2.2298
Min	.8145	.128	.5601	.6535	.6535
Avg	.8188	1.0563	1.0744	1.2263	1.0855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 202 / 11KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3898	.6535	.5601	.6908
2		.4477	.6535	.7392	.6535
3		.4477	.7392		.6535
4		.5373	.8316	.8316	.6535
5		.6268	.924	1.0059	.924
6		.7087	1.2803	1.4632	1.2826
7		1.1517	1.9004	1.829	.9728
8			.8676	.9335	
9		.924	.9431	.9431	
10		.462	.7392	.7762	.7545
11		.4854	.7095	.8131	.6602
12		.5228	.5601	.8131	.4715
13		.5601			.3772
14		.5601			
15		.5975	.3734		.4715
16		.6348	.5601	.7392	.5658
17		.6722	.7468	.924	.6602
18		.6348	1.0974	1.0974	1.1694
19		1.2803	1.0974	1.2803	1.6221
20		1.0425	1.0974	1.2803	1.1888
21		.961	1.0164	1.0164	1.0164
22	.3582	.4481	.4668	.4668	.5228
23	.3544	.6722	.6535	.6535	.056
24		.3544	.6535	.7392	.7468
Max	.3582	1.2803	1.9004	1.829	1.6221
Min	.3544	.3544	.3734	.4668	.056
Avg	.3563	.6575	.8439	.9453	.7673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 203 / 11KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0974	1.0164	1.0974	1.0059
2		1.134	1.0164	1.0974	1.0974
3		1.1888	.924	1.1888	1.1888
4		1.267	1.0164	1.2803	1.2803
5		1.3575	1.0974	1.4632	1.4632
6		1.4327	1.2803	1.4937	1.307
7			1.4632	1.4937	1.3032
8		1.267			1.3535
9		1.0059	1.358		1.0185
10		1.9281	1.4632		1.9113
11		1.8099	1.6461		2.0957
12		1.8823	1.9909	.4481	2.1795
13		1.9909	2.1719	.7392	2.1795
14		1.9909	2.1719	.7762	2.1963
15		2.1719	2.1719	.8131	2.1628
16		2.1719	1.9909	.924	2.0119
17		1.9909	1.8099	.9877	1.9448
18		.7842	.924	1.1888	.3395
19		1.39	1.0974	1.4632	1.6221
20		1.39	1.3717	1.6461	1.4632
21		1.2803	1.2803	1.2803	1.0974
22	1.1706	1.2803	1.1888	1.1888	1.0269
23	1.1888	1.0974	1.0974	1.0974	1.0269
24		1.1888	1.0425	.905	1.0059
Max	1.1888	2.1719	2.1719	1.6461	2.1963
Min	1.1706	.7842	.924	.4481	.3395
Avg	1.1797	1.4825	1.4170	1.1286	1.4701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 201 / 11kv Darga

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3921	.3174	.4668	.3174
2		.3696	.2801	.4668	.2829
3		.4108	.2801	.5601	.2829
4		.4668	.3734	.5601	.4527
5		.5544	.4435	.6535	.5228
6		.6348	.5175	.6535	.6161
7		.6653	.5175	.5601	.6535
8		.5975	.6283	.6535	.6908
9	.5847	.5601	.5975	.4668	.6535
10	.5731	.5601	.5601	.5249	.5601
11	.543	.5601	.5228	.4481	.5601
12	.5788	.4668	.4481	.4294	.4668
13	.5041	.4066	.4338	.4108	.4668
14	.4668	.462	.3961	.3734	.3696
15	.3881	.462	.3961	.3361	.3391
16	.3921	.462	.415	.3174	.4668
17	.462	.5487	.5601	.4668	.5228
18	.5601	.567	.5601	.5601	.5788
19	.6468	.6401	.5935	.6908	.6722
20	.5975	.567	.6535	.6283	.5975
21	.5175	.499	.5601	.5175	.5601
22	.4668	.4435	.5601	.462	.4668
23	.4108	.3881	.4239	.3881	.4108
24		.4294	.3511	.0467	.7655
Max	.6468	.6653	.6535	.6908	.7655
Min	.3881	.3696	.2801	.0467	.2829
Avg	.5128	.5047	.4746	.4851	.5115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 202 / 11 Rotegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6908	.8962	.8402	.8402
2		.7023	.9335	.8402	.9431
3		.7842	.9335	.9335	1.0185
4		.9055	1.307	1.2136	1.1317
5		1.2883	1.848	1.4003	1.6804
6		1.4937	1.9959	1.6804	1.8671
7		1.8665	2.1437	2.0538	2.0911
8		.8775	1.2936	1.307	1.363
9		.9335	1.1949	1.1765	1.307
10	.7164	1.0269	1.0829	.7095	1.2012
11	1.251	.9335	.9335	.7842	1.1203
12	1.773		.8215	.7655	1.0269
13	1.885	.6468	.8299	.8402	.9335
14	1.7924	.6468	.811	.8029	.8402
15	1.7551	.5487	.811	.7842	.2241
16	1.6078	.7392	.7545	.7468	.9335
17	1.6804	.9145	.8402	.9335	1.0269
18	1.0534	1.0974	.9335	1.1203	1.0269
19	.8589	1.2437	.9326	1.2696	1.1949
20	.9149	1.0059	1.1203	1.0719	1.0829
21	.8686	.8316	1.0269	.8316	.8029
22	.8215	.8316	.9335	.7762	.7842
23	.7577	.7947	.8402	.7207	.8215
24		.5975	.7947	.8402	.7655
Max	1.885	1.8665	2.1437	2.0538	2.0911
Min	.7164	.5487	.7545	.7095	.2241
Avg	1.2669	.9305	1.0839	1.0185	1.0845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 203 / 11kv Tilakroad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7655	.7167	.6783	.6838
2		.7947	.6602	.7468	.6535
3		.8589	.6602	.8402	1.0082
4		.961	.811	.9335	1.0082
5		1.1576	.9335	1.0269	1.1088
6		1.386	1.1576	1.1203	1.2936
7		1.4415	1.363	1.2136	1.4045
8		1.363	1.363	1.307	1.3121
9	1.2757	1.307	1.3203	1.4003	1.307
10	1.1641	1.2136	1.2826	1.1576	1.307
11	1.1088	1.2012	1.1317	1.1203	1.2136
12	1.0829	1.1088	1.0185	1.0642	1.1203
13	.961	1.0164	.9808	.8962	.9326
14	.924	.9335	.9431	.9149	.9335
15	.9149	1.0269	.8676	.8402	.9335
16	.7762	1.0269	.9431	.7762	.9335
17	.9335	1.2012	1.1203	1.1827	1.0642
18	1.0903	1.3121	1.2136	1.3306	1.2136
19	1.4563	1.4415	1.307	1.4784	1.4003
20	1.2936	1.2752	1.4003	1.3169	1.2883
21	1.2012	1.1576	1.307	1.2071	1.1949
22	1.0829	1.0082	1.2136	1.0425	1.0642
23	.8775	.8402	1.1203	.823	.8402
24		.7762	.7468	.9335	.7207
Max	1.4563	1.4415	1.4003	1.4784	1.4045
Min	.7762	.7655	.6602	.6783	.6535
Avg	1.0762	1.1073	1.0659	1.0563	1.0808



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 204 / town 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5041	.4904	.4668	.4854
2		.4668	.4715	.4668	.4715
3		.499	.4715	.5601	.4715
4		.6908	.5658	.5601	.7167
5		.7762	.7095	.6535	.8402
6		.9149	.8962	.7468	.9335
7		1.0719	1.0082	.8402	.9896
8		.9149	.9522	.9335	.9149
9	.8145	.8402	.8488	.8029	.8402
10	.7468	.7468	.7545	.6535	.6783
11	.7762	.6535	.6602	.6161	.6783
12	.6348	.6468	.6036	.5788	.5935
13	.5359	.6099	.6036	.5228	.5601
14	.5601	.6468	.5847	.5415	.4668
15	.5729	.5544	.5847	.5601	.4668
16	.5975	.6468	.6602	.5228	.5601
17	.5544	.7468	.6535	.6535	.5975
18	.6535	.7842	.7468	.7468	.6908
19	.7762	.8962	.7468	.8589	.8962
20	.9149	.8402	.763	.8871	.8029
21	.7577	.7922	.7468	.8131	.7655
22	.6908	.7167	.6535	.7023	.6908
23	.6653	.5847	.6535	.5729	.503
24		.5228	.5281	.5601	.5228
Max	.9149	1.0719	1.0082	.9335	.9896
Min	.5359	.4668	.4715	.4668	.4668
Avg	.6834	.7112	.6816	.6592	.6724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 205 / pahade express feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3326	.0189	.2614	.3921
2		.3174	.0189	.2614	.3961
3		.3361	.0189	.2614	.3961
4		.3734	.0189	.2987	.3961
5		.3881	.0187	.2987	.3921
6		.4108	.0187	.3361	.3921
7		.3734	.0187	.3734	.3921
8		.3142	.0187	.3734	.3921
9	.3547	.1848	.2263	.3982	.3734
10	.3142	.1109	.2829	.3361	.3734
11	.3361	.0183	.2829	.3361	.4108
12	.3326	.0189	.3018	.3258	.3734
13	.3174	.0185	.3018	.3439	.8478
14	.3511	.1109	.3206	.3361	.4668
15	.2987	.1109	.3206	.3174	.3734
16	.3174	.1294	.3584	.2801	.2721
17	.3734	.1307	.3391	.3361	.3734
18	.4066	.1494	.3734	.3361	.2801
19	.4294	.112	.3982	.3734	.4108
20	.3881	.0747	.4108	.4066	.3921
21	.4066	.0189	.4108	.4251	.3734
22	.4108	.0189	.3353	.4251	.4108
23	.3881	.0189	.3734	.4066	.3734
24		.3734	.0189	.3734	.3921
Max	.4294	.4108	.4108	.4251	.8478
Min	.2987	.0183	.0187	.2614	.2721
Avg	.3617	.1852	.2169	.3425	.4019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 206 / water supply Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0259	.0225	.0373	.0221
2			.0248	.0225	.0335	.0221
3			.0236	.0225	.0339	.0221
4			.0372	.0225	.056	.0221
5			.0236	.0221	.0509	.045
6			.0366	.0221	.0337	.045
7			.0495	.0221	.045	.0674
8	.0383		.0255	.0221	.0678	.0562
9		.0442	.0383	.0225	.056	.0373
10		.0394	.0383	.0225	.0991	.0848
11		.0495	.0255	.0225	.0619	.0848
12		.0638	.0383	.0337	.0495	.0848
13		.0366	.0503	.0343	.0724	.0747
14		.0495	.0372	.0229	.0373	.0747
15		.0248	.0372	.0229	.0248	.0248
16		.0255	.0372	.0229	.0244	.0373
17		.0248	.0337	.0373	.0225	.0248
18		.0236	.0225	.0373	.0225	.0373
19		.0255	.0225	.0373	.0225	.0248
20		.0248	.0225	.0373	.0225	.0373
21		.0255	.0221	.0373	.0221	.0373
22		.0248	.0221	.0373	.0221	.0373
23		.0236	.0221	.0037	.0221	.0373
24			.0244	.0221	.0373	.0221
Max	.0383	.0638	.0503	.0373	.0991	.0848
Min	.0383	.0236	.0221	.0037	.0221	.0221
Avg	.0383	.0337	.0309	.0263	.0407	.0443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 207 / 11 KV MGM

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2033	.1886	.1867	.1848
2		.1867	.1886	.1867	.1867
3		.2033	.1886	.1867	.1867
4		.2241	.2263	.2241	.2241
5		.2587	.2241	.2241	.2218
6		.2801	.2614	.2241	.2772
7		.2801	.2801	.2614	.2772
8		.2987	.2801	.2035	.2772
9	.2743	.2987	.2829	.2987	.2801
10	.2587	.2987	.2641	.2614	.2543
11	.2987	.2772	.2641	.2715	.2614
12	.2772	.2772	.2641	.3077	.2614
13	.2614	.2772	.2452	.2987	.2241
14	.2772	.2587	.2452	.3142	.2241
15	.3174	.2614	.2452	.2715	.2058
16	.2801	.2241	.2452	.3326	.2058
17	.2957	.2772	.2801	.3326	.2614
18	.3174	.3511	.2713	.3696	.2427
19	.3326	.3511	.2987	.4251	.3921
20	.3734	.3511	.3361	.3734	.3361
21	.3326	.2987	.2987	.2801	.2801
22	.2801	.2614	.2614	.2427	.2241
23	.1848	.2054	.2241	.2054	.1677
24		.2054	.168	.1867	.1848
Max	.3734	.3511	.3361	.4251	.3921
Min	.1848	.1867	.168	.1867	.1677
Avg	.2908	.2671	.2513	.2696	.2434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 201 / 11 KV CHINCHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487	.583	.6859	.8764
2		.5487	.6173	.6859	.8764
3		.583	.6516	.7545	1.0517
4		.6516	.7202	.7888	1.2269
5		.7716	.823	.8097	1.2269
6		.8916	1.1145	1.1012	1.2269
7		1.1145	1.2174	1.3603	1.7878
8		.7373	.7202	.8688	.7537
9		.5182	.5249	.5792	.5898
10		.3077	.3258		.426
11		.2915	.2896		.3605
12		.2429			.3277
13		.2753			.3277
14		.2429	.3258		.3277
15		.2591	.362	.3932	.3605
16		.2591	.3982	.4588	.3932
17		.2753	.4344	.4915	.4588
18	.4409	.583	.8326	.5571	.5898
19	.6516	.8059	.9774	.6554	.7373
20	.763	.7545	.8688	.8192	.7865
21	.6478	.6859	.724	.8192	.5735
22	.5506	.583	.5144	.8063	.6661
23	.4858	.583	.583	.8764	.8764
24		.5487	.583	.6173	.8764
Max	.763	1.1145	1.2174	1.3603	1.7878
Min	.4409	.2429	.2896	.3932	.3277
Avg	.5900	.5443	.6451	.7436	.7377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 202 / 11 KV AGARSAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3887	.4115	.4344	.4096
2		.3887		.4344	.4096
3		.4372	.4458	.4344	.4915
4		.5144	.5144	.4706	.5735
5		.5182	.5487	.5068	.6554
6		.6154	.6687	.6335	.7045
7		.6478	.703	.7964	.7373
8		.6316	.6344	.6878	.8192
9		.3258	.362	.362	.6062
10		.6516	1.1488	1.0631	.9114
11		.7716	1.4746	1.3496	1.3496
12		1.2689	1.4746	1.4022	1.4022
13		1.4918	1.4746	1.4022	1.4373
14		1.5432	1.4403	1.3146	1.3496
15		1.4575	1.3717	1.5249	1.3146
16		1.3717	1.3032	1.6476	1.1919
17		1.2689	1.2003	1.4198	1.2971
18	.4858	.3601	.5144	.3277	.3768
19	.6154	.5487	.6697	.4915	.4915
20	.6478	.6516	.6154	.6226	.6062
21	.5506	.6173	.5249	.4915	.4915
22	.5182	.583	.5249	.4752	.4752
23	.4534	.4115	.4344	.4096	.4915
24		.3887	.3772	.4344	.4096
Max	.6478	1.5432	1.4746	1.6476	1.4373
Min	.4534	.3258	.362	.3277	.3768
Avg	.5452	.7439	.8190	.7974	.7918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 403 / 33 KV VAIJAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.9127	2.6595	3.0247	2.9687
2			2.9127	2.6029	3.0247	2.9687
3			3.1367	2.6029	3.3608	3.0247
4			3.6969	3.3385	3.8649	3.9209
5			4.4353	4.201	3.9169	4.768
6			5.1029	4.9291	4.8171	5.3778
7			5.647	5.3772	5.3772	5.8768
8			4.3347	4.5931	4.8731	5.0452
9		3.4568	4.1581	4.481	4.6491	4.8731
10		3.9363	3.9918	4.3004	3.7529	4.5931
11		4.3799	3.8809	3.8089	3.6969	4.425
12		4.7188	2.5766	3.4728	3.5848	4.0329
13		4.5462	3.0807	3.4168	3.4168	3.6408
14		4.4353	3.1367	3.3048	3.3608	3.035
15		4.181	3.3048	3.2487	3.1367	3.3048
16		3.9506	3.271	3.3608	2.9687	3.5288
17		4.2353	3.8809	3.8649	3.9769	3.8649
18		4.1027	4.3244	3.4682	4.537	4.313
19		4.4445	4.768	4.481	5.1532	4.9851
20		4.4907	4.1581	4.4239	4.7611	4.537
21		4.1027	3.6408	4.369	4.1027	3.9769
22		3.8089	3.3608	4.0329	3.7146	3.6408
23		3.1927	2.8567	3.3573	2.9938	3.1927
24	2.7446		2.9687	2.6886	3.3608	2.9384
Max	2.7446	4.7188	5.647	5.3772	5.3772	5.8768
Min	2.7446	3.1927	2.5766	2.6029	2.9687	2.9384
Avg	2.7446	4.1322	3.7307	3.7660	3.8928	4.0347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 201 / shivoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7059	.8145	.8859	.7602
2	.7602	.8688	1.0099	.8688
3	.8326	.9412	1.1163	1.0136
4	.9412	1.2489	1.1871	1.1584
5	1.2127		1.258	1.3756
6	1.267	1.5023	1.5769	1.5384
7	1.5203	1.8642	1.8073	1.9728
8	.8145	.8745	.8328	.9231
9	.6335	.6859	.6201	.7059
10	.5249	.5316	.4784	.4973
11	.3258	.3366	.3544	.4973
12	.3429	.443	.3544	.463
13	.3086	.3721	.4163	.463
14	.2572	.3898	.3801	.4973
15	.2743	.4252	.3077	.4287
16	.3258	.3898	.2172	.5316
17	.463	.443	.4163	.463
18	.5487	.6201	.5973	
19	.6344	.691	.7421	
20	.5487	.6201	.6878	
21	.5144	.5138	.5792	.4973
22	.8145	.8328	.8145	
23	.8145	.8328		.8145
24	.7059	.8145	.8505	.7602
Max	1.5203	1.8642	1.8073	1.9728
Min	.2572	.3366	.2172	.4287
Avg	.6705	.7416	.7605	.8115



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 202 / sudamwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.583	.5316	.5792
2	.6516	.583	.5316	.6154
3	.6878	.6516	.5847	.6516
4	.724		.6733	.6878
5	.7602		.7265	.7783
6	.8145	.8059	.7973	.8775
7	.7964	.7373	.7973	.8145
8	.7964	.6516	.7087	.7421
9	.5249	.4458	.443	.5068
10	.8507	1.3289	1.3643	1.3575
11	1.4299		2.1616	1.7194
12	1.6832	2.3388	2.2857	1.8823
13	2.009		2.3529	1.9547
14	1.9185		2.3348	1.7918
15		2.6223	2.2443	1.7375
16	2.2986	2.6578	2.0995	1.828
17	2.0633	2.3565	1.5384	1.7556
18	.4973	.567	.362	
19	.7202	.7265	.8326	
20	.703	.7442	.7602	
21	.6859	.7442	.7421	.7373
22	.6001	.567	.6516	
23	.6335	.5316		.6001
24	.6154	.6001	.5316	.5792
Max	2.2986	2.6578	2.3529	1.9547
Min	.4973	.4458	.362	.5068
Avg	1.0035	1.0654	1.1329	1.1098

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2353	.1715	.1772	.1991
2	.2353	.2058	.1772	.2172
3	.2353	.2058	.1949	.2353
4	.2353		.2126	.2534
5	.2353		.2481	.2534
6	.2353	.2229	.2658	.2715
7	.2534	.2572	.8505	.2353
8	.3439	.3429	.3189	.3439
9	.1991	.1886	.1772	.2715
10	.1448	.2303	.2835	.1991
11	.2896	.3366	.3012	.3258
12	.2896	.3012	.3189	.362
13	.2915	.3721	.3077	.2915
14	.3258	.2835	.3077	.2896
15	.3258	.2835	.3258	.2534
16	.2896	.3012	.2896	.2896
17	.2896	.3189	.2715	.2229
18	.181	.1595	.2172	
19	.2229	.3189	.2534	
20	.2229	.3012	.2534	
21	.2229	.2658	.2534	.2229
22	.2229	.2303	.2353	
23	.1886	.1949		.1715
24	.2353	.1886	.1949	.1991
Max	.3439	.3721	.8505	.362
Min	.1448	.1595	.1772	.1715
Avg	.2480	.2582	.2798	.2554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOR

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.4801	.4784	.4525
2	.543	.5144	.4607	.5068
3	.5792	.6001	.4784	.543
4	.6154		.6201	.6154
5	.7059		.7265	.6878
6	.8326	.7888	.815	.8507
7	.7421	.6859	.7087	.8145
8	.6878	.6516	.6556	.6697
9	.5792	.4287	.4075	.4887
10	.5249	.4784	.4784	.4887
11	.724	.6556		.5973
12	.7421	.691	.7442	
13	.6335	.5138	.7602	
14	.4163	.691	.7059	.6878
15	.6335	.6201	.6335	.724
16	.7421	.691	.6516	.7421
17	.6697	.6379	.6335	.7602
18	.3801	.5316	.4887	
19	.6516	.7442	.6878	
20	.583	.6201	.6154	
21	.5144	.5493	.5792	.5658
22	.463	.5138	.5249	
23	.463	.4961		.4973
24	.4887	.4458	.4961	.4525
Max	.8326	.7888	.815	.8507
Min	.3801	.4287	.4075	.4525
Avg	.6002	.5922	.6068	.6192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 205 / BOLTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.7202	.7973	.8688
2	.8688	.823	.8328	.905
3	.9412	.8573	.8505	
4	1.0317		.9214	1.0498
5	1.1041		1.0631	1.1222
6	1.1765	1.0288	.8328	1.2127
7	1.0498	.4115	.7796	.8688
8	1.0136	.9602	.691	1.1765
9	.7421	.6001	.5493	.8688
10	.9593	1.3643	1.2934	1.2489
11	1.4842	1.6478	1.5415	1.448
12	1.5384	1.7187	1.5947	1.5023
13	1.448	1.5415	1.6289	
14	1.3937	1.4529	1.6289	
15	1.448	1.4706	1.6289	1.9909
16	1.5023	1.4529	1.0679	2.0814
17		1.3112	1.647	
18	.7421		.6878	
19	1.0288	1.0631	1.0679	
20	.9602	1.0277	1.0679	
21	.7716		1.0498	
22	.703	.9036		
23	.6859	.8505		.905
24	.8326	.6859	.815	.8688
Max	1.5384	1.7187	1.647	2.0814
Min	.6859	.4115	.5493	.8688
Avg	1.0547	1.0946	1.0926	1.2079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 206 / BANGLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.5792	.6201	.5792
2	.362	.6154	.6733	.6535
3	.362	.6878	.7087	.6878
4	.3982		.7442	.724
5	.4163		.7619	.7783
6	.4344	.9231	.9214	.8145
7	.9593	1.3575	1.4175	1.3937
8	.6697	.5144	.6201	.5788
9	.5973	.5316	.5493	.5249
10	.5068	.443	.4961	.463
11	.3601	.3544	.4075	.3429
12	.3429	.3721	.4075	.3258
13	.3429		.3258	.3772
14	.3772		.3258	.3086
15	.3429	.3366	.3258	.3801
16	.3429		.3439	.3429
17	.3772		.4163	.3944
18	.4973	.7087	.6878	
19	.8573	.7973	.8326	
20	.703	.7087	.7602	
21	.6001	.6556	.6697	.6859
22	.3439	.4784	.4706	
23	.3982	.5493		.724
24	.362	.5068	.567	.5792
Max	.9593	1.3575	1.4175	1.3937
Min	.3429	.3366	.3258	.3086
Avg	.4715	.6178	.6110	.5829

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVVOOR

Feeder No / Name : 207 / Ex.BANGLA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1991	.6335	.3898	.6154
2	.1991	.5792	.3366	.6154
3	.2172	.5792	.3189	.6154
4	.2172	.543	.3012	.5792
5	.2353		.3012	
6	.2353	.543	.3366	.5249
7	.2172	.4344	.3721	.543
8	.2353	.3077	.3721	.4163
9	.8869	.8326	.5138	.4706
10	.6335	.4961	.6201	.7783
11	.9231	.9036	.8328	.724
12	.8507	.7265	.7087	.6878
13	.8688	.5847	.7602	.4887
14	.8869	.4961	.9774	.7783
15	.8869	.6201	1.0498	.9593
16	.8688	.5847	.8326	1.0136
17	.8326	.6024	.9412	.905
18	.543	.5316	.8145	
19	.4525	.443	.6154	
20	.5068	.4075	.6335	
21	.543	.4075	.6516	.6154
22	.6335	.3898	.5973	
23	.6516	.4075		.6335
24	.1991	.7059	.4075	.6154
Max	.9231	.9036	1.0498	1.0136
Min	.1991	.3077	.3012	.4163
Avg	.5385	.5548	.5950	.6621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOR

Feeder No / Name : 208 / KORADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3801	.5068	.2481	.6878
2	.4163	.5792	.3189	.7602
3	.4706	.7059	.4075	.8688
4	.5068		.5138	.9774
5	.6154		.7265	
6	.7602	.8145	.8328	1.1222
7	1.0679	1.0269	1.0631	1.4118
8	.3982	.4115	.4961	.5068
9	.4344	.4287	.3721	.4887
10	.2172	.2303	.2658	.2915
11	.1715	.1772		.2572
12	.2058	.2303	.1772	.2401
13	.1715	.3012	.2896	
14	.1372	.3544	.2896	.2058
15	.1715	.3189	.2896	.2743
16	.2058	.3721	.362	.3258
17	.2058	.4252	.3801	.4287
18	.4115	.5493	.543	
19	.583	.6201	.6697	
20	.5487	.5316	.5611	
21	.5144	.4607	.4344	.3601
22	.362	.2126	.543	
23	.3982	.2658		.4525
24	.3801	.4525	.2658	.6878
Max	1.0679	1.0269	1.0631	1.4118
Min	.1372	.1772	.1772	.2058
Avg	.4056	.4534	.4568	.5749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 202 / KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.9526	.9335	.6224
2		.7922	1.0479	1.0456	.6602
3		.811	1.1431	.9335	.7167
4		.8488	1.2955	1.0456	.7545
5		.8865	1.3717	1.1203	.9808
6		1.094	1.6194	1.307	1.0374
7		1.2637	1.6032	1.307	1.3014
8		1.1317	1.6032	1.1949	1.1883
9		.9431	1.3717	1.1203	.9431
10		2.0538	1.3413	1.2239	2.2405
11		1.5242	1.9448	1.643	2.3339
12		2.3712	2.0119	1.8442	2.1658
13		2.2405	2.0119	2.0243	2.2405
14		2.3339	1.9448	1.8442	1.643
15		2.2592	1.8442	1.5592	2.1472
16		2.3712	1.8442	1.9784	2.1472
17		2.1472	1.9113	2.0119	1.9605
18	.9054	1.2384	1.1203	1.1317	1.1812
19	1.0562	1.4861	1.419	1.0374	1.3336
20	.9242	1.2574	1.307	.9242	1.2574
21	.8299	1.2384	1.1203	.7545	1.1431
22	.7922	1.0479	.9335	.7167	1.0479
23	.7167	.9526	.9335	.6224	1.0479
24		.7167	.9526	.8589	.5658
Max	1.0562	2.3712	2.0119	2.0243	2.3339
Min	.7167	.7167	.9335	.6224	.5658
Avg	.8708	1.4068	1.4437	1.2576	1.3608



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 203 / DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7167	.4191	.5601	.5281
2		.7167	.4572	.5601	.6224
3		.7545	.5716	.5601	.6602
4		.7545	.724	.6348	.7167
5		.7733	.9145	.6722	.8488
6		.7545	.9526	.8215	.9054
7		.8488	.9526	.8589	1.0374
8		.5658	.8192	.8589	.811
9		.6602	.5335		.547
10		1.467	.9389	1.0059	1.7528
11		1.4289	1.358	1.1065	1.829
12		1.5813	1.4419	1.4754	1.7147
13		1.587	1.5089	1.6263	1.6804
14		1.643	1.4754	1.7604	1.6804
15		1.6057	1.4083	1.9281	1.6598
16		1.086	1.3413	1.8442	1.5655
17		1.4563	1.3077	1.7772	1.448
18	.8488	.5716	.6348	.8488	.4763
19	.8865	.9145	.7468	.8676	.8383
20	.7922	.7621	.7095	.8299	.7621
21	.6224	.724	.6722	.7733	.6668
22	.6602	.6097	.5975	.7167	.6668
23	.6413	.5716	.5601	.679	.6097
24		.6413	.4191	.5601	.6413
Max	.8865	1.643	1.5089	1.9281	1.829
Min	.6224	.5658	.4191	.5601	.4763
Avg	.7419	.9665	.8944	1.0142	1.0279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 204 / Borsar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6516	.6859	.503	.5068
2		.6516	.6668	.6036	.5792
3		.6878	.6668	.7377	.724
4		.6878	1.1812	.8383	.8916
5		.724	1.3336	1.0059	.9945
6		.7783	1.7147	1.073	1.046
7		.9774	1.6804	1.3077	1.6095
8		.3772	.6097	.7095	.5847
9		.4527	.5335	.5601	.6036
10		.381	.3734	.2075	.4191
11		.381	.2987	.2263	.2858
12		.2858	.2987	.2263	.3429
13		.381	.2614	.2263	.2667
14		.381	.2614	.2263	.3048
15		.3429	.2614	.2829	.2667
16		.381	.2987	.3206	.3429
17		.381	.3734	.3395	.381
18	.6036	.6668	.5601	.679	.7621
19	.811	.8764	.7468	.8676	.7621
20	.7545	.6668	.7842	.7167	.724
21	.6036	.5716	.5601	.5658	.7621
22	.6413	.3048	.2683	.543	.8002
23	.6335	.3048	.3018	.4344	.9145
24			.5335	.4481	.3439
Max	.811	.9774	1.7147	1.3077	1.6095
Min	.6036	.2858	.2614	.2075	.2667
Avg	.6746	.5345	.6356	.5687	.6341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 205 / parsoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.905	.9526	.6706	.6516
2		.8573	1.0479	.7712	.6878
3		.8886	1.3336	.8383	.7602
4		.9221	1.5242	.9389	.9259
5		.9556	1.6221	1.0059	1.1401
6		1.0059	1.6804	1.1065	1.2239
7		1.2574	1.6975	1.5089	1.8461
8		.9619	1.3203	1.0456	1.2071
9		1.0374	1.0479	.9335	1.1128
10		.724	.7468	.5281	.724
11		.6668	.5601	.5658	.6287
12		.5335		.5281	.5716
13		.5144	.3734	.4527	.5335
14		.4954	.4108	.4338	
15		.4954	.4481	.415	
16		.4382	.4481	.5658	
17		.6478	.4481	.5658	.6478
18	1.5466	.8573	1.1949	1.4901	1.1431
19	1.4523	1.3717	1.307	1.5278	1.467
20	1.1317	1.105	1.1203	1.3203	1.3717
21	1.0751	.9526	.9335	1.1317	1.3336
22	.8299	.5716	.503	.6878	1.2193
23	.8688	.5716	.503	.6335	1.1431
24		.8688	.7621	.6706	.543
Max	1.5466	1.3717	1.6975	1.5278	1.8461
Min	.8299	.4382	.3734	.415	.5335
Avg	1.1507	.8169	.9559	.8473	.9944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 206 / KHADI CENTER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.1905	.2683	
2		.1886	.1524	.1677	
3		.1886	.1524	.1677	
4		.2263	.1524	.1677	
5		.2263	.1905	.1677	
6		.2641	.1905	.1341	
7			.1905	.0335	
8		.2263	.1524	.0335	
9		.2263	.2667	.0373	
10		.381	.2347	.0377	
11		.4572	.4024	.0377	
12		.4191	.3353	.3772	
13		.5716	.4359	.415	
14		.5716	.4694	.3772	
15		.6097	.4694	.3395	
16		.6287	.6036	.415	
17		.4954	.6036	.415	
18	.1509	.3429	.6036	.3395	
19	.0377	.3429	.1677	.1509	
20	.0754	.1905	.1677	.2263	
21	.0754	.2667	.1677	.1886	
22	.1132	.3048	.2683	.1509	
23	.1132	.2858	.2683	.1132	
24		.1886	.2286	.2683	.0754
Max	.1509	.6287	.6036	.415	.0754
Min	.0377	.1886	.1524	.0335	.0754
Avg	.0943	.3388	.2944	.2096	.0754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 201 / Babhulgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.8802	.9556	.4854	.415	.4108	.3982
2	.663	.9393	.9665	.5415	.4481	.4481	.3932
3	.8383	.9602	.9831	.5975	.5281	.499	.5415
4	.9945	1.0526	1.065	.7468	.7922	.7023	.7922
5	1.2574	1.0883	1.1934	.8501	1.0829	.9145	.9831
6	1.4089	1.166	1.3435	1.1643	1.2136	1.1523	1.0791
7	1.6108	1.5729	1.4746	.9877	1.251	1.1888	1.0059
8	1.0269	1.0242	.8192		.8215	.9795	.7922
9	.6036	.6984	.6718		.6161	.7392	.6036
10	.4108	.3582	.4641	1.0898	.8583	1.1317	1.0456
11	.3018	.2126	.2515		1.1437	1.1797	1.2209
12	.2641	.1949	.2486	1.2125	1.2146	1.3108	
13	.2427	.1928	.1989	1.4419	1.3094	1.278	
14	.2427	.1907		1.4746	1.3226	1.0814	.9503
15	.2452	.2103	.1989	1.2955	1.3245	1.065	1.4632
16	.2641	.2303	.2204	1.2146	1.2887	1.065	1.4563
17		.3898	.2652	1.2631	1.1869	1.0486	1.4998
18	.7468	.5731	.6203	.5975	.679	.7095	.7316
19	.9242	.8238	.8029	.7762	.8488	.9511	.9149
20	.7356	.724	.7291	.7316	.6413	.8048	.7499
21	.5975	.6089	.5935	.6099	.6348	.6653	.6226
22	.7773	.6642	.4752	.5228	.5041	.5228	.5304
23	.8383	.8962	.4294	.4294	.462	.4294	.4481
24	.4534	.8223	.9602	.4481	.4108	.3734	.3856
Max	1.6108	1.5729	1.4746	1.4746	1.3245	1.3108	1.4998
Min	.2427	.1907	.1989	.4294	.4108	.3734	.3856
Avg	.6954	.6864	.6926	.8800	.8749	.8605	.8458

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 202 / Rahegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5138	.4744	.4748	.3395	.3361	.3772	.2926
2	.5304	.4801	.4748	.3772	.3772	.415	.2949
3	.57	.5121	.4588	.4294	.415	.4338	.3113
4	.5801	.5441	.4973	.4854	.4904	.5228	.4024
5	.6783	.583	.5898	.5359	.5658	.5975	.4752
6	.8122	.639	.6882	.7207	.5975	.6653	.5853
7	.9665	.7865	.8192	.6219	.5041	.5914	.5853
8	.3395	.5121	.3605	.5175	.3772	.5175	.3658
9	.3395		.3113	.4108	.2263	.3361	.2926
10	.3734		.1638		.6478	.7373	.7316
11	1.8484		.0983	.6882	.6802	.7042	
12			.0983	.7209	.663	.6554	
13				.6554	.6554		.639
14		.1063		.5898	.5967	.6554	.7373
15				.5801	.583	.7209	.7045
16	.1494			.5365	.57	.7865	.6882
17	.2427			.6706	.5636	.8192	.8029
18		.2126	.2949	.3361	.3961	.3361	.8288
19	.6036	.5731	.5256	.5975	.6348	.5729	.6584
20	.547	.543	.4807	.5079	.6036	.5359	.6535
21	.4715	.5014	.4409	.5228	.5281	.4668	.4904
22	.4973	.3125	.3605	.4108	.3361	.3547	.3658
23	.4973	.4481	.3113	.3361	.3206	.3018	.3292
24	.4973	.4374	.4694	.2829	.3395	.3395	.2926
Max	1.8484	.7865	.8192	.7209	.6802	.8192	.8288
Min	.1494	.1063	.0983	.2829	.2263	.3018	.2926
Avg	.5820	.4791	.4168	.5163	.5003	.5410	.5240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 203 / Nalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2629	.2785	.3086	.2818	.2915	.3292
2	.2829	.3189	.2949	.3353	.2753	.3258	.4024
3	.2987	.3582	.3277	.3353	.2818	.3521	.3932
4	.2987	.3761	.3605	.3688	.3887	.4191	.4572
5	.3361	.4119	.3932	.4096	.4372	.4862	.4588
6	.3772	.5068	.4588	.4752	.4973	.5571	.6584
7	.4715	.5304	.5243	.639	.8288	.8192	.8192
8	.4435	.4163	.4024	.2801	.3174	.2801	.3292
9	.2896	.2835	.2622	.3174	.2054	.2427	.2458
10	.4534	.5155	.4973	.2263	.168	.168	.1638
11	.5304	.4641	.5243	.1698	.0943		.0983
12	.5801	.4858	.5967	.1132	.112		.0983
13	.6104	.4801	.5898	.1132	.1132	.1132	.1311
14	.547	.4858	.5735	.0943	.112	.1132	.1311
15	.5407	.4801	.6062	.0943	.1132	.1132	.0983
16	.5304	.5121	.5898	.0943	.132	.1494	.1494
17	.4144	.4858	.5243	.168	.1509	.1867	.1638
18	.2641	.2686	.1966	.2801	.2452	.2987	.2458
19	.415		.3315	.3696	.3881	.4251	.3647
20	.3734		.2652	.3326	.3547	.3511	.2984
21	.3584	.362	.2321	.2743	.3174	.2772	.2683
22		.3224	.1989	.2058	.2267	.2401	.3109
23	.3206	.3012	.2321	.2743	.2984	.2915	.3361
24	.2263	.2629	.1966	.2572	.2591	.2572	.3292
Max	.6104	.5304	.6062	.639	.8288	.8192	.8192
Min	.2263	.2629	.1966	.0943	.0943	.1132	.0983
Avg	.4011	.4042	.3941	.2724	.2750	.3072	.3034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 204 / AMANSPURWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3189	.3772	.583	.7377	.8402	.7956
2	.3547	.3366	.3772	.6371	.7209	.8551	
3	.3772	.3761	.3772	.6706	.7625	.9054	.7865
4	.3734	.4298	.3921	.6882	.8048	.9389	.8192
5	.4108	.4706	.4481	.7537	.8619	.9892	.852
6	.4527	.5853	.4854	.8192	.8907	1.065	.852
7	.4481	.543	.5544	1.1469	1.3592	1.3763	1.4746
8	.3772	.4298	.4024	.2987	.3772	.4294	.3149
9	.3361		.3841	.3361	.2987	.3206	.3174
10	.5668	1.1873	1.1469	.2987	.2263	.2452	.2012
11	1.3413	1.4083	1.2944	.2641	.1132	.1886	.1696
12		1.4083		.2829	.1494	.1698	.1638
13		.8855	1.1142	.2641	.1867	.1698	.0983
14	1.4255	1.3603	1.3108	.2452	.1494	.1509	.0983
15	1.5257	1.2803	1.2452	.2263	.1886	.1509	
16	1.6108	1.166	1.2125	.2263	.2263	.1698	
17		1.1822	1.1797	.3547	.2263		
18		.2658	.2987	.4066	.2957	.2801	.3086
19	.4527	.3582	.462	.5175	.4715	.4854	.3921
20	.3921	.4344	.4024	.5487	.4338	.4251	.3801
21	.3772	.439	.3696	.4294	.3772	.3696	.3696
22	.3361	.394	.4287	.6173	.5506	.6173	.6554
23	.2801	.3721	.463	.7042	.6464	.788	.8589
24	.2641	.2804	.3772	.5144	.7125	.7888	.7701
Max	1.6108	1.4083	1.3108	1.1469	1.3592	1.3763	1.4746
Min	.2641	.2658	.2987	.2263	.1132	.1509	.0983
Avg	.6002	.6918	.6567	.4931	.4903	.5530	.5339



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 205 / dhondalgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.427	.3429	.3395	.3174	.3395	.2818
2	.4915	.4801	.3688	.4108	.3395	.3361	.3315
3	.5735	.5281	.503	.4668	.3772	.3921	.3978
4	.6706	.583	.6036	.5175	.4481	.4251	.4973
5	.7865	.7773	.6882	.5544	.5975	.5544	.5967
6	.9835	.8482	.9339	.7865	.8299	.695	.6796
7	1.1401	1.065	1.0486	.695	.8299	.7316	.663
8	.3395	.5121	.439	.5487	.3921	.5175	.4641
9	.3174	.3224	.3881	.4066	.3206	.4294	.4239
10	.3734	.3045	.2987	.7888	.4973		.5304
11		.2126	.2427	1.0059	.6796	.6706	.6783
12	.2263	.1928	.2452		.7537	.6718	.8139
13	.2263		.1886	.8848	.8288	.6554	.7045
14	.1886	.2103	.1698	.9175	.8478	.7537	
15	.1886	.208	.168	.9831	.8453	.7865	
16	.2263	.2279	.2054	1.0322	.8029	.8029	.6962
17	.2614	.2658	.2054	.852	.6962	.8383	.8139
18	.4338	.3224	.3696	.3734	.3961	.3734	.3391
19	.5601	.4755	.4024	.5175	.5415	.5914	.5087
20	.5228	.4298	.4755	.4938	.4854	.5729	.4748
21	.3961	.3544	.4066	.4251	.4108	.4481	.407
22	.3401	.2656	.3734	.3734	.3395	.3734	.3222
23	.3812	.3734	.3361	.3206	.3206	.3174	.2984
24	.4144	.3906	.3429	.3018	.3206	.3018	.2818
Max	1.1401	1.065	1.0486	1.0322	.8478	.8383	.8139
Min	.1886	.1928	.168	.3018	.3174	.3018	.2818
Avg	.4570	.4251	.4061	.6085	.5508	.5469	.5093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 206 / sanjarpurwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	15-DEC-17	16-DEC-17	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2303	.2829	.2572	.2984	.2915	.2915
2	.2614	.2629	.2829	.2683	.2984	.3353	.3391
3	.2218	.2686	.3174	.3018	.2949	.3688	.3315
4	.2987	.3045	.3547	.3018	.373		.373
5	.3395	.3403	.3696	.3353	.4748	.503	.4409
6	.3584	.3982	.4066	.3688	.5138	.5243	.5801
7	.3772	.4207	.462	.7537	1.2039	1.1142	1.3413
8	.4108	.362	.4207	.1867	.3361	.3174	.2543
9	.3206	.3224	.1867	.2614	.2263	.2801	.1311
10	.4858	.3906	.583	.1867	.2263	.1509	.1823
11	.6464	.5376	.6554	.1494	.132	.1509	.1357
12	.7042	.639	.6882	.132	.1307	.1132	
13	.6226	.4858	.6554	.1509	.132	.1132	.1696
14	.6133	.5992	.639	.1886	.1698	.112	.1696
15	.5668	.6062	.6718	.1886	.1509	.168	.1326
16	.6464	.6447	.6718	.1698	.1307	.168	.1509
17	.4807	.6154	.6882	.2427		.1867	.1658
18	.2263		.2241	.3142	.3206	.3142	.2515
19	.3921	.3224	.3921	.3292	.3734	.3511	.3353
20	.3547	.3841	.3511	.3475	.3921	.3326	.2652
21	.3547	.3439	.3361	.2801	.3018	.2801	.2321
22	.2987	.3045	.2054	.2401	.2429	.2058	.2652
23	.2614	.2804	.2229	.2743	.3052	.2401	.2543
24	.2263	.2103	.2829	.2229	.2622	.2743	.2652
Max	.7042	.6447	.6882	.7537	1.2039	1.1142	1.3413
Min	.2218	.2103	.1867	.132	.1307	.112	.1311
Avg	.4046	.4032	.4313	.2688	.3170	.2998	.3069

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 201 / 11 KV GARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3174	.2515	.2614	.2801
2		.3361	.2515	.2427	.3361
3		.3547	.2515	.3361	.4668
4		.7682	.3353	.4108	.5487
5		.8145	.503	.6401	.6401
6		.8859	.7545	.8145	.7316
7		.7783	.6706	.815	.8402
8		.724	.5868	.6335	.6401
9		.462	.4191	.5544	.4108
10		.9231	.7545	.788	.7545
11		1.0059	1.1233	1.0227	1.0898
12		1.0898	1.1961	1.0059	1.0059
13		1.1736	1.1603	1.21	
14		1.2574	1.1233	1.0059	1.0898
15		1.1736	1.0562	1.0227	1.0059
16		1.2574	.9892	.9892	.8383
17		.8383	1.0059	.9389	1.0059
18		.3353	.5601	.5788	.4191
19		.8383	.6401	.6468	.6706
20		.7545	.4668	.543	.9221
21	.3734	.7545	.4108	.4108	.6706
22	.3361	.2515	.3734	.3734	.3353
23	.2987	.2515	.3361	.3361	.2515
24		.2801		.2801	.2987
Max	.3734	1.2574	1.1961	1.21	1.0898
Min	.2987	.2515	.2515	.2427	.2515
Avg	.3361	.7344	.6617	.6609	.6632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 202 / 11 KV MANOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7888	.3353	.5487	.5601
2		.8779	.3391	.6401	.7023
3		.905	.4191	.7059	.8145
4		.9955	.503	.724	.9145
5		1.0974	.5868	.9745	.9593
6		1.1222	.7545	.9922	.9745
7		.905	.8383	1.0099	1.0341
8		.823	.8383	.9955	.8316
9		.7023	.5868	.7499	.7468
10		.6706	.8383	.8551	.9221
11		.9221	1.2803	1.4737	1.5089
12		1.0898	1.3441	1.4373	1.5927
13		1.1736	1.2955	1.5935	1.5927
14			1.3765	1.587	1.6766
15		.7545	1.2407	1.4575	1.5927
16		1.2574	1.2955	1.4737	1.1736
17		1.2574	1.247	1.1065	1.3413
18		.6706	.905	.8682	.5868
19		1.0898	1.1517	1.086	.9221
20		.9221	.9955	1.0059	1.0898
21	1.0059	.6706	.6767	.7577	.6706
22	.905	.503	.6535	.7095	.4191
23	.823	.4191	.6283	.6535	.3353
24		.6335	.3353	.5601	.5601
Max	1.0059	1.2574	1.3765	1.5935	1.6766
Min	.823	.4191	.3353	.5487	.3353
Avg	.9113	.8805	.8527	.9986	.9801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 203 / 11 KV POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	17-DEC-17	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.587	1.4251	1.5089	1.3413
2		1.5394	1.6766	1.6842	1.6032
3		2.1872	1.6766	1.7654	2.3434
4		2.4996	1.8442	2.6558	2.5911
5		2.915	2.1795	2.8902	2.8197
6		2.9721	2.8826	2.9683	2.8959
7		3.0704	3.1855	3.0483	3.0178
8		.9745	.9221	1.1888	1.0974
9		.8048	.6706	1.1403	1.0136
10		.1494	.3353	.3547	.4108
11		.0838	.1307	.2054	.1677
12		.0838	.0934		.0838
13		.0838	.0934		.0838
14		.0838	.0934		.0838
15		.0838	.0934	.056	.0838
16		.1677	.1867	.0934	.0838
17		.1677	.4024	.1494	.0838
18		.7545	.8413	.8145	.3353
19		1.5089	1.0974	1.1517	1.3413
20		1.1736	.9145	1.0059	1.0059
21	.905	.7545	.8507	1.0059	.6706
22	1.1603	1.1736	1.0898	1.1717	1.5089
23	1.2146	1.0898	1.1336	1.2308	1.4251
24		1.0898	1.0898	1.1904	1.3077
Max	1.2146	3.0704	3.1855	3.0483	3.0178
Min	.905	.0838	.0934	.056	.0838
Avg	1.0933	1.1249	1.0379	1.2990	1.1416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 201 / biloni SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3283	1.2003	1.3603	1.4575
2	1.5043	1.3717	1.4737	1.4899
3	1.6804	1.4746	1.6032	1.5223
4	1.8724	1.5261	1.6964	1.5546
5	2.0729	1.6956	1.8244	1.8023
6	2.2672	1.7804	1.9524	
7	2.0972	2.0965	2.5232	2.5069
8	.9979	.5658	.5975	.6535
9	.924	.7545	.8871	.8501
10	.6099	.7392	.8316	.7842
11	.6468	.7947	.823	.8029
12	.7356	.8413	.9328	.7842
13	.7392	.6584	.9145	.9328
14	.7682	.7682	.8326	.9145
15	.5121	.8596	.8779	.8596
16	.7392	.9511	.8048	.9145
17	.9055	.961	.9511	.9328
18	.9709	.961	.9425	1.0082
19		.8871	.9896	1.0642
20	.679	.8215	.9522	.8775
21	.7468	.7468	.9522	.8029
22	.8381	1.0185	1.1092	1.2651
23	.9362	1.2037	1.3923	1.5257
24	1.1523	1.0059	1.2346	1.4403
Max	2.2672	2.0965	2.5232	2.5069
Min	.5121	.5658	.5975	.6535
Avg	1.1185	1.0701	1.1858	1.1629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 202 / jarul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.9709	.7842	.924
2	.8589	.9709	.8215	.924
3	.8589	1.0082	.8589	.924
4	.8589	1.0082	.8962	.924
5	.8775		.9335	.924
6	.8775	1.0456	.9709	.9149
7	.8962	1.0642	.7545	1.0269
8	.961	.9431	.9054	.8316
9	.8501	.811	.8962	.8316
10	.703	.7628	.8583	.9172
11	.9282	.8745	1.0202	.9282
12	.9602	.9835	.9717	.4572
13	.9282	.9835	.9762	.8688
14	.8749	.9602	.8421	.8749
15	.7202	.9088	.8745	.8592
16	.7362		.9069	.9602
17	.7842	.823	.6133	.9602
18	.9709		.7682	1.0082
19	.9335	.8501	.9979	1.0082
20	.961	.961	1.0534	.961
21	.8871	.8131	1.0349	.9054
22	.8775	.8215	.9709	.9335
23	.8215	.8215	.924	.8775
24	.8501	.8215	.7842	.924
Max	.9709	1.0642	1.0534	1.0269
Min	.703	.7628	.6133	.4572
Avg	.8681	.9146	.8924	.9029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 15-DEC-17 and 21-DEC-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 203 / lakh khandala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	18-DEC-17	19-DEC-17	20-DEC-17	21-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6036	.5658	.5281
2	.5658	.6413	.5658	.5658
3	.5658	.6413	.5658	.5658
4	.5658	.6602	.5847	.5847
5	.5847	.6979	.5847	.6413
6	.5847	.6979	.6036	.679
7	.6036	.6413	.5658	.6602
8	.5658	.4715	.415	.5281
9	.3772	.3772	.3772	.2641
10	.8619	.423	.8173	.8642
11	1.1203	.719	.8619	.8381
12		1.0288	1.0059	.9602
13	1.0242	1.0288		.9755
14	.9282	1.001	1.0974	.945
15	.8962	.9869	1.0987	.945
16	.9282	.9457	1.2041	.9755
17	.953	.751	1.189	1.0059
18	.3734	.3018	.3018	.4527
19	.5788	.4338	.6036	.5093
20	.547	.5847	.5658	.547
21	.547	.4338	.5281	.5658
22	.547	.5658	.5281	.5093
23	.5228	.4904	.5093	.5281
24	.5658	.5281	.4904	.5093
Max	1.1203	1.0288	1.2041	1.0059
Min	.3734	.3018	.3018	.2641
Avg	.6684	.6523	.6796	.6728