

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 201 / 11 KV SAJAPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.1463	.112	.112	.132	.1254	.2622
2	.1227	.1463	.0934	.1075	.1509	.1433	.2458
3	.1402	.1463	.112	.128	.1698	.1612	.2622
4	.1753	.1629	.1494	.1629	.1886	.1791	.2785
5	.2454	.2896	.2427	.2195	.2263	.2149	.2785
6	.3403	.3361	.3361	.3258	.3584	.2507	.2949
7	.3681	.3801	.3734	.301	.3961	.1753	.2801
8	.3224	.2801	.2801	.3258	.3206	.1928	.2294
9	.2686	.1991	.2801	.2241	.2829	.1402	.2458
10	.2229	.3174	.2031	.2454	.2279	.2614	.1509
11	.25	.213	.125	.2835	.2629	.2458	.1132
12	.1875	.2427	.2229	.2835	.2686	.1966	.0943
13	.25	.2622	.2172	.3012	.2149	.2427	.0943
14	.208	.2622	.1806	.2835	.2686	.2294	.0754
15	.2031	.2294	.2315	.2835	.2686	.213	.0943
16	.216	.2987	.2229	.298	.2507	.2294	.0754
17	.2258	.2458	.2378	.2804	.2507	.213	
18	.1829	.0934	.0753	.2263	.1612	.0112	.1509
19	.2743	.1867	.1806	.2263	.2279	.2054	.2452
20	.2172	.1867	.2987	.2641	.1753	.1867	.2263
21	.1463	.1867	.168	.2263	.1578	.1307	.1698
22	.1448	.1494	.1094	.1886	.1402	.112	.1509
23	.1267	.112	.1267	.1509	.1402	.112	.1509
24	.1075	.128	.0934	.1307	.1509	.1227	.2622
Max	.3681	.3801	.3734	.3258	.3961	.2614	.2949
Min	.1052	.0934	.0753	.1075	.132	.0112	.0754
Avg	.2105	.2167	.1947	.2325	.2247	.1790	.1927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 202 / 11KV DAULATABAD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.3352	1.2883	1.3213	1.4003	1.3253	.5735
2	1.3146	1.3213	1.307	1.3676	1.3443	1.3253	.5571
3	1.3672	1.3169	1.4003	1.3717	1.4563	1.3969	.5735
4	1.4723	1.3394	.2987	1.4118	1.5684	1.5402	.6226
5	1.6126	1.5927	1.643	1.6617	1.7556	1.6297	.6882
6	1.9342	1.7737	1.9791	1.8671	2.1582	1.7193	.7865
7	2.0332	1.9231	1.9978	1.9728	2.4143	1.7878	.9339
8	2.0058	1.9052	1.8484	1.7341	2.2862	1.9204	.9175
9	1.9342	1.8642	1.8298	1.8054	1.9753	1.8404	.9339
10	.7407	.7865	.6562	.8551	.929	.9012	1.7556
11	.639	.7842	.703	.9221	.7888	.9012	1.643
12	.7059	.7282	.5418	.8383	.7343	.852	1.6244
13	.6562	.6908	.6802	.7545	.8238	.8192	1.587
14	.5117	.6348	.5569	.7377	.7164	.6882	1.531
15	.6093	.6062	.5569	.7459	.8059	.639	1.4937
16	.6093	.5735	.6173	.7293	.8059	.7209	1.4377
17	.6405	.6226	.602	.779	.8417	.7045	1.531
18	1.643	1.4937	1.531	1.7002	1.7013	1.7364	1.6804
19	1.8755	1.9231	1.8099	1.9753	1.893	2.0725	2.0119
20	1.9728	1.9978	1.9185	2.0119	1.9281	2.1472	2.1033
21	1.8461	1.7737	1.828	1.848	1.9281	1.9044	1.9753
22	1.647	1.6617	1.6644	1.7926	1.6827	1.7737	1.7737
23	1.4449	1.4937	1.4842	1.6263	1.4899	1.5123	1.643
24	1.3611	1.3213	1.3443	1.3394	1.4563	1.3672	.5735
Max	2.0332	1.9978	1.9978	2.0119	2.4143	2.1472	2.1033
Min	.5117	.5735	.2987	.7293	.7164	.639	.5571
Avg	1.3266	1.3110	1.2536	1.3820	1.4535	1.3844	1.2896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 203 / 11KV FATIYABAD FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.2031	.2458	.2709	.3086	.3224	.7095
2	.2804	.1957	.2294	.2812	.3086	.3582	.6908
3	.3155	.2006	1.3272	.2688	.3429	.3582	.7282
4	.3155	.216	.2785	.2751	.373	.4298	.8402
5	.3403	.3086	.2949	.3086	.407	.5014	.9709
6	.4656	.3858	.4588	.4515	.6706	.5552	1.2323
7	.6485	.5247	.7209	.7968	.9831	.929	1.0456
8	.6984	.6539	.8848	.953	1.0814	1.134	.8029
9	.7701	.587	.7209	.9646	.9831	1.0341	.5415
10	.567	.5788	.4887	.6161	.5784	.5788	.5868
11	.4481	.5228	.4374	.5228	.5083	.5415	.7545
12	.3439	.4854	.4163	.5093	.5014	.5228	.788
13	.3906	.4481	.4706	.4904	.4119	.5228	.8048
14	.4755	.4668	.4805	.5228	.4656	.5601	.7545
15	.4344	.4481	.5611		.4477	.5601	.7042
16	.543	.5415	.5068	.5228	.5373		
17	.6036	.5415	.5304	.5601	.6089	.5788	.7127
18	.6584	.5601	.5788	.6348	.591	.6722	.6535
19	.9145	.9149	1.0374	.9709	.8413	.9149	.8962
20	.9619	.9335	.9412	1.0269	.8413	.9709	.9522
21	.8869	.8402	.9412	.9335	.8238	.9149	.9522
22	.7682	.8029	.8507	.8402	.7888	.8402	.8589
23	.6878	.7282	.7282	.7468	.7011	.7468	.7842
24	.2686	.2343	.2458	.2623	.3258	.3155	.7095
Max	.9619	.9335	1.3272	1.0269	1.0814	1.134	1.2323
Min	.2454	.1957	.2294	.2623	.3086	.3155	.5415
Avg	.5430	.5134	.5990	.5970	.6013	.6462	.8032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 205 / ASEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2454	.1932	.2012	.2006	.2401	.2507	.5601
2	.2454	.2006	.1802	.2006	.2401	.2686	.5788
3	.2629	.1957	.213	.216	.2572	.3045	.6161
4	.2804	.1932	.2294	.2315	.2743	.3582	.7468
5	.3045	.2778	.2801	.2462	.3086	.3761	.8402
6	.3761	.3269	.2801	.3311	.4578	.4119	.9709
7		.3612	.3441	.3763	.503	.5316	.9522
8	.3761	.3462	.3768	.4012	.547	.567	.8029
9	.3761	.3462	.3605	.3913	.503	.5258	
10	.4954	.4854	.4338	.5415	.5083	.5415	.3641
11	.4382	.3734	.4525	.4338		.4294	.4287
12	.362	.4668		.415	.3582	.3921	.4115
13	.362	.3547	.3429	.3772	.4477	.3921	.4287
14	.362	.3547	.362	.3772	.2865	.3734	.4287
15	.381	.3921	.4191	.3961	.394	.2241	.3772
16	.381	.3921	.3658	.3772	.4298	.4294	.3944
17		.4294	.4572	.3772	.4656	.4108	.3944
18	.6668	.5041	.4954	.5093	.5373	.4854	.5601
19	.8764	.7282	.7811	.8215	.7362	.7468	.7468
20	.8002	.8029	.8573	.8402	.7011	.7842	.8402
21	.7049	.7468	.7621	.7842	.6836	.7095	.7655
22	.6668	.6722	.7049	.7095	.6661	.6535	.7095
23	.6154	.6348	.6097	.6535	.5959	.5975	.6535
24	.2507	.1783	.213	.1957	.2454	.2454	.5601
Max	.8764	.8029	.8573	.8402	.7362	.7842	.9709
Min	.2454	.1783	.1802	.1957	.2401	.2241	.3641
Avg	.4468	.4149	.4227	.4335	.4516	.4587	.6144



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 206 / 11 KV JAMBHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8573	.8589	.8383	.8402	.8238	.2622
2	.9114	.8589	.8402	.823	.8589	.8596	.2785
3	.9816	.9526	.8478	.9242	.9335	.8954	.3113
4	1.0517	1.0669	1.2136	1.1431	1.1203	1.0029	.3768
5		1.3769	1.419	1.2955	1.307	1.1462	.4588
6	1.2894	1.3146		1.2574		1.2536	.4915
7	1.1694	1.3717	1.307	1.4098	1.1203	1.1568	.5243
8		.9907	1.0269	.8383	1.0456	.9214	.5571
9		.7621	.7468	.7621	.8589	.8413	.5243
10		.5228	.3864	.4801	.5959	.5601	.5281
11	.421	.4096	.4161	.5144	.5258	.4915	.3772
12	.3567	.3932	.4214	.4801	.7164	.5571	.3584
13	.4062	.3605	.4321	.4458	.5258	.6226	.3395
14	.2778	.4108	.4515	.5087	.5731	.5735	.3584
15	.3269	.3605	.4938	.6036	.6089	.4588	.3772
16	.3593	.426	.4755	.6706	.6089	.3277	.415
17	.3567		.4515	.7377	.5731	.3605	.5658
18	.8383	.5228	.5335	.5601	.5373	.6348	.5975
19	1.1431		.9907	1.1203	.9114	1.0456	1.0829
20	1.2193	1.1949	1.2193	1.2323	.9465	1.1576	1.1949
21	1.1431	1.0829	1.105	1.1203	.9816	1.0642	1.1203
22	1.0479	.9709	1.105	1.0269	.9114	.9522	1.0269
23	.9907	.8962	1.0288	1.4479	.8764	.8962	.9335
24	.9671	1.0098	.8589	1.0288	.8962	.8063	.2949
<b>Max</b>	<b>1.2894</b>	<b>1.3769</b>	<b>1.419</b>	<b>1.4479</b>	<b>1.307</b>	<b>1.2536</b>	<b>1.1949</b>
<b>Min</b>	<b>.2778</b>	<b>.3605</b>	<b>.3864</b>	<b>.4458</b>	<b>.5258</b>	<b>.3277</b>	<b>.2622</b>
<b>Avg</b>	<b>.8067</b>	<b>.8233</b>	<b>.8100</b>	<b>.8862</b>	<b>.8206</b>	<b>.8087</b>	<b>.5565</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 207 / SHAHAPUR BANJARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1806	.1802	.1581	.1734	.2149	.2987
2	.2103	.1806	.1638	.1734	.1753	.2149	.3734
3	.2804	.1932	.1966	.1696	.1907	.2507	.3921
4	.3155	.2229	.2294	.2294	.2229	.2865	.5228
5	.3761	.2709	.3113	.253	.2743	.3224	.6535
6	.4119	.3121	.3277	.2932	.373	.4119	.7282
7	.3681	.3201	.3921	.3462	.4239	.4961	.6535
8	.394	.4064	.3768	.3858	.4359	.5316	.5228
9	.394	.3763	.3441	.3462	.4191	.4733	.3734
10	.3429	.3361		.3395	.3155	.2801	.298
11	.1715	.2801		.2075	.2279	.4294	.3121
12	.2096	.2054		.2075	.2103	.168	.3155
13	.2286	.168	.2477	.1886	.1791	.1867	.333
14	.2477	.2054	.2286	.1886	.197	.1867	.3506
15	.2477	.2054	.2286	.2075	.2149	.2054	.3814
16	.2286	.2241	.2667	.2263	.2328	.2427	.4115
17	.3048	.2241	.2667	.2641	.2507	.2987	.4287
18	.362	.2801	.2829	.2829	.3045	.2987	.3395
19	.6097	.5041	.5716	.5658	.5083	.5415	.5093
20	.6097	.5788	.6859	.5847	.5258	.6535	.5601
21	.5716	.5228	.5525	.5601	.5258	1.0642	.5975
22	.5144	.4854	.5335	.5041	.4382	.4668	.5281
23	.4572	.4294	.9859	.4527	.3856	.4108	.4527
24	.2328	.1783	.1966	1.0288	.1928	.2279	.3734
Max	.6097	.5788	.9859	1.0288	.5258	1.0642	.7282
Min	.1715	.168	.1638	.1581	.1734	.168	.298
Avg	.3444	.3038	.3604	.3402	.3082	.3693	.4462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044044 / 33 KV MALIWADA

Feeder No / Name : 208 / Paper Mill (Saptashrunji) SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1928	.2715	.1867	.2801	.2303	.1227	.2054
2	.1928	.2743	.2054	.2715	.2126	.1227	.1867
3	.2103	.2715	.2241	.2534	.1949	.1417	.2054
4	.2103	.2715	.2427	.2481	.2303	.1402	.2054
5	.2507	.2715	.2427	.2353	.2658	.1578	.2241
6	.197	.2534	.2427	.2801	.2303	.1595	.2427
7	.2454	.3174	.2241	.2353	.2658	.1928	.2241
8	.2149	.3258	.2241	.2353	.2481	.1227	.1867
9	.2149	.2172	.2054	.2353	.2126	.1402	
10	.1886	.2801	.181	.3012	.1227	.1867	.2126
11	.2926	.3921	.2172		.1753	.2054	.2303
12	.2715	.3921	.3109	.2658	.0895	.2054	.2835
13	.2715	.3921	.2353	.2126	.1075	.2054	.3155
14	.2353	.3547	.2561	.2481	.1433	.2241	.298
15	.2534	.3547	.2896	.2835	.1433	.2241	.2804
16	.2454	.3547	.3258	.2658	.1075	.2241	.2658
17	.286	.3361	.2353	.2835	.1433	.2054	.2303
18	.2172	.2987	.2172	.1949	.0895	.2054	.2126
19	.2896	.2614	.1991	.2303	.1052	.2241	.1949
20	.2896	.2614	.2241	.2481	.1052	.2427	.2126
21	.2641	.2427	.2353	.2835	.1052	.2614	.2126
22	.2829	.2614	.2172	.2658	.1052	.2614	.2328
23	.2926	.2427	.2195	.2481	.1578	.2241	.2126
24	.2507	.2715	.2054	.2353	.2303	.1052	.2054
Max	.2926	.3921	.3258	.3012	.2658	.2614	.3155
Min	.1886	.2172	.181	.1949	.0895	.1052	.1867
Avg	.2442	.2988	.2320	.2540	.1676	.1877	.2296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 201 / 11KV Chowka Gaothan

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.2286	.2286	.1905	.2667	.2096
2	.1905	.2096	.2286	.2477	.1905	.2667	.2286
3	.2667	.2286	.2477	.2667	.2667	.2858	.2667
4	.3429	.3239	.2858	.3048	.3429	.362	.362
5	.4382	.4572	.381	.4001	.4572	.4572	.5716
6	.5144	.5716	.5144	.4954	.5144	.5716	.5716
7	.6097	.6287	.6287	.5716	.5335	.5525	.6097
8	.5906	.5525	.6097	.4954	.3429	.5335	.5144
9		.4382	.5144	.381	.2858	.4954	.4382
10	.3429	.3048	.362	.3048	.2286	.362	.3048
11	.2858	.2286	.3048	.2477	.2667	.2667	.2286
12	.1715	.1715	.2286	.2096	.2286	.1524	.2667
13	.1715	.1715	.2477	.1715	.1715	.1524	.1905
14	.1524	.1905	.1715	.1524	.1715	.1524	.2096
15	.1524	.1715	.1715	.1524	.1715	.1905	.1715
16	.1334	.1715	.2286	.1524	.2096	.1715	.1905
17	.3239	.2096	.2096	.2286	.2286	.2667	.1905
18	.362	.3048	.2286	.3239	.3048	.3048	.2096
19	.5144	.4191	.381	.5335	.5716	.4763	.4763
20	.4382	.381	.4382	.4191	.5525	.5335	.4572
21	.3429	.3048	.3429	.3239	.4763	.4382	.381
22	.2477	.2667	.2286	.2477	.362	.3048	.3239
23	.2477	.2286	1.0288	.2096	.3239	.2858	.2667
24	.2096	.2096	.2286	1.0288	.1905	.2667	.2667
Max	.6097	.6287	1.0288	1.0288	.5716	.5716	.6097
Min	.1334	.1715	.1715	.1524	.1715	.1524	.1715
Avg	.3148	.3064	.3517	.3374	.3159	.3382	.3294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 202 / 11 KV SAWANGI Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.381	.3429	.4572	.4382	.4954	.4382
2	.4191	.381	.3429	.4763	.4572	.4954	.4382
3	.4954	.381	.3429	.4954	.5335	.4954	.4763
4							.5144
5		.0953					.5335
6							.5716
7							.9145
8							1.1812
9							1.1812
10	.5906	.5144		.743	.6478	.7811	
11	.5716	.5335		.7621	.8002	.8688	
12	.4954	.4763		.7049	.7621	.9145	
13	.4572	.4382	.5144	.5335	1.0288	.8764	
14	.381	.4572	.4001	.5144	.8002	.8573	
15	.381	.4763	.4382	.5144	.724	.8573	
16	.4001	.4572	.5906	.6097	.6668	.7621	.381
17	.4763	.4763	.6478	.6478	.743	.5716	.4763
18		.4954	.4763	.4954	.5335	.4763	.4763
19	.5525	.5525	.5716	.5335	.5716	.5716	.5716
20	.4954	.5716	.5525	.5525	.5716	.5525	.6287
21	.4763		.5335	.5335	.5716	.5144	.5335
22	.381	.4191	.4954	.4763	.5716	.4954	.4763
23	.381	.381	.4382	.4191	.5335	.4572	.4191
24	.4191	.381	.3429	.4572	.4382	.4954	.4572
Max	.5906	.5716	.6478	.7621	1.0288	.9145	1.1812
Min	.381	.0953	.3429	.4191	.4382	.4572	.381
Avg	.4584	.4371	.4687	.5515	.6330	.6410	.5927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 203 / 11 KV CHOWKA Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.0953
2	.0953	.0953	.0953	.0953	.0953	.0953	.0953
3	.0953	.0953	.0953	.0953	.0953	.0953	.0953
4	.0953	.1524	.0953	.0953	.1905	.1524	
5	.1524	.1905	.1905	.0953	.3429	.2858	
6	.1905	.2858	.2858	.1905	.4382	.381	
7	.2858	.381	.381	.362	.5716	.9526	
8	.381	.5716	.5716	.4572	.8002	.8145	
9		.6287	.5335	.7621	.8764	.7811	
10							.362
11							.5335
12							.6478
13							.381
14							.381
15							.381
16	.0953	.0953	.0953	.0953	.0953	.0953	.4763
17	.0953	.0953	.0953	.0953	.0953	.0953	.381
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.0953	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	1.0288	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	1.0288	.0953	.0953	.0953
Max	.381	.6287	1.0288	1.0288	.8764	.9526	.6478
Min	.0953	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1323	.1863	.2297	.2244	.2424	.2506	.2498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 204 / Lingdari

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.1143	.0953	.0953	.0953	.0953	.0953
2	.0762	.1143	.0953	.0953	.0953	.0953	.1143
3	.1143	.1143	.0953	.1143	.1334	.0953	.1334
4							.1524
5							.1715
6							.1715
7							.1715
8							.1905
9							.1905
10	.1334	.1143	.1334	.0953	.1334	.1143	
11	.1524	.1334	.1524	.1524	.1524	.1524	
12	.1524	.0953	.1524	.1524	.1524	.1905	.9145
13	.1143	.0762	.0953	.1524	.1715	.1905	
14	.0953	.0762	.0572	.1334	.1143	.1715	
15	.0953	.0953	.0572	.1334	.0953	.1524	
16	.0953	.0762	.0762	.1334	.0953	.1334	.0953
17	.0953	.0953	.0762	.0953	.1143	.0953	.0953
18	.1524	.1334	.0953	.1143	.1334	.1334	.1524
19	.2477	.1905	.1334	.2477	.1715	.1905	.1905
20	.2096	.1905	.1905	.2667	.2286	.1715	.2096
21	.1905	.2286	.1715	.1715	.1524	.1715	.1334
22	.1715	.1334	.1143	.1334	.1524	.0953	.1143
23	.0762	.0953	.0953	.1143	.1334	.1524	.0953
24	.0953	.1143	.0953	1.0288	.0953	.1143	.1334
Max	.2477	.2286	.1905	1.0288	.2286	.1905	.9145
Min	.0762	.0762	.0572	.0953	.0953	.0953	.0953
Avg	.1302	.1217	.1101	.1905	.1344	.1397	.1855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 205 / Sawangi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9526	1.1431	1.105	.9526	1.0479	1.0288
2	.9145	.9526	1.1431	1.105	.9145	1.0479	1.0288
3	1.105	.9526	1.1431	1.1431	1.0669	1.1241	1.105
4	1.2765	1.1812	1.3717	1.2955	1.3527	1.2574	1.2955
5	1.6766	1.4289	1.7147	1.4861	1.6766	1.6194	1.4861
6	1.8671	1.6385	1.9624	1.7147	1.9418	1.9052	1.7528
7	1.848	1.7337	1.9243	1.7909	1.8099	2.0195	1.9052
8	1.8099	1.6385	1.7147	1.6004	1.8671	1.8671	1.7528
9	1.4289	1.3336	1.2955	1.5242	1.3717	1.6194	1.3717
10	1.1431	1.1431	1.0479	1.2193	.9526	1.1431	1.1431
11	1.0098	.9526	.9145	1.0479	.8764	.9907	.9526
12	.8002	.8383	.8002	.9907	.8383	.8383	.9145
13		.6859	.724	.9526	.724	.8002	.9145
14	.7621	.6478	.743	.9145	.7621	.8573	.8573
15	.7049	.724	.7811	.8573	.8002	.9526	.8954
16	.7049	.8764	.8573	.8573	.8764	1.0288	.9526
17	.8764	1.0479	1.0669	1.105	1.0288	1.2193	1.0669
18	1.4289	1.448	1.3336	1.3336	1.467	1.3336	1.2955
19	1.6575	1.6194	1.6385	1.6575	1.6575	1.5623	1.6194
20	1.4098	1.5242	1.6004	1.448	1.6194	1.6766	1.6575
21	1.2384	1.2765	1.3336	1.3336	1.4289	1.3717	1.3908
22	1.1431	1.1431	1.1431	1.1431	1.2765	1.2955	1.1622
23	1.0479	1.1431	1.0669	1.0098	1.1622	1.105	1.0669
24	.9526	.9526	1.1431	1.1431	.9526	1.0479	1.0288
Max	1.8671	1.7337	1.9624	1.7909	1.9418	2.0195	1.9052
Min	.7049	.6478	.724	.8573	.724	.8002	.8573
Avg	1.2052	1.1598	1.2336	1.2408	1.2240	1.2805	1.2352



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 206 / 11 KV Tuljapur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.2286	.1905	.2858	.2286	.2286
2	.2477	.2858	.2286	.1905	.2667	.2286	.2477
3	.2477	.2858	.1905	.2286	.2858	.1905	.2667
4	.2667	.2477	.1905	.2477	.2858	.1905	.2477
5	.2477	.2477	.1905	.2667	.3239	.1905	.3429
6	.2858	.2286	.1905	.3048	.3239	.1905	.3048
7	.3048	.381	.1905	.2858	.3239	.2286	.2858
8	.2858	.381	.2286	.2858	.3429	.2858	.3048
9	.5144	.4763	.6097	.4382	.362	.2858	.2858
10	.7621	.8002	.8764	.6668	.3429	.2477	.4572
11	.8192	1.0669	.9145	.9907	.3048	.2477	.7621
12	.8002	.8002	.8764	1.2765	.3048	.2858	.9526
13	.7621	1.0288	.4763	1.3717	.2858	.2477	.6097
14	.8573	1.1431	1.105	.8954	.2858	.2477	.7621
15	.9526	.9526	.7811	.8954	.2858	.2477	.6668
16	.9526	.4763	.6859	.8573	.2667	.2286	.6097
17	.9526	.9335	1.2955	.9145	.2858	.2667	.5716
18	.743	.8002	1.0288	1.0288	.2858	.2477	.6668
19	.4763	.4001	.362	.3239	.2858	.2667	.2667
20	.381	.3429	.2858	.3239	.2477	.2667	.2858
21	.3429	.2858	.2667	.3429	.2477	.2477	.3048
22	.3239	.2286	.2286	.3048	.2477	.2286	.2858
23	.3048	.2286	.2667	.3239	.2477	.2477	.3048
24	.3048	.2858	.2286	.2858	.2858	.2286	.2477
Max	.9526	1.1431	1.2955	1.3717	.362	.2858	.9526
Min	.2477	.2286	.1905	.1905	.2477	.1905	.2286
Avg	.5168	.5247	.4969	.5517	.2921	.2405	.4279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044045 / 33/11KV CHOWKA S/S

Feeder No / Name : 207 / 11 KV Unique Stone crusher SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0572	.0191	.0191	.0762
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0381	.0191	.0381
11	.1334	.0191	.1905	.0762	.0572	.0191	.0572
12	.1524	.1334	.1524	.1524	.0381	.0191	.0572
13	.1715	.1715	.1143	.1334	.0572	.0191	.0191
14	.1524	.1905	.0953	.1334	.0572	.0191	.0191
15	.1143	.1334	.0572	.0762	.0381	.0191	.0191
16	.0381	.0762	.0762	.0953	.0572	.0191	.0191
17	.1334	.1334	.1905	.0762	.0191	.0191	.0191
18	.0953	.1715	.1334	.0762	.0191	.0191	.0191
19	.1524	.1715	.1143	.0762	.0191	.0191	.0191
20	.0762	.0953	.0762	.0572	.0191	.0191	.0191
21	.0191	.0381	.0381	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.1715	.1905	.1905	.1524	.0572	.0191	.0762
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0620	.0659	.0619	.0524	.0278	.0191	.0254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 201 / 11KV GROWTH CENTRE I

SHEDDABLE URBAN

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5959	.6478	.5959	.631	.5959	.631
2		.5959	.6478	.5959	.5959	.5959	.6661
3		.631	.6478	.631	.631	.631	.7011
4		.6661	.8383	.6661	.631	.6661	.7362
5		.7011	.8383	.7011	.6661	.6661	.7712
6		.7712	.8954	.7712	.6661	.7011	.8413
7		.7011	.9717	.8063	.7011	.7362	.8063
8		.8413	1.086	.7011	.7712	.8413	.8063
9	.8573	.7011	.8573	.631	.7712	.8413	.631
10	.6478	.7621	.5853	.567	.6401	.8413	.6219
11	.6478	.5144	.4755	.4572	.6584	.6584	.5853
12	.4954	.4572	.5487	.4572	.4755	.4572	.4755
13	.4572	.4572	.5121	.4572	.4572	.4755	.4755
14	.4382	.4572	.4572	.439	.4572	.4954	.4755
15	.4572	.4763	.4024	.439	.439	.4954	.4755
16	.4572	.4572	.439	.4572	.4755	.5144	.4572
17	.4557	.3506	.4572	.4954	.4954	.5144	.5144
18	.4908	.4207	.4755	.6478	.5716	.0572	.5335
19	.631	.7011	.6219	.8192	.6859	.6859	.6668
20	.7011	.7011	.7316	.8383	.8002	.7621	.8383
21	.7011	.6661	.7316	.8383	.8573	.8383	.8573
22	.7011	.6661	.6401	.8002	.8383	.6478	.8383
23	.6661	.6668	.631	.7011	.631	.6135	.7362
24		.631	.6097	.5959	.6661	.631	.5959
Max	.8573	.8413	1.086	.8383	.8573	.8413	.8573
Min	.4382	.3506	.4024	.439	.439	.0572	.4572
Avg	.587	.6079	.6562	.6296	.6339	.6234	.6557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 202 / 11KV A.S.CLUB FEEDER Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0381	.0377	.0175	.0175	.0175
2		.0189	.0381	.0377	.0175	.0175	.0175
3		.0189	.0381	.0377	.0175	.0351	.0351
4		.0189	.0381	.0566	.0351	.0526	.0351
5		.0377	.0572	.0754	.0526	.0526	.0526
6		.0566	.0762	.0943	.0701	.0701	.0701
7		.0566	.0762	.0754	.0876	.1052	.1052
8		.0701	.0572	.1052	.1402	.1578	.1928
9	.0953	.0754	.0953	.1052	.1402	.1753	.2279
10	.0191	.0381	.1097	.0914	.0914	.0914	.0914
11	.0381	.0381	.1097	.0914	.0732	.0914	.0549
12	.0381	.0381	.1097	.0549	.0549	.0732	.0914
13	.0191	.0381	.1097	.0366	.0549	.0732	.0183
14	.0191	.0381	.0732	.0366	.0549	.0572	.0366
15	.0191	.0381	.0732	.0366	.0549	.0572	.0549
16	.0191	.0381	.0366	.0366	.0366	.0381	.0366
17	.0175	.0351	.0366	.0572	.0381	.0762	.0762
18	.0566	.0377	.0366	.0572	.0381	.0762	.0762
19	.0566	.0351	.0549	.0953	.0572	.0762	.0572
20	.0566	.0351	.0732	.0762	.0572	.0572	.0762
21	.0566	.0377	.0732	.0572	.0572	.0572	.0762
22	.0566	.0377	.0566	.0572	.0381	.0572	.0572
23	.0377	.0381	.0566	.0566	.0189	.0377	.0526
24		.0377	.0381	.0566	.0175	.0175	.0175
Max	.0953	.0754	.1097	.1052	.1402	.1753	.2279
Min	.0175	.0189	.0366	.0366	.0175	.0175	.0175
Avg	.0403	.0397	.0651	.0635	.0551	.0675	.0678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 203 / 11KV P.M.CHORDIA FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0526	.0572	.0526	.0526	.0526	.0526
2		.0526	.0572	.0526	.0526	.0526	.0526
3		.0526	.0572	.0526	.0526	.0526	.0526
4		.0526	.0572	.0526	.0526	.0526	.0526
5		.0526	.0572	.0526	.0526	.0526	.0526
6		.0526	.0572	.0526	.0526	.0526	.0526
7		.0526	.0572	.0526	.0526	.0526	.0526
8		.0526	.0572	.0526	.0526	.0526	.0526
9	.0953	.0526	.0572	.1227	.0351	.0701	.2103
10	.1524	.0762	.1097	.2195	.0914	.2743	.1829
11	.1524	.1524	.1463	.0914	.0914	.4024	.2012
12	.1905	.1524	.3292	.1646	.1646	.1829	.1097
13	.1905	.1524	.3292	.128	.128	.1646	.0549
14	.1524	.0953	.3292	.0549	.1463	.1524	.0549
15	.1524	.3048	.3658	.0549	.1646	.1334	.0549
16	.1524	.2286	.2012	.0549	.1097	.1143	.128
17	.0876	.0876	.2012	.0572	.1334	.2096	.1334
18	.0526	.1753	.2012	.0572	.1334	.1524	.1334
19	.0526	.1578	.0732	.0572	.0572	.1143	.1334
20	.0526	.1578	.0549	.0572	.0572	.1143	.0953
21	.0526	.1402	.0549	.0572	.0572	.1143	.0572
22	.0526	.0876	.0549	.0572	.0572	.1143	.0572
23	.0526	.1715	.0526	.0526	.0526	.0701	.0876
24		.0526		.0514	.0526	.0526	.0526
Max	.1905	.3048	.3658	.2195	.1646	.4024	.2103
Min	.0526	.0526	.0526	.0514	.0351	.0526	.0526
Avg	.1094	.1111	.1312	.0733	.0814	.1190	.0903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 204 / 11KV Growth Center II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3506	.3429	.2804	.2804	.3155	.298
2		.3155	.3429	.2454	.298	.298	.2804
3		.2804	.362	.2454	.3155	.2804	.2804
4		.298	.362	.2804	.3155	.2804	.298
5		.3155	.362	.2804	.3155	.3155	.3155
6		.3506	.381	.3155	.3155	.3155	.3506
7		.3506	.3429	.3155	.333	.2804	.3155
8		.298	.362	.2804	.298	.3155	.2804
9	.3048	.2629	.3239	.2743	.2454	.2804	.2804
10	.2286	.2858	.2743	.2195	.2926	.2561	.2926
11	.2286	.2286	.2378	.2012	.2926	.2743	.2743
12	.2286	.2286	.2195	.1829	.2743	.2926	.2743
13	.2096	.2286	.2195	.2195	.2561	.2926	.2378
14	.2286	.2477	.2195	.2012	.2561	.2858	.2378
15	.2667	.2096	.2195	.2012	.2378	.2858	.2561
16	.2667	.2477	.2012	.2378	.2561	.2858	.2378
17	.2454	.1928	.2195	.2286	.2477	.2477	.2667
18	.2454	.2279	.2378	.2667	.2477	.2667	.2667
19	.3155	.298	.3109	.3429	.3429	.3048	.3429
20	.3506	.3681	.3841	.381	.4001	.3429	.381
21	.3506	.3506	.3841	.4001	.4001	.381	.4001
22	.3506	.3506	.4024	.4191	.381	.4001	.381
23	.3506	.381	.3506	.3506	.3155	.3506	.333
24		.333	.3429	.298	.333	.3155	.3155
Max	.3506	.381	.4024	.4191	.4001	.4001	.4001
Min	.2096	.1928	.2012	.1829	.2378	.2477	.2378
Avg	.2781	.2917	.3086	.2778	.3021	.3027	.2999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 205 / 11KV Sara

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3672	1.448	1.3321	1.3496	1.3672	1.1218
2		1.3321	1.448	1.3321	1.3496	1.3321	1.3321
3		1.5424	1.4861	1.4723	1.3847	1.4373	1.5249
4		1.7528	1.7909	1.7177	1.6126	1.7703	1.6476
5		2.0332	1.7909	2.0683	1.858	2.1033	1.7528
6		2.2611	2.0576	2.1735	2.1033	2.4539	1.893
7		2.1033	2.5149	2.2786	2.4364	2.3838	1.858
8		2.2961	2.1338		2.2961	2.3487	1.6476
9	2.0767	2.2961	1.7718	1.6301	1.9456	1.9281	1.2269
10	1.8671	1.7909	1.1706	1.6461	1.7375	1.4815	1.6827
11	1.6004	1.5051	1.0974	1.262	1.5364	1.4815	1.4815
12	1.4289	1.448	1.2803	.8779	1.4815	1.4998	1.3352
13	1.4098	1.2955	1.262	.8779	1.2803	1.2986	1.2437
14	1.2765	1.1812	1.1706	.8779	1.2986	1.467	1.2437
15	1.1622	1.1812	1.0974		1.3352	1.4098	1.2254
16	1.2193	1.2193	1.1888		1.2803	1.448	.9877
17	1.3847	1.3672	1.3535	1.5623		1.4861	1.5432
18	1.6476	1.4373	1.4998	1.6385	1.448	1.6385	1.6004
19	1.6827	1.858	1.8839	1.8099	2.2291	1.9052	1.829
20	1.7353	1.858	2.1216	1.9433	2.2862	1.9433	1.8671
21	1.5775	1.8229	1.829	2.0386	2.0576	2.0576	1.8861
22	1.4918	1.7528	1.9387	1.9243	1.9243	2.0767	2.0576
23	1.4723	1.5813	1.858	1.5249	1.6476	1.1919	1.6651
24		1.4022	1.4861	1.3496	1.3672	1.5249	1.1218
Max	2.0767	2.2961	2.5149	2.2786	2.4364	2.4539	2.0576
Min	1.1622	1.1812	1.0974	.8779	1.2803	1.1919	.9877
Avg	1.5355	1.6536	1.6117	1.5875	1.7063	1.7098	1.5323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 206 / 11KV South City

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.333	.362	.3155	.298	.333	.333
2		.333	.362	.298	.298	.3155	.3506
3		.333	.362	.298	.298	.3155	.3856
4		.3506	.4191	.3506	.3155	.3506	.4207
5		.3856	.4572	.4207	.3506	.3506	.4557
6		.4382	.4572	.4908	.4557	.3856	.4908
7		.4031	.5716	.4557	.5258	.3506	.4557
8		.4908	.4763	1.6301	.4908	.4557	.4557
9	.4763	.3681	.4191	.4045	.4207	.4908	.333
10		.1334	.3841	.4024	.439	.4572	.3658
11	.4191	.4191	.3658	.3841	.439	.439	.3475
12	.362	.381	.3475	.3658	.4024	.3658	.3658
13	.3429	.362	.3475	.3292	.3658	.3292	.3109
14	.3239	.3429	.3475	.3109	.3475	.3429	.3109
15	.3048	.3239	.3658	.3109	.3292	.362	.3292
16	.3048	.3239	.3109	.3292	.3292	.381	.3292
17	.3155	.3506	.3841	.3239	.381	.3429	.362
18	.3155	.4031	.439	.381	.381	.381	.381
19	.3506	.4382	.4572	.4572	.4954	.381	.4191
20	.4031	.4031	.4572	.4572	.5335	.4001	.4572
21	.3506	.3856	.4207	.4382	.4191	.4191	.4572
22	.3506	.3506	.3841	.4191	.4191	.4191	.4382
23	.3506	.381	.3681	.3681	.3506	.3506	.3506
24		.3506	.362	.3086	.333	.333	.333
Max	.4763	.4908	.5716	1.6301	.5335	.4908	.4908
Min	.3048	.1334	.3109	.298	.298	.3155	.3109
Avg	.3550	.3660	.4012	.4271	.3924	.3772	.3849



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044068 / 33KV WALUJ MAHANAGAR S/STN.

Feeder No / Name : 209 / 11 KV Stone Crusher

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6661	.6097	.5959		.631	.631
2		.631	.6097	.5959		.631	.6661
3		.631	.6478	.6661		.6661	.6661
4		.6661	.724	.7011	.631	.7011	.7011
5		.6661	.7621	.7362	.6661	.7712	.7712
6		.7011	.8573	.7712	.7011	.8413	.8413
7		.7712	.9145	.7362	.7712	.9114	.8764
8		1.0517	1.2003	.7011	.8413	.9816	.9816
9	1.5051	1.2795	1.4289		.9816	1.4022	1.4022
10	1.2003	1.448	1.2071	.8048	1.2986	1.829	1.262
11	1.448	1.5051	1.1523	.7499	1.2437	1.0425	1.5912
12	1.0288	1.4098	1.4449	.7316	1.262	1.7741	1.6278
13	1.1812	1.2955	1.3535	.6767	1.1523	1.5546	1.262
14	1.0288	1.2384	1.2803	.6219	1.0791	1.9052	1.2254
15	1.0098	.9907	1.1706	.6219	.9511	1.8099	1.1888
16	1.0288	1.2193	1.4266	.5853	.9877	2.0195	1.4083
17	1.2971	1.262	1.1883	.6668	1.3146	1.2955	1.1622
18	1.4022	1.1919	1.1888	.6859	1.3336	1.2193	1.1431
19	1.0867	1.0517	1.0425	.724	1.2955	1.105	1.0479
20	.7712	.631	.8779	.724	1.2193	.9526	.9145
21	.7011	.631	.8596	.743	.7621	.9145	.8002
22	.7011	.631	.8596	.724	.8002	.9145	.7621
23	.7011	.8192	.7011	.631	.6661	.7011	.6661
24		.7011	.8002	.6516	.5959	.631	.6661
Max	1.5051	1.5051	1.4449	.8048	1.3336	2.0195	1.6278
Min	.7011	.631	.6097	.5853	.5959	.631	.631
Avg	1.0728	.9621	1.0128	.6890	.9788	1.1336	1.0110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 201 / 11 KV Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3294	.3155	.3121	.2774	.3224	.2835
2	.3086	.3121	.3467	.333	.3121	.3439	.2835
3	.3467	.3121	.3641	.3641	.3155	.3582	.3189
4	.3814	.3601	.3772	.3772	.3506	.3982	.3544
5	.4115	.4115	.4287	.4239	.3898	.443	.5258
6	.4458	.5316	.4681	.6173	.4607	.4733	.5258
7	.5765	.5765	.5087	.6952	.5609	.5784	.4908
8	.4862	.5256	.4973	.6613	.4908	.5434	.4382
9	.6783	.6783	.6516	.1543	.4334	.4656	.3294
10	.6613	.6687	.5784	.1357	.4801	.6485	
11	.373	.5375	.5784	.2058	.6415	.6241	.5201
12	.3601	.4382	.6024	.6415	.6001	.5721	.583
13	.3429	.3045	.4382	.5258	.4733	.6068	.583
14	.3086	.3155	.3366	.3856	.3814	.5895	.6001
15	.3258	.3366	.3544		.3772	.3641	.5087
16	.3391	.3544	.4119		.3856	.3121	.4239
17	.3561	.3403	.4298	.2947	.4161	.3641	.3561
18	.39	.4733	.443	.4557	.4075	.5609	.3506
19	.463	.6201	.4607	.4557	.4706	.6485	.4557
20	.4458	.5258	.591	.4681	.4835	.4382	.5138
21	.583	.4334	.5316	.4161	.4525	.4382	.4075
22	.3601	.4298	.394	.3429	.4252	.4252	.3898
23	.3258	.362	.3582	.3086	.394	.3721	.3582
24	.3086	.3258	.3155	.3155	.2774	.362	.3544
Max	.6783	.6783	.6516	.6952	.6415	.6485	.6001
Min	.3086	.3045	.3155	.1357	.2774	.3121	.2835
Avg	.4120	.4376	.4493	.4041	.4274	.4689	.4328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 202 / 11 KV Patoda Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0347	.0351	.0347	.104	.1109	.1417
2	.0343	.0347	.0351	.0351	.104	.1267	.1417
3	.0347	.0347	.0347	.0347	.1402	.1478	.1595
4	.0347	.0343	.0351	.0343	.1402	.181	.1772
5	.0343	.0343	.0351	.0339	.1772	.2149	.1928
6	.0343	.0343	.0347	.0343	.2481	.2481	.2629
7	.0339	.0339	.0343	.0339	.3155	.2804	.2804
8	.0335	.0678	.0701	.0339	.3155	.2279	.2454
9	.0678	.1357	.0857	.1372	.2254	.2561	.208
10	.1865	.1029	.0905	.1696	.2401	.2804	.4458
11	.1696	.1448	.0709	.2058	.2774	.3641	.4161
12	.1029	.1109	.0709	.2774	.2572	.3641	.3772
13	.0686	.0924	.0701	.2103	.2629	.3814	.3772
14	.0686	.0876	.0354	.1928	.2279	.3814	.4115
15	.0686	.0905	.0709		.2401	.3814	.39
16	.0678	.0924	.0716		.2683	.4508	.407
17		.0914	.0716	.0693	.2947	.4334	.39
18	.0339	.1448	.1417		.1448	.1578	.1753
19	.1886	.1949	.1772	.1402	.181	.1928	.1928
20	.1886	.2172	.2149	.1734	.2218	.1928	.2126
21	.1372	.1829	.1772	.1387	.181	.1753	.1772
22	.1029	.1791	.1612	.1372	.1463	.1595	.1595
23	.1029	.1448	.1433	.1029	.1478	.1595	.1612
24	.0343	.0343	.0358	.0351	.104	.128	.1417
Max	.1886	.2172	.2149	.2774	.3155	.4508	.4458
Min	.0335	.0339	.0343	.0339	.104	.1109	.1417
Avg	.0810	.0981	.0835	.1078	.2069	.2499	.2602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044087 / 33 KV Patoda S/S

Feeder No / Name : 203 / WALDGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029		.124	.0693			
2	.1029	.0693	.1052	.1052			
3	.1387	.0693	.104	.104			
4	.1387	.1029	.1372	.1029			
5	.1715	.1029	.1372	.1357			
6	.1715	.1029	.2058	.1372			
7	.2035	.1357	.2543	.2035			
8	.2347	.1696	.2572	.2035			
9	.2713	.1357	.2915	.2058			
10				.2058	.2058	.2601	.3429
11				.2401	.2601	.3467	.3814
12				.2774	.2915	.3467	.3772
13				.2103	.2629	.3814	.4115
14				.1753	.2601	.3814	.3772
15					.2572	.3121	.373
16					.2515	.3121	.39
17				.0347	.2427	.3121	.407
24	.1029	.0686	.1052	.1052			
Max	.2713	.1696	.2915	.2774	.2915	.3814	.4115
Min	.1029	.0686	.104	.0347	.2058	.2601	.3429
Avg	.1639	.1063	.1722	.1572	.2540	.3316	.3825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 201 / Adgaon(Sarak)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3441	.2294	.3638	.2458	.4096	.2294	.1638
2	.4424	.2622	.3638	.2458	.4096	.2622	.1638
3	.4424	.2785	.3804	.2458	.4096	.2785	.1638
4	.4915	.3932	.4134	.3277	.4915	.3277	.1638
5	.5735	.4096	.43	.3605	.5898	.3605	.1966
6	.6226	.5407	.5127	.426	.8192	.5898	.2294
7	.6554	.5898	.7938	.8684	1.2125	1.1305	.213
8	.426	.7537	.9095	1.0814	.8192	1.065	.1802
9	.3473	.678	.5735	.9339	.5735	.9667	.1475
10	.1158	.1158	.1475	.1311	.1147	.1475	.8848
11	.0661	.0827	.0983	.0983	.0983	.1475	.6718
12	.0496	.0827	.0983	.0819	.0819		1.0814
13	.0496	.0661	.0819		.0819		.9995
14	.0496	.0661	.0819	.0983	.0492	.0819	1.4419
15	.3038	.0661	.0983	.0983	.0819	.1147	1.2289
16	.0827	.0827	.0983	.0983	.0819	.1147	.4915
17	.1147	.0827	.0983	.1147	.0819	.1475	.4915
18	.1311		.1147	.1311	.0983	.1475	.1311
19	.1638	.1488	.1475	.1475	.1475	.1802	.1638
20	.1638	.1488	.1638	.1638	.1638	.1966	.1966
21	.1638	.1819	.1638	.1638	.1638	.1966	.213
22	.1475	.1654	.1638	.1638	.1638	.1802	.1802
23	.1475	.1488	.1475	.1638	.1475	.1638	.1638
24	.2458	.2294	.3638	.213	.3605	.2294	.1638
Max	.6554	.7537	.9095	1.0814	1.2125	1.1305	1.4419
Min	.0496	.0661	.0819	.0819	.0492	.0819	.1311
Avg	.2642	.2523	.2837	.2871	.3188	.3299	.4219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 202 / Mandki

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	.2561	.1715	.2172	.1311	.2561	.1753
2	.1475	.2743	.1715	.2172	.1311	.2561	.181
3	.1475	.2743	.1715	.2172	.1526	.2534	.181
4	.1638	.2896	.1905	.2715	.1475	.2743	.2172
5	.1638	.3142	.2096	.3077	.1638	.2926	.2715
6	.1966	.3511	.2477	.3439	.1966	.3326	.3077
7	.2458	.4294	.2667	.3439	.2294	.3734	.4887
8	.213	.3921	.2477	.3258	.1638	.4854	.7059
9	.2096	.1905	.1802	.3439	.2534	.1966	.6344
10	.1326	.1341	.1638	.3439	.3801	.2294	.1629
11	.1326	.1341	.1475	.3856	.4887	.2458	.2172
12	.1509	.1219		.4207	.4525	.2622	.1629
13	.1341	.0914		.4458	.543	.2949	.0724
14	.1174	.0949	.1638	.2279	.4525	.2785	.2195
15	.0857	.0949	.1802	.2454	.3801	.2785	.1267
16	.12	.1235	.1638	.2804	.4887	.213	.1629
17	.2172	.108	.362	.2458	.4207	.2896	.1475
18	.2534		.1991	.1638	.2534	.2172	.1311
19	.3734	.1905	.2715	.1638	.3142	.2534	.1475
20	.3547	.2096	.2896	.1638	.3921	.2353	.1966
21	.3109	.1905	.2353	.1475	.3142	.2534	.1966
22	.3077	.1715	.2353	.1311	.2896	.1991	.1638
23	.2715	.1715	.2353	.1311	.2715	.2353	.1638
24	.1475	.2715	.1715	.181	.1147	.2534	.181
Max	.3734	.4294	.362	.4458	.543	.4854	.7059
Min	.0857	.0914	.1475	.1311	.1147	.1966	.0724
Avg	.1977	.2122	.2125	.2611	.2969	.2691	.2340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 203 / Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.7133	.6468	.7133	.7316	.7316	.7316
2	.7133	.7133	.6401	.7133	.7316	.7316	.7316
3	.7316	.7682	.6838	.7133	.7316	.7682	.7316
4	.823	.8501	.8215	.9145	.823	.8413	.9145
5	.9145	.9522	.9896	1.0974	.9145	.9795	1.0974
6	1.0974	1.3957	1.3203	1.4266	1.3535	1.3957	1.3535
7	1.3717	1.2883	1.3014	1.262	1.262	1.3014	1.2986
8	1.1888	1.1389	1.094	1.1706	.9328	1.2136	1.1706
9	.9619	.9431	.8596	.924	.695	.9694	.9145
10	.7095	.7095	.6401	.6697	.6401	.823	.7059
11	.5601	.5975	.4938	.5792	.5487	.823	.6219
12	.4656	.5175	.4572	.4656	.439		.5249
13	.4477	.4435	.4024		.4572		.567
14	.4119	.4251	.439	.4706	.4755	.5487	.4938
15	.5083	.462	.4755	.4706	.5121	.7133	.5487
16	.4854	.4805	.4938	.4887	.5121	.6767	.6036
17	.695	.4435	.6219	.6036	.567	.7499	.6219
18	.8316		.7133	.7316	.7316	.7682	.6401
19	1.0456	.9795	1.0425	1.0242	.8596	1.0242	.8962
20	1.0269	.9522	1.0059	.9511	1.1016	1.0242	1.1888
21	.8413	.8029	.8962	.9328	.9335	.9511	.9694
22	.7682	.7762	.8413	.8779	.8413	.8596	.8779
23	.7392	.7023	.7499	.823	.7682	.7865	.7865
24	.7316	.7133	.6468	.7133	.7316	.7316	.7316
Max	1.3717	1.3957	1.3203	1.4266	1.3535	1.3957	1.3535
Min	.4119	.4251	.4024	.4656	.439	.5487	.4938
Avg	.7826	.7725	.7615	.8146	.7623	.8824	.8218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044090 / 33 KV POKHRI S/S

Feeder No / Name : 204 / 11 KV Jatwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4784	.4825	.4887	.4938	.4706	.543
2	.4755	.4784	.4825	.4887	.4938	.4706	.543
3	.4755	.4733	.4825	.4887	.4938	.4706	.543
4	.4938	.4908	.4825	.4887	.5487	.4835	.543
5	.5487	.4908	.4825	.4887	.6036	.4835	.5973
6	.6036	.5658	.5719	.543	.6584	.5959	.7059
7	.7133	.583	.8221	.8688	1.0974	.9945	.7059
8	.6584	.583	.8399	.9774	1.2803	1.166	.6516
9	.5361	.5361	.823	.7888	1.086	1.0242	.6154
10	.5897	.7095	.6036	.5973	.5973	.6036	.6154
11	.5719	.554	.5487	.5973	.5973	.6036	.823
12	.5719	.5183	.5487	.5611	.543	.567	.9774
13	.5719	.5361	.5304	.543	.543	.5487	1.0631
14	.5719	.5004	.5304	.543	.543	.5487	1.086
15	.5719	.5361	.5304	.543	.543	.5487	.8688
16	.5249	.5183	.4938	.5249	.543	.5304	1.0317
17		.5004	.543	.5487	.543	.543	.9877
18	.5973		.543	.6036	.5611	.543	.5304
19	.7059	.6433	.8688	.6584	.6697	.6516	.6219
20	.5973	.6255	.6516	.6219	.6878	.5973	.6584
21	.5792	.5897	.5973	.6036	.5973	.5973	.6036
22	.5611	.554	.5973	.6036	.5611	.5973	.6036
23	.5611	.554	.5973	.5853	.5611	.5973	.5853
24	.3841	.4887	.5004	.4887	.4938	.4344	.5973
Max	.7133	.7095	.8688	.9774	1.2803	1.166	1.086
Min	.3841	.4733	.4825	.4887	.4938	.4344	.5304
Avg	.5626	.5438	.5898	.5935	.6392	.6113	.7126



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 201 / 11 Kv Sajapur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.9431	.7888	.8764	.9054	.9242	.1677
2	.7922	.9619	.8059	.8002	.9242	.9808	.1677
3	.8865	.9431	.823	.8383	.9431	1.0185	.1829
4	.8676	.9619	.8573	.8002	.9619	.9997	.1981
5	.9619	.9242	.8745	.7621	.9431	.9808	.1981
6	1.0374	.9808	.9088	.7811	.9808	.9619	.2286
7	1.094	.9808	.9088	.8002		1.0185	.2743
8	1.0751	.9997	.703	.8383		.9808	.3353
9	.9619	.9054	.7545	.7356	.547	.9431	.3506
10	.2353	.2591	.2667	.3018	.3077	.2439	.5525
11	.2534	.2286	.2667	.2263	.2896	.3048	.7049
12	.2534	.2134	.2667	.2075	.2715	.2591	.8002
13	.2353	.1981	.2477	.2452	.2534	.2439	.7621
14	.2172	.1829	.2286	.2452	.2534	.2743	.4954
15	.2172	.1677	.2667	.2452	.2896	.2439	
16	.2715	.1524	.2286	.3018	.3045	.2286	.4954
17	.2715	.1829	.2477	.2829	.2896	.2286	.6478
18	.7733	.7202	.4001	.4527	.7733	.6859	.8002
19	.9997	.9088	.5716	.9242	.9431	.8059	.8573
20	1.0374	.9945	.6097	1.0562	.9619	.9088	.7811
21	1.0562	.9431	.9717	1.0751	.9997	.8573	.7621
22	.9997	.8573	1.0288	1.0185	.9619	.8059	
23	.9242	.823	.9526	.9808	.9431	.3772	
24	.9054	.9242	.8059	.3086	.9431	.9431	.1829
Max	1.094	.9997	1.0288	1.0751	.9997	1.0185	.8573
Min	.2172	.1524	.2286	.2075	.2534	.2286	.1677
Avg	.7165	.6815	.6160	.6294	.6814	.6758	.4736

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 202 / 11kv Karodi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.415	.3258	.3429	.4527	.4715	.1067
2	.3206	.4904	.3429	.362		.5093	.1067
3	.3584	.4715	.3772	.381	.4715	.4904	.1219
4	.415	.5093	.4115	.4572	.415	.5281	.1372
5	.547	.5847	.4115	.4382	.415	.5658	.1677
6	.7167	.6602	.5658	.4954	.4527	.6224	.1981
7	.7922	.7545	.6344	.5716	.679	.679	.2286
8	.6602	.6413	.5144	.5906	.6602	.6413	.3048
9	.4904	.5093	.463	.5281	.4904	.5281	.3048
10	.128	.1524	.1905	.2263	.2012	.1372	.3429
11	.1629	.1372	.1905	.2263	.2012	.1829	.3239
12	.1463	.1372	.2667	.2075	.2195	.1981	.3048
13	.1463	.1219	.3048	.1886	.1991	.1981	.2667
14	.1463	.1219		.1886	.2012	.1829	.2286
15	.1463	.1372	.2667	.1886	.2378	.1372	.2477
16	.1646	.1372	.1524	.1698	.2561	.1372	.2286
17	.1829	.1524	.1334	.1886	.2743	.1372	.4001
18	.4904	.4287	.3429	.2075	.4904	.2743	.5144
19	.5658	.4458	.4954	.4527	.5658	.4458	.5716
20	.4715	.4458	.5716	.4904	.4904	.4801	.5658
21	.415	.4115	.4954	.4904	.3961	.4115	.4904
22	.3772	.3601	.4001	.4527	.3584	.3429	.4338
23	.3395	.3086	.381	.4527	.3584	.3429	.3961
24	.3395	.3772	.3258	.4001	.4715	.3961	.1067
Max	.7922	.7545	.6344	.5906	.679	.679	.5716
Min	.128	.1219	.1334	.1698	.1991	.1372	.1067
Avg	.3693	.3713	.3723	.3624	.3895	.3767	.2958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-I S/D[399] BU 2241

Substation No/ Name :- 044102 / KARODI

Feeder No / Name : 203 / 11 kv INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4508	.3429	.4954	.2263	.4382	.3429
2	.3772	.4382	.3258	.4763	.2452	.4557	.3258
3	.3772	.4733	.3086	.4001	.1132	.4031	.3429
4	.3584	.4557	.3086	.381	.2641	.4031	.3601
5	.3395	.4557	.3429	.3429	.3018	.4207	.3429
6	.3772	.4207	.3258	.362	.3206	.4031	.3429
7	.4715	.4075	.3086	.3239	.3206	.3856	.3258
8	.5281	.4607	.4458	.2858	.3961	.4801	.3772
9	.6036	.4607	.5487	.2829	.7356	.8048	.5658
10	.8048	.5316	.7621	.2641	.5487	1.0974	.6097
11	1.2793	.6001	.7811	.2641	.788	.6859	.5906
12	.8551	.7202	.7621	.2452	1.0774	.6344	.6097
13	.6706	.6516	.6859	.2452	.9831	.6001	.6097
14	.7045	.7716	.5716	.2263	.8848	1.166	.6478
15	.7712	.7202	.6478	.2263	.9724	.9088	.5906
16	.8453	.703	.7049	.3018	1.1305		.6097
17	.8951	.6173	.6097	.2263	1.0814	.583	.5716
18	.788	.5487	.6097	.2452	.7042	.4801	.5335
19	.6036	.5316	.5906	.2641	.5144	.4287	.5335
20	.5765	.4458	.6287	.2829	.4681	.3772	.4904
21	.5426	.4287	.5716	.2641	.4207	.3772	.415
22	.5144	.3601	.5335	.2641	.4207	.3772	.3584
23	.4973	.3429	.5144	.2641	.4252	.3772	.3772
24	.4904	.4854	.3258	.5144	.2263	.4207	.3772
Max	1.2793	.7716	.7811	.5144	1.1305	1.166	.6478
Min	.3395	.3429	.3086	.2263	.1132	.3772	.3258
Avg	.6119	.5201	.5232	.3104	.5654	.5525	.4688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 201 / 11 KV SUKHNA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1905	.2286	.2286	.0953
2		.1905	.1905	.1905	.2286	.2286	.0953
3		.1905	.7621	.1905	.2858	.2477	.1334
4		.2286	.2858	.2858	.381	.2667	.1524
5		.2858	.381	.2858	.5716	.3429	.1905
6		.4763	.4763	.4763	.4763	.4954	.1905
7		.4763	.4763	.381	.5716	.5716	.381
8		.4763	.4763	.2858	.4763	.4763	.381
9	.2858	.381	.381	.1905	.381	.381	.381
10	.2858	.2858	.381	.1905	.3048	.2286	.2858
11	.2858	.2858	.381	.2858	.3048	.3048	.2858
12	.2858	.2858	.381		.3048	.2858	.1905
13	.2858	.2858	.381	.2858	.2667	.2858	.1905
14	.2858	.381	.2858	.2286	.2858	.3048	.1905
15	.2858	.2858	.1905	.1905	.3048	.2477	.1905
16	.2858	.381	.2858	.1905	.2858	.2667	
17	.2858	.2858		.1905	.2858	.2858	.1905
18	.2858	.2858	.381	.1905	.1715	.1905	.1905
19	.2858	.381	.4763	.381	.4191	.381	.381
20	.381	.2858	.381	.381	.362	.2858	.2858
21	1.1431	.2858	.381	.381	.2858	.2858	.2858
22	.2858	.2858	.381	.381	.2667	.2858	.1905
23	.2286	.1905	.2858	.2858	.2477	.2286	.1905
24	.1905	.1905	.1905	.1905	.2286	.2477	.0953
Max	1.1431	.4763	.7621	.4763	.5716	.5716	.381
Min	.1905	.1905	.1905	.1905	.1715	.1905	.0953
Avg	.3358	.3032	.3645	.2709	.3302	.3064	.2236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 202 / 11 KV KHODEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1905	.1905	.1334	.1524	.2286
2		.1905	.1905	.1905	.1334	.1524	.2286
3		.1905	.1905	.1905	.1905	.1905	.2858
4		.1905	.1905	.1905	.2286	.2286	.2858
5		.2286	.1905	.1905	.381	.1905	.2858
6		.2858	.2286	.2858	.2286	.2096	.4763
7		.381	.381	.4763	.381	.2286	.5716
8		.381	.2858	.4763	.2858	.381	.4763
9	.2858	.381	.2858	.4763	.3048	.362	.4763
10	.381	.381	.381	.4763	.2286	.381	.2858
11	.381	.381	.2858	.2858	.1905	.2858	.2858
12	.2858	.381	.2858	.1905	.1715	.2477	.2858
13	.2858	.362	.2858	.2286	.2667	.2286	.2858
14	.2858	.381	.2858	.1905	.2667	.1905	.2858
15	.2858	.2858	.2858	.1905	.2667	.2096	.2858
16	.2858	.2858	.2858	.1905	.3048	.2858	
17	.2858	.381	.2858	.1905	.362	.381	.2858
18		.381	.381	.381	.4001	.381	.2858
19	.4763	.381	.4763	.381	.5716	.4763	.4763
20	.381	.381	.4763		.4191	.381	.4763
21	.381	.2858	.381	.2858	.362	.381	.381
22	.2858	.2858	.2858	.2858	.3429	.2858	.2858
23	.2858	.2858	.2858	.2858	.3048	.2858	.1905
24	.1905	.1905	.1905	.1905	.1334	.1524	.2286
Max	.4763	.381	.4763	.4763	.5716	.4763	.5716
Min	.1905	.1905	.1905	.1905	.1334	.1524	.1905
Avg	.3175	.3104	.2913	.2791	.2858	.2770	.3322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 203 / 11 KV MURADABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.7621	.5716	.7621	.724	.381
2		.7621	.7621	.5716	.7621	.7621	.381
3		.7621	.7621	.7621	.8573	.9145	.381
4		.9526	.8573	.9526	.9526	1.0288	.4763
5		1.0479	.8573	1.0479	1.1431	1.0098	.5716
6		1.1431		1.2384	1.1431	1.0098	.5716
7		.5716	1.1431	1.1431	1.1431	1.105	.5716
8		.7621	.9526	.9526	.9526	.9526	.5716
9		.7621	.5716	.7621	.743	.8764	.5716
10		.5716	.381	.381	.5335	.5144	.6668
11	.4763	.5716	.381	.4763	.5144	.4572	.5716
12	.5716	.5716	.381	.4763	.4191	.4191	.381
13	.5716	.4763	.4763	.381	.3429	.381	.381
14	.5716	.4763	.4763	.381	.381	.3239	.2858
15	.5716	.381	.4763	.381	.4191	.3429	.381
16	.4763	.4763	.4763	.4763	.381	.362	
17	.4763	.4763	.4763	.5716	.4572	.381	.4763
18	.9526	.5716	.7621	.7621	.5906	.5716	.5716
19	1.1431	.7621	1.1431	1.1431	1.1812	.9526	1.1431
20	1.1431	.9526	1.0479	1.1431	1.086	.9526	1.0479
21	.9526	.8573	.9526	.9526	.9526	.9526	.7621
22	.9526	.7621	.9526	.8573	.8573	.9526	.7621
23	.7621	.7621	.7621	.7621	.743	.7621	.5716
24		.7621	.7621	.7621	.7621	.724	.381
Max	1.1431	1.1431	1.1431	1.2384	1.1812	1.105	1.1431
Min	.4763	.381	.381	.381	.3429	.3239	.2858
Avg	.7401	.7065	.7207	.7462	.7533	.7264	.5591

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 204 / 11 KV RAJAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6668	.5716	.7621	.5716	.8573	1.5242
2		.5716	.5716	.9526	.5716	.8573	1.5242
3		.6668	.5716	1.1431	.7621	.9145	1.5242
4		.7621	.7621	1.1431	1.1431	.9907	1.9052
5		.8573	1.0479	1.3336	1.5242	1.2193	2.2862
6		.9526	1.3336	1.7147	1.5242	1.8099	3.0483
7		1.5242	1.5242	1.7147	1.5242	2.1338	
8		1.5242	1.5242	1.7147	1.5242	2.1719	3.0483
9		1.3336	1.1431		1.6766	1.848	2.6673
10		1.9052	1.5242			1.9243	1.4289
11	1.9052	1.5242	1.5242			1.5242	1.4289
12	1.8099	1.5242	1.5242	1.4289	1.4098	1.4289	1.5242
13	1.5242	1.3336	1.3336	1.2384			1.3336
14	1.3336	1.1431		1.2384	1.4289		1.1431
15	1.7147		1.4289	1.2384	1.4861	1.7337	1.1431
16	2.0005	1.7147	1.5242	1.5242	1.7337	1.7909	
17	2.4768	1.9052	2.0957	1.9052	2.0005	2.2862	1.3336
18	3.0483	2.2862	2.4768	2.2862	2.4006	2.2862	2.191
19	2.6673	2.6673	3.0483	2.8578	2.7816	2.6673	2.8578
20	2.2862	2.2862	2.3815	2.2862	2.4768	2.2862	2.572
21	2.0957	1.9052	2.0957	1.9052	2.2291	1.9052	2.2862
22	1.7147	1.7147	1.9052	1.9052	1.9624	1.7147	1.9052
23	1.5242	1.5242	1.5242	1.5242	1.6385	1.5242	1.7147
24	.7621	.6668	.5716	.7621	.5716	.8764	1.5242
Max	3.0483	2.6673	3.0483	2.8578	2.7816	2.6673	3.0483
Min	.7621	.5716	.5716	.7621	.5716	.8573	1.1431
Avg	1.9188	1.4330	1.4786	1.5514	1.5686	1.6705	1.9052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 205 / 11 KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2858	.2858	.381	.381	.4763	.7621
2		.2858	.2858	.381	.381	.4763	.7621
3		.2858	.2858	.5716	.381	.5335	.7621
4		.381	.381	.5716	.4763	.5716	.9526
5		.5716	.5716	.7621	.6668	.7621	1.2384
6		.7621	.8573	.9526	.9526	.9717	1.7147
7		.9526	.9526	1.3336	1.1431	1.2765	1.7147
8		1.0479	1.0479	1.2384	.9526	1.3146	1.5242
9	.9526	.9526	.8573	.9526	1.0669	1.105	1.5242
10	1.2384	.9526	.9526	.5716	1.105	1.0288	.9526
11	.9526	.7621		.5716	.6478	.724	.9526
12	.8573	.5716	.7621	.6668	.5144	.6859	.9526
13	.7621	.5716	.7621	.5716	.5716	.6478	.9526
14	.6668	.5716	.5716	.5716	.5716	.6287	.8573
15	.7621	.5716	.4763	.5716	.5906	.6287	.9526
16	.8573		.6668	.381	.6478	.724	
17	1.2384	.9526	.7621	.9526	.8764	.9526	.9526
18	1.5242	.9526	1.1431	1.1431	.9717	1.1431	1.0479
19	1.5242	1.5242	1.5242	1.5242	1.6004	1.5242	1.3336
20	1.1431	1.1431	1.4289	1.3336	1.467	1.3336	1.2384
21	.9526	.9526	1.1431	1.1431	1.086	1.1431	.9526
22	.9526	.7621	.9526	.9526	.8764	.9526	.9526
23	.7621	.7621	.7621	.7621	.724	.7621	.7621
24	.381	.2858	.2858	.381	.381	.4763	.7621
Max	1.5242	1.5242	1.5242	1.5242	1.6004	1.5242	1.7147
Min	.381	.2858	.2858	.381	.381	.4763	.7621
Avg	.9705	.7331	.7704	.8018	.7930	.8685	1.0686



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 206 / EHV THAPTI TANDA

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.1905	.2858	.381	.381	.381
2		.1143	.1905	.2858	.381	.4191	.381
3		.1143	.1905	.381	.381	.4572	.381
4		.1524	.1905	.381	.381	.4954	.381
5		.1905	.1905	.381	.381	.6478	.5335
6		.1524	.2858	.4763	.4763	.6859	.6668
7		.1905	.2858	.381	.5716	.5335	.5716
8		.1905	.2286	.381	.6668	.724	.5716
9	.2858	.1524	.1905	.381	.5716	.724	.5716
10	.2858	.1905	.1905	.2858	.5335	.5716	.4763
11	.2858	.1905	.1905	.2858	.381	.4572	.4763
12	.1905	.2286	.1905	.2858	.381	.381	
13	.1905	.1905	.1905	.381	.381	.381	.381
14	.1905	.1905	.1905	.381	.381	.3048	.381
15	.1905	.1905	.2858	.381	.381	.2667	.381
16	.1905	.1905	.381	.2858	.381	.4191	
17	.381	.2858	.381	.2858	.4572	.4763	.4763
18	.1905	.1905	.5716	.5716	.5335	1.2384	.5716
19	.1905	.1905	.5716	.5716	.8002	.7621	.7621
20	.1905	.2858	.4763	.5716	.7621	.7621	.6668
21	.1905	.2286	.4763	.4763	.5716	.6668	.5716
22	.1524	.1905	.4763	.4763	.5335	.5716	.5716
23	.1143	.1905	.381	.381	.4572	.5716	.4763
24	.1905	.1143	.1905	.2858	.381	.4191	.4763
Max	.381	.2858	.5716	.5716	.8002	1.2384	.7621
Min	.1143	.1143	.1905	.2858	.381	.2667	.381
Avg	.2131	.1842	.2953	.3850	.4795	.5549	.5049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044004 / 33KV ADUL

Feeder No / Name : 207 / ANTERWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5716	.5716	.5716	.5716	.5335	.381
2		.5716	.5716	.5716	.5716	.5335	.381
3		.5716	.5716	.7621	.6668	.5716	.381
4		.6668	.5716	.7621	.7621	.6478	.381
5		.8573	.5716	.9526	.9526	.8764	.381
6		1.1431	.5716	1.0479	1.0479	1.1431	.4763
7		.9526	.9526	.9526	1.0479	1.1812	.5716
8		.8573	.6668	.9526	.7621	.9717	.4763
9	.4763	.6668	.5716	.7621	.4954	.6097	.3239
10	.381	.2858	.2858	.381	.2667	.4572	.4763
11	.381	.381	.2858	.381	.3429	.4191	.4763
12	.381	.2858	.2858	.381		.4572	.381
13	.381	.2858	.2858	.381	.4954	.5335	.381
14	.381	.2858	.381	.381	.4954	.5144	.2858
15	.381	.2858	.381	.381	.4954	.4572	.381
16	.381	.381		.381	.4954	.4954	
17	.6668	.3429	.381	.2858	.5716	.4763	.4763
18	.8573	.4763	.5716	.7621	.6097	.7621	.6668
19	.6668	.7621	1.1431	.9526	1.086	.9526	1.1431
20	.6668	.6668	.9526	.8573	.9526	.8573	.7621
21	.6668	.6668	.9526	.7621	.743	.7621	.7621
22	.5716	.6668	.7621	.6668	.6478	.6668	.5716
23	.5716	.5716	.7621	.5716	.6287	.5716	.5716
24	.5716	.5716	.5716	.5716	.5716	.5716	.381
Max	.8573	1.1431	1.1431	1.0479	1.086	1.1812	1.1431
Min	.381	.2858	.2858	.2858	.2667	.4191	.2858
Avg	.5239	.5739	.5923	.6430	.6644	.6676	.4987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 201 / 11 KV KARMAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4024	.3353	.2743	.2743	.2683	.6413
2	.4359	.4359	.3018	.2743	.2743	.3018	.6413
3	.4359	.4694	.3018	.2743	.2743	.4024	.6413
4	.4694	.4359	.3018	.2743	.4115	.4694	.679
5	.4694	.4694	.3018	.3429	.5365	.5365	.7922
6	.503	.503	.503	.3688	.5868	.5868	.9054
7	.503	.5365	.57	.5365	.5868	.6371	1.0185
8	.5197	.503	.5868	.57	.6036	.6706	.9431
9	.5868	.4694	.5868	.503	.6539	.5533	.8299
10	.7356	.6602	.6602	.7356	.679	.679	.5868
11	.6224	.6036	.7167	.6036	.6036	.6413	.6203
12	.7356	.5316	.7167	.6602	.6036	.6224	.5868
13	.7167	.6602	.6602	.4904	.4904	.6413	.6036
14	.6224	.7356	.7356	.0377	.5658	.6036	.5197
15	.547	.6602	.5847	.6036	.6036		.5533
16	.5847	.6602	.6036	.7356	.6413	.6036	.57
17	.5847	.5847	.5658	.7356	.6224	.6413	.5365
18	.7356	.6602	.7167	.8488	.6224	.679	.7545
19	.811	.8299	.8299	.9431	.8865	.9054	.8676
20	.8676	.7545	.8676	.9431	1.094	.9054	.9054
21	.7922	.7545	.8299	.9054	.9808	.8299	.8299
22	.7167	.7545	.7545	.7545	.9242	.7545	.7545
23	.6602	.7545	.6413	.7545	.811	.679	.679
24	.3688	.3688	.3353	.2743	.2743	.2347	.6413
Max	.8676	.8299	.8676	.9431	1.094	.9054	1.0185
Min	.3688	.3688	.3018	.0377	.2743	.2347	.5197
Avg	.6011	.5916	.5837	.5602	.6085	.6020	.7126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 202 / 11 KV GADHE JALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.0374	1.0374	1.0185	1.0185	1.1317	.503
2	1.0374	1.094	1.0374	1.0562	1.0185	1.1694	.503
3	1.094	1.0374	1.1317	1.1317	1.0185	1.2826	.503
4	1.1694	1.1694	.8865	1.2826	1.226	1.2826	.5365
5	1.166	1.2826	1.5655	1.7353	1.6409	1.358	.7377
6	1.3957	1.4146	1.7918	1.9993	1.6975	1.4335	.9389
7	1.5466	1.6221	2.0559	1.8861	1.8296	1.6409	1.2071
8	1.6032	1.9239	1.6975	1.6221	1.5089	1.6787	1.3413
9	1.4146	1.6032	1.4146		1.3203	1.3203	1.1736
10	.5197	.5144	.5868		.8718	1.2071	1.1128
11	.5365	.7373	.7545	.4862	1.0395	1.2407	.7922
12	.5868	.6001	.8383	.5197	1.1401	1.2239	.7356
13	.6706	.5868	.8048	.4359	1.073		.7545
14	.5533	.5533	.7712	.8215	1.0059	1.1736	
15	.5868	.583	.7545	1.0898	.9389	1.2071	.6602
16	.503	.6001	.7545	1.0562	1.0059	1.1736	.8299
17	.6036	.6001	.7377	.9892	.9054	.9389	1.0374
18	1.226	.9431	1.0562	1.226	1.0185	1.1694	1.226
19	1.4146	1.2637	1.5466	1.4146	1.3957	1.6221	1.4146
20	1.4712	1.3203	1.4335	1.3769	1.5089	1.4335	1.4335
21	1.2826	1.226	1.3203	1.3203	1.358	1.2826	1.2826
22	1.0562	1.1317	1.1694	1.3203	1.2071	1.1317	1.1317
23	1.0374	1.0374	1.0562	1.226	1.1128	1.0562	1.0562
24	.9997	1.0374	1.0374	1.0185	1.0185	1.0374	.3353
Max	1.6032	1.9239	2.0559	1.9993	1.8296	1.6787	1.4335
Min	.503	.5144	.5868	.4359	.8718	.9389	.3353
Avg	1.0213	1.0383	1.1350	1.1833	1.2033	1.2694	.9238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 203 / 11 KV SHEKTA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8488	.9431	.8488	.9431	.9431	.8488	.8718
2	.8488	.8488	.8488	.9431	.9431	.8488	.8718
3	1.094	.9431	1.0374	.9431	.9431	.9808	.8718
4	1.094	1.0374	.9431	.9808	1.0374	1.094	.9054
5	1.1694	1.094	1.1317	1.2071	1.1694	1.2826	1.073
6	1.2826	1.2826	1.5089	1.6221	1.5089	1.4901	1.2407
7	1.2826	1.4146	1.7353	1.6598	1.7353	1.6032	1.7772
8	1.358	1.4335	1.3203	1.4712	1.5089	1.4335	2.1795
9	1.0562	1.1317	.6036	1.2826	1.3203	1.0374	2.079
10	.7545	.7716	1.0898	1.3748			.811
11	.8718	.9945	1.2574	1.5927	1.6766	2.0119	.7545
12	.9724	.8745	1.0898	1.643	1.9448	2.0622	.8488
13	1.0059	.7545	1.3413	1.3748	2.0454	2.0119	.7733
14	.8048	.7042	1.3077	1.5592	1.9784	1.9281	.7922
15	.5365	.7202	.2347	1.6095	1.8778	2.0119	.7167
16	.811	.7545		1.643	1.9113	1.9281	.7167
17	.8488	.8383	1.4419	1.5424	1.6766	1.9784	.8488
18	.9619		1.0562	1.5089	1.0374	1.0562	1.0374
19	1.3014	1.0374	1.5089	1.358	1.4712	1.4712	1.2071
20	1.226	.9808	1.358	1.3203	1.5089	1.358	1.358
21	1.1694	.9431	1.2071	1.2071	1.4335	1.2449	1.2449
22	1.226	.9431	1.1317	1.0562	1.226	1.1694	1.1694
23	1.0374	.8488	1.0562	.9431	1.1694	1.094	1.094
24	.811	.8488	.8488	.9431	.9431	.7922	.5365
Max	1.358	1.4335	1.7353	1.6598	2.0454	2.0622	2.1795
Min	.5365	.7042	.2347	.9431	.9431	.7922	.5365
Avg	1.0156	.9627	1.1264	1.3220	1.4352	1.4234	1.0741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 204 / 11KV DUDHAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2012	.1715	.1886	.1928	.2012	.5658
2	.2347	.2347	.1715	.2058	.1928	.2683	.5658
3	.2347	.2012	.2058	.2058	.1928	.3018	.6036
4	.2683	.2347	.2058	.2229	.2401	.3018	.6224
5	.2683	.2683	.2229	.2229	.2915	.3353	.7545
6	.3018	.3018	.3086	.285	.3086	.4024	.9054
7	.3018	.2683	.3353	.285	.3601	.3185	.9431
8	.3353	.3185	.3353	.3353	.3429	.3521	.8299
9	.285	.3353	.285	.2683	.3258	.3353	.679
10	.6413	.6413	.6036	.6413	.679	.679	.2683
11	.5658	.6036	.547	.5316	.6036	.6413	.2683
12	.5093	.4801	.5281	.5658	.5658	.6036	.285
13	.4715	.4904	.5093	.547	.5658	.6413	.2347
14	.4715	.4715	.547	.4904	.5658	.6036	
15	.4715	.4527	.4904	.5281	.6036	.6413	.3185
16	.415	.4715	.5093	.4904	.5658	.5658	.285
17	.415	.547	.5281	.547	.5658	.5281	.3018
18	.6224	.5658	.5658	.6602	.5847	.5658	.6036
19	.811	.6602	.7545	.7167	.7167	.7922	.7733
20	.7733	.7356	.7922	.8488	.7922	.7545	.7545
21	.7356	.6979	.7545	.811	.7545	.7545	.7545
22	.5658	.6413	.7545	.7356	.7356	.7167	.7167
23	.4338	.5658	.6413	.6602	.6602	.679	.679
24	.2012	.2012	.1715	.1886	.1928	.2012	.6036
Max	.811	.7356	.7922	.8488	.7922	.7922	.9431
Min	.2012	.2012	.1715	.1886	.1928	.2012	.2347
Avg	.4390	.4412	.4558	.4659	.4833	.5077	.5790

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 205 / 11 KV GOLATGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.4694	.503	.583	.5335	.6371	1.1694
2	.503	.503	.503	.583	.6001	.6371	1.2071
3	.5868	.5868	.5868	.583	.6001	.7042	1.3203
4	.5868	.5868	.5868	.583	.6371	.8048	1.4335
5	.6371	.6371	.2012	.7545	.6874	.9724	1.773
6	.7042	.7545	.503	.7377	.9221	1.2742	2.0748
7	.7545	.9221	.5868	1.2071	1.1401	1.3413	2.0748
8	.8048	1.0898	.6706	1.3748	1.2574	1.4754	1.6975
9	.7712	.9221	.788	1.3413	1.2574	1.3077	1.3203
10	1.1317	.9619	.6224	.8488	1.0185	.7167	1.1401
11	.7356	.7167	.6036	.6036	.7167	.679	1.3413
12		.6602	.4904	.5093	.6413	.7167	1.5592
13		.7167	.6413	.4904	.6413	.679	1.3748
14	.6413	.7167	.7545	.547	.7167	.7167	1.2071
15	.6602	.6979	.7167	.6224	.7545	.679	1.2071
16	.7167	.6602	.7922	.7545	.7545	.7167	1.2239
17	.7167	.7922	.9054	.9242	.8488	.8676	1.2574
18	.811		1.094	1.4146	1.094	1.0562	1.3769
19	1.6032	1.4335	1.4712	1.6221	1.7918	1.773	1.3957
20	1.6598	1.5089	1.6221	1.6975	1.9239	1.6975	1.6975
21	1.4712	1.4335	1.3203	1.5089	1.8484	1.4335	1.4335
22	1.2826	1.3203	1.3203	1.3769	1.358	1.3957	1.3957
23	1.1694	1.226	1.0562	1.3203	1.2826	1.3203	1.3203
24	.4359	.4359	.503	.583	.6001	.5365	1.1694
Max	1.6598	1.5089	1.6221	1.6975	1.9239	1.773	2.0748
Min	.4359	.4359	.2012	.4904	.5335	.5365	1.1401
Avg	.8570	.8588	.7851	.9405	.9844	1.0058	1.4238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044013 / 33KV GADEJALGAON SUB STATION

Feeder No / Name : 206 / 11 Kv Mirza industrial SHEDDABLE FEEDER HAVING WEEKLY  
Feeder Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377		.0377	.0377	.0377	.0377	.0377
2	.0377	.0377	.0377	.0377	.0377	.0377	.0377
3	.0377	.0377	.0377	.0377	.0377	.0377	.0377
4	.0377	.0377	.0377	.0377	.0377	.0377	.0377
5	.0377	.0377	.0377	.0377	.0377	.0377	.0377
6	.0377	.0377	.0377	.0377	.0377	.0377	.0377
7	.0377	.0377	.0377	.0377	.0377	.0377	.0377
8	.0377	.0377	.0377	.0377	.0377	.0377	.0377
9	.0377	.0377	.0377	.0377	.0377	.0377	.0377
10	.0377	.0377	.0377	.0377	.0377	.0377	.0377
11	.0377	.0377	.0377	.0377	.0377		.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0335		.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0335
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0377	.0377	.0377	.0377	.0377	.0377
21	.0377	.0377	.0377	.0377	.0377	.0377	.0377
22	.0377	.0377	.0377	.0377	.0377	.0377	.0377
23	.0377	.0377	.0377	.0377	.0377	.0377	.0377
24	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Max	.0377	.0377	.0377	.0377	.0377	.0377	.0377
Min	.0335	.0377	.0377	.0377	.0377	.0377	.0335
Avg	.0375	.0377	.0377	.0377	.0377	.0377	.0375



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 201 / 11 KV SHENDRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.0514	.0463	.5144	.6001	.1029
2	.5144	.5144	.0514	.0463	.5144	.6001	.1029
3	.6001	.5144	.0514	.0463	.5144	.6001	.1115
4	.6001	.583	.06	.0583	.583	.7716	.1372
5	.6859	.7202	.0686	.072	.7545	.8573	.1715
6	.7716	.7545	.072	.0857	.8916	.8573	.1886
7	.8573	.9259	.0892	.1097	1.1317	.8916	.1886
8	.8573	.9602	.0909	1.0288	1.3032	1.286	1.6632
9	.0772	.0857	.8916	.9431	.12	.9259	1.3717
10	.108	.1132	.9945	.7716	.1235	.9259	.8573
11	.0943	1.0974	.8573	.7716	.1115	.9945	.9431
12	.0857	.9259	.6859	.7716	.0857	.9945	1.0631
13	.0754	.823	.7888	.5144	.0857	.823	1.0288
14	.0754	.7888	.6859	.5144	.0857	.7888	.9431
15	.0686	.7888	.6859	.5144	.0857	.7888	.9945
16	.0772	1.0288		.8573	.0943	.8573	1.0288
17	1.2689	.7888	.9945	.9945	.9431	.0892	1.0631
18	1.2689	.0943	1.166	1.0974		.1029	1.0974
19	1.5432	.1372	1.4746	1.5432	1.5432	.1475	1.5432
20	1.3717	.1629	.1629	1.5432	1.5432	.1629	1.5432
21	1.3375	.1543	.1423	1.5089	1.5432	.1252	1.4746
22	1.2003	.12	.1372	1.2003	1.3717	.12	1.2689
23	1.0974	.1115	.12	1.1317	1.2003	.1115	1.1317
24	.5144	.4458	.0514	.0463	.5144	.5144	.1029
Max	1.5432	1.0974	1.4746	1.5432	1.5432	1.286	1.6632
Min	.0686	.0857	.0514	.0463	.0857	.0892	.1029
Avg	.6527	.5481	.4510	.6757	.6808	.6224	.8384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 202 / 11 KV MAHALPIMPRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3429	.0412	.0343	.3772	.4287	.0857
2	.5144	.3429	.0412	.0343	.3772	.4287	.0857
3	.5144	.3429	.0421	.0343	.3772	.5144	.0857
4	.6001	.4115	.0514	.0429	.5144	.6859	.1029
5	.8573	.5144	.06	.06	.6516	.8573	.1372
6	1.0288	.6173	.0772	.0686	.823	.9259	.1715
7	1.0288	.6859	.0857	.0857	.8573	1.1145	.1509
8	.9945	.8573	.0857	.9431	1.2346	1.4575	1.2517
9	.0686	.0772	.7202	.9431	.1029	1.2689	1.0288
10	.0514	.0772	.6859	.6859	.0686	.9259	1.0288
11	.0514	.7888	.5487	.5144	.0686	.7545	1.2003
12	.0514	.5487	.4115	.4287	.06	.6173	1.2003
13	.0343	.5487	.4115	.4287	.0514	.5144	1.1488
14	.0429	.5144	.4115	.5487	.0514	.583	1.0631
15	.0514	.5144	.4115	.5487	.0514	.5487	.3429
16	.06	.5144	.4115	.5144	.06	.6173	.3429
17	.7888	.0686	.4801	.6859	.6001	.0686	.9602
18	.6859	.0086	.6173	.6859	.7716	.0772	.0686
19	1.3032	.12	.9259	1.0974	1.1145	.12	.1715
20	1.2003	.1372	.1372	1.2003	1.2003	.1372	1.4746
21	1.0288	.12	.0943	1.166	1.2003	.1115	1.3375
22	1.0288	.0943	.0857	1.0288	1.0802	.1029	1.166
23	.9259	.0857	.0789	.9259	1.0288	.0857	1.0288
24	.5144	.3429	.0412	.0343	.3772	.4287	.0857
Max	1.3032	.8573	.9259	1.2003	1.2346	1.4575	1.4746
Min	.0343	.0086	.0412	.0343	.0514	.0686	.0686
Avg	.5808	.3615	.2899	.5308	.5458	.5573	.6550

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 203 / 11 KV BHALGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.0514	.0566	.6173	.6516	.1372
2	.5144	.5144	.0514	.0566	.6173	.6859	.1372
3	.5144	.5144	.0514	.0566	.6173	.6859	.1543
4	.6001	.6859	.0686	.0686	.6859	.8573	.1886
5	.6859	.8573	.0772	.0789	.8573	1.0288	.2143
6	.7888	1.0288	.0857	.0943	1.0974	1.2517	.2572
7	.7716	1.0288	.0943	.1166	1.3717	1.286	.2486
8	.9431	1.0631	.0943	1.0288	1.4403	1.6289	2.2291
9	.0943	.0943	.823	1.0288	.1372	1.406	1.8861
10	.1543	.1372	1.2003	1.0288	.1372	1.2689	1.1145
11	.1286	1.2003	1.0974	1.0288	.1286	1.0974	1.1145
12	.1029	1.2346	1.0631	.8573	.1029	1.0974	1.1145
13	.0857	1.0974	.9945	.7202	.0857	.9945	1.0631
14	.0857	1.0288	.9259	.8573	.0857	.9945	1.0288
15	.1029	.9602	.9259	.9431	.0943	.9602	1.2003
16	.1029	1.0288	1.0288	1.0288	.1029	1.0288	1.2003
17	1.2689	1.1317	1.0974	1.0288	1.0288	.12	1.5089
18	1.6118	.12	1.3717	1.3032	1.3375	.1286	1.3375
19	2.1605	.1629	2.0233	2.0233	2.0576	.1715	2.0576
20	1.8861	.1886	.1972	1.8861	1.8861	.1886	2.1262
21	1.6804	.18	.1715	1.8519	1.8861	.1578	1.8861
22	1.5432	.1543	.1543	1.7147	1.7147	.1457	1.7147
23	1.4746	.1457	.1509	1.5432	1.5432	.1457	1.5432
24	1.0288	.4801	.0514	.0566	.6173	.6344	.1372
Max	2.1605	1.2346	2.0233	2.0233	2.0576	1.6289	2.2291
Min	.0857	.0943	.0514	.0566	.0857	.12	.1372
Avg	.7852	.648	.5771	.8524	.8438	.7757	1.0667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 205 / 11KV Om Gajanan Industrial SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0343	.0051	.0051	.0514	.0514	.0051
2	.0514	.0343	.0051	.0051	.0514	.0514	.0051
3	.0514	.0343	.0051	.0051	.0514	.0514	.0051
4	.0514	.0343	.0051	.0051	.0514	.0514	.0051
5	.0514	.0343	.0051	.0051	.0514	.0514	.0051
6	.0514	.0343	.0051	.0069	.0514	.0514	.0069
7	.0514	.0343	.0051	.0069	.0514	.0514	.0051
8	.0686	.0514	.0069	.1029	.0514	.0514	.0514
9	.0069	.0137	.1029	.12	.0086	.0686	.0686
10	.012	.0223	.1029	.1543		.0857	.1029
11	.012	.1372	.1372	.1543	.0137	.1029	.1372
12	.012	.1372	.2401	.1543	.0137	.1372	.1543
13	.012	.1372	.1372	.1543	.0171	.12	.1715
14	.012	.1372	.1372	.1715	.0137	.1372	.1715
15	.0171	.1029	.1372	.1715	.0137	.12	.1715
16	.012	.1372	.1715	.1715	.0137	.1543	.1715
17	.1372	.1715	.1715	.1715	.1372	.012	.1715
18	.1029	.0154	.1372	.1029	.0686	.012	.1029
19	.0857	.0051	.1029	.0857	.0686	.0086	.0686
20	.0686	.0069	.0103	.0686	.0686	.0086	.0686
21	.0686	.0103	.0103	.0686	.0686	.0086	.0857
22	.0686	.0086	.0086	.0686	.0686	.0086	.0857
23	.0514	.0069	.0086	.0686	.0686	.0069	.0686
24	.0514	.0343	.0051	.0086	.0686	.0514	.0051
Max	.1372	.1715	.2401	.1715	.1372	.1543	.1715
Min	.0069	.0051	.0051	.0051	.0086	.0069	.0051
Avg	.0483	.0573	.0693	.0849	.0488	.0606	.0789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044037 / 33/11 KV SUNDARWADI S/S

Feeder No / Name : 206 / 11 Kv R. K. Feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0034	.0034	.0343	.0343	.0034
2	.0343	.0343	.0034	.0034	.0343	.0343	.0034
3	.0343	.0343	.0034	.0034	.0343	.0343	.0034
4	.0343	.0343	.0034	.0034	.0343	.0343	.0034
5	.0343	.0343	.0034	.0034	.0343	.0343	.0034
6	.0343	.0343	.0034	.0034	.0343	.0343	.0034
7	.0343	.0343	.0034	.0034	.0343	.0343	.0034
8	.0343	.0343	.0034	.0343	.0514	.0343	.0343
9	.0069	.0051	.0514	.0514	.0034	.0343	.0514
10	.0051	.0051	.0857	.0514	.0034	.0686	.0514
11	.0051	.0686	.0857	.0514	.0034	.0686	.0686
12	.0051	.0514	.1029	.0514	.0034	.0514	.0686
13	.0086	.0343	.0514	.0514	.0034	.0514	.0686
14	.0086	.0343	.0514	.0514	.0034	.0343	.0514
15	.0051	.0343	.0514	.0514	.0034	.0343	.0686
16	.0051	.0343		.0514	.0034	.0343	.0686
17	.0343	.0343	.0343	.0343	.0343	.0034	.0343
18	.0343	.0034	.0343	.0343	.0343	.0034	.0343
19	.0343	.0034	.0343	.0343	.0343	.0034	.0343
20	.0343	.0034	.0034	.0343	.0343	.0034	.0343
21	.0343	.0034	.0034	.0343	.0343	.0034	.0343
22	.0343	.0034	.0034	.0343	.0343	.0034	.0343
23	.0343	.0034	.0034	.0343	.0343	.0034	
24	.0343	.0343	.0034	.0034	.0343	.0343	.0034
Max	.0343	.0686	.1029	.0514	.0514	.0686	.0686
Min	.0051	.0034	.0034	.0034	.0034	.0034	.0034
Avg	.0249	.0263	.0273	.0297	.0247	.0296	.0332

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 201 / 11KV HARMAN

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4098	1.2955	1.1241	1.0669	1.2003	1.0669	.8002
2	1.3146	1.2574	1.1431	1.0669	1.1431	1.1431	.8002
3	1.2574	1.2384	1.105	1.0288	1.105	1.0669	.7811
4	1.1812	1.2384	1.0669	1.0288	1.0479	1.0479	.7811
5	1.105	1.2193	1.0669	.9907	1.0098	.9526	.7811
6	1.0479	1.2003	1.105	.9907	1.0098	.9907	.7621
7	1.3527	1.1431	1.105	1.0669	1.3336	.9526	.9145
8	1.6004	1.105	1.5623	1.2955	1.5813	1.1431	1.6004
9	1.7147	1.1431	1.7147	1.3717	1.5242	1.2955	1.5623
10	1.7147	1.1431	1.829	1.6194	1.5242	1.3146	1.6194
11	1.6194	1.448	1.7528	1.6194	1.448	1.2574	1.6385
12	1.5623	1.4098	1.6766	1.6385	1.448	1.1622	1.6766
13	1.6004	1.2955	1.6004	1.6766	1.448	1.0288	1.6385
14	2.0005	1.3717	1.4861	1.6766	1.3336	1.0288	1.6194
15	1.8099	1.5242	1.8671	1.7147	1.6385	1.0669	1.6194
16	1.8099	1.2574	1.7909	.9526	1.6004	1.0288	1.5242
17	1.848	1.1431	1.7147	1.3146	1.7147	1.0288	1.7337
18	1.7147	1.1812	1.6194	1.3336	1.8099	.9145	1.467
19	1.5432	1.1812	1.5242	1.3336	1.5242	.9526	1.4289
20	1.448	1.1431	1.1812	1.4098	1.3336	.9907	1.4861
21	1.4289	1.1431	1.2955	1.5051	1.3336	.9526	1.5432
22	1.3908	1.1812	1.448	1.3336	1.2574	.8764	1.3336
23	1.3717	1.1431	1.448	1.2955	1.1431	.8383	1.2955
24	1.467	1.3336	1.0479	1.2955	1.2384	1.0669	.8002
Max	2.0005	1.5242	1.8671	1.7147	1.8099	1.3146	1.7337
Min	1.0479	1.105	1.0479	.9526	1.0098	.8383	.7621
Avg	1.5130	1.2392	1.4281	1.3178	1.3646	1.0487	1.3003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 202 / 11KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.743	.6478	.5335	.8002	.8383
2	.8764	.8573	.6859	.6478	.5144	.8002	.8383
3	.8573	.8002	.6859	.6478	.4763	.7621	.8192
4	.8192	.7621	.6859	.6097	.4763	.8002	.8192
5	.7811	.743	.7049	.6097	.4954	.7621	.8192
6	.7621	.743	.6859	.6097	.4954	.7621	.8002
7	.8002	.7621	.6668	.6478	.6097	.7621	.8383
8	.8383	.8002	.8383	.6478	.6859	.9145	.724
9	1.2384	.8954	.9145	.743	1.0479	.9145	.9907
10	1.3717	.9145	.9907	.8002	1.0669	1.0669	1.1431
11	1.3717	.9907	1.0288	.8002	1.1431	1.1812	1.2955
12	1.4098	1.0288	1.0288	.7621	1.2193	1.0669	1.3336
13	1.3717	.9526	.9907	.7621	1.2193	.9335	1.3336
14	1.4098	1.0288	.9335	.8002	1.2193	.9907	1.2384
15	1.3146	.9145	1.105	.7621	1.2193	1.0669	1.2384
16	1.3336	.7621	1.0288	.5716	1.2193	.9907	1.3336
17	1.086	.8192	.9907	.6287	1.1431	1.0669	1.2574
18	1.0288	.8002	.724	.6097	.9907	.9145	1.2384
19	.9526	.6859	.6859	.5906	.8764	.8954	1.0288
20	.9335	.6859	.7621	.6097	.8573	.8764	1.0669
21	.9717	.6859	.6478	.6097	.8764	.9145	1.105
22	1.0098	.743	.6859	.5906	.8764	.9526	1.105
23	.9907	.8002	.724	.5716	.9526	.9907	1.0669
24	.9335	.9526	.8002	.6859	.5716	.8002	.8383
Max	1.4098	1.0288	1.105	.8002	1.2193	1.1812	1.3336
Min	.7621	.6859	.6478	.5716	.4763	.7621	.724
Avg	1.0574	.8351	.8224	.6653	.8661	.9161	1.0463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 203 / 11KV KUMBHEPHAL

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3361	.3734	.415	.3921	.3734	.4715
2	.3361	.3361	.3734	.4527	.3734	.381	.4715
3	.3547	.3547	.3734	.4527	.4108	.3734	.5093
4	.3921	.4108	.3734	.4527	.4668	.4108	.5281
5	.4481	.4854	.4108	.4904	.5415	.4854	.5281
6	.5041	.6161	.4854	.6413	.5788	.5975	.7167
7	.4854	.5788	.5601	.6413	.5975	.6348	.7167
8	.4481	.5041	.4481	.5658	.5975	.4854	.6036
9	.3734	.4572	.4481	.4854	.6478	.5415	.5601
10	.3361	.4572	.4481	.4481	.6478	.5228	.5228
11	.3547	.4954	.4294	.4108	.5716	.5228	.5544
12	.3547	.415	.4294		.5716	.5041	.5601
13	.3734	.4191	.3921		.5335	.4668	
14	.3547	.4001	.3361		.4572	.4481	.5487
15	.3734	.4191	.3547		.4954	.4294	.5121
16	.3734	.381	.3734	.4481	.4572	.4108	.5228
17	.4668	.2801	.4954	.5975	.4481	.4191	.5415
18	.4108	.3734	.5335	.5788	.5041	.4904	.5228
19	.3547	.4108	.5716	.5601	.5041	.5658	.5228
20	.4481	.4108	.5716	.5228	.4481	.6036	.5041
21	.4294	.4108	.5335	.5228	.4668	.5335	.4668
22	.4108	.3734	.4527	.4854	.4481	.4904	.4294
23	.3921	.3547	.4527	.4481	.3921	.4904	.4294
24	.3547	.3734	.3734	.415	.4108	.3734	.4715
Max	.5041	.6161	.5716	.6413	.6478	.6348	.7167
Min	.3361	.2801	.3361	.4108	.3734	.3734	.4294
Avg	.3952	.4189	.4414	.5017	.4984	.4814	.5311



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 204 / 11KV BALIRAJA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.0098	1.1431	1.086	1.1431	1.0669	1.0288
2	.9717	.9526	1.1812	1.086	1.086	.9907	1.0288
3	.9145	.9145	1.1431	1.086	1.0098	.9907	.9907
4	.8764	.8954	1.1431	1.0669	.9145	.9526	.9907
5	.8383	.8192	1.1812	1.0669	.8002	.8573	.9526
6	.8192	.7621	1.1431	1.0669	.6859	.8573	.8764
7	.9145	.8764	1.1431	1.1431	.7811	.8002	.7621
8	1.105	.9526	1.2384	.9526	.9145	1.105	.9907
9	1.7147	1.2955	1.448	1.1812	1.4861	1.3908	1.5623
10	1.7718	1.3336	1.6575	1.1812	1.5242	1.4289	1.7147
11	2.0005	1.448	1.6766	1.2193	1.4098	1.448	1.9052
12	2.0195	1.448	1.6194	1.2384	1.2574	1.5242	1.9433
13	2.0957	1.2955	1.6194	1.2384	1.2574	1.6194	1.9814
14	1.7147	1.3717	1.6004	1.2574	1.7528	1.7147	1.9814
15	2.0576	1.7147	1.9433	1.2384	2.21	1.8099	2.0195
16	1.8099	.9907	1.848	.7621	2.21	1.829	2.0005
17	1.5242	1.1431	1.5242	.8002	1.9052	1.5051	1.7718
18	1.4098	1.1431	1.3336	.743	1.467	1.2955	1.3717
19	1.2193	1.0479	1.2955	.6668	1.1431	1.2955	1.3336
20	1.2384	1.0479	1.3336	.8002	1.1431	1.2955	1.3336
21	1.1812	1.0669	1.448	.9335	1.2384	1.2193	1.3146
22	1.105	1.0669	1.5242	1.2574	1.467	1.4098	1.2955
23	1.0669	1.1431	1.6004	1.2384	1.5623	1.4098	1.2574
24	1.0479	1.0479	1.1431	1.6004	1.2003	1.0669	1.0669
Max	2.0957	1.7147	1.9433	1.6004	2.21	1.829	2.0195
Min	.8192	.7621	1.1431	.6668	.6859	.8002	.7621
Avg	1.3511	1.1161	1.4138	1.0796	1.3154	1.2868	1.3948

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 205 / 11KV VAISHNAVI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5228	.5658	.4715	.2957	.5658	.6224
2	.499	.5228	.5093	.4715	.2957	.5658	.6224
3	.5359	.5415	.5093	.4715	.3142	.547	.6036
4	.5601	.5415	.5093	.4527	.3326	.547	.6036
5	.5975	.5601	.5093	.4527	.3511	.5658	.6036
6	.6161	.5975	.5281	.4527	.3734	.5658	.6036
7	.5975	.5788	.5281	.3961	.4108	.6224	.5658
8	.5975	.5601	.6224	.3395	.4668	.6224	.5658
9	.7922	.8573	.7167	.3772	.8573	.679	.6602
10	.7922	.8764	.7733	.4527	.8764	.6979	.7468
11	.7922	.7621	.8002	.4715	.8764	.7356	.7842
12	.7922	.6036	.8002	.5658	.8764	.811	.7842
13	.811	.8002	.7545	.5658	.9145	.8764	.9431
14	.7356	.8002	.679	.5658	.8764	.7545	.9431
15	.9054	.6478	.811	.5658	.8383	.6224	.9054
16	.7922	.7621	.7167	.3395	.7621	.679	.9526
17	.7545	.679	.7811	.4527	.7922	.6668	.9907
18	.679	.5658	.6287		.7922	.7545	.7621
19	.6224	.5093	.6287	.4108	.4904	.5281	.5281
20	.5228	.5093	.5716	.3734	.4715	.4954	.5228
21	.5601	.5093	.4572	.3361	.5658	.4954	.5041
22	.5788	.5658	.5281	.3547	.5658	.6413	.5601
23	.5788	.5658	.5658	.3547	.4527	.6413	.5415
24	.5228	.5601	.5658	.5658	.3326	.5658	.6224
Max	.9054	.8764	.811	.5658	.9145	.8764	.9907
Min	.499	.5093	.4572	.3361	.2957	.4954	.5041
Avg	.6558	.6250	.6275	.4461	.5909	.6353	.6893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 206 / 11KV SUSHMA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6859	.7621	.724	.6097	.8573	.6859
2	.6859	.6859	.743	.724	.6097	.8573	.7049
3	.7049	.7049	.724	.724	.6287	.8002	.7049
4	.743	.724	.743	.743	.6478	.8002	.724
5	.8002	.743	.743	.743	.6478	.8002	.724
6	.8192	.7621	.724	.7621	.6668	.8573	.724
7	.8383	.8192	.724	.6097	.6859	.7621	.6859
8	.8383	.8573	.8002	.6478	.7049	.8002	.7621
9	.9526	.8573	1.1812	.6478	.7621	1.1622	.9907
10	.9526	.8383	1.4289	.6287	.7621	1.2765	.9526
11	1.0479	.9907	1.4098	.6287	1.0669	1.3717	1.3336
12	1.2193	.9526	1.3336	.5716	.8002	1.2955	1.448
13	1.1812	.8764	1.2384	.5144	.7621	1.1431	1.1812
14	1.3336	.8383	1.0669	.5144	.9907	1.1431	1.105
15	1.2384	1.2193	1.2574		1.1431	1.1812	1.1812
16	.8954	1.2193	1.3717	.724	1.0669	1.1812	1.3717
17	1.1812	1.0288	1.2193	.6097	.9526	1.1431	1.1812
18	1.0479	.9526	.8764		.8573	.724	1.0098
19	.8192	.8383	.8764	.724	.8002	.6097	.743
20	.743	.8573	.6478	.7049	.8002	.6097	.7621
21	.7621	.8573	.6478	.6859	.9526	.724	.8002
22	.7621	.8002	.8383	.6668	1.0288	.724	.8002
23	.743	.743	.8383	.6668	.8002	.6859	.7811
24	.7621	.724	.7621	.7621	.6478	.9145	.6859
Max	1.3336	1.2193	1.4289	.7621	1.1431	1.3717	1.448
Min	.6859	.6859	.6478	.5144	.6097	.6097	.6859
Avg	.9081	.8573	.9566	.6694	.8081	.9343	.9185

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044059 / 33KV SHENDRA MIDC

Feeder No / Name : 207 / 11KV Aurangabad Jalna

TollWays Feeder KV- 11 /

OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.021	.0274	.0221	.0377	.0693	.0362	.0377
2	.0221	.0267	.029	.0377	.0671	.037	.0377
3	.0225	.0191	.0286	.0377	.0486	.0373	.0377
4	.0248	.0171	.0282	.0377	.0457	.037	.0377
5	.0267	.0171	.024	.0377	.0429	.0286	.0377
6	.029	.0126	.0191	.0377	.0316	.0191	.0377
7	.0191	.0126	.0168	.0377	.0229	.0122	.0377
8	.0137	.0126	.0141	.0377	.0156	.0152	.0377
9	.0191	.0381	.0191	.0168	.0381	.0065	.0377
10	.0191	.0381	.0213	.0171	.0381	.0114	.0377
11	.0171	.0381	.0213	.0164	.0381	.0187	.0187
12	.0168	.0377	.0213	.0191	.0381	.0202	.0189
13	.0202	.0381	.0259	.0194	.0381	.0217	.0381
14	.0339	.0381	.029	.0198	.0381	.016	.0381
15	.0282	.0381	.0217	.0202	.0381	.0133	.0381
16	.032	.0381	.0164	.0225	.0381	.0133	.0267
17	.0183	.0202	.0381	.0217	.0229	.0381	.0217
18	.0267	.0324	.0381	.0267	.0232	.0381	.0278
19	.0309	.0351	.0381	.0332	.0362		.0354
20	.0701	.0362	.0381	.0362	.0366		.0709
21	.0526	.0362	.0381	.0943	.0362	.0381	.1063
22	.0362	.0366	.0377	.1132	.0362	.0377	.1307
23	.0305	.0366	.0377	.0514	.0305	.0377	.0532
24	.0198	.0446	.0324	.0381	.0686	.0358	.0377
Max	.0701	.0446	.0381	.1132	.0693	.0381	.1307
Min	.0137	.0126	.0141	.0164	.0156	.0065	.0187
Avg	.0271	.0303	.0273	.0362	.0391	.0259	.0433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 201 / LADSAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.3887	.724	.362	.362	.4748	.543
2	.8145	.4534	.8145	.3982	.362	.4915	.6516
3	.905	.4915	.8688	.4163	.4525	.5596	.6908
4	.905	.5571	.905	.5249	.543	.6443	.6878
5	.8145	.7461	.9231	.6154	.6335	.6554	.7468
6	.9955	.8907	1.0136	.724	.905	.7449	.6697
7	.905	1.0159	1.0498	1.086	1.1765	.9503	.6335
8	1.086	.9503	1.1222	1.1584	1.267	.9012	.724
9	1.086	.9326	1.1765	1.0679	1.1765	.8356	1.0136
10	.724	.5898	.724	.905	.8145	.724	.5611
11	.7291	.6335	.724	.724	.6783	.724	.8326
12	.6783	.6697	.6335	.724	.6316		.905
13	.7045	.6878	.5973	.724	.5506	.9955	.7602
14	.6226	.6878	.543	.724	.5144	.6335	.724
15	.6274	.6878	.543	.6335	.6783	.6335	.724
16	.5898	.6154	.6335	.543	.7122	.724	.7602
17	.6554	.6154	.7059	1.267	.7373	.7783	.724
18	.5765	.6335	.7602	.8145	.7865	.8145	.7783
19	.7449	.724	.905	1.086	.9326	1.1584	1.1222
20	.8745	.724	.8869	.9955	1.0174	1.0317	.9955
21	.5571	.724	.8688	.905	.7045	1.086	.905
22	.4915	.724	.7421	.724	.6226	.7964	.7964
23	.4752	.724	.6878	.724	.5426	.724	.7059
24	.8145	.4409	.8145	.3077	.362	.4915	.6878
<b>Max</b>	<b>1.086</b>	<b>1.0159</b>	<b>1.1765</b>	<b>1.267</b>	<b>1.267</b>	<b>1.1584</b>	<b>1.1222</b>
<b>Min</b>	<b>.4752</b>	<b>.3887</b>	<b>.543</b>	<b>.3077</b>	<b>.362</b>	<b>.4748</b>	<b>.543</b>
<b>Avg</b>	<b>.7542</b>	<b>.6795</b>	<b>.8070</b>	<b>.7564</b>	<b>.7151</b>	<b>.7640</b>	<b>.7643</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 202 / 11 KV ANJANDOH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.3887	.8145	.6335	.724	.4915	.7059
2	.8145	.4588	.8145	.8326	.8145	.5182	.6335
3	.905	.426	.905	1.4118	1.448	.583	.724
4	.9955	.4915	1.2851	1.7737	1.5384	.6478	.7421
5	1.086	.639	1.4842	1.8099	1.6289	.7537	.7964
6	1.267	.9717	1.5384	1.9004	1.8099	.8421	.8869
7	1.267	1.0202	1.8099	2.3529	1.9909	.9717	1.0498
8	1.3575	1.153	1.9004	2.5158	1.9909	1.1142	1.0679
9	.9955	1.0852	2.0814	2.4977	1.8099	1.065	1.086
10	.905	.5426	.2715	.3982	1.8099	.905	1.267
11	.5898	.543		.362	.583	.6335	1.267
12	.5087	.4887	.362	.2715	.5182	.4525	1.3575
13		.4525	.2715		.5087	.4887	1.4661
14		.3801	.2353		.4372	.5249	1.5203
15		.362	.2172	.2715	.5426	.543	1.6289
16	.5426	.3258	.2534	.4525	.5087	.6335	1.6651
17	.5344	.2715	.2715	.362	.5407	.543	1.7013
18	.6226	.2715	.3077	.4525	.4915	.6154	.3982
19	.8309	.362	.3982	.543	.8478	.6335	.5792
20	.852	.4525	.4525	.6335	1.0513	.7059	.4887
21	.5426	.4525	.4344	.543	.6882	.724	.4525
22	.5087	.362	.3982	.543	.639	.543	.3801
23	.4588	.362	.362	.543	.5087	.543	.3077
24	.543	.4409	.8145	.362	.8145	.4534	.6335
<b>Max</b>	<b>1.3575</b>	<b>1.153</b>	<b>2.0814</b>	<b>2.5158</b>	<b>1.9909</b>	<b>1.1142</b>	<b>1.7013</b>
<b>Min</b>	<b>.4588</b>	<b>.2715</b>	<b>.2172</b>	<b>.2715</b>	<b>.4372</b>	<b>.4525</b>	<b>.3077</b>
<b>Avg</b>	<b>.8024</b>	<b>.5293</b>	<b>.7688</b>	<b>.9757</b>	<b>1.0102</b>	<b>.6637</b>	<b>.9502</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 203 / 11 KV PIMPALKHUTTA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3052	.4525	.3439	.362	.2915	.4525
2	.4525	.2622	.3801	.362	.362	.3277	.3734
3	.5544	.3391	.3982	.3982	.4525	.3768	.724
4	.6335	.3768	.4525	.4163	.543	.4588	.7964
5	.543	.4858	.4887	.4525	.543	.4915	.7421
6	.6335	.6554	.5249	.543	.6335	.6802	.6908
7	.6335	.5344	.5973	.6335	.6335	.5344	.6878
8	.543	.4588	.362	.4887	.543	.4588	.6335
9	.4525	.3605	.362	.4163	.6335	.39	.6201
10	.2715	.3113	.3258	.4525	.6335	.4525	.2534
11	.2949	.4525	.543	.6335	.5992	.5068	.181
12	.3277	.3982	.4525	.6335	.6316	.724	.1448
13	.3441	.4525	.362	.543	.6478	.7602	.1991
14	.3768		.4344	.4525	.6154	.7964	.181
15	.3441	.3077	.4525	.543	.6104		.181
16	.3277	.3258		.543	.5935	.5973	.1448
17	.3052	.362	.4525	.543	.5256	.4706	.1629
18	.3239	.2353	.2353	.2715	.4748	.5068	.2534
19	.4239	.4163	.4525	.543	.4915	.5792	.4887
20	.5407	.4706	.4344	.543	.5087	.4344	.4525
21	.4534	.4344	.4163	.4525	.4424	.4525	.3982
22	.426	.362	.3801	.362	.3932	.362	.3982
23	.3768	.362	.362	.362	.3277	.2172	.3258
24	.362	.3391	.3439	.3439	.362	.2622	.1448
Max	.6335	.6554	.5973	.6335	.6478	.7964	.7964
Min	.2715	.2353	.2353	.2715	.3277	.2172	.1448
Avg	.4294	.3916	.4202	.4698	.5235	.4840	.4013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 204 / SAYYAIDPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.3887	.4163	.4887	.543	.5426	1.086
2	.8145	.4409	.4525	.543	.543	.5898	1.1765
3	.724	.4752	.5973	.5792	.543	.6783	1.2308
4	.905	.4915	.724	.8507	.905	.6226	1.2851
5	1.1765	.6882	.9955	.9231	.9955	.78	1.3575
6	1.267	1.153	1.267	1.1946	1.267	1.2209	1.267
7	1.3575	1.2125	1.3575	1.3032	1.3575	1.2209	1.3032
8	1.1765	1.0174	1.1041	1.0136	1.448	.9503	1.3575
9	.9955	.763	.6878	.8145		.7935	1.4661
10	.724	.7373	.9955	1.3756		1.8099	.543
11	.9326	1.086	1.448	1.8099	2.0243	2.1719	.6335
12	.9831	.9955	1.5023	1.9909	2.2283	2.3529	
13	.9665	.9955	1.267	1.9909	2.2996	1.448	
14	.8192	1.086	1.0317	1.8099	2.2939	1.4842	
15	.9012	1.0317	.9955	1.7194	2.0348	1.531	
16	.9717	1.1222	1.5384	1.5384	2.0243	1.8642	
17	.9503	1.086	1.3032	2.9864	1.8313	1.3394	
18	.5243	.2715	.4163	.4525	.6554	.724	.4706
19	.7935	.6335	.7421	.905	.9156	.8326	.8688
20	.9503	.6335	.7059	.8145	.8192	.6697	.7602
21	.6554	.543	.6335	.724	.6316	.543	.5792
22	.5243	.4887	.5068	.4525	.583	.4706	.4887
23	.4588	.4344	.4344	.4525	.5182	.4525	.3801
24	.362	.4239	.4163	.3982		.4858	.5068
<b>Max</b>	<b>1.3575</b>	<b>1.2125</b>	<b>1.5384</b>	<b>2.9864</b>	<b>2.2996</b>	<b>2.3529</b>	<b>1.4661</b>
<b>Min</b>	<b>.362</b>	<b>.2715</b>	<b>.4163</b>	<b>.3982</b>	<b>.5182</b>	<b>.4525</b>	<b>.3801</b>
<b>Avg</b>	<b>.8607</b>	<b>.7583</b>	<b>.8975</b>	<b>1.1305</b>	<b>1.2601</b>	<b>1.0658</b>	<b>.9311</b>



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 205 / 11 KV Hatmali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525		.362	.4706	.4525	.4409	.724
2	.543		.362	.5068	.543	.4534	.7964
3	.6335	.4915	.4525	.5249	.543	.4858	.8688
4	.724	.5243	.7421	.724	.724	.5243	1.267
5	.9955	.7122	.8507	.8145	.905	.6478	1.448
6	1.086	1.1305	.905	1.1765	1.1765	.8192	1.5746
7	.181	1.1469	1.086	.905	1.5384	.7209	1.6108
8	.181	.6882	.905	.9774	1.448	.6882	1.6289
9	.8145	.763	.543	.7059	1.086	.6226	1.3443
10	.6335	.6062	.724	.905	1.1041	.8145	.4706
11	.8192	.9955	.905	1.1765	1.166	1.448	.2715
12	.8848	1.0317	1.1403	.3258	1.247	1.3575	.362
13	.8817	1.0136	1.086	1.3575	1.3279	1.448	.2715
14	.7865	.9955	1.0498	1.267	1.2631	1.267	.2534
15	.8192	.9955	1.0679	1.267	1.2452	1.1584	.2715
16	.9326	.905	1.1041	1.1765	1.2548	1.1584	.2534
17	.8478	.9231	1.1946	1.1765	1.1469	.7783	.2715
18	.5426	.362	.3982	.4525	.5426	.8326	.3801
19	.8309	.6335	.724	.905	.7969	.8869	.7421
20	.9175	.6335	.6697	.6335	.8478	.7059	.6335
21	.6104	.543	.6154	.6535	.6783	.6335	.543
22	.4696	.543	.5249	.543	.5898	.543	.5611
23	.4409	.5068	.4887	.543	.5426	.4344	.4887
24	.6335		.4706	.4706	.4525	.4534	.4706
<b>Max</b>	<b>1.086</b>	<b>1.1469</b>	<b>1.1946</b>	<b>1.3575</b>	<b>1.5384</b>	<b>1.448</b>	<b>1.6289</b>
<b>Min</b>	<b>.181</b>	<b>.362</b>	<b>.362</b>	<b>.3258</b>	<b>.4525</b>	<b>.4344</b>	<b>.2534</b>
<b>Avg</b>	<b>.6942</b>	<b>.7688</b>	<b>.7655</b>	<b>.8191</b>	<b>.9426</b>	<b>.8051</b>	<b>.7295</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044063 / 33/11 KV LADSAWANGI SUB

STATIO

Feeder No / Name : 206 / BHAKARWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3052	.4887	.6335	.6335	.3391	
2	.362	.3391	.5068	.724	.724	.4588	
3	.362	.4748	.5068	.7602	.724	.4915	
4	.462	.4915	.543	.7783	.8145	.6104	
5	.4525	.5596	.905	.8869	.905	.7122	
6	.543	.4424	.9593	1.086	1.3575	1.2887	
7	.6335	.7865	.9955	1.448	1.5384	1.0486	
8	.905	.8684	1.1041	1.5203	1.6289	1.1869	
9	.543	.6783	1.086	1.5384	1.5384	1.3056	
10	.2715	.3113	.1267	.2715	.362	.2715	
11	.1311	.181	.0905	.181	.2429	.181	
12	.0819	.181	.0905	.181	.1619	.181	.543
13	.0983		.0905	.0905	.1357	.181	.9955
14	.1357	.181	.0905	.0905	.1475	.0905	1.1765
15	.1475	.181	.0905	.181	.1619	.0905	1.3575
16	.1696	.1991	.1267	.181	.2458	.181	1.3575
17	.1638	.1991	.181	.181	.2543	.181	1.1765
18	.2949	.2353	.181	.362	.3391	.2896	.2715
19	.4424	.3258	.4525	.543	.4578	.4706	.3439
20	.5735	.2715	.362	.2715	.407	.3174	.3077
21	.4588	.2715	.2715	.2715	.3391	.2172	.2715
22	.407	.2353	.2353	.181	.2713	.2353	.2534
23	.3277	.2172	.2172		.2267	.2715	.2353
24	.362	.2622	.4706	.5792	.724	.2949	.2172
Max	.905	.8684	1.1041	1.5384	1.6289	1.3056	1.3575
Min	.0819	.181	.0905	.0905	.1357	.0905	.2172
Avg	.3583	.3564	.4238	.5627	.5976	.4540	.6544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 201 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.4287	.0343	.3429	.0343	.1715
2		.0343	.4287	.0343	.3429	.0343	.1715
3		.0429	.4287	.0343	.3429	.0514	.1715
4		.0514	.4287	.0343	.4287	.0514	.2572
5		.06	.5144	.0429	.5144	.06	.3429
6		.06	.6859	.0429	.5144	.06	.4287
7		.0686	.6001	.0514	.6001	.0514	.4287
8		.0343	.5144	.0514	.5144	.0343	.4287
9	.0514	.0343	.3429	.0429	.3429	.0257	.4287
10	.0257	.0257	.3429	.0343	.3429	.0257	.1715
11	.0343	.2572	.0343	.2572	.0429	.4287	.0171
12	.0257	.3429	.0343	.2572	.0429	.5144	
13	.0257	.2572	.0343	.3429	.0429	.5144	
14	.0171	.2572	.0343	.3429	.0429	.5144	.0171
15	.0257	.3429	.0343	.3429	.0429	.5144	.0171
16	.0257	.3429	.0343	.4287	.0514	.5144	
17	.0257	.2572	.0429	.3429	.0514	.5144	.0257
18	.0343	.2572	.0343	.1715	.0257	.4287	.0257
19	.0343	.4287	.0514	.5144	.0514	.5144	.0429
20	.0429	.4287	.0514	.5144	.0429	.5144	.0514
21	.0514	.4287	.0429	.4287	.0429	.4287	.0514
22	.0514	.4287	.0429	.4287	.0429	.4287	.0429
23	.0343	.4287	.0429	.3429	.0343	.3429	.0429
24	.0343	.0343	.4287	.0343	.3429	.0343	.1715
Max	.0514	.4287	.6859	.5144	.6001	.5144	.4287
Min	.0171	.0257	.0343	.0343	.0257	.0257	.0171
Avg	.0337	.2058	.2358	.2147	.2161	.2765	.1670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 202 / EKLAHARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0086	.0857	.0086	.0857	.0086	.2572
2		.0086	.0857	.0086	.0857	.0086	.2572
3		.0086	.0857	.0086	.0857	.0171	.2572
4		.0086	.1715	.0086	.0857	.0171	.2572
5		.0171	.1715	.0171	.1715	.0257	.3429
6		.0171	.2572	.0257	.2572	.0257	.4287
7		.0257	.2572	.0257	.2572	.0257	.6001
8		.0086	.1715	.0171	.1715	.0171	.6859
9	.0257	.0086	.1715	.0171	.1715	.0171	.7716
10	.0343	.0429	.5144	.0257	.2572	.06	.0857
11	.0429	.6001	.06	.2572	.06	.7716	.0086
12	.0514	.6001	.06		.0686	.8573	.0086
13	.0514	.5144	.06	.4287	.0772	.7716	.0086
14	.0514	.5144	.06	.6001	.0772	.6859	.0086
15	.0429	.5144	.06	.5144	.0686	.6859	.0086
16	.0429	.5144	.06	.6001	.0772	.6859	
17	.0429	.5144	.06	.5144	.0772	.6859	.0086
18	.0086	.7716	.0086	.0857	.0086	.0857	.0086
19	.0086	.0857	.0171	.1715	.0171	.0857	.0171
20	.0171	.1715	.0171	.1715	.0171	.1715	.0171
21	.0171	.1715	.0171	.1715	.0171	.1715	.0171
22	.0086	.1715	.0171	.1715	.0171	.1715	.0171
23	.0086	.0857	.0171	.0857	.0086	.1715	.0171
24	.0086	.0086	.0857	.0086	.0857	.0086	.4287
Max	.0514	.7716	.5144	.6001	.2572	.8573	.7716
Min	.0086	.0086	.0086	.0086	.0086	.0086	.0086
Avg	.0289	.2247	.1072	.1715	.0961	.2597	.1964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 203 / CHITEPIMPALGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.4287	.0514	.5144	.0514	.6001
2		.0514	.4287	.0514	.5144	.0514	.6001
3		.06	.5144	.06	.5144	.06	.6001
4		.0686	.6001	.06	.6001	.06	.7716
5		.0772	.6859	.0686	.7716	.0772	.9431
6		.0857	.7716	.0943	1.0288	.0943	1.286
7		.0943	.8573	.1029	1.1145	.1115	1.286
8		.0943	1.0288	.0943	1.286	.12	1.1145
9	.0943	.0943	.8573	.1029	1.0288	.1286	.7716
10	.0943	.0857	.6859	.0686	.7716	.0686	.9431
11	.0686	.6859	.06	.4287	.0514	.5144	.12
12	.06	.5144	.0514	.3429	.0514	.5144	.1115
13	.06	.0514	.0514	.2572	.0429	.4287	.1115
14	.0514	.6001	.0429	.3429	.0429	.4287	.12
15	.0514	.6001	.0514	.4287	.0514	.5144	.1115
16	.06	.5144	.0514	.5144	.06	.5144	
17	.0772	.6001	.0514		.06	.6001	.12
18	.0857	.6859	.0857	.7716	.0857	.7716	.0686
19	.1029	.8573	.1029	1.0288	.1115	.9431	.1029
20	.1115	.7716	.1029	1.0288	.1115	.8573	.1029
21	.0772	.6859	.0857	.7716	.0772	.6859	.0943
22	.0686	.6001	.0772	.6859	.0772	.6859	.0857
23	.06	.6001	.06	.6001	.0686	.6001	.06
24	.06	.0514	.5144	.0514	.5144	.0514	.6001
Max	.1115	.8573	1.0288	1.0288	1.286	.9431	1.286
Min	.0514	.0514	.0429	.0514	.0429	.0514	.06
Avg	.0739	.3576	.3436	.3481	.3979	.3722	.4663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 204 / pachod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.3429	.0343	.3429	.0429	.5144
2		.0343	.3429	.0343	.3429	.0429	.5144
3		.0343	.4287	.0429	.3429	.0429	.5144
4		.0429	.4287	.0429	.4287	.0429	.6001
5		.0429	.5144	.0514	.5144	.0429	.7716
6		.0686	.6001	.06	.6001	.0686	.9431
7		.0686	.6001	.06	.6859	.0772	.8573
8		.0686	.6001	.0514	.8573	.0943	.6859
9	.0429	.0686	.6001	.0772	.9431	.1029	.6001
10	.0686	.06	.5144	.0514	.4287	.0514	.5144
11	.0514	.4287	.0343	.3429	.0343	.4287	.06
12	.0429	.4287	.0343	.2572	.0343	.3429	.0514
13	.0429	.4287	.0343	.2572	.0343	.3429	.0514
14	.0429	.3429	.0343	.2572	.0343	.3429	.0772
15	.0429	.3429	.0343	.3429	.0429	.2572	.0772
16	.0343	.3429	.0343	.3429	.0429	.3429	
17	.0514	.4287	.0343	.4287	.0429	.4287	.0772
18	.0686	.5144	.0514	.6001	.06	.5144	.0429
19	.0772	.6859	.06		.0686	.6001	.0686
20	.0772	.6859	.0772	.8573	.0686	.6859	.0686
21	.0686	.6001	.06	.6859	.0686	.6001	.0686
22	.06	.5144	.06	.6001	.0686	.6001	.06
23	.0514	.5144	.0514	.5144	.0514	.5144	.0514
24	.0171	.0429	.3429	.0257	.3429	.0343	.5144
Max	.0772	.6859	.6001	.8573	.9431	.6859	.9431
Min	.0171	.0343	.0343	.0257	.0343	.0343	.0429
Avg	.0525	.2844	.2465	.2617	.2701	.2769	.3385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 205 / Pimpri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0772	.6859	.0857	.8573	.0857	.3429
2		.0772	.6859	.0772	.8573	.0857	.3429
3		.0857	.7716	.0772	.8573	.0943	.3429
4		.0857	.8573	.0857	.9431	.0943	.4287
5		.0943	1.0288	.0943	.9431	.1029	.4287
6		.1115	1.2003	.1029	1.0288	.1115	.5144
7		.12	1.1145	.1115	1.1145	.12	.4287
8		.1029	.9431	.1029	1.0288	.0943	.5144
9	.12	.0943	.9431	.0943	.8573	.0943	.5144
10	.0429	.0343	.3429	.0429	.3429	.0514	.7716
11	.0429	.3429	.0429	.3429	.0343	.5144	.0772
12	.0429	.3429	.0429	.3429	.0343	.4287	.0686
13	.0429	.2572	.0429	.3429	.0343	.4287	.0686
14	.0343	.2572	.0429	.3429	.0343	.4287	.0686
15	.0343	.3429	.0429	.3429	.0429	.4287	.0686
16		.3429	.0429		.0429	.4287	
17	.0429	.3429	.0429		.0514	.4287	.0772
18	.0857	.7716	.0943	.9431	.0943	.7716	.0772
19	.0943	.9431	.1029	1.2003	.1029	1.0288	.0943
20	.1029	1.0288	.1115	1.2003	.1115	1.2003	.1115
21	.1029	.9431	.1029	1.1145	.1115	1.0288	.1115
22	.0943	.8573	.0943	1.0288	.1115	.9431	.1029
23	.0857	.8573	.0857	.9431	.1029	.8573	.0943
24	.0857	.0772	.7716	.0857	.8573	.0857	.3429
Max	.12	1.0288	1.2003	1.2003	1.1145	1.2003	.7716
Min	.0343	.0343	.0429	.0429	.0343	.0514	.0686
Avg	.0703	.3579	.4265	.4139	.4415	.4140	.2606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 206 / Bafana feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0086	.0857	.0086	.0857	.0086	.0857
2		.0086	.0857		.0857	.0086	.0857
3		.0086	.0857		.0857	.0086	.0857
4		.0086	.0857		.0857	.0086	.0857
5		.0086	.0857		.0857	.0086	.0857
6		.0086	.0857		.0857	.0086	.0857
7		.0086	.0857		.0857	.0086	.0857
8		.0086	.0857		.0857	.0086	.0857
9	.0086	.0086	.0857		.0857	.0086	.0857
10	.0086	.0086	.0857		.0857	.0086	.0857
11	.0086	.0857	.0086		.0086	.0857	.0086
12	.0086	.0857	.0086		.0086	.0857	.0086
13	.0086	.0857	.0086		.0086	.0857	.0086
14	.0086	.0857	.0086		.0086	.0857	.0086
15	.0086	.0857	.0086		.0086	.0857	.0086
16	.0086	.0857	.0086		.0086	.0857	
17	.0086	.0857	.0086		.0086	.0857	.0086
18	.0086	.0857	.0086		.0086	.0857	.0086
19	.0086	.0857	.0086		.0086	.0857	.0086
20	.0086	.0857	.0086		.0086	.0857	.0086
21	.0086	.0857	.0086		.0086	.0857	.0086
22	.0086	.0857	.0086		.0086	.0857	.0086
23	.0086	.0857	.0086		.0086	.0857	.0086
24	.0086	.0086	.0857	.0086		.0086	.0857
Max	.0086	.0857	.0857	.0086	.0857	.0857	.0857
Min	.0086	.0086	.0086	.0086	.0086	.0086	.0086
Avg	.0086	.0504	.0439	.0086	.0421	.0504	.0455



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044064 / 33KV PIMPRI RAJA

Feeder No / Name : 207 / Ambikarpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0086	.0857	.0086	.0857	.0086	.0857
2		.0086	.0857	.0086	.0857	.0086	.0857
3		.0086	.0857	.0086	.0857	.0086	.0857
4		.0086	.0857	.0086	.0857	.0086	.0857
5		.0086	.0857	.0086	.0857	.0086	.0857
6		.0171	.0857	.0086	.1715	.0086	.1715
7		.0171	.1715	.0086	.1715	.0086	.1715
8		.0171	.0857	.0086	.0857	.0086	.2572
9	.0086	.0171	.0857	.0086		.0086	.2572
10	.0171	.0171	.0857	.0086	.0857	.0086	.0857
11	.0086	.0857	.0171	.0857	.0171	.1715	.0086
12	.0171	.0857	.0171	.0857	.0171	.2572	.0086
13	.0171	.0857	.0171	.0857	.0171	.1715	.0086
14	.0171	.0857	.0171	.0857	.0171	.1715	.0086
15	.0171	.0857	.0171	.0857	.0257	.1715	.0086
16	.0171	.0857	.0171	.0857	.0257	.1715	
17	.0171	.0857	.0257	.0857	.0257	.1715	.0086
18	.0086	.0857	.0086	.0857	.0086	.0857	.0086
19	.0086	.0857	.0086	.0857	.0086	.0857	.0086
20	.0086	.0857	.0086	.0857	.0086	.0857	.0086
21	.0086	.0857	.0086	.0857	.0086	.0857	.0086
22	.0086	.0857	.0086	.0857	.0086	.0857	.0086
23	.0086	.0857	.0086	.0857	.0086	.0857	.0086
24	.0086	.0086	.0857	.0086	.0857	.0086	.0857
Max	.0171	.0857	.1715	.0857	.1715	.2572	.2572
Min	.0086	.0086	.0086	.0086	.0086	.0086	.0086
Avg	.0123	.0521	.0504	.0504	.0533	.0790	.0678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 201 / GANDHELI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8573	.8402	.6859	.6173	
2	.8507		.8916	.8402	.7545	.6516	
3	.8688		.9259	.8573	.7888	.6859	
4	.8688		1.2346	.8916	.9431	.7888	
5	.905		1.406	1.166	1.0974	.9602	
6	1.3937		1.5604	1.5775	1.286	1.166	
7	1.3756		1.4746		1.0117	1.286	
8	1.4299				.9088	1.166	
9	1.1946	1.3756			.8573	1.0631	
10	.5658		.7602	.8048	.543	.6516	
11	.5144	.543	.6878	.6767	.4887	.6687	.8145
12	.4801	.5609	.5611	.6401	.4557	.6516	.8145
13	.463	.4525	.5249	.543	.4908	.583	.6878
14	.5487	.3506	.4706	.5304	.463	.6516	.6697
15	.3429	.3506	.4938	.4706	.4458	.583	
16		.3772	.5304	.543	.4458	.5658	
17	.5611	.4287		.3944	.5083	.5487	.6173
18	1.134	.8745	.9945		.7373	.8059	.703
19	1.3756	1.3375	1.4232	1.0117	1.0802	.9774	.9431
20		1.2689	1.3375	1.086	1.0117	.823	.8059
21		1.1488	1.2174		.9088		.7373
22		.9431	1.2174	.9055	.7545	.7888	.7373
23		.8573	.9774	.8131	.6516		.6173
24	.8507		.8402	.8573	.6859	.583	.2401
Max	1.4299	1.3756	1.5604	1.5775	1.286	1.286	.9431
Min	.3429	.3506	.4706	.3944	.4458	.5487	.2401
Avg	.8735	.7764	.9708	.8131	.7502	.7849	.6990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 202 / ADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5144	.4801	.4801	.5144	
2	.543		.5487	.5144	.5144	.583	
3	.543		.6173	.5316	.5144	.6859	
4	.724		.7888	.5658	.6687	.7545	
5	1.086		.8916	.6859	.9259	.9602	
6	1.1765		1.1317	.8402	1.1488	1.1831	
7	1.2489		1.1831		1.2003		
8	1.267		1.0631	1.2174	1.1488		
9	1.086	1.0498	.9088	.9231	.9602	1.0631	
10	.4801	.362	.6516	.5611	.362	.4458	
11	.463	.362	.7059	.4344	.3982	.6344	.5068
12	.4458		.5249	.4024	.4207	.6516	.4706
13		.5973	.5792	.3658	.4382	.4115	.3439
14	.463	.567	.6268	.4024	.4458	.4287	.3258
15	.4973	.4557	.5487	.3801	.4801		
16	.583	.5144	.4525	.3801	.3944		
17	.5611	.5658	.5316	.3086	.3506	.4287	.4115
18	.8413	.4973	.5487	.5144	.6859	.6173	.5316
19	1.0608	.7373	.9259	.8573	.823	.9259	.8059
20		.6859	.823	.9774			.7545
21		.6516	.6859	.7545	.6687		.6516
22		.5144	.583	.7577	.583	.583	.5487
23		.5144	.5316	.6283	.5658		.4458
24	.543		.4973	.4973	.5316	.5144	.2401
Max	1.267	1.0498	1.1831	1.2174	1.2003	1.1831	.8059
Min	.4458	.362	.4525	.3086	.3506	.4115	.2401
Avg	.7563	.5768	.7027	.6078	.6395	.6697	.5031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 203 / SINDHON BINDHON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.463	.463	.463	.4801	
2	.6516		.5144	.4801	.4973	.5144	
3	.6878		.583	.5316	.5487	.583	
4	.724		.7545	.583	.6173	.6516	
5	.7602		.8402	.9259	.8916	.8916	
6	1.0679		.9774	1.0802	.9602	1.1831	
7	1.2489		1.0802	1.2003	.9431		
8	.8507		1.0288	1.046	.9259	1.0631	
9	.7059	.8869	.8573	.8326	.6859	.9431	
10	.2572		.3258	.3982	.4344	.5144	
11	.2401	.4163	.3258	.4024	.4344	.6001	.3439
12	.2572	.3155	.3077	.4207	.4382	.583	.3258
13	.2915	.298	.2715	.3658	.4557	.5144	.362
14	.2743	.2629	.2378	.3475	.4458	.5658	.3439
15	.2401	.2629	.2743	.3292	.4287	.5487	
16	.3086	.2572	.3292	.3801	.4115		
17	.3258	.3086	.3772	.3086	.4382	.5487	.4287
18	.7133	.5316	.6173		.6344	.703	.5658
19	.8048	.7716	.8573	.9259	.7888	.9431	.6859
20		.6173	.8059	.9231	.7373		.6859
21		.583	.7202		.6173		.5658
22		.5487	.6344	.5729	.5316	.5316	.5316
23		.5144	.5144	.5175	.4801		.4801
24	.6516		.4458	.463	.463	.4801	.2572
Max	1.2489	.8869	1.0802	1.2003	.9602	1.1831	.6859
Min	.2401	.2572	.2378	.3086	.4115	.4801	.2572
Avg	.5822	.4696	.5893	.6135	.5947	.6759	.4647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 204 / 11 KV EXP.MAHANANDA NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857	.0857	.0857	.0857	
2	.0934		.0857	.0686	.0857	.0857	
3	.0934		.0686	.0514	.0686	.0857	
4	.0934		.0686	.0343	.0514	.0857	
5	.0934		.0514	.0343	.0514	.0686	
6	.056		.0514	.0343	.0686	.0514	
7	.0747		.0514	.0514	.0514	.0514	
8	.0934		.12	.0857	.0857	.0857	
9	.0934	.112	.1029	.1267	.1372	.1029	
10	.12	.1494	.1267	.1448	.168	.1029	
11			.1448	.1267	.168	.12	.1307
12	.12	.0876	.0905	.1097	.168	.1029	.1267
13	.0857	.0934	.1075	.0905	.0934	.1029	.0747
14	.1372	.1307	.0905	.1097	.0747	.12	.112
15	.1029	.1307	.1097	.0914	.1307	.12	
16		.1307	.1448	.1267	.128		
17	.1267	.056	.12	.0857	.1463	.12	.12
18	.1097	.1029	.0686	.12	.0857	.1029	.1029
19	.0732	.0514	.0514	.0514	.0686	.0514	.0686
20		.0514	.0686	.0747	.0686		.0514
21		.0686	.0686	.0857	.0857		.0686
22			.0857	.0924	.0857	.0857	.0857
23		.0857	.0857	.0924	.0514		.0857
24	.0934		.0857	.0857	.0857	.0857	.0857
Max	.1372	.1494	.1448	.1448	.168	.12	.1307
Min	.056	.0514	.0514	.0343	.0514	.0514	.0514
Avg	.0976	.0962	.0889	.0858	.0956	.0909	.0927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 205 / PRATIK METAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307		.1543	.1132	.1029	.1372	
2	.1307		.1372	.1183	.1029	.12	
3	.128		.1543		.12	.1372	
4	.1307		.1543	.1252	.1029	.12	
5	.1307		.1543	.12	.12	.1372	
6			.1715	.1166	.1372	.1543	
7	.1494		.1715	.1097	.1372	.1543	
8	.1494		.1372	.1286	.12	.12	
9	.1494	.1494	.12	.1448	.1715	.1543	
10	.12	.168	.3258	.1267	.4481	.1543	
11			.1629	.1463	.4481	.1372	.2614
12	.1629	.0168	.3077	.1463	.4854	.1372	.3921
13	.1372	.112	.2926	.1463	.5041		.2427
14	.12	.168	.3077	.1463	.4854	.1886	.2172
15	.1715	.112	.3658	.1646	.4458	.3944	
16	.12	.112	.4572	.1629	.2378		
17	.1829	.1867	.4973	.1543	.2195	.1543	
18	.1463	.2058	.3772	.1372	.1029	.4458	.2401
19	.128	.1372	.1509	.1372	.1115	.1886	.1406
20		.1372	.1303	.1307	.1149		.1543
21		.1715	.1269		.1543		.0154
22		.1543	.1132	.1663	.1235	.1509	.1543
23		.1543	.096	.1663	.12		.1509
24	.1307		.1715	.0789	.12	.12	.1166
Max	.1829	.2058	.4973	.1663	.5041	.4458	.3921
Min	.12	.0168	.096	.0789	.1029	.12	.0154
Avg	.1399	.1418	.2182	.1358	.2182	.1740	.1896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044079 / 33/11KV Gadheli S/S

Feeder No / Name : 206 / 11 KV MGM FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171	.012	.0171	.0171	
2	.0187		.0171	.0103	.0171	.0171	
3	.0187		.0171		.0171	.0171	
4	.0187		.0171	.012	.0171	.0171	
5	.0187		.0171	.012		.0171	
6	.0187		.0171	.0137		.0171	
7	.0373		.0171	.0171	.0171	.0171	
8	.0373		.0171		.0171	.0171	
9	.0112	.0112			.0171	.0171	.0373
10	.0171	.0187		.0181	.0299	.0173	.0373
11			.0181	.0366	.0299	.0343	.0373
12	.0189	.0187	.0181	.0366	.0299	.0171	.0373
13	.0171	.0187	.0183	.0181	.0187	.0171	
14	.0206		.0181	.0183	.0187	.0171	.0373
15	.024	.0149	.0183	.0181	.0187	.0171	
16	.0343		.0183	.0181	.0274		
17	.0181			.0171	.0183	.0154	.012
18	.0183			.0171	.0171	.0154	.0137
19	.0183			.0171	.0171	.0154	.0137
20		.0171			.0154		.0171
21		.0171		.0171	.0103		.0154
22		.0171	.0103	.0185	.0137	.0137	.0171
23		.0171		.0185	.0137		.0171
24	.0187		.0171	.012	.0171	.0171	.0171
Max	.0373	.0187	.0183	.0366	.0299	.0343	.0373
Min	.0112	.0112	.0103	.0103	.0103	.0137	.012
Avg	.0214	.0167	.0171	.0179	.0189	.0175	.0238

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 201 / Khodegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.8676	.8488	.7922	.8865	.3326
2		.7545	.8488	.9242	.7922	.9054	.3658
3		.8865	.9242	.9808	.9619	.8488	.4024
4		.9431	1.0185	1.0374	1.1317	.8676	.4572
5		.9997	1.1128	1.1694	1.226	.9808	.5373
6		1.1317	1.2637	1.226	1.2826	1.2826	.6268
7		1.0374	.9997	1.3203	1.226	1.2071	.6447
8		1.1317	.7545	.9808	1.1883	1.094	.7011
9	1.0374	.7922	.6602	.5373	.9242	.8299	.6661
10		.4338	.3812	.4578	.5975	.3944	.547
11	.3361	.4715	.4144	.4807	.6299	.5487	.5281
12	.3734	.4715	.4973	.502	.5761	.5316	.4904
13	.4108	.4338	.5243	.5668	.5801	.583	.4715
14	.3881	.3772	.5571	.4915	.547	.6516	.4715
15	.4066	.415	.4588	.4915	.4144	.6173	.4715
16	.4481	.4298	.5407	.4973	.5304	.6001	.4904
17	.3881	.4835	.5407	.5765	.3856	.5868	.6036
18	.9242	.6979	.6413	.7282	.7167	.7167	.679
19	.9431	.8299	1.1128	.8402	.9431	.8488	.7167
20	.9808	.9242	.8299	1.0082	.9808	.9997	.811
21	.9242	.9242	.7316	1.0185	.9808	.9619	.8488
22	.8676	.9242		.9997	.7922	.7888	.8488
23	.8488	.9242	.7545	.9242	.9054	.8488	.8299
24	.6602	.8488	.8676	.8865	.7356	.8865	.3326
Max	1.0374	1.1317	1.2637	1.3203	1.2826	1.2826	.8488
Min	.3361	.3772	.3812	.4578	.3856	.3944	.3326
Avg	.6625	.7509	.7523	.8123	.8267	.8111	.5781



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 202 / Kachner

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5601	.2241	.1867	.1867	.1791	.5658
2		.4668	.2241	.2641	.2054	.2149	.6036
3		.3734	.2427	.2987	.2427	.1991	.6602
4		.3361	.2427	.3547	.2801	.2172	.7545
5		.2427	.2427	.4108	.2987	.3258	1.0374
6		.3921	.3921	.4108	.3921	.4477	1.3957
7		.4668	.5121	.4481	.4108	.6443	1.3957
8		.6036	.4755	.5658	.5853	.6706	1.226
9	.4525	.3475	.4572	.5373	.5853	.583	1.0562
10	.8869		.6979	.4338	.6219	.7922	.4239
11	1.0269		.5658	.4527	.6602	.5093	.4359
12	.6161	.2772	.4338	.4338	.5658	.415	.3887
13	.4854	.499	.3772	.4338	.4715	.4904	.4096
14	.4481	.4435	.3584	.415	.4715	.5281	.4161
15	.4668	.4294	.4338	.4338	.3395	.5093	.4409
16	.6602	.5041	.3109	.4715	.3395	.5093	.4191
17	.7545	.6908	.3206	.6224	.4694	.6602	.3988
18	1.0374	.8299	.4904	.8488	.7167	.811	.7167
19	1.0751	.8488	1.0562	.8676	1.1883	.9431	.7922
20	.8488	.8488	.9997	.7356	.9431	1.0185	.9242
21	.6979	.1698	.8865	.6413	.7922	.7356	.8865
22	.6224	.6602	.811	.6036	.7545	.6602	.679
23	.5658	.6036	.7545	.5658	.6036	.6224	.6224
24	.2279	.5601	.2241	.1494	.1867	.1791	.5658
Max	1.0751	.8488	1.0562	.8676	1.1883	1.0185	1.3957
Min	.2279	.1698	.2241	.1494	.1867	.1791	.3887
Avg	.6795	.5070	.4889	.4827	.5130	.5361	.7173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 203 / Gadiwat

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5175	.3856	.3734	.2427	.3224	.5281
2		.462	.4031	.4668	.2614	.3403	.5658
3		.462	.4207	.5975	.2987	.3403	.6224
4		.4435	.4207	.6908	.2987	.3224	.6979
5		.4251	.4207	.7842	.3921	.362	.8488
6		.5304	.5434	.9335	.3921	.5552	.9431
7		.2743	.5083	1.1763	.5415	.7291	.9054
8		.4607	.5375	1.2449	.6283	.7545	.7922
9	.7701	.3403	.5487	.4527	.6468	.6706	.6413
10	.6335	.3582	.3772	.2263	.6602	.415	.373
11	.905	.2865	.2829	.2263	.547	.2452	.421
12	.5792	.2686	.2452	.1886	.5093	.1886	.4534
13	.543	.2507	.2452	.2263	.4527	.2263	.5079
14	.6516	.2149	.2263	.1886	.4338	.2263	.5441
15	.7602	.2149	.2829	.2829		.2452	.4755
16	.3801	.3018	.2829	.2263	.3772	.2452	.5117
17	.547	.3772	.3206	.3395	.3395	.415	.5407
18	.5847	.5658	.3772	.5281	.5281	.4904	.3395
19	.7356	.6036	.679	.547	.7922	.5847	.4527
20	.6413	.6413	.7167	.5847	.7167	.679	.6224
21	.5847	.6036	.6602	.6036	.6602	.6413	.6224
22	.5658	.5658	.6224	.5658	.6224	.5658	.6036
23	.5281	.547	.5093	.5281	.5847	.5658	.5847
24	.2507	.5175	.3856	.3326	.2427	.3224	.5281
Max	.905	.6413	.7167	1.2449	.7922	.7545	.9431
Min	.2507	.2149	.2263	.1886	.2427	.1886	.3395
Avg	.6038	.4264	.4334	.5131	.4856	.4355	.5886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044086 / 33/11KV Khodegaon

Feeder No / Name : 204 / 11 Kv Power Grid

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0017	.0581	.0476	.0381	
2			.0017	.0581	.0476	.0497	
3			.0017	.061	.0191	.0533	
4			.0017	.0465	.0048	.0434	
5			.0017	.0465	.0048	.0366	
6			.0029	.0118	.0048	.0295	
7			.0029	.0116	.0048	.0152	
8			.0467	.0002	.0124	.0152	
9			.0373		.0029	.0183	.0105
10					.0057	.0091	.0021
11	.0152					.0091	
12	.0152					.0091	.0053
13	.0152					.0076	
14	.0152					.0019	
15	.0152					.0019	.0059
16	.0152					.0019	.0057
17	.0152				.0029	.0238	
18	.0152				.0086	.0143	
19	.0152	.0011	.0116	.0143	.0053		
20	.0152	.0006		.0714	.0229		
21	.1372	.0017		.1	.0229		
22	.1115	.0017	.0002	.1143	.1509		
23	.0429	.0017	.0002	.1143	.0412		
24	.0051		.0017	.0581	.0476	.0427	
Max	.1372	.0017	.0467	.1143	.1509	.0533	.0105
Min	.0051	.0006	.0002	.0002	.0029	.0019	.0021
Avg	.0321	.0014	.0086	.0547	.0254	.0221	.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 201 / 11KV Hiwara

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2374	.2515	.2543	.1696	.2229	.4801
2	.1715	.2374	.3086	.2374	.1886	.2229	.4917
3	.2058	.2204	.3521	.2713	.2229	.2229	.5087
4	.2035	.2713	.3521	.3222	.2374	.2229	.5596
5	.2204	.4024	.4191	.407	.2713	.3052	.6613
6	.2543	.4409	.3856	.4527	.3561	.4409	.7969
7	.3018	.6613	.5197	.6706	.5868	.78	.7377
8	.3856	.6783	.6371	.8048	.4191	.8309	.57
9	.4287	.6104	.6706	.7716	.4527	.5765	.4578
10	.3185	.3052	.2347	.2515	.218	.2713	.4748
11	.2401	.2543	.2012	.1886	.1844	.1865	.5935
12	.218	.2543	.1865	.1844		.1865	.5658
13	.2012	.2374	.2012	.1844		.1844	.4973
14	.2401	.2374	.2204	.1886		.2012	.4801
15	.1844	.2204	.1865	.1844		.2012	.4287
16	.218	.2374	.2401	.218		.2035	.4801
17	.2347		.2572	.2374		.2204	
18	.3944	.2743	.3601	.3052		.3429	.3429
19	.5533	.4862	.5256	.5197	.6226	.6001	.5256
20	.5365	.503	.6104	.6036	.6371	.583	.4409
21	.5487	.4973	.5256	.4862	.5658	.5426	.5256
22	.4917	.4694	.4748	.4748	.4862	.5144	.5087
23	.4578	.4287	.4578	.4409	.463	.4973	.4748
24	.1886	.2374	.1341	.2543	.1865	.2229	.463
Max	.5533	.6783	.6706	.8048	.6371	.8309	.7969
Min	.1715	.2204	.1341	.1844	.1696	.1844	.3429
Avg	.3070	.3653	.3630	.3714	.3687	.3660	.5246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044100 / 33/11KV Hiwara

Feeder No / Name : 202 / 11KV KARMAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5256	.5365	.5426	.5087	.5487	.0394
2	.5316	.5087	.5487	.5426	.5487	.5658	.407
3	.5658	.5765	.5533	.5765	.5658	.6001	.4239
4	.6104	.788	.6371	.6443	.6104	.6687	.4748
5	.8139	.788	.8215	.78	.7461	.763	.5426
6	.9496	.9221	.8215	.9326	.9156	.8817	.5765
7	.8048	.5765	.788	.8048	.7712	.7969	.6706
8	.6539	.4748	.6371	.6203	.6874	.6613	.6036
9	.4973	.5426	.4191	.4973	.5197	.4748	.6783
10	.4359	.5197	.5868	.4862	.57	.5765	.3391
11	.3944	.5256	.5868	.6173	.503	.6783	.2035
12	.4359	.5765	.5765	.503	.6613	.6783	.2058
13	.4694	.5596	.6203	.5365	.6706	.7042	.1886
14	.463	.4917	.5935	.4973	.7042	.6874	.3086
15	.503	.4748	.5426	.4694	.6706	.6706	.3429
16	.4359	.5087	.5487	.5197	.6371	.6104	.2743
17	.4359	.4359	.5487	.5087	.503	.2204	.3258
18	.4287	.3086		.373	.3086	.3944	.3944
19	.6371	.4862	.6001	.6371	.6226	.6173	.5935
20	.5935	.503	.6783	.6539	.6874	.6516	.6443
21	.583	.5487	.6104	.5868	.6173	.6274	.5596
22	.5765	.5868	.5935	.5765	.6036	.6104	.6104
23	.5596	.5487	.5426	.5426	.5487	.583	.5935
24	.5487	.5256	.5533	.5256	.5256	.5487	.3772
Max	.9496	.9221	.8215	.9326	.9156	.8817	.6783
Min	.3944	.3086	.4191	.373	.3086	.2204	.0394
Avg	.5601	.5543	.6063	.5823	.6128	.6175	.4324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 201 / 11KV DUDHAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.503	.5138	.4973	.4973	.503	.4915	.4096
2	.5533	.547	.5304	.5304	.5365	.5243	.4096
3	.5868	.5801	.5801	.5801	.5868	.5407	.4049
4	.6706	.5967	.6299	.6133	.6706	.5735	.4096
5	.7956	.7459	.9116	.8383	.7545	.8288	.5243
6	1.094	1.0774	1.1904	1.1065	.8383	1.0774	.8288
7	1.0277	1.1271	1.1065	1.0898	.7956	1.1437	1.278
8	.8785	.9116	.9221	.8718	.663	.8951	1.3413
9	.6962	.7459	.7209	.7291	.547	.7625	1.166
10	.4475	.5801	.6133	.8139	.2721	1.0277	.5243
11	.547	.7127	.8122	1.0174	.2818	1.326	.3401
12	.4973	.7293	.8619	1.0682	1.2431	1.4586	.2881
13	.4973	.7127	.8288	1.1022	1.3923	1.442	.3401
14	.4807	.5281	.7459	1.1022	1.2431	1.3592	.2949
15	.5138	.6133	.8453	1.1022	.663	1.2431	.3401
16	.5801	.4973	.7842	1.0682	1.1603	1.1934	.2949
17	.4973	.5967	.8453	1.0898	1.2289	1.0159	.3605
18		.3605	.3978		.4424	.4144	.4144
19	.779	.5898	.8122	.7545	.6882	.7701	.663
20	.7293	.7373	.8288	.8718	.8684	.8886	.7459
21	.663	.663	.6962	.7042	.7373	.703	.7956
22	.6133	.5801	.5967	.6371	.6226	.6371	.6464
23	.5636	.547	.547	.7545	.5407	.5487	.5801
24	.5365	.5138	.5138	.5138	.5365	.5079	.4024
Max	1.094	1.1271	1.1904	1.1065	1.3923	1.4586	1.3413
Min	.4475	.3605	.3978	.4973	.2721	.4144	.2881
Avg	.6414	.6586	.7424	.8459	.7423	.8906	.5751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

AURANGABAD R-II S/D[400] BU 2267

Substation No/ Name :- 044101 / 33/11KV Bhambarda

Feeder No / Name : 202 / 11KV GEORAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.5596	.6104	.7291	.8478	.9088	.7545
2	.7122	.5935	.6274	.763	.9156	.9602	.8059
3	.7291	.6104	.6783	.8478	1.0174	.9945	.9724
4	.763	.6274	.7122	.9156	1.153	1.0631	1.0059
5	.7969	.763	.8916	1.3717	1.3226	1.3717	1.0395
6	1.0174	1.1022	1.0288	1.5604	1.7295	1.8519	1.1603
7	1.2209	1.2887	1.5939	2.2805	2.6282	2.8635	.9175
8	1.1736	1.4413	1.7295	2.4863	2.6825	2.8978	.8886
9	1.1736	1.17	1.6278	2.1704	2.5652	2.6749	.5658
10	.4024	.4191	.3222	.3561	.3856	.4115	1.8107
11	.2374	.3521	.2543	.3052	.285	.3222	2.3663
12	.2713	.3018	.3052	.3052	.218	.3052	2.3137
13	.2204	.3018	.2543	.2543	.2743	.3052	2.3137
14	.2374	.3018	.2713	.2543	.3258	.3052	.6516
15	.2543	.3353		.2713	.3086	.3391	1.8107
16	.3561	.285	.3688	.2543	.3258	.2713	1.7695
17	.4239	.3521	.3353	.3391	.3429	.2949	2.431
18	.6104	.3688	.4359	.39	.463	.4144	.3222
19	.8987	.6539	.8648	.8648	.7888	.8848	.7291
20	.9156	.8817	.9156	.9835	1.0288	.8886	.9326
21	.8478	.8139	.8309		.8916	.8573	.8478
22	.78	.78	.78	.8139	.8573	.788	.8817
23	.7461	.7291	.7291	.763	.7888	.7716	.8478
24	.6274	.5596	.5935	.6952	.7969	.8402	.7377
<b>Max</b>	<b>1.2209</b>	<b>1.4413</b>	<b>1.7295</b>	<b>2.4863</b>	<b>2.6825</b>	<b>2.8978</b>	<b>2.431</b>
<b>Min</b>	<b>.2204</b>	<b>.285</b>	<b>.2543</b>	<b>.2543</b>	<b>.218</b>	<b>.2713</b>	<b>.3222</b>
<b>Avg</b>	<b>.6706</b>	<b>.6497</b>	<b>.7287</b>	<b>.8685</b>	<b>.9560</b>	<b>.9827</b>	<b>1.2032</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 201 / BIDKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0857	.1372	.1017		.1543	.0686
11	.1029	.1372	.1357	.1029	.1543	.0686
12	.12	.0686	.1017	.0686		.0686
13	.12	.1029	.1017	.1029	.1715	.2058
14	.1029	.0686	.1017	.1372	.1715	.2401
15	.0857	.1372	.1017	.1715	.1715	.1715
16	.0857	.1029	.1357	.1715	.1886	.2058
17	.0686	.1372	.1017	.2058	.2058	.1715
21					.0943	
22					.1886	
Max	.12	.1372	.1357	.2058	.2058	.2401
Min	.0686	.0686	.1017	.0686	.0943	.0686
Avg	.0964	.1115	.1102	.1372	.1667	.1501



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 202 / INDUSTRIAL STONE CRUSHER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0857	.1029	.3391	.1372	.2572	.1372
2	.0686	.0857	.1372	.1696	.1715	.2572	.1715
3	.0686	.0857	.1029	.2713	.2058	.2915	.2058
4	.0686	.1029	.1372	.3052	.2401	.3258	.1715
5	.1029	.1029	.1029	.3391	.1715	.3429	.2058
6	.1372	.1029	.1029	.3052	.2058	.3944	.1715
7	.0686	.1029	.0686	.1696	.0686	.1715	.0686
8	.0686	.0857	.0686	.1696	.0686	.1372	.0686
9	.1372	.0857	.1372	.1357	.0686	.1886	.0686
10	.12	.1029	.1017	.1029	.12	.0686	.1357
11	.2572	.1372	.1017	.1372	.12	1.4403	.4409
12	.3944	.1372	.1357	.1715	.12	.0686	.5087
13	.3944	.1715	.1696	.2401	.12	.1715	.373
14	.3772	.2058	.1696	.2401	.12	.2058	.373
15	.3772	.1715	.3391	.2743	.2058	.1715	.1696
16	.1886	.1372	.2035	.2058	.2915	.2058	.2713
17	.3601	.0686	.407	.2401	.3944	.2401	.2374
18	.463	.1372	.2713	.1715	.4115	.1715	.5087
19	.4115	.1029	.3391	.2058	.2915	.2058	.3052
20	.3258	.0686	.1357	.1715	.1715	.2401	.2374
21	.2915	.0686	.1017	.1715	.2401	.1715	.1696
22	.2572	.0686	.1017	.2058	.3086	.1029	.1696
23	.2058	.1029	.2035	.1372	.3429	.1372	.3052
24	.0686	.1715	.0686	.3391	.0686	.3086	.1029
Max	.463	.2058	.407	.3391	.4115	1.4403	.5087
Min	.0686	.0686	.0686	.1029	.0686	.0686	.0686
Avg	.2201	.1122	.1587	.2175	.1943	.2615	.2324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 203 / LAKHEGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.1715	.1715	.2035	.1715	.3772	.1715
11	.2229	.2058	.3052	.1372	.3772	.2058
12	.2743	.2401	.2713	.1029	.3772	.1372
13		.2058	.373	.1372	.3601	.1715
14	.1715	.2401	.3391	.1715	.3601	.2058
15	.2229	.3086	.3052	.1372	.3601	.2058
16	.2058	.2401	.3052	.2058	.3601	.2401
17	.2058	.2743	.6783	.2401	.3601	.2058
Max	.2743	.3086	.6783	.2401	.3772	.2401
Min	.1715	.1715	.2035	.1029	.3601	.1372
Avg	.2107	.2358	.3476	.1629	.3665	.1929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 204 / PANGRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.12	.1715	.2035			
2	.2058	.12	.1715	.2035			
3	.2401	.1543	.1372	.2035			
4	.2058	.1715	.1715	.2035			
5	.2401	.2058	.2058	.1696			
6	.3429	.2229	.1372	.2374			
7	.3086	.2401	.2058	.3052			
8	.2743	.2401	.2401	.2713			.0686
9	.2058	.2401	.2058	.2374	.1715	.1886	.0686
10							.0678
11							.2035
12							.3052
13							.2713
14							.2713
15							.4409
16							.3391
17							.373
24	.0686	.12	.2743	.1696			
Max	.3429	.2401	.2743	.3052	.1715	.1886	.4409
Min	.0686	.12	.1372	.1696	.1715	.1886	.0678
Avg	.2264	.1835	.1921	.2205	.1715	.1886	.2409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 205 / NILAJGAON Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1715	.1696	.1715	.1715	.1715
2	.0857	.2058	.1696	.2058	.1715	.2058
3	.1029	.2401	.1696	.1715	.1715	.2401
4	.12	.2743	.1696	.2401	.1715	.2743
5	.1372	.3086	.2374	.2058	.1715	.3086
6	.1543	.3429	.3391	.2401	.2401	.3086
7	.2572	.3772	.4409	.3772	.6173	
8	.2572	.3429	.5087	.4115	.7716	.2401
9	.2572	.1715	.5087	.3772	.7373	.2058
10						.2035
11						.5087
12						.6104
13						.6783
14						.6783
15						.6783
16						.6783
17						.5426
19						.5426
24	.0857	.1715	.1696	.1372	.0857	.1715
Max	.2572	.3772	.5087	.4115	.7716	.6783
Min	.0857	.1715	.1696	.1372	.0857	.1715
Avg	.1543	.2606	.2883	.2538	.3310	.4026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 207 / INDUSTRIAL BIDKIN  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.1715	.3391	.1715	.2572	.2058
2	.2743	.2401	.1715	.3052	.2058	.2572	.2401
3	.2401	.2401	.2058	.3052	.2401	.2572	.2058
4	.2743	.2743	.1715	.3052	.2743	.2915	.2743
5	.3086	.2915	.2058	.3052	.3086	.3258	.3086
6	.3429	.3086	.3086	.2713	.3429	.3429	.3086
7	.3086	.2915	.3772	.2035	.2401	.3429	.3429
8	.3429	.3429	.3429	.2035	.2058	.3258	.0686
9	.3086	.3944	.4115	.2374	.1715	.3601	.3429
10	.5316	.4115	.5087	.1715	.4973	.3429	.3391
11	.4973	.3429	.4748	.1372	.4973	.2401	.373
12	.463	.2401	.3391	.1715	.5144	.2058	.407
13	.4973	.3086	.373	.1372	.5316	.2058	.4409
14	.5316	.2401	.407	.1372	.5316	.2401	.4409
15	.5487	.1715	.407	.1715	.4973	.2058	.407
16	.5487	.2058	.407	.2058	.4801	.2401	.407
17	.5487	.2401	.3391	.1715	.463	.2058	.4409
18	.4973	.3086	.3391	.2058	.5144	.1715	.407
19	.4458	.3429	.3052	.2058	.4801	.4115	.4409
20	.3944	.3772	.3391	.2401	.4458	.3429	.407
21	.3429	.2058	.3391	.1715	.4458	.3086	.407
22	.3086	.3086	.3391	.2058	.4287	.4115	.407
23	.2743	.2401	.407	.2058	.4287	.3429	.373
24	.3429	.2401	.3086	.2883	.1715	.3429	.2401
Max	.5487	.4115	.5087	.3391	.5316	.4115	.4409
Min	.2401	.1715	.1715	.1372	.1715	.1715	.0686
Avg	.3922	.2836	.3333	.2209	.3787	.2908	.3431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 209 / BIDKIN Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.2003	1.0288	.9156	.9259	.9431	.9259
2	.9945	1.2003	1.166	.9835	.9945	.9431	.9945
3	1.2003	1.4746	1.2003	1.1869	1.166	1.2003	1.166
4	1.4746	1.7147	1.406	1.56	1.5432	1.5432	1.5432
5	1.7833	2.0233	2.0233	1.8652	1.8861	1.9033	1.8861
6	2.572	2.2291	2.7435	2.2043	1.6118	2.5892	2.7435
7	2.6063	2.2462	2.7435	2.4756	2.572	2.692	2.4006
8	2.2634	1.9376	1.8861	2.2721	2.572	2.4006	2.1262
9	1.9204	1.6289	1.3717	1.7974	2.2291	1.9719	1.6118
10	1.3546	1.2003	1.3565	1.5432	1.286	1.2003	1.3565
11	.9431	1.3717	.9156	.9979	1.1831	.8573	1.0852
12	.5316	.9602	.9156	.8916	1.0974	.823	
13	.6344	.8573	.8478	.823	1.0117	.8916	.6783
14	.7373	.9259	.9156	.823	.9259	.9259	.5087
15	.8402	.8916	.9156	.8916	1.0288	.8916	.5765
16	.8745	1.0288	.9156	.8916	1.1317	.9602	.9496
17	1.6289	1.2689	1.2209	.9602	1.2517	1.2003	.9496
18	1.869	1.4403	1.6617	1.922	1.5947	1.5432	.9496
19	1.7318	1.8861	2.2043	1.5432	1.6975	1.8861	1.8652
20	1.5947	1.6804	1.6617	1.6118	1.8004	1.5432	1.5939
21	1.5432	1.3717	1.4582	1.3717	1.5089	1.3717	1.3565
22	1.4746	1.2003	1.2548	1.2003	1.2174	1.0288	1.1869
23	1.3717	.9602	.9496	.9602	.9431	.8916	1.0174
24	.823	1.2003	.8916	.9156	.8573	.9431	.8573
Max	2.6063	2.2462	2.7435	2.4756	2.572	2.692	2.7435
Min	.5316	.8573	.8478	.823	.8573	.823	.5087
Avg	1.4010	1.4125	1.4023	1.3586	1.4182	1.3810	1.3187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044012 / 33 KV S/S BIDKIN

Feeder No / Name : 210 / Bidkin Town

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.3717	1.166	1.0174	1.0288	1.1145	.8916
2	1.0631	1.3717	1.2003	.9835	.9945	1.1145	1.0288
3	1.2689	1.749	1.3717	1.2548	1.2003	1.2003	1.2003
4	1.4403	2.0233	1.6118	1.3226	1.3717	1.286	1.4403
5	1.8861	2.0748	1.749	1.3565	1.5775	1.406	1.8861
6	2.1262	2.1091	2.0233	1.8313	1.8861	2.0233	2.0576
7	2.2291	2.3148	2.2291	2.2721	1.0288	2.0748	2.2291
8	2.0576	2.0919	1.8861	2.0348	2.0576	1.9033	2.0576
9	2.1262	1.8861	1.5432	1.7974	1.8861	1.8176	1.8861
10	1.6289	1.6118	1.5261	1.5432	1.5604	1.5432	1.7295
11	1.4232	1.3717	1.2887	1.6804	1.4575	1.4403	1.5261
12	1.2174	1.2003	1.1191	1.5432	1.3546		1.3226
13	1.1488	1.3717	1.0852	1.3717	1.2517		1.0174
14	1.0974	1.2689	1.0174	1.3375	1.1488		1.0174
15	1.046	1.3717	1.0513	1.2003	1.2517	1.3717	.9835
16	1.0631	1.6118	1.1191	1.3717	1.3717	1.5432	1.0174
17	1.3889	1.8861	1.2887	1.6118	1.4918	1.3717	
18	1.6118	1.5432	1.4243	1.989	1.6461	1.5432	1.7295
19	1.6632	1.4403	1.933	1.749	1.7661	1.8861	2.0687
20	1.7147	1.5775	1.8313	1.7147	1.8861	1.749	1.56
21	1.6461	1.3717	1.5261	1.5432	1.6461	1.6804	1.4582
22	1.5432	1.2689	1.3226	1.3717	1.406	1.0288	1.3226
23	1.4746	1.0631	1.1191	1.0288	1.166	1.0631	1.153
24	.8916	1.3717	1.0288	1.0174	.9945	1.1145	1.0288
Max	2.2291	2.3148	2.2291	2.2721	2.0576	2.0748	2.2291
Min	.8573	1.0631	1.0174	.9835	.9945	1.0288	.8916
Avg	1.4839	1.5968	1.4359	1.4977	1.4346	1.4893	1.4614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 201 / 11 KV PACHOD GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 / OUTGOING

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
1		.5716
2		.5716
3		.6859
4		.9145
5		1.105
9		.9526
10	.9145	.8764
11	.7621	
12	1.0669	
13	.5716	
14	.5335	
15	.4572	
16	.6859	
17	.7621	
18	.8764	
19	.9526	
20	.7621	
21	.724	
22	.6859	
23	.5716	
24	.5335	
Max	1.0669	1.105
Min	.4572	.5716
Avg	.7240	.8111



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 202 / 11 KV KADETHAN AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17
HR	Load (MW)	Load (MW)
1		.1524
2		.1524
3		.1524
10	.724	.9526
11	.9907	
12	1.0669	
13	1.1431	
14	1.105	
15	1.1431	
16	1.1812	
17	1.0669	
18	.1524	
19	.2286	
20	.2667	
21	.2667	
22	.3048	
23	.3048	
24	.1905	
<b>Max</b>	<b>1.1812</b>	<b>.9526</b>
<b>Min</b>	<b>.1524</b>	<b>.1524</b>
<b>Avg</b>	<b>.6757</b>	<b>.3525</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 203 / 11 KV MURMA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 204 / 11 KV COTTON MILL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 205 / 11 KV MURMA GAONTHAN

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044014 / 33 KV PACHOD SUB STN

Feeder No / Name : 207 / 11 KV PACHOD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 201 / 11 KV VIHAMANDWA FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
18	.4763
Max	.4763
Min	.4763
Avg	.4763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 202 / 11 KV CHONDHALA FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 203 / Hiradpuri  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 204 / Vihamandava Gaothan feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	1.3336
Max	1.3336
Min	1.3336
Avg	1.3336

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 205 / Navgaon Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044032 / VIHAMANDAVA 33 KV

Feeder No / Name : 206 / Navgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
18	.9526
Max	.9526
Min	.9526
Avg	.9526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 201 / BARANAGAR I

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0747	.0747	.0934	.0934	.0943	.0943
2	.0934	.0747	.0747	.1494	.1509	.1296	.0943
3	.0934	.1307	.1307	.168	.1867	.1619	.0943
4	.0934	.1307	.168	.1867	.2241	.2105	.0943
5	.0934	.1867	.2427	.2075	.2614	.2439	.0943
6	.1307	.2241	.3174	.3921	.4668	.503	
7	.2241	.4294	.3734	.4668	.5601	.6097	
13							.5182
14							.6706
15							.6401
16							.6097
17							.5792
18							.4572
20	.112	.0934	.1494	.0934	.0943	.1132	.0943
21	.0934	.0934	.1494	.0934	.0943	.0943	.0943
22	.0747	.0934	.112	.0934	.0943	.0943	.0943
23	.0747	.0934	.0934	.0934	.0943	.0943	.0943
24	.0934	.0747	.0747	.9526	.0934	.0943	.0943
Max	.2241	.4294	.3734	.9526	.5601	.6097	.6706
Min	.0747	.0747	.0747	.0934	.0934	.0943	.0943
Avg	.1058	.1416	.1634	.2492	.2012	.2036	.2761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 202 / BARANAGAR II

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307	.1307	.1307	.1307	.1132	.1132
2	.112	.1307	.1307	.1307	.1307	.1132	.1943
3	.112	.1307	.1307	.1307	.1307	.1132	.0486
4	.112	.1307	.1307	.1307	.1307	.1132	.4725
5	.112	.1307	.1307	.1307	.1307	.1132	.4725
6		.1307					.7011
7							.8383
13	.2801	.6535	.8029	1.2136	.9907	1.2803	
14	.6161	.6535	.9335	1.1203	1.1279	1.3108	
15		.7468	1.0269	1.307	1.1888	1.3565	
16	.4668	.6908	1.0829	1.307	1.2651	1.387	
17	.5228	.6535	1.0269	1.251	.8383	1.2041	
18	.4668	.5601	.8402	1.0269	.9145	.9907	
20	.112	.1307	.1307	.1307	.0943	.0943	.1132
21	.112	.1307	.1307	.1307	.0943		.0943
22	.1307	.1307	.1307	.1307	.0943	.0943	.0943
23	.1307	.1307	.1307	.1307	.0943	.1132	.0943
24	1.475	.1307	.1307	.1307	.1307	.1132	.1132
<b>Max</b>	<b>1.475</b>	<b>.7468</b>	<b>1.0829</b>	<b>1.307</b>	<b>1.2651</b>	<b>1.387</b>	<b>.8383</b>
<b>Min</b>	<b>.112</b>	<b>.1307</b>	<b>.1307</b>	<b>.1307</b>	<b>.0943</b>	<b>.0943</b>	<b>.0486</b>
<b>Avg</b>	<b>.3249</b>	<b>.3174</b>	<b>.4388</b>	<b>.5333</b>	<b>.4679</b>	<b>.5674</b>	<b>.2792</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 203 / 11 KV KAPUS WADI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.0934	.0934	.0943	.0943
2	.0373	.0373	.0373	.0934	.0934	.0943	.0943
3	.0373	.0373	.0373	.0934	.0934	.0943	.0943
4	.0373	.0373	.0373	.0934	.0934	.0943	.0943
5	.0373	.0373	.0373	.0934	.0934	.0943	.0943
6	.0373	.0373					
7	.0934						
8	.2054	.2801	.3734	.4108	.3361	.2896	
9	.2241	.2801	.3921	.3734	.3734	.3506	
10	.2241	.3361	.3361	.4108	.4668	.3963	
11	.1867	.4668	.3174	.3734	.4854	.3506	
12	.1307	.3734	.3174	.3772	.3506	.381	
19							.4572
20	.0373	.0373	.0934	.0747	.0943		.381
21	.0373	.0373	.0934	.0934	.0943		.3353
22	.0373	.0373	.0934	.0934	.0934		.3201
23	.0373	.0373	.0934	.0943	.0943	.0943	.3201
24	.0373	.0373	.0373	.0934	.0934	.0943	.0943
Max	.2241	.4668	.3921	.4108	.4854	.3963	.4572
Min	.0373	.0373	.0373	.0747	.0934	.0943	.0943
Avg	.0867	.1342	.1556	.1908	.1966	.2024	.2163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 204 / 11 kv Balanagar Gaothan GAOTHAN FEEDER  
feeder Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.9709	.9335	.8589	.8589	.8962	.8962
2	.8402	.9709	1.0269	1.0269	1.0269	.9335	.9149
3	.8402	.9709	1.2136	1.2136	1.2136	1.0269	.9522
4	.8402	1.307	1.4937	1.4937	1.6804	1.2323	1.2136
5	.8402	1.7737	1.9605	1.7737	2.0165	1.8111	1.8111
6	1.2136	2.2965	2.4832	2.5766	2.3899	2.4832	2.4646
7	1.1576	2.1472	2.2405	2.0351	2.1658	2.4459	2.1845
8	1.0269	2.2032	1.9978	1.9231	2.0538	2.2405	2.0165
9	1.0829	1.8671	1.7737	1.7737	1.6804	1.9978	1.7177
10		1.6057	.9896	1.2136	1.3256	1.4003	1.307
11	.6535	1.2136	.9335	.9335	.8029	.9522	.8215
12	.8775	1.1203	.6535	.6908	.7655	.7655	.6535
13	.8775	1.0269	.5601	.6535	.7842	.7468	.6161
14		.9335	.5975	.5975	.7655	.7545	.5975
15	.9335	.8775	.6722	.6722	.8589	.8402	.6535
16	1.307	.9335	.7842	1.0269	1.0082		.8589
17	1.7364	1.2136	1.1203	1.1203	1.1949	1.2883	1.0829
18	1.9231	1.4937	1.531	1.5123	1.6244	1.7177	1.3443
19	1.8671	1.8671		1.8671	2.0911	2.1285	1.9231
20	1.4003	***	1.7551	1.2323	1.8671	1.6804	1.5123
21	1.1576	1.1203	1.2136	1.1576	1.363	1.1949	1.1389
22	1.0269	1.0269	1.1203	.9335	1.0642	1.0082	.9709
23	1.0082	.9335	.8962	.9335	.9149	.9149	.8962
24	.8402	.9709	.8775	.8775	.8402	.8962	.8962
Max	1.9231	14.302	2.4832	2.5766	2.3899	2.4832	2.4646
Min	.6535	.8775	.5601	.5975	.7655	.7468	.5975
Avg	1.1041	1.8811	1.2534	1.2541	1.3482	1.3633	1.2268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 205 / Ginning

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1307	.1307	.112	.168	.1509	.1132
2	.1307	.1307	.1307	.1867	.168	.1509	.1132
3	.1307	.1307	.1307	.1867	.1494	.1509	.1132
4	.1307	.1307	.1307	.1867	.1494	.1509	.1132
5	.1307	.1307	.1307	.1867	.1494	.1509	.1132
6	.168	.1307	.1307	.2427	.1494	.1698	.1886
7	.2054	.1867	.1867	.2054	.1867	.1509	.1886
8	.2054	.2054	.168	.2427	.1886	.2075	.2452
9	.2427	.2427	.2054	.2801	.2054	.3206	.2452
10	.2241	.2614	.2241	.3361	.2641	.3018	.2263
11	.2054	.2987	.2987	.2801	.2987	.2829	.1886
12	.2614	.2427	.2427	.1867	.2641	.2641	.2263
13	.2801	.2801	.2427	.2801	.2452	.2452	.2452
14	.2801	.2614	.2427	.3361	.2452	.2452	.2641
15	.2987	.2987	.2427	.3361	.2829	.2452	.1886
16	.2241	.2987	.2427	.2987	.2829	.2452	.1886
17	.2054	.2614	.2054	.2801	.2452	.2263	.1886
18	.2054	.2054	.1867	.2427	.2075	.2075	.2075
19	.2054	.168		.2054	.2075	.2263	.2075
20	.168	.168	.1867	.1867	.2075	.2263	.1886
21	.168	.2054	.1867	.1867	.1698	.1886	.1509
22	.1307	.1867	.1494	.1494	.1698	.1698	.1698
23	.1307	.1494	.1307	.1509	.1698	.1509	.1698
24	.1494	.1307	.1307	.112	.168	.1509	.132
Max	.2987	.2987	.2987	.3361	.2987	.3206	.2641
Min	.1307	.1307	.1307	.112	.1494	.1509	.1132
Avg	.1922	.2015	.1851	.2249	.2059	.2075	.1823



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044041 / BALANAGAR

Feeder No / Name : 206 / kherda

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.056	.056		.056	.0566	.0566
2		.056	.056		.056	.0566	.0566
3		.056	.056		.056	.0566	.0566
4		.056	.056		.056	.0566	.0566
5		.056	.056		.056	.0566	.0566
6		.056					
8							.5944
9							.503
10							.4572
11							.5944
12							.6554
18	.2054						
19	.4854	.6161		.5601	.7621	.3658	
20	.5041	.6161		.5658	.6097	.4725	.0566
21	.5228	.6535	.056	.5601	.5792	.4572	.0566
22	.5228	.6161	.056	.5601	.5639	.6401	.0566
23	.5041	.5601	.056	.5658	.5335	.6097	.0377
24		.056	.4294		.056	.0566	.0566
Max	.5228	.6535	.4294	.5658	.7621	.6401	.6554
Min	.2054	.056	.056	.5601	.056	.0566	.0377
Avg	.4574	.2878	.0975	.5624	.3077	.2623	.2234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 201 / 11 KV LOHAGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8							1.5242
9							1.5242
11							1.3546
12							1.1736
13							1.0669
14							1.2003
15							1.2403
16	.6668	.0469	.5716	.9335	.9717	1.5242	1.2403
17	.6668	.503	.6668	1.1203	1.6194	1.5242	
18	.6668	.4858			1.6194	1.5242	
19	.6668	.4858			1.6194	1.5242	
20	.6668	.4858			1.2955	1.3336	
21	.6668	.4858			1.4575	1.2384	
22		.4858				1.2384	
23		.5668	.6668		1.2146	1.2384	
Max	.6668	.5668	.6668	1.1203	1.6194	1.5242	1.5242
Min	.6668	.0469	.5716	.9335	.9717	1.2384	1.0669
Avg	.6668	.4432	.6351	1.0269	1.3996	1.3932	1.2906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 202 / 11 KV DHAKEPHAL FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3239	.5716	.4668	.4858	
2	.381	.3239	.5716	.4934	.4858	
3	.381	.3239	.5716	.4934	.4858	
4	.4763	.4049	.6668	.4801	.5668	
5	.4763	.4049	.6668	.4001	.6478	
6	.4763	.4858	.6668	.5335	.7287	
7	.5716	.4858	.7621	.7068	.8097	
14					.7621	
15					.7621	
16						1.2003
17						1.4803
18						1.1603
24	.381	.3239	.5716	.4668	.4858	
Max	.5716	.4858	.7621	.7068	.8097	1.4803
Min	.381	.3239	.5716	.4001	.4858	1.1603
Avg	.4406	.3846	.6311	.5051	.6220	1.2803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 203 / 11 KV TONDOLI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0953
2							.0953
3							.0953
4							.0953
5							.0953
6							.0953
7							.0953
8		.4763		.5716	.3467	.3239	
9		.4763		.5716	.3601	.4049	
10			.3239	.5716	.4858	.4858	
11	.1334	.3239	.381		.4858	.7621	
12	.1334	.3239	.4763		.5668	.9526	
13	.1524	.3239	.4763		.6478	1.0479	
14	.1524	.3239	.4763		.7545	1.0479	
15		.3353	.5335		.6478	1.0479	
24							.0953
Max	.1524	.4763	.5335	.5716	.7545	1.0479	.0953
Min	.1334	.3239	.3239	.5716	.3467	.3239	.0953
Avg	.1429	.3691	.4446	.5716	.5369	.7591	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 204 / 11 KV BRAMHAGAWAN FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0953	.1905	.1905	.1048	.2267	
2	.1334	.0953	.1905	.1905	.1467	.2267	
3		.0953	.6668	.2286	.1153	.2429	
4		.0953	.1905	.2286	.1257	.2429	
5		.0953	.1905	.2286	.1362	.2429	
6			.1905	.2858	.1467	.3239	
7		.1334	.1905	.2858	.1572	.3353	
8						.3239	.1905
9							.381
10							.4001
11							.4268
12							.4801
13							.4001
14							.4268
15							.4534
24	.1734	.0953	.1905	.1905	.1048	.2267	
Max	.1734	.1334	.6668	.2858	.1572	.3353	.4801
Min	.1334	.0953	.1905	.1905	.1048	.2267	.1905
Avg	.1467	.1007	.2500	.2286	.1297	.2658	.3949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 205 / 11 KV VIJAYPUR FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.5716	.4858	.8573	.9374	1.5242	.9335
17		.4858	.8954	1.1336	1.5242	1.1336
18	.381	.4049	.8573	1.1429	1.5623	1.1336
19	.381	.4049	.8573	1.1336	1.4289	
20	.381	.3887	.8573	1.1336	1.4289	
21	.381	.4049	.8573	1.1336	1.3336	
22		.4049	.8002	.9717	1.3336	
23		.4049	.7621	.9717	1.2384	
Max	.5716	.4858	.8954	1.1429	1.5623	1.1336
Min	.381	.3887	.7621	.9374	1.2384	.9335
Avg	.4191	.4231	.8430	1.0698	1.4218	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 206 / 11 kv Lohgaon Gaothan  
feeder Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4816	.9526	.6478	.7621	.6472	.6478	.7621
2	.5117	1.1431	.6478	.9526	.6472	.6478	1.1431
3	.5268	1.7147	.6478	1.3336	.7526	.6478	1.1431
4	.6773	1.9052	.8097	1.7147	.8278	.7287	1.1431
5	1.0536	2.0957	.9717	1.9052	1.0536	.9717	1.3336
6	1.2041	2.2862	1.4575	2.0957	1.5202	1.2955	1.7147
7	1.3546	2.0957	1.7814	2.0957	1.7158	1.6194	2.0957
8	1.7459	2.0005	1.6194	1.9052	1.6707	1.6194	2.0957
9	1.3847	1.9052	1.4575	1.8099	1.5202	1.6194	1.9052
10			1.4575	1.4289	.8097	1.4575	.9031
11	.8573		1.3336		.8097	1.3336	.7526
12	.7621		1.1431		.9717	1.1431	.6321
13	.7621		.9526		.7773	.7621	.602
14	.6668				.6478		.602
15	.6668				.6478		.6321
16	.7621		.7621		.8097	1.1431	.7526
17	.8573		.8573		.9717	1.2384	.8429
18	.9526		1.1431		1.2955	1.3336	.9633
19	1.1431		1.1431		1.4575	1.3336	
20	1.1431		.9526		1.6194	1.2384	
21	.9526		.9526		.9717	1.1431	
22		1.1336	.8573		.9717	.9526	
23		.6478	.7621		.6802	.7621	
24	.4816	.7621	.6478	.7621	.6472	.6478	.7621
Max	1.7459	2.2862	1.7814	2.0957	1.7158	1.6194	2.0957
Min	.4816	.6478	.6478	.7621	.6472	.6478	.602
Avg	.9023	1.5535	1.0457	1.5242	1.0185	1.1039	1.0937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 207 / 11 KV Segenta  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0524	.0953	.081	.0953	.0572	.084	.0953
2	.0524	.0953	.081	.0953	.0572	.0838	.0953
3	.0476	.0953	.0812	.0953	.0572	.081	.0953
4	.0524	.0953	.081	.0953	.0524	.081	.0953
5	.0524	.0953	.081	.0953	.0524	.081	.0953
6	.0524	.0953	.081	.0953	.0629	.081	.0953
7	.0572	.2858	.081	.0953	.0629	.081	.0953
8	.0524		.0972	.1905	.0629	.2429	.381
9		.381	.3239	.4763	.241	.2105	.4763
10			.4049	.4763	.4858	.3239	.3248
11	.2858	.3239	.4763		.4858	.4763	.3144
12	.2858	.4049	.5716		.4858	.4763	.3144
13	.2477	.4049	.5716		.4858	.5144	.3144
14	.2286	.4049	.6287		.4534	.5335	.3144
15	.4572	.4049	.6287		.4858	.5525	.4967
16	.381	.4049	.4763		.4049	.4763	.3144
17	.2477	.1509	.1524		.1134	.381	.1257
18	.1905	.081	.0953		.081	.1524	.0838
19	.1905	.081	.0953		.081	.0953	
20	.1524	.081	.0953		.0791	.0953	
21	.1524	.081	.0953		.081	.0953	
22		.081	.0953		.081	.0953	
23		.081	.0953		.081	.0953	
24	.0629	.0953	.081	.0953	.0629	.0812	.0953
Max	.4572	.4049	.6287	.4763	.4858	.5525	.4967
Min	.0476	.081	.081	.0953	.0524	.081	.0838
Avg	.1651	.1963	.2313	.1732	.1939	.2279	.2222



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044047 / LOHAGAON 33KV

Feeder No / Name : 208 / 11 KV Gadegaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.2858
2							.2858
3							.2858
4							.2858
5							.2858
6							.2858
7							.3429
8	.2	.1524	.1619	.5716	.4001	.2267	
9	.1734	.1524	.1619	.5716	.4001	.3239	
10			.1943	.5716	.3239	.4858	
11	.2286	.1296	.2286		.2096	.5716	
12	.2286	.1134	.2858		.3239	.5716	
13	.2286	.1134	.2858		.2915	.6287	
14	.2286	.1174	.2858			.5716	
15	.2477	.1134	.2858			.5716	
24							.2858
Max	.2477	.1524	.2858	.5716	.4001	.6287	.3429
Min	.1734	.1134	.1619	.5716	.2096	.2267	.2858
Avg	.2194	.1274	.2362	.5716	.3249	.4939	.2929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 201 / 11 KV HARSHI AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572	.0572	.0572	.0572	.0572
2		.0572	.0572	.0572	.0572	.0572	.0572
3		.0572	.0572	.0762	.0572	.0381	.0572
10		.2286	.2606	.1781	.2286	.3429	
11			.208	.2675	.3048	.2606	
12		.381	.1738	.3239	.3429	.2606	
13		.3239	.1783		.381	.2896	
14	.1905	.3239	.208		.3429	.2462	
15		.3048	.2317	.4001	.381	.3521	
16		.3048	.2462	.4001	.381	.3048	.0191
17	.2286	.3048	.2675	.362	.3429	.4191	.0381
18	.0762	.0381	.0572	.0381	.0572	.0762	.0381
19	.0572	.0572	.0572	.0572	.0572	.0762	.0762
20	.0572	.0762	.1143	.0381	.0762	.0953	.0762
21	.0381	.0762	.0762	.0381	.0572	.0762	.0762
22	.0381	.0572	.0762	.0381	.0572	.0762	
23	.0572	.0572	.0762	.0572	.0572	.0762	
24		.0572	.0572		.0572	.0572	
Max	.2286	.381	.2675	.4001	.381	.4191	.0762
Min	.0381	.0381	.0572	.0381	.0572	.0381	.0191
Avg	.0929	.1625	.1367	.1593	.1831	.1757	.0551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 202 / 11KV DADEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.2858	.1829	.1905	.2096	.1802
2		.1905	.3048	.1829	.2477	.2477	.1781
3		.2286	.3429	.208	.2858	.2858	.192
4		.2667	.3429	.2229	.3048	.3429	.208
5		.362	.381	.2378	.362	.381	.2187
6		.4572	.4572	.2675	.4001	.4001	.3521
7		.6668	.724	.4923	.7049	.8764	.5068
8		.6859	.6478	.6226	.9335	.9335	.6081
9		.6478	.8192	.6516	.8002	.9717	.6081
10							.6371
11							.6097
12							.8764
13							.9526
16	.0572	.0381	.0381	.0572	.0381		
17		.0381	.0381	.0572	.0381	.0381	
18	.0762	.0762	.0762	.0762	.0381	.0381	.0762
19	.1524	.1334	.1334	.1334	.0762	.1307	.1524
20	.1143	.1334	.1524	.1143	.0762	.1494	.1524
21	.0762	.1524	.1307	.1143	.0762	.1494	.1715
22	.0953	.1143	.0953	.1143	.0762	.1143	
23	.0953	.0953	.0762	.1143	.0572	.0747	
24		.2286	.1505		.1524	.1677	
Max	.1524	.6859	.8192	.6516	.9335	.9717	.9526
Min	.0572	.0381	.0381	.0572	.0381	.0381	.0762
Avg	.0953	.2614	.2887	.2265	.2699	.3242	.3930

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 203 / 11KV KUTUBKHEDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0381	.0381	.0572	.0572	.0381
2		.0572	.0381	.0381	.0572	.0762	.0381
3		.0762	.0381	.0381	.0572	.0762	.0381
10		.1143	.0892	.0526	.1143	.1143	
11		.1905	.1143	.1017	.2286	.1928	
12		.1905	.1075	.1334	.2096	.2229	
13		.1524	.0914	.1143	.1524	.2328	
14		.1524	.1075	.1334		.1886	
15		.1524	.0892	.1715		.1886	
16		.1524	.0914	.1524		.1886	.0191
17	.0572	.1524	.12	.1524		.1677	.0191
18	.0381	.0191	.0183	.0381	.0191	.0381	.0191
19	.0762	.0191	.0358	.0381	.0381	.0335	.0191
20	.0762	.0381	.0381	.0381	.0381	.0343	.0381
21	.0381	.0381	.0362	.0381	.0572	.0335	.0381
22	.0381	.0381	.0572	.0381	.0572	.0381	
23	.0381	.0381	.0572	.0381	.0572	.0381	
24		.0381	.0373		.0381	.0381	
Max	.0762	.1905	.12	.1715	.2286	.2328	.0381
Min	.0381	.0191	.0183	.0381	.0191	.0335	.0191
Avg	.0517	.0931	.0669	.0797	.0844	.1089	.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 204 / 11KV DAWARWADI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.1905	.2286	.1334	.1905	.1943
2	.0953	.1143	.1905	.2286	.1524	.1905	.192
3	.0953	.1524	.2096	.2378	.1715	.2096	.192
4	.1143	.2286	.2096	.2378	.1905	.2286	.1981
5	.1334	.2667	.2286	.2343	.1905	.2858	.1981
6	.1715	.3239	.2286	.2526	.2096	.3239	.208
7	.1905	.381	.381	.3048	.362	.4001	.2972
8	.2286	.4382	.4382	.3269	.4191	.4382	.3361
9	.2477	.3429	.4191	.3715	.362	.4001	.3121
10							.3418
11							.4572
12							.5335
13							.5525
14							.5716
15							.6097
16	.0381	.0191	.0191	.0191	.0381	.0191	.5906
17		.0191	.0191	.0191	.0381	.0191	.5335
18	.0381	.0191	.0381	.0191	.0381	.0191	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0191	.0381	.0572	.0381
21	.0572	.0381	.0377	.0191	.0381	.0381	.0572
22	.0381	.0381	.0381	.0191	.0381	.0572	
23	.0572	.0191	.0381	.0191	.0381	.0381	
24	.0953	.1905	.2286		.1334	.2012	
Max	.2477	.4382	.4382	.3715	.4191	.4382	.6097
Min	.0381	.0191	.0191	.0191	.0381	.0191	.0381
Avg	.1042	.1545	.1662	.1526	.1461	.1753	.3090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 205 / 11 KV NANDAR AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0572	.0572	.0572	.1143	.0572
2	.0572	.0572	.0572	.0572	.0572	.1143	.0572
3	.0572	.0762	.0572	.0572	.0572	.0953	.0762
10		.0762	.1067	.1448	.1905	.2286	
11		.2096	.0869	.1448	.1715	.213	
12	.0762	.2096			.1524	.2606	
13		.1334	.1303			.2526	
14	.0953	.1143	.1067		.1905	.2785	
15		.1143	.112	.1715	.2096	.2675	
16	.1143	.1143	.104	.1715	.1715	.2713	.0191
17	.1524	.0953	.1219	.1524	.1905	.2591	.0381
18	.0762	.0191	.0381	.0572	.0572	.0566	.0381
19	.0762	.0381	.0572	.0572	.0572	.0566	.0762
20	.0762	.0572	.0762	.0572	.0762	.0747	.0762
21	.0572	.0762	.0747	.0572	.0762	.0747	.0762
22	.0572	.0762	.056	.0572	.0762	.0747	
23	.0762	.0762	.056	.0572	.0762	.0747	
24	.0191	.0572	.0572		.0572	.0566	
Max	.1524	.2096	.1303	.1715	.2096	.2785	.0762
Min	.0191	.0191	.0381	.0572	.0572	.0566	.0191
Avg	.0749	.0932	.0797	.0928	.1132	.1569	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 206 / 11 KV GFSS-I

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4001	.4954	.4191	.3048	.4191	.4572	.3125
2	.4763	.5335	.4382	.3437	.4572	.5335	.3353
3	.5525	.6287	.4954	.3658	.5525	.5716	.4161
4	.6668	.8002	.6478		.6668	.6097	.5053
5	.8573	.9717	.8192	.6241	.8573	.9145	.6081
6	1.2574	1.3146	1.1241	.8916	.9526	1.2384	.9869
7	1.3527	1.3336	1.1431	1.0856	1.2384	1.448	1.001
8	1.1812	1.3908	.9145	.8543	1.0098	1.3717	.9362
9	.8764	.9907	.743	.7876	.9717	1.2574	.8916
10		.9907	.4572	.5792	.724	.724	.6249
11		.7811	.4534	.503	.6097	.5407	.3048
12	.381	.8192	.4531	.2858	.4954	.4531	.2858
13		.8002	.381	.2667	.4954	.3688	.2096
14	.4954	.8002	.3681	.362	.4001	.3681	.4382
15		.7811	.3658	.4382	.3429	.3658	.381
16	.5906	.8002	.4115	.4954	.362	.4161	.4572
17	.8002	.8002	.6154	.6668	.4191	.5944	.6287
18	1.105	.8764	.6539	.8954	.4954	.724	.8954
19	.8954	.9145	.8322	1.0479	.724	.8882	1.1241
20	.743	.8192	.6687	.8002	.9145	.6554	.8002
21	.6287	.6478	.4904	.6478	.8002	.4904	.6668
22	.5716	.5716	.5716	.6097	.6859	.4572	
23	.5144	.4954	.3906	.5335	.4954	.3963	
24	.4191	.4572	.3563		.4572	.3605	
Max	1.3527	1.3908	1.1431	1.0856	1.2384	1.448	1.1241
Min	.381	.4572	.3563	.2667	.3429	.3605	.2096
Avg	.7383	.8256	.5922	.6086	.6478	.6752	.6100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044053 / DAWARWADI 33KV

Feeder No / Name : 207 / 11 KV GFSS-II FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2667	.3048	.2439	.2858	.2667	.2683
2	.3429	.2667	.3239	.2743	.3239	.3048	.2622
3	.4191	.362	.381	.3048	.381	.3429	.2812
4	.5716	.5716	.4572	.3864	.5335	.4954	.3658
5	.743	.8573	.6859	.5944	.5906	.6097	.503
6	1.086	1.0669	.9526	.7095	.724	.9145	.6081
7	1.105	1.0288	.8573	.7529	.9145	.9526	.7727
8	1.0479	.9717	.9335	.5792	.7621	.8002	.6371
9	1.0098	.8573	.7811	.4904	.6287	.743	.4877
10		.8764	.4481	.3593	.5144	.4954	.4374
11		.6097	.2812	.2343	.2286	.2343	.3048
12	.4382	.5144	.1677	.2286	.1905	.208	.2286
13		.5335	.1524		.1905	.192	.2858
14	.4001	.5144	.1875			.2012	
15		.4763	.2155	.2667		.1875	
16	.4382	.4763	.2343	.3048		.2429	.3239
17	.6097	.5335	.3258	.4191		.3506	.381
18	.7621	.5906	.4908	.5906	.4954	.5053	.6097
19	.6097	.6859	.5487	.7811	.5335	.5792	.724
20	.5716	.6097	.4489	.5906	.5716	.4607	.5906
21	.4001	.4382	.3361	.3429	.4191	.3353	.4572
22	.381	.381	.3315	.3239	.381	.3077	
23	.362	.3429	.2656	.3048	.3429	.2785	
24	.3048	.3239	.2622		.2858	.2622	
Max	1.105	1.0669	.9526	.7811	.9145	.9526	.7727
Min	.2858	.2667	.1524	.2286	.1905	.1875	.2286
Avg	.5944	.5898	.4322	.4325	.4649	.4279	.4489



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 201 / 11KV NATH MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048	.8059	.7682	.9242	.8954	.905	.9877
2	.7682	.6964	.8048	.9054	.9492	.8954	.9145
3	.7682	.6964	.823	.9619	.9896	.8962	.9335
4	.823	.7865	.9145	.9997	1.0059	.8954	1.0082
5	.9145	.8648	.9145	1.0456	1.0974	.9412	1.0425
6	.9694	.9156	.9877	1.0719	1.1157	1.0425	1.134
7	1.0608	1.0004	1.0974	1.1523	1.0974	1.0974	1.1523
8	1.0242	.9496	1.0642	1.0425	1.134	1.0317	1.0974
9	.9694	.8987	.9055	.9511	.9511	1.0317	.9694
10	.8688	.8987	.924	.8413	.9145	1.0059	1.0242
11	.8869	.8139	.8596	.9511	.8962	.9694	.823
12	.905	.763	.8596	.8779	.8596		.8413
13	.8596	.8139	.8779	.8596	.8962	.9877	.9328
14	.7343	.8059	.8962	.8048	.9036	.9328	.8779
15		.8573	.7865	.7499	.8505	.9511	.8413
16		.7545		.7682	.9511	1.0185	.9145
17	.8764	.8402	.9511		1.0791	1.0269	.9877
18	.985	.8139	1.0608	.9511	1.0608	1.0974	.9694
19	1.1104	1.046	1.1523	1.4083	1.3032	1.3352	1.1706
20	1.182	1.1523	1.262	1.3169	1.3575	1.3443	1.3306
21	1.1163	1.134	1.1888	1.1888	1.2715	1.2437	1.2567
22	1.0387	1.0059	1.1088	1.1706	1.1641	1.1523	1.1827
23	.8954	1.0185	.961	1.0425	1.0679	1.0608	1.0719
24	.8048	.8238	.9145	.9149	.9328	.9492	.9877
Max	1.182	1.1523	1.262	1.4083	1.3575	1.3443	1.3306
Min	.7343	.6964	.7682	.7499	.8505	.8954	.823
Avg	.9257	.8815	.9601	.9957	1.0310	1.0353	1.0188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 204 / 11 KV OPEN JAIL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0747	.0373	.0566	.0914	.0747	.0549
2	.0732	.0747	.0373		.0549	.0747	.056
3	.0732	.0747	.0373	.0566	.0549	.0747	.056
4	.0732	.0747	.0373	.0566	.0549	.0934	.056
5	.0732	.0914	.0373	.0754	.0549	.0934	
6		.0914		.0754		.0934	
10	.2229	.2743	.2883	.3077	.4572	.6485	
11	.1734	.2743	.2258	.3506	.439	.7186	
12	.1734	.2926	.2	.3506		.7362	
13	.1734	.2743	.1833	.3506		.9877	
14	.1734	.3109	.141	.3506	.5121	.9145	
15	.161	.3475	.1833	.3506	.4024	.8764	
16		.1829			.5304	.7712	
17	.1858	.4024	.1692	.3292	.5121	.6836	
18	.0366	.0732	.0377	.0366	.0366	.0754	
19	.0373	.0549	.0377	.0549	.0747	.0754	.0566
20	.0373	.056	.0566	.0549	.0747	.0754	.0566
21	.056	.0747	.0566	.0549	.0747	.0754	.0566
22	.0747	.0747	.0566	.0366	.0747	.0754	.0566
23	.0747	.0747	.0566	.0366	.0747	.0566	.0566
24	.0366	.0747	.0934	.0566	.0366	.0747	.0189
Max	.2229	.4024	.2883	.3506	.5304	.9877	.0566
Min	.0366	.0549	.0373	.0366	.0366	.0566	.0189
Avg	.1043	.1583	.1038	.1601	.2006	.3500	.0525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 205 / 11 KV CHANGATPURI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1478		.1315	.2378	.1734	.1578
2		.0991		.1315	.2378	.1734	.1578
3		.1463	.1113	.1315	.2195	.1814	.1578
4		.1021	.1372	.1425	.2743	.1814	.1928
5		.1036	.0947	.1425	.2743	.184	.2103
6		.1036	.1353	.1425	.2743	.2073	.2103
7			.1894	.2134	.2743	.3429	.3155
8		.2235	.2029	.333	.3109	.3201	.333
9		.2103	.1894	.298	.3475	.4733	.4207
10							.4908
11							.3681
12							.4995
13							.5312
14							.5106
15							.4978
16							.5127
17	.0867						
18	.0526	.0366		.0549	.0549	.0754	.0377
19	.0526	.0366	.0754	.0732	.0532	.0754	.0377
20	.0701	.0366	.0754	.0732	.0549	.0754	.0566
21	.0701	.0366	.0754	.0732	.0543		.0566
22	.0701	.0366	.0754	.0914	.0543		.0754
23	.0701	.0366	.0566	.0914	.0543	.0754	.0754
24		.1486		.141	.2195	.161	.1928
Max	.0867	.2235	.2029	.333	.3475	.4733	.5312
Min	.0526	.0366	.0566	.0549	.0532	.0754	.0377
Avg	.0675	.1003	.1182	.1415	.1873	.1928	.2652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 206 / 11kV Telwadi  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0549	.0549		.0914	.0747	.0754
2	.0914	.0549	.0549	.0754	.0914	.0754	.0754
3	.0914	.0549	.0549	.0754	.0934		.0754
4	.0732	.0549	.0732	.0754	.0914		.0754
5	.0914	.0549	.0732	.0754	.0914		
6		.0549		.0754			
10		.1052	.1315	.1578	.2743		
11		.0657	.1446	.1753	.2378		
12		.1183	.1425	.2103		.2103	
13		.0657	.1425	.1753	.2378	.2629	
14		.0657	.1425	.1578	.2378	.333	
15	.1166	.0526	.1276	.1928	.2378	.3155	
16	.0867	.1052				.298	
17	.0619	.1183	.1425	.1578	.2743	.2804	
18	.0377	.1097		.1132	.0549	.0566	.0566
19	.0566	.0732	.0754	.0732	.0532	.0754	.0566
20	.0566	.0732	.0943	.0732	.0724	.0754	.0754
21	.0526	.0914	.0943	.0924		.0566	.0754
22	.0566	.1463	.0943	.1829		.0566	.0566
23	.0566	.1463	.0754	.0914	.0754	.0566	.0566
24	.0549	.0566	.0549		.0914	.0747	.0566
Max	.1166	.1463	.1446	.2103	.2743	.333	.0754
Min	.0377	.0526	.0549	.0732	.0532	.0566	.0566
Avg	.0729	.0820	.0985	.1239	.1441	.1535	.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 207 / 11kV Nath Express  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0164	.0183	.0189	.0183	.0177	.0189
2	.0183	.0183	.0183	.0189	.0183	.0177	.0189
3	.0183	.0183	.0183	.0189	.0183	.0175	.0189
4	.0183	.0183	.0183	.0189	.0183	.0173	.0189
5	.0183	.0183	.0183	.0189	.0183	.0171	.0189
6	.0183	.0183	.0183	.0189	.0183	.0171	.0189
7	.0183	.0183	.0183	.0189	.0183	.0171	.0189
8	.0183	.0183	.0183	.0183	.0183		.0189
9	.0189	.0183	.0189	.0189	.0183	.0171	.0189
10	.0171	.0183	.0189	.0189	.0183	.0189	.0183
11	.0162	.0183	.0189	.0189	.0183	.0189	
12	.0164	.0183	.0189	.0189	.0183		.0189
13	.0162	.0183	.0189	.0189	.0183	.0183	.0189
14	.0162	.0183	.0189	.0175	.0183	.0189	.0189
15		.0183	.0189	.0189	.0183	.0189	.0189
16		.0183		.0189	.0183	.0189	.0189
17	.0162	.0183	.0189	.0189	.0183	.0189	.0189
18	.0164	.0183	.0189	.0189	.0183	.0189	.0189
19	.0171	.0183	.0189	.0183	.0175	.0189	.0189
20	.0158	.0183	.0189	.0183	.0173	.0189	.0189
21	.0171	.0183	.0189	.0187	.0171	.0189	.0189
22	.0171	.0183	.0189	.0183	.0175	.0189	.0189
23	.017	.0183	.0189	.0183	.0175	.0189	.0189
24	.0183	.017	.0183	.0189	.0179	.0175	.0189
Max	.0189	.0183	.0189	.0189	.0183	.0189	.0189
Min	.0158	.0164	.0183	.0175	.0171	.0171	.0183
Avg	.0174	.0182	.0187	.0187	.0181	.0182	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 208 / 11kV Urban Gaonthan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4338	.4755	.4715	.9328	.4904	.5281
2	.3658	.4207	.4755	.4715	.9145	.4904	.4755
3	.3841	.4207	.4938	.547	.9431	.5093	.4904
4	.4572	.5853	.6401	.7167	1.134	.5847	.6413
5	.7316	.9145	.8596	1.0374	1.4266	1.0562	.9431
6	.9877	1.4998	1.3717	1.3817	1.4449		1.4335
7	1.134		1.5181	1.39	1.3535	1.6221	1.7164
8	1.0608	1.4632	1.3535	1.4449	1.3717	1.4563	1.4335
9	1.262	1.3535	1.1949	1.2254	1.1157	1.1157	1.3392
10	1.0642	1.1706	.8686	.9328	.7682	.9997	.9694
11	.7655	.823	.5853	.6401	.6036	.7133	.6283
12	.5788	.6036	.5121	.5121		.5487	.5304
13	.5359	.6401	.5304	.4207		.5121	.4755
14	.4854	.7316	.5304	.4024	.5487	.4938	
15	.5228	.7316	.5304	.4715	.4938	.5304	
16	.5415	.5487			.6401	.6401	
17	.8402	.8413	.7499	.7133	.7133	.7133	
18	1.0456	.7865	.9795	1.0059	.9145	.8865	.924
19	1.1203	.8962	1.1458	1.1506	1.2883	1.2637	1.1016
20	.8962	.823	1.0349	1.0562	1.1203	1.1317	.8488
21	.6535	.6401	.7947	.8962	.7468	.7922	.7545
22	.5228	.5853	.6283	.6219	.6535	.6413	.6224
23	.4854	.4572	.5041	.5304	.5658	.5658	.5847
24	.3658	.0377	.4572	.4904	.4938	.5041	.5093
<b>Max</b>	<b>1.262</b>	<b>1.4998</b>	<b>1.5181</b>	<b>1.4449</b>	<b>1.4449</b>	<b>1.6221</b>	<b>1.7164</b>
<b>Min</b>	<b>.3658</b>	<b>.0377</b>	<b>.4572</b>	<b>.4024</b>	<b>.4938</b>	<b>.4904</b>	<b>.4755</b>
<b>Avg</b>	<b>.7155</b>	<b>.7569</b>	<b>.7928</b>	<b>.8057</b>	<b>.9176</b>	<b>.7940</b>	<b>.8475</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044056 / PAITHAN SUB STN

Feeder No / Name : 209 / 11KV GHARI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732		.0991	.1578	.2801	.2332	.3584
2	.0732	.1867	.1238	.1578	.1867	.2202	.3506
3	.0732		.1362	.1555	.1829	.2235	.362
4	.0732		.1362	.1555	.2561	.2235	.3841
5	.1097		.1334		.2195	.2401	.3801
6	.1097	.1494	.1362	.1787	.2195	.257	.4024
7	.1463		.1734	.4207	.3475	.4144	.5083
8	.2195	.2987	.4268	.4938	.567	.5716	.5434
9	.2804	.1951	.4001	.4557	.6036	.6485	.5784
10							.7186
11							.6268
12							.6836
13							.7255
17	.0566						.0377
18	.056			.0366	.0549	.298	.0566
19	.0543		.2172	.0366	.0732	.333	.0566
20	.0732	.1698	.1715	.0366	.0724	.3681	.0566
21	.0747	.1781	.1974	.0366	.0724	.4031	.0566
22	.0543	.1315	.1974	.0366	.0747	.4031	.0566
23	.0543	.1296	.1833	.0549	.0549	.3681	.0566
24	.0495	.1362	.1315	.1692	.3109	.2591	.3506
Max	.2804	.2987	.4268	.4938	.6036	.6485	.7255
Min	.0495	.1296	.0991	.0366	.0549	.2202	.0377
Avg	.0960	.1750	.1909	.1722	.2235	.3415	.3500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 201 / 11KV DHORKIN GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2829	.2801	.2772	.2829	.2801	.2987
2	.2772	.2829	.2801	.2772	.2829	.2801	.2987
3	.3361	.3772	.3361	.3361	.2829	.3734	.3734
4	.4481	.3772	.4108	.4668	.4715	.4668	.4668
5	.6224	.5658	.6535	.5658	.6602	.5601	.6413
6	.7545	.7545	.8215	.7922	.8488	.7842	.7922
7	.811	.8488	.8029	.8299	.8488	.7468	.8299
8	.7095	.679	.7468	.7095	.6602	.6722	.7167
9	.5601	.6413	.5601	.5975	.4715	.5975	.6036
10	.3921	.415	.4481	.3921	.4904	.4481	.4481
11	.2829	.3734	.3326	.3547	.2987	.3547	.2241
12	.2263	.3734	.2587	.2987	.2957	.2987	.2241
13	.2263	.3734	.2561	.2987	.2957	.2801	.2241
14	.2263	.2957	.2772	.2241	.2772	.2587	.1867
15	.2263	.2957	.2957	.2801	.2772	.3326	.1867
16	.2641	.2772	.3142	.2829	.3326	.3696	.2263
17	.3772	.3361	.3511		.3921	.4066	.1886
18	.4715	.3734	.2987	.5281	.4481	.4668	.4338
19	.4715	.4481	.5658	.6224	.5975	.5093	.5658
20	.4338	.4854	.5281	.5658	.5228	.5228	.4715
21	.4338	.4294	.4668	.2829	.3921	.4481	.2829
22	.3395	.3361	.3921	.2743	.3547	.3734	.2829
23	.2829	.3174	.3361	.2829	.3174	.3361	.2829
24	.2957	.2829	.2987	.2957	.2829	.2801	.2987
Max	.811	.8488	.8215	.8299	.8488	.7842	.8299
Min	.2263	.2772	.2561	.2241	.2772	.2587	.1867
Avg	.4061	.4259	.4297	.4276	.4327	.4353	.3979



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 202 / 11KV DHORKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0587	.0572	.08	.0914	.1189	.1067
2	.061	.0587	.0579	.0934	.0914	.1219	.1067
3	.061	.0743	.0743	.0947	.108	.1406	.1067
4	.0617	.0743	.0781	.096	.108	.1423	.1219
5	.0791	.0743	.0972	.1113	.16	.1619	.1219
6	.08	.0892	.1187	.1286	.1619	.1677	.1406
7	.1187	.1017	.1656	.1505	.2187	.2623	.2187
8	.1326	.1337	.2107	.2709	.2494	.2846	.2591
9	.1638	.1715	.2526	.3311	.3858	.2896	.3311
10							.3506
11							.3763
12							.3913
13							.4725
14							.4725
15							.503
16							.503
17							.503
19	.0572	.0953	.0953	.0953	.1143	.0953	.0953
20	.0762	.1143	.0953	.0953	.1143	.0572	.0953
21	.0762	.0953	.0762	.0953	.0953	.0953	.0762
22	.0762	.0572	.0762	.0953	.0953	.0953	.0762
23	.0762	.0572	.0762	.0953	.0762	.0762	.0762
24	.061	.0594	.0472	.08	.088	.0975	.1054
Max	.1638	.1715	.2526	.3311	.3858	.2896	.503
Min	.0572	.0572	.0472	.08	.0762	.0572	.0762
Avg	.0828	.0877	.1052	.1275	.1439	.1471	.2439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 203 / 11KV KARKIN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0189	.0189	.0377	.0377	.0189	.0377
2	.0377	.0189	.0189	.0377	.0377	.0189	.0377
3	.0377	.0189	.0377	.0377	.0377	.0189	.0377
10	.0648	.0354	.12	.0701	.0914	.1115	
11	.0638	.0945	.1063	.1212	.1635	.1404	
12	.0638	.144	.0857	.0701	.1463	.1509	
13	.0638	.1296	.1189	.1048	.156	.161	
14	.0714	.1029	.109	.1124	.1915	.1707	
15	.0572	.101	.101	.1143	.1787	.1486	
16	.0381	.1174	.1124	.1276	.1814	.1341	
17	.0518	.0777	.1105	.1486	.1707	.1219	
19	.0187	.0791	.0377	.0377	.0189	.0377	.0377
20	.0189	.0377	.0377	.0377	.0189	.0377	.0377
21	.0189	.0377	.0377	.0377	.0189	.0377	.0377
22	.0189	.0189	.0377	.0377	.0189	.0377	.0377
23	.0189	.0189	.0377	.0377	.0189	.0377	.0189
24	.0377	.0189	.0189	.0377	.0377	.0189	.0377
Max	.0714	.144	.12	.1486	.1915	.1707	.0377
Min	.0187	.0189	.0189	.0377	.0189	.0189	.0189
Avg	.0423	.0630	.0675	.0711	.0897	.0825	.0356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 204 / 11KV DHANGAN AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0472	.04	.0495	.0343	.3048	.2934	.3334
2	.0503	.0429	.0503	.036	.3048	.3429	.3734
3	.0503	.0429	.0533	.0372	.3201	.3715	.4268
4	.0511	.0526	.0676	.0495	.3241	.4115	.4534
5	.0648	.0533	.0686	.0511	.3437	.4531	.4668
6	.0657	.0518	.0695	.08	.3437	.506	.5573
7	.0714	.0695	.0926	.0974	.5668	.7274	.7727
8	.0695	.088	.1189	.1907	.8583	.7926	.8642
9	.0667	.096	.132	.1635	.7522	.8128	.9877
10							1.1431
11							1.0467
12							1.2498
13							1.2342
14							1.2186
15							1.2186
16							1.2193
17							1.2651
19	.0179		.0164	.0554	.0943	.0943	.0554
20	.0185		.0166	.056	.0943	.0943	.0566
21			.0166	.0566	.0754	.0943	.0566
22			.0166	.0566	.0566	.0943	.0566
23			.0164	.0566	.0566	.0754	.0566
24	.0343	.0747	.0488	.3161	.3161	.2972	.2667
Max	.0714	.096	.132	.3161	.8583	.8128	1.2651
Min	.0179	.04	.0164	.0343	.0566	.0754	.0554
Avg	.0506	.0612	.0556	.0891	.3208	.3641	.6687

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 206 / 11KV INDUSTRIAL FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0061	.0187	.0141	.0122	.0236	.013	.0111
2	.0053	.0187	.0114	.013	.0271	.0126	.0069
3	.0099	.0183	.016	.013	.0286	.013	.0084
4	.0107	.0137	.021	.0126	.0305	.0114	.0122
5	.0166	.0111	.0221	.0137	.0309	.0126	.0069
6	.0171	.0111	.0251	.0149	.0316	.0088	.0069
7	.0229	.021	.0135	.016	.0225	.0112	.0152
8	.0244	.0105	.0145	.0221	.0072	.0065	.0183
9	.0267	.0093	.008	.0038	.0084	.0053	.0061
10	.0067	.0111	.0191	.056	.0316	.0032	.0034
11	.0069	.0114	.0221	.0754	.0082	.0038	.0175
12	.0301	.0118	.0244	.0566	.0034	.0137	.0175
13	.0175	.009	.0267	.0754	.0091	.0183	.0051
14	.0152	.0082	.0297	.0377	.013	.0118	.0103
15	.0069	.0114	.0324	.0377	.008	.0149	.0076
16	.0111	.0021	.0343	.0221	.0232	.0069	.0069
17	.0055	.0019	.0335	.0111	.0164	.0053	.0118
18	.0118	.0114	.0282	.0187	.0065	.003	.0118
19	.0221	.0076	.0267	.0103	.0095	.0107	.0122
20	.0221	.0107	.0236	.0111	.013	.0133	.0137
21	.0251	.0099	.0221	.0202	.021	.0179	.0118
22	.0251	.0088	.0156	.0198	.0202	.0168	.0122
23	.0221	.0091	.0145	.0202	.0168	.016	.0122
24	.0072	.0198	.0103	.0122	.016	.0183	.0137
Max	.0301	.021	.0343	.0754	.0316	.0183	.0183
Min	.0053	.0019	.008	.0038	.0034	.003	.0034
Avg	.0156	.0115	.0212	.0252	.0178	.0112	.0108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 211 / NANDALGAON AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.1551	.1128	.1391	.1509	.1486	.1972
11	.1486	.1269	.1551	.2042	.2378	.2366
12	.1486	.141	.1692	.2366	.2235	.2235
13	.1486	.141	.2	.1425	.1578	.2235
14	.1486	.1128	.1858	.1829	.1972	.2103
15	.1505	.1269	.1715	.1829	.184	.2103
16	.0914	.141	.1715	.2134	.1972	.2103
17	.0914	.1269	.1715	.2134	.1972	.2103
Max	.1551	.141	.2	.2366	.2378	.2366
Min	.0914	.1128	.1391	.1425	.1486	.1972
Avg	.1354	.1287	.1705	.1909	.1929	.2153

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044069 / 33/11 KV DHORKIN

Feeder No / Name : 212 / 11KV KARKIN GAOTHAN FEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2829	.2641	.2772	.2829	.2801	.2801
2	.2587	.2829	.2641	.2772	.2743	.2801	.2801
3	.3547	.3772	.3018	.3361	.2829	.3361	.2987
4	.4294	.4715	.4668	.5228	.4715	.4294	.3734
5	.5847	.6602	.6535	.6413	.6602	.5228	.6036
6	.7733	.8488	.8402	.7733	.8488	.7468	.7733
7	.7167	.7545	.7468	.6979	.9242	.7468	.7922
8		.7545	.6348	.6224	.7922	.6348	.6979
9		.5658	.5228	.5228	.5201	.5601	.5658
10		.3772	.3547	.3734	.4715	.4108	.3361
11	.4525	.2987	.2957	.2987	.2801	.2801	.2241
12	.3018	.2427	.2218	.1867	.1663	.2427	.1867
13	.2641	.2054	.1829	.1848		.2241	.2054
14	.2263	.2054	.2195	.1848	.1663	.2033	.2054
15	.2641	.2218	.2378	.1867	.2218	.2402	.1867
16	.3772	.2218	.2587	.2801	.2218	.2772	.2263
17	.4527	.2614	.3696	.3734	.3361	.3174	.3734
18	.5281	.3734	.4668	.5093	.4481	.4294	.4715
19	.5658	.4854	.5658	.6036	.6161	.5228	.6036
20	.4527	.4294	.5228	.5658	.4854	.4715	.4715
21	.415	.3734	.3921	.415	.3734	.3734	.4338
22	.3395	.3361	.0373	.3772	.3361	.3361	.3395
23	.2829	.2987	.3224	.3018	.2801	.2987	.2829
24	.2772	.2829	.2614	.2772	.2829	.2801	.2801
Max	.7733	.8488	.8402	.7733	.9242	.7468	.7922
Min	.2263	.2054	.0373	.1848	.1663	.2033	.1867
Avg	.4084	.4005	.3918	.4079	.4236	.3935	.3955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 201 / 11KV Ranjangaon Gaonthan GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2915	.3086	.2743	.3086	.3086	.3258
2	.2743	.2915	.2743	.2743	.3086	.3086	.3258
3	.2743	.2915	.3086	.3086	.3086	.3086	.3258
4	.4163	.3772	.3258	.4458	.4344	.4115	.4163
5	.6516	.6173	.6516	.6516	.6697	.6516	.7059
6	.8402	.8916	.9774	.9259	.9896	.8916	1.0456
7	1.0082	.9774	.8573	.9088	1.0269	.9602	1.0269
8	.9149	.8059	.7545	.8402	.9149	.7316	.8589
9	.7059	.703	.5658	.6859	.6516	.7202	.6516
10	.5316	.6001	.4458	.5249	.4973	.5249	.4572
11	.3772	.5487	.3086	.3086	.3772	.3258	.3772
12	.2743	.4115	.2401	.2572	.2743	.2401	.3086
13	.2401	.3772	.2401	.2401	.2743	.2401	.2229
14	.2401	.3429	.2401	.2229	.2743	.2229	.2743
15	.2743	.3086	.2058	.2058	.2743	.2229	.3086
16	.3429	.2915	.2743	.2915	.3429	.3086	.3429
17	.5316	.3944	.3601	.3944	.4287	.3772	.3772
18	.5335	.4458	.4973	.5792	.6001	.5792	.5144
19	.6401	.6001	.7888	.8402	.7716	.7655	.6687
20	.6173	.6516	.6173	.7059	.6173	.5792	.6173
21	.4801	.4115	.4287	.4887	.4268	.4706	.5144
22	.3772	.3601	.3772	.3982	.3353	.3772	.3772
23	.2743	.3258	.3429	.3258	.3258	.3258	.3258
24	.2743	.2743	.3086	.3086	.3086	.3258	.3258
Max	1.0082	.9774	.9774	.9259	1.0269	.9602	1.0456
Min	.2401	.2743	.2058	.2058	.2743	.2229	.2229
Avg	.4737	.4830	.4458	.4753	.4892	.4658	.4873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 202 / Marhola  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1067	.0914	.0762	.1067	.0914	.12
2	.0914	.1067	.1067	.0914	.1067	.0914	.12
3	.1029	.1219	.1067	.0914	.1067	.0914	.12
10	.1829	.2286	.2286	.2286	.2896	.3201	
11	.1829	.2439	.2439	.2743	.3048	.3658	
12	.1524	.2286	.2286	.2896	.3658	.3963	
13	.0914	.2134	.2439	.2896	.3658	.3963	
14	.0914	.2439	.2743	.2743	.3506	.3963	
15	.1524	.2286	.2591	.2743	.381	.4115	
16	.1829	.2134	.2591	.2743	.381	.381	.0457
17	.2134	.2286	.2439	.2896	.381	.3506	.061
18	.1067	.0914	.0914	.0857	.0762	.0686	.061
19	.0914	.0914	.1067	.12	.1219	.12	.0762
20	.1067	.1067	.1067	.12	.1067	.12	.0914
21	.1067	.0914	.0914	.12	.1067	.1067	.0762
22	.1067	.1067	.0914	.12	.0914	.12	.0762
23	.1067	.1067	.0914	.1029	.0914	.1029	.0762
24	.1029	.1067	.1219	.8535	.1029	.0914	.1029
Max	.2134	.2439	.2743	.8535	.381	.4115	.12
Min	.0914	.0914	.0914	.0762	.0762	.0686	.0457
Avg	.1264	.1592	.1660	.2209	.2132	.2234	.0856



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 203 / Shekta

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0762	.0914	.061	.0457	.061	.0762
2	.0914	.0762	.1067	.061	.0457	.061	.0762
3	.0914	.0914	.1219	.0762	.0457	.061	.0762
4	.0914	.0914	.1067	.0762	.061	.061	.0762
5	.0914	.0914	.1219	.0914	.0762	.0762	.0762
6	.1219	.0914	.1067	.1067	.1067	.0914	.0914
7	.1219	.1067	.1067	.1067	.1219	.1067	.1372
8	.1372	.1067	.1372	.1219	.1524	.1219	.1372
9	.1067	.1067	.1524	.1219	.1524	.1524	.1524
10							.1524
11							.1829
12							.1677
13							.1677
14							.1829
15							.1981
16							.1829
17							.1067
24		.061	.0762	.061	.0457	.061	.0762
Max	.1372	.1067	.1524	.1219	.1524	.1524	.1981
Min	.0914	.061	.0762	.061	.0457	.061	.0762
Avg	.1050	.0899	.1128	.0884	.0853	.0854	.1287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 204 / AURANGPURWADI AG FEEDER FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1219	.2286	.1524	.1524	.2286	.2439
2	.1829	.1219	.2134	.1524	.1524	.2286	.2439
3	.1829	.1219	.2134	.1677	.1524	.2286	.2439
4	.1829	.1219	.1981	.1829	.1829	.3048	.2439
5	.1981	.1524	.2134	.1829	.2286	.3658	.2591
6	.2286	.1524	.2439	.2134	.2591	.4268	.2439
7		.1981	.2591	.3201	.4115	.5182	.3201
8	.2439	.2286	.2896	.381	.4725	.5487	.3658
9	.2134	.2134	.2896	.3506	.4725	.5487	.4115
10							.4268
11							.4572
12							.4877
13							.5182
14							.5792
15							.6097
16	.0762	.061	.061	.061	.0762	.061	.6401
17	.0762	.061	.061	.0762	.1067	.061	.6859
18	.1067	.0762	.061	.0914	.1067	.0914	.0762
19	.1067	.0762	.0762	.0914	.1067	.0914	.0914
20	.1067	.0914	.0914	.0914	.1067	.0914	.0762
21	.1067	.0914	.0914	.061	.1067	.1067	.0914
22	.1067	.0914	.0914	.0762	.1067	.0762	.0762
23	.1067	.0762	.0762	.0762	.1067	.0762	.0762
24	.1829	.1067	.1981	.1524	.1524	.2286	.2439
Max	.2439	.2286	.2896	.381	.4725	.5487	.6859
Min	.0762	.061	.061	.061	.0762	.061	.0762
Avg	.1524	.1202	.1643	.1600	.1922	.2379	.3213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044072 / ranjangaonkhuri

Feeder No / Name : 205 / DARGHA AG FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1067	.0914	.0762	.0914	.0914	.0762
2	.0914	.1067	.1067	.0762	.0914	.0914	.0762
3	.0914	.1067	.0914	.0914	.0914	.0914	.0762
10	.1677	.1981	.2439	.2439	.2743	.2896	
11	.1829	.2134	.2439	.2896	.3048	.381	
12	.1829	.1981	.2439	.2743	.3353	.381	
13	.1372	.1829	.2439	.2743	.3658	.381	
14	.1372	.1981	.2286	.2591	.3658	.3658	
15	.1524	.1981	.2134	.2439	.381	.3658	
16	.1829	.1829	.1981	.2439	.3658	.3506	.061
17	.1981	.1829	.2286	.2591	.3353	.3353	.061
18	.1341	.0914	.0762	.0914	.0914	.0762	.0762
19	.1219	.0914	.0914	.0914	.0914	.0762	.0762
20	.1219	.0914	.0914	.1067	.0914	.0762	.0762
21	.1067	.0914	.0914	.0762	.0914	.0762	.0762
22	.1067	.1067	.0762	.0914	.0914	.0762	.0762
23	.1067	.1067	.0762	.0914	.0914	.0914	.0914
24	.0914	.1067	.0914	.0914	.0914	.0914	.0762
Max	.1981	.2134	.2439	.2896	.381	.381	.0914
Min	.0914	.0914	.0762	.0762	.0914	.0762	.061
Avg	.1336	.1422	.1516	.1651	.2023	.2049	.0749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 201 / Wadwali

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
18			.0191	
19			.0191	
20			.0191	
21			.0191	
22			.0191	
23			.0191	
24	.0762	.0332		.1524
Max	.0762	.0332	.0191	.1524
Min	.0762	.0332	.0191	.1524
Avg	.0762	.0332	.0191	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 202 / Anantpur

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.5144	
13			.5525	
14			.7049	
15			.724	
16			.724	
17			.743	
18			.0191	
19			.0381	
20			.0381	
21			.0381	
22			.0381	
23			.0381	
24	.0191	.0164		.0381
Max	.0191	.0164	.743	.0381
Min	.0191	.0164	.0191	.0381
Avg	.0191	.0164	.3477	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 203 / Apegaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.0762	
12			.0762	
13			.0762	
14			.0762	
15			.0762	
16			.0762	
17			.0762	
18			.0191	
19			.0191	
20			.0191	
21			.0191	
22			.0191	
23			.0191	
24	.0191	.0183		.0191
Max	.0191	.0183	.0762	.0191
Min	.0191	.0183	.0191	.0191
Avg	.0191	.0183	.0498	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 204 / WADWALI GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11			.381	
12			.3239	
13			.0953	
14			.0762	
15			.0762	
16			.0762	
17			.7621	
18			1.1431	
19			1.2384	
20			1.1431	
21			.9526	
22			.7621	
23			.724	
24	.4763	.5975		.4954
Max	.4763	.5975	1.2384	.4954
Min	.4763	.5975	.0762	.4954
Avg	.4763	.5975	.5965	.4954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 205 / 11kvWAGHADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
18		.0191	
19		.0191	
20		.0191	
21		.0191	
22		.0191	
23		.0191	
24	.1989		.1524
Max	.1989	.0191	.1524
Min	.1989	.0191	.1524
Avg	.1989	.0191	.1524



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044089 / WADWALI

Feeder No / Name : 208 / 11KV Naigaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
18		.0191	
19		.0191	
20		.0191	
21		.0191	
22		.0191	
23		.0191	
24	.0332		.0191
Max	.0332	.0191	.0191
Min	.0332	.0191	.0191
Avg	.0332	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 201 / UDYOGMITRA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0166	.964	.8063	.7888	.631	.9816	.9465
2	1.0341	.9114	.8063	.7888	.631	.964	.929
3	1.0341	.8764	.7888	.7888	.631	.964	.929
4	1.0341	.8764	.7888	.7716	.6661	.964	.929
5	1.0341	.964	.8063	.7202	.7011	.964	.9465
6	1.0867	.8764	.8589	.6859	.7011	1.0517	.9991
7	1.1393	.7888	.8764	.7164	.8413	1.1393	1.0517
8	1.2048	.9114	.9114	.7522	.8764	1.3432	1.1871
9	1.3535	.9114	.8764	.8059	1.0867	1.3432	1.3112
10	1.4998	.9492	.9511	.7343	1.1888	1.4327	1.4327
11	1.4632	1.0745	.9511	.7164	1.39	1.4327	1.4327
12	1.3717	.8596	.9877	.7522	1.2437	1.3969	1.3432
13	1.4632	.8954	.9511	.7343	1.2803	1.4327	1.3969
14	1.4632	.9313	.9511	.788	1.3169	1.3432	1.4327
15	1.4998	.8954	.9511	.8596	1.39	1.4327	1.2536
16	1.5546	.7164	.9145	.7522	1.3169	1.4327	1.4327
17	1.2269	.8589	.9259	.7712	1.2971	1.4175	1.3969
18	1.1393	.8238	.9259	.7011	1.3146	1.3289	1.2536
19	1.0517	.8413	.8916	.6485	1.262	1.1517	1.2536
20	1.0517	.8238	.8764	.631	1.1919	.9991	1.0745
21	1.0166	.8063	.8413	.6485	1.1393	.964	1.0745
22	1.0166	.8063	.8413	.6661	1.0517	.9465	1.0745
23	.9816	.8063	.8413	.6485	1.0166	.9465	.985
24	1.0166	.964	.8063	.8413	.6661	.9816	.9465
Max	1.5546	1.0745	.9877	.8596	1.39	1.4327	1.4327
Min	.9816	.7164	.7888	.631	.631	.9465	.929
Avg	1.1981	.8805	.8803	.7380	1.0347	1.1814	1.1672

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 202 / NAIGAON

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.6135	.6661	.7362	.631	.8764	.7011
2	.631		.6661	.7362	.631	.8413	.7011
3	.6661	.6661	.6836	.7362	.6661	.8413	.7362
4	.7362	.7011	.7362	.7716	.7011	.8413	.7712
5	.8413	.7362	.8238	.8573	.7888	.8764	.8764
6	1.1218	1.0745	1.0692	1.2346	1.0867	1.2003	1.2269
7	1.2269	1.2269	1.2269	1.2536	1.262	1.286	1.3672
8	1.2048	1.0517	1.1043	1.1765	1.2445	1.3253	1.2403
9	1.1641	1.0517	1.0166	.9955	1.0517	1.2178	1.134
10	1.0745	.8954	1.0387	.6516	1.0242	1.1283	1.1104
11	.8954	.8954	.9511	.6089	1.0136	1.0745	.985
12	.7164	.7164	.8326	.6447	.8954	.985	.8954
13	.5014	.8596	.6089	.5373	.7421	.985	.8238
14	.7164	.8954	.6335	.5373	.905	.8954	.788
15	.7701	.8238	.6516	.6089	1.0136	1.0029	.788
16	.7701		.8779	.6447	.9877	1.0029	.985
17	.9114	.964	.9259	.7011	1.0517	.7442	1.0745
18	.964	.9465	.8573	.7888	1.0166	.9745	1.1641
19	1.0517	1.0166	1.0631	1.0166	1.1393	1.0277	1.0745
20	.8764	.9114	1.0517	.8413	1.0517	.9816	.985
21	.8413	.8238	.8764	.7362	.9114	.9465	.8954
22	.7888	.7712	.8764	.7011	.8764	.8764	.788
23	.7011	.7362	.7888	.6135	.8764	.7712	.8954
24	.6836	.6135	.7011	1.1172	.5959	.8764	.7011
Max	1.2269	1.2269	1.2269	1.2536	1.262	1.3253	1.3672
Min	.5014	.6135	.6089	.5373	.5959	.7442	.7011
Avg	.8550	.8632	.8637	.8020	.9235	.9824	.9462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 203 / 11 KV CHITEGAON GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.1462	.9709	1.0166	.9709	.8413	1.1096
2	.9709	1.1104	.9465	.9816	.9709	.9465	1.0867
3	1.0056	1.0745	.9536	.9816	.9882	.9816	1.0749
4	1.1616	1.182	1.1096	1.0517	1.0576	1.0517	1.2136
5	1.3003	1.2894	1.283	1.2346	1.2483	1.262	1.387
6	1.6644	1.5074	1.5604	1.7147	1.5604	1.7147	1.8204
7	1.7528	1.6126	1.647	1.749	1.6297	1.749	1.7684
8	1.7177	1.8625	1.7857	1.4083	1.7684	1.858	1.7878
9	1.7528	1.8861	1.8054	1.2742	1.6644	1.9281	1.8229
10	1.7177	1.6827	1.7528	1.3321	1.7878	1.8229	1.5424
11	1.7177	1.7528	1.6476	1.1568	1.6476	1.893	1.5424
12	1.4723	1.6126	1.4022	.8764	1.5074	1.9281	1.6476
13	1.262	1.4373	1.3321	.9816	1.2269	1.7528	1.6126
14	1.4373	1.4022	1.4022	.964	1.3321	1.4723	1.5775
15	1.2971	1.4685	1.4373	.9465	1.4373	1.5424	1.6126
16	1.3672	1.5074	1.5424	.9465	1.6126	1.6476	1.7177
17	1.6476	1.4548	1.6118	1.1096	1.4746	1.6126	1.6476
18	1.7193	1.5257	1.6461	1.2136	1.6126	1.5775	1.6476
19	1.6834	1.491	1.6827	1.4737	1.7193	1.7353	1.8755
20	1.5402	1.387	1.5424	1.387	1.5089	1.5257	1.5775
21	1.3611	1.283	1.2971	1.2483	1.4723	1.3176	1.4899
22	1.182	1.1789	1.182	1.1443	1.2971	1.2136	1.4022
23	1.182	1.0517	1.1462	1.0056	1.1919	1.1789	1.1919
24	.9709	1.182	.9709	1.0387	.9709	1.0867	1.1096
Max	1.7528	1.8861	1.8054	1.749	1.7878	1.9281	1.8755
Min	.9709	1.0517	.9465	.8764	.9709	.8413	1.0749
Avg	1.4106	1.4204	1.4024	1.1765	1.4024	1.4850	1.5111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044095 / 33 KV S/S CHITEGAON

Feeder No / Name : 205 / 11 KV CHITEGAON INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.4207	.4207	.4207	.4207	.3681	.4382
2	.4207	.4207	.4207	.4031	.4207	.3506	.4382
3	.4031	.4207	.4031	.4031	.4031	.3506	.4382
4	.4207	.3856	.4031	.3944	.4031	.3506	.4382
5	.4031	.4382	.4207	.3944	.3856	.3856	.4382
6	.4207	.4382	.4557	.4801	.4207	.3856	.4908
7	.4207	.4557	.4908	.4458	.4908	.4458	.4382
8	.4607	.4207	.5083	.4115	.5258	.6447	.5316
9	.5959	.4557	.5258	.4287	.4382	.5014	.6379
10	.5258	.788	.8954	.5014	.5014	.7164	1.0029
11	.7011	1.1104	1.0029	.4908	.5014	.7522	.9313
12	.7186	.8954	.8596	.4557	.7164	.788	.8596
13	.7362	.8954	.9313	.3856	.6089	.788	.788
14	.9114	.9671	.9313	.3856	.6268	.8238	.7164
15	1.0517	.8954	.8954	.3856	.4298	.8596	.985
16	1.0517	1.0745	.8954	.4557	.6089	1.0745	.8954
17	1.1218	.8413	.7888	.4557	.6135	.9922	.7164
18	.9114	.5258	.9259	.4207	.6135	.7973	.8954
19	.4207	.4733	.6859	.4733		.4961	.5373
20	.4207	.3856	.4908	.4207	.4382	.4908	.4656
21	.4908	.4031	.4908	.4207	.4207	.4908	.4477
22	.4557	.4207	.4207	.4207	.4031	.4733	.4477
23	.4557	.4031	.4557	.4207	.3856	.4207	.5014
24	.4207	.4557	.3856	.4207	.4207	.4207	.4207
Max	1.1218	1.1104	1.0029	.5014	.7164	1.0745	1.0029
Min	.4031	.3856	.3856	.3856	.3856	.3506	.4207
Avg	.5983	.5996	.6294	.4290	.4869	.5903	.6208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 201 / RAPDRP NEW KAWSAN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207	.439	.5487	.5304	.5304	.5304	.5544
2	.4024	.439	.567	.5304	.5121	.5304	.5729
3	.4024	.4572	.4938	.5121	.5121	.5121	.5729
4	.4572	.5121	.5487	.5487	.5304	.5304	.5914
5	.5853	.6036	.6401	.6036	.6219	.6219	.6283
6	.8413	.7316	.7316	.6767	.7499	.823	.8131
7	.8131	.8413	.7865	.7316	.695	.7316	.7947
8	.7392	.6401	.6401	.6219	.6401	.5853	.6283
9	.5729	.567	.5304	.5249	.5853	.5853	.5544
10	.4805	.5121	.4938	.4938	.5304	.567	.5359
11	.5175	.4755	.5121	.5121	.4755	.5121	.5175
12	.4435	.4938	.5121	.4755	.439	.4755	.5175
13	.4066	.4755	.4938	.4572	.4572	.4755	.462
14	.3696	.4755	.439	.439	.439	.439	.499
15		.4572	.4938	.4024	.4572	.4572	.4435
16	.4066	.439	.4572	.4572	.4207	.4572	.4435
17	.4251	.4572	.4572	.439	.4207	.4938	.4805
18	.4656	.4938	.5487	.4938	.5121	.5487	.499
19	.5544	.6401	.6219	.5544	.6401	.6219	.5544
20	.5914	.6036	.6584	.7392	.6219	.7133	.6283
21	.5914	.6219	.6584	.7023	.6401	.7316	.6468
22	.5729	.5487	.6401	.6468	.5853	.6767	.6468
23	.5175	.5853	.5853	.5729	.5853	.5487	
24	.462	.4572	.5487	.5544	.5487	.5487	.5853
Max	.8413	.8413	.7865	.7392	.7499	.823	.8131
Min	.3696	.439	.439	.4024	.4207	.439	.4435
Avg	.5234	.5403	.5670	.5508	.5479	.5716	.5726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 044099 / RAPDRP RAMNAGAR ,PAITHAN

Feeder No / Name : 202 / RAPDRP POWER HOUSE SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.695	.7682	.7682	.7865	.8048	.7682
2	.7133	.695	.7499	.7682	.7316	.7682	.7499
3	.695	.7316	.7133	.7682	.7316	.7682	.7682
4	.7316	.7865	.7316	.823	.7682	.7682	.8048
5	.905	.8596	.8048	1.0059	1.0242	.9145	.8413
6	1.134	.9694	.9145	1.1523	1.1523	1.0059	1.0242
7	1.1088	1.0791	1.0974	1.1706	1.2437	1.0791	1.1523
8	1.1458	1.0791	1.0791	1.0974	1.2803	1.0608	1.1888
9	.9795	1.0059	1.0242	1.0425	1.0974	1.0974	1.1088
10	1.0164	1.0374	.9511	1.0059	.9694	1.0791	1.0534
11	.961	1.0059	.9145	1.0425	.9328	1.0242	.961
12	.924	.9511	.9145	.9877	.8779	.9877	.924
13	.9055	.9431	.9145	1.0791	.9511	.8962	.8686
14	.8686	.8779	.9145	.8413	1.0242	.9511	.8501
15	.8871	.8413	.8596	.8413	.9328	1.0059	.924
16	.924	.8779	.9145	.9328	.9694	1.0059	.961
17	.924	.8779	.9145	1.0059	1.0059	1.134	1.0349
18	.961	.9511	1.0974	1.0791	.9877	1.1157	1.1088
19	1.1088	1.1888	1.2803	1.1088	1.2437	1.2437	1.0719
20	1.2012	1.0974	1.2071	1.1458	1.134	1.4083	1.1458
21	1.0349	1.0242	1.134	1.1827	1.1523	1.2803	1.1458
22	.8871	.8962	1.0059	1.0164	1.0242	1.0425	1.0349
23	.7762	.8596	.8779	.8871	.9328	.8779	.924
24	.7392	.7392	.7865	.8316	.823	.8413	.8871
Max	1.2012	1.1888	1.2803	1.1827	1.2803	1.4083	1.1888
Min	.695	.695	.7133	.7682	.7316	.7682	.7499
Avg	.9269	.9196	.9404	.9827	.9907	1.0067	.9709

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 201 / PANTHEWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.9526
Max	.9526
Min	.9526
Avg	.9526



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 202 / KAUTGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	1.1431
Max	1.1431
Min	1.1431
Avg	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 203 / PAITHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.0479
Max	1.0479
Min	1.0479
Avg	1.0479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 204 / RAHATGAON  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	2.0957
Max	2.0957
Min	2.0957
Avg	2.0957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 205 / MIDC FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	2.6673
Max	2.6673
Min	2.6673
Avg	2.6673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 206 / CHAGATPURI  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-SEP-17
HR	Load (MW)
24	.381
Max	.381
Min	.381
Avg	.381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 207 / PIMPALWADI GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17
HR	Load (MW)
24	3.0483
Max	3.0483
Min	3.0483
Avg	3.0483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 208 / BALANAGAR  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	4.763
Max	4.763
Min	4.763
Avg	4.763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 401 / 33 KV Paper Mill  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	3.4294
Max	3.4294
Min	3.4294
Avg	3.4294



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 402 / 33 KV Bidkin  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 403 / 33 KV Pachod  
Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	4.2867
Max	4.2867
Min	4.2867
Avg	4.2867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 404 / 33 KV ABAD WATER WORKES NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-SEP-17
HR	Load (MW)
24	5.144
Max	5.144
Min	5.144
Avg	5.144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 407 / 33 KV Dawarwadi  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	4.0009
Max	4.0009
Min	4.0009
Avg	4.0009

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 047020 / PAITHAN 132 KV

Feeder No / Name : 703 / 132 kv HYDRO POWER PLANT NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
 Feeder KV- 132 / OUTGOING (NON CONTINOUS PROCESS)(NO  
 STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 401 / 33 KV Bidkin

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
 (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	8.5734
Max	8.5734
Min	8.5734
Avg	8.5734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 402 / 33 KV Allana  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	6.8587
Max	6.8587
Min	6.8587
Avg	6.8587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 403 / 33 KV Badve Engineering  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	6.2872
Max	6.2872
Min	6.2872
Avg	6.2872



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 404 / 33 KV Water Workes

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	8.5734
Max	8.5734
Min	8.5734
Avg	8.5734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 405 / 33 KV AURANGABAD ELECTRICAL NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	10.2881
Max	10.2881
Min	10.2881
Avg	10.2881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 406 / 33 KV CHITEGAON

Feeder KV- 33 / INCOMING

DATE	01-SEP-17
HR	Load (MW)
24	9.145
Max	9.145
Min	9.145
Avg	9.145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 407 / 33 KV Jailaxmi

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	9.7165
Max	9.7165
Min	9.7165
Avg	9.7165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 408 / 33 KV Videcon  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	8.0018
Max	8.0018
Min	8.0018
Avg	8.0018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 409 / 33 KV RAJANGAON(KHURI)  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-SEP-17
HR	Load (MW)
24	7.4303
Max	7.4303
Min	7.4303
Avg	7.4303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL I DIVN.[224]

PAITHAN (R) S/D[398] BU 2232

Substation No/ Name :- 048028 / 220 KV CHITEGAON

Feeder No / Name : 703 / 132 KV R L STEEL FEEDER  
Feeder KV- 132 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-SEP-17
HR	Load (MW)
23	11.4312
24	16.0037
Max	16.0037
Min	11.4312
Avg	13.7175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11 KV JAMGAON FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.1715	.0572	.0857	.0572	
2	.0857	.0953	.1715	.0762	.0857	.0762	
3	.0857	.1143	.1715	.0572	.0857	.0572	
4	.0857	.1334	.1715	.0762	.12	.0572	
5	.0857	.1524	.1905	.0572	.12	.0762	
6	.0857	.1715	.2096	.0953	.12	.1143	
7	.0857	.1905	.2096	.1524	.1886	.2858	
8	.1029	.2096	.2286	.2096	.2401	.381	
9	.1543	.2477	.2229	.2743	.3048	.3429	
10							.2401
11							.2572
12							.2743
13							.3086
14							.3086
15							.3258
16			.0171			.0171	.2915
17				.0171		.0171	.3772
18	.0191			.0171		.0191	.0171
19	.0191			.0343	.0381	.0191	.0171
20	.0191			.0171	.0381	.0381	.0343
21	.0191			.0171		.0381	.0343
22	.0191		.0762	.0171		.0381	.0171
23	.0191			.0171		.0381	.0171
24	.1029	.0953	.1905	.0762	.0857	.0572	
Max	.1543	.2477	.2286	.2743	.3048	.381	.3772
Min	.0191	.0762	.0171	.0171	.0381	.0171	.0171
Avg	.0672	.1486	.1693	.0746	.1260	.0961	.1800



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11 KV MANJARI FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0762	.0762	.0762	.1029	.0762	.3086
2	.1029	.0762	.0762	.0572	.1029		.3086
3	.1029	.0762	.0762		.1029		.3258
4							.3429
5							.3601
6							.4287
7							.4458
8							.7545
9							.7373
10	.3429	.4191	.3772	.3944	.6097	.5487	
11	.3429	.4954	.4458	.5144	.5335	.6173	
12	.3772	.4763	.4115	.5144	.5716		
13		.4382	.4115	.4973	.5144		
14		.4191	.4287	.4973	.5716	.6516	
15	.2915	.4382	.4287	.4973	.5144	.6001	
16	.381			.4973	.5335	.6001	.0171
17	.4191		.4763	.3086	.5716	.6173	.0171
18	.0762		.0572	.0514		.0686	.0514
19	.0953			.1029	.0762	.0686	.0857
20	.0762			.12	.1143	.0686	.0686
21	.0762			.0857		.0686	.0514
22	.0762		.0762	.1029	.0762	.0514	.0514
23	.0953			.1029		.0514	.0514
24	.1029	.0762	.0762		.1029		.1715
Max	.4191	.4954	.4763	.5144	.6097	.6516	.7545
Min	.0762	.0762	.0572	.0514	.0762	.0514	.0171
Avg	.1914	.2991	.2629	.2763	.3399	.3145	.2543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11 KV MALUNJA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5335	.5716	.4954	.6516	.2286	.1372
2	.5144	.5716	.6097	.5335	.6516	.381	.1715
3	.5316	.6097	.6668	.6478	.6859	.4954	.1886
4	.5487	.6668	.7621	.724	.7202	.5716	
5	.6001	.7621	.9145	.8002	.7716	.6668	
6	.6344	.9526	1.086	.8383	.823	.8954	
7	.8573	1.105	1.086	1.1812	1.1488	1.3336	
8	.7545	1.1431	1.2955	1.1812	1.3717	.5716	
9	.8402	1.2384	1.0974	1.2003	1.1812	1.3889	
10					1.1812		1.0631
11							1.1145
12							1.2003
13							1.1145
14							1.0288
15							.9945
16	.1334		.1372	.12		.12	1.1145
17	.1334		.1524	.1372	.0762	.1372	1.1145
18	.1715			.1715		.1543	.1372
19	.2858		.1524	.2401		.1715	.2058
20	.2858		.0953	.2915	.1524	.1886	.2401
21	.2667		.0953	.2229	.1905	.2058	.2401
22	.2286		.0953	.2058	.0762	.2229	.2229
23	.2477			.1886	.0762	.2401	.2229
24	.4801	.5716	.5716	.5716	.6173	.0572	.2058
Max	.8573	1.2384	1.2955	1.2003	1.3717	1.3889	1.2003
Min	.1334	.5335	.0953	.12	.0762	.0572	.1372
Avg	.4460	.8154	.5868	.5417	.6485	.4461	.5954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / TOWN I FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.9526	.9145	.8954	.8402	.8764	.7716
2	.8745	.9907	.9526	.9907	.8573	.9526	.823
3	.8745	1.0479	1.0479	1.105	.8573	1.105	.8573
4	.9088	1.1431	1.2955	1.2574	1.0288	1.2193	.9431
5	.9774	1.2384	1.1431	1.3717	1.2003	1.3336	1.0288
6	1.286	1.4289	1.4289	1.5242	1.3889	1.4289	1.286
7	1.4403	1.5432	1.5813	1.5623	1.5604	1.5242	1.4232
8	1.4232	1.4289	1.4098	1.5242	1.4746	1.3908	1.3375
9	1.2174	1.3146	1.1317	1.2517	1.4289	1.1145	1.0631
10	.9945	1.2384	1.0288	1.0974	1.1812	1.0117	.9945
11	.9945	1.0669	.9602	.9088	1.1431	.9945	.9431
12	.9259	.9526	.8402	.9602	1.0098	.9602	.8573
13	.9088	.9145	.823	.8916	.8954	.8916	.8745
14	.8573	.8383	.8059	.8573	.9526	.8573	.8573
15	.8059	.8954	.9259	.8573	1.1812	.7888	.8573
16	.9526		.8745	.823	.9526	.8916	.9088
17	1.0288		.9526	.8745	1.3336	.9431	.9088
18	1.1431		1.0669	.8745	1.4861	1.0288	1.0802
19	1.5051		1.448	1.2003	1.5813	.4287	1.3032
20	1.4289		1.467	1.2517	1.5242	1.2003	1.2346
21	1.3717		1.2955	1.1317	1.2955	1.0288	1.2003
22	1.3336		1.1431	1.0631	1.1431	.9431	1.0631
23	1.1431		1.0288	.9602	1.0669	.9088	.9602
24	.823	.9526	.9526	.9526	.8916	.9526	.8573
Max	1.5051	1.5432	1.5813	1.5623	1.5813	1.5242	1.4232
Min	.8059	.8383	.8059	.823	.8402	.4287	.7716
Avg	1.0865	1.1217	1.1049	1.0911	1.1781	1.0323	1.0181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 205 / TOWN II FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5335	.5335	.4572	.463	.4572	.4801
2	.4287	.5716	.5716	.5335	.463	.5335	.5144
3	.4801	.5716	.6668	.6097	.4801	.5716	.5658
4	.4801	.5716	.7049	.6859	.5144	.6478	.6001
5	.5316	.6668	.724	.724	.6001	.6859	.5144
6	.6859	.8002	.8002	.7621	.7888	.7621	.7373
7	.7888	.8764	.8954	.8002	.823	.8954	.7716
8	.7545	.7621	.8573	.8383		.7621	.6859
9	.6173	.6859	.6687	.6859	.724	.7202	.6516
10	.583	.6287	.5316	.6001	.6097	.6001	.5658
11	.4973	.5906	.4973	.5316	.5335	.583	.5144
12	.4973	.5335	.4973	.4801	.5716	.5144	.4973
13	.3772	.4954	.4287	.4458	.4954	.5144	.4801
14	.3772	.4763	.4115	.4287	.4763	.4801	.463
15	.3944	.4763	.3944	.4115	.4572	.4458	.463
16	.4572		.3944	.3944	.5144	.4287	.463
17	.4954		.4572	.4287	.5716	.5144	.5144
18	.6097		.5716	.5144	.6859	.6001	.6001
19	.724		.6859	.6687	.7621	.6516	.6687
20	.6668		.7621	.6516	.724	.6001	.6344
21	.5716		.6859	.583	.6478	.5144	.6001
22	.5335		.5716	.5658	.6097	.4973	.5658
23	.4954		.5335	.5316	.5716	.4801	.5316
24	.4287	.4763	.5335	.4954	.4973	.4954	.463
Max	.7888	.8764	.8954	.8383	.823	.8954	.7716
Min	.3772	.4763	.3944	.3944	.4572	.4287	.463
Avg	.5377	.6073	.5991	.5762	.5906	.5815	.5644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 206 / TOWN III FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2667	.2477	.1905	.2401	.2667	.2229
2	.2915	.3048	.2667	.2286	.2401	.3048	.2401
3	.2915	.3429	.2858	.3048	.2572	.3429	.2572
4	.3086	.381	.3048	.3429	.2915	.381	.3086
5	.3429	.4001	.3239	.381	.3086	.381	.3429
6	.4287	.4382	.4763	.4572	.3772	.4191	.4287
7	.4287	.4763	.5335	.4763	.4115	.4954	.463
8	.463	.4382	.381	.4572	.3429	.4572	.3772
9	.3086	.362	.3086	.3429	.3429	.3086	.3601
10	.2401	.3048	.2572	.2572	.3048	.3086	.2572
11	.2401	.2858	.2401	.2572	.2286	.2743	.2401
12	.2572	.2667	.2401	.2401	.2667	.2401	.2401
13	.2401	.2667	.2401	.2058	.2286	.2572	.2058
14	.2401	.2477	.2401	.1886	.2286	.6859	.2229
15	.2401	.2096	.2743	.2229	.2286	.1886	.2229
16	.3048		.2401	.2572	.2858	.2058	.2401
17	.2858		.3048	.2401	.2667	.2743	.2915
18	.3429		.2858	.2572	.3429	.3086	.2915
19	.4001		.381	.3601	.4572	.3944	.3772
20	.381		.4191	.3601	.381	.3429	.3429
21	.362		.3429	.3086	.3429	.3086	.3429
22	.3429		.3239	.3086	.3048	.2743	.2915
23	.3239		.3048	.2401	.2858	.2743	.2572
24	.2572	.3048	.2667	.2667	.2401	.2286	.2401
Max	.463	.4763	.5335	.4763	.4572	.6859	.463
Min	.2401	.2096	.2401	.1886	.2286	.1886	.2058
Avg	.3158	.3310	.3121	.2980	.3002	.3301	.2944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 207 / 11 KV WARKHED FEEDER  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.1715
2							.2058
3							.2401
4							.2743
5							.3086
6							.3258
7							.3429
8							.583
9							.3429
10	.3944	.4191	.4287	.6344	.5487	.4801	
11	.4287	.4763	.463	.6859	.7545	.5487	
12	.4115	.381		.6173	.7545	.6173	
13	.4287	.362	.4287	.5658	.724	.6859	
14	.4287	.3429	.4287	.5316	.7621	.6859	
15	.4458	.381		.5487	.7049	.5144	
16	.3429		.583	.6173	.7621	.4801	
17	.2667		.724	.6173	.8192	.4801	
24							.1715
Max	.4458	.4763	.724	.6859	.8192	.6859	.583
Min	.2667	.3429	.4287	.5316	.5487	.4801	.1715
Avg	.3934	.3937	.5094	.6023	.7288	.5616	.2966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 208 / 11 kv NAWABPUR GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4763	.4382	.4572	.4287	.4954	.3944
2	.4801	.5335	.4763	.5335	.4458	.5335	.4287
3	.4973	.5716	.5144	.6859	.5144	.6478	.4801
4	.4973	.6668	.5335	1.3717	.6173	.724	.5144
5	.5144	.7621	.6668	.9907	.7716	.8764	.6001
6	1.0802	.8002	.9526	1.1431	1.1831	1.0098	.7716
7	.9088	.8764	1.2574	.9526	.8573	1.0288	.9259
8	.7373	.7621	1.0098	.8573	.7888	.9907	.8402
9	.6516	.5716	.6687	.6859	.724	.6344	.5658
10	.3772	.4763	.463	.4115	.6287	.4801	.3944
11	.3086	.362	.3086	.3086	.5144	.463	.3601
12	.2058	.3239	.2401	.1886	.3048		.3429
13		.3048	.2229	.1886	.2667		.3086
14		.2858	.2058	.1886	.2858	.2743	.2743
15	.3429	.2096	.2058	.2058	.2667	.2743	.2572
16	.4191			.2915	.3239	.3086	.1886
17	.4954		.381	.3258	.381	.4287	.2915
18	.5525		.4382	.463	.6478	.724	.463
19	.8002		.8573	.7373	.8192	.8573	.7545
20	.7621		.9145	.8402	.7621	.7621	.823
21	.5716		.8002	.583	.6478	.6668	.6859
22	.5335		.6859	.5316	.5716	.5716	.5144
23	.4763		.4763	.463	.4954	.4382	.4458
24	.3429	.381	.4763	.4954	.4287	.4572	.3429
Max	1.0802	.8764	1.2574	1.3717	1.1831	1.0288	.9259
Min	.2058	.2096	.2058	.1886	.2667	.2743	.1886
Avg	.5471	.5228	.5736	.5792	.5698	.6203	.4987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044001 / 33/11 KV GANGAPUR

Feeder No / Name : 209 / 11KV NEW INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0762	.0686			.1543
2			.0762	.0514			.1372
3			.0762	.0686			.1372
4			.0762	.0514			.12
5			.0762	.0686	.0686		.1372
6			.0762	.0857	.1372		.1543
7			.0762		.1543		.1543
8			.0762	.0514	.1372		
9	.0686	.0762	.0762		.1524	.1715	
10		.0953			.1524	.1372	
11	.0686	.1143			.1334	.1372	
12	.0686	.1524		.0686	.1905		
13	.0686	.1524	.0686		.1334		
14	.0686	.1905			.1905		
15		.1524					.0686
16	.0762		.0686	.0686	.0953		.0686
17	.0762		.0762				
18					.1143	.0857	
19						.1029	
20						.12	
21			.0572			.1372	
22			.0572			.1372	
23			.0762			.1372	
24			.0762				
Max	.0762	.1905	.0762	.0857	.1905	.1715	.1543
Min	.0686	.0762	.0572	.0514	.0686	.0857	.0686
Avg	.0708	.1334	.0729	.0648	.1383	.1296	.1257



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 201 / 11KV TURKABAD AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1905	.1524	.2286		.0373
2		.1905	.1524	.2286		.0183
3		.1905	.1524	.2286		.0187
4		.1905	.1524	.2286		
5		.2286	.1905	.2477		
6		.2667	.2286	.2401		
7		.3429	.2743	.3429		
8		.3429	.3086	.3688		
9		.3086	.3429	.4409		
10						.1311
11						.1311
12						.1147
13						.116
14						.1017
15						.1134
16	.1143	.1143	.0678	.0162	.0351	.1311
17	.1905	.1143	.0678	.0164	.0362	.0328
18	.2286	.1334	.1638	.0162	.0187	.0328
19	.2286	.1905	.2035	.0164	.0373	.0328
20	.2286	.2286	.1943	.017	.0373	.0164
21	.1905	.2286	.1619	.0162	.0373	.0162
22	.1524	.1524	.1638	.0164	.0187	.0164
23	.1143	.1334	.1696	.0164	.0187	.0166
24		.1905	.1524	.2286		.0187
Max	.2286	.3429	.3429	.4409	.0373	.1311
Min	.1143	.1143	.0678	.0162	.0187	.0162
Avg	.1810	.2077	.1833	.1619	.0299	.0609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 202 / 11 KV SHIVRAI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143	.0953	.1143	.0655		.3506
2		.1143	.1143	.1143	.0655		.4755
3		.1334	.1524	.1334	.0655		.4908
4							.5258
5							.6241
6							.7316
7							.7362
8							.8063
9							.8939
10	.2572	.381	.3429	.5087		.7316	
11	.2572	.3601	.4973	.6203		.8962	
12	.2572	.3601	.4973	.5735		.9145	
13	.2572	.3601	.4973	.6274		.8596	
14	.2572	.3772	.4973	.6203		.7811	
15	.2743	.3772	.4973	.5668		.8589	
16	.2743	.4115	.4973	.5087		.8779	.0492
17	.2743	.3772	.4801	.4858		.9335	.0648
18	.1143	.1143	.1143	.0848		.0732	.0648
19	.1334	.1143	.1334	.0838		.0732	.0678
20	.1334	.1143	.1334	.0819		.0709	.0655
21	.1143	.0953	.0953	.0678		.0362	.0492
22	.1143	.0953	.0953	.0678		.0366	.0655
23	.1143	.0953	.0953	.0655		.2804	.0655
24		.1143	.0953	.0953	.0655		.3292
Max	.2743	.4115	.4973	.6274	.0655	.9335	.8939
Min	.1143	.0953	.0953	.0655	.0655	.0362	.0492
Avg	.2024	.2283	.2740	.3011	.0655	.5303	.3587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 203 / 11 KV DAHEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0191	.0191	.0328		
2		.0191	.0191	.0191	.0328		
3		.0191	.0191	.0191	.0339		
10		.1524	.1372	.1638		.0351	
11		.1715		.1638		.0343	
12		.1715		.1638		.0351	
13	.1143	.1715	.1715	.1475			
14	.1143	.1143	.1543	.1526		.0701	
15	.1143	.1143	.1715	.1357		.0701	
16	.1143	.1143	.1543		.1357	.0701	.0162
17	.1334	.1715	.1543		.0339	.0343	.0162
18	.0191	.0191	.0191		.0339	.0187	.0164
19	.0191	.0191	.0191		.0324		.0164
20	.0191	.0191	.0191		.0328		.0166
21	.0191		.0191		.0328		.0164
22	.0191		.0191		.0324		.0162
23	.0191		.0191		.0328		.0164
24		.0191	.0191	.0191	.0328		
Max	.1334	.1715	.1715	.1638	.1357	.0701	.0166
Min	.0191	.0191	.0191	.0191	.0324	.0187	.0162
Avg	.0641	.0877	.0709	.1004	.0416	.0460	.0164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 204 / 11 KV MANGEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1524	.1524	.2286	.2012		.0366
2		.1524	.1524	.2286	.1966		.0366
3		.1524	.1524	.2286	.1638		.0366
4		.1905	.1524	.2286	.1638		
5		.2286	.1715	.2286	.2374		
6		.2667	.1905	.2229	.2458		
7		.2858	.2058	.2401	.2458		
8		.3048	.2401	.1677	.2785		
9		.2743	.2743	.3391	.3563		
10							.2429
11							.2458
12							.2458
13							.2591
14							.2458
15							.2543
16	.0191	.0191	.0191	.0164		.0187	.2753
17	.0191	.0191	.0191	.0164		.0183	.2949
18	.0191	.0191	.0191	.0164		.0179	.0324
19	.0191	.0191	.0381	.0164		.0187	.0332
20	.0191	.0191	.0381	.0164		.0187	.0328
21	.0191	.0191	.0381	.0164		.0183	.0328
22	.0191	.0191	.0381	.0164		.0183	.0328
23	.0191	.0191		.017		.0183	.0328
24		.1524	.1524	.2286	.2035		.0366
Max	.0191	.3048	.2743	.3391	.3563	.0187	.2949
Min	.0191	.0191	.0191	.0164	.1638	.0179	.0324
Avg	.0191	.1285	.1208	.1374	.2293	.0184	.1337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 205 / 11 kv DAHEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)
1		.8676
2		.9335
3		1.1317
4		1.1203
5		1.4937
6		1.6804
7		1.6221
8		1.4327
9		1.0745
10	.9526	
11	.9431	
12	.7167	
14	.7167	
15	.5228	
16	.7095	
17	.9335	
18	.9431	
19	1.1317	
20	1.1694	
21	1.1317	
22	1.0456	
24		.7545
<b>Max</b>	<b>1.1694</b>	<b>1.6804</b>
<b>Min</b>	<b>.5228</b>	<b>.7545</b>
<b>Avg</b>	<b>.9097</b>	<b>1.2111</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 206 / 11 KV TURKABAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8002	.8002	.7621	.8192		.7316
2		.8002	.8002	.7621	.7865		.8589
3		.8002	.8764	.8764	.7287		1.1203
4		1.0288	.9526	.9526	.9012		1.2071
5		1.4575	1.2955	.9945	1.065		1.39
6		1.7147	1.7147	1.6289	1.1142		1.4632
7		1.5432	1.5775	1.5432	1.1961		1.4083
8		1.2003	1.286	1.3279	1.2146		1.2803
9		1.2574	1.2384	1.1233	1.2955		1.2071
10	.9774	1.1431		1.0898		1.0456	.8097
11	.6097	.9526				.9335	.7865
12		.8573		.9717		.8215	.7701
13		.5525				.7468	.7373
14	.5716	.6478	.4588	.9012		.6722	.6962
15	.8002		.5243	.8097		.7468	.6554
16		.7621		.7611		.8413	.6802
17	.8954	.9145	.5243	.7287		.9145	.7373
18	1.2003	1.1431	1.0174	.6802		1.0974	.8817
19	1.5242	1.3717	1.491	.8745		1.0608	.9339
20	1.5051	1.2955	1.1142	1.0486		.9335	1.004
21	1.0288	.9907	.8192	1.166		.8413	1.0978
22	.8764	.8764	.7291	1.0159		.7468	.9012
23	.8002	.8002	.6554	.9724		.695	.8192
24		.8002	.8002	.7621	.9012		.5601
Max	1.5242	1.7147	1.7147	1.6289	1.2955	1.0974	1.4632
Min	.5716	.5525	.4588	.6802	.7287	.6722	.5601
Avg	.9808	1.0309	.9829	.9888	1.0022	.8641	.9474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 207 / 11 KV YESGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381	.0191	.0381	.0324		.1829
2		.0381	.0191	.0381	.0328		.1829
3		.0381	.0191	.0572	.0328		.2195
4							.2195
5							.1829
6							.2195
7							.1867
8							.1463
9							.1829
10	.1524	.1524		.1357		.2195	.1638
11	.1524	.1524				.2195	
12	.1524	.1715		.1357		.2561	
13	.1524		.1492			.2195	
14	.1524			.1296		.1829	
15	.1715		.1509	.1311		.1772	
16		.1143		.1311		.1829	.0164
17	.0572			.1311		.1463	.0166
18	.0381	.0191	.0166	.0328		.0366	.0168
19	.0381	.0191	.0663	.0324		.0183	.0164
20	.0381	.0191	.0671	.0324		.0177	.0164
21	.0381	.0191	.0663	.0328		.0183	.0164
22	.0381	.0191	.0678	.0164		.0183	.0162
23	.0381	.0191	.0655	.0164		.1463	.0164
24		.0381	.0191	.0381	.0339		.1829
Max	.1715	.1715	.1509	.1357	.0339	.2561	.2195
Min	.0381	.0191	.0166	.0164	.0324	.0177	.0162
Avg	.0938	.0613	.0605	.0706	.0330	.1328	.1159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 208 / 11KV ARYANSH IND FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4763	.3429	.6097	.6554		.2195
2		.4763	.3429	.5716	.6226		.2561
3		.4763	.3429	.5716	.6062		.2614
4		.4763	.381	.5716	.5992		.2987
5		.5144	.381	.6097	.5668		.2926
6		.5335	.6668	.6287	.5735		.3361
7		.5335	.6668	.6287	.6443		.2614
8		.2858	.7621	.5365	.6554		.3361
9		.2858	.7621	.5426	.6299		.3734
10	.6668	.2858	.7621	.5801		.2926	.4191
11	.6668	.2858	.7621	.583		.3292	.4144
12	.6668	.2858	.8002	.5182		.3658	.4424
13	.5716	.2667	.8002	.5735		.3292	.4696
14	.4191	.2667	.8002	.5243		.3292	.4915
15	.381	.2667	.8002	.5735		.3658	.5426
16	.381	.2477	.7621	.6554		.4024	.7122
17	.362	.2477	.7621	.664		.3658	.7545
18	.5716	.2667	.4572	.7287		.2926	.7045
19	.6097	.2096		.7865		.2987	.6882
20	.6478	.1905	.5716	.8478		.2614	.6554
21	.6668	.1715	.5716	.8192		.2241	.6226
22	.6668	.1715	.5716	.7042		.1829	.5735
23	.6478	.1715	.5716	.6554		.1867	.5243
24		.4763	.3429	.6097	.6783		.2195
Max	.6668	.5335	.8002	.8478	.6783	.4024	.7545
Min	.362	.1715	.3429	.5182	.5668	.1829	.2195
Avg	.5661	.3279	.6080	.6289	.6232	.3019	.4529



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044015 / 33/11 KV LIMBEJALGAON

Feeder No / Name : 209 / SAVERA IND FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.6668	.6668	.6554		.7316
2		.6478	.6668	.6097	.639		.7842
3		.6668	.6668	.6097	.5898		.7468
4		.6668	.6859	.6097	.5898		.6805
5		.6668	.7049	.6668	.5668		.7316
6		.6859	.724	.6859	.5735		.7682
7		.7049	.724	.7049	.6062		.7316
8		.8573	.7621	.3201	.6316		.695
9		.8764	.7621	.3441	.6226		.7316
10	.381	.8573	.7621	.3768		.7316	.6952
11	.2858	.7621	.7621	.4096		.7842	.6882
12	.2858	.7621	.7621	.2543		.8048	.6882
13		.7621	.7621	.2429		.8215	.7045
14	.2858	.7621	.7621	.3391		.7316	.7373
15	.7621	.7621	.7621	.373		.8048	.7373
16	.7621	.8002	.8002	.5087		.7865	.7537
17	.8002	.8192	.7049	.5935		.7682	.7373
18	.7621	.8573	.724	.6783		.7468	.7122
19	.724	.743		.7122		.7316	.6554
20	.7049	.6668	.6668	.7373		.6219	.6554
21	.6668	.6478	.6668	.7701		.6584	.6226
22	.6478	.6478	.6668	.6554		.7468	.57
23	.6478	.6478	.6668	.6706		.7316	.503
24		.6478	.6668	.6668	.6718		.695
Max	.8002	.8764	.8002	.7701	.6718	.8215	.7842
Min	.2858	.6478	.6668	.2429	.5668	.6219	.503
Avg	.5936	.7319	.7174	.5503	.6147	.7479	.6982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 201 / 11 KV SHENDURWADA 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.4715	.5658	.5716	.6602	.3395	.7602
2	.2829	.4715	.5658	.5716	.5658	.3395	.7602
3	.2829	.5281	.5658	.6668	.5658	.3772	.724
4	.3772	.6602	.6602	.6859	.6602	.4715	.724
5	.3772	.7167	.7545	.6859	.7545	.5658	.7602
6	.4715	.7545	.7545	.6859	.811	.5658	.7602
7	.5658	.7545	.7545	.9259	.8488		.7602
8	.5658	.6602	.7545	.503	.7545		.7602
9	.4715	.2829	.6173	.2263	.3772		.5658
10	.4715	.3772	.6344	.2829	.3772		.4715
11	.3772		.6173	.2829	.3395	.3395	.3772
12	.3772	.3772	.6001		.3395	.3395	.3395
13	.3772	.3772	.5487		.3395	.3772	.3395
14	.3772	.3772	.5316		.3395	.3772	.3772
15	.3772	.3772	.5487			.3772	.3772
16	.3772	.3772	.5487	.6602	.3772	.3772	.3395
17	.4715	.4715		.4715	.724	.8688	.3429
18	.5658	.5658	.6859	.6602	.7783	.905	.3772
19	.6602	.6602	.7716	.7545	.8145	.9231	.3944
20	.7545	.7545	.8573	.8488	.8145	.9431	.4115
21	.6602	.7167	.8745		.7783	.8688	.4287
22	.6602	.6413	.7621	.8488	.7783	.8145	.4287
23	.6036	.6602	.823	.811	.7783	.8145	.4287
24	.4904	.547	.6602	.8764	.7733	.7783	.8145
Max	.7545	.7545	.8745	.9259	.8488	.9431	.8145
Min	.2829	.2829	.5316	.2263	.3395	.3395	.3395
Avg	.4739	.5470	.6720	.6326	.6239	.5882	.5343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 202 / 11 KV SAWAKHEDA 1 SINGLE PHASING  
PHASHING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0754	.0754	.0572	.0943	.0943	.1294
2		.0754	.0754	.0572	.0943	.0943	.1294
3		.0754	.0943	.0572	.0943	.0943	.1294
4		.0943	.1132	.0572	.1132	.1132	.1294
5		.0943	.1509	.0572	.1509	.1509	.1478
6		.1132	.1509	.0762	.1509	.1867	.1848
7		.1132	.1132	.0762	.1509	.1494	.1848
8		.1132	.0943	.0762	.1509	.1509	.1848
9		.0943	.0953		.132	.1132	.1132
10		.0943	.0762		.132	.1132	.1132
11	.0943	.0943	.0762	.0943	.1132	.0943	.0943
12	.0943	.1132	.0572	.0943	.1132	.0754	.0943
13	.1132	.1132	.0514	.0943	.1132	.0754	.0943
14	.1132	.0943	.0572	.0943	.1132	.0754	.0943
15	.0943	.0943	.0572	.0943		.0943	.1132
16	.0943	.0943	.0762	.0943	.1132	.0943	.1132
17	.1132	.1132	.0953	.1132	.112	.1307	.1143
18	.1509	.1509	.1143	.1509	.1494	.132	.12
19	.1698	.1509	.1143	.1509	.1494	.1646	.1029
20	.1886	.1132	.1143	.1132	.0373	.1646	.12
21	.1698	.1132	.1143		.1494	.128	.1029
22	.1698	.1132	.1029	.0943	.112	.128	.0953
23	.1509	.0943	.1029	.0943	.0934	.128	.0857
24		.1132	.0943	.1143	.0943	.0934	.1307
Max	.1886	.1509	.1509	.1509	.1509	.1867	.1848
Min	.0943	.0754	.0514	.0572	.0373	.0754	.0857
Avg	.1320	.1045	.0945	.0910	.1186	.1183	.1217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 203 / 11 KV MAHALAXMIKHEDA(LIS- SINGLE PHASING

I) 1 Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5658	.5658	.5716	.6602	.4715	.5658
2	.5658	.4715	.5658	.5716	.5658	.4715	.5658
3	.4715	.4715	.6602	.6668	.5658	.5658	.6602
4	.4715	.6602	.7545	.7621	.9431	.5658	.7468
5	.6602	.9431	1.1317	.8573	1.1317	.6535	.9335
6	.7545	1.1317	1.1317	.9526		.7468	1.0269
7	.9431					.3734	1.0269
8	1.1317			.9526		.7468	.8402
9	.4715	.6602	.3772	1.0479	.7602	.8688	.6602
10	.5658	.7167	.4458		.8145	.9231	.5658
11	.6036		.4572	.4715	.8145	.905	.4715
12			.6001	.5281	.8145	.905	
13			.5792	.5658	.7602	.905	
14			.4877	.6413	.7602	.905	
15	.4715	.6602		.6602		.905	.3772
16	.679	.6602	.5658	.6413	.724	.905	.3772
17	.7545	.9431	.6859	.7545	.5658	.5658	.6001
18	.9431	.9431	.2915	.8488	.7468	.5658	.6859
19	1.1317	1.1317	1.0288	1.1317	.8402	.7468	.6401
20	.9431	1.1317	1.1145	.9431	.8402	.7468	.7373
21	.8488	.9431	1.2003		.7468	.7468	.6859
22	.8488	.8488	1.0288	.9431	.5658	.6602	.6706
23	.7545	.7545	.8573	.8488	.4715	.5658	.7202
24	.7545	.6602	.7545	.6859	.7545	.4715	.5658
Max	1.1317	1.1317	1.2003	1.1317	1.1317	.9231	1.0269
Min	.4715	.4715	.2915	.4715	.4715	.3734	.3772
Avg	.7302	.7943	.7278	.7641	.7423	.7036	.6726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 204 / 11KV MUKTESHWAR HT EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0566	.0381	.0566	.0377	.0377
2	.0566	.0566	.0566	.0381	.0566	.0377	.0377
3	.0566	.0566	.0566	.0572	.0566	.0377	.0377
4	.0566	.0754	.0566	.0762	.0754	.0377	.0377
5	.0566	.0754	.0566	.0572	.0943	.0566	.0377
6	.0566	.0566	.0566	.0572	.0754	.0566	.0566
7	.0566	.0566	.0566	.0762	.0566	.0566	.0566
8	.0566	.0566	.0566	.0572	.0566	.0377	.0377
9	.0754	.0754	.0762	.1132	.0747	.0377	.0377
10	.0943	.0943	.0762	.1509	.112	.0566	.0566
11	.0943	.0943	.0572	.1509	.1494	.0934	.0377
12	.0943	.0943	.0762	.1698	.1494	.112	.0377
13	.0943	.0943	.0953	.1509	.1494	.1109	.0377
14	.0754	.0754	.0762	.1509	.1478	.1109	.0377
15	.0754	.0754	.0953	.132		.1509	.0377
16	.0754	.0566	.0762	.1132	.0934	.1494	.0377
17	.0566	.0566		.0943	.0747	.0566	.0381
18	.0566	.132	.0572	.0943	.0566	.0377	.0381
19	.0566	.0566	.0572	.0943	.0566	.0377	.0343
20	.0566	.0566	.0572	.0754	.0566	.0377	.0381
21	.0566	.0566	.0381		.0377	.0377	.0381
22	.0566	.0566	.0343	.0754	.0377	.0377	.0381
23	.0754	.0566	.0381	.0754	.0377	.0377	.0381
24	.0566	.0754	.0566	.0381	.0566	.0377	.0377
Max	.0943	.132	.0953	.1698	.1494	.1509	.0566
Min	.0566	.0566	.0343	.0381	.0377	.0377	.0343
Avg	.0668	.0707	.0618	.0929	.0791	.0625	.0400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 205 / 11KV LIS II 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0377	.0377	.0381	.0377	.0377	.0377
2	.0754	.0377	.0377	.0381	.0377	.0377	.0377
3	.0754	.0377	.0377	.0381	.0377	.0377	.0377
4	.0943	.0377	.0377	.0381	.0566	.0377	.0377
5	.0943	.0566	.0377	.0572	.0566	.0377	.0377
6	.1132	.0566	.0377	.0762	.0566	.0566	.0566
7	.1132	.0566	.0566	.0762	.0754	.0566	.0566
8	.0943	.0377	.0566	.0762	.0754	.0377	.0566
9	.1132	.1886	.061		.1991	.3258	.0377
10	.1509	.1886	.0762		.2353	.3439	.0377
11	.1698		.1334	.1886	.2534	.362	.0377
12	.1698		.1524	.1886	.2534	.362	
13	.1886		.1219	.2075	.2534	.362	
14	.2075		.1372	.2263	.2534	.3801	
15	.2075	.2075		.2263		.3439	.0377
16	.2075	.2075	.1372	.2263	.2896	.3077	.0377
17	.0754	.1509		.0754	.0377	.0377	
18	.0754	.1132	.0343	.0754	.0377	.0377	
19	.0566	.0943	.0381	.0754	.0566	.0566	.1143
20	.0566	.0943	.0381	.0566	.0566	.0566	.12
21	.0377	.0754	.0381		.0377	.0377	.1372
22	.0377	.0566	.0343	.0566	.0377	.0377	.12
23	.0377	.0377	.0343	.0377	.0377	.0377	.1372
24	.0943	.0377	.0377	.0343	.0377	.0377	.0377
Max	.2075	.2075	.1524	.2263	.2896	.3801	.1372
Min	.0377	.0377	.0343	.0343	.0377	.0377	.0377
Avg	.1092	.0905	.0643	.1006	.1092	.1444	.0639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 206 / 11KV GURUDHANORA 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2829	.3772	.3429	.3772	.4572	.1886
2	.2829	.2829	.3772	.3429	.3772	.4572	.1886
3	.3395	.2829	.3772	.3601	.415	.4572	.1886
4	.415	.3772	.415	.3772	.4715	.5068	.2829
5	.415	.4715	.4715	.3944	.4715	.543	.3772
6	.4715	.5281	.5281	.3944	.5658	.5792	.5281
7	.4715	.547	.5658	.4115	.5658	.5487	.5281
8	.415	.4338	.5658	.5144	.5658	.543	.3772
9	.3772	.1509	.3772	.0943	.2263	.1886	.2829
10	.3395	.1509	.3429	.1132	.1886	.1886	.3206
11	.2829	.1886	.3086	.132	.1886	.1509	.2801
12	.1886	.1886	.2743		.1886	.1509	.1867
13	.1886	.2263	.2743		.1886	.1509	.1867
14	.1509	.2263	.2229	.1509	.1886	.1509	.1867
15	.1509	.2263	.2058	.1509		.1509	.1867
16	.1509	.2263	.2058		.1886	.1509	.2218
17	.1886	.2829		.1886	.2263	.1886	.2286
18	.2263	.3772	.3772	.2829	.3395	.2829	.2401
19	.2829	.3772	.4115	.3772	.2829	.2829	.2572
20	.2829	.2829	.4115	.3395	.2263	.2829	.2743
21	.2263	.2263	.5144		.1886	.2263	.2743
22	.2263	.2263	.5144	.2829	.1886	.1886	.2572
23	.1886	.2263	.4458	.2263	.1886	.1886	.2572
24	.1886	.1886	.1886	.3772	.1886	.1886	.1886
Max	.4715	.547	.5658	.5144	.5658	.5792	.5281
Min	.1509	.1509	.1886	.0943	.1886	.1509	.1867
Avg	.2782	.2908	.3806	.2927	.3042	.3002	.2704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044021 / 33/11 KV SHENDURWADA

Feeder No / Name : 207 / 11 KV DHAMORI (BK) SINGLE PHASING

1PHASING Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.3772	.3772	.381	.4715	.4525	.1132
2	.2829	.3772	.4715	.4191	.4715	.4525	.1132
3	.3395	.4715	.5658	.4287	.5658	.543	.1132
4	.3772	.5658	.6602	.4801	.6602	.6335	.1509
5	.4715	.6602	.6602	.5144	.6602	.7164	.1886
6	.5658	.6602	.6602	.583	.6979	.7522	.1886
7	.5658	.6602	.6602	.6173	.6979	.7964	.1886
8	.5658		.679	.6516	.6979	.8059	.1509
9	.0754	.0943	.1143	.0943	.0943	.1886	.543
10	.0754	.0943	.0953	.0943	.0943	.1698	.6697
11	.0754		.0762	.0943	.0943	.1132	.6335
12	.0943	.0943	.0762		.0943	.0943	.6335
13	.0943	.0943	.0762		.0943	.0943	.6335
14	.0943	.0943	.0762		.0943	.1132	.5792
15	.0754	.0943	.0762			.1132	.5792
16	.0754	.0943	.0686	.0943	.0943	.1132	.6878
17	.0943	.1132	.0762	.1132	.0943	.1132	.0953
18	.1132	.1509	.1143	.1132	.1132	.1509	.0857
19	.1509	.1509	.1334	.132	.1509	.1886	.1029
20	.1132	.1132	.1524	.132	.1509	.1886	.1029
21	.0943	.1132	.1334		.1509	.1886	.1029
22	.0943	.0943	.1029	.1132	.1509	.1509	.1029
23	.1132	.0943	.1029	.0943	.1509	.1509	.0857
24	.0943	.0943	.0943	.0953	.0943	.1509	.1132
Max	.5658	.6602	.679	.6516	.6979	.8059	.6878
Min	.0754	.0943	.0686	.0943	.0943	.0943	.0857
Avg	.2075	.2435	.2626	.2761	.2887	.3098	.2899



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 201 / 11 KV SAWANGI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	1.2136	.9335	.8215		1.1203	
2	.924	1.307	1.0269	.8131		1.4003	
3	1.1088	1.4003	1.1203	.8413		1.5497	
4	1.2936	1.4937	1.307	.8413		1.7737	
5	1.4784	1.587	1.587	.9145		2.0538	
6	1.2936	1.6804	1.7737	.8916		2.2405	
7	1.4784	1.6617	2.2779	1.2548		2.4272	
8	1.4784	1.7737	2.5206	1.704		2.5579	
9	1.4784	1.8298	1.9791	1.8679		2.6513	
10	.7282	.8402	.679		.8402	.9335	1.4937
11	.7842	.9335	.5716		.9335	.9335	1.9044
12	.8029	1.0269	.5335		.7468	.9335	1.7551
13	.8402	1.0456	.8764		.8402	.9335	1.6804
14	.9335	1.0829	.9145		.9149	.7468	1.7177
15	1.0269	1.0269	.8764		1.0642	.7468	1.8298
16	1.0642	1.0082	.9526		1.0082	.7468	1.9231
17	.9335	.9709	1.086		1.0456	.8402	2.2779
18	1.0269	1.1016	1.3336		1.0829	.9335	.8402
19	1.0642	1.1763	1.7147		1.1576	1.1203	.8402
20	1.1203	1.2136	1.829		1.2136	1.1203	1.0456
21	1.0269	1.1203	1.7147		1.307	1.2136	.9335
22	.9896	1.0082	1.1431		.8962	1.307	1.0082
23	.9335	.8402	1.1431		.9335	1.1203	1.0269
24	.9335	1.1203	.7842			.9335	1.1203
Max	1.4784	1.8298	2.5206	1.8679	1.307	2.6513	2.2779
Min	.7282	.8402	.5335	.8131	.7468	.7468	.8402
Avg	1.0694	1.2276	1.2783	1.1056	.9989	1.3474	1.4265

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 202 / TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	.7468	.8029	.7468		.7468	
2	.924	.8402	.8775	.7468		.8402	
3	.924	.9335	.9335	.8131		.8775	
4	.9979	1.0269	.9709	.8501		.9896	
5	1.0349	1.0642	1.0269	.9145		1.0456	
6	1.0719	1.1203	1.0642	1.0242		1.1203	
7	1.0719	1.1949	1.1203	1.1706		1.1949	
8	1.0349	1.1203	1.0456	.9671		1.1203	
9	.924	.9709	.7468	.905		.8402	
10		.6722	.9145		.9896	.9335	
11	.7842	.6908	.8779		.9335	.9335	.8589
12	.8402	.6348	.8413		.8962	.8589	.8589
13	.8962	.7468	.8048		.8962	.7842	.8215
14	.8215	1.4564	.7682		.8215	.7655	.8589
15	.7468	.7842	.7316		.8589	.7468	.7842
16	.7842	.8215	.7682		.8962	.7468	.8962
17	.8215	.8589	.8048		.9522	.8402	.9149
18	1.0082	1.0082	.9145		1.0082	.9335	.8215
19	1.0829	1.2323	1.2071		1.1203	1.0456	.8589
20	1.0456	1.0829	1.1203		1.1949	1.1203	1.0829
21	1.0082	1.0082	1.0456		1.0082	.9335	1.0269
22	.9709	.8402	.9335		.8962	.8402	.9709
23	.8402	.7842	.7468		.7842	.7468	.8402
24	.9335	.8402	.7468	.7468		.7468	.7468
Max	1.0829	1.4564	1.2071	1.1706	1.1949	1.1949	1.0829
Min	.7468	.6348	.7316	.7468	.7842	.7468	.7468
Avg	.9344	.9367	.9089	.8885	.9469	.9063	.8815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 203 / 11 KV RAIPUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4668	.4668	.3734		.4668	
2	.3696	.5041	.5041	.3734		.4108	
3	.3696	.5601	.5415	.3696		.4481	
4	.462	.5975	.5601	.3658		.5415	
5	.462	.6348	.5975	.4024		.6161	
6	.462	.5601	.5788	.4344		.6722	
7	.5544	.5975	.5975	.5144		.7468	
8	.5544	.6348	.7095	.5898		.8589	
9	.7023	.6722	.6348	.6478		.7842	
10	.2987	.2241	.2286		.2987	.1494	.5041
11	.168	.1867			.2241	.1494	.5228
12	.1867	.1494			.1867	.1867	.5228
13	.1494	.168	.1905		.181	.1867	.5041
14	.1494	.1867	.1905		.1867	.1867	.4481
15	.1494	.168	.1905		.2241	.1867	.4668
16	.168	.2241	.1905		.2241	.2241	.5415
17	.2614	.2241	.1905		.208	.2241	.3734
18	.3174	.2987	.2286		.2534	.4481	.3361
19	.5601	.5601	.5335		.4108	.5601	.5228
20	.5975	.6348	.6478		.6535	.5601	.4854
21	.6348	.5601	.5716		.5975	.5601	.5041
22	.5601	.4854	.4954		.5228	.4854	.5601
23	.4668	.4668	.4572		.4481	.4854	.5041
24	.5544	.5975	.5601	.3734		.5601	.4668
Max	.7023	.6722	.7095	.6478	.6535	.8589	.5601
Min	.1494	.1494	.1905	.3658	.181	.1494	.3361
Avg	.397	.4318	.4485	.4444	.3300	.4458	.4842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 204 / 11 KV MALIWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.6535	.5601	.9431		.4481	
2	.7392	.7468	.6535	.9526		.5228	
3	.924	.8402	.7468	1.2574		.5975	
4	1.2936	.9335	.9335	1.3336		.6722	
5	1.4784	1.0456	1.0269	1.4098		.7842	
6	1.5154	1.2883	1.2136	1.6004		1.0829	
7	1.4784	1.419	1.307	1.3957		1.3817	
8	1.1088	1.0082	1.0829	1.0562		1.1203	
9	.924	.8215	.8215	.8764		.8962	
10	.4854	.5228	.5243		.6348	.9335	
11	.4108	.4108	.4588		.5975	.9335	.3361
12	.4481	.4108	.3605		.4854	.6348	
13	.4108	.3734	.3932		.4854	.4668	.3361
14	.4854	.4481	.3277		.4854	.4668	.2987
15	.4481	.4108	.3605		.4854	.4481	.2987
16	.5228	.4294	.3932		.4481	.5228	.3734
17	.4481	.4108	.426		.5601	.3734	.4481
18	.5788	.5228	.4572		.5228	.5228	.5975
19	.9335	1.0829	.8764		.9522	.9335	.6161
20	1.1203	1.0082	1.0288		1.2323	.9335	.7468
21	1.0269	.8962	.9907		.9709	.7842	.9335
22	.9335	.7468	.8764		.8589	.7655	.8215
23	.7468	.6535	.6859		.6722	.7468	.6722
24	.7468	.6535	.4668	.6478		.4668	.7468
Max	1.5154	1.419	1.307	1.6004	1.2323	1.3817	.9335
Min	.4108	.3734	.3277	.6478	.4481	.3734	.2987
Avg	.8311	.7391	.7072	1.1473	.6708	.7266	.5558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044022 / 33/11 KV LASUR STATION

Feeder No / Name : 206 / 11 kv GINNING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.037	.0747	.0747	.0572		.0747	
2	.037	.0747	.0747	.0572		.0747	
3	.037	.0747	.0747	.0572		.0747	
4	.037	.0747	.0747	.0572		.0747	
5	.0554	.0747	.0747	.0572		.0747	
6	.0554	.0747	.0747	.0572		.0747	
7	.0554	.0747	.0747	.0572		.0747	
8	.0554	.0747	.0747	.0572		.0747	
9	.0554	.0747	.0747	.0762		.0747	
10	.0747	.0747	.0572		.0747	.0747	.0747
11	.056	.0747	.0572		.0747	.056	.0747
12	.056	.056	.0572		.0747	.056	.0747
13	.056	.0747	.0572		.056	.056	.0747
14	.0747	.0747	.0572		.056	.056	.0747
15	.0747	.0747	.0572		.056	.056	.0747
16	.0747	.0747	.0572		.056	.056	.0747
17	.0747	.056	.0572		.056	.056	.0747
18	.0747	.0747	.0572		.056	.056	.0747
19	.0747	.0747	.0572		.056	.056	.0747
20	.0747	.0747	.0572		.056	.0747	.0747
21	.0747	.0747	.0572		.0747	.056	.056
22	.0747	.0747	.0572		.0747	.0747	.056
23	.0747	.0747	.0572		.0747	.056	.056
24	.056	.0747	.0747	.0572		.0747	.056
Max	.0747	.0747	.0747	.0762	.0747	.0747	.0747
Min	.037	.056	.0572	.0572	.056	.056	.056
Avg	.0613	.0731	.0645	.0591	.0640	.0661	.0697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 201 / 11 KV SILLEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0476	.0476	.0476	.0953	.0953	.0953	.3734
2	.0476	.0476	.0476	.0953	.0953	.0953	.3734
3	.0476	.0476	.0476	.0953	.0953	.0953	.3734
4	.0476	.0476	.0476	.0953	.0953	.0953	.4572
5	.0953	.0476	.0476	.0953	.0953	.0953	.5487
6	.0953	.0953	.0953	.0953	.0953	.0953	.6401
7	.0953	.0953	.0953	.0953	.0953	.0953	.7164
8	.0476	.0476	.0476	.0476	.0476	.0476	.4477
9	.0476	.0476	.0476	.0476	.0476	.0476	.985
10	.7316	.543	.724	.7316	.905	.823	.0476
11	.7087	.6335	.7164	.6268	.985	.8954	.0476
12	.7087	.7087	.7164	.7011	1.0745	.8954	.0476
13	.6201	.7011	.6268	.7802	.985	.8954	.0476
14	.7164	.6001	.6268	.7802	.985	.8954	.0476
15	.6201	.6859	.6268	.7716	.8954	.8954	.0476
16	.6201	.6783	.7164	.8478	.8954	.8059	.0476
17	.0476	.7888	.7164	.8764	.8954	.8059	.0476
18	.0476	.0476	.0476	.0476	.0476	.0476	.0476
19	.0476	.0476	.0476	.0476	.0476	.0476	.0476
20	.0476	.0476	.0476	.0953	.0953	.0476	.0476
21	.0953	.0953	.0953	.0953	.0953	.0476	.0476
22	.0476	.0953	.0476	.0953	.0953	.0476	.0476
23	.0476	.0953	.0953	.0953	.0953	.0476	.0476
24	.0476	.0476	.0476	.0953	.0953	.0953	.3734
Max	.7316	.7888	.724	.8764	1.0745	.8954	.985
Min	.0476	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.2386	.2641	.2676	.3104	.3731	.3356	.2481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 202 / 11KV MALUNJA (BK) AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.2372	.362	.4668	.362	.3734	.0953
2	.3734	.2343	.362	.4572	.362	.3658	.0953
3	.3658	.3048	.4477	.4572	.443	.3658	.0953
4	.3658	.381	.5316	.6268	.443	.4572	.0953
5	.4477	.4572	.5258	.5373	.5258	.5373	.0953
6	.5373	.4744	.6859	.6135	.6935	.7164	.1429
7	.7011	.5401	.763	.7888	.7716	.7888	.1429
8	.7888	.5316	.8383	.8573	.8478	.964	.1429
9	.7888	.5258	.763	.8764	.8669	.964	.0953
10	.0953	.0476	.0476	.0476	.0953	.0476	.7164
11	.0476	.0476	.0476	.0476	.0476	.0476	7.1759
12	.0476	.0476	.0476	.0476	.0476	.0476	.6201
13	.0476	.0476	.0476	.0476	.0476	.0476	.543
14	.0476	.0476	.0476	.0476	.0476		.4525
15	.0476	.0476	.0476	.0476	.0476		.3658
16	.0476	.0476	.0476	.0476	.0476	.0476	.2686
17	.0953	.0476	.0476	.0476	.0476	.0476	.1772
18	.1905	.0476	.0476	.0953	.0476	.0953	.0953
19	.0476	.1429	.0476	.0953	.0953	.0953	.0953
20	.0476	.1429	.0953	.0953	.0953	.0953	.0476
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0953	.0953	.0953	.0476	.0953	.0953	.0953
24	.3734	.2372	.362	.4668	.362	.3734	.0953
Max	.7888	.5401	.8383	.8764	.8669	.964	7.1759
Min	.0476	.0476	.0476	.0476	.0476	.0476	.0476
Avg	.2568	.2052	.2708	.2939	.2763	.3074	.4975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 203 / 11 KV GAJGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.1296
2	.0953	.0953	.0953	.0953	.0953	.0953	.1296
3	.0953	.0953	.0953	.0953	.0953	.0953	.1334
4	.0953	.0953	.0953	.0953	.0953	.0953	.2
5	.0953	.1905	.0953	.1905	.0953	.1905	.2058
6	.1905	.1905	.1905	.1905	.1905	.1905	.2896
7	.1905	.1905	.1905	.1905	.1905	.1905	.2972
8	.0953	.0953	.0953	.0953	.0953	.1905	.2896
9	.0953	.0953	.0953	.0953	.0953	.0953	.2896
10	.1943	.2372	.2743	.2896	.3715	.362	.0953
11	.3163	.2934	.2896	.2934	.3906	.381	.0953
12	.3163	.2972	.3906	.3668	.3906	.381	.0953
13	.2372	.2972	.3125	.3715	.3906	.3906	.0953
14	.2401	.3048	.3125	.3048	.3906	.381	.0953
15	.3163	.3086	.3125	.3125	.3125	.2972	.0953
16	.3125	.3125	.3125	.3201	.3125	.2172	.0953
17	.0476	.381	.3125	.2343	.3048	.2172	.0953
18	.0953	.0953	.0953	.0953	.0953	.0953	.0953
19	.0953	.0953	.0953	.0953	.0953	.0953	.0953
20	.0953	.0953	.0953	.0953	.1905	.0953	.0953
21	.0953	.0953	.0953	.0953	.0953	.0953	.0953
22	.0953	.0953	.0953	.0953	.0953	.0953	.0953
23	.0476	.0953	.0953	.0953	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.1296
Max	.3163	.381	.3906	.3715	.3906	.3906	.2972
Min	.0476	.0953	.0953	.0953	.0953	.0953	.0953
Avg	.1520	.1768	.1763	.1793	.1948	.1889	.1428



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 204 / 11 KV KATEPIMPALGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.282	.2343	.2667	.362	.3715		.1905
2	.282	.2286	.2667	.362	.3715		.1905
3	.2896	.3125	.3429	.362	.4515		.1905
4	.3715	.3163	.3429	.4458	.4572		.1905
5	.4572	.3953	.4287	.5335	.6097		.1905
6	.5335	.5535	.5135	.5468	.7716		.2858
7	.6249	.6859	.6097	.6249	.8592		.2858
8	.703	.7811	.7621	.8192	.9602		.1905
9		.7907	.6249	.8192	.7811	.8592	.1905
10		.1905	.0953	.1905	.0953	.1905	.5792
11		.0953	.0953	.0953	.0953	.0953	.7116
12		.0953	.0953	.0953	.0953	.0953	.7202
13	.0953	.0476	.0953	.0953	.0953	.0953	.7202
14	.0953	.0953	.0953	.0953	.0953	.0953	.6325
15	.0953	.0953	.0953	.0953	.0953	.0953	.6249
16	.0953	.0953	.0953	.0953	.0953	.0953	.6249
17	.0953	.0476	.0953	.0953	.0953	.0953	.4744
18	.1905	.1905	.1905	.1905	.0953	.1905	.1905
19	.1905	.2858	.1905	.1905		.1905	.1905
20	.1905	.2858	.1905	.1905		.2858	.1905
21	.1905	.1905	.1905	.0953		.2858	.1905
22	.0953	.1905	.1905	.1905		.2858	.1905
23	.1905	.1905	.1905	.1905		.1905	.1905
24	.2743	.2372	.2667	.3525	.3668		.1905
Max	.703	.7907	.7621	.8192	.9602	.8592	.7202
Min	.0953	.0476	.0953	.0953	.0953	.0953	.1905
Avg	.2671	.2763	.2638	.2972	.3609	.2097	.3469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 206 / 11 KV Shahapur AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0953	.0953	.0953	.0953	.0953	.2801
2	.0953	.0953	.0953	.0953	.0953	.0953	.2801
3	.0953	.0953	.0953	.0953	.0953	.0953	.2743
4	.0953	.0953	.0953	.0953	.0953	.0953	.3658
5	.0953	.0953	.0953	.0953	.0953	.0953	.3582
6	.2858	.1429	.1429	.0953	.1429	.1429	.4477
7	.1429	.1429	.1429	.0953	.1429	.1429	.5258
8	.1429	.0953	.0953	.0953	.1429	.1429	.5373
9	.0953	.0953	.0953	.0476	.0953	.0953	.5258
10	.4572	.443	.543	.4572	.4525	.5487	.0953
11	.3544	.3582	.5373	.443	.5373	.5258	.0476
12	.3544	.443	.4477	.443	.5258	.5258	.0476
13	.3544	.4382	.3582	.4382	.4382	.5258	.0476
14	.3582	.3467	.3582	.4334	.4382	.4477	.0476
15	.362	.3429	.3582	.4287	.4382	.4477	.0476
16	.3544	.3353	.3582	.4239	.4382	.2743	.0476
17	.0476	.3506	.4477	.4382	.5144	.2686	.0476
18	.0476	.0476	.0953	.0953	.0476	.0953	.0476
19	.1429	.1429	.1429	.1429	.0953	.0953	.0476
20	.0953	.1429	.1429	.1429	.0953	.0953	.0953
21	.0953	.0953	.0953	.1429	.0953	.0953	.0953
22	.0476	.0953	.0953	.1429	.0953	.0953	.0953
23	.0476	.0953	.0953	.1429	.0953	.0953	.0953
24	.0953	.0953	.0953	.0953	.0953	.0953	.2801
Max	.4572	.443	.543	.4572	.5373	.5487	.5373
Min	.0476	.0476	.0953	.0476	.0476	.0953	.0476
Avg	.1816	.1969	.2135	.2175	.2251	.218	.1992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044025 / 33/11 KV SIDHANATH WADGAON

Feeder No / Name : 207 / 11 KV Wadali AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.1562	.1848	.2801	.2772	.2801	.0476
2	.2801	.1543	.1848	.2801	.2772	.2801	.0476
3	.2801	.1581	.1848	.3658	.2715	.3658	.0476
4	.3658	.2286	.2715	.4572	.362	.3658	.0476
5	.4477	.3163	.3582	.5373	.362	.3658	.0953
6	.4382	.3953	.4382	.5373	.443	.4477	.0953
7	.5258	.4744	.5144	.5258	.5258	.5373	.0953
8	.4382	.5316	.5935	.6001	.6001	.6135	.0953
9	.5258	.543	.5201	.6135	.6135	.7011	.0476
10	.0476	.0476	.0476	.0476	.0476	.0476	.3658
11	.0476	.0476	.0476	.0476	.0476	.0476	.3658
12	.0476	.0476	.0476	.0476	.0476	.0476	.362
13	.0476	.0476	.0476	.0476	.0476	.0476	.362
14	.0476	.0476	.0476	.0476	.0476	.0476	.362
15	.0476	.0476	.0476	.0476	.0476	.0476	.2743
16	.0476	.0476	.0476	.0476	.0476	.0476	.2801
17	.0476	.0476	.0476	.0476	.0476	.0476	.1772
18	.0476	.0476	.0476	.0476	.0476	.0476	.0476
19	.0953	.0476	.0476	.0953	.0476	.0476	.0476
20	.0476	.0476	.0476	.0953	.0476	.0476	.0476
21	.0476	.0476	.0476	.0953	.0476	.0476	.0191
22	.0476	.0476	.0476	.0953	.0476	.0476	.0476
23	.0476	.0476	.0476	.0476	.0476	.0476	.0476
24	.2801	.1581	.1848	.2801	.2772	.2801	.0476
Max	.5258	.543	.5935	.6135	.6135	.7011	.3658
Min	.0476	.0476	.0476	.0476	.0476	.0476	.0191
Avg	.1907	.1576	.1709	.2223	.1948	.2043	.1447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 201 / 11KV JAMGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.6535	.7468	.7468	.7095	.7842	1.2517
2	.7316	.6535	.7468	.7468	.7468	.7842	1.286
3	.823	.7468	.8775	.8402	.7842	.8402	1.3717
4	.823	.7842	.9522	.8779	.8215	.9522	1.5089
5	.8779	.8402	1.0082	.9896	.8962	1.0082	1.7147
6	1.0059	1.0269	1.0269	1.0456	.9896	1.1016	
7	1.0608	1.1016	1.1016	1.1389	1.0269	1.0082	
8	.9511	1.0456	.9709	1.0791	1.1389	1.0269	
9	.9145	.8962	.9808	.9877	1.0269	1.0269	
10	.7316	.7468	.9431	.7316	1.0374	1.2323	.6516
11	.7095	.6908	.6036	.8215	.7545	.7842	.6859
12	.5601	.6348	.5658	.7468		.6722	.583
13	.5601	.6908	.5658	.7095		.6722	.5144
14	.6722	.6908	.5847	.5853		.6908	.4973
15	.7468	.7468	.6602	.6722	.7167	.8215	.583
16	.7468	.7468	.7545	.8589	.9054	.9709	.583
17	1.1016	.9149	.7922	1.0456	1.094	1.363	.6173
18	1.4937	1.1203	1.2071	1.3817	1.2174		1.2346
19	1.6617	1.4937	1.8673		1.8004	1.8671	1.6787
20	1.6804	1.6617	1.6975	1.8671	1.749	1.7541	1.7918
21	1.4563	1.4003	1.4712	1.531	1.5089	1.6975	1.5278
22	1.4003	1.307	1.3392	1.2136	1.286	1.5466	1.5089
23	1.1203	1.1576	1.1883	1.0082	1.307	1.5089	1.4146
24	.7468	1.1203	.7468	.5658	.7095	.7468	1.3392
Max	1.6804	1.6617	1.8673	1.8671	1.8004	1.8671	1.7918
Min	.5601	.6348	.5658	.5658	.7095	.6722	.4973
Avg	.9718	.9530	.9750	.9648	1.0584	1.0809	1.1172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 202 / 11KV L.I.S. FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.0934	.1886	.1886	.2241	.1886	.1715
2	.1372	.0934	.1886	.1886	.2614	.1886	.1715
3	.1372	.112	.1886	.1886	.2801	.1886	.1715
4	.1543	.112	.2263	.1886	.3174	.2263	.1886
5	.1543	.1867	.2263	.1886	.3361	.2829	.1886
6	.2915	.2229	.2263	.2452	.3547	.2829	.2229
7	.2915	.3086	.3206	.3206	.4481	.3772	
8	.3086	.2743	.3361	.3018	.4481	.5658	
9	.3086	.2572	.3395	.3961	.3734	.5093	
10	.0686	.0686	.0566	.132	.1698	.168	.5144
11	.0686	.0686	.0686	.1307	.112	.0187	.5316
12	.0514	.0686	.0686	.0747	.1509	.0187	.6001
13	.0514	.0686	.0686	.0747	.1494	.0187	.6001
14	.056	.0747	.0686	.056	.132	.0187	.5487
15	.056	.0747	.0686	.112	.132	.0187	.583
16	.056	.0747	.0686	.1307	.1267	.0187	.5658
17	.1307	.112	.0686	.1494	.1267	.0187	.5487
18	.112	.112	.1029	.1494	.1543	.1494	.1029
19	.112	.112	.1372	.168	.2058	.1494	.1698
20	.0934	.1494	.132	.1494	.1886	.1509	.1698
21	.0934	.112	.132	.1307	.1715	.1509	.1132
22	.0747	.112	.132	.1307	.1372	.132	.1132
23	.0747	.112	.1132	.1494	.1494	.132	.0943
24	.0189	.0747	.1886	.2075	.2241	.0754	.132
Max	.3086	.3086	.3395	.3961	.4481	.5658	.6001
Min	.0189	.0686	.0566	.056	.112	.0187	.0943
Avg	.1266	.1273	.1548	.173	.2239	.1687	.3096

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 203 / 11KV NEVARGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.5415	.6535	.4854	.4854	.5975	.463
2	.3921	.5415	.6535	.5228	.5228	.5975	.5144
3	.5041	.5601	.6722	.5601	.5601	.6348	.5144
4	.7095	.5975	.8402	.5601	.8402	.6722	.6001
5	.5601	.6535	.8962	.6535	1.0082	.7282	.6001
6	.6535	1.0456	.9896	.8962	1.1389	.8589	.6859
7	1.0269	1.1763	1.1016	1.0082	1.0829	.9896	.4801
8	.9335	1.0456	.8402	.8589	1.0456	1.0082	.5144
9	.8402	.8215	.8488	.5601	.8215	.7468	.5487
10	.3361	.3734	.3206	.5975	.4344	.3921	.2229
11	.2801	.3734	.3086	.3174	.4706	.3734	.2229
12	.2801	.2614	.3086	.3361	.362	.3734	.2058
13	.2801	.2427	.3429	.3361	.3258	.3734	.2401
14		.2241	.2058	.3734	.2896	.3921	.2743
15		.2614	.2263	.2987	.2896	.3734	.2743
16		.2614	.2641		.3258	.3547	.3429
17	.2801	.3361	.4527		.3258	.4108	.3429
18	.6535	.3734	.6036		.4115	.6908	.4115
19	.8402	.7468	.8865		.7888	.8029	.7167
20	.7468	.8029	.7545	.8962	.7716	.679	.8488
21	.7095	.7842	.6413	.7095	.6859	.6036	.6602
22	.5975	.6908	.5658	.6348	.6516	.5847	.6602
23	.5601	.6535	.4527	.5415	.5975	.547	.5658
24	.3734	.5041	.6348	.4904	.4668	.5658	.5281
Max	1.0269	1.1763	1.1016	1.0082	1.1389	1.0082	.8488
Min	.2801	.2241	.2058	.2987	.2896	.3547	.2058
Avg	.5690	.5780	.6027	.5818	.6126	.5980	.4766

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 204 / 11KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0187	.0187	.0189	.0189	.0171
2	.0189	.0189	.0187	.0187	.0189	.0373	.0171
3	.0189	.0189	.0187	.0187	.0189	.0373	.0171
4	.0189	.0189	.0187	.0189	.0189	.0189	.0171
5	.0189	.0189	.0187	.0189	.0189	.0189	.0171
6	.0189	.0189	.0187	.0189	.0189	.0189	.0171
7	.0377	.0189	.0187	.0189	.0189	.0189	.0171
8	.0189	.0189	.0187	.0189	.0189	.0189	.0171
9	.0189	.0189	.0189	.0377	.0377	.0189	.0171
10	.0189	.0377	.0191	.0754	.0566	.0189	.0343
11	.0189	.0189	.0191	.0377	.0566	.0189	.0343
12	.0189	.0189	.0572	.0566	.0566	.0189	.0343
13	.0189	.0187	.0572	.0566	.0566	.0189	.0343
14	.0189	.0189	.0572	.0566	.0754	.0189	.0343
15	.0189	.0189	.0572	.1132	.0566	.0189	.0343
16	.0189	.0189	.0572	.0754	.0566	.0189	.0343
17	.0189	.0377	.0572	.0566	.0566	.0189	.0343
18	.1698	.0189	.0572	.0566	.0514	.0187	.0343
19	.0187	.0189	.0566	.0566	.0514	.0373	.0191
20	.0189	.0189	.0189	.0566	.0566	.0191	.0191
21	.0189	.0189	.0189	.0189	.0189	.0191	.0191
22	.0189	.0189	.0189	.0189	.0189	.0191	.0191
23	.0189	.0189	.0191	.0189	.0377	.0191	.0191
24	.0189	.0189	.0189	.0191	.0189	.0377	.0191
Max	.1698	.0377	.0572	.1132	.0754	.0377	.0343
Min	.0187	.0187	.0187	.0187	.0189	.0187	.0171
Avg	.0260	.0205	.0316	.0401	.0381	.0220	.0241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 205 / 11kv KANADGAON 1PHASING SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3429	.2263	.3395	.3361	.3772	.3429
2	.3601	.3429	.2263	.3395	.3734	.3772	.3429
3	.4115	.3772	.2263	.3395	.4481	.3961	.3601
4	.463	.3772	.3395	.3772	.5041	.3961	.3601
5	.5144	.4115	.3772	.3961	.6348	.4338	.3601
6	.6344	.5487	.5093	.4338	.7282	.547	.4115
7	.4973	.4973	.5847	.547	.6722	.7167	.463
8	.4115	.4287	.4481	.6036	.5975	.5093	.5144
9	.3601	.3772	.4527	.3395		.2452	
10	.2401	.2058	.2829		.3258	.2987	
11	.2401	.2058	.2401		.3801	.3361	
12	.2915	.2058	.2058	.2241	.5068	.4294	
13	.2743	.2401	.2058	.2241	.3982	.4108	.1029
14	.2801	.3174	.2229		.4344	.4108	.12
15	.2801	.3174	.2401		.4344	.3361	.1372
16	.2801	.3174	.2401	.2241	.4344	.4108	.2058
17	.2987	.3174	.2401	.2801	.4344		.2401
18	.5601		.3086	.2427	.2572	.5041	.3601
19	.6535	.2614	.463	.4481	.3258	.5601	.547
20	.7095	.2241	.3772	.5228	.4287	.547	.5281
21	.4481	.1867	.3772	.4854	.3772	.4527	.3772
22	.3921	.1867	.3206	.4668	.3258	.3772	.3395
23	.3361	.1494	.2263	.3734	.3361	.3772	.3395
24	.3361	.3361	.132	.2829	.3361	.3772	.2263
Max	.7095	.5487	.5847	.6036	.7282	.7167	.547
Min	.2401	.1494	.132	.2241	.2572	.2452	.1029
Avg	.4014	.3120	.3114	.3745	.4361	.4273	.3339



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 206 / 11 KV NEW LIS SHANTAI PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171			
2		.0171			
3		.0171	.0191		
4		.0171	.0191		
5		.0171			
6		.0686			
7		.0343	.0381		
8	.0686	.0686	.0191		
9	.0686	.0686			
10		.0171	.0686	.1629	.1543
11					.1543
12					.1543
13					.1715
14					.1715
23		.0189			
24			.0189		
Max	.0686	.0686	.0686	.1629	.1715
Min	.0686	.0171	.0189	.1629	.1543
Avg	.0686	.0329	.0305	.1629	.1612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044036 / 33/11KV JAMGAON

Feeder No / Name : 207 / 11KV BAGADI Ag 1-PHASING SINGLE PHASING

FEEDE Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3921	.3395	.2829	.2614	.3772	.3086
2	.3429	.3921	.3395	.2829	.2801	.3772	.3086
3	.3429	.4481	.3361	.3206	.3174	.415	.3429
4	.3772	.5041	.3772	.3395	.4294	.415	.3429
5	.3772	.5601	.4481	.4338	.5228	.547	.3772
6	.583	.5601	.5041	.5093	.6161	.6224	.4115
7	.463	.7095	.5415	.4338	.6161	.5658	.3429
8	.4115	.6535	.5415	.5658	.4854	.547	.3429
9	.3944	.5041	.547	.4338		.4527	.2572
10	.1715	.2241	.2263		.3077	.2241	.1029
11	.1715	.1867	.4115	.1494	.2896	.2801	.0343
12	.2572	.1867	.2401	.2987	.2896	.3547	.0686
13	.2401	.1494	.2401	.3174	.2353	.3361	.0514
14	.112	.1867	.2401	.3361	.2896	.3361	.0514
15	.1867	.2241	.2401	.2987	.2896	.3734	.0686
16	.1867	.2614	.2401	.2987	.3258		.1029
17	.2427	.2614	.2401	.2801	.362		.12
18	.3174	.3734	.2572	.3361	.2915		.3601
19	.5041	.4108	.2915	.4854	.463	.415	.4527
20	.5601	.4294	.3206	.4481	.463	.3772	.4527
21	.4481	.3734	.3206	.3734	.4115	.3395	.3772
22	.3921	.3734	.3206	.3361	.3601	.3395	.3772
23	.3361	.3361	.3206	.2987	.3734	.3395	.3395
24	.3772	.3361	.3361	.2829	.2614	.3734	.3395
Max	.583	.7095	.547	.5658	.6161	.6224	.4527
Min	.112	.1494	.2263	.1494	.2353	.2241	.0343
Avg	.3391	.3765	.3425	.3540	.3714	.4004	.2639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 201 / 11 KV BHENDALA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0762		.0572	.0953	.2858
2		.0762	.0762	.0953	.0572	.0762	.2858
3		.0762	.0762	.0953	.0762	.0762	.2858
4							.2858
5							.2858
6							.2858
7							.2858
8							.1905
9							.1905
10		.1143		.2477	.1905	.2858	
11	.0762	.1524	.1143	.1905	.1905	.3048	
12	.0762	.1524	.1524	.2286	.2096	.2858	
13	.0381	.1524	.1524	.1905	.1905	.2858	
14	.0762	.1524	.1524	.1905	.2096	.2858	
15	.0381	.1143	.2096	.1905	.2096	.2858	
16	.0762	.1143	.2096	.1905	.2286	.2858	.0762
17	.0381	.1143	.2096	.1905	.2477		.0381
18	.0762	.0762	.0953	.0762	.0762	.0953	.0762
19	.0762	.0762	.0953	.0762	.0953	.0953	.0762
20	.0762	.0381	.0953	.0762	.0953	.0953	.0762
21	.0762	.0381	.0953	.0762	.0762	.0953	.0762
22	.0762	.0381	.0953	.0381	.0762	.0953	.0762
23	.0762		.0953	.0381	.0953	.0953	.0381
24		.0762	.0381	.1143	.0381	.0762	.2858
Max	.0762	.1524	.2096	.2477	.2477	.3048	.2858
Min	.0381	.0381	.0381	.0381	.0381	.0762	.0381
Avg	.0674	.0964	.1199	.1356	.1344	.1715	.1778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 202 / 11 DHOREGAON FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905			.1905	.381
2	.1905	.2286	.1905			.2096	.381
3	.1905	.2286	.2667			.2096	.4572
4	.2286	.2286	.2667			.1905	.4572
5		.2286					.5335
6	.5716	.2286					.5335
7	.5335	.4763	.5335			.5335	.5335
8	.4954	.381	.3429			.5335	.5335
9	.3048	.381	.3048			.381	
10	.381	.381	.3048			.381	
11	.3048	.3048	.3048			.3048	
12	.3048	.2858	.3048		.2667	.3048	
13	.3048	.2286	.3048		.381	.4572	
14	.3048	.2286	.3048		.3048	.4572	
15							.3429
16							.381
17							.381
18		5.9061					.4572
19	.1905	.3048	.2667		.381	.381	.4954
20	.2286		.2667		.381	.4572	.4954
21	.2286	.3429	.4763		.3048	.4572	.5335
22	.2286	.3429	.4763		.3048	.1905	.5335
23	.2286	.2286	.4763		.3048	.381	.2286
24	.2286	.2286	.2286	.381		.3048	.381
Max	.5716	5.9061	.5335	.381	.381	.5335	.5335
Min	.1905	.1905	.1905	.381	.2667	.1905	.2286
Avg	.2968	.5677	.3228	.381	.3286	.3514	.4467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 203 / 11 KV AMALNER FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.1524	.2667	.2667	.3048	.1905
2	.2286	.2286	.2286	.2667	.2286	.3048	.1905
3	.2667	.2096	.2667	.2667	.2286	.2667	.1905
4	.2667	.2667	.2286	.381	.2667	.3048	.1905
5	.2667	.2667	.2286	.381	.2667	.3429	
6	.2667	.2667	.2667	.381	.2477	.3048	
7							.3048
8							.3048
9							.3048
10							.3048
11							.2286
12							.2286
13	.0762	.0762		.0762	.1143	.1143	.2286
14	.0762	.0762	.1143	.0762	.1143	.1143	.2286
15	.0762	.0762	.1143	.0762	.0762	.1524	
16	.0762	.0762	.1143	.0762	.0762	.1524	
17	.0762	.0762	.1143	.1143	.0762	.1524	
18	.0762	.0762	.1524	.1143	.0762	.1524	
19	.0762	.0762	.1524	.1524	.1524	.1905	.1524
20	.1524	.0762	.1524	.1524	.1715	.2286	.1524
21	.1524	.0762	.1524	.1524	.1524	.2286	.1524
22	.1524	.1905	.1524	.1524	.1524	.2286	.1524
23	.1905	.1905	.1905	.2286	.3048	.2286	.1143
24	.1905	.1905	.1905	.2667	.1905	.3048	.2286
Max	.2667	.2667	.2667	.381	.3048	.3429	.3048
Min	.0762	.0762	.1143	.0762	.0762	.1143	.1143
Avg	.1609	.1513	.1748	.1990	.1757	.2265	.2138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 204 / 11 KV GANESHWADI GAONTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.1905	.2858
2	.2667	.2667	.2286	.2858
3	.2667	.3048	.2096	.2858
4	.4763	.3048	.4001	.4763
5	.6859	.4191	.7621	.6097
6	.724	.724	.724	.7049
7	.6478	.8002	.6668	.6668
8	.5716	.7621	.743	.6668
9	.4763	.5716	.6668	.5716
10	.4382	.381	.4572	.4191
11	.3429	.3048	.3239	.3429
12	.2477	.2477	.2858	.2667
13	.2286	.2667	.2477	.2286
14	.1905	.2477	.2477	.1905
15	.1905	.2477	.381	.1905
16	.2667	.2858	.4191	.2667
17	.3048	.381	.4572	.3429
18	.4572	.4572	.5716	.5144
19	.6287	.6478	.6668	.6859
20	.6859	.4954	.743	.6097
21	.381	.381	.5716	.381
22	.3239	.3048	.2858	.3048
23	.3048	.2667	.2858	.3048
24	.2667	.2667	.2477	.2858
Max	.724	.8002	.7621	.7049
Min	.1905	.2477	.1905	.1905
Avg	.4017	.4001	.4493	.4120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 205 / 11kv Kokan agro

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2286	.3048	.3429	.3048	.381	.2858
2	.2096	.2667	.3429	.3429	.3429	.3429	.2858
3	.2096	.2667	.3048	.3429	.3429	.2286	.2858
4	.1905	.3048	.2667	.2286	.3048	.2667	.2858
5	.1905	.3048	.2667	.3048	.3048	.2858	.2858
6	.2286	.381	.2286	.2286	.381	.362	.2858
7	.2286	.362	.3239	.3429	.381	.3239	.4763
8	.2858	.4191	.381	.3429	.4191	.3239	.5716
9	.3048	.5906	.6668	.3429	.5335	.3239	.5906
10	.5335	.6859	.6859	.362	.743	.381	.6097
11	.5716	.8573	.724	.5716	.743	.4382	.5716
12	.6668	.7811		.743	.8002	.4191	.5525
13	.5716	.743		.6859	.7811	.4191	.6097
14	.5906	.7049		.6859	.8383	.4191	.6287
15	.5716	.6859		.5335	.7621	.381	.6097
16	.6097	.6478		.3429	.7049	.3429	.6478
17	.6287	.4954		.4572	.5716	.3429	.5906
18	.5335	.4001		.381	.4572	.2667	.362
19	.5144	.381		.3429	.4954	.2286	.3429
20	.5144	.381		.3429	.4572	.2286	.3239
21	.4954	.4001		.3239	.5525	.381	.3048
22	.3429	.3429		.4382	.5335	.381	.3048
23	.362	.3239		.381	.362	.4001	.3048
24	.1905	.381	.3239	.3429	.3429	.4382	.4001
Max	.6668	.8573	.724	.743	.8383	.4382	.6478
Min	.1905	.2286	.2286	.2286	.3048	.2286	.2858
Avg	.4057	.4723	.4017	.4064	.5192	.3461	.4382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 206 / 11 KV GALNEEMB AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.0953	.1905	.1905	.0953
2	.1334	.1334	.0953	.1905	.1715	.0953
3	.1143	.1524	.0953	.1905	.1905	.0953
4	.1334	.1524	.0953	.1905	.1905	
5	.1524	.1334	.1143	.2286	.2096	
6	.1143	.1524	.2096	.2286	.1905	
7	.1143	.1715	.2096	.2286	.1905	
8	.1143	.1524	.2096	.2667	.1905	
9	.1143	.1524	.2096	.2667	.1905	
10			.0762			.1524
11						.1524
12						.1524
13						.1524
14						.1524
15			.0762			.1524
16	.0381	.0381	.0762	.0381	.0762	.1524
17	.0381	.0381	.0762	.0572	.0762	.1143
18	.0381	.0381	.0762	.0572	.0953	.0762
19	.0762	.0381	.0381	.0572	.0953	.0762
20	.0572	.0381	.0762	.0381	.0953	.0762
21	.0572	.0381	.0762	.0572	.0953	.0762
22	.0572	.0381	.0381	.0572	.0953	.0762
23	.0572		.0762	.0572	.0953	.0381
24	.1143	.1143	.1143	.1143	.1715	.0953
Max	.1524	.1715	.2096	.2667	.2096	.1524
Min	.0381	.0381	.0381	.0381	.0762	.0381
Avg	.0910	.1009	.1067	.1397	.1450	.1101



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 207 / 11Kv Lakhmapur Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1905	.1524	.1524	.1524	.1143	.3429
2	.1524	.1905	.1524	.1524	.1524	.0762	.3429
3	.1524	.1905	.1524	.1905	.1905	.1143	.3429
4	.1905	.2286	.1905	.2667	.1905	.1524	.3429
5	.1905	.2286	.1905	.2667	.1905	.1905	.3429
6	.2286	.2286	.1905	.2667	.2286	.2286	
7	.2286	.2286	.2286	.1905	.2286	.2286	
8	.1905	.2286	.2286	.1905	.2286	.1905	
13	.1524		.2286				.0762
14	.1524		.2286	.2286			.0762
15	.1905	.1905	.2286	.2286	.3048	.3048	.0762
16	.2286	.1905	.2286	.2286	.3429	.3429	.0762
17	.3048	.2286	.2286	.2667	.381	.3429	.1524
18	.3048	.2286	.2286	.2667	.381	.3429	.0762
19	.3048	.2286	.3048	.2667	.4191	.381	.1524
20	.2667	.2667	.3048	.2667	.381	.381	.1905
21	.2667	.2667	.3048	.2286	.381	.3429	.1905
22	.2667	.1905	.2477	.2667	.381	.3429	.1905
23	.1905	.1905	.1905	.1905	.1524	.3429	.1524
24	.1905	.1905	.1905	.1524	.1524	.1143	.3429
Max	.3048	.2667	.3048	.2667	.4191	.381	.3429
Min	.1524	.1905	.1524	.1524	.1524	.0762	.0762
Avg	.2153	.2159	.2200	.2246	.2688	.2519	.2039

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 208 / 11 kv MAUJABAD AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1905	.2286	.1905	
8	.1905	.1905	.2286	
9	.2286	.1905	.2667	
10	.2286	.1524	.3239	
11	.1524	.1524	.2477	
12	.1524	.1715	.362	
13	.1905	.2286	.362	
14	.1905	.2286	.362	
15				.2286
16				.2286
17				.2286
18				.2286
19				.2286
20				.2286
21				.2286
22				.2286
Max	.2286	.2286	.362	.2286
Min	.1524	.1524	.1905	.2286
Avg	.1905	.1929	.2929	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044040 / 33/11 KV GANESHWADI

Feeder No / Name : 209 / 11 KV BHIVDHANORA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	30-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.724	.7621	.6668
2		.7621	.7621	.7811	.6668
3		.7621	.8002	.743	.743
4		1.1431	.8764	1.0098	1.1431
5		1.4289	1.105	1.4289	1.5623
6		1.829	1.6766	1.7718	1.6575
7		1.4289	1.8671	1.8671	1.5242
8		1.4289	1.7147	1.7147	1.2765
9		1.1431	1.5242	1.6194	1.1431
10		1.0288	1.0669	1.1431	1.0479
11		.7621	.8002	.743	.6859
12		.724	.6287	.4191	.6287
13		.5716	.6097	.4763	.5335
14			.6097	.4763	.4763
15		.5906	.6478	.8573	.5335
16		.6478	.7811	1.1431	.6478
17		.7621	1.086	1.2384	.743
18		1.086	1.1812	1.2955	1.0669
19	1.5242	1.2955	1.467		1.5242
20	1.2955	1.5623	1.1812	.8002	1.4861
21	.9907	1.0288	1.0098	.8002	1.0669
22	.7621	.9526	.8764	.7621	.8192
23	.724	.7621	.8383	.6668	.7621
24		.7621	.724	.8002	.6668
Max	1.5242	1.829	1.8671	1.8671	1.6575
Min	.724	.5716	.6097	.4191	.4763
Avg	1.0593	1.0098	1.0233	1.0139	.9613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 201 / NARAYANPUR AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1219	.112	.0914	.0762	.112	.2267
2	.1097	.1372	.112	.0914	.0914	.112	.2267
3	.128	.1372	.132	.128	.0914	.112	.2915
4	.128	.1524	.132	.1478	.1067	.112	.3239
5	.1307	.1524	.132	.1829	.1067	.1307	.3563
6	.128	.1829	.1698	.2054	.1219	.1509	.421
7	.1463	.1829	.1698	.168	.1219	.1698	.4534
8	.1463	.1677	.1307	.1646	.0914	.132	.502
9	.1097	.1219	.0914	.128	.0762	.0934	.5668
10		.3547		.5182	.3887	.547	.0747
11	.3401	.3913	.4938	.5506	.5256	.5344	.056
12	.3725	.3612	.5041	.5182	.6133	.5182	.0549
13	.3239	.2743	.4572	.081	.547	.5182	.0549
14	.3077	.3086	.439	.4161	.5138	.502	.0709
15	.2915	.2896	.3841	.4534	.4641	.502	.0549
16	.3239	.3086	.3734	.5344	.3978	.4858	.0526
17	.1943	.3125	.3841	.502	.499	.4858	.0526
18	.061	.0747	.0732	.0762	.0829	.0762	.0716
19	.0914	.1097	.128	.0762	.132	.0762	.0914
20	.1219	.1097	.1307	.0914	.1509	.0762	.0914
21	.1524	.1097	.128	.0914	.1307	.0914	.0914
22	.1677	.112	.1307	.0914	.1307	.0914	.0914
23	.1524	.112	.112	.0914	.112	.0914	.0732
24	.112	.1219	.112	.0914	.0762	.112	.2591
Max	.3725	.3913	.5041	.5506	.6133	.547	.5668
Min	.061	.0747	.0732	.0762	.0762	.0762	.0526
Avg	.1836	.1961	.2188	.2288	.2354	.2430	.1921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 202 / RANJANGAON S.P. GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8298	1.8298	1.9044	1.7558	1.7924	1.9791	1.9418
2	1.8671	1.9044	1.9044	1.7924	1.9044	1.9044	1.9044
3	1.9791	2.0165	1.9418	1.9791	2.0165	1.8671	1.8298
4	2.2405	2.1285	1.9418	2.0538	2.2032	2.0165	2.0165
5	2.7073	2.2032	2.0165	2.1582	2.3525	2.3152	2.0911
6	2.838	2.3152	2.6139	2.3152	2.5019	2.6972	2.3152
7	2.4646	2.4272	2.3899	2.3899	2.6886	2.4897	2.5393
8	2.2405	2.2779	2.2218	1.9791	2.4272	2.1285	2.3152
9	1.7551	2.0538	1.9791	1.7551	2.0911	2.0911	1.9044
10	1.643	1.7924	1.8111	1.6057	1.8671	1.8671	1.7551
11	1.643		1.3535		1.9044	1.8671	1.643
12	1.5497		1.9044		1.9791	1.9418	1.531
13	1.6057		1.7177		1.8484	1.9418	1.6827
14	1.6057		1.5364		1.9044	1.9044	1.8671
15			1.6461		1.8298	1.9044	1.8671
16	1.7177	1.8298	1.7924		1.7551	1.9044	1.8298
17	1.7551	1.8484	1.8671		2.1658	1.9044	1.9791
18	1.8671	2.0538	1.9387		2.1879	2.0538	2.0538
19	1.9044	2.0911	1.9753	2.0538	2.3899	2.2032	2.4646
20	1.9044	2.3525	2.2779	2.1285	2.6886	2.2405	2.5393
21	1.9418	2.1582	2.4646	2.2257	2.5019	2.2779	2.2634
22	1.9791	2.1285	2.1948	2.2634	2.5019	2.3152	2.1879
23	1.9044	1.9791	1.9753	2.0911	2.2779	2.0911	2.037
24	1.8671	1.8298	1.9418	1.8671	1.7924	2.0538	1.9791
Max	2.838	2.4272	2.6139	2.3899	2.6886	2.6972	2.5393
Min	1.5497	1.7924	1.3535	1.6057	1.7551	1.8671	1.531
Avg	1.9483	2.0642	1.9713	2.0259	2.1489	2.0817	2.0224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 203 / PIMPARKHEDA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2241	.2452	.2614	.2241	.2427	.2241
2	.2614	.2801	.2452	.2987	.2241	.2427	.2241
3	.3292	.3361	.2641	.3734	.2987	.2241	.2614
4	.3734	.3921	.2829	.4108	.3734	.2801	.2987
5	.439	.4481	.3961	.4755	.4481	.3547	.3361
6	.4938	.5041	.4715	.5121	.5228	.4108	.3734
7	.5304	.5788	.5658	.5487	.5788	.4904	.4108
8	.5228	.4854	.5093	.5415	.5788	.4715	.3361
9	.4854	.4294	.4715	.4715	.4108	.4715	.3361
10	.439	.4108	.4338	.3921	.2801	.4338	.5121
11	.3921	.4108	.3658	.3734	.2987	.4108	.4024
12	.2801	.3772	.2614	.3547	.3174	.3921	.3361
13	.2801	.3206	.2987	.3361	.2987	.3734	.3109
14		.3018	.2926	.3174	.2987	.3547	.2743
15	.2801	.2801	.2561	.2987	.2987	.3361	.2926
16	.2987	.2987	.3292	.2829	.3174	.3361	.2829
17	.3361	.3547	.3475	.3206	.3361	.3547	.3584
18	.4294	.4294	.4024	.3547	.4294	.3921	.415
19	.3921	.4715	.4572	.4294	.4715	.4294	.4904
20	.3547	.415	.4024	.3734	.4338	.4108	.4338
21	.3174	.3395	.3921	.3547	.3921	.3734	.3772
22	.2987	.3206	.3109	.3361	.3174	.3361	.3395
23	.2614	.2641	.2987	.2987	.2829	.2614	.3018
24	.2561	.2241	.2641	.2614	.2614	.2614	.2241
Max	.5304	.5788	.5658	.5487	.5788	.4904	.5121
Min	.2195	.2241	.2452	.2614	.2241	.2241	.2241
Avg	.3596	.3707	.3569	.3741	.3622	.3602	.3397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 204 / JOGESHWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.5684	1.5844	1.2803	1.5684	1.5497	1.5684
2	1.419	1.643	1.5655	1.4998	1.7551	1.531	1.7924
3	1.6804	1.7177	1.5655	1.7558	2.0165	1.475	2.0165
4	1.6804	1.8298	1.5655	1.9418	2.1285	1.6617	2.2032
5	2.3525	2.0165	1.9427	2.0538	2.3899	2.0936	2.3899
6	2.4459	2.1285	2.3577	2.2131	2.4646	2.3954	2.4272
7		2.3152	2.1691	2.2592	2.3339	2.5086	2.2965
8	2.3339	1.7364	1.905	1.9231			
9	1.7737	1.5123	1.6244	1.7737			
10	1.5684	1.4003	1.4003	1.587	1.8858	1.9605	1.7541
11	1.1949	1.3817	1.2136	1.5123	1.6991	1.8298	1.5684
12	1.0269	1.3443	1.2136	1.4563	1.587	1.7177	1.4003
13	1.0269	1.2323		1.4003	1.5497	1.643	1.4377
14	1.0269	1.2323	1.5684	1.3256	1.4937	1.5684	1.5497
15	1.1763	1.2136	1.4377	1.2696	1.5123	1.4937	1.4377
16	1.251	1.307	1.3817	1.1949	1.6057	1.4003	1.386
17	1.3817	1.4003	1.4003	1.363	1.587	1.5123	1.6078
18	1.3817	1.8298	1.4003	1.419	1.6991	1.643	1.7177
19	1.4563	1.6032	1.9605	1.5684	1.9231	1.7737	1.9978
20	1.6057	1.7918	1.9418	1.7924	2.1691	1.8298	2.1098
21	1.6617	1.7918	1.8858	1.7924	2.0165	1.8858	1.9044
22	1.7364	1.773	1.7737	1.8858	1.9418	1.9231	1.7918
23	1.587	1.6032	1.587	1.7551	1.7924	1.587	1.6975
24	1.307	1.4937	1.5844	1.307	1.587	1.6244	1.4937
Max	2.4459	2.3152	2.3577	2.2592	2.4646	2.5086	2.4272
Min	1.0269	1.2136	1.2136	1.1949	1.4937	1.4003	1.386
Avg	1.5351	1.6194	1.6534	1.6387	1.8503	1.7549	1.7977

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 205 / 11 kv NANDEDA gaotthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1949	1.2071	1.1203	1.2323	1.1763	1.1576
2	1.2323	1.2696	1.2071	1.2323	1.4563	1.1576	1.419
3	1.6617	1.419	1.2826	1.4563	1.7924	1.1576	1.8298
4	1.9791	1.643	1.4901	1.6804	2.0538	1.4003	2.0165
5	2.2405	1.7924	1.8673	1.8298	2.2032	1.7177	2.2032
6		2.0165		1.9231	2.2405	2.0936	
7	2.1285	1.9044		1.7364			
8	1.6991	1.8111	1.9978	1.7737	2.0911	1.9993	1.531
9	1.5729	1.6057	1.587	1.531		1.9427	1.7364
10	1.307	1.363	1.363	1.2696	1.531	1.643	1.3256
11	1.0642	1.2136	1.1016	1.1576		1.5684	.9335
12	1.0456	.9709	.9896	1.0082		1.4563	.8589
13	.8962	.924	.8775	.8775		1.3443	.8029
14	.7842	.8871	.8775		1.1576	1.2696	
15	.8029		.8962		1.1763	1.1949	
16	1.0829	.6161	1.0829	1.0642	1.2323	.9709	1.1273
17	1.2883	.6535	1.0608	1.251	1.4003	1.419	1.3676
18	1.475	.8589	1.2136	1.3443	1.4563	1.6057	1.5708
19	1.4377	1.9044	1.4937	1.4563	1.9231	1.8111	1.7737
20	1.4003	1.8484	1.5684	1.5684	1.9605	1.7177	1.6804
21	1.363	1.5089	1.3256	1.4937	1.6991	1.6057	1.4563
22	1.3256	1.358	1.2323	1.4003	1.4563	1.3817	1.3443
23	1.2696	1.226	1.1576	1.307	1.363	1.251	1.3203
24	1.1203	1.1949	1.2071	1.1203	1.2323	1.2323	1.1576
Max	2.2405	2.0165	1.9978	1.9231	2.2405	2.0936	2.2032
Min	.7842	.6161	.8775	.8775	1.1576	.9709	.8029
Avg	1.3607	1.3558	1.2767	1.3910	1.6136	1.4833	1.4306



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 206 / 11 KV Waluj Gaohan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.2323	1.2826	1.307	1.3443	1.2883	1.419
2	1.475	1.2696	1.2449	1.419	1.6057	1.2696	1.643
3	1.7924	1.3817	1.3203	1.6617	1.8298	1.2696	1.8298
4	2.0538	1.8298	1.5089	1.9791	2.0911	1.5684	2.0165
5	2.3339	2.1285	1.9805	2.2218		2.0559	2.3152
6	2.7446	2.4832	2.7349	2.726	2.2965	2.5652	2.5393
7	2.7073	2.8193	2.6783	2.6886	2.7446	2.7161	2.6326
8	2.3899	2.6139	2.3577	2.6513	2.3899	2.6029	2.2405
9	2.0165	2.2965	2.0748	2.2779	1.9231	2.3954	2.0725
10	1.9418	1.9044	1.8861	1.9044	1.6057	2.0748	1.7924
11	1.531	1.7177	1.5123	1.7551	1.475	1.9791	1.6804
12	1.4377	1.4563	1.363	1.531	1.419	1.8671	1.3817
13	1.1203	1.4003	1.2437	1.363	1.2136	1.7924	1.419
14	1.0082	1.3676		1.419	1.2323	1.7177	1.3213
15	1.1763	1.3306	1.2883	1.4563	1.307	1.6057	1.4377
16	1.251	1.4003	1.4449	1.4937	1.4003	1.4937	1.5497
17	1.6804	1.6244	1.6804	1.7364	1.5123	1.587	1.6804
18	1.9418	1.9978	1.7551	1.7924	1.7177	1.8298	1.9044
19	1.2696	2.1691	2.4143	1.8298	1.9616	2.2032	2.3388
20	1.6804	1.9239	2.0119	1.7177	2.2068	2.0165	2.1313
21	1.5684	1.7164	1.8298	1.643	1.8858	1.8298	2.037
22	1.419	1.5466	1.5684	1.6057	1.6244	1.6244	1.8484
23	1.3443	1.3769	1.3443	1.4937	1.3256	1.4003	1.6975
24	1.1203	1.2696	1.2826	1.8671	1.419	1.3256	1.307
Max	2.7446	2.8193	2.7349	2.726	2.7446	2.7161	2.6326
Min	1.0082	1.2323	1.2437	1.307	1.2136	1.2696	1.307
Avg	1.6718	1.7607	1.7308	1.8142	1.7187	1.8366	1.8431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 207 / 11 KV Ghanegaon Ag SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3725	.3772	.1867	.2267	.5138	.1372
2	.4481	.3725	.3772	.2054	.2591	.547	.1524
3	.4854	.4049	.3772	.1867	.2915	.5636	.1677
4	.5487	.4372	.3772	.2241	.3563	.6133	.1981
5	.5853	.4696	.4115	.2614	.421	.6706	.2286
6	.5975	.502	.5533	.2561	.502	.7377	.2439
7	.6161	.6535	.5801	.1867	.5992	.8648	.2591
8	.5415	.5312	.6133	.2801	.6964	.9259	.2286
9	.6348	.5182	.2374	.2054	.7045	.9259	.2134
10	.1867	.1219	.0762	.0457	.0914		
11	.1307	.1524	.0732	.0457			.7282
12	.1067	.1334	.0709	.0457		.061	.8029
13	.1067			.0457		.0914	.7842
14	.1219		.0914			.0914	
15	.1067		.0732		.1132	.0914	
16	.0914	.1334	.0914	.0457	.1143	.0914	1.094
17	.1219	.1524	.0732	.0457	.0953	.0762	1.1768
18	.1219	.1715	.0747	.0457	.1143	.1067	.1334
19	.1219	.1905	.1829	.0457	.1334	.1219	.2096
20	.1372	.1905	.112	.0457	.1905	.1372	.2096
21	.1372	.1905	.112	.2267	.1715	.1524	.2096
22	.1524	.1905	.112	.2753	.1524	.1867	.1905
23	.1524	.1524	.0934	.2267	.1334	.168	.1905
24	.3658	.3563	.3601	.1867	.2267	.4973	.1372
Max	.6348	.6535	.6133	.2801	.7045	.9259	1.1768
Min	.0914	.1219	.0709	.0457	.0914	.061	.1334
Avg	.2929	.3046	.2392	.1509	.2797	.3743	.3665

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044062 / 33/11 KV WALUJGAON SUB- ST

Feeder No / Name : 208 / 11 KV East West Industri SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2614	.381	.2926	.2241	.2667	.2987
2		.2614	.3429	.3734	.1524	.2667	.3048
3	.2561	.2241	.3429	.3292	.1867	.2667	.2667
4	.2926	.2241	.2286	.4108	.1867	.2286	.2667
5	.2241	.2241	.3048	.3734	.2241	.2667	.2667
6	.2561	.2241	.2667	.2987	.2241	.2667	.2667
7	.2241	.2241	.2286	.2241	.2241	.2286	.2667
8	.1867	.2241	.2667	.2241	.2614	.2286	.2286
9	.3361	.2987	.3696	.2614	.3734	.4191	.2286
10	.5228	.3361	.4706	.2987	.4481	.4191	.5228
11	.5601	.381	.5228	.3361	.5335	.4108	.6584
12	.5975	.381	.4481	.3734	.5335	.4481	.5975
13	.5975	.4191	.3361	.4481	.5335	.4854	.5601
14	.5601	.4954		.4108	.5716	.5228	.5601
15	.5228	.5335	.5601	.3734	.5716	.5601	.5601
16	.4854	.4954	.5228	.2987	.5716	.5601	.543
17	.5228	.381	.4108	.3361	.4954	.4481	.4706
18	.3361	.2667	.2241	.2743	.3429	.3734	.3429
19	.3361	.2667		.2987	.2286	.2614	.2667
20	.3734	.3048	.3292	.2987	.3048	.2614	.2667
21	.3734	.3048	.3361	.2614	.3048	.2987	.3429
22	.3734	.3429	.2926	.2614	.3048	.2987	.3429
23	.3361	.3429	.4108	.2263	.2667	.3734	.3429
24	.2195	.2614	.3429	.3734	.2241	.2667	.2987
Max	.5975	.5335	.5601	.4481	.5716	.5601	.6584
Min	.1867	.2241	.2241	.2241	.1524	.2286	.2286
Avg	.3790	.3200	.3609	.3191	.3455	.3511	.3779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 201 / 11 KV GAJGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1463	.1524	.1334	.1334	.1143	.2715
2	.1334	.1417	.1524	.1334	.1334	.1143	.3429
3	.132	.1463	.1524	.1334	.1524		.3429
4							.4115
5							.4049
6							.5182
7							.5535
8							.6009
9							.6097
10	.3658	.381	.3429		.5716	.3429	
11	.4755	.4191	.4287		.8002	.5144	
12	.4961	.5144	.502		1.0479	.5658	
13	.5304		.5182	.1524	.9145	.6001	
14	.4607	.3048	.4858	.1905	.7811	.583	
15	.4252	.5144	.506	.2286	.7621	.5668	
16	.4607	.5335	.5344	.7621	.724	.5344	.0572
17	.4024	.5716	.4858	.8383	.6859	.4858	.0762
18	.1097	.0762	.0566		.1143	.0762	.0953
19	.1097	.1143	.0953	.0953	.1143	.0953	.1143
20	.0886	.1143	.0953	.1334	.1143	.1143	.1143
21	.1463	.1334	.1143	.1334	.1143	.1143	.1143
22	.1417	.1524	.1143	.1334	.1143	.1143	.1143
23	.1448		.1143	.1334	.1143	.1143	.1143
24	.1143	.1463	.1524	.1143	.1334	.1143	.181
Max	.5304	.5716	.5344	.8383	1.0479	.6001	.6097
Min	.0886	.0762	.0566	.0953	.1143	.0762	.0572
Avg	.2706	.2756	.2780	.2368	.4181	.3038	.2798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 202 / 11 kv RANJANGAON POL AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.6335	.4763	.5373	.5716	.4763	.5716
2	.4024	.7133	.4763	.5144	.6097	.5335	.5716
3	.4163	.7545	.5335	.5487	.6668	.4572	.5658
4	.4298	.7964	.5335	.6001	.724	.7049	
5	.4287	.8682	.6478	.5735	.7621	.7621	
6	.5144	.8328	.6668	.6478	.8002	.7621	
7	.4973	.8505	.6668	.7202	.9526	.9526	
8	.5365	.9412	.6859	.7432	1.1431	.9526	
9	.5344	.9907	.6859	.6249	1.105	.3429	
10							.381
11							.4954
12							.6097
13							.6668
14							.8573
15							.9907
16	.3658		.1905	.1524		.1905	.9907
17	.4755	.2286	.1905	.1905		.2286	.9526
18	.4252	.2667	.2477		.2667	.2858	.3429
19	.4607	.2667	.381	.2858	.3429	.381	.4191
20	.3544	.3429	.4763	.381	.381	.4191	.4763
21	.3898	.381	.4763	.381	.4191	.4763	.4763
22	.4252	.381	.4763	.4763	.4191	.4763	.4763
23	.3898	.4191	.4763	.4763	.4191	.4763	.4763
24	.2286	.3544	.3429	.5716	.5716	.381	.4763
Max	.5365	.9907	.6859	.7432	1.1431	.9526	.9907
Min	.2286	.2286	.1905	.1524	.2667	.1905	.3429
Avg	.4265	.5895	.4795	.4956	.6347	.5144	.5998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 203 / 11 KV GAWALI SHIVARA

GAOTHAN FEEDER

GAOTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.3292	.2896	.2926	.3048	.3439	.2743
2	.3109	.5138	.3258	.3292	.3429	.362	.2743
3	.3658	.6024	.3982	.4525	.4191	.439	.2926
4	.4572	.6024	.5121	.543	.5335	.5121	.3292
5	.543	.7087	.5121	.6335	.5906	.543	.4024
6	.5973	.6379	.5973	.6335	.6668	.6036	.543
7	.6154	.567	.6219	.5611	.6097	.6036	.5792
8	.543	.5493	.5853	.543	.5335	.5068	.543
9	.362	.4344	.4572	.4344	.4572	.4706	.4024
10	.3898	.3292	.362	.381	.4024	.3982	.381
11		.3439	.2743	.3048	.3658	.362	.3429
12	.1595	.1991	.1829	.2667	.2715	.3077	.3048
13	.1829		.2012	.2477	.2534	.2172	.2667
14	.1949	.1646	.2195	.2477	.2534	.2172	.2286
15	.2126	.2096	.2195	.3048	.2743	.2195	.2286
16	.2303	.2172	.2353	.381	.2715	.2534	.2667
17	.2378	.2561	.3109	.4572	.2896	.3292	.3048
18	.362	.3801	.3658		.4344	.3658	.4191
19	.4024	.439	.5487	.5335	.4344	.4572	.5335
20	.3658	.4572	.5068	.5335	.3982	.5544	.5716
21	.2896	.4755	.4572	.4572	.362	.3658	.5335
22	.2149	.4024	.362	.381	.3258	.3292	.4763
23	.2126	.2378	.3109	.3429	.2896	.2926	.381
24	.2957	.1949	.2534	.2743	.3048	.3258	.2772
Max	.6154	.7087	.6219	.6335	.6668	.6036	.5792
Min	.1595	.1646	.1829	.2477	.2534	.2172	.2286
Avg	.3409	.4022	.3796	.4146	.3912	.3908	.3815

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 204 / 11 KV RAJANGAON POL  
GAOTHAN Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2926	.2743	.2587	.2667	.3077	.2561
2	.2743	.3189	.3258	.2743	.3048	.3077	.2743
3	.3292	.3544	.3801	.2743	.381	.3258	.2926
4	.362	.5138	.3982	.3292	.4763	.362	.3292
5	.5068	.6219	.5068	.4525	.5716	.4344	.4572
6	.6335	.6401	.6335	.543	.6859	.5792	.543
7	.7602	.6584	.6697	.5973	.6287	.6154	.5611
8	.724	.567	.5716	.5853	.5716		.5487
9	.4706	.4024	.3292	.3109	.4763		.3258
10	.3658	.1463	.2743	.2286	.3292	.3658	.2858
11	.2835	.128	.1829	.1715	.2195	.3109	.2667
12		.128	.1463	.1715	.1829	.2195	.2286
13	.1646		.1463	.1715	.1829	.1646	.1905
14	.2012	.128	.1663	.1715	.1829	.1646	.1715
15	.1829	.1463	.1829	.1715	.2378	.1829	.1715
16	.2263		.1829	.1905		.2195	.1905
17	.2452	.2534	.2378	.2286		.2715	.2096
18	.4607	.3292	.2715		.439	.3658	.3048
19	.3544	.4344	.4525	.4191	.4024	.4572	.381
20	.4252	.4024	.5487	.4572	.3658	.4805	.4572
21	.3544	.3982	.4525	.4001	.3658	.3658	.4191
22	.2835	.3658	.3658	.3429	.3258	.3142	.381
23	.2561	.2378	.2743	.3048	.2926	.2772	.3048
24	.2772	.2195	.2743	.2561	.2667	.2534	.2587
Max	.7602	.6584	.6697	.5973	.6859	.6154	.5611
Min	.1646	.128	.1463	.1715	.1829	.1646	.1715
Avg	.3660	.3494	.3437	.3179	.3707	.3339	.3254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 205 / 11 KV BORGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2835	.3429	.1629	.1524	.3429	.1143
2	.1905	.2926	.381	.181	.1524	.381	.1143
3	.1829	.3189	.381	.2172	.1905	.4191	.1143
4	.181	.3189	.4382	.2172	.2286	.4191	
5	.2149	.3544	.4572	.2401	.2858	.4382	
6	.2629	.3544	.4763	.3155	.3429	.4572	
7	.2804	.4607	.4763	.4115	.4763	.4763	
8	.3086	.4607	.381	.4096	.5716	.5335	
9	.3429	.4954		.4049	.5144	.6287	
10							.2858
11							.3429
12							.381
13							.381
14							.4191
15							.381
16	.0732		.0381	.0381	.0191	.0572	.3429
17		.0381	.0572	.0381	.0191	.0762	.381
18	.0709	.0381	.0762		.0572	.0953	.0572
19	.0732	.0381	.0762	.0953	.0762	.0953	.0953
20	.0886	.0381	.0953	.0953	.0762	.0953	.0953
21	.0914	.0381	.0953	.0953	.0762	.1143	.0953
22	.0732	.0762	.0953	.0953	.0762	.1143	.1143
23	.0732	.0762	.0953	.0953	.0762	.1143	.1143
24	.1524	.1463	.1905	.1448	.1524	.1905	.1143
Max	.3429	.4954	.4763	.4115	.5716	.6287	.4191
Min	.0709	.0381	.0381	.0381	.0191	.0572	.0572
Avg	.1666	.2252	.2443	.1916	.1969	.2805	.2191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 206 / 11 KV GAWALI SHIWARA AG SEPARATED AG FEEDERS HAVING SPECIAL  
FEEDER Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1063	.1143	.0953	.0953	.0762	.2172
2	.0953	.1063	.1143	.0953	.0953	.0762	.2715
3	.0953	.1063	.1143	.0943	.1143	.0762	.2715
4							.3258
5							.4252
6							.4287
7							.4801
8							.5243
9							.5735
10	.3544	.4763	.3772	.6668	.6668	.7087	
11	.3898	.4763	.4915	.7621	.9526	.8764	
12	.3898	.5144	.5182	1.0479	.9717	1.0402	
13	.362		.5144	.9907	.9907	1.0802	
14	.4252	.5144	.503	.9526	.9907	1.0974	
15	.3658	.5144	.5243	1.0098	1.0288	1.046	
16	.3544	.5525	.6001	1.0098	1.0479	1.0288	.0381
17	.3366	.5716	.6001	1.0479	.9526	1.0288	.0572
18	.0732	.0381	.0381		.0381	.0381	.0762
19	.0914	.0381	.0572	.0762	.0572	.0572	.0953
20	.0857	.0381	.0762	.0762	.0572	.0572	.0953
21	.0914	.0381	.0762	.0762	.0762	.0572	.0953
22	.1132	.0381	.0762	.0762	.0762	.0572	.0953
23	.0914	.0381	.0953	.0953	.0762	.0572	.0953
24	.0762	.1063	.0762	.0953	.0953	.0762	.1905
Max	.4252	.5716	.6001	1.0479	1.0479	1.0974	.5735
Min	.0732	.0381	.0381	.0762	.0381	.0381	.0381
Avg	.2159	.2514	.2760	.4863	.4657	.4742	.2420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 207 / 11KV KBS INDUSTRIAL FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0177	.0191	.0191	.0191	.0381	.0191
2	.0191	.0177	.0191	.0191	.0191	.0381	.0191
3	.0191	.0177	.0191	.0191	.0191	.0381	.0191
4	.0191	.0177	.0191	.0191	.0191	.0381	.0191
5	.0191		.0191	.0191	.0191	.0381	.0191
6	.0191	.0183	.0191	.0191	.0191	.0381	.0191
7	.0191	.0177	.0191	.0191	.0191		.0191
8	.0191	.0177	.0191	.0191	.0191		.0191
9	.0191	.0191	.0191	.0191	.0191		.0191
10	.0183	.0191	.0191	.0191	.0191	.0373	.0191
11	.0183	.0191	.0191	.0191	.0191	.0191	.0191
12	.0183	.0191	.0191	.0191	.0191	.0191	.0191
13	.0183		.0191	.0191		.0191	.0191
14	.0183	.0191	.0191	.0191	.0191	.0191	.0191
15	.0177	.0191	.0191	.0191	.0191	.0191	.0191
16	.0177	.0191	.0191	.0191	.0191	.0191	.0191
17	.0183	.0191	.0191	.0191	.0191	.0191	.0191
18	.0183	.0191	.0191		.0191	.0191	.0191
19	.0183	.0191	.0191	.0191	.0191	.0191	.0191
20	.0183	.0191	.0191	.0191	.0191	.0191	.0191
21	.0177	.0191	.0191	.0191	.381	.0191	.0191
22	.0183	.0191	.0191	.0191	.0191	.0191	.0191
23	.0183	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0183	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.381	.0381	.0191
Min	.0177	.0177	.0191	.0191	.0191	.0191	.0191
Avg	.0186	.0186	.0191	.0191	.0348	.0254	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044066 / RANJANGAON POL

Feeder No / Name : 208 / Dhananjay auto

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1772	.1524	.2058	.2286	.1905	.2667
2	.2254	.1772	.1715	.2058	.2286	.1905	.2667
3	.2401	.2012	.1715	.2254	.2286	.2286	.2858
4	.2454	.2561	.1715	.2374	.2286	.2286	.2858
5	.2572	.2658	.2286	.218	.1905	.2286	.3048
6	.2601	.2835	.2286	.1966	.1524	.2667	.3048
7	.2743		.2477	.1715	.1905	.3048	.3048
8	.2058	.2835	.1905	.1475	.1905	.3048	.2561
9	.1715	.1905	.1143	.1267	.2096	.2096	.1905
10	.2012	.1905	.1475	.1905	.2096	.2401	.2667
11	.1772	.1905	.1715	.1905	.1905	.2401	.2667
12	.1772		.1715	.1905	.1905	.2229	.2667
13	.1829		.1781	.1905	.1905	.2229	.2667
14	.181	.1334	.2012	.1905	.1905	.2401	.2667
15	.181	.1334	.2058	.1905	.1905	.2058	.2667
16	.1829	.1334	.1715	.1905	.2096	.2229	.2667
17	.1829	.1334	.1865	.1905	.2286	.2401	.3048
18	.1949	.1334	.2035		.2286	.2572	.3048
19	.1949	.1334	.2401	.3048	.2286	.2743	.3048
20	.1949	.1334	.2058	.3048	.1905	.2858	.3048
21	.1949	.1334	.1372	.3048	.1905	.2286	.3048
22	.1949	.1334	.1372	.3048	.1715	.2477	.3048
23	.1646	.1143	.1543	.2286	.1715	.2667	.3048
24	.2035	.1595	.1334	.1372	.2286	.1715	.2667
Max	.2743	.2835	.2477	.3048	.2286	.3048	.3048
Min	.1646	.1143	.1143	.1267	.1524	.1715	.1905
Avg	.2039	.1757	.1801	.2106	.2024	.2383	.2806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 201 / 11 KV AMINABAD AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521	.3734	.3353	.4287	.5544	.4578	.3772
2	.3605	.4108	.4191	.5087	.5544	.4973	.415
3	.3932	.4435	.503	.5087	.6283	.5765	.415
4	.4641	.5175	.5868	.6203	.7023	.6443	.4527
5	.4915	.5544	.7209	.7042	.8048	.78	.4904
6	.6783	.7392	.8383	.9116	.9511	.9326	.5281
7	.8478	1.0387	1.2574	1.1603	.9145	1.3565	.5281
8	.9496	1.1568	1.5089	1.2955	1.6804	1.5581	.4527
9	.945	1.2308	1.5089	1.4089	1.5424	1.7126	.3018
10	.2374	.2263	.2263	.2263	.2641	.2374	.8383
11	.2263	.1886	.1698	.1886	.1543	.1886	1.0059
12	.2263	.1132	.1698	.1509		.1886	1.0898
13	.1509	.132	.1509	.1509	.1187	.1509	1.1736
14	.1509	.1509	.1509		.1187	.1478	1.1736
15	.1509	.1509	.1509		.1357	.1886	1.2574
16	.1509	.1509	.132	.1886	.1219	.1886	1.3413
17	.1886	.1698	.1886	.2263	.1696	.2263	
18		.2452	.2263		.1829	.3395	.1886
19	.3395	.3052	.2641	.3395	.2207	.3772	.3772
20	.3395	.3395		.3395	.3391	.3772	.415
21	.2641	.3018	.2263	.3395	.2713	.3395	.3772
22	.2263	.2075	.1886	.2641	.2374	.3018	.3395
23	.2263	.2075	.1698	.1886	.2204	.3018	.3018
24	.373	.3734	.3353	.5258	.5601	.4409	.3772
Max	.9496	1.2308	1.5089	1.4089	1.6804	1.7126	1.3413
Min	.1509	.1132	.132	.1509	.1187	.1478	.1886
Avg	.3797	.4053	.4534	.5084	.4977	.5213	.6181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 202 / 11 KV WARKHED AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1658	.1886	.1886	.1886	.1886	.2713	.5228
2	.1696	.1886	.1886	.1886	.1886	.2713	.5228
3	.1696	.2263	.2263	.1886	.2263	.2713	.5601
4	.1886	.2263	.2263	.2641	.2263	.2883	.5914
5	.2058	.2641	.2452	.2829	.2641	.3222	.6653
6	.2204	.3018	.2641	.3395	.3395	.3391	.7762
7	.2374	.3018	.2452	.3395	.3018	.3018	1.0974
8	.2204	.3018	.2075	.2641	.2641	.2347	1.0608
9	.1696	.1886	.1509	.1698	.1698	.2204	1.0974
10	.407	.5853	.57	.3768	.8596	.8139	.1509
11	.4435	.6371	.5868	.8779	.9835	.9503	.132
12	.2218	.5868	.5365	.9145	1.0513	1.0277	.132
13	.5914	.503	.5365	.8048	1.1191	1.073	.1132
14	.6283	.2683	.503	.7762	1.0852	1.0059	.1132
15	.4805	.285	.57		1.0852	1.0059	.1132
16	.2957	.3018	.8192	.7392	1.1191	.8322	.1132
17	.5175		.8192	.7392	1.153	.8322	.1132
18	.1886		.1509		.2035	.3018	.1509
19	.3018		.2641	.3018	.2713	.3395	.2641
20	.3018		.3395	.3018	.3052	.3395	.3018
21	.2641	.2263	.3395	.2641	.2713	.3395	.132
22	.2263	.2263	.2829	.2263	.2713	.2641	.2075
23	.1886	.1886	.2829	.1886	.2713	.1886	.1886
24	.1696	.1886	.1886	.2641	.1886	.2713	.5914
Max	.6283	.6371	.8192	.9145	1.153	1.073	1.0974
Min	.1658	.1886	.1509	.1698	.1698	.1886	.1132
Avg	.2906	.3093	.3638	.4091	.5170	.5044	.4046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 204 / 11KV GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3734	.3584	.3772	.3734	.373	.3734
2	.3898	.4108	.3772	.3772	.3734	.4207	.3734
3	.4607	.4854	.5658	.4715	.4481	.4557	.4481
4	.567	.5975	.7545	.7167	.4854	.5609	.5175
5	.6379	.6722	.9431	.8402	.6348	.7537	.6653
6	.9214	.924	.9808	.9709	.8962	.8413	.8779
7	.9114	.5228	.9431	.8775	.8215	.8573	.8413
8	.8413	.7316	.415	.9242	.7316	.6935	.7682
9	.7011	.5544	.679	.7392	.5853	.7011	.0427
10	.5548	.4435	.4527	.4251	.4066	.5609	.4527
11	.4435	.3395	.3547	.2957	.2543	.3326	.3258
12	.2957	.2641	.2772	.2561		.2957	.3018
13	.2218	.132	.1848	.2587	.2713	.2587	.3018
14	.2218	.0943	.1867		.2658	.2587	.2263
15	.2587	.1509	.1848		.2374	.2587	.2452
16	.2587	.1132	.1294	.2987	.2713	.2957	.2829
17	.4435	.3772	.362	.3734	.4031	.4435	
18		.6602	.462		.5083	.5544	.6224
19	.8131		.8676	.8215	.7011	.6653	.8299
20	.6283			.7095	.7011	.5975	.6979
21	.4481	.6413	.5658	.5228	.5258	.5228	.5281
22	.4481	.5281	.4715	.4854	.4733	.415	.4527
23	.4108	.415	.415	.4481	.4207	.3772	.3772
24	.3429	.4108	.415	.3772	.4108	.3856	.3734
Max	.9214	.924	.9808	.9709	.8962	.8573	.8779
Min	.2218	.0943	.1294	.2561	.2374	.2587	.0427
Avg	.5031	.4474	.4933	.5508	.4870	.4950	.4750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044070 / 33/11 KV WARKHED

Feeder No / Name : 205 / 11KV MUDDESH WADGAON AG FEEDER SEPERATION/PURE AG  
FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2957	.2683	.4908	.5601	.4748	
2	.2267	.2957	.2683	.503	.5544	.4917	
3	.2267	.3326	.3018	.503	.5914	.4973	
4	.2622	.3326	.3353	.5087	.6219	.57	
5		.3696	.4191	.5935	.6584	.6371	
6		.4805	.4527	.6036	.7682	.6706	
7		.2772	.5868	.6706	1.0136	.8223	
8		.7499	.7042	.8288	1.1488	1.153	
9	.6097	.7682		.852	1.0059	1.1271	
10							1.0059
11							1.1401
12							1.1736
13							1.0227
14							1.0898
15							1.2071
16							1.3245
17							1.3077
24	.2035	.2957	.2683	.4801	.5228	.4748	
Max	.6097	.7682	.7042	.852	1.1488	1.153	1.3245
Min	.2035	.2772	.2683	.4801	.5228	.4748	1.0059
Avg	.2904	.4198	.4005	.6034	.7446	.6919	1.1589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 201 / 11 KV DONGAON AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2743	.1886	.1387	.1543	.1698	.4715
2	.2572	.2652	.1886	.156	.1658	.168	.4715
3	.2915	.2818	.2054	.1734	.1966	.1867	.5093
4	.3052	.2949	.2241	.2452	.1781	.1886	.6413
5	.3353	.3277	.2427	.2601	.2267	.2241	.7545
6	.3521	.3239	.2713	.3584	.3201	.2713	.7733
7	.407	.3725		.4191	.3795	.3647	.6036
8	.4748	.4161	.2984	.3315	.4531	.3481	.547
9	.4239	.2721	.285	.2949	.3125	.4024	.4338
10	.2641	.3018	.3395	.2075	.3688	.2829	.1326
11	.2641	.2374	.2829	.2263	.2204	.2452	.1492
12	.2452	.1989	.2075	.1886	.2321	.2641	.1326
13	.2641	.1823	.1886	.1886	.2347	.2452	.116
14	.3018	.1696	.1886	.2075	.218	.2263	.116
15	.3018	.1844	.2075	.2263	.2374	.2641	.1492
16	.2829	.1823	.2263	.2263	.218	.2263	.1658
17	.3206	.2035	.2829	.2641	.1989	.2641	.2012
18	.3018	.3174	.3206	.3395	.3547	.4338	.4527
19	.547	.5975	.6413	.6413	.4854	.4715	.6602
20	.679	.6036	.6224	.5847	.5975	.547	.5658
21	.4904	.5041	.6036	.5658	.4527	.5093	.5281
22	.4527	.4481	.4338	.4338	.3921	.4715	.4904
23	.4527	.3921	.3395	.3395	.3547	.4527	.4715
24	.2601	.2572	.1509	.1214	.1543	.1509	.415
Max	.679	.6036	.6413	.6413	.5975	.547	.7733
Min	.2452	.1696	.1509	.1214	.1543	.1509	.116
Avg	.3555	.3170	.3017	.2974	.2961	.3074	.4147



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 202 / 11 KV RAIPUR AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.4115	.2614	.1734	.2012	.2614	.5658
2	.2915	.431	.2829	.2254	.1989	.2829	.6036
3	.3052	.3978	.3174	.2601	.2294	.2801	.6602
4	.3052	.3932	.3395	.3294	.2622	.2987	.6979
5	.3353	.426	.3547	.3467	.3647	.3174	.7545
6	.3647	.4858	.4917	.4287	.4001	.5087	.9054
7	.5596	.502		.6036	.5376	.57	.7545
8	.6001	.5761	.6371	.6133	.7499	.7459	.7167
9	.5144	.5281	.6036	.6796	.6562	.7209	.5658
10	.3018	.3521	.415	.2263	.4862	.3206	.2321
11	.3395	.2543	.3395	.2263	.407	.285	.2652
12	.2829	.2155	.2263	.2452	.2652	.3395	.2652
13	.3018	.2155	.2075	.2641	.2347	.3395	.2652
14	.3018	.2035	.2263	.2641	.2347	.3395	.2486
15	.3206	.218	.2452	.2829	.2543	.3395	.2652
16	.3206	.2652	.2641	.2829	.285	.3772	.3315
17	.3772	.2713	.3584	.3206	.2984	.3961	.4024
18	.3395	.4108	.3961	.4338	.4294	.6036	.6224
19	.7356	.8962	.811	.8488	.7842	.7167	.8676
20	.9619	.9054	.9054	.9431	.9149	.7922	.811
21	.811	.7468	.8676	.8488	.7356	.7545	.7545
22	.6979	.6348	.6602	.679	.6722	.7167	.7356
23	.6979	.5601	.5093	.5093	.6413	.6224	.7167
24	.3121	.3258	.2427	.1734	.2263	.2452	.6036
Max	.9619	.9054	.9054	.9431	.9149	.7922	.9054
Min	.2829	.2035	.2075	.1734	.1989	.2452	.2321
Avg	.4458	.4428	.4332	.4254	.4362	.4656	.5671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044075 / 33/11 KV DONGAON SUB STATION

Feeder No / Name : 203 / 11 KV PADALSA AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545		.6036	.6036	.5658	.5975	.3772
2	.8299	.679	.6348	.6224	.6413	.6535	.4115
3	.9054	.7167	.7167	.679	.6979	.7167	.4287
4	1.0751	.7356	.8402	.8676	.8488	.811	.4578
5	1.2071	1.0185	.9522	1.3203	1.3014	.9335	.5256
6	1.3769	1.1317	1.1361	1.358	1.4146	1.153	.5868
7	1.226	1.3392		1.3014	1.3392	1.0059	.7377
8	1.1317	1.226	.9221	1.1317	.9242	1.0277	.7712
9	.9808	.811	.788	.8299	.9242	.8718	.6706
10	.426	.4527	.4862	.5243	.57	.6783	.2641
11	.4915	.407		.4858	.6274	.6706	.2829
12	.4534	.3978	.5087	.4641	.6299	.6203	.2641
13	.4696	.3481	.373	.4481	.5868	.5935	.2452
14	.4915	.3391	.3561	.4481	.57	.5935	.2641
15	.4858	.3353	.3391	.4161	.5765	.4973	.2829
16	.4696	.3647	.3561	.3841	.6036	.4287	.3018
17	.421	.4409	.4917	.4641	.6299	.4287	.3772
18	.3772	.3547	.3395	.3395	.4294	.7167	.7356
19	.679	.9335	.9431	.9619	.8402	.7545	.9997
20	.9431	.9242	.9054	1.0751	1.1203	.8299	.9431
21	.9054	.7468	.7733	.7922	.7733	.7922	.811
22	.8488	.6908	.7167	.7167	.7167	.7167	.7356
23	.8488	.6348	.6224	.6413	.6602	.6602	.679
24	.7167	.7167	.5658	.5847	.6036	.6348	.3467
Max	1.3769	1.3392	1.1361	1.358	1.4146	1.153	.9997
Min	.3772	.3353	.3391	.3395	.4294	.4287	.2452
Avg	.7715	.6846	.6532	.7275	.7748	.7244	.5208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 201 / 11 KV ZANZARDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.1174	.0566	.0754	.0781	.1006	.3048
2	.0671	.1006	.0566	.0754	.0781	.1006	.3048
3	.0671		.0566	.0566	.0791	.1006	.3048
4							.3353
5							.381
6							.3963
7							.3963
8							.4572
9							.5487
10	.381	.6036	.3563	.5182	.6874	.6401	
11	.4359	.5182	.5243	.6944	.8383	.7621	
12	.4694	.3963	.4858	.6481	.9389	.823	
13	.503	.4146	.4534	.6173	1.0174	1.0364	
14	.5426	.3715	.4372	.5792	1.0395	1.0669	
15	.5197	.3887	.4534	.6249		1.0059	
16	.5365	.3887	.5243	.6859	.9156	.9145	
17	.503	.3467		.6636	.9496	.6401	.0566
18	.0671	.0754	.0754	.0594	.0678	.0914	.0566
19	.0838	.132	.0943	.0743	.0848	.112	.0943
20	.1017	.1509	.1132	.0914	.1017	.112	.1132
21	.1017	.0943	.1132		.1174	.1097	.0943
22	.0848	.0754	.1132	.0762	.1006	.112	.0754
23	.1017	.0566		.061	.1006	.112	.0754
24	.0663	.1006	.0566	.0754	.0781	.0838	.2743
Max	.5426	.6036	.5243	.6944	1.0395	1.0669	.5487
Min	.0663	.0566	.0566	.0566	.0678	.0838	.0566
Avg	.2610	.2548	.2482	.3339	.4278	.4402	.2511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 202 / 11 KV PENDAPUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1486	.1844	.0937	.213	.1372	.2035	.1132
2	.1486	.1943	.08	.2267	.1543	.2204	.132
3	.1783	.2012	.0819	.2294	.1524	.2204	.1886
4	.2134	.2012	.0972	.2622	.1698	.2374	
5	.2286	.2515	.1296	.2591	.1852	.2134	
6	.2439	.2683	.1966	.2949	.1981	.2543	
7	.2623	.3052	.176	.3441	.2753	.3353	
8	.2896	.3222	.1311	.3401	.3125	.3688	
9	.3401	.3391	.1296	.3441	.3549	.4024	
10							.2286
11							.2591
12							.2294
13							.1802
14							.2105
15							.1572
16	.1006	.0943	.0943	.0429	.1006	.0914	.1486
17	.1174	.1132		.0572	.1357	.128	.2031
18	.1341	.132	.1132	.0714	.1526	.1509	.1132
19	.1509	.1698	.1698	.1341	.1696	.1886	.1509
20	.1677	.1509	.1509	.1475	.1865	.1886	.1698
21	.1844	.1509	.132		.1844	.1509	.132
22	.2012	.132	.1132	.0972	.2012	.132	.132
23	.1844	.1132		.0892	.1696	.1132	.1132
24	.1457	.1677	.1311	.1147	.1219	.2012	.1132
Max	.3401	.3391	.1966	.3441	.3549	.4024	.2591
Min	.1006	.0943	.08	.0429	.1006	.0914	.1132
Avg	.1911	.1940	.1263	.1922	.1868	.2112	.1653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 203 / 11KV BABARGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1635	.1677	.2949	.1638	.1158	.1677	
2	.1829	.1844	.3052	.1966	.1158	.2012	
3	.1829	.2012	.2753	.1875	.1337	.2347	
4	.1981	.218	.2753	.208	.1337	.2543	
5	.2006	.2204	.3239	.2881	.1524	.2713	
6	.216	.2347	.3239	.2968	.1524	.285	
7	.2315	.3353	.3401	.3041	.3125	.4359	
8	.3086	.4359	.5182	.4534	.3795	.503	
9	.3563	.4694	.4801	.4424	.4999	.57	
10							.3658
11							.4915
12							.3521
13							.2785
14							.285
15							.298
16							.4752
17							.4687
24	.1486	.1341	.1696	.1696	.1143	.1341	
Max	.3563	.4694	.5182	.4534	.4999	.57	.4915
Min	.1486	.1341	.1696	.1638	.1143	.1341	.2785
Avg	.2189	.2601	.3307	.2710	.211	.3057	.3769

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

GANGAPUR (R) S/DN[397] BU 2224

Substation No/ Name :- 044085 / 33KV/11KV SOLEGAON

Feeder No / Name : 204 / 11KV EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0168	.0124	.0124	.0124	.0168	.0152
2	.0168	.0168	.013	.013	.013	.0168	.0152
3	.0168	.0168	.013	.013	.0133	.0162	.0152
4	.017	.017	.013	.0156	.0133	.0168	.0152
5	.0171	.0339	.013	.0156	.0135	.017	.0152
6	.0173	.0339	.0316	.013	.0135	.017	.0152
7	.0173	.0339	.0234	.013	.0152	.0335	.0152
8	.0312	.0339	.0362	.0124	.0158	.0335	.0152
9	.0526	.0335	.0162	.0124	.0143	.0339	.0152
10	.0347	.0335	.013	.012	.0312	.0532	.0154
11	.0503	.017	.0156	.0143	.017	.0335	.0339
12	.0509	.0164	.0324	.0135	.017	.0335	.0124
13	.0509	.0162	.0124	.0135	.0168	.0335	.013
14	.0335	.013	.0156	.0133	.0168	.0335	.0156
15	.0335	.0131	.0149	.0135		.0335	.013
16	.0335	.0175	.0286	.0143	.0335	.0335	.0156
17	.0335	.0377		.0156	.0335	.0335	.0339
18	.0335	.0373	.0143	.0133	.0339	.0335	.056
19	.0335	.0328	.0143	.0133	.0339	.0335	.0124
20	.0335	.0118	.0143	.0124	.0339	.0335	.013
21	.0335	.013	.0124		.0335	.0152	.0124
22	.0335	.0259	.0312	.0124	.0339	.0152	.0124
23	.0335	.0124		.0124	.0339	.0152	.0116
24	.0173	.0168	.0124	.0124	.0124	.0168	.0152
Max	.0526	.0377	.0362	.0156	.0339	.0532	.056
Min	.0168	.0118	.0124	.012	.0124	.0152	.0116
Avg	.0309	.0230	.0183	.0133	.0220	.0272	.0176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 202 / 11 KV KHULTABAD II  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.415	.4115	.415	.3772	.4904	.285
2	.3601	.4527	.4115	.415	.3772	.4904	.2347
3	.3772	.4904	.4801	.4527	.3772	.5281	.2347
4	.4458	.4904	.5487	.4904	.4458	.6036	.2683
5	.5487	.5658	.6173	.4904	.583	.7167	.3185
6	.6687	.7545	.703	.7545	.823	1.0185	.4024
7	.7202	.9431	.8573	1.1317	1.1488	1.3203	.3353
8	.8059	1.1317	.9774	1.5089	1.3889	1.6975	.2683
9	.7202	1.0185	.9945	1.5089	1.4918	1.8861	.1844
10	.1677	.1543	.1543	.12	.1543	.1543	.6687
11	.1006	.12	.1029	.0686	.12	.0686	.5316
12	.0934	.0857	.1029	.0686	.1029	.0857	.2229
13	.0914	.0857	.1029	.1029	.0857	.0857	.5144
14	.1006	.1029	.1029	.0857	.0857	.1029	.4973
15	.0838	.0857	.1029	.0857	.0857	.1029	.5144
16	.0838	.1029	.1029	.0857	.0686	.1174	.5144
17	.1132	.12	.1132	.0857	.1132	.1509	.5144
18	.1886	.1372	.1509	.1029	.1132	.1677	.1543
19	.3018	.2401	.2263	.2401	.2263	.218	.3086
20	.2641	.2743	.2641	.2572	.3395	.285	.3086
21	.2641	.2572	.2263	.2229	.2641	.3018	.3258
22	.2263	.2229	.2263	.2743	.2641	.3018	.3429
23	.1886	.2058	.2263	.1886	.2263	.3018	.3258
24	.3601	.3772	.4115	.3772	.3772	.415	.2347
Max	.8059	1.1317	.9945	1.5089	1.4918	1.8861	.6687
Min	.0838	.0857	.1029	.0686	.0686	.0686	.1543
Avg	.3181	.3681	.3591	.3972	.4017	.4838	.3546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 203 / 11 KV T. V. Centre  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167	.6344	.7545	.703	.7545	.8488
2	.7545	.7167	.6344	.7545	.703	.7545	.823
3	.823	.7167	.6859	.7545	.7545	.7545	.823
4	.823	.7167	.7545	.8299	.8573	.7922	.9054
5	.8745	.7545	.823	.9054	.9602	.7922	.9145
6	.8745	.9431	.8916	1.0185	1.1145	1.0185	.9997
7	.9602	.9431	.9774	1.1317	1.2517	1.0562	1.0059
8	.9774	.9431	.9431	1.1317	1.2346	1.1317	.9511
9	.9088	.9431	.8916	1.094	.9945	1.0562	.9145
10	.8596	.7888	.8573	.9602	.8059	.8573	.823
11	.788	.7888	.823	.7716	.7545	.7545	.7888
12	.8413	.7888	.8402	.9945	.7716	.7202	.8573
13	.8048	.8059	.823	.7888	.7373	.7716	.823
14	.7865	.703	.7373	.7888	.7202	.8573	.8059
15	.7356	.7373	.7888	.7716	.7373	.7716	.823
16	.7682	.7202	.8059	.8402	.7545	.8676	.823
17	.7545	.7202	.8676	.8573	.8299	.7865	.7373
18	.8299	.7545	.9431	.8059	.8676	.8299	.7716
19	1.1317	1.0631	1.1317	1.0631	1.0185	1.0608	1.0802
20	1.1317	1.0974	1.2449	1.0802	1.2449	1.1157	1.0631
21	1.0185	.9945	1.1317	1.0288	1.1317	1.0242	1.0288
22	.9431	.9088	1.0562	.9602	1.0562	1.0059	.9431
23	.8299	.7888	.9431	.8573	.9431	.8962	.8745
24	.7545	.7545	.6344	.8299	.703	.8676	.8488
Max	1.1317	1.0974	1.2449	1.1317	1.2517	1.1317	1.0802
Min	.7356	.703	.6344	.7545	.703	.7202	.7373
Avg	.8637	.8253	.8693	.9072	.9021	.8874	.8866



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 204 / 11KV ELLORA MANDIR  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.415	.4287	.4527	.4115	.4527	.4755
2	.4287	.415	.4287	.4527	.4115	.4527	.4755
3	.4287	.4527	.5144	.4904	.4115	.4904	.4755
4	.5144	.5281	.5487	.4904	.4801	.4904	.567
5	.6173	.6413	.6516	.6413	.6173	.6413	.695
6	.823	.9054	.8059	.8299	.8745	.8299	.823
7	.8573	.9431	.8402	.8299	.7373	.9054	.8596
8	.7373	.3018	.2743	.7922	.8059	.8676	.8779
9	.4458	.7545	.2401	.9054	.6344	.7545	.8413
10	.695	.703	.6173	.6859	.4973	.3429	.5316
11	.5121	.583	.6344	.583	.5487	.4458	.4287
12	.4904	.3944	.6344	.463	.6344	.3772	.3772
13	.4755	.3429	.3601	.3772	.3258	.4287	.3429
14	.5121	.463	.4801	.3258	.4973	.5316	.2915
15	.439	.4287	.3584	.3601	.5487	.5144	.3258
16	.6767	.4973	.6036	.5316	.5487	.4755	.463
17	.7545	.4458	.6413	.6687	.7922	.439	.583
18	.679	.5487	.7545	.7373	.8299	.5853	.6344
19	.7545	.7373	.7545	.7202	.7545	.7133	.6859
20	.679	.6344	.679	.6344	.8299	.5935	.6001
21	.6413	.5658	.6036	.6001	.679	.6036	.5316
22	.5658	.5144	.5658	.5316	.6036	.5658	.5144
23	.4904	.4458	.4904	.4458	.5281	.4904	.4458
24	.4287	.4527	.4287	.9671	.4115	.4458	.4755
Max	.8573	.9431	.8402	.9671	.8745	.9054	.8779
Min	.4287	.3018	.2401	.3258	.3258	.3429	.2915
Avg	.5865	.5464	.5558	.6049	.6006	.5599	.5551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 205 / 11 KV KASABKHEDA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2263	.1886	.2263	.2058	.2263	.1677
2	.2229	.2263	.1886	.2263	.2058	.2263	.1677
3	.2401	.2641	.1886	.2641	.2058	.2641	.2012
4	.2743	.2641	.2401	.2641	.2401	.2641	.2012
5	.3086	.3018	.2743	.3395	.3086	.3395	.3185
6	.3601	.3772	.3429	.415	.3772	.3772	.4191
7	.3944	.4527	.3601	.3772	.3944	.415	.4938
8	.3772	.3772	.3086	.3772	.3258	.3772	.57
9	.3086	.3018	.2058	.3018	.2572	.3018	.6203
10	.6371	.463	.5487	.5144	.5487	.6001	.1715
11	.5853	.4458	.5316	.6516	.7373	.7373	.1372
12	.6161	.5144	.4973	.6516	.7202	.7545	.12
13	.6371	.4287	.5144	.6173	.6516	.7888	.1543
14	.5658	.3429	.4801	.5144	.5487	.7545	.12
15	.5533	.4115	.4904	.6687	.6001	.6001	.1372
16	.503	.3944	.5847	.6859	.6344	.5197	.1372
17	.4527	.5144	.7545	.703	.679	.503	.1543
18	.2641	.1715	.1886	.1715	.2263	.2012	.2058
19	.3018	.3086	.2641	.3086	.2641	.2515	.2915
20	.3018	.2743	.3395	.2743	.2641	.2347	.2572
21	.2641	.2229	.3018	.2572	.3018	.2012	.2058
22	.2263	.2229	.2641	.2401	.2641	.1781	.1886
23	.2263	.2058	.2263	.2229	.2641	.1509	.1715
24	.2229	.2263	.1886	.2263	.2058	.2263	.1677
Max	.6371	.5144	.7545	.703	.7373	.7888	.6203
Min	.2229	.1715	.1886	.1715	.2058	.1509	.12
Avg	.3778	.3308	.3530	.3958	.3930	.3956	.2408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 206 / 11 KV PALASWADI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1509	.12	.1509	.12	.1509	.1677
2	.12	.1509	.12	.1509	.12	.1509	.1677
3	.12	.1509	.1372	.1886	.12	.1886	.1677
4	.1372	.1886	.1715	.1886	.1372	.1886	.2012
5	.1715	.1886	.1886	.2263	.1715	.2263	.2347
6	.2058	.2263	.1886	.2641	.2058	.2641	.285
7	.2229	.3018	.2401	.3395	.3086	.3018	.285
8	.1886	.3395	.2743	.4527	.2915	.3018	.218
9	.2229	.3395	.2915	.415	.3258	.5658	.12
10	.1006	.1715	.12	.1372	.1372	.1029	.12
11	.0943	.0857	.0857	.1029	.12	.1029	.1543
12	.0754	.1029	.12	.0857	.0857	.0857	.1543
13	.1097	.1029	.0686	.0857	.0857	.1029	.1886
14	.0671	.1029	.0857	.0857	.0857	.0857	.2058
15	.0838	.0857	.0943	.0857	.0857	.0857	.12
16	.1174	.1029	.0943	.12	.1029	.0838	.2058
17	.1132	.0857	.1132	.1029	.0754	.1006	.1886
18	.1886	.0857	.1509	.12	.1886	.1494	.1372
19	.2263	.2229	.1886	.2058	.1886	.2012	.2229
20	.2263	.2058	.2641	.2058	.1886	.218	.2058
21	.1886	.2058	.2263	.2058	.2263	.2012	.2058
22	.1886	.1886	.2263	.1886	.2263	.2012	.2229
23	.1886	.1715	.2263	.1886	.2263	.2054	.2058
24	.12	.1509	.12	.1509	.12	.1509	.1677
Max	.2263	.3395	.2915	.4527	.3258	.5658	.285
Min	.0671	.0857	.0686	.0857	.0754	.0838	.12
Avg	.1499	.1712	.1632	.1853	.1643	.1840	.1897

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 207 / 11KV MTDC(EXPRESS)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0343	.0377	.0343	.0377	.0366
2	.0343	.0377	.0343	.0377	.0343	.0377	.0366
3	.0343	.0377	.0343	.0377	.0343	.0377	.0366
4	.0343	.0377	.0343	.0343	.0171	.0377	.0377
5	.0343	.0377	.0343	.0377	.0171	.0377	.0377
6	.0343	.0377	.0343	.0377	.0171	.0377	.0183
7	.0343	.0377	.0171	.0377	.0171	.0377	.0183
8	.0343	.0377	.0171	.0377	.0686	.0377	
9	.0171	.0377	.0171	.0377		.0377	.0189
10		.0343	.0343	.0343	.1372	.0343	.0343
11	.0189	.1886	.2572	.0343	.2572	.0343	.0343
12	.0183	.1886	.2058	.0343	.2915	.0343	.0343
13	.0183	.1886	.2058	.2058	.2058	.0171	.1372
14	.0183	.0857	.0343	.2229	.1715	.0343	.2058
15	.0183	.0171	.0171	.2229	.12	.0343	.2058
16	.0189	.0171	.0343	.1886	.1715	.0189	.0343
17	.0377	.0171	.0377	.0171	.0377	.0189	.0343
18	.0377	.0171	.0377	.0171	.0377	.0189	.0343
19	.0377	.0514	.0377	.0171	.0377	.0366	.0343
20	.0377	.0343	.0377	.0343	.0377	.0366	.0343
21	.0377	.0514	.0377	.0514	.0377	.0366	.0343
22	.0377	.0514	.0377	.0343	.0377	.0366	.0343
23	.0377	.0343	.0377	.0343	.0377	.0366	.0343
24	.0343	.0377	.0343	.0377	.0343	.0377	.0366
Max	.0377	.1886	.2572	.2229	.2915	.0377	.2058
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0183
Avg	.0305	.0572	.0560	.0634	.0823	.0336	.0523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 208 / 11KV CAVES

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0754	.0343	.0377	.0514	.0377	.0335
2	.0514	.0754	.0343	.0377	.0514	.0377	.0335
3	.0514	.0754	.0343	.0377	.0514	.0377	.0335
4	.0514	.0754	.0343	.0377	.0514	.0377	.0335
5	.0514	.0754	.0343	.0377	.0514	.0377	.0503
6	.0514	.0754	.0343	.0377	.0514	.0377	.0503
7	.0514	.0754	.0514	.0377	.0343	.0754	.0503
8	.0343	.0754	.0343	.0377	.0686	.0754	.0671
9	.0514	.0754	.0343	.0377	.0514	.0754	.0503
10	.0335	.0514		.0686	.0343	.0686	.0514
11	.0335	.0514	.0514	.0514	.0514	.0686	.0514
12	.0503	.2058	.0514	.0514	.0514	.0686	.0514
13	.0503	.0514	.0514	.0343	.0514	.0686	.0514
14	.0503	.0514	.0343	.0343	.0514	.0686	.0514
15	.0335	.0343	.0514	.0514	.0514	.0514	.0514
16	.0503	.0514	.0532	.0686	.0514	.0671	.0514
17	.0754	.0343	.0754	.0514	.0754	.0671	.0514
18	.0754		.0754	.0514	.0754	.0503	.0686
19	.0754	.0514	.0754	.0686	.0754	.0671	.0686
20	.0754	.0514	.0754	.0686	.0754	.0503	.0686
21	.0754	.0343	.0754	.0514	.0754	.0503	
22	.0754	.0343	.0754	.0686	.0754	.0503	.0686
23	.0377	.0343	.0754	.0514	.0754	.0503	.0686
24	.0514	.0754	.0343	.0377	.0514	.0377	.0335
Max	.0754	.2058	.0754	.0686	.0754	.0754	.0686
Min	.0335	.0343	.0343	.0343	.0343	.0377	.0335
Avg	.0537	.0648	.0513	.0479	.0577	.0557	.0517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044017 / 33/11KV ELLORA

Feeder No / Name : 209 / 11kv kagzipura

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1886	.2263	.1886	.2263	.2195
2	.1886	.1886	.1886	.2263	.1886	.2263	.2195
3	.2058	.2263	.2058	.2641	.1886	.2641	.2195
4	.2743	.2641	.2743	.2641	.2401	.2641	.2561
5	.3601	.3395	.3772	.3395	.3086	.3395	.3584
6	.4801	.5281	.4973	.4904	.463	.4527	.4572
7	.4801	.5658	.3601	.5281	.3944	.5658	.4755
8	.4287	.5281	.4287	.4527	.2915	.5281	.3772
9	.3772	.3772	.3601	.415	.3601	.415	.3584
10	.3109	.2743	.2743	.2915	.2743	.3086	.2572
11	.2743	.2572	.2743	.2058	.2058	.2229	.2058
12	.2195	.1886	.2229	.2401	.1715	.3429	.2401
13	.2012	.1886	.1715	.2401	.1715	.2229	.1543
14	.1646	.1543	.1715	.2058	.1715	.1886	.1886
15	.1886	.1543	.1543	.2229	.1715	.2058	.1886
16	.2012	.1886	.1715	.3258	.1886	.2743	.1886
17	.2641	.2058	.2263	.2229	.2263	.2743	.2229
18	.3395	.2401	.2641	.2743	.3018	.3292	.2743
19	.3772	.3601	.3395	.3601	.3772	.4024	.3944
20	.3395	.3258	.3772	.3429	.3772	.3658	.3429
21	.2641	.2572	.3018	.2572	.3395	.3109	.2058
22	.2263	.2058	.2641	.2572	.3018	.2743	.2572
23	.2263	.2058	.2263	.2058	.2641	.2263	.2229
24	.1886	.1886	.1886	.2263	.1886	.2263	.2263
Max	.4801	.5658	.4973	.5281	.463	.5658	.4755
Min	.1646	.1543	.1543	.2058	.1715	.1886	.1543
Avg	.2821	.2751	.2712	.2952	.2648	.3107	.2713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 201 / 11KV BAZAR SAWANGI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.2096	.2286	.2286	.2858	.2286
2		.2477	.1905	.2286	.3048	.3429	.2286
3		.2667	.362	.2667	.381	.4001	.2286
4		.2667	.4001	.2858	.4572	.4954	.2667
5		.5716	.4763	.4763	.5716	.5906	.3429
6		.6478	.5525	.4763	.6668	.8002	.6097
7		.6478	.6097	.6478	.7621	.9335	
8		.6668	.6859	.7049	.9526	1.105	
9	.6097	.6668	.4763	.6478	.8383	.6859	
10	.2477						.4954
11							.7811
12							.9907
13							1.0288
14							1.086
15							1.1812
16							1.2574
17							1.3336
19	.4382					.2286	.2096
20	.3429	.4191	.4251	.4191	.4191	.4572	.2858
21	.2858	.4001	.2858	.2667	.3429	.381	.3239
22	.2286	.3239	.2096	.2096	.2667	.3048	.2858
23	.1905	.2096	.1524	.1524	.1715	.2286	.2286
24		.1715	.2096	.2286	.1334	.2477	.2096
Max	.6097	.6668	.6859	.7049	.9526	1.105	1.3336
Min	.1905	.1715	.1524	.1524	.1334	.2286	.2096
Avg	.3348	.4096	.3747	.3742	.4640	.4992	.5801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 202 / 11 KV. Bodkha AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1334	.1524	.1905	.1143	.2286
2	.1524	.1715	.1143	.2286	.1905	.1334	.2286
3	.1524	.1715	.1334	.1524	.2286	.1715	.2667
4	.1905	.1905	.1715	.1334	.2286	.2096	.3429
5	.1905	.2667	.2286	.2667	.2667	.2286	.3429
6	.2096	.2667	.2858	.3429	.2667	.2477	.362
7							.4191
8					.2667		
9							.3429
10	.2477		.2858	.1905	.362	.4954	
11	.3048	.3174	.3048	.3048	.5716	.5716	
12	.2452	.2614	.3239	.362	.5906	.6287	
13	.3696	.2987	.3429	.2667	.6097	.6478	
14	.6468	.2801	.2477	.4191	.5716	.6668	
15	.462	.3048	.2957	.4763	.5335	.6097	
16	.3174	.2667	.3048	.381	.6097	.5716	
17	.1905	.2286	.2858	.3429	.5525	.4763	
19	.1905					.2667	.2286
20	.1905	.2286	.2427	.2286	.2477	.3429	.2667
21	.1524	.2667	.2096	.1905	.2286	.3048	.2858
22	.1524	.2096	.2096	.1524	.1715	.2667	.2667
23	.1334	.1524	.1524	.1715	.1524	.2477	.2477
24	.1334	.1524	.1524	.1524	.1715	.1334	.2286
Max	.6468	.3174	.3429	.4763	.6097	.6668	.4191
Min	.1334	.1524	.1143	.1334	.1524	.1143	.2286
Avg	.2392	.2337	.2329	.2587	.3506	.3668	.2898



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 203 / 11 KV. KANATGAON. AG. SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2096	.2667	.0953	.2286	.2286	.3048
2	.2667	.2096	.2477	.2858	.1905	.2096	.3048
3	.2286	.1905	.2286	.2858	.1905	.2286	.3048
4	.2286	.1905	.2858	.2667	.2286	.2477	.3048
5	.2286	.1905	.2858	.2286	.2667	.2477	.4191
6	.2286	.1905	.3048		.3048		.5716
7							.724
8							.7621
9							.9526
10	.5525		.6478	.4572	.8383	.7621	
11	.5716	.5415	.6287	.8002		.9526	
12	.5228	.5228	.6287	.6478		1.105	
13	.5544	.5601	.5716	.6668	.6097	.7621	
14	.5175	.5041	.5716	.6287	.9145		
15	.5041	.5335	.4294	.6668	1.0098		
16	.4435	.4954	.4191	.5716	.9145		
17	.4001		.4572	.5144	.9145	.381	
18		.4763					
19	.3048					.1143	.1905
20	.2667	.3429	.3696	.3239	.362	.1524	.2286
21	.2477	.3239	.3429	.2477	.2667	.1524	.2286
22	.2477	.2858	.2667	.2286	.2286	.1905	.1905
23	.2286	.2477	.2667	.2286	.2477	.1905	.1715
24	.2667	.2096	.2477	.2286	.2286	.2477	.3048
Max	.5716	.5601	.6478	.8002	1.0098	1.105	.9526
Min	.2286	.1905	.2286	.0953	.1905	.1143	.1715
Avg	.3538	.3458	.3930	.4096	.4673	.3858	.3975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 204 / 11KV YESGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.2858	.2286	.1143	.3429	.4382	.0762
2	.0762	.2858	.2477	.0953	.381	.4763	.0762
3	.0762	.3048	.2477	.0953	.4572	.5525	.0762
4	.0762	.3048	.2667	.1524	.5335	.6287	.0762
5	.0762	.3429	.3239	.1524	.6097	.6859	.0762
6	.0762	.3429	.4382	.2286	.6859	.7621	.0762
7	.0762	.3429	.5144	.5144	.7621	.8002	
8	.362	.4001	.5144		.9145	1.0669	
9	.4191	.4572	.6478	.6859	.9526	1.0669	
10							.5335
11							.6859
12							.7621
13							.724
14			.5716				.6859
15							.6478
16							.6097
17							.5716
19	.1143					.0762	.0572
20	.0762	.1143	.0943	.0762	.0762	.0762	.0572
21	.0572	.0953	.0762	.1143	.0953	.0762	.0762
22	.0381	.0762	.0762	.0572	.0762	.0762	.0572
23	.0381	.0572	.0762	.0762	.0762	.0762	.0572
24	.1143	.2667	.2477	.1143	.3429	.4191	.0762
Max	.4191	.4572	.6478	.6859	.9526	1.0669	.7621
Min	.0381	.0572	.0762	.0572	.0762	.0762	.0572
Avg	.1194	.2626	.3048	.1905	.4504	.4852	.3029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 205 / 11KV TAJNAPUR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1715	.2096	.1905	.3239	.1524
2	.2286	.2096	.1905	.2096	.2667	.362	.2096
3	.2667	.2286	.2286	.2286	.3429	.4001	.2096
4	.3048	.3429	.2286	.3429	.3429	.5335	.2286
5	.3429	.3429	.2667	.4191	.381	.6097	.381
6	.381	.381	.362	.4572	.381	.7049	
7	.4382	.381	.4763	.4954	.381	.724	
8	.4572	.5716	.4954	.4954	.5716	.8002	
9	.4763	.5716	.4954	.1715	.7049	.4572	
10							.5716
11							.6859
12							.7621
13							.7811
14							.8192
15							.8002
16							.8192
17							.8764
19	.381					.2096	.1715
20	.2858	.3429	.3326	.3048	.4382		.2477
21	.2667	.3239	.2858	.1715	.3048	.2286	.2477
22	.2667	.2477	.2096	.1905	.2477	.2667	.2667
23	.2477	.2096	.1524	.1334	.1905	.3048	.2858
24	.1715	.1334	.1715	.2096	.1334	.2858	.2096
Max	.4763	.5716	.4954	.4954	.7049	.8002	.8764
Min	.1715	.1334	.1524	.1334	.1334	.2096	.1524
Avg	.3137	.3198	.2905	.2885	.3484	.4436	.4593

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 206 / 11KV Yesgaon Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.2858	.3048	.3048	.2858	.2858
2	.3429	.3048	.2667	.3048	.381	.2858	.2858
3	.381	.381	.3048	.3048	.4572	.3048	.2858
4	.4572	.5716	.362	.3048	.5716	.3429	.2667
5	.5716	.9526	.4572	.5716	.6859	.5335	.7621
6	.8002	1.0669	.6859	1.0479	.8573	.8002	1.0479
7	1.0288	1.0669	.9335	1.0288	1.105	.9907	.9717
8	.8954	.9526	.7049		.9145	.8192	.8383
9	.7811	.7621	.743	.6859	.7811	.724	.6859
10	.5716		.5144	.5335	.4191	.5335	.5525
11	.4001	.3395	.381	.4191	.2858	.4191	.4001
12	.2987	.3174	.2667	.3048	.2477	.381	.3239
13	.2801	.2801	.2477	.3429	.2286	.2667	.2858
14	.1867	.2241	.1524	.3429	.2477	.2286	.3048
15	.2263	.2667	.1867	.1905	.2286	.2286	.2667
16	.1867	.2477	.2286	.2286	.2667	.2858	.2667
17	.2858	.2286	.2477	.2858	.2858	.3429	.2858
18	.4763	.3239	.3326	.5525	.3429	.4191	.381
19	.6668	.5144	.462	.8192	.5716	.5144	.5906
20	.5716	.5906	.6697	.6859	.6668	.6668	.6478
21	.4191	.5716	.6097	.5335	.5525	.5716	.4954
22	.3429	.4001	.3429	.362	.381	.381	.3429
23	.2858	.2858	.2858	.3429	.3429	.3048	.3048
24	.2667	.2667	.2858	.8192	.3048	.3048	.2858
Max	1.0288	1.0669	.9335	1.0479	1.105	.9907	1.0479
Min	.1867	.2241	.1524	.1905	.2286	.2286	.2667
Avg	.4595	.4862	.4149	.4920	.4763	.4557	.4652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 207 / 11KV VIKAS GINNING EXP SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0191	.0381	.0381	.0381	.0381	.0381
5	.0381	.0191	.0381	.0381	.0381	.0381	.0381
6	.0381	.0191	.0381	.0381	.0381	.0572	.0381
7	.0381	.0191	.0381	.0381	.0381	.0191	.0381
8	.0381	.0191	.0381	.0381	.0191	.0381	.0381
9	.0381	.0191	.0381	.0381	.0381	.0381	.0381
10	.0381		.0381	.0381	.0381	.0572	.0381
11	.0381	.0377	.0381	.0381	.0381	.0381	.0381
12	.0377	.0377	.0381		.0381	.0381	.0381
13	.0377	.0377	.0381	.0381	.0381	.0381	.0381
14	.0377	.0377	.0381	.0381	.0381	.0381	.0381
15	.0377	.0381	.0377	.0381	.0381	.0381	.0381
16	.0377	.0381	.0381	.0381	.0572	.0381	.0381
17	.0381	.0381	.0381	.0381	.0762	.0381	.0381
18	.0381	.0381	.0377	.0381	.0381	.0381	.0381
19	.0381	.0381	.0377	.0381	.0381	.0381	.0381
20	.0381	.0381	.0377	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	.0381	.0381	.0381	.0381	.0762	.0572	.0381
Min	.0377	.0191	.0377	.0381	.0191	.0191	.0381
Avg	.0380	.0331	.0380	.0381	.0397	.0389	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 208 / Bodhaka Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.2286	.1524	.3048	.2477	.2858
2	.3429	.2858	.2096	.1524	.3048	.2667	.2667
3	.381	.2858	.2286	.1524	.3429	.2858	.2667
4	.4572	.4763	.2667	.2667	.3429	.362	.3429
5	.5716	.6668	.4954	.3429	.381	.5335	.4191
6	.6859	.8764	.7049	.8002	.5716	.6859	.7621
7	.9145	.8573	.7811	.8573	.8573	.8954	.724
8	.743	.4763	.6478	.7621	.724	.724	.6097
9	.6478		.5144	.5906	.5906	.6097	
10	.4191		.3048	.4954	.362	.4001	.381
11	.2667	.2452	.2286	.2858	.1905	.3048	.2477
12	.1494	.1698		.2286	.2096	.2096	.2096
13	.1698	.1509	.1334	.2096	.1715	.2096	.1905
14	.132	.1886	.1524	.2096	.1524	.2286	.1905
15	.1509	.1715	.1886	.2286	.1905	.2096	.2667
16	.1867	.1905	.2096	.1905	.2096	.1905	.2667
17	.2667	.1905	.2477	.2096	.1905	.3429	.2667
18	.381	.2858	.2801	.4001	.381	.4191	.3429
19	.6478	.4001	.462	.6668	.4763	.5335	.4382
20	.381	.5144	.6283	.6097	.6859	.6287	.5716
21	.3429	.4572	.4191	.4382	.5716	.5716	.4763
22	.2858	.3239	.3429	.362	.4001	.381	.3429
23	.2477	.2667	.2858	.2667	.2858	.2858	.3048
24	.2477	.2477	.2477	.1524	.2858	.2667	.2858
Max	.9145	.8764	.7811	.8573	.8573	.8954	.7621
Min	.132	.1509	.1334	.1524	.1524	.1905	.1905
Avg	.3885	.3642	.3569	.3763	.3826	.4080	.3678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044020 / 33/11KV BAZAR SAWANGI

Feeder No / Name : 209 / 11 kv BAZARSAWANGI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1334	.1143	.1143	.1143	.1143
2	.2667	.1524	.1143	.1143	.1524	.0953	.1143
3	.3048	.1715	.1524	.1143	.1905	.1143	.0953
4	.3429	.1905	.1905	.1905	.2286	.1524	.1524
5	.381	.3048	.2477	.1524	.2667	.2096	.3429
6	.4572	.3429	.2858	.4572	.3429	.3048	.4191
7		.3239	.3429	.381	.4001	.362	.4001
8	.3239	.2858	.3239	.3239	.3429	.3048	.3239
9	.3239	.2477	.2096	.2667	.2477	.2477	.2667
10	.1905		.1334	.1905	.1524	.1524	.1334
11	.1334	.1509	.1334	.1334	.1143	.1143	.0953
12	.0943	.132	.1334		.1334	.0953	.0953
13	.1132	.0943	.0762	.0953	.1334	.0953	.0953
14	.132	.0754	.1143	.0953	.1524	.0953	.0953
15	.132	.1143	.132	.1143	.1143	.0953	.1143
16	.132	.1524	.0953	.1143	.1143	.0762	.1143
17	.1334	.1715	.1334	.1143	.1334	.0762	.0953
18	.2286	.1905	.2241	.1524	.2096	.1143	.1905
19	.3239	.2667	.2801	.2858	.3429	.1143	.2477
20	.2667	.3239	.3696	.3239	.381	.362	.2858
21	.2286	.2858	.2096	.2477	.3048	.2286	.2858
22	.1524	.1715	.2096	.1905	.2286	.2096	.1524
23	.1334	.1334	.1524	.1143	.1334	.1524	.1524
24	.1334	.1334	.1334	.0953	.1143	.1334	.1143
Max	.4572	.3429	.3696	.4572	.4001	.362	.4191
Min	.0943	.0754	.0762	.0953	.1143	.0762	.0953
Avg	.2226	.1986	.1888	.1905	.2104	.1675	.1874

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 201 / 11 KV Bhadji AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0549
2							.0549
3							.0549
4							.0543
5							.0532
6							.0549
7							.0876
8							.1928
9							.1829
10	.1334	.1463	.1029	.1715	.2743	.2572	
11	.1524	.1254	.1372	.2096	.3086	.2743	
12	.1524	.1463	.156	.2096	.3429	.3086	
13	.1715	.128	.1387	.2286	.3429	.2915	
14	.1143	.124	.1715	.2667	.3601	.3086	
15	.1143	.124	.2229	.2477	.3601	.2915	
16	.0762	.1543	.1578	.2667	.3155	.1097	
17	.1097	.2058	.1928	.2667	.3366	.0905	
24							.0297
Max	.1715	.2058	.2229	.2667	.3601	.3086	.1928
Min	.0762	.124	.1029	.1715	.2743	.0905	.0297
Avg	.1280	.1443	.1600	.2334	.3301	.2415	.0820



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 202 / 11KV GADANA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2926	.2429	.2458	.3239	.2883	.2477
2	.3048	.2926	.2429	.2622	.3429	.3086	.2667
3	.3429	.3142	.2949	.2622	.4382	.3467	.2858
4	.4001	.3292	.3441	.2622	.4382	.3988	.3048
5	.4572	.3898	.3887	.3605	.5335	.4908	.3048
6	.5144	.4458	.4973	.4424	.6097	.6415	.362
7	.5335	.5079	.5801	.639	.8954	.9259	.2858
8	.7049	.5407	.7459	.7373	1.1622	.9878	.2286
9	.743	.506	.8139	.8223	1.1241	.9804	.1905
10	.1524	.1334	.1143	.0381	.0572	.12	.3944
11	.0953	.0953	.0762	.0953	.0572	.0667	
12	.0953	.0762	.0762	.0953	.0476	.0572	
13	.0762	.0762	.0762	.0953	.0476	.0572	
14	.0762	.0762	.0762	.0953	.0476	.0476	
15	.0953	.0762	.0762	.0953	.0476	.0476	
16	.0953	.0381	.0762	.1143	.0762	.0953	.4954
17	.0953	.0476	.0953	.1143	.0953	.1524	.5335
18	.1334	.0572	.0953	.1143	.1143	.1334	.1143
19	.2096	.0762	.1715	.1905	.1905	.0191	.2096
20	.2096	.0953	.2286	.2286	.2286		.2667
21	.2096	.1048	.1905	.2096	.1905	.2477	.2858
22	.1905	.1886	.1905	.1905	.1905	.2858	.3048
23	.1715	.0953	.1524	.1715	.1524	.2667	
24	.2858	.2378	.2572	.2258	.3048	.2623	.2667
Max	.743	.5407	.8139	.8223	1.1622	.9878	.5335
Min	.0762	.0381	.0762	.0381	.0476	.0191	.1143
Avg	.2699	.2122	.2543	.2545	.3215	.3143	.2971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 203 / 11 KV Bhandegaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1143	.1334	.1143	.2096	.1334	.1772
2	.2096	.1189	.1334	.1238	.2096	.1429	.1772
3	.2096	.1143	.1334	.1334	.2477	.2829	.1829
4	.2477	.1143	.1238	.1334	.2477	.1524	.2454
5	.2667	.1288	.1238	.1429	.2667	.1524	.0543
6	.2858	.1334	.1143	.1429	.2667	.1429	.3681
7	.2286	.1111	.1048	.1048	.2286	.1048	.4207
8	.2096	.0762	.0762	.0762	.1715	.0857	.5138
9	.1524	.0572	.0667	.0572	.1334	.0667	.5434
10	.2858	.3012	.3077	.4954	.5316	.5144	.0476
11	.2667	.3012	.333	.5144	.5316	.5316	.0476
12	.2667	.1189	.3086	.4954	.5487	.5144	
13	.2858	.2126	.2401	.4763	.5658	.5144	
14	.2096	.124	.2321	.4572	.583	.5487	
15	.2477	.0857	.2321	.4191	.6001	.5316	
16	.2286	.1715	.3721	.4382	.4334	.4252	.0572
17	.1949	.2058	.3294	.4382	.4681	.3155	.0572
18	.0762	.0381	.0476	.0953	.0476	.0476	
19	.096	.0572	.0762	.1524	.0857	.0857	
20	.1111	.0857	.0953	.2096	.0953	.0857	.1524
21	.1429	.1143	.1048	.2286	.1238	.0762	.1334
22	.1238	.1238	.1143	.2667	.1334	.0667	
23	.1238	.1238	.1288	.2667	.1334	.0572	
24	.2477	.1257	.2401	.1143	.2477	.1334	.1772
Max	.2858	.3012	.3721	.5144	.6001	.5487	.5434
Min	.0762	.0381	.0476	.0572	.0476	.0476	.0476
Avg	.2061	.1316	.1738	.2540	.2963	.2380	.2097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 204 / 11KV GADANA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1097	.1109	.1097	.1143	.1132	.128
2	.0953	.1097	.1132	.1109	.1143	.1132	.128
3	.0953	.1109	.1509	.1109	.1524	.1132	.1294
4	.1715	.128	.1698	.128	.1905	.1509	.1294
5	.2286	.1772	.1901	.1848	.2286	.1886	.1829
6	.2858	.2896	.2075	.2353	.2858	.2641	.2561
7	.2858	.2865	.2263	.2481	.2667	.2452	.2454
8	.2286	.2126	.1663	.2126	.2096	.2075	.1791
9	.1715	.1463	.1509	.1829	.1715	.2012	.1478
10	.1143	.1052	.0943	.0953	.0857	.1029	.1029
11	.0572	.0732	.1478	.0572	.0857	.1029	
12	.0381	.0549	.0566	.0762	.0857	.0857	
13	.0381	.0739	.1509	.0953	.0857	1.046	
14	.0572	.0739	.0566	.0953	.0686	.0686	
15	.0572	.0549	.0566	.1143	.0686	.0686	
16	.0762	.0514	.0566	.1143	.0754	.0732	.0762
17	.1109	.0857	.0754	.1143	.0943	.0914	.0762
18	.1478	.1372	.1132	.1143	.1132	.0914	.1143
19	.2378	.1543	.2218	.2477	.2641	.2126	.2286
20	.2378	.1715	.2587	.2477	.2829	.2012	.2477
21	.1848	.1715	.1829	.2096	.1886	.1646	.2096
22	.1463	.1543	.1463	.1715	.1509	.1478	.1715
23	.1524	.1372	.128	.1334	.132	.1463	
24	.1143	.1294	.1029	.1109	.1143	.1132	.128
Max	.2858	.2896	.2587	.2481	.2858	1.046	.2561
Min	.0381	.0514	.0566	.0572	.0686	.0686	.0762
Avg	.1436	.1333	.1389	.1467	.1512	.1797	.1601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 205 / 11 KV Takali R.R.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0754	.0762	.0762	.0754	.1772
2	.0572	.0762	.0754	.0762	.0762	.0754	.1715
3	.0572	.0762	.0754	.0953	.0762	.0943	.1543
4	.0762	.0953	.0754	.0953	.0953	.0943	.1715
5	.0953	.0953	.0943	.1143	.0953	.0943	.2103
6	.1334	.1334	.0943	.1143	.1143	.1132	.2804
7	.1334	.1334	.0943	.1097	.1334	.1132	.4908
8	.0953	.0762	.0754	.0762	.0953	.0943	.5624
9	.0762	.0572	.0566	.0572	.0572	.0762	.6718
10	.2858	.2622	.1957	.4191	.4287	.4973	.0572
11	.3048	.3277	.3048	.6097	.5144	.5144	
12	.3048	.3953	.3963	.6287	.583	.583	
13	.3239	.3441	.4268	.6287	.6516	.6687	
14	.381	.3441	.4064	.6097	.7716	.7202	
15	.381	.3768	.3913	.5906	.7373	.7716	
16	.381	.3944	.2896	.7811	.6554	.6554	.0191
17	.3277	.3772	.381	.8954	.679	.4696	.0191
18	.0566	.0286	.0566	.0572	.0566	.0572	.0191
19	.0953	.0286	.0953	.0762	.0754	.0953	.0572
20	.1143	.0381	.1143	.0953	.0943	.0953	.0762
21	.1143	.0476	.0914	.0953	.0943	.0953	.0762
22	.0953	.0476	.0953	.0953	.0943	.0762	.0572
23	.0762	.0381	.0762	.0953	.0754	.0572	
24	.0762	.0762	.0381	.0762	.0762	.0754	.1753
Max	.381	.3953	.4268	.8954	.7716	.7716	.6718
Min	.0566	.0286	.0381	.0572	.0566	.0572	.0191
Avg	.1716	.1644	.1698	.2737	.2670	.2609	.1915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 206 / 11 KV TAKALI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.1663	.1715	.1905	.2241	.1905
2	.1905	.1715	.2033	.2096	.1715	.2241	.2096
3	.2096	.2096	.2263	.2477	.2286	.2801	.2286
4	.2858	.2667	.2641	.2858	.2858	.3547	.3429
5	.5335	.4382	.3395	.4954	.362	.5041	.5525
6	.724	.6478	.4527	.6478	.4954	.6535	.724
7	.6478	.6287	.6602	.6668	.5144	.7095	.724
8	.5716	.5335	.547	.5716	.5144	.6283	.6478
9	.5144	.381	.415	.5525	.5144	.6097	.5906
10	.362	.2477	.2641	.3048	.2743	.3429	.3944
11	.2286	.2096	.2075	.1334	.2743	.3429	
12	.1905	.1334	.1886	.1334	.2572	.3086	
13	.1524	.1715	.1698	.1524	.2401	.2915	
14	.1334	.1524	.1886	.1715	.2058	.2058	
15	.1334	.1715	.1886	.1715	.1886	.1715	
16	.1715	.2058	.1698	.2096	.2452	.1905	.2286
17	.2667	.2401	.1886	.2858	.3395	.3429	.3048
18	.4191	.3258	.3206	.3048	.4715	.4382	.4001
19	.362	.3258	.4954	.5525	.6413	.5716	.5525
20	.3239	.3601	.4001	.5335	.5658	.5716	.5335
21	.2477	.2915	.3048	.4191	.4338	.4191	.4191
22	.2286	.2572	.2477	.3048	.3395	.2858	.2858
23	.1715	.2058	.1905	.2477	.2401	.2477	
24	.1905	.1715	.1543	.1905	.2096	.2263	.2096
Max	.724	.6478	.6602	.6668	.6413	.7095	.724
Min	.1334	.1334	.1543	.1334	.1715	.1715	.1905
Avg	.3104	.2883	.2897	.3318	.3418	.3810	.4188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 207 / 11 KV Viramgaon AG.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1715	.1635	.1844	.1905	.1865	.3048
2	.2858	.2058	.1781	.213	.2096	.2229	.3239
3	.3429	.218	.2321	.2591	.2477	.2572	.362
4	.381	.2294	.2984	.2688	.3429	.2743	.4001
5	.4382	.3605	.3978	.3953	.4954	.3294	.4191
6	.4954	.4475	.4424	.4531	.6097	.5375	.3048
7	.5335	.5365	.4784	.5468	.724	.7202	.2858
8	.5906	.506	.5967	.68	.8573	.8907	.2286
9	.6668	.427	.5304	.7186	.9145	.933	.1524
10	.1524	.1143		.1143	.0572	.1372	.6001
11	.1524	.0762	.0754	.0762	.0857	.0572	
12	.0953	.0762	.0754	.0762	.0476	.0572	
13	.0572	.0953		.0572	.0476	.0476	
14	.0572	.1143	.0754	.0572	.0686	.0476	
15	.0572	.0953	.0754	.0572	.0381	.0381	
16	.0762	.0476	.0754	.0762	.0754	.0762	.5335
17	.0953	.0381	.0754	.0762	.0754	.1334	.5906
18	.1524	.0476	.1132	.0953	.0754	.1524	.1143
19	.2096	.0572	.2286	.1905	.1509	.2477	.2286
20	.1905	.1372	.1905	.2286	.1886	.2667	.2477
21	.1715	.1543	.1524	.1905	.1509	.3429	.2667
22	.1524	.0857	.1524	.1524	.1509	.381	.3048
23	.1334	.0762	.0953	.1334	.132	.3429	
24	.2286	.2096	.1715	.1886	.1905	.1355	.3429
Max	.6668	.5365	.5967	.7186	.9145	.933	.6001
Min	.0572	.0381	.0754	.0572	.0381	.0381	.1143
Avg	.2485	.1886	.2216	.2287	.2553	.2840	.3339

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 208 / 11KV NAKODA GINNING  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0122	.013	.0122	.0381	.0133	.0122
2	.0381	.0122	.013	.0122	.0381	.0133	.0122
3	.0381	.0122	.013	.0114	.0381	.0133	.0122
4	.0381	.0122	.0126	.0122	.0381	.0133	.0122
5	.0381	.0122	.0126	.0122	.0381	.0133	.0122
6	.0381	.0122	.0126	.0122	.0381	.0126	.0122
7	.0381	.0122	.013	.0137	.0381	.013	.0122
8	.0381	.0122	.0377	.0122	.0381	.0133	.0122
9	.0381	.0122	.0126	.0122	.0381	.0038	.0122
10	.0381	.0122	.013	.0381	.0038	.0038	.0038
11	.0381	.0114	.0126	.0381	.0038	.0038	
12	.0381	.0122	.0133	.0381	.0038	.0038	
13	.0381	.0122	.0133	.0381	.0038	.0038	
14	.0381	.0122	.0133	.0381	.0038	.0038	
15	.0381	.0122	.013	.0381	.0038	.0038	
16	.0381	.0038	.013	.0381	.0133	.0122	.0381
17	.0114	.0038	.0141	.0381	.0133	.0122	.0381
18	.0122	.0038	.0133	.0381	.0133	.0122	.0381
19	.0122	.0171	.0122	.0381	.0133	.0122	.0381
20	.0122	.0038	.0122		.0133	.0122	.0381
21	.0122	.0038	.0122	.0381	.0126	.0122	.0381
22	.0122	.0038	.0122	.0381	.0377	.0122	.0381
23	.0122	.0038	.0122	.0381	.013	.0122	
24	.0381	.0122	.0038	.0122	.0381	.013	.0122
Max	.0381	.0171	.0377	.0381	.0381	.0133	.0381
Min	.0114	.0038	.0038	.0114	.0038	.0038	.0038
Avg	.0305	.0099	.0135	.0269	.0222	.0101	.0218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 209 / 11KV LODHA STONE CRUSHER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0189	.0189	.0191	.0189	.0189
2	.0191		.0189	.0189	.0191	.0189	.0189
3	.0191		.0189	.0189	.0191	.0189	.0189
4	.0191	.0189	.0189	.0189	.0191	.0189	.0189
5	.0191	.0189	.0189	.0189	.0191	.0189	.0189
6	.0191	.0189	.0189	.0189	.0191	.0189	.0189
7	.0191	.0189	.0189	.0189	.0191	.0189	.0189
8	.0191	.0183	.0189	.0189	.0191	.0189	.0189
9	.0191	.0189	.0189	.0061	.0191	.0189	.0061
10	.0191	.0189	.0189	.0191	.0171	.0171	.0171
11	.0191	.0189	.0189	.0191	.0171	.0171	
12	.0191	.0189	.0189	.0191	.0171	.0171	
13	.0191	.0189	.0189	.0191	.0171	.0171	
14	.0191	.0189	.0189	.0191	.0171	.0171	
15	.0191	.0189	.0189	.0191	.0171	.0171	
16	.0191	.0171	.0189	.0191	.0189	.0189	.0953
17	.0189	.0171	.0189	.0191	.0189	.0189	.0953
18	.0189	.0171	.0189	.0191	.0189	.0189	.0191
19	.0189	.0171	.0189	.0191	.0189	.0061	.0191
20	.0189	.0171	.0189	.0191	.0189	.0189	.0191
21		.0171	.0189	.0191	.0189	.0189	.0191
22	.0189	.0171	.0189	.0191	.0189	.0189	.0191
23	.0189	.0171	.0189		.0189	.0189	
24	.0191	.0189	.0171	.0189	.0191	.0189	.0189
Max	.0191	.0189	.0189	.0191	.0191	.0189	.0953
Min	.0189	.0171	.0171	.0061	.0171	.0061	.0061
Avg	.0190	.0182	.0188	.0185	.0185	.0179	.0266



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044039 / 33/11KV GADANA

Feeder No / Name : 210 / 11 KV SULTANPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1715	.2075	.1905	.2096	.1886	.1334
2	.2286	.1905	.2829	.1905	.1905	.1886	.1715
3	.2858	.2096	.3395	.2286	.1905	.2829	.1905
4	.4572	.2477	.3961	.2667	.4191	.3395	.3048
5	.6097	.4763	.4715	.4954	.6478	.3961	.4763
6	.8192	.6287	.5658	.5716	.8192	.7468	.6097
7	.8002	.5716	.6602	.6859	.6668	.7655	.5906
8	.7049	.4954	.5658	.5335	.6287	.6224	.4954
9	.5716	.381	.4527	.4191	.4954	.5658	.5144
10	.4191	.2286	.3772	.4001	.3258	.3429	.3086
11	.2477	.2096	.1698	.2858	.3086	.3086	
12	.2477	.1715	.1886	.2477	.2572	.2572	
13	.2477	.1143	.2075	.2286	.2572	.2401	
14	.1715	.1715	.1698	.1905	.2229	.2058	
15	.2096	.1905	.1509	.2096	.2229	.2058	
16	.2286	.1886	.2263	.2286	.2641	.2286	.2667
17	.3048	.2058	.2263	.2858	.2829	.2477	.2477
18	.362	.3086	.3206	.362	.3961	.3239	
19	.5144	.4115	.7049	.6097	.6224	.5335	
20	.4572	.5144	.5335	.5906	.6224	.5144	
21	.381	.4115	.362	.4954	.3961	.362	.4763
22	.2667	.3601	.2858	.381	.3395	.2858	.362
23	.2286	.2915	.2286	.2858	.3018	.2286	
24	.2858	.2096	.1886	.1905	.2477	.2641	.2096
Max	.8192	.6287	.7049	.6859	.8192	.7655	.6097
Min	.1715	.1143	.1509	.1905	.1905	.1886	.1334
Avg	.3874	.3067	.3451	.3572	.3890	.3602	.3572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

KHULATABAD (R) S/D[401] BU 2275

Substation No/ Name :- 044104 / 33/11KV KANADGAON SUBSTATION

Feeder No / Name : 202 / 11KV KANADGAON GAOTHAN FEEDER SEPERATION/PURE AG  
FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0189	.0373	.0377	.0373	.0366	.0373
2	.0373	.0189	.037	.0377	.0373	.037	.037
3	.0373	.0189	.037	.0377	.0373	.037	.037
4	.056	.0189	.037	.0566	.0373	.037	.037
5	.0747	.0754	.0716	.1132	.1307	.0716	.0732
6	.112	.1132	.1063	.132	.1307	.1063	.1063
7	.112	.1132	.0886	.0943	.112	.1214	.1052
8	.112	.0943	.0716	.0943	.0747	.1063	.0886
9	.056	.037	.037	.0566	.0747	.0716	.0566
10	.0189	.0187	.0189	.0187	.0189	.037	.0377
11	.0189	.0187	.0189	.0187	.0189	.0187	.0189
12	.0189	.0187	.0189		.0189	.0187	.0189
13	.0189	.0187	.0189		.0189	.0187	.0189
14	.0189	.0187	.0189		.0189	.0187	.0189
15	.0189	.0187	.0189		.0189	.0187	.0189
16	.0189	.0373	.0189		.0189	.0373	.0189
17	.0189	.0373	.0189	.0187	.0189	.037	.0189
18	.0566	.037	.0377	.0187	.0189	.0549	.0189
19	.0943	.0724	.0754	.112	.1132	.1063	.1132
20	.0943	.1063	.1132	.112	.1132	.1063	.1132
21	.0943	.0543	.0754	.0747	.0754	.0716	.0943
22	.0189	.037	.0566	.0747	.0754	.0549	.0566
23	.0189	.037	.0377	.056	.0724	.037	.0566
24	.0373	.0189	.037	.0377	.0373	.0724	.037
Max	.112	.1132	.1132	.132	.1307	.1214	.1132
Min	.0189	.0187	.0189	.0187	.0189	.0187	.0189
Avg	.0500	.0441	.0462	.0633	.0554	.0555	.0516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 201 / GINNING AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2801	.2801	.2801	.2801	.2801	.3125
2	.2572	.2801	.2801	.2801	.2801	.2772	.3125
3	.2572	.2801	.2743	.2801	.2801	.2743	.3201
4	.3429	.3772	.4668	.3772	.3772	.3734	.4096
5	.4287	.4715	.4668	.4715	.4715	.4668	.5258
6	.5144	.5658	.5658	.5658	.5658	.5658	.7164
7	.5144	.5658	.5658	.5658	.5658	.5658	.763
8	.4668	.4668	.4715	.4715	.4715	.4715	.8097
9	.3734	.3734	.2801	.3772	.3772	.3772	.7621
10	.3277		.5468	.5468	.6097	.8697	.1867
11	.3277	.381	.6249	.7621	.9145	1.0402	.1867
12	.4096	.5201	.703	.8383	1.1717	1.2146	.1867
13	.3201	.5135	.6249	.9145	1.0936	1.0669	.1867
14	.4096	.4687	.6325	.8383	1.0269	.9145	.1848
15	.3334	.4458	.4687	.7621	.9536	.8383	.1829
16	.3048	.423	.6249	.703	.9145	.7621	.1829
17	.3858	.4572	.6859	.8697	.8383	.6249	.1829
18	.2801	.1848	.1848	.1848	.1829	.2743	.1848
19	.3772	.2801	.3734	.3772	.3734	.3734	.3772
20	.3772	.3734	.3772	.3772	.3734	.3734	.3772
21	.2801	.2801	.3734	.2829	.2801	.2801	.3772
22	.2801	.2801	.2801	.2801	.2801	.2801	.2801
23	.2801	.2801	.2801	.2801	.2801	.3125	.2801
24	.2572	.2801	.2772	.0934	.2801	.2801	.3201
Max	.5144	.5658	.703	.9145	1.1717	1.2146	.8097
Min	.2572	.1848	.1848	.0934	.1829	.2743	.1829
Avg	.3485	.3839	.4462	.4908	.5518	.5482	.3587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 202 / 11 KVV- PAL-AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3125	.3201	.4096	.4687	.4001	.2801
2	.3277	.3125	.3201	.4049	.4687	.4096	.2801
3	.3429	.3125	.3201	.4096	.4687	.4687	.2829
4	.4287	.3906	.4096	.5144	.5468	.5601	.3772
5	.4915	.4687	.4915	.6135	.6249	.7545	.4715
6	.6554	.6249	.6097	.8764	.7116	.9326	.5658
7	.8192	.7116	.8859	.9536	1.2003	1.1431	.5658
8	.6097	.9221	.8592	.9221	1.4575	1.4403	.5658
9	.7373	.8907	.8697	1.0669	1.5384	1.4575	.2829
10	.2829	.2829	.2801	.2743	.3772	.3772	.3277
11	.2829	.2801	.1848	.1886	.2829	.2772	.7621
12	.1867	.1867	.1848		.1886	.1829	.8383
13	.1867	.1867	.1848		.1886	.1715	.9145
14		.1886	.1772		.1867	.1715	.9374
15	.1867	.2801	.1848		.1867	.1715	.9374
16	.1829	.1867	.1848		.1867	.1867	1.0402
17	.1867	.1829	.1886	.1829	.1886	.1867	1.0402
18	.2801	.2772	.1867	.1848	.2829	.2801	.1829
19	.4715	.3772	.2801	.2829	.3772	.3734	.3772
20	.4715	.3772	.4715	.4715	.4715	.3772	.4715
21	.3772	.3772	.3772	.3772	.3772	.3772	.3772
22	.2829	.2829	.3734	.3772	.2829	.3772	.2801
23	.2801	.2829	.2829	.2801	.2829	.2829	.2801
24	.3163	.3125	.3201	.4144	.3906	.4001	.2801
Max	.8192	.9221	.8859	1.0669	1.5384	1.4575	1.0402
Min	.1829	.1829	.1772	.1829	.1867	.1715	.1829
Avg	.3789	.3753	.3728	.4845	.4890	.4900	.5300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 203 / 11KV PHULAMBRI GAONTHAN SHEDDABLE URBAN

FEEDER Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5373	.5373	.5487	.5316	.5373	.5487
2	.5144	.5373	.5373	.5487	.5258	.5487	.5487
3	.5144	.5316	.5373	.5487	.5316	.5373	.5487
4	.5144	.5373	.5373	.5601	.5316	.5487	.5487
5		.543	.6401	.2772	.6268	.6535	.6468
6	.7716	.8316	.823	.8488	.9431	.823	.7716
7	.9431	1.0374	1.0374	1.0374	1.1317	.9431	1.0269
8	1.0374	.9335	1.0374	1.0374	1.1317	1.0374	.9335
9	.823	.8316	.9431	.924	.9335	.8402	.7316
10	.9145	.7392	.8316	.8316	.7316	.823	.7316
11	.7316	.6335	.6335	.7316	.8145	.823	.823
12	.7316	.543	.6268	.7316	.724	.8145	.823
13	.6401	.6335	.6335		.6268	.7716	.7164
14	.6268	.5316	.5316	.6401		.6859	.7164
15		.5373	.6268	.5487	.7164	.6859	.724
16	.823	.6268	.6268	.7164	.6135	.7164	.724
17	.7164	.6268	.724	.724	.7164	.7164	.724
18	.8316	.7316	.7087	.823	.8059	.7164	.724
19	.9335	.823	.9145	.9431	.9145	.8316	.9431
20	.8402	.823	.924	.8402	.9145	.8316	.9431
21	.7316	.7164	.7392	.7316	.823	.7392	.823
22	.7316	.7164	.7316	.7316	.7316	.7392	.7316
23	.5373	.6268	.6401	.6268	.6401	.6401	.6335
24	.5144	.5487	.5373	.5487	.5487	.5487	.5373
Max	1.0374	1.0374	1.0374	1.0374	1.1317	1.0374	1.0269
Min	.5144	.5316	.5316	.2772	.5258	.5373	.5373
Avg	.7244	.6741	.7108	.7174	.7482	.7314	.7343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 205 / 11 KV DEOGIRI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1867	.1715	.181	.1867	.1867	.3048
2	.1715	.1848	.1753	.1829	.1848	.1867	.3048
3	.1715	.1867	.1829	.181	.1848	.1772	.301
4	.1715	.1867	.1867	.1848	.1848	.1867	.301
5	.2572	.2829	.2801	.2801	.2829	.2801	.4096
6	.3429	.3772	.3734	.2829	.3772	.3734	.4334
7	.3429	.3772	.2801	.2829	.3772	.3734	.4191
8		.2801	.2829	.2829	.3772	.2829	.4915
9		.1867	.1886	.1867	.2829	.1886	.4572
10	.3277	.3315	.3858	.3763	.5468	.5468	.1867
11	.3201	.2972	.3858	.381	.5735	.6325	.0905
12	.3048	.3125	.3086	.4458	.5468	.7202	.0934
13	.2286	.2743	.3906	.381	.5792	.6097	.0934
14	.2286	.2667	.3858	.4572	.5868	.6859	.0857
15	.2286	.2972	.3906	.4572	.5068	.6097	.0876
16	.2286	.3125	.3906	.5468	.5944	.6249	.0857
17	.2286	.3048	.5944	.4687	.4572	.3906	.0857
18	.1886	.0934	.1772	.1848	.1734		.0857
19	.2829	.1886	.1867	.1886	.2801		.1886
20	.2829	.2801	.2801	.1886	.2801	.2743	.2829
21	.1886	.1867	.181	.1867	.2801	.1867	.1867
22	.1867	.1867	.181	.1867	.181	.1848	.1867
23	.1867	.1867	.1829	.1867	.2743	.181	.1867
24	.1715	.1867	.1753	.1848	.1867	.1867	.2858
Max	.3429	.3772	.5944	.5468	.5944	.7202	.4915
Min	.1715	.0934	.1715	.181	.1734	.1772	.0857
Avg	.2369	.2481	.2799	.2861	.3536	.3668	.2348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 206 / 11KV BILDA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3125	.3906	.4001	.4687	.4572	.2829
2	.4287	.3086	.4096	.4096	.4687	.4915	.2801
3	.4287	.3086	.4096	.4096	.4687	.503	.2801
4	.5144	.3906	.4096	.4287	.5468	.5868	.2801
5	.5735	.4687	.4744	.5258	.6249	.6097	.3772
6	.6554	.5468	.7316	.823	.8697	.9907	.4572
7	.9831	.8697	.9831	1.2269	1.5384	1.406	.5544
8	.9907	1.0155	1.2498	1.3413	1.7004	1.8023	.4668
9	.9145	1.1203	1.3603	1.2955	1.6404	1.7204	.3734
10	.2801	.1867		.2772	.1867	.2772	.9374
11	.1867	.1867	.0876	.1867	.1867	.1791	1.0669
12		.1867	.0914	.1867	.1848	.1791	1.0669
13		.1867	.0857	.1867	.1867	.1715	.9907
14		.1867			.2801	.1715	.9374
15		.1886	.0895	.1867	.1867	.1715	.7811
16		.1886		.1848	.2801	.1867	.9488
17		.1867	.0934	.1848	.1867	.1867	.9488
18	.2772	.1848	.1867	.2772	.2801	.2801	.1829
19	.3772	.3734	.2743	.3658	.3734	.3734	.3734
20	.3772	.3734	.3696	.3772	.3734	.3658	.3734
21	.2801	.2801	.2801	.2715	.2801	.2801	.2772
22	.2801	.2801	.2801	.2743	.2801	.2829	.2743
23	.2772	.2801	.2829	.2772	.2801	.2801	.2715
24	.3953	.3125	.3125	.4001	.3906	.4801	.2829
Max	.9907	1.1203	1.3603	1.3413	1.7004	1.8023	1.0669
Min	.1867	.1848	.0857	.1848	.1848	.1715	.1829
Avg	.4805	.3718	.4215	.4564	.5110	.5181	.5444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 207 / 11KV DARI-GAOTHAN FEEDER GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2629	.2572	.2801	.2629	.2572	.2743
2	.2572	.2601	.2629	.2801	.2629	.2629	.2743
3	.2572	.2629	.3506	.3734	.2629	.2743	.2772
4	.3429	.3582	.4572	.4572	.4477	.4287	.3696
5	.4287	.5487	.5601	.6268	.6401	.6535	.6468
6	.6859	.8402	.7888	.9431	.9431	.9431	.9431
7	.7716	.8488	.9431	.8764	.9431	.8488	.8402
8	.7316	.7011	.7468	.7716	.8488	.8488	.7468
9	.6268	.6135	.6468	.6068	.7468	.6468	.5487
10	.4572	.4668	.4572	.4477	.5373	.4477	.4572
11	.2686	.3544	.3582	.2686	.3582	.3544	.3429
12	.1753	.2801	.2658	.2801	.2686	.3544	.2572
13	.2572	.2829	.2629	.2686	.2572	.3429	.3582
14	.1715	.2772	.2629		.3506	.2572	.3506
15	.2572	.2801	.2572	.2572	.3544	.2572	.2629
16	.1715	.2829	.2658	.2601	.3506	.3658	.2629
17	.3544	.2629	.3734	.2629	.3429	.4477	.3506
18	.4525	.3429	.3696	.4525	.4334	.4477	.4477
19	.6535	.6401	.6401	.6468	.6602	.7316	.6535
20	.6468	.5658	.7011	.7468	.7468	.6468	.6468
21	.3582	.3658	.4477	.4525	.5373	.462	.4477
22	.3582	.3772	.3734	.3582	.3658	.3696	.3582
23	.2658	.2572	.3734	.3544	.3658	.3544	.3582
24	.2572	.2658	.2572	.7392	.2629	.2743	.362
Max	.7716	.8488	.9431	.9431	.9431	.9431	.9431
Min	.1715	.2572	.2572	.2572	.2572	.2572	.2572
Avg	.3943	.4166	.4450	.4787	.4813	.4699	.4516



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 208 / 11 KV WAREGAON- AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1848	.1715	.1867	.1829	.1867	.2515
2	.1715	.1829	.1867	.1886	.1829	.1829	.2686
3	.1715	.1848	.1867	.1867	.1829	.1772	.2629
4	.1715	.1829	.1829	.1867	.1867	.1867	.2629
5	.2572	.2829	.2829	.2801	.2829	.2801	.3506
6	.3429	.3772	.3734	.362	.3772	.3734	.4287
7	.3429	.4715	.3772	.3734	.3772	.3734	.4191
8	.3658	.2801	.3772	.2801	.3772	.3772	.4096
9	.2743	.2772	.2801	.1867	.2801	.2829	.381
10	.2286	.2629	.3048	.3201	.2715	.3086	.1867
11	.2286	.2343	.3048	.4001	.3277	.3906	.1867
12	.2286	.2343	.3048	.3048	.1848	.3906	.1829
13	.2286	.2258	.3086	.3048	.3201	.3048	.0857
14		.2343	.3048		.3048	.3048	.0867
15	.2286	.2201	.3086	.2286	.3125	.3048	.0867
16	.2229	.2343	.3048	.2286	.2972	.3125	.0857
17	.2286	.2458		.2286	.3048	.1867	.0857
18	.1829	.1715	.1867	.0905	.1829	.1867	.0857
19	.2829	.2829	.2772	.1867	.2829	.2801	.1886
20	.2829	.2801	.2772	.1886	.2801	.2772	.2829
21	.1867	.1867	.1867	.1829	.1867	.1867	.1848
22	.1848	.1886	.1867	.1848	.1753	.1886	.1848
23	.1829	.1867	.1886	.1848	.1753	.1886	.1829
24	.1715	.1848	.1715	.1867	.1848	.1867	.2343
Max	.3658	.4715	.3772	.4001	.3772	.3906	.4287
Min	.1715	.1715	.1715	.0905	.1753	.1772	.0857
Avg	.2321	.2416	.2624	.2370	.2592	.2674	.2236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044007 / 33/11KV PHULAMBRI S/S

Feeder No / Name : 209 / 11 KV GADEKAR INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0934	.0572	.0857	.0857	.0591
2	.0857	.0857	.0857	.0619	.0857	.0914	.06
3	.0857	.0857	.0876	.0619	.0857	.0857	.0591
4	.0857	.0857	.0914	.0591	.0857	.0838	.0638
5	.0857	.0857	.0934	.0619	.0886	.1715	.0772
6	.0857	.0876	.08	.0676	.0876	.0924	.0734
7	.0857	.0857	.0934	.0619	.0857	.0934	.0838
8	.0914	.0857	.0876	.0762	.0857	.0895	.0753
9	.1867	.0743	.0905	.0772	.0934	.0905	.1886
10	.1867	.1867	.1886	.0895	.1867	.1886	.1886
11	.1886	.1867	.1886	.0943	.0819	.1867	.0934
12	.1867	.1829	.1886	.0857	.0934	.1867	.0934
13	.1886	.0791	.0886	.0857	.0734	.0857	.0857
14	.0857	.0714	.0934		.0905	.0857	.0905
15	.0934	.1753	.1867	.0857	.0743	.0857	.0905
16	.0857	.1619	.0934	.0867	.0876	.0743	.1867
17	.0924	.0934	.0714	.0857	.0886	.0591	.0895
18	.0895	.0914	.0619	.0857	.0762	.0553	.0924
19	.0895	.0934	.0619	.0857	.0762	.0619	.0905
20	.0876	.0857	.0857	.0857	.0838	.0591	.0905
21	.1886	.0857	.0876	.1886	.0876	.1886	.0895
22	.0876	.0934	.0876	.1886	.0934	.0924	.0886
23	.0857	.0857	.0619	.0914	.0934	.0791	.0876
24	.0857	.0895	.0857	.0648	.0905	.0762	.0667
Max	.1886	.1867	.1886	.1886	.1867	.1886	.1886
Min	.0857	.0714	.0619	.0572	.0734	.0553	.0591
Avg	.1125	.1052	.1014	.0865	.0901	.1020	.0944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 202 / 11 KV BORGAON ARJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2829	.1886	.1886	.2829	.1698	.3544
2	.1886	.2829	.1886	.1886	.2829	.1698	.3544
3	.1886	.2829	.1886	.1886	.2829	.1698	.3544
4	.1886	.3772	.1886	.1886	.3772	.2263	.3544
5	.2829	.3772	.2829	.2829	.3772	.3206	.5258
6	.3772	.3772	.3772	.4715	.3772	.4715	.7011
7	.3772	.2829	.3772	.4715	.3772	.4715	.7011
8	.3772	.1886	.3772	.3772	.2829	.3206	.7011
9	.2829	.1886	.2829	.2829	.1886	.2829	.6135
10	.3506	.6706	.7011	.7011	.8383	.503	.1886
11	.4382	.6706	.7888	.7011	.8383	.7011	.132
12	.503	.6135	.7888	.7545	.5868	.7011	
13	.6706	.6135	.7888	.7545	.4191	.7011	.0943
14	.6706	.6135	.7888	.7545	.4191	.7011	.0943
15	.6706	.5258	.7011	.6706	.3688	.7011	.0943
16	.6706	.5258	.6135	.6706	.4191	.6135	.0943
17	.5868	.5258	.6135	.503	.3353	.4382	.0754
18	.2829	.1886	.1886	.2829	.132	.2829	.1886
19	.3772	.2829	.2829	.3772	.3206	.3772	.2829
20	.3772	.3772	.3772	.3772	.3206	.3772	.2829
21	.3772	.3772	.3772	.3772	.2829	.3772	.2641
22		.2829	.2829	.3772	.2641	.2829	.2641
23	.3772	.2829	.2829	.2829	.2263	.2829	.1886
24	.1886	.2829	.1886	.1509	.2829	.1886	.3544
Max	.6706	.6706	.7888	.7545	.8383	.7011	.7011
Min	.1886	.1886	.1886	.1509	.132	.1698	.0754
Avg	.3910	.3948	.4257	.4323	.3701	.4097	.3156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 203 / 11 KV ALAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.503	.3544	.3544	.503	.4191	.1886
2	.2658	.503	.3544	.3544	.503	.4191	.1886
3	.2658	.503	.3544	.3544	.503	.4191	.1886
4	.3544	.6706	.3544	.443	.6706	.4191	.1886
5	.5258	.6706	.5316	.6201	.8383	.503	.2829
6	.7011	.7545	.7888	.7888	1.0059	1.1736	.3772
7	.8764	.7545	1.0517	1.2269	1.1736	1.4251	.3772
8	.964	1.0059	1.2269	1.3146	1.3413	1.4251	.3772
9	.964	1.0059	1.1393	1.2269	1.3413	.9221	.2829
10	.132	.1886	.1509	.2263	.1886	.132	.5258
11	.132	.1886	.1509	.132	.1886	.0943	.964
12	.1886	.0943	.132	.1886	.1698	.0943	.7545
13	.1886	.0943	.132	.1886	.1698	.0943	.6706
14	.1886	.0943	.132	.1886	.1698	.0943	.7545
15	.1886	.0943	.132	.1886	.1509	.0943	.6706
16	.1886	.0943	.132	.1886	.1698	.0943	.8383
17	.1886	.0943	.132	.1886	.132	.1509	.5868
18	.2829	.1886	.1886	.2829	.132	.2829	.2641
19	.3772	.2829	.2829	.3772	.3584	.3772	.3206
20	.3772	.3772	.3772	.3772	.3206	.3772	.3206
21	.3772	.3772	.3772	.3772	.2829	.3772	.2641
22	.1886	.2829	.2829	.3772	.2641	.2829	.2829
23	.503	.2829	.2829	.2829	.2263	.2829	.2641
24	.2658	.503	.3544	.3544	.503	.4191	.1886
Max	.964	1.0059	1.2269	1.3146	1.3413	1.4251	.964
Min	.132	.0943	.132	.132	.132	.0943	.1886
Avg	.3729	.4004	.3915	.4418	.4711	.4322	.4217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 204 / 11 KV PEDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2829	.1886	.1886	.2829	.1698	.3544
2	.1886	.2829	.1886	.1886	.2829	.1698	.3544
3	.1886	.2829	.1886	.1886	.2829	.1698	.3544
4	.1886	.2829	.1886	.1886	.2829	.1886	.3544
5	.2829	.2829	.2829	.2829	.2829	.2641	.5258
6	.3772	.2829	.3772	.3772	.2829	.2829	.7011
7	.3772	.2829	.3772	.3772	.2829	.3584	.7011
8	.3772	.1886	.3772	.3772	.2829	.2829	.7011
9	.2829	.1886	.2829	.2829	.1886	.2263	.6135
10	.4382	.503	.5258	.6135	.8383	.4191	.1509
11	.5258	.6706	.6135	.6135	.8383	.5258	.0943
12	.503	.6135	.6135	.6706	.4191	.5258	.0943
13	.6706	.6135	.6135	.6706	.4191	.5258	.0943
14	.6706	.6135	.6135	.6706	.4191	.5258	.0754
15	.6706	.5258	.5258	.6706	.4191	.5258	.0754
16	.6706	.5258	.5258	.6706	.4191	.5258	
17	.6706	.5258	.5258	.503	.3353	.5258	.0943
18	.2829	.1886	.1886	.2829	.132	.2829	.0566
19	.2829	.2829	.2829	.2829	.2829	.3772	.2829
20	.2829	.3772	.3772	.3772	.2641	.3772	.2829
21	.2829	.3772	.3772	.3772	.2641	.3772	.2641
22	.2829	.2829	.2829	.2829	.2263	.2829	.1698
23	.2829	.2829	.2829	.2829	.1886	.2829	.132
24	.1886	.2829	.1886	.1886	.2829	.132	.3544
Max	.6706	.6706	.6135	.6706	.8383	.5258	.7011
Min	.1886	.1886	.1886	.1886	.132	.132	.0566
Avg	.3816	.3760	.3746	.4004	.3417	.3469	.2992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044010 / 33 KV ALAND

Feeder No / Name : 206 / 11 KV LOANEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.4191	.3544	.3544	.503	.1677	.1886
2	.2658	.4191	.3544	.3544	.503	.1677	.1886
3	.2658	.4191	.3544	.3544	.503	.1677	.1886
4	.2658	.503	.3544	.3544	.5868	.2515	.1886
5	.3544	.503	.5258	.443	.6706	.3353	.2829
6	.5258	.503	.7011	.6135	.6706	.5868	.3772
7	.7888	.5868	.8764	1.0517	.8383	.9724	.3772
8	.7888	.6706	1.1393	1.1269	1.0059	1.0898	.3772
9	.7888	.6706	1.0517	1.0402	1.0059	1.0395	.2829
10	.132	.1886	.132	.1886	.1886	.132	.4715
11	.0943	.1886	.0943	.0943	.1886	.0943	.7888
12	.1886	.0943	.0943	.1886	.0754	.0943	.6706
13	.1886	.0943	.0943	.1886	.0943	.0943	.6706
14	.1886	.0943	.0943	.1886	.0943	.0943	.6706
15	.1886	.0943	.0943	.1886	.0754	.0943	.5868
16	.1886	.0943	.0943	.1886	.0943	.0943	.5868
17	.1886	.0943	.0943	.1886	.0943	.132	.5868
18	.2829	.1886	.1886	.2829	.132	.2829	.1886
19	.2829	.2829	.2829	.3772	.3206	.3772	.2829
20	.3772	.3772	.3772	.3772	.2829	.3772	.2829
21	.3772	.3772	.3772	.3772	.2641	.3772	.2263
22	.2829	.2829	.2829	.3772	.1886	.2829	.1886
23	.2829	.2829	.2829	.2829	.1698	.2829	.1698
24	.2658	.4191	.3544	.3544	.503	.1677	.1886
Max	.7888	.6706	1.1393	1.1269	1.0059	1.0898	.7888
Min	.0943	.0943	.0943	.0943	.0754	.0943	.1698
Avg	.3258	.3270	.3604	.3974	.3772	.3232	.3755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 201 / 11 kv Bodhegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1905	.3048	.2477	.3429	.3429	.4115
2	.381	.1905	.4973	.3048	.4287	.3772	.442
3	.4572	.1905	.583	.381	.5144	.4287	.5144
4	.5335	.2858	.7011	.4191	.5487	.4801	.5144
5	.5144	.4763	.8573	.4801	.583	.5144	.6001
6	.5487	.5335	.823	.5144	.6173	.5487	.6687
7	.6516	.5716	.5944	.6516	.1543	.6001	.463
8	.6001	.6668	.7373	.7202	.823	.8059	.5316
9	.5144	.6287	.6516	.7716	.8916	.9774	.5182
10	.4458	.3353	.3258	.2743	.3429	.6859	.5716
11	.381	.2743	.2401	.1715	.3086	.5487	.4954
12	.3048	.3258	.2477	.1543	.3086	.6173	.4801
13	.2667	.1829	.2286		.3086	.3258	.4973
14	.2286	.2915	.2477		.3086	.2058	.6001
15	.2096	.2286	.2858		.2915	.2477	.5487
16	.2096	.2229	.2572		.2743	.2667	.5144
17	.2096	.1829	.2743		.3258	.2858	.5144
18	.5335	.5144	.4001		.3429	.3048	.3048
19	.6668	.5792	.7373	.6173	.3772	.9602	.5716
20	.7621	.7373	.823	.6516	.4115	.4973	.3086
21	.5716	.0566	.6097	.6859	.4801	.3086	.2743
22	.4763	.463	.5716	.6516	.4115	.2896	.2858
23	.4763	.4458	.4954	.6001	.3772	.3086	.2858
24	.2743	.1905	.7888	.2477	.5144	.3429	.2915
Max	.7621	.7373	.8573	.7716	.8916	.9774	.6687
Min	.2096	.0566	.2286	.1543	.1543	.2058	.2743
Avg	.4400	.3652	.5118	.4747	.4287	.4696	.4670

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 202 / 11 KV Babra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.3944	.1524	.4115	.4287	.4973
2	.362	.3429	.5487	.1905	.4287	.5144	.6516
3	.4191	.2858	.5944	.2477	.4801	.6859	.8402
4	.5716	.4572	.7716	.2858	.5144	.7545	1.0288
5	.6516	.6097	.823	.3086	.6001	.7888	1.1145
6	.8192	.8383	.8573	.2286	.6516	.823	1.2003
7	.7716	.9526	.9431	.7202	.6859	.8402	1.1431
8	.7716	.9526	.8573	.9259	.7716	.8745	1.0288
9	.5487	1.0288	1.0117	.6687	.703	.583	.8402
10	.3429	.4725	.3258	.5144	.4287	.4572	.4763
11	.3429	.3772	.3086	.3601	.4287	.4458	.381
12	.3429	.2743	.2858	.3601	.4287		.4801
13	.3048	.2915	.3239		.4287	.4287	.5144
14	.3048	.3258	.381		.4287	.3944	.4287
15	.3048	.0394	.4382		.4115	.4572	.4458
16	.4191	.4287	.3772		.4115	.4763	.5716
17	.4954	.4973	.3601		.463	.5144	.4973
18	.6478	.6687	.4763		.4973	.8078	.5525
19	.8573	.823	.8573	.9088	.5144	.8573	1.0479
20	1.0479	.9088	.9431	.8573	.6001	.8402	1.0479
21	.8573	.7373	.7621	.6859	.5487	.0686	.8192
22	.6668	.6687	.6097	.5144	.5144	.5658	.6668
23	.6668	.6344	.5525	.4801	.4801	.4973	.6287
24	.1715	.2858	.3258	.1334	.4287	.4287	.3086
Max	1.0479	1.0288	1.0117	.9259	.7716	.8745	1.2003
Min	.1715	.0394	.2858	.1334	.4115	.0686	.3086
Avg	.5406	.5495	.5887	.4746	.5108	.5884	.7172



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 203 / 11 Kv Nidhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5716	.6001	.5335	.3429	.3086	.3258
2	.6668	.5716	.0669	.5525	.4287	.3086	.4973
3	.743	.5716	.7373	.5716	.4801	.3429	.6859
4	.8002	.6668	.8402	.6097	.5144	.3772	.7316
5	.823	.8573	.9431	.6516	.6001	.4115	.6687
6	.8573	1.0479	.0857	.6001	.6516	.4458	.5658
7	.6001	.7621	.7716	.823	.6859	.463	.4973
8	.6173	.5716	.8402	.6516	.7888	.5316	.7373
9	.5144	.7621	.703	.6344		.5144	.6173
10	.5316	.4572	.2572	.2915	.6687	.6687	.381
11	.381	.6001	.3086	.3772	.6173	.8402	.362
12	.4191	.442	.4001	.3944	.6173	.9431	.3429
13	.381	.4115	.4001		.5487	.823	
14	.381	.3772	.4191		.6173	.6344	
15	.3429	.3258	.4191		.6344	.6478	
16	.3429	.3258	.3772		.6344	.5716	.381
17	.381	.4115	.4115		.3429	.5335	.4572
18	.6097	.6001	.4382		.3772	.6687	.5335
19	.8002	.5144	.7888	.3258	.4115	.8573	.8383
20	.9526	.8078	.8916	.8573	.4458	.8402	.9145
21	.6668	.6687	.8002	.4287	.4801	.6249	.6859
22	.6668	.6344	.6478	.5144	.4115	.503	.6859
23	.6668	.583	.5716	.4801	.3772	.4115	.5906
24	.5487	.5716	.8402	.5716	.4287	.3429	.3258
Max	.9526	1.0479	.9431	.8573	.7888	.9431	.9145
Min	.3429	.3258	.0669	.2915	.3429	.3086	.3258
Avg	.5960	.5881	.5650	.5483	.5263	.5673	.5631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 204 / 11KV LEHA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4191	.3429	.4954	.4801	.3429	.3048
2	.4763	.4191	.4287	.5716	.5144	.4287	.4115
3	.5716	.4191	.5144	.724	.6001	.5144	.463
4	.6668	.5716	.6344	.8002	.6859	.6859	.5144
5	.6859	.724	.6859	.823	.0772	.8573	.6859
6	.8402	.8383		.8916	.823	.8916	.5144
7	.7716	.6668	.7716	.823	.8573	.9088	.4287
8	.6687	.5906	.6859	.7202	.7202	.703	.6687
9	.5144	.5716	.4458	.5316	.583	.5144	.5487
10	.2058	.3258	.2572	.463	.6344	.6001	.2667
11	.2286	.2572	.3944	.4973	.6516	.6859	.2096
12	.2477	.3258	.3772	.583	.6687	.7716	.1886
13	.2858	.3258	.4572		.6859	.6687	.1886
14	.362	.2743	.4572		.6859	.583	.2229
15	.3429	.3772	.4763		.703	.4287	.2401
16	.3429	.381	.4458		.703	.4001	.2477
17	.362	.5144	.4458		.703	.2858	.2058
18	.4191	.6097	.2667		.6859	.4115	.2858
19	.5716	.6687	.6287	.1886	.4801	.5487	.6859
20	.6097	.5335	.6344	.2572	.5144	.4268	.6687
21	.4954	.3772	.5335	.3086	.6001	.4115	.4973
22	.4191	.3353	.4763	.3429	.5144	.3944	.4382
23	.4191	.4115	.4382	.3772	.4801	.2896	.4572
24	.3772	.4191	.3429	.4115	.3429	.4287	.2572
Max	.8402	.8383	.7716	.8916	.8573	.9088	.6859
Min	.2058	.2572	.2572	.1886	.0772	.2858	.1886
Avg	.4718	.4732	.4844	.5450	.5998	.5493	.4000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 205 / 11KV NAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.3258	.1334	.3429	.3772	.2591
2	.2286	.1905	.3944	.1524	.3429	.4287	.463
3	.2477	.1905	.4287	.1905	.3772	.4801	.6344
4	.2858	.2667	.463	.2286	.4115	.5144	.823
5	.3086	.3429	.4973	.2572	.4458	.583	.8573
6	.3772	.4382	.6001	.2743	.4801	.6173	.8402
7	.4801	.5335	.3944	.4801	.5144	.6344	.5944
8	.5316	.5716	.5144	.5487	.8059		.5144
9	.4458	.6097	.6001	.6001	.7373	.7888	.463
10	.3429	.2896	.2229	.2058	.1372	.6001	.381
11	.1143	.2401	.12	.12	.1372	.3772	.3239
12	.1524	.2572	.1143	.1029	.1372	.2572	.4115
13	.1524	.1543	.1143		.1372	.1715	.5658
14	.1524	.1543	.1334		.1372	.1372	.463
15	.1334	1.4746	.1524		.1372	.1905	.6001
16		.1372	.1372		.1372	.1905	.5144
17	.1334	.1543	.1543		.1372	.1524	.5658
18	.2096	.2572	.1905		.1715	.2572	.1143
19	.4763	.4973	.5316	.1886	.2058	.3258	.5335
20	.5906	.5658	.583	.2058	.2572	.3944	.5144
21	.5144	.4973	.4572	.2572	.3086	.4287	.3772
22	.381	.4115	.3429	.3086	.2915	.3429	.381
23	.381	.3772	.362	.3429	.2572	.2915	.2858
24	.2096	.1905	.2229	.1143	.3086	.8059	.2058
Max	.5906	1.4746	.6001	.6001	.8059	.8059	.8573
Min	.1143	.1372	.1143	.1029	.1372	.1372	.1143
Avg	.3069	.3747	.3357	.2617	.3065	.4064	.4869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044024 / 33/11KV BABARA

Feeder No / Name : 206 / 11KV KHAMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.3258	.2667	.5144	.3429	.4458
2	.2858	.2858	.4115	.3429	.6001	.5144	.4973
3	.3429	.2858	.4973	.381	.6516	.6859	.6687
4	.381	.381	.6687	.4572	.6859	.823	.7316
5	.4287	.4763	.8059	.5144	.7202	.8573	.0857
6	.5487	.5716	.9088	.5487	.7545	.9259	.9431
7	.7545	.6668	.9088	.7202	.7888	.9602	.9602
8	.6516	.6668	.6859	.8573	.7716	.9259	.6859
9	.5487	.5335	.6001	.7202	.8059	.8573	.5658
10	.4458	.442	.2572	.463	.4801	.6687	.6859
11	.4191	.6001	1.2346	.2058	.4287	.5658	.6097
12	.381	.4973	.381	.3258	.4287	.4458	.583
13	.3429	.2915	.3429		.4287	.3258	.5658
14		.3258	.3239		.4287	.2572	.5144
15	.2858	.2915	.3429		.4115	.381	.5335
16	.3429	.3258	.3086		.4115	.4191	.4973
17	.4191	.3601	.3429		.4287	.381	.4801
18	.6859	.6687	.381		.4287	.6001	.4763
19	.8192	.823	.8573	1.1145	.5144	.7716	.9526
20	.9526	.0909	.9431	1.0288	.6001	.8402	.8573
21	.724	.6687	.5716	.8573	.6516	.5658	.823
22	.6668		.5525	.6859	.6001	.4287	.8383
23	.6668	.583	.4382	.5144	.5144	.3429	.7621
24	.2401	.2858	.6687	.2286	.3429	.4287	.3086
Max	.9526	.823	1.2346	1.1145	.8059	.9602	.9602
Min	.2401	.0909	.2572	.2058	.3429	.2572	.0857
Avg	.5052	.4525	.5733	.5685	.5580	.5965	.628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 201 / 11 kv Shevata

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0791	.0838	.0857	.0838	.1543	.1463	.1372
2	.0791	.0838	.0762	.0829	.1543	.1646	.1829
3	.1448	.116	.1417	.1357	.1886	.1772	.2427
4	.1334	.1677	.2172	.1715	.2374	.2134	.2743
5	.2172	.218	.3189	.2204	.3018	.2743	
6	.3361	.3018	.3856	.3018	.4144	.3391	.4294
7	.3429	.3353	.4096	.3688	.2622	.4801	.3801
8	.2534		.4458	.3812	.2458	.6535	.2801
9	.3353	.4527	.3601	.285	.3277	.5344	.2195
10	.2035	.2263	.2058	.1509	.1509	.1802	.1638
11	.1509	.1886	.1509	.1086	.0869	.0914	.1619
12	.0943	.1463	.0943	.0754	.0701	.061	
13	.0943	.1578	.0943		.0914	.0943	
14	.0943	.1509	.0943		.1463	.0914	.1966
15	.0943	.1067	.1132		.0848	.1097	.2591
16	.0754	.1417	.132		.128	.1086	.2753
17	.1132	.1417	.1509		.124	.1646	.2267
18	.3018	.3077	.3018		.0146	.1829	.1132
19	.5281	.3174	.4904	.4527	.5975	.3361	.3206
20	.3772	.2926	.4338	.3395	.4207	.2427	.3584
21	.2452	.2926	.3018	.2641	.2561	.2195	.2452
22	.2452	.1898	.2477	.2641	.2195	.1417	.2452
23	.2263	.1715	.2263	.2452	.1463	.1463	.2452
24	.0848	.0838	.0762	.1006	.0914	.1219	.3601
Max	.5281	.4527	.4904	.4527	.5975	.6535	.4294
Min	.0754	.0838	.0762	.0754	.0146	.061	.1132
Avg	.2021	.2032	.2314	.2240	.2048	.2198	.2532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 202 / 11 kv NARLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0503	.0457	.0509	.0857	.0914	.1017
2	.0526	.0503	.0532	.0503	.0857	.0078	.1017
3	.0633	.0671	.0914	.0838	.1029	.1097	.1494
4	.0772	.0838	.1448	.116	.1357	.1372	.2926
5	.1107	.116	.1886	.1526	.1677	.1829	
6	.1734	.1677	.2241	.1844	.2155	.2241	.567
7	.2195	.1844	.1829	.2012	.2949	.3366	.5788
8	.2427	.285	.2743	.3222	.3932	.4435	.4344
9	.2614	.2347	.0283	.2683	.426	.1543	.3109
10	.1772	.1886	.1357	.1698	.1509	.1417	.1457
11	.132	.1063	.1132	.0949	.1097	.0857	.1802
12	.0943	.1097	.0943	.0886	.0857	.0678	.1311
13	.0943	.0791	.0943		.0655	.0739	.1638
14	.0943	.1063	.0943		.0943	.0886	.1311
15	.0943	.0671	.1132		.0747	.1063	.0819
16	.1132	.0943	.132		.0914	.1463	.1147
17	.1509	.0914	.132		.0934	.1595	.1311
18	.2829	.1227	.2641		.2241	.2614	.1886
19	.4527	.1829	.4338	.415	.4024	.4294	.4338
20	.3772	.3475	.3772	.4715	.4294	.3018	.3395
21	.2641	.2801	.2829	.3206	.2561	.2241	.2641
22	.2075	.1715	.1905	.2452	.2012	.2012	.2452
23	.1524	.1372	.1698	.1698	.1715	.1321	.1698
24	.0526	.0503	.0526	.0838	.0686	.0886	.5316
Max	.4527	.3475	.4338	.4715	.4294	.4435	.5788
Min	.0526	.0503	.0283	.0503	.0655	.0078	.0819
Avg	.1664	.1406	.1631	.1938	.1844	.1748	.2517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 203 / 11 kv Pathri

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6024	.6413	.6219	.6413	.6602	.6401	.2134
2	.5571	.6602	.5335	.6602	.679	.5792	.2926
3	.6661	.7167	.7316	.7167	.7922	.7716	.0302
4	.7865	.9145	1.3032	1.1431	1.1128	.9145	.4115
5	.8962	1.4335	1.4419	1.358	1.4523	1.475	
6			1.6753	1.6598	1.6598	1.6598	.4458
7	1.166	1.3717	1.4074	1.5089	1.6032	.1525	.6371
8		1.5655	1.2071	1.3957	1.4335	1.2209	.6535
9	1.475	1.1506	.9172	.9808	1.2071	.6642	.567
10	.5316	.5365	.6687	.6706	.5992	.6001	.679
11	.4862	.5601	.6203	.9088	.8987	.6878	.4715
12	.4641	.4755	.5868	.583	.6722	.5182	.3961
13	.4527	.4557	.5365		.6325	.5121	.3584
14	.4904	.5041	.4641		.6401	.4481	.3961
15	.4024		.4694		.5992	.5201	.4527
16	.2818	.4096	.4527		.7545	.6348	.4527
17	.285	.4817	.4359		.7095	.5144	.4527
18	.9054	.9242	.9054		.6556	.583	.5847
19	1.3392	.8962	1.358	.6539	1.3032	1.2883	1.094
20	1.226	.695	1.2449	.5868	1.4563	.9014	1.1506
21	.9808	.567	.9808	.4359	.9877	.8139	.9997
22	.8299	.8048	.7811	.8488	.8413	.7682	.8299
23	.679	.6859	.679	.7167	.6859	.6401	.7356
24	.6154	.6602	.631	.6413	.679	.583	.6516
Max	1.475	1.5655	1.6753	1.6598	1.6598	1.6598	1.1506
Min	.2818	.4096	.4359	.4359	.5992	.1525	.0302
Avg	.7327	.7778	.8606	.8950	.9465	.7538	.5633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 204 / 11kv Wadod Bazar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2012	.2229	.218	.2401	.2347	.443
2	.2378	.2155	.2214	.2321	.2401	.2715	.4668
3	.2658	.2515	.2683	.2515	.2743	.3086	.7095
4	.2526	.3018	.3048	.3052	.3391	.3544	.7682
5	.0336	.3353	.426	.4024	.4359	.4733	
6	.4854	.4862	.5493	.5138	.547	.5197	1.0692
7	.4877	.5304	.503	.6203	.6882	.5407	1.046
8	.4251		.6173	.6962	.6299	.7712	.8962
9	.4359	.4527	.5079	.6036	.5304	.7186	.8865
10	.6908	.6036	.5144	.4338	.679	.5316	.2972
11	.5281	.4481	.4527	.5601	.4915	.6024	.426
12	.4527	.3898	.3584	.4715	.4115	.5281	.3768
13	.4715	.3258	.3395		.439	.5281	.3605
14		.3841	.3206		.5415	.5228	.3605
15	.4715	.4668	.3772		.5144	.5304	.3932
16	.4527	.0414	.4338		.502	.1097	.3605
17	.5658	.4755	.5658		.567	.6024	.3277
18	.679	.5853	.7167		.0672	.7087	.679
19	.8676	.6874	.9619	1.0562	.9335	.8048	.9431
20	.7922	.7133	.9054	.8865	.8215	.811	.8676
21	.679	.6201	.7545	.7922	.7682	.7392	.7545
22	.6036	.6135	.6097	.679	.6767	.6584	.679
23	.5281	.5243	.5281	.6224	.5487	.5351	.6036
24	.1966	.2263	.2229	.218	.2401	.7316	.4572
Max	.8676	.7133	.9619	1.0562	.9335	.811	1.0692
Min	.0336	.0414	.2214	.218	.0672	.1097	.2972
Avg	.4700	.4296	.4868	.5313	.5053	.5474	.6162



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044049 / 33 KV WADODBAZAR

Feeder No / Name : 205 / 11 KV RAJENDRA INDUSTRIAL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1578	.1509	.1372	.1509	.132	.1646	.1646
2	.1629	.1492	.1423	.1509	.132	.1595	.1543
3	.1595	.1509	.1475	.1509	.132	.0158	.1629
4	.1475	.1509	.1509	.1526	.1509	.1543	.1543
5	.1662	.1509	.1578	.1509	.1509	.1543	
6	.1578	.1509	.1466	.1509	.1509	.1646	.1578
7	1.2567	.1526	.1865	.1509	.1509	.1543	.168
8	.168	.1509	.2126	.1509	.1509	.1867	.1943
9	1.906	.1677	.1949	.1492	.1509	.7842	.2263
10	.2126	.1989	.1739	.1677	.132	.2103	.2075
11	.1844	.5601	.1823	.1949	.2012	.1886	.1698
12	.1677	.2126	.1677	.1509	.1372	.1865	.1698
13	.1677	.2012	.1677		.1646	.2195	.1886
14	.1677	.1786	.1677		.1867	.2195	.1698
15	.1677	.1696	.1658		.1715	.2195	.1509
16	.1658	.1898	.1677		.1423	.1886	.1509
17	.1658	.2195	.1341		.0193	.2195	.132
18	.1658	.1802	.1509		.2012	.6219	.132
19	.1509	.2012	.1658	.1509	.1829	.1867	.1509
20	.1509	.2195	.1677	.1509	.1867	.2012	.132
21	.1658	.1638	.1658	.132	.2126	.168	.132
22	.1509	.1829	.1658	.1509	.2195	.1829	.1509
23	.1492	.1717	.1886	.132	.1715	.1543	.2263
24	.1543	.1509	.1772	.1326	.132	.1543	.1595
Max	1.906	.5601	.2126	.1949	.2195	.7842	.2263
Min	.1475	.1492	.1341	.132	.0193	.0158	.132
Avg	.2821	.1906	.1660	.1512	.1568	.2192	.1655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 201 / 11KV JATEGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1294	.1307	.0934	.1494	.1494	.1372
2	.0914	.128	.128	.0934	.1494	.1494	.1372
3	.1463	.128	.128	.0934	.168	.1494	.1524
4	.1646	.168	.1307	.0934	.1867	.1867	.1829
5	.2012	.1867	.1646	.128	.2054	.2263	.2134
6	.1829	.2054	.1463	.1494	.2054	.2241	.2896
7	.1829	.1867	.1494	.1494	.168	.2054	.3353
8	.1463	.1307	.1463	.1494	.1307	.1494	.5182
9	.1097	.0747	.0934	.0934	.0934	.0934	.4877
10	.2972	.3963	.3292	.4904	.823	.3963	.056
11	.3567	.4877	.6468	.7225	.9145	.6859	.056
12	.443	.4725	.8402	.8278	1.0059	.6401	.056
13	.2469	.4877	.8402		.9145	.6097	.037
14	.3475	.3353	.7842			.6097	.0373
15	.3185	.3963	.6401		.6859	.5335	.0373
16	.2469	.4268	.7468		.6401	.4725	.056
17	.3144	.442	.6767		.5487	.3658	.0373
18	.056	.0732	.1097		.0747	.0747	.056
19	.112	.0543	.1097	.0934	.112	.112	.0934
20	.112	.056	.112	.1307	.1307	.112	.0934
21	.1307	.0549	.112	.1494	.1307	.112	.112
22	.1307	.128	.0934	.1494	.1494	.0934	.0934
23	.1307	.128	.0747	.1494	.1494	.0934	.0747
24	.0914	.1294	.1307	.0934	.1494	.1494	.1219
Max	.443	.4877	.8402	.8278	1.0059	.6859	.5182
Min	.056	.0543	.0747	.0934	.0747	.0747	.037
Avg	.1938	.2253	.3110	.2139	.3428	.2747	.1447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 202 / 11KV DHAMANGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.153	.1867	.1867	.2641	.2439	.0934
2	.1463	.1669	.1867	.1867	.2787	.2591	.0934
3	.1463	.1692	.1867	.2241	.2972	.2591	.0934
4	.1829	.1692	.2195	.2801	.3612	.3048	.112
5	.1829	.1858	.2195	.3361	.3913	.3506	.112
6	.2561	.2787	.3734	.3734	.4268	.4725	.1494
7	.2561	.4365	.5228	.7655	.8259	.7926	.1307
8	.3658	.4666	.5121	.823	.9717	.9145	.112
9	.439	.4816	.5853	.7682	.8579	.7926	.112
10	.056	.056	.0732	.056	.0747	.0747	.4515
11	.0373	.056	.0366	.0373	.056	.056	.6249
12	.0373	.0373	.0366	.0373	.056	.056	.759
13	.0373	.0373	.0366		.0373	.0373	.7682
14	.0373	.0373	.0373		.0373	.0373	.7362
15	.0373	.0373	.0366		.0373	.0373	.6642
16	.0377	.0373	.0373		.0373	.0373	.602
17	.0377	.0373	.0549		.0373	.056	.5268
18	.056	.0549	.056		.056	.056	
19	.0754	.0549	.0747	.0747	.0934	.0934	.0747
20	.0747	.0732	.0732	.0934	.0934	.0934	.0934
21	.0747	.0747	.0747	.0747	.0747	.0934	.0934
22	.0747	.0732	.056	.0747	.0747	.0934	.0934
23	.056	.0732	.056	.0747	.0747	.0934	.0934
24	.1463	.1429	.1829	.1867	.2688	.2439	.0934
Max	.439	.4816	.5853	.823	.9717	.9145	.7682
Min	.0373	.0373	.0366	.0373	.0373	.0373	.0747
Avg	.1249	.1413	.1631	.2585	.2410	.2312	.2906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 203 / 11KV BABHULGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0934	.056	.056	.0747	.0747	.1372
2	.0549	.0934	.056	.0549	.0747	.0747	.1372
3	.0549	.0934	.0549	.056	.0747	.0747	.1524
4	.0549	.0934	.056	.056	.0934	.0747	.1829
5	.0549	.0934	.0549	.0747	.0934	.0934	.2134
6	.0732	.112	.0549	.0747	.0934	.112	.2743
7	.0732	.112	.056	.0914	.112	.112	.4268
8	.0914	.0747	.0914	.0934	.0934	.0934	.7011
9	.0549	.056	.0747	.0934	.0747	.0747	.6706
10	.1448	.1829	.1867	.4816	.6859	.4572	.0373
11	.1572	.2439	.4572	.9031	.6859	.7316	.0187
12	.2317	.2743	.6584	.7977	.6097	.7621	.0187
13	.2058	.3048			.884	.7621	.0187
14	.2469	.3353			.9145	.6859	.0187
15	.2643	.2743			.8383	.6401	.0187
16	.282	.2134	.4525		.7621	.6097	.0373
17	.2364	.3201	.6584		.7316	.503	.0373
18	.056	.0549	.0747		.056	.056	.0373
19	.0747	.0549	.0747	.0747	.0934	.056	.056
20	.056	.0549	.0747	.0747	.0934	.056	.056
21	.056	.056	.0754	.0747	.0747	.0566	.056
22	.056	.0549	.0549	.0747	.0747	.0373	.0373
23	.056	.0057	.3361	.0747	.0747	.0373	.0373
24	.0549	.0934	.0549	.056	.0747	.0747	.1219
Max	.282	.3353	.6584	.9031	.9145	.7621	.7011
Min	.0549	.0057	.0549	.0549	.056	.0373	.0187
Avg	.1144	.1394	.1768	.1812	.3099	.2629	.1460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 204 / 11 KV JATEGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.0934	.3361	.3174	.3292	.3475	.3475
2	.3292	.0934	.3292	.3361	.3292	.3475	.3475
3	.3292	.0934	.3658	.4024	.3326	.3658	.3658
4	.4024	.1494	.4024	.5601	.5975	.4755	.439
5	.6219	.2054	.6219	.8488	.8029	.7095	.5975
6	.7682	.3547	.8962	.9709	.9522	.9709	.9709
7	.7682	.4108	1.0242	1.0082	.8097	.9709	.9709
8	.823	.3547	.8402	.7316	.8029	.8589	.7842
9	.5853	.5359	.7468	.6401	.5788	.6908	.8215
10	.4668	.3658	.5853	.4481	.4755	.5041	.4854
11	.1494	.2561	.3734	.3326	.3658	.439	.3511
12	.2218	.2561	.2614	.2772	.2743	.3658	.2957
13	.2561	.2614	.2614		.2561	.3292	.2772
14	.2743	.2195	.2801		.1494	.2987	.2561
15	.2172	.2926	.2378		.2195	.2743	.2561
16	.2353	.2926	.2801		.3292	.2561	.2402
17	.2957	.3292	.3292		.3292	.4024	.2772
18	.5975	.4668	.4668		.5228	.439	.3881
19	.8775	.6401	.823	.8775	.7468	.6908	.6535
20	.6722	.695	.7842	.8402	.8029	.5601	.7282
21	.4668	.4904	.6535	.5228	.5975	.4854	.5041
22	.3547	.4108	.3921	.4294	.4481	.3734	.462
23	.3326	.3734	.3052	.3734	.3734	.3734	.3881
24	.3109	.0934	.3361	.3174	.3511	.3048	.3658
Max	.8775	.695	1.0242	1.0082	.9522	.9709	.9709
Min	.1494	.0934	.2378	.2772	.1494	.2561	.2402
Avg	.4452	.3223	.4972	.5686	.4907	.4931	.4822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044060 / 33/11KV JATEGAON S/S

Feeder No / Name : 205 / 11KV SULTANWADI

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2	.2561	.1867	.208	.1677	.1494
2	.1829	.2	.2561	.181	.2229	.1829	.1494
3	.1829	.2027	.2614	.1867	.2378	.1829	.1494
4	.2743	.2027	.2614	.1867	.2408	.2134	.1867
5	.3292	.2172	.2801	.2054	.2559	.2439	.2241
6	.3292	.3269	.3734	.2378	.301	.3201	.2614
7	.3658	.4365	.3658	.4024	.5117	.503	.2614
8	.3658	.602	.3734	.4668	.5569	.4877	.2241
9	.3658	.3763	.3734	.4572	.4816	.4115	.168
10	.1402	.112	.7468	.1402	.1494	.1307	.286
11	.1227	.0934	.0934	.1052	.1307	.112	.3612
12	.1227	.0934	.0934	.0876	.1307	.0934	.3612
13	.1052	.0934	.0934		.112	.0747	.3311
14	.1029	.112	.0934		.112	.0934	.3161
15	.1029	.0934	.0934		.112	.0934	.3161
16	.1052	.0934	.0934		.1307	.0934	.301
17	.1372	.112	.0905		.168	.1494	.301
18	.2103	.1463	.0934		.1867	.1494	
19	.2229	.1646	.1829	.1949	.2054	.2241	.2454
20	.2058	.168	.1829	.1949	.1867	.1867	.2103
21	.1715	.1646	.1829	.1402	.168	.1494	.1595
22	.1578	.1463	.1867	.1402	.1494	.1494	.1417
23	.1595	.1463	.1494	.12	.1307	.1494	.1227
24	.1829	.2	.2561	.1867	.1738	.1677	.1494
Max	.3658	.602	.7468	.4668	.5569	.503	.3612
Min	.1029	.0934	.0905	.0876	.112	.0747	.1227
Avg	.2012	.1960	.2264	.2123	.2193	.1971	.2338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 201 / 11KV KINGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.1612	.1341	.168	.2804	.2481	.1886
2	.2915	.1791	.1174	.1867	.2774	.2835	.1886
3	.3258	.1949	.1174	.2054	.3086	.3121	.2075
4	.3814	.2126	.1296	.2241	.2984	.3814	.2263
5	.4115	.2454	.2429	.4287	.3277	.5144	.2829
6	.463	.3814	.4049	.4334	.5407	.8951	.3206
7	.5144	.6104	.5796	.6173	.7811	.9831	.3395
8	.5487	.5344	.4668	.7888	.7773	1.0688	.3018
9	.583	.4372	.5182	.5506	.7407	1.0669	.2075
10	.1829	.1509	.1509	.1509	.181	.2263	.3258
11	.1294	.132	.1886	.1509	.1294	.1509	.5144
12	.112	.1509	.1372	.1698	.1109	.1132	.5548
13	.0934	.1132	.12	.1698	.1109	.132	.5487
14	.112	.1698	.1132	.1698	.1109	.1698	.5487
15	.112	.1509	.0934	.1886	.0934	.132	.583
16	.1307	.0943	.112	.1886	.1109	.1509	.7888
17	.1294	.1509	.1307	.1886	.1463	.2075	.6859
18	.181	.1698	.1734	.1698	.181	.1886	.2801
19	.2149	.3018	.2572	.2075	.2534	.2075	.2058
20	.2149	.2829	.2401	.2452	.2896	.2452	.1715
21	.181	.2452	.1734	.2263	.2534	.2075	.1715
22	.1294	.2452	.168	.2075	.2012	.1886	.168
23	.112	.1886	.168	.2075	.1663	.1886	.168
24	.2743	.1791	.1341	.1867	.3155	.2507	.2075
Max	.583	.6104	.5796	.7888	.7811	1.0688	.7888
Min	.0934	.0943	.0934	.1509	.0934	.1132	.168
Avg	.2550	.2368	.2113	.2679	.2911	.3547	.3411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 202 / 11KV PIMPALGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0905	.0943	.0857	.112	.0905	.1132
2	.0857	.0905	.0943	.0857	.1494	.1097	.1132
3	.1886	.1254	.1132	.1214	.1494	.1433	.112
4	.1886	.1772	.132	.1715	.1867	.2149	.1463
5	.2229	.2303	.1886	.2254	.2054	.2804	.2054
6	.2601	.2774	.2829	.2743	.3361	.3155	.2829
7	.3086	.3294	.3395	.2915	.3547	.2947	.3109
8	.2915	.2829	.3292	.2591	.2614	.2743	.2743
9	.2572	.132	.2452	.192	.2427	.2427	.2378
10	.2149	.1132	.1734	.1294	.1772	.0754	.1715
11	.0905	.0943	.0934	.0934	.1254	.0754	.1214
12	.0905	.0943	.0747	.0934	.1086	.1132	.104
13	.0549	.0754	.0857	.0747	.0905	.0754	.0934
14	.0732	.0566	.0747	.0747	.0914	.0754	.1029
15	.0914	.0754	.0857	.0747	.0914	.0747	.1029
16	.0905	.0566	.1029	.0747	.1086	.0747	.1029
17	.1086	.0754	.1372	.0934	.1075	.1463	.1029
18	.1949	.1646	.156	.168	.1254	.1886	.1715
19	.2804	.2378	.2601	.2614	.2629	.2614	.2427
20	.2303	.2012	.2427	.2614	.2804	.2012	.2254
21	.1612	.1698	.1867	.1867	.2658	.1698	.1715
22	.1254	.1463	.1494	.1494	.197	.1463	.1372
23	.1267	.1307	.1029	.1307	.1086	.1307	.12
24	.0857	.1086	.112	.1029	.112	.1086	.1132
Max	.3086	.3294	.3395	.2915	.3547	.3155	.3109
Min	.0549	.0566	.0747	.0747	.0905	.0747	.0934
Avg	.1628	.1473	.1607	.1531	.1771	.1618	.1616



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 203 / 11KV GANORI AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.112	.1132	.112	.1132	.112	.1509
2	.1372	.112	.132	.112	.1132	.112	.1715
3	.1715	.1478	.1509	.1494	.1509	.1478	.2012
4	.1886	.1829	.1698	.1867	.1509	.1829	.2458
5	.2229	.2172	.2075	.2241	.1886	.181	.2949
6	.2401	.2353	.2452	.2427	.2829	.2172	.3953
7	.2572	.2507	.2829	.2614	.2829	.2328	.3909
8	.3086	.2263	.2452	.2058	.2452	.1886	.4572
9	.1715	.1509	.1886	.2075	.2075	.1698	.443
10	.2454	.1134	.3121	.421	.3601	.5335	.112
11	.3155		.5201	.6154	.7712	.7773	.112
12	.298	.2267	.5548	.8025	.8356	.8145	.0934
13	.3012	.3239	.5375	.8179	.9231	.724	.112
14	.298	.2429	.5201	.7682	.8192	.7164	.112
15	.3121	.2143	.5658	.6882	.7127	.7011	.0934
16	.3294	.3269	.6241	.7116	.7625	.3475	.1029
17	.3601	.3658	.4161	.6316	.8192	.208	.1307
18	.3721	.1132	.156	.1698	.1109	.132	.1494
19	.3898	.1886	.1715	.2075	.1829	.2075	.1867
20	.2481	.1886	.1907	.2075	.2353	.1698	.2054
21	.1267	.1509	.1734	.1509	.1991	.132	.1867
22	.0924	.1509	.168	.1132	.1829	.132	.1494
23	.0934	.132	.1494	.0943	.1109	.1132	.1307
24	.1372	.0934	.1132	.1307	.1132	.112	.1509
Max	.3898	.3658	.6241	.8179	.9231	.8145	.4572
Min	.0924	.0934	.1132	.0943	.1109	.112	.0934
Avg	.2398	.1942	.2878	.3430	.3698	.3069	.1991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 204 / 11 KV DONGERGAON-SHIRODI SEPARATED AG FEEDERS HAVING SPECIAL  
AG Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.0373	.1006	.1214	.2601	.2658	.2263
2	.2743	.0373	.0671	.1372	.3086	.3155	.2054
3	.3086	.0373	.0671	.1715	.3647	.5028	.2427
4	.3429	.056	.0857	.2572	.3978	.5935	.2829
5	.4115	.0554	.3077	.4801	.4534	.7293	.3395
6	.463	.1109	.3963	.5144	.6167	.9012	.3772
7	.5144	.1848	.6706	.8573	.9172	1.1142	.3961
8	.6516	.1943	.643	.9259	1.034	1.0002	.3018
9	.703		.6716	.8745	.9646	1.057	.2075
10	.1629	.1132	.1214	.132	.1829	.1698	.5144
11	.128	.0943	.1494	.0943	.0924	.1132	.7042
12	.1294	.0754	.1214	.0943	.0924	.0943	.7362
13	.112	.0754	.104	.0754	.0934	.0943	.7545
14	.112	.0943		.0754	.0934	.1132	
15	.1109	.0943	.0857	.0754	.0934	.0943	.8402
16	.0914	.0943	.1029	.0754	.0924	.112	.9762
17	.1267	.0943	.12	.0754	.1294	.1509	.8962
18	.1791	.1132	.1734	.1132	.1463	.1509	.2427
19	.2507	.2075	.208	.1886	.2172	.2263	.2801
20	.2507	.2452	.2254	.2641	.2534	.2641	.2614
21	.2328	.1886	.1867	.2075	.2353	.2452	.2241
22	.1848	.1698	.168	.1698	.1829	.2452	.2054
23	.1663	.1509	.168	.1509	.1663	.2263	.1867
24	.2572	.0554	.1886	.2801	.2658	.2658	.2075
Max	.703	.2452	.6716	.9259	1.034	1.1142	.9762
Min	.0914	.0373	.0671	.0754	.0924	.0943	.1867
Avg	.2683	.1121	.2232	.2671	.3189	.3769	.4178

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 205 / 11 KV WAREGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2686	.2926	.2987	.2801	.2686	.2743
2	.2427	.2865	.3174	.2915	.3361	.3012	.3018
3	.2572	.3544	.3734	.3734	.5041	.3681	.3395
4	.583	.4733	.5658	.4973	.5975	.5144	.4668
5	.6859	.6783	.7468	.6001	.7842	.7461	.7392
6	.6859	.8718	.8764	.7545	1.0059	.9448	.9774
7	.7202	.7122	.9816	.7935	.6535	.8288	.6767
8	.703	.7316	.7682	.7202	.7468	.7499	.695
9	.6859	.7095	.7316	.6173	.7468	.6348	.7499
10	.583	.3658	.2915	.3658	.6173	.4938	.3429
11	.2427	.3206	.2427	.2241	.2126	.3174	.2743
12	.1928	.2641	.208	.1867	.2658	.2686	.2572
13	.1949	.2263	.1907	.1867	.2507	.2987	.2572
14	.1772	.0754	.1734	.1867	.181	.2801	.2572
15	.1949	.0914	.2058	.1867	.0914	.2614	.2987
16	.298	.2427	.2254	.2054	.1772	.2743	.2058
17	.3814	.2452	.3429	.2054	.2454	.3292	.3174
18	.6036	.3658	.4858	.3921	.3944	.4904	.5601
19	.779	.6447	.6802	.7095	.7377	.6584	.8962
20	.6796	.7265	.502	.8501	.8139	.6767	.8495
21	.5144	.547	.4458	.6908	.6859	.6036	.6859
22	.4607	.4024	.3429	.5228	.5028	.5041	.4458
23	.3544	.3734	.2572	.4108	.3189	.4163	.4115
24	.2229	.2686	.3174	.2614	.2801	.2686	.3292
Max	.779	.8718	.9816	.8501	1.0059	.9448	.9774
Min	.1772	.0754	.1734	.1867	.0914	.2614	.2058
Avg	.4451	.4269	.4402	.4388	.4763	.4791	.4837

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044074 / 33/11KV WAREGAON

Feeder No / Name : 206 / 11 KV WANEGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2195	.2263	.2241	.3018	.2715	.2058
2	.2572	.2172	.2452	.2427	.3018	.2896	.218
3	.3086	.2534	.2829	.2801	.3395	.2865	.2543
4	.3601	.3045	.3206	.2915	.3772	.3189	.2622
5	.4115	.3582	.3772	.3734	.3961	.3189	.3277
6	.4287	.3898	.4668	.3772	.4527	.333	.4572
7	.4458	.4207	.5093	.3768	.4715	.3856	.4778
8	.3429	.3584	.415	.3547	.3395	.3772	.543
9	.3086	.2075	.2452	.2241	.2641	.3206	.503
10	.1772	.2429	.2601	.2915	.394	.3658	.1494
11	.2774	.3077	.3814	.3681	.4287	.2892	.1307
12	.2774	.2267	.4161	.3725	.4409	.5182	.112
13	.2629	.218	.3467	.3637	.4578	.5357	.112
14	.2629	.1943	.2947	.3637	.4578		.112
15	.2629	.1829	.3429	.3795	.4578	.4715	.112
16	.2774	.1932	.3944	.3795	.4973	.4666	.112
17	.3294	.2896	.4458	.4586	.5426	.3658	.112
18	.3544	.132	.2543	.1509	.1646	.1886	.1307
19	.3506	.2641	.3174	.2641	.2865	.2452	.1867
20	.3189	.2829	.2614	.3395	.3224	.2263	.2427
21	.2865	.3018	.2427	.3206	.2896	.1886	.1867
22	.2534	.3018	.2801	.3018	.2715	.1698	.168
23	.2561	.2829	.2987	.2829	.2896	.1509	.1494
24	.2401	.2561	.2641	.2801	.3018	.2896	.2035
Max	.4458	.4207	.5093	.4586	.5426	.5357	.543
Min	.1772	.132	.2263	.1509	.1646	.1509	.112
Avg	.3045	.2669	.3287	.3192	.3686	.3206	.2279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 201 / 11 KV PIRBAWADA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.181	.1524	.1905	.2263	.1905	.415
2	.2641	.1829	.1905	.1905	.2801	.1905	.4527
3	.2614	.2126	.2096	.2667	.3761	.2286	.5847
4	.2772	.2601	.2075	.2858	.463	.2743	.7167
5	.2804	.333	.3734	.394	.5087	.4108	.8676
6	.3052	.4287	.4458	.5716	.5868	.5144	1.094
7	.4239	.5493	.5959	.7202	.8951	.9313	1.0374
8	.373	.7059	.6089	.9259	.9614	1.2803	.8865
9	.3326	.6447	.6733	.9526	.8648	.8326	.6413
10	.3584	.3772	.394	.3772	.4715	.3315	.3544
11	.218	.2469	.3048	.2829	.3258	.4382	.6154
12	.2254	.2317	.3048	.2829	.2812	.381	.7701
13	.2058	.2439	.2858		.2812	.381	.7802
14	.2658	.2134	.2667		.2785	.3429	.6443
15	.2629	.2753	.2858			.3429	.5868
16	.2652	.2429	.3048		.3395	.3048	.5959
17	.2774	.2622	.3239		.3593	.3395	.6485
18	.6478	.362	.4382		.4572	.5093	.4001
19	.8192	.5335	.7621	.8676		.7733	.7811
20	.743	.5906	.7621	.7356	.7621	.679	.743
21	.5525	.5525	.5525	.5658	.6478	.5847	.6097
22	.4954	.4954	.4572	.5093	.5525	.5281	.5525
23	.4572	.4572	.4572	.3961	.4763	.4715	.4763
24	.2263	.1478	.1524	.1715	.2641	.1905	.4338
Max	.8192	.7059	.7621	.9526	.9614	1.2803	1.094
Min	.1886	.1478	.1524	.1715	.2263	.1905	.3544
Avg	.3636	.3638	.3962	.4826	.4845	.4771	.6537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 202 / 11 KV RANJANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.181	.1905	.1905	.1886	.1905	.1494
2	.3395	.2012	.1905	.1905	.2263	.2286	.168
3	.4527	.2481	.2286	.2286	.3206	.2667	.2012
4	.5281	.3467	.2641	.2667	.5847	.2926	.2743
5	.679	.4207	.5228	.5335	.7167	.5601	.2915
6	.7922	.5144	.703	.7811	.8488	.7202	.3391
7	.7865	.6201	.7011	.7621	.7167	.8238	.407
8	.6413	.5249	.5373	.7049	.6036	.6219	.4144
9	.415	.4119	.3898	.4572	.4338	.3982	.373
10	.2218	.2058	.2507	.333	.4287	.2321	.2126
11	.1509	.1646	.3258	.3429	.5068	.3772	.1448
12	.1907	.2027	.3086	.407	.4374	.4115	.1254
13	.1715	.2134	.3086		.4062	.3086	.104
14	.1772	.2134	.2401		.3277	.3601	.1357
15	.2103	.1943	.2572		.3239	.3429	.1677
16	.2155	.1296	.2572		.3395	.3429	.1578
17	.2254	.1966	.2572		.2812	.2374	.1334
18	.3048	.1334	.2667		.2926	.3395	.2858
19	.6287	.3429	.5906	.547		.4715	.4763
20	.5144	.4191	.6097	.5093	.4954	.3961	.4763
21	.3239	.3048	.3048	.3961	.3429	.3395	.3429
22	.2096	.2667	.2667	.3584	.2667	.2641	.2858
23	.1905	.2286	.2286	.2263	.2286	.2263	.2286
24	.1886	.1478	.2096	.2096	.2075	.1905	.1132
Max	.7922	.6201	.703	.7811	.8488	.8238	.4763
Min	.1509	.1296	.1905	.1905	.1886	.1905	.104
Avg	.3668	.2847	.3504	.4136	.4141	.3726	.2503

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

AURANGABAD RURAL II DIVN.[223]

PHULAMBRI S/DN.[803] BU 4803

Substation No/ Name :- 044091 / 33/11 KV PIRBAWADA

Feeder No / Name : 203 / 11 KV GEOVRAI PAIGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.362	.381	.3429	.3395	.3429	.2427
2	.3772	.3658	.381	.3429	.3772	.381	.2772
3	.5093	.3898	.4572	.381	.5093	.4954	.2804
4	.7356	.4854	.5658	.4954	.7167	.5487	.3222
5	.8676	.631	.724	.7621	.8299	.7842	.3561
6	.9431	.7888	.9259	1.0288	1.0185	.8916	.3978
7	.9431	.9214	.7712	.8383	.9808	.9313	.4694
8	.8299	.7964	.6447	.8002	.7922	.8048	.5243
9	.6036	.6447	.6024	.5716	.6413	.6516	.57
10	.3086	.4458	.4298	.5487	.7122	.431	.3544
11	.4024	.4664	.6173	.5365	1.1584	.5487	.2534
12	.5201	.5502	.583	.7042	.9061	.6859	.2149
13	.5144	.5487	.6173		.8124	.6516	.208
14	.5316	.4268	.5487		.7865	.6173	.2374
15	.5959	.5182	.4458		.6154	.6097	.2012
16	.4641	.3887	.5144		.6173	.4115	.2454
17	.4508	.3932	.5144		.5312	.2743	
18	.4954	.2667	.3048		.3658	.415	.2667
19	.8002	.4191	.6478	.7545		.6036	.5716
20	.6859	.4954	.724	.679	.724	.6036	.5335
21	.4954	.4954	.5335	.5281	.4954	.5281	.4191
22	.4572	.4191	.4572	.4527	.4191	.4904	.381
23	.381	.4191	.381	.415	.381	.415	.381
24	.3018	.3326	.381	.3429	.3772	.381	.2263
Max	.9431	.9214	.9259	1.0288	1.1584	.9313	.5716
Min	.3018	.2667	.3048	.3429	.3395	.2743	.2012
Avg	.5640	.4988	.5481	.5847	.6568	.5624	.3450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 201 / FARDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361			.6722			.3734
2	.3734			.6413			.3361
3	.3772			.6413			.3772
4	.415		.8299	.679		.7167	.415
5	.4108			.7545			.415
6	.4481			.8215			.4527
7	.4854		.7842	.7842		.7545	.4527
8	.4458	.4904	.7842	.7202	.6859	.7202	.4115
9	.4115		.6722	.7202	.583	.6859	.4115
10	.5144		.4108	.4115	.4115	.5144	.583
11	.4801		.4108	.4115	.4115	.4801	.6173
12	.5144	.7922	.3734	.4115	.4115	.4458	.6173
13	.5144		.4108	.4115		.4458	
14	.5144		.4481	.4115	.7202	.4458	.6516
15	.5144		.4481		.9259	.4115	.6173
16	.5716	.5281	.4854	.4572	1.1317	.3658	.6478
17	.6097		.4481	.4572	.9431	.3963	.6859
18	.6859		1.0082		1.4712	.7468	.5716
19	.6859		1.1576		.9054	.8962	.7621
20	.724	.7167	1.2696		.8676	.7842	.8383
21	.7621		1.1949		.9054	.8215	.8764
22	.6859		1.2696		.9054	.7842	.8383
23	.6478		.679			.7468	.7621
24	.3361	.5716	.7167			.8299	.3361
Max	.7621	.7922	1.2696	.8215	1.4712	.8962	.8764
Min	.3361	.4904	.3734	.4115	.4115	.3658	.3361
Avg	.5194	.6198	.7264	.5879	.8057	.6312	.5674



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 202 / 11KV JANGLA GAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867			.2241			.2263
2	.1867			.1867			.2641
3	.2241			.1867			.2641
4	.2241		.1886	.2241		.1886	.3018
5	.2241			.2241			.3395
6	.2641			.2614			.3395
7	.2614		.2263	.2614		.2263	.3772
8	.2743	.3772	.1867	.2401		.2058	.2058
9			.112	.2401	.1715	.1715	.1715
10	.1029		.4481	.1372	.1372	.2058	.0686
11	.0686		.4481	.1715	.1715	.3429	.1372
12	.0686	.0754		.1715	.2058	.3772	.1372
13	.0686			.1715	.2743	.3772	.1029
14	.0686		.4108	.1715	.3429	.4115	.1029
15	.0686		.4481		.3086	.4115	.1029
16	.0762	.0754	.4854	.1905	.3395	.4108	.1143
17	.0762		.4854	.2286	.3018	.4108	.1143
18			.4481		.2263	.2614	.1524
19			.1494		.2641	.3361	.1905
20		.1132	.2987		.3018	.3395	.1905
21			.2987		.3395	.3734	.1524
22			.2614		.3018	.3395	.1905
23			.2241			.2987	.1524
24	.1494		.1132	.2286		.2263	.2241
Max	.2743	.3772	.4854	.2614	.3429	.4115	.3772
Min	.0686	.0754	.112	.1372	.1372	.1715	.0686
Avg	.1525	.1603	.3078	.2070	.2633	.3113	.1926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 203 / 11 K V PALASKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842			.4854			.7468
2	.6722			.5228			.7095
3	.6348			.5228			.7922
4	.6348		.8299	.5601		.7545	.9054
5	.7095			.6348			1.0185
6	.7468			.6722			1.1203
7	.7468		.9054	.7095		.8299	1.1949
8	.7202	.7922	.9335	.6516	.6516	.9259	.6859
9	.6859		.5975	.6516	.6173	.8573	.7202
10	.4115		.4481	.5487	.4458	.583	.5144
11				.4458	.3772	.4801	.583
12	.4115	.4904		.4115	.3429	.4458	.583
13	.4458		.4854	.4115	.5144	.4801	.6173
14	.4458		.5228	.4458	.583	.5487	.6173
15	.4115		.5228		.6173	.5487	.7888
16	.4572	.7167	.5975	.4572	.6413		.8383
17	.5716		.7095	.6478	.8676		.8764
18			.8589		.9808		.8764
19			1.0829		1.0185	.8589	.8764
20		.8299	1.2071		1.0185	.8589	.9526
21			1.0185		1.0562	.9709	.9145
22			.9431		1.094	.8676	.8764
23			.8299			.8299	.8383
24	.7842		.7545	.4954		.8676	.7468
Max	.7842	.8299	1.2071	.7095	1.094	.9709	1.1949
Min	.4115	.4904	.4481	.4115	.3429	.4458	.5144
Avg	.6044	.7073	.7793	.5456	.7218	.7317	.8081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 205 / 11KV MTDC FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328			.0312			.0312
2	.0312			.0305			.0312
3	.0312			.0312			.0312
4	.0312		.0381	.0312		.0381	.0305
5	.0312			.0312			.0305
6	.0312			.0312			
7	.0305		.0381	.0312		.0381	.0312
8	.0038	.0381	.0312	.0038	.0038	.0038	.0038
9	.0038		.0312	.0343	.0038	.0038	.0038
10	.0076		.0625	.0076	.0038	.0076	.0038
11	.0076		.0625	.0076	.0229	.0191	.0038
12	.0076	.1143	.0625	.0076	.0267	.0229	.0038
13	.0076		.0625	.0191	.0267	.0229	.0038
14	.0076		.061	.0229	.0267	.0229	.0038
15	.0076		.061	.0152	.0229	.0229	.0038
16	.0762	.0762	.0625	.1524	.2286	.1875	.0381
17	.0762		.0625	.1905	.0762	.1562	.0381
18			.0312		.0381	.0312	.0381
19			.0312		.0381	.0305	.0381
20		.0381	.0312		.0381	.0312	.0381
21			.0312		.0381	.0305	.0381
22			.0312		.0381	.0305	.0381
23			.0312			.0305	.0381
24	.0312		.0381	.0305		.0381	.0305
Max	.0762	.1143	.0625	.1905	.2286	.1875	.0381
Min	.0038	.0381	.0312	.0038	.0038	.0038	.0038
Avg	.0253	.0667	.0453	.0394	.0422	.0404	.0240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 207 / AJANTHA CAVES

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305			.0324			.0312
2	.0305			.0305			.0312
3	.0305			.0305			.0312
4	.0305		.0381	.0305		.0381	.0312
5	.0305			.0305			.0312
6	.0305			.0305			.0305
7	.0305		.0381	.0305		.0381	.0373
8	.0038	.0381		.0038	.0038	.0038	.0038
9	.0038		.0324	.0038	.0038	.0038	.0038
10	.0076		.0324	.0038	.0038	.0076	.0038
11	.0076		.061	.0076	.0686	.0076	.0038
12	.0076	.0762	.0648	.0076	.0076	.0076	.0038
13	.0076		.061	.0076	.0076	.0076	.0038
14	.0076		.0648	.0076	.0076	.0076	.0038
15	.0076		.061	.0076	.0076	.0076	.0038
16	.0762	.0762	.061	.0762	.0762	.061	.0381
17	.0762		.0648	.0762	.0762	.061	.0381
18			.061		.0381	.0305	.0381
19			.061		.0381	.0305	.0381
20		.0381	.0648		.0381	.0305	.0381
21			.0312		.0381	.0305	.0381
22			.0312		.0381	.0305	.0381
23			.0312			.0305	.0381
24	.0312		.0381	.0305		.0381	.0312
Max	.0762	.0762	.0648	.0762	.0762	.061	.0381
Min	.0038	.0381	.0312	.0038	.0038	.0038	.0038
Avg	.0250	.0572	.0499	.0249	.0302	.0249	.0246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044002 / FARDAPUR

Feeder No / Name : 209 / Tondapur Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / INCOMING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10		.3018	.2187	.2401	.2058	.2743
11			.2987	.2401	.2058	.3429
12		.3395	.2987	.2401	.1715	.4115
13	.1372		.2622	.2743	.1715	.4115
14	.1372		.25	.2743	.2058	.4458
15			.25	.2401	.2058	
16		.3018	.25	.2667	.2263	.2134
17	.1905		.25	.1905	.3018	
Max	.1905	.3395	.2987	.2743	.3018	.4458
Min	.1372	.3018	.2187	.1905	.1715	.2134
Avg	.1550	.3144	.2598	.2458	.2118	.3499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 201 / 11KV BANOTI-AG- FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2286	.2667	.2286	.1905
2				.2286	.2667	.2286	.2667
3				.2286	.2667	.2667	.3048
4				.2286	.2667	.3429	.3429
5				.2286	.3048	.381	.381
6				.2286	.3048	.4572	.4191
7				.3048	.4572	.6097	.6097
8				.4572	.5716	.8383	.7621
9				.4572	.6859	.8764	.8764
10	.3048		.4001				
11	.2667		.5716				
12	.3048	.2286	.4954				
13	.3048		.4954				
14	.3048		.4572				
15	.2667		.4191				
16	.2286		.4001				
17	.1905	.4191	.4572				
24				.2286	.2667	.4191	.1143
Max	.3048	.4191	.5716	.4572	.6859	.8764	.8764
Min	.1905	.2286	.4001	.2286	.2667	.2286	.1143
Avg	.2715	.3239	.4620	.2819	.3658	.4649	.4268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 202 / 11 KV NANDGAON AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.1143				
2	.0762	.0762	.1143				
3	.0762	.0762	.1143				
4	.0762	.1143	.1143				
5	.0762	.1143	.1143				
6	.1143	.1524	.1143				
7	.1524	.1905	.1905				
8	.1905	.2286	.2286				
9	.2286	.2667	.2096				
10				.2286	.2286	.2286	
11				.2667	.2667	.2667	.2286
12				.3048		.2667	.2286
13				.3048	.3048	.3048	.2286
14				.3048	.3048	.2667	.2286
15					.3048	.2667	.2286
16				.2286	.2667		.2286
17				.2667			.2286
24	.0762	.1143	.1143				
Max	.2286	.2667	.2286	.3048	.3048	.3048	.2286
Min	.0762	.0762	.1143	.2286	.2286	.2286	.2286
Avg	.1143	.1410	.1429	.2721	.2794	.2667	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 204 / 11 KV BANOTI GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.2286	.2096	.2286	.2667	.2667	.2667
2	.2477	.2286	.2286	.2286	.2477	.2667	.2667
3	.2667	.2667	.2667	.2286	.2858	.3429	.3429
4	.4001	.3429	.381	.3048	.4001	.381	.381
5	.6287	.6097	.6478	.4954	.6287	.6859	.6478
6	.9526	.9526	.9907	.8002	.9717	.9526	.8764
7	1.0098	.8383	.9145	.6859	.743	1.0288	.9526
8	.8002	.7811	.7621	.724	.6859	.724	.8383
9	.5906	.724	.362	.6097		.4954	.7049
10	.381	.3429		.3429	.4191	.4763	.381
11	.3048		.1905	.2286	.2096	.381	.1905
12	.3048	.2096	.1524			.2667	.1905
13	.2667	.1905	.1334			.2667	.2667
14	.2667	.1905	.1143		.2286	.2477	.2477
15	.3048	.1905	.2286		.2096	.2858	.2667
16	.3048		.2286	.2858	.3048	.3239	.2667
17	.4191	.2667	.3048	.3048	.3429	.3239	.3429
18	.7621	.4763	.4382	.5335	.4572		.4954
19	.6859	.7049	.724	.7811	.8192	.8002	.7621
20	.5335	.7049	.6097	.6668	.7621	.8573	.5716
21	.381	.4572	.4001	.4191	.4954	.4763	.4191
22	.3048	.3429	.3429	.3429	.381	.381	.362
23	.2667	.3048	.2477	.3048	.3429	.3048	.3048
24	.2477	.2667	.2286	.2477	.2667	.2667	.2286
Max	1.0098	.9526	.9907	.8002	.9717	1.0288	.9526
Min	.2477	.1905	.1143	.2286	.2096	.2477	.1905
Avg	.4533	.4373	.3959	.4382	.4509	.4697	.4406



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 205 / Hanumantkheda gaothan  
feeder Feeder KV- 11 /  
OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2096	.2096	.2286	.2286	.2286	.2286
2	.2096	.2096		.2286	.2286	.2286	.2286
3	.2286	.2286	.2286	.2286	.2477	.2667	.2667
4	.3048	.3048	.3048	.2667	.2858	.3048	.3048
5	.4001	.381	.4191	.3429	.4191	.381	.4191
6	.5906	.6859	.5335	.4001	.6668	.5335	.6097
7	.5335	.4954	.4572	.4763	.4191	.5716	.6097
8	.4763	.4572	.4572	.381	.4954	.4572	.4763
9	.4191	.4001	.381	.3429	.381	.4191	.3429
10	.3429		.2096	.1905	.2096	.3048	.2096
11	.2096		.0953	.1715	.0953	.2286	.1524
12	.1524	.1334	.1143	.1524		.1715	.1334
13	.1524	.1143	.1143	.1143	.2096	.1715	.1524
14	.1334	.1334	.1143		.1905	.1715	.1334
15	.1905	.1334	.1334		.1905	.1905	.1524
16	.2667		.1905	.1715	.2096	.2096	.1524
17	.381	.1905	.2286	.2667	.2667	.2858	.2096
18	.5335	.3239	.362	.3429	.3048	.4191	.381
19	.4191	.4382	.4572	.381	.4572	.4191	.4954
20	.381	.4001	.4191	.4382	.4191	.381	.4763
21	.3048	.3429	.3429	.3429	.381	.3239	.3429
22	.2667	.3048	.2858	.3048	.3429	.3048	.2858
23	.2286	.2477	.2477	.2477	.2667	.2667	.2667
24	.2286	.2667	.2096	.2477	.2286	.2286	.2096
Max	.5906	.6859	.5335	.4763	.6668	.5716	.6097
Min	.1334	.1143	.0953	.1143	.0953	.1715	.1334
Avg	.3159	.3048	.2833	.2849	.3106	.3112	.3017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 206 / Wakdi Gaothan feeder

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0572	.0572	.0762	.0762	.0762	.0762
2	.0762	.0572	.0572	.0762	.0762	.0762	.0762
3	.0953	.0762	.0762	.0762	.0953	.0953	.0953
4	.1143	.1143	.1143	.1143	.1143	.1334	.1334
5	.1905	.2667	.2477	.1905	.1715	.2096	.2096
6	.3048	.3048	.3048	.2858	.3048	.3048	.2858
7	.3048	.2286	.2286	.2477	.3048	.2667	.2477
8	.2286	.2096	.1715	.1905	.2286	.2286	.2096
9	.1905	.1905	.1524	.1334	.1524	.2096	.1524
10	.1334	.1143	.0762	.0762	.0762	.1143	.0953
11	.0762	.0572	.0381	.0381	.0572	.0381	.0572
12	.0572	.0381	.0381	.0381		.0381	.0381
13	.0572	.0381	.0381	.0381	.0762	.0572	.0572
14	.0572	.0572	.0381	.0381	.0762	.0762	.0572
15	.0572	.0572			.0953	.0762	.0572
16	.1143		.0762	.0572	.0762	.0572	.0762
17	.0953	.0762	.0762	.0953	.1143	.0953	.0762
18	.1905	.1334	.1143	.1143	.1143	.1143	.1143
19	.1905	.2096	.1905	.1905	.2096	.1715	.2286
20	.2096	.2096	.1905	.2096	.2667	.1715	.2096
21	.1524	.1524	.1524	.1334	.1905	.1524	.1524
22	.1143	.1143	.1334	.1143	.1524	.1143	.1334
23	.0953	.0953	.0953	.0953	.1143	.0762	.0953
24	.0762	.0762	.0572	.0953	.0953	.0953	.0572
Max	.3048	.3048	.3048	.2858	.3048	.3048	.2858
Min	.0572	.0381	.0381	.0381	.0572	.0381	.0381
Avg	.1358	.1276	.1185	.1185	.1408	.1270	.1247

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 207 / 11 KV GONDEGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.1715	.1524	.1524	
2				.1715	.1524	.1524	.1143
3				.1715	.1524	.1524	.1524
4				.1715	.1524	.1905	.1524
5				.1715	.1524	.2286	.1905
6				.1715	.1524	.2667	.1905
7				.2286	.2667	.381	.2286
8				.3429	.3239	.4954	
9				.381	.381	.5716	.3048
10	.2286	.2667	.3048				
11	.2667	.3429	.381				
12	.2667	.3048	.3429				
13	.2286	.3429	.3048				
14	.2096	.3048	.3048				
15	.2096	.2667	.2667				
16	.1905		.2667				
17	.1524	.2667	.2667				
23						.1143	
24				.1715	.1524	.2286	
Max	.2667	.3429	.381	.381	.381	.5716	.3048
Min	.1524	.2667	.2667	.1715	.1524	.1143	.1143
Avg	.2191	.2994	.3048	.2153	.2038	.2667	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 208 / 11 K V HANUMANT KHEDA SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.1143				
2	.0762	.0762	.1143				
3	.0762	.0762	.1143				
4	.0762	.0953	.1143				
5	.1143	.0953	.1524				
6	.1143	.1143	.1524				
7	.1524	.1524	.1524				
8	.2858	.1905	.2286				
9	.3429	.2286	.2096				
10				.2667	.3429	.2667	.2286
11				.2667	.381	.3048	.3048
12				.2286		.381	.3048
13					.2667	.3429	.3429
14					.4572		.3048
15					.4191	.2667	.3429
16				.2667	.381	.1905	.381
17				.2286	.4191	.1905	.3429
24	.0762	.1524	.1143				
Max	.3429	.2286	.2286	.2667	.4572	.381	.381
Min	.0762	.0762	.1143	.2286	.2667	.1905	.2286
Avg	.1391	.1257	.1467	.2515	.381	.2776	.3191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044018 / 33/11 KV BANOTI SUB STN

Feeder No / Name : 209 / 11 KV GONDEGAON GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2477	.2858	.2667	.2667
2	.2667	.2667	.2667	.2477	.2667	.2667	.2667
3	.2858	.3429	.3429	.2477	.3048	.3048	.3048
4	.3429	.4191	.4191	.3429	.381	.3429	.3429
5	.5335	.4954	.5335	.5335	.4954	.5716	.5335
6	.6859	.7621	.6859	.743	.7621	.6478	.724
7	.6478	.8002	.6478	.724	.724	.7621	.6097
8	.4572	.724	.4954	.5716	.5525	.7049	.4572
9	.4191	.4572	.381	.4572	.4572	.5335	.4191
10	.4191	.3429	.3048	.3429	.4191		.3429
11	.3048	.3048	.2477	.2667	.2667	.0381	.2667
12	.3048	.2667	.2667	.2286		.3048	.2286
13	.2667	.2286	.2667	.2286	.3048	.2667	.2286
14	.3048	.2286	.3048	.2286	.3048	.2667	.2477
15	.3048	.2667	.3048		.2667	.2667	.2667
16	.3429		.381	.3048	.2286	.3048	.2858
17	.3429	.3048	.3239	.3429	.2667	.3429	.3048
18	.4954	.3429	.381	.4001	.3048	.381	.3429
19	.5335	.4572	.5525	.5716	.4954	.4191	.5716
20	.4954	.5716	.5716	.5335	.5716	.4191	.5335
21	.4191	.4954	.4572	.4191	.4954	.381	.4191
22	.3429	.381	.381	.381	.381	.3429	.3429
23	.3048	.3429	.3048	.3429	.3429	.3048	.3048
24	.2667	.2667	.2667	.2667	.3048	.3048	.2667
Max	.6859	.8002	.6859	.743	.7621	.7621	.724
Min	.2667	.2286	.2477	.2286	.2286	.0381	.2286
Avg	.3898	.4059	.3898	.3901	.3993	.3802	.3699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 201 / 11 K V SOYEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6805	.7316	.6783			.8413	.7842
2		.7316				.8048	
3		.7682	.6882				
5						1.134	
6	.8962		.8962				1.1706
7		.9877				.9808	
9			.5792		.6371	.8048	
10	.2926				.4024	.3292	
11					.439	.3658	.2881
12			.3018				
13					.5121	.439	
14	.3658						
15			.3734				
16						.4024	.3277
17			.3395		.4755	.3201	
18	.8779				.9511		.2949
19					1.1706		
20			.9945		1.0974	1.086	
21	.7682						
23	.7316				.8048	.8048	.8048
24		.695	.6805	.7545		.8048	
Max	.8962	.9877	.9945	.7545	1.1706	1.134	1.1706
Min	.2926	.695	.3018	.7545	.4024	.3201	.2881
Avg	.6590	.7828	.6146	.7545	.7211	.7014	.6117

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 202 / 11 K V GALWADA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.6348	.5959			.6584	.6154
2		.6219				.6219	
3						.695	
5		.7316					
6	.8589		.7377			.9511	.8596
7		.695					
9			.4801		.4801		
10	.1829				.439	.4024	
11	.0732				.4755	.4755	.2881
12	.1097		.3734		.4755	.4024	
14						.439	
15			.3395				
16					.439	.4024	.2881
17	.2804		.394		.4755		
18					.6219		
19					.9145	.8238	
20			.8505				.7964
22	.4108						
23	.6639				.6584	.6154	.6584
24		.6219	.6401	.6859	.6516	.6219	
Max	.8589	.7316	.8505	.6859	.9145	.9511	.8596
Min	.0732	.6219	.3395	.6859	.439	.4024	.2881
Avg	.4031	.6610	.5514	.6859	.5631	.5924	.5843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 203 / JARANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2	.112	.2743		.2865	.2926	
2		.1463				.2926	
3		.1463	.1357				
4						.3292	
5						.4024	
6	.2439		.2012				.16
7		.2195					
9	.2195		.2743			.2561	.2561
10	.1463				.3658		
11					.3658		
12			.3018		.439		.1791
13					.4755		
14	.1097			.2622			
15			.3018				
17			.3018		.3734	.2881	.0716
18					.3292		
19	.4024						
20	.3658		.3326		.4024		
23	.3292				.3292	.2865	.1097
24		.1097	.1494	.2743	.2012	.2926	
Max	.4024	.2195	.3326	.2743	.4755	.4024	.2561
Min	.1097	.1097	.1357	.2622	.2012	.2561	.0716
Avg	.2521	.1468	.2525	.2683	.3568	.3050	.1553



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044035 / SOYGOAN

Feeder No / Name : 205 / 11KV LIHA FEEDER

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.032		.0343	
9		.0716		.0686	
10	.0732				.0983
11	.0732				
12	.1097				.0983
17	.1097				.1296
24		.1341	.1029	.1029	
Max	.1097	.1341	.1029	.1029	.1296
Min	.0732	.032	.1029	.0343	.0983
Avg	.0915	.0792	.1029	.0686	.1087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 202 / 11 kv DEVHARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0572	.0953	.0381	.0381	
2	.0191	.0191	.0572	.0953	.0381	.0381	
3	.0191	.0191	.0572	.0953	.0381	.0381	
4	.0191	.0191	.0572	.0953	.0381	.0381	
5	.0191	.0191	.0572	.0953	.0381	.0762	
6	.0191	.0191	.0572	.0953	.0953	.0762	
7		.0191	.0572	.0953	.1143	.1334	
8		.0381	.0762	.1715	.1334	.1143	
9	.0191	.0381	.0762	.1524	.2096	.1524	
10							.0381
11							.0381
12							.0762
13							.0572
14							.0572
15							.0572
16							.0762
17							.1143
24		.0191	.0572	.0953	.0381	.0381	
Max	.0191	.0381	.0762	.1715	.2096	.1524	.1143
Min	.0191	.0191	.0572	.0953	.0381	.0381	.0381
Avg	.0191	.0229	.061	.1086	.0781	.0743	.0643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 203 / 11 kv MOLKHEDA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0381
2							.0381
3							.0381
4							.0381
5							.0381
6							.0381
7							.0381
8							.0762
9							.0762
10	.0381	.2858	.1715	.2477	.1905		
11	.0191	.362	.2096	.2858	.3048	.0762	
12	.0191	.1715	.1905	.2858	.3048	.1524	
13	.0381	.1715	.1715	.1905	.3429	.1143	
14	.0191	.1905	.1715	.1905	.3048	.0762	
15	.0191	.1905	.1715	.1905	.3048	.0762	
16	.0381	.2096	.2096	.1905	.3429	.0762	
17	.0191	.2858	.2286	.0381	.3048	.0762	
24				.2163			.0381
Max	.0381	.362	.2286	.2858	.3429	.1524	.0762
Min	.0191	.1715	.1715	.0381	.1905	.0762	.0381
Avg	.0262	.2334	.1905	.2040	.3000	.0925	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 204 / 11 KV SAWALADBARA GAOTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0953	.0953	.0953	.0953	.0953
2	.0953	.1143	.0953	.0953	.0953	.0953	.0953
3	.1143	.1524	.1143	.1143	.1143	.0953	.0953
4	.1524	.1905	.1334	.0762	.1334	.0953	.0953
5	.1524	.2096	.1334	.1334	.1334	.1143	.1143
6	.1905	.1905	.1524	.1524	.1524	.1524	.1715
7	.1905	.1715	.1524	.1524	.1524	.1524	.1524
8	.1524	.1334	.1524	.1334	.1334	.1524	.1524
9	.1334	.1334	.1334	.1334	.1143	.1143	.1334
10	.0953	.0762	.1143	.1143	.0953	.0953	.1143
11	.0762	.0572	.0953	.0953	.0762	.0953	.1143
12	.0762	.0572	.0572	.0953	.0762	.0762	
13	.0762	.0572	.0572	.0572	.0762	.0762	.0572
14	.0953	.0762	.0572	.0572	.0762	.0762	.0572
15	.0953	.0953	.0572	.0762	.0762	.0762	.0953
16	.1143	.1143	.0762	.0953	.0953	.0953	.0953
17	.1334	.1143	.1334	.1143	.1143	.1143	.1143
18	.1524	.1334	.1524	.1334	.1334	.1334	.1334
19	.1905	.1524	.1715	.1524	.1524	.1524	.1524
20	.2096	.1524	.1715	.1715	.1524	.1524	.1715
21	.1905	.1524	.1524	.1715	.1334	.1334	.1715
22	.1524	.1524	.1524	.1524	.1143	.1143	.1524
23	.1334	.1334	.1334	.1334	.1143	.1143	.1334
24	.0953	.1143	.1143	.1143	.1143	.1143	.1143
Max	.2096	.2096	.1715	.1715	.1524	.1524	.1715
Min	.0762	.0572	.0572	.0572	.0762	.0762	.0572
Avg	.1318	.1270	.1191	.1175	.1135	.1119	.1210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044055 / 33/11 KV SAWALADBARA

Feeder No / Name : 205 / 11KV Molkheda Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	31-AUG-17	01-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)
23	.3258		.4938
24		.352	
Max	.3258	.352	.4938
Min	.3258	.352	.4938
Avg	.3258	.352	.4938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 201 / 11 KV KINHI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1715	.1715	.1715	.0381	.0381	.0572
2	.1334	.1753	.1524	.2096	.0381	.0381	.0572
3	.1334	.1715	.1905	.2477	.0381	.0381	.0572
4	.1334	.1886	.1905	.2477	.0381	.0381	.0572
5	.1715	.1886	.2096	.2858	.0381	.0572	.0572
6	.1905	.1844	.2858	.2858	.0572	.0572	.0572
7	.2096	.2515	.3239	.3239	.0381	.0572	.0572
8	.2858	.3048	.4001	.381	.0381	.0572	.0572
9	.3048	.4572	.4382	.5144	.0572	.0572	.0572
10	.0191	.0381	.0381	.3772	.4954	.7049	.0381
11	.0191	.0381	.0381	.4024	.7049	.8383	.0381
12	.0381	.0381	.0381	.503	.8192	.9717	.0381
13	.0381	.0381	.0381	.5407	.9526	1.0669	.0381
14	.0381	.0381	.0381	.5898	.9526	1.105	.0381
15	.0381	.0381	.0381	.5898	.9335	1.0669	.0381
16	.0381		.0381	.5571	1.0669	1.1241	.0381
17	.0381	.0381	.0381	.5243	.9717	.8002	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0572	.0381	.0381
20	.0381	.0381	.0381	.0381	.0572	.0381	.0381
21	.0381	.0381	.0381	.0381	.0572	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.1334	.1543	.1334	.1143	.0381	.0381	.0381
Max	.3048	.4572	.4382	.5898	1.0669	1.1241	.0572
Min	.0191	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0969	.1193	.1262	.2956	.3167	.3493	.0453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 202 / 11 KV KINHI GAOTHAN GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2804	.2858	.2477	.2629	.2858	.2477
2	.2858	.2804	.2858	.2477	.2629	.2858	.2477
3	.2858	.2804	.2667	.2401	.3155	.2858	.3048
4	.362	.3155	.3048	.2915	.3086	.3239	.3048
5	.4382	.3681	.3429	.3429	.3772	.4001	.4382
6	.5906	.6036	.381	.4115	.5365	.743	.5525
7	.5906	.503	.5335	.3521	.5365	.5525	.4763
8	.4954	.5335	.5716	.3353	.5144	.5144	.381
9	.4954	.381	.4763	.2572	.4115	.4191	.362
10	.4001	.2858	.381	.2572	.3429	.381	
11	.3155	.0191	.2667	.1578	.1905	.2858	.2096
12	.1715	.1905	.2477	.1578	.1715	.2286	.1905
13	.1928	.1905	.1905	.1372	.1905	.2096	.1905
14	.1886	.2096	.1715	.1543	.1905	.2096	.1905
15	.2103	.2477	.2096	.1715	.1905	.1905	.2096
16	.2743		.2286	.2058	.1524	.2477	.2477
17	.3258	.3048	.2477	.2229	.2286	.2858	.2667
18	.5316	.3429	.3239	.3429	.3048	.4001	.3429
19	.5144	.381	.5716	.5487	.5716	.5906	.5525
20	.3772	.5716	.5144	.5144	.5716	.4001	.5906
21	.4458	.5144	.381	.3944	.381	.3048	.4763
22	.3258	.381	.2858	.3086	.3048	.3048	.362
23	.2572	.3048	.2667	.2743	.2858	.2667	.2858
24	.2667	.2629	.2858	.2477	.2629	.2858	.2477
Max	.5906	.6036	.5716	.5487	.5716	.743	.5906
Min	.1715	.0191	.1715	.1372	.1524	.1905	.1905
Avg	.3587	.3371	.3342	.2842	.3277	.3501	.3338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044084 / 33/11 KV KINHI SUB STN

Feeder No / Name : 203 / 11 KV WADGAON AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.0381	.1052	.0762	.0762
2	.0572	.0381	.0381	.0381	.1052	.0762	.0762
3	.0572	.0381	.0381	.0381	.1052	.0762	.0762
4	.0572	.0381	.0381	.0381	.1029	.0762	.0762
5	.0572	.0381	.0381	.0381	.1029	.0762	.0762
6	.0572	.0381	.0381	.0381	.1029	.0953	.0953
7	.0572	.0381	.0381	.0381	.1372	.2096	.1524
8	.0572	.0381	.0191	.0381	.2683	.2477	.1905
9	.0572	.0381	.0381	.0381	.3018	.362	.2096
10	.0762	.0572	.0953	.0381	.0381	.0572	.2477
11	.0686	.0762	.1143	.0381	.0381	.0572	.2286
12	.1029	.1143	.1143	.0381	.0572	.0381	.2667
13	.1029	.1143	.1334	.0381	.0381	.0381	.2477
14	.1052	.1143	.1715	.0381	.0381	.0381	.2858
15	.1052	.1143	.1524	.0381	.0381	.0572	.3048
16	.1029		.1715	.0381	.0381	.0381	.2667
17	.1052	.1334	.1905	.0381	.0381	.0572	.2286
18	.0381	.0381	.0381	.0381	.0381	.0572	.0381
19	.0381	.0381	.0381	.0381	.0572	.0572	.0381
20	.0381	.0381	.0381	.0381	.0572	.0572	.0381
21	.0381	.0381	.0381	.0381	.0572	.0572	.0381
22	.0381	.0381	.0381	.0381	.0572	.0572	.0381
23	.0381	.0381	.0381	.0381	.0762	.0572	.0381
24	.0572	.0381	.0381	.0381	.0732	.0762	.0762
Max	.1052	.1334	.1905	.0381	.3018	.362	.3048
Min	.0381	.0381	.0191	.0381	.0381	.0381	.0381
Avg	.0654	.0580	.0722	.0381	.0863	.0873	.1421



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 201 / 11Kv Ghosla new SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6478	.381	.362	.6668	.6668	.6859
2	.6859	.724	.4191	.381	.724	.6859	.6668
3	.724	.8383	.5335	.4001	.7621	.6478	.724
4	.9907	.9145	.5716	.4191	.6859	.6668	1.4098
5	1.2193	.9907	.5906	.4572	.6478	.6478	1.5623
6	1.3336	1.2193	.6097	.6287	.724	.6668	1.5432
7	1.5051	1.5051	.6287	.8192	.7049	.724	1.467
8	1.2384	1.1812	.6668	.7811	.724	.7621	.1143
9	1.1241	.9907	.6478	1.2955	.743	.7621	.9717
10	.4763	.4572	.6097	.5716	.5716	.724	.8383
11	.4382	.4382	.5716	.4382	.4382	.4954	.5335
12	.4191	.4191	.4954	.4001	.4001		.4763
13	.4001	.4001	.4191	.4191	.4572		.5335
14	.381	.381	.4382		.4954	.5716	.4572
15	.4382	.4763	.4763	.4382	.5525	.5335	.5335
16	.4001	.6287	.5144	.5144	.5525	.724	.4763
17	.4763	.724	.5525	.5525		.743	.4382
18	1.0098	.8764	.7049	.6668		.8383	.6478
19		.9145	.8573	1.1622	1.2003	1.2384	.8002
20	1.0479		.9717	1.2193	1.086	1.0098	.9907
21		.8573	.9145	1.0098	.8954	.9907	1.0098
22	.7621	.743	.7621	.8002	.8573	.724	.8383
23	.6097	.6287	.6097	.6478	.6859	.6668	.7049
24	.6668	.5716	.5335	.381	.6097	.6287	.6859
Max	1.5051	1.5051	.9717	1.2955	1.2003	1.2384	1.5623
Min	.381	.381	.381	.362	.4001	.4954	.1143
Avg	.7784	.7621	.6033	.6420	.6902	.7327	.7962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 202 / 11Kv Bahulkheda new SINGLE PHASING  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7049	.9145	.7621	.6097	.9526	.6097
2	.8764	.724	.9526	.8383	.5716	1.0098	.5906
3	.9145	.8002	1.0479	.8002	.6287	1.0479	.5716
4	.9526	.6668		.7621	.5906	1.105	.6478
5	.9907	.6478		.7811	.6097	1.2003	.6287
6	.9335	.5906		.8002	.5906	1.2955	.6097
7	.8573	.5716		.8383	.6859	1.0669	.6478
8	.8002			.7621	.4954	.9335	.4763
9	.6668	.7049		.6287		.8383	.5906
10	.4763	.4382	.6668	.5906	.5525	.6478	.6478
11	.4191	.4572	.6287	.4572	.5906	.5716	
12	.4763	.4763	.5716	.4572	.5335	.4954	.4191
13	.4572	.4954	.5144	.4763	.5716	.4763	.6287
14	.4954	.5144	.5525	.4954	.5906	.5525	.6859
15	.4763	.5525	.6287	.5335		.5525	.7049
16	.4954	.6097	.6859	.4954			.7049
17	.6097		.743	.5144		.5335	.724
18	.7049		.8383	.5716		.724	.9717
19		.8383	.8573	.8764	.8573	.8764	.8383
20	.724	.9145	.8192	.6859	.9717	.724	.724
21	.6859	.9907	.8002	.6287	1.0098		.6478
22	.6859	1.0288	.8192	.5716	.9907	.6478	.5716
23	.6668	.9907	.8002	.5906	.8383	.5906	1.0479
24	.8192	.6668	.9526	.7621	.5716	.8764	.6097
Max	.9907	1.0288	1.0479	.8764	1.0098	1.2955	1.0479
Min	.4191	.4382	.5144	.4572	.4954	.4763	.4191
Avg	.6966	.6850	.7663	.6533	.6769	.8054	.6652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

AJANTHA(R) S/SN[405] BU 7242

Substation No/ Name :- 044106 / 33/11 kv JARANDI

Feeder No / Name : 203 / 11Kv Jarandi new SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	1.0288	.9907	.9907	1.1241	1.1622	1.0098
2	.9145	1.105	1.0479	1.105	1.2193	1.2955	.9907
3	.8954	.9907	1.105	1.1812	1.3336	1.4098	1.0669
4	.9907	1.0098	1.1812	1.2955	1.5432	1.5623	1.1431
5	1.2384	1.1812	1.3336	1.448	1.7528	1.6766	1.2193
6	1.3717	1.2193	1.5623	1.6766	1.9624	1.829	1.2955
7	1.3336	1.2955	1.829	1.829	1.8671	1.7147	1.2193
8	1.2193	1.0098	1.4289	1.3146	1.4098	1.4098	1.1241
9	.9717	1.1431	1.2193	1.086	1.0098	1.0669	1.0669
10	.743	.9907	.9907	1.0288	1.0098	.9717	.9145
11	.724	.9526	.9526	1.0669	1.1431	1.0098	.8002
12	.6668	.8954	.8764	.8954	1.1812		.8764
13	.6287	.8192	.8383	.9526	1.105		.743
14	.6478	.7621	.8573	.9907	1.1431	1.2765	.8002
15	.8383	.9145	.8954		1.4098	1.2193	.8383
16	.9526	1.0479	.9145	1.0479	1.3336	1.2384	.8192
17	1.0669		.9335	1.1431		1.086	.8002
18	1.2003	1.3146	.8383	1.2384		1.1431	1.0288
19		1.2955	1.105	1.3527	1.3336	1.2384	1.1812
20	1.448	1.2765	1.3336	1.3908	1.5051	1.2765	1.2765
21	1.2193	1.2574	1.2574	1.2003	1.3527	1.2193	1.2193
22		1.1431	1.1431	1.105	1.2003	1.105	1.1431
23		1.0288	.9907	1.0288	1.0669	1.0098	1.0479
24	.8383	1.0288	.9907	.9335	.9907	1.105	1.0288
Max	1.448	1.3146	1.829	1.829	1.9624	1.829	1.2955
Min	.6287	.7621	.8383	.8954	.9907	.9717	.743
Avg	.9889	1.0744	1.1090	1.1870	1.3180	1.2739	1.0272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 201 / 11 KV JAWLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0522	.0622	.0658	.3795	.5228	.0549	.506
2	.5376	.0677	.075	.3029	.6722	.0658	.7282
3	.6535	.075	.0951	.4428	.7282	.0768	.7432
4	.5535	.0841	.1225	.7468	.8962	.1061	.7907
5	.6325	.1134	.1463	.7282	1.307	.128	1.0279
6	.9488	.128	.1738	.9149	1.8111	.15	1.0911
7	1.439	.1427	.1573	1.587	1.7737	.1719	.4744
8	1.419	.1189	.1244	.9335	1.5123	.1536	.68
9		.0988	.0951	.9149	.1097	.1207	.8223
10	.3734	.0494	.047		.0567	.0437	.5975
11	.3077	.0389	.3605	.4854	.0583	.4902	.2987
12	.2429	.0356	.2688	.3953	.0599	.4902	.2241
13	.3563	.0356	.3163	.4108	.0615	.4902	.2987
14	.3239	.034		.3239	.0453	.506	.2241
15	.3725	.0308	.427	.4858	.0389	.4744	.1943
16	.3401	.0291	.4744	.421	.0453	.3953	.2614
17	.3563	.0372	.5415	.6535	.0421	.2846	.3547
18	.9896			.3921	.053	.3361	
19	1.4563	.0896	.9335	1.3443	.1353	1.419	1.3443
20	1.1389	.1225	1.3817	1.3256	.1445	.9335	1.251
21	.8029	.0805	.9335	1.3256	.0988	.7545	.8962
22	.7095	.0713	.9149	.6535	.0786	1.1831	.7842
23	.6348	.0622	.5975	.6161	.0677	.5144	.5975
24	.4744	.0585	.0585	.8447	.5788	.0585	.6535
Max	1.4563	.1427	1.3817	1.587	1.8111	1.419	1.3443
Min	.0522	.0291	.047	.3029	.0389	.0437	.1943
Avg	.6572	.0724	.3777	.7230	.4541	.3917	.6454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 202 / 11 KV KHAMGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.0729	.0713	.7907	.7125	.0826	.7842
2	.9335	.081	.0745	.7116	.7449	.8421	.9522
3	1.0269	.0842	.081	.6642	.7287	.0794	1.1203
4	1.2136	.0858	.0777	.7907	.8097	.0745	1.1022
5	1.307	.0729	.0761	.933	.7611	.0842	1.3256
6	1.3441	.1134	.0729	.9488	.8097	.0988	1.4937
7	1.6617	.1279	.1296	.0988	.9717	.1036	.1774
8	1.1069	.1409	.1134		1.0526	.1279	1.6804
9	1.4074	.1134	.1198		.081	.1328	1.307
10	.9335	.0823	.0951		.0841	.0914	1.4074
11	.8402		.7282		.0713	1.0269	1.2492
12	.9335	.064	.7468	.7748	.0457	1.0456	1.3765
13	.9335	.053	.6535	.9335	.0549	.9335	1.2955
14	.9149	.0585	.5601	.5601	.053	.8402	1.2136
15	.9335	.0567	.5415	.6535	.0549	.9149	1.307
16	1.0269	.0549	.5601	.7282	.064	.7701	1.2146
17	1.1203	.0786	.7282	.8402	.0695	.9335	1.1336
18	1.1389	.0914	.7468	.7468	.0732	.9335	.9522
19	1.307	.128	.7282	.8402	.0914	.9149	.9335
20	1.2136	.1353	.7842	.8962	.1408	.8775	.9149
21	1.1203	.1116	.8402	.9335	.128	.9335	.8775
22	1.1389	.0951	.8962	.9149	.1006	.9149	.9335
23	1.1203	.0988	.9149	.4763	.0914	.7468	1.0269
24	1.2136	.068	.081	.081	.7773	.0777	.7282
Max	1.6617	.1409	.9149	.9488	1.0526	1.0456	1.6804
Min	.8402	.053	.0713	.081	.0457	.0745	.1774
Avg	1.1153	.0899	.4342	.7159	.3572	.5659	1.1045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044023 / 33 KV AURALA

Feeder No / Name : 203 / 11 KV pedakwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601		.034	.4744	.3401	.0356	.3688
2	.5415		.0372	.6009	.3725	.0389	.3921
3	.6001		.0405	.6167	.4049	.047	.3734
4	.7282		.0421	.6325	.4049	.0518	.4481
5	.8402		.0502	.6642	.502	.0583	.4854
6	.9335		.0632	.7116	.6316	.0664	.8402
7	1.1203		.0761	.7748	.7611	.0761	.7842
8	.7116		.0826		.8259	.0988	.5601
9	.7748	.0777	.081	.6325	.0826	.0842	.5415
10	.9335	.0732	.0604	.6167	.064	.0658	.5535
11	.5601	.0274	.4108	.4748	.0567	.6706	.6325
12	.4668	.0219	.4294	.2372	.0274	.5415	.7935
13	.5041	.0183	.3734	.3734	.0183	.2801	.7611
14	.5601	.0146	.3734	.4668	.0128	.1867	.4854
15	.4668	.0165	.3547	.3547	.0165	.2801	.5975
16	.5415	.0183	.2801	.2801	.0183	.3921	.7935
17	.5601	.0366	.5601	.6535	.0219	.3734	.5668
18	.6535	.0329	.5415	.5415	.0274	.3921	.5601
19	.7282	.0549	.5601	.5601	.0549	.7282	.3921
20	.8402	.0732	.5228	.6535	.0732	.7468	.7468
21	.9335	.0567	.5228	.7468	.064	.7282	.7282
22	.6535	.053	.5415	.5415	.053	.7468	.4108
23	.5601	.0457	.0467	.4668	.0494	.7282	.5788
24	.6161	.0405	.0356	.0648	.4858	.0389	.6535
Max	1.1203	.0777	.5601	.7748	.8259	.7468	.8402
Min	.4668	.0146	.034	.0648	.0128	.0356	.3688
Avg	.6829	.0413	.2550	.5278	.2237	.3107	.5853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 201 / 11 KV WADALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5676	.5144	.5493	.5834	.4801	.5828	.5658
2	.5493	.5658	.5493	.5834	.4287	.5828	.6516
3	.5859	.6001	.6042	.6381	.463	.6375	.703
4	.7324	.7373	.7324	.8022	.5316	.8925	.8402
5	.8971	1.0117	.9338	1.1304	.6516	1.2203	.8402
6	1.0985	1.2003	1.0985	1.3857	.7202	1.3842	.8402
7	1.3182	1.0631	1.1352		.7545	1.1657	.9259
8	1.2084	.9259	.9887		.7545	1.2385	1.4403
9	1.0253		.6591		.583	1.02	1.7833
10	.8422	.7202	.9704	.8573	1.1145	1.7121	.4287
11	.8059	.9338	1.1547	.9431	1.492	1.749	.2732
12	.7888	.9704	1.094	1.1317	1.5829	1.869	.2732
13	.7888	.9338	1.1304	1.2174	1.6739	1.3717	.2545
14	.823	1.0619	1.1304	1.2689	1.4556	1.406	.2545
15	.7888	1.0985	1.1304	1.2689	1.7849	1.4403	.2908
16	.823	.9887	1.1487	1.2174	1.8214	1.4403	.3999
17	.823	1.0436	1.2034	1.4403	1.8396	1.3375	.3999
18	.7545	.476	.4558	.5316	.4194	.6001	.3999
19	1.2689	.9521	1.0393	.823	1.1293	.9602	.9088
20	1.0802	.8788	1.3675	1.0631	1.0928	1.0631	1.0905
21	.9431	.769	.9663	.8962	.9107	.823	.8361
22	.6344	.6591	.7658	.6859	.765	.6344	.6907
23	.5487	.5859	.6199	.5487	.6375	.583	.6543
24	.5859	.5316	.5493	.6199	.4801	.5828	.4973
Max	1.3182	1.2003	1.3675	1.4403	1.8396	1.869	1.7833
Min	.5487	.476	.4558	.5316	.4194	.5828	.2545
Avg	.8451	.8357	.9157	.9351	.9820	1.0957	.6768

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 202 / 11KV NIMDONGRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3932	.333	.3753	.4289	.4031	.3574	.4207
2	.3932	.3681	.3574	.4289	.4031	.3574	.4382
3	.4468	.4557	.3217	.4646	.4382	.3574	.4908
4	.5183	.5434	.4468	.6612	.4908	.5004	.5609
5	.5719	.7011	.5004	.9293	.5434	.6612	.631
6	.7327	.8764	.5719	1.0722	.631	.8221	.7011
7	.8578	.7712	.6791	.8935	.6661	.6791	.8413
8	.6433	.6485	.5719	.7148	.6485	.4344	1.0166
9	.5004	.4557	.3038	.4468	.4207	.3574	1.0692
10	.554	.631	.6433	.7186	.8413	1.108	.333
11	.6135	.7327	.7514	1.0867	1.1795	1.4723	.1787
12		.7684	.7506	.929	1.2702	1.5074	.1608
13	.5959	.6433	.6564	1.0692	1.3238	1.262	.1608
14	.5609	.6791	.6255	1.1393	1.0555	1.3146	.1608
15	.5609	.6433	.7148	.9991	1.1807	.9114	.161
16	.5959	.6791	.7684	1.0341	1.1986	1.1218	.1789
17	.5609	.697	.7863	1.1393	1.2881	.8764	.2683
18	.3681	.2859	.2681	.3155	.2505	.3506	.2683
19	.6135	.5719	.5897	.5959	.6083	.5784	.6261
20	.5959	.5897	.6791	.6485	.6977	.631	.6798
21	.5434	.5361	.5719	.5784	.6083	.5609	.6083
22	.4908	.5183	.5183	.5083	.5009	.4908	.5188
23	.4031	.4468	.4646	.4207	.4472	.4557	.4294
24	.3932	.3856	.3932	.4289	.3856	.3578	.4207
Max	.8578	.8764	.7863	1.1393	1.3238	1.5074	1.0692
Min	.3681	.2859	.2681	.3155	.2505	.3506	.1608
Avg	.5438	.5817	.5546	.7355	.7284	.7302	.4718



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 203 / 11 KV NANDGIRWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2037	.1907	.2377	.2037	.208	.2719	.3294
2	.2207	.208	.2546	.2037	.208	.3059	.3814
3	.2207	.2427	.3056	.2377	.2427	.3399	.4508
4	.2377	.2947	.3395	.3056	.3121	.3739	.6415
5	.2716	.3814	.3735	.3395	.3814	.4079	.7975
6	.2886	.4854	.3735	.3735	.4854	.4419	.9015
7	.2886	.4508	.3904	.4244	.5028	.5778	.7628
8	.3904	.6241	.4414	.4923	.6415	.7478	.6241
9	.4244	.4681	.4923	.4923	.6241	.7308	.5548
10	.4074	.3467	.3395	.4508	.4334	.5098	.5201
11	.3294	.3056	.2716	.2947	.3399	.3467	.4588
12	.2427	.2546	.2546	.2774	.3059	.3814	.5438
13	.2427	.2716	.2377		.3059	.2947	.4928
14	.2774	.2546	.2546		.3229	.3467	.5608
15	.2427	.2716	.2716		.3059	.3294	.5098
16	.2774		.2716	.3294	.3909	.3294	.6595
17	.3467	.3056	.3395	.3121		.3641	.6968
18	.4334	.3904	.3225	.4334	.4249	.4161	.3059
19	.6762	.5941	.5262	.5895	.6628	.6241	.5948
20	.6241	.6451	.696	.6588	.7138	.6762	.6118
21	.5548	.5772	.5432	.5375	.6288	.5721	.5778
22	.4854	.5432	.4923	.5548	.5268	.5548	.5438
23	.4508	.4414	.4414	.4854	.4928	.4508	.5438
24	.1867	.1907	.2207	.2037	.208	.2379	.4161
Max	.6762	.6451	.696	.6588	.7138	.7478	.9015
Min	.1867	.1907	.2207	.2037	.208	.2379	.3059
Avg	.3468	.3799	.3621	.3905	.4204	.443	.5617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 204 / 11KV HIWARKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.3155	.3121	.3467	.3681	.5207	.333
2	.3641	.333	.3467	.3467	.3681	.5554	.3506
3	.3814	.3681	.4161	.3814	.4207	.5901	.3856
4	.4161	.3681	.4854	.3814	.5083	.6248	.4031
5	.4508	.3681	.5201	.4161	.6485	.6595	1.2445
6	.4681	.4207	.5548	.4334	.8063	.6943	1.3321
7	.4854	.5434	.5721	.5093	.8764	1.0587	1.1568
8	.6935	.7712	.7802	.7108	1.0867	1.4406	.9991
9	.7455	.8939	.9189	.9882	1.0517	1.5621	.8764
10	.6068	.4908	.4508	.5784	.6135	.6595	.7537
11	.4557	.4161	.3814	.4382	.4686	.5258	.972
12			.3467	.4207		.6485	1.0587
13	.4557		.3467			.5258	1.3364
14	.4031	.4334	.3814		.5039	.5959	.9199
15	.4207	.4854			.538	.631	1.0761
16	.4733		.3988	.4733	.538	.7186	1.3885
17	.5784	.5028	.5375	.5434		.7537	1.6489
18	.6661	.4854	.5548	.631	.6595	.7537	.781
19	.8063	.6935	.7455	.8413	.8678		.8852
20	.8063	.7455	.8322	.8764	.9372	.8939	.972
21	.7362	.6935	.7455	.7186	.8678	.929	.9372
22	.7011	.6588	.6762	.7712	.781	.8764	.8678
23	.6485	.6068	.6588	.5434	.7984	.8063	.8157
24	.3294	.3155	.2947	.3294	.3856	.486	.631
Max	.8063	.8939	.9189	.9882	1.0867	1.5621	1.6489
Min	.3294	.3155	.2947	.3294	.3681	.486	.333
Avg	.5408	.5195	.5329	.5562	.6711	.7613	.9219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044042 / 33KV CHIKALTHAN

Feeder No / Name : 205 / 11KV BAHIRGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2951	.3898	.3818	.3645	.5316	.6255	.5316
2	.3298	.4252	.4513	.3818	.5493	.6603	.5493
3	.3818	.4961	.5207	.3818	.6201	.7471	.5493
4	.4339	.5493	.5554	.486	.691	1.0252	.567
5	.486	.6556	.6248	.5554	.9214	.9035	.8682
6	.5207	.7973	.6769	.6075	1.134	.9383	1.1694
7	.538	.7973	.6943	.7506	1.1694	1.2163	1.1517
8	.6769	.8859	.8331	.6943	1.2226	1.3032	1.0454
9	.7116	.8859	.781	.9199	1.1517	1.3727	.7796
10		.5138	.538	.6201	1.1871	.6081	.6024
11	.3366	.4339	.3818	.4075		.3898	6.481
12			.2603	.4024	.4344	.443	.7993
13	.4075	.3298	.2777	.4075	.4344	.3189	.8861
14	.3898	.3298	.3298	.3856	.3996	.1949	.9035
15	.3721	.3645	.3298	.3898	.3996	.2303	.9556
16	.4252	.3992	.3818	.4075	.4691	.4607	.8861
17	.5847	.4513	.4166	.5138	.4691	.567	.973
18	.7973	.6248	.5901	.7265	.5734	.6556	.556
19	1.0277	1.024	.7463	.9568	.9383		.9556
20	1.0454	1.0587	1.0414	1.0808	1.1815	1.0631	
21	1.0277	.9199	.972	.9745	.973	.9391	.9556
22	.9391	.8678	.8505	.9036	.9556	.8859	.7298
23	.7796	.729	.7637	.7442	.8166	.7265	.7471
24	.3818	.4252	.3471	.3645	.5316	.5908	.6556
Max	1.0454	1.0587	1.0414	1.0808	1.2226	1.3727	6.481
Min	.2951	.3298	.2603	.3645	.3996	.1949	.5316
Avg	.5858	.6241	.5728	.6011	.7719	.7333	1.0564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 201 / 11 KV WADNER AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1551	.1241	.1402	.1551	.0465	.1753	.0775
2	.1551	.1241	.1241	.1551	.0465	.1753	.0775
3	.1551	.1241	.1241	.1551	.0465	.1753	.0775
4	.1551	.1551	.1241	.1551	.0465	.2103	.0775
5	.1551	.1861	.1551	.1551	.062	.2629	.0775
6	.1861	.2326	.2326	.1551	.062	.2629	.0775
7	.2326	.2326	.3877	.2326	.0465	.3506	.0775
8	.2326	.2481	.3877	.2326		.3506	.0775
9	.2326	.3102	.3877	.2326		.3506	.0775
10	.0155	.0155	.0155	.031		.031	.1551
11	.0155	.0175	.0155	.0155		.031	.1551
12	.0155	.0175	.0155	.0155		.0155	.2326
13	.0155	.0175	.0155	.0155	.3506	.0155	.5428
14	.0155		.0155	.0155	.3506	.0155	.4652
15	.0155		.0155	.0155	.3506	.0155	.3877
16	.0155	.0175	.0155	.0155	.3155	.0155	.3877
17	.0155	.0175	.0155	.0155	.0351	.0155	.3877
18	.0155	.0351	.031	.0155	.0526	.0465	.0155
19	.0465	.0526	.0775	.031	.0526	.0775	.031
20	.062	.0351	.0775	.0465	.0526	.0775	.062
21	.0465	.0351	.0775	.0465	.0526		.062
22	.0465	.0351	.0775	.0465	.0526	.0775	.0465
23	.031	.0351	.0775	.0465	.0526	.0775	.031
24	.093	.1515	.1052	.1241	.0465	.1052	.0775
Max	.2326	.3102	.3877	.2326	.3506	.3506	.5428
Min	.0155	.0155	.0155	.0155	.0351	.0155	.0155
Avg	.0885	.1009	.1130	.0885	.1116	.1274	.1557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 202 / 11 KV AMBA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0791	.0701	.0786	.0791	.0351	.0786
2	.0943	.0791	.0629	.0786	.0791	.0351	.0786
3	.0943	.0791	.0629	.0786	.0791	.0351	.0786
4	.0943	.0791	.0629	.0786	.0791	.0351	.0786
5	.0943	.0791	.0629	.0786	.0949	.0526	.0786
6	.0943	.0949	.0943	.0786	.0949	.1402	.0786
7	.0943	.0949	.0943	.0786		.1402	.0786
8	.0943	.0791	.0472	.0786		.1402	.0786
9	.0943	.0949	.0314	.1257		.1402	.0786
10	.0157	.0791		.0786		.0314	.1572
11	.0158	.1052		.1265	.298	.0314	.1581
12	.0158	.1227		.1581	.0351	.0157	.1265
13	.0158	.0876		.3016	.0351	.0157	.1265
14	.0158	.0876	.0786	.0158	.0351	.0157	.1265
15	.0158	.0876	.0786	.0158	.0351	.0157	.1265
16	.0158	.0876	.0786	.0316	.0351	.0157	.2372
17	.0158	.0701	.0786	.0158	.0351	.0157	.2372
18	.0158	.0351		.0316	.0351	.0472	.0316
19	.0791	.0526		.0791	.0351	.0786	.0949
20	.0791	.0701	.0786	.0791	.0351	.0786	.0791
21	.0791	.0701	.0786	.0791	.0351	.0786	.0791
22	.0791	.0701	.0786	.0633	.0351	.0786	.0791
23	.0791	.0701	.0786	.0633	.0351	.0786	.0791
24	.0786	.0791	.0876	.0786	.0791	.0351	.0786
Max	.0943	.1227	.0943	.3016	.298	.1402	.2372
Min	.0157	.0351	.0314	.0158	.0351	.0157	.0316
Avg	.0610	.0806	.0725	.0822	.0652	.0578	.1052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 203 / 11 KV KOLWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0774	.0464	.0701	.0774	.0464	.0351	.0774
2	.0774	.0464	.0309	.0774	.0464	.0351	.0774
3	.0774	.0464	.0309	.0774	.0464	.0351	.0774
4	.0774	.0774	.0464	.0774	.0619	.0351	.0774
5	.0774	.0774	.0464	.0774	.0774	.0351	.0928
6	.0774	.0774	.0464	.0774	.0774	.0351	.1238
7	.0774	.0774	.0464	.0774	.0774	.0526	.1547
8	.0774	.0774	.0464	.0774	.0774	.0526	.2321
9	.0774	.0774	.0309	.0774	.0774	.0351	.3094
10	.1547	.2321	.0774	.2321		.4641	.0155
11	.1547	.3155	.1547	.4641	1.0517	.8509	.0155
12	.3094	.4382	.3868	.8509	1.0517	.8509	.0155
13	.3094	.5258	.4641	1.0829	1.3146	.8509	.0155
14	.3868	.5258	.5415	1.1139	1.4022	.8509	.0155
15	.3868	.5258	.8509	1.0056	1.4022	.7735	.0155
16	.3868	.4382	.8509	1.0056	1.4373	.7735	.0155
17	.3868	.3506	.8509	1.0056	1.3146	.7735	.0155
18	.0155	.0526	.0774	.0155	.0526	.0774	.0155
19	.0774	.0526	.0774	.0619	.0526	.0774	.0619
20	.0774	.0526	.0774	.0774	.0526	.0774	.0774
21	.0774	.0526	.0774	.0774	.0526	.0774	.0774
22	.0774	.0526	.0774	.0464	.0526	.0774	.0774
23	.0464	.0526	.0774	.0464	.0526	.0774	.0619
24	.0774	.0464	.0526	.0774	.0464	.0526	.0774
Max	.3868	.5258	.8509	1.1139	1.4373	.8509	.3094
Min	.0155	.0464	.0309	.0155	.0464	.0351	.0155
Avg	.1509	.1799	.2120	.3275	.4315	.2940	.0748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 204 / 11 KV MUNDWADI

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0876	.0876	.0526	.0876	.0876	.1052
2	.0351	.0876	.0876	.0526	.0876	.0876	.1052
3	.0351	.0876	.0876	.0526	.0876	.0876	.1052
4	.0526	.0876	.1052	.0526	.0876	.0876	.1402
5	.0701	.1052	.1578	.0701	.1052	.1402	.1753
6	.0701	.1227	.1753	.0701	.1052	.1402	.4382
7	.0701	.1052	.1753	.0701	.0876	.0876	.4908
8	.0701	.0876	.1227	.0526	.0876	.0701	.5258
9	.0526	.0876	.0876	.0351	.0876	.0526	.5258
10	.2804	.3506	.2629	.3856		.3506	.0175
11	.298	.298	.3681	.4031	.6135	.7186	.0175
12	.2804	.5258	.5258	.5258	.7712	.7362	.0175
13	.333	.4382	.4557	.5784	.8413	.7362	.0175
14	.3506	.3681	.4382	.6661	.8413	.7537	.0175
15	.3856	.4207	.5083	.7186	1.0166	.7186	.0175
16	.3506	.4557	.5609	.7011	.8764	.7186	.0175
17		.3856	.5083	.6661	.8764	.7186	.0175
18	.0351	.1052	.0351	.0526	.1052	.0526	.0175
19	.0876	.1052	.0701	.0876	.1052	.0701	.0876
20	.0876	.1227	.0701	.0876	.1402	.0701	.0876
21	.0876	.1227	.0526	.1052	.1402	.0701	.1052
22	.0876	.1227	.0526	.0876	.1227	.0526	.0876
23	.0876	.1052	.0526	.0876	.1052	.0526	.0876
24	.0351	.0876	.1052	.0526	.0876	.1052	.0876
Max	.3856	.5258	.5609	.7186	1.0166	.7537	.5258
Min	.0351	.0876	.0351	.0351	.0876	.0526	.0175
Avg	.1425	.2030	.2147	.2381	.3246	.2819	.1380

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 205 / 11KV WADNER GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3598	.3409	.2804	.3788	.3788	.2804	.3788
2	.3598	.3409	.303	.3788	.3788	.2804	.3788
3	.3788	.3409	.303	.4356	.4166	.298	.4734
4	.4734	.4166	.4545	.6818	.5303	.4382	.7575
5	.7386	.6439	.7196	1.0226	.606	.7011	1.0226
6	.9658	.9848	1.1173	1.0416	.6439	.9465	1.1741
7	.9469	1.0226	1.0984	.9469	.8522	.7362	1.0794
8	.8711	.8711	.8901	.9279	.7575	.5258	.9658
9	.7196	.5492	.6249	.6249	.6439	.4908	.6628
10	.4166	.3219	.3788	.303		.3788	.3598
11	.2273	.1402	.2841	.1704	.2279	.1515	.2083
12	.2083	.1227	.1326	.1894	.1052	.1515	.2083
13	.1894	.1227	.1515	.1515	.1227	.1894	.1894
14		.1578	.2083	.1136	.1227	.2273	.1136
15	.1894	.1753	.2462	.1515	.1402	.2841	.2083
16	.2841	.2103	.1894	.2273	.2103	.3409	.2651
17	.4734	.298	.3409	.3598	.3155	.4166	.3409
18	.7954	.3506	.6439	.4545	.4382	.8143	.4734
19	.909	.8413	.9658	.909	.8238	.7764	.7954
20	.606	.8764	.7764	.7007	.6485	.7196	.7196
21	.5492	.5609	.5681	.5681	.5434	.5871	.5303
22	.4166	.4557	.4734	.4734	.4207	.4734	.4734
23	.3409	.333	.4166	.3977		.4166	.4166
24	.3788	.3409	.2804	.3788	.3788	.298	.3788
Max	.9658	1.0226	1.1173	1.0416	.8522	.9465	1.1741
Min	.1894	.1227	.1326	.1136	.1052	.1515	.1136
Avg	.5130	.4508	.4937	.4995	.4412	.4551	.5239



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 206 / 11KV KOLWADI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.133	.152	.0876	.133	.152	.0876	.114
2	.133	.152	.095	.133	.152	.1052	.114
3	.152	.1899	.114	.171	.1899	.1402	.152
4	.1899	.2659	.1899	.2279	.3039	.1753	.2469
5	.2849	.3419	.3229	.2849	.3989	.298	.3229
6	.3989	.4939	.3609	.3799	.4369	.4031	.3609
7	.3419	.4369	.2279	.3609	.3039	.298	.2849
8	.3039	.3039	.152	.3229	.2089	.2103	.1899
9	.2659	.2279	.114	.1899	.133	.1402	.133
10	.152	.114	.114	.095		.114	.095
11	.095	.0876	.095	.057	.0701	.095	.076
12	.057	.0351	.057	.057	.0526	.057	.095
13	.038	.0351	.038	.057	.0526	.057	.057
14	.038	.0351	.057	.038	.0526	.057	.076
15	.057	.0351	.057	.057	.0526	.076	.057
16	.057	.0351	.057	.057	.0701	.095	.076
17	.133	.0526	.095		.0701	.133	.076
18	.2849	.1753	.152	.1899	.2103	.2279	.152
19	.3229	.2454	.3039	.3419	.333	.2849	.2849
20	.2279	.2629	.2849	.3039	.298	.2469	.2849
21	.2279	.1578	.2279	.2279	.1578	.2089	.2659
22	.171	.1402	.1899	.171	.0876	.1899	.2089
23	.152	.0876	.171	.152	.0876	.152	.171
24	.133	.152	.0876	.133	.152	.0876	.133
Max	.3989	.4939	.3609	.3799	.4369	.4031	.3609
Min	.038	.0351	.038	.038	.0526	.057	.057
Avg	.1813	.1756	.1521	.1800	.1751	.1642	.1678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 207 / 11KV AMBA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1663	.1578	.1663	.1848	.1578	.1848
2	.1663	.1848	.1663	.1663	.1848	.1578	.1848
3	.1848	.1848	.1848	.2033	.1848	.1578	.2218
4	.2772	.2587	.1109	.2587	.2957	.2279	.3142
5	.3326	.2957	.3881	.3881	.4066	.298	.462
6	.4435	.3881	.4066	.4805	.5729	.5784	.6099
7	.5175	.3511	.4435	.4251	.5544	.4207	.5175
8	.4805	.3326	.3881	.4066	.4805	.3681	.462
9	.3511	.2587	.2218	.2402		.3856	.3511
10	.2033	.1109	.1109			.3142	.1478
11	.1109	.0701	.0739	.0739	.1227	.1663	.1109
12	.0554	.0701	.0739	.0739	.1052	.1478	.1109
13	.0739	.0701	.0554	.1294	.1227	.0924	.0924
14	.037	.0701	.0554	.0924	.1227	.1109	.0924
15	.0554	.0701	.0739	.1109	.1402	.1478	.1109
16	.0924	.0876	.0924	.1109	.1753	.1848	.1294
17	.1848	.1578	.1294	.2033	.1928	.2402	.1848
18	.4066	.2279		.2957	.2279	.4251	.3142
19	.3326	.3681		.4435	.4031	.4066	.5544
20	.2957	.3506	.4066	.4066	.3155	.3696	.4066
21	.2587	.2279	.2957	.3326	.2103	.3511	.2957
22	.1848	.0175	.2402	.2218	.1227	.3511	.2218
23	.1848	.1753	.1848	.2033	.1402	.2587	.2218
24	.1663	.1663	.1753	.3568	.1848	.1928	.1848
Max	.5175	.3881	.4435	.4805	.5729	.5784	.6099
Min	.037	.0175	.0554	.0739	.1052	.0924	.0924
Avg	.2318	.1942	.2016	.2517	.2478	.2713	.2703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044054 / 33kv wadner s/s

Feeder No / Name : 208 / 11KV KALIMATH GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0351	.0377	.0377	.0526	.0566
2	.0566	.0566	.0377	.0377	.0377	.0526	.0566
3	.0566	.0566	.0566	.0566	.0377	.0701	.0754
4	.0943	.0754	.0943	.0754	.0943	.1227	.1132
5	.1509	.1132	.132	.1132	.1509	.1753	.1698
6	.2075	.1886	.1886	.1886	.1886	.1928	.2075
7	.1886	.1698	.1886	.2075	.1886	.1753	.1886
8	.1698	.1698	.1698	.1698	.0754	.1402	.1698
9	.1509	.132	.132	.132	.1509	.1402	.132
10	.0943	.0754	.0566	.0377		.132	.0754
11	.0377	.0351		.0377	.0351	.0566	.0377
12	.0189	.0175	.0189	.0189	.0351	.0566	.0377
13	.0189	.0175	.0189	.0189	.0175	.0377	.0189
14	.0189	.0175	.0189	.0189		.0377	.0189
15	.0189	.0175	.0189	.0189		.0377	.0189
16	.0377	.0175	.0377	.0377	.0175	.0566	.0189
17	.0754	.0876	.0377	.0377	.0351	.0754	.0189
18	.132		.0943	.0943	.0526	.1132	.0566
19	.1509	.1753	.132	.1509	.0876	.1509	.1132
20	.1132	.1578	.1509	.132	.1578	.132	.0943
21	.0754	.0876	.0943	.0943	.1578	.132	.0754
22	.0566	.0876	.0754	.0566	.1402	.1132	.0566
23	.0566	.0526	.0566	.0377	.0876	.0566	.0377
24	.0566	.0566	.0351	.0377	.0377	.0351	.0566
Max	.2075	.1886	.1886	.2075	.1886	.1928	.2075
Min	.0189	.0175	.0189	.0189	.0175	.0351	.0189
Avg	.0872	.0836	.0818	.0770	.0868	.0977	.0794

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 201 / 11KV HATNOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5658	.4938	.5658	.5959	.5487	.2401
2	.5792	.5658	.5068	.5658	.5548	.5249	.2401
3	.5973	.5658	.5373	.6036	.6241	.567	.2743
4	.7602	.8299	.6805	.6036	.7282	.7442	.3258
5	1.2437	1.0185	1.0029	.8676	.8573	1.0974	.4115
6	1.0974	1.1317	1.2403		1.0852	1.3169	.5658
7	1.134	1.2071	.9877	1.2071	.9945	.9145	.7202
8	.9145	1.1317	.8413	1.2071	1.0852	.9511	.8402
9	1.1706	1.1317	.9877	1.0288	.9496	.9945	
10	.4801	.4694	.4862	.5487	.503	.6859	.6588
11	.5144	.4359	.5138	.5028	.5533	.6516	.5258
12	.4287	.4862	.4191	.5201	.6882	.7888	.3856
13	.3841	.4359	.3856	.4681	.7712	.8402	.3856
14	.421	.3856	.4359	.5144	.788	.5316	
15	.3887	.4024	.4144	.5028	.7545	.583	.4161
16	.3932	.4694	.431	.5601	.8048	.583	.4908
17	.421	.4862	.4694	.5087	.8886	.6344	.5895
18	.9054	.695	.6036	.6173	.6584	.6859	.7282
19	1.2071	1.0791	1.2071	1.0288	1.3169	.9945	.8063
20	1.1317	1.134	1.2071	.9602	1.2071	.9431	.8322
21	.9808	1.0608	1.0374	.8916	.9145	.8573	.7712
22	.7922	.7865	.8676	.6935	.6219	.7202	.7282
23	.679	.6219	.679	.6241	.6219	.6001	.6661
24	.695	.6036	.4755	.5658	.5609	.5487	.2401
Max	1.2437	1.2071	1.2403	1.2071	1.3169	1.3169	.8402
Min	.3841	.3856	.3856	.4681	.503	.5249	.2401
Avg	.7488	.7375	.7046	.7025	.797	.7628	.5383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 202 / 11 KV SHIVRAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.1509	.2429	.1677	.333	.2347	.2572
2	.2515	.1543	.2458	.1677	.3681	.2515	.2915
3	.2686	.1715	.2622	.1677	.3814	.2622	.4287
4	.285	.1715	.2785	.2401	.3814	.2949	.4287
5	.3018	.2401	.2949	.2401	.4334	.3605	.6001
6	.3521	.4115	.3239	.3429	.4115	.426	.8745
7	.4694	.4801	.3841	.4801	.6001	.7042	.8059
8	.5197	.5144	.503	.6173	.7202	.7377	.6687
9	.6036	.6133	.6203	.9326	.763	1.0117	
10	.2829	.2561	.2641	.3155	.3109	.2058	.3814
11	.1509	.1646	.1886	.1772	.2195	.1543	.5487
12	.1509	.1463	.1132	.1417	.1646	.1372	.6516
13		.1463	.112	.1063	.1463	.12	.7202
14	.1132	.2378	.132	.1417	.1463	.12	.583
15	.1132	.2195	.1509	.1578	.1646	.1372	.6001
16	.1509	.2378	.1886	.1417		.1372	.583
17	.2452	.2378	.2263	.1595	.1829	.1886	.5083
18	.3961	.2926	.3018	.1949	.2743	.3258	.2427
19	.7733		.7167	.7282	.6767	.5658	.2804
20	.6413	.5304	.6979	.6415	.7133	.463	.3155
21	.5281	.6767	.6036	.6068	.5487	.3944	.333
22	.3395		.3772	.5258	.3658	.3429	.298
23	.3206		.3206	.4207	.2926	.2915	.333
24	.2347	.1509	.2683	.1677	.3467	.2347	.2572
Max	.7733	.6767	.7167	.9326	.763	1.0117	.8745
Min	.1132	.1463	.112	.1063	.1463	.12	.2427
Avg	.3357	.2954	.3257	.3326	.3889	.3376	.4779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 203 / 11 KV TAPARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3647	.3521		.3988	.4915	.3429
2	.3521	.3647	.3605	.3768	.4161	.5365	.3429
3	.3521	.3688	.3887	.426	.4458	.5243	.4287
4	.3563	.4024	.426	.4641	.4508	.5571	.6001
5	.3768	.4024	.4424	.4973	.5144	.5898	.7202
6	.4191	.4694	.4424	.5304	.583	.6226	.8916
7	.503	.5533	.5868	.6036		.8383	.7888
8	.6203	.663	.7209	.7545	.8648	1.0562	.5487
9	.6226	.679	.7209	.7888	.9665	1.1831	
10	.3961	.2195	.192	.3506	.4024	.2743	.8573
11	.3395	.2561	.2452	.2454	.3109	.2915	.9945
12	.2263	.2195	.2263	.2103		.2401	1.1022
13	.2263	.2195	.2263	.1949		.2229	1.17
14	.2263	.2195	.2075	.1753		.2401	1.1361
15	.2452	.2012	.2263	.2279			1.1831
16		.2195	.2263	.2126	.3292	.2401	1.153
17	.3206	.2561	.2641	.2279	.2926	.2572	
18	.415	.3109	.2829	.2629	.3658	.3258	.3395
19	.679	.6219	.679	.5083	.695	.5658	.3584
20	.679	.6401	.679	.5721	.7133	.583	2.6595
21	.6036	.5487	.5658	.5895	.6401	.583	.5658
22	.5281	.4755	.5658	.5434	.5121	.5316	.5093
23	.4527	.4207	.4527	.4207	.439	.4458	.4715
24	.3353	.3605	.3277	.3681	.4161	.4915	.3429
Max	.679	.679	.7209	.7888	.9665	1.1831	2.6595
Min	.2263	.2012	.192	.1753	.2926	.2229	.3395
Avg	.4179	.3940	.4087	.4153	.5135	.5084	.7958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044076 / HATNUR

Feeder No / Name : 204 / 11 KV JAITAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.3206	.2926	.3206	.2658	.2195	.3429
2	.2715	.3206	.3077	.3206	.2481	.2534	.4287
3	.2926	.3772	.3077	.3395	.2629	.3292	.4973
4	.362	.4904	.3292	.4527	.3155	.4024	.4973
5	.4525	.5658	.3658	.5281	.4161	.5487	.5144
6	.6335	.6036	.3801		.5721	.6401	.5487
7	.5853	.5658	.3475	.6036	.5548	.5487	.703
8	.4938	.4715	.2378	.4715	.4508	.4207	.8402
9	.3658	.1698	.1646	.3506	.333	.2572	
10	.4915	.5533	.5121	.6859	.8215	.8402	.124
11	.547	.5365		.7969	.9054	1.0288	.0886
12	.5636	.5533	.6722	.9602	.9339	1.1488	.0709
13	.503	.2012	.6401	1.0174	.8684	1.2003	
14	.4938	.6203	.6562	.9835	.8848	1.1488	
15	.4999	.57	.6882	.9774	.9724	1.046	.1063
16	.4999	.6203	.6722	.9835	.8848	1.0288	.1417
17	.4999	.6036	.6722	1.0004	.9556	.9088	.1753
18	.3961	.2378	.2263	.2103	.2012	.2058	.2103
19	.5093	.4572	.4904	.4075	.4572	.3772	.2629
20	.5281	.4572	.5093	.4382	.4755	.3601	.3155
21	.415	.3841	.415	.4031	.3658	.3772	.3681
22	.3772	.3475	.3395	.3721	.5304	.3258	.3641
23	.3395	.3109	.3206	.3189	.3109	.2743	.3155
24	.2561	.3206	.2743	.3206	.2804	.2195	.3429
Max	.6335	.6203	.6882	1.0174	.9724	1.2003	.8402
Min	.2534	.1698	.1646	.2103	.2012	.2058	.0709
Avg	.4429	.4441	.4270	.5767	.5528	.5879	.3456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 201 / 11KV JEHUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4763	.5906	.4191	.4763	.6287	.1829
2	.4382	.4954	.6097	.4191	.4572	.6478	.1852
3	.4191	.5716	.6097	.4572	.5144	.6859	.2286
4	.4763	.724	.743	.5335	.5716	.8383	.2812
5	.6097	.8383	.9717	.724	.6668	1.0288	.3521
6	.724	1.0098			.7621		.4191
7	.8383	.8764	.9335	1.0479	.9145	.9907	.5249
8	.724	.8192		.8764	.8573	.8954	.5144
9	.7621	.6859	.6478	.7049	.743	.724	.5636
10	.3521	.381	.2785	.4024	.4572	.4191	.4001
11	.3239	.2787	.3311	.4001	.3841	.381	.2667
12	.362	.2606	.3311	.3048	.3281	.3506	.2286
13	.3239	.2494	.2439	.4191	.2709	.3647	.2477
14	.362	.2408	.2258	.381	.3353		.2477
15	.3429	.2623	.2462	.4001	.2824	.3441	.2858
16	.362	.2743	.3001	.4763	.3715	.3277	.3048
17	.4001	.2812	.2896	.4572	.3858	.3077	.4382
18	.5716	.4572	.4572	.5525	.5525	.6668	.5906
19	.8764	.8573	.8764	.8954	.8764	.8573	.743
20	.7621	.9335	.9335	.724	.9907	.724	.8764
21	.743	.6097	.6668	.6097	.9526	.6859	.8383
22	.6668	.5906	.6287	.5716	.8192	.5716	.724
23	.6287	.5716	.6097	.6097	.6097	.4954	.5906
24	.4763	.5716	.5906	.5335	.5144	.6287	.2286
Max	.8764	1.0098	.9717	1.0479	.9907	1.0288	.8764
Min	.3239	.2408	.2258	.3048	.2709	.3077	.1829
Avg	.5402	.5549	.5507	.5617	.5873	.6166	.4276



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 202 / 11 KV CHIWALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2134	.2286	.2402	.2286	.2096	.2054	.2667
2	.2187	.2667	.2561	.3048	.2286	.1848	.2667
3	.2343	.2858	.3109	.25	.2286	.2587	.2858
4	.253	.3429	.3841	.2881	.2667	.3511	.3429
5	.2881	.4191	.4163	.3239	.362	.4191	.381
6	.3239	.4763	.443	.3605	.4191	.4805	.4954
7	.3521	.4763	.3898	.4641	.362	.4938	.6097
8	.3163	.4572	.4161	.4531	.4382	.5373	.4572
9	.3144	.381	.4115	.421	.4001	.5716	.3429
10	.2096	.2286	.1905	.1905	.1905	.1905	.1669
11	.1143	.1524	.1334	.1143	.1143	.1334	.218
12	.0953	.1143	.1143	.0953	.0953	.0953	.2458
13	.0953	.0953	.1143	.0953	.0953	.0953	.213
14	.0953	.0953	.0953	.0953	.1143	.1334	.1989
15	.0953	.0953	.1143	.1143	.1143	.1334	.2347
16	.0953	.0953	.1143	.1143	.1524	.1715	.2204
17	.2286	.1524	.1715	.1524	.1715	.2096	.2713
18		.2858	.2096	.2286	.4382	.2858	.3239
19	.5716	.5144	.4763	.5716		.2858	.4572
20	.4763	.4954	.4954	.4382	.5335	.4001	.5144
21	.381	.362	.4191	.3429	.4763	.3429	.4763
22	.362	.362	.362	.3048	.4191	.3048	.4382
23	.3239	.3429	.3429	.3239	.3048	.2858	.3239
24	.2286	.2096	.2033	.2858	.2286	.1867	.2667
Max	.5716	.5144	.4954	.5716	.5335	.5716	.6097
Min	.0953	.0953	.0953	.0953	.0953	.0953	.1669
Avg	.2559	.2890	.2844	.2734	.2767	.2815	.3341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044077 / 33/11KV JEHUR

Feeder No / Name : 203 / 11KV NIPANI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0762	.1663	.1067	.0953	.1867	.1905
2	.0914	.0953	.1848	.108	.1143	.2241	.1905
3	.1219	.1334	.1848	.125	.1524	.2402	.2096
4	.125	.1715	.2012	.125	.1715	.2772	.2286
5	.1423	.1905	.2378	.1423	.1905	.3142	.2858
6	.1677	.1905	.2715	.1658	.2096	.2957	.3429
7	.1848	.2477	.2507	.1696	.2096	.2172	.381
8	.168	.2667	.1595	.2454	.2477	.2658	.2667
9	.1989	.2286	.2753	.2515	.2286	.2858	.1524
10	.0762	.0572	.0381	.1143	.0953	.1334	.1696
11	.0953	.0381	.0381	.0572	.1143	.0762	.104
12	.0762		.0381	.0762	.0762	.0953	.1227
13	.0572	.0381	.0381	.0762	.0572	.0953	.1227
14	.0762	.0381	.0572	.0762	.0762	.1334	.1387
15	.0762	.0572	.0572	.0762	.1143	.1524	.1227
16		.0762	.0953	.0572	.1524	.1905	.1417
17	.1524	.0953	.0953	.1143	.1715	.2096	.1595
18		.1334	.1143	.2096	.2477	.3239	.1524
19	.4763	.4572	.3429	.2667	.4191	.3048	.3429
20	.4572	.4763	.5906	.4382	.4763	.4001	.4382
21	.381	.4382	.4763	.362	.4191	.3429	.4191
22	.362	.4001	.3429	.3429	.4001	.2858	.381
23	.3048	.362	.3048	.3429	.3429	.2667	.362
24	.0762	.0762	.1494	.1334	.0953	.1494	.2286
Max	.4763	.4763	.5906	.4382	.4763	.4001	.4382
Min	.0572	.0381	.0381	.0572	.0572	.0762	.104
Avg	.1799	.1889	.1963	.1743	.2032	.2278	.2356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 201 / 11KV CHAPANER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.1886	.2452	.2452	.218	.2829	.2801
2	.1677	.2263	.2452	.2452	.218	.3018	.2801
3	.2012	.2229	.2641	.2641	.2515	.3395	.2987
4	.2347	.2572	.3018	.2829	.2713	.3772	.3361
5	.2683	.3018	.2641	.3429	.3052	.3772	.4108
6	.3018	.4287	.3772	.3772	.3353	.5658	.5415
7	.3018	.5281	.5093	.547	.0441	.6516	.6535
8	.3521		.4527	.5144	.5935	.8299	.9522
9	.4527		.4338	.5144	.4409	.7922	.8029
10	.415		.4904	.5847	.6348	.5093	.6859
11	.4715	.4294	.3961		.2058	.4108	.4458
12	.3772	.3734	.3206	.3361	.3395	.3547	.5658
13	.3395	.3734	.3018	.3734	.2572	.3547	.5093
14	.3395	.3734	.3018	.3547	.3772	.3361	.4715
15	.3429	.3734	.3772	.3547	.3772	.3361	
16	.415	.3113	.3584	.3734	.3772	.4294	.2829
17		.3734		.3361	.3584	.4481	.3018
18			.3584	.5601	.3772	.5601	.5658
19	.415		.8299	.7282	.6979	.6908	.7167
20	.3772		.7545	.5601	.3772	.7468	.6602
21			.7545	.4668	.5658	.5415	.6979
22			.8299	.4854		.4481	.5658
23			.8488	.4481		.4108	.6602
24		.3772	.3395	.2683		.2801	.2801
Max	.4715	.5281	.8488	.7282	.6979	.8299	.9522
Min	.1677	.1886	.2452	.2452	.0441	.2801	.2801
Avg	.3300	.3426	.4502	.4158	.3630	.4740	.5202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 202 / 11KV SIRAJGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1341	.1509	.2641	.2829	.2515	.2829	.2241
2	.1341	.1509	.2641	.2829	.2515	.2829	.2241
3	.1844	.1886	.3018	.2829	.2515	.3018	.2614
4	.2347	.2075	.3018	.2829	.3018	.3772	.2801
5	.2515	.2452	.3772	.3772	.3353	.415	.2987
6	.3018	.3772	.3772	.415	.373	.5658	.3361
7	.3688	.5281	.4904	.5316	.5087	.703	.4108
8	.5533		.6602	.8402	.8048	1.0374	.6161
9	.3401		.9054	.5144	.6706	1.226	.5041
10	.3772		.1886	.2452	.1677	.2263	.415
11	.2263	.1494	.1132		.1715	.1867	.5487
12		.112	.1132		.3584	.168	.6602
13		.112	.0754		.1715	.1494	.6344
14		.1307	.132		.1509	.1307	.7545
15		.1307	.1509		.0566	.1494	.7202
16		.1494	.1698	.168	.1509	.2054	.811
17		.168	.1698	.1867	.1886	.3361	.6173
18				.3734	.2263	.4108	.415
19			.6224	.5041	.4904	.5975	.4715
20			.6224	.3734	.415	.5975	.5658
21			.5658	.3921	.5093	.4668	.4715
22			.6036	.4108		.3734	.5281
23			.5658	.3734		.3734	.2263
24		.1698		.2347		.2801	
Max	.5533	.5281	.9054	.8402	.8048	1.226	.811
Min	.1341	.112	.0754	.168	.0566	.1307	.2241
Avg	.2824	.1980	.3652	.3722	.3241	.4101	.4780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 203 / 11KV TAKLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5658	.5658	.5658	.5228	.5281	.4191
2	.5601	.6036	.5658	.5658	.5228	.5658	.4359
3	.5601	.5658	.6036	.6036	.5228		.4694
4	.6348	.5658	.6036	.5658	.5601	.7545	.4862
5	.6908	.6602	.679	.5658	.6161	.8488	.503
6	.7468	1.2071	1.094	.6602	.6535	1.226	.5868
7	.8215	1.1317	1.094	1.094	.7468	1.1128	.6783
8	.9896		.7545	.8865	.9522	1.0374	.7377
9	.8215		.6224	.5658	.6722	.8299	.9054
10	.7545		.4904	.463	.6161	.6224	.5144
11	.3772	.3521	.4904	.4359		.57	.3584
12	.3772	.3018	.5093	.4694	.6859	.5868	.2058
13	.3395	.2439	.4904	.503	.6859	.6036	.1698
14	.4338	.3018	.4904	.4862	.7545	.5533	.1698
15	.4338	.3688	.4458	.503	.6344	.503	
16	.4338	.4359	.5658	.5868	.6979		.2452
17	.6602	.503	.5658	.6706	.6859		.3018
18	.6602		.7922	.6706	.6859	.3734	.7545
19	.7545		.9997	.7712	.7922	.9335	.7545
20	.8676		.9997	.6371	.7545	.8402	.7545
21	.8488		.7545	.6783	.7733	.7842	.811
22	.7545		.6602	.6783		.7095	.7545
23	.8299		.5658	.5087		.7095	.5658
24		.7545		.5228		.4862	
Max	.9896	1.2071	1.094	1.094	.9522	1.226	.9054
Min	.3395	.2439	.4458	.4359	.5228	.3734	.1698
Avg	.6483	.5708	.6697	.6108	.6768	.7228	.5264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 204 / Banshendra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0566	.0754	.0754	.0671	.0754	.0747
2	.0503	.0566	.0943	.0943	.0671	.0754	.0747
3	.0671	.0754	.0943	.1132	.0838	.0943	.0747
4	.0671	.0754	.0943	.132	.0335	.1132	.112
5	.1006		.1132	.132	.1006	.1698	.0747
6	.1006	.12	.132	.1509	.1357	.2829	.168
7	.1341	.1886	.1698	.1509	.1696	.3772	.2241
8	.1844	.2229	.2263	.2829	.3222	.3772	.3734
9	.2515		.3395	.3584	.39	.3772	.2241
10			.132	.1509	.1307	.1886	.1886
11		.112	.0377		.0943	.112	.2263
12		.0934	.0377	.0934	.0943	.0934	.1132
13				.0934		.0934	.2452
14				.0934		.0934	.1715
15				.0934		.112	.2229
16				.0934		.1494	.2572
17			.0566	.112		.1867	.2572
18			.2829	.1494		.1867	.2829
19			.3772	.2614	.2263	.2427	.2829
20			.2829	.2614	.2263	.2987	.2829
21			.1698	.2801	.2263	.2801	.1886
22			.1886	.2801		.2614	.1698
23			.1886	.2241		.2241	.1886
24		.0754		.1006		.168	
Max	.2515	.2229	.3772	.3584	.39	.3772	.3734
Min	.0503	.0566	.0377	.0754	.0335	.0754	.0747
Avg	.1118	.1076	.1628	.1642	.1579	.1931	.1947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044078 / 33/11KV CHAPANER

Feeder No / Name : 205 / 11 KV GUDAMA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0377	.0566	.0377	.0503	.0566	.056
2	.0335	.0566	.0566	.0343	.0503	.0754	.056
3	.0503	.0754	.0566	.0566	.0503	.0943	.056
4	.0503	.0754	.0754	.0566	.0671	.0943	.0934
5	.0838	.0943	.0943	.0754	.0838	.0943	.112
6	.0838	.1509	.1132	.0857	.1006	.1886	.1494
7	.1006	.1509	.132	.1132	.1174	.1886	.1494
8	.1341	.132	.132	.1543	.1677	.132	.168
9	.1174		.1886	.1029	.1844	.1698	.168
10	.0943		.0754	.0943	.0934	.1886	.1698
11	.1132	.0373	.0754	.0934	.0566	.056	.1698
12	.0566	.0373	.0754	.0747	.0754	.0373	.2229
13	.0377	.0373	.0377		.0754	.0373	.1132
14		.0373	.0377	.0747	.0566	.0373	.0943
15		.0373	.0377	.0747	.0566	.0373	.0754
16		.0373	.0566	.0747	.0377	.0373	.1509
17		.0373	.0566	.0747	.0377	.0187	.132
18	.0754			.1307	.0566	.1494	
19	.0943		.2263	.1867	.0566	.2241	.0943
20	.0754		.2263	.1867	.3395	.2054	.1509
21	.0943		.1886	.1867	.1698	.112	.3018
22			.1886	.1867		.112	.0754
23	.0754		.2075	.112		.112	.0754
24				.0671		.0934	
Max	.1341	.1509	.2263	.1867	.3395	.2241	.3018
Min	.0335	.0373	.0377	.0343	.0377	.0187	.056
Avg	.0780	.0690	.1089	.1015	.0945	.1063	.1288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 201 / 11kv ANDHANER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0479	.6859	.8688	.7716	.7468	1.226	1.226
2	.9526	.7202	.8688	.7716	.7095	1.226	1.226
3	.9526	.823	1.0136	.8573	.724	1.3203	1.226
4		.9602	1.2136	1.0288	.9526	1.6032	2.0748
5	1.1431	1.1145	1.419	1.1145	1.3146	1.6032	2.2634
6	1.2384	1.286	1.4563	1.286	2.0195	1.8861	2.3765
7	1.5051	1.3717	1.4937	1.3717	2.1437	1.9616	2.3765
8	1.4098	1.3717	1.7164	1.7147	2.3152	2.6595	2.1125
9	1.2567	1.3717	1.5089	1.3717	2.1068	2.3765	
10	1.3032	1.1145	.9619	.8573	1.0802	1.166	1.0288
11		.8573	.7373	.7811	.8573	.3772	1.1145
12	.6687	.6516	.6859	.9145	.7373		1.0631
13	.6344	.6516	.5487	.724	.7202	.5144	
14	.6516	.6173	.5487	.6668	.6859	.7545	1.1145
15	.6687	.6154	.583	.6001	.6516	.3772	1.2517
16	.703	.6516	.6516	.823	.9431	.3944	1.3546
17	.7716	.7373	.823	.8916	1.0751	1.0974	1.406
18	1.4575	1.1765	.6859	1.166	.1509	1.5089	1.6221
19	1.8861	1.9909	2.0576	2.4006	1.9616	2.1502	1.6598
20	2.0576	2.2592	1.8861	2.5911	2.4897	1.9616	2.0576
21	1.8861	1.6975	1.7147	2.0957	2.0748	1.6461	1.8861
22	1.5432	1.6598	1.5432	1.8671	1.9616	1.5089	1.7147
23	1.1145	1.4937	1.3717	1.7147	1.8296	1.4335	1.5432
24	1.1431	.5144	.8402	.6859	.7621	1.0374	1.358
Max	2.0576	2.2592	2.0576	2.5911	2.4897	2.6595	2.3765
Min	.6344	.5144	.5487	.6001	.1509	.3772	1.0288
Avg	1.1816	1.0997	1.1333	1.2111	1.2922	1.3822	1.5935



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 203 / 11KV GARADA AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2401	.3077	.2401	.3048	.2641	.3772
2	.2667	.2401	.3077	.2401	.2858	.3018	.3772
3	.2286	.2743	.3439	.2743	.2858	.3018	.415
4		.2915	.3734	.3086	.381	.3395	.4527
5	.2858	.3429	.3961	.3429	.4382	.3395	.4904
6	.381	.3772	.4108	.3772	.4382	.3772	.5281
7	.4763	.3772	.4527	.3772	.4001	.415	.6413
8	.4382	.3429	.3772	.3772	.3239	.3961	.7545
9	.362	.3429	.3142	.3086	.3239	.3584	
10	.2572	.4973	.547	.5144	.4458	.6859	.2743
11		.5316	.6516	.6478	.8745	.9774	.1886
12	.5487	.5144	.7202	.7621	.5487	.9431	.1715
13	.5487		.6859	.8764	.8573	1.0117	.1715
14	.583		.6516	.9335	.9945		.1715
15	.5144	.6036	.6859	.6173	.9945	1.0117	.2401
16	.4115	.6687	.7545	.6859	1.0562		.2401
17	.4801	.6687	.6687	.7716	1.0374		.2572
18	.3547	.3018	.3086	.2572	.1509		.3772
19	.3429	.4191	.3944	.4001		.3772	.3772
20	.3429	.3361	.3601	.381	.3734	.3961	.4458
21	.3429	.3206	.3429	.3429	.3018	.3772	.4801
22	.2743	.3206	.3086	.3048	.2641	.3772	.3429
23	.2743	.3206	.2915	.3239	.2641	.3395	.2915
24	.2858	.2743	.3018	.2743	.3239	.2263	.3395
Max	.583	.6687	.7545	.9335	1.0562	1.0117	.7545
Min	.2286	.2401	.2915	.2401	.1509	.2263	.1715
Avg	.3766	.3912	.4565	.4558	.5073	.4908	.3655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 204 / 11KV KALIMATH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.5144	.6878	.6859	.8573	.7167	.8962
2	.5716	.5144	.6878	.6516	.8192	.7167	.9054
3	.5716	.6001	.724	.6001	.7621	.7922	.9808
4		.6516	.724	.6516	.724	.8488	1.094
5	.7621		.8402	.6859		.9054	1.1128
6	.8573	.6859	.9054	.6859		.9431	1.1317
7	.9335	.6859	.9431	.6859		.9808	1.1128
8	.6478	.6859	.7167	.6001	.8764		1.094
9	.4954	.5144	.7545	.5144	.6097	.7356	
10	.5487	.4287	.6036	.5487	.7202	1.0288	.3429
11	.583	.5487	.5658	.8573	.8573	1.2174	.2401
12	.5487	.6001	.6001	.8192	1.0802	1.2689	.2058
13	.5487	.5658	.3601	.9335	1.1145	1.3032	.2229
14	.5487	.6348	.6859	.7621			.2401
15	.5144	.6413			.1509	.9602	.2229
16	.4973	.6001	.6516	.8573	1.3014	.9259	.2915
17	.6001	.6516	.6859	.8573	1.3203	.9431	.2743
18	.7716	.5415	.3429	.4973	.5658	.5093	.7922
19	.823	.9907	.7716	.8192	.8865	.7922	.7922
20	.8573	.8962	.7202	1.0098	1.0269	.9808	.6859
21	.6687	.8299	.6859	1.0098	1.0185	.9511	.6516
22	.5144	.8299	.6001	1.0288	.9997	.9808	.6001
23	.5144	.7922	.5144	.9526	.9808	.9619	.8573
24	.7621	.5144	.7545	.7716	.8954	.811	.7842
Max	.9335	.9907	.9431	1.0288	1.3203	1.3032	1.1317
Min	.4954	.4287	.3429	.4973	.1509	.5093	.2058
Avg	.6463	.6486	.6750	.7603	.8784	.9215	.6753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 205 / 11KV GARADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2241	.2172	.1867	.1905	.2263	.1829
2	.1905	.2614	.2641	.1867	.1905	.2263	.1886
3	.1715	.2614	.2534	.2241	.1715	.3772	.2263
4		.3361	.3395	.2427	.2858	.415	.415
5	.381	.4108	.3961	.3734	.4191	.5281	.4904
6	.5716	.5601	.6224	.5415	.5335	.6036	.5975
7	.6668	.6535	.6602	.4854	.6668	.6602	.6036
8	.4954	.4668	.4904	.3734	.5144	.5093	.4904
9	.381	.3734	.3206	.3921	.3429	.3961	
10	.2229	.1886	.2452	.2427	.3086	.2401	.2614
11	.1543	.1886	.1543	.1524	.1715	.1886	.1715
12	.1029	.1543	.1029	.1524	.1543	.1715	.1543
13	.12	.1372	.12	.1334	.1543	.1372	.1543
14	.12	.0748	.12	.1334	.1543	.1715	.1543
15	.1029	.1307	.12	.1543	.1543	.1715	.1543
16	.1029	.1372	.1543	.1543	.2263	.2401	.1372
17	.2987	.2229	.168	.1886	.2641	.2743	.2229
18	.4108	.3439	.3361	.2572	.3584		.3772
19	.3734	.4854	.4854	.4954	.4527	.4715	.4527
20	.3734	.3547	.4854	.4382	.4527	.415	.5601
21	.3361	.2452	.4108	.381	.3018	.3018	.5601
22	.2427	.2452	.3174	.2477	.2641	.2641	.3174
23	.2241	.1886	.2054	.2286	.2263	.2075	.2614
24	.1905	.1867	.1886	.2054	.1905	.1886	.1886
Max	.6668	.6535	.6602	.5415	.6668	.6602	.6036
Min	.1029	.0748	.1029	.1334	.1543	.1372	.1372
Avg	.2793	.2847	.2991	.2738	.2979	.3211	.3184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044092 / 33kv Andhaner substation

Feeder No / Name : 206 / 11KV Rail Single Phasing SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0514	.0905	.1715	.1334	.0754	.0189
2	.0572	.0514	.0905	.1715	.1524	.0754	.0189
3	.0572	.0514	.112	.2058	.1524	.0754	.0189
4		.0686	.1448	.2229	.1524	.1132	.0189
5	.0953	.0857	.2263	.2401	.1524	.1132	.0377
6	.1143	.1029	.2452	.2743	.1905	.1698	.0566
7	.1334	.1029	.2452	.2743	.3048	.1698	.0377
8	.1524	.1715	.2263	.3086	.362	.415	.0377
9	.1905	.2058	.2263	.3772	.4001	.5093	
10	.0171	.0171	.0377	.0171	.0171	.0171	.1715
11	.0171	.0171	.0343	.0191	.0171	.0171	.2915
12	.0171	.0171	.0171	.1524	.0171	.0171	.2743
13	.0171	.0171	.0171	.0191	.0171	.0171	.2915
14	.0171	.0187	.0171	.0191	.0171	.0171	.3086
15	.0171	.0189	.0171	.0171	.0171	.0171	.3258
16	.0171		.0171	.0191	.0189	.0171	.3772
17	.0343	.0171	.0171	.0171	.0189	.0171	.3601
18	.0343	.0187	.0171	.0171	.0189	.0189	.0377
19	.0343	.0038	.0171	.0191	.0189	.0566	.0377
20	.0343	.0377	.0343	.0191	.0377	.0377	.0343
21	.0171	.0381	.0171	.0191	.0189	.0189	.0343
22	.0171	.0189	.0171	.0191	.0189	.0189	.0171
23	.0171	.0189	.0171	.0191	.0189	.0189	.0171
24	.0762	.1029	.0754	.1715	.1334	.0754	.0189
Max	.1905	.2058	.2452	.3772	.4001	.5093	.3772
Min	.0171	.0038	.0171	.0171	.0171	.0171	.0171
Avg	.0548	.0545	.0824	.1171	.1003	.0874	.1236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 201 / 11 KV Deogaon Urban SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5947	1.5775	1.7147	1.6817	1.7372	.8869	.8573
2	1.5947	1.5775	1.7528	1.6632	1.7002	.905	.8573
3	1.6289	1.5775	1.7528	1.6632	1.7002	.905	.8573
4	1.8861	1.9281	1.8099	1.7002	1.9404	1.0498	.9526
5	2.3011	2.2786	2.4768	1.8111	2.2546	1.2308	1.0479
6	2.8481	2.3663	2.6673	2.6981	2.809	1.3394	1.0479
7	2.8292	2.5415		2.5503	2.7905	1.4842	1.2384
8	2.3954	2.191	2.191	2.2546	2.4579	1.6289	1.2445
9	1.8665	1.7147	1.4899	2.1338	1.9052	1.6108	1.3466
10	.7783	.7926	.964	1.086	1.1765	1.386	1.4289
11	.7964		.964		1.3611	1.3491	1.4289
12	.9412	.7773	1.1393		1.4899	1.3676	1.4098
13	.9955	.7773	.7888	1.4118	1.5061		1.3717
14	.9774		.8764	1.5775	1.4899		1.3717
15	.9774	.7164	.8764	1.4198	1.5061		
16	.929		1.1393	1.3321	1.4661	1.8111	
17		1.0288	1.3032	1.5249	1.3108	1.6651	1.3717
18	1.6827	1.7147	1.4299		1.4232	1.8404	1.6632
19	2.0157	2.21	2.0328	1.9281	2.1125	2.191	2.32
20	2.1033	2.2862	2.1253	2.3663	2.4949	2.191	2.2634
21	1.9281	2.1148	2.1622	2.2177	2.2731	2.191	2.1434
22	1.8404	2.0386	2.0328	2.0328	2.0328	2.191	2.2257
23	1.6651	1.7718	1.8665	1.8665	1.885	1.9052	1.7833
24	1.5947	1.5775	1.7528	1.6817	1.7372	.9055	.8573
Max	2.8481	2.5415	2.6673	2.6981	2.809	2.191	2.32
Min	.7783	.7164	.7888	1.086	1.1765	.8869	.8573
Avg	1.6596	1.6933	1.6221	1.8382	1.8567	1.5255	1.4131

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 202 / 11KV Mategaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3144	.5601	.6097	.5487	.6154	.2587	.2881
2	.3144	.5281	.5487	.5914	.6154	.2587	.2881
3	.5335	.5281	.5792	.6584	.6516	.2957	.2881
4	.5487	.5281	.5792	.6584	.724	.2957	.3201
5	.5487	.5761	.6335	.695	.8145	.3326	.3201
6	.6097	.6081	.7011	.7682	.8145	.3696	.3201
7	.6554	.6401	.8764	.9231	1.0136	.3326	.4001
8	.8383	.7202	1.0059	1.086	1.267	.3326	.4001
9	.9774		.8802	1.086	1.4022	.2987	.2858
10	.2587		.16	.2286	.1905	.724	.6335
11	.1848		.08	.2286	.2286	.7602	.724
12	.1478		.16	.1905	.2286	1.3575	.7164
13	.1478		.16	.1905		1.3575	.6335
14	.1478		.16	.2286	.1905	1.086	.6335
15	.1478		.16	.128	.1905	.9955	.6335
16	.128		.16	.16	.2286	.724	
17		.2858	.1848	.16		.6401	.6401
18	.2401	.381	.2218	.2401		.2401	
19	.3201	.4382	.3881	.3201	.381	.3361	
20	.3201		.4066	.3841	.6468	.3361	.2286
21	.3201	.381	.4066	.4435	.4066	.2881	.2286
22	.2881	.2858	.2957	.3696	.3326	.2881	
23	.2401	.2858	.2772	.2957	.2772	.2881	
24	.503	.5601	.543	.543	.543	.2587	.2401
Max	.9774	.7202	1.0059	1.086	1.4022	1.3575	.724
Min	.128	.2858	.08	.128	.1905	.2401	.2286
Avg	.3798	.4871	.4241	.4636	.5601	.5190	.4328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 203 / 11KV Dhondalgaon feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2343	.2715	.2926	.2172	.3326	.2812
2		.2343	.2896	.3326	.2534	.3696	.2812
3		.2343	.2896	.3326	.2534	.3696	.3125
4		.2812	.3258	.3696	.2896	.4066	.3437
5	.1619	.3125	.3982	.3696	.3258	.7023	.4999
6	.2096	.3906	.4525	.4251	.4344	.8131	.5468
7	.2286	.3906	.4525	.4435	.5068	.7392	.5937
8	.2477	.5468	.6668	.6154	.6335	.5359	.4374
9	.5792	.5182	.5624	.6335	.6733	.4108	.381
10	.2772		.2031	.1524	.2858	.5249	.5068
11	.2033		.1562	.0762	.1715	.5249	.4706
12	.1478		.1875	.1524	.1715	.7059	.4525
13	.1478		.125	.1524	.1905	.4887	.5068
14	.1294			.1715	.1715	.7164	.4929
15	.1294		.125	.1406	.1715		.4108
16	.1562		.3041	.1875	.0953	.3121	
17		.2477	.2033	.1718		.3125	.2191
18	.3125	.4191	.2772	.2656		.3125	
19	.3906	.5144	.4805	.3437	.2096	.3593	.2286
20	.3906	.4954	.4435	.4374	.5359	.3593	.2477
21	.3437	.381	.4435	.4066	.4251	.3281	.2286
22	.3125	.3429	.3696	.3696	.3696	.3281	
23	.2812	.3429	.3511	.3326	.3326	.2812	
24		.2343	.2896	.5754	.2172	.3326	.25
Max	.5792	.5468	.6668	.6335	.6733	.8131	.5937
Min	.1294	.2343	.125	.0762	.0953	.2812	.2191
Avg	.2583	.3600	.3334	.3229	.3152	.4594	.3846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044094 / Deogaon Rangari Kannad

Feeder No / Name : 205 / 11KV Deogaon Rural SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.0936	1.2384	1.2197	1.2567	.7602	.5937
2	1.2346	1.0936	1.3336	1.2696	1.2936	.7964	.6249
3	1.286	1.2498	1.2955	1.3443	1.2936	.7964	.703
4	1.3375	1.3279	1.3336	1.3443	1.5708	.8688	.7343
5	1.4575	1.4842	1.7147	1.4563	1.7372	.9412	.7811
6	1.7918	1.4842	2.0005	1.8298	1.7372	1.0498	.7811
7	1.1736	1.406	1.7147	1.2382	1.6817	1.086	.8592
8	1.0364	1.1717	1.2955	1.3306	1.423	1.3394	.8592
9	.9412	.9602	.8592	1.2384	1.1431	1.3032	.9955
10	.5175		.703	.9907	.8859	.6838	.7621
11	.6036		.5468	.964	.9907	.6838	.7621
12	.6154	.5944	.6249	1.448		.6653	.7621
13		.5335	.6249		.964	.6099	.8002
14			.6249	.8592	.9816	.5914	.724
15	.7602	.5182	.6249	.7811	1.0631	.6653	.724
16	.6249		.703	.8124	1.0867	.7392	
17		1.0288	.6878	.8592	.9907	.703	.6097
18	.9686	1.3717	.7392	.703	.5487	1.0155	.6859
19	1.2498	1.4289	1.386	1.0936	1.0974	1.0155	1.3203
20	1.3279	1.4861	1.3676	1.4842	1.3306	1.2498	1.3375
21	1.1717	1.3527	1.3676	1.3121	1.386	1.1717	1.286
22	1.1717	1.2955	1.2936	1.3306	1.3306	1.1717	1.2346
23	1.1717	1.2384	1.2382	1.3306	1.3306	1.1717	1.2003
24	1.0974	1.0936	1.2955	1.2197	1.2567	.7762	.5937
Max	1.7918	1.4861	2.0005	1.8298	1.7372	1.3394	1.3375
Min	.5175	.5182	.5468	.703	.5487	.5914	.5937
Avg	1.0779	1.1607	1.1089	1.1939	1.2339	.9106	.8580



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 201 / Town-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3361	.0326	.3395	.3361	.0326	.3361
2	.3361	.3361	.0326	.3174	.3361	.0326	.3361
3	.3547	.3361	.0362	.3361	.3361	.038	.3547
4	.3734	.3361	.0398	.3734	.3734	.0362	.3921
5	.4294	.4854	.0525	.5228	.5975	.0434	.4854
6	.6348	.5601	.0579	.6283	.6348	.0543	.7095
7	.6348	.5975	.0615	.6653	.7468	.0543	.6348
8	.6348	.5487	.6535	.6283	.7842	.0561	.6535
9	.5658		.5914	.6036	.6516	.0579	.6535
10	.5228	.4755	.5601	.5601	.0471	.5544	.5601
11	.4108	.3658	.4435	.4481	.3982	.4904	.4108
12	.3734	.3292	.4251	.4108	.0434	.4435	.4854
13	.3361	.3658	.3772	.3361	.3801	.415	.4108
14	.2987	.3292	.3734	.2987	.3258	.3881	.4108
15	.2987	.3292	.3734	.3361	.3258	.4066	
16	.2987	.2926	.3696	.3361	.2896	.4294	.4108
17	.4108	.0326		.3734	.3801	.4527	.4108
18	.4481	.0398	.4481	.4481	.0507	.4854	.4108
19	.5228	.0471	.5228	.5228	.0579	.5544	.5975
20	.5228	.0543	.5601	.5228	.0507	.5175	.5975
21	.4854	.0471	.5281	.4854	.0471	.4481	.7095
22	.4108	.038	.4108	.4481	.0434	.4805	.5601
23	.3734	.0362	.4108	.4108	.0398	.3696	.4108
24	.3511	.3361	.0326	.3361	.3734	.038	.3734
Max	.6348	.5975	.6535	.6653	.7842	.5544	.7095
Min	.2987	.0326	.0326	.2987	.0398	.0326	.3361
Avg	.4318	.2893	.3215	.4453	.3187	.2866	.4919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 202 / TOWN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1389	1.0829	.1109	1.1576	1.1576	.1158	1.2136
2	1.1389	1.1203	.1072	1.1458	1.1203	.1134	1.1949
3	1.1576	1.2696	.1035	1.1576	1.1203	.1109	1.1949
4	1.1576	1.1203	.1294	1.1643	1.1576	.1331	1.2136
5	1.7177	1.531	.1552	1.4415	1.6057	.1626	1.7924
6	1.9044	1.8671	.1885	1.7924	1.8298	.1774	1.8671
7	2.0911	1.9044	.1959	2.0538	2.1285	.1848	1.9605
8	1.9791	1.7741	1.6263	1.848	2.0538	.1515	1.7551
9	1.6787	1.4784	1.531	1.6817	.1497	.1478	1.531
10	1.1203	1.4045	1.3256	1.4563	.1331	1.4784	1.4937
11	1.2323	1.2197	1.307	1.3817	.122	1.3817	1.3443
12	1.1949	1.1827	1.1949	1.307	.1146	1.2012	1.1576
13	1.1576	1.1458	1.1203	1.1203	.1183	1.2012	1.1949
14	1.0456	.9979	.7468	1.1203	.1109	1.1643	1.1203
15	1.1203	.7392	1.1203	1.1203	.122	1.134	
16	1.1576	1.1088	1.1576	1.1203	.1257	1.2382	1.1949
17	1.2323	.1405	1.2136	1.2696	.1257	1.3306	1.3443
18	1.4937	.1552	1.3443	1.3817	1.4415	1.3676	1.4563
19	1.4937	.1774	1.6632	1.643	1.5154	1.7556	1.8298
20	1.7551	.1626	1.9044	1.7177	.1737	1.7551	1.9044
21	1.6057	.1515	1.8484	1.643	.1626	1.643	1.7551
22	1.4563	.1331	1.5278	1.5684	.1441		1.6057
23	1.2696	.1294	1.3443	1.3443	.1368	1.3443	1.1203
24	1.1576	1.1576	.1072	1.2136	1.2323	.122	1.2696
Max	2.0911	1.9044	1.9044	2.0538	2.1285	1.7556	1.9605
Min	1.0456	.1294	.1035	1.1203	.1109	.1109	1.1203
Avg	1.3940	.9648	.9614	1.4104	.7543	.8441	1.4571

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 203 / Town 3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.2987	.0293	.3547	.3361	.0329	.3547
2	.3547	.3174	.0329	.3326	.3361	.0329	.3361
3	.3547	.3174	.0329	.3734	.3361	.0366	.3361
4	.3547	.3361	.0366	.3921	.3361	.0384	.3734
5	.5415	.4854	.0476	.5228	.5975	.0585	.5228
6	.8215	.6348	.0585	.7468	.8215	.0695	.6161
7	.8131	.7842	.0768	.8871	.8215	.0732	.7095
8	.8589	.8589	.7095	.9522	.7095	.0768	.8215
9	.8215	.7468	.7095	.7468	.5853	.075	.7842
10	.6348	.7468	.5975	.5975	.5487	.7095	.7842
11	.5975	.6722	.5975		.4755	.6535	.6722
12	.5228	.5228	.499	.5975	.3658	.5975	.5975
13	.4481	.4854	.4527	.5228	.3292	.5175	.4854
14	.3734	.3734	.3547	.5228	.3292	.5228	.4481
15	.3734	.3361	.415	.4481	.3841	.5228	
16	.4108	.3361	.4108	.4854	.4755	.5228	.5228
17	.5601	.0402	.5601	.5228	.0567	.6722	.5975
18	.6722	.0476	.7095	.7468	.0695	.7468	.6722
19	.7095	.0549	.7655	.6722	.7316	.7095	.8589
20	.5601	.0585	.6722	.5228	.0585	.7468	.7095
21	.4854	.0512	.5228	.4481	.0622	.6348	.5975
22	.4108	.0439	.4854	.4481	.0549	.5228	.5228
23	.3734	.0384	.4108	.4108	.0457	.4854	.4481
24	.3734	.3361	.0329	.3696	.3734	.0384	.4481
Max	.8589	.8589	.7655	.9522	.8215	.7468	.8589
Min	.3547	.0384	.0293	.3326	.0457	.0329	.3361
Avg	.5325	.3718	.3842	.5489	.3850	.3790	.5747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 204 / Town 4

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.3734	.0366	.4066	.4108	.0384	.4294
2	.4108	.3734	.0402	.3881	.4108	.0366	.4108
3	.4108	.3734	.0384	.3921	.4108	.0384	.4108
4	.4108	.3734	.0439	.4108	.4108	.0439	.4294
5	.5415	.4481	.0549	.4805	.4854	.053	.5601
6	.5601	.5228	.0585	.5975	.5975	.0549	.5788
7	.6161	.5975	.0622	.6348	.7468	.0585	.6348
8	.6348	.6154	.6348	.7095	.7842	.0567	.7095
9	.6348	.6154	.5544	.7023	.0695	.0622	.6348
10	.5975	.6154	.6413	.7095	.5487	.7095	.6348
11	.5975	.6154	.5975	.7468	.5853	.7023	.5975
12	.5975	.5792	.5975	.6722	.567	.6722	.5975
13	.5975	.543	.6283	.7095	.5853	.6348	
14	.5228	.5068	.5788	.6348	.6219	.5975	
15	.5228	.4706	.5788	.5975	.5487	.5544	
16	.5228	.543	.5914	.5975	.5121	.5544	.7468
17	.5601	.0585	.5975	.5975	.5304	.5601	.7095
18	.6722	.0658	.6161	.6722	.5853	.6348	.7095
19	.7095	.0695	.7468	.7468	.6584	.7023	.8589
20	.5975	.0585	.7468	.6722	.0549	.6908	.7842
21	.5601	.0585	.6348	.6348	.0622	.5914	.6348
22	.5228	.0512	.5601	.5601	.053	.5544	.5601
23	.4481	.0457	.4904	.5228	.0476	.4854	.5228
24	.4481	.4108	.0384	.4251	.4481	.0384	.4481
Max	.7095	.6154	.7468	.7468	.7842	.7095	.8589
Min	.4108	.0457	.0366	.3881	.0476	.0366	.4108
Avg	.5469	.3744	.4237	.5926	.4473	.3802	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 205 / Ritthi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395		.6104	.6161		.061	
2	.3734		.0577	.6348		.0678	
3	.3772		.0543	.5975		.0712	
4	.2452		.0577	.5914		.078	
5	.4108		.061	.8589		.0916	
6	.3961		.0644	.8215		.1051	
7	.3961		.0661	.8589		.1221	
8	.5847		.8501	1.2136		.1475	
9	.7762		1.1016	1.423	1.4922	.1577	
10			.2801		.1696	.2614	
11			.2263		.3052	.3174	
12			.2957		.3052	.3961	
13			.3584		.3052	.3961	
14			.3174		.2713	.4338	
15			.3018		.3561	.4338	
16			.2987		.407	.3772	.9877
17		.0271	.5975		.4409	.3961	1.0608
18		.0305	.6036		.4917	.415	.3395
19		.0356	.4481		.5256	.415	.4904
20		.0509	.5847		.0543	.547	.5658
21		.0509	.5281		.0509	.4715	.5658
22		.0475			.0441	.3961	.5281
23		.0441	.5281		.0458	.4527	.5281
24	.2452		.0509	.5304		.061	
Max	.7762	.0509	1.1016	1.423	1.4922	.547	1.0608
Min	.2452	.0271	.0509	.5304	.0441	.061	.3395
Avg	.4144	.0409	.3627	.8146	.3510	.2780	.6333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

KANNAD (R) S/DN[403] BU 7226

Substation No/ Name :- 044097 / 33 KV Sub Station,Kannad

Feeder No / Name : 206 / Industrial SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.0754	.0092	.1867	.1867	.0092	.0754
2	.1867	.0754	.0092	.1867	.1886	.0092	.0754
3	.1886	.1132	.0111	.1867	.1886	.0129	.0754
4	.2054	.1886	.0185	.181	.1886	.0129	.1132
5	.2054	.1886	.0185	.1867	.1886	.0185	.1509
6	.2054	.2263	.0222	.2241	.2263	.0222	.1886
7	.2054	.2641	.0222	.2241	.2263	.024	.1886
8	.2452	.1663	.2263	.2241	.1886	.0166	.132
9	.2829	.1848	.2801	.2641	.2957	.0092	.2075
10	.2263	.2218	.2263	.2641	.2587	.0924	.1886
11	.2263	.2218	.3174	.2263	.2218	.1848	.1698
12	.2263	.2218	.3018	.3395	.2772	.1867	.1132
13	.2263	.2957	.2641	.2641	.2772	.1867	.1132
14	.2987	.2957	.3361	.3018	.2772	.2054	.1698
15	.2829	.2587	.2641	.1132	.2957	.2241	.1698
16	.2641	.2587	.2641	.2641	.3142	.2614	.1698
17	.2263	.0277	.2427	.3018	.2957	.2641	.1698
18	.2263	.0274	.2987	.2263	.2772	.2075	.1886
19	.2641	.0296	.2241	.2641	.1848	.2241	.1886
20	.3018	.0333	.2987	.3018	.0222	.2263	.1886
21	.2263	.0277	.2614	.2263	.0259	.2263	.1886
22	.1698	.0259	.2241	.1886	.0222	.0943	.1509
23	.1698	.0166	.1867	.1886	.0111	.0754	.1132
24	.2054	.0754	.0111	.1867	.1886	.0092	.0754
Max	.3018	.2957	.3361	.3395	.3142	.2641	.2075
Min	.1698	.0166	.0092	.1132	.0111	.0092	.0754
Avg	.2280	.1467	.1808	.2301	.2012	.1168	.1485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 201 / 11KV NAGAD AG(WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4382		.5335	.7811	.3048	.3429
2	.3239	.4382		.5335	.7621	.3239	.3048
3	.3239	.4763		.5144	.8192	.3429	.3429
4	.362	.4763		.5525	.8383	.381	.4001
5	.4001	.4572		.5335	.8573	.4001	.4572
6	.4382	.5144		.5525	.9145	.5335	.5525
7	.4572	.5525		.724	.9145	.5144	.5335
8	.381	.6668		.8573	.8764	.5144	.5144
9	.4763	.6668		.7621	.9335	.4382	.4382
10	.2096	.2286		.2477	.381	.8383	.7811
11	.1905	.2286		.3429	.362	1.0098	.724
12	.1143	.2477		.4191	.362	1.0669	.7621
13	.1143	.2477		.4191	.381	1.105	.7811
14	.1143	.2667		.381	.381	1.0479	.7811
15	.0953	.3048		.4191	.381	.9145	.8383
16	.2477	.3048		.4382	.381	.8573	.8954
17	.2096	.3239		.2858	.2096	.8192	.9335
18	.2858	.381		.4763	.4191	.4001	.4763
19	.4572	.4001	.5525	.4954	.4191	.4954	.4954
20	.4382	.4191	.5335	.5144	.4382	.4954	.4763
21	.4001	.381	.5144	.4572	.381	.4763	.4763
22	.3429	.362	.4763	.4191	.4191	.4572	.4572
23	.3239		.381	.381	.362	.4191	.4001
24	.3048	.4001		.5335	.8002	.362	.3429
Max	.4763	.6668	.5525	.8573	.9335	1.105	.9335
Min	.0953	.2286	.381	.2477	.2096	.3048	.3048
Avg	.3048	.3993	.4915	.4914	.5739	.6049	.5628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 202 / 11KV SAIGAWN AG (WITH SDT) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.0572		.4382	.3048	.1715	.1524
2	.2667	.0572		.4382	.3048	.1524	.1524
3	.2667	.0762		.4572	.3239	.1524	.1334
4	.2477	.0762		.381	.362	.1524	.1524
5	.2858	.0762		.4191	.381	.1905	.1905
6	.3048	.0762		.4382	.4001	.2286	.2096
7	.3048	.0572		.6287	.4572	.2096	.2096
8	.3048			.6859	.4763	.2286	.1524
9	.381	.3239		.4954	.5525	.2096	.1524
10	.1524	.0762		.1524	.1143	.5335	.4763
11	.0572	.0762		.1715	.1143	.6859	.4954
12	.0572	.0572		.1905	.1143	.8383	.5335
13	.0572	.0762		.1905	.1143	.8002	.5716
14	.0572	.1524		.1524	.1143	.6478	.6097
15	.0572	.1524		.1524	.1143	.6097	.6668
16	.0572	.1524		.1524	.1143	.6668	.7811
17	.1524	.1524		.1524	.1524	.7621	.6097
18	.1524	.1905		.1715		.1905	.2096
19	.1715	.2096	.3429	.1905		.1905	.2286
20	.1524	.2858	.3239	.2096		.1715	.2286
21	.1334	.2667	.3048	.2096		.1905	.1905
22		.2286	.2667	.1905		.1715	.1905
23	.0572		.1524	.1905		.1715	.1905
24	.2477	.0572		.4382	.2858	.1715	.1524
Max	.381	.3239	.3429	.6859	.5525	.8383	.7811
Min	.0572	.0572	.1524	.1524	.1143	.1524	.1334
Avg	.1822	.1334	.2781	.3040	.2667	.3541	.3183



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 203 / 11 KV BELKHEDA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334		.1524	.1715	.3429	.2858
2	.1334	.1334		.1524	.1715	.3429	
3	.1334	.1334		.1715	.1715	.362	
4	.1524	.1524		.1715	.1905	.381	
5	.1905	.1905		.1905	.2096	.381	
6	.2667	.2477		.2096	.2477	.4001	
7	.2858	.3429		.2477	.2667	.4191	
8	.2477	.3048		.2858	.2286	.5335	
9	.2096	.1905		.1905	.2096	.4954	
10	.2667	.362		.4382	.4954	.1905	.381
11	.3048	.362		.4763	.5335	.1524	.0762
12	.3429	.381		.4954	.5525	.1143	.0762
13	.3429	.381		.4954	.5906	.1143	.0762
14	.3048	.381		.5335	.6097	.0953	.0953
15	.3429	.4382		.5335	.6668	.0953	.0953
16	.3048	.4382		.4954	.724	.0953	.0953
17	.3429	.4382		.4382	.6287	.1334	.1143
18	.2096	.2286		.2096	.2096	.1905	.1905
19	.2477	.3048	.2477	.2286		.2667	.1905
20	.2096	.2667	.2096	.2477		.2477	.1905
21	.1905	.2477	.1905	.2477		.2667	.1905
22	.1524	.2477	.1905	.2286		.2477	.2096
23	.1524		.1524	.1905		.1905	.1524
24	.1334	.1334		.1524	.1715	.3048	.2858
Max	.3429	.4382	.2477	.5335	.724	.5335	.381
Min	.1334	.1334	.1524	.1524	.1715	.0953	.0762
Avg	.2334	.2800	.1981	.2993	.3710	.2651	.1691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 204 / 11kv Nagad gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1715		.2477	.2286	.2477	.2477
2	.2096	.1905		.2096	.2286	.2477	.2477
3	.2477	.1905		.2096	.2667	.2667	.2667
4	.2477	.2477		.2667	.3429	.3429	.3048
5	.3239	.3239		.3429	.4001	.3429	.3429
6	.4954	.4954		.5144	.4572	.4763	.4763
7	.5144	.4954		.4954	.3048	.4954	.3239
8	.4572	.4191		.4191	.3048	.362	.2858
9	.4191	.362		.4191	.362	.381	.3429
10	.3239	.2286		.3239	.2667	.3048	.2667
11	.1905	.2096		.2858	.2286	.2477	.2286
12	.1715	.2096		.2477	.2286	.1905	.1905
13	.1715	.1905		.2286	.1905	.1905	.1905
14	.1334	.1715		.2286	.1905		.1905
15	.2096	.1715		.2286	.1905	.2477	.1905
16	.2477	.1905		.2477	.2667		.1905
17	.2667	.2286		.2858	.3048	.2858	.1905
18	.3239	.3429		.3429	.4191	.3239	.3048
19	.3429	.381	.4763	.4001	.381	.4191	.381
20	.3048	.362	.4572	.4382	.3048	.4572	.3239
21	.2096	.3239	.3429	.4001	.2858	.3239	.2096
22	.1905	.3048	.3048	.381	.2858	.2667	.2667
23	.1715		.2667	.4934	.2667	.2667	.2667
24	.2096	.1715		.2477	.2667	.2667	.2477
Max	.5144	.4954	.4763	.5144	.4572	.4954	.4763
Min	.1334	.1715	.2667	.2096	.1905	.1905	.1905
Avg	.2747	.2775	.3696	.3294	.2905	.3161	.2699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 205 / 11kv Belkheda gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2477		.2667	.2477	.2667	.2477
2	.2096	.2477		.2667	.2477	.2667	.2477
3	.2477	.2477		.2477	.3048	.3048	.2667
4	.2858	.3048		.3048	.3429	.3239	.3048
5	.381	.4191		.381	.381	.4954	.4572
6	.4572	.5906		.5525	.4572	.5335	.6097
7		.6097		.4382	.5716	.5525	.5525
8	.4191	.5144		.362	.4382	.5144	.4382
9	.4001	.3429		.362	.3048	.3239	.3429
10	.2667	.1334		.2477	.1905	.1905	.1905
11	.1905	.1143		.1334	.1524	.1334	.1524
12	.1715	.0762		.1334	.1334	.1334	.1334
13	.1715	.0762		.1334	.1334	.1334	.1143
14	.1524	.0953		.1334	.1143	.1524	.0953
15	.1905	.1524		.1334	.1715	.1524	.1143
16	.2477	.1715		.1715	.1905	.1715	.1905
17	.2858	.1905		.2667	.2286	.3239	.2096
18	.4572	.3048		.3429	.2667	.362	.3048
19	.4382	.4191	.5144	.381	.381	.4572	.381
20	.381	.381	.4191	.4001	.4001	.3429	.3429
21	.3239	.3429	.3429	.381	.362	.3048	.362
22	.3048	.3048	.3048	.3429	.3239	.2667	.2858
23	.2667		.2858	.2858	.2858	.2667	.2667
24	.1905	.2667		.2858	.2477	.2667	.2477
Max	.4572	.6097	.5144	.5525	.5716	.5525	.6097
Min	.1524	.0762	.2858	.1334	.1143	.1334	.0953
Avg	.2883	.2849	.3734	.2898	.2866	.3017	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044005 / 33KV NAGAD

Feeder No / Name : 206 / 11kv saigawan gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477	.1715		.2477	.2667	.3048	.1905
2	.2667	.1715		.2477	.2667	.3048	.2096
3	.2667	.1905		.2667	.3429	.3239	.2096
4	.3048	.2477		.3429	.381	.3429	.2667
5	.3429	.3239		.4001	.4191	.5716	.3429
6	.4001	.5335		.5525	.5335	.5525	.5525
7	.4191	.4191		.4001	.5906	.5335	.381
8	.381			.2858	.4954	.4954	.3429
9	.2477	.3048		.2667	.381	.381	.2477
10	.2667	.2096		.2477	.2286	.1524	.2667
11	.1905	.1905		.1905	.1905	.1524	.2286
12	.1524	.1905		.1905	.1715	.1715	.1905
13	.1524	.1715		.1905	.1715	.1524	.1524
14	.1524	.2096		.1715	.1905	.1334	.1143
15	.1524	.2096		.1715	.1905	.1334	.1334
16	.1905	.2096		.1905	.2667	.1905	.2096
17	.2667	.2286		.2858	.3048	.3048	.2667
18	.4191	.3429		.381	.3429	.3048	.3048
19	.4572	.4191	.4763	.4001	.381	.4954	.381
20	.4001	.4001	.381	.4191	.362	.381	.4191
21	.3048	.381	.2858	.4001	.3048	.2667	.362
22	.2477	.3429	.2667	.381	.3048	.2477	.3239
23	.2477		.2667	.3429	.3048	.2096	.2858
24	.2477	.2096		.2477	.2667	.2858	.2096
Max	.4572	.5335	.4763	.5525	.5906	.5716	.5525
Min	.1524	.1715	.2667	.1715	.1715	.1334	.1143
Avg	.2802	.2763	.3353	.3009	.3191	.3080	.2747

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 201 / 11 KV NADARPUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.9431
Max	.9431
Min	.9431
Avg	.9431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 202 / 11 KV PISHOR Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.3772
Max	.3772
Min	.3772
Avg	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 203 / 11kv KOLAMBI AG WITH SDT SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.8916
Max	.8916
Min	.8916
Avg	.8916

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 204 / 11 KV RAMNAGAR

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-SEP-17
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 205 / 11kv Nadarpur gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 206 / 11KV Palashi AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-SEP-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044006 / 33 KV Pishor S/S

Feeder No / Name : 207 / 11KV KOLAMBI GAANTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 201 / 11 KV CHINCHOLI (LI)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2586	.3391	.365	.3448	.9126		.6897
2	.2586	.3429	.365	.3448	.9126	.9126	.6897
3	.3448	.5087	.5476	.4311	1.0951	1.0951	.8621
4	.3448	.5087	.5476	.5173	1.0951	1.0951	1.0345
5	.5173	.5087	.6571	.5173	1.4601	1.4601	1.3794
6	.5173	.6783	.7301	.6035	1.4601	1.4601	1.5518
7	.6035	.6783	.7301	.6897	1.6427	2.0077	1.8966
8	.5173	.6859	.7301	.6897	2.0077	1.8252	1.5518
9	.5087	.8478	.6035	.6035	1.8252	1.2776	1.2069
10	.5087	1.0174	.8621				.3448
11	.5144	.9126	.6897		.7301	1.0951	.6035
12	.5087	.9126	.6897	.5087	.7301	1.0951	.6897
13	.5087	.7301	.5173	.5087	.5476	.8621	.5173
14	.3391	.7301	.5173	.5087	.5476	.6897	.5476
15	.3391	.9126	.5173	.6783	.7301	.5173	.7301
16		.9126	.6897	.8478	.7301	.5173	.7301
17		.9126	.7759	.6783	.9126	.5173	1.0951
18	1.1869	1.0951	.8621	1.0951	1.0951	1.0345	1.0951
19	1.3717	1.4601	1.4601	1.4601	1.2776	1.5518	1.2776
20	1.6956	2.0077	2.0077	1.8252	1.4601	1.638	1.6427
21	1.5432	1.0951	1.4601	1.4601	1.8252	1.3794	1.8195
22	.6783	.7301	1.0951	1.0951	1.4601	1.0345	1.4601
23	.6859	.7301	.8726	.3833	1.0917	.8621	.9126
24	.2586	.3391	.365	.9126	.7301		.6897
Max	1.6956	2.0077	2.0077	1.8252	2.0077	2.0077	1.8966
Min	.2586	.3391	.365	.3448	.5476	.5173	.3448
Avg	.6368	.8165	.7774	.7593	1.1426	1.1394	1.0424

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 202 / 11 KV WAKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3433	.5087	.5173	.515	.3448	.5173	.3433
2	.3433	.6783	.5173	.515	.3448	.6897	.515
3	.515	.8478	.5173	.6008	.5173	.6897	.515
4	.515	.8573	.6897	.6866	.563	.8621	.6866
5	.6866	.8478	.9383	.8583	.6897	1.0345	.8583
6	.8583	1.0174	.8621	1.03	.6897	1.0345	.9441
7	1.03	1.0288	1.0345	.8583	.6897	.8621	1.03
8	.8583	.8573	.8583	.8583	.8726	.8621	1.03
9	.6783	.8478	.515	.6866	.9031	.8031	1.2016
10	.6783	.8573	.8583	.6859		.6897	.6897
11	.6783	.5613	1.03	.8478		.6897	.515
12	.6783	.5173	.8583	.8478	.6897	.515	.3433
13	.6783	.3437	.6866	.6783	.5173	.515	.3433
14	.5087	.3437	.6866	.5087	.3448	.3433	.3448
15	.5087	.3437	.515	.5087	.3448	.3433	.3448
16		.365	.515	.6783	.563	.3433	.3448
17		.3612	.6866	.6783	.563	.515	.5173
18	.8573	.7506	.6866	.5173	.6889	.6008	.6035
19	.8573	.8621	.6897	.6897	.7506	.8583	.563
20	1.0288	.8621	.8621	.6897	.8621	.8583	.6897
21	1.0288	.6897	.8592	.9031	1.0345	.6866	.8592
22	.6859	.7506	.5173	.8621	.8621	.6866	.9355
23	.5144	.6897	.5173	.7453	.8621	.515	.563
24	.3433	.5087	.5173	.346	.5173	.5173	.3433
Max	1.03	1.0288	1.0345	1.03	1.0345	1.0345	1.2016
Min	.3433	.3437	.515	.346	.3448	.3433	.3433
Avg	.6761	.6791	.7057	.6998	.6461	.6680	.6302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 203 / 11 KV GANESHPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.4801
Max	.4801
Min	.4801
Avg	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 204 / 11 KV TAKLI (A)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
23	.4973
Max	.4973
Min	.4973
Avg	.4973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 205 / 11 KV Wadod

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5001	.7461	.6863	.5168	.6283	.5599	.4168
2	.5335	.823	.7405	.5001	.6863	.6141	.4834
3	.5501	.8817	.8308	.5335	.8238	.6502	.5835
4	.6335	.9835	.9211	.6501	.8308	.6863	.6335
5	.9002	1.166	.9211	.9335	.905	.7155	.7502
6	1.1003	1.166	.9753	1.0336	.9211	1.0114	.8169
7	1.1169	1.1869	1.0114	1.0169	.9753	.9211	.8669
8	1.0836	1.1869	1.0476	.9669	.9773	1.1169	.9002
9	.763	.7545	.7002	.6668	.9572	.8502	.9669
10	.4409	.3429	.3501	.5765	.4696	.3001	.3668
11	.407	.4696	.4668	.5765	.3251	.2667	.3001
12	.2713	.5418	.4334	.6104	.2967	.1834	.2167
13	.3052	.578	.4334	.5256	.2167	.1667	.1834
14	.3052	.5599	.4168	.4917	.1806	.1667	.1806
15	.3052	.5418	.4334	.5256	.1745	.2	.1806
16		.4928	.4668	.4748		.2667	.2167
17		.4696	.5001	.5571	.3285	.3334	.289
18	.6859	.5599	.4834	.708	.4696	.7335	.4696
19	.78	.6863	.6502	.8308	.6521	.7668	.5418
20	.8916	.9031	.9503	.9795	.8308	.9002	.5418
21	.8573		1.0837	.9211	.9753	.8502	.7405
22	.5658		.7405	.708	.9031	.7668	.9211
23	.5487	.5963	.6502	.5418	.7405	.6501	.5599
24	.5168	.6613	.6502	.6863	.5418	.5599	.3834
Max	1.1169	1.1869	1.0837	1.0336	.9773	1.1169	.9669
Min	.2713	.3429	.3501	.4748	.1745	.1667	.1806
Avg	.6392	.7408	.6893	.6888	.6439	.5932	.5213



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044026 / 33 KV CHINCHOLI (LI)

Feeder No / Name : 206 / 11 KV NEW NEVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4932	.5765	.5404	.3659	.5235	.5235	.5409
2	.4932	.6443	.6283	.3977	.5235	.5934	.5409
3	.5409	.7461	.6283	.4613	.5585	.6632	.5727
4	.6204	.8139		.5727	.6283	.8028	.6363
5	.6682	.8817	.7155	.6682	.5235	.89	.6522
6	.7795	.8817	.9211	.7159	.8028	.9424	.9386
7	.8591	.9249	.89	.7795	.89	.89	.8272
8	.8272	.9156	1.0645	.8272	.6981	.89	.7795
9	.9496	.8478	.9545	.7318		.6283	.6204
10	.407	.8573	.2864	.3391	.7947	.6863	.5409
11	.3052	.541	.2386	.3391	.8028	.7225	.6522
12	.2713	.4537	.2227		.89	.8002	.7159
13	.2374	.3141	.2227	.3052	1.0122	.7954	.6841
14		.1745	.2386		1.1017	.7954	.8754
15	.3391	.2094	.2386	.2374	1.1867	.8002	.9392
16		.2792	.2704	.3052	.5998	.7795	.9503
17		.2967	.2864	.3258	.6653	.7	.5418
18	.5765	.2348	.4454	.559	.7483	.4773	.6303
19	.823	.8308	.6863	.5253	.733	.6204	.7405
20	.8916	.9031	.8019	.9211	.9075	.8113	.8754
21	.7888	.5418	.89	.8669	.8761	.7636	.6863
22	.5487	.7155	.6632	.5418	.8031	.6522	.6141
23	.463	.5599	.6488		.6632	.6045	.3502
24	.4773	.5256		.4287	.5235	.4537	.5568
Max	.9496	.9249	1.0645	.9211	1.1867	.9424	.9503
Min	.2374	.1745	.2227	.2374	.5235	.4537	.3502
Avg	.5886	.6112	.5674	.5340	.7590	.7203	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 201 / 11 KV NACHANWEL

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.1715	.1715	.1715	.1715	.1715
2	.1886	.1715	.1715	.1715	.1715	.1715	.2572
3	.1715	.1734	.2572	.1715	.2572	.2572	.2572
4	.2829	.2572	.2572	.2572	.2572	.2572	.3429
5	.3429		.3429	.3429	.3429	.2572	.3429
6	.3429	.3429	.4287	.4287	.4287	.1715	
7	.3429	.4287	.3429	.4287	.3429	.4287	.4287
8		.3429	.3429	.3429	.3429	.3429	.4287
9		.2572	.2572	.2572	.2572	.2572	.4287
10	.1715	.1715	.2572	.2572	.3429	.2572	.1715
11	.1715		.2572	.2572	.4287	.3429	.1715
12	.1715	.1715	.3429	.3429	.4287	.4287	.1715
13	.1715	.2572	.3429	.3429	.5144	.5144	.1715
14	.1715	.2572	.3429	.3429	.4287	.5144	.0857
15	.1715	.3429	.2572	.3429	.5144	.5144	.0857
16	.1715	.2572	.3429	.3429	.5144	.5144	.1715
17	.1715	.3429	.3429	.3429	.4287	.4287	.1715
18	.1886	.2572	.3429	.2572	.3429	.2572	.1715
19	.2829	.1715	.3429	.2572	.3429	.2572	.1715
20	.1886	.1715	.3429	.1715	.2572	.2572	.1715
21	.1886	.1715	.2572	.2572	.2572	.1715	.2572
22	.1886	.1715	.1715	.1715	.1715	.1715	.1715
23	.1886	.1715	.1715	.1715	.1715	.1715	.1715
24	.1886	.1715	.1715	.1715	.1715	.1715	.1715
Max	.3429	.4287	.4287	.4287	.5144	.5144	.4287
Min	.1715	.1715	.1715	.1715	.1715	.1715	.0857
Avg	.2112	.2378	.2858	.2751	.3287	.3037	.2237

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 202 / 11 KV DONGARGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.0857	.0857	.1715	.1715	.0857
2	.1886	.0876	.0857	.1715	.1715	.1715	.0857
3	.1886	.1715	.1715	.1715	.1715	.2572	.1715
4	.2829	.1715	.1715	.2572	.1715	.1715	.1715
5	.2572	.1715	.1715	.2572	.2572	.1715	.1715
6	.2572	.1715	.2572	.2572	.2572	.2572	.2572
7	.2572	.2058	.3429	.2572	.3429	.3429	.2572
8	.2572	.2572	.3429	.2572	.4287	.4287	.1715
9	.2572	.1715	.2572	.2572	.3429	.3429	.1715
10	.1715	.0857	.0857	.1715	.1715	.1715	.1715
11	.0857	.0857	.0857	.0857	.0857	.0857	.2572
12	.0857		.0857	.0857	.0857	.0857	.3429
13	.0857	.0857	.0857	.0857	.0857	.0857	.2572
14	.0857	.0857	.0857	.0857	.0857		.3429
15	.0857	.0857	.0857	.0857	.0857		.2572
16	.0857	.0857	.0857	.0857	.0857		.3429
17	.0857	.0857	.0857	.1715	.0857		.3429
18	.0857	.0857	.1715	.1715	.1715	.0857	.1715
19	.1886	.0857	.1715	.0857	.1715	.1715	.1715
20	.1886	.0857	.1715	.0857	.1715	.1715	.2572
21	.1886	.1715	.1715	.1715	.1715	.1715	.1715
22	.0943	.1715	.0857	.0857	.1715	.0857	.1715
23	.0943	.0857	.0343	.0857	.1715	.0857	.0857
24	.1886	.1715	.0857	.0857	.1715	.1715	.0857
Max	.2829	.2572	.3429	.2572	.4287	.4287	.3429
Min	.0857	.0857	.0343	.0857	.0857	.0857	.0857
Avg	.1640	.1320	.1443	.1500	.1786	.1843	.2072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 203 / 11 KV SAROLA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1715	.1715	.1715	.1715	.1715	.1715
2	.2572	.1715	.1715	.2572	.2572	.1715	.1715
3	.2829	.2572	.1715	.2572	.3429	.1715	.1715
4	.3772	.2572	.2572	.3429	.2572	.2829	.2572
5	.3772	.3429	.2572	.3429	.3429	.3429	.3429
6	.3429	.3429	.3429	.4287	.4287	.4287	
7	.3429	.4287	.3429	.4287	.5144	.5144	.3429
8	.3429	.3429	.2572	.4287	.5144	.4287	.2572
9	.3429	.3429	.3429	.4287	.5144	.4287	.3429
10	.2572	.2572	.0857	.1715	.3429	.2572	.2572
11	.1715	.2572	.0857	.0857	.1715	.1715	.3429
12	.1715	.2572	.0857	.0857	.1715	.0857	.3429
13	.1715	.0857	.0857	.0857	.1715	.0857	.2572
14	.1715	.0857	.1715	.0857	.1715	.0857	.2572
15	.1715	.0857	.1715	.1715	.1715	.0857	.2572
16	.1715	.0857	.1715	.1715	.2572	.0857	.1715
17	.1715	.1715	.1715	.1715	.1715	.0857	.2572
18	.1715	.1715	.2572	.1715	.2572	.2572	.1715
19	.3772	.1715	.3429	.2572	.3429	.2286	.1715
20	.3772	.1715	.3429	.1715	.2572	.3429	.1715
21	.2829	.2572	.2572	.2572	.2572	.3429	.2572
22	.1886	.1715	.1715	.1715	.1715	.1715	.1715
23	.1886	.1715	.1715	.0857	.1715	.1715	.1715
24	.2829	.1715	.0857	.0857	.1715	.1715	.1715
Max	.3772	.4287	.3429	.4287	.5144	.5144	.3429
Min	.1715	.0857	.0857	.0857	.1715	.0857	.1715
Avg	.2615	.2179	.2072	.2215	.2751	.2321	.2386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 204 / 11KV DONGARGAON GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0857	.0857	.0857	.0857	.0857	.1714
2	.0943	.0857	.0857	.1715	.0857	.0857	.1714
3	.1715	.0857	.0857	.1715	.1715	.0857	.343
4	.2829	.1715	.0857	.1715	.2572	.1715	.343
5	.2572		.1715	.2572	.2572	.2572	.2572
6	.3429	.2572	.3429	.2572	.3429	.2572	.5144
7	.3429	.2572	.2572		.4287	.3429	.2572
8	.3429	.2572	.2572	.2572	.3429	.1715	.5144
9	.2572	.1715	.1715	.1715	.2572	.1715	.5144
10	.0857	.1715	.0857	.0857	.0857	.0857	.1715
11	.0857	.1715	.0857	.0857	.0857	.0857	.1715
12	.0857	.0857	.0857	.0857	.0857	.0857	.0857
13	.0857	.0857	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857		.0857	.0857	.0857
15	.0857	.0857	.0857	.0857	.0857	.0857	.0857
16	.0857	.0857	.0857	.0857	.0857	.0857	.0857
17	.0857	.0857	.0857	.0572	.0857	.0857	.0857
18	.0857	.0857	.1715	.1715	.1715	.1715	.0857
19	.1886	.1715	.1715	.1715	.1715	.1715	.1715
20	.1886	.1715	.1715	.2572	.1715	.1715	.1715
21	.1886	.1715	.1715	.1715	.1715	.1715	.1715
22	.0943	.0857	.0857	.0857	.0857	.0857	.0857
23	.0943	.0857	.2572	.0857	.0857	.0857	.0857
24	.0857	.0857	.2572	.2572	.0857	.0857	.1714
Max	.3429	.2572	.3429	.2572	.4287	.3429	.5144
Min	.0857	.0857	.0857	.0572	.0857	.0857	.0857
Avg	.1582	.1342	.1465	.1507	.1607	.1357	.2036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 205 / 11 kv NACHANWEL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.1715	.1715	.1715	.1715	.1715	.2572
2	.3772	.1715	.2572	.2572	.1715	.2572	.2572
3	.4715	.2572	.2572	.3429	.2572	.4287	.4287
4	.5658		.4287	.5144	.4287	.6859	.5144
5	.6602	.5144	.6001	.6001	.5144	.7716	
6	.7545		.8573	.7716	.7716	.7716	.6859
7	.6859	.7716	.7716	.7716	.6859	.8573	.6859
8	.6859	.6859	.6859	.6859	.6859	.7716	.5144
9	.6602	.5144	.5144	.5144	.6001	.6859	.6001
10	.3429	.6001	.3429	.3429	.5144	.4287	.5144
11	.2572	.5144	.1715	.1715	.4287	.2572	.3429
12	.1715		.1715	.1715	.2572	.2572	.3429
13	.1715	.0857	.1715	.1715	.3429	.2572	.1715
14	.1715	.0857	.1715	.1715	.3429	.2572	.1715
15	.1715	.1715	.1715	.1715	.2572	.2572	.1715
16	.1715	.1715	.1715	.1715	.2572	.2572	.2572
17	.2572	.1715	.2572	.2572	.2572	.2572	.2572
18	.3429	.1715	.4287	.3429	.5144	.4287	.3429
19	.6602	.2572	.5144	.4287	.6001	.5144	.3429
20	.5658	.2572	.4287	.3429	.6001	.6859	.4287
21	.3772	.3429	.3429	.3429	.4287	.4287	.4287
22	.2829	.3429	.2572	.2572	.3429	.2572	.3429
23	.1886	.2572	.1715	.1715	.2572	.1715	.2572
24	.2829	.1715	.1715	.1715	.1715	.1715	.1715
Max	.7545	.7716	.8573	.7716	.7716	.8573	.6859
Min	.1715	.0857	.1715	.1715	.1715	.1715	.1715
Avg	.3983	.3184	.3537	.3465	.4108	.4287	.3690

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 206 / 11 kv SAROLA GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0857	.1715	.0857	.1715	.1715	.0857
2	.0943	.0857	.2572	.1715	.1715	.1715	.1715
3	.1715	.1715	.2572	.2572	.2572	.1715	.2572
4	.2829	.2572	.3429	.3429	.3429	.2572	
5	.3772		.4287	.4287	.4287	.3429	.3429
6	.4715	.4287	.5144	.5144	.5144	.3429	.4287
7	.4287	.4287	.6001	.5144	.6001	.5144	.4287
8	.4715		.4287	.4287	.5144	.5144	.3429
9	.4287	.3429	.4801	.3429	.4287	.4287	.3429
10	.2572	.2572	.1715	.1715	.2572	.2572	
11	.0857	.1715	.0857	.0857	.1715	.1715	.2572
12	.0857	.1715	.0857	.0857	.0857	.0857	.1715
13	.0857	.1715	.0857	.0857	.0857	.0857	.0857
14	.0857	.0857	.0857	.0857	.0857	.0857	.1715
15	.0857	.0857	.0857	.0857	.0857	.3086	.0857
16	.0857	.0857	.0857	.0857	.1715	.1715	.0857
17	.0857	.0857	.0857	.0857	.1715	.1715	.1715
18	.1715	.1715	.2572	.1715	.2572	.2572	.2572
19	.3772	.1715	.3429	.1715	.3429	.3429	.2572
20	.3772	.2572	.3429	.2572	.2572	.3429	.1715
21	.1886	.1715	.2572	.2572	.2572	.2572	.1715
22	.0943	.1715	.1715	.1715	.1715	.1715	.1715
23	.0943	.0857	.0857	.1715	.1715	.0857	.1715
24	.0943	.0905	.1715	.0857	.1715	.1715	.0857
Max	.4715	.4287	.6001	.5144	.6001	.5144	.4287
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2115	.1834	.2450	.2143	.2572	.2451	.2143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 207 / MOHADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1715	.0857	.0857	.0857	.1715	.0857
2	.1886	.1715	.0857	.1715	.1715	.1715	.0857
3	.1886		.1715	.1715	.1715	.1715	.0857
4	.1715	.1715	.1715	.2572	.1715	.2572	.0857
5	.2572	.1715	.2572	.2572	.2572	.3429	.0857
6	.2572	.1715	.2572	.3429	.2572	.3429	
7	.2572	.2572	.2572	.3429	.3429	.4287	.1715
8	.2572	.2058	.3429	.3429	.4287	.5144	.1715
9	.2572	.1715	.2572	.3429	.4287	.5144	.1715
10	.1715	.0857	.0857	.1715	.3429	.0857	.1715
11	.0857	.0857	.0857	.1715	.1715	.0857	.1715
12	.0857	.0857	.0857	.0857	.0857	.0857	.2572
13	.0857	.0857	.0857	.0857	.0857	.0857	.2572
14	.1715	.0857	.0857	.0857	.0857	.0857	.2572
15	.1715	.0857	.0857	.0857	.0857	.0857	.3429
16	.1715	.0857	.0857	.0857	.0857	.0857	.2572
17	.1715	.0857	.0857	.0857	.0857	.0857	.3429
18	.1715	.0857	.0857	.0857	.0857	.0857	.1715
19	.1886	.0857	.0857	.0857	.1715	.0857	.0857
20	.1886	.1715	.1715	.0857	.1715	.1715	.0857
21	.1886	.0857	.0857	.0857	.0857	.1715	.0857
22	.1886	.0857	.0857	.0857	.0857	.0857	.0857
23	.1886	.0857	.0857	.0857	.0857	.0857	.0857
24	.1886	.1715	.0857	.0857	.0857	.1715	.0857
Max	.2572	.2572	.3429	.3429	.4287	.5144	.3429
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1850	.1282	.1357	.1572	.1715	.1857	.1603



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044028 / 33 KV NACHANWEL

Feeder No / Name : 210 / MOHRA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886		.1715	.0857	.1715	.0857	.1715
2	.1715		.1715	.1734	.1715	.1715	.2572
3	.2829		.1715	.1715	.1715	.1715	.2572
4	.2829		.2572	.2572	.1715	.1715	
5	.3772		.1715	.3429	.2572	.2572	.3429
6	.3772		.3429	.3429	.3429	.3429	.3429
7	.3429		.3429	.3429	.4287	.4287	.3429
8	.2572		.2572	.3429	.4287	.3429	.3429
9	.1715		.1715	.2058	.3429	.2572	.2572
10	.1715		.1715	.1734	.1715	.2572	.1715
11	.1715		.1715	.1715	.1715	.2572	.1715
12	.1715		.1715	.1715	.2572	.2572	.1715
13	.1715	.0857	.1715	.1715	.3429	.2572	.1715
14	.1715	.0857	.1715	.1715	.2572	.2572	.0857
15	.1715	.0857	.1715	.1715	.2572	.2572	.0857
16	.1715	.0857	.1715	.1715	.1715	.1715	.0857
17	.1715	.1715	.1715	.1715	.1715	.1715	.0857
18	.1715	.1715	.1715	.2572	.1715	.2572	.0857
19	.2829	.1715	.1715	.2572	.2572	.2572	.1715
20	.2829	.2572	.2572	.1715	.2572	.3429	.1715
21		.1715	.2572	.1715	.1715	.3429	.0857
22		.1715	.1715	.0857	.1715	.2572	.1715
23		.1715	.0857	.0857	.0857	.1715	.0857
24	.1886		.1715	.0857	.0857	.0857	.1734
Max	.3772	.2572	.3429	.3429	.4287	.4287	.3429
Min	.1715	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.2262	.1481	.1965	.1981	.2286	.2429	.1865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 201 / 11 KV WASADI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2058	.1715	.2401	.2241	.1715	.192
2	.2401	.2058	.1715	.2401	.2241	.1715	.192
3	.2401	.2058	.1715	.2401	.2401	.1715	.3201
4	.2721	.3086	.2572	.3201	.3201	.2572	.4161
5	.3521	.3429	.3429	.4001	.4801	.3429	.4801
6	.4321	.4801	.463	.4801	.6401	.4287	.5761
7	.5601	.5658	.6859	.4801	.8002	.4287	.5601
8	.6401	.7716	.8002	1.0479	.9602	.3429	.4801
9	.6401	.8573	.8002	.9602	.9602	.2572	.3361
10	.16	.2572	.144	.2401	.3429	.6401	.5601
11	.16	.2572	.144	.144	.1715	.6401	.6401
12	.128	.0857	.096	.112	.0514	.7682	.6401
13	.128	.0857	.096	.112	.0514	.8162	
14		.0514	.096	.112	.0514	.8907	.8802
15	.128	.0514	.096	.112	.0514	.7682	.9602
16	.128	.0514		.144	.0514	.7682	1.0402
17	.192	.1543	.096	.096	.1543	.7522	1.0402
18	.3841	.2058	.112	.2401	.2572	.208	.144
19	.4481	.4287	.2881	.3201	.5144	.4161	.3521
20	.3201	.4287	.2881	.3841	.3429	.3521	.3201
21	.2561	.3429	.208	.2401	.2572	.2241	.2561
22	.2241	.2572	.16	.2241	.2058	.2241	.192
23	.192	.1715	.16	.192	.2058	.192	.16
24	.2401	.192	.1715	.192	.192	.1715	.192
Max	.6401	.8573	.8002	1.0479	.9602	.8907	1.0402
Min	.128	.0514	.096	.096	.0514	.1715	.144
Avg	.2915	.2902	.2617	.3031	.3229	.4335	.4752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 202 / 11KV NIMBHORA AG

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1715	.1715	.1905	.1524	.2572	.2058
2	.1524	.1715	.1715	.1905	.1524	.2572	.2058
3	.1905	.1715	.2572	.1905	.1524	.3429	.2972
4	.1905	.1715	.2572	.2096	.1715	.4287	.3048
5	.2096	.2058	.2572	.2286	.1905	.5144	.3506
6	.2477	.2058	.2743	.2477	.2286	.6001	.4001
7	.2096	.2058	.1715	.2667	.2858	.8573	.8002
8	.1905	.1715	.2858	.2286	.2477	1.2003	.8002
9	.1905	.1715	.1524	.1905	.2286	1.3717	1.0402
10	.4572	.3429	.4763	.2591	.4287	.0953	.1524
11	.4572	.5144	.6859	.6097	.703	.0953	.0953
12	.3048	.6001	.7621	.6401	.8745	.0953	.0953
13	.3048	.6001	.6859	.6249	.8916	.1143	.0953
14	.3201	.6344	.6859	.6718	.8573	.0572	.0953
15	.4481	.6344	.6859	.703	.8573		.0953
16	.5144	.6344	.4287	.7042	.8573		.0762
17	.4763	.6173	.4287	.7362	.4458		.1143
18	.1143	.0857	.0648	.0953	.1029		.208
19	.2286	.12	.2286	.1905	.1715	.1905	.2286
20	.3048	.1029	.2286	.1905	.1715	.1905	.2286
21	.1905	.1715	.1905	.1905	.1715	.1905	.1905
22	.1905	.1715	.1905	.1524	.1543	.1905	.1905
23	.1905	.1715	.1905	.1524	.1372	.1524	.1905
24	.1524	.1715	.1715	.1905	.1524	.1715	.2058
Max	.5144	.6344	.7621	.7362	.8916	1.3717	1.0402
Min	.1143	.0857	.0648	.0953	.1029	.0572	.0762
Avg	.2662	.3008	.3376	.3356	.3661	.3687	.2778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 203 / 11KV DEVPUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1715	.16	.16	.144	.2572	.2401
2	.1905	.1715	.16	.16	.144	.2572	.2401
3	.1905	.1715	.2401	.192	.16	.2572	.2401
4	.2286	.2401	.2561	.2401	.192	.3429	.3201
5	.3048	.2743	.3429	.2721	.2241	.4287	.3841
6	.3201	.3086	.3201	.3201	.2561	.5144	.4481
7	.2881	.3429	.2858	.3201	.2881	.6859	.6401
8	.2721	.3429	.2401	.2881	.2881	.8573	.6882
9	.2401	.2572	.2401	.2267	.2401	.8573	.7202
10	.2241	.2572	.3201	.2561	.4287	.208	.16
11		.2572	.4321	.4321	.6001	.16	.096
12		.2572	.4321	.4641	.6001	.128	.096
13	.208		.4001	.5281	.6001	.096	.096
14	.208	.2572	.4572	.6081		.128	.096
15	.208	.2572	.3841	.6081			.096
16	.2401	.3429	.3201		.6859		.096
17	.2401	.2915	.4763	.4961	.7202	.144	.08
18	.144	.12	.381	.096	.1029	.144	.096
19	.2561	.2058	.096	.208	.3429	.2401	.2401
20	.2241	.2058	.2241	.2401	.3429	.192	.192
21	.16	.1715	.192	.16	.2572	.144	.16
22	.16	.1715	.16	.16	.1715	.144	.16
23	.144	.1715	.16	.144	.1715	.144	.16
24	.1905	.144	.1715	.16	.144	.1715	.192
Max	.3201	.3429	.4763	.6081	.7202	.8573	.7202
Min	.144	.12	.096	.096	.1029	.096	.08
Avg	.2197	.2344	.2855	.2930	.3229	.2955	.2474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 204 / 11 KV MEHGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1029	.0857	.0953	.0533	.0857	.0762
2	.0953	.1029	.0953	.0953	.0553	.0857	.0762
3	.0953	.1029	.0857	.0953	.0572	.0857	.0762
4	.1334	.1372	.1905	.0953	.1143	.1715	.1143
5	.1524	.1372	.1905	.1334	.1692	.1715	.1524
6	.1524	.1715	.1905	.1905	.2172	.1715	.1905
7	.1886	.1886	.1905	.2286	.2343	.1715	.1143
8	.1905	.2572	.1905	.1943	.2812	.1715	.1143
9	.1692	.2572	.2096	.2896	.2667	.0857	.1143
10	.0572	.0857	.0762	.0762	.0857	.1143	.2229
11	.0572	.0857	.0381	.0572	.0857	.2286	.2753
12	.0572	.0857	.0381	.0572	.0857	.2858	.2591
13	.0572	.0857	.0381	.0572	.0857	.3144	.2591
14	.0381	.0514	.0381	.0572	.0514	.2606	.2743
15	.0762	.0514	.0572	.0572	.0514	.2824	.3048
16	.0572	.0514	.0572	.0572	.0514	.2256	.3429
17	.0953	.0514	.0572	.0762	.0857	.1974	.2286
18	.0953	.0857	.0572	.0953	.0857	.0953	.0953
19	.0953	.1029	.1143	.1143	.1715	.1524	.1334
20	.0953	.0857	.1334	.1143	.1715	.1334	.0953
21	.0953	.0857	.1143		.1715	.0953	.0762
22	.0953	.0857	.0762	.0953	.0857	.0953	.0572
23	.0762	.0857	.0572	.0762	.0857	.0762	.0572
24	.0953	.0524	.0857	.0953	.0524	.0857	.0762
Max	.1905	.2572	.2096	.2896	.2812	.3144	.3429
Min	.0381	.0514	.0381	.0572	.0514	.0762	.0572
Avg	.1007	.1079	.1028	.1089	.1190	.1601	.1578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 205 / 11KV NIMBHORA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0857	.0953	.0762	.0747	.0857	.0934
2	.0762	.0857	.0953	.0762	.0747	.0857	.0934
3	.1143	.9774	.0953	.0762	.0934	.0857	.1494
4	.1524	.1029	.1905	.0953	.1494	.1715	.1867
5	.2096	.1372	.2858		.1867	.1715	.1867
6	.3048	.1372	.2858	.1143	.1867	.1715	.1867
7	.1334	.1372	.2858	.2477	.1494	.2572	.2614
8	.1143	.1715	.1905	.1143	.1494	.1715	.2054
9	.112	.1715	.1905	.1715	.1494	.1715	.1867
10	.112	.1715	.0953	.112	.0857	.112	.0953
11	.112	.0857	.0572	.0934	.0857	.112	.0572
12	.112	.0857	.0572	.0934	.0857	.0934	.0572
13	.0934	.0857	.0572	.056	.0857	.0747	.0572
14	.0747	.0857	.0572	.056	.0514	.0747	.0572
15		.0514	.0572	.0747	.0514		.0762
16		.0514	.0572	.0747	.0857		.0762
17		.0514	.0572	.0934	.0857		.0572
18	.2241	.0857	.0572	.1307	.1715		.0953
19	.1867	.1715	.1715	.1867	.2229	.2614	.1905
20	.1494	.1715	.2096	.1867	.1715	.2241	.1524
21	.0934	.0857	.1334	.112	.1715	.1494	.1143
22	.0934	.0857	.0953	.0934	.0857	.112	.0762
23	.0934	.0857	.0762	.0934	.0857	.0934	.0762
24	.0762	.0934	.0857	.0762	.0747	.0857	.0934
Max	.3048	.9774	.2858	.2477	.2229	.2614	.2614
Min	.0747	.0514	.0572	.056	.0514	.0747	.0572
Avg	.1292	.1439	.1266	.1089	.1173	.1382	.1201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 206 / 11KV WASADI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0857	.0857	.0762	.0747	.0857	.0934
2	.0572	.0857	.0857	.0762	.0747	.0857	.0934
3	.0762	.0857	.0857	.0762	.0934	.0857	.1307
4	.1143	.1372	.1715	.1143	.1494	.1715	.1867
5	.1524	.1715	.2572	.1524	.1867	.1715	.2241
6	.2096	.2058	.2572	.2096	.2241	.2572	.2427
7	.2286	.2229	.2572	.2286	.2427	.2572	.2241
8	.2096	.1715	.1905	.1905	.2054	.1715	.2241
9	.168	.1715	.1905	.1715	.1867	.1715	.1867
10	.1307	.1715	.1334	.1307	.1715	.1867	.1524
11	.112	.0857	.1334	.0934	.0857	.168	.0953
12	.112	.0857	.0953	.0934	.0857	.1494	.0953
13	.0934	.0857	.0762	.0934	.12	.1494	.0953
14		.0857	.0762	.0934	.0857	.0747	.0953
15	.0934	.0514	.0762	.0934	.0857	.1307	.0953
16	.0934	.0514	.0762	.0747	.0857	.1307	.0953
17	.0934	.0514	.0762	.0934	.0857	.1494	.2477
18	.1494	.0857		.0934	.1715	.1494	.1524
19	.1867	.1715	.1524	.1867	.1715	.2241	.1905
20	.168	.1715	.2286	.168	.1715	.2241	.1334
21	.0934	.1715	.1524	.1494	.1715	.1494	.1143
22	.0934	.0857	.1143	.1307	.0857	.1307	.0762
23	.0934	.0857	.0762	.112	.0857	.112	.0762
24		.0934	.0857	.0762	.112	.0857	.0934
Max	.2286	.2229	.2572	.2286	.2427	.2572	.2477
Min	.0572	.0514	.0762	.0747	.0747	.0747	.0762
Avg	.1266	.1196	.1363	.1241	.1339	.1530	.1423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044046 / 33 KV WASADI

Feeder No / Name : 207 / 11KV MEHGAON GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1372	.1715	.1143	.1494	.1715	.1494
2	.1524	.1372	.1715	.1143	.1494	.1715	.1494
3	.2286	.1715	.1715	.1524	.1867	.1715	.1867
4	.3239	.3086	.2572	.3048	.2987	.2572	.3361
5	.4572	.4115	.4287	.4191	.3734	.4287	.4108
6	.5716	.4458	.5144	.5144	.4854	.5144	.4668
7		.5144	.5144	.5525	.5415	.3429	.4108
8	.4954	.4287	.4763	.4763	.4668	.3429	.3547
9	.3734	.3429	.2477	.381	.3361	.2572	.3547
10	.2614	.1715	.1334	.2241	.1715	.1867	.1905
11	.2614	.0857		.0934	.0857	.1494	.0953
12		.0857		.0934	.0857	.1307	.0953
13	.0934	.0857	.0953	.0934	.0857	.0934	.0953
14	.0747	.0857	.0953	.0934		.0747	.0762
15	.0934	.0514	.0953	.112			.0953
16	.0934	.0514	.0953	.112	.0857		.0953
17	.168	.12	.0953	.1494	.1715	.1867	.1524
18	.3361	.1715	.0953	.2241	.1715	.2427	.1524
19	.2987	.2915	.3239	.3734	.4287	.4294	.381
20	.2614	.2915	.381	.3734	.3429	.3361	.3239
21	.2054	.2572	.2858	.2054	.2572	.1867	.2477
22	.1867	.1715	.2096	.1494	.1715	.1494	.1905
23	.1307	.1715	.1715	.1494	.1715	.1307	.1524
24	.1143	.1307	.1715	.1143	.1494	.1715	.1307
Max	.5716	.5144	.5144	.5525	.5415	.5144	.4668
Min	.0747	.0514	.0953	.0934	.0857	.0747	.0762
Avg	.2407	.2133	.2364	.2329	.2439	.2330	.2206



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 201 / 11 KV KARANJKHEDA AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0572	.0762	.0171	.0762	.1029
2			.0572	.0572		.0762	
3	.0171	.0171	.0572	.0572	.0171	.0572	.1372
4			.0572	.0572		.0572	
5	.0171	.0171	.0572	.0572	.0171	.0572	.1715
6			.0381	.0572		.0572	
7	.0171	.0171	.0381	.0572	.0171	.0572	.2058
8		.0171	.0381	.0572		.0572	
9	.0171	.0171	.0191	.0572	.0191		.3429
10		.1524	.0191		.2134		
11	.1886	.1524	.2134	.1715	.2743	.2058	.0171
12		.2286	.2439		.381		
13	.0351	.2286	.2439	.2229	.3201	.2401	.0171
14		.2134	.2591		.3353		
15	.2572	.2134	.2591	.2229	.381	.2572	.0171
16		.2134	.2591		.3963		
17	.2915	.2134	.2591	.3258	.3963	.2401	.0171
18		.0191	.0572		.0572		
19	.0171	.0381	.0572	.0171	.0572	.0171	.0171
20		.0572	.0572		.0572		
21	.0171	.0572	.0572	.0171	.0572	.0171	.0171
22		.0572	.0572		.0572		
23	.0171	.0572	.0572	.0171	.0572	.0171	.0171
24	.0171	.0171	.0572	.0572	.0171	.0762	.061
Max	.2915	.2286	.2591	.3258	.3963	.2572	.3429
Min	.0171	.0171	.0191	.0171	.0171	.0171	.0171
Avg	.0713	.0963	.1074	.0933	.1573	.0979	.0878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 202 / 11 KV NAGAPUR AG ( WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.3601	.4801	.2896	.2743	.1829	.2058
2			.3048	.2439		.2134	
3	.3258	.4115	.3048	.2743	.3086	.2439	.2743
4			.3353	.2743		.3353	
5	.3429	.4287	.3353	.3048	.3429	.3963	.4458
6			.3963	.3048		.4268	
7	.3944	.3944	.2439	.381	.4287	.503	.4801
8		.3601	.2286	.381	.463		
9	.3258	.3601	.2439	.4572	.4973		.2915
10		.381	.1524		.442		
11	.3258	.2286	.1524	.1715	.2743	.2058	.4458
12		.1219	.1372		.2743		
13	.2743	.1524	.1219	.1543	.2439	.2401	.3601
14		.1524	.1524		.3048		
15	.2572	.1677		.2058	.381	.3258	.3258
16		.1524	.1981		.3963		
17	.1886	.1524	.1981	.2915	.4115	.2915	
18		.1372	.1715		.1715		
19	.1715	.1886	.1715	.1715	.1715	.2229	.1543
20		.1886	.1715		.1886		
21	.1543	.1886	.1715	.1715	.1886	.1886	.1543
22		.1543	.1372		.1715		
23	.1543	.1372	.1543	.1543	.1372	.1543	.1543
24	.1372	.3429	.381	.1677	.1886	.1677	.1886
Max	.3944	.4287	.4801	.4572	.4973	.503	.4801
Min	.1372	.1219	.1219	.1543	.1372	.1543	.1543
Avg	.2453	.2458	.2323	.2588	.2981	.2732	.2901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 204 / 11kv KARANJKHEDA GAONTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.463	.3429	.3429	.4801	.3429	.3429
2			.3772	.3772		.3772	
3	.4458	.5144	.3772	.3601	.4973	.3944	.4458
4			.4801	.4973	.4973	.4458	
5	.5487	.6173	.5144	.5144	.6687	.4801	.6173
6			.6516	.823		.6516	
7	.7202	.8573	.823	.8916	.8916	.8745	.8745
8		.3429	.8402	.8573	.9431		
9	.7202	.3944	.5144	.823	.8402		.823
10		.6687	.4801		.823		
11		.5144	.3944	.5144	.5487	.5487	.583
12		.3772	.3086		.4115		
13	.463	.3429	.3258	.463	.3772	.463	.4458
14		.2915	.3258		.3601		
15	.3429	.3258	.3086	.4287	.3772	.3601	.4458
16		.3258	.3429		.4458		
17	.4287	.3429	.3601	.463	.4801	.463	.4115
18		.4458	.5144		.6859		
19	.4801	.6516	.7373	.7202	.7202	.6687	.6687
20		.6859	.6516		.7373		
21	.4973	.7202	.6001	.5144	.6516	.6516	.583
22		.5487	.4458		.5144		
23	.3429	.3772	.4115	.4115	.3944	.3944	.4458
24	.3429	.4287	.3429	.3429	.3429	.3429	.3429
Max	.7202	.8573	.8402	.8916	.9431	.8745	.8745
Min	.3429	.2915	.3086	.3429	.3429	.3429	.3429
Avg	.4730	.4875	.4780	.5497	.5768	.4973	.5408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 205 / 11KV REULGAON AG (WITH SEPARATED AG FEEDERS HAVING SPECIAL  
SDT) Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0171	.0914	.0914	.1029	.0914	.0171
2			.3201	.0914		.1067	
3	.1543	.1372	.3658	.0914	.12	.1067	.0171
4			.1067	.1067		.1219	
5	.1715	.1715	.1334	.1067	.12	.1677	.0171
6			.1219	.1334		.1677	
7	.1715	.2058	.1219	.1981	.2229	.1981	.0171
8		.1715	.2286	.2134	.2401	.1981	
9	.1886	.1715	.1524	.2286	.1715	.2134	.0343
10		.0191	.0191		.0191		
11	.0171	.0191	.0191	.0171	.0191	.0171	.2058
12		.0191	.0191		.0191		
13	.0171	.0191	.0191	.0171	.0191	.0171	.1715
14		.0191	.0191		.0191		
15	.0171	.0191	.0191		.0191	.0171	.2058
16		.0191	.0191		.0191		
17	.0171	.0191	.0191	.0171	.0191	.0171	
18			.0191		.0191		
19	.0171	.0191	.0191	.0171	.0191	.0171	.0152
20		.0191	.0191		.0191		.0171
21	.0171	.0191	.0191	.0171	.0191	.0171	.0171
22		.0191	.0191		.0191		
23	.0171	.0191	.0191	.0171	.0191	.0171	.0171
24	.12	.12	.0914	.0914	.1543	.0914	.0171
Max	.1886	.2058	.3658	.2286	.2401	.2134	.2058
Min	.0171	.0171	.0191	.0171	.0191	.0171	.0152
Avg	.0804	.0621	.0834	.0909	.0666	.0931	.0592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044050 / 33KV NAGAPUR

Feeder No / Name : 206 / CHIMNAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2058	.2058	.2058	.2058		.2058
2			.2058	.2058			
3	.2572	.2401	.2401	.2058	1.406		.2401
4			.2743	.3086			
5	.3429	.3086	.3086	.3429	.3429		.3601
6			.3429	.3944			
7	.3429	.3429	.4115	.3772	.3258		.3601
8			.2401	.3086	.3258		
9	.2401	.2058	.1715	.2401	.2743		.2572
10		.2401	.1372		.3601		
11	.12	.1886	.0686	.1715	.1715	.1715	.1715
12		.1715	.0686		.0857		
13	.1372	.1543	.0686	.1372	.0857	.1372	.2058
14		.1029	.0762		.0686		
15	.2572	.0857	.12	.1372	.0857	.1715	.1886
16		.1029	.12		.1029		
17	.2572	.12	.1029	.1543	.12	.1543	
18		.2229	.1715		.1372		
19	.2572	.3086	.1715	.2058	.3258	.1886	.2229
20		.3429	.3772		.2743		
21	.2743	.4115	.4115	.3086	.2401	.2401	.2572
22		.3772	.2401		.1715		
23	.2058	.1372	.1372	.1543	.1543	.1543	.2058
24	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Max	.3429	.4115	.4115	.3944	1.406	.2401	.3601
Min	.12	.0857	.0686	.1372	.0686	.1372	.1715
Avg	.2361	.2221	.2018	.2370	.2588	.1736	.2372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 201 / SHELGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
23	.703
24	.703
Max	.703
Min	.703
Avg	.703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

PISHOR SDN[873]

BU 4873

Substation No/ Name :- 044103 / SHELGAON

Feeder No / Name : 203 / 11kV JAMADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 200 / 11 kv Narmada Express      NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder Feeder KV- 11 /      (CONTINUOUS PROCESS)(NO STAGGERING)  
OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 201 / 11 Kv Deulgaon(Bz) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.1494	.112	.2641	.2713	.1886	.1886
2				.3395	.3391		.2263
3	.112	.1867	.1867	.3772	.4915	.2829	.3018
4				.415			.3395
5	.2241	.2033	.2614	.4715		.415	.3772
6	.2987		.2801	.5658			.4715
7		.1463	.2957	.6036		.5281	.5281
8		.181	.2629	.4904		.4715	.415
9	.2543		.132	.1696	.5658	.1132	.3018
10			.1143	.1296		.1463	.1619
11	.1696		.1334	.1017	.1017	.1543	.2881
12	.2035		.0943	.1017	.1029	.1402	.2591
13			.0754	.128		.1075	.1943
14	.1696	.1886	.0754	.1457	.0838	.0914	.1619
15		.1509	.0943			.0905	.1966
16	.2204		.0943	.176	.0671	.0886	
17		.1509	.132	.192	.0857	.1097	.2267
18		.3395	.1886			.2263	.2713
19	.1526		.3395	.2294	.3772		.2713
20		.3018	.415				.3052
21				.3391	.3395		.3391
22	.1865	.2829					
23	.2204	.1886		.407	.2263		.373
24	.0934	.1886	.0943	1.2003		.1886	.1886
Max	.2987	.3395	.415	1.2003	.5658	.5281	.5281
Min	.0934	.1463	.0754	.1017	.0671	.0886	.1619
Avg	.1846	.2045	.1780	.3424	.2543	.2089	.2903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 202 / 11 Kv Kotnandra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.5601	.2801	1.2449		1.0374	.9431
2				1.3203			1.094
3	.4108	.7095	.4066	1.4335		1.2449	1.1694
4				1.6598			1.2449
5	.5487	.6584	.5601	1.8107		1.4712	1.4335
6	.6468		.6653	1.8484			1.5089
7		.7316	.823	1.6975		1.6032	1.6598
8	.5658	.6201	.8478	1.6032		1.4335	1.3203
9			.2829	1.3565	1.1694	1.226	1.0185
10	.5658		.3429	.3277		.5144	.426
11			.2667	.5761	.3814	.506	.4858
12	.7733		.2263	.4641	.4287	.5868	.583
13			.2263	.6478		.4973	.4961
14	.7167	.415	.2452	.7362	.4687	.4641	.583
15		.3772	.2641	.7373		.4915	
16	.5658		.2829		.5668	.4858	.639
17		.3772	.415	.503	.7011	.4915	.8139
18	.5847	1.1317	.5847			.6036	
19			1.094	1.0343	1.1317		.8309
20	.6036	1.3203	1.3717	1.0513			
21					1.3957		.8648
22		1.0374		1.0513			.8987
23	.5847	.8488		1.0174	1.3203		
24	.3734	.5601	.3361	.5087		1.1317	.7922
Max	.7733	1.3203	1.3717	1.8484	1.3957	1.6032	1.6598
Min	.3326	.3772	.2263	.3277	.3814	.4641	.426
Avg	.5594	.7190	.5011	1.0776	.8404	.8618	.9403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 203 / 11 Kv Ghatnandra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.5601	.3326	1.1203	.8648	1.1317	1.0374
2				1.2449	.8817		1.1317
3	.4066	.7316	.4572	1.4146	1.0174	1.3203	1.2449
4				1.6221			1.419
5	.6653	.8501	.6653	1.7353		1.6032	1.643
6	.7316		.7842	1.8484			1.7924
7		.7373	.8501	1.6975		1.8484	1.8298
8		.7802	.8764	1.6409		1.6598	1.6804
9	.6478		.7545	1.3735	1.5278	1.358	1.643
10			.9431	.6783		.4668	1.3748
11	.6443		.8299	.664	.4458	.5249	.6478
12	.6554		.7545	.6478	.4854	.4525	.6722
13	.7773		.5975	.6562	.5144	.3982	.6882
14		1.0374	.7621	.6802	.5201	.3761	
15	.6952	.8676	.8299	.7537		.4049	.6882
16				.7773	.7011	.543	
17	.639	1.0562		.9717	.5935	.5853	.7461
18		1.4712	1.4937			1.531	.78
19	.7122		1.8298	1.0513	1.6975		
20		1.6221	1.6804				.7865
21	.7122			.6443	1.6221		.8309
22		1.3203					.6783
23	.6952	1.226		.6952	1.2449		.8648
24	.4668	.4294	.3734	1.1203		1.1317	1.1317
Max	.7773	1.6221	1.8298	1.8484	1.6975	1.8484	1.8298
Min	.3361	.4294	.3326	.6443	.4458	.3761	.6478
Avg	.6275	.9761	.8714	1.0970	.9320	.9585	1.1101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 204 / 11 Kv Shindephal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.5729	.2263	.679	.5087	.5658	.4715
2				.8676	.6443		.5658
3	.4066	.5601	.3772	.9431	.6783	.8676	.7545
4				1.1317			.9054
5	.5544	.6653	.4854	1.2449		1.1317	1.0374
6	.5975		.5601	1.3203			1.1317
7		.6859	.695	1.2449		1.1694	1.2449
8		.6588	.6859	1.094		1.094	1.1317
9	.5935		.415	.373	.7733	.9431	.8299
10			.4763	.3441		.4287	.4915
11	.6443		.4191	.3277	.3605	.426	.6443
12	.5087		.3429	.3932	.3841	.3429	.3561
13			.2858	.4858		.3189	.5087
14	.6783	.4715		.6081	.3479	.2835	
15		.4904	.3048	.6554		.3277	.3887
16	.6952		.381	.6882	.2622	.3647	
17		.4527	.5281	.6718	.3155	.3353	.4534
18	.8139	.9054	.6602	.6783		.5847	.5087
19			.9431		1.1694		
20	.9496	1.0562	1.2826	.6226			.6104
21					1.0974		
22	1.0174	.8488		.6952			.663
23	1.0159	.5658		.7122	.8488		.6952
24	.2987	.3361	.2241	.4287		.7545	.5658
Max	1.0174	1.0562	1.2826	1.3203	1.1694	1.1694	1.2449
Min	.2801	.3361	.2241	.3277	.2622	.2835	.3561
Avg	.6467	.6361	.5163	.7368	.6159	.6212	.6979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044016 / 33 KV DEOLGAON BAZAR

Feeder No / Name : 205 / 11 Kv Charner SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.3361	.1867	.4715	.3391	.415	.3772
2				.5658			.415
3	.2241	.2957	.2218	.679	.6104	.5658	.4338
4				.7545			.4763
5	.2772	.3292	.2402	.7922		.8488	.5716
6	.2926		.2561	.8676			.6859
7			.4458	.6859		.679	.724
8	.3544	.3429	.4915	.5716		.5658	.5716
9			.0943	.3391	.7545	.4191	.4001
10	.1886		.0953	.502		.4096	.3441
11			.0762	.4915	.463	.4586	.3563
12	.2263		.0762	.4748		.5407	.407
13			.0762	.4801		.5304	.5243
14	.2075	.1509	.0953	.6226	.4481	.4687	.4858
15		.1509	.1143	.6783		.4572	
16	.2075			.7122	.5121	.4572	.6952
17		.1509	.1524	.6952	.5144	.4096	.7122
18	.2452	.3395	.2667	.3052		.2286	.78
19			.4191		.4904		
20	.2829	.4527	.5716	.2543			.8309
21					.4715		
22		.3772		.3052			.8648
23	.1886	.2829		.3222	.415		.8817
24	.2263	.2241	.1867	.4287		.3772	.3395
Max	.3544	.4527	.5716	.8676	.7545	.8488	.8817
Min	.1867	.1509	.0762	.2543	.3391	.2286	.3395
Avg	.2391	.2861	.2259	.5454	.5019	.4895	.5656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 202 / 11kv Undengaon feeder  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
23	.6379	
24		.631
Max	.6379	.631
Min	.6379	.631
Avg	.6379	.631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 203 / 11Kv Khedi feeder  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
23	.591	
24		.4031
Max	.591	.4031
Min	.591	.4031
Avg	.591	.4031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 204 / 11Kv Khandala feeder  
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
23	.1791	
24		.0532
Max	.1791	.0532
Min	.1791	.0532
Avg	.1791	.0532



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044027 / 33 KV GOLEGAON

Feeder No / Name : 207 / 11Kv Mandna feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	31-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
23	.394	
24		.4119
Max	.394	.4119
Min	.394	.4119
Avg	.394	.4119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044030 / 33 KV BHARADI

Feeder No / Name : 201 / 11 Kv Bharadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
6	2.4822	
7	2.0576	
23		1.829
24		2.0348
<b>Max</b>	<b>2.4822</b>	<b>2.0348</b>
<b>Min</b>	<b>2.0576</b>	<b>1.829</b>
<b>Avg</b>	<b>2.2699</b>	<b>1.9319</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044030 / 33 KV BHARADI

Feeder No / Name : 203 / 11 Kv Dhanora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
6	3.4625	
24		2.572
Max	3.4625	2.572
Min	3.4625	2.572
Avg	3.4625	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044030 / 33 KV BHARADI

Feeder No / Name : 204 / 11 KV Upali

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
6	1.2336	
24		2.7149
<b>Max</b>	<b>1.2336</b>	<b>2.7149</b>
<b>Min</b>	<b>1.2336</b>	<b>2.7149</b>
<b>Avg</b>	<b>1.2336</b>	<b>2.7149</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044030 / 33 KV BHARADI

Feeder No / Name : 205 / Shrikrushna FDR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	01-SEP-17
HR	Load (MW)	Load (MW)
6	.0087	
23		.0857
24		.0857
Max	.0087	.0857
Min	.0087	.0857
Avg	.0087	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 201 / 11Kv Sirsala Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.1886	.1478	.1698	.1509	.1526
2	.1886	.1698	.1886	.1478	.1698	.1509	.1526
3	.1886	.1698	.1886	.1646	.1698	.1509	.1526
4	.1886	.1867	.1886	.1646	.1698	.1698	.1696
5	.1886	.1867	.1886	.181	.1886	.1886	.2204
6	.1886	.1867	.2075	.1848	.1886	.1886	.2883
7	.1886	.1509	.1698	.1646	.1698	.1509	.2652
8	.1509	.1132	.1132	.1663	.132	.1132	.2984
9	.1132	.0566	.0566	.1509		.1478	.285
10	.2204	.12	.1715	.2035	.0754	.2515	.0566
11	.2204	.1017	.2229	.2204	.2058	.2486	.0924
12	.2515	.2035	.2401	.2229	.2401	.2486	.0739
13	.2515	.2035	.2058	.2321	.2572	.2486	.0739
14	.218		.2229	.1886	.2572	.2458	.0739
15	.218	.1526	.2229	.2652	.2572	.2486	.0732
16	.2347	.1526	.2401	.2486	.2229	.2486	.0914
17	.2347	.1526	.2486	.2652	.2572	.2486	
18	.132	.0754	.1097	.0754	.2263	.132	.1109
19	.1698	.132	.1097	.1509	.1886	.1509	.1294
20	.168	.1509	.1463	.1698	.1698	.1509	.1646
21	.168	.1886	.1646	.1698	.132	.1509	.1646
22	.1698	.1886	.1848	.1886	.132	.1698	.1478
23	.1646	.1886	.1663	.1886	.132	.1698	.1483
24	.1886	.168	.1886	.1663	.1886	.132	.1526
Max	.2515	.2035	.2486	.2652	.2572	.2515	.2984
Min	.1132	.0566	.0566	.0754	.0754	.1132	.0566
Avg	.1914	.1552	.1806	.1845	.1870	.1857	.1538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 202 / 11Kv Hatti Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.0943	.132	.0943	.0943	.132	.1187
2	.1509	.0943	.132	.0943	.0943	.132	.1187
3	.1509	.0943	.132	.0943	.0943	.132	.1187
4	.1509	.0943	.132	.132	.0943	.132	.1187
5	.1698	.1698	.132	.1478	.132	.1509	.1526
6	.1509	.1698	.1509	.1478	.1509	.1509	.2035
7	.1509	.1509	.132	.1478	.1509	.132	.0857
8	.132	.1509	.1132	.132	.1132	.1132	.2058
9	.1132	.1132	.0566	.0943	.0754	.0943	.2683
10	.12	.1543	.0857	.1543		.1677	.0377
11	.12	.2204	.1543	.2058	.2229	.2486	.0377
12	.1715	.2035	.1494	.2035	.2401	.2486	.0377
13	.1372	.1865	.1372	.2401	.2058	.2984	.0377
14	.1543	.1865	.2058	.2204	.2572	.3315	.0377
15	.1715	.1526	.1886	.2204	.3086	.2984	.0377
16	.1543	.1696	.1715	.2204	.2572	.2818	.0377
17	.1543	.1696	.1677	.2486	.2229	.2321	.0377
18	.1132	.0566	.0754	.0943	.1509	.0754	.0754
19	.132	.1132	.1132	.132	.1509	.1132	.0754
20	.132	.132	.1132	.1509	.1509	.1132	.0943
21	.1132	.1509	.1132	.1509	.1509	.0943	.0943
22	.132	.132	.132	.132	.132	.0943	.0943
23	.132	.0943	.1132	.132	.132	.0943	.0943
24	.1509	.132	.132	.1132	.1132	.132	.1187
Max	.1715	.2204	.2058	.2486	.3086	.3315	.2683
Min	.1132	.0566	.0566	.0943	.0754	.0754	.0377
Avg	.1420	.1411	.1319	.1543	.1607	.1664	.0975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 203 / 11Kv Ambhai Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0377	.0189	.0189	.0189	.0189	.0339
2	.0189	.0377	.0189	.0189	.0189	.0189	.0339
3	.0189	.0377	.0189	.0189	.0189	.0189	.0339
4	.0189	.0377	.0189	.0189	.0189	.0189	.0339
5	.0189	.0377	.0189	.0189	.0189	.0189	.0339
6	.1132	.0377	.0189	.0189	.0189	.0189	.0509
7	.0189	.0377	.0189	.0189	.0189	.0189	.0838
8	.0189	.0377	.0189	.0189	.0189	.0189	.0686
9	.0189	.0377	.0189	.0189	.0189	.0189	.0857
10	.1029	.0514	.0857	.0514		.0514	.0189
11	.1029	.0678	.1029	.0857	.12	.0943	.0189
12	.12	.1017	.12	.1029	.0686	.1187	.0189
13	.12	.1017	.12	.1029	.12	.1357	.0189
14	.12		.12	.056	.1372	.1357	.0189
15	.12	.0678	.12	.0857	.1543	.1357	.0189
16	.1029	.0678	.12	.12	.0857	.1357	.0189
17	.1029	.0678	.12	.12	.12	.1187	
18	.0189	.0189	.0189	.0189	.0189	.0189	.0189
19	.0377	.0189	.0189	.0189	.0189	.0189	.0189
20	.0377	.0189	.0189	.0189	.0189	.0189	.0189
21	.0377	.0189	.0189	.0189	.0189	.0189	.0189
22	.0377	.0189	.0189	.0189	.0189	.0189	.0189
23	.0377	.0189	.0189	.0189	.0189	.0189	.0189
24	.0189	.0377	.0189	.0189	.0189	.0189	.0377
Max	.12	.1017	.12	.12	.1543	.1357	.0857
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0576	.0442	.0505	.0428	.0482	.0512	.0323



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 204 / 11Kv Chinchpur feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1029	.0339	.1029	.1715	.1696	.0377
2	.1017	.1029	.0339	.1029	.1715	.1696	.0377
3		.1029	.0339	.1372	.1715	.1696	.0377
4		.12	.0678	.1372	.1715	.1696	.0377
5		.12	.1017	.1509	.2035	.2543	.0377
6		.1543	.1017	.2012	.2374	.3391	.0377
7		.3688	.2035	.3521	.547	.5935	.0189
8		.5138	.3561	.5138	.6554	.9156	.0189
9		.4973	.4917	.5304	.6464	.9808	.0189
10		.0189	.0171	.0189	.0171	.0566	.503
11		.0189	.0171	.0189	.0171	.0377	.5138
12	.0189	.0189	.0343	.0189	.0171	.0377	.9614
13	.0189	.0377	.0171	.0189	.0171	.0377	.8421
14	.0189	.0754	.0343	.0189	.0171	.0377	.9012
15	.0189	.0754	.0343	.0189	.0171	.0377	.8848
16	.0189	.0377	.0343	.0189	.0171	.0377	.8745
17	.0189	.0377	.0377	.0189	.0171	.0377	.9012
18	.0377	.0377	.0377	.0189	.0189	.0189	.0189
19	.0377	.0189	.0377	.0189	.0377	.0377	.0189
20	.0377	.0189	.0377	.0189	.0377	.0377	.0377
21	.0377	.0377	.0377	.0189	.0377	.0377	.0377
22	.0377	.0189	.0377	.0189	.0377	.0377	.0377
23	.0377	.0189	.0377	.0189	.0377	.0377	.0377
24	.1017	.12	.0339	.1372	.1715	.1357	.0377
Max	.1017	.5138	.4917	.5304	.6554	.9808	.9614
Min	.0189	.0189	.0171	.0189	.0171	.0189	.0189
Avg	.0430	.1114	.0796	.1096	.1455	.1844	.2871

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 205 / 11Kv Ambhai Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3174	.3361	.3361	.3174	.3174	.3361
2	.3734	.3174	.3361	.3361	.3174	.3174	.3361
3	.3734	.3174	.3361	.4108	.3174	.3361	.3361
4	.6535	.3734	.3734	.4252	.3734	.4668	.3734
5	.6535	.4294	.5041	.4908	.4668	.5601	.4668
6	.6722	.6653	.8029	.5959	.6283	.7468	.5975
7	.7282	.2801	.6722	.4908	.3921	.5601	.2987
8	.6535	.4108	.5415	.5434	.4108	.2241	.3734
9	.6161	.5228	.5228	.6348	.3734	.5041	.3734
10	.5041	.4294	.3429	.5975	.3086	.5228	.3734
11	.4108	.3361	.2572	.5415	.1886	.4108	.3921
12	.3921	.3174	.2229	.5415	.1886	.3361	.3734
13	.3361	.3174	.2572	.4668	.2401	.3734	.3361
14	.3174		.2572	.4294	.2572	.4108	.3734
15	.3921	.3734	.2572	.3361	.2915	.3734	.3734
16	.4668	.3734	.3429	.3361	.4287	.3734	.3734
17	.5415	.4668	.3734	.4481	.5144	.3174	
18	.5228	.5415	.4108	.5975	.5601	.5601	.4908
19	.5415	.5601	.4108	.6099	.4854	.5041	.5258
20	.5228	.5228	.4908	.4481	.5041	.4668	.5258
21	.4108	.4294	.5258	.4108	.4668	.4108	.4207
22	.3734	.3734	.4294	.3734	.3921	.3734	.4108
23	.3361	.3361	.3734	.3361	.3734	.3361	.3734
24	.3734	.3174	.3361	.3361	.3174	.3361	.3361
Max	.7282	.6653	.8029	.6348	.6283	.7468	.5975
Min	.3174	.2801	.2229	.3361	.1886	.2241	.2987
Avg	.4808	.4056	.4047	.4614	.3798	.4224	.3987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 206 / 11Kv Nanegaon feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.0754	.0914	.0943	.1132	.0848
2	.0943		.0754	.0914	.0943	.1132	.0848
3	.0943		.0754	.0914	.0943	.1132	.0848
4	.0943		.0754	.0924	.0943	.1132	.0848
5	.0943		.0754	.0914	.0943	.1132	.0848
6	.0943		.0943	.0914	.0943	.132	.0848
7	.0943		.0754	.0914	.0943	.1132	.1372
8	.1132		.0189	.0924	.0754	.0943	.12
9	.1132		.0754	.0943	.0566	.0943	.1006
10	.0754		.1029	.1372	.12	.1357	.0377
11	.0754		.1029	.1357	.12	.1357	.0377
12	.0943		.1543	.1372	.1372	.1357	.0377
13	.1357		.1715	.1543	.12	.1357	.0377
14	.1543		.1715	.12	.12	.1357	.0377
15	.0857	.0848	.1372	.0857	.1543	.0678	.0566
16	.0754	.0848	.1029	.0514	.1543	.0678	.0566
17	.1029	.0848	.0943	.1029	.2058	.0678	
18	.1132	.0754	.0943	.0566	.1886	.0754	.0566
19	.112	.0754	.0943	.0377	.1509	.0943	.0754
20	.1132	.0754	.0943	.1132	.132	.0943	.0754
21	.1132	.0943	.1132	.1132	.132	.0754	.0754
22	.1132	.0754	.1132	.1132	.1132	.0754	.0754
23		.0754	.1097	.1132	.1132	.0754	.0754
24	.0943		.0754	.1097	.0943	.1132	.0678
Max	.1543	.0943	.1715	.1543	.2058	.1357	.1372
Min	.0754	.0754	.0189	.0377	.0566	.0678	.0377
Avg	.1019	.0806	.0989	.1004	.1187	.1035	.0726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 207 / 11Kv Ghatambri Feeder

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1029	.0678	.0686	.1372	.1017	.0189
2	.1017	.1029	.0678	.0686	.1372	.1017	.0189
3	.1017	.1029	.0678	.0857	.1372	.1017	.0189
4	.1526	.1029	.1017	.0857	.1543	.1017	.0189
5	.1865	.1372	.1696	.1029	.1543	.1696	.0566
6	.1865	.1029	.2035	.1357	.1696	.1865	.0943
7	.1696	.2515	.2374	.1341	.2543	.2204	.0857
8	.1357	.2204	.2374	.1677	.2543	.2713	.0343
9	.1187	.1543	.3921	.1715	.2984	.3772	.0189
10	.0189	.0189	.0343	.0189	.0171	.0377	.0857
11	.0189	.0189	.0343	.0189	.0171	.0377	.1372
12	.0189	.0189	.0343	.0189	.0171	.0377	.1341
13	.0189	.0189	.0343	.0189	.0171	.0377	.1326
14	.0189	.0189	.0343	.0189	.0171	.0377	.1677
15	.0189	.0189	.0343	.0189	.0343	.0377	.1677
16	.0189	.0189	.0343	.0189	.0343	.0377	.1677
17	.0189	.0189	.0343	.0189	.0343	.0377	.1372
18	.0189	.0189	.0189	.0377	.0189	.0189	.0189
19	.0189	.0189	.0377	.0377	.0189	.0189	.0189
20	.0189	.0189	.0189	.0377	.0189	.0189	.0189
21	.0189	.0189	.0189	.0377	.0189	.0189	.0189
22	.0189	.0189	.0189	.0377	.0189	.0189	.0189
23	.0189	.0189	.0189	.0377	.0189	.0189	.0189
24	.017	.1543	.0678	.0343	.1029	.0377	.0189
Max	.1865	.2515	.3921	.1715	.2984	.3772	.1677
Min	.017	.0189	.0189	.0189	.0171	.0189	.0189
Avg	.0640	.0707	.0841	.0597	.0876	.0869	.0678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044057 / 33 KV AMBHAI

Feeder No / Name : 208 / 11Kv Hatti Gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3174	.3174	.3361	.3174	.2054	.3174
2	.3734	.3174	.3174	.3361	.3174	.2054	.3174
3	.3734	.3361	.3174	.4252	.3547	.2054	.3174
4	.3734	.4481	.3734	.5258	.5228	.2241	.4668
5	.7095	.6099	.5601	.5959	.6468	.2427	.5601
6	.7095	.8686	.9522	.8413	.9055	.2801	.8402
7	.6908	.7762	.8215	.7362	.8131	.2241	.7202
8	.6722	.7207	.6348	.7186	.7023	.2054	.7888
9	.6535	.5544	.5788	.5228	.5975	.1494	.5487
10	.3921	.3174	.3429	.2054	.3772	.112	.2743
11	.2241	.2427	.1715	.2241	.2229	.2241	.2229
12	.2241	.2241	.1715	.1867	.1715	.2241	.2058
13	.2241	.2241	.1715	.1698	.1886	.2054	.1867
14	.1867	.2054	.1715	.168	.2058	.2054	.1867
15	.2075	.2614	.1715	.168	.2058	.2241	.1867
16	.2801	.2614	.2058	.2241	.2229	.2801	.2054
17	.3921	.2987	.2801	.2987	.2572	.3734	.2987
18	.5601	.2987	.443	.5041	.3734	.6161	.4908
19	.7023	.5041	.6661	.7947	.5601	.8029	.5316
20	.5228	.4668	.5959	.6099	.7468	.7468	.6661
21	.4294	.4108	.4961	.4805	.4668	.5975	.5959
22	.3734	.3734	.3734	3.8836	.3921	.3734	.3361
23	.3361	.3174	.3361	.3395	.3361	.3361	.3361
24	.3734	.3174	.3174	.2987	.3174	.3361	.3361
Max	.7095	.8686	.9522	3.8836	.9055	.8029	.8402
Min	.1867	.2054	.1715	.168	.1715	.112	.1867
Avg	.4316	.4030	.4078	.5664	.4259	.3166	.4140

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 201 / 11Kv Jalki Bazar Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8686	.6348	.362	.6348	.439	.5316	.4854
2	.823	.6653	.3841	.6135	.4572	.6154	.5228
3	.7392	.7468	.3326	.6516	.4887	.6661	.5228
4	1.0534	.7842	.4024	.631	.5373	.7108	.5601
5	1.46	.7975	.462	.6415	.5731	.7455	.5601
6	1.6632	.8939	.4572	.6344	.6201	.7975	.5975
7	1.5684	.8029	.4287	.7282	.8238	.9088	.5975
8	1.4784	.6468	1.2883	.7282	.9431	1.1488	.5415
9	1.1128	.6283	.4733	.5544	.9335	1.3169	.499
10	.7023	.6878	.3511	.4294	.4805	.2241	.4525
11	.3174	.5249	.3142	.3772	.3921	.2427	.3982
12	.2947	.543	.2614	.3395	.2957	.3361	.4938
13	.3086	.5853	.3018	.3395	.2772	.4294	.3582
14	.3326	.4835	.3511	.3206	.3174	.4481	.3258
15	.3511	.3982	.4527		.3696	.5601	.3258
16	.3511	.4344	.5228		.4481	.6722	.4163
17	.4287	.499	.6653		.5729	.7468	.462
18	.5415	.5175	.8029		.7655	.8589	.9055
19	.6161	.5914	.7655	1.1458	.8316	.9335	1.1643
20	.6838	.7207	.7095	1.0164	.8029	1.0456	1.1273
21	.7577	.924	.6722	.961	.7842	1.1203	1.1016
22	.7392	.8686	.5914	.9522	.7655	1.1576	.9979
23	.7842	.6036	.6348	.9149	.7468	.9335	.9425
24	.9055	.4801	.4163	.3696	.4066	.4481	
Max	1.6632	.924	1.2883	1.1458	.9431	1.3169	1.1643
Min	.2947	.3982	.2614	.3206	.2772	.2241	.3258
Avg	.7867	.6443	.5168	.6492	.5864	.7333	.6243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 202 / 11Kv Shivna Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	1.0164	.543	.6485	.695	.443	1.307
2	.7392	1.0867	.567	.7186	.7602	.5258	1.4563
3	.961	1.2308	.6697	.7888	.8059	.6135	1.531
4	1.1643	1.3003	.7682	.9055	.8954	.7087	1.6804
5	1.5524	1.4217	.9328	.9795	.9568	.9568	1.6804
6	1.6461	1.5261	1.0534	.9991	1.0631	1.0229	1.8298
7	1.6817	1.6301	1.0498	1.1827	1.1218	1.0852	1.8298
8	1.7551	1.4918	1.0341	1.1317	1.3565	1.2209	1.7551
9	1.4377	1.4784	1.0229	1.4377	.9425	1.3546	1.6057
10	1.1389	1.0608	.7282	1.8296	1.1088	.8589	.9412
11	.7888	.8316	.5544	1.7177	.8962	.9709	.9055
12	.7373	.7682	.5228	1.587	.8402	.8589	.9231
13	.7373	.8131	.462	1.4937	.8775	.7468	.905
14	.7455	.7577	.4805	1.419	.9149	.8215	.8688
15	.7362	.7207	.5175		.9979	.8589	.823
16	.7108	.7316	.5544		1.0829	1.1203	.8954
17	.7537	.7577	.6099		1.1949	1.1203	.9593
18	1.1883	.7392	.7023		1.2696	1.2323	1.1706
19	1.1643	.9055	.7095	1.7926	1.5339	1.307	1.3169
20	1.1643	.9412	.7023	1.6632	1.4784	1.3817	1.2936
21	1.1643	.924	.7023	1.5708	1.4003	1.4563	1.2752
22	1.1949	.9055	.6653	1.5497	1.307	1.307	1.1643
23	1.2197	.8686	.6283	1.4937	1.226	1.1576	1.1203
24	.8131	.8573	.6036	.6099	.6283	.9709	
Max	1.7551	1.6301	1.0534	1.8296	1.5339	1.4563	1.8298
Min	.7108	.7207	.462	.6099	.6283	.443	.823
Avg	1.0803	1.0319	.6993	1.2760	1.0564	1.0042	1.2712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 203 / 11Kv Amsari Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7716	.2743	.2103	.2801	.2401	.0934
2	.7207	.8238	.2772		.3142	.2774	.0934
3	.6838	.8495	.2957		.3292	.3155	.0934
4	.7392	.8939	.3258	.2801	.4024	.333	.0934
5	.7682	.9189	.4251	.2772	.5121	.3506	.0934
6	.8316	.9431	.462	.2801	.6268	.3681	.0934
7	.8131	.4435	.3988	.4435	.5068	.4382	.0934
8	.8402	.5765	.4207	.4287	.3898	.4382	.0747
9	.6348	.5914	.4207	.3734	.3326	.583	.0739
10	.4207	.6219	.4481	.2587	.2614	.1867	.2926
11	.2481	.2772	.3696	.2452	.2772	.2241	.2896
12	.2543	.2957	.2829	.2641	.2801	.2241	.2896
13	.2572	.2926	.3142	.2641	.2614	.2987	.2743
14	.2572	.2926	.3511	.2829	.2587	.3734	.2353
15	.2572	.2957	.3881	.3018	.2587	.4108	.2534
16	.2572	.2957	.4481	.3395	.2587	.4854	.4525
17	.2572	.2957	.4435	.3772	.2614	.4854	.4572
18	.4481	.2801	.4481	.4715	.462	.5601	.6838
19	.4481	.3142	.4294	.6161	.462	.5975	.8402
20	.4481	.3511	.415	.7095	.4715	.6348	.7947
21	.4435	.3881	.3921	.6535	.4481	.6722	.7842
22	.462	.3658	.4108	.6161	.4435	.5601	.7392
23	.4854	.3142	.4251	.5975	.4108	.4108	.695
24	.5544	.4854	.2534	.2454	.2614	.2801	
Max	.8402	.9431	.462	.7095	.6268	.6722	.8402
Min	.2481	.2772	.2534	.2103	.2587	.1867	.0739
Avg	.5109	.4991	.3800	.3880	.3655	.4062	.3428



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 204 / 11Kv Pimpaldari Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.4066	.9149	.9335	1.4377	.8316	.7316
2	.3881	.4435	.8775	1.0164	1.4563	.9335	.7682
3	.4294	.4904	.9425	1.0903	1.531	1.0374	.7682
4	.499	.5601	1.1016	1.1949	1.6804	1.1203	.7865
5	.6838	.6348	1.3306	1.3014	1.7926	1.2136	.8413
6	.7392	.7095	1.4415	1.3676	1.9589	1.3306	.9145
7	.7716	.961	1.3676	1.6263	1.885	1.5684	.9511
8	.8962	.8962	1.3443	1.5893	1.848	1.5684	.9145
9	1.0867	.924	1.307	1.2136	1.4784	1.531	.8686
10	1.419	.8501	.7095	.7964	.6653	.5853	1.2567
11	1.6804	1.1458	.6024	.7087	.6173	.7316	1.307
12	1.0082	1.1643	.5487	.6447	.6379	.7316	
13	1.1016	1.0974	.5175	.6219	.5658	.695	
14	1.1827	.9979	.5415	.5792	.5087	.695	
15	1.2883	.8131	.5375	.5373	.5935	.695	
16	1.3676	.8962	.5914	.5068	.6859	.6584	1.307
17	1.4563	.961	.5975	.5853	.7377	.5853	1.3443
18	1.1458	1.2136	1.2197	1.9044	1.307	1.1203	1.386
19	1.1273	1.2382	1.1763	1.9589	1.1088	1.2323	1.3817
20		1.2752	1.1088	1.7741	1.2012	1.3443	1.3306
21	1.1576	1.2936	1.0829	1.5524	1.1203	1.5684	1.307
22	1.1576	1.2136	1.0164	1.5154	1.0269	1.6804	1.2382
23	1.1827	1.1389	.9335	1.4563	.9335	1.6804	1.1643
24	.4066	1.0269	.924	.8501	1.419	.439	
Max	1.6804	1.2936	1.4415	1.9589	1.9589	1.6804	1.386
Min	.3696	.4066	.5175	.5068	.5087	.439	.7316
Avg	.9802	.9313	.9473	1.1386	1.1749	1.0657	1.0825

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 205 / 11Kv Halda Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6348	1.0751	1.1088	.8676	.8316	.6584
2	.6468	.7095	1.0269	1.2012	.8865	1.0164	.6584
3	.7392	.7842	1.0185	1.386	.9242	1.2012	.695
4	1.0903	.8589	1.3014	1.6804	1.0082	1.386	.695
5	1.1643	1.0456	1.5844	1.8111	1.1949	1.5708	.695
6	1.2936	1.2323	1.7353	2.1068	1.419	1.848	.7316
7	1.2696	1.262	1.6057	1.9044	1.1949	1.7372	.7316
8	1.1458	1.4563	1.4937	2.0328	.9709	1.5893	
9	1.0642	1.4415	1.419	1.3957	.9335	1.1576	
10	.961	1.1088	.7712	.6661	.8238	1.0242	
11	.8871	.9335	.8413	.6173	.9156	1.0974	
12	.8215	.961	.9114	.5487	.9717	1.1706	
13	.8589	.924	.9088	.5087	.6783	1.2803	
14	.8962	.823	.8817	.4801	.2218	1.2803	
15	.9335	.7947	.9088	.4748	.6173	1.0608	
16	.9709	.924	.9568	.5144	1.0059	.9511	.5601
17	1.1576	1.0642	.9979	.5201	.9326	.9145	.7733
18	1.094	1.2449	.8871	.6036	.924		1.4335
19	1.1576	1.358	1.0903	1.2136	1.5524		1.6032
20	1.2382	1.4146	1.1088	1.1576	1.386		1.5655
21	1.3443	1.4712	1.5123	1.0456	1.307		1.5466
22	1.2136	1.358	1.386	.9709	1.2136	1.0456	1.358
23	1.1203	1.3014	1.2136	.8676	1.1203	1.0456	1.226
24	.6908	.5601	1.1317	1.2696	.8488	.7842	
Max	1.3443	1.4712	1.7353	2.1068	1.5524	1.848	1.6032
Min	.6468	.5601	.7712	.4748	.2218	.7842	.5601
Avg	1.0175	1.0694	1.1570	1.0869	.9966	1.1996	.9954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 206 / 11Kv Digras feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.3696	1.1203	.8402	1.226	.7762	.5853
2	.5041	.4294	1.2197	.9055	1.2637	.8402	.6584
3	.5544	.4904	1.2936	.9997	1.3443	.8686	.6722
4	.5914	.5601	1.4003	1.0829	1.4563	1.0082	.695
5	.6838	.5914	1.5684	1.1576	1.6244	1.1576	.695
6	.695	.6413	1.6991	1.2382	1.7741	1.251	.7316
7	.7655	.8589	1.531	1.363	1.7002	1.2936	.7499
8	.8316	.8865	1.363	1.4146	1.5893	1.2382	.7682
9	.924	.8871	1.2012	1.0829	1.0903	1.1576	.7282
10	1.0164	.7682	.5201	.7265	.6161	.7316	1.307
11	1.1088	1.0349	.5914	.6783	.6348	.8413	1.2197
12	.9896	1.0719	.5895	.6516	.6173	.8048	
13	.9979	.9979	.5144	.6485	.5967	.7865	
14	1.0164	.9694	.5426	.6068	.5935	.7682	
15	1.0349	.9425	.583	.6241	.6516	.7316	
16	1.0751	1.1273	.6241	.6516	.6415	.695	1.3256
17	1.1458	1.307	.6838	.6935	.6783	.7095	1.46
18	.9522	1.358	1.0082	1.3256	1.0829	.8215	1.3443
19	.961	1.3491	.9795	1.5708	1.2012	.9335	1.4003
20	.9896	1.4563	.9522	1.4045	.8215	1.1576	1.3121
21	.9896	1.475	.9425	1.2936	.8215	1.2696	1.1763
22	.8383	1.3676	.8962	1.2696	.8962	1.307	1.1203
23	.8402	1.2696	.8501	1.2136	.9335	1.307	1.0269
24	.4481	.7545	1.1203	.7655	1.2071	.4668	
Max	1.1458	1.475	1.6991	1.5708	1.7741	1.307	1.46
Min	.4481	.3696	.5144	.6068	.5935	.4668	.5853
Avg	.8507	.9568	.9914	1.0087	1.0443	.9551	.9988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044067 / 33 KV AJANTHA

Feeder No / Name : 207 / Water Supply FDR  
Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0173		.0173				
7	.0173	.0171	.0171	.0171	.0173	.0171	.0173
8	.0173	.0171	.0171	.0171	.0173	.0171	.0173
9	.0171	.0173	.0171	.0343	.0171	.0171	.0347
10	.0343	.0347	.0343	.0343	.0171	.0171	.0347
11	.0343	.0347	.0343	.0343	.0171	.0343	.0347
12	.0343	.0347	.0343	.0343	.0171	.0171	.0347
13	.0343	.0347	.0343	.0343	.0343	.0171	.0347
14	.0343	.0347	.0343	.0343	.0343	.0347	.0347
15	.0343	.0347	.0343	.0343	.0171	.0347	.0347
16	.0343	.0347	.0343	.0343	.0171	.0347	.0347
17	.0343	.0347	.0343	.0343	.0343	.0347	.0347
18	.0343	.0347	.0343	.0343	.0343	.0347	.0347
19						.0347	
Max	.0343	.0347	.0343	.0343	.0343	.0347	.0347
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0173
Avg	.0291	.0303	.0290	.0314	.0229	.0265	.0318

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 201 / 11KV BHAVAN (NILLOD)

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.4108	.2347	.5144	.5601	.5144	.5601
2	.2572	.4481	.2683	.583	.5975	.5487	.6348
3	.2915	.4748	.3185	.6516	.6722	.823	.6104
4	.3429	.5975	.3647	.8573	.7969	1.0288	.7095
5	.5144	.8589	.4475	1.166	1.4377	1.2003	.8589
6	.6859	1.0829	.7459	1.3889	1.6057	1.3375	1.2696
7	1.0974	1.1389	.8288	1.3717	1.6244	1.3375	1.251
8	1.1317	1.2883	1.3763	1.2346	1.2136	.8648	1.1389
9	.9259	1.1949	1.0688	.8745	1.1203	.8402	
10	.6104	.6036	.4904	1.1949	.9709	.8589	.5197
11	.3361	.3772	.3429	1.6244	1.286	1.2742	.7377
12	.2241	.3772	.3086	1.6057	1.4746	1.4937	.8718
13	.2035		.3086	1.587	1.4403	1.4003	
14		.3206	.3772	1.587	1.2346	1.2696	
15	.3361	.3584	.3601	1.4937	1.2689	1.1576	1.1469
16	.3734	.3961	.4115	1.4563	1.1317	.6348	1.3108
17	.4294	.3395		1.2323	1.166	.3921	1.1961
18		.3584	.583	.5228	.5487	.6443	.5788
19	1.1389	.8299	.9945	.9709	1.0288	1.1203	1.0082
20	1.0829	.7733	.9431	1.1203	1.0631	.9709	
21	1.0082	.679	.6516	.7468	.6516	.9259	.7545
22	.5788	.5847	.6173	.6348	.6516		.6535
23	.5087	.547	.5487	.5601	.6173	.7095	.5658
24	.2229	.3734	.2012	.5144	.5228	.5487	.5601
Max	1.1389	1.2883	1.3763	1.6244	1.6244	1.4937	1.3108
Min	.2035	.3206	.2012	.5144	.5228	.3921	.5197
Avg	.5692	.6267	.5562	1.0622	1.0286	.952	.8469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 202 / 11 KV BORGAON KH

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	1.0829	1.094	.9259	.9335	.9945	.7461
2	1.0288	1.0456	1.1317	.9259	1.0082	.9945	.9335
3	1.0288	1.0082	1.1883	.9945	1.1576	1.0288	1.0456
4	1.0974	1.0829	1.2637	1.0974	1.4377	1.2003	1.4003
5	1.166	1.2323	1.358	1.1317	2.1472	1.7833	1.6804
6	1.2003	1.2548	1.4937	1.2003	2.8753	2.4691	2.3525
7	1.2346	1.4563	1.0829	1.7833	3.0434	2.8292	2.3899
8	1.166	1.1203	.7655	2.0748	3.062	3.4705	3.0247
9	.9945	.8402	.6161	1.9547	2.6699	3.3981	2.1285
10	.5041	.7045	1.0322	.5601	.8589	.6722	.6602
11	.5041	1.0322		.4917	.6859		.679
12	.6348	.8192			.6516	1.0395	
13	.7095	1.0978	1.2689		.6859	1.1203	1.0374
14	.8402	.9995	1.8519	1.0082	.9259	1.0829	1.0082
15	.7468	1.065	1.9204	1.0082	.9259	1.1203	1.1128
16	.7468	1.0486	2.0233	1.0456	1.0288	1.1576	1.1016
17	.7468	1.0159	2.0748		1.1317		1.0829
18		.4915	.6516	.9149	1.286	.8648	1.0374
19	1.3443	.8402	1.2003	1.4937	1.6804	1.531	1.6244
20	1.2323	1.1317	1.6118	1.7551	1.5775	1.2323	1.6617
21	1.2323	1.2071	1.4575	1.587	1.5775	1.4003	1.587
22	1.0829	1.0751	1.3717	1.419	1.5089	1.4563	1.5278
23	1.0456	1.0374	1.0974	1.3443	1.406	1.3443	1.4937
24	1.0288	.9156	1.0562	.9259	.8215	.9259	.8215
Max	1.3443	1.4563	2.0748	2.0748	3.062	3.4705	3.0247
Min	.5041	.4915	.6161	.4917	.6516	.6722	.6602
Avg	.9715	1.0252	1.3005	1.2211	1.4620	1.5053	1.3973

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 203 / 11 KV PALASHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0631	1.1949	1.1949	.5144	.6348	.6173	.5087
2	1.0288	1.2323	1.2323	.5144	.6722	.6516	.6348
3	1.166	1.2696	1.3014	.5144	.6687	.823	.0162
4	1.3375	1.3817	1.3817	.583	.8775	.9945	.0143
5	1.6804	1.643	1.6409	.7545	1.0456	1.2003	.0143
6	1.6118	1.8484	1.7924	.9945	1.6244	1.3032	.0143
7	1.6804	1.8484	1.7737	1.2346	1.7177	1.6289	.0143
8	1.5089	1.6804	1.6244	.9945	1.6991	2.0165	.0164
9	1.5089	1.2136	1.251	1.2346	1.6804	1.7177	.9709
10	.6535	.6882	.7373	.9709	.8962	.9389	.9619
11	.7095	1.0322	.583		.583	.9896	
12	.6535	.9339	1.0974	.5426	.6173	.7842	
13	.7095	1.0486	1.1317	.7095	.6173	.8589	.4715
14	.7655	.8848	1.0974	.7468	.6516	.7712	.7922
15	.8962	.8453	.9945	.6908	.703	.9335	.8215
16	.8962	.8619	1.0631	.8402	.9259	.9896	.8402
17	.8589	.8848	1.0974	.9149	.8916	1.1203	.823
18	1.1763	.8676	.9945	1.0513	1.2346	1.1203	1.0829
19	1.7364	1.4377	1.3717	1.6244	1.5775	1.6804	1.5123
20	1.4563	1.358	1.5089	1.7177	1.6804	1.5684	1.6244
21	1.3817	1.2449	1.2346	1.286	1.3717	1.3817	1.3443
22	1.1763	1.1883	1.2003	1.2696	1.2346	1.251	1.2323
23	1.1203	1.1506	1.166	1.2323	1.2003	1.2323	1.226
24	1.0631	1.1203	1.1883	.4801	.5601	.583	.503
Max	1.7364	1.8484	1.7924	1.7177	1.7177	2.0165	1.6244
Min	.6535	.6882	.583	.4801	.5601	.583	.0143
Avg	1.1600	1.2025	1.2358	.9311	1.0569	1.1315	.7018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 204 / 11Kv Bhagawati Agro  
Express Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.014	.0171	2.7221	.0171	
2	.0171	.0325	.014	.0171	.0142	.0171	.0143
3		.0374	.014	.0171	.0162		.0141
4	.0171	.0141	.014	.0171	.0374	.0171	.0143
5	.0171	.0141	.014	.0171	.0143	.0171	.0143
6	.0171	.0141	.014	.0171	.0287	.0171	.0143
7	.0171	.0143	.014		.0287	.0171	.0143
8	.0171	.0144	.014	.0171	.0287	.0374	.0141
9	.0171	.0143	.014	.0171	.0374	.0373	.0143
10	.0374	.0139	.014	.034	.0573	.0287	.0147
11	.0291	.014	.0171	.0299	.0171		.0148
12	.0144	.0139	.0171	.0374	.0171	.0287	.0148
13	.0301	.0139	.0171	.0284	.0171		.0148
14	.0341	.014	.0171	.0936	.0171	.0287	.0148
15	.0374	.014	.0171	.0374	.0171		.0147
16	.0299	.014	.0171	.0374	.0171	.0287	.0148
17	.0299	.0139	.0171	.0299	.0171	.0287	.0148
18	.0299	.0139	.0171	.0299	.0171	.0282	.0148
19	.0287	.014	.0171	.0287	.0171	.0374	.0147
20	.0143	.014	.0171	.0374	.0171	.0287	.0147
21	.0141	.014		.0287	.0171	.0143	.0147
22		.014	.0171	.0332	.0171	.0332	.0147
23	.0144	.014	.0171		.0171	.0374	.0147
24	.0171		.014	.0171	.0143	.0171	.0143
Max	.0374	.0374	.0171	.0936	2.7221	.0374	.0148
Min	.0141	.0139	.014	.0171	.0142	.0143	.0141
Avg	.0226	.0159	.0156	.0291	.1342	.0259	.0146



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044073 / 33 KV BHAVAN

Feeder No / Name : 205 / 11Kv Nillod Dharan

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0157				
2			.0157				
3			.0157				
4			.0157				
5			.0157				
6			.0157				
7			.0157				
8	.0343	.0282	.0157				
9	.0343	.0283	.0157				
10				.0716	.0149	.0143	
11				.0935	.1029	.0141	.047
12				.0606	.0857	.0436	.047
13				.0299	.0686	.0141	.0157
14				.0141	.0514	.0282	.0157
15				.015	.0686	.0143	.0157
16				.0573	.0343		.0157
17				.0288	.0343		.0157
24			.0157				
Max	.0343	.0283	.0157	.0935	.1029	.0436	.047
Min	.0343	.0282	.0157	.0141	.0149	.0141	.0157
Avg	.0343	.0283	.0157	.0464	.0576	.0214	.0246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 201 / 11 KV PALOD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.1619	.2347	.2515	.2429	.3772	.415
2	.415	.1619	.2347	.2486	.2429	.3772	.4527
3	.415	.1619	.2683	.2652	.2591	.3772	.4527
4	.4527	.1943	.3018	.2984	.2915	.415	.4904
5	.4904	.1943	.3353	.431	.3563	.6413	.5281
6	.6413	.1943	.3688	.4973	.4534	.7545	.6036
7	.7167	.1943	.4694	.5138	.5506	.7922	.7167
8	.5658	.1619	.4973	.547	.583	.679	.547
9	.6413	.3563	.4862	.6133	.6478	.5658	.4715
10	.3563	.2347		.3206	.3772	.5868	.2713
11	.3239	.2683		.2829	.3772	.7545	.2374
12	.3239	.218			.2641	.7712	.2713
13	.3563	.2347		.3018	.2641	.2515	.6036
14	.3887	.2347		.2829	.2641	.1844	.7042
15	.421	.2641	.3206	.3018	.2641	.2683	.8383
16	.3887	.2829	.3395	.3018	.2641	.3018	.8951
17		.3018	.3772	.3018	.3395	.3856	.9116
18	.415	.4904	.4527	.415	.4527	.4904	.3772
19	.4904	.6036	.6413	.679	.679	.6602	.6413
20	.5281	.5658	.6036	.679	.6413	.6036	.5658
21	.4904	.5281	.5847	.5658	.5658	.5281	.547
22	.4527	.4904	.4715	.4904	.5281	.4904	.5281
23	.3772	.4527	.415	.4527	.4527	.4527	.4715
24	.415	.1457	.2683	.2347	.2591	.415	.4527
Max	.7167	.6036	.6413	.679	.679	.7922	.9116
Min	.3239	.1457	.2347	.2347	.2429	.1844	.2374
Avg	.4557	.2957	.4037	.4033	.4009	.5052	.5414

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 202 / 11 KV ANWI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.1296	.1677	.1677	.2012	.3772	.415
2	.3772	.1296	.1677	.1677	.2012	.3395	.415
3	.3772	.1619	.2263	.1677	.2347	.3395	.4338
4	.4527	.1943	.2012	.2012	.3018	.3772	.4527
5	.679	.2267	.2347	.2486	.3353	.5658	.4904
6	.8676	.3018	.2683	.3688	.3688	.679	.5658
7	.7545	.3772	.2515	.3812	.57	.7167	.6413
8	.679	.3395	.3481	.4475	.57	.5658	.3772
9	.4904	.3018	.3315	.3812	.6371	.2829	.1886
10	.1619	.2347		.2641	.3395	.503	.3258
11	.1619	.2515		.2075	.1886	.7209	.4239
12	.2267	.2012			.2641	.7042	.4694
13	.2591	.218		.2641	.2641	.7209	.5636
14	.2591	.2347		.1886	.3018	.7377	.5801
15	.2267	.2641	.3018	.2641	.3018	.6706	.6299
16	.2267	.2452	.3018	.2641	.3018	.5868	.6299
17	.2591	.2452	.3206	.3018	.3018	.5365	.663
18	.415	.415	.415	.3772	.5281	.415	.3961
19	.4904	.5281		.5658	.679	.5281	.5658
20	.5281	.4527	.5281	.7545	.5658	.4904	.5281
21	.4527	.4527	.4715	.6036	.5658	.4527	.5093
22	.415	.4527	.4527	.4527	.5281	.415	.4715
23	.415	.415	.415	.4527	.4904	.415	.4527
24	.415	.1296	.2347	.1677	.2012	.415	.415
Max	.8676	.5281	.5281	.7545	.679	.7377	.663
Min	.1619	.1296	.1677	.1677	.1886	.2829	.1886
Avg	.4169	.2876	.3132	.3330	.3851	.5231	.4835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 203 / RAHIMABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2915	.5281	.4527	.6413	.6036	.9389	.4024
2	.3239	.5281	.4527	.6602	.6413	.9389	.4359
3	.3239	.5658	.4904	.6602	.6413	1.0059	.4694
4	.3563	.679	.5281	.679	.7545	1.073	.503
5	.4858	.9054	.679	1.0374	1.0185	1.1401	.5365
6	.4858	.679	.8886	1.1128		1.3413	.6036
7	.7449	.6413	.7733	1.094	.9431	1.7772	.7042
8	.6478	.3772	.7167	.9431	.7922	1.9784	.7042
9	.3239	.679	.4715	.6036	.6413	1.9784	.7293
10	.5658	.4904	.4359	.664	1.2407	.1886	.3018
11	.3018	.5281	.7459	1.0364	1.9448	.1132	.1698
12	.2641	.7167	.8215		2.1795	.1132	.1698
13	.2263	.7922	.7956	1.3603	1.9113	.1509	.1886
14	.2263	.7545	.8785	1.5546	1.9448	.1698	.1886
15	.2641	.6706	.8192	1.2955	1.9784		.2075
16	.3395	.6371	.8619	1.4899	1.9448		.2829
17	.4904	.6203	.8951	1.0688	2.0119		.415
18	.679	.6413	.6224	.4904	.5281	.8299	.5658
19	.7167	.7167	.7545	.9431	.5658	.7167	.9242
20	.7167	.6036	.7167	.7545		.6224	.8488
21	.6036	.4904	.679	.7167	.5281	.5281	.547
22	.5281	.4904	.6413	.6036	.5658	.4904	.5281
23	.5281	.4527	.6413	.6036	.5658	.4904	.5281
24	.2915	.5281	.4527	.6413	.6036	.9389	.4024
Max	.7449	.9054	.8951	1.5546	2.1795	1.9784	.9242
Min	.2263	.3772	.4359	.4904	.5281	.1132	.1698
Avg	.4469	.6132	.6756	.8980	1.1159	.8345	.4732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044080 / 33 KV ANWI

Feeder No / Name : 204 / ASADI AG MIX SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619	.2012	.1886	.2263	.2263	.3018	.1509
2	.1943	.2012	.1886	.2263	.2263	.3018	.1677
3	.2267	.2012	.2263	.2263	.2263	.3353	.2012
4	.2267	.2683	.2263	.2641	.2641	.3688	.2347
5	.2915	.4024	.3395	.3772	.3772	.4024	.2347
6	.3239	.4359	.5281	.4904	.5658	.6036	.2683
7	.3563	.4694	.4904	.4904	.4904	.7042	.3018
8	.3239	.3688	.4338	.415	.4527	.8048	.3521
9	.1943	.3018	.2263	.3395	.3395	.6036	.2652
10	.1886	.2263	.2012	.3077	.4534	.0943	.1132
11	.1886	.2641	.3315	.5344	.7449	.0943	
12	.1509	.415	.3481		.7449	.1132	
13	.1509	.4715		.583	.8383	.0943	.1132
14	.1478	.415		.6316	.8383	.1132	
15	.1886	.3688	.3605	.5506	.9054	.1132	.1132
16	.1886	.3856	.3647	.6478	.8383	.132	.1132
17	.2641	.4191	.3812	.4858	.8048	.1509	.1132
18	.3018	.2641	.2263	.2641	.2641	.3584	.2075
19	.3018	.3395	.3018	.415	.3018	.4715	.3961
20	.3018	.2263	.3018	.3772	.3772	.3772	.3772
21	.3018	.2641	.2641	.3395	.3395	.2829	.2829
22	.3018	.2263	.2452	.3018	.3018	.1886	.2829
23	.2641	.1886	.2263	.2641	.2641	.1886	.2641
24	.1619	.2347	.1886	.2263	.2641	.3018	.1509
Max	.3563	.4715	.5281	.6478	.9054	.8048	.3961
Min	.1478	.1886	.1886	.2263	.2263	.0943	.1132
Avg	.2376	.3150	.2995	.3906	.4771	.3125	.2240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 201 / 11 kv Dhawda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1698	.1886	.124	.1254	.0914	.1017
2	.1509	.1509	.1886	.124	.1086	.1267	.1029
3	.1905	.1886	.2263	.1417	.1267	.1448	.1227
4	.2075	.2263	.2641	.1578	.124	.1612	.1372
5	.3772	.3961	.3395	.1907	.1402	.2172	.1543
6	.3961	.5093	.4715	.2401	.1543	.2328	.1677
7	.4338	.5093	.4715	.2601	.2804	.4024	.2155
8	.3584	.3772	.3395	.2229	.3601	.5197	.3401
9	.2858		.1886	.3222	.4024	.547	.3437
10	.0848		.1898	.132	.1886	.132	.1132
11	.0995		.216	.1132	.132	.0943	.1132
12	.0983		.2315	.0943	.1132	.0943	.0943
13	.1174		.2315	.0943	.0953	.1132	.0943
14		.2347	.2591	.1132	.0762	.132	.0943
15		.2561	.2469	.132	.0943	.1132	.0943
16	.1357	.2591	.2315	.1132	.1143	.1132	.1132
17	.1677	.2561	.2656	.1132	.132	.1509	.1509
18	.3206	.2263	.1698	.1698	.2096	.2829	.1886
19	.3961	.3961	.2452	.2641	.3584	.3584	.2263
20	.3395	.3584	.415	.3395	.2641	.3018	.2641
21	.2829	.2829	.3206	.2641	.1886	.2641	.2452
22	.2263	.2641	.2096	.2641	.1715	.2075	.2263
23	.1886	.2452	.1715	.2263	.1509	.1886	.1886
24	.1715	.1698	.2075	.0895	.124	.0732	.1006
Max	.4338	.5093	.4715	.3395	.4024	.547	.3437
Min	.0848	.1509	.1698	.0895	.0762	.0732	.0943
Avg	.2355	.2882	.2621	.1794	.1765	.2110	.1664

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 202 / 11 kv Jambhai SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.7545	.7167	.3547		.3361	.3734
2	.8002	.811	.6602	.3921		.3696	.4108
3	.9242	.9431	.6979	.4066		.4108	.4294
4	1.0185	1.0562	.9054	.4481		.4435	.4715
5	1.2826	1.1694	1.0374	.5041		.4854	.5041
6		1.226	1.1317	.4805		.6161	.6099
7		1.2071	.7733	.5487		.6878	.6584
8		.9808	.6224	.5249		.6984	.6268
9	1.1694		.4527	.4835	.5487	.6201	.6154
10	.3361		.2195	.3961	.6036	.3772	.3772
11	.3658		.2947	.2641	.5093	.2829	.3772
12	.3155		.3077	.2614	.415	.2829	.3584
13	.2835		.3812	.2829		.3018	.3584
14	.2686	.3761	.4862	.3206	.3584	.3018	.3584
15	.2686	.3681	.4359	.3584	.4382	.3395	.3961
16	.3077	.3641	.4191	.415	.5281	.4715	.4527
17	.3696	.3814	.3772	.5281	.5847	.6036	.5658
18	.9431	.6979	.6668	.6979	.6979	1.0751	.9808
19	1.3014	1.0751	.8488	1.0374	1.2637	1.226	1.094
20	1.0185	1.1128	.8676	1.0751	1.1883	1.0562	.9054
21	.9431	.9619	.9526	1.0374	1.0751	.9242	.8488
22	.8676	.9054	.7922		.9431	.8299	.8299
23	.7922	.8299	.6979		.811	.7545	.811
24	.7733	.7545	.7922	.3174		.2987	.3547
Max	1.3014	1.226	1.1317	1.0751	1.2637	1.226	1.094
Min	.2686	.3641	.2195	.2614	.3584	.2829	.3547
Avg	.7201	.8408	.6474	.5061	.7118	.5747	.5737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 203 / 11 kv Amthana SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5658	.5281	.2241	.2241	.2241	.2801
2	.6036	.6224	.5093	.3142	.2427	.2427	.2987
3	.6602	.679	.5658	.3361	.2801	.3142	.3361
4	.7733	.8488	.679	.3696	.3734	.3142	.3921
5	.9242	1.094	.9242	.3921	.4294	.4066	.4668
6	1.3392	1.3769	1.3392	.5175	.5415	.5359	.5601
7	1.3392	1.3203	1.358	.6161	.5788	.6283	.5729
8	1.1883	1.0751	1.1506	.5853	.6516	.7421	.5544
9	.9619		.7922	.4887	.543	.5552	.5068
10	.2534		.2572	.4715	.547	.547	.4715
11	.2835		.3018	.415	.3961	.4338	.415
12	.2658		.3563	.3395	.2829	.415	.3395
13	.2254		.3605	.3584	.3206	.3772	.3206
14	.2035	.3189	.3441	.3584	.3429	.3584	.2829
15	.2035	.3544	.3149	.3772	.3772	.3772	
16	.2279	.3155	.3018	.3772	.415	.415	.2829
17	.2507	.3012	.3086	.415	.4572	.4715	.5281
18	.8488	.5281	.6036	.5847	.5658	.6413	.6602
19	.9619	.9808	.8865	.9997	1.0562	.9619	.811
20	.9054	.9054	1.0562	1.0185	1.0751	.8676	.8488
21	.811	.8299	.8488	.811	.8865	.7733	.7356
22	.6979	.6224	.743	.6602	.7356	.6224	.6036
23	.6413	.547	.6224	.547	.5716	.4904	.5658
24	.5906	.5658	.5281	.2614	.1829	.2614	.2218
Max	1.3392	1.3769	1.358	1.0185	1.0751	.9619	.8488
Min	.2035	.3012	.2572	.2241	.1829	.2241	.2218
Avg	.6555	.7290	.6533	.4933	.5032	.4990	.4807



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 204 / 11 kv JOGESHWARI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.547	.6036	.3142	.3801	.3142	.3696
2	.547	.5658	.6036	.3511	.3921	.3658	.4066
3	.6478	.6224	.6224	.3841	.4481	.3841	.4294
4	.7733	.811	.7167	.4207	.5228	.3982	.4668
5	1.0374	.9997	.9242	.5487	.5601	.4887	.499
6	1.2071	1.3392	1.2826	.6984	.7023	.6154	.6401
7	1.1883	1.226	1.1949	.6805	.7783	.7888	.7783
8	1.0374	1.0562	.9997	.0627	.8059	.7291	.6805
9	.9619		.6979	.6201	.6371	.6539	.6661
10	.3045		.4359	.7922	.6036	.7545	.7167
11	.3814		.4144	.6908	.547	.6413	.679
12	.3429		.3887	.6224	.5093	.6602	.6413
13	.3467		.4096	.547	.4904	.6602	.6036
14	.3222	.4557	.3978	.4904	.5144	.679	.4904
15	.2486	.4144	.3856	.4527	.5847	.6413	.5281
16	.3429	.4191	.3944	.5281	.6602	.6224	.5847
17	.3944	.4733	.3467	.6224	.7733	.7167	.6413
18	.9997	.6979	.8299	.8488	.8865	.9242	.9054
19	1.0751	1.0562	.9997	1.0562	1.0374	1.1694	.9997
20	.9242	.8676	1.0562	.9619	1.0751	1.0374	.9054
21	.7545	.7545	.9808	.8488	.9054	.9242	.8299
22	.679	.7167	.8488	.7545	.7733	.811	.7733
23	.6036	.6602	.6602	.6602	.6224	.6413	.6602
24	.5716	.5658	.6224	.2801	.333	.2772	.3475
Max	1.2071	1.3392	1.2826	1.0562	1.0751	1.1694	.9997
Min	.2486	.4144	.3467	.0627	.333	.2772	.3475
Avg	.6758	.7499	.7007	.5932	.6476	.6624	.6351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044081 / 33 KV AMTHANA

Feeder No / Name : 205 / Kelgaon murdeshwar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5847	.5281	.2801	.2829	.2801	.3142
2	.547	.5658	.547	.3142	.2641	.3142	.3326
3	.6036	.6224	.5847	.3326	.2987	.3326	.3734
4	.8299	.8676	.6602	.3734	.3361	.3658	.3921
5	.9619	1.0185	.8676	.3921	.4108	.3881	.4108
6	1.3014	1.2449	1.3014	.5249	.5415	.5304	.4854
7	1.358	1.4146	1.2826	.5175	.499	.6089	.6036
8	1.1694	1.0562	.9808	.5304	.6805	.691	.724
9	.8383		.6413	.4163	.5959	.6135	.6024
10	.2378		.2774	.3961	.4338	.4527	.3961
11	.2658		.3185	.3206	.3772	.3018	.3584
12	.3045		.3441	.3395	.3395	.3206	.3018
13	.2865		.3647	.3395	.3239	.3395	.2641
14	.2481	.2774	.3812	.3584	.3395	.3772	.3018
15	.2149	.3601	.3521	.3961	.3584	.3584	
16	.3224	.3045	.3258	.3961	.381	.3772	.3206
17	.3582	.362	.1715	.415	.415	.4338	.3584
18	.9054	.6036	.5144	.5847	.6036	.9054	.8865
19	.9997	.8865	.7922	1.0562	1.094	.9808	.9242
20	.8865	.8676	.8676	.9431	1.1128	.8299	.9242
21	.7922	.7733	.7545	.7733	.9242	.7545	.7733
22	.7167	.6979	.6979	.679	.724	.6602	.6602
23	.6413	.6224	.5847	.6224	.5847	.679	.6036
24	.6036	.5847	.5281	.2427	.2402	.2241	.2715
Max	1.358	1.4146	1.3014	1.0562	1.1128	.9808	.9242
Min	.2149	.2774	.1715	.2427	.2402	.2241	.2641
Avg	.6650	.7218	.6112	.4810	.5067	.5050	.5036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 201 / 11 KV LONAWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3921	.4338	.3395	.4108	.4481	.8775
2	.3921	.4481	.462	.5975	.5228	.5228	.8775
3	.5228	.5228	.5121	.6413	.5601	.5975	.9522
4	.6535	.6535	.6653	.6602	.7468	.8962	1.0829
5	.7655	.7468	.8488	.6602	.7655	1.3817	1.2696
6	.9149	1.4712	1.0425	1.1506	1.2136	1.7551	1.4377
7	.9896	1.4937	1.2883	1.5684	1.7187	2.0538	1.643
8	1.1949	1.7551	1.4712	1.6787	1.7737	2.2032	1.3256
9	1.1949	1.643	1.3256	1.7353	1.8298	2.2405	1.0456
10	.8029	.7468	.5415	.6535	.7468	.6535	.5415
11	.7468	.4294	.5121	.5041	.4668	.4854	.6908
12	.5975	.4527	.5041	.4805	.4668	.6413	.9054
13	.5601	.4294	.4572	.4854	.5601	.6908	.9709
14	.5975	.4294	.5041	.5228	.6348	.6722	1.094
15	.6722	.5359	.5853	.5729	.7095	.6602	1.0642
16	.7282	.5544	.6468	.6838	.7282	.6348	1.0562
17	.7655	.6219	.7023	.8402	.8402	.6602	1.0751
18		.7095	1.1883	1.0269	1.0082	1.0642	1.1458
19	.8402	1.2071	1.8484	1.2883	.9335	1.4712	1.1523
20	1.0082	1.4003	1.6078	1.2012	1.1949	1.5089	1.2323
21	1.1949	1.1643	1.5123		1.307	1.2637	1.2567
22	1.307	.961	1.1576	1.0456	1.2136	1.0374	.9694
23	1.2696	.7922	.9242	.9335	1.1203	.9522	.9425
24	1.0082	1.1203	.4338	.3584	.4481	.9335	.8775
Max	1.307	1.7551	1.8484	1.7353	1.8298	2.2405	1.643
Min	.3734	.3921	.4338	.3395	.4108	.4481	.5415
Avg	.8305	.8617	.8823	.8534	.9134	1.0595	1.0619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 202 / 11 KV ANDHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3361	.4251	.4668	.3734	.4108	.7655
2	.3361	.3734	.4527	.5041	.4435	.3734	.7468
3	.3734	.4481	.4715	.7167	.4805	.4481	.7842
4	.4668	.6535	.547	.8402	.5544	.4854	.8402
5	.6535	.7468	.6283	.9619	.7392	.5601	.9522
6	.8402	.8215	.7468	1.0082	.924	.5975	1.1763
7	.9335	.8962	.9335	.9242	1.0719	.7922	1.307
8	.8962	.9896	.9149	.9054	1.0608	.8402	1.1016
9	1.0642	1.1949	.7842	.9619	1.1088	.8402	.8589
10	1.0642	.8402	.9054	1.1203	.8402	.7602	.3734
11	.7468	.7095	.7655	.7842	.6535	.6161	.4338
12	.6535	.5544	.6722	.7468	.4668	.5228	.4481
13	.5415	.499	.5281	.6722	.4854	.4294	.415
14	.5601	.499	.5975	.8402	.4668	.4668	.3921
15	.6161	.5601	.679		.4668	.5041	.3772
16	.6535	.6283	.7282		.5041	.5415	.2829
17	.7282	.6219	.7468		.5228	.6161	.2829
18	1.3443	.7133	1.0425	1.0456	.679	.8775	.3696
19	1.6617	1.3717	1.1389	1.2323	1.0456	1.0456	.8596
20	1.5684	1.8484	1.0269	.9335	.8402	1.1203	.7499
21	1.3443	1.5729	.9619	1.0349	.7095	1.0269	.6767
22	1.0185	1.386	.8865	.8962	.6535	.8775	.6584
23	.7468	1.1458	.7762	.8215	.5975	.8402	.6468
24	.6535	.6535	.4338	.4108	.3921	.5228	.7655
Max	1.6617	1.8484	1.1389	1.2323	1.1088	1.1203	1.307
Min	.3174	.3361	.4251	.4108	.3734	.3734	.2829
Avg	.8243	.8360	.7414	.8489	.6700	.6715	.6777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044083 / 33 KV ANDHARI

Feeder No / Name : 203 / 11 KAV ANDHARI - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2241	.2241	.2054	.0924	.2614	.8775
2	.1867	.2614	.2241	.2241	.1294	.3361	.8589
3	.2054	.3361	.2427	.2452	.1109	.3361	.9522
4	.2241	.3734	.3018	.3361	.0924	.3734	1.1016
5	.2614	.4294	.3772	.3772		.4481	1.307
6	.2987	.4481	.4668	.5093		.7282	1.6244
7	.3361	.3772	.5658	.6036		1.0082	1.7924
8	.3174	.5041	.5281	.6602	.5121	1.0082	1.531
9	.4668	.4854	.4527	.6413	.462	.9522	1.2883
10	.4668	.3734	.3772	.4294	.4481	.8962	.4481
11	.3361	.2378	.3547	.2614	.3174	.6161	.415
12	.2054	.2427	.2218	.2054	.4854	.5041	.3921
13	.168	.2561	.1494	.1867	.5228	.4481	.4338
14	.168	.2561	.1663		.5601	.5093	.4108
15	.1867	.1646	.2195	.2241	.5975	.5601	.4338
16	.2054	.2195	.2378	.2427	.6535	.6722	.4481
17	.2427	.2587	.2743	.3361	.7468	.8215	.4527
18	.7282	.3475	.462	.5041	.9522	1.1389	.4572
19	.7842	.695	.6908	.8215	1.3443	1.3443	1.1203
20	.5788	.8048	.6348	.6161	1.1203	1.363	.9425
21	.4481	.6468	.4805		1.0082	1.2136	.6838
22	.3361	.5544	.3921		.8962	.8402	.6401
23	.2987	.4668	.2987	.3174	.7468	.8402	.6099
24	.2801	.2614	.2241	.2241	.0934	.7095	.8215
Max	.7842	.8048	.6908	.8215	1.3443	1.363	1.7924
Min	.168	.1646	.1494	.1867	.0924	.2614	.3921
Avg	.3299	.3844	.3570	.3891	.5663	.7471	.8351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISION SILLOD

Feeder No / Name : 201 / 11 KV INDUSTRIAL EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
FEED Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0943	.1132	.0914	.1132	.1307	.0943
2	.0754	.0943	.1132	.0914	.1132	.1307	.0943
3	.0754	.0943	.1132	.0943	.1132	.1307	.0934
4	.0747	.0943	.112	.0943	.132	.1307	.112
5	.0934	.0914	.1307	.0876	.1509	.1294	.112
6	.1109	.0943	.1294	.0943	.1509	.1494	.1294
7	.1109	.0943	.1478	.0934	.1698	.1494	.1307
8	.112	.0934	.1478	.0914	.1509	.1478	.1294
9	.112	.0905	.1478	.0934	.1509	.1478	.1294
10	.112	.0943	.1478	.0934	.1494	.1494	.0747
11	.0943	.1478	.0934	.112	.1494	.1478	.0943
12	.0934	.1478	.0934	.1494	.1494	.1463	.0934
13	.0934	.1494	.0934	.168	.1307	.1478	.0934
14	.0905	.1494	.1867	.1494	.1494	.1478	.0934
15	.0905	.1478	.1867	.1307	.1494	.1478	.0943
16	.0934	.1478	.1867	.1494	.1494	.1494	.0905
17	.0934	.1478		.1494	.1494	.1478	.1463
18	.0934	.1509	.0943	.1494	.112	.1478	.0943
19	.0934	.1307	.0934	.1494	.1294	.1307	.0905
20	.0747	.1132	.0943	.1509	.1307	.1307	.0943
21	.0934	.0943	.0934	.1494	.1307	.0914	.0943
22	.0943	.1132	.0943	.1494	.1307	.0914	.0943
23	.0934	.1132	.0914	.1509	.1307	.0943	.0934
24	.0754	.0943	.1132	.0914	.1307	.112	.0943
Max	.112	.1509	.1867	.168	.1698	.1494	.1463
Min	.0747	.0905	.0914	.0876	.112	.0914	.0747
Avg	.0925	.1160	.1225	.1218	.1382	.1345	.1025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 202 / TILAKNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.543	.5658	.543	.5975	.6161	.5658
2	.6036	.5601	.5658	.5601	.5601	.5975	.5658
3	.6602	.5601	.5975	.5601	.5601	.6161	.5975
4	.7167	.5601	.6535	.5601	.8402	.6468	.6283
5	.7468	.7468	.7023	.6535	.924	.7023	.6653
6	.8402	.8145	.8215	.7468	1.0164	.7392	.8402
7	.9425	.9335	.8871	.9335	1.0608	.924	.9522
8	.8962	.8145	.8131	.9335	.9511	.9145	.7762
9	.7655	.7468	.695	.724	.8048	.8029	.7577
10	.6722	.724	.695	.7468	.5914	.6908	.7842
11	.6335	.6653	.6535	.6838	.6535	.7207	.7011
12	.6535	.5914	.5601	.6535	.6161	.6401	.7316
13	.5601	.5544	.543	.6161	.5914	.6219	.6401
14	.5601	.5359	.5601	.6161	.6099	.6036	.543
15	.543	.499	.543	.5914	.6653	.6283	.543
16	.5601	.5914	.6535	.6535	.7023	.6653	.6335
17	.5601	.5788		.7023	.7023	.6653	.7468
18	.7468	.6722	.7468	.7762	.6283	.6838	.6535
19	.8402	.7655	.7468	.8131	.8131	.8131	.7468
20	.7655	.6908	.7468	.8029	.8048	.7655	.7842
21	.6602	.6335	.7468	.7655	.7762	.7468	.7468
22	.6535	.679	.7468	.7023	.7316	.7011	.6535
23	.5601	.6036	.5601	.6535	.6401	.6602	.6335
24	.6036	.543	.5658	.5258	.6161	.6535	.6036
Max	.9425	.9335	.8871	.9335	1.0608	.924	.9522
Min	.543	.499	.543	.5258	.5601	.5975	.543
Avg	.6812	.6503	.6682	.6882	.7274	.7008	.6873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 203 / NEW TOWN 2

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4525	.4904	.5258	.4805	.5729	.5281
2	.4527	.4668	.4904	.5601	.4668	.5544	.5281
3	.4904	.4668	.4904	.543	.4668	.5544	.547
4	.5228	.4668	.5601	.543	.6468	.6468	.5658
5	.5975	.5258	.6535	.6535	.8316	.6722	.5601
6	.7468	.6535	.7468	.724	1.0164	.6838	.7468
7	.8131	.7468	.8131	.9335	1.0974	.8413	.8589
8	.8215	.724	.8316	.9335	.8145	.9145	.7762
9	.7655	.7011	.7762	.905	.7392	.8962	.7577
10	.7655	.724	.6838	.8764	.5914	.7468	.8131
11	.6535	.7392	.6135	.8402	.5544	.7655	.8145
12	.6135	.6283	.5258	.7468	.5729	.6401	.7545
13	.5258	.5175	.5601	.6535	.5544	.5853	.6335
14	.4668	.4805	.5601	.5228	.6099	.6401	.5601
15	.5601	.3881	.5601	.5914	.6535	.6283	.5258
16	.5601	.5175	.5601	.6535	.6722	.6653	.6535
17	.543	.5544		.7392	.7316	.7095	.7468
18	.7468	.6535	.7468	.7762	.7947	.7762	.724
19	.8402	.7922	.8402	.8131	.8316	.8131	.8402
20	.6722	.7095	.724	.7468	.7499	.7842	.8402
21	.6335	.5601	.6335	.6908	.7207	.7011	.7468
22	.5601	.5658	.5487	.6348	.7023	.6535	.5601
23	.4525	.5281	.5601	.5601	.6535	.6413	.5601
24	.4527	.4525	.4904	.4668	.5041	.5975	.5658
Max	.8402	.7922	.8402	.9335	1.0974	.9145	.8589
Min	.4525	.3881	.4904	.4668	.4668	.5544	.5258
Avg	.6129	.5840	.6287	.6931	.6857	.6952	.6753



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 204 / TOWN 1

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5068	.4904	.5658	.4854	.5601	.5281
2	.4904	.4525	.4904	.543	.4668	.5601	.5281
3	.5658	.4668	.5281	.5601	.4668	.5601	.547
4	.5658	.4668	.5658	.5601	.462	.5788	.5658
5	.6535	.5258	.5975	.5601	.5487	.5914	.5544
6	.7207	.6335	.6653	.6535	.823	.6468	.7095
7	.7762	.724	.7392	.7468	.9145	.7682	.7947
8	.7842	.724	.7207	.8402	.823	.724	.7762
9	.6722	.724	.7316	.724	.7682	.8316	.6838
10	.7095	.7011	.7392	.7468	.6838	.7468	.7095
11	.6602	.6722	.6535	.7762	.6653	.7392	.724
12	.5601	.6468	.6535	.7023	.6468	.7316	.724
13	.6335	.5601	.6535	.6535	.5853	.7133	.7468
14	.6335	.5544	.5601	.6348	.6584	.7023	.724
15	.6335	.5415	.6335	.6468	.6468	.6653	.7468
16	.6535	.6283	.7095	.6653	.695	.7164	.6535
17	.6335	.6838		.7023	.7392	.7392	.7468
18	.7468	.7468	.8402	.7762	.7392	.7577	.7468
19	.8402	.811	.8402	.8215	.8048	.8215	.8145
20	.6908	.7095	.8402	.7468	.724	.7468	.7842
21	.5258	.5601	.7011	.6722	.7023	.724	.724
22	.5258	.5658	.5601	.6348	.6099	.543	.543
23	.4668	.5093	.4382	.5601	.5914	.5281	.5601
24	.4904	.4668	.4904	.4668	.5041	.5601	.5281
Max	.8402	.811	.8402	.8402	.9145	.8316	.8145
Min	.4668	.4525	.4382	.4668	.462	.5281	.5281
Avg	.6301	.6076	.6453	.665	.6564	.6774	.6735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044096 / 33 KV SUB DIVISON SILLOD

Feeder No / Name : 206 / 11 KV BALAJINAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3734	.4715	.5601	.4668	.5975	.5093
2	.415	.362	.4715	.5601	.4668	.5975	.5093
3	.4481	.3734	.5281	.5601	.5601	.5788	.5281
4	.5281	.3734	.5415	.5601	.5601	.5914	.5281
5	.5544	.4382	.5975	.5601	.6535	.5853	.5228
6	.6468	.5601	.6535	.6535	.7392	.6036	.7282
7	.7023	.724	.7023	.724	.823	.7316	.7947
8	.7655	.6535	.7392	.8402	.7682	.724	.7392
9	.6722	.6135	.5853	.724	.7762	.6535	.6099
10	.5975	.5601	.5729	.6335	.499	.5975	.5914
11	.4525	.5175	.4668	.5121	.462	.5544	.4668
12	.4525	.3921	.3734	.462	.4207	.4755	.3734
13	.6535	.3696	.362	.4251	.4108	.4435	.362
14	.362	.3511	.3734	.3734	.4294	.4066	.362
15	.362	.3696	.3734	.4066	.4481	.4435	.3734
16	.362	.3696	.3506	.4481	.4481	.5175	.3734
17	.362	.3696		.4481	.5175	.499	.362
18	.4668	.4668	.5601	.8131	.5175	.5359	.4668
19	.6535	.5658	.5601	.499	.6154	.6348	.6535
20	.5788	.5601	.5601	.6535	.6516	.6348	.6722
21	.4715	.5258	.543	.5975	.6219	.543	.5601
22	.4525	.5281	.4668	.5415	.5914	.5258	.5601
23	.4668	.4904	.4668	.5041	.5601	.5281	.4668
24	.415	.362	.4715	.4668	.4668	.5601	.5093
Max	.7655	.724	.7392	.8402	.823	.7316	.7947
Min	.362	.3511	.3506	.3734	.4108	.4066	.362
Avg	.5107	.4696	.5127	.5636	.5614	.5651	.5260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 202 / YESHWANTNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0549	.0682	.0572	.0682	.0572	.0543
2		.0549	.0818	.0572	.0657	.0572	.0543
3	.128	.0747	.1483	.0572	.068	.1109	.0905
4	.1646	.0914	.1705	.1143	.1247	.1663	.1448
5	.2012	.1646	.2217	.1663	.2217	.1848	.1629
6	.2195	.2195	.2558	.1848	.2387	.2195	.1991
7	.2561	.2743	.2472	.2172	.2217	.2715	.2172
8	.2378	.2378	.1813	.2279	.2046	.2149	.181
9	.2195	.2012	.1646	.1753	.1448	.181	.1629
10	.1848	.1705	.1086	.1535	.1109	.1629	.1097
11	.128	.1364	.0724	.1194	.0732	.1086	.1097
12	.0732	.1023	.0526	.0853	.1086	.0905	.112
13	.0366	.0682	.0543	.0853	.0914	.0905	.1109
14	.0549	.0682	.0724	.0659	.1086	.0724	.1097
15	.0549	.0682	.0543	.0682	.1267	.0543	.1097
16	.0549	.0682	.0732	.0855	.1086	.0724	.1097
17	.0914	.1023	.1109	.0853	.1629	.1267	.0914
18	.128	.1194	.168	.1023	.1848	.1448	.0739
19	.1646	.1309	.2241	.1194	.2241	.1448	.2195
20	.1463	.1194	.1848	.1194	.1848	.1267	.1829
21	.1097	.0853	.1109	.0853	.1109	.1086	.1097
22	.0914	.0682	.0747	.0682	.0754	.0905	.0732
23	.0732	.0684	.0572	.0684	.0572	.0724	.0549
24	.0732	.0682		.0682		.0543	
Max	.2561	.2743	.2558	.2279	.2387	.2715	.2195
Min	.0366	.0549	.0526	.0572	.0572	.0543	.0543
Avg	.1289	.1174	.1286	.1099	.1342	.1243	.1236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 204 / MAHADEV MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.5601	.5627	.5525	.5968	.6097	.724
2	.6584	.5487	.5968	.5906	.5555	.6478	.724
3	.7316	.6161	.7162	.6478	1.0401	.6838	.7602
4	.8596	.7468	.8355	.7023	1.2277	.7421	.7964
5	.9328	.9896	.9549	.7783	1.3641	.9134	.9955
6	.9694	.9145	1.0572	1.0208	1.4494	1.0136	1.1584
7	1.134	1.2071	1.1595	1.0974	1.4371	1.0288	1.3756
8	1.2254	1.2254	1.0401	1.3375	1.4323	1.2795	1.4118
9	1.2567	1.1706	1.2715	1.4232	1.0117	1.267	1.3032
10	1.1273	1.0231	1.0288	1.0231	.924	1.2489	1.0974
11	.7316	.9549	.964	.9208	.8059	1.1946	1.0974
12	.7865	.648	.8328	.824	.9593	1.1222	.9511
13	.5975	.5798	.6379	.7332	.8573	.9593	.9145
14	.567	.5627	.5731	.6991	.8939	.9412	.9145
15	.5975	.5109	.6135	.7746	.929	.8869	.9145
16	.5853	.6821		.9549	1.0745	.8688	
17	.6401	.6309	.823	1.006	1.0867	.9774	1.0791
18	1.0242	.7844	1.0164	.5798	1.2127	1.2308	1.1523
19	1.0608	.9719	1.0974	.5798	1.3169	1.267	1.3169
20	.9145	.7503	1.0059	.5968	1.1827	1.2308	1.1706
21	.7282	.6309	.924	.8014	1.0242	1.0498	1.0242
22	.6584	.5968	.7392	.7162	.924	.9774	.9145
23	.6161	.5627	.6859	.6592	.8573	.7964	.823
24	.5487	.5627		.648		.724	
Max	1.2567	1.2254	1.2715	1.4232	1.4494	1.2795	1.4118
Min	.5487	.5109	.5627	.5525	.5555	.6097	.724
Avg	.8156	.7680	.8698	.8195	1.0506	.9859	1.0281

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404]

BU 7234

Substation No/ Name :- 044098 / 33 KV KHODKAI

Feeder No / Name : 205 / AURANGABAD NAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.567	.4938	.5109	.5335	.4835	.5335	.5792
2	.6036	.4938	.5798	.5525	.3835	.6097	.5792
3	.6584	.5487	.6098	.6097	.665	.5914	.5973
4	.695	.5853	.665	.6219	.8014	.6767	.724
5	.7316	.7316	.7844	.6878	.8837	.7207	.7421
6	.7316	.7133	.8185	.8413	.9719	.8326	.905
7	.823	.8596	.8526	.9492	.9549	.9671	.9955
8	1.134	.9145	.8526	.9991	.9378	1.0029	.9774
9	1.134	.9877	.8869	1.0056	.7537	.8954	.9231
10	.9145	.8526	.9774	.8837	.7392	.8688	.9328
11	.6401	.7332	.7964	.8526	.7602	.8326	.9328
12	.6767	.6309	.6859	.8014	.724	.7602	.7499
13	.5853	.5627	.543	.6139	.7011	.724	.7316
14	.5601	.5627	.4908	.366	.7522	.6878	.7316
15	.6161	.5627	.583	.5988	.7701	.6335	.7316
16	.6219	.4945	.631	.3983	.8145	.5973	
17	.6401	.4604	.8145	.6309	.8682	.724	.8596
18	.7316	.7162	.924	.7162	.8954	.8688	.9145
19	.8596	.8365	.9877	.7503	1.0534	.905	1.0425
20	.7316	.6821	.8686	.7503	.924	.8688	.9145
21	.6401	.6309	.7468	.6821	.8501	.8145	.8413
22	.5601	.5968	.6668	.6309	.7468	.7602	.7087
23	.4938	.5456	.6287	.5988	.6859	.724	.6584
24	.5041	.3401		.5475		.6335	
Max	1.134	.9877	.9877	1.0056	1.0534	1.0029	1.0425
Min	.4938	.3401	.4908	.366	.3835	.5335	.5792
Avg	.7022	.6473	.7350	.6926	.7878	.7597	.8078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 047025 / 132 KV SILLOD

Feeder No / Name : 204 / 11 KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-SEP-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

SILLOD(R) S/DN[404] BU 7234

Substation No/ Name :- 047025 / 132 KV SILLOD

Feeder No / Name : 207 / 11kV INDUSTRIAL FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-SEP-17
HR	Load (MW)
24	3.0521
Max	3.0521
Min	3.0521
Avg	3.0521

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 201 / BHAGOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086		.3429		.1715	.3429	.1715
2	.3086		.3429		.2058	.3429	.1715
3	.3772		.3429		.3086	.3429	.2058
4	.3772		.4458		.3772	.4115	.2401
5	.4801		.5487		.4801	.4115	.2401
6	.4801		.6516		.5487	.5144	.2743
7	.4458		.6173		.6173	.5144	
8	.3772		.5487		.7202	.5144	
9	.3429		.4458		.6516	.5144	.3429
10		.4115		.4801	.4801		.1715
11		.4115		.5487	.5487		.2401
12		.4115		.5487	.6516		
13		.3772		.6173	.6036		.3086
14		.3772		.5487	.5365		.3086
15		.3429		.4801	.5487		.3429
16		.3429		.4458	.4801		.3772
17		.4458		.4801	.5365		.3772
18		.1715		.1715	.3429		.4801
19		.4458		.4458	.6516		.6516
20		.4801		.5144	.5487		.6516
21		.3772		.4801	.3772		.4801
22		.3429		.4801	.3429		.3772
23		.3429		.3772	.3353		.3429
24	.3086		.3429		.1372	.3429	.1715
Max	.4801	.4801	.6516	.6173	.7202	.5144	.6516
Min	.3086	.1715	.3429	.1715	.1372	.3429	.1715
Avg	.3806	.3772	.4630	.4728	.4668	.4252	.3299



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 202 / JATEGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.9259	.5487	.7545	.5487	.583	.583
2	.583	.9945	.583	.9259	.6173	.6173	.6173
3	.6516	1.0288	.6516	.9602	.6516	.6173	.6173
4	.7888	1.1317	.7888	.9945	.7202	.6516	.7202
5	.7888	1.166	.8916	.9945	.7888	.823	.9259
6	.823	1.166	.9088	1.0974	.823	.823	.9602
7	.823	1.1317	.9431	1.0288	.8573	.7888	.9945
8	.8573	1.0974	.9602	1.0288	.8059	1.0974	1.0631
9	.823	.7202	.7716	.9602	.6859	1.1317	1.0974
10	.5144	.6173	.6859	.7202	.6783	.7202	.3086
11	.5144		.6173	.7716	.8383	.7888	.3429
12			.6516	.7545	.8573	.7202	.3086
13		.6173	.6516	.6859	.9259	.6516	.3086
14		.6001	.7545	.7888	.9259		.3601
15		.6516	.6859	.8573	.8573	.6173	.3601
16	.5144	.6859	.7888	.8916	.8573		.3944
17	.5487	.7373	.9259	.9259	.9389		.4801
18	.9259	.5487	.8573	.6344	.9945	.6516	.823
19	1.0974	1.3032	1.0974	1.1488	1.0059	.9259	1.1488
20	1.166	.7202	1.166	.7202	1.0288	.9602	1.2003
21	1.2003	.583	1.0288	.6001	.6173	1.0631	.8745
22	1.1317	.583	.823	.6001	.57	1.0974	.8916
23	1.0288	.5487	.7888	.5658	.6173	.9945	.8573
24	.5487	.8916	.5316	.7202	.5316	.583	.5487
Max	1.2003	1.3032	1.166	1.1488	1.0288	1.1317	1.2003
Min	.5144	.5487	.5316	.5658	.5316	.583	.3086
Avg	.7939	.8386	.7959	.8388	.7810	.8051	.6994

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 203 / MAHALGOAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5144	.3772	.7202	.4801	.5144	.9602
2	.7202	.4801	.3772	.7202	.5487	.5487	.9945
3	.7888	.4801	.4458	.9945	.6173	.583	1.0288
4	.7888	.5487	.4801	1.0974	.823	.6173	1.0974
5	.823	.583	.5144	1.0974	.9259	.7888	1.2003
6	.823	.6173	.5316	1.166	.9945	.9259	1.3375
7	.823	.7202	.8916	1.2346	1.0288	1.166	1.2689
8	.7888	.9259	.9945	1.0974	1.2517	1.2003	1.2346
9	.8059	.8573	.7373		1.2346	1.2003	1.2003
10	.8573	.4801	.4115	.5144		.823	
11	.5316	.5144	.4458	.5144		.5144	.7545
12		.4801	.4458	.5144			.823
13	.4801	.4458	.4115	.5144	.6173	.4801	.8573
14	.5144	.4458		.5144	.583		.9602
15	.5144	.4801		.5316	.4973	.6173	.9259
16	.5487	.4801	.4801	.583	.4458		.9945
17	.6173	.5487	.583	.6859	.6859		.9431
18	.9602	.8745	.8962	.9602	.823	1.0288	
19	1.166	1.2003	1.0974	1.2689	.9945	1.166	1.166
20	1.2689	1.0288	1.3032	1.0802	.9389	1.3032	1.0974
21	1.3375	.823	1.166	.7888	.8573	1.3375	.823
22	1.2346	.7888	.7888	.7545	.7712	1.2346	.7373
23	1.0974	.7888	.7545	.6344	.6859	1.0974	.6859
24	.6859	.5487	.3429	.7545	.463	.5144	.9259
Max	1.3375	1.2003	1.3032	1.2689	1.2517	1.3375	1.3375
Min	.4801	.4458	.3429	.5144	.4458	.4801	.6859
Avg	.8201	.6523	.6580	.8149	.7747	.8831	1.0008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 204 / KATE PIMPLGOAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401		.3429	.1715	.3429	.3429	.1715
2	.3086		.3429	.1715	.3772	.3429	.1715
3	.3772		.4458	.2058	.3772	.4115	.2058
4	.4458		.4801	.3429	.4115	.4458	.2401
5	.4458		.5487	.2743	.4458	.4801	.3086
6	.463		.5658	.1029	.4458	.5144	.3429
7	.4458		.5144	.0686	.4801	.5144	.3429
8	.4287		.4458	.0686	.3772	.4801	.4458
9	.3086		.2401	.0686	.3086	.4458	
10		.463		.3772			.1029
11		.463		.4458			.1029
12		.4801		.4115	.5144		.1029
13		.4801		.2743	.583		.1372
14		.5144		.4115	.5487		.12
15		.4801		.4801	.5487		.12
16		.463		.5144	.583		.12
17		.4973		.5658	.583		.1372
18		.2229		.1372	.3772		.2401
19		.4115		.3429	.3353		.4801
20		.3429		.3772	.3353		.3258
21		.3601		.3429	.3353		.3086
22		.3429		.3601	.3429		.3086
23		.3429	.3429	.3601	.3086		.3086
24	.2401		.3429	.1715	.3429	.3429	.1715
Max	.463	.5144	.5658	.5658	.583	.5144	.4801
Min	.2401	.2229	.2401	.0686	.3086	.3429	.1029
Avg	.3704	.4189	.4193	.2936	.4229	.4321	.2311

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 206 / PANVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.8916	.7545	.6173	.823	.7545	.6516
2	.6173	.9259	.7545	.6516	.8916	.7888	.6516
3	.6173	.9602	.9602	.7202	.8916	.7888	.6516
4	.6516	1.0288	.9945	.9945	.9945	.823	.6859
5	.6859	1.166	1.0631	1.0288	1.0974	.8573	.7202
6	.703	1.1317	1.0631	1.0288	1.1317	.8916	.7888
7	.703	1.0974	.8573	.9259	1.1317	.9259	.7888
8	.703	.9602	.6859		.8573	.6859	.7545
9	.6344	.7202	.3772		.7202	.6516	.7888
10	.3772	.6516	.6859		.3429	.4458	
11	.3601		.6516	.5487	.5316	.6173	.3086
12			.6516	.4801		.583	.3429
13	.3429	.6001	.6173	.4115	.6443	.5487	.3429
14	.4458	.4801		.4458	.6173		.2915
15	.4115	.4458		.4458	.5487	.583	.3429
16	.4115	.3772	.6173	.5144	.583		.3772
17	.4458	.5144	.6173	.5658	.5487		.3944
18	.583	.4801	.5144	.4287	.5935	.6516	.6173
19	.823	.8745	.823	.7373	.6859	.7202	.8059
20	1.0974	.8059	.9945	.8402	.8048	.7888	.8402
21	1.0288	.7716	1.0288	.823	.6859	.9602	.7716
22	.9945	.7202	.6516	.8059	.6859	.9945	.7373
23	.9602	.7202	.6516	.7545	.7377	.9602	.7373
24	.5487	.8573	.7202	.583	.7202	.7545	.6173
Max	1.0974	1.166	1.0631	1.0288	1.1317	.9945	.8402
Min	.3429	.3772	.3772	.4115	.3429	.4458	.2915
Avg	.6389	.7810	.7607	.6834	.7508	.7512	.6091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 207 / MALISAGAJ SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458		.4801	.6516	.4801	.5144	.823
2	.4801		.4801	.6859	.5487	.6173	.9259
3	.4801		.5144	.7888	.5487	.583	.8573
4	.5144		.5487	.9602	.6173	.6516	.823
5	.5144		.5487	1.0974	.6516	.823	.823
6	.5487		.5658	1.0631	.7888	.8573	.7888
7	.6516		.8573	1.0288	.8573	.9259	1.2346
8	.7202		.9259	.9945	.9602	.9945	.6173
9	.7202		.5316	.9945	.9602	1.0974	.7545
10		.4458		.3772	.6706		.5487
11		.463		.4287	.5144		.5487
12		.4115		.4115	.5144		
13		.3772		.3429	.5144		.5487
14		.3944		.3772	.5365		.583
15		.3944		.4287	.503		.6344
16		.3772		.4458	.583		.6001
17		.5316		.4458	.5144		.5658
18		.7202		.6173	.503		.6859
19		1.3032		1.166	.8048		1.2174
20		1.2003		.9431	.9724		1.1145
21		1.0802	1.0802	.7888	.9389		.9602
22		1.0631	1.0631	.823	.9259		1.0117
23		1.0631	1.0631	.823	.9945		1.046
24	.4458		.4801	.6516	.463	.5144	
Max	.7202	1.3032	1.0802	1.166	.9945	1.0974	1.2346
Min	.4458	.3772	.4801	.3429	.463	.5144	.5487
Avg	.5521	.7018	.7030	.7223	.6819	.7579	.8051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 208 / SIRASGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3429	.4458	.4801	.583	.7202
2	.4115	.3772	.3772	.4458	.4801	.6173	.7373
3	.4115	.4115	.4458	.4801	.6173	.6859	.823
4	.4458	.4801	.4801	.6173	.823	.6859	.8573
5	.4458	.5144	.4801	.6859	.823	.7545	.9602
6	.4458	.5487	.5144	.7202	.8916	.823	.9259
7	.5487	.6516	.6516	.823	.8916	.8573	.9602
8	.583	.7545	.8059	.8573	1.1145		.7545
9	.5487	.6859	.823		1.0802		.7888
10	.6001	.4801	.2401		.2401	.5144	.7202
11	.4458		.2743	.5144	.3772	.4801	.7545
12			.3086	.4458	.3429	.4458	.7888
13		.4287	.3086	.3429	.4458	.4458	.7888
14		.3086	.3429	.4115	.4115		.7202
15		.3772	.3429	.4287	.3772		.8573
16	.5144	.4115	.3086	.4458	.3772		.9259
17	.5144	.4287	.3086	.5144	.4458		.7716
18	.7202	.6173	.6173	.5487	.57	.6516	.6001
19	.9945	.8745	1.0974	.823	.8048	.7888	.9088
20	1.0974	.8573	1.166	.6516	.9259	.8573	1.0117
21	1.0288	.7373	1.0288	.4801	.7712	1.0288	.8573
22	.9945	.7202	.6516	.5658	.6859	1.0974	.8573
23	.9602	.7202	.6173	.5316	.583	1.0288	.8573
24	.3772	.3429	.3429	.4115	.4287	.583	.6859
Max	1.0974	.8745	1.166	.8573	1.1145	1.0974	1.0117
Min	.3772	.3086	.2401	.3429	.2401	.4458	.6001
Avg	.6233	.5487	.5365	.5541	.6245	.7183	.8180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044008 / MAHALGAON

Feeder No / Name : 209 / CHINCHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6859	.6859	.6859	.823	.583	.5487
2	.6516	.9602	.7202	.9602	.823	.6173	.583
3	.7202	1.0288	.823	.9945	.8916	.6173	.6173
4	.9602	1.0974	.9602	.9945	.9945	.6859	.6173
5	.9945	1.166	1.0631	1.0288	1.0288	.823	.6516
6	1.0288	1.166	1.166	1.0974	1.0631	.9259	.6859
7	1.0288	1.1317	1.166	1.0974	1.0631	1.0288	.7545
8	1.0288	1.0974	1.0631	1.0974	1.0974	.9602	.6859
9	.9602	.9602	.823		.9602	.9945	
10	.4801	.4801	.5144		.8048	.6859	
11	.4801	.4801	.583	.5487	.6173	.4801	.2743
12	.4458	.4458	.5144	.5487	.6859	.5487	
13	.4115	.4458	.4458	.4801	.6859	.6173	.2058
14	.4458	.3429	.3086	.583	.6036		.2058
15	.4115	.4458	.3429	.6173	.703		.2743
16	.4115	.4458	.5144	.6859	.5144		.2743
17	.4458	.4801	.5487	.6859	.5487		.2743
18	.6516	.5487	.6516	.4115	.5144	.6173	.4801
19	.9945	1.0288	.9259	.9602	.6036	.8573	.8916
20	1.1317	.8916	1.0974	1.0631	.6783	.9259	.9945
21	1.0974	.7545	.9945	.6859	.6859	.9945	.9945
22	1.0631	.7202	.7202	.7545	.6173	1.0288	.9602
23	.9945	.7202	.6516	.7202	.583	.9602	.6173
24	.6516	.6516	.6859	.6173	.7545	.583	.5144
Max	1.1317	1.166	1.166	1.0974	1.0974	1.0288	.9945
Min	.4115	.3429	.3086	.4115	.5144	.4801	.2058
Avg	.7559	.7573	.7487	.7872	.7644	.7767	.5765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 201 / LADGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4801	.4572		.5144	.4287	.4049
2		.3429	.4572		.5144	.4287	.381
3		.3429	.4572		.5144	.4287	.381
4		.3429	.4572		.5144	.4287	.381
5		.3429	.4572		.6001	.5144	.4572
6		.4287	.4572		.6859	.6001	.5335
7		.4287	.6097		.8478	.9431	.6097
8		.6001	.7621		.9221	1.166	.9907
9		.5144	.7621		1.0774	1.0288	.9145
10	.5144	.2858			.1715	.1905	.2858
11	.5144	.2858		.2858	.1715	.1905	.1905
12	.5144	.1905		.1905	.1715	.1905	.1905
13	.5144	.1905		.1905	.1715	.1905	.1905
14		.1905		.1905	.1715	.1905	.1905
15		.1905		.1905	.1715	.1905	.1905
16		.1905		.2858	.1715	.2858	.1905
17	.3429	.1905		.2858	.1715	.2858	.1905
18	.3429	.1905		.2858	.1715	.2858	.2858
19	.4287	.4763		.381	.3429	.381	.381
20	.0857	.4763		.4763	.3429	.4763	.4763
21	.3429	.4763		.4763	.3429	.4763	.4763
22	.2572	.4763		.381	.3429	.4763	.381
23	.2572	.381		.381	.3429	.381	.2858
24		.3429	.3048		.5144	.4287	.381
Max	.5144	.6001	.7621	.4763	1.0774	1.166	.9907
Min	.0857	.1905	.3048	.1905	.1715	.1905	.1905
Avg	.3741	.3482	.5182	.3078	.4151	.4411	.3892



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 202 / SAWKHED GANAGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.2858		.2858	.2572	.2858
2		.3429	.2858		.2858	.2572	.2858
3		.3429	.2858		.2858	.3429	.2858
4		.5144	.381		.2858	.3429	.381
5		.6859	.4763		.2858	.3429	.381
6		.8573	.6668		.2858	.3429	.4763
7		.6859	.5716		.381	.4287	.4763
8		.6001	.4763		.381	.3429	.381
9		.5144	.381		.2858	.3429	.381
10	.3429	.2572		.5144	.6859	.1905	.1829
11	.3429	1.0669		.6001	.7716	.6859	.1829
12	.3429	1.0669		.6859		.6859	.1829
13	.3429	1.0669		.6859	.7716	.6859	.1829
14		1.0669		.8288	.6859	.1905	.1829
15		1.0669			.6859	.1905	.6859
16				.8288	.6859	.1905	.7716
17	.3429			.8478	.6859	.1905	.7716
18	.3429			.2858	.2572	.2858	.2858
19	.5144	.1905		.381	.4287	.381	.381
20	.6859	.381		.4763	.3429	.4763	.4763
21	.6859	.381		.4763	.3429	.4763	.4763
22	.5144	.381		.4763	.3429	.381	.4763
23	.3429	.2858		.381	.3429	.381	.381
24		.3429	.2858		.2858	.2572	.2858
Max	.6859	1.0669	.6668	.8478	.7716	.6859	.7716
Min	.3429	.1905	.2858	.2858	.2572	.1905	.1829
Avg	.4364	.5924	.4096	.5745	.4382	.3604	.3850

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 203 / PURANGOAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6859	.7621		.5716	.6859	.7621
2		.6859	.7621		.5716	.6859	.7621
3		.6859	.7621		.5716	.6859	.7621
4		.6859	.7621		.5716	.8573	.9526
5		1.0288	1.1431		.5716	1.0288	1.1431
6		1.2003	1.3336		.5716	1.2003	1.3203
7		.9431	1.1431		.7621	1.0288	1.1431
8		.7716	.9526		.9526	.8573	.9526
9		.6859	.7621		.5716	.6859	.7621
10		.9145		1.0174	1.3717	1.2193	.8478
11	.3429	1.0669		1.3413	1.3717	1.2193	1.0059
12	.3429	1.0669		1.326	1.3717	1.2955	1.3765
13	.3429	1.0669		.3544	1.7147	1.2955	1.5384
14		1.0669		1.5242	1.7147	1.2955	1.5565
15		1.0669			1.7147	1.2193	1.4746
16		1.0669		1.3108	1.7147	1.2193	1.3108
17	.4287	1.0669		1.4575	1.7147	1.2193	1.4746
18	.5144	.7621		.5716	.6001	1.2193	.6668
19	.6859	1.1431		.7621	.8573	.9526	.8573
20	.8573	1.1431		.9526	.9431	1.1431	.9526
21	.8573	1.0479		.8573	.8573	1.1431	.9526
22	.6859	.9526		.7621	.6859	.9526	.8573
23	.6859	.9526		.7621	.6859	.8573	.7621
24		.6859	.7621		.5716	.6859	.7621
Max	.8573	1.2003	1.3336	1.5242	1.7147	1.2955	1.5565
Min	.3429	.6859	.7621	.3544	.5716	.6859	.6668
Avg	.5744	.9351	.9145	1	.9836	1.0272	1.0398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 204 / 11KV KAPUS WADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	02-SEP-17	03-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715		.2572
2		.1715		.2572
3		.1715		.2572
4		.1715		.2572
5		.1715		.3429
6		.1715		.3429
7		.2572		.5144
8		.2572		.6859
9		.2572		.6859
10	.3429		.1715	
11	.3429		.1715	
12	.3429		.1715	
13	.3429		.1715	
14			.1715	
15			.1715	
16			.1715	
17	.1715		.1715	
18	.2572		.1715	
19	.2572		.3429	
20	.3429		.3429	
21	.3429		.3429	
22	.2572		.2572	
23	.2572		.2572	
24		.1715		.2572
Max	.3429	.2572	.3429	.6859
Min	.1715	.1715	.1715	.2572
Avg	.2962	.1972	.2205	.3858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 205 / 11KV BABHULGAON GANGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.381		.381	.2572	.2858
2		.1715	.381		.381	.2572	.2858
3		.1715	.381		.381	.2572	.2858
4		.1715	.4763		.381	.3429	.381
5		.1715	.5716		.381	.5144	.5716
6		.1715	.7621		.381	.6001	.6668
7		.1715	.4763		.381	.4287	.5716
8		.1715	.4763		.381	.3429	.4763
9		.1715	.381		.2858	.3429	.381
10	.1715	.1715		1.0174	1.3717	1.2193	1.0059
11	.1715	.1715		1.326	1.3717	1.2193	1.326
12	.1715	.1715		1.326	1.3717	1.2193	1.326
13	.1715	.1715		1.2431	1.5432	1.2193	1.3765
14		.1715		1.326	1.5432	1.1431	1.3765
15		.6859		1.3108	1.4575	1.1431	1.326
16		.1715		1.3108	1.4575	1.2193	1.3108
17	.1715	.1715		1.1603	1.4575	1.2193	1.3108
18	.1715			.2858	.2572	.2858	.2858
19	.1715	.381		.4763	.3429	.381	.381
20	.1715	.4763		.6668	.4287	.4763	.4763
21	.1715	.4763		.5716	.4801	.4763	.4763
22	.1715	.381		.5716	.3429	.381	.4763
23	.1715	.381		.4763	.3429	.381	.381
24		.1715	.381		.381	.2572	.2858
Max	.1715	.6859	.7621	1.326	1.5432	1.2193	1.3765
Min	.1715	.1715	.381	.2858	.2572	.2572	.2858
Avg	.1715	.2477	.4668	.9335	.7285	.6493	.7094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 206 / BHAOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4572		.5144	.5144	
2		.4287	.4572		.5144	.5144	
3		.4287	.4572		.5144	.5144	
4		.4287	.4572		.6001	.5144	
5		.4287	.4572		.6859	.6001	
6		.4287	.4572		.8573	.6001	
7		.5144	.4572		1.0288	.8573	
8		.6001	.6097		1.1869	1.1145	
9		.5144	.6097		1.4089	1.1145	
10	.6859	.4763		.381	.3429	.4763	
11	.6859	.381		.381	.3429	.381	
12	.6859	.381		.381	.2572	.381	
13	.6859	.2858		.381	.2572	.2858	
14		.2858		.381	.2572	.2858	
15		.2858			.2572	.2858	
16		.2858		.381	.2572	.2858	
17	.6001	.381		.5716	.2572	.2858	
18	.6859	.5716		.7621	.4287		1.3108
19	.8573	.9526		.9526	.8573		1.3108
20	.9431	.9526		1.2384	.8573		1.1203
21	.8573	.8573		1.1431	.8573		1.1203
22	.6859	.7621		1.0479	.6859		.9526
23	.6859	.7621		.9526	.6859		.7621
24		.4287	.381		.5144	.5144	
Max	.9431	.9526	.6097	1.2384	1.4089	1.1145	1.3108
Min	.6001	.2858	.381	.381	.2572	.2858	.7621
Avg	.7326	.5104	.4801	.6888	.6011	.5292	1.0962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044009 / LADGOAN

Feeder No / Name : 207 / mhaski

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.381		.4287	.3429	.3239
2		.3429	.381		.4287	.3429	.3239
3		.3429	.381		.4287	.3429	.3239
4		.3429	.381		.5144	.3429	.3239
5		.3429	.381		.6001	.3429	.3239
6		.3429	.381		.6859	.4287	.3048
7		.3429	.4572		.6859	.5144	.4572
8		.3429	.7621		.7716	.6859	.6097
9		.5144	.7621		.6859	.6859	.6097
10	.3429	.1905		.1905	.1715		.381
11	.6859	.1905		.1905	.1715		.1905
12	.6859	.1905		.1905	.1715	.0953	.1905
13	.6859	.1905		.1905	.1715	.0953	.1905
14		.1905		.1905	.1715	.1905	.1905
15		.1905		.2858	.2572	.2858	.1905
16		.1905		.2858	.1715	.2858	.1905
17	.6859	.381		.2858	.1715	.2858	.1905
18	.3429	.381		.381	.2572	.381	.381
19	.5144	.5716			.5144	.381	.6668
20	.6001	.5716		.7621	.6001	.5716	.7621
21	.5144	.5716		.6668	.5144	.5716	.6668
22	.3429	.4763		.5716	.3429	.381	.5716
23	.3429	.381		.381	.3429	.381	.381
24	.3429	.3429	.3048		.3429	.3429	.3239
Max	.6859	.5716	.7621	.7621	.7716	.6859	.7621
Min	.3429	.1905	.3048	.1905	.1715	.0953	.1905
Avg	.5073	.3445	.4572	.3517	.4001	.3763	.3779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 201 / NAGAMTHAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.2667	.1943	.1619	.218	.2591	.4572
2	.2347	.2667	.2267	.2012	.218	.2915	.4572
3	.2012	.3048	.2915	.2347	.2347	.421	.4572
4	.2012	.3048	.3239	.3018	.2515	.7125	.5335
5	.2012	.3429	.3563	.3353	.285	.3887	.724
6	.218	.381	.3887	.3856	.4527	.421	.7621
7	.4694	.5335	.421	.503	.6036	.6668	.8383
8	.4694	.5906	.5506	.6539	.7545	.743	.7811
9	.4527	.5144	.3887	.4862	.7042	.7621	.6478
10	.2263	.1905	.2753	.3961	.3734	.2286	.3239
11	.2641	.2286	.2054	.2263	.4854	.2667	.3239
12		.2286	.1886	.2075	.3734	.2477	.2915
13		.2286	.1886	.2075	.2427	.2667	.2915
14	.218	.2286	.1698	.2075	.2427	.2667	.2915
15		.2477	.2075	.2075	.2241	.2858	.3239
16	.3018	.2286		.2263	.2614	.3048	.5344
17	.3961	.3048		.2641	.3174	.3429	.4858
18	.5281	.5716		.415	.4294	.4763	.4294
19	.7545	.6859	.6908	.6602	.7282	.6478	.5601
20	.6602	.6478	.7842	.7545	.6722	.6097	.6535
21	.547	.5716	.7095	.679	.5601	.5716	.5788
22	.5281	.5335	.5415	.4904	.5228	.5716	.5228
23	.5093	.4572	.3734	.4527	.5041	.5335	.4854
24	.2347	.2477	.1619	.1619	.218	.2683	.4572
Max	.7545	.6859	.7842	.7545	.7545	.7621	.8383
Min	.2012	.1905	.1619	.1619	.218	.2286	.2915
Avg	.3738	.3794	.3637	.3675	.4116	.4398	.5088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 202 / MAHANKALWADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	1.1065	.4572	1.1065	1.0059	1.1736	.4191
2	1.1736	1.1065	.4572	1.1401	1.0059	1.2071	.4572
3	1.2071	1.1401	.5335	1.1736	1.0395	1.2407	.6478
4	1.2407	1.2071	.6478	1.2407	1.073	1.3413	.8002
5	1.2742	1.2742	.724	1.3077	1.1401	1.4083	1.0669
6	1.3413	1.3413	.7621	1.3748	1.3413	1.4754	1.2574
7	1.4083	1.4754	1.1431	1.6095	1.6766	1.7436	1.3336
8	1.4754	1.3748	1.448	.8383	1.8107	1.8107	1.105
9	1.3748	1.3748	1.5242		1.8107	1.8778	.8764
10	.415	.381	.6097		.5975	.3048	1.4251
11	.4527	.4191	.4108	.3772	.4481	.4572	1.6766
12	.3772	.381	.4108	.3772	.3734		1.7772
13	.3772	.3429	.4108	.3772	.3361		1.6766
14	.3772	.3429	.4108	.3772	.3734	.381	1.643
15		.3429	.3361	.3772	.4108	.4191	1.576
16	.5658	.3429		.415	.3734	.4572	1.5089
17	.5658	.4572		.4338	.2614	.4954	1.5089
18	.7545	.8383		.6036	.5975	.6859	.4854
19	1.094	1.0669	1.1203	.9054	1.0829	.9145	.6535
20	1.0374	.9907	1.0456	1.0562	1.0642	.9526	.9709
21	.9054	.9526	.8402	.9808	1.0456	.9526	.8962
22	.9054	.8764	.4108	.8676	.6722	.8383	.8589
23	.7545	.7621	.3734	.7545	.3921	.6478	.8215
24	1.1065	1.073	.4191	1.1065	1.0059	1.1736	.4191
Max	1.4754	1.4754	1.5242	1.6095	1.8107	1.8778	1.7772
Min	.3772	.3429	.3361	.3772	.2614	.3048	.4191
Avg	.9286	.8738	.6903	.8546	.8724	.9981	1.0776



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 203 / DAGPIMPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.4191	.3887	.4024	.503	.6668	.5716
2	.3353	.4572	.421	.4359	.503	.724	.5716
3	.3688	.4572	.4534	.4694	.5365	.743	.6097
4	.4359	.5335	.5182	.57	.57	.7621	.6859
5	.4694	.6668	.6154	.6371	.6036	.8573	.8764
6	.5365	.8764	.7042	.6874	.6706	.8954	.9526
7	.6706	1.0479	.8048	1.0059	.9054	1.3527	1.0288
8	.7042	1.2003	1.0395	1.1233	1.2071	1.4861	.724
9	.7209	.8002	.7773	1.1065	1.2574	1.5623	.6859
10		.7621	.2263	.415		.2286	.6706
11			.2075	.2452	.2987	.2858	.7042
12			.2075	.1886	.2801	.2286	.8383
13		.1905	.2075	.1886	.2614	.2477	.7712
14		.2286	.2263	.1886	.2801	.2667	.7042
15		.2286	.2263	.2263	.2987	.2667	.7377
16		.2286		.2452	.3361	.2667	.8383
17		.2286		.2641	.4108	.2667	.8383
18	.7545	.4191		.3395	.3734	.5716	.4108
19	.8488	.4572	.7655	.7167	.7468	.8383	.7095
20	.7545	.8573	.8029	.811	.7095	.7621	.8775
21	.679	.7621	.6722	.7922	.6722	.6859	.7468
22	.6602	.6478	.6348	.6413	.6535	.6478	.6722
23	.6224	.5906	.5228	.6224	.6348	.6097	.5601
24	.3521	.381	.3887	.4024	.503	.6668	.5716
Max	.8488	1.2003	1.0395	1.1233	1.2574	1.5623	1.0288
Min	.3353	.1905	.2075	.1886	.2614	.2286	.4108
Avg	.5780	.5655	.5148	.5302	.5746	.6621	.7232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 204 / BHAMATHAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.3429	.3734	.3395	.4108	.9145
2		.3395	.2987	.3734	.3395	.4108	.9145
3		.3395	.2987	.3734	.3395	.3734	.9145
4		.3584	.2987	.3361	.3772	.3734	.9145
5		.3395	.3361	.3361	.3772	.3361	.9526
6		.3772	.3734	.3361	.3395	.3361	.9907
7		.3772	.4108	.3734	.3395	.3361	.9907
8		.4904	.4854	.1867	.3018	.3734	.9526
9		.3772	.4108	.3018	.2641	.3734	1.1431
10		.7621	.7468	.8383	.8383	.9145	.1886
11		.7621	.7377	.8718	.9724	1.1812	.1509
12		.724	.7042	.8048		1.2193	.1509
13	.503	.6859	.7377	.7712		1.2193	.1509
14	.503	.724	.7377	.8048	1.0395	1.1812	.1886
15	.503	.7621	.7377	.8048	1.073	1.1812	.1886
16	.5365	.7621		.8048	1.073	1.1812	.1886
17	.5365	.8002		.8383	1.1065	1.1431	.2263
18	.3395	.381		.5281	.3734	.381	.2614
19	.5281	.5335	.3734	.5281	.4854	.5335	.3772
20	.5281	.6097	.3734	.4904	.4854	.4954	.4854
21	.4904	.6097	.4481	.4527	.5228	.4572	.4854
22	.4527	.5335	.4854	.415	.4854	.4572	.4481
23	.415	.4191	.4481	.3772	.4481	.4191	.4108
24		.415	.381	.3734	.3772	.4108	.9145
Max	.5365	.8002	.7468	.8718	1.1065	1.2193	1.1431
Min	.3395	.3395	.2987	.1867	.2641	.3361	.1509
Avg	.4851	.5358	.4841	.5289	.5590	.6541	.5627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044034 / NAGAMTHAN

Feeder No / Name : 205 / AWALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8764	.8962	.8402	.8676	.8402	.6097
2	.9054	.8764	.8962	.9335	.8676	.9335	.6097
3	.9054	.9526	.9335	1.0269	.9054	1.0269	.6478
4	.9431	.9907	1.0082	1.2136	.9054	1.1203	.6859
5	1.0185	1.0669	1.1203	1.307	.9808	1.2696	.8002
6	1.0059	1.1431	1.1949	1.3443	1.0185	1.363	.8764
7	1.1736	1.0669	1.251	1.3256	1.0374	1.3817	.9526
8	1.0059	1.0288	1.307	1.0456	1.094	1.2696	1.0098
9	.9221	.7621	1.0456	.9808	1.094	.9709	1.0288
10	.503	.5716	.7842	.7377	.7209	.8002	.3772
11	.6602	.6478	.7209	.6706	.7712	.8764	.4715
12		.6478	.7209	.7545	.8383	.8764	.3395
13	.5658	.6859	.6874	.7545	.9389	.8383	.3395
14	.5533	.7621	.5868	.7712	.9556	.8764	.3772
15	.57	.6097	.5533	.8048	.9556	.8764	.415
16	.5868	.6097		.8718	.9054	.9145	.4527
17	.5868	.6097		.9221	.8886	.9526	.5658
18	.6979	.9526		.6706	.9709	1.0669	.6535
19	1.0374	1.3717	1.0456	.7545	.9522	1.3336	.8402
20	1.094	.9526	1.0082	.8676	.9522	1.2574	.9896
21	1.0562	.9907	.9896	1.0374	.9335	1.105	.5788
22	.9808	.9907	.9709	.9997	.8962	1.0288	.9709
23	.8676	.9907	.9335	.8676	.8775	.8764	.9335
24	.8488	.8383	.8962	.8402	.8676	.8402	.6097
Max	1.1736	1.3717	1.307	1.3443	1.094	1.3817	1.0288
Min	.503	.5716	.5533	.6706	.7209	.8002	.3395
Avg	.8404	.8748	.9310	.9309	.9248	1.0290	.6723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 201 / 11KV PALKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.5601	.8488	.6535	.6335	.5658	.5601
2	.724	.5601	.9054	.6535	.6335	.5847	.5601
3	.905	.5601	.9431	.7468	.724	.8488	.5601
4	.9955	.6535	1.0185	.8402	.905	1.0374	.5601
5	.9955	.7468	1.0374	.8402	.9955	1.0374	.6535
6	1.0745	.8402	1.0456	.9335	1.0745	1.1317	.6535
7	1.086	.7468	1.0456	1.0974	1.0974	1.1317	.6535
8	.9955		.8402	1.0164	.9431	1.0374	.5601
9	.905		.6535	.8316	.7545	.7733	.5658
10	.5601		.3856	.443	.4858	.7468	
11	.5601	.2591	.4481	.3898	.4049	.7468	.2241
12	.4668	.2591	.4854	.3898	.3887	.5601	
13	.3734	.2949	.3734	.4207	.3563	.5601	.168
14	.3734	.3315	.3734	.3506	.3563	.4668	.1867
15	.3734	.3647	.3921	.3506	.3605	.3734	.2241
16	.3734	.4144	.4108	.3506	.4973	.2801	.2241
17	.3734	.4191	.5228	.3506	.4973	.2801	.3361
18	.7468	.5658	.6348	.5487	.6602	.7095	.4481
19	.8402	.9054	.6722	.905	.8488	.7468	.7842
20	.8402	.8488	.7842	.9955	1.0374	.9335	.8215
21	.8402	.8299	.7468	.724	1.0374	1.0269	.8402
22	.7468	.811	.6535	.6335	.6602	.8402	.7095
23	.6535	.6602	.5975	.543	.6413	.5601	.5601
24	.6335	.5601	.6602	.5601	.6335	.6224	.4668
Max	1.086	.9054	1.0456	1.0974	1.0974	1.1317	.8402
Min	.3734	.2591	.3734	.3506	.3563	.2801	.168
Avg	.7112	.5806	.6866	.6487	.6928	.7334	.5146

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 202 / 11KV SHIVRAI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3544	.5601	.6584	.5601	.443	.4784	.8402
2	.362	.5601	.6584	.5601	.443	.4784	.8402
3	.443	.5601	.6767	.5601	.5316	.4733	.8402
4	.443	.5601	.6878	.6535	.5316	.7888	.9335
5	.5258	.6602	.7059	.6535	.6201	.8573	1.0164
6	.443	.7468	.724	.7468	.7011	.9221	1.0164
7	.6135	.8402	.7973	1.0164	1.1888	1.1065	1.0974
8	.7011		1.2403	1.1888	1.1736	1.576	.7545
9	.8764	1.0974	1.1765	.924	1.2574	1.4083	.5658
10	.5601	.5601	.415	.2743	.3772	.7282	.5975
11	.5601	.4668	.3734	.2926	.3584	.5658	.6413
12	.3734	.3734	.3734	.2926	.3361	.3734	
13		.2263	.3734	.3109	.3361	.3734	.6722
14		.2263	.3734	.2743	.2829	.2801	.6348
15	.3734	.3395	.2987	.2743	.3395	.3734	.6348
16	.3734	.3772	.2987	.2743		.5601	.6722
17	.3734	.3772	.2987	.362	.4715	.5601	.7095
18	.8402	.5658	.4481	.4525	.5658	.5601	.8215
19	.9335	.9054	.7095	.9955	.7922	.6535	1.0349
20	1.0164	1.094	1.0082	.905	1.0374	.9335	.961
21	1.0164	1.0562	.9335	.905	.9808	1.0269	.924
22	.9335	1.0374	.9335	.905	.9431	.9335	.924
23	.8316	.8488	.8402	.8145	.9054	.8402	.8962
24	.3544	.7468	.5544	.4668	.3544	.443	.7468
Max	1.0164	1.0974	1.2403	1.1888	1.2574	1.576	1.0974
Min	.3544	.2263	.2987	.2743	.2829	.2801	.5658
Avg	.6046	.6429	.6482	.6110	.6509	.7206	.8163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044082 / 33/11KV SHIVRAI

Feeder No / Name : 203 / 11KV DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.905	.7468	1.0374	1.0164	1.0745	1.0185	.5601
2	.9955	.7468	1.094	.924	.9955	1.0562	.5601
3	.9955	.7468	1.094	.924	.9955	1.0562	.5601
4	1.086	.8402	1.094	.924	.985	1.1317	.5601
5	1.086	1.0269	1.1016	1.0059	1.0745	1.1694	.6535
6	1.0745	1.1088	1.1203	1.0059	1.0745	1.2071	.6535
7	1.0745	1.0974	1.1203	1.0974	1.0974	1.2136	.7468
8	1.0745		1.1203	1.0974	1.0269	1.363	.9145
9			.9335	1.0164	.9335	1.0829	.9431
10	1.1088		.6135	.6135	.7287	.9335	
11	1.1203	.4534	.6348	.6135	.7449	.9335	.2614
12	.8402	.4588	.6722	.6485	.7773	.5601	
13	.7468	.4915	.6348	.6485	.7373	.7468	.1867
14	.6535	.4973	.5975	.7011	.7293	.7468	.2241
15	.6535	.4973	.6348	.7011	.7127	.7468	.2241
16	.6535	.5365	.6348	.7011		.6535	.2614
17	.4668	.5533	.7468	.7011	.9945	.6535	.4481
18	1.0269	.6722	.8589	.8145	1.0374	.9335	.6722
19	1.1088	1.1694	.9335	1.086	1.1317	1.0456	.9709
20	1.1088	1.094	1.0082	1.086	1.1317	1.0974	.9979
21	1.1088	1.094	1.1203	1.086	1.094	1.0974	1.0349
22	1.1088	1.0374	1.1088	1.086	1.0185	1.0974	1.0974
23	.9335	1.0374	1.0974	1.086	.9997	1.0974	1.0974
24	.9955	.7468	1.0374	1.0164	1.086	.9808	.5601
Max	1.1203	1.1694	1.1203	1.0974	1.1317	1.363	1.0974
Min	.4668	.4534	.5975	.6135	.7127	.5601	.1867
Avg	.9533	.793	.9187	.9000	.9644	.9843	.6449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 201 / 11kv Darga

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4854	.4668	.4854	.4668	.4904	.4294
2	.4294	.4668	.4668	.4668	.4668	.4715	.3561
3	.3921	.4668	.5087	.3734	.5601	.4715	.3734
4	.5228	.4854	.5601	.6348	.5601	.4904	.407
5	.6722	.5041	.5601	.6722	.6535	.5041	.4748
6	.7468	.6161	.6535	.6161	.6535	.5975	.5935
7	.7842	.6908	.6535	.6908	.7468	.6535	.6613
8	.7468	.7095	.7468	.7095	.7468	.6535	.5935
9	.6908	.5935	.6535	.6908	.6908	.6348	.5935
10	.6161	.5087	.5788	.6348	.6161	.5415	.5087
11	.5601	.5087	.5415	.6348	.5601	.5228	.5601
12	.4854	.5087	.4854	.5601	.5228	.5228	.4668
13	.5228	.4239	.4668	.5228	.5228		.4668
14	.4481	.4668	.4108	.4294	.4668		.3734
15	.4108	.4668	.4481	.4668	.4668	.5788	.3734
16	.4481	.4239	.4668	.4854	.4668	.5601	
17	.4854	.5144	.4854	.5415	.5228	.5975	
18	.5788	.5087	.5228	.5087	.5228	.6722	
19	.7095	.5087	.7468	.5935	.7095	.7095	.8962
20	.6348	.6535	.7095	.5935	.6908	.6535	.8215
21	.6161	.6535	.6535	.6783	.6348	.6161	.7468
22	.5975	.6535	.5975	.7468	.6161	.5788	.5601
23	.5415	.5601	.5415	.6535	.5601	.5228	.5601
24	.5041	.5041	.4239	.4887	.5935	.5228	.4668
Max	.7842	.7095	.7468	.7468	.7468	.7095	.8962
Min	.3921	.4239	.4108	.3734	.4668	.4715	.3561
Avg	.5671	.5368	.5562	.5783	.5841	.5712	.5373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 202 / 11 Rotegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.4287	.5601	.5228	.6535	.5281	.7282
2	.2801	.373	.5601	.5415	.6535	.5571	.6274
3	.3361	.3277	.6535	.6535	.724	.6036	.5935
4	.3734	.3361	.6535		.7888	.6009	.9088
5	.3734	.3563	.7468	.9709	.8669	.6802	1.1389
6	.4294	.4428	.8402	.8589	.8573	.8192	1.2883
7	.4668	.5468	.9335	1.2323	.9431	1.1736	1.307
8	.5041	.5639	1.0269	1.2696	.9012	1.3426	.8402
9	.5083	.8402	.9335	1.3676	1.2136	1.3817	.8402
10	.5014	.8402	.6908	.7186	1.4754	.7468	.8402
11	.362	.9335	.5975	.583	1.0829	.6535	.7468
12		.8478	.4668	.4961	.9709		.8402
13		.763	.4854	.5373	.8962	.6908	.8402
14	.2534	.6783	.4294	.5121	.8215	.6535	.9335
15	.4252	.6783	.4668	.543	.7095	.5975	.9335
16	.4557	.763	.7468	.5121	.6535	.5228	
17	.5144	.6783	.5601	.6089	.6036	.7468	
18	.6661	.6783	.6348	.6535	.6516	.9335	
19	1.0745	.763	.7842	.7316	1.0387	1.0269	1.307
20	.7522	.8402	1.0829	.8316	1.1568	1.0829	1.2696
21	.6878	.7468	1.0082	.8402	.9088	.9149	1.0642
22	.6219	.5935	.8962	.8316	.8063	.8589	.9335
23	.5729	.5601	.8029	.7392	.7701	.8029	.8962
24	.2427	.503	.5601	.5415	.7468	.5249	.7655
Max	1.0745	.9335	1.0829	1.3676	1.4754	1.3817	1.307
Min	.2427	.3277	.4294	.4961	.6036	.5228	.5935
Avg	.4855	.6285	.7134	.7434	.8706	.8019	.9354



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 203 / 11kv Tilakroad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9522	.9335	.8962	.9335	.9522	.9709
2	.8775	.9335	.8402	.9335	.9335	.9335	.9335
3	.8402	.9709	.9335	1.0082	1.0269	.9709	.9335
4	.9709	.9896	1.0269	1.1016	1.1203	1.0082	1.0829
5	1.1389	1.0829	1.0269	1.3443	1.2136	1.0829	1.1949
6	1.3443	1.307	1.1203	1.419	1.307	1.2323	1.2696
7	1.4377	1.3256	1.307	1.4003	1.4003	1.1949	1.3256
8	1.4003	1.2883	1.2136	1.2136	1.4003	1.1763	1.0829
9	1.2323	.9335	1.1576	1.1576	1.1576	1.1763	1.0269
10	1.1016	.9326	1.1203	1.0829	1.0642	1.0456	.9335
11	1.0642		1.0269	1.1016	.9896	.9709	.9335
12	.9709	.9335	.9896	1.0269	.9522	1.0456	.8402
13	1.0829	.9335	.9522	.9709	.9335	1.0456	.8402
14	.8775	1.0269	.8962	.8962	.8962	.9335	.9335
15	.8215	1.0269	.8029	.5415	.8775	.8589	.9335
16		1.1203	.7655	.5975	.8962	.7842	
17	1.1576	1.1203	.8215	1.1763	.9896	.9335	
18	1.1763	1.1203	.8589	1.2136	1.0829	1.1949	
19	1.531	1.2136	1.4003	1.2717	1.475	1.3817	2.0538
20	1.4563	1.2003	1.4563	1.4003	1.4563	1.4563	1.7737
21	1.3256	1.4003	1.363	1.307	1.3256	1.307	1.6244
22	1.2323	1.307	1.2136	1.307	1.2323	1.2136	1.4937
23	1.0642	1.1203	1.0642	1.2136	1.0829	1.1203	1.3443
24	.9522	.9709	1.0269	.9328	1.1203	.9896	1.0082
Max	1.531	1.4003	1.4563	1.419	1.475	1.4563	2.0538
Min	.8215	.9326	.7655	.5415	.8775	.7842	.8402
Avg	1.1300	1.0961	1.0549	1.1048	1.1195	1.0837	1.1682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 204 / town 1

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6908	.5601	.6535	.5601	.6722	.6908
2	.5975	.6722	.5601	.5975	.5601	.6348	.5935
3	.5601	.6722	.6535	.6535	.6535	.6535	.6535
4	.7095	.6722	.6535	.7468	.6535	.6722	.7095
5	.9149	.6908	.7468	.9149	.7468	.6908	.8589
6	1.0642	.8589	.8402	.9709	.8402	.7842	.9335
7	1.1763	.9522	.8402	.9522	.8402	.8029	.9896
8	1.1203	.8589	.8402	.8775	.8402	.8589	.8402
9	.9335	.7468	.7655	.7095	.8029	.7842	.7468
10	.7468		.6722	.6722	.7468	.6161	.7468
11	.6722		.5975	.6535	.7095	.5601	.6535
12	.6722	.6535	.6535	.6348	.6535	.7468	.6535
13	.6535	.5601	.6161	.5788	.6348	.7095	.7468
14	.5788	.5601	.5415	.5788	.6348	.6535	.7468
15	.6348	.6535	.6722	.6161	.6161	.5975	.7468
16		.6535	.6535	.5975	.5975	.5601	
17	.7655	.6859	.6908	.6348	.6161	.7842	
18	.7842	.7468	.7842	.7468	.6535	.9335	
19	.9522	.8402	.9335	.8402	.8589	1.0829	1.251
20	.9522	.8402	1.0082	.8402	.9522	1.0082	1.0269
21	.9335	.9335	.9709	.8402	.9709	.9149	.9335
22	.8589	.8402	.8962	.8402	.8962	.8402	.7842
23	.7842	.7468	.7842	.7468	.8215	.7842	.6908
24	.6908	.7095	.5601	.7095	.6535	.7356	.7282
<b>Max</b>	<b>1.1763</b>	<b>.9522</b>	<b>1.0082</b>	<b>.9709</b>	<b>.9709</b>	<b>1.0829</b>	<b>1.251</b>
<b>Min</b>	<b>.5601</b>	<b>.5601</b>	<b>.5415</b>	<b>.5788</b>	<b>.5601</b>	<b>.5601</b>	<b>.5935</b>
<b>Avg</b>	<b>.8004</b>	<b>.7381</b>	<b>.7289</b>	<b>.7336</b>	<b>.7297</b>	<b>.7534</b>	<b>.7964</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 205 / pahade express feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.0943	.1187	.112	.132	.1509	.1357
2	.1494	.0943	.12	.112	.132	.0377	.1494
3	.1494	.0754	.1187	.0934	.132	.1509	.1494
4	.1494	.0754	.1187	.0934	.132	.1509	.1494
5	.1494	.0754	.1187	.0934	.132	.1509	.1494
6	.1494	.0754	.1187	.0934	.132	.1509	.1494
7	.1494	.0754	.1187	.1307	.132	.132	.1494
8	.1494	.0754	.1187	.1307	.132	.1509	.1494
9	.1494	.0686	.1307	.1294	.1494	.1494	.1494
10	.1494	.1017	.1307	.1494	.1494	.1494	.1494
11	.1494	.1017	.1307	.1494	.1494	.0934	.1494
12	.1494	.0747	.1307	.1509	.1494	.1494	.1494
13	.1494	.0678	.0934	.1494	.1494	.1494	.1494
14	.1494	.0509	.1307	.1494	.1494	.1494	.1494
15	.1494	.0509	.1494	.1494	.1494	.1494	.1494
16		.0509	.112	.1494	.1494	.1494	
17	.1494	.1017	.0934	.1494	.1494	.1494	
18	.0934	.1017	.0934	.1357	.1509	.1494	
19	.1132	.1017	.1307	.1357	.1509	.1494	
20	.112	.1307	.112	.1357	.132	.1494	
21	.1132	.1187	.112	.1509	.1509	.1494	
22	.1132	.1187	.112	.1357	.1509	.1494	
23	.0943	.1307	.112	.1187	.1509	.1494	.0747
24	.1494	.0943	.1187	.1029	.1187	.1509	.1494
Max	.1494	.1307	.1494	.1509	.1509	.1509	.1494
Min	.0934	.0509	.0934	.0934	.1187	.0377	.0747
Avg	.1382	.0878	.1185	.1292	.1419	.1421	.1442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 206 / water supply Express NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0377	.0339	.037	.0754	.0377	.0373
2	.0373	.0377	.0339	.0362	.0754	.0377	.0339
3	.0373	.0377	.0339	.0373	.0754	.0377	.0339
4	.0373	.0377	.0339	.056	.1132	.0377	.0373
5	.0373	.0377	.0509	.056	.1132	.0377	.0514
6	.0934	.0377	.0509	.0747	.1509	.0377	.0509
7	.1307	.0377	.0509	.1867	.1509	.0377	.0678
8	.168	.0377	.0509	.112	.1132	.0377	.0678
9	.1307	.0339	.0373	.0934	.0747	.0373	.0509
10	.0934	.0339	.0373	.0934	.0747	.0373	.0509
11	.0373	.0339	.0373	.168	.0747	.0373	.0339
12	.0747	.0339	.0373	.168	.0747	.0373	.0339
13	.056	.0339	.0373	.0934	.0747		.0373
14	.0747	.0339	.0373	.0934	.0747		.0373
15	.0747	.0339	.0373	.0747	.0747	.0373	.0339
16		.0339	.0373	.0373	.056		
17	.0934	.0373	.0373	.0373	.0566	.0373	
18	.056	.0373	.0373	.0339	.0566	.0373	
19	.056	.0373	.0373	.0339	.0377	.0373	.0373
20	.0377	.0934	.0373	.0339	.0377	.0373	.0373
21	.0377	.0343	.0373	.0339	.0377	.0373	.0373
22	.0377	.0037	.0373	.0339	.0377	.0373	.0373
23	.0377	.0934	.0373	.0339	.0377	.0373	.0373
24	.0373	.0377	.0339	.0373	.0339	.0377	.0373
Max	.168	.0934	.0509	.1867	.1509	.0377	.0678
Min	.0373	.0037	.0339	.0339	.0339	.0373	.0339
Avg	.0658	.0395	.0389	.0706	.0743	.0375	.0420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044093 / 33/11kv Vaijapur

Feeder No / Name : 207 / 11 KV MGM

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2033	.2075	.1865	.1867	.2241	.2075	.1865
2	.1867	.2075	.1865	.1867	.2241	.2075	.1865
3	.1867	.2075	.1865	.2054	.2241	.2075	.1865
4	.2241	.2075	.2054	.2241	.2054	.2075	.2035
5	.2801	.2263	.2241	.2614	.2054	.2075	.2035
6	.3361	.2641	.2241	.2427	.2054	.2427	.2427
7	.3174	.2263	.2035	.2054	.2054	.2054	.2204
8	.2987	.2054	.2614	.2054	.2241	.2054	.2374
9	.2614	.1865	.2427	.168	.2241	.1867	.2035
10	.2241	.2035	.2241	.2427	.2241	.1867	.2241
11	.168	.2035	.1867	.2614	.2054	.1867	.2054
12	.2987	.2241	.2427	.2614	.2054	.1867	.2054
13	.2801	.2035	.2241	.2801	.2054	.2054	.2054
14	.2614	.2054	.2054	.2614	.2241	.1867	.2054
15	.2241	.1865	.2054	.2614	.2241	.168	.2054
16	.2241	.2054	.2427	.2614	.2054	.1494	
17	.2427	.2241	.2614	.2614	.2241	.2241	
18	.2614	.2241	.2427	.2801	.2241	.2614	
19	.3734	.2058	.3734	.2801	.3174	.2987	.4668
20	.3547	.2241	.3547	.2801	.3361	.3361	.4294
21	.2987	.2241	.3174	.2801	.2987	.3174	.3734
22	.2801	.2241	.2614	.2543	.2801	.2801	.3547
23	.2427	.2241	.2427	.2035	.2641	.2427	.2987
24	.2033	.2241	.2054	.197	.2241	.2263	.2241
Max	.3734	.2641	.3734	.2801	.3361	.3361	.4668
Min	.168	.1865	.1865	.168	.2054	.1494	.1865
Avg	.2597	.2144	.2380	.2397	.2335	.2223	.2509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 201 / 11 KV CHINCHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3982	.4115	.4115	.6001	.6001	.4801
2	.4287	.3982	.4115	.4115	.6001	.6173	.4801
3	.4287	.4115	.4458	.4458	.6001	.6173	.5144
4	.5144	.4115	.4458	.4801	.6001	.6516	.5487
5	.5144	.4115	.4801	.4801	.6706	.6859	.583
6	.5144	.5144	.583	.5487	.6478	.7042	.6859
7	.503	.5144	.6706	.6173	.6478	.7125	.8059
8	.503	.6036	.7125	.7888	.8421	.9069	.6859
9	.4858	.583	.6859	.6687	.8583	.9717	.5316
10	.4115	.3982	.2743	.2172	.362	.3429	.4458
11	.2401		.2401	.2172	.181	.2401	.4458
12	.2172	.2534	.2229	.2172	.2172	.2229	.3772
13	.181	.2172	.2058	.2172	.2534	.2229	.4207
14	.181	.2172	.2229	.2172	.2534	.2058	.4207
15	.2172	.2534	.2058	.2172	.2534	.2058	.4207
16	.2172	.2896	.2058	.2172	.2534	.2401	.4908
17	.2896	.3258	.2058	.2534	.2401		.4908
18	.4108	.4344	.4115	.3734	.3734	.3772	.2896
19	.7468	.8215	.6516	.6535	.7095	.6516	.2858
20	.7842	.7964	.583	.7095	.7842	.6859	.6516
21	.7468	.6348	.583	.6535	.7468	.6687	.6722
22	.7095	.6348	.5487	.5975	.6722	.583	.6348
23	.6722	.5975	.5144	.5975	.5975	.5487	.6348
24	.4525	.4344	.4344	.3772	.6001	.583	.4801
Max	.7842	.8215	.7125	.7888	.8583	.9717	.8059
Min	.181	.2172	.2058	.2172	.181	.2058	.2858
Avg	.4499	.4589	.4315	.4412	.5235	.5324	.5199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 044105 / 33/11 Kv Chinchadgaon

Feeder No / Name : 202 / 11 KV AGARSAYGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3982	.3982	.3429	.4525	.4344	.3429
2	.362	.3982	.3982	.3429	.4525	.4344	.3429
3	.362	.4344	.3982	.4115	.543	.4344	.3429
4	.4525	.4706	.4344	.4115	.543	.5068	.3601
5	.543	.5068	.5068	.4458	.543	.543	.3944
6	.6335	.6154	.5792	.4801	.543	.5792	.4115
7	.7059	.6878	.6878	.583	.543	.6154	.4115
8	.6335	.5792	.543	.5144	.4458	.5068	.6001
9	.4887	.4344	.3772	.3429	.3429	.3982	.6802
10	.3258	.3086	.3429	.5144	.463	.4458	.1448
11	.3429		.4115	.5144	.6173	.6516	.1086
12	.3429	.3944	.4287	.5144	.6335	.6687	.0724
13	.3772	.3086	.4115	.4287	.583	.583	.0724
14	.3688	.3429	.4287	.4287	.5658	.4458	.0724
15	.3772	.3772	.4115	.4191	.5658	.4801	.1086
16	.2743	.3772	.5144	.4534	.5658	.5487	.1448
17	.3086	.4458	.583	.5992	.6478	.583	.1448
18	.362	.5228	.3086	.1629	.3547	.1886	.2172
19	.4854	.5601	.3772	.4525	.4294	.4115	.4108
20	.5601	.5601	.4115	.5973	.5041	.463	.5601
21	.5228	.5228	.3944	.543	.4854	.4115	.4854
22	.4854	.4854	.3772	.4668	.4481	.3772	.3982
23	.4854	.4108	.3772	.4481	.4108	.3429	.3982
24	.4525	.3982	.4108	.3601	.4525	.3982	.3086
Max	.7059	.6878	.6878	.5992	.6478	.6687	.6802
Min	.2743	.3086	.3086	.1629	.3429	.1886	.0724
Avg	.4423	.4583	.4380	.4491	.5057	.4772	.3139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 201 / BHAGGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.8596	.8954	.8238	1.0745	1.0745	.6089
2	1.0029	.8954	1.3253	.7522	1.1462	1.1104	.6626
3	1.182	.9671	1.3969	.7522	1.1641	1.1462	.7343
4	1.2715	1.0745	1.2178	.788	1.2178	1.2536	.788
5	1.2715	1.3969	1.3611	1.1104	1.2536	1.4685	.8596
6	1.3611	1.7909	1.7909	1.7193	1.4685	1.6834	.9671
7	1.3611	1.8983	1.7193	1.6476	1.576	1.6476	1.2178
8	1.6476	1.5043	1.3969	1.4685	1.3253	1.5043	1.6834
9	1.1462	1.2536	.9313	1.2894	1.0387	1.1462	1.9342
10	.788	.788	.5731	1.0745	1.3969	1.3611	.5895
11	.8954	.8596	1.0387			1.6118	.4298
12	.8238	.8954	.9313	1.1104	1.3611	1.7909	
13	.9671	.7522	.9671	1.1104	1.4327	1.7551	.4298
14	.8954	.7164	.8238	1.3611	1.4685	1.5402	.394
15	.8954	.5731	1.0566	1.2536	1.4327	1.5043	.394
16	.788	.6447	.9671	1.2536	1.5043	1.5565	.4298
17	.6089	.788	1.0745	.8954	1.6118	1.3969	.4656
18	.8954	.5731		.5373	.5373	.6089	
19	1.0745	1.182	1.3611	1.3611	.8059	1.182	1.1462
20	1.0745	1.1462	1.2178	1.3253	1.3969	1.1462	1.1104
21	1.0745	.9671	.9313	.788	1.3253	.8954	1.0387
22	.9671	.8954	.9671	.8954	1.2894	.8954	.9313
23	.8596	.8596	.8596	.8954	1.2178	.8954	.788
24	.8238	.8238	.8238	.8238	1.0029	1.0387	.5731
Max	1.6476	1.8983	1.7909	1.7193	1.6118	1.7909	1.9342
Min	.6089	.5731	.5731	.5373	.5373	.6089	.394
Avg	1.0238	1.0044	1.1143	1.0886	1.2630	1.3006	.8262



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 202 / GHAYGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2507	.3224	.2865	.2507	.3045	.3224	.5014
2	.2686	.3582	.3403	.2507	.3224	.3582	.5373
3	.2686	.3582	.4298	.2149	.3224	.3582	.591
4	.2507	.3224	.3224	.2507	.3582	.394	.6268
5	.2865	.3582	.3582	.3582	.3582	.3582	.6805
6	.4298	.4298	.4656	.4656	.4298	.4656	.8238
7	.4298	.5014	.5014	.5373	.6447	.7522	.8954
8	.5014	.6447	.7164	.6447	.8238	.7164	.7164
9	.5373	.6089	.6089	.5731	.8596	.7164	.4298
10	.2865	.2507	.2149	.2865	.1433	.3224	.3224
11	.1791	.1433	.1433	.1791	.1254	.2507	.3582
12	.1791	.1075	.1075	.2149	.2149	.2686	.394
13	.1791	.1433	.1075	.2507	.2149	.2686	.394
14	.1791	.1791	.1791	.1791	.2149	.2149	.4298
15	.2149	.1791		.2686	.2507	.2149	.4656
16	.2149	.1791		.2507	.2149	.2865	.4656
17	.2507	.2507		.2507	.2149	.2865	.5014
18	.394	.3224		.2865	.2865	.3224	.2865
19	.4656	.6089	.7522	.6805	.5731	.5014	.6805
20	.5731	.6089	.6447	.6805	.7164	.5373	.6089
21	.5373	.5373	.5731	.5731	.6447	.5373	.5373
22	.5014	.5014	.5731	.5014	.6089	.5373	.5014
23	.4298	.4656	.4656	.5014	.5731	.5373	.4656
24	.2149	.2865	.2507	.2507	.2865	.3224	.4656
Max	.5731	.6447	.7522	.6805	.8596	.7522	.8954
Min	.1791	.1075	.1075	.1791	.1254	.2149	.2865
Avg	.3343	.3612	.4021	.3708	.4044	.4104	.5283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 205 / ROTEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5731	.6268	.788	.7701	.7701	1.1104	.9671
2	.591	.6626	.9313	.7343	.8238	1.1462	1.0029
3	.6089	.6089	1.0566	.7522	.8417	1.182	1.0387
4	.6268	.5731	.8059	.8417	.9313	1.182	1.0924
5	.6447	.5194	.985	1.0029	1.0029	1.1999	1.2178
6	.7164	1.0387	.9671	1.1999	1.0029	1.3253	1.4685
7	.8238	1.0387	1.2536	1.5043	1.6476	1.3969	1.3969
8	1.2715	1.5223	1.8088	1.8983	1.6476	1.9342	1.2715
9	.9671	1.4685	1.3969	1.7372	2.2028	2.0595	.9134
10	.5373	.5014	.5014	.4835	.5552	.4477	1.379
11	.3224		.394	.3761	.5014	.4119	1.6118
12	.2865	.2507	.2865	.1254	.4119	.4477	1.6476
13	.2865	.2328	.3045	.3403	.4656	.4477	1.576
14	.2686	.2328	.394	.3582	.4477	.3582	1.3611
15	.2865	.2328	.3761	.3761	.394	.4477	1.4685
16	.2686	.2507	.3761	.3582	.4477	.5373	1.7551
17	.3761	.3761	.4835	1.5939	.394	.4477	1.6118
18	.6089	.5014	.5194	.8417	.8775	.7522	.4835
19	.6805	1.0745	1.1462	.5194	1.1104	1.2357	1.3432
20	1.1104	1.2178	1.2536	1.4327	1.6118	1.3611	1.2894
21	1.0566	1.0745	1.1104	1.0566	1.5939	1.2536	1.1999
22	.9313	1.0029	.9671	1.0566	1.5402	1.0566	1.0029
23	.8238	.9134	.8954	.8954	1.4685	.8954	.9313
24	.5552	.6089	.6984	.7522	.7522	1.0745	.9134
Max	1.2715	1.5223	1.8088	1.8983	2.2028	2.0595	1.7551
Min	.2686	.2328	.2865	.1254	.394	.3582	.4835
Avg	.6343	.7187	.8208	.8753	.9768	.9880	1.2477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 206 / SHELKEWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.6626	.8775	.7343	.8596	.8596	.6447
2	.788	.6805	.9313	.7164	.8954	.8954	.6805
3	.8596	.7164	1.4327	.7343	.9492	.9313	.7343
4	.9671	.8596	1.0208	.7701	1.0387	.9671	.7701
5	1.0387	1.1104	1.0924	1.0208	1.1462	1.1462	.7701
6	1.182	1.4148	1.3253	1.3432	1.3253	1.4506	.8238
7	1.1999	1.2894	1.3256	1.2715	1.3432	1.3253	1.0745
8	1.0745	1.1283	.197	1.0566	1.1283	1.1283	1.4864
9	.8775	.8417	.1433	.8238	.788	.3582	.8596
10	.5731	.6268	.1075	.7164	1.0566	.5731	.5194
11	.5552	.5731	.1075		1.2536	1.5043	.3403
12	.5373	.591	.1612	1.0387	1.5402	.1791	.4298
13		.3761	.788	1.0208	1.4327	1.3253	.394
14	.5373	.5014	.8059	1.0745	1.2178	1.4327	.4298
15	.4656	.5373	.8775	1.1104	1.4148	1.4148	.4119
16	.591	.6268	.985	1.1104	1.5402	1.4506	.5194
17	.4656	.3761	.7164	1.2536	1.576	1.1999	.6099
18	.6089	.3761		.0724	.591	.9492	.7522
19	.7522	.8954		.985	.8059	.9492	1.3073
20	1.0387	.9492	.5552	.4477	1.1104	1.1462	1.2894
21	.9671	.8775	.4656	1.0029	1.0566	.9313	1.2178
22	.8775	.8238	.7701	.9134	1.0387	.8775	.9313
23	.7522	.8059	.7522	.8417	.9671	.8596	.8596
24	.6984	.6268	.7701	.7343	.8059	.8238	.6089
Max	1.1999	1.4148	1.4327	1.3432	1.576	1.5043	1.4864
Min	.4656	.3761	.1075	.0724	.591	.1791	.3403
Avg	.7895	.7611	.7367	.9041	1.1201	1.0283	.7694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR (R) S/DN[402] BU 7218

Substation No/ Name :- 047021 / VAIJAPUR

Feeder No / Name : 403 / 33 KV VAIJAPUR URBAN

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7446	3.0807	2.8567	2.8567	3.0247	3.0807	3.1927
2	2.5766	2.8006	2.5434	2.8567	3.0247	3.0247	3.0807
3	2.4646	2.8006	3.1367	3.1927	3.3608	3.1367	3.0247
4	2.9687	2.8567	2.9504	2.8567	3.5848	3.2487	3.6408
5	3.6408	3.0247	3.4728	4.313	3.9769	3.4728	4.145
6	4.201	3.6969	3.4591	4.313	4.201	3.9769	4.5931
7	4.425	3.9769	4.0889	4.257	4.481	4.369	4.8171
8	3.9769	3.8649	4.257	4.537	4.425	4.5931	3.9209
9	3.9769	3.6969	3.9209	4.313	4.313	4.313	3.8649
10	3.4168	3.5288	3.4728	3.6408	4.0329	3.3048	3.4728
11	3.0247	1.7924	3.1367	3.5848	3.7529	3.0807	3.2487
12	2.6326	3.3608	2.9687	3.3048	3.5288	2.6886	3.1927
13	2.7446	3.0807	2.9127	3.1367	3.4168	2.8006	3.2487
14	2.6326	2.9687	2.6326	2.9687	3.2487	2.5766	3.3608
15	2.7446	3.1367	2.8567	2.6886	3.1367	2.9687	3.3608
16	1.1763	3.2487	3.0247	2.6886	3.0247	2.7446	
17	3.4728	1.9044	2.9687	3.4728	3.1367	3.4728	
18	3.6969	3.2556	3.1927	3.5288	3.3608	4.145	
19	4.8171	3.8089	4.425	4.0889	4.6491	4.6491	6.0494
20	4.369	3.6523	4.7611	4.145	4.8171	4.7051	5.3772
21	4.5931	4.145	4.425	4.145	4.369	4.257	4.7611
22	3.7529	3.8089	3.9769	4.145	4.0329	3.9769	4.257
23	3.3048	3.3608	3.5848	3.7529	3.6969	3.6408	3.8649
24	2.8006	3.0807	2.7978	3.0247	3.5288	3.1927	3.3608
Max	4.8171	4.145	4.7611	4.537	4.8171	4.7051	6.0494
Min	1.1763	1.7924	2.5434	2.6886	3.0247	2.5766	3.0247
Avg	3.3398	3.2472	3.4093	3.5755	3.7552	3.5592	3.8969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVLOOR

Feeder No / Name : 201 / shivoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982	.4382	.4344	.3761	.3982	.4525	.3601
2	.4344	.5249	.4344	.4075	.4481	.4525	.3944
3	.543	.543	.5068	.443	.5068	.5249	.4287
4	.6516		.5792	.6201	.5792	.724	
5	.7783	.8145	.7059	.7265	.7783	.8145	.6001
6	.9412	.9231	.905	.9036	1.0136	1.1222	.8059
7	.8869	.8145	1.0317	.9745	1.267	1.286	
8	.8869	.8869	.9774	.9568	1.251	1.448	.6687
9	.8145	.724	.8145	.9391	1.0679	1.2489	.4287
10	.3429	.3258	.2658	.2534	.3258	.4287	.8215
11	.2572	.2401	.2303	.2715	.2572	.3086	.7964
12	.2229	.2401	.2303	.2353	.2401		.7783
13	.2229	.2058	.2303	.1991	.2401		
14	.2229	.2058	.2481	.2172	.2401		
15	.2229	.2058	.2481	.2353	.2572	.2572	
16	.2401	.2572	.2126	.2353	.2572	.3258	
17		.2229	.2481	.2715	.2572	.2572	.6697
18	.4287	.4115	.3366	.3982	.3429		.5249
19	.6344	.6001	.5493	.5611	.583	.6859	.7602
20	.5316	.583	.4961	.543	.6687	.5487	.724
21	.4801	.463	.443	.5249	.6001	.5144	.6697
22	.4458	.4287	.4075	.4525	.5144	.4801	.543
23	.3772	.3944	.3721	.362	.4115	.4287	.4525
24	.3801	.3801	.3982	.3544	.3982	.4344	.3772
Max	.9412	.9231	1.0317	.9745	1.267	1.448	.8215
Min	.2229	.2058	.2126	.1991	.2401	.2572	.3601
Avg	.4932	.4710	.4711	.4776	.5377	.6372	.6002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 202 / sudamwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5144	.6516	.6379	.5973	.5658	.2353
2	.6154	.5144	.6859	.6201	.6154	.5658	.2353
3	.6516	.5144	.7202	.6556	.6335	.6001	.2715
4	.6878	.5487	.7716	.7087	.6335	.6859	.2715
5	.7783	.6001	.823	.7619	.6697	.8573	.2896
6	.8688	.6516	.823	.815	.6878	.9259	.3086
7	.6335	.4801	.6859	.7087	.7059	.7202	
8	.6335	.3086	.5658	.6024	.5611	.6344	1.0136
9	.4706	.2915	.4287	.443	.4163	.5487	.9955
10	.2534	.362	.3012	.5068	.5973	.3982	.3439
11		.3258	.4075	.5611	.6335	.724	.2715
12	.3982	.2743	.2835	.5792	.7421	.9231	.2715
13	.4163	.2896	.4252	.5792	.7964	.8145	.2715
14	.3982	.3077		.6335	.8688	.7421	
15	.3801	.2743	.6379	.6697	.8573	.6878	
16	.4525	.4525	.4961	.7602	.9088	.5973	.362
17	.3982	.4887	.5847	.5792	.9412	.2172	.2534
18	.3429	.3429	.3189	.2715	.3086		
19	.5487	.5658	.4961	.2715	.6516	.7716	.362
20	.5316	.6859	.6556	.3801	.703	.6344	.4344
21	.5316	.6859	.7265	.4525	.6859	.6859	.5792
22	.5316		.6733	.5788	.6859	.7202	.6516
23	.5487	.6173	.6379	.6335	.6516	.6859	.5973
24	.5792	.5316	.823	.6001	.5973	.6001	.1886
Max	.8688	.6859	.823	.815	.9412	.9259	1.0136
Min	.2534	.2743	.2835	.2715	.3086	.2172	.1886
Avg	.5317	.4621	.5923	.5838	.6729	.6655	.4104

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 203 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9412	1.0117	.8916	1.0277	.9412	.9945	.724
2	.905	.9945	.8573	.9568	.9231	.9602	.7202
3	.8869	.9945	.823	.9391	.8869	1.0117	.8145
4	.8869	1.0117	.8916	.9745	.8507	1.0288	.8688
5	.8869	1.0288	.9431	.9745	.6878	1.0117	.905
6	.9149	.9945	.9945	1.382	.8688	1.0288	.9945
7	.9149	1.0117		1.2757	1.0136	1.0117	
8		.8745		.8682	.6908	1.0117	1.3394
9	.6697	.6516		.691	.2534	.8745	1.3394
10	.7783	.6335	.2658	.5249	.4115	.6878	.4706
11	.7059	.4525	.3544	.5973	.543		.3077
12	.5792	.7059	.567	.5249	.724	.8869	
13	.6335		.6024	.5973	.8869	.7888	
14	.6335	.543	.6556	.6335	.905	.7602	
15	.6335	.905	.567	.6697	1.0136		
16	.7964	.8507	.6556	.9412	.9593	.7362	.362
17	.7964	.6516	.5493	.5792	.9412		.4344
18	1.086	.6687	.691	.543	.5144		.7964
19	1.0288	.9431	1.0985	1.1041	.9945		.7783
20	1.0117	1.0117	1.134	.9774	1.0288	.9431	.7964
21	1.0117	1.0288	1.2048	.8688	1.0288	.9945	.9412
22	1.0288	.9945	1.0454	.9593	.9945	.9945	1.0317
23	1.0288	.9945	1.0099	1.0317	1.0117	1.0117	.9412
24	.9412	1.0117	.9431	.9945	1.0136	.9431	.724
Max	1.086	1.0288	1.2048	1.382	1.0288	1.0288	1.3394
Min	.5792	.4525	.2658	.5249	.2534	.6878	.3077
Avg	.8565	.8682	.7974	.8598	.8370	.9305	.8047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 204 / NIMGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.4458	.5144	.5138	.5249	.4973	.181
2	.543	.5144	.6001	.6024	.543	.5144	.2172
3	.5792	.6001	.6516	.6379	.5792	.5144	.2058
4	.6154	.6859	.7202	.6733	.6154	.6001	.2058
5	.7282	.7202	.7716	.7619	.6516	.6516	.2715
6	.905	.8059	.8745	.8859	.6878	.7202	.3077
7	.8589	.6859	.583	.6556	.724	.703	
8	.6697	.5316	.3944	.567	.5973	.5658	.4887
9	.5068	.4115	.4115	.443	.4163	.4801	.4525
10	.2353	.181	.1417	.1086	.1417	.1991	.1629
11	.181	.181	.124	.1629	.1448	.1086	.1086
12	.1629	.1629	.0886	.1991	.2172	.1086	
13	.1448	.1267	.1063	.2353	.2353	.1715	
14	.1448	.12	.1949	.1991	.2353	.2172	
15	.1629	.1086	.1949	.181	.2715	.2172	
16	.1629	.1267	.2126	.2172	.2172	.2715	.1267
17	.1629	.1629	.1595	.2715	.2534		.1991
18	.463	.3086	.2303	.2172	.2058		.4163
19	.6344	.5658	.4961	.5975	.5487		.7059
20	.583	.703	.5316	.5792	.6173	.6173	.6697
21	.5487		.6201	.5973	.5487	.6173	.6154
22	.5316	.4287	.5493	.5611	.4801	.583	.5611
23	.4973	.4973	.4961	.543	.4973	.5487	.4887
24	.5068	.463	.4801	.4801	.5249	.4973	.181
Max	.905	.8059	.8745	.8859	.724	.7202	.7059
Min	.1448	.1086	.0886	.1086	.1417	.1086	.1086
Avg	.4598	.4147	.4228	.4538	.4366	.4478	.3456



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 206 / BANGLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1267	.1448	.1595	.1991	.181	.4287
2	.1629	.1267	.1629	.1772	.2172	.1991	.463
3	.181	.1448	.1629	.2126	.2534	.1991	.5144
4	.1991	.1448	.181	.2126	.2896	.2353	.6001
5	.2172		.181	.2303	.3258	.2715	.6859
6	.2427	.1448	.2103	.2658	.362	.2896	.7716
7	.2896	.1991	.3077	.2481	.3982	.4525	
8	.3801	.362	.5068	.4961	.5973	.4525	.4287
9	.4887	.3801	.5792	.3366	.4887	.5611	.3258
10	.2401	.2058	.2481	.1629	.2058	.2058	.362
11	.2401	.1715	.2303	.1991	.1715	.2058	.6878
12	.2058	.1715	.2658	.2172	.1715	.2058	.3982
13		.2058	.2303	.2353	.1715	.2572	.7059
14		.2229	.2303	.2353	.2058	.2915	
15		.2401	.2303	.2534	.2743	.2915	
16	.4801	.2743	.2835	.3077	.2572	.2915	.7964
17	.4801	.3944	.3012	.3439	.2572	.2058	.6697
18	.5316	.3601	.4075	.362	.3086		.362
19	.6001	.5144	.4961	.5792	.5316	.583	.6878
20	.5144	.6001	.5316	.5792	.6001	.6859	.6516
21	.4801	.5144	.5847	.5973	.5487	.6001	.6154
22	.4287	.4801	.5493	.5611	.5144	.5487	.543
23	.3944	.4287	.443	.4887	.4801	.4801	.5068
24	.1267	.1267	.2172	.1448	.1629	.1448	.463
Max	.6001	.6001	.5847	.5973	.6001	.6859	.7964
Min	.1267	.1267	.1448	.1448	.1629	.1448	.3258
Avg	.3338	.2843	.3202	.3169	.3330	.3408	.5556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOR

Feeder No / Name : 207 / Ex.BANGLA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1086	.1086	.0895	.1086	.0905	.0905
2	.1086	.1086	.1086	.0886	.1086	.0905	.0886
3	.0905	.1086	.1086	.0886		.0905	.0857
4	.0905	.1086	.0905	.0886	.1086	.0905	.0905
5	.0914	.1086	.0905	.0886	.1086	.0905	.0876
6	.0905	.0876	.0905	.0886	.1086	.0905	.1029
7	.1267	.1267	.1086	.1063	.1086	.0905	
8	.1086	.1086	.1086	.1063	.1086	.0905	.1086
9	.1267	.1267	.1267	.1063	.1086	.1086	.1267
10	.1267	.1086	.124	.1086	.1086	.1267	.1448
11	.1267	.0905	.124	.1086	.1029	.1267	.1086
12	.0905	.1267	.124	.1629	.1086	.1267	.1086
13	.1086	.1086	.0886	.1267	.1267	.1029	.1086
14	.1086	.0876	.0886	.1086	.1267	.1086	
15	.1086	.0905	.0886	.0905	.1086	.1086	
16	.1086	.0905	.0886	.1086	.0857	.1086	.1086
17	.0905	.1086	.0886	.0905	.1086	.1086	.0905
18	.0905	.0905	.1063	.1086	.0857		.0905
19	.0905	.0905	.1063	.1086	.0724	.1029	.0905
20	.1086	.1086	.1063	.1086	.0724	.1086	.0905
21	.1029	.1029	.1063	.112	.0686	.1029	.0905
22	.1086	.1086	.1063	.1086	.0905	.12	.0905
23	.1086	.1086	.1063	.1086	.1086	.12	.0905
24	.1086	.1086	.1086	.1086	.1086	.1086	.1086
Max	.1267	.1267	.1267	.1629	.1267	.1267	.1448
Min	.0905	.0876	.0886	.0886	.0686	.0905	.0857
Avg	.1054	.1051	.1043	.105	.1023	.1049	.1001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044011 / 33/11KV SHIVOOOR

Feeder No / Name : 208 / KORADGAON

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.181	.1578	.1063	.181	.1267	.3429
2	.1086	.181	.181	.1595	.2172	.1267	.3086
3	.1267	.181	.2103	.1949	.2534	.1629	.3429
4	.1267	.1991	.2172	.1772	.2896	.1629	.3772
5	.1448	.1991	.2279	.1949	.3258	.2172	.4287
6	.1448	.181	.2353	.2835	.4163	.2534	.5658
7	.2896	.2241	.3086	.3012	.5068	.4344	
8	.4344	.2353	.4344	.3189	.5973	.5611	.4287
9	.362	.2896	.362	.3544	.5068	.5068	.3086
10	.1029	.1029	.0886	.1086	.1372	.1372	.362
11	.1029	.0857	.0709	.1086	.12	.1029	.4344
12	.1029	.0857	.0177	.1086	.12	.1029	
13	.0686	.0686	.0177	.1267	.1372	.1029	
14	.1029	.0686	.0709	.1086	.1372	.1029	
15	.1372	.1029	.0709	.112	.1372	.1029	
16	.1372		.1063	.1267	.1715	.2058	.5068
17	.1715	.0857	.1417	.181	.1715		.4887
18	.3429	.2915	.2481	.2172	.2915		.2896
19	.4115	.4973	.443	.4887	.5144	.4458	.543
20	.4115		.4607	.4706	.4801	.4801	.4887
21	.3772		.443	.4525	.3429	.4287	.4163
22	.3429	.3429	.3721	.3982	.3086	.3772	.3982
23	.3429	.3086	.3189	.3439	.3086	.3429	.3801
24	.1086	.1448	.1448	.0905	.181	.1086	.3429
Max	.4344	.4973	.4607	.4887	.5973	.5611	.5658
Min	.0686	.0686	.0177	.0905	.12	.1029	.2896
Avg	.2129	.1932	.2229	.2306	.2855	.2542	.4081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 202 / KHANDALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.9335	.8453	.8764	.7545	.9335	.3048
2	.7167	.9335	.9088	.8002	.7922	.9335	.3475
3	.7167	.9335	.9922	.8954	.8488	1.0456	.431
4	.7545	1.0456	.9991	1.105	.9054	1.0829	.4923
5	1.1883	1.1203	1.0745	1.3443	.9431	1.1949	.6093
6	1.4712	1.1949	1.0631	1.643	1.3392	1.419	.7472
7	1.4146	1.1203	.9991	1.643	1.2637	1.307	.9659
8	1.1317	1.0082	.9134	1.531	1.094	1.1949	.9717
9	.811	.9335	.823	1.4377	.811	1.0456	1.0715
10	.3353	.5502	.6097	.7964	.6706	.7282	.9145
11	.4024	.4858	.7621	.905	.8718	.873	.7621
12	.3688	.535	.7621	.9412	1.0059	.8977	.8573
13	.3688	.4489	.7621	1.0136	1.0059	.9659	.8002
14	.503	.4923	.724	1.0136	1.0395	.8431	.7621
15	.503	.5944	.6859	1.0498	1.0395	.9065	
16	.503	.5144	.9145	1.0136	1.073	.9002	
17	.5365	.5573	.9526	1.0136	1.0364	.8398	.9808
18	.9335	.9259	1.2323	1.1317	.8589	.929	1.2193
19	1.2696	1.0867	1.307	1.226	1.1203	1.0117	1.4289
20	1.3817	1.1869	1.5242	1.1128	1.3443	1.1919	1.5813
21	1.307	1.0341	1.4289	.9431	1.1949	1.0288	1.5242
22	1.1203	.8817	1.2193	.8676	1.0456	.9156	1.3336
23	1.0456	.8059	1.086	.7922	.9335	.9991	1.0288
24	.7356	.9335	.8859	.9717	.7545	.8589	.506
Max	1.4712	1.1949	1.5242	1.643	1.3443	1.419	1.5813
Min	.3353	.4489	.6097	.7922	.6706	.7282	.3048
Avg	.8416	.8440	.9781	1.0862	.9894	1.0019	.8927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 203 / DAHEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547		.407	.4954	.5093	.4854	.125
2	.5658		.4784	.4954	.5281	.4854	.125
3	.5658		.5304	.5716	.5281	.4854	.1337
4	.5847		.6173	.6668	.6036	.5601	.1829
5	.6979		.7122	.8383	.6413	.6722	.2972
6	.8488		.8589	.8402	.8676	.8589	.3765
7	.9242		.6344	.7468	.7733	.7468	.4858
8	.6224		.4908	.6859	.6036	.6348	.6081
9	.547	.5601	.3772	.4763	.415	.4854	.8471
10	.2012	.2675	.2667	.4887	.3353	.3913	.1143
11	.3018	.3041	.4763	.543	.4024	.5068	.1524
12	.2683	.3567	.5144	.543	.57	.4633	.1524
13	.2683	.2858	.4572	.5611	.57	.4572	.1334
14	.2683	.2824	.4954	.5068	.57	.3858	.1143
15	.2683	.333	.6097	.4706	.57	.4458	
16	.3353	.3429	.6668	.4706	.57	.443	
17	.4024	.3909	.6668	.5068	.57	.5068	.2858
18	.1867	.3391	.6602	.5658	.3734	.3605	.4954
19	.3734	.6201	.6535	.6979	.5228	.4973	.6287
20	.6348	.6952	.7049	.6413	.6722	.5316	.6668
21	.5975	.5784	.6668	.6413	.5975	.6135	.724
22	.5601	.5316	.6097	.6036	.5975	.5087	.6859
23	.4854	.4973	.6097	.5658	.5601	.5083	.4191
24	.5281		.4135	.5716	.5658	.4854	.0914
Max	.9242	.6952	.8589	.8402	.8676	.8589	.8471
Min	.1867	.2675	.2667	.4706	.3353	.3605	.0914
Avg	.4826	.4257	.5658	.5914	.5632	.5217	.3566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 204 / Borsar

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.4481	.4961	.4572	.4904	.4854	.1265
2	.5847	.4481	.4641	.4191	.5093	.4854	.1204
3	.6224	.4481	.3429	.4954	.547	.4854	.1852
4	.6224	.4481	.6661	.6859	.6036	.5228	.2229
5	.6602	.6348	.6952	.8002	.6602	.5601	.3048
6	.9242	.7468	.8238	.9145	.9431	.8215	.333
7	.9431	.7842	.6516	.8215	.8299	.7842	.4012
8	.8676	.6348	.5304	.7621	.6979	.7468	.4572
9	.5847	.4481	.4207	.5716	.5093	.5601	.6081
10	.2683	.1783	.3048	.3982	.3353	.3567	.3048
11	.3353	.2107	.4191	.4887	.4359	.443	.3429
12	.3353	.2858	.4572	.4887	.4359	.5213	.2477
13	.3353	.2606	.4382	.4706	.4359	.423	.2667
14	.3353	.2675	.381	.4706	.4359	.3864	.3048
15	.3353	.2896	.381	.4706	.4359	.3269	
16	.3018	.2961	.4572	.4706	.503	.3429	
17	.3018	.3475	.4191	.4887	.503	.362	.381
18	.4481	.4801	.5716	.5658	.3734	.3944	.4954
19	.5601	.5087	.6478	.7733	.5601	.5138	.6097
20	.6722	.631	.743	.6979	.6348	.5935	.7621
21	.5601	.5087	.6859	.6036	.5975	.567	.6859
22	.5601	.5426	.5906	.5658	.5601	.4641	.5716
23	.4854	.5258	.5716	.5093	.4854	.4458	.4572
24	.547	.4854	.4458	.5144	.5093	.4854	.1875
Max	.9431	.7842	.8238	.9145	.9431	.8215	.7621
Min	.2683	.1783	.3048	.3982	.3353	.3269	.1204
Avg	.5307	.4525	.5252	.5793	.5430	.5032	.3808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 205 / parsoda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2347	.253	.3048	.3206	.3353	.5801
2	.3439	.2347	.2812	.3429	.3395	.3353	.6274
3	.362	.2683	.301	.3429	.3772	.4024	.663
4	.4163	.3353	.3475	.4191	.3801	.503	.7122
5	.3982	.4024	.4012	.5716	.4163	.6036	.8939
6	.5792	.4694	.543	.6097	.5792	.6706	1.0682
7	.5792	.57	.5647	.6979	.724	.7377	1.2403
8	.6516	.6706	.5921	1.0288	.8745	.8048	1.166
9	.724	.6706	.695	.9335	.9412	1.0059	.6344
10	.3734	.3429	.5335	.4338	.3734	.3258	.5716
11	.4108	.2984	.381	.5093	.4481	.3681	.5716
12	.4108	.3113	.381	.3961	.1494	.39	.4191
13	.4108	.2743	.3048	.3206	.1494	.3429	.5093
14	.3734	.3222	.381	.2829	.1494	.3155	.5335
15	.3734	.3429	.3429	.3772	.4481	.3258	
16	.4854	.3856	.381	.3772	.4481	.3647	
17	.5601	.3978	.381	.3772	.4481	.4557	.4191
18	.7468	.7202	.9526	.7922	.6722	.6274	.6478
19	.9709	.9816	1.094	1.1506	.9335	.8063	1.0288
20	1.1949	.8648	1.105	1.1317	1.1203	.8648	1.1431
21	1.0456	.8505	1.0479	.9431	.9335	.8413	1.105
22	.7468	.6952	.8002	.8676	.7468	.7202	.9907
23	.6722	.6173	.724	.7167	.7468	.6464	.7621
24	.3018	.2683	.2477	.2641	.3018	.3353	.6001
Max	1.1949	.9816	1.105	1.1506	1.1203	1.0059	1.2403
Min	.3018	.2347	.2477	.2641	.1494	.3155	.4191
Avg	.5607	.4804	.5432	.5913	.5426	.5470	.7676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044029 / 33/11KV PARSODA

Feeder No / Name : 206 / KHADI CENTER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2347	.2134	.4191	.4344	.2347	.431
2	.3258	.2683	.3125	.4191	.4706	.2347	.5487
3	.3258	.2683	.3913	.5335	.543	.2683	.5087
4	.362	.2683	.4458	.5716	.6516	.3353	.4801
5	.362	.3018	.543	.4954	.7964	.4024	.5304
6	.362	.3353	.6081	.4481	.9945	.8383	.6661
7	.543	.6706	.695	1.251	1.0631	1.6766	.5144
8	.543	1.0059	.9431	1.2323	1.6118	2.0119	.5609
9	.5792	.8383	1.0425	1.1203	1.7166	1.8442	.2035
10	.112	.1017	.1143	.1132	.1867	.1326	.4572
11	.112	.1311	.1143	.1509	.1867	.2035	.5335
12	.112	.1326	.1524	.1509	.2241	.1492	1.1203
13	.112	.1715	.1524	.1886	.2241	.1638	2.0538
14	.112	.1357	.1905	.2263	.2241	.2058	1.6804
15	.112	.1989	.1905	.2641	.2241	.2058	
16	.112	.1475	.2286	.2641	.2241	.2155	
17	.1494		.2286	.3018	.2614	.2374	1.9044
18	.2614	.2321	.4572	.5281	.3361	.3544	.2286
19	.3734	.4252	.4954	.6036	.4481	.4748	.3048
20	.5601	.5144	.6097	.6036	.5975	.5765	.5716
21	.5228	.431	.6097	.6036	.5975	.4641	.6859
22	.4481	.4748	.5716	.5658	.5601	.5144	.6287
23	.3734	.4207	.5716	.4904	.4854	.5138	.5716
24	.3018	.2347	.2667	.3772	.415	.2347	
Max	.5792	1.0059	1.0425	1.251	1.7166	2.0119	2.0538
Min	.112	.1017	.1143	.1132	.1867	.1326	.2035
Avg	.3116	.3454	.4228	.4968	.5615	.5205	.7231



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 201 / Babhulgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.4527	.5601	.5788	.5316	.5365
2	.6036		.4904	.6908	.5975	.5609	.5868
3	.7167		.547	.7842	.7095	.7164	.6203
4	.7577		.5658	.8962	.8779	.8682	.6097
5	1.0751		.6036	.9877	1.0751	.9774	.6859
6	1.1317		.7545	1.0608	1.2449	1.0974	.7316
7	1.0829		.9694	.8048	.9335	.9955	.6097
8	1.0374	1.0136	.7316	.6653	.811	.7973	.6249
9	.7167	.7442	.5658	.5415			.6401
10	.5312	.5376	.5658	.6706	.6081	.5312	.5788
11	.5761	.5487	.5658	.583		.7316	.2987
12			.5868	.547		.7468	.2829
13			.5533		.6325	.7926	.2641
14			.503	.5668	.6241	.8383	.2829
15	.583	.3429	.57	.6154	.6802		.3395
16	.5992	.6371	.6371	.6882	.7202	.7468	
17		.5365	.6706	.6154	.7611	.5792	.4108
18	.6733	.4527	.6348				.7023
19	.8417	.7167	.8775	.8962		.6602	1.0059
20	.8779	.8488	.9709	.9335	.8775	.8488	.8048
21	.7522	.7545	.7095	.8589	.8048	.7545	.6584
22	.6878	.6602	.5788	.7545	.7343	.6602	.5601
23	.6024	.5658	.4481	.6413	.6626	.6413	.4481
24	.5975	.5373	.4527	.4108	.567	.4908	.5144
Max	1.1317	1.0136	.9709	1.0608	1.2449	1.0974	1.0059
Min	.5312	.3429	.4481	.4108	.567	.4908	.2641
Avg	.7521	.6355	.6252	.7170	.7632	.7413	.5564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 202 / Rahegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3224	.1886	.3206	.3326	.298	.2058
2	.3772	.3544	.2263	.3772	.3696	.3403	.2572
3	.3772	.3544	.2829	.4527	.4481	.4252	.2743
4	.4108	.4119	.3018	.5281	.4481	.5068	.2915
5	.5228	.4607	.3018	.5975	.5601	.5792	.3258
6	.7922	.7059	.3206	.6535	.7842	.7865	.3601
7	.7468	.6805	.3584	.7095	.6089	.6335	.4458
8	.679	.6219	.3018	.5544	.5121	.5316	.4801
9	.4527	.4784	.2263	.4108	.3544	.4119	.4458
10	.3125	.3479	.2572	.3658	.427	.4586	.1886
11	.3479	.3601	.3155	.3795	.4481	.4801	.1905
12	.4049	.3429	.3772	.3841	.4858	.4458	.1524
13	.3521	.3429	.3429	.3681	.4428	.4115	.1509
14	.3163	.4287	.3086	.3887	.4001	.3772	
15	.3361	.4801	.3601		.4049	.503	
16	.4049	.4458	.4024	.25	.4321	.4973	
17	.3361	.3772	.4359	.3749	.4481	.463	.2614
18	.443	.2263	.3921	.2987	.2658		.4481
19	.5249	.3018	.5601	.5658	.5249		.5975
20	.5731	.3772	.5228	.5228	.5014	.3584	.6584
21	.4252	.3961	.5228	.4854	.4784	.3018	.5729
22	.4119	.3018	.4294	.4668	.4477	.2829	.4481
23	.3506	.2263	.3395	.3961	.3898	.2263	.3206
24	.3734	.3155	.1886	.2614	.3361	.2629	.1886
Max	.7922	.7059	.5601	.7095	.7842	.7865	.6584
Min	.3125	.2263	.1886	.25	.2658	.2263	.1509
Avg	.4437	.4025	.3443	.4397	.4521	.4355	.3459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 203 / Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1389	.2058	.1433	.1581	.1581	.2263
2	.1718	.1406	.2572	.1402	.1562	.1875	.2452
3	.1718	.1739	.2915	.1753	.1581	.1898	.2641
4	.1875	.176	.3429	.1715	.1898	.208	.3018
5	.1898	.1898	.4287	.2058	.1898	.208	.3018
6	.2056	.2105	.5144	.2347	.2105	.2267	.3584
7	.2214	.2401	.5144	.2012	.2429	.2561	.3961
8	.2401	.2591	.2263	.285	.2984	.3239	.3395
9	.25	.2949	.3086	.3277	.3563	.3725	.2263
10	.0914	.1075	.1132	.0934	.1433	.1417	.3155
11	.0905	.1132	.0754	.0747	.0886	.1132	.3086
12	.0709	.1132	.0754	.0754		.1132	.2804
13	.0701	.1132	.0762	.0754		.0943	.2572
14	.0716	.1132	.0762			.0943	.2572
15	.0886	.0943	.0943			.1132	.2915
16	.1063	.0943	.1132	.0934	.0895	.1132	
17		.0943	.1509	.0934	.0886	.1132	.3086
18	.1772	.2641	.1867	.1494	.1433	.2829	.1886
19	.2328	.2829	.2614	.2452	.2507	.3772	.2614
20	.2896	.3772	.3547	.3206	.3258	.3584	.3326
21	.2658	.3584	.2987	.2801	.2686	.3395	.2772
22	.2481	.3018	.2614	.2641	.2303	.2829	.2241
23	.208	.2263	.2263	.2195	.2303	.2263	.1886
24	.1389	.1562	.2058	.1791	.1543	.1562	.1886
Max	.2896	.3772	.5144	.3277	.3563	.3772	.3961
Min	.0701	.0943	.0754	.0747	.0886	.0943	.1886
Avg	.1713	.1931	.2358	.1840	.1987	.2104	.2756

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 204 / AMANSPURWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1406	.1423	.2058	.2454	.1875	.1852	.2263
2	.1423	.1562	.2401	.2804	.2315	.2214	.2263
3	.1562	.16	.2572	.3086	.2105	.25	.2452
4	.1875	.1898	.2915	.3772	.2401	.2846	.2452
5	.1898	.2267	.3258	.4144	.2915	.3239	.2641
6	.25	.2721	.3772	.4534	.3239	.3725	.2829
7	.3163	.3005	.4801	.4687	.3906	.4534	.3018
8	.4586	.4372	.57	.3963	.5693	.639	.2829
9	.4999	.4915	.5144	.2972	.6478	.6964	.2263
10	.1829	.2126	.1886	.1867		.1595	
11		.2263	.1509	.1509	.1595	.1698	.3155
12	.1433	.1886	.1132		.1387	.1509	.3429
13	.1052	.1886	.1143		.1063	.1698	.3086
14	.1063	.1886	.1143		.1075	.1886	.2743
15		.2263	.1143	.1307	.1267	.1509	.3086
16		.2263	.1132	.132	.1417	.1698	
17	.1772	.2263	.1509	.1494	.1417	.1886	.3772
18	.2328	.2829	.1867	.1886	.1791	.2829	.2829
19	.3258	.3584	.3361	.3395	.2835	.3772	.3361
20	.3045	.415	.4108	.3772	.3658	.3584	.4066
21	.2835	.3018	.3734	.3734	.3439	.3018	.3174
22	.2481	.2263	.3206	.3395	.3045	.2829	.2641
23	.2103	.1886	.2641	.2614	.2454	.2641	.2263
24	.1235	.1718	.2058	.2103	.1852	.1875	.1886
Max	.4999	.4915	.57	.4687	.6478	.6964	.4066
Min	.1052	.1423	.1132	.1307	.1063	.1509	.1886
Avg	.2278	.2502	.2675	.2896	.2575	.2845	.2841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 205 / dhondalgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2454	.1886	.3018	.3326	.3155	.2058
2	.2829	.2865	.2263	.3584	.3395	.3582	.2572
3	.3326	.2896	.2829	.4294	.415	.4525	.2915
4	.3734	.333	.2829	.4938	.5228	.5373	.2915
5	.4715	.4119	.3018	.5487	.5601	.6335	.3258
6	.7922	.7865	.3206	.6036	.8299	.7865	.3772
7	.6224	.6154	.3395	.6584	.695	.6447	.4287
8	.5093	.5014	.2829	.4854	.5228	.543	.4024
9	.2987	.3012	.2263	.3734	.3544	.4075	.4115
10	.1898	.3005	.2743	.3921	.25	.2688	.1886
11	.2214	.3429	.2743	.2846	.3201	.3258	.1905
12		.3086	.3086	.253		.3086	.1524
13		.3086	.2683	.2753	.3321	.2915	.1509
14	.2881	.3258	.2743	.2294	.2881	.3086	.1509
15		.4458	.3086		.3239	.4115	.1886
16	.2753	.4115	.3353		.3605	.4115	
17	.2214	.3086	.3688	.3201	.3887	.3772	.2614
18		.1886	.2987	.2263	.197	.2641	.3734
19	.4525	.2641	.3921	.439	.4477	.3584	.5228
20	.4656	.3584	.5041	.4715	.4755	.3395	.6099
21	.3721	.3395	.4481	.4108	.4298	.3018	.499
22	.362	.2641	.3921	.3772	.3721	.2641	.3921
23	.2835	.2263	.3206	.3018	.298	.2452	.3018
24	.2772	.2481	.1886	.2641	.2801	.2481	.1715
Max	.7922	.7865	.5041	.6584	.8299	.7865	.6099
Min	.1898	.1886	.1886	.2263	.197	.2452	.1509
Avg	.3687	.3505	.3087	.3863	.4059	.3918	.3107

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044043 / 33/11KV DHONDALGAON

Feeder No / Name : 206 / sanjarpurwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1235	.2058	.1612	.125	.1389	.1886
2	.0926	.125	.2401	.1753	.125	.1423	.2263
3	.1094	.1423	.2743	.2103	.125	.1562	.2263
4	.1094	.144	.3258	.2058	.1423	.1781	.2641
5	.125	.16	.3772	.2572	.16	.176	.2829
6	.1265	.16	.4801	.3185	.1619	.1943	.3018
7	.216	.2429	.4862	.285	.3437	.3277	.415
8	.2688	.2721	.2263	.3932	.5468	.4696	.3584
9	.4218	.426	.4359	.4915	.5376	.5735	.2263
10	.0747	.0886	.1132	.0754	.0709	.0701	.3772
11	.0716	.0943	.0754	.056	.0701	.1132	.3429
12	.0526	.0943	.0754	.056	.0716	.1132	.2915
13	.0537	.0943	.0762	.0566	.0537	.0943	.2743
14	.0709	.0943	.0762	.0566	.0537	.0943	.2743
15	.0709	.0943	.0953	.056	.0537	.0943	.3086
16	.0876	.0943	.1132	.0554	.0537	.0943	
17	.1075	.0943	.1132	.0943	.0709	.1132	.3429
18	.1433	.2641	.1494	.0943	.0895	.2263	.2241
19	.1772	.3584	.2614	.2743	.2715	.3584	.2987
20	.2715	.3584	.3547	.3361	.3045	.3772	.3511
21	.2507	.3395	.2987	.3018	.2896	.3584	.2987
22	.2328	.3018	.2427	.2801	.2686	.3395	.2427
23	.1928	.2263	.2075	.2641	.2481	.2263	.1886
24	.0772	.1562	.2058	.1612	.1235	.1562	.1886
Max	.4218	.426	.4862	.4915	.5468	.5735	.415
Min	.0526	.0886	.0754	.0554	.0537	.0701	.1886
Avg	.1457	.1896	.2296	.1965	.1817	.2161	.2823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 201 / LONI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.631	.5959	.7712	.9114	.8063	.5609	.4382
2	.5784	.5784	.7011	.8764	.7362	.5784	.4382
3	.4908	.6135	.6661	.8589	.7011	.5258	.4733
4	.5609	.6135	.5959	.929	.6661	.5434	.4557
5	.631	.6836	.7186	1.0517	.8939	.5959	.5083
6	.6836	.7362	1.4198	1.3146	1.6301	.6836	.6661
7	.8589	.8939	1.2971	1.2269	1.3672	.7362	
8	.8063	.7186	.9465	.9465	1.0517	.6135	.8238
9	.7011			.7712	.8764	.5258	.7537
10	.3681	.4207	.3681	.4557	.5434	.4557	.4382
11	.4207	.4031	.3681	.3856	.5083	.5083	.3856
12		.3155	.2629		.4908	.5083	.3506
13	.4382	.3856	.3155	.4207	.5609	.4733	.333
14	.4031	.3681	.333	.4908	.5258	.4557	.3856
15	.3856	.3681	.3681	.5083		.4557	
16	.4382	.3856	.4382	.5959		.4207	.4207
17	.4733	.3506	.4557	.5434	.5609		.4733
18	.5609	.8413	.6485	.7186	.631		.5959
19	.7712	1.1744	1.1043	1.0517	.7712	.7537	.8413
20	.8413	1.1218	1.2269	1.3847	.8413	.7011	.9465
21	.8063	1.0692	1.1218	1.2269	.8238	.6836	.8764
22	.7186	1.0517	1.0341	1.1043	.7537	.631	.7537
23	.7011	.9465	.929	.9114	.6836	.631	.7186
24	.7362	.6661	.8238	.8413	.8413	.6135	.4382
Max	.8589	1.1744	1.4198	1.3847	1.6301	.7537	.9465
Min	.3681	.3155	.2629	.3856	.4908	.4207	.333
Avg	.6089	.6653	.7354	.8490	.7848	.5752	.5689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 202 / WAKLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.333	.2629	.2454	.4031	.3155	.298
2	.3155	.3506	.2629	.2629	.3856	.298	.3506
3	.333	.3506	.2454	.2629	.3506	.3155	.3506
4	.333	.3681	.2804	.2804	.3506	.3506	.3856
5	.3681	.3856	.3681	.3155	.4207	.3681	.4031
6	.3856	.4207	.4908	.3856	.5258	.3681	.5083
7	.4207	.4557	.5258	.4908	.4207	.4031	
8	.4706	.4031	.333	.333	.3506	.4207	.8413
9		.3506	.2629	.3155	.2629		.8939
10		.3681	.5609	.3856	.5083	.4207	
11	.4207	.3856	.5258		.5258	.6485	.2804
12	.4908	.4031	.5083	.4557	.5959	.6836	.2804
13	.4557	.4557	.5609	.5258	.6485	.5959	.2454
14	.4207	.4908	.5258	.6135	.631	.5258	.2804
15	.3681	.5083	.5434	.6661	.6661	.5258	
16	.4557	.5258	.6135	.6661	.6485	.5258	.3155
17	.5083	.5609	.6135	.7362	.6836		.3681
18	.3506		.2804		.3506		.4557
19	.3681	.5083	.5434	.4207	.4207	.4207	.5258
20	.4031	.5609	.4733	.4557	.4557	.4031	.5784
21	.4031	.3681	.4031	.3506	.4031	.3506	.4908
22	.3681	.298	.3506	.3155	.3681	.333	.3681
23	.3506	.2629	.3155	.298	.333	.298	.3155
24	.3681	.3506	.2454	.2804	.2804	.298	.3155
Max	.5083	.5609	.6135	.7362	.6836	.6836	.8939
Min	.3155	.2629	.2454	.2454	.2629	.298	.2454
Avg	.3959	.4115	.4207	.4119	.4579	.4223	.4215



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 203 / Anchalgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5258	.5609	.5258	.4908	.5434	.4908	.3506
2	.4557	.5258	.4908	.4733	.5083	.4557	.333
3	.4557	.5083	.4733	.4733	.4733	.4207	.333
4	.4908	.4557	.4557	.4908	.4382	.4382	.3681
5	.5258	.5434	.5609	.5959	.7011	.6836	.4031
6	.5434	.6661	1.0166	.8238	1.0517		.4557
7		.8413	.9114	.964	.9465	.6661	
8		.6135	.631	.7712	.6661		.5258
9		.4733		.6135	.5083	.7011	.4557
10		.3155	.4207	.2804	.4031		.3506
11		.3506	.4382	.333	.4031	.4031	.298
12	.4382	.333	.333	.4733	.4382	.4207	.298
13	.3681	.3506	.4031	.4207	.4207	.3856	.3155
14	.3506	.4382	.2804	.3856	.4557	.4031	.3155
15	.3155	.4557	.3155	.4382		.3506	
16	.3681	.4382	.3681	.4908		.1578	.333
17	.4207	.4382	.4207	.3681	.5258		.3681
18	.631	.4557	.4207	.4207	.5083		.5258
19	.7888	.8063	.8238	.7362	.6661	.8063	.7712
20	.8063	.7712	.7712	.7888	.8764	.7011	.8063
21	.7712	.7186	.7011	.7186	.7362	.6485	.7186
22	.7011	.6836	.631	.6485	.631	.5784	.6485
23	.6485	.5959	.5609	.5959	.5784	.5434	.5258
24	.5609	.6135	.5434	.4908	.5609	.5258	.333
Max	.8063	.8413	1.0166	.964	1.0517	.8063	.8063
Min	.3155	.3155	.2804	.2804	.4031	.1578	.298
Avg	.5351	.5397	.5434	.5536	.5928	.5148	.4470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 204 / Mauli Ginning

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	02-SEP-17
HR	Load (MW)
6	.0526
Max	.0526
Min	.0526
Avg	.0526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 205 / Bhadli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.2629	.1578	.2629	.3155	.333	.4557
2	.333	.298	.1578	.2629	.3506	.3506	.4207
3	.3506	.298	.1753	.2454	.3506	.4207	.3506
4	.3506	.333	.1753	.2804	.3681	.4382	.3681
5	.4207	.3681	.1928	.3155	.3681	.5258	.3856
6	.4382	.4031	.1928	.4207	.3681	.5784	.4207
7	.4908	.4382	.1928	.5258	.5784	.7712	
8	.4557	.4908	.1052	.7362	.7011	.8764	.4908
9	.4207	.5083	.0876	.7537		.6661	.3506
10	.3506	.3506	.0876	.2804	.0351	.333	.4908
11		.2804	.0876	.0876	.0876	.298	.7712
12	.2804	.2804	.1928	.0526	.2454	.2804	.8063
13	.2804	.298	.3681	.0351	.2279	.298	.8589
14	.2629	.2804	.1753	.0351	.2629	.298	.9114
15	.298	.2454	.1227	.2804		.333	
16	.298	.2629	.1402	.3155		.3506	.8238
17	.3155	.2804	.1402	.3155	.2454		.8063
18	.4031	.3506	.1753	.2454	.333		.4031
19	.4557	.4908	.3155	.3155	.4207	.4207	.4557
20	.4908	.5258	.3506	.4207	.5784	.631	.5784
21	.5258	.4908	.2804	.4207	.5609	.5784	.5258
22	.5083	.4557	.3155	.3681	.5258	.5258	.5258
23	.4557	.4031	.2804	.3506	.4382	.4908	.5083
24	.3155	.2804	.1753	.2279	.3155	.298	.4733
Max	.5258	.5258	.3681	.7537	.7011	.8764	.9114
Min	.2629	.2454	.0876	.0351	.0351	.2804	.3506
Avg	.3849	.3615	.1935	.3148	.3656	.4589	.5537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044048 / 33/11 LONI

Feeder No / Name : 206 / 11 kv parala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.1753	.1928	.1578	.6485	
2	.1753	.1753	.1578	.1928	.1402	.631	
3	.1928	.1928	.2103	.1753	.1402	.631	
4	.1753	.1753	.2103	.1928	.1928	.6661	
5	.2103	.2103	.1753	.2103	.1928	.7712	
6	.2103	.2103	.1753	.1753	.2103	.8413	
7	.2279	.2279	.1578	.1578		.8238	
8	.2279	.2103	.1753	.1402	.1402	.8413	
9		.1928	.1402	.1227	.1227	.7362	
10							.7186
11							.6836
12							.7362
13							.7888
14							.7712
16							.8063
17							.8063
24	.1928	.1578	.1928	.1753	.1402	.7186	
Max	.2279	.2279	.2103	.2103	.2103	.8413	.8063
Min	.1753	.1578	.1402	.1227	.1227	.631	.6836
Avg	.1987	.1928	.1770	.1735	.1597	.7309	.7587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 201 / 11 KV GARAJ

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2858	.2858	.2987	.2987	.2372	.181
2	.2829	.2858	.2858	.2987	.2987	.1581	.1772
3	.3772	.2858	.381	.3361	.3361	.1638	.1991
4	.4715	.381	.381	.3734	.4108	.2486	.2279
5	.5658	.4763	.4763	.4668	.4668	.2515	.2658
6	.5658	.4763	.5716	.5975	.6535	.3315	.298
7	.6602	.5716	.5716	.7655	.6908	.4049	.3045
8	.5658	.4763	.6668	.5415	.5601	.5668	.2572
9	.4715	.4763	.5716	.4668	.4108	.5335	.2515
10	.3048	.381	.3429	.3506		.2829	.2614
11	.4763	.381	.3441	.3429	.4287	.2054	.2667
12	.4763	.3429	.3311	.4001	.5001	.1867	.2858
13	.4763	.381	.3121	.4515	.5001	.1867	.2667
14	.381	.4001	.3121	.4607	.5001	.1867	.1905
15	.4191		.3506	.4108	.5001	.2054	.1905
16	.4191	.4191	.3963	.4607	.5001	.2241	.2096
17		.4191	.3704	.4515	.5001	.2054	.2096
18	.5716	.381	.2427	.3361	.2829	.2614	.2858
19	.5716	.4191	.5228	.5281	.5658	.3734	.381
20	.3772	.381	.5847	.4668	.6602	.4108	.381
21	***	.381	.4527	.4294	.5658	.3174	.2858
22	.3429	.3429	.3734	.3734	.3772	.2801	.381
23	.381	.3429	.3174	.3174	.2829	.2801	.2858
24	.2829	.2858	.1905	.2987	.2987	.2429	.2172
Max	38.4469	.5716	.6668	.7655	.6908	.5668	.381
Min	.2829	.2858	.1905	.2987	.2829	.1581	.1772
Avg	2.0944	.3901	.4015	.4260	.4604	.2811	.2609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 202 / 11 KV MANOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5716	.5716	.5975	.5601	.3391	.3801
2	.5658	.5601	.5716	.5975	.5601	.3506	.3982
3	.7545	.5716	.5906	.6535	.6535	.3544	.3898
4	.9431	.7621	.6097	.6722	.7468	.443	.4382
5	1.1317	.7621	.5716	.7468	.8589	.443	.5138
6		.9526	.6668	.8402	.9335	.6135	.6024
7	.7545	.9526	.9526	1.1016	.9709	.6935	.6984
8	.5658	.8573	.9526	.8215	.9149		.7888
9	.8488	.8573		.7282	.7095	.8192	.7209
10	.3239	.4763	.5716	.3658		.4715	.4108
11	.5144	.4763	.426	.439	.6859	.3734	
12	.5144	.4763	.6171	.5001	.7621	.3361	.3429
13	.5716	.5335	.5647	.5268	.7621	.3361	.3239
14	.5144	.5716	.5498	.5053	.7621	.3174	.3429
15	.5716	.5716	.5639	.4401	.7621	.3361	.3429
16	.5716	.5906	.5639	.5201	.6859	.3547	.381
17		.5906	.5401	.4816	.6859	.5041	.381
18	.9907	.6668	.5041	.4294	.3772	.5601	.5716
19	.9907	.7621	.8775	.9997	.9335	.6535	.6668
20	.743	.8764	1.1016	.8402	1.0374	.8402	.6668
21	.7621	.5716	.8402	.7655	.8488	.7282	.5716
22	.7811	.6413	.7468	.6535	.7545		.5716
23	.7621	.6668	.6348	.5788	.5658	.5788	.5716
24	.5658	.5716	.5716	.5975	.5601	.3429	.3258
Max	1.1317	.9526	1.1016	1.1016	1.0374	.8402	.7888
Min	.3239	.4763	.426	.3658	.3772	.3174	.3239
Avg	.6958	.6621	.6592	.6418	.7431	.4904	.4957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044071 / 33/11 KV GARAJ

Feeder No / Name : 203 / 11 KV POKHARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1905	.1905	.2172	.2629	.4715	.5601
2	.0905	.1905	.1905	.1772	.2658	.4715	.5601
3	.1829	.1905	.1905	.1753	.3155	.5658	.6535
4	.1829	.2858	.2858	.2835	.3814	.7545	.7468
5	.1829	.381	.381	.3814	.4681	.9431	.9709
6	.2715	.4763	.4763	.5434	.6001	1.1317	1.1576
7	.3582	.381	.5716	.8059	.8328	1.0374	1.4003
8	.3544	.381	.7621	.7975	.8764	.8488	.7282
9		.381	.6287	.9015	1.0322	.8488	.5601
10	.3772	.0953				.4915	.4049
11	.1905	.1143			.0943	.6081	.6668
12	.1905	.0191	.2241	.1867		.679	.5716
13	.1905	.0189	.2054	.2427		.7562	.5716
14	.0381	.0191	.2241	.2614	.0943	.7621	.7621
15	.0953	.0191	.1867	.2241	.0943	.8223	.8573
16	.0953	.0953	.1867	.2614	.0943		.9145
17		.0953		.2801	.0943	.4801	.9145
18	1.1812	.6859		.5415	.1886		.6668
19	1.1812	.8573	1.0269	1.1317	.5601	.7095	.8573
20	.8488	.9526	1.1949	.9335	1.0374	1.0269	.7621
21	.8002	.7621	.9335	.8402	.8488	.8029	.7621
22	.8002	.3361	.8402	.7842	.5658	.6722	.724
23	.8192	.381	.7095	.7468	.5658	.5975	.0762
24	.1772	.1905	.1905	.1991	.2534	.4715	.5601
Max	1.1812	.9526	1.1949	1.1317	1.0374	1.1317	1.4003
Min	.0381	.0189	.1867	.1753	.0943	.4715	.0762
Avg	.3995	.3125	.4800	.4962	.4536	.7251	.7254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 201 / biloni SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.2743	.2058	.3715	.2743	.6722	.5601
2	.2103	.3048	.2058	.4458	.2743	.7373	.5601
3	.2103	.3125	.2401	.4877	.4115	.7373	.5975
4	.2454	.3201	.3429	.5624	.4748	.7459	.6348
5	.2804	.3201	.3429	.7202	.6104	.7956	.6722
6	.2743	.3932	.407	.9503	.6706	.8951	.8215
7	.3932	.6081	.9922	1.1736	1.3108	1.7368	.7468
8	.5898	.8749	1.0883	1.5181	1.6461	2.0317	.6413
9	.6706	.8535	1.1728	1.6324	1.6156	1.8785	.4527
10	.1132	.1132	.2263	.112	.1886	.1494	1.1888
11	.1509	.1509	.2075	.1494	.1886	.1867	1.8122
12	.1132	.0754	.1886	.2614	.2641	.2241	1.8122
13	.1132	.1509	.2263	.2987	.2641	.2614	1.0669
14	.1509	.1509	.2614	.2241	.2614	.2614	1.2193
15	.1886	.1509	.2987	.3361	.4108	.2987	1.4661
16	.2263	.2263	.3361	.3361	.4108	.3361	
17	.2641	.3361	.3326	.3361	.4854	.3361	1.7284
18	.415	.4527	.3772	.3772	.5281	.4854	.2957
19	.5658	.6036	.5281	.6036	.679	.6722	.5601
20	.5658	.6413	.679	.7167	.7922	.7282	.7545
21	.5658	.5658	.5658	.5658	.7167	.6722	.7545
22	.5658	.4904	.5281	.5281	.6413	.6348	.7167
23	.5658	.4904	.4904	.4527	.5281	.5601	.679
24	.2263	.1894	.1581	.3102	.2683	.3963	.5601
Max	.6706	.8749	1.1728	1.6324	1.6461	2.0317	1.8122
Min	.1132	.0754	.1581	.112	.1886	.1494	.2957
Avg	.3281	.3771	.4334	.5613	.5798	.6847	.8827



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 202 / jarul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.7167	.6413	.6722	.6722	.7545	.2427
2	.6036	.7167	.6413	.6722	.6722	.7545	.2427
3	.6413	.7545	.6413	.6722	.6722	.7545	.2774
4	.6413	.7545	.6413	.6722	.6722	.7545	.2774
5	.7167	.7545	.679	.7095	.6908	.7922	.3121
6	.7356	.8299	.6979	.7545	.7282	.8299	.4694
7	.6099	.679	.6036	.7545	.6161	.6036	.6036
8	.5041	.5601	.5658	.6036	.5041	.547	.8796
9	.4108	.4294	.3361	.4481	.4108	.2241	1.0059
10	.3525	.3201	.4599	.5182	.6626	.6097	.1867
11	.4268	.5144		.7926	.6676	.8333	.2241
12	.4329	.5487	.6287	.679	.719	.787	.2614
13	.4134	.4938	.6573	.7621	.6401	.8025	.2926
14	.5544	.4801	.6859	.6944	.6767	.7316	.3292
15	.3658	.3102	.6908	.7011	.6485	.7716	.4024
16	.4464	.5357	.7049	.7716	.743	.8078	
17	.4934	.5075	.695	.8179	.6954	.8688	.439
18	.2896	.2534	.1387	.3174	.2012	.3361	.5914
19	.5975	.5975	.394	.6161	.6283	.6348	.6653
20	.6283	.6653	.6653	.7095	.5415	.6722	.6908
21	.6838	.6653	.6838	.7095	.6908	.7468	.7282
22	.7023	.6838	.6653	.7655	.7282	.7842	.6908
23	.6722	.5658	.6722	.7468	.7356	.7468	.6722
24	.6413	.6908	.6584	.6722	.7468	.7167	.2401
Max	.7356	.8299	.7049	.8179	.7468	.8688	1.0059
Min	.2896	.2534	.1387	.3174	.2012	.2241	.1867
Avg	.5486	.5845	.6021	.6764	.6402	.7027	.4663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-AUG-17 and 04-SEP-17

AURANGABAD ZONE[067]

AURANGABAD CIRCLE[670]

KANNAD DIVISION[226]

VAIJAPUR-II S/DN.[743] BU 4743

Substation No/ Name :- 044088 / 33/11 KV BHAYGAON S/Sn

Feeder No / Name : 203 / lakh khandala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	29-AUG-17	30-AUG-17	31-AUG-17	01-SEP-17	02-SEP-17	03-SEP-17	04-SEP-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3772	.3772	.4527	.4527	.415	.2058
2	.3772	.3772	.3772	.4527	.4527	.415	.2058
3	.3772	.3961	.3772	.4527	.4527	.415	.2058
4	.3772	.415	.3772	.4527	.4527	.415	.2035
5	.415	.415	.3772	.4527	.4904	.415	.2347
6	.4527	.415	.415	.415	.5281	.4527	.426
7	.3772	.3772	.3395	.415	.4527	.3395	.8642
8	.3018	.2641	.3018	.3395	.3018	.2641	1.1248
9	.1886	.2263		.2263	.2263	.2263	.679
10	.3948	.3185		.6836	.7754	.6097	.0373
11	.3517	.4633		.873	.7895	.7716	.037
12	.4664	.5213	.751	.8535	.7613	.8642	.0377
13	.4801	.5487	.7788	.8642	.7682	.8025	.0377
14	.3734	.5285	.8067	.8951	.7819	.7621	.0377
15	.3829	.2972	.823	.7011	.7529	.8951	.0754
16	.3418	.5921	.8505	.8025	.8573	1.0059	
17	.4001	.743	.9602	.8642	.9682	.9145	.0754
18	.1132	.0754		.0373	.0377	.0373	.2263
19	.3395	.3018	.3395	.2614	.2641	.2987	.3018
20	.3772	.3772	.415	.415	.3772	.4108	.3395
21	.3772	.3772	.4527	.4527	.3772	.4108	.3395
22	.415	.415	.4527	.4527	.415	.4108	.3395
23	.3772	.3772	.4527	.4527	.415	.3361	.3018
24	.3772	.3772	.415	.4527	.4527	.415	.208
Max	.4801	.743	.9602	.8951	.9682	1.0059	1.1248
Min	.1132	.0754	.3018	.0373	.0377	.0373	.037
Avg	.3672	.3990	.5220	.5300	.5252	.5126	.2845