

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.5525	.4572			.6478
2	.6859	.5716	.5144	.4954			.5716
3	.6097	.5335	.5335	.4572			.5716
4	.6097	.5716	.4954				.4954
5	.5716	.5335	.5525	.5335			.5335
6	.5716	.5716	.5716	.5335			.5716
7	.5716	.6097	.5906	.5716		.6097	.6097
8	.8002	.8002	.4001	.8002		.6668	.7621
9	.9145	1.0669	.5335	1.0669	.9526	.9907	.9145
10	1.105	1.1431	.5716	1.0669	1.0288	.9907	1.0669
11	1.2003	1.2384	.6097	1.105	1.105	.9907	1.1431
12	1.1622	1.2193	.6287	1.1431	1.2574	1.0288	1.2384
13	.7049	1.2193	.6097	1.1812	1.3146		1.3146
14	1.0098	1.2193	.5716	1.2193	1.2193	1.0669	1.3146
15	1.1812	1.2955	.5335	1.2384	1.2193	1.1812	1.3146
16	1.2384	1.2193	.4572	1.2003	1.2193	1.105	1.2193
17	1.2193	1.2955	.5716		.9526	1.1431	1.1431
18		1.0669	.5906		.9526	1.2574	1.0669
19		.9907	.5716		.8764	.9145	1.0098
20		1.0098	.5335		.8192	.8764	.9907
21		.9526	.4954		.8573	.8764	.9145
22		.9526	.4763		.8383	.7621	.8383
23		.7621	.4763		.8192	.743	.7621
24	.7621	.724	.6478	.4763		.7621	.743
Max	1.2384	1.2955	.6478	1.2384	1.3146	1.2574	1.3146
Min	.5716	.5335	.4001	.4572	.8192	.6097	.4954
Avg	.8669	.9240	.5454	.8466	1.0288	.9391	.9066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV N. DATTA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954		.362	.3048			.381
2	.4572		.362	.3048			.381
3	.4191		.3429	.3048			.3429
4	.381		.362	.3048			.3429
5	.381		.381	.3048			.3429
6	.3429		.381	.3048			.381
7	.3429		.4001	.3048		.381	.381
8	.381		.3048	.381		.362	.381
9	.4572	.4572	.362	.5335	.5335	.362	.4572
10	.724	.4954	.362	.5335	.6859	.4572	.6097
11	.7621	.5335	.3429	.6097	.7621	.5716	.6859
12	.8002	.5716	.3429	.6097	.7621	.6859	.7621
13	.6859	.6097	.3429	.6859	.6097	.724	.9145
14	.6859	.7621	.3048	.7621	.7621	.7621	.9145
15	.8383	.7621	.3048	.8383	.8002	.9145	.9145
16	.9145	.8002	.3429	.7621	.8383	.8002	.9145
17	.724	.8383	.381		.7621	.724	.8383
18		.7621	.381		.7621	.7621	.6859
19		.6097	.381		.7621	.6859	.6097
20		.5335	.381		.4954	.5716	.6097
21		.5144	.381		.4572	.5335	.5716
22		.5144	.381		.381	.5335	.5335
23		.4572	.381		.362	.5335	.5335
24	.5335		.381	.3429		.362	.4572
Max	.9145	.8383	.4001	.8383	.8383	.9145	.9145
Min	.3429	.4572	.3048	.3048	.362	.362	.3429
Avg	.5737	.6148	.3604	.4819	.6491	.5959	.5811

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954		.4382	.5335			.4572
2	.4954		.4382	.4954			.381
3	.4954		.4572	.4572			.381
4	.4572		.4382	.4572			.381
5	.4572		.4572	.4572			.381
6	.4572		.5144	.5335			.4572
7	.4572		.5335	.6097		.5906	.5335
8	.9145		.4954	.7621		.5525	.5716
9	.9907	.4954	.4954	.8383	.6097	1.0669	.6097
10	1.2003	.6859	.4572	.8383	.724	1.1812	.6859
11	1.4289	1.2193	.4191	.9145	.8002	1.3717	.8383
12	1.2384	1.1431	.4191	.9145	.9907	1.6766	1.0669
13	.9526	.9907	.4191	.9907	.8383	1.5242	1.105
14	.9145	1.1431		.9907		1.5623	1.1431
15	1.105	1.2955	.381	1.0669	1.2955	1.5242	1.1431
16	1.2193	1.2193	.381	1.0669	1.3717	1.4861	1.0669
17	1.1431	.9907	.381		1.3717	1.1812	.9907
18		.9526	.4572		1.1431	.9145	.9145
19		.724	.4572		.8573	.6097	.6859
20		.5906	.4954		.6287	.5716	.6859
21		.5335	.5335		.5716	.5335	.6097
22		.5144	.5335		.5144	.4954	.5335
23		.5144	.5335		.4572	.4572	.4572
24	.5335		.4572	.5335		.4763	.4572
Max	1.4289	1.2955	.5335	1.0669	1.3717	1.6766	1.1431
Min	.4572	.4954	.381	.4572	.4572	.4572	.381
Avg	.8309	.8675	.4606	.7329	.8696	.9875	.6890

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905		.1334	.1524			.1524
2	.1524		.1524	.1524			.1524
3	.1524		.1334	.1524			.1524
4	.1905		.1334	.1715			.1524
5	.2096		.1524	.1905			.1905
6	.2286		.2096	.2286			.2286
7	.2286		.2286	.3048		.2477	.2667
8	.2667		.2477	.2858		.2667	.2667
9	.3048	.3048	.2667	.2667	.2858	.2858	.2858
10	.2667	.2667	.2667	.2667	.2667	.3048	.2477
11	.2477	.1905	.2477	.2667	.2667		.2286
12	.2286	.2286	.2477	.2477	.2667	.2667	.2286
13	.2096	.2477	.2286	.2667	.2286	.2286	.2286
14	.1715	.2667	.2096	.2858	.2286	.2477	.2286
15	.1905	.2667	.1905	.2667	.1905	.3048	.2477
16	.2286	.2667	.1715	.2477	.1905	.2667	.2477
17	.2667	.2667	.2286		.2286	.1715	.2286
18		.2667	.2667		.2477	.1524	.2667
19		.2858	.2667		.2667	.2667	.2667
20		.2477	.2286		.2477	.2667	.2667
21		.2286	.1905		.2477	.2286	.2477
22		.1715	.1905		.1905	.1905	.2477
23		.1334	.1524		.1905	.1524	.2286
24	.1905		.1334	.1524		.1715	.1524
Max	.3048	.3048	.2667	.3048	.2858	.3048	.2858
Min	.1524	.1334	.1334	.1524	.1905	.1524	.1524
Avg	.2180	.2426	.2032	.2297	.2362	.2365	.2254

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.381	.4572			.381
2	.4572		.362	.4572			.381
3	.4191		.381	.4572			.381
4	.381		.381	.4572			.381
5	.381		.362	.4572			.381
6	.4572		.4191	.4572			.4191
7	.4572		.4382	.4572		.4763	.4572
8	.4572		.4191	.4572		.5144	.4572
9	.6097	.4191	.4572	.4572	.4954	.6097	.4572
10	.8383	.4572	.4572	.5335	.6478	.724	.6859
11	1.0098	.9145	.4572	.5335	.8002	.8002	.7621
12	.9526	.9145	.4572	.6097	.9145	.9145	.8383
13	.7621	.9145	.381	.6097	.9145	.8002	.9145
14	.7621	.9145	.381	.7621	.9526	.8764	.9145
15	.8383	.9145	.4572	.7621	.9907	.9145	.9145
16	.8573	.9526	.4572	.9145	1.0669	.9145	.9145
17	.9526	1.0669	.4572		.9145	.9145	.8383
18		.9145	.4572		.8002	1.0669	.7621
19		.5716	.4572		.6859	.7621	.6859
20		.5335	.4572		.6097	.6478	.6859
21		.4954	.4572		.4954	.4572	.6097
22		.4763	.4572		.4382	.4572	.6097
23		.4382	.4572		.4191	.4572	.5716
24	.4572		.4001	.4572		.4191	.4572
Max	1.0098	1.0669	.4572	.9145	1.0669	1.0669	.9145
Min	.381	.4191	.362	.4572	.4191	.4191	.381
Avg	.6393	.7265	.4270	.5469	.7430	.7070	.6192

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957		1.5623	1.6004			1.6194
2	1.9052		1.5813	1.5813			1.6194
3	1.8671		1.5432	1.5813			1.6194
4	1.8671			1.5242			1.7147
5	1.848		1.6194	1.6004			1.7147
6	1.829		1.6575	1.829			1.8671
7	1.829		1.7528	2.1719		2.1529	2.0576
8	1.9814		2.1338	2.1719		2.191	2.21
9	2.0957	2.0957	2.0576	2.0576	2.191	2.0957	2.2862
10	2.1148	2.1338	2.0195	2.21	2.1338	.2286	2.2862
11	2.1338	2.1338	1.8671	2.3243	2.1529	2.2481	2.3243
12	2.191	2.1719	1.8099	2.2862	2.1529	2.2862	2.3243
13	2.2481	2.1338	1.8099	2.2481	2.1338	2.3243	2.3243
14	2.0005	2.0957	1.7909	2.21	2.0957	2.2481	2.3243
15	2.0005	2.0386	1.7718	2.1338	2.0767	2.3243	2.2862
16	2.0195	2.0576	1.7718	2.0957	2.0005	2.0576	2.5149
17	2.1529	2.2672	2.2291		2.3434	2.4387	2.9721
18		2.6482	2.4006		2.6863	2.8959	3.1055
19		3.0102	2.553		3.0293	2.9721	3.1245
20		2.7054	2.2862		2.8006	2.8197	3.0483
21		2.3624	2.0576		2.4577	2.6673	2.8197
22		2.0386	1.9433		2.0957	2.2862	2.5149
23		1.6575	1.6194		1.9052	1.848	2.4768
24	2.2862		1.6194	1.6194		1.829	1.7718
Max	2.2862	3.0102	2.553	2.3243	3.0293	2.9721	3.1245
Min	1.829	1.6575	1.5432	1.5242	1.9052	.2286	1.6194
Avg	2.0259	2.2367	1.8895	1.9556	2.2837	2.2174	2.2886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038		.0056	.0038		.0038	.0055
2	.0038		.0056	.0038		.0038	.0056
3	.0038		.0055	.0038		.0038	.0056
4	.0038		.0056	.0075		.0038	.0056
5	.0057		.0056	.0038		.0038	.0056
6	.0057		.0055	.0057		.0075	.0056
7	.0075		.0074	.0075		.0093	.0075
8	.0093	.6348	.0092	.0075	.7468	.0092	.0092
9	.7762		.0092	.0074			.0092
10	.0093		.5359		.0074		
11	.0075	.4805	.5304	.5121	.0074	.5853	
12	.0075		.5121		.0055		
13	.0075		.4938	.4207	.0055	.5975	.4572
14	.0075		.4755		.0055		
15	.0074	.4024	.4755	.3475	.0055	.6024	.5792
16	.0056		.4572		.0055		
17		.0056	.0036		.0055	.0075	.5792
18	.7602	.0075	.0073	.724	.0074		.7865
19	.7577	.0075	.0074	.6468	.0091		.7316
20	.6653	.0075	.0056	.5975	.0075		.6653
21	.5228	.0075	.0056	.5544	.0056		
22	.4854	.0075	.0056	.4854	.0056		
23	.3961	.0056	.0038	.3921	.0038		.0057
24	.0038		.0056	.0038		.0038	.0056
Max	.7762	.6348	.5359	.724	.7468	.6024	.7865
Min	.0038	.0056	.0036	.0038	.0038	.0038	.0055
Avg	.1941	.1566	.1493	.2492	.0556	.1417	.2276

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0113		.0112	.0113		.0113	
2	.0113		.0111	.0113		.0113	
3	.0113		.0112	.0113		.0113	
4	.0113		.0112	.0113		.0113	
5	.0113		.0112	.0113		.0113	
6	.0132		.0131	.0132		.0149	
7	.0168		.0129	.0149		.0168	
8	.0168	1.4415	.0185	.0187	1.46	.0185	.0185
9	1.5524		.0185	.0165			.0185
10	.0187		1.3352		.0185		
11	.0187	1.4083	1.3169	1.3352	.0166	1.3937	
12	.0187		1.2803		.0148		
13	.0185			1.2127	.0166	1.0791	1.2437
14	.0185		1.2437		.0166		
15	.0185	1.1157	1.2071	1.0534	.0166	1.1584	1.1888
16	.0168		1.1706		.0166		
17		.0166	.0146		.0146	.0168	1.2936
18	1.6078	.0203	.0166	1.6461	.0185		1.7193
19	1.6078	.0222	.0183	1.6827	.0201		1.7002
20	1.5524	.0222	.0166	1.5708	.0183		1.6078
21	1.423	.0203	.0168	1.4415	.0166		
22	1.2936	.0166	.0149	1.2936	.0148		
23	1.0164	.0168	.0112	1.0534	.0129	.0168	.0131
24	.0113		.0112	.0113		.0132	.0112
Max	1.6078	1.4415	1.3352	1.6827	1.46	1.3937	1.7193
Min	.0113	.0166	.0111	.0113	.0129	.0113	.0112
Avg	.4477	.4101	.3388	.6537	.1128	.2703	.8815

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0036		.0053	.0034		.0036	
2	.0036		.0051	.0035		.0036	
3	.0036		.0053	.0035		.0036	
4	.0036		.0051	.0035		.0036	
5	.0036		.0053	.0034		.0051	
6	.0036		.007	.0035		.0054	
7	.0054		.007	.0072		.0089	
8	.0072	.3155	.0088	.007	.373	.0086	.0088
9	.3641		.0105	.0084			.0088
10	.0105		.3978		.0105		
11	.0105	.3812	.3856	.4641	.0131	.3932	
12	.0105		.4024		.0105		
13	.0105		.3561	.4049	.0123	.3277	.3932
14	.0123		.3391		.0123		
15	.0123	.4096	.2984	.3887	.0123	.3361	.3441
16	.0105		.2743		.0105		
17		.0105	.0084		.0081	.0105	.3239
18	.3086	.0105	.0067	.3887	.0083		.3481
19	.2947	.0105	.0068	.3018	.0083		.2713
20	.2743	.0088	.0051	.2374	.0067		.2058
21	.2058	.0088	.0051	.2347	.0051		
22	.1734	.007	.0034	.2204	.0069		
23	.1372	.007	.0049	.2155	.0067	.007	.0035
24	.005		.0053	.0037		.0053	.0053
Max	.3641	.4096	.4024	.4641	.373	.3932	.3932
Min	.0036	.007	.0034	.0034	.0051	.0036	.0035
Avg	.0815	.1169	.1066	.1528	.0336	.0802	.1913

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 201 / 11 KV Vivekanand Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.6516			.583	
2	.5487	.5487			.5487	
3	.5144	.5487			.5487	
4	.5144	.5487			.5487	
5	.6173	.583			.5487	
6	.6516	.6173			.6859	
7	.823	.823			.8573	
8	.9259	.823			.8916	
9	.8916		.8573		.8573	.8916
10	.8573		.8573		.7545	.823
11			.823		.6859	.7545
12			.7202		.6173	.6516
13			.6859		.583	.6516
14			.6173		.5487	.6173
15			.5144		.583	.6173
16			.5487		.5487	.5144
17	.7545			.5487		
18	.8573			.8916		
19	.8916			.9945		
20	.9259			.9259		
21	.8573			.8573		
22	.7888			.7545		
23	.7545			.7202		
24	.5658	.6859		.6401	.6859	.583
Max	.9259	.823	.8573	.9945	.8916	.8916
Min	.5144	.5487	.5144	.5487	.5487	.5144
Avg	.7392	.6478	.7030	.7916	.6516	.6783

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 203 / 11 KV Gandhi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6859			.6859	
2	.6516	.6173			.583	
3	.6516	.6173			.583	
4	.6687	.6173			.583	
5	.7202	.6173			.583	
6	.7202	.6859			.7545	
7	.8745	.823			.7888	
8	.9259	.9259			.8916	
9			.9259		.9259	1.0288
10			.9602		1.0288	1.1317
11			1.0288		1.2689	1.3032
12			1.1317		1.3375	1.5089
13			1.0631		1.3375	1.5089
14			1.0631		1.3375	1.4403
15			1.0288		1.3717	1.3717
16			.9945		1.406	1.5432
17	1.6118			1.4403		
18	1.8176			1.7147		
19	1.7661			1.8176		
20	1.0974			1.7147		
21	1.2346			1.5261		
22	.9602			1.0631		
23	.8916			.823		
24	.6859	.8573		.6859	.7545	.703
Max	1.8176	.9259	1.1317	1.8176	1.406	1.5432
Min	.6516	.6173	.9259	.6859	.583	.703
Avg	.9977	.7164	1.0245	1.3482	.9542	1.2822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743			.2743	
2	.2743	.2401			.2058	
3	.2743	.2401			.2058	
4	.3086	.2401			.2058	
5	.3086	.2401			.2058	
6	.3258	.2743			.2743	
7	.3772	.3086			.3772	
8	.3944	.3772			.4115	
9			.4458		.4458	.5144
10			.4801		.5144	.5487
11			.583		.6859	.6859
12			.6687		.7888	.8573
13			.6516		.823	.8573
14			.6859		.8573	.8916
15			.7202		.8573	.8916
16			.7202		.8573	.8573
17	.8573			.7888		
18	1.0974			1.0631		
19	1.1317			1.2003		
20	.8916			1.166		
21	.8916			.7545		
22	.4801			.4458		
23	.4458			.3429		
24	.2743	.3429		.2572	.3086	.2915
Max	1.1317	.3772	.7202	1.2003	.8573	.8916
Min	.2743	.2401	.4458	.2572	.2058	.2915
Avg	.5380	.2820	.6194	.7523	.4882	.7106

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 205 / 11 KV Hattenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.4458			.4458	
2	.4115	.4115			.4115	
3	.4115	.4115			.4115	
4	.4287	.4115			.4115	
5	.4801	.4115			.4115	
6	.4801	.4458			.4801	
7	.5487	.5144			.583	
8	.6001	.6173			.6859	
9			.6173		.6516	.6859
10			.6173		.6173	.6173
11			.583		.583	.6173
12			.583		.5487	.583
13			.6173		.5487	.583
14			.6516		.5144	.5487
15			.6859		.5144	.5144
16			.6859		.5487	.5487
17	.6001			.5144		
18	.7202			.6173		
19	.7202			.6516		
20	.6859			.6859		
21	.6878			.6516		
22	.6687			.5487		
23	.583			.4801		
24	.463	.5144		.4287	.4801	.4973
Max	.7202	.6173	.6859	.6859	.6859	.6859
Min	.4115	.4115	.583	.4287	.4115	.4973
Avg	.5595	.4649	.6302	.5723	.5205	.5773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3944	.4458			.4458	
2	.3772	.3772			.4115	
3	.3772	.3772			.4115	
4	.4115	.3772			.4115	
5	.4115	.3772			.4115	
6	.4458	.4115			.5487	
7	.583	.7202			.583	
8	.6173	.7545			.6859	
9			.6516		.6516	.7545
10			.6859		.583	.6173
11			.6516		.5144	.6173
12			.583		.4458	.583
13			.5487		.4458	.5144
14			.4801		.4458	.4458
15			.4458		.4458	.4115
16			.4458		.3429	.4458
17	.3944			.4115		
18	.6516			.6859		
19	.6516			.7202		
20	.6516			.7202		
21	.6173			.6516		
22	.5487			.5487		
23	.5144			.5144		
24	.3944	.4801		.4801	.4801	.4287
Max	.6516	.7545	.6859	.7202	.6859	.7545
Min	.3772	.3772	.4458	.4115	.3429	.4115
Avg	.5026	.4801	.5616	.5916	.4862	.5354

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 157004 / 132 KV S/S MIDC

Feeder No / Name : 201 / 11 KV MAROTI FERTOCHM
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	07-DEC-17
HR	Load (MW)
23	.0034
Max	.0034
Min	.0034
Avg	.0034

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4763	.3429	.3429	.362	.3395	.4191
2	.4191	.5335	.3239	.3391	.3561	.3429	.2515
3	.4191	.6097	.3429	.407	.4239	.4115	.285
4	.5658	.6602	.5335	.4409	.4527	.5144	.3561
5	.6413	.6979	.7545	.4694		.6443	.4458
6	.7545	.7545	.8676	.503	.5533	.763	.6516
7	.8299	.7922	1.0562	.6036	.5868	.8139	.8718
8		.8488	1.0185	.7042	.663	.8478	1.0111
9	.811	.7922	.7922	.6874	.8192	.8192	.9012
10	.6036	.5281	.7167	.5847	.4715	.5658	.6413
11	.6001	.6539	.6443	.4527	.4904	.415	.4338
12	.7461	.7042	.7209	.3772	.3961	.3772	.415
13	.6539	.6796	.6874	.3961	.415	.3772	
14	.78	.6962	.57	.3772	.3772	.3395	
15	.7712	.6882	.6874	.3395	.3584	.3772	.4715
16	.788	.6882	.6464	.3395	.3961	.415	.5093
17	.7293	.7127	.6464	.3584	.4527	.4527	1.1316
18	.7537	.7209	.6371	.5281	.6602	.6224	.6224
19	.5847	.811	.679	.5847	.7356	.8299	.7922
20	.5658	.7167	.6036	.679	.6979	.7545	.7167
21	.547	.5847	.5658	.6036	.6224	.6224	.6413
22	.5093	.4954	.4715	.5658	.5281	.5093	.6036
23	.4527	.4191	.4191	.5335	.3961	.4763	.4954
24	.4763	.415	.3429	.3429	.5144	.3395	.4382
Max	.8299	.8488	1.0562	.7042	.8192	.8478	1.1316
Min	.4191	.415	.3239	.3391	.3561	.3395	.2515
Avg	.6287	.6533	.6279	.4817	.5100	.5404	.5957

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 203 / 11KV NANDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2477	.2096	.1905	.2286		.2286
2	.4409	.407	.5144	.2286	.3429	.2452	.2477
3	.5087	.4862	.5487	.2641	.4001	.2829	.2477
4	.57	.5868	.6443	.3772	.4382	.3395	.2858
5	.6539	.6874	.6952	.415	.4527	.415	.3772
6	.8048	.9221	.8383	.4715	.5093	.5281	.5093
7	.9448	.9945	1.1603	.547	.547	.5658	.5093
8		1.1768	1.1961	.5093	.4715	.5281	.4904
9	1.0562	.9831	1.166	.3772	.3395	.3772	.3772
10	.2829	.2263	.3206	.2829	.2452	.3018	.2641
11	.2075	.2075	.2263	.8648	.9892	.9665	.8916
12	.2075	.1698	.2263	.9892	1.0608	1.0059	1.0004
13	.1509	.1509	.1886	1.0562	1.0442	1.1065	1.1904
14	.1698	.1132	.1698	1.0898	1.0277	1.1603	1.1233
15	.1698	.1132	.1698	1.0395	1.0059	.9945	.9116
16	.1886	.0943	.3018	1.1271	1.0059	.9175	1.0277
17	.3772	.1698	.3206	1.1105	1.0562	1.1142	1.0111
18	.415	.3206	.3395	.9831	1.0562	1.1603	1.0395
19	.4527	.415	.3961	.4338	.3961	.3961	.3772
20	.3961	.3961	.3772	.3961	.3772	.3772	.3772
21	.3584	.3206	.3395	.3395	.3584	.3395	.3395
22	.3206	.3018	.2829	.3018	.3206	.3018	.3018
23	.3018	.2667	.2667	.3048	.2452	.2667	.2667
24	.2286	.2641	.2286	.2286	.2667	.2286	.2477
Max	1.0562	1.1768	1.1961	1.1271	1.0608	1.1603	1.1904
Min	.1509	.0943	.1698	.1905	.2286	.2286	.2286
Avg	.4094	.4176	.4636	.5803	.5911	.6052	.5685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 204 / 11KV NAGZARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.1715	.1905	.1905	.1509	.2096
2	.1715	.2096	.1715	.7122	.763	.8139	.7545
3	.1524	.2096	.1905	.8139	.8987	.9156	.8048
4	.2075	.2452	.2096	.8478	1.0059	1.0059	.8619
5	.2263	.2829	.2452	.9389	1.1568	1.1401	1.0059
6	.2641	.3018	.2829	1.0059	1.3748	1.2574	1.2239
7	.2452	.3206	.3206	1.3748	1.6095	1.6575	1.6385
8		.2641	.2263	1.5089	1.6575	1.5912	1.749
9	.2075	.2075	.2263	1.5083	1.6518	1.6057	1.749
10	.1886	.2263	.2263		.1886	.1509	.1509
11	1.4083	1.3916	1.5769	.1698	.1509	.1886	.1698
12	1.1233	1.7436	1.8945	.132	.1132	.1886	
13	1.8679	1.8233	1.8107	.1698	.132	.1509	
14	1.7859	1.9062	1.7604	.132	.1132	.1509	.1886
15	1.7859	1.9334	1.7939	.132	.132	.1509	.1698
16	1.8187		1.6907	.1132	.132	.1509	.132
17	1.4752	1.6194	1.6078	.132	.1509	.1509	.1886
18	1.3763	1.4586	1.5249	.2452	.1886	.2641	.3018
19	.3206	.3395	.2829	.2829	.2829	.3584	.3395
20	.3018	.2829	.2641	.3018	.3772	.3395	.3206
21	.2829	.2641	.2263	.2829	.2641	.3206	.2829
22	.2641	.2452	.2075	.2641	.2263	.2829	.2641
23	.2641	.2286	.2286	.2477	.1886	.2667	.2667
24	.2286	.2452	.1905	.1905	.2286	.1886	.2286
Max	1.8679	1.9334	1.8945	1.5089	1.6575	1.6575	1.749
Min	.1524	.2075	.1715	.1132	.1132	.1509	.132
Avg	.7033	.6947	.7221	.5086	.5491	.5601	.5910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 205 / Rajeshwari Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018	.0018	.0018	.0018
2	.0018	.0018	.0018	.0018	.0018	.0018	.0018
3	.0018	.0018	.0018	.0018	.0018	.0018	.0018
4	.0018	.0018	.0018	.0018	.0018	.0018	.0018
5	.0018	.0018	.0018	.0018	.0018	.0018	.0018
6	.0018	.0018	.0018	.0018	.0018	.0018	.0018
7	.0018	.0018	.0018	.0018	.0018	.0018	.0018
8		.0018	.0018	.0018	.0018	.0018	.0018
9	.0018	.0018	.0018		.0018	.0018	.0018
10	.0018	.0018	.0018	.0018	.0018	.0018	.0018
11	.0018	.0018	.0018	.0018	.0018	.0018	.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13	.0018	.0018	.0018	.0018	.0018	.0018	.0018
14	.0018	.0018	.0018	.0018	.0018	.0018	.0018
15	.0018	.0018	.0018	.0018	.0018	.0018	.0018
16	.0018	.0018	.0018	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	.0018
18	.0018	.0018	.0018	.0018	.0018	.0018	.0018
19	.0018	.0018	.0018	.0018	.0018	.0018	.0018
20	.0018	.0018	.0018	.0018	.0018	.0018	.0018
21	.0018	.0018	.0018	.0018	.0018	.0018	.0018
22	.0018	.0018	.0018	.0018	.0018	.0018	.0018
23	.0018	.0018	.0018	.0018	.0018	.0018	.0018
24	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Max	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0018	.0018	.0018	.0018	.0018	.0018	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 206 / harangul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381	.2858	.2858	.3048	.2858	.3048
2	.5144	.4382	.2858	.5087	.2543	.6001	.4475
3	.5906	.5335	.381	.5765	.4917	.7122	.4973
4	.7621	.6097	.5525	.6706	.6371	.8139	.5765
5	.8573	.7621	.7811	.8048	.6706	.9326	.6859
6	.9335	.9145	1.0479	.8551	1.0898	1.1736	.9088
7	1.105	1.086	1.1431	1.2407	1.4083	1.3757	1.2517
8		1.0288	1.1431	1.3413	1.4752	1.5083	1.2689
9	1.0288	.8764	.9526	1.21	1.3904	1.3245	1.153
10	.9335		.724	.6287	.7049	.6668	.6478
11	1.1904	1.1869	1.1361	.4572	.4191	.5335	.4382
12	1.2929	1.4251	1.3077	.3048	.3048	.5335	.3048
13	1.4255	1.326	1.4922	.2858	.2858	.381	.2667
14	1.4089	1.2431	1.3748	.2286	.2477	.2667	.2667
15	1.3592	1.326	1.4083	.2667	.3048	.3239	.2667
16	1.3094	1.3599	1.3923	.2667	.2858	.362	
17	1.1934	1.3757	1.3413	.381	.4001	.381	.5335
18	.6062	1.3077	1.2742	.6287	.6478	.6287	.7049
19	.7621	.8002	.7811	.6097	.743	.724	.7621
20	.6859	.6859	.5716	.5906	.6097	.6859	.6859
21	.4954	.5335	.4191	.4954	.5716	.6287	.5716
22	.4191	.4382	.3429	.4572	.4191	.4191	.4382
23	.381	.2858	.3239	.4382	.3018	.362	.381
24	.4191	.3429	.2858	.3048	.381	.3048	.3048
Max	1.4255	1.4251	1.4922	1.3413	1.4752	1.5083	1.2689
Min	.381	.2858	.2858	.2286	.2477	.2667	.2667
Avg	.8761	.8812	.8645	.5766	.5979	.6637	.5942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
2	.0857	
8	.3601	.3429
Max	.3601	.3429
Min	.0857	.3429
Avg	.2229	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
2	.1715	
8	.4458	.4115
Max	.4458	.4115
Min	.1715	.4115
Avg	.3087	.4115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 203 / 11KV BHADGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
2	.9774	
8	1.8861	1.9719
Max	1.8861	1.9719
Min	.9774	1.9719
Avg	1.4318	1.9719

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2543	.2401	.3018	.2572	.2641	.2743
2	.3395	.2374	.2401	.6379	.9945	.8749	.9945
3	.415	.2374	.2401	.9945	1.1145	1.1561	1.1145
4	.4527	.2374	.2743	.9503	1.2346	1.2654	1.2346
5	.5281	.4239	.3429	1.1797	1.3717	1.406	1.5261
6	.6602	.6104	.583	1.3441	1.4632	1.4632	1.6975
7	.7545	.6952	.7202	1.7939	2.1262	1.7375	2.0233
8	.7545	.6783	.3772	2.079	2.1262	1.9509	2.0405
9	.6001	.6219	.5426	1.989	1.8519		1.9372
10	.4801		.4748	.3429	.4481		.4527
11	1.9033	1.8107	1.6956	.2915	.2641		.2829
12		1.9281		.2401	.2641		.2452
13	2.2462	1.9662	2.2043	.1886	.1886		.2263
14	2.0576	1.8343	2.1534	.2401	.1509		
15	1.749	1.8976	2.0687		.2263		
16	1.8861	1.9608	2.1534	.1886	.2263		
17	1.8176	2.0576	1.9662	.2401	.3018	.3258	.3395
18	1.7318	1.9376	1.9334	.3506	.415	.4287	.5281
19	.5487	.5487	.6348	.5487	.6413	.5316	.6036
20	.4973	.4973	.5601	.4973	.4527	.5144	.5658
21	.4287	.4287	.415	.4115	.4904	.4458	.4904
22		.3258	.3395	.3258	.415	.3601	.4338
23		.2915	.3206	.2915	.3395	.3086	.3772
24	.2829		.2743	.3018	.2743	.2641	.2915
Max	2.2462	2.0576	2.2043	2.079	2.1262	1.9509	2.0405
Min	.2829	.2374	.2401	.1886	.1509	.2641	.2263
Avg	.9722	.9764	.9024	.6839	.7349	.8311	.8419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / PTS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0339	.0343	.0377	.0343	.0377	.0343
2	.0377	.0339	.0343	.0377		.0377	.0343
3	.0377	.0339	.0343	.0373	.0343	.0377	.0343
4	.0377	.0339	.0343	.0373	.0343	.0377	.0343
5	.0377	.0339	.0343	.0373	.0343	.0377	.0343
6	.0377	.0339	.0343	.0366	.0343	.0377	.0343
7	.0377	.0339	.0343	.0377	.0343	.0377	.0343
8	.0366	.0339	.0343	.0377	.0343	.0377	.0343
9	.0343	.0373	.0339	.0343	.0377		.0377
10	.0343	.0373	.0339	.0343	.0377		.0377
11	.0343	.0373	.0343	.0343	.0377		.0377
12	.0343	.0373		.0343	.0377		.0377
13	.0343	.0377	.0339	.0343	.0377		.0377
14	.0343	.0377	.0373	.0343	.0377		.0377
15	.0343	.0377	.0339	.0343	.0377		.0377
16	.0343	.0377	.0339	.0343	.0373		.0377
17	.0343	.0343	.0366	.0343	.0377	.0343	.0377
18	.0343	.0343	.0373	.0343	.0377	.0343	.0377
19	.0343	.0343	.0373		.0377	.0343	.0377
20	.0343	.0343	.0377	.0343	.0377	.0343	.0377
21	.0343	.0343	.0377	.0343	.0377	.0343	.0377
22		.0343	.0377	.0343	.0377	.0343	.0377
23		.0343	.0377	.0343	.0377	.0343	.0377
24	.0377		.0343	.0381	.0343	.0377	.0343
Max	.0377	.0377	.0377	.0381	.0377	.0377	.0377
Min	.0343	.0339	.0339	.0343	.0343	.0343	.0343
Avg	.0356	.0353	.0353	.0355	.0365	.0362	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.4578	.4458	.4715	.3772	.5093	.4801
2	.4024	.2883	.2915	.4715	.3258	.5093	.463
3	.439	.3391	.2915	.5228	.3258	.6413	.463
4		.4239	.3429	.6722	.3429	.7842	.5144
5	.5548	.5935	.4287	.8779	.4287	.9335	.6001
6	.6661	.7291	.6516	.9694	.6687	1.0082	.9431
7	.9835	.8648	.9088	1.3203	.8745	1.2883	1.1317
8	1.073	1.0174	1.0631	1.226	.823	1.3443	1.1317
9	1.1488	.9175	1.0513	.9945	.8299		1.1389
10	.9602	.9389	.8478	.8059	.7922		.9335
11	.6859	.6908	.6783	.823	.9214		.6562
12	.6001	.6413		.8402	.8916		.703
13	.4973	.6036	.4481	.823	.9259		.7499
14	.4287	.415	.4854	.823	.6068		.6874
15	.4115	.4904	.4409	.7545	.759		.6405
16	.4287	.4527	.407	.8573	.7432		.7343
17	.5487	.4973	.5975	.823	.7968	.6859	.8592
18	.8573	.7373	.8215		.7343	.7202	.7716
19	.9774	.9431	1.0562		1.0456	.9774	1.1317
20	.8059	.823	.9054	.7202	.9709	.9431	.9808
21	.703	.6516	.6413	.6001	.8215	.7545	.8299
22		.5487	.5658	.5144	.679	.6001	.7167
23		.5144	.5281	.4801	.5658	.5487	.6413
24	.5281		.4801	.4715	.4287	.547	.5144
Max	1.1488	1.0174	1.0631	1.3203	1.0456	1.3443	1.1389
Min	.4024	.2883	.2915	.4715	.3258	.5093	.463
Avg	.6775	.6339	.6252	.7665	.6950	.7997	.7674

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3222	.3086	.3018	.3086	.4527	.3601
2	.4527	.3052	.3086	.6733	1.3375	1.2811	1.4232
3		.3052	.3086	.7888	1.2955	1.6004	1.5432
4	.5281	.373	.3429	.9835	1.4022	1.7433	1.6804
5	.7922	.6443	.4801	1.4419	1.6004	1.8576	1.8861
6	.9808	.9665	.8745	1.7078	2.0881	1.9862	1.9966
7	.9808	1.0174	.7888	2.2043	1.6004	2.2577	2.7263
8	.811	1.0174	.463	2.1956	2.5301	2.1576	2.4387
9	.7373	.7922	.6613	2.2805	2.4006		2.3005
10	.2058		.39	.6687	.5658		.679
11	2.3405	2.1091	.2035	.4287	.3772		.2641
12	2.572	2.2184		.1715	.2829		.2641
13	2.4177	2.4036	2.2405	.2229	.2452		.2641
14	2.4348	2.4813	1.8652	.1715	.2452		.2641
15	2.3491	2.431	2.4926	.1886	.1886		.2641
16	2.6578	2.372	2.5434	.2401	.2263		.3206
17	2.4082	2.3777	2.2138	.3086	.3584	.3944	.4108
18	2.1643	2.1338		.5658	.6413	.6344	.6348
19	.9088	.8916	.8962	.823	.7468	.6516	.8299
20	.7373	.7373	.7545	.7716	.8215	.7545	.811
21	.5316	.5487	.6413	.6001	.6161	.6001	.679
22		.4287	.4527	.4287	.5658	.4973	.5658
23		.3772	.3772	.4801	.5281	.4458	.4715
24	.3772		.3429	.3395	.3429	.4527	.3944
Max	2.6578	2.4813	2.5434	2.2805	2.5301	2.2577	2.7263
Min	.2058	.3052	.2035	.1715	.1886	.3944	.2641
Avg	1.3222	1.2388	.9068	.7911	.8881	1.1105	.9780

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 207 / 11KV SHELU SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0848	.0857	.0953	.0857	.132	.1029
2		.6783	.7373	.0953	.0857	.1132	.0857
3	.823	.9326	.8573	.1524	.0857	.1132	.0857
4	.8436	1.0174	.9945	.1905	.0857	.1509	.1029
5	1.0814	1.2717	1.1145	.1905	.12	.2263	.1372
6	1.1961	1.3565	1.3717	.2477	.1715	.2641	.2229
7	1.4746	1.4413	1.4918	.2858	.2572	.2829	.2572
8	1.4746	1.4582	1.5242	.3429	.2572	.2452	.2572
9	1.5261	1.3125	1.5261	.1886	.2286		.1886
10	.1715	.1524	.1696	.1372	.1143		.132
11	.1029	.1524	.112	1.2003	1.2574		1.2186
12	.0857			1.1145	1.2963		1.2811
13	.0857		.0848	1.4575	1.2811		1.3592
14	.0686		.0678	1.5775	1.2803		1.406
15	.0686	.1143	.0678	1.5432	1.587		1.4373
16	.0686	.1143	.0509	1.326	1.5741		.3206
17	.0686	.0686	.1524	1.3889	1.6091	1.5947	1.4419
18	.1029	.12	.2286	.9602	1.4217	1.4918	1.2811
19	.1886	.1886	.2286	.2229	.1886	.2401	.2286
20	.2058	.1886	.2096	.1715	.2263	.1715	.1905
21	.1372	.1543	.1143	.1372	.1886	.1715	.1905
22		.1029	.1143	.12	.1886	.1372	.1524
23		.0857	.0953	.1029	.1509	.12	.1334
24	.0953		.0857	.0953	.0857	.1509	.1029
Max	1.5261	1.4582	1.5261	1.5775	1.6091	1.5947	1.4419
Min	.0686	.0686	.0509	.0953	.0857	.1132	.0857
Avg	.4745	.5498	.4993	.5560	.5761	.3503	.5132

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 201 / TAKLI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
10		.4024
12	.7459	
Max	.7459	.4024
Min	.7459	.4024
Avg	.7459	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 202 / KATGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
8		2.2131
10		.2652
12	.1696	
Max	.1696	2.2131
Min	.1696	.2652
Avg	.1696	1.2392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 203 / RAMESHWAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
8		1.2041
10		.1696
12	.0381	
Max	.0381	1.2041
Min	.0381	.1696
Avg	.0381	.6869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV BHOISAMUDRA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	07-DEC-17
HR	Load (MW)
10	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV GANJUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
8		.2382
10		.0191
12	.0191	
Max	.0191	.2382
Min	.0191	.0191
Avg	.0191	.1287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV JEWALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
10		.0476
12	.3144	
Max	.3144	.0476
Min	.3144	.0476
Avg	.3144	.0476

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2743	.3086	.3429		.3429
2	.7202	.4115	.6859	.2743	.2743		.3086
3	.823	.823	.8573	.3429	.3429		.3429
4	.7545	.9602	.9259	.4115	.4801		.3772
5	.9602	1.0288	1.0974	.4801	.6859		.7545
6	1.3717	1.3032	1.3717	.823	.823	.6859	.8916
7	1.6118	1.5775	1.4403	.9602	1.0288		.8916
8	1.7147	1.7147	1.749	.9602	.9602		.823
9		1.5775	1.7318		.5144	.823	
10	.6859	.5144	.6173	.9259	.5144		
11		.4115	.4801		1.2346	1.4403	
12	.3429	.2743	.4115			1.6461	
13	.3429	.2743	.3429		1.5775	1.6118	1.6118
14	.2743	.2401	.2743		1.3717	1.4918	
15	.2743	.2743	.2743		1.5089	1.3717	
16	.2401	.2572	.2743		1.5775	1.5089	
17	.5487	.3086	.3429	1.5775		1.5089	1.6461
18	.5487	.5487	.6173	1.5089	1.4403	1.4403	1.3717
19	.6859	.7202	.6859	.7545		.7545	.7545
20	.823	.6173	.7545	.6859		.6173	.6173
21	.6859	.5144	.6859	.5487		.5487	.5487
22	.5487	.4458	.5487	.4801		.4801	.4458
23	.4801	.3772	.3429	.4801		.4115	.3772
24	.2743	.3429	.3086	.3429	.3429		.3772
Max	1.7147	1.7147	1.749	1.5775	1.5775	1.6461	1.6461
Min	.2401	.2401	.2743	.2743	.2743	.4115	.3086
Avg	.6812	.6580	.7123	.6980	.8835	1.0894	.7343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1029	.1372	.1715	.1029		.2058
2	.3429	.1372	.3429	.2058	.1029		.2058
3	.3772	.4115	.3086	.2058	.1372		.1715
4	.3772	.4801	.3429	.2058	.2058		.2058
5	.4458	.5487	.4115	.2743	.4801		.2743
6	.6516	.823	.5487	.4115	.5487	.3429	.4115
7	.823	.8916	.8916		.6173		.3772
8	.8916	.9602	1.0288		.6173		
9		.9259	.9945				
10	.2743		.2058	.7545			
11	.2058		.1372		.6173	.7202	
12		.1372	.1372			.823	
13	.1372	.12	.1029		.8916	.8916	1.3375
14	.1029	.1029	.1029		.823	.823	
15	.1029	.12	.1029		.823	.7716	
16	.1372	.1372	.1372		.8916	.823	
17	.2058	.1372	.1372	1.166		.823	.8916
18	.2058	.2401	.2058	.9602	1.1317	.7545	.7545
19	.2743	.3429	.3429	.2058		.4115	.4115
20	.2058	.2743	.4115	.2058		.3429	.3086
21	.2058	.2058	.3429	.2058		.3429	.2401
22	.1372	.1886	.2743	.1715		.2743	.1715
23	.1372	.1715	.2058	.1372		.2058	.1372
24	.1715	.1372	.1715	.2058	.1372		.1715
Max	.8916	.9602	1.0288	1.166	1.1317	.8916	1.3375
Min	.1029	.1029	.1029	.1372	.1029	.2058	.1372
Avg	.2977	.3453	.3344	.3658	.5418	.5964	.3922

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0343	.1029	.0686		.2058
2	.0514	.0686	.0343	.4801	.1372		.4801
3	.1029	.0686	.0514	.4801	.823		.5487
4		.0686	.0686	.4801	.9602		.6173
5		.1029	.1715	.5487	1.0288		.823
6		.1372	.2572	.7545	1.0974	.8573	.9602
7		.2743	.2572	.9602	1.166		1.0288
8		.2058	.2401	1.166	1.2346		1.2346
9		.2058			1.0974	1.2003	
10	.1715	.0686	.0686	1.0288	.2058	.0686	
11	.6859	.8573	.8916		.1372		
12		.9945	1.0288				
13	1.0974	1.0974	1.166				.1029
14	1.166	1.166	1.2346		.1029		
15	1.0974	1.1317	1.166		.0686		
16	1.0974	1.2346	1.166		.1372		
17	1.0974	1.2003	1.0974	.0686		.1372	.1029
18	1.0288	1.0288	1.0288	.1029	.1029	.1715	.1029
19	.1372	.1372	.2058	.1372		.2058	.1715
20	.2058	.12	.2743	.2058		.2058	.12
21	.2743	.1029	.2743	.1372		.1715	.0857
22	.2058	.0857	.2058	.1029		.1372	.0686
23	.1372	.0686	.1372	.0686		.1029	.0514
24	.0686	.0686	.0686	.1372	.0686		
Max	1.166	1.2346	1.2346	1.166	1.2346	1.2003	1.2346
Min	.0514	.0686	.0343	.0686	.0686	.0686	.0514
Avg	.5114	.4401	.4838	.4095	.5273	.3258	.4190

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 204 / 11 KV SALGARA II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.4801	.6516	.6859	.5487		.6173
2	.6516	.4115	.6516	1.2346	1.0288		1.4403
3	.7202	.3429	.7545	1.3032	1.166		1.5089
4	.8916	.4115	.9259	1.4403	1.4403		1.6461
5	1.0288	.6173	1.0288	1.5775	1.5775		1.989
6	1.0288	.9602	1.3717	1.7833	2.5377	1.7147	2.4006
7	1.3375	.8916	1.4403	2.2634	2.6063		2.7435
8	1.1317	.823	1.0631	2.4006	2.9492		2.5377
9		.4801			2.4691	2.5377	
10	.4801	.7545	.4801	1.749	.7545	.7888	
11	1.989	1.7147	2.0576		.5487		
12	2.1948	2.1605	2.5377				
13	2.332	2.2291	2.7435				.6516
14	2.1262	2.2977	2.6749		.2743		
15	2.1262	2.4006	2.7435		.2058		
16	2.332	2.332	2.6749		.2743		
17	2.2634	2.1262	2.4006	.2058		.3429	.6859
18	2.0576	2.1262	1.989	.4801	.823	.6173	.7888
19	.5487	1.1317	.6173	.7545		.823	1.1317
20	.9602	.9602	.9602	1.0288		.7545	.9259
21	.823	.823	.823	.9602		.6859	.8573
22	.6173	.7545	.7545	.8916		.6173	.7888
23	.5487	.6859	.6859	.7545		.5487	.7545
24	.6859	.5487	.6859	.6173	.6859		.5487
Max	2.332	2.4006	2.7435	2.4006	2.9492	2.5377	2.7435
Min	.4801	.3429	.4801	.2058	.2058	.3429	.5487
Avg	1.2838	1.1860	1.4224	1.1842	1.2431	.9431	1.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 201 / 11KV KAWA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1334	.0953	.0953	.1143	.1524	.1334
2	.4049	.2458	.3277	.1143	.1143	.1524	.1334
3	.4534	.2949	.3725	.1334	.1143	.1905	.1715
4	.4534	.2949	.4049	.1715	.1524	.1905	.2096
5	.506	.4096	.4424	.2286	.2286	.2667	.2477
6	.506	.4696	.583	.3048	.3239	.2667	.2858
7	.6483	.7287	.7125	.2667	.362	.2858	.3429
8	.68	.7773	.7287	.2667	.3048	.3048	.3048
9	.7316		.6133	.2286	.3048	.2858	.2858
10	.2477	.2286	.2858	.1715	.1905	.2286	.2286
11	.1524	.1143	.1715	.6062	.5441	.7125	.7611
12	.1143	.0953	.1334	.7045	.5668	.6964	.9069
13	.0762	.0953	.1143	.7701	.6154	.5182	.8097
14	.0572		.0762	.7773	.6802	.7343	.8097
15		.0762		.8097	.6964		.7773
16	.1334	.0572	.0762	.8259	.7611	.7926	.8421
17		.0572	.0953	.7773		.6859	.7935
18	.2286	.1905	.1905			.4049	.6964
19	.2286	.2286	.2477	.2286		.2858	.2667
20	.2096	.2096	.2477	.2477		.2477	.2286
21	.1905	.1905	.1905	.1905		.1905	.1715
22	.1334	.1524	.1143	.1334		.1715	.1524
23	.1143	.1143	.1143	.1334			.1334
24	.0953	.1143	.1143	.1143		.1524	
Max	.7316	.7773	.7287	.8259	.7611	.7926	.9069
Min	.0572	.0572	.0762	.0953	.1143	.1524	.1334
Avg	.2937	.2399	.2805	.3609	.3796	.3599	.4214

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0934	.0934	.0934	.112	.1307
2	.0934	.0934	.0934	.1677	.1677	.2229	.1907
3	.0934	.0934	.1307	.1677	.2012	.2229	.2254
4	.112	.1307	.168	.216	.2515	.2622	.2572
5	.1494	.168	.1867	.2315	.3018	.2622	.2915
6	.2241	.2054	.2054	.2561	.3077		.3258
7	.2427	.2054	.2241	.3201	.3887	.4049	.3391
8	.2614	.2241	.2241	.4161	.4049	.3887	.407
9	.2054		.2241	.4321	.4049	.421	.4458
10	.168	.1494	.1867	.0187	.112	.112	.1307
11	.2743	.3018	.3441	.0187	.0934	.0747	.0747
12	.2968	.3185	.2785	.0187	.056	.056	.0747
13	.3041	.1677	.3113	.0187	.0747	.0373	
14	.3201	.1844	.3605	.0187	.056	.0373	
15	.3201	.1844		.0187	.0747	.056	.112
16	.2881	.2012	.4424	.0187	.056	.056	.0747
17	.3547	.2105	.3932	.0747	.056	.056	.0747
18	.2881	.1943	.3563	.168		.1494	.168
19	.1867	.2172	.1867	.168		.2054	.2054
20	.1867	.2054	.1867	.168		.1867	.1867
21	.1494	.168	.1307	.168		.1494	.168
22	.1307		.112	.1307		.1307	.1494
23	.112	.0934	.112	.112			.1307
24	.0934	.0934	.0934	.0934	.0934	.112	.112
Max	.3547	.3185	.4424	.4321	.4049	.421	.4458
Min	.0934	.0934	.0934	.0187	.056	.0373	.0747
Avg	.2062	.1774	.2193	.1464	.1774	.1689	.1943

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0191	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.2006	.1619	.2294	.2591
3	.0381	.0381	.0572	.2006	.2429	.2294	.2915
4	.0572	.0762	.0953	.2315	.2915	.2949	.3725
5	.0762	.0762	.1334	.2343	.3239	.4049	.4001
6	.1143	.1334	.1715	.2721	.3401	.4372	.4481
7	.1715	.1905	.1715	.2881	.421	.502	.502
8	.1715	.1905	.1334	.3521	.5182	.5668	.4858
9	.1334		.0953	.3521	.4999	.5506	.5182
10	.1143	.0953	.0762	.0572	.0572	.0762	.0572
11	.3858	.3725	.421	.0191	.0191	.0191	.0191
12	.4481	.4372	.4372	.0191	.0191	.0191	.0191
13	.4961	.5182	.502	.0191	.0191	.0191	.0191
14	.5121	.502	.5344	.0191	.0191	.0191	.0191
15	.4961	.5344		.0191	.0191	.0191	.0191
16	.4641	.4858	.5506	.0191	.0191	.0191	
17	.4641	.502	.5344	.0191		.0191	.0191
18	.4001	.4858	.4696	.0572		.0572	.0762
19	.0953	.0762	.1143	.0762		.1143	.1143
20	.0953	.0762	.0953	.0953		.0953	.0953
21	.0572	.0762	.0762	.0762		.0762	.0762
22	.0381	.0381	.0762	.0381		.0572	.0762
23		.0381	.0572	.0381			.0572
24	.0381	.0381	.0381	.0572	.0381	.0381	.0381
Max	.5121	.5344	.5506	.3521	.5182	.5668	.5182
Min	.0381	.0381	.0191	.0191	.0191	.0191	.0191
Avg	.2149	.2199	.2129	.1166	.1793	.1696	.1748

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.104	.12	.104	.0892	.125	.1372
2	.0937	.0892	.12	.3418	.3269	.3437	.2401
3	.0937	.0892	.12	.3715	.3418	.3749	.3429
4	.1094	.0892	.12	.4012	.3567	.4374	.4287
5	.125	.104	.0171	.431	.4458	.5624	.6173
6	.125	.1189	.1543	.5201	.5498	.6093	.8059
7		.1486	.1715	.535	.6984	.8124	.8745
8		.1486	.1715	.8025	.8173	.8592	1.046
9	.1562	.1372	.12	.8173		.8749	1.0631
10	.1337	.1372	.1486	.0446	.0937	.1029	.0892
11	.6836	.8059	.7727	.0446	.0781	.1029	.0892
12	.8916	.8745	.8768	.0594	.0937	.0857	.0892
13	.9065	.9602	.8768	.0594	.0937	.0686	.0892
14	.9214	.9602	.8619	.0594	.0781	.0686	.0743
15	.9214	1.0288	.8471	.0594	.0625	.0171	.0892
16	.9808	1.0117	.8768	.0594	.0781	.0857	.0743
17	.9214	.9431	.8916	.0594	.0781	.0857	.0743
18	.7876	.8402	.8173	.1189	.0781	.1715	.104
19	.1486	.3086	.1189	.1189	.1406	.1543	.1486
20	.1189	.1372	.1189	.1189	.1562	.1886	.1635
21	.1189	.1543	.1189	.1189	.125	.1372	
22	.1189	.1372	.1189	.1189	.1406	.1372	.1337
23		.1372	.1189	.104	.1406	.1372	.1189
24	.0937	.104	.12	.104	.0892	.1406	.1372
Max	.9808	1.0288	.8916	.8173	.8173	.8749	1.0631
Min	.0937	.0892	.0171	.0446	.0625	.0171	.0743
Avg	.4068	.3987	.3666	.2322	.2240	.2785	.3057

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11KV GANGAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.4801	.4854	.5316	.5548	.583
2	.7282	.6588	.6344	.4854	.5144	.5201	.6001
3	1.0402	.9015	.8916	.4854	.4801	.5201	.6001
4	1.283	1.1443	1.1317	.5201	.463	.7975	.7716
5	1.387	1.4563	1.4403	.8322	.6516	1.0402	1.286
6	1.543	1.7337	1.7661	1.1269	1.286	1.3523	1.3203
7		2.1845	2.0405	1.335	1.0288	1.0402	
8		2.2712	2.3834	1.2656	.8402	.9709	.9088
9	2.2192	2.2119	2.1776	1.0288		.9189	.9945
10	.6588	.8573	.8149	.7202	.7282	.6859	.3772
11	.5375	.4973	.6588	1.6289		1.5947	1.4575
12	.3294		.5375	2.0233		1.9033	1.8347
13	.3814	.3086	.3641	2.0576	2.2885	2.0405	2.0576
14	.2947	.3086	.3641	2.2634	2.2539	2.1434	2.1434
15	.2947	.2743	.3467	2.1262	2.1845	2.1434	2.1605
16	.2947	.2915	.3467	2.3834	2.1845	2.0748	2.2634
17	.3641	.3601	.4854	2.2291	2.1498	2.1605	2.332
18	.8495	.7545	.8322	2.1434	2.1152	1.9719	2.0576
19	1.0576	1.0288	.9536	.9088	.9015	1.0631	1.046
20	.9362	.8745	.9189	.8573	.8669	.9602	.9088
21	.7802	.8059	.7628	.7373	.8149	.8402	.8402
22	.6588	.6173	.6415	.7373	.6935	.703	.7888
23		.4973	.5028	.5658	.6241	.6173	.6344
24	.5028	.5028	.4801	.5028	.5487	.5721	.583
Max	2.2192	2.2712	2.3834	2.3834	2.2885	2.1605	2.332
Min	.2947	.2743	.3467	.4854	.463	.5201	.3772
Avg	.7917	.9142	.9148	1.2271	1.1500	1.2162	1.2413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.2652	.2915	.2652	.2347	.2683	.3086
2	.2347	.2486	.2915	.1989	.3018	.3018	.3429
3	.2347	.3978	.3429	.2321	.3353	.3688	.3772
4	.3521	.2818	.3601	.2984	.3688	.4024	.4801
5	.5365	.3315	.6173	.3647	.4862	.4694	.703
6	.6706	.4807	.6859	.5304	.503	.4862	.7888
7		.663	.7716	.5967	.7377	.9054	.8059
8		.7293	.703	.779	1.0059	.9389	1.1488
9	.5533	.5487	.5487	.8215		.9556	.9602
10	.3978	.3944	.4641	.3688	.3353	.4287	.3521
11	.4144	.4973	.4973	.3185	.3018	.3258	.3018
12	.547	.6859	.663	.2683	.2683	.2915	.2347
13	.5636	.8059	.6962	.218	.218	.2401	.1783
14	.663	.6859	.6962	.1844	.2012	.1715	.2012
15	.7127	.7373	.7127	.1341	.1677	.1543	.2012
16	.7956	.7545	.8619	.1509	.2347	.1543	.1677
17	.7625	.7888	.8288	.2012	.3353	.2058	.2347
18		.6859	.6796	.4359	.4024	.4115	.4191
19	.5636	.5316	.5801	.5533	.4694	.5658	.6036
20	.4973	.4801	.4475	.5197	.4024	.4973	.4862
21	.431	.3772	.3812	.3521	.3688	.4115	.4359
22	.3481	.3429	.2984	.3018	.3353	.3601	.3856
23		.2915	.2818	.2683	.3018	.3258	.3353
24	.2683	.2818	.2915	.2818	.2515	.3018	.3086
Max	.7956	.8059	.8619	.8215	1.0059	.9556	1.1488
Min	.2347	.2486	.2818	.1341	.1677	.1543	.1677
Avg	.4899	.5120	.5414	.3602	.3725	.4143	.4484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / K R REFINARY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0171	.0191	.0191	.0191	.0171
2	.0191	.0191	.0171	.0191	.0191	.0191	.0171
3	.0191	.0191	.0171	.0191	.0191	.0191	.0171
4	.0191	.0191	.0171	.0191	.0191	.0191	.0171
5	.0191	.0191	.0171	.0191	.0191	.0191	.0171
6	.0191	.0191	.0171	.0191	.0191	.0191	.0171
7		.0191	.0171	.0191	.0191	.0191	.0171
8		.0191	.0171	.0191	.0191	.0191	.0171
9		.0171	.0171	.0191		.0191	.0171
10	.0191	.0171	.0191	.0191	.0191	.0171	.0191
11	.0191	.0171	.0191	.0191	.0191	.0171	.0191
12	.0191	.0171	.0191	.0191	.0191	.0171	.0191
13	.0191	.0171	.0191	.0191	.0191	.0171	.0191
14	.0191	.0171	.0191	.0191	.0191	.0171	.0191
15	.0191	.0171	.0191	.0191	.0191	.0171	.0191
16	.0191	.0171	.0191	.0191	.0191	.0171	.0191
17	.0191	.0171	.0191	.0191	.0191	.0171	.0191
18	.0191	.0171	.0191	.0191	.0191	.0171	.0191
19	.0191	.0171	.0191	.0191	.0191	.0171	.0191
20		.0171	.0191	.0191	.0191	.0171	.0191
21	.0191	.0171	.0191	.0191	.0191	.0171	.0191
22	.0191	.0171	.0191	.0191	.0191	.0171	.0191
23	.0191	.0171	.0191	.0191	.0191	.0171	.0191
24	.0191	.0191	.0171	.0191	.0191	.0191	.0171
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0171	.0171	.0191	.0191	.0171	.0171
Avg	.0191	.0179	.0183	.0191	.0191	.0179	.0183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2915	.2572	.3395	.3258	.3121	.4287
2	.924	.3601	.3944	.3584	.3086	.3121	.4801
3	1.262	.6344	.6516	.4338	.3086	.333	.6516
4	1.5746	.7716	.9431	.5281	.3944	.4908	.7373
5	1.701	1.1145	1.166	.7356	.8573	.8495	.8916
6	1.7353	1.2346	1.286	.9149	1.0117	1.0749	1.0288
7		1.4575	1.6632	.9709	1.166	1.2269	1.1145
8	1.8778	1.6804	1.7318	.9335	.823	1.0402	
9	1.8519	1.6575	1.6461	.9189	.7545	.8865	.8059
10	.6173	.5658	.5316	.6588	.6516	.811	.5144
11	.2915	.5093	.3258	1.595	1.6804	1.262	1.3375
12				1.7177	1.8861	1.6409	1.8004
13		.381		1.7684	1.9376	1.587	1.5947
14		.2858	.3086	1.8724	1.8004	1.5565	1.6289
15		.3018	.2401	.2629	1.749	1.491	1.6632
16		.3239	.2572	1.8404	1.9033	1.4419	1.8176
17	.5144	.4115	.3018	1.8176	1.8724	1.5947	1.6741
18	.6687	.6344	.3772		1.647	1.7661	1.6712
19	.6001	.6344	.5281	.6001	1.0056	.8573	.6602
20	.5487	.5658	.5847	.6344	.7362	.7373	.7922
21	.5144	.463	.5093	.5487	.6661	.6687	.7545
22	.4287	.3086	.4527	.4801	.5609	.6001	.6838
23	.3086	.2229	.3961	.4115	.4031	.5658	.5544
24	.3206	.2915	.2401	.3772	.3429	.4031	.4115
Max	1.8778	1.6804	1.7318	1.8724	1.9376	1.7661	1.8176
Min	.2915	.2229	.2401	.2629	.3086	.3121	.4115
Avg	.8912	.6566	.6724	.9008	1.0330	.9796	1.0303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7545	.9088	.7392	.7545	.7802	.8573
2	.7947	.7716	.9431	1.2437	.6001	.6935	1.0117
3	.9979	.9431	1.0117	1.5746	.9431	.9709	1.166
4	1.2936	1.166	1.0974	1.7737	1.286	1.3672	1.5089
5	1.7556	1.286	1.3032	2.364	1.7147	1.893	1.5947
6	1.9035	1.5432	1.5089	2.8296	2.3148	2.4539	2.3663
7	1.9959	1.8176	1.8176	3.0476	2.8807	2.9096	2.8292
8	2.1068	1.8519	1.9204	3.0498	3.0864	2.9835	3.155
9	1.6289	1.6617	1.6461	2.9447	3.0007	3.0167	2.692
10	1.3375	1.587	1.3375	1.2309	1.2174	.9522	1.1488
11	2.1605	1.7375	1.8861	.8322	1.1145	.8402	.8573
12	2.6749	2.1195	2.4691	.6935	.8916	.6908	.7716
13	2.6406	2.6452	2.572	.6661	.6859	.6161	.7202
14	.6173	2.5888	2.6063	.6661	.6516	.6535	.7373
15	2.3148	2.6452	2.6406	.5959	.5658	.6001	.7545
16	2.4691	2.7469	2.7606	.6485	.6173	.7655	.703
17	2.7949	2.5892	2.2805	.7202	.7712	.7545	1.0269
18	2.4863	2.5377	2.6063	1.1831	1.1568	1.2517	1.1016
19	1.286	1.4918	1.2696	1.2174	1.4563	1.4575	1.2936
20	1.3717	1.3889	1.3676	1.286	1.335	1.3717	1.419
21	1.2517	1.2346	1.1458	1.2003	1.2971	1.2517	1.3256
22	1.1145	1.046	1.0349	1.0631	1.1568	1.0974	1.2012
23	.8745	.9088	.9979	.8573	.8764	.9602	1.0534
24	.8029	.7716	.8916	.7842	.7545	.8238	.8402
Max	2.7949	2.7469	2.7606	3.0498	3.0864	3.0167	3.155
Min	.6173	.7545	.8916	.5959	.5658	.6001	.703
Avg	1.6441	1.6598	1.6677	1.3838	1.2971	1.2981	1.3390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 203 / 11KV AGRAWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.1886	.1715	.2058	.1543	.1867	.1715
2	.1715	.1715	.1886	.1886	.1372	.168	.1715
3	.1543	.1715	.2058	.1715	.1372	.168	.2058
4	.1715	.1543	.2058	.1715	.1372	.1886	.2572
5	.1886	.1715	.2229	.1886	.1372	.1886	.2401
6	.1886	.1886	.2401	.2229	.1372	.2263	.2572
7	.2058	.2058	.2058	.2401	.1715	.2801	.2572
8	.2401	.2401	.2401	.2572	.1715	.2829	
9	.2229	.2401	.2401	.2241	.2058	.2401	.2401
10	.2229	.2229	.2058	.2241	.2229	.2572	.2229
11	.2572	.2401	.1886	.2614	.2229	.2401	.2229
12	.2572	.2058	.1886	.2614	.2401	.2401	.2401
13	.2572	.2229	.1715	.2614	.2401	.2572	.2572
14	.2572	.2401	.1715	.2641	.2401	.2401	.2572
15	.2401	.2229	.2058	.2614	.2743	.2401	.2572
16	.2743	.2401	.2229	.2614	.2572	.2915	.2572
17	.2572	.2572	.2229	.2229	.2801	.2915	.3086
18	.2401	.2229	.2058	.2058	.3174		.2743
19	.1886	.1886	.2229	.1886	.2772	.2229	.2572
20	.1886	.1886	.2401	.1886	.2054	.2229	.2614
21	.2058	.1715	.2229	.1715	.2054	.2401	.2229
22	.2058	.1886	.2401	.1543	.2054	.2229	.2058
23	.2058	.1886	.2229	.1543	.1867	.2058	.2058
24	.1715	.1715	.1715	.2229	.1543	.1734	.1886
Max	.2743	.2572	.2401	.2641	.3174	.2915	.3086
Min	.1543	.1543	.1715	.1543	.1372	.168	.1715
Avg	.2136	.2043	.2094	.2156	.2049	.2294	.2365

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 204 / PANAN MAHASANGH NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0171	.0173	.0171
2	.0171	.0171	.0171	.0171	.0171	.0173	.0171
3	.0171	.0171	.0171	.0171	.0171	.0175	.0171
4	.0171	.0171	.0171	.0171	.0171	.0175	.0171
5	.0171	.0171	.0171	.0171	.0171	.0175	.0171
6	.0171	.0171	.0171	.0171	.0171	.0175	.0171
7	.0171	.0171	.0171	.0171	.0171	.0175	.0171
8	.0171	.0171	.0171	.0171	.0171	.0171	.0171
9	.0171	.0171	.0171	.0173	.0171	.0171	.0171
10	.0171	.0171	.0171	.0175	.0171	.0171	.0171
11	.0171	.0171	.0171	.0175	.0171	.0171	.0171
12	.0171	.0171	.0171	.0175	.0171	.0171	.0171
13	.0171	.0171	.0171	.0175	.0171	.0171	.0171
14	.0171	.0171	.0171	.0173	.0171	.0171	.0171
15	.0171	.0171	.0171	.0173	.0171	.0171	.0171
16	.0171	.0171	.0171	.0173	.0171	.0171	.0171
17	.0171	.0171	.0171	.0171	.0173	.0171	.0171
18	.0189	.0171	.0171	.0171	.0173	.0171	.0171
19	.0171	.0171	.0171		.0175	.0171	.0171
20	.0171	.0171	.0171	.0171	.0173	.0171	.0171
21	.0171	.0171	.0171	.0171	.0173	.0171	.0171
22	.0171	.0171		.0171	.0175	.0171	.0171
23	.0171	.0171	.0171	.0171	.0175	.0171	.0171
24	.0171	.0171	.0171	.0171	.0171	.0173	.0171
Max	.0189	.0171	.0171	.0175	.0175	.0175	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0172	.0171	.0171	.0172	.0172	.0172	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 201 / 11KV MALVATI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-DEC-17
HR	Load (MW)
15	.2743
Max	.2743
Min	.2743
Avg	.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 202 / 11KV KOLPA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-DEC-17
HR	Load (MW)
14	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154077 / 33/11 KV KOLPA

Feeder No / Name : 203 / 11KV BHATKHEDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-DEC-17
HR	Load (MW)
14	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 201 / 11KV BHATANGALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.024		.0377	.0339			.0377
2	.3906		.4858	.0339		.024	.0377
3	.4744		.5735	.0335		.024	.0373
4	.506		.5761	.0339		.024	.0373
5	.5535		.6316	.0339			.0366
6	.6642		.8322	.0335			.0366
7	.8855		.9602	.0339			.0347
8	.8697		.9762	.0335		.024	.0339
9	.9717		.9646	.0339	.0362	.024	.024
10	.037		.024		.0362	.024	.024
11	.0377		.024		1.0688	.6249	.9488
12	.037		.024		.9804	.7274	.9014
13	.0377		.024		.933	.8697	.9804
14	.0377		.024		.9122	1.012	.7682
15	.0377		.024		.9555	.9646	.8697
16	.0377				.9962	.9488	.9488
17		.0377	.0332			.9602	.7907
18		.0377	.0335			.787	.9488
19		.0373	.0335			.037	.024
20		.0373	.0339			.037	.024
21		.0373	.0332			.037	.024
22		.0377	.0335			.037	.024
23		.0377	.0335			.037	
24	.024		.0377	.0339		.024	.0373
Max	.9717	.0377	.9762	.0339	1.0688	1.012	.9804
Min	.024	.0373	.024	.0335	.0362	.024	.024
Avg	.3309	.0375	.2806	.0338	.7398	.3624	.3317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 202 / 11KV CHIKHALTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.012					.012	
2				.2543		.1898	.2401
3	.012			.2713		.2214	.3041
4	.012			.285		.253	.3201
5	.012			.3391			.3521
6	.012			.4409			.4049
7	.012			.4694			.5079
8	.012			.5087		.4744	.4696
9			.012	.4748	.506	.4111	.4902
10			.012			.012	.012
11	.5281		.3795			.012	.012
12	.5441					.012	.012
13	.5601		.427				.012
14	.5376		.506			.012	.012
15	.5761		.4744			.012	.012
16	.5921						.012
17		.5668	.5087				.012
18		.4961	.503				.012
19							.012
20							.012
21							.012
22							.012
24	.012					.012	
Max	.5921	.5668	.5087	.5087	.506	.4744	.5079
Min	.012	.4961	.012	.2543	.506	.012	.012
Avg	.2453	.5315	.3528	.3804	.506	.1361	.1545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 203 / 11KV BAMNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048		.032	.0693		.012	.0326
2	.012		.0337	.2543		.253	.2105
3	.072		.0332	.285		.253	.2785
4	.096		.0553	.2883		.4428	.3768
5	.12		.0884	.3353			.4096
6	.132		.1437	.4694			.6203
7	.144		.1574	.5935			.788
8	.132		.16	.6203		.6483	.7459
9	.1012		.144	.5765	.6554	.6009	.6325
10	.0562		.132		.0686	.072	.072
11	.427		.3637		.0337	.048	.048
12	.4111		.6325		.0217	.048	.048
13	.5506		.6483		.0099	.048	.048
14	.5535		.6325		.0099	.048	
15	.5441		.6009		.0109	.4801	.048
16	.5441				.0097	.048	.048
17		.6081	.57			.0412	.048
18		.583	.5533			.0652	.048
19		.1029	.1174			.1012	.06
20		.08	.1006			.0774	.072
21		.0686	.0829			.0572	.048
22		.0472	.0663			.0465	.048
23		.0457	.0671			.0472	
24	.048		.0343	.0678		.048	.036
Max	.5535	.6081	.6483	.6203	.6554	.6483	.788
Min	.012	.0457	.032	.0678	.0097	.012	.0326
Avg	.2348	.2194	.2369	.3560	.1025	.166	.2167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 201 / 11KV water supply feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.2058				
6		.2012					
7	.1696		.2058	.2378		.2561	
8	.2949		.2572	.2561		.2926	.2229
9		.3467					.1829
10	.4024	.3988	.2561			.3658	
12	.4024	.4607				.4207	
14		.4961				.5487	
15	.4572						
16	.4572	.4961	.3475				.5121
17	.4755				.439		
18		.4115	.3658				.4763
20		.3086	.2743				
21							.2204
22			.2743				
24	.1734	.1646	.1886			.1646	.1886
Max	.4755	.4961	.3658	.2561	.439	.5487	.5121
Min	.1696	.1646	.1886	.2378	.439	.1646	.1829
Avg	.3541	.3649	.2639	.2470	.439	.3414	.3005

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 202 / 11KV AIRPORT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.6516				
6	.8322	.9412					
7	.8505		1.0802	.985		.9593	
8	1.2765		1.2174	1.0745		1.1765	1.1145
9		1.1622					1.2851
10	1.2178	1.2574	1.1222			1.1641	
12	1.0387	1.1706				1.1641	
14						1.1641	
15	1.1462	1.3717					
16	1.1641	1.2574	.7682				1.4118
17	1.2851				1.5203		
18		1.2003	.8954				1.4289
20		.9259	.8954				
21							.8495
22			.6268				
24	.6068	.6335	.5144			.6878	.4801
Max	1.2851	1.3717	1.2174	1.0745	1.5203	1.1765	1.4289
Min	.6068	.6335	.5144	.985	1.5203	.6878	.4801
Avg	1.0464	1.1022	.8635	1.0298	1.5203	1.0527	1.0950

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 203 / 11KV Goodwill feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.3086				
6	.373	.3772					
7			.3429	.2858		.1886	
8	.2481		.3086	.3429		.1886	.3429
9		.3658					.4904
10	.4191	.373	.3395			.2858	
12	.381	.4108				.381	
14		.3189					
15	.381					.381	
16	.381	.4481					.4904
17	.6036				.415		
18		.4458					.6097
20		.3429	.2858				
21							.3814
22			.2858				
24	.3544	.3395	.3086			.1509	.3086
Max	.6036	.4481	.3429	.3429	.415	.381	.6097
Min	.2481	.3189	.2858	.2858	.415	.1509	.3086
Avg	.3927	.3802	.3114	.3144	.415	.2627	.4372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.2058				
6		.0171					
7	.0678		.0171	.0819		.0857	
8	.0671		.3601	.0819		.1029	.0171
9		.1772					.0171
10	.0164	.1772	.0171			.0983	
12	.0164	.2481				.0983	
14		.208				.0819	
15	.0164						
16	.0164	.208	.0514				.0686
17	.0171				.0857		
18		.3086	.0492				.0164
20		.2572	.0492				
21							.0328
22			.0492				
24	.0678	.0514	.2058			.0857	.2572
Max	.0678	.3086	.3601	.0819	.0857	.1029	.2572
Min	.0164	.0171	.0171	.0819	.0857	.0819	.0164
Avg	.0357	.1836	.1117	.0819	.0857	.0921	.0682

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 205 / KANHAIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.1886				
6	.1865	.2743					
7			.2058	.128		.1463	
8	.1357		.12	.1463		.1097	.1029
9		.1595					.0914
10	.2561	.4207	.0914			.1829	
12	.3658	.5525				.2378	
15	.1829	.1865				.1829	
16	.2561	.2947	.1097				.2743
17	.3841				.2378		
18		.2743	.1097				.156
20		.1886	.1097				
21							.1174
22			.1097				
24	.1357	.128	.1543			.1097	.12
Max	.3841	.5525	.2058	.1463	.2378	.2378	.2743
Min	.1357	.128	.0914	.128	.2378	.1097	.0914
Avg	.2379	.2755	.1332	.1372	.2378	.1616	.1437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.8916				
6		.9335					
7			.8916	.8962		1.0269	
8			.8916	.9149		1.0642	.823
9		.9511					.8962
10		.9149	.8962			1.0456	
12	.4668	.9694				1.0829	
14		.9896				.9522	
15	.9335						
16	1.0269	.9145					.9522
17	.9522				1.1016		
18		.8402					.8139
20		.8402	.7842				
21							.7975
22			.8215				
24		.8589	.7888			.9709	.7545
Max	1.0269	.9896	.8962	.9149	1.1016	1.0829	.9522
Min	.4668	.8402	.7842	.8962	1.1016	.9522	.7545
Avg	.8449	.9125	.8522	.9056	1.1016	1.0238	.8396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 207 / 11 KV Dhoot feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.2058				
6	.2374	.2229					
7			.2743	.2035		.2401	
8	.2883		.2743	.2374		.2229	.2572
9		.3294					.3086
10	.3052	.3721	.2401			.2543	
12	.3277	.4075				.2543	
14		.3898				.407	
15	.3391						
16	.3391	.4252	.3429				.2572
17	.3601				.3429		
18		.3772	.3391				.218
20		.3601	.2543				
21							.2883
22			.1696				
24	1.0029	.2401	.2401			.2058	.2743
Max	1.0029	.4252	.3429	.2374	.3429	.407	.3086
Min	.2374	.2229	.1696	.2035	.3429	.2058	.218
Avg	.4000	.3471	.2601	.2205	.3429	.2641	.2673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 208 / 11 KV Kalantri feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			1.1317				
6	1.1157	1.226					
7			1.1488	1.2003		1.1506	
8	1.1622			1.2384		1.1317	1.3889
9		1.1523					1.6032
10	1.2574	1.2955	1.0642			1.3336	
12	1.2955	1.2071				1.3336	
14		1.2323				1.6004	
15	1.1622						
16	1.2384	1.3717	1.2449				1.2449
17	1.226				1.7541		
18		1.2003	1.2384				1.1163
20		1.0802	1.1431				
21							.6952
22			1.0479				
23	.4755						
24	1.2323	1.3014	.9088			1.2449	1.3546
Max	1.2955	1.3717	1.2449	1.2384	1.7541	1.6004	1.6032
Min	.4755	1.0802	.9088	1.2003	1.7541	1.1317	.6952
Avg	1.1295	1.2296	1.1160	1.2194	1.7541	1.2991	1.2339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 201 / 11KV Nagazari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0857	.0934	.0943	.1029	.1029	.1132
2	.0857	.1029	.0934	.1677	.2401	.2401	.2347
3	.0857	.1372	.112	.2321	.3086	.2743	.2984
4	.0857	.1715	.1494	.2984	.3429	.3429	.3353
5	.1029	.2058	.1494	.3277	.4115	.4801	.3978
6	.1543	.2572	.1867	.3605	.4973	.6173	.4096
7	.2058	.2572	.2614	.502	.6344	.7888	.6478
8	.2572	.2401	.2614	.6882	.8402	.7545	.6802
9	.2229	.2229	.2241	.6964	.8059	.7202	.6882
10	.1715	.1372	.1494	.132	.1543	.0943	.1132
11	.5316	.4801	.5138	.0857	.1029	.0943	.1029
12	.6001	.6882	.6882	.0857	.0686	.0754	.0905
13	.6859	.7373	.6554	.0686	.0686	.0754	.0724
14	.703	.7045	.6554	.0857	.0686	.0566	.0543
15	.7373	.6718	.6802	.0686	.0857	.0754	.0549
16	.7716	.6554	.7045	.0857	.12	.0943	.0934
17	.7888	.5898	.6554	.1029	.0857	.0943	.112
18	.6344	.2279	.547	.1543	.2058	.1509	.168
19	.1715	.2054	.2075	.1715	.2058	.2263	.2054
20	.1543	.1867	.1698	.1715	.1715	.2263	.168
21	.1372	.1494	.1698	.1543	.12	.1886	.1307
22	.1029	.112	.1509	.1543	.1029	.1509	.1307
23	.0857	.0934	.132	.12	.1029	.1132	.112
24	.2458	.0857	.0934	.1132	.12	.1029	.1132
Max	.7888	.7373	.7045	.6964	.8402	.7888	.6882
Min	.0857	.0857	.0934	.0686	.0686	.0566	.0543
Avg	.3260	.3086	.3210	.2134	.2486	.2558	.2303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 202 / 11 KV SAI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.12	.1494	.132	.1372	.12	.1509
2	.3601	.2058	.4239	.132	.12	.12	.1509
3	.463	.3429	.4096	.1509	.1029	.1372	.1698
4	.5316	.4801	.4424	.1886	.12	.1715	.2263
5	.6344	.6001	.583	.2263	.1543	.2058	.3395
6	.7888	.7202	.7125	.2829	.2572	.2401	.3772
7	.9774	.9088	.852	.3584	.3086	.2743	.3772
8	1.1317	1.0974	1.0322	.3395	.2915	.2058	.3206
9	1.1145	1.0288	1.0322	.2452	.2229		.2263
10	.1715		.1357	.1886	.1715		
11	.1029	.0343	.1132	.7545	.7716	.7865	.852
12		.1063	.0754	.7888	.8402	.9012	1.065
13		.0732	.0754	.9945	.9431	.8619	1.0486
14		.0732	.0943	1.0631	1.0288	1.1336	1.065
15	.0857	.0747	.0754	1.0288	1.0288	.9503	1.004
16	.0857	.0747	.0754	1.0631	1.0288	.9503	1.065
17	.0857	.0934	.1132	1.0802	.7716	1.0688	1.0526
18	.1886	.1867	.0943	.9774	.6859	.9339	.9831
19	.2058	.2427	.2452	.2058	.2401	.2829	.2835
20	.1886	.2614	.2452	.2058	.2401	.2641	.1991
21	.1886	.2054	.2263	.1886	.1886	.2263	.168
22	.1372	.168	.1886	.1886	.1715	.1886	.168
23	.12	.1494	.1698	.1715	.1372	.1509	.168
24	.3932	.12	.1494	.1509	.1543	.1372	.1509
Max	1.1317	1.0974	1.0322	1.0802	1.0288	1.1336	1.065
Min	.0857	.0343	.0754	.132	.1029	.12	.1509
Avg	.3837	.3203	.3214	.4628	.4215	.4687	.5048

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154120 / Nagazri Substation

Feeder No / Name : 203 / 11 KV RAIWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.3361	.3395	.3258	.3429	.3395
2	.4287	.4287	.3429	.3395	.2915	.3429	.3395
3	.5144	.5144	.3441	.3772	.2572	.3429	.3772
4	.583	.6001	.4588	.4904	.2743	.3772	.5281
5	.6687	.6859	.4915	.5658	.3258	.4801	.6036
6	.7888	.7716	.7537	.6224	.4115	.5144	.6602
7	.9259	.8573	.9339	.6602	.4801	.6173	.6979
8	1.0631	.9945	1.004	.7167	.4458	.5144	.6979
9	1.0974	.9774	1.0322	.5847	.5144	.5487	.6036
10	.3944	.4287	.4115	.4338	.3429	.3961	.415
11	.3086		.3018	.8916	.6859	.663	.7956
12	.2572		.2641	.9774	.7888	.5365	.9667
13	.1886	.2896	.1886	1.0288	.8573	.9012	.8097
14	.1715	.2801	.2263	1.0974	.9259	.8288	.9012
15	.1715	.2427	.2075	.9602	1.0288	.9503	.8583
16	.2401	.2427	.2263	.9945	1.0288	.9012	.8356
17	.2743	.2801	.2452	1.0117	.9774	.9393	.8421
18	.4115	.4668	.4338	.8745	.8745	.9012	.7865
19	.5144	.5788	.5847	.4458	.583	.6224	.567
20	.4801	.5601	.547	.4801	.5144	.6036	.5228
21	.4458	.4854	.4904	.4458	.4115	.5658	.4481
22	.3772	.3734	.4527	.4115	.3772	.4904	.3734
23	.3086	.3547	.3772	.3944	.3429	.3772	.3361
24		.3086	.3361	.3395	.3601	.3429	.3772
Max	1.0974	.9945	1.0322	1.0974	1.0288	.9503	.9667
Min	.1715	.2427	.1886	.3395	.2572	.3429	.3361
Avg	.4749	.5014	.4579	.6451	.5594	.5875	.6118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 201 / 11KV GANJUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
23	.1638
Max	.1638
Min	.1638
Avg	.1638

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 202 / 11KV WAKDI SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.4572
Max	.4572
Min	.4572
Avg	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 201 / 11KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.1463	.1463	.128	.1227	.1448	.124
2	.1029	.1463	.128	.1254	.12	.1463	.1052
3	.1017	.1478	.1267	.1075	.1029	.1254	.104
4	.1187	.1478	.128	.1086	.12	.1267	.1214
5	.1227	.1478	.1478	.128	.1214	.1267	.1214
6	.1214	.1433	.1629	.1509	.1417	.1463	.1402
7	.1433	.1646	.1646	.1494	.1663	.1646	.1433
8	.1478	.168	.1629	.1478	.1886	.1791	.1772
9	.1829	.2033	.1886	.1886	.2075	.2075	.2263
10	.1772	.2587	.1886	.1867	.2096	.2641	.2641
11	.1629	.2218	.1663	.2218	.2075	.2263	.2195
12	.1612	.2012	.1029	.2378	.2075	.2427	
13	.1463	.2012	.1646	.2012	.2075	.1829	
14	.1478	.1646	.1663	.1629	.2054	.1646	.2033
15	.1267	.1463	.1478	.1463	.1663	.1463	.1612
16	.1612	.1867	.1463	.1448	.1509	.1463	.1629
17	.1698	.1463	.1463	.1905	.1829	.1629	.2012
18	.1663	.181	.1254	.1646	.1829	.1612	.2012
19	.1663	.1478	.1254	.1867	.1791	.1612	.1578
20	.1463	.1629	.1267	.1448	.1829	.1791	.1578
21	.168	.1612	.1463	.1646	.1629	.1829	.1772
22	.1646	.1463	.1463	.1848	.1663	.1848	.1772
23	.1448	.1463	.1463	.1478	.1629	.1629	.1578
24	.1448	.1448	.1448	.1478	.1433	.181	.1433
Max	.1829	.2587	.1886	.2378	.2096	.2641	.2641
Min	.1017	.1433	.1029	.1075	.1029	.1254	.104
Avg	.1467	.1680	.1478	.1611	.1670	.1715	.1658

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 202 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7316	.7133	.6099	.6535	.7468	.7095
2	.6535	.695	.6516	.5788	.6161	.7095	.6722
3	.6535	.6653	.6219	.5041	.5975	.6767	.6722
4	.6722	.7023	.6908	.5041	.6535	.7207	.6908
5	.7282	.7392	.7095	.6161	.7095	.9412	.7468
6	.8686	.924	.8131	.8029	.924	1.086	.9335
7	1.0242	1.182	1.0242	1.1458	1.1157	1.2567	1.2012
8	1.086	1.0985	1.086	1.0242	1.086	1.1523	1.2071
9	1.0719	1.0277	1.0166	1.0059	1.0402	1.0454	1.0136
10	1.0679	.9568	.9774	.924	.8573	.9602	.9015
11	1.0608		.8573	.8962	.8817	.9156	.9536
12	.9795	.9214	.8139	.8962	.7712	.9214	
13	.9231	.8939	.7455	.8326	.8551	.8063	
14	.7947	.8322	.6935	.8131	.8059	.8413	1.2536
15	.8413	.7975	.6836	.8029	.8149	.7716	1.0679
16		.8322	.7362	.8215	.8149	.8589	1.0608
17	.8916	.9568	.8413	.8648	1.0208	.8669	1.1041
18	1.4548	1.3169	1.0056	1.2048	1.1946	1.2757	1.4083
19	1.387	1.419	1.0985	1.3073	1.4118	1.3611	1.5154
20	1.3321	1.3121	1.0387	1.2178	1.3575	1.2536	1.4045
21	1.2048	1.134	.9313	1.1283	1.1888	1.2437	1.2752
22	1.0387	1.0269	.8688	.9593	.9955	.9979	1.0829
23	.8869	.8501	.7762	.8413	.8413	.8589	.9619
24	.7577	.7499	.7316	.6838	.7207	.7577	.7655
Max	1.4548	1.419	1.0985	1.3073	1.4118	1.3611	1.5154
Min	.6535	.6653	.6219	.5041	.5975	.6767	.6722
Avg	.9604	.9463	.8386	.8744	.9137	.9594	1.0274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 203 / 11KV KANHERI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435	.4435	.4854	.4294	.4481	.4805	.4668
2	.4108	.4294	.4668	.415	.4294	.4668	.4294
3	.4108	.4108	.4338	.3772	.4108	.462	.4294
4	.4294	.4294	.4805	.3772	.4481	.4755	
5	.4294	.4481	.4938	.4854	.4481	.5415	.5359
6	.5487	.547	.5228	.5788	.695	.7468	.7095
7	.695	.7602	.6838	.8316	.8596	.7947	.8488
8	.7783	.7164	.679	.7499	.788	.8488	.8488
9	.7468	.7087	.724	.6838	.7619	.788	.724
10	.7095	.7442	.6068	.7842	.6068	.6516	.6687
11	.7207		.6626	.7468	.6173	.7282	.6588
12	.7545	.7087	.4784	.7167	.5658	.7087	
13	.6908	.6379	.5138	.6908	.6344	.7087	
14	.6036	.6733	.4163	.5175	.4252	.5304	.6516
15	.6722		.4525	.6413	.6485	.6024	.7316
16	.6224	.6485	.4477	.7167	.6836	.5721	.7499
17	.703	.7783	.5847	.6952	.7682	.6935	.7602
18	.9015	.9896	.7975	.9114	.9055	.9568	.9145
19	.9114	1.0374	.7796	.9214	1.0082	.9313	.9795
20	.9036	.9335	.7343	.8417	.924	.8869	.9335
21	.7164	.7733	.6697	.7682	.811	.7682	.7733
22	.6401	.6908	.5853	.6584	.6722	.6653	.6979
23	.5487	.5601	.5121	.5487	.5847	.5975	.5716
24	.4938	.4805	.5281	.4481	.4805	.5041	.5228
Max	.9114	1.0374	.7975	.9214	1.0082	.9568	.9795
Min	.4108	.4108	.4163	.3772	.4108	.462	.4294
Avg	.6452	.6613	.5725	.6473	.6510	.6713	.6955

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695			
7				2.0328
8	1.8858			
9				1.7551
10				1.4045
11				1.2696
13			1.046	1.2936
14			1.0288	1.1949
15			1.046	1.1273
16				1.0829
17		1.3306		
22		1.0082		
24	.7287			
Max	1.8858	1.3306	1.046	2.0328
Min	.695	1.0082	1.0288	1.0829
Avg	1.1032	1.1694	1.0403	1.3951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 202 / 11 KV MURUD RURAL FEEDER

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
11		1.5154
13		1.8671
14		1.8298
15		1.7918
16		1.9404
24	2.1796	
Max	2.1796	1.9404
Min	2.1796	1.5154
Avg	2.1796	1.7889

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 203 / 11 KV DHORALA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	02-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
7			.9335
9			1.134
17		1.1576	
24	1.8443		
Max	1.8443	1.1576	1.134
Min	1.8443	1.1576	.9335
Avg	1.8443	1.1576	1.0338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
7			.1307
9			.2534
10			.0914
11			.2279
13			.3841
14			.1448
15			.2454
16			.2401
19		1.0526	
22		.0747	
24	2.7355		
Max	2.7355	1.0526	.3841
Min	2.7355	.0747	.0914
Avg	2.7355	.5637	.2147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 205 / 11 KV WATAWADA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.6984		
8	.8871		
11			1.0974
13		1.0517	1.3146
14		1.0669	1.2071
15		1.0669	1.1949
16			1.3169
24	1.1191		
Max	1.1191	1.0669	1.3169
Min	.6984	1.0517	1.0974
Avg	.9015	1.0618	1.2262

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 206 / 11 KV KARKATTA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
7			.2402
9			.1417
10			.112
11			.0362
13			.0934
14			.0701
15			.0732
16			.0543
22		.132	
24	.7545		
Max	.7545	.132	.2402
Min	.7545	.132	.0362
Avg	.7545	.132	.1026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
7			2.2779
9			2.4086
10			.0934
11			.0549
14			.0532
15			.056
16			.0366
17		2.6427	
22		.0943	
24	.763		
Max	.763	2.6427	2.4086
Min	.763	.0943	.0366
Avg	.763	1.3685	.7115

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 208 / 11 KV GUMPHAWADI -AG-

FEEDER Feeder KV- 11 /

OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
11		1.1389
13		1.5339
14		1.5893
15		1.386
16		1.4937
24	2.192	
Max	2.192	1.5893
Min	2.192	1.1389
Avg	2.192	1.4284

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 209 / 11 KV HOSPITAL (SEPERATE)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	07-DEC-17
HR	Load (MW)
9	.0187
10	.0914
11	.0187
13	.0183
14	.0187
15	.0187
16	.0187
Max	.0914
Min	.0183
Avg	.0290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 201 / 11 KV MURUD AKOLA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3224		.2984	.3155	.3395		.3315
2	.3224	.4715	.2984	.9259	1.3108		1.3923
3	.3506		.2984	.9945	1.3765		1.5912
4	.5487	.4715	.2984	1.3077	1.4575		1.6575
5	.7545			1.7695	1.5384		1.8233
6	.8817	1.1317	.5304	2.1376	1.6194		1.9227
7	.989		.9945	2.1862	1.8623		2.2377
8	.9156	.6573	1.0277	2.1052	1.8623		2.4531
9	.8916	.8488	1.0277	2.1376	1.8623	2.2809	2.42
10	.5967	.6036	.7293	.5487	.5658	.4715	
11	1.6575	1.406	2.1216	.4801	.3772	.2829	
12	2.3868	2.4034	2.3205		.3395	.2263	
13	2.5095	2.3644	2.1879	.3086	.2829	.2263	
14	2.5857	2.3967	2.3205	.2743	.2829	.2263	
15	2.5857	2.3967	2.3205	.2683	.1886	.2263	
16	2.3868	2.3482	2.5857	.2743	.1886	.2829	.3018
17	2.3482	2.5194	2.3758	.3206		.2984	.4527
18	2.2672	2.1879	2.1628	.4715		.5967	.679
19		.6962	.6859	.8488		.7293	.7545
20		.5967	.6173	.7545		.663	.7167
21		.4973	.4908	.5658		.4641	
22		.3315	.4207	.4715		.3978	.5014
23	.5658	.2984	.3856	.3772		.3315	.4298
24	1.0898	.4715	.2984	.3506	.3395	.3772	.3315
Max	2.5857	2.5194	2.5857	2.1862	1.8623	2.2809	2.4531
Min	.3224	.2984	.2984	.2683	.1886	.2263	.3018
Avg	1.3478	1.2549	1.1651	.8780	.9291	.5051	1.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433		.1905	.1402	.1698		.1905
2	.5258	.6706	.6859	.1578	.1698		.1905
3	.6365	.7287	.7621		.1698		.1905
4	.7202		.8383		.1698		.2667
5	.8048		.9145	.2572	.2263		.3429
6	.852		.9526	.3086	.2829		.381
7	.8907	1.0202	1.1431	.3086	.3395		.381
8	1.065	1.0202	1.2955	.3086	.2829		.3429
9	.9831		1.2193	.2401	.2641	.2263	.2286
10	.1905	.2263	.2286	.1372	.1886	.1698	
11	.1143	.1448	.0762	.6516	.9012	.9012	
12			.1143	.9614	.9717	.9717	
13			.0762	1.1142	.9717	.9717	
14			.0762	.9831	.9717	.9717	
15			.0953	1.0159	.9717	.9717	
16	.1143		.0953	.4973	.9717	1.004	1.0923
17	.1509	.1524	.1029	.9393		1.1431	.9503
18	.2263	.5716	.2058	.9393		1.0669	.9221
19		.381	.3155	.3206		.3429	
20		.3048	.2629	.2829		.2667	.2686
21		.2286	.2103	.2263		.2286	
22		.1905	.1753	.2075		.2286	
23	.2075	.1905	.1753	.1886		.1905	.1433
24	1.0898	.1886	.1905	.1402	.1698	.1886	.1905
Max	1.0898	1.0202	1.2955	1.1142	.9717	1.1431	1.0923
Min	.1143	.1448	.0762	.1372	.1698	.1698	.1433
Avg	.5447	.4299	.4334	.4694	.4819	.6153	.4054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1372	.2515	.3353
3				.3086	.3277	.3688
4					.4096	.4024
5				.3605		.4359
6				.431	.5668	.4694
7				.426	.5668	.6706
8				.4588	.5668	.663
9				.426	.5898	.6706
11	.5304	.4801	.5068			
12	.663	.6554	.5792			
13	.8048	.6554	.6516			
14	.7293	.6882	.724			
15	.8413	.6554	.724			
16	.7625	.6226	.7964			
17	.7449	.6783	.6706			
18	.6154	.5426	.6371			
24	1.0898					
Max	1.0898	.6882	.7964	.4588	.5898	.6706
Min	.5304	.4801	.5068	.1372	.2515	.3353
Avg	.7535	.6223	.6612	.3640	.4684	.502

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 204 / HT Chaitanya STEEL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	01-DEC-17	02-DEC-17
HR	Load (MW)	Load (MW)
20		.2774
24	1.0898	
Max	1.0898	.2774
Min	1.0898	.2774
Avg	1.0898	.2774

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 201 / 11 KV GADWAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.9069
Max	.9069
Min	.9069
Avg	.9069

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 202 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.0898
Max	1.0898
Min	1.0898
Avg	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 203 / 11 KV MASLA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.153
Max	1.153
Min	1.153
Avg	1.153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 204 / 11 KV WANJARKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 201 / 11 KV BOPLA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.8138
Max	1.8138
Min	1.8138
Avg	1.8138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 202 / 11 KC CHATA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.7287
Max	.7287
Min	.7287
Avg	.7287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 203 / 11 KV Takli FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.2146
Max	1.2146
Min	1.2146
Avg	1.2146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 206 / 11 kV Ekurga new SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2753	.2343	.2343	.3048	.3201	.2812
2	1.6108	1.406	1.0936	.2343	.3048	.3201	.2812
3	1.6194	1.8747	1.3904	.2656	.3429	.3521	.3437
4	1.6872	2.037	1.6248	.3281	.4763	.3841	.3906
5	1.9925	2.1605	1.8122	.3906	.5716	.4801	.4531
6	2.5301	2.3148	2.3434	.4374	.6097	.5281	.578
7	2.5934	2.4387	2.5777	.4687	.7621	.5121	.6405
8	2.1032	2.5934	2.7808	.4062	.724	.5121	.5624
9	2.0309	2.5911	2.3929	.3593	.5144		.6287
10	.3437	.4763	.4161	.3749	.4763		.5716
11	.3125	.3048	.2881	2.0153	2.4291		1.7166
12	.2187	.2477	.2241	2.2497	2.734		2.4129
13		.2286	.16	2.3746	2.672		2.5301
14		.2286	.1296	2.484	2.5617		1.085
15		.1905	.1524	2.4528	2.6882		.3401
16		.1905		2.4215	2.8147		
17	.2881	.2343			2.3434	2.5309	2.5459
18	.3201	.3906			2.2184	1.4998	
19	.4481	.4531			.5281	.5937	
20	.5121	.4218			.4801	.5312	
21	.4801	.3437			.4161	.4687	
22	.4481	.3125			.3521	.3749	
23	.3841	.2812			.2881	.3281	
24	.9389	.2753	.2343	.2343	.3429	.3041	.2812
Max	2.5934	2.5934	2.7808	2.484	2.8147	2.5309	2.5459
Min	.2187	.1905	.1296	.2343	.2881	.3041	.2812
Avg	1.0574	.9280	1.1159	1.0430	1.1648	.6275	.9202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 207 / 11 KV MBF New

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0381	.0381	.0381	.0381	.0381	.0381
2	.0572	.0381	.0381	.0381	.0381	.0381	.0381
3	.0572	.0381		.0381	.0381	.0381	.0381
4	.0572	.0381	.0381	.0381	.0381	.0381	.0381
5	.0572	.0381	.0381	.0381	.0381	.0381	.0381
6	.0572	.0381	.0381	.0381	.0381	.0381	.0381
7	.0572	.0381	.0381	.0381	.0381	.0381	.0381
8	.0572	.0381	.0381	.0381	.0381	.0381	.0381
9	.0572	.0381	.0381	.0381	.0381		.0381
10	.0572	.0381	.0381	.0381	.0381		.0381
11	.0572	.0572	.0381	.0762	.0953		.0572
12	.0572	.0953	.0381	.0762	.0953		.0762
13	.0572	.0953	.0381	.0762	.0762		.0762
14	.0572	.0762		.0572	.0572		.0572
15		.0762	.0381	.0572	.0572		.0572
16		.0762		.0572	.0953		.0572
17	.0572	.0762			.0754	.0762	.0762
18	.0381	.0381			.0566	.0381	
19	.0381	.0381			.0572	.0381	
20	.0381	.0381			.0381	.0381	
21	.0381	.0381			.0381	.0381	
22	.0381	.0381			.0381	.0381	
23	.0381	.0381			.0381	.0381	
24	1.0526	.0381	.0381	.0381	.0381	.0381	.0381
Max	1.0526	.0953	.0381	.0762	.0953	.0762	.0762
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0972	.0500	.0381	.0482	.0516	.0405	.0487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.5144	.4801	.4877	.4984	.4725	.4801
2	1.6766	1.6766	1.1203	.503	.5168	.4877	.5121
3	1.989	2.1216	1.6004	.5792	.5335	.5182	.5121
4	2.0972	2.1136	1.7124	.7773	.4974	.9297	.5921
5	2.2024	2.13	1.9524	.8383	.9746		.9602
6	2.2672	2.332	2.1765	.945	1.0461	1.0974	1.2163
7	2.1765	2.3644	2.3525	1.0212	1.155	1.1736	1.1523
8	2.1125	2.2024	2.2725	1.0059	1.0106	1.2193	1.1203
9	2.0805	2.1605	2.2405	.8663			1.0395
10	.5487	.3521	.7926	.5252	.8342	.6722	
11	.4801	.3361	.3048	1.7797	1.4632	1.9204	1.6575
12	.3437		.3353	2.1574	1.6461	2.0005	1.9662
13	.2572	.2401	.2896	1.8903	2.0119	2.1285	2.0645
14	.2743	.2881	.2439	2.2458	2.1338	2.1125	2.0729
15	.3086	.3041	.2439	2.3672	2.1795	2.0805	2.1136
16	.3086	.3361	.2591	2.0357	2.1948	2.1765	2.1052
17	.3429	.4481	.381	2.1656	1.9966	2.0485	2.1628
18	.8916	.8802	.6097	1.7742	1.9662	1.9364	2.0153
19	.6859	1.0402	.9602	.9613	.8383	1.0082	1.0288
20	.583	.6401	.7316	.8669	.7926	.8482	.8916
21	.5144	.6081		.6835	.6706	.6722	.7202
22	.5144	.5121	.5487	.5668	.5335	.5761	.6173
23	.4801	.4801	.4572	.5454	.503	.5281	.5487
24	.763	.4801	.4801	.442	.5335	.4877	.5121
Max	2.2672	2.3644	2.3525	2.3672	2.1948	2.1765	2.1628
Min	.2572	.2401	.2439	.442	.4974	.4725	.4801
Avg	1.0164	1.0679	.9802	1.1680	1.1535	1.2316	1.2201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0343	.0309	.0305	.038	.0305	.0309
2	.3898	.3429	.3395	.0305	.038	.0305	.0309
3	.4961	.3772	.4321	.0305	.038	.0305	.0309
4	.4961	.4801	.4321	.0305	.038	.0305	.0309
5	.567	.5487	.4938	.0305	.038	.0305	.0309
6	.6733	.6516	.571	.0305	.0289	.0305	.0309
7	.7442	.6889	.6481	.0305	.038	.0305	.0309
8	.7796	.7545	.5864	.0305	.038	.0305	.0309
9	.7442	.7099	.5864	.038	.038	.0305	.0377
10	.0377	.0309	.0305	.038	.038	.0309	.0377
11	.0377	.0309	.0305	.6417	.5335	.5556	.6173
12	.0377	.0309	.0305	.6387	.7468	.679	.6859
13	.0377	.0309	.0305	.7567	.7621	.7253	.703
14	.0377	.0309	.0305	.7097	.7926	.7716	.6952
15	.0377	.0309	.0305	.8639	.8078	.8002	.703
16	.0377	.0309	.0305	.7351	.823	.7522	.703
17	.0377	.0309	.0305	.7068	.6706	.6944	.703
18	.0362	.0309	.0305	.7668	.6249	.6173	.583
19	.0362	.0309	.0305	.038	.0305	.0309	.0343
20	.0362	.0309	.0305	.0379	.0305	.0309	.0362
21	.0362	.0309	.0305	.038	.0305	.0309	.0362
22	.0362	.0309	.0305	.038	.0305	.0309	.0362
23	.0362	.0309	.0305	.038	.0305	.0309	.0343
24	1.0898	.0354	.0309	.0305	.038	.0305	.0309
Max	1.0898	.7545	.6481	.8639	.823	.8002	.703
Min	.0362	.0309	.0305	.0305	.0289	.0305	.0309
Avg	.2723	.2107	.1908	.2650	.2634	.2536	.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1097	.0995	.1219	.0802	.0762	.0663
2	.1772	.1463	.1326		1.5561	1.5089	1.5912
3	.1772	.1463	.1326	1.5546	1.6904	1.6309	1.7736
4	.3189	.1829	.1658	1.6613	1.7407	1.6613	1.8233
5	.3544	.2534	.2984	1.8595	1.9319	1.7833	2.0222
6	.3898	.3544	.4973	2.2558	1.866	1.8442	2.1051
7	.4252	.4557	.4973	2.4387	2.0236	2.4082	2.4531
8	.4961	.4115	.4144	2.6673	2.1177		2.4366
9	.4252	.3315	.2984	2.684	2.2619	1.9357	2.4577
10		.3315	.2743	.2	.212	.2652	.2829
11	2.1862	2.1216	1.9966	.0854	.5335		
12	2.332	2.4531	2.1643		.5182		.0754
13	2.4291	2.6852			.0457	.0663	.0754
14					.061	.0617	.1029
15	2.4615		1.5394		.0457	.064	.1132
16	2.4615		2.4082		.0457	.0995	.1509
17	2.2996		2.3929		.061	.0995	.1698
18	2.1376		2.3015		.0762	.2321	.3086
19	.3429		.3353	.3334	.3048	.3315	.4115
20	.3086		.2134	.2406	.2439	.2486	.2743
21	.2058		.1524	.15	.1219	.1658	.1715
22	.1372		.1219	.0854	.1067	.0995	.181
23	.1063		.1067	.0834		.0995	.1448
24	1.1022	.1097	.0995	.1067	.0831	.0914	.0995
Max	2.4615	2.6852	2.4082	2.684	2.2619	2.4082	2.4577
Min	.1063	.1097	.0995	.0834	.0457	.0617	.0663
Avg	.9735	.7209	.7565	1.033	.7708	.7035	.8387

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	05-DEC-17
HR	Load (MW)
19	.0305
Max	.0305
Min	.0305
Avg	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.0724		.061	.0718	.061	.0716
2	.0712	.0724		.061	.054	.061	.0895
3	.0886	.0724		.061	.0538	.061	.0895
4	.0905	.0905		.061	.0538	.0457	.0895
5	.0886	.0905		.061	.072	.0457	.0895
6	.0724	.0905		.061	.0718	.061	.0895
7	.0543	.0905		.061	.072	.0762	.0895
8	.0543		.0537	.0305	.0722	.0762	.0895
9	.0543			.0667	.0897	.0762	.0905
10	.0709		.0457	.0897	.0897	.1075	.0724
11	.0709		.0762	.0891	.0762	.1433	.0724
12	.0709		.1067	.1251	.0914	.1612	.1086
13	.0709		.1067	.1436	.0914	.1612	.1086
14	.0886		.1067	.1501	.0914	.1612	.1132
15	.0886		.0914	.1256	.0762	.1433	.1139
16	.0886		.0914	.1072	.0762	.128	.1132
17	.0886		.0762	.1072	.0762	.1433	.1132
18	.0886		.0762	.1077	.061	.1254	.1509
19	.0709		.0762	.0897	.061	.1254	.1509
20	.0724		.0762	.0894	.061	.1075	.132
21	.0724		.0762	.0714	.061	.0895	.132
22	.0724		.061	.0715	.061	.0895	.1086
23	.0724		.061	.0718	.061	.0716	.1086
24	1.0526	.0724	.0716	.061	.0715	.061	.0716
Max	1.0526	.0905	.1067	.1501	.0914	.1612	.1509
Min	.0543	.0724	.0457	.0305	.0538	.0457	.0716
Avg	.1160	.0815	.0783	.0843	.0716	.0993	.1024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.6461		1.9719	1.8861	1.9204	1.6118
11			2.0233				
12	.5144						
16	2.0576	2.2291			.2401	.2229	
17							.6859
18				.6687			
24	1.1012	.2743	.2743	.2572	.2915	.2743	.2915
Max	2.0576	2.2291	2.0233	1.9719	1.8861	1.9204	1.6118
Min	.5144	.2743	.2743	.2572	.2401	.2229	.2915
Avg	1.2244	1.3832	1.1488	.9659	.8059	.8059	.8631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.8861	.4115	1.7147	.3772	.3086	.583	.2743
13	.1029						
16	.1029	.1715	.0857	2.2291	2.1605	2.2634	1.5089
24	1.0526	.1372	.0857	.12	.1029	.1886	.0857
Max	1.8861	.4115	1.7147	2.2291	2.1605	2.2634	1.5089
Min	.1029	.1372	.0857	.12	.1029	.1886	.0857
Avg	.7861	.2401	.6287	.9088	.8573	1.0117	.6230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.3772
8				.823	.8916	.9774	1.0117
11	.823	.7545	.5487				
16	.6173	.7202	.6516		.4287	.2401	
17				.6516			.823
24	.9069	.3086	.3086	.3086	.2743	.3772	
Max	.9069	.7545	.6516	.823	.8916	.9774	1.0117
Min	.6173	.3086	.3086	.3086	.2743	.2401	.3772
Avg	.7824	.5944	.5030	.5944	.5315	.5316	.7373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 204 / 11 KV Kanadi Borgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.5144	.3944	1.3375	1.5775	1.3717	1.0288
13	.2401						
16	1.4746	1.3717	1.2517	.2058	.1543	.2058	.583
24	1.1022	.2743	.2401	.2058	.2743	.2915	.3086
Max	1.4746	1.3717	1.2517	1.3375	1.5775	1.3717	1.0288
Min	.2401	.2743	.2401	.2058	.1543	.2058	.3086
Avg	.9390	.7201	.6287	.5830	.6687	.623	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 205 / 11 KV Tandulja Gao SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.0898
Max	1.0898
Min	1.0898
Avg	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 206 / 11KV Tandulja AG SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5487	.0171	.5487	.0343	.0343	.0343	.0343
16				.5316	.5658	.4973	.5316
24	1.0526						
Max	1.0526	.0171	.5487	.5316	.5658	.4973	.5316
Min	.5487	.0171	.5487	.0343	.0343	.0343	.0343
Avg	.8007	.0171	.5487	.2830	.3001	.2658	.2830

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.116	.0995	.0983	.1326	.0983	.1326
2	.0983	.1326	.0995	.3605	.2486	.3768	.3978
3	.1147	.1326	.0995	.5407	.4973	.4752	.5304
4	.1638	.116	.116	.6718	.7459	.6133	.5967
5	.213	.2486	.1326	.8029	1.0774	.7293	.6554
6	.2294	.2591	.1658	.9175	1.1603	.9282	.9831
7	.2458	.2652	.2652	1.0608	1.2266	1.0442	1.1142
8	.2785	.2818	.2622	1.1603	1.2929	1.1233	
9	.213	.1823	.2294	1.1934	1.326	1.1437	1.1633
10	.1823	.1658	.2321	.1989	.2321	.1311	.0829
11	1.326	1.1271	1.0486	.1658	.1638	.0983	.0995
12	1.4089	1.2431	1.326		.1475		.0829
13	1.3592	1.2929	1.3923		.0983		.0663
14	1.326	1.21	1.3435				.0829
15	1.3108	1.1934	1.2125			.0819	.0663
16	1.2929	1.0774	1.1934	.1658		.0819	.0663
17	1.1603	1.21	1.2289	.1823	.1475	.0983	.0829
18	1.1603	1.0774	1.0978	.2818	.1966	.1989	.1658
19	.1989	.2155	.2294	.3315	.2458	.2486	.2321
20	.2486	.1989	.1966	.3315	.2294	.2321	.1989
21	.1989	.1989	.1802		.1966	.1989	.1658
22	.116	.1658	.1311	.1989	.1638	.1638	.1326
23	.116	.116	.0983	.1658	.1475	.1658	.116
24	1.1022	.116	.0995	.0983	.1326	.1147	.1492
Max	1.4089	1.2929	1.3923	1.1934	1.326	1.1437	1.1633
Min	.0983	.116	.0983	.0983	.0983	.0819	.0663
Avg	.5908	.5143	.5200	.4698	.4671	.3975	.3202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 203 / 11 Kv Samangaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.0526
Max	1.0526
Min	1.0526
Avg	1.0526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 204 / 11 KV Natural FEEDER
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
6	.0191		
7		.0191	
8	.0191		
20			.0191
21			.0191
24	1.0526		
Max	1.0526	.0191	.0191
Min	.0191	.0191	.0191
Avg	.3636	.0191	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 201 / 11 KV Shiur Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
9	.4748
24	1.0526
Max	1.0526
Min	.4748
Avg	.7637

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.8048			.2012			
4	1.0395			.2515			
6	1.5257	1.4074		.4191			
7			1.7465		.2543	.5087	
8	1.8778	1.8821	1.8652	.4191	.2543	.4239	
9	.1017		1.8991	.373		.3561	.3353
11					1.4752		
12			.1677		1.7804		1.8107
13		.1187					
14			.1174				1.8442
15	.1357			1.9669			
16			.1174				1.861
17	.1526	.1696		1.8143	1.8991		1.9113
18		.2883	.2683		1.6956		
19			.3018				.2347
20				.2883			
21	.2374		.2515				.2683
23		.2035			.2035		
24	1.0526		.1865	.2012		.1865	
Max	1.8778	1.8821	1.8991	1.9669	1.8991	.5087	1.9113
Min	.1017	.1187	.1174	.2012	.2035	.1865	.2347
Avg	.7698	.6783	.6921	.6594	1.0803	.3688	1.1808

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1677			.8383			
4	.2683			.8718			
6	.57	.5765		1.0227			
7			.5426		1.4922	1.4074	
8	.5868	.5935	.5765	1.4251	1.5261	1.4413	
9			.4917	1.4243		1.3565	
10							.3018
11		1.1869			.1696		
12			1.358		.0848		.1006
14			1.358				.0671
15	1.2209			.0848			
16			1.2742				.0838
17	1.0513	1.3056			.1357		
18		1.3904			.2543		
19	.4748		.4024				.4694
20				.2883			
21	.2713		.2347				.2347
23		.1696			.1865		
24	1.0898		.1696	.1677		.1696	
Max	1.2209	1.3904	1.358	1.4251	1.5261	1.4413	.4694
Min	.1677	.1696	.1696	.0848	.0848	.1696	.0671
Avg	.6334	.8704	.7120	.7654	.5499	1.0937	.2096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 204 / 11 KV WATER WORKS EXP NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0671			.0671			
4	.0671			.0671			
6	.0671	.0339		.0671			
7					.017	.017	
8	.0671		.0339	.0671		.0678	
9	.0678		.0339	.0678		.0678	
10							.0671
11		.0678			.017		
12			.0168		.017		.0168
14			.0168				.0168
15	.017			.0678			
16							.0671
17	.017	.0339		.0678	.0678		.0671
18		.0339	.0671		.0678		
19			.0671				.0671
20				.0678			
21	.0678		.0671				.0671
23		.0339			.0678		
24	1.0898			.0671		.0678	
Max	1.0898	.0678	.0671	.0678	.0678	.0678	.0671
Min	.017	.0339	.0168	.0671	.017	.017	.0168
Avg	.1698	.0407	.0432	.0674	.0424	.0551	.0527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 205 / 11 KV Bhoyra New SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.8383			.3018			
4	1.0059			.4359			
6	1.0227	1.0174		.5868			
7			1.3056		.5765	.7122	
8	1.4083	1.4413	1.3056	.5197	.5426	.6613	
9	.5256		1.2548	.4748		.5596	
10							.3185
12			.2683				1.1065
14			.2012				1.0898
15	.1526			1.1869			
16							1.1065
17	.2543	.2713		1.0174	1.1361		1.1401
18		.4239	.4024		1.1022		
19			.4694				.5197
20				.2374			
21	.3561		.4024				.4024
23		.2543			.373		
24	1.0526		.2543	.3018		.3391	
Max	1.4083	1.4413	1.3056	1.1869	1.1361	.7122	1.1401
Min	.1526	.2543	.2012	.2374	.373	.3391	.3185
Avg	.7352	.6816	.6516	.5625	.7461	.5681	.8119

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 206 / 11 KV Ankoli new

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
11			.9326
12			.9665
13		.1696	
24	1.0526		
Max	1.0526	.1696	.9665
Min	1.0526	.1696	.9326
Avg	1.0526	.1696	.9496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 207 / 11 KV Dhanori SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0503			.4359			
4	.0671			.503			
6	.1677	.1357		.57			
7			.1696		.7969	.7122	
8	.1341		.1357	.6203	.7461	.8478	
9	.0678		.1187	.6952		.763	
10							.0838
11		.6613			.0509		
12			.7545		.0339		.0335
14			.7712				.0168
15	.6952			.0339			
16			.6874				.0168
17	.7969	.7291		.0339	.0509		.0335
18		.7461	.6874				
19			.1341				.1174
20				.0848			
21	.1017		.1006				.0838
23		.0848			.0848		.0671
24	1.0526		.0848	.0671		.0848	
Max	1.0526	.7461	.7712	.6952	.7969	.8478	.1174
Min	.0503	.0848	.0848	.0339	.0339	.0848	.0168
Avg	.3482	.4714	.3644	.3382	.2939	.6020	.0566

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3086	.3149	.3206	.2915	.2429	.3113
2	.3772	.2743	.3361	.3361	.2915	.2591	.2818
3	.3772	.3258	.3361	.3772	.3401	.2591	
4	.4668	.5144	.3658	.4668	.4534	.4858	
5	.5975	.5658	.4572	.5487	.5506	.6802	
6	.7682	.7202	.5792	.7947	.7125	.8421	
7	.8779	.823	.6268	.9145	.8097	.7935	
8	.7783	.7716	.6036	.8779	.8583	.7125	
9	2.572		2.1605	.7316	.664	.6316	
10	2.7778	2.6216	2.372	.5973	.5182	.5182	.5243
11	3.0864	2.6379	.4024	.5144	.4049	.3481	.3258
12	3.1722	2.6397	.2896	.3429	.2429	.2785	.2926
13	3.1036	2.672	2.1052	.3429	.2753	.2713	.2012
14	3.1893	2.6379	2.4006	.2915	.1619	.2321	.1991
15	3.0007	2.6882	2.372	.1372	.1781	.1966	
16	3.1379	2.6871	2.5911	.1543	.1619	.2035	
17	.3429	.3277	2.3967	2.3472	2.5101		1.9662
18	.5658	.5801	2.1348	2.3015	2.4777	2.4905	2.3482
19	.7202	.663	.7095	2.2558	2.1862	2.3102	2.452
20	.6516	.6882	.6535	2.1491	1.8785	2.2611	1.9433
21	.5144	.5304	.4904	1.6309	1.8461	2.1464	1.917
22	.3772	.407	.3734	1.6918	1.7976		1.7814
23	.3258		.3174	1.6766	1.6194		1.7814
24	1.0526	.3086	.3113	.3018	1.6461	1.587	2.0317
Max	3.1893	2.6882	2.5911	2.3472	2.5101	2.4905	2.452
Min	.3258	.2743	.2896	.1372	.1619	.1966	.1991
Avg	1.3830	1.1997	1.0708	.9210	.9532	.8453	1.2238

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.3258	.2204	1.9204	1.4251	1.4575	1.5729
2	.2829	.3086	.213	1.8884	1.7004	1.5546	1.6244
3	.3395	.3772	.2458	1.866	1.7652	1.6842	1.8842
4	.5601	.5487	.3277	1.9204	1.9109	1.9271	1.989
5	.695	.6344	.639	1.9433	2.1052	2.0729	2.0481
6	.8326	.823	.9012	2.1052	2.332	2.2024	2.1136
7	.9671	.7373	.852	2.1605	2.4129	2.2348	2.3758
8	.823	.6859	.8356	2.1862	2.4777	2.1862	2.4741
9	.6001		.7468	.6401	.664	.4534	.4144
10	.3772		.5487	.394	.3725	.2753	
11	.2572	.1989	1.6164	.2401	.2915	.1966	
12	.1543	.1989	1.9766	.1372	.2429	.1677	
13	.12	.116	.1097	.1029	.1296	.1187	.1463
14	.12	.0995	.128	.0857	.081	.1147	.1086
15			.1478	.0857	.081	.1174	.128
16			.1463	.12	.1943	.1147	.181
17	2.6406	2.3482	.2241	.1677	.2267		.3018
18	2.5377	2.7035	.3772	.3201	.3725	.4096	.6224
19	2.452	2.556	1.8842	.5487	.5992	.5868	.6602
20	2.4006	2.2119	1.9204	.4572	.421	.5426	.5228
21	2.332	2.13	2.0005	.3353	.3725	.4191	.4338
22	1.9033	1.9989	2.0317	.2439	.2429		.3734
23	1.9376		1.9919	.1829	.2105		.3361
24	1.0898	1.8861	1.8351	1.9433	.1829	.2267	.2515
Max	2.6406	2.7035	2.0317	2.1862	2.4777	2.2348	2.4741
Min	.12	.0995	.1097	.0857	.081	.1147	.1086
Avg	1.0758	1.0994	.9133	.9165	.8673	.9078	.9792

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1469	.9431	1.0159	.0754	.0648	.0648	
2	1.2003	1.0974		.0566	.081	.0648	.0671
3	1.186	1.2346	1.1142	.0943	.081	.0972	.0663
4	1.2651	1.3717	1.2289	.132	.1134	.1296	.1147
5	1.4403	1.3889	1.5061	.168	.1619	.1943	.1475
6	1.6194	1.6804	1.5708	.2829	.2267	.2591	.2818
7	1.8138	1.7833	1.5384	.3361	.2429	.3077	.2652
8	1.7284	1.869	1.491	.2743	.2591	.2591	.2543
9	.2058		.2801	1.4403	1.4089	1.5223	1.4746
10	.1372	.116	.0724	1.5813	1.6356	1.7328	1.5384
11	.0686	.0497	.0549	1.8004	1.668	1.8515	1.6324
12	.0514	.0509	.0549	1.8347	1.6194	1.8842	1.6804
13	.0514	.0497	.0549	1.7833	1.8299	1.8515	1.7394
14	.0514	.0509	.0543	1.8176	1.9595	1.4255	1.6356
15	.0514	.0492		1.8861	1.3279	1.4419	1.587
16	.0514	.0509	.0554	1.9033	1.4251	1.4255	1.0402
17	.0514	.0663	.0566	.0457	.0648		
18	.1372	.1696	.132	.0914	.1296	.1492	.2075
19	.2058	.2374	.2263	.1829	.1943	.2543	.2263
20	.1715	.2204	.1698	.1524	.1457	.2012	.1509
21	.1029		.0943	.0914	.1457	.1357	.1509
22	.0857	.0663	.0943	.0762	.081		.0943
23	.0686		.0754	.061	.0648		.0754
24	1.0898	.0514	.0663	.0754	.061	.0486	.0678
Max	1.8138	1.869	1.5708	1.9033	1.9595	1.8842	1.7394
Min	.0514	.0492	.0543	.0457	.061	.0486	.0663
Avg	.5826	.5999	.5003	.6768	.6247	.7286	.659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 201 / 11 KV RAMEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2259				.2259		.189
2	.2635		.1905		.8669	.7865	.9035
3	.3012				.9442		.865
4	.3734		.2286		1.1349		1.0913
5	.4108				1.1742		1.2044
6	.4854		.4191		1.2833	.9393	1.3169
7	.5228		.4572		.9012	1.1984	1.3993
8	.4668	.1334			1.373	1.1984	1.383
9		.2		1.1375		1.209	
10		.3048		.3012	.2667	.2071	
11		.7449	1.0002	.2241	.1143	.0934	
12	1.2713	1.004		.1307	.0762	.0934	
13			1.467	.112	.0762	.0747	.0667
14		1.3603		.0938	.0762	.0747	
15	1.3003	1.3603		.0751	.0762	.0747	
16		1.2955		.1127	.0762	.112	
17	1.3003	1.1984		.188	.0762	.1494	
18		1.166		.2447	.2286	.2614	
19	.3346	.4191	.3011	.3765	.4191	.3765	.3001
20		.381		.3765	.381	.378	
21				.3012		.2646	
22	.3346	.2667		.2259	.2286		
24	.7287		.1905		.2071	.1905	.189
Max	1.3003	1.3603	1.467	1.1375	1.373	1.209	1.3993
Min	.2259	.1334	.1905	.0751	.0762	.0747	.0667
Avg	.5943	.7565	.5318	.2786	.4860	.4268	.8098

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2447				.2259		.2268
2	.8688		.9831		.2627	.1905	.2641
3	1.1342				.3003		.2641
4	1.3565		1.2125		.3361	.3048	.3388
5	1.6671				.3734		.4141
6	1.7449		1.587		.4854	.4572	.4854
7	1.7897		1.7924		.5601	.6097	.5601
8	1.8309	2.0005			.5228	.4954	.5228
9		2.0073		.368		.4481	
10		.2667		.32	.3048	.32	
11		.1905	.1673	1.7028	1.7368	1.7337	
12	.2007	.1905		1.7337	1.9433	1.7469	
13		.1524	.1673	1.7939	1.8138	1.7646	.3334
14	.0335	.1524		1.925	2.0405	1.8454	
15	.0167	.1524		1.9726	1.9109	1.7984	
16		.1524		1.9608	2.0405	1.8299	
17	.1338	.1524		1.9805	2.0405	1.7604	
18		.2667		1.6038	1.9433	1.7243	
19	.4334	.4954	.4334	.5647	.4954	.4518	.4334
20		.4191		.5271	.4572	.4158	
21				.3765		.3409	
22	.2342	.3048		.3012	.3429		
24	1.0526		.2286		.1882	.2286	.2268
Max	1.8309	2.0073	1.7924	1.9805	2.0405	1.8454	.5601
Min	.0167	.1524	.1673	.3012	.1882	.1905	.2268
Avg	.8494	.4931	.8215	1.2236	.9678	.9719	.3700

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 203 / 11 KV GONDEGAN

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.9221
Max	.9221
Min	.9221
Avg	.9221

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 201 / 11 KV JAWALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 202 / 11 KV BODKA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.065
Max	1.065
Min	1.065
Avg	1.065

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154109 / 33/11 KV JAWALA

Feeder No / Name : 203 / 11 KV DHOKI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.9012
Max	.9012
Min	.9012
Avg	.9012

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 201 / 11KV Bhisewagholi SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.1022
Max	1.1022
Min	1.1022
Avg	1.1022

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 202 / 11kv Wadiwagholi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.0898
Max	1.0898
Min	1.0898
Avg	1.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 203 / 11kv Khuntephal SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.9496
Max	.9496
Min	.9496
Avg	.9496

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 157013 / 132/33 kv Niwali Sstn

Feeder No / Name : 402 / 33 kv Niwali feeder

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	4.0124
Max	4.0124
Min	4.0124
Avg	4.0124

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 157013 / 132/33 kv Niwali Sstn

Feeder No / Name : 403 / 33 kv Shirala feeder

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	4.5268
Max	4.5268
Min	4.5268
Avg	4.5268

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 158006 / 220/33 kv Murud EHV

Feeder No / Name : 401 / 33kv Murud Feeder

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	3.5608
Max	3.5608
Min	3.5608
Avg	3.5608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 201 / 11 Kv Renapur-I SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4287		.6859	.6001	.6001	.7716	.6859
16		1.0288		.3429		.8573	.6859
24	.3429		.3429	.3429			.4287
Max	.4287	1.0288	.6859	.6001	.6001	.8573	.6859
Min	.3429	1.0288	.3429	.3429	.6001	.7716	.4287
Avg	.3858	1.0288	.5144	.4286	.6001	.8145	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 202 / 11 Kv Mahapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144	1.9719	.4287	.4287	.8573	.6859
16			.5144		1.8861	1.6289
24	.2572	.3429	.2572			.3429
Max	.5144	1.9719	.5144	.4287	1.8861	1.6289
Min	.2572	.3429	.2572	.4287	.8573	.3429
Avg	.3858	1.1574	.4001	.4287	1.3717	.8859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 203 / 11 KV HANMANTWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3429		.1715	1.0288	.6859	.8573	.7716
16		.8573		.1715		.0857	.0857
24	.2572		.1715	.0857			.1715
Max	.3429	.8573	.1715	1.0288	.6859	.8573	.7716
Min	.2572	.8573	.1715	.0857	.6859	.0857	.0857
Avg	.3001	.8573	.1715	.4287	.6859	.4715	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 204 / 11 Kv Samsapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8916		2.0576	.7716	.3429	.6859	.8573
16		.3429		1.7147		2.0576	1.9719
23		.3429				.3429	
Max	.8916	.3429	2.0576	1.7147	.3429	2.0576	1.9719
Min	.8916	.3429	2.0576	.7716	.3429	.3429	.8573
Avg	.8916	.3429	2.0576	1.2432	.3429	1.0288	1.4146

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 205 / 11 Kv Phata SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4973		.4287	.5144	.4287	.5144	.4287
16		.2572		.2572		.1715	.2572
23		.1715					
24	.1715			.1715			.1715
Max	.4973	.2572	.4287	.5144	.4287	.5144	.4287
Min	.1715	.1715	.4287	.1715	.4287	.1715	.1715
Avg	.3344	.2144	.4287	.3144	.4287	.3430	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 206 / 11 Kv Renapur-II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.6859		.6859	.6001	.6859
16	.4287		.2572		.3429	
24		.3429				.2572
Max	.4287	.6859	.2572	.6859	.6001	.6859
Min	.4287	.3429	.2572	.6859	.3429	.2572
Avg	.4287	.5144	.2572	.6859	.4715	.4716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2865		.4096	.0934		.1966	.1629
4	.8573		.9012	.1646		.2458	.2481
6	.9282		1.0978	.3292		.2458	.3155
7		1.182			.3429		
8	.9012	1.2346	1.2452	.3582	.2743	.3277	.3155
9		1.3032					
10	.128	.1966	.1638	.1267	.1966	.1311	.2149
12	.0924	.1311	.0983	1.1683	1.4746	1.2616	.1254
14			.0373	1.5432	1.4091	1.2498	1.4175
16	.1029	.0983		1.7372	1.5402	1.1385	1.4175
17			.1109				
18		.213	.2172			1.1702	1.2323
20			.2507	.2743		.2507	.2534
21				.2743			
22			.1463			.1791	.1646
23	.12						
24	.1646	.0895	.1311	.0914	.1029	.1638	.1448
Max	.9282	1.3032	1.2452	1.7372	1.5402	1.2616	1.4175
Min	.0924	.0895	.0373	.0914	.1029	.1311	.1254
Avg	.3979	.5560	.4008	.5601	.7629	.5467	.5010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2172		.3441	.0914		.1638	.128
4	.823		.6226	.1829		.2458	.181
6	1.1142		1.0322	.3801		.2949	.3224
7		1.1305			.4424		
8	1.2811	1.1797	1.2125		.3277	.2785	.3544
9		1.2452					
10	.1463	.1966	.2458	.181	.1966	.0655	.2534
12	.0924	.1147	.1147	1.1363	1.2289	1.065	1.2289
14			.056	1.065	1.1142	1.1336	1.2146
16	.1075	.0492		1.1469	1.2125	1.1843	1.0688
17			.0739				
18		.2458	.3045			1.2334	.9991
20			.3258			.2507	.2172
22			.1646			.1448	.1109
23	.0983						
24	.0924	.0819	.0983	.0914	.0983	.1311	.1097
Max	1.2811	1.2452	1.2125	1.1469	1.2289	1.2334	1.2289
Min	.0924	.0492	.056	.0914	.0983	.0655	.1097
Avg	.4414	.5305	.3829	.5344	.6601	.5160	.5157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 203 / 11 Kv Bhokaramba SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0191			.0191			
7		.0179					
8	.0191	.0179	.0164	.0191	.0179		.0381
9		.0179					
10	.0191	.0164	.0164	.0191	.0164	.0164	.0191
12	.0191	.0328	.0164	.0191	.0164	.0164	.0191
14		.0164	.0191		.0164	.0191	.0381
16	.0358	.0328			.0164	.0191	.0381
17			.0191				
18		.0164				.0381	.0191
20						.0191	.0191
23	.0179						
Max	.0358	.0328	.0191	.0191	.0179	.0381	.0381
Min	.0179	.0164	.0164	.0191	.0164	.0164	.0191
Avg	.0217	.0211	.0175	.0191	.0167	.0214	.0272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.2058		.4801			.583
8	.5487	.583	.5144	.9431	.9945	.9774	1.046
12	.7888		.9431	.2401		.2572	
16		1.1317	1.0631	.1715	.1372	.1372	.0857
20	.2915				.2572	.3258	
24	.1372			.1372	.1372	.1543	.1543
Max	.7888	1.1317	1.0631	.9431	.9945	.9774	1.046
Min	.1372	.2058	.5144	.1372	.1372	.1372	.0857
Avg	.4416	.6402	.8402	.3944	.3815	.3704	.4673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	07-DEC-17
HR	Load (MW)
16	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 203 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	02-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)
12		.0857
16	.0171	
Max	.0171	.0857
Min	.0171	.0857
Avg	.0171	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.2193		1.0974	.3736	.9602	.8688	.5487
16		.3658		1.3969		1.0536	1.1279
24	.4115		.3963	.2027	.4115	.4572	.4268
Max	1.2193	.3658	1.0974	1.3969	.9602	1.0536	1.1279
Min	.4115	.3658	.3963	.2027	.4115	.4572	.4268
Avg	.8154	.3658	.7469	.6577	.6859	.7932	.7011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.3717	1.6956	.5093	.4268	.4908	.4854
16			1.7444		1.6032	1.5242
24	.1372	.1086	.1524	.1067	.181	.1448
Max	1.3717	1.6956	1.7444	.4268	1.6032	1.5242
Min	.1372	.1086	.1524	.1067	.181	.1448
Avg	.7545	.9021	.8020	.2668	.7583	.7181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu (J) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5335		.583	1.278	1.2498	1.3592	1.3592
16		1.085		.132		.1448	.1524
24			.2103	.2286		.2103	.2103
Max	.5335	1.085	.583	1.278	1.2498	1.3592	1.3592
Min	.5335	1.085	.2103	.132	1.2498	.1448	.1524
Avg	.5335	1.085	.3967	.5462	1.2498	.5714	.5740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 202 / Kamkheda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.2127					
8	2.0576		.12	.8573	.4382	.6173	.7164
12	.2686						
13					1.5775		
16	.1433	.1257	.1886	.0594	2.0576	2.0774	2.0576
20	.5611					.5487	
24	.2401		.1619	.2229	.1585		.2896
Max	2.0576	1.2127	.1886	.8573	2.0576	2.0774	2.0576
Min	.1433	.1257	.12	.0594	.1585	.5487	.2896
Avg	.6541	.6692	.1568	.3799	1.0580	1.0811	1.0212

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 204 / Wanjarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.181					
8	.6001	.6089	.631	2.2291	2.4326	2.6578	2.8117
12	2.9371					.1254	
13					.1029		
16	2.4177	2.6406	2.7435	.1509	.1543	.1433	
20	.3982					.362	
24	.1543		.2328	.1543	.1928		.1629
Max	2.9371	2.6406	2.7435	2.2291	2.4326	2.6578	2.8117
Min	.1543	.181	.2328	.1509	.1029	.1254	.1629
Avg	1.3015	1.1435	1.2024	.8448	.7207	.8221	1.4873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 205 / Faradpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1267					
8	.2915	.3258	.3224	.6173	.7045	.7716	.6447
12	.6626					.0724	
13					.0514		
16	.6626	.7611	.7545	.1029	.0857	.0716	.0686
20	.2172					.2195	
24	.1029		.1267	.1029	.1075		.1086
Max	.6626	.7611	.7545	.6173	.7045	.7716	.6447
Min	.1029	.1267	.1267	.1029	.0514	.0716	.0686
Avg	.3874	.4045	.4012	.2744	.2373	.2838	.2740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 206 / Wala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.267					
8	2.1434	2.2744	2.0005	.7202	.7042	.6173	.7701
12	.197					1.8267	
13					2.0576		
16	.1612	.16	.1372	1.7124	1.9204	2.0595	2.2977
20	.543					.5249	
24	.2229		.2686	.2401	.2686		.2534
Max	2.1434	2.2744	2.0005	1.7124	2.0576	2.0595	2.2977
Min	.1612	.16	.1372	.2401	.2686	.5249	.2534
Avg	.6535	1.2338	.8021	.8909	1.2377	1.2571	1.1071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1029	.1029	.1109	.12	.112	.1372
2	.2058	.2058	.2401	.112	.12	.1109	.1372
3	.2058	.2572	.3429	.1109	.1372	.112	.1372
4	.2915	.3086	.421	.1848	.1715	.2801	.1715
5	.3605	.4287	.4534	.2241	.2401	.3734	.2572
6	.4915	.4801	.583	.3142	.3086	.4066	.3086
7	.5992	.5487	.6154	.4066	.3772	.4805	.4115
8	.5668	.583	.6154	.3734	.3772	.3696	.3429
9	.6401	.583	.583	.3086	.2743	.2957	.2743
10	.1372	.1886	.2561	.1372	.2054	.1372	.2058
11	.1372		.1478	.5487	.5197	.5144	.421
12		.1372	.0934	.5144	.5182	.5658	.583
13	.0857	.1029	.0934	.4801	.4588	.583	.5506
14	.0857	.0857	.0934	.4458	.4858	.5144	.5506
15	.0686	.0686	.0747	.6173	.4915	.463	.5506
16	.0857	.0686	.0747	.6001	.4424	.4801	.5506
17	.0857	.0857	.1848	.6516	.4858	.6344	.5182
18	.1886	.1886	.2427	.6001	.5182	.5144	.4858
19	.2743	.2743	.2218	.2915	.2218	.2743	.2743
20	.2401	.2401	.2218	.2058	.2241	.2401	.2401
21	.2058	.2058	.1867	.1715	.1848	.1715	.2058
22		.1372	.1478		.1478		.1715
23		.1372	.1494		.1109		.1372
24	.1109	.1029	.1029	.112	.12	.1109	.1372
Max	.6401	.583	.6154	.6516	.5197	.6344	.583
Min	.0686	.0686	.0747	.1109	.1109	.1109	.1372
Avg	.2466	.2401	.2604	.3419	.3026	.3520	.3233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 202 / 11 KV BHRAMWADI -Ghavan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1543	.1029	.1494	.1029	.1132	.1029
2	.298	.3086	.583	.1509	.1029	.1143	.1029
3	.3429	.3601	.7773	.1494	.1029	.1524	.1029
4	.5487	.6516	.9069	.1867	.1543	.1886	.1543
5	1.0059	1.0288	1.2955	.2801	.2058	.2801	.2572
6	1.3927	1.2003	1.4575	.3734	.2572	.3734	.3086
7	1.4255	1.4918	1.5061	.4108	.3086	.4481	.3601
8	1.6194	1.6975	1.5546	.1132	.2572	.3361	
9	1.4575	1.6975	2.915	.1543	.2058	.2987	.2058
10		.1543	.2241	.1029		.1543	
11	.1543	.1029	.168	1.1317			1.1174
12	.1029	.0514	.0754	1.286	1.4251		1.3441
13	.0514	.0514	.056	1.4403	1.4746		1.4575
14	.0514	.0514	.0566	1.3889	1.4746	1.7147	1.4089
15	.0514	.0514	.0566	1.286	1.4575	1.7147	1.4575
16		.0514	.0566	1.4403	1.4737	1.5432	1.4575
17		.0514	.1478	1.3889	1.4746	1.5432	1.4575
18		.1543	.2241	1.1317	1.4251	1.4918	1.2146
19	.2401	.2743	.2772	.2572	.1867	.2572	.2401
20	.3086	.2401	.2614	.2058	.2241	.2058	.2058
21	.2572	.2058	.1867	.2058	.2263	.1543	.1715
22		.1543	.168		.1698		.1543
23		.1543	.1509		.1494		.1029
24	.1509	.1543	.1029	.1132	.1029	.1509	.1029
Max	1.6194	1.6975	2.915	1.4403	1.4746	1.7147	1.4575
Min	.0514	.0514	.056	.1029	.1029	.1132	.1029
Avg	.5338	.4372	.5546	.6067	.5892	.5913	.6131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2229	.2058	.2241	.2058	.2241	.2229
2	.2241	.2229	.2229	.298	.3086	.4287	.3429
3	.2614	.2229	.2401	.3772	.3772	.5868	.4287
4	.3734	.2572	.2743	.4748	.5144	.5801	.6001
5	.5041	.3429	.3429	.5935	.6516	.7373	.6859
6	.5544	.4287	.4458	.7042	.7716	.9012	.7716
7	.5788	.5316	.4801	.779	.9259	.9175	.8916
8	.5601	.5487	.4458	.852	.9088	.9231	.9602
9	.4066	.4801	.3944	.823	.8573	.8259	.8573
10	.3258	.3086	.3361	.2572	.2957	.2572	.2401
11	.6687	.6478	.5765	.2229	.2263	.2058	.2058
12		.6964	.503	.1715	.1848	.1715	.1715
13	.5144		.7537	.1029	.1494	.1372	.1372
14	.6001	.664	.7373	.12	.1294	.1372	.1372
15	.8573	.7125	.7209	.12	.1109	.1372	.1372
16	.8916	.3887	.8322	.12	.1494	.1372	.1372
17	.8573	.6478	.8002	.2401	.1867	.1543	.2401
18	.7716		.6718	.3601	.2801	.3086	.4115
19	.463	.4458	.2402	.4287	.3734	.4115	.4458
20	.3944	.4115	.4108	.3601	.4668	.3772	.3772
21	.3601	.3429	.3326	.3086	.4108	.3429	.3429
22		.2743	.2801		.2614		.3086
23		.2401	.2241		.2241		.2743
24	.2427	.2229	.2058	.2218	.2058	.2427	.2229
Max	.8916	.7125	.8322	.852	.9259	.9231	.9602
Min	.2241	.2229	.2058	.1029	.1109	.1372	.1372
Avg	.5064	.4210	.4449	.3709	.3823	.4157	.3979

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 203 / 11KV Khanapur(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2241			1.0903	.7468	1.1576	1.1643
4	.2241			1.9774		1.8671	2.0883
6				2.384			3.0862
7	.2614				2.9874	2.9874	
8	.2614		.2987	3.0247	3.3608	3.5475	3.3265
9				3.062			
10		.2241		.2241	.2587		.1478
11				.1494			
12		3.3608	3.1417	.1494	.1478	.1867	.1848
13						.1867	
14		3.5475		.1867	.1848		.1848
15				.2241			
16				.1867			
17		3.3608			.1494		.1494
18					.1494	.2218	
19				.0373			
20		.2987			.2614	.2957	.2614
21				.2987	.2614		
22		.2987				.2587	
23					.2614		
24	.2614			.2218			.2587
Max	.2614	3.5475	3.1417	3.062	3.3608	3.5475	3.3265
Min	.2241	.2241	.2987	.0373	.1478	.1867	.1478
Avg	.2465	1.8484	1.7202	.9440	.7972	1.1899	1.0852

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.961		.2054	.037		.037	.0366
4	1.5524			.037		.037	.037
6				.0366			.037
7	2.6057				.0373	.037	
8	1.1827		3.1741	.0366	.0373	.037	.0366
9				.037	.0373		
10		.0373		.037	.037		
12		.0373	.037	2.7721	1.8296	2.6139	2.5503
13						2.8006	
14		.0373		2.8275	2.6797		2.6612
15				2.3655			
16				2.809		2.6139	
17		.0373			2.5873		2.6139
18					2.5318	.5175	
19				.0373			
20		.0373			.037	.037	.0373
21				.0373	.037		
22		.0373				.037	
23					.037		
24	.037			.037			.037
Max	2.6057	.0373	3.1741	2.8275	2.6797	2.8006	2.6612
Min	.037	.0373	.037	.0366	.037	.037	.0366
Avg	1.2678	.0373	1.1388	.8544	.8989	.8768	.8941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 206 / 11kv Old midc of 33KV AUSA SHEDDABLE FEEDER HAVING WEEKLY
sub Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.0934		.0739		.0934	.1109
4	.0934		.1109		.0934	.0739
6			.1294			.037
7	.1307				.112	
8	.0934		.0924		.0934	.0924
9			.112			
10			.1307	.0739		.2402
12		.1663	.1867	.1848		.3326
14			.2427	.1478		.2033
15			.1867			
16			.2801			
17				.1307		
18				.1494		
20				.056	.0739	
21				.056		
22					.0739	
23				.0934		
24	.112		.1109			.0747
Max	.1307	.1663	.2801	.1848	.112	.3326
Min	.0934	.1663	.0739	.056	.0739	.037
Avg	.1046	.1663	.1506	.1115	.09	.1456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Karajgaon gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1109		.0747	.1254	.2054	.1109	.0924
4	.1294			.1663		.1294	.1663
6				.2587			.2218
7	.2033				.2241	.2587	
8	.1848		.1867	.1478	.1867	.1848	.1663
9				.1294			
10		.112		.0739	.0924		
12		.112	.0895	.0739	.0924	.0747	.1109
13						.0934	
14				.0739	.0924		.0924
15				.0554			
16				.0739		.0747	
17					.0924		
18					.1294		
19				.112			
20		.1867			.1848	.1663	.1867
21				.168	.1848		
22		.112				.1294	
23					.1109		
24	.1109			.1294			.0924
Max	.2033	.1867	.1867	.2587	.2241	.2587	.2218
Min	.1109	.112	.0747	.0554	.0924	.0747	.0924
Avg	.1479	.1307	.1170	.1222	.1451	.1358	.1412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 208 / 11 KV Almala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2033	.2957		.2218	.2033
4	.2957	.2957		2.7166	.3142
6		.4805			.5175
7	.5544			.5729	
8	.3881	.4805		.462	.3511
9		.4066			
10		.3142	.2772		.3326
12		.2402	.1848		.2587
14		.2033	.2033		.0554
15		.2033			
16		.2033			
17			.2772		
18			.3881	.3326	
20			.4066	.3881	
21			.3696		
22				.2772	
23			.2772		
24	.2033	.2587			.2033
Max	.5544	.4805	.4066	2.7166	.5175
Min	.2033	.2033	.1848	.2218	.0554
Avg	.3290	.3075	.298	.7102	.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 202 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
1	.0988	.115
2	.1152	.1314
3	.1481	.1478
4	.1975	.1642
5	.2305	.1971
6	.2634	.1971
7	.2963	.2956
8	.2628	.2792
24	.0988	.0985
Max	.2963	.2956
Min	.0988	.0985
Avg	.1902	.1807

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 203 / 11KV Baranpur Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
1	1.062	1.1414
2	1.2612	1.2756
3	1.3428	1.3428
4	1.4099	1.3764
5	1.5442	1.4099
6	1.6785	1.5106
7	1.7624	1.6449
8	1.7456	1.5778
24	.6638	.705
Max	1.7624	1.6449
Min	.6638	.705
Avg	1.3856	1.3316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154021 / 33KV Bhada S/S

Feeder No / Name : 205 / utti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)
1	.3121	.2896
2	.3467	.3077
3	.3814	.3258
4	.3814	.3982
5	.4161	.4344
6	.4508	.4706
7	.5201	.543
8	.4161	.4887
24	.3121	.2896
Max	.5201	.543
Min	.3121	.2896
Avg	.3930	.3942

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.6859		
8			.2591			1.1279
10					.1715	
11		.6097				
14		1.0059				
16	1.1317				.061	
23			.9945			
24		.0857		.0857		
Max	1.1317	1.0059	.9945	.6859	.1715	1.1279
Min	1.1317	.0857	.2591	.0857	.061	1.1279
Avg	1.1317	.5671	.6268	.3858	.1163	1.1279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				.3086		
8			1.7833			.1829
10					.1372	
11		.061				
14		.0457				
16	.0514		.0857		1.4784	
24		.1372		.1372		
Max	.0514	.1372	1.7833	.3086	1.4784	.1829
Min	.0514	.0457	.0857	.1372	.1372	.1829
Avg	.0514	.0813	.9345	.2229	.8078	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 203 / Hasegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6				1.0802		
8			.381			.1524
10					.2401	
11		.5182				
14		.8688				
16	1.1488		1.3717		.1372	
24				.1543		
Max	1.1488	.8688	1.3717	1.0802	.2401	.1524
Min	1.1488	.5182	.381	.1543	.1372	.1524
Avg	1.1488	.6935	.8764	.6173	.1887	.1524

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 202 / 11kv water works express NON SHEDDABLE WATER SUPPLY AND
 feede Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0857	.0686		.0686	.0743	.0171	.0667
16	.0686				.0857	.0686	.0857
18			.0857				
24	.0857	.0857		.0857		.0857	
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0686	.0686	.0857	.0686	.0743	.0171	.0667
Avg	.08	.0772	.0857	.0772	.08	.0571	.0762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 204 / Devtala Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.2439
8	1.6632	1.5432		.703	.6859	.6001	.6554
16	.2058				.4287	1.5432	1.5432
18			.463				
19				.381			
24	.2229	.2401		.2229		.2743	
Max	1.6632	1.5432	.463	.703	.6859	1.5432	1.5432
Min	.2058	.2401	.463	.2229	.4287	.2743	.2439
Avg	.6973	.8917	.463	.4356	.5573	.8059	.8142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 205 / Kavli Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.4287
8	2.2634	2.2977		1.5089	1.448	2.452	.6859
16	1.1145			1.9719	2.0576	2.0748	1.3717
18			2.3148				
24	.6516	.6001		1.5432		.703	
Max	2.2634	2.2977	2.3148	1.9719	2.0576	2.452	1.3717
Min	.6516	.6001	2.3148	1.5089	1.448	.703	.4287
Avg	1.3432	1.4489	2.3148	1.6747	1.7528	1.7433	.8288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 201 / 11kv Belkund SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.2858	
4					.3048	.2858	
8		1.7436			.381	1.0059	
10	.3353		.2515		.2515	.5365	.2515
11	.2801						
12	.2195			.4572	1.6766		
13	.2054						
14	.1928				1.5927		
15	.2035						
16		.2515	.2515	1.3717	1.6385	1.0059	
17	.2715						
18	.4382						
19	.7701						
20				.2286			
21	.4572						
23				.3048			
24		.3018			.2286	.2858	
Max	.7701	1.7436	.2515	1.3717	1.6766	1.0059	.2515
Min	.1928	.2515	.2515	.2286	.2286	.2858	.2515
Avg	.3374	.7656	.2515	.5906	.8677	.5676	.2515

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 204 / Gukheda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3163	
4					1.829	1.5813	
8		.4744			2.7435	2.5301	
10	.2372		.2372		.4744		1.7394
11	1.9766				.3163		
12	2.8464						
13	2.8464						
14	2.8464				.2372		
15	2.9254						
16		2.8464	2.372	.2286	.2372	.1581	
17	2.6882						
18	2.5301						
19	.3953						
20				.3048			
21	.4744						
23				.3048			
24		.2372			.381	.3163	
Max	2.9254	2.8464	2.372	.3048	2.7435	2.5301	1.7394
Min	.2372	.2372	.2372	.2286	.2372	.1581	1.7394
Avg	1.9766	1.186	1.3046	.2794	.8884	.9804	1.7394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 206 / Davakhana Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4					.0191	.0373	
8		.0934			.0476	.056	
10	.0291		.0373		.0914	.056	.0934
11	.0629						
12	.0619			.0191	.0934		
13	.0619						
14	.0619				.0934		
15	.0619						
16		.0934	.0934	.0476	.0934	.0934	
17	.0753						
18	.0734						
19	.0734						
20				.0305			
21	.0373						
23				.0305			
24		.0373			.0191	.0373	
Max	.0753	.0934	.0934	.0476	.0934	.0934	.0934
Min	.0291	.0373	.0373	.0191	.0191	.0373	.0934
Avg	.0599	.0747	.0654	.0319	.0653	.056	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.2267	.2454	.2321	.2321	.2454	.2652
2	.2267	.2267	.2454	.7373	.8192	.9114	.7373
3	.2591	.2591	.2454	1.2955	1.7004	1.8861	1.5223
4	.3887		.3155	1.5384	1.9433	2.4006	2.0243
5	.5182	.5506	.3856	1.7004	2.1376	2.7435	2.2725
6	.6154	.6478	.5258	2.1765	2.3205	2.8292	2.5301
7	.7935	.8097	.5959	2.3403	2.4646	2.915	2.5617
8	.7125	.6154	.4557	2.5301	2.6882	1.3717	2.8292
9	.6154	.5182	.5959	2.5301	2.4827	1.7147	2.4348
10	.421	.3239	.3277	.4096	.4108	.3086	.3429
11	1.4899	2.0576	1.7814	.2486	.2454	.2321	.2058
12	2.1052	2.7092	2.4985	.1989	.1715	.1989	.1715
13	1.9433	3.0521	2.6882	.1658	.1715	.1658	.1715
14	2.7854	2.9835	2.6882		.1753		.1715
15	.2591	2.915	2.7199		.1715		.1715
16		2.915	2.7199		.1715	.1658	.2058
17	2.7854	2.4006	2.7199		.1715	.2984	.2401
18	1.9433	2.4348	2.625	.4588	.5144	.4915	.3086
19	.6802	.6859	.6478	.5898	.583	.7373	.6859
20		.5609	.6226	.5243	.583	.6226	.6173
21	.3887	.4207	.4588	.3932	.3772	.4915	.5144
22	.2915	.3506	.2818	.2652	.2743	.3481	.3429
23	.2591	.2454	.2486	.2321	.2743	.2652	.2743
24	.2267	.2267	.2454	.2321	.2321	.2454	.2652
Max	2.7854	3.0521	2.7199	2.5301	2.6882	2.915	2.8292
Min	.2267	.2267	.2454	.1658	.1715	.1658	.1715
Avg	.9061	1.2233	1.1202	.9400	.8882	.9813	.9111

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1509	.1509	.0924	.1294	.1494	.1478
2	.1886	.1886	.3361	.0924	.0924	.1494	.1478
3	.415	.4527	.4854	.1109	.0924	.1509	.1478
4	.679	.5658	.5601	.1848	.1663	.1886	.2218
5	.8299	.9054	.9335	.2587	.3292	.2987	.3841
6	1.0562	1.1694	1.1203	.3292	.5121	.4108	.5121
7	1.2071	1.3203	1.307	.4066		.5487	.5792
8	1.358	1.2449	1.3443	.4024	.5792	.5601	.5041
9	1.358	1.2826	1.2696	.3658	.5121	.4108	.4108
10			.3292	.2926	.3921	.1867	.3361
11			.1663	.6154	.9335		.5601
12	.1132		.1109	.905	1.0456	.823	1.1203
13	.1509	.0943	.1109	1.0745	1.0829	.9774	1.1949
14	.1509	.0754	.0924	1.1104	1.1203	1.0136	1.1949
15	.1132	.0754	.0924	1.1104	1.1576	1.1104	1.1576
16	.1509		.1294	1.1765	1.1949	1.1104	1.2323
17	.1886	.1867	.1848	1.2308	1.1949	1.1104	1.307
18	.4527	.3734	.3142	1.1222	1.0456	1.1283	1.2323
19	.4904	.5228	.439	.4572	.4481	.3658	.3734
20	.415	.3734	.3658	.3658	.3734	.3292	.3734
21	.2641	.2614	.3326	.3326	.2614	.2772	.2614
22	.1886	.1867	.2218	.2587	.1867	.1478	.1867
23	.1886	.1494	.1294	.1848	.1494	.1478	.1494
24	.1509	.1509	.1509	.1294	.1478	.1494	.1478
Max	1.358	1.3203	1.3443	1.2308	1.1949	1.1283	1.307
Min	.1132	.0754	.0924	.0924	.0924	.1478	.1478
Avg	.4664	.4865	.4449	.5254	.5716	.5106	.5785

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 201 / 11 KV Pethe SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.12	.1955	.1715		.1715	.1372
5		.12	.1635				
7				.1715		.1372	.1372
8	.1715		.1962	.1715	.1715		.1715
9		.1372	.2572	.1715		.1715	.1715
10	.2572		.2572	.2058	.2572		.1715
11		.1635	.2572			.1715	
12	.2572						.3269
13		.1962					
14	.3429		.2572	.3429		.1715	.3596
15		.2452					
16	.3429		.2572	.4287		.1715	.3596
17		.2942	.2572			.1715	
18	.1715	.2942	.2572	.3429		.1715	.3596
19		.2942					.3596
20	.1372		.1715			.1715	
21		.1962		.1715			.0981
22	.1372		.1715				
23		.1962	.1715			.1715	.1303
24	.1715	.12	.1955	.1715	.1715	.1715	.1715
Max	.3429	.2942	.2572	.4287	.2572	.1715	.3596
Min	.1372	.12	.1635	.1715	.1715	.1372	.0981
Avg	.2210	.1981	.2190	.2349	.2001	.1684	.2272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 202 / 11kv Selu SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429	.3269	.12		.1372	.12
5		.8573	1.6347				
7				.1715		.1715	.1307
8	1.3717		1.9616	.1715	.1715		.1372
9		1.3717		.12		.1372	.1494
10	.1715		.0981	.0857	.1715		.1372
11		.1308	.12			.1715	
12	.0857						1.6347
14	.0857		.0857	1.7147		3.0864	1.6347
15		.0817					
16	.0857		.0857	1.8861		3.0864	1.6347
17		.0817	.0857			3.2579	
18	.1372	.1308	.1715	1.7147		2.7435	1.6347
19		.1635					.1635
20	.1715		.2058			.2572	
21		.1635		.2572			.1308
22	.1372		.1715				
23		.1303	.12			.1715	.1349
24	.1715	.1372	.1303	.12	.1715	.1372	.1715
Max	1.3717	1.3717	1.9616	1.8861	.1715	3.2579	1.6347
Min	.0857	.0817	.0857	.0857	.1715	.1372	.12
Avg	.2686	.3265	.3998	.6361	.1715	1.2143	.6011

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 203 / 11kv Almala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0857	.0817	.6859		.0857	.3429
5			.0817				
7				1.7147		1.7147	1.8861
8	.0857		.0817	2.0576	2.2291		2.0576
9		.0857	.0857	2.0576		1.9719	2.0576
10				.0857	.0857		.0857
11		.5721	1.0288				
12	2.572						.0817
13		1.6347					
14	2.7435		2.4006	.0857		.0857	.0817
15		2.2885					
16	2.7435		2.572	.0857		.0857	.091
17		2.452	2.2291			.0857	
18	2.4006	1.9616	1.8861			.0857	.0817
19		.0817					.0817
20	.0857		.0857			.0857	
21		.0846		.0857			.0817
22	.0857		.0857				
23		.0817	.0857			.0857	.0814
24	.0857		.203	.0857	.0857	.0857	.0857
Max	2.7435	2.452	2.572	2.0576	2.2291	1.9719	2.0576
Min	.0857	.0817	.0817	.0857	.0857	.0857	.0814
Avg	1.3503	.9328	.8390	.7716	.8002	.4372	.5459

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 204 / Khuntegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429	.3269	.12		.1372	.12
5		.7716	.9808				
7				.12		.2058	.2229
8	1.0288		1.1728	.12	.1715		.1715
9		.6859		.0857		.1372	.1715
10	.0857		.0981	.0857	.0857		.12
11		.0981	.0857				
12	.0857						.9808
13		.2942					
14	.0857		.0857	.9431		1.1145	1.0625
15		.0327					
16	.0857		.0857	1.1145		1.2003	1.1116
17		.0817	.0857			1.2003	
18	.1715	.1308	.1715			1.1145	.9808
19		.1635					.1635
20	.2058		.1715			.1886	
21		.1629		.1715			.1308
22	.1715		.1715				
23		.0981	.12				.1308
24	.0857	.1372	.0981	.12	.1715	.1372	.1372
Max	1.0288	.7716	1.1728	1.1145	.1715	1.2003	1.1116
Min	.0857	.0327	.0857	.0857	.0857	.1372	.12
Avg	.2229	.2500	.2811	.3201	.1429	.6040	.4234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 205 / 11KV Budhoda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1372	.1308	.1715		.1715	.1715
5		.1372	.1635				
7				.2229		.2572	.2915
8	.3429		.2606	.2572	.2572		.3429
9		.2058		.2915		.2572	.3429
10	.1715		.1635		.1715		.1715
11		.1308	.2058			.1715	
12	.2058						.1308
13		.2942					
14	.3086		.3429	.0857		.1372	.1308
15		.1635					
16	.2743		.3429	.0857		.12	.1308
17		.2942	.3429			.1372	
18	.2572	.2779	.2572	.2572		.2058	.2289
19		.2615					.2942
20	.2572		.2572			.3429	
21		.2615		.1715			.2289
22	.1715		.2572				
23		.2289	.1715			.1715	.1635
24	.1715	.1372	.2538	.1715	.1715	.1715	.1715
Max	.3429	.2942	.3429	.2915	.2572	.3429	.3429
Min	.1715	.1308	.1308	.0857	.1715	.12	.1308
Avg	.2401	.2108	.2423	.1905	.2001	.1949	.2154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 206 / 11KV Hasala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2572	.1955	.3429		.3429	.3429
5		.3429	.2615				
7				1.0288		1.286	1.5432
8	.3429		.3269	1.1145	1.4575		1.6289
9		.2572		1.0802		1.3375	1.6289
10	.2572		.2942	.3429	.3429		.3429
11		.6539	.8573			.2058	
12	.9431						.1635
13		1.1443					
14	.6859		1.0288	.1715		.1715	.1635
15		.2942					
16	1.406		1.0288	.1715		.0857	.1308
17		.9808	1.0288			.12	
18	1.1145	.85	1.1145	.4287		.3429	.3433
19	1.1145	.2942					.4577
20	.2572		.3429			.5144	
21		.3584		.4287			
22	.3429		.2915				.3923
23		.2942	.2572				.2942
24	.2572	.2743	.0147	.2572	.3429	.3429	.2915
Max	1.406	1.1443	1.1145	1.1145	1.4575	1.3375	1.6289
Min	.2572	.2572	.0147	.1715	.3429	.0857	.1308
Avg	.6721	.5001	.5417	.5367	.7144	.4750	.5941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 201 / 11KV Tungi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2641	.2683	.3018	.2829		.3018	.2572
4	.415	.3429	.4527	.4668	.3121	.431	.4287
6	.547	.5228	.6036	.6036		.5636	.5609
8	.4527		.5658	.4572	.4024	.5304	.5083
10	2.452	2.5652	2.5606	.1267		.2987	.2241
12	2.6886	2.6783	2.8006	.1867		.1867	.1619
14	2.7161	2.7538	2.6406				
16	2.4006	2.6406	2.5463		.128	.1494	
18	.4954		.4382	2.3537	2.3482	2.894	2.5526
20	.3052	.5281	.4108	2.2672	2.6783	2.4577	2.1125
22	.2949	.3395	.2829	2.1052	2.4897	2.0119	2.0729
23	2.6886						
24	.2641	.2054	.2641	.2801	.2401	2.1691	2.0348
Max	2.7161	2.7538	2.8006	2.3537	2.6783	2.894	2.5526
Min	.2641	.2054	.2641	.1267	.128	.1494	.1619
Avg	1.2296	1.2845	1.1557	.9130	1.2284	1.0904	1.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 202 / 11 KV Nagarsoga Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.415	.4024	.4527	1.6975	1.5432	1.4255	1.4575
4	.6413	.4458	.679	1.7737	1.6991	1.8233	1.9719
6	.9054	.7468	.9431	1.8107	2.1033	2.1548	2.1033
8	.9054	.8131	.9054	.4706	2.1795	2.1879	
10	.5258		.4024	.2614	.4062	.3361	.3521
12			.2801	.2801	.2881	.168	.2267
14	.3395		.2263	.1867	.2241	.2054	.2267
16	.3086	.415	.2829	.2829	.192	.2241	.2267
18	2.5911	2.7435	2.572		.3563	.6348	.431
20	1.933	2.4143	2.1472	2.1472	.6413	.6554	.4801
22	1.704	2.037	2.1125	2.1125	.4527	.3688	.3887
24	1.7353	1.467	1.8861	1.6975	.2881	.3395	.3222
Max	2.5911	2.7435	2.572	2.1472	2.1795	2.1879	2.1033
Min	.3086	.4024	.2263	.1867	.192	.168	.2267
Avg	1.0913	1.2761	1.0741	1.1564	.8645	.8770	.7443

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 203 / 11KV Gadavewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	2.3765	2.4143	2.8669	.1886	.2058	.1658	.1715
4	2.5274	2.7778	3.0178	.3361	.2254	.3315	.3086
6	2.5652	3.062	3.1687	.5093	.5258	.4973	.4908
8	2.3388	3.1417	3.0178	.4382	.4024	.431	
10	.2641	.2641	.1829	2.9321	2.3434	2.894	2.4646
12	.112	.1886	.112	3.1367	2.5286	3.006	2.4291
14	.1886	.1132	.1132	3.2861	2.5101	3.0807	2.5911
16	.1029	.1886	.1132		2.3868	2.9874	2.4615
17				2.4691			
18	.2667	.2286	.2667	.2652		.2614	
20	.3052	.3395	.3174	.3239	.3772	.4096	.2881
22	.2294	.2263	.2641	.2267	.2641	.2347	.2267
24	.1886	.1467	.1886	.2054	.16	.1886	.1865
Max	2.5652	3.1417	3.1687	3.2861	2.5286	3.0807	2.5911
Min	.1029	.1132	.112	.1886	.16	.1658	.1715
Avg	.9555	1.0910	1.1358	1.1931	1.0845	1.2073	1.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3039	.3213	.3223	.2651	.3184	.3412	.3036
2	.6029	1.1633	1.2696	.3042	.3558	.3573	.3416
3	2.1672	1.9776	1.7499	.3419	.3555	.3791	.4175
4	2.3158	2.079	2.0929	.4934	.4518	.4175	.5308
5	2.4263	2.2801	2.4434		.6036	.5698	.7583
6	2.7315	2.6089	2.6216	.8711	.9054	.909	.9459
7	2.8437	3.1305	2.9126	1.0206	1.0206	1.0395	1.0206
8	2.9637	1.6823	2.8826	.9828	.9838	.872	1.0605
9	.7598	2.5489	2.8688	.6054	.8307	.6628	.7567
10		.5292	.4554	.6888	1.6723	1.6388	.4141
11	.4175	.3033	.3036	2.4674	2.9007	2.6002	.2651
12	.3803	.2096	.2279	3.0178	2.9608	2.6092	.1898
13	.3042	.1903	.1898	2.7863	2.9843	2.7433	2.6567
14	.2469	.2096	.1521	2.9709	2.8637	2.8006	2.8302
15	.2277	.2282	.0951	2.6352	2.7515	2.8664	2.9709
16	.1898	.2094	.1141	2.9675	2.6551	2.7346	2.7161
17	.3229	.3039		3.0281	2.5917	2.4701	2.7958
18	.5693	.6439	.1521	.6432	.6275	.5693	.6445
19	.759	.759	.4563	.7204	.7788	.6804	.7211
20	.4739	.5118	.6432	.567	.6066	.5687	.5108
21	.3969	.417	.417	.4531	.3973	.4563	.4531
22	.378	.3799	.3405	.3753	.3953	.3795	.3961
23	.3402	.3423	.3036	.2993	.3772	.3803	.3761
24	.2659	.3213	.3036	.2649	.2981	.3788	.3423
Max	2.9637	3.1305	2.9126	3.0281	2.9843	2.8664	2.9709
Min	.1898	.1903	.0951	.2649	.2981	.3412	.1898
Avg	.9734	.9729	1.0138	1.2509	1.2786	1.2260	1.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 202 / 11 KV Bheta Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0128	1.0155	1.0364	.9442	.1905	.2277	.1898
2	.2268	.189	.1901	.8738	.9488	.6043	.6898
3	.3416	.2275	.2279	1.0037		.9568	1.1267
4	.4179	.3423	.2467	1.1349	1.0876	1.0909	1.109
5	.4924	.5144	.2849	1.3336	1.2988	1.3186	1.1603
6	.5693	.6287	.4183	1.432	1.4353	1.4519	1.2264
7	.6432	.7225	.5514	1.5337	1.5873	1.5295	1.3373
8	.6831	.7218	.4749	1.5123	1.4979	1.5302	1.3923
9		.5324	.4373	1.4468	1.4379	1.5101	1.3457
10	.3803	.2852	.3784	.3412	.2467	.1898	1.0864
11	.1334	.1715	.2662	.1524		.1518	.9627
12		.1141		.1136		.1141	1.0582
13		.1142	.1143	.1326		.1141	.0761
14	.1494	.1331		.0946	.1331	.1143	
15	.1494	.114		.0953	.1141	.0762	
16	.1494	.0952		.1143	.1141	.0762	
17	.1518	.2277	.1899	.1331	.1903	.1143	.1521
18	1.1605	1.1003	1.0002	.3042	.2849	.2657	.3232
19	1.317	1.349	1.326	.5303	.5704	.5693	.5313
20	1.2367	1.1874	1.2394	.455	.455	.4554	.3989
21	1.0869	1.1772	1.1962	.3226	.3409	.3795	.3423
22	1.0936	1.1591	1.1603	.2464	.2832	.3036	.2852
23	1.0623	1.1363	1.1191	.2085	.2464	.2662	.2667
24	1.0466	1.0467	1.0588	1.0501	.2096	.2085	.2279
Max	1.317	1.349	1.326	1.5337	1.5873	1.5302	1.3923
Min	.1334	.0952	.1143	.0946	.1141	.0762	.0761
Avg	.6431	.5960	.6458	.6462	.6336	.5675	.7280

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 201 / 11KV Shivali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201	.3201	.3953		1.8023	1.4403	1.3117
2	.3201	.3201	.3163		1.9662	1.4403	1.3889
3	.3201	.3201	.3163		1.9662	1.6004	
4	.3201	.3201	.3953		2.0481	1.7604	1.7747
5	.3201	.4001	.4744		2.13	1.9204	2.0062
6	.4001	.4801	.4687		2.2119	2.0005	2.1605
7	.4801		.5468		2.4577	2.0805	
8	.4801		.6249		2.4577	2.1605	2.0062
9	.4801		.4744	.3239		.4801	.4687
10	.4801		.4744	.3201		.4001	.3953
11	.4001			.3201	.4001	.3163	.381
12	.4001			.2401	.3163	.3163	.3048
13	.3201			.2401	.3163	.2372	.3048
14	.3201	.2372		.2401	.3201	.2372	.3048
15		.2372		.2401	.3201	.2372	.3048
16	.3201	.2372		.2401	.3201	.2372	.3048
17	2.4006	2.2862		.3201	.3201	.3163	.3048
18	2.4006	1.9814		.3201	.3201	.3953	.3048
19	1.9204	2.1338		.4001	.4801	.4744	
20		2.0576		.4858		.4744	
21	2.0005	2.0576		.4858	.4801	.4744	
22	2.0005	1.9814		.3239	.4001	.3953	
23	2.0005	1.929		.3201	.4001	.3953	
24	1.4403	1.9204	1.929		.3201	.3201	.3163
Max	2.4006	2.2862	1.929	.4858	2.4577	2.1605	2.1605
Min	.3201	.2372	.3163	.2401	.3163	.2372	.3048
Avg	.9020	1.1306	.5833	.3214	1.0359	.8379	.8437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.4575	1.5432		.3201	.3239	.3163
2	1.6194	1.7814	1.6975		.3201	.3239	.3163
3	1.9433	1.7814	1.7747		.3201	.3239	.3163
4	1.9433	1.9433	1.9052		.3201	.3239	.3953
5	2.1052	2.1052	2.1338		.4001	.4049	.3953
6	2.1052	2.2672	2.2862		.4001	.4049	.3953
7	2.5911	2.5101	2.3624		.4049	.4049	.3953
8	2.5911	2.5911	2.3624		.4049	.4049	.3953
9	.2429	.4049	.3906	2.13		2.2672	2.0833
10	.3239	.3163	.3163	2.4577		2.4291	2.2377
11	.3239	.2372		2.4577	2.1862	2.2862	2.2862
12	.2429	.2372		2.8673		2.1338	2.2862
13	.2429	.1581		2.8673	2.4291	2.5911	2.2862
14	.1619	.1581		2.6216	2.753	2.4387	2.2862
15		.1581		2.6216	2.915	2.4387	2.2862
16		.1581		2.6216	2.753	2.3624	.4572
17		.1581		.3201	.2429	.2372	
18	.2429	.3163		.3201	.2429	.3163	.3048
19	.3239	.3953		.3201	.3953	.3953	
20		.3953		.3201		.3953	
21	.4049	.3953		.3201	.4049	.3953	
22	.3239	.3163		.3201	.3239	.3163	
23	.3239	.3163		.2401	.3239	.3163	
24	.3239	.3239	.3163		.2401	.3239	.3163
Max	2.5911	2.5911	2.3624	2.8673	2.915	2.5911	2.2862
Min	.1619	.1581	.3163	.2401	.2401	.2372	.3048
Avg	.9919	.8701	1.5535	1.5204	.9050	1.0233	1.0975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 203 / 11KV Warwada Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.16	.0791		.16	.16	.1581
2	.08	.16	.0791		.16		.1581
3	.08	.16	.0791		.16	.16	.1581
4	.16	.2401	.1581		.2401	.1619	.2372
5	.2401	.3201	.3163		.2401	.2401	.3163
6	.4001	.3201	.3953		.3201	.3201	.3163
7	.4801	.3201	.3953		.3201	.3201	.3953
8		.3201	.3953		.3201	.3201	.3163
9	1.6804	1.9204	1.6975	.16		.2401	.2372
10	1.9204	1.929	1.8519	.16		.16	.1581
11	1.9204	1.929		.16		.0791	.1524
12	1.9204	2.0062		.08		.0791	.1524
13	2.0005	2.0062		.08		.0791	.1524
14	2.0805	2.0062		.08		.0791	.1524
15		2.0833		.08		.0791	.2286
16	2.2405	1.929		.08	.16	.0791	.2286
17	.16	.0791			1.7604	1.5432	1.5242
18	.16	.1581		2.3758	2.2405	1.5432	1.5242
19	.3201	.3163		2.0805	2.0805	1.4661	
20		.2372		1.7604		1.4661	
21	.3201	.1581		1.7004	1.9204	1.3889	
22	.2401	.1581		1.7204	1.9204	1.0031	
23	.16	.1581		1.6194	1.7604	1.0802	
24	.08	.16	.0791		1.6194	1.7604	1.0802
Max	2.2405	2.0833	1.8519	2.3758	2.2405	1.7604	1.5242
Min	.08	.0791	.0791	.08	.16	.0791	.1524
Avg	.7964	.8015	.5024	.8669	.9614	.6004	.4024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 201 / 11KV Gondri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.7468	.7468	.6097	.679	.6535	.6554
2	.7316	.7468	.7468	.6706	.5792	1.1576	.6097
3	1.2193	1.6804	1.4937	.7621	1.0562	1.8671	1.2498
4	1.6766	1.7924	1.8671	1.0059	1.2971	2.0538	1.4022
5	1.9814	1.8671	2.0538	1.1888	1.5604	2.4272	1.7071
6	2.1948	2.0538	2.3339	1.3717	2.1293	2.6139	1.6766
7	2.1338	2.2405	2.5206		2.3807	2.95	1.5242
8	2.1033	2.4272	2.5206	1.5242	2.4981	2.894	1.7071
9	1.9509	1.7737	2.3339	1.6766	2.4813	2.7073	2.0424
10	.6859	.7095	.7842	.6097	.7922	.7095	.5487
11	.4854	.5093	.6706	.4527	.7468	.4572	.4481
12	.4481	.3584		.415	.2241	.2439	.4108
13	.3734	.3206		.3584	.2614		.4108
14	.3734	.3206	.3963	.3395	.3734	.2591	.3734
15	.3361	.2829	.1829	.3018	.3734	.2439	.3361
16	.3734	.3395	.3048	.3395	.3361		.4108
17	.4108	.3584	.3658	.4338	.4668		.5601
18	.7468	.7356	.6706	.7167	.7468	.4877	.7095
19	.9335	1.0562	.7011	1.0185	.9896	.7316	.9335
20	.9709	1.0269	.6097	.9808	1.0269	.6706	.9335
21	.9335	.9335	.6401	.9054	.9335	.6401	.8402
22	.8962	.9335	.6097	.7922	.8402	.5487	.7468
23	.8402	.8402	.5792	.7545	.7468	.6097	.7468
24	.5792	.8402	.8402	.5487	.7167	.6535	.6249
Max	2.1948	2.4272	2.5206	1.6766	2.4981	2.95	2.0424
Min	.3361	.2829	.1829	.3018	.2241	.2439	.3361
Avg	.9995	1.0373	1.0897	.7729	1.0098	1.2181	.9004

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 202 / 11KV Dhanora SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3734	.3734	.3506	.3772	.3734	.3658
2	.3963	.3734	.3734	.3048	.3584	.3734	.3048
3	.3963	.3734	.3734	.3658	.3772	.3734	.3353
4	.4268	.4108	.4108	.4268	.3961	.4108	.3658
5	.4268	.5601	.5601	.4572	.4338	.5228	.3963
6	.583	.8402	.7468	.5487	.5281	.5601	.4268
7	.5487	.8962	.8402	.5792	.6602	.6348	.4877
8	.5792	.7468	.7468	.6097	.6979	.5975	.3658
9	.4877	.5975	.7095	.5487	.5365	.5415	.3048
10	.3353	.4481	.5228	.3658	.3395	.3734	.3048
11	1.9605	1.5089	1.3413	1.9281	2.0538	1.5242	1.6804
12	2.4272	2.0454	1.7071	2.0119	2.5206	1.9052	1.8671
13	2.5206	2.2801	1.9509	2.1125	2.2405	1.9814	2.0538
14	2.5206	1.1401	1.9966	2.146	2.5206	1.8747	2.6139
15	2.5206	2.2969	2.0729	2.0454		1.5394	2.7073
16	2.7073	2.3304	2.0424	2.1125	2.5766	1.5242	2.6139
17	2.7073	2.3472	1.9814	2.1628	2.5766	1.6766	2.7073
18	2.5766	2.2801	1.829	2.079	2.5766	1.5851	2.7073
19	.6535	.6602	.4877	.6979	.7468	.5487	.7095
20	.6535	.6535	.4572	.5658	.7468	.5182	.7468
21	.5601	.5975	.3963	.4904	.6535	.4877	.7468
22	.5228	.5601	.3201	.415	.5601	.3658	.6535
23	.4108	.4481		.3961	.4668	.3353	.5601
24	.3353	.4108	.4108	.3353	.3961	.4108	.3048
Max	2.7073	2.3472	2.0729	2.1628	2.5766	1.9814	2.7073
Min	.3353	.3734	.3201	.3048	.3395	.3353	.3048
Avg	1.1509	1.0491	.9848	1.0023	1.1018	.8766	1.0971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154092 / 33KV Wanwada S/S

Feeder No / Name : 201 / 11KVBorfal Feeder
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	04-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)
10		.1802
11		.0983
17		.1638
18	1.0322	1.7924
19	2.1445	2.0485
20	2.0873	2.0165
21	2.0805	2.0485
22		2.0405
Max	2.1445	2.0485
Min	1.0322	.0983
Avg	1.8361	1.2986

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3206	.3395	.2641	.3584	.3584	.3018
2	.2829	.3206	.3395	.2641	.3772	.3018	.3018
3	.2829	.3206	.3206	.2829	.3584	.3206	.3206
4	.2829	.3206	.3395	.2829	.3772	.3206	.3018
5	.3018	.3206	.3206	.3206	.3395	.3206	.3206
6	.3206	.3206	.3206	.3206	.3584	.3584	.3206
7	.3772	.3395	.2829	.3206	.3772	.3584	.3772
8	.3395	.3395	.2829	.3772	.3584	.3772	.3961
9	.3395	.3772	.2829	.415	.3772	.3961	.3961
10	.4527	.5658	.4527	.4715	.3584	.7167	.4527
11	.7545	.679	.415	.4904	.3772	.7545	.547
12	.7167	.679	.4527	.4715	.3772	.7167	.6413
13	.5847	.6602	.4715	.415	.3772	.6602	.5658
14	.5093	.6602	.4715	.4338	.4338	.6602	.5847
15	.6602	.6602	.4338	.4338		.6602	.5658
16	.7167	.6413	.415	.4527	.4715	.6979	.6413
17	.7167	.6224	.4527	.4715	.547	.6602	.6224
18	.7167	.5658	.4338	.415	.679	.7167	.5658
19	.6224	.4904	.3961	.4715	.5658	.7167	.547
20	.5658	.5093	.2829	.4527	.4904	.5281	.4715
21	.3395	.5281	.2829	.3584	.3961	.3395	.3961
22	.3395	.3395	.2641	.3395	.3206	.3772	.3584
23	.3206	.3206	.3018	.3584	.3206	.3206	.3584
24	.3206	.3206	.3206	.2829	.3772	.3018	.3018
Max	.7545	.679	.4715	.4904	.679	.7545	.6413
Min	.2829	.3206	.2641	.2641	.3206	.3018	.3018
Avg	.4652	.4676	.3615	.3819	.4076	.4975	.4440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4075	.4075	.4075	.3898	.3898	.4607	.4607
2	.4075	.3898	.3898	.4075	.4075	.443	.443
3	.3898	.3898	.4075	.4075	.4075	.443	.443
4		.4252	.3898	.4075	.4075	.443	.4784
5	.443	.5138	.443	.4784	.4784	.5316	.5316
6	.6201	.6733	.4784	.7087	.6379	.7265	.6733
7	.7087	.691	.6733	.8505	.7442		.7619
8	1.0277	.7796	.8859	.8859	.9036	.8859	.8859
9	1.0277	.7442	.8859	.9036	.7087	.9745	.8682
10	.7796	.7087	.7265	.7265	.7087	.7973	.7265
11	.8505	.6733	.7442	.6733	.6024	.7442	.691
12	.7442	.7619	.7442	.7619	.6556	.7442	.7087
13	.7265	.7087	.8328	.5847	.691	.7619	.815
14	.6379	.6379	.7265	.6556	.7087	.7087	.7619
15	.6733	.6024	.691	.6024	.6733	.6379	.7265
16	.6379	.6556	.7265	.6024	.7087	.6379	.7265
17	.6733	.7087	.7087	.6201	.7265	.7265	.7973
18	.9214	.7442	1.0099	.815	.9391	.8328	.8859
19	.8682	.8859	1.0631	.9745	.9214	.9391	.9922
20	.7619	.7973	.8417	.7973	.8682	.8859	.9036
21	.691	.691	.7164	.7087	.7087	.815	.7796
22	.6201	.6024	.5493	.6201	.6379	.691	.7265
23	.5316	.5316	.4784	.5138	.567	.567	.6024
24	.4252	.4252	.4607	.4075	.4252	.4784	.4961
Max	1.0277	.8859	1.0631	.9745	.9391	.9745	.9922
Min	.3898	.3898	.3898	.3898	.3898	.443	.443
Avg	.6772	.6312	.6659	.6460	.6511	.6903	.7036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706	.4887	.4887	.4344	.4344	.543	.543
2		.4706	.4706	.4525	.4344	.5249	.5249
3	.4887	.4706	.4706	.4344	.4525	.5249	.5249
4	.4887	.543	.4887	.4525	.4525	.5792	.543
5	.5068	.6154	.5068	.543	.5068	.6335	.6335
6	.7059	.7964	.6335	.7783	.7964	.8688	.8145
7	.9412	.9774	.8507	.9593	.9593	.9955	.9412
8	.9412	1.0498	.8688	1.086	.9231	1.1041	.9593
9	.9412	.8326	.8869	.9955	.8688	.8688	.9412
10	.8869	.724	.8688	.8145	.7602	.724	.7602
11	.7783	.7059	.7602	.6878	.7421		.8145
12	.7783	.6878	.7602	.724		.724	.7602
13	.724	.6335	.7421	.6878	.6878	.6878	.7421
14	.6516	.5792	.6516	.6154	.6878	.6878	.724
15	.5973	.5792	.6335	.5973	.6878	.6878	.724
16	.6335	.5973	.6154	.5973	.6697	.6878	.7783
17	.6878	.5973	.724	.7059	.7783	.7964	.7964
18	.9231	.6335	.8869	.905	1.0136	.9593	1.0679
19	1.0317	.9955	1.0498	.905	1.0317	1.086	1.0498
20	.9412	.905	.9231	.905	.9774	.9774	.9412
21	.8326	.8145	.8145	.8145	.8507	.8869	.8869
22	.6878	.6697	.6697	.6697	.7421	.7783	.7783
23	.6154	.6335	.543	.543	.6697		.7059
24	.5068	.5068	.543	.4706	.4887	.5611	.5792
Max	1.0317	1.0498	1.0498	1.086	1.0317	1.1041	1.0679
Min	.4706	.4706	.4706	.4344	.4344	.5249	.5249
Avg	.7287	.6878	.7021	.6991	.7224	.7676	.7723

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 202 / 11 kv Yelawat AG feeder

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17
HR	Load (MW)
23	2.0576
24	2.0348
Max	2.0576
Min	2.0348
Avg	2.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.3772	.6859	.583	.4287	.4287	.4115
2	.2401	.4801	.7716	.5144	.4801	.5144	.6516
3	.2743	.6001	.823	.4801	.5144	.6859	.8059
4	.3772	.8745	1.0288	.5144	.6173	.7716	.8402
5	.4458	1.0974	1.166	.5316	.9431	1.0631	.8402
6	.5144	1.2003	1.286	.5487	1.1145	1.2003	.8573
7	.583	1.4403	1.3375	.8059	1.2346	1.2346	1.2174
8	.5487	1.4746	1.3375	.8745	1.286	1.286	1.0974
9	.463	.2401	.4115	.6173	.7202	.823	.6687
10	.3429	.2058	.2915	.6859	.7716	.8916	.7373
11				.7545	.7888	.9259	.7202
12				.7716	.823	.9945	.703
13				.8573	.9602	.9774	.6516
14				1.0288	1.0288	.9259	.823
15	.7545	.0171	.0171	.9945	1.2003	.8573	.9602
16	.0171	.1715	.1886	.9431	1.0631	.9088	.7545
17	1.046	.0171	.9774	.1886	.1886	.1715	.2229
18	.9088	1.0288	1.0631	.3429	.3601	.3772	.3772
19	.7888	.9431	.8402	.4801	.4458	.3944	.5144
20	.6859	.8573	.8916	.4458	.4287	.3429	.4801
21	.703	.823	.823	.4115	.3772	.2915	.3772
22	.6516	.8573	.7545	.3429	.3429	.2058	.3086
23	.6344	.8916	.6859	.2743	.2743	.1543	.2915
24	.6001	.583	.7202	.6173	.2401	.2401	.1543
Max	1.046	1.4746	1.3375	1.0288	1.286	1.286	1.2174
Min	.0171	.0171	.0171	.1886	.1886	.1543	.1543
Avg	.5410	.7090	.8050	.6087	.6930	.6944	.6444

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 201 / 11 KV Jawali Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1867	.181	.1715	.1867	.1867	.181
2	.1905	.1867	.181	.4858	.4973	.3315	.5258
3	.1905	.1867	.181	.6554	.663	.4973	.7716
4	.1905	.1867	.2629	.8097	.8288	.663	.8573
5	.1791	.2801	.2572	.9831	1.0774	1.1603	1.0288
6	.2286	.2801	.3429	1.2289	1.2431	1.4918	1.4251
7	.381	.3734	.4287		1.5746	1.6575	1.7204
8	.4763	.3734	.4287	1.7604	1.6575	1.9062	1.7004
9		.3506		1.6385	1.6575	1.8023	1.4575
10		.2629		.2858	.3734		.1905
11		.7716	.6173	.1867	.1867		.1524
12		1.0059	1.2651	.0934	.1867		.0762
13	.9945	1.0898	1.4575	.0934	.1867	.1753	.0762
14	1.1603	.5144	1.4575	.0934	.0934	.0876	
15	1.4918	.8573	1.4746	.0934	.0934	.0905	
16	1.4918	.8383	1.4746	.0934	.0934	.0905	
17	1.326	.9221	1.5927		.1867	.0905	
18	1.326	.9831	1.2651		.3734	.181	
19	.3734	.4382	.3506	.4668	.4668	.3506	.3239
20	.2801	.5258	.362	.4668	.4668	.4382	.4477
21	.2801	.2629	.2858	.3734	.3734	.3506	.362
22	.1867	.2715	.2858	.2801	.2801	.2715	.3658
23	.1867	.181	.1905	.2801	.2801	.2715	.2772
24	.1524	.1867	.181	.1524	.1867	.1867	.181
Max	1.4918	1.0898	1.5927	1.7604	1.6575	1.9062	1.7204
Min	.1524	.181	.181	.0934	.0934	.0876	.0762
Avg	.5638	.4798	.6602	.5092	.5506	.5848	.6379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 203 / 11 KV Kharosa Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0934	.0905	.0838	.0934	.0934	.0905
2	.503	.4144	.4382	.0838	.0934	.0934	.0905
3	.6706	.663	.7011	.0838	.0934	.0934	.181
4	.8383	.9945	.8573	.1677	.1867	.1867	.1791
5	1.0059	1.1603	1.1145	.2515	.2801	.2801	.2629
6	1.3413	1.326	1.5089	.3353	.4668	.2801	.4382
7	1.8442	1.6575	1.6385	.4191	.5601	.4668	.5144
8	2.0119	1.8233	1.7604	.4191	.4668	.4668	.5144
9	1.8442	1.8023	1.6766			.4382	.2572
10	.1677	.2572	.1753		.2801		.0838
11	.1867	.0876	.1677	.9945	.4973		.5868
12	.1867		.0838	1.4918	.9945		1.3413
13	.0934		.0838	1.5746	1.2431	.8573	1.3413
14	.0934	.0876	.0838	1.5746	1.4089	1.4746	1.4251
15	.0934	.0905	.0838	1.5746	1.4918	1.5565	1.5089
16	.0934	.0905	.0838	1.5746	1.5746	1.6194	1.5089
17	.3734	.0905	.0838	1.4918	1.4918	1.7004	1.5089
18	.4668	.3506	.2515	1.4089	1.326	1.3413	1.3413
19	.5601	.5258	.3353	.3734	.4668	.3506	.3353
20	.3734	.5258	.2515	.2801	.3734	.3506	.2515
21	.2801	.2629	.1677	.1867	.2801	.2715	.2515
22	.1867	.181	.1677	.1867	.2801	.181	.1677
23	.0934	.181	.0838	.0934	.1867	.181	.0838
24	.0838	.0934	.0905	.0838	.0934	.0934	.0905
Max	2.0119	1.8233	1.7604	1.5746	1.5746	1.7004	1.5089
Min	.0838	.0876	.0838	.0838	.0934	.0934	.0838
Avg	.5615	.5800	.4992	.6697	.6187	.5894	.5981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 204 / 11 KV Lamjana II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2801	.362	.381	.3734	.3734	.362
2	.381		.362	.5373	.4973	.4973	.6135
3	.381	.2801	.4382	.6201	.5801	.663	.8573
4	.5716	.3429	.6135	.7087	.8288	.7459	1.0288
5	.7621	.4668	.7716	.8764	.9945	.9945	1.2574
6	.8573	.6535	.8573	.9536	1.1603	1.1603	1.3927
7	1.1431	.8402	1.0288	1.3003	1.326	1.4089	1.5565
8	1.1431	.9335	1.1145	1.4413	1.4089	1.5746	1.3765
9	.9526	.6859	.9431	1.3565	1.326	1.4746	1.3927
10		.4287	.7888	.7621	.5601	.4287	.4763
11	.663	.6706	.8907	.5601		.3506	.2858
12	.8288	.8383		.3734	.3734	.2629	.2858
13	.9116	.8383	1.4089	.3734	.3734	.2629	.1905
14	1.1603	.6706	1.326	.2801	.2801	.2629	.1715
15	1.326	.8383	1.1603	.2801	.2801	.2629	.2286
16	1.326	.8383	1.3413	.3734	.2801	.2629	.3239
17	1.326	1.1336	1.4575	.4668	.4668	.3506	.3506
18	1.1603	1.1469	1.2574	.6535	.6535	.6135	.7087
19	.7468	.7888	.8573	.8402	.8402	.7888	.8573
20	.6535	.8573	.7621	.8402	.8402	.724	.6668
21	.4668	.6135	.5716	.6535	.6535	.5258	.5716
22	.3734	.543	.4763	.4668	.4668	.362	.4763
23	.3734	.362	.381	.4668	.4668	.362	.381
24	.381	.3734	.362	.381	.3734	.3734	.362
Max	1.326	1.1469	1.4575	1.4413	1.4089	1.5746	1.5565
Min	.3734	.2801	.362	.2801	.2801	.2629	.1715
Avg	.7943	.6706	.8492	.6644	.6697	.6286	.6739

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 206 / 11 KV Chalburga SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 201 / 11 KV Tambarwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3555	.3429	.3429	.3429	.3631	.3429	.3429
2	.3555	.3429	.3429	.5144	.7263	.6859	.8573
3	.3555	.3429	.3429	.8573	1.1802	.9431	1.7147
4	.3555	.4287	.4287	1.1145	1.4525	1.2003	1.8861
5	.4444		.5144	1.2003	1.6341	1.3717	2.0576
6	.5333	.5144	.5144	1.3717	1.9972	1.8861	2.2291
7	.6221	.6001	.5144	2.0576	2.088	1.9719	2.2291
8	.6221	.6001	.6001	2.1434	2.1788	2.1434	2.2291
9	.5144	.4444	.5144	2.1434	2.1788	2.1788	2.0576
10	.5144	.3555	.4287				
11	1.0288	.9777	1.2003				
12		1.9553	2.0576				
13	1.7147	2.1331	2.1434				
14	1.8861	2.2219	2.0576				
15	2.0576	2.2291	1.9719				
16	2.0576	2.1434	2.1434	.4539			.7716
17		2.1434	2.2291	.3631	.4287		.3487
18	2.0576	2.0576	2.1434	.3631	.4287	.4287	
19	.4287	.4287	.4287	.4539	.4287	.4287	.4358
20	.5144	.5144	.4287	.4539	.4287	.5144	.4358
21	.4287	.5144	.4287	.3487	.4287	.6001	.3487
22	.4287	.4287	.4287	.3631	.3429	.5144	.3487
23	.3429	.3429	.3429	1.7147	1.8861	.4287	.3429
24	.3555	.3429	.3429	.3429	.3631	.3429	.3429
Max	2.0576	2.2291	2.2291	2.1434	2.1788	2.1788	2.2291
Min	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.817	.9741	.9538	.9224	1.0903	.9989	1.1164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0832	.3429	.0857	.0857	.0813	.0857	.0857
2	.3326	.0857	.1715	.0857	.0834	.0857	.0857
3	.4158	.6001	.6001	.0857	.0813	.0857	.0762
4	.5821	.6859	.6859	.1715	.1625	.1715	.0762
5	.6653	.8573	.7716	.1715	.1663	.1715	.1524
6	.8316	.9431	.7716	.2572	.2495	.2572	.1524
7	.9979	1.0288	.8573	.2572	.2438	.2572	.1524
8	.9979	1.0288	1.1145	.2572	.2438	.1715	.2572
9	.7716	.9979	.9145		.1625		.2286
10				.1715	.0813	.0813	.0857
11				.1715		.4063	.5144
12				.8573	.8126	.8938	.7716
13				.8573	.9751	1.1376	.6859
14				.9979	.8938	1.1376	.7716
15				.9979	.8938	.8938	.7716
16	.0857	.0857		.9148	.8126	1.1145	.7716
17	.0857	.0857	.0857	.8316	.7621	.8573	.6501
18	.1715	.1715	.1715	.7485	.8573	.8573	.6501
19	.2572	.1715	.2572	.1663	.2572	.1715	.1625
20	.2572	.1715	.2572	.1663	.2572	.1715	.1625
21	.1715	.1715	.1715	.1625	.1715	.1715	.1625
22	.1715	.1715	.1715	.1625	.1715	.1715	.1625
23	.0857	.0857	.0857	.1625	.1715	.1715	.0857
24	.0832			.0857	.0832	.0857	.0857
Max	.9979	1.0288	1.1145	.9979	.9751	1.1376	.7716
Min	.0832	.0857	.0857	.0857	.0813	.0813	.0762
Avg	.3915	.4521	.4483	.3837	.3772	.4178	.3234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5447	.5144	.4287	.5144	.5447	.6001	.4287
2	.6355	.6001	.4287	.5144	.5447	.6001	.4287
3	.7263	.8573	1.2003	.5144	.5447	.6001	
4	1.0894	1.2003	1.3717	.6001		.6859	.4287
5	1.271	1.286	1.5432	.8573	.9078	.7716	.5144
6	1.4525	1.3717	1.7147	.9431	1.0894	.8573	.6859
7	1.9064	1.8861		1.0288	1.1802	1.0288	.8573
8	1.9972	2.0576	2.1434	1.0288	1.271	1.1145	1.0288
9	1.7147	1.9972	1.7147	.8573	.817	.9078	.8573
10				.7716	.6355	.7263	.6859
11				.8573		.9986	1.0288
12				1.3717	.817	1.5433	1.5432
13				1.8861	1.4525	1.6341	1.5432
14				1.7147	1.7249	1.7249	1.6289
15				1.7147	1.5433	1.6341	1.6289
16	.4287	.3429		1.9972	1.6341	1.5432	1.6289
17	.5144	.6859	.5144	1.7249	1.3717	1.7147	1.8157
18	.7716	.8573	.7716		1.3717	1.7147	1.6341
19	1.0288	.8573	.9431	1.0894	1.0288	.6001	.9986
20	1.0288	.6859	1.0288	.9078	1.0288	.5144	.9078
21	.8573	.6859	.9431	.817	.8573	.6859	.9078
22	.6859	.6859	.7716	.7263	.6859	.6859	.7263
23	.6001	.6001	.6859	.6355	.6859	.6001	.6859
24	.5447	.6001	.5144	.5144	.5447	.6001	.5144
Max	1.9972	2.0576	2.1434	1.9972	1.7249	1.7249	1.8157
Min	.4287	.3429	.4287	.5144	.5447	.5144	.4287
Avg	.9888	.9873	1.0449	1.0255	1.0128	1.0036	1.0047

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 204 / express feeder NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4687	.3429	.4287	.3429	.4687	.2572	.3429
2	.3749	.3429	.4287	.3429	.4687	.2572	.3429
3	.4687	.3429	.3429	.3429	.4687	.2572	.2572
4	.4687	.3429	.3429	.3429	.4687	.2572	.2572
5	.4687	.3429	.3429	.3429	.4687	.2572	.1715
6	.4687	.3429	.3429	.3429	.4687	.2572	.2572
7	.3749	.3429	.3429	.2572	.1875	.2572	.2572
8	.3749	.3429	.3429	.2572	.1875	.2572	.1715
9	.3429	.3749	.0857	.2572	.3749	.0937	.1715
10	.3429	.1875	.0857	.2572	.0937	.0937	.0857
11	.1715	.0937	.1715	.2572	.0937	.0937	.0857
12	.1715	.1875	.3429	.1715	.0937	.0937	.1715
13	.1715	.1875	.3429	.1715	.0937	.0937	.1715
14	.1715	.0937	.2572	.1715	.0937	.0937	.1715
15		.1715	.2572	.2572	.0937	.0937	.0857
16	.2572	.1715	.2572	.2812	.0937	.0086	.0857
17	.1715	.1715	.2572	.1875	.0857	.0857	.0937
18	.1715	.1715	.0857	.0937	.0857	.0857	.0937
19	.0857	.1715	.0857	.0937		.0857	.0937
20	.0857	.0857	.0857	.0937	.0857	.0857	.0937
21	.0857	.0857	.0857	.0937	.0857	.0857	.0937
22	.3429	.0857	.1715	.0937	.0857	.0857	.3749
23	.0857	.4287	.3429	.4687	.1715	.1715	.3429
24	.4687	.3429	.4287	.3429	.4687	.2572	.2572
Max	.4687	.4287	.4287	.4687	.4687	.2572	.3749
Min	.0857	.0857	.0857	.0937	.0857	.0086	.0857
Avg	.2867	.2398	.2608	.2443	.2299	.1527	.1887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4786	.7438	.5255	.8973	.7438	.6005	.4792
2	.673	.8925	.5255	1.346	1.1157		1.3862
3		.9669	.563	2.034	1.4876	2.6273	
4	.8002	1.0413	.7506	2.0216	2.3243		
5	.9158	1.1157	.9383	2.034	2.9752	3.0026	
6	1.1336	1.0227	1.1271	1.8656	3.3471		
7			1.126	2.5425	3.1983	3.1903	
8				2.6322	3.3471	3.0026	2.5417
9	.8375	.8368		2.6056	1.8652	2.7475	3.3099
10	.9002	.8925	.8257				
11	2.0454		1.9742				
12	2.9843		2.6056				
13	3.0681		2.8307				
14	3.3471		2.5724				
15	3.3471		2.934				
16	3.1611		2.934	.2603	.2252	.2997	.2975
17	2.9752		2.4528	.4649	.3003	.329	
18	3.3471		2.4677	.7438		.5982	.7438
19	1.3016		.8973	1.0227	1.126	.9273	1.1157
20	1.0413		.9572	.9699		1.0002	.9669
21	.8925		.9273	.8182	.8632	.8335	.9669
22	.7438		1.0002	.4103		.8002	.9297
23	.6694	.6005	.5981	.595	.6381	.6661	.8925
24	.6694	.5255	.5857	.6694	.6381	.5384	.8925
Max	3.3471	1.1157	2.934	2.6322	3.3471	3.1903	3.3099
Min	.4786	.5255	.5255	.2603	.2252	.2997	.2975
Avg	1.6825	.8638	1.4600	1.3296	1.6130	1.4109	1.2102

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 202 / 11 KV Kinnithot SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3001	.2975	.319	.2393	.2975	.3003	.2929
2	.2334	.5207		.2393	.3719		.2898
3	1.0823	.7438	1.126	.2692	.3719	.3378	.3041
4	1.3321	.9669	1.3136	.2997			.3668
5	1.4154	1.1157		.3296		.3753	.3996
6		1.6735	1.689	.3457			.3668
7		2.0517	1.8766	.3589	.3347	.4129	.3668
8		2.0826	2.0643	.4334	.5207		
9	.4001	1.7719	1.8766	.333	.3719		
10				.1795	.2975	.1334	.2975
11				.8925	.7506	1.1669	.8182
12				1.7107	1.5951	1.467	1.3016
13				1.7665	1.689	1.5985	1.5806
14				1.8595	1.689	1.5837	1.5248
15				1.9524		1.6004	1.5806
16			.1334	1.9585	1.689	1.5985	1.6735
17			.1496	1.8652	1.6514	1.3759	1.5806
18	.1859		.2307	.9669		1.2279	1.3946
19	.2603		.2692	.4476	.4495	.3905	.373
20	.4091		.3589	.4091		.3914	.4091
21	.4091		.329	.3719	.3753	.333	.3719
22	.3719		.3334	.3719		.2997	.3357
23	.3347	.3753	.3001	.3347	.3378		.3347
24	.3347	.3378	.2478	.3347	.3378	.3001	.3719
Max	1.4154	2.0826	2.0643	1.9585	1.689	1.6004	1.6735
Min	.1859	.2975	.1334	.1795	.2975	.1334	.2898
Avg	.5438	1.0852	.7886	.7612	.7724	.8274	.7425

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1865	.1501	.1332	.2231	.1689	.1334
2	.3334	.4663		.1795	.2603		.1468
3	1.1323	.9326	1.3136	.2331	.2603	.1877	.1499
4	1.4832	1.1157	1.5013	.2393	.2975		.2667
5	1.6981	1.3946		.2393	.3347	.3003	.2997
6	1.7004	1.8595	2.0643	.2623	.3719		.333
7	1.865	2.1384	2.0643	.2991	.3347	.4504	.3001
8	1.9982	2.1942	2.2519	.2667	.3347		
9	1.2997	2.0454	2.0643	.1998	.2975		
10				.1196	.1859	.1198	.2231
11				.8182	.8445	1.2322	.7438
12				1.6787	1.689	1.6337	.9297
13				1.8595	1.8766	1.6671	1.6735
14				1.9524	1.8766	1.5255	1.7665
15				1.8595	1.8766	1.4657	1.7665
16	.093			1.8595	1.8766	1.2563	1.9524
17	.1119			1.8595	1.8766	1.6318	1.8595
18	.1859		.1334	1.6735		1.1336	1.7719
19	.2984		.1795	.2975	.3003	1.467	.2975
20	.2975		.3001	.2975		.2664	.2975
21	.2231		.2658	.2231	.1877	.2997	.2231
22	.2231		.2334	.1488		.333	.2231
23	.1859	.1877	.1496	.1859	.1877	.3004	.1859
24	.1859	.1501	.1305	.2231	.1689	.1978	.2231
Max	1.9982	2.1942	2.2519	1.9524	1.8766	1.6671	1.9524
Min	.093	.1501	.1305	.1196	.1689	.1198	.1334
Avg	.7471	1.1519	.9144	.7129	.7458	.8230	.7167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 201 / 11 KV Limbala Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2429		.1658		.1715	.2601	.1753
2	.2429		.1658		.1734	.2601	.1734
3	.9717		.8192		.1696	.3429	.2601
4	1.0688		.8192		.1715	.4287	.4334
5	1.1336		1.1469		.2543	.5087	.5144
6	1.2146		1.1469		.2572	.5935	.6001
7	1.2146		1.3108		.3429	.5935	.6001
8	1.2955		1.3927		.3391	.5087	.5087
9	1.1336		1.4746		.3391	.3391	.3391
10	1.1336		1.4746		.2572	.2515	.2543
11	.1619	.1677	.1677	.1619	.1696	.1696	
12		.1677		1.1336	1.1022	1.0174	
13		.1677		1.2955	1.2717	1.2717	1.3108
14		.1677		1.2955	1.3565	1.3565	
15		.1677		1.3765	1.3717	1.3413	1.3108
16		.1677		1.3765	1.4575	1.2717	1.2289
17		.1677	.1677	1.2146	1.4413	1.1869	1.3108
18		.1658	.2515	1.2955	1.286	1.1022	1.3108
19		.2486	.3353	1.2955	1.2003	.9431	1.2289
20		.2486	.2515	.3239	.3429	.4239	.2486
21		.2486		.2429	.4287	.4287	.3315
22		.2486		.2429	.4334	.3429	.2486
23		.2486		.1715	.3467	.2572	.1658
24	.2429		.1658		.1734	.3506	.1734
Max	1.2955	.2486	1.4746	1.3765	1.4575	1.3565	1.3108
Min	.1619	.1658	.1658	.1619	.1696	.1696	.1658
Avg	.8381	.1987	.7035	.8789	.6191	.6479	.6061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 202 / 11 KV Mangrool SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858		.1619		.6001	.6859	.3467
2	.4858		.2429		.6068	.6935	.4334
3	.6478		.703		1.5604	1.4575	1.2003
4	.6478		.7811		1.5432	1.5432	1.5432
5	.8097		.7811		1.7147	1.6956	1.6108
6	.8097		.8592		1.8652	1.7804	1.5261
7	.8097		.7811		2.0348	2.0119	
8	.8097		.7811		2.0119	1.95	1.8652
9	.8097		.7811		2.0348	1.5261	1.7804
10	.8097		.7811		1.5261	1.3565	1.7147
11	.3239	.2429		.2429		.5935	.1619
12	.7287	1.8519	1.8519	.6478	.503	.8478	.6249
13	.2429	1.929	2.0833	.6478	.5935	.9326	.6249
14		2.0062	2.0062	.6478	.5935	.9221	.7811
15		.9259	2.0062	.6478	.7716	.8478	.7811
16		1.0802	2.0062	.6478	.8478	.9326	.7811
17		1.6975	1.8519	.6478	.9326	.9431	.7811
18		1.8519	1.8519	.7287	1.3717	1.1022	1.0936
19		1.0802	1.8519	.8097	1.2003	1.1869	1.2498
20		.4687	.7811	.9717	.8573	.763	.4687
21		.5468		.9431	1.0402	.8573	.5468
22		.5468			1.1269	.6001	.4687
23		.4687		.8478	.9536	.4287	.2429
24	.4858		.2429		.6859	.8669	.3429
Max	.8097	2.0062	2.0833	.9717	2.0348	2.0119	1.8652
Min	.2429	.2429	.1619	.2429	.503	.4287	.1619
Avg	.6362	1.1305	1.1594	.7026	1.1729	1.1052	.9118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 204 / 11 KV SARANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619		.1677		.0867	.1734	.1753
2	.1619		.1677		.0876	.1753	.1753
3	1.4575		.7459		.0867	.1734	.1734
4	1.6194		1.1603		.0867	.2601	.2601
5	1.7814		1.326		.1753	.3467	.3467
6	1.9433		1.6575		.1734	.3429	.4287
7	2.1052		1.989		.2572	.4287	.4287
8	2.0243		1.9662		.2543	.3391	.3429
9	1.7814		2.13		.2572		
10	1.7814		2.13				
11	.1619	.1658		.1619			
12			.1677	1.6194	2.0348	2.2043	
13		.1658	.1677	1.7814	2.2891	2.1195	2.0243
14	.1619	.0829	.1677	1.9433	2.2043	2.1195	2.1862
15		.0829	.1677	1.9433	2.1434	2.2043	2.1862
16		.0829	.1677	2.0243	2.0348	2.2043	2.1862
17		.0829	.1677	2.0243	2.0576	1.9719	2.1862
18		.1677	.1677	2.0243	1.8652	1.7147	2.1052
19		.2515	.1677		1.5261	1.3565	1.9433
20		.2515	.1677	.2429	.3429	.4287	.1677
21		.2515		.2429	.3429	.5144	.2515
22		.1677	.1677	.2429	.3391	.4287	.2515
23		.1677		.1619	.2572	.3467	.1677
24	.1619		.1677		.1715	.2601	.1734
Max	2.1052	.2515	2.13	2.0243	2.2891	2.2043	2.1862
Min	.1619	.0829	.1677	.1619	.0867	.1734	.1677
Avg	1.1772	.1601	.7279	1.2011	.867	.9578	.9080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 205 / 11 KV BANEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1619		.1696		.1734	.1734	.1753
2	.1619		.1696		.1753	.1753	.1715
3	.1619		.1696		.8669	.7716	.7716
4	.1619		.1696		.9431	.8669	.9536
5	.1619		.1696		.9431	.9431	1.0402
6	.1619		.1696		1.0288	1.0288	1.0288
7	.2429		.1696		1.1145	1.3565	1.3717
8	.2429		.1696		1.1145	1.4413	1.2717
9	.1619		.1696		1.1145	1.3565	1.2003
10	.1619		.1696		1.2003	.5144	1.1022
11	.1619		.1696	.081	.1696	.1696	
12		.9831	.9945	.081	.0848	.1696	
13		1.065	1.1603	.081	.0848	.1715	.1696
14		1.1469	1.1603	.081	.0848	.0848	.0848
15		.5735	1.1603	.081	.0857	.0857	.0848
16		.6554	1.1603	.081	.0848	.0857	.0848
17		.9831	1.1603		.1715	.0867	.0848
18		1.0774	1.1603	.1619	.2572	.1715	.0848
19		.7459	1.1603	.2429	.2572	.2543	.1696
20		.1696	.1696	.2429	.2572	.2543	.1696
21		.1696		.2429	.2572	.2572	.1696
22		.1696		.1619	.1734	.2572	.1696
23		.1696		.1619	.1753	.1715	.1696
24	.1619		.1696		.1734	.1715	.1734
Max	.2429	1.1469	1.1603	.2429	1.2003	1.4413	1.3717
Min	.1619	.1696	.1696	.081	.0848	.0848	.0848
Avg	.1754	.6591	.5391	.1417	.4580	.4591	.4865

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.1524	.1524	.2294	.1524	.2294	.3048
2	.1966	.2286	.1524	.1966	.1524	.2294	.3048
3	.1966	.2286	.1524	.1966	.1524	.1966	.2286
4				.2458	.2286	.1966	.2286
5				.2622	.2286	.2622	.3048
6				.3277	.2286	.4588	.381
7				.3605	.3048	.3605	.3048
8				.3605	.3048	.3605	.2286
9	1.0974		1.1431	.3605	.2286	.2949	.2286
10	1.1888		1.1431	.2622	.1524	.2622	.1524
11	1.2193	1.1431	1.2452				
12	1.2955		1.278				
13	1.2955	1.2193	1.3108				
14	1.2193	1.2193	1.3435				
15	1.2193	1.0669	1.2452				
16	1.1431	1.0669	1.2125				
17				1.0669	1.1984	.7621	1.0669
18	.2286	.0762	.2458	1.2193	1.2308	.8383	1.1431
19	.3048	.0762	.2949		1.2125	.8383	1.1431
20	.3048	.0762	.2949	1.0669	.9831	.9145	1.0669
21	.3048	.1524	.2622	1.0669	.852	.9145	.9907
22	.2286	.1524	.2458	.9907	.9175	.9907	.9145
23	.2286	.1524	.2458	.9145	.9175	1.0669	.9145
24	.2622	.1524	.1524	.2458	.9145	.9069	.9907
Max	1.2955	1.2193	1.3435	1.2193	1.2308	1.0669	1.1431
Min	.1966	.0762	.1524	.1966	.1524	.1966	.1524
Avg	.6757	.4776	.6734	.5514	.5756	.5602	.6054

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1524	.2286	.7773	.5335	.4801	.7621
2	.128	.1524	.2286	.7449	.6097	.5761	.8383
3	.128	.1524	.3048	.7449	.6859	.6722	.8383
4	.16	.1524	.3048	.7773	.7621	.8002	.9145
5	.16	.2286	.381	.8097	.7621	.8322	.9145
6	.192	.2286	.381	.8421	.9145	.9602	.9907
7	.192	.2286	.2286	.8907	.9145	.9602	.7621
8	.192	.3048	.1524	.7682	.9145	.9602	.7621
9	.2439		.2286				
10	.2439		.2286				
11		.1524					
15				.0762	.08	.1524	.0762
16				.0762	.08	.1524	.0762
17	.9145	.4572	.9831	.1524	.08	.2286	.1524
18	.9907	.6097	1.0562	.1524	.2267	.2286	.2286
19	1.0669	.7621	1.0242	.3048	.2429	.2286	.3048
20	1.0669	.7621	.9069	.3048	.2429	.1524	.3048
21	.9907	.9145	.8421	.2286	.2267	.2286	.2286
22	.9145	.9145	.8097	.2286	.192	.2286	.1524
23	.7621	.9907	.8097	.1524	.16	.1524	.1524
24	.8002	.6859	.9907	.8097	.1524	.16	.1524
Max	1.0669	.9907	1.0562	.8907	.9145	.9602	.9907
Min	.128	.1524	.1524	.0762	.08	.1524	.0762
Avg	.5170	.4617	.5605	.4912	.4322	.453	.4784

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7621	.7621	.1638	.1524	.1638	.3048
2	.8097	.8383	.7621	.1311	.1524	.1638	.381
3	.8097	.9145	.9145	.1311	.2286	.1638	.381
4	.8421	.9145	.9145				
5	1.1523	.9907	.8383				
6	1.2955	.9907	.9145				
7	1.4899	1.0669	.7621				
8	1.3123	1.0669	.381				
9			.3048	1.2308	.9907	1.2308	.9145
10			.2286	1.2955	1.0669	1.2631	.9145
11			.1966	1.2193	1.2308	1.0669	.9145
12			.1638	1.1431	1.2955	1.0669	.9145
13			.1638	1.1431	1.2955	.9907	.9907
14			.1638	1.1431	1.278	.9907	.9145
15			.1638	1.0669	1.166	.9145	.8383
16			.1638	.9907	1.0814	.9145	.8383
17		.0762	.1311				
18	.3048	.0762	.2622	.1524	.3932	.1524	
19	.3048	.1524	.3277	.3048	.3605	.1524	.3048
20	.3048	.1524	.3605	.3048	.3605	.2286	.3048
21	.2286	.2286	.2949	.2286	.3277	.3048	.1524
22	.2286	.2286	.2622	.1524	.2458	.3048	.1524
23	.1524	.3048	.1966	.0762	.1966	.1524	.0762
24	.1638	.0762	.1524	.1638	.0762	.1638	.1524
Max	1.4899	1.0669	.9145	1.2955	1.2955	1.2631	.9907
Min	.1524	.0762	.1311	.0762	.0762	.1524	.0762
Avg	.6698	.5525	.4077	.6134	.6610	.5772	.5559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 201 / 11 KV Chincholi (T) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3658
2				1.0288		1.1431
3		.4287				1.7528
4				1.6385		2.4006
5		.4915				2.21
6				2.3472		2.572
7	.7316	.6554		2.6216	2.6825	2.7435
8	.7621			3.0178	2.0729	2.713
9		.9221		2.9127	2.4539	3.0864
10	.6615		.1623			.6859
11	2.572	1.9528				
12	2.753					
13	2.834	2.0005				
14	2.8006		.1646			.1905
15	2.8006	1.2003				.2115
16	2.7673		.16	.2439	.1067	.2086
17	2.5301	2.0005				.2896
18						.2667
19	.8002		.6249			.3048
21	1.086		.503			
22			.3201			
23	.7392		.6859			
24	.4268				.4572	.3048
Max	2.834	2.0005	.6859	3.0178	2.6825	3.0864
Min	.4268	.4287	.16	.2439	.1067	.1905
Avg	1.7332	1.2065	.3744	1.9729	1.5546	1.2617

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 202 / 11 KV Utka SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058		.2172		.1372
2						.0914
3		.743		.1966		.0762
4				.1738		.0953
5		1.1203				.0762
6				.2012		.0953
7	1.5242	1.4403		.2572	.3048	.0914
8	1.1888			.3155	.2591	.1067
9		1.6004		.3506		
10			.1486	.3801		.16
11	.1429	.1753			.5716	.9976
12	.12		1.5546		1.5242	
13	.1238				1.9719	1.2651
14	.1021		1.6004		2.0576	
15	.1067	.1158			1.9719	1.6004
16	.1372		1.6404	1.6156	.1372	
17	.1692	.1581			1.6766	1.5623
18	.2606				1.6766	
19	.3715		.2172			.12
21			.2191			.2143
22			.1572			
23	.2401		.2629		.1143	
24	.2439				.2286	.1143
Max	1.5242	1.6004	1.6404	1.6156	2.0576	1.6004
Min	.1021	.1158	.1486	.1738	.1143	.0762
Avg	.3639	.6949	.7251	.4120	1.0412	.4252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 203 / 11 KV Gotewadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1143		.0762		.0762
2						.0914
3		.6401		.0762		.1334
4						.1372
5		.9374		.1524		.1143
6						.061
7	1.5394	1.2803		.2858	.3048	.0762
8	1.1584			.3429	.2591	.061
9		1.5623			.2439	
10	.1905		.1524		.0762	.0914
11	.1143	.0953		.1524	.6859	.9412
12	.0762		1.2498		1.0364	
13		.0572			1.3717	1.1145
14	.0381		1.2498		1.3717	
15		.0381			1.0669	1.2793
16			1.2803	1.2498	1.3717	
17	.0762	.0572			1.4575	1.3117
18					1.2955	
19	.2286		.1143			.125
21	.2858		.1905			.1524
22			.0953			
23	.1905		.0762			
24	.061				.061	.0305
Max	1.5394	1.5623	1.2803	1.2498	1.4575	1.3117
Min	.0381	.0381	.0762	.0762	.061	.0305
Avg	.3599	.5314	.5511	.3337	.8156	.3623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.503
2		.2812			.3125		.4973
3			.4973				
4		.3549			.5468		
5			.5243				.5801
6		.4374			.6249		.503
7	.9069			.8002	.6249	.8097	.7545
8		.3906	.7888				
9	.8097	.3858		.703	.703	.4049	.8288
10							.7811
11	.703	.4973		.6249			
12		.4973					
13	.6249	.663		.5468			
14		.5735					
15	.5937	.7373		.5468			
16		.7459		.4687		.8192	.6249
17	.4687	.8192	.4858	.4687			
18	.4374	.7373			.7287	.8288	.703
19		.6783	.8097	.3906			
20	.3906					.5868	.6249
21				.3437		.5868	
22	.3593	.5087	.4915			.503	.5468
23		.5087	.4481	.3125	.4049	.503	
24	.3125		.503	.3437		.3239	.4687
Max	.9069	.8192	.8097	.8002	.7287	.8288	.8288
Min	.3125	.2812	.4481	.3125	.3125	.3239	.4687
Avg	.5607	.5510	.5686	.5045	.5637	.5962	.6180

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5801		3.6466
2		3.2808					3.5637
3		2.9683	3.5227		.663	.4973	3.6466
5		3.0464	2.8502				2.4034
6							.663
7	.7956	.663		.8097			.5935
8			.8478				
9	.4973	.663		.5801			.503
14					3.0045		
16	.2486			.1658		.3315	.2486
17		.3315	.3201	.3315			
18	.3315	.4973			.4973	.3391	.4144
19		.5868	.663	.663			
20	.4144					.5935	.4973
21				.4973		.503	
22	.4687	.4191	.4144			.503	.6249
23		3.4808	2.9959	.5801	2.8464		
24	3.3589		3.6046	.5801		3.5627	3.1245
Max	3.3589	3.4808	3.6046	.8097	3.0045	3.5627	3.6466
Min	.2486	.3315	.3201	.1658	.4973	.3315	.2486
Avg	.8736	1.5937	1.9023	.5260	1.5183	.9043	1.6608

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 206 / 11 KV DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8288			.703		.503
2							.5868
3	.8288	.8288		.663	1.0936		.663
5					1.6404		
7					2.2653	2.734	
8			.6706				
9					1.7185	2.734	
11	.9374			.7811			1.5623
13	2.734	2.8673		2.5777			2.6558
14		3.0407	3.0045				
15	2.8902	2.4006		2.6558			2.5777
16		3.0312	2.6882	2.734		1.2289	
17	2.8121	3.2007	2.5301	2.8121			
18	2.3434	2.6216			.6706	2.4577	2.3434
19		.9326	.9221	.9945			
20	.7459					2.2634	.7459
21				.663		2.1548	
22	.8288	.5935	.5801			.5868	.7459
23			.4973	.6554	.4973	.503	.7459
24	.8288		.503	.4973		.4973	.7459
Max	2.8902	3.2007	3.0045	2.8121	2.2653	2.734	2.6558
Min	.7459	.5935	.4973	.4973	.4973	.4973	.503
Avg	1.6610	2.0346	1.4245	1.5034	1.2270	1.6844	1.2614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1222	1.1576	1.1584	.543	.5792	.6335	.5975
2	1.448	1.643	1.5384	.543	.5487	.6335	.6535
3	1.7194	1.7924	1.6108	.543	.7095	.5792	.6535
4	1.8823	1.8861	1.8861	.6335	.7842	.724	.7468
5	2.19	2.3339	2.3529	.8145	.9335	.8326	.7468
6	2.5339	2.7073	3.0769	.905	1.0269	.9593	.8402
7	2.733	3.2861	2.0814	.905	.8775	.7421	.8402
8	1.8861	2.894	2.572	.6859		.7888	.9149
9	.583	.7842		1.8861		2.3491	1.6804
10	.2801		.3429			2.572	2.4646
11							2.4272
12	.1867		.1715		1.2003		2.6139
13	.1867				1.9547		2.1472
14	.1494	.1029	.1372		2.452	1.869	2.2405
15					2.572		2.3339
16		.1715	.1372		2.7092	2.2977	2.2405
17			.2058				.3361
18		.4287			.4115		.5601
19					.7373		.7468
20		.7716	.7716				.7468
21							.7095
23		.7716	.6001				
24	.543	1.2136	.5144	.5144	.6335	.6516	.5973
Max	2.733	3.2861	3.0769	1.8861	2.7092	2.572	2.6139
Min	.1494	.1029	.1372	.5144	.4115	.5792	.3361
Avg	1.2460	1.4630	1.1974	.7973	1.2087	1.2025	1.2654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 201 / 11 KV TAGARKHEDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.3429			.4287	
9	.4287	.5144		.4287	.4287		.5144
16	.0857	.1715	.0857		.2572	.1715	.0857
17				.1715			
24	.0857	.0857	.1715	.0857	.0857	.1715	.0857
Max	.4287	.5144	.3429	.4287	.4287	.4287	.5144
Min	.0857	.0857	.0857	.0857	.0857	.1715	.0857
Avg	.2000	.2572	.2000	.2286	.2572	.2572	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 202 / 11 KV HALGARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.6859			.6859	
9		.6859		.6001	.7716		.7716
14		.2572					
16	.3429				.3429	.3429	.2572
17				.3429			
24	.3429	.3429	.3429	.3429	.3429	.3429	.3429
Max	.3429	.6859	.6859	.6001	.7716	.6859	.7716
Min	.3429	.2572	.3429	.3429	.3429	.3429	.2572
Avg	.3429	.4287	.5144	.4286	.4858	.4572	.4572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 203 / 11 KV SAWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.4287				
9	.6001	.6001		.5144	.6001	.5144	.6001
16	.1715	.0171	.1715		.1715	.1715	.1715
17				.2572			
24	.0857	.1715	.1715	.1715	.1715	.1715	.2572
Max	.6001	.6001	.4287	.5144	.6001	.5144	.6001
Min	.0857	.0171	.1715	.1715	.1715	.1715	.1715
Avg	.2858	.2629	.2572	.3144	.3144	.2858	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 204 / 11 KV SHIRSHI HANGARGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.5144			.5144	
9	.6859	.5144			.5144		
16		.1715	.1715		.2572	.1715	.2572
17	.1715			.1715			
24	.2572	.2572	.3429	.3429	.2572	.3429	.3429
Max	.6859	.5144	.5144	.3429	.5144	.5144	.3429
Min	.1715	.1715	.1715	.1715	.2572	.1715	.2572
Avg	.3715	.3144	.3429	.2572	.3429	.3429	.3001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 205 / 11 KV SAWARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			2.4863				
9	2.6578	2.572					
16	.0857				2.7435	2.7435	2.2291
17				2.7435			
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	2.6578	2.572	2.4863	2.7435	2.7435	2.7435	2.2291
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.9431	1.3289	1.286	1.4146	1.4146	1.4146	1.1574

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 206 / 11 KV HALGARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.0857				
9				2.572	2.7435		2.7435
13		2.7435					
16	2.7435		.2743		.0857		.0857
24	.0857	.0857	.0857	.0857	.0857	2.8292	.0857
Max	2.7435	2.7435	.2743	2.572	2.7435	2.8292	2.7435
Min	.0857	.0857	.0857	.0857	.0857	2.8292	.0857
Avg	1.4146	1.4146	.1486	1.3289	.9716	2.8292	.9716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 207 / 11 KV TAGARKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5			.0857				
8						1.9719	
9				1.9719	1.9719		1.7147
16		1.7147	1.9719				.0857
17	1.8861			.0857			
24	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Max	1.8861	1.7147	1.9719	1.9719	1.9719	1.9719	1.7147
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.9859	.9002	.7144	.7144	1.0288	1.0288	.6287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 202 / 11 KV TUPADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.8067		1.073	.8817
2	.128				.9282		
3			.0857	1.7604		2.0553	1.6095
4	.128				1.3245		
6	.1448		.12	2.304	1.8991	2.4577	2.3758
7	.1646						
8		.1174	.1372	2.1534	2.4577	2.4981	2.4034
10		.1029	.104	.0867	.0857	.0848	.0857
11	.0838		.0514			.1029	
12		.052	.1029	.0514	.0686		
13	.0829						
14					.0857		
15		.1187	.0693				
16	.0671	.12			.0686		
17				.0686		.0686	
18		2.7949	2.652		.0686		
19				.1029		.12	
20		2.2119	2.1956		.1029		
21						.0857	
22	2.2382		1.9616	.0686	.0857	.0867	
23			1.95				
24	2.1582	2.0576					
Max	2.2382	2.7949	2.652	2.304	2.4577	2.4981	2.4034
Min	.0671	.052	.0514	.0514	.0686	.0686	.0857
Avg	.5773	.9469	.8572	.9336	.6523	.8633	1.4712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292		.5028	.3681	.3601	.3601	.3601
2	.6335						
3			.6344	.5144	.3429	.3944	.5201
4	.7682						
6	1.1403		.9556	.5721	.5426	.6762	.631
7	1.382						
8		1.3748	1.3094	.5201	.503	.6762	.567
10			.5765	1.1393	1.1437	1.1443	1.3998
11	.3018	.3988				1.1233	
12		.2804	.2743	1.166	1.0898		
13	.2818					1.0227	
14			.2572	1.1736	1.17		
15		.218				1.21	
16	.2012	.2743	.208	1.1831	1.0749	1.2616	
18		.4115	.3988	.5304	.3772		
19						.4973	
20		.5548	.4854	.6371	.6001		
21						.5658	
22	.4409		.4161	.4191	.5201	.4458	
23			.4115				
24	.3258	.4458					
Max	1.382	1.3748	1.3094	1.1831	1.17	1.2616	1.3998
Min	.2012	.218	.208	.3681	.3429	.3601	.3601
Avg	.5805	.4948	.5358	.7476	.7022	.7815	.6956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FDR Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2103	.2016	.1472	.1981	.2156
2	.1792			.1959			
3			.1766	.1805	.1367	.1701	.1595
4	.161			.163			
5				.028			
6	.0128		.0124	.0175	.0177	.0245	.0177
7	.0146						
8		.0263	.0123	.0123	.0177		.0158
9						.0123	
10		.014	.0105	.0561	.0649		.0372
11	.048					.0105	
12		.0245	.0123	.0438	.0578		
13	.024						
14			.0123	.085	.0602	.0177	
15		.024					
16	.036	.0175	.0121	.0719	.062	.028	
18		.0121	.012	.0163	.0372	.0158	
20		.0124	.0123	.0245	.0248	.0123	
22	.0225		.0124	.0245	.2086	.2514	
23			.0105				
24	.2213	.2126					
Max	.2213	.2126	.2103	.2016	.2086	.2514	.2156
Min	.0128	.0121	.0105	.0123	.0177	.0105	.0158
Avg	.0799	.0429	.0422	.0801	.0759	.0741	.0892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154029 / 33/11 KV MADANSURI

Feeder No / Name : 202 / 11 KV MADANSURI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.4575			
11	.5516					
16				1.2103	.7888	1.406
19		.8916				
Max	.5516	.8916	1.4575	1.2103	.7888	1.406
Min	.5516	.8916	1.4575	1.2103	.7888	1.406
Avg	.5516	.8916	1.4575	1.2103	.7888	1.406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154029 / 33/11 KV MADANSURI

Feeder No / Name : 203 / 11 KV RAMTIRTH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			1.5432		
12	.1112				
16				1.5144	1.4232
19		.3772			
Max	.1112	.3772	1.5432	1.5144	1.4232
Min	.1112	.3772	1.5432	1.5144	1.4232
Avg	.1112	.3772	1.5432	1.5144	1.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154029 / 33/11 KV MADANSURI

Feeder No / Name : 204 / 11 KV DONGARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.7888		
12	2.4813				
16				.1372	.2686
19		.6344			
Max	2.4813	.6344	.7888	.1372	.2686
Min	2.4813	.6344	.7888	.1372	.2686
Avg	2.4813	.6344	.7888	.1372	.2686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					1.5604	1.6504	1.5661
8	.4567		.3991	1.6764			
16		1.7562		.2549	.1562	.1585	.2358
Max	.4567	1.7562	.3991	1.6764	1.5604	1.6504	1.5661
Min	.4567	1.7562	.3991	.2549	.1562	.1585	.2358
Avg	.4567	1.7562	.3991	.9657	.8583	.9045	.9010

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.9248	2.3062	1.5242
8	1.5403		1.9319	1.6099			
16		1.4489		1.5413	1.3769	1.6164	1.6004
Max	1.5403	1.4489	1.9319	1.6099	1.3769	2.3062	1.6004
Min	1.5403	1.4489	1.9319	1.5413	.9248	1.6164	1.5242
Avg	1.5403	1.4489	1.9319	1.5756	1.1509	1.9613	1.5623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 201 / 11 KV AURAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.8192		1.1203	
16	1.0269	1.0288	1.065		.0934	.0943	.0943
24		.0934		.0566		.0934	.0934
Max	1.0269	1.0288	1.065	.8192	.0934	1.1203	.0943
Min	1.0269	.0934	1.065	.0566	.0934	.0934	.0934
Avg	1.0269	.5611	1.065	.4379	.0934	.436	.0939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 202 / 11 KV SHELGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		3.0521	2.7854				
16	.0343	.0362	.0754		3.0521	2.672	3.0312
24		.0343		.0566		.0343	.056
Max	.0343	3.0521	2.7854	.0566	3.0521	2.672	3.0312
Min	.0343	.0343	.0754	.0566	3.0521	.0343	.056
Avg	.0343	1.0409	1.4304	.0566	3.0521	1.3532	1.5436

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.3361	.3696	.3521		.4481	.3696	.2652
24		.3734		.4024			.4481
Max	.3361	.3734	.3521	.4024	.4481	.3696	.4481
Min	.3361	.3696	.3521	.4024	.4481	.3696	.2652
Avg	.3361	.3715	.3521	.4024	.4481	.3696	.3567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 204 / 11 KV AURAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.6335	.5544	.503		.5544	.5544	.5243
24		.4525		.3353		.462	.4668
Max	.6335	.5544	.503	.3353	.5544	.5544	.5243
Min	.6335	.4525	.503	.3353	.5544	.462	.4668
Avg	.6335	.5035	.503	.3353	.5544	.5082	.4956

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.1829	.2772	.1696		.2772	.1658
24		.3658		.2572	.3658	.2801
Max	.1829	.3658	.1696	.2572	.3658	.2801
Min	.1829	.2772	.1696	.2572	.2772	.1658
Avg	.1829	.3215	.1696	.2572	.3215	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 201 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1638		.1715	.4915	.5144		.4915
4		.16				.6401	
6	.2458		.2572		.9431		.8192
7	.2458	.2429	.2572	.9831	.8573	.8907	.9831
8	.2458	.2429	.2572	1.065	.8573	.9717	.9831
9	.2458			.9012	.8573		
10			.2458				
11	.4858				.16		
12		.8573	.9012	.1715			.1715
13						.1638	
14	.9717		.9831		.1619		
15			.9012			.1638	
16		1.0288	.9012	.1715	.16	.1638	
17	.9717						
18			.9012			.2458	
19			.2458		.2429		
20		.2572		.2572		.2458	.2572
21	.2401		.2458		.2429		
24	.2458	.1581	.1715	.1638	.1715	.1581	.2458
Max	.9717	1.0288	.9831	1.065	.9431	.9717	.9831
Min	.1638	.1581	.1715	.1638	.16	.1581	.1715
Avg	.4062	.4210	.4954	.5256	.4699	.4048	.5645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 203 / 11 KV MASALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1886		.1905	.4715	.8573		.5658
4		.1867				.7468	
6			.2858		.9526		.9431
7	.2829	.2829	.2858	.9431	.9526	1.0374	1.1317
8	.2829	.2829	.2858	.9431	1.1431	1.1317	1.1317
9	.2829			.9431	1.1431		
10			.2829				
11	.9335				.1867		
12		.9526	1.1317	.1905			
13						.1886	
14	1.3203		1.1317		.1848		
15			1.1317			.1886	
16		.9526	1.1317	.1905	.1867	.1886	.1905
17	1.1203						
18			.9431			.1886	
19			.2829		.2801		
20		.2858		.2858		.2829	.2858
21	.2772		.2829		.2801		
24	.1886	.1848	.1905	.1886	.1905	.1848	.1886
Max	1.3203	.9526	1.1317	.9431	1.1431	1.1317	1.1317
Min	.1886	.1848	.1905	.1886	.1848	.1848	.1886
Avg	.5419	.4469	.5813	.5195	.5780	.4598	.6339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	03-DEC-17
HR	Load (MW)
7	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 205 / 11 KV Aambegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1619		.1715	.4858	.5144		.4858
4		.1658				.663	
6	.1619		.1715		.8573		.9717
7	.1619	.1658	.1715	.9717	.8573	.9945	1.1336
8	.1619	.1638	.1715	.9717	.8573	.9945	.9717
9	.1619			.8907	.8573		
10			.1619				
11	.8288				.1638		
12		.8573	.9717				.1715
13						.1619	
14	1.0774		.9717		.1638		
15			.9717			.1619	
16		.8573	.9717	.1715	.1658	.1619	.1715
17	.9831						
18			.8097			.1619	
19			.1619		.1638		
20		.1715		.1715		.1619	.1715
21	.1638		.1619		.1658		
24	.1619	.1619	.1715	.1619	.1715		
Max	1.0774	.8573	.9717	.9717	.8573	.9945	1.1336
Min	.1619	.1619	.1619	.1619	.1638	.1619	.1715
Avg	.4025	.3633	.4646	.5464	.4489	.4327	.5825

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154072 / 33/11 KV BORSURI

Feeder No / Name : 201 / 11 KV SONKHED SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706	.6783	.6783	.6706	.5868	.6783	.7545
2	.6706	.8478	1.0174	.6706	.6706	.6783	.7545
3	1.8442	1.1869	1.3565	.6706	.6706	.8478	.7545
4	1.8442	1.1869	1.6956	.7545	.6706	.8478	.7545
5	2.0119	1.5261	1.95	.7545	.8383	.8478	.8383
6	2.0119	1.5261	2.1195	.8383	.9221	1.0174	.6706
7	2.1795	1.6956	2.3739	.9221	.9221	1.1022	.7545
8	2.1795	2.0348	2.0348	.8383	.4191	1.1869	.7545
9	2.1795	2.3739	2.6282	.5868	.4191	.763	
10	.503	.763	.763	.5868		.3391	.503
11	.1677	.3391	.5868	1.5927			
12				2.1795	2.3739	1.9281	
13			.1677	2.2634	2.3739	2.5149	
14			.1677	2.0119	2.713	2.5987	
15			.1677	2.0957	2.5434	2.2634	
16			.1677	2.2634	2.2891	2.5149	
17			.2515	2.1795	2.3739	2.5149	
18		.5087	.2515	2.2634	2.3739	2.5149	
19		1.1022	.5868	.8383	.763	.9221	
20		1.1022	.8383	.7545	.9326	.9221	
21		.9326	.8383	.7545	.9326	.8383	
22		.763	.8383	.7545	.8478	.7545	
23		.6783	.7545	.7545	.6783	.7545	
24	.6706	.6783	.6783	.7545	.6706	.6783	.7545
Max	2.1795	2.3739	2.6282	2.2634	2.713	2.5987	.8383
Min	.1677	.3391	.1677	.5868	.4191	.3391	.503
Avg	1.4111	1.1069	.9962	1.1981	1.2721	1.3056	.7293

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 201 / 11 KV NITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4024		2.8509
6		.9709		3.3608
7		1.0669		
8	1.0631	.9709		3.4374
16			.3521	
18			.6516	
19			1.893	
20	2.9569			
22	3.1093			
24		1.1888		.4858
Max	3.1093	1.1888	1.893	3.4374
Min	1.0631	.4024	.3521	.4858
Avg	2.3764	.9200	.9656	2.5337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 202 / 11 KV SHEND FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.583	.6036	.6036	.4641	.4694	.4588
6						.9709
8				.9945	1.1088	1.0719
12	1.4548	1.8351	1.6575			
14	1.6194					
16	1.6842	1.6244	1.2597			
18					1.8176	
19		.8535			1.893	
20	.924		.7293	1.6278		
21		.5967				
22	.5853					
24	.4239	.3353	.2984	.2652	1.2597	1.2498
Max	1.6842	1.8351	1.6575	1.6278	1.893	1.2498
Min	.4239	.3353	.2984	.2652	.4694	.4588
Avg	1.0392	.9748	.9097	.8379	1.3097	.9379

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 203 / 11 KV BASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	2.1376	2.0119	2.079	.4641	.5365	.5898
6		2.0805				
7		3.0483				
8		2.6699	2.0111			
11					2.5263	
12				3.062		
13					2.4059	
16	.1943	.1989	.1989	2.7069	2.3045	
19		.7316			.9465	
20	.7023		.5304	.6443		
21		.431				
22	.3292					
24	.2204	.2134	.2321	.2155	.2984	.2591
Max	2.1376	3.0483	2.079	3.062	2.5263	.5898
Min	.1943	.1989	.1989	.2155	.2984	.2591
Avg	.7168	1.4232	1.0103	1.4186	1.5030	.4245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 201 / 11 KV NANAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3437	.3429	.3277	.3239	.3086	.2622	.2915
2	.6249	.6859	.9069	.3887	.3086	.2949	.2591
3	.9374	1.2003	1.1012	.421	.3429	.3605	.4534
4	1.0936	1.5432	1.4403	.4999	.4801	.4588	.4858
5	1.1561	1.8861	1.7497	.6874	.6859	.5898	.6802
6	1.5623	2.2291	1.8747	.759	.8916	.6882	.9069
7	2.1559	2.4348	2.2885	.8436			
8	2.2809	2.4006	2.2291				
9	2.4996	2.7435	2.2558				
10				.6154	.5571		
11				1.5546	1.3927	1.6644	1.8861
12				2.0576	1.9616	2.2298	2.572
13				2.0576	2.1696	2.5911	2.6063
14				2.4006	2.1148	2.4059	2.572
15				2.4006	2.1994	2.4291	2.572
16	.3429	.2949	.3563	2.4006	2.114	1.9433	2.572
17	.4458	.426	.4858	2.4691	2.2009	1.6194	2.4006
18	.6859	.6226	.5624	2.4006	2.021	1.6518	2.4006
19	.5487	.6882	.7186	.6516	.7537	.7449	.7888
20	.4801	.5571	.6802	.5487	.5898	.6802	.6859
21	.3429	.4588	.5506	.4115	.4915	.5441	.5144
22	.3429	.3605	.3887	.3944	.3605	.3887	.3429
23	.3086	.2949	.3563	.3429	.3277	.3239	.3086
24	.2812	.3086	.2949	.2915	.3086	.2949	.2915
Max	2.4996	2.7435	2.2885	2.4691	2.2009	2.5911	2.6063
Min	.2812	.2949	.2949	.2915	.3086	.2622	.2591
Avg	.9130	1.0821	1.0315	1.1328	1.0753	1.1083	1.2795

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 202 / 11 KV JEWRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.3086	.3277	.3125	.3086	.2622	.2267
2	.4534	.3429	.3932	.4062	.4458	.4588	.3887
3	.5937	.3429	.4588	.6478	.8573	.8192	.6154
4	.7811	.5144	.5243	.7499	1.2003	.9717	.7773
5	.9061	.7202	.6554	1.0936	1.2003	1.1336	.8124
6			.8192	1.2186	1.3717	1.3603	.9717
7				1.2498	1.2003	1.3279	1.2308
8				1.3123	1.5775	1.4723	1.4575
9				1.2498	1.3603	1.3123	1.2955
11	.6859	.8573	.8097				
12	1.0974	1.2631	1.2498				
13	1.2003	1.2631	1.2498				
14	1.3375	1.1012	1.2955				
15	1.3375	1.2631	1.1984				
16	1.3375	1.2631	1.2955	.2401	.2294	.2915	.2743
17	1.3375	1.166	1.1336	.2401	.2622	.3563	.3772
18	1.3717	1.1142	1.0688	.3429	.6554	.6249	.6516
19	.823	.8745	.6802	.7202	.8848	.7449	.6859
20	.6859	.5898	.5506	.5144	.5571	.6154	.6173
21	.4801	.4588	.3437	.3772	.4915	.3749	.3772
22	.3086	.3277	.3239	.3429	.3605	.3239	.3086
23	.3086	.2949	.2812	.3086	.2949	.2915	.2743
24	.253	.2743	.2949	.2915	.3086	.2622	.25
Max	1.3717	1.2631	1.2955	1.3123	1.5775	1.4723	1.4575
Min	.253	.2743	.2812	.2401	.2294	.2622	.2267
Avg	.8222	.7547	.7477	.6455	.7537	.7224	.6440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 203 / 11 KV MALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2812	.3429	.2622	.2915	.3086	.2294	.2591
2	.3353	.3429	.2949	.5312	.6859	.6226	.5506
3	.4428	.3772	.3605	.8097	1.2003	1.0688	.7125
4	.6009	.3772	.4915	.8745	1.3717	1.2631	.8745
5	.7499	.6859	.7209	1.1336	1.3717	1.4083	1.2308
6	.8436	.823	.9717	1.406	1.5432	1.6004	1.2955
7	.9374		1.004	1.5546	1.406	1.6964	1.4575
8	.9831		.9717	1.6842	1.9204	1.7711	1.6194
9	.9374		.8848	1.5546	1.6644	1.8027	1.6194
10	.4999						
11	1.0288	1.0631	.9374				
12	1.3717	1.4723	1.3748				
13	1.5432	1.5364	1.5623				
14	1.5432	1.3927	1.4373				
15	1.6461	1.5364	1.4685				
16	1.6461	1.5684	1.5623	.2401	.2012	.2267	.3086
17	1.6461	1.5684	1.4373	.3086	.2622	.3239	.4115
18	1.6461	1.3763	1.406	.4115	.4915	.5506	.5487
19	.823	.852	.6802	.823	.7865	.9069	.8573
20	.6516	.5898	.6154	.6173	.5571	.7773	.6516
21	.4801	.4915	.421	.4801	.4588	.4534	.4115
22	.3429	.3277	.3353	.3772	.3277	.3563	.3429
23	.3086	.2949	.2812	.3429	.2949	.2915	.3429
24	.2915	.3086	.2949	.2591	.2743	.2622	.2267
Max	1.6461	1.5684	1.5623	1.6842	1.9204	1.8027	1.6194
Min	.2812	.2949	.2622	.2401	.2012	.2267	.2267
Avg	.8992	.8664	.8598	.7611	.8404	.8673	.7623

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 201 / 11 KV SARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.3429	.1905	.1905	.1905	.2096	.2096
2	.3441	.3048	.3401	.1905	.2096	.2477	.2096
3	.5407	.381	.5525	.2477	.2667	.2477	.2096
4	.7712	.4572	.5138	.3429	.3239	.2667	.2477
5	.8383	.5335	.6478	.5144	.4382	.2667	.2477
6	.9326	.6097	.9069	.6668	.5716	.4382	.3239
7	1.0343	.6097	.8684	.724	.7049	.6478	.5716
8		.8383	1.0111	.5716		.5525	.743
9	.9667	1.0526		.4954	.381	.5335	.4001
10	.381	.2105	.5144	.4191	.381	.2286	.2858
11	.2477	.1781		.3361	.4372	.6154	.4372
12				.8192	.9555	1.0364	.5335
13			.2096	.7865	1.2308	.9717	.6097
14	.1715	.0953		.3353	1.1984	1.085	.7316
15	.1524	.0953		1.0159	1.1363	.9717	.7621
16	.1715	.1143	.1524	.9831	1.1523	1.0202	.8383
17		.1715		1.0322	.6316	1.004	.9145
18		.3239	.4001	1.065	.6154	1.004	1.0364
19	.2286	.5716		.4001	.5144	.4001	.4763
20	.2667		.5525	.4954	.4001	.4763	.4763
21	.3048			.3429	.2858	.362	.5716
22	.3429	.2667	.3429	.2858	.2477	.2858	.381
23	.3429	.2286		.2477	.2477	.2477	.2858
24	.2096	.2858	.1905	.2096	.1905	.2096	.2096
Max	1.0343	1.0526	1.0111	1.065	1.2308	1.085	1.0364
Min	.1524	.0953	.1524	.1905	.1905	.2096	.2096
Avg	.4441	.3836	.4929	.5299	.5527	.5554	.4880

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 202 / 11 KV MUDGAD EKOJI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3887	.3353	.2896				
3	.6154	.5335	.3361				
4	.7373	.6859	.4049				
5	.8684	.9221	.6316				
6	.9831	1.0526	.6802				
7	1.2431	1.0669	.8097				
8	1.2793	1.1984	.9231				
9	1.3603	1.1336					
10					.4049		
11				.5247	1.0526	.502	.3887
12				1.0562	1.2003	1.0688	.5335
13				1.166			.6859
14				1.2308	1.2146		.8383
15				1.2146	1.1984		.9145
16				1.2631	1.1822		.9907
17				1.1043			1.0669
18				1.0242	.6316		.9602
Max	1.3603	1.1984	.9231	1.2631	1.2146	1.0688	1.0669
Min	.3887	.3353	.2896	.5247	.4049	.502	.3887
Avg	.9345	.8660	.5822	1.0730	.9835	.7854	.7973

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 203 / 11 KV KOKALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2477		.3239	.2667	.2286	.2477	.2477
2	.2858	.3048	.3239	.2439	.2591	.2591	.4696
3	.3429	.3353	.3429	.3048	.3978	.6316	.502
4	.4572	.4763	.4382	.5121	.5801	.7537	.5992
5	.6859	1.1431	.5906	.7611	.8048		.8002
6	.9145	1.0479	.8954	1.0227	.9088	.8745	1.1469
7	1.0479	.6668	.9907	1.0898	.9945		1.1603
8			.8954	.9724		1.1174	1.2407
9	.9717			.9389	.9282		1.1469
10	.7621	.4763		.4382	.3429	.4763	.381
11	.8421	.4858	.583	.2286	.1905	.3239	.2477
12	.8356	.7748		.1524		.1715	.1143
13	.9831	.7977	.4481	.1334		.1524	.1143
14	.9878	.8688		.1143		.1524	.1524
15	.9717	.7621	.8848	.1524			.1905
16	1.1498	.7935	1.0395	.1524		.1715	.381
17		.5506		.3429		.1715	.4763
18	.6097	.5668	.9389	.4191	.381	.381	.5716
19	.6668	.743		.6859	.743	.6478	.743
20	.6097	.5716	.7621	.743	.6097	.5906	.7621
21	.6097	.4191		.4763	.381	.4763	.6668
22	.5716		.381	.3429	.362	.3239	.5716
23	.381	.3239		.2667	.3239	.2858	.381
24	.2477	.2477	.3239	.2858	.2477	.2858	.2477
Max	1.1498	1.1431	1.0395	1.0898	.9945	1.1174	1.2407
Min	.2477	.2477	.3239	.1143	.1905	.1524	.1143
Avg	.6901	.6178	.6351	.4603	.5108	.4247	.5548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2715	.0914	.2715	.0429	.0762	.0514
2	.0072	.2715		.4525	.5716		.5335
3	.0732	.2715	.1086	.7011	.9335	.3144	.8764
4	.1086	.2715	.144	.8669	1.1812	1.2384	1.1812
5		.2715	.1677	1.0288	1.6575	1.6766	1.6194
6		.3544	.2347	1.0576	1.9052	1.8861	1.9052
7		.443	.192	1.5261	2.1529	1.9814	2.0767
8	.1029	.3856	.1677	1.6289	2.0957		1.0669
9		.3506		1.6549	1.9814		
10		.2686	.2686	.2103	.0396	.1303	.0427
11			1.4022	.0503			.1715
12	1.3717	.743	1.6118	.0377		.0572	.1715
13		1.8671	1.6289			.0572	.1612
14	1.6108	1.9052	1.6289			.0476	.1433
15	1.6108		1.6975			.0362	.1267
16	1.6108	1.9052	1.6787				.1267
17	1.5261	1.9433	1.5261	.0457			.1448
18	1.5091	1.8671	1.4575	.1057		.0309	.181
19	.362	.1715	.362	.1286		.0524	.2715
20	.4525	.2058	.3982	.0446		.0446	.362
21	.3982		.3982	.0396			.362
22	.362	.1372	.362	.0549		.1006	.3258
23	.2715	.1143	.3361	.056		.088	.2715
24	.096	.2715	.1067	.2715	.0412	.0914	.0817
Max	1.6108	1.9433	1.6975	1.6549	2.1529	1.9814	2.0767
Min	.0072	.1143	.0914	.0377	.0396	.0309	.0427
Avg	.7171	.6805	.7259	.5117	1.1457	.4653	.5328

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 202 / 11 KV BHOOTMUGLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2353	.1905	.2172	.2477	.2286	.2858
2		.3582	.381	.2195	.2286		.2667
3		.5316	.4763	.2172	.2667		.2667
4	.543	.8764	.6036	.2172	.3048	.2858	.3048
5		.8669	.9955	.2126	.3429		.4001
6	.6516	1.0288	1.166	.2629	.381		.5335
7	.0772	1.1145	1.2071	.3224	.4954		.5716
8	.7682	1.2269	.12	.3224	.5906	.4191	.5716
9	.8802	1.286	1.3375	.2686	.5144	.2858	.4191
10		.1448	.181	.2686	.362	.0189	
11			.1402	.4607			.3429
12	.1086	.1143	.1433	.873		.9332	1.2003
13	.1086		.1791	1.0467		.9568	1.1869
14	.1086	.0953	.1791	1.0059		.9686	1.267
15	.1086	.0943	.1086	1.0364		.9031	1.1869
16	.1086	.0943	.1086	1.0494	1.1012	.7716	1.1869
17	.1402		.1753	1.0269		.8215	1.1869
18	.2103	.1905	.2103	.8109		.873	1.2209
19	.3155	.3429	.2378	.3391		.4557	.181
20	.362	.381	.2715	.3601	.3429	.4161	.181
21	.362		.2686	.2429		.3641	.181
22	.2715	.3048	.2534	.3048	.2667	.381	.181
23	.2534	.2858	.2353	.2667		.3048	.2172
24	.2286	.2353	.2286	.2195	.2667	.2286	.2667
Max	.8802	1.286	1.3375	1.0494	1.1012	.9686	1.267
Min	.0772	.0943	.1086	.2126	.2286	.0189	.181
Avg	.3115	.4904	.3916	.4822	.4080	.5342	.5916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154108 / 33/11 KV AMBULAGA

Feeder No / Name : 201 / 11KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	2.0729	1.704	2.5692	2.0222		2.3205
10	2.3205	2.4249	2.7349	2.2939		2.3205
11	2.6189	2.6825		1.6804		2.5987
12	2.7496	2.8166	1.3765	2.1628		2.5149
13	2.9843	2.7183	2.5396	2.4531		2.7664
14	3.0521	2.7515		2.7496		2.652
15	2.9843	2.6852	2.6825	2.8502		2.5194
16			2.5857		2.5194	2.5194
17			2.6825		2.652	2.4863
18			2.7161		2.8837	1.9433
19			.6562		.6249	.703
20					.759	.759
21					.8223	.6874
22					.7907	.6958
23					.7907	.6562
24	1.6385					
Max	3.0521	2.8166	2.7349	2.8502	2.8837	2.7664
Min	1.6385	1.704	.6562	1.6804	.6249	.6562
Avg	2.5526	2.5404	2.2826	2.3160	1.4803	1.8762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 201 / NEW BANK COLONY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5959	.6733	.6135	.6733	.7011	.6722	.631
2	.5784	.691	.5784	.691	.6661	.6602	.631
3	.631	.7442	.5784	.7442	.6836	.6602	.6135
4	.6836	.7619	.631	.7796	.7362	.7922	.7011
5	.8063	.8328	.7362	.8328	.8764	.9808	.7537
6	.8764	.9036	.8764	.9568	1.0341	1.0059	1.1043
7	1.0517	1.1163	1.0166	1.0631	1.1218	1.1694	1.1919
8	1.1218	1.1163	1.0867	1.1694	1.0166	1.2323	1.1043
9	1.1393	1.0099	1.1218	.9568	1.0517	1.0808	1.1393
10	1.0808	.929	1.0631	.8764	.9313	.9816	1.0517
11	1.0277	.8589	.9922	.7362	.9214	.9465	.8939
12	.9922	.8063	.6379	.7186	.8505	.8589	.8413
13	.8682	.7362	.6733	.7011	.8505	.8238	.8063
14	.7973	.7362	.6379	.7011	.815	.7888	
15	.7796	.7011	.6556	.631	.7362	.8063	.7537
16	.7973	.7362	.5847	.7362	.7712	.7712	.7712
17	.8682	.7362	.8328	.7888	.8596	.8589	.8413
18	1.0985	1.0867	.9922	.9816	1.2178	1.1393	1.0867
19	1.1694	1.1218	1.1163	1.0867	1.2048		1.1393
20	.9391	.964	1.0985	1.0517	1.0745	1.0692	1.0517
21	.8505	.8764	.9391	.8764	.9511	.9465	.9465
22	.7087	.8238	.7973	.8063	.8413	.8063	.8764
23	.691	.7362	.7265		.6722	.7186	
24	.5959	.6733		.691	.7186	.679	.6661
Max	1.1694	1.1218	1.1218	1.1694	1.2178	1.2323	1.1919
Min	.5784	.6733	.5784	.631	.6661	.6602	.6135
Avg	.8645	.8488	.8255	.8370	.8877	.8891	.8907

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 202 / ASHOK NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1478	.1417	.1663	.1417	.1663	.1886	.1848
2	.1663	.1772	.1478	.1417	.1478	.1886	.1663
3	.2033	.2126	.2033	.1772	.2033	.1886	.2033
4	.2402	.3366	.2587	.2481	.2772	.2263	.2218
5	.3511	.4607	.3881	.3366	.3696	.415	.3326
6	.4805	.567	.5729	.567	.5914	.6348	.6653
7	.6653	.815	.8316	.7796	.7207	.6602	.7392
8	.8316	.8328	.7392	.7442	.8131	.8029	.6838
9	.6468	.6556	.6283	.6556	.7392	.5601	.6468
10	.5316	.5914	.5316	.4435	.5601	.5359	.499
11	.4607	.3881	.3544	.3326	.3361	.4805	.2218
12	.3544	.3142	.2303	.2587	.2829	.3511	.2033
13	.2835	.2402	.1949	.2033	.2263	.2218	.1663
14	.2481	.1848	.1772	.1663	.1886	.2033	
15	.2126	.1478	.2126	.1663	.1886	.1848	.2218
16		.2218	.1949	.2218	.2054	.2033	.2218
17	.2303	.2957	.2481	.2772	.2641	.2402	.2957
18	.443	.4435	.4607	.3881	.5093	.3881	.4066
19	.4961	.499	.4784	.5544	.5658		.6283
20	.4252	.4251	.3366	.4435	.4904	.499	.462
21	.3012	.3511	.2303	.3326	.3772	.3696	.3511
22	.2126	.2772	.2149	.2402	.2263	.2772	.2587
23	.1772	.2218	.1772		.2075	.2402	
24	.1478	.1595	.1848	.1595	.1848	.1886	.2033
Max	.8316	.8328	.8316	.7796	.8131	.8029	.7392
Min	.1478	.1417	.1478	.1417	.1478	.1848	.1663
Avg	.3590	.3734	.3401	.3469	.3684	.3586	.3629

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 201 / 11 KV ANASARWADA GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.7202
8				.6344
9				.6344
10		.6516		
14	.1543		.1543	
16	.2058			
17			.2229	
18	.4973		.5144	
23			.4458	
Max	.4973	.6516	.5144	.7202
Min	.1543	.6516	.1543	.6344
Avg	.2858	.6516	.3344	.663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 202 / 11 KV ANASARWADA AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)
7		2.2291
8		2.0748
9		2.1948
14	2.452	
16	2.2291	
18	1.7833	
Max	2.452	2.2291
Min	1.7833	2.0748
Avg	2.1548	2.1662

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 203 / 11 KV TALIKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.8059
8				.6516
9				.703
10		.8059		
14	.9774		1.166	
16	1.0631			
17			1.1317	
18	.9431		.8059	
23			.4801	
Max	1.0631	.8059	1.166	.8059
Min	.9431	.8059	.4801	.6516
Avg	.9945	.8059	.8959	.7202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 201 / 11KV SYED ANKULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.0229	.3239	.3429	.2515		.1905
2	.2012	.0229	.3239	.4954	.2515		.3048
3	.2515	.0286	.3048	.6859	.3353		.3048
4	.2515	.0286	.3048	.6173	.3506		.381
5	.3353	.0286	.3429	.6173	.4382		.4572
6	.3353	.0381	.3429	.6516	.7362		.5792
7	.3353	.0381	.381		.8063		.7164
8	.2515	.0343	.381		.8764		.6859
9		.0286	.381		.9114		.7164
10	.2012	.0286				.3429	.2286
11	.3353	.3963	.4954	.3018	.3048	.2286	.0229
12	.5365	.5182	.6516	.2515	.3048	.1905	.0191
13	.5365	.5335	.7202	.2515	.3048	.2286	.0191
14		.6401	.6859	.2515	.3048	.1905	.0191
15	.6371	.6097	.6859		.2667	.1905	.0191
16	.6706	.5335	.583	.1677	.1905	.1905	.0229
17	.6706	.5335	.583		.1905	.1905	.0229
18	.5868	.6097	.6173			.1905	.0286
19	.0286	.3429	.3048	.2515		.2286	.0286
20	.0286	.3429	.3048	.2515		.3239	.0286
21	.0286	.381	.3429	.2683		.3429	.0286
22	.0286	.3429	.3429	.2515		.3048	.0286
23	.0286	.3429	.3429			.2286	.0191
24	1.5432	.0229	.3429	.3429			.2286
Max	1.5432	.6401	.7202	.6859	.9114	.3429	.7164
Min	.0286	.0229	.3048	.1677	.1905	.1905	.0191
Avg	.3670	.2687	.4387	.3750	.4265	.2409	.2125

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 202 / 11 KV BIBRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.0572	.5716	.724	.503		.6668
2	.5868	.0572	.6668	1.0288	.8383		.6097
3	.6371	.061	.7621	1.2346	1.262		.9145
4	.7545	.061	.7621	1.2689	1.3672		1.6766
5	.8048	.0667	.8573	1.3375	1.3672		1.829
6	.8718	.0857	1.0479	1.3717	1.4022		1.9052
7	1.0166	.0953	1.1431		1.7528		2.0271
8	.7545	.0953	1.1431		2.3663		2.1795
9		.0953	1.0288		2.2786		1.9814
10	.503	.7621	.5716			.5716	.5716
11	1.0059	1.1431	1.5432	.503		.4763	.0476
12	1.2574	1.6766	2.4863	.4694		.4191	.0476
13	1.4754	1.829	2.5774	.4694		.4191	.0476
14	1.8442	1.9814	2.1434	.4191	.4954	.381	.0419
15	2.0119	1.829	2.1262		.5335	.4191	.0419
16	2.0957	1.6766	2.1605	.3688	.5335	.381	.0476
17	2.0957	1.829	2.0576		.5335	.4382	.0476
18	2.0119	1.9052	2.0233			.4763	.0572
19	.0572	.5716	.6097	.503		.6668	.0667
20	.0667	.6668	.6859	.5365		.7621	.0667
21	.0667	.7621	.6859	.5868		.8573	.061
22	.0667	.7621	.6859	.5365		.8573	.061
23	.0572	.6668	.6859			.7621	.0572
24	2.0576	.0572	.6668	.724	.503		.7621
Max	2.0957	1.9814	2.5774	1.3717	2.3663	.8573	2.1795
Min	.0572	.0572	.5716	.3688	.4954	.381	.0419
Avg	.9864	.7831	1.2372	.7551	1.1240	.5634	.6590

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 203 / 11 KV Ujed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.0343	.381	.4572	.2515		.381
2	.3018	.3353	.381	.4572	.2515		.381
3	.3506	.3353	.4572	.4954	.3018		.381
4	.3506	.3353	.5335	.4954	.3018		.381
5	.5258	.503	.6097	.6097	.3353		.4763
6	.5609	.503	.6097	.6668	.4024		.4763
7	.5258	.5365	.5335		.4359		.5335
8	.5258	.5365	.5335		.5365		.5716
9		.5868	.5335		.5365		.5716
10	.2515	.2858	.381			.5716	
11	.0286	.2858	.3048	.5258		.381	
12	.0229	.2858	.3048	.5609		.4572	
13	.0229	.2858	.2286	.5609		.5335	
14	.0191	.381	.1905	.503	.381	.6097	.4191
15	.0191	.2858	.1905		.5525	.5335	.4191
16	.0191	.2858	.1905	.4908	.547	.5335	.503
17	.0286	.3429	.381		.4904	.4572	.503
18	.0343	.381	.4572			.4268	.503
19	.0381	.4191	.4572			.4763	.0343
20	.0419	.4763	.4954	.3018		.4763	.0381
21	.0419	.4191	.4191			.381	.0381
22	.0381	.381	.4191			.381	.0381
23	.0381	.381	.381	.3353		.381	.0286
24	1.3717	.0343	.381	.381	.2515		.381
Max	1.3717	.5868	.6097	.6668	.5525	.6097	.5716
Min	.0191	.0343	.1905	.3018	.2515	.381	.0286
Avg	.2352	.3599	.4064	.4887	.3983	.4714	.3529

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 204 / 11kv Halki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.0286		.4191	.2515		.381
2	.3506	.3353		.4572	.2515		.381
3	.4382	.503		.4572	.3353		.381
4	.5258	.5868		.4572	.4024		.381
5	.7888	.7545		.4954	.4359		.381
6	.8764	.8383		.4954	.4359		.4191
7	.8764	.8383			.4694		.4191
8	1.0059	1.0059			.503		.4763
9		1.0059			.4694		.4191
10	.2515	.0286				.6478	.4191
11	.0286		.3048	.7011	.724	.5487	.5868
12	.0286		.2667	.964	.9945	.8688	.6706
13			.1905	.964	1.166	.884	.9221
14	.0229		.1905	.964	1.166	.7926	.9221
15	.0229		.1905		1.0631	.8535	
16			.1905	.8764	1.0974	.9297	
17			.2286		1.0974	.884	.8383
18	.0286		.2667			.8383	.9221
19	.0381		.3048	.3353		.5716	.0343
20	.0476		.3429			.5716	.0381
21	.0476		.3429	.3018		.4763	.0381
22	.0381		.381	.3018		.4763	.0381
23	.0381		.4191			.381	.0343
24	2.572	.0343		.4191	.3018		.381
Max	2.572	1.0059	.4191	.964	1.166	.9297	.9221
Min	.0229	.0286	.1905	.3018	.2515	.381	.0343
Avg	.4145	.5418	.2784	.5739	.6567	.6946	.4311

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.713	2.672	2.8826	.8402	.7468	.8775	.8215
9	2.4417	2.834	2.8487	.8962	.8402	.8775	.6697
12		.2987		2.672	2.5774	2.4417	
15	.2427	.1867		2.672	2.713	2.5774	
16			.2204				
18	.5601	.5792		2.4291	2.1704	2.1704	
19							.6516
21	.5601			.4668			
24	.4481	.3734	.3361	.4481	.3734	.3734	.3361
Max	2.713	2.834	2.8826	2.672	2.713	2.5774	.8215
Min	.2427	.1867	.2204	.4481	.3734	.3734	.3361
Avg	1.1610	1.1573	1.5720	1.4892	1.5702	1.5530	.6197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.6348	.6535	.6348	1.1336	.9717	1.153	1.0174
9	.5788	.5601		1.2146	1.2146	1.4243	1.2887
12	1.1336	1.2887		.2172		.2614	
15	1.1336	1.3565		.1494	.181	.1494	
16			1.1568				
18	1.1336	1.2209		.3734	.4108	.4294	
19							.499
21	.3361						
24	1.8861	.2241	.2614	.2801	.3361	.2987	.2614
Max	1.8861	1.3565	1.1568	1.2146	1.2146	1.4243	1.2887
Min	.3361	.2241	.2614	.1494	.181	.1494	.2614
Avg	.9767	.8840	.6843	.5614	.6228	.6194	.7666

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 203 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	2.0348	1.9433	2.5434		.905	.9412	.8215
9	2.5095	2.3482	2.2382		.6335	.8215	.8215
12	.2172	.2054		1.2146	1.9669	1.9669	
15		.1307		2.0243	2.4417	2.4417	
16			.1658				
18	.1448	.5611		2.1052	2.3061	2.1026	
19							.7373
21	.4525			.543			
24	2.0576	.362	.3258		.4525	.4481	.4481
Max	2.5095	2.3482	2.5434	2.1052	2.4417	2.4417	.8215
Min	.1448	.1307	.1658	.543	.4525	.4481	.4481
Avg	1.2361	.9251	1.3183	1.4718	1.4510	1.4537	.7071

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 204 / 11 KV DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3734	.5281	.4344	1.8623	1.6194	2.1026	2.3739
9	.0724	.4527	.4108	1.9433	2.0243	2.1956	2.3061
12		2.2043		.0754	.1086	.0724	
15	2.2672	2.2043		.0754	.112	.0747	
16			2.3205				
18	2.0243	2.2043		.2263	.2896	.2987	
19							.3982
21	.415			.3772			
24	.181	.3395	.3361	.3018	.3395	.1494	.112
Max	2.2672	2.2043	2.3205	1.9433	2.0243	2.1956	2.3739
Min	.0724	.3395	.3361	.0754	.1086	.0724	.112
Avg	.8889	1.3222	.8755	.6945	.7489	.8156	1.2976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2743				.3658	
4							.6001
7			.9431			.9145	
8		.9145			.9431		
9	.8573					.823	.6001
11	.5487				.5487		
12		.3429		.5144			.5144
13	.4572				.4572		
15		.3429					
16					.3658		
17	.4572						
21					.5487		
22	.4572						
23		.4287		.4287			.4287
24	.3429		.4287		.3429	.4287	
Max	.8573	.9145	.9431	.5144	.9431	.9145	.6001
Min	.3429	.2743	.4287	.4287	.3429	.3658	.4287
Avg	.5201	.4607	.6859	.4716	.5344	.633	.5358

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1638				.3277	
4							.4287
7			.4287		1.286	.8192	
9	.5144		.4287			.8192	.8573
11	.4915				.1638		
12		.6859		.1715			.1715
13	.5735				.1638		
15		.7716					
16					.1638		
17	.6554						
21					.3277		
22	.2458						
23	1.3717	.2572		.4287			.2572
24	.2572		.1715		.2572	.1715	
Max	1.3717	.7716	.4287	.4287	1.286	.8192	.8573
Min	.2458	.1638	.1715	.1715	.1638	.1715	.1715
Avg	.5871	.4696	.3430	.3001	.3937	.5344	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 203 / 11KV ARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.8097				.4049	
4							.5144
7			1.8861		.6859	.6478	
8		1.8623					
9	2.0576		2.3148			.5668	.4287
11	.3239				1.2146		
12		.2572		2.1434			2.3148
13	.2429				2.0243		
15		.2572					
16					1.9433		
17	.1619						
21					.6478		
22	.5668						
23		.5144		.5144			.6001
24	1.3717		.3429		.5144	.3429	
Max	2.0576	1.8623	2.3148	2.1434	2.0243	.6478	2.3148
Min	.1619	.2572	.3429	.5144	.5144	.3429	.4287
Avg	.7875	.7402	1.5146	1.3289	1.1717	.4906	.9645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 204 / 11KV WATER WORKS NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0229			
7			.0343		.0343
8		.0572			
9	.1715		.0343		
11	.0248				.0229
12		.0343		.0343	
13	.0248				
15		.0343			
17	.0248				
22	.0229				
23		.0343		.0343	
24	.0343		.0343		.0343
Max	.1715	.0572	.0343	.0343	.0343
Min	.0229	.0229	.0343	.0343	.0229
Avg	.0505	.0366	.0343	.0343	.0305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG SEPARATED AG FEEDERS HAVING SPECIAL
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.7392				.037	
4							.0343
7			1.8004		.0343	.037	
8		1.7556					
9	1.8861		1.8861			.037	.0343
11	.0924				1.5708		
12				1.7147			2.1434
13					1.9404		
16					2.0328		
17	.037						
21					.0554		
22	.037						
23		.0343		.0343			.0343
24	.0343		.0343		.0343	.0343	
Max	1.8861	1.7556	1.8861	1.7147	2.0328	.037	2.1434
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4174	.8430	1.2403	.8745	.9447	.0363	.5616

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2801				1.0269	
4							1.2003
7			.4287		2.2291	2.0538	
8		.7468					
9	.2572		.3429			2.4272	2.1434
11	1.307				.1867		
12		1.7147		.1715			.1715
13	2.0538				.1867		
15		2.0576					
17	1.9605						
21					.4668		
22	.3734						
23		.2572		.3429			.2572
24	.1715		.1715		.2572	.2572	
Max	2.0538	2.0576	.4287	.3429	2.2291	2.4272	2.1434
Min	.1715	.2572	.1715	.1715	.1867	.2572	.1715
Avg	1.0206	1.0113	.3144	.2572	.6653	1.4413	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 201 / 11 KV TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3292	.3475	.3658	.2926	.3292	.3258
2	.6661	.6173	.6516	.3658	.2926	.3292	.3077
3	.7362	.6859	.7164	.4024	.3292	.3292	.3258
4	.9465	.7888	.8238	.439	.3658	.3658	.362
5	1.262	.8916	.9313	.4755	.4024	.439	.4344
6	1.3565	1.0562	1.2048	.6219	.6219	.5487	
7	1.4754	1.3748	1.387	.6219	.724	.543	
8	1.4586	1.576	1.5424	.6219	.724	.5792	.3258
9	1.326	1.6095	1.4754	.567	.5792	.4024	
10	.439		.439	.3292	.362	.298	1.1163
11			.2926	.9313	1.1218		1.1043
12	.1646		.1646	1.1218	1.5424		1.4723
13	.128	.1463	.128	1.3108	1.6476		1.7177
14			.1097	1.3763	1.7528		1.949
15			.0732	1.4586		1.1012	1.8781
16			.0914	1.3763		1.5223	1.6655
17			.1097	1.3763		1.5223	***
18	.4207	.2561	.2926	1.2209	1.6461	1.4575	1.0099
19	.6401	.5544	.5121	.543	.5304	.6154	
20	.5487	.5121	.4938	.4755	.4755	.543	
21	.4755	.439	.3841	.4024	.439	.4706	.4207
22	.4024	.3658	.3658	.3292	.3658	.3982	.3898
23	.3292	.3658	.3658	.3292		.3258	.3155
24	2.2291	.3292	.3475	.3658	.2926	.3292	.3258
Max	2.2291	1.6095	1.5424	1.4586	1.7528	1.5223	11.4461
Min	.128	.1463	.0732	.3292	.2926	.298	.3077
Avg	.8072	.6999	.5521	.7262	.7254	.6225	1.4154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 202 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2172	.2926	.2195				
3		.3292	.3258				
4	.394	.3658	.3898				
5	.5373	.439	.4557				
6	.6805	.5487	.631				
7	.7442	.6584	.7011				
8	.7522	.7499	.6805				
9	.7011	.6516	.6379				
11				.362	.3012	.4115	.5258
12				.4252	.3544	.4458	.6024
13					.4607	.4801	.6661
14				.4207	.4908	.3772	.7442
15				.4382		.4287	.7796
16				.4207		.5144	.7011
17				.4207		.5144	.631
18				.4961	.5434	.5144	.4706
24	2.0576						
Max	2.0576	.7499	.7011	.4961	.5434	.5144	.7796
Min	.2172	.2926	.2195	.362	.3012	.3772	.4706
Avg	.7605	.5044	.5052	.4262	.4301	.4608	.6401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 203 / 11 KV GHUGI SANGVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124		.128			.128	
2	.1254		.1086	.2229		.181	.2058
3	.128		.1448	.3429		.4075	.2743
4			.181	.4115		.4961	.3429
5	.2561		.2896	.4694		.5373	.4458
6	.439		.3982	.6036		.6805	
7	.5121		.439	.7377		.788	
8	.4755		.4024	.7712		.8505	
9	.3658		.3658	.7712	.6935	.8413	
10		.3224		.1463	.7796		.703
11	.4024	.3224	.4024	.0914	.3544		.1715
12	.6584		.6718		.1417		.1715
13	.7164	.7164	.6882	.0886	.1595		.1372
14	.815	.6733	.7209	.0724	.1772		.1052
15	.8063	.7712	.8029	.0914			.1052
16	.7796	.7712	.8029	.1097			
17	.7712	.7712	.8029	.128			
18	.631	.7011	.7712	.2195	.2454		.1928
19		.3155		.3292	.3292		
20		.2561		.2561	.2561		.2835
21		.1829		.1829	.2195		.2126
22		.1463			.1829		.1772
23		.128					.1402
24	1.5432		.128			.128	
Max	1.5432	.7712	.8029	.7712	.7796	.8505	.703
Min	.124	.128	.1086	.0724	.1417	.128	.1052
Avg	.5617	.4675	.4583	.3182	.3217	.5038	.2446

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 204 / 11 KV NEW TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	2.2291
Max	2.2291
Min	2.2291
Avg	2.2291

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 201 / 11 KV SHIVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926		.3429	.381		.381	
2	.7373	.6859	.823	.381		.4763	
3	1.4403		1.5844	.381		.4763	
4	1.7147	1.3717	1.7604	.381		.5716	
5	1.8861		1.8404	.4572		.5335	
6	2.0405	1.4632	1.9204	.4572		.5716	
7	2.2291		2.2291	.4572		.4763	.381
8	2.0576	1.448	2.2085	.4572			
9	2.0576		2.2862		.381		
10			.3048		.4763		
11	.3048	.3086	.3048		.9145	.9145	
12		.3467	.3048	1.5242	2.2481		
13	.3048	.3582	.3048		2.3624	1.2193	
14		.3582	.381	1.7528	2.4768		
15	.3048	.3429	.381		2.5911	1.2193	1.2193
16		.4344	.381	1.9433	2.5911		
17		.4115	.381		2.6673	1.2193	
18	.3048	.439	.381	1.829	2.6673		
19		.3772	.381	.4049	.381		
20		.4298	.381		.381		
21		.3814	.381		.381	.381	
22		.3814	.381		.381		
23	.381	.3856	.381		.381	.381	
24	2.0576	.3048	.381		.381		.4049
Max	2.2291	1.4632	2.2862	1.9433	2.6673	1.2193	1.2193
Min	.2926	.3048	.3048	.381	.381	.381	.381
Avg	1.2076	.5683	.8502	.8313	1.3539	.6785	.6684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 202 / 11 KV HIPPALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467		.3224	.2858		.381	
2	.2957		.3121	.5335		.6859	.3048
3	.2926		.3429	.724	.7621	.9145	
4	.3292	.3277	.3467	.9145		1.0669	.7621
5	.3658		.3772	1.0669	.9145	1.2193	
6	.3658	.3048	.3772	1.2193		1.2955	.9145
7	.439			1.2955	1.0669	1.4098	
8	.4024	.3048	.4115	1.3717			.9145
9			.4572	1.2955	.9145		
10	.3048		.381		.2858		
11		.3429	.6859		.2858		
12	.9717	.6173	.9145		.2858		
13	1.065	.7888	.9907		.2858		
14		.8573	1.105				
15	1.1469	.9431	1.2955		.2858		
16		.8573	1.4098		.2858		
17	.9012	.8002	1.448		.2858		
18	.3277	.7682	1.2193		.2858		
19		.3121	.2858	.381	.381		
20		.3429	.2858		.381		
21		.3856	.2858		.381		
22		.3814	.2858		.381		
23	1.5432	.3467	.2858		.381	.3048	
24	.3582	.2458	.2858		.381		.7621
Max	1.5432	.9431	1.448	1.3717	1.0669	1.4098	.9145
Min	.2926	.2458	.2858	.2858	.2858	.3048	.3048
Avg	.5910	.5251	.6136	.9088	.4572	.9097	.7316

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 203 / 11 KV GANESHWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732		.0895	.0953		.0953	
2	.1715	.1829	.1543	.0953		.0953	
3	.3086		.3086	.0953		.0953	
4	.3086	.2286	.3601	.0953		.0953	
5	.3429		.3841	.0953		.0953	
6	.3429	.2286	.4001	.0953		.0953	
7	.3772		.4001	.0953		.0953	
8	.4115	.3048	.4321	.0953			.1219
9	.4115			.0953			
10			.0953				
11	.0762		.0953			.3048	
12		.0867	.0953	.4572			
13		.0867	.0953		.3429	.381	
14	.1219	.0867	.0953	.4572	.4572		
15		.0914	.0953		.5335	.4572	.4572
16		.0867	.0953	.5335	.6097		
17		.0867	.0953		.5716	.4572	
18		.0895	.0953		.5335		
19		.0895	.0953	.1219	.0953		
20		.0914	.0953		.0953		
21		.0857	.0953		.0953		
22		.0895	.0953		.0953		
23	.081	.0895	.0953		.0953	.1219	
24	.6859	.0762	.0953		.0953		.1219
Max	.6859	.3048	.4321	.5335	.6097	.4572	.4572
Min	.0732	.0762	.0895	.0953	.0953	.0953	.1219
Avg	.2856	.1224	.1721	.1867	.3017	.1991	.2337

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 203 / 11 KV THODAGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-DEC-17
HR	Load (MW)
24	.0934
Max	.0934
Min	.0934
Avg	.0934

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 204 / 11 KV NANDURA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.1867
Max	.1867
Min	.1867
Avg	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 201 / 11 KV KINGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6859
6						1.3375
8			1.5432	1.286		
10		1.3717				
12						.8573
14					.7545	.6859
16		1.0288			.7716	
17				.8573		
20					1.2003	
23				.7716		
24	.703			.6859	.6859	
Max	.703	1.3717	1.5432	1.286	1.2003	1.3375
Min	.703	1.0288	1.5432	.6859	.6859	.6859
Avg	.703	1.2003	1.5432	.9002	.8531	.8917

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 203 / 11 KV KOPARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.6173
6						1.5089
8			1.5432	1.2003		
10		1.1145				
11					3.0864	2.4006
12						2.4006
14					2.8292	2.2291
16		.6859			2.4006	2.572
17				2.572		
20					.9431	
23				2.2291		
24	.7202			.6001	2.2291	
Max	.7202	1.1145	1.5432	2.572	3.0864	2.572
Min	.7202	.6859	1.5432	.6001	.9431	.6173
Avg	.7202	.9002	1.5432	1.6504	2.2977	1.9548

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154018 / 33/11 KV KINGAON

Feeder No / Name : 204 / 11 KV KINGAON EXPRESS

NON SHEDDABLE WATER SUPPLY AND

FEEDER Feeder KV- 11 /

UTILITY

OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0137
6						.0086
8			.0137	.0137		
14					.0034	
16		.0034				
17				.0034		
20					.0137	
23				.0086		
24	.0034			.0034	.0086	
Max	.0034	.0034	.0137	.0137	.0137	.0137
Min	.0034	.0034	.0137	.0034	.0034	.0086
Avg	.0034	.0034	.0137	.0073	.0086	.0112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 201 / 11 KV UJANA

Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.2803	1.0974	1.1706
16	1.9845	1.7718	1.893
24	.924	.9335	.8962
Max	1.9845	1.7718	1.893
Min	.924	.9335	.8962
Avg	1.3963	1.2676	1.3199

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 202 / 11 KV SANGHAVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17
HR	Load (MW)	Load (MW)
8	1.0242	1.0974
16	3.2952	2.9447
24	.8215	.7316
Max	3.2952	2.9447
Min	.8215	.7316
Avg	1.7136	1.5912

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 203 / 11 KV GANGA HIPPARGA
Feeder KV- 11 / OUTGOING

SINGLE PHASING

DATE	01-DEC-17	02-DEC-17
HR	Load (MW)	Load (MW)
8	2.8349	3.155
16	.6584	.5792
24	.5853	.5601
Max	2.8349	3.155
Min	.5853	.5601
Avg	1.3595	1.4314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 205 / 11KV BALGHAT KARKHANA NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.0747	.1829	.0732
16	.0934	.0732	.0724
24	.0747	.0934	.0747
Max	.0934	.1829	.0747
Min	.0747	.0732	.0724
Avg	.0809	.1165	.0734

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 201 / 11 KV DHALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
1	2.0576
2	2.0576
3	2.2291
4	2.4006
5	2.4006
6	2.572
7	2.4006
8	2.4006
9	.5144
11	.5144
13	.583
14	.6859
15	.6859
17	.7716
18	1.0288
19	1.2003
20	1.2003
21	1.286
22	1.2003
23	1.0288
24	1.0288
Max	2.572
Min	.5144
Avg	1.4403

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 202 / 11 KV ANDHORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.5432
Max	1.5432
Min	1.5432
Avg	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154081 / 33/11 KV ANDHORI

Feeder No / Name : 203 / 11 KV KENDREWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
23	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144		.5144	.6001	.6001	.5144	.5144
16	2.4006	2.4006	2.1434	.1715		.2058	.1715
24	.2572	.2572	.2572	.2572	.8573	1.286	1.286
Max	2.4006	2.4006	2.1434	.6001	.8573	1.286	1.286
Min	.2572	.2572	.2572	.1715	.6001	.2058	.1715
Avg	1.0574	1.3289	.9717	.3429	.7287	.6687	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 203 / 11 KV KAJAL HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.7435	3.0007	2.4863				
16	.2572	.2572	.1715	3.0864		2.572	1.6289
24	.3429	.3429	.4287	.3429	.4287	.4287	.4287
Max	2.7435	3.0007	2.4863	3.0864	.4287	2.572	1.6289
Min	.2572	.2572	.1715	.3429	.4287	.4287	.4287
Avg	1.1145	1.2003	1.0288	1.7147	.4287	1.5004	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326		.3511	.3326	.3511		.3511
2	.3696		.3696	.3511	.4251	.4066	.3511
3	.4066	.5544	.3696	.3696	.5544		.3511
4	.4435		.4805	.4435	.5914	.5914	.3696
5	.5175		.6653	.5914	.6653		.5914
6	.6838	.8871	.8131	.7762	.8316	.924	.8316
7	.8131		1.1088	1.0534	.961	.9979	1.0349
8	.8871	1.0164	1.0164	1.0719	.8871	.8871	.8501
9	.924	.8871	1.0349	.924	.8316	.7762	.7947
10	.7392	.4066	.924	.8316	.7762	.6838	
11			.462	.5359	.5729	.4805	.5544
12	.4435		.5175	.4251	.4066		
13			.3696	.3696			.3142
14	.3511	.2772	.3326	.2957		.3142	
15	.2957	.4435	.3326	.2587		.2957	.3326
16		.4066	.3511	.2957		.3142	.3696
17	.3696	.4805	.3696	.3881	.4251	.3326	.3696
18	.7023	.7207	.7023	.6283	.6468	.6653	.6838
19		.7762	.8131	.8131	.7392	.7762	.8131
20		.6099	.6283	.7392		.6653	.7023
21	.5544	.5175	.4805	.6653	.5544	.5544	.5544
22		.4066	.4066	.5544		.4435	.4435
23	.4805	.3881	.3696	.5175	.4435	.4066	.4251
24	.4805	.4066	.3696	.3326	.4435	.4066	.3696
Max	.924	1.0164	1.1088	1.0719	.961	.9979	1.0349
Min	.2957	.2772	.3326	.2587	.3511	.2957	.3142
Avg	.5441	.5741	.5683	.5652	.6170	.5748	.5456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				1.5364	.0316	.0305	1.5364
3				1.6004	.0316		1.6004
4				1.9204	.0316	.0305	1.6644
5				1.9845	.0316		1.7604
6				2.0485	.0316	.0305	1.7604
7				2.0805	.0316	.0305	1.8884
8				2.7526		.0305	2.1445
9				2.2405		.061	2.1125
10	2.2405	1.9814	2.2405				
11		2.7206	2.5606				
12	2.4387	2.5286	2.6406		.4066		
13		2.7206	2.4646				
14	2.652	2.7206	2.4006				
15	2.6566	2.6886	2.4326				
16		2.6246	2.4646				
17	2.5149	3.0308	2.4966				
Max	2.6566	3.0308	2.6406	2.7526	.4066	.061	2.1445
Min	2.2405	1.9814	2.2405	1.5364	.0316	.0305	1.5364
Avg	2.5005	2.6270	2.4626	2.0205	.0852	.0356	1.8084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	1.7604	1.6156	1.8884				
3	2.0165		1.9845				
4	2.0805	1.89	2.0485				
5	2.2085		2.1445				
6	2.3045	2.0424	2.2405				
7	2.4006		2.3365				
8	2.4806	1.8595	2.3045				
9	2.5606	2.0424	2.1125				
10				1.9204	.0316	.061	2.2405
11				2.372	.061	.064	2.6886
12				1.9608	.0305		2.9127
13				2.3365			2.9767
14				2.4669		2.2405	
15				2.5301		2.4966	2.8166
16				.0316		2.6246	2.8807
17				.0316	.0305	2.6246	2.9767
Max	2.5606	2.0424	2.3365	2.5301	.061	2.6246	2.9767
Min	1.7604	1.6156	1.8884	.0316	.0305	.061	2.2405
Avg	2.2265	1.8900	2.1325	1.7062	.0384	1.6852	2.7846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
ST

Feeder No / Name : 201 / 11KV BUSTAND FEEDER.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	1.5402
Max	1.5402
Min	1.5402
Avg	1.5402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
STFeeder No / Name : 202 / 11KV TELEPHONE FEEDER SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.7773
Max	.7773
Min	.7773
Avg	.7773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432] BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
STFeeder No / Name : 203 / 11KV EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-DEC-17
HR	Load (MW)
24	.16
Max	.16
Min	.16
Avg	.16

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
9		.0951	
11			1.6129
24	1.9052		
Max	1.9052	.0951	1.6129
Min	1.9052	.0951	1.6129
Avg	1.9052	.0951	1.6129

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.1029		.1029	.0914	.1029
2	1.0974	1.2125	1.0059		.1029		.1029
3		1.326	1.1736		.1029		.1029
4	1.0974	1.4575	1.1336		.1029		.1372
5		1.5684	1.4575		.1029	.0914	.1372
6	1.5242	1.7185	1.7814		.1017		.1341
7		1.906	1.9433		.1017		.1341
8	1.829	1.9433	1.9433		.1029	.0914	.1341
9		2.0081		.1029	.1029		
10	.1017	.1029		1.3592	1.2498		
11	.1029	.0686		1.9608	1.5242		
12				1.906	1.5546	1.9433	
13				1.8747	1.7071	2.0081	
14				1.9292		2.1052	
15		.0686		1.8435	1.5242	1.9433	
16	.1017	.0686		1.8976	1.6156	1.9433	
17	.1017	.0686		1.906		1.8351	
18	.1029	.0686		.1029		.0686	
19	.1017	.1029		.1029		.1029	
20	.1029	.0686		.1029	.0914	.1029	
21	.1017	.0686		.1029		.1029	
22	.1029	.0686		.1029	.0914	.1029	
23	.1017						
24	.0914	.104	.1029		.1029	.0914	.1029
Max	1.829	2.0081	1.9433	1.9608	1.7071	2.1052	.1372
Min	.0914	.0686	.1029	.1029	.0914	.0686	.1029
Avg	.4441	.7051	1.1827	1.0925	.5769	.8416	.1209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1029	.3086		.1029	.1029	.2058
2	1.0974	1.0608	1.0059		.1029		.2058
3			1.3413		.1029		.2743
4	1.0974	1.1984	1.4575		.1029		.3086
5		1.4723	1.6194		.1029	.0914	.3688
6	1.5242	1.5813	1.7814		.1029		.503
7		1.6872	2.0405		.1017	.0914	.6036
8	1.829	1.7166	2.079		.1029	.0914	.6036
9		1.6842		.1029	.1029		.503
10	.1017	.1029		1.2407	1.6766	1.5546	
11	.1029	.2401		1.9006	1.829	1.749	
12	.1017	.2012		1.8884	1.829	1.9433	
13	.1029	.2267		1.9204	1.768	1.9433	
14	.1029	.1943		1.8564	1.768	1.9433	
15	.1029	.1715		1.7185	1.6461	1.9433	
16	.1017	.1715		1.5043	1.6766	1.7814	
17	.1029	.2058		1.6518		1.7166	
18	.1029	.1715		.1029		.0686	
19	.1029	.3429		.1029		.1715	
20	.1029	.4115		1.3717	.0914	.2058	
21	.1029	.3429		.1029		.2401	
22	.1017	.2401		.1029	.0914	.3086	
23	.1029						
24	.0914	.1029	.2058		.1029	.0914	.2401
Max	1.829	1.7166	2.079	1.9204	1.829	1.9433	.6036
Min	.0914	.1029	.2058	.1029	.0914	.0686	.2058
Avg	.3724	.6195	1.3155	1.1120	.7055	.8910	.3817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9614	.9717		.1029	.0914	.1029
2	.0914	.1029	.1029		.6706		.6706
3		.1029	.1029		.8048		.8048
4	.0914	.1029	.1006		.8288		.8048
5		.1017	.1006		.8951	.7621	.8421
6	.0914	.1017	.1006		.9831		.9717
7		.1029	.1006		1.0364	1.0669	1.1336
8	.0914	.1029	.1029			1.0669	1.2308
9		.1029		.9831	1.1469		1.0688
10	.1029	.1029		.1029	.1029	.0914	
11	.1029	.1029		.1029	.0914	.1029	
12		.1006		.1029	.0914	.1029	
13		.0972		.1029	.0914	.1029	
14		.0972		.1029	.0914	.1029	
15		.1029		.1029	.0914	.1029	
16	.1029	.1029		.1029	.0914	.1029	
17	.1029	.1029		.1029		.1029	
18	1.2452	1.1736		.1029			
19	1.1797	1.1401		.1029			
20	1.1336	1.073		.1029	.0914	.1029	
21	1.0814	1.073		.1029		.1029	
22	1.0159	1.0631		.3601	.0914	.1029	
23	.9831						
24	.9145	.9503	1.0059		.1029	.0914	.1029
Max	1.2452	1.1736	1.0059	.9831	1.1469	1.0669	1.2308
Min	.0914	.0972	.1006	.1029	.0914	.0914	.1029
Avg	.5554	.3941	.2987	.1841	.4114	.2624	.7733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.4024		.3086	.2743	.3353
2	.3048	.3018	.4024		.3391		.3688
3		.3121	.3688		.3429		.3688
4	.3353	.3391	.3887		.4115		.4024
5		.4409	.4534		.5365	.4268	.4858
6	.4877	.503	.583		.6554		.5506
7		.6706	.583		.6706	.6097	.6154
8	.6097	.583	.6706		.5765	.5487	.6036
9		.583			.5967		.4858
10	.5087	.4858			.4115	.3963	
11	.4748	.421			.3658	.4024	
12		.4534		.503	.3658	.4024	
13		.4534		.407	.3772	.3932	
14		.421		.3772	.3353	.4024	
15		.421		.3429	.3048	.421	
16	.6104	.3887		.373	.3048	.4024	
17	.6104	.4534		.3429		.3887	
18	.7042	.5365		.6104		.5487	
19	.663	.6036		.6706		.6516	
20	.6036	.6036		.5967	.5487	.583	
21	.5426	.4801		.4801		.4801	
22	.4359	.4115		.4024	.3658	.4458	
23	.407						
24	.3963	.3391	.4458		.3391	.2743	.3429
Max	.7042	.6706	.6706	.6706	.6706	.6516	.6154
Min	.3048	.3018	.3688	.3429	.3048	.2743	.3353
Avg	.5130	.4586	.4776	.4642	.4293	.4473	.4559

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 206 / 11KV Atola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2374	.3429		2.6246	2.6406	.8718
2	.0914	.2347	.3353		.3086		.1715
3		.2743	.3353		.3086		.1715
4	.0914	.3052	.3688		.2743		.1341
5		.3429	.503		.3429		.2012
6	.3086	.4748	.7042		.4748		.2347
7		.6036	.8097		.6036	.4572	.2683
8	.5487	.4801	.57		.503	.3963	.2347
9		.4458		.4748	.4115		.2012
10	2.6246	2.6558		.3429	.3048	.2743	
11	2.4966			.2743	.2743	.0671	
12	2.6871	2.8826		.2743	.2134	.0686	
13	2.5301			.2374	.1219	.0686	
14	2.6558	2.915		.2374	.1219	.0671	
15	2.6246	2.8826		.2058	.1219		
16	2.7183			.2401	.1219	.2058	
17	2.4966	2.9172		.2743		.2058	
18	.3052	.4115					
19	.407	.4801					
20	.5144	.5144		2.6246	2.4996	.9389	
21	.4801	.4801		2.7808		.9945	
22	.3429	.4115		2.7206	2.652	1.0288	
23	.3086						
24	.0914	.2401	.3086		2.6246		.9054
Max	2.7183	2.9172	.8097	2.7808	2.652	2.6406	.9054
Min	.0914	.2347	.3086	.2058	.1219	.0671	.1341
Avg	1.2802	1.0095	.4753	.8906	.7846	.5703	.3394

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343		.0343	.0305	.0343
2	.0343	.0343	.0343		.0343		.0343
3			.0343		.0343		.0343
4	.0343	.0343	.0343		.0343		.0343
5		.0343	.0335		.0343	.0305	.0343
6	.0343	.0343	.0343		.0343		.0335
7		.0343	.0324			.0305	.0335
8	.0343	.0343	.0343		.0343	.0305	.0335
9		.0343		.0343			.0335
10	.0343	.0343		.0343		.0305	
11	.0343	.0343		.1029		.0343	
12	.0343	.0335		.0343		.0343	
13		.0324		.0343			
14	.0343	.0324		.0343			
15		.0343		.0343			
16	.0343	.0335		.0343		.0343	
17	.0343	.0335		.0343		.0343	
18	.0343	.0343		.0343		.0343	
19	.0343	.0343		.0343		.0343	
20	.0343	.0343		.0343		.0343	
21	.0343	.0343		.0343		.0343	
22	.0343	.0343		.0343		.0343	
23	.0343					.0343	
24	.0343	.0343	.0343			.0305	.0343
Max	.0343	.0343	.0343	.1029	.0343	.0343	.0343
Min	.0343	.0324	.0324	.0343	.0343	.0305	.0335
Avg	.0343	.0340	.034	.0392	.0343	.0329	.0340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7							1.8861
8	.7621	.9907		1.7528	1.448		
15							.381
16	1.6766			.3048		.6001	
19			1.286				
20						.6859	
23						1.0288	
24		.6859		.9145	.7716		
Max	1.6766	.9907	1.286	1.7528	1.448	1.0288	1.8861
Min	.7621	.6859	1.286	.3048	.7716	.6001	.381
Avg	1.2194	.8383	1.286	.9907	1.1098	.7716	1.1336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							1.0288
8	2.21	2.4387	1.286	1.3717	1.6004		1.5432
15							1.5242
16	1.2193			1.6766		1.7147	
24		.6859		.9145	.7716		
Max	2.21	2.4387	1.286	1.6766	1.6004	1.7147	1.5432
Min	1.2193	.6859	1.286	.9145	.7716	1.7147	1.0288
Avg	1.7147	1.5623	1.286	1.3209	1.186	1.7147	1.3654

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 203 / 11 KV MAHALANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.7716
8		1.6766	1.8861	2.21	2.1338		2.572
15							2.2862
16	2.5911			2.0576		1.8004	
24		.7716		.6097	.7716		
Max	2.5911	1.6766	1.8861	2.21	2.1338	1.8004	2.572
Min	2.5911	.7716	1.8861	.6097	.7716	1.8004	.7716
Avg	2.5911	1.2241	1.8861	1.6258	1.4527	1.8004	1.8766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 201 / 11KV Chakur

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.7621	
8		1.9052			1.7147	
9			1.9014		1.5242	1.9014
12				1.3336		
16	1.3336			1.3336		
17	1.3336					1.5242
24		.7621			.7621	
Max	1.3336	1.9052	1.9014	1.3336	1.7147	1.9014
Min	1.3336	.7621	1.9014	1.3336	.7621	1.5242
Avg	1.3336	1.3337	1.9014	1.3336	1.1908	1.7128

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 202 / 11KV Gharni SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3788			.7575	
9			.1901		.3788	.571
16	3.7875			.1894		
17	.1894					3.5056
24		.1894			2.6513	
Max	3.7875	.3788	.1901	.1894	2.6513	3.5056
Min	.1894	.1894	.1901	.1894	.3788	.571
Avg	1.9885	.2841	.1901	.1894	1.2625	2.0383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 204 / 11KV Tivghal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					2.6513	
8		3.5982			3.3141	
9			4.1831		3.7875	3.9929
12				.2841		
16				3.3141		
17	3.5982					.362
24		3.1247			.5681	
Max	3.5982	3.5982	4.1831	3.3141	3.7875	3.9929
Min	3.5982	3.1247	4.1831	.2841	.5681	.362
Avg	3.5982	3.3615	4.1831	1.7991	2.5803	2.1775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154019 / 33/11 KV CHAKUR S/S

Feeder No / Name : 205 / 11KV Bothi Express NON SHEDDABLE WATER SUPPLY AND
 Feeder KV- 11 / OUTGOING UTILITY

DATE	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0947	
8		.0947			.0947	
9			.0951		.0947	.0951
16	.0947			.0947		
17	.0947					.081
24		.0947			.0947	
Max	.0947	.0947	.0951	.0947	.0947	.0951
Min	.0947	.0947	.0951	.0947	.0947	.081
Avg	.0947	.0947	.0951	.0947	.0947	.0881

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 202 / 11KV Janwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.8445			
7		.9195	.8445			
8		.8445	.9383	.9571		
9			.8069			.8944
16			2.2707		.2609	
17				.3003		
18				.563		
21	2.0268					
22	1.9892					
23	1.8766			.9008		
24				1.7077		
Max	2.0268	.9195	2.2707	1.7077	.2609	.8944
Min	1.8766	.8445	.8069	.3003	.2609	.8944
Avg	1.9642	.882	1.1410	.8858	.2609	.8944

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.3239			
7		.3239	.3048			
8		1.829	1.848	.4001		
9			2.8578			.2286
16			.0762		2.572	
17				3.0674		
18				2.7625		
21	.1524					
22	.1143					
23	.0953					
24				.0953		
Max	.1524	1.829	2.8578	3.0674	2.572	.2286
Min	.0953	.3239	.0762	.0953	2.572	.2286
Avg	.1207	1.0765	1.0821	1.5813	2.572	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9536	1.1603	1.4327	.7888	.8764	.8288	.6135
16	.4382		.1658	1.326	1.4022	1.2269	1.4022
24	.3506	.4144	.5144	.5258	.4382	.4144	.5258
Max	.9536	1.1603	1.4327	1.326	1.4022	1.2269	1.4022
Min	.3506	.4144	.1658	.5258	.4382	.4144	.5258
Avg	.5808	.7874	.7043	.8802	.9056	.8234	.8472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 202 / 11KV Ajansonda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.1795	2.0576	1.8004				.6783
16				1.8861	1.4251	1.6766	1.5432
24	1.1517	1.0288	1.0059	.8478	.8478	.7716	.6706
Max	2.1795	2.0576	1.8004	1.8861	1.4251	1.6766	1.5432
Min	1.1517	1.0288	1.0059	.8478	.8478	.7716	.6706
Avg	1.6656	1.5432	1.4032	1.3670	1.1365	1.2241	.9640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 203 / 11KV Naigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.503		
8				1.7804	1.7204	1.7604
16		1.989	1.8442			
24	.503	.503	.4915		.4973	.503
Max	.503	1.989	1.8442	1.7804	1.7204	1.7604
Min	.503	.503	.4915	.503	.4973	.503
Avg	.503	1.246	1.1679	1.1417	1.1089	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 204 / 11KV BSF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.0362			
8	.04	.04	.0381	.0362	.0343	.0838	.0362
16	.0362	.0372	.04	.04	.0305	.0333	.0381
24	.0314	.04	.0381	.0362	.0343	.04	.0305
Max	.04	.04	.04	.04	.0343	.0838	.0381
Min	.0314	.0372	.0381	.0362	.0305	.0333	.0305
Avg	.0359	.0391	.0387	.0372	.0330	.0524	.0349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 201 / 11KV Ganjur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1886	.181	.1715	.1886	.1715
2	.181	.1715	.1886	1.1145	1.0288	1.1317	1.0288
3	.181	.1715	.1886	1.1145	1.0288	1.1317	1.1145
4	.181	.1715	.1886	1.2003	1.2003	1.1317	1.3717
5	.181	.2572	.2829	1.286	1.3717	1.3203	1.5432
6	.2715	.3429	.3772	1.286	1.5432	1.3575	1.7147
7	.2715	.4287	.3772	1.2955	1.5432	1.5384	1.8004
8	.362	.5144	.2829	1.3765	1.5432	1.7194	1.7147
9	.181	.3429	.2829	1.2955	1.5432	1.6289	1.5432
10	1.1765	1.1145	1.086	.181	.2572	.1886	.2572
11	1.2003	1.4146	1.2146	.1715	.1886	.1715	.1886
12	1.4575	1.448	1.2955	.1715	.1886	.1715	.1886
13	1.286	1.448	1.2955	.1715	.1886	.1715	.0943
14	1.3717	1.448		.1715	.1886	.1715	.0943
15	1.3717	1.448	1.3765	.1715	.1886	.1715	.0943
16	1.4575	1.448	1.3765	.0857	.1886	.1715	.0943
17	1.3717	1.3575	1.2955	.0857	.1886	.1715	.2829
18	.2572	.1886	.181	.1715	.1886	.2572	.2829
19	.3429	.3772	.2715	.2572	.1886	.3429	.2829
20	.2572	.3772	.2715	.2572	.2829	.2572	.2829
21	.2572	.3772	.181	.2801	.2829	.2572	.2829
22	.2572	.2829	.181	.1715	.2829	.2572	.1886
23	.1715	.2829	.181	.1715	.2829	.1715	.1886
24	.181	.1715	.2829	.181	.1715	.2829	.1715
Max	1.4575	1.448	1.3765	1.3765	1.5432	1.7194	1.8004
Min	.1715	.1715	.181	.0857	.1715	.1715	.0943
Avg	.6003	.6565	.5586	.5354	.5930	.5985	.6241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 202 / 11KV Shivankhed SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2572	.2829	1.2717	.2572	.3772	.2572
2	.2715	.2572	.2829	1.5384	1.286	1.448	1.2003
3	.2715	.2572	.2829	1.5384	1.5432	1.6289	1.3717
4	.362	.3429	.2829	1.6194	1.7147	1.8099	1.5432
5	.4525	.4287	.4715	1.7814	1.8861	1.9909	1.7147
6	.6335	.5144	.6602	1.7814	2.0576	2.1719	1.8861
7	.905	.6001	.7545	1.8623	2.1434	2.1719	2.0576
8	.905	.7716	.5658	1.8623	2.0576	2.2624	2.0576
9		.6859	.4715	1.7004	1.8861	1.9909	1.8861
10		1.2003	1.267	.4525	.4287	.2829	.3429
11	1.1145	1.8099	1.3765	.2572	.2829	.3429	.2829
12	1.6289	1.9004	1.5384	.2572	.2829	.2572	.2829
13	1.8004	1.8099	1.6194	.2572		.2572	.1886
14	1.8004	1.8099	1.7814	.1715		.1715	.1886
15	1.7147		1.7814	.1715		.1715	.1886
16	1.5432	2.0814	1.7004	.1715		.1715	.1886
17	1.7147	1.9909	1.8004	.1715	.2829	.2572	.2829
18		1.6975	.4525	.3429	.2829	.3429	.3772
19	.6001	.5658	.543	.5144	.4715	.6001	.5658
20	.5144	.5658	.6335	.4287	.5658	.4287	.5658
21	.4287	.5658	.543	.4287	.5658	.3429	.3772
22	.3429	.4715	.4525	.3429	.4715	.3429	.2829
23	.3429	.3772	.362	.2572	.4715	.2572	.2829
24	.4525	.2572	.2829		.2572	.3772	.2572
Max	1.8004	2.0814	1.8004	1.8623	2.1434	2.2624	2.0576
Min	.2715	.2572	.2829	.1715	.2572	.1715	.1886
Avg	.8605	.9226	.8412	.8339	.9598	.8523	.7762

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 203 / 11KV Dhaveli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1886	.181	.1715	.1886	.1715
2	2.572	1.8861	1.8861	.181	.1715	.1886	.1715
3	2.4291	2.0576	2.1719	.181	.1715	.1886	.1715
4	2.5101	2.4006	2.3529	.181	.1715	.1886	.1715
5	2.5101	2.572	2.452	.181	.1715	.1886	.1715
6	2.5911	2.7435	2.4434	.181	.2572	.2829	.2572
7	2.753	2.915	2.5339	.1715	.3429	.3772	.3429
8	2.753	2.8292	2.6244	.2715	.3429	.3772	.3429
9	2.672	2.7435	2.7149	.2715	.2572	.2829	.2572
10	.181	.1715	.1886	1.8623	2.0576	2.0748	2.0576
11	.1715	.1886		2.3148	2.7149	2.3148	2.1434
12	.1715	.1886		2.572	2.7149	2.3148	2.4863
13	.1715	.1886	.0905	2.572	2.7149	2.3148	2.4863
14		.1886	.0905	2.1434	2.7149	2.4006	2.572
15		.1886	.0905	2.572	2.8054	2.4006	2.572
16		.1886	.0905	2.6578	2.8054	2.572	2.6578
17	.0857	.1886	.0905	2.6578	2.5339	2.6578	2.572
18	.1715	.1886	.0905	.1715	.1886	.1715	.1886
19	.2572	.1886	.181	.1715	.1886	.2572	.1886
20	.2572	.1886	.181	.1715	.1886	.1715	.1886
21	.2572	.1886	.181	.1715	.1886	.1715	.1886
22	.1715	.1886	.181	.1715	.1886	.1715	.1886
23	.1715	.1886	.181	.1715	.1886	.1715	.1886
24	.181	.1715	.1886	.181	.1715	.1886	.1715
Max	2.753	2.915	2.7149	2.6578	2.8054	2.6578	2.6578
Min	.0857	.1715	.0905	.1715	.1715	.1715	.1715
Avg	1.1057	.9631	.9633	.9318	1.0176	.9424	.9545

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	.3795	.3795		.3841	.3841	
2	1.1385	1.0753	1.1385		.3521	.3841	
3	1.5181	1.3599	1.3283	.3163	.3521	.4801	.3795
4	1.7078	1.4548	1.4083		.4161	.4801	
5	1.8976	1.9608	1.8976		.5121	.5761	.506
6	1.8976	2.0241		.5693	.6081	.7042	
7	1.9608	2.13	1.9608		.6722	.7682	.759
8	1.8976	2.0873	1.8484	.6958	.6722	.7682	.6958
9	1.866	1.9071		.5693	.6325		
10	.3163	.4401	.4428	1.7078	1.5813	1.5813	
11		.4401		1.8343	1.467		1.6129
12		.4108		1.8027		1.8976	1.7078
13		.2934	.2214	1.7711	1.7078	1.7711	
14		.2054		1.7924	1.8976		
15	.253	.2214		1.7604	1.7604	1.1385	
16	.2214	.2214	.253	1.8884	1.9204	1.7078	1.7711
17		.2934			1.7924		1.8027
18		.4428				.506	.4428
19		.506			.4694		.5693
20		.5693			.5761	.6325	.506
21		.4744	.3795		.5281		.506
22		.3795			.5121		.4428
23		.3795			.5121	.506	
24	.3163	.3795	.3521	.3163	.4161	.3841	.506
Max	1.9608	2.13	1.9608	1.8884	1.9204	1.8976	1.8027
Min	.2214	.2054	.2214	.3163	.3521	.3841	.3795
Avg	1.1775	.8348	.9675	1.2520	.8974	.8629	.8720

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0158	.0158		.016	.016	
2	.0158	.0158	.0147	.1265	.144	.064	.0949
3	.0158	.0158	.0158		.144	.088	
4	.0158	.0158	.0147		.16	.128	
5	.0147	.0158	.0158	.1898	.192	.128	.1581
6	.0158	.0158			.192	.1467	
7	.0158	.0158	.0158		.2721	.2241	.1265
8	.0158	.0158	.0158	.2214	.2241	.2241	.2214
9	.0158	.0147		.2214	.2214		
10	.1898	.2054	.1581	.0158	.0158	.0158	
11		.2054		.0158	.0158		.0158
12	.2214	.2347		.0158	.0158	.0158	.0158
13	.253	.2347	.2372	.0158	.0147	.0158	
14	.2846	.253		.016	.0158		
15	.253	.253		.016	.0147	.0158	
16	.2214	.253	.2214	.016	.016	.0158	.0158
17		.253			.016		.0158
18		.0158				.0158	.0158
19		.0158			.0147		.0158
20		.0158			.016	.0158	.0158
21		.0158			.0147		.0158
22		.0158			.016		.0158
23		.0158			.016	.0158	
24	.0158	.0158	.0158	.0158	.016	.016	.0158
Max	.2846	.253	.2372	.2214	.2721	.2241	.2214
Min	.0147	.0147	.0147	.0158	.0147	.0158	.0158
Avg	.0988	.0893	.0674	.0738	.0775	.0683	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0158			.016	
2			.0158		.4161	.3841	.3795
3			.0158	.5693	.4481	.4801	
4			.0158		.5121	.5121	
5			.0158		.5761	.5761	.6325
6				.6958	.6401	.7042	
7			.0158		.2561	.7042	.759
8			.0158	.6958	.6722	.7362	.6958
9		.0147		.6325	.6161		
10		.5868	.5693		.0147		
11	.5693	.5868			.0158		
12	.6958	.6455			.0158		
13	.6958	.6748	.759		.0158		
14	.7274	.7274			.0158		
15	.6958	.8215			.0147		
16	.6642	.8215	.8223		.0147		
17		.8855			.016		
18		.0158					
19		.0158			.016		
20		.0158			.016		
21		.0147			.016		
22		.0158			.016		
23		.0158			.016		
24			.0158			.016	
Max	.7274	.8855	.8223	.6958	.6722	.7362	.759
Min	.5693	.0147	.0158	.5693	.0147	.016	.3795
Avg	.6747	.3905	.207	.6484	.2067	.4588	.6167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 201 / 11KV Mahalangra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1524	.1905	.1524	.1905	.1524	.1905
2	.1524	.1524	.724		.724	.8002	.9526
3	.1524	.1524	.2286	.9145	1.0669	1.105	1.1431
4	.2286	.2286	.2667	1.1431	1.1431	1.2193	1.448
5	.3048	.3239	.3048	1.4861	1.4861	1.7147	1.6004
6	.362	.381	.362	1.5623	1.7528	1.7909	1.8671
7	.4572	.4191	.381	1.829	1.9052	1.3908	2.0386
8	.4191	.381	.4001	1.8861	2.0195	1.6956	2.0005
9	.3429	.2858	.3429	1.8099	1.7337	1.829	1.4632
10	1.3908	1.5623	1.1241	.2477	.2477	.1905	.1829
11	1.9243	2.1529		.1905	.1524	.1334	.1219
12	1.848	2.0767		.1143		.1334	
13	1.8099	1.9433		.0953		.1334	
14	1.8861	1.9433	2.0386	.0953		.1334	.1067
15	1.9243	1.9624	1.8671	.0953		.1334	
16	2.0386	1.8861	2.0386	.0953	.1524	.1334	.1067
17	.6478	1.7909			.1905	.1334	.1715
18	.2286	.2286		.2477	.2286	.2667	.2858
19	.3239	.4191		.3048	.3429	.3048	.3239
20	.3048	.3239		.3239	.3429	.3429	.381
21	.2667	.3048		.2858	.3239	.3048	.3048
22	.2096	.2858	.2286	.2096	.2858	.2667	.2667
23	.1905	.2286	.1905	.1905	.2477	.2286	.2286
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	2.0386	2.1529	2.0386	1.8861	2.0195	1.829	2.0386
Min	.1524	.1524	.1905	.0953	.1524	.1334	.1067
Avg	.7414	.8240	.6799	.6123	.7364	.6136	.7321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 202 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1524	.1143	.1143	.1143
2	.1143	.1143	.1143	.4191	.6097	.724	.8764
3	.1524	.1524	.1524	.9907	.8383	.8764	1.0669
4	.1905	.2286	.1524	1.2955	1.1812	1.1241	1.3717
5	.1905	.2858	.1905	1.4098	1.4861	1.6385	1.5242
6	.2286	.3048	.2286	1.6766	1.7147	1.7337	1.8099
7	.2667	.3429	.3048	1.7718	1.9052	1.2384	2.0576
8	.2286	.3048	.2286	1.5623	1.8671	1.4861	1.8671
9	.1524	.2286		1.6004	1.6385	1.8671	1.4632
10	1.4861	1.3527	1.3527	.1905	.1905	.1524	.1524
11	1.6766	1.6956	1.6004	.1524	.1143	.1143	.1219
12	1.7528	1.9052	1.6956	.0762	.0762	.1143	
13	1.829	1.9433	1.6766	.0762	.0762	.1143	
14	1.7718	1.7147	1.6194	.0762	.0762	.1143	.0914
15	1.829	1.7337	1.6004	.0762	.1143	.1143	
16	1.829	1.7909	1.7909	.0762		.1143	.0914
17	1.6575				.1905	.0762	.0762
18	.1905	.2286		.2667	.2286	.1524	.1905
19	.2286	.2667		.2667	.2667	.2286	.2286
20	.2286	.2286		.2286	.2286	.2286	.2667
21	.1905	.1905		.1905	.2286	.2286	.1905
22	.1524	.1905	.1524	.1524	.1905	.1905	.1524
23	.1524	.1524	.1524	.1524	.1905	.1524	.1143
24	.1143	.1143	.1143	.1524	.1524	.1524	.1524
Max	1.829	1.9433	1.7909	1.7718	1.9052	1.8671	2.0576
Min	.1143	.1143	.1143	.0762	.0762	.0762	.0762
Avg	.6970	.6776	.7356	.5657	.5947	.5438	.6657

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 203 / 11KV Ashta

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1905	.2286	.2286	.2667	.2286	.2667
2	.6668	.724	.724	.2286	.2286	.1905	.2286
3	1.0669	1.0288	.9907	.3429	.2286	.2477	.2286
4	1.3717	1.4861	1.2193	.4191	.3048	.4191	.3048
5	1.6385	1.6575	1.5242	.5144	.4191	.5335	.381
6	1.7528	1.829	1.7528	.6097	.5335	.6478	.4572
7	2.0957	2.0767	1.9052	.6478	.6478	.6859	.5716
8	2.2862	2.1148	2.0195	.6287	.6097	.6478	.5716
9	1.9433	1.9433	1.3717		.5144	.4572	
10	.4572	.4191	.4191		1.5623	1.3336	1.0974
11	.3429	.3048	.3048		.8764	1.1431	1.3108
12	.2858	.2286	.2477			1.9052	
13	.2477	.1905	.2096			2.0957	1.3717
14	.2096	.1905	.1715		.8573	2.0957	1.3717
15	.2286	.1905			2.1719	1.9052	1.4937
16	.2286	.2477	.2286		2.0195	1.9052	1.6766
17	.2096				2.0957	1.9433	1.9624
18	.3239	.4191		.3429	.362	.3048	
19	.4572	.5335		.4954	.4572	.381	.4191
20	.4954	.4191		.4572	.4382	.4954	.4954
21	.4191	.381		.4191	.381	.381	.4191
22	.362	.3429	.362	.381	.3429	.3429	.3429
23	.2667	.2667	.3048	.3429	.3429	.3048	.3429
24	.2286	.2286	.2286	.2858	.2858	.3048	.2667
Max	2.2862	2.1148	2.0195	.6478	2.1719	2.0957	1.9624
Min	.2096	.1905	.1715	.2286	.2286	.1905	.2286
Avg	.7422	.7571	.7896	.4229	.7248	.8708	.7419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 201 / 11 KV LIMBALWADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.132	.132		.1132	.1133
4					.9054	
5					.9431	
6			.1886			
7			.1886		1.1694	
8			.1886			
9						1.2136
10						.0934
12				.0377		
17	1.1317					
18				.0754		
20				.1132		
24		.132				.1121
Max	1.1317	.132	.1886	.1132	1.1694	1.2136
Min	1.1317	.132	.132	.0377	.1132	.0934
Avg	1.1317	.132	.1745	.0754	.7828	.3831

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 202 / 11 KV DEVANGARA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1867		.2054	.1869
4					1.1016	
5					1.1389	
6			.4108			
7			.4668		1.6244	
8			.4481			
9						1.531
10						.2801
12				.1307		
17	1.4377					
18				.2054		
20				.3174		
24		.2241				.2056
Max	1.4377	.2241	.4668	.3174	1.6244	1.531
Min	1.4377	.1867	.1867	.1307	.2054	.1869
Avg	1.4377	.2054	.3781	.2178	1.0176	.5509

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 203 / 11 KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0925	.0914		.128	.1296
4					.1646	
5					.2012	
6			1.3717			
7			1.5912		.3475	
8			1.701			
9						.2427
10						1.4563
12				1.8656		
17	.0926					
18				.1463		
20				.2743		
24		.1109				.1296
Max	.0926	.1109	1.701	1.8656	.3475	1.4563
Min	.0926	.0925	.0914	.1463	.128	.1296
Avg	.0926	.1017	1.1888	.7621	.2103	.4896

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 201 / 11KV TOGARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.5144	.3258	.4287	.3772	.5144	.3391
2	.439	.5144	.3429	.5144	.3772	.5144	.407
3	.5121	.5144	.3429	.6001	.4115	.5144	.5426
4	.5487	.5144	.3772	.6859	.4801	.5144	.5765
5	.5853	.6001	.4287	.6001	.6173	.5487	.6443
6	.6219	.6001		.6001	.6859	.5487	.7122
7		.6859		.5144	.823	.5144	.7969
8				.5144	.8573	.5144	.7291
9	.8048				.823	.4458	.763
10	.6274	.4458				.4801	.4917
11	.5144	.7202	.6859		.5487	.4409	.4458
12	.5144	.7202	.6859			.39	.4287
13	.5487	.7545	.7202		.4801	.407	.4287
14	.5144	.7888	.6859			.4409	.4287
15	.4801	.823	.6173		.4801	.3391	.4287
16	.4458	.823	.6001	.4115	.5144	.3561	.4458
17	.4458	.7373	.5144	.3772	.5144	.4239	.4973
18	.5144	.5487	.4458	.5487	.5144	.6443	.6687
19	.5144	.583	.5144	.6516	.6001	.7122	.6859
20	.6001	.583	.6001	.6001	.6001	.7461	.6516
21	.6859	.5487	.6001	.5316	.6001	.5087	.6001
22	.6859	.4287	.5144	.3944	.5144	.4409	.5487
23	.6859	.3772	.5144	.3772	.5144	.407	.5144
24	.4024	.5144	.3772	.4287	.3429	.5144	.373
Max	.8048	.823	.7202	.6859	.8573	.7461	.7969
Min	.3658	.3772	.3258	.3772	.3429	.3391	.3391
Avg	.5481	.6064	.5207	.5164	.5560	.4951	.5479

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 202 / 11KV LASONA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5144	.0857	.0857	.0686	.0514	.0848
2	1.3565	1.0288	.9431	.0857	.0686	.0514	.0848
3	2.0348	1.286	.9431	.0857	.0857	.0514	.0848
4	2.2382	1.6289	1.0631	.0857	.1029	.0514	.0848
5	2.4417	1.8004	1.1145	.0857	.1372	.0514	.0848
6	2.5774	1.8519	1.3717				.0848
7	2.713	1.8861	1.406				.0848
8	2.8487		1.406				.0848
9	2.6452		1.3717				.0848
10	.8779	.1715	.1372		.823	.823	.5596
11	.8916	.1715	.1715			.5765	.6344
12	.8573	.1372	.1372		1.0288	.3391	.7373
13		.1372	.1372		.8916	1.0174	.7373
14		.0857	.1543			.6783	.7716
15		.0857	.1372		.9602	.6783	.7888
16		.0857	.1372	1.2003	.9431	.6783	.6687
17		.0857	.1372	1.0631	.9945	.5426	.6516
18		.1715	.0857	.1029	.0857	.1017	.1372
19		.1715	.0857	.1029	.0857	.1017	.1372
20	.6859	.1715	.0857	.1029	.0857	.1017	.12
21	.6001	.1372	.0857	.0857	.0857	.0848	.1029
22	.6001	.1029		.0686		.0848	.1029
23	.5144	.0857	.0857	.0686	.0857	.0848	.0857
24	.5121	.5144	.0857	.0857	.0686	.0514	.0848
Max	2.8487	1.8861	1.406	1.2003	1.0288	1.0174	.7888
Min	.4755	.0857	.0857	.0686	.0686	.0514	.0848
Avg	1.4630	.5596	.4943	.2364	.3883	.3101	.2951

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 203 / 11KV WALANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5144	.4801	.5144	.4115	.5144	.407
2	.5487	.5144	.4801	.6001	.6859	.6859	.7122
3	.6584	.6001	.5144	.6001	.9602	.7716	.78
4	.8048	.6001	.6859	.6859	1.0288	.8573	.8817
5	.8779	.6516	.8916	.6859	1.0974	.9431	1.0174
6	1.0242	.6859		.9945	1.2346	1.0288	1.1191
7		.8573		.9945	1.4403	1.0288	1.5261
8					1.4746	1.0288	1.56
9	1.0242				1.4746	1.1145	1.4243
10	.9835	.6516	1.0288		.583	.583	.1357
11	.8573	1.3032	.9945			.5765	.0857
12	.823	1.286	.9945		.5144	.5426	.2743
13	.823	1.2517	1.0288			.2035	.3086
14	.6859	1.286	.9945		.5144	.5087	.3429
15	.6859	1.286	.9945		.3772	.407	.3429
16	.6516	1.286	.9945	.1715	.4115	.2713	.3772
17	.6516	1.3032	.8573	.3086	.3772	.407	.3772
18	.4801	.6859	.4801	.6173	.5144	.5426	.6859
19	.5144	.7716	.5144	.7545	.6001	.78	.6859
20	.6001	.823	.6001	.703	.6859	.8817	.6001
21	.6001	.7202	.6001	.6173	.6859	.8478	.5487
22	.5144	.5487	.5144	.4801	.6001	.5087	.5144
23	.5144	.4801	.5144	.4115	.6001	.4748	.4801
24	.5121	.5144	.4801	.5144	.3772	.5144	.4409
Max	1.0242	1.3032	1.0288	.9945	1.4746	1.1145	1.56
Min	.4801	.4801	.4801	.1715	.3772	.2035	.0857
Avg	.6976	.8464	.7322	.6034	.7568	.6676	.6512

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 205 / 11KV BORUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17
HR	Load (MW)
24	.3052
Max	.3052
Min	.3052
Avg	.3052

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 206 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.5144	.2743	.4287	.2743	.5144	.3052
2	.3658	.5144	.2743	.5144	1.0288	.6859	.763
3	.439	.6001	.2743	1.0288	1.5089	.8573	.8478
4	.5121	.6001	.3429	1.6289	2.0576	1.1145	.9326
5	.6584	.6516	.5487	1.6804	2.1948	1.2346	1.0174
6	.7499	.6859		1.8861	2.2634	1.4403	1.1361
7		.6859		2.1434	2.4691	1.5432	1.3904
8		.6859		2.3148	2.572	1.6289	1.3904
9	.8413				1.9719	1.5089	1.2717
10	1.6956	.6859	1.7661			.3429	.4578
11	2.2291	2.0576	1.9204		.4801	.2713	.2915
12	2.3148	2.1434	1.8861		.5144	.2035	.1886
13	2.4006	2.1434	2.0576			.2035	.2401
14	2.4006	2.1605	2.0576				.2572
15	2.3148	2.1948	2.452		.3086		.2743
16	2.4006	2.1948	2.4863	.2401	.3429	.2374	.2743
17	2.3148	2.2291		.2401	.3429	.2713	.2743
18	.5144	.4801	.4458	.4287	.3429	.4917	.5144
19	.5144	.5316	.5144		.4287	.6104	.5144
20	.6001	.5316	.6001	.6173	.5144	.6443	.4801
21	.6001	.4287	.6001	.6173	.5144	.5087	.4115
22	.5144	.3429	.5144	.4801	.5144	.4239	.3944
23	.5144	.2915	.5144	.3772	.4287	.373	.3772
24	.3658	.5144	.2915	.4287	.6859	.4287	.3391
Max	2.4006	2.2291	2.4863	2.3148	2.572	1.6289	1.3904
Min	.2926	.2915	.2743	.2401	.2743	.2035	.1886
Avg	1.1615	1.0378	1.0432	.9409	1.0361	.7063	.5977

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154098 / 33 KV SUB STATION TOGRI

Feeder No / Name : 203 / 11 KV WAGDRI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.6979					
2		1.4901		.6413	.5601		.4904
3		1.7541					
4		1.8298		.6979			.5093
5		2.0936					
6		2.3577		1.0185			
7	2.0119	2.3525				.9145	
8	2.0119	2.1285		1.1694	1.1273	.9145	
9		2.3712		.9431		.9145	
10	.6036	.5601	.5281	1.8107			.9335
11		.4854			1.7772	2.0936	2.0538
12		.4108	.3018	2.0936			2.2405
13		.2987		2.1502		2.3765	2.2779
14		.2987	.3018		2.0317		2.3152
15		.3361					2.3899
16	.3921	.3361	.3206			2.2822	2.4272
17	.5228	.2987					2.3011
18	.5415	.8589	.6413				.6413
19	.7207	.7922			.7537	.6413	.8962
20	.9425	.7167	.7167		1.9662		.7468
21	.8962	.679	.6413			.6036	.6413
22	.8029	.6413				.4904	.5658
23	.7545	.6036	.415	.6722		.4527	.5281
24	.4024	.679		.4527		.4024	.415
Max	2.0119	2.3712	.7167	2.1502	2.0317	2.3765	2.4272
Min	.3921	.2987	.3018	.4527	.5601	.4024	.415
Avg	.8466	1.0446	.4833	1.1650	1.3694	1.0987	1.3161

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 201 / JAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4954	.5144	.5335	.4954	.4954	.4954
2	.7011	1.2003	.6783	.5716	.5716	.5716	.5525
3	.9282	1.2071	.7545	.6097	.6478	.6668	.5716
4	1.073	1.3077	.8817	.6478	.7621	.7621	.7621
5	1.2346	1.3927	1.0174	.9526	.8573	.9526	.8002
6	1.4022	1.4899	1.1145	.7621	.9907	.8764	
7	1.7718	1.5623	1.6356	.8764	.8764	.8573	
8	1.97	1.6461	1.9559	.8002	.9907	.9526	
9	1.8427	1.8299	1.8652	.7621	.7049	.6859	
10	.8192	.8383	.8383	1.166	1.3056	1.3413	1.4413
11	.4954	.5716	.4954	1.4784	1.7295	1.56	1.5242
12	.4763	.381	.381	1.5242		1.7337	1.6766
13	.362	.2667	.2667	1.6309		1.7718	1.6004
14	.3048	.3048	.2667	1.4784	1.5091	1.9982	1.6613
15	.2858	.2667	.1905	1.5901	2.0178	1.9342	1.7223
16	.2858	.2286	.1905	1.6766	1.813	1.9136	1.6309
17		.3048	.3048	1.5061	1.9669	1.7177	.9878
18		.5144	.5716	.5906	.5716	.4763	.6097
19	.9907	.8764	.9145	.9907	.9526	.9907	.8954
20	.8573	.8573	.8383	.7811	.8573	.8383	.8573
21	.6097	.7621	.6478	.6097	.6668	.6478	.724
22	.5716	.6668	.6097	.5335	.5716	.6097	.6478
23	.5335	.5716	.5716	.4954	.5144	.5716	.5716
24	.5335	.4954	.5144	.5335	.4572	.5144	.4954
Max	1.97	1.8299	1.9559	1.6766	2.0178	1.9982	1.7223
Min	.2858	.2286	.1905	.4954	.4572	.4763	.4954
Avg	.8412	.8349	.7508	.9626	.9923	1.06	1.0114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 202 / 11 KV KAUTHALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076	.0057	.0038	.0057	.0057	.0057	.0057
2	.0076	.0076	.0038	.0061	.0181	.0102	.0074
3	.0076	.0114	.0057	.008	.021	.0119	.0091
4	.0076	.0133	.0057	.0098	.0223	.0134	.0117
5	.0133	.0152	.0095	.0117	.024	.0168	.0137
6	.0152	.0171	.0171	.0137	.0257	.0201	
7	.021	.021	.021	.0228	.0268	.0288	
8	.0191	.0171	.0191	.0248	.0302	.0302	
9	.0152	.0152	.0152	.0245	.0285	.0302	
10	.0158	.0114	.0137	.0114	.0114	.0114	.0133
11	.0224	.0169	.018	.0076	.0076	.0076	.0095
12	.0246	.0136	.024	.0057	.0038	.0057	.0057
13	.0235	.0254	.0266	.0057	.0038	.0038	.0057
14	.0232	.0259	.0266	.0057	.0038	.0038	.0038
15	.0251	.0271	.0228	.0038	.0038	.0038	.0038
16	.0232	.022	.0195	.0057	.0038	.0038	.0038
17		.022	.0195	.0057	.0038	.0057	.0057
18		.0095	.0076	.0076	.0076	.0057	.0095
19	.0133	.0133	.0152	.0152	.0133	.0133	.0152
20	.0114	.0152	.0114	.0133	.0114	.0114	.0133
21	.0076	.0133	.0076	.0095	.0095	.0095	.0095
22	.0076	.0095	.0076	.0057	.0095	.0076	.0076
23	.0076	.0076	.0076	.0057	.0076	.0076	.0057
24	.0076	.0057	.0057	.0057	.0057	.0057	.0057
Max	.0251	.0271	.0266	.0248	.0302	.0302	.0152
Min	.0076	.0057	.0038	.0038	.0038	.0038	.0038
Avg	.0149	.0151	.0139	.0100	.0129	.0114	.0083

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 203 / 11 KV MATEGADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0019	.0019	.0038	.0019	.0019	.0038
2	.0038	.0038	.0038	.0058	.0117	.0084	.0058
3	.0038	.0057	.0038	.0074	.0117	.0101	.0074
4	.0038	.0076	.0038	.0091	.0134	.0117	.0101
5	.0057	.0076	.0057	.0107	.0146	.0151	.0122
6	.0076	.0095	.0095	.0125	.0178	.017	
7	.0095	.0095	.0095	.0136	.019	.0201	
8	.0076	.0076	.0076	.016	.0208	.0203	
9	.0057		.0057	.0187	.0197	.0218	
10	.0125	.0155	.0116	.0038	.0038	.0038	.0038
11	.0198	.0171	.0152	.0019	.0019	.0038	.0038
12	.0211	.0136	.018	.0019	.0019	.0038	.0019
13	.0227	.0218	.0203	.0019	.0038	.0019	.0019
14	.0232	.0227	.0206	.0019	.0019	.0019	.0019
15	.0235	.0218	.0189	.0019	.0019	.0019	.0019
16		.022	.0189	.0019	.0019	.0019	.0019
17		.0227	.0189	.0019	.0019	.0019	.0171
18		.0038	.0038	.0019	.0076	.0038	.0038
19	.0057	.0038	.0057	.0057	.0057	.0057	
20	.0038	.0038	.0038	.0038	.0038	.0057	.0038
21	.0038	.0038	.0038	.0038	.0038	.0038	.0038
22	.0038	.0038	.0038	.0019	.0038	.0038	.0019
23	.0019	.0038	.0038	.0019	.0038	.0038	.0019
24	.0038	.0019	.0038	.0038	.0019	.0019	.0038
Max	.0235	.0227	.0206	.0187	.0208	.0218	.0171
Min	.0019	.0019	.0019	.0019	.0019	.0019	.0019
Avg	.0094	.0102	.0093	.0057	.0075	.0073	.0049

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 204 / Morge Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0464						
9	.0556			.0651			
10	.0091	.0186	.0742	.0549			.0747
11	.0457	.0372	.0556	.0549	.0465		.0653
12	.0457	.0186	.0464	.0549	.0186	.0557	.056
13	.0457	.0186	.0558	.0457	.0745	.037	.0467
14	.0549	.0186	.0466				.056
15	.0549	.0373	.0371	.064	.0559	.0557	.0747
16		.0373	.0371	.0549	.0559	.0464	.0653
17			.0371	.0457			.056
18		.0465		.0457			
19	.0091			.0091			
20	.0091			.0091			.0093
21	.0091			.0091			.0093
22	.0091			.0091			.0093
23	.0091			.0091			
Max	.0556	.0465	.0742	.0651	.0745	.0557	.0747
Min	.0091	.0186	.0371	.0091	.0186	.037	.0093
Avg	.0310	.0291	.0487	.0380	.0503	.0487	.0475

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 201 / mortalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.4287			.3429	
5		.8573			.8573	.8573
9		1.0288			.8573	.8573
10		1.0288			.8573	
12	.6859		.8573	.4287	.3429	
15	.5144					
16	.4287	.8573		.2572		
24		.2572			.3429	.4287
Max	.6859	1.0288	.8573	.4287	.8573	.8573
Min	.4287	.2572	.8573	.2572	.3429	.4287
Avg	.543	.7430	.8573	.3430	.6001	.7144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 202 / khandsari

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		1.3717			.0857	
5		1.7147			.0857	.0857
7		1.5432				
8		1.5432				
9					1.7147	1.8004
10					1.7147	
12	.0857		.0762	1.8861	1.9719	
15	.0857					
16	.0857	.0762		1.7147		
24		.0857			.0857	.0857
Max	.0857	1.7147	.0762	1.8861	1.9719	1.8004
Min	.0857	.0762	.0762	1.7147	.0857	.0857
Avg	.0857	1.0558	.0762	1.8004	.9431	.6573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 203 / wadhona SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429			.3429	
5		.8573			.8573	.8573
9		1.5432			.8573	.8573
10		1.3717			.4287	
12	1.2003		1.0669	.2572	.1715	
15	1.3717					
16	1.3717	1.0669		.1715		
24		.1715			1.0288	1.0288
Max	1.3717	1.5432	1.0669	.2572	1.0288	1.0288
Min	1.2003	.1715	1.0669	.1715	.1715	.8573
Avg	1.3146	.8923	1.0669	.2144	.6144	.9145

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 204 / shelgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		2.4006			.1715	
5		2.4006			.1715	.1715
7		2.4006				
8		2.4006				
9					2.4006	2.7435
10					2.572	
11	.3429					
12			.1715	2.572	2.8292	
15	.1715					
16	.1715	.1715		2.572		
24		.1715			.1715	.1715
Max	.3429	2.4006	.1715	2.572	2.8292	2.7435
Min	.1715	.1715	.1715	2.572	.1715	.1715
Avg	.2286	1.6576	.1715	2.572	1.3861	1.0288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 205 / mortalwadi-ww

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-DEC-17	02-DEC-17	03-DEC-17	06-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9		.2058		
10		.2058		
12			.2229	
15	.2401			
16		.2229		
24				.2058
Max	.2401	.2229	.2229	.2058
Min	.2401	.2058	.2229	.2058
Avg	.2401	.2115	.2229	.2058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 201 / telgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0123	.0142	.012	.0142	.0154	.0159	.0154
2	.0123	.0159	.0137	.0159	.0154	.0159	.0171
3	.0158	.0195	.0189	.0159	.0189	.0213	.0206
4	.0225	.023	.0223	.0248	.0257	.023	
5	.0277	.0319	.0274	.0301	.0309	.0301	
6	.0351	.0319	.036	.0478	.0372	.0425	.0429
7	.0444	.0408	.048	.0585		.0567	.0429
8	.0499	.0478	.0446	.0585	.0496	.0585	.0549
9	.0446	.048	.0463	.0638	.0532	.0589	.0585
10	.0429	.0412	.0399	.0372	.0377	.0463	.0532
11	.0394	.0412	.0451	.0408	.0446	.0463	.0532
12	.0394	.0377	.0309	.0532	.0429	.0686	
13	.0532		.0446	.039		.0421	.039
14	.0532	.0583	.0463	.0266		.0452	
15	.0566	.06	.0514	.039		.0402	.039
16	.0585	.0583	.0394	.0408		.0421	.0337
17	.0549	.072	.0446	.0434	.0425	.0343	.0407
18		.0446	.0463	.0412	.0425	.036	.0326
19	.0443	.0446	.0446	.0394	.039	.0394	.0343
20	.0283	.0274	.0257	.0257	.0248	.0257	.0274
21	.0213	.0206	.0189	.0206	.0213	.0206	.0206
22	.0159	.0154	.0159	.0154	.0177	.0171	.0171
23	.0159	.0137	.0124	.0137	.0159	.0137	.0137
24	.0139	.0142	.012	.0124	.0137	.0159	.0154
Max	.0585	.072	.0514	.0638	.0532	.0686	.0585
Min	.0123	.0137	.012	.0124	.0137	.0137	.0137
Avg	.0349	.0357	.0328	.0341	.0310	.0357	.0336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 202 / shirur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.014	.0159	.0137	.0124	.0137	.0159	.0154
2	.014	.0159	.0137	.0195	.0223	.0159	.0189
3	.014	.0159	.0137	.0195	.0223	.023	.0206
4	.0156	.0159	.0154	.0213	.024	.023	
5	.0173	.0213	.0171	.0248	.0274	.0248	.0223
6	.0259	.0283	.024	.0283	.0301	.0301	.0274
7	.0333	.0337	.0309	.0372		.0372	.0377
8	.0333	.0354	.0343	.039	.0425	.0408	.0377
9		.0291	.0291	.0408	.0377	.0381	.0408
10	.0309	.0274	.0277	.023	.0223	.024	.023
11	.0343	.0326	.0381		.0206	.0206	.0195
12	.0326	.0171	.0326		.0189	.0223	.0195
13			.0343			.0201	.0195
14	.036	.0326	.0309			.0199	
15	.0326	.0326	.0309			.0165	.0177
16	.0337	.0326	.0103	.023		.0183	.0195
17	.0319	.0274	.0309	.0253	.0319	.0171	.0203
18	.0266	.024	.024	.0257	.0354	.0274	.024
19	.0301	.0274	.0257	.0274	.0354	.0291	.0274
20	.0248	.024	.0223	.024	.0319	.0257	.0274
21	.0213	.0171	.0206	.0137	.0248	.0206	.0223
22	.0195	.0171	.0177	.0171	.0213	.0206	.0206
23	.0177	.0154	.0142	.0154	.0177	.0171	.0171
24	.0139	.0159	.0137	.0142	.0137	.0159	.0171
Max	.036	.0354	.0381	.0408	.0425	.0408	.0408
Min	.0139	.0154	.0103	.0124	.0137	.0159	.0154
Avg	.0252	.0241	.0236	.0238	.0260	.0235	.0234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 203 / belur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0386	.0372	.0377	.0053	.0069	.0053	
2	.0403	.039	.0394		.0069	.0053	.0069
3	.0421	.0443	.0412		.0069	.0053	.0069
4	.0433	.0461	.0394		.0086	.0071	
5	.0468	.0496	.0446		.012	.0106	.0103
6	.0554	.0567	.0514		.0177	.0159	.0103
7	.061	.0585	.0171		.0199	.0177	.0154
8	.0554	.0567	.0463	.0142	.0159	.0142	.0154
9	.0154	.0137	.0154	.0142	.0137	.0121	.0142
10	.012	.0112	.0121	.0106	.0086	.0103	.0089
11	.0086	.0051	.0087	.0071	.0051		.0053
12		.0034	.0051	.0053	.0051	.0069	.0053
13	.0051		.0051	.0585		.0622	.0532
14	.0034	.0051	.0051	.0461		.0633	
15	.0177	.0051	.0034	.0567		.0622	.0549
16	.0053	.0051	.0051	.0567		.0622	.0478
17	.0053	.0069	.0051	.0579	.0585	.0566	.0536
18		.012	.012	.0532	.0567	.0532	.048
19	.0142	.0103	.0137	.0497	.0567	.0549	.0463
20	.0124	.0103	.0103	.048	.0549	.0514	.0429
21	.0089	.0069	.0086	.0103	.0106	.0086	.0103
22	.0071	.0069	.0023	.0069	.0089	.0069	.0086
23	.0053	.0051	.0053	.0069	.0089	.0069	.0069
24	.0052	.0053	.0051	.0053	.0069	.0053	.0069
Max	.061	.0585	.0514	.0585	.0585	.0633	.0549
Min	.0034	.0034	.0023	.0053	.0051	.0053	.0053
Avg	.0231	.0218	.0183	.0285	.0195	.0263	.0228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 204 / shirur Exp.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175	.0177	.0171	.0177	.0171	.0177	.0171
2	.0175	.0177	.0171	.0177	.0171	.0177	.0171
3	.0175	.0177	.0171	.0177	.0171	.0177	.0171
4	.0173	.0177	.0171	.0177	.0171	.0177	
5	.0173	.0177	.0171	.0177	.0171	.0177	.0171
6	.0185	.0177	.0171	.0177	.0177	.0177	.0171
7	.0185	.0177	.0171	.0177	.0181	.0177	.0171
8	.0185	.0177	.0171	.0177	.0177	.0177	.0171
9	.0171	.0171	.0171	.0177	.0171	.0173	.0177
10	.0171	.0171	.0173	.0177	.0171	.0171	.0177
11	.0171	.0171	.0173	.0177	.0171	.0171	.0177
12	.0171	.0171	.0171	.0177	.0171	.0171	.0177
13	.0187		.0171	.0177		.0183	.0177
14	.0171	.0171	.0171	.0177		.0181	
15	.0171	.0171	.0171	.0177			.0177
16	.0177	.0171	.0171	.0177		.0183	.0177
17	.0177	.0171	.0171	.0181	.0177	.0171	.0185
18		.0171	.0171	.0171	.0177	.0171	.0171
19	.0177	.0171	.0171	.0171	.0177	.0171	.0171
20	.0177	.0171	.0171	.0171	.0177	.0171	.0171
21	.0177	.0171	.0171	.0171	.0177	.0171	.0171
22	.0177	.0187	.0177	.0171	.0177	.0171	.0171
23	.0177	.0171	.0177	.0171	.0177	.0171	.0171
24	.0173	.0177	.0171	.0177	.0171	.0177	.0171
Max	.0187	.0187	.0177	.0181	.0181	.0183	.0185
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0176	.0174	.0172	.0176	.0174	.0175	.0174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 201 / kolnoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.3429	.4287
2	.5144	.5144	1.0288	.6859
3	.5144	.5144	1.286	.7716
4	.5144	.6001	1.286	.823
5	.6173	.6859	1.286	.9088
6	.7202	.6859	1.3717	1.0631
7	.7716	.8573	1.7147	1.3375
8	.6859	.8573	1.9719	1.3717
9		.6001	1.6289	1.3717
10	1.5432	1.2003	.4287	.5144
11	1.6289		.3429	.5144
12	1.7147			.4287
13	1.5432			
14	1.5432		.3429	.3429
15	1.6289		.3429	.2572
16	1.5432		.4287	.2572
17	1.5432		.5144	.3429
18	.5144		.6859	.5144
19	.6001		.7716	.8573
20	.7716		.7716	.8573
21	.7716		.7373	.6859
22	.7202		.6859	.5144
23	.5144		.6001	.3429
24	.5487	.5144	.3429	.5144
Max	1.7147	1.2003	1.9719	1.3717
Min	.5144	.5144	.3429	.2572
Avg	.9557	.6859	.8597	.6829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 202 / sonwala SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4287	.5144	.5144
2	.6859	1.0288	.4287	.5144
3	1.0288	1.0288	.4287	.5144
4	1.2003	1.3717	.5144	.6001
5	1.5432	1.7147	.7716	.8573
6	1.8861	1.8861	1.0288	1.1145
7	2.0576	2.2291	1.2003	1.286
8	2.0576	2.4006	1.286	
9	.5144	2.0576	1.0288	1.1145
10	.8573	.8573	1.286	.9431
11	.6859		1.286	1.7147
12	.5144		1.286	1.9719
13	.4287		1.3717	1.7147
14			1.3375	1.8861
15	.3429		1.286	1.9719
16	.2572		1.2003	1.8861
17	.2572		1.1145	1.8861
18	.6001		.6001	.8573
19	.6859		.8573	1.0288
20	.6859		.8573	1.1145
21	.6001		.823	.8573
22	.4287		.7716	.6859
23	.4287		.7202	.6859
24	.5144	.4287	.5144	.6859
Max	2.0576	2.4006	1.3717	1.9719
Min	.2572	.4287	.4287	.5144
Avg	.8163	1.4029	.9381	1.1481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 203 / mali hipparga

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5144	.5144	.6001
2	.5144	.5144	1.286	.7373
3	.5144	.6001	1.3717	.9945
4	.6001	.6516	1.3717	1.2346
5	.6859	.6859	1.6289	1.3717
6	.8573	.8573	1.7147	1.6118
7	1.3032	1.0288	2.0576	1.7147
8	1.0288		2.0576	1.8004
9		1.1145	1.8861	1.7147
10	1.5432	1.7147	.7716	.7716
11	1.7147		.6859	.6001
12	1.7147		.5658	.5144
13	1.7147		.5144	.4287
14	1.8004		.5144	.3429
15	1.8004		.5144	.3429
16	1.8861		.6859	.2572
17	1.5432		.7716	.3429
18	.6859		.8573	
19	.7716		1.0288	1.0288
20	.8573		.9602	1.0288
21	.8573		.9259	.8573
22	.6859		.8573	.6859
23	.6859		.7716	.5144
24	.6859	.5144	.5144	.6859
Max	1.8861	1.7147	2.0576	1.8004
Min	.5144	.5144	.5144	.2572
Avg	1.0855	.8196	1.0345	.8775

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 201 / kumtha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0213	.0194	.0229	.0395	.034	.0265	.034
2	.0229	.0213	.0244	.047	.0391	.0311	.0393
3	.0227	.0259	.0259	.0496	.0448	.0344	.0421
4	.0259	.0275	.0256	.0502	.0522	.0381	.0442
5	.0295	.0295	.0271	.0617	.0592	.0431	.0475
6	.0311	.0311	.0282	.0544	.0624	.0492	.0502
7	.0393	.0344	.0308	.0534	.0538	.0508	.0541
8	.0372	.0356	.0323	.0496	.0551	.0442	.0524
9	.0168	.0111		.034	.0308	.0344	.0328
10	.0151	.0091		.0091	.0328	.0324	.0293
11	.0075	.0073		.0288	.0232	.0295	.0271
12	.0057	.0055		.0206	.0213	.0262	.0257
13	.0056	.0037		.0259		.0229	.0229
14	.0057	.0055		.0256		.0262	.0217
15	.0057	.0037		.0231		.0279	.0214
16	.0056	.0037		.0246		.0279	.0217
17	.0508	.04		.0093	.6722	.0057	
18	.0551	.0472		.0074	1.0269	.0112	.0111
19	.0573	.0507		.0364	1.4146	.0093	.0129
20	.0508	.0484		.0453	1.0642	.0057	.0093
21	.0453	.0425		.0437	.7842	.0075	.0075
22	.0437	.0411		.0359	.5847	.0057	.0057
23	.0442	.0391		.0372	.4668	.0038	.0057
24	.0389	.0426	.0361	.0368	.0056	.4481	.0038
Max	.0573	.0507	.0361	.0617	1.4146	.4481	.0541
Min	.0056	.0037	.0229	.0074	.0056	.0038	.0038
Avg	.0285	.0261	.0281	.0354	.3264	.0434	.0271

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 202 / chimachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0075	.0075	.0075	.0112	.0131	.7095	.0075
2	.0093	.0093	.0094		.0091	.7468	.0093
3	.0113	.0094	.0113	.0073	.0094	.8676	.0094
4	.0151	.0113	.0132	.0127	.0075	.9431	.0113
5	.017	.0151	.0168	.0129	.0055	1.7177	.0149
6	.0187	.0205	.0185	.0245	.017	.0207	.0168
7	.0205	.0205	.0203	.0168	.0203	.0187	.017
8	.0226	.0205	.0185	.0166	.0207	.0226	.0132
9	.0729	.0565		.0149	.0256	.0189	.0113
10	.0754	.0514		.0712	1.4377		.0092
11	.0754	.06		.0687		.0132	.0092
12	.077	.07		.0073	.6908		.0074
13	.077	.0629		.0056		.0057	.0055
14	.0754	.0629		.0057		.0057	.0037
15	.0745	.0586		.0037		.0056	.0037
16	.0737	.06		.0038		.0038	.0037
17		.0056		.0567	.0573	.0761	.0586
18	.0151	.0112		.0696	.0737	.0632	.0486
19	.0131	.0131		.0055	.0688	.0672	.0521
20	.0113	.0113		.0056	.0639	.0623	.0543
21	.0093	.0093		.0056	.059	.059	.0499
22	.0075	.0075		.0054	.0564	.0567	.0499
23	.0075	.0057		.0055	.053	.0534	.0476
24	.0057	.0057	.0057	.0056		.0508	.0502
Max	.077	.07	.0203	.0712	1.4377	1.7177	.0586
Min	.0057	.0056	.0057	.0037	.0055	.0038	.0037
Avg	.0345	.0277	.0135	.0192	.1494	.2540	.0235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 201 / hadoliti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.5087	.5373	.4382	.5373	.4287	.5258
2	.8573	.8669	.7087	.4382	.5316	.4287	.5258
3	.8573	.9536	.7973	.5144	.5316	.4287	.5258
4	.9431	1.0402	.964	.5144	.5258	.4287	.6135
5	1.0288	1.2136	1.2269	.6001	.7011	.7716	.6001
6	1.2003	1.5604	1.4737	.6859	.8669	.9431	.7716
7	1.8861	1.7337	1.7147	.6783	1.1145	1.0288	.7716
8	1.8861	1.9071	1.8004	.6935	1.0288	.9431	.6859
9	1.7147	1.9071	1.5775	.6935	1.0288	.8573	.5935
10	.6859	.6783	.7802	1.1145	1.0288	1.2003	.8669
11	.4239	.5201	.7011	1.286	1.2003	1.5432	1.0402
12	.4239	.5144	.5087	1.4575	1.286	1.5261	1.387
13	.3391	.4287	.5087	1.4575		1.6956	1.387
14		.3429	.4239	1.4575		1.6956	
15	.4239	.3429		1.4575		1.5261	1.2136
16	.4239	.3429		1.3717		.8478	1.2136
17	.4239	.5144	.5144	1.3003		1.2003	1.2136
18	.5087	.7973	.6135	.443	.8573	.5258	.4239
19	.6783	.8859	.7011	.6201	.8573	.5258	.6783
20	.763	.7087	.7011	.7164	.7716	.7011	.763
21	.8478	.6268	.7011	.6268	.6001	.7011	.763
22	.763	.6268	.6135	.5373	.4287	.6135	.6783
23	.5935	.5373	.5258	.5373	.4287	.5258	.5935
24	.4287	.5087	.5373	.4382	.5373	.4287	.5258
Max	1.8861	1.9071	1.8004	1.4575	1.286	1.6956	1.387
Min	.3391	.3429	.4239	.4382	.4287	.4287	.4239
Avg	.8056	.8361	.8469	.8366	.7822	.8965	.7983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 202 / jagalpur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3391	.3582	.3506	.3582	.3429	.3506
2	.6859	.6935	.443	.3506	.3544	.3429	.3506
3	.6859	.8669	.5316		.3544	.3429	.3506
4	.7716	.8669	.6135	.3506	.3506	.3429	.3544
5	.7716	.9536	.7888	.3429	.4382	.5144	.4287
6	.8573	1.0402	.9536	.4287	.5258	.6001	.5144
7	1.286	1.2136	1.1269	.5144	.6859	.6859	.5144
8	1.286	1.387	1.1145	.5201	.6859	.6001	.5144
9	1.2003	1.387	1.0517	.5201	.6001	.5144	
10	.4287	.3391	.3391	.8573		1.0288	.6935
11	.2543	.3467	.3391	.9431	1.0288	1.2003	.8669
12	.2543	.3429	.2543	.9431	1.0288	1.1869	1.2136
13	.1696	.3429	.2543	1.0288		1.2717	1.2136
14		.3429	.2543	.8573		1.2717	
15	.2543	.3429	.2543	.8573			1.2136
16		.3429		.9431			1.2136
17	.2543	.3429	.3429	.9536	.7716	.8478	1.2136
18		.6201		.3544	.6001	.3506	.3391
19	.4239	.7087	.4382	.6201	.6859	.4382	.4239
20	.4239	.6201	.4382	.5373	.6001	.4382	.4239
21	.5087	.5373	.4382	.4477	.4287	.4382	.4239
22	.4239	.4477	.3506	.3582	.3429	.3506	.3391
23	.3391	.3582	.2629	.3582	.3429	.3506	.3391
24	.3429	.3391	.3582	.3506	.3582	.3429	.3506
Max	1.286	1.387	1.1269	1.0288	1.0288	1.2717	1.2136
Min	.1696	.3391	.2543	.3429	.3429	.3429	.3391
Avg	.5698	.6301	.5139	.5995	.5548	.6274	.6203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadoliti

Feeder No / Name : 203 / walsangi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2543	.3582	.2629	.2686	.2572	.3506
2	.2572	.2543	.3544	.4382	.7973	.6859	1.0517
3	.2572	.2543	.3544	.6859	1.1517	.8573	1.0517
4	.2572	.3391	.3544	1.2003	1.3289	.9431	1.0517
5	.2572	.4239	.4382	1.2003	1.4022	1.2003	1.286
6	.5144	.5087	.5201	1.2003	1.5604	1.4575	1.3717
7	.6859	.5087	.6859	1.6956	1.7147	1.6289	1.8861
8	.6859	.5087	.7716	1.7337	1.8861	1.7147	1.8861
9		.5087	.7011	1.7337	1.8004	1.7147	1.9071
10	1.2003	1.2136	1.2136	.5144	.4287	.3429	.4239
11	1.387	1.8204	1.6956	.3429	.3429	.2543	.2543
12	1.5604	1.8861	1.5261	.2572	.2572	.2543	.2543
13	.5201	1.9719	1.6956	.1715		.2543	.2543
14		1.9719	1.3565	.1715		.2543	
15	1.7337	1.8861	1.3565	.1715		.2543	.2543
16	1.7337	1.8861		.1715		.1696	.2543
17	1.5604	1.5432		.1715	.2572		.2543
18	.3391	.3544	.4382	.3544	.3429		.3391
19	.4239	.5316	.4382	.5316	.5144	.4382	.4239
20	.4239	.443	.4382	.4477	.4287	.4382	.4239
21	.3391	.3582	.4382	.3582	.2572	.4382	.4239
22	.3391	.3582	.3506	.3582	.2572	.3506	.3391
23	.2543	.3582	.2629	.2686	.2572	.3506	.3391
24	.2572	.2543	.3582	.2629	.2686	.2572	.3506
Max	1.7337	1.9719	1.6956	1.7337	1.8861	1.7147	1.9071
Min	.2543	.2543	.2629	.1715	.2572	.1696	.2543
Avg	.6929	.8499	.7321	.6127	.7761	.6598	.7144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 201 / jalkot

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6602	.6001	.6602		.6602	.5868	.6602
8	.8488	.6706	.7545		.7545	.7545	.6602
9		.6706					
10	.7545						
12	.6706	.6602	.8488	.7545	.6706	.6602	.6602
16	.6706	.7545		.7545		.6602	.6602
17					.6706		
18	.6706						
20	.6706	.7545		.6602	.6706	.6602	.6602
24	.5658		.7545	.6602	.6602	.6706	.6602
Max	.8488	.7545	.8488	.7545	.7545	.7545	.6602
Min	.5658	.6001	.6602	.6602	.6602	.5868	.6602
Avg	.6890	.6851	.7545	.7074	.6811	.6654	.6602

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 202 / kunki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.6706	.6706	.6706		.2801	.1753	.2801
8	1.0059	.9945	1.0059		.1867	.2801	.1867
10	.1677						
12	.2572		.1677	.8383	.503	.6706	.6706
13		.1867					
16	.2572	.1867		.6706		.7545	.6706
17					.8288		
18	.1753						
20	.1753	.2801		.2801	.9945	.2801	.1677
24	.1677	.1753	.2801	.1677	.2801	.1753	.2801
Max	1.0059	.9945	1.0059	.8383	.9945	.7545	.6706
Min	.1677	.1753	.1677	.1677	.1867	.1753	.1677
Avg	.3596	.4157	.5311	.4892	.5122	.3893	.3760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 203 / ravankola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3696	.1753	.3734		2.3472	1.989	2.1795
8	.2772	.2572	.3734		2.5149	2.5149	2.3472
12	2.4863	2.5149	2.7721	.1867	.2572	.2801	.2772
15				.1867			
16	1.989	2.1795				.1867	.2772
17					.1715		
18	.2572						
20	.2572	.3734		.3734	.1715	.3734	.2772
24	.2772	.2572	.3734	.2772	.3734	.1753	.3734
Max	2.4863	2.5149	2.7721	.3734	2.5149	2.5149	2.3472
Min	.2572	.1753	.3734	.1867	.1715	.1753	.2772
Avg	.8448	.9596	.9731	.256	.9726	.9199	.9553

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 202 / sandol

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.1524	.1524	2.4387	2.5149	2.8959
16	2.8502					
23	.1524	.1524				
24	.1524		.1524	.1524	.1524	.1524
Max	2.8502	.1524	.1524	2.4387	2.5149	2.8959
Min	.1524	.1524	.1524	.1524	.1524	.1524
Avg	1.0517	.1524	.1524	1.2956	1.3337	1.5242

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 203 / jaybhachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.3429		.3429	
7		3.0693		.3429		.3429
8					.3429	
16	.3429					
23	.3429					
24	.3429	.3429	.3429	.3429	.3429	.3429
Max	.3429	3.0693	.3429	.3429	.3429	.3429
Min	.3429	.3429	.3429	.3429	.3429	.3429
Avg	.3429	1.7061	.3429	.3429	.3429	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.6443	.6783	.6443	.6154	.6783	.6783
2	.6783	.6443	.6443	.6443	.583	.6783	.6783
3	.6783	.6443	.6443	.6443	.583	.6783	.6783
4	.7461	.6783	.7122	.6443	.6154	.7291	.7122
5	.8139	.9835	.78	.7461	.7287	.7969	.9496
6	.8817	1.0513	.8648	.8817	.8907	.8987	1.153
7	1.17	1.0513	.9156	1.1191	1.0364	1.2039	1.153
8	1.3603	1.1869	1.2209	1.3226	1.2146	1.3056	1.2308
9	1.3117	1.153	1.1869	1.2887	1.153		1.2146
10	1.2146	1.0852	1.0852	1.1336	1.0174		.9717
11	1.1012	.9835	1.0174	.9717	.9496		.8907
12		.763	.9326	.8383	.9496		.8383
13	.9717	.78	.8817		.9326		.8383
14	.8421	.78	.8817		.78		.7287
15	.8478	.7291	.8139	.8097	.78		.7287
16	.7287	.6613	.7461	.7773	.7122		.7287
17	.7773	.8139	.9496	.7773	.8139		.8097
18	.8907	1.0513	1.2209	1.1012	1.1869		.9831
19	1.0202	1.2209	1.1869	1.1401	1.153		1.1633
20	1.0526	1.1191	1.0513	1.0688	1.1191		1.1012
21		.9835	1.0852	.9717	1.0343		1.0526
22		.8648	.8817	.8684	.9326		.8907
23		.7461		.7125			.7773
24	.6783	.6783	.6783	.6783	.6478	.7122	.7122
Max	1.3603	1.2209	1.2209	1.3226	1.2146	1.3056	1.2308
Min	.6783	.6443	.6443	.6443	.583	.6783	.6783
Avg	.9222	.8874	.9156	.8993	.8882	.8535	.9026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1696	.1696	.2035	.1715	.1696	.2035
2	.1696	.1696	.1696	.2035	.1715	.1696	.2035
3	.1696	.1696	.1696	.2035	.1715	.1696	.2035
4	.1696	.2035	.1696	.2374	.1715	.1696	.2035
5	.2035	.2035	.1865	.2713	.1715	.2035	.2374
6	.2374	.2374	.2204	.2713	.2058	.2204	.2374
7	.2713	.2374	.2543	.2713	.2915	.2713	.2543
8	.3601	.2883	.3052	.3052	.3258	.3052	.3086
9	.4115	.2883	.3052	.3391	.3391		.3429
10	.4287	.3052	.2713	.3258			.3429
11	.4287	.3391	.3052	.3086	.3391		.2572
12	.4287	.373	.3052	.2915	.373		.2229
13	.3772	.3391	.3052				.2058
14	.3429	.3222	.2713		.373		.2058
15	.3429	.3052	.2713	.3772	.3391		.2572
16	.2915	.3052	.2713	.3429	.3222		.3258
17	.2915	.3052	.3391	.3258	.373		.3429
18	.3429	.4239	.407	.4801	.4917		.3772
19	.3772	.4748	.407	.4801	.4578		.463
20	.3772	.407	.373	.4458	.407		.4458
21		.3052	.3391	.3429	.3391		.4115
22		.2543	.2543	.2915	.2883		.3086
23		.2204		.1943			.2105
24	.1696	.2035	.2035	.2035	.2058	.2035	.2035
Max	.4287	.4748	.407	.4801	.4917	.3052	.463
Min	.1696	.1696	.1696	.1943	.1715	.1696	.2035
Avg	.3029	.2854	.2728	.3053	.3014	.2091	.2823

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 203 / 11 KV TELEPHONE Express NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678	.0678	.0678	.0678	.0724	.0678	.0678
2	.0678	.0678	.0678	.0678	.0724	.0678	.0678
3	.0678	.0678	.0678	.0678	.0724	.0678	.0678
4	.0678	.0678	.0678	.0678	.0724	.0678	.0678
5	.0678	.0678	.0678	.0678	.0724	.0678	.0678
6	.0678	.0678	.0678	.0678	.0724	.0678	.0678
7	.0678	.0678	.0678	.0678	.0724	.0678	.0848
8	.0724	.0678	.0678	.0678	.0724	.0678	.0724
9	.0724	.0848	.0678	.0678	.0678		.0724
10	.0724	.0678	.0678	.0724	.0848		.1086
11	.1086	.1357	.0678	.1448	.0848		.1448
12	.1267	.1526	.0678	.1629	.1357		.181
13	.1448	.1526	.1526		.1696		.181
14	.1629	.1357	.1526		.1696		.181
15	.1629	.1526	.1526	.1448	.1696		.181
16	.1629	.1526	.1526	.1448	.1696		.181
17	.181	.1526	.1357	.1448	.1526		.181
18	.1086	.1526	.1357	.1448	.1526		.181
19	.0724	.0848	.1357	.0724	.0848		.1629
20	.0724	.0678	.0678	.0724	.0848		.1448
21		.0678	.0678	.0724	.0678		.1448
22		.0678	.0678	.0686	.0678		.1086
23		.0678		.0724			.0724
24	.0678	.0678	.0678	.0678	.0724	.0678	.0678
Max	.181	.1526	.1526	.1629	.1696	.0678	.181
Min	.0678	.0678	.0678	.0678	.0678	.0678	.0678
Avg	.0982	.0961	.0914	.0907	.1006	.0678	.1191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4748	.5087	.5087	.5087	.4534	.5087	.5087
2	.4748	.5087	.5087	.5087	.421	.5087	.5087
3	.4748	.5087	.5087	.5087	.421	.5087	.5426
4	.6443	.7122	.5765	.6104	.4372	.5765	.6443
5	.8139	.8478	.6443	.7122	.5182	.6443	.8139
6	.8817	.9835		.8139	.7287	.763	.8139
7	.9835	.8817	.9156	.9835	1.004	1.0004	.9496
8	1.0174	1.0513	1.0513	1.0174	1.1336	1.0852	.9393
9	1.153	1.0174	.9835	.9156	1.1191		.9717
10	1.1869	.9835	.9496	.8421	1.0174		.9717
11	1.1869	.9496	.9496	.8097	.9665		.9717
12	1.1022	.9156	.9496	.8097			.9717
13	1.0174		.8817		.9665		.9717
14	.8478		.8478		.8478		.8097
15	.5087	.78	.8478	.8097	.8139		.8097
16	.5087	.78	.8309	.7287	.78		
17	.763	.8478	.8817	.7449	.8139		.8097
18	.8478	1.1022	1.153	.7773	1.2548		.9717
19	1.0174	1.0682	1.1022	.9069	1.153		.9717
20	1.0174	.9496	.9835	.8097	1.0852		1.1012
21		.8139	.8139	.6478	.8309		.8421
22		.6443	.6783	.5668	.6443		.6478
23		.5426		.4858			.5668
24	.5087	.5087	.5087	.5087	.4858	.5426	.5426
Max	1.1869	1.1022	1.153	1.0174	1.2548	1.0852	1.1012
Min	.4748	.5087	.5087	.4858	.421	.5087	.5087
Avg	.8301	.8139	.8216	.7285	.8135	.6820	.8110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115			.5144		.543	
2	.4287			.4801		.5175	
3	.4115			.4287		.6401	
4	.6001			.5144		.4572	
5	.5487			.6859		.5487	
6	.6001			.8402		.6401	
7				1.0288		.905	
8	1.1145			1.1145		1.0059	
9		.8916		1.0059		.905	.8573
10		.7716		.924		.8573	
11		.8573		.8501		.905	
12		.8573		.6878		.7545	
13		.6859				.724	
14		.6859				.6516	
15		.6859		.5792			
16		.8573		.6219		.6173	
17			.6859				.6859
18			.8573		.924		.8573
19			.8573		.905		.8916
20			.7716		.7316		.8573
21			.6859		.6584		.6859
22			.6001		.5487		.6001
23			.5144		.3982		.5144
24	.524			.4115		.4572	
Max	1.1145	.8916	.8573	1.1145	.924	1.0059	.8916
Min	.4115	.6859	.5144	.4115	.3982	.4572	.5144
Avg	.5799	.7866	.7104	.7125	.6943	.6956	.7437

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792			.6335		.6036	
2	.6335			.7095		.6602	
3	.7468			.5792		.7167	
4	.6878			.7468		.9808	
5	.9955			.8145		.9431	
6	1.1403			1.0136		.9997	
7				1.267		1.4335	
8	1.307			1.4003		1.4146	
9		1.086		1.1883		1.2851	
10		1.3213		1.3957		1.3394	
11		1.448		1.3957		1.3756	
12		1.267		1.2826		1.267	
13		1.086				1.1584	
14		1.1403				1.267	
15		1.1765		1.1317		1.1584	
16		1.1145		1.2071		1.1222	
17			1.3756				1.1946
18			1.4661		1.1317		1.3213
19			1.267		1.094		1.1765
20			1.2308		.8299		.9955
21			1.086		.7545		.703
22			.905		.6036		.724
23			.8145		.6036		.6535
24	.6697			.6516		.6348	
Max	1.307	1.448	1.4661	1.4003	1.1317	1.4335	1.3213
Min	.5792	1.086	.8145	.5792	.6036	.6036	.6535
Avg	.8450	1.2050	1.1636	1.0278	.8362	1.0800	.9669

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 208 / VAISHALI AGRO EXPRESS

SHEDDABLE RURAL

FEEDER Feeder KV- 11 /
OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534			.3258		.2172	
2	.2715			.3258		.1829	
3	.2896			.181		.2715	
4	.3258			.2172		.2195	
5	.3258			.3258			
6	.3258			.3734		.2715	
7				.362			
8	.2534			.3361		.3142	
9		.3258		.3258			
10		.362		.3658			
11		.3258		.3361			
12		.3258		.3326			
13		.3258					
14		.3258					
15		.3258		.2587			
16		.3258		.2926			
17			.3258		.3292		.3801
18			.3439		.3326		.362
19			.362		.3292		.362
20			.3258		.2926		.3429
21			.3258		.2926		.3174
22			.3258		.2378		.3258
23			.3258		.2587		.3258
24	.3258			.3258		.2743	
Max	.3258	.362	.362	.3734	.3326	.3142	.3801
Min	.2534	.3258	.3258	.181	.2378	.1829	.3174
Avg	.2964	.3303	.3336	.3123	.2961	.2502	.3451

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 201 / 11KV BODHAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2103	.1753	.2103	.2103	.2103	.2279	.2279
2	.2103	.1753	.2103	.2103	.2103	.2279	.2279
3	.2103	.1753	.2103	.2103	.2454	.2279	.2279
4	.2103	.1753	.2103	.2629	.2804	.2804	.2629
5	.2454	.2454	.2103	.298	.3155	.3155	.298
6	.2804	.3155	.2804	.3681	.3506	.3856	.3506
7	.3856	.4557	.4207	.4733	.4207	.4908	.4557
8	.4557	.4557	.4557	.5609	.4557	.4733	.4908
9	.4359	.3353	.4557	.4207	.3856	.3601	.3856
10	.3944	.3353	.4207	.3856	.3506	.3772	.3856
11	.3944	.3258	.3681	.3506	.3155	.3086	.3856
12	.3944	.3018	.3856	.2804	.3155	.3086	.3856
13	.3772	.3018	.333	.2804	.3155	.3086	.3155
14	.3601	.3018	.3155	.2804	.2804	.3086	.3155
15	.3601	.285	.298	.2804	.2454	.3258	.3155
16	.3772	.3185	.3155	.2804	.2804	.3018	.3155
17	.3856	.3601	.3601	.2743	.3086	.3353	.3429
18	.4557	.3944	.3772	.3944	.3429	.3353	.4115
19	.4207	.3772	.4115	.3601	.3772	.3688	.3944
20	.4031	.3429	.3429	.3429	.3429	.3429	.3772
21	.3856	.3155	.2915	.3086	.3086	.3601	.3429
22		.3155	.2804	.298	.298	.298	.298
23	.2103	.2454	.2454	.2454	.2629	.2629	.2629
24	.2103	.2103	.2103	.2103	.2279	.2279	.2454
Max	.4557	.4557	.4557	.5609	.4557	.4908	.4908
Min	.2103	.1753	.2103	.2103	.2103	.2279	.2279
Avg	.3380	.3017	.3175	.3161	.3103	.3233	.3342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.0168	.0335	.0503	.0335	.0503
2	.0335	.0335	.0168	.0335	.0503	.0335	.0503
3	.0335	1.3748	.0168	.0335	.0503	.0335	.0503
4	.0335	.0335	.0168	.0335	.0503	.0335	.0503
5	.0503	.0335	.0168	.0335	.0671	.0335	.0503
6	.0671	.0503	.0168	.0503	.0671	.0335	.0671
7	.0335	.0335	.0168	.0838	.0838	.0838	.1006
8	.0503	.0671	.0671	.0838	.1006	.0838	.0838
9	.0655	.0819	.0671	.0671	.0838	.0671	.1006
10	.0655	.0655		.0838	.0503	.1006	.0671
11	.0983	.0492	.0671	.0671	.0671	.1006	.0838
12	.1147	.0671	.0671	.0671	.0503	.0838	.0838
13	.1147	.0655	.0503	.0671	.0671	.1006	.0335
14	.1006	.0655	.0838	.0671	.0671	.1006	.0503
15	.0983	.0819		.0503	.0503	.0838	.0671
16	.0983	.0983		.0924	.0671	.0819	.0838
17	.0838	.0838	.0838	.1006	.0335	.0983	.1006
18	.0671	.1006	.0671	.1006	.0335	.0983	.0671
19	.0671	.0838	.0671	.0838	.0503	.0819	.0671
20	.0503	.0335	.0335	.0671	.0503	.0655	.0335
21	.0503	.0335	.0335	.0671	.0503	.0655	.0335
22	.0335	.0335	.0335	.0671	.0503	.0671	.0335
23	.0335	.0335	.0335	.0671	.0503	.0503	.0335
24	.0503	.0335	.0335	.0335	.0671	.0503	.0503
Max	.1147	1.3748	.0838	.1006	.1006	.1006	.1006
Min	.0335	.0335	.0168	.0335	.0335	.0335	.0335
Avg	.0636	.1113	.0431	.0639	.0587	.0694	.0622

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2402	.2402	.2218	.2402	.2402	.2587
2	.2587	.2402	.2402	.2218	.2218	.2218	.2587
3	.2402	.2587	.2587	.2218	.2218	.2218	.2587
4	.2218	.2402	.2218	.2402	.2957	.2957	.2772
5	.2587	.2957	.2587	.2772	.2957	.3142	.3142
6	.2957	.3696	.2957	.3142	.3142	.3511	.3696
7	.3881	.5359	.3881	.4805	.4435	.4805	.4435
8	.5175	.6283	.5359	.5359	.5729	.5729	.5544
9	.5365	.57	.6468	.5175	.5359	.6283	.5729
10	.5533	.503	.5914	.4805	.4251	.5175	.5544
11	.503	.4527	.5359	.499	.4435	.462	.462
12	.4527	.5197	.5175	.3696	.2772	.462	.5359
13	.4191	.4694	.4251	.2957	.3696	.4805	.4435
14	.4024	.4359	.3696	.3326	.4066	.3326	.4435
15	.4024	.4191	.4066	.3326	.3326	.4435	.462
16	.4024	.4694	.462	.3475	.3696	.4024	.462
17	.462	.5544	.4251	.3881	.3881	.3688	.4435
18	.5544	.5729	.499	.499	.462	.4024	.499
19	.5359	.5544	.499	.4805	.4854	.4694	.5359
20	.462	.462	.4435	.4066	.4435	.4359	.499
21	.4435	.3881	.3881	.3881	.4251	.4287	.462
22	.3511	.3326	.3142	.3511	.3326	.3881	.3881
23	.2957	.2772	.2587	.3142	.2957	.3326	.3326
24	.3501	.2587	.2587	.2402	.2587	.2587	.2957
Max	.5544	.6283	.6468	.5359	.5729	.6283	.5729
Min	.2218	.2402	.2218	.2218	.2218	.2218	.2587
Avg	.3978	.4187	.3950	.3648	.3690	.3963	.4220

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3109	.3109	.3109	.3109	.3109	.3109
2	.3109	.2926	.2926	.2926	.2926	.2926	.2926
3	.2926	.2926	.2926	.2926	.2926	.2926	.2926
4	.2926	.2926	.2926	.3109	.3109	.3109	.3292
5	.3292	.3475	.2926	.3475	.3658	.3475	.3658
6	.3841	.4024	.3658	.3841	.4207	.4207	.439
7	.5487	.4755	.4938	.5121	.4938	.5487	.567
8	.6036	.5304	.5487	.5487	.5304	.6036	.5853
9	.5533	.503	.5729	.5304	.5853	.567	.5304
10	.6203	.5487	.4755	.5121	.5121	.5487	.5121
11	.57	.5365	.4572	.5121	.5121	.6219	.6584
12	.503	.4694	.4755	.4938	.5853	.5853	.6036
13	.4359	.4694	.4572	.439	.5487	.5487	.6401
14	.4024	.4527	.439	.4572	.5121	.567	.567
15	.4359	.4527	.4024	.439	.5121	.567	.5304
16	.4527	.4527	.4207	.4572	.567	.5533	.5853
17	.5121	.5304	.5121	.4938	.6036	.5533	.6401
18	.7316	.7316	.6767	.695	.8048	.6706	.7682
19	.7133	.7316	.6767	.6584	.7499	.7209	.8048
20	.6584	.6767	.6401	.6036	.695	.6874	.7316
21	.6036	.567	.5487	.5487	.6401	.583	.6401
22	.4572	.4755	.439	.4755	.439	.4024	.4755
23	.3658	.3658	.3658	.3658	.3841	.3841	.4024
24	.3292	.3109	.3475	.3292	.3475	.3475	.3475
Max	.7316	.7316	.6767	.695	.8048	.7209	.8048
Min	.2926	.2926	.2926	.2926	.2926	.2926	.2926
Avg	.4757	.4675	.4499	.4588	.5007	.5015	.5258

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI
HEALTHCAR Feeder KV- 11 /
OUTGOING

SHEDDABLE RURAL

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0709	.0709	.0709	.0709	.0709	.0709
2	.0886	.0709	.0709	.0709	.0709	.0709	.0709
3	.0886	.0709	.0709	.0709	.0709	.0709	.0709
4	.0886	.0709	.0709	.0709	.0886	.0709	.0709
5	.0709	.0709	.0709	.0709	.0886	.0709	.0886
6	.0709	.0709	.0709	.0709	.0709	.0709	.0709
7	.0709	.0709	.0709	.0709	.0886	.0886	.0709
8	.0709	.0709	.0709	.0886	.0709	.0886	.0886
9	.0671	.0671	.0709	.0886	.0709	.1417	.0886
10	.0671	.0671	.0709	.0709	.0709	.1417	.0709
11	.0671	.0671	.0886	.0709	.0709	.0709	.0886
12	.0671	.0671	.0886	.0709	.0709	.0886	.0886
13	.0671	.0671	.1063	.0709	.0709	.0886	.0709
14	.0671	.0671	.1063	.0709	.0886	.1772	.0886
15	.0671	.0671	.1063	.0886	.0886	.1417	.1063
16	.1341	.0671	.1063	.0886	.0886	.1509	.1063
17	.124	.1063	.1063	.0886	.1595	.1844	.124
18	.1063	.1417	.1063	.1463	.1595	.1677	.2126
19	.1063	.1417	.1063	.1595	.1417	.0671	.1595
20	.0886	.1417	.1063	.1417	.1772	.1543	.1063
21	.0709	.0709	.0886	.0709	.1772		.1063
22	.0709	.0709	.0709	.0709	.1417	.124	.0886
23	.0709	.0709	.0709	.0709	.124	.0709	.0709
24	.0886	.0709	.0709		.0709	.0709	.0886
Max	.1341	.1417	.1063	.1595	.1772	.1844	.2126
Min	.0671	.0671	.0709	.0709	.0709	.0671	.0709
Avg	.0820	.0800	.0849	.0850	.0997	.1062	.0945

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 201 / 11 KV Bus Stand

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	07-DEC-17
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 401 / 33 KV UDGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-DEC-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4465	3.4979	3.6008	3.6008	3.0864	3.3951	3.4979
2	5.9671	6.5844	5.7613	5.6584	5.4527	5.7613	5.5556
3	6.5329	7.0473	6.5844	6.2243	5.5556	5.9671	6.07
4	7.4589	7.7675	7.0473	6.9959	5.7613	6.7387	7.4074
5	8.4362	8.1276	7.5103	7.3045	7.1502	7.0473	8.5391
6	9.2593	9.0535	9.6708	7.8189	7.7675	8.6934	9.1564
7	10.8025	10.5967	10.2881	9.5679	9.8251	11.0082	11.0082
8	10.391	8.642	10.5453	8.9506	8.2819	9.2078	10.4938
9	10.1098	9.2044	9.2593	8.7449	9.5679	5.7316	9.6194
10	8.0979	9.3553	7.9733	8.1276	7.5617	6.4678	7.9218
11	8.4499	9.7737	8.3848	9.1564	8.642	6.7833	8.2305
12	8.5505	8.9529	8.6934	8.8992	7.8704	7.2039	8.3333
13	8.5002	8.3493	6.3786	7.356	8.2819	7.1514	7.7675
14	8.3493	8.5505	8.0247	8.0761	8.0761	7.0462	6.4301
15	8.1985	8.802	6.5329	7.7675	5.9156	7.3617	8.0761
16	8.0476	7.0416	5.9671	6.4301	6.0185	6.4883	6.3272
17	9.8766	10.0435	9.5176	7.9401	5.8368	6.6392	7.8875
18	6.1214	6.3626	6.0471	4.6799	4.7851	5.1303	5.1006
19	6.3786	6.6255	6.5729	5.3635	5.679	5.3818	5.7842
20	5.9671	6.0997	5.679	4.7851	5.1006	5.1955	5.2058
21	5.2469	5.144	4.6799	4.2067	4.4696	4.5268	4.7851
22	4.6296	4.6296	4.2181	3.7037	3.9095	4.0124	4.2181
23	4.2181	4.1152	3.8066	3.5494	3.4979	3.7037	3.7037
24	2.3148	3.9095	4.0124	3.6523	3.2407	3.4979	3.4979
Max	10.8025	10.5967	10.5453	9.5679	9.8251	11.0082	11.0082
Min	2.3148	3.4979	3.6008	3.5494	3.0864	3.3951	3.4979
Avg	7.3063	7.4282	6.9482	6.6067	6.3056	6.2559	6.8591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 201 / 11 KV ATNOOR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1844	
2			.1844	
3			.1844	
4			.2683	
5			.503	
6			.7377	
7			.7712	
8			.7042	
9			1.4251	
10			1.5592	
11		.4694	1.6095	1.5257
12		.3856		1.5257
13	1.2346	.2515		1.3748
14		.1844		
15		.1677		1.643
16		.1677		1.643
17		.218		
18		.4694		.3856
19		.7042		.5365
20				.4527
21		.4191		.4024
22		.3018		.3353
23		.1844		.2683
24			.1844	
Max	1.2346	.7042	1.6095	1.643
Min	1.2346	.1677	.1844	.2683
Avg	1.2346	.3269	.6930	.9175

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 202 / 11 KV AWALKONDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.2574	
2		1.2574	
3		1.2574	
4		1.3413	
5		1.4251	
6		1.6598	
7		1.8442	
8		1.0898	
9		.9724	
11	.6203	.7209	.3856
12	.4527		.3353
13	.4024		.2347
14	.3521		.2515
15	.3353		.218
16	.3353		.2347
17	2.2634		.3521
18	2.1963		.57
19	2.1795		.7545
20			.6706
21	1.6766		.5868
22	1.4922		.4862
23	1.3748		.4191
24		1.3077	
Max	2.2634	1.8442	.7545
Min	.3353	.7209	.218
Avg	1.1401	1.2849	.4230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 203 / 11 KV Nalgir

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	03-DEC-17	04-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.1006	
2		.1006	
3		.1006	
4		.1677	
5		.2347	
6		.4359	
7		.4359	
8		.3856	
9		.3856	
11	.8048	.2683	.218
12	1.1401		.2012
13	1.0562		.1844
14	1.1568		.1509
15	1.1065		.1509
16	1.0562		.1844
17	.1677		1.0898
18	.3185		1.1736
19	.3856		1.1401
20			1.1065
21	.285		1.0898
22	.2012		1.073
23	.1341		1.0059
24		.1006	
Max	1.1568	.4359	1.1736
Min	.1341	.1006	.1509
Avg	.6511	.2469	.6745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2601	.2629	.2572	.2572	.2601	.3391
2	.2572	.2601	.2629	.5144	.5144	.5201	.5087
3	.2572	.2601	.2629	.6859	.5144	.6935	.5935
4	.2572	.3467	.3506	.6859	.6859	.7802	.6783
5	.3429	.4334	.3506	.6859	.8573	1.0402	.763
6	.4287	.5201	.5258	.9431	1.0288	1.2136	.9326
7	.5144	.5201	.5258	1.286	1.286	1.3003	1.2717
8	.5144	.4334	.5258	1.2003	1.3717		1.3565
9	.5144	.5201	.4334		1.3717	1.2136	1.2136
10	.8573	.9536	1.0288	.3429	.3429	.2601	.3429
11	.9536	1.0402	1.2003	.3429	.3467	.2572	.2572
12	1.2136	1.1269	1.2003	.2572	.3467	.2601	.1715
13	1.2136	1.0402	1.2003	.2572	.2601		.1715
14	1.3003	.3467	1.2003	.1715	.2601		.1715
15	1.3003	1.3003	1.2003	.1715	.2601		.1715
16	1.2136	1.3003	1.3717	.1715	.2601	.1734	.1715
17	1.1269	1.1869	1.2003	.1715	.2601	.2629	.1715
18	.2601	.3391	.3429	.3429	.3467	.3506	.2572
19	.3467	.4239	.4287	.4287	.4334	.5258	.4287
20	.4334	.4239	.4287	.3429	.4334	.4382	.4287
21	.4334	.3391	.3429	.3429	.3467	.3506	.3429
22	.3467	.3391	.3429	.2572	.3467	.3506	.3429
23	.2601	.3391	.3429	.2572	.3429	.3391	.2572
24	.2572	.2601	.3391	.2572	.2572	.2601	.3506
Max	1.3003	1.3003	1.3717	1.286	1.3717	1.3003	1.3565
Min	.2572	.2601	.2629	.1715	.2572	.1734	.1715
Avg	.6192	.5964	.6530	.4510	.5305	.5425	.4873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.2629	.2686	.2601	.2601	.2629	.2572
2	.2601	.2629	.2686	.3467	.4334	.4382	.4287
3	.2601	.2629	.2686	.3467	.5201	.5258	.4287
4	.2601	.3506	.3582	.4334	.5201	.5201	.5144
5	.3467	.4382	.4477	.5201	.5201	.6068	.5144
6	.4334	.4382	.5373	.6068	.6068	.7888	.6001
7	.5201	.5258	.5373	.7802	.7802	.8764	.8573
8	.4334	.5258	.6268	.9536	.9536	.8764	.9431
9	.4334	.4382	.5258		.8669	.7888	.8764
10	.6935	.7011	.7802	.5201	.3467	.2629	.3467
11	.7011	.8764	.9536	.3467	.2629	.2601	.2601
12	.8764	.964	.8669	.2601	.2629	.1753	.1734
13	.8764	.8764	.8669	.2601	.2629	.1753	.1734
14	.8764	.7888	.8669	.2601	.2629	.1753	.1734
15	.7888	.8764	.9536	.1734	.2629	.1753	.1734
16	.8764	.7888	.8669	.1734	.2629	.2629	.1734
17	.7888	.8573	.8669	.1734	.3506	.2686	.2572
18	.2629	.3429	.4334	.3467	.3506	.3582	.3467
19	.2629	.5144	.5201	.4334	.3506	.4477	.5201
20	.3506	.4287	.4334	.3467	.4382	.4477	.4334
21	.3506	.3429	.3467	.2601	.3506	.3582	.3467
22	.2629	.3429	.3467	.2601	.3506	.2686	.2601
23	.2629	.2572	.2601	.2601	.3506	.2572	.2601
24	.2601	.2629	.2572	.2601	.2601	.2629	.2686
Max	.8764	.964	.9536	.9536	.9536	.8764	.9431
Min	.2601	.2572	.2572	.1734	.2601	.1753	.1734
Avg	.4874	.5303	.5608	.3731	.4245	.4100	.3995

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 203 / 11 KV DIGRESS SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2658	.2572	.2658	.2658	.2658	.2572	.2601
2	1.4175	1.3717	1.2403	.2658	.2658	.2572	.2601
3	1.5947	1.5432	1.5061	.2658	.2658	.2601	.2601
4	1.7718	1.7337	1.5947	.3544	.2658	.3429	.3467
5	1.949	1.8861		.3544	.3544	.4334	.3467
6	2.1262	2.2539	2.1262	.7087	.5316	.5144	.5201
7	2.4806	2.5139	2.4806	.7087	.6201	.6068	.6935
8	2.5692	2.4006	2.4806	.5316	.443	.5201	.6068
9	2.3034	2.4863	2.392		.443	.4287	.443
10	.443	.443	.3544	1.7718	1.5947	1.4175	1.5061
11		.2658	.3544	2.1262	2.0805	2.3034	2.0376
12		.0886	.2658	2.1262	2.2291	2.392	2.1262
13		.1772	.1772	2.1262	2.1672	2.4806	2.1331
14		.1772	.1772	2.0376		2.392	2.1262
15	.1734	.1772	.1772	2.2148		2.5692	2.1262
16	.2601	.1772	.1772	2.0376		2.4806	2.1262
17	.2572	.1734	.1772	2.0376		2.3034	2.1262
18	.3467	.3467	.3544	.2658	.1734	.3544	.3544
19	.3429	.5201	.443	.443	.2601	.5316	.5316
20	.3429	.3467	.443	.3544	.3467	.443	.443
21	.4334	.3467	.3544	.3544	.3467	.3544	.443
22	.3467	.3467	.3544	.3544	.3467	.3544	.3544
23	.2601	.2601	.2658	.2658	.2601	.2601	.2658
24	.2658	.2572	.2601	.2658	.2658	.2572	.2658
Max	2.5692	2.5139	2.4806	2.2148	2.2291	2.5692	2.1331
Min	.1734	.0886	.1772	.2658	.1734	.2572	.2601
Avg	.9975	.8563	.8010	.9668	.6763	1.0214	.9460

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 201 / 11 KV DEVARJAN (AG)

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	02-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.6173		
8	1.1145	1.2174	
9	1.0802		
10			.1715
11			.2915
Max	1.1145	1.2174	.2915
Min	.6173	1.2174	.1715
Avg	.9373	1.2174	.2315

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 202 / 11 KV SHEKAPUR (AG)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.823
8				1.0288
9				.9088
10		.6516		
11	.9431			
13	1.3032			
15	1.4118		1.2174	
16			1.2003	
17			1.2689	
Max	1.4118	.6516	1.2689	1.0288
Min	.9431	.6516	1.2003	.823
Avg	1.2194	.6516	1.2289	.9202

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 204 / 11 KV SHEKAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12			
7				.3772
8	.3772			.3429
9				.5144
10		.3429		
11	.2058			
13	.0857			
15	.0762		.0514	
16			.0514	
17			.0857	
24	.1543	.1543		.12
Max	.3772	.3429	.0857	.5144
Min	.0762	.1543	.0514	.12
Avg	.1699	.2486	.0628	.3386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 205 / 11 KV DEVARJAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12			
7				.3506
8				.4287
9				.4287
10		.2743		
11	.1753			
13	.0914			
15	.0686		.0686	
16			.0857	
17			.1372	
24	.12	.1372		.1227
Max	.1753	.2743	.1372	.4287
Min	.0686	.1372	.0686	.1227
Avg	.1151	.2058	.0972	.3327

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 207 / 11 KV ARASNAL AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-DEC-17	03-DEC-17	04-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)
7			1.406
8			1.8404
9			1.8861
10	1.267		
11	1.6289		
13	1.7364		
15	1.6118	1.7604	
16		1.2003	
17		1.1145	
Max	1.7364	1.7604	1.8861
Min	1.267	1.1145	1.406
Avg	1.5610	1.3584	1.7108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 201 / 11 KV LOHARA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3048	.2286	.4108	.3048	.2286	.3734
2	.8775	1.5242	.7011	.4294	.3048	.2439	.3921
3	1.2883	1.5242	1.0364	.4481	.3048	.2743	.3921
4	1.5684	1.5242	1.2193	.4294	.2896	.3048	.4108
5	1.8111	1.5242	1.4632	.4108	.3353	.3658	.4294
6	2.0351	1.5242	1.6766	.4294	.3201	.3658	.4668
7	2.2032	1.829	1.7985	.4668	.3048	.3963	.5041
8	2.3339	1.9052	1.829	.4668	.3506	.4268	.4854
9	1.475	1.768	2.3339		.3201	.4854	.4668
10	.1867	.2439	.2614	1.829	1.0364	.8962	.7926
11				1.9052	1.6461	1.0642	.884
12	.2054		.2987	2.2862	1.5242	1.2883	.9145
13	.2054	.2134	.3547	1.9814	1.768	1.4563	.945
14	.2054	.2439	.4294	2.1338	1.768	1.5684	1.1431
15	.2054	.2439	.4294		1.89	1.6617	1.2193
16	.1867	.1829	.4481		1.829	1.8484	1.3717
17	.1494	.2439	.4294	1.5242	1.768	2.0165	1.6461
18	.1219	.2743	.4294	.2896	.2439	.3734	.2439
19	.1524	.3048	.4294	.2896	.3658	.4108	.3658
20	.1677	.3658	.4108	.2743	.3353	.4294	.381
21	.2591	.3353	.4481	.2896	.3048	.4481	.3353
22	.2439	.3048	.4294	.3048	.3048	.4481	.3506
23	.2743	.2743	.4108	.3048	.2743	.4294	.3201
24	.4294		.2439	.4294	.2896	.2439	.4108
Max	2.3339	1.9052	2.3339	2.2862	1.89	2.0165	1.6461
Min	.1219	.1829	.2286	.2743	.2439	.2286	.2439
Avg	.7390	.7933	.7713	.8254	.7576	.7365	.6352

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 202 / 11 KV BHAKASKHEDA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.2743	.2134	.4108	.3048	.2134	.3921
2	.4108	.2439	.2134	.5415	1.5242	.7621	.6535
3	.3921	.2439	.2439	.7282	1.6766	.9145	.7282
4	.3734	.2743	.2439	.8962	1.7071	1.0364	.8589
5	.3921	.2743	.3048	1.2323	1.5242	1.0974	1.1016
6	.4108	.2896	.3658	1.4563	1.5242	1.1584	1.251
7	.4294	.2896	.3963	1.5497	1.3717	1.2193	1.531
8	.4481	.2896	.3353	1.587	1.5242	1.3717	1.643
9	.4481	.3353	.4481		1.3717	1.7924	1.7551
10		.7926	.3547	.2896	.1829	.2241	.1829
11		1.0364	.5041	.3048	.1829	.2614	
12	.5788	1.3413	.7282	.3048	.2134	.3174	
13		1.4022		.2896	.2134	.3174	.1981
14	1.8671	1.4632	.5788	.2743	.2134	.3547	.2134
15	1.5242	1.4632	1.1576	.3048	.2439	.3547	.2591
16	1.3717	1.0974	1.2883	.3048	.2134	.4108	.2743
17	1.2193	1.3413	1.4003	.2896	.2439	.4294	.3048
18	.1677	.2286	.2801	.2743	.2439	.4481	.2439
19	1.3717	.2743	.3174	.2591	.3048	.4481	.3048
20	.2743	.3048	.3361	.2743	.3048	.4668	.3048
21	.2439	.3048	.3921	.2896	.2743	.4481	.2743
22	.2896	.2743	.4108	.2743	.2743	.4481	.2896
23	.2743	.2439	.4108	.2896	.2439	.4294	.2896
24	.4294	.2591	.2134	.4294	.3048	.2134	.4108
Max	1.8671	1.4632	1.4003	1.587	1.7071	1.7924	1.7551
Min	.1677	.2286	.2134	.2591	.1829	.2134	.1829
Avg	.6346	.5976	.4842	.5589	.6744	.6307	.6120

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 203 / 11 KV KUMTHA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.2591	.2439	.4481	.2896	.2439	.3921
2	.4108	.2286	.2439	.7095	1.5242	.9145	.7655
3	.4294	.2134	.3048	.8589	1.6461	1.0974	1.1203
4	.4294	.2134	.3048	1.1016	1.6766	1.1888	1.251
5	.4481	.2439	.3658	1.531	1.7071	1.2498	1.475
6	.4668	.2439	.4268	1.7177	1.7528	1.3108	1.7177
7	.4668	.2743	.4877	1.7551	1.7223		1.7737
8	.4854		.4268	1.7551	1.5242	1.6766	1.8484
9	.4668		.5601		1.5242	2.0538	1.4563
10		.9755		.2743	.2134	.2614	.2134
11		1.3413		.2896	.2286	.2801	.2286
12	.5228	1.4632	.8962	.2896	.2286	.2801	.2439
13	1.4937	1.5242	1.1016	.2743	.2439	.2614	.2591
14	1.8671	1.5242	1.587	.2591	.2439	.2801	.2439
15	1.6804	1.6461	1.8111	2.7435	.2439	.2987	.2591
16	1.3717	1.3413		.2743	.2439	.2614	.2591
17	1.2193	1.4632	1.8671	.2743	.2743	.3174	.2896
18	.1829	.2439	.3547	.2896	.2743	.3174	.2743
19	.1829	.3353	.4294	.2743	.4268	.3361	.4268
20	.2134	.3658	.4481	.2896	.3658	.3361	.3963
21	.2134	.3353	.4294	.3048	.3353	.3547	.3658
22	.2286	.3048	.4294	.2896	.3048	.3734	.3506
23	.2591	.3048	.4481	.3048	.3048	.3547	.3506
24	.4294	.2743	.2743	.4481	.2743	.2743	.3734
Max	1.8671	1.6461	1.8671	2.7435	1.7528	2.0538	1.8484
Min	.1829	.2134	.2439	.2591	.2134	.2439	.2134
Avg	.6309	.6873	.6400	.7286	.7322	.6227	.6806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 204 / 11 KV Express Feeder
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2439	.1524	.2801	.2134	.1524	.2427
2	.1867	.2286	.1524	.2614	.1981	.1524	.168
3	.1867	.2286	.1219	.2427	.1829	.1219	.1867
4	.1867	.1981	.1219	.2241	.2134	.1219	.1867
5	.1867	.2134	.1219	.2241	.2286	.1219	.1867
6	.1867	.2134	.1219	.2427	.2134	.1219	.1867
7	.1867	.2286	.1524	.2614	.1981	.1524	.2241
8	.1867	.2134	.1524	.2614	.2134	.1524	.2241
9	.2614	.2134	.2241		.1981	.2241	.2427
10		.2286	.2614		.2134	.2427	.2134
11		.2286	.2427		.2439		.2134
12	.2614	.2439	.2427	.2286	.2439	.2614	.1981
13		.2439	.2241	.2134	.2439	.2614	.2286
14	1.6804	.2439	.2427	.1829	.2591	.2427	.2591
15	.2614	.2286	.2614	.1981	.2439	.2614	.2591
16	.2134	.2286	.2614	.2134	.2439	.2614	.2591
17	.1829	.2134	.4294	.2134	.2439	.2241	.2743
18	.1829	.2286	.2241	.2286	.2134	.2801	.2286
19	.1829	.2134	.2241	.1981	.2134	.2801	.2134
20	.2134	.2134	.2614	.1981	.2134	.2987	.2134
21	.1981	.2134	.2241	.1829	.1829	.2614	.1981
22	.2286	.1829	.2427	.2134	.1829	.2427	.1981
23	.1981	.1829	.2614	.1981	.1829	.2614	.1829
24	.2241	.2134	.1524	.3174	.2134	.1524	.2241
Max	1.6804	.2439	.4294	.3174	.2591	.2987	.2743
Min	.1829	.1829	.1219	.1829	.1829	.1219	.168
Avg	.2763	.2204	.2116	.2278	.2166	.2110	.2172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.3018	.2987		.3018	.2987	.1867
2	.5487	2.7149	2.1262		.6413	.6859	.4668
3	.5487	2.572	2.5377		.6413	.6859	.5601
4	.8779	2.7435	2.5857		.6036	.7956	.5601
5	.8573	2.7435	2.652		.6036	.8619	1.1203
6	.9602	2.9329	2.5911		.5365	1.0608	1.1949
7	.9389		2.6871		.8718	1.1012	1.3443
8	.7956	2.9165	2.6825		1.073	1.1012	1.1203
9	.7459	2.3472		.9389	.9221	.8749	1.0059
10	.7545	.8413		2.431	2.5232	2.7633	2.431
11	.7377			2.8147	2.6825	2.9874	2.6216
12	.6036			1.9662	2.4996	3.2114	2.9165
13	.6036				2.6825	2.9874	3.0011
14	.5967				2.5606	2.6139	2.8837
15	.6036			1.6766	2.6216		2.8837
16	.4694			2.9165	2.4996	3.2114	2.9172
17	.6706			1.5424	2.4371		2.8837
18	.3772				.2103	.2987	.3658
19	.4527				.3696	.4481	.4527
20	.415				.4481	.3734	.4527
21	.3772				.3734	.3174	.415
22	.3772				.2987	.2987	.3018
23	.3018	.2987			.2987	.1867	.3018
24	.2263	.3018	.2614		.3018	.2614	.1867
Max	.9602	2.9329	2.6871	2.9165	2.6825	3.2114	3.0011
Min	.2263	.2987	.2614	.9389	.2103	.1867	.1867
Avg	.5861	1.8831	2.0469	2.0409	1.2084	1.2466	1.3573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2075	.2641	.2241		.2641	.2241	.2035
2	.2452	.2614	.2587		.5601	.6173	.5087
3	.2829	.2641	.2587		.6584	.6859	.5426
4	.3395	.3018	.2957		.6661	.823	.8139
5	.4715	.3772	.4435		.7202	.8619	1.0174
6	.5281	.5658	.5792		.8383	.9282	1.0852
7	.5175				.8718	1.166	1.1191
8	.5121				.9054	1.1012	1.0174
9	.3772			1.0395	.8916	1.1336	1.1401
10	.9012	.8002		.3395	.3018	.1696	.2452
11	.7773			.3018	.1509	.1357	.1509
12	.9488			.1132	.1086	.1187	.1132
13	.9488			.1132	.1086	.0848	.0943
14	.9282			.1132	.1086		.0943
15	.9054			.1132	.1086		.0943
16	.852			.1132	.1086	.0678	.132
17	.852				.1086	.0747	.132
18	.415				.1478	.0678	.1886
19	.3772				.2987	.373	.3772
20	.3772				.4108	.3391	.3772
21	.3772				.3734	.2713	.3395
22	.3018				.2987	.2883	.2641
23	.2641	.2241			.2614		.2641
24	.2075	.2641	.2241		.2641	.2241	.2204
Max	.9488	.8002	.5792	1.0395	.9054	1.166	1.1401
Min	.2075	.2241	.2241	.1132	.1086	.0678	.0943
Avg	.5381	.3692	.3263	.2809	.3973	.4646	.4390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 201 / 11 KV GUTTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2286	.2286	.2477	.2667	.2477	.2667
2	.6516	.5144	.5256	.2286	.2477	.2286	.2667
3	.7373	.6516	.6464	.2286	.2286	.2286	.2858
4	.8402	.8745	.8718	.2477	.2667	.2858	.2858
5	.9945	1.1317	.9995	.2667	.2858	.4001	.3429
6	1.2226	1.2517	1.1984	.3048	.5716	.5335	.4954
7	1.382	1.0974	1.1305	.7621	.8002	.8002	.7621
8	1.2934	.8859	1.2616	.8192		.8383	.743
9	1.258	1.2048	1.0814	.724	.743	.743	.6668
10	.5906	.6097	.6668	.8478	.6783	.7545	.8002
11	.4572	.5335	.6097	1.0978	.8916		.8192
12	.3429	.4001	.4191	1.1142	.823	.78	.8954
13	.2667		.2286		.8402	.763	.9526
14	.2286	.2155	.2286	.7773	.0686	.8478	.9335
15	.2286	.2096	.1715	.7537	.7545	.78	.9145
16			.1524	.7293	.7888	.7432	.9145
17	.2858		.2667	.7545	.9145	.7611	.8764
18	.5144	.5144	.4954	.4954	.5144		.5144
19	.7049	.5906	.6287	.6097	.7049	.6478	.6287
20	.5144	.5716	.5525	.4954	.6097	.5335	.6478
21	.4001	.4382	.4382	.4572	.4572	.4382	.5335
22	.3429	.362	.3429	.362	.4191	.3048	.4001
23	.2858	.3048	.3048	.3048	.4001	.2858	.2858
24	.2477	.2477	.2667	.2667	.2858	.381	.2667
Max	1.382	1.2517	1.2616	1.1142	.9145	.8478	.9526
Min	.2286	.2096	.1524	.2286	.0686	.2286	.2667
Avg	.6112	.6113	.5715	.5607	.5461	.5603	.6041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 202 / 11 kv CHINCHOLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.381	.381	.381	.381	.4191	.4191
2	.5335	.381	.381	.2126	.2229	.2401	.2865
3	.743	.4382	.4382	.2126	.2401	.2401	.3224
4	.7811	.5525	.5716	.2303	.2401	.2915	.3544
5	.8002	.6478	.6668	.3189	.3258	.3944	.3898
6	.8764	.7621	.7621	.3814	.463	.4801	.4508
7	.9145	.9526	.8954	.6001	.703	.583	.5426
8	.8764	.9145	.8573	.7973	.703	.583	.5087
9	.8002	.8383	.724	.5316	.4191	.5658	.5087
10	.5144	.6024	.4917	.6287	.6859	.5906	.381
11		.7373	.6104	.4954	.5144		.4191
12	.6516	.5898	.6783	.4763	.381	.4191	.3429
13	.583	.664	.7716	.2858	.381	.3429	.3239
14	.5487	.7537	.7202	.2667	.3429	.2858	.3239
15	.5658	.8122	.7888	.2858	.3048	.2667	.3429
16	.6173	.6882	.3155	.3429	.3048	.1905	.3048
17	.6516		.5201	.381	.3429	.8002	.3239
18	.6668	.6668	.6478	.6668	.2858		.5525
19	.8383	.6478	.7811	.7811	.8192	.724	.6668
20	.6287	.6287	.6478	.6859	.6478	.6287	.724
21	.4954	.5144	.5335	.6859	.5335	.5335	.6668
22	.4572	.4572		.4763	.4763	.4954	.5716
23	.4191	.4191	.4382	.4382	.4382	.4572	.4572
24	.4001	.381	.4191	.4191	.4191	.4001	.4382
Max	.9145	.9526	.8954	.7973	.8192	.8002	.724
Min	.4001	.381	.3155	.2126	.2229	.1905	.2865
Avg	.6435	.6274	.6105	.4576	.4407	.4514	.4426

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-DEC-17 and 07-DEC-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 203 / 11 KV SULLALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-DEC-17	02-DEC-17	03-DEC-17	04-DEC-17	05-DEC-17	06-DEC-17	07-DEC-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1524	.1524	.1715	.1524	.2096	.1905
2	.1524	.1524	.1524	.1543	.1595	.1543	.3772
3	.3048	.1715	.1715	.1543	.1595	.1543	.4161
4	.362	.2096	.2286	.1543	.1772	.2229	.4694
5	.4382	.2477	.2667	.1715	.3544	.4115	.4858
6	.4572	.3239	.3429	.3052	.443	.6173	.4915
7	.4954	.4954	.5335	.3048	.7442	.7202	.5182
8	.4382	.4001	.4572	.6024	.5847	.5487	.5571
9	.381	.3048		.3898		.463	.583
10	.8002	.6024	.5898	.1905	.2477	.2286	.1143
11	.7888	.788	.7293	.1143	.2286		.1143
12	.8573	.7611	.7377	.1143	.1524	.1334	.0953
13	.8402	.7701	.7545	.1524	.1143	.1715	.0953
14	.7888	.8097	.7042	.0953	.0953		.0762
15	.7716	.8192	.7042	.1143	.0953	.0762	.1334
16	.8059		.373	.1143	.0953	.0953	.1334
17	.6344	.6962	.5426	.2096	.1143	.0953	.1143
18	.3048	.7125	.2096	.2096	.1524		.3429
19	.3048	.3048	.3239	.3239	.2858	.4001	.362
20	.2477	.2858	.2667	.2477	.2477	.3048	.381
21	.1905	.1715	.2096	.2096	.2477	.2667	.362
22	.1715	.1715	.1905	.1715	.2286	.2286	.2286
23	.1715	.1905	.1715	.1715	.1715	.1905	.1905
24	.1524	.1715	.1524	.1715	.1715	.1524	.1905
Max	.8573	.8192	.7545	.6024	.7442	.7202	.583
Min	.1334	.1524	.1524	.0953	.0953	.0762	.0762
Avg	.4580	.4223	.3898	.2091	.2358	.2783	.2926