

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 201 / 11 KV CHAITANYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.5144		.4191	.4954	.4001
2		.4572	.4954		.381	.4572	.381
3		.4191	.4763	.1715	.381	.4572	.381
4		.4954	.4572	.1715	.4001	.4191	.4191
5		.4954	.4572	.1905	.4572	.381	.4191
6		.4191	.4382	.2667	.4954	.381	.4001
7		.4572	.4191	.6287	.7049	.4191	.6097
8		.4572	.5716	.724	.6859	.4382	.6859
9	.6287	.4954	.6097	.9145	.7811	.4191	.9907
10		.6478	.6478	.9335	.8573	.4191	
11		.7049	.724	.9526	.8383	.4382	
12		.743	.7621	.5716	.8573	.4001	
13		.743	.7621	.6287	.8192	.4191	
14		.724	.7621	.3239	.8002	.4001	
15		.7049	.8002	.4191	.8383	.381	
16		.7049	.7811	.4382	.8573	.4001	
17	.7621	.724	.7811	.4191	.8573	.381	
18	.5335	.7621	.6859	.362	.8192	.362	.4382
19	.381	.743	.5335	.4191	.8002	.4001	.4954
20	.3429	.6859	.362	.381	.7621	.4382	.4382
21	.3429	.6478	.362	.381	.6859	.4191	.4382
22	.3429	.6097	.3429	.4191	.6478	.4191	.4191
23	.381	.5716	.3048	.4191	.6097	.4191	.381
24		.381	.5335		.4001	.5335	.381
Max	.7621	.7621	.8002	.9526	.8573	.5335	.9907
Min	.3429	.381	.3048	.1715	.381	.362	.381
Avg	.4644	.5922	.5660	.4826	.6732	.4207	.4799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 202 / 11 KV N. DATTA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.4572	.4954	.3429	.2667		.3048
2	.381	.4954	.4572	.3429	.3048		.3048
3		.4954	.4572	.3429	.2667		.3048
4	.381	.4191	.4191	.3429	.3048		.3048
5	.381	.4954	.4191	.3048	.3048		.3429
6	.381	.4954	.381	.3048	.3048		.3048
7	.381	.4572	.381	.3048	.3048		.3048
8	.3429	.4572	.4572	.3429	.362	.4191	.3429
9	.4572	.4572	.5716	.4572	.4954	.4382	.4191
10		.5335	.6859	.6859	.724	.4382	
11		.6097	.7621	.6478	.724	.4001	
12		.7621	.7621	.8383	.6859	.4382	
13		.7621	.7621	.6478	.6097	.4382	
14		.7621	.8002	.6097	.5335	.4382	
15		.8383	.8383	.6097	.5335	.4191	
16		.8383	.8383	.6097	.4954	.4191	.7621
17	.8002	.8383	.8383	.6097	.4954	.381	.8002
18	.6097	.7621	.8002	.6097	.4572	.381	.8383
19	.6478	.6859	.7621	.4191	.4382	.381	.7621
20	.5716	.6859	.6097	.4191	.4191	.381	.6859
21	.5335	.6097	.5716	.4191	.4191	.381	.6859
22	.381	.5716	.5335	.4191	.381	.4001	.6097
23	.3429	.5335	.4572	.381	.381	.4191	.5335
24	.5335	.4572	.5335	.381	.3048	.3429	.3048
Max	.8002	.8383	.8383	.8383	.724	.4382	.8383
Min	.3429	.4191	.381	.3048	.2667	.3429	.3048
Avg	.4691	.6033	.6081	.4747	.4382	.4068	.4953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 203 / 11 KV OLD SHASHAKIYA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5716	.5335	.4954	.3429	.381	.381
2	.5716	.5335	.5335	.4572	.381	.3429	.381
3		.6097	.4954	.4572	.3429	.3429	.381
4	.5716	.6859	.4954	.4572	.381	.381	.381
5	.5716	.5335	.4572	.4954	.381	.381	.381
6	.5716	.5335	.4572	.5716	.381	.4191	.4191
7	.5716	.5335	.4572	.6859	.4572	.4191	.4191
8	.5335	.6097	.6859	.7621	.4572		
9	.6478	.724	.8383	.7621	.6478		
10		.8383	.9145	1.2193	.6859		.381
11		1.2193	1.0669	1.2955	.6859		.381
12		1.3717	1.1431	1.1431	.7621		
13		1.2193	1.1431	1.0669	.7621		
14		.9907	1.2193	.6478	.6859		
15		.9145	1.1431	.6859	.6859		
16		.8383	1.0288	.6859	.6097		.743
17	.724	.8383	.7621	.6859	.5716		.7621
18	.5335	.7621	.6859	.4572	.5716		.7621
19	.5716	.6859	.5716	.4191	.5335		.9145
20	.5335	.6097	.4572	.381	.4954		.6859
21	.4572	.5716	.4954	.381	.4572		.6859
22	.381	.5716	.4954	.362	.4191		.6097
23	.3429	.5716	.5335	.381	.4191		.5716
24	.5716	.5335	.5716	.5335	.3429	.381	.381
Max	.724	1.3717	1.2193	1.2955	.7621	.4191	.9145
Min	.3429	.5335	.4572	.362	.3429	.3429	.381
Avg	.5430	.7446	.7160	.6454	.5192	.381	.5345

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 204 / 11 KV NEW SHASHAKIYA
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2477	.2286	.2286	.2096	.1905	.2096
2	.1715	.2858	.2667	.1905	.1905	.2286	.0191
3		.2667	.2858	.1905	.2096	.2477	.1905
4	.1715	.2667	.3048	.1905	.2096	.2667	.1905
5	.1715	.2667	.3239	.1905	.2096	.2858	.2096
6	.2286	.3048	.3429	.2667	.2477	.3048	.2667
7	.3239	.2667	.3429	.2858	.3048	.3048	.362
8	.3048	.2667	.3048	.2858	.3239	.3239	.362
9	.3048	.2667	.2477	.2858	.3048	.3048	.3048
10	.2477	.2667	.2477	.3239	.2858	.2477	
11	.2477	.2858	.2286	.2096	.2858	.2286	
12	.3048	.2667	.2477	.2286	.3048	.2667	
13	.2286	.2667	.2477	.2096	.2667	.2286	
14	.2477	.2858	.2477	.1905	.2286	.2096	
15	.2667	.2858	.2477	.1905	.2286	.2286	
16	.2477	.2667	.2477	.2096	.2286	.2286	
17	.4954	.2858	.2477	.2477	.2477	.2286	
18	.4954	.3048	.2667	.2667	.2667	.2667	.3048
19	.6668	.2858	.2858	.3048	.2667	.3048	.381
20	.4954	.2667	.3429	.3048	.2477	.2858	.3239
21	.4954	.2667	.3429	.2667	.2286	.2667	.3048
22	.4954	.2477	.3048	.2667	.2096	.2477	.2858
23	.4954	.2286	.2667	.2096	.1905	.2286	.2667
24	.1905	.2477	.2286	.2667	.2096	.1905	.2286
Max	.6668	.3048	.3429	.3239	.3239	.3239	.381
Min	.1715	.2286	.2286	.1905	.1905	.1905	.0191
Avg	.3256	.2707	.2770	.2421	.2461	.2548	.2632

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 205 / 11 KV TEXTILE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.4954	.4191	.3048	.3429	.3048
2	.3048	.381	.4572	.4191	.3048	.3429	.3048
3		.381	.4572	.381	.3048	.3429	.3048
4	.3048	.3429	.4572	.381	.3048	.381	.3048
5	.3048	.3429	.4191	.381	.3048	.381	.3048
6	.381	.381	.4191	.4191	.3048	.381	.3048
7	.381	.381	.4191	.4572	.3048	.381	.3048
8	.381	.3429	.4572	.4572	.3048	.381	.3048
9	.4572	.4191	.4572	.4572	.381	.3429	.381
10		.5335	.5716	.6097	.6097	.381	
11		.8383	.6859	.8383	.6478	.3048	
12		.9145	.7621	.8383	.6859	.3048	
13		.9145	.9145	.6859	.6097	.3048	
14		.9907	.9526	.6859	.6097	.3048	
15		.9145	.4763	.7621	.6097	.3048	
16		.9145	.9526	.8383	.5716	.3239	.4572
17	.8002	.9145	.9526	.4572	.5716	.3429	.6859
18	.724	.8383	.8764	.6097	.5335	.3429	.7621
19	.4954	.7621	.7621	.4191	.5335	.3429	.7621
20	.5335	.6859	.6097	.3429	.4572	.3048	.6097
21	.5716	.6097	.5716	.3048	.4572	.3429	.6097
22	.5716	.5716	.5335	.3048	.4191	.3429	.5716
23		.5335	.4572	.3048	.381	.3239	.5716
24	.3048	.3429	.4954	.4572	.3048	.3429	.3048
Max	.8002	.9907	.9526	.8383	.6859	.381	.7621
Min	.3048	.3429	.4191	.3048	.3048	.3048	.3048
Avg	.4547	.6081	.6089	.5096	.4509	.3413	.4530

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154073 / 33/11 KV MIDC

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	2.1338	2.2481	2.2862	1.6004	2.2481	1.829
2	1.6385	2.2481	2.191	2.2481	2.0005	2.191	1.7909
3		2.3243	2.1338	2.21	2.0576	2.1338	1.829
4	1.5242	2.4006	2.0957	2.0767	1.9814	2.0957	1.8671
5	1.6766	2.4387	2.0957	2.0767	2.0957	2.0957	2.0957
6	1.7909	2.4768	2.1719	2.0005	2.2481	2.0576	2.1338
7	1.8861	2.5149	2.2481	2.21	2.3815	2.0576	2.3815
8	2.0386	2.5149	2.2481	2.2481	2.21		2.2672
9	2.0005	2.5911	2.2672	2.3053	2.2672		2.2862
10	2.2481	2.6673	2.2862	2.3434	2.2481		
11	2.3243	2.5149	2.4768	2.3434	2.3243		
12	2.4768	2.4196	2.4768	2.191	2.2862		
13	2.5911	2.4387	2.5149	2.3053	2.191		
14	2.4387	.0191	2.5149	2.2481	2.0195		
15	2.2862	2.4577	2.4768	2.0767	2.2481		
16	2.2291	2.4387	2.4768	2.0386	2.2862		
17	2.2862	2.4768	2.4196	2.0767	2.3624		2.2862
18	2.2481	2.5911	2.6482	2.6101	2.4387		2.4387
19	3.1436	2.6673	2.7816		2.5149		2.8959
20	2.3243	2.8197	3.296	2.4768	2.4768		2.8578
21	2.2481	2.6673	2.8197	2.2862	2.4577		2.6673
22	2.0576	2.4768	2.5911	2.4768	2.3815		2.4768
23	1.9433	2.2862	2.3434	1.5623	2.3243		2.2862
24	1.6385	2.0957	2.2862	2.3434	1.9433	2.2862	
Max	3.1436	2.8197	3.296	2.6101	2.5149	2.2862	2.8959
Min	1.5242	.0191	2.0957	1.5623	1.6004	2.0576	1.7909
Avg	2.1156	2.3617	2.4212	2.2191	2.2227	2.1457	2.2743

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 201 / 11 KV MEDICAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0075	
8		.5729	.0075	.6535
10		.0055		.4938
11	.6335	.005		.5304
12	.5249	.0503		.4755
13	.439		.4755	.4207
14	.4024			.4251
15			.4938	
16	.4938	.0054	.4706	.4207
17	.5792	.0054	.4835	.5121
18	.7783	.0071		.5853
19	.7682	.0091		.8316
20	.7682	.0075		.6348
21	.6283	.0075	.679	.6348
22				.5975
23		.0057		.6224
Max	.7783	.5729	.679	.8316
Min	.4024	.005	.0075	.4207
Avg	.6016	.0619	.3739	.5599

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 202 / 11 KV DWARAKA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.0168	
8	.0168	1.6448	1.6057	.0185	1.5339
10			.0163		1.448
11		1.9004	.0163		1.3535
12		1.4661	.0161		1.5181
13		1.3535		1.3394	1.6827
14		1.2437			1.5181
15				1.2936	
16		1.2437	.0148	1.2803	1.5729
17		1.3032	.0125	1.2986	1.6827
18		1.5384	.0181		1.9204
19		1.6461	.0238		2.3228
20		1.7193	.024		2.1992
21		1.4632	.0222	1.7364	2.1658
22					2.0165
23			.0187		1.7353
Max	.0168	1.9004	1.6057	1.7364	2.3228
Min	.0168	1.2437	.0125	.0168	1.3535
Avg	.0168	1.5020	.1626	.9977	1.7621

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 204 / 11 KV SWAMI SAMARTH
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17	24-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
4			.3018
6			.3772
8		.4294	.462
16	.4108	.3475	
17	.4294	.3511	
18	.4294		
19	.4854		
20	.4715	.5853	
21	.4668		
22	.4338	.4066	
23	.3174		
24			.332
Max	.4854	.5853	.462
Min	.3174	.3475	.3018
Avg	.4306	.4240	.3683

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154075 / 33/11 KV ARVI

Feeder No / Name : 205 / 11 KV SIDDESHWAR MANDIR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.0036	
8		.2402	.0054	.2378
10		.0052		.1696
11		.005		.1715
12	.2058	.005		.1715
13	.2543		.2058	.1753
14	.1772			.1772
15			.1734	
16	.1543	.0035	.1612	.1734
17	.1715	.0034	.1433	.1772
18	.2103	.0034		.2126
19	.2303	.0053		.1791
20	.2126	.0037		.1867
21	.1772	.0037	.1848	.2033
22				.1867
23		.0036		.1494
Max	.2543	.2402	.2058	.2378
Min	.1543	.0034	.0036	.1494
Avg	.1993	.0256	.1254	.1837

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 201 / 11 KV Vivekanand Chowk
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8573	.8916		.7545	.8779	.8402
2	.7202	.8573	.8916	.8402	.7202	.8413	.8573
3	.7202	.8573	.8916	.8573	.7202	.8413	.8916
4	.7202	.8573	.8573	.8573	.7202	.823	.823
5	.7545	.9431	.9511	.8402	.7545	.823	.8916
6	.7545	.9431	.9877	.8916	.8573	.8962	.9259
7	.8573	1.0288	1.0425	.9088	1.0288		.9431
8	.8573	.9431	1.0059	.9088	.8916		.9774
9	.8916	.9431	.9602		.8059	.9259	.9431
10	.8573	.7545	.8573		.7373	.7888	.8573
11	.6001	.7716	.9602		.7373	.7888	.7373
12	.583	.5658	.7202		.6859	.823	.6859
13	.6344	.6001	.7716		.6687	.823	.5536
14	.6173	.583	.823			.6516	.6001
15	.6516	.6687	.7545		.8402	.6516	.6001
16	.6516	.7716	.9602	.7468	.7373	.6516	
17	.6859	.7888	.823	.7202	.8413	.7888	.7202
18	.7716	.823	.7373	1.0288	.9694	.9088	.8573
19	.9945	1.0631	1.0117	1.0288	1.2254	1.0631	1.0974
20	1.0288	1.166	1.166	.9945	1.1523	1.0802	1.1317
21		1.1317	1.1488	.9259	1.134	1.1145	1.0631
22	.9431	1.1145	1.1145	.8573	1.0059	1.0117	.9602
23	.8573	1.0631		.823	.9694	.8916	.8916
24	.7716	.8573	.9945		.7888	.8962	.8402
Max	1.0288	1.166	1.166	1.0288	1.2254	1.1145	1.1317
Min	.583	.5658	.7202	.7202	.6687	.6516	.5536
Avg	.7686	.8731	.9271	.8820	.8585	.8619	.8561

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 203 / 11 KV Gandhi Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545			.7888	.7888	.9145	.8059
2	.7202	.7716		.7716	.7545	.9145	.7888
3	.7202			.7716	.7545	.9145	.7888
4	.7202	.7716		.8059	.7545	.9511	.823
5	.7545	.8573		.8573	.7888	.9877	.8573
6	.7888	.9259		.8916	.8916	1.0242	.9259
7	.8916	.9259		.8916	1.0288	1.0242	.9602
8	.8573	.9431		.9945	1.0631	1.0608	.9945
9	.9259	.9774	1.0974		1.1145	1.0288	1.0288
10	1.0974	.4287	1.1317		1.1488	1.0288	1.4575
11	1.406	.6687	1.2003		1.4403	1.0631	1.5432
12	1.7147	1.6804			1.5432	1.1317	1.5569
13	1.5432	1.6461			1.5947	1.2346	
14	1.5604	1.4575	1.749		1.5432	1.2003	1.5432
15	1.5432	1.4918	1.749		1.5089	1.0974	1.4575
16	1.5432	1.5775	1.8519	1.2003	1.4403	.9945	1.5927
17	1.6289	1.6289	1.749	1.3375	1.6461	1.1145	1.5432
18	1.7147	1.6118	1.6632	1.5432	1.829	1.2346	1.7147
19	1.8347		2.1776	1.5775	2.2497	1.2689	1.989
20	1.7147	2.2119	1.8861	1.406	2.1582	1.286	1.989
21	1.5432	1.7318	1.8519	1.2346	1.9753	1.1831	1.7147
22	1.2003	1.1831	1.2346	1.1317	1.2254	.9945	1.2346
23	.8573	1.0631	.8402	.8916	.9877	.8573	.9602
24	.7716	.865		.8059	.8916		.8059
Max	1.8347	2.2119	2.1776	1.5775	2.2497	1.286	1.989
Min	.7202	.4287	.8402	.7716	.7545	.8573	.7888
Avg	1.2003	1.2104	1.5525	1.0530	1.2967	1.0656	1.2642

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 204 / 11 kV Subhash Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3429		.3429	.3429	.3658	.3601
2	.3086	.346		.3258	.3429	.3292	.3429
3	.2743	.346		.3772	.3086	.3292	.3429
4	.2743	.3429		.4287	.3086	.3292	.3944
5	.3086	.3429		.463	.3086	.3658	.3944
6	.3429	.4287		.463	.3772	.4024	.4115
7	.3772	.463		.463	.3772	.439	.4287
8	.4115	.5144		.4973	.4801	.4938	.4458
9	.4458	.5144	.583		.5487	.4458	.692
10	.5144	.5316	.6173		.583	.5144	.7716
11	.823	.8745	.6516		.8402	.5144	.9088
12	.8916	.9774	.7545		.9088	.6001	.9431
13	.9088	.9945	.823		.9088	.8573	.9774
14	.9259	1.0631	.8573		.9602	.8573	.9861
15	.8916	.9774	.7888		.9774	.8573	.9774
16	.8573	1.0117	.823	.8764	.9774	.823	1.086
17	1.0288	.9945	.9088	.9259	1.0974	.8745	1.0974
18	1.1145	1.046	.9431	1.166	1.134	.9088	1.2003
19	1.2003	1.3203	1.286	1.0974	1.3352	.8916	1.3375
20	1.1244	1.3717	1.286	1.0288	1.3535	.8059	1.3717
21	1.0288	1.1317	1.2346	.8573	1.2437	.7202	1.2346
22	.6859	.6173	.6687	.5487	.7316	.4973	.8573
23	.3429	.5144	.5487	.4458	.439	.4115	.4801
24	.3429	.346		.3429	.3772	.3841	.3601
Max	1.2003	1.3717	1.286	1.166	1.3535	.9088	1.3717
Min	.2743	.3429	.5487	.3258	.3086	.3292	.3429
Avg	.6570	.7256	.8516	.6265	.7193	.5841	.7668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 205 / 11 KV Hattenagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859			.7545	.5487	.7316	.6344
2	.6516	.6859		.7202	.5487	.7316	.6173
3	.6516	.6859		.7202	.5144	.695	.6173
4	.6516	.6859		.7716	.5144	.695	.6516
5	.6859	.692		.7716	.5487	.7316	.6859
6	.7716	.7716		.8059	.6173	.7316	.6859
7	.8573	.8573		.8402	.6859	.9694	.703
8	.8916	.865		.9259	.6859	1.0059	.6687
9	.8573	.7716	.9945		.6173	.9259	.6001
10	.8573	.9259	.823		.5487	.6859	.5144
11	.823	.8916	.8916		.6001	.6516	.7716
12	.7888	.7716	.6859		.5487	.6859	.4801
13	.6173	.7716			.5316	.6001	.519
14	.6173	.7716	.7545		.5487	.5487	.5144
15	.6516	.7888	.7545		.5487	.5487	.463
16	.6859	.7202	.7888	.5258	.5658	.5144	.4887
17		.8916	.9602	.583	.695	.6001	.5144
18	.8573	.8916	.9774	.7545	.7499	.6687	.6859
19	1.0288	1.0117	1.0288	.7202	.9694	.7202	.7888
20	.9431	1.1145	1.0974	.6935	1.0608	.7716	.823
21	.9259	1.0288	1.0631	.6173	.9877	.823	.7545
22	.8573	.9945	1.0288	.6173	.9328	.7888	.6859
23	.6859	.823	.8916	.583	.8048	.6687	.6516
24	.6859	.7785		.823	.583	.7499	.6344
Max	1.0288	1.1145	1.0974	.9259	1.0608	1.0059	.823
Min	.6173	.6859	.6859	.5258	.5144	.5144	.463
Avg	.7709	.8344	.9100	.7193	.6649	.7185	.6314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D[419] BU 5118

Substation No/ Name :- 154116 / 33/11 KV OPH S/S

Feeder No / Name : 206 / 11 KV SALE GALLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6001		.5487	.5487	.6219	.5658
2	.4801			.6001	.5487	.6219	.583
3		.6001		.6001	.5144	.6219	.6516
4	.4801	.6001		.6173	.5144	.6219	.7202
5	.5144	.6001		.6516	.5487	.6584	.7202
6	.583	.6859		.703	.6516	.695	.7373
7	.6516	.6859		.7202	.6516	.695	.7373
8	.6516	.6859		.6859	.6859	.7499	.6687
9	.6859	.6344	.8916		.583	.6859	.6001
10	.6859	.5658	.583		.5487	.7202	.5658
11	.5316	.463	.6516		.5487	.7545	.5316
12	.5144	.5658			.5316	.7202	.5144
13	.4458	.583	.6173		.5316	.6173	.463
14	.4458	.6001	.6516		.5144	.5487	.463
15	.463	.463	.5144		.4973	.5487	.463
16	.4801	.463	.5487	.5609	.5316	.5144	.5249
17	.5144	.4973	.7716	.583	.5853	.583	.5144
18	.6001	.5316	.9774	.7202	.6584	.6173	.6173
19	.7373	.703	.7545	.7888	.8596	.7202	.7545
20	.6859	.8573	.8059	.7545	.8413	.7373	.7545
21	.6859	.7888	.7716	.6859	.7682	.6859	.7202
22	.6516	.7373	.7373	.6516	.7316	.6687	.6859
23	.6001	.6859	.5487	.6173	.6401	.6001	.6173
24	.5144	.6001		.6001	.583	.6036	.5658
Max	.7373	.8573	.9774	.7888	.8596	.7545	.7545
Min	.4458	.463	.5144	.5487	.4973	.5144	.463
Avg	.5703	.6173	.7018	.6523	.6091	.6505	.6142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 202 / 11KV MIDC SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5847	.6097	.6097	.5335	.5281	.2774
2	.6097	.6224	.6097	.6859	.5716	.6036	.3121
3	.6859	.679	.6287	.7621	.6287	.6602	.3429
4	.8002	.7545	.6287	.8676	.7545	.7545	.4115
5	.9431	.8488	.8488	.9431	.8676	.811	.4409
6	.9242	1.0374	1.1128	1.0562	.9997	.9054	.4748
7	.9242	1.0751	1.0562	1.094		1.0562	.4862
8	.9619	.8865	.7167	1.0374		1.0562	.4694
9	.8299	.6602	.1907	.7922	1.094	.8676	.3601
10	.2601	.2427	.1907	.1949	.3224	.3012	.6224
11	.0886	.2572	.2601	.1753	.2804	.3506	.5281
12	.0886	.2572	.2743	.1753	.2743	.3086	.4338
13	.2279	.2543	.3222	.2058	.2543	.3018	.4338
14	.2401	.2515	.2883	.2743	.2984	.285	.4904
15	.2543	.2683	.3052	.2883	.2486	.285	.4715
16	.2515	.3018	.3052	.3052	.2321	.3052	.5093
17	.2572	.3222	.285	.3353	.2374	.285	.5093
18	.4904	.4904	.5093	.5281	.4904	.679	.4715
19	.811	.679	.7545	.5658	.7356	.7545	.7545
20	.7922	.811	.8865	.5847	.8299	.8299	.7356
21	.7545	.7545	.8676	.6602	.7167	.7545	.7356
22	.679	.724	.6859	.6224	.7167	.6859	.6979
23	.6224	.6668	.6097	.5281	.6224	.6097	.5658
24	.5281	.547	.6097	.6097	.4763	.5658	.1928
Max	.9619	1.0751	1.1128	1.094	1.094	1.0562	.7545
Min	.0886	.2427	.1907	.1753	.2321	.285	.1928
Avg	.5665	.5824	.5648	.5792	.5539	.6060	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 203 / 11KV NANDGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.298	.2454	.1753	.208	.2427		.3429
2	.3155	.2629	.1734	.2427	.2601		.381
3	.3506	.3155	.1734	.2743	.2572		.4191
4	.3258	.3506	.1886	.3086	.2883		.4904
5	.3391	.3429	.2204	.3052	.3222		.5281
6	.3561	.3772	.2713	.3391	.3391		.5658
7	.4409	.4239	.4191	.3353	.3561		.5847
8	.4748	.3601	.3856	.3353			.4715
9	.3688	.4191	.3391	.3856	.3018		.2829
10	.2263	.1886	.2641	.2829	.1886		.2915
11	.2641	.1886	.1698	.1698	.1509	.1698	.3086
12	.2075	.1509	.1509	.1509	.1509	.1886	.2743
13	.1886	.1509	.1698	.1509	.2263	.2641	.2713
14	.1886	.1886	.1886	.1509	.1886	.2452	.2572
15	.2263	.1886	.2263	.1698	.1698	.2641	.2058
16	.2075	.1509	.2263	.1886	.2075	.3018	.2572
17	.3018	.1886	.2641	.2075	.2829	.2263	.3222
18	.3018	.1886	.2641	.3772	.3206	.3772	.3584
19	.3961	.3395	.3395	.3772	.415	.415	.3772
20	.415	.415	.415	.3961	.4338	.4715	.3772
21	.415	.3395	.3772	.3395	.415	.415	.415
22	.3584	.3239	.3429	.2075	.3395	.3429	.3584
23	.298	.3048	.3239	.2829	.3018	.3239	.3018
24	.2629	.2103	.1753	.2103	.2103	.1578	.3239
Max	.4748	.4239	.4191	.3961	.4338	.4715	.5847
Min	.1886	.1509	.1509	.1509	.1509	.1578	.2058
Avg	.3136	.2756	.2602	.2665	.2769	.2974	.3653

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 204 / 11KV NAGZARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2263	.2667	.2667	.2286	.2263	
2	.2667	.2263	.2667	.2286	.2286	.2263	
3	.2858	.2641	.2667	.2858	.2477	.2641	
4	.3239	.2641	.2858	.3018	.2452	.2829	
5	.362	.2829	.3018	.3018	.2641	.2829	
6	.3584	.3018	.3395	.3395	.2829	.3206	
7	.3395	.3206	.3018	.3584	.3018	.3395	
8	.2452	.2452	.2452	.3395		.3395	
9	.2075	.2641	.2263	.2263	.2263	.2075	.4024
10	.4748	.4287	.4748	.4382	.3429	.3429	.2452
11	.5533	.5426	.5935	.5144	.4527	.373	.2075
12		.6274	.6706	.5144	.4024	.3647	.1886
13	.5304	.6203	.6371	.57	.3856	.3932	.2452
14	.5898	.6036	.6539	.4862		.431	.2263
15	.5898	.6036	.6203	.4191		.4096	.1698
16	.5571	.6203	.6706	.5197	.2883	.426	.1886
17	.5935	.6962	.6539	.5197	.3353	.3932	.2263
18	.2075	.1886	.1886	.2263	.2641	.2641	.2452
19	.3018	.2829	.2641	.2452	.3395	.3018	.3018
20	.3395	.3584	.3206	.2829	.3772	.3584	.3206
21	.3395	.3395	.3395	.2641	.3584	.3395	.3206
22	.3018	.3239	.3239	.2452	.3018	.3048	.2829
23	.2641	.2858	.3048	.2452	.2829	.2858	.2641
24	.2286	.2263	.2667	.2667	.2096	.2641	.2427
Max	.5935	.6962	.6706	.57	.4527	.431	.4024
Min	.2075	.1886	.1886	.2263	.2096	.2075	.1698
Avg	.3691	.3810	.3951	.3502	.3031	.3226	.2549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 205 / Rajeshwari Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0018	.0018	.0018	.0018	.0018	.0018	.0018
2	.0018	.0018	.0018	.0018	.0018	.0018	.0018
3	.0018	.0018	.0018	.0018	.0018	.0018	.0018
4	.0018	.0018	.0018	.0018	.0018	.0018	.0018
5	.0018	.0018	.0018	.0018	.0018	.0018	.0018
6	.0018	.0018	.0018	.0018	.0018	.0018	.0018
7	.0018	.0018	.0018	.0018	.0018	.0018	.0018
8	.0018	.0018	.0018	.0018		.0018	.0018
9	.0018	.0018	.0018	.0018	.0018	.0018	.0018
10	.0018	.0018	.0018	.0018	.0018	.0018	.0018
11	.0018	.0018	.0018	.0018	.0018	.0018	.0018
12	.0018	.0018	.0018	.0018	.0018	.0018	.0018
13	.0018	.0018	.0018	.0018	.0018	.0018	.0018
14	.0018	.0018	.0018	.0018	.0018	.0018	.0018
15	.0018	.0018	.0018	.0018	.0018	.0018	.0018
16	.0018	.0018	.0018	.0018	.0018	.0018	.0018
17	.0018	.0018	.0018	.0018	.0018	.0018	.0018
18	.0018	.0018	.0018		.0018	.0018	.0018
19	.0019	.0018	.0018	.0018	.0018	.0018	.0018
20	.0018	.0018	.0018	.0018	.0018	.0018	.0018
21	.0018	.0018	.0018	.0018	.0018	.0018	.0018
22	.0018	.0018	.0018	.0018	.0018	.0018	.0018
23	.0018	.0018	.0018	.0018	.0018	.0018	.0018
24	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Max	.0019	.0018	.0018	.0018	.0018	.0018	.0018
Min	.0018	.0018	.0018	.0018	.0018	.0018	.0018
Avg	.0018	.0018	.0018	.0018	.0018	.0018	.0018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154013 / 33/11 KV HARANGUL

Feeder No / Name : 206 / harangul SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4191	.4763	.5716	.4572	.4763	.2774
2	.5335	.5144	.4763	.6478	.5335	.5335	.3086
3	.5716	.6097	.5144	.7621	.6287	.6859	.3429
4	.7049	.7621	.6668	.9907	.7621	.8002	.3772
5	.9335	.9907	.8383	1.1431	.8573	.9145	.4409
6	1.0669	1.1241	1.0669	1.1812	.9907	1.0288	.4748
7	1.0288	.9717	1.0288	1.2193	1.2193	1.086	.4862
8	.9907	.9526	.8573	1.086	1.0288	1.0098	.5365
9	.8383	.743	.6478	.8192	.8192	.8002	.4359
10		.3772	.3429	.3772	.2328	.3856	.3239
11	.3812	.3391		.4115	.1753	.3856	.5335
12	.3768	.3222	.3561	.3944	.1753	.4024	.4954
13	.3725	.3018	.4191	.3429	.3772	.3277	.4001
14	.3239	.3018	.4475	.3856	.3647	.3978	.381
15	.2915	.3185	.4973	.3772	.3315	.4024	.4001
16	.3277	.3185	.5138	.373	.3113	.431	.362
17	.3018	.3768	.3647	.4475	.2572	.3978	.5144
18	.4763	.4572	.4382	.4904	.5525	.5716	.6478
19	.7811	.6859	.6478	.5716	.8002	.724	.9145
20	.8383	.8002	.7621	.6097	.7811	.8573	.7621
21	.7049	.7811	.6859	.5525	.6478	.8002	.6287
22	.5525	.7049	.5716	.4763	.5525	.6478	.5716
23	.4763	.5716	.4954	.4191	.4572	.4763	.4382
24	.4001	.3429	.4763	.4572	.381	.4001	.2427
Max	1.0669	1.1241	1.0669	1.2193	1.2193	1.086	.9145
Min	.2915	.3018	.3429	.3429	.1753	.3277	.2427
Avg	.5978	.5870	.5909	.6295	.5706	.6226	.4707

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 201 / 11KV BHADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.12			.1715
4	.12			.1886
6	.1715			.2572
7	.2058	.218		.2915
8	.1543			.3086
9	.1715			.2058
12			.12	.0934
16			.0686	
18				.112
22			.1543	
24	.1029	.1326		.1715
Max	.2058	.218	.1543	.3086
Min	.1029	.1326	.0686	.0934
Avg	.1494	.1753	.1143	.2000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 202 / 11KV MAMDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.1029			.0857	
4	.12			.0857	
5					.1357
6	.2401			.1029	.1006
7	.2229	.0995		.0857	
8	.1715			.1543	
9	.1543			.1715	
12			.2229	.1357	
16			.2229		
18				.2402	
22			.2229		
24	.1029	.1006		.1029	
Max	.2401	.1006	.2229	.2402	.1357
Min	.1029	.0995	.2229	.0857	.1006
Avg	.1592	.1001	.2229	.1294	.1182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 203 / 11KV BHADGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3086			.2743	
4	.3086			.3772	
5					.3326
6	.463			.5316	.4108
7	.5658	.6535		.6001	
8	.4973			.5144	
9	.4287			.4287	
12			.3772	.3561	
16			.4287		
18				.3361	
22			.3429		
24	.3258	.3547		.3086	
Max	.5658	.6535	.4287	.6001	.4108
Min	.3086	.3547	.3429	.2743	.3326
Avg	.4140	.5041	.3829	.4141	.3717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154022 / 33/11 KV MAMDAPUR

Feeder No / Name : 204 / 11KV SOLVANT

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.3086			.1886	
4	.2743			.1715	
5					.1526
6	.2572			.1715	.1663
7	.2743	.3688		.1715	
8	.1886			.1886	
9	.3258			.1715	
12			.3258	.1492	
16			.4287		
18				.1509	
22			.1715		
24	.3429	.3391		.1715	
Max	.3429	.3688	.4287	.1886	.1663
Min	.1886	.3391	.1715	.1492	.1526
Avg	.2817	.3540	.3087	.1705	.1595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 203 / SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3563	.2858	.4252		.4115	.4481
2		.3563	.2972	.4252		.4115	.4481
3		.3887	.463	.4458		.4287	.4854
4		.3887	.4801	.4801		.4115	.5601
5		.3887	.4973	.5144		.5487	.7316
6		.5182	.6516	.5533		.6344	.7316
7		.6154	.6401	.8048		.5944	.5868
8		.583	.503	.7712		.6554	.5851
9	.6104	.6859	.6562	.7716		.8962	.6173
10	.4108	.2058		.3772		.4668	.3772
11	.3361	.1715		.3601		.3174	.2743
12	.2987	.1543		.3086		.3018	.2743
13	.2452	.12		.2743		.3018	
14	.2641	.1886		.2915		.3206	
15	.2829	.2229		.2743		.3206	
16		.2743				.3395	
17		.2572	.2614		.4572	.2987	
18		.2572	.3174		.4725	.3772	
19		.6001	.5228		.4877	.6348	
20		.6001	.5975		.6173	.6348	
21		.6001	.6535		.6173	.5601	
22		.5144	.5975		.5144	.5228	
23		.4458	.5228		.4801	.4481	
24		.3563	.4287	.4252		.4287	.4527
Max	.6104	.6859	.6562	.8048	.6173	.8962	.7316
Min	.2452	.12	.2614	.2743	.4572	.2987	.2743
Avg	.3497	.3854	.4927	.4689	.5209	.4694	.5056

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 204 / PTS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0377	.0229	.0377		.0343	.0377
2		.0377	.0343	.0377		.0343	.0377
3		.0377	.0343	.0377		.0343	.0377
4		.0377	.0343	.0381		.0343	.0377
5		.0377	.0343	.0381		.0343	.0373
6		.0377	.0343	.0381		.0343	.0373
7		.0377	.0343	.0373		.0343	.0366
8		.0377	.0343	.0373		.0343	.0366
9	.0377	.0343	.0377	.0229		.0377	.0343
10	.0373	.0343		.0343		.0377	.0343
11	.0373	.0343		.0229		.0377	.0343
12	.0373	.0343		.0343		.0377	.0343
13	.0373	.0343		.0343		.0377	
14	.0377	.0343		.0343		.0377	
15	.0377	.0343		.0343		.0377	
16		.0343		.0343		.0377	
17		.0229	.0373		.0343	.0377	
18		.0343	.0373		.0343	.0377	
19		.0343	.0373		.0343	.0377	
20		.0343	.0377		.0343	.0373	
21		.0343	.0377		.0343	.0373	
22		.0343	.0377		.0343	.0373	
23		.0343	.0377		.0343	.0377	
24		.0377	.0343	.0377		.0343	.0377
Max	.0377	.0377	.0377	.0381	.0343	.0377	.0377
Min	.0373	.0229	.0229	.0229	.0343	.0343	.0343
Avg	.0375	.0351	.0352	.0348	.0343	.0364	.0364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 205 / 11KV BABHALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3601	.306		.703	.7545
2		.3239	.3601	.3199		.703	.7167
3		.3563	.3601	.3201		.703	.7095
4		.3563	.3601	.3616		.7202	.7095
5		.4372	.2401	.3765		.7888	.8215
6		.4372	.4801	.4161		.8745	1.0082
7		.4858	.6516	.4458		.5658	.4755
8		.5506	.5658	.547		.6001	.4527
9	.4915	.4287	.6093	.5144		.6348	.5144
10	.6535	.583		.7373		.8215	.5487
11	.6036	.5144		.6173		.7468	.5487
12	.5658	.2858		.6001		.6161	
13	.5281	.463		.583		.6161	
14	.5281			.583		.6535	
15	.5281	.4801		.5487		.4668	
16		.4801		.4973		.5975	
17		.5144	.6036		.5144	.6602	
18			.5847		.5316	.7468	
19		1.0631	.8488		.5144	.9808	
20		1.0288	.9054		.9602	1.0185	
21		.9602	.9808		.9602	.9335	
22		.9088	.9054		.8916	.8962	
23		.3725	.7922		.7888	.6413	
24		.3239	.3601	.306		.7202	.7922
Max	.6535	1.0631	.9808	.7373	.9602	1.0185	1.0082
Min	.4915	.2858	.2401	.306	.5144	.4668	.4527
Avg	.5570	.5308	.5864	.4753	.7373	.7254	.6710

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 206 / 11KV DHANEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3429			.5487	.6224
2		.3239	.3772			.5487	.5601
3		.3563	.4287	.3475		.6001	.679
4		.3725	.4801	.3765		.6516	.6584
5		.3887	.4572	.4054		.6859	.7316
6		.502	.4877	.3765		.7716	.8779
7		.6478	.6249			.823	.9511
8		.6964	.5316			.703	.8589
9	.5535	.4973	.5624	.6097		.4338	.6687
10	.5601	.5144		.8573			.4973
11	.4904	.4458		.4687		.3018	.4801
12	.4904	.3601		.4115		.4854	.3601
13	.2263	.2058		.1886		.6535	
14	.2641	.2401		.1029		.5601	
15	.3018	.2572		.3772		.3734	
16		.2743		.4973		.2801	
17		.4287	.3734		.4268	.6224	
18		.4115	.1143		.4725	.7095	
19		.9088	.8299		.503	1.0751	
20		.9259	.8676		.7888	.8589	
21		.8059	.9054		.7202	.7545	
22		.7545	.8676		.6516	.7167	
23		.6344	.7922		.6001	.6413	
24		.3077	.3429	.282		.5658	.6602
Max	.5601	.9259	.9054	.8573	.7888	1.0751	.9511
Min	.2263	.2058	.1143	.1029	.4268	.2801	.3601
Avg	.4124	.4827	.5521	.4078	.5947	.6246	.6620

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154033 / 33/11 KV BABHALGAON

Feeder No / Name : 207 / 11KV SHELU SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1886	.1905		.1886	.1886
2			.1886	.1905		.1715	.1886
3			.1372	.1905		.1715	.1886
4			.2229	.2096		.1715	.2096
5			.16	.2286		.1886	.2286
6			.2572	.2286		.2401	.2477
7			.2572	.3048		.2401	.2858
8			.1886	.2286		.2572	.2286
9	.2477	.1372	.1698	.1886		.2241	.2058
10	.4938	.2229		.3258		.3361	.381
11	.4451			.2572		.2801	.2591
12	.3467			.2915		.3174	.2743
13	.2553	.2743		.2915		.1132	
14	.2705	.3258		.2401		.0566	
15	.2401	.3258		.3258		.1132	
16		.2743		.2743		.1509	
17		.2058	.3477		.12	.1524	
18		.12	.1143		.1372	.1905	
19		.2229	.1905		.2229	.2477	
20		.2401	.2096		.2591	.2477	
21		.2229	.2477		.2286	.2477	
22		.2229	.2096		.1886	.2477	
23		.2058	.2096		.1886	.2286	
24			.1886	.1905		.1886	.2286
Max	.4938	.3258	.3477	.3258	.2591	.3361	.381
Min	.2401	.12	.1143	.1886	.12	.0566	.1886
Avg	.3285	.2308	.2052	.2445	.1921	.2072	.2396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 201 / TAKLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1619
2					.1619
3					.1619
4					.1943
5					.2267
6					.2915
7		.2458			.3077
8		.213	.216		
9		.213	.1865		.2915
10				.3353	
11	.1581			.3052	
12	.1357			.2374	
13	.1017			.2035	
14	.0848			.1865	
15	.0972			.1781	
16				.1898	
18	.3018				.3201
19	.4382	.2486			
20	.4572				
21	.3658				.3048
22	.3174				
24					.1619
Max	.4572	.2486	.216	.3353	.3201
Min	.0848	.213	.1865	.1781	.1619
Avg	.2458	.2301	.2013	.2337	.2349

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 202 / KATGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1619
2					.1867
3					.1867
4					.2241
5					.2801
6					.3658
7		.6554			.4525
8		.5735	.4801		
9		.4096	.2572		
11	.6287				
13	.6478			.7287	
14				.7287	
15	.5668			.7287	
16	.503			.6325	
17	.4049				
18	.2804				.2187
19	.3696	.2572			
20	.4668				
21	.4108				.3391
22	.3734				
24					.1619
Max	.6478	.6554	.4801	.7287	.4525
Min	.2804	.2572	.2572	.6325	.1619
Avg	.4652	.4739	.3687	.7047	.2578

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 203 / RAMESHWAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1307
2					.1307
3					.1307
4					.1494
5					.2172
6					.3258
7		.4096			.3506
8		.3239	.2949		
9		.176	.1433		
10				.2429	
11	.2538			.2429	
12				.2429	
13	.2591			.2429	
14	.2949			.1898	
15	.2915			.1581	
16	.2429			.1265	
17	.1943				
18	.1296				.0671
19	.2614	.1677			
20	.2614				
21	.2241				.2058
22	.2054				
24					.1307
Max	.2949	.4096	.2949	.2429	.3506
Min	.1296	.1677	.1433	.1265	.0671
Avg	.2380	.2693	.2191	.2066	.1839

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 204 / 11 KV BHOISAMUDRA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3239
2					.3239
3					.3239
4					.3563
5					.3896
6					.4534
7		.5851			.4696
8		.5535	.1524		
9		.4744	.4954		
10				.2143	
11	.0655			.2429	
12	.0678				
13	.0655			.2372	
14				.2629	
15	.0671			.2204	
16	.1006			.2035	
17	.1341				
18	.218				.2622
19	.3734	.1787			
20	.4294				
21	.4294				.3086
22	.3734				
24					.3506
Max	.4294	.5851	.4954	.2629	.4696
Min	.0655	.1787	.1524	.2035	.2622
Avg	.2113	.4479	.3239	.2302	.3562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 205 / 11 KV GANJUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0934
2					.0747
3					.0747
4					.0934
5					.1448
6					.2353
7		.218			.2896
8		.2515	.1905		
9		.2012	.1524		
10				.1619	
11				.2846	
12	.2591			.2846	
13	.2622			.2372	
14	.2591			.2429	
15	.2591			.2372	
16	.2267			.2204	
17	.1619				
18	.1063				.1524
19	.1494	.1905			
20	.1867				
21	.168				.2218
22	.1494				
24					.1052
Max	.2622	.2515	.1905	.2846	.2896
Min	.1063	.1905	.1524	.1619	.0747
Avg	.1989	.2153	.1715	.2384	.1485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154040 / 33/11 KV TAKALI

Feeder No / Name : 206 / 11 KV JEWALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.2103
2					.1966
3					.1966
4					.2297
5					.2915
6					.3239
7		.3041			.3563
8		.3384	.2096		
9		.2921	.3353		
10				.1134	
11	.0532			.0648	
12	.0549			.0648	
13	.0486			.0648	
14	.0486			.0905	
15	.0486			.0474	
16	.0486			.0486	
17	.0509				
18	.0532				.0762
19	.112	.0381			
20	.1494				
21	.1307				.112
22	.112				
24					.2241
Max	.1494	.3384	.3353	.1134	.3563
Min	.0486	.0381	.2096	.0474	.0762
Avg	.0759	.2432	.2725	.0706	.2217

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 201 / 11KV BORI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058	.3772		.2058	.4115
2			.2058	.4115		.1715	.4115
3			.2058	.3772		.2058	.4458
4			.2743	.3772		.2058	.4801
5			.4115	.3772		.2743	.5144
6	.4115		.4801	.3772		.3429	.8916
7			.5487	.5144		.4801	.823
8	.4801	.5487		.4801		.4801	.6859
9	.4115	.4458	.4115	.4458		.4801	
10	.5487	.4115	.4801	.6859		.6516	.3429
11	.4115	.3772	.4801	.6173		.5144	
12		.3429	.3429	.4801		.4458	
13		.3772	.2743			.4458	
14		.3429	.2743	.3429		.4115	
15			.3429	.3429		.4115	.3429
16			.3429	.4115	.6173	.4458	
17		.3429	.3772	.3429	.4115	.4115	.3429
18		.6859	.4115	.5487	.4801	.4801	.4458
19		.823	.7545			.7545	.7202
20		.7545	.7545		.823	.7202	.823
21		.6173	.6516		.6859	.583	.6173
22		.5487	.583		.5487	.5144	.5144
23			.5144		.4801	.4458	.4801
24	.2743			.3772		.2058	.4115
Max	.5487	.823	.7545	.6859	.823	.7545	.8916
Min	.2743	.3429	.2058	.3429	.4115	.1715	.3429
Avg	.4229	.5091	.4240	.4382	.5781	.4287	.5392

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 202 / 11KV MUSHIRABAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058	.2401		.1372	.2058
2			.2058	.2401		.1372	.2058
3			.2058	.2743		.1372	.2058
4			.2058	.2743		.2058	.2401
5			.2743	.3429		.2058	.2743
6	.3429		.3429	.3429		.2743	.5144
7			.4115	.4458		.4115	.583
8	.4115	.5144		.4801		.3429	.4115
9	.3429	.4801	.3429	.4115		.4115	
10	.2743		.2058			.2743	.1715
11	.2058		.1372			.2401	
12	.1372	.2058	.1372	.1372		.2058	
13		.1715	.1372	.1372		.2058	
14		.1372	.1029	.1372		.2058	
15		.1372	.1029	.1029		.1715	.2743
16			.1372	.1372	.1372	.1715	
17		.1715	.1715	.1372	.2743	.2058	.2743
18		.2743	.2401	.2058	.1372	.2743	.2401
19		.4115	.5144			.5144	.2401
20		.3429	.4801		.3429	.3772	.4458
21			.3429		.2743	.3086	.3086
22		.2058	.2401		.2058	.2401	.2401
23			.2401		.2058	.2058	.2058
24	.2058			.2058		.1372	.2058
Max	.4115	.5144	.5144	.4801	.3429	.5144	.583
Min	.1372	.1372	.1029	.1029	.1372	.1372	.1715
Avg	.2743	.2775	.2447	.2501	.2254	.2501	.2915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 203 / 11KV SALGARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2058	.0686		.1029	.0686
2			.1715	.0686		.1029	.0686
3			.1715	.0857		.1372	.1029
4			.2058	.1029		.1372	.1372
5			.2058	.1715		.2058	.1372
6	.2743		.2743	.3086		.2743	.1715
7			.2743	.2743		.2743	.2058
8	.1372	.3086		.2058		.2058	.2058
9		.2401	.1372	.1715		.1372	
10	.2058	.2058	.2058	.1372		.1715	.1029
11	.2058	.1886	.2058	.1372		.1715	
12	.2058	.2743	.2743	.2058		.1715	
13		.2401	.2743			.1715	
14		.2401	.2058	.1372		.1715	
15		.2058	.2058	.2058		.1886	.1372
16			.2743	.4115	.1029	.2058	
17		.2058	.3086	.2058	.2058	.2058	.12
18		.2743	.1029	.0686	.1372	.1029	.1029
19		.2743	.1715			.1715	.1715
20		.2058	.1543		.2058	.2058	.1372
21		.1715	.1372		.1715	.1372	.1372
22		.1372	.1029		.1715	.1029	.1029
23			.0686		.1372	.0686	.0686
24	.0686			.0686		.1372	.0686
Max	.2743	.3086	.3086	.4115	.2058	.2743	.2058
Min	.0686	.1372	.0686	.0686	.1029	.0686	.0686
Avg	.1829	.2266	.1972	.1686	.1617	.1651	.1248

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154050 / 33/11 KV BORI

Feeder No / Name : 204 / 11 KV SALGARA II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4801	.7545		.4801	.5144
2			.5144	.7545		.4115	.5144
3			.5144	.8573		.4801	.4801
4			.6173	.9259		.5487	.4801
5			.823	.9945		.6859	.4801
6	.8916		.823	1.0974		.7545	.4801
7			.7545	1.0288		.7545	.6001
8	.5487	.7202		.8573		.6859	.7545
9		.583	.5487	.6859		.5487	
10	.4115	.4115	.4801	.5487		.4801	.3429
11	.4801	.583	.4801	.5487		.6516	
12	.4115	.6173	.5487	.6173		.5487	
13		.6173	.4801			.5144	
14		.5487	.4801	.4115		.4115	
15		.6173	.4801	.4115		.4801	.3772
16			.4801	.4801	.4115	.4801	
17		.4115	.6173	.4801	.4801	.5144	.4458
18		.4801	.5144	.4115	.4801	.6859	.583
19		.6173	.9259			.9259	.9259
20		.6859	1.166		.823	1.166	1.166
21		.6173	1.0288		.7545	.9945	1.0288
22		.5487	.9259		.6173	.7888	.9259
23			.7888		.4801	.7545	.7888
24	.5487			.6859			.7202
Max	.8916	.7202	1.166	1.0974	.823	1.166	1.166
Min	.4115	.4115	.4801	.4115	.4115	.4115	.3429
Avg	.5487	.5757	.6578	.6973	.5781	.6411	.6449

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 201 / 11KV KAWA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0655	.0762		.064	.0492	.2096
2	.0686	.0655	.0762		.064	.0492	.2096
3	.0686	.1134	.0762		.064	.064	.2096
4	.0838	.1134	.0762		.08	.08	.2096
5	.1006	.1619	.0762		.112	.0972	.2286
6	.1134	.1943	.0926		.1134	.0648	.2667
7	.1943	.2105	.1875		.1296	.0486	.3239
8	.2105		.253		.1296	.1791	.3239
9	.2105	.2267	.2343	.2591	.1619	.2401	.2667
10	.1524	.1905	.1524	.2915	.2096	.2096	.1543
11	.1143	.1143	.1524		.1715	.1905	.1715
12	.1143	.0953	.0953		.1143	.1524	.1829
13	.1143	.0953		.2096	.1143	.1524	.1543
14	.1334	.1143	.1143	.1143	.1524	.1334	.1852
15	.1334	.0953	.0953	.0953	.1524	.1524	.1372
16	.1143	.1143		.1524	.1334	.1334	.1372
17	.1334	.1143		.1334	.1334	.1334	.1372
18	.1334	.1143	.1524	.2667	.1524	.1715	.1715
19		.2286	.2667	.2667	.2858	.2286	
20	.2286		.2667	.2477	.2667	.2667	.2858
21	.2286	.2667	.2286	.2096	.2286	.2667	.2477
22	.2096	.2286	.2477	.2096	.1524	.2477	.2286
23	.2096	.2096		.2096	.2286	.2096	.2096
24	.0686	.0655	.0762		.064	.0492	.2096
Max	.2286	.2667	.2667	.2915	.2858	.2667	.3239
Min	.0686	.0655	.0762	.0953	.064	.0486	.1372
Avg	.1394	.1454	.1498	.2050	.1449	.1487	.2113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 202 / 11KV KHOPEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1867	.1867	.1867	.1494	.168	.0457
2	.1494	.1867	.1867	.1867	.1494	.168	.0457
3	.1494	.2054	.1867	.2241	.1867	.1848	.0457
4	.1867	.2054	.2033	.2241	.1867	.2218	.0474
5	.2054	.2241	.2587	.2427	.2241	.2054	.0648
6	.2614	.2241	.2772	.2614	.2614	.2241	.0648
7	.2427	.2427	.2772	.2427	.2614	.2587	.081
8	.1867		.1848	.1867	.2054	.2402	.0972
9	.1307	.168	.1307	.168	.1494	.2241	.0972
10	.0469	.0347	.0514		.0152	.052	.1307
11	.0312	.0693	.0686		.0152	.0347	.112
12	.0312	.0514	.0693	.0469	.0305	.0347	.0934
13	.0312	.0867	.0514	.0469	.0309	.0347	.0747
14	.0316	.052	.0693	.0469	.0312	.0347	.0934
15	.0316	.052	.052	.0316	.0316	.0347	.112
16	.0474	.0857			.0474	.0347	.0934
17	.032	.0857	.1029	.048	.048		.1307
18	.0934	.1294	.0934	.1867		.1698	.168
19	.2241	.1848	.2054	.2241	.2218	.1886	.2614
20	.2054	.2801	.2614	.2241	.2218	.2641	.2427
21	.2241	.2427	.2427	.2054	.2241	.2452	.2427
22	.2054	.2241	.2241	.2054	.2241	.2452	.2241
23	.1867	.2054	.2054	.1867	.1867	.2075	.1867
24	.168	.1867	.1867	.1867	.1494	.168	.0457
Max	.2614	.2801	.2772	.2614	.2614	.2641	.2614
Min	.0312	.0347	.0514	.0316	.0152	.0347	.0457
Avg	.1363	.1571	.1642	.1696	.1414	.1584	.1167

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154052 / 33/11 KV KAWA

Feeder No / Name : 203 / 11KV RAJIV NAGAR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0762	.0762	.0572	.0762	.0762	.0457
2	.0572	.0762	.0762	.0572	.0762	.0762	.0457
3	.0572	.0762	.0762	.0762	.0953	.1143	.0457
4	.0572	.0953	.0953	.0953	.0953	.1524	.0469
5	.1143	.1334	.1143	.1334	.1334	.1334	.064
6	.1715	.1715	.1524	.1524	.1715	.1715	.0648
7	.1524	.1715	.1905	.1905	.1715	.1905	.081
8	.1334		.1143	.1334	.1334	.1905	.1134
9	.1334	.0953	.0953	.1143	.1143	.1334	.1134
10	.0914	.0972	.08	.0762	.0762	.081	.0572
11	.0926	.0972	.16	.0781	.0914	.1134	.0191
12	.0937	.0648	.176	.125	.0914	.081	.0381
13	.1406	.081	.16	.1581	.0926	.081	.0381
14	.1406	.0972	.176	.1581	.0633	.0972	.0381
15	.125	.1296	.208	.1581	.0791	.0972	.0381
16	.1265	.0972		.1423	.0791	.0648	.0572
17	.112	.1296	.176	.192	.08	.0972	.0381
18	.0191	.0191	.0187	.0754	.0381	.0572	.0572
19	.1143	.0191	.0953	.0762	.1143	.0762	.1334
20	.1143	.1143	.0953	.0953	.1143	.0762	.1334
21	.0953	.0381	.1143	.1143	.0953	.0953	.0953
22	.0762	.0762	.0953	.0953	.0762	.0953	.0762
23	.0762	.0762	.0762	.0762	.0762	.0953	.0762
24	.0572	.0747	.0762	.0572	.0762	.0762	.0457
Max	.1715	.1715	.208	.192	.1715	.1905	.1334
Min	.0191	.0191	.0187	.0572	.0381	.0572	.0191
Avg	.1004	.0916	.1173	.1120	.0963	.1051	.0651

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 201 / 11KV WASANGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1486	.1486		.1715	.1486		.208
2	.1486	.1486		.1715	.1486		.208
3	.1486	.1635		.1715	.1486		.208
4	.1486	.1783		.1715	.1635		.2229
5	.1783	.1932		.1886	.1635		.2378
6	.1783	.1932		.2058	.1635		.2526
7	.1783	.1635		.2058	.1486		.2972
8	.1932	.1337	.1337	.1372	.1337	.1486	.2972
9		.1486	.1543	.1372	.1189	.1337	.3086
10	.1783	.2229	.2915	.2972	.2972	.2378	.1372
11	.1783	.3121	.3601	.2972	.2972	.3269	.1372
12	.1932	.3121	.3429	.3567	.3269	.3269	.0686
13	.2378	.3269	.4287	.3567	.3567	.3269	.0857
14	.2378	.3864	.4287	.3567	.3269	.2972	.0857
15	.2229	.3864	.3944	.3567	.2972	.3121	.0857
16	.1486	.3715	.3258	.3418	.2824	.3121	.0857
17	.2229	.3864	.3258	.3418	.2824	.2972	.1029
18	.0892	.0892	.1029	.1189	.1337	.0892	.12
19	.1635	.1337	.1715	.1635	.1486	.1486	.1715
20	.1783		.2229	.1635	.1783	.1783	.1886
21			.2058	.1635	.1635	.1783	.1886
22			.2229	.1635	.1635	.1635	.2058
23			.2058	.1486	.1635		.2058
24	.1486	.1486		.1715	.1486	.1486	.208
Max	.2378	.3864	.4287	.3567	.3567	.3269	.3086
Min	.0892	.0892	.1029	.1189	.1189	.0892	.0686
Avg	.1761	.2274	.2699	.2233	.2043	.2266	.1799

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 202 / 11KV GANGAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3641	.4115		.4115			.7975
2	.3467	.4801		.4115			.7802
3	.3467	.5487		.4115			.7802
4	.3814	.6173		.5487			.8322
5	.4508	.6859		.6173			1.0056
6	.4854	.703		.6859			1.1269
7	.5201	.7202		.7202			
8	.5721		.8059	.6173			1.1789
9	.5721		.8059	.6516			.8573
10	.5375		.5144	.8149	.6173		
11	.4161		.3772	.6935	.5487		.4115
12	.3481		.3772	.5721	.3429	.208	.3772
13	.3641		.3944	.4854	.5658	.5548	.4115
14	.3467		.3601	.3814	.583	.5548	.4115
15	.3467		.3601	.4161	.6173	.3814	.4458
16	.3641	.3772	.3429	.4161	.6173	.3988	.5487
17	.4854		.3601	.6241	.4973	.3814	
18	.5721		.4287	.6935	.6859	.6762	.7716
19	.9709		.7716	.9362	.9774	1.1789	.9088
20	1.0056		1.0974		1.046	1.1096	1.0802
21			.9774		.9602	1.0229	1.0802
22			.8916		.8916	.9189	.9431
23			.823		.8573		.7716
24	.3641	.3772		.3601			.7975
Max	1.0056	.7202	1.0974	.9362	1.046	1.1789	1.1789
Min	.3467	.3772	.3429	.3601	.3429	.208	.3772
Avg	.4838	.5468	.6055	.5734	.7006	.6714	.7770

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 203 / 11KV PETH SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3812			.4115	.3601		.1658
2	.3978			.4115	.3315		.1658
3	.4144			.4115	.3647		.1823
4	.4641			.463	.4115		.1989
5	.5304			.5487	.547		.1989
6	.7625			.7202	.6796		.2321
7	.8453			.7888	.663		.2486
8	.7127		.6464	.7202		.7459	.2818
9			.5144	.6344		.663	.2401
10	.2984		.3258	.2652		.1823	.3601
11	.2984		.3772	.2984		.1989	.3258
12	.3149		.3601	.1989		.2321	.3258
13	.3315		.3944	.2984		.2321	.2572
14	.3315		.4115	.2984		.2155	.2572
15	.2984		.3944	.3978		.1989	.3086
16	.2652	.3647	.2915	.4144	.2321	.2155	.3258
17	.2652		.3601	.3978		.2321	.3944
18	.3481		.3258	.431		.3149	.463
19	.5304		.5144	.4973		.4475	.6173
20	.5636		.5658	.5304		.431	.583
21			.5487	.4973		.4144	.5487
22			.4973	.4641		.3812	.4973
23			.4801	.3978			.4287
24	.3812			.4115	.3647	.3978	.1658
Max	.8453	.3647	.6464	.7888	.6796	.7459	.6173
Min	.2652	.3647	.2915	.1989	.2321	.1823	.1658
Avg	.4368	.3647	.4380	.4545	.4394	.3439	.3239

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154071 / 33/11 KV GANGAPUR

Feeder No / Name : 204 / K R REFINARY

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191			.0171			.0191
2	.0191			.0171			.0191
3	.0191			.0171			.0191
4	.0191			.0171			.0191
5	.0191			.0171			.0191
6	.0191			.0171			.0191
7	.0191			.0171			.0191
8	.0191		.0191	.0171		.0191	.0191
9			.0171	.0171		.0191	.0171
10	.0191		.0171	.0191		.0191	.0171
11	.0191		.0171	.0191		.0191	.0171
12	.0191		.0171	.0191		.0191	.0171
13	.0191		.0171	.0191		.0191	.0171
14	.0191		.0171	.0191		.0191	.0171
15	.0191		.0171	.0191		.0191	.0171
16	.0191	.0191	.0171	.0191	.0191	.0191	.0171
17	.0191		.0171	.0191		.0191	.0171
18	.0191		.0171	.0191		.0191	.0171
19	.0191		.0171	.0191		.0191	.0171
20	.0191		.0171			.0191	.0171
21			.0171	.0191		.0191	.0171
22			.0171	.0191		.0191	.0171
23			.0171	.0191			.0171
24	.0191			.0171	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0191	.0191	.0171	.0171	.0191	.0191	.0171
Avg	.0191	.0191	.0172	.0182	.0191	.0191	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 201 / 11KV CHINCHOLIRAOWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3429	.4287	.4458	.2374	.3944	.4287
2	.3086	.373	.463	.463	.3052	.4115	.4801
3	.3258	.3814	.5144	.3963	.3429	.4287	.6001
4	.3429	.5144	.5658	.4801	.4115	.4801	.7202
5	.3601	.5426	.6344	.4877	.4458	.6344	.9945
6	.3944	.6104	.703	.5182	.4801	.6687	1.1317
7	.5487	.6962	.7545	.5335	.5144	.6687	1.166
8	.703	.4748	.8745	.6613	.5087	.6173	1.1576
9		.5668	.6613	.6173		.6173	.7888
10	.4458	.3944	.5935	.3944	.5658	.4115	.3772
11	.4287	.3511	.3772	.3772	.4715	.3601	.4108
12		.2572		.3601	.3258	.3258	.4748
13		.2229		.3429	.3206		.4409
14		.2401	.2229	.3086			.4801
15	.394	.2229	.2743	.2743			.2947
16		.2229	.2374	.2743	.4287		.3294
17		.2572	.3511	.4115	.4973	.6335	.3601
18	.6687	.3086	.5175	.5487	.5658	.7468	.4287
19	.7888	.4801	.823	.8063	.5658	.8865	.6001
20	.8745	.703	.8573	.8322	.5144	.9054	.6687
21	.8063	.7545	.8059	.8322	.463	.8589	.6001
22	.7011	.5487	.7373	.6588		.6602	.5144
23	.5609	.4801	.6859	.4854	.3944	.5121	.4287
24	.3258	.2883	.3944	.4287	.2058	.3944	.463
Max	.8745	.7545	.8745	.8322	.5658	.9054	1.166
Min	.3086	.2229	.2229	.2743	.2058	.3258	.2947
Avg	.5169	.4264	.5672	.4975	.4282	.5808	.5975

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 202 / 11KV KHANDAPUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.823	.9431	.8916		.8059	.7202
2	.8059	.8322	.9259	.8573		.8402	.7716
3	.8573	.1698	.9602	.8916		.9088	.8573
4	.9602	1.1443	.9945	1.166		1.1488	.9945
5	1.2174	1.3523	1.046	1.4918		1.5089	1.286
6	1.5775	1.6991	1.0802	1.6289		1.5775	1.406
7	1.7833	1.5775	1.1317	1.6632		1.6632	1.3717
8	1.5775	1.3717		1.5089		1.5089	1.4632
9		1.4575	.7716	1.1317		1.3375	1.2346
10	.823	1.2003		.6516	.924	.5658	.8745
11	.7888	1.1361	.8402	.6516	.9259	.6001	.8745
12		1.2174	1.2346	.6344		.7373	.7888
13	.7716		.8573	.6516		.8916	.6859
14	.8097	1.2146	1.2346	.7373	.9259	.9088	.6516
15	.8907	1.1797	1.2174	.8916	1.1145	.8745	.7455
16			1.3717				.7455
17		1.1317	1.3279	.9015		.9088	.823
18	1.0229	.463	.9088	1.0056		1.1584	.9431
19	1.2689	.5658	.6344	1.166	1.046	1.2308	1.166
20	1.3717	.7373	1.0631	1.0867	1.0288	1.1765	1.2689
21	1.262	.823	1.0288	1.0517	.9774	1.1523	1.2174
22	1.1919	.8402	.9945	.9816	.8402	1.0608	1.0802
23	.9816	.8745	.9602	.8669	.8402	.9431	.9259
24	.7545	.8916	.9088	.9259		.7716	.6687
Max	1.7833	1.6991	1.3717	1.6632	1.1145	1.6632	1.4632
Min	.7545	.1698	.6344	.6344	.8402	.5658	.6516
Avg	1.0753	1.0319	1.0198	1.0189	.9581	1.0557	.9819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 203 / 11KV AGRAWAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.168	.1715	.1543	.2241	.1543	.1543
2	.12	.1698	.1715	.1543	.2075	.1543	.1715
3	.1372		.1886	.1372	.2075	.1715	.1543
4	.1715	.1494	.2229	.1372	.2075	.1715	.1543
5	.1886	.1698	.2401	.1715	.2075	.1715	.1715
6	.1715	.168	.2572	.2058	.2075	.1715	.1715
7	.1715	.1867	.2743	.2401	.2075	.1886	.1886
8	.1543	.168	.2572	.2401	.2054	.1715	.1886
9		.1715	.2427	.2572		.1543	.1867
10	.2058	.1886	.2427	.1886	.1715	.1372	.2241
11	.1715	.1886	.2427	.1886	.2058	.1543	.2241
12	.1543	.2058	.2452	.0154	.2401	.1543	.2241
13	.1715	.1886	.2263	.1715	.2229	.1543	.2075
14	.1715	.2058	.2427	.1886	.2058	.1543	.1867
15	.1543	.1886	.2452	.1886	.1886	.1372	.2241
16		.1886	.2614	.2058	.7202		.2054
17		.2058	.2401	.2241	.1886	.1715	.1715
18	.2054	.2572	.2229	.2058	.1715	.1715	.1715
19	.2241	.2572	.2058	.2427	.1715	.1543	.1543
20	.2241	.2401	.2058	.2452	.1886		.1372
21	.2054	.2229	.1886	.2263	.1886	.1543	.1372
22	.2054	.2229	.1715	.2452		.1372	.1372
23	.1886	.2058	.1886	.2452	.1372	.1715	.1372
24	.12	.2075	.1886	.1715	.2263	.1543	.1715
Max	.2241	.2572	.2743	.2572	.7202	.1886	.2241
Min	.12	.1494	.1715	.0154	.1372	.1372	.1372
Avg	.1732	.1967	.2227	.1938	.2228	.1598	.1773

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 204 / PANAN MAHASANGH NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.0171	.0171	.0173	.0171	.0171
2	.0171	.0171	.0171	.0171	.0175	.0171	.0171
3	.0171	.0173	.0171	.0171	.0171	.0171	.0171
4	.0171	.0173	.0171	.0171	.0171	.0171	.0171
5	.0171	.0173	.0171	.0171	.0175	.0171	.0171
6	.0171	.0173	.0171	.0171	.0173	.0171	.0171
7	.0171	.0175	.0171	.0171	.0175	.0171	.0171
8	.0171	.0171	1.2174	.0171	.0171	.0171	.0171
9		.0171	.0171	.0171			.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	.0171	.0171	.0171	.0171	.0171	.0171	.0171
12	.0171	.0171	.0171	.0171	.0171	.0171	.0171
13	.0171	.0171	.0171	.0171	.0171	.0171	.0171
14	.0171	.0171	.0171	.0171	.0171	.0171	.0171
15	.0171	.0171	.0171	.0171	.0171	.0171	.0173
16		.0171	.0171	.0171			.0173
17		.0171	.0171	.0171	.0171	.0171	.0171
18	.0173	.0171	.0171	.0171	.9431	.0171	.0171
19	.0173	.0171	.0171	.0171	.0171		.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0175	.0171	.0171	.0173	.0171	.0171	.0171
22	.0175	.0171	.0171	.0175	.0171	.0171	.0171
23	.0177	.0171	.0171	.0171		.1543	.0171
24	.0171	.0171	.0171	.0171	.0175	.0171	.0171
Max	.0177	.0175	1.2174	.0175	.9431	.1543	.0173
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0172	.0172	.0671	.0171	.0613	.0236	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154076 / 33/11 KV MANJARA KARKHANA

Feeder No / Name : 205 / 11KV KARKHANA SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	25-AUG-17
HR	Load (MW)
13	.0154
Max	.0154
Min	.0154
Avg	.0154

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 201 / 11KV BHATANGALI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1063			.0762
2			.1063			.0762
3			.1097			.0762
4			.1115			.0583
5			.1115			.0838
6			.1149			.0869
7			.1669			.0914
8	.1543	.1875	.2286	.216	.1658	.1257
9	.1829			.2315		
10	.0373			.0229		
11	.0373			.0221		
12	.037			.0229		
13	.0373			.0225		
14	.0373			.0232		
15	.0377			.0229		
16	.0377	.0282		.0229		
17		.0312			.032	
18		.0282			.0316	
19		.032			.0328	
20		.032			.0328	
21		.032			.0328	
22		.032			.0328	
23		.0324			.0328	
24	.0903	.128	.1029	.1235	.116	.0716
Max	.1829	.1875	.2286	.2315	.1658	.1257
Min	.037	.0282	.1029	.0221	.0316	.0583
Avg	.0689	.0564	.1287	.0730	.0566	.0829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 202 / 11KV CHIKHALTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0118			.0116	.0166
9				.0116	
10	.1107			.1219	
11	.1492			.125	
12	.1658			.1235	
13	.1457			.1265	
14	.1475			.1219	
15	.1677			.0914	
16	.1619	.1635	.1696	.0926	
17		.1505			.1174
24	.0118			.0116	
Max	.1677	.1635	.1696	.1265	.1174
Min	.0118	.1505	.1696	.0116	.0166
Avg	.1191	.157	.1696	.0838	.067

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154094 / 33/11 KV BHATANGALI

Feeder No / Name : 203 / 11KV BAMNI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.061			.0629
2			.0591			.0503
3			.0709			.0511
4			.093			.0638
5	.0937		.1143			.108
6			.1486			.1486
7			.1257			.1349
8	.1875	.1677	.1257	.1417	.1989	.1257
9	.1829			.1395		
10	.1187			.1158		
11	.1417			.1204		
12	.1433			.1372		
13	.1402			.1372		
14	.1147			.1355		
15	.1187			.1524		
16	.1227	.1265	.0236	.1429	.0781	
17		.1134			.108	
18		.0533			.0629	
19		.0814			.0899	
20		.0914			.0686	
21		.0686			.072	
22		.0591			.0572	
23		.0619			.0619	
24	.0047	.08	.061	.0827	.0829	.0629
Max	.1875	.1677	.1486	.1524	.1989	.1486
Min	.0047	.0533	.0236	.0827	.0572	.0503
Avg	.1244	.0903	.0883	.1305	.0880	.0898

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 201 / 11KV water supply feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.2012	
7					.2743	
8		.2926			.2378	
9	.2012		.3658			.1829
10		.3734			.3189	
11			.4755			
12		.4854			.4572	
14		.3475				
16			.567			.567
17				.3292		
18			.3189			
19	.2926					
20			.2835			
22				.2012		
23	.2195					
24		.2378			.2012	
Max	.2926	.4854	.567	.3292	.4572	.567
Min	.2012	.2378	.2835	.2012	.2012	.1829
Avg	.2378	.3473	.4021	.2652	.2818	.3750

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 202 / 11KV AIRPORT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.6584	
7					.8145	
8		.8688			.905	
9	.7164		.905			.9145
10		.6733			.7291	
11			.6154			
12		.5487			.5487	
14		.39				
16			.6878			.6036
17				.5611		
18			.6024			
19	.7059					
20			.7442			
22				.4887		
24		.3982			.5068	
Max	.7164	.8688	.905	.5611	.905	.9145
Min	.7059	.39	.6024	.4887	.5068	.6036
Avg	.7112	.5758	.7110	.5249	.6938	.7591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 203 / 11KV Goodwill feeder
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.2829	
7					.1509	
8					.1509	
9	.1905		.1886			.1509
10		.5335			.2987	
11			.4904			
12					.407	
14		.3361				
16			.4904			.4527
17				.2263		
18			.3734			
19	.2641					
20			.1696			
22				.1132		
23	.1509					
24		.1886			.1509	
Max	.2641	.5335	.4904	.2263	.407	.4527
Min	.1509	.1886	.1696	.1132	.1509	.1509
Avg	.2018	.3527	.3425	.1698	.2402	.3018

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 204 / SHANKARSHETH POLYMERS NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO
 STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.0171	
7					.0171	
8		.0171			.0171	
9	.0328		.0171			.0514
10		.0848			.0671	
11			.0171			
12		.0339			.0509	
14		.0335				
16		.0678	.0171			.0857
17				.0171		
18			.0509			
19	.0171					
20			.0503			
22				.0171		
23	.0171					
24		.0171			.0171	
Max	.0328	.0848	.0509	.0171	.0671	.0857
Min	.0171	.0171	.0171	.0171	.0171	.0514
Avg	.0223	.0424	.0305	.0171	.0311	.0686

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 205 / KANHAIYA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.0914	
7					.1097	
8					.1097	
9	.1097		.1829			.1097
10		.362			.4191	
11			.2195			
12		.4382			.3544	
14		.1907				
16			.2378			.2561
17				.1463		
18			.3109			
19	.3109					
20			.1341			
22				.1463		
23	.1646					
24		.2195			.128	
Max	.3109	.4382	.3109	.1463	.4191	.2561
Min	.1097	.1907	.1341	.1463	.0914	.1097
Avg	.1951	.3026	.2170	.1463	.2021	.1829

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 206 / Gajraj

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.8215	
7					.8402	
8		.8589			.8775	
9	.8029		.8029			
10		.8779			.823	
11			.8029			
12		.8779			.763	
14		.7973				
16		.815	.7282			.8215
17				.8589		
18			.8779			
19	.9149					
20			.7122			
22				.9149		
23	.8402					
24		.9149			.3206	
Max	.9149	.9149	.8779	.9149	.8775	.8215
Min	.8029	.7973	.7122	.8589	.3206	.8215
Avg	.8527	.8570	.7848	.8869	.7410	.8215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 207 / 11 KV Dhoot feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.1886	
7					.1886	
8					.2229	
9	.2035		.2743			
10		.362			.2012	
11			.3601			
12		.3658			.3658	
14		.3544				
16			.3601			.1886
17				.2743		
18			.4572			
19	.3429					
20			.39			
22				.2229		
23	.2743					
24		.3601			.1715	
Max	.3429	.3658	.4572	.2743	.3658	.1886
Min	.2035	.3544	.2743	.2229	.1715	.1886
Avg	.2736	.3606	.3683	.2486	.2231	.1886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154095 / 33/11 KV ADD MIDC

Feeder No / Name : 208 / 11 KV Kalantri feeder SHEDDABLE FEEDER HAVING WEEKLY
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					1.3203	
7					1.3769	
8					1.2637	
9	1.4289		1.5655			1.3014
10		1.5623			1.2193	
11			1.1694			
12		1.7528			1.0749	
14		.9745				
16			1.5844			1.2449
17				1.5278		
18			1.6766			
19	1.6032					
20			1.6194			
22				1.2826		
23	.9054					
24		1.2826			1.1317	
Max	1.6032	1.7528	1.6766	1.5278	1.3769	1.3014
Min	.9054	.9745	1.1694	1.2826	1.0749	1.2449
Avg	1.3125	1.3931	1.5231	1.4052	1.2311	1.2732

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 201 / 11KV GANJUR SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1015		.1724	.1471
9		.1297	.1218	
10		.1708		
11	.1423		.1154	
12		.223		.0784
13		.2356	.1297	.0775
14		.2293		.0427
15				.0553
18			.1168	
Max	.1423	.2356	.1724	.1471
Min	.1015	.1297	.1154	.0427
Avg	.1219	.1977	.1312	.0802

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 202 / 11KV WAKDI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1186		.1344	.049
9			.136	
11	.0569		.0648	
12	.0506	.068		.0459
13		.0553	.0506	.0712
14		.0474		.0759
15				.0775
18			.0553	
23			.0617	
Max	.1186	.068	.136	.0775
Min	.0506	.0474	.0506	.0459
Avg	.0754	.0569	.0838	.0639

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (R) S/D[420] BU 5126

Substation No/ Name :- 154121 / Ganjur Substation

Feeder No / Name : 203 / 11 KV TADKI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0553		.0727	.0332
9			.0822	
11			.0221	
12		.0364		.019
13			.0158	.0285
14		.0506		.0206
15				.0206
18			.03	
23			.0237	
Max	.0553	.0506	.0822	.0332
Min	.0553	.0364	.0158	.019
Avg	.0553	.0435	.0411	.0244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 201 / 11KV MEDICAL COLLEGE
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1457	.1406	.16	.1526	.1638	.1638	.1387
2	.1406	.1423	.1389	.1509	.1457	.1457	.1372
3	.1355	.144	.1389	.1341	.1457	.128	.1187
4	.1235	.125	.1389	.1326	.1457	.144	.1187
5	.128	.1423	.1389	.1311	.1457	.144	.1187
6	.1423	.1326	.16	.1311	.1492	.16	.1509
7	.1907	.1715	.1581	.1265	.1949	.144	.1433
8	.1677	.1928	.1928	.1526	.1991	.1638	.1254
9	.2126	.2353	.2402	.1677	.2195	.1677	.2149
10	.2614	.2353	.2987	.197	.2218	.1715	.2481
11	.2587	.2534	.2987	.1753	.2149	.1772	.2149
12	.2378	.2534	.2772	.1677	.2172	.1595	.2172
13	.1772	.2172	.2926	.1753	.2172	.1753	.2149
14	.1734	.181	.2149	.1658	.197	.1791	.1448
15	.1734	.1753	.2126	.1492	.1658	.1595	.1417
16	.1734	.1772	.2126	.1475	.1734	.1433	.1612
17	.1844	.2103	.1907	.1526	.144	.1463	.1402
18	.1677	.1844	.1907	.1715	.1543	.1463	.1629
19	.1823	.208	.1907	.2058	.1844	.1612	.1612
20	.1802	.1865	.1865	.2058	.1696	.1734	.1595
21	.1802	.2012	.208	.1715	.1696	.1715	.1578
22	.1865	.2035	.1907	.1865	.1844	.1886	.1595
23	.1658	.1844	.1715	.1989	.1658	.1526	.1595
24	.16	.16	.1802	.1715	.1658		.1417
Max	.2614	.2534	.2987	.2058	.2218	.1886	.2481
Min	.1235	.125	.1389	.1265	.144	.128	.1187
Avg	.1770	.1857	.1993	.1634	.1773	.1594	.1605

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 202 / 11KV MARKET YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.9054	1.0374	.9431	.8865	.9808	.9054
2	.7545	.9054	.9997	.9054	.8676	.8865	.9054
3	.7545	.8865	.9054	.9054	.8676	.8488	.8676
4	.7545	.8865	.9054	.9431	.8676	.8676	.8676
5	.8299	.9054	.9997	.9808	.8676	.8676	.9808
6	1.0185	1.0185	1.1694	1.0374	1.0185	.9808	1.0374
7	1.1317	.9997	1.2637		1.1506	1.0374	1.1694
8	1.0456	.8865	1.1203	1.2449	1.0456	1.0829	1.0456
9	.9709	.8962	.9979	1.1643	1.0719	1.0903	1.0903
10	.8779	.8589	1.0242	1.1157	1.0059	1.0456	1.1016
11	.8779		1.0679	1.0059	1.0136	1.1088	1.1827
12	.9145	1.0534	1.0242	.9774	.9774	.9877	1.0349
13	.8326	1.0349	.9979	.9231	.9774	.9145	.9511
14	.8326	1.0349	.9979	1.0242	.8779	.9795	.7602
15	.8507	.9694	1.0164	1.0608	.8501	1.0059	.9055
16	.7783	1.0059	1.0719	1.0349	1.0164	.9979	1.0242
17	.9795	1.134	1.0534	.961	.9511	.9425	1.0791
18	1.0242	1.1523	1.2382	1.1643	1.0059	.8596	1.2127
19	1.386	1.46	1.4784	1.1949	1.4003	1.2936	1.5912
20	1.3817	1.5497	1.4937	1.3443	1.3817	1.2012	1.4784
21	1.2883	1.3817	1.419	1.1763	1.2323	1.2136	1.3256
22	1.2136	1.3014	1.3443	1.1317	1.2323	1.1203	1.2449
23	1.0374	1.1317	1.2637	1.0185	1.094	1.0082	1.1883
24	.811	.9431	1.0562	.8865	.9431	.9997	.9431
Max	1.386	1.5497	1.4937	1.3443	1.4003	1.2936	1.5912
Min	.7545	.8589	.9054	.8865	.8501	.8488	.7602
Avg	.9641	1.0566	1.1228	1.0497	1.0251	1.0134	1.0789

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

LATUR (U) S/D(SOUTH)[640] BU 4640

Substation No/ Name :- 154113 / MEDICAL COLLEGE

Feeder No / Name : 203 / 11KV KANHERI ROAD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5658	.6413	.6602	.5093	.6413	.6224
2	.5525	.5658	.5847	.6413	.4904	.5847	.6036
3	.547	.547	.5658	.6224	.4904	.5658	.5847
4	.5658	.547	.5658	.6224	.4904	.547	.5847
5	.6097	.5658	.5847	.7167	.547	.547	.6413
6	.743	.6979	.679	.7922	.6036	.6413	.7167
7	.7545	.7922	.811		.679	.7733	.7922
8	.7356	.7167	.7545	.811	.7167	.7545	.7922
9	.6722	.6979	.7167	.7167	.7167	.6908	.7468
10	.6348	.7095	.7762	.7762	.7095	.7095	.7392
11	.6653	.7682	.6653	.7392	.7316	.8402	.7947
12	.7762	.724	.6838	.7095	.7682	.811	.7733
13	.7316	.6516	.7095	.6535	.7133	.7316	.7282
14	.7316	.6335	.7356	.6161	.6283	.6535	.6036
15	.7133	.6468	.7095	.6535	.7392	.7356	.7095
16	.6767	.7392	.7655	.6979	.6838	.7468	.7468
17	.7421	.7947	.7947	.6722	.8048	.7865	.695
18	.8059	.7865	.8871	.8029	.8779	.8413	.8507
19	1.0059	.9795	.9795	.8215	.9795	.924	1.0534
20	.9335	.9896	.9896	.8962	1.0269	.9425	.9709
21	.8676	.9242	.9522	.7842	.8775	.8775	.8676
22	.7811	.8488	.9242	.7545	.811		.7356
23	.6478	.7621	.811	.6859	.7049	.7167	.6602
24	.5906	.5658	.6224	.7167	.5658	.6602	.6602
Max	1.0059	.9896	.9896	.8962	1.0269	.9425	1.0534
Min	.547	.547	.5658	.6161	.4904	.547	.5847
Avg	.7107	.7175	.7462	.7201	.7027	.7271	.7364

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 201 / 11 KV MURUD URBAN FEEDER GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					1.6817	
7		2.0144				
15				1.1104		
16				1.1584		1.0117
17	1.1827	1.2936	1.2567			
18		1.2012				
20	1.8296	1.7372				
21	1.6078	1.5708				
24		1.0719				
Max	1.8296	2.0144	1.2567	1.1584	1.6817	1.0117
Min	1.1827	1.0719	1.2567	1.1104	1.6817	1.0117
Avg	1.5400	1.4815	1.2567	1.1344	1.6817	1.0117

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 202 / 11 KV MURUD RURAL FEEDER FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	24-AUG-17
HR	Load (MW)
24	.1478
Max	.1478
Min	.1478
Avg	.1478

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 203 / 11 KV DHORALA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12				.3048
15				.2743
16				.2743
17	.439	.5601	.4115	
Max	.439	.5601	.4115	.3048
Min	.439	.5601	.4115	.2743
Avg	.439	.5601	.4115	.2845

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 204 / 11 KV Gumphwadi FEEDER GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6					.1294
7		.1254			
12				.1715	
15				.1029	
16				.1029	
17	.0724	.1463	.2427		
18		.1463			
20	.128	.1463			
21	.128	.1463			
24		.1294			
Max	.128	.1463	.2427	.1715	.1294
Min	.0724	.1254	.2427	.1029	.1294
Avg	.1095	.14	.2427	.1258	.1294

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 205 / 11 KV WATAWADA FEEDER
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)
16		.3963
24	.5249	
Max	.5249	.3963
Min	.5249	.3963
Avg	.5249	.3963

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 206 / 11 KV KARKATTA

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.2587		
12				.1029
15				.0857
16				.1029
17	.1109	.0886	.1052	
20	.2402	.2353		
21	.2195	.2427		
24		.0905		
Max	.2402	.2587	.1052	.1029
Min	.1109	.0886	.1052	.0857
Avg	.1902	.1832	.1052	.0972

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 207 / 11 KV KARKATTA-AG-FEEDER SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.1109		
12				.4877
15				.5487
16				.4877
17	.6584	.9795	.5304	
18		.0934		
20	.0924	.1109		
21	.0924	.0914		
24		.0924		
Max	.6584	.9795	.5304	.5487
Min	.0924	.0914	.5304	.4877
Avg	.2811	.2464	.5304	.5080

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 208 / 11 KV GUMPHAWADI -AG-

FEEDER Feeder KV- 11 /

OUTGOING

FEEDER SEPERATION/PURE AG

DATE	24-AUG-17
HR	Load (MW)
24	.1663
Max	.1663
Min	.1663
Avg	.1663

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154001 / 33/11 KV MURUD

Feeder No / Name : 209 / 11 KV HOSPITAL (SEPERATE) NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO
 STAGGERING)

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7		.0181		
12				.0171
15				.0171
16				.0171
17	.0183	.0181	.0187	
20	.0187			
21	.0187	.0185		
24		.0181		
Max	.0187	.0185	.0187	.0171
Min	.0183	.0181	.0187	.0171
Avg	.0186	.0182	.0187	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 201 / 11 KV MURUD AKOLA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4641	.4801		.4458	
2		.4641	.4801		.4458	
3		.4973	.5144			
4		.5304	.823		.5144	
5		.7956	.9326		.6443	
6		.9282	.9835		.7545	
7		.8619	1.0513		.9724	.7969
8		.7956	.8478		.8478	
9	.7922	.6554	.6706	.6173	.6706	.8029
10		.6882	.6036	.6859	.6859	.6602
11		.9282	.8848	.6859		
12		.4144	1.0814	.78		
13	.763	.9116	1.2125	.78		.3395
14		.8192	1.2125	.763	.8215	
15	.763	.8951	1.2452	.763		
16		.9116	1.3108	.7969	.8718	.4715
17	.852	.9054	1.2742	.823		
18	.5243	.4458		.4801	.5658	
19	.7209			.6001		
20	.7625	.6859		.6859		
21	.663	.6516			.6602	
22	.5304	.6001				
23	.4641	.5487		.5144		
24		.4641	.4801		.4801	
Max	.852	.9282	1.3108	.823	.9724	.8029
Min	.4641	.4144	.4801	.4801	.4458	.3395
Avg	.6835	.6897	.8938	.6904	.6701	.6142

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 202 / 11 KV BHOYRA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.1886		.1886	
2		.2286	.1715			
3		.2286	.1715			
4		.3048	.2058		.2058	
5		.3429	.2572			
6		.381	.2743		.2743	
7		.381	.3086		.3429	.3391
8		.3429	.2572		.2743	
9	.2263	.2286	.2058	.2058	.2058	.3052
10		.2667	.2515	.2058	.1715	.2075
11		.2652	.2667	.2058		
12		.3315	.3048	.2401		
13	.3052	.3315	.2286	.2572		.0754
14		.3018	.3048	.2743	.285	
15	.3391		.381	.2743		
16		.3018	.4572	.2572	.2683	.132
17	.4191	.3429	.3688	.2743		
18	.2286	.1372		.2058	.1886	
19	.2667			.2401		
20	.3429	.2743		.2572		
21	.3048	.2572			.2829	
22	.2286					
23	.2286	.2401		.2058		
24			.1886		.1886	
Max	.4191	.381	.4572	.2743	.3429	.3391
Min	.2263	.1372	.1715	.2058	.1715	.0754
Avg	.2890	.2859	.2663	.2387	.2397	.2118

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154005 / 33/11 KV MURUD-AKOLA

Feeder No / Name : 203 / 11 KV RAMEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0903	.1372		.1372	
2		.0903	.1372		.1372	
3		.0903	.1372		.1372	
4		.1204	.1696			
5		.1204	.1677		.1715	
6		.0903	.2012			
7		.1054	.2347		.1677	
8		.1204	.2515		.1677	
9	.1715	.1505	.2374	.2401	.1677	
10						.12
13						.1715
16						.1372
24		.0903	.1372		.1029	
Max	.1715	.1505	.2515	.2401	.1715	.1715
Min	.1715	.0903	.1372	.2401	.1029	.12
Avg	.1715	.1069	.1811	.2401	.1486	.1429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 201 / 11 KV GADWAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582		.2686	.3582	.362	.362	.7164
2	.3582		.3582	.3582	.3582	.362	.8859
3	.3582		.3582	.3582	.362	.4477	.8764
4	.3582		.3582	.4477	.4525	.4477	.8764
5	.4477		.4477	.4477	.4525	.4477	1.0517
6	.4477		.4477	.4477	.4525	.4525	1.0517
7	.4477		.4477	.3582	.4525	.4525	1.0517
8			.4477	.3582	.4525	.543	1.0517
9			.4477	.3582	.4525	.5373	1.0517
10			.4477	.543		.6268	.362
11			1.4327	1.4022		.7164	.362
12			1.4327	1.4022		.8954	.362
13			1.4327	1.4899		1.0745	.362
14			1.4327	1.4022		1.0745	.362
15			1.6118			.8954	.362
16	1.387		1.6118	.724		1.0745	.362
17	1.387		1.6118	1.4327		1.0745	.362
18	.3582		.3582	.4477			.4525
19			.3582	.543			.543
20			.3582	.543			
21	.362		.3582	.4525			.543
22	.362		.3582	.362			.4525
23	.362		.3582	.362			.362
24	.3582	.362	.2686	.3582	.362	.362	.543
Max	1.387	.362	1.6118	1.4899	.4525	1.0745	1.0517
Min	.3582	.362	.2686	.3582	.3582	.362	.362
Avg	.5252	.362	.7089	.6503	.4159	.6581	.6263

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 202 / 11 KV JAWALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16		.16	.16	.1619	.1619	.081
2	.16		.16	.16	.1619	.16	.081
3	.16		.16	.16	.1619	.16	.081
4	.16		.16	.16	.2401	.1619	.081
5	.16		.16	.16	.3201	.1619	.081
6	.2401		.16	.3201	.3201	.1619	.081
7	.3201		.16	.3201	.3201	.1619	.081
8			.16	.3201	.3201	.1619	.081
9			.3201	.16	.2401	.16	
10				.081	.081	.08	.081
11				.081		.08	.081
12			.08	.081		.08	.08
13			.08	.081		.08	.16
14			.08				.16
15			.08			.08	.16
16	.081		.08			.08	
17	.081		.08			.08	
18	.081		.08				
19			.08				.081
20			.08	.081			.081
21	.081		.08	.081			.081
22	.081		.08				.081
23	.081		.08	.081			.081
24	.08	.081	.08	.08	.081	.081	.081
Max	.3201	.081	.3201	.3201	.3201	.1619	.16
Min	.08	.081	.08	.08	.081	.08	.08
Avg	.1376	.081	.1200	.1510	.2189	.1231	.0928

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 203 / 11 KV MASLA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16		.16	.16	.1619	.1619	.1619
2	.16		.16	.16	.1619	.1619	.1619
3	.16		.16	.16	.1619	.1619	.16
4	.2401		.16	.16	.1619	.1619	.3201
5	.2401		.16	.16	.2429	.1619	.4801
6	.3201		.16	.16	.3239	.2401	.4801
7	.3201		.16	.16	.3239	.2401	.4801
8			.16	.16	.3239	.3201	.4744
9			.3201	.16	.3239	.3201	.4744
10			.16	.3201		.2401	.16
11			.3201	.7907		.4801	.1619
12			.4801	.8592		.4801	.1619
13			.6401	.8697		.4801	.1619
14			.6401	.8802		.4801	.1619
15			.8002			.4801	
16	.6249		.9602	.9488		.4801	
17	.724		.9602	.9374		.4801	
18	.1619		.16				.1619
19			.16				.2429
20			.16	.1619			
21	.1619		.16	.1619			.2429
22	.1619		.16	.1619			.1619
23	.1619		.16	.1619			.1619
24	.16	.1619	.16	.16	.1619	.1619	.1619
Max	.724	.1619	.9602	.9488	.3239	.4801	.4801
Min	.16	.1619	.16	.16	.1619	.1619	.16
Avg	.2684	.1619	.3200	.3740	.2348	.3163	.2567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154017 / 33/11 KV GADWAD S/S

Feeder No / Name : 204 / 11 KV WANJARKHEDA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3201		.3201	.3201	.2429	.2429	.2429
2	.3201		.3201	.4801	.2429	.2429	.2401
3	.3201		.3201	.4801	.3201	.2429	.2401
4	.3201		.3201	.6401	.3239	.2429	.2401
5	.3201		.4001	.8002	.4001	.2429	.3201
6	.3201		.4801	.8002	.4001	.2401	.3201
7	.3201		.4801	.9602	.4001	.2401	.3201
8			.6401	.8002	.4001	.3201	.3201
9			.6401	.8002	.4001	.3201	
10				.1619	.1619	.16	.3201
11				.1619		.16	.1619
12			.16	.1619		.16	.1619
13			.16	.1619		.16	.2429
14			.16				.2429
15			.16			.16	.2429
16	.1619		.16			.16	
17	.1619		.16			.16	
18	.1619		.16				
19			.2401				.1619
20			.2401	.1619			.1619
21	.2429		.2401	.1619			.2429
22	.2429		.2401	.2429			.2429
23	.2429		.16	.2429			.2429
24	.3201	.3201	.2401	.2401	.2429	.2429	.2429
Max	.3201	.3201	.6401	.9602	.4001	.3201	.3201
Min	.1619	.3201	.16	.1619	.1619	.16	.1619
Avg	.2697	.3201	.2910	.4322	.3214	.2175	.2456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 206 / 11 kV Ekurga new SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4						.4858	
5				1.0242			
6				1.1523			
7			1.3108	1.2483			.5921
8		1.0402	1.2631	1.2003	.9878	1.012	.6287
9				1.1363			.5144
10							.6964
11					.2915	.2241	.7611
12							.7202
13							.7362
14							.7611
15							.7293
16			.192		.1433	.2721	
17						.3163	
18	.2477						
20					.506		
23		.3647			.2881		
24		.6478		.4001	.6299		.2561
Max	.2477	1.0402	1.3108	1.2483	.9878	1.012	.7611
Min	.2477	.3647	.192	.4001	.1433	.2241	.2561
Avg	.2477	.6842	.9220	1.0269	.4744	.4621	.6396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154028 / 33 KV S/S BOPLA

Feeder No / Name : 207 / 11 KV MBF New

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0373	
4			.0377			
5			.0377			
6			.0377			
7		.0362	.0377			.0377
8	.0381	.0366		.0381	.0373	.0381
9						.0381
10						.0381
11				.0366	.0377	.0572
12						.0572
13						.0572
14						.0762
15						.0762
16		.0377		.0366	.0377	
17					.0377	
18	.0377					
20				.0373		
23	.0373					
24	.0381		.0377	.0381		.0377
Max	.0381	.0377	.0377	.0381	.0377	.0762
Min	.0373	.0362	.0377	.0366	.0373	.0377
Avg	.0378	.0368	.0377	.0373	.0375	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 201 / 11 KV Shirala Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7575	.6882	.4999	.4572	.4537	.3001	.4915
2	.8059	.6882	.4813	.4572	.4537	.3296	.4915
3	.8059	.6882	.5219	.4572	.4705	.3668	.4096
4	.8381	.7209	.5635	.5182	.5377	.4186	.4588
5	.8704	.7865	.6313	.6097	.6722	.5133	.4915
6	.8865	.8097	.7808	.7316	.7226	.6168	.6478
7	.9187	.8745	1.0764	.8078	.9242	.8021	.7449
8	.8865	.9175	.9739	.7773	.8402	.77	.9282
9	.8543		1.0502		.6134	.2429	.4115
10	.2401			.548	.3534	.3201	.5182
11	.3772	.401		.4191	.3458	.3681	.503
12	.3429	.3144		.2579	.299	.3277	.503
13	.3429	.2545		.2257	.2413		.4877
14	.3391	.2472	.2896	.2095	.2358	.3563	.4877
15	.3688	.3669	.2896	.2185	.2406	.3605	.5182
16	.3932	.2802	.2743	.2185	.3048	.3605	.5182
17	.4239	.2802	.2743	.3361	.2898	.4049	.4572
18	.6554	.385	.3353	.5041		.5668	.5487
19	.8192	.6592	.6097	.8066	.6427	.7773	.6249
20	.9831	.8502	.5792	.7898	.6668	.7287	.6706
21	.9012	.6396	.5487	.7898	.5937	.6964	.6554
22	.663	.599	.5335	.6049	.5815	.5898	.5792
23	.5801	.5815	.503	.5041	.4935	.5079	.4877
24	.7575	.6554	.4995	.4268	.4537	.5641	.4915
Max	.9831	.9175	1.0764	.8078	.9242	.8021	.9282
Min	.2401	.2472	.2743	.2095	.2358	.2429	.4096
Avg	.6588	.5767	.5658	.5076	.4970	.4908	.5469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 202 / 11 KV Chincholi B Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0311	.0686	.0668	.0762	.1196	.0729	.0343
2	.0311	.1029	.0642	.0762	.1047	.0718	.0343
3	.0466	.1029	.0644	.0762	.1047	.088	.6173
4	.0466	.1372	.0667	.0762	.1047	.09	.0343
5	.0621	.1372	.0665	.0914	.1047	.1077	.0343
6	.0932	.1715	.0644	.1067	.1047	.1154	.0343
7	.0932	.1715	.1299	.1219	.1196	.2252	.0343
8	.0933	.1753	.1349	.1981	.1196	.2252	.0343
9	.0934	.1715	.1978	.249	.1299		.0343
10	.0354	.0662		.0311	.0333	.0339	.1067
11	.0354	.0331		.0311	.0322	.0343	.1524
12	.0366	.0342		.0311	.0287	.0343	.1677
13	.0339	.0331	.0305	.0311	.0283	.0343	.1829
14	.0366	.0341	.0305	.0311	.0322	.0343	.1829
15	.0362	.033	.0305	.0299	.0363	.0343	.1829
16	.0362	.0325	.0305	.0299	.0322	.0857	.1981
17	.0362		.0305	.0299	.0376	.0343	.1981
18	.0358	.0379	.0305	.0299	.0341	.0343	.0457
19		.0379	.0305	.0299	.0289	.0343	.0457
20	.0354	.0379	.0305	.0299	.0338	.0343	.0457
21	.0354	.0375	.0457	.0299	.0322	.0343	.0305
22	.0354	.0321	.0305	.0321	.033		.0305
23	.0358	.0363	.0305	.0299	.0341	.0343	.0305
24	.0311	.0686	.0735	.0762	.1196	.0678	.0343
Max	.0934	.1753	.1978	.249	.1299	.2252	.6173
Min	.0311	.0321	.0305	.0299	.0283	.0339	.0305
Avg	.0472	.0780	.0609	.0656	.0662	.0710	.1053

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 203 / 11 KV Wadiwagholi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1303	.1402	.1669	.1372	.0806	.161	.4191
2	.1631	.1402	.1631	.1372	.1289	.2	
3	.1957	.2103	.1667	.1372	.1289	.2	.4191
4	.2609	.2454	.2085	.1829	.1612	.212	.5571
5	.3588	.3155	.3001	.2439	.2257	.2839	.6226
6	.4566	.4161	.401	.2743	.2579	.3837	.7209
7	.4893	.4801	.3439	.2743	.2257	.3579	.7865
8	.4566	.4115	.3425	.1067	.2257	.299	.9069
9	.3588	.3429	.2966	.1142	.1886		.9282
10	.4915	.5731		.8154	.7476	.3429	.2439
11	.9069	1.0588			.8021	.6478	.1067
12	1.0288				.9169	.9717	.0914
13	1.0513		.7773	1.109	.8482	1.004	.0762
14	1.0974			1.1742	.8232	1.0242	.1067
15	1.0288	.8642	.884		.9064	1.0562	.1219
16	.9945	.8195		1.096	.9064	1.0883	.1219
17	1.0974	.795		1.1927	.6786	1.1385	.1219
18	.1715	.1242		.1128	.1496	.2683	.2286
19	.2058	.2922		.1289	.3642	.2515	.2439
20	.1715	.3626		.1289	.2888	.1989	.1981
21	.1543	.2415	.2439	.0967	.2167	.2035	.1677
22	.1372	.1414	.1372	.0806	.1667	.1715	.1372
23	.1372	.1283	.1067	.0806	.1536	.1372	.1219
24	.1305	.1417	.1444	.1219	.0806	.1615	.3353
Max	1.0974	1.0588	.884	1.1927	.9169	1.1385	.9282
Min	.1303	.1242	.1067	.0806	.0806	.1372	.0762
Avg	.4864	.3926	.3122	.3688	.4030	.4680	.3384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	23-AUG-17
HR	Load (MW)
14	.1521
Max	.1521
Min	.1521
Avg	.1521

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154045 / 33/11 KV SHIRALA S/S

Feeder No / Name : 205 / 11kv AADI AGRO Exp Fed NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0713	.0686	.1234	.0914	.107	.0897	.1063
2	.0711	.0686	.0997	.0762	.107	.0897	.1063
3	.0713	.0686	.1077	.0762	.107	.0878	.0886
4	.0713	.0686	.1077	.0762	.107	.0897	.0886
5	.0892	.0857	.1234	.0914	.107	.0897	.0876
6	.0892	.0857	.1163	.1067	.107	.0878	.1063
7	.0713	.0857	.1234	.1067	.0892	.1057	.1052
8	.1248	.1052	.0812	.0914	.1251	.0897	.104
9	.1069	.1052	.1234	.107	.1234		.0914
10	.12	.0881		.0892	.1256	.0686	.0762
11	.12	.0907		.0892	.1258	.0686	.0762
12	.12	.0892		.0892	.1052	.12	.1067
13	.12	.1057	.0762	.107	.0881	.12	.0914
14	.1187	.1457	.0914	.1251	.1056	.12	.0762
15	.1052		.1067	.143	.1077	.12	.061
16	.1052		.1219	.143	.1077	.12	.061
17	.1052	.127	.0914	.143	.1061	.12	.061
18	.0914	.0897	.1067	.143	.1077	.12	.061
19	.0905	.1052	.0914	.1251	.0881	.1017	.061
20	.0724	.1227	.0914	.0894	.0802	.1017	.0762
21	.0724	.123	.0914	.1072	.0897	.1029	.0914
22	.0905	.127	.0914	.1072	.0881	.1029	.0914
23	.0905	.1234	.0914	.1072	.0878	.1029	.0914
24	.0713	.0857	.127	.0914	.107	.1056	.1063
Max	.1248	.1457	.127	.143	.1258	.12	.1067
Min	.0711	.0686	.0762	.0762	.0802	.0686	.061
Avg	.0942	.0984	.1040	.1051	.1042	.1011	.0864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 201 / 11 KV Takalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.7545	.7888	.5487		.8916	.7545
9					.3429		
16	.6859	.6859	1.0288	.8573	.6516	.6173	.4458
24	.8916	.4287	.3429	.3429	.4115	.4115	.4458
Max	.8916	.7545	1.0288	.8573	.6516	.8916	.7545
Min	.6859	.4287	.3429	.3429	.3429	.4115	.4458
Avg	.7888	.6230	.7202	.5830	.4687	.6401	.5487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 202 / 11 KV Pimpalgaon Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4973		.823	.7202	.7545	.703	.12
15		.1715					
16	.1029		.0686	.1372	.0857		.5144
17						.1372	
24	.2743	.1029	.2915	.1715	.2058	.2229	.0857
Max	.4973	.1715	.823	.7202	.7545	.703	.5144
Min	.1029	.1029	.0686	.1372	.0857	.1372	.0857
Avg	.2915	.1372	.3944	.3430	.3487	.3544	.2400

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154060 / 33/ 11 KV TANDULJA S/S

Feeder No / Name : 203 / 11 KV Tandulja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0974	1.2003	1.2346	1.3375	1.0288	.4801	
9							.5487
16	.7202	.4115	.3429	.4458		.2743	.8916
17					.3086		
24		.583	.6859	.583	.5487	.3086	.2743
Max	1.0974	1.2003	1.2346	1.3375	1.0288	.4801	.8916
Min	.7202	.4115	.3429	.4458	.3086	.2743	.2743
Avg	.9088	.7316	.7545	.7888	.6287	.3543	.5715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 202 / 11 KV Chikurda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1311	.1457	.1715	.1311	.1475	.1696
2	.1372	.1311	.1296	.1372	.1311	.1475	.2058
3	.1372	.1311	.1311	.1372	.1311	.1311	.2058
4	.1715	.1638	.1475	.1372	.1357	.1311	.2401
5	.2572	.2294	.1638	.1715	.1638	.1966	.2401
6	.3258	.2949	.213	.2572	.2294	.3277	.2572
7	.3601	.3277	.2949	.2743	.1966	.2622	.3429
8	.2572	.2622	.2622	.2915	.1311	.213	.3086
9	.2058	.2294	.2267	.2458	.2294	.2105	
10	.2572	.2949	.4287	.1638	.1966	.2374	.0983
11	.3932	.3932	.4287	.3277	.2949	.2572	.0983
12	.3932	.426	.5144	.3113	.4096	.2572	.0983
13	.3605	.421	.6173		.3932	.2743	.0983
14	.3932	.4049	.6001	.1311	.3277	.2713	.1147
15	.3932	.4424	.583	.4588	.3441	.3429	.1147
16	.426	.4915	.6001	.4588	.3441	.3944	.1311
17	.4588	.1966	.6173	.5243	.2949	.3429	.1311
18	.1147	.1147	.12	.0983	.3441	.1543	.1638
19	.1966	.1966	.2572	.2294	.1966	.2743	.1966
20	.2622	.2458	.2572	.2458	.2294	.2572	.213
21	.2294	.0213	.2058	.213	.2267	.2572	.1966
22	.213	.1966	.1715	.1966	.213	.2058	.1638
23	.1966	.1619	.1715	.1638	.1966	.1715	.1638
24	.1715	.1638	.1619	.1715	.1638	.1802	.1715
Max	.4588	.4915	.6173	.5243	.4096	.3944	.3429
Min	.1147	.0213	.12	.0983	.1311	.1311	.0983
Avg	.2687	.2530	.3104	.2399	.2356	.2352	.1793

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154061 / 33/ 11 KV CHIKURDA S/S

Feeder No / Name : 203 / 11 Kv Samangaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	26-AUG-17
HR	Load (MW)
1	.1543
Max	.1543
Min	.1543
Avg	.1543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 201 / 11 KV Shiur Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0671			
3							.1677
4			.0838				
6				.1006			.3018
7						.1865	
8	.1187	.1187	.1677	.1006	.1187	.1526	.2515
11							.017
12			.0503			.0503	
16			.0503			.0671	.0678
17	.0678			.0509	.0509		.0678
18			.0503			.1341	
20			.2012				
21						.1844	
23	.0848				.0848		
24	.0509	.0848	.0838	.0671	.0678	.0848	.1341
Max	.1187	.1187	.2012	.1006	.1187	.1865	.3018
Min	.0509	.0848	.0503	.0509	.0509	.0503	.017
Avg	.0806	.1018	.0982	.0773	.0806	.1228	.1440

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 202 / 11 KV Utti Tawarja Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0671			
3							.0503
4			.1006				
6				.1006			.0671
7						.1187	
8	.0509	.0848	.2012	.1341	.1187	.1187	.1006
11							.1017
12			.0335			.0335	
16			.0335			.0335	.0509
17	.0339			.0339	.0339		.0678
18			.0335			.0503	
20			.0671				
21						.0503	
23	.0848				.0848		
24	.0509	.0848	.0671	.0671	.0509	.0848	.0503
Max	.0848	.0848	.2012	.1341	.1187	.1187	.1017
Min	.0339	.0848	.0335	.0339	.0339	.0335	.0503
Avg	.0551	.0848	.0766	.0806	.0721	.0700	.0698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 203 / 11 KV SAWARGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1006			
3							.2683
4			.2012				
6				.4527			.3688
7						.7461	
8	.4578	.4578	.503	.503	.6443	.7122	.3353
11							.2374
12			.3353			.3018	
16			.503			.3688	.2374
17				.2883	.2713		.2713
18			.1341			.3018	
20			.3018				
21						.3185	
23	.2543				.3391		
24	.1696	.2543	.1006	.1006	.2035	.3391	.2012
Max	.4578	.4578	.503	.503	.6443	.7461	.3688
Min	.1696	.2543	.1006	.1006	.2035	.3018	.2012
Avg	.2939	.3561	.297	.2890	.3646	.4412	.2742

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 204 / 11 KV WATER WORKS EXP NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0168			
3							.0168
4			.0168				
6				.0168			.0168
7						.017	
8	.017	.017	.0168	.0168	.017	.017	.0168
11							.017
12			.0671			.0168	
16			.0671			.0168	.017
17	.0678			.017	.0678		.017
18			.0671			.0168	
20			.0168				
21						.0168	
23	.017				.017		
24	.017	.017	.0168	.0168	.017	.017	.0168
Max	.0678	.017	.0671	.017	.0678	.017	.017
Min	.017	.017	.0168	.0168	.017	.0168	.0168
Avg	.0297	.017	.0384	.0168	.0297	.0169	.0169

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 205 / 11 KV Bhoyra New SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.2012			
3							.3353
4			.3353				
6				.3521			.5868
7						.373	
8	.3561	.3391	.3353	.503	.4239	.4409	.5365
9	.1357						
11							.3052
12			.1677			.2683	
15						.1844	
16			.2012				
17	.2035			.2883	.2543		
18						.3521	
20			.5365				
21						.3185	
23	.4239				.4239		
24	.3391	.3391	.2347	.3018	.1526	.2035	.2347
Max	.4239	.3391	.5365	.503	.4239	.4409	.5868
Min	.1357	.3391	.1677	.2012	.1526	.1844	.2347
Avg	.2917	.3391	.3018	.3293	.3137	.3058	.3997

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 206 / 11 KV Ankoli new SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1677			
3							.1677
4			.1174				
6				.285			.3018
7						.2035	
8	.1865	.3561	.3688	.3185	.1865	.1865	.3185
11							.1696
12			.0503				
16			.0503			.1341	.1696
17	.0848			.0509	.1187		.1696
18			.0671			.1341	
20			.2347				
21						.2347	
23	.1187				.1865		
24	.1696	.1696		.1677	.1865	.1696	.1341
Max	.1865	.3561	.3688	.3185	.1865	.2347	.3185
Min	.0848	.1696	.0503	.0509	.1187	.1341	.1341
Avg	.1399	.2629	.1481	.1980	.1696	.1771	.2044

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154062 / 33/ 11 KV Ankoli S/S

Feeder No / Name : 207 / 11 KV Dhanori SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.0671			
3							.0335
4			.0838				
6				.1844			.0671
7						.017	
8	.1696	.1696	.1509	.1844		.017	.0671
11							.017
12			.2683			.0838	
16			.3018			.0671	.017
17	.1696						.017
18			.0335			.0168	
20			.1006				
21						.0168	
23	.1696				.017		
24	.1017	.1696	.0838	.0671		.017	.0335
Max	.1696	.1696	.3018	.1844	.017	.0838	.0671
Min	.1017	.1696	.0335	.0671	.017	.0168	.017
Avg	.1526	.1696	.1461	.1258	.017	.0336	.0360

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 201 / 11 KV KARKHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3521		.3734			.4024	.1619
2		.3086	.3696			.3982	.1296
3		.3429	.4024			.439	.1457
4		.4973	.462			.4525	.1457
5		.6001	.6154			.6268	.1781
6	.5121	.703	.823			.7602	.2105
7	.6401	.7373	.6201			.724	.2105
8	.6722	.6516	.5373			.6201	.2753
9		.4801					.2753
10	.2372	.2591	.4744				.3401
11	.2187	.3163	.503		.192	.3963	.3005
12	.25	.3681	.583	.2401	.208	.381	.2688
13	.25	.3841	.6316	.2721	.176	.3353	.2688
14	.2343	.4001	.5992		.1875		.2881
15	.2105	.3437	.6478	.2561	.125	.3963	.3005
16	.2591	.3953	.6802	.2721	.1581	.4725	
17	.25	.4534	.6802		.1423	.4268	
18	.3401	.3258	.3439		.4835		.5851
19	.6154	.5601	.5973		.7392	.7602	.6081
20	.5668	.8316	.6335		.7316	.724	.5921
21	.4858	.6219	.5792		.6219	.5068	.5218
22	.4268	.5121			.5544	.4706	.5281
23	.4049	.4435			.4572	.4163	.3163
24	.3361	.3239	.3841			.4119	.1619
Max	.6722	.8316	.823	.2721	.7392	.7602	.6081
Min	.2105	.2591	.3439	.2401	.125	.3353	.1296
Avg	.3822	.4722	.5496	.2601	.3674	.5061	.3097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 202 / 11 KV NIVALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.4458	.3647	.362	.1658	.3277	
2		.4458	.3932	.3258		.3239	
3	.2949	.5144	.4049	.3258	.2294	.3521	
4		.583	.4534	.2591	.2949	.3479	
5	.3605	.6516	.5281	.3239	.3605	.4161	
6		.6859	.6964	.3563	.4096	.5344	
7	.4588	.6516	.6478	.3887	.5407	.6478	
8	.4752	.6001	.6478	.3563	.5079	.5992	
9		.5182	.6401	.3887	.426	.5735	
10	.4096		.4119	.4887			
11	.25		.2286				.1311
12			.1781		.1638	.1829	.3605
13	.2187	.197	.1457		.1791	.2286	.3277
14	.1875	.181	.1619	.1966		.1829	.2818
15	.1619	.1791	.1619	.2321		.1829	.3113
16	.1457	.2353	.1619	.2458	.2743	.2896	.2949
17	.2105	.2561	.1943		.4572	.3353	
18	.7287	.3292			.5601	.543	
19	.7287	.5601	.362		.6908	.8145	.6133
20	.8583	.8589	.4525		.8402		.6299
21	.6316	.679	.5068		.6535	.543	.5735
22	.3658	.5093	.4344		.5281	.4525	.4973
23	.3401	.415	.4163		.3734	.3801	.3647
24	.2622	.3887	.373	.4163	.1311	.3018	
Max	.8583	.8589	.6964	.4887	.8402	.8145	.6299
Min	.1457	.1791	.1457	.1966	.1311	.1829	.1311
Avg	.3869	.4707	.3898	.3333	.4098	.4076	.3987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154086 / 33 KV S/S NIVALI

Feeder No / Name : 203 / 11 KV DHAKNI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2214	.2572	.2721	.0724	.176	.2214	.0648
2		.2572	.2881	.0905		.2214	.0648
3	.2372	.2743	.2915	.1086	.2241	.2343	.081
4		.3429	.2881	.2753	.3201	.253	.081
5	.2688	.4115	.3239	.3077	.3361	.2881	.1457
6		.463	.4096	.4534	.3681	.3201	.2591
7	.3479	.4973	.5281	.5344	.4321	.4161	.2429
8		.5144	.6325	.5344	.4111	.421	
9		.4858	.5921	.583	.427	.4161	
10	.0791	.1067	.1075	.1086	.1107	.1433	.3077
11	.0625	.0724	.061	.0648	.048	.0762	.3201
12		.0549			.048		.3725
13	.0781	.0532	.0486	.048	.0532		.3479
14	.0781	.0532	.0486		.0537	.061	.3201
15	.0648	.0543	.0486	.064	.0543	.061	.3005
16	.0648	.0537	.0486	.0633	.0732	.0457	.2721
17	.0486	.0543	.0648		.0739	.061	.2688
18	.081	.0732	.0724	.144	.0934	.1267	.1265
19	.1943	.1867	.1629		.1867	.2172	.176
20	.1781	.2054	.1991	.1107	.1698	.2715	.1581
21	.0972	.1494	.2353		.1509	.0905	.1423
22	.0914	.1132	.0905	.0791	.0943	.0905	.112
23	.081	.0943	.0724	.08	.0943	.0905	.0791
24	.2214	.2105	.2818	.0724	.128	.2155	.081
Max	.3479	.5144	.6325	.583	.4321	.421	.3725
Min	.0486	.0532	.0486	.048	.048	.0457	.0648
Avg	.1387	.2100	.2247	.1997	.1794	.1974	.1965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 201 / 11 KV RAMEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3012		.2			
2	.1667	.2635	.2282	.2	.1823	.2284	
3		.3012		.2			
4	.2	.3734		.2	.1658	.3426	.2652
5		.4108		.2334			
6	.2667	.4472		.2667			
7		.4472	.4183	.3334	.431	.3807	.2652
8	.3668		.716	.2667	.4144	.2798	.2818
9	.2334			.2			
10	.2353	.2956	.3334		.3003		.2334
11	.2393	.3471	.3668	.3647	.2709	.1989	.2334
12	.2682	.3708	.4334		.2531		.1667
13	.2682	.3704		.3481	.2781	.3481	.1667
14	.2384	.345			.2778	.1658	.1667
15	.2682	.4017	.4668		.2155		.1673
16	.298	.4012	.4668	.4144	.1854	.3149	.2
17	.3278	.4017	.4334		.3396		.2334
18	.3361	.1523	.2	.3978	.1901		.2667
19		.3042	.2334		.1901		.3334
20	.4518	.3803	.2	.3315	.3803	.3647	.2334
21	.4518		.2		.3042		.2667
22	.4141		.2	.2321	.2662	.2652	.2334
23	.3765				.2284		.2
24	.1667	.3388	.2282	.2		.2282	
Max	.4518	.4472	.716	.4144	.431	.3807	.3334
Min	.1667	.1523	.2	.2	.1658	.1658	.1667
Avg	.2934	.3502	.3416	.2743	.2708	.2834	.2302

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 202 / 11 KV CHINCHOLI (B) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4458					
2	.6001	.4805	.5298			.4755	
3		.5175					
4	.5668	.5081	.5871		.4475	.5011	.3315
5		.5733					
6	.5335	.5683					
7		.5364		.1667	.5801	.5312	.5304
8	.6335		.5958	.7335	.547	.4944	.4475
9	.6001			.8002			
10	.2801	.2282	.1667		.334		.4334
11	.2614	.0188	.2	.2486	.2981	.2155	.5001
12		.0191	.2334		.2241		.5001
13	.1497	.2282	.2667	.2155	.2609	.2486	.5001
14	.1875	.2282	.3001		.2603	.2155	.4668
15	.225	.2582	.2		.2957		.4684
16	.2245	.2218	.2	.0166	.2218	.2486	.5335
17	.2619	.1844	.2		.2149		.5668
18	.2619	.3042	.2667		.3042		.3334
19		.4183	.4001				.4334
20	.5082	.5704	.4001	.3647	.5704	.4641	.4001
21			.4001		.5324		.3668
22			.4334	.3647		.2818	.3668
23				.2321	.4183		.3668
24	.6335	.4108	.5533			.5064	
Max	.6335	.5733	.5958	.8002	.5801	.5312	.5668
Min	.1497	.0188	.1667	.0166	.2149	.2155	.3315
Avg	.3952	.3537	.3490	.3492	.3673	.3802	.4439

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154102 / 33/11 KV RAMEGAON

Feeder No / Name : 203 / 11 KV GONDEGAN SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2259		.1667			
2	.1667	.2259		.2	.1492		
3		.2635		.2			
4	.2	.3012	.1901	.2	.2818		.3481
5		.3361		.3001			
6	.3001	.3734		.3668			
7		.3361	.4944	.5001	.431	.3807	.3978
8	.3334		.358	.3334	.3481	.4057	.4144
9	.2334			.3334			
10	.4234	.6212	.5001		.3307		.1
11	.3908	.5535	.5668	.4641	.3161	.8785	.1334
12	.3739		.6668		.3208		.1334
13	.3278	.6413	.7668	.5138	.093	.4475	.1334
14	.3576	.5475	.8002		.3704	.1989	.1334
15	.3576	.6004	.8669		.3704		.1334
16	.3725	.6026	.8669	.4973	.3704	.3978	.1334
17	.4172	.5871	.8335		.3382		.1667
18	.1684	.1142	.1334	.3647	.1901		.2
19		.2662	.1667				.2667
20	.3012	.3423	.1667	.1658	.2855	.2321	.2
21			.1667		.2282		.2334
22			.1667	.1989	.1901	.1989	.2
23					.1521		.1667
24	.1334	.1882	.1521	.1667		.1521	
Max	.4234	.6413	.8669	.5138	.431	.8785	.4144
Min	.1334	.1142	.1334	.1658	.093	.1521	.1
Avg	.3036	.3959	.4625	.3107	.2804	.3658	.2055

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 201 / 11KV Bhisewagholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17
HR	Load (MW)
8	.4748
16	.1844
22	.3395
24	.2452
Max	.4748
Min	.1844
Avg	.3110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 202 / 11kv Wadiwagholi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17
HR	Load (MW)
8	.0934
16	.2949
22	.0754
24	.0943
Max	.2949
Min	.0754
Avg	.1395

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

MURURD (R) S/DN[421] BU 5134

Substation No/ Name :- 154119 / 33/11kv BHISEWAGHOLI

Feeder No / Name : 203 / 11kv Khuntephal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17
HR	Load (MW)
8	.0848
16	.1006
22	.0377
24	.0566
Max	.1006
Min	.0377
Avg	.0699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 201 / 11 Kv Renapur-I SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.4287		
16		.4287		.5144	.4287
20		.4287			
24	.4287		.3429		
Max	.4287	.4287	.4287	.5144	.4287
Min	.4287	.4287	.3429	.5144	.4287
Avg	.4287	.4287	.3858	.5144	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 202 / 11 Kv Mahapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.6001	
16		.4287		.4287
20		.6001		
24	.5144		.4287	
Max	.5144	.6001	.6001	.4287
Min	.5144	.4287	.4287	.4287
Avg	.5144	.5144	.5144	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 204 / 11 Kv Samsapur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.6859	
16		.2572		.2572
20		.6859		
24	.4287		.4287	
Max	.4287	.6859	.6859	.2572
Min	.4287	.2572	.4287	.2572
Avg	.4287	.4716	.5573	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 205 / 11 Kv Phata SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9			.1715	
16		.1715		.1715
20		.1715		
24	.0857		.0857	
Max	.0857	.1715	.1715	.1715
Min	.0857	.1715	.0857	.1715
Avg	.0857	.1715	.1286	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154007 / 33/11 KV RENAPUR S/S

Feeder No / Name : 206 / 11 Kv Renapur-II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154036 / 33/11 KV Pangaon S/S

Feeder No / Name : 201 / 11 Kv Pangaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 201 / 11 Kv Poharegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12			.2572			
2	.1372		.2561	.2743		.1943	
3	.1543			.3086			
4	.1715		.3125	.3258		.2241	
5	.1886			.3429			
6	.2058		.3201	.3601	.3429	.2187	
7	.2572						
8	.2743	.3772	.4572	.4287		.25	.3429
9		.4115		.4115			
10			.181	.2572		.2686	.2058
11		.1715	.1543	.1886			
12			.0857	.0686	.1949	.1928	
13		.124	.1372	.1372	.2126		
14			.1372				
15			.12				
16	.1543		.1372	.2401			.2572
17		.2279	.1543				
18			.1886				.3772
19			.3772				
20		.4207	.3601		.3801		
21			.3772				
22	.2743	.2835	.3429				
23			.3601			.2058	
24	.12	.1543	.2229	.2743	.2401	.1823	.2401
Max	.2743	.4207	.4572	.4287	.3801	.2686	.3772
Min	.12	.124	.0857	.0686	.1949	.1823	.2058
Avg	.1870	.2713	.2464	.2768	.2741	.2171	.2846

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 202 / 11 Kv Shera SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311			.0819			
2	.1147		.0983	.1147		.1017	
3	.1475			.1311			
4	.1638		.1134	.1475		.1475	
5	.1638			.1638			
6	.1802		.1423	.1802		.1475	
7	.0819						
8	.1966		.2778	.2743		.2401	.3277
9		.3277		.3277			
10			.2149	.2458		.2804	.1638
11		.0655	.1475	.1638			
12			.0819	.0983	.0905	.1075	
13		.0358	.0655	.0983			
14			.0819				
15			.0655				
16	.0655		.0655		.0886		.1638
17		.1254	.0819	.1638			
18			.1147		.1612		.2622
19			.2294				
20		.3258	.2294		.3761		
21			.2458				
22	.1638	.1753	.2458				
23			.2622			.1475	
24	.1147	.0819	.0686	.0819		.0514	.1638
Max	.1966	.3277	.2778	.3277	.3761	.2804	.3277
Min	.0655	.0358	.0655	.0819	.0886	.0514	.1638
Avg	.1385	.1625	.1491	.1624	.1791	.1530	.2163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154047 / 33/11 KV POHAREGAON S/STN

Feeder No / Name : 203 / 11 Kv Bhokaramba SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716			.6859			
2	.9431		.7011	.823			
3	1.0288			.9431			
4	1.286		1.1744	1.2003			
5	1.3717			1.3717			
6	1.7147		1.7833	1.7147	1.2936		
7	1.6632						
8	1.3203			1.4575		.3155	.8954
9		1.1088		1.1488			
10			.5506	.7545			.7023
11		.6805	.6687	.703			
12			.703	.703	.5693	.6718	
13		.6562	.8573	.7373			
14			.823		.2267		
15			.8402				
16	.6805		.3601		.5312		.7392
17		.6478	.9945	.788			
18			1.0631		.7888		1.0719
19			1.2517				
20		1.3696	1.2003		1.0517		
21			1.1488				
22	1.0164	.964	1.0288				
23			.6687				
24	.6687	.7577	.7701	.6687	.7023		.6089
Max	1.7147	1.3696	1.7833	1.7147	1.2936	.6718	1.0719
Min	.6687	.6478	.3601	.6687	.2267	.3155	.6089
Avg	1.1332	.8835	.9215	.9785	.7377	.4937	.8035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 201 / 11 Kv Sindhgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3086		.2572	.3601	.3772	.3086	.2572
8	.6173	.583	.5144	.7545	.7888	.7202	.4458
12		.2572	.3944	.3772		.3258	.2572
16			.4115	.3258	.2572	.3258	
17		.2801					.3086
20		.6001	.6173	.5144	.6001	.5316	.5487
24	.2229	.2401	.2572	.2743	.2401	.2401	.2229
Max	.6173	.6001	.6173	.7545	.7888	.7202	.5487
Min	.2229	.2401	.2572	.2743	.2401	.2401	.2229
Avg	.3829	.3921	.4087	.4344	.4527	.4087	.3401

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154051 / 33/11 KV SINDHGAON S/STN

Feeder No / Name : 202 / 11 Kv Niwada SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.3086		.3772		.2401	.2058	.4801
5				.1886			
8	.463	.6001	.5144	.5487	.3601	.5144	.7545
12		.2572		.2743	.1886	.2401	.3429
16			.2572	.3429	.3086		
17		.3086					.3429
20		.7716	.7716	.6859	.583	.6001	.5144
24	.1715	.1886	.1715	.1886	.1543	.1543	.3944
Max	.463	.7716	.7716	.6859	.583	.6001	.7545
Min	.1715	.1886	.1715	.1886	.1543	.1543	.3429
Avg	.3144	.4252	.4184	.3715	.3058	.3429	.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 201 / 11 Kv Kharola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5487	.4967	.5975	.5792	.4725	.6485	
16	.4214	.1654	.4725	.4572			.3201
24	.141	.3311	.3241	.3353	.2743		
Max	.5487	.4967	.5975	.5792	.4725	.6485	.3201
Min	.141	.1654	.3241	.3353	.2743	.6485	.3201
Avg	.3704	.3311	.4647	.4572	.3734	.6485	.3201

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 202 / 11 Kv Kumbharwadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.3281	.3953	.3353	.3125	.3605	
16	.0625	.132	.1219	.0972			.2134
24	.1086	.1875	.1446	.1524	.1943		
Max	.1086	.3281	.3953	.3353	.3125	.3605	.2134
Min	.0625	.132	.1219	.0972	.1943	.3605	.2134
Avg	.0856	.2159	.2206	.1950	.2534	.3605	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154070 / 33/11 KV KHAROLA S/S

Feeder No / Name : 203 / 11 Kv Selu (J) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6036	.4973	.6224	.5487	.5182	
16	.4409	.3807	.442		.2538	.442
24	.4527	.373	.415	.3506		
Max	.6036	.4973	.6224	.5487	.5182	.442
Min	.4409	.373	.415	.3506	.2538	.442
Avg	.4991	.417	.4931	.4497	.386	.442

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154084 / 33/11 KV BITTERGAON

Feeder No / Name : 202 / Kamkheda SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4298	.0381		.0091		.1014	.048
12				.3045			.3258
16			.08	.3801	.1174		.3045
20				.5249			.6878
24	.2534	.0398		.0366			
Max	.4298	.0398	.08	.5249	.1174	.1014	.6878
Min	.2534	.0381	.08	.0091	.1174	.1014	.048
Avg	.3416	.0390	.08	.2510	.1174	.1014	.3415

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 201 / 11 KV DARJI BORGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0633	.1029	.0949	.0648	.0857	.0791	.1715
2	.0633		.0949	.0648	.0857	.0633	.1905
3	.0633	.12	.0949	.081	.0857	.0633	.2286
4	.0633	.1372	.1107	.0972	.0857	.0633	.2667
5	.1265	.1372	.1265	.0972	.1029	.1265	.3048
6	.1581	.1715	.1581	.1296	.12	.1898	.3429
7	.1581	.1715	.1581	.1296	.1372	.1562	.4191
8	.1581	.2058	.1581	.1296	.1372	.2214	.3429
9	.0949	.1715	.1265	.1619	.0949	.1898	.2667
10	.1029	.1107	.1143	.1372	.0791		.0857
11		.0949	.0762	.1372	.0633		.0857
12	.0857	.0791	.0762	.12	.0633	.0762	.0857
13	.0857	.0633	.0762	.1029	.0633	.0762	.0857
14	.0857	.0633	.0762	.0857	.0633	.0762	.0857
15	.0857	.0791	.0762	.1029	.0949	.0762	.0857
16	.0857	.0949	.0762	.0857	.0949	.1143	.1029
17	.1029	.0949	.0762	.0857	.1107	.1143	.1029
18	.1029	.1265	.0762	.1734	.1265	.1524	.1372
19	.2058	.2656	.2286	.2401	.1581	.2286	.2058
20	.2572	.1898	.2667	.2058	.1898	.2667	.2572
21	.2058	.1898	.2286	.1715	.1898	.2286	.2229
22		.1581	.1905		.1898	.2096	
23		.1423	.1715		.1581	.1905	
24	.0633	.1029	.0633	.0648	.0857	.0633	.1715
Max	.2572	.2656	.2667	.2401	.1898	.2667	.4191
Min	.0633	.0633	.0633	.0648	.0633	.0633	.0857
Avg	.1152	.1336	.1248	.1213	.1111	.1375	.1931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 202 / 11 KV BHARAMWADI -Ghavan SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0514	.0701	.0648	.0514	.0543	.1715
2	.0686	.1029	.0701	.0648	.0514	.0526	.1905
3	.1029	.1543	.1029	.0972	.1029	.0543	.1905
4	.1029	.2058	.1677	.0972	.1029	.0543	.2286
5	.1696	.2572	.2012	.1296	.1543	.1791	.2667
6	.2035	.3601	.3315	.1457	.1543	.2149	.3048
7	.2543	.4115	.3978	.2915	.2058	.2629	.3429
8	.2012	.3086	.3481	.3401	.2572	.3561	.2286
9	.2012	.2572	.3086	.2743	.2572	.2715	.1143
10	.1029	.0905	.0762	.0514	.0543	.0762	.1029
11	.0514	.0732	.0572	.0514	.056	.0572	.1029
12	.0514	.0739	.0572	.0514	.0554	.0572	.0514
13	.0514	.0747	.0572	.0514	.0554	.0572	.0514
14	.0514	.056	.0572	.0514	.056	.0572	.1029
15	.0514	.056	.0572	.0514	.056	.0572	.1029
16	.0514	.056	.0572	.0514	.056	.0572	.1543
17	.0514	.0566	.0572	.0514	.0724	.0762	.1543
18	.0514	.0747	.0572	.2058	.0876	.1143	
19		.1867	.1905	.2572	.168	.1905	.2058
20	.3086	.2195	.3048	.2058	.1867	.2286	.2572
21	.2572	.2195	.2667	.1543	.2103	.2477	.2058
22		.1867	.2286		.181	.2286	
23		.168	.1715		.168	.1905	
24	.0701	.0514	.0566	.0486	.0514	.0526	.1715
Max	.3086	.4115	.3978	.3401	.2572	.3561	.3429
Min	.0514	.0514	.0566	.0486	.0514	.0526	.0514
Avg	.1201	.1564	.1563	.1267	.1188	.1354	.1763

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

LATUR DIVISION[518]

RENAPUR (R) S/DN[564] BU 5649

Substation No/ Name :- 154110 / 33KV/11KVDARJI BORGAON S/S

Feeder No / Name : 203 / 11 KV INDARTHANA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2572	.2915	.3048	.2572	.2915	.1296
2	.2374	.2572	.2915	.3048	.2572	.2915	.1296
3	.2515	.2572	.2915	.3429	.2572	.2915	.1457
4	.285	.3086	.3467	.4191	.2572	.3258	.1619
5	.4748	.3772	.5144	.4954	.3429	.4382	.1619
6	.5426	.6001	.5487	.6097	.4801	.4508	.1781
7	.5868	.6516	.6173	.5716	.5144	.4115	.1943
8	.5365	.463	.4748	.5144	.3601	.2374	.1943
9	.3688	.3429	.373	.4954	.285	.2035	.2105
10	.1029	.12	.2267	.1029	.1357		.2743
11	.1029	.1017	.1372	.1029	.1187	.0972	.2572
12	.1029	.1017	.1296	.1029	.1017	.1134	.2058
13	.1029	.0848	.1134	.1029	.1029	.1296	.2058
14	.1029	.1187	.1134	.1029	.0848	.1296	.2058
15	.1029	.1187	.1134	.0857	.1174	.1457	.1715
16	.12	.1357	.1134	.1372	.1174	.1457	.1715
17	.1543	.1357	.1134	.1372	.2012	.1457	.1715
18	.2058	.2058	.2477	.4458	.218	.3429	.2915
19	.3429	.2883	.4191	.4458	.3052	.4572	.3429
20	.4287	.373	.4572	.3429	.3353	.4191	.4287
21	.3429	.373	.381	.3086	.39	.4191	.3429
22		.3258	.3429		.373	.381	
23		.2883	.3048		.2883	.3429	
24	.2743	.2572	.2713	.2858	.2572	.298	.1296
Max	.5868	.6516	.6173	.6097	.5144	.4572	.4287
Min	.1029	.0848	.1134	.0857	.0848	.0972	.1296
Avg	.2731	.2726	.3014	.3073	.2566	.2830	.2139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 203 / 11KV Khanapur(AG)

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1867					
4		.1867					
6		.2241					.2987
7							.2987
8				.0747		.2241	.2987
9						.2241	.4481
10		.4858					
11						.5601	.1867
12					.4481		
13		.9335					
14					.6348	.6722	
15		.8962				.6722	
16		.9335					
17	.8589		.8962				.1848
18			.1867	.2241		.7095	.2218
19	.2241						
20						.2241	
21	.2241						
22						.1494	
23	.2241						
24			.2241			.2241	
Max	.8589	.9335	.8962	.2241	.6348	.7095	.4481
Min	.2241	.1867	.1867	.0747	.4481	.1494	.1848
Avg	.3828	.5495	.4357	.1494	.5415	.4066	.2768

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 204 / 11kv Borphal AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2587					
4		.2402					
5				.3361			
6		.2218		.3734			.0373
7							.0373
8				.4108	.5544	.5601	.0373
9						.5914	.037
11						.037	.4066
12					.0373		
14					.0373	.037	
15		.0373				.037	
16		.0373					
17	.037		.0373				.3658
18			.0373			.0373	.037
19	.037						
20						.0373	
21	.037						
22						.0373	
23	.037						
24			.0934			.2241	
Max	.037	.2587	.0934	.4108	.5544	.5914	.4066
Min	.037	.0373	.0373	.3361	.0373	.037	.037
Avg	.037	.1591	.056	.3734	.2097	.1776	.1369

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 205 / 11kv Utti w/w express NON SHEDDABLE WATER SUPPLY AND
 feeder Feeder KV- 11 / UTILITY
 OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.037					
4		.037					
5				.0747			
6		.037		.0747			.0373
7							.0373
8				.1867	.1478	.1494	.0373
9						.1109	.1478
11						.1478	.1478
12					.1494		
13		.0373					
14					.1867	.1478	
15		.112				.1478	
17			.112				.1294
18			.0747	.1109		.1494	.1294
19	.037						
20						.112	
21	.037						
22						.112	
23	.037						
24			.0373			.1494	
Max	.037	.112	.112	.1867	.1867	.1494	.1478
Min	.037	.037	.0373	.0747	.1478	.1109	.0373
Avg	.037	.0521	.0747	.1118	.1613	.1363	.0952

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 206 / 11kv Old midc of 33KV AUSA SHEDDABLE FEEDER HAVING WEEKLY
sub Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0747					
4		.0554					
5				.0373			
6		.056		.056			.0373
7							.0747
8				.112	.0549	.056	.0747
9						.0934	.0747
11						.112	.0747
12					.0747		
13		.056					
14					.0747	.1307	
15		.0747				.0934	
16		.056					
17			.0747				.0554
18			.1307	.1109		.056	.1109
19	.0747						
20						.056	
21	.056						
22						.0373	
23	.056						
24			.056			.056	
Max	.0747	.0747	.1307	.112	.0747	.1307	.1109
Min	.056	.0554	.056	.0373	.0549	.0373	.0373
Avg	.0622	.0621	.0871	.0791	.0681	.0768	.0718

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 207 / 11kv Karajgaon gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1663					
4		.1663					
5				.2054			
6		.2218		.1867			.112
7							.1867
8				.1867	.1848	.1867	.2801
9						.1109	.1848
11						.0739	.1109
12					.056		
13		.0747					
14					.0747	.0739	
15		.0934				.0739	
17	.0924		.0934				.1294
18			.0934			.112	.1294
19	.1663						
20						.168	
21	.2033						
22						.1307	
23	.1848						
24			.1494			.1494	
Max	.2033	.2218	.1494	.2054	.1848	.1867	.2801
Min	.0924	.0747	.0934	.1867	.056	.0739	.1109
Avg	.1617	.1445	.1121	.1929	.1052	.1199	.1619

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154002 / 33KV AUSA

Feeder No / Name : 208 / 11 KV Almala Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /
OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.2772					
4		.3326					
5				.4108			
6		.6283		.4108			.1867
7							.2241
8				.4668	.4251		.1867
9							.1294
12					.2427		
13		.1494					
14					.2241		
15		.2241					
17	.2772		.2054				.3142
18			.2241	.2987		.1307	.2772
19	.4251						
20						.1494	
21	.4251						
22						.1494	
23	.3326						
24			.3174				
Max	.4251	.6283	.3174	.4668	.4251	.1494	.3142
Min	.2772	.1494	.2054	.2987	.2241	.1307	.1294
Avg	.365	.3223	.2490	.3968	.2973	.1432	.2197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 201 / 11KV Yerandi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.3309				
8	.2572	.2401		.2743		.2572	.3036
9		.2229	.1103		.2439		
10		.1328					.1839
11		.0949				.0949	.1655
12						.1139	
13							.2206
14						.1139	
16	.0514		.0514	.0857		.1287	.2206
17		.1139	.0514			.1518	.2206
18		.1518				.1898	.1708
23		.1839					
24	.1372	.1715		.1524	.1543	.1715	
Max	.2572	.2401	.3309	.2743	.2439	.2572	.3036
Min	.0514	.0949	.0514	.0857	.1543	.0949	.1655
Avg	.1486	.1640	.136	.1708	.1991	.1527	.2122

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 202 / 11KV Kaneri Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.2657				
8	.1524	.1543		.0857		.1543	
9		.0857			.1543		
10		.0552					.1328
11		.1103				.2022	.1139
12						.2574	.1139
13							.0949
14						.239	
16			.0914	.12		.1328	.0949
17		.1839					.1139
18		.1518				.1139	.1328
24	.1886	.1715		.0514	.1372	.1543	
Max	.1886	.1839	.2657	.12	.1543	.2574	.1328
Min	.1524	.0552	.0914	.0514	.1372	.1139	.0949
Avg	.1705	.1304	.1786	.0857	.1458	.1791	.1139

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154030 / 33KV YERANDI S/S

Feeder No / Name : 203 / Hasegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.4744				
8	.1829	.2572		.3601			
9		.2743			.3429	.4115	
10		.2022					.2467
11		.2758				.2206	
12						.0368	.1898
13							.1708
14						.2206	
16	.2572		.3048	.2896		.1839	.1708
17		.2942					.1518
18						.1708	.2277
24	.1715	.2401	.2657	.2401	.1981	.2401	
Max	.2572	.2942	.4744	.3601	.3429	.4115	.2467
Min	.1715	.2022	.2657	.2401	.1981	.0368	.1518
Avg	.2039	.2573	.3483	.2966	.2705	.2120	.1929

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 202 / 11kv water works express NON SHEDDABLE WATER SUPPLY AND
feede Feeder KV- 11 / OUTGOING UTILITY

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0857		.0857	.0857	.0857	.0857	.0857
16	.0743	.0857	.0857	.061	.0857	.0857	.0743
24	.0857		.0857	.0857	.0857	.0857	.0857
Max	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Min	.0743	.0857	.0857	.061	.0857	.0857	.0743
Avg	.0819	.0857	.0857	.0775	.0857	.0857	.0819

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 204 / Devtala Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6687		.6859	.7202	.583	.7202	.5658
16		.2572	.3429	.2713	.3429	.2743	
24	.3429		.3429	.3429	.3429	.3429	.3772
Max	.6687	.2572	.6859	.7202	.583	.7202	.5658
Min	.3429	.2572	.3429	.2713	.3429	.2743	.3772
Avg	.5058	.2572	.4572	.4448	.4229	.4458	.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154032 / 33kv Matola

Feeder No / Name : 205 / Kavli Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4458	.6068	.3429	.7716		.8573	1.3032
16	.6068	.8573	.8916	.3467	.9431	.5487	.6935
24	.2915		.2058	.6001		.5144	.7716
Max	.6068	.8573	.8916	.7716	.9431	.8573	1.3032
Min	.2915	.6068	.2058	.3467	.9431	.5144	.6935
Avg	.4480	.7321	.4801	.5728	.9431	.6401	.9228

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 201 / 11kv Belkund SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858				.2858	
2	.2858				.381	
3	.2858				.381	
4	.2858	.381			.381	
5	.381				.381	
6	.3048				.4572	
7	.3048				.4572	
8	.3048	.3353			.381	
9	.3048				.3048	
10	.1524	.3048		.2515	.3048	.503
11				.2286		
12				.2286		
13				.2286		
14		.1524		.1524		
15				.1524		
16				.1524		
18			.2515	.1524		
19				.1905		
20				.2858		
21				.3239		
22				.3239		
23				.2286		
24	.3506	.3048			.2286	
Max	.381	.381	.2515	.3239	.4572	.503
Min	.1524	.1524	.2515	.1524	.2286	.503
Avg	.2951	.2957	.2515	.2230	.3585	.503

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 203 / 11 kv Karkhana Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381				.3048	
2	.3048				.3048	
3	.3048				.3048	
4	.3048	.2858			.3048	
5	.3048				.381	
6	.381				.381	
7	.381				.381	
8	.381	.2972			.4572	
9	.1524				.4572	
10	.3048	.2972		.1457	.4572	.1457
11	.2439			.6097		
12	.2667			.6859		
13	.2667			.7621		
14		.4572		.7621		
15				.7621		
16				.6097		
18			.1457	.2286		
19				.2286		
20				.2286		
21				.3048		
22				.3048		
23				.3048		
24	.381	.2286			.3048	
Max	.381	.4572	.1457	.7621	.4572	.1457
Min	.1524	.2286	.1457	.1457	.3048	.1457
Avg	.3113	.3132	.1457	.4567	.3671	.1457

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 204 / Gukheda Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048				.381	
2	.2286				.381	
3	.2286				.381	
4	.2286	.2429			.381	
5	.3048				.4572	
6	.3048				.4572	
7	.3048				.4572	
8	.2286	.3239			.3048	
9	.2286				.3048	
10	.381	.2858		.4744	.381	.6325
11				.3048		
12				.3048		
13				.3048		
14				.3048		
15				.3048		
16				.3048		
18			.2372	.2286		
19				.2286		
20				.2286		
21				.2286		
22				.2286		
23				.3048		
24	.3048	.2429			.3048	
Max	.381	.3239	.2372	.4744	.4572	.6325
Min	.2286	.2429	.2372	.2286	.3048	.6325
Avg	.2771	.2739	.2372	.2885	.381	.6325

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154034 / 33/11 Kv Belkund S/S

Feeder No / Name : 205 / Malumbra Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097				.381	
2	.6097				.381	
3	.6859				.381	
4	.6859	.4096			.381	
5	.6859				.381	
6	.4572				.6097	
7	.4572					
8	.4572	.4096				
9	.4572					
10	.2286	.2286		.2429	.3048	.2429
11				.2286		
12				.2286		
13				.2286		
14		.1638		.1524		
15				.1524		
16				.1524		
18			.2591	.1524		
19				.2286		
20				.2286		
21				.2286		
22				.2286		
23				.2286		
24	.3048	.4096			.2286	
Max	.6859	.4096	.2591	.2429	.6097	.2429
Min	.2286	.1638	.2591	.1524	.2286	.2429
Avg	.5127	.3242	.2591	.2063	.3810	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 201 / 11 KV Jawalga Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2321	.2652	.2915	.3239	.2591	.4915
2	.2321	.2652	.2591	.2915	.2591	.5735
3	.2652	.2652	.2591	.2915	.2591	.5735
4	.4144	.3315	.2915	.3239	.2915	.6478
5	.5304	.4144	.3239	.4534	.5182	.7287
6	.6554	.6554	.4534	.6478	.7125	.7287
7	.6554	.4915	.5182	.7773	.7773	.8097
8	.6554	.5898	.6478	.6802	.6802	.9602
9	.4973		.5506	.5506	.5506	.9393
10	.4973	.4858	.6478	.5506	.5182	.4049
11	.6554	.8097	.7773	.7125	.6036	.3481
12	.7373	.9069	.8097	.5182		.2486
13	.5801	.9717	.8097	.5182		.2486
14	.4973	.9717	.8745	.583		.2486
15	.5735	.9393	.9231	.583		.1989
16	.5735	.9393	.9069	.5506		.2486
17	.6554	.9717	1.0364	.5182		.1658
18	.2652	.2267	.1943	.5506		.3647
19	.5801	.3887	.3887			.5735
20	.6554	.583	.5506			.4915
21	.4973	.4858	.5182	.5182		.4915
22	.3647	.421	.421	.4534		.4144
23	.3315	.3239	.3563	.3563		.3315
24	.2652	.2984	.3239	.3239	.2915	.3277
Max	.7373	.9717	1.0364	.7773	.7773	.9602
Min	.2321	.2267	.1943	.2915	.2591	.1658
Avg	.4945	.5653	.5472	.5035	.4767	.4817

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154041 / 33KV Jawalga S/S

Feeder No / Name : 203 / 11 KV Haregaon Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2772	.3772	.1886	.1886	.1478
2	.2743	.3658	.3772	.2829	.1886	.1478
3	.3658	.4572	.415	.2829	.2829	.1478
4	.4572	.6335	.4904	.3772	.3395	.1478
5	.5487	.6516	.5658	.4527	.4527	.1478
6	.6219	.6401	.7167	.5658	.6036	
7	.5853	.6335	.7545	.5658	.6413	.1848
8	.5853	.3658	.8299	.5281	.4527	.1848
9	.567		.7545	.415	.4527	.2218
10	.3696	.2263	.7167	.2263	.2263	.2772
11		.1886	.1132	.1509		.4024
12	.2957	.1886	.0377	.132		.3658
13	.2772	.1886		.0377		.3658
14	.1848	.1132		.132		.3658
15	.1478	.1132		.132		.3292
16	.1109	.1132		.1134		.3658
17	.1663	.1132	.1296	.1509		.4024
18	.1848	.1509	.1509	.3772		.1829
19	.2772	.1886	.1886			.3696
20	.2957	.3772	.3395	.3772		.3326
21	.3292	.3772	.2641	.3018		.3326
22	.2587	.2641	.1509	.1886		.2772
23	.2772	.1886	.1132	.1509		.1848
24	.1829	.2772	.1886	.1886	.1886	.2218
Max	.6219	.6516	.8299	.5658	.6413	.4024
Min	.1109	.1132	.0377	.0377	.1886	.1478
Avg	.3321	.3084	.3837	.2747	.3652	.2655

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 201 / 11 KV Pethe SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.1715		.0817		.1372	
4		.1715		.0817		.12	
6		.1715		.0817		.1715	
7			.1715		.1715	.1715	
8	.1715	.1715	.1715	.0814	.1715	.343	.1715
9			.1715		.1715		
10	.1715		.2572	.0817	.1715		.1635
11		.2572		.1715			
12			.1308		.2572	.1715	.1308
13	.2572						
14		.2572	.0789	.1715	.2572		.0817
16		.2572	.0817	.1715	.1372	.1715	.0817
18	.1715	.2572	.0817	.1715	.1715	.1715	.0817
20		.1715	.0817	.1715	.1715		.0817
22				.1715		.1715	.0817
23		.1715	.0817				
24	.1715	.1715	.1715	.0814	.343	.1715	.1715
Max	.2572	.2572	.2572	.1715	.343	.343	.1715
Min	.1715	.1715	.0789	.0814	.1372	.12	.0817
Avg	.1886	.2027	.1345	.1266	.2024	.1801	.1162

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 202 / 11kv Selu SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429		.0981		.3429	
4		.3429		.1308		.3429	
6		.5144		.1635		.4287	
7			.6859		.3429		
8	.3429	.5144	.6001	.2942	.3429	.4287	.1715
9			.5144		.2572	.4287	
10	.0857		.1715	.0817	.1715		.2452
11		.12		.0857			
12			.0817		.0857	.0857	.1635
13	.0857						
14		.0857	.0817	.0857	.0857		.1308
16			.0817	.0857	.12	.0857	.0981
18	.0857	.0857	.0817	.12	.1372	.0857	.0817
20		.2572	.1308	.2572	.1715		.1308
22				.2058		.1715	.0981
23		.2058	.0817				
24	.4287	.3429	.4287	.0817	.3429	.3429	.1715
Max	.4287	.5144	.6859	.2942	.3429	.4287	.2452
Min	.0857	.0857	.0817	.0817	.0857	.0857	.0817
Avg	.2057	.2812	.2673	.1408	.2058	.2743	.1435

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 203 / 11kv Almala

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.0857		.0817		.0857	
4				.0817		.0857	
6				.0081		.0857	
7			.0857		.0857		
8		.0857	.0857		.0857	.1714	.6859
9					.0857		
10	.4287		.4287	.2452	.4287		.0817
11		.8573		.6859			
12			.7846		.6001	.7716	
14		.6859	.8173	.6859	.5144		.0817
16		.6859	.85	.7716		.8573	.0817
18	.0857	.0857	.0817	.0857		.7716	.0817
20		.0857	.0817	.0857	.3429		.0817
22				.0857		.6859	.0817
23		.0857	.0817				
24	.4287	.0857	.0857	.0817	.0857	.3429	.6859
Max	.4287	.8573	.85	.7716	.6001	.8573	.6859
Min	.0857	.0857	.0817	.0081	.0857	.0857	.0817
Avg	.3144	.3048	.3383	.2635	.2786	.4286	.2328

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154054 / 33KV BUDHODA

Feeder No / Name : 204 / Khuntegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.3429		.1308		.3429	
4		.4287		.1308		.4287	
6		.5144		.1955		.4287	
7			.6859		.2572		
8	.3429	.6001	.6859	.3269	.1715	.8574	.1715
9			.6859		.5144		
10	.0857		.0857	.049	.12		.3269
11		.0857					
12			.0327		.0857	.0857	.2452
14		.0857	.049		.0857		.1635
16		.0857	.0489	.0857	.0857	.0857	.1635
18	.0857	.0857	.0654	.12	.0857		.0817
20		.2058	.114	.2058	.1715		.0981
22				.2058		.1715	.0817
23		.2058	.0817				
24	.3429	.3429	.4287	.0817	.1715	.3429	.1715
Max	.3429	.6001	.6859	.3269	.5144	.8574	.3269
Min	.0857	.0857	.0327	.049	.0857	.0857	.0817
Avg	.2143	.2712	.2694	.1532	.1749	.3429	.1671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 201 / 11KV Tungi Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2683	.4144	.3429	.2652	.3018	.3052	.4973
4	.3932	.5801	.4458	.431	.4748	.4024	.6299
6	.431	.6962	.57	.4973	.6687	.8288	.5967
8	.2984	.4641	.2984	.2652	.3561	.6154	.5636
10	.2347	.2321	.1524	.1677	.2267	.4012	.3353
12	.1677	.1658	.1658	.1823	.1783	.1219	.0819
14	.1677	.1326		.1341		.1219	.2241
16		.1658				.1219	.285
18	.8383	.9614	.8288	.6882	.583	.5636	.3856
20	.7545	.663	.8288	.8383	.5365	.5304	.4694
22	.663	.4641	.5636	.5935	.4854		.4144
23		.431				.4973	
24	.3841	.6133	.4458	.4641	.4694	.4557	.4973
Max	.8383	.9614	.8288	.8383	.6687	.8288	.6299
Min	.1677	.1326	.1524	.1341	.1783	.1219	.0819
Avg	.4183	.4603	.4642	.4115	.4281	.4138	.4150

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 202 / 11 KV Nagarsoga Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4024	.7209	.5487	.5636	.503	.407	.431
4	.6554	.8048	.6516	.6962	.5935	.4694	.6962
6	.7956	.8478	.8383	1.0277	.6516	.663	.8288
8	.6962	.8478	.7827	.7293	.78	.7287	.8619
10		.2743		.4024	.2591	.2778	.6173
12	.2683	.1989	.0995	.2155	.2675	.2652	.5407
14	.3018	.1658	.1989		.2294	.2652	.4801
16	.3277	.1829	.1989	.2883		.2652	.503
18	.3521	.2743	.3647	.3041	.4161	.2984	.3521
20	.4694	.5967	.6299	.503	.6371	.5304	.6706
22	.4973			.5087	.5548		.5801
23		.6104	.3978			.431	
24	.3887	.4475	.4801	.3315	.3856	.4508	.3978
Max	.7956	.8478	.8383	1.0277	.78	.7287	.8619
Min	.2683	.1658	.0995	.2155	.2294	.2652	.3521
Avg	.4686	.4977	.4719	.5064	.4798	.4210	.5800

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154058 / 33KV Nagaarsoga S/S

Feeder No / Name : 203 / 11KV Gadavewadi Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.2012	.1658	.1658	.1989	.1677	.1696	.2321
4	.3277	.2012	.1823	.2652	.2543	.2321	.3048
6	.4973	.3052	.3315	.2652	.3601	.3563	.3647
8	.3315	.2374	.1989	.1989	.2543	.1943	.2652
10	.8048	1.0277	.7293	.8048	.7125	.463	.1372
12	1.073	1.094	1.0277	.8785	.5792	.5967	.0983
14	.8718	1.1603	1.0608	1.0059	.6882		.112
16	1.0159	1.1603	1.1934	.6952	.6882	.663	.1341
18				.096	.16	.1326	.3353
20	.2515	.1989	.2321	.2515	.3018	.2984	.7545
22	.2155			.2035	.2427	.2321	.663
23		.1989	.1989				
24	.192	.1823	.1989	.1989	.1677	.1734	.1989
Max	1.073	1.1603	1.1934	1.0059	.7125	.663	.7545
Min	.192	.1658	.1658	.096	.16	.1326	.0983
Avg	.5257	.5393	.5018	.4219	.3814	.3192	.3000

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154065 / 33KV Bbeta S/S

Feeder No / Name : 201 / 11 KV Andhora feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4545	.4187	.3658	.3791	.3852	.3901	.4287
2	.4924	.4354	.3677	.4158	.4187	.4116	.4287
3	.567	.5024	.4074	.4531	.4187	.4099	.4001
4	.6348	.5861	.4854	.5308	.4354	.5271	.4268
5	.7834	.6699	.7906	.7938	.5359	.7182	.4572
6	.9316	.8541	.9571	.9431	.7536	.8488	.5506
7	.8935	.6866	.9986	.9808	.6866	.9808	.6154
8	.8173	.4522	.8659	.9026	.7871	.9798	.5992
9	.6275	.7871	.7042	.7938		.4607	.6009
10	.9211	.6003	.7516	.6699	.6699	.5053	.4715
11	.9043	.6955	.6836	.9378	.7819	.6539	.3009
12	.8708	.823	.6698	.9211	.7579	.743	.2611
13	.8708	.8228	.7106	.9378	.7836	.8025	.2609
14	.8541	.8022	.8407	.9713	.8086	.8025	.2957
15	.8373	.7934	.8516	1.0048	.7109	.5357	.296
16	.8373	.8351	.8517	1.0048	.4636	.5639	.2969
17	.2512		.2282	.9713	.5271	.6203	.4099
18	.3349	.2281	.2649	.4522	.4472	.4066	.4904
19	.6699	.5959	.5687	.5861	.5926	.6283	.7037
20	.6364	.5281	.6845	.5359	.5613	.5544	.5914
21	.5024	.5121	.756	.5024	.4668	.5175	.4649
22	.4354	.4539	.6048	.4187	.4091	.4435	.4481
23	.4019	.3982	.4909	.4019	.4066	.3881	.4124
24	.455	.3684	.3957	.4154	.3684	.3873	.3868
Max	.9316	.8541	.9986	1.0048	.8086	.9808	.7037
Min	.2512	.2281	.2282	.3791	.3684	.3873	.2609
Avg	.6660	.6022	.6373	.7052	.5729	.5950	.4416

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154065 / 33KV Bheta S/S

Feeder No / Name : 202 / 11 KV Bheta Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3791	.2573	.2646	.3973	.4801	.3018	.2641
2	.3409	.2894	.2667	.3955	.5121	.3041	.2452
3	.3799	.2894	.2662	.422	.5601	.3362	.2452
4	.455	.3216	.3416	.4518	.5761	.3695	.2829
5	.4944	.402	.5681	.8011	.6081	.3834	.3772
6	.5698	.4824	.7204	.4687	.6401	.3839	.6036
7	.5975	.4663	.6268	.503	.6562	.6126	.6036
8	.5201	.402	.5319	.5299	.6401	.5243	.679
9	.417	.3698	.4175	.4365	.5121	.6224	.5319
10	.2573	.1886	.3416	.2251	.3216	.2452	.2364
11	.193		.2282	.1608	.1512	.132	.2643
12			.1129	.1286	.1135	.132	.2969
13		.1304	.1143	.0965	.1491	.132	.285
14	.0804	.1303	.1143	.1126	.1472	.1509	.25
15	.0804	.1463	.1143	.1286	.1471	.1612	.2507
16	.0965	.1774	.1143	.1608		.1254	.2396
17	.7236	.6465	.7099	.193	.189		.2945
18	.7075	.618	.791	.2894	.3423	.2241	.3613
19	.7236	.956	.8418	.3538	.4527	.5415	.4749
20	.7075	.6382	.7097	.402	.455	.4481	.4373
21	.6754	.6054	.6117	.3538	.4162	.3734	.362
22	.6562	.5693	.5826	.3377	.3412	.2987	.3423
23	.6401	.5533	.5137	.2894	.4183	.2614	.2659
24	.3166	.611	.5273	.4733	.402	.3269	.2614
Max	.7236	.956	.8418	.8011	.6562	.6224	.679
Min	.0804	.1303	.1129	.0965	.1135	.1254	.2364
Avg	.4551	.4205	.4346	.3380	.4014	.3213	.3523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 201 / 11KV Shivali Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4915	.4049	.4096	.4801	.3201	.3277
2	.4915	.4049		.4801	.4001	.3277
3	.4915	.4049	.4096	.4801	.4001	.3277
4	.4915	.4049	.4915	.4801	.4001	.3277
5	.4915	.4858	.4096	.6401	.4801	.3277
6	.4915	.4858	.7373	.6478	.4801	.4096
7	.6554	.7287	.7373	.7287	.8002	.4915
8	.6554	.7287	.8192	.7287	.4858	.4915
9	.3277	.3277	.4915	.3239		
10	.3239	.3277	.4572	.3239		
11	.2458			.3239		
12	.2458		.3048	.2429		
13	.2458		.3048			.4915
14	.2458		.3048			.4915
15	.2458		.3048			
16			.3048			.4915
17	.2458		.3048			
18	.3277		.3048	.3125		.4915
19	.4096			.4744		.4915
20	.4915		.3048	.4744		.5735
21	.4096		.3048	.4744		.4915
22	.4096		.3048	.4744		.4915
23	.3277		.3048	.3953		.4096
24	.3277	.3277		.3277	.4049	.3277
Max	.6554	.7287	.8192	.7287	.8002	.5735
Min	.2458	.3277	.3048	.2429	.3201	.3277
Avg	.3952	.4574	.4158	.4639	.4635	.4324

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 202 / 11KV Jaifal Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3277	.3277	.3239	.3239	.3277
2	.3277	.3277	.3277	.3239	.3239	.3277
3	.3277	.3277	.3277	.3239	.3239	.3277
4	.3277	.3277	.3277	.3239	.3239	.3277
5	.3277	.4096	.4096	.3239	.4049	.3277
6	.3277	.4915	.4096	.3239	.4096	.4096
7	.3277	.4915	.4096	.3239	.4858	.4096
8	.3277	.4001	.3277	.3239	.3239	.4096
9	.5601	.5735	.4915	.7287		
10	.5668	.6554	.4572	.7287		
11	.5668		.6859	.7287		
12	.6478		.6859	.8097		
13	.5668		.6859	.8097		.2458
14	.5668		.6859	.8097		.2458
15	.6478		.6859	.8097		.2458
16	.5668		.6859	.8097		.2458
17	.2429		.3048	.2429		.6554
18	.3239		.3048	.3239		.8192
19	.4049		.3048	.4049		.8192
20	.3277		.3048	.4049		.7373
21	.3277		.3048	.4049		.7373
22	.3277		.3048	.3239		.6554
23	.3277		.3048	.3239		
24	.3239	.3277	.3277	.3239	.3163	.3277
Max	.6478	.6554	.6859	.8097	.4858	.8192
Min	.2429	.3277	.3048	.2429	.3163	.2458
Avg	.4132	.4236	.4330	.4825	.3596	.4527

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154067 / 33KV SHIVALI S/S

Feeder No / Name : 203 / 11KV Warwada Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.1638		.3239	.1619	.2458
2	.3239	.1638		.3239	.1619	.2458
3	.3239	.1638		.3239	.1619	.3277
4	.3239	.3277		.3239	.2429	.3277
5	.3239	.4096		.3239	.3239	.3277
6	.3239	.4915		.3239	.3239	.3277
7	.3239	.4096		.3239	.3239	.3277
8	.3277	.4096		.3239	.3239	.3277
9	.3277	.2458		.3239		
10	.3277	.0819		.3239		
11	.0819			.081		
12	.0819			.081		
13	.0819		.2286	.081		.1638
14	.0819		.2286	.081		.1638
15	.0819		.2286	.081		.1638
16	.0819			.081		.1638
17	.3277		.5335	.2429		
18	.4096		.4572	.3239		.1638
19	.4915		.4572	.4049		.2458
20	.4915		.6097	.4858		.3277
21	.4915		.6097	.4049		.3277
22	.4096		.6097	.3239		.2458
23	.4096		.4572	.3239		.6554
24	.4858	.3277		.4858	.3239	.2458
Max	.4915	.4915	.6097	.4858	.3239	.6554
Min	.0819	.0819	.2286	.081	.1619	.1638
Avg	.3024	.2904	.442	.2800	.2609	.2803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 201 / 11KV Gondri SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.5792	.7468	.9335		.3439	.7167
2	.6935	.6097	.7773	.9335		.3439	.7167
3	.7108	.7011	.823	1.0269		.362	.7356
4	.7545	.7621	.884	1.0269		.3898	.811
5	.8139	.823	.8383	1.0269		.443	.9431
6	.8383	.9602	.9755	1.1203		.4733	1.0562
7	.8551	.884	1.0974			.583	1.094
8	.8886	.9145	1.2193			.3681	.9808
9	.8383	.884	1.1431			.6371	.6413
10	.4527		.6001	.5868	.7042	.6602	.4024
11	.3353	.3601	.5601		.6706	.3961	.5487
12	.3048	.2572	.4668		.6097	.3961	.6249
13	.2896	.2915		.5868	.6249	.3584	
14	.3048	.2572	.4108	.6706	.5182	.3584	
15	.2743	.3086	.4481	.4904		.415	
16	.2896	.2743	.4481	.4904		.3772	.6516
17	.3353	.3086	.4481	.4527	.4527	.3395	.6859
18	.3506	.4458	.5228	.6224	.7167	.6224	.5144
19	.3658	.7202	.6535	.7202	.9431	.811	.8573
20	.3963	.9945	1.0269	.7545	.9997		.8573
21	.4572	.9431	.9335		.9431	.811	.9431
22	.5182	.8916	.9335	.4715	.9242	.7545	.8916
23	.4572	.8402			.7922	.7545	
24	.6335	.5335	.6706			.3292	.7356
Max	.8886	.9945	1.2193	1.1203	.9997	.811	1.094
Min	.2743	.2572	.4108	.4527	.4527	.3292	.4024
Avg	.5343	.6324	.7558	.7446	.7416	.4925	.7704

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154074 / 33KV DHANORA/Gondri

Feeder No / Name : 202 / 11KV Dhanora

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.5182	.3772	.5601	.415	.4527	.439
2	.5658	.5487	.3429	.5601	.415	.4338	.439
3	.5658	.5792	.4115	.5601	.4338	.5093	.4525
4	.6036	.6249	.4287	.5601	.4904	.6036	.4656
5	.7167	.6401	.5144	.6535	.547	.679	.4607
6	.7167	.6554	.6516	.6535	.6413	.6979	.4733
7	.7733	.6097	.703	.7468	.7167	.7356	.583
8	.7356		.6001	.6535	.6602	.679	.6706
9	.5847	.4268	.4458	.5601	.5658	.5658	.6371
10	.5197		.503		.4694	.4862	
11	.5792	.6249	.9335	.5281	.4725	.503	.2401
12	.6859	.6554	1.1203	.6413	.4877	.5533	.2058
13			1.1203		.5182	.6539	
14	.5792		1.1203	.7922	.5487	.7209	
15	.6097		1.1203	.8383		.7922	
16	.6554	.7316	1.1203	.7377		.7209	
17	.6706			.8718	.503	.6371	.2743
18	.2134	.7773	.2614	.4527	.3772	.3584	
19	.3086	.5144	.5228	.5847	.5281	.5847	
20	.2896	.7202	.6535	.6036	.6036	.6413	.6516
21	.3353	.6687	.6535	.5658	.4715	.5847	.6001
22	.3658	.6001	.5601	.4715	.4904	.4904	.5487
23	.3963	.5144	.5601	.415	.4715	.415	.5144
24	.5847	.4877	.4458		.415	.4527	.4338
Max	.7733	.7773	1.1203	.8718	.7167	.7922	.6706
Min	.2134	.4268	.2614	.415	.3772	.3584	.2058
Avg	.5496	.6054	.6596	.6195	.511	.5813	.4759

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418] BU 5185

Substation No/ Name :- 154092 / 33KV Wanwada S/S

Feeder No / Name : 201 / 11KVBorfal Feeder SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018			
2	.3521			
3	.3481			
4	.4144			
5	.4424			
6	.5735			
7	.5571			
9		.218		.3277
10				.1966
12				.1341
13		.1174		.1341
14				.1341
15		.116		.1509
16		.1341		.1341
17			.1509	
18			.2012	
19			.218	
20			.3018	
21			.3353	
22			.3018	
24	.3018			
Max	.5735	.218	.3353	.3277
Min	.3018	.116	.1509	.1341
Avg	.4114	.1464	.2515	.1731

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 201 / 11 KV NEW MIDC FEEDER.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1698	.2263	.1886	.2452		.132
2	.1886	.1698	.2263	.2075	.2641	.2075	.132
3	.2075	.1698	.2452	.2075	.2452	.2075	.132
4	.2075	.1698	.2263	.2075	.2641	.2075	.132
5	.2075	.1886	.2263	.2075	.2641	.2075	.1509
6	.2075	.1886	.2452	.2263	.2641	.2075	.1509
7	.2452	.2075	.2263	.2075	.2829	.2075	.1886
8	.2263	.1886	.2263	.2263	.3206	.2075	.1886
9	.2075	.1886	.2452	.2263	.2829	.1698	.2075
10	.2263	.2829	.3206	.2452	.3395	.2263	.2641
11	.2075	.3395	.3584	.2641	.3206		.3395
12	.2075	.3961	.3961	.2263	.3961		.3772
13	.1886	.3395	.3584	.2263	.3395	.1698	.3395
14		.3395	.3018	.2452	.3206	.1698	.3018
15	.2263	.2829	.3018	.2641	.3206	.2075	.3206
16	.2452	.3018	.3018	.2829	.2829	.2075	.2641
17	.2452	.3772	.2829	.3018	.2829	.2075	.3018
18	.2263	.3395	.2641	.2829	.2829	.1886	.3018
19	.2075	.3584	.2641	.2829	.2641	.1698	.2829
20	.1886	.2641	.2641	.2452	.2075	.1509	.2641
21	.1886	.2452	.1886	.2452	.1886	.1509	.1886
22	.1886	.2263	.1886	.2641	.2075	.1509	.1509
23	.1886	.2263	.1886	.2641	.2075	.1509	.1509
24	.2075	.1886	.2263	.1886	.3206		.1509
Max	.2452	.3961	.3961	.3018	.3961	.2263	.3772
Min	.1886	.1698	.1886	.1886	.1886	.1509	.132
Avg	.2099	.2562	.2625	.2389	.2798	.1886	.2256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 202 / 11 KV CHOWRASTA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.6201	.6733	.6201	.6201		.6024
2	.5316	.5493	.6556	.6201	.6024	.6024	.6024
3	.5493	.5493	.6556	.6379	.6024	.6024	.6024
4	.5493	.567	.6556	.6201	.6379	.5847	.6024
5	.567	.6201	.7087	.6556	.6379	.6379	.6379
6	.6733	.7087	.7973	.7619	.7442	.7087	.7087
7	.7796	.815	.8682	.7973	.7973	.7796	.8682
8	.7973	.7265	.8328	.9214	.691	.8682	.8505
9	.7619	.7087	.7265	.9036	.7442	.8505	.7796
10	.6201	.691	.6733	.7796	.691	.7265	.7087
11	.6379	.6379	.6556	.7265	.6024	.6556	.6201
12	.6379	.7087	.7087	.7442	.6201	.7442	.6556
13	.567	.6379	.6733	.691	.6201	.7265	.6733
14	.567	.6556	.7442	.691	.6556	.7087	.5493
15	.567	.567	.7087	.6556	.691	.7087	.567
16	.6733	.6201	.6733	.6556	.6379	.6556	.567
17	.691	.6733	.6556	.6379	.7442	.6201	.6733
18	.7442	.7087	.6733	.691	.7796	.6733	.815
19	.8505	.8859	.9568	.8859	.8682	.9391	.8682
20	.8859	.9922	1.0099	.7973	.9036	.9391	.9036
21	.7796	.9214	.9036	.7973	.8328	.8682	.815
22	.815	.8505	.7973	.7973	.7442	.7973	.7442
23	.7442	.7796	.6733	.815	.691	.7087	.7087
24	.5493	.6733	.691	.6379	.7087		.6556
Max	.8859	.9922	1.0099	.9214	.9036	.9391	.9036
Min	.5316	.5493	.6556	.6201	.6024	.5847	.5493
Avg	.6696	.7028	.7405	.7309	.7028	.7321	.6991

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

AUSA (R) S/DN[418]

BU 5185

Substation No/ Name :- 154112 / 33 KV MIDC SUB-STATION AUSA.

Feeder No / Name : 203 / 11 KV SAMTA NAGER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6335	.6697	.7602	.7602	.8869		.7059
2	.6335	.6516	.7421	.7421	.8869	.7468	.6878
3	.6516	.6516	.724	.7421	.905	.7059	.6878
4	.6697	.6697	.724	.7602	.905	.7059	.6878
5	.6697	.7059	.7964	.7783	.9412	.7602	.7059
6	.8145	.8145	.9412	.9593	.9231	.8688	.7602
7	.9412	.9412	1.0136	1.1222	1.0317	.9412	.905
8	.9593	.9231	.9593	1.0498	1.0136	.8326	.8507
9	.9955	.8326	.8688	.9774	.8688	1.0136	.8145
10	.8507	.8688	.724	.8145	.8688	.7421	.7964
11	.7602	.8145	.8145	.8869	.8145	.8688	.7421
12	.7421	.8145	.8688	.8145	.7421	.8688	
13	.724	.8507	.8145	.8507	.6697	.8326	.7783
14	.6697	.8507	.8326	.8326	.7602	.7964	.7059
15	.6516	.7783	.7602	.7421	.7783	.8688	.7059
16	.724	.7964	.8145	.6878	.724	.7421	.5792
17	.724		.8326	.8145	.7783	.724	.6878
18	.8688	.905		.8145	.8688	.7602	1.0136
19	.9955	1.1403	1.2127	.8507	1.0498	1.1584	1.2308
20	1.0317	1.2127	1.2308	.8145	1.0679	1.1584	1.1765
21	.9412	1.1041	.9412	.9412	.9774	.9412	.8869
22	.9231	.9955	.905	.8145	.8869	.8688	.8507
23	.8326	.905	.8869	.8326	.8326	.8145	.7783
24	.6516	.7421	.7964	.7964	.8688		.7421
Max	1.0317	1.2127	1.2308	1.1222	1.0679	1.1584	1.2308
Min	.6335	.6516	.724	.6878	.6697	.7059	.5792
Avg	.7941	.8538	.8680	.8417	.8771	.8509	.8035

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154008 / 33 kv s/s killari

Feeder No / Name : 203 / 11 kv Old Killari Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.4287	.3429	.2572		
2	.3429	.2572	.3944	.3944	.3429		
3	.3772	.2572	.4801	.4115	.3772		
4	.1372	.2058	.3086	.12	.1715		
5	.1715	.1543	.3429	.1372	.1372		
6	.1715	.12	.2915	.1372	.1029		
7	.1372	.2401	.2572	.1543	.1372		.6859
8	.1029	.463	.3086	.3772	.1715		.6001
9	.1715	.5316	.5316	.6687			.6001
10	.1715	.5487	.5658	.6001		.3429	.4287
11	.1715	.4801	.4115	.5658			.5144
12		.5144	.4458	.5144			.3429
13		.4801	.4801	.4458			.2572
14	.4115	.5487	.4115	.3772	.3429		.3772
15	.3429	.4287	.4458	.4287			.5144
16	.3944	.4115	.0171	.0171		.6001	.463
17	.0857	.0343	.0343	.0171		.1543	.4287
18	.12	.3086	.0343	.1372			.3944
19	.3601	.3772	.3258	.2572			.4287
20	.4801	.4287	.3772	.4287			.3944
21	.4115	.5144	.3429	.4801			.5144
22	.3772	.4287	.3429	.4115			.4801
23	.3429	.4115	.3258	.3429			.3429
24	.2743	.3086	.3258	.3086	.3086		
Max	.4801	.5487	.5658	.6687	.3772	.6001	.6859
Min	.0857	.0343	.0171	.0171	.1029	.1543	.2572
Avg	.2666	.3644	.3429	.3365	.2349	.3658	.4569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 201 / 11 KV Jawali Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2715	.2801	.2801	.2715	.381	.2686
2	.2715	.2715	.2801	.2801	.2715	.4763	.2658
3	.362	.362	.2801	.2801	.3506	.4763	.2658
4						.543	.3506
5						.5144	.4382
6						.5716	.5258
7						.5716	.5316
8						.5144	.5316
9						.4668	.5258
10	.2743	.3429	.2801	.2486		.3201	.2629
11	.3429	.3429	.3315	.3315		.3201	.1867
12	.3429	.3429	.4144	.4382		.3953	.2801
13	.2629	.3506	.4144	.4287	.2572	.3953	.3734
14	.2629	.3429	.4668	.3353	.2715	.381	.3734
15	.2629	.3429	.4668	.3429	.3658	.381	.4668
16	.2629	.3429	.4144	.3429	.3658	.381	.4668
17	.2715	.3429	.4144	.3429	.2572	.381	.2801
18	.2715	.2829	.1867	.2572	.2629	.2658	.3734
19	.543	.3734	.2801	.2715	.5487	.3506	.3734
20	.5258	.3772	.3734	.362	.5487	.5258	.5601
21	.4525	.2715	.3734	.362	.4525	.443	.4668
22	.362	.2801	.2801	.2715	.3506	.3506	.3734
23	.362	.2743	.2801	.2715		.3506	.3734
24	.2715	.2629	.2801	.2801	.2715	.2858	.2572
Max	.543	.3772	.4668	.4382	.5487	.5716	.5601
Min	.2629	.2629	.1867	.2486	.2572	.2658	.1867
Avg	.3320	.3210	.3387	.3182	.3461	.4184	.3822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 203 / 11 KV Kharosa Feeder

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.181	.2572	.2486	.181	.2572	.1677
2	.1829	.181	.3429	.2486	.181	.2572	.1677
3	.181	.181	.3429	.2486	.1753	.2572	.1677
4	.2715	.2629	.4239	.3315	.2629	.3429	.2515
5	.2715	.2572	.4239	.3315	.2572	.3429	.2515
6	.3506	.3353	.503	.3315	.3429	.3391	.3353
7	.4287	.4049	.503	.3315	.4287	.3391	.4191
8	.4096	.4191	.4239	.3315	.4191	.4287	.4191
9	.3239		.4239	.3315	.4191	.4287	.4191
10						.2515	.1677
11						.0838	.1658
12						.0838	.1658
13							.2486
14							.2486
15							.3315
16	.181	.0848	.1867			.0838	.4144
17	.181	.0857	.1867	.0905		.1677	.4144
18		.1753	.1867	.181		.2515	.3734
19	.3506	.3429	.2801	.1753	.2743	.3353	.4668
20	.4382	.3429	.3734	.2629	.362	.4191	.3734
21	.3506	.2543	.3734	.2715	.3582	.3353	.2801
22	.3506	.2572	.2801	.2715	.2715	.2515	.2801
23	.181	.2572	.2801	.181	.2801	.1677	.1867
24	.181	.1753	.2801	.2486	.181	.2801	.1677
Max	.4382	.4191	.503	.3315	.4287	.4287	.4668
Min	.181	.0848	.1867	.0905	.1753	.0838	.1658
Avg	.2833	.2469	.3373	.2598	.2930	.2716	.2868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154026 / 33/11 KV LAMJANA SUBSTATION

Feeder No / Name : 204 / 11 KV Lamjana II SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.362	.4525	.4668	.362	.5716	.2858
2	.362	.4382	.4668	.3734	.362	.5716	.2858
3	.4525	.5258	.5601	.3734	.4382	.5716	.2858
4						.6668	.2715
5						.8962	.2686
6						.6859	.3544
7						.9526	.5716
8						.8145	.6401
9						.7316	.4763
10	.362	.3582		.2486	.3506	.5868	.6668
11	.4382	.3429	.3315	.3315	.3429	.3353	.5601
12	.4287	.3353	.3315	.4382	.3429		.5601
13	.3353	.3429	.3315	.4287	.3429	.3315	.5601
14	.3353	.3429	.3315	.3429	.3429	.3506	.6535
15	.3277	.3391	.4144	.3429	.3429	.2372	.5601
16	.3239	.3506	.4144	.3429	.3429	.2629	.7468
17	.3277	.3391	.4144	.4382		.3544	.8402
18	.3506	.5144	.3734	.5144	.543	.6401	.8402
19	.6135	.7468	.5601	.6001	.7468	.7621	.8402
20	.7716	.7468	.7468	.6859	.8145	.905	.9335
21	.6135	.5487	.5601	.5258	.7011	.7621	.7468
22	.543	.543	.5601	.4525	.543	.5716	.5601
23	.4525	.4382	.4668	.4525	.4525	.4763	.3734
24	.3658	.362	.4477	.4668	.362	.4763	.1905
Max	.7716	.7468	.7468	.6859	.8145	.9526	.9335
Min	.3239	.3353	.3315	.2486	.3429	.2372	.1905
Avg	.4314	.4432	.4567	.4348	.4549	.5876	.5447

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 201 / 11 KV Tambarwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.4287	.3429	.3429	.362	.3429
2		.4287		.3429	.3429	.4525	
3		.4287	.5144	.4287	.4525	.4525	
4		.5144	.5144			.6335	
5		.5144	.6859			.724	
6		.6001	.6859			.8145	
7		.6001	.8573			.905	
8			.8573				
9			1.0288				
10		.4287	.6001	.5144	.543		
11	.543		.6001	.5144	.8145		
12	.543	.543	.5144	.5144	.905		.2715
13	.543	.4525	.6001	.5144	1.086		.2715
14	.543		.6001	.5144	1.086		
15	.543	.543	.6001	.5144	.8145		.362
16	.543	.543	.6001	.6001	.905		.362
17	.543	.543	.6859	.3429	.724		.362
18	.4525	.2715	.3429	.3429	.6335		.362
19	.4525	.4525	.4287	.4525	.543		.5293
20	.543	.4525	.4287	.4287	.6335		.5293
21	.4525	.4287	.4287	.3429	.6335		.5293
22	.4287	.5144	.3429	.3429	.543		.4287
23	.4287	.4287		.3429	.4525		.4287
24		.4287	.4287	.3429		.4525	
Max	.543	.6001	1.0288	.6001	1.086	.905	.5293
Min	.4287	.2715	.3429	.3429	.3429	.362	.2715
Avg	.5045	.4730	.5806	.4300	.6738	.5996	.3983

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 202 / 11 KV Shivani-Luc SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.2572	.1715	.1715	.16	
2		.3429		.1715	.16	.16	
3		.5144	.2572	.1524	.16	.16	
4		.5144	.3429	.1524	.16	.2401	
5		.6001	.3429	.1524	.16	.2401	
6		.6001	.4287	.2286	.16	.2401	
7		.6001	.4287	.2572	.2401	.3201	
8		.5144	.5144	.2286	.2401		
9		.4287	.6001	.3429	.16		
11							.16
12							.16
15		.08					.16
16		.08	.0857		.08		.16
17		.08	.0857	.0857	.08		.16
18	.08	.08	.1715	.0857	.08		.16
19	.16	.16	.2286	.2401	.16		.2401
20	.2401	.2401	.1429	.2572	.16		.2401
21	.16	.1715	.1524	.1715	.2401		.16
22	.0857	.1715	.1524	.1715	.16		.1715
23	.1715	.1715		.1715	.16		.1715
24		.1715	.1715	.1715		.2401	
Max	.2401	.6001	.6001	.3429	.2401	.3201	.2401
Min	.08	.08	.0857	.0857	.08	.16	.16
Avg	.1496	.2996	.2727	.1890	.1607	.2201	.1767

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 203 / 11 KV Kharosa SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7716	.0772		.3429	.6889	
2		.7716			.3429	.775	
3		.8573			.4306	.8612	
4		.8573	.8573		.4306	.8612	
5		.9431	1.0288		.5167	1.0334	
6		1.0288	1.1145		.5167	1.0334	
7		1.0288	1.1145		.6889	1.2056	
8		.1115	1.2003		.6889		
9		1.286	1.2003		.6889		
11				.3429			
12				.3429			.3445
13							.4306
15		.4306					
16		.4306			.6889		.3445
17		.4306	.6001	.4287	.8612		.3445
18	.6889	.6028	.6859		.8612		.5167
19	.9473	.9473	.8573	1.2056	.8612		.6028
20	1.2056	1.2056	1.1145		1.0334		1.0334
21	1.1195	.8573	1.0288		1.0334		1.0334
22	.0857	.6859	1.1145	.7716	.8612		
23	.7716	.7716		.7716	.775		.7716
24		.7716	.8573	.3429		.775	
Max	1.2056	1.286	1.2003	1.2056	1.0334	1.2056	1.0334
Min	.0857	.1115	.0772	.3429	.3429	.6889	.3445
Avg	.8031	.7784	.9180	.6009	.6837	.9042	.6024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718]

BU 4718

Substation No/ Name :- 154055 / 33 KV SUB STATION KHAROSA

Feeder No / Name : 204 / express feeder

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.1715	.0857	.0857	.0936	
2		.1715		.0857	.0857	.0936	
3		.1715	.1715	.0857	.0936	.0936	
4		.1715	.1715	.0857	.0936	.0936	
5		.1715	.1715	.0857	.0936	.0936	
6		.1715	.1715	.2572	.0936	.0936	
7		.1715	.1715	.3429	.4682	.0936	
8		.3429	.4287	.4287	.4682		
9		.3429	.4287	.4287	.4682		
10		.3429	.3429	.4287	.4682		
11	.4682	.4682	.3429	.4287	.4682		.3746
12	.4682	.4682	.4287	.3429	.4682		.3746
13	.4682	.3746	.4287	.3429	.3746		.2809
14	.4682	.3746	.4287	.3429	.3746		
15	.3746	.3746	.4287	.3429	.3746		.1873
16	.3746	.3746	.4287	.3429	.3746		.3746
17	.3746	.3746	.4287	.3429	.3746		.3746
18	.2809	.2809	.4287	.3429	.3746		.2809
19	.2809	.2809	.4287	.0936	.3746		.2809
20	.2809	.2809	.4287	.3429	.3746		.0936
21	.2809	.2572	.4287	.3429	.3746		.0936
22	.1715	.2572	.4287	.3429	.3746		.0857
23	.0857	.2572		.3429	.3746		.0857
24		.0857	.2572	.0857		.0936	
Max	.4682	.4682	.4287	.4287	.4682	.0936	.3746
Min	.0857	.0857	.1715	.0857	.0857	.0936	.0857
Avg	.3367	.2808	.3430	.2789	.3250	.0936	.2406

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 201 / 11 KV Yelli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7514	.6328	.9669		.717	.7438
2		1.0332	.6328	1.0413	.8453	.7183	.8182
3		1.221	.8326	.9669	1.0332	.8659	.8925
4						.8992	.9669
5						.8992	.7438
6						.9669	.595
7						1.0336	.7438
8						.9669	.8182
9						.8659	.8925
10		.7502	.9669	.7438		.4163	.7438
11		.7502	.8925	.7506	.4995	.4649	.3381
12		.766	.8182		.4664	.3719	.3006
13		.7993	.7438	.5636	.5995	.4463	
14		.7993	.8182	.5636	.6413	.4463	.3006
15		.7327	.8925	.5636	.6121	.4649	.3381
16		.7956	.8182	.526		.595	
17		8.4186	.7438	.5636	.5247	.6694	.3006
18		.5328	.8925	.2614	.6668	.595	.7514
19		.6661	.9669		.7183	.8182	.9768
20		.8002	1.0413	1.1271	.7381	.8925	1.2023
21		.8326	1.1157		.787	.9669	.9393
22		.8326	.9669	.8453	.7777	.8925	.7514
23	.9393	.7993	.8925	.9017	.8326	.8182	.7514
24	.9017	.6661	.8925	.5228	.7993	.6694	.5636
Max	.9393	8.4186	1.1157	1.1271	1.0332	1.0336	1.2023
Min	.9017	.5328	.6328	.2614	.4664	.3719	.3006
Avg	.9205	1.2193	.8645	.7272	.7028	.7275	.7033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 202 / 11 KV Kinnithot SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.263	.2664	.2975		.2016	.3347
2			.2997	.3347	.263	.2498	.3719
3		.3006	.2997	.3719		.2501	.3719
4			.333	.4091	.2818	.2664	.3347
5		.3757	.3668	.4091		.2298	.4463
6			.3996	.4463	.3006	.3334	.4649
7			.4022	.4463		.3668	.3719
8		.3757	.4372	.373	.3006	.3996	.3719
9		.3945	.2915	.4649	.3006	.3663	.3719
10						.1998	.2975
11						.1488	.3006
12						.1859	.3006
13						.1859	.3006
14						.2231	.263
15						.2231	.2254
16		.0999	.1488	.1127		.2231	.2254
17		.1001	.1859	.1127	.1457	.2231	.263
18		.1001	.2231		.1724	.2975	.2254
19		.1998	.2975		.2298	.3719	
20		.2997	.3719	.3945	.2726	.4091	.4508
21		.333	.3347		.333	.3347	.4696
22		.3663	.3719	.3006	.316	.3719	.3757
23	.3643	.3663	.3719	.2442	.2915	.3719	.3757
24	.2818	.2664	.3347	.263	.2307	.3347	.3381
Max	.3643	.3945	.4372	.4649	.333	.4091	.4696
Min	.2818	.0999	.1488	.1127	.1457	.1488	.2254
Avg	.3231	.2744	.3187	.3320	.2645	.2820	.3414

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154068 / 33 KV SUB STATION YELLI

Feeder No / Name : 203 / 11 KV Tupadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2254	.2818	.2603	.3347		.2334	.2975
2			.2997	.3719	.3006	.2334	.2975
3	.3006	.3006	.3338	.3719		.2334	.3347
4			.333	.3347	.3381	.2501	.373
5			.3497	.3347		.2667	.3719
6		.4133	.3663	.3719	.3757	.3334	.4463
7			.4081	.4649		.3668	.4463
8		.4696	.4662	.4463	.3757	.3668	.3719
9		.3945	.3206	.3719	.3757	.4005	.4463
10						.1332	.2231
11						.1116	.3006
12						.1116	.3006
13						.1116	.3006
14						.1116	.3006
15						.1488	.3006
16		.0333	.1116	.0939		.1488	.3006
17		.0999	.1116	.1503	.1457	.1488	.3003
18		.0999	.1488	.1503	.1457	.2231	.2254
19		.1665	.1859		.1724	.2975	.3757
20		.1998	.2231	.2128	.2329	.2975	.4133
21		.3004	.2975		.2692	.3719	.3757
22		.2997	.2975	.2622	.2972	.3347	.3006
23	.2254	.2664	.3347	.1879	.2332	.3357	.263
24	.2818		.373	.2254	.2016	.2975	.2254
Max	.3006	.4696	.4662	.4649	.3757	.4005	.4463
Min	.2254	.0333	.1116	.0939	.1457	.1116	.2231
Avg	.2583	.2558	.2901	.2929	.2664	.2445	.3288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 201 / 11 KV Limbala Feeder SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3239		.2429	
2		.3048	.3239	.2572	.2429	.2572
3		.4049	.4049		.2429	
4		.4049	.4049	.2572	.3239	.2572
5		.4049	.4049		.3239	
6		.4858	.4687	.2572	.3239	.3429
7		.4858	.4687		.4049	
8		.4858	.3125	.3429	.4049	
9		.4049	.2429		.4049	
10	.2286	.4049	.3429	.4287	.4049	.1715
12						.1715
13						.1715
14						.1715
16						.1372
18						.1372
19	.2429	.2429		.2429		.1715
20	.3239	.362		.3239	.3429	
21	.3239	.3239		.3429		
22	.3239	.3239		.3239	.3429	.1715
23	.2429	.2429	.3429	.3239	.3429	
24	.1619	.2429	.2429	.2572	.2429	.2572
Max	.3239	.4858	.4687	.4287	.4049	.3429
Min	.1619	.2429	.2429	.2429	.2429	.1372
Avg	.264	.3656	.357	.3053	.3280	.2015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 202 / 11 KV Mangrool SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3239		.3239	
2		.3239		.4287	.3239	.3429
3		.3239			.3125	
4		.3239		.5144	.4049	.3429
6						.5144
8						.5144
9						.3429
10						.3429
11	.381	.381		.5144	.4049	
12	.4572	.4572	.4287	.4858	.5144	.5144
13	.4049	.5335		.4858	.5144	.6859
14	.4858	.5335	.8573	.4858	.6001	.6859
15	.4572	.4572	.8573	.4858	.6859	
16	.4687	.4572	.8573	.4858	.6001	.6859
17	.4687	.4572		.5668	.5144	
18	.5468	.5335	.6859	.6478	.5144	.8573
19	.4049	.381		.4049		
20	.4858	.4858	.5144	.4858	.3429	.3429
21	.4858	.4858		.4687		
22	.4858	.4858		.4858		.2572
23	.4049	.4049	.4287	.4049	.1715	
24		.4049	.4049	.4287	.4049	.1715
Max	.5468	.5335	.8573	.6478	.6859	.8573
Min	.381	.3239	.3239	.4049	.1715	.1715
Avg	.4567	.4308	.5954	.4862	.4422	.4715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 204 / 11 KV SARANI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4049	.4049		.4049	
2		.4858	.4858		.4049	.3429
3		.4858	.4858		.4049	
4		.4858	.5668		.4858	.3429
5		.5668	.6478		.4858	
6		.5668	.6478		.4858	.5144
7		.6478	.7287		.5668	
8		.6478	.7287	.5144	.5668	.6001
9		.5668	.5668	.6859	.5668	
10		.5182	.5668	.5658	.4049	.5144
12						.2058
13						.2058
14						.2572
18						.3944
19	.4049	.4049		.4049		
20	.4858	.4858		.4858	.5144	
21	.4858	.4858	.5144	.4858		
22	.4858	.4858		.4858	.5144	.463
23	.4049	.4049		.3906	.3944	
24		.4049	.4049		.4049	.3429
Max	.4858	.6478	.7287	.6859	.5668	.6001
Min	.4049	.4049	.4049	.3906	.3944	.2058
Avg	.4534	.5030	.5624	.5024	.4718	.3803

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154069 / 33 / 11 KV MANGROOL

Feeder No / Name : 205 / 11 KV BANEGAON FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1619	.1524		.1619	
2		.1619	.1619	.1715	.1619	.0857
3		.1619	.1619		.1619	
4		.1619	.1619	.1715	.1619	.1715
6						.2058
8						.1715
9						.1715
10						.1372
11	.2429	.1619		.1677	.1134	
12	.2429	.2429	.2429	.1619	.1715	.1715
13	.2429	.2572		.1943	.1715	.1715
14	.2429	.2429	.3429	.1943	.2058	
15	.2429	.2429	.2572	.1943	.2058	
16	.2429	.2429	.2572	.1943		
17	.1943	.2429	.2572	.2429		
18	.1943	.2429	.2058	.2429	.1715	.12
19	.1619	.1619		.1562		
20	.1619	.1619	.1715	.1619	.0857	
21	.1619	.1619		.1619		
22	.1619	.1619		.1619	.0857	.1029
23	.1619	.1619	.1715	.1619	.0857	
24		.1619	.1619	.1715	.1619	.0857
Max	.2429	.2572	.3429	.2429	.2058	.2058
Min	.1619	.1619	.1524	.1562	.0857	.0857
Avg	.2043	.1942	.2082	.1819	.1504	.1450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 201 / 11 KV Karla SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.2321	.1524	.2286	.2286	.2286	.2286
2	.1524	.1966	.1524	.2286	.2286	.2286	.2286
3	.1524	.1966	.1524	.3048	.1524	.2286	.3048
4	.2286	.2294	.2286	.381	.3048	.3048	.3048
5	.2286	.2622	.2286	.3048	.3048	.3048	.381
6	.2286	.3277	.2286	.3048	.3048	.3048	.381
7	.2286	.3277	.2286	.2286	.3048	.2286	.381
8	.3048	.2622	.2286	.2286	.2286	.2286	
9	.1658	.1658	.1524	.1524	.2286	.2286	
10	.2486	.1638	.1524	.1524	.1524	.1524	
16	.1658						.1524
17	.2743	.2286	.2286	.3048	.2286	.2286	.1524
18	.2743	.3048	.2286	.3048	.2286	.3048	.2286
19	.1829	.3048	.2286	.3048	.2286	.3048	.2286
20	.2591	.3048	.3048	.3048	.3048	.3048	.2286
21	.2267	.2286	.3048	.2286	.3048	.3048	.3048
22	.2267	.2286	.381	.2286	.381	.2286	.3048
23	.2267	.2286	.2286	.2286	.2286	.2286	.2286
24	.1524	.2267	.2286	.2286	.2286	.2286	.2286
Max	.3048	.3277	.381	.381	.381	.3048	.381
Min	.1524	.1638	.1524	.1524	.1524	.1524	.1524
Avg	.2147	.2455	.2244	.2582	.254	.254	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 202 / 11 KV Kumtha SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1943	.3048	.3048			.2286
2	.2286	.1943	.3048	.3048			.2286
3	.3048	.1943	.381	.381			.2286
4	.3048	.2591	.381	.381			.2286
5	.3048	.3239	.4572	.4572			.3048
6	.2743	.3887	.4572	.6097			.3048
7	.2439	.3795	.4572	.4572			.2743
8	.2286	.3795	.4572	.381	.3048		.2286
14							.3048
15	.1658	.0762	.1524	.0762	.1524		.1524
16	.1658	.0762	.1524				.1524
17	.1989	.1524	.2286		.1524		.2286
18	.2321	.1524	.2286	.1524	.1524		.3048
19	.3978	.1524	.2286	.2286	.1524		.3048
20	.3315	.1524	.1524	.2286	.2286		.2286
21	.2984	.1524	.1524	.2286	.2286		.2286
22	.2652	.1524	.1524		.2286		.2286
23	.2652	.1524	.2286		.1524		.1524
24	.1524	.2321	.1524	.3048			.1524
Max	.3978	.3887	.4572	.6097	.3048	.3048	.381
Min	.1524	.0762	.1524	.0762	.1524	.1524	.1524
Avg	.2551	.2092	.2794	.3211	.1947	.2311	.2489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154093 / 33 KV SUB STATION KARLA

Feeder No / Name : 203 / 11 KV Sirsal SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1989		.2286	.1524	.1524	.1524
2	.2286	.1989		.3048	.3048	.2286	.2286
3	.1524	.1989		.3048	.3048	.2286	.2286
4							.2286
5							.3048
6							.3048
7							.3048
9	.4049	.3239		.1524	.3048	.2286	
10	.2429	.3239		.3048	.3048	.1524	
11	.2915	.2286		.2286	.2286		
12	.2915	.2286		.2286	.2286	.2286	
13		.2286		.2286	.3048	.2286	
14	.2915	.2286		.3048	.3048	.2286	
15	.253	.2286		.2286	.2286	.2286	
16	.2214	.2286		.1524	.3048	.2286	
17							.1524
18	.1989	.1524	.1524	.2286	.1524	.2286	.2286
19	.3647	.1524	.1524	.2286	.1524	.2286	.0762
20	.3978	.1524	.1524	.2286	.1524	.2286	.0762
21	.2984	.1524	.2286	.2286	.2286	.2286	.1524
22	.2652	.0762	.2286	.2286	.2286	.1524	.2286
23	.2652	.0762	.2286	.1524	.2286	.1524	.1524
24	.2286	.2321	.0762	.2286	.1524	.1524	.1524
Max	.4049	.3239	.2286	.3048	.3048	.2286	.3048
Min	.1524	.0762	.0762	.1524	.1524	.1524	.0762
Avg	.2721	.2006	.1742	.2328	.2371	.2062	.1981

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 201 / 11 KV Chincholi (T) SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3715	.3658					
4			.1905				
9				.4458		.2896	.2743
10	.4572		.3429				
11	.3963						
12	.3658					.3286	
13	.3963						
14	.442						
15	.3963					.3429	
16	.3658		.4668	.4268			.2439
17	.4268						
18	.3048					.3525	
19	.6097						
20	.7316						
23			.4115				
24		.6097			.4572		
Max	.7316	.6097	.4668	.4458	.4572	.3525	.2743
Min	.3048	.3658	.1905	.4268	.4572	.2896	.2439
Avg	.4387	.4878	.3529	.4363	.4572	.3284	.2591

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 202 / 11 KV Utka SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2058						
6	.2896	.3048					
8			.2134				
9	.3525			.362		.1067	.1448
12						.0724	
15						.0667	
16	.1067		.0943	.1219			.1677
17	.1524						
18	.1829					.0943	
19	.2286						
20	.2286						
23			.1791				
24		.1829			.2439		
Max	.3525	.3048	.2134	.362	.2439	.1067	.1677
Min	.1067	.1829	.0943	.1219	.2439	.0667	.1448
Avg	.2184	.2439	.1623	.2420	.2439	.0850	.1563

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

KILLARI S/DN.[718] BU 4718

Substation No/ Name :- 154099 / 33 / 11 Tapse - Chincholi

Feeder No / Name : 203 / 11 KV Gotewadi SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.141						
6	.1296	.1524					
8			.1905				
9	.1858			.12		.0914	.0914
12						.0191	
15						.0191	
16	.0152		.0191	.0152			1.4937
17	.0152						
18	.0152					.0191	
19	.0152						
23			.0381				
24		.1219			.061		
Max	.1858	.1524	.1905	.12	.061	.0914	1.4937
Min	.0152	.1219	.0191	.0152	.061	.0191	.0914
Avg	.0739	.1372	.0826	.0676	.061	.0372	.7926

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 201 / 11 KV SHINDKHED GAOTHAN GAOTHAN FEEDER
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2486		.1658		.1658		
3	.2486	.2515	.2486	.2515	.1989		
5						.2058	
7					.3239		.3315
8						.2629	.3277
9					.3315	.2543	
10		.1658		.1326		.1677	.2515
11	.2429	.3315	.2515		.1696		
12		.3315		.2486		.1658	.2486
14	.2486	.3315	.3239	.3315		.2458	
15						.2515	
16				.0829		.1174	
17					.1638	.1989	
18				.1989	.1658	.2515	.1943
19					.2458	.2486	
20		.3315	.4191	.1638		.2515	
21					.1658		
22		.2486		.1619			.1677
23	.1677						
24		.1658		.1658		.1677	.1311
Max	.2486	.3315	.4191	.3315	.3315	.2629	.3315
Min	.1677	.1658	.1658	.0829	.1638	.1174	.1311
Avg	.2313	.2697	.2818	.1931	.2145	.2146	.2361

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 204 / 11 KV HADGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973		.4973		.3315		
3	.4144		.4973		.4144		
4		.6478					
5	.5801		.663		.5801	.5935	
7	.663	1.065	.9116	.8383	.7459		.8192
8						.8383	.7373
9		1.0774	.9717	.7459	.8288	.9116	
10						.3315	.5668
11					.2515		
12						.2515	.8097
14						.2515	
15						.2543	
16			.1696	.1829		.2486	
17		.3734			.3201	.3353	
18	.3239			.3734	.3353	.4096	.4191
19		.4572			.4973	.503	
20			.6783	.4668		.5801	
21		.5544			.503		
22				.4668			.5087
23	.4915						
24		.4973		.3734		.3353	.503
Max	.663	1.0774	.9717	.8383	.8288	.9116	.8192
Min	.3239	.3734	.1696	.1829	.2515	.2486	.4191
Avg	.4950	.6675	.6270	.4925	.4808	.4495	.6234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154003 / 33/11 KV NILANGA

Feeder No / Name : 206 / 11 KV DHANORA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203		.8402				
3	.9335	.9221	1.0269	.9116	1.0269		
5						.8288	
7							.7202
8							.7202
9					.7468	.8802	.7459
10		.4144		.3315		.5801	
11		.7459	.8288		.5868		
12				.663		.663	.2515
13		.3315					
14	.7907			.7459		.663	
15		.663	.9488			.7459	
16			.9488	.7459		.5801	
17		.8288			.4801	.6401	
18	.4144			.8288	.5801		.7459
19		.9145			.9116	.9012	
20			1.0059	.5487		.8802	
21		1.0059			.6554		
22				.7468			.763
23	.7545						
24		.823		.7468		.663	.4915
Max	1.1203	1.0059	1.0269	.9116	1.0269	.9012	.763
Min	.4144	.3315	.8288	.3315	.4801	.5801	.2515
Avg	.8027	.7388	.9332	.6966	.7125	.7296	.6340

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 201 / 11 KV KASAR SHIRSHI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7468	.8215				.3734
2	.7095	.7468	.8215				
3	.9335	.8215	.8962	.7716			.3734
4					.6001	.6001	.3734
5							.4668
6							.4668
7							.5601
8					.7716	.6859	.6535
9				.5144			
10	.7095					.3429	.1867
11	.6348						
12	.5975		1.2003	.7716	.5144	.5144	
13	.8402					.7468	.2241
14	.8402			.8573			.2241
15						.7468	
16	.7468		.6859	.7716	.2572		.2801
17						.6535	.3361
18	.7468				.3429		.4854
19			.5144				.7468
20	.8402					.9335	
21	.8402					.7468	.7468
22						.7095	.7468
23	.7468		.7716		.6859	.5601	.6722
24	.6535	.7468	.8589	.7716	.6001	.6859	.3734
Max	.9335	.8215	1.2003	.8573	.7716	.9335	.7468
Min	.5975	.7468	.5144	.5144	.2572	.3429	.1867
Avg	.7495	.7655	.8213	.7430	.5389	.6605	.4606

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154009 / 33/11 KV KASAR SHIRSHI

Feeder No / Name : 204 / 11 KV RAMLING MUDGAD SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6737	.5182	.4146				.4534
2	.6737	.5182	.4405				.4534
3	.7125	.4664	.4664				.4664
4	.7125	.5182	.4664		.7716	.9431	
5	.7773	.57					.57
6	.7125	.6219	.6737				.5182
7	.6478	.881	1.0364				
8	.8421	.8032	1.1401			1.0288	.6478
9	.7773		1.0364		1.2003	.9431	.583
10	.7773			1.0288			.5182
12				1.2003			.5959
13					.3429		.6737
14							.6996
15							.6996
16	.2591		.1715			.3239	.57
17							.6737
18					.5144		
19			.6859			.5182	.7255
20	.5182					.7125	
21	.6219						.6737
22			.6859			.5182	.6478
23	.57				.6859	.4664	.6478
24	.6737	.57	.4146		.7716	.8573	.4664
Max	.8421	.881	1.1401	1.2003	1.2003	1.0288	.7255
Min	.2591	.4664	.1715	1.0288	.3429	.3239	.4534
Avg	.6633	.6075	.6360	1.1146	.7145	.7013	.5939

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 201 / 11 KV TAGARKHEDA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7					.3429		
8	.3429	.3429	.2572	.2572			
16	.0857	.0857	.0857	.1715		.0857	.3429
17					.1715		
22			.0857				
24	.0857	.4287	.0857		.0857		.0857
Max	.3429	.4287	.2572	.2572	.3429	.0857	.3429
Min	.0857	.0857	.0857	.1715	.0857	.0857	.0857
Avg	.1714	.2858	.1286	.2144	.2000	.0857	.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 202 / 11 KV HALGARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6859	.6859	.7716	.7716	.5144		
15							.3429
16	.1715	.1715	.1715	.5144	.3429	.2572	
22			.4287				
24	.3429	.3429	.3429		.3429		.3429
Max	.6859	.6859	.7716	.7716	.5144	.2572	.3429
Min	.1715	.1715	.1715	.5144	.3429	.2572	.3429
Avg	.4001	.4001	.4287	.643	.4001	.2572	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 203 / 11 KV SAWARI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4287	.5144	.4287	.5144	.4287		
16	.1715	.1715	.1715	.1715	.1715	.1715	.2572
22			.1715				
24	.1715	.1715	.1715		.1715	.1715	.1715
Max	.4287	.5144	.4287	.5144	.4287	.1715	.2572
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.2572	.2858	.2358	.3430	.2572	.1715	.2144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 204 / 11 KV SHIRSHI HANGARGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144	.5144	.6001	.6001	.5144		
16	.1715	.1715	.1715	.1715	.1715	.1715	.2572
22			.2572				
24	.2572	.2572	.2572		.2572		.2572
Max	.5144	.5144	.6001	.6001	.5144	.1715	.2572
Min	.1715	.1715	.1715	.1715	.1715	.1715	.2572
Avg	.3144	.3144	.3215	.3858	.3144	.1715	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 205 / 11 KV SAWARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6001	.6859	.8573	.5144			
16		.0857	.0857	.0857		.0857	.3429
17					.0857		
24	.2572	.2572	.3429				.0857
Max	.6001	.6859	.8573	.5144	.0857	.0857	.3429
Min	.2572	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.4287	.3429	.4286	.3001	.0857	.0857	.2143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 206 / 11 KV HALGARA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16	.6859		.8573	.5144		.5144	
18					.2572		
22				.0857			
24	.0857	.0857	.0857	.0857	.0857		.2572
Max	.6859	.0857	.8573	.5144	.2572	.5144	.2572
Min	.0857	.0857	.0857	.0857	.0857	.5144	.2572
Avg	.3858	.0857	.4715	.2286	.1715	.5144	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 207 / 11 KV TAGARKHEDA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13					.1715	
16	.2572	.5144	.5144	.4287		.3429
22			.0857			
24	.0857	.0857				
Max	.2572	.5144	.5144	.4287	.1715	.3429
Min	.0857	.0857	.0857	.4287	.1715	.3429
Avg	.1715	.3001	.3001	.4287	.1715	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 208 / 11 KV KHANDSARI

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(NON-CONTINUOUS PROCESS)(NO
STAGGERING)

DATE	26-AUG-17
HR	Load (MW)
8	.4287
Max	.4287
Min	.4287
Avg	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154016 / 33/11 KV HALGARA

Feeder No / Name : 209 / 11 KV SHIRSHI HANGARGA AG FEEDER SEPERATION/PURE AG
Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5144	.7716	.9431	.4287	
16					.3429
24	.2572	.2572	.3429		
Max	.5144	.7716	.9431	.4287	.3429
Min	.2572	.2572	.3429	.4287	.3429
Avg	.3858	.5144	.643	.4287	.3429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 202 / 11 KV TUPADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.3506		.3601	.2561	
4	.463						.0509
6			.6516		.3988	.2561	
7						.2534	
8	.5533		.8573		.373		.0671
9				.6783			
10					.0362		.0857
11						.0838	.208
12				.0343			
13					.0876		.2107
14				.0343		.0671	
16	.0905	.1029					
17					.124		.1966
18	.1097		.0762	.0514			
20		.1214			.128		
21				.052			
22			.0739				.0732
23		.1227	.4666		.128		
24			.1029			.1267	.1029
Max	.5533	.1227	.8573	.6783	.3988	.2561	.2107
Min	.0905	.1029	.0739	.0343	.0362	.0671	.0509
Avg	.3041	.1157	.3684	.1701	.2045	.1739	.1244

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 204 / 11 KV GOUR FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.6588		
4					.5935
6			.7802		
7		.7011			
8			.8669		.9054
9		.7716			
10					.7545
11	.6325			.7461	.4666
12		.7461			
13		.6443			.3462
14				.8048	
16		.6706		.9835	
17					.4807
18	.3277	.3391			
21		.5487			
22	.7316				.7164
24					.583
Max	.7316	.7716	.8669	.9835	.9054
Min	.3277	.3391	.6588	.7461	.3462
Avg	.5639	.6316	.7686	.8448	.6058

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154027 / 33/11 KV PANCHINCHOLI

Feeder No / Name : 205 / 11KV SHARADA CON.EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS
 FDR Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.009		.0213	.0128	
4	.0105						.0125
6					.0283	.0109	
7				.0097		.011	
8	.0105		.077		.0124		.0103
9			.0107	.0195			
10		.0106					.0105
11					.0301	.156	.1672
12		.0171		.0177			
13							.0794
14		.0103		.0602	.0941	.0947	
16				.0425		.1818	
17					.0088		.0103
18			.0171	.0106			
20					.011		
21				.0089			
22			.0133				.0112
23		.1134			.0128		
24			.0106			.1267	.0105
Max	.0105	.1134	.077	.0602	.0941	.1818	.1672
Min	.0105	.0103	.009	.0089	.0088	.0109	.0103
Avg	.0105	.0379	.0230	.0242	.0274	.0848	.0390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 202 / 11 KV TAMBALA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.9534		1.43	1.0656	.7945	.3178
16				.2383	.2383	
24	.3224	.3227				
Max	.9534	.3227	1.43	1.0656	.7945	.3178
Min	.3224	.3227	1.43	.2383	.2383	.3178
Avg	.6379	.3227	1.43	.6520	.5164	.3178

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154035 / 33/11 KV KASAR BALKUNDA

Feeder No / Name : 203 / 11 KV TAKLI FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7227		.6424	.8107	.7227	.4015
12	.3212					
16		.3212		.3212	.2409	
18	.803					
24	.5621	.6424				
Max	.803	.6424	.6424	.8107	.7227	.4015
Min	.3212	.3212	.6424	.3212	.2409	.4015
Avg	.6023	.4818	.6424	.5660	.4818	.4015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 201 / 11 KV LAMBOTA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4458	.3772	.3765	.3768	.1932	.2972	.381
2	.3715	.3957	.4141	.3768	.1932	.2972	.3048
3	.3715	.4145	.4706	.4706	.208	.2972	.3048
4	.2972	.4145	.4706	.4706	.208	.3048	.381
5					.208	.2972	.4572
6					.208	.3715	.4572
7					.2229	.381	.5335
8					.1932	.381	.5335
9	.5201	.8462	.9393	1.0332		.4572	.4572
10		.9393	.9393	1.126		.5335	.4572
11	.5647	1.0342		1.0332		.4572	.3048
12	.8462	1.1271	.5641	1.0332		.5335	.3048
13		1.1271	.9393	1.0332	.5201	.6097	.381
14	.8462	1.1271	1.0332	1.126	.4458		.3048
15	.9393		1.201	1.126	.3715		.381
16	.8462	.7153	1.2198	1.126	.2972	.4572	
17	.9393			.4141	.2	.3048	
18				.4701	.2972	.3048	
19	.3768	.245	.2826	.3761	.2972	.4572	.4572
20	.4711	.245	.3768	.4706	.2972	.4458	.5335
21	.4711	.3768	.4145		.2972	.4572	.5335
22	.4145	.3392	.3768	.2261	.2667	.4572	.5335
23	.3768	.3388	.3768	.2261	.2972	.4572	.5335
24	.4458	.3768	.3392	.3768	.245	.2972	.4572
Max	.9393	1.1271	1.2198	1.126	.5201	.6097	.5335
Min	.2972	.245	.2826	.2261	.1932	.2972	.3048
Avg	.5614	.6141	.6314	.6785	.2733	.4026	.4282

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 204 / 11 KV JAJNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.3768	.4706		.2972	.3567	.381
2	.2972	.3768	.4706		.2972	.3715	.3048
3	.2972	.3768	.4894		.3269	.3715	.3048
4	.3715	.3957	.5647		.3269	.4458	.381
5	.3715	.5647	.7522		.3121	.5201	.4572
6	.3715	.8471	.8462		.3715	.5944	.4572
7	.4458	1.126	1.0509		.5201	.535	.5335
8	.5944	.9402	1.1447		.5944	.6097	
9	.2972		.4894			.4268	.4572
10	.3768		.3576				.5335
11	.2824		.245	.535			.5335
12	.1884		.1886	.5796			.5335
13				.5647		.1486	.5335
14				.5498		.2286	
15					.1486	.2286	.3048
16					.1635	.2286	.3048
17				.4458	.2229	.2286	.3048
18				.4755	.2972	.3048	.381
19	.5647	.6023	.5647	.4904	.3715	.4572	.4572
20	.5647	.6205	.6023	.5201	.5201	.5335	.4572
21	.4711	.5265	.5647	.5201	.4458	.4572	.381
22	.4141	.4518	.4706	.3121	.3715	.4572	.381
23	.4141	.4141	.3768	.3121	.3715	.381	.381
24	.2972	.3772	.4141		.2972	.3418	.381
Max	.5944	1.126	1.1447	.5796	.5944	.6097	.5335
Min	.1884	.3768	.1886	.3121	.1486	.1486	.3048
Avg	.3843	.5712	.5591	.4823	.3476	.3918	.4157

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154046 / 33/11 KV ZARI

Feeder No / Name : 205 / 11KV KELGAON SPP SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2972	.9393	.7522	.3768	.4458	.4458	.3048
2	.3334	.8453	.8453	.3768	.5053	.5201	.3048
3	.2972	.9393	.8453	.3768	.5201	.5944	.381
4	.2972	1.0332	.9393	.8462	.5944	.6687	.381
5	.5201	1.2198	1.0332	.9393	.7133	.743	.381
6	.743	1.4075	1.126	1.2198	.743	.8173	.381
7	.8173	1.4075	1.3887	1.3512	.7876	.8173	.381
8	1.0402	1.3136	1.2748	1.4075	.8173	.743	.381
9					.6984	.5201	.381
10					.6687	.4572	.3048
11			.6023		.5944	.6097	.3048
12			.4706		.4458		.3048
13					.2972	.1524	.3079
14					.2229	.2286	.3048
15	.6588	.4522	.5647	.5053	.2229	.3048	.3048
16	.6588	.4711		.4755	.4161	.3048	
17	.8471	.7529	.7529	.5201	.5944	.2972	
18	.9402	.8086	1.0332	.5944	.4458	.3715	.3048
19	.8462	.8453	.9393	.5201		.4458	.4618
20	.9402	.8641	.9393	.5944	.3864	.3715	.4572
21	.8462	.8266	.8462	.4458	.4458	.3715	.4572
22	.8462	.6017	.8462	.2972	.4458	.2972	.5335
23	.6588	.677	.7522	.3715	.4458	.2972	.4572
24	.2972	.9393	.7514	.3768	.4458	.4458	.2972
Max	1.0402	1.4075	1.3887	1.4075	.8173	.8173	.5335
Min	.2972	.4522	.4706	.2972	.2229	.1524	.2972
Avg	.6603	.9080	.8791	.6442	.5175	.4706	.3672

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 201 / 11 KV AURAD

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.0943	
16	.4668		.4144			.362
24		.0924		.0566	.0943	
Max	.4668	.0924	.4144	.0566	.0943	.362
Min	.4668	.0924	.4144	.0566	.0943	.362
Avg	.4668	.0924	.4144	.0566	.0943	.362

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 202 / 11 KV SHELGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8					.0566
16	.0343				
19			.0566		
24		.1715		.2743	.0377
Max	.0343	.1715	.0566	.2743	.0566
Min	.0343	.1715	.0566	.2743	.0377
Avg	.0343	.1715	.0566	.2743	.0472

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 203 / 11 KV SHELGI GAOTHAN
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.6335	.7293	.6874	.499	.724
16	.2957		.218			.2715	
17				.3185			
24		.3734		.3429	.3856	.2801	
Max	.2957	.3734	.6335	.7293	.6874	.499	.724
Min	.2957	.3734	.218	.3185	.3856	.2715	.724
Avg	.2957	.3734	.4258	.4636	.5365	.3502	.724

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 204 / 11 KV AURAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.8402	.7459	.7042	.6468	.8962
9					.4908		
16	.543					.7468	
19			.6371				
24		.462		.4908	.4801	.3734	
Max	.543	.462	.8402	.7459	.7042	.7468	.8962
Min	.543	.462	.6371	.4908	.4801	.3734	.8962
Avg	.543	.462	.7387	.6184	.5584	.589	.8962

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154056 / 33/11 KV AURAD

Feeder No / Name : 205 / 11KV GRAM PANCHYAT AURAD

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.6535	.4973	.2515	.3696	.6535
16	.1829		.1677			.2801	
24		.181		.1772	.2035	.1867	
Max	.1829	.181	.6535	.4973	.2515	.3696	.6535
Min	.1829	.181	.1677	.1772	.2035	.1867	.6535
Avg	.1829	.181	.4106	.3373	.2275	.2788	.6535

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 201 / 11 KV MUGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1715			
3	.2572	.2429	.2458			.1638	.1715
6				.2572			.2572
7					.2429	.2458	
8					.2429	.2458	
10	.2429	.2458	.2572	.2401		.2572	.1677
13					.3277		
14	.3201						
15					.3277		
16			.3429		.2458	.3429	.1619
17							.1619
18	.16	.1638		.3239	.1638		
19							.2458
20			.2572			.0257	
21					.2458		.2429
22	.2401			.1619			
24	.1715	.16	.2458	.1715	.16	.2458	.1715
Max	.3201	.2458	.3429	.3239	.3277	.3429	.2572
Min	.16	.16	.2458	.1619	.16	.0257	.1619
Avg	.2320	.2031	.2698	.2210	.2446	.2181	.1976

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 203 / 11 KV MASALGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1905			
3	.2858	.2829	.2858			.1905	.1905
6				.2858			.3429
7					.2829	.2858	
8					.2829	.2858	
10	.3734	.2858	.2858	.3772		.2858	.1829
13					.381		
14	.3772			.3772			
15					.381		
16			.381		.381	.381	.1867
17							.1867
18	.1848	.1905		.1867	.1905		
19							.2829
20			.2858			.2858	
21					.2858		.2772
22	.2801			.1886			
24	.1905	.1867	.1905	.1867	.1867	.1905	.2858
Max	.3772	.2858	.381	.3772	.381	.381	.3429
Min	.1848	.1867	.1905	.1867	.1867	.1905	.1829
Avg	.2820	.2365	.2858	.2561	.2965	.2722	.2420

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 204 / 11 KV WATER WORKS
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	27-AUG-17
HR	Load (MW)
16	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154063 / 33/11 KV MASALGA

Feeder No / Name : 205 / 11 KV Aambegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2				.1715			
3	.1715	.1638	.1619			.1619	.1715
6				.1715			.2572
7					.1658	.1619	
8					.1638	.1619	
10		.1619	.2572	.2486		.2572	.1658
13					.1619		
14	.3315			.3315			
15					.1943		
16			.2572		.1619	.3429	
17							.1677
18	.1658	.1619		.1677	.1619		
19							.1696
20			.1715			.1715	
21					.1619		.1677
22	.1638			.1658			
24	.1715	.1658	.1619	.1715	.1677	.1619	.1715
Max	.3315	.1658	.2572	.3315	.1943	.3429	.2572
Min	.1638	.1619	.1619	.1658	.1619	.1619	.1658
Avg	.2008	.1634	.2019	.2040	.1674	.2027	.1816

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154072 / 33/11 KV BORSURI

Feeder No / Name : 201 / 11 KV SONKHED

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6935	.5201	.8669	.6935	.7202
2			.5201	.8669	.6935	.6859
3		.6935	.5201	.8669	.6935	.7202
4		.8669	.5201	.8669	.6935	.6859
5		1.0402		.8669	.8669	.9088
6		1.0402		1.0402	1.0402	1.0802
7		1.0402		1.0402	1.0402	1.2003
8		1.1269	.6935	1.0402	1.0402	1.0802
9		1.2136	.6935	.8669	1.0402	.9431
10					.5201	.3601
11			.3467	.6935	.5201	
12			.3467	.1734		
15				.1734		
16			.3467	.5201	.6001	
17		.3353	.5201	.5201		
18	.3467	.3353	.8669	.6935		
19			.7802	.6935		
20			.7802	.6935		
23		.6706				
24	.2601	.6935		.5201	1.3431	
Max	.3467	1.2136	.8669	1.0402	1.3431	1.2003
Min	.2601	.3353	.3467	.1734	.5201	.3601
Avg	.3034	.8125	.5735	.7224	.8296	.8385

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154072 / 33/11 KV BORSURI

Feeder No / Name : 203 / 11 KV CHANDORI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)
11	.4334	
16		1.5604
Max	.4334	1.5604
Min	.4334	1.5604
Avg	.4334	1.5604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 201 / 11 KV NITUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	25-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5	.6562			
8			1.1065	
11		.9374		
13				.6661
16	.5304	.8619		.3467
20	1.1763			
22				.6706
23	.8048			
24	.6249		.4793	
Max	1.1763	.9374	1.1065	.6706
Min	.5304	.8619	.4793	.3467
Avg	.7585	.8997	.7929	.5611

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 202 / 11 KV SHEND FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.6687			.3353	.3963
5	.6874					
8		1.0364			.6706	.4298
10	.25			.8048		.4298
11			.4374			
13						.2317
16			.3567			.2134
19					.6859	
20	.6908			.4024		
22			.3144			.3658
24	.25	.3353		.2538	.285	.301
Max	.6908	1.0364	.4374	.8048	.6859	.4298
Min	.25	.3353	.3144	.2538	.285	.2134
Avg	.4696	.6801	.3695	.487	.4942	.3383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154078 / 33/11 KV NITUR

Feeder No / Name : 203 / 11 KV BASPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4458			.4024	.3048
5	.5312					
8				.8718		.5014
10	.3125					
11			.4999			
12		.407		.4191		
13						.2606
16		.407	.3864	.4694		.2401
17	.431					
19					.6516	
20	.9335			.6706		
22			.3144			.3658
24	.25	.3048	.3315	.2538	.2683	.2408
Max	.9335	.4458	.4999	.8718	.6516	.5014
Min	.25	.3048	.3144	.2538	.2683	.2401
Avg	.4916	.3912	.3831	.5369	.4408	.3189

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 201 / 11 KV NANAND

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.506	.6097	.3605	.4938	.6097	.3605
2		.5312	.7621	.426	.5312	.6097	.3932
3	.1677	.6325	.7621	.4915	.7499	.6097	.426
4	.1677	.7865	.9145	.5571	.7811	.7621	.4915
5	.2622	.8223	.9145	.6226	.8951	.7926	.5898
6	.3277	.9804	1.0669	.6882	.9259	.9145	.6882
7	.4588	1.1069	1.2193	.8192	.9568	1.0364	.8192
8	.852	1.2811	1.2193	.9717	.9259	1.0364	.9717
9	.8192	1.2498	1.1888	.9717	.7407	1.0688	
10					.4877	.3605	.5624
11					.3048	.2949	.5864
12					.2134	.2294	.6249
13					.2134		.679
14					.2134	.2294	.7099
15					.2134	.2294	.7099
16	.253	.2439	.2622	.3125	.2134	.2294	.759
17	.2812	.2743	.3277	.2812	.2439	.2949	.7716
18	.3749	.3048	.3932	.4111	.4572	.3932	.4012
19	.7499	.3048	.6226	.6874	.6706	.6882	.5693
20	.8223	.3048	.8192	.8124	.4572	.6554	.6009
21	.6009	.3048	.6882	.7274	.3658	.5898	.4687
22	.4687	.2778	.5243	.6081	.2743	.4915	.4062
23	.3795	.2134	.3932	.3795	.2439	.3932	.3437
24	.5571	.4687	.4268	.2949	.463	.4572	.3277
Max	.852	1.2811	1.2193	.9717	.9568	1.0688	.9717
Min	.1677	.2134	.2622	.2812	.2134	.2294	.3277
Avg	.4714	.5886	.7286	.5791	.5015	.5642	.5766

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 202 / 11 KV JEWRI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2949	.3163	.2134	.3277	.3395	.1524	.2294
2	.3605	.3479	.2743	.4588	.3395	.1829	.2294
3	.5243	.506	.4572	.5898	.4744	.1829	.2622
4					.6249	.2439	.2949
5					.6562	.2743	.3605
6					.679	.3658	.3605
7					.6642	.3963	.426
8					.6958	.3658	.3932
9					.6562	.3605	.4428
10	.2214	.2743	.3048	.426	.2778	.2622	.4428
11	.2846	.2134	.2949	.2812	.2439	.2622	.2214
12	.2214	.2134	.2294	.25	.2134	.2294	.1543
13	.2187	.2134	.2622	.2187	.2134	.2622	.1852
14	.2812	.2134	.2622	.253	.2134	.2949	.2214
15	.3125	.2134	.2622	.1852	.2134	.2949	
16	.25	.1829	.2949	.1966	.2134	.3277	
17	.2187	.2743	.3277	.2214	.2134	.3277	
18	.4062	.3048	.3932	.3749	.2743	.426	.4938
19	.7274	.3201	.6882	.7186	.3048	.5571	.7907
20	.7499	.3048	.6882	.759	.2743	.5898	.5693
21	.5864	.3048	.5898	.6554	.2134	.4588	.463
22	.4374	.2439	.4588	.5693	.1829	.3605	.3479
23	.2812	.1829	.3277	.3749	.1524	.2949	.2812
24	.2622	.253	.1852	.2622	.3086	.1524	.1677
Max	.7499	.506	.6882	.759	.6958	.5898	.7907
Min	.2187	.1829	.1852	.1852	.1524	.1524	.1543
Avg	.3688	.2713	.3619	.3957	.3601	.3177	.3494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154104 / 33/11 KV NANAND

Feeder No / Name : 203 / 11 KV MALEGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.3437	.3353	.3605	.3086	.3048	.2949
2	.3932	.3749	.4572	.4915	.3932	.3353	.2949
3	.5243	.4744	.4877	.5898	.4938	.4572	.3277
4					.5864	.4877	.3932
5					.6173	.6097	.4915
6					.7956	.7621	.5571
7					.7099	.9145	.5571
8					.6481	.9145	.5243
9					.6481	.8745	.4428
10	.25	.3048	.3963	.4588		.2622	.4428
11	.3125	.4268	.4588	.3795	.2743	.3277	.2846
12	.3437	.4268	.4915	.3795	.2743	.3932	.2214
13	.3163	.4268	.4588	.3704	.3048	.3605	.2846
14	.4481	.3658	.4588	.3704	.3353	.3605	.25
15	.4687	.3658	.4915	.3086	.3353	.3277	.2812
16	.506	.3048	.4915	.3395	.3353	.3277	.2846
17	.4744	.3658	.5243	.3163	.3048	.3277	.3395
18	.4012	.4572	.3605	.3479	.3658	.1966	.5376
19	.6249	.6706	.6882	.7407	.7316	.6226	.8223
20	.5624	.6401	.7537	.7407	.6706	.7209	.6481
21	.5247	.5792	.6226	.5937	.4572	.4915	.5693
22	.5312	.4572	.4915	.463	.3658	.3932	.4111
23	.3163	.3048	.3605	.3749	.2743	.2949	.3125
24	.2949	.2812	.3048	.2949	.3395	.3048	.2294
Max	.6249	.6706	.7537	.7407	.7956	.9145	.8223
Min	.25	.2812	.3048	.2949	.2743	.1966	.2214
Avg	.4234	.4206	.4796	.4400	.4596	.4738	.4084

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 201 / 11 KV SARWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.2105	.381	.2591	.3041	.2743	.2667
2	.3467	.208	.4572	.2778	.3401	.3048	.3239
3	.3641	.2561	.4877	.3086	.3239	.381	.362
4	.4207	.3077	.5182	.3241	.3361	.4268	.4572
5	.4557	.3725	.4877	.4001	.3163	.4572	.5525
6	.4784	.4586	.4572	.4481	.3637	.4877	.6668
7	.4961	.4858	.4877	.4801	.4049	.5335	.724
8	.5316	.4144	.503	.5121	.426	.5487	.5906
9		.3963	.4687	.3932	.4475	.4858	.5716
10					.1334	.4191	.2591
11				.1905	.1143	.2477	.2591
12				.1524	.0953	.1524	.2439
13				.1334	.1143	.1524	.2439
14				.1143		.1334	.2743
15				.0953		.1334	.2591
16		.0953	.1524	.0953		.1715	.2439
17		.1524	.2096	.1334	.2286	.2096	.2286
18		.1715	.2667	.1715	.2667	.2286	.2858
19		.2858	.3429	.3429	.2858	.381	.3048
20		.5906	.5144	.4763	.2858	.5335	.3048
21		.2858	.4191	.362	.3048	.3429	.3239
22		.381		.2477	.2667	.2858	.3239
23		.381	.1981	.2286	.2286	.2286	.2667
24	.2401	.2056	.381	.1981	.1457	.2134	.2286
Max	.5316	.5906	.5182	.5121	.4475	.5487	.724
Min	.2401	.0953	.1524	.0953	.0953	.1334	.2286
Avg	.4066	.3144	.3960	.2759	.2730	.3222	.3569

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 202 / 11 KV MUDGAD EKOJI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2105	.1829	.2229	.1966	.2286	
2	.2881		.1829	.2408	.1943	.2743	
3	.3077	.2267	.1981	.2896	.2105	.3048	
4	.3239	.2753	.1981	.3048	.2267	.3353	
5	.3239	.4096	.2286	.3201	.208	.3353	
6	.3401	.4321	.2896	.3858	.2622	.3506	
7	.3401	.3401	.381	.4012	.3361	.3506	
8	.3725	.3315	.4877	.4374	.4049	.2439	
9		.3353	.4481	.3481	.3605	.2286	
10							.1524
11							.1524
12							.1829
13							.1829
14							.2134
15							.2134
16							.1829
17							.1524
24	.192	.1943	.1524	.1783	.1457	.1905	
Max	.3725	.4321	.4877	.4374	.4049	.3506	.2134
Min	.192	.1943	.1524	.1783	.1457	.1905	.1524
Avg	.3049	.3062	.2749	.3129	.2546	.2843	.1791

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154105 / 33/11 KV MUDGAD EKOJI

Feeder No / Name : 203 / 11 KV KOKALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.381	.5335	.381	.3048	.381	.2286
2	.5906	.4572	.5335	.4954	.381	.4763	.2932
3	.724	.6287	.4763	.5716	.381	.5335	.3549
4					.4001	.6668	.3593
5					.743	.724	.3749
6						.7621	.4062
7					.743	.8573	.3906
8					.8002	.8954	.4218
9					.3429	.6478	.3048
10		.2286	.2429	.2429	.4049	.3048	.4572
11		.2439	.3144		.421	.2675	.1143
12		.2743	.3814	.3149	.4049	.2229	
13		.3048	.3521	.3401		.2378	.1715
14		.2743	.2858		.3277	.2709	.1905
15		.2439	.3081	.2818	.2818	.2709	.1905
16		.2743	.3269	.3401	.2785	.1429	.2286
17		.2286	.3418	.3725		.2477	.2286
18		.1524	.1905	.213		.2858	.2667
19		.4763	.381	.4572		.4763	.2667
20		.7049	.6478	.5335		.724	.3048
21		.6668	.5335	.4572	.3048	.4001	.2858
22		.6478		.381	.3048	.3429	.2858
23		.6097		.3239	.2858	.3048	.2286
24	.3429	.2858	.5716	.2667	.2858	.2858	.1981
Max	.724	.7049	.6478	.5716	.8002	.8954	.4572
Min	.3429	.1524	.1905	.213	.2785	.1429	.1143
Avg	.5335	.3935	.4013	.3733	.4109	.4471	.2849

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 201 / 11 KV HARIJAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.0377	.1143	.381	.0272	.08	.362
2	.362	.0533	.1158	.3429	.0223	.06	.3582
3	.3429	.0777	.1303	.3429	.0223		.362
4	.362	.1257		.3429	.0314		.4525
5	.362	.1383	.1477	.381	.0429	.4287	.4525
6	.4763	.1509	.1387	.4572	.0518	.4508	
7	.4954	.1882	.1143	.5335	.0876	.4161	
8	.3239	.1829	.1143	.4763	.1286	.3467	
9	.3048	.1303	.0886	.381	.132	.2601	
10	.1905	.0429		.2858	.0817	.1734	
11				.0272	.08	.1734	.0503
12						.1734	.0503
13					.0354	.1791	.0503
14				.0503		.1734	
15				.0503	.032	.1791	
16				.0427	.0427	.1791	
17	.6859	.4954		.9335	.2	.7164	
18	.9526	.5525		.8573	.2743	.6268	
19	.7811	.4801		.7811		.6268	.088
20	.7621	.4489		.8002		.5068	.1257
21	.8002	.6563		.8002		.4572	.0939
22	.724			.7621		.4572	.0943
23	.724			.7621		.3658	.088
24	.381	.7049	.4481	.5716	.7621	.0827	.3658
Max	.9526	.7049	.4481	.9335	.7621	.7164	.4525
Min	.1905	.0377	.0886	.0272	.0223	.06	.0503
Avg	.5218	.2791	.1569	.4711	.1208	.3233	.2138

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154107 / 33/11 KV HARIJAWALGA

Feeder No / Name : 202 / 11 KV BHOTMUGLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.362	.2614	.2286	.2667	.2829	.2195
2	.2286	.4382	.2829	.2286	.2286	.3018	.2195
3	.2286	.4763	.3395	.2477	.2667	.3395	.2012
4	.2286	.5335		.2667	.3048	.3772	.2012
5					.3048	.394	.2378
6					.3429	.4344	
7					.4382	.4161	
8			.3734		.4954	.4382	
9	.2469	.3963	.4525	.1219	.3077	.5014	
10	.2743	.3755		.128	.2559		
11	.2801			.3477	.3856	.4477	.1143
12	.2029	.543			.4477	.543	.1143
13	.3201	.5731		.1669	.3772	.5373	
14	.3567	.5144		.3525	.4287	.4477	.1143
15	.3201	.5144		.3807	.3429	.4525	.1334
16	.3109	.5658		.3909	.3353	.4525	.1334
17				.1905	.1867	.1829	.2408
18				.2858	.1886	.1848	.2526
19	.3429	.3361		.3429	.2829	.2195	.1943
20	.4001	.415		.381	.3395	.2218	.2315
21	.381	.3018		.381	.3395	.2195	.2107
22	.3048	.2987		.3429	.2829	.2195	.208
23	.3048			.3048		.2241	.216
24	.2667	.3048	.2641	.2858	.3048	.2614	.2195
Max	.4001	.5731	.4525	.3909	.4954	.543	.2526
Min	.2029	.2987	.2614	.1219	.1867	.1829	.1143
Avg	.2925	.4343	.3290	.2829	.3241	.3522	.1924

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154108 / 33/11 KV AMBULAGA

Feeder No / Name : 201 / 11KV AMBULGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.7287	.6009
2		.7287	.5851
3		.7449	.5693
4		.7611	.6081
5		.7611	.6401
9	.6401		
10	.7287		
11	.6401		
12	.6722		
13	.6722		
14	.6401		
15	.7202		
16	.6401		
17	.6401		
18	.7202		
19	.4687		
20	.5693		
21	.6009		
22	.6722		
24		.6722	.6081
Max	.7287	.7611	.6401
Min	.4687	.6722	.5693
Avg	.6447	.7328	.6019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 201 / NEW BANK COLONY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8682				.8505
2		.8413	.8505	.7712		.7922	.8682
3	.6135		.9214		.7186		.9036
4		.8779	.9391	.8589		.7922	.9214
5	.8238	1.0269	1.0099	.9465		.8676	.9568
6	.9465	1.0425	1.1163	1.0341		1.0751	1.0099
7	1.0517	1.1104	1.1694	1.0867		1.1694	1.1694
8		1.2071	.985		1.1393	1.1273	1.1393
9	.9114	.9745	1.0277	.9991		1.134	.5258
10	.9015	.8859	.9465			1.1104	.9114
11	.8669	.8859	.8764	.8764	1.0277	1.0387	.8413
12		.8505				.9492	.8063
13	.7888	.7619		.7537	.7087	.9134	
14	.7442	.7265	.8238	.7712		.9036	.631
15	.7796	.691			.7442	.8682	
16	.7442	.7442	.8764	.7888	.7164	.8682	.7011
17	.7522	.8328				.8505	.8764
18	.8596	1.0277	1.0166	.8238		.9214	
19		1.0631			1.0974	1.134	1.0341
20	1.0059	1.0454	1.1393	1.1043		1.1517	.9816
21		1.0277				1.0454	.929
22	1.0059	1.0099	.9465	.9114		.9922	
23	.8779	.9568				.9214	.8413
24	.6836	.8596	.9036	.8063	.7712	.9054	.9036
Max	1.0517	1.2071	1.1694	1.1043	1.1393	1.1694	1.1694
Min	.6135	.691	.8238	.7537	.7087	.7922	.5258
Avg	.8445	.9295	.9657	.8952	.8654	.9787	.8901

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVISION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154115 / 33/11 KV ASHOK NAGAR NILANGA

Feeder No / Name : 202 / ASHOK NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2126				.1949
2		.2263	.2481	.1848		.2075	.2126
3	.2218		.2865		.2218		.1949
4		.2641	.3898	.3696		.2641	.2835
5	.499	.4904	.4961	.5359		.415	.4961
6	.6653	.7545	.6447	.7023		.6668	.6201
7	.7947		.6984	.7947		.8573	.7442
8		.5788	.567		.6838	.7733	.7762
9	.5544	.4854	.5847	.7023		.6602	.5544
10	.4108	.443	.4435			.3761	.4435
11	.3361	.3045	.2772	.5914	.3921	.3189	.2957
12	.2241	.2149				.3224	.2218
13	.2241	.124		.2587	.2614	.2126	
14	.2241	.124	.1848	.2033		.1949	.2402
15	.2241	.124			.1867	.2126	
16	.2801	.2126	.2218	.2218	.2195	.2658	.2402
17	.3361	.197				.2686	.3142
18	.3772	.3544	.3511	.3881		.443	
19		.443			.5658	.567	.5544
20	.415	.4119	.5175	.5544		.5493	.499
21		.3366				.3898	.3696
22	.3395	.3189	.3326	.3511		.3012	
23	.2641	.2658				.2328	.2587
24	.2033	.2263	.1949	.2218	.2402	.2263	.1949
Max	.7947	.7545	.6984	.7947	.6838	.8573	.7762
Min	.2033	.124	.1848	.1848	.1867	.1949	.1949
Avg	.3663	.3286	.3913	.4343	.3464	.3966	.3855

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 201 / 11 KV ANASARWADA GAOTHAN GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.8745			.7202
8	.6173	.8402	.7545	.823		.6173
9						.5658
12					.2743	
16			.1886		.2401	.2058
17		.2229				
19	.3944					
20		.6344				
24		.3258	.3429			.3429
Max	.6173	.8402	.8745	.823	.2743	.7202
Min	.3944	.2229	.1886	.823	.2401	.2058
Avg	.5059	.5058	.5401	.823	.2572	.4904

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 202 / 11 KV ANASARWADA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16			.583	.4115	.2401
17		.583			
19	.4458				
20		.4115			
24		.3429	.2401		.2058
Max	.4458	.583	.583	.4115	.2401
Min	.4458	.3429	.2401	.4115	.2058
Avg	.4458	.4458	.4116	.4115	.2230

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

NILANGA (R) S/DN[417] BU 5177

Substation No/ Name :- 154118 / 33/11 KV Anasarwada

Feeder No / Name : 203 / 11 KV TALIKHED GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.2058
8	.3086	.463		.2572		.2058
9						.1886
12					.12	
16			.3772		.1543	.1372
17		.2401				
19	.3086					
20		.3429				
22					.1372	
24		.2401	.2743			.1715
Max	.3086	.463	.3772	.2572	.1543	.2058
Min	.3086	.2401	.2743	.2572	.12	.1372
Avg	.3086	.3215	.3258	.2572	.1372	.1818

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 201 / 11KV SYED ANKULGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858		.3048	.0286	.2601	.2629	.3429
2	.1905		.3048	.0286	.2629	.2103	.3429
3	.1905		.3429	.0286	.2629		.3429
4	.1905		.3429	.0343	.2629	.2103	.3395
5	.1905		.3429	.0343	.2629	.3155	.3395
6	.1905		.3429	.0343	.3155		.3395
7	.1905		.3429	.3121	.3121	.3506	.3734
8	.1905		.3429	.3467	.3155		.3734
9	.1905		.2286	.3467	.3155	.3155	.4108
10	.3048		.2667		.3467	.381	.1905
11		.3429		.3467		.2667	.0191
12		.1905	.2515	.4334	.3429	.2667	.0191
13		.1905		.4382	.3467	.2667	.0191
14		.1905	.2515	.5201		.2667	.0191
15		.1905	.3353	.5201	.3155	.2667	.0191
16		.1905	.3353	.5258		.3048	.0191
17		.1905	.3353	.5258	.3155	.3048	.0286
18		.1905	.0191		.1753	.2286	.0286
19		.2286	.0191	.1734		.2667	.0286
20		.2667	.0286	.1734		.2667	.0286
21		.2667	.0286	.2629		.2858	.0286
22		.2858	.0286	.2601		.2858	.0286
23		.3048	.0286	.2601		.3048	.0286
24	.2858		.3048	.0286	.2601	.2629	.3429
Max	.3048	.3429	.3429	.5258	.3467	.381	.4108
Min	.1905	.1905	.0191	.0286	.1753	.2103	.0191
Avg	.2182	.233	.2331	.2574	.2921	.2805	.1689

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 202 / 11 KV BIBRAL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.5335	.0476		.3353	.4527
2	.4763		.5335	.0476		.3353	.5601
3	.4763		.5335	.0476			.5601
4	.5716		.5335	.0572		.4382	.5601
5	.5716		.5335	.0572		.4908	.5975
6	.6668		.5335	.0572			.5975
7	.6668		.381	.5201		.5258	.5975
8	.5716		.5335	.5201			.6348
9	.5716		.381			.4908	.6173
10	.6097		.5335			.5716	.3048
11		.5716				.5335	.061
12		.5716	.503			.5281	.0762
13		.6036	.5868		.7011	.4904	.0381
14		.7468	.5868			.4904	.0381
15		.7468	.6706		.5609	.5228	.0381
16		.7842	.6706			.5601	.0476
17		.7202	.7545		.5609	.5975	.0476
18		.5716	.0381		.2629	.3429	.0476
19		.5716	.0572			.3429	.0476
20		.5335	.0572			.3429	.0476
21		.5335	.0572			.362	.0476
22		.5335	.0572			.381	.0381
23		.5335	.0476			.381	.0381
24	.5716		.5335	.0476	.5201	.3506	.381
Max	.6668	.7842	.7545	.5201	.7011	.5975	.6348
Min	.4763	.5335	.0381	.0476	.2629	.3353	.0381
Avg	.5750	.6171	.4196	.1558	.5212	.4483	.2699

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 203 / 11 KV Ujed

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048		.415	.3353		.3018	.3429
2	.3048		.4527	.4191		.3018	.3429
3	.381		.4527	.4191			.3429
4	.381		.4481	.4191			.3429
5	.4572		.5228	.4191		.5258	.381
6	.4572		.5068	.503			.381
7	.381		.5487			.5609	.381
8	.381		.583			.4382	.4191
9	.381		.583				.4191
10	.3429		.1905			.2858	
11		.1905					.3353
12		.1905	.0191				.3353
13		.1905	.0191		.2601		.3353
14		.1905	.0191				.3353
15		.2286	.0286		.2103	.3048	.4191
16		.2286	.0286			.3429	.4191
17		.2286	.0286		.2629	.3429	.503
18		.2286			.3506	.3429	.0286
19		.2667	.0381			.3048	.0381
20		.3048	.0381			.3048	.0381
21		.3429	.0381			.3048	.0381
22		.3429	.1143			.3429	.0381
23		.3429	.0381			.3429	.0286
24	.381		.381	.3353	.4334	.2629	.3429
Max	.4572	.3429	.583	.503	.4334	.5609	.503
Min	.3048	.1905	.0191	.3353	.2103	.2629	.0286
Avg	.3775	.2520	.2497	.4071	.3035	.3507	.2864

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154014 / 33/11 KV UJED

Feeder No / Name : 204 / 11kv Halki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572		.4191	.4191		.3353	.3429
2	.4572		.4191	.4191		.3506	.3048
3	.5335		.4191	.0476			.3048
4	.5335		.4191	.4191		.5258	.3429
5	.5335		.415	.503		.5258	.3429
6	.5335		.4668	.503			.3429
7	.6097		.4668			.6135	.3429
8	.6097		.5228				.381
9	.5335		.5228			.4908	.3048
10	.381		.2286			.2858	.3429
11		.1905				.2286	.3018
12		.1905	.0229				
13		.1524				.2286	
14		.1524	.0286			.2286	
15		.1524	.0286		.2629	.2286	.503
16		.1524	.0286			.2286	.503
17		.1524	.0286		.2629	.2667	.503
18		.1905	.0286		.3155	.3048	.0343
19		.2286	.0381			.3048	.0381
20		.2667	.0381			.3429	.0381
21		.2667				.3429	.0381
22		.2858	.0381			.3429	.0819
23		.2858	.0381			.3429	.0286
24	.4572		.381	.4191	.4334	.3506	.3429
Max	.6097	.2858	.5228	.503	.4334	.6135	.503
Min	.381	.1524	.0229	.0476	.2629	.2286	.0286
Avg	.5127	.2052	.2380	.39	.3187	.3435	.2746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 201 / 11 KV DIGOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.6478		.8097	.5668		
9	.6478	.8907			.8097		
12			.362	.362			
15	.2715			.2715			
19	.543			.543			
24	.4858	.4858	.4049	.3887	.381	.4344	.543
Max	.6478	.8907	.4049	.8097	.8097	.4344	.543
Min	.2715	.4858	.362	.2715	.381	.4344	.543
Avg	.4870	.6748	.3835	.4750	.5858	.4344	.543

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 202 / 11 KV YEROL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.5544		.5487	.543		
9	.362	.2926			.5658		
12			.1943	.2429			
15	.1619			.2753			
19	.3982			.5544			
24	.3258	.3395	.1829	.3292	.3292	.1619	.2915
Max	.3982	.5544	.1943	.5544	.5658	.1619	.2915
Min	.1619	.2926	.1829	.2429	.3292	.1619	.2915
Avg	.3120	.3955	.1886	.3901	.4793	.1619	.2915

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 203 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.4858		.6154			
9	.4858	.5668			.4268		
12			.2561	.362			
15	.181						
19	.4525						
24	.3887	.4049	.3239	.4534		.3258	.4887
Max	.4858	.5668	.3239	.6154	.4268	.3258	.4887
Min	.181	.4049	.2561	.362	.4268	.3258	.4887
Avg	.377	.4858	.29	.4769	.4268	.3258	.4887

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154024 / 33/11 KV YEROL

Feeder No / Name : 204 / 11 KV DHAMANGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.3772		.3696			
9	.2743	.2641			.3772		
12			.3563	.4049			
15	.3239			.8097			
19	.2587						
24	.2241	.2641	.1132	.2614		.061	.2134
Max	.3239	.3772	.3563	.8097	.3772	.061	.2134
Min	.2241	.2641	.1132	.2614	.3772	.061	.2134
Avg	.2703	.3018	.2348	.4614	.3772	.061	.2134

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 201 / 11KV SHIRUR ANANTPAL

GAOTHAN FEEDER

GAOTHAN F Feeder KV- 11 /
OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.4572		
4		.5487					
7	.8573	.9145		.7716	.823		.9431
8		.823			.7316		
9	.6001		.7716		.6401	.6001	
12	.4572	.6401	.3429				.6401
13				.6401		.4287	
15			.3429	.5487			.4572
17	.5487			.5487			.5487
19			.5144				
22				.5487			
23		.5144	.4287			.6001	
24	.3429	.4572	.4287	.3429	.4287		.4287
Max	.8573	.9145	.7716	.7716	.823	.6001	.9431
Min	.3429	.4572	.3429	.3429	.4287	.4287	.4287
Avg	.5612	.6497	.4715	.5668	.6161	.5430	.6036

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 202 / 11KV BHINGOLI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.1638		
4		.2458					
7	.2572	.2458		.2572	.2458		.3429
8		.2458			.2458		
9	.1715	.2458	.1715		.2458	.2572	
10				.3429			
11				.2458			
12			.2572				.1638
13				.3277		.3429	
15				.3277			.1638
17	.2458			.3277			.1638
19			.1715				
22				.2458			
23		.1715	.2572			.1715	
24	.1715	.2458	.1715	.2572	.1715		.2572
Max	.2572	.2458	.2572	.3429	.2458	.3429	.3429
Min	.1715	.1715	.1715	.2458	.1638	.1715	.1638
Avg	.2115	.2334	.2058	.2915	.2145	.2572	.2183

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 203 / 11KV ARI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4049					
7	.6001	.4858		.4287			.5144
8		.5668					
9	.5144	.4858	.5144			.6001	
10				.2572			
12	.2429		.2572				.4858
13				.2429		.2572	
15			.1715	.2429			.4049
17	.2429			.1619			.3239
23		.5144	.2572			.3429	
24	.4287	.3239	.6001	.4287	.4287		.3429
Max	.6001	.5668	.6001	.4287	.4287	.6001	.5144
Min	.2429	.3239	.1715	.1619	.4287	.2572	.3239
Avg	.4058	.4636	.3601	.2937	.4287	.4001	.4144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 205 / 11KV SHIRUR ANANTPAL AG SEPARATED AG FEEDERS HAVING SPECIAL
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4		.4668					
7	.3429	.5601		.3429			.0343
8		.5601					
9	.4287	.5601	.4287			.4287	
12	.0373		.0343				.7468
13						.0343	
15			.0343				.4668
17	.0373						.5601
19			.0343				
23		.0343	.0343			.0343	
24	.3429	.5601	.1715	.3429	.1715		.0343
Max	.4287	.5601	.4287	.3429	.1715	.4287	.7468
Min	.0373	.0343	.0343	.3429	.1715	.0343	.0343
Avg	.2378	.4569	.1229	.3429	.1715	.1658	.3685

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154064 / 33/11KV SHIRUR ANANTPAL

Feeder No / Name : 206 / 11 KV LAKKAD JAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3					.2772		
4		.1772					
7	.2572	.2772			.5544		.3429
8		.2772			.462		
9	.2572	.2772	.2572		.462	.3429	
12	.5544		.6001				.1848
13				.462		.6859	
15			.6859				.1848
17				.3696			.1848
22				.2772			
23		.2572	.2572			.2572	
24	.2572	.2772	.2572	.2572	.2572		.3429
Max	.5544	.2772	.6859	.462	.5544	.6859	.3429
Min	.2572	.1772	.2572	.2572	.2572	.2572	.1848
Avg	.3315	.2572	.4115	.3415	.4026	.4287	.2480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 201 / 11 KV TALEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3429	.3772	.3582	.2743	.3224	.1715
2	.3506	.3429	.4115	.3582	.2743	.3224	.2058
3	.3856	.3429	.4458	.394	.3086	.3582	.3086
4	.3856	.3772	.4115	.4252	.3086	.3544	.3429
5	.4207	.4115	.4458	.4607	.3429	.3898	.3772
6	.4908	.4458	.5144	.5258	.3772	.4557	.4115
7	.5548	.6173	.4801	.5609	.4458	.4801	.4973
8	.4508	.5487	.5144	.5258	.5316	.4458	.4801
9	.4207		.4801	.4961	.4458	.4115	.3772
10	.1715		.2279	.2241	.2149	.3772	.1829
11	.1029		.1387	.168	.181		.2743
12	.0857		.0693	.1494	.1448		.2439
13	.0686		.0876		.1086		.2439
14	.0857		.1052	.0857			.2743
15	.0857		.1052	.112	.1086		.3048
16			.0886	.112	.1267		.2743
17			.0886	.1494	.1629		.2743
18			.1417	.2054	.2507		.1372
19	.3086		.3155	.5228	.5014		
20	.3772		.4557	.5228	.5373		
21	.4115		.4557	.4481	.4656		
22	.3772		.4252	.4108	.4298		
23	.3772		.3898	.3361	.3582		
24	.3544	.3429	.4115	.3658	.2743	.3155	.2058
Max	.5548	.6173	.5144	.5609	.5373	.4801	.4973
Min	.0686	.3429	.0693	.0857	.1086	.3155	.1372
Avg	.3151	.4191	.3161	.3442	.3119	.3848	.2941

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 202 / 11 KV SAKOL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2804	.3292	.3086	.2865	.2561	.2896	
2	.2804	.3292	.3429	.2865	.2561	.2865	
3	.3189	.3658	.3086	.3224	.2926	.3224	
4	.3506	.3658	.3429	.3544	.3658	.3582	
5	.3506	.4024	.3772	.3544	.4024	.4298	
6	.4557	.439	.4115	.4252	.5121	.4961	
7	.4854	.4572	.4458	.4908	.543	.4115	
8	.4854	.4024	.4115	.4908	.4706	.3772	
9	.4207		.3772	.4252	.3982	.3429	
11							.2743
12							.3086
13							.3429
14							.3086
15							.3429
16							.3086
17							.3772
24	.2103	.3292	.2743	.2896	.2561	.2804	
Max	.4854	.4572	.4458	.4908	.543	.4961	.3772
Min	.2103	.3292	.2743	.2865	.2561	.2804	.2743
Avg	.3638	.3800	.3601	.3726	.3753	.3595	.3233

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154066 / 33/11 KV SAKOL

Feeder No / Name : 203 / 11 KV GHUGI SANGVI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063		.1433		.0724	.0686
2	.1063		.1433		.1075	.0686
3	.1063		.1433		.1075	.0857
4	.124		.1612		.1433	.0686
5	.124		.1791		.1791	.0762
6	.1402		.2835		.2481	.12
7	.1753		.2835			.1029
8	.1402		.2454			.1372
9	.1227		.1772			.1715
10	.1147	.1753	.2195	.1629	.1372	
11	.1147	.2804	.1097	.1448		
12	.1147	.3155	.128	.1075		
13	.1147	.3189		.0905		
14	.1147	.2804		.0905		
15	.0983	.2835	.0914	.0895		
16	.0983	.3189	.1463	.0905		
17		.3189		.1267		
18		.1595		.1448		
19		.2126		.181		
20		.2835		.2507		
21		.2481		.2507		
22				.1417		
23		.1433		.1075		
24	.124		.1433		.0701	.1029
Max	.1753	.3189	.2835	.2507	.2481	.1715
Min	.0983	.1433	.0914	.0895	.0701	.0686
Avg	.1200	.2568	.1732	.1414	.1332	.1002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 201 / 11 KV SHIVPUR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.381	.4755	.3429		.439	.381
2	.3841	.381	.5487	.381		.4755	.381
3	.3641	.4191	.5487	.381		.4755	.381
4	.3841	.4191	.5316	.381		.5121	.381
5	.3841	.4572	.5316	.381		.5487	.381
6	.439	.4572	.5487	.4572		.6036	.381
7	.4755	.4572	.6068	.4572		.6036	.381
8	.5121	.5335	.6241	.4572			.381
9	.5487	.5335		.4572		.5121	.381
10	.2195	.2561		.2561		.381	.3658
11	.2858	.2926		.2926		.381	.3582
12	.2858	.2926	.2858	.2926	.3292	.4191	.3582
13	.2858	.3292	.3429	.2561	.3658	.4191	.3658
14	.2858	.3292	.381	.2561	.439	.4572	.3658
15	.3429	.2926	.381	.2561	.4755	.4572	.3658
16	.3429	.3292	.381	.2561	.2561	.4572	.4024
17	.381	.3292	.381	.2561	.2926	.4572	.4024
18	.381	.3292	.381		.2926	.3429	.2743
19	.381	.3429	.4572		.3292	.381	.2743
20	.4191	.3086	.381		.3292	.381	.2743
21	.4191	.3292	.381			.381	.2743
22	.381	.3292	.381			.381	.2743
23	.381	.3292	.3429			.381	.2743
24	.3429	.3429	.3429			.381	
Max	.5487	.5335	.6241	.4572	.4755	.6036	.4024
Min	.2195	.2561	.2858	.2561	.2561	.3429	.2743
Avg	.3744	.3667	.4398	.3422	.3455	.4447	.3504

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 202 / 11 KV HIPPALGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2858	.1829	.2858	.1829	.2195	.3048
2	.2195	.2858	.1829	.2858	.1829	.2195	.3048
3	.2195	.2858	.1829	.2858	.1829	.2195	.3429
4	.2561	.2858	.1829	.2858	.1829	.2926	.3429
5	.2561	.2858	.2012	.2858	.2195	.2926	.381
6	.2561	.2858	.2012	.2858	.2561	.2926	.381
7	.2926	.2858	.2561	.2858	.2926	.2926	.381
8	.2926	.2858	.2561	.2858	.4755	.2835	.381
9	.2561	.2858	.2926		.2561	.2926	.4572
10	.1829		.3429	.3292	.394	.3048	.1829
11	.3429		.381	.3658	.3658	.3429	.1829
12	.381		.381	.439	.4024	.381	.1829
13	.381		.381	.4755	.4024	.4191	.1829
14	.381		.381	.5487	.3658	.381	.1829
15	.4191	.3475	.4572	.439	.3658	.381	.1829
16	.4191	.439	.4572	.439	.4024	.381	.2195
17	.381	.4024	.4572	.439	.3658	.381	.2195
18	.3429	.3841	.2858		.2195	.381	.4024
19	.3429	.2195	.2858		.2561	.381	.2195
20	.3429	.2195	.2858	.2195	.2926	.3429	.4024
21	.3048	.2561	.2858	.1829	.2926	.2858	.1829
22	.3048	.2561	.2858	.1829	.2926	.2858	
23	.3048	.2561	.2858	.1829	.2561	.2858	.1829
24	.3048	.3048	.2858		.1791	.2667	
Max	.4191	.439	.4572	.5487	.4755	.4191	.4572
Min	.1829	.2195	.1829	.1829	.1791	.2195	.1829
Avg	.3087	.2978	.2991	.3265	.2952	.3169	.2820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

NILANGA DIVSION[517]

SHIRUR ANANTPAL S/DN[823] BU 4823

Substation No/ Name :- 154111 / 33KV/11KV HIPPALGAON

Feeder No / Name : 203 / 11 KV GANESHWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1143	.128			.0732	.0953
2	.1097	.1143	.1254			.0732	.0953
3	.1075	.1143	.128			.0732	.0953
4	.1097	.1143	.12			.0732	.0953
5	.1075	.1143	.12	.1143		.0914	.0953
6	.1097	.1524	.1214	.1143		.1097	.0953
7	.1097	.1524	.1753	.1143		.0914	.0953
8	.1097	.1524	.208	.1524		.0914	.0953
9	.1097	.1524	.2561	.1524		.0914	.0953
10	.0732	.0914	.0953	.1097		.0953	.0914
11	.0762	.0914	.0953	.1075		.0953	.0914
12	.0762	.0914	.0953	.0895		.0953	
13	.0953	.0914	.0953	.0914	.1097	.1143	.0914
14	.0953	.0914	.0953	.0732		.1524	.0914
15	.0953	.0914	.0953	.0732		.1524	.0914
16	.0953	.0914	.0953	.0914		.1524	.0914
17	.0953	.0914	.0953	.0914		.1524	.0914
18	.0953	.0914	.0953		.0934	.0953	.0914
19	.0953	.0914	.0953		.0895	.0953	.0747
20	.0953	.0914	.0953		.0934	.0953	.0724
21	.0953	.0914	.0953		.0914	.0953	.0732
22	.0953	.0914	.0953		.0914	.0953	.0732
23	.0953	.0914	.0953		.0914	.0953	.0366
24	.1143					.0953	
Max	.1143	.1524	.2561	.1524	.1097	.1524	.0953
Min	.0732	.0914	.0953	.0732	.0895	.0732	.0366
Avg	.0988	.1070	.1181	.1058	.0943	.1019	.0872

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 202 / 11 KV Nandura AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.2458			
12	.4144	.2515		
13		.3315		
14	.2486	.381		
15	.4144			
16	.4191	.4191	.2486	
17	.4144	.2515	.2801	.2801
Max	.4191	.4191	.2801	.2801
Min	.2458	.2515	.2486	.2801
Avg	.3595	.3269	.2644	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 203 / 11 KV THODAGA AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867		.1867		.1867
2		.1867		.1867		.1867
3		.1867		.1867		.1867
4		.1867		.1867		.1867
5		.1867		.1867		.1867
6		.1867		.1867		.1867
7		.2801		.1867		.1867
8		.2801	.3353	.1867		.1867
15	.1677	.1677				
16	.1677	.2486	.1638			
17	.2286		.1867		.1867	.1867
18	.1867		.1867		.1867	
19	.1867		.1867		.1867	
20	.1867		.1867		.1867	
21	.1867		.181		.1867	
22	.1867		.1867		.1867	
23	.1867		.1867		.1867	
24		.1867	.1638	.1867		.1867
Max	.2286	.2801	.3353	.1867	.1867	.1867
Min	.1677	.1677	.1638	.1867	.1867	.1867
Avg	.1871	.2076	.1964	.1867	.1867	.1867

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 204 / 11 KV NANDURA GFSS

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.181		.1867		.2801
2		.1867		.1867		.2801
3		.1867		.1867		.2801
4		.1867		.1867		.2801
5		.1867		.2801		.362
6		.1867		.3734		.4668
7		.2715		.3734		.543
8		.2801	.4239	.3734		.5601
9	.2458	.2543				
10	.2286	.2543				
11		.1677				
12	.1638	.1677				
13		.1658				
14	.1658					
15	.1619	.0829				
16	.1619	.1677	.1658			
17	.1658	.1677	.1867		.1867	.1867
18	.1867		.1867		.2801	
19	.1867		.1867		.2801	
20	.1867		.1867		.3734	
21	.1867		.1867		.3734	
22	.181		.1867		.2801	
23	.1867		.1867		.2743	
24		.1867	.2515	.1867		.2801
Max	.2458	.2801	.4239	.3734	.3734	.5601
Min	.1619	.0829	.1658	.1867	.1867	.1867
Avg	.1852	.1930	.2148	.2593	.2926	.3519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154004 / 33/11 KV AHMEDPUR

Feeder No / Name : 205 / 11 kv Kalegaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3734		.2801		.3734
2		.3734		.2801		.3734
3		.3734		.2801		.3734
4		.4668		.2801		.3734
5		.4668		.3734		.3734
6		.4668		.3734		.3734
7		.4668		.362		.4668
8		.4525	.5087	.3734		.5601
9		.4191				
10		.2515				
12		.3277				
13		.3277				
14		.2486				
15		.2486				
16			.3734			
17	.3734		.2801		.3734	.3734
18	.3734		.2801		.3734	
19	.3734		.2801		.3734	
20	.3734		.2801		.4668	
21	.3734		.2801		.5601	
22	.3734		.2801		.5601	
23	.3734		.2801		.4668	
24		.4239	.3353	.2801		.3734
Max	.3734	.4668	.5087	.3734	.5601	.5601
Min	.3734	.2486	.2801	.2801	.3734	.3734
Avg	.3734	.3791	.3178	.3203	.4534	.4014

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 201 / 11 KV UJANA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8688	.724	.7712	.9412	.5373	.7164	
16	.5487	.5373	.5014	.6201	.6089	.5487	.6219
24	.6722	.6135	.5601	.5975	.5601	.5975	.4572
Max	.8688	.724	.7712	.9412	.6089	.7164	.6219
Min	.5487	.5373	.5014	.5975	.5373	.5487	.4572
Avg	.6966	.6249	.6109	.7196	.5688	.6209	.5396

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 202 / 11 KV SANGHAVI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.964	.6219	1.0745	.7087	1.0242	.7087
16	.5258	.6268	.6878	.543	.6516	.543	.5373
24	.4854	.6401	.5792	.6348	.6535	.6722	.4668
Max	.5258	.964	.6878	1.0745	.7087	1.0242	.7087
Min	.4854	.6268	.5792	.543	.6516	.543	.4668
Avg	.5056	.7436	.6296	.7508	.6713	.7465	.5709

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 203 / 11 KV GANGA HIPPARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.7392	.3429	.4706	.4908	.2172	.4382	.362
16	.1867	.1829	.1402	.2743	.1829	.2743	.4481
24	.5601	.1791	.4298	.4668	.1867	.2241	.2801
Max	.7392	.3429	.4706	.4908	.2172	.4382	.4481
Min	.1867	.1791	.1402	.2743	.1829	.2241	.2801
Avg	.4953	.2350	.3469	.4106	.1956	.3122	.3634

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 204 / 11 KV UJANA EXPRESS FEEDER NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0187	.181	.0181	.1848	.2033	.1949	.1829
16	.0183	.1829	.1848	.1753	.0543	.1791	.1646
24	.0187	.1829	.1848	.2033	.1867	.1991	.1867
Max	.0187	.1829	.1848	.2033	.2033	.1991	.1867
Min	.0183	.181	.0181	.1753	.0543	.1791	.1646
Avg	.0186	.1823	.1292	.1878	.1481	.1910	.1781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154043 / 33/11 KV UJANA

Feeder No / Name : 205 / 11KV BALGHAT KARKHANA NON SHEDDABLE EXPRESS HV FEEDERS
FEEDER Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0914	.0905	.0724	.1097	.0905	.0934	.0914
16	.0905	.0905	.0716	.0905	.0724	.0924	.0724
24	.056	.0914	.0747	.056	.0934	.0566	.0905
Max	.0914	.0914	.0747	.1097	.0934	.0934	.0914
Min	.056	.0905	.0716	.056	.0724	.0566	.0724
Avg	.0793	.0908	.0729	.0854	.0854	.0808	.0848

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 201 / 11 KV ROKADA SAWARGAON SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3429	.5144	.5487	.5144	.4287	.4458	.4287
16	.6858	.3429	.5144		.5144		.1715
24	.1715	.343	.1715	.2572	.2572	.2572	.2572
Max	.6858	.5144	.5487	.5144	.5144	.4458	.4287
Min	.1715	.3429	.1715	.2572	.2572	.2572	.1715
Avg	.4001	.4001	.4115	.3858	.4001	.3515	.2858

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 202 / 11 KV TAKALGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.2058	
8	.1715	.2572	.3086	.5144	.2572	.2572	.3429
16	.1715	.1715	.1715		.0857	.1715	.0857
24	.1715	.2572	.4287	.4287	.1715		.2572
Max	.1715	.2572	.4287	.5144	.2572	.2572	.3429
Min	.1715	.1715	.1715	.4287	.0857	.1715	.0857
Avg	.1715	.2286	.3029	.4716	.1715	.2115	.2286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154083 / 33/11 KV ROKADA SAWARGAON

Feeder No / Name : 203 / 11 KV KAJAL HIPARGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7						.4287	
8	.4287	1.0288	.5144	.8573	.6859	.2572	.4287
16		.3429	.3086		.3086	.3429	.3429
24	.5144	1.0288	.3429	.5144	.4287		.4287
Max	.5144	1.0288	.5144	.8573	.6859	.4287	.4287
Min	.4287	.3429	.3086	.5144	.3086	.2572	.3429
Avg	.4716	.8002	.3886	.6859	.4744	.3429	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 201 / 11KV Thodga GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5544		.5544			
2	.5544	.6283		.5544			
3	.5544	.6468	.6283	.5914			
4	.5914	.7207		.7392			
5	.7023	.8316		.8871			
6	.7392	.9979	.8871	1.0349			
7	.9979	.924		1.0164		.7762	
8	.8871	.8501	.9979	.9979	.7392	.9055	.7762
9	.7762	.8131	.7392	.6468	.7023	.7762	
10	.462	.6099	.5914		.5359	.7392	.7762
11	.4066		.462		.5175	.5914	.5175
12	.2957		.2957		.4805	.4435	.4805
13	.3142	.3326	.2772	.5544	.4251	.462	.3881
14	.2772		.2772		.3696	.4435	.4435
15	.2957		.2957	.4435	.3881	.4066	.3696
16	.3142		.3142		.4251	.4435	.4066
17	.3696	.4066	.3326	.5175	.462	.462	.4435
18	.3881	.3696	.3696	.6468	.5359	.6653	.6283
19	.6468		.6653		.7023	.7392	.6653
20	.8316		.8316		.9055	.8131	
21	.7207		.7577	.7392	.961	.7392	.6283
22	.5914	.5914	.6468			.6468	.4805
23	.5544		.5914	.5544		.5914	.4805
24	.5175	.5175	.5175	.5544			
Max	.9979	.9979	.9979	1.0349	.961	.9055	.7762
Min	.2772	.3326	.2772	.4435	.3696	.4066	.3696
Avg	.5544	.6530	.5515	.6895	.5821	.6262	.5346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 202 / 11KV MOGHA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10	.0633	.1581	.2214	.2241		.1265
11	.0633	.1524	.2241		.1581	.16
12	.0633		.2241	.2439	.1898	.192
13	.0633		.2241	.2134	.1898	.2241
14	.0633		.2241		.16	.2241
15	.1265	.1829	.2241	.1829	.1581	.2241
16	.16		.2561		.192	.2241
17	.1898	.2439	.2561	.1524	.1898	.192
Max	.1898	.2439	.2561	.2439	.192	.2241
Min	.0633	.1524	.2214	.1524	.1581	.1265
Avg	.0991	.1843	.2318	.2033	.1768	.1959

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154106 / 33/11KV THODAGA

Feeder No / Name : 203 / 11KV TEMBHURNI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.1265		.128	.0633	
2	.16	.128		.128	.0633	
3	.16	.1265	.2134	.16	.096	
4	.16	.1265		.192	.0949	
5	.192	.1265		.2241	.1265	
6	.192	.1265	.3048	.2561	.1265	
7	.192	.1898		.3521	.1898	
8	.2881	.2561	.3658	.4801	.2846	
9	.3201	.3163	.3963	.4801	.2846	
10						.128
11						.192
12						.192
13						.192
14						.192
15						.192
16						.192
17						.192
24	.16	.1265	.1219	.128	.0633	
Max	.3201	.3163	.3963	.4801	.2846	.192
Min	.16	.1265	.1219	.128	.0633	.128
Avg	.1984	.1649	.2804	.2529	.1393	.184

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
ST

Feeder No / Name : 201 / 11KV BUSTAND FEEDER.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317			
2	1.0974			
3	1.166			
4	1.2346			
5	1.2689			
6	1.3032			
7	1.3375			
8	1.406	1.7193	1.7193	1.8625
9	1.4746			1.8267
10	1.406			1.576
11	1.3717			1.5043
12				1.4327
13				1.3611
14				1.3253
15				1.3611
16		1.6118	1.6118	1.4685
17				1.5043
18			1.7551	1.8267
19				2.0058
20				1.8861
21				1.8861
22				1.5089
23				1.4746
24	1.166	1.4685	1.7551	1.6118
Max	1.4746	1.7193	1.7551	2.0058
Min	1.0974	1.4685	1.6118	1.3253
Avg	1.2803	1.5999	1.7103	1.6131

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB
STFeeder No / Name : 202 / 11KV TELEPHONE FEEDER
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068			
2	.5068			
3	.6097			
4	.6802			
5	.6097			
7	.7621			
8	.8421	1.0745	1.0387	1.1104
9	.823			1.0745
10				1.0387
11	.7621			.9313
12				.9313
13				.8954
14				.8596
15				.8238
16		.9313	.8954	.8954
17				.9671
18			1.0029	1.1462
19				.9335
20				.945
21				.9145
22				.7468
23				.823
24	.6097	.8596	1.0387	1.0387
Max	.8421	1.0745	1.0387	1.1462
Min	.5068	.8596	.8954	.7468
Avg	.6712	.9551	.9939	.9456

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

AHMEDPUR[432]

BU 5151

Substation No/ Name :- 154114 / 33/11KV URBAN AHMADPUR SUB

ST

Feeder No / Name : 203 / 11KV EXPRESS FEEDER

NON SHEDDABLE WATER SUPPLY AND

Feeder KV- 11 / OUTGOING

UTILITY

DATE	22-AUG-17	23-AUG-17	24-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0671	.1677	.1006
9				.1006
10				.2347
11				.2683
12				.2683
13				.2683
14				.2347
15				.2347
16		.2012	.2012	.2683
17				.2683
18			.2347	.2012
19				.16
20				.2134
21				.1867
22				.2134
23				.1867
24	.1715	.1006	.1341	.1006
Max	.1715	.2012	.2347	.2683
Min	.1715	.0671	.1341	.1006
Avg	.1715	.1230	.1844	.2064

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 201 / 11KV Khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17
HR	Load (MW)
8	.9431
Max	.9431
Min	.9431
Avg	.9431

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 202 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.1619	.1524		.1296	
2		.1619	.1619	.1524	.1677	.1296	.1143
3	.2439		.1619	.1829		.1296	
4		.1619	.1943	.1829	.1677	.1619	.1143
5	.2439		.1943	.2743		.1619	
6		.2591	.2591		.2012	.1943	.1143
7	.2743		.3239			.1943	
8	.3048	.2591	.2286		.2683	.2267	.1143
9	.3048	.3887	.4534		.3239	.2591	
10		.1006	.0937		.1029	.1006	
11		.1006	.0949	.0914	.1006		
12		.1006	.096		.1006		
13		.1006		.0914	.1006		
14	.0914						
15		.1006			.1006		
16		.1006		.0914	.1006		
17		.0972			.0983		
18		.1006			.1006		
19					.1006		
20		.1029			.0972		
21		.1017			.1006		
22		.1017			.1006		
23		.1017					
24	.1524	.1677	.1619	.1524	.1715	.1029	
Max	.3048	.3887	.4534	.2743	.3239	.2591	.1143
Min	.0914	.0972	.0937	.0914	.0972	.1006	.1143
Avg	.2210	.1449	.1989	.1524	.1391	.1628	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 203 / 11KV Chakur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219		.1296	.1219		.1296	
2		.1296	.1296	.1219		.1296	.1143
3	.1219		.1619	.1219		.0972	
4		.1296	.1619	.1219		.1296	
5	.1524		.1943	.1524		.1619	
6		.1619	.2267			.1619	.1143
7	.1524		.2267			.1619	
8	.1829	.1943	.3239		.1943	.1619	.1143
9	.1524	.2591	.2267		.3887	.1619	
10		.0914			.1006	.1006	.1219
11		.1006	.0937	.0914	.1006		
12		.1006	.0949		.1017		
13		.1006		.0914	.1017		
14	.0914	.1006					
15		.1006			.1006		
16		.1006		.0914	.1006		
17		.1006			.0972		
18		.1006			.1006		
19					.1006		
20		.1029			.1006		
21		.1029			.1006		
22		.1029			.1006		
23		.1029			.1006		
24	.1219	.1341	.1372	.1219	.1372	.1029	
Max	.1829	.2591	.3239	.1524	.3887	.1619	.1219
Min	.0914	.0914	.0937	.0914	.0972	.0972	.1143
Avg	.1372	.1219	.1756	.1151	.1267	.1363	.1162

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 204 / 11KV Lohara SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914		.0972	.0914		.1006	
2		.1006	.1006	.0914		.1006	.1524
3	.0914		.1006	.0914		.1006	
4		.1006	.1006	.0914		.1006	.1524
5	.0914		.0972	.0914		.1006	
6		.1006	.0972			.1006	.1905
7	.0914		.0972			.1006	
8	.0914	.1006	.0972		.1006	.1006	.1905
9	.0914		.1006		.1006	.1006	
10			.1562		.1296	.1296	
11		.1296	.1562	.1219	.1341		
12	.0914	.1943	.125		.1296		
13		.1943		.1524	.1296		
14	.1219	.1619					
15		.1943			.1296		
16		.1943		.1829	.1341		
17		.2347			.1296		
18					.0972		
19		.1017			.1006		
20		.1006			.1006		
21		.1029			.1006		
22		.1029			.1006		
23		.1017					
24	.0914	.0972	.1029	.0914	.1029	.1372	
Max	.1219	.2347	.1562	.1829	.1341	.1372	.1905
Min	.0914	.0972	.0972	.0914	.0972	.1006	.1524
Avg	.0948	.1360	.1099	.1117	.1147	.1066	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 205 / 11KV Nalegaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3963		.4858	.4268		.4534	
2		.4359	.4858	.4268		.4534	.4572
3	.4268		.4858	.4572		.4858	
4		.4534	.4858	.4572		.6154	.4572
5	.5487		.5182	.5487		.6478	
6		.6478	.6154			.6802	.6097
7	.5792		.6802			.6478	
8	.4268	.6478	.5182			.5506	.7621
9	.4268	.5182	.421		.5182	.5506	
10		.4858	.4062		.4694		
11		.3563	.3795	.4572	.3563		
12		.3887	.3479		.3239		
13		.3887		.4458	.3239		
14	.3353	.3887					
15		.3887			.3239		
16		.3887		.3048	.3563		
17					.3563		
18		.5182			.4534		
19					.6154		
20		.8916			.7773		
21		.6859			.6478		
22		.5487			.6154		
23		.5487					
24	.3963	.4534	.4801	.4268	.4801	.4801	
Max	.5792	.8916	.6802	.5487	.7773	.6802	.7621
Min	.3353	.3563	.3479	.3048	.3239	.4534	.4572
Avg	.4420	.5075	.4854	.4390	.4727	.5565	.5716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 206 / 11KV Atola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914		.1006	.0914		.1006	
2		.1006	.0972	.0914	.1006	.1006	.2743
3	.0914		.0972	.0914		.1006	
4		.1006		.0914	.0972	.1006	.3048
5	.0914			.0914		.1006	
6		.0972	.0972		.1006	.1006	.381
7	.0914		.1006			.0972	
8	.0914	.1006	.0972		.1006	.1006	.4572
9	.0914	.0972	.0972		.1006	.1006	
10		.1619	.1875		.1677	.3239	.0914
11		.421	.3749	.1524	.3563		
12		.5182	.506		.3239		
13		.5182		.3963	.3239		
14	.3353	.5182					
15		.5182			.3239		
16		.5182		.5182	.2915		
17		.5506			.2267		
18		.1006			.1006		
19					.0972		
20		.1029			.1006		
21		.1029			.1006		
22		.1029			.1006		
23		.1029					
24	.0914	.1006	.1029	.0914	.1029	.2743	
Max	.3353	.5506	.506	.5182	.3563	.3239	.4572
Min	.0914	.0972	.0972	.0914	.0972	.0972	.0914
Avg	.1219	.2544	.1690	.1795	.1731	.1364	.3017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154006 / 33 KV SUBSTATION NALEGAON

Feeder No / Name : 207 / 11 KV GILDA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305		.0339	.0305		.0324	
2		.0324	.0335	.0305	.0335	.0324	.0381
3	.0305		.0335	.0305		.0324	
4		.0324	.0335	.0305	.0324	.0324	.0381
5	.0305		.0328	.0305		.0324	
6		.0324	.0328		.0324	.0324	.0381
7			.0312			.0324	
8	.0305	.0324	.0324		.0324	.0324	
9		.0324	.0312		.0324	.0324	
10		.0305	.0312		.0324	.0324	
11		.0324	.032	.0305	.0324		
12		.0305	.0312		.0324		
13		.0324		.0305	.0335		
14		.0324					
15		.0324			.0312		
16		.0324		.0305	.0324		
17		.0324			.0324		
18		.0324			.0305		
19					.0324		
20		.0343			.0324		
21					.0324		
22		.0343					
23		.0343					
24	.0305	.0309	.0343	.0305	.0335	.0343	
Max	.0305	.0343	.0343	.0305	.0335	.0343	.0381
Min	.0305	.0305	.0312	.0305	.0305	.0324	.0381
Avg	.0305	.0324	.0326	.0305	.0324	.0326	.0381

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 201 / 11KV Chapoli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3			.5144				
8	.8573	.8573	.5144	2.0576	.3429	.9431	
9							.5144
16	.3429		.3429		.2572		.3429
24		.4287		.4287			
Max	.8573	.8573	.5144	2.0576	.3429	.9431	.5144
Min	.3429	.4287	.3429	.4287	.2572	.9431	.3429
Avg	.6001	.643	.4572	1.2432	.3001	.9431	.4287

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 202 / 11KV Jadhala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8573	.8573	.7716	.5144	.6001	1.0288	
9							.6859
16			.3429		.2572		.5144
24		.6001	.9431	.6859			
Max	.8573	.8573	.9431	.6859	.6001	1.0288	.6859
Min	.8573	.6001	.3429	.5144	.2572	1.0288	.5144
Avg	.8573	.7287	.6859	.6002	.4287	1.0288	.6002

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154011 / 33KV ZARI S/N

Feeder No / Name : 203 / 11 KV MAHALANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.6859	.6001	.6859
24		.4287	.7716
Max	.6859	.6001	.7716
Min	.6859	.4287	.6859
Avg	.6859	.5144	.7288

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 202 / 11KV Janwal

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5249	.4687	.5249	.4312	.4874	.4124
2	.5249	.4874	.4874	.4499	.5062	.3937
3	.6187	.4874		.4499	.5437	.3937
4	.7499	.5249	.5999	.5062	.5624	.4124
5	.7874	.7124	.8249	.5437	.6374	.4124
6	.9374	.9186	.9561	.5999	.7874	.5062
7	1.0123	.9374	.9936	.8624	.8249	.5624
8	.8061	.8811	.7874	.7686	.7686	.8436
9	.7499	.6374	.6936	.5624	.5999	.7499
10	.4874	.4874		.4124	.6749	.5437
11	.3	.3187		.2625	.5624	.4124
12	.2812	.2625			.3749	.3374
13	.3187	.2812	.3562	.3562	.3374	.3187
14		.3187	.3374		.3374	.3374
15	.3	.5062	.3187		.3749	.3562
16	.4874	.4874	.9186	.5624	.3749	.3749
17	.4687	.4124		.5437	.5624	.3937
18	.5624	.5999		.5249	.5999	.4499
19	.5812	.6936		.5812		.8249
20	.6187	.6749		.5062	.4687	
21	.5624	.6374	.4874	.4687	.4499	.6562
22	.5249	.5999	.4874	.4312	.4124	.5624
23	.5249	.5624	.4687	.4312		.4874
24		.4687	.5249	.4312	.4499	.4124
Max	1.0123	.9374	.9936	.8624	.8249	.8436
Min	.2812	.2625	.3187	.2625	.3374	.3187
Avg	.5786	.5569	.6104	.5089	.5317	.4850

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154038 / 33/11 KV WADWAL

Feeder No / Name : 203 / 11KV Gharola

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4954	.4954	.1524	.4763	.4191
2	.5335	.5144	.4954	.1524	.4763	.4763
3	.6478	.5144	.5335	.1524	.5144	.5716
4	.7811	.5716	.724	.1524	.5335	.6097
5	.9526	.6668	.8764	.1905	.5525	.6097
6	.8002	.9145	.9526	.2286	.724	.8192
7	.8002	.9526	.9526	.3239	.7811	.9526
8	.4763	.5335	.4763	.3429	.4763	.7621
9	.6287	.6097	.4954	.3048	.5906	.5144
10	.6859	.6097		.3048	.6287	.4191
11	.6668	.6097	.6097	.362	.5716	.381
12	.743	.6287	.6668		.5144	.3048
13	.3429	.6478	.6859	.6287	.5716	.3429
14	.4954	.6478	.724		.6097	.3429
15	.6097	.8383	.7621		.6478	.3429
16	.1905	.2667	.3429	.5144	.362	.5716
17	.1905	.1524		.2858	.4191	.7621
18	.3048	.3429		.4191	.4572	.7621
19	.4954	.4954		.6097		.6668
20	.6859	.6478		.5716	.6097	
21	.6287	.6097	.1524	.5716	.5335	.4572
22	.5716	.6097	.1524	.5335	.4763	.4382
23	.5335	.5716	.1524	.4763		.4382
24		.4954	.5335	.1524	.4763	.4191
Max	.9526	.9526	.9526	.6287	.7811	.9526
Min	.1905	.1524	.1524	.1524	.362	.3048
Avg	.5774	.5811	.5676	.3538	.5456	.5384

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 201 / 11KV Chapoli

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6935	.6068	.7802	.964	.5801	.7011	.5258
16	.4334	.4334	.3429	.3315	.4334	.4382	.4144
24	.3467	.3467	.4191			.3467	.3506
Max	.6935	.6068	.7802	.964	.5801	.7011	.5258
Min	.3467	.3467	.3429	.3315	.4334	.3467	.3506
Avg	.4912	.4623	.5141	.6478	.5068	.4953	.4303

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 202 / 11KV Ajansonda

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8478	1.0174	1.0174	1.2003	.7716	.9326	.6783
16	.2543	.2515	.2572	.3429	.3391	.4239	.5144
24	.3391	.4239	.503			.4239	.4191
Max	.8478	1.0174	1.0174	1.2003	.7716	.9326	.6783
Min	.2543	.2515	.2572	.3429	.3391	.4239	.4191
Avg	.4804	.5643	.5925	.7716	.5554	.5935	.5373

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 203 / 11KV Naigaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4191	.503	.5868	.4096	.503	.5868	.4191
16	.3353	.503	.6554	.6706	.4191	.4239	.2515
24	.4191	.3391	.3353			.3353	.3353
Max	.4191	.503	.6554	.6706	.503	.5868	.4191
Min	.3353	.3391	.3353	.4096	.4191	.3353	.2515
Avg	.3912	.4484	.5258	.5401	.4611	.4487	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154048 / 33/11kv chapoli

Feeder No / Name : 204 / 11KV BSF

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.0257	.0267	.0276	.0381	.0381	.0257	.0267
16	.0267	.0343	.0381	.04	.0267	.0381	.04
24	.0257	.0267	.0267			.0267	.0276
Max	.0267	.0343	.0381	.04	.0381	.0381	.04
Min	.0257	.0267	.0267	.0381	.0267	.0257	.0267
Avg	.0260	.0292	.0308	.0391	.0324	.0302	.0314

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 201 / 11KV Ganjur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1715	.1886	.2572	.181	.2829	.2572
2	.181	.1715	.1886	.2572	.181	.2829	.2572
3	.181	.1715	.1886	.2572	.181	.2829	.2572
4	.181	.2572	.2829	.2572	.181	.2829	.2572
5	.2715	.3429	.2829	.3429	.2715	.2829	.3429
6	.362	.3429	.2829	.3429	.2715	.3772	
7	.2715	.3429	.2829	.4287	.362	.3772	
8	.181	.3429	.3772	.3429	.2715	.3772	
9	.181	.3429	.2829	.1715	.362	.3772	
10	.3429	.2572	.3429	.1715	.2572	.362	
11	.3429	.3429	.3429	.3772	.2572	.362	
12	.3429	.3429	.5144	.3772	.2572	.4525	
13	.3429	.2572	.5144	.4715	.2572	.4525	
14	.3429	.3429	.5144	.4715	.2572	.543	.2829
15	.3429	.4287	.5144	.4715	.3429	.4525	.1886
16	.3429	.3429	.6001	.4715	.3429	.4525	.1886
17	.3429	.4715	.5144	.4525	.3772	.4287	.1886
18	.1715	.1886	.1715	.181	.1886	.1715	.181
19	.1715	.2829	.2572	.181	.2829	.1715	.2715
20	.1715	.2829	.2572	.362	.2829	.1715	.2715
21	.1715	.2829	.2572	.362	.2829	.1715	.362
22	.1715	.2829	.2572	.2715	.2829	.1715	.2715
23	.1715	.2829	.2572	.181	.2829	.1715	.2715
24	.181		.2829	.2572		.2829	.2572
Max	.362	.4715	.6001	.4715	.3772	.543	.362
Min	.1715	.1715	.1715	.1715	.181	.1715	.181
Avg	.2477	.2989	.3315	.3216	.2702	.3225	.2567

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 202 / 11KV Shivankhed SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2572	.4715	.3429		.3772	.3429
2	.2715	.2572	.4715	.3429		.3772	.3429
3	.362	.2572	.4715	.3429		.4715	.3429
4	.4525	.3429	.4715	.4287		.4715	.3429
5	.4525	.4287	.4715	.5144		.4715	.4287
6	.543	.6859	.5658			.5658	.5144
7	.543	.4287	.7545			.6602	.5144
8	.543	.3429	.6602	.6001		.5658	.6001
9	.543	.3429	.5658	.5144		.4715	.4715
10	.3429	.2572	.3429	.3429		.4525	.3772
11	.4287	.2801	.5144	.4715		.543	.2829
12	.4287	.3429	.5144	.4715		.543	.2829
13	.4287	.3429	.5144	.4715	.1715	.4525	
14	.4287		.4287		.2572	.4525	
15	.4287			.3772	.3429	.543	
16	.4287		.4287	.4715	.3429	.543	
17	.4287	.3772	.4287	.4525	.4715	.5144	.3772
18	.2572	.2829	.2572		.2829	.2572	.4525
19	.4287	.3772	.4287		.3772	.4287	.543
20	.1715	.5658	.6001		.5658	.4287	.6335
21	.4287	.5658	.6001		.4715	.4287	.6335
22	.3429	.4715	.5144		.4715	.3429	.543
23	.3429	.4715	.4287		.3772	.3429	.362
24	.362	.3429	.4715	.3429		.3772	.2572
Max	.543	.6859	.7545	.6001	.5658	.6602	.6335
Min	.1715	.2572	.2572	.3429	.1715	.2572	.2572
Avg	.4025	.3820	.4946	.4325	.3756	.4618	.4323

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154080 / 33/11 KV SHIVANKHED

Feeder No / Name : 203 / 11KV Dhaveli SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4525	.3429	.3772	.2572	.362	.2829	.1715
2	.362	.3429	.3772	.2572		.3772	.1715
3	.362	.3429	.3772	.3429	.4525	.3772	.1715
4	.4525	.4287	.3772	.3429	.4525	.3772	.1715
5	.4525	.5144	.4715	.4287	.4525	.3772	.1715
6	.4525	.5144	.4715	.4287	.543	.4715	.2572
7	.362	.6001	.5658	.5144	.543	.4715	.2572
8	.543	.6001	.5658	.5144	.543	.4715	.3429
9	.543	.6001	.5658	.5144	.543	.4715	.2829
10	.1715	.1715	.181	.1715	.1715	.181	.2829
11	.1715	.0857		.1886	.1715	.181	.3772
12	.1715	.0857	.181	.0943	.1715	.181	.3772
13	.1715	.0857	.0905	.0943	.1715	.0905	.2829
14	.1715	.0857	.0905	.0943	.1715	.0905	.2829
15	.1715	.0857	.0905	.0943	.1715	.0905	.2829
16	.1715	.0857	.181	.0943		.0905	.3772
17	.1715	.0943	.0857	.0905	.1886	.1715	.2829
18	.1715	.0943	.0857	.181	.1886	.1715	.181
19	.1715	.1886	.1715		.1886	.1715	.181
20	.1715	.1886	.2572	.181	.1886	.1715	.181
21	.1715	.1886	.2572	.181	.1886	.1715	.2715
22	.1715	.1886	.1715	.181	.1886	.1715	.181
23	.1715	.1886	.1715	.181	.1886	.1715	.181
24	.362	.3429	.2829	.2572	.2715	.2829	.1715
Max	.543	.6001	.5658	.5144	.543	.4715	.3772
Min	.1715	.0857	.0857	.0905	.1715	.0905	.1715
Avg	.2810	.2686	.2803	.2472	.2960	.2528	.2455

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 201 / 11KV Sugaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4108		.4108	.3227		.2347
2	.3814	.4108		.4108	.3227		.2347
3	.3814	.4694	.4694	.4694	.2934	.4694	.2934
4	.4401	.4694		.5281	.3814		.2934
5	.4694	.5868		.5868	.4988		.3521
6	.5281	.7335	.5281	.7042	.5575	.5868	.4108
7	.5575	.7042		.7335	.6161		.4108
8	.5281	.3521	.5281	.5868	.5281	.6455	.3814
9	.4401			.4108		.5868	.3814
10	.2347	.3521				.2347	.4108
11	.2347			.2347		.2347	.3521
12				.2347		.2347	.2934
13	.176	.3521		.2641		.2641	.2641
14	.2347			.3227		.2641	
15	.2347			.3521		.2347	
16	.2641	.2934	.3521	.3081		.2347	.2641
17	.2641		.2934	.3521		.2347	.3814
18	.2347	.3521	.3521	.2934		.3521	.0147
19	.4401		.3521	.3814		.4694	.4988
20	.6455		.3521	.4108		.5281	.4988
21	.5281		.4694			.5281	.4694
22	.5281		.4694	.3521		.4694	.4401
23	.4694		.4694	.3227		.4694	.4108
24	.4108	.4401	.4694	.4108	.3227	.4694	.2347
Max	.6455	.7335	.5281	.7335	.6161	.6455	.4988
Min	.176	.2934	.2934	.2347	.2934	.2347	.0147
Avg	.3929	.4559	.4254	.4128	.4270	.3953	.3421

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 202 / 11KV Devangra SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0147			.0147	.0147		.0293
2	.0147	.0147		.0147	.0147		.0293
3	.0147	.0147	.0147	.0147	.0147	.0147	.0293
4	.0147	.0147		.0147	.0147		.0293
5	.0147	.0147		.0147	.0147		.0293
6	.0147	.0147	.0147	.0147	.0147	.0147	.0293
7	.0147	.0147		.0147	.0147		.0293
8	.0147		.0147	.0147	.0147	.0147	.0293
9	.0147		.0147	.0147		.0147	.0293
10	.088	.0147	.0293	.0293		.0293	.0147
11	.088		.1174	.0293		.0293	.0147
12	.088		.1174	.0293		.0293	.0147
13	.0587	.0293	.088	.044		.0293	.0147
14	.0587		.088	.044		.0293	.0147
15	.0587		.088	.044		.0293	.0147
16	.0587	.0293	.088	.044		.0293	.0147
17	.0587		.0587	.044		.0293	.0147
18	.0147	.0147	.0147	.0147		.0147	.0147
19	.0147		.0147	.0147		.0147	.0147
20	.0147		.0147	.0147		.0147	.0147
21	.0147		.0147			.0147	.0147
22	.0147		.0147	.0147		.0147	.0147
23	.0147		.0147	.0147		.0147	.0147
24	.0147	.0147	.0147	.0147	.0147	.0147	.0293
Max	.088	.0293	.1174	.044	.0147	.0293	.0293
Min	.0147	.0147	.0147	.0147	.0147	.0147	.0147
Avg	.0330	.0174	.0440	.0230	.0147	.0208	.0208

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154090 / 33 KV SUBSTATION SUGAON

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.0587
2							.0587
3							.0587
4							.088
5							.088
6							.088
7							.088
8							.088
9							.088
10	.2054	.0587	.1467	.0734		.0587	
11	.0587		.1174	.0734		.0293	
12	.088		.1174	.088		.0587	
13	.088	.1467	.1174	.088		.0587	
14	.088		.1174	.088		.0587	
15	.088		.1174	.088		.0587	
16	.088	.1174	.088	.088		.0587	
17	.088	.088	.088	.0734	.0587	.0587	
24							.0293
Max	.2054	.1467	.1467	.088	.0587	.0587	.088
Min	.0587	.0587	.088	.0734	.0587	.0293	.0293
Avg	.0990	.1027	.1137	.0825	.0587	.0550	.0733

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 201 / 11KV Mahalangra

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.1905			.2058	.1524
2		.2915	.1905	.1903		.2401	.1524
3		.2915	.2286			.2572	.1905
4		.3086	.2286			.2915	.1905
5		.3429	.2667	.2665		.3429	.2096
6		.3601	.2667			.3601	.2096
7		.3429	.2858	.3993		.3601	.2286
8	.3799	.3086	.2667			.3429	.2401
9	.2401	.2858		.2852		.3429	.2401
10	.1372	.1143	.1713		.1372	.3429	.1886
11	.1372	.1524	.2282		.1372	.3429	.1886
12	.1715	.2096	.3423		.1715	.2096	.1715
13	.2229	.2096	.3807		.1886	.2286	.1543
14	.2572	.2286	.3423		.2401	.2286	.1543
15	.2743	.2667	.3419		.2401	.2667	.12
16	.2915	.2667	.3423		.2058	.2286	.12
17	.2915	.2858			.1886	.1905	.1543
18	.1715	.1524			.1543	.2096	.1715
19	.1715	.1524			.1886	.2286	.2915
20		.1905			.2572	.2667	.3086
21	.2058	.2286			.2915	.2858	.3429
22	.2401	.2667			.2401	.2477	.2572
23	.2058	.2286		.1219	.2058	.1905	.2229
24	.1899	.2058	.1905	.188		.2058	.1905
Max	.3799	.3601	.3807	.3993	.2915	.3601	.3429
Min	.1372	.1143	.1713	.1219	.1372	.1905	.12
Avg	.2242	.2478	.2665	.2419	.2033	.2674	.2021

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 202 / 11KV Ganjur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1372	.1524			.1029	.1524
2		.1715	.1524	.1523		.1372	.1905
3		.1715	.1905			.2058	.1905
4		.2058	.2477			.2058	.1905
5		.2058	.3048			.2401	.2286
6		.2401	.3429			.2401	.2096
7		.2401	.3429			.2401	.2096
8	.1901	.1715	.1905			.1524	.2401
9	.1029	.1143	.1524	.1521		.1524	.2401
10	.1886	.1143	.1141		.1715	.1524	.1029
11	.1886	.2286	.1899		.1886	.2286	.1029
12	.3601	.3239	.2089		.2229	.3048	.1372
13	.2401	.3048	.2282		.2915	.2858	.1372
14	.2743	.3048	.2279		.2915	.3048	.1029
15	.3086	.2858	.2282		.2058	.3048	.1029
16	.3086	.2286	.2659		.1029	.2286	.0686
17	.2915	.1905			.1372	.2096	.1029
18	.1029	.1905			.1029	.1524	.1029
19	.1029	.1905			.1372	.7621	.2058
20		.2286			.1715	.1905	.2058
21	.1372	.2286			.2058	.1905	.2058
22	.1715	.2286			.1715	.2286	.1715
23	.1372	.1905	.1521		.1372	.1905	.1715
24	.1521	.1372	.1524	.1521		.1029	.1524
Max	.3601	.3239	.3429	.1523	.2915	.7621	.2401
Min	.1029	.1143	.1141	.1521	.1029	.1029	.0686
Avg	.2036	.2097	.2136	.1522	.1813	.2297	.1635

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154097 / 33 KV ASHTA S/S

Feeder No / Name : 203 / 11KV Ashta SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.381			.2572	.1905
2		.2743	.4001			.3086	.2667
3		.2743	.4572			.3429	.3048
4		.3086	.4572			.4115	.4191
5		.3086	.4954	.4563		.4115	.5335
6		.3086	.4954			.4458	.6478
7		.463	.4954	.5704		.4973	.743
8	.5888	.5144	.6668			.4954	.583
9	.5144	.4763	.5525	.6078		.4763	.5144
10	.2915	.2858	.2852		.2058	.3429	.2572
11	.2572	.1905	.152		.2229		.2915
12	.2229	.1715	.114		.2229		.3429
13	.1715	.1715	.1141		.2058	.1905	.4115
14	.1715	.1715	.114		.1886	.2286	.4801
15	.1715	.1715	.1521		.1886	.2477	.463
16	.2058	.1905	.152		.1715	.2286	.4458
17	.2058	.2286			.2572	.2286	.4801
18	.2058	.3429			.2743	.3048	.3258
19	.2743	.4572			.3429	.381	.4458
20		.4954			.4115	.4191	.4801
21	.3772	.4382			.3772	.4572	.4458
22	.3086	.4001			.3258	.4001	.4115
23	.2743	.3429	.3803		.2915	.3429	.3429
24	.2659	.2058	.381	.4183		.2058	.1905
Max	.5888	.5144	.6668	.6078	.4115	.4973	.743
Min	.1715	.1715	.114	.4183	.1715	.1905	.1905
Avg	.2817	.3097	.3470	.5132	.2633	.3466	.4174

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 201 / 11 KV LIMBALWADI SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.2241
9			.1307	
10			.1307	
11			.1867	
12	.2662		.1867	
13			.2241	
14	.3423			
21	.1331			
24		.1331		
Max	.3423	.1331	.2241	.2241
Min	.1331	.1331	.1307	.2241
Avg	.2472	.1331	.1718	.2241

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 202 / 11 KV DEVANGARA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.4668
9			.3361	
11			.2241	
12	.2236		.2241	
13			.2241	
14	.2422			
21	.3727			
24		.2795		
Max	.3727	.2795	.3361	.4668
Min	.2236	.2795	.2241	.4668
Avg	.2795	.2795	.2521	.4668

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

CHAKUR (R) S/DN[433] BU 5169

Substation No/ Name :- 154117 / 33/11 DEVANGARA

Feeder No / Name : 203 / 11 KV AMBULGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7				.2801
9			.2987	
10			.056	
11			.0373	
12	.0742		.0934	
13			.0934	
14	.0742			
21	.2231			
24		.0928		
Max	.2231	.0928	.2987	.2801
Min	.0742	.0928	.0373	.2801
Avg	.1238	.0928	.1158	.2801

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 201 / 11KV TOGARI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573	.8139	.7461	
2		.8573	.8478	.78	
3		.8573	.8817	.78	
4		.8916	.9156	.8478	
5		.9431	.9496	.9156	
6		1.0288	.9835	.9496	
7		.9945	1.0174	1.0004	
8		.8573	.9326	.9326	
9	.6516	.823	.9156	.8309	
10	.7202	.4115	.4409	.407	
11		.4748	.5087		.3601
12		.5087	.5256		
13	.1715	.5426	.5256		
14	.1372	.5087	.5256		.6001
15	.2401	.5426	.5087		.583
16	.2572	.5426	.5087		
17	.3086	.4409	.407		
18	.7888	.78	.7291		
19	.823	1.0852	.78		
20	1.2174	1.153	.8478		
21	1.1145	1.1022	.8478		
22	1.0288	1.0174	.8139		
23	.8573	.9496	.763		
24		.8573	.8478	.7461	
Max	1.2174	1.153	1.0174	1.0004	.6001
Min	.1372	.4115	.407	.407	.3601
Avg	.6397	.7928	.7432	.8124	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 202 / 11KV LASONA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9945	.8139	.8139	
2		.9945	.8139	.8139	
3		.9945	.9496	.8478	
4		1.0288	1.0174	.9835	
5		1.1145	1.0174	1.1191	
6		1.2003	1.2209	1.2887	
7		1.3375	1.3565	1.2548	
8		1.406	1.2209	1.0174	
9	1.0288	1.0288	1.2209	1.0513	
10	1.2003	.6859	1.1191	.6783	
11	.8573	.6783	1.2209		.6859
12	.8916	.8817	1.4243		.6859
13	.9259	1.0852	1.4243		.6859
14	.9431	1.1191	1.2548		.6687
15	1.166	1.153	1.2548		.6516
16	1.2003	1.2209	1.2887		
17	1.2003	1.2209	1.2548		
18	1.0288	.5426	.5426		
19	1.2003	.8817	.6783		
20	1.406	1.1191	.7461		
21	1.2003	1.2209	.8139		
22	1.1317	1.0174	.8478		
23	1.0802	.9496	.8478		
24		.9774	.7461	.8139	
Max	1.406	1.406	1.4243	1.2887	.6859
Min	.8573	.5426	.5426	.6783	.6516
Avg	1.0974	1.0355	1.0457	.9711	.6756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 203 / 11KV WALANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2572	.3391	.4409	
2		.2572	.3391	.5765	
3		.3429	.373	.6104	
4		.4458	.407	.6783	
5		.4801	.407	.78	
6		.5144	.4239	.8817	
7		.5487	.4409	.5765	
8		.4458	.5426	.6443	
9	.4115	.3772	.4409	.6104	
10	.1715	.3086	.2035	.5426	
11	.1715	.3391	.2374		.3429
12	.1715	.2713	.2713		.3429
13	.2401	.2035	.2713		.3429
14	.2743	.2374	.2713		.3086
15	.2743	.2713	.2374		.2743
16	.2743	.2374	.2374		
17	.2401	.2713	.2374		
18	.2743	.373	.4409		
19	.7545	.6104	.407		
20	.823		.407		
21	.7716	.9156	.4409		
22	.6859	.7122	.4409		
23	.6173	.6783	.373		
24		.2401	.2713	.373	
Max	.823	.9156	.5426	.8817	.3429
Min	.1715	.2035	.2035	.373	.2743
Avg	.4104	.4060	.3526	.6104	.3223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 205 / 11KV BORUL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4287	.4409	.2713	
2		.4287	.4748	.2713	
3		.4287	.5426	.3052	
4		.5144	.5765	.373	
5		.6859	.6104	.4409	
6		.8573	.6443	.5087	
7		.823	.6783	.6104	
8		.7202	.6104	.5426	
9		.6859	.5426	.4409	
10	.4115	.3086	.2713	.2713	
11	.3429	.407	.3391		.3086
12	.3086	.3391	.3391		.3086
13	.2743	.2713	.3391		.3429
14	.2743	.2713	.3391		.3086
15	.3429	.3052	.373		.2743
16	.2743	.3391	.373		
17	.3086	.3391	.4409		
18	.2058	.2374	.2035		
19	.5487	.4748	.2035		
20	.7888		.2035		
21	.7888	.7122	.2035		
22	.5144	.5426	.2035		
23	.4458	.3391	.2035		
24		.4115	.4409	.2035	
Max	.7888	.8573	.6783	.6104	.3429
Min	.2058	.2374	.2035	.2035	.2743
Avg	.4164	.4727	.3999	.3854	.3086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154010 / 33/11 DEVANI

Feeder No / Name : 206 / AMBEGAON

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.3391	.373	
2		.2743	.3391	.373	
3		.3086	.373	.39	
4		.3429	.407	.39	
5		.4801	.4409	.407	
6		.8573	.4748	.4239	
7		.6859	.5087	.5426	
8		.5144	.5935	.5087	
9	.4115	.4801	.4748	.4748	
10	.2058	.3258	.2713	.4409	
11	.2058	.407	.3052		.2915
12	.2229	.3391	.3391		.3086
13	.2058	.2374	.2374		.2401
14	.2058	.2543	.2374		.2401
15	.2229	.2543	.2035		
16	.2401	.2035	.2035		
17	.2401	.2713	.2374		
18	.2572	.2543	.2713		
19	.5144	.4748	.3052		
20	.6859	.6783	.3052		
21	.6859	.6783	.3391		
22	.6001	.5935	.3391		
23	.5144	.5426	.3222		
24		.2743	.3391	.4409	
Max	.6859	.8573	.5935	.5426	.3086
Min	.2058	.2035	.2035	.373	.2401
Avg	.3612	.4169	.3420	.4332	.2701

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822] BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 201 / JAWALGA SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2543	.2782	.3772	.2543	.2667	.6097
2	.285	.2515	.282	.4024	.2683	.2705	.6859
3	.3018	.285	.2896	.426	.2683	.2705	.8002
4	.3185	.2915	.3185	.4588	.2683	.3018	.9145
5	.3277	.3239	.3521	.503	.2713	.306	.9907
6	.3401	.3725	.3475	.5365	.3052	.306	
7	.3281	.6371	.4755	.5506	.407	.3841	
8	.3658	.6154	.4344	.3963	.4748	.3765	
9	.3353	.5765	.4214	.442	.407	.3567	1.0669
10	.381	.4954	.6668	.6287	.6097	.6478	.373
11		.381	.4572	.381	.381	.4763	.373
12		.3048	.3048	.3429	.3429	.381	.407
13		.2667	.3239	.2667	.2286	.3239	.3391
14		.2667	.2477	.3048	.2286		
15		.2286	.2286	.2667	.2286		
16		.2286		.2286	.2667	.4191	
17		.3048		.2667	.3048	.4001	.4239
18	.5716	.3429		.4001	.3048	.5144	.5716
19	.724	.5335	.6478	.9526	.4572	.7049	1.0479
20	1.0669	1.0098	1.105	1.0479	.724	.8573	.9526
21	.9526	.8573	1.0288	.9526	.6859	.743	.8954
22	.9907	.6859	.7621	.8573	.6097	.6478	.8383
23	.8764	.5335	.5716	.7621	.4572	.5716	.7621
24	.3086	.3391	.2743	.3429	.3391	.2401	.5335
Max	1.0669	1.0098	1.105	1.0479	.724	.8573	1.0669
Min	.285	.2286	.2286	.2286	.2286	.2401	.3391
Avg	.5296	.4328	.4675	.5039	.3789	.4439	.6992

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 202 / 11 KV KAUTHALA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0076	.0095		.0076	.0095	.0076	.0051
2	.0076	.0114		.0095	.0114	.0076	.0049
3	.0095	.0133		.0095	.0114	.0095	.005
4	.0133	.0171		.0133	.0133	.0114	.0069
5	.0171	.0191		.0171	.0152	.0133	.0069
6	.0191	.0191		.021	.0171	.021	.0072
7	.021	.0191		.021	.0152	.021	.0127
8	.021	.021		.021	.0191	.0191	.011
9	.0171	.0152		.0152	.0171	.0171	.009
10	.0051	.0058		.0104	.0055	.005	.0133
11	.0051	.0059		.0084	.0041	.0066	.0057
12	.0051	.0045	.0049	.0102	.0056	.0067	.0057
13	.0068	.0046	.0062	.0085	.0041	.0044	.0038
14	.0068	.0072	.0078	.0068	.0041	.0046	.0038
15	.0051	.0057	.0081	.0068	.004	.0045	.0038
16	.0051	.0056	.0079	.0068	.0027	.0062	.0038
17	.0051	.0072	.0097	.0068	.0026	.0045	.0057
18	.0057	.0057	.0057	.0057	.0057	.0057	.0057
19	.0095		.0095	.0095	.0114	.0114	.0095
20	.0114		.0152	.0114	.0133	.0152	.0133
21	.0114		.0114	.0114	.0095	.0114	.0133
22	.0095		.0095	.0095	.0076	.0095	.0114
23	.0095			.0076	.0076	.0076	.0095
24	.0057	.0095		.0057	.0076	.0076	.0055
Max	.021	.021	.0152	.021	.0191	.021	.0133
Min	.0051	.0045	.0049	.0057	.0026	.0044	.0038
Avg	.0100	.0109	.0087	.0109	.0094	.0099	.0076

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 203 / 11 KV MATEGADI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0038	.0038	.0038	.0038	.0038	.0038	.0032
2	.0057	.0057	.0038	.0038	1.3717	.0057	.003
3	.0076	.0057	.0038	.0057	.0057	.0057	.0045
4	.0076	.0076	.0038	.0076	.0057	.0057	.0043
5	.0095	.0076	.0057	.0076	.0057	.0076	.0041
6	.0095	.0076	.0076	.0076	.0076	.0095	.0048
7	.0114	.0095	.0095	.0095	.0076	.0095	.0057
8	.0095	.0095	.0076	.0095	.0095	.0095	
9	.0076	.0091	.0057		.0095	.0076	.0057
10	.0051	.0043	.0026	.0076	.0053	.004	.0057
11	.0049	.0045	.0027	.0049	.004	.0043	.0038
12	.0051	.0045	.0021	.0051	.0055	.0044	.0019
13	.0051	.0045	.0026	.005	.004	.0042	.0019
14	.0051	.0042	.0024	.0051	.004	.005	.0019
15	.0051	.0043	.0025	.0051	.004	.0036	.0019
16	.0034	.0042	.0027	.0051		.0038	.0019
17	.0034	.0092	.0041	.005		.0023	.0019
18	.0038	.0038	.0019	.0019		.0038	.0019
19	.0038	.0057	.0057	.0057	.0057	.0057	.0057
20	.0057	.0076	.0076	.0057	.0076	.0076	.0076
21	.0057	.0057	.0057	.0057	.0057	.0057	.0076
22	.0057	.0038	.0057	.0057	.0057	.0057	.0076
23	.0057	.0038		.0038	.0038	.0038	.0057
24	.0038	.0038	.0038	.0038	.0038	.0038	.0034
Max	.0114	.0095	.0095	.0095	1.3717	.0095	.0076
Min	.0034	.0038	.0019	.0019	.0038	.0023	.0019
Avg	.0060	.0058	.0045	.0057	.0708	.0055	.0042

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

DEVANI S/DN.[822]

BU 4822

Substation No/ Name :- 154101 / 33/11 KV JAWALGA

Feeder No / Name : 204 / Morge Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0091			.0091		
2		.0091			.0091		
3		.0091			.0091		
4		.0091			.0091		
5		.0091			.0091		
6	.0091	.0091			.0091		
7	.0091	.0091			.0091		
8	.0091	.0091			.0091		
9	.0274	.0091		.0274	.0091		
10	.0549	.0092	.0091	.0549	.0092	.0732	
11	.0549	.0092	.0091	.0549	.0092		.0366
12	.0457	.0092	.0091	.0457	.0092	.0366	.0366
13	.0457	.0092	.0091	.0274	.0092	.0366	.0732
14	.0549	.0092	.0091	.0091	.0092	.0091	
15	.0549	.0275		.0091	.0092		.0549
16	.0274	.0092	.0091	.0091		.0366	.064
17	.0274		.0091	.0091		.0732	.0549
18	.0366	.0459	.0091	.0091		.0457	.0457
19	.0091	.0092	.0091	.0091			
20	.0091	.0091	.0091	.0091			
21	.0091	.0092	.0091	.0091			
22	.0091	.0092	.0091	.0091			
23	.0091			.0091			
24		.0091			.0091		
Max	.0549	.0459	.0091	.0549	.0092	.0732	.0732
Min	.0091	.0091	.0091	.0091	.0091	.0091	.0366
Avg	.0279	.0117	.0091	.0201	.0091	.0444	.0523

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 201 / mortalwadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.5144	.3429	.5144		.4287	.3429
2	.3429	.5144	.4287	.5144			.3429
3	.3429	.5144	.8573	.6859		.8573	.5144
4	.6859	.6859	.8573	.8573			.6859
5	1.0288	.8573	1.0288	1.0288		1.0288	.8573
9		.3429		.3429	.6602	.3429	.3429
10		.2572		.3429		.3429	.3429
11				.3429			
12		.1715	.3429	.2572	.2572	.2572	.6859
13					.2572	.2572	
14			.2572			.2572	
15						.1715	
16	.3429		.3429			.2572	
19			1.0288				
20	.8573	.8573	1.0288				
21						.5658	
23	.5144				.4287		
24	.3429	.5144	.3429	.5144		.4287	.3429
Max	1.0288	.8573	1.0288	1.0288	.6602	1.0288	.8573
Min	.3429	.1715	.2572	.2572	.2572	.1715	.3429
Avg	.5334	.5230	.6235	.5401	.4008	.4330	.4953

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 202 / khandsari SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857	.0857	.0857		.0857	.2572
2		.0857	.0857	.0857			.2572
3		.0857	.0857	.0857		.0857	.2572
4		.0857	.0857	.0857			.3429
5		.0857	.0857	.0857		.0857	.3429
9		.0857				.0857	.3429
10		.0857		.0857			.2572
11				.0857			
12		.0857	.0857	.0762	.0857		.0476
13					.0857	.0857	
14			.0857			.0857	
15						.0857	
16			.0857			.0857	
17			.0857				
19			1.1145				
20	.4287	1.0288	1.0288				
21						.2572	
23	.4287				.4287		
24		.4287	1.0288	.6859		.4287	.2572
Max	.4287	1.0288	1.1145	.6859	.4287	.4287	.3429
Min	.4287	.0857	.0857	.0762	.0857	.0857	.0476
Avg	.4287	.2143	.3286	.1513	.2000	.1372	.2625

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 203 / wadhona

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.1715	.4287	.3429		.4287	.5144
2	.3429	.1715	.4287	.3429			.5144
3	.3429	.2572	.8573	.5144		.8573	.5144
4	.6859	.3429	.8573	.6859			
5	.8573	.3429	1.0288	1.0288		.8573	
9		.2572		.3429		.4287	.3429
10		.2572		.4287		.3429	.2572
11				.4287			
12		.3429	.3429	.3048	.2572	.2572	.3048
13					.2572	.2572	
14			.3429			.2572	
15						.2572	
16			.3429			.2572	
19			.6859				
20	.2572	.8573	.6859				
21						.5144	
23	.1715				.1715		
24	.3429	.1715	.3429	.3429		.4287	.5144
Max	.8573	.8573	1.0288	1.0288	.2572	.8573	.5144
Min	.1715	.1715	.3429	.3048	.1715	.2572	.2572
Avg	.4179	.3172	.5767	.4763	.2286	.4287	.4232

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154012 / 33 kv s/s hali

Feeder No / Name : 204 / shelgaon

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.3429	.2572	.5144		.2572	.1715
2	.6859	.3429	.3429	.6859			.1715
3	.8573	.3429	.4287	.6859		.3429	
4	.8573	.4287	.4287	.7716			
5	.8573	.4287	.8573	.8573		.3429	
6	1.0288	.9431	.8573	1.0288		.4287	
7	1.0288	1.0288	1.0288	1.2003			
8	1.0288	1.0288	1.0288	1.3717		.8573	
9		.4287		.4287		.4287	.4287
10		.3429		.4287		.2572	.3429
11			.1715	.2572			
12		.3429		.1715	.1715	.1715	.1715
13					.1715	.1715	
14	.8573					.1715	
15						.1715	
16			.1715			.1715	
19			.1715				
20	.6859	.4287	.3429				
21						.1715	
23	.2572				.1715		
24	.2572	.2572	.1715	.1715		.1715	.1715
Max	1.0288	1.0288	1.0288	1.3717	.1715	.8573	.4287
Min	.2572	.2572	.1715	.1715	.1715	.1715	.1715
Avg	.7573	.5144	.4814	.6595	.1715	.2940	.2429

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 201 / telgaon SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0165	.0195	.012	.0181	.0124	.0123	.0159
2	.0165	.0195	.0137	.0181	.0142	.0123	.0159
3	.0165	.0195	.0137	.0181	.0142	.014	.0159
4	.0183	.0213	.0154	.0199	.0159	.014	.0177
5	.0274	.0301	.0206	.0271	.0195	.0158	.0177
6	.0293	.0337	.024	.0344	.0266		.0248
7	.0271	.0319	.024	.0308	.0266	.0263	.0248
8	.0271	.0283	.0189	.029	.023	.0193	.0266
9	.0206	.0235	.0159	.0253	.0154	.0137	.0248
10	.0154		.023	.0154	.0206	.0235	.0213
11	.0189	.0199	.0301	.0291	.0223	.0145	.0142
12	.0189	.0253	.0213	.0377	.0257	.0235	.0106
13	.0223		.0266	.0377	.0257	.0271	.0142
14	.0189		.0337	.036	.024	.029	
15	.0206		.0354	.036	.0274		.0159
16	.0189		.0309	.0326	.0274	.0253	.0159
17	.0124	.0291	.0344	.0319	.0274	.0253	.0181
18		.0086	.0127	.0124	.0103	.0183	.0199
19	.0213	.012	.0183	.0159	.0137	.0256	.0256
20	.0266	.0206	.0219	.0159	.0189	.0238	
21	.023		.0219	.0142	.0154	.0201	
22	.0213		.0219	.0124	.0137	.0195	
23	.0195		.0201	.0124	.0137	.0177	
24	.0165	.0195	.012	.0183	.0124	.0123	.0177
Max	.0293	.0337	.0354	.0377	.0274	.029	.0266
Min	.0124	.0086	.012	.0124	.0103	.0123	.0106
Avg	.0206	.0226	.0218	.0241	.0194	.0197	.0188

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 202 / shirur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0165	.0189		.0217	.0177	.0193	.0124
2	.0165	.0189		.0217	.0195	.0193	.0124
3	.0165	.0189		.0217	.0213	.0193	.0124
4	.0165	.0189		.0235	.0248	.0193	.0142
5	.0219	.024		.0235	.0213	.0206	.0142
6	.0238	.0274		.029	.0266	.0245	.0159
7	.029	.0319	.0291	.0326	.0301	.0298	.0195
8	.029	.0266	.0274	.0308	.0283	.028	.0213
9	.024	.0235	.023	.0271	.024	.0245	.0248
10	.0189		.0213	.0206	.0171		.0213
11	.0189	.0235	.0248	.0223		.0217	.0195
12	.0171	.0217	.0248	.0223		.0199	.0177
13	.0189	.0217	.0248	.024	.0171	.0199	.0159
14	.0171		.023	.0274	.0171		.0177
15	.0189		.0177	.0223	.0171	.0163	.0177
16	.0171		.0206	.0206	.0189	.0199	.0177
17	.0213	.0223	.0235	.0213	.0206	.0163	.0181
18		.0206	.0199	.0177	.0206	.0219	.0253
19	.0283	.024	.0256	.0266	.0274	.0274	.0238
20	.0283		.0311	.0266	.0274	.0274	.0219
21	.0283		.0293	.023	.0257		.0238
22	.023		.0274	.0213	.024	.023	.0219
23	.0195		.0238	.0195	.0206	.0195	.0201
24	.0165	.0189		.0219	.0177	.0193	.0142
Max	.029	.0319	.0311	.0326	.0301	.0298	.0253
Min	.0165	.0189	.0177	.0177	.0171	.0163	.0124
Avg	.0211	.0226	.0245	.0237	.0220	.0218	.0185

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 203 / belur

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0073	.0089	.0103	.0109	.0089	.0088	.0089
2	.0073	.0089	.0103	.0109	.0089	.0088	.0177
3	.0073	.0089	.012	.0127	.0089	.0105	.0089
4	.0073	.0089	.012	.0127	.0106	.0105	.0089
5	.0128	.0142	.0154	.0145	.0106	.0105	.0089
6	.0146	.0142	.0171	.0163	.0124	.0103	.0106
7	.0145	.0177	.0206	.0217	.0159	.0158	.0159
8	.0145	.0159	.0189	.0235	.0177	.0158	.0142
9	.0137	.0163	.0195	.0199	.0171	.0158	.0124
10	.0069		.0071	.0103	.0069	.0072	.0106
11	.0069			.0086			.0124
12	.0034		.0053	.0069			.0106
13	.0051		.0035	.0069	.0051		.0106
14	.0034			.0051	.0034	.0072	.0106
15	.0051		.0053	.0051		.0072	.0124
16	.0051		.0054	.0051		.0072	
17	.0053	.0051	.0072	.0071	.0051	.0072	
18		.0069	.0072	.0071	.0069	.0091	
19	.0106	.0137	.011	.0124	.012	.0128	.0128
20	.0106		.0128	.0124	.0103	.0128	
21	.0124		.0128	.0106	.012	.011	
22	.0106		.011	.0089	.0103	.0089	.0073
23	.0089		.0073	.0089	.0086	.0089	.0055
24	.0073	.0089	.0103	.011	.0089	.0088	.0089
Max	.0146	.0177	.0206	.0235	.0177	.0158	.0177
Min	.0034	.0051	.0035	.0051	.0034	.0072	.0055
Avg	.0087	.0114	.0110	.0112	.0100	.0102	.0110

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154020 / shirur taj.

Feeder No / Name : 204 / shirur Exp.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183	.0177	.0171	.0181	.0177	.0171	.0177
2	.0183	.0177	.0171	.0181	.0177	.0171	.0177
3	.0183	.0177	.0171	.0181	.0177	.0171	.0177
4	.0183	.0177	.0171	.0181	.0177	.0171	.0177
5	.0183	.0177	.0171	.0181	.0177	.0171	.0177
6	.0183	.0177	.0171	.0181	.0177	.0171	.0177
7	.0181	.0177	.0171	.0181	.0177	.0175	.0177
8	.0181	.0177	.0171	.0181	.0177	.0171	.0177
9	.0171	.0181	.0177	.0181	.0171	.0175	.0177
10			.0177	.0171	.0171	.0181	.0177
11			.0177	.0171		.0181	.0177
12			.0177	.0171		.0181	.0177
13			.0177	.0171	.0171	.0181	.0177
14	.0171		.0177	.0171	.0171	.0181	.0177
15	.0171		.0177	.0171	.0171	.0181	.0177
16	.0171		.0171	.0171	.0171	.0181	.0177
17	.0177	.0171	.0181	.0177	.0171	.0181	.0181
18		.0171	.0181	.0177	.0171	.0183	.0181
19	.0177	.0171	.0183	.0177	.0171	.0183	.0183
20	.0177		.0183	.0177	.0171	.0183	.0183
21	.0177		.0183	.0177	.0171	.0183	.0183
22	.0177		.0183	.0177	.0171	.0177	.0183
23	.0177		.0183	.0177	.0171	.0177	.0183
24	.0183	.0177	.0171	.0183	.0177	.0171	.0177
Max	.0183	.0181	.0183	.0183	.0177	.0183	.0183
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0177
Avg	.0178	.0176	.0176	.0177	.0173	.0177	.0179

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 201 / kolnoor

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6001	.5658			.6859	.5658
2	.6001	.6859	.7545			.6859	.5658
3	.6516	.6859	.7545		.5144	.6859	.5658
4	.6859	.7716	.7545			.7716	.7545
5	.8573	.8573	.7545			.9431	.7545
6	.8573	1.0288	.9431			1.1145	.9431
7	.8573	1.0288	.9431			.8573	.9431
8		.7716	.9431	.823	.8573	.8573	.7545
9	.6001			.8573	.8573	.8573	.6859
10	.4287	.5144		.7716	.6001	.5144	
11			.6859	.6859	.6001		
12		.5658	.8573	.8573	.6001		.4801
13		.7545	.8573	.8573			.5144
14		.7545	.8573		.5144		.5144
15		.7545	.8573	.8573	.5144		.5144
16	.5144	.7545	.8573		.5144		
17	.6001	.7545	.7716		.5144		
18	.5144	.8488			.6859		.5144
19	.6001	.9431		1.0288	.9431	.7545	.5487
20	.6859	.7545		.8573	1.0288	.7545	.5144
21	.7716	.7545		.7716	1.0288	.5658	
22	.6001	.7545		.6859	.8573	.5658	
23	.6001	.5658			.8573	.5658	.4287
24	.5144	.6001	.5658		.5144	.6859	.5658
Max	.8573	1.0288	.9431	1.0288	1.0288	1.1145	.9431
Min	.4287	.5144	.5658	.6859	.5144	.5144	.4287
Avg	.6363	.7502	.7952	.8230	.7060	.7416	.6182

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154037 / kolnoor

Feeder No / Name : 202 / sonwala

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4287	.9431		.4287	.3429	.3772
2	.4287	.4287	.7545		.4287	.3429	.3772
3	.5144	.4287	.7545			.3429	.3772
4	.6001	.4287	.7545		.5144	.4287	.3772
5	.6859	.4287	.7545		.6001	.4287	.3772
6	.7202	.6001	.7545		.6001	.5144	
7	.823	.7202	.7545		.6859	.6859	.5658
8	.7716	.7716	.7545	.5144	.6859	.6859	.5658
9	.6859	.6859		.5144		.6001	.5144
10	.8573	.7716		.6859	1.0288	.8573	.4287
11		.8488		.6001	.7716	.9431	.4801
12				.6859	.6859	.9431	.5144
13				.6859		.5658	.5144
14					.5144	.5658	.4801
15		.5658	.3429		.6173	.5658	.4801
16	.4801		.3429		.5487	.7545	.4287
17	.6859	.5658	.4287		.5487	.6573	.4287
18	.6859	.9431		.3429	.6859		.5144
19	.9431	1.3769		1.0288	1.0288	.5658	.6001
20				1.1145	1.0288	.5658	.5144
21	.6859	1.3203		1.0288	1.0288	.5658	
22	.6001	.9431		.6859		.3772	
23	.5144	.9431		.5144	.6859	.3772	.4287
24	.4287	.4287			.5144	.3429	.3772
Max	.9431	1.3769	.9431	1.1145	1.0288	.9431	.6001
Min	.4287	.4287	.3429	.3429	.4287	.3429	.3772
Avg	.6411	.7173	.6672	.7002	.6816	.5661	.4630

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 201 / kumtha

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0094	1.0829	.0075	.0093	.0082
2		.0094	.9619	.0075	.011	.0082
3		.0113	.7922	.0094	.0106	.0097
4		.0112	.8962	.0094	.0109	.0112
5		.0131	.9997	.0093	.0112	.0109
6		.0148	1.4335	.0112	.0109	.0131
7		.0129	1.6409		.0146	.013
8	.0163	.0111	1.587		.0146	.0127
9	.0211	.0163	.0191		.0201	.0112
10	.018		.0203		.0146	.0092
11	.0141	.0166	.0174		.013	.0074
12	.0131	.0182	.0171		.0131	.0055
13		.018	.0145		.0113	.0055
14		.0194	.0188		.0113	.0056
15		.0197	.0193		.0115	.0037
16		.0194	.0178		.0131	.0056
17		.3768	.0076		.0112	.0109
18		.8848	.0076		.0113	.0139
19		1.0322	.0122		.0112	.0168
20		1.2125	.0107		.0112	.0081
21		1.326	.0107		.0081	.0081
22		1.2763	.0091		.0082	.0122
23			.0078		.0096	.0107
24		.0097	1.1105	.008	.008	.0081
Max	.0211	1.326	1.6409	.0112	.0201	.0168
Min	.0131	.0094	.0076	.0075	.008	.0037
Avg	.0165	.2881	.4465	.0089	.0117	.0096

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154079 / kumtha

Feeder No / Name : 202 / chimachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0183	.0164	.0152		.0112
2		.0198	.0182	.0168		.0091
3		.0211	.0213	.0168		.0092
4		.0211	.0218	.0166		.0073
5		.0223	.0232	.0181		.028
6		.0238	.0262	.0196		.0348
7		.0312	.0369			.0201
8	.0261	.0253	.0323		.0291	.0205
9	.0271	.0166	.0166		.0274	.0197
10	.0112				.0075	.0187
11		.7655			.022	.0158
12	.0054	.6161			.018	.0142
13		.6036	.0092		.0075	.016
14		.5847	.0074		.0055	.0162
15		.5658	.0074		.0075	.0158
16		.6161	.0056		.0073	.018
17		.4588	.0075		.0089	.0075
18		.6908	.0093		.011	.0094
19		1.2883	.0131		.0093	.0187
20		1.7353	.0131		.0073	
21		1.5497	.0112		.0092	
22		1.251	.0094		.0091	
23			.0094		.0093	
24		.0094	1.1203	.0094	.0112	
Max	.0271	1.7353	1.1203	.0196	.0291	.0348
Min	.0054	.0094	.0056	.0094	.0055	.0073
Avg	.0175	.4970	.0684	.0161	.0122	.0163

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 201 / hadolti

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5201	.5144	.5201	.5316	.6135	.5144	.5258
2	.6068	.5144	.6068	.6135	.6135	.5144	.5258
3	.6068	.5144	.6068	.6135	.6135	.5144	.5258
4	.6068	.5144	.6935	.6135	.6135	.5144	.5258
5	.6068	.5144	.7802	.6135	.6135	.5144	.5258
6	.6935	.6001	.8669	.6935	.8764		.6135
7	.7802	.6001	.8669	.7802	.8764	.6001	.4382
8	.7802	.6859	.9536	.8669	.964	.6859	.7011
9	.6935	.5144	.8669	.7802	.964	.6001	.7011
10	.4287		.4239	.5201	.4287	.6859	.5258
11	.5144	.4239	.4287	.4334	.4287	.5258	.4382
12	.4287	.4239	.4334	.3467	.3429	.5258	.3467
13	.4287	.4239	.4334	.3467	.3429		.3467
14	.3429	.3391	.4334		.4287	.4382	.3467
15	.3429	.3391	.4334	.4334	.4287	.4382	.3467
16	.4287	.3391	.4334	.4334	.4287	.4382	.3467
17	.4287	.3391	.4334	.4334	.4287	.4382	.4334
18		.4239	.4382	.3467	.4287	.5258	
19	.7716	.5087	.6201	.6068	.6001	.7011	.4382
20	.7716	.6783	.7973	.6935	.6859	.7011	.5258
21	.6859	.6783	.7087	.6935	.6859	.7011	.5316
22	.6001	.5935	.7087	.6068	.6001	.6135	.5316
23	.5144	.5087	.6201	.5201	.5144	.5258	.443
24	.5201	.5144	.5201	.443	.6135	.5144	.5258
Max	.7802	.6859	.9536	.8669	.964	.7011	.7011
Min	.3429	.3391	.4239	.3467	.3429	.4382	.3467
Avg	.5697	.5003	.6095	.5636	.5890	.5560	.4874

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 202 / jagalpur SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3467	.4287	.4334	.5316	.4382	.4287	.3506
2	.4334	.4287	.4334	.5316	.4382	.4287	.3506
3	.4334	.4287	.5201	.5316	.4382	.4287	.3506
4	.4334	.4287	.5201	.5316	.4382	.4287	
5	.5201	.4287	.5201	.5258	.5258	.4287	
6	.5201	.5144	.6068	.6135	.6135		.3506
7	.5201	.5144	.6935	.6935	.7011	.5144	.3506
8	.6068	.5144	.6935	.6935	.7011	.5144	.5258
9	.5201	.5144	.5201	.6935	.7011	.5144	.5258
10	.2572		.3467	.4334	.2572	.3429	.3506
11	.4287			.3467	.3429	.2629	.2629
12	.3429			.2601	.3429	.2629	
13	.3429	.2543		.2601	.3429	.2629	.2601
14	.2572	.2543	.1715		.3429	.2629	
15	.3429	.2543	.2572	.2601	.3429	.2629	.3467
16	.3429	.2543	.2601	.2601	.3429	.3506	.4334
17	.3429	.1696	.2601		.3429	.3506	.4334
18		.2543	.2629	.2601	.3429	.3506	.3467
19	.5144	.3391	.3506	.3467	.4287	.4382	.3506
20	.5144	.4239	.4382	.4334	.5144	.4382	.4382
21	.4287	.4239	.4382	.4334	.5144	.4382	.3544
22	.4287	.4239	.3544	.3467	.4287	.3506	.3544
23	.4287	.3391	.3544	.3467	.4287	.3506	.3544
24	.3467	.5144	.4334	.443	.4382	.4287	.3506
Max	.6068	.5144	.6935	.6935	.7011	.5144	.5258
Min	.2572	.1696	.1715	.2601	.2572	.2629	.2601
Avg	.4197	.3860	.4223	.4444	.4479	.3844	.3721

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154082 / Hadolti

Feeder No / Name : 203 / walsangi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3391	.2572	.3391	.3544	.3506	.3429	.3506
2	.3391	.2572	.3391	.3544	.3506	.3429	.4382
3	.3391	.2572	.3391	.3544	.3506	.3429	.4382
4	.3391	.2572	.3391	.3544	.3506	.3429	.4382
5	.4239	.3429	.4239	.4382	.4382	.3429	.4382
6	.4239	.3429	.4239	.5258	.5258		.4382
7	.4239	.3429	.4239	.6068	.5258	.5144	.4382
8	.5087	.3429	.4239	.5201	.4382	.6001	.4382
9	.4239	.3391	.3391	.3467	.4382	.6001	
10	.5144		.4334	.2601	.3429	.3429	
11	.3429	.5201	.6001	.6935	.4287	.7011	
12	.3429	.4334	.6935	.6935	.3429	.7011	.1791
13	.3429		.6935	.6068	.3429	.5258	.1734
14	.3429	.4334	.6068		.4287	.5258	.1734
15	.3429	.4334	.6068	.2601	.4287	.5258	.1734
16	.3429	.4334	.5201	.6935	.4287	.5258	.1734
17	.3429	.4334	.5201	.6935	.4287	.5258	
18		.2543	.1753	.2601	.2572	.3506	.2629
19	.4287	.3391	.3506	.3467	.4287	.4382	.3506
20	.4287	.4239	.4382	.4334	.4287	.4382	.4382
21	.3429	.4239	.3506	.4334	.4287	.4382	.3544
22	.3429	.3391	.3544	.3467	.3429		.3544
23		.3391	.3544	.3467	.3429	.3506	.3544
24	.3391	.3429	.3391	.3544	.3506	.3429	.2629
Max	.5144	.5201	.6935	.6935	.5258	.7011	.4382
Min	.3391	.2543	.1753	.2601	.2572	.3429	.1734
Avg	.3799	.3586	.4345	.4469	.3967	.4619	.3334

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 201 / jalkot

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.5658	.7545	.5658	.6602	.6602	.6602	.5868
9	.6602	.6602	.4973	.6706	.6602	.7545	.5868
12	.6602	.4715	.5801		.5658	.6602	.5868
15			.6706				
16	.6602	.4715		.5658	.5658	.5658	.5868
18			.5868				
20		.5658		.6602	.6602		.6706
21	.7545						
24	.5658	.5658	.5658	.503	.6602	.6602	.503
Max	.7545	.7545	.6706	.6706	.6602	.7545	.6706
Min	.5658	.4715	.4973	.503	.5658	.5658	.503
Avg	.6445	.5816	.5777	.6120	.6287	.6602	.5868

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 202 / kunki

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3							.1848
4	.4191	.4191	.6706	.503	.3353	.4191	
8				.663			
9	.5868	.503	.6706	.7459	.6706	.6706	
12	.1677	.1867	.1677		.1867	.2801	.3315
15			.1715				
16	.1677	.1867			.1867	.2801	.4973
18			.1753	.1867			
20	.1677	.2801		.2801	.2801		.1715
24	.3353	.3353	.2801	.3353	.2801	.2801	.1715
Max	.5868	.503	.6706	.7459	.6706	.6706	.4973
Min	.1677	.1867	.1677	.1867	.1867	.2801	.1715
Avg	.3074	.3185	.3560	.4523	.3233	.386	.2713

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154088 / Jalkot

Feeder No / Name : 203 / ravankola SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4	.2801	.2772	.2801	.1867	.2801		.4287
8				.1677			
9	.2801	.2772	.1677		.2801	.2801	.4287
10				.2572			
12	.3696	.4191	.4973		.6706	.6706	.1715
15			.663				
16	.3696	.4191		.6706	.503	.6706	.2572
18			.8288				
20	.2772	.2801		.2801	.2801		.2572
24	.2801	.2772	.2801	.2572	.2801	.2801	.3429
Max	.3696	.4191	.8288	.6706	.6706	.6706	.4287
Min	.2772	.2772	.1677	.1677	.2801	.2801	.1715
Avg	.3095	.3250	.4528	.3033	.3823	.4754	.3144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 202 / sandol

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.1524	.1524	.1524	.1524		
8					.1524	.7011
15					.5335	.1524
24	.1524	.1524	.1524	.1524		.1524
Max	.1524	.1524	.1524	.1524	.5335	.7011
Min	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.1524	.1524	.1524	.1524	.3430	.3353

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

SHIRUR (R) S/DN[434] BU 5193

Substation No/ Name :- 154089 / Dongraj

Feeder No / Name : 203 / jaybhachi wadi

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7	.8573	.6516	.9602	1.1145		
8					.6001	.3429
15					.6859	.5144
24	.3429	.3429	.3429	.3429		.3429
Max	.8573	.6516	.9602	1.1145	.6859	.5144
Min	.3429	.3429	.3429	.3429	.6001	.3429
Avg	.6001	.4973	.6516	.7287	.643	.4001

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 201 / 11 KV TOWN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8817	1.0566	.9393	.9496	1.0059	.9955
2	.8589	.8817	1.0498	.8907	.9496	1.0059	.9694
3	.9055	.8478	1.0498	.8907	.9496	.8907	.9694
4	.9511	.8478	1.0631	.9717	.9835	.9745	.985
5	.985	.8817	1.0923	1.0526	.9835	1.0402	.9991
6	1.0566	.9496	1.1317	1.085	1.0513	1.1145	1.1568
7	1.1919	1.1022	1.1869	1.2955	1.2548	1.2483	1.3003
8	1.3203	1.153	1.2717	1.3603	1.3904	1.3565	1.3565
9	1.1869	1.0692	1.2003	1.4582	1.1869	1.2003	
10	1.0682		1.2003	1.4752	1.1616	1.1919	
11		1.0749	1.1145	1.3904	1.1393	1.1919	1.1869
12		1.0749		1.2548	1.1163	1.1163	1.0852
13		1.0387		1.1191	1.0924	1.0974	.9496
14		.9955		1.0513	1.0498	.964	.9156
15	1.1022	.9694	.8573	.9156	1.0242	.964	.8817
16	.9835	.924		.8478	1.0242	.9313	.8648
17	1.0174	.985	.9602	.9496	1.0317	1.0867	.9835
18	1.0852	1.0402	.9717	1.1361	1.166	1.2689	1.153
19	1.2887	1.2174	1.1336	1.3395	1.3395	1.3735	1.3565
20	1.3735	1.3735	1.2955	1.3904		1.3546	1.3226
21	1.2209	1.4243	1.2955	1.2378		1.3032	1.2209
22	1.153	1.286	1.2146	1.153		1.1869	1.153
23	1.0174	1.1443	1.1012	1.0852		1.0974	1.0852
24	.9335	.9156	1.0867	.9717	.9602	1.0349	1.1104
Max	1.3735	1.4243	1.2955	1.4752	1.3904	1.3735	1.3565
Min	.8589	.8478	.8573	.8478	.9496	.8907	.8648
Avg	1.0798	1.0469	1.1167	1.1359	1.0902	1.1250	1.0910

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 202 / 11 KV NAGARPALIKA(Nalgir)

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378	.2035	.3155	.2572	.2374	.2534	.2715
2	.2195	.2035	.3155	.2572	.2374	.2378	.2378
3	.2195	.2035	.3012	.2572	.2374	.2378	.2378
4	.2378	.2035	.2865	.2572	.2374	.2378	.2534
5	.2614	.2204	.2865	.2743	.2374	.2686	.2534
6	.2534	.2374	.2865	.2743	.2713	.3012	.2865
7	.3467	.3052	.3155	.3429	.3222	.3155	.3155
8	.3601	.3391	.3429	.4287	.39	.4748	.3429
9	.373	.3506		.4239	.3467	.4748	
10	.373	.3561		.4409	.3189	.4458	
11		.373		.4748	.3681	.4334	.5596
12		.373		.4748	.4239	.4334	.5087
13				.4409	.4115	.4334	.4578
14		.4024		.4409	.4115	.4557	.4239
15	.5087	.4191		.407	.3988	.4748	.39
16	.4578	.4527		.373	.4031	.4031	.373
17	.4748	.4527			.3856	.4557	.407
18	.5087	.4527		.4409	.4748	.4973	.4917
19	.5765	.4862		.5087	.5533	.5256	.5087
20	.5256	.503		.4748		.4801	.4578
21	.5087	.4908		.4239		.4334	.407
22	.3391	.4382		.3391		.3601	.3561
23	.2743	.4207		.2713		.298	.3052
24	.2743	.2374	.3467	.2572	.2743	.2534	.2896
Max	.5765	.503	.3467	.5087	.5533	.5256	.5596
Min	.2195	.2035	.2865	.2572	.2374	.2378	.2378
Avg	.3665	.3532	.3108	.3714	.3471	.3827	.3698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 203 / 11 KV TELEPHONE Express NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0848	.0905	.0905	.0848	.0905	.0905
2	.0905	.0678	.0905	.0905	.0848	.0905	.0905
3	.0905	.0678	.0905	.0905	.0848	.0905	.0905
4	.0905	.0678	.0905	.0905	.0848	.0905	.0905
5	.0905	.0848	.0905	.0905	.0848	.0905	.0905
6	.0905	.0848	.0905	.0905	.0848	.0905	.0905
7	.0905	.0848	.0905	.0905	.0848	.0905	.0905
8	.0905	.0848	.0905	.1086	.0848	.0905	.0905
9	.0848	.0905		.1017	.0905	.0905	
10	.0848	.1075		.1017	.0905	.0905	
11		.124		.1696	.1052	.1075	.0848
12		.1417		.1696	.1214	.124	.1357
13		.124		.1357	.1214	.1227	.1357
14		.1402		.1357	.1372	.1214	.1357
15	.1526	.156		.1526	.1372	.1372	.1357
16	.1526	.1715		.1526	.1372	.1372	.1526
17	.1543	.1417		.1357	.1526	.1187	.1526
18	.0848	.0905		.0848	.1097	.1052	.0848
19	.0848	.0905		.0848	.0905	.0905	.0848
20	.0848	.0905		.0848		.0905	.0848
21	.0848	.0905		.0848		.0905	.0848
22	.0848	.0905		.0848		.0905	.0848
23	.0848	.0905		.0848		.0905	.0848
24	.0905	.0848	.0905	.0905	.0857	.0905	.0905
Max	.1543	.1715	.0905	.1696	.1526	.1372	.1526
Min	.0848	.0678	.0905	.0848	.0848	.0905	.0848
Avg	.0976	.1022	.0905	.1082	.1029	.1009	.1026

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154042 / 33/11 KV Udgir

Feeder No / Name : 204 / 11KV AMBEDKAR CHOWK
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6274	.6443	.9665	.6371	.6783	.6443	.78
2	.5765	.6443	.8987	.6371	.6783	.6443	.78
3	.6783	.6443	.8478	.6371	.6783	.6443	.763
4	.7291	.6783	.8478	.6706	.6783	.6783	.763
5	.763	.7291	.8478	.8383	.7291	.8478	.763
6	.7969	.8139	.8987	.9221	.7969	.9326	.9326
7	.8987	1.0513	.9724	1.0898	.9496	1.0059	1.1022
8	.9835	1.0174	1.073	1.1233	1.0682	1.1401	1.1191
9	.9156	.9496		1.153	1.0004	1.0898	
10	.8817			1.153	.9496	1.0059	
11				1.0852	.9326	1.0059	.9665
12		1.0004		1.0174	.9156	1.0059	.8817
13		1.0059		.9496	.9326	.9326	.8139
14		.9556		.9156	.9496	.9326	.8139
15	.964	.9156		.8817	.9665	.9326	.78
16	1.0343	.8648		.8478	.9496	.9326	.78
17	1.0631	1.0174		.9496	.9326	1.073	.8817
18	1.1317	1.1736		1.0343	1.1736	1.2548	1.1869
19	1.2209	1.2071		1.2039	1.3748	1.3735	1.2209
20	1.2717	1.2239		1.2887		1.2071	1.1191
21	1.2039	1.1736		.9665		1.073	1.0852
22	.8478	1.1233		.8478		.9496	.8139
23	.7461	1.0852		.78		.8139	.7461
24	.6952	.6783	1.0174	.6706	.6516	.6783	.7969
Max	1.2717	1.2239	1.073	1.2887	1.3748	1.3735	1.2209
Min	.5765	.6443	.8478	.6371	.6516	.6443	.7461
Avg	.9015	.9362	.9300	.9292	.8993	.9499	.9041

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 202 / 11 KV TALWES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5487			.4755		.5868
2		.5068			.4706		.6371
3		.5544			.4755		.6706
4		.5487			.4805		.7545
5		.5792			.5487		.8383
6		.7316			.6878		.8383
7		.9145			.9412		.8383
8		1.0974			1.0974		1.1145
9		.8718	.8779		.9389		1.0059
10		.8718	.9145		.8383		.9145
11		.8718	.8048		.6036		.724
12		.8383	.7316		.6706		.6219
13		.6706	.6154		.6036		.5068
14		.8383	.6878		.6371		.5068
15		.7716	.5792		.6371		.5121
16		.6706	.695		.6706		.5068
17	.724			.695		.5868	
18	.7682			.7316		.8383	
19	.9145			.9145		.9221	
20	.9412			.8688		.9221	
21	.8688			.7316		.7545	
22	.8131			.6584		.6706	
23	.7316			.6154		.6371	
24		.5853			.4805		.5868
Max	.9412	1.0974	.9145	.9145	1.0974	.9221	1.1145
Min	.724	.5068	.5792	.6154	.4706	.5868	.5068
Avg	.8231	.7336	.7383	.7450	.6622	.7616	.7155

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 205 / 11KV MIDC

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5658			.4904		.4694
2		.5281			.4854		.6706
3		.5228			.4904		.6706
4		.5281			.4904		.7545
5		.5281			.5658		.8383
6		.8299			.9054		.9221
7		1.0562			1.2071		.9431
8		1.0185			1.0242		1.3032
9		.8718	1.0185		1.0059		1.6409
10		.8718	1.2071		1.5089		1.6221
11		1.1401	1.2449		1.5424		1.5466
12		1.2574	1.2071		1.4251		1.4712
13		1.2071	1.2449		1.3413		1.4335
14		1.0059	1.2071		1.4251		1.4335
15		1.1065	1.2071		1.0059		1.3957
16		.5868	1.094		1.0562		1.358
17	.8676			1.0185		1.4251	
18	.9054			1.0185		1.4251	
19	1.0562			1.0562		1.3413	
20	1.0562			.9054		1.1401	
21	.9431			.7922		1.0898	
22	.7922			.7167		.8383	
23	.6722			.5853		.6706	
24		.6036			.4904		.4694
Max	1.0562	1.2574	1.2449	1.0562	1.5424	1.4251	1.6409
Min	.6722	.5228	1.0185	.5853	.4854	.6706	.4694
Avg	.8990	.8370	1.1788	.8704	.9683	1.1329	1.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154053 / 33/11 KV LONI

Feeder No / Name : 208 / VAISHALI AGRO EXPRESS

SHEDDABLE RURAL

FEEDER Feeder KV- 11 /

OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0366			.0366		.0343
2		.0366			.037		.0362
3		.0362			.0366		.0362
4		.0366			.0362		
5		.037			.0366		
6		.0366			.0366		.0343
7		.0366			.0362		
8		.0366			.0366		.0362
9		.0343	.0362		.0343		.0366
10			.0366		.0335		.0366
11			.0366				.0362
12		.0343	.0366		.0343		.0366
13		.0343	.0366		.0343		.0366
14			.0366		.0343		.0366
15		.0335	.0366		.0343		.0362
16		.0343	.0366		.0343		.0366
17	.0366			.0366		.0362	
18	.0366			.0366			
19	.0366			.0366		.0362	
20	.0366			.0366		.0335	
21	.0366			.0362			
22	.0366			.0366		.0343	
23	.0362			.0362		.0335	
24		.0366			.0366		.0335
Max	.0366	.037	.0366	.0366	.037	.0362	.0366
Min	.0362	.0335	.0362	.0362	.0335	.0335	.0335
Avg	.0365	.0357	.0366	.0365	.0355	.0347	.0359

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 201 / 11KV BODHAN NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	25-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058			.1494
2	.1886			
3	.2058			
4	.2401			
5	.2743			
6	.3086			
7	.4115			
8	.373			
9	.3429			
10	.3086			
18	.5228			
19	.4854			
20	.5601			
24	.2058	.2743	.1494	
Max	.5601	.2743	.1494	.1494
Min	.1886	.2743	.1494	.1494
Avg	.3310	.2743	.1494	.1494

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 204 / 11 KV MAHADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0335	.0335	.037	.037	.037	.037
2	.0335	.0335	.0335	.037	.037	.037	.037
3	.0335	.0335	.0335	.0185	.037	.037	.037
4	.0335	.0503	.0335	.037	.037	.037	.037
5	.0335	.0503	.0335	.037	.037	.037	.037
6	.0335	.0503	.0671	.037	.037	.037	.037
7	.0503	.0503	.0838	.037	.037	.0554	.0554
8	.0492	.0335	.0671	.0554	.0554	.0554	.037
9	.0655	.0328	.0739	.0819	.0503	.0739	.0335
10	.0655	.0328	.037	.0655	.0671	.0554	.0503
11		.0492	.0554	.0819	.0503	.037	.0335
12		.0655	.0739	.0492	.0503	.0554	.0503
13		.0492	.0924	.0655	.0503	.0554	.0671
14		.0655	.0924	.0655	.0335	.0739	.1006
15		.0655	.0924	.0819	.0492	.0655	.0671
16		.0739	.0554	.0819	.0492	.0492	.0671
17	.037	.0924	.0503	.0492	.0492	.0655	.0655
18	.0554	.0924	.0335	.0492	.0492	.0655	.0655
19	.037	.0739	.0503	.0655	.0492	.0671	.0492
20	.0554	.0554	.0335	.0655	.0655	.0503	.0492
21		.037	.0335	.0492	.0655	.0492	.0492
22			.037				.0366
23		.0339	.037			.037	.0366
24	.0335	.0503	.0335	.037	.037	.0335	.037
Max	.0655	.0924	.0924	.0819	.0671	.0739	.1006
Min	.0335	.0328	.0335	.0185	.0335	.0335	.0335
Avg	.0433	.0524	.0528	.0539	.0468	.0507	.0489

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 205 / 11 KV VETERINARY COLLEGE SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2402	.2957	.2957	.3326	.3142	.3142	.3142
2	.2402	.2772	.2957	.3142	.2957	.2957	.2957
3	.2218	.2772	.3142	.3142	.2957	.2957	.2957
4	.2402	.2957	.3142	.3511	.3142	.3142	.3142
5	.2957	.3142	.3326	.3881	.3142	.3326	.3511
6	.3326	.4066	.3658	.4251	.4066	.4066	.3881
7	.4251	1.0534	.4251	.462	.4805	.462	.4435
8	.4024	.499	.4435	.5175	.5175	.4805	.499
9	.3353	.3856	.4251	.5487	.9425	.5359	.4805
10	.4024	.3856	.4066	.4973	.924	.499	.462
11		.3688	.4435	.4191	1.035	.4066	.4251
12		.3688	.4066	.3353	.887	.3881	.4066
13		.3688	.4066	.3353	.8502	.4066	.4066
14		.3521	.3881	.3353	.3326	.4066	.7392
15		.3185	.3881	.3018	.3601	.3185	.7022
16		.3326	.3881	.3018	.3561	.3601	.3881
17	.4435	.3142	.5175	.3185	.3601	.3944	.3772
18	.4066	.3511	.462	.3772	.39	.4115	.3944
19	.5359	.499	.499		.463	.4801	.463
20	.499	.5175	.5175	.4458	.4527	.4458	.4287
21		.5175	.499	.4287	.4801	.463	.4287
22			.462			.4066	.439
23		.3881	.3881		.0343	.3511	.455
24	.2587	.3142	.3511	.3511	.3881	.3174	.3142
Max	.5359	1.0534	.5175	.5487	1.035	.5359	.7392
Min	.2218	.2772	.2957	.3018	.0343	.2957	.2957
Avg	.3520	.4001	.4057	.3857	.4867	.3955	.4255

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 206 / 11 KV SHIVAJI CHOWK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.4207	.4207	.462	.4251	.4251	.4435
2	.3109	.4024	.4024	.4435	.3881	.4251	.4251
3	.3292	.3841	.3841	.462	.3881	.4066	.4251
4	.3292	.4024	.439	.4805	.4066	.4251	.4066
5	.3475	.4207	.5121	.5175	.4251	.4435	.4435
6	.4207	.4252	.567	.5175	.499	.5175	.5175
7	.5487	.5121	.6036	.5544	.5729	.5914	.6099
8	.503	.5487	.6036	.6099	.6468	.5729	.6653
9	.503	.5533	.6283	.583	.6219	.6099	.6036
10	.5365	.5533	.6653	.5868	.567	.6653	.5853
11		.6036	.6653	.5365	.6219	.5914	.6219
12		.6203	.6653	.5365	.6401	.5729	.6036
13		.6036	.6468	.5197	.6767	.6838	.567
14		.5868	.6283	.503	.6219	.5544	.567
15		.5868	.6468	.503	.5658	.5144	.5853
16		.6468	.6283	.5365	.583	.5316	.567
17	.9055	.6653	.6767	.5365	.6344	.583	.5316
18	.8316	.7207	.7316	.6173	.6687	.6173	.6344
19	.924	.8501	.9328	.7202	.823	.7545	.7545
20	.924	.9055	.8962	.6706	.8215	.7373	.6859
21		.7577	.7316	.57	.7373	.6859	.6344
22			.6653			.6099	.6584
23		.5121	.5544			.5175	.6401
24	.3475	.439	.4572	.4805	.499	.439	.4435
Max	.924	.9055	.9328	.7202	.823	.7545	.7545
Min	.3109	.3841	.3841	.4435	.3881	.4066	.4066
Avg	.5394	.5705	.6147	.5431	.5834	.5615	.5675

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 154100 / 33/11 KV MAHADA

Feeder No / Name : 207 / 11KV EXPRESS RUDRANI SHEDDABLE RURAL
HEALTHCAR Feeder KV- 11 /
OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1417	.1417	.1595	.1109	.1109	.1109	.1109
2	.1417	.1417	.1417	.1109	.0739	.1294	.1294
3	.124	.1417	.1063	.1294	.0924	.1294	.1294
4	.1417	.1595	.124	.0924	.1109	.1109	.1109
5	.1417	.124	.124	.1294	.0739	.1478	.0739
6	.124	.124	.1417	.1294	.1294	.1478	.1478
7	.124	.0886	.1417	.1109	.0739	.1478	.1109
8	.1006	.1063	.1063	.0924	.0924	.1109	.1109
9	.0838	.0838	.0924	.0671	.0886	.1109	.124
10	.0671	.0838	.0739	.0857	.1063	.0739	.1417
11		.0838	.0739	.0838	.0886	.0739	.1063
12		.0838	.0924	.0838	.0709	.0739	.1063
13		.1006	.0739	.1006	.0886	.0739	.1417
14		.1006	.0924	.1006	.1772	.0924	.1063
15		.1006	.0924	.1341	.1543	.0671	.1063
16		.0924	.0924	.1006	.1886	.0857	.1063
17	.0924	.1109	.1097	.1006	.2058	.0857	.1029
18	.1109	.1109	.1417	.1372	.1715	.0857	.1372
19	.1294	.1294	.1595	.1715	.1715	.1029	.1029
20	.1109	.1294	.1417	.1372	.1174	.1029	.1029
21		.1109	.1772	.1029	.1543	.1029	.12
22			.1109			.1109	.0549
23		.1595	.0924			.1109	.0549
24	.1417	.1595	.1417	.1109	.0924	.1063	.1294
Max	.1417	.1595	.1772	.1715	.2058	.1478	.1478
Min	.0671	.0838	.0739	.0671	.0709	.0671	.0549
Avg	.1184	.1160	.1168	.1101	.1197	.1040	.1112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 201 / 11 KV Bus Stand

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-AUG-17
HR	Load (MW)
22	1.2803
23	1.1643
Max	1.2803
Min	1.1643
Avg	1.2223

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR URBAN S/DN.[742] BU 4742

Substation No/ Name :- 157003 / 132 KV UDGIR

Feeder No / Name : 402 / 33 KV NALGIR

SHEDDABLE URBAN

Feeder KV- 33 / INCOMING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3436	3.3436	3.858	3.6214	2.7435	3.6214	2.963
2	3.4465	3.2922	3.8066	3.5665	2.5789	3.6214	3.2373
3	3.6008	3.4465	3.6808	4.6091	2.6337	3.4568	3.4568
4	4.0124	3.6008	4.6273	5.1029	2.7435	3.8409	3.5117
5	4.4239	3.6523	4.9897	5.487	2.7984	4.1701	3.7311
6	4.9897	4.2181	5.6584	5.7613	3.4568	4.6091	3.4568
7	5.9671	4.7325	5.9156	5.2126	4.6639	5.9808	4.5542
8	5.3315	4.6296	6.0357	5.8711	5.6516	5.487	4.3896
9	5.4824	3.2693	4.6091	6.07	5.7613	4.7737	3.8386
10	3.0681	3.722	2.9081	5.2812	4.2067	4.2798	3.1024
11		3.722	4.0055	4.9291	3.4179	4.2798	3.8912
12		3.6214	3.786	5.0297	3.2602	4.1152	4.2067
13		2.9172	3.8409	4.8285	1.6827	4.225	4.0489
14		3.2693	3.9506	4.1747	1.6827	4.225	3.5757
15		3.4202	4.4445	3.6214	1.6975	3.7037	3.4705
16		3.7311	4.6639	3.4202	1.5432	3.7037	3.1024
17	3.2922	3.786	4.0489	2.8166	2.9835	3.3951	3.7551
18	4.0055	3.1276	3.6283	2.7161	2.9835	2.7778	3.7551
19	4.7737	4.0604	4.2593	4.1667	4.4753	3.9609	5.0926
20	4.4993	4.4445	4.7325	4.2753	4.4262	4.321	4.6811
21		4.4907	4.3644	3.7551	4.2181	4.1152	2.8807
22			3.8409				2.9081
23		2.8921	3.4568				3.0178
24	3.2407	3.2922	3.9438	3.7311	3.3471	3.6808	3.1824
Max	5.9671	4.7325	6.0357	6.07	5.7613	5.9808	5.0926
Min	3.0681	2.8921	2.9081	2.7161	1.5432	2.7778	2.8807
Avg	4.2318	3.6818	4.2940	4.4567	3.3162	4.1066	3.6587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 201 / 11 KV ATNOOR

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2515	.3353	.3353	.3353	.3353	.3521	.2683
2	.2515	.3688	.3353	.3353	.3353	.3521	.2683
3	.2591	.3856	.4694	.3353	.3353	.3688	.3018
4	.3353	.4191	.57	.4191	.4191	.4191	.3018
5	.4694		.7042	.503	.5197	.503	.3521
6	.7377	.7042	.7712	.7209	.6874	.6539	.3688
7	.8886	.7545	.8048	.7545	.7712	.788	.4694
8	.7545	.6706	.8048	.6874	.8551	.8048	.4359
9	.6539	.6874	.6371	.7042	.7209	.7545	
10	.3018	.2012	.3521	.503	.3688	.3353	.4359
11		.3185	.3018	.5533	.285	.4527	.3688
12		.3018	.3018	.57	.3353	.4359	.3018
13		.3688	.3521	.57		.4024	.2683
14		.4024	.4862	.57		.4024	.2347
15	.2515	.4024	.4862	.4862		.3856	.2683
16	.503	.2683	.4862	.4527		.3353	.2347
17	.285	.3353	.4862	.4191	.2347	.3018	.2683
18	.2515	.2347	.2347	.285	.218	.3688	.3018
19	.503	.4359	.4359	.4527	.4359	.6036	.6036
20	.503	.503	.503	.57	.7209	.57	.5365
21	.4694	.503	.57	.503	.5533	.503	.503
22	.4527	.4694	.4694	.4191	.4862	.4527	.3688
23	.3856	.4191	.4024	.3506	.4024	.4024	.3521
24	.2515	.3521	.3856	.3688	.3353	.3688	.2683
Max	.8886	.7545	.8048	.7545	.8551	.8048	.6036
Min	.2515	.2012	.2347	.285	.218	.3018	.2347
Avg	.4380	.4279	.4869	.4945	.4678	.4715	.3514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 202 / 11 KV AWALKONDA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527		.5868	.3688		.3353	.5365
2	.4359		.6371	.4024		.3353	.5365
3	.4359		.6706	.503		.3688	.57
4	.4527		.7042	.6036		.4862	.6371
5	.5365		.7712	.6706		.503	.7712
6	.6539		.8383	.7545		.6203	.8048
7	.8215		1.1065	.8886	.2683	.6874	.7712
8	.8551		1.1904	1.1233	.3521	.7042	.8383
9	.7712		1.1065	1.1904	.3521	.788	.7042
10	.4862	.2683	1.1065	.6203	.1174	.4862	.5365
11		.6371	.3856	.5197	.0335		.5197
12		.7042	.3856	.3185			.6706
13		.3353	.3018	.3185		.4191	.7042
14		.3521	.285	.3185		.3856	.7545
15		.3185	.285	.3856		.3856	.6874
16		.3185	.3018	.3688		.3688	.6539
17		.3353	.3018		.2683	.3353	.7377
18	.3688	.3688	.3018	.3018	.2515	.3856	.3856
19	.6371	.6203	.6371	.5365	.6874	.8383	.8048
20		.7042	.7042	.6706	.8718	.8048	.8048
21		.7712	.5868		.788	.7377	.7042
22		.6874	.5868	.2347	.6874	.6706	.5365
23		.6036	.6203	.2515	.5365	.6706	.4694
24	.3018		.503	.3018		.2515	.57
Max	.8551	.7712	1.1904	1.1904	.8718	.8383	.8383
Min	.3018	.2683	.285	.2347	.0335	.2515	.3856
Avg	.5546	.5018	.6210	.5296	.4345	.5258	.6546

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154025 / 33 KV NALGIR

Feeder No / Name : 203 / 11 KV Nalgir

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.218	.285	.285	.285	.2347	.2683	.1677
2	.218	.285	.3353	.285	.2347	.2683	.1677
3	.218	.285	.3353	.285	.2347	.285	.1677
4	.218	.285	.3688	.285	.285	.285	.1677
5	.285	.3353	.4024	.3353	.3353	.3018	.2012
6	.4024	.3688	.4191	.3688	.3856	.4024	.2012
7	.4527	.4694	.4694	.4527	.4191	.4527	.3353
8	.4191	.4191	.4024	.4359	.4694	.4694	.3353
9	.3856	.3688	.3353	.4359	.3856	.4024	.3018
10	.2012	.1844	.2683	.2683			
11		.2347	.2012	.3018		.3353	
12		.2012		.3353		.3185	
13		.2347	.2347	.3185		.3185	
14		.2683	.3018	.3185		.3185	.2683
15		.2683	.3185	.2515		.285	.2347
16		.2683	.3353	.3018		.285	.2012
17		.2347	.3185	.285	.1174	.3018	.218
18	.2515	.2012		.2347	.2683	.2683	.2683
19	.3688	.3521	.3521	.3353	.3688	.4024	.4024
20	.3688	.3856	.3506	.4024	.4191	.4024	.3688
21	.3688	.4024	.3856	.3688	.3856	.3688	.3521
22	.3688	.3521	.3521	.3353	.3856	.3018	.2683
23	.3018	.3353	.3185	.285	.3018	.2683	.2683
24	.218	.285	.3018	.3018	.2347	.285	.2012
Max	.4527	.4694	.4694	.4527	.4694	.4694	.4024
Min	.2012	.1844	.2012	.2347	.1174	.2683	.1677
Avg	.3097	.3046	.336	.3255	.3215	.3302	.2549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 201 / 11 KV KARADKHEL

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2601	.3391	.3429	.3467	.2572	.1715
2	.2572	.2601	.3391	.3429	.3467	.2572	.1715
3	.2572	.2601	.3391	.3429	.3467	.2572	.1715
4	.3429	.3467	.4239	.3429	.4334	.2572	.1715
5	.4287	.3467	.4239	.3429	.4334	.3429	.1715
6	.5144	.4334	.5087	.5144	.5201	.5144	.2572
7	.4287	.5201	.5087	.5144	.6068	.5144	.3429
8	.3429		.4239	.4287	.5935	.3429	.3391
9	.4287		.4287	.4334	.4287	.5201	.3391
10	.2572	.3429	.3429	.3467	.2629	.2601	.3391
11		.4287	.4287	.4334	.2572	.2601	.2543
12		.4287	.4287	.5201	.3391	.3467	.2543
13		.4287	.5144	.5201	.3429	.2601	.1696
14	.2572	.5144	.5144	.6068	.3429	.2601	.1696
15	.2572	.4287	.5144	.5201	.3429	.2601	.1696
16	.3429	.4287	.5144	.5201	.3429		.1696
17	.1753	.4287	.5144	.5201	.2572	.3429	.1715
18	.2572	.2572	.2601	.2601	.2572	.3429	.2572
19	.3429	.3429	.3429	.3467	.3429	.4287	.3429
20	.5144	.5144	.4334	.4334	.4287	.4287	.4287
21	.4334	.4287	.4287	.5201	.3429	.4287	.4287
22	.4334		.3429	.4334	.3429	.3429	.3429
23	.3467		.3429	.3467	.2572	.3429	.2572
24	.2572	.3467	.3391	.3429	.3467	.2572	.1715
Max	.5144	.5201	.5144	.6068	.6068	.5201	.4287
Min	.1753	.2572	.2601	.2601	.2572	.2572	.1696
Avg	.3397	.3873	.4166	.4282	.3693	.3402	.2526

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 202 / 11 KV HER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2601	.2629	.3429	.3467	.2629	.2601	.1734
2	.2601	.2629	.3429	.3467	.2601	.2601	.1734
3	.3467	.3506	.3429	.3467	.2629	.2601	.1734
4	.4334	.3506	.4287	.3467	.3506	.3467	.1734
5	.5201	.4382	.4287	.4334	.3506	.4334	.1734
6	.6068	.4382	.5144	.6068	.4382	.4334	.1734
7	.6068	.5258	.6001	.6935	.5258	.5201	.2601
8	.6068	.5258		.6068	.5144	.5201	.2572
9	.4334	.4334		.5258		.4382	.2572
10	.2601	.1734		.3506	.1734	.3506	.5144
11		.1734	.2601	.5258	.3506	.3506	.3429
12		.2601	.2601	.6135	.3429	.3506	.2572
13	.1734	.2601	.2601	.6135	.3506	.3506	.2572
14	.2601	.2601	.2601	.6135	.2629	.3506	.2572
15	.2601	.2601	.2601	.6135	.1753	.3506	.2572
16	.2629	.2601	.2601	.6135	.1753		.2572
17	.2601	.2601	.3467	.5258	.1734	.1734	.2601
18	.2601	.2601	.2601	.2629	.2601	.3467	.3467
19	.5144	.3506	.4334	.3506	.2601	.3467	.5201
20	.5201	.4334	.5201	.4382	.3467	.4334	.4334
21	.4382	.4334	.4334	.5258	.4334	.4334	.4334
22	.3506		.4334	.4382	.3467	.3467	.3467
23	.3506		.3467	.3506	.2601	.3467	.3467
24		.3506	.3429	.3467	.2601	.2601	.1734
Max	.6068	.5258	.6001	.6935	.5258	.5201	.5201
Min	.1734	.1734	.2601	.2629	.1734	.1734	.1734
Avg	.3802	.3329	.3656	.4765	.3103	.3593	.2841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154031 / 33 / 11 KV KARADKHEL

Feeder No / Name : 203 / 11 KV DIGRESS

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.2601	.2601	.3544	.3467	.1772	.3544
2	.2658	.2601	.2601	.3544	.3467	.1829	.3544
3	.2658	.3467	.3467	.3544	.3467	.1772	.3544
4	.2658	.3429	.3467	.3544	.4334	.1772	.3544
5	.2658	.2572	.3467	.443	.4334	.1772	.443
6	.3544	.3467	.4334	.5316	.5201	.3544	.5316
7	.3544	.6001	.6068	.7973	.5201	.5316	.7087
8	.443	.6001	.6935	.7087	.6068	.3544	.6935
9	.443	.3544	.443	.6935		.4334	.6068
10	.3544	.3544	.3544	.1734	.1753		.4334
11		.1772	.2658	.1715			.4334
12		.1772	.1772	.1715			.4334
13	.1772	.1772	.1772	.1715		.1734	.3467
14	.1772	.1772	.1772	.1715		.1734	.3467
15	.1772	.1772	.1772	.1734	.1734	.1734	.3467
16	.2601	.1772	.1772	.1734	.1734		.3467
17		.0876	.1772	.1734	.1772	.1772	.3544
18	.1753	.1753	.1772	.1734	.1772	.1772	.3544
19	.4382	.3467	.3544	.2572	.3544	.3544	.443
20	.5258	.4334	.5316	.3467	.3544	.443	.443
21	.4334	.4382	.3544	.3467	.443	.443	.3544
22	.4334		.3544	.3429	.3544	.3544	.3544
23	.3467		.3544	.2601	.2658	.3544	.2658
24	.1772	.2572	.2601	.2658	.3467	.2658	.3544
Max	.5258	.6001	.6935	.7973	.6068	.5316	.7087
Min	.1753	.0876	.1772	.1715	.1734	.1734	.2658
Avg	.3101	.2966	.3253	.3318	.3447	.2828	.4172

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 204 / 11 KV SHEKAPUR GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.5258		.381	.5079
9	.3944		.3201	
10	.2743		.2134	
11			.1829	
12			.0914	
14		.0743		
16			.1067	
17			.1219	
24	.1543		.1677	
Max	.5258	.0743	.381	.5079
Min	.1543	.0743	.0914	.5079
Avg	.3372	.0743	.1981	.5079

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 205 / 11 KV DEVARJAN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.543		.3506	.3506
9	.3506		.3048	
10	.3155		.1829	
11			.1524	
12			.1524	
14		.1052		
16			.1524	
24	.1448		.1219	
Max	.543	.1052	.3506	.3506
Min	.1448	.1052	.1219	.3506
Avg	.3385	.1052	.2025	.3506

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 207 / 11 KV ARASNAL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	26-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.1692
10	.3506		.1829	
11			.2439	
12			.3658	
14		.2715		
17			.4115	
Max	.3506	.2715	.4115	.1692
Min	.3506	.2715	.1829	.1692
Avg	.3506	.2715	.3010	.1692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431] BU 5142

Substation No/ Name :- 154039 / 33 / 11 KV DEVARJAN

Feeder No / Name : 208 / 11 KV Water Works Feeder NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-AUG-17
HR	Load (MW)
8	.0017
9	.0017
10	.0017
24	.0017
Max	.0017
Min	.0017
Avg	.0017

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 201 / 11 KV LOHARA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3086	.5201	.4572	.3048	.3048	.3086
2	.2743	.2743	.5487	.5487	.3048	.3048	.3086
3	.2743	.2743	.5487	.5487	.3048	.3048	.3086
4	.3353	.3429	.6173	.5792	.3658	.3658	.3429
5	.4572	.4801	.6516	.6706	.4268	.3658	.4115
6	.5182	.6859	.6859	.7316	.4877	.4877	.4801
7	.5792	.7888	.7545	.7926	.5792	.6173	.6001
8	.5487	.7888	.823	.8535	.6401	.6173	.5144
9	.6097	.7202	.8573	.8535	.5487	.5487	.4801
10	.3048	.2058	.2058	.3048	.2134	.4115	.4801
11			.2134	.3048	.2134	.3086	.5144
12			.2134	.2743	.2439	.3086	.5144
13		.2058	.2439		.2439		.3772
14	.3086	.2401	.2439	.2439	.2439	.3086	.3429
15	.3086	.2401	.2439	.2134	.3048	.2743	.3086
16	.3086	.2401	.3048	.2439	.2439	.2743	.3086
17	.2743		.2743	.2439	.2439	.2743	.3429
18	.3086		.2286	.3048	.2286	.4115	.4458
19	.4458		.2439		.2743	.4801	.4458
20	.4458		.3658	.3658	.3658	.4801	.4115
21	.4115		.3963	.3658	.3963	.5144	.4115
22	.3772		.3963	.3658	.3963	.4458	.3772
23	.3429	.3467	.3353	.3353	.3353	.3772	.3429
24	.3048	.3086	.4801	.4877	.3048	.3048	.3429
Max	.6097	.7888	.8573	.8535	.6401	.6173	.6001
Min	.2743	.2058	.2058	.2134	.2134	.2743	.3086
Avg	.3830	.4032	.4332	.4586	.3423	.3953	.4051

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 202 / 11 KV BHAKASKHEDA FEEDER SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.2058	.208	.1829	.2134	.2134	.2401
2	.1829	.2058	.2058	.1829	.2134	.2134	.2401
3	.1829	.2058	.2401	.2134	.2134	.2134	.2401
4	.2134	.2743	.2743	.2439	.2439	.2439	.2743
5	.2439	.3429	.3086	.2743	.2439	.2439	.2743
6	.3048	.3772	.4115	.3658	.3658	.3658	.2743
7	.4268	.3429	.5144	.4572	.4572	.3658	.2743
8	.3658	.3086	.4458	.4268	.4877	.3086	.3086
9	.3048	.2743	.3772	.3353	.3658	.2743	.2572
10	.4115	.5487	.5144	.4268	.4572	.2401	.1715
11		.6859	.5792	.3658	.5182	.2058	.1715
12		.6173	.6706	.6097	.6097	.2058	.1715
13		.5487	.7926	.6706	.6706	.1715	.1715
14	.3429	.583	.7985	.7316	.7926	.2058	.1715
15	.2743	.583	.6706	.8535	.7011	.1715	.1715
16	.2743	.6173	.6097	.7926	.7316	.1715	.1715
17	.2401		.7316	.7316	.6706	.2058	.1715
18	.1715		.1829	.1524	.1829	.2401	.2743
19	.3086		.2134		.2439	.3086	.2743
20	.2743		.2743	.1829	.2743	.3086	.2401
21	.2401		.3048	.2286	.3048	.3086	.2401
22	.2401		.3048	.3353	.3048	.2743	.2058
23	.2058	.2572	.2439	.3048	.2439	.2401	.1715
24	.1829	.2058	.2401	.2134	.2439	.2439	.2401
Max	.4268	.6859	.7985	.8535	.7926	.3658	.3086
Min	.1715	.2058	.1829	.1524	.1829	.1715	.1715
Avg	.2655	.3991	.4215	.4036	.4064	.2477	.2251

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 203 / 11 KV KUMTHA FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3086	.2427	.2439	.2743	.2743	.3086
2	.2743	.3086	.2401	.2439	.2743	.2743	.3086
3	.2743	.3086	.2743	.2439	.2743	.2743	.3086
4	.3048	.4458	.3086	.2743	.3048	.3048	.3429
5	.5182	.583	.3429	.3048	.3658	.3353	.4458
6	.6097	.7545	.4801	.4268	.4268	.4268	.4458
7	.7621	.8916	.6859	.5487	.5487	.4268	.3772
8	.6706	.8573	.4458	.4877	.6706	.8573	.3772
9	.6706	.7202	.3429	.3963	.4877	.8573	.4115
10	.4801	.6859	.4801	.4877	.4268	.3086	.3086
11		.7545		.4268	.4877	.2743	.3086
12		.5144	.7316	.5487	.5792	.2743	.3086
13			.7316	.6097	.6706	.2743	.2743
14		.5487	.8535	.7926	.7316	.3086	.2743
15	.3772	.5487	.7926	.9145	.7316	.3086	.3086
16	.3772	.5487	.7011	.8535	.7011	.2743	.3086
17				.7316		.2743	.3086
18			.2134	.3048	.2134	.3772	.4115
19	.4458		.2134		.2439	.4801	.4115
20	.4115		.3658	.4268	.3048	.5144	.3429
21	.3772		.3658	.4877	.3658	.5144	.3086
22	.3772		.3963	.4268	.3963	.4115	.2743
23	.3086	.2743	.3658	.3048	.3658	.3429	.2401
24	.2743	.3086	.2572	.3048	.2743	.2743	.3086
Max	.7621	.8916	.8535	.9145	.7316	.8573	.4458
Min	.2743	.2743	.2134	.2439	.2134	.2743	.2401
Avg	.4327	.5507	.4469	.4692	.4400	.3851	.3343

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154085 / 33 KV LOHARA S/S

Feeder No / Name : 204 / 11 KV Express Feeder

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.12	.1715	.1524	.1219	.1219	.12
2	.1219	.12	.1372	.1219	.1219	.1219	.12
3	.1219	.12	.1372	.1219	.1219	.1219	.12
4	.1219	.12	.1372	.1219	.1219	.1219	.12
5	.1372	.12	.1372	.1219	.1219	.1219	.12
6	.1372	.1372	.1372	.1219	.1219	.1219	.1372
7	.1524	.1715	.1372	.1524	.1524	.1524	.1715
8	.1524	.2058	.2058	.1524	.1524	.2058	.1715
9	.1524	.2743	.2743	.1524	.1524	.2743	.2058
10	.3086	.2743	.2743	.2134	.1524	.2743	.2743
11		.3086	.2896	.2439	.2591	.3086	.2743
12		.3086	.2743	.2439	.2591	.3086	.2915
13		.3086	.2439	.2743	.2591		.2915
14	.2743	.3086	.2439	.2743	.2743	.2743	.2743
15	.2743	.3429	.2743	.2743	.2591	.2743	.2743
16	.2743	.3429	.2743	.2591	.2591	.2743	.2743
17	.2743		.2439	.2743	.2439	.2743	.2572
18	.2401		.2439	.2439	.2439	.2401	.2401
19	.2572		.2439		.2439	.2743	.2401
20	.2401		.2134	.2134	.2134	.2743	.2401
21	.2058		.2134	.2134	.2134	.2743	.2401
22	.2058		.2134	.1829	.2134	.2401	.2058
23	.1715	.2058	.1829	.1524	.1829	.2058	.1715
24	.1524	.1715	.1715	.1524	.1524	.1524	.1715
Max	.3086	.3429	.2896	.2743	.2743	.3086	.2915
Min	.1219	.12	.1372	.1219	.1219	.1219	.12
Avg	.1951	.2200	.2115	.1928	.1924	.2180	.2086

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 202 / 11 KV S.OMARGA

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.3429	.5144	.4908	.2218		.2957
2	.4801	.4287	.5144	.4801	.2772		.2957
3	.5144	.4287	.5144	.5487	.2772		.2957
4	.5144	.5144	.5087	.6173	.3326		.3326
5	.6173	.5935	.5426	.6859	.3696		.4344
6	.6783	.663	.6104		.3696		.6516
7	.7461	.8288	.4641		.3696		.5609
8	.7956	.9116	.9282		.4525	.583	.4908
9	.663	.8916	.7293	1.0608	.6173	.8916	.4207
10	.2804	.2804	.3155	.3506	.1867	.3772	.4801
11		.1753	.2103	.2829	.3772	.2454	.6535
12		.1402	.1402	.1509	.2641	.1402	.6535
13		.1052	.1402	.0943	.1886	.1402	.6602
14	.0876	.1052	.1402	.0943	.1886	.1402	.5975
15	.1402	.1402	.1402	.132	.1886	.1402	.6036
16	.1753	.1402	.1402	.1509	.1886	.1402	.6535
17	.1753	.2172	.1402	.0943	.2263	.1753	.6722
18		.2218	.1753	.0943	.2263	.181	.2829
19	.3696	.3696	.2957	.1886	.4527	.2957	.2829
20	.3696	.4805	.4435	.3395	.4805	.4435	.3395
21	.3326	.5175	.3696	.3018	.2587	.3696	.2263
22	.3326	.4066	.3326	.2829	.2218	.3696	.2829
23	.3326	.3696	.2957	.2829	.2218	.3696	.2829
24	.4908	.3429	.5144	.4908	.2218		.3326
Max	.7956	.9116	.9282	1.0608	.6173	.8916	.6722
Min	.0876	.1052	.1402	.0943	.1867	.1402	.2263
Avg	.4288	.4007	.3800	.3436	.2992	.3127	.4493

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154087 / 33/11 KV S. OMARGA

Feeder No / Name : 203 / 11 KV KARWANDI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.2218	.3326	.2218	.1402		.2103
2	.1848	.2772	.3326	.2218	.1402		.2103
3	.2218	.2772	.3326	.2957	.1753		.2454
4	.2218	.3326	.3696	.2957	.1753		.2454
5	.2218	.3696	.3982	.3696	.4287		.2743
6	.2534	.4525	.543		.462		.3086
7	.2103	.2103	.3155		.4458		.3086
8		.1753	.3155		.2572	.4908	.2743
9		.3155	.2454	.3326	.2829	.2804	.3086
10		.2058	.3429	.3429	.2241	.1715	.2804
11		.3772	.3772	.3772	.2195	.2058	.1886
12		.3429	.3429	.3772	.2195	.2058	.1886
13		.3086	.3086	.415	.2241	.2058	.1509
14	.2058	.2058	.3052	.415	.2241	.1715	.1132
15	.2058	.2058	.2713	.415	.2241	.1715	.1132
16	.2572	.2743	.2713	.3856	.2263	.1715	.1132
17	.2572	.2743	.3315	.3429	.1886	.1715	.1509
18		.2454	.1402	.1829	.0943	.1086	.2641
19	.2896	.362	.2587	.2263	.3696	.2587	.2829
20	.2957	.4435	.4066	.2263	.3696	.4066	.3395
21	.3326	.4435	.3696	.1886	.3696	.3696	.3395
22	.2957	.3696	.3326	.1886	.3326	.3326	.2829
23	.2587	.3326	.2957	.1509	.2957	.2957	.2263
24	.1848	.2218	.3326	.2218	.1402		.2103
Max	.3326	.4525	.543	.415	.462	.4908	.3395
Min	.1848	.1753	.1402	.1509	.0943	.1086	.1132
Avg	.2401	.3019	.3280	.2949	.2596	.2511	.2346

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 201 / 11 KV GUTTI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.2096	.3086	.3429	.3429	.1402	.381
2	.1886	.2286	.2915	.3601	.3429	.156	.381
3	.1886	.1905	.3086	.3601	.381	.1543	.4191
4	.156	.2477	.3258	.3772	.4001	.1753	.4572
5	.1734	.2667	.3429	.3944	.4382	.1734	.5716
6	.2204	.3048	.3601	.4252	.4572	.2401	.724
7	.2543	.3429	.4458	.5316	.5144	.3353	.8383
8	.285	.362	.3772	.5316	.4572	.3353	.7621
9	.2486			.567	.4382	.4607	.724
10	.4763	.4954	.5335	.6287	.5335		.3292
11		.3239	.362	.2477	.4954	.381	.3772
12			.2477	.3048	.3048	.2667	.2629
13		.1905	.2096	.2667		.2286	.2743
14		.1524	.2096	.3239		.2096	.2713
15		.1715	.1905	.2477		.2286	.2572
16	.362	.1905	.2096	.2667		.2286	.2572
17	.3239	.2477	.2667	.3048	.2858	.2286	.2572
18	.3048	.2858	.3048	.3239		.362	.381
19	.4572	.5144	.5335	.4001	.6097	.724	.7049
20	.5335	.724	.6668	.4954	.7049	.6287	.6478
21	.4954	.5906	.6097	.5525	.5716	.5716	.5525
22	.4382	.5144	.5335	.5906	.5716	.5335	.4954
23	.4001	.4572	.4572	.4001	.4763	.4954	.4763
24	.1772	.362	.3258	.3772	.3258	.1402	.4191
Max	.5335	.724	.6668	.6287	.7049	.724	.8383
Min	.156	.1524	.1905	.2477	.2858	.1402	.2572
Avg	.3084	.3351	.3661	.4009	.4553	.3216	.4676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 202 / 11 kv CHINCHOLI FEEDER

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6097	.5716	.6097	.5525	.6097	.2401
2	.6097		.5716	.6287	.5906	.6097	.2401
3	.5716		.6287	.6287	.6859	.6287	.2572
4	.6287	.7049	.6668	.6859	.7049	.6478	.2743
5	.724	.743	.7811	.743	.8192	.6859	.2915
6	.8383	.8002	.9145	.8383	.8764	.9145	.3258
7	1.0479	.8192	.9145	.9145	.9335	1.0479	.3601
8	.8573	.8383	.8573	.8764	.8764	.8383	.4458
9	.6859				.8383	.6097	.3772
10	.2601	.2915	.2743	.3511	.3258	.2572	
11		.2915	.2743	.3429	.2601	.2743	.5335
12		.2572	.2915	.3239	.2229	.2743	.4954
13		.2229	.3109	.3048		.2401	.4382
14		.1886	.3077	.3048		.2401	.4001
15		.1715	.2561	.3239		.2401	.381
16		.1715	.2743	.3429		.2401	.4191
17	.3429		.2926	.3086	.2515	.2401	.4572
18	.5144	.4191	.5525	.4382	.6859	.5716	.6668
19	.5906	.6668	.6097	.724	.8573	.8573	.8764
20	.724	.9145	.743	.9335	.8764	.743	.724
21	.6859	.8192	.7049	.9145	.8383	.724	
22	.6478	.7049	.724	.743	.8002	.6097	.724
23	.6097	.6668	.6859	.6478	.6859	.6287	.6859
24	.6097	.6287	.6097	.6668	.6478	.6668	.2572
Max	1.0479	.9145	.9145	.9335	.9335	1.0479	.8764
Min	.2601	.1715	.2561	.3048	.2229	.2401	.2401
Avg	.6421	.5465	.5573	.5911	.6665	.5583	.4487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 22-AUG-17 and 28-AUG-17

LATUR ZONE, LATUR[068]

LATUR CIRCLE[680]

UDGIR DIVISION[685]

UDGIR(R) S/DN[431]

BU 5142

Substation No/ Name :- 154103 / 33 KV S/S GUTTI

Feeder No / Name : 203 / 11 KV SULLALI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	22-AUG-17	23-AUG-17	24-AUG-17	25-AUG-17	26-AUG-17	27-AUG-17	28-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2286	.2286	.1905	.2286	.1715
2	.2096	.2667	.2286	.2286	.2096	.2477	.1886
3	.1905	.3048	.2286	.2477	.2286	.2477	.1715
4	.2477	.3429	.2858	.2858	.2477	.2667	.2058
5	.2477		.3239	.3429	.3048	.2667	.2229
6	.2858	.3239	.362	.4191	.362	.362	.2572
7	.381	.362	.3048	.4954	.3239	.4191	.2915
8	.3048			.4382	.362	.3429	.2572
9	.2286			.3429	.3429	.2667	.1949
10		.1543	.1029	.2561	.2915	.1029	.2286
11		.1029	.0514	.3048	.1357	.0857	.1905
12		.1029	.1448	.3048	.1357	.1543	.1905
13		.0857	.1334	.2915		.0857	.1715
14		.0857	.1334	.3239		.12	.1715
15		.0857	.2195	.2667		.1543	.1715
16		.1029	.2427	.2858		.1543	.1905
17	.1524	.0686	.2402	.3048	.1311	.1372	.1905
18	.2286	.1143	.2096	.1334	.2096	.1905	.2858
19	.2477	.1524	.2858	.3429	.3429	.2286	.2286
20	.2667	.4001	.362	.4382	.3429	.2477	.2477
21	.2858	.3429	.3429	.4191	.3239	.2667	.2477
22	.2477	.2858	.2858	.3239	.3048	.2286	.2477
23	.2286	.2477	.2477	.2667	.2667	.2858	.2477
24	.2286	.2096	.2096	.2286	.2286	.2667	.1715
Max	.381	.4001	.362	.4954	.362	.4191	.2915
Min	.1524	.0686	.0514	.1334	.1311	.0857	.1715
Avg	.2477	.2090	.2352	.3134	.2643	.2232	.2143