

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 201 / BHOKAR TOWN I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3658		.4287	.3658
2				.3658		.4287	.3658
3				.3658		.4287	.3658
4	.4239			.3658	.4239	.4287	.3658
5	.4239			.4572	.4239	.4287	.3658
6	.4239			.4572	.4239	.4287	.5487
7	.543			.5487	.543	.5144	.5487
8	.5935			.6401	.5258	.5144	.6401
9	.5258			.5487		.5144	.6401
10	.5144		.5201				
11	.4287		.4334		.5487		
12	.4287			.4382	.4572		
13	.4287		.3544	.4334		.4572	
14	.4287		.3467	.4334		.3658	
15	.4287		.3467	.4334	.4572	.3658	.3391
16	.4287		.3506	.4334	.4287	.3658	.3429
17	.5144			.4334	.4287	.4572	.4287
18	.5144		.3658	.4334	.5144	.4572	.4382
19	.5144	.5144	.5487	.4334	.5144		.4287
20	.6001	.5144	.4572	.4334	.5144	.4572	.4382
21	.5144	.5144	.4572	1.4022	.5144	.4572	.4287
22	.5144	.5144	.4572		.6516	.4572	
23	.5144	.5144	.4572		.5144	.4572	
24	.4239	.4287	.5144	.4572	.4287	.4287	.3658
Max	.6001	.5144	.5487	1.4022	.6516	.5144	.6401
Min	.4239	.4287	.3467	.3658	.4239	.3658	.3391
Avg	.4824	.5001	.4315	.4940	.4890	.4421	.4363

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 202 / BHOKAR TOWN II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.0974		1.0288	1.0974
2				1.0974		1.0288	1.0974
3				1.0974		1.0288	1.0974
4	1.2003			1.0974	1.2269	1.0288	1.0974
5	1.2003			1.0974	1.2269	1.0288	1.0974
6	1.2003			1.2803	1.2269	1.0288	1.3717
7	1.3146			1.4632	1.3146	1.2003	1.4632
8	1.2269			1.4632	1.4022	1.3717	1.4632
9	1.1145			1.3717		1.3717	1.4632
10	1.1145		1.2136				
11	1.0288		1.1393		1.2803		
12				1.0402	1.0974		
13	1.0288		1.0517	1.0402		1.0974	
14	1.0288		1.0517	1.0288		1.0974	
15	1.0288		1.0631	1.1269	1.0974	1.0974	1.0288
16	1.1145		1.1517	1.2269		1.0974	1.0288
17	1.1145			1.2269	1.0288	1.0974	1.0517
18	1.2003		1.2803	1.2269	1.2003	1.1888	1.1393
19	1.286	1.2003	1.2803	1.2269	1.286		1.3146
20	1.3717		1.4632	1.4022	1.286	1.3717	1.4022
21	1.3717		1.3717	1.4022	1.286	1.2803	1.4022
22	1.286		1.1888		1.286	1.1888	
23	1.2003		1.0974		1.2003	1.0974	
24	1.2003	1.2003		1.0974	1.2269	1.2003	1.0974
Max	1.3717	1.2003	1.4632	1.4632	1.4022	1.3717	1.4632
Min	1.0288	1.2003	1.0517	1.0288	1.0288	1.0288	1.0288
Avg	1.1816	1.2003	1.1961	1.2055	1.2296	1.1465	1.2184

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 203 / BATALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2743		.3048	.3658
2				.2743		.3048	.3658
3				.2743		.3048	.3658
4	.5801			.3772	.5201	.381	.4572
5	.5801			.3658	.5144	.4287	.5487
6	.5801			.3658	.5144	.5144	.7316
7	.4973			.4572	.5801	.6001	.9145
8	.3315			.5121	.7545	.6859	.9145
9	.3467			.4572		.6097	1.0059
10	.3429		.5201				
11	.381		.2543		.2743		
12				.2486	.2743		
13	.381		.2486	.2486		.2743	
14	.4572		.2486	.2486		.2743	
15	.5144		.2486	.2486	.2743	.2743	.2486
16	.4801		.2629	.2601		.2743	.2486
17	.4287			.2486	.2286	.3658	.2486
18	.4287		.3658	.3315	.3429	.3658	.3315
19	.6001	.5144	.3658	.4973	.4287		.4973
20	.6859		.5487	.5801	.5335	.5487	.4973
21	.6001		.5487	.5801	.5335	.5487	.5801
22	.6001		.5487		.4572	.5487	
23	.6001		.5487		.4572	.5487	
24	.5801	.6001		.5487	.4973	.4572	.5487
Max	.6859	.6001	.5487	.5801	.7545	.6859	1.0059
Min	.3315	.5144	.2486	.2486	.2286	.2743	.2486
Avg	.4998	.5573	.3925	.3700	.4491	.4308	.5218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 204 / NARWAT

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7316		.6859	.7316
2				.7316		.6097	.7316
3				.7316		.6859	.7316
4	.4239			.7316	.6859	.6859	.7316
5	.5144			.7316	.6783	.6097	.7316
6	.5144			.823	.6783	.5335	.7316
7	.6135			.7316	.503	.4572	.7316
8	.7011			.5487	.3391	.4572	.6401
9	.6935			.4572		.4572	.5487
10	.6097		.3353				.5087
11	.2286		.5201		.6401		.6783
12	.2286			.4334	.823		.8764
13	.2286		.3467	.3467		.7316	
14	.2286		.4382	.3467		.7316	
15	.2286		.5316	.3467	.823	.5487	.7011
16	.3429		.1772	.3467		.6401	.7888
17	.3429			.4334	.6097	.7316	.7716
18	.4287		.6401	.5258	.5335	.823	.763
19	.6859	.5335	.5487	.5087	.5335		.5144
20	.7716	.6097	.7316		.6859	.823	.6783
21	.8573	.6859	.823		.6859	.823	.763
22	.7716		.823		.6859	.7316	
23	.7716		.7316		.7716	.7316	
24	.6706	.7716		.7316	.6706	.6859	.7316
Max	.8573	.7716	.823	.823	.823	.823	.8764
Min	.2286	.5335	.1772	.3467	.3391	.4572	.5087
Avg	.5170	.6502	.5539	.5688	.6467	.6592	.7043

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 205 / MANJIT COTTON EXP. FEEDER

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0914		.1715	.0914
2				.0914		.0857	.0914
3				.0914		.0857	.0914
4	.0848			.0914	.0848	.0857	.0914
5	.0857			.0914	.0848	.0857	.0914
6	.0857			.0914	.0848	.0857	.0914
7	.0876			.0914	.0848	.0857	.0914
8	.3429			.0914	.1696	.1715	.0914
9	.3429			.1257		.1715	.0914
10	.3429						.0857
11	.1715				.1829		.0857
12	.4287				.1829		.0848
13	.4287		.1753			.1829	
14	.4287		.0876	.1696		.1829	
15	.4287		.0848		.5487	.1829	.0867
16	.4287		.3506			.0914	.0876
17	.4287				.5144	.0914	.0867
18	.4287		.0914	.1715	.3429	.0914	.0857
19	.4287	.0857	.0914	.0876	.1715		.0838
20	.4287	.0857	.0914		.1715	.0914	.0848
21	.4287	.0857	.0914		.1715	.0914	.0848
22	.4287		.0914		.1715	.0914	
23	.4287		.0914		.1715	.0914	
24	.0848	.4287		.0914	.0876	.1715	.0914
Max	.4287	.4287	.3506	.1715	.5487	.1829	.0914
Min	.0848	.0857	.0848	.0876	.0848	.0857	.0838
Avg	.3225	.1715	.1247	.1059	.2016	.1194	.0885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174011 / BHOKAR

Feeder No / Name : 206 / EXP. FEEDER W/S BKR(SUDHA) Only one consumer of WW with HT-IV  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0914		.0857	.0914
2				.0914		.0857	.0914
3				.0914		.0857	.0914
4	.0848			.0914	.0848	.0857	.0914
5	.0848			.1829	.1696	.0857	.1829
6	.0848			.1829	.1715	.1715	.1829
7	.1753			.1829	.1753	.1524	.1829
8	.1715			.1829	.181	.1715	.1829
9	.1734			.1829		.1715	.1829
10	.1715		.1753				.1715
11	.1715				.1829		.1715
12	.1715			.1734	.1829		.1715
13	.1715		.0876	.1734		.1829	
14	.1715		.0876	.0857		.1829	
15	.0857		.0876	.1734	.0914	.0914	.1715
16	.0857		.0876	.1715		.0914	.1715
17	.0857			.0857	.0857	.0914	.0848
18	.0857		.0914	.0838	.0857	.0914	.0838
19	.0857	.0857	.0914	.0857	.0857		.0838
20	.0857	.0857	.0914		.0857	.0914	.0876
21	.0857	.0857	.0914		.0857	.0914	.0848
22	.0857		.0914		.0857	.0914	
23	.0857		.0914		.0857	.0914	
24	.0838	.0857		.0914	.0829	.0857	.0914
Max	.1753	.0857	.1753	.1829	.1829	.1829	.1829
Min	.0838	.0857	.0876	.0838	.0829	.0857	.0838
Avg	.1184	.0857	.0976	.1336	.1201	.1139	.1327

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 201 / MATUL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.4656	.3582		.3772	.0335
2	.3588		.5014	.3544		.3429	.0366
3	.3521		.5014	.3898		.3772	.0396
4	.2956		.5316	.4656		.4458	.0396
5	.2637		.567	.5316			.0488
6	.2262		.6024	.6024		.3944	.064
7	.2281		.7164	.815		.4973	.0854
8	.2279	.4801	.7087	.7522	.0701	.5316	.0914
9	.2106	.4801	.6661	.061	.0701		.0671
10	.1562	.4115	.5275	.0457	.061	.4801	.061
11	.2124	.3772		.0152	.1631	.2229	.0229
12	.0244	.3772	.2103	.0213	.1469	.4115	.0244
13	.0335			.0152	.1306	.3086	.0244
14	.0335	.4115		.0152	.1143		.0244
15	.0366	.4458		.0152	.2449	.2743	.0244
16	.0366	.4801		.0183	.2936	.3086	.0244
17	.0427	.5144	.2865	.0229	.3262	.3429	.0244
18	.0335	.5144	.2865	.0244	.3588	.4115	.0305
19	.0396	.5144	.5014				.0366
20	.0427	.4801	.4607		.3914	.4801	.0396
21	.0427	.583	.4252		.2286	.4458	.0396
22	.0396	.5487	.4252		.2123	.0396	.0396
23		.5144	.394		.4039	.0366	.0381
24	.3311		.5373	.394		.5144	.0366
Max	.3588	.583	.7164	.815	.4039	.5316	.0914
Min	.0244	.3772	.2103	.0152	.061	.0366	.0229
Avg	.157	.4755	.4903	.2588	.2144	.3622	.0415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 202 / BENDRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2334				.0069	.1715	.0152
2	.1959	.1791		.1715	.0061		.0152
3	.1852	.1791		.1715	.0069	.1372	.0183
4	.2011	.1791			.0069	.1372	.0183
5	.2168	.2149			.0069	.1543	.0213
6	.1877	.2149		.2058	.0171	.12	.0213
7	.1633	.2481		.2401	.0244		.0171
8	.1305	.2507			.024	.1372	.0183
9	.0816	.2507				.0857	.0152
10	.0883	.2126				.12	.0183
11		.1417				.2401	.0122
12	.0086	.1772		.0069	.1136		.0152
13	.0103	.2126		.0122	.1305	.2058	.0171
14	.0091	.2507		.0122	.0857	.2058	.0171
15	.0137	.2481		.0122	.0857	.2401	.0069
16	.0206	.2804		.0152	.12	.2401	.0069
17	.0183	.2804		.0171		.2401	.0122
18	.0213	.2835		.024	.1543	.2572	.0229
19	.0335	.3155			.1715		.0274
20	.0335	.4207				.3772	.0305
21	.0427	.4207			.2401	.3772	.0335
22	.0274	.3856			.2229	.0335	.0335
23		.3544	.3429		.2743	.0305	.0305
24	.2243				.0152		.0305
Max	.2334	.4207	.3429	.2401	.2743	.3772	.0335
Min	.0086	.1417	.3429	.0069	.0061	.0305	.0069
Avg	.0976	.2591	.3429	.0808	.0902	.1848	.0198



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174046 / MATUL

Feeder No / Name : 203 / SONARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5538	.7602	1.0745	1.0029		.8573	.0823
2	.563	.7164	1.0277	.9774		.9945	.0823
3	.6595	.7164	1.0029	.9774			.0823
4	.716	.788	.9313	1.0387	.0975	1.0288	.0854
5	.8531	.7964	1.0745	1.1462			.0914
6	.9887	.6805	1.1584	1.2894	.1067	1.0288	.0975
7	.8688	.8145	1.2308	1.134	.0914		.1036
8	.8267	.8954	.9922	.9313	.0884	.8573	.0945
9	.6904	.8764	.8063	.064		.7716	
10	.5524	1.0029	.3898	.0533	.1036	.7888	
11	.3138	.9671	.4961	.061	.7716	.4458	.061
12	.0274	.4961	.7087	.0686	.9431	.8916	.0884
13	.0305	.4298		.0686			.0838
14	.0305	.5731		.0732	1.1145		.0838
15	.0305	.5731		.0762		.9945	.0884
16	.0381	.6089		.0732	.8573	.9945	.0914
17	.0427	.6089	.9465	.0854	.9431		.0914
18	.0686	.6516	.9816	.0838		1.0974	.0914
19	.0823	.9313	.7087	.0762	.8573	.8916	.0732
20	.0884	1.134	.788		.8916	1.0974	.0914
21	.0884	1.1462	1.1104			1.0288	.1036
22	.061	1.1584	1.0745		1.0974	.0914	.0975
23	.0884	1.1104	1.0387		.7716	.0884	.0975
24	.9758	.724	1.086	1.0136		.7716	.0854
Max	.9887	1.1584	1.2308	1.2894	1.1145	1.0974	.1036
Min	.0274	.4298	.3898	.0533	.0884	.0884	.061
Avg	.3850	.7983	.9314	.5147	.6239	.8178	.0885

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 201 / MASALGA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1			.0335
2			.0335
3			.0335
4			.0335
5			.0671
6			.1006
7			.1341
8			.1677
9		.2012	.2347
10			.3353
12	.1341		
16	.2347		
17	.2347		
Max	.2347	.2012	.3353
Min	.1341	.2012	.0335
Avg	.2012	.2012	.1174

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 202 / PALAJ AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	22-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0857		
2	.0857		
3	.0857		
4	.0857		
5	.1715		
6	.1715		
7	.1715		
8	.1715		
9	.1715		
10	.1715		
12		.2012	.2347
13			.2347
14			.2347
15			.2012
16		.2347	
Max	.1715	.2347	.2347
Min	.0857	.2012	.2012
Avg	.1372	.2180	.2263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 203 / KINI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401		.1867	.1772	.1772		
2	.2401		.2241	.1772	.1772		
3	.2401		.2241	.2126	.2126		
4	.2401		.2614	.2126	.2481		
5	.2401		.2987	.2481	.2481		
6	.2743		.3361	.2481	.2835		.3734
7	.2401		.3361	.2835	.2835		.3361
8	.2401		.2614			.2987	.2987
9	.1372					.2241	.1867
10	.1372						.1494
12						.1494	
13						.1867	
14						.1867	
15						.1867	
16					.1867	.2241	
20		.2987				.2987	
21		.2614					
22		.2241					
23		.1867				.2241	
24	.2401		.1867	.1772	.1772	.2241	.2241
Max	.2743	.2987	.3361	.2835	.2835	.2987	.3734
Min	.1372	.1867	.1867	.1772	.1772	.1494	.1494
Avg	.2245	.2427	.2573	.2171	.2216	.2203	.2614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174047 / KINI

Feeder No / Name : 204 / PALAJ GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401		.2241	.2561	.2195		
2	.2401		.2614	.2561	.2195		
3	.2401		.2987	.2561	.2561		
4	.2401		.2987	.2926	.2561		
5	.2401		.3361	.2926	.2926		.3734
6	.2743		.3734	.3292	.2926		.4108
7	.2401		.4481	.3292	.3292		.4108
8	.2401		.3734			.4108	.3734
9	.1715					.3361	.2987
10	.1715						.2614
12					.1867	.2614	
13						.2614	
14						.2614	
15						.2614	
16					.2614	.2614	
20		.3361				.3361	
23		.2987				.2614	
24	.2401		.2241	.2561	.2195	.2614	.2614
Max	.2743	.3361	.4481	.3292	.3292	.4108	.4108
Min	.1715	.2987	.2241	.2561	.1867	.2614	.2614
Avg	.2307	.3174	.3153	.2835	.2533	.2913	.3414

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 201 / SINGARWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3481		.0995	.116	.116	.1658	.1658
2	.3481		.0995	.1326	.116	.1658	.1658
3	.3481		.0995	.0995	.1326	.1658	.1658
4	.3481		.0995	.0995	.1326	.1658	.1658
5	.3481		.0995	.0995	.1326	.1989	.1658
6	.3978		.1326	.0995	.1326	.1989	.1658
7	.1989		.0995	.0829	.1492	.1989	.1658
8	.1989		.0995	.0663		.1658	.1326
9	.1492		.0663		.1658		.1326
10	.1326		.0332		.0995		.0829
11	.1326		.0995				.1492
12	.0663			.0497	.0995	.1326	
13	.0663		.0995	.0497	.1326	.0995	.1492
14	.0663			.0995	.1326	.0663	.1492
15	.0663		.0995	.1492	.1326	.0663	.0995
16	.0995		.0995	.1492	.1326	.0663	.0995
17	.1326	.1326	.1989	.1492	.1658	.1326	.1989
18	.2486	.0995	.2486	.1492	.1989	.1989	.1989
19	.2486	.2984	.3481	.2486	.2984	.2321	.1989
20	.2486	.2984	.3481	.3481	.3315	.2984	.3481
21	.2984	.2984	.3978	.3481	.3647	.3315	.3978
22	.2984	.2984	.3978	.3481	.3647	.3315	.3978
23	.3481	.2984	.3481	.3481	.3647	.3315	.3481
24	.3481	.3481	.2984	.3481	.3481	.3647	.3315
Max	.3978	.3481	.3978	.3481	.3647	.3647	.3978
Min	.0663	.0995	.0332	.0497	.0995	.0663	.0829
Avg	.2286	.2590	.1778	.1705	.1929	.1942	.1989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 202 / SAWARGAON MAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.064		.064	.064	.048	.064	.064
2	.048		.064	.064	.048	.064	.064
3	.064		.032	.064	.048	.064	.064
4	.064		.064	.064	.048	.064	.064
5	.064		.064	.064	.048	.064	.064
6	.064		.064	.064	.048	.064	.064
7	.064		.064	.064	.048	.064	.064
8	.064		.064	.064		.064	.064
9	.096		.032		.032		.048
10	.096		.032		.032		.048
11	.048		.096		.096		.096
12	.048			.096	.096	.064	.128
13	.048		.064	.0995	.128	.096	.096
14	.048		.064	.096	.128	.096	.096
15	.048		.096	.064	.128	.064	.096
16	.048		.096	.064	.128	.096	.16
17	.048	.032	.064	.064	.128	.096	.128
18	.048	.032	.064	.096	.128	.096	.096
19	.048	.032	.064	.048	.064	.064	.048
20	.048	.064	.096	.096	.064	.064	.096
21	.096	.064	.096	.096	.064	.064	.096
22	.096	.064	.096	.096	.064	.064	.096
23	.096	.064	.064	.048	.064	.064	.048
24	.064	.048	.064	.064	.048	.064	.064
Max	.096	.064	.096	.0995	.128	.096	.16
Min	.048	.032	.032	.048	.032	.064	.048
Avg	.0633	.05	.0682	.0733	.0751	.0716	.0813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174114 / SOMTHANA

Feeder No / Name : 203 / DEWTHANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671		.2347	.2515	.2012	.2347	.2347
2	.0671		.2012	.2515	.2012	.2347	.2347
3	.0671		.2012	.2012	.2012	.2347	.2347
4	.1006		.2012	.2012	.2012	.2347	.2347
5	.1006		.2347	.2012	.2012	.2347	.2347
6	.1006		.2347	.2515	.2012	.2347	.2347
7	.1006		.2347	.2012	.2012	.2347	.2347
8	.1341		.1341	.2012		.2012	.2012
9	.0671		.0671		.1341		.1509
10	.0671		.0671		.1006		.1006
11	.1006		.1006		.0671		.1006
12	.1006			.0671	.1006		.1006
13	.1006		.0671	.0671	.1006		.1006
14	.1006		.1006	.0671	.1006		.1006
15	.1006		.0671	.1006	.1341		.0671
16	.1006		.0671	.1006	.1341	.1006	.0671
17	.1006	.1341	.0671	.0671	.1341	.1006	.1006
18	.1006	.1677	.0671	.1006	.1341	.1006	.1006
19	.2012	.2012	.2012	.2012	.1677	.1677	.2012
20	.2515	.2347	.2515	.2012	.2012	.2012	.2012
21	.2515	.2347	.2515	.2515	.2347	.2347	.2012
22	.2515	.2347	.2515	.2515	.2347	.2347	.2012
23	.2012	.2347	.2515	.2012	.2347	.2347	.2012
24	.2012	.2012	.2347	.2515	.2012	.2347	.2347
Max	.2515	.2347	.2515	.2515	.2347	.2347	.2347
Min	.0671	.1341	.0671	.0671	.0671	.1006	.0671
Avg	.1265	.2054	.1648	.1757	.1662	.2032	.1698



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 201 / BHOSI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.4572			.381	
3	.6478						
4			.4763			.4115	
5	.6344						
6		.7716	.6219		.5144	.4725	
7	.8573		.695	.423			
8			.5658				
9	.8573						
10						.3353	.3658
12		.1905				1.1622	
13		.2096		.7716			
14	.3429					1.1812	
15				.6859			
16	.3772					1.1431	
17		.381					
18	.4115			1.0288			
20	.4801	.5906		.5144			
21	.5144		.3086				
22		.5335					
24	.4954	.463	.4954		.463	.381	.3658
Max	.8573	.7716	.695	1.0288	.5144	1.1812	.3658
Min	.3429	.1905	.3086	.423	.463	.3353	.3658
Avg	.5618	.4485	.5172	.6847	.4887	.6835	.3658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 202 / WAKAD FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.2286				
3						.1829	
4			.2286				
5	.4458						
6		.4287	.2378		.2572	.1981	
7	.5316		.1829	.1372			
8	.4344		.1715				
9	.6516					.1524	
10							.1524
12		.1524				.543	
13				.5144			
14	.1715	.1334				.6516	
15				.5487			
16	.1715					.7783	
17		.2096					
18	.2058			.4801			
20	.3086			.2915			
21	.3429		.1143				
22		.2667					
24	.3429	.3086	.2286		.3429	.1524	.2286
Max	.6516	.4287	.2378	.5487	.3429	.7783	.2286
Min	.1715	.1334	.1143	.1372	.2572	.1524	.1524
Avg	.3607	.2499	.1989	.3944	.3001	.3798	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

BHOKAR (R) S/DN[457] BU 7412

Substation No/ Name :- 174116 / BHOSI

Feeder No / Name : 203 / CHITGIRI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.439			.8688	
3	.3077						
4			.4251			1.105	
5	.3429						
6		.6001	.6697		.6859	1.3527	
7	.5487			.6554			
8			.7888			1.5242	
9	.4801						
10						1.5242	1.4861
12		1.0288				.2286	
13				.1029			
14	.7716	.7888				.2591	
15				.2572			
16	.6859					.2743	
17		.724					
18	.7202			.3429			
19		.5335					
20	.5144			.5316			
21	.4287		.2743				
22		.5716					
24	.381	.3944	.4954		.463	.4115	.4268
Max	.7716	1.0288	.7888	.6554	.6859	1.5242	1.4861
Min	.3077	.3944	.2743	.1029	.463	.2286	.4268
Avg	.5181	.6630	.5154	.378	.5745	.8387	.9565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 201 / AMBALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5375		1.1905	.3429	.3856	.4694	.4715
2	.5375		1.2231	.3429	.3856	.503	.4191
3	.5375		1.4218	.3429	.4024	.503	.3887
4	.5721		1.5165	.4287	.4024	.5365	.4144
5	.5895		1.5181	.4287	.4024		.4525
6	.5721		1.5493	.463	.5868	.5868	.426
7	.5895		1.8009	.6001	.9221		.663
8	.4334		1.6113	.7888		1.0059	.7287
9	.4344		.7583	.7888		1.0059	
10				.7042	.8718		.7287
11	.5365		.2743	.2347	.2515	.9389	
12	.503			.2347	.2543	.3353	
13	.4694			.2347	.2543	.3353	
14	.4694			.2347		.362	
15	.4191		.2572	.2515	.2543	.362	.2743
16	.4024		.3086	.2347	.2515	.3506	.2743
17	.3688		.3429	.3018		.3033	.2915
18	.4191	.759	.3429	.3185	.3521	.362	.3429
19	.503	.5687	.4115	.4359	.5197	.4527	.5144
20	.5868	.5687	.4801	.57		.503	.6001
21	.5868	.6635	.5487	.5868	.5868	.543	.583
22	.5533	.567	.583	.57	.5868	.5658	.583
23	.5365	.4893	.5144	.5533	.57	.5658	.4877
24	.5365	.5687		.5144	.5365	.543	
Max	.5895	.759	1.8009	.7888	.9221	1.0059	.7287
Min	.3688	.4893	.2572	.2347	.2515	.3033	.2743
Avg	.5084	.5978	.8765	.4378	.4619	.5302	.4802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 202 / HADGAON

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842			1.3032	1.4118	1.3756	1.1736
2	1.448			1.3032	1.4118	1.4118	1.2407
3	1.3575			1.3717	1.448		1.278
4	1.3575			1.4575	1.4661	1.4842	1.326
5	1.4842			1.7147	1.4842	1.5927	1.3916
6	1.7556			1.749	1.828	1.7375	1.4251
7	1.7918			1.7147	1.7375	2.0271	1.5927
8	1.7918			1.5432		1.7194	1.5257
9	1.5203		1.4786	1.5947		1.6108	
10	1.3575			1.448	1.4118	1.3672	1.3413
11			1.2346	1.448		1.2934	
12	1.3575		1.2003	1.3575	1.3394	1.0745	
13	1.3032		1.166	1.267	1.3032	1.0517	
14	1.2308		1.166	1.1946	1.267	1.086	
15	1.2308		1.1317	1.3032		1.086	1.166
16	1.267		1.1317	1.3032	1.3575	1.086	1.2003
17	1.267		1.2003	1.4118		1.267	1.286
18	1.3756	1.5135	1.3375	1.7375	1.6289	1.267	1.3032
19	1.7375	1.6113	1.5604	1.7375	1.7556	1.2574	1.4918
20	1.647	1.7061	1.4575	1.828	1.7194	1.2793	1.4575
21	1.5927	.6615	1.4575	1.7194		1.2574	1.4746
22	1.5565	1.6113	1.4403	1.7194	1.5746	1.2574	1.3717
23	1.448	1.3047	1.3717	1.5746	1.4842	1.1736	1.3203
24	1.3375	1.4042		1.3032	1.448	1.3203	
Max	1.7918	1.7061	1.5604	1.828	1.828	2.0271	1.5927
Min	1.2308	.6615	1.1317	1.1946	1.267	1.0517	1.166
Avg	1.4652	1.4018	1.3096	1.5044	1.5043	1.3514	1.3537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 203 / BELMANDAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287		.7583	.6859	.7842	.7762	.7392
2	.4115		.6523	.6859	.7842	.7842	.7922
3	.4287		.8531	.6859	.8029		.7545
4	.4115		.7339	.7545	.8402	.8215	.8299
5	.4115		.8531	.7888	.8402		.8871
6	.4458		.8531	.8573	.9335	.8402	.9145
7	.5144		.7339	.823	.8589		.8316
8	.6687		.6828	.6001		.7095	.7545
9	.6516		.5676	.583		.6535	.724
10	.5535				.3772	.4805	.502
11	.3361		.7164	.7011	.8907	1.086	
12	.3174		.7164	.8078		1.267	
13	.3361		.8402	.8642		1.2127	
14	.3734		.7468	.9282	.9602		
15	.3734		.8573	1.0242		1.0562	1.0669
16	.4108		.7773	1.0562	1.5927	1.0059	1.0669
17	.4294		.8916	1.0402	1.3763	1.0059	1.0974
18	.5601	.5687	.7926	1.0242	1.3927	.9717	1.1279
19	.7095	.759	.583	.4481	.7762		.7716
20		.7583	.6859	.8299	.2614	.7392	.7716
21	.8215	.8531	.7202	.7922		.811	.7545
22	.7842	.8151	.7202	.8488	.8402	.811	.7202
23	.7842	.6523	.6859	.7922	.8215	.7577	.7202
24	.6706	.7506		.6859	.7733	.7392	
Max	.8215	.8531	.8916	1.0562	1.5927	1.267	1.1279
Min	.3174	.5687	.5676	.4481	.2614	.4805	.502
Avg	.5145	.7367	.7465	.7960	.8837	.8700	.8330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 204 / WATEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.455	.3772	.4435	.4435	.4251
2	.2572		.4077	.3772	.4435	.4481	.4163
3	.2572		.424	.3772	.462		.4435
4	.2572		.51	.6001	.4805	.5228	.543
5	.2229		.4893	.6001	.5175		.6335
6	.3772		.7339	.6859	.7392	.6535	.7392
7	.2058		.6635	.6001	.7023		.6099
8	.3944		.6635	.5144		.6348	.543
9	.3944		.3048	.4458		.5601	
10	.3841			.3174	.3326	.3982	.2772
11	.2402		.4458		.5601	.4961	
12	.1867		.4458	.4999	.703	.6335	
13	.1867		.4115	.4531		.543	
14	.2241		.4115	.502	.7621	.5668	
15	.2614		.4458	.5506		.5868	.5144
16	.2987		.4458	.6478	.6859	.5868	.5144
17	.3734		.463	.6478		.4191	.5487
18	.4481	.3602	.3772	.7468	.6859	.3353	.583
19	.5228	.5687	.4115	.499	.462	.3961	.4287
20	.5415	.4739	.4115	.499	.4668	.4715	.3429
21	.5041	.4914	.4115	.4805		.4338	.3772
22	.4668	.4929	.4115	.4805	.4668	.4338	.3772
23	.4668	.4554	.3772	.462	.4668	.4338	.3772
24	.4191	.455		.3772	.4435	.4338	
Max	.5415	.5687	.7339	.7468	.7621	.6535	.7392
Min	.1867	.3602	.3048	.3174	.3326	.3353	.2772
Avg	.3395	.4711	.4601	.5105	.5458	.4967	.4830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 205 / KOTHALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658		.3414	.4287	.4161	.4877	.4049
2	.5658		.3643	.4287	.4321	.5668	.4049
3	.583		.3588	.4801	.4321		.3563
4	.6001		.3751	.4801	.4641	.6478	.4144
5	.5658		.4077	.5316	.4801	.6722	.4096
6	.6001		.4893	.5144	.4801	.7202	.4096
7	.5487		.5121	.6516	.4961	1.0526	.6859
8	.463		.6523	.6859		1.0364	.7716
9	.3429		.4929	.7888		1.0974	
10	.2743		.6001	.6964	1.1736	1.2437	
11	.499		.1715	.5761	.3734	.362	
12	.5535		.1715	.5761	.3734	.3881	
13	.5735		.2058	.5761	.3734	.4251	
14	.5468		.2058	.5761		.3696	
15	.5535		.2401	.5761		.3353	
16	.5312		.2058	.5761	.3018	.3353	.3429
17	.5218		.1886	.5761	.4108	.3163	.3429
18	.5668	.6642	.2058	.5761	.4294	.3906	.3429
19	.5544	.5693	.4458	.5761	.5228	.462	.6001
20	.5975	.6622	.5487	.5761	.5788	.5729	.6001
21		.6635	.583	.4161	.5975	.5544	.6001
22	.2987	.6635	.5487	.4161	.6535	.5658	.6001
23	.3361	.6452	.5144	.4161	.6348	.5544	.5487
24	.5365	.6256		.5316	.4161	.543	
Max	.6001	.6642	.6523	.7888	1.1736	1.2437	.7716
Min	.2743	.5693	.1715	.4161	.3018	.3163	.3429
Avg	.5121	.6419	.3839	.5511	.502	.5956	.4897



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174013 / HADGAON

Feeder No / Name : 206 / KOTHALA WW EXP.

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686						
2	.0686						
3	.0686		.061	.0533	.061		.0457
4	.0686		.0526	.0533	.0457		.061
5	.0686		.061	.0547	.0457		.061
6	.0686		.061	.0547	.0457		.061
7	.0686		.0457	.0533	.0457		.0457
8			.0457	.052			
9				.052			
10				.061		.061	
11				.061			
17							.0587
18		.061		.061	.061	.061	.056
19		.061				.0457	.056
Max	.0686	.061	.061	.061	.061	.061	.061
Min	.0686	.061	.0457	.052	.0457	.0457	.0457
Avg	.0686	.061	.0545	.0556	.0508	.0559	.0556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 201 / WAIPANA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5609		.7621	.4908		.8002	.5365
2	.5609		.7621	.4908		.8573	.5609
3	.5609		.8002	.4908		.9145	.5609
4	.583		.8573	.4908		.8573	.5609
5	.6173		.8573	.5609		1.0479	.5609
6	.6859		.9526	.7011		1.1431	.7011
7	.823		.8573	.7011		1.1431	.0351
8	.9282		.7621	.6783		1.0669	.6706
9				.7209		1.0479	
10	.9149			.7655	.9526	1.1431	.9431
11	.5975		.5761	.7282	1.0479		.9808
12	.5415				.9907		.9335
13	.4481		.5182		1.0669	.602	.9335
14	.3921		.3567		1.0288	.602	.9511
15	.3361		.4816	.6535	.9526	.602	1.0185
16	.4108		.2343	.9149	.9526	.5944	1.0269
17	.4854	.7621	.6249	.9896	.8573	.6401	.9709
18	.5601	.8573	.6401	.9149	.9526	.4877	.8775
19	.5601	.7621	.003	.6348	.9145	.5243	
20	.5228	.5716	.5365	.5487	.7621	.5365	.7842
21	.5281	.6097	.5304	.5601	.6668	.5365	.7282
22	.4904	.4572	.4641	.4854	.7621	.506	.6722
23		.4763	.4694		.8002	.6036	.6535
24	.5609		.5144	.4908		.7621	.5365
Max	.9282	.8573	.9526	.9896	1.0669	1.1431	1.0269
Min	.3361	.4572	.003	.4854	.6668	.4877	.0351
Avg	.5759	.6423	.5981	.6506	.9077	.7736	.7362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 202 / TALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.381	.679		.5716	.7545
2	.3772		.4191	.679		.6097	.7545
3	.3772		.4572	.679		.6287	.7167
4	.4115		.5144	.679		.6478	.7167
5	.4458		.5335	.7545		.6859	.7545
6	.4801		.4763	.9054		.724	.8299
7	.6859		.5716	.9054		.6668	.9054
8	.6783		.5335	.7545		.7049	.7545
9						.6668	
10	.7682				.5716	.6097	.7468
11	.2561		.5693	.7499	.8002		.9335
12	.2561			.823	.9335		.9709
13	.2896		.5693	.8596	1.0669	.7042	.9709
14	.2896		.6325		.9526	.7042	.9709
15	.3077		.4858	.8779	1.0479	.6958	.9709
16	.3841		.6401	.8962	.8573	.6958	.9335
17	.4572	.381	.431	1.0608	.7621	.6958	.9709
18	.4887	.381	.6554	1.0242	.8002	.7186	.9896
19	.6697	.4763	.8299	.7655	.6097	.8676	
20	.7059	.5716	.8299	.8048	.6668	.8676	.7186
21	.7964	.5335	.8299	.8413		.8299	.7796
22	.8145	.4763	.7922	.8596	.6668	.8299	.7796
23		.4763	.7167		.6668	.7545	.8299
24	.7545		.4763	.679		.724	.7545
Max	.8145	.5716	.8299	1.0608	1.0669	.8676	.9896
Min	.2561	.381	.381	.679	.5716	.5716	.7167
Avg	.5033	.4709	.5879	.8139	.8002	.7093	.8412

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 203 / TAMSA TOWN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.4763	.6348		.5716	.547
2	.5975		.4954	.6348		.5716	.547
3	.5975		.5335	.5975		.6097	.5228
4	.5601		.5144	.5975		.6478	.5228
5	.5601		.5716	.5975		.6668	.5601
6	.6348		.6097	.6348		.724	.6348
7	.7095		.6668	.7842		.7621	.7468
8	.6722		.4763	.7095		.6668	.679
9				.6722		.5716	
10	.6335			.5853		.5144	.5975
11	.5792		.5175	.4938			.5601
12	.5487		.5175	.4938			.5415
13	.5611		.5544	.5121		.4854	.4938
14	.5611		.499	.5121		.4805	.5041
15	.543		.6283	.5121		.4435	.4572
16	.5611		.4435	.5487		.4435	.439
17	.5611	.5716		.5975		.5175	.4668
18	.5792	.6097	.7316	.6335		.4854	.5415
19	.6878	.6668	.6838	.6767		.5975	
20	.6516	.7049	.6838	.6908		.5601	.5853
21	.6516	.6668	.6535	.6584		.5601	.543
22	.6348	.5716	.6348	.6584	.6097	.5415	.5083
23		.5335	.6348		.5716	.5415	.547
24	.6348		.4763	.6348		.5716	.5415
Max	.7095	.7049	.7316	.7842	.6097	.7621	.7468
Min	.543	.5335	.4435	.4938	.5716	.4435	.439
Avg	.6054	.6178	.5716	.6118	.5907	.5698	.5494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 204 / JAMBHALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527		.5716	.3563		.5716	.4024
2	.4115		.5716	.3688		.6478	.4024
3	.415		.6097	.301		.7621	.4694
4	.415		.5716	.2972		.8573	.5609
5	.4115		.6097	.3688		.9526	.5609
6	.4904		.6668	.3418		1.0479	.7011
7	.4527		.7049	.639		1.3336	.9991
8	.4191		.6668	.6249		1.6194	1.1069
9						1.5242	
10	.2534			.5487		1.4861	1.4937
11	.6516						
12	.7602						
13	.7865					.2667	.2561
14			.2477			.2667	.2614
15	.6697		.2667	.6401		.2667	.2534
16	.724		.2858	.2012		.2667	.2378
17	.8326	1.1431		.2427		.3048	.2614
18	.9231	.8573	.3395	.3292		.3772	.2743
19	.3982	.381	.415	.3841		.4904	
20	.5121	.4763	.4904	.439		.4904	.439
21	.5249	.4382	.4904	.5121		.4904	.4706
22	.5121	.4572	.4904	.5249	.5144	.5093	.4755
23		.4191	.4904		.5525	.5093	.4854
24	.4904		.4191	.4904		.5335	.4715
Max	.9231	1.1431	.7049	.6401	.5525	1.6194	1.4937
Min	.2534	.381	.2477	.2012	.5144	.2667	.2378
Avg	.5479	.5960	.4949	.4228	.5335	.7079	.5292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174014 / TAMSA

Feeder No / Name : 206 / Natraj Exp

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0046		.0381	.0046		.0381	.0046
2	.0038		.0381	.0053		.0381	.0046
3	.0046		.0381	.0046		.0381	.0351
4	.0038		.0381	.0053		.0381	.0053
5	.0038		.0381	.0046		.0381	.0042
6	.0038		.0381	.0053		.0381	.003
7	.0034		.0381	.0057		.0381	.0069
8	.0019		.0381	.0019		.0381	.0095
9				.005		.0381	
10	.0351					.0381	.0373
11	.0351		.0023				.0366
12	.0351		.0023	.0366			.0366
13	.0362		.0023	.0366		.0046	.0366
14	.0351		.0023	.0366		.0046	.0373
15	.0351		.0023	.0354		.0023	.0366
16	.0351		.005	.0366		.0015	.0362
17	.0351	.0381	.0042	.0373		.0046	.0366
18	.0351	.0381	.0015	.0366		.0019	.0362
19	.0362	.0381	.003	.0366		.0046	
20	.0362	.0381	.0046	.0354		.0046	.0351
21	.0362	.0381	.0042	.0354		.0046	.0362
22	.0362	.0381	.0042	.0351	.0381	.0042	.0351
23		.0381	.0046		.0381	.0046	.0343
24	.0046		.0381	.0046		.0381	.0053
Max	.0362	.0381	.0381	.0373	.0381	.0381	.0373
Min	.0019	.0381	.0015	.0019	.0381	.0015	.003
Avg	.0226	.0381	.0175	.0212	.0381	.0210	.0250

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 201 / RUI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4706		.3666	.463	.5121	.4973	.5068
2	.439		.3666	.4458	.5121	.4973	.4706
3	.4344		.3666	.4458	.5121	.4973	.4706
4	.4706		.3666	.4801	.5487	.5487	.5792
5	.543		.4458	.5144	.6584	.6516	.6219
6	.724		.6706	.7545	.8048	.8745	.7682
7	.7964			.7888	.8048	.7888	.8048
8	.6516			.6859		.703	.8688
9	.5853			.4973	.4024		.543
10	.2534				.4024		.3982
11			.1932		.3772	.567	
12			.2572	.3086	.3601	.5487	
13			.2439	.3086	.3429	.5853	
14			.2743	.3086	.3086		.3292
15	.3048		.2572	.2743	.3258	.5121	.2591
16	.3353		.3944	.3086	.3772	.5068	.3048
17	.4062	.3353	.5144	.3429	.5144		.3563
18	.4877	.4268	.6001	.5144		.5853	.4534
19	.4572	.5792	.6344	.6516	.7373	.6219	.5944
20	.4877	.5498	.5658	.6859	.6859	.5853	.5182
21	.4572	.4607	.5316	.583	.583	.5853	.4572
22	.4458	.4287	.4973	.5144	.5316	.5487	.4572
23	.4161	.3948	.463	.5144	.5144	.5487	.4268
24	.4755		.3666	.463	.5121	.4973	.5068
Max	.7964	.5792	.6706	.7888	.8048	.8745	.8688
Min	.2534	.3353	.1932	.2743	.3086	.4973	.2591
Avg	.4821	.4536	.4188	.4934	.5149	.5875	.5093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 202 / DHANORA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2949					
10	.2949					
15	.2286					
16	.2286					
17		.4268	.4801	.7468	.3563	.5792
18		.3963	.4572	.7621	.3563	.6562
19		.2743	.3658	.6249	.3932	.5182
20		.2286	.3658	.5639	.3277	.4877
21		.2286	.3658	.5335	.3277	.4572
22		.2439	.3429	.5182	.3277	.442
23		.2439	.3201	.503	.3277	.431
24			.2439	.3201	.4877	
Max	.2949	.4268	.4801	.7621	.4877	.6562
Min	.2286	.2286	.2439	.3201	.3277	.431
Avg	.2618	.2918	.3677	.5716	.3630	.5102



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 203 / VARULA AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1219	.1829	.1966
2			.1219	.2286	
3			.1372		.1966
4			.1524		.1966
5			.1829		.2294
6			.2134		.2294
7			.2743		.3982
8			.2743		.3932
17	.3048	.2972			
18	.1981	.3269			
19	.1829	.1286			
20	.0914	.1286			
21	.0572	.1286			
22	.0714	.141			
23	.0564	.141			
24					.1966
Max	.3048	.3269	.2743	.2286	.3982
Min	.0564	.1286	.1219	.1829	.1966
Avg	.1375	.1846	.1848	.2058	.2546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 204 / Yelamb AG Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2785		
2				.1638		
3				.1638		
5				.2195		
6				.1966		
7	.1638					
8	.2195			.2785		
9	.1966		.1219			.2949
10	.1147			.1638		.2591
11		.2667		.2439		
12		.1981	.1829	.2439		
13		.2286	.2058	.3201		.2926
14		.2591	.2058	.4115		.2896
15		.1981	.2286	.4115		.1677
16			.2286	.3658		.2286
19			.2286			
20			.2515	.3048		
21			.2058	.2743		
22			.16	.2439		
23			.1372	.2439		
24				.1372	.2286	
Max	.2195	.2667	.2515	.4115	.2286	.2949
Min	.1147	.1981	.1219	.1372	.2286	.1677
Avg	.1737	.2301	.1961	.2592	.2286	.2554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 205 / NIWGHA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292		.2538	.3086	.3292	.3086	.3258
2	.3258		.2538	.3086	.3292	.3086	.3258
3	.3258		.2538	.2743	.3292	.3086	.3292
4	.362		.2538	.2743	.3658	.3429	.362
5	.3982		.3144	.3429	.4755	.3772	.3982
6	.4755		.4755	.5144	.4755	.4973	.4344
7	.6154			.4801	.5487	.5316	.5068
8	.5487			.4973	.5487	.5487	.5068
9	.2561			.4287	.3292	.463	.3982
10					.3292	.3772	.362
11			.2378		.3086	.3801	
12			.2743	.2401	.2743	.3658	
13			.2743	.2401	.3086	.3658	.2561
14			.2743	.2401	.2743	.3292	.2561
15	.2591		.2915	.2058	.2915	.3292	.2591
16	.2743		.3086	.2743	.3086	.3658	.2743
17	.3048	.3048	.3944	.3429	.3944	.3658	.3239
18	.3658	.3353	.3772	.3772	.3944	.3982	.3887
19	.442	.3963	.4458	.4458	.463	.3982	.3658
20	.3506	.3963	.3772	.4115	.4287	.3658	.3658
21	.3353	.3418	.3601	.3772	.3772	.3658	.3201
22	.2972	.2896	.3429	.3429	.3429	.3658	.3048
23	.2972	.2715	.3258	.3429	.3429	.3292	.2675
24	.3292		.2538	.3086	.3292	.3258	.3258
Max	.6154	.3963	.4755	.5144	.5487	.5487	.5068
Min	.2561	.2715	.2378	.2058	.2743	.3086	.2561
Avg	.3627	.3337	.3172	.3445	.3708	.3798	.3481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174032 / NIWGHA

Feeder No / Name : 206 / PEWA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344		.3384	.4115	.3658	.3429	.3982
2	.6036		.3384	.3772	.9877	.3601	.3982
3	.4024		.3384	.3772	.3658	.3601	.3982
4	.439		.3666	.4115	.4024	.3772	.4706
5	.4755		.4512	.4973	.5121	.4458	.5487
6	.5487		.0423	.6516	.6584	.6173	.6516
7	.6516			.6001	.6219	.6173	.6516
8	.5853			.5487	.6219	.583	.6878
9	.5121			.4287	.4755	.5487	.4706
10	.4024				.2534	.4458	.4024
11			.208	.1715	.2743	.3658	
12			.1715	.1715	.2743	.3658	
13			.2058	.1715	.12	.3982	.3109
14			.2401	.1372	.12	.3982	.2743
15	.2439		.2743	.1372	.1029		.1829
16	.2896		.3258		.1029		.2439
17	.2896	.3048	.3601	.1372	.1715	.3982	.3048
18	.4268	.3048	.4287		.4801	.4344	.426
19	.4877	.5053	.5144	.2743	.5487	.4755	.442
20	.4725	.4877	.4458	.4458	.4801	.439	.4268
21	.4115	.4115	.4973	.4115	.4287	.439	.4268
22	.3567	.3715	.463	.3772	.3772	.4755	.3567
23	.3418	.3567	.4287	.3772	.3772	.439	.3567
24	.4344		.3384	.4115	.362	.3601	.4024
Max	.6516	.5053	.5144	.6516	.9877	.6173	.6878
Min	.2439	.3048	.0423	.1372	.1029	.3429	.1829
Avg	.4405	.3918	.3389	.3584	.3952	.4403	.4196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 201 / LINGAPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1762	.0704	.267		.0617	.0689
2	.1584	.1471	.062		.0617	.0689
3	.1586	.1651	.1471		.0617	.0775
4	.1584	.1839	.1583		.0608	.0775
5	.1584	.1793	.1605		.0739	.0861
6	.2094	.2131	.165		.0706	.0861
7	.2756	.3475	.1783		.0689	.1033
8	.354	.3869	.1962		.1033	.1999
9	.3292	.3677	.1468			.0775
10		.4458	.1513			.0581
11		.0759	.1636	.4353	.399	
12		.0935	.2244	.5079	.478	
13		.1043	.2241	.5447	.4964	
14		.0934	.1717	.5804	.4815	
15		.1041	.2241	.3968	.4716	
16		.1041	.2239	.5653	.4596	.411
17		.1084	.4005	.5647	.4716	.4384
18		.132	.4513	.4758	.477	.4404
19		.1856		.1521	.069	.151
20		.1858		.1699	.0739	.1512
21		.1506		.1894	.0689	.1186
22				.1523	.1255	.1512
23		.132		.1523	.0794	.1355
24	.1318	.0529	.13		.0663	.0689
Max	.354	.4458	.4513	.5804	.4964	.4404
Min	.1318	.0529	.062	.1521	.0608	.0581
Avg	.211	.1752	.2024	.3759	.2173	.1563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 202 / ASHTI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5682	.4807		.5664		.6543	.5464
2	.6044	.475		.5676		.6619	.5664
3	.6057	.4813		.6042		.6972	.6608
4	.6488	.5415		.6419		.6979	.6608
5	.6495	.5631		.6608		.8496	.756
6	.7846	.7133		.6608		.9639	.8316
7	.8867	.8928		.6419		.7575	.7189
8	.941	.9385		.5676		.7189	.7182
9	.9459	.9511		.4343		.5601	.7567
10	.7305	.7486		.4343		.5556	.6231
11	.5985	.3435		.5168		.7356	.6523
12	.5079			.5495		.7801	.8084
13				.5508		.8066	
14			.7645	.7563		.7082	
15			.7058	.7609			
16			.7305	.7907		.8786	
17			.5809	.7572		.6118	
18			.6645	.9175		.6508	
19			.6342			.5804	
20	.7609		.5956			.653	
21	.5857		.5859		.756	.6011	
22	.4944		.5664		.7189	.5828	
23	.4881	.487	.5664		.7175	.6072	
24	.6701	.4881		.5344		.6804	.5441
Max	.9459	.9511	.7645	.9175	.756	.9639	.8316
Min	.4881	.3435	.5664	.4343	.7175	.5556	.5441
Avg	.6748	.6234	.6395	.6270	.7308	.6954	.6803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174036 / ASHTI

Feeder No / Name : 204 / YEOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6102	.6238		.5933		.8505	.7502
2	.6206	.6238		.5912		.945	.7379
3	.6186	.6167		.6176		1.134	.8221
4	.6283	.6057	.6994	.6241		1.1328	.9263
5	.629	.6255	.6783	.6523		1.1328	1.0105
6	.6501	.7855	.9372	.7416		1.214	1.0935
7	.7102	.7118	.9835	.9762		1.658	1.3523
8	.6515	.756	.8345	1.0376		1.7684	1.4484
9			1.0229	.8807		1.6861	1.3489
10				1.0713	1.3846	1.4719	.8431
11				.3873	.3265		.4343
12				.3502			.4162
13				.3521	.4158	.4736	.3784
14				.3124	.3589	.4914	.417
15				.3793	.4176	.4919	.4347
16				.3525	.4371	.3402	.4158
17				.3982	.475	.5676	.4158
18				.4741		.5687	.4914
19	.8256				.6557	.567	.6048
20	.5194				.6564	.6804	.6615
21	.6287					.6797	.6615
22	.5072					.6419	.5676
23	.5072					.6048	.5676
24	.6167	.5194		.6426		.6426	.5804
Max	.8256	.7855	1.0229	1.0713	1.3846	1.7684	1.4484
Min	.5072	.5194	.6783	.3124	.3265	.3402	.3784
Avg	.6231	.6520	.8593	.6018	.5697	.8974	.7242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 201 / BARADSHEWALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8459	.7754		.7682	.7895
2	1.0288		.8459	.7754		.7682	.7895
3	1.0288		.7754	.7754		.7682	.7895
4	1.0288		.7754	.8036		.7682	.7895
5	1.166		.8459	.8741		.823	.9305
6			.9305	.9869		.9877	1.0433
7	1.4952		.9587	1.1138		1.2209	1.0997
8	1.3717		.8459			1.4266	1.1279
9	1.2346		.9023			1.2346	1.2125
10	.8916						1.0715
11			.6062	.8459	.8642		.7049
12	.3525		.5639	.3666	.6722		.6344
13	.5921		.5921		.7133		.6908
14			.6203		.7133		.7331
15					.7133		.7049
16	.3666		.8459	.7049	.7545		.8459
17	.3948	.6767	.9446	.9587	.9602		1.0151
18	.8318	.8036	1.0292	.9869	1.1111		
19	1.2689	1.1279	1.2125	1.1561	1.2483	1.0574	
20	1.2407	1.1984	1.2548	1.1279	1.3032	1.2266	1.2689
21	1.2407	1.0715	1.1843	1.0997	1.3032	1.2266	1.2548
22	1.2125	1.0574	1.1843	1.1984	1.2071	1.1279	1.1279
23	1.1702	1.1279	1.1561		1.1385	1.0715	1.1138
24	1.1385		1.0574	1.142		1.0974	1.0433
Max	1.4952	1.1984	1.2548	1.1984	1.3032	1.4266	1.2689
Min	.3525	.6767	.5639	.3666	.6722	.7682	.6344
Avg	1.0029	1.0091	.9081	.9230	.9771	1.0382	.9446



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174059 / BARADSHEWALA

Feeder No / Name : 203 / SIBDARA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629		.5258	.5548		.5258	.5548
2	.2629		.5258	.5548		.5258	.5548
3	.2629		.5258	.5548		.5258	.5548
4	.2629		.5258	.5548		.5258	.5548
5	.298		.6135	.5548		.5609	.5548
6	.3681		.631	.6241		.5959	.6241
7	.4382		.7011	.6935		.7011	.7628
8	.3506		.7011			.6661	.6935
9	.3155		.5258			.6661	.5548
10	.2103						.3814
11	.1387		.1734	.3506	.6661		.3506
12	.1387		.4854	.3506	.6661		.5258
13			.4854	.3506	.4557		.7011
14	.1387		.4854		.5258		.6135
15	.104				.6135		.6135
16	.1734		.4854	.5258	.6661		.7011
17	.2774	.3506	.4854	.6135	.7712		.7011
18	.4161	.3506	.4854	.7011	.7712		
19	.6241	.7011	.5548	.7011	.7011	.5548	
20	.6241	.7011	.6241	.7011	.7011	.5548	.7011
21	.5548	.5258	.6241	.7011	.5959	.5548	.7011
22	.4161	.5258	.5548	.5609	.5609	.5548	.7011
23	.5548	.5258	.5548			.5548	.6135
24	.3506		.5258	.5548		.5609	.5548
Max	.6241	.7011	.7011	.7011	.7712	.7011	.7628
Min	.104	.3506	.1734	.3506	.4557	.5258	.3506
Avg	.3280	.5258	.5364	.5668	.6412	.5752	.6031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 201 / TALNI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0147			.0452	.0602	.044	.0743
2					.0602	.044	.0743
3					.0753	.044	.0743
4					.0753	.044	.0743
5	.0147			.0753	.0753	.0587	.104
6					.0753	.0587	.104
7				.0753	.0753	.0587	.104
8				.1054	.0903	.0734	.1486
9				.1054	.0753	.0734	.1486
10				.1204	.1054	.0734	.1486
12	.0734	.0093					
13	.088	.1867					
14	.1174	.1867					
15	.1174	.1656					
16	.1174	.1656					
17	.0734	.1806					
18	.0734	.1505					
19	.0147	.0301	.0301		.0301		
20			.0301			.0187	.0149
21			.0301			.0149	.0149
22	.0147			.0301		.0149	.0149
23		.0301	.0301	.0301		.0149	.0149
24	.0147	.0147		.0301	.0373	.6602	.0149
Max	.1174	.1867	.0301	.1204	.1054	.6602	.1486
Min	.0147	.0093	.0301	.0301	.0301	.0149	.0149
Avg	.0612	.1120	.0301	.0686	.0696	.0864	.0753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 202 / SHIVOOR

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867			.1848	.3696	.3734	.3734
2	.1867			.1848	.3696	.3734	.3734
3	.1867			.2218	.3696	.4108	.3734
4	.1867			.2402	.3881	.4294	.3734
5	.1867			.2772	.4066	.4294	.3734
6				.2772	.462	.4668	.4668
7				.3326	.6099	.5228	.4668
8					.7023	.5601	.5041
9				.3696	.7392	.5601	.5041
10				.462	.7762	.4668	.5601
11		.1848					
12	.1867	.2772					
13	.2801	.3696					
14	.2801	.3696					
15	.2801	.3881					
16	.2801	.3881					
17	.2801	.4066					
18	.1867	.4066					
19	.1867	.2772	.037		.462		
20	.1867	.2772	.2402			.2801	.2801
21	.1867	.2772	.2402	.3326		.2801	.2801
22	.1867	.2772	.2402	.3511		.2801	.2801
23		.2957	.2402	.3511		.2801	.3734
24	.1867	.1867		.2402	.3511	.3734	.3174
Max	.2801	.4066	.2402	.462	.7762	.5601	.5601
Min	.1867	.1848	.037	.1848	.3511	.2801	.2801
Avg	.2142	.3130	.1996	.2942	.5005	.4058	.3933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174060 / TALNI

Feeder No / Name : 203 / TALNI GAONTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468			.8402	.8402	.8402	.7468
2	.7468			.3547	.8402	.8402	.7468
3	.7468			.3734	.8962	.8962	.7468
4	.7468			1.0082	1.0829	1.0269	.8775
5	.9335			1.1763	1.2136	1.1203	1.0269
6	1.307			1.531	1.363	1.2136	1.4937
7	1.587			1.4003	1.3256	1.307	1.531
8	1.4937			1.2136	1.307	1.307	1.307
9	1.4937			1.0829	.8962	1.307	1.0269
10	.9335			.5601	.6535	1.1203	.6535
11				.4668	.5601	.8029	.4668
12	.3734			.3734	.3921	.7842	.4668
13	.3734			.3361	.3734	.7468	.4668
14	.3734				.4108	.7468	
15	.5601					.7468	.4668
16	.3734			.4294	.5228	.7468	.4668
17	.7468		.4668			.7468	.8402
18	.9335		.5601			.9335	1.2136
19	1.307		1.3443		1.3443	1.0269	1.2136
20	1.307	1.0456	1.0269			.8962	1.2136
21	1.1203	.9335	.9709			.8402	1.0642
22	.9335	.8962	.8962	.8962		.7468	.7468
23		.8402	.8402	.8402		.7468	.7468
24	.9335	.7468	.8402	.8402	.8402	.8402	.7468
Max	1.587	1.0456	1.3443	1.531	1.363	1.307	1.531
Min	.3734	.7468	.4668	.3361	.3734	.7468	.4668
Avg	.9123	.8925	.8682	.8072	.8742	.9304	.8816

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 201 / Lyhari

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.4409	.4607	.5144	.6443	.7642	.4453
2	.5093	.4409	.4607	.5087	.6104	.7633	.4742
3		.4409	.4607	.5426	.6274	.7938	.5047
4		.4409	.4733	.5426	.6274	.8202	.5707
5			.4733	.5895	.6443	.8858	.614
6			.5258	.6783		1.0147	.6552
7			.6613	.9389		1.1429	.8961
8			.8383	.9614		1.2026	1.1232
9	.3981			.9602		1.2691	1.1934
10				.7377		1.1296	1.065
11	.5604		.2263	.3772	.3206	.2638	.3018
12	.4588		.2263	.2452	.3018	.3042	.2641
13	.4915		.2241	.3018	.2641	.3965	.2641
14	.6554		.2801	.3395	.3018	.3965	.3361
15	.5898	.7682	.2987	.3206	.3018	.3973	.3547
16	.5571	.7773	.3174	.2987	.3395	.4364	.3174
17	.6554	.5571	.3772	.2241	.3772	.3791	.3921
18	.5571	.663	.415	.2829	.3772	.3973	.3361
19	.6036	.4854	.4527	.5281	.4904	.4919	.4668
20	.6036	.4294	.5281	.547	.4904	.5287	.5281
21	.5658	.5281	.5601	.5658	.4904	.5281	.5415
22	.5281	.547	.5601	.547	.4904	.5287	.5415
23	.4904	.5228	.5415	.547	.4904	.5087	.5415
24	.5098	.4409	.4904	.5041	.5281	.4909	.5098
Max	.6554	.7773	.8383	.9614	.6443	1.2691	1.1934
Min	.3981	.4294	.2241	.2241	.2641	.2638	.2641
Avg	.5437	.5345	.4478	.5251	.4588	.6598	.5516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 202 / HARDAP

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.3052	.4481	.439	.462	.4527	.429
2	.2949	.3052	.4481	.4481	.462	.454	.4277
3		.3052	.4481	.4481	.4481	.4536	.4458
4		.3052	.4668	.4481	.4668	.4522	.4467
5			.5228	.4805	.499	.4899	.482
6			.5658	.5228		.5281	.0378
7			.5975	.5601		.5664	.6218
8			.3584	.5228		.4904	.5087
9	.447			.2743		.378	.4518
10	.4294			.2033		.3027	.2987
11	.2274		.6097	.6636	.759	.8373	.7099
12	.1696	.2507	.7316	.703	.9374	.9143	.9259
13	.1696	.2303	.7316	.8592	.9686	.8431	.8383
14	.1696	.2353	.7621	.8749	.9998	.7159	.884
15	.2035	.2587	.7011	.7811	1.0155	.8253	.7225
16	.2374	.2534	.6249	.8124	1.0155	.6379	.7011
17	.2035	.2686	.6327	.8951	1.0311	.6333	.7621
18	.2713	.3475	.7099	.7253	1.0623	.628	.7773
19	.2713	.4251	.4251	.4251	.3749	.3685	.4207
20	.2713	.4668	.4435	.462	.3749	.444	.4668
21	.2713	.4805	.499	.5175	.3749	.4463	.4854
22	.3391	.4805	.4755	.5041		.4303	.4854
23	.373	.462	.4805	.499		.4522	.4854
24	.4422	.407	.4435	.4572	.4805	.4531	.4264
Max	.447	.4805	.7621	.8951	1.0623	.9143	.9259
Min	.1696	.2303	.3584	.2033	.3749	.3027	.0378
Avg	.2816	.3404	.5512	.5636	.6901	.5499	.5517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174091 / LYHARI

Feeder No / Name : 203 / PINGALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2655	.2652	.5138	.4973	.5304	.5156	.5001
2	.2489	.2652	.4973	.4973	.5304	.5144	.4995
3	.2655	.2652	.4807	.4973	.547	.5138	.4995
4	.2489	.2984	.4973	.4973	.547	.5138	.499
5	.2655		.5138	.547	.547	.4807	.4829
6	.299		.5801	.5304	.547	.4646	.4673
7	.4319		.4973	.5138	.4807	.4319	.4673
8	.4486		.4475	.431	.3978	.3992	.4172
9	.3821			.3812	.2818	.3817	.3839
10	.4315				.2652		.2652
11	.2157		.3315	.3481	.4973	.4668	.5636
12	.2321	.1989	.3978	.4807		.6335	.5967
13	.2155	.1989	.3978	.5304		.6168	.5138
14	.1989	.1989	.3978	.547		.5001	.6299
15	.1989	.2486	.3315	.4973		.5162	.4475
16	.2155	.2321	.2984	.5801	.6638	.4662	.5138
17	.2486	.2486	.3315	.5967	.7152	.4995	.547
18			.3315	.6796	.751	.2331	.5967
19	.4973	.4475	.431	.3978	.5138	.3497	.3812
20	.5304	.5138	.4807	.547	.5138	.5162	.5304
21	.5636	.5304	.5304	.5801	.5144	.5162	.5304
22	.4755	.5304	.5304	.5636	.5144	.5162	.5304
23	.5304	.5304	.5304	.5636	.5138	.5162	.5304
24	.531	.5138	.5138	.5138	.547	.515	.4995
Max	.5636	.5304	.5801	.6796	.751	.6335	.6299
Min	.1989	.1989	.2984	.3481	.2652	.2331	.2652
Avg	.3453	.3429	.4483	.5138	.5209	.4816	.4956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 201 / JAWALGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429		
2		.3734		
3		.362		
4		.3582		
5		.3734		
6		.3506		
7		.5601		
11	.1017			
12	.104			
13	.1029		.2572	
14	.1017		.2303	1.7147
15	.1006		.2543	1.7147
16	.1029		.2572	1.5432
17	.1086			1.7147
18				1.7147
19	.6001			1.7147
20	.4477			1.7147
21	.4382			1.7147
22	.362			1.5432
23	.3658			1.7147
24		.3658		
Max	.6001	.5601	.2572	1.7147
Min	.1006	.3429	.2303	1.5432
Avg	.2447	.3858	.2498	1.6804



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 202 / VIRSANI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3544	.3734	.3174	.4525		.362
2	.2743	.3467	.3734	.3174	.4525		.362
3	.2743	.362	.4481	.3361	.4525		.3258
4	.3429	.362	.3921	.3547	.4525		.3258
5	.4287	.4525	.4108	.3547	.4525		.4344
6	.5487	.5601	.4108	.3734	.5144		.5258
7	.6001	.5601	.3361	.3361	.5144		.5609
8	.5144		.3174	.4108	.5144		.5144
9	.4287			.3734	.5144		.5014
10	.2804		.3361		.4287		.5258
11	.362			.2058	.2572		
12	.3814			.2172	.2743	.2896	
13	.4108		.1867	.2195	.2572	.2629	.2715
14	.4024		.1867	.2686	.2401	.2172	.2572
15	.394		.1867	.2743		.2715	.2743
16	.3856		.2054	.2743	.2743	.362	.2715
17	.394			.2686	.3258		
18			.4294	.3429	.3429		
19	.4572	.5228	.4481	.5144	.5144		
20	.4668	.5415	.4668	.543	.5144	.4024	.4668
21	.462	.4481	.4481	.543	.4525	.4024	.462
22	.4668	.4481	.4481	.543	.4115	.4024	.4715
23	.3734	.4294	.4481	.4572	.3982	.3982	.3696
24	.3086	.4294	.4481		.4525		.3982
Max	.6001	.5601	.4668	.543	.5144	.4024	.5609
Min	.2743	.3467	.1867	.2058	.2401	.2172	.2572
Avg	.4029	.4475	.3650	.3566	.4115	.3343	.4043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174093 / JAWALGAON

Feeder No / Name : 203 / KAMARI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.9431	.8962	.8962	.905		.7602
2	.5144	.9335	.8775	.8775	.9335		.724
3	.6001	.9335	.8775	.8775	.905		.724
4	.6001	.905	.9335	.8962	.905		.7602
5	.6859	.9335	.9709	.9522	.905		.8145
6	.6859	.9431	.9896	1.0829	.8573		.8145
7	.6859	.9431	1.0082	1.0829	.8573		.905
8	.6001		.8962	1.0082	.8573		.8954
9	.5144		.4108	.7468	.7716		.7888
10	.5144		.6535				
11	.5487		.6348	.6535	1.0288		
12	.4668			.7392	1.1145	.5792	.7545
13	.4287		.7095	.9431	1.0288	.6335	.7392
14	.4287	.4668	.7468	.8573	1.0631	.6335	.7468
15	.443		.7468	.8859		.5792	.7468
16	.4287		.7468	.9335	1.0288	.5792	.6535
17	.4239			.8573	.8573		
18		.8029	.7095	.8573	.8573		
19	.9145		.9709	.8573	.8573		
20	.9431		.9709	.905	.8573	.8871	.9431
21	.9335	.9335	.9522	.905	.823	.7316	.9335
22	.9431	.9335	.9335	.905	.823	.823	.9431
23	.9431	.9335	.9335	.905		.8145	.9335
24	.6859	.9335	.9149		.905		.8145
Max	.9431	.9431	1.0082	1.0829	1.1145	.8871	.9431
Min	.4239	.4668	.4108	.6535	.7716	.5792	.6535
Avg	.6281	.8876	.8402	.8920	.9115	.6956	.8103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 202 / KEDARGUDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5335	.5068		.5093	.4715
2			.5335	.5068	.5335	.5093	.4715
3			.5335	.5068	.5144	.5093	.5093
4			.5335	.5068	.5144	.5281	.4904
5			.5335	.5175	.4954	.5281	.547
6	.3109		.5525	.5359	.5144	.547	
7		.4287	.4382	.462	.4382	.4527	.3772
8			.3018	.4435		.4191	.3772
9	.3149		.3206	.3018		.381	.3018
10	.2683	.3239	.1781		.2096	.3018	.2829
11	.1524	.1905	.2753	.2683	.3725		.2915
12		.1715	.2591	.2915	.4096		.3277
13	.1905	.1715	.2915	.3077	.2622	.3772	.2818
14	.1886	.1886	.2818	.3077	.4049	.3206	.2622
15	.1905	.1905	.2652	.3239	.4049	.2949	.2321
16	.1886		.2321	.3113	.4049	.2949	.2984
17	.2263	.2096	.2652	.2881	.4144	.3315	.3239
18	.2477	.2667	.2652	.426	.5093	.3113	.3506
19	.4382	.2667	.4557	.4572	.5093	.3768	.4207
20	.5658	.5281	.4908	.5847	.547		.5304
21	.5658	.5525	.4908	.5716	.5658		.547
22	.4715	.547	.5083	.5906	.5658		.547
23	.5658	.547	.5083	.5525	.547	.5281	.5281
24		.5658	.5335	.5068	.5716	.5281	
Max	.5658	.5658	.5525	.5906	.5716	.547	.547
Min	.1524	.1715	.1781	.2683	.2096	.2949	.2321
Avg	.3257	.3432	.3992	.4381	.4623	.4236	.3986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174094 / MANATHA

Feeder No / Name : 203 / MALZARA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987		.811	.7762		.7167	.7922
2	.3326		.811	.7762	.811	.7545	.7922
3	.3696		.811	.7762	.7922	.7545	.7922
4	.4024		.811	.7762	.7733	.7922	.8299
5	.4525		.8676	.9808	.8865	.8299	.9054
6	.5544		1.0185	1.0185	1.0562	1.0374	.5093
7	.567	.4755	.9431	.9808	1.0185	1.094	.9431
8	.5258		.8676	.8589		.9054	.9431
9	.463		.6036	.6602			.7545
10	.4115		.3647		.5281		.6036
11	.381	.3772	.3315	.5087	.4748	.4915	.4372
12	.381	.3772	.3315	.5407	.6154	.4973	.5967
13	.381	.3772	.3315	.5243	.426	.6036	.4641
14	.4001	.415	.4458	.5138	.4858	.5093	.421
15	.4001	.415	.4287	.4973	.4858	.3315	.4049
16	.4527		.3429	.4807	.4915	.2818	.3932
17	.4715	.5658	.3429	.3563	.3277	.2949	.4588
18	.5847	.6036	.3856	.5243	.547	.3239	.4287
19	.9431	.7922	.7762	.6036	.9431	.4338	.7545
20	.9145	.8488	.8501	.9619	.9526		.9054
21	.9242	.8488	.7762	.8676	.9054		.8488
22	.8488	.8488	.7762	.8488	.7545		.8488
23	.5658	.811	.7762	.8299	.679	.7922	.8488
24	.7733	.7922	.811	.7762	.7922	.7167	.7922
Max	.9431	.8488	1.0185	1.0185	1.0562	1.094	.9431
Min	.2987	.3772	.3315	.3563	.3277	.2818	.3932
Avg	.5333	.6106	.6506	.7147	.7022	.6401	.6862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 201 / LOHA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2743	.2789	.3696		.2772
2			.2743	.2783	.3734	.2772	.2772
3			.2772	.3643	.3734		.2772
4			.2772	.3685	.3734	.3696	.2772
5			.2743	.3711	.3734		
6			.2772	.4596	.5601	.5544	.3696
7			.2743	.4453	.5601	.6401	
8	.2815		.2772	.4649		.7316	.5544
9	.2815			.5578			.6468
10	.1848			.5487			
11	.2743			.1848			
12	.4572			.1848	.1829		.1848
13	.4525			.1829	.181		.1867
14				.1848		.1848	.1848
15				.1848			
16	.4572		.185	.1848	.181	.2772	.1848
17			.1856	.1848		.2772	.1848
18	.3696		.1825	.1848		.2772	.1848
19			.2701	.2772		.2772	
20	.2801		.2815	.3696	.2772	.2772	.3696
21		.3658	.2815	.3696		.3696	.3696
22		.2772	.2749	.3696		.3696	.3696
23		.2772	.2795	.2772		.3696	.3696
24		.2801	.2772	.2698	.2772	.2801	.3696
Max	.4572	.3658	.2815	.5578	.5601	.7316	.6468
Min	.1848	.2772	.1825	.1829	.181	.1848	.1848
Avg	.3376	.3001	.2602	.3145	.3402	.3688	.3132

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 202 / CHIKALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.924	.9307	.9335		.924
2			.9145	.9278	.9335	.924	.924
3			.924	.9174	.9335		.924
4			.924	.8907	.9335	.924	.924
5			.924	.925	.924		.924
6			.924	.8993	.7468	.924	.7392
7			.924	.9316	.7468	.924	.7392
8	1.126		.7392	.6495	.7392	.8145	.7392
9	1.126		.7301				.6468
10	.924		.3677	.5544			
11			.7301	.7392	1.0059		
12	.3658		.925	.924			.924
13	.362		.9193	1.1088	1.3575	.924	.924
14			.9383	1.0974		.924	.924
15				1.1088			
16	.3658		.9193	1.1088	1.267		.7392
17			.9193	.6468		.7392	.924
18	.6468			1.1088		.7392	1.1088
19			.7301	.7392		.7392	
20	1.0269		.8453	1.0164	1.0164	.924	.924
21		.924	.9278	1.0164		.924	.924
22		.924	.925	1.0164		.924	.924
23		.924	.9316	.924		.924	.924
24		.9335	.924	.9278	.924	.9335	.924
Max	1.126	.9335	.9383	1.1088	1.3575	.9335	1.1088
Min	.362	.924	.3677	.5544	.7392	.7392	.6468
Avg	.7429	.9264	.8605	.9178	.9586	.8804	.8824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174107 / LOHA

Feeder No / Name : 203 / WANWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.924	.5476	.7468		.924
2			.924	.5533	.7468	.3696	.924
3			.924	.559	.7468		.924
4			.924	.555	.7468	.462	.924
5			.924	.555	.7468		.924
6			.924	.7423	1.1203	1.1088	.924
7			.924	.5378	1.1203	1.2936	.924
8	.3677		.924	.9297	1.2136	1.1765	1.1088
9	.3753		.9126	.9316			1.1088
10	.1848		.9193	.924			
11			.3688	.1848	.1829		
12	.9145		.3563	.1848	.1829		.1867
13	.905		.3749	.1848	.181	.2772	.1848
14			.3711	.1848		.2772	
15				.1867			
16	.9145		.3727	.1848	.2715	.2772	.2772
17			.365	.2772		.2772	.2772
18	.7392		.3753	.3696		.3734	.3696
19			.4563	.5544		.5544	
20	.6535		.5356	.7468	.7392	.6535	.6468
21		.6468	.6455	.7468		.6535	.6468
22		.6468	.5516	.7468		.6468	.6535
23		.6468	.5567	.6468		.6468	.5544
24		.6535	.6468	.5533	.6535	.6535	.6468
Max	.9145	.6535	.924	.9316	1.2136	1.2936	1.1088
Min	.1848	.6468	.3563	.1848	.181	.2772	.1848
Avg	.6318	.6485	.6609	.5245	.6714	.6063	.6910

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 201 / KOLI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435		.4435	.4435		.4481	.4435
2	.4435		.4435	.4435		.4481	.462
3	.462		.4435	.4435		.4668	.462
4	.4805		.5359	.4805		.4854	.462
5	.5544		.5914	.5914		.5975	.5544
6	.7947		.8131	.7023		.7655	.6468
7	.7762		.8316	.7392		.8029	.7023
8	.6283		.6653	.7023		.7095	.6283
9	.4854		.499	.4854			.6283
10	.2614		.2957	.3734	.2801		
11	.2427		.2587	.2427	.2614		
12	.2614		.1848	.1867	.3174		
13	.2801		.2402	.2241	.2801		
14	.2987		.2587	.2801	.3174	.5729	
15	.3547		.2957	.2801	.2987	.6099	
16	.3921		.3696	.3174		.4805	
17	.4294		.4435	.3921		.5359	
18	.5601	.5359	.5175	.5228		.5729	
19	.6722	.6468	.6653	.6161		.4805	
20	.6535	.5914	.5914	.5788		.462	.5544
21	.5041	.5359	.499	.4854		.4805	.4805
22	.4854	.5359	.462	.4668	.4854	.462	.4435
23	.4668	.4435	.4435	.4668	.4668	.4251	.4435
24	.4435	.4481	.4435	.4435	.4481	.4481	.4435
Max	.7947	.6468	.8316	.7392	.4854	.8029	.7023
Min	.2427	.4435	.1848	.1867	.2614	.4251	.4435
Avg	.4739	.5339	.4682	.4545	.3506	.5397	.5254



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 202 / KOLI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0753			
2	.0903			
3	.0903			
4	.0903			
5	.0903			
6	.1505			
7	.2258			
8	.2559			
9	.2743			
10	.2439			
11		.3462	.3963	.442
12		.3462	.5335	.5639
13		.3913	.5335	.6249
14		.3311	.503	.6249
15		.4251	.381	.6249
16		.3462	.3963	
17		.301	.3048	
18		.1505		
Max	.2743	.4251	.5335	.6249
Min	.0753	.1505	.3048	.442
Avg	.1587	.3297	.4355	.5761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HADGAON (R) S/DN[456] BU 7439

Substation No/ Name :- 174119 / KOLI

Feeder No / Name : 203 / BHATEGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152		.1067	.061		.1067	.1067
2	.0152		.1067	.061		.1067	.1067
3	.0152		.1067	.061		.1067	.1067
4	.0152		.1067	.061		.1067	.1219
5	.0152		.1067	.061		.1372	.1677
6	.0305		.1219	.0914		.1677	.1067
7	.0305		.1219	.1219		.2286	.1524
8	.0305		.1372	.1981		.2591	.1524
9	.0152		.1677	.1981			.1677
10	.0305		.1677	.1829	.3048		
11	.061		.1524				
12	.1524						
13	.1219						
14	.1372						
15	.1372						
16	.1372						
17	.1524						
18	.1524	.1372					
19	.0305	.1372				.0914	
20	.0152	.1067	.0762	.0914		.1219	
21	.0152	.1067	.0762	.0914		.1219	
22	.0152	.1067	.061	.0914	.1067	.1294	
23	.0152	.1067	.061	.1067	.1067	.0924	
24	.0152	.0152	.1067	.061	.1067	.1067	.0914
Max	.1524	.1372	.1677	.1981	.3048	.2591	.1677
Min	.0152	.0152	.061	.061	.1067	.0914	.0914
Avg	.0571	.1023	.1115	.1026	.1562	.1345	.1280

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 201 / HIMAYATNAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.961	1.0631	.9568	.924		1.0608	.8962
2	.9709	1.0692	.9877	.8871		1.0608	.8962
3	.9335	1.0056	.9877	.8962		1.0608	.8962
4	.924	1.0517	.9877	.8962		1.0631	.9335
5	.9335	1.0341	.9877	.924		1.0974	.924
6		1.0166	1.0829	.9709		1.0974	1.0719
7		1.0099	1.1458	1.0269		1.1888	1.1088
8		1.0867	1.1088	1.0829		1.1576	1.1576
9	.9816	1.0974	1.0608	1.0517		1.1088	1.1088
10	.9882	1.134	1.0349	1.0517	.9835	1.1576	1.0719
11		1.0631	.9877	1.0985	1.0974		1.0867
12	1.0166	1.0242	.9877	1.0517	1.0974		1.1043
13	.9991	1.0059	.8779	1.0166	1.0242		1.1218
14	1.0277	1.0242	.8871	1.0631	1.0242		1.0517
15	.9816	.9922	.8779	1.0692	.9877		1.0692
16	.9465	1.0059	.8326	1.0341	.9877	.9145	1.0166
17	.9391	1.0059	.924	1.0341	1.0974	.961	.9816
18	1.0166	1.0277	1.0059	1.0631	1.0631	.961	.4401
19	1.1218	1.0974	1.1458	1.0692	1.1694	.9877	1.0867
20	1.1218	1.0242	1.134	1.1517	1.1888	1.0829	1.0631
21	1.0631	1.0242	1.0974		1.1706	1.1203	1.0631
22	1.0517	1.0242	1.0719	1.0985	1.1706	1.0456	1.0517
23	1.0808	.9877	.9979		1.0974	.9979	1.0166
24	.961	1.0166	.9877	.9709		1.0974	.9335
Max	1.1218	1.134	1.1458	1.1517	1.1888	1.1888	1.1576
Min	.924	.9877	.8326	.8871	.9835	.9145	.4401
Avg	1.0010	1.0372	1.0065	1.0197	1.0828	1.0643	1.0063

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174019 / HIMAYATNAGAR

Feeder No / Name : 204 / KHADKI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2591	.2785	.4572	.0191		.4961	.0754
2	.2462	.2561	.443	.0168		.5121	.0796
3	.2743	.2622	.4572	.0274		.4961	.0869
4	.2743	.2785	.4572	.0229		.5487	.1067
5	.2743	.2949	.4572	.0286		.5487	.1014
6		.3113	.4572	.0286		.5316	.1097
7		.2622	.3475	.0324		.6401	.1166
8		.2458	.6036	.0333		.1677	.0823
9	.2721	.5304	.0267	.5959		.2058	.0907
10	.2622	.2926	.0333	.5144	.6584		.0907
11	.5144	.4572	.096	.1475	.3658		.16
12	.4908	.5487	.1067	.144	.2926		.1802
13	.5609	.6401		.136	.2743		.184
14	.5258	.6401	.16	.1311	.2658		.1638
15	.5258	.5853	.1448	.136	.3658		.168
16	.5493	.5853	.1593	.1638	.3658		.152
17	.5258	.5487	.1448	.1557	.3277		.16
18	.5609	.5121	.1555	.176	.4024		.176
19	.2801	.4572	.1738	.1802	.5316		.213
20	.3031	.5853	.1882	.3041	.5853	.2172	.2949
21	.3113	.5853	.2267		.5487	.2601	.3041
22	.2949	.5853	.2534	.3031	.5487	.2534	.2881
23	.2867	.5853	.2332		.5487	.2462	.2867
24	.2591	.2721	.5853	.2462		.5487	.2462
Max	.5609	.6401	.6036	.5959	.6584	.6401	.3041
Min	.2462	.2458	.0267	.0168	.2658	.1677	.0754
Avg	.3739	.4417	.2769	.1611	.4344	.4052	.1632

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174027 / ISLAPUR

Feeder No / Name : 201 / KOSMETH

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5735	.6859	.5316	.6859	.7087	
9					.5801	.6392
12	.5144					
13				.5505	.503	.9164
14					.4973	
15				.6193		
18	.5144					
20				.757	.6554	.7796
21	.6859					
22				.7087		
Max	.6859	.6859	.5316	.757	.7087	.9164
Min	.5144	.6859	.5316	.5505	.4973	.6392
Avg	.5721	.6859	.5316	.6643	.5889	.7784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 201 / JALDHARA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0347				.0389	.0124
2		.0347				.0394	.0124
3		.0347	.0118			.0406	.0124
4		.052	.0124				.0124
5		.052	.0124			.0389	.0143
6	.0278	.052	.013		.0173	.0389	.0152
7	.052	.052	.0488		.0173	.0777	
8	.052	.052	.0524		.0693	.1315	
9	.052		.0648			.1555	
10	.052					.1578	
16							.0693
18							.0693
21				.0173	.0301	.0324	.0173
22				.0173	.0335	.0301	.0173
23					.0335	.0309	
24	.0139	.0347				.0335	.0305
Max	.052	.052	.0648	.0173	.0693	.1578	.0693
Min	.0139	.0347	.0118	.0173	.0173	.0301	.0124
Avg	.0416	.0443	.0308	.0173	.0335	.0651	.0257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174044 / JALDHARA

Feeder No / Name : 202 / NANDGAON

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5201	.6036			.4904	.5658
2		.5201	.6036			.4904	
3		.5201	.6413			.4854	
4		.5201	.6413			.5041	.5658
5		.5201	.6413			.5228	.5847
6	.5975	.5201	.6348		.5201	.547	.5847
8						.5415	
11	.2427		.5975		.2743	.2926	
12	.2774				.2926	.3475	
13	.2774		.2241	.2427	.2896	.3658	
14	.2774						
15	.2774				.2926	.3547	
16	.3121		.2835	.2774	.3258	.3734	.3121
17	.3467			.3121	.3658	.3734	
18	.4161		.2835	.3121	.4024		.4508
19	.4508				.4481		
20	.4854			.5201	.5658	.5847	
21	.5201	.415		.5201	.5788	.6036	.5201
22		.6413		.5201	.5093	.6036	.5201
23		.6036			.4904	.5847	
24	.5975	.5201	.6036			.4904	.5847
Max	.5975	.6413	.6413	.5201	.5788	.6036	.5847
Min	.2427	.415	.2241	.2427	.2743	.2926	.3121
Avg	.3907	.5301	.5235	.3864	.4120	.4753	.5210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 201 / SARSAM

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9214	.8573	.9214	.8573	.9214	.8573
2	.8573	.8859	.3772	.4252	.4287	.4607	.4287
3	.8573	.8859	.4287	.4252	.4801	.4961	.583
4	.8916	.8859	.463	.4607	.5144	.5316	.583
5	.9431	.9568	.4801	.5316	.583	.6379	.6001
6	1.046	1.0277	.5487	.6733	.7545	.7442	.6859
7	.8573	.9214	.583	.815	.7716	1.0631	.8573
8	.8059	.815	.6859	.8505	.7545	1.0985	.9259
9	.6379		.6379	.7716		.9945	.9214
10	.4252					.583	
11	.4961		.443		.4961		
12			.3898	.4115			
13	.5316			.4115			.567
14						.5658	.567
15	.5316				.4252	.5144	
16	.6024		.567	.4801	.567	.5487	
17	.6024			.5487		.6516	.6733
18	.7087		.6733	.6516		.6859	
19	.9568	.8916	.9214	.8573			
20	1.0631	.8916	.9922	1.046	1.0277	.8916	.9036
21	1.0808	.9602	.9922	1.0288		.9945	.9391
22	1.0454	.9774	1.0277	.9945		.9602	
23		.9431		.9431		.9431	
24	.9431		.8916		.8916		.9088
Max	1.0808	1.0277	1.0277	1.046	1.0277	1.0985	.9391
Min	.4252	.815	.3772	.4115	.4252	.4607	.4287
Avg	.7988	.9203	.6644	.6972	.6578	.7519	.7334



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 202 / TEMBHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.1417	.1372	.124	.12	.1417	.1372
2	.0686	.0709	.1372	.124	.12	.124	.12
3	.1029	.0709	.12	.124	.12	.124	.12
4	.1029	.0709	.12	.124	.1372	.124	.12
5	.0857	.0886	.1372	.124	.1372	.1417	.1372
6	.0857	.0886	.1372	.1417	.1372	.1595	.1372
7	.1372	.1417	.12	.1063	.1029	.1417	.1029
8	.1886	.1772	.1029	.1063	.1029	.124	.1029
9	.1063		.0886	.1029		.12	.1063
10	.1417					.1543	
11	.124		.1595		.1417		
12	.0709		.1417	.12			
13	.0709			.0857			
14	.0532		.1417			.1543	
15	.0532				.124	.1543	
16	.0709		.1595	.12	.124	.1372	.1417
17						.1372	.1595
18	.0886		.1063	.0857		.0857	
19	.124	.12	.124	.12			
20	.1417	.12	.1417	.1372	.1417	.1372	.1417
21	.1417	.1372	.1417	.1372		.1372	.1417
22	.1417	.1372	.1417	.1372	.1595	.1372	
23		.1372		.1372		.1372	
24	.1372		.1372		.1372		.1372
Max	.1886	.1772	.1595	.1417	.1595	.1595	.1595
Min	.0532	.0709	.0886	.0857	.1029	.0857	.1029
Avg	.1072	.1155	.1313	.1199	.1290	.1354	.1290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174061 / SARSAM

Feeder No / Name : 203 / TAKARALA (OLD POTA)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.8859	.8059	.8859	.8916	.9214	.8573
2	.8573	.8859	.3772	.3898	.4287	.4607	.3772
3	.9431	.8859	.4287	.4252	.4287	.4607	.4287
4	1.0631	.9568	.4287	.4252	.4801	.5316	.4458
5	1.1145	1.0631	.4801	.5316	.5144	.7087	.463
6	1.2003	1.2403	.5487	.6201	.823	.8859	.6687
7	1.286	1.2226	.6344	.6379	1.0974	.9745	.9774
8	.823	.9568	.6001	.7973	1.1831	1.3289	.9431
9			.6024	.7716		.8916	.9745
10						.7373	
11	.5493		.3366				
12	.443			.4458			
13	.6024			.4801			
14	.6201					.6516	.5493
15	.6556				.4961	.703	
16	.6201		.567	.5487	.5493	.7373	.6024
17					.6733		
18	.6201		.815	.6516		.6859	
19	.8859	.8745	.9036	.9259			
20	.9922	.7545	.9745	1.046	1.0808	.9431	1.0277
21	.9922	.9088	.9568	1.046	1.134	.9602	1.0277
22	.9745	.823	.9745	.9945	1.0631		
23		.8402		.9431		.9259	
24	.9088		.8059		.9088		.8916
Max	1.286	1.2403	.9745	1.046	1.1831	1.3289	1.0277
Min	.443	.7545	.3366	.3898	.4287	.4607	.3772
Avg	.8522	.9460	.6612	.6981	.7835	.7946	.7310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 201 / KANCHALI

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13		.0429		.0714	.1858
14		.0572			.1957
15		.0572			
16		.0286	.0793		
17	.1475	.0286			.0937
18	.1147	.0286	.1058		.1562
19	.1492	.0286	.0529		.128
20	.0648	.0286	.0529		.1296
21	.0648	.0143			.1265
22	.0655	.0143	.0529		.125
Max	.1492	.0572	.1058	.0714	.1957
Min	.0648	.0143	.0529	.0714	.0937
Avg	.1011	.0329	.0688	.0714	.1426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174095 / Shiwani

Feeder No / Name : 202 / SHIWANI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1974		.2622	.2286	.2256	.2949
2	.1974		.2591	.2286	.2256	.2915
3	.1974		.2713	.2286	.2256	.3018
4	.2256		.253	.2143	.2256	.2743
5	.2256		.2652	.2429	.2256	.3018
6	.2256		.2949	.2429		.3605
11	.2294		.2143		.2143	.3125
12	.2267			.1692	.2143	.2429
13	.2035		.1429	.1692	.1715	.2372
14	.1966		.1429			.2343
15	.1989					.1875
16	.16		.1715	.1692		.2105
17	.1696	.2294	.1715	.141		.2031
18		.2429	.1715	.1974		.2105
19		.2713	.2286	.1894		.2949
20		.2753	.1715	.2256		.2949
21		.2785	.2286			.3052
22		.2785	.2286	.2538		.2949
23		.2622	.2286	.2538		.2915
24	.2256		.2591	.2286	.2256	.2984
Max	.2294	.2785	.2949	.2538	.2256	.3605
Min	.16	.2294	.1429	.141	.1715	.1875
Avg	.2057	.2626	.2203	.2114	.2171	.2722

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 201 / Andegaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5601	.3361	.5609		.5609	.4904
2	.5975	.5601	.3292	.4908		.4908	
3	.5975	.5544	.3224	.4801		.4458	
4	.5914	.5544	.3155	.4908		.4115	
5	.5914		.3086	.4287		.5258	
6	.6161		.285	.3086		.5959	
7	.4755		.3185	.2713	.218	.6805	
8	.362		.3932	.4481	.192	.503	.5506
9			.3887	.4115	.218		.6173
10				.2328	.2454		
11				.2103	.2279		
12			.1526	.2229	.2058		.1867
13			.1865	.2401	.2401		.2534
14			.1886	.1943	.2012		.2353
15			.2035	.2401	.218		.2149
16	.442		.2254	.2804	.2804	.3189	.2507
17			.3155	.3224	.3224		.2865
18			.3921	.6348	.5975		.3206
19			.6413	.5975	.6348		.5658
20			.6413	.5658	.6036		.6979
21			.6413	.6036	.5658		.6979
22			.6036	.6036	.6036		.679
23			.6036	.6413	.6036		.6413
24	.6036	.5601	.3361	.6036		.5658	.5658
Max	.6161	.5601	.6413	.6413	.6348	.6805	.6979
Min	.362	.5544	.1526	.1943	.192	.3189	.1867
Avg	.5475	.5578	.3695	.4202	.3634	.5099	.4534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

HIMAYATNAGAR S/DN[750] BU 4750

Substation No/ Name :- 174112 / Andegaon

Feeder No / Name : 202 / TEMBHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1307	.0747	.1227		.1227	.0754
2	.1307	.1307		.1227		.1227	
3	.1307	.1478	.0716	.12		.1307	
4	.1294		.0701	.1227		.12	
5	.1109		.0686	.12		.1227	
6	.0934		.0503	.12		.1227	
7	.0732		.1174	.1187	.1341	.1254	
8	.0905	.2374	.0492	.096	.144	.1006	.0324
9			.0648	.1372	.1677		.0343
10			.0781	.1612	.1578		
11			.1265	.1753	.1753		
12			.1357	.1543	.1543		.1494
13			.1696	.1715	.1886		.1629
14			.1886	.2347	.1677		.181
15			.1526		.1509		.197
16	.061		.156		.1402	.2303	.2149
17			.1402		.1254		.2507
18			.112		.1307		.0943
19			.1509		.112		.1132
20			.1509		.1132		.1509
21			.1509		.132		.1509
22			.132		.1509		.1509
23			.132		.132		.1509
24	.132	.1307	.0747	.132		.1509	.1132
Max	.132	.2374	.1886	.2347	.1886	.2303	.2507
Min	.061	.1307	.0492	.096	.112	.1006	.0324
Avg	.1083	.1555	.1138	.1406	.1457	.1349	.1389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 201 / 11 KV MANDVI

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	28-JUL-17
HR	Load (MW)
9	.2454
13	.4161
Max	.4161
Min	.2454
Avg	.3308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 202 / 11 KV PALSHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	28-JUL-17
HR	Load (MW)
9	.7522
13	.2401
Max	.7522
Min	.2401
Avg	.4962



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174020 / 33 KV MANDVI

Feeder No / Name : 203 / 11 KV UMRI

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	28-JUL-17
HR	Load (MW)
9	.1387
13	.3155
Max	.3155
Min	.1387
Avg	.2271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 201 / 11KV WAI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2772	.1848			.1848	.2715
4	.2715	.2772	.1848			.1848	.2715
8			.1829			.1829	.2126
12	.1829			.1753			.1753
16	.1848			.0876			.1753
19	.2686	.2772				.3582	
20				.2103	.2743		.3506
22	.3696	.2772		.2629	.3696	.3258	.3506
Max	.3696	.2772	.1848	.2629	.3696	.3582	.3506
Min	.1829	.2772	.1829	.0876	.2743	.1829	.1753
Avg	.2582	.2772	.1842	.1840	.3220	.2473	.2582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 202 / 11KV SINDAKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5792	.5914	.5914		.5258	.5175	.4706
4	.5792	.5914	.5914		.5258	.5175	.4706
7					.5258		
8			.5487			.5121	.443
12	.4024			.3506			.2629
16	.3696			.3506			.2103
19	.5373	.5544				.5014	
20				.5609	.5914		.5609
22	.6584	.6283		.5609	.6283	.6154	.5258
Max	.6584	.6283	.5914	.5609	.6283	.6154	.5609
Min	.3696	.5544	.5487	.3506	.5258	.5014	.2103
Avg	.5210	.5914	.5772	.4558	.5594	.5328	.4206

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174030 / 33 KV SARKHANI

Feeder No / Name : 203 / 11KV DAHELI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.543	.5544	.5175		.5609	.4805	.5068
4	.5068	.5544	.5121		.5609	.4805	.5068
7					.5959		
8			.5175	.4557		.4755	.5316
12	.3658		.3856	.3856			.3856
16	.2195		.3856	.4557			.3506
19	.6219	.5544				.5373	
20			.631	.631	.6219		.6485
22	.7392		.631	.5959	.6283	.6268	.5784
Max	.7392	.5544	.631	.631	.6283	.6268	.6485
Min	.2195	.5544	.3856	.3856	.5609	.4755	.3506
Avg	.4994	.5544	.5115	.5048	.5936	.5201	.5012

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 201 / 11 KV BODHADI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.8149	1.0534	.8842	1.0719	.9313
2	.9313		.7802	1.0349	.8322	1.0791	.9313
3	.9313		.7802	.9979	.8149	1.0974	.9313
4	.9671		.8149	1.0349	.9015	1.0974	.9492
5	1.0745		.8669	1.0164	1.0749	1.134	1.0387
6	1.3611		.9362	1.0349	1.2136	1.2803	1.2536
7	1.2894		1.1269	1.134	1.1789	1.3321	1.3611
8	1.1443		1.0749	1.2094	1.1269	1.262	1.2715
9	.9015		.9536	.9671		1.1568	1.1641
10	.6935				.9694		1.0924
11	.6241			.6935	.9145		
12	.5201			.6588	.7947		
13	.4681			.6068	.7207	.6984	.7164
14	.5028				.7023	.6984	
15	.5201				.7392		
16	.7282			.6935	.924	.9134	.8596
17	.8596	.8322		.8495	.9979	1.0029	.9134
18	.9877	1.0749	1.134	.9882	1.0974	1.0029	.9134
19	1.3169	1.2136	1.1827	1.1616	1.2803		
20	1.2437	1.1963	1.2382	1.1789	1.1706	1.0745	1.0745
21	1.1706		1.1088	1.1269	1.0974	1.0566	.9671
22	1.1088	.8149	1.0807	1.0749	1.0903		
23	1.0719	.9015	1.0621	1.0056	1.1088	.9671	.8954
24	.9313	1.0349	.8669	1.0164	.8669	1.0903	.9313
Max	1.3611	1.2136	1.2382	1.2094	1.2803	1.3321	1.3611
Min	.4681	.8149	.7802	.6068	.7023	.6984	.7164
Avg	.9282	1.0098	.9889	.9780	.9783	1.0564	1.0109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 202 / 11 KV SAWRI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4854	.5223	.5201	.559	.6447
2	.591		.4334	.5415	.4854	.5404	.6447
3	.5731		.4334	.5041	.4508	.5729	.6447
4	.5731		.4681	.5228	.4854	.559	.6447
5	.591		.5548	.5041	.5548	.5404	.6089
6	.6447		.5895	.5544	.5895	.5914	.6805
7	.6447		.5548	.5544	.5201	.6283	.6089
8	.5548		.4854	.5914	.4161	.5914	.5194
9	.4334		.3467	.4435		.5544	.4477
10	.2601		.3142	.3121	.2236		.3761
11	.2427		.2981	.208	.2241		
12	.208		.2795	.2254	.2614		
13	.1907		.2981	.2601	.2427	.3045	.3224
14	.2254		.3168		.2957	.3224	
15	.1734		.1863		.3326		
16	.1907		.354	.2427	.3696	.3761	.3582
17	.3174	.3641	.3727	.2601	.4426	.394	.3224
18	.4066	.4334	.4805	.3641	.5853		.394
19	.6036	.5028	.5914	.4681	.6219		
20	.6219	.5548	.5963	.5548	.5914	.6268	.6626
21	.5729		.559	.5721	.5544	.5731	.6805
22	.5544	.5548	.5596	.5375	.5544		
23	.5544	.4681	.5596	.5201	.559	.6447	.6447
24	.591	.5544	.5201	.5596	.5201	.5544	.6447
Max	.6447	.5548	.5963	.5914	.6219	.6447	.6805
Min	.1734	.3641	.1863	.208	.2236	.3045	.3224
Avg	.4487	.4903	.4432	.4465	.4522	.5255	.5472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 204 / 11 KV BODHADI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.2601	.2254	.2558		.5627	.5304
10	.2947	.2558	.2947	.4458		.7127
11	.2774	.2728	.3467	.463		
12	.2601	.2572	.3988	.5144		
13	.2601	.2387	.4334	.5475	.5801	.8122
14	.2254	.2558		.5968	.5636	
15	.208	.2728		.648		
16	.2774	.2899	.4508	.6309	.3481	.4973
Max	.2947	.2899	.4508	.648	.5801	.8122
Min	.208	.2254	.2558	.4458	.3481	.4973
Avg	.2579	.2586	.3634	.5495	.5136	.6382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174041 / BODHADI 33 KV

Feeder No / Name : 205 / 11 KV SAWRI AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.1734	.1734	.1364		.2558	.3315
10	.208	.1876		.2058		.3978
11	.1907	.2217		.2229		
12	.1734	.2046	.1387	.2743		
13	.1734	.1705	.1734	.324	.2818	.1658
14	.208	.1876		.3069	.3149	
15	.1734	.2046		.341		
16	.156	.2046	.1387	.341	.2155	.1658
Max	.208	.2217	.1734	.341	.3149	.3978
Min	.156	.1705	.1364	.2058	.2155	.1658
Avg	.1820	.1943	.1468	.2880	.267	.2652



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 201 / 11KV Chinchkhed

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
8	.16	
17		.128
Max	.16	.128
Min	.16	.128
Avg	.16	.128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 202 / 11KV Umri

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
8	.8413	
17		.5959
Max	.8413	.5959
Min	.8413	.5959
Avg	.8413	.5959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

KINWAT (R) S/DN[455] BU 7421

Substation No/ Name :- 174100 / Umri Bazar

Feeder No / Name : 203 / 11KV Wazara

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)
8	.1406	
17		.125
Max	.1406	.125
Min	.1406	.125
Avg	.1406	.125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 202 / 11KV SHIKHAR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17
HR	Load (MW)
9	.8764
10	.5083
11	.5258
12	.5609
13	.5784
14	.5784
15	.5784
Max	.8764
Min	.5083
Avg	.6009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 203 / 11KV HADSANI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7621	.6908	.298	.3258	.298	.3681
2		.724	.6722	.3155	.3506	.298	.3641
3		.7049	.6722	.333	.3506	.298	.3641
4		.7049	.6722	.333	.3856	.298	.3681
5		.6859	.5975	.3506	.3856	.298	.3681
6		.6859	.4668	.3506	.4382	.2804	.3988
7		.6287		.3506	.4207	.2804	.4557
8		.5525		.333	.333	.2804	.3155
9	.4481		.2743			.2629	
10	.3547						
11	.1227		.1715	.2241	.3506		.2629
12	.1402		.1886		.2629	.4382	.2629
13	.1402		.3048	.3174	.2804	.381	.298
14	.1402		.2858	.3174	.2629	.381	.333
15	.1907		.2858		.2629	.4382	
16	.1907		.362	.3361	.2629	.4382	.3155
17	.2058	.3052	.3506	.4382	.3856	.5228	.3155
18	.2804	.3052	.3506	.5335	.5258	.5601	.0876
19	.7621	.7468	.6661		.5609	.6908	.3155
20	.7621	.7655	.7011		.6661	.7468	.6135
21	.7811	.6348	.7712	.8383	.7362	.7655	.6836
22	.7811	.6722	.7712	.8383	.7362	.7655	.7011
23	.7621	.7282	.7362	.8383	.7186	.7468	.7011
24		.7621	.7282	.7011	.8002	.7011	.7468
Max	.7811	.7655	.7712	.8383	.8002	.7655	.7468
Min	.1227	.3052	.1715	.2241	.2629	.2629	.0876
Avg	.4041	.6481	.5105	.4471	.4456	.4623	.4114

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 204 / 11KV ASTHA(SARKHANI)

Single Phasing Feeders

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3429	.9522	.7712	.9907	.8939	.9335
2		.3429	.9522	.7712	1.0288	.8939	.9522
3		.3772	.9709	.7712	1.0288	.8939	.9522
4		.3772	.9896	.7888	1.0479	.8939	.9522
5		.3944	1.0642	.7888	1.0479	.929	1.0082
6		.4207	1.1203	.7888	1.0098	.964	1.0829
7		.4382	1.0082	.8413	.9907	.9991	.9709
8		.4207	.8775	.7011	.8573	.8413	.7468
9	.1052		.6859			.7811	
10	.1402						
11	.2801		.3258	.2804	.4908		.5258
12	.2054		.3155	.3224	.5258	.4115	.5258
13	.4854		.2743	.3544	.5083	.3856	.4031
14	.4481		.2743		.4733	.4031	.4207
15	.2801		.2572		.4382	.3856	
16	.5788		.3086	.3681	.4207	.4207	.4382
17	.6287	.6348	.3506	.4382		.4382	.4557
18	.8192	.7282	.3856	.4557	.5609	.4557	.4557
19	.9907	.8962	.8413		.9114	.8029	.4908
20	1.0098	1.0829	.964		.9114	.9709	.6135
21	1.0098	1.0829	.9991	1.0098	.9465	1.0082	.7888
22	1.0479	1.0642	.9991	1.0288	.9465	.9149	.8764
23	.9907	1.0269	.929	1.0098	.9114	.9709	.9114
24		.9907	.9709	.929	.9907	.9114	.9522
Max	1.0479	1.0829	1.1203	1.0288	1.0479	1.0082	1.0829
Min	.1052	.3429	.2572	.2804	.4207	.3856	.4031
Avg	.6013	.6638	.7311	.6899	.8113	.7532	.7360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 205 / 11KV MAHUR FEEDER NEW Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.7392	.7316	.6661	.8215	.6836	.7023
2	.6661	.7207	.7133	.6661	.8215	.6836	.7023
3		.7023	.7133	.6661	.8131	.6836	.7023
4		.7023	.7133	.6836	.8131	.6836	.7207
5		.7023	.8131	.7011	.7762	.7011	.7392
6		.6653	.7762	.7362	.7947	.7362	.7577
7		.6283	.7023	.7362	.7577	.0175	.7392
8		.7023	.6767	.6135	.7392	.0175	.6838
9	.6468		.6468			.8779	
10	.5544						
11	.5544		.6348	.5544	.5959		.631
12	.5544		.5975	.5544	.5959	.567	.631
13	.5175		.5975	.5729	.5959	.5487	.6135
14	.4805		.5975		.6135	.5175	.631
15	.5544		.5601		.6135	.5175	
16	.5175		.5601	.5914	.5959	.4755	.5959
17	.4805	.5544	.5609	.5544		.5914	.5784
18	.6468	.6099	.6135	.6283		.6099	.5784
19	.7762	.7207	.7011		.6485	.6653	.6836
20	.7842	.7316	.7712		.7362	.7577	.7011
21	.7762	.8048	.7888	.8402	.7537	.7947	.7888
22	.8402	.7865	.7888	.8402	.7537	.7762	.7888
23	.8402	.7682	.7712	.8029	.7186	.7392	.7537
24	.6661	.7947	.7499	.7362	.8215	.7011	.7207
Max	.8402	.8048	.8131	.8402	.8215	.8779	.7888
Min	.4805	.5544	.5601	.5544	.5959	.0175	.5784
Avg	.6401	.7083	.6861	.6747	.7190	.6067	.6878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174021 / 33 KV MAHUR SUBSTATION

Feeder No / Name : 206 / 11KV RENUKADEVI PHC Only one consumer of WW with HT-IV  
EXPRESS FE Feeder KV- 11 /  
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0358	.0724	.0701	.0362	.0905	.0362
2		.0358	.0724	.0701	.0362	.0905	.0181
3		.0537	.0724	.0701	.0362	.0362	.0181
4		.0537	.0724	.0701	.0362	.0362	.0724
5		.0358	.0724	.0526	.0362	.0362	.0724
6		.0358	.0181	.0351	.0362	.0362	.0724
7		.0358	.0181	.0351	.0362	.0362	.0181
8		.0362	.0181	.0351	.0362	.0181	.0181
9	.0181		.0362			.0358	
10	.0181						
11	.0362		.0362	.0905	.0701		.0351
12	.0362		.0362	.0905	.0701	.0358	.0351
13	.0724		.0905	.0362	.0876	.0358	.0351
14	.0724		.1086		.0876	.0716	.0526
15	.0724		.1086		.0876	.0716	
16	.0905		.0724	.0905	.0876	.0358	.0526
17	.0362	.0724	.0701	.0905		.0362	.0526
18	.0362	.0905	.0701	.0362		.0362	.0351
19	.0362	.0362	.0351		.0362	.0362	.0351
20	.0724	.0362	.0351		.0362	.0905	.0351
21	.0724	.0724	.0351	.0362	.0362	.0905	.0526
22	.0362	.0724	.0351	.0362	.0362	.0905	.0526
23	.0362	.0724	.0351	.0362	.0905	.0905	.0526
24		.0362	.0724	.0701	.0362	.0724	.0905
Max	.0905	.0905	.1086	.0905	.0905	.0905	.0905
Min	.0181	.0358	.0181	.0351	.0362	.0181	.0181
Avg	.0495	.0507	.0562	.0584	.0526	.0550	.0449



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 201 / 11 KV WAI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099			.6838	.5729
2	.6099			.6838	.5729
3	5.8583			.6838	
4	.5729			.6838	.5729
5	.6838			.6838	.6099
6	.6099			.7577	.6468
7	.4668			.6838	.6468
8	.5729			.6099	.6468
9	.5548			.4668	.5729
10	.4024			.4668	.5041
11	.4161		.4224		.5041
12	.3467				.5041
13	.3772				.4668
14	.4161			.4294	.4294
15			.5729	.4294	.4294
16		.4172	.5729	.4294	.4294
17			.8478	.7712	.6104
18			.7682	.7712	
20			.6653		
21			.8048		
22			.8048		
23			.78	.7362	.7712
24	.6838			.78	.7362
Max	5.8583	.4172	.8478	.78	.7712
Min	.3467	.4172	.4224	.4294	.4294
Avg	.8788	.4172	.6932	.6324	.5682

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 202 / 11 KV HIWALANI FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3647			.5415	.5041
2				.5041	.5041
3	.3647			.5041	
4	.3647			.5041	.5041
5	.4458			.5041	.5415
6	.4458				.5415
7	.4115				.5415
8	.3647				.3921
9	.3174				.4024
10	.2427				.503
11	.2427		.5018		.3605
12	.2427				.3277
13	.2427				.2915
14	.2054			.2622	.3932
15			.5765	.3277	.2949
16		.3855	.5087	.3277	.2949
17			.3174	.3174	.3174
18			.4668	.3174	
19			.5041		
21			.5788		
22			.5415		
23			.5415	.5359	
24	.4508			.5415	.5415
Max	.4508	.3855	.5788	.5415	.5415
Min	.2054	.3855	.3174	.2622	.2915
Avg	.3362	.3855	.5041	.4323	.4268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174102 / 33/11 KV WAI SUBSTATION

Feeder No / Name : 203 / 11 KV ANJANKHED FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099				.6099
2	.6099				.6099
3	.5415				.5729
4	.5415				
5	.5729				.5729
6	.3547				.6099
7					.5729
8					.4668
9	.192				
10	.16				.1265
11	.192		.4915		.0949
12	.192				.0949
13					.0949
14	.3018			.2622	
15				.2622	.0949
16		.5007	.4588	.2949	.0949
17			.4668	.4294	.0949
20			.7207		
21			.6099		
22			.5729		
23				.6468	.5243
24	.6838				.6468
Max	.6838	.5007	.7207	.6468	.6468
Min	.16	.5007	.4588	.2622	.0949
Avg	.4127	.5007	.5534	.3791	.3676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 201 / 11 KV Ashta

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.6104		.1187	.1696	.1696	.1696
2	.6443	.6104		.1187		.1696	.1696
3	.6443	.6104		.1187		.1696	.1696
4	.6443	.6104		.1187		.1696	.1696
5	.6443	.6104				.2035	.2035
6	.6443	.6104				.2035	.2035
7	.5765	.5426				.2035	.2374
8	.4748	.4748				.2035	.2713
9	.407					.1696	.2374
10	.3391		.1017			.2035	.2374
11	.0678		.1017	.3052	.3391	.3391	
12				.2713		.3052	
13			.2883	.3222		.3391	.373
14			.3052	.2785		.3391	
15	.0678		.3052	.3391		.3391	.1017
16	.1017		.3222	.3561		.3052	
17	.1017		.407	.407		.3052	
18	.1017		.4578	.4578		.4409	
19	.6443		.5765	.6274		.5765	
20	.6443		.6104	.6952		.6783	.6783
21	.7122		.7461	.7122		.6783	.6783
22	.6783		.7122	.7122		.6783	.6783
23	.6783		.7011	.6783		.6443	.6443
24	.6443	.6443		.6613	.6613		.6104
Max	.7122	.6443	.7461	.7122	.6613	.6783	.6783
Min	.0678	.4748	.1017	.1187	.1696	.1696	.1017
Avg	.4812	.5916	.4335	.4055	.39	.3406	.3431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 202 / 11 KV Takali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1753	.1753	.3506		.3681		.3506
2	.1753	.1753	.3506				.3506
3	.1753	.1753	.3506				.3506
4	.1753	.1753	.3506				.3506
5	.2103	.2103					.3506
6	.2103	.2103					.4557
7	.2804	.2804					.4207
8	.2804	.3155				.4557	.4908
9	.2804						.4207
10	.2804		.3506			.3506	.3155
11	.1753		.2454	.3506	.5083	.3506	
12				.4031		.3856	
13			.2454	.3681			.5609
14			.2629	.407			.5609
15	.1753		.2279	.4031		.2454	.1753
16	.1753		.2804	.4557		.4207	.4207
17	.2103		.298	.5609		.4557	
18	.3155		.2279	.5609		.4207	
19	.3856		.4207	.4207		.3856	
20	.3856		.4733	.4382		.3856	.4207
21	.3856		.4207	.4031		.3856	.3856
22	.3856		.3856	.4031		.3856	.3856
23	.3856		.3681	.3856		.3856	.3856
24	.3856	.3506		.3681	.3856		.3856
Max	.3856	.3506	.4733	.5609	.5083	.4557	.5609
Min	.1753	.1753	.2279	.3506	.3681	.2454	.1753
Avg	.2671	.2298	.3300	.4234	.4207	.3856	.3967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

MAHUR SUB-DIVISION[793] BU 4793

Substation No/ Name :- 174118 / 33 KV ASHTA

Feeder No / Name : 203 / 11 KV Gokul

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6104	.4748	.2374		.1865	.1696	.2374
2	.6104	.4748	.2374			.1696	.2374
3	.6104	.4748	.2374			.1696	.2374
4	.5765	.4748	.2374			.1696	.2374
5	.5765	.5087				.2035	.2374
6	.6104	.5087				.2374	.3052
7	.6783					.2374	.2713
8	.5765	.4409				.2035	.3052
9	.3052					.1696	.2374
10	.2713		.2035			.1357	.1696
11			.1696	.2543	.2883	.373	
12				.2883		.3391	
13			.2883	.3222		.2713	.2713
14			.3052	.3391		.373	.2713
15	.1357		.3561	.3222		.407	.3052
16	.1357		.39	.3391		.5087	.3052
17	.1696		.4239	.4409		.5426	
18	.2035		.5426	.5426		.5765	
19	.7122		.5935	.6783		.6443	
20	.6783		.7122	.763		.6783	.6783
21	.6443		.7291	.7122		.6783	.6783
22	.6443		.6952	.6952		.6443	
23	.6443		.6613	.6613		.6443	.6443
24	.6443	.6104		.6443	.6443		.6104
Max	.7122	.6104	.7291	.763	.6443	.6783	.6783
Min	.1357	.4409	.1696	.2543	.1865	.1357	.1696
Avg	.5019	.4960	.4129	.5002	.3730	.3716	.3467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 201 / UMRI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288			.8573			.6859
2		.8573		.8573		1.2003	1.2003
3				.8573			1.3336
4	1.0288	.8573		.8573		1.2003	1.3717
5				.9431		1.3717	1.3717
6		1.0288		1.1145		1.5432	1.3717
7				1.2003		1.5432	1.3717
8			1.2003	1.286	1.2003	1.3717	.6859
9			1.2003		1.2003	1.3717	.8573
10						1.3717	.8573
11						1.3717	.8573
12						1.2003	.8573
13						1.2003	1.0288
14						1.2003	.6859
15						1.2003	.8573
16		1.0288			1.0288	1.0288	.8573
17					.8573		1.0288
18		.8573			.8573		.6859
19							1.2003
20		1.0288	1.2003		1.2003		1.5432
21			1.1145		1.2003		1.3717
22			1.0288		1.2003		1.3717
23		1.0288	1.0288		1.2003		1.2003
24		.8573		.8573			1.2003
Max	1.0288	1.0288	1.2003	1.286	1.2003	1.5432	1.5432
Min	1.0288	.8573	1.0288	.8573	.8573	1.0288	.6859
Avg	1.0288	.9431	1.1288	.9812	1.1050	1.2983	1.0772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 202 / TALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003			.5144	.8573		
2		1.5432		.5144	1.0288	.8573	
3				.5144	1.0288	.8573	
4	1.2003	1.5432		.5144	1.0288	.8573	
5	1.3717			.5144	1.0288	.8573	
6	1.7147	1.7147		.6859	1.0288	1.0288	
7	1.8861			.8573	1.0288	1.0288	1.0288
8	1.3717	1.7147	.8573	.8573	1.0288	1.0288	1.0288
9			.8573	.6859	1.0288	.5144	1.2003
10			.8573	.6859	.8573	.5144	1.2003
11			.8573	.6859	.6859		
12			.8573		.5144		
13			.8573		.5144		.6859
14			.8573		.5144		.5144
15			.8573	.8573	.5144		.5144
16		.3429	.8573	.8573	.5144		.5144
17			.9431	.8573	.5144		.5144
18		.6859	.8573	.6859			.6859
19			1.3717	.8573	1.2003		1.0288
20		.8573	1.5432	1.0288	1.2003		1.2003
21			1.5432	1.0288	1.2003		1.0288
22			1.5432	1.0288	1.2003		.8573
23	1.2003	.8573	1.3717	1.0288	1.2003		.6859
24		1.3717		1.2003	1.0288	.8573	
Max	1.8861	1.7147	1.5432	1.2003	1.2003	1.0288	1.2003
Min	1.2003	.3429	.8573	.5144	.5144	.5144	.5144
Avg	1.4207	1.1812	1.0556	.7838	.9021	.8402	.8459



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 203 / BOTHI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5144			
2		.6859		.5144		.8573	
3				.5144			
4		.6859		.5144		.8573	
5				.5144		1.0288	
6		.6859		.6859		1.0288	
7				.6859		1.0288	1.0288
8		.6859	.8573	.6859	1.0288	1.2003	.6859
9	.5144		.6859		1.0288	1.2003	.6859
10			.6859		.8573	1.2003	.6859
11			.6859		.3429	.3429	
12			.6859		.3429	.3429	.5144
13			.6859		.3429		.5144
14							.5144
15							.5144
16			.6859		.5144		.5144
17			.6859				.5144
18			.5144		.5144		.6859
19			.6859				1.0288
20			.8573		1.0288		1.0288
21			.8573		1.0288		1.0288
22			.8573				.8573
23		.6859	.6859		1.0288		.8573
24				.5144		.8573	
Max	.5144	.6859	.8573	.6859	1.0288	1.2003	1.0288
Min	.5144	.6859	.5144	.5144	.3429	.3429	.5144
Avg	.5144	.6859	.7226	.5716	.7326	.9041	.7287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 204 / JAMGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3429			
2		.5144		.3429		.3429	
3				.3429			
4		.5144		.3429		.3429	
5				.3429		.3429	
6		.6859		.5144		.4287	
7				.5144		.4287	.5144
8		.6859	.3429	.5144		.3429	.5144
9	.3429		.3429			.3429	.3429
10			.3429		.5144		.3429
11			.3429		.5144		
12			.5144		.6859	.8573	.8573
13			.6859		.8573	.8573	.8573
14			.6859			1.0288	.8573
15			.6859			1.0288	.8573
16			.6859		.8573		.8573
17			.8573				1.0288
18			.8573		1.0288		1.0288
19			.5144				.5144
20			.5144		.3429		.5144
21			.5144				.5144
22			.5144		.3429		.5144
23			.3429		.3429		.3429
24		.5144		.3429		.3429	
Max	.3429	.6859	.8573	.5144	1.0288	1.0288	1.0288
Min	.3429	.5144	.3429	.3429	.3429	.3429	.3429
Avg	.3429	.583	.5465	.4001	.6096	.5573	.6537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 205 / GOLEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.1715			
2		.3429		.1715		.3429	
4		.3429				.3429	
5						.3429	
6		.3429				.3429	
7						.3429	.3429
8		.3429	.3429	.1715		.3429	.3429
9			.3429		.1715	.3429	.3429
10			.3429		.3429	.3429	
11			.3429		.3429	.3429	
12			.3429		.3429	.3429	.4287
13			.3429		.3429	.3429	.4287
14			.3429			.3429	
15			.3429			.3429	.3429
16			.3429		.3429		.3429
17			.3429				.3429
18			.8573		.3429		.3429
19			.1715				.3429
20			.8573		.3429		.3429
21			.1715		.3429		.3429
22			.1715				.1715
23			.3429		.3429		.3429
24		.3429		.1715		.3429	
Max	.1715	.3429	.8573	.1715	.3429	.3429	.4287
Min	.1715	.3429	.1715	.1715	.1715	.3429	.1715
Avg	.1715	.3429	.3751	.1715	.3258	.3429	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174016 / UMRI

Feeder No / Name : 206 / CIVIL HOSPITAL EXPRESS Only one consumer of WW with HT-IV  
FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171					
2		.0171			.0171	
4		.0171			.0171	
6		.0171			.0171	
7					.0171	
8		.0171	.0171			.0171
9			.0171			
11					.0171	
12					.0171	.0171
13					.0171	.0171
14					.0171	
15					.0171	
16				.0171		.0171
18				.0171		
20				.0171		
22				.0171		
23				.0171		
24		.0171			.0171	
Max	.0171	.0171	.0171	.0171	.0171	.0171
Min	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0171	.0171	.0171	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 201 / SHINDI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715			.2572	.1715
2	.1715			.2572	.1715
3	.1715			.2572	.1715
4	.1715			.2572	.1715
5	.2572			.2572	.1715
6	.2572			.2572	.1715
7	.2572			.2572	.1715
8	.2572			.2572	.1715
9	.1715			.2572	.1715
10	.1715			.1715	.1715
11	.1715		.0857	.1715	.1772
12	.1715		.0857	.1715	.1772
13	.1715		.0857	.1715	.1791
14	.1715		.0857	.1715	.16
15	.1715		.0857	.1715	.1581
16	.1715		.0857	.1715	
17	.2058		.0857	.1715	
18	.2572		.0857	.1715	.16
19	.3429	.2572			
20	.3429	.2572		.2572	
21	.3429	.2572		.2572	
22	.3086	.2572		.2572	
23	.2601	.1715		.2572	
24	.1715			.2572	.1715
Max	.3429	.2572	.0857	.2572	.1791
Min	.1715	.1715	.0857	.1715	.1581
Avg	.2216	.2401	.0857	.2237	.1705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 202 / HUNDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429			.3429	.3429
2	.3429			.3429	.3429
3	.3429			.3429	.3429
4	.3734			.4287	.3429
5	.2572			.4287	.5144
6	.2572			.5144	.5144
7	.1715			.6001	.6859
8	.1715			.6001	.8573
9	.1715			.5144	.6859
10	.1715			.5144	.6859
11	.1715		.1715	.2572	.1772
12	.1715		.1715	.2572	.1772
13	.1715			.2572	.1791
14	.1715		.3429	.2572	.1581
15	.1715		.3429	.2572	.16
16	.2572		.4287	.2572	.16
17	.2572		.4287	.2572	.1581
18	.2572		.0857	.2572	
19	.5144	.2572		.2572	
20	.5144	.3429		.3429	
21	.5144	.4287		.3429	
22	.5144	.5144		.3429	
23	.4287	.5144		.3429	
24	.3429			.4287	.3429
Max	.5144	.5144	.4287	.6001	.8573
Min	.1715	.2572	.0857	.2572	.1581
Avg	.2942	.4115	.2817	.3644	.3793

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 203 / SHIVANGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838		.0838	.0857
2	.0838		.0838	.0857
3	.0848		.0838	.0857
4	.0829		.0838	.0857
5	.0838		.0838	.0857
6	.0838		.0838	.0857
7	.0838		.0829	.0857
8	.0848		.0829	.0857
9	.0848		.0838	.0857
10	.1341		.0838	.0857
11	.0838	.0838	.0857	.0791
12	.0848	.0838	.0857	.0791
13	.0838	.0838	.0857	.08
14	.0848	.0838	.0857	.0791
15	.0838	.0838	.0857	.08
16	.0838	.0838	.0857	
17	.0829	.0838	.0857	
18	.0829	.2515	.0857	
19	.0838		.0857	
20	.0829		.0857	
21	.0838		.0857	
22	.0838		.0857	
23	.0829		.0857	
24	.0848		.0838	.0857
Max	.1341	.2515	.0857	.0857
Min	.0829	.0838	.0829	.0791
Avg	.0860	.1048	.0848	.0838

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 204 / 11 kv Dairy feeder

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.1715	.1715
2	.0857		.1715	.1715
3	.1715		.1715	.1715
4	.1715		.1715	.1715
5	.1715		.1715	.2572
6	.1715		.1715	.2572
7	.1715		.1715	.2572
8	.1715		.1715	.3429
9	.1715		.0857	.3429
10	.1715		.0857	.2572
11	.1715	.1715	.0857	.1772
12	.1715	.1715	.0857	.0886
13	.0857	.0857	.0857	.0895
14	.0857	.1715	.0857	
15	.0857	.0934	.0857	
16	.0857	.0857	.0857	
17	.0857	.1715	.0857	
18	.1715	.0857	.0857	
19	.1715		.0857	
20	.1715		.1715	
21	.1715		.1715	
22	.1715		.1715	
23	.1715		.1715	
24	.1715		.1677	.1715
Max	.1715	.1715	.1715	.3429
Min	.0857	.0857	.0857	.0886
Avg	.1501	.1296	.1320	.2091



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 205 / PALASGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.2003
2				1.2003
3				1.2003
4				1.1145
5				1.1145
6				1.1145
7				1.1145
8	1.2003			1.2003
9	1.2003			1.0288
10	1.2003			.9431
11	.4287			
12	.3429	.3429	.8573	1.2403
13	.3429	.3429	1.0288	1.2536
14	.4334	.3429	1.0288	1.1517
15	.4334	.3429	1.0288	
16	.6068	.5144	1.0288	
17	.6859	.6001	1.1145	
18	.8573	.6859	1.2003	
19	1.2003		1.2003	
20	1.2003			
21	1.2003			
22	1.1145			
23	1.2003			
24				1.2003
Max	1.2003	.6859	1.2003	1.2536
Min	.3429	.3429	.8573	.9431
Avg	.8530	.4531	1.0610	1.1484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174080 / SHINDI

Feeder No / Name : 206 / SHELGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572			.1715
2	.2572			.2572
3	.2572			.2572
4	.2515			.3429
5	.1677			.3429
6	.1677		.2515	.3429
7	.1677		.2515	.3429
8	.1677		.2515	.3429
9	.1677		.2515	.5144
10	.1677		.2515	.5144
11	.0838	.0838	.1715	.1772
12	.0838	.0838	.1715	
13	.0848	.0838	.1715	.1772
14	.0838	.0838	.1715	
15	.0838	.0838	.1715	
16	.1677	.0838	.1715	
17	.1677	.0838	.1715	
18	.1677	.1696	.1715	
19	.2515		.2572	
20	.2515		.2572	
21	.2515		.1715	
22	.2486		.1715	
23	.2486		.1715	
24	.2572			.1715
Max	.2572	.1696	.2572	.5144
Min	.0838	.0838	.1715	.1715
Avg	.1859	.0945	.2032	.3042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 201 / 11 kv waghalwada

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	28-JUL-17
HR	Load (MW)
20	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 202 / 11kv Hassa feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	28-JUL-17
HR	Load (MW)
20	.12
Max	.12
Min	.12
Avg	.12

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

BHOKAR DIVSION[695]

UMRI SUB-DIVISION[794] BU 4794

Substation No/ Name :- 174127 / 33kv karkala sub station

Feeder No / Name : 203 / 11 kv Hatni Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	28-JUL-17
HR	Load (MW)
20	.12
Max	.12
Min	.12
Avg	.12

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 203 / BILOLI URBAN

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		1.0534		1.1458	.924	1.1458	
9							.9795
16	.8131		.7762	.8316	.7392	.7392	.7392
24		.924		.961		.8501	1.0349
Max	.8131	1.0534	.7762	1.1458	.924	1.1458	1.0349
Min	.8131	.924	.7762	.8316	.7392	.7392	.7392
Avg	.8131	.9887	.7762	.9795	.8316	.9117	.9179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174018 / 33 KV ARJAPUR(BILOLI)

Feeder No / Name : 204 / Govt. Hospital Express

HV Non-Express Feeder

Feeder Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8		.0183		.0183		.0181	
9							.0183
16	.0183		.0183	.0185	.0181	.0183	.0185
24		.0183		.0183		.0177	.0183
Max	.0183	.0183	.0183	.0185	.0181	.0183	.0185
Min	.0183	.0183	.0183	.0183	.0181	.0177	.0183
Avg	.0183	.0183	.0183	.0184	.0181	.0180	.0184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 201 / 11 KV LOHGAON FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.8954		.9412			1.0985	1.829
16	.7733		.724	.4715		1.2071	.4024
19					1.5089		
24	1.2826	1.3203	.9526	1.3336		***	1.2955
Max	1.2826	1.3203	.9526	1.3336	1.5089	14.2027	1.829
Min	.7733	1.3203	.724	.4715	1.5089	1.0985	.4024
Avg	.9838	1.3203	.8726	.9026	1.5089	5.5028	1.1756



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 202 / 11 KV RAHER FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3395		.3018			.1509	.1097
16	.1311		.1006	.1113		.0907	.0754
19					.1844		
24	.2263	.2241	.2241	.2241		.2263	.112
Max	.3395	.2241	.3018	.2241	.1844	.2263	.112
Min	.1311	.2241	.1006	.1113	.1844	.0907	.0754
Avg	.2323	.2241	.2088	.1677	.1844	.1560	.0990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174034 / 33 KV SUB STATION RAHER

Feeder No / Name : 203 / 11 KV HARNAL FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.811		1.0185			.9808	.2587
16	.2378		.1829	.1387		.2012	.3734
19					.2481		
24	.7545	.6348	.7095	.7095		.7167	.7095
Max	.811	.6348	1.0185	.7095	.2481	.9808	.7095
Min	.2378	.6348	.1829	.1387	.2481	.2012	.2587
Avg	.6011	.6348	.6370	.4241	.2481	.6329	.4472

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 201 / 11 KV BELKONI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4225			.423	
2			.4225			.423	
3			.4225			.3254	
4			.4225			.4556	
5			.4225			.4556	
6			.4063			.4881	
7			.4063			.423	
8	.4481		.3413	.4024	.3579	.3905	.3887
9			.2925				
11					.325		
12		.2275			.3738		
16			.2614			.3721	.179
19		.3088			.3413		
24	.4527		.4225	.5228		.423	.3982
Max	.4527	.3088	.4225	.5228	.3738	.4881	.3982
Min	.4481	.2275	.2614	.4024	.325	.3254	.179
Avg	.4504	.2682	.3857	.4626	.3495	.4179	.3220

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 202 / 11 KV SAVLI FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5914			.5914	
2		.6262			.5914	
3		.6262			.5914	
4		.6262			.6262	
5		.661			.6262	
6		.661			.6436	
7		.661			.7654	
8	.6722	.6262	.8048	.7306	.9045	.9808
9		.5914				
11				.487		
12				.4349		
16		.4755			.5316	.4001
19				.9219		
24	.9431	.8697	.8688		.8349	.8413
Max	.9431	.8697	.8688	.9219	.9045	.9808
Min	.6722	.4755	.8048	.4349	.5316	.4001
Avg	.8077	.6378	.8368	.6436	.6707	.7407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 203 / 11 KV CHINCHALA FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1163			.1163	
2		.1163			.1163	
3		.1163			.1163	
4		.1163			.1163	
5		.1163			.1495	
6		.1163			.1495	
7		.1163			.0831	
8	.1494	.1163	.1097	.1495	.1661	.1562
9		.1163				
11				.1163		
12				.1661		
16		.1494			.2629	.0831
19				.1661		
24	.112	.1163	.1829		.1163	.2126
Max	.1494	.1494	.1829	.1661	.2629	.2126
Min	.112	.1163	.1097	.1163	.0831	.0831
Avg	.1307	.1193	.1463	.1495	.1393	.1506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 204 / 11 KV TALNI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4966			.4972	
2		.4966			.5327	
3		.4961			.6037	
4		1.0631			.6392	
5		.6208			.6747	
6					.6747	
7		.5853			.5682	
8	.4854	.4966	.5258	.6221	.551	.3391
9		.4966				
11				.2666		
12				.2666		
16		.112			.3582	.2306
19				.5149		
24	.5228	.5138	.5121		.5149	.3544
Max	.5228	1.0631	.5258	.6221	.6747	.3544
Min	.4854	.112	.5121	.2666	.3582	.2306
Avg	.5041	.5378	.5190	.4176	.5615	.3080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 205 / 11 KV KASRALI FEEDER

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1489			.1675	
2		.1489			.1675	
3		.1489			.1489	
4		.1489			.1489	
5		.1489			.1489	
6		.1489			.1489	
7		.1489			.1303	
8	.1448		.1109	.1489	.1303	.1294
9		.1489				
11				.0931		
12				.1117		
16		.0724			.0876	.0931
19				.1675		
24	.1494	.1675	.128		.1675	.1402
Max	.1494	.1675	.128	.1675	.1675	.1402
Min	.1448	.0724	.1109	.0931	.0876	.0931
Avg	.1471	.1431	.1195	.1303	.1446	.1209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174068 / 33 KV SUB-STATION KASRALI

Feeder No / Name : 206 / 11 KV RUDRAPUR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0652			.1143	
2		.0652			.1143	
3		.0652			.1306	
4		.0652			.1306	
5		.0652			.1306	
6		.0652			.1306	
7		.0814			.1959	
8	.0732	.1466	.0972	.1306	.2123	.1334
9		.0977				
11				.0489		
12				.0326		
16		.0362			.0526	.1143
19				.0653		
24	.0934	.0814	.0934		.0816	.0701
Max	.0934	.1466	.0972	.1306	.2123	.1334
Min	.0732	.0362	.0934	.0326	.0526	.0701
Avg	.0833	.0759	.0953	.0694	.1293	.1059



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 201 / 11 KV DAULATAPUR FEEDER Single Phasing Feeders  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4801	.4633	.3593	.3658	.333	.3658	.3658
16	.1562		.3437	.3185		.3963	.4481
24	.2915	.3125	.3437	.3593	.3269	.3201	.2743
Max	.4801	.4633	.3593	.3658	.333	.3963	.4481
Min	.1562	.3125	.3437	.3185	.3269	.3201	.2743
Avg	.3093	.3879	.3489	.3479	.3300	.3607	.3627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 202 / 11 KV SAGROLI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4207		
8		.4938		.4755			
16	.3292		.2743	.3292		.2743	.2987
24	.3944	.4024	.4572	.4207	.4207	.3353	.3048
Max	.3944	.4938	.4572	.4755	.4207	.3353	.3048
Min	.3292	.4024	.2743	.3292	.4207	.2743	.2987
Avg	.3618	.4481	.3658	.4085	.4207	.3048	.3018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174079 / 33 KV SUB STATION - SAGROLI

Feeder No / Name : 203 / 11 KV BOLEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3086	.3932	.9061	1.0159	1.0623	.9755	1.0059
16	.5502		.2374	.1966			.1829
24	.3429	.3391	.3521	.3605	.39	.3353	.2743
Max	.5502	.3932	.9061	1.0159	1.0623	.9755	1.0059
Min	.3086	.3391	.2374	.1966	.39	.3353	.1829
Avg	.4006	.3662	.4985	.5243	.7262	.6554	.4877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 201 / 11 kv BAMNI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2743		.3086	.2743	.3601	.4801	.3086
16	.2401		.2401	.2401		.2058	
22					.3086		
23						.2058	.2401
24		.2743	.2743	.2058	.2743	.3086	
Max	.2743	.2743	.3086	.2743	.3601	.4801	.3086
Min	.2401	.2743	.2401	.2058	.2743	.2058	.2401
Avg	.2572	.2743	.2743	.2401	.3143	.3001	.2744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 202 / 11 KV HINGNI FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.1372		.2743	.1715	.1715	.3086	.3429
16	.1029		.1715	.0857		.1715	
22					.2401		
23						.2401	
24		.2058	.2058	.1543	.1543	.2058	
Max	.1372	.2058	.2743	.1715	.2401	.3086	.3429
Min	.1029	.2058	.1715	.0857	.1543	.1715	.3429
Avg	.1201	.2058	.2172	.1372	.1886	.2315	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

BILOLISUB-DIVISION[792] BU 4792

Substation No/ Name :- 174126 / 33 KV BAMNI SUB-STATION

Feeder No / Name : 203 / 11 KV BADOOR FEEDER

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.6516		.6516	.3772	.3601	.823	.6173
16	.2743		.3429	.4458		.4458	
22					.6173		
23						.4458	
24		.5144	.5487	.4115	.2401	.583	
Max	.6516	.5144	.6516	.4458	.6173	.823	.6173
Min	.2743	.5144	.3429	.3772	.2401	.4458	.6173
Avg	.4630	.5144	.5144	.4115	.4058	.5744	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 202 / 11 KV TOWN 2 DEGLOOR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6348				
2			.6348	.6219			
3			.6348				
4			.5975	.6268			
5			.6348				
6			.6722	.6878			
7			.7095				.7842
8			.7468				
12			.6516		.5228		
13	.4973						
14			.543	.439			
16		.5975	.5487	.4755			
17		.6348			.5228		
18	.6401	.6722	.6584	.5121			
19	.6584	.7095					
20		.7468	.7602	.7164			
21	.695	.7842					
22		.7842		.724			
23		.7468					
24			.6722			.5175	.5544
Max	.695	.7842	.7602	.724	.5228	.5175	.7842
Min	.4973	.5975	.543	.439	.5228	.5175	.5544
Avg	.6227	.7095	.6500	.6004	.5228	.5175	.6693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 203 / 11 KV TOWN 3 DEGLOOR Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.5228				
2			.4854	.5068			
3			.4481				
4			.4854	.5121			
5			.5228				
6			.5601	.5792			
7			.5975				.6838
8			.6348	.5853			
11						.5544	
12			.5487		.4854		
13	.543						
14			.4525	.3982			
16	.5973		.5068	.4755			
17		.5601			.4854		
18	.567	.5975	.6335	.4525			
19	.695	.6348					
20		.6722	.7316	.6335			
21	.6767	.7095					
22		.6722		.6401			
23		.6348					
24			.5601			.5544	.4668
Max	.695	.7095	.7316	.6401	.4854	.5544	.6838
Min	.543	.5601	.4481	.3982	.4854	.5544	.4668
Avg	.6158	.6402	.5493	.5315	.4854	.5544	.5753



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174007 / 33 KV DEGLOOR-I

Feeder No / Name : 207 / GOVT. HOSPITAL EXPRESS

HV Express Feeder

FEEDER Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.0181			
4			.0183			
6			.0181			
7						.0189
8			.0183			
12		.0181		.0189		
13	.0183					
14		.0183	.0181			
16	.0183	.0181	.0181			.0183
17				.0189		
18	.0183	.0181	.0181			
19	.0183					
20		.0181	.0181			
21	.0183					
22			.0183			
24					.0189	.0189
Max	.0183	.0183	.0183	.0189	.0189	.0189
Min	.0183	.0181	.0181	.0189	.0189	.0183
Avg	.0183	.0181	.0182	.0189	.0189	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 201 / 11 KV MUKRAMABAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.415	.3361
2		.4108	.3361
3		.4481	.3361
4		.4481	.4108
5		.4108	.4108
6		.4481	.4108
7		.5601	.4108
8		.5487	.439
9			.4024
10			.3361
11			.394
12			.439
13			.3658
14			.3292
15			.3658
16			.3658
17	.4066		.4024
18	.4066		.3696
19	.4481		.3696
20	.4854		.4066
21	.5228		.4108
22	.5228		.3734
23	.4904		.3361
24		.4527	.3361
Max	.5228	.5601	.439
Min	.4066	.4108	.3292
Avg	.4690	.4603	.3789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 202 / 11 KV GOJEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.5281	.6219
2		.4854	.5914
3		.5228	.6584
4		.5601	.6584
5		.6348	
6		.6348	
7		.7095	
8		1.0242	
11			.5731
12			.439
13			.6154
14			.5853
15			.5853
16			.6219
17	.3696		.5121
18	.4805		.5914
19	.4854		.7392
20	.4481		.8131
21	.4854		.8676
22	.4481		.7202
23	.4527		.7316
24		.4904	.6653
Max	.4854	1.0242	.8676
Min	.3696	.4854	.439
Avg	.4528	.6211	.6439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 203 / 11 KV RAVANKOLA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3018	.439
2		.2987	.5487
3		.3361	.6219
4		.3734	.6089
5			.8596
6			.9259
7			1.166
8			1.3375
9			1.406
10			1.2346
17	.924		.1867
18	.924		.2241
19	.3734		.2987
20	.3361		.3734
21	.3734		.3361
22	.3734		
23	.3395		.2987
24		.3395	.3361
Max	.924	.3734	1.406
Min	.3361	.2987	.1867
Avg	.5205	.3299	.6589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174029 / 33 KV S/S MUKRAMABAD

Feeder No / Name : 204 / 11 KV SAWARMAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1		.3395	.3361
2		.3361	.3361
3		.3361	.2987
4		.3734	.2987
5			.4066
6			.4755
7			.5144
8			.583
9			.6173
10			.6348
17	.2957		.1132
18	.3326		.112
19	.1867		.1867
20	.4108		.4805
21	.4481		.4108
22	.4108		.3734
23	.3772		.3734
24		.3772	.4066
Max	.4481	.3772	.6348
Min	.1867	.3361	.112
Avg	.3517	.3525	.3865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 201 / 11 KV TAMLOOR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1829			.1867	.1867
2	.1867	.1829			.1867	.1867
3	.2054				.2054	.2054
4	.2054	.2012			.2054	.2054
10						.3921
11	.4108	.3658	.3658	.3734	.4481	.3921
12	.3547	.3475	.3475	.3547	.3921	.3547
13	.3361	.3292	.3292	.3174	.3734	.3174
14	.3174	.2743	.2743	.2987	.3547	.2987
15	.2987	.2743	.2743	.2801	.3361	.2801
16	.2801	.3109	.3109	.2801	.3174	.2801
17	.2801	.3292	.3292	.3361	.3361	.2801
18	.3547	.3475	.3475	.3547		
19		.1829		.168		
20	.1867	.1829		.2054		
21	.1867	.1829		.2054		
22	.1867	.1829		.2054		
23		.1829		.1867	.1867	.2054
24	.1867		.1829		.1867	.1867
Max	.4108	.3658	.3658	.3734	.4481	.3921
Min	.1867	.1829	.1829	.168	.1867	.1867
Avg	.2602	.2538	.3068	.2743	.2858	.2694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 202 / 11KV NARANGAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3258			.3547	.2987
2	.3547	.3258			.3547	.2987
3	.3734	.362			.4108	.3174
4	.4108	.362			.4481	.3361
5	.4294	.3801			.4854	.3547
6	.4294	.362			.5041	.3547
7		.3982				
8	.4294	.3258			.3734	.3547
9	.2987	.2896			.3547	.2987
10	.2241	.2353			.3547	.2614
15					.112	
16			.1448		.1307	
17		.181	.1448	.112	.1494	.168
18	.168	.181	.1629	.1307		
19	.2801	.1991		.1307		
20	.2987	.2172		.1307		
21	.2614	.2534		.2614		
22	.2427	.2353		.2427		
23		.2172		.2241	.2054	.2241
24	.2241		.2172		.2241	.1867
Max	.4294	.3982	.2172	.2614	.5041	.3547
Min	.168	.181	.1448	.112	.112	.168
Avg	.3174	.2853	.1674	.1760	.3187	.2878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 203 / 11 KV SANGVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.5914			.5415	.5601
2	.4108	.6283			.5415	.5601
3	.4854	.6653			.5975	.5975
4	.5415	.7023			.7095	.7282
5	.5975	.7392			.7468	.7842
6	.5975	.7762			.7655	.9522
7	.7468	.8131			.8962	.9522
8	.8215	.8131			.9335	.9522
9	.7095	.7762			.7468	.9335
10	.6722	.7392			.7282	.9149
11		.1294				
12		.1109				
16			.1294			
17	.112	.1109	.1478		.112	.112
18	.112	.1109	.1478			
19	.1307	.1294				
20	.1494	.1294				
21	.1494	.1478		.1307		
22	.168	.1478		.1494		
23		.1478		.1307	.112	.1307
24	.112		.1478		.1307	.112
Max	.8215	.8131	.1478	.1494	.9335	.9522
Min	.112	.1109	.1294	.1307	.112	.112
Avg	.4075	.4426	.1432	.1369	.5817	.6377



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 204 / 11KV MANDAGI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0532			.0934	.0747
2	.112	.0532			.112	.0747
3	.112	.0532			.112	.0747
4	.1494	.0709			.112	.0934
5	.1494	.0709			.1307	.0934
6	.0747	.0886			.1307	.1494
7	.168	.0886			.1307	.1494
8	.1867	.0709			.1307	.168
9	.1307	.0709			.1867	.1307
10	.112	.0709			.2054	.112
17	.0187	.0532	.0532	.4294	.0373	
18	.0187		.0709	.4108		.0373
19	.056	.0532		.4108		
20	.0747	.0532		.0747		
21	.056	.0709		.056		
22	.056	.1063		.056		
23		.0532		.056	.056	.056
24	.0373		.0532		.0373	.0373
Max	.1867	.1063	.0709	.4294	.2054	.168
Min	.0187	.0532	.0532	.056	.0373	.0373
Avg	.0955	.0676	.0591	.2134	.1135	.0962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174035 / 33 KV S/S TAMLOOR

Feeder No / Name : 205 / 11KV SHELGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4298			.3361	.3734
2	.3734	.4298			.3361	.3734
3	.3921	.3761			.3547	.3921
4	.4108	.3582			.3734	.4108
11	.5415	.5014	.5014	.6161	.5601	.4294
12	.6348	.5014	.4656	.4294	.4854	.5041
13	.5601	.4656	.4298	.4108	.4854	.4854
14	.4854	.4298	.3582	.4668	.4854	.4668
15	.4481	.3761	.3224	.4481	.4854	.4481
16	.4294	.4298	.3582	.4294		.4294
17	.4294	.4298	.394	.4294		.4108
18	.5228	.4119	.4298	.4108		
19	.5041	.4119		.4108		
20	.4854	.4298		.3734		
21	.4668	.4656		.3547		
22	.4668	.4656		.3547		
23		.4477		.3361	.3547	.3734
24	.4481		.4656		.3361	.3547
Max	.6348	.5014	.5014	.6161	.5601	.5041
Min	.3734	.3582	.3224	.3361	.3361	.3547
Avg	.4690	.4330	.4139	.4208	.4175	.4194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 201 / 11 KV KARADKHED

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
12	1.5074
Max	1.5074
Min	1.5074
Avg	1.5074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 202 / 11 KV MARKHEL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
10	.362
12	.7625
Max	.7625
Min	.362
Avg	.5623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 203 / 11 KV KINI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
12	.7628
Max	.7628
Min	.7628
Avg	.7628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 204 / 11 KV DEGLOOR WATER SUPPLY  
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	27-JUL-17
HR	Load (MW)
8	.108
12	.0926
Max	.108
Min	.0926
Avg	.1003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174053 / 33 KV S/S KARADKHED

Feeder No / Name : 205 / 11 KV CHAKUR EXPRESS

HV Express Feeder

FEEDER Feeder KV- 11 /

OUTGOING

DATE	27-JUL-17
HR	Load (MW)
12	.0543
Max	.0543
Min	.0543
Avg	.0543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 201 / 11 KV MIDC-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1372	.1543
2	.1372	.12	.1372	.1715		
3					.1372	.1543
4	.1372	.12	.1372	.1372		
5					.1372	.1543
6		.1372	.1715	.1372	.1543	.1543
7	.1886	.1372	.1886	.1715		
8		.1715	.2058	.2058	.1886	.2058
9	.1715					
10	.3258				.2743	.2058
11			.3429		.3772	
12	.4287		.3601			
13			.3601		.4287	
14	.3429					
15					.3772	
16	.463			.3429		
17	.4287				.3772	
18	.2572			.2572		
19					.3429	
20	.2058			.2058		
21	.1886		.2058		.2743	
22			.1715	.1715		
23	.1715	.1715	.1715	.1715	.2058	
Max	.463	.1715	.3601	.3429	.4287	.2058
Min	.1372	.12	.1372	.1372	.1372	.1543
Avg	.2651	.1429	.2229	.1972	.2625	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174103 / 33 KV S/S KHANAPUR MIDC

Feeder No / Name : 202 / 11 KV TADKHEL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.6001	.7716
2	.6173	.703	.7716	.6173		
3					.6001	.7716
4	.6859	.8745	.9602	.8573		
5					.7202	.8916
6		.8745	.9602	.9945	.7888	.8916
7	.7202	.8573	.7716	.9431		
8		.9431	.7202	.9945		1.1831
9	.6859					
10	.4973				.703	1.0631
12					.2058	
14					.2058	
15				.2572	.2058	
17	.3429			.2743	.2915	
18	.3429			.2743		
19					.2743	
20	.3772			.3086		
21	.3772		.3086		.2401	
22			.3429	.3086		
23	.3772	.4115	.3601	.3086	.2401	
Max	.7202	.9431	.9602	.9945	.7888	1.1831
Min	.3429	.4115	.3086	.2572	.2058	.7716
Avg	.5024	.7773	.6494	.5580	.4230	.9288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 201 / 11 KV DAPKA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715		.2374	.2713	.1677	.1715	.1715
2	.1715		.2012	.2439	.1677	.1715	.1715
3	.1886		.2035	.2439	.1844	.2058	.1886
4	.2035		.2134	.2439	.218	.2229	.2204
11	.1715	.2515	.1524		.2543		
12	.2035	.2035	.1539		.2543		.2543
13	.1696	.2543	.1509		.2543	.2229	.2439
14	.1017	.2543			.2058	.2058	.2035
15	.1006	.2035			.1715	.2058	.2515
16	.1006	.2035	.1526	.1677	.1715	.2229	.2439
17	.1174	.1696	.1526	.1677	.1886	.2058	.2515
18	.2012	.2035	.1526	.1677	.2058		.2713
19	.2515	.2035	.2543	.1677	.2543		.2713
20	.2515	.2286	.2683	.2683	.2713	.2229	.2515
21	.2683	.2713	.3018	.2347	.2543	.2229	.2286
22	.2683	.2713	.218	.2515	.2374	.2058	.2374
23	.2515	.2543	.2012	.1677	.2058	.1886	.2035
24	.1715		.2543	.2543	.1677	.1886	.1715
Max	.2683	.2713	.3018	.2713	.2713	.2229	.2713
Min	.1006	.1696	.1509	.1677	.1677	.1715	.1715
Avg	.1869	.2287	.2043	.2193	.2130	.2046	.2256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 202 / 11 KV BAMNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39	.5365	.5047	.5426	.57	.6104	.6274
2	.3772	.5868	.503	.6371	.5967	.6104	.6274
3	.407	.6036	.4694	.6443	.5624	.6443	.6443
4	.4409	.6036	.5087	.6706	.6443	.6706	.6783
11	.4409	.5087	.5935		.7122		
12	.3353	.6783	.7122		.9054		.9145
13		.763				.9054	1.0059
14		.8478	.5426		.8383	.8718	.9326
15		.6783	.5426		.8048	.8886	.9326
16		.6706	.6706	.6874	.8383	.8718	.9326
17		.5487	.7461	.7712	.8718	.9221	.9496
18		.5868	.7209	.8383	.8383		1.0174
19	.503	.5087	.7712	.8048	.8383		.3391
20	.5868	.5868	.6874	.8048	.8048	.8139	.4144
21	.6371	.6036	.6539	.4527	.78	.763	.4748
22	.6706	.6036	.6443	.5365	.7122	.6783	.4917
23	.6036	.5868	.6036	.547	.6783	.6443	.4748
24	.407	.503	.5868	.57	.57	.6443	.6443
Max	.6706	.8478	.7712	.8383	.9054	.9221	1.0174
Min	.3353	.503	.4694	.4527	.5624	.6104	.3391
Avg	.4833	.6114	.6154	.6544	.7392	.7528	.7119

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174110 / 33 KV S/S DAPKA

Feeder No / Name : 203 / 11 KV HATRAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.2683	.2374	.2683	.3018	.2743	.3052
2	.2374	.2683	.2035	.2683	.3018	.2743	.3052
3	.2543	.2713	.2347	.285	.3185	.2883	.3222
4	.2713	.2683	.2347	.3018	.3353	.3052	.3391
11	.2374	.2683	.2035		.2713		
12	.2683	.2683	.2035		.3052		.3391
13	.2347	.3052	.2374			.3688	.373
14	.2515				.373	.3353	.3052
15	.2515	.3353	.3391		.3222	.3521	.3391
16	.2515	.2515	.3185	.1844	.3391	.3391	.3391
17	.3018		.3052	.285	.373	.3688	.3052
18	.3018		.2713	.3018	.3391		.3391
19	.3353		.2713	.285	.3052		.2543
20	.3353	.1677	.3353	.2896	.3391	.3052	.2713
21	.3018	.2713	.3353	.3353	.3052	.3222	.2713
22	.3018	.2683	.2896	.3391	.3052	.3052	.2543
23	.2683	.2515	.3018	.2984	.2883	.2883	.2374
24	.2058	.2515	.2543	.2683	.3018	.2713	.2883
Max	.3353	.3353	.3391	.3391	.373	.3688	.373
Min	.2058	.1677	.2035	.1844	.2713	.2713	.2374
Avg	.2693	.2654	.2692	.2854	.3191	.3142	.3052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174120 / 33 KV S/S SHAHAPUR

Feeder No / Name : 201 / 11 KV Shahapur

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)
2	.3452	
11	.5004	
17	.4275	
21	.4577	
24		.452
Max	.5004	.452
Min	.3452	.452
Avg	.4327	.452

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174120 / 33 KV S/S SHAHAPUR

Feeder No / Name : 202 / 11 KV Chainpur

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)
1	.4833	
4	.4262	.4014
8	.6139	
17	.2783	
20	.6674	
24		.4774
Max	.6674	.4774
Min	.2783	.4014
Avg	.4938	.4394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174120 / 33 KV S/S SHAHAPUR

Feeder No / Name : 203 / 11 KV Aloor

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)
2	.4833	
11	.3586	
15	.2725	
20	.5956	
24		.5148
Max	.5956	.5148
Min	.2725	.5148
Avg	.4275	.5148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174124 / 33 KV S/S MALEGAON

Feeder No / Name : 201 / Malegaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0148	.0278			
13			.0427		.0594
17			.0612		
18				.0464	
Max	.0148	.0278	.0612	.0464	.0594
Min	.0148	.0278	.0427	.0464	.0594
Avg	.0148	.0278	.0520	.0464	.0594



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174124 / 33 KV S/S MALEGAON

Feeder No / Name : 202 / Hali

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0349	.0367				
13			.082	.0941		.08
17				.0609		
18					.0784	
Max	.0349	.0367	.082	.0941	.0784	.08
Min	.0349	.0367	.082	.0609	.0784	.08
Avg	.0349	.0367	.082	.0775	.0784	.08

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174124 / 33 KV S/S MALEGAON

Feeder No / Name : 203 / Kini

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11	.0251	.0286				
13			.0553	.0658		.0868
17				.0818		
18					.0921	
22		.0321				
Max	.0251	.0321	.0553	.0818	.0921	.0868
Min	.0251	.0286	.0553	.0658	.0921	.0868
Avg	.0251	.0304	.0553	.0738	.0921	.0868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174125 / 33 KV S/S RAMTAPUR

Feeder No / Name : 201 / 11 KV Ramtapur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.0672			.1172		
8		.2031		.1896			
9				.1843			.1648
10							.1612
17					.0113	.0522	
18	.0456					.0474	
19			.0459				
20				.1139		.1012	
21			.1044				
22				.1157		.0965	
Max	.0456	.2031	.1044	.1896	.1172	.1012	.1648
Min	.0456	.0672	.0459	.1139	.0113	.0474	.1612
Avg	.0456	.1352	.0752	.1509	.0643	.0743	.163

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174125 / 33 KV S/S RAMTAPUR

Feeder No / Name : 202 / 11 KV Somur

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.2297		
8		.2481			
9		.2729			.4359
10				.0725	.4359
17				.1787	
18				.1834	
19	.2261				
20				.34	
21	.2831				
22				.3258	
<b>Max</b>	<b>.2831</b>	<b>.2729</b>	<b>.2297</b>	<b>.34</b>	<b>.4359</b>
<b>Min</b>	<b>.2261</b>	<b>.2481</b>	<b>.2297</b>	<b>.0725</b>	<b>.4359</b>
<b>Avg</b>	<b>.2546</b>	<b>.2605</b>	<b>.2297</b>	<b>.2201</b>	<b>.4359</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DEGLOOR (R) S/DN[449] BU 2488

Substation No/ Name :- 174125 / 33 KV S/S RAMTAPUR

Feeder No / Name : 203 / 11 KV Bijalwadi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.0047			.0078		
8	.0062		.0124			
9			.0124			.0106
10						.0106
17					.0016	
18					.0016	
19		.0063				
20					.0079	
21		.0063				
22					.0079	
Max	.0062	.0063	.0124	.0078	.0079	.0106
Min	.0047	.0063	.0124	.0078	.0016	.0106
Avg	.0055	.0063	.0124	.0078	.0048	.0106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 201 / 11 KV DHARMABAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307				1.2136	
2		1.0374		1.4003		1.3203
4					1.1203	1.3203
5		1.1317				
6	1.307			1.307		1.3203
7		1.3203			1.2136	
8						1.587
10	1.1203				1.2136	1.307
12			1.1203		1.2136	
14					1.2136	
15	1.1203					1.2136
16			1.4003		1.1203	
17	1.1203					1.1145
20	1.5089				1.5089	
21						1.6975
22			1.6804		1.5089	
24		1.5089				1.3203
Max	1.5089	1.5089	1.6804	1.4003	1.5089	1.6975
Min	1.1203	1.0374	1.1203	1.307	1.1203	1.1145
Avg	1.2473	1.2496	1.4003	1.3537	1.2585	1.3556

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 202 / 11 KV DIGRAS

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867				.1867	
2		.2641		.1867		.132
4					.2241	.1509
5		.2641				
6	.1494			.2241		.1509
7		.2452			.2614	
8						.1307
10	.1867				.112	.1867
12					.112	
13			.112		.112	
14					.0934	
15	.1494					.1307
16			.1307		.1867	
17	.1494					.1307
20	.2641				.2641	
21						.3018
22			.1867		.2641	
24		.2829				.2641
Max	.2641	.2829	.1867	.2241	.2641	.3018
Min	.1494	.2452	.112	.1867	.0934	.1307
Avg	.1810	.2641	.1431	.2054	.1817	.1754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 203 / 11 KV BABHALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112				.5228	
2		.1509		.2801		.3395
4					.7095	.3772
5		.1132				
6	.112			.3734		.3961
7		.0943			.6535	
8						.4294
10	.2801				.0934	.0747
12			.0934		.0934	
14					.0934	
15	.3734					.0934
16			.112		.0934	
17	.3734					.0747
20	.1509				.132	
21						.1698
22			.112		.132	
24		.1509				.132
Max	.3734	.1509	.112	.3734	.7095	.4294
Min	.112	.0943	.0934	.2801	.0934	.0747
Avg	.2336	.1273	.1058	.3268	.2804	.2319



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 205 / 11 KV RATNALI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668				.4668	
2		.4904		.4668		.415
4					.5601	.415
5		.4715				
6	.4668			.5228		.415
7		.4715			.5228	
8						.3734
10	.4668				.3361	.3361
12			.3734		.2987	
14					.3361	
15	.2987					.2801
16			.3361		.2054	
17	.2801					.2241
20	.4904				.4338	
21						.4527
22			.5228		.4338	
24		.4904				.415
Max	.4904	.4904	.5228	.5228	.5601	.4527
Min	.2801	.4715	.3361	.4668	.2054	.2241
Avg	.4116	.4810	.4108	.4948	.3993	.3696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 206 / 11 KV PIONEER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734				.0934	
2		.0566		.2801		.2075
4					.0934	.2075
5		.2263				
6	.3734			.2801		.2075
7		.2263			.0934	
8						.1867
10	.5228				.0305	.3361
12			.3734		.0934	
14					.0934	
15	.5041					.3547
16			.3734		.3174	
17	.4481					.3921
20					.2263	
21						.2641
22			.2801		.2263	
24						.2075
Max	.5228	.2263	.3734	.2801	.3174	.3921
Min	.3734	.0566	.2801	.2801	.0305	.1867
Avg	.4444	.1697	.3423	.2801	.1408	.2626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174015 / 33 KV DHARMABAD

Feeder No / Name : 211 / RURAL HOSPITAL EXP  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097				.112	
2		.1132		.1097		.132
4					.112	.132
5		.1132				
6	.112			.1097		.132
7		.132			.112	
8						.1294
10	.1097				.1294	.1109
12			.1097		.1294	
14					.1109	
15	.1109					.1307
16			.1097		.1294	
17	.1109					.1109
20	.1132				.1132	
21						.132
22			.1097		.1132	
24		.1132				.1132
Max	.1132	.132	.1097	.1097	.1294	.132
Min	.1097	.1132	.1097	.1097	.1109	.1109
Avg	.1111	.1179	.1097	.1097	.1179	.1248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 201 / 11 KV KUNDALWADI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.596				
8				.6478	
16		.5046	.5906		.4335
Max	.596	.5046	.5906	.6478	.4335
Min	.596	.5046	.5906	.6478	.4335
Avg	.596	.5046	.5906	.6478	.4335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 203 / 11 KV GUJARI

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.4299			
8				.2667
16		.1871		
17			.3239	
Max	.4299	.1871	.3239	.2667
Min	.4299	.1871	.3239	.2667
Avg	.4299	.1871	.3239	.2667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 204 / 11 KV KONDALWADI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.2507			
16		.5373	.6668	.4298
Max	.2507	.5373	.6668	.4298
Min	.2507	.5373	.6668	.4298
Avg	.2507	.5373	.6668	.4298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 205 / 11 KV GUJARI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)
8		.4001
16	.0381	
Max	.0381	.4001
Min	.0381	.4001
Avg	.0381	.4001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 206 / 11 KV SHELGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.3015			
8			.1905	
16		.2096		.1422
Max	.3015	.2096	.1905	.1422
Min	.3015	.2096	.1905	.1422
Avg	.3015	.2096	.1905	.1422



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 207 / 11 KV MACHNOOR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
8	.1524
Max	.1524
Min	.1524
Avg	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174043 / 33 KV CHAINAPUR

Feeder No / Name : 208 / 11 KV MACHNOOR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6	.5199			
8			.2477	
16		.1334		.1778
Max	.5199	.1334	.2477	.1778
Min	.5199	.1334	.2477	.1778
Avg	.5199	.1334	.2477	.1778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 201 / 11 KV KARKHELI

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)
10	.5068	.905
Max	.5068	.905
Min	.5068	.905
Avg	.5068	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 202 / 11 KV YETALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17
HR	Load (MW)
10	.5601
Max	.5601
Min	.5601
Avg	.5601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

DHARMABAD (R) S/DN[458] BU 2470

Substation No/ Name :- 174066 / 33 KV KARKHELI

Feeder No / Name : 203 / 11 KV ELEGAON

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17
HR	Load (MW)
10	.2896
Max	.2896
Min	.2896
Avg	.2896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 201 / 11 KV MUKHED TOWN I

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5144		.5144
2	.6001		.4801	.583	.5144		.5144
4	.6516		.5487	.6173	.5487		.4801
5	.6859	.5316			.5487		.5144
6		.5144	.583	.6516	.6173	.5316	.5487
7							.583
8	.7202	.5144	.5487	.6859	.583		.583
9	.5487						
10						.6173	
11	.4458				.5316	.6173	
12			.4801			.583	
13	.4458			.6516			
14	.5658		.5144				.5144
15						.5487	
16	.5487			.6001	.463	.5487	.5144
17				.583	.4801		.5487
18	.5144	.4973	.583	.6001			
19	.5316					.583	.6859
20	.5487	.6173		.6859			
21	.5658		.7202	.703		.5487	.6859
22	.5682	.6173					
23		.6001	.6516			.5487	.6516
24	.6516		.583	.6516	.5487		.5487
Max	.7202	.6173	.7202	.703	.6173	.6173	.6859
Min	.4458	.4973	.4801	.583	.463	.5316	.4801
Avg	.5729	.5561	.5693	.6376	.5350	.5697	.5634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174012 / 33 KV MUKHED

Feeder No / Name : 206 / 11 MUKHED TOWN II

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8916		.8916
2	.8573		.9945	.8573	.8916		.8916
4	.823		.9945	.8916	.8916		.9602
5	.823				.9259		1.0288
6		.9432	1.0974	.9259	1.046	.8573	1.0974
7							1.0631
8	.9602	.8916	.8916	.9259	.8059		1.046
9	.823						
10	.7202					.9259	
11	.7202				.8573	.9259	
12	.6859		.823			.9259	
13	.8573			.8745			
14	.8916		.8573				.8916
15						.9259	
16	.823				.823	.8916	.8573
17				.823	.8059		.8916
18	.905	.8745	.9259	.8059			
19	.8745	1.046				1.1317	
20	.8916	1.1317		.9431			
21	.9431		1.0631	.9602		.9602	1.0802
22		1.1317					
23		1.0631	.9945			.9431	.9602
24	.8916		1.0631	.9945	.9259		.9259
Max	.9602	1.1317	1.0974	.9945	1.046	1.1317	1.0974
Min	.6859	.8745	.823	.8059	.8059	.8573	.8573
Avg	.8432	1.0117	.9705	.9002	.8865	.9431	.9681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 201 / 11 KV YEOTI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.39	.2515
2	.2229	.2229	.2401	.2058		.3772	.2374
3						.3772	.2374
4	.2401	.2947	.2915	.2572		.3988	.2572
5						.4115	.2713
6	.3641	.3772	.4115	.3467	.3856	.5144	.3185
7					.3429	.583	.4359
8		.4801	.5144		.3391	.6036	.4475
9					.3353		
10	.3601				.3315		.2374
12	.2058		.4115				
13					.3353	.4748	.3391
14	.2572		.3429		.3353	.4409	.3688
15					.373	.4115	.3856
16	.2058		.3258		.4024	.4191	.407
17					.4748	.4409	
18	.2743	.3944	.3429		.4694	.4748	
19					.5935	.1357	
20	.3944	.4115	.4287		.5487	.2401	.4191
21					.4748	.3018	.4191
22	.2743	.3601	.3429		.463	.285	.407
23					.4458	.2515	.39
24	.2743	.2572	.2915	.2401	.4287	.407	.2515
Max	.3944	.4801	.5144	.3467	.5935	.6036	.4475
Min	.2058	.2229	.2401	.2058	.3315	.1357	.2374
Avg	.2794	.3498	.3585	.2625	.4164	.3969	.3379



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

MUKHED (R) S/DN[448] BU 2496

Substation No/ Name :- 174067 / 33 KV YEOTI

Feeder No / Name : 202 / 11 KV HONWADAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.8916	.8573
2	.7282	.8063	.7802	.8842		1.0056	.8817
3						1.0288	.9054
4	.8764	.8764	.8842	.9362		1.0288	1.0174
5						1.0059	1.0174
6	1.1043	1.2269	.9709	1.0692	1.3146	1.326	1.1736
7					1.4746	1.3763	1.3592
8		1.2269	1.2445		1.8233	1.0814	1.3108
9					1.7814		1.0486
10	.4557		1.0056		1.6194		.9945
11							.7762
12	.5201		.4207				.7316
13					.3696	.7762	.3734
14	.6588		.5201		.4108	.8029	.4066
15					.4481	.7468	
16	.7537		.5959		.5228	.7392	.7392
17					.5544	.7762	
18	.8495	.929	.6135		.6036	.8589	
19					1.1317	.7392	
20	1.262	1.2483	1.1269		1.1949	1.0829	1.1088
21					1.1458	1.0562	1.1088
22	.9991	.9465	.9362		1.1203	.9709	1.0829
23					1.0185	.9335	.9808
24	.8413	.8413	.8413	.8322	.2572	.9431	.9431
Max	1.262	1.2483	1.2445	1.0692	1.8233	1.3763	1.3592
Min	.4557	.8063	.4207	.8322	.2572	.7392	.3734
Avg	.8226	1.0127	.8283	.9305	.9877	.9585	.9409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 201 / 11 KV NARSI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5914	.5281	.5658	.5144	.5601	.5239
2	.5544	.5853	.5281	.5658	.5144	.5601	.483
3	.5544	.5853	.5281	.5658	.5144	.5601	.4884
4	.6348	.6283	.5281	.5658	.5487	.5601	.4874
5	.6653	.6283	.5281	.5975	.6001	.6413	.5265
6	.6908	.6348	.5975	.6348	.6687	.6722	.6011
7	.7095	.7049	.6653	.7392	.703	.7545	.6605
8	.7468	.7733	.6653	.7095		.8488	.7491
9	.7049		.5914			.724	.789
10	.6401		.5975				.6361
11	.6535		.5228	.4287	1.2826		
12	.6283		.5601	.4973	1.2826	.5233	
13	.499		.5415			.4859	.6348
14	.5415		.4854	.5144	.4854		.4527
15	.5601		.5228	.5249	.4854		.5228
16	.5415		.5281	.5249		.4495	.5281
17	.5228			.6173			.5281
18	.5228		.5228	.6335		.5504	.5601
19	.5601		.5228	.5784			
20	.6348	.6348	.6722	.7095			.6722
21	.6908	.5975	.6722	.7095			
22	.6348	.5601	.6348	.583			.7095
23	.6348	.5658	.5658	.5316	.6908	.5233	.6535
24	.5975	.5975	.5228	.5658	.5144	.5975	
Max	.7468	.7733	.6722	.7392	1.2826	.8488	.789
Min	.499	.5601	.4854	.4287	.4854	.4495	.4527
Avg	.6116	.6221	.5666	.5887	.6773	.6007	.5898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 202 / 11 KV NAIGAON GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.1203	1.2071	1.2071	1.0974	1.2696	1.2411
2	1.1088	1.1203	1.1694	1.2071	1.0974	1.1949	1.2023
3	1.1088	1.1088	1.1694	1.2071	1.1145	1.1576	1.1974
4	1.2567	1.2936	1.1694	1.2826	1.2003	1.2696	1.2059
5	1.3817	1.4045	1.2696	1.3957	1.3717	1.4712	1.319
6	1.5524	1.6617	1.4563	1.6804	1.6461	1.8099	1.6155
7	1.7551	1.8111	1.7924	1.885	1.6804	1.9231	1.9122
8	1.6787	1.8111	1.7741	1.7551		1.8111	1.8034
9	1.4563		1.3817			1.6617	1.5604
10	1.307		1.307				1.4678
11	1.1203		1.1949	1.085			
12	1.1763		1.2323	1.0688		1.5404	
13	1.1431		1.1389	1.0136		1.3746	1.307
14	.9997		.4854	.8916	1.2323	1.3003	1.2323
15	1.105		.4527	1.0974	1.2323		1.0829
16	1.1203		.4481	1.1946		1.1974	1.1949
17	1.2071			.4706			
18	1.2955		1.531	1.4842		1.6907	
19	1.4335	1.2696	1.5154	1.6832			
20	1.475	1.5524	1.5893	1.7013			1.9044
21	1.4969	1.419	1.5154	1.5927	1.9605		
22	1.3817	1.3817	1.4563	1.4022			1.4937
23	1.307	1.2696	1.1949	1.286	1.6617	1.2348	1.3443
24	1.1949	1.1827	1.1576	1.2071	1.0974	1.4937	1.2361
Max	1.7551	1.8111	1.7924	1.885	1.9605	1.9231	1.9122
Min	.9997	1.1088	.4481	.4706	1.0974	1.1576	1.0829
Avg	1.2993	1.3862	1.2439	1.3090	1.366	1.4625	1.4067

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174009 / 33 KV NARSI

Feeder No / Name : 203 / 11 KV CANAL AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0406	.096	.0972	.0714		
2	.0857	.0417	.096	.0972	.0857		
3	.0869	.0417	.1296	.0972	.0857		
4	.1014	.0556	.1296	.096	.1		
5	.1174	.0556	.128	.1107	.1143		
6	.132	.0695	.16	.125	.1286		
7	.1467	.1252	.1581	.1524	.1429		
8	.168	.0823	.1898	.1524			
9	.0823						
10			.1562		.0619		
11	.032		.0617	.0667	.0743		
12	.096		.064	.0533	.0619	.1146	
13	.0974		.064	.0533		.1085	.1543
14	.0777		.0617	.0533	.1132	.0847	.1562
15	.0674		.0937	.0572	.1536	.0826	.1235
16	.0777		.1219	.0572		.0858	.1219
17	.0777			.0572			.0914
18	.0777		.1219	.0572			.1562
19	.0549	.0926	.0914	.0429			
20	.0556	.125	.1235	.0429			.1235
21	.0412	.1265	.125	.0572			
22	.0412	.0949	.1094	.0572			.1235
23	.0412	.096	.096	.0714			.1094
24	.0857	.0412	.0949	.096	.0714		
Max	.168	.1265	.1898	.1524	.1536	.1146	.1562
Min	.032	.0406	.0617	.0429	.0619	.0826	.0914
Avg	.0839	.0777	.1124	.0796	.0973	.0952	.1289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 201 / 11 KV RUI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335		.724	.7316		
2	.9335		.7164	.7392		
3	.9335		.724	.7316		
4	1.0269		.823	.905		
5	1.1203		.924	1.1088		
6	1.4003		1.086	.924		
7	1.307		1.086	.9955		
8	1.1203		1.1641	.905		
11					.1867	
12					.2801	1.1269
13						1.0402
14			.3658			.3696
15			.5544		.1772	.3696
16			.924			.3772
17			.9335			
18		.8573	.9335			
19		1.4937	1.307			
20		1.4937			1.5089	
21		1.4003	1.386			
22		1.307	1.307			
23		1.1203	1.2136			
24	1.0269		1.1203	1.1203		
Max	1.4003	1.4937	1.386	1.1203	1.5089	1.1269
Min	.9335	.8573	.3658	.7316	.1772	.3696
Avg	1.0891	1.2787	.9607	.9068	.5382	.6567

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 202 / 11 KV DEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181		.7468	.7545		.7545	.5658
2	.1829		.7468	.7545		.7545	.5658
3	.1848		.7468	.7545		.6602	.6602
4	.1848		.7545	.8488		.7545	.6602
5	.2772		.9431	.8488		.7545	.7545
6	.3696		.9431	1.0374		.9335	
7	.462		1.0374	1.1203		1.0269	
8	.4572		.9335	.8488		1.1203	
9			.8402			1.0269	
10			.5658				
11			.3467		.2543		
12			.3391		.2572	.3544	
13						.3544	
14			.3353			.3544	
15			.3467		.1715	.2658	
16			.3506			.2658	
17			.3544				
18		.6535	.443				
19		.8402	.7545				
20		.9431			.4287		
21		.8488	.7545				
22		.7545	.7545				
23		.7468	.7545		.7468		
24	.6602		.7468	.7545		.7468	.6535
Max	.6602	.9431	1.0374	1.1203	.7468	1.1203	.7545
Min	.181	.6535	.3353	.7545	.1715	.2658	.5658
Avg	.3289	.7978	.6608	.8580	.3717	.6752	.6433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 204 / 11 KV KAHALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829		.8402	.7545			.7545
2	.2829		.8402	.7545			.6602
3	.2801		.8402	.8488			.6602
4	.2801		.9335	.9431			.9431
5	.3734		1.0374	1.1317			1.0374
6	.3734		1.1317	1.3203			
7	.362		1.1317				
8	.4525		1.1203	1.226			
11					.5087		
12					.5201	.7011	
13						.5258	
14						.4334	
15			.4382		.6001	.4382	
16			.5201			.3506	
17			.5144				
18		.9335	.5087				
19		1.1203	1.1203				
20		1.2136			1.2136		
21		1.0269	1.2136				
22		.8402	1.1203				
23		.8402	.8402				
24	.7545		.8402	.7545			.7468
Max	.7545	1.2136	1.2136	1.3203	1.2136	.7011	1.0374
Min	.2801	.8402	.4382	.7545	.5087	.3506	.6602
Avg	.3824	.9958	.8818	.9667	.7106	.4898	.8004

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174028 / 33 KV GHUNGRALA

Feeder No / Name : 205 / TATA Chemicals

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0145		.0189	.0139
2	.013		.0187	.0122
3	.0116		.0187	.0131
4	.0111		.009	.0099
5	.0109		.017	.0103
6	.0099		.0143	.0099
7	.0111		.0114	.0114
8	.0084		.0116	.017
14			.0069	
15			.0048	
16			.0057	
17		.0189	.0072	
18			.0076	
21			.0131	
22			.007	
23		.0189	.016	
24	.005		.0189	.0154
Max	.0145	.0189	.0189	.017
Min	.005	.0189	.0048	.0099
Avg	.0106	.0189	.0122	.0126



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 201 / 11 KV GADGA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3982		.4287	.5144		.3734	.3086
2	.3982	.3734	.4287	.5144		.3734	.2743
3	.3982	.3734	.4287	.6001		.4668	.2743
4	.3982	.4668	.5144	.6001		.6535	.3086
5		.5601	.6001	.6859		.7468	.3429
6	.6516	.7468	.7716	.6859		1.0269	.3429
7	.7964	.8402	.8573	.8573		1.1576	.5144
8	.905	.9335	.8916	.8916		1.1576	.4973
9	.724		.8916	.8573		1.1203	.3772
10	.5258				.5601	1.0269	.3772
11	.3734	.2572	.2229	.2896	.3734		.4115
12	.2801	.2572	.1715	.2534	.2801		.4458
13	.1867	.2572	.1715	.2561	.2801	.3086	.5144
14	.1867	.2572	.1886	.2195	.2801		.4115
15	.1867	.2572	.1715	.2195	.2801		.4508
16	.1867	.2915	.1715	.2561		.2572	.4801
17	.1867	.2915	.2401	.2926			.4854
18	.3361	.2915	.2743	.3292		.3258	.4908
19	.4668	.3429	.3429	.362	.4668		.7164
20	.5228	.4287	.5144	.439	.5601	.3772	.8505
21	.4668	.4287	.4287	.4024	.4668	.3429	
22	.285	.3429	.3429	.3658	.415	.3429	
23	.3734	.3429	.3429		.3734	.3429	
24	.3258	.3361	.3429	.3429		.3734	.3086
Max	.905	.9335	.8916	.8916	.5601	1.1576	.8505
Min	.1867	.2572	.1715	.2195	.2801	.2572	.2743
Avg	.4156	.4132	.4234	.4652	.3942	.5986	.4373

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 202 / 11 KV KOLAMBI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1494	.1543	.1543		.168	.1543
2	.1448	.1494	.1543	.1543		.168	.1715
3	.1448	.168	.1543	.1543		.168	.1715
4	.1448	.168	.1715	.1715		.168	.1715
5	.1448	.0934	.1715	.1715		.168	.2572
6	.181	.1867	.1715	.1886		.1867	.4115
7	.2534	.2054	.1715	.1886		.1867	.823
8	.2896	.1867	.1715	.1543		.2241	1.0288
9	.543		.1543	.12		.1867	
10	.4656				.1494	.1494	.8059
11	.3734	.2572	.4973	.5487	.5601		.3506
12	.4668	.3429	.583	.695	.8402		
13	.4668	.4801	.6173	.6878	.9335	.9945	.3224
14	.4668	.4801	.583	.6154	.9335		.2865
15	.3734	.4973	.6173	.543	.9335		
16	.3734	.4973	.6173	.4706		.823	.0366
17	.4108	.4973	.6173	.4344			.0366
18	.4108	.5144	.6173	.362		.3086	.3258
19	.2241	.1715	.1543		.2241		.5731
20	.1867	.1886	.1715		.1867	.1715	.724
21	.168	.1715	.1715		.1867	.1715	
22	.168	.1715	.1715		.168	.1715	
23	.1494	.1715	.1715		.168	.1543	
24	.1463	.1494	.1543	.1715		.168	.1543
Max	.543	.5144	.6173	.695	.9335	.9945	1.0288
Min	.1448	.0934	.1543	.12	.1494	.1494	.0366
Avg	.2851	.2681	.3139	.3325	.4803	.2631	.3781

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174054 / 33 KV MANJARAM

Feeder No / Name : 203 / 11 KV MANJRAM

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4668	.5144	.5144		.4715	.5144
2	.4854	.4668	.5144	.5487		.4668	.5144
3	.4854	.5601	.5144	.6173		.5601	.5144
4	.4854	.7468	.5144	.6859		.8402	.6001
5	.4854	.8402	.6859	.7716		1.0269	.6001
6	.5201	.9335	.9431	.9431		1.2136	.6859
7	.5201	1.0269	1.0288	1.0288		1.307	.7716
8	.5609	1.2136	1.0288	1.1145		1.4003	.6859
9	.4557		1.0288	1.0288		1.307	
10	.407				.6535	.9335	.6001
11	.3734	.2572	.3429	.3658	.5601		.3772
12	.2801	.1715	.1715	.2926	.4668		.4161
13	.2801	.1715	.1715	.2926	.4108	.4287	.5087
14	.2801	.1715	.2572	.2561	.3734		.4694
15	.2801	.1715	.2743	.2561	.3734		.4694
16	.2801	.2572	.3086	.3292		.4287	.2984
17	.3734	.2572	.3429	.3658			.3772
18	.4668	.3429	.3429	.4024		.5144	.4409
19	.5601	.5144	.4458		.6535		.5609
20	.6535	.5144	.6001			.5144	.6379
21	.5601	.5144	.5144		.6535	.5144	
22	.5601	.4287	.5144		.5601	.5144	
23	.4668	.4287	.4801		.5601	.5144	
24	.5121	.4668	.4287	.4801		.5601	.5144
Max	.6535	1.2136	1.0288	1.1145	.6535	1.4003	.7716
Min	.2801	.1715	.1715	.2561	.3734	.4287	.2984
Avg	.4507	.4965	.5204	.5719	.5265	.7509	.5279

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 201 / 11 KV KUNTOOR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6468	
2	.5729		.6283	
3	.5914		.6653	
4	.6099		.6838	
5	.6653		.7577	
6	.9795		1.0164	
7	1.0349		1.0719	
8	.8501		.9795	
12		.5544		
13		.499		
14		.499		.5601
24	.6468		.6468	
Max	1.0349	.5544	1.0719	.5601
Min	.5729	.499	.6283	.5601
Avg	.7439	.5175	.7885	.5601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 202 / 11 KV KUNTUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
2	.0377		
3	.0377		
4	.0377		
5	.0377		
6	.0377		
7	.0377		
8	.0566		
12		.0754	
13		.0566	
14		.0377	.2743
Max	.0566	.0754	.2743
Min	.0377	.0377	.2743
Avg	.0404	.0566	.2743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 203 / Koklegaon Ag

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	26-JUL-17
HR	Load (MW)
2	.2241
3	.2427
4	.2801
5	.3326
6	.4805
7	.7023
8	.7207
Max	.7207
Min	.2241
Avg	.4261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 204 / 11 kv New Ambika EX  
Feeder KV- 11 / OUTGOING

HV Non-Express Feeder

DATE	22-JUL-17	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0566		.0377
2	.0566		.0377
3	.0566		.0377
4	.0566		.0377
5	.0566		.0377
6	.0754		.0377
7	.0754		.0377
8	.0566		.0377
12		.0377	
13		.0377	
14		.0377	
24	.0754		.0377
Max	.0754	.0377	.0377
Min	.0566	.0377	.0377
Avg	.0629	.0377	.0377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174065 / 33 KV KUNTUR

Feeder No / Name : 205 / 11 KV KOKLEGAON GAOUTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772		.2957	
2	.2772		.2957	
3	.2957		.3142	
4	.3142		.3142	
5	.3696		.3881	
6	.4805		.499	
7	.462		.4251	
8	.3326		.3696	
12		.168		
13		.1494		
14		.168		
15				.2378
24	.2957		.3142	
Max	.4805	.168	.499	.2378
Min	.2772	.1494	.2957	.2378
Avg	.3450	.1618	.3573	.2378



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 201 / 11 KV VAZIRGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.3734	.4481	.4287	.3658	.4481
2	.4287	.3658	.4481	.4287	.3658	.4854
3	.5144	.3734	.4481	.4287	.3658	.4854
4	.6001	.4668	.4854	.5144	.4572	.5601
5	.6859	.4572	.4854	.5144	.5487	.6348
6	.6859	.4668	.5228	.6001	.6535	.6722
7	.6859	.5601	.5601	.6001	.7468	.6722
8	.6001	.5601	.5228	.6001	.6535	.7095
9	.5144	.4668	.4668	.6001	.5601	.7095
10	.3429	.4854	.4668	.6001	.5975	.6535
11	.0857	.3658	.2801	.2572	.5487	.5601
12	.4287	.3734	.2801	.2572	.5228	.5601
13	.3429	.3734	.2801	.1715	.4481	.4668
14	.3429	.3361	.2801	.1715	.3734	.3734
15	.2572	.3361	.2801	.2572	.4481	.3734
16	.3429	.3658	.2801	.3429	.7468	.5601
17	.3429	.3734	.3734	.4287	.5228	.7468
18	.4287	.4024	.3734		.5487	.7468
19	.5144	.5487		.5144	.5601	.4668
20	.0857	.5487	.4668	.5144	.5487	.4668
21	.4287	.4755	.4668	.4287	.5228	.4668
22	.3429	1.0082	.4668	.3429	.4481	.4668
23	.3429	.439	.4668	.3429	.4481	.4668
24	.4287	.3734	.4481	.4287	.3658	.4481
Max	.6859	1.0082	.5601	.6001	.7468	.7468
Min	.0857	.3361	.2801	.1715	.3658	.3734
Avg	.4251	.4540	.4173	.4249	.5153	.5500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 202 / 11 KV ANTERGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	1.0059	1.0829	.9431	1.0059	1.0456
2	.5144	1.0059	1.1203	.9431	1.0269	1.0456
3	.6001	1.0269	1.1203	.9431	1.0269	1.1203
4	.6859	1.2136	1.2696	1.0288	1.1203	1.1949
5	.7716	1.2136	1.307		1.1888	1.2696
6	.8573	1.307	1.4563		1.307	1.307
7	.8573	1.2136	1.1949		1.1203	1.2696
8	.8573	1.1203	1.1203		1.307	1.2696
9	.8573	.9145	1.1203		1.2136	1.1949
10	1.0288	.7468	1.1203		1.1203	1.1203
11	.6001	.5975	.7468		1.0456	.9335
12	.6001	.5601			1.1949	.9335
13	.6001		.5601		1.1203	.8402
14	.5144	.5853	.5601		.8779	.7468
15	.5144	.6722	.5601		1.1949	.7468
16	.6001	.6722	.5601		1.1203	
17	.7716	.695	.5601		1.1203	
18	.9431	.9511	.7468	1.286	1.0456	
19	1.1145	1.134	1.086	1.1145	1.1576	1.1203
20	1.2003	1.1706	1.1203	1.1145	1.1576	1.1203
21	1.1145	1.1706	1.1203	1.1145	1.0829	1.1203
22	1.0288	1.134	1.1203	1.0288		1.0269
23	.9431	1.0974	1.0269	.9431	1.0456	1.0269
24	.6859	1.0269	1.0829	.9431	1.0059	1.0456
Max	1.2003	1.307	1.4563	1.286	1.307	1.307
Min	.5144	.5601	.5601	.9431	.8779	.7468
Avg	.7823	.9667	.9897	1.0366	1.1133	1.0714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174069 / 33 KV BARBADA

Feeder No / Name : 203 / 11 KV BARBADA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.4572	.6722	.5144	.9335	
2	.8573	.4668	.6722	.5144	.9335	
3	1.0288	.4572	.7095	.5144	.9335	
4	1.2003	.4668	.7468	.5144	1.2136	
5	1.4575	.5487	.7468	.6859	1.4937	1.5684
6	1.6289	.6401	.8215	.7716	1.7737	1.7177
7	1.5432	.7468	.8215	.7716	1.7737	1.643
8	1.5432	.6535	.7842	.6859	1.7737	1.5684
9	1.3717	.4668	.7468	.6859	1.4632	1.419
10	1.1145	.5121	.7468	.5144	1.2803	1.307
11	.3429	.5228	.6535	.6001	1.2803	1.1203
12	.3429	.5121	.6535	.6859	.4755	1.1203
13	.4287	.6348	.5601	.6859	.4755	1.0269
14		.7468	.5601	.6001	.5487	.9335
15	.4287	.8779	.5601	.7716	.5487	.9335
16	.4287	.9709	.6535	.9431	.7468	.3734
17	.5144	1.0974	.7468	1.1145	.7682	.5601
18	.5144	1.1706	.9335	1.1145	.5487	.7468
19	1.286	1.39	1.307	1.4575	1.2071	1.307
20	1.286	1.2803	1.307	1.2003	1.134	1.1203
21	1.1145	1.0242	1.307	1.0288	1.0456	1.0269
22	1.0288	.9877	1.1203	.9431	1.0082	1.0269
23	1.0288	.9709	1.1203	.8573	.9877	.9335
24	.8573	1.1203	.9335	.8573	.9335	
Max	1.6289	1.39	1.307	1.4575	1.7737	1.7177
Min	.3429	.4572	.5601	.5144	.4755	.3734
Avg	.9654	.7801	.8285	.7930	1.0534	1.1291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 201 / 11 kv kirti

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862					2.5579	2.5652
2	2.2862					2.4326	2.4832
3	2.2862					2.6513	2.5206
4	2.2862					2.6139	2.4143
5	2.2862					2.6337	2.4272
6	2.2862					2.4832	2.396
7	2.553					2.3594	2.4508
8	2.2481					2.4874	2.396
9	2.3243					2.5579	2.6886
10	2.3011		2.4768	2.364	2.2131	2.7915	
11	2.3152		2.5339	2.3282	2.4832	2.726	
12	2.268		2.4768	2.2923	2.5206	2.8481	
13	2.2779		2.6482	2.2744	2.9235	2.6513	2.4196
14	2.2822		2.21	2.4177	2.584	2.4691	2.4958
15	2.2032		2.7435	2.6684	2.6513	2.5953	
16	2.2405	2.5072	2.4768	2.6578		2.5579	2.6673
17	2.3152	2.5968	2.4768	2.6223		2.524	2.7244
18	2.6326	2.5072	2.6482	2.5072		2.6886	2.7625
19		2.4356	2.553	2.5869		2.7538	2.6673
20		2.3461	2.572	2.64		2.652	2.572
21		2.3282	2.5911			2.6217	2.553
22		2.3282			2.3777	2.5423	2.4768
23		2.3461			2.3899	2.5393	1.9814
24	1.7147					2.5463	2.5953
Max	2.6326	2.5968	2.7435	2.6684	2.9235	2.8481	2.7625
Min	1.7147	2.3282	2.21	2.2744	2.2131	2.3594	1.9814
Avg	2.2839	2.4244	2.5339	2.4872	2.5179	2.5952	2.5129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 202 / 11 kv flemingo  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905			.1905		.3841	.0934
2	.1905			.1905		.4108	.0934
3	.1905			.1905		.3475	.0943
4	.1905			.1905		.1646	.0549
5	.1905			.1905		.0724	.056
6	.1905			.1905		.0747	.0566
7	.1334			.0953		.0732	.0934
8	.0762			.0953		.0747	.0549
9	.1143					.2926	.0914
10	.2241		.1524	.2614	.5068	.3174	
11	.5853		.1715	.3174	.5788	.3361	
12	.4108		.1905	.2987	.5601		
13	.4108		.1905	.2801	.5601	.0747	.5335
14	.5415		.2096	.3174	.4904	.3174	.4763
15	.6413		.1905	.3547	.5788	.2987	
16	.4294	.2054	.1905	.3361		.3547	.381
17	.1663	.168	.1905	.2987		.3292	
18	.2241	.1867	.1905	.2987		.168	
19		.2801	.1905	.2241		.132	.381
20		.3547	.1905	.1494		.132	.381
21		.3361	.3239	.2427		.0914	.2667
22		.3361		.3174	.3206	.0934	.4001
23		.3174			.2987	.0934	.3429
24	.381			.1905		.3361	.0934
Max	.6413	.3547	.3239	.3547	.5788	.4108	.5335
Min	.0762	.168	.1524	.0953	.2987	.0724	.0549
Avg	.2885	.2731	.1985	.2373	.4868	.2160	.2191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 203 / 11 kv advance steel  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334			.1143		.112	.1307
2	.1334			.1143		.132	.112
3	.1334			.1143		.128	.1132
4	.1334			.1143		.112	.128
5	.1334			.1143		.112	.1307
6	.1334			.1143		.128	.128
7	.1334			.1143		.1494	.112
8	.1334			.1143		.1494	.1307
9	.1524					.1463	.1307
10	.1494		.1143	.112	.1307	.1494	
11	.112		.1143	.112	.0747	.1494	
12	.1494		.1334	.1307	.0754	.1307	
13	.1463		.1334	.1307	.0754	.1307	.1334
14	.1494		.1334	.112	.0754	.112	.1334
15	.1494		.1334	.112	.1307	.112	
16	.112	.1307	.1334	.112		.0914	.1334
17	.0934		.1334	.1307		.0934	.1524
18	.0934		.1334	.112		.1307	.1524
19			.1334	.112		.1132	.1524
20			.1334	.1307		.1097	.1524
21			.1334	.1307		.1307	.1334
22			.1334	.1307	.1307	.112	.1334
23			.1334		.1307	.1132	.1334
24	.1524			.1334		.1097	.1307
Max	.1524	.1307	.1334	.1334	.1307	.1494	.1524
Min	.0934	.1307	.1143	.112	.0747	.0914	.112
Avg	.1330	.1307	.1307	.1189	.1030	.1232	.1328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 204 / 33kv flemingo

Sheddable Rural/Mix Feeder

Feeder KV- 33 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
2	.4481
Max	.4481
Min	.4481
Avg	.4481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 205 / 33 KV Venkys Express

HV Express Feeder

Feeder Feeder KV- 33 /  
OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2867			3.4294		4.0741	4.145
2	4.2867			3.4294		4.1872	4.257
3	4.2867			3.4294		4.0889	4.1872
4	4.2867			3.4294		4.1701	4.1872
5	4.5725			3.4294		4.1152	4.257
6	4.4582			3.4294		4.145	4.1701
7	4.5725			3.4865		4.225	4.1701
8	4.401			3.4294		4.1701	4.0889
9	4.5153					3.9209	4.5542
10	4.425		3.4294	3.2922	3.7466	4.1872	
11	4.313		3.4865	3.4019	3.6214	4.0889	
12	4.257		3.4294	3.4019	3.9209	4.257	
13	3.9506		3.315	3.4568	4.145	4.1152	3.4294
14	3.9209		3.6008	3.4568	4.1307	4.145	4.0009
15	3.786		3.4865	3.4019	4.145	4.1701	
16	3.8649	3.2922	3.4294	3.5665		3.8409	4.2867
17	4.0329		3.4294	3.6763		4.0889	4.2867
18	4.0175		3.4294	3.5117		4.201	2.7435
19			3.4294	3.5665	4.201	4.257	2.8578
20			3.4294	3.6214	4.1701	4.357	2.8578
21			3.4294	3.5117	4.145	4.3004	4.3439
22			3.4294	3.4019	3.8409	4.201	
23			3.4294		4.0175	4.357	4.0581
24	4.0009			3.4294		4.0329	4.257
Max	4.5725	3.2922	3.6008	3.6763	4.201	4.357	4.5542
Min	3.786	3.2922	3.315	3.2922	3.6214	3.8409	2.7435
Avg	4.2229	3.2922	3.4416	3.4631	4.0076	4.154	3.9547



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174106 / 33 KV KRUSHNUR

Feeder No / Name : 207 / 11 KV India Mega Agro  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572			.381		.3658	.415
2	.4572			.381		.3921	.3961
3	.4572			.381		.3547	.3658
4	.4572			.381		.3475	.3921
5	.4572			.381		.3395	.3018
6	.4572			.381		.3292	.2926
7	.4572			.3239		.3658	.2561
8	.4382			.2286		.3475	.2614
9	.4382					.3734	.4024
10	.4294		.5716	.3696	.5415	.5041	
11	.3921		.6478	.4435	.6722	.4938	
12	.3772		.5716	.4251	.5788	.4904	
13	.3734		.362	.4066	.4572	.4706	.5335
14	.3361		.4954	.6099	.4527	.4938	.724
15	.1867		.6668	.7392	.7167	.4854	
16	.2054	.5914	.5716	.6283		.4854	.7621
17	.3547		.6097	.499		.4024	.7621
18	.3547		.5335	.5359		.3658	.4954
19			.4763	.5544		.3921	.4763
20			.4763	.5175		.3961	.381
21			.4763	.4805		.3841	.3429
22			.4763	.4435	.3292	.4108	.4572
23			.4763		.3511	.4108	.4763
24	.4572			.381		.3547	.3921
Max	.4572	.5914	.6668	.7392	.7167	.5041	.7621
Min	.1867	.5914	.362	.2286	.3292	.3292	.2561
Avg	.3970	.5914	.5294	.4488	.5124	.4065	.4443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174111 / 33 KV NAIGAON

Feeder No / Name : 101 / Lalwandi feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.415		
2		.415		
3		.4527		
4		.4904		
5		.5658		
6		.6224		
7		.6602		
8		.679		
11				.8299
12			.679	.8676
13			.7545	.811
14			.7167	.8299
15			.679	.7733
16				.7167
18	.4904			
19	.5658			
20	.5281			
21	.4904			
22	.4527			
23	.415			
24		.415		
Max	.5658	.679	.7545	.8676
Min	.415	.415	.679	.7167
Avg	.4904	.5239	.7073	.8047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

DEGLOOR DIVSION[691]

NAIGAON (R) S/DN[450] BU 2445

Substation No/ Name :- 174111 / 33 KV NAIGAON

Feeder No / Name : 103 / 11 kv Degaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.1886	.1886			
2	.2641		.1886	.1829			
3	.2641		.2263	.2263			
4	.2926		.2641	.2641			
5	.2926		.3018	.2561			
6	.3395		.3395	.3018			
7	.3772		.3772	.3395			
8	.3772		.3772	.3772			
9			.3395	.2829	.2829		
10			.3395	.2829	.2829		
11			.2743	.2829	.2452	.5281	
12			.2829	.2829	.3018	.5093	
13			.3018	.2829	.3395	.3961	.3961
14			.3018		.3018		.3961
15			.3395		.2829		
16			.3658	.3395			
17			.3772	.3961			
18		.1509	.3395	.3961			
19		.2075	.1829	.2263			
20		.2263	.1886	.2263			
21		.2075	.2263	.2263			
22		.2075	.2641	.2829			
23		.1886	.2641	.2829			
24	.2263		.1886	.2641	.2829		
Max	.3772	.2263	.3772	.3961	.3395	.5281	.3961
Min	.2263	.1509	.1829	.1829	.2452	.3961	.3961
Avg	.2955	.1981	.2850	.2814	.2900	.4778	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 201 / 11 KV WATER WORKS

Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5544	.8688	.3696		.6584	.961
2	.9335	.5544	.8779	.3696	.9335	.6584	.9412
3		.5544	.8871	.3696		.7316	.8871
4	.9335	.5544	.8871	.3696	.9335	.7316	.8871
5		.5544	.8871	.3696	.9335	.7316	.924
6	.9335	.5544	.8871	.7392	.9335	.6401	.924
7	.9335	.5544	.7392	.5544	.9335	.5487	.961
8	.9335		.961	.5596	.9335	.5487	.961
9	.9335			.5487		.5601	.9145
10	.9335					.5601	.9145
11	.9335		.8871		.961		
12			.8871	.7316	.961		
13	.5601			.5487	.6653		.7316
14				.1829		.5601	.5316
15	.5601		.7392	.1829	.6653	.5601	.5487
16	.9335		.6653	.3658	.961	.9335	.7316
17				.5601	.9145	.924	.9335
18	.9145		.7461	.9335			.9335
19	.8413		.7461	.9335	.7316		
20	.7316	.6447	.7392	.9335	.7316	.8871	.5601
21	.7316	.6984	.7461		.7316	.6653	.3734
22	.5596	.6447	.7461		.7316	.6653	.3734
23	.5596	.905	.7392		.7316	.6516	.3734
24	.9335	.5544	.8688	.5601	.9335	.6584	.961
Max	.9335	.905	.961	.9335	.961	.9335	.961
Min	.5596	.5544	.6653	.1829	.6653	.5487	.3734
Avg	.8219	.6107	.8161	.5359	.8511	.6776	.7775

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 202 / 11 KV GURUDWARA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5493	.7316	.5487		.6584	.6584
2	.5487	.5487	.7316	.5487	.7316	.6219	.6584
3		.5487	.7682	.5487		.5853	.7133
4	.5487	.5487	.7682	.5487	.7316	.5487	.6584
5		.5487	.823	.6401	.7316	.5487	.7316
6	.7316	.5487	.823	.7324	.823	.5853	.7316
7	.9145	.6401	.823	.8422	.9145	.9145	.8413
8	.9145		.8048	.5127	.7316	.823	.8871
9	.7316			.6584		.9145	.823
10	.7316					.823	.823
11	.823		.8048		.8048		
12			.6584	.823	.7316		
13	.6401		.6219	.7316	.5853		.7316
14			.6219	.7316		.7316	.7316
15	.6401		.5853		.6584	.6401	.7316
16	.6401		.6584	.7316	.7392	.7316	.7316
17	.7682			.7316	.8048	.7316	.7316
18	.8779		.8788	.7316			.823
19	.9511	.8048	.8422	1.0059	.9145		
20	1.829	.7682	.844	.9145	.9145	.7682	1.7375
21	.9145	.7682			.823	.8048	.7316
22	.7324	.7316	.7324		.7316	.7316	.7316
23	.6965	.695	.6605		.7316	.6584	.6401
24	.6401	.6408	.7316	.6408	.7316	.6584	.6584
Max	1.829	.8048	.8788	1.0059	.9145	.9145	1.7375
Min	.5487	.5487	.5853	.5127	.5853	.5487	.6401
Avg	.8039	.6417	.7457	.7013	.7686	.7095	.7860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 203 / 11 KV SOMESH COLONEY

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1752	1.3717	1.2656		1.2803	1.386
2	1.4327	1.1752	1.386	1.2656	1.2536	1.2803	1.386
3		1.1752	1.386	1.2656		1.4632	1.2936
4	1.4327	1.1641	1.386	1.2656	1.2536	1.4632	1.3575
5		1.1641	1.6632	1.356	1.3432	1.5546	1.7556
6	1.5223	1.2536	1.6632	1.4464	1.3432	1.6461	1.7556
7	1.6118	1.356	1.7194	1.6272	1.7013	1.829	1.848
8	1.6118		1.6289	1.6272	1.7013	1.829	1.6289
9	1.7909			1.829		1.7909	2.1948
10	1.7909					2.0595	2.1948
11	1.8804		1.7556		2.4025		
12			1.7194	2.5606	2.2177		
13	2.0595			2.5606	2.2177		2.5606
14			2.2177	2.5606		2.0595	2.3777
15	1.7909		2.1253		2.1253	2.0595	2.1948
16	1.7013		2.2177	2.7435	2.2177	1.97	2.1948
17	2.0119		2.26	2.3282	2.7435	2.0328	2.1491
18	2.3777		2.3504	2.1491			2.1491
19	2.3777	1.848	2.3504	2.5072	2.7435		
20	2.3777	1.6632	2.26	2.3282	2.5606	2.0328	2.1491
21	2.1948	1.5708	1.808		2.0119	1.848	1.7909
22	1.7176	1.5708	1.5368		1.6461	1.5708	1.6118
23	1.4464	1.4784	1.4464		1.4632	1.386	1.4327
24	1.4327	1.2656	1.2936	1.2656	1.3432	1.2803	1.386
Max	2.3777	1.848	2.3504	2.7435	2.7435	2.0595	2.5606
Min	1.4327	1.1641	1.2936	1.2656	1.2536	1.2803	1.2936
Avg	1.8190	1.3739	1.7879	1.8862	1.9050	1.7071	1.8475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 204 / 11 KV VAZIRABAD

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823	.9145	.9174		1.2803	.9145
2	.8954	.823	1.0059	.9174	.9145	1.1888	.9145
3		.823	1.0059	.9174		1.0974	.9145
4	.9145	.823	1.0974	.9174	.9145	1.0631	1.1888
5		.823	1.1888	.9174	1.0059	1.0974	1.1888
6	1.1888	.9145	1.1888	1.0641	1.2803	1.0974	1.2071
7	1.2803	1.0059	1.2803	1.1375	1.2803	1.1888	1.2437
8	1.1888		1.2437	1.2843	1.2803	1.2803	1.2936
9	1.2803			1.0242		1.2803	1.1888
10	1.3717					1.3717	1.1888
11	1.4632		1.4632		1.4632		
12			1.4266	1.6461	1.4632		
13	1.5546			1.4632			1.4632
14			1.4632	1.4632		1.4632	1.2803
15	1.4632					1.4632	1.1888
16	1.4632			1.4998		1.4632	1.4632
17	2.0119			1.6461		1.6095	1.6461
18	1.6827		1.8347	1.6461			1.6461
19	1.7558	1.5729	1.9081	1.9204	2.3777		
20	1.829	1.4632	1.9081	2.0119	2.3777	1.9204	1.7375
21	1.6461	1.4632	1.6844		1.4175	1.4266	1.5546
22	1.1765	1.1706	1.321		1.4632	1.1888	1.0974
23	1.0136	.9877	1.2136		1.3717	.9877	1.0059
24	1.0059	.9145	.9145	1.0091	1.0059	1.2803	.9877
Max	2.0119	1.5729	1.9081	2.0119	2.3777	1.9204	1.7375
Min	.8954	.823	.9145	.9174	.9145	.9877	.9145
Avg	1.3782	1.0467	1.3368	1.3002	1.4011	1.3025	1.2530

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174042 / 33 kV NTC

Feeder No / Name : 205 / 11 KV Khadakpura

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1088	1.2012	1.1564		1.0974	1.1765
2	1.1203	1.1088	1.2012	1.1191	1.1203	1.0974	1.1765
3		1.1088	1.386	1.1191		1.1888	1.2012
4	1.1203	1.1191	1.386	1.2124	1.2136	1.2803	1.267
5		1.3989	1.587	1.3802	1.307	1.4632	1.4632
6	1.6804	1.5295	1.6632	1.6041	1.6804	1.6461	1.5565
7	1.9605	1.6632	1.922	1.8838	1.9605	1.9204	1.9909
8	1.9605		2.0668	2.0517	2.1472	1.829	2.2731
9	2.0538			1.9204		1.9605	2.3777
10	1.8671					1.587	2.1948
11	1.587		1.5154		1.6632		
12				1.4632	1.6078		
13	1.4003			1.4632	1.423		1.829
14				1.134		1.4937	1.4632
15	1.2136		1.4045		1.3121	1.307	1.2803
16	1.307		1.2936	1.2803	1.2936	1.307	1.2803
17	1.6461		1.5708	1.587	1.4632	1.4784	1.587
18	1.9022		1.8111	1.8671			1.9605
19	1.829	2.1068	1.9025	2.3339	2.0119		
20	1.829	1.7926	1.6414		2.0119	1.6632	1.7737
21	1.7558	1.7926	1.4784		1.6461	1.4118	1.587
22	1.4415	1.7556	1.4175		1.3717	1.4045	1.4003
23	1.3056	1.2803	1.2567		1.2803	1.4415	1.307
24	1.2136	1.2124	1.1827	1.1564	1.2136	1.1888	1.1827
Max	2.0538	2.1068	2.0668	2.3339	2.1472	1.9605	2.3777
Min	1.1203	1.1088	1.1827	1.1191	1.1203	1.0974	1.1765
Avg	1.5891	1.4598	1.5204	1.5137	1.5404	1.4614	1.5871



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 201 / 11 KV COLLECTOR OFFICE

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554		.0549	.0686		.0732
2				.0514		.0732
3	.0543					.0732
4			.0554			.0732
5						.0716
6	.0537		.0724			.0701
7	.0532			.0686		.0701
8	.0686		.0351	.0686		.0716
9	.0709	.0514		.0514	.0543	.0709
10	.0732			.0514	.0739	
11		.0514		.0514		
12	.0732	.0514		.0514		
13	.0732			.0514	.0358	
14		.0171				
15		.0343		.0343		
16		.0343		.0343	.0351	
17		.0724	.0514		.0709	.0686
18		.0554	.0686			
19			.0686		.0709	
20			.0514		.0724	.0701
21			.0343		.0732	
22		.0532	.0343			
23		.0526	.0343		.1097	
24			.0554			.0732
Max	.0732	.0724	.0724	.0686	.1097	.0732
Min	.0532	.0171	.0343	.0343	.0351	.0686
Avg	.0640	.0474	.0513	.0530	.0662	.0716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 202 / 11 KV CHIKHALWADI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501		.7316	.823		.7682
2				.7716		.7682
3	.7602					.7316
4						.7316
5						.788
6	.788		.9412			.9114
7	.815			.8573		.8413
8	.6859		.7712	.7888		.8596
9	.815	.7202		.7716	.7964	.8505
10	.8413			.823	.8501	
11		.8573		.9259		
12	1.0974	.9259		.9945		
13	1.0974			1.0288	1.0029	
14		.9602				
15		.9602		1.0288		
16		.9602		1.0288	.9465	
17		1.086	1.0974		1.0631	1.0288
18		1.1827	1.2003			
19			1.3032		1.2757	
20			1.3032		1.3032	1.1919
21			1.1317		1.0974	
22		.9214	.9602			
23		.7712	.8573		.8779	
24			.7392			.8413
Max	1.0974	1.1827	1.3032	1.0288	1.3032	1.1919
Min	.6859	.7202	.7316	.7716	.7964	.7316
Avg	.8611	.9345	1.0033	.8947	1.0237	.8594

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 203 / 11 KV GRANTH BHAVAN

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0554		.0549	.0514		.0549
2				.0514		.0549
3	.0543					.0549
4			.0554			.0732
5						.0716
6	.0358		.0362			.0526
7	.0354			.0514		.0351
8	.0343		.0351	.0351		.0358
9	.0354	.0343		.0343	.0543	.0354
10	.0366			.0343	.037	
11		.0343		.0343		
12	.0366	.0343		.0343		
13	.0366			.0343	.0358	
14		.0343				
15		.0343		.0343		
16		.0343		.0343	.0351	
17		.0362	.0343		.0354	.0343
18		.037	.0343			
19			.0343		.0354	
20			.0514		.0362	.0526
21			.0514		.0549	
22		.0532	.0514			
23		.0526	.0514		.0549	
24			.0554			.0549
Max	.0554	.0532	.0554	.0514	.0549	.0732
Min	.0343	.0343	.0343	.0343	.0351	.0343
Avg	.0400	.0385	.0455	.0390	.0421	.0509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 205 / 11 KV OLD MONDHA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088		1.2437	1.3717		1.134
2				1.3717		1.0974
3	1.0136					1.0974
4			1.1827			1.0974
5						1.1104
6	1.2178		1.267			1.262
7	1.2048			1.2346		1.262
8	1.2003		1.1568	1.2003		1.2178
9	1.2048	1.166		1.2003	1.1584	1.134
10	1.2437			1.2003	1.2197	
11		1.1317		1.2003		
12	1.1706	1.0631		1.2346		
13	1.2437			1.286	1.1462	
14		1.0631				
15		1.0288		1.1317		
16		1.0631		1.1317	1.0517	
17		1.1584	1.0974		1.0631	.9945
18		1.2567	1.2346			
19			1.3717		1.4175	
20			1.4575		1.1584	1.4022
21					1.2437	
22		1.2757	1.4746			
23		1.3321	1.406		1.2071	
24			1.2936			1.1706
Max	1.2437	1.3321	1.4746	1.3717	1.4175	1.4022
Min	1.0136	1.0288	1.0974	1.1317	1.0517	.9945
Avg	1.1787	1.1539	1.2896	1.2330	1.1851	1.1650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 206 / 11 KV SACHKHAND

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066		.439	.3772		.4755
2				.3429		.4755
3	.362					.4024
4			.3696			.3292
5						.2686
6	.2149		.2172			.2629
7	.1772			.2229		.1753
8	.2401		.2103	.2401		.1791
9	.2481	.2058		.2058	.181	.2126
10	.2561			.2401	.1848	
11		.2058		.2572		
12	.1829	.2058		1.2346		
13	.2195			.2401	.1791	
14		.1715				
15		.1886		.3429		
16		.1886		.3429	.1753	
17		.2172	.2401		.1772	.2058
18		.2218	.2915			
19			.3086		.2481	
20			.3601		.5068	.3506
21					.3658	
22		.3544	.3429			
23		.4207	.4115		.5121	
24			.4435			.439
Max	.4066	.4207	.4435	1.2346	.5121	.4755
Min	.1772	.1715	.2103	.2058	.1753	.1753
Avg	.2564	.2380	.3304	.3679	.2811	.3147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174074 / 33 kV GURUDAWARA

Feeder No / Name : 207 / 11 KV RAILWAY HOSPITAL

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109		.1097	.12		.1097
2				.1029		.1097
3	.1086					.1097
4			.1109			.1097
5						.1075
6	.1254		.1086			.1052
7	.1417			.1543		.1052
8	.1029		.1402	.1372		.1075
9	.1063	.1372		.12	.1086	.1063
10	.1097			.1372	.1109	
11		.1029		.1372		
12	.1097	.1372		.1372		
13	.1097	.1372		.12	.1433	
14		.1372				
15		.12		.2401		
16		.12		.1715	.1052	
17		.1086	.1029		.1063	.1029
18		.1109	.1029			
19			.1029		.1063	
20			.1029		.1086	.1227
21			.1543		.1097	
22		.1063	.1372			
23		.1052	.12		.1097	
24			.1109			.1097
Max	.1417	.1372	.1543	.2401	.1433	.1227
Min	.1029	.1029	.1029	.1029	.1052	.1029
Avg	.1139	.1202	.1170	.1434	.1121	.1088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 201 / 11 KV BILAL NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1088	1.1088	1.0974	1.1088	1.1088	1.2936
2	1.1088	1.1088	1.1088	1.0974	1.1088	1.1088	1.2936
3	1.1088	1.1088	1.1088	1.0974	1.1088	1.1088	1.2936
4	1.1088	1.1088	1.1088	1.0974	1.1088	1.1088	1.2936
5	1.1088	1.2936	1.1088	1.1088	1.1088	1.1088	1.2936
6	1.1088	1.386	1.2936	1.2936	1.1088	1.2012	1.4784
7	1.2936	1.386	1.4784	1.6632	1.2936	1.2936	1.6632
8	1.2936	1.4003	1.4784	1.6632	1.2936	1.307	1.848
9	1.2936		1.307	1.4937		1.1088	1.7918
10	1.2936					1.1088	1.3108
11	1.1088		1.1088	1.2936	1.4632		
12	1.1088		1.1088	1.1088	1.2936		
13	1.1088		1.1088	1.1088	1.2936	1.2936	1.587
14			1.1088	1.1088		1.2936	1.4632
15	1.1088		1.1088	1.0974	1.0974	1.2936	1.307
16			1.2012	1.2803	1.0974	1.2803	
17	1.2012			1.2936	1.0974	1.4784	1.2936
18	1.386		1.4784	1.2936		1.848	1.4632
19	1.4784	1.2936	1.2936	1.4784	1.587		
20	1.4784	1.2936	1.2936	1.4784		1.4784	1.386
21	1.2936	1.1088	1.2012	1.2936	1.2803	1.4784	1.386
22	1.2936	1.1088	1.2936	1.1088	1.1088	1.4784	1.386
23	1.1088	1.1088	1.0974	1.1088	1.2012	1.2936	1.0974
24	1.1088	1.1088	1.1088	1.1088	1.1088	1.1088	1.2936
Max	1.4784	1.4003	1.4784	1.6632	1.587	1.848	1.848
Min	1.1088	1.1088	1.0974	1.0974	1.0974	1.1088	1.0974
Avg	1.2096	1.2088	1.2097	1.2510	1.2036	1.2804	1.4112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 202 / 11 KV RLY TRACK

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.848	1.848	1.6461	1.848	1.848	1.6632
2	1.4784	1.848	1.848	1.6461	1.6632	1.848	1.6632
3	1.6632	1.848	1.6632	1.6461	1.6632	1.848	1.6632
4	1.848	1.848	1.6632	1.6461	1.6632	1.848	1.6632
5	1.848	1.848	1.6632	1.6461	1.6632	1.848	1.6632
6	1.6632	1.6632	1.6632	1.6632	1.6632	1.848	1.848
7	1.6632	1.6632	1.848	1.7556	1.848	1.848	1.848
8	1.848	1.9605	2.0328	1.848	1.848	1.8671	2.0328
9	2.0328		2.0538	2.0538		2.0328	2.3577
10	2.0328					2.0328	1.8842
11	1.848		1.848	1.848	2.0328		
12	1.848		1.848	1.848	1.848		
13	1.6632		1.848	1.848	1.848	1.848	2.5206
14			1.6632			1.6632	1.829
15	1.4784		1.7556	1.829	1.5546	1.4784	1.6804
16	1.4784		1.6632	1.829	1.6461	1.4632	1.6804
17				1.6632	1.6461	1.6632	1.6632
18	1.848	1.848	1.6632	1.848		1.9909	1.829
19	2.2177	2.2177	2.0328	2.0328	2.1472	2.0328	
20	2.0328	2.2177	2.0328	2.4025		2.0328	2.1253
21	2.0328	2.0328	1.9404	2.0328	2.0119	1.848	1.9404
22	2.0328	2.0328	1.848	1.848	1.848	1.848	1.848
23	1.848	1.848	1.829	1.848	1.848	1.848	1.829
24	1.4784	1.848	1.848	1.848	1.848	1.848	1.6632
Max	2.2177	2.2177	2.0538	2.4025	2.1472	2.0328	2.5206
Min	1.4784	1.6632	1.6632	1.6461	1.5546	1.4632	1.6632
Avg	1.7892	1.9048	1.8229	1.8307	1.7968	1.8379	1.8522



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 203 / 11 KV DEGLOOR NAKA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2177	2.2177	2.2177		2.2177	2.5873	2.2177
2	2.2177	2.2177	2.2177	2.1948	2.2177	2.4025	2.2177
3	2.0328	2.2177	2.2177	2.1948	2.0328	2.4025	2.2177
4	2.0328	2.2177	2.2177	2.1948	2.0328	2.2177	2.2177
5	2.2177	2.2177	2.2177	2.1948	2.2177	2.2177	2.2177
6	2.2177	2.2177	2.4025	2.2177	2.2177	2.2177	2.4025
7	2.2177	2.2177	2.5873	2.2177	2.4025	2.4025	2.5873
8	2.2177	2.8006	2.5873	2.4025	2.5873	2.6139	2.9569
9	2.5873		2.6139	2.6139		2.5873	3.3951
10	2.5873					2.5873	2.9492
11	2.5873		2.5873	2.5873	2.5873		
12	2.2177		2.2177				
13	2.0328		2.2177	2.9569		2.2177	3.3608
14				2.5873		2.2177	2.5606
15	2.2177			2.3777			2.2405
16	2.2177		2.5873	2.1948	2.3777		2.0538
17		2.2177		2.2177	2.7435		2.0328
18	2.5873	2.2177	2.5873	2.5873			2.1948
19	2.7721	2.5873	2.9569	2.9569	2.9874		
20	2.5873	2.5873	2.7721	2.9569		2.9569	2.5873
21	2.5873	2.5873	2.5873	2.5873	2.9264	2.5873	2.4025
22	2.5873	2.5873	2.5873	2.5873	2.2177	2.5873	2.5873
23	2.2177	2.5873	2.1948	2.5873	2.5873	2.4025	2.1948
24	2.2177	2.2177	2.2177	2.2177	2.2177	2.5873	2.2177
Max	2.7721	2.8006	2.9569	2.9569	2.9874	2.9569	3.3951
Min	2.0328	2.2177	2.1948	2.1948	2.0328	2.2177	2.0328
Avg	2.3353	2.3696	2.4396	2.4587	2.4107	2.4584	2.4673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-I[442] BU 2411

Substation No/ Name :- 174077 / 33 kV CHOUPHALA

Feeder No / Name : 204 / 11 KV KHUDWAI NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4784	1.4784	1.4784	1.4632	1.4784	1.4784	1.4784
2	1.4784	1.4784	1.4784	1.4632	1.4784	1.4784	1.4784
3	1.4784	1.4784	1.2936	1.4632	1.4784	1.4784	1.4784
4	1.4784	1.4784	1.2936	1.4632	1.4784	1.4784	1.4784
5	1.4784	1.6632	1.2936	1.4632	1.4784	1.4784	1.4784
6	1.4784	1.6632	1.4784	1.4784	1.6632	1.4784	1.6632
7	1.6632	1.6632	1.6632	1.6632	1.848	1.7556	1.848
8	1.6632	1.6804	1.848	1.6632	1.848	1.8671	2.2177
9	1.848		1.8671	1.6804		1.848	2.1691
10	1.848					1.848	1.8023
11	1.6632		1.4784	1.4784	1.4784		
12	1.4784		1.4784	1.6632	1.4784		
13	1.4784		1.4784	1.4784	1.386	1.2936	2.0538
14			1.2936	1.2936		1.2936	1.4632
15	1.2936		1.2936	1.2803		1.2936	1.307
16	1.2936		1.2936	1.2803	1.829	1.2803	1.307
17		1.6632		1.4784	1.4632	1.4784	1.386
18	1.7556	1.6632	1.7556	1.6632		1.848	1.6461
19	1.848	1.848	1.848	1.848	1.8671	1.848	
20	1.848	1.6632	1.7556	1.848		1.6632	1.6632
21	1.6632	1.6632	1.5708	1.6632	1.7375	1.6632	1.5708
22	1.6632	1.6632	1.4784	1.6632	1.6632	1.4784	1.4784
23	1.4784	1.6632	1.4632	1.4784	1.5708	1.4784	1.4632
24	1.4784	1.4784	1.4784	1.4784	1.4784	1.4784	1.4784
Max	1.848	1.848	1.8671	1.848	1.8671	1.8671	2.2177
Min	1.2936	1.4784	1.2936	1.2803	1.386	1.2803	1.307
Avg	1.5834	1.6181	1.5164	1.5390	1.5946	1.5585	1.6147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 201 / 11 KV VISHNUPURI

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.924			.8316			.924
4						1.1088	
6	1.1088			1.1088			1.1088
7			1.1763			1.1576	
8	1.2012						
9	1.0456		1.1088	1.1088		1.0456	1.1088
10				.8779			
12	.8215				.9511		
13			.7392	.7316			
14						.924	
15	.8589		.7762	.7316	1.0242		
16			.8316		.8059		
17				.7468			
18	.8871						
19			.924				
20	.8779				1.0164		
21		.9979		1.1949			
22			.924		1.0164		
23	.9335	.9145		.8962			
24	.7947		.924	.8316		.8779	.924
Max	1.2012	.9979	1.1763	1.1949	1.0242	1.1576	1.1088
Min	.7947	.9145	.7392	.7316	.8059	.8779	.924
Avg	.9453	.9562	.9255	.9060	.9628	1.0228	1.0164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 202 / 11 KV WAJEGAON (OLD  
TUPPA) Feeder KV- 11 /  
OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1478			.1478			.1478
4						.1848	
6	.1478			.1848			.1848
7			.1867			.2241	
8	.1478						
9	.112		.1848	.1478		.1867	.1848
10				.1463			
12	.112				.1097		
13			.1478	.112			
14						.1463	
15	.112		.1478	.112	.1097		
16			.1478		.1075		
17				.1097			
18	.1494						.1494
19			.1478				
20	.112				.2033		.1494
21				.112			
22			.1294		.1294		
23	.112	.0366		.112			.112
24	.1478		.1109	.1478		.128	.1478
Max	.1494	.0366	.1867	.1848	.2033	.2241	.1848
Min	.112	.0366	.1109	.1097	.1075	.128	.112
Avg	.1301	.0366	.1504	.1332	.1319	.1740	.1537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 203 / 11 KV BHAGYLAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.037			.037			.037
4						.037	
6	.0739			.037			.037
7			.0373			.0554	
8	.0739						
9	.0747		.037	.037		.0373	.037
10				.0914			.0373
12	.0747				.0549		.0554
13			.037	.0366			
14						.037	
15	.0747		.037	.0366	.0549		.056
16			.037		.0537		
17				.0554			
18	.0747						.056
19			.037				
20	.056				.037		.056
21				.0373			
22			.037		.037		
23	.0373	.0229		.056			.056
24	.037		.037	.037		.0366	.037
Max	.0747	.0229	.0373	.0914	.0549	.0554	.056
Min	.037	.0229	.037	.0366	.037	.0366	.037
Avg	.0614	.0229	.0370	.0461	.0475	.0407	.0465

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 204 / 11 KV CHOUPHALA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	1.2936			1.2197			1.2936
4						1.8111	
6	2.1253						2.1253
7			2.0911	1.4784		1.9605	
8	2.0328						
9	1.6632		1.6263	1.2936		1.9978	1.848
10				.9145			1.8671
12	1.2197				1.2803		1.4784
13			1.1088	1.2803			
14						1.2936	
15	1.2936		1.1088	1.0974	1.0608		
16			1.2936		1.1641		
17				1.2936			
18	1.5684						1.5154
19			1.4784				
20	1.8671				1.5893		1.8671
21				1.6057			
22			1.2936		1.5524		
23	1.2696	1.2437		1.3443			1.2323
24	1.1088		1.2567	1.1088		1.2437	1.2936
Max	2.1253	1.2437	2.0911	1.6057	1.5893	1.9978	2.1253
Min	1.1088	1.2437	1.1088	.9145	1.0608	1.2437	1.2323
Avg	1.5442	1.2437	1.4072	1.2636	1.3294	1.6613	1.6134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 206 / 11 KV SHRINIWASA

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2957			.3696			.3696
4						.462	
6	.3326			.3326			.2772
7			.4668			.3734	
8	.3326						
9	.3361		.3696	.3326		.4294	.2218
10				.439			
12	.8962				.3292		
13			.3326	.4572			
14						.4251	
15	.3734		.462	.4755	.4755		
16			.462		.4477		
17				.4854			
18	.3658						
19			.462				
20	.2614				.2218		.3361
21				.4668			
22			.462		.1848		
23	.2241	.4572		.4668			.2987
24	.3142		.462	.3696		.2195	.3696
Max	.8962	.4572	.4668	.4854	.4755	.462	.3696
Min	.2241	.4572	.3326	.3326	.1848	.2195	.2218
Avg	.3732	.4572	.4349	.4195	.3318	.3819	.3122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174023 / 33 kV MIDC

Feeder No / Name : 207 / 11 Kv Water works

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3696			.3696			.3696
4						.3696	
6	.4435			.3696			.4066
7			.4481			.3734	
8	.4435						
9	.4481		.5175	.4435		.3361	.4066
10				.5487			.4854
12	.7468				.5853		.7842
13			.6653	.7682			
14						.2743	
15	.6348		.7762	.7842	.5487		.6283
16			.8316		.5731		
17				.7842			
18	.7468						.7023
19			.5914				
20	.4854				.5914		.3734
21				.3734			
22			.4066		.4435		
23	.4108	.439		.4108			.3361
24	.3696		.4066	.4066		.3658	.3696
Max	.7468	.439	.8316	.7842	.5914	.3734	.7842
Min	.3696	.439	.4066	.3696	.4435	.2743	.3361
Avg	.5099	.439	.5804	.5259	.5484	.3438	.4862



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 201 / 11 KV NANAKSAR GAUTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.2629	.3506	
16			.543		.1753	.2804	.2534
24	.1402	.1448		.1402			
Max	.1402	.1448	.543	.1402	.2629	.3506	.2534
Min	.1402	.1448	.543	.1402	.1753	.2804	.2534
Avg	.1402	.1448	.543	.1402	.2191	.3155	.2534

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 202 / 11 KV VIDYAPEETH

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.3506	
16				.6135	.5609	.543
24	.3155	.2534	.2804			
Max	.3155	.2534	.2804	.6135	.5609	.543
Min	.3155	.2534	.2804	.6135	.3506	.543
Avg	.3155	.2534	.2804	.6135	.4558	.543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 203 / 11 KV GANGABET

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.4031	.3506	
16			.2715		.3155	.3506	.362
24	.2629	.2534		.2103			
Max	.2629	.2534	.2715	.2103	.4031	.3506	.362
Min	.2629	.2534	.2715	.2103	.3155	.3506	.362
Avg	.2629	.2534	.2715	.2103	.3593	.3506	.362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 204 / 11 KV PIMPALGAON

Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	26-JUL-17
HR	Load (MW)
10	.2353
Max	.2353
Min	.2353
Avg	.2353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 205 / 11 KV KALESHWAR AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	27-JUL-17
HR	Load (MW)
10	.0175
Max	.0175
Min	.0175
Avg	.0175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 208 / 11 KV GODAWARI AG  
Feeder KV- 11 / OUTGOING

Ag dominated/Pure Ag

DATE	26-JUL-17
HR	Load (MW)
10	.0175
Max	.0175
Min	.0175
Avg	.0175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174073 / 33 kV VISHNUPURI

Feeder No / Name : 209 / 11 KV VISHNUPURI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10					.6154	.5609	.6335
16	.4344		.4525		.4557	.4207	.4344
24	.6135	.5068		.4908			
Max	.6135	.5068	.4525	.4908	.6154	.5609	.6335
Min	.4344	.5068	.4525	.4908	.4557	.4207	.4344
Avg	.5240	.5068	.4525	.4908	.5356	.4908	.5340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 201 / 11 kV NAGAPUR G

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4467		.3658
2				.484		.3658
3				.5228		.462
4				.6722		.5544
5				.7842		.6535
6				.8962		.8402
7				.8962		.9431
8				.7468		.9431
9		.5228				
10		.6735				
11		.6735				
12	.3244					.5975
13	.2654	.3368				
14		.3704				.6036
15	.2905	.3299				
16	.4422				.415	.8962
17	.5068		.5584		.415	
18	.6141		.7095			.6584
19	.6154					
20	.5889				.8488	
21						.6722
22			.4108			
23		.6283	.3734		.5658	
24			.6219	.3704		.3658
Max	.6154	.6735	.7095	.8962	.8488	.9431
Min	.2654	.3299	.3734	.3704	.415	.3658
Avg	.4560	.5050	.5348	.6466	.5612	.6373



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 202 / 11 kV PUNEGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1517	.1524
2			.1834	.1524
3			.1834	.2286
4			.1834	.2286
5			.2445	.2286
6			.2761	
7			.3067	.4572
8			.2457	.4572
9		.2881		
12	.2241			
13	.1951			
15	.1294			
16	.1658			
17	.103			
18	.169			
Max	.2241	.2881	.3067	.4572
Min	.103	.2881	.1517	.1524
Avg	.1644	.2881	.2219	.2721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 203 / 11 kV TUPPA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
14	.055			.061
15	.0553			
16	.055		.1219	.061
17		.0732	.0625	.0584
18		.0732		.0588
Max	.0553	.0732	.1219	.061
Min	.055	.0732	.0625	.0584
Avg	.0551	.0732	.0922	.0598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 204 / 11 kv New Wajegaon

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.898		.7545	
2				.898		.7545	
3				.9709		.7545	
4				1.0509			
5				1.201		.9431	
6				1.28		1.1317	
7				1.3553		1.358	
8				1.315		1.3203	
9		1.1203					
10		1.1635					
11	1.1623	1.0829					
12	1.0873	.9335				.8299	
13	.8249	.8589					
14		.7778				.679	
15	.8624	.7468					
16	.7874				.9431	.7167	
17			.8232		.9431	.8606	
18	1.1998		1.16			1.16	
19	1.2748		1.2761			1.0884	
20	.9749		.9788		1.1317	.9355	
21			.9335			.8299	
22			.8935			.7842	
23		.8589	.8889		.7545	.7468	
24				.8632			.7468
Max	1.2748	1.1635	1.2761	1.3553	1.1317	1.358	.7468
Min	.7874	.7468	.8232	.8632	.7545	.679	.7468
Avg	1.0217	.9428	.9934	1.0925	.9431	.9204	.7468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 205 / 11 kv Injegaon AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	25-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1077	.112
2			.107	.112
3			.107	.1494
4			.1092	.1509
5			.1819	.1886
6			.1833	.1886
7			.184	.2263
8			.1475	.2263
9		.185		
10		.0736		
12	.1495			
13	.1495			
15	.1121			
16	.1495			
17	.1495			
18	.1121			
Max	.1495	.185	.184	.2263
Min	.1121	.0736	.107	.112
Avg	.1370	.1293	.1410	.1693

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174096 / 33 kV TUPPA (DHANEGAON)

Feeder No / Name : 206 / 11Kv MARATHWADA EXPRESS SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0823		.0823
2				.0821		.0823
3				.0821		.0846
4				.0821		
5				.0821		.0846
6				.0821		
7				.0823		
8				.0825		.0869
9		.1651				
10		.1651				
11	.2567	.1658				
12	.2888	.1934				.2107
13	.3208	.1658				
14		.1651				.1219
15	.1925	.1651				
16	.2567				.2286	.1524
17			.1376		.2286	
18	.1925		.1926			
19	.2246		.1372			
20	.2246		.1372			
21			.1094			.1189
22			.1097			
23		.0903	.1097		.0914	
24				.1097		
Max	.3208	.1934	.1926	.1097	.2286	.2107
Min	.1925	.0903	.1094	.0821	.0914	.0823
Avg	.2447	.1595	.1333	.0853	.1829	.1138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 201 / 11 KV R.T.O.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.5525	.7049	.8002	.6859	.724	.4763
2	.6859	.5525	.7049	.8002	.6859	.724	.4763
3	.6478	.5525	.7049	.8002	.6859	.724	.4763
4	.6097	.5525	.7049	.8002	.6859	.7049	.4763
5	.6097	.5525	.7049	.8002	.6859	.6859	.4763
6	.6097	.5525	.7049	.8002	.6859	.6859	.6097
7	.6097	.5716	.6668	.7621	.6097	.6287	.5716
8	.6097		.6287	.8002	.6097	.5906	.5716
9	.8002		.7621	.8383		.5335	.6097
10	1.1431			1.3336		.4572	1.0374
11	1.2384		1.2955	1.4861	.9145		
12	1.2384		1.2574	1.6766	1.2193		
13	1.105		1.1622	1.5623	.9907	.6097	1.0669
14	1.1812		1.2193	1.448		.6097	.8192
15	1.3527		1.5089	1.5623	.9907	.5335	
16	1.1431		1.4289	1.3527	1.3717	.5335	.8573
17	1.3717	1.3146		1.448	1.4289	.4572	.9145
18	1.2003	1.105	1.1812	1.3717		.4572	.7621
19	1.0374	.8002	.8954	1.3717	.9717		
20	.6287	.7621	.8383	1.1431	.7621	.4763	.8002
21	.6287	.7621	.7621	.7621	.7621	.4763	.5335
22	.6097	.7049	.8002	.7621	.7621	.4763	
23	.6287	.7049	.8002	.7621	.7621	.4763	.6859
24	.6859	.5716	.7049	.8002	.6859	.8002	.4763
Max	1.3717	1.3146	1.5089	1.6766	1.4289	.8002	1.0669
Min	.6097	.5525	.6287	.7621	.6097	.4572	.4763
Avg	.8776	.7075	.9155	1.0852	.8478	.5888	.6683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 202 / 11 KV NANDED FLOOR MILL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	1.0288	1.2384	1.0479	.9907	.9717	.6859
2	.7621	1.0479	1.2384	1.0479	.9907	.9526	.6859
3	.7621	1.0479	1.2384	1.0479	.9907	.9526	.6859
4	.7621	1.0479	1.2384	1.0479	.9907	.9526	.6859
5	.7621	1.0098	1.2384	1.0479	.9907	.9526	.6859
6	1.2193	.9526	1.2765	1.0479	1.1431	1.1431	.9526
7	1.2193	.9526	1.2765	1.0479	1.2193	.9717	.9526
8	1.1431		1.2955	1.0479	1.2193	.8383	.9526
9	1.1241		1.2193	1.0479		.7621	.9335
10	1.4861			1.1622		.6859	1.3146
11	1.7528		1.829	1.2955	1.9052		
12	1.9433		1.5813	1.4289	1.9052		
13	1.9052		1.448	1.448	1.6004	.6859	1.2574
14	1.9433		1.4098	1.4861		.6859	1.3717
15	1.9624		1.7528	1.448	1.6004	.6859	
16	1.5242		1.5242	1.7147	1.6766	.6859	1.448
17	1.6194	1.3527		1.6004	.4066		1.3717
18	1.4289	1.2384	1.5051	1.2193			.9145
19	1.086	1.105	1.1622	1.1431	1.0479		
20	1.0479	1.1812	1.0669	1.105	1.0098	.6859	.9145
21	1.0669	1.1431	1.086	1.0669	1.0479	.6859	.9145
22	1.1431	1.2003	1.0479	1.0669	1.0288	.6859	
23	1.0288	1.1812	1.0479	1.0669	.9907	.6859	.8383
24	.7621	1.0288	1.1812	1.0479	.9907	.9717	.6859
Max	1.9624	1.3527	1.829	1.7147	1.9052	1.1431	1.448
Min	.7621	.9526	1.0479	1.0479	.4066	.6859	.6859
Avg	1.2590	1.1012	1.3137	1.1971	1.1873	.8233	.9606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174097 / 33 kV MIDC II

Feeder No / Name : 203 / 11 KV GODAWARI DRUG

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.7356	.6478	.3048	.2926	.5121	.5716
2	.6036	.7621	.6478	.3048	.2926	.5601	.5716
3	.679	.743	.6478	.3048	.2926	.5601	.5716
4	.679	.7621	.6478	.3048	.2926	.5544	.5716
5	.679	.7167	.6478	.3048	.2926	.5544	.5716
6	.679	.6979	.6097	.3048	.2926	.5487	.5716
7	.679	.6602	.4191	.3429	.2172	.5373	.5716
8	.679		.381	.3048	.2172	.5258	.5716
9	.8002		.3734	.3048		.5014	.5316
10	.7621			.3048		.5068	.5373
11	.8002		.3921	.3429	.2926		
12	.8002		.3734	.3429	.2149		
13	.8764		.4338	.2667	.2926	.5121	.5373
14	.8383		.3734	.2667		.5121	.5373
15	.8002		.3326	.3048		.5068	
16	.8002		.3077	.3048	.3658	.5068	.5258
17	.8488	.724		.2149	.4066		.5014
18	.8192	.724		.2865			.5853
19	.6979		.3658	.2896	.3222		
20	.7167	.724	.3511	.2172	.3018	.5716	.5068
21	.6722	.6859	.2926	.2172	.2812	.5716	.5068
22	.5914	.6859	.2926	.2149	.5487	.5716	.5175
23	.5975	.6478	.2667	.2149	.4572	.5716	.5014
24	.6036	.6348	.6478	.2667	.2926	.3982	
Max	.8764	.7621	.6478	.3429	.5487	.5716	.5853
Min	.5914	.6348	.2667	.2149	.2149	.3982	.5014
Avg	.7211	.7074	.4501	.2849	.3140	.5307	.5453



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 201 / 11 kV ASARJAN GAUTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.2743
6				.3012	.2883	.2713	.2713
7				.3366	.2883	.3361	
8		.3012			.2543	.2713	.3052
9	.2865		.2686	.2686		.2835	.2481
10	.2865					.2481	.2126
11	.2172				.1772	.197	.197
12	.1791				.1734		
13	.1791			.181			
14	.1791		.1612	.1646			
15	.1629					.1791	
16	.197					.1595	
17							.181
18							.2012
20							.2987
22							.2561
24	.2378	.2534		.2172	.2204	.2204	.2229
Max	.2865	.3012	.2686	.3366	.2883	.3361	.3052
Min	.1629	.2534	.1612	.1646	.1734	.1595	.181
Avg	.2139	.2773	.2149	.2449	.2337	.2407	.2426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 202 / 11 KV KOUTH GAUTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							1.0288
6				1.2048	1.0974	1.2696	1.1191
7				1.382	1.2346	1.2887	
8		1.262			1.2689		1.3032
9	1.267		1.2803	1.267		1.2403	
10	1.2308					1.2757	
11					.9114	1.3112	
12					.9114		
13	1.1222			.8238			
14	1.0136		.8048	.7682			
15	.8596					.8596	
16	.8859					.8505	
17							.9412
18							.9511
20							1.2071
22							1.1458
24	.9709	.9774		.2896	.9496	1.0174	.9156
Max	1.267	1.262	1.2803	1.382	1.2689	1.3112	1.3032
Min	.8596	.9774	.8048	.2896	.9114	.8505	.9156
Avg	1.05	1.1197	1.0426	.9559	1.0622	1.1391	1.0765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 203 / 11 KV AG FEEDER

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.0339
6				.0354	.0509	.0339	.0339
7				.0532	.0678	.0678	
8					.0339		.0678
9			.0358	.0362		.0709	.0709
10						.0709	.0709
11	.0183						
12	.0183						
13	.0181						
14	.0181						
15	.0366						
16	.0354						
17							.0362
18							.0366
20							.0366
22							.0366
24	.0366	.0362		.0362	.0343	.017	.0339
Max	.0366	.0362	.0358	.0532	.0678	.0709	.0709
Min	.0181	.0362	.0358	.0354	.0339	.017	.0339
Avg	.0259	.0362	.0358	.0403	.0467	.0521	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) MIDC SDN.[724] BU 4724

Substation No/ Name :- 174098 / 33 kV KAUTHA (ASARJAN)

Feeder No / Name : 204 / Sahayog G.

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5							.3052
6				.4252	.4748	.4115	.3052
7				.1772	.4801	.407	
8		.4607			.4409		.3391
9	.5014		.5068	.2561		.4607	.3366
10	.4755					.4607	.3189
11	.4656				.4557	.4656	.3189
12	.4344				.5258		
13	.5014			.2561			
14	.5121		.543	.2507			
15	.5068					.5373	
16	.4908					.567	
17							.5121
18							.5068
20							.439
22							.1867
24	.3292	.3544		.2896	.3429	.2743	.3052
Max	.5121	.4607	.543	.4252	.5258	.567	.5121
Min	.3292	.3544	.5068	.1772	.3429	.2743	.1867
Avg	.4686	.4076	.5249	.2758	.4534	.4480	.3522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 201 / 11 KV REST HOUSE

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	1.307	1.4937	1.6804	1.4937	1.4937	1.4937
2	1.2136	1.307	1.4003	1.5089	1.307	1.4146	1.4003
3	1.2136	1.307	1.4003	1.448	1.2136	1.4003	1.4003
4	1.2136	1.2136	1.4937	1.5384	1.2136	1.4937	1.4937
5	1.307	1.307	1.587	1.587	1.307	1.4937	1.4937
6	1.4003	1.4937	1.6804	1.8671	1.587	1.6804	1.6804
7		1.6804	1.7737	1.8671	1.587	1.6804	1.6804
8		1.6804	1.7737	1.8671	1.587	1.6804	1.7737
9	1.6804		1.7737	1.6804			1.6804
10	1.6804		1.4937	1.6804			1.4937
11	1.587		1.4937	1.587			1.4937
12	1.4937		1.4003	1.4003			1.4937
13			1.4003	1.4003	1.307	1.2136	1.307
14			1.4003	1.4003		1.2136	1.307
15	1.307		1.4003	1.4003	1.307	1.2136	1.4003
16	1.3203	1.2012	1.4937	1.4003	1.307	1.307	1.4003
17		1.307	1.5546	1.4937	1.4937	1.4003	
18	1.587	1.4003		1.4937		1.4003	1.4937
19	1.7737	1.7737	1.8671	1.6804		1.4937	1.4937
20	1.8671	1.8671		1.6804		1.8671	1.6804
21	1.6804	1.8671	1.8099			1.8671	1.6632
22	1.6804	1.7737	1.6289	1.7737	1.7737	1.8671	1.4784
23	1.587	1.587	1.6289	1.7737	1.6804	1.4937	1.386
24	1.2936	1.4937	1.4937	1.6975	1.4937	1.4937	1.4937
Max	1.8671	1.8671	1.8671	1.8671	1.7737	1.8671	1.7737
Min	1.2136	1.2012	1.4003	1.4003	1.2136	1.2136	1.307
Avg	1.4838	1.5039	1.5655	1.6046	1.4439	1.5084	1.5079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 202 / 11 KV STADIUM

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8402	.8402	.924	.9335	.8402	.9335	.8402
2	.7468	.7468	.8316	.9335	.8402	.8402	.8402
3	.7468	.7468	.8402	.8764	.8402	.8316	.8402
4	.7468	.7468	.8402	.9335	.8402	.8316	.9335
5	.8402	.8402	.9335	1.0269	.9335	.9335	.8402
6	.8402	.9335	.9335	.9955	1.0269	1.0374	.8402
7		.9335	1.0269	1.0517	.9335	1.0269	.9335
8		.9335	1.1203	1.0517	1.1203	1.0269	1.1203
9	1.1088		1.1203	.9335			.9335
10	1.1203		.9335	.9335			1.1203
11	1.1203		.9335	.9335			1.0269
12	1.1317		.9335	.8402			1.0269
13			.9335	.8402		.8402	.9335
14			.8402	.8402		.8402	.8402
15	.9335		.8402	.9335		.8402	.7468
16	.8402		.8145	1.0269	1.0269	.9335	.7468
17		.8316	.9335	1.0269		.9335	
18	1.1203	.9335		1.0269		1.0269	
19	1.307	1.1317	1.267	1.1203		1.1203	1.1203
20	1.307	1.2136				1.1203	1.4784
21	1.2136	1.2136				1.1203	1.2936
22	1.0269	1.1203		1.1203	1.1203	1.0269	1.2012
23	.9335	1.0269		1.0269	1.0269	.9335	1.0164
24	.8316	.8402	.924	1.0269	.8402	.9335	.8402
Max	1.307	1.2136	1.267	1.1203	1.1203	1.1203	1.4784
Min	.7468	.7468	.8145	.8402	.8402	.8316	.7468
Avg	.9871	.9395	.9434	.9742	.9491	.9565	.9779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 203 / 11 KV NAGARJUNA HOTEL Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4937	1.587	1.587	1.7737	1.6804	1.6975	1.587
2	1.4937	1.4937	1.4937	1.7737	1.4937	1.587	1.587
3	1.4937	1.4937	1.4937	1.8671	1.4937	1.587	1.587
4	1.4937	1.4937	1.587	1.8671	1.4937	1.6804	1.6804
5	1.587	1.6804	1.7737	1.8099	1.8671	1.6804	1.8671
6	1.6804	1.8671	2.1472	2.0748	2.0538	1.9805	2.0538
7		2.0538	2.1472	2.1691	2.0538	2.1472	2.0538
8		2.0538	2.0538	2.1719	2.0538	2.1472	2.0538
9	2.0538		1.8671	1.8671			1.6804
10	1.8671		1.587	1.7737			1.8671
11	1.6804		1.4003	1.587			
12	1.4937		1.4003	1.3203			1.307
13			1.307	1.2136		1.2136	1.307
14			1.307	1.1203		1.2136	1.2136
15	1.307		1.307	1.2136	1.2136	1.1203	1.0269
16	1.4003	1.2936	1.3575	1.2136	1.2136	1.1203	
17		1.4003	1.4937	1.4937		1.307	
18	1.8671	1.587		1.4937		1.4937	1.6804
19	2.1472	1.8671	2.1719	1.7737		1.7737	1.9605
20	2.0538	2.0538				1.8671	1.8671
21	1.8671	1.8671	1.9281			1.7737	1.848
22	1.8671	1.7918	1.9281	1.8671	1.8671	1.7737	1.7556
23	1.8671	1.6804	1.8099	1.7737	1.8671	1.6804	1.5708
24	1.4784	1.6804	1.587	1.6289	1.6804	1.6975	1.587
Max	2.1472	2.0538	2.1719	2.1719	2.0538	2.1472	2.0538
Min	1.307	1.2936	1.307	1.1203	1.2136	1.1203	1.0269
Avg	1.6943	1.7026	1.6698	1.6749	1.6948	1.6271	1.6734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174050 / 33 kV VIDYUT BHAVAN

Feeder No / Name : 204 / 11 KV DATTA NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1472	2.1472	2.2405	2.0538	2.3101	2.1472	2.1472
2	2.0538	2.1472	2.1472	2.0538	2.2405	2.1472	2.0538
3	2.0538	2.0538	2.1472	2.1719	2.2405	2.1472	2.0538
4	2.0538	2.0538	2.1472	2.2405	2.1472	2.1472	2.0538
5	2.1472	2.0538	2.2405	2.1719	2.2405	2.2405	2.2405
6	2.3339	2.1472	2.5206	2.3339	2.5206	2.5206	2.4272
7		2.2405	2.5463	2.4272	2.4272	2.5206	2.4272
8		2.3339	2.5206	2.3529	2.4272	2.5206	2.4272
9	2.5206			2.3339			2.2405
10	2.4272			2.2405			2.3339
11	2.3339			2.2634			2.2405
12	2.2634			2.1472			2.2405
13				2.0538		2.0538	2.0538
14			2.0538	1.9605		1.8671	1.9605
15	2.0538		1.8671	2.1472	2.0538	1.8671	1.8671
16	2.1472		2.0814		2.0538	1.8671	2.0538
17		1.9605	2.0814			1.9605	
18	2.4272	2.0538		2.6139		2.0538	2.2177
19	2.8006	2.5206	2.6139	2.894		2.3339	2.4949
20	2.8006	2.7349				2.5206	2.5873
21	2.6139	2.7073	2.6139			2.3339	
22	2.5206	2.5206	2.4272	2.7073	2.6139	2.4272	
23	2.3339	2.452	2.3339	2.6139	2.5206	2.2405	2.3101
24	2.1253	2.2405	2.2405	2.2405	2.3339	2.2405	2.1472
Max	2.8006	2.7349	2.6139	2.894	2.6139	2.5206	2.5873
Min	2.0538	1.9605	1.8671	1.9605	2.0538	1.8671	1.8671
Avg	2.3241	2.2730	2.2837	2.3011	2.3177	2.2079	2.2180



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 201 / 11 KV RLY DIVISION

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.132	.0914	.1132	.1132	.0943
2	.0943	.132	.0914	.0943	.1132	.0754
3	.0943	.0943	.0914	.1132	.0943	.0754
4	.0943	.0943	.0914	.0943	.0943	.0754
5	.1132	.0943	.0914	.0943	.0943	.0943
6	.0943	.1132	.0914	.0943	.1132	.0943
7	.1132	.0943	.0914		.1132	.1132
8	.1132	.1132	.0914		.132	.1509
9		.1132	.128		.1509	.1509
10			.1509	.1886	.1698	.1698
11		.1463	.1886	.1886	.1698	.1698
12		.1463	.1698	.1698	.1509	.1698
13		.1463	.1698	.1698	.1509	.1698
14		.1463	.1698	.1698	.132	.1509
15		.1463	.1463	.1698		.1509
16		.1463	.1463	.1698	.132	.1509
17		.1463	.1698	.1509	.1509	.1509
18		.1097	.1509	.1509	.132	.132
19		.0914	.1509	.1509	.132	.132
20		.0914	.1509	.132	.1509	.132
21		.0914	.132	.132	.1509	.1132
22		.0914	.1132	.1132	.1132	.132
23		.0914	.132	.1132		.1132
24	.0943	.132	.0914	.1132	.1132	.1132
Max	.1132	.1463	.1886	.1886	.1698	.1698
Min	.0943	.0914	.0914	.0943	.0943	.0754
Avg	.1006	.1175	.1288	.1374	.1303	.1281

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 202 / 11 KV CHAITNYA NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.4575	1.5546	1.3763	1.4899	1.3375
2	1.2483	1.3717	1.5546	1.3763	1.4251	1.286
3	1.2323	1.3717	1.5546	1.3763	1.4251	1.286
4	1.2003	1.3717	1.5546	1.3603	1.4575	1.286
5	1.3603	1.7147	1.6461	1.4083	1.4899	1.3717
6	1.5043	1.8861	1.829	1.6644	1.7814	1.6289
7	1.6644	2.0576	1.829		1.9757	1.7147
8	1.6484	1.9204	1.829		1.9757	1.7147
9		1.749	1.829		1.7814	1.7147
10			1.4883	1.4251	1.6004	1.5775
11		1.3717	1.3763	1.3927	1.5203	1.4899
12		1.3717	1.2483	1.2308	1.2003	1.4575
13		1.1888	1.2323	1.1336	1.1843	1.3279
14		1.1888	1.2003	1.1336	1.1523	1.1984
15		1.1888	1.1523	1.1984		1.166
16		1.3717	1.1683	1.2631		1.166
17		1.3717	1.2323	1.2955	1.286	1.2483
18		1.6461	1.3763	1.3603	1.3717	1.3603
19		1.6461	1.5364	1.6842	1.7147	1.5524
20		1.6461	1.8564	1.7814	1.8861	1.6484
21		1.6461	1.7284	1.7814	1.8861	1.8656
22		1.5546	1.6804	1.6842	1.7147	1.6004
23		1.5546	1.6004	1.587	1.5432	1.4723
24	1.2803	1.5432	1.5546	1.4563	1.587	1.3717
Max	1.6644	2.0576	1.8564	1.7814	1.9757	1.8656
Min	1.2003	1.1888	1.1523	1.1336	1.1523	1.166
Avg	1.3799	1.5300	1.5255	1.4271	1.5659	1.4518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 203 / 11 KV MAHALAJ - SANGVI Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9145	.823	.8413	.8779	.823
2	.9145	.9145	.823	.823	.8779	.823
3	.905	1.0059	.823	.823	.8779	
4	1.0059		.823	.8686	.9511	.9145
5	1.2254	1.0242	.9145		1.0608	1.1888
6	1.5364	1.3169	1.1888	.4435	1.3717	1.4266
7	1.5364	1.6461	1.2803		1.3717	1.2803
8	1.7193	1.3169	1.2803		1.39	1.2803
9	1.39	1.0974	.9145		1.4266	1.0974
10			.823	1.2803	1.0425	1.2437
11		.9145	.9694	1.134	1.0059	1.134
12		.9145	.8779	1.0242	1.0974	.8413
13		.823	.7947	.9511	.8779	.8413
14		.823	.8131	.9511	1.0425	.8413
15		.823	.8131	.9511		.9145
16			.8686	.9511		.9511
17			.9979	.9511	1.0242	.9877
18		1.1888	1.134	1.134	1.0974	1.134
19		1.1888	1.2071	1.3169	1.2071	1.39
20		1.1888	1.39	1.3169	1.2803	1.4083
21		1.1888	1.1706	1.134	1.2803	1.1888
22		.9145	1.1706	1.0242	1.1888	1.1157
23		.823	.9511	.9145	1.0974	.9877
24	.9511	1.0059	.0732	.924	.9145	.9145
Max	1.7193	1.6461	1.39	1.3169	1.4266	1.4266
Min	.905	.823	.0732	.4435	.8779	.823
Avg	1.2099	1.0517	.9552	.9879	1.1074	1.0751

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 205 / 11 KV AIRPORT

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0305	.0293	.0373	.0343	.0305
2	.0373	.0305	.0293	.0373	.0343	.0305
3	.0373	.0305	.0293	.0373	.0343	.0305
4	.0373	.0305	.0293	.0373	.0343	.0305
5	.0373	.0305	.0293	.0373	.0343	.0305
6	.0373	.0305	.0293	.0373	.0343	.0305
7	.0373	.0305	.0293		.0343	.0305
8	.0377	.0305	.0293		.0343	.0305
9		.0305	.0293		.0343	.0305
10			.0373	.0343	.0373	.0305
11		.0293	.0373	.0343	.0373	.0343
12		.0293	.0373	.0343	.0373	.0343
13		.0293	.0373	.0343	.0373	.0343
14		.0293	.0373	.0343	.0373	.0343
15		.0293	.0373	.0686		.0343
16		.0587	.0747	.0686	.0747	.0343
17		.0587	.0373	.0343		.0373
18		.0587	.0373	.0343	.0305	.0373
19		.0587	.0373	.0343	.0305	.0373
20		.0293	.0373	.0343	.0305	.0373
21		.0293	.0373	.0343	.0305	.0373
22		.0293	.0373	.0343	.0305	.0373
23		.0293	.0373	.0343	.0305	.0373
24	.0373	.0305	.0293	.0373	.0343	.0305
Max	.0377	.0587	.0747	.0686	.0747	.0373
Min	.0373	.0293	.0293	.0343	.0305	.0305
Avg	.0373	.0349	.0355	.0386	.0358	.0334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 206 / 11KV GADEGAON

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152		.037		.0152
2	.0152		.037		.0152
3	.0152		.037	.0187	.0152
4	.0152		.037	.0181	.0152
5	.0152		.037	.0181	.0152
6	.0152		.037	.0181	.0152
7	.016	.0366		.0187	.016
8	.016	.0366		.0187	.016
9		.0366		.0187	.016
10		.0732	.0373	.0554	.016
Max	.016	.0732	.0373	.0554	.016
Min	.0152	.0366	.037	.0181	.0152
Avg	.0154	.0458	.0370	.0231	.0155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174072 / 33 kV SANGVI

Feeder No / Name : 207 / 11Kv Asana River Express Only one consumer of WW with HT-IV

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732		.0724	.0732	.0739	.0724	.0724
2	.0732		.0724	.0732	.0739	.0724	.0724
3	.0724		.0724	.0732	.0732	.0724	.0724
4	.0732		.0724	.0732	.0739	.0724	.0724
5	.0732		.0724	.0732	.0739	.0747	.0724
6	.0732		.0724	.0732	.0739	.0724	.0724
7	.0724		.0724	.0732		.0724	.0724
8	.0732		.0724	.0732		.0724	.0724
9	.0732		.0724	.0732		.0724	.0724
10				.0732	.0724	.0739	.0724
11			.0732	.0732	.0724	.0739	.0724
12			.0732	.0732	.0724	.0739	.0724
13			.0732	.0732	.0724	.0732	.0724
14			.0732	.0732	.0724	.0732	.0724
15			.0732	.0732	.0724		.0724
16				.0732	.0724		.0724
17				.0732	.0724	.0724	.0739
18			.0732	.0732	.0724	.0724	.0739
19			.0732	.0732	.0724	.0724	.0739
20			.0732	.0732	.0724	.0724	.0739
21			.0732	.0732	.0724	.0724	.0739
22		.0724	.0732	.0732	.0724	.0724	.0739
23		.0724	.0732	.0732	.0724	.0724	.0739
24	.0732		.0724	.0732	.0739	.0724	.0724
Max	.0732	.0724	.0732	.0732	.0739	.0747	.0739
Min	.0724	.0724	.0724	.0732	.0724	.0724	.0724
Avg	.0730	.0724	.0728	.0732	.0729	.0728	.0728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 201 / 11 KV MAHAVEER SOCIETY Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2686	.2772	.2772	.2686	.3696	.2743
2	.2772		.2801	.2743	.2686	.3696	.2743
3	.2743		.2801	.2743	.2686	.3696	.2743
4	.2743		.2801	.2743	.2686	.3696	.2743
5	.2743		.3696	.2743	.2715	.462	.2743
6	.3658		.462	.462	.3696	.5544	.3658
7	.3658		.5544	.5544	.4668	.5544	.462
8	.5544		.5544	.5601	.5658	.5544	.5544
9			.5544		.5658		
10	.5601		.5544	.5601	.5544		.6535
11			.462		.5544		
12	.3696		.3696	.4668	.5601	.3696	.6535
13			.3696		.4668	.3696	
14	.3658		.3696	.3734	.4572	.3696	.462
15			.3696		.3658	.3696	
16	.3658		.3696	.3734	.3696	.3696	.3658
17		.462	.3696	.4668	.4287	.3696	.462
18	.5544	.5544	.4668	.5601	.5601	.5601	.5601
19		.5544	.6535	.5601	.5601	.5601	.5601
20	.462	.5544	.4668	.5544	.5601	.4668	.4668
21		.462	.3734	.4572	.5175		.3696
22	.362	.3696	.3696	.362	.3696		.3696
23	.362	.3696	.3696	.3582	.3696	.3696	.3696
24	.3696	.2686	.3696	.2772	.2686	.3696	.3696
Max	.5601	.5544	.6535	.5601	.5658	.5601	.6535
Min	.2743	.2686	.2772	.2743	.2686	.3696	.2743
Avg	.3785	.4293	.4132	.4160	.4282	.4288	.4208

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 202 / 11 KV SHIVAJI NAGAR ROAD Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.823	.9335	.7392	.8316	.9335	.7392
2	.9145		.924	.7316	.8316	.924	.7316
3	.7316		.924	.7316	.8316	.924	.7316
4	.7316		.924	.7316	.8316	.924	.7316
5	.7316		.9335	.7316	.8316	1.0269	.7316
6	.7316		.9335	.924	.9335	1.1203	.9145
7	.9145		1.0269	1.0164		1.2136	.9145
8	.9145		1.0269	1.0164		1.2136	1.0059
9			1.0374				
10	1.1203		1.0269	1.0269			1.1203
11			1.0269				
12	1.0269		1.0269	1.0269		1.0164	1.1203
13			1.0269			1.0164	
14	1.0269		1.0269	1.0269	1.0269	1.0164	1.0269
15			1.0269		1.0269		
16	1.0269		1.0269	1.1203	1.0269	.924	.924
17		.924	1.0269	1.1203	1.1203	.924	1.0164
18	1.307	1.0164	1.0269	1.1203	1.2136	1.0269	1.1203
19		1.307	1.1203	1.307	1.307	1.2136	1.307
20	1.1203	1.2136	1.1203	1.307	1.307	1.1203	1.307
21		1.2136	1.0269	1.307	1.307		1.1203
22	1.0269	1.1203	1.0269	1.1088	1.2136		1.0269
23	.924	.9335	.9335	1.1088	1.1203	.9335	.924
24	.924	.823	.9335	.9335	.924	1.1203	.9335
Max	1.307	1.307	1.1203	1.307	1.307	1.2136	1.307
Min	.7316	.823	.924	.7316	.8316	.924	.7316
Avg	.9463	1.0416	1.0028	1.0068	1.0403	1.0329	.9724



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 203 / 11 KV INDUSTRIAL AREA

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3239	.381	.3048	.3086	.3239	.3048
2	.381		.381	.3048	.3086	.3239	.3048
3	.381		.3906	.3048	.3086	.2743	.3048
4	.381		.3906	.3048	.3086	.2667	.3048
5	.381		.3906	.3048	.3125	.2667	.3048
6	.3715		.3906	.381	.4001	.2629	.381
7	.381		.4001	.3906	.4001	.3572	.381
8	.3953		.4001	.4191	.4001	.3858	.3906
9			.5144				
10	.5316		.5544	.5487			.6268
11			.6602				
12	.6602		.7545	.6602		.6602	.6401
13			.7545			.6602	
14	.6602		.7545	.6602	.7545	.6602	.6535
15			.7545		.7545	.6602	
16	.6602		.7545	.7545	.7545	.6602	.6602
17		.5544	.7545	.7545	.8488	.6602	.5601
18	.5487	.543	.6535	.7545	.8488	.6535	.5544
19		.543	.6535	.7545	.7545	.6468	.5487
20	.5373	.5201	.5487	.6335	.7545	1.7194	.5373
21		.5144	.4382	.5201	.6335		.5258
22	.4239	.4144	.4191	.4096	.5316		.4191
23	.4049	.4049	.4049	.3906	.5144	.4001	.4001
24	.4049	.3239	.381	.381	.3086	.3734	.3048
Max	.6602	.5544	.7545	.7545	.8488	1.7194	.6602
Min	.3715	.3239	.381	.3048	.3086	.2629	.3048
Avg	.4638	.4602	.5366	.4968	.5371	.5377	.4554

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174084 / 33 kV INDUSTRIAL AREA

Feeder No / Name : 204 / I.T.M. Feeder

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5487	.5601	.5544	.5544	.4715	.4477
2	.5544		.5658	.462	.5544	.4715	.462
3	.5544		.5658	.4572	.5544	.4715	.462
4	.5544		.5658	.4572	.5544	.4715	.462
5	.5544		.5658	.4572	.5544	.4715	.462
6	.5544		.5658	.4572	.5601	.5658	.462
7	.5544		.5658	.5544	.6535	.6602	.5544
8	.5544		.5658	.5544	.6535	.6602	.5544
9			.6535		.6535		
10	.5601		.6535	.6468	.8402		.7468
11			.7468		.8402		
12	.6602		.7468	.7468	.8316	.6535	.7545
13			.7468		.823	.6535	
14	.6602		.7468	.7392	.8316	.6535	.7545
15			.7468		.8316	.6535	
16	.6602		.7468	.823	.8316	.6535	.7468
17		.6468	.7468	.823	.8316	.6535	.7468
18	.7545	.6468	.7468	.7392	.8316	.6535	.7468
19		.8316	.7468	.9335	.8316	.7468	.8488
20	.7545	.8316	.7468	.8402	.8402	.8402	.8488
21		.7392	.6535	.7392	.7545		.6535
22	.6468	.6602	.5601	.6468	.6602		.6535
23	.5487	.5601	.5601	.6468	.5658	.5601	.5601
24	.5544	.5487	.5601	.5601	.5544	.4715	.4668
Max	.7545	.8316	.7468	.9335	.8402	.8402	.8488
Min	.5487	.5487	.5601	.4572	.5544	.4715	.4477
Avg	.6020	.6682	.6512	.6419	.7080	.6019	.6197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 201 / 11 KV Yashwant Nagar  
Feeder KV- 11 / OUTGOING

SPARE FEEDER

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4887	.5487	.5487	.5731	.5914	.5121	.4755
2	.4656	.4805	.5487	.5083	.6283	.4755	.4755
3	.4207	.4805	.4755	.5611	.4805	.4607	.4755
4	.4207	.4435	.5121	.6154	.4805	.5316	.5487
5	.4382	.5175	.6219	.6154	.5175	.6219	.5487
6	.4477	.5853	.6219	.631	.5175	.6584	.5487
7	.3982	.6219	.5487	.6268	.4805		.5487
8	.6447	.5121	.6584		.6283		.5121
9	.6154		.6335				.5121
10	.4525		.3801				.1829
11	.4805		.3077	.3326	.5121		.2103
12	.0111		.6516	.3326	.5487	.3292	.4557
13	.3696		.6154	.3696	.6219	.6584	.3801
14	.4435			.5487	.6219	.695	.2896
15				.6584	.6584	.7316	.2896
16				.1109	.6219	.6584	.2629
17	.4435	.5853	.3077	.1109	.5853	.695	.3801
18	.6584	.6584	.4887	.1109	.5487	.7316	.4344
19	.6584	.6584			.4755	.6584	.4557
20	.5853	.6584			.695		
21	.5487	.695	.6335		.7682		.5249
22	.5121	.4755	.6089	.3326	.6584		.5249
23	.6219	.439	.6268	.3696	.6219	.5121	.567
24	.6154	.5853	.4024	.6154	.6283	.5853	.5121
Max	.6584	.695	.6584	.6584	.7682	.7316	.567
Min	.0111	.439	.3077	.1109	.4755	.3292	.1829
Avg	.4882	.5591	.5364	.4457	.5859	.5947	.4398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 202 / 11 KV NASARADPURA

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.2218	.2561	.2743	.2614	.2926	.2561
2	.2896	.2218	.2561	.2534	.2241	.2561	.2561
3	.2715	.2218	.2561	.2195	.2241	.2561	.2561
4	.2534	.2587	.2926	.2172	.2614	.3292	.3292
5	.2896	.2957	.3292	.2743	.3361	.3658	.3658
6	.362	.3326	.3658	.3801	.3734	.3898	.4024
7	.3982	.3696	.4024	.439	.4435		.439
8	.4344	.4435	.5487		.4435		.439
9	.3982						.4755
10	.3982						.4755
11	.3326			.3326	.3658		.439
12				.2957	.3658	.3658	.3658
13				.2587	.0914	.3658	.3258
14				.2218		.3658	.3258
15				.2218	.0914	.3292	.2534
16				.2957	.0914	.3292	.2715
17		.3292		.3696	.3658	.3658	.2896
18	.3326	.3658		.3326	.439	.439	.3658
19	.4435	.3658			.4755	.439	.4024
20	.4435	.3658			.5487	.4572	.439
21	.4066	.3658	.3292		.5853	.4755	.4024
22	.3696	.3658	.2896	.3696	.3658	.3658	.3292
23	.3326	.3292	.3292	.3326	.3658	.3292	.3292
24	.3077	.2587	.2926	.2926	.2957	.3292	.2926
Max	.4435	.4435	.5487	.439	.5853	.4755	.4755
Min	.2534	.2218	.2561	.2172	.0914	.2561	.2534
Avg	.3540	.3195	.3290	.2990	.3340	.3603	.3553

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 203 / 11 KV Dnyaneshwar Wadi  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.9774	.9877	1.0317	.9877	1.0608	1.0608
2	1.0498	1.0136	.9877	.9774	1.0242	1.0242	1.0242
3	1.0425	.9412	1.0242	.9774	.9511	1.0242	1.0974
4	1.0679	1.0136	1.0974	1.0136	1.0974	1.3717	1.3717
5	1.1403	1.086	1.3717	1.1222	1.3394	1.4632	1.5546
6	1.4299	1.3253	1.4998	1.448	1.448	1.5729	1.7375
7	1.6108	1.5402	1.6461	1.5927	1.6289		1.829
8	1.6651	1.6118	1.7193		1.6289		1.829
9	1.4083		1.5565				1.5729
10	1.3032		1.3032				1.3535
11	1.1946		1.1222	1.4327	.8413		1.1584
12	1.086		1.1222	1.0745	.8779	1.2803	.9593
13			1.0136	1.0136	.9145	1.2437	.9955
14			.9231	1.0136	.9511	1.0974	.9593
15			.8869	1.0498	.9511	1.0974	.9231
16			1.1222	.9774	.9745	1.0608	.9412
17		1.0974	1.262	1.086	1.0974	1.134	1.0136
18	1.2536	1.2803	1.2308	1.1584	1.134	1.2071	1.1403
19	1.3611	1.3169			1.3535	1.1706	1.3394
20	1.4327	1.3169			1.4266		1.3756
21	1.3253	1.3169	1.2127		1.4998		1.2489
22	1.1946	1.2437	1.1584	1.1946	1.3169		1.2308
23	1.086	1.0974	1.1222	1.086	1.1888	1.1706	1.1403
24	1.1041	1.0136	1.0608	1.0679	1.0242	1.0974	1.0974
Max	1.6651	1.6118	1.7193	1.5927	1.6289	1.5729	1.829
Min	1.0425	.9412	.8869	.9774	.8413	1.0242	.9231
Avg	1.2548	1.1995	1.2014	1.1288	1.1662	1.1923	1.2481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 204 / 11 KV FARANDE NAGAR - II Urban/Sheddable Urban Feeder  
Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5611	.5175	.5487	.4706	.5544	.5853	.5487
2	.543	.4435	.5121	.4344	.4805	.5487	.5487
3	.5249	.4435	.5121	.3982	.4805	.5487	.5487
4	.5249	.4805	.5487	.4525	.5175	.6219	.6584
5	.543	.5487	.6219	.5249	.6283	.695	.7316
6	.6697	.6219	.695	.7421	.7316	.7316	.7682
7	.8779	.7316	.7316	.7059	.961		.8048
8	.8869	.8688	.7316		.9145		.8413
9	.7865						.8048
10	.724						.695
11	.6219			.5121	.695		.5792
12	.5121			.4755	.6584	.6219	.5068
13				.4435	.5853	.6219	.4887
14				.4435	.5487	.5487	.4706
15				.4755	.5487	.5487	.4344
16				.4805	.5853	.4755	.4706
17		.6584		.5487	.5853	.6401	.5068
18	.5853	.7316		.5544	.695	.823	.5611
19	.6584	.7682			.7682	.7682	.6697
20	.7316	.7316			.8048		.7059
21	.6584	.7316	.6697		.9145	.823	.6584
22	.6584	.7316	.7059	.7023	.7316	.6401	.6584
23	.5853	.695	.5249	.6653	.695	.6219	.5853
24	.5973	.5121	.6219	.4887	.5914	.6219	.5853
Max	.8869	.8688	.7316	.7421	.961	.823	.8413
Min	.5121	.4435	.5121	.3982	.4805	.4755	.4344
Avg	.6448	.6385	.6187	.5288	.6671	.6381	.6180

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 174104 / 33 kV PAWDEWADI

Feeder No / Name : 205 / 11 KV Vijay Nagar

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9774	.905	.9877	.8688	.9511	.9511	.9877
2	.9412	.905	.9877	.8507	.9145	.9511	.9877
3	.8869	.9774	.9877	.7964	1.0242	.9511	1.0608
4	.8869	1.0498	1.0974	.8145	1.0974	1.1888	1.134
5	.9412	1.1946	1.2071	.9774	1.1946	1.2803	1.2803
6	1.1403	1.2894	1.3169	1.3213	1.3032	1.3717	1.3717
7	1.3032	1.5043	1.4632	1.448	1.4118		1.4632
8	1.4299	1.4327	1.4632		1.3756		1.4632
9	1.3937		1.3756				1.4632
10	1.2127		1.1584				1.3169
11	1.1584		1.0136	1.086	1.2803		1.2127
12	1.0498		.9412	.9412	1.1888	1.0974	.905
13			.8688	.9774	1.0059	1.0974	.8869
14			.8869	.9774	.9145	1.0974	.8507
15			.8869	.9412	.8779	1.0974	.8145
16			.9231	.905	1.0059	1.0059	.7783
17		1.1888	1.0317	.9412	1.0059	1.1888	.9774
18	1.1222	1.4266	1.0317	1.086	1.1888	1.3717	1.0317
19	1.2894	1.4632			1.2803	1.3717	1.1403
20	1.2536	1.3717			1.3717	1.3717	1.3032
21	1.1946	1.2803	1.2308		1.4632	1.2803	1.1888
22	1.1222	1.1706	1.2127	1.1584	1.1888	1.0974	1.0974
23	1.0136	1.0974	.9412	1.0498	1.0974	1.0608	1.0059
24	.9955	.9412	1.0242	.9231	.9877	.9313	1.0242
Max	1.4299	1.5043	1.4632	1.448	1.4632	1.3717	1.4632
Min	.8869	.905	.8688	.7964	.8779	.9313	.7783
Avg	1.1217	1.1999	1.0926	1.0035	1.1423	1.1454	1.1144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 202 / 11 KV ANAND NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.9774	1.9605	2.0376
16	1.6461	1.5708	
24	1.7741	1.848	1.848
Max	1.9774	1.9605	2.0376
Min	1.6461	1.5708	1.848
Avg	1.7992	1.7931	1.9428



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 203 / 11 KV GAJANAN MANDIR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
8	2.3712	2.2634	2.1948
16	1.6975	1.6289	
24	1.7372	1.848	1.848
Max	2.3712	2.2634	2.1948
Min	1.6975	1.6289	1.848
Avg	1.9353	1.9134	2.0214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 205 / 11 KV GANESH NAGAR

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
8	1.1949	1.1203	1.1888
16	.9335	.8316	
24	.9448	1.0349	1.1088
Max	1.1949	1.1203	1.1888
Min	.9335	.8316	1.1088
Avg	1.0244	.9956	1.1488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 206 / 11 KV PAWDEWADI

Feeder KV- 11 / OUTGOING

Only one consumer of WW with HT-IV

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
9	1.8671		2.0538
12		1.9404	
Max	1.8671	1.9404	2.0538
Min	1.8671	1.9404	2.0538
Avg	1.8671	1.9404	2.0538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 207 / 11 KV VIVEK NAGAR  
Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
8	3.131	2.9874	2.9264
16	1.3717	1.386	
24	1.1706	1.1827	1.2012
Max	3.131	2.9874	2.9264
Min	1.1706	1.1827	1.2012
Avg	1.8911	1.8520	2.0638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 208 / 11 KV POLICE COLONY`

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.1827	1.1088	1.1203	
16	1.0059	.9145		.9955
24	.8688	.905	.905	
Max	1.1827	1.1088	1.1203	.9955
Min	.8688	.905	.905	.9955
Avg	1.0191	.9761	1.0127	.9955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 209 / 11 KV SAHAYOG NAGAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	2.0911	2.1472	2.1948	2.1472	2.1658	2.1253	2.3339
16	1.6461	1.7375	1.7556	1.829	1.7187	1.9909	1.6289
24	1.7741	1.8446	1.829	1.829	2.0119	2.0119	1.9404
Max	2.0911	2.1472	2.1948	2.1472	2.1658	2.1253	2.3339
Min	1.6461	1.7375	1.7556	1.829	1.7187	1.9909	1.6289
Avg	1.8371	1.9098	1.9265	1.9351	1.9655	2.0427	1.9677

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 400 / Auxiliary Supply

DIVISION FEEDER

Feeder KV- 33 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
11					2.372		
24	1.9685	1.6804	2.1862	1.8519		2.2565	2.1348
Max	1.9685	1.6804	2.1862	1.8519	2.372	2.2565	2.1348
Min	1.9685	1.6804	2.1862	1.8519	2.372	2.2565	2.1348
Avg	1.9685	1.6804	2.1862	1.8519	2.372	2.2565	2.1348

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 401 / 33 KV Pawdewadi (Old NTC) HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	8.6877	8.1447	8.5963	8.059	9.2307	8.6877	9.4559
Max	8.6877	8.1447	8.5963	8.059	9.2307	8.6877	9.4559
Min	8.6877	8.1447	8.5963	8.059	9.2307	8.6877	9.4559
Avg	8.6877	8.1447	8.5963	8.059	9.2307	8.6877	9.4559



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 402 / 33 KV LIMBGAON FEEDER

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	.2241	.2829	.2829	.2801	.2829	.2829	.2743
Max	.2241	.2829	.2829	.2801	.2829	.2829	.2743
Min	.2241	.2829	.2829	.2801	.2829	.2829	.2743
Avg	.2241	.2829	.2829	.2801	.2829	.2829	.2743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 403 / 33 KV DEGAON FEEDER

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	1.2449	1.3014	1.4146	1.1883	1.1883	1.1317	1.386
Max	1.2449	1.3014	1.4146	1.1883	1.1883	1.1317	1.386
Min	1.2449	1.3014	1.4146	1.1883	1.1883	1.1317	1.386
Avg	1.2449	1.3014	1.4146	1.1883	1.1883	1.1317	1.386

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 404 / 33 KV VIDHUT BHAVAN FEEDER HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	8.9403	8.8272	8.9621	8.714	9.6194	9.3364	9.2307
Max	8.9403	8.8272	8.9621	8.714	9.6194	9.3364	9.2307
Min	8.9403	8.8272	8.9621	8.714	9.6194	9.3364	9.2307
Avg	8.9403	8.8272	8.9621	8.714	9.6194	9.3364	9.2307

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED (U) S/DN-II[445] BU 4445

Substation No/ Name :- 177001 / 132 kV JANGAMWADI

Feeder No / Name : 405 / 33 KV NEELA FEEDER

HV Non-Express Feeder

Feeder KV- 33 / INCOMING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
24	2.3891	2.524	2.7721	2.4977	2.6029	2.5206	2.6578
Max	2.3891	2.524	2.7721	2.4977	2.6029	2.5206	2.6578
Min	2.3891	2.524	2.7721	2.4977	2.6029	2.5206	2.6578
Avg	2.3891	2.524	2.7721	2.4977	2.6029	2.5206	2.6578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 201 / 11 KV LIMBGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373		.0743	.0743	.1143	.0686
2		.0373		.0743	.0743	.1143	.1372
3		.0373		.0743	.0743	.1143	.1372
4		.0373		.0743	.0743	.1128	.1372
5				.0714	.0714	.1448	.1372
6				.0714	.0743	.2229	.1372
7				.1486	.1486	.2526	.2743
8				.1524		.2934	.3048
9			.1467	.1524	.3086	.301	.3048
10				.0895	.3048		.3048
11	.2201						
15	.1391						
16	.1738						
18	.1669						
19	.0377			.0373	.0377		
20			.0373	.0373	.0373		
21					.0373		
22	.0373						
23	.0373				.0373		
24		.0373				.0373	
Max	.2201	.0373	.1467	.1524	.3086	.301	.3048
Min	.0373	.0373	.0373	.0373	.0373	.0373	.0686
Avg	.1160	.0373	.092	.0881	.1042	.1708	.1943

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 202 / 11 KV CHUDAWA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.1334	.0695	.0695	.153	
2	.0373	.0373	.2058	.0695	.0834	.153	
3	.0373	.037	.2086	.0695	.0834	.1551	
4	.0373	.037	.2115	.1391	.1391	.1692	
5			.2143	.1353	.1353	.2172	
6			.2201		.2229	.2972	.1448
7			.2229	.2086	.2229	.4515	.4572
8			.2229	.2058		.5647	.6859
9			.2115	.2086		.6401	.5401
10				.2743	.2858		.602
11	.2782						
15	.16						
16	.2225						
18	.2058						
19	.0373	.037			.0377	.037	
20	.037	.037			.0377	.0373	.0373
21	.0373	.037			.0377	.0373	.0373
22	.037	.037			.0373	.0373	.0373
23	.037	.037			.0373	.0373	.0373
24	.0373	.037	.0554			.0373	
Max	.2782	.0373	.2229	.2743	.2858	.6401	.6859
Min	.037	.037	.0554	.0695	.0373	.037	.0373
Avg	.0885	.0371	.1906	.1534	.11	.2016	.2866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 203 / 11 KV NALESHWAR AG  
Feeder KV- 11 / OUTGOING

AG Feeder with SDT

DATE	24-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)
16		1.6057
18	.1021	
Max	.1021	1.6057
Min	.1021	1.6057
Avg	.1021	1.6057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 204 / 11 KV TALNI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2397	.0554	.0739	.0924	.056	.056
2	.2801	.2397	.056	.0739	.0924	.056	.056
3	.2229	.2397	.056	.0554	.0934	.056	.056
4	.2229	.2572	.056	.0373	.056	.0747	.056
5	.2258	.3567					
6	.301	.4572					
7	.3763	.6481					
8	.4572	.7253					
9	.5268						
10	.5575						
11			.4401	.4572	.7716		
12			.4344	.4572	.9259		
13				.5868	.9568	.2896	.9907
14			.5944	.5868	.9414	.6602	
15			.5944	.5868	.9145	.743	.5268
16			.5944	.2201	.8688	.743	.6859
17				.5868	.8535	.7335	.7526
18			.2201	.6602	.743	.6516	.5268
19	.0747	.0566	.0747	.168	.0739	.0554	
20	.0747	.0566		.112	.0747	.056	.0747
21	.0739	.056	.0747	.112		.056	.0747
22	.0554	.056	.0747		.0747	.056	.0373
23	.0554	.056	.0747	.0934	.056	.056	.056
24	.0373	.0554	.0554	.0747	.0934	.056	.056
Max	.5575	.7253	.5944	.6602	.9568	.743	.9907
Min	.0373	.0554	.0554	.0373	.056	.0554	.0373
Avg	.2330	.2500	.2304	.2907	.4519	.2749	.2861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174025 / 33 kV LIMBGAON

Feeder No / Name : 205 / 11 KV LIMBGAON GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3361	.3696	.3772	.3772	.3734	.3734
2	.3734	.3361	.3734	.3772	.3772	.3734	.3734
3	.3391	.3734	.3734	.3772	.3772	.3734	.3734
4	.3734	.4108	.4668	.5544	.5658	.4108	.3772
5	.5658	.7545	.4668	.8488	.6602	.7095	.4715
6	.7545	.8488	.5601	.8402	.8488	.8488	
7	.8488	.9431	.9335	.9431	.9431	.9054	.9431
8	.8488	.9054	.9335	.9335		.9431	.9431
9	.6535		.7468	.7468		.8402	.6602
10	.4481			.462	.5228		.4668
11	.3326		.3734	.3734	.3326		
12			.2801	.2801			
13				.2801		.3734	.3734
14			.2829			.4668	.3734
15	.2957		.2801		.3326	.5601	.3734
16	.3881		.2829	.2829	.4435	.6535	.2801
17				.4715	.4481	.6535	.4668
18	.5601		.5601	.5658	.5914	.6535	.4668
19	.6722	.5601	.6535	.6602	.7468	.5601	
20	.5975	.6535		.5601		.5601	.5601
21	.4854	.5544	.4668	.4668		.4668	.4668
22	.4108	.3696	.4668	.4668	.4481	.4668	.4668
23	.3734	.3696	.3734	.3734	.4108	.3734	.3734
24	.3734	.3734	.3696	.3734	.3734	.3734	.3734
Max	.8488	.9431	.9335	.9431	.9431	.9431	.9431
Min	.2957	.3361	.2801	.2801	.3326	.3734	.2801
Avg	.5034	.5563	.4807	.5280	.5176	.5685	.4778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 202 / 11 KV SUGAR FACTORY

HV Non-Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914		.1219	.0762		.1219	.0914
2	.0914		.1219	.0762		.1219	.0914
3	.0854		.1219	.0762		.1219	.0914
4	.0854		.1219	.0762		.1219	.0838
5	.0762		.1219	.0762		.1219	.0838
6	.0762		.1219	.0762		.1219	.0854
7	.0914		.1219	.061		.1219	.0686
8	.0914		.1219	.0533		.1219	.0747
9			.0914		.1219	.0762	
10			.0762		.1219	.0667	
11			.0762		.1219	.0667	
12			.0667		.1219	.0667	
13					.1219	.0572	
14					.1219	.0572	
15					.1219	.0457	
16					.1219	.0457	
17		.1219				.0457	
18		.1219	.0667			.0526	
19		.1219	.0762			.0533	
20		.0122	.0762			.0667	
21		.1219	.0762			.0667	
22		.1219	.0762		.1219	.0914	
23		.1219	.0762		.1219	.0914	
24	.0914		.1219	.0762		.1219	.0914
Max	.0914	.1219	.1219	.0762	.1219	.1219	.0914
Min	.0762	.0122	.0667	.0533	.1219	.0457	.0686
Avg	.0867	.1062	.0976	.0720	.1219	.0853	.0847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174048 / 33 KV DEGAON

Feeder No / Name : 205 / 11KV PIMPALGAON GOVTHAN

Gaathan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.679	.7468	.6173	.6722		.6173	.6722
2	.679	.7468	.6173	.6722		.6173	.6722
3	.7545	.9335	.6859	.6722		.6859	.6722
4	.9431	1.1088	.7202	.7468		.6859	.8215
5	1.1203	1.2936	.9945	.924		.9945	1.1203
6	1.4937	1.2936	1.2346	1.2936		1.166	1.307
10	.9335	.924			.8573	1.1203	
11	.9335	.8131			.7545	.9335	
12	.7468	.8131			.7545	.8589	
13	.5601	.7468			.7202	.8589	
14	.5601	.7468			.7202	.8589	
15	.5601	.6722			.6859	.8589	
16	.5601	.6348			.6859	.8589	
17	.7468	1.4327				.8589	
18	.924	1.6389	.924			.9335	
19	.924		.924			1.0349	
20	.924	.8916	.8871			1.0349	
21	.7392	.9602	.8501			.7842	
22	.7392	.8573	.7468		.8573	.6722	
23	.7468	.7545	.6722		.7545	.6722	
24	.6722	.7468	.6173	.6722		.6859	.6722
Max	1.4937	1.6389	1.2346	1.2936	.8573	1.166	1.307
Min	.5601	.6348	.6173	.6722	.6859	.6173	.6722
Avg	.8067	.9378	.8070	.8076	.7545	.8472	.8482

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 202 / 11 KV JAITAPUR AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494			.0373			.0373
2	.1494		.0377	.0373		.0377	.0373
3	.1867			.0373			.0373
4	.2241	.2858	.0377	.0373	.0381	.0377	.0373
5	.2801						
6	.2801	.3239					
7	.3734						
8	.5601	.3429					
9	.6535						
10	.7468						
11			.6535	.4763			1.2384
12			.9335		1.0374		
13			.8962				
14			.7468		1.226		1.7147
16			.3734	.6668	1.3203		1.7147
17			.7468	.6668			1.5242
18		.0377	.8402		1.2936		
19						.0373	
20		.0377			.0377	.0373	
21						.0373	
22		.0377	.0373		.0377	.0373	
23	.0381		.0373	.0381		.0373	.0381
24	.0373	.0381	.0377	.0373	.0381	.0377	.0377
Max	.7468	.3429	.9335	.6668	1.3203	.0377	1.7147
Min	.0373	.0377	.0373	.0373	.0377	.0373	.0373
Avg	.3066	.1577	.4482	.2261	.6286	.0375	.6417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 203 / 11 KV PIMPALGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934			.0373			.0373
2	.1494		.0377	.0373		.0377	.0373
3	.2241			.0373			.0373
4	.2801	.2858	.0377	.0373	.0381	.0377	.0373
5	.3734						
6	.4668	.3239					
7	.4668						
8	.4668	.381					
9	.5228						
10	.5975						
11			.5601	.381			.9526
12			.7468		.5658		
13			.7842				
14			.8402		.5658		.9526
15			.7468				
16			.7468	.4382	.5658		.8573
17				.4191			.8002
18		.0377			.5658		
19						.0373	
20		.0377	.0373		.0377	.0373	
21			.0373			.0373	
22		.0377	.0373		.0377	.0373	
23	.0381		.0377	.0381		.0373	.0381
24	.0373	.0381	.0377	.0373	.0381	.0377	.0373
Max	.5975	.381	.8402	.4382	.5658	.0377	.9526
Min	.0373	.0377	.0373	.0373	.0377	.0373	.0373
Avg	.3097	.1631	.3606	.1625	.3019	.0375	.3787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 204 / 11 KV SUGAON AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373			.0934			.0373
2	.0373		.1886	.0934		.1886	.0373
3	.0373			.1494			.1867
4	.0373	.0381		.1867	.2286	.3206	.1867
5				.1867			.2801
6				.2241		.4715	.4108
7				.2801			.6535
8				.4668	.5716	.8488	.8962
9				.4668			.924
10						1.0185	.7468
12		.4715					
14		.5658					
16		.5658					.0381
17			.0373	.0381			.0381
18		.5658	.0373		.0377		
19						.0377	
20		.0377			.0377		
21			.0377				
22		.0377	.0373		.0377		
23	.0381		.0373	.0381		.0373	.0381
24	.0373	.0381	.0377	.0373	.0381	.0377	.0373
Max	.0381	.5658	.1886	.4668	.5716	1.0185	.924
Min	.0373	.0377	.0373	.0373	.0377	.0373	.0373
Avg	.0374	.2901	.0590	.1884	.1586	.3701	.3222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174057 / 33 kV NALESHWAR

Feeder No / Name : 205 / 11 KV NALESHWAR GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095			.6535			.7468
2	.7468		.811	.7095		.8488	.7842
3	.7468			.8402			.8871
4	.8962	.6478	.8865	.8402	.8002	1.0185	1.1203
5	1.0269			1.0269			1.2567
6	1.2136	1.1622	1.1317	1.2696		1.3203	1.386
7	1.1576			1.358			1.3817
8	1.1576	1.2384	1.1317	1.4003	1.3908	1.3203	1.2136
9	1.1203			1.3443			.8402
10	.9709					1.226	.6722
11			.5601	.6668			.6478
12		.6413	.3696		.6413		
13			.3361				
14		.4527	.3734		.4527		.4954
15			.4108				
16		.6413	.4668	.381	.6413		.4191
17			.5601	.4763			.724
18		.8865	.5601		.8865		
20		1.0374			1.0374		
21			.7468				
22		.8488	.7095		.8488		
23	.6668		.6535	.7621		.6535	.7621
24	.6535	.6478	.7733		.6668	.6979	.6535
Max	1.2136	1.2384	1.1317	1.4003	1.3908	1.3203	1.386
Min	.6535	.4527	.3361	.381	.4527	.6535	.4191
Avg	.9222	.8204	.6551	.9022	.8184	1.0122	.8744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 201 / 11KV MUGAT GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.6859		.6838		.6859	.6653
2	.7207	.6859		.7023		.6859	.7023
3	.7577	.7545		.7207		.7716	.7392
4	1.1458	.823		.7207		.9602	.7762
5	1.4784	1.0288		.8871		.9945	1.1088
6	1.6632	1.3375		1.4045		1.3717	1.4415
7	1.5708	1.406		1.7002		1.6118	1.6461
8	1.5154	1.4403		1.6632		1.6118	1.5524
9	1.406		1.2936	1.4937		1.4632	1.3169
10	.9602		1.1827	1.0269		1.1458	
11	.7716		.8871	.7468	1.0631	.8871	
12			.6653	.5601	.5144	1.1088	
13			.6468	.5601	.5144	1.1088	
14			.6099	.5601		1.1088	
15			.7577	.6535		1.1088	
16			.8871	.6535		1.0349	
17	1.0974		.924	.7842		.9979	
18	1.1317		.9425	.8402		1.0349	
19	1.1317		1.3306	1.1203	.6859	.961	
20	1.0974		1.3306	1.0269	1.2003	.8501	.7468
21	.823		1.2012	.9335	1.0288	.7762	.7468
22	.6859		.8686	.7095	.8573	.7392	.6535
23	.6859		.7023	.6535	.6859	.6653	.6535
24	.7392	.6859		.6838		.6859	.6653
Max	1.6632	1.4403	1.3306	1.7002	1.2003	1.6118	1.6461
Min	.6859	.6859	.6099	.5601	.5144	.6653	.6535
Avg	1.0571	.9831	.9487	.8954	.8188	1.0154	.9582



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 202 / 11 KV MATASAB AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2957	.4115				
2	.2957	.4115				
3	.2957	.4115				
4	.3696	.4115				
5	.3696	.4115				
6	.3696	.4115				
7	.4435	.3429				
8	.4435	.3048				
9	.4115	.3048				
10	.4115	.3048				
11			.3696	.3048	.3429	.3734
12			.3696	.3048	.3429	.3734
13			.3696	.3048	.3429	.3734
14			.3696	.3048		.3734
15			.3696	.3048		.3696
16			.3696	.3048		.3696
17			.3696	.3048		.3696
18			.3696	.3048		.3696
Max	.4435	.4115	.3696	.3048	.3429	.3734
Min	.2957	.3048	.3696	.3048	.3429	.3696
Avg	.3706	.3726	.3696	.3048	.3429	.3715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174062 / 33KV AMDURA

Feeder No / Name : 203 / 11 KV AMDURA AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1372	.1524	.2218		.1715	.3658
2	.1867	.1372	.1524	.2218		.2058	.3658
3	.2241	.1372	.1524	.2218		.2058	.3658
4	.2218	.1372	.1524	.2957		.2058	.3658
5	.2218	.1372	.2286	.2957		.2058	.4024
6	.2218	.1372	.2286	.2957		.3429	.4024
7			.2286	.2957		.3429	.5853
8			.2743	.4435		.6173	.5853
9			.3696	.3658		.6447	.6584
10			.3696	.3048		.7164	
11	.3429	.2591					
12		.2743					
13		.2743					
14		.2439					
15		.2286					
16		.2286					
17		.2286					
18	.3429	.1524					
19	.1372	.1524	.1494	.1524	.1372	.1357	
20	.1372	.1524	.1494	.1524	.1372	.1357	.1524
21	.1372	.1524	.1494	.1524	.1372	.1357	.1524
22	.1372	.1524	.1494	.1524	.1372	.1357	.1524
23	.1372	.1524	.1494	.1524	.1372	.1357	.1524
24	.1494	.1372	.1524	.1494		.1372	.1357
Max	.3429	.2743	.3696	.4435	.1372	.7164	.6584
Min	.1372	.1372	.1494	.1494	.1372	.1357	.1357
Avg	.1962	.1806	.2005	.2421	.1372	.2797	.3459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 201 / 11 KV TRIKUT AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0857	.0934	.0857	.0934
2			.0857	.0934	.0857	.0934
3			.0857	.0934	.0857	.0934
4			.0857	.0924	.0857	.0934
5			.0857	.0934	.0857	.112
6			.0857	.0943	.0857	.1307
7			.0857	.0943	.0857	.1307
8			.0857	.0943	.0857	.1307
9			.0857		.0857	.1307
10					.0857	.1307
14	.0857					
16	.0857					
17	.0857					
18	.0857	.0857				
19	.0857					
20	.0857					
24	.2572					
Max	.2572	.0857	.0857	.0943	.0857	.1307
Min	.0857	.0857	.0857	.0924	.0857	.0934
Avg	.1102	.0857	.0857	.0936	.0857	.1139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 202 / 11 KV MATASAB GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2926	.2987		.2743	.3361
2	.2801	.2926	.2801		.2743	.3361
3		.2926	.2957		.2926	.3734
4		.4024	.3696		.3292	.4668
5		.5487	.5601		.4755	.6535
6		.7316	.7922		.695	.7468
7		.7316	.9054		.7682	.4668
8		.7316	.7545		.6219	.4668
9		.5487			.439	.5228
10					.5487	.4668
11		.3361			.4668	
12		.2241		.2195	.4668	
13		.1867		.1829	.3734	
14	.3429	.1867			.4527	.4287
15		.1848		.2561	.3734	
16	.3429	.2801		.3292	.3734	.4287
17	.4525	.4668		.439	.4668	.5144
18	.4525	.5601			.4668	.5144
19	.543			.5487	.4668	.5144
20	.543	.4668		.4755	.4854	.6001
21	.543	.2987		.3658	.4481	.6001
22	.543	.2987		.3292	.3326	.5144
23	.4525	.2987		.2926	.2957	.5144
24			.2801		.2926	.2926
Max	.543	.7316	.9054	.5487	.7682	.7468
Min	.2572	.1848	.2801	.1829	.2743	.2926
Avg	.4321	.3981	.5040	.3439	.4367	.4879

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 203 / 11 KV MUGHAT RLY STN

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.0857	.0934		.0857	.0934
2	.4287	.0857	.0934		.0857	.0934
3	.4287	.0857	.0934		.0857	.0934
4	.3658	.0857	.0934		.0857	.0934
5	.4115	.0857	.0934		.0857	.0934
6	.3658	.0857	.0943		.0857	.0934
7	.4115					
8	.3429					
9	.4481					
10	.3772					
11		.3734		.3772	.3734	.381
12		.5601		.5487	.4668	.4572
13		.5601		.6584	.5228	.5335
14		.6535			.6036	.5335
15		.5914		.4755	.6535	.6097
16		.5975		.5853	.7468	.6859
17		.5975		.6584	.7468	.6859
18		.3734				.6859
19	.0905			.0857	.0934	.0857
20	.0905	.0934		.0857	.0934	.0857
21	.0905	.0934		.0857	.0934	.0857
22	.0905	.0934		.0857	.0924	.0857
23	.0905	.0934		.0857	.0914	.0857
24	.0857		.0934		.0857	.0914
Max	.4481	.6535	.0943	.6584	.7468	.6859
Min	.0857	.0857	.0934	.0857	.0857	.0857
Avg	.2842	.2886	.0935	.3393	.2725	.2826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 204 / 11 KV DHANAJ AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0857		.0686	.1715
2		.0857		.0686	.1886
3		.0857		.1029	.1886
4		.0857		.1029	.2229
5		.0857		.0857	.2401
6		.0857		.2058	.2743
7		.2058	.0514	.3772	.4458
8		.2058	.0857	.5853	.6001
9		.2572		.5487	.6859
10				.6584	.6859
16	.2534				
17	.2743				
18	.3429				
19	.3429				
20	.2401				
Max	.3429	.2572	.0857	.6584	.6859
Min	.2401	.0857	.0514	.0686	.1715
Avg	.2907	.1314	.0686	.2804	.3704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174082 / 33 kV MAATASAB

Feeder No / Name : 205 / 11 KV GURUDWARA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0514	.0514		.0686	.0514
2	.0686	.0514	.0514		.0686	.0514
3	.052	.0514	.0514		.0686	.0514
4	.0514	.0514	.0514		.0686	.0514
5	.0514	.0514	.0514		.0686	.0514
6	.0514	.0514	.0514		.0686	.0514
7	.0514		.0514		.0686	.0857
8	.0514	.0343	.0686		.0686	.0857
9	.0514	.0343			.0686	.0857
10	.0514				.0686	.0857
11	.0514	.0514		.0686	.0686	.0762
12	.0514	.0514		.0686	.0686	.0762
13		.0686		.0686	.0857	.061
14	.0514				.0857	.061
15		.0686		.0686	.0857	.061
16	.0514	.0686		.0686	.0857	.061
17	.0514	.0686		.0514	.0686	.0686
18	.0686	.0686			.0514	.0686
19	.0686			.0686	.0514	.0686
20	.0686	.0686		.0686	.0514	.0686
21	.0686	.0686		.0686	.0514	.0686
22	.0686	.0514		.0686	.0514	.0514
23	.0686	.0514		.0686	.0514	.0514
24	.0686		.0514		.0857	.0514
Max	.0747	.0686	.0686	.0686	.0857	.0857
Min	.0514	.0343	.0514	.0514	.0514	.0514
Avg	.0587	.0559	.0533	.0670	.0679	.0644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 201 / 11 KV NEELA GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	1.0456		.9709		1.0082	.9709
2	.9709	1.0456		1.0082		.9709	1.0082
3	1.0082	1.0829		1.0829		1.0082	1.0829
4	1.307	1.3443		1.307		1.3443	1.307
5	1.8484	1.8298		1.8298		1.8484	1.8484
9						1.6057	
10	1.307					1.5684	
11			1.1203		1.1203		
12	.7468				.8215		
13	.6348		.5975			1.419	
14	.6348		.7842			1.3443	
15	.6722		.9335			1.2136	1.1203
16			1.0456	1.0829		1.1203	1.0082
17			1.251			1.2136	1.0829
18	1.307	1.3443	1.307			1.307	1.1203
19	1.531	1.4937	1.4937		1.4937	1.2323	1.1949
20	1.3817	1.4563	1.307	1.4937	1.4937	1.1203	1.307
21	1.1949	1.2696	1.1203		1.3443	1.0829	1.1203
22	1.0456	1.0456	1.0829		1.1203	1.0269	1.0456
23	1.0082	1.0082	1.0456		1.0456	.9896	1.0829
24	.9709	1.0082		.9709		1.0082	.9709
Max	1.8484	1.8298	1.4937	1.8298	1.4937	1.8484	1.8484
Min	.6348	1.0082	.5975	.9709	.8215	.9709	.9709
Avg	1.0906	1.2478	1.0907	1.2183	1.2056	1.2333	1.1514



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174083 / 33 kV NEELA

Feeder No / Name : 202 / 11 KV CHIKHALI AG

AG Feeder with SDT

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0267	.1829		.2172		.1943	.2201
2	.16	.2134		.2896		.2073	.2934
3	.2614	.2743		.362		.2469	.3715
4	.192	.2743		.4401		.2469	.4458
5	.2115	.3353		.6602		.282	.602
6	.2115			.7335		.5502	.8278
7	.3909	.3353		.8173		1.0974	1.1431
8	.5053			.7876	1.0402	1.2498	1.4022
9	.5487			.7676		1.2651	
10	.3048					1.1589	
11			.2641				
12	.6097		.2675				
13	.6554		.2709			.443	
14	.6859		.2743			.4694	
15	.5487		.2743			.4988	.301
16			.4115	.3269		.5418	.4572
17			.4725			.5719	.4923
18	.6097	.7145	.3048			.5944	.3948
19							.0377
20		.0377	.0377	.029	.0377	.056	.0377
21		.0377	.0377		.0377	.056	
22		.0377	.0373		.0377	.0373	.0377
23	.112	.0377	.0373		.0377	.037	.0377
24	.0373	.112	.0377	.037		.0377	.037
Max	.6859	.7145	.4725	.8173	1.0402	1.2651	1.4022
Min	.0267	.0377	.0373	.029	.0377	.037	.037
Avg	.3571	.2161	.2098	.4557	.2382	.4687	.4199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174128 / 33 KV RAHATI

Feeder No / Name : 201 / 11 KV RAHATI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2401	.3174				.2614
2		.2401	.3361				.2614
3		.2743	.3174				.2614
4		.4115	.4108				.2987
5		.5487	.5601				.5601
6		.6173	.5975				.5601
7		.583	.4108				.6722
8			.4854				.6722
9	.543			.5676			
10	.3429			.3982			
11	.2058		.1324	.181		.4854	
12	.1715			.181			
13	.1372			.181		.3734	
14	.1372		.1513	.181		.3734	
15	.1715		.1892	.181		.3734	
16	.2572			.2353		.3734	
17	.3086	.2801		.362		.3734	.3801
18	.3429	.3361		.362		.4108	
19	.4287	.5788		.4525		.3921	
20	.4458	.4481		.5068		.2987	
21	.4115	.4108		.3439		.2987	
22	.3429	.3734		.3077		.2801	
23	.2743	.2987		.2715		.2801	.2715
24	.2534	.2743	.2987		.2534		.2614
Max	.543	.6173	.5975	.5676	.2534	.4854	.6722
Min	.1372	.2401	.1324	.181	.2534	.2801	.2614
Avg	.2984	.3944	.3506	.3142	.2534	.3594	.4055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174128 / 33 KV RAHATI

Feeder No / Name : 203 / 11 KV GODAWARI RAHATI AG Ag dominated/Pure Ag  
Feeder KV- 11 / OUTGOING

DATE	24-JUL-17	25-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
13			.0747	
14	.0511		.0747	
15	.0568		.0747	
16			.0747	
17			.0747	.0914
18		.0152	.0747	
19			.0747	
Max	.0568	.0152	.0747	.0914
Min	.0511	.0152	.0747	.0914
Avg	.0540	.0152	.0747	.0914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED DIVSION[241]

NANDED RURAL-I S/DN[443] BU 2429

Substation No/ Name :- 174130 / 33 KV TALANI

Feeder No / Name : 201 / 11 KV TALANI GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2427	.2646		.2614	.2614	.2957
2	.2012	.2427	.2646		.2614	.2614	.2957
3	.2713	.2801	.378		.2987	.2987	.2957
4	.3429	.4805	.6054		.3841	.3361	.3292
5	.3772	.6283	.6426		.5853	.3734	.3658
6	.4801	.5175	.6426		.695	.4805	.5121
7	.5144	.7133	.6426		.6935	.6584	.6154
8	.5658	.6089	.6426			.695	.6878
9	.4115		.5103			.6584	.6516
10	.2054					.567	.5658
11	.1663					.5175	.4801
12	.1494	.0944		.1307			.3772
13	.1494			.1307			.3086
14		.0945		.1494			.2743
15				.1867			.2058
16		.378		.2241			.2401
17				.2987			.2743
18	.5415	.3398		.3361			.2743
19	.5228			.3841	.5601	.3881	.3601
20	.4108	.3024			.5228	.3696	.4458
21	.3361				.3921	.3326	.3429
22	.2987	.2835		.2987	.3361	.2957	.2743
23	.2801			.2801	.2987	.2957	.2401
24	.2401	.2614	.2835		.2614	.2614	.2957
Max	.5658	.7133	.6426	.3841	.695	.695	.6878
Min	.1494	.0944	.2646	.1307	.2614	.2614	.2058
Avg	.3335	.3645	.4877	.2419	.4270	.4148	.3754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 201 / 11 KV KANDHAR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.267	1.1431		1.1765	1.086	1.086
2	1.2012	1.267	1.1431		1.086	1.086	1.086
3	1.2936	1.267	1.1431		1.1765	1.1765	1.086
4	1.2936	1.3575	1.2955		1.267	1.1765	1.1765
5	1.386	1.3575	1.4098		1.267	1.267	1.267
6	1.4784	1.448	1.5242		1.448	1.448	1.448
7	1.6632	1.5384	1.7147		1.6289	1.3575	1.6289
8	1.4784		1.5242		1.448	1.267	***
9	1.2936		1.448	1.3575	1.267	1.267	1.6289
10				1.267	1.267	1.3575	1.6289
11				1.267	1.267		1.7194
12	1.448			1.086	1.267	1.448	1.5384
13	1.448			1.086	1.3575	1.5384	1.5384
14				1.267	1.3575		1.448
15	1.5384			1.267	1.3575		
16	1.5384			1.267	1.267		1.448
17	1.448			1.448	1.267		1.448
18	1.5384			1.448	1.267		1.448
19	1.448			1.448	1.448		1.5384
20	1.5023			1.5384	1.5384		1.5384
21	1.5023			1.448	1.5384		1.267
22	1.5023			1.267	1.448		1.3575
23	1.448			1.267	1.267		1.267
24	1.1088	1.3575	1.1431		1.086	1.267	1.267
Max	1.6632	1.5384	1.7147	1.5384	1.6289	1.5384	17.303
Min	1.1088	1.267	1.1431	1.086	1.086	1.086	1.086
Avg	1.4171	1.3575	1.3489	1.3153	1.3236	1.2879	2.0940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 202 / 11 KV AMBULGA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.4715	1.0974			1.267	1.086
2	.4066	.4715	1.0974			1.6289	1.086
3	.4066	.5658	1.0974			1.8099	1.267
4	.462	.5658	1.4998			1.8099	1.448
5	.5544	.5658	1.4998			2.3529	1.8099
6	.5544	.3772	1.6461			2.3529	1.9909
7	.5544	.4715				.4525	
8	.462					.4525	
9	.462			1.6289	.4525	.4525	
10	.4715			1.3575	.362	.362	.4715
11				1.3575	.362		.4715
12	.4715			.4525	.362		.4715
13	.4715			.3506	.362		.5658
14				.362	.362		.4715
15	1.286			.362	.362		
16	1.286			.362	.362		.4715
17	1.2003				.362		.3772
18	1.286				.362		.6602
19	1.2003				.4525		.5658
20	1.286				.4525		.6602
21	1.286				.4525		.5658
22	1.2003				.543		.5658
23	.5658				.905		1.4575
24	.462	.5658	1.1706			1.267	.905
Max	1.286	.5658	1.6461	1.6289	.905	2.3529	1.9909
Min	.4066	.3772	1.0974	.3506	.362	.362	.3772
Avg	.7635	.5069	1.3012	.7791	.4344	1.2916	.8684

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 203 / 11 KV PANBHOSI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.8573	.3429		.362	.362	.362
2	.5544	.8573	.3429		.362	.362	.362
3	.5544	1.0288	.3429		.362	.362	.2715
4	.7392	.8573	.3429		.362	.362	.2715
5	.924	.9431	.3429		.362	.362	.2715
6	.3696	.9431	.3429		.905	.4525	.362
7	.3696	.2829	.3429			.724	
8			1.0974		.724	.905	
9	.3696		1.0974		1.086	.905	
10	.2829				.905	.905	
11	.2829				.905		
12	.2829				.8145		
13	.2829				.905		
14					.905		
15	.3772				.2715		
16	.3772				.2715		.0857
17	.2829				.2715		.5144
18	.2829				.2715		.8573
19	.3772				.362		.8573
20	.4715				.362		.9431
21	.4715			.362	.362		.9431
22	.3772			.362	.362		.7716
23	1.0288			.362	.362		.4715
24	.7316	.9431	.3429		.362	.362	.362
Max	1.0288	1.0288	1.0974	.362	1.086	.905	.9431
Min	.2829	.2829	.3429	.362	.2715	.362	.0857
Avg	.4786	.8391	.4938	.362	.5312	.5512	.5138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174026 / 33 KV KANDHAR

Feeder No / Name : 204 / 11 KV KURULA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.5658	.3429			.2715	.2715
2	.3658	.4715	.3429			.362	.2715
3	.3658	.4715	.3429			.362	.2715
4	.3658	.4715	.3429			.4525	.2715
5	.3658	.5658	.4115			.4525	.362
6	.3658	.3772	.4115			.543	.362
7	.7316	1.0288				.362	.362
8	.9145						.362
9	1.0974			.362	.362		.3772
10	1.0288			.2715			.3772
11	1.0288			.2715			.3772
12	1.0288			.2715	.2715		.4715
13	1.2003			.2715	.2715		.4715
14				.2715	.2715		.2829
15	.4287			.724	.724		
16	.4287			.724	.724		.5658
17	.3772			.905	.8145		
18	.4715			.905	1.086		.5144
19	.3772			1.086	1.086		.5144
20	.5658			1.267	.905		.5144
21	.5658			1.267	.905		.4287
22	.5658			1.086	.905		.3772
23	.4715			.362	.2715		.3772
24	.3658	.4715	.3429		.362	.2715	.2715
Max	1.2003	1.0288	.4115	1.267	1.086	.543	.5658
Min	.3658	.3772	.3429	.2715	.2715	.2715	.2715
Avg	.6019	.5530	.3625	.6697	.6400	.3846	.3843



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174033 / 33 KV BARUL

Feeder No / Name : 202 / 11 KV PETHWADAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112		.1307	.112	.1307	.112	.112
2	.0934		.2614	.3734	.5601	.5975	.5601
3	.0747		.4108	.4108	.6348	.7095	.5975
4	.0934		.5601	.4481	.6722	.7842	.6348
5	.112		.6535	.4668	.7468	.8589	.6908
6	.1494		.6908	.5601	.8589	.9335	.7468
7	.168		.6908	.5975	.9709		.7842
8	.1494			.6535	1.1203		
9	.1307		.6535	.6908		.9709	
10	.4668	.4108	.112	.112		.112	.7095
11	.3734	.5975	.0934	.0747	.0747	.0934	1.0269
12		.5601	.0747	.0747	.056	.0747	.9709
13	.2987	.168	.0747	.056	.0747	.0934	.9335
14		.1494	.0934	.0747	.0747	.112	.0747
15		.4108	.112	.0934	.0747	.112	
16	.2801	.5975	.112	.056	.0934	.1307	.0747
17	.2987	.6722	.1307	.056	.0934	.1307	.0934
18	.3734	.0934	.1494	.0934	.112	.1509	.112
19	.3734	.1494	.168	.112	.1307	.1698	.1494
20	.1886	.2241	.1867	.1494	.1867	.1698	.168
21	.1698	.168	.168	.168	.168	.1886	.168
22	.1698	.1494	.168	.168	.1494	.1698	.168
23		.1307	.1494	.1494	.1307	.132	.1494
24	.1307		.1307	.1307	.1307	.112	.1307
Max	.4668	.6722	.6908	.6908	1.1203	.9709	1.0269
Min	.0747	.0934	.0747	.056	.056	.0747	.0747
Avg	.2103	.3201	.2598	.2451	.3293	.3145	.4312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 201 / 11 KV KURULA AG

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857					
2	.0857					
3	.1143					
4	.1429					
5	.1715					
6	.2439					
7	.3795					
8	.4001					
9	.3521					
10	.2561					
11		.3521		.583	.5937	
12		.5121	.5243	.6478	.6097	
13		.3841	.5571		.6097	
14		.4752	.5243		.6722	.6325
15		.4915				.6722
16			.6226		.6882	.7042
17			.6401		.6562	.6722
18		.5407	.6401		.6401	.6483
Max	.4001	.5407	.6401	.6478	.6882	.7042
Min	.0857	.3521	.5243	.583	.5937	.6325
Avg	.2232	.4593	.5848	.6154	.6385	.6659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 202 / 11 KV KURULA GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095		.7468	.7468	.7842	.7468	.7095
2	.7095		.7468	.7468	.7842	.7468	.7095
3	.7095		.7468	.7468	.7842	.7468	.7095
4	.8402		.8402	.8402	.8402	.8962	.8402
5	.9709		.9709	.9335	1.0269	.9709	1.0269
6	1.2696		1.2136	1.1203	1.2883	1.1016	1.2136
7	1.2883		1.3443	1.307	1.1763	1.3443	1.307
8	1.2136		1.1763	1.2883	1.1949	1.3817	1.2696
9	1.0829		1.0269	1.0829		1.1389	1.1949
10	.8215					1.0269	1.1203
11			.4207		.6722	.8589	
12			.4024	.5228	.2614	.7468	
13	.499		.3658	.4668		.7095	
14			.6219	.5228		.4108	.5304
15			.567				.5175
16	.5792			.5228		.6161	.5175
17				.4854		.6283	.6516
18	.695		.6584	.5975			.7421
19	.961		.8316	.8779			
20	1.1949		1.0642	1.2696		.7655	
21	.9709		.9335	1.0456		.7655	.8962
22	.8589		.8589	.9335	.9335	.7468	
23		.8029	.7842	.8962	.8402	.7095	
24	.7468		.7468	.7468	.8402	.7842	.7095
Max	1.2883	.8029	1.3443	1.307	1.2883	1.3817	1.307
Min	.499	.8029	.3658	.4668	.2614	.4108	.5175
Avg	.8956	.8029	.8128	.8429	.8790	.8497	.8627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174045 / 33 KV KURULA

Feeder No / Name : 203 / 11 KV DIGRAS AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1235	.1966	.0714	.1429	.1638
2			.2458	.0714	.1715	.1638
3			.2458	.1143	.2143	.1638
4			.2949	.1429	.2675	.1638
5			.3277	.1783	.3048	.2241
6			.3932	.2286	.3353	.2458
7			.4588	.3048	.3887	.2785
8			.3605	.4877	.5506	.3441
9			.2458		.5668	.3277
10					.5668	.3277
11		.2458				
12		.213				
13	.1189	.1966				
16	.1656					
18	.1509					
24				.0714		
Max	.1656	.2458	.4588	.4877	.5668	.3441
Min	.1189	.1235	.1966	.0714	.1429	.1638
Avg	.1451	.1947	.3077	.1856	.3509	.2403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 201 / 11 KV JANGAMWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2774	.1086	.1772		.181	.2172
2		.2947	.1086	.1753		.1791	.181
3	.362		.128	.1753		.197	.2195
4			.1086	.1734		.2149	.181
5			.1086	.1753		.2103	.181
6	.4525		.128	.1928		.2279	.2172
7	.4344		.1267	.1928		.208	.2534
8	.5068		.1448	.1907		.208	.2353
9	.5201		.1267	.1372		.1907	.1991
10	.3887			.0848	.1696	.2172	.2126
11	.116			.4424	.4191	.7964	.6783
12	.0983			.3563	.6081	.8326	.8619
13	.0655			.3239	.6562	.7973	.7956
14				.3241	.6718	.7796	
15	.0655			.3906	.6562	.823	
16	.0838	.0905		.4096	.6882	.8779	.7459
17	.116	.0724		.4475	.7042	.8326	.6554
18	.1357	.0905		.5636	.6718	.823	.663
19	.1867	.181		.168	.2195	.2172	.2054
20	.2402	.2172		.3734	.2772	.2172	.2427
21	.2218		.2218		.2218	.2172	.2241
22	.2012	.2172	.2033		.2054	.181	.2033
23	.2012	.1448	.1848		.1867	.181	.2033
24	.181	.2033	.1448	.1829		.1867	.181
Max	.5201	.2947	.2218	.5636	.7042	.8779	.8619
Min	.0655	.0724	.1086	.0848	.1696	.1791	.181
Avg	.2409	.1789	.1418	.2694	.4540	.4082	.3526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 202 / 11 KV HARBAL

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2774	.8688	.4961		.5792	.5487
2		.2774	.8326	.5258		.6089	.5258
3	.1629	.298	.8688	.631		.6626	.6401
4		.298	.8688	.7975		.7164	.6335
5		.3189	.905	.9465		.7011	.724
6	.181	.3582	.9412	1.0517		.7888	.905
7	.181	.3761	.9774	1.2445		1.1269	.9593
8	.181		1.0136	1.2136		1.4737	1.0679
9	.2601		1.1222	1.2003		1.1443	1.0136
10	.2267			.5935	1.1869	1.1641	.8505
11	.431			.1966	.0838	.2534	.2204
12	.4915			.1457	.064	.2715	.1658
13	.7537			.1296	.0625	.2534	.1658
14				.1389	.125		
15	.4915			.1562	.1094	.2172	
16	.6874	.9412		.1638	.128	.1829	.1326
17	.7459	1.1584		.1658	.16	.2172	.1311
18	.7461	1.0136	.2172	.1658	.125	.2172	.1989
19		.3841	.2947	.2987	.1829	.2896	.3361
20	.4066	.3801	.3898	.4108	.2587	.362	.4108
21	.3881	.362	.3326		.2772	.3258	.3734
22	.3658	.3439	.3326		.2801	.3734	.3326
23	.3292	.3439	.3142		.2241	.3258	.3326
24	.5068	.3142	.3258	.3109		.2241	.362
Max	.7537	1.1584	1.1222	1.2445	1.1869	1.4737	1.0679
Min	.1629	.2774	.2172	.1296	.0625	.1829	.1311
Avg	.4187	.4653	.6628	.5230	.2334	.5426	.5014

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174070 / 33 KV PHULWAL

Feeder No / Name : 203 / 11 KV PANSHEWADI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1214	.3292	.2658		.2896	.2743
2		.1214	.3258	.2804		.3224	.2715
3	.0905	.1227	.362	.3155		.3224	.362
4		.1402	.362	.3121		.3582	.362
5		.1417	.4024	.3506		.4207	.3982
6	.1267	.1612	.4344	.3681		.4382	.4344
7	.1267	.1791	.4344	.4382		.5201	.4525
8	.1267		.4755	.5201		.5721	.4344
9	.104		.4887	.4458		.3988	.4525
10	.0648			.2035	.4748	.3982	.3898
11	.1989			.0655	.0838	.1086	.0848
12				.0648	.08	.0732	.0829
13					.0625	.0732	.0663
14		.2353			.0625	.0905	
15	.1311	.2172			.0625	.1086	
16	.2347	.362		.0655	.08	.0905	.0829
17	.2652	.3982	.081	.0663	.096	.0905	.0655
18	.2035	.4572	.0905	.0829	.0937	.1086	.0995
19	.112	.1267	.1214	.1307	.1097	.1463	.1494
20	.1663	.1097	.1417	.1494	.1478	.1463	.168
21	.1663	.1448	.1478		.1478	.1267	.1494
22	.1463	.1448	.1478		.1494	.1448	.1478
23	.1463	.1267	.1294		.1307	.1267	.1294
24	.2353	.1294	.1267	.128		.1307	.1097
Max	.2652	.4572	.4887	.5201	.4748	.5721	.4525
Min	.0648	.1097	.081	.0648	.0625	.0732	.0655
Avg	.1556	.1911	.2706	.2363	.1272	.2336	.2349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 201 / 11 KV PETHWADAJ

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.5658	1.1203	1.0269	.9145	1.1203	1.1203
2	.462	.5658	1.0269	.924	.9145	1.0269	.9335
3	.462	.5658	1.0269	.924	.9145	1.0269	.9335
4	.462	.5658	1.0269	.924	1.0059	1.0269	.9335
5	.462	.6602	1.0974	1.0059	1.0974	1.0059	1.1203
6	.5487	.6535	1.0974	1.0059	1.0974	1.0974	1.0974
7	.7316	.7392	1.0974	1.0059	1.0974	1.0974	1.0974
8	.9145	.7392	1.0059	1.0974		1.0059	1.0974
9	.823		.9145		1.0974		
10	.823		.823		.7316		
11	.3658		.5487		1.0059	.9145	
12	.3658		.6401	.823	1.0059	1.0974	.823
13	.3658		.6401	.9145	1.0974	1.0974	.823
14			.6468	.9145	1.0974	1.0974	.823
15	.4572		.6468	.9145		1.0059	.823
16	.5487	.5487		.9145		.9145	.823
17	.5487	.5487	.6468	.823			.9145
18	.6401	.5487	.7392	.823			.9145
19	1.1203	.8488	.9335	1.1317			
20	1.2826	1.1317	1.2136	1.3203		1.226	
21	1.226	1.226	1.226	1.3203		1.226	
22	1.226	1.226	1.1317	1.226	1.3203	1.1317	
23	1.1317	1.1317	1.1317	1.1317	1.226	1.1317	1.1317
24	1.0269	1.1317	1.1317	1.0374	1.1317	1.1317	1.1317
Max	1.2826	1.226	1.226	1.3203	1.3203	1.226	1.1317
Min	.3658	.5487	.5487	.823	.7316	.9145	.823
Avg	.7155	.7881	.9354	1.0099	1.0472	1.0727	.9730



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174085 / 33 KV PETHWADAJ

Feeder No / Name : 202 / 11 KV WARWANT

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.8488	.5601	.5601	.823	.7468	.6535
2	.7392	.8488	.5601	.6468	.823	.8402	.6535
3	.7392	.8488	.5601	.7392	.9145	1.0269	.6535
4	.8316	.9431	.7468	.7392	.9145	1.1203	.7468
5	.8316	.9808	.823	.823	1.0974	1.1888	.8402
6	1.0974	1.0269	.9145	.9145	1.1888	1.2803	.9145
7	1.1888	1.1088	.9145	1.0974	1.1888	1.2803	1.0059
8	1.0974	1.0164	1.0059	1.0059		1.3717	1.1888
9	.9145		.823		1.1888		
10	.9145		.7316		1.0974		
11	.7316		.5487		.6401	.7316	
12	.6401		.4572		.6401	.7316	.6401
13	.7316		.4572		.5487	.7316	.6401
14			.5544	.7316	.5487	.7316	.5487
15	.6401		.5544	.7316		.7316	.5487
16	.7316	.823		.7316		.6401	.6401
17	.7316	.823	.6468	.7316			.7316
18	.823	.7316	.6468	.823			.7316
19	.9335	.7545	.8402	.9431		.8488	
20	1.1317	.9431	1.1203	1.1317		.9431	
21	1.0374	.9431	1.0374	1.1317		.9145	
22	1.0374	.9431	.9431	1.0374	1.0374	.9431	
23	.9431	.9431	.9431	.9431	.9431	.8488	.9431
24	.8402	.9431	.8488	.8488	.9431	.9431	.8488
Max	1.1888	1.1088	1.1203	1.1317	1.1888	1.3717	1.1888
Min	.6401	.7316	.4572	.5601	.5487	.6401	.5487
Avg	.8716	.91	.7495	.8585	.9086	.9297	.7606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 201 / 11 KV BACHOTI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4275		.8541	.8775		.8897	.8764
2	.4453		.8541	.8596		.9253	.9114
3	.4453		.8907	.8596		.9965	.9816
4	.5327		.9253	1.0029		1.0321	1.0166
5	.567		1.0332	1.0208		1.1389	1.1218
6	.6024		1.1389	1.0387		1.2812	1.262
7	.7796		1.3524	1.2178		1.3346	1.262
8	.8907		1.2456	1.2536		1.388	1.2971
9	.8194		1.1744			.8541	1.0517
10	.7125					.9609	1.0517
11	.7125		.6556	.8764	1.0321	.8764	
12			.815	.9114	1.1389	.7011	
13			.8505		1.21	1.0517	1.3437
14		.6413			1.21	1.1919	1.2403
15	.6755	.7482			1.2456	1.2269	1.2336
16	.7482	.8194				1.262	1.0926
17	.8194	.8551				1.3321	.4934
18	.3741	.9263	1.0277			1.4022	.6697
19	.8551	.9976	1.2536		1.0677	1.0517	
20	1.2826	1.1044	1.2178			1.1919	1.2048
21	1.1401	1.0332	1.1462			1.1568	1.0985
22	1.0332	.9976	1.0387		1.0677	1.0517	
23	.9263	.9619	.9492		1.0321	1.0166	.9568
24	.8551		.8897	.8775		.9609	.9465
Max	1.2826	1.1044	1.3524	1.2536	1.2456	1.4022	1.3437
Min	.3741	.6413	.6556	.8596	1.0321	.7011	.4934
Avg	.7450	.9085	1.0165	.9814	1.1255	1.0948	1.0556

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 202 / 11 KV CHINCHOLI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6769		.3203	.2835		.3559	.3506
2	.6769		.3559	.2658		.3915	.3856
3	.6591		.3915	.3189		.4627	.4557
4	.799		.4982	.3544		.5338	.5258
5	1.0631		.6228	.3898		.6762	.6661
6	1.1517		.6406	.4252		.8363	.7888
7	.9036		.6762	.4784		.9253	.7888
8	.9085		.7652	.7265		.8008	.8589
9	.7838		.7296			.8186	.7712
10	.6413					.7652	.7362
11	.3206		.5552	.4031	.5516	.7011	
12			.4656	.4031	.4982	.7011	
13		.57	.4119				.4774
14		.5344			.3915	.5258	.5316
15	.1955	.4988			.4449	.5258	.4934
16	.2672	.4453				.6135	
17	.3206	.4988				.7186	.7049
18	.3563	.5344	.6268			.8939	.793
19	.9619	.7482	.8238		.8186		
20	1.0688	.8016	.788			.7712	.9568
21	.8551	.766	.7164			.7362	.7442
22	.7125	.7125	.6626		.6762	.7011	
23	.6235	.6769	.6447		.6406	.631	.6379
24	.7125		.6228	.6447		.605	.5959
Max	1.1517	.8016	.8238	.7265	.8186	.9253	.9568
Min	.1955	.4453	.3203	.2658	.3915	.3559	.3506
Avg	.6980	.6170	.5957	.4267	.5745	.6678	.6454

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174086 / 33 KV BACHOTI

Feeder No / Name : 203 / 11 KV BAMNI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7304		.3915	.4784		.4982	.4908
2	.7304		.4271	.5316		.5338	.5258
3	.7125		.4982	.6379		.605	.5959
4	.799		.6406	.7619		.7118	.7011
5	.8859		.8186	.7973		.8541	.8413
6	.9391		.9253	.8328		1.0855	1.0692
7	.9745		.9787	.9391		1.3524	1.3146
8	.8016		1.0855	.9922		1.5659	1.4198
9	.6413		1.0321			1.5481	1.4022
10	.5522					1.4414	1.3146
11			.4784	.4207	.5338	.7011	
12			.443	.4207	.4982	.7011	
13		.7125	.3898	.4207	.4449	.7011	.5304
14		.4275				.7362	.4961
15		.1781			.3203	.7712	.5639
16	.4275	.1781				.7712	.6168
17	.4453	.1959				.8063	.7402
18	.4632	.2138			.7296	.8063	.7578
19	.5166	.9263	.9214		.8008	.8413	
20	1.0332	.8907	.8859			.8764	.8505
21	.8907	.8729	.8505			.8413	.8328
22	.8551	.8372	.7973		.8008	.7888	
23	.7838	.8194	.7619		.7652	.7712	.7619
24	.7482		.8008	.7087		.7118	.7011
Max	1.0332	.9263	1.0855	.9922	.8008	1.5659	1.4198
Min	.4275	.1781	.3898	.4207	.3203	.4982	.4908
Avg	.7332	.5684	.7293	.6618	.6117	.8759	.8263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 201 / 11 KV DIGRAS GAOTHAN  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3772	.3772	.3696	.3921	.3544	.1772
2	.3361	.3395	.3395	.3361	.3772	.3544	.1772
3	.3395	.3395	.3395	.3361	.3772	.3544	.1772
4	.3734	.3772	.3395	.3734	.415	.4252	.2126
5	.4108	.4527	.415	.4108	.4715	.4706	.2835
6	.5281	.5847	.5658	.5601	.5601	.5068	.3544
7		.6413	.6348	.5658	.5975	.543	.4656
8			.6348	.5601	.5601	.6154	.6516
9	.5228		.5601	.4904		.6584	.543
10	.4108					.6219	.4344
11		.3361	.2241		.2481		
12	.1867	.2241	.2926	.2402	.2481		
13	.2241	.2241	.2587	.1848	.2401		.2218
14		.168	.2587	.2033	.208		.2218
15	.2241	.168	.2587	.2033	.2126		.2218
16	.2218	.168		.1848	.2835		.2241
17	.2587	.1867		.2427	.362		.2195
18	.2402	.1867	.3258	.1478	.5068		.2561
19	.3696	.4481	.4024	.2614	.543		
20	.5975	.5601	.5853	.6348			.5175
21		.5228	.5121	.5544			.4435
22	.4854	.5175	.439	.4805			
23	.4481	.4481	.4066	.4481			.3734
24	.3696	.4108	.3921	.4108	.4108	.4252	.3544
Max	.5975	.6413	.6348	.6348	.5975	.6584	.6516
Min	.1867	.168	.2241	.1478	.208	.3544	.1772
Avg	.3642	.3658	.4077	.3727	.3897	.4845	.3265

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

KANDHAR (R) S/DN[447] BU 2461

Substation No/ Name :- 174101 / 33 KV DIGRAS

Feeder No / Name : 202 / 11 KV DIGRAS AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3048	.282	.4458	.6584	.5487
2			.3353	.3475	.5053	.7316	.5487
3			.4268	.3814	.5719	.9979	.6584
4			.5182	.4458	.6706	1.1088	.7682
5			.5792	.535	.7811	1.1203	.924
6			.6097	.679	.8539	1.1576	.9979
7			.7926	.8749	1.0562	1.1576	1.1088
8			.7926	.9804	1.0437	1.307	1.1088
9			.7926	.9061		1.3817	1.1203
10						1.307	1.1203
11	.4633	.7621					
12	.1486	.9145					
13	.5719	1.0059					
14		.884					
15	.4214	.9259					
16	.7621	.9568					
17	.8025	1.0185					
18	.8025	1.0185					
Max	.8025	1.0185	.7926	.9804	1.0562	1.3817	1.1203
Min	.1486	.7621	.3048	.282	.4458	.6584	.5487
Avg	.5675	.9358	.5724	.6036	.7411	1.0928	.8904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 201 / DEULGAON (OLD SAWARGAON)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
10	.2915	
11	.2915	.2915
12	.2915	.2915
13	.2915	.2915
14	.2915	.2572
15	.2915	.2572
16	.2915	.2572
17	.2915	
Max	.2915	.2915
Min	.2915	.2572
Avg	.2915	.2744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 202 / SAWARGAON (OLD SUNEGAON)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
10	.6001	
11	.6001	.7716
12	.6001	.6859
13	.6859	.6001
14	.5144	.6001
15		.6001
16	.1715	.6001
17	.1715	
Max	.6859	.7716
Min	.1715	.6001
Avg	.4777	.6430



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 203 / RAIWADI (OLD KAREGAON)

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
10	.1715	
11	.7716	.1715
12	.7716	
13	.2915	
14	.2915	
15	.2915	.2572
16	.2915	.2572
17	.8573	
Max	.8573	.2572
Min	.1715	.1715
Avg	.4673	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 204 / LOHA URBAN

Feeder KV- 11 / OUTGOING

Urban/Sheddable Urban Feeder

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
10	1.7147	
11	1.7147	1.8004
12	1.7147	1.7147
13	1.6289	1.6289
14	1.6289	1.6289
15	1.6289	1.7147
16	1.6289	1.8004
17	1.8004	
Max	1.8004	1.8004
Min	1.6289	1.6289
Avg	1.6825	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 206 / Karegaon New

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
10	.8573	
11	.8573	.6859
12	1.0288	.6859
13	.8573	
14	.8573	.5144
15	.1715	.6859
16	.1715	.8573
17	.1715	
Max	1.0288	.8573
Min	.1715	.5144
Avg	.6216	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174008 / 33 KV LOHA

Feeder No / Name : 207 / SUNEGAON NEW

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	25-JUL-17	26-JUL-17
HR	Load (MW)	Load (MW)
11		.1715
12		.1715
13	.1715	.1715
14		.1715
15		1.3717
16		1.5432
17	1.3717	
Max	1.3717	1.5432
Min	.1715	.1715
Avg	.7716	.6002

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 201 / KALAMBAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.168	.1905
2					.1867	.1646	.1905
3	.3258			.1886		.1848	.2286
4					.2241	.2218	.2286
5					.2743	.2195	.2477
6	.4344	.4382			.2957	.2561	.2858
7					.3174	.2743	.3239
8	.5068			.2452		.2743	.2858
9	.4908			.2452		.2743	.2858
10	.3944			.2103	.2172		
11	.1267		.2896	.362	.3801		
12	.1267			.362	.4525	.5335	
13	.1307			.3506	.4477	.5716	
14	.1267		.2865		.4525	.5716	
15	.128			.2896	.4477		
16	.1267		.2896	.3292	.4656		
17	.1663			.362			
18	.1848			.3982	.4733	.381	
19						.2096	
20						.2096	.4572
21			.2263		.2054	.2096	
22					.1886	.1905	
23				.1867	.1698	.1905	
24	.1886	.1494		.1886	.1867	.168	.1905
Max	.5068	.4382	.2896	.3982	.4733	.5716	.4572
Min	.1267	.1494	.2263	.1867	.1698	.1646	.1905
Avg	.2470	.2938	.273	.2860	.3168	.2775	.2650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 202 / PANGRA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1307	.1143
2					.1307	.128	.1143
3	.1829				.1307	.1448	.1143
4					.1494	.1463	.1143
5	.2534				.1494	.1646	.1334
6					.1463	.1663	.1334
7					.1463	.181	.1524
8	.5121					.1417	.1524
9	.4801			.1886		.1463	.1143
10	.3856			.1448	.128		
11	.1075		.439	.394	.5731		
12				.6535	.6697	.8192	
13				.6984	.8238	.8573	
14					.8688	.8573	
15	.0905			.5552	.905		
16	.0895		.4572	.6335	.9568		
17	.112			.6661	.9313		
18	.1086			.7602	.8238	.7621	
19						.1143	
20						.1143	.6268
21			.1509		.1867	.1143	
22					.1494	.1143	
23				.1307	.1494	.1143	
24		.132			.1307	.1494	.1143
Max	.5121	.132	.4572	.7602	.9568	.8573	.6268
Min	.0895	.132	.1509	.1307	.128	.1143	.1143
Avg	.2322	.132	.3490	.4825	.4289	.2824	.1713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 203 / TELKI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3734		.3658	.4763
2	.1886			.3658		.3544	.4763
3				.4572		.443	.4763
4				.5487	.5601	.5373	.6668
5					.6268	.6335	.6668
6	.1886	.1629			.6733	.7888	.6668
7		.181			.7186	.9465	.9145
8	.1886			.8316		1.0166	1.2384
9	.1753			.7316		1.1043	1.2384
10	.1433			.7362	.8063		.9214
11	.3189		.0943	.1267	.1307		
12	.3506			.1267		.1905	.1772
13	.3155			.1294		.2096	
14	.3189		.132		.1463	.2096	
15	.3189			.1463	.1433		
16	.3121		.1509	.1478			
17	.3982			.1829	.1629		
18	.4557				.181	.1715	
19						.1905	
20						.1905	.2452
21			.1886		.2241	.1905	
22					.1886	.1715	
23					.1494	.1715	
24	.1886	.1494		.1509	.1494	.1494	.1715
Max	.4557	.181	.1886	.8316	.8063	1.1043	1.2384
Min	.1433	.1494	.0943	.1267	.1307	.1494	.1715
Avg	.2758	.1644	.1415	.3611	.3472	.4229	.6412

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 204 / ALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.168	.1905
2					.1867	.1663	.2096
3	.4525					.1848	.2096
4					.1867	.2195	.2096
5					.2402	.2427	.2286
6	.724	.7011			.2561	.2743	.2858
7					.2715	.2926	.2858
8	.724					.2353	.2286
9	.6859			.2263		.2012	.2096
10	.631		.181	.181			
11	.1267			.4887	.5973		
12	.1307			.543	.5373	.8764	
13	.112				.5194	.8954	
14	.112				.5792	.8954	
15	.1086			.5611	.6335		
16	.1086		.4572	.6089	.6805		
17	.1433			.6335	.8145		
18	.1867			.6697	.8775	.7621	
19						.2096	
20						.2096	.6401
21			.1646		.2263	.2286	
22					.1886	.2286	
23				.168	.1698	.1715	
24	.1509	.1494			.168	.168	.1715
Max	.724	.7011	.4572	.6697	.8775	.8954	.6401
Min	.1086	.1494	.1646	.168	.168	.1663	.1715
Avg	.3141	.4253	.2676	.4534	.4196	.3489	.2608



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174017 / 33 KV KALAMBAR

Feeder No / Name : 205 / Pokharbhosi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.362	.4763
2	.132				.5544	.4382	.4763
3					.8402	.5316	.7621
4					.9335	.6268	.7621
5	.1886				.8859	.6733	.8573
6					.8859	.9745	1.0479
7					1.0029	1.262	1.1431
8	.1494					1.1443	1.1431
9	.1448			.5853		1.0517	1.1431
10	.1227			.543	.7392	1.0479	
11	.4115		.1509	.0739	.0914	.0953	
12	.4557				.0924	.1143	
13	.4607			.0934	.0914	.1143	
14	.4706				.0905	.1143	
15	.3155			.0914	.0905	.1143	
16	.3155		.1509	.0895	.0914		
17	.3544			.0934	.1109		
18	.4207			.112	.1086	.1334	
19						.1524	
20						.1524	.1509
21			.1886		.1494	.1524	
22					.1307	.1334	
23				.1307	.132	.1334	
24	.132	.1132			.1307	.132	.1334
Max	.4706	.1132	.1886	.5853	1.0029	1.262	1.1431
Min	.1227	.1132	.1509	.0739	.0905	.0953	.1334
Avg	.2910	.1132	.1635	.2014	.3764	.4388	.7360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 201 / KAPSI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3163	.5258	.4668	.3953	.5144	.5868	.4744
2	.3163	.5258	.4668	.3953	.5144	.6535	.5535
3	.3163	.5373	.4668	.3953	.5144	.5868	.5535
4	.3163	.5373	.5601	.4744	.6001	.6706	.5535
5	.3953	.5373	.7468	.4744	.6001	.7468	.6325
6	.5535	.5144	.8383	.5535	.5935	.9335	.7116
7	.7907		1.0269	.7907	.763	1.1203	.9488
8	.8697	.6859	.9335	.7907	.8478	1.2136	1.0279
9	.7907		.9335	.7907		1.307	1.1069
10	.543		.7907		1.0269		.6859
11	.543		.7907		.8383		.6859
12	.5258		.6325		.7468	.7907	.6859
13	.5258		.4744	.2572	.6535	.6325	.4287
14			.4744	.5935	.6535	.5535	.5144
15			.4744		.6535	.5535	.5144
16	.2572		.4744		.7468		.6001
17	.4287	.4668			.7468		
18	.4239		.4744	.5144	.6706	.4744	.362
19	.6001		.4744	.5144	.8402	.7116	.4525
20	.5258	.7468	.6325	.5144	.8402	.6325	.6335
21	.5258	.7468	.6325	.5144	.7468	.6325	.4525
22	.5144	.6535	.5535	.5144	.7468	.5535	.362
23	.5144	.5601	.4744	.5144	.6535	.4744	.362
24		.543	.3953		.5144	.4744	
Max	.8697	.7468	1.0269	.7907	1.0269	1.307	1.1069
Min	.2572	.4668	.3953	.2572	.5144	.4744	.362
Avg	.5044	.5831	.6169	.5293	.6968	.7151	.6047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 202 / MARTALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7011	.5601	.5601	.6859	.6706	.7468
2	.6535	.7011	.5601	.5601	.6859	.6706	.7468
3	.6535	.8059	.6535	.5601	.7716	.7468	.7468
4	.6535	.8059	.5868	.6535	.7716	.6706	.8402
5	.7468	.8145	.8402	.7468	.8573	.8402	.9335
6	.8402	.8954	1.0269	.8402	.8573	.9335	1.1203
7	.9335	.8764	1.1203	1.0269	1.0174	1.1203	1.1203
8	1.1203	1.0174	1.1203	1.1203	1.0174	1.1203	1.1203
9	1.1203		.9335	.9335		1.1203	1.1203
10	.543		.9335		1.0269		.8573
11	.543		.9335		.9335		.8573
12	.5258		.7468		.8402	.9335	.8573
13	.5258		.5601		.7468	.8402	.6859
14			.5601		.6706	.7468	.5144
15			.5601	.3155	.7545	.7468	.5144
16					.8402	.7468	.4287
17	.6001	.6535			.6706	.7468	.6268
18	.6783	.7468	.6535	.5258	.8402	.8402	.6268
19	.6859	.8402	.7468	.5144	.7545	.8402	
20	.7011	.8383	.9335	.5144	.9335	.9335	.6335
21	.7164	.8402	.8402	.5258	.9335	.9335	.543
22	.724	.7468	.6535	.5258	.8402	.8402	.543
23	.724	.6535	.6535	.5373	.7468	.7468	.543
24		.724	.6535		.5144	.7468	
Max	1.1203	1.0174	1.1203	1.1203	1.0269	1.1203	1.1203
Min	.5258	.6535	.5601	.3155	.5144	.6706	.4287
Avg	.7171	.7913	.7650	.6538	.8135	.8425	.7603

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 203 / Sai Stone Crusher (Express HV Express Feeder  
Fee Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0895	.0934	.0914	.0905	.0838	.0914
2	.0914	.0905	.0934	.0914	.0914	.0934	.0914
3	.1829	.0905	.0934	.0914	.0914	.0934	.0914
4	.1829	.0905	.1867	.1829	.0914	.0934	.0914
5	.1829	.0905	.1867	.1829	.0905	.0934	.0914
6	.1829	.0876	.0934	.1829		.0934	.0914
7	.1829	.1052	.0934	.0914		.0838	.0914
8	.1829	.1017	.0934	.0914		.0934	.0914
9	.0914		.1307	.0914		.0934	.0914
10	.0924		.0914		.0934		.0895
11	.0924		.0914		.0934		.0895
12	.1052		.1829		.1882	.1829	.0895
13	.0876		.1829	.0857	.1867	.1829	.0895
14	.0848		.1829	.0857	.1867	.1829	.0895
15	.0848		.1829	.0905	.1677	.1829	.0895
16	.0857		.0914	.0905	.0838	.0914	.0895
17	.0857	.0934	.0914	.0905	.0934	.0914	.0905
18	.0857	.0934	.0914	.0905	.0838	.0914	.0905
19	.0857	.0934	.0914	.0905	.0934	.0914	.1097
20	.0905	.0934	.0914	.0895	.0934	.0914	.1086
21	.0905	.0934	.0914	.0905	.0838	.0914	.112
22	.0905	.0934	.0914	.0914	.0934	.0914	.112
23	.0905	.0934	.0914	.0934	.0934	.0914	.1097
24		.0905	.0914		.0905	.0914	
Max	.1829	.1052	.1867	.1829	.1882	.1829	.112
Min	.0848	.0876	.0914	.0857	.0838	.0838	.0895
Avg	.1141	.0931	.1167	.1043	.1090	.1080	.0949

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174039 / 33 KV KAPSI

Feeder No / Name : 204 / Golegaon New

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.7164	.5601	.5658		.6706	.7545
2	.5658	.7164	.5601	.5658		.7468	.7545
3	.5658	.7011	.5601	.5658		.7468	.7545
4	.5658	.7011	.6535	.6602		.8402	.8488
5	.6602	.7011	.7468	.7545		.9335	.9431
6	.7545	.7888	.9412	.9431		1.1203	1.1317
7	.9431	.8764	1.0269	.9431		1.307	1.3203
8	1.0374	1.3565	1.1203	1.0374		1.307	1.3203
9	.9431		1.0059	1.1317		1.1203	1.1317
10	.905		1.1317		1.1203		1.7147
11	.905				1.0269		1.5432
12			.9431	.823	.8383	1.0374	1.5432
13			.5658	.823		.9431	
14	.4287		.5658		.7468	.8488	
15	.5144		.5658	.8145	.7468	.7545	
16	.6859		.5658	.8764	.6706	.7545	
17	.5144	.6535	.6602	1.2803	.6535	.7545	1.7013
18	.6859		.6602	1.6461	.6706	.6602	1.7194
19	.9431	.7468	.7545	1.6461	.8402	.7545	1.6118
20	.964	.7468	.6602	1.4632	.9335	.8488	1.3575
21	.9431	.6535	.6602	1.2269	.8383	.9431	1.267
22	.823	.6535	.5658	1.2269	.8402	.8488	1.267
23	.7716	.5601	.5658	1.2269	.7529	.7545	1.267
24		.8145	.5658			.7545	
Max	1.0374	1.3565	1.1317	1.6461	1.1203	1.307	1.7194
Min	.4287	.5601	.5601	.5658	.6535	.6602	.7545
Avg	.7469	.7591	.7220	1.0110	.8215	.8841	1.2606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 201 / GOLEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1629		.132	.1357
2		.1629		.132	.1296
3		.1463		.132	.1326
4		.1629		.132	.1619
5		.1629		.165	.1989
6		.1829		.198	.2204
7				.198	.1966
8				.2035	.1989
9				.1638	.1326
10			.132	.1696	.1475
11			.462	.5243	
12			.495	.5765	
13			.5463	.5735	
14			.561	.547	
15			.594	.5304	
16			.594	.3052	
17			.495	.3052	
18				.3978	
19	.1086		.165	.1526	
20	.2012		.165	.1526	
21	.1829		.495	.1526	
22	.1829			.1526	
23	.1663			.1526	
24		.1578		.132	.1311
Max	.2012	.1829	.594	.5765	.2204
Min	.1086	.1463	.132	.132	.1296
Avg	.1684	.1627	.4277	.2617	.1623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 202 / SHIRADHON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2622		.33	.2984
2		.2267		.33	.2949
3		.2267		.33	.3018
4		.2622		.33	.3605
5		.2915		.462	.4694
6		.373		.528	.5304
7		.4578		.561	.5571
8		.4748		.594	.5197
9				.6105	.4917
10			.429	.6241	.431
11			.429	.5548	
12			.396	.5609	
13			.363	.4207	
14			.33	.4031	
15			.198	.39	
16			.198	.2785	
17	.3391		.231	.2622	
18	.3988		.231	.3561	
19	.3441		.4438	.373	
20	.4681		.528	.3239	
21	.373			.2984	
22	.3391			.3052	
23	.2785			.3052	
24		.2774		.33	.2949
Max	.4681	.4748	.528	.6241	.5571
Min	.2785	.2267	.198	.2622	.2949
Avg	.3630	.3169	.3433	.4109	.4136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 203 / JOSHI SANGVI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1966		.495	.4409
2		.2267		.495	.4359
3		.2267		.495	.4748
4		.2591		.495	.5426
5		.3932		.66	.6443
6		.4409		.825	.7461
7		.5506		1.1549	1.0174
8		.5426		1.2209	1.1191
9				1.2539	1.1469
10			.8909	1.1869	1.0174
11			.132	.1696	
12			.099	.1696	
13			.1024	.1457	
14			.099	.1658	
15			.1155	.1865	
16			.1155	.2035	
17	.421		.165	.1638	
18	.4424		.165	.2035	
19	.1966		.2145	.1989	
20	.2267		.2145	.192	
21	.1966			.1989	
22	.1943			.1966	
23	.1619			.2458	
24		.1619		.165	.2035
Max	.4424	.5506	.8909	1.2539	1.1469
Min	.1619	.1619	.099	.1457	.2035
Avg	.2628	.3331	.2103	.4536	.7081



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174051 / 33 KV SHIRADHON

Feeder No / Name : 205 / Osmannagar

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	23-JUL-17	24-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2591		.396	.3978
2		.2321		.396	.3887
3		.2267		.396	.3932
4		.2622		.396	.431
5		.2915		.495	.5571
6		.3605		.8744	.6962
7		.6274		1.1219	.7956
8		.78		1.3694	
9				1.2539	.8951
10			1.0559	1.2125	.9448
11			.2145	.3052	
12			.198	.2785	
13			.198	.2883	
14			.066	.2883	
15			.165	.2818	
16			.2145	.2785	
17	.4748		.231	.2622	
18	.4409		.264	.2984	
19	.2915		.33	.3149	
20	.2721		.363	.2949	
21	.3113			.2984	
22	.2881			.2883	
23	.2753			.2785	
24		.2622		.264	.2883
Max	.4748	.78	1.0559	1.3694	.9448
Min	.2721	.2267	.066	.2622	.2883
Avg	.3363	.3669	.3000	.4971	.5788

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 201 / SONKHED GAOTHAN

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658		.346	.3658	.3155	.346	.3048
2	.3658		.346	.3658	.3086	.346	.3048
3	.4024		.4152	.3658	.3429	.4844	.3048
4	.439		.4828	.4024	.4287	.4844	.381
5	.4755		.5862	.4755	.4801	.5536	.4572
6	.6219		.6228	.6584	.5144	.6207	.5335
7	.6584		.6552	.6584	.5658	.6724	.5335
8	.695		.6207	.6219	.4973	.5862	.5335
9	.5853		.5517	.5853		.5517	.4572
10	.439				.4311	.4572	.4755
11	.3429				.4844		
12	.3086			.298	.3806		
13	.2915			.2915	.346	.381	.3658
14	.2915		.2926	.2915	.3276	.381	
15	.2915		.2926	.3258	.3448	.381	
16	.3258		.3292	.3258	.3448	.4572	
17		.3448	.3658	.3506		.4572	.439
18	.4115	.4483	.4755	.4557			
19	.4938	.4655	.5853	.5373	.5862		
20	.5316	.5517	.5121	.5487	.6228	.381	.6219
21	.4287	.4828	.439		.5882	.3048	
22	.3601	.3806	.439	.4207	.4152		.4755
23	.3429	.346	.4024	.3856	.346	.3048	.4024
24	.3658	.3506	.346	.3658	.3429	.346	.3048
Max	.695	.5517	.6552	.6584	.6228	.6724	.6219
Min	.2915	.3448	.2926	.2915	.3086	.3048	.3048
Avg	.4276	.4213	.4553	.4332	.4292	.4472	.4310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 202 / SHEVADI

Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	24-JUL-17	26-JUL-17	27-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)
8	.9688		.8621
16		1.1725	
24	.6228		.8304
Max	.9688	1.1725	.8621
Min	.6228	1.1725	.8304
Avg	.7958	1.1725	.8463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 203 / Dagadgaon

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263		.3793	.2058	.2572	.3806	.3048
2	.2263		.3793	.2058	.3086	.3806	.3048
3	.2263		.4828	.2058	.3506	.4844	.3048
4	.2641		.4828	.2401	.3841	.5517	.381
5	.3018		.5173	.2743	.4801	.6897	.381
6	.415		.5173	.4534	.5335	.6897	.4572
7	.4527		.6552	.583	.6093	.7587	.6097
8	.2641		.6207	.4858	.6935	1.0173	.6859
9	.3395		.6207	.6882		.9688	.4572
10	.2279				.9342	.8383	.5243
11	.1715				.173		
12	.2401			.1578	.1903		
13	.2321			.1715	.1724	.2286	.1829
14	.2401		.1715	.1715	.1379	.3048	
15	.2401		.2058	.1658	.173	.381	
16	.3605		.2561	.1457	.1897	.2286	
17		.519	.2561	.2591		.2286	.2561
18	.4115	.4844	.2561	.2915			
19	.2743	.2768	.3658	.3041	.2249		
20	.2984	.3114	.3292	.3041	.2422	.2286	.2641
21	.2572	.2759	.2926		.2414	.1524	.2561
22	.2229	.2768	.2926	.2401	.2422		.2195
23	.2572	.2759	.2561	.2241	.2422	.1524	.1829
24	.2263	.2915	.2595	.2561	.2241	.2422	.1524
Max	.4527	.519	.6552	.6882	.9342	1.0173	.6859
Min	.1715	.2759	.1715	.1457	.1379	.1524	.1524
Avg	.2772	.3390	.3798	.2873	.3335	.4688	.3485

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174052 / 33 KV SONKHED

Feeder No / Name : 204 / Dapshed Feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904		.3793	.3429	.4382	.4844	.381
2	.4904		.3806	.3429	.4557	.4844	.381
3	.4904		.3806	.3429	.4908	.5517	.381
4	.5281		.4483	.3772	.5144	.8276	.4572
5	.5658		.4844	.4115	.6135	.8621	.5335
6	.679		.5017	.4534	.6859	.8621	.5335
7	.6413		.519	.5182	.703	.8966	.6097
8	.6413		.519	.5182	.8573	.8966	.7621
9	.4904		.5173	.5243		.865	.5335
10	.3772				.5882	.6859	.5898
11	.3429				.3287		
12	.3475			.2103	.2941		
13	.3086				.2931	.381	.4024
14	.2915		.2401		.2941	.3048	
15	.3258		.2401	.3086	.3104	.381	
16	.3658		.3658	.3429	.3276	.381	
17		.3806	.3658	.3429		.4572	.5121
18	.3258	.4152	.439	.4115			
19	.4801	.5173	.4755	.4908	.4828		
20	.5316	.4844	.5121	.5658	.5536	.381	.5853
21	.4801	.4152	.439		.4844	.381	.5487
22	.4458	.4152	.439	.4801	.4498		.4755
23	.4458		.4024	.5068	.4671	.381	.4755
24	.4904	.4458	.4152	.4024	.4287	.4152	.381
Max	.679	.5173	.519	.5658	.8573	.8966	.7621
Min	.2915	.3806	.2401	.2103	.2931	.3048	.381
Avg	.4598	.4391	.4232	.4155	.4791	.5726	.5025

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 201 / MALAKOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.3696	.3395		1.0117	1.3216	1.386
2	.823	.3696	.2672		1.0117	1.2474	1.2936
3	.924	.3696			.9326	1.2198	1.1888
4	.924	.462			.9483	1.1962	1.3717
5	1.1088	.462			1.0164	1.2186	1.5708
6	1.1203				1.0426	1.3932	1.848
7	1.4003	.4668	.5118			1.5692	1.9605
8	1.4784	.4066	.4166			1.6701	1.9605
9	1.2936		.3412				1.4784
10	1.1088				.944		
11	.924			1.1214	1.3003		
12	.7392			1.1203	1.628	1.4937	
13	.8316				1.6718	2.0328	1.5708
14		.321			1.7828	1.9404	1.4784
15	.7392				1.8861		
16	.9145			1.2087	1.0395	1.848	1.386
17		.3206				1.386	1.2936
18	.9335	.402					1.2936
19	1.2136					1.4146	
20	1.7556	.5303				1.6975	1.6804
21	1.5708	.5098				1.6032	1.4937
22	1.4632	.4715		1.5089		1.4784	
23		.4715		1.4563		1.386	1.2936
24	1.2803		.4343		1.2617	1.331	1.3717
Max	1.7556	.5303	.5118	1.5089	1.8861	2.0328	1.9605
Min	.7392	.3206	.2672	1.1203	.9326	1.1962	1.1888
Avg	1.1133	.4238	.3851	1.2831	1.2484	1.4972	1.4956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 202 / MALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1372	.0943		.1855		.2279
2	.1029	.12	.0891		.2023		.2481
3	.12	.1372	.1252		.2035		.2279
4	.0983	.1658	.1825		.2241		.2454
5	.116	.1696	.2056		.2587		.2481
6	.1715	.2035	.2263		.2844		.2686
7	.2058	.2427	.2464				.298
8	.2454	.2401	.2841				.3258
9	.208		.2085				.3155
10	.1734				.2832		.3045
11	.0857			.0187	.1858		
12	.0693			.0187	.1295	.1387	
13	.0686				.1115	.1029	.104
14		.1699			.0938	.0876	.0905
15					.0754		
16	.0686	.133		.0186	.0756	.1387	.1227
17		.1509				.1227	
18	.1227	.1462					.1052
19	.1753	.0566				.1772	
20	.1753	.0568				.2629	.2534
21	.1734	.0566				.2126	.2103
22	.1372	.0566		.1698		.1753	
23	.1402	.0566		.15		.156	.1417
24	.12	.1372	.0566		.1178		.1387
Max	.2454	.2427	.2841	.1698	.2844	.2629	.3258
Min	.0686	.0566	.0566	.0186	.0754	.0876	.0905
Avg	.1372	.1354	.1719	.0752	.1737	.1575	.2154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 203 / ASHTUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.0974	.415		.6744		.924
2	1.1088	1.0534	.4453		.6744		.961
3	1.0164	1.0719	.5009		.7673		1.0059
4	1.0719	1.1088	.6388		.8621		1.0974
5	1.3306	1.1088	.785		1.1088		1.1458
6	1.643	1.1088	1.2071		1.2891		1.2382
7	1.7551	1.0829	.7583				1.5684
8	1.7177	1.0349	.7954				1.4377
9	1.3306		.7583				1.3676
10	1.1088				1.4538		1.1458
11	.7392			.3177	.9659		
12				.2801	.888	1.1088	
13	.5914				.8359	1.1458	
14		.6797			.7506	1.1273	.5487
15					.7922	1.1273	
16		.6078		.2417	.8694		.823
17		.5847				1.1827	.7316
18	.7468	.0183					.8316
19	1.251	.4154				1.307	
20	1.531	.4545				1.358	.9709
21	1.3817	.4343				1.3203	1.0082
22	1.267	.415		1.3203		1.2936	
23	1.1888	.3772		1.2696		1.2012	.823
24	1.134	1.0974	.3398		1.0598		1.1706
Max	1.7551	1.1088	1.2071	1.3203	1.4538	1.358	1.5684
Min	.5914	.0183	.3398	.2417	.6744	1.1088	.5487
Avg	1.2143	.7640	.6644	.6859	.9280	1.2172	1.0444



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174064 / 33 KV MALAKOLI

Feeder No / Name : 204 / Limboti Dam Express

HV Express Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0164	.0189		.0169		.0162
2	.0171	.0166	.0178		.0169		.0162
3	.0166	.0332	.0179		.0171		.016
4	.0324	.0332	.0183		.0172		.016
5	.0328	.0328	.0187		.037		.0162
6	.0332	.0332	.0189		.0379		.0164
7	.0343	.0339	.0379				.1052
8	.0343	.0339	.0379				.1417
9	.0514		.0379				.1543
10	.0514				.0755		.1402
11	.0514			.0187	.0557		
12	.0514			.0373	.037	.0514	
13	.0514				.0372	.0343	.0156
14		.0189			.0375	.0164	.0156
15	.016				.0189		
16	.0324	.019			.0189	.0164	.0995
17		.0377				.0164	
18	.0166	.0378					.0829
19	.0166	.0378				.0166	
20	.0166	.0379				.0164	.016
21	.0164					.0164	.0162
22	.0171			.0189		.0164	
23	.0162			.0187		.0162	.1463
24	.0171		.0189		.0168		.016
Max	.0514	.0379	.0379	.0373	.0755	.0514	.1543
Min	.016	.0164	.0178	.0187	.0168	.0162	.0156
Avg	.0291	.0302	.0243	.0234	.0315	.0217	.0581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 201 / PENUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.4144	.6097	.5335		.2713
2	.3963	.4572	.5087	.6097	.5335	.2286	.3315
3	.4115	.4572	.4973	.6249	.5335	.2286	.3647
4	.4725	.4572	.6104	.6706	.6097	.381	.3647
5	.5487	.4572	.6443	.6859	.6097	.381	.503
6	.5792	.4572	.7461	.6249	.6859	.381	.5197
7	.6859	.4572	.6097	.6706	.6859	.4572	.5365
8	.4572	.4572	.5792	.6249	.6859	.3048	.4694
9	.4572		.5487	.6097	.6859	.381	
10	.4572		.5944	.6097	.6859	.3768	
11	.2286		.4572	.2286	.2743	.4424	
12			.3048	.2286	.2286	.4424	
13	.2286		.3201	.2286		.4424	
14			.3048	.2286			
15	.2286	.2429	.2743	.2286		.426	
16	.2286	.1943	.2743	.2286		.4096	
17	.2286	.1943		.2286		.4424	
18	.2286	.2105		.1981		.4752	
19	.3048	.4239		.4572		.503	
20	.4572	.6104		.4572	.4572	.5197	
21	.4572	.5365	.503	.4572	.4572	.503	.4572
22	.4572	.4694	.5487	.4572	.4572	.503	.4572
23	.4572	.4239	.5944	.4572	.4572	.4694	.4572
24	.4877	.4572	.4239	.5944	.4572	.4572	.4191
Max	.6859	.6104	.7461	.6859	.6859	.5197	.5365
Min	.2286	.1943	.2743	.1981	.2286	.2286	.2713
Avg	.4053	.4123	.4879	.4591	.5317	.4162	.4293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 202 / ANTESHWAR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2286	.1341	.1524	.1524		.1677
2		.2286	.1509	.1677	.1524	.3048	.1989
3		.2286	.1677	.1677	.1524	.3048	.285
4		.2286	.2012	.1677	.1524	.3048	.3353
5		.2286	.2321	.1677	.2286	.3048	.3688
6		.2286	.2515	.1524	.2286	.3048	.4024
7		.2286	.2286	.1677	.2286	.3048	.4191
8	.1524	.2286	.2134	.1829		.3048	.4694
9	.1524		.1829	.1829		.4572	
10	.0953		.1524	.1829		.4915	
11	.3048		.1524	.2286		.1638	
12			.1677	.2286	.381	.1475	
13	.3048		.1677	.3048		.1638	
14			.1524	.3048			
15	.3048	.1696	.1524	.1524		.1989	
16	.3048	.1619	.1524	.1524		.2012	
17	.3048	.1696		.1524		.1677	
18	.3048	.1696		.1524	.3048	.1509	
19	.1524	.1677		.1524	.1524	.1509	
20	.1524	.2035		.1524	.1524	.1509	.1524
21	.2286	.1526	.1524	.1524	.2743	.1677	.1524
22	.2286	.1526	.1524	.1524	.4572	.1658	.1524
23	.2286	.1526	.1524	.1524	.1524	.1492	.1524
24		.2286	.1475	.1524	.1524	.1524	.1509
Max	.3048	.2286	.2515	.3048	.4572	.4915	.4694
Min	.0953	.1526	.1341	.1524	.1524	.1475	.1509
Avg	.2300	.1976	.1732	.1785	.2215	.2370	.2621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174075 / 33 KV PENUR

Feeder No / Name : 203 / Godawari Ag Feeder

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2						.1524	.4144
3						.1524	.4191
4						.1524	.3688
5						.1524	.3856
6						.1524	.4191
7						.1524	.4191
8						.1524	.4694
9						.1524	
10						.1638	
11	.3048		.1524	.1524	.2591		
12			.1524	.1524	.381		
13	.3048		.1524	.1524	.3048		
14			.1524	.1524	.1524		
15	.3048	.1696	.1524	.1524	.1524		
16	.3048	.1696	.1524	.1524	.3048		
17	.3048	.1619		.1524	.3048		
18	.3048	.1658		.1677	.3048		
Max	.3048	.1696	.1524	.1677	.381	.1638	.4694
Min	.3048	.1619	.1524	.1524	.1524	.1524	.3688
Avg	.3048	.1667	.1524	.1543	.2705	.1537	.4136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 201 / Mohanpura Gaothan

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429		.3734	.3961		.3734	.3772
2	.3429		.3734	.3772		.4668	.3772
3	.3601		.4668	.3772		.4668	.3768
4	.4458		.4668	.5481		.4668	.4329
5	.5144		.5601	.6224		.4668	.5271
6	.6516		.5601	.7371		.5601	.5653
7	.8059		.5601	.7567		.5601	.6763
8	.6173			.7167		.5601	.64
9	.5487			.6419		.6535	.6017
10	.5601			.3944	.5601	.6602	.5487
11			.2657	.2229	.3734	.5297	.4287
12			.2268	.2058	.2801	.4536	.3429
13			.2263	.1715	.2801	.415	.3086
14			.2254	.1543	.2801		
15	.3734	.2801		.1715	.3734	.4364	
16	.3734	.3734			.3734	.5281	
17	.4668	.4668		.2915	.4668	.5658	.5316
18	.4668	.5601	.4338		.5601	.6011	.4115
19		.5601	.5082		.6535		.4287
20		.5601	.567		.6535	.4899	.4115
21		.4668	.567		.5601	.4904	.4115
22		.3734	.4919		.5601	.4536	.4115
23		.3734	.455		.4668	.3772	.3772
24	.3429		.3734	.3961		.3734	.3772
Max	.8059	.5601	.567	.7567	.6535	.6602	.6763
Min	.3429	.2801	.2254	.1543	.2801	.3734	.3086
Avg	.4809	.4460	.4278	.4224	.4601	.4977	.4554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 203 / Betsangavi Agri

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171					
2	.0171					
3	.0171					
4	.0171					
5	.0171					
6	.0171					
7	.0171					
8	.0171					
9	.0171					
10	.0164					
11		.0264	.0152	.0819	.1172	.1067
12		.0267	.0152	.08	.1454	.1524
13		.0267	.0305	.0781	.1465	
14		.0267	.061	.0781	.1742	
15			.0457	.08	.1738	
16				.0781	.1648	
17			.0457	.0781	.1372	.1067
18		.0848		.0781	.1357	.0914
Max	.0171	.0848	.061	.0819	.1742	.1524
Min	.0164	.0264	.0152	.0781	.1172	.0914
Avg	.0170	.0383	.0356	.0791	.1494	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174087 / 33 KV MOHANPURA

Feeder No / Name : 204 / Jawala

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572		.2801	.2946		.3734	.2649
2	.2572		.2801	.298		.3734	.2946
3	.2401		.3734	.296		.3734	.3437
4	.3086		.3734	.2963		.5601	.3613
5	.3429		.4668	.3285		.6535	.3941
6	.4115		.4668	.3808		.8402	.4106
7	.4973		.4668	.491		.8402	.4927
8	.5487			.4933		.8402	.6335
9	.5144			.4561		.8402	.7058
10	.5601			.3963	.5601	.491	.4725
11	.2241		.1794	.1543	.5601	.4305	.2058
12	.2241		.1296	.1372	.1867	.4305	.1715
13	.2241		.0322	.1372	.1867	.4106	.1372
14	.2241		.0321	.1372	.1867	.3782	
15	.2801	.3734		.1543	.1867	.3146	
16	.2801	.3734			.2801	.3285	
17	.2801	.4668		.2058	.2801	.3285	.3086
18	.2801	.4668	.3109		.3734	.3421	.2915
19		.4668	.36		.3734		.3086
20		.3734	.3258		.4668	.3273	.3772
21		.4668	.2946		.4668	.298	.3601
22		.3734	.312		.3734	.2815	.3429
23		.2801	.3117		.2801	.2466	.3086
24	.2401		.2801	.2463		.2801	.2483
Max	.5601	.4668	.4668	.4933	.5601	.8402	.7058
Min	.2241	.2801	.0321	.1372	.1867	.2466	.1372
Avg	.3260	.4045	.2931	.2884	.3401	.4601	.354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 201 / Janapuri

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.124	.0905	.2641	.2641	.2263	.2263	.2263
2	.1433	.0905	.2641	.2452	.2263	.2263	.2263
3	.1791	.1086	.2641	.2452	.2641	.2263	.2263
4	.1791	.1075	.2641	.2641	.3018	.2452	.2641
5	.2172	.1075	.3206	.2829	.3395	.3018	.3395
6	.2172	.1629	.2641	.3395	.3772	.3395	.3772
7	.2658		.2641	.3772	.3961	.415	.3772
8	.3429		.2263	.3961		.3584	.3772
9			.3018	.3395		.415	.3772
10						.3395	.3361
11			.2214	.1658	.1677	.2683	
12	.1698		.216	.2721	.2401	.3563	
13						.4096	.2458
14						.3277	
15	.1698			.2778	.3239	.4096	
16	.1698			.3321	.3239	.2591	
17	.1886	.2241		.3479		.2846	.4096
18	.2263	.2241	.3277	.3479			.4534
19	.2641	.2801	.3018	.2801			
20	.2829	.3395				.2801	.3395
21	.2829	.3018	.2829			.2801	.2829
22	.2829	.2641	.2801	.2829	.2641	.2614	.2829
23	.2641	.2641	.2801	.2614	.2452	.2452	.2641
24	.2614	.2452	.2641	.2641	.2263	.2263	.2263
Max	.3429	.3395	.3277	.3961	.3961	.415	.4534
Min	.124	.0905	.216	.1658	.1677	.2263	.2263
Avg	.2227	.2008	.2710	.2940	.2802	.3046	.3129



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 202 / Wadepuri

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1848	.5281	.5093	.4527	.4904	.5093
2	.1829	.2218	.5281	.4904	.4527	.4904	.4904
3	.1829	.2561	.5281	.4904	.4904	.5093	.5093
4	.2241	.2926	.547	.5658	.5658	.5281	.6036
5	.2801	.3292	.7167	.6036	.679	.6036	.679
6	.3361	.4435	.8488	.7167	.7922	.7922	.7733
7	.3292		.7373	.679	.9054	.7922	.8676
8	.3696		.8488	.7167		.8299	.8299
9			.7922	.6224		.7167	.7922
10						.7545	.7167
11			.2883	.3391	.4239	.3506	
12	.3206		.3563	.2984	.3932	.407	
13			.3239			.3988	.2012
14						.4508	
15	.2452			.3077	.3768	.463	
16			.3772	.3315	.3978	.3944	
17		.3961		.3688		.3988	.5258
18		.4904	.39	.4191			.5935
19	.7167	.5847	.7167	.5658			
20	.2743	.7545				.5658	.7167
21	.3109	.5658	.679			.5658	.6224
22	.2926	.5281	.5658	.5658	.5847	.5281	.5658
23	.5281	.5281	.5281	.5093	.5281	.5093	.5281
24	.5093	.5093	.5281	.5093	.4715	.4904	.5093
Max	.7167	.7545	.8488	.7167	.9054	.8299	.8676
Min	.1829	.1848	.2883	.2984	.3768	.3506	.2012
Avg	.3305	.4346	.5699	.5057	.5367	.5468	.6130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 203 / Ratneshwari Gaothan  
Feeder KV- 11 / OUTGOING

Gaothan Feeder

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3772	.415	.3772	.3772	.415	.415
2	.415	.3772	.415	.3772	.3772	.3961	.415
3	.415	.415	.4338	.3772	.415	.3961	.415
4	.4715	.4527	.4527	.4527	.5281	.4338	.5281
5	.4715	.5281	.6036	.5281	.6413	.5281	.6413
6	.4715	.6979	.7545	.6413	.7545	.6602	.7545
7	.4715		.6036	.7655	.8589	.4904	.7842
8	.5658		.547	.7842		.3018	.5601
9			.6535	.7468		.7282	.6722
10						.5041	.6161
11			.3395	.3734	.4904	.4527	
12	.3206		.3395	.3206	.3584	.4108	
13			.2614			.4904	.3658
14			.2075			.547	
15	.3395		.2263	.3206	.2801	.6413	
16	.3961		.2829	.3395	.3395	.5601	
17	.4338	.3961		.3921		.4854	.6535
18	.4668	.2987	.4527	.4481			.6535
19	.5601	.5415	.5975	.4854			
20	.5228	.6036				.4904	.5658
21	.4854	.4904	.4527			.4527	.5281
22	.4481	.4338	.3961	.4338	.3961	.4338	.4715
23	.415	.415	.3961	.3961	.415	.415	.4527
24	.415	.3961	.415	.3772	.3772	.415	.415
Max	.5658	.6979	.7545	.7842	.8589	.7282	.7842
Min	.3206	.2987	.2075	.3206	.2801	.3018	.3658
Avg	.4474	.4588	.4403	.4704	.4721	.4840	.5504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

LOHA (R) S/DN[446] BU 2453

Substation No/ Name :- 174089 / 33 KV WADEPURI

Feeder No / Name : 204 / 11 KV Pratchett Express

HV Express Feeder

Feeder Feeder KV- 11 / OUTGOING

DATE	22-JUL-17
HR	Load (MW)
1	.415
Max	.415
Min	.415
Avg	.415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 201 / 11KV MUDKHED (U)

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1145	.9145	1.0517	1.0288		1.0288	.964
2	1.1145	1.0288	1.0517	1.0288		1.0288	.964
3	1.1145	1.0288	1.0517	1.0288		1.0288	.964
4	1.1145	1.0288	1.0517	1.0288		1.0288	.964
5	1.1145	1.0288	1.1393	1.1145		1.1145	1.0517
6	1.2003	1.1145	1.3146	1.2003		1.2003	1.1393
7	1.2003	1.286	1.3146	1.4575		1.1145	1.3146
8			1.2269	1.286		1.1145	1.3146
9	1.0288		1.2003		1.2003	1.0288	1.3146
10	1.0288		1.2003		1.1145	1.0517	
11	.9431		1.2003		1.0288	.964	
12	.8573		.9431		1.0288	.7888	
13	.9431		.8573		.7716	.7888	
14	.8573	.964	.8573		.9431	.8764	
15	.9431	.964	.8573		.9431	.8764	
16	.9431	.8764	.9431		1.0288	.8764	
17	1.0288	.964			1.0288	1.0517	
18	1.0288	.964	1.1145		1.0288		
19	1.2003	1.3146	1.2003		1.1145		
20	1.1145	1.3146	1.2003		1.2003	1.2269	
21	1.1145	1.1393	1.1145		1.2003	1.2269	
22	1.1145	1.1393	1.1488		1.2003	1.1393	
23	1.1145	1.1393			1.1145	1.0517	
24	1.1145	1.0288	1.0517	1.0288		1.0288	.964
Max	1.2003	1.3146	1.3146	1.4575	1.2003	1.2269	1.3146
Min	.8573	.8764	.8573	1.0288	.7716	.7888	.964
Avg	1.0586	1.0688	1.0951	1.1336	1.0631	1.0289	1.0955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 202 / 11KV MENDAKA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.7621	.703	.4572		.7621	.6249
2	.6859	.7621	.6249	.4572		.7621	.6249
3	.6859	.7621	.6249	.4572		.7621	.6249
4	.6859	.7621	.6249	.4572		.7621	.6249
5	.6859	.7621	.703	.4572		.7621	.703
6	.6859	.7621	.8592	.5335		.7621	.8592
7	.7621	.7621	.7811	.5335		.6859	.7811
8			.703	.4572		.6097	.6249
9	.5335		.381		.7621	.6097	.5468
10	.3048		.381		.7621	.5468	
11	.4572		.381		.6097	.703	
12	.5335		.5335		.7621	.7811	
13	.5335		.6097		.2286	.7811	
14	.6097	.703	.4572		.9145	.7811	
15	.4572	.703	.4572		.9145	.9374	
16	.4572	.703	.6859		.9145	.9374	
17	.5335	.703	.6859		.9145	.9374	
18	.4572	.703	.6859		.9145		
19	.7621	.703	.5335		.7621	.6249	
20	.7621	.7811	.5335		.7621	.7811	
21	.7621	.7811	.5335		.7621	.703	
22	.7621	.703	.5335		.7621	.703	
23	.7621	.703			.7621	.703	
24	.6859	.7621	.703	.5335		.7621	.6249
Max	.7621	.7811	.8592	.5335	.9145	.9374	.8592
Min	.3048	.703	.381	.4572	.2286	.5468	.5468
Avg	.6196	.7379	.5965	.4826	.7672	.7461	.6640

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 203 / 11KV IZALI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4572	.3906	.4572		.4572	.4687
2	.3048	.4572	.3906	.5335		.4572	.703
3	.3048	.4572	.3906	.6097		.4572	.703
4	.381	.4572	.4687	.6097		.4572	.703
5	.381	.4572	.4687	.6097		.5335	.8592
6	.4572	.5335	.4687	.6859		.6097	.8592
7	.4572	.5335	.7811	.6859		1.2193	1.1717
8		.4572	.9374	.9145		1.3717	1.406
9	.6097		.9145		.9907	1.448	1.4842
10	.5335		.6859		.9145	1.4842	
11	.2286		.1524		.2286	.3125	
12	.2286				.2286		
13	.2286				.1524	.3125	
14	.2286				.1524	.3125	
15	.2286	.2343	.1524		.1524	.3125	
16	.2286	.2343	.1524		.1524	.3125	
17	.3048	.2343	.2286		.1524	.3906	
18	.381	.3125	.3048		.1524	.3906	
19	.5335	.4687	.5335		.3048	.3906	
20	.5335	.5468			.381	.4687	
21	.5335	.5468			.4572	.4687	
22	.4572	.5468	.4572		.4572	.4687	
23	.4572	.4687			.4572	.3906	
24	.6097	.4572	.4687	.381		.4572	.3906
Max	.6097	.5468	.9374	.9145	.9907	1.4842	1.4842
Min	.2286	.2343	.1524	.381	.1524	.3125	.3906
Avg	.3877	.4367	.4637	.6097	.3556	.5862	.8749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174022 / 33 KV MUDKHED

Feeder No / Name : 204 / 11KV DONGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5335	.6249	.5335		.6859	.6249
2	.6097	.5335	.6249	.5335		.6859	.5468
3	.6097	.5335		.5335		.6859	.5468
4	.6097	.5335		.5335		.6859	.5468
5	.6097			.5335		.6097	.5468
6	.6097			.4572		.6097	.6249
7	.6097			.4572		.4572	.5468
8				.381		.3048	.3906
9	.3048				.5335	.2286	.1562
10	.3048				.5335		
11	.381				.4572	.5468	
12	.381					.4687	
13	.381					.4687	
14	.381	.4687			.6097	.5468	
15	.3048	.3906			.6097	.6249	
16	.3048	.4687			.6859	.703	
17	.3048	.4687			.6859	.703	
18	.3048	.4687	.4572		.6097	.703	
19	.5335	.6249	.5335		.6859	.4687	
20	.5335	.703			.6859	.6249	
21	.5335	.703			.6859	.6249	
22	.5335	.703	.6097		.6859	.6249	
23	.6097	.703			.6859	.6249	
24	.6097	.6097	.703	.6097		.6859	.6249
Max	.6097	.703	.703	.6097	.6859	.703	.6249
Min	.3048	.3906	.4572	.381	.4572	.2286	.1562
Avg	.4771	.5631	.5922	.5081	.6273	.5814	.5156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 201 / NAGELI

Sheddable Rural/Mix Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.381	.381		.381	.381
2	.5426	.381	.3963		.3658	.381
3	.6104	.3963	.3963		.3658	.3963
4	.6443	.3963	.4268		.381	.3963
5	.6104	.4115	.4725		.3963	.442
6	.7122	.4268	.5182		.4268	.3658
7	.7291	.442	.4572		.4572	.4877
8	.8078	.2896	.4115		.381	.4115
9		.2896	.3506		.3658	.3506
10	.7621	.2134	.2743	.3048	.2591	
11	.2134	.6097	.9326	1.0669	.6097	
12	.1829	.7316	1.0343	1.2193		
13		.7926	1.2039	1.2193		
14	.0914	.9755	1.1022	1.3717	1.0212	
15	.1524	1.0669	1.1361	1.3717	1.0669	
16	.2134		1.1869	1.448	1.0974	
17	.2439		1.2887	1.448	.9145	
18	.3048	.9755	1.1869	1.448	.9602	
19	.381	.3353	.394	.3658		
20	.4115	.3963				
21		.3963				
22		.3963				
23		.3963			.381	
24	.407	.3963	.381		.381	.381
Max	.8078	1.0669	1.2887	1.448	1.0974	.4877
Min	.0914	.2134	.2743	.3048	.2591	.3506
Avg	.4489	.5044	.6966	1.1264	.5673	.3993



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 202 / 11KV BARASGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173		.6097	.6097		.7621	.5792
2	.6687		.6401	.6401		.9145	.6097
3	.7202		.6401	.6706		.9145	.6706
4	.7888		.6706	.6706		.9145	.7011
5	.7716		.7011	.7011		1.0669	.7316
6	.823		.7011	.7316		1.1431	.7926
7	.9602		.7316	.7468		1.1431	1.0669
8	.7926		.5792	.7621		1.3717	1.2955
9			.5487	.7773		1.5242	1.5699
10	.6097		.7011	.763	1.0669	1.1431	
11	.7621		.3048	.2686	.3048	.3658	
12	.7621		.2896	.2686	.2743		
13	.6859	.7926	.2896	.2865		.3353	
14	.6097	.7926	.2743			.4115	
15	.6097	.7773	.2743	.2686		.4268	
16	.6859	.823		.3224		.4268	
17	.6097	.8535		.3045		.4877	
18	.6097	.884	.4268	.5373	.5335	.5182	
19	.8535	.6401	.5182	.6268	.6097		
20			.6401				
21			.6401		.2743		
22		.5182	.6249				
23		.5487	.6097			.5639	
24	.6516		.5792	.5792		.3963	.5487
Max	.9602	.884	.7316	.7773	1.0669	1.5242	1.5699
Min	.6097	.5182	.2743	.2686	.2743	.3353	.5487
Avg	.7154	.7367	.5452	.5545	.5106	.7805	.8566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 203 / BARAD

Gaothan Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.381	.3658			.3963
2	.3429		.381	.3963			.3963
3	.3772		.381	.3963			.3963
4	.4115		.381	.4268			.4268
5	.4801		.3963	.4268			.4268
6	.4973		.4268	.4268			.4572
7	.5144		.4572	.442			.4572
8	.4801		.4572	.4572			.4268
9			.381	.4268			.4268
10	.4458		.3506	.3944	.4287		
11	.3944		.3353	.3601	.3944	.3658	
12	.3429		.3353	.3258	.3429		
13	.3258	.2896	.3201	.3429	.3258	.3048	
14	.3086	.2896	.2743	.3429	.3429	.3201	
15	.3772		.2743	.3086	.3772	.3353	
16	.3429			.3429	.3772	.3201	
17	.3944			.3601	.3944	.3201	
18	.4458		.3963	.4287	.3944	.3201	
19	.5144		.4268	.4801	.463		
20	.4973		.4572				
21	.4801		.4268				
22	.4458		.3963				
23	.4458		.3963			.4115	
24	.4115		.3963	.3658			.3963
Max	.5144	.2896	.4572	.4801	.463	.4115	.4572
Min	.3086	.2896	.2743	.3086	.3258	.3048	.3963
Avg	.4197	.2896	.3831	.3909	.3841	.3372	.4207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 204 / SHEMBOLI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783		.5182	.5182		.5182	.5487
2	.7122		.5182	.5182		.4877	.5487
3	.763		.5182	.5182		.4877	.5487
4	.7461		.5487	.5487		.5182	.5792
5	.8478			.5792		.5487	.6401
6	.9835			.5792		.6401	.6859
7	1.0852			.6097		.7316	.6706
8	1.1888		.7621	.6249		.6401	.6097
9			.5792			.5792	.5792
10	1.0669		.503		.4877	.4877	
11	.3658		.6097		.9145	.9907	
12	.3658		.7316	.7969	1.0669		
13	.3506	.3353	.884		1.2193		
14	.3506	.3353	.8535	.78	1.2955	1.1888	
15	.3506	.3201	.9755	.8987	1.3717	1.2193	
16	.381	.3658		.763	1.3717	1.2498	
17	.3963	.3963		1.0852	1.3717	1.3108	
18	.4572	.4572	1.0059	.8817	1.3717	1.3565	
19	.6401	.5182	.4572	.6268	.4572		
20		.3048	.5182			.6097	
21		.3963	.5182			.6401	
22		.4877	.5182			.5792	
23		.5182	.5182			.5639	
24	.5144		.5182	.503		.5182	.5487
Max	1.1888	.5182	1.0059	1.0852	1.3717	1.3565	.6859
Min	.3506	.3048	.4572	.503	.4572	.4877	.5487
Avg	.6444	.4032	.6345	.6770	1.0928	.7555	.5960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 205 / Barad AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.442	.3658		.3963
2			.442	.3658		.3963
3			.4572	.3963		.4268
4			.4572	.3963		.4572
5			.4877	.4115		.4877
6			.4877	.4268		.503
7			.5182	.5335		.6097
8			.6401	.6401		.8383
9			.6401	.6706		1.0059
10			.6097	.5596	.8383	.3963
11	.5335					
12	.5335					
13	.6097					
14	.6097					
15	.6097					
16	.5335					
17	.5335					
18	.5335	.7164				
Max	.6097	.7164	.6401	.6706	.8383	1.0059
Min	.5335	.7164	.442	.3658	.8383	.3963
Avg	.5621	.7164	.5182	.4766	.8383	.5518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 206 / AMBEGAON AG

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5426		.4115	.3963		.3658	.3658
2	.5765		.4115	.3963		.3506	.3658
3	.6443		.3963			.3506	.3658
4	.7122		.3963			.3658	.381
5	.7461		.4115			.381	.381
6	.8139		.4115	.4572		.4115	.3963
7	.8987		.4268	.4572		.4268	.3963
8	.945		.1981			.3658	.4115
9			.2134			.3048	.4115
10	.7621			.0895		.2743	
11	.1829		.6097	.8596	1.0669	.6097	
12	.1981		.6554	.9496	1.1431		
13		.1372	.7011		1.1431		
14	.1524	.1372	.7621	.6443	1.2955	1.2193	
15	.1829	.1372	.823	.9496	1.5242	1.3108	
16	.2286	.1524		1.153	1.6766	1.3717	
17	.2286	.1829		1.2548	1.6766	1.4022	
18	.2286	.2286	.884	1.2887	1.6766	1.3565	
19	.381	.3048	.3353	.3582	.3658	.3353	
20		.2743	.381			.3353	
21		.3353	.3963			.3658	
22		.3963	.3963			.3658	
23		.442	.3963			.3506	
24	.4115		.4268	.3658		.381	.3658
Max	.945	.442	.884	1.2887	1.6766	1.4022	.4115
Min	.1524	.1372	.1981	.0895	.3658	.2743	.3658
Avg	.4909	.2480	.4783	.6872	1.2854	.5910	.3841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174024 / 33 KV BARAD

Feeder No / Name : 207 / DONGARGAON AG

Ag dominated/Pure Ag

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0716		.0762	.0762		.381	.1524
2	.0716		.0762	.0762		.4572	.2134
3	.0716		.0762	.0762		.4572	.2134
4	.0716		.0762	.0762		.4572	.2439
5	.0716		.0762	.0762		.4572	.2439
6	.0895		.0914	.1524		.5335	.2591
7			.3048	.2439		.5335	.6097
8			.3506	.4115		.7621	.7316
9			.4115	.3506		.7621	.823
10			.4877	.4748	.6859	.4572	
11	.381						
12	.381						
13	.381	.5487					
14	.381	.5487					
15	.381	.5182					
16	.381	.4877					
17	.4572	.4572					
18	.4572	.4115					
19	.0914	.0914	.1829	.1791	.1219	.0762	
20		.061	.2134			.0914	
21		.061	.2134			.0914	
22		.0914	.2134			.0914	
23		.0914	.1677			.0914	
24	.1029		.0914	.1219		.0914	.0914
Max	.4572	.5487	.4877	.4748	.6859	.7621	.823
Min	.0716	.061	.0762	.0762	.1219	.0762	.0914
Avg	.2401	.3062	.1943	.1929	.4039	.3620	.3582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 201 / 11 Kv Niwgha

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2753	.2591	.2591	.2591	.2753	.3239	.3077
2	.2753	.2915	.2915	.2591	.2753	.3239	.3077
3	.2753	.3239	.2915	.2591	.2915	.3239	.3077
4	.3077	.3239	.3239	.2915	.3239	.3563	.3239
5	.3563	.3563	.3563	.3077	.3887	.3563	.3563
6	.4049	.3887	.3563	.3401	.4049	.3563	.3887
7	.3887	.421	.3563	.3077	.421	.3887	.3563
8	.3563	.3887	.3077	.2915	.4049	.3563	.3239
9	.664			.2591	.3725	.3563	
10	.583			.1781	.2915	.3239	
11	.421			.1457		.3239	
12	.421			.1134		.2591	
13	.3887			.1134		.2591	
14	.3887					.2591	
15	.4534					.2591	.2429
16	.4858		.2429			.3077	.2429
17	.2267	.3239	.7125	.6802	.9717	.8745	.8097
18	.2591	.3239		.7287	.9393	.9393	.9717
19	.2591	.3563		.7449	.9393	.8097	.8097
20	.2915	.3239		.7287	.9069	.8259	.7773
21	.2753	.3239	.3887	.6316	.9393	.7449	.7125
22	.2591	.2915	.3887	.5992	.8745	.7125	.6802
23	.2591	.2591	.3887	.5668	.8097	.7125	.6478
24	.2753	.2591	.2591	.3725	.5344	.7449	.7125
Max	.664	.421	.7125	.7449	.9717	.9393	.9717
Min	.2267	.2591	.2429	.1134	.2753	.2591	.2429
Avg	.3563	.3259	.3517	.3894	.5758	.4791	.5155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 202 / 11 kv Pardi

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	.081	.3563	.3239	.4049	.7449	.6802
2	.0972	.0972	.3887	.3563	.4049	.7773	.7449
3	.0972	.0972	.4534	.3887	.4372	.8421	.7449
4	.1134	.0972	.4858	.4372	.4858	.9069	.7773
5	.1134	.0972	.5182	.4858	.5992	.9717	.7773
6	.1296	.1134	.5182	.5506	.6802	.9717	.8097
7	.1296	.1296	.5506	.7287	.9069	1.004	1.004
8	.1134	.1296	.6154	.6478	.9393	1.1336	1.0364
9	.1134			.0972		.1296	
10	.081			.081		.0972	
11	.0648			.0648		.0648	
12	.0486			.0648		.0648	
13	.0486			.0486		.0486	
14	.0324		.0486	.0486		.0648	
15	.0486		.0486	.0648	.0486	.0648	.0648
16			.0486	.081	.0648		.0486
17	.6154	.5506		.081	.081	.0648	.0486
18	.5182	.583		.081	.081	.081	.0648
19	.5182	.583		.0972	.081	.0972	.081
20	.4858	.5506		.1134	.081	.0972	.081
21	.4858	.5182	.1134	.0972	.0972	.0972	.081
22	.4858	.4858	.0972	.0972	.0972	.0972	.0972
23	.4858	.3563	.0972	.0972	.0972	.0972	.0972
24	.3887	.4858	.3563	.0972	.081	.0972	.0972
Max	.6154	.583	.6154	.7287	.9393	1.1336	1.0364
Min	.0324	.081	.0486	.0486	.0486	.0486	.0486
Avg	.2310	.3097	.3131	.2180	.3149	.3746	.4076



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174081 / 33kv Niwgha

Feeder No / Name : 203 / 11 KV Khambal feeder

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2267	.5182	.0324	.0324	.0324	.0324	.0324
2	.2591	.5506	.0324	.0324	.0324	.0324	.0324
3	.2591	.6154	.0324	.0324	.0324	.0324	.0324
4	.2915	.6478	.0324	.0324	.0324	.0324	.0324
5	.3077	.6478	.0324	.0324	.0324	.0324	.0324
6	.3401	.6478	.0324	.0324	.0324	.0324	.0324
7	.583	.6802	.0324	.0324	.0324	.0324	.0324
8	.5992	.6154	.0324	.0324	.0324	.0324	.0324
9	.0324			.4858		.8745	
10	.0162			.4858		.8745	
11	.0162			.5182		.7125	
12	.0162			.5182		.7287	
13	.0162			.5506		.7773	
14	.0162		.6478	.5992		.7773	
15	.0162		.6478	.583	.421	.7773	
16	.0162		.6154	.6478	.5506	.8745	
17		.0162		.0324	.0162	.0324	.3239
18	.0324	.0324		.0324	.0324	.0324	.0324
19	.0324	.0324		.0324	.0324	.0324	.0324
20	.0324	.0324		.0324	.0324	.0324	.0324
21	.0324	.0324	.0324	.0324	.0324	.0324	.0324
22	.0324	.0324	.0324	.0324	.0324	.0324	.0324
23	.0324	.0324	.0324	.0324	.0324	.0324	.0324
24	.0324	.0324	.0324	.0324	.0324	.0324	.0324
Max	.5992	.6802	.6478	.6478	.5506	.8745	.3239
Min	.0162	.0162	.0324	.0324	.0162	.0324	.0324
Avg	.1408	.3229	.1533	.2045	.0819	.2881	.0506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 201 / 11 KV Mahati

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2805	.373	.2724		.322	.3334
2		.2802	.373	.2724		.317	.3329
3		.297	.373	.2949		.3387	.3318
4		.2973	.373	.3195		.3647	.3464
5		.2984	.373	.3121		.3658	.3668
6		.3128	.3052	.3425		.439	.4839
7		.2643	.3052	.3441		.4113	.4146
8		.2792	.4409	.2703	.2076	.4417	.4036
9	.3044		.3224	.2986		.4355	.4652
10	.3739		.2679		.174		.3521
11			.2713		.3532		.583
12			.3069			.638	.6478
13			.3391		.4908	.618	.7449
14			.3399		.4908	.581	.7449
15	.2262		.341		.4207	.6775	.7449
16	.2628			.4319		.7082	.7293
17	.2804	.2035	.2719				.7865
18		.2035		.4272			
19	.403	.373	.3416	.2401	.4098		
20	.4353	.4748	.4001		.4644	.4275	
21	.4263	.407	.374	.3576	.439	.4262	
22	.3676	.407	.3466		.411	.3993	
23	.331	.373	.3475		.3852	.3715	.3628
24		.3111	.373	.2683	.3039	.3616	.3435
Max	.4353	.4748	.4409	.4319	.4908	.7082	.7865
Min	.2262	.2035	.2679	.2401	.174	.317	.3318
Avg	.3411	.3164	.3436	.3180	.3792	.4550	.5010

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 202 / 11 KV Malkautha

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6506	.2195			.4534	.5521
2		.6516	.2225	.3864		.483	.5521
3		.6487	.2195	.4744		.5474	.5835
4		.7016	.2195	.5152		.5864	.5835
5		.7762	.2743	.5441		.5864	.6158
6		.9015	.3841	.6682			.9094
7		.6968	.439	.7016		.5243	.8909
8		.6367	.439	.6081	.9187	.695	.9681
9	.6154		.5243	.5901		.8145	1.1616
10	.415		.5243		.8881	.893	.9015
11	.4403		.3448		.3507	.5235	.3628
12			.3165		.3517	.4268	.3109
13			.2957		.3256	.4388	.3201
14			.2858		.2713	.4489	.4329
15	.5599		.316			.5061	.4329
16	.4041			.3779		.5335	.4329
17		.3932					.487
18	.4172	.3932	.3429	.4554			
19	.7808	.7209	.8343	.5701	.664		
20	.7865	.7865	.8802		.7658	.8059	
21	.7713	.7865	.8322	.6887	.7415	.7979	
22	.7479	.7865	.7922		.7161	.768	
23	.6984	.7865	.7777		.6885	.7119	.6401
24		.6889	.6584	.6914	.6127	.6365	.6554
Max	.7865	.9015	.8802	.7016	.9187	.893	1.1616
Min	.4041	.3932	.2195	.3779	.2713	.4268	.3109
Avg	.6033	.6879	.4610	.5594	.6079	.6091	.6207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 203 / 11 KV Rohipimpalgaon  
Feeder KV- 11 / OUTGOING

Single Phasing Feeders

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2061	.2846	.2257		.216	.2386
2		.2056	.2846	.2229		.2401	
3		.2056	.2846	.2515		.2401	
4		.2201	.2846	.2787		.2662	
5		.2445	.3163	.3041		.262	
6		.3768	.3163	.3064		.2881	
7		.4455	.3479	.2766		.2662	
8		.4641	.3163	.2263	.232	.3	.3004
9	.4625		.2027	.2146		.1905	.2401
10	.5609		.2027		.1362	.2447	.2401
11	.2195		.5849		.7298	.9462	.9282
12			.5517		.767	.928	.9156
13			.5184		.7282	.8936	1.0513
14			.5201			.8612	.9496
15	.1957		.553			.8946	.9496
16	.2019		.5862	.4358		.8936	.9156
17	.2043	.2214	.5862				.9496
18	.2091	.2214		.6429			1.0513
19	.2972	.3163		.1788	.3014		
20	.3109	.3795	.3292		.3292	.2743	
21	.2909	.3795	.3039	.2833	.3039	.2728	
22	.29	.3163	.2763		.2774	.2698	
23	.2698	.3163	.2782		.2763	.3006	.3391
24		.2713	.3163	.2246	.2486	.2469	.2667
Max	.5609	.4641	.5862	.6429	.767	.9462	1.0513
Min	.1957	.2056	.2027	.1788	.1362	.1905	.2386
Avg	.2927	.2994	.3748	.2909	.3936	.4426	.6668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 204 / DAREGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6408	.3121	.2069		.3827	.4175
2		.6408	.3121	.208		.4184	.4175
3		.6408	.3121	.2401		.4508	.4175
4		.6581	.3467	.2774		.4508	.4175
5		.7274	.3467	.3121		.6661	.4175
6		.7628	.3814				.5218
7		.6241	.3814	.2774		.6935	.748
8		.5548	.3814	.1734	.663	.9045	.9741
9	.4673		.3121	.1736		.9065	1.0056
10	.2771		.2774			.8688	.9015
11	.3117		.104		.1043		.208
12			.104		.1043		.1734
13			.1384		.104		.208
14			.1379		.104	.3301	.2427
15	.3464					.3649	.2427
16	.3464			.1631		.417	.2774
17	.3464	.4161					
18	.3464	.4161		.1631			.4161
19	.6401	.4508			.5908		
20	.692	.6935			.631	.661	
21	.6574	.6935		.6203	.5992	.661	
22	.6581	.6588	.3709		.5621	.6262	
23	.6581	.6241	.373		.5258	.6262	.6241
24		.6581	.6241	.373	.4893	.4865	.6262
Max	.692	.7628	.6241	.6203	.663	.9065	1.0056
Min	.2771	.4161	.104	.1631	.104	.3301	.1734
Avg	.4790	.6163	.3068	.2657	.4071	.5832	.4872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

MUDKHED SUB-DIVISION[791] BU 4791

Substation No/ Name :- 174108 / 33 Kv Malkautha

Feeder No / Name : 205 / Chikala

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2385	.373	.4774		.4097	.3922
2		.3066	.373			.4092	.3922
3		.3066	.373	.5087			.4263
4		.3406	.373	.5456		.4748	.4774
5		.3406	.5087	.5438		.4758	.5115
6		.4939	.6783			.6783	.6821
7		.6472	.78	.6821		.6458	.7162
8		.7154	.6104	.648	.4997	.5463	.648
9	.4389		.5804	.6145		.478	.5087
10	.4423		.4438			.5633	.4409
11	.2722		.478		.8139	.9218	.8817
12			.5121		.8817	.8535	.9835
13			.5438			.9218	1.0513
14			.5463		.9239	.9208	1.0174
15						.9549	.8478
16				.6811		.9549	.9156
17	.4083	.3391				.9549	.9496
18	.4934	.4409		.8011			.9835
19	.6125	.4409		.4694	.5456	.5456	
20	.6125	.6104	.6407		.5798	.5456	
21	.5444	.6104	.6104	.5508	.5469	.5115	
22	.511	.4409	.5798		.5121	.4774	
23	.4769	.4508	.5098		.4796	.4433	.373
24		.4088	.373	.5087	.4566	.478	.3922
Max	.6125	.7154	.78	.8011	.9239	.9549	1.0513
Min	.2722	.2385	.373	.4694	.4566	.4092	.373
Avg	.4812	.4457	.5204	.5859	.6240	.6439	.6796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 201 / ARDHAPUR

Urban/Sheddable Urban Feeder

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3717	1.4575		1.4575	1.3717
2			1.4575	1.4575		1.4575	1.3717
3			1.4575	1.4575		1.4575	1.3717
4			1.5432	1.5432		1.5432	1.3717
5			1.6289	1.6289		1.5432	1.7147
6			1.7147	1.8004		1.7147	1.8861
7			1.7147	1.7147		1.7147	1.9719
8			1.6289	1.6289		1.6289	1.8861
9		1.5089	1.5432	1.6289		1.6289	1.8861
10	1.3717	1.5089	1.4575			1.5432	1.8004
11		1.3717	1.3717			1.3717	1.8861
12	1.1145	1.2346	1.286				1.8004
13	1.1145	1.0974	1.286			1.2003	
14	1.1145	1.0974	1.286			1.2003	
15	1.1145	1.0974	1.286		1.2003	1.2003	
16		1.0974				1.2003	
17	1.286	1.286	1.286		1.3717	1.3717	
18	1.4575	1.3717	1.5432		1.6289	1.3717	
19	1.4575		1.5432		1.7147	1.5432	
20	1.4575	1.4575	1.5432		1.6289	1.6289	
21	1.4575	1.5432	1.5432		1.6289	1.6289	
22	1.4575	1.4575	1.4575		1.6289	1.5432	
23		1.3717	1.4575		1.5432	1.3717	1.5432
24			1.3717	1.4575		1.5432	1.3717
Max	1.4575	1.5432	1.7147	1.8004	1.7147	1.7147	1.9719
Min	1.1145	1.0974	1.286	1.4575	1.2003	1.2003	1.3717
Avg	1.3094	1.3215	1.4687	1.5775	1.5432	1.4724	1.6595

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 202 / DABHAD

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3944	.6001		.5144	.8573
2			.3944	.6001		.5144	.8573
3			.3944	.6859		.6001	.8573
4			.4115	.6859		.7716	.8573
5				.6859		.823	.8573
6				.6859		1.046	1.0288
7				.7716		1.6289	1.0288
8				1.0288		2.0405	1.3717
9				.0171		2.0919	1.4575
10						1.8004	1.5089
11	.8573		.9431				
12	1.0288		1.0288				
13	1.1145		1.0631				
14	1.2003		1.1145				
15	1.2003		1.2003				
16	1.2003						
17	1.2003		1.2003		.3944	.4287	.3772
18	1.2003		1.2003		.4287	.4287	.3772
19	.5144		.3429		.4115	.4287	.4287
20	.5144	.4287	.3429		.463	.4287	.463
21	.5144	.4458	.3429		.4287	.4287	.4801
22	.5144	.4458	.3429		.4287	.5144	.5144
23		.4115	.3429		.3944	.5144	.3772
24			.4115	.3429		.3601	.5144
Max	1.2003	.4458	1.2003	1.0288	.463	2.0919	1.5089
Min	.5144	.4115	.3429	.0171	.3944	.3601	.3772
Avg	.9216	.4330	.6748	.6104	.4213	.8535	.7897



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 203 / Dabhad-II

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9431	.6859		.6001	.8573
2			.9431	.6859		.6001	1.0288
3			.9431	.6859		.6859	1.0288
4			1.0288	.6859		.7716	1.0288
5				.6859		.8573	1.2003
6				.6859		1.166	1.286
7				.9431		1.7833	1.286
8				.9431		2.0062	1.5432
9				.9431		1.7147	1.7147
10						.8573	1.5604
11	.6859		.5144			.9431	.3772
12	.7716		.6516				
13	.7716		.5487			.7716	.3772
14	.7716					.6859	
15	.8573		.703		1.0288	.6001	
16	.8573					.6859	.5144
17	.6859		.6859			.6859	.5144
18	.7716		.6859		1.1317	.7716	.6516
19	.6859		.8573		1.0631	.8573	.6859
20	.8573	.9431	.8573		.9259	.7716	.823
21	.8573	.8402	.7716		.9431	.7716	.8573
22	.7716	.8573	.7716		.8916	.7716	.7716
23		.823	.7716		.7716	.7716	.7373
24			.823	.6859		.7716	.7716
Max	.8573	.9431	1.0288	.9431	1.1317	2.0062	1.7147
Min	.6859	.823	.5144	.6859	.7716	.6001	.3772
Avg	.7787	.8659	.7813	.7631	.9651	.9088	.9341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 204 / MENDHALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.4973	.5144		.6001	.5144
2			.5144	.5144		.6001	.5144
3			.6001	.6859		.6859	.6859
4			.6344	.8573		.6859	.7716
5			.7716			.8402	.8573
6			.9602			.9259	.8573
7			1.0117			.9774	1.0288
8			1.0802			.9431	.9431
9			1.0802				.9431
10	.8573		1.0288			.8573	.6344
11						.8573	.8402
12							.8916
13						.9431	1.0631
14						1.0288	.9431
15					1.3717	1.0288	.9945
16						1.0288	1.0117
17	.6859		.7716		1.4746	.9431	.9431
18	.8573		.8573		1.406	1.0288	1.0288
19	.7716		.8573		.823	.5144	.6687
20	.6859	.0171	.7716		.6516	.6859	.6173
21	.5144	.6344	.6859		.6344	.8573	.6001
22	.5144	.5144	.6859		.6001	.8573	.6516
23		.463	.4287			.5144	.463
24			.463	.4287		.5144	.5144
Max	.8573	.6344	1.0802	.8573	1.4746	1.0288	1.0631
Min	.5144	.0171	.4287	.4287	.6001	.5144	.463
Avg	.6981	.4072	.7611	.6001	.9945	.8145	.7909

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174010 / 33 KV ARDHAPUR

Feeder No / Name : 205 / NIRML COTTON & GINNING  
Feeder KV- 11 / OUTGOING

HV Express Feeder

DATE	22-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0171		.0171	.0343
2			.0171		.0171	.0343
3			.0171		.0171	.0343
4			.0343		.0171	.0343
5			.0343		.0171	.0343
6			.0343		.0171	.0171
7			.0343		.0171	.0171
8			.0343		.0171	.0171
9			.0171		.0171	.0171
10	.0171				.0171	.0171
11	.0171				.0171	.0171
12	.0171					.0171
13	.0171				.0171	.0171
14	.0171				.0171	.0171
15	.0171			.0171	.0171	
16	.0171				.0171	.0171
17	.0171	.0171		.0171	.0171	.0171
18	.0171	.0171		.0171	.0171	.0171
19	.0171	.0343		.0171	.0343	.0171
20	.0171	.0343		.0171	.0343	.0171
21	.0171	.0343		.0171	.0343	.0171
22	.0171	.0171		.0171	.0343	.0171
23		.0171		.0343	.0343	.0171
24			.0171		.0343	.0343
Max	.0171	.0343	.0343	.0343	.0343	.0343
Min	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.0171	.0245	.0257	.0193	.0216	.0216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 201 / MALEGAON

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.5365	1.0164	.9724	1.1203	1.2136	1.2071
2		.6706	1.0269	1.0059	1.1203	1.2136	1.182
3		.7712	1.0642	1.1065	1.2136	1.307	1.2483
4		.8383	1.2136	1.6057	1.4003	1.4003	1.3226
5		.8718	1.4937	1.8671	1.6244	1.6804	1.4419
6		.8718	1.7556	1.8858	1.8671	1.8671	1.6118
7		1.2071	1.7737	2.0165	1.9805	1.9791	1.6956
8		1.4083	1.7737	1.8671		1.9418	1.5604
9	1.1142			1.531		1.7177	1.4083
10	.9922	1.2887		1.0269			1.307
11	.8962	1.0269	.9389	1.0031	1.2071		1.0402
12	.8589	1.0269		1.0802	1.3413	1.3565	1.0802
13	.8215	1.0164	1.0059	1.1574	1.4754	1.5424	1.0279
14		1.0164	1.0395	1.1574	1.4419	1.6118	.9945
15	.8215	1.0164	1.0059	1.1574	1.4083	1.6832	
16	.8589	1.0269	.9724	1.1431	1.4091	1.4998	.9602
17		1.2136		1.1431	1.3763	1.1949	1.1012
18	1.1949	1.386	.9054	1.2018			1.2289
19	1.5684		1.5497	1.6804	1.4937	1.3306	1.587
20	1.587	1.7556	1.5684	1.4937	1.5497	1.419	1.4937
21	1.3443	1.5708	1.3443	1.307	1.307	1.4118	1.4003
22	1.1949	1.2012	1.1949	1.2136	1.2696	1.3112	1.2136
23	1.1203	1.1203	1.1203	1.2136	1.2136	1.2803	1.2136
24	1.0082	1.0829	1.0269	1.0829	1.2136	1.2136	1.2696
Max	1.587	1.7556	1.7737	2.0165	1.9805	1.9791	1.6956
Min	.8215	.5365	.9054	.9724	1.1203	1.1949	.9602
Avg	1.0926	1.0875	1.2395	1.3300	1.4017	1.4846	1.2868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 202 / UMRI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.2801	.2801	.3856	.3361	.3658
2		.3856	.2801	.2801	.4294	.3361	.3224
3		.4024	.2801	.2801	.4294	.3361	.3121
4		.4359	.3174	.3361	.4854	.3734	.39
5		.4694	.3734	.4108	.6535	.6535	.4862
6		.4694	.4854		.8962	.8402	.5658
7		1.1904	.499	.4668	.8962	.8775	.6274
8		1.2742	.5121	.5041		.8402	.5658
9	.9724			.3174		.5228	.4527
10	1.4083	.9326		.2054			.3481
11	.2054		.4527	.9172	1.1142		.8482
12			.4694	.9061	1.1797	1.1869	1.0494
13		.2427	.4191	.9374	1.2289	1.2971	1.0437
14		.2427	.4359	.9842	1.2289	1.3432	.8478
15		.2427	.4694	1.0155	1.2289	1.3032	
16		.2427	.6371	.953	1.278	1.2803	.9922
17		.2801		.9374	1.278	1.2696	1.0688
18	.5041	.3361	.5868	1.0155			1.1469
19	.5228		.4294	.6722	.5228	.4805	.5228
20	.5228	.4294	.3734	.5601	.4854	.5228	.4854
21	.4481	.3734	.3734	.4854	.4294	.4525	.4481
22	.3921	.2801	.2332	.4715	.3921	.4075	.4294
23	.3734	.2801	.2801	.4481	.3734	.3841	.4108
24	.3734	.3734	.2801	.2801	.4294	.3734	.4108
Max	1.4083	1.2742	.6371	1.0155	1.278	1.3432	1.1469
Min	.2054	.2427	.2332	.2054	.3734	.3361	.3121
Avg	.5723	.4609	.4032	.5941	.7672	.7341	.6148

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 203 / DEGAON (KD.)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.6722	.3734	.3353	.4191	.4588	.5487
2		.6722	.3605	.3688	.4973	.5243	.6089
3		.7468	.3647	.4694	.547	.6226	.7108
4		.8402	.3856	.5868	.5898	.6882	.8139
5		.9335	.4287	.6706	.6478	.7537	.9389
6		.9709	.4508	.6706	.7773	.7865	1.046
7		.6161	.5365	1.073	1.0364	1.2125	1.0852
8		.4481	.6478	1.0395		1.3763	1.0631
9	.6413			.9724		1.2125	1.0227
10	.6348	.4294		.759			.9175
11	.5735	.6554	.2054	.2987			.4108
12	.5735	.6401	.1867	.2987			.3547
13		.6173				.2103	.3734
14		.6173				.2686	.3734
15	.4694	.6173	.4481		.2241	.2896	
16	.5365	.6173	.4854		.2987	.2561	.5788
17		.5468		.3734	.4668	.1494	.6535
18	.5868	.5121	.4481	.7468			.7655
19	.7095		.8775	.8962	.5788	.499	.7468
20	.7282	.3734		.8402	.5788	.7468	.7468
21	.6722	.5601	.6161	.7468	.5788	.6516	.7468
22	.6348	.7655	.6161	.6535	.4854	.5138	.7468
23	.6348	.7468	.5975	.6348	.4481	.439	.7095
24	.6722	.5975	.7356	.5975	.5975	.4481	.4854
Max	.7282	.9709	.8775	1.073	1.0364	1.3763	1.0852
Min	.4694	.3734	.1867	.2987	.2241	.1494	.3547
Avg	.6243	.6453	.4869	.6516	.5482	.6054	.7151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174031 / 33 KV MALEGAON

Feeder No / Name : 204 / KASARKHEDA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4854	.2429	.2515	.4694	.4588	.4938
2		.5601	.2785	.3018	.5304	.5735	.6268
3		.6722	.2984	.3734	.5801	.6554	.7455
4		.7468	.3688	.4024	.639	.6882	.8309
5			.4115	.4694	.7125	.7373	.8718
6		.8589	.4854	.503	.7773	.7701	.9945
7		.9335	.5533	.788	.9717	1.0978	1.0852
8		.8589	.6802	.7545		1.2289	1.0631
9	.6535			.7377		1.1469	1.0059
10	.4294	.4668		.6167			1.0829
11	.5407	.7209	.2801	.3174	.3174		.3921
12	.5571	.7202	.2427	.2801	.3361	.2713	.3547
13	.57	.7253	.2801	.2801	.2987	.2629	.3361
14		.7253	.2801	.2801	.2987	.2686	.3361
15	.6706	.7253	.2801	.2801	.2801	.3258	
16	.6706	.7253	.3174	.4108	.3734	.439	.3921
17		.6249		.4108	.4854	.5415	.5601
18	.5868	.4641	.3734				.6348
19	.7095		.6908	.7655	.6535	.5544	.6348
20	.6908	.6908	.6348	.6535	.6908	.5975	.5975
21	.6348	.6161	.5601	.5975	.5601	.5068	.5601
22	.5228	.5601	.5415	.5601	.5228	.4607	.5228
23	.4481	.5228	.4854	.5228	.4854	.4572	.5041
24	.4481	.4481	.4854	.4854	.4854	.4854	.4481
Max	.7095	.9335	.6908	.788	.9717	1.2289	1.0852
Min	.4294	.4481	.2427	.2515	.2801	.2629	.3361
Avg	.5809	.6596	.4177	.4801	.5234	.5966	.6554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 202 / CHABHARA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.4334	.3429			.5144	.6687
2	.4287	.4334	.3429			.5144	.7202
3	.4287	.4287	.3772			.5144	.7716
4	.4287	.5144	.4287			.6859	.8573
5	.4287	.5144	.5487			.7716	1.1145
6	.5144	.6001	.6859			.8573	1.166
7	.6516	.6516	.7373			1.6956	1.2003
8	.5144	.583	.6001			1.9719	1.6461
9	.4287		.4801			2.2291	1.6461
10	.3429		.3086				.7716
11	.6859		.7202		.2058		.2572
12	.823		.7545	.1372			.2572
13	.9431		.7545			.3772	.3429
14	1.0631		.7888	.1543	.3429	.3601	.3086
15	1.166		.8573	.1715	.2572	.3429	.3086
16	1.1191		.9259	.2058	.2058	.4115	.3429
17			.9259	.2572	.3086	.4115	.3429
18	1.1145		.9259	.3429	.3429	.4287	.3429
19	.583	.5487		.5144	.3429	.3944	
20	.5144	.5144		.5144	.4287	.5487	.4287
21	.5144	.4801		.4801	.4287	.6687	.4287
22	.5144	.4458			.4287	.5144	.4287
23	.4287	.4287			.4287	.4801	
24	.4287	.4287	.3772	.4115		.4287	.4458
Max	1.166	.6516	.9259	.5144	.4287	2.2291	1.6461
Min	.3429	.4287	.3086	.1372	.2058	.3429	.2572
Avg	.6302	.5004	.6254	.3189	.3383	.7201	.6726



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 203 / LONI

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8573			
24	.8573		.823	.8573	.7716
Max	.8573	.8573	.823	.8573	.7716
Min	.8573	.8573	.823	.8573	.7716
Avg	.8573	.8573	.823	.8573	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174040 / 33 kv LAHAN substation

Feeder No / Name : 204 / 11KV SONALA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.4334	.4801			.5144	.4287
2	.5487	.4334	.4801			.5144	.5144
3	.5487	.4287	.5144			.5144	.6001
4	.6001	.5144	.6001			.6001	.6859
5	.6859	.5144	.6516			.7716	.7716
6	.6859	.6859	.6859			.8573	.823
7	.7716	.8573	.7716			1.1869	.8573
8	.6001	.6516	.7545			1.2003	.9431
9	.5144		.5144	.5144		1.286	.8573
10	.4115		.4115				.8573
11	.4801		.5487		.3429		.3429
12	.4287		.5487				.3429
13	.4287		.5487			.3772	.3429
14	.4287		.5487		.3429	.4115	.3086
15	.7202		.5487	.3429	.3429		.3086
16	.8048		.583	.3772	.3429	.4801	.3429
17			.583	.4115	.4287	.5316	.3429
18	.8573		.6173	.3772	.5144	.583	.4801
19	.6516	.5144		.6344	.6173	.5658	.5487
20	.6001	.6516		.6516	.6516	.6516	.6173
21	.6001	.6173		.6516	.6516		.6001
22	.5144	.583			.6173	.583	.6001
23	.4287	.5487			.5487	.5487	
24	.5487	.4287	.5144			.5487	.5316
Max	.8573	.8573	.7716	.6516	.6516	1.286	.9431
Min	.4115	.4287	.4115	.3429	.3429	.3772	.3086
Avg	.5829	.5616	.5740	.4951	.4910	.6698	.5673

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 201 / PARDI (M)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961	.4481	.5365	1.1271	1.1694	1.2136	1.2398
2	.4961	.4801	.5898	1.126	1.1317	1.226	1.2386
3	.567	.5121	.5871	1.2023	1.1317	1.3203	1.311
4	.6024	.6081	.6081	1.3525	1.3203	1.5089	1.4638
5	.631	.6401	.6554			1.0562	1.1317
6	.8413	.7682	.8619			1.1317	.9709
7	1.1218		1.0162			1.1317	1.0413
8	1.1919		1.0159			1.5089	.9393
9	1.1142	1.1717	.8759			1.1317	1.1271
10	1.0364	1.1574				1.0562	
11	.1509	.6036	.4508	.9488	.3841	.995	
12	.1509	.3003	.526	1.0753	1.0402		
13		.4116	.5265	1.0669	1.1203	1.1561	.3128
14		.3742	.6005	1.0974	1.1203	1.4548	.5569
15	.1886	.4137	.677	1.0974	1.2803	1.3916	
16	.1886	.563	.7522	1.1728	1.6004	1.2772	.8663
17	.1886	.8299		1.2193	1.6004	1.4083	1.1262
18	.7545	.9054	1.053	1.4022	1.6004	1.2879	.6807
19	1.3203	1.2865	1.2774	1.4335	1.3443	.8694	
20	1.4146	1.2852	1.2774	1.358	1.307	1.2096	1.3525
21	1.3203	1.2108	1.2787	1.2826	1.2136	1.2449	1.2787
22	1.226	1.2096	1.2023	1.2071	1.226	1.2474	1.2761
23	1.226	1.1753	1.1283	1.1694	1.1203	1.2449	1.1271
24	1.2071	1.226	1.1374	1.1283	1.1694	1.1317	1.2386
Max	1.4146	1.2865	1.2787	1.4335	1.6004	1.5089	1.4638
Min	.1509	.3003	.4508	.9488	.3841	.8694	.3128
Avg	.7925	.7991	.8470	1.1926	1.2156	1.2263	1.0673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 202 / CHORAMBA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2641	.3024	.2475	.2881	.2641	.3224
2	.2263	.2641	.3006	.2475	.3163	.2591	.3201
3	.2641	.2641	.3006	.2475	.3163	.2591	.3201
4	.3018	.3018	.3381	.2816	.3795	.2915	.3193
5				.2785	.4062	.3239	.3269
6				.3094	.4374	.5668	.3563
7				.3713	.6562	.7287	.6045
8				.4022	.7621	.7287	.7426
9				.495	.8002	.759	.7116
10				.4816	.8002	.7499	.2785
11	.2241	.3387	.2475			.1509	.1127
12	.3201	.3277	.4332				.1127
13		.5243	.4332			.1512	.1127
14		.5376	.4332			.1892	.1126
15	.4801	.5542	.526			.1132	.1238
16	.4801	.5508	.5569			.1513	.1126
17	.4801	.463		.1509	.2241	.1886	.1503
18	.4801	.4111	.4704	.1698	.2614	.189	.1879
19	.2641	.3018	.2254	.2641	.2614	.2263	.263
20	.2641	.3024	.3006	.3018		.2646	.2475
21	.2641	.3402	.3009	.3206	.2614	.3024	.3003
22	.2641	.3405	.3009	.3206	.2614	.3018	.3006
23	.2641	.3412	.3006	.3018	.2614	.2641	.263
24	.2641	.2641	.3033	.263	.2641	.2641	.2627
Max	.4801	.5542	.5569	.495	.8002	.759	.7426
Min	.2241	.2641	.2254	.1509	.2241	.1132	.1126
Avg	.3167	.3718	.3573	.3030	.4093	.3342	.2902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174088 / 33 kV SUB-STATION PARDI (M)

Feeder No / Name : 203 / Delub Bk

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6036	.6811	.4332	.6478	.5761	.4858
2		.6036	.6824	.495	.6478	.5761	.6081
3		.6413	.6811	.5005	.6722	.6081	.6363
4		.679	.7567	.5631	.7362	.6081	.6325
5				.6272	.8124	.6401	.6249
6				.7426	.9061	1.0402	.7773
7				.8759	1.1873	1.2803	1.209
8				.9282	1.0059	1.3603	1.439
9				.8663	1.2308	1.2651	1.3304
10				.9145	1.2308	1.3279	.8045
11	.6226	.8778	.6807		1.2163	.5658	.4508
12	.8002	.9831	.9282				.4504
13		1.0437	.9901			.3402	.3761
14		1.0468	.9901			.454	.3757
15	.8907	1.0085	1.052			.5281	.3006
16	.8907	.764	1.052			.4527	.4504
17	.8097	.7811		.5093	.5228	.5658	.4508
18	.8097	.8048	1.0011	.5847	.679	.7167	.6011
19	.7922	.7922	.7514	.7545	.7167	.756	.6756
20	.7922	.756	.7522	.7545	.7167	.7189	.6756
21	.7545	.7567	.677	.7545	.679	.7182	.6756
22	.679	.7204	.677	.679	.679	.7167	.6756
23	.6413	.7204	.677	.679	.679	.6804	.6011
24	.6036	.6036	.6824	.6763	.679	.679	.6368
Max	.8907	1.0468	1.052	.9282	1.2308	1.3603	1.439
Min	.6036	.6036	.677	.4332	.5228	.3402	.3006
Avg	.7572	.7881	.8066	.6855	.8234	.7467	.6643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 201 / KAMTHA (BK.)

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.3772	.1509		.1886	.1886	.1698
2	.5093	.3772	.1509		.1886	.1886	.1698
3	.5093	.4715	.1509		.1886	.1886	.1698
4	.5658	.4715	.132		.2263	.1886	.1886
5	.5658	.5658	.132		.2641	.1886	.1886
6	.6224	.6036	.1509		.3018	.2263	.2075
7	.6224	.6602	.2263		.3206	.2263	.2452
8	.679	.679	.2641		.2829	.2452	.2452
9	.679					.2452	.2263
10	.6224					.2075	.2075
11	.1132		.4527	.5658	.7545	.5658	.5658
12	.1132		.5093	.6224	.6224	.5658	.6036
13			.5658	.6224	.6224	.679	.6036
14	.132		.5658	.6602		.679	.5281
15	.1132		.5658		.6224	.679	
16	.1132	.1509	.5658	.6602	.5658	.6224	.5658
17	.1698		.5658	.6602	.6602	.6224	.6979
18	.2075		.6224	.679		.6224	
19	.2263		.2641	.1886	.2263	.2075	
20	.2452	.1886	.2452	.2829	.2452	.2263	.2452
21	.2263	.1886	.2075	.2263	.2452	.2263	.2263
22	.2075	.1886	.2075	.2075	.2263	.2075	.2075
23	.1886	.1886	.1886	.1886	.1886	.1886	.1886
24	.1886	.1886		.1886	.1886		.1886
Max	.679	.679	.6224	.679	.7545	.679	.6979
Min	.1132	.1509	.132	.1886	.1886	.1886	.1698
Avg	.3485	.3786	.3278	.4425	.3565	.3559	.3162

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 202 / GANPUR

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.5658		.5658	.5658	.5658
2	.1698	.1886	.5658		.5658	.5658	.5658
3	.1886	.2075	.5658		.6602	.6602	.679
4	.1886	.2263			.7545	.7545	.679
5	.2075	.2452			.9431	.9431	.9054
6	.2452	.2829			1.0374	1.0374	1.1317
7	.2829	.3395			1.1317	1.1317	1.2449
8	.2829	.3206			1.4712	1.3203	1.2449
9	.2641					1.5655	1.2449
10	.2075					1.1317	1.2449
11	.4715		.0943	.0943	.1132	.1509	.1509
12	.5658		.0943	.0943	.0754	.1509	.132
13	.5658		.0943	.0943	.0943	.132	.132
14	.6224		.0943	.0943		.132	.1132
15	.5658		.0943		.0943	.132	
16	.5658	.8488	.1132	.1132	.132	.1886	.1509
17	.7167		.1509	.1698	.1698	.2075	.2263
18	.7167		.2075	.1698		.2263	
19	.2452		.2641	.2452	.1886	.2452	
20	.2263	.1886	.2452	.3018	.2195	.2452	.2263
21	.1886	.1886	.2263	.2452	.2263	.2263	.2075
22	.1886	.1886	.1886	.2075	.1886	.2263	.1886
23	.1886	.1886	.1886	.1886	.1886	.1886	.1886
24	.1886	.1886		.1698	.1886		.1886
Max	.7167	.8488	.5658	.3018	1.4712	1.5655	1.2449
Min	.1698	.1886	.0943	.0943	.0754	.132	.1132
Avg	.3426	.2708	.2346	.1683	.4504	.5273	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-JUL-17 and 28-JUL-17

NANDED ZONE[066]

NANDED CIRCLE[690]

NANDED RURAL DIVISION[242]

NANDED RURAL II S/DN[444] BU 2437

Substation No/ Name :- 174105 / 33 KV KAMTHA (BK.)

Feeder No / Name : 203 / NANDUSA

Single Phasing Feeders

Feeder KV- 11 / OUTGOING

DATE	22-JUL-17	23-JUL-17	24-JUL-17	25-JUL-17	26-JUL-17	27-JUL-17	28-JUL-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.2829	.1132		.1132	.132	.0943
2	.5658	.3395	.1132		.1132	.1029	.0943
3	.5658	.4715	.1132		.1132	.1132	.0943
4	.679	.5658	.0943		.132	.1132	.1132
5	.7922	.5658	.0943		.1509	.132	.1132
6	.8488	.6602	.0943		.1698	.132	.1509
7	.9054	.7922	.132		.1698	.1509	.1698
8	.8488	.811	.1698		.1509	.1509	.1698
9	.7922					.1698	.1698
10	.7356					.1509	.1509
11	.0754		.5093	.5281	.6036	.679	.7545
12	.0754		.5658	.6224	.8676	.7922	.9619
13	.0754		.6224	.7167	.9054	.9054	.9431
14	.0754		.6224	.7545		.9054	.5093
15			.6224		.0943	.9054	
16		.0566	.679	.7733	.8488	.9054	.6979
17			.679	.8676	.9431	.9054	.7545
18	.0943		.679	.8488		.9054	
19	.1509		.1886	.132		.132	
20	.1509	.132	.1886	.1509	.1698	.1509	.1509
21	.1509	.132	.1698	.1509	.1509	.1509	.1509
22	.132	.132	.1698	.1509	.1509	.1509	.1509
23	.132	.132	.1509	.132	.1509	.132	.132
24	.0943	.132		.132	.132		.1132
Max	.9054	.811	.679	.8676	.9431	.9054	.9619
Min	.0754	.0566	.0943	.132	.0943	.1029	.0943
Avg	.4024	.3718	.3224	.4585	.3226	.3899	.3162