

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 201 / 11 KV MIDC I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.6975	1.3717	1.7147	2.191	1.6975	1.9624
2	1.7147	1.5844	1.3717	1.7718	2.0957	1.6409	1.9433
3	1.7147	1.5844	1.3336	1.6575	2.0957	1.5844	1.9624
4	1.6004	1.5278	1.4289	1.7147	2.0005	1.6409	1.9052
5	1.5242	1.4712	1.467	1.7147	2.0005	1.6975	1.9052
6	1.6194	1.4146	1.5242	1.5432	2.1529	1.6975	1.6194
7	1.6194	1.4146	1.5051	1.4289	2.0005	1.6975	1.5623
8	1.5623	1.358	1.5051	1.7337	1.8099	1.5844	1.6385
9	1.5051	1.358	1.5623	1.8099	1.9052	1.6975	1.848
10	1.8099	1.2449	1.829	2.0005	2.0195	2.2634	1.9624
11	1.8673	1.086	1.7147	1.9052	1.9052	2.3815	2.0957
12	1.8673	1.105	1.7147	1.9052	2.0936	2.4006	2.2862
13	1.8107	1.0479	1.9052	1.9624	1.9239	2.3243	2.2291
14	1.8673	1.3146	1.9433	2.0386	1.9805	2.3053	2.0005
15	1.8673	1.2955	1.9052	2.0005	2.0936	1.9433	2.0957
16	1.9239	1.3336	1.9624	2.0005	1.9805	2.0005	2.2862
17	1.9239	1.3336	1.9052	1.9814	2.32	2.0005	
18	1.8673	1.4861	1.9243	1.9243	1.9805	1.9433	2.2862
19	1.9239	1.467	2.1338	1.9243	2.1502	1.9433	2.191
20	1.8673	1.4289	2.2862	1.9624	1.9805	2.0005	2.2862
21	1.6975	1.4098	2.2862	1.9624	1.9805	1.8861	2.2862
22	1.8673	1.3336	1.9433	1.9624	1.9239	1.8099	2.0957
23	1.6975	1.2955	1.7909	2.21	1.8107	2.0005	2.0386
24	1.6956	1.6975	1.4289	1.9052	2.2672	1.6975	1.9624
Max	1.9239	1.6975	2.2862	2.21	2.32	2.4006	2.2862
Min	1.5051	1.0479	1.3336	1.4289	1.8099	1.5844	1.5623
Avg	1.7538	1.3871	1.7393	1.8639	2.0276	1.9099	2.0195

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 202 / 11 KV MIDC II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.1905	.381	.5716	.2286	.1905
2	.381	.2858	.1905	.381	.5716	.1715	.2858
3	.381	.2858	.1905	.1905	.381	.1715	.3048
4	.381	.2858	.1905	.1905	.381	.1715	.2858
5	.381	.2858	.1905	.1905	.381	.1715	.1905
6	.381	.2858	.1905	.1905	.381	.2286	.1905
7	.381	.2858	.1905	.1905	.2858	.2286	.1905
8	.381	.2858	.1905	.1905	.1905	.2286	.1905
9	.381	.2286	.1905	.1905	.2858	.2858	.1905
10	.5716	.2858	.381	.381	.5335	.2858	.1905
11	.4572	.2286	.381	.5716	.381	.2286	.1905
12	.5144	.1905	.381	.5716	.4001	.4763	.1905
13	.2858	.1905	.381	.5716	.3429	.4763	.381
14	.5716	.2858	.381	.5716	.4001	.4954	.381
15	.4572	.1905	.381	.4763	.3429	.381	.381
16	.6859	.1905	.381	.4763	.4001	.3048	.381
17	.5144	.2286	.381	.381	.3429	.2858	.1905
18	.3429	.2286	.381	.381	.3429	.4954	.1905
19	.4001	.2477	.381	.381	.2858	.4954	.1905
20	.3429	.2286	.381	.2858	.2858	.3429	.1905
21	.2858	.1905	.381	.1905	.2286	.4954	.1905
22	.2858	.1905	.381	.381	.2858	.3429	.1905
23	.2858	.1905	.381	.381	.2858	.381	.381
24	.381	.4001	.1905	.381	.381	.2858	.2858
Max	.6859	.4001	.381	.5716	.5716	.4954	.381
Min	.2858	.1905	.1905	.1905	.1905	.1715	.1905
Avg	.4048	.2493	.3016	.3532	.3612	.3191	.2469

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 203 / 11 KV TAKALGHAT (G)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.086	1.0479	1.0479	.9526	1.086	.9526
2	.9526	1.086	1.0479	1.0479	.9526	1.0288	.9717
3	.9526	1.086	1.0098	1.0479	.9526	1.0288	.9717
4	.9526	1.0288	1.0098	1.1431	.9526	.9717	1.0098
5	.9526	1.0288	1.0669	1.1431	.9526	.9717	.9907
6	.9526	.9717	1.105	1.0479	.9526	.9145	1.086
7	.9526	.9145	.9145	.9526	.8573	.8573	.9907
8	.7621	.8573	.8954	.8573	.7621	.743	.9526
9	.5716	.8002	.8954	.7621	.8573	.8002	.8954
10	.7621	.8002	.8764	.7621	.9526	.8002	.8002
11	.8002	.8002	.7621	.7621	.7621	.8192	.7621
12	.8002	.8002	.7621	.7621	.743	.8764	.7621
13	.9717	.8002	.7621	.7621	.9717	.7621	.6668
14	1.0288	.8192	.8573	.7621	.743	.743	.6668
15	1.086	.7621	.8573	.7621	.8002	.9145	.6668
16	1.0288	.7811	.8573	.7621	.8002	.8764	.5716
17	.9717	.743	.9526	.7621	.743	.9145	.6478
18	.9717	1.0479	.9526	.8573	.8002	.9526	.7621
19	.9717	1.105	1.086	.9526	1.0288	1.0669	.7621
20	1.3146	1.2955	1.1431	1.0479	1.1431	1.2574	.9526
21	1.3146	1.3336	1.1431	1.1431	1.1431	1.3146	.9526
22	1.2003	1.3146	1.1431	1.1431	1.1431	1.2384	.9526
23	1.1431	1.2955	1.1431	1.1431	1.086	1.086	.9526
24	.9526	1.086	1.105	1.1431	.9526	1.086	1.086
Max	1.3146	1.3336	1.1431	1.1431	1.1431	1.3146	1.086
Min	.5716	.743	.7621	.7621	.743	.743	.5716
Avg	.9717	.9852	.9748	.9407	.9169	.9629	.8661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 204 / 11 KV MIDC III

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2574		1.2574	1.2384	
2				1.3146	1.1812	
3				1.1812	1.1431	
4				1.105	1.1431	
5				1.2384	1.2193	
6				1.2384	1.3146	
7				1.2193	1.2765	
8				1.4289	1.2193	
9			1.2384	1.5242		1.2003
10		.7811	1.3146	1.6194	1.3336	1.4289
11	1.5432	.7621	1.3336	1.5623	1.4861	1.448
12	1.5432	.724	1.3336	1.5623	1.4861	1.4289
13	1.3146	.7621	1.467	1.5432	1.3146	1.3717
14	1.5432	.8192	1.6194	1.5432	1.6575	1.5623
15	1.5432	.8192	1.6194	1.6194	1.6575	1.5432
16	1.5432	.8002	1.6385	1.6766	1.6575	1.6766
17	1.4289	.7811	1.5623	1.7337		
18	1.2574	.8002	1.2765	1.6004		
19	1.2003	.8192	1.1431	1.4289		
20	1.3146	.8573	1.0479	1.3336		
21	1.2003	.9526	1.0479	1.2384		
22	1.1431	.9526	1.0479	1.105		
23	1.1431	.9526	1.0479	1.2765		
24	.0343	1.2574	.9717	1.2955	1.2955	
Max	1.5432	1.2574	1.6385	1.7337	1.6575	1.6766
Min	.0343	.724	.9717	1.105	1.1431	1.2003
Avg	1.2680	.8811	1.2944	1.4019	1.3515	1.4575

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 205 / 11 KV MIDC IV

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.2949	.3048	.4954	.6097	.5407	.4763
2	.3429	.2949	.2858	.4954	.5716	.5407	.4954
3	.3429	.2949	.2858	.4763	.5716	.5407	.4763
4	.4001	.2949	.2858	.4954	.6097	.5407	.4382
5	.4001	.2785	.3048	.4763	.5716	.4915	.4191
6	.4382	.2785	.3239	.4191	.6097	.4915	.381
7	.2667	.2785	.3048	.3048	.5716	.4915	.3429
8	.3048	.2622	.2858	.381	.5525	.4915	.381
9	.362	.2458	.3239	.4001	.724	.6882	.5906
10	.3048		.4191	.4001	.8573	.639	.5716
11	.2949		.4763	.4001	.7621	.7621	.5716
12	.2949		.4763	.4572	.6882	.8764	.5716
13	.3441		.381	.381	.639	.8383	.5335
14	.3441	.3048	.381	.3048	.5407	.8764	.5525
15	.5144	.3048	.381	.3429	.4915	.8192	.381
16	.3932	.3239	.3429	.4001	.7373	.6287	.381
17	.2949	.3239	.3429	.4382	.5407	.6097	.381
18	.2949	.3429	.3239	.4382	.5407	.6097	.4001
19	.2949	.3429	.3239	.4763	.5898	.6287	.4191
20	.2949	.362	.3429	.4763	.5407	.5716	.4382
21	.2949	.362	.381	.5144	.5407	.6668	.4191
22	.3932	.362	.4191	.5525	.5407	.7621	.381
23	.3932	.3429	.4763	.6668	.4915	.8002	.4382
24	.4001	.4424	.3239	.4572	.6478	.5407	.6097
Max	.5144	.4424	.4763	.6668	.8573	.8764	.6097
Min	.2667	.2458	.2858	.3048	.4915	.4915	.3429
Avg	.3496	.3169	.3540	.4437	.6059	.6436	.4604

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 206 / 11 KV MIDC VI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.3146	.5716	1.1431	1.2384	1.2574	.9907
2	1.2003	1.5432	.5716	1.1431	1.1812	1.2574	.9907
3	1.1431	1.4289	.4763	1.0479	1.105	1.2003	.9717
4	1.1431	1.2574	.4763	.9526	1.0479	1.1431	.9526
5	1.0669	1.1431	.381	.9526	1.0479	1.0288	.9717
6	1.0669	.9145	.381	.9526	.9907	.9717	.9526
7	.9907	.4572	.3429	.9526	1.0479	.9717	.9907
8	1.0479	.4001	.381	.9526	1.1431	1.0288	1.0098
9	1.0669	.2858	.4954	.9526	1.2384	1.1431	.9907
10	1.0669	.2286	.5716		1.2955	.9717	.9907
11	1.2003	.2858	1.0479	1.0479	.9907		1.0098
12	.9717	.381	1.1431	1.1431	1.1431	.9526	1.0479
13	.8002	.362	1.1431	1.0479	.8573	.743	.9526
14	.9717	.381	1.1431	.9907	.9717	.7621	.9526
15	.743	.381	1.1431	1.0479	.9717	.9145	.9526
16	.9717	.362	1.1431	1.0669	1.0288	.9717	.9526
17	1.1431	.3429	1.1431	1.0669	1.0288	.9526	.9526
18	1.2003	.3429	1.1431	1.1431	.9717	.9526	.9526
19	1.2003	.2858	1.2384	1.1431	1.0288	.9145	.9526
20	1.3146	.3429	1.3336	1.0669	1.3146	1.0669	.9526
21	1.2574	.381	1.3336	1.0669	1.3146	1.2574	1.0479
22	1.1431	.4001	1.2384	1.1431	1.1431	1.1431	1.1431
23	1.1431	.4191	1.1431	1.2193	1.3146	1.1241	1.1431
24	1.2955	1.3146	.9526	1.1431	1.3717	1.3717	1.0098
Max	1.3146	1.5432	1.3336	1.2193	1.3717	1.3717	1.1431
Min	.743	.2286	.3429	.9526	.8573	.743	.9526
Avg	1.0979	.6231	.8724	1.0603	1.1161	1.0479	.9931

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 207 / 11 KV MIDC VII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6287	.5335	.6478	.5335	.6287	.6097
2	.6668	.743	.5335	.6668	.5335	.5716	.5906
3	.6668	.6859	.4954		.5144	.5716	.6097
4	.743	.6287	.4954	.6859	.5525	.5716	.5716
5	.743	.6287	.5144	.6668	.5525	.6287	.6097
6	.8192	.6287	.5335	.6668	.6097	.6287	.6287
7	.8002	.6287	.5335	.5716	.5906	.6287	.6668
8	.8573	.5716	.5716	.7049	.5906	.743	.7621
9	.9145	.5716	.9145	.8573	.7621	.8573	.8192
10	1.0098		1.0288	.9526	.9717	.9717	.8002
11	1.1431		1.0479	1.0479	1.0098	1.1431	.8002
12	1.086		1.105	1.1622	1.086	1.1622	.7621
13	.9717	.4572	1.0479	1.1431	.9717	1.1622	.6668
14	1.3146	.5525	1.1431	1.1622	1.0288	1.1431	.7621
15	1.1431	.5716	1.1431	1.1622	1.0288	.9907	.724
16	1.3146		1.1431	1.105	.9145	1.0098	.6668
17	1.3717	.5716	1.1431	1.0669	1.3146	1.0479	.6668
18	1.1431	.5716	1.0479	.8573	1.086	1.0288	.6478
19	.6859	.5716	.9526	.7621	.8573	.6287	.6097
20	.8002	.5716	.6859	.724	.6287	.6097	.6668
21	.8573	.5716	.6668	.6287	.743	.6478	.6097
22	.8002	.5525	.6097	.6668	.6859	.6478	.5716
23	.6287	.5525	.5906	.6287	.6287	.6287	.5716
24	.7811	.6859	.5525	.6859	.5906	.6287	.6287
Max	1.3717	.743	1.1431	1.1622	1.3146	1.1622	.8192
Min	.6287	.4572	.4954	.5716	.5144	.5716	.5716
Avg	.9161	.5973	.7931	.8358	.7827	.8034	.6676

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 208 / 11KV MIDC No.VIII

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	1.1431	.7049	1.3336	.9526	.9717	1.2003
2	1.0479	1.1431	.7049	1.3336	.9526	1.0288	1.2003
3	.9907	1.086	.724	1.2384	.9526	1.0288	1.2003
4	.9907	1.0288	.724	.7621	.9526	1.086	1.1431
5	.9526	.9717	.7621	1.105	.9526	1.086	1.1431
6	.9526	.9717	.8383	1.1431	.9526	1.086	1.0669
7	.9526	.9145	.8764	1.1431	.9526	1.0288	1.3336
8	.9526	.8573	.8573	1.2955	.9526	.9717	1.4289
9	.9526	.8002	1.7718	1.4861	1.3336	1.3717	1.4861
10	1.1431	.8002	1.8099	1.7147	1.7147	1.5432	1.467
11	1.4289	.8002	1.9052	2.0957	1.5242	1.7147	1.4861
12	1.3146	.8002	1.9052	2.2862	1.5432	1.8861	1.3717
13	1.0288	.8192	1.9052	2.0005	1.7147	2.0005	1.3336
14	.9717	.8002	1.8099	1.7147	1.9433	2.0957	1.3908
15	1.3146		1.7147	1.8099	1.5432	1.9052	1.3336
16	1.0288		1.7147	1.8099	1.5432	1.6766	1.3336
17	.9717		1.7147	1.9052	1.9433	1.5242	1.3336
18	1.1431		1.7147	1.8099	1.7147	1.4861	1.3336
19	1.0288	.724	1.8099	1.7147	1.4289	1.448	1.3336
20	1.1431	.7621	1.9052	1.5242	1.3146	1.3336	1.2384
21	1.3146	.8764	1.7147	1.3336	.9717	1.2765	1.1431
22	1.3146	.8764	1.5623	1.1431	1.3717	1.2384	1.1431
23	1.1431	.7049	1.3336	1.1431	1.0288	1.2193	.9526
24	1.1431	1.3717	.743	1.3336	.9526	1.1431	1.2765
Max	1.4289	1.3717	1.9052	2.2862	1.9433	2.0957	1.4861
Min	.9526	.7049	.7049	.7621	.9526	.9717	.9526
Avg	1.0963	.9126	1.3844	1.5075	1.3003	1.3813	1.2781

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164018 / 33 KV MIDC BUTIBORI

Feeder No / Name : 209 / 11 KV MIDC IX

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.0288	.8764	.381	.9145	.8573	1.0098
2	.9526	1.0288	.8954	.9526	.9526	.8002	1.0098
3	.9526	1.0288	.8573	.9526	.9526	.8002	1.0288
4	.9145	1.0288	.8764	.7049	.9526	.8002	.9907
5	.9145	.9717	.8764	.9526	.8954	.8002	.9145
6	.9907	.9717	.9145	.9526	.8764	.8002	.8573
7	.9335	.9717	1.0479	.9335	1.0479	.8002	1.105
8	.9335	.8573	1.0669	.9526	1.1431	1.0288	1.1431
9	.9717	.8002	1.7337	1.3146	1.3336	1.086	1.2003
10	1.6766	.8573	1.7718	1.6194	1.5432	1.3717	1.1812
11	1.3146	.8002	1.7147	1.5242	1.105	1.3908	1.1812
12	.9717	.8002	1.448	1.3336	1.3717	1.1812	1.1812
13	1.1431	.7621	1.6194	1.3336	1.3717	1.2384	1.1622
14	1.4289	.8002	1.7147	1.3336	1.4861	1.3717	1.1431
15	1.3717		1.7147	1.3717	1.4861	1.2955	1.1431
16	1.3717		1.7147	1.3717	1.4289	1.5242	1.1431
17	1.4861	.8192	1.6194	1.5051	1.3717	1.1431	1.1431
18	1.5432	.8573	1.4861	1.2384	1.2574	.9526	.9526
19	1.1431	.9335	1.4289	.8954	.8573	.8573	.9526
20	1.2574	.9526	1.3336	1.0288	.9145	.8573	.9526
21	1.086	.9335	1.3336	1.105	.9145	1.2384	.8573
22	1.086	.9145	1.1812	1.0669	.8573	1.1431	.7621
23	.9145	.9145	.9526	.8954	.8002	.8192	.7621
24	1.0479	.9145	.9145	1.0479	.9907	.9145	1.0288
Max	1.6766	1.0288	1.7718	1.6194	1.5432	1.5242	1.2003
Min	.9145	.7621	.8573	.381	.8002	.8002	.7621
Avg	1.1423	.9067	1.2955	1.1153	1.1177	1.0447	1.0336

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 201 / 11 KV MOHOGAON SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7147	1.8861	1.5432	1.5432	1.5432	1.3717
2		1.7147	1.8861	1.6289	1.5432	1.5432	1.3717
3		1.7147	2.0576	1.6289	1.5432	1.3717	1.3717
4		1.7147	1.8861	1.7147	1.5432	1.3717	1.3717
5		1.7147	1.8861	1.7147	1.5432	1.3717	1.3717
6		1.7147	1.8861	1.7147	1.7147	1.3717	1.5432
7		1.5432	1.3717	1.5432	1.5432	1.3717	1.3717
8		1.3717	1.3717	1.3717	1.3717	1.2003	1.3717
9		1.3717	1.3717	1.3717	1.3717	1.2003	1.2003
10	1.3717	1.3717	1.3717	1.2003	1.2003	1.2003	1.3717
11	1.5432	1.3717	1.3717	1.3717	1.3717	1.2003	1.2003
12	1.3717	1.3717	1.2003	1.3717	1.3717	1.3717	1.3717
13	1.3717	1.2003	1.3717	1.3717	1.3717	1.2003	1.2003
14	1.5432	1.3717	1.3717	1.2003	1.3717	1.3717	1.0288
15	1.3717	1.3717	1.3717	1.3717	1.3717	1.2003	1.0288
16	1.5432	1.3717	1.3717	1.3717	1.3717	1.2003	.6859
17		1.3717	1.3717	1.3717	1.3717	1.2003	.6859
18	1.3717	1.3717	1.5432	1.3717	1.3717	1.2003	.6859
19	1.5432	1.5432	1.7147	1.5432	1.7147	1.5432	.6859
20	2.0576	1.8861	1.8861	1.8861	1.8861	1.7147	.7716
21	2.2291	1.8861	2.0576	2.0576	1.8861	1.7147	.7716
22	2.2291	2.0576	1.8861	2.0576	1.8861	1.7147	1.5432
23	1.8861	1.8861	1.7147	1.8861	1.7147	1.5432	1.0288
24	1.7147	1.8861	1.7147	1.7147	1.7147	1.5432	1.5432
Max	2.2291	2.0576	2.0576	2.0576	1.8861	1.7147	1.5432
Min	1.3717	1.2003	1.2003	1.2003	1.2003	1.2003	.6859
Avg	1.6534	1.5789	1.6218	1.5575	1.5289	1.3860	1.1645

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 202 / 11 KV BUTIBORI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9945	1.1145	1.0288	.9431	.9602	.8916
2		1.989	.9945	.9945	.9431	.9602	.8573
3		.9602	1.0288	.9945	.9431	.823	.8573
4		.9602	1.0631	.9602	.9088	.8573	.8573
5		.9602	1.0288	.9431	.9088	.8573	.8745
6		.9602	1.0288	.9602	.9602	.823	.8916
7		.8573	.8402	.8573	1.749	.7545	.8573
8		.7545	.7888	.8059	.8059	.7373	
9		.7202	.8573	.7716	.7716	.7716	
10	.8059	.7202	.7716	.7202	.7373	.7716	.6687
11	.7202	.6173	.6859	.6859	.703	.7716	.6859
12	.7202	.5316	.6516	.6859	.6516	.7716	.7716
13	.7202	.6001	.6173	.6859	.6516	.6516	.6344
14	1.046	.6344	.6001	.6344	.6516	.6859	.5316
15	.7202	.6687	.6344	.6687	.6859	.6859	.5487
16	.7545	.6687	.7202	.6859	.6687	.6859	.6859
17	.7716	.6344	.7373	.7373	.6859	.6344	.7716
18	.703	.6859	.7716	.7545	.6859	.703	.6859
19	.8916	.8573	.9088	.8916	.9088	.8573	.6859
20	1.166	1.1317	1.0288	1.0288	1.1145	.9945	.6859
21	1.2003	1.1317	1.0974	1.0288	1.046	.9945	
22	1.166	1.1488	1.0288	1.0288	1.0288	.9945	.9431
23	1.0802	1.1145	1.0288	.9945	1.0117	.9602	.8573
24	1.0288	1.0288	1.0288	.9945	.9431	.9259	.9088
Max	1.2003	1.989	1.1145	1.0288	1.749	.9945	.9431
Min	.703	.5316	.6001	.6344	.6516	.6344	.5316
Avg	.8996	.8888	.8773	.8559	.8795	.8180	.7692

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 203 / 11 KV BORKHEDI SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9431	.9431	1.0288	.9088	.6516	.8573
2		.9431	1.0288	.9431	.9088	.6859	.8573
3		.9431	.8573	.9259	.8916	.6859	.8573
4		.9431	.9431		.8916	.7716	.8573
5		.9431	1.0288		.8916	.7716	.8573
6		.823	.8573	.2572	.823	.7545	.8059
7		.703	.6001	.6001		.7373	.823
8		.7373	.7545	.7545	.4458	.6859	
9		.7373	.7888	.7716	.6001	.703	.4115
10	.7716	.7716	.8916	.8573	.6001	.6001	.6859
11	.8059	.6859	.8916	.7716	.5316	.703	.7716
12	.703	.7716	.8573	.7888	.6173	.703	.6859
13	.703	.6001	.9259	.7716	.6859	.6859	.6173
14	.6859	.5144	.823	.7373		.6859	.5316
15	.8573	.7202	.8916	.7545	.8573	.5144	.5487
16	.8059	.7202	.8573	.3429	.6859	.5487	.5144
17	.8573		.8573	.1715	.6859	.6001	.6001
18		.5144	.9602	.7202	.7545	.6859	.6001
19	1.0288	1.0974	.9431	.9088	.9431	.8745	.6001
20	1.2174	1.1488	1.0288	1.0288	1.046	.9774	
21	1.1488	1.1145	1.1145	1.0288	1.046	.9945	.6859
22	1.0802	1.0974	1.0288	1.0288	1.0288	.9431	.8573
23	1.0288	1.0288	1.0288	.9431	.9431	.9088	.8573
24	.9945	.9774	1.0288	.9774	.9088	.6001	.8916
Max	1.2174	1.1488	1.1145	1.0288	1.046	.9945	.8916
Min	.6859	.5144	.6001	.1715	.4458	.5144	.4115
Avg	.9063	.8469	.9138	.7778	.8043	.7280	.7170

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 205 / 11 KV AIR II

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4115	.4115	.2401	.3429	.3429	.3086
2		.4115	.4115	.2229	.3429	.3429	.3086
3		.3944	.4115	.2229	.3429	.3429	.3086
4		.3944	.4115	.2058	.3429	.3601	.3086
5		.3944	.4115	.1886	.3086	.3429	.3086
6		.4115	.4115	.0857	.3086	.2572	.3258
7		.1029	.1029	.1029	.1029	.1029	.1029
8		.1029	.1029	.1029	.1029	.1029	.1029
9		.1029	.1029	.1029	.1029	.1029	.1029
10	.1029	.1029	.1029	.1029	.1029	.1029	.1029
11	.1029	.1029	.1029	.1029	.1029	.1029	.1029
12	.1029	.1029	.1029	.1029	.1029	.1029	.1029
13	.1029	.1029	.1029	.1029	.1715	.1886	.1029
14	.1029	.1029	.1029	.0857	.1715	.1886	.1029
15	.1029	.1029	.1029	.2915	.1715	.1886	.1029
16	.1029	.1029	.1029	.2915	.1715	.1886	.1029
17	.3429	.3429	.1029	.3429	.2058	.1715	.1029
18	.3944	.4115	.2572	.3429	.3601	.3086	.1029
19	.3944	.4115	.4287	.3258	.3601	.3086	.1029
20	.3429	.4115	.4115	.3258	.3429	.3429	.1715
21	.4287	.4115	.4287	.3258	.3429	.3086	.2401
22	.4115	.4115	.4115	.2915	.3429	.3086	.3086
23	.3944	.4115	.4115	.2915	.3429	.3086	
24	.3772	.4115	.4115	.4115	.3086	.3601	.3086
Max	.4287	.4115	.4287	.4115	.3601	.3601	.3258
Min	.1029	.1029	.1029	.0857	.1029	.1029	.1029
Avg	.2538	.2779	.2651	.2172	.2458	.2408	.1841

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 206 / 11 KV W.T.PLANT FEEDER

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.4458	.4287	.4801	.463	.4801
2		.2915	.4287	.4115	.4801	.4287	.4801
3		.2915	.4115	.3772	.4801	.4287	.3944
4		.2915	.3772	.3601	.4287	.4287	.3944
5		.2915	.3944	.3772	.3944	.3772	.3944
6		.3258	.4115	.4115	.3429	.3258	.3601
7		.3086	.4115	.3258	.3258	.3258	.3429
8		.3429	.4458	.3086	.4115	.3086	.2401
9		.4458	.4801	.4287	.4458	.3086	.3086
10	.2401	.5658	.6173	.5144	.5487	.3429	.3601
11	.4115	.6001	.6173	.583	.463	.4458	.3601
12	.6173	.4287	.583	.583	.4458	.4115	.3429
13	.2572	.4287	.5658	.6173	.4287	.4115	.3086
14	.6687	.3772	.6001	.6001	.4115	.4115	.2915
15	.6859	.4115	.6859	.583	.4801	.4287	.3086
16	.6001	.4115	.6001	.583	.5487	.4115	.3086
17	.3429	.3429	.6001	.4973	.5487	.3944	.3429
18	.3258	.3429	.3258	.3429	.2915	.4458	.3429
19	.3601	.3772	.3772	.463	.3601	.4801	
20	.1029	.3944	.3772	.4973	.4801	.4801	
21	.3258	.3944	.4287	.5144	.463	.463	
22	.3258	.3772	.4458	.4801	.463	.4801	.3601
23	.3258	.3944	.463	.4801	.463	.4801	.4287
24	.2743	.3258	.463	.463	.463		.4801
Max	.6859	.6001	.6859	.6173	.5487	.4801	.4801
Min	.1029	.2915	.3258	.3086	.2915	.3086	.2401
Avg	.3909	.3779	.4815	.4680	.4437	.4123	.3633

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 208 / 11 KV RAMADAM NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1715	.3429	.3258	.3429	.3772	.3429
2		.1715	.3601	.3258	.3429	.3772	.3429
3		.1715	.3429	.3429	.3429	.3772	.3429
4		.1715	.3601	.3601	.3429	.3772	.3429
5		.1715	.3601	.3429	.3429	.3429	.3429
6		.2058	.3601	.3601	.3601	.2229	.2229
7		.2058	.3772	.3601	.3601	.2229	.2229
8		.3429	.3429	.3601	.3601	.2058	.2229
9		.3429	.3601	.3601	.3601	.2058	.2229
10	.2915		.3601	.3601	.3601	.2229	.2229
11	.2572	.3086	.3601	.3601	.3772	.3601	
12	.2401		.3772	.3772	.3601	.3601	
13	.1715		.3944	.3601	.3429	.3429	
14	.3601		.3772	.3601	.2401	.3601	
15	.1715	.3086	.3601	.2401	.3601	.2229	
16	.3601		.3601	.2401	.3772	.2229	
17	.2572	.3601	.3601	.2401	.3772	.2229	
18	.3772	.3772	.1715	.2401	.2572	.2229	
19	.2401	.3772	.1715	.3601	.3601	.3429	
20	.1715	.3772	.1715	.3601	.3772	.3429	
21	.1715	.3772	.3601	.3601	.3772	.3429	
22	.1715	.3601	.3429	.3601	.3772	.3429	.4973
23	.1715	.3772	.3601	.3601	.3772	.3429	.1715
24	.1715	.1715	.3601	.3601	.3601	.3601	.3429
Max	.3772	.3772	.3944	.3772	.3772	.3772	.4973
Min	.1715	.1715	.1715	.2401	.2401	.2058	.1715
Avg	.2389	.2816	.3372	.3365	.3515	.3051	.2954

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 401 / 33 KV BELA

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.0576	1.749	1.5432	1.749	1.9033	1.749
2		2.0576	1.8004	1.5432	1.749	1.8519	1.749
3		2.0576	1.8519	1.6461	1.749	1.8004	1.749
4		1.8519	1.8004	1.6461	1.749	1.8004	1.749
5		1.8519	1.8519	1.4918	1.6975	1.6975	1.749
6		1.8004	1.8004	1.3889	1.4403	1.5947	1.6461
7		1.2346	1.6461	1.4403	1.0288	1.286	1.286
8		1.4918	1.749	1.4918	1.2346	1.0802	1.0288
9		1.3889	1.749	1.1317	.9259	1.1317	1.0288
10	1.4403	1.1831	1.749	1.1317	1.2346	.5144	1.0288
11	1.286	.823	1.8004	1.6461	1.3375	1.1317	1.0288
12	1.1831	.8745	1.5432	1.6975	1.4403	1.2346	.7716
13	1.1831	.9259	1.6461	1.5947	1.4403	1.1317	.9774
14	1.286	.8745	1.6975	1.9033	1.4403	1.0802	.9774
15	1.1317	.6687	1.6975	1.6975	1.3889	1.1317	1.0288
16	1.286	.7202	1.8004	1.749	1.749	1.0288	1.8004
17	1.286	.7716	1.8519	1.4918	1.5432	1.0288	1.8004
18	1.1831	.6173	1.0288	1.0802	1.286	1.286	1.5432
19	1.5432	.9774	1.5947	1.5432	1.5947	1.5432	1.5432
20	1.749	1.6975	1.5432	1.6975	1.8004	1.8004	1.8004
21	1.9547	1.8004	2.7778	1.6461	2.1091	1.8004	1.8004
22	2.0576	2.1605	2.0576	1.5432	1.8519	1.8004	1.5947
23	2.0062	1.9547	1.6975	1.6461	1.749	1.8004	1.5947
24	1.9547	2.0576	1.8519	1.8004	1.6461	1.8004	1.6975
Max	2.0576	2.1605	2.7778	1.9033	2.1091	1.9033	1.8004
Min	1.1317	.6173	1.0288	1.0802	.9259	.5144	.7716
Avg	1.5020	1.4125	1.7640	1.5496	1.5389	1.4275	1.4468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164019 / 33 KV AIR Buttibori

Feeder No / Name : 402 / 33 KV VARRON AUTO NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3601	.3601	.3601	.3601	.3601	.3601
2		.3601	.3601	.3601	.3601	.3601	.3601
3		.3601	.3601	.3601	.3601	.3601	.3601
4		.3601	.3601	.3601	.3601	.3601	.3601
5		.3601	.3601	.3601	.3601	.3601	.3601
6		.3601	.3601	.3601	.3601	.3601	.3601
7		.3601	.3601	.3601	.3601	.3601	.3601
8		.3601	.3601	.3601	.3601	.3601	.3601
9		.3601	.3601	.3601	.3601	.3601	.3601
10	.3601	.3601	.3601	.3601	.3601	.3601	.3601
11	.3601	.3601	.3601	.3601	.3601	.3601	.3601
12	.3601	.3601	.3601	.3601	.3601	.3601	.3601
13	.3601	.3601	.3601	.3601	.3601	.3601	.3601
14	.3601	.3601	.3601	.3601	.3601	.3601	.3601
15	.3601	.3601	.3601	.3601	.3601	.3601	.3601
16	.3601	.3601	.3601	.3601	.3601	.3601	.3601
17	.3601	.3601	.3601	.3601	.3601	.3601	.3601
18	.3601	.3601	.3601	.3601	.3601	.3601	.3601
19	.3601	.3601	.3601	.3601	.3601	.3601	.3601
20	.3601	.3601	.3601	.3601	.3601	.3601	.3601
21	.3601	.3601	.3601	.4115	.3601	.3601	.3601
22	.3601	.3601	.3601	.3601	.3601	.3601	.3601
23	.3601	.3601	.3601	.3601	.3601	.3601	.3601
24	.3601	.3601	.3601	.3601	.3601	.3601	.3601
Max	.3601	.3601	.3601	.4115	.3601	.3601	.3601
Min	.3601	.3601	.3601	.3601	.3601	.3601	.3601
Avg	.3601	.3601	.3601	.3622	.3601	.3601	.3601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0693	.0762	.0747	.0693	.0762	.0747
2	.0747	.0648	.0762	.0747	.0716	.0762	.0747
3	.0747	.0625	.0762	.0747	.0693	.0762	.0747
4	.0747	.0625	.0762	.0747	.0693	.0762	.0747
5	.0747	.0463	.0762	.0747	.0693	.0762	.0747
6	.056	.0463	.0762	.0747	.0543	.0572	.0747
7		.0486	.0572	.056	.0537	.0572	.0747
8	.056	.052	.0572	.056	.0486	.0572	.056
9	.056	.052	.0572	.056		.0572	.056
10	.056	.052	.0572	.056		.0572	.056
11	.052	.0572	.056	.0463		.0549	.052
12	.052	.0572	.056	.0469		.0549	.052
13	.052		.056	.0469	.0572	.0549	.052
14	.052		.056	.052	.0572		.052
15	.0526	.0572	.056	.052	.0572	.0486	.052
16	.052	.0572	.056	.052	.0572	.0486	.052
17	.052	.0572	.056	.0543	.0572	.0486	.0526
18	.052	.0572	.056	.0526	.0572	.056	.0526
19	.0693	.0572	.056	.052	.0572	.056	.0486
20	.0693	.0762	.056	.0701	.0762	.0747	.056
21	.0693	.0762	.056	.0701	.0762	.0747	.052
22	.0701	.0762	.056	.0732	.0762	.0747	.052
23	.0701	.0762	.056	.0747	.0762	.0747	.056
24	.0747	.0648	.0762	.0747	.0701	.0762	.0747
Max	.0747	.0762	.0762	.0747	.0762	.0762	.0747
Min	.052	.0463	.056	.0463	.0486	.0486	.0486
Avg	.0625	.0603	.0621	.0621	.0640	.0637	.0603

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 201 / 11 KV MOHOGAON

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6516	.724	.6722	.5609	.6478	.6348
2	.6535	.6516	.724	.6348	.5975	.6097	.6161
3	.6161	.6535	.6859	.6161	.5721	.6097	.5788
4	.5788	.6348	.6668	.5975	.5792	.5716	.5601
5	.5601	.5721	.6478	.5788	.543	.5335	.5601
6	.5601	.6401	.6478	.5975	.5601	.5716	.5415
7		.6036	.6097	.6348	.5415	.5525	.5601
8	.6348	.567	.4572	.6161	.5788	.5335	.5415
9	.6535	.5548	.6859	.6161		.5335	.5788
10	.6535	.5201	.6859	.6722		.6097	.5601
11	.5316	.5335	.5975	.5959		.3898	.5375
12	.5611	.5525	.5601	.5258		.5487	.3439
13	.5028		.5601	.5375	.6859	.5304	.362
14	.5201		.5975	.4908	.6478	.4334	.3921
15	.567	.3429	.5975	.3681	.6287	.4508	.3467
16	.5487	.4001	.5975	.3467	.5716	.4294	.3921
17	.567	.4954	.5041	.4755	.5906	.4108	.3734
18	.5258	.5525	.5041	.5121	.6097	.4572	.4382
19	.5375	.6478	.6348	.5201	.6859	.5975	.4681
20	.5853	.6859	.7282	.4854	.6859	.6348	.5973
21	.7011	.7621	.7282	.5028	.724	.6535	.5975
22	.7865	.7621		.5975	.724	.6348	.5611
23	.7133	.7621	.6722	.5895	.6859	.6348	.5601
24	.7282	.695	.724	.6908	.6535	.6478	.6348
Max	.7865	.7621	.7282	.6908	.724	.6535	.6348
Min	.5028	.3429	.4572	.3467	.5415	.3898	.3439
Avg	.6077	.6019	.6322	.5614	.6213	.5511	.5140

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 202 / 11 KV CICR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0549	.0572	.056	.0347	.0572	.056
2	.056	.0549	.0572	.056	.0347	.0572	.056
3	.056	.0366	.0572	.056	.0362	.0572	.056
4	.056	.0373	.0572	.056	.0362	.0572	.056
5	.056	.0347	.0572	.0747	.0351	.0572	.056
6	.056	.0347	.0572	.0373	.0362	.0572	.056
7		.0347	.0572	.0373	.0362	.0572	.056
8	.0373	.104	.0572	.056	.056	.0572	.056
9	.056		.1143	.112		.0572	.056
10	.168	.104	.1143	.168		.0572	.056
11	.1753	.2286	.2054	.1734		.0486	.1387
12	.1907	.2477	.2427	.2149		.0543	.2427
13	.2195		.2427	.2054	.1334	.0366	.2686
14	.1867		.2054	.1928	.1524	.0354	.3292
15	.197	.2286	.2054	.1907	.1715	.0566	.2801
16	.208	.2096	.2054	.1753	.1143	.0486	.1494
17	.1829	.0953	.0747	.1387	.0572	.056	.0876
18	.0549	.0572	.056	.104	.0572	.056	.056
19	.0366	.0572	.056	.0867	.0572	.056	.052
20	.052	.0572	.056	.052	.0572	.056	.0526
21	.0347	.0572	.056	.0362	.0572	.056	.0543
22	.0251	.0572	.056	.0362	.0572	.056	.0526
23	.0366	.0572	.056	.0347	.0572	.056	.056
24	.056	.0347	.0762	.056	.0366	.0572	.056
Max	.2195	.2477	.2427	.2149	.1715	.0572	.3292
Min	.0251	.0347	.056	.0347	.0347	.0354	.052
Avg	.0980	.0897	.1033	.1003	.0657	.0542	.1015

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 203 / 11 KV KHAPRI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.2427	.2286	.1867	.2241	.2858	.2614
2	.2054	.2241	.1905	.1867	.1867	.2477	.2241
3	.2241	.1867	.1905	.2241	.2012	.2286	.2054
4	.1494	.1448	.1524	.168	.1448	.1905	.1867
5	.112	.1307	.1334	.1494	.1307	.1905	.1494
6	.0747	.0747	.0953	.1494	.112	.1143	.0747
7		.0934	.0953	.1494	.0905	.0762	.0934
8	.0934	.0867	.0953	.168	.0876	.0762	.0747
9	.0934	.0867	.1143	.168		.0762	.0747
10	.1307	.0867	.1143	.1494		.1143	.0648
11	.1387	.1524	.1494	.1387		.1097	.104
12		.1524	.168	.156		.0914	.128
13	.156		.1494	.1387	.0572	.0905	.1307
14	.1646		.0934	.1387	.0572	.1052	.1267
15	.1387	.1524	.1494	.1402	.0572	.1086	.128
16	.156	.1524	.1307	.1494	.0572	.0937	.1463
17	.1086	.1334	.1307	.1387	.0572	.112	.1052
18	.0754	.1334	.1307	.1214	.0572	.0934	.104
19	.1097	.1334	.112	.1227	.0572	.0747	.1052
20	.1052	.1334	.1494	.1402	.0572	.112	.1052
21	.1227	.1334	.0934	.1052	.0572	.0934	.1097
22	.1494	.2477	.2427	.2103	.1905	.2614	.0991
23	.2254	.1715	.1867	.2987	.1715	.2801	.1307
24	.1494	.2743	.1715	.168	.3109	.3048	.2801
Max	.2254	.2743	.2427	.2987	.3109	.3048	.2801
Min	.0747	.0747	.0934	.1052	.0572	.0747	.0648
Avg	.1395	.1512	.1445	.1611	.1183	.1471	.1338

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 204 / 11 K V JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1448	.3048	.1494	.1494	.1524	.1494
2	.1494	.1494	.3048	.1494	.1494	.1334	.1494
3	.1494	.1494	.3048	.1494	.1494	.1334	.2614
4	.1307	.1214	.2668	.1494	.1494	.1334	.1307
5	.1494	.1307	.2668	.1494	.1448	.1334	.1307
6	.1494	.1214	.2668	.1494	.1267	.1334	.1307
7		.1294	.3048	.1307	.1307	.1334	.1307
8	.1494	.104	.1334	.1494	.1307	.1524	.1307
9	.1494	.104	.1334	.1307		.1524	.1307
10	.1494	.0581	.1334	.168		.3048	.1307
11	.1387	.3048	.336	.1296		.1463	.1402
12	.1387	.381	.1494	.1494		.1463	.1387
13	.1387		.1494	.1448	.2668	.1448	.1448
14	.1387		.1494	.1402	.2668	.1307	.1494
15	.1387	.1524	.1494	.1463	.3048	.1214	
16	.1698	.1524	.1494	.1463	.3048	.1307	.1448
17	.1214	.1524	.1494	.1448	.1524	.1134	.1448
18	.1463	.1334	.1494	.1448		.1307	.156
19	.1646	.1334	.1494	.156	.1524	.1494	.1387
20	.156	.1334	.1494	.1578	.1524	.1494	.1402
21	.1646	.1524	.168	.168	.1524	.1494	.1448
22	.1646	.1524	.1494	.1578	.1524	.1494	.1296
23	.1646	.1524	.1506	.1646	.3048	.1494	.1387
24	.1837	.1829	.1524	.1494	.1646	.1524	.1494
Max	.1837	.381	.336	.168	.3048	.3048	.2614
Min	.1214	.0581	.1334	.1296	.1267	.1134	.1296
Avg	.1502	.1544	.1967	.1490	.1845	.1469	.1450

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 205 / 11 Kv MJP W/W

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0187	
2	.0187		.0187	
3	.0187		.0187	
4	.0187		.0187	
5	.0181		.0187	
6	.0187		.0187	
7			.0187	
8	.0187		.0187	
9	.0187		.0187	
10	.0187	.0187	.0187	
11		.0187		.0156
12		.0187		
13		.0187		
14		.0187		
15		.0187		
16		.0187		
17		.0187		
18		.0187		
19		.0187		
20		.0187		
21		.0187		
22		.0187		
23		.0187		
24	.0187		.0187	
Max	.0187	.0187	.0187	.0156
Min	.0181	.0187	.0187	.0156
Avg	.0186	.0187	.0187	.0156

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 401 / 33 KV INCOMMER

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	1.0082	.8322		1.0642	1.1317	.8002	.8402
16	1.1523		1.1763	.9619		.7356	.9054
24	1.1763	1.3169	1.2003	1.1203	1.2449	1.2003	1.1763
Max	1.1763	1.3169	1.2003	1.1203	1.2449	1.2003	1.1763
Min	1.0082	.8322	1.1763	.9619	1.1317	.7356	.8402
Avg	1.1123	1.0746	1.1883	1.0488	1.1883	.9120	.9740

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 402 / 33 KV TRANSFORMER NO-I

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9522						
8	.7842	.7356	.5716	.8402	.7356	.6287	.6722
16	.9619		.9522	.7356		.5658	.679
24	1.1763	1.0425	.9717	.8962	1.0185	.9717	.9522
Max	1.1763	1.0425	.9717	.8962	1.0185	.9717	.9522
Min	.7842	.7356	.5716	.7356	.7356	.5658	.6722
Avg	.9687	.8891	.8318	.824	.8771	.7221	.7678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164020 / 33 KV S/STN. KHAPRI

Feeder No / Name : 403 / 33 KV TRANSFORMER NO-II

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.2241	.1698	.1715	.2241	.1578	.1715	.168
16	.2195		.2241	.2195		.1698	.2263
24	.2241	.2743	.2286	.2241	.2241	.2286	.2241
Max	.2241	.2743	.2286	.2241	.2241	.2286	.2263
Min	.2195	.1698	.1715	.2195	.1578	.1698	.168
Avg	.2226	.2221	.2081	.2226	.1910	.1900	.2061

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 200 / 11 KV S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0572	.0381	.0381	.0381	.0572
2	.0572	.0381	.0572	.0572	.0381	.0381	.0572
3	.0572	.0381	.0381	.0381	.0381	.0381	.0572
4	.0572	.0381	.0381	.0381	.0381	.0381	.0572
5	.0572	.0381	.0381	.0381	.0381	.0381	.0572
6	.0381	.0381	.0381	.0381	.0381	.0381	.0381
7	.0381	.0381	.0381	.0381	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	.0381	.0381	.0572
9	.0381	.0572	.0381	.0572	.0381	.0381	.0381
10	.0381	.0381	.0381	.0191	.0381	.0381	.0381
11	.0381	.0381	.0191	.0381	.0381	.0381	.0381
12	.0381	.0381	.0191	.0381	.0381	.0381	.0381
13	.0381	.0381	.0191	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0191
15	.0381	.0381	.0381	.0381	.0381	.0381	.0191
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0191
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19		.0572	.0381	.0381	.0381	.0572	.0572
20	.0381	.0572	.0572	.0572	.0381	.0572	.0572
21	.0572	.0572	.0572	.0572	.0381	.0572	.0572
22	.0381	.0572	.0572	.0572	.0381	.0572	.0572
23	.0572		.0572	.0572	.0381	.0572	.0572
24	.0381	.0572	.0572	.0572	.0572	.0381	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0381	.0381	.0191	.0191	.0381	.0381	.0191
Avg	.0431	.0431	.0413	.0429	.0389	.0421	.0453

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 201 / CIDCO Fdr SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2858	.1905	.1905	.1905	.381
2	.1905	.1905	.2477	.1905	.1905	.1905	.381
3	.1905	.1905	.2477	.1905	.1905	.1905	.2858
4	.1905	.1905	.2286	.1905	.1905	.1905	.2858
5	.1905	.1905	.2096	.1905	.1905	.1905	.2858
6	.1905	.1905	.1905	.1905	.0953	.0953	.1905
7	.1905	.1905	.1905	.1905	.0953	.0953	.1905
8	.1905	.1905	.1905	.1905	.0953	.0953	.1905
9	.1524	.1905	.1905	.1524	.0953	.0953	.1905
10	.0953	.1905	.1905	.1334	.0953	.0953	.1905
11	.1905	.1905	.1524	.0953	.0953	.1524	.0953
12	.0953	.1905	.0953	.1524	.0953	.1905	.0953
13	.0953	.1905	.1524	.0953	.0953	.1905	.1334
14	.0953	.1905	.1143	.0953	.0953	.1905	.0953
15	.0953	.1905	.0953	.1143	.0953	.1905	.0953
16	.0953	.1905	.0953	.0953	.0953	.1905	.0953
17	.0953	.2286	.0953	.0953	.0953	.1905	.1143
18	.1905	.1905	.0953	.0953	.0953	.1905	.0953
19		.1905	.1905	.0953	.1905	.1905	.1905
20	.1905	.2858	.1905	.1905	.1905	.2858	.1905
21	.1905	.2858	.1905	.1905	.1905	.2858	.1905
22	.1905	.2858	.1905	.1905	.1905	.381	.1905
23	.1905	.3048	.1905	.1905	.1905	.381	.1905
24	.1905	.1905	.2858	.1905	.1905	.1905	.381
Max	.1905	.3048	.2858	.1905	.1905	.381	.381
Min	.0953	.1905	.0953	.0953	.0953	.0953	.0953
Avg	.1599	.2088	.1794	.1540	.1389	.1929	.1969

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 202 / MIDC Fdr SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716	.5716	.7049	.5716	.5716	.5716	.5716
2	.5335	.1905	.6859	.5716	.4763	.4763	.5716
3	.4763	.5716	.6668	.4763	.4763	.4763	.4763
4	.4763	.5716	.6097	.381	.4763	.381	.4763
5	.381	.4763	.5716	.381	.4763	.381	.4763
6	.381	.381	.4382	.381	.381	.381	.381
7	.381	.381	.381	.381	.381	.381	.381
8	.381	.381	.381	.381	.381	.1905	.2858
9	.381	.381	.381	.381	.381	.1905	.1905
10	.381	.4382	.381	.381	.381	.381	.1905
11	.381	.381	.381	.381	.381	.2858	.381
12	.5716	.5716	.5716	.381	.381	.2858	.381
13	.5716	.6097	.5716	.381	.381	.2286	.381
14	.5716	.5906	.5716	.381	.381	.1905	.2858
15	.5144	.5716	.4763	.381	.381	.1905	.1905
16	.381	.5716	.5716	.381	.381	.1905	.1905
17	.381	.4763	.381	.381	.381	.1905	.1905
18	.381	.381	.381	.381	.381	.1905	.381
19		.6287	.381	.5716	.381	.381	.381
20	.5716	.6287	.5716	.5716	.5716	.4763	.381
21	.5716	.6097	.5716	.5716	.5716	.4763	.381
22	.7621	.7811	.5716	.5716	.5716	.5716	.381
23	.5716	.8573	.7621	.5716	.5716	.5716	.381
24	.5716	.5716	.7621	.5716	.5716	.5716	.5716
Max	.7621	.8573	.7621	.5716	.5716	.5716	.5716
Min	.381	.1905	.381	.381	.381	.1905	.1905
Avg	.4846	.5239	.5303	.4485	.4445	.3588	.3691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 203 / Satgaon Fdr

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743		.8192	.7621		.743
2	.724		.7621	.743		.724
3	.724		.7049	.7049		.6668
4	.724		.724	.6859		.6668
5	.724		.6668	.6478		.6478
6	.0572		.724	.6287		.5716
7	.5716		.6097	.5906		.4382
8	.5335		.5716	.5525		.4382
9	.5144		.5716	.4572		.4001
10	.4763		.4382	.4572		.4954
11		.4763	.4763		.4572	.4763
12			.4191		.4382	.4572
13		.4191	.4382		.4191	.4954
14		.4572	.4382		.4001	.381
15		.5144	.4763		.4382	.3429
16		.4763	.4763		.4001	.362
17		.5144	.5144		.4382	.4001
18		.4954	.5335		.4382	.4763
19		.7049	.6097			.5716
20		.8002	.7811		.7049	.6478
21		.8954	.8573		.8002	.6859
22		.9526	.8573		.8573	.6668
23		.924	.8192		.7621	.6478
24	.8478		.8192	.7811		.7621
Max	.8478	.9526	.8573	.7811	.8573	.7621
Min	.0572	.4191	.4191	.4572	.4001	.3429
Avg	.6036	.6359	.6295	.6374	.5462	.5485

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD**Feederwise Load Information for All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 205 / 11 KV INCOMMER
Feeder KV- 11 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	2.0386
Max	2.0386
Min	2.0386
Avg	2.0386

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164040 / Satgaon S/Stn

Feeder No / Name : 401 / 33 KV INCOMMER
Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 201 / 11 KV Dongargaon feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4668	.4755	.4938	.4755	.4755	.4251	.439
2	.4207	.4755	.4805	.4755	.4755	.3982	.439
3	.4207	.462	.4668	.4755	.4755	.3841	.4207
4	.4207	.462	.462	.4755	.4755	.3881	.4024
5	.439	.4435	.439	.4572	.4755	.3734	.3841
6	.439	.4481	.4854	.439	.4755	.3734	.3658
7	.439	.4481	.4938	.4525	.4572	.3734	.3658
8	.439	.5228	.439	.4755	.5121	.4066	.3658
9	.3841	.4481	.4668	.4344	.5068	.3881	.3475
10	.4024	.4854	.5121	.4706	.4481	.3696	.3292
11	.4207	.5359	.4668	.5175	.4481	.3841	.3292
12	.4527	.439	.4572	.4835	.4572	.3292	.3292
13	.4294	.4755	.4207	.4706	.3511	.3841	.3403
14	.4481	.439	.4572	.4435	.3696	.2926	.3475
15	.4435	.4938	.5487	.4119	.3696	.3292	.3142
16	.4668	.4854	.5853	.4066	.3696	.2926	.3292
17	.4572	.4207	.4572	.394	.4481	.3109	.3109
18	.439	.462	.4755	.4024	.4108	.3292	.3696
19	.4481	.4755	.5121	.4938	.4805	.4755	.4525
20	.5975	.543	.5487	.5316	.5544	.4938	.462
21	.543	.543	.5121	.5487	.4854	.4755	.4435
22	.5601	.5487	.4961	.5249	.4572	.4572	.4163
23	.5415	.5228	.5121	.5121	.4435	.439	.4066
24	.4572	.5041	.4887	.4938	.4938	.4481	.4572
Max	.5975	.5487	.5853	.5487	.5544	.4938	.462
Min	.3841	.4207	.4207	.394	.3511	.2926	.3109
Avg	.4573	.4816	.4866	.4694	.4548	.3884	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 202 / 11 KV Dhuti feeder

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2172	.1829	.2195	.2195	.2012	.1949
2	.2012	.1991	.1848	.2195	.2172	.1848	.2012
3	.2012	.1991	.168	.2195	.2172	.1829	.1949
4	.2012	.1829	.168	.2195	.2195	.1629	.2012
5	.1829	.1848	.1848	.2012	.2195	.1629	.2012
6	.1097	.2218	.2012	.2012	.2012	.1478	.1829
7	.1646	.168	.1848	.2012	.2012	.1478	.1829
8	.1463	.1463	.1663	.1646	.1646	.1463	.1646
9	.1097	.1294	.1629	.1448	.1463	.1294	.1463
10	.0924	.1097	.1097	.1086	.1448	.1097	.128
11	.0924	.112	.1097	.1097	.1097	.1097	.128
12	.0905	.0924	.128	.0914	.1294	.1097	.1109
13	.1097	.0924	.1097	.0905	.1086	.1097	.1086
14	.1097	.0549	.128	.0924	.128	.1097	.0716
15	.1097	.1307	.128	.0924	.1097	.0914	.0732
16	.0924	.128	.128	.112	.1097	.0732	.0724
17	.0924	.112	.0914	.0895	.1029	.0732	.1086
18	.1109	.112	.1267	.0914	.1294	.0914	.1478
19	.1478	.1294	.181	.1646	.2033	.2012	.1646
20	.2241	.2012	.1829	.2012	.2033	.2012	.181
21	.2402	.2507	.2378	.2378	.2218	.2012	.197
22	.2587	.2328	.2561	.2172	.2378	.2012	.2012
23	.2218	.2241	.2195	.2378	.2427	.2012	.1848
24	.2012	.2218	.2033	.2241	.2195	.6878	.2012
Max	.2587	.2507	.2561	.2378	.2427	.6878	.2012
Min	.0905	.0549	.0914	.0895	.1029	.0732	.0716
Avg	.1547	.1605	.1643	.1647	.1753	.1682	.1562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 203 / 11 kv Swapnil Agro NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5087	.6539	.3511	.3841	.5868	.6401
2	.5121	.5365	.6464	.4755	.4207	.57	.6584
3	.4938	.5407	.6299	.4755	.4887	.5533	.6767
4	.2378	.5636	.6299	.5121	.5487	.5087	.695
5	.2195	.5596	.5868	.567	.6036	.4641	.695
6	.1463	.5765	.503	.6036	.6556	.4748	.7133
7	.1463	.5658	.0343	.6036	.7133	.4024	.7133
8	.0732	.0671	.0838	.128	.0366	.0671	.0549
9	.0914	.064	.0686	.0732	.0543	.0678	.0914
10	.1017	.0486	.1097	.0905	.0554	.1029	.0914
11	.1187	.017	.0709	.1109	.0724	.0686	.0671
12	.0848	.0678	.0366	.1097	.0739	.1097	.0671
13	.12	.0848	.0905	.112	.0857	.0914	.0671
14	.104	.1543	.0732	.0924	.1029	.0549	.0503
15	.1267	.0351	.0732	.0905	.1357	.0366	.0838
16	.0857	.0663	.0549	.0895	.0995	.0914	.0838
17	.0867	.0995	.128	.1075	.104	.0732	.1006
18	.0848	.0732	.0914	.0914	.1187	.1097	.0905
19	.0848	.0857	.0914	.0549	.1187	.0732	.0671
20	.1017	.0924	.1646	.0549	.1029	.0549	.0671
21	.1214	.5487	.7133	.0905	.6706	.5487	.57
22	.1017	.6687	.1294	.3475	.5197	.6036	.5365
23	.1017	.6783	.2743	.128	.6613	.6401	.6706
24	.5121	.1187	.6783	.5487	.1097	.6371	.6036
Max	.5121	.6783	.7133	.6036	.7133	.6401	.7133
Min	.0732	.017	.0343	.0549	.0366	.0366	.0503
Avg	.1820	.2842	.2757	.2462	.2890	.2913	.3398

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 205 / Mohagaon (Gaothan)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0924	.0924	.1063	.0914	.1509	.0914
2	.0914	.0934	.0914	.1097	.0914	.132	.0732
3	.0905	.0747	.0739	.1097	.0886	.132	.0732
4	.0905	.0747	.0747	.1063	.0914	.112	.0732
5	.0914	.112	.0934	.1097	.0914	.0934	.0914
6	.1097	.1463	.112	.1097	.1097	.0943	.1097
7	.0914	.0739	.1478	.0914	.0732	.0739	.1097
8	.1097	.1612	.1214	.0914	.1097	.104	.0914
9	.128	.1663	.1509	.1086	.1097	.1307	.0732
10	.112	.1509	.1646	.1463	.1867	.1294	.0732
11	.0934	.1294	.1417	.1494	.1478	.1214	.1086
12	.1478	.128	.2012	.1109	.1494	.1646	.0754
13	.0867	.1307	.0914	.1109	.0943	.1097	.0572
14	.1478	.1307	.0914	.1075	.1109	.1097	.0377
15	.1663	.1663	.1097	.1109	.1109	.1097	.1132
16	.132	.1886	.0549	.128	.0914	.1097	.0754
17	.1307	.1109	.0914	.1254	.1463	.128	.0754
18	.0739	.1494	.0716	.128	.0924	.128	.1132
19	.112	.1478	.1086	.1097	.1109	.0914	.1132
20	.1307	.1307	.1097	.1097	.0943	.0914	.1143
21	.0924	.128	.1478	.1086	.1886	.0914	.1132
22	.1294	.1097	.1097	.1097	.1132	.0914	.1132
23	.0924	.112	.128	.1097	.0934	.0914	.1132
24	.1097	.0924	.0924	.1097	.0914	.1334	.1097
Max	.1663	.1886	.2012	.1494	.1886	.1646	.1143
Min	.0739	.0739	.0549	.0914	.0732	.0739	.0377
Avg	.1105	.1250	.1113	.1132	.1116	.1135	.0914

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 400 / 33 KV PANJARI(INCOMMER)

Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4344	.4435	.4938	.4108	.4024	.4854	.4572
2	.4207	.462	.4938	.439	.4207	.4481	.4572
3	.4207	.4481	.4668	.439	.439	.4481	.4572
4	.3292	.4481	.4668	.4572	.4572	.4066	.4572
5	.3292	.4435	.462	.4572	.4755	.3841	.4572
6	.3109	.4805	.4435	.4572	.4755	.3506	.4572
7	.2896	.4251	.2987	.0183	.4755	.3361	.4572
8	.2561	.2957	.2801	.2926	.2743	.2402	.2378
9	.2378	.2743	.2743	.2772	.5544	.2378	.2195
10	.2402	.2587	.2926	.2957	.5486	.2427	.2195
11	.2427	.2587	.2561	.2957	.2587	.2353	.2218
12	.2641	.2402	.2743	.2743	.2801	.2561	.2033
13	.2561	.2587	.2378	.2957		.2378	.2033
14	.2801	.2587	.2561	.2686		.2012	.1663
15	.2801	.2772	.3109	.2614		.2012	.1991
16	.2587	.2987	.3109	.2587	.2241	.2012	.1867
17	.2587	.2587	.2743	.2587	.2743	.2012	.1991
18	.2402	.2587	.2743	.2378	.2587	.2378	.2378
19	.2614	.2801	.3077	.2926	.3142	.2743	.2743
20	.3511	.3224	.3475	.3174	.3109	.2926	.2743
21	.3292	.5121	.5487	.3475	.5415	.439	.462
22	.3475	.5249	.3475	.4207	.462	.4938	.439
23	.3292	.5359	.4207	.3292	.7784	.4755	.4755
24	.439	.3142	.5121	.4572	.3109	.499	.4755
Max	.439	.5359	.5487	.4572	.7784	.499	.4755
Min	.2378	.2402	.2378	.0183	.2241	.2012	.1663
Avg	.3086	.3574	.3605	.3275	.4065	.3261	.3290

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164041 / 33 KV Dongargaon S/S

Feeder No / Name : 402 / 33 KV VRINDAVAN S/S
Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0572	.0572	.0549	.0549	.0572	.0549
2	.0549	.0572	.0572	.0549	.0549	.0572	.0549
3	.0549	.0572	.0572	.0549	.0549	.0572	.0549
4	.0549	.0572	.0572	.0549	.0549	.0572	.0549
5	.0549	.0572	.0572	.0549	.0549	.0572	.0549
6	.0549	.0572	.0572	.0549	.0549	.0572	.0549
7	.0549	.0572	.0572	.056	.0549	.0572	.0549
8	.0543	.0572	.0572	.0543	.056	.0572	.0549
9	.0549	.0572	.0572	.056	.0549	.0572	
10	.0572	.0572	.0549	.056	.0572	.0572	.0549
11	.0572	.0572	.0549		.0572	.0549	.0572
12	.0572	.0572	.056		.0572	.0549	.0572
13	.0572	.0572	.0549		.0572	.0549	.0572
14	.0572	.0572	.0549		.0572	.0549	.0572
15	.0572	.0572	.0543		.0572	.0549	.0572
16	.0572	.0572	.0549		.0572	.0549	.0572
17	.0572	.0572	.0543		.0572	.0549	.0572
18	.0572	.0572	.0549	.0549	.0572	.0549	.0572
19	.0572	.0572	.0549	.0549	.0572	.0549	.0572
20	.0572	.0572	.0532	.056	.0572	.0549	.0572
21	.0572	.0572	.056	.0549	.0572	.0549	.0572
22	.0572	.0572	.0537	.0543	.0572	.0549	.0572
23	.0572	.0572	.0549	.0549	.0572	.0549	.0572
24	.0543	.0572	.0572	.056	.0549	.0572	.0549
Max	.0572	.0572	.0572	.056	.0572	.0572	.0572
Min	.0543	.0572	.0532	.0543	.0549	.0549	.0549
Avg	.0562	.0572	.0558	.0552	.0563	.0560	.0562

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 200 / MIHAN STATION T/F
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0171	.0187	.0179	.0175	.0173	.0183
2	.0181	.0171	.0183	.0179	.0175	.0171	.0183
3	.0179	.0171	.0183	.0179	.0175	.0171	.0183
4	.0179	.0171	.0183	.0179	.0175	.0171	.0183
5	.0181	.0171		.0179	.0175	.0171	.0183
6	.0179	.0171	.0183	.0179	.0175	.0171	.0183
7	.0179	.0171	.0183	.0179	.0175	.0171	.0183
8	.0179	.0171	.0183	.0179	.0175	.0171	.0183
9	.0179	.0171	.0183	.0179	.0175	.0171	.0183
10	.0179	.0183	.0179	.0179	.0175	.0183	.0179
11	.0171	.0183	.0179	.0175	.0171	.0183	.0179
12	.0171	.0183	.0179	.0175	.0171	.0183	.0179
13	1.3969	.0183	.0179	.0175		.0183	.0179
14	.0171	.0183	.0179	.0175		.0183	.0179
15	.0171	.0183	.0179	.0175	.0171	.0183	.0179
16	.0171	.0183	.0179	.0175	.0171	.0183	.0179
17	.0173	.0183	.0179	.0175	.0171	.0183	.0179
18	.0171	.0183	.0179	.0175	.0171	.0183	.0179
19	.0171	.0183	.0179	.0175	.0171	.0183	.0179
20	.0175	.0183	.0179	.0175	.0171	.0183	.0179
21	.0171	.0183	.0179	.0175	.0173	.0183	.0179
22	.0175	.0183	.0179	.0175	.0179	.0183	.0179
23	.0171	.0183	.0179	.0175	.0173	.0175	.0179
24	.0179	.0175	.0183	.0179	.0175	.0173	.0183
Max	1.3969	.0183	.0187	.0179	.0179	.0183	.0183
Min	.0171	.0171	.0179	.0175	.0171	.0171	.0179
Avg	.0750	.0178	.0181	.0177	.0174	.0178	.0181

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 201 / Mihan-I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.1088	1.0974	1.0974	1.086	1.307	1.0059
2	1.0974	1.1088	1.0974	1.0608	1.0498	1.2136	1.0059
3	1.0608	1.1088	1.0608	1.0974	1.0498	1.1888	.9145
4	1.0059	1.0719	1.0059	1.0059	1.0829	1.1203	.9145
5	.9145	1.0719	.9145	1.0059	1.0829	.9145	.9145
6	.9145	.924	.823	.9145	.9335	.924	.7316
7	1.134	1.0534	1.0059	1.0059	1.0829	.7316	.9145
8	.3658	1.1458	1.0974	1.0608	1.086	.7392	1.0608
9	.3658	1.2936	1.307	1.134	1.1584	.7682	1.2803
10	.3658	1.2803	1.3717	1.3169	1.3032	.9145	1.2803
11	.2772	1.3717	1.3717	1.448	1.4632	.9145	1.3169
12	1.2936	1.3717	1.4266	1.4842	1.3306	.8413	1.1888
13	1.4415	1.3717	1.3717	1.267		.9145	1.0974
14	1.386	1.134	1.4266	1.448		.9145	1.0608
15	1.3306	1.3717	1.4632	1.448	.3326	.8413	1.1888
16	1.2936	1.3717	1.4998	1.3394	.2772	.9145	1.2803
17	1.2936	1.2803	1.2803	1.3575	1.2012	.9511	
18	1.3306	1.2803	1.2437	1.4118	1.2936	.9877	1.2803
19	1.4784	1.5546	1.5546	1.6632	1.4784	1.1706	1.4998
20	1.5708	1.5546	1.4998	1.4784	1.531	1.2803	1.4632
21	1.4784	1.4632	1.4266	1.5203		1.2071	1.3717
22	1.4784	1.4632	1.3169	1.448	1.4632	1.1706	1.0974
23	1.307	1.2803	1.1888	1.2308	1.4003	1.086	1.0059
24	1.0974	1.2696	1.1888	1.134	1.1584	1.363	1.0136
Max	1.5708	1.5546	1.5546	1.6632	1.531	1.363	1.4998
Min	.2772	.924	.823	.9145	.2772	.7316	.7316
Avg	1.0991	1.2627	1.2517	1.2658	1.1355	1.0158	1.1256

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 202 / Mihan-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	.0366	.0366	.0362	.0351	.0366	.0366
2	.0362	.0366	.0366	.0362	.0351	.0366	.0366
3	.0362	.0366	.0366	.0362	.0351	.0366	.0366
4	.0362	.0366	.0366	.0362	.0373	.0366	.0366
5	.0362	.0366	.0366	.0362	.0373	.0366	.0366
6	.0362	.0362	.0366	.0362	.0373	.0366	.0366
7	.0362	.0366	.0362	.0362	.0373	.0366	.0366
8	.0362	.0366	.0366	.0362	.0351	.0366	.0366
9	.0362	.0366	.037	.0362	.0351	.0366	.0549
10	.0366	.0366	.0362	.0362	.0351	.0366	.0362
11	.0366	.0366	.0362	.0351	.0366	.0366	.0362
12	.0366	.0366	.0362	.0351	.0366	.0366	.0362
13	.0366	.0366	.0362	.0351		.0366	.0362
14	.0366	.0366	.0362	.0351		.0366	.0362
15	.0366	.0366	.0362	.0351	.0366	.0366	.0362
16	.0366	.0366	.0362	.0351	.0366	.0366	.0366
17	.0366	.0366	.0362	.0351	.0366	.0366	.0362
18	.0366	.0366	.0362	.0351	.0366	.0366	.0362
19	.0366	.0366	.0362	.037	.0366	.0366	.0366
20	.0366	.0366	.0362	.0373	.0366	.0366	.0366
21	.0366	.0366	.0362	.0351	.0366	.0366	.0362
22	.0366	.0366	.0362	.0351	.0366	.0366	.0362
23	.0366	.0366	.0362	.0351	.0366	.0351	.0362
24	.0366	.0366	.0366	.0362	.0351	.0366	.0351
Max	.0366	.0366	.037	.0373	.0373	.0366	.0549
Min	.0362	.0362	.0362	.0351	.0351	.0351	.0351
Avg	.0365	.0366	.0364	.0358	.0363	.0365	.0371

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 203 / Mihan-III SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.3169	1.2803	1.3169	1.2803	1.2803	1.1888
2	1.2437	1.2803	1.2437	1.2803	1.2269	1.2803	1.1888
3	1.1888	1.2437	1.1888	1.2437	1.2803	1.1888	1.0974
4	1.134	1.2803	1.1888	1.1888	1.2696	1.0974	1.0974
5	1.2437	1.2437	1.2437	1.1888	1.2696	1.1088	1.0974
6	1.1888	1.2936	1.1765	1.1888	1.307	1.1088	1.0974
7	1.2437	1.2437	1.2803	1.2437	1.2936	1.0974	1.134
8	1.3169	1.2071	1.2803	1.2803	1.2803	1.134	1.2803
9	1.2803	1.1283	1.2936	1.1888	1.2437	1.0974	1.2803
10	1.2803	1.0974	1.2803	1.1888	1.2071	1.1888	1.2803
11	1.2803	1.0974	1.2437	1.2437	1.2803	1.2803	1.2437
12		1.0974	1.1888	1.1706	1.2308	1.1706	1.0974
13	1.1888	1.0608	1.134	1.0974		1.0974	.9511
14	1.2803	1.0059	1.2437	1.0974		1.1706	.9145
15	1.2803	1.0608	1.1888	1.134	1.4632	1.0974	.9145
16	1.267	1.0974	1.134	1.1888	1.267	1.0974	1.0059
17	1.267	1.1888	1.2437	1.0985	1.267	1.0974	1.0059
18	1.2308	1.0974	1.1888	1.2437	1.2803	1.2071	1.0974
19	1.2803	1.2071	1.3717	1.4563	1.4632	1.2803	1.1888
20	1.5708	1.4632	1.4266	1.4784	1.5181	1.4266	1.2437
21	2.3101	1.3717	1.4632	1.5364	1.4632	1.4632	1.1888
22	1.587	1.4632	1.4266	1.5364	1.4632	1.2896	1.2437
23	1.4998	1.4632	1.4266	1.4632	1.4632	1.2803	1.134
24	1.4026	1.386	1.3717	1.3717	1.4266	1.3717	1.1888
Max	2.3101	1.4632	1.4632	1.5364	1.5181	1.4632	1.2803
Min	1.134	1.0059	1.134	1.0974	1.2071	1.0974	.9145
Avg	1.3411	1.2248	1.2712	1.2677	1.3293	1.2047	1.1317

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 204 / 11 KV INCOMMER-I
Feeder KV- 11 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	1.2197
Max	1.2197
Min	1.2197
Avg	1.2197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 205 / Mahindra Boomdale

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	.0549	.0549	.0537	.0526	.0549	.0549
2	.0532	.0549	.0549	.0532	.0526	.0549	.0549
3	.0537	.0549	.0549	.0537	.0526	.0549	.0549
4	.0532	.0549	.0549	.0532	.0175	.0549	.0549
5	.0532	.0549	.0543	.0532	.0554	.0549	.0549
6	.0532	.0549	.0549	.0532	.056	.0366	.0549
7	.0532	.0549	.0549	.0532	.056	.0549	.0549
8	.0532	.0549	.0549	.0532	.0526	.0549	.0549
9	.0532	.0549	.056	.0532	.0526	.0549	
10	.0554	.0549	.0537	.0532	.0526	.0549	.0532
11	.0549	.0549	.0532	.0526	.0549	.0549	.0532
12	.0549	.0549	.0532	.0175	.0549	.0366	.0532
13	.0549	.0549	.0532	.0532		.0366	.0532
14	.0549	.055	.0532	.0526		.0549	.0532
15	.0549	.0549	.0537	.0526	.0549	.0549	.0532
16	.0543	.0549	.0537	.0526	.0549	.0549	.0549
17	.0549	.0549	.0532	.0526	.0549	.0549	.0532
18	.0549	.0549	.0532	.0526	.0549	.0549	.0549
19	.0549	.0549	.0532	.0554	.0549	.0549	.0554
20	.0549	.0549	.0537	.0526	.0549	.0549	.0549
21	.0549	.0549	.0532	.0526	.0549	.055	.0532
22	.0549	.0549	.0532	.0526	.0554	.0549	.0537
23	.0549	.0549	.0532	.0526	.0549	.0526	.0532
24	.0554	.0549	.0549	.0532	.0526	.0549	.0549
Max	.0554	.055	.056	.0554	.056	.055	.0554
Min	.0532	.0549	.0532	.0175	.0175	.0366	.0532
Avg	.0543	.0549	.0540	.0516	.0526	.0525	.0542

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 206 / 11 KV INCOMMER-II
Feeder KV- 11 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	1.3169
Max	1.3169
Min	1.3169
Avg	1.3169

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 401 / 33 KV INCOMMER-I
Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	1.2197
Max	1.2197
Min	1.2197
Avg	1.2197

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164052 / Mihan S/St'n

Feeder No / Name : 402 / 33 KV INCOMMER-II
Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	1.3306
Max	1.3306
Min	1.3306
Avg	1.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 200 / S/STN TRANSFORMER
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.3841	.3881	.3841	.3841	.3881	.3841
2	.439	.3841	.3921	.3841	.3841	.3921	.3841
3	.439	.3841	.3841	.3841	.3841	.3841	.3841
4	.439	.3841	.3841	.3841	.3841	.3841	.3841
5	.3841	.3881	.3841	.3292	.3841	.3841	.3841
6	.439	.2743	.3841	.2743	.3841	.3841	.3841
7	.3841	.2772	.2743	.2743	.2743	.2743	.2743
8	.3841	.2743	.2743	.2743	.2743	.2743	.2743
9	.3841	.2743	.2743	.2743	.2743	.2743	.2743
10	.2743	.2772	.2743	.2743	.2743	.2772	.2743
11	.2743	.2743	.2743	.2743	.2772	.2743	.2743
12	.2772	.2743	.2743	.2743	.2743	.2743	.2743
13	.2743	.2743	.2743	.2743	.2772	.2743	.2743
14	.2743	.2772	.2743	.2743	.2743	.2743	.2743
15	.2772	.2743	.2743	.2743	.2743	.2743	.2772
16	.2743	.2743	.2743	.2743	.2772	.2743	.2772
17	.2743	.2743	.2743	.2743	.2772	.2743	.2772
18	.2743	.2743	.2743	.2743	.2772	.2743	.2772
19	.2772	.2743	.3841	.2743	.3881	.2743	.3881
20	.3881	.3841		.3841	.3881	.3841	.3881
21	.3881	.3841	.3841	.3841	.3881	.3841	.3881
22	.3841	.3841	.3841	.3841	.3881	.3841	.3881
23	.3841	.3881	.3841	.3841	.3881	.3841	.3881
24	.3841	.3881	.3881	.3841	.3841	.3921	.3841
Max	.439	.3881	.3921	.3841	.3881	.3921	.3881
Min	.2743	.2743	.2743	.2743	.2743	.2743	.2743
Avg	.3482	.3209	.3275	.3178	.3306	.3256	.3305

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 201 / SANDESH CITY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0366	.037	.0366	.0366	.037	.0366
2	.0366	.037	.0373	.0366	.0366	.0373	.0366
3		.0366	.0366	.0183	.0366	.0366	.0183
4	.0366	.0366	.0366		.0366	.0366	.0183
5	.0183	.0183	.0183	.0366	.0366	.128	.0183
6	.0183	.0183	.0183	.0366	.0183	.0183	.0183
7	.0183	.0185	.0183	.0183	.0183	.0183	.0183
8	.0183	.0183	.0183	.0183	.0183	.0183	.0183
9	.0366	.0183	.0366	.0183	.0183	.0183	.0183
10	.0549	.0366	.0366	.0366	.0366	.0554	.0366
11	.0366	.0183	.0366	.0366	.0185	.0366	.0183
12	.0185	.0183	.0366	.0183	.0183	.0366	.0183
13	.0183	.0183	.0366	.0183	.0185	.0183	.0183
14	.0183	.0185	.0366	.0366	.0183	.0366	.0183
15	.0185	.0366	.0366	.0183	.0183	.0366	.0185
16	.0185	.0183	.0183	.0183	.0185	.0366	.0185
17	.0183	.0183	.0366	.0183	.0185	.0366	.0185
18	.0183	.0183	.0366	.0183	.0185	.0183	.0185
19	.037	.0183	.0366	.0183	.037	.0366	.037
20	.0366	.0366	.0366	.0366	.037	.0366	.037
21	.037	.0366	.0366	.0366	.037	.0366	.037
22	.0366	.0366	.0366	.0366	.037	.0366	.037
23	.0366	.0373	.0366	.0366	.037	.0366	.037
24	.0366	.037	.037		.0366	.0373	.0366
Max	.0549	.0373	.0373	.0366	.037	.128	.037
Min	.0183	.0183	.0183	.0183	.0183	.0183	.0183
Avg	.0287	.0268	.0329	.0275	.0276	.0367	.0253

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 202 / JAMTHA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4572	.3881	.4755	.5121	.6283	.4572
2	.4572	.4572	.3361	.4755	.5487	.6348	.4572
3		.439	.3292	.4572	.4938	.5487	.4572
4	.5487	.3841	.3292	.439	.4938	.5121	.439
5	.5304	.3841	.2926	.4024	.4755	.5121	.4207
6	.4938	.3475	.2743	.3658	.4572	.4938	.4024
7	.3841	.3511	.2926	.3109	.3109	.4755	.439
8	.3841	.6036	.4024	.4572	.4024	.4755	.4755
9	.3841	.6401	.7316	.4755	.695	.5121	.439
10	.7316	.6219	.6401	.7682	.8048	.5914	.5853
11	.7133	.6401		.7133	.7762	.6401	.5487
12	.5729	.6767	.6767	.6401	.2743	.5853	.5487
13	.5121	.6036	.5853	.6036	.7023	.5853	.567
14	.6584	.5544	.3841	.5487	.5304	.567	.5853
15	.6468	.6767	.567	.7133	.695	.5487	.5914
16	.5544	.7682	.6584	.9511	.7207	.567	.5914
17	.6401	.7316	.4938	.6767	.7207	.5487	.5729
18	.6401	.6036	.4572	.6767	.6468	.6036	.5914
19	.6468	.6767	.567	.6767	.8131	.5853	.5914
20	.6283	.7133	.5304	.7316	.8316	.6036	.5914
21	.5544	.6219	.4755	.7133	.7577	.567	.5544
22	.5304	.5853	.439	.6401	.6838	.6219	.5544
23	.4755	.462	.4938	.6584	.6653	.5853	.5544
24	.439	.4805	.3326	.3658	.5487	.6722	.5487
Max	.7316	.7682	.7316	.9511	.8316	.6722	.5914
Min	.3841	.3475	.2743	.3109	.2743	.4755	.4024
Avg	.5471	.5617	.4642	.5807	.6067	.5694	.5235

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 204 / 11 KV INCOMMER-II
Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.4024						
9		.6584	.7682		.7133	.5304	.4572
10				.8048			
20		.7499		.7682	.8686		.6283
Max	.4024	.7499	.7682	.8048	.8686	.5304	.6283
Min	.4024	.6584	.7682	.7682	.7133	.5304	.4572
Avg	.4024	.7042	.7682	.7865	.7910	.5304	.5428

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 401 / 33 KV INCOMMER

Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8	.3841						
9		.6516	.7682		.7133	.543	.439
10				.823			
20		.7682		.7682	.8145		.6099
Max	.3841	.7682	.7682	.823	.8145	.543	.6099
Min	.3841	.6516	.7682	.7682	.7133	.543	.439
Avg	.3841	.7099	.7682	.7956	.7639	.543	.5245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164067 / 33 KV JAMTHA

Feeder No / Name : 403 / 33 KV TRANSFORMER NO-II

Feeder KV- 33 / OUTGOING

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
9	.6516	.7682		.7133	.543	.439
10			.823			
20	.7682		.7682	.8145		.6099
Max	.7682	.7682	.823	.8145	.543	.6099
Min	.6516	.7682	.7682	.7133	.543	.439
Avg	.7099	.7682	.7956	.7639	.543	.5245

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 200 / SUB STATION T/F

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.0017		.0017
2	.0017		.0017
3	.0017		.0017
4	.0017		.0017
5	.0017		.0017
6	.0017		.0034
7	.0017		.0017
8	.0017		.0017
9	.0017		.0017
10	.0017		.0017
11		.0017	
12		.0017	
13		.0017	
14		.0017	
15		.0034	
18		.0017	
20		.0017	
21		.0017	
22		.0137	
23		.0017	
24	.0017		.0017
Max	.0017	.0137	.0034
Min	.0017	.0017	.0017
Avg	.0017	.0031	.0019

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 201 / 11 KV C ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.9431	.8676	1.0288	.8573		1.0288
2	.9945	.9054	.8764	1.0288	.8573		.9907
3	1.0288	.811	.8573	.9526	.8573		.9717
4	1.1317	.8865	.8764	1.0288	.8573		.9717
5	.9088	.8299	.8954	1.0098	.8573		1.0288
6	.9088	.811	.9145	.9717	.8745		.9145
7	.9259	.8488	.9335	1.0669	.8745		.8954
8	.9431	.7922	.9145	1.105	.9602		1.1431
9	.9945	.679	1.0479	1.1241	.9945		1.0288
10	1.046	.7356	1.3527	1.2003	1.2689		1.105
11		.7733	1.5051	1.0974		1.6385	.9907
12		.811	1.4289	1.1317		1.5813	1.1622
13		.7733	1.2574	1.0631		1.4289	1.1812
14		.7733	1.3146	1.1145		1.3336	1.2003
15		.7922	1.1812	1.0974		1.6194	1.3336
16		.8383	1.105			1.5242	1.2765
17		.7811	1.4098			1.4289	1.3336
18		.8192	1.2765	1.046		1.3336	1.086
19		.8192	1.086			1.2384	1.0098
20		.8002	1.0288	.9088		1.0479	.9907
21		.8383	1.0288	.8916		1.086	.9526
22		.8764	.9907	.8916		1.0479	1.0098
23		.9054	1.0288	.9431		1.0288	.9145
24	.0343		.8954	1.0669	.9602		1.0669
Max	1.1317	.9431	1.5051	1.2003	1.2689	1.6385	1.3336
Min	.0343	.679	.8573	.8916	.8573	1.0288	.8954
Avg	.8932	.8193	1.0864	1.0366	.9290	1.3336	1.0661

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 202 / 11 KV D ZONE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.7922	.8299	.8192	.7373		.6859
2	.8573	.7733	.811	.8573	.6859		.7049
3	.7716	.7545	.7922	.8764	.6859		.6668
4	.6859	.6979	.7356	.8764	.6687		.6287
5	.6859	.6602	.7733	.8383	.6173		.6097
6	.7202	.6413	.7356	.743	.6516		.8383
7	.7202	.6036	.5847	.7049	.6687		.8764
8	.7545	.679	.7733	1.2003	1.2517		.9335
9	.9774	.8676	1.1506	1.5051	1.4746		1.0288
10	1.0974	.7733	1.467	1.7909	.7202		1.5242
11		.8488	1.6956	1.8004		1.6194	1.4901
12		.811	1.6575	2.8978		1.6194	1.1694
13		.8299	1.5432	1.6804		1.467	***
14		.9431	1.5813	1.6118		1.5813	1.1694
15		.9431	1.5051	1.6289		1.5623	1.1883
16		.9431	1.5432			1.5242	.9619
17		.6979	1.3146			1.2765	1.3203
18		.5847	1.2193	.8573		.743	.7733
19		.6979	1.2765			.7621	.7733
20		.8676	1.2193	.8916		.743	.7733
21		.8676	.9526	.823		.6668	.679
22		.9431	1.1241			.7049	.7356
23		.8676	.9717	.823		.6859	.679
24	.0857		.6602	.8954	.823		.6859
Max	1.0974	.9431	1.6956	2.8978	1.4746	1.6194	14.2781
Min	.0857	.5847	.5847	.7049	.6173	.6668	.6097
Avg	.7482	.7864	1.1216	1.2061	.8168	1.1504	1.4656

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 203 / 11 KV INCOMMER-I

Feeder KV- 11 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
1	1.8861
Max	1.8861
Min	1.8861
Avg	1.8861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 204 / 11 KV INCOMMER-II
Feeder KV- 11 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
1	.8745
Max	.8745
Min	.8745
Avg	.8745

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 205 / 11 KV FOOD PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8745	.5658	.6979	.7621	.7202		.8192
2	.8573	.5281	.6602	.724	.7202		.8002
3	.8059	.5093	.6224	.7811	.7202		.7811
4	.7716	.5093	.6224	.8383	.703		.8002
5	.7373	.4904	.6413	.7621	.703		.8764
6	.6859	.4715	.6036	.7049	.6687		.7621
7	.5487		.5847	.743	.6687		
8	.7202	.5281	.8676	1.0479	.8916		
9	.7716	.6224	1.0185	1.1241	1.0631		
10	1.1488	.7545	1.1431	1.4289	1.2003		
11		.7356	1.105	1.286		1.3336	
12		.4338	1.1241	1.2346		.9335	.6979
13		.547	1.0098	1.286		1.4861	.7545
14		.679	1.105	1.0802		1.3908	1.0185
15		.6979	1.0479	1.3889		1.4289	.9997
16		.6979	1.086			1.0669	1.0562
17			1.2574			1.1431	.9619
18			1.086	1.1317		1.105	.9619
19		.547	1.0288			1.1241	.7922
20		.5847	.9145	.9945		1.0288	.8299
21		.6413	1.0479	1.0288		.8764	.7356
22		.6979	.9907	.9602		1.0669	.8299
23		.8488	.9526	1.0802		1.1622	.7922
24	.0343		.7733	.9526	.7373		.8573
Max	1.1488	.8488	1.2574	1.4289	1.2003	1.4861	1.0562
Min	.0343	.4338	.5847	.7049	.6687	.8764	.6979
Avg	.7233	.6045	.9163	1.0162	.7997	1.1651	.8488

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 401 / 33 KV INCOMMER

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
1	2.4691
Max	2.4691
Min	2.4691
Avg	2.4691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 402 / 33 KV TRANSFORMER NO-I
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	1.9033
Max	1.9033
Min	1.9033
Avg	1.9033

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164069 / 33 KV APREL PARK

Feeder No / Name : 403 / 33 KV TRANSFORMER NO-II

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
1	.7716
Max	.7716
Min	.7716
Avg	.7716

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 200 / S/STN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.112	.112	.112	.112	.112
2		.112	.112	.112	.112	.112	
3	.112	.112	.112	.112	.112	.112	.112
4		.112	.112	.112	.112	.112	
5		.112	.112	.112	.112	.112	.112
19					.112		
20	.112	.112	.112	.112	.112		.112
21	.112	.112	.112	.112	.112	.112	.112
22	.112	.112	.112	.112	.112		.112
23	.112	.112	.112	.112	.112	.112	.112
24	.112	.112	.064	.112	.112		.112
Max	.112	.112	.112	.112	.112	.112	.112
Min	.112	.112	.064	.112	.112	.112	.112
Avg	.112	.112	.1072	.112	.112	.112	.112

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 201 / VRINDAVAN FEEDER NO. I

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0392	.0411	.0448	.0541	.0429	.0373	.0616
2		.0336	.0429	.0523	.0392	.0336	
3	.0373	.0299	.0373	.0429	.0373	.0317	.0541
4		.0299	.0336	.0243	.0336	.028	
5	.0299	.0317	.0299	.0299	.028	.0336	.028
6		.0317	.028	.0336	.0261	.0355	
7	.0355	.0373	.0355	.028	.0336	.028	.0336
8	.0411	.0467	.0411	.0653	.0411	.0317	.0299
9	.0541	.0597	.056	.0784	.0653	.0485	.0411
10	.0355	.0859	.0859	.0859	.0971		.0504
11	.1008	.1046	.1046	.1083	.1139	.0766	.0859
12	.0803	.1195	.1139	.1027	.1083		.0766
13	.0952	.0971	.0952	.1064	.0934	.0635	.056
14	.0971	.1102	.1176	.0653	.1083	.0579	.0541
15	.1027	.0485	.1288	.0952	.099	.0616	.0691
16	.0896	.099	.1008	.1027	.0784	.056	.0579
17	.0971	.1027	.0859	.0597	.0616	.0635	.0373
18	.0896	.0822	.0597	.056	.0635	.0597	.0429
19	.084	.0822	.0896	.0878	.0952		.0672
20	.0728	.0766	.0728	.0766	.0728		.0541
21	.0803	.0878	.0691	.0878	.0766	.0635	.0523
22	.0672	.0784	.0728	.0653	.0784		.0467
23	.0597	.0709	.0709	.0597	.0616	.0541	.0504
24	.0504	.0523	.056	.056	.056		
Max	.1027	.1195	.1288	.1083	.1139	.0766	.0859
Min	.0299	.0299	.028	.0243	.0261	.028	.028
Avg	.0685	.0683	.0697	.0677	.0671	.0480	.0525

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 202 / VRINDAVAN FEEDER NO. II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	03-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)
9	.0229	.0229
Max	.0229	.0229
Min	.0229	.0229
Avg	.0229	.0229

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562]

BU 0562

Substation No/ Name :- 164830 / 33 KV Vrindavan City S/St'n

Feeder No / Name : 203 / VRINDAVAN FEEDER NO. III

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.049	.0604	.0472	.0396	.0616	.0336	
2		.0566	.049	.0377	.0597	.0299	
3	.0472	.0547	.049	.0434	.0597	.0355	.0355
4		.0528	.0472	.0453	.0579	.028	
5	.034	.0547	.049	.049	.0579	.0355	.0355
6		.0566	.0509	.0585	.0672	.0392	
7	.0321	.0585	.0453	.0415	.0672	.0467	.0392
8	.0396	.0302	.0377	.0283	.0355	.0523	.0467
9		.0245	.0283	.0415	.028	.0336	.0392
10	.0358	.0245	.0358	.034			.0541
11	.0358	.049	.0472	.0472	.0467	.0616	.0299
12	.049	.0434	.0509	.0358	.0411		.0336
13	.0547	.0585	.0585	.0245	.0523	.0485	.0392
14	.0453	.0434	.0283	.0264	.0373	.0541	.028
15	.0415	.049	.0358	.0377	.0411	.0485	.0429
16	.0585	.0698	.0566	.0754	.0766	.0392	.0448
17	.049	.0698	.0604	.0792	.0653	.0541	.0485
18	.0396	.049	.0396	.0434	.0728	.0429	.0377
19	.0245	.0245	.0283	.0245	.0434		.0261
20	.0321	.0434	.034	.0377	.0541		.0336
21	.0358	.034	.0396	.0283	.0355		.0355
22	.0358	.034	.0358	.0377	.0336		.0317
23	.0547	.0396	.034	.0453	.0411		.0336
24	.0566	.0641	.0415	.0343	.0392		
Max	.0585	.0698	.0604	.0792	.0766	.0616	.0541
Min	.0245	.0245	.0283	.0245	.028	.028	.0261
Avg	.0425	.0477	.0429	.0415	.0511	.0427	.0376

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 400 / Station T/F
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 401 / Khapari

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 403 / 33 kv Chinchbhawan-I
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
1	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 404 / 33 kv Chinchbhawan-II
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
1	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 405 / 33 kV Classic City
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 406 / Dongargaon

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 407 / 33KV Mihan -I

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 408 / 33KV Mihan -II
Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 167025 / 132 KV KHAPRI

Feeder No / Name : 409 / DRDO

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 401 / 33 kV MIDC

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 402 / Jaiswal Neco (33 KV
SUNDER RO Feeder KV- 33 /
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 403 / KEC

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 404 / 33KV INDIGO DENIM
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 405 / S/STN TRANSFORMER-I
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 406 / 33KV Morarji+Dinshaw
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 407 / 33 KV Nagpur(U)

SHEDDABLE URBAN

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 408 / 33KV Sutgirani
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 409 / 33KV Meenakshi
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 410 / 33 KV CYTEC
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 411 / 33 KV INNOVATIVE
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 412 / 33 kV B S Metal
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.0572
Max	.0572
Min	.0572
Avg	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 413 / 33 KV Indoworth Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 414 / 33 KV Indorama Feeder
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 415 / 33 kV VIPL
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 416 / 33 KV Mihan W/W
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 417 / 33 KV Akashwani
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 418 / 33 KV SATGAON

Feeder KV- 33 / INCOMING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 419 / 33 KV MIDC - II
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
2	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 420 / Tapadiya Polyester
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 421 / S/STN TRANSFORMER-II
Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.0514
Max	.0514
Min	.0514
Avg	.0514

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 422 / 33 KV APPREL PARK
Feeder KV- 33 / INCOMING

SHEDDABLE URBAN

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 803 / 220 KV Inox
Feeder KV- 220 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168018 / 220 KV BUTIBORI

Feeder No / Name : 805 / 220 KV SANVIJAY STEEL NON SHEDDABLE EHV INDUSTRIAL FEEDERS
Feeder KV- 220 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING

DATE	01-AUG-17
HR	Load (MW)
2	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 400 / 33 KV S/STN TRANSFORMER

Feeder KV- 33 / OUTGOING

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 402 / 33 KV ISHAN CASTING
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 405 / 33 KV SAWANGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 407 / 33 KV PLASMA METAL
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 408 / 33 KV RUCHI SOYA

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

BUTIBORI S/DN.[562] BU 0562

Substation No/ Name :- 168024 / 220 KV BUTIBORI-III

Feeder No / Name : 410 / CEAT

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 201 / 11KV SAWANGI

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5083	.4733	1.3847	1.3321	1.4373	1.3146	.4409
2	.5258	.4557	1.3847	1.3146	1.3496	1.2757	.4557
3	.4908	.443	1.3672	1.2795	1.3146	1.2048	.4382
4	.4908	.4334	1.3321	1.2269	1.262	1.1462	.4382
5	.4557	.4733	1.3146	1.1919	1.1919	.9745	.4207
6	.4477	.4961	1.0692	1.0867	.9816	.8238	.4207
7	.394	.5138	.7362	.7362	.7362	.7442	.3506
8	.5014	.5194	.5609	.5959	.5083	.6661	.3681
9		.5083	.5609	.5609	.4031	.5959	.3506
10	.5959	.6201	.4031	.298	.3681	.4557	.6836
11	.5609	.5609	.5784	.4557	.4557	.4733	.6485
12	.5083	.6135	.5609	.4908	.4784	.4733	.631
13	.5609	.6661	.5258	.4557	.4656	.4557	.631
14	.6379	.6661	.5434	.3155	.4733	.4733	.5784
15	.7164	.6661	.5083	.3681	.443	.4207	.5609
16	.6836	.5609	.3856	.4031	.4075	.4733	.5609
17	.6556	.5434	.4382	.333	.3681	.4382	.5959
18	.6135	.5784	.6485	.5434	.9568	.5609	.8063
19	1.1744	.9465	.9816	1.0166	1.1744	.929	1.0867
20	1.4723	1.4548	1.3672	1.3321	1.3847	1.2795	1.2094
21	1.5592	1.56	1.5074	1.5074	1.5238	1.3672	1.2795
22	1.5402	1.5775	1.5249	1.4723	1.4548	1.4198	1.2795
23	1.4883	1.4373	1.4723	1.4198	1.4373	1.3496	1.2269
24	.4557	.4733	1.4022	1.4022	1.3672	1.4022	.4733
Max	1.5592	1.5775	1.5249	1.5074	1.5238	1.4198	1.2795
Min	.394	.4334	.3856	.298	.3681	.4207	.3506
Avg	.7408	.7184	.9399	.8808	.9143	.8632	.6640

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 202 / Kanholibara - I

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.1475					.1696
2	.1017	.1341					.1696
3	.1187	.1311					.1696
4	.1017	.116					.1696
5	.1357	.1326					.1526
6	.1017	.1326					.1526
7	.1017	.1475					.1187
8	.1187	.1509					
9		.1326					.0848
10			.1187	.0678	.1017	.1017	.0848
11			.1357	.1357	.1147	.1017	.0848
12			.1696	.1187	.1107	.1865	
13			.1696	.1526	.1326	.1696	
14			.1865	.1017	.1311	.1865	
15			.1696	.1526	.1174	.1696	
16			.1526	.1526	.116	.1696	
17			.1526	.1357	.1174	.1526	
24	.1017	.1677					.1696
Max	.1357	.1677	.1865	.1526	.1326	.1865	.1696
Min	.1017	.116	.1187	.0678	.1017	.1017	.0848
Avg	.1093	.1393	.1569	.1272	.1177	.1547	.1388

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 203 / 11 KV GUMGAON - SPARE- SINGLE PHASING
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478	.7956	1.4074	1.4074	1.3565	1.3108	.7122
2	.8817	.7701	1.4074	1.3565	1.3056	1.2452	.7122
3	.8478	.7537	1.3735	1.3226	1.3056	1.1498	.7122
4	.8139	.7293	1.3395	1.2717	1.2689	1.065	.6952
5	.8139	.7461	1.3395	1.2209	1.1869	.9892	.6952
6	.763	.7122	1.1361	1.17	1.0513	.8785	.6613
7	.7122	.7045	.9156	.9496	.9326	.8122	.5596
8	.6274	.6962	.8817	.8309	1.0343	.7701	.5765
9		.7373	.8139	.8478	.7291	.7459	.6274
10	.7969	.7625	.6274	.5087	.5765	.6104	.78
11	.8478	.8139	.78	.5765	.5967	.6274	.7122
12	.8718	.8478	.7291	.5935	.6133	.6613	.763
13	.8684	.8478	.7291	.6274	.6299	.6783	.7461
14	.9221	.9496	.7461	.5596	.639	.6443	.7291
15	.9175	.9496	.6952	.6104	.6133	.6443	.7122
16	.9012	.9496	.6613	.6783	.5868	.6274	.7122
17	.8718	.8648	.7122	.5765	.5571	.6274	.7461
18	.8122	.8309	.8817	.78	.9831	.763	.9156
19	1.1961	1.0513	1.0852	1.153	1.1797	.9665	1.1022
20	1.4586	1.4752	1.4752	1.4074	1.3927	1.3056	1.2039
21	1.5089	1.56	1.5769	1.6448	1.4746	1.3904	1.2548
22	1.4419	1.56	1.56	1.56	1.4419	1.4243	1.2209
23	1.442	1.4582	1.4752	1.4582	1.3923	1.3565	1.17
24	.8139	.7865	1.4243	1.4413	1.4074	1.3435	.7122
Max	1.5089	1.56	1.5769	1.6448	1.4746	1.4243	1.2548
Min	.6274	.6962	.6274	.5087	.5571	.6104	.5596
Avg	.9556	.9314	1.0739	1.0230	1.0106	.9432	.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 204 / 11 KV Kanholibara-II

SINGLE PHASING

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8238	.7164	1.773	1.7013	1.7013	1.3432	1.379
2	.8238	.7343	1.7551	1.6118	1.6297	1.2894	1.3611
3	.7701	.7964	1.7551	1.576	1.5581	1.1999	1.1104
4	.8059	.8596	1.7193	1.5223	1.5203	1.1765	1.1641
5	.8688	1.0317	1.7193	1.4864	1.448	1.1041	1.1999
6	1.0136	1.1584	1.2894	1.4685	1.2178	1.0387	1.2715
7	1.1041	1.2536	.985	1.1104	1.0208	1.0208	1.1641
8	1.267	1.3213	.9671	.9671	.8596	.9313	.5731
9		.7522	.8238	.8596	.7164	.8059	.5731
10	.788	.788	1.2715	.5731	.8775	.8954	.9671
11	.7701	.7343	1.2894	.9671	.9313	.9671	.9313
12	.7783	.7522	.8954	.985	.985	1.1462	.8596
13	.7701	.8059	1.182	.8954	1.0745	1.0387	.7522
14	.8059	.8059	1.2178	.7701	1.1641	.788	.8059
15	.8326	.8238	.5731	.8775	1.1765	1.2178	.7522
16	.8059	.7343	.8059	.9313	1.1104	1.0566	.7522
17	.788	.6626	1.1999	.9134	.9015	.7343	.7522
18	.7964	.788	.7701	.7522	1.3969	.8775	1.0745
19	1.5581	1.3969	1.2715	1.4685	1.6476	1.4148	1.4506
20	1.9728	1.9521	1.8088	1.8823	1.8088	1.7551	1.6118
21	1.9342	2.0595	1.9521	2.0271	1.9547	1.8088	1.6655
22	1.9004	2.0237	1.9342	1.8461	1.8267	1.8625	1.6118
23	1.8088	1.7909	1.8267	1.7918	1.7556	1.7372	1.5581
24	.7701	.6805	1.773	1.7372	1.7375	1.7013	.8059
Max	1.9728	2.0595	1.9521	2.0271	1.9547	1.8625	1.6655
Min	.7701	.6626	.5731	.5731	.7164	.7343	.5731
Avg	1.0677	1.0593	1.3566	1.2801	1.3342	1.2046	1.0895

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 205 / 11 KV NARAYANA

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17
HR	Load (MW)
12	.0191
24	.0191
Max	.0191
Min	.0191
Avg	.0191

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 206 / R.R.R Water works Boregaon NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	02-AUG-17
HR	Load (MW)
11	.0572
Max	.0572
Min	.0572
Avg	.0572

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 207 / Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0381
2		.0572	.0381	.0572	.0572	.0572	.0381
3	.0572	.0572	.0381	.0381	.0572	.0572	.0381
4	.0572	.0572	.0381	.0381	.0381	.0572	.0381
5	.0572	.0572	.0381	.0381	.0381	.0381	.0381
6	.0572	.0572	.0381	.0381	.0572	.0381	.0381
7	.0572	.0572	.0381	.0381	.0572	.0381	.0381
8	.0762	.0572	.0381	.0572	.0381	.0381	.0381
9	.0572	.0762	.0762	.0953	.1143	.0381	.0381
10	.0953	.0572	.0762	.0953	.0953	.0381	.0762
11	.1143		.0762	.1143	.0953	.0381	.0762
12	.1143	.0762	.0762	.0953	.0953	.0381	.0762
13	.1143	.0572	.0953	.1334		.0381	.0572
14	.1143	.0762	.0953	.1143		.0381	.0572
15	.0953	.0762	.0953	.1143	.0762	.0381	.0572
16	.1143	.0762	.0953	.0762	.1143	.0381	.0572
17	.1143	.0572	.0762	.0762	.1143	.0381	.0572
18	.1143	.0572	.0572	.1143	.1334	.0381	.1524
19	.1143	.0953	.0572	.1334	.1524	.0381	.1143
20	.0953	.0762	.0572	.1334	.1143	.0381	.0572
21	.0953	.0762	.0572	.1143	.0762	.0381	.0381
22	.0953	.0572	.0572	.1143	.0762	.0381	.0381
23	.0762		.0572	.0572	.0572	.0381	.0381
24	.0762	.0572	.0572	.0572	.0572	.0572	.0381
Max	.1143	.0953	.0953	.1334	.1524	.0572	.1524
Min	.0572	.0572	.0381	.0381	.0381	.0381	.0381
Avg	.0878	.0650	.0619	.0834	.0806	.0421	.0556

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 208 / 11 KV Jagruteshwar

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 11 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2458		
2			.1802		
3			.2458		
4			.2949		
9			.3277	.3932	
10	.2622	.4915	.3932	.3277	.2458
11	.3277		.3768	.4096	.2294
12	.431	.3113	.1966	.4096	.1989
13	.4694				
14	.4641			.4915	.2515
15	.431	.3605	.4915	.3441	.3812
16	.4694	.4424		.4915	.3149
17	.4588	.2949	.3768	.3605	.3277
18	.431	.2458	.4424	.4096	.2785
19	.4641	.2949	.4096		
20	.4475		.426		.4588
21	.3441	.3932	.4424		.6592
22	.2321	.4424	.4096		.2683
23			.2785		.1823
24			.4424		
Max	.4694	.4915	.4915	.4915	.6592
Min	.2321	.2458	.1802	.3277	.1823
Avg	.4025	.3641	.3518	.4041	.3164

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164011 / 33 KV SAWANGI SUB STATION

Feeder No / Name : 402 / 33 KV Abhijit MADC

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / OUTGOING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.1143	.1143	.1143
2	.1143	.1143	.1143	.1143	.1143	.1143	.1143
3	.1143	.1143	.1143	.1143	.1143	.1143	.1143
4	.1143	.1143	.1143	.1143	.1143	.1143	.1143
5	.1143	.1143	.1143	.1143	.1143	.1143	.1143
6	.1143	.1143	.1143	.1143	.1143	.1143	.1143
7	.1143	.1143	.1143	.1143	.1143	.1143	.1143
8	.1143	.1143	.1143	.1143	.1143	.1143	.1143
9		.1143	.1143	.1143	.0572	.1143	
10		.1143	.1143	.1143			
11	.1143	.1143	.1143	.1143	.1143		
12	.1143		.1143	.1143	.1143		
13	.1143	.1143	.1143	.1143	.1143		.1143
14	.1143	.1143	.1143	.0572	.1143		.1143
15	.1143	.1143	.1143		.1143		.1143
16	.1143	.1143	.1143	.1143	.1143		.1143
17	.1143	.1143	.1143	.1143	.1143		.1143
18	.1143	.1143	.1143	.0572	.1143		.1143
19	.1143	.1143	.1143	.1143	.1143		.1143
20	.1143	.1143	.1143	.1143	.1143		.1143
21	.1143	.1143	.1143	.1143	.1143		.1143
22	.1143		.1143	.1143	.1143		.1143
23	.1143	.1143	.1143	.1143	.1143		.1143
24	.1143	.1143	.1143	.1143	.1143	.1143	
Max	.1143	.1143	.1143	.1143	.1143	.1143	.1143
Min	.1143	.1143	.1143	.0572	.0572	.1143	.1143
Avg	.1143	.1143	.1143	.1093	.1118	.1143	.1143

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 201 / 11 kV Mohagaon Ag Sep
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1296	.1524	.1104	.128	.2858	.1114	.1296
2	.1296	.1524	.1094	.128	.1524	.1114	.1296
3	.1296	.1524	.1104	.128	.1524	.1115	.1296
4	.1296	.1524	.1104	.128	.1524	.1115	.1296
5	.1296	.1524	.1104	.128	.1334	.1115	.1296
6	.1296	.1905	.0947	.112	.1334	.0715	.1296
7	.1619	.1905	.0781	.096	.0953	.0796	.1296
8	.1781	.2667	.0789	.08	.0762	.0637	.1457
9	.1943	.3048	.0789	.08	.0762	.0637	.1457
10	.0474	.0762	.2267	.1296	.1524	.1115	.096
11	.0572	.0614	.2105	.1905	.187	.1619	.0953
12	.0762	.0461	.2915	.2286	.1843	.1781	.0953
13	.0762	.0461		.2286	.2187	.1943	.0953
14	.0572	.0461	.3401	.2286	.208	.2105	.0953
15	.0572	.0614	.2591	.2286	.2401	.2267	.0953
16	.0572	.0614	.2105	.2667	.2386	.2267	.0953
17	.0572	.0614	.2105	.2667	.1909	.2105	.0953
18	.0762	.0621	.0972	.0953	.0795	.08	.1334
19	.1143	.0932	.128	.1334	.1115	.096	.1524
20	.1334	.1087	.128	.1524	.1112	.112	.1524
21	.1524	.1087	.1296	.1524	.1114	.108	.1524
22	.1524	.1087	.144	.1524	.1114	.112	.1715
23	.1524	.1087	.144	.1524	.1114	.112	.1524
24	.1296	.1334	.1091	.128	.1524	.1114	.1296
Max	.1943	.3048	.3401	.2667	.2858	.2267	.1715
Min	.0474	.0461	.0781	.08	.0762	.0637	.0953
Avg	.1129	.1208	.1526	.1559	.1528	.1286	.1252

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 202 / 11 kV Hingna

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8461	1.9052	1.8319	1.829	1.9052	1.7049	1.5729
2	1.8099	1.9052	1.8138	1.7924	1.9052	1.6687	1.5729
3	1.7918	1.9052	1.7956	1.7375	1.9052	1.6324	1.5384
4	1.7918	1.9052	1.7775	1.7194	1.9052	1.6324	1.5203
5	1.7187	1.8099	1.7775	1.7194	1.9052	1.5961	1.5023
6	1.6827	1.8099	1.743	1.7375	1.829	1.5598	1.5023
7	1.6461	1.7147	1.5961	1.647	1.7147	1.507	1.448
8	1.5912	1.5242	1.5598	1.5565	1.6194	1.454	1.4118
9	1.4266	1.5242	1.5598	1.5384	1.5242	1.3995	1.5746
10	1.5364	1.5623	1.5203	1.5203	1.5242	1.3799	1.448
11	1.5242	1.492	1.5023	1.5242	1.4795	1.3575	1.4289
12	1.5242	1.4192	1.4842	1.4289	1.4975	1.267	1.3336
13	1.5242	1.4359	1.5384	1.4289	1.4088	1.2308	1.3336
14	1.5242	1.5268	1.5203	1.4289	1.463	1.2437	1.2384
15	1.5242	1.5449	1.4842	1.3336	1.4449	1.262	1.2384
16	1.5242	1.4904	1.448	1.3336	1.3907	1.2127	1.2384
17	1.5242	1.3632	1.5384	1.3336	1.324	1.1946	1.3336
18	1.7147	1.3603	1.5746	1.5623	1.451	1.4632	1.5242
19	1.9052	1.7412	1.829	1.8099	1.7412	1.6095	1.5242
20	2.0957	2.0495	2.0302	2.0005	1.8863	1.6827	1.7147
21	2.191	2.0495	2.0302	2.0576	1.8883	1.7193	1.7147
22	2.0957	2.0495	2.0485	2.0005	1.8883	1.7558	1.7147
23	2.0957	1.977	1.9204	1.9052	1.8682	1.6827	1.6194
24	1.8461	1.9052	1.8863	1.8473	1.9052	1.7593	1.6095
Max	2.191	2.0495	2.0485	2.0576	1.9052	1.7593	1.7147
Min	1.4266	1.3603	1.448	1.3336	1.324	1.1946	1.2384
Avg	1.7273	1.7071	1.7004	1.6580	1.6823	1.4990	1.4857

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 203 / 11 kV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7621	.6859	.8764	.8954	.8383	.7621
2	.724	.7621	.6859	.8383	.8954	.8383	.724
3	.743	.7621	.6859	.8573	.8954	.8573	.724
4	.724	.7621	.6859	.8002	.8573	.8573	.743
5	.724	.7621	.6668	.8002	.8573	.8002	.724
6	.7621	.6859	.7049	.8383	.8573	.8002	.7811
7	.8002	.6859	.6478	.9145	.8002	.9145	.8002
8	.8764	.6859	.7621	.9145	.8573	.8573	.8764
9	.8573	.6859	.8383	.8764	.8954	.8573	.8383
10	.7811	.6859	1.0669	.9145	.8573	.8383	.7621
11	.8002	.6287	1.2574	.9907	.8573	.9526	.7621
12	.8002	1.7873	.9717	1.0669	.8573	.9145	.7621
13	.8383	1.9624	.8573	1.0669	.9526	.8573	.7621
14	.8383	1.9624	1.1812	1.0479	.7811	.9145	.7621
15	.8002	.6478	1.105	1.0479	.8192	.9526	.7621
16	.8383	.8573	.8573	.9526	.8192		.6097
17	.8764	.8383	.9145	1.0479	1.2765		.7621
18	.8383	.8573	.9145	1.0479	1.0669	.7621	.7621
19	.7621	.8573	.8764	1.0479	1.0098	.8383	.8383
20	.8002	.6859	.8573	1.0479	.8573	.8383	.8383
21	.8002	.6859	.8002	1.105	.7811	.8002	.8573
22	.8383	.6859	.8192	.9526	.7621	.8002	.8573
23	.8002	.6859	.8764	.8573	.8764	.8002	.8573
24	.724	.7621	.6859	.8954	.8573	.8383	.7621
Max	.8764	1.9624	1.2574	1.105	1.2765	.9526	.8764
Min	.724	.6287	.6478	.8002	.7621	.7621	.6097
Avg	.7954	.8810	.8502	.9502	.8851	.8513	.7788

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 204 / 11 kV Sangam Ag Sep
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL
DESIGN TRANSFORMER

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.08	.1143	.1131	.0972	.1334	.0796	.08
2	.064	.1143	.1131	.0972	.1334	.0799	.08
3	.08	.1143	.1131	.0972	.1334	.0799	.08
4	.08	.0953	.1131	.1134	.1334	.0799	.08
5	.0704	.0953	.1131	.1134	.1334	.0959	.08
6	.0688	.0762	.1292	.1296	.1524	.0959	.08
7	.064	.0762	.2262	.1781	.1524	.0959	.064
8	.08	.0762	.3182	.2429	.3239	.1119	.064
9	.048	.0762	.3185	.2915	.362	.1119	.064
10	.1134	.1143	.064	.048	.0572	.048	.0648
11	.1524	.1984	.048	.0572	.0477	.0633	.0762
12	.1524	.1984	.032	.0572	.0485	.048	.0762
13	.1715	.1802	.0192	.0572	.0795	.048	.0762
14	.1905	.1819	.064	.0572	.0636	.064	.0762
15	.1905	.1488	.0474	.0572	.0636	.08	.0762
16	.1905	.1984	.048	.0572	.0636	.064	.0953
17	.1905	.1984	.048	.0572	.0636	.08	.0762
18	.0572	.0992	.064	.0953	.0796	.0772	.1143
19	.0953	.0992	.096	.1143	.1115	.096	.1334
20	.1143	.0817	.0848	.1524	.0956	.096	.1334
21	.1334	.0804	.08	.1524	.0959	.096	.1334
22	.1143	.0804	.08	.1524	.0799	.096	.1334
23	.1143	.0804	.08	.1524	.0799	.096	.1143
24	.08	.1143	.0804	.0972	.1524	.0959	.08
Max	.1905	.1984	.3185	.2915	.362	.1119	.1334
Min	.048	.0762	.0192	.048	.0477	.048	.064
Avg	.1123	.1205	.1039	.1136	.1183	.0825	.0888

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 205 / 11 kV Amar/Rajiv Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.9052	1.8908	1.8671	1.9052	1.7629	1.587
2	1.7375	1.9052	1.8908	1.8298	1.9052	1.7629	1.5684
3	1.6827	1.9052	1.8538	1.7924	1.9052	1.7072	1.5497
4	1.6827	1.9052	1.8167	1.7741	1.9052	1.6701	1.5154
5	1.6804	1.9052	1.7796	1.7193	1.8099	1.633	1.5154
6	1.6804	1.8099	1.7796	1.701	1.8099	1.5773	1.5154
7	1.6057	1.7147	1.5942	1.5364	1.7147	1.4289	1.4266
8	1.5123	1.5242	1.483	1.3535	1.5242	1.3917	1.3717
9	1.4563	1.4289	1.4274	1.3535	1.5242	1.3917	1.39
10	1.2883	1.3336	1.3169	1.3535	1.3336	1.3732	1.3443
11	1.2384	1.2515	1.2254	1.2384	1.2963	1.3535	1.2574
12	1.2384	1.299	1.2437	1.2003	1.2963	1.2803	1.1431
13	1.2384	1.3546	1.2254	1.2003	1.2976	1.2071	1.1431
14	1.2384	1.3917	1.2986	1.2003	1.3519	1.1888	1.0479
15	1.2384	1.4103	1.3169	1.2003	1.3519	1.1706	1.0479
16	1.2384	1.3917	1.3535	1.2384	1.3333	1.134	1.0479
17	1.2955	1.3917	1.3352	1.2384	1.2593	1.0974	1.1431
18	1.4289	1.3917	1.3535	1.3336	1.2963	1.3169	1.3336
19	1.5242	1.5185	1.7177	1.5242	1.6078	1.4815	1.5242
20	1.7147	2.037	1.9978	1.8099	1.8333	1.7177	1.7147
21	2.0005	2.2245	2.0538	1.8671	1.9094	1.7712	1.7147
22	2.0005	2.206	2.0725	1.9052	1.9835	1.7551	1.7147
23	2.0005	2.0762	1.9791	1.9052	1.9279	1.6804	1.6194
24	1.7924	1.9052	1.9464	1.8858	1.9052	1.8186	1.6057
Max	2.0005	2.2245	2.0725	1.9052	1.9835	1.8186	1.7147
Min	1.2384	1.2515	1.2254	1.2003	1.2593	1.0974	1.0479
Avg	1.5537	1.6745	1.6230	1.5428	1.6245	1.4863	1.4101

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 206 / 11 kV Mahajanwadi

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9526	.9845	.9979	1.0479	.9297	.8589
2	.9709	.9526	.9288	.961	1.0479	.9297	.8402
3	.9335	.9145	.8916	.961	1.0479	.9297	.8131
4	.9335	.9145	.8916	.9335	.9907	.8925	.8131
5	.9522	.8573	.9288	.924	.9907	.8554	.7947
6	.9619	.8573	1.0031	.9795	.9526	.8182	.8131
7	.9149	.9526	.9288	.8779	.8573	.8368	.8131
8	.8402	.8764	.8359	.8048	.7621	.7438	.7865
9	.7655	.8002	.7331	.7762	.6859	.6694	.7762
10	.7577	.7621	.7392	.724	.6859	.6694	.7392
11	.6859	.7971	.7392	.6668	.6495	.7392	.724
12	.6859	.7252	.7023	.6668	.6501	.7023	.6478
13	.6097	.7438	.7392	.6668	.6687	.7095	.6478
14	.6097	.7438	.7343	.6668	.7059	.6653	.5716
15	.6097	.781	.7207	.6668	.7059	.6468	.5716
16	.6859	.743	.7023	.6668	.6501	.6099	.5716
17	.7621	.7059	.7577	.6668	.6501	.5914	.6097
18	.8573	.6687	.7947	.7621	.7245	.7282	.724
19	.9526	.9102	1.0082	.9526	.9288	.8413	.8383
20	1.0479	1.1145	1.1389	1.0479	1.0217	.924	.9145
21	1.1431	1.1145	1.1389	1.0669	1.0588	.9808	.9145
22	1.1431	1.096	1.1317	1.0669	1.0588	.9709	.9145
23	.9907	1.0774	1.094	1.0669	1.0217	.9149	.8573
24	.9979	.9526	1.0217	1.0185	1.0479	.9297	.8589
Max	1.1431	1.1145	1.1389	1.0669	1.0588	.9808	.9145
Min	.6097	.6687	.7023	.6668	.6495	.5914	.5716
Avg	.8675	.8756	.8871	.8579	.8588	.8012	.7673

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 207 / 11 kV Mohagaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3048	.3042	.2957	.2858	.2846	.2561
2	.3018	.3048	.3042	.2743	.2858	.2846	.2561
3	.2829	.3048	.3042	.2743	.2858	.2846	.2561
4	.2829	.2667	.2852	.2743	.2858	.2846	.2561
5	.2829	.2667	.2852	.2743	.2858	.2467	.2561
6	.2402	.2286	.2662	.2378	.2667	.2279	
7	.1829	.2286	.2092	.2195	.2667	.1899	
8	.1848	.2286	.2092	.1829	.1905	.2277	
9	.2012	.2667	.2472	.2195	.1905	.2467	
10	.1829	.3239	.3841	.2561	.3048	.2846	
11	.2286	.3206	.4024	.2667	.3232	.2195	
12	.2286	.3388	.3841	.2667	.3232	.2195	.1905
13	.2286	.3018	.3292	.2667	.3419	.2378	.2286
14	.2096	.3803	.2561	.2667	.2469	.2561	.2286
15	.1905	.3423	.3292	.2667	.2469	.2743	.2286
16	.1905	.3423	.3109	.2667	.2469	.2743	.1905
17	.1905	.3232	.3109	.2667	.3419	.2743	.1905
18	.2286	.3232	.2926	.2477	.3419	.2614	.2286
19	.2667	.2646	.2614	.2477	.2657	.2561	.3048
20	.2667	.3402	.3292	.3048	.3036	.2743	.3048
21	.3048	.3423	.3292	.3239	.3036	.2743	.3048
22	.3048	.3423	.3142	.3239	.3036	.2743	.2667
23	.3048	.3232	.2926	.2858	.2846	.2743	.2667
24	.2926	.3048	.3042	.2743	.2858	.2846	.2561
Max	.3048	.3803	.4024	.3239	.3419	.2846	.3048
Min	.1829	.2286	.2092	.1829	.1905	.1899	.1905
Avg	.2450	.3048	.3019	.2660	.2837	.2590	.2484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 208 / 11 kV Sangam

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3429	.3479	.3292	.3048	.3299	.3109
2	.3395	.3429	.3482	.3258	.3048	.3299	.3109
3	.3361	.3429	.3482	.3258	.3048	.3299	.3077
4	.3361	.3429	.3299	.3258	.3048	.3299	.2896
5	.3174	.3048	.3299	.3258	.2667	.3299	.2896
6	.2743	.2667	.3116	.2896	.2667	.2932	.2715
7	.2561	.2667	.2566	.2353	.2286	.2202	.2353
8	.2378	.2667	.2566	.1991	.2667	.2202	.2172
9	.2195	.3048	.2383	.2103	.2667	.2199	.2172
10	.2534	.3048	.2896	.2715	.6859	.2195	.2715
11	.2477	.2183	.3258	.2667	.2545	.1991	.2477
12	.2477	.2365	.2715	.2667	.2363	.1991	.2286
13	.2477	.2545	.3258	.2667	.2545	.1991	.2286
14	.2477	.2729	.3077	.2667	.2363	.181	.2286
15	.2477	.2926	.3077	.2667	.2566	.1629	.2286
16	.2477	.2926	.3077	.2286	.2566	.1629	.1905
17	.2477	.2378	.2534	.2286	.2199	.1448	.2286
18	.2667	.2926	.2172	.2667	.2383	.1629	.2667
19	.3048	.3292	.3077	.3048	.3482	.2715	.3048
20	.381	.4198	.3841	.3429	.3666	.2896	.3048
21	.381	.4198	.3841	.3429	.3482	.3258	.3048
22	.381	.4015	.3658	.3429	.3486	.3258	.3048
23	.3429	.3662	.362	.3429	.3482	.3292	.2858
24	.3586	.3429	.3662	.3258	.3429	.3302	.3077
Max	.381	.4198	.3841	.3429	.6859	.3302	.3109
Min	.2195	.2183	.2172	.1991	.2199	.1448	.1905
Avg	.2942	.3110	.3143	.2874	.3023	.2544	.2659

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164035 / 33KV WANADONGARI

Feeder No / Name : 402 / 33 kV Abhijeet MADC

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	07-AUG-17
HR	Load (MW)
11	.0171
Max	.0171
Min	.0171
Avg	.0171

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 202 / 11 KV Issasani

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4382	.415	.4435	.4382	.4066	.3772
2	.4066	.4382	.4338	.3881	.4382	.3881	.3772
3	.4066	.4382	.4338	.3881	.4382	.3658	.3584
4	.3881	.4382	.3772	.3881	.4191	.3696	.3584
5	.3696	.4191	.415	.3696	.4191	.3326	.3395
6	.3326	.4191	.415	.3696	.4001	.3326	.3584
7	.3326	.4191	.3772	.037	.381	.3142	.3395
8	.3326	.362	.3395	.3881	.362	.2957	.3206
9	.3326	.3239	.3018	.3326	.362	.3475	.3395
10		.3239	.3429	.2829	.3048	.3429	.3239
11	.381	.3239	.3048	.2829	.3048	.3239	.3239
12	.381	.2858	.3429	.3395	.3048	.3239	.2987
13	.362	.3239	.3239	.2829	.3429	.3239	.2829
14	.362	.3239	.3475	.2641	.3429	.3239	.2587
15	.362	.362	.3429	.3206	.3239	.3239	.2772
16	.381	.3395	.3239	.3206	.3048	.3048	.2829
17	.3429	.3772	.3511	.3206	.3048	.2829	.3018
18	.3239	.3018	.3109	.3048	.3326	.2641	
19	.4001	.3772	.3511	.362	.3881	.3395	.2957
20	.4954	.4715	.4435	.4572	.4251	.415	.3326
21	.4954	.4904	.462	.4763	.4435	.415	.3292
22	.5144	.5093	.4572	.4572	.4251	.4338	.3326
23	.4954	.4715	.4207	.4572	.2957	.3961	.3142
24	.4066	.4572	.4527	.4066	.4382	.4207	.3772
Max	.5144	.5093	.462	.4763	.4435	.4338	.3772
Min	.3239	.2858	.3018	.037	.2957	.2641	.2587
Avg	.3918	.3931	.3786	.3517	.3725	.3495	.3261

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

HINGANA S/DN[362]

BU 3956

Substation No/ Name :- 164837 / 33 KV ISSASANI

Feeder No / Name : 203 / 11 KV Bhimnagar

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2254	1.4289	1.358	1.3352	1.3908	1.2437	1.1883
2	1.2071	1.4289	1.3203	1.2382		1.2197	1.1883
3	1.1827	1.4289	1.3769	1.2012	1.3908	1.1706	1.1694
4	1.1643	1.4289	1.358	1.2382	1.3717	1.1458	1.1694
5	1.1273	1.448	1.4146	1.2936	1.3717	1.1273	1.2449
6	1.1827	1.448	1.4146	1.3169	1.3717	1.1088	1.226
7	1.2197	.8002	1.2637	1.1273	1.2765	1.0903	1.1883
8	1.1273	1.1241	1.1883	1.1273	1.1622	1.0534	1.2637
9	1.2012	1.105	1.2449	1.0719	1.2003	1.0242	1.2637
10		1.3146	1.3336	1.3392	1.2765	1.0479	1.3336
11	1.6385	1.4861	1.467	1.358	1.4289	1.105	1.2955
12	1.5432	1.467	1.5242	1.358	1.4098	1.0288	1.1763
13	1.5242	1.4289	1.5051	.9431	1.5432	1.0479	1.0903
14	1.6194	1.5051	1.5339	1.0185	1.5051	.8954	1.0082
15	1.5432	1.5432	1.5813	1.3014	1.2955	.8954	.9896
16	1.5623	1.5466	1.5432	1.4146	1.3146	.8954	.8962
17	1.467	1.3014	1.3491	1.2637	1.2574	.9431	.9149
18	1.2003	1.1506	1.134	1.1622	1.1088	.9808	
19	1.3146	1.3014	1.1888	1.3336	1.2803	1.2637	1.2254
20	1.6385	1.6032	1.3676	1.5432	1.3121	1.3957	1.2803
21	1.6766	1.4901	1.4045	1.5623	1.4449	1.4146	1.3169
22	1.6004	1.6032	1.4969	1.5432	1.4815	1.3957	1.2012
23	1.5051	1.4901	1.423	1.448	1.3491	1.2826	1.1088
24	1.2936	1.3908	1.3769	1.2936	1.3717	1.2752	1.1883
Max	1.6766	1.6032	1.5813	1.5623	1.5432	1.4146	1.3336
Min	1.1273	.8002	1.134	.9431	1.1088	.8954	.8962
Avg	1.3811	1.3860	1.3820	1.2847	1.3441	1.1271	1.1708

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonegoan S/Stn

Feeder No / Name : 201 / Dainik Bhaskar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.8299	.5716	.6668	.743	.7049	.5335
2	.6859	.811	.5335	.8002	.7811	.6668	.8002
3	.6478	.7468	.5906	.743	.724	.6478	.8002
4	.6097	.6722	.5525	.724	.6668	.6287	.7621
5	.5716	.6097	.5335	.7621	.6287	.6287	.6668
6	.5906	.6036	.5716	.6478	.6668	.6097	.5716
7	.5144	.5281	.6097	.7049	.6097	.6287	.5906
8	.6859	.5415	.5906	.7621	.0191	.6668	.5335
9	.6859	.4904	.6478	.7049	.724	.6668	.6478
10	.9335		.8488	1.0288	.8954	.8002	.8002
11	1.1622	.5144	1.0082	1.1431	1.0479	.9145	.9335
12	1.1431	.6097	1.094	1.2765	1.1431	.8764	.8954
13	1.1622		.9997	.9907	.9335	.8002	.7811
14	1.1241		1.0669	1.1622	1.086	.8002	.9335
15	1.1812	.6287	1.0669	1.2574	1.086	.8383	.9717
16	1.1622	.7621	1.2003	1.2765	1.1431	.9526	.9145
17	1.1812	.6859	1.1622	1.2574	1.0479	.8573	.8764
18	1.1622	.724	1.0288	1.2003	.9907	.8764	
19	.8954	.6287	1.0098	.9145	.9145	.8383	.743
20	.6602	.4763	.724	.6859	.743	.7811	.5716
21	.6287	.5144	.6287	.6097	.724	.7811	.6097
22	.724	.5144	.6478	.6478	.724	.6668	.6478
23	.6287	.4954	.7049		.724	.8002	.6287
24	.724		.5525	.7811	.7811	.724	.8002
Max	1.1812	.8299	1.2003	1.2765	1.1431	.9526	.9717
Min	.5144	.4763	.5335	.6097	.0191	.6097	.5335
Avg	.8396	.6194	.7894	.9021	.8145	.7565	.7397

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonegoan S/Stn

Feeder No / Name : 202 / 11 kV RC PLASTO

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.2955	1.3336	1.4861	1.5623	1.5242	.9145
2	1.4861	1.2384	1.2574	1.5242	1.5242	1.4861	1.6004
3	1.448	1.3203	1.2384	1.448	1.5813	1.448	1.3717
4	1.2955	1.1128	1.2955	1.4861	1.6004	1.4861	1.448
5	1.1431	1.0669	1.2955	1.3336	1.5242	1.448	1.3908
6	1.2193	1.2384	1.3717	1.5242	1.4289	1.3717	1.4098
7	1.2955	1.2193	1.2955	1.4861	1.2384	1.4098	1.3717
8	1.4861	1.1812	1.3336	1.4861	1.1812	1.3336	1.448
9	1.448	.4854		1.5242	1.5051	1.5623	1.4861
10	1.4861	1.1317	1.448	1.4861	1.6194	1.5623	1.5242
11	1.448	1.0288	1.3957	1.5242	1.5242	1.4861	1.448
12	1.5242	1.0669	1.4098	1.6004	1.3336	1.4861	1.5623
13	1.448	1.1431	1.3717	1.6004	1.3717	1.4861	1.4289
14	1.2955	1.2193	1.5051	1.6004	1.4861	1.5623	1.4861
15	1.4289	1.1431	1.4861	1.5242	1.448	1.5242	.9717
16	1.5242	1.1431	1.5623	1.448	1.5242	1.5623	1.4289
17	1.6194	1.2193	1.5623	1.6004	1.6004	1.6766	1.5623
18	1.3146	1.2193	1.6004	1.6194	1.5623	1.7147	
19	1.1506	1.2955	1.6004	1.5623	1.448	1.6194	1.5242
20	1.3717	1.2193	1.4861	1.5242	1.2955	1.3717	.5716
21	1.2193	1.2193	1.448	1.5051	1.5242	1.4098	.724
22	.743	1.2574	1.3717	1.448	1.5242	1.5242	1.2193
23	1.1431	1.3336	1.3717		1.4861	1.5242	1.4861
24	1.2955		1.2955	1.4861	1.5051	1.4861	1.4861
Max	1.6194	1.3336	1.6004	1.6194	1.6194	1.7147	1.6004
Min	.743	.4854	1.2384	1.3336	1.1812	1.3336	.5716
Avg	1.3482	1.1651	1.4059	1.5143	1.4750	1.5027	1.3419

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 164825 / 33 kV Sonegoan S/Stn

Feeder No / Name : 203 / 11KV Rukmini Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7545	.6478	.724	.7621	1.6766	
2	.8573	.7922	.6668	.8002	.8002	1.7147	.5906
3	.9145	.7545	.6287	.743	.6668	1.6956	.6859
4	.8954	.7356	.5906	.724	.5525	1.7337	.6668
5	.9145	.6602	.6478	.7621	.5716	1.6766	.6859
6	.8383	.6668	.724	.743	.6668		.6478
7	.8002	.4715	.7811	.6478	.6287	1.5623	.6287
8	1.1622	.4527	.9907	.6668	.6668	1.7528	.743
9	1.086	.4904	1.8671	1.3336	1.3336	2.3434	1.5432
10	1.6575	.5041	1.7718	1.8671	1.4098	2.6101	1.448
11	1.5813	.4572	1.226	1.6385	1.2765	2.2481	1.3527
12	1.9433	.4954	1.3908	1.7337	1.9814	2.6292	1.2193
13	1.6004		1.2384	1.4861	1.1812	2.1719	.8954
14	1.6956		1.4098	1.6956	1.3717	2.7244	1.0669
15	1.5623	.4954	1.5242	1.6575	1.8099	1.6575	1.1622
16	1.7337	.5335		1.4289	1.4861	1.6194	1.1883
17	1.4146	.5144	2.0005	1.4289		1.1812	1.1622
18	1.7337	.4954	1.0098	.8954		1.4098	
19	1.0669	.5335	.9145	.724	1.9433	1.9814	.9526
20	.6413	.5335	.5716	.6097	1.829	.5525	
21	.5658	.5525	.6287	.6097	1.8671	.5906	
22	.743	.6478	.724	.8002	1.6575	.6859	.6478
23	.7922	.6478	.724		1.7337	.8383	.5525
24	.5144		.6668	.8002	.743	1.5623	.8383
Max	1.9433	.7922	2.0005	1.8671	1.9814	2.7244	1.5432
Min	.5144	.4527	.5716	.6097	.5525	.5525	.5525
Avg	1.1480	.5804	1.0150	1.0661	1.2245	1.6791	.9339

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 200 / Station T/F

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.1715			
16						.1715	
17			.1715		.1715		.1715
23		.1715					
24	.1715						
Max	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Min	.1715	.1715	.1715	.1715	.1715	.1715	.1715
Avg	.1715	.1715	.1715	.1715	.1715	.1715	.1715

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 204 / 11 KV INDUSTRIAL-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				1.2003	1.2003	
16		1.2003				
17			1.2003			1.2003
23		1.2003				
24	1.5432					
Max	1.5432	1.2003	1.2003	1.2003	1.2003	1.2003
Min	1.5432	1.2003	1.2003	1.2003	1.2003	1.2003
Avg	1.5432	1.2003	1.2003	1.2003	1.2003	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 209 / 11 KV MANKAPUR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.8573	
16		.8573			
17					.8573
23			.8573		
24	.8573				
Max	.8573	.8573	.8573	.8573	.8573
Min	.8573	.8573	.8573	.8573	.8573
Avg	.8573	.8573	.8573	.8573	.8573

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 210 / 11 KV HINGNA-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				1.2003	
16		1.2003			
17			1.2003		1.2003
24	1.2003				
Max	1.2003	1.2003	1.2003	1.2003	1.2003
Min	1.2003	1.2003	1.2003	1.2003	1.2003
Avg	1.2003	1.2003	1.2003	1.2003	1.2003

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 211 / 11 KV HINGNA-II

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				2.3148	2.3148	
16		2.3148				
17			2.3148			2.3148
24	2.4863					
Max	2.4863	2.3148	2.3148	2.3148	2.3148	2.3148
Min	2.4863	2.3148	2.3148	2.3148	2.3148	2.3148
Avg	2.4863	2.3148	2.3148	2.3148	2.3148	2.3148

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 214 / 11 kv Urban-II

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.5144	.5144	
16		.5144				
17			.5144			.5144
24	.5144					
Max	.5144	.5144	.5144	.5144	.5144	.5144
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.5144	.5144	.5144	.5144	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 216 / 11 KV INDUSTRIAL-I

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				1.5432	1.5432	
16		1.5432				
17			1.5432			1.5432
24	1.5432					
Max	1.5432	1.5432	1.5432	1.5432	1.5432	1.5432
Min	1.5432	1.5432	1.5432	1.5432	1.5432	1.5432
Avg	1.5432	1.5432	1.5432	1.5432	1.5432	1.5432

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 217 / 11 KV WATER WORKS NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.5144	.5144	
16		.5144				
17			.5144			.5144
24	.5144					
Max	.5144	.5144	.5144	.5144	.5144	.5144
Min	.5144	.5144	.5144	.5144	.5144	.5144
Avg	.5144	.5144	.5144	.5144	.5144	.5144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - I S/DN.[690] BU 4690

Substation No/ Name :- 167006 / 132/11KV HINGNA-I

Feeder No / Name : 219 / 11 KV ABC

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
15				.6859	.6859	
16		.6859				
17			.6859			.6859
24	.5144					
Max	.5144	.6859	.6859	.6859	.6859	.6859
Min	.5144	.6859	.6859	.6859	.6859	.6859
Avg	.5144	.6859	.6859	.6859	.6859	.6859

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 201 / Suvarna Laghu Udyog(SLU) SHEDDABLE FEEDER HAVING WEEKLY

Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.467	1.5623	.4481	1.5623	1.5623	1.5432	1.6194
2	1.467	1.5432	.4481	1.5242	1.5623	1.6004	1.5623
3	1.4098	1.4861	.4854	1.5432		1.4098	1.5242
4	1.3908	1.5242	.4854	1.5051	1.5242	1.5051	1.5623
5	1.2765	1.4289	.5415	1.4861	1.5242	1.3717	1.448
6	1.3146	1.3146	.5228	1.5432	1.5623	1.6956	1.4098
7	1.2765	.8764	.5975	1.5242	1.6575	1.5813	1.448
8	1.2765	.5525	1.0642	1.6385	1.7147	1.8099	1.5813
9	1.2955	.5144	1.475	1.7147	1.7528	1.7737	1.6004
10	1.6385		1.5432	1.7147	1.6991	1.7737	1.6956
11	1.5623	.0381	1.7718	2.0957	1.5684	2.1338	1.7528
12	1.5813	.0381	1.7147	2.0957	1.5123	1.6194	1.7147
13	1.5242	.0419	1.8671	1.8861	1.7364	1.7718	1.7718
14	1.6766	.0381	1.9243	1.9243	1.9791	1.4098	1.7909
15	1.5242	.04	1.6956	1.9243	1.9418	1.3336	1.8099
16	1.6766	.0362	2.0195	1.9624	1.9418	1.467	1.8671
17	1.6385	.0381	1.9433	1.9624	2.0351	1.4861	1.9624
18	1.5623	.0457	1.7147	1.9052	2.1472	1.7337	1.9052
19	1.4098	.04	1.4861		1.9243	1.3336	1.7147
20	1.448	.0457	1.467	1.4289	1.7528	1.5432	2.0576
21	1.4861	.4294	1.467	1.4289	1.6766	1.6004	1.8099
22	1.3908	.4108	1.2003	1.448	1.7337	1.6956	1.6194
23	1.5432	.0457	1.1812	1.5813	1.4937	1.5051	1.7718
24	1.4289	1.5242	.4668	1.5813	1.7147	1.4098	1.5242
Max	1.6766	1.5623	2.0195	2.0957	2.1472	2.1338	2.0576
Min	1.2765	.0362	.4481	1.4289	1.4937	1.3336	1.4098
Avg	1.4694	.5919	1.2304	1.6948	1.7268	1.5878	1.6885

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 202 / Berar Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.381	.4294	.362	.3429	.3239	.381
2	.3429	.381	.4108	.381	.3429	.2667	.3429
3	.3429	.362	.3734	.362	.3429	.2858	.362
4	.3239	.3429	.3547	.3429	.3239	.3239	.381
5	.3239	.3429	.3921	.362	.3239	.362	.3429
6	.3429	.4382	.4294	.3429	.3239	.3429	.3048
7	.3429	.362	.4108	.3239	.3429	.3429	.381
8	.4954	.4001	.2987	.3239	.3429	.3239	.4191
9	.4954	.381	.2801	.5144	.3429	.2801	.381
10	.5144	.4001	.5906	.5144	.3174	.3174	.362
11	.5335	.0324	.5144	1.1241	.5228	.4001	.5716
12	.4572	.0362	.6097	.7811	.8029	.8573	.6859
13	.362	.0381	.8954	.8573	.6535	.2477	.6478
14	.4191	.0324	.5525	.5144	.4481	.4001	.6097
15	.381	.0324	.5335	.5144	.4481	.3429	.2286
16	.4001	.0286	.4954	.5144	.4108	.381	.2858
17	.3048	.0267	.4382	.4954	.3547	.3048	.2667
18	.3429	.0438	.4572	.4191	.3174	.2286	.2286
19	.362	.0343	.3239	.3429	.3429	.2286	.2667
20	.3429	.0343	.2667	.3429	.362	.362	.2096
21	.3239	.3174	.362	.3429	.3429	.2858	.2477
22	.4191	.3361	.4001	.3429	.362	.2858	.2858
23	.381	.04	.381	.362	.2614	.3429	.2477
24	1.4937	.362	.3921	.381	.362	.3048	.3048
Max	1.4937	.4382	.8954	1.1241	.8029	.8573	.6859
Min	.3048	.0267	.2667	.3239	.2614	.2286	.2096
Avg	.4329	.2161	.4413	.4652	.3891	.3392	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 203 / Varsha feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.743	.5415		.743	.8192	.7621
2	.6859	.724	.5228		.743	.8573	.724
3	.6668	.724	.5041		.7049	.7621	.743
4	.6668	.6859	.5228		.7049	.7049	.6859
5	.6668	.6668	.5041		.7049	.6668	.6668
6	.6859	.6478	.5415		.6859	.743	.6668
7	.6859	.6478	.5601		.6859	.9335	.6478
8	.6859	.5525	.5975		.6859	.743	.7049
9	.8383	.5525	.7282		.7621	.8402	.8002
10	.9526	.5525	.8764	.9526	1.0642	.9335	.9145
11	1.0288	.0553	1.0288	1.0288	1.0829	.9335	.8573
12	1.0098	.0591	.8954	1.0288	1.0642	.9717	.8002
13	.9907	.0591	.9907	1.0669	1.1389	1.0288	.8573
14	1.0669	.0572	1.0288	1.0288	1.2323	.9526	.9526
15	1.105	.0553	1.0669	1.0288	1.2136	.9717	.9526
16	1.2003	.0533	1.105	1.0669	1.1389	.9907	.8573
17	1.0669	.0533	1.1431	1.086	1.1016	1.0669	.8383
18	1.0288	.0553	.9526	.9335	1.0479	.9145	.8002
19	.9335	.0591	.9907	.8954	.9907	.8383	.8573
20	.8764	.0476	.9145	.8764	.9145	.9145	.8002
21	.8383	.5041	.8192	.8383	.8764	.8573	.7621
22	.7621	.5228	.743	.8002	.7811	.6287	.5906
23	.743	.0514	.7621	.7621	.8215	.724	.6478
24	1.6804	.724	.5041		.743	.7811	.724
Max	1.6804	.743	1.1431	1.086	1.2323	1.0669	.9526
Min	.6668	.0476	.5041	.7621	.6859	.6287	.5906
Avg	.8980	.3689	.7852	.9567	.9013	.8574	.7756

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 164824 / 33 KV Nildoh Industrial

S/stn

Feeder No / Name : 204 / Sanvijay

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.6668	.4382	.5716	.6478	.724	.724
2	.4954	.6478	.3921	.6097	.6097	.6668	.6859
3	.4954	.6097	.4294	.5335	.6097	.743	.7049
4	.4763	.5716	.4481	.5525	.5716	.6859	.6668
5	.5144	.4954	.4294	.5716	.5716	.7049	.6097
6	.5525	.4572	.4108	.5788	.6478	.7621	.6478
7	.5716	.4572	.4481	.5975	.6859	.7811	.6859
8	.6097	.4572	.5601	.7095	.6859	.8192	.743
9	.7811	.4191	.7468	.9149	.9526	.9149	.9335
10	.9717	.4572	.8954	1.0288	1.0829	1.0082	1.0288
11	.7811	.0438	.8383	.9526	1.0269	.9526	1.0479
12	.743	.0457	.8764	1.0098	.9896	.9907	.9717
13	.7049	.0457	.8192	.9335	.9896	.9145	.9145
14	.9526	.0438	.8764	1.1431	.9709	1.0098	.8573
15	.743	.0457	.8002	1.105	1.0829	.8573	.7621
16	.9907	.0419	1.0098	1.0288	1.1203	1.0669	.8573
17	.9717	.04	.9335	1.0098	1.1389	.9526	.9335
18	.9335	.0457	.8954	1.0098	1.0642	.9335	.9717
19	.7811	.04	.9145	.9145	1.0288	.8192	.8573
20	.724	.0362	.6668	.724	.9335	.7621	.7621
21	.6478	.3361	.8002	.7049	.8383	.8192	.8573
22	.7049	.3547	.6478	.7049	.8573	.8383	.9145
23	.6859	.0362	.6668	.6859	.7842	.724	.743
24	1.4937	.6668	.4481	.5525	.6478	.743	.6859
Max	1.4937	.6668	1.0098	1.1431	1.1389	1.0669	1.0479
Min	.4763	.0362	.3921	.5335	.5716	.6668	.6097
Avg	.7434	.2942	.6830	.7978	.8558	.8414	.8153

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 201 / 11 KV ELECTRONIC ZONE
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.9874	2.9874	2.9874
24	2.0538			
Max	2.0538	2.9874	2.9874	2.9874
Min	2.0538	2.9874	2.9874	2.9874
Avg	2.0538	2.9874	2.9874	2.9874

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 202 / 11 KV EXPRESS-II
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.0538	2.0538	2.0538	2.1472	2.0538
24	2.2405					
Max	2.2405	2.0538	2.0538	2.0538	2.1472	2.0538
Min	2.2405	2.0538	2.0538	2.0538	2.1472	2.0538
Avg	2.2405	2.0538	2.0538	2.0538	2.1472	2.0538

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 203 / 11 KV NILDOH
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	2.2405	2.3339	2.2405	2.2965
Max	2.2405	2.3339	2.2405	2.2965
Min	2.2405	2.3339	2.2405	2.2965
Avg	2.2405	2.3339	2.2405	2.2965

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 205 / 11 KV EXPRESS-I
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.1317	1.1203	1.1317	1.1203	1.1203
24	1.2136					
Max	1.2136	1.1317	1.1203	1.1317	1.1203	1.1203
Min	1.2136	1.1317	1.1203	1.1317	1.1203	1.1203
Avg	1.2136	1.1317	1.1203	1.1317	1.1203	1.1203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 206 / 11 KV VICCO DIFFUSION
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		3.9209	4.0143	3.9582	3.9209
24	3.9209				
Max	3.9209	3.9209	4.0143	3.9582	3.9209
Min	3.9209	3.9209	4.0143	3.9582	3.9209
Avg	3.9209	3.9209	4.0143	3.9582	3.9209

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 207 / 11 KV SHARDA
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12	2.452	2.4272	2.4272	2.4272	2.4272
Max	2.452	2.4272	2.4272	2.4272	2.4272
Min	2.452	2.4272	2.4272	2.4272	2.4272
Avg	2.452	2.4272	2.4272	2.4272	2.4272

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 212 / Vicco Alpha
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.6804	1.6804	1.6804	1.6804	1.6804
24	1.6804					
Max	1.6804	1.6804	1.6804	1.6804	1.6804	1.6804
Min	1.6804	1.6804	1.6804	1.6804	1.6804	1.6804
Avg	1.6804	1.6804	1.6804	1.6804	1.6804	1.6804

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 215 / 11KV INCOMER NO.I
Feeder KV- 11 / INCOMINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	4.1076
Max	4.1076
Min	4.1076
Avg	4.1076

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 216 / 11KV INCOMER NO.II
Feeder KV- 11 / INCOMINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	4.6677
Max	4.6677
Min	4.6677
Avg	4.6677

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 400 / Station T/F
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT
HAVING WEEKLY STAGGERING

DATE	01-AUG-17
HR	Load (MW)
24	.5601
Max	.5601
Min	.5601
Avg	.5601

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 401 / 33 KV RAMSON
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		2.5766	5.5453	5.8282	6.3295
24	5.0412				
Max	5.0412	2.5766	5.5453	5.8282	6.3295
Min	5.0412	2.5766	5.5453	5.8282	6.3295
Avg	5.0412	2.5766	5.5453	5.8282	6.3295

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 402 / 33 KV NACAST

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY
STAGGERING (MIDC, EQUIVALENT)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
12		1.4003	2.5206	4.2438	5.0412	5.0412
24	5.3212					
Max	5.3212	1.4003	2.5206	4.2438	5.0412	5.0412
Min	5.3212	1.4003	2.5206	4.2438	5.0412	5.0412
Avg	5.3212	1.4003	2.5206	4.2438	5.0412	5.0412

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

MIDC METER NAGPUR[678]

MIDC - II S/DN.[691] BU 4691

Substation No/ Name :- 167015 / 132KV HINGNA II

Feeder No / Name : 407 / 33 kv Nildoh feeder
incommer Feeder KV- 33 /
INCOMINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-AUG-17
HR	Load (MW)
24	4.8097
Max	4.8097
Min	4.8097
Avg	4.8097

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 201 / Temple Bazar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3142	.3511	.3734	.3547	.3174	.3392	.2587
2	.2957	.3511	.3326	.3547	.2957	.3361	.2402
3	.3137	.3511	.3142	.3547	.2957	.3361	.2402
4	.3179	.3326	.2772	.3361	.2957	.2987	.2402
5	.3031	.3174	.3142	.3361	.2957	.3018	.2402
6	.2913	.2987	.3142	.3174	.3142	.2829	.2402
7	.2791	.2987	.3142	.2987	.2829	.2641	.2614
8	.2867	.3018	.2987	.3395	.2614	.2641	.2614
9	.2867	.3018	.2801	.3018	.2641	.2641	.2452
10	.2913	.3174	.3174	.3206	.3395	.2641	.2614
11		.4668	.5041	.5093	.4715	.3584	.4668
12		.6722	.7468	.7545	.7468	.4715	.6161
13	.7577	.7468	.7468	.7733	.7468	.5041	.6348
14	.8215	.7842	.7468	.6908	.7468	.5415	.6348
15	.8215	.8316	.7468	.679	.7468	.5601	.6535
16	.724	.8215	.7468	.7468	.7655	.5658	.6348
17	.7316	.8402	.7655	.8215	.7468	.5601	.7392
18	.8871	.8589	.9055	.8316	.8686	.6348	.8131
19	.9795	.9335	.9055	.8871	.8871	.7095	.8131
20	.9055	.8686	.8686	.9055	.8871	.7023	.7762
21	.7207	.6908	.6908	.5975	.7023	.5914	.4668
22	.4066	.3881	.3881	.3881	.4108	.3881	.2957
23	.3696	.3582		.3361	.3292	.2772	.2957
24	.3361	.3511	.3734	.3547	.3547	.3361	.2614
Max	.9795	.9335	.9055	.9055	.8871	.7095	.8131
Min	.2791	.2987	.2772	.2987	.2614	.2641	.2402
Avg	.5201	.5348	.5336	.5246	.5155	.4230	.4413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 202 / Station Transformer No I SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0305	.0171	.0154	.0171	.0297	.0171
2	.0171	.0305	.0171	.0154	.0171	.0297	.0171
3	.0206	.0305	.0171	.0154	.0171	.0305	.0171
4	.0206	.0156	.0171	.0156	.0171	.0152	.0171
5	.0206	.0156	.0171	.0156	.0171	.0152	.0171
6	.0206	.0156	.0171	.0162	.0171	.0152	.0171
7	.0137	.0162	.0171	.0168	.0173	.0162	.0171
8	.0069	.0171	.0171	.0166	.0171	.0162	.0171
9	.0069	.0179	.0173	.0156	.0171	.017	.0171
10	.0137	.0187	.0187	.0171	.0171	.0171	.0171
11	.0373	.0373	.0373	.037	.0377	.0191	.0181
12	.0373	.0747	.0747	.0572	.0566	.0381	.0381
13	.0747	.0747	.0747	.0572	.0747	.0572	.056
14	.0747	.0934	.2614	.0754	.0754	.0747	.056
15	.0747	.0924	.0747	.0754	.0754	.0747	.056
16	.0747	.0732	.0747	.0747	.0754	.0747	.0747
17	.0747	.0739	.0747	.0747	.0739	.0747	.0739
18	.0924	.0739	.0747	.0747	.0924	.0747	.0739
19	.1254	.0924	.0905	.0914	.0914	.0905	.1075
20	.124	.1254	.1063	.1075	.1075	.1063	.1063
21	.1086	.0739	.0732	.0732	.1097	.0905	.056
22	.0309	.0343	.0305	.0343	.0366	.0343	.0305
23	.0305	.0343		.0171	.0297	.0343	.0293
24	.0137	.0305	.0171	.0152	.0171	.0297	.0171
Max	.1254	.1254	.2614	.1075	.1097	.1063	.1075
Min	.0069	.0156	.0171	.0152	.0171	.0152	.0171
Avg	.0471	.0497	.0538	.0427	.0469	.0448	.0402

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 203 / Station Transformer No II SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0523	.0566	.0754	.0554	.0572	.0566	.0377
2	.0444	.0566	.0566	.0554	.0572	.0566	.0566
3	.0457	.0566	.0566	.0554	.0572	.0566	.056
4	.0528	.0566	.0572	.056	.0572	.0377	.056
5	.0453	.0566	.0572	.056	.0572	.0377	.056
6	.0533	.0566	.0572	.0566	.0572	.0377	.056
7	.061	.7356	.0566	.0754	.0762	.0377	.0373
8	.061	.0514	.056	.0762	.0572	.0377	.0373
9	.061	.0572	.0754	.0762	.0762	.0572	.0566
10	.0762			.0943	.0953	.0747	.0572
11	.1509	.1307	.1132	.1698	.1307	.0943	.1143
12	.2241	.2054	.1886	.1886	.1886	.132	.168
13	.2241	.2054	.1886	.1886	.2241	.1307	.1867
14	.2241	.2054	.2054	.2054	.2241	.1494	.1848
15	.2241	.2054	.2054	.2054	.2241	.168	.1848
16	.2241	.2033	.2054	.2054	.2241	.1663	.1848
17	.2054	.2241	.2054	.2241	.1867	.1848	.1848
18	.2054	.1848	.1867	.1848	.2033	.1646	.2033
19	.2195	.2195	.2195	.2195	.2172	.2149	.2012
20	.2195	.2195	.2195	.2172	.2378	.2172	.1829
21	.0168	.2195	.181	.2012	.2172	.1991	.1829
22	.0953	.0943	.0943	.1294	.1132	.1307	.0572
23	.0566	.0754		.0762	.0762	.0572	.0572
24	.0528	.0566	.0754	.0554	.0566	.0566	.0566
Max	.2241	.7356	.2195	.2241	.2378	.2172	.2033
Min	.0168	.0514	.056	.0554	.0566	.0377	.0373
Avg	.1207	.1580	.1289	.1303	.1322	.1065	.1107

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 207 / Zero Mile

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6783	.6859	.6588	.6733	.6556	.6485
2	.6859	.6783	.6859	.6588	.6733	.6556	.6241
3	.6927	.6783	.6859	.6588	.6733	.6556	.6241
4	.679	.639	.6859	.6588	.6485	.6485	.6241
5	.6996	.639	.6859	.6344	.6661	.6415	.6241
6	.6516	.639	.6859	.6344	.6241	.6173	.6241
7	.6722	.639	.703	.6344	.6485	.6173	.6241
8	.679	.6154	.703	.6516	.6859	.6173	.6241
9	.6996	.6539	.703	.6554	.703	.6226	.6173
10	.7407	.7316	.8131	.7577	.7537	.6226	.6859
11	.8779	.823	.924	.8779	.788	.6554	.8596
12	.8779	.9328	.9795	.8962	.9055	.6554	.8779
13	.8779	.9145	.9412	.9145	.8779	.6859	.8507
14		.9511	.9231	.8869	.8688	.6859	.8238
15	.8779	.9465	.9328	.9145	.8688	.6859	.8962
16	.9511	.929	.9511	.9511	.8869	.6859	.8417
17	.9511	.8669	.9511	.9511	.8688	.6859	.7712
18	.8059	.8238	.7973	.7888	.7796	.6859	.7362
19	.7282	.7712	.7455	.7628	.7619	.6859	.7362
20	.7202	.7202	.7373	.7282	.7362	.6859	.6859
21	.6952	.7202	.7202	.7202	.6859	.6661	.6539
22	.6783	.7202	.6952	.7164	.6859	.6661	.6613
23	.6783	.6859		.691	.6783	.6485	.6443
24	.6927	.6783	.6859	.6588	.6661	.6556	.6485
Max	.9511	.9511	.9795	.9511	.9055	.6859	.8962
Min	.6516	.6154	.6859	.6344	.6241	.6173	.6173
Avg	.7521	.7531	.7836	.7526	.7420	.6578	.7087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 209 / 11 KV Mure Memorial

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0566	.0934	.0934	.0934	.0747	.0747
2	.0747	.0566	.0934	.0934	.0747	.0747	.0747
3	.0739	.0566	.0934	.0934	.0747	.0747	.0739
4	.0747	.0566	.0934	.0934	.0747	.0747	.0739
5	.0739	.0566	.0943	.0747	.0934	.0747	.0747
6	.0652	.0562	.0934	.0732	.0924	.0554	.0747
7	.0739	.0747	.0943	.0732	.0934	.0554	.0747
8	.0822	.0943	.112	.0934	.0924	.0739	.0739
9	.0971	.0934	.1109	.0924	.1132	.0724	.0934
10	.1509	.1307	.1494	.1334	.1715	.0934	.1334
11		.1886	.1698	.1715	.1886	.0914	.1698
12	.2195	.2614	.2641	.1905	.2075	.0905	.1698
13	.2452	.2427	.2641	.1905	.2075	.0905	.1698
14		.2427	.2641	.1905	.2075	.0905	.1698
15	.2263	.2263	.2641	.1905	.2075	.0905	.1698
16	.2452	.2263	.2641	.1905	.2075	.0914	.1886
17	.2641	.2241	.2829	.1905	.1698	.0924	.1509
18	.1509	.2263	.132	.1132	.1132	.0934	.1132
19	.1334	.1524	.132	.132	.1132	.1143	.1132
20	.1143	.1334	.112	.132	.1143	.1143	.1132
21	.1097	.1143	.1132	.1132	.0943	.0953	.0953
22	.0934	.1143	.0943	.0934	.0943	.0943	.0754
23	.0754	.0943		.0934	.0747	.0747	.0747
24	.083	.0566	.0943	.0934	.0934	.0747	.0747
Max	.2641	.2614	.2829	.1905	.2075	.1143	.1886
Min	.0652	.0562	.0934	.0732	.0747	.0554	.0739
Avg	.1273	.1348	.1513	.1250	.1278	.0843	.1113

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162015 / 11 KV Regent Switching

Feeder No / Name : 211 / 11KV Variety Chowk

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0533	.0566	.0572	.0572	.0572	.0566	.0373
2	.0533	.0566	.0572	.0572	.0381	.0566	.0381
3	.0457	.0566	.0572	.0572	.0381	.0566	.0381
4	.0528	.0377	.0572	.0381	.0381	.0377	.0381
5	.0377	.0381	.0572	.0381	.0381	.0381	.0381
6	.0377	.0381	.0381	.0381	.0381	.0381	.0377
7	.0453	.0381	.0381	.0381		.0381	.0377
8	.0528	.0572	.0572	.0572	.0381	.0381	.0381
9	.0604	.0572	.0572	.0566	.0566	.0381	.0377
10	.0597	.056	.0572	.0572	.0566	.0566	.0572
11	.0572	.056	.0572	.0572	.0566	.0572	.0566
12	.0566	.0747	.0762	.0762	.0754	.0572	.0566
13	.0566	.0934	.0762	.0953	.0747	.0566	.0381
14	.0747	.0934	.0754	.0747	.0747	.056	.0572
15	.0747	.056	.0762	.0747	.0934	.056	.0572
16	.0747	.0943	.0572	.0754	.0943	.0566	.0572
17	.056	.0754	.0572	.0566	.0754	.0566	.0747
18	.0566	.0943	.0754	.0747	.0754	.056	.0747
19	.0732	.0943	.0762	.0754	.0754	.0566	.0572
20	.0754	.0762	.0747	.0943	.0762	.0566	.0572
21	.0934	.0943	.0943	.0754	.0762	.0566	.0377
22	.0762	.0572	.0572	.0566	.0762	.0566	.0377
23	.0754	.0762		.0572	.0762	.0381	.0381
24	.0457	.0572	.0566	.0572	.0572	.0566	.0381
Max	.0934	.0943	.0943	.0953	.0943	.0572	.0747
Min	.0377	.0377	.0381	.0381	.0381	.0377	.0373
Avg	.0602	.0660	.0628	.0623	.0633	.0512	.0474

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 201 / 11 KV YASHWANT STEDIUM SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4668	.4715	.4715	.4668	.4338	
2	.4715	.4668	.4715	.415	.4668	.4338	
3	.415	.4668	.415	.415	.3734	.3772	
4	.3772	.3734	.415	.3772	.3734	.3772	
5	.3772	.2801	.3772	.3772	.3734	.3772	
6	.3772	.2772	.3772	.3772	.3734	.3772	.3206
7	.3772	.3696	.3772	.3772	.3734	.3772	.3772
8	.415	.3696	.415	.4715	.3734	.3395	.3961
9	.4715	.3734	.415	.3772	.4668	.3772	.415
10	.4904	.4715	.462	.4715	.4715	.3772	.415
11	.5658	.6602	.5544	.5658	.5658	.3772	
12	.6602	.6602	.5544	.5658	.4715	.4715	
13	.6602	.6602	.6535	.6602	.5658	.4715	
14	.6602	.6602	.6468	.6602	.5658	.4715	
15	.6602	.6602	.6468	.6602	.6602	.4715	.5658
16	.6602	.6602	.6468	.6602	.6602	.4715	.5658
17	.6535	.6602	.6602	.6535	.6602	.415	.4715
18	.5601	.6602	.5658	.5601	.6224	.415	.5658
19	.6535	.6602	.6602	.5601	.6036	.4338	.5658
20	.5601	.6602	.6602	.5601	.6036	.4715	.5093
21	.5544	.6602	.5658	.5601	.6036	.4527	.415
22	.5544	.4715	.5658	.4668	.5281	.415	.4527
23	.5658	.4715	.4715	.4668	.4715	.3772	
24	.415	.462	.4715	.4715	.4668	.4715	
Max	.6602	.6602	.6602	.6602	.6602	.4715	.5658
Min	.3772	.2772	.3772	.3772	.3734	.3395	.3206
Avg	.5261	.5243	.5217	.5084	.5067	.4181	.4643

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 202 / 11 KV PUSHPAKUNJ FDR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.4668	.4715	.4715	.4668	.4338	.3772
2	.4715	.4668	.4715	.415	.4668	.4338	.3772
3	.415	.3734	.4715	.3772	.3734	.3772	.3772
4	.415	.3734	.3772	.3772	.3734	.3772	.3772
5	.415	.3696	.3772	.3772	.3734	.3772	.3772
6	.415	.3734	.3772	.3772	.3734	.3772	.3772
7	.4527	.462	.415	.3772	.3734	.3772	.3772
8	.415	.4668	.415	.415	.3734	.3772	.3772
9	.5658	.4668	.415	.4715	.5601	.4338	.415
10	.5658	.4715	.4108	.5658	.5658	.4715	.5658
11	.5658	.5658	.6535	.5658	.5658	.5281	
12	.6602	.5658	.6535	.5658	.6036	.4715	
13	.6602	.6602		.6602	.5658	.3772	
14	.6602	.6602	.5601	.6602	.5658	.3772	
15	.6602	.7545	.6468	.5658	.5658	.3772	.4715
16	.6602	.6602	.6468	.5676	.5658	.3772	.4715
17	.6535	.6036	.5658	.6535	.5658	.3772	.4715
18	.6535	.5658	.5658	.6535	.5658	.3772	.4715
19	.6535	.5093	.5658	.6535	.5281	.3772	.4715
20	.5601	.4715	.5658	.5601	.5281	.415	.4715
21	.5658	.415	.5658	.5601	.5093	.415	.4715
22	.4715	.3772	.4715	.4668	.5093	.415	.415
23	.4668	.4715	.5658	.4668	.4715	.3772	.3772
24	.4338	.4668	.4715	.4715	.4668	.4338	.3772
Max	.6602	.7545	.6535	.6602	.6036	.5281	.5658
Min	.415	.3696	.3772	.3772	.3734	.3772	.3772
Avg	.5387	.5016	.5087	.5123	.4949	.4055	.4234

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 203 / 11 KV PRESS FDR NON SHEDDABLE EXPRESS HV FEEDERS
 Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1307	.1698	.132	.1307	.132	.132
2		.1307	.1509	.0943	.1307	.132	.132
3		.112	.1509	.0943	.112	.0943	.1132
4		.0934	.132	.0943	.0934	.0943	.1132
5		.0934	.132	.0943	.0934	.0943	.1132
6		.112	.1132	.0943	.0934	.0943	.1132
7		.112	.1132	.0943	.112	.132	.1132
8		.112	.132	.132	.1307	.132	.1132
9		.1867	.132	.132	.1867	.132	.132
10	.1886	.1886	.1867	.2829	.2829	.132	.1509
11	.1886	.3206	.3734	.3584	.2829	.1509	
12	.415	.3772	.3734	.3772	.3395	.1509	
13	.3772	.4715	.5601	.3772	.2829	.1886	
14	.3772	.4715	.3696	.3772	.3772	.1886	
15	.3961	.3772	.3734	.3772	.3772	.1886	.2641
16	.415	.3772	.3696	.3772	.3772	.1886	.2829
17	.3696	.3772	.4715	.3734	.3772	.1886	.2829
18	.3696	.4715	.415	.3734	.2829	.1886	.2829
19	.3696	.3206	.2829	.2801	.2452	.1886	.2829
20	.2772	.2641	.1886	.1867	.2452	.1886	.1886
21	.1886	.2829	.1886	.1867	.2075	.1509	.1886
22	.1848	.2075	.1886	.1867	.1886	.132	.132
23	1.9404	.2075	.1886	.1307	.1509	.132	.132
24	.2263	.1886	.1886	.1509	.1294	.1509	.132
Max	1.9404	.4715	.5601	.3772	.3772	.1886	.2829
Min	.1848	.0934	.1132	.0943	.0934	.0943	.1132
Avg	.4189	.2494	.2477	.2232	.2179	.1477	.1698

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 204 / 11 KV VIJAYANAND FDR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6535	.7922	.6602	.6535	.6224	.5281
2		.6535	.7545	.6036	.6535	.6224	.5093
3		.5601	.6602	.5658	.5601	.5658	.5093
4		.5601	.6602	.5658	.5601	.5658	.4715
5		.5601	.6602	.5658	.5601	.5281	.4715
6		.5601	.5658	.5658	.5601	.5281	.4715
7		.5658	.5847	.5658	.5601	.4904	.5281
8		.5601	.6036	.5658	.5601	.5093	.5658
9		.6602	.6602	.6602	.6535	.5658	.6602
10	.6602	.7545	.7392	.7545	.7545	.6602	.7545
11	.6602	1.0374	.9335	.9431	.9431	.6602	
12	.9431	1.1317	1.1203	.9431	1.0374	.6602	
13	.9431	1.1317	1.1317	1.1317	1.0374	.6602	
14	.9431	1.1317	1.1088	1.1317	1.0374	.6602	
15	.9431	1.226	1.1203	1.1317	1.0374	.5658	.8488
16	1.226	1.1317	1.1088	1.1317	1.0374	.5658	.8488
17	1.1203	1.1317	1.226	1.1203	1.0374	.5658	.8488
18	1.0269	1.1317	1.1317	1.0269	.9997	.5658	.8488
19	.924	1.0751	1.1317	1.0269	.9997	.7167	.7545
20	1.1088	1.0374	.9431	.9335	.8865	.6602	.7545
21		.8488	.8488	.7468	.7922	.6602	.6602
22	.8488	.7545	.7545	.7468	.7167	.6602	.5658
23	.7468	.7545	.7545	.6535	.6979	.6602	.4715
24	.4715	.6535	.8488	.6602	.6535	.6224	.5658
Max	1.226	1.226	1.226	1.1317	1.0374	.7167	.8488
Min	.4715	.5601	.5658	.5658	.5601	.4904	.4715
Avg	.8976	.8444	.8685	.8084	.7912	.6059	.6319

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162262 / 11 KV CONGRESS NGR SW/STN

Feeder No / Name : 205 / 11kv Chhoti Dhantoli

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0924	.132	.0943	.0924	.1132	.0943
2		.0924	.132	.0943	.0934	.1132	.0943
3		.0924	.1132	.0943	.0934	.0943	.0754
4		.0924	.1139	.0943	.0747	.0943	.0754
5		.0739	.0943	.0943	.0739	.0943	.0754
6		.0924	.0943	.0943	.0747	.0943	.0754
7		.0747	.0943	.0943	.0934	.0754	.0566
8		.0934	.0754	.0943	.0934	.0754	.0566
9		.0924	.0943	.0943	.0934	.0754	.1132
10		.0943	.112	.1509		.0943	.132
11	.132	.1509	.1307	.1698	.0943	.0943	
12	.2263	.1886	.1867	.1886	.1886	.0943	
13	.2263	.1886	.1307	.1886	.1509	.0943	
14	.2452	.1886	.1867	.1886	.1509	.0943	
15	.2263	.1886	.1867	.1886	.1886	.0943	.132
16	.2263	.1886	.1848	.1886	.1886	.0943	.132
17	.1848	.2075	.1886	.1848	.1886	.0943	.132
18	.1848	.2263	.1886	.1848	.1698	.0943	.132
19		.1886	.1509	.1294	.1698	.0943	.0943
20	.1294	.1509	.0943	.0934	.1509	.0948	.132
21	.1294	.1509	.132	.1109	.1132	.0943	.0943
22	.1294	.1509	.132	.0924	.1132	.0943	.0943
23	.0924	.1509	.0943	.0924	.1132	.0943	.0943
24	.3018	.0924	.1509	.0943	.0924	.132	.0943
Max	.3018	.2263	.1886	.1886	.1886	.132	.132
Min	.0924	.0739	.0754	.0924	.0739	.0754	.0566
Avg	.1873	.1376	.1331	.1290	.1242	.0951	.0990

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 201 / 11 KV Deo Nagar SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.463	.4715	.4287	.4294	.4481	.4108
2	.4527	.463	.4668	.4287	.4294	.4481	.4108
3	.4527	.4287	.4481	.3429	.4066	.4294	.3734
4	.415	.4287	.4481	.3429	.4066	.4294	.3734
5	.415	.4287	.4108	.3429	.3696	.4108	.3734
6	.415	.4287	.4108	.3429	.3696	.4108	.3734
7	.3772	.3772	.3921	.3429	.3361	.3734	.4108
8	.415	.3772	.4108	.3429	.3734	.3734	.4108
9	.4338	.3772	.4294	.3429	.4066	.3734	.4108
10	.4527	.3772	.4294	.4668	.4481	.4294	.4108
11	.4854	.4668	.4481	.4481	.4572	.4108	.4481
12	.4668	.5041	.4668	.4668	.4572	.439	.4668
13	.4668	.5041	.4668	.4854	.4572	.4207	.4294
14	.4668	.5228	.4668	.4668	.4668	.3761	.4108
15	.4668	.5228	.4668	.4854	.6908	.3506	.4108
16	.4294	.5041	.4668	.4668	.4572	.3881	.4108
17	.4854	.5041	.5228	.4854	.4854	.362	.4481
18	.4801	.5281	.4801	.5228	.4668	.4108	.4287
19	.5144	.5658	.5144	.5544	.5601	.4481	.4287
20	.5487	.5658	.5144	.5228	.5601	.4668	.4287
21	.5144	.5658	.5144	.499	.5228	.4668	.4287
22	.5144	.5658	.5144	.462	.5041	.4668	.4115
23	.5144	.5658	.4801	.4668		.4668	.4572
24	.415	.463	.5093	.463	.4481	.4481	.4294
Max	.5487	.5658	.5228	.5544	.6908	.4668	.4668
Min	.3772	.3772	.3921	.3429	.3361	.3506	.3734
Avg	.4612	.4791	.4646	.4383	.4569	.4187	.4165

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 202 / 11 KV NERI NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2241	.1886	.1848	.1867	.1867
2	.1886	.1886	.2054	.1886	.1848	.1867	.1867
3	.1886	.1886	.2054	.1886	.1848	.1867	.1867
4	.1886	.1886	.1867	.1886	.1867	.1867	.1867
5	.1886	.1715	.1867	.1715	.1867	.1867	.1867
6	.1886	.1715	.1867	.1715	.1867	.1867	.1867
7	.1886	.1715	.1867	.1715	.1867	.1867	.1867
8	.2263	.1715	.2241	.1715	.2054	.1867	.1867
9	.2263	.1886	.2614	.1715	.2054	.1867	.1867
10	.3772	.3429	.462	.3921	.2054	.1867	.2801
11	.462	.4251	.4805	.4108	.2218	.168	.2801
12	.4251	.4251	.4805	.4108	.2772	.362	.3174
13	.4066	.4251	.462	.4294	.2427	.1867	.2957
14	.3696	.4251	.4251	.3361	.2772	.181	.2772
15	.3696	.4251	.4251	.3734	.2427		.3142
16	.4251	.4435	.4066	.3734	.2033	.1867	.3142
17	.4251	.4066	.4435	.3696	.2033	.1734	.2772
18	.3086	.3206	.2915	.2772	.1867	.1867	.2058
19	.2229	.2829	.2229	.2402	.2241	.1867	.1715
20	.2229	.2641	.2229	.2241	.2241	.1867	.1715
21	.2058	.2452	.2058	.2033	.2241	.1867	.1715
22	.2058	.2452	.1886	.1867	.1867	.1867	.1715
23	.1886	.2427	.1886	.1848		.1867	.1715
24	.3395	.1886	.2263	.1886	.1848	.1867	.1867
Max	.462	.4435	.4805	.4294	.2772	.362	.3174
Min	.1886	.1715	.1867	.1715	.1848	.168	.1715
Avg	.2803	.2807	.2916	.2589	.2094	.1927	.2203

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 203 / 11KV Orange City SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5144	.6535	.5144	.5601	.5601	.4668
2	.5658	.5144	.6348	.5144	.5544	.5601	.4481
3	.5281	.5144	.6348	.4801	.5175	.5601	.4481
4	.5281	.4287	.5975	.463	.5041	.4668	.4481
5	.5281	.4287	.5975	.463	.4805	.4668	.4108
6	.4715	.4287	.4854	.4287	.4668	.4668	.4108
7	.4715	.4287	.4668	.4287	.4668	.4481	.4108
8	.5093	.4287	.5041	.4287	.4854	.4668	.5041
9	.4715	.4287	.5041	.463	.4854	.5041	.5601
10	.5281	.4801	.5228	.5601	.5228	.5228	.5601
11	.5975	.5601	.5601	.5601	.5975	.4854	.5975
12	.5601	.5601	.5601	.5601		.5373	.5544
13	.6161	.5601	.5975	.5975	.6283	.4668	.5175
14	.6348	.6161	.5975	.5788	.5975	.4715	.462
15	.6348	.6348	.5975	.5975	.5914	.4298	
16	.6348	.6283	.5601	.5601	.5975	.4572	
17	.5601	.6099	.6535	.5975	.6099	.4252	.4668
18	.5144	.6413	.5144	.6161	.5975	.4668	.463
19	.5487	.6413	.5658	.6161	.6535	.5228	.5144
20	.6001	.6602	.6001	.6535	.6348	.5601	.5144
21	.6001	.6602	.6001	.6468	.6348	.5601	.5144
22	.6344	.7167	.6001	.6468	.6535	.5601	.4973
23	.6173	.7545	.6516	.6348		.5228	.4287
24	.4527	.5316	.6602	.583	.6161	.5601	.4854
Max	.6348	.7545	.6602	.6535	.6535	.5601	.5975
Min	.4527	.4287	.4668	.4287	.4668	.4252	.4108
Avg	.5572	.5571	.5800	.5497	.5662	.5020	.4856

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 204 / 11KV Jail SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0514	.0747	.0514	.0739	.0934	.0747
2	.0943	.0514	.0747	.0514	.0747	.0934	.9896
3	.0943	.0514	.0747	.0514	.0747	.2614	.0934
4	.0943	.0514	.0747	.0514	.0747	.0934	.0747
5	.0943	.0514	.0747	.0514	.0747	.0934	.0747
6	.0754	.0343	.0747	.0343	.0747	.0747	.0747
7	.0566	.0343	.0747	.0343	.056	.0373	.0747
8	.0754	.0343	.056	.0514	.0554	.0373	.0373
9	.0943	.0857	.0934	.0857	.0747	.0747	.0747
10	.0943	.0857	.0924	.112	.0934	.0747	.0934
11	.0934	.0924	.0924	.112	.0924	.0934	.0934
12	.0934	.0924	.0739	.112	.0914	.0905	.0924
13	.0924	.0924	.0739	.112	.112	.0934	.0924
14	.0924	.0924	.0739	.0934	.0924	.0754	.0739
15	.0924	.0924	.0739	.0934	.112	.0914	.0554
16	.0739	.0554	.0554	.0747	.0924	.0895	.0554
17	.0747	.0554	.0739	.0924	.0934	.0914	.0554
18	.0514	.0943	.0514	.0739	.0934	.0747	.0514
19	.0686	.0943	.0686	.0924	.0934	.0747	.0686
20	.0686	.0943	.0686	.0747	.0934	.0747	.0686
21	.0514	.0943	.0686	.0747	.0747	.0747	.0686
22	.0686	.0943	.0686	.0747	.0934	.0934	.0686
23	.0686	.0943	.0514	.0747		.0747	.0686
24	.2452	.0514	.0754	.0514	.0739	.0934	.0747
Max	.2452	.0943	.0934	.112	.112	.2614	.9896
Min	.0514	.0343	.0514	.0343	.0554	.0373	.0373
Avg	.0876	.0717	.0723	.0742	.0841	.0883	.1104

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 205 / 11KV Kanchpura SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3429	.7842	.6859	.7095	.6535	.7095
2	.3395	.3429	.7468	.6001	.6908	.6535	.6535
3	.3395	.3429	.7095	.6001	.6722	.6535	.6535
4	.3018	.3429	.7095	.6001	.6535	.6535	.5601
5	.3018	.3429	.6722	.6001	.6535	.5975	.5601
6	.3395	.3429	.6722	.6001	.6535	.5975	.5601
7	.3772	.3429	.6908	.6001	.6161	.5788	.6348
8	.3395	.2915	.7468	.6001	.6161	.6348	.6535
9	.3772	.3429	.7095	.6344	.6908	.6535	.6722
10	.4527	.3601	.7842	.7468	.8029	.6535	.7468
11	.499	.4108	.8215	.8402	.8029	.6908	.8029
12	.4805	.6535	.8402	.7842	.7392	1.0048	.7468
13	.4854	.8215	.8029	.7842	.7947	.6068	.6722
14	.462	.8215	.7842	.7842	.7499	.6219	.6161
15	.462	.8215	.8402	.7842	.7762	.567	.6161
16	.5228	.8402	.8402	.8402	.7655	.5487	.6161
17	.5228	.8316	.8962	.8029	.7762	.5729	.6161
18	.4287	.7545	.6859	.8215	.7468	.5975	.6001
19	.3944	.7922	.823	.8215	.8215	.6908	.6687
20	.3944	.8488	.7716	.8402	.8402	.7468	.6687
21	.3944	.8488	.7716	.7947	.8215	.7468	.6173
22	.3601		.7716	.7842	.8029	.7468	.6173
23	.3601	.9054	.7716	.7842		.7468	.583
24	.2641	.3429	.8488	.7373	.7468	.7468	.7095
Max	.5228	.9054	.8962	.8402	.8402	1.0048	.8029
Min	.2641	.2915	.6722	.6001	.6161	.5487	.5601
Avg	.3975	.5690	.7706	.7280	.7367	.6652	.6481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 162263 / 11KV AJANI SWITCHING STATION

Feeder No / Name : 206 / 11 KV Sai Mandir SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5658	.5316	.5975	.5144	.5601	.5601	.5601
2	.5658	.5316	.5975	.5144	.5601	.5601	.5601
3	.5658	.5144	.5601	.5144	.5601	.5601	.5601
4	.5658	.5144	.5601	.5144	.5601	.5601	.5601
5	.5281	.5144	.5601	.5144	.5601	.5228	.5228
6	.5281	.5144	.5601	.4801	.5601	.5228	.5228
7	.5281	.5144	.5601	.4801	.5601	.5041	.5228
8	.5658	.5144	.5601	.5144	.5601	.5228	.5601
9	.6413	.5487	.6161	.5144	.6161	.5601	.5601
10	.6413	.5487	.6535	.6348	.6348	.5228	.5601
11	.7468	.6535	.7095	.7468	.6722	.5601	.6535
12	.7468	.7095	.7468	.5601	.7468	.5258	.6348
13	.7095	.7468	.7468	.7095	.7133	.5959	.6283
14	.6838	.7468	.7392	.7095	.6838	.567	.6161
15	.6838	.7095	.7468	.7095		.5975	.5975
16	.7468	.7468	.7468	.7468	.6722	.6335	.5975
17	.7468	.7468	.7468	.7468	.6908	.5975	.6348
18	.6859	.7167	.6344	.7468	.7468	.6348	.6001
19		.7922	.6859	.7468	.7468	.6535	.6001
20	.6859	.7545	.6859	.7468	.7468	.6535	.583
21	.6344	.7167	.6687	.7095	.7095	.6535	.5487
22	.6344	.6602	.6344	.6908	.6535	.6161	.5144
23	.583	.6413	.583	.6161		.5601	.463
24	.4904	.5316	.6036	.5487	.5601	.5601	.5601
Max	.7468	.7922	.7468	.7468	.7468	.6535	.6535
Min	.4904	.5144	.5601	.4801	.5601	.5041	.463
Avg	.6293	.6300	.6460	.6221	.6397	.5752	.5717

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 201 / 11 KV HAMP YARD

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.0242	1.1523	1.1157	.9694	.9145	.8962
2	1.0059	.9877	1.0974	1.0791	.5304	.8779	.8779
3	.9877	.9511	1.0425	1.0059	.8779	.823	.8413
4	.9145	.9145	.9511	1.0059	.8596	.7865	.7316
5	.8596	.8779	.8413	.8048	.8413	.7499	.7316
6	.7577	.7682	.8131	.7682	.7499	.7316	.6584
7	.7865	.8048	.8779	.8779	.7499	.695	.7316
8	.9328	.8596	.9979	.9511	.7602	.695	.8779
9		.9997	.9979	.8779	.8507	.8488	.9431
10	1.1088	1.0974		1.0059	1.086	.8962	1.0349
11	1.2323	1.2071	1.1765	1.0974	1.1222	.9054	1.086
12	1.3203	1.1883	1.2308	1.0425	1.1403	.8865	1.0317
13	1.2883	1.226	1.1584	1.0425	1.1222		.9997
14	1.226	1.2637	1.2308	1.0974	1.086		.905
15	1.2826	1.358	1.267	1.0425	1.0317		.9997
16	1.3203	1.1706	1.2127	1.0425	1.0317		.9431
17	1.1706	1.2637	1.1523	1.0608	1.1317	.695	.8962
18	1.0974	1.2437	1.2071	1.0974	1.094	.7499	.9694
19	1.1888	1.3717	1.2803	1.1157	1.226	.9511	1.0974
20	1.262	1.3717	1.4083	1.1706	1.2826	.9694	1.0608
21	1.1706	1.3717	1.3169	1.0974	1.226	.9877	1.0425
22	1.2254	1.39	1.3717	1.0974	1.226	.9694	1.0242
23	1.1523	1.3535	1.2803	1.1157	1.0059	1.0242	.9511
24	1.1523	1.0608	1.262	1.2071	1.0425	.9877	.9694
Max	1.3203	1.39	1.4083	1.2071	1.2826	1.0242	1.0974
Min	.7577	.7682	.8131	.7682	.5304	.695	.6584
Avg	1.1088	1.1302	1.1446	1.0341	1.0018	.8572	.9292

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 202 / 11KV Chichabhawan

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7888	.7202	.7716	.7716	.7716	.7545	.6687
2	.7373	.6859	.703	.7373	.7202	.7202	.6687
3	.703	.6516	.6516	.6687	.703	.6859	.6173
4	.6859	.6344	.6001	.6859	.703	.6516	.6001
5	.6687	.6173	.583	.6344	.6687	.6344	.583
6	.7023	.583	.6653	.6516	.6687	.583	.6001
7	.703	.6516	.6173	.703	.7202	.583	.6173
8	.6687	.6516	.6468	.6687	.6687	.6344	.6859
9	.7716		.6283	.6516	.6344	.6516	.7716
10	.6859		.5658	.6344	.7202	.6859	.7888
11	.6859		.5658	.6344	.6859	.7373	.6516
12	.7202			.6516	.6859	.6859	.6344
13	.6859	.7888	.5316	.6173	.6687		.5658
14	.7733	.703	.5487	.583	.6344		.5658
15	.6036	.6516	.583	.6173	.6173		.6036
16	.6979	.6516	.583	.6344	.6173		.6602
17	.6173	.6173	.5658	.6344	.6344	.6001	.6001
18	.6516	.6173	.583	.7716	.7733	.6173	.7373
19	.7888	.7716	.9088	.8402	.8916	.7888	.8916
20	.823	.8059	.9259	.9088	.8745	.7716	.8573
21	.8573	.7888	.9088	.8573	.8745	.7716	.823
22	.8402	.823	.8916	.8573	.8402	.7545	.7373
23	.8402	.8573	.9088	.8573	.8402	.7545	.703
24	.8402	.7373	.7716	.823	.8059	.8145	.703
Max	.8573	.8573	.9259	.9088	.8916	.8145	.8916
Min	.6036	.583	.5316	.583	.6173	.583	.5658
Avg	.7309	.7005	.6830	.7123	.7260	.6940	.6806

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 204 / 11KV AJNI O/G

Feeder KV- 11 / INCOMING

NON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8861	2.0748	2.5463	2.3954	2.3011	2.1399	1.9805
2	1.8107	2.037	2.3765	2.2445	2.1125	2.1691	1.8673
3	1.7353	1.9805	2.2445	2.1691	2.0559	2.1313	1.8861
4	1.6975	1.8484	2.1691	2.2257	2.0936	2.0936	1.7918
5	1.7164	1.7164	2.0936	2.0182	2.0748	1.8861	.6413
6	1.6448	1.6787	1.9959	1.9805	1.8861	1.7918	1.7541
7	1.8484	1.773	2.1313	2.0559	2.0559	1.8107	1.8107
8	1.7918	1.7164	2.0144	2.0748	1.9616	1.8296	1.9427
9	1.9239	1.8861	2.1992	2.2068	2.1125	1.9805	2.2068
10	2.2592	2.1879	2.7161	2.4832	2.3577	2.037	2.4709
11	2.584	2.4897	2.9801	2.6783	2.6406	2.0748	2.5652
12	2.6406	3.0178	3.0367	2.6595	2.6972	2.0936	2.4897
13	2.6406	3.0178	2.9424	2.8481	2.6406		2.3011
14	2.5652	2.8292	2.8858	2.6513	2.5274		2.1879
15	2.6406	3.0933	3.0556	2.7633	2.5652		2.3011
16	2.7349	2.9613	3.0556	2.8104	2.4897		2.2634
17	2.6217	3.0933	3.0367	2.7915	2.5463	1.8296	2.2822
18	2.5463	2.8292	2.9424	2.8481	2.6217	1.9993	2.32
19	2.5652	2.9424	3.0933	2.9047	2.8858	2.3011	2.5652
20	2.5766	2.9235	3.1121	2.8292	2.9047	2.3954	2.5086
21	2.4897	2.9235	2.9801	2.6217	2.7349	2.4331	2.452
22	2.4709	2.9235	2.9801	2.6595	2.7349	2.3765	2.3011
23	2.2822	2.9613	2.8104	2.6029	2.4897	2.3577	2.1125
24	2.037	2.1313	2.6783	2.6029	2.452		2.1691
Max	2.7349	3.0933	3.1121	2.9047	2.9047	2.4331	2.5652
Min	1.6448	1.6787	1.9959	1.9805	1.8861	1.7918	.6413
Avg	2.2379	2.4598	2.6699	2.5052	2.4143	2.0911	2.1321

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 205 / 11 KV NAVJEEVAN COLONY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.6722	.6401	.6219	.6348	.567	.5601
2	.5487	.6348	.6219	.5853	.5975	.5601	.5228
3	.5304	.5975	.6401	.5853	.5975	.5415	.5228
4	.4938	.5601	.6036	.567	.5601	.5415	.5041
5	.4755	.5415	.5304	.5093	.5601	.5228	.4668
6	.4435	.4854	.5175	.4572	.4668	.4481	.4294
7	.5304	.5041	.5304	.5121	.5228	.4668	.4668
8	.4938	.5228	.5175	.5304	.4938	.4668	.5415
9	.5601	.6224	.5359	.5487	.5487	.5415	.5487
10	.5853	.5975	.6036	.567	.5853	.5121	.6219
11	.6348	.6224	.6036	.5304	.7133	.5093	.5487
12	.6348	.5601	.6036	.4938	.6219	.5281	.5304
13	.5788	.5975	.6219	.5121	.5304		.547
14	.6224	.5975	.6036	.5121	.567		.5175
15	.5975	.6224	.6401	.5304	.5487		.5281
16	.5788	.5975	.6219	.5487	.5853		.4715
17	.5601	.6224	.5601	.5601	.5658	.4854	.4755
18	.5975	.567	.5853	.5975	.6602	.4668	.5304
19	.6348	.6219	.6401	.6348	.6602	.5788	.6036
20	.7316	.6767	.7133	.7095	.7167	.6348	.6401
21	.7545	.7316	.6584	.7167	.7167	.6348	.6036
22	.8029	.7682	.7316	.7282	.7023	.6161	.6219
23	.7733	.7133	.7316	.7356	.7095	.6219	.567
24	.6219	.7095	.695	.6584	.6722		.5487
Max	.8029	.7682	.7316	.7356	.7167	.6348	.6401
Min	.4435	.4854	.5175	.4572	.4668	.4481	.4294
Avg	.5988	.6144	.6146	.5814	.6057	.5392	.5383

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 206 / 11 KV PANDEY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6401	.7655	.7865	.7133	.7282		.6348
2	.6219	.7095	.7316	.695	.6348	.6722	.5975
3	.6219	.6722	.7133	.6401	.6161	.6348	.5788
4	.6036	.6348	.6584	.6401	.6161	.5975	.5228
5	.5853	.5788	.6036	.567	.5788	.5415	.4854
6	.5914	.6161	.5729	.5853	.5788	.4854	.4854
7	.5853	.6161	.5853	.5853	.5788	.5041	.5041
8	.6401	.6036	.6099	.6401	.5611	.5228	.5975
9	.6908	.7356	.7023	.7133	.6219	.5975	.7059
10	.695	.7655	.8048	.7682	.7865	.6401	.7947
11	.8029	.8676	1.0425	.7316	.7682	.7167	.0732
12	.8402	.8215	.8596	.7865	.8048	.679	.7682
13	.8215	.8402	.823	.7682	.7316		.679
14	.8865	.8402	.8596	.7133	.7499		.6584
15	.8215	.8589	.7499	.7316	.7316		.6602
16	.9149	.8402	.823	.7499	.7316		.6413
17	.8215	.811	.8215	.8029	.7733	.5228	.6219
18	.8402	.8048	.8596	.8215	.8676	.6348	.7499
19	.9522	.823	.8962	1.0185	.9431	.8589	.7499
20	.9328	.9328	.8962	.8589	.9431	.7468	.7682
21	.9149	.8413	.8413	.8215	.8865	.7468	.4572
22	.9149	.8962	.8596	.7842	.8402	.7095	.695
23	.9694	.9511	.8596	.7842	.7655	.7499	.6767
24	.7316	.8029	.8413	.7865	.7655		.6401
Max	.9694	.9511	1.0425	1.0185	.9431	.8589	.7947
Min	.5853	.5788	.5729	.567	.5611	.4854	.0732
Avg	.7684	.7762	.7834	.7378	.7335	.6423	.6144

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 207 / 11 KV Wireless

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4755	.4572	.4755	.4572	.3841	.3841
2	.3841	.439	.439	.439	.4024	.3841	.3475
3	.3841	.4024	.439	.4207	.4024	.362	.3658
4	.3658	.3841	.4207	.439	.3841	.362	.3475
5	.3475	.3841	.4024	.4207	.3841	.362	.3475
6	.3696	.4024	.4251	.3841	.3658	.3292	.3109
7	.3658	.3658	.3841	.3921	.3841	.3292	.3109
8	.3841	.3841	.3696	.3921	.3734	.2926	.3475
9	.4108	.4527	.4251	.3841	.3921	.3361	.3921
10	.3881	.4207	.4163	.4066	.3921	.3734	.4024
11	.4854	.4527	.4481	.439	.4481	.3961	.4251
12	.4668	.4854	.4854	.439	.4668	.3961	
13	.4294	.4854	.4854	.439	.4294		.3772
14	.4854	.4668	.4854	.4251	.4481		.3734
15	.4854	.5041	.5041	.4066	.4294		.3772
16	.5041	.5121	.5041	.439	.4481		.3961
17	.5121	.4854	.4755	.439	.415	.3475	.3841
18	.4938	.4755	.5121	.4572	.4527	.3475	.3841
19	.5304	.4938	.547	.4938	.5281	.6767	.4527
20	.5788	.5487	.5601	.5304	.5281	.7133	.4572
21	.5304	.5487	.5853	.4938	.5281	.695	
22	.5487	.567	.5304	.5121	.4938	.7316	.4207
23		.567	.567	.5121	.4938	.439	.4024
24	.4572	.5121	.5121	.5121	.4938	.4755	.415
Max	.5788	.567	.5853	.5304	.5281	.7316	.4572
Min	.3475	.3658	.3696	.3841	.3658	.2926	.3109
Avg	.4483	.4673	.4742	.4455	.4392	.4367	.3828

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 211 / 11KV Congressnagar-I
 outgoing Feeder KV- 11 /
 INCOMING

NON SHEDDABLE WATER SUPPLY AND
 UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.8865	.8676	.8488	.7733	.7733	.6602
2	.7733	.8488	.811	.7922	.7167		.679
3	.7167	.7733	.7545	.7167	.6979	.7356	.6602
4	.6979	.7167	.7545	.7733	.6413	.6979	.6036
5	.679	.679	.6979	.6413	.6602	.6036	.6413
6	.6602	.6413	.6036	.6413	.6413	.6036	.5847
7	.6979	.679	.7356	.7167	.6413	.6036	.5281
8	.7922	.6413	.7167	.7167	.6602	.6036	.6979
9	.8676	.8865	.7733	.7922	.7167	.6602	.7922
10	.9526	.9054	.9808	.8764	.9054	.7167	.8488
11	1.1317	1.1506	1.1506	1.0185	1.1694	.7545	.9431
12	1.3203	1.2637	1.3014	1.0185	1.1883	.7922	.9431
13	1.3203	1.1883	1.1883	1.094	1.1317		.9808
14	1.358	1.2637	1.2071	1.105	1.094		.9997
15	1.3392	1.3203	1.3392	1.1317	1.1317		.9054
16	1.3014	1.2826	1.3014	1.1506	1.1317		.9431
17	1.3392	1.2071	1.1694	1.1128	1.1506	.6979	.9054
18	1.226	1.1317	1.1317	1.094	1.0751	.6413	.9431
19	1.226	1.1506	1.1506	1.0751	1.1128	.7545	.9808
20	1.105	1.0751	1.1128	.9808	1.0374	.7356	.8488
21	1.0562	1.0562	1.0374	.9808	.9808	.6979	.8676
22	.7733	1.0185	.9997	.9054	.8488	.679	.7733
23	.9808	.9619	.9619	.8676	.8488	.6979	.7356
24	.8488	.9242	.9431	.9431	.8488	.7545	.7922
Max	1.358	1.3203	1.3392	1.1506	1.1883	.7922	.9997
Min	.6602	.6413	.6036	.6413	.6413	.6036	.5281
Avg	.9982	.9855	.9871	.9164	.9085	.6949	.8024

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 212 / 11KV chatrapati-
 Congressnagar Feeder KV- 11 /
 INCOMING

NON SHEDDABLE WATER SUPPLY AND
 UTILITY

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9619	.9242	.7733	.8299	.7733
2		.9054	.8676	.8676	.8299	.7545
3		.8676	.7922	.7922	.7922	.7167
4		.8488	.7922	.7922	.7545	.7356
5		.8299	.7167	.7545	.7356	.6602
6		.811	.7733		.7167	.6979
7		.8299	.7545	.7733	.7167	.7167
8		.811	.811	.7733	.7922	.7356
9	.9242		.8865	.8299	.811	.8676
10	.9945	1.2071	1.0751	1.0562	.7922	.9997
11	1.4712	1.5278	1.4146	1.4523	.8488	
12	1.6598	1.6409	1.5655	1.5466	.9431	1.3014
13	1.6221	1.7541	1.6221	1.5466		1.2826
14	1.6598	1.7541	1.5655	1.6221		1.3392
15	1.8107	1.7164	1.6409	1.5278		1.3203
16	1.7918	1.7918	1.6598	1.5278		1.2449
17	1.7353	1.773	1.6598	1.5278	.8676	1.2071
18	1.7353	1.6787	1.6221	1.5089	.8676	1.2826
19	1.6975	1.5844	1.5655	1.4146	.9431	1.226
20	1.4146	1.4523	1.3392	1.3392	.9431	1.1506
21	1.3203	1.2071	1.1317	1.1506	.9054	.9997
22	1.1317	1.0562	1.1128		.8865	.8865
23	1.094	1.094	1.0751	.9997	.8865	.8676
24		1.0185	.9997	.9431		.8488
Max	1.8107	1.7918	1.6598	1.6221	.9431	1.3392
Min	.9242	.811	.7167	.7545	.7167	.6602
Avg	1.4709	1.2662	1.1820	1.1600	.8349	.9833

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164802 / 33 KV CHATTRAPATI

Feeder No / Name : 405 / 33kv Congress Nagar O/G SHEDDABLE URBAN
Feeder KV- 33 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6214	3.6214	2.7161	2.7161	2.2634		2.2634
2	3.1687	3.3951	2.4897	2.4897	2.2634		2.037
3	3.1687	3.1687	2.4897	2.4897	2.2634		1.8107
4	3.1687	2.9424	2.4897	2.4897	2.2634		2.037
5	2.9424	2.7161	2.2634	2.2634	2.2634		1.8107
6	2.9424	2.9424	2.4897	2.2634	2.2634		2.037
7	2.9424	2.9424	2.4897	2.4897	2.2634		1.8107
8	3.1687	3.1687	2.4897	2.2634	2.2634		2.2634
9	3.3951	2.7161	2.7161	2.037		2.2634	2.2634
10	4.0741	3.1687	3.3122	2.9424		2.2634	2.7161
11	4.9794	3.6214	3.6214	3.1687		2.4897	
12	5.6584	3.6214	3.8477	3.6214		2.4897	2.9424
13	5.4321	3.6214	3.6214	3.6214			3.1687
14	5.6584	3.8477	3.8477	3.3608			2.9424
15	5.6584	3.8477	3.8477	3.6214			2.9424
16	5.6584	3.8477	3.8477	3.6214			2.9424
17	5.4321	3.8477	4.0741	3.3951		2.2634	3.1687
18	5.6584	3.8477	3.6214	3.3951		2.2634	3.1687
19	5.4321	3.6214	3.8477	3.3951		2.4897	2.9424
20		3.6214	3.6214	3.3951		2.4897	3.1687
21	3.6214	3.3951	3.3951	3.1687		2.4897	2.7161
22	4.5268	3.3951	3.1687	2.9424		2.7161	2.7161
23	4.0741	3.3951	3.1687	4.6399		2.7161	2.4897
24	3.8477	3.8477	2.9424	3.1687	2.7161		2.4897
Max	5.6584	3.8477	4.0741	4.6399	2.7161	2.7161	3.1687
Min	2.9424	2.7161	2.2634	2.037	2.2634	2.2634	1.8107
Avg	4.2709	3.4234	3.1841	3.0400	2.3137	2.4486	2.5586

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 201 / 11kv A.I.R.

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.1203	1.1317	1.1506	1.0751	.9997	.9808
2	.9808	1.1203		1.094	1.0751	.9431	.9431
3	.9431	1.1203	1.0751	1.0751	1.0269	.8488	.9431
4	.9431	.9335	1.0374	1.0751	.9335	.7922	.8488
5	.9242	.9335	1.0374	1.0374	.8962	.7922	.7922
6	.9054	.9431	.9808	1.0374	.9054	.7922	.7545
7	.9242	.9242	.9808	.9431	.9242	.7922	.7922
8	.9431	.9335	.9431	.9054	.9335	.8299	.8676
9	.9808	1.0185	1.1317	1.0185	.9709	.7922	
10	1.1317	1.2071	1.1016	.9431	1.1506	.7922	1.0185
11		1.3203	1.2323	1.1883	1.226	.8488	
12		1.3203	1.2323	1.1317	1.1883	.9054	
13		1.2826	1.1827	1.1883	1.2449	.8676	
14		1.2826	1.2323	1.1694	1.2449	.7733	
15	1.226	1.2637	1.2883	1.1694	1.2637	.7922	.9619
16	1.2637	1.358	1.2883	1.1506	1.1506	.7922	.9619
17	1.251	1.3203	1.2637	1.1763	1.1317	.7733	.9997
18	1.251	1.2826	1.2449	1.0829	1.1317	.7545	1.0185
19	1.2136	1.2826	1.3203	1.2323	1.2449	.8488	1.094
20	1.3203	1.2637	1.2637	1.1949	1.2449	.9619	1.094
21	1.3014	1.226	1.2637	1.1643	1.1694	.9619	1.0751
22	1.2637	1.2071	1.226	1.1576	1.1694	.9808	1.0185
23	1.2826	1.2637	1.2637	1.2637	1.094	.9808	.9997
24	1.1317	1.1883	1.1694	1.1694	1.1203	1.094	.9808
Max	1.3203	1.358	1.3203	1.2637	1.2637	1.094	1.094
Min	.9054	.9242	.9431	.9054	.8962	.7545	.7545
Avg	1.1109	1.1715	1.1692	1.1133	1.1048	.8629	.9550

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 202 / 11 KV KALIMATA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1883	1.251	1.4146	1.2826	1.1576	1.358	1.1317
2	1.1317	1.251	1.3203	1.226	1.1576	1.3203	1.1317
3	1.094	1.2136	1.226	1.1694	1.1317	1.226	
4	1.0751	1.1203	1.1317	1.1506	1.1203	1.226	1.0374
5	1.0751	1.0269	1.1317	1.1317	1.0269	1.1317	.9619
6	1.0374	1.0562	1.094	1.1317	1.0374	1.0374	.9997
7	.9997	1.1389	1.1317	1.1694	1.2071	1.0374	1.0374
8	1.1506	1.1949	1.3203	1.226	1.2323	1.0185	1.094
9	1.3203	1.2136	1.3014	.9997	1.3014	1.1694	1.2071
10	1.4901	1.5089	1.3817	1.3203	1.3957	.3018	1.2826
11	1.6409	1.6032	1.5497	1.3769	1.358	1.226	
12	1.8107	1.6787	1.7737	1.6409	1.7541	1.2071	
13	1.7918	1.7164	1.6991	1.6409	1.6221	1.3203	
14	1.7541	1.7541	1.7924	1.5089	1.7353	1.3203	
15	1.7918	1.7164	1.7551	1.7164	1.7353	1.358	1.3769
16	1.8296	1.7353	1.8298	1.6598	1.6598	1.3203	1.3769
17		1.6975	1.7353	1.587	1.6409	1.3203	1.5089
18		1.6787	1.5466	1.7177	1.4335	1.3203	1.4712
19		1.5089	1.7918	1.5497	1.773	1.4523	1.4146
20		1.5466	1.6787	1.7177	1.6221	1.4335	1.4712
21	1.6409	1.5466	1.6032	1.5497	1.5844		1.226
22	1.6032	1.5844	1.5466	1.4901	1.6221	1.3203	1.3957
23	1.5655	1.4901	1.5089	1.3957	1.5466	1.3203	1.3203
24	1.2637	1.4146	1.5089	1.3769	1.2567	1.4712	1.2449
Max	1.8296	1.7541	1.8298	1.7177	1.773	1.4712	1.5089
Min	.9997	1.0269	1.094	.9997	1.0269	.3018	.9619
Avg	1.4127	1.4436	1.4906	1.4057	1.4213	1.2268	1.2468

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 203 / 11 KV ITI NON SHEDDABLE EXPRESS HV FEEDERS
Feeder KV- 11 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0373	.0377	.0377	.0373	.0377	.0377
2	.0377	.0373	.0377	.0377	.0373	.0377	.0377
3	.0377	.0373	.0377	.0377	.0373	.0377	.0377
4	.0377	.0373	.0377	.0377	.0373	.0377	.0377
5	.0377	.0373	.0377	.0377	.0373	.0377	.0377
6	.0377	.0373	.0377	.0377	.0373	.0377	.0377
7	.0377	.037	.0377	.0377	.037	.0377	.0377
8	.0377	.0373	.0377	.0377	.0373	.0377	.0377
9	.0377	.0373	.0377	.0377	.0373	.0377	.0377
10	.0377	.0377	.037	.0377	.0566	.0377	.0377
11	.0377	.0943	.0934		.0943		
12	.0943	.0943	.0934	1.5089	.0943		
13	.0943	.0943	.0934	.0943	.0943	.0377	
14	.0943	.0943	.0934	.0943	.0943		
15	.0754	.0943	.0924	.0943		.0377	.0943
16	.0754	.0943	.0934	.0943	.0943	.0377	.0943
17	.0554	.0943	.0943	.0924		.0377	.0943
18	.037	.0754	.0943	.0747	.0566	.0377	.0377
19	.037	.0377		.0554	.0566	.0377	.0377
20	.037	.0377	.0377	.0373	.0377	.0377	.0377
21	.0377	.0377	.0377	.0373	.0377	.0377	.0377
22	.0377	.0377	.0377	.0373	.0377	.0377	.0377
23	.0373	.0377	.0377	.0373	.0377	.0377	.0377
24	.0377	.0373	.0377	.0377	.037	.0377	.0377
Max	.0943	.0943	.0943	1.5089	.0943	.0377	.0943
Min	.037	.037	.037	.0373	.037	.0377	.0377
Avg	.0486	.0556	.0571	.1162	.0529	.0377	.0462

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 204 / SARAF COURT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3206	.4066	.3395	.3395	.3361	.3018	.2829
2	.3018	.4066	.3395	.3206	.3361	.2829	.2641
3	.2829	.3696	.3206	.3206	.2801	.2452	.2263
4	.2829	.3696	.3206	.3018	.2801	.2452	.2263
5	.2829	.2772	.3206	.3018	.2801	.2452	.2075
6	.2829	.2772	.2829	.2829	.2801	.2452	.2263
7	.2452	.2587	.2829	.2829	.2614	.2641	.2452
8	.2641	.2801	.3018	.2829	.2614	.2641	.2641
9	.3018	.2987	.3584	.2829	.2614	.2641	.2829
10	.3961	.4527	.5041	.4715	.415	.3018	.415
11	.6036	.6224	.6722	.6036	.6036	.3206	
12	.7167	.7167	.7842	.7356	.6979	.3395	
13	.7545	.7545	.7577	.7356	.679	.415	
14	.7733	.811	.7947	.6602	.6979	.4338	
15	.811	.811	.7842	.7733	.6979	.415	.5847
16	.8299	.7922	.7842	.7545	.6979	.3772	.5847
17	.8131	.7922	.8676	.6908	.6979	.3772	.6602
18	.8215	.7922	.8299	.7095	.7167	.3961	.6413
19	.8029	.7545	.7733	.7095	.7167	.3772	.6036
20	.7842	.679	.679	.6722	.679	.3584	.5281
21	.5093	.5658	.5658	.5281	.547	.3584	.415
22	.4527	.4715	.4715	.3961	.4338	.3584	.3584
23	.415	.415	.415	.415	.3961	.3395	.3395
24	.3584	.3734	.3772	.3772	.3361	.3584	.2829
Max	.8299	.811	.8676	.7733	.7167	.4338	.6602
Min	.2452	.2587	.2829	.2829	.2614	.2452	.2075
Avg	.5170	.5312	.5386	.4979	.4829	.3285	.3820

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 206 / TIE CABLE

Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	04-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1	.7922	.8775	
2	.7922	.8775	
3	.7922	.7655	
4	.7922	.7282	
5	.7922	.7282	
6	.7922	.7733	
7	.7922	.7468	
8	.7922	.7655	
9	.9431		
10	.9431		
11	.9808		1.4712
12	1.5844		
13	1.5466		
14	1.5466		
15	1.7541		
16	1.8673		
17	1.6804		
18	1.587		
19	1.4937		
20	1.531		
21	.3206		
22	1.1694		
23	1.0164		
24	.9808	.9431	
Max	1.8673	.9431	1.4712
Min	.3206	.7282	1.4712
Avg	1.1368	.8006	1.4712

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 207 / SUBSTATION FEEDER
Feeder KV- 11 / OUTGOING

DATE	05-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)
6		.0377
10	1.1506	
Max	1.1506	.0377
Min	1.1506	.0377
Avg	1.1506	.0377

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 401 / 33KV CHHATRAPATI i/c NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 33 / OUTGOING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.3951	3.6969	2.8858	2.8292	2.5766		2.3765
2	3.2253	3.6969	2.8292	2.6595	2.5766		2.3765
3	3.1687	3.4728	2.6595	2.6029	2.4646		2.2068
4	3.1121	3.1927	2.4897	2.5463	2.3525		2.1502
5	3.1121	2.9687	2.4897	2.4897	2.2405		1.9805
6	3.0556	3.0556	2.3765	2.4897	2.2405		1.9805
7	2.999	3.1121	2.4331	2.4331	2.4086		2.0936
8	3.1687	3.1927	2.6029	2.4331	2.4646		2.2634
9	3.5648	2.5206	2.6595	2.32		2.2634	2.4897
10	3.9609	3.2253	3.0247	2.7726		2.4331	2.7161
11	4.4702	3.5648	3.5288	3.1687		2.4331	
12	5.4321	3.7346	3.8649	3.5648		2.4897	
13	5.4321	3.8477	3.7146	3.4517		2.6595	
14	.7922	3.9609	3.8809	3.3951		2.5463	
15	5.6584	3.9043	3.8809	3.7346		2.6029	2.999
16	5.8282	3.9609	3.9769	3.6214		2.5463	2.999
17	5.7693	3.9043	3.9609	3.5288		2.4331	3.2819
18	5.4893	3.7912	3.7346	3.5848		2.4897	3.1687
19	5.2092	3.5648	3.9043	3.5288		2.7726	3.1687
20	5.2092	3.5082	3.678	3.5848		2.7726	3.1121
21	3.7912	3.3385	3.4517	3.2487		2.7726	2.7726
22	4.5268	3.2819	3.2819	3.0247		2.7726	2.8292
23	4.3004	3.1687	3.2253	3.0807			2.7161
24	3.7912	3.9209	3.0556	2.9424	2.7446		2.5463
Max	5.8282	3.9609	3.9769	3.7346	2.7446	2.7726	3.2819
Min	.7922	2.5206	2.3765	2.32	2.2405	2.2634	1.9805
Avg	4.1026	3.4828	3.2329	3.0432	2.4521	2.5705	2.6114

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164812 / 33 KV CONGRESS NAGAR

Feeder No / Name : 402 / 33KV SITABUILD I/C
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND
UTILITY

DATE	05-AUG-17	06-AUG-17
HR	Load (MW)	Load (MW)
1		2.6595
2		2.6029
3		2.3765
4		2.32
5		.2829
6		2.0936
7		2.0936
8		2.1502
9	2.5463	
10	2.999	
11	3.2819	
12	3.7346	
13	3.6214	
14	3.7912	
15	3.7912	
16	3.6214	
17	3.5648	
18	3.3385	
19	3.7912	
20	3.5648	
21	3.3385	
22	3.2819	
23	3.0556	
24		2.9424
Max	3.7912	2.9424
Min	2.5463	.2829
Avg	3.4215	2.1691

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 201 / 11 KV BANK OF MAHARASHATRA SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.2641	.2641	.2829	.2641	.2641	.2075
2	.2263	.2641	.2641	.2641	.2641	.2452	.1886
3	.2263	.2641	.2452	.2641	.2641	.2452	.2075
4	.2452	.2641	.2452	.2641	.2452	.2452	.2075
5	.2263	.2452	.2452	.2641	.2452	.2263	.1886
6	.2263	.2263	.2641	.2641	.2452	.2263	.2075
7	.2075	.2641	.2452	.3206	.2452	.2075	.2263
8	.2452	.2452	.2263	.2641	.2263	.2452	.2263
9	.2641	.3018	.2641	.3018	.2641	.2641	.2263
10	.415	.3584	.415	.3584	.3772	.2641	.2641
11	.6224	.5658	.5658	.5847	.5658	.3395	.4338
12	.8865	.9431	.8676	.8676	.8299	.4904	.6413
13	.9431	.9242	.9431	.8676	.9431	.547	.7167
14	.9997	.9431	.9997	.9431	.9431	.5847	.7733
15	.9808	.9431	.9808	.9242	.9619	.6413	.8299
16	.9619	.9431	.9431	.9808	.9242	.6224	.7922
17	.9242	.9054	.9808	.9808	.9431	.6224	.7733
18	.9619	.9431	.9619	.9431	.9808	.6413	.8299
19	1.0751	.9997	1.0562	1.0185	1.0751	.7167	.8299
20	1.0185	.9997	.9431	.9242	1.0185	.6602	.9619
21	.811	.7922	.7922	.8488	.7922	.5658	.6413
22	.4338	.4338	.3961	.415	.4904	.415	.3395
23	.3395	.3395	.3584	.3206	.3395	.3018	.2641
24	.2829	.2829	.2829	.3018	.3841	.2641	.2641
Max	1.0751	.9997	1.0562	1.0185	1.0751	.7167	.9619
Min	.2075	.2263	.2263	.2641	.2263	.2075	.1886
Avg	.5745	.5690	.5729	.5737	.5764	.4102	.4684

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 202 / 11KV REGENT -I o/g NON SHEDDABLE WATER SUPPLY AND
Feeder KV- 11 / INCOMING UTILITY

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8676	.8954	.8676	.8676	.8299	.8573	.7922
2	.8488	.8764	.8676	.8676	.8299	.8383	.7922
3	.8299	.8764	.8764	.8488	.8299	.8573	.8002
4	.8488	.8764	.8573	.8488	.811	.811	.7811
5	.9054	.8573	.8764	.8488	.7922	.7922	.7811
6	.9431	.8764	.8764	.8299	.7922	.7922	.7811
7	1.094	.8764	.8954	.8676	.7922	.7922	.8002
8	.8676	.8954	.8954	.8676	.8865	.8002	.7922
9	.8865	.9145	.9242	.9054	.9242	.8764	.7922
10	1.0185	.9717	1.0098	.9619	.9619	.8764	.9335
11	1.1694	1.1317	1.2384	1.226	1.1694	.9335	1.105
12	1.226	1.2071	1.2955	1.2071	1.226	.9335	1.1812
13	1.2449	1.226	1.3146	1.2071	1.2449	.9526	1.1622
14	1.2449	1.226	1.2765	1.2449	1.226	.9526	1.1622
15	1.3014	1.2826	1.3146	1.2449	1.2449	.9717	1.1812
16	1.2826	1.2449	1.2765	1.2637	1.2449	.9907	1.1622
17	1.2955	1.2449	1.2574	1.2449	1.2384	.9907	1.1622
18	1.1812	1.1694	1.1506	1.1317	1.1431	.9619	1.0669
19	1.105	1.1694	1.1317	1.1317	1.1431	1.0288	1.0669
20	1.105	1.094	1.1128	1.094	1.105	1.0288	1.0288
21	1.105	1.0751	1.094	1.0562	1.086	.9907	1.0288
22	1.0288	.9717	.9619	.9242	1.0288	.8764	.8764
23	.9526	.9619	.9431	.8676	.9526	.8299	.8764
24	.8865	.9526	.9242	.8676	.8676	.8764	.8383
Max	1.3014	1.2826	1.3146	1.2637	1.2449	1.0288	1.1812
Min	.8299	.8573	.8573	.8299	.7922	.7922	.7811
Avg	1.0516	1.0364	1.0516	1.0177	1.0154	.9005	.9560

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 203 / 11 KV SANSKRUTIK SANKUL SHEDDABLE URBAN
FDR Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1886	.1698	.1698	.1698	.1886	.1698
2	.1698	.1886	.1698	.1698	.1698	.1886	.1698
3	.1698	.1886	.1698	.1698	.1698	.1886	.1698
4	.1698	.1886	.1698	.1886	.1698	.1886	.1698
5	.1698	.1698	.1509	.1698	.1698	.1886	.1698
6	.1698	.1886	.1509	.1509	.1698	.1886	.1698
7	.1886	.1886	.1698	.1886	.1886	.1698	.0943
8	.2641	.2641	.3018	.2641	.2641	.1886	.1698
9	.3772	.3395	.3772	.3395	.3584	.3395	.1886
10	.4527	.415	.5281	.4904	.4715	.3395	.3395
11	.5658	.4904	.6036	.6036	.5281	.3961	.3772
12	.6224	.5847	.6413	.6036	.547	.415	.4715
13	.6036	.6413	.679	.5847	.4904	.3395	.4338
14	.5847	.5847	.5847	.5847	.5281	.3395	.4338
15	.6602	.6036	.6224	.6036	.5658	.3772	.4527
16	.6413	.6979	.6413	.6224	.6224	.415	.3961
17	.6413	.6413	.6224	.6413	.5847	.4527	.3961
18	.6413	.6224	.6413	.6413	.5847	.3206	.415
19	.6979	.6348	.6413	.6413	.6979	.3772	.415
20	.6413	.5658	.547	.6036	.5847	.3772	.415
21	.4338	.3772	.3961	.415	.4715	.3395	.3395
22	.3772	.2829	.2641	.2829	.3395	.3206	.2641
23	.2641	.1886	.1886	.1886	.2075	.1886	.1886
24	.2263	.1886	.1886	.1698	.1698	.1886	.1886
Max	.6979	.6979	.679	.6413	.6979	.4527	.4715
Min	.1698	.1698	.1509	.1509	.1698	.1698	.0943
Avg	.4126	.3927	.4008	.3953	.3843	.2923	.2916

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 204 / 11 KV UNIVERSITY LIBRARY SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.5041	.4668	.4715	.4338	.4481	.4108
2	.4527	.4481	.4668	.4527	.4338	.4481	.3921
3	.415	.4668	.4481	.4338	.415	.4481	.3921
4	.415	.4481	.4481	.4338	.415	.4527	.3921
5	.415	.4108	.4294	.415	.415	.4527	.3921
6	.4338	.4481	.4294	.415	.415	.4338	.3921
7	.4715	.4294	.4854	.4904	.4715	.415	.3921
8	.4904	.4854	.5601	.5093	.5281	.4108	.4108
9	.6036	.6722	.6535	.6602	.547	.4854	.4854
10	.7842	.8215	.8676	.8029	.7922	.4668	.6348
11	1.0082	.9431	.9896	.9335	.8865	.4854	.6908
12	1.0082	.9808	.9709	.9149	.9054	.4854	.7282
13	1.0642	1.0185	1.0829	.9149	1.0185	.4854	.7282
14	1.0082	1.0562	1.0642	.9709	.9242	.4854	.7468
15	1.0269	1.0562	1.0269	.9709	.9619	.4668	.7842
16	1.0082	1.0185	1.0082	.9709	.8676	.4294	.7468
17	1.0269	1.0751	1.0185	.9522	.8589	.4294	.7095
18	1.0082	.8962	.9431	.9054	.8215	.4668	.6908
19	.9335	.8589	.8299	.8488	.7282	.4668	.6535
20	.7842	.7282	.7922	.5658	.6348	.4854	.5601
21	.6348	.6535	.6413	.6036	.5601	.4481	.5041
22	.6348	.5601	.6602	.5658	.5601	.4481	.4481
23	.5601	.5788	.5658	.547	.5601	.4108	.4108
24	.5281	.4854	.3734	.4904	.5093	.4854	.4108
Max	1.0642	1.0751	1.0829	.9709	1.0185	.4854	.7842
Min	.415	.4108	.3734	.415	.415	.4108	.3921
Avg	.7154	.7102	.7176	.6767	.6526	.4558	.5461

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 205 / 11 KV APANA BHANDAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5068	.5041	.5093	.5093	.4706	.3982
2	.4715	.4706	.4706	.4904	.4904	.4706	.3982
3	.4527	.4706	.4706	.5093	.4904	.4525	.362
4	.4527	.4706	.4706	.4904	.4715	.4715	.3439
5	.415	.4706	.4525	.4715	.4338	.4527	.3439
6	.415	.3982	.4163	.4527	.3772	.415	.3258
7	.415	.3982	.3982	.4338	.3961	.3772	.362
8	.415	.3982	.4163	.415	.3772	.3982	.362
9	.415	.4163	.4525	.4715	.3961	.3982	.4163
10	.4706	.4344	.4706	.4525	.4527	.3982	.4344
11	.4887	.4904	.543	.4887	.5281	.4525	.4887
12	.5792	.5658	.5792	.543	.5658	.4706	.5249
13	.5792	.5847	.6154	.543	.5658	.4706	.4887
14	.6154	.5847	.6335	.543	.6036	.4525	.543
15	.6335	.6036	.6335	.5792	.6413	.5068	.5068
16	.6335	.6413	.6516	.5792	.6224	.5068	.543
17	.6516	.6413	.6348	.6154	.5973	.5249	.543
18	.6335	.6154	.679	.6413	.6516	.543	.543
19	.7421	.6878	.7733	.7356	.724	.6878	.6154
20	.7421	.7421	.7922	.7733	.7421	.6878	.6154
21	.6697	.6878	.7167	.7167	.6878	.6154	.543
22	.6154	.5792	.6224	.6036	.6154	.5068	.4706
23	.5973	.5973	.6413	.5847	.543	.4706	.4344
24	.5093	.5068	.5249	.547	.5281	.4706	.4344
Max	.7421	.7421	.7922	.7733	.7421	.6878	.6154
Min	.415	.3982	.3982	.415	.3772	.3772	.3258
Avg	.5460	.5401	.5651	.5496	.5421	.4863	.4600

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 206 / 11 KV LANDMARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.3395	.3206	.3395	.3206	.3395	.3018
2	.3395	.3395	.3206	.3206	.3018	.3395	.2829
3	.3018	.3206	.3206	.3206	.3018	.3395	.2829
4	.3018	.3206	.3206	.3018	.3018	.3206	.2829
5	.3018	.3018	.3018	.3018	.3018	.3018	.2829
6	.3018	.3018	.3018	.3018	.3018	.3018	.3018
7	.2452	.3018	.3018	.3018	.2743	.3018	.3206
8	.3206	.3018	.3018	.2641	.2829	.3206	.3206
9	.3961	.3584	.3395	.3584	.3206	.415	.2641
10	.5093	.5658	.6036	.4904		.4527	.415
11	.9997	.9619	.8865	.8488	.7733	.6979	.8299
12	.9997	.9431	.9431	.9242	.9054	.5847	.8299
13	.9619	.9619	.9431	.8676	.8865	.5658	.8676
14	.9619	.9431	.9808	.8865	.8676	.7167	.8865
15	.9054	.9054	.8865	.8865	.7922	.6979	.8865
16	.9431	.8865	.8676	.8676	.8676	.7167	.8676
17	.9431	.9619	.8775	.8676	.8299	.7167	.8676
18	.9242	.8676	.8488	.8299	.7922	.7167	.8676
19	.8488	.8299	.7167	.8865	.8488	.7167	.7356
20	.7922	.8299	.7167	.7545	.811	.679	.7733
21	.679	.7167	.7356	.6413	.7167	.6413	.679
22	.5847	.5847	.4904	.5658	.5658	.547	.7356
23	.415	.3395	.3395	.3206	.3772	.3395	.3206
24	.3206	.3395	.3395	.3206	.3018	.3395	.3018
Max	.9997	.9619	.9808	.9242	.9054	.7167	.8865
Min	.2452	.3018	.3018	.2641	.2743	.3018	.2641
Avg	.6162	.6051	.5835	.5737	.5671	.5045	.5627

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 207 / 11 KV Poonam Mall-Bhgwa SHEDDABLE URBAN
Ghar- Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9231	.9997	.9431	.9242	.8507	.7783
2	.8676	.9231	.905	.9242	.8676	.8145	.7059
3	.7922	.8869	.8688	.9054	.8676	.7964	.6878
4	.7545	.8326	.8507	.8488	.8299	.7922	.6878
5	.7922	.7964	.8145	.8299	.8299	.7922	.6878
6	.811	.8145	.7602	.7922	.8488	.7545	.7059
7	.8299	.8507	.8326	.8865	.8488	.7167	.6878
8	.9619	.8326	.8326	.8676	.8299	.7602	.7602
9	.9054	.905	.9412	.8676	.8676	.7421	.8688
10	1.0317	.9774	1.0317	.9955	1.0374	.9231	.9412
11	1.1041	1.0751	1.1041	1.0498	1.094	.7964	.9412
12	1.0498	1.0751	1.1222	1.0498	1.1506	.8326	.9593
13	1.1222	1.094	1.1403	1.0498	1.1694	.8869	.905
14	1.1584	1.094	1.1946	1.0317	1.0374	.7421	.8869
15	1.1222	1.1694	1.2127	1.0498	1.0562	.6878	.8145
16	1.1584	1.1694	1.1584	1.1222	1.094	.7059	.8326
17	1.1946	.9619	1.1584	1.1576	1.0498	.6335	.8507
18	1.2127	1.086	1.2449	1.1694	1.086	.6878	.9231
19	1.267	1.1946	1.2449	1.1694	1.1765	.8145	.9774
20	1.1946	1.1403	1.226	1.1694	1.0679	.8326	.9231
21	1.1946	1.1222	1.1506	1.1128	.9955	.8688	.905
22	1.1403	1.0498	1.0751	1.0751	.9955	.8326	.7964
23	1.0679	1.0136	1.1128	1.0751	.9412	.8688	.9231
24	.9619	.9774	1.0498	1.0562	.9808	.9412	.8326
Max	1.267	1.1946	1.2449	1.1694	1.1765	.9412	.9774
Min	.7545	.7964	.7602	.7922	.8299	.6335	.6878
Avg	1.0250	.9985	1.0430	1.0083	.9853	.7948	.8326

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 208 / 11 KV ETERNITY MALL SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1663	.1663	.1509	.1698	.1663	.1663
2	.132	.1294	.1109	.132	.1509	.1294	.1294
3	.1132	.1109	.1109	.132	.1132	.1109	.0924
4	.1132	.1109	.1109	.1132	.1132	.1132	.0924
5	.1132	.1109	.0924	.1132	.1132	.0943	.0924
6	.1132	.1109	.0924	.0943	.1132	.0754	.0924
7	.1132	.1109	.0924	.132	.1132	.0754	.0924
8	.1132	.1109	.1109	.1132	.1132	.0924	.0924
9	.2075	.2033	.1663	.1886	.2075	.1848	.1663
10	.2218	.3881	.2957	.2402	.2452	.1848	.2033
11	.4435	.4527	.462	.5175	.3584	.3881	.3511
12	.499	.547	.5914	.6099	.547	.6099	.462
13	.499	.547	.5544	.5359	.547	.5914	.4435
14	.5729	.5847	.5729	.6099	.6602	.5729	.4805
15	.5729	.6602	.6099	.6283	.6413	.6099	.5544
16	.5729	.6036	.5544	.6653	.6413	.5729	.5544
17	.5175	.5281	.5359	.6468	.6099	.5544	.5359
18	.499	.462	.5093	.5847	.5544	.5175	.6283
19	.5359	.5544	.5658	.6979	.6099	.6099	.5175
20	.5359	.5175	.5658	.5658	.6653	.6283	.499
21	.5175	.4805	.547	.5093	.6283	.5729	.4805
22	.462	.4251	.4338	.4904	.6099	.5175	.3696
23	.3696	.3696	.3395	.3961	.4066	.3696	.3881
24	.3206	.2772	.2033	.2075	.2452	.2587	.2218
Max	.5729	.6602	.6099	.6979	.6653	.6283	.6283
Min	.1132	.1109	.0924	.0943	.1132	.0754	.0924
Avg	.3462	.3568	.3498	.3781	.3824	.3584	.3211

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 209 / 11 KV CARE HOSPITAL SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	1.0534	1.0164	1.1128	1.1317	1.0164	.9979
2	.8488	.9055	.9425	.9997	.9808	.9979	.8686
3	.7733	.9055	.9055	.9242	1.0185	.9425	.8501
4	.6979		.8871	.7922	.8488	.9431	.8316
5	.679	.7947	.8501	.8488	.8488	.9054	.8316
6	.7922	.7577	.7947	.9242	.8488	.8488	.8131
7	.9619	.9425	.924	1.0185	.9619	.7922	.9055
8	.9431	.8686	.9795	1.0374	.9997	.924	.7762
9	.9997	.961	1.0534	1.0562	1.1317	.9425	1.0164
10	1.2197	1.1458	1.2197	1.1827	1.1694	1.0349	1.0719
11	1.3676	1.4146	1.4415	1.386	1.3392	1.0349	1.2936
12	1.2936	1.4901	1.5154	1.423	1.4146	1.2012	1.2936
13	1.46	1.3957	1.6263	1.4969	1.5278	1.2752	1.2752
14	1.531	1.358	1.5708	1.6263	1.4523	1.1643	1.4045
15	1.5154	1.5844	1.5339	1.5524	1.4335	1.1458	1.2752
16	1.5154	1.4712	1.4969	1.5524	1.4146	1.0719	1.2197
17	1.3491	1.3957	1.5154	1.4415	1.3491	1.0164	1.1827
18	1.3306	1.2197	1.5089	1.3769	1.3121	.961	1.1273
19	1.3676	1.2752	1.358	1.3769	1.2936	1.1088	1.1827
20	1.3121	1.386	1.3392	1.2637	1.2567	1.2197	1.1088
21	1.1827	1.4045	1.2826	1.2826	1.2382	1.1273	1.1273
22	1.2752	1.3491	1.2637	1.3014	1.2012	1.2012	1.0903
23	1.1643	1.3121	1.2449	1.2826	1.2012	1.1643	1.0719
24	.9242	1.1088	1.2012	1.2071	1.1883	1.0719	1.0534
Max	1.531	1.5844	1.6263	1.6263	1.5278	1.2752	1.4045
Min	.679	.7577	.7947	.7922	.8488	.7922	.7762
Avg	1.1476	1.1956	1.2280	1.2278	1.1901	1.0463	1.0695

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 211 / 11 KV AJMERA - SHEDDABLE URBAN
NARESHCHANDRA Feeder KV- 11 /
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.2075	.1886	.1698	.1509	.1509	.0943
2	.1509	.1886	.1698	.1509	.1509	.132	.0943
3	.1509	.1886	.1698	.132	.1509	.132	.0943
4	.1509	.1698	.1698	.132	.132	.132	.0943
5	.1698	.1698	.1698	.1509	.1509	.132	.1132
6	.1698	.1886	.1886	.1698	.1698	.132	.132
7	.1698	.1698	.1886	.1698	.1698	.132	.132
8		.1886	.1886	.1698	.1886	.1509	.1698
9	.1886	.1886	.2075	.1886	.1698	.132	.132
10	.2075	.1886	.2241	.2075	.1886	.132	.1886
11	.2641	.2452	.2614	.2829	.2452	.1132	.2075
12	.3206	.3018	.3206	.2641	.2829	.1509	.2075
13	.3018	.3395	.3584	.3206	.3206	.1509	.2075
14	.3206	.3018	.3206	.2829	.3018	.1509	.2075
15	.3206	.3206	.3584	.3206	.3018	.1509	.2263
16	.3584	.3584	.3584	.3206	.3206	.1509	.2263
17	.3584		.3206	.3206	.3206	.1509	.2452
18	.3772	.3584	.3395	.3206	.3206	.1509	.2641
19	.415	.3584	.3961	.3772	.3584	.1886	.3018
20	.3772	.3584	.3206	.3395	.3395	.1886	.2641
21	.3206	.3018	.3206	.2829	.2641	.1509	.2075
22	.2452	.2263	.2452	.2075	.2263	.132	.1698
23	.2263	.2075	.1698	.1886	.1886	.132	.132
24	.1698	.2075	.1886	.1698	.1509	.1509	.1132
Max	.415	.3584	.3961	.3772	.3584	.1886	.3018
Min	.1509	.1698	.1698	.132	.132	.1132	.0943
Avg	.2559	.2493	.256	.2350	.2318	.1446	.1760

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 212 / 11kv ANAND TALKIES 4 POLE SHEDDABLE URBAN
STRU Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7655	.7842	.7922	.7356	.6908	.6348
2	.679	.7095	.7282	.6979	.679	.6908	.5975
3	.6602	.7095	.7095	.679	.6979	.6535	.5788
4	.6602	.6908	.6908	.6979	.679	.6413	.5788
5	.6602	.6535	.6908	.679	.5658	.6036	.5601
6	.6602	.6535	.6535	.6602	.679	.5847	.5228
7	.6602	.6348	.7468	.6979	.679	.5847	.5601
8	.6602	.6908	.6722	.6413	.6979	.6161	.6908
9	.679	.6908	.6535	.679	.7356	.6535	.6348
10	.7095	.7095	.6908	.6908	.7545	.6348	.6348
11	.7842	.7545	.8215	.7655	.811	.6161	.7468
12	.8962	.9242	.9522	.8775	.8676	.6908	.7842
13	.9149	.9242	.9709	.9335	.9619	.7095	.8029
14	.9335	.9808	.9335	.8962	.9054	.7095	.7842
15	.9522	.9431	1.0082	.9149	.9054	.7095	.8029
16	.9709	.9808	.9522	.9522	.9808	.7282	.8029
17	.9709	1.0185	.9335	.9335	.8589	.6722	.8589
18	.9335	.9896	.9808	.9242	.9335	.6535	.9149
19	1.1389	1.2323	1.094	1.094	1.1389	.8029	1.0082
20	1.1389	1.1949	1.0562	1.0751	1.1016	.8215	1.0082
21	.9896	1.0642	1.0185	.9997	1.0269	.8402	.8775
22	.9335	.9709	.9242	.8488	.9522	.7468	.7282
23	.8962	.8962	.9054	.8488	.8589	.6908	.7095
24	.7733	.8029	.7842	.7922	.7545	.8029	.6161
Max	1.1389	1.2323	1.094	1.094	1.1389	.8402	1.0082
Min	.6602	.6348	.6535	.6413	.5658	.5847	.5228
Avg	.8322	.8577	.8482	.8238	.8317	.6895	.7266

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

REGENT S/DN.[682] BU 4682

Substation No/ Name :- 164819 / 33 KV SITABULDI S/STN

Feeder No / Name : 213 / 11KV Regent II o/g SHEDDABLE URBAN
Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3961	.4108	.3921	.4527	.415	.3734	.3174
2	.3961	.4108	.3921	.415	.415	.3547	.3174
3	.3961	.3921	.4108	.4338	.3961	.3547	.3174
4	.3772	.3921	.3921	.415	.3961	.3584	.2987
5	.3772	.3734	.3921	.415	.3429	.3584	.2987
6	.3584	.3734	.4294	.4338	.3772	.3395	.3174
7	.3584	.3547	.3734	.3961	.3961	.3395	.3361
8	.3772	.3734	.4108	.415	.3772	.3547	.3921
9	.3961	.3921	.3921	.415	.3772	.3361	.3547
10	.4481	.2987	.5041	.4527	.5093	.3734	.4108
11	.8029	.811	.8589	.7842	.7356	.4854	.6722
12	1.0269	1.0374	1.1016	.9709	1.0751	.6161	.8589
13	1.1203	1.1128	1.1576	.9149	1.1128	.6722	.8402
14	1.0829	1.1128	1.1389	.9335	1.094	.6908	.8962
15	1.1203	.9619	1.1203	1.0269	1.0562	.7282	.9149
16	1.1016	1.0751	1.1016	1.0082	.9997	.7095	.8962
17	1.1389	1.1317	1.1203	1.0829	1.0456	.7468	.9522
18	1.1203	1.1016	1.1317	.9431	1.1203	.8215	1.0269
19	1.251	1.226	1.1883	1.1317	1.1763	.9149	1.0082
20	1.1763	1.1389	1.1694	1.1506	1.1763	.9335	.9896
21	.8775	.8962	.9054	.7733	.8962	.7468	.6722
22	.5228	.5041	.4904	.4904	.4668	.4668	.3734
23	.4668	.4854	.5093	.5093	.4108	.3547	.3361
24	.4338	.4481	.4294	.4527	.4338	.4108	.3547
Max	1.251	1.226	1.1883	1.1506	1.1763	.9335	1.0269
Min	.3584	.2987	.3734	.3961	.3429	.3361	.2987
Avg	.7135	.7006	.7297	.6840	.7001	.5350	.5897

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 202 / 11KV Shankarnagar Incomer
Feeder KV- 11 / INCOMING

SHEDDABLE URBAN

DATE	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.3817	1.1949
2		1.307	1.1883
3		1.2136	1.1016
4		1.1949	1.0829
5		1.1389	1.1389
6		1.1016	1.1763
7		1.1389	1.1949
8		1.1576	1.2696
9		1.251	1.4563
10		1.4003	1.531
11		1.4661	1.5497
12			1.7177
13		1.5912	1.643
14		1.4523	1.531
15		1.3756	1.5684
16	1.9605	1.358	1.5339
17	1.9605	1.363	1.531
18	1.9418	1.4563	1.6804
19	2.1472	1.7364	1.7737
20	1.9605	1.7551	1.7364
21	1.8111	1.6617	1.531
22	1.6632	1.5123	1.531
23	1.6078	1.4377	1.3256
24		1.4377	1.2696
Max	2.1472	1.7551	1.7737
Min	1.6078	1.1016	1.0829
Avg	1.8816	1.3865	1.4274

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 227 / 11 KV BAJAJ NGR FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.543	.5093	.5228	.5041	.4854	.4031
2	.3982	.5068	.5093	.4854	.4715	.4481	.415
3	.362	.4706	.4715	.462	.4715	.4108	.362
4	.362	.4344	.4527	.462	.4294	.3921	.362
5	.362	.3982	.3961	.4108	.4294	.3921	.3801
6	.362	.3982	.415	.3921	.4481	.3734	.3982
7	.4108	.4525	.4527	.4108	.4715	.3921	.4163
8	.4163	.439		.5041	.4854	.4108	.4163
9	.4668	.5041	.4108	.5041	.5041	.4108	.4706
10	.5041	.5041	.5041	.5228	.5544	.4481	.5601
11	.5975	.6722	.6348	.6535	.6722	.4887	.5601
12	.6535	.6722	.7095	.6535	.6535		.5415
13	.6908	.6348	.6722	.6653	.6161	.5121	.5041
14	.6908	.6348	.6161	.6348	.6161	.4715	.4481
15	.6908	.6348	.6535			.4344	.4854
16	.7095	.6722	.6908	.6535	.6161	.4527	.499
17	.7316	.6468	.6516	.6516	.6154	.4298	.5041
18	.7059	.6099	.6516	.6154	.5973	.4656	.5601
19	.6878	.6722	.6878	.6516	.6722	.5552	.5788
20	.7421	.7023	.7059	.724	.6335	.5792	.5788
21	.724	.6348	.7602	.7602	.5792	.543	.5041
22	.6335	.6224	.6348	.724	.543	.4887	.5228
23	.5973	.5788	.5975	.5975	.5415	.4887	.4854
24	.5068	.5853	.5281	.5415	.547	.5228	.4344
Max	.7421	.7023	.7602	.7602	.6722	.5792	.5788
Min	.362	.3982	.3961	.3921	.4294	.3734	.362
Avg	.5621	.5677	.5790	.5741	.5510	.4607	.4746

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 228 / 11 KV SHRADHANANDPETH FDR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.6878	.6602	.6348	.5975	.5601	.4763
2	.5228	.6401	.6224	.5975	.5847	.5175	.4715
3	.5228	.5853	.6036	.5729	.5281	.4805	.4527
4	.5228	.5487	.5658	.5544	.5228	.4805	.4338
5	.5228	.5487	.5658	.499	.5041	.462	.4527
6	.5228	.5068	.5281		.5041	.462	.4715
7	.5415	.543	.5281	.5359	.547	.4435	.4715
8	.5601	.567		.5601	.5228	.462	.5093
9	.6161	.5914	.5729	.5853	.5487	.5228	.6224
10	.6722	.7207	.6348	.6722	.6219	.5788	.5788
11	.7842	.8962	.9335	.7655	.8029	.6154	.5601
12	.9522	.8962	.8215	.7842	.7842		.7282
13	.8962	.9522	.8402	.7947	.8316	.6767	.6908
14	.9149	.9149	.8215	.7842	.7655	.6036	.6348
15	.9335	.8962	.8402			.5792	.6535
16	.9335	.8402	.8402	.7842	.8215	.547	.6283
17	.8779	.8871	.8507	.8048	.811	.5716	.6348
18	.9412	.8871	.8145	7.5474	.8676	.5906	.6908
19	.905	.961	.8507	.8326	.8501	.7049	.7468
20	.9593	.961	.9412	.8869	.7922	.7049	.7468
21	.905	.9149	.9774	.905	.7545	.6668	.6348
22	.8688	.8775	.7842	.8507	.6979	.6287	.6348
23	.7783	.8131	.8029	.6908	.6653	.5906	.5041
24	.6348	.7316	.7095	.6653	.6348	.5788	.5144
Max	.9593	.961	.9774	7.5474	.8676	.7049	.7468
Min	.5228	.5068	.5281	.499	.5041	.4435	.4338
Avg	.7445	.7654	.7439	1.0140	.6766	.5665	.5810

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 229 / 11KV vasant Nagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0373	.0377	.0377	.0373
2	.0373	.0377	.0377	.0373	.0377	.0377	.0377
3	.0373	.0377	.0377	.037	.0377	.0377	.0373
4	.0373	.0377	.0377	.037	.0377	.0377	.0373
5	.0373	.0377	.0377	.0377	.0377	.0377	.0373
6	.0373	.0373	.0377	.0377	.0377	.0377	.0373
7	.0377	.0373	.0377	.0377	.0377	.0377	.0373
8	.0373	.0373		.0373		.0377	.0373
9	.0373	.0373	.0373	.0566	.0566	.0377	.0373
10	.056	.056	.056	.056	.0566	.0373	.0373
11	.0747	.0747	.056	.0747	.0747	.0373	.056
12	.0747	.0747	.0747	.0747	.0747		.056
13	.0747	.0747	.0747	.0754	.0754	.0373	.056
14	.0747	.0747	.0747	.0747	.0747	.0377	.056
15	.0747	.0747	.0747			.0377	.056
16	.0747	.056	.0747	.056	.056	.0377	.037
17	.0747	.0566	.056	.056	.056	.0373	.0373
18	.056	.0377	.056	.056	.056	.0373	.0377
19	.0373	.0377	.056	.0566	.0566	.0373	.0373
20		.0377	.0373	.0373	.0373	.0373	.0373
21	.0373	.0377	.0373	.0373	.0373	.0373	.0373
22	.0373	.0377	.0187	.0373	.0373	.0373	.0377
23	.0377	.0377	.0373	.0377	.0377	.0373	.0377
24	.0381	.0377	.0377	.0377	.0377	.0377	.0373
Max	.0747	.0747	.0747	.0754	.0754	.0377	.056
Min	.0373	.0373	.0187	.037	.0373	.0373	.037
Avg	.0504	.0477	.0488	.0488	.0495	.0375	.0413

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 232 / 11KV AATH RASTA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.724	.3395	.3174	.3174	.3018	.2614
2	.5788	.6878	.3395	.3174	.3018	.2957	.3395
3	.5788	.6335	.3395	.3142	.3018	.2772	.2427
4	.5601	.6036	.3018	.2772	.2801	.2772	.2427
5	.5601	.6036	.2829	.2772	.2801	.2452	.2614
6	.5228	.5611	.2829	.2587	.2614	.2218	.2614
7	.5788	.6154	.2829	.3142	.2829	.2587	.2614
8	.5788	.5853		.3174	.2614	.2402	.2987
9	.6348	.3109	.3326	.3326	.3142	.2801	.3174
10	.6722	.567	.3921	.3921	.3881	.3361	.3547
11	.8215	.6722	.4854	.5041	.4481	.3258	.3734
12	.8402	.5041	.4854	.5415	.4668		.3921
13	.8402	.5041	.4854	.5304	.4572	.3658	.3921
14	.8215	.5228	.5415	.4854	.4854	.3395	.3921
15	.8775	.5788	.5601			.3258	.3734
16	.8402	.5601	.5601	.4668	.4668	.3206	.3696
17	.8596	.5601	.5792	.4755	.4668	.3174	.3547
18	.8326	.5228	.5792	.4525	.4481	.3547	.3921
19	.8145	.5658	.5487	.567	.5544	.4294	.4108
20		.5601	.4887	.6335	.4854	.4294	.3734
21	.724	.4715	.4706	.5792	.4294	.4108	.3547
22	.8507	.4572	.4294	.543	.3921	.3547	.3361
23		.3921	.3511	.3734	.3734	.3174	.2987
24	.7095	.8115	.3395	.3547	.3395	.3018	.2801
Max	.8775	.8115	.5792	.6335	.5544	.4294	.4108
Min	.5228	.3109	.2829	.2587	.2614	.2218	.2427
Avg	.7151	.5656	.426	.4185	.3827	.3186	.3306

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162006 / 11 KV KACHIPURA

Feeder No / Name : 233 / 11KV Bhagwaghar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	07-AUG-17
HR	Load (MW)
7	.2614
Max	.2614
Min	.2614
Avg	.2614

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 202 / 11KV SHANKAR NAGAR I/C

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3899	2.1098	2.0911	1.8298
2	2.2592	2.0165	1.9791	1.7737
3	2.1285	1.9044	1.7364	1.7177
4	2.1285	1.9044	1.7364	1.7177
5	2.1285	1.9044	1.7364	1.7177
6	2.0165	1.9044	1.7364	1.7177
7	1.9978	1.9044	1.7364	1.7551
8	2.1845	2.0538	1.8111	2.0165
9	2.3339	2.0165	1.8671	2.0725
10	2.5019	2.2068	2.0328	2.2592
11	2.5019	2.3577	2.2405	2.3152
12	2.5766	2.32	2.2032	2.3712
13	2.5019	2.1879	2.2177	2.1845
14	2.4832	2.1691	1.9231	2.1098
15	2.6326	2.1879	1.8671	2.1098
16	2.5393	2.1879	1.7737	
17		2.3899	1.7364	2.2592
18	2.4764	2.3152		2.2634
19	2.809	2.5873		2.4143
20	2.7721	2.5688		
21		2.4394		
22	2.5206	2.3525	2.2218	2.2405
23	2.5019	2.1845	2.1285	2.0351
24	2.5019	2.2779	2.1845	1.9978
Max	2.809	2.5873	2.2405	2.4143
Min	1.9978	1.9044	1.7364	1.7177
Avg	2.4039	2.1855	1.9480	2.0418

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 223 / 11KV LAXMI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.6535	.6653	.6401	.5601	.5601	.4854
2	.5601	.5975	.6099	.6036	.5601	.5228	.4668
3	.5228	.5788	.5729	.5487	.5228	.4481	.4481
4	.4805	.5359	.5544	.5487	.5228	.4481	.4481
5	.5041	.5359	.5601	.5487	.5228	.4481	.4481
6	.5041	.4854	.5041	.5121	.5228	.4481	.4481
7	.5228	.5228	.5228	.4938	.5228	.4481	.4481
8	.5415	.5601	.5544	.567	.5041	.5041	.5228
9	.5601	.5228	.5281	.5544	.4854	.4854	.5228
10	.5729	.5175	.547	.5975	.5658	.5487	.567
11	.6099	.4251	.6413	.5544	.6036	.6036	.5544
12	.6283	.5729	.5658	.6584	.5847	.5914	.5544
13	.5975	.5975	.5658	.5853	.547	.6099	.4887
14	.6036	.5975	.6036	.5544	.5281	.4755	.4251
15	.5847	.6161	.6224	.5415	.547	.4805	.4481
16	.6348	.6161	.6036	.5601	.5281	.4435	
17	.6348	.6348	.6348	.5975	.5914	.4163	.4755
18	.6722	.6535	.6535	.6154	.6036		.547
19	.7282	.7468	.7468	.695	.724		.6413
20	.7468	.7468	.7655	.6878	.695		
21	.7468	.7468	.7468		.6584		
22	.7762	.7468	.7602	.7095	.6908	.6161	.6161
23	.0112	.7762	.7499	.7095	1.6617	.5975	.5228
24	.6348	.7095	.7207	.6584	.6348	.6348	.5601
Max	.7762	.7762	.7655	.7095	1.6617	.6348	.6413
Min	.0112	.4251	.5041	.4938	.4854	.4163	.4251
Avg	.5816	.6124	.6250	.5975	.6203	.5165	.5066

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 224 / 11KV ABHYANKAR NAGAR
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.6697	.6516	.6268	.5975	.5975	.5041
2	.5611	.6335	.5792	.591	.5601	.5601	.4854
3	.543	.5973	.6154	.567	.5041	.5415	.4854
4	.543	.5792	.5792	.567	.5041	.4481	.4854
5	.5068	.543	.543	.5731	.5041	.4481	.4854
6	.4887	.5304	.5121	.5373	.5041	.4481	.4854
7	.499	.5304	.5359	.5194	.5041	.4481	.4854
8	.5175	.5853	.5853	.567	.5601	.5041	.5601
9	.6219	.5973	.6413	.6268	.5975	.5415	.5975
10	.6767	.6626	.7167	.6767	.679	.5373	.6024
11	.7316	.724	.7922	.724	.7733	.6089	.6335
12	.7682	.7602	.811	.7796	.7733	.6447	.6268
13	.7682	.7682	.7545	.7343	.7545	.6516	.6024
14	.8962	.7682	.7922	.7421	.7167	.5373	.5552
15	.823	.7762	.8299	.7421	.7167	.4656	.5316
16	.8029	.8402	.811	.7421	.7167	.394	
17	.7655	.4854	.8029	.7421	.7059	.4066	.567
18	.8215	.7842	.7842	.6805	.6379		.6413
19	.8589	.7468	.8962	.8063	.7362		.7167
20	.8962	.8589	.8589	.815	.7442		
21	.8962	.8029	.8215		.7087		
22	.7973	.8215	.8505	.7468	.6722	.6535	.6535
23	.8145	.7783	.7442	.7468	.6722	.5975	.5601
24	.6219	.7133	.6878	.6805	.6348	.5975	.5601
Max	.8962	.8589	.8962	.815	.7733	.6535	.7167
Min	.4887	.4854	.5121	.5194	.5041	.394	.4854
Avg	.7007	.6899	.7165	.6754	.6449	.5316	.5631

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 225 / 11KV SHIVAJI NAGAR(nagpur) SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4805	.2772	.2743	.2427	.2241	.2054
2	.4066	.462	.2587	.2534	.2241	.2054	.1867
3	.4024	.4435	.2378	.2353	.2054	.1867	.1494
4	.3841	.4207	.2378	.2353	.2054	.1867	.1494
5	.3841	.4066	.2378	.2353	.2054	.1867	.1494
6	.3658	.4251	.2402	.2195	.2054	.1867	.1494
7	.462	.4251	.2241	.2195		.1867	.1494
8	.3696	.4066	.2054	.2012	.1867	.1867	.1867
9	.4066	.3841	.2378	.2033	.1494	.1867	.1867
10	.4251		.2378	.2218	.1646	.2172	.2218
11	.4066	.2353	.2012	.2012	.1629	.2353	.2012
12	.4066	.2195	.1646	.1991	.1886	.2172	.2012
13	.4251	.2054	.1629	.2012	.1646	.2353	.181
14	.4481	.1867	.1829	.2218	.1646	.181	.1829
15	.4435	.2402	.1991	.2218	.1646	.181	.1663
16	.4108	.2241	.1829	.2054	.1698	.181	
17	.4108	.2241	.2241	.2427	.2218	.1829	.1829
18	.4294	.1867	.2241	.2103	.2195		.2033
19	.4668	.2241	.2427	.2715	.2378		.2075
20	.5415	.2987	.2427	.2715	.2402		
21	.5228	.2614	.2614		.2587		
22	.567	.2987	.2896	.2427	.2241	.2241	.2241
23	.5853	.3142	.2926	.2614	.2241	.2241	.2241
24	.4755	.5175	.3109	.2743	.2614	.2241	.2241
Max	.5853	.5175	.3109	.2743	.2614	.2353	.2241
Min	.3658	.1867	.1629	.1991	.1494	.181	.1494
Avg	.4410	.3257	.2323	.2315	.2040	.2020	.1873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 226 / 11kv VNIT(College)

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.6224	.6413	.6602	.5788	.5788	.5228
2	.5716	.6036	.6036	.6224	.5601	.5601	.5228
3	.5525	.5847	.5847	.6036	.5601	.5228	.5228
4	.5716	.5906	.5847	.6036	.5601	.5228	.5228
5	.5716	.5847	.5847	.5847	.5601	.5228	.5228
6	.5335	.5281	.5716	.5847	.5601	.5228	.5228
7	.6097	.6478	.679	.6036	.5601	.5228	.5601
8	.6668	.679	.7167	.679	.5228	.4854	.6348
9	.6602	.6979	.679	.7356	.5601	.5228	.6161
10	.7922	.679	.7545	.7733	.6036	.5658	.6224
11	.8676	.8299	1.0562	.7922	.6036	.5658	.7167
12	.9242	.9054	.7922	.6413	.5847	.5716	.7167
13	.8488	.8299	.7733	.7167	.5281	.5658	.679
14	.8002	.8865	.9242	.7167	.5281	.5281	.7167
15	.9054	.9242	.9054	.8488	.5281	.5335	.7545
16	.8962	.9149	.9054	.811	.5658	.5525	.7922
17	1.0269	.9522	.6348	.811	.6413	.5281	.7922
18	.7842	.7282	.7468	.7356	.6224		.6602
19	.7655	.7468	.7468	.7922	.679		.679
20	.7842	.7842	.7468	.7733	.7167		
21	.6722	.6908	.6908		.6224		
22	.7621	.7282	.7545	.6348	.5975	.5975	.5975
23	.7049	.7356	.7167	.6348	.5975	.5975	.5975
24	.6097	.7167	.7049	.6979	.5975	.5975	.5415
Max	1.0269	.9522	1.0562	.8488	.7167	.5975	.7922
Min	.5335	.5281	.5716	.5847	.5228	.4854	.5228
Avg	.7280	.7330	.7291	.6981	.5849	.5482	.6279

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 227 / 11kv CIIMS HOSPITAL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1478	.1357	.1448	.1307	.1307	.112
2	.1463	.1448	.1357	.1448	.112	.1307	.112
3	.128	.124	.1147	.124	.112	.1307	.112
4	.1267	.124	.1147	.1214	.112	.1307	.112
5	.124	.1267	.1357	.1357	.112	.1307	.112
6	.124	.1417	.1402	.1227	.112	.1307	.112
7	.1886	.1886	.1448	.124	.112	.1307	1.7551
8	.1867	.1886	.168	.128	.168	.1307	.112
9	.2477	.2286	.2172	.1905	.1867	.1307	.1494
10	.1905	.2477	.2378	.2286	.1829		.197
11	.2452	.2667	.2353	.2075	.2012	.1867	.1886
12	.2667	.2667	.2012	.2477	.181	.1417	.2477
13	.3048	.3018	.2353	.2286		.1448	.1886
14	.2858	.2667	.2195	.2286	.2012	.1663	.2075
15	.3048	.2561	.2172	.2667	.2195	.1848	.1905
16	.2614	.2614	.2195	.2096	.1991	.1715	.1905
17	.2614	.2241	.2427	.2667	.2075	.1829	.2096
18	.2614	.2241	.2427	.2096	.1867		.1991
19	.1867	.1867	.2054	.2096	.1663		.1629
20	.1867	.168	.1867	.1791	.1494		
21	.2241	.2054	.1494		.1715		
22	.1886	.1867	.168	.1494	.168	.1307	.1494
23	.168	.1867	.1698	.1494	.1307	.112	.1307
24	.1463	.168		.1463	.1494	.1307	.112
Max	.3048	.3018	.2427	.2667	.2195	.1867	1.7551
Min	.124	.124	.1147	.1214	.112	.112	.112
Avg	.2051	.2013	.1842	.1810	.1596	.1436	.2301

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162606 / 11KV VNIT

Feeder No / Name : 228 / 11 KV KACHIPURA OUTGOING

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	06-AUG-17
HR	Load (MW)
11	.4108
Max	.4108
Min	.4108
Avg	.4108

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 201 / 11 KV Switching campus

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7577	.8871	1.0164	.9795	.9425	.924	.8954
2	.7577	.823	.961	.8779	.9055	.8779	.788
3	.6838	.6099	.8871	.823	.8596	.8413	.7522
4	.6653	.7577	.8316	.8316	.8402	.8048	.7522
5	.6283	.7023	.6722	.7947	.8131	.7762	.7164
6	.6036	.6468	.7095	.7762	.8131	.6722	.0362
7	.6602	.6908	.7947	.8131	.8589	.6908	.7602
8	.6224	.6535	.8029	.7947	.8501	.7282	.7602
9	.6653	.7316	.8962	.8501	.8029	.7947	.788
10	.6838	.7499	.9425	.9055	.8775	.8501	.7964
11	.7316	.8954	.985	.8954	.924	.9335	.8048
12	.7392	1.0029	1.0387		.961	.924	.8871
13	.7316	1.086	1.0745	.9412	.9511	.9145	.9145
14	.7392	1.086	1.0745	.9774	.961	1.0164	.924
15	.7468	1.086	1.0745	.9774	.9877	.9511	.7499
16	.7316	1.0924	1.0498	.9313	.8871	.6653	.7499
17	.8596	1.0745	.9774	.9313	.8779	.6584	.7577
18	.8686	.9877	.9391	.9412	.9145	.7392	.823
19	.9425	1.0974	1.0679	.9774	1.0425	.8779	.9412
20	.9795	1.134	1.134	1.086	1.0425	.9328	.9593
21	.9979	1.1706	1.1222	1.086	1.0425	.9145	.9593
22	.9877	1.2071	1.134	1.0498	1.0974	.9412	.9231
23	1.0059	1.1888	1.0974		1.0608	.8954	.8954
24	.823	.9055	1.1458	1.0534	.9795	.9877	.9412
Max	1.0059	1.2071	1.1458	1.086	1.0974	1.0164	.9593
Min	.6036	.6099	.6722	.7762	.8029	.6584	.0362
Avg	.7755	.9278	.9762	.9225	.9289	.8463	.8032

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 202 / 11 kv gokulpeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3582	.3801	.3681	.3814	.3801	.3601	.3224
2	.3761	.3761	.3544	.3641	.3582	.3429	.2865
3	.3544	.362	.3467	.3506	.3222	.3391	.2865
4	.3189	.3544	.3189	.3294	.3018	.3222	.2507
5	.3224	.3189	.3258	.3294	.3052	.2883	.2507
6	.3109	.3142	.3045	.3121	.2883	.2774	.2507
7	.3109	.333	.3403	.3121		.2601	.2507
8	.3292	.3142	.3045	.3045	.3292	.2601	.2896
9	.3841	.3658	.3366	.362	.298	.2926	.2865
10	.4525	.4207	.4207	.4207	.362	.3012	.2896
11	.4755	.0537	.5373	.4715	.4024	.3982	.2896
12	.4755	.0537	.5731		.462	.4024	.3292
13	.4805		.6089	.4706	.4572	.4435	.3696
14	.5487		.5792	.4706	.4706	.4656	.4024
15	.543		.543	.4706	.4755	.4525	.5068
16	.5487	.5731	.543	.4706	.567	.4207	.5121
17	.6401	.5731	.5249	.4298	.567	.0554	.5175
18	.6283	.6516	.6556	.4298	.6268	.4607	.5731
19	.7499	.6878	.7522	.4706	.7087	.5258	.6036
20	.7682	.7343	.7712	.4706	.6984	.5493	.5731
21	.6584	.6379	.6556	.5068	.5847	.5316	.4854
22	.6584	.5258	.5083		.4508	.4508	.4656
23	.4706	.4557	.4656	1.0903	.4287	.4298	.394
24	.4119	.3982	.4031	.3814	.3814	.3944	.362
Max	.7682	.7343	.7712	1.0903	.7087	.5493	.6036
Min	.3109	.0537	.3045	.3045	.2883	.0554	.2507
Avg	.4823	.4231	.4809	.4363	.4446	.3760	.3812

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 203 / 11 KV Dharampeth switching

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0366	.0362	.0358	.0354	.0354	.0358
2	.0362	.0358	.0354	.0362	.0351	.0354	.0358
3	.0358	.0354	.0362	.0362	.0351	.0354	.0358
4	.0177	.0347	.0177	.0177	.0347	.0354	.0358
5	.0171	.0173	.017	.0173	.0168	.0351	.0358
6	.0339	.0175	.017	.0168	.0171	.0343	.0362
7	.0339	.0175	.0171	.017	.0166	.0168	.0362
8	.0171	.0171	.0173	.0171	.0171	.017	.0362
9	.0343	.0362	.0549	.0526	.0532	.0339	.0358
10	.0537	.0724	.0732	.0532	.0724	.0339	.0366
11	.1086	.1075	.1075	.0895	.0914	.0686	.037
12	.1097	.1433	.1448		.1097	.0701	.0366
13	.1086	.1448	.1433	.1448	.1097	.0914	.0549
14	.128	.1448	.1448	.1448	.1086	.0886	.0739
15	.1433	.181	.1791	.1448	.1463	.0716	.128
16	.1417	.1433	.1433	.1448	.1629	.1063	.128
17	.1646	.1433	.1448	.1448	.1646	.1075	.128
18	.128	.1463	.128	.1433	.181	.1052	.128
19	.1848	.1829	.1829	.1448	.1646	.1086	.1463
20	.1663	.1463	.128	.1448	.128	.1086	.1433
21	.1097	.1086	.1075	.1448	.1086	.1097	.0914
22	.1097	.0739	.0716	.0905	.0886	.0914	.0358
23	.0366	.0543	.0537	.0358	.0549	.0716	.0362
24	.0362	.0362	.0362	.0358	.0354	.0354	.0362
Max	.1848	.1829	.1829	.1448	.181	.1097	.1463
Min	.0171	.0171	.017	.0168	.0166	.0168	.0358
Avg	.0830	.0865	.0849	.0806	.0828	.0645	.0652

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 204 / 11 KV Bajaj Nagar

SHEDDABLE URBAN

switching Feeder KV- 11 /
OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0747	.0747	.0747	.0747	.0554	.0358
2	.0747	.0747	.0747	.0739	.0747	.0554	.0358
3	.0747	.0747	.0747	.0747	.0739	.0554	.0358
4	.0747	.0747	.0747	.0747	.0732	.0554	.0358
5	.056	.0747	.0739	.056	.0732	.0554	.0358
6	.056	.0747	.0739	.056		.0554	.0362
7	.0754	.0747	.0739	.056	.0747	.0549	.0362
8	.0754	.0747	.0739	.056	.056	.0732	.0362
9	.056	.0747	.0747	.0747	.056	.0566	.0358
10	.0754	.0747	.0747	.0747	.0747	.056	.0362
11	.0732	.0716	.0358	.0716	.0739	.0739	.0366
12	.0747	.0716	.0358		.0732	.0732	.0554
13	.0732	.0724	.0358	.0724	.0732	.0924	.0732
14	.0739	.0724	.0358	.0724	.0924	.0934	.0739
15	.0747	.0724	.0362	.0724	.0732	.0739	.0549
16	.0739	.0716	.0362	.0362	.0905	.0366	.0549
17	.0914	.0716	.0362	.0358	.0914	.0366	.0549
18	.0934	.0924	.1097	.0362	.0747	.056	.0747
19	.1063	.1052	.0924	.0362	.0739	.056	.0739
20	.1254	.0934	.1109	.0362	.1086	.0732	.0747
21	.124	.1109	.1109	.0362	.0739	.0739	.0747
22	.112	.0934	.112		.0747	.0747	.0358
23	.0747	.0747	.0934	.0747	.0747	.0358	.0358
24	.0747	.0934	.0373	.0747	.0747	.056	.0362
Max	.1254	.1109	.112	.0747	.1086	.0934	.0747
Min	.056	.0716	.0358	.0358	.056	.0358	.0358
Avg	.0808	.0798	.0693	.0603	.0763	.0616	.0487

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 162608 / 11 KV Shankar nagar

Switching

Feeder No / Name : 205 / 11 KV Incommer from
Shankar Na Feeder KV- 11 /
INCOMING

SHEDDABLE URBAN

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.3169	1.4969	1.4815	1.4377	1.3575	1.2894
2	1.1576	1.2803	1.4266	1.3575	1.4003	1.2894	1.1462
3	1.1157	1.1888	1.3352	1.267	1.3032	1.2536	1.1104
4	1.0791	1.1706	1.2803	1.2803	1.2357	1.1999	1.0745
5	1.0059	1.0903	1.2752	1.262	1.262	1.1584	1.0387
6	.9149	1.0349	1.2012	1.1827	1.2254	1.0242	1.0498
7	.9896	1.0349	1.1827	1.1827	1.1706	1.0242	1.0498
8	.9795	.9149	1.2567	1.2567	1.2437	1.0242	1.1222
9	1.0791	1.134	1.262	1.2752	1.1706	1.1706	1.1104
10	1.2012	1.1706	1.3352	1.2752	1.2803	1.1888	1.1222
11	1.4632	1.1283	1.6655	1.2894	1.5546	1.2382	1.134
12	1.4784	1.2715	1.773		1.6078	1.2254	1.2197
13	1.4632	1.7556	1.773	1.5927	1.5912	1.2308	1.2437
14	1.5708	1.8099	1.773	1.6289	1.6278	1.3717	1.2752
15	1.5546	1.8823	1.8461	1.6651	1.6817	1.2936	1.3717
16	1.5708	1.8804	1.7737	1.647	1.6095	1.2071	1.3717
17	1.6461	1.8625	1.7737	1.5565	1.6263	1.2197	1.386
18	1.6263	1.7924	1.773	1.5565	1.701	1.2489	1.5384
19	1.8107	1.9909	1.9909	1.5927	1.8461	1.5384	1.7193
20	1.8111	2.1033	1.9909	1.7375	1.828	1.6289	1.6832
21	1.7193	1.7878	1.8461	1.7737	1.7013	1.5384	1.576
22	1.6461	1.828	1.7375		1.5927	1.4685	1.5023
23	1.4815	1.829	1.701	1.6095	1.5565	1.4327	1.3756
24	1.3169	1.3717	1.6644	1.5181	1.4632	1.4842	1.3756
Max	1.8111	2.1033	1.9909	1.7737	1.8461	1.6289	1.7193
Min	.9149	.9149	1.1827	1.1827	1.1706	1.0242	1.0387
Avg	1.3688	1.4846	1.5889	1.4540	1.4882	1.2841	1.2869

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 201 / 11 KV SHANAKAR NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	.9907	.8688	.811	.7922	.8002	.6516
2	.9054	.9145	.8326	.7733	.7545	.7621	.6154
3	.8488	.8764	.7602	.7733	.7545	.743	.6335
4	.7356	.8192	.724	.7545	.7545	.724	.6335
5	.7167	.7621	.7059	.7356	.7545	.8002	.5973
6	.7922	.8192	.7783	.7733	.7842	.724	.6516
7	.703	.6668	.5973	.7545	.7282	.6668	.6335
8	.7167	.724	.6697	.679	.6535	.6859	.6697
9	.6602	.6668	.6154	.6413	.5975	.6668	.6154
10	.6413	.7621	.6097	.5973	.5601	.6668	.6335
11	.6697	.7167	.7049	.6335	.6348	.5975	.6668
12	.5611	.679	.6668	.6878	.6908	.6722	.7049
13	.7421	.679	.2667	.6878		.6722	.6097
14	.7602	.7545	.8954	.6878	.7282	.6535	.6478
15	.7964		.9145	.6878	.6722	.6161	.6478
16	.6878	.6224	.7811	.724	.6722	.5788	.6478
17	.7421	.6878	.7621	.6878	.6908	.7545	.6287
18	.6859	.6516	.6979	.6335	.7621	.5847	.6161
19	.8002	.7421	.811	.6697	.8764	.6697	.7282
20	.8954	.7964	.8676	.7964	.9335	.6878	.7655
21	.9335	.8507	.8676	.7964	.9526	.6878	.7282
22	.9717	1.0679	.8299	.8326	.9717	.724	.7655
23	.9717	.905	.9242	.8589	.9145	.7421	.7282
24	.9619	1.0479	.8145	.8676	.8215	.8383	.7059
Max	.9717	1.0679	.9242	.8676	.9717	.8383	.7655
Min	.5611	.6224	.2667	.5973	.5601	.5788	.5973
Avg	.7835	.7914	.7486	.7310	.7589	.6966	.6636

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 202 / 11 KV HINDUSTAHAN COLOANY SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.3429	.3077	.3142	.3206	.3048	.2534
2	.2772	.3239	.3077	.2957	.2829	.2858	.2534
3	.2801	.3048	.2896	.2772	.2641	.2858	.2172
4	.2614	.2858	.2715	.2587	.2614	.2667	.2172
5	.2402	.2667	.2715	.2772	.2801	.2667	.2172
6	.2587	.2477	.2534	.2772	.2801	.2286	.1991
7	.2772	.3048	.2715	.2743	.2987	.2477	.2534
8	.2561	.2667	.2534	.2534	.2801	.2477	.2534
9	.2587	.2667	.2353	.2587	.2614	.2858	.3077
10	.2402	.2477	.2667	.2534	.2614	.2667	.2896
11	.2534	.2402	.2477	.2353	.2801	.2926	.2858
12	.2353	.2402	.2286	.2353	.2427	.2743	.2477
13	.2353	.2402	.2286	.1991	.2427	.2195	.2096
14	.2353	.2402	.2477	.2353	.2054	.2012	.2096
15	.2715	.2587	.2477	.3258	.2054	.2012	.2096
16	.2534	.2587	.2477	.2172	.2241	.1829	.2096
17	.2534	.2715	.2667	.2534	.2241	.2033	.2096
18	.2667	.2534	.2353	.2534	.2667	.2402	.2427
19	.3048	.2715	.2534	.2896	.2858	.2715	.2801
20	.3429	.3258	.3077	.2896	.3239	.2715	.2801
21	.3429	.3077	.3292	.2896	.3239	.2715	.3174
22	.381	.362	.3292	.3077	.3239	.2896	.2987
23	.4001	.362	.3511	.3734	.3048	.2715	.2801
24	.3174	.362	.3258	.3326	.3361	.3048	.2534
Max	.4001	.362	.3511	.3734	.3361	.3048	.3174
Min	.2353	.2402	.2286	.1991	.2054	.1829	.1991
Avg	.2801	.2855	.2739	.2741	.2742	.2576	.2498

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 203 / 11 KV NIT-GOKULPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8775	.9526	.905	.9149	.9054	.8764	.7059
2	.8029	.9145	.8507	.8589	.8676	.8383	.6697
3	.7842	.8764	.8145	.8402	.811	.8002	.6516
4	.7655	.8383	.7964	.8029	.7733	.7811	.6516
5	.7468	.8192	.7602	.7842	.7545	.7621	.6335
6	.6722	.724	.724	.6908	.7167	.6668	.6154
7	.7655	.7621	.7602	.7468	.7356	.6478	.5973
8	.7095	.7621	.724	.7282	.7167	.6859	.6697
9	.7842	.7621	.724	.7282	.6979	.6287	.7421
10	.8402	.8192	.8573	.8145	.8029	.7621	.8145
11	.9593	1.0829	1.0288	.9412	.9709	.8029	.9145
12	1.0679	1.0829	1.1431	.9774	1.0456	.8775	.9145
13	1.1041	1.1016	1.105	1.0317	1.0642	.8962	.9526
14	1.1222	1.1203	1.1431	.9774	1.0829	.8402	.9335
15	1.1222	1.1389	1.2003	1.0136	1.0829	.8402	.9145
16	1.1584	1.1949	1.105	1.0498	1.0456	.8029	.9717
17	1.1584	1.1222	1.1431	1.1041	1.0642	.8402	.9717
18	1.2765	1.086	1.363	1.1584	1.1812	.9335	1.0642
19	1.3908	1.267	1.363	1.3032	1.3717	1.0679	1.1949
20	1.448	1.3032	1.2986	1.2851	1.3908	1.086	1.1389
21	1.3146	1.267	1.262	1.2308	1.2955	1.0498	1.0642
22	1.1622	1.6108	1.0791	.9774	1.086	.8688	.8775
23	1.1431	1.1041	1.0791	1.0456	1.0479	.8688	.8215
24	.9522	1.0479	.9774	.9709	.9997	.9335	.6516
Max	1.448	1.6108	1.363	1.3032	1.3908	1.086	1.1949
Min	.6722	.724	.724	.6908	.6979	.6287	.5973
Avg	1.0054	1.0317	1.0086	.9573	.9796	.8399	.8390

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 204 / 11KV BULDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1524	.1448	.1509	.1509	.1524	.1267
2	.1494	.1524	.1448	.1509	.1509	.1524	.1448
3	.1494	.1524	.1448	.1509	.1509	.1524	.1267
4	.1307	.1524	.1448	.1509	.1509	.1524	.1307
5	.1494	.1524	.1448	.1509	.1509	.1524	.1267
6	.1307	.1524	.1448	.1509	.1509	.1334	.1267
7	.1307	.1334	.1448	.132	.132	.1334	.1267
8	.168	.1524	.1448	.168	.1509	.1524	.1267
9	.2054	.1905	.2172	.1886	.1886	.1524	.1267
10	.3174	.2858	.3429	.2715	.2614	.1715	.1629
11	.3077	.3174	.362	.3077	.2801	.1355	.1905
12	.3258	.3206	.3048	.3077	.2427	.1677	.1905
13	.3077	.3018	.3048	.3077	.2614	.1543	.1905
14	.3258	.3018	.3048	.3258	.2427	.1562	.1905
15	.3077	.3018	.3239	.2896	.2614	.1475	.2096
16	.3077	.3206	.2858	.3077	.2614	.1509	.1905
17	.3077	.3439	.3239	.3439	.2614	.125	.1905
18	.3239	.3077	.3206	.3258	.2667	.125	.1867
19	.3048	.2715	.2829	.2715	.2096	.1448	.168
20	.2477	.2172	.2452	.1991	.1905	.1448	.168
21	.1715	.181	.1698	.1629	.1524	.1448	.1494
22	.1715	.1629	.1509	.1629	.1524	.1448	.1494
23	.1715	.1629	.1509	.1494	.1524	.1448	.1494
24	.1494	.1524	.1448	.1509	.1509	.1524	.1448
Max	.3258	.3439	.362	.3439	.2801	.1715	.2096
Min	.1307	.1334	.1448	.132	.132	.125	.1267
Avg	.2255	.2225	.2247	.2199	.1968	.1477	.1581

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 209 / 11 KV HILLTOP

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.6097	.5792	.5729	.547	.5525	.4706
2	.4938	.5716	.543	.5487	.5281	.5144	.4525
3	.4805	.5525	.543	.5487	.5093	.4954	.4525
4	.4805	.5335	.5068	.4805	.4904	.4763	.4525
5	.499	.5335	.4887	.4481	.4668	.4572	.4344
6	.4207	.4954	.4525		.4481	.4382	.362
7	.439	.4572	.4525	.4668	.4668	.4001	.3801
8	.415	.4763	.4163	.4435	.4294	.4382	.3801
9	.4294	.4382	.4163	.4108	.4108	.4382	.4525
10	.415	.4382	.4001	.3801	.3921	.4382	.4525
11	.4344	.4108	.381	.3801	.3921	.4294	.4763
12	.3801	.3734	.362	.362	.3921	.439	.4382
13	.3801	.415	.4001	.3801	.3921	.439	.381
14	.4344	.4338	.4572	.6878	.4108	.3841	.362
15	.4163	.4294	.4572	.6878	.4108	.3658	.381
16	.4344	.4481	.4572	.3982	.3921	.3658	.381
17	.4344	.4344	.4572	.3982	.3921	.3841	.381
18	.4954	.4525	.4435	.3801	.4191	.4024	.4294
19	.5716	.5249	.5611	.5249	.5525	.5068	.5228
20	.724	.5973	.6154	.5792	.6287	.5611	.5415
21	.7049	.6516	.6219	.5792	.6287	.5249	.5601
22	.724	.6697	.6584	.6154	.6287	.5068	.5415
23	.743	.6878	.1463	.6348	.6478	.543	.5228
24	.5975	.6478	.6154	.5853	.6161	.6097	.543
Max	.743	.6878	.6584	.6878	.6478	.6097	.5601
Min	.3801	.3734	.1463	.362	.3921	.3658	.362
Avg	.5027	.5118	.4763	.4997	.4830	.4629	.4480

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 210 / 11 KV University Feeder

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1334	.1267	.128	.132	.1524	.1267
2	.128	.1334	.1267	.1463	.132	.1524	.1086
3	.1097	.1334	.1267	.128	.132	.1524	.1267
4	.1097	.1334	.1267	.128	.132	.1334	.1267
5	.1294	.1334	.1267	.128	.132	.1334	.1267
6	.0914	.1143	.0905	.1097	.112	.1143	.1086
7	.1109	.1143	.1086	.1109	.1307	.1143	.1086
8	.1307	.0953	.1086	.1294	.1307	.1143	.1267
9	.1494	.1334	.1448	.1294	.1494	.1143	.1267
10	.1848	.1905	.2096	.1991	.2054	.1143	.1629
11	.3439	.4066	.4382	.2896	.3361	.128	.3048
12	.3982	.4207	.4572	.2896	.3734	.1646	.3429
13	.4344	.4207	.4572	.3439	.3361	.1829	.3048
14	.3982	.439	.4763	.3258	.3174	.1463	.2858
15	.4163	.4251	.4572	.3258	.2987	.1463	.3048
16	.3982	.4435	.4191	.2896	.2987	.1463	.3048
17	.362	.362	.4001	.2896	.2614	.128	.2477
18	.1905	.181	.1991	.2534	.1905	.1097	.1494
19	.1715	.1448	.1629	.181	.1715	.1629	.1494
20	.1524	.1629	.1448	.1629	.1524	.1629	.168
21	.1524	.1629	.1646	.1629	.1524	.1448	.1494
22	.1715	.1629	.1646	.1629	.1524	.1448	.168
23	.1524	.1448		.1494	.1334	.1448	.1494
24	.128	.1334	.1448	.1463		.1524	.1267
Max	.4344	.4435	.4763	.3439	.3734	.1829	.3429
Min	.0914	.0953	.0905	.1097	.112	.1097	.1086
Avg	.2143	.2219	.2340	.1962	.1984	.1400	.1835

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 214 / 11KV TELANGKHEDI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722	.743	.6878	.7282	.6979	.6859	.543
2	.6535	.724	.6878	.6908	.679	.6668	.543
3	.6348	.7049	.6697	.6722	.679	.6478	.543
4	.6161	.6859	.6516	.6722	.6413	.6287	.543
5	.6161	.6668	.6335	.6535	.6413	.6097	.5249
6	.5975	.6287	.6154	.6161	.6036	.5525	.5249
7	.5788	.6097	.5973	.5975	.6036	.5335	.4887
8	.5788	.5906	.543	.5415	.5658	.5335	.543
9	.5788	.5335	.5068	.5601	.5658	.5525	.5249
10	.6535	.6478	.6287	.6335	.5788	.381	.6154
11		.6535	.6287	.6154	.6348	.567	.6287
12		.6468	.6478	.6154	.6348	.5487	.5906
13		.6584	.6668	.5792	.6348	.5487	.5716
14		.6838	.724	.5973	.6161	.5487	.5335
15		.7282	.743	.6516	.6348	.5487	.5716
16		.7095	.6859	.6697	.5975	.5121	.5716
17		.6697	.6859	.6516	.5975	.4572	.5716
18	.724	.6697	.6535	.6154	.6478	.5121	.6348
19	.8192	.7964	.8029	.724	.8002	.6154	.6722
20	.8573	.7783	.823	.7602	.7621	.6516	.7095
21	.8764	.8145	.823	.7783	.7621	.6516	.6908
22	.8573	.7964	.8048	.7602	.7621	.6335	.6722
23	.8573	.7783	.7682	.7842	.7621	.6335	.6161
24	.7468	.7811	.7421	.7282	.7545	.7049	.543
Max	.8764	.8145	.823	.7842	.8002	.7049	.7095
Min	.5788	.5335	.5068	.5415	.5658	.381	.4887
Avg	.7011	.6958	.6842	.6623	.6607	.5802	.5822

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164805 / 33 KV AMRAVATI ROAD

Feeder No / Name : 215 / 11KV TILAK NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8029	.8573	.8145	.8402	.8299	.8002	.7059
2	.7655	.8383	.7602	.7842	.7922	.7811	.6878
3	.7468	.8192	.7602	.7655	.7545	.7621	.6154
4	.7282	.8002	.7421	.7468	.7167	.743	.6154
5	.7095	.7811	.724	.7468	.7167	.7049	.6335
6	.7095	.7811	.7059	.7282	.679	.6478	.6516
7	.5788	.743	.7059	.7468	.7545	.7049	.6335
8	.7655	.7621	.7783	.7282	.7167	.724	.7059
9	.7842	.7811	.8145	.7655	.7545	.7811	.7059
10	.9709	.9145	.9335	.7964	.8215	.7621	.7964
11	1.0679	1.0829	1.086	.9774	.8962	.7842	
12	1.0317	1.0829	1.0479	.9955	.9896	.8215	.9335
13	1.086	1.0642	1.1241	.9955	1.0456	.8775	.8764
14	1.0679	1.0829	1.105	.9774	1.0269	.8402	.8764
15	1.1765		1.2003	.9774	1.0082	.985	.9335
16	1.1403	1.1576	1.1812	.9955	1.0456	.8215	.8764
17	1.1765	1.1403	1.1241	.9593	.9896	.7842	.9526
18	1.1431	1.1041	1.0642	1.0498	1.0098	.8589	.9149
19	1.1812	1.1041	1.0829	1.0498		.905	.9522
20	1.105	1.0136	1.0269	1.0136	1.0669	.905	.9522
21	1.0288	.905	.9896	.9231	.9907	.8688	.8962
22	1.0288	.9231	.9522	.8145	.9145	.8507	.8029
23	.9907	.905	.8962	.8775	.8764	.7421	.7468
24	.8589	.8954	.8688	.8589	.8488	.8192	.6154
Max	1.1812	1.1576	1.2003	1.0498	1.0669	.985	.9526
Min	.5788	.743	.7059	.7282	.679	.6478	.6154
Avg	.9435	.9365	.9370	.8797	.8802	.8031	.7861

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 201 / 11KV VNIT(nagpur)

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			2.3152	2.1068	2.0538	1.848
2			2.2405	2.0328	1.9791	1.7551
3			2.2032	1.9959	1.3344	1.6991
4			2.0911		1.8671	1.6975
5			1.9418	1.885	1.7737	1.6221
6			1.8671	1.7924	1.6617	1.6598
7			1.8671	1.8671	1.6804	1.6975
8			2.0165	1.9044	1.7924	1.9239
9			2.0165	1.9418	1.8111	2.0559
10	1.2696		2.1098	2.2405	1.8298	2.1125
11			2.3152	2.2822	2.0538	2.2405
12				2.3011	2.0911	2.2405
13			2.4086	2.3388	1.9044	2.6886
14			2.2965	2.1879	1.8298	2.0165
15			2.4459	2.1691	1.7924	2.1098
16			2.3899	2.1472	1.8111	2.0165
17			2.3899	2.2218	1.7924	2.1068
18			2.3899	2.1098	1.8107	2.1845
19			2.5766	2.3899	2.1879	2.384
20			2.6886	2.4832	2.2634	2.384
21			2.4832	2.3712	2.2257	2.2361
22		2.8006	2.4394	2.3525	2.1879	2.2177
23		2.5873	2.4764	2.2965	2.1313	2.0165
24			2.4025	2.2965	2.1658	1.9805
Max	1.2696	2.8006	2.6886	2.4832	2.2634	2.6886
Min	1.2696	2.5873	1.8671	1.7924	1.3344	1.6221
Avg	1.2696	2.6940	2.2770	2.1615	1.9180	2.0372

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 202 / 11KV shankar nagar I

SHEDDABLE URBAN

Feeder KV- 11 / INCOMING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.307	1.5089	1.531	1.4045	1.419	1.1827
2	1.1203	1.2323	1.4563	1.4563	1.3306	1.3256	1.1203
3	1.0829	1.1949	1.3817	1.3817	1.3491	1.251	1.1576
4	1.0269	1.1203	1.3203	1.2696	1.2567	1.1763	1.1317
5	1.0269	1.0829	1.2449	1.2323	1.2382	1.1203	1.094
6	.9709	1.0269	1.2826	1.1949	1.1389	1.0456	1.0562
7		1.1016	1.2071	1.1949	1.1949	1.0082	1.094
8	.9335	.9709	1.1694	1.1203	1.0456	1.0456	1.1317
9	1.1506	.9896	1.2883	1.1949	1.1273	1.1203	1.2826
10	1.2071	1.2696	1.4937	1.363	1.2696	1.1576	1.3203
11	1.4937	1.2136	1.643	1.4937	1.5089	1.2323	1.4563
12	1.5844	1.251	1.7924		1.5844	1.3443	1.4563
13	1.5684	1.8484	1.8671	1.7924	1.1883	1.2883	1.4003
14	1.587	1.6991	1.8298	1.7177	1.6598	1.1949	1.363
15	1.643	1.8671	1.8298	1.7924	1.6409	1.2696	1.419
16	1.6804	1.9791	1.7926	1.7177	1.643	1.1949	1.3817
17	1.6804	1.8671	1.7741	1.6804	1.587	1.1949	1.2936
18	1.4937	1.8484	1.848	1.7177	1.7364	1.2637	1.5154
19	1.7924	2.0351	1.9959	1.9418	1.8671	1.5655	1.7372
20	1.9418	2.0911	2.0698	1.9605	1.8858	1.6598	1.7002
21	1.7924	2.0351	1.8296	1.8671	1.7737	1.6221	1.5497
22	1.643	1.8861	1.7924	1.7187	1.643	1.5089	1.423
23	1.4937	1.8107	1.7002	1.6263	1.6057	1.4712	1.307
24	1.363	1.4377	1.6975	1.5524	1.6057	1.4937	1.3203
Max	1.9418	2.0911	2.0698	1.9605	1.8858	1.6598	1.7372
Min	.9335	.9709	1.1694	1.1203	1.0456	1.0082	1.0562
Avg	1.4118	1.5069	1.6173	1.5442	1.4702	1.2906	1.3289

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 203 / 11KV Ramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.6908	.679	.6348	.6653	.6908	.5914
2	.5601	.6535	.6535	.6348	.6283	.6161	.5975
3	.5228	.6348	.6161	.5975	.6099	.5975	.5601
4	.5041	.6348	.6036	.5975	.5914	.5788	.5281
5	.5041	.5975	.5847	.5975	.5914	.5601	.4904
6	.5228	.5975	.5658	.5975	.5788	.5415	.5093
7	.6161	.6348	.6224	.5975	.6161	.5041	.5281
8	.6161	.6161	.6413	.5975	.6348	.6161	.6224
9	.679	.6722	.6722	.6348	.6348	.5975	.6602
10	.7167	.7282	.7468	.7468	.6722	.5975	.7545
11	.9335	.9709	.8589	.8589	.9808	.6348	.8215
12	1.0185	.9522	1.0456	.9335	.9997	.7468	.8029
13	1.0082	.9709	.9522	.8962	.9054	.7468	.8029
14	1.0082	.9896	1.0456	.8589	.9054	.7282	.7655
15	1.1203	1.0829	1.0456	.9335	.9054	.6722	.8029
16	1.1203	1.0642	1.0082	.9335	.9335	.7282	.7842
17	1.0829	1.0642	1.0269	.9709	.8402	.7468	.8131
18	1.0829	.9896	1.0164	1.0456	.9709	.7922	.8775
19	1.1949	1.1203	1.1273	1.0642	1.0642	.811	.9055
20	1.0829	1.1016	1.1088	1.0456	1.0642	.9054	.924
21	1.0642	.9709		1.0269	.9896	.8676	.8131
22	.8962	.8676	.8962	.8871	.8589	.7922	.7577
23	.7842	.7733	.8131	.7762	.7655	.7167	.6535
24	.6535	.7282	.7167	.7023	.7655	.7095	.6413
Max	1.1949	1.1203	1.1273	1.0642	1.0642	.9054	.924
Min	.5041	.5975	.5658	.5975	.5788	.5041	.4904
Avg	.8280	.8378	.8281	.7987	.7988	.6874	.7087

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 204 / 11Kv Dandige Layout

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8029	.8299	.8589	.7577	.7282	.6653
2	.6722	.7468	.7842	.7842	.7392	.5053	.6161
3	.6722	.7095	.7655	.7468	.7023	.6722	.6161
4	.6722	.7095	.7545		.6653	.6348	.6036
5	.6722	.6722	.7167	.7095	.6653	.5975	.5658
6	.6722	.6722	.679	.6348	.6161	.5788	.6036
7	.6161	.6348	.6413	.6722	.5975	.5041	.6036
8	.6348	.6722	.679	.5975	.6348	.5415	.6413
9	.8676	.8402	.8215	.8962	.7282	.6908	.8299
10	.9808	1.0642	.9896	.9709	.8775	.7095	.9054
11	1.1203	1.1763	1.2136	1.0642	1.094	.7468	.9709
12	1.1694	1.1576	1.1949	1.1016	1.0751	.7842	1.0082
13	1.1203	1.1203	1.1203	1.0642	.9808	.7468	.8962
14	1.1949	1.1949	1.2696	1.1389	1.0374	.7468	.9149
15	1.2136	1.1576	1.2696	1.1016	1.0374	.7468	.9335
16	1.2696	1.3443	1.2567	1.1576	1.0456	.6722	.8589
17	1.2136	1.251	1.1949	1.1389	.9709	.7095	.924
18	1.1576	1.2323	1.1088	1.1389	1.0082	.7733	.9522
19	1.2136	1.2136	1.1458	1.1949	1.1389	.9054	.961
20	1.1389	1.1576	1.0534	1.1016	1.0456	.9431	.8686
21	1.0829	1.0642		1.0456	.9896	.9808	.8131
22	1.0456	1.1317	1.1203	.961	1.0082	.9054	
23	.9709	1.0185	.961	.961	.9149	.9054	.7468
24	.8402	.8589	.9054	.8871	.9149	.7842	.7167
Max	1.2696	1.3443	1.2696	1.1949	1.1389	.9808	1.0082
Min	.6161	.6348	.6413	.5975	.5975	.5041	.5658
Avg	.9566	.9835	.9772	.9534	.8852	.7297	.7920

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 205 / 11KV SMG Hospital

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.168	.2263	.1867	.1663	.2054	.1478
2		.1867	.2054	.168	.1478	.1867	.1494
3	.1867	.1867	.168	.1494	.1294	.2054	.1494
4	.1494	.168	.1698	.1494	.1478	.168	.1509
5	.1494	.168	.1509	.168	.1294	.1494	.1509
6	.1307	.1867	.1886	.168	.1307	.168	.1509
7	.2987	.1867	.1698	.1494	.1494	.1307	.132
8	.1307	.2054	.2263	.1494	.168	.1494	.132
9	.2452	.2427	.2614	.2241	.2987	.1867	.3772
10	.2452	.2427	.2987	.2801	.2801	.1867	.1886
11	.2614	.2987	.2987	.2614	.2829	.2054	.2241
12	.3018	.3174	.3174	.2801	.3018	.168	.2241
13	.2987	.3734	.2801	.2801	.6224	.1867	.2241
14	.3174	.2987	.3174	.2987	.2829	.1867	.2054
15	.3361	.3361	.3142	.2427	.3018	.168	.2241
16	.2987	.2987	.2987	.2241	.2987	.168	.2241
17	.3174	.2801	.3361	.2241	.2801	.168	.2218
18	.3174	.2801	.3326	.2054	.2801	.1886	.2241
19	.2801	.2987	.2957	.2241	.2427	.1886	.4066
20	.2427	.2614	.2957	.2241	.2987	.1698	.2218
21	.2241	.2427		.2241	.2614	.1886	.1848
22	.2987	.2641	.2241	.2402	.2614	.2075	.1663
23	.2241	.2641	.2218	.2033	.2427	.2263	.1494
24	.2054	.2054	.2452	.2033	.2427	.2427	.1886
Max	.3361	.3734	.3361	.2987	.6224	.2427	.4066
Min	.1307	.168	.1509	.1494	.1294	.1307	.132
Avg	.2463	.2484	.2540	.2137	.2478	.1833	.2008

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 206 / 11KV DHARAMPETH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.4108	.4527	.4108	.3696	.3547	.3326
2	.3361	.4108	.3734	.3734	.3696	.3174	.2987
3	.3361	.3734	.3734	.3361	.3326	.3174	.2987
4	.3174	.3734	.3395	.3361	.2957	.3174	.2829
5	.3174	.3361	.3395	.3174	.2957	.3174	.2641
6	.2987	.3174	.3772	.3174	.3547	.3174	.3018
7	.2987	.3174	.3395	.3361	.3547	.2987	.3018
8	.3734	.3361	.3584	.3174	.3361	.3174	.3772
9	.3772	.3921	.3361	.4108	.3734	.3174	.415
10	.4904	.4854	.4481	.5041	.4294	.3174	.3961
11	.7095	.6722	.6722	.6161	.6413	.3361	.5415
12	.7922	.8215	.7842		.6036	.4854	.5788
13	.8215	.7655	.8215	.8029	.7167	.5041	.5975
14	.8215	.8215	.8029	.6908	.679	.5415	.5788
15	.8215	.8215	.8029	.7468	.7167	.0373	.5975
16	.7468	.8402	.7282	.7655	.6722	.5041	.5788
17	.7655	.8215	.8029	.7468	.6535	.4854	.5914
18	.7655	.7842	.7577	.7468	.7468	.4904	.6468
19	.7842	.8215		.7095	.7842	.6036	
20	.8589	.8215	.7577	.7655	.7655	.6224	.6653
21	.7468	.7282	.5914	.6908	.6722	.5658	.5175
22	.5975	.6036	.6535	.5359	.5415	.5281	.4435
23	.5975	.5847	.5914	.5175	.5228	.4715	.3734
24	.4294	.4854	.5093	.4435	.5228	.4481	.415
Max	.8589	.8402	.8215	.8029	.7842	.6224	.6653
Min	.2987	.3174	.3361	.3174	.2957	.0373	.2641
Avg	.5725	.5894	.5658	.5408	.5313	.4090	.4519

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 208 / 11KV TRIKONI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1494	.1509	.1867	.2033	.1867	.1848
2	.1867	.1494	.1494	.1494	.1848	.2054	.1867
3	.1867	.1494	.1494	.1494	.1663	.1867	.168
4	.1867	.1494	.132	.1494	.1663	.1867	.1509
5	.1867	.1494	.132	.1494	.1663	.1867	.1509
6	.1867	.1494	.1509	.1494	.168	.1867	.1698
7	.1867	.1494	.1509	.1494	.1867	.1867	.1886
8	.2054	.168	1.1694	.1867	.1494	.2241	.1698
9	.2263	.1494	.2427	.1307	.2241	.1867	.2452
10	.3018	.2427	.2614	.2987	.2801	.1867	.2263
11	.4108	.4108	.3734	.3547	.3395	.1867	.2987
12	.5093	.4854	.5041		.4527	.2614	.2987
13	.5228	.5041	.4854	.4668	.4715	.2614	.3361
14	.5041	.4854	.5041	.3921	.4338	.2801	.3547
15	.4854	.4854	.5041	.3921	.415	.2987	.3921
16	.5228	.5228	.462	.4108	.4294	.3361	.3547
17	.4854	.4854	.5228	.3921	.3921	.2987	.3881
18	.4854	.4668	.499	.3921	.3734	.3018	.4108
19	.5228	.4668	.5175	.4854	.4294	.3772	.3881
20	.5228	.4481	.4435	.4294	.4481	.3772	.3696
21	.4294	.3921	.2957	.3361	.3734	.3018	.2957
22	.2801	.2641	.2241	.2402	.2801	.2452	.2402
23	.2241	.2075	.2218	.2218	.2427	.2263	.2054
24	.2241	.2054	.2075	.1848	.2427	.2241	.2263
Max	.5228	.5228	1.1694	.4854	.4715	.3772	.4108
Min	.1867	.1494	.132	.1307	.1494	.1867	.1509
Avg	.3412	.3098	.3523	.2782	.3008	.2458	.2667

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 209 / 11 kv Hill Top II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.9896	.9997	.9709	.9055	.8962	.8131
2	.8962	.9522	.9335	.8962	.8871	.8589	.7842
3	.8589	.8962	.9335	.8589	.7577	.8215	.7655
4	.8215	.8402	.9054	.8215	.8501	.7842	.7545
5	.8215	.8402	.8676	.7842	.8131	.7468	.7167
6	.7842	.8029	.811	.7842	.7655	.7095	.6979
7	.7468	.7655	.7356	.7468	.7655	.6722	.679
8	.7842	.7655	.7733	.6722	.6908	.6908	.6413
9	.7922	.7468	.7468	.7282	.7468	.7095	.7922
10	.7733	.7655	.7095	.7468	.7468	.6722	.7733
11	.7468	.7095	.7095	.7282	.7167	.7095	.7655
12	.7167	.6722	.6908	.6908	.6979	.6908	.6722
13	.7095	.6908	.7095	.6722	.6979	.6908	.6348
14	.7282	.7282	.8215	.6908	.7167	.6348	.5975
15	.8215	.7655	.8215	.7095	.7356	.6535	.5975
16	.8215	.7655	.7842	.7282	.6908	.6161	.5975
17	.8215	.7842	.8029	.7095	.6908	.5975	.6099
18	.7842	.7468	.8131	.7468	.7282	.6413	.7095
19	.9522	.9335	.924	.8962	.9522	.8865	.9055
20	1.0642	.9149	1.0534	1.0082	.9896	.9242	.9425
21	1.1016	1.1016	1.0829	1.0456	1.0082	.9242	.961
22	1.1763	1.1506	1.1389	1.0719	1.0269	.9619	.961
23	1.1576	1.1506	1.1458	1.0719	1.0456	.9431	.8962
24	.9709	1.0642	1.094	1.0164	1.0456	.9335	.8488
Max	1.1763	1.1506	1.1458	1.0719	1.0456	.9619	.961
Min	.7095	.6722	.6908	.6722	.6908	.5975	.5975
Avg	.8645	.8559	.8753	.8248	.8197	.7654	.7549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 214 / 11KV SHIVAJI PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7842	.8488	.8215	.7762	.7095	.6468
2		.7468	.7655	.7842	.7577	.7095	.6161
3	.7095	.7095	.7468	.7842		.0691	.5975
4	.6535	.6722	.7167	.7468	.6653	.6535	.5658
5	.6348	.6348	.679	.7095	.6653	.6161	.5281
6	.5975	.5975	.6602	.5788	.5975	.5975	.5658
7	.6535	.6161	.6036	.6535	.6161	.5601	.547
8	.5601	.6161	.6224	.5975	.5975	.5975	.7167
9		.6348	.6161	.6535	.6535	.5975	.7356
10	.8676	.6908	.6161	.6535	.6161	.6161	.7356
11	.7468		.6535	.6908	.679	.6535	.8215
12	.7167		.7655	.7095	.7733	.6348	.7842
13			.6908	.6535	.7356	.5975	.7095
14	.6722	.8775	.8029	.6722	.7356	.5601	.6348
15	.7468	.8402	.8029	.7095	.6979	.5601	.5975
16	.8402	.9149	.7577	.7655	.6722	.5788	.5788
17	.8215	.8775	.7468	.7282	.7095	.5975	.6653
18	.8402	.8589	.8131	.7842	.7095	.5847	.6722
19	.8962	.8962	.8686	.8215	.8029	.7356	.7762
20	.9709	.9709	.8871	.8215	.8589	.7545	.7392
21	.9709	.9335	.9055	.8215	.7468	.6979	.7023
22	.9709	.9431	.8962	.8501	.7842	.7356	.7023
23	.9522	.9431	.9425	.8871	.8215	.7545	.6908
24	.8215	.8962	.9054	.8316	.8131	.8402	.6979
Max	.9709	.9709	.9425	.8871	.8589	.8402	.8215
Min	.5601	.5975	.6036	.5788	.5975	.0691	.5281
Avg	.7805	.7931	.7631	.7387	.7167	.6255	.6678

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 215 / 11KV Kachipura Incomer
Feeder KV- 11 / INCOMING

SHEDDABLE URBAN

DATE	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)
1		1.363	1.1458
2		1.2696	1.1576
3		1.1763	1.0456
4		1.1389	1.0185
5		1.1203	1.0374
6		1.0829	1.0562
7		1.0829	1.1317
8		1.1203	1.2071
9		1.2696	1.3957
10		1.2323	1.5466
11		1.2696	1.6804
12		1.4937	1.6057
13		1.419	1.6057
14		1.4563	1.475
15		1.2883	1.4937
16	1.8671	1.3443	1.531
17	1.8671	1.3443	.8131
18	1.8484	1.4335	1.5893
19	2.4832	1.7353	1.7002
20	2.0165	1.6975	1.6448
21	1.7924	1.6598	1.4969
22	1.6244	1.5278	1.423
23	1.587	1.3957	1.2696
24	1.587	1.4937	1.2826
Max	2.4832	1.7353	1.7002
Min	1.587	1.0829	.8131
Avg	1.8526	1.3506	1.3481

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 217 / 11KV ALANKAR TALKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.6348	.679	.7095	.6468	.3361	.2772
2	.5788	.6348	.6535	.6908	.6099	.3174	.2801
3	.5601	.5975	.6161	.6722	.4805	.2987	.2427
4	.5415	.5975	.6036	.6348	.5729	.2801	.2263
5	.5415	.5975	.5658	.5975	.5729	.2614	.2263
6	.5415	.5601	.547	.5601	.5228	.2614	.2452
7	.5415	.5601	.547	.5601	.5228	.2987	.2829
8	.5415	.5415	.5093	.5041	.5228	.2801	.3018
9	.547	.5975	.5415	.5601	.5601	.2801	.3772
10	.7167	.6722	.6348	.6535	.6161	.2801	.3961
11	.7655	.7282	.7282	.6348	.6602	.3921	.3547
12	.7922	.7655	.7842	.7468	.7545	.3547	.3734
13	.7282	.8029	.7468	.7095	.7545	.3921	.3734
14	.8029	.8215	.8589	.7095	.7545	.3547	.3547
15	.8775	.8215	.8501	.7842	.4715	.3361	.3361
16	.8402	.8589	.8402	.8215	.4481	.3547	.3734
17	.8589	.8215	.8029	.7842	.4668	.3547	.3881
18	.8029	.7468	.8131	.7655	.4668	.4527	.4108
19	.8962	.8775		.8775	.4854	.4527	.462
20	.9709	.9709	.8871	.8589	.5228	.4904	.462
21	.8962	.8589	.7392	.8215	.4854	.415	.4066
22	.8402	.811	.8402	.7392	.4294	.3772	.3696
23	.8215	.8488	.7762	.7577	.3921	.3395	.3361
24	.6722	.7095	.7167	.7207	.6468	.3361	.3206
Max	.9709	.9709	.8871	.8775	.7545	.4904	.462
Min	.5415	.5415	.5093	.5041	.3921	.2614	.2263
Avg	.7205	.7265	.7079	.7031	.5569	.3457	.3407

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 218 / 11KV MADHUMADHAV

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.168	.1886	.1867	.1848	.168	.1848
2	.168	.168	.168	.168	.1478	.0137	.1494
3	.168	.168	.168	.168	.0924	.1494	.1494
4	.1494	.168	.1698	.168	.1478	.1494	.1509
5	.1494	.1494	.1698	.168		.1494	.1509
6	.1494	.168	.1698	.168	.1867	.1494	.1509
7	.1867	.1867	.1698	.168	.1494	.1494	.1509
8	.1494	.168	.1886	.168	.168	.1494	.1698
9	.2075	.1867	.1867	.2054	.1867	.168	.2452
10	.3395	.3174	.2987	.3361	.2801	.168	.2829
11	.5041	.4668	.4294	.5041	.4338	.2427	.3734
12	.6036	.5041	.5601	.5601	.5093	.2801	.4668
13	.5975	.5415	.5601	.5601	.6036	.2987	.4481
14	.5601	.5788	.5544	.5415	.5281	.2987	.4481
15	.5601	.5415	.5601	.5415	.5093	.2801	.4481
16	.5975	.5601	.5544	.5415	.5601	.2801	.4294
17	.5975	.5415	.5228	.5415	.5601	.2987	.4251
18	.5415	.5228	.5359	.5228	.5041	.3206	.4108
19	.5228	.5415	.5359	.5415	.5228	.3206	.4435
20	.5415	.5415	.462	.4668	.4854	.3395	.3696
21	.4668	.4108	.3142	.4108	.4294	.3395	.2772
22	.3174	.3018	.2801	.2772	.2987	.2829	.2218
23	.2987	.2452	.2587	.2402	.2614	.2263	.2054
24	.2241	.2241	.2263	.2218	.2033	.2241	.1886
Max	.6036	.5788	.5601	.5601	.6036	.3395	.4668
Min	.1494	.1494	.168	.168	.0924	.0137	.1494
Avg	.3654	.3488	.3430	.3490	.3458	.2269	.2892

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

SHANKAR NAGAR S/DN.[681] BU 4681

Substation No/ Name :- 164820 / 33KV SHANKAR NAGAR

Feeder No / Name : 219 / POONAM CENTRAL MALL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0943	.0934	.0924	.0934	.0924
2	.0934	.0934	.0934	.0934	.0924	.0648	.0934
3	.0934	.0934	.0934	.0934	.0924	.0934	.0934
4	.0934	.0934	.0943	.0934	.0924	.0934	.0943
5	.0934	.0934	.0943	.0934	.0924	.0934	.0943
6	.0934	.0934	.0943	.0934	.0747	.0934	.0943
7	.0934	.0934	.0943	.0934	.0747	.0934	.0943
8	.0934	.0934	.0943	.0934	.0934	.0934	.0943
9	.0943	.0934	.0934	.112	.112	.0934	.0943
10	.1132	.0934	.112	.1494	.168	.1307	.1132
11	.2987	.5415	.4481	.6535	.547	.6161	.3361
12	.6979	.7095	.7282	.6535	.5847	.6161	.6535
13	.7095	.6348	.6722	.6348	.6413	.6535	.6161
14	.6535	.6722	.6908	.6348	.6413	.6908	.5788
15	.6348	.6535	.6908	.6348	.6602	.6908	.6161
16	.6535	.6348	.6348	.6535	.6535	.6722	.6161
17	.6535	.6348	.6348	.6161	.6535	.7655	.5914
18	.6535	.6722	.6468	.6908	.6722	.7922	.6161
19	.6722	.6908	.7207	.7095	.7655	.8676	.6099
20	.6908	.6535	.7392	.7468	.7468	.811	.6099
21	.6722	.6348	.6838	.7095	.7282	.811	.5914
22	.5788	.5658	.6722	.5914	.6908	.6979	.5175
23	.0934	.1132	.5914	.6099	.6161	.6413	.112
24	.0934	.0934	.0943	.0924	.0924	.0905	.5847
Max	.7095	.7095	.7392	.7468	.7655	.8676	.6535
Min	.0934	.0934	.0934	.0924	.0747	.0648	.0924
Avg	.3629	.3683	.4003	.4017	.4033	.4316	.3587

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 201 / 11 KV SHASTRI LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.8413	.823	.7499	.7316	.7207	.6219
2	.695	.8048	.8048	.695	.7133	.7133	.6219
3	.6584	.7499	.7682	.695	.6584	.6584	.6036
4	.6584	.7392	.7392	.6653	.6653	.6401	.5853
5	.6468	.7023	.7207	.6468	.7023	.6036	.567
6	.6468	.6653	.6838	.6468	.6468	.5914	.5729
7	.6468	.6838	.6099	.6219	.6468	.5544	.5914
8	.6283	.6767	.6838	.6219	.5914	.5914	.6099
9	.7023	.7133	.6468	.6584	.5914	.6099	.7207
10	.6653	.724	.7207	.6584	.6154	.6099	.6878
11	.7207	.7059	.7023	.6099	.6878	.6653	.6878
12	.7577	.6878	.7023	.6653	.6878	.6283	.6516
13	.7023	.6878	.7023	.6099	.6516	.6283	.5973
14	.7577	.724	.7392	.6099	.6697	.5729	.5611
15	.7947	.724	.7655	.6653	.6697	.6099	.5611
16	.7947	.7783	.7207	.7023	.6516	.5729	.5973
17	.7602	.7499	.7577	.7023	.6516	.5544	.6036
18	.7964	.7316	.7762	.695	.6697	.5914	.695
19	.8869	.8145	.8686	.8413	.8326	.7023	.8145
20	.9412	.9694	.924	.8413	.8688	.7762	.7865
21	.9774	.9511	.9055	.8779	.8326	.7577	.7682
22	1.0317	.9877	.924	1.7372	.8145	.7762	.7421
23	.9979	.9511	.8962	.9145	.8316	.7682	.6767
24	.7499	.924	.8596	.8048	.8131	.7762	.695
Max	1.0317	.9877	.924	1.7372	.8688	.7762	.8145
Min	.6283	.6653	.6099	.6099	.5914	.5544	.5611
Avg	.7623	.7787	.7685	.7473	.7040	.6531	.6508

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 202 / 11 KV BHENDE LAYOUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.2254	1.2254	1.1157	1.1157	1.0534	.9511
2	1.0425	1.0974	1.134	1.0791	1.0608	1.0425	.9328
3	1.0059	1.0791	1.134	1.0425	1.0059	.9877	.8779
4	.9877	1.0534	1.1088		.9979	.9511	.8596
5	.9795	1.0349	1.0903		.961	.9145	.8413
6	.9795	1.0164	1.0534	.9055	.9425	.8131	.8131
7	.961	1.0903	.961	.9145	.961	.7947	.8501
8	.9055	.9511	.961	.9877	.8501	.8871	.9425
9	.9795	.9511	.9795	.9145	.9055	.924	1.0534
10	.924	.7964	.8501	.8779	.8507	.9055	1.0317
11	.8501	.7602	.8501	.8131	.8145	.9425	.905
12	.8131	.7421	.7947	.7392	.7964	.9055	
13	.8316	.7783	.8131	.7577	.7964	.8871	.7059
14	.8501	.7783	.7947	.7577	.7602	.8131	.6878
15	.8501	.8326	.8962	.7577	.7783	.7577	.6697
16	.924	.905	.924	.7947	.8145	.8316	.7421
17	.9593	.9694	.961	.8131	.7783	.7762	.7499
18	.905	.8596	.9055	.8048	.8507	.7947	.8596
19	1.2127	1.0317	1.1458	1.0791	1.0679	.9979	1.0317
20	1.3394	1.2803	1.2567	1.1888	1.1584	1.1088	1.1157
21	1.3575	1.3352	1.3306	1.2803	1.1584	1.1088	1.0425
22	1.3575	1.4266	1.3306	1.2567	1.1584	1.1088	.9955
23	1.4045	1.4083	1.3169	1.262	1.2197	1.134	.9511
24	1.134	1.2936	1.3169	1.2803	1.2382	1.1458	1.0608
Max	1.4045	1.4266	1.3306	1.2803	1.2382	1.1458	1.1157
Min	.8131	.7421	.7947	.7392	.7602	.7577	.6697
Avg	1.0271	1.0290	1.0473	.9738	.9601	.9411	.8987

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 203 / 11 KV DIN DAYAL NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608		1.2254	1.1888	1.1157	1.1088	.9511
2	1.0242	1.1706	1.1523	1.1706	1.0608	1.0534	.9145
3	1.0059	1.1157	1.1157	2.0851	1.0059	.9877	.8962
4	1.0059	1.1088	1.0719	2.0328	1.0164	.9694	.8962
5	1.0349	1.0719	1.0534	1.9404	1.0349	.9328	.8596
6	1.0349	1.0534	1.0534	1.8111	1.0349	.8686	.8871
7	1.0164	1.0534	1.0349	1.829	1.0164	.8501	.9055
8	1.0349	1.0974	1.0534	1.7741	.9979	.9425	1.0164
9	1.1088	1.0974	1.1088	1.7558	1.0719	.961	1.1458
10	1.1088	1.0679	1.0903	1.7558	1.0136	1.0164	1.1946
11	1.0903		1.0349	1.7002	1.0136	1.1273	1.1222
12	1.0719		1.0719	1.7741	1.0136	1.0164	.9774
13	1.0534	1.3575	1.0719	1.7002		1.0349	.9412
14	1.0719	1.1946	1.1088	1.6632	1.0136	.961	.9412
15	1.0719	1.1946	1.1576	1.0164	1.0136	.8686	.905
16	1.1088	1.1584	1.1273	1.0164	1.0317	.8501	.905
17	1.1584	1.134	1.2012	1.0164	1.0136	.924	.9877
18	1.2308	1.1706	1.2382	1.134	1.1041	.9979	1.0974
19	1.4118	1.3394	1.4045	1.3535	1.3032	1.1827	1.267
20	1.6108	1.4815	1.4784	1.4266	1.5203	1.2567	1.2986
21	1.5927	1.5181	1.4784	1.4083	1.3394	1.2752	1.262
22	1.5565	1.5729	1.5154	1.4415	1.3756	1.2382	1.1946
23	1.4784	1.4632	1.3717	1.3352	1.2936	1.1157	1.0425
24	1.134	1.3491	1.3535	1.2986	1.2197	1.1827	1.0242
Max	1.6108	1.5729	1.5154	2.0851	1.5203	1.2752	1.2986
Min	1.0059	1.0534	1.0349	1.0164	.9979	.8501	.8596
Avg	1.1699	1.2272	1.1906	1.5262	1.1141	1.0301	1.0264

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 204 / 11 KV JAITALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5121	.5304	.4755	.4755	.462	.4207
2	.439	.4755	.4755	.4755	.439	.4572	.4024
3	.439	.4572	.4755	.439	.4207	.4207	.3841
4	.4024	.4435	.4435	.4024	.4251	.4024	.3658
5	.3881	.4066	.4066	.3841	.4066	.3841	.3658
6	.3881	.3696	.3696	.3881	.4066	.3142	.3326
7	.4251	.4435	.4066	.4024	.4251	.2957	.3511
8	.4066	.3841	.4435	.4024	.4066	.3142	.3881
9	.4805	.5121	.462	.4938	.462	.3696	.4435
10	.4805	.4525	.4805	.439	.4344	.4435	.4163
11	.462		.4251	.3881	.4344	.4251	.3801
12	.4435	.5611	.4435	.3696	.4163	.4066	.3439
13	.4251	.4344	.4435	.3881	.3801	.3881	.3258
14	.4435	.4163	.4066	.3881	.3801	.3326	.2896
15	.4435	.4344	.4108	.4251	.3439	.3326	.2896
16	.4435	.4163	.4251	.3881	.362	.3326	.2896
17	.4344	.3841	.3881	.3881	.3258	.3142	.3292
18	.4344	.4024	.4435	.4024	.3982	.3881	.3841
19	.5068	.5068	.5359	.5487	***	.4805	.4887
20	.6335	.567	.5729	.567	.5068	.499	.5121
21	.6335	.6036	.5729	.5853	.4887	.499	.4755
22	.6154	.6036	.5914	.5914	.543	.462	.4887
23	.6099	.5853	.5853	.5487	.499	.4938	.439
24	.5121	.5359	.5304	.5121	.499	.4805	.4207
Max	.6335	.6036	.5914	.5914	54.1715	.499	.5121
Min	.3881	.3696	.3696	.3696	.3258	.2957	.2896
Avg	.4736	.4743	.4695	.4497	2.6688	.4041	.3886

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 205 / 11 KV TRIMURTI NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	1.0791	1.134	1.0059	.9511	.961	.823
2	.9145	1.0059	1.0425	.9877	.9145	.8962	.7865
3	.8596	.9511	1.0059	.9328	.9145	.823	.7499
4	.8413	.924	.9425	.924	.924	.823	.7316
5	.8316	.8871	.8871	.8871	.9055	.8048	.7133
6	.8131	.8501	.8501	.8686	.9055	.7762	.7023
7	.8871	.961	.8871	.9328	.8871	.7762	.8316
8	.8871	.9145	.8871	.8962	.8871	.8131	.8686
9	.961	.9694	.961	.9511	.9055	.9055	1.0164
10	.924	.8688	.924	.8779	.905	.8686	.905
11	.8686	.905	.9795	.924	.8326	.924	.9593
12	.8686	.905	.9055	.8871	.8326	.8686	.8326
13	.8871	.8688	.8686	.8501	.8507	.8316	.7421
14	.8686	.8688	.9055	.8131	.8145	.8131	.7421
15	.8871	.905	.9425	.8316	.8688	.7762	.7783
16	.961	.8869	.9055	.9055	.8688	.7947	.7602
17	.9593	.8962	.9055	.8316	.8507	.7947	.7316
18	.9774	.9328	.9795	.8962	.8688	.7762	.8413
19	1.1041	1.0136	1.0719	1.0608	1.0136	.9425	.9593
20	1.1041	1.2071	1.1827	1.134	1.0679	.961	1.0242
21	1.267	1.2254	1.2012	1.134	1.0317	.961	.9877
22	1.2308	1.2803	1.2197	1.1273	1.0498	.961	.9412
23	1.3121	1.2986	1.2254	1.134	1.0903	1.0059	.9145
24	1.0242	1.1458	1.2071	1.0974	1.0719	1.0534	.8962
Max	1.3121	1.2986	1.2254	1.134	1.0903	1.0534	1.0242
Min	.8131	.8501	.8501	.8131	.8145	.7762	.7023
Avg	.9647	.9896	1.0009	.9538	.9255	.8713	.8433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 206 / 11 KV KHAMLA SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0242	1.2986	1.2986	1.134	1.0974	1.0719	.9328
2	1.0242	1.2071	1.1888	1.0608	1.0608	.9877	.8962
3	.9694	1.1706	1.1706	1.0425	1.0425	.9694	.8596
4	.9328	1.1643	1.1458	1.0164	1.0164	.9328	.8596
5	.924	1.1458	1.1088	.961	.9979	.8962	.8413
6	.9055	1.1273	1.0719	.9055	.9795	.8501	.8501
7	1.0164	1.1273	1.0349	.9694	1.0164	.8316	.8501
8	.961		1.1643	1.0425	.9795	.924	.8871
9	1.0164	1.1157	1.0903	1.0242	1.1458	.9425	.9795
10	.9979	1.0498	1.1458	1.0242	1.1041	.961	1.0136
11	1.0534	1.1765	1.2197	1.0903	1.1222	.961	1.0498
12	1.1458	1.1765	1.2012	1.0719	1.2127	.961	.9955
13	1.0903	1.1584	1.2382	.9979	1.086	.924	.9412
14	1.1643	1.1584	1.2197	1.0164	1.086	.8316	.8326
15	1.1827	1.2308	1.2883	1.0534	1.086	.8131	.8507
16	.0739	1.2308	1.2752	1.0349	1.0679	.8501	.8507
17	1.4118	1.2437	1.2936	1.0534	1.0317	.8316	.8779
18	1.3032	1.262	1.2567	1.0974	1.1041	.924	1.0608
19	1.5746	1.3575	1.4415	1.4266	1.0317	1.2382	1.1584
20	1.5927	1.5912	1.423	1.4632	1.2851	1.2752	1.1706
21	1.5927	1.4998	1.3121	1.3352	1.2308	1.3121	1.134
22	1.5565	1.4815	.8686	1.3121	1.1946	1.1827	1.0498
23	1.5154	1.4815	1.2437	1.2803	1.1643	1.1157	.9694
24	1.1523	1.423	1.39	1.2071	1.1458	1.1458	1.0059
Max	1.5927	1.5912	1.4415	1.4632	1.2851	1.3121	1.1706
Min	.0739	1.0498	.8686	.9055	.9795	.8131	.8326
Avg	1.1326	1.2556	1.2121	1.1092	1.0954	.9889	.9549

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 207 / 11 KV AMEYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7499	.8048	.823	.8048	.7682	.7577	.6401
2	.7133	.7682	.7865	.7499	.7316	.695	.6219
3	.695	.7316	.7316	.7682	.7133	.695	.6036
4	.6584	.7392	.7023	.7577	.6653	.6767	.6036
5	.6468	.7207	.6838	.7392	.6468	.6584	.5853
6	.6468	.7207	.6838	.7207	.6468	.6283	.6099
7	.6838	.6838	.6283	.6219	.6653	.5729	.5914
8	.6653	.695	.7023	.6767	.6838	.5729	.6283
9	.6653	.7316	.6838	.6401	.6468	.6283	.6468
10	.6838	.6878	.6653	.6219	.6335	.6653	.6697
11	.6653	.6516	.6838	.6653	.6516	.6653	.7059
12	.6838	.6878	.6838	.6468	.6516	.6468	.6516
13	.7023	.6516	.7023	.7023	.6697	.6099	.5792
14	.6838	.6697	.6838	.6468	.6516	.5914	.543
15	.6838	.6878	.7095	.6283	.6335	.5544	.543
16	.7023	.7059	.7023	.6283	.6154	.5544	.543
17	.6697	.7133	.7023	.6468	.6154	.5729	.5487
18	.7059	.6767	.7023	.6767	.6516	.5914	.6401
19	.905	.8507	.924	.8596	.8326	.7023	.7602
20	.9412	.9328	.9425	.9145	.8688	.7577	.823
21	.9774	.9328	.9425	.9145	.8326	.7577	.7682
22	.9774	.9694	.9425	.8871	.8145	.7392	.7783
23	.961	.9877	.9145	.8779	.8501	.7499	.6767
24	.8048	.8501	.8962	.8596	.8316	.7947	.6767
Max	.9774	.9877	.9425	.9145	.8688	.7947	.823
Min	.6468	.6516	.6283	.6219	.6154	.5544	.543
Avg	.7447	.7605	.7593	.7357	.7072	.6599	.6433

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 208 / 11 KV JAYPRAKASH NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.957	1.9936	1.9022	1.0242	1.0349	.9145
2	1.701	1.7924	1.8473	1.7924	.9694	.9795	.8596
3	1.6461	1.7193	1.701	1.701	.9511	.9511	.823
4	1.5546	1.6632	1.6632	1.6632	.924	.9145	
5	1.5154	1.6078	1.6263	1.5893	.8871	.8596	.823
6	1.46	1.5339	1.5708	1.5339	.8131	.7577	.7392
7	1.5524	1.5893	1.5708	1.5364	.8501	.7207	.7577
8	1.5893	1.6461	1.6448	1.5912	.8686	.8686	.9425
9	1.5893	1.5546	1.5893	1.4998	.9055	.8686	.9795
10	1.46		1.4969	.7865	.8145	.8871	.7964
11	1.4045	1.3394	1.4415	.7392	.7421	.9055	.8326
12	1.4415	1.3394	1.386	.6838	.7059	.8871	.7059
13	1.4415	1.3394	1.3676	.7207	.6878	.7947	.6697
14	1.4415	1.3575	1.4415	.6838	.6154	.6838	.543
15	1.46	1.3575	1.5497	.7392	.7059	.6838	.5973
16	1.5154	1.4842	1.4784	.7762	.6697	.7207	.6335
17	1.4661	1.4998	1.4784	.7577	.724	.7207	.6401
18	1.5927	1.5364	1.5708	.823	.8326	.8501	.8962
19	1.9728	1.9004	1.9404	1.1157	1.086	1.0164	1.0136
20	2.1176	2.0668	2.0328	1.134	1.1403	1.0903	1.0791
21	2.19	2.1399	2.1068	1.1706	1.086	1.0534	1.0425
22	2.2805	2.2862	2.2361	1.1088	1.1584	1.0534	.9955
23	2.2546	2.2862	2.1582	1.262	1.2197	1.0608	.9328
24	1.9022	2.0698	2.0668	1.957	1.1458	1.1273	.9694
Max	2.2805	2.2862	2.2361	1.957	1.2197	1.1273	1.0791
Min	1.4045	1.3394	1.3676	.6838	.6154	.6838	.543
Avg	1.6809	1.6985	1.7066	1.2195	.8970	.8954	.8342

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 209 / 11 KV GOPAL NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6767	.7499	.7499	.7133	.0549
2	.6584	.695	1.4632	.695	.0732
3	.6219	.6767	.695	.6767	.0732
4	.6219	.6838	.7023	.6838	
5	.6468	.6838	.7392	.6838	
6	.6653	.6838	1.5524	.6838	
7	.6283	.7207	.6838	.7207	
8	.6468	.6219	.6468	.6401	
9	.6838	.6219	.6468		
10	.6468		.6468		
11	.6283	.6154	.6653		
12	.6468	.5973	.6653		
13	.6283	.6335	.6468		
14	.6099		.6838		
15	.6283	.6697	.7095		
16	.6468	.6516	.7023		
17	.6516	.6767	.6653		
18	.6697	.695	.7392		
19	.8145	.8145	.8501		
20	.9593	.9328	.8871		
21	.9231	.9694	.8871		
22	.905	.9511	.8871		
23	.8686	.9511	.8596		
24	.695	.7577	.7865	.7499	
Max	.9593	.9694	1.5524	.7499	.0732
Min	.6099	.5973	.6468	.6401	.0549
Avg	.6988	.7297	.7984	.6941	.0671

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 210 / 11 KV TELECOM NAGAR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	1.0242	1.0059	.9511	.8596	.9055	.7316
2	.823	.9694	.9877	.0732	.9145	.8048	.695
3	.7865	.8779	.8779	.0732	.8048	.7865	.6767
4	.7682	.8501	.8501	.0924	.7947	.7682	.6767
5	.7577	.8316	.7947	.0924	.7947	.7316	.6767
6	.7577	.8131	.7762	.0924	.8131	.6838	.6838
7	.8131	.8131	.8686	.0732	.7762	.7023	.7392
8	.7947	.8413	.8131	.0732	.8131	.7392	.7947
9	.7762	.8596	.7577	.0914	.7023	.7947	.8501
10	.7577		.7392	.0914	.7059	.7577	.8326
11	.7762	.7783	.7392	.0924	.7602	.8131	.7602
12	.7577	.7421	.6838	.0739	.7421	.7392	.724
13	.7577	.7059	.7207	.1109	.724	.6838	.6697
14	.7577	.7421	.7577	.0924	.724	.6653	.6154
15	.7392	.7783	.7655	.7392	.7059	.6838	.6516
16	.7947	.8145	.7947	.7392	.724	.7023	.6697
17	.8507	.8048	.8131	.7947	.7783	.7023	.7133
18	.8326	.7865	.8131	.8048	.7964	.7392	.8048
19	1.0317	.9412	1.0164	.9511	.9231	.8316	.8688
20	1.1946	1.0791	1.0534	.9877	1.0317	.924	.9145
21	1.1946	1.0791	1.0534	1.0242	.9955	.961	.9328
22	1.2127	1.2254	1.1458	1.1273	1.0317	.924	.8326
23	1.1827	1.1706	1.1157	1.0791	1.0534	.8962	.7865
24	.9877	1.0719	1.0974	1.0059	.9979	1.0534	.823
Max	1.2127	1.2254	1.1458	1.1273	1.0534	1.0534	.9328
Min	.7392	.7059	.6838	.0732	.7023	.6653	.6154
Avg	.8735	.8957	.8767	.4719	.8320	.7914	.7552

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164803 / 33/11KV TRIMURTINAGAR SUBSTN

Feeder No / Name : 211 / 11 KV Prasad Nagar FDR SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4083	1.5181	1.5729	1.4815	1.4266	1.4045	1.262
2	1.3169	1.4632	1.4815	1.4266	1.3717	1.2986	1.1888
3	1.2986	1.39	1.4266	1.3535	1.3352	1.2803	1.1523
4	1.2986	1.3676	1.4045	1.3306	1.3306	1.2437	1.1523
5	1.3121	1.3306	1.386	1.3306	1.3121	1.2071	1.134
6	1.3306	1.2936	1.3676	1.3306	1.2936	1.1088	1.0719
7	1.2936	1.3121	1.2936	1.2986	1.2752	1.1088	1.1088
8	1.2936	1.2071	1.2382	1.2012	1.2382	1.1088	1.2197
9	1.3676	1.3121	1.2936	1.2803	1.2936	1.1827	1.3676
10	1.2936		1.2197	1.1706	1.1584	1.2382	1.1946
11	1.2382	.3439	1.2567	1.1827	1.1041	1.2012	1.2127
12	1.2197	.2896	1.1643	1.0903	1.1041	1.2012	1.1403
13	1.2012	1.3032	1.2197	1.1273	1.1041	1.0719	1.0317
14	1.2567	1.1765	1.2567	1.1273	1.1584	1.0719	.9412
15	1.2752	.3258	1.307	1.1458	1.1041	1.0534	1.0136
16	1.2936	1.1584	1.2382	1.2197	1.1041	1.0534	.8869
17	1.3032	1.4266	1.2936	1.2197	1.1403	1.0534	1.0791
18	1.3213	1.4083	1.3306	1.2254	1.1765	1.0719	1.2071
19	1.5203	1.5565	1.5893	1.5181	1.4661	1.3676	1.4661
20	1.7556	1.7193	1.7002	1.6644	1.5203	1.46	1.4632
21	1.8099	1.7375	1.7187	1.6644	1.5565	1.4415	1.4632
22	1.8099	1.8656	1.7372	1.7372	1.5384	1.4415	1.4118
23	1.8296	1.8656	1.7193	1.6461	1.5893	1.4266	1.2437
24	1.4815	1.6632	1.6278	1.5912	1.5154	1.4415	1.3169
Max	1.8296	1.8656	1.7372	1.7372	1.5893	1.46	1.4661
Min	1.2012	.2896	1.1643	1.0903	1.1041	1.0534	.8869
Avg	1.3971	1.3058	1.4101	1.3485	1.3007	1.2308	1.1971

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 202 / 11 KV KACHOREPATIL FDR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.6413	1.0534	.6653	1.3203	.6099	.5544
2	.5973	.6224	.6283	.6283	.5544	.6283	.5175
3	.5792	.6413	.6099	.5914	.5544	.6099	.4251
4	.5249	.6036	.5544	.5914	.5544	.499	.4435
5	.5068	.5658	.5729	.5729	.5359	.4805	.4435
6	.5068		.5544	.5729	.5175	.4805	.462
7	.4706	.5847	.5175	.5544	.499	.4435	
8	.5249	.5281	.5359	.5175		.499	.4805
9	.5249	.462	.5544	.5175	.462	.5175	.462
10	.5611	.4435	.462	.462	.4066	.462	.5359
11	.5068	.462	.462	.4435	.462	.5175	.462
12	.5611	.5175	.462	.4481	.5359	.4435	.462
13	.543	.499	.499	.4435	.462	.4435	.4066
14	.543	.462	.462	.4805	.4805	.4435	.3772
15	.5068	.462	.4805	.462	.462	.4435	.3696
16	.5068	.5175	.462	.462	.462	.4435	.3696
17	.547	.462	.5359	.462	.462	.4066	.4066
18	.5658	.499	.5175	.462	.4805	.4435	.5359
19	.6602	.6283	.6468	.6413	.6283	.5914	.5914
20	.7922	.7023	.7207	.7392	.6838	.6099	.6099
21	.7733	.7207	.7762	.7577	.7023	.6099	.5914
22	.7922	.7392	.7762	.7207	.7023	.4435	.5914
23	.7922	.7023	.7392	.7023	.7023	.6099	.5544
24	.679		.6653	.7023	.6468	.6283	.5544
Max	.7922	.7392	1.0534	.7577	1.3203	.6283	.6099
Min	.4706	.4435	.462	.4435	.4066	.4066	.3696
Avg	.5909	.5667	.5937	.5667	.5773	.5128	.4873

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 205 / 11 KV SOMALWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7356	.811	.7545	1.4335	1.4712	1.2637
2	.7049	.6979	.6979	.7167	1.358	1.3203	1.2071
3	.6478	.6602	.6979	.6979	1.3203		1.1694
4	.6287	.6413	.6224	.6413	1.2826	1.2826	1.094
5	.6036	.6413	.6224	.6413	1.2449	1.2071	1.0562
6	.6036	.6602	.6224	.6413	1.2449	1.094	1.1317
7	.6859	.7356	.679	.6602	1.3203	1.1128	
8	.7049	.6602	.679	.679		1.2449	1.3392
9	.7545	.679	.7545	.6979	1.4146	1.3203	1.4712
10	.7545	.7167	.7733	1.3957	1.5466	1.4335	1.3203
11	.7922	.7545	.8488	1.5089	1.6221	1.4146	1.4335
12	.8299	.7545	.8676	1.3213	1.5089	1.5089	1.3676
13	.8676	.7922	.9054	1.4712	1.5466	1.358	1.2826
14	.8676	.7922	.8488	1.3769	1.4712	1.3203	1.3014
15	.9054	.8488	.811	1.4146	1.4335	1.2449	1.2071
16	.9242	.811	.8488	1.4523	1.5089	1.2637	1.2637
17	.9431	.811	.8299	1.4335	1.4335	1.2071	1.2637
18	.8865	.7922	.811	1.4523	1.4712	1.2637	1.358
19	.9997	.8676	.9808	1.5927	1.5278	1.4146	1.5655
20	1.0185	.8676	.9619	1.6975	1.8296	1.5655	1.5655
21	.9619	.9054	.9431	1.7164	1.6787	1.5278	1.5466
22	.9431	.8865	.9619	1.7918	1.6975	1.3957	1.4335
23	.9242	.9054	.8676	1.6975	1.6975	1.5278	1.358
24	.7922		.8488	.7922	1.6032	1.5089	1.3957
Max	1.0185	.9054	.9808	1.7918	1.8296	1.5655	1.5655
Min	.6036	.6413	.6224	.6413	1.2449	1.094	1.0562
Avg	.8120	.7660	.8040	1.1769	1.4868	1.3482	1.3215

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 206 / 11 KV KARVE NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9036	1.0185	1.0534	1.0164	.961	.961	
2	.8859	.9619	1.0164	.9795	.8686	.924	.7577
3	.815	.9242	.9425	.924	.8686	.8501	.7577
4	.7796	.9054	.924	.9055	.8501	.8131	.7762
5	.7701	.9054	.9055	.9055	.8316	.7762	.8131
6	.7701	.8676	.8131	.9055	.7762	.7392	.8871
7	.7783	.8488	.8871	.8501	.7947	.7392	
8	.7619	.8676	.8686	.8686		.7207	.8501
9	.815	.8316	.8501	.8871		.7762	.8501
10	.8328	.7947	.8131	.8131	.7947	.8131	.8501
11	.8328	.7619	.8686	.8501	.8501	.8686	.8871
12		.8501	.8871	.8316	.8686	.8501	.8131
13	.815	.8501	.8871	.8316	.924	.8501	.7282
14	.8328	.8316	.8871	.7947	.8501	.7762	.6908
15	.8859	.8316	.924	.8131	.8501	.7023	.6283
16	.8682	.9055	.8501	.7947	.7392	.6838	.6653
17	.8676	.7947	.8131	.7577	.7762	.6838	.6283
18	1.1128	.8131	.924	.7762	.7947	.6838	.7762
19	1.1128	.9979	1.0903	1.0242	1.0349	.924	.9795
20	1.1506	1.1643	1.2012	1.1273	1.1273	1.0164	1.0349
21	1.2826	1.2382	1.2567	1.2012	1.1273	1.0534	1.0164
22	1.3957	1.3491	1.2936	1.2012	1.1643		.9795
23	1.3014	1.3121	1.2197	1.1458	1.1643	1.0164	.9055
24	1.1506		1.1273	1.0903	1.0719	1.0534	.8686
Max	1.3957	1.3491	1.2936	1.2012	1.1643	1.0534	1.0349
Min	.7619	.7619	.8131	.7577	.7392	.6838	.6283
Avg	.9444	.9403	.9710	.9290	.9131	.8380	.8247

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164813 / 33 /11 KV CHINCHBHAWAN

Feeder No / Name : 207 / 11KV CARGO

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.2826	1.2382	1.226	1.3203	1.3203	1.1317
2	1.2449	1.1883	1.1694	1.1883	1.3392	1.3203	1.1128
3	1.3014	1.226	1.1506	1.2071	1.358	1.3203	.9997
4	1.0751	1.1317	1.1506	1.1506	1.3203	1.1317	1.0185
5	1.0029	1.094	1.1694	.8488	.9054	.9054	1.094
6	.8954	1.0185	1.1128	1.094	.9808	.9431	1.1317
7	1.094	1.1506	1.1128	1.094	.9808	1.1128	
8	1.1694	1.1506	1.2826	1.2071		1.094	1.2071
9	1.2071	1.2449	1.1694	1.226	1.1694	1.094	1.1694
10	1.3014	1.3203		.9808	1.226	1.1317	.4338
11	1.3769	1.358	1.3392	1.2449	1.2449	1.1317	1.1694
12	1.4523	1.3014	.6413	1.0562	1.094	.7167	1.1317
13	1.3014	1.3957	1.0562	1.358	.6413	.6979	1.2071
14	1.3769	1.226	1.3203	1.2637	1.1506	1.1317	1.1883
15	1.2826	1.3392	1.3392	1.3203	1.1694	1.094	1.094
16	1.3392	1.1883	1.3203	1.358	1.0562	1.0562	1.2071
17	1.3392	1.1883	1.3203	1.2826	1.094	.9808	1.1317
18	1.3392	1.3203	1.2826	1.226	1.1506	.9808	1.3392
19	1.5655	1.4712	1.5089	1.5089	1.5089	1.4335	1.5089
20	1.5655	1.5466	1.5278	1.5466	1.4146	1.4523	1.4335
21	1.5655	1.5466	1.5089	1.4712	1.4712	1.4523	1.4712
22	1.4901	1.4712	1.094	1.4901	1.4712		1.4335
23	1.3957	1.3392	1.3203	1.4146	1.5089	1.2826	1.2637
24	1.3203		1.2449	1.2826	1.358	1.3203	1.2826
Max	1.5655	1.5466	1.5278	1.5466	1.5089	1.4523	1.5089
Min	.8954	1.0185	.6413	.8488	.6413	.6979	.4338
Avg	1.3035	1.2826	1.2339	1.2519	1.2145	1.1350	1.1809

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 201 / 11KV GAYATRI NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.499	.3881	.4938	.5175	.4572	.3511
2	.462	.4805	.4066	.4755	.4805	.439	.3511
3	.4435	.3319	.4066	.4755	.462	.3658	.3511
4	.4481	.462	.4251	.4755	.4435	.4024	.3511
5	.4294	.462	.4435		.4251	.4024	.3696
6	.4294	.4435	.462	.4572	.4251	.3658	.3696
7	.4207	.4435	.4066	.4024	.4066	.4024	.3881
8	.4108	.4251		.4572	.3841	.3658	.3511
9	.4294	.4066	.4251	.4024	.3658	.3658	.3511
10	.3921	.4066		.4207	.4024	.3696	.4066
11			.3921	.3475	.3841	.3511	.3696
12	.3547		.3921	.3475	.3841	.3511	.3326
13	.3921		.3921	.3475	.3475	.3696	.3142
14	.3921	.5415	.4108	.4024	.3475	.3326	.3142
15	.4108	.5041	.4294	.3841	.3658	.3326	.3326
16	.3921	.4668	.4108	.4207	.4024	.3326	.3326
17	.3921		.4481	.4207	.3658	.3511	.3326
18	.4251	.4481	.4668	.4207	.4207	.3881	.4066
19	.499	.5228	.5228	.4938	.4887	.4805	.4805
20	.6099	.5788	.5853	.567	.5304	.462	.4938
21	.6283	.4668	.6036	.567	.5249	.499	.4755
22	.6099	.6535	.6036	.5487	.543	.4805	.462
23	.5914	.6535	.5853	.5544	.5487	.499	.4435
24	.5175	.5359	.5415	.5487	.5175	.462	
Max	.6283	.6535	.6036	.567	.5487	.499	.4938
Min	.3547	.3319	.3881	.3475	.3475	.3326	.3142
Avg	.4584	.4866	.4613	.4535	.4368	.4012	.3796

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 202 / 11 KV IT PARK

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4527	.4715	.2743	.4668	.5093	.3772	.3361
2	.415	.679	.2743	.4294	.415	.3395	.3361
3	.415	.3772	.2926	.4108	.415	.3395	.3361
4	.4191	.3584	.2926	.3734	.3961	.0566	.3361
5	.3921	.3584	.3109	.3174	.3584	.3018	.3361
6	.4001	.3772	.3109	.3174	.3547	.2829	.3361
7	.3841	.415	.3109	.3174	.4066	.3109	.3361
8	.4763	.4715	.5853	.4668	.3921	.3206	.5601
9	.743	.7545	.7865	.7682	.6722	.3395	.5601
10	1.0425	1.1458		.9877	.9149	.3584	.6908
11	1.1888	1.2071	1.1643	1.1016	.9709	.3772	.0543
12	1.2071	1.2071	1.2197	1.1016	.9149	.3584	.724
13	1.1523	1.2254	1.2197	1.1016	.9149	.3584	.7602
14	1.2071	1.2071	1.2567	1.1576	.9149	.3772	.7783
15	1.2986	1.262	1.2936	1.251	.8775	.3584	.8507
16	1.3169	1.2986	1.2197		.8962	.3395	.8507
17	1.3169	1.2254		1.2696	.9522	.3961	.8145
18	1.2437	1.1888	1.2197	1.1403	.823	.3395	.7059
19	1.0425	1.0608	.9979	.8869	.6161	.3206	.6516
20	.8962	.8596	.8596	.8145	.4481	.3206	.6036
21	.6767	.6584	.6036	.6036	.4108	.3206	.5792
22	.567	.5487	.5487	.5788	.3961	.3206	.4525
23	.4938	.5487	.4938	.5041	.3584	.3961	.4066
24	.4715	.4938	.439	.5041	.4527	.3206	
Max	1.3169	1.2986	1.2936	1.2696	.9709	.3961	.8507
Min	.3841	.3584	.2743	.3174	.3547	.0566	.0543
Avg	.8008	.8083	.7261	.7335	.6159	.3304	.5389

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 203 / 11 KV SUBHASH NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.924	1.1827	.7577	.9694	.9795	.9328	.7207
2	.924	.9425	.7762	.9145	.924	.9328	.7207
3	.8871	.924	.7947	.9145	.8871	.9145	.7947
4	.8402	.9055	.8131	.8962	.8871	.8779	.8131
5	.8029	.9055	.8316	.8779	.8686	.823	.8316
6	.7842	.8501	.8686	.8596	.8686	.7499	.8501
7	.823	.8501	.8316	.8413	.8413	.7682	.8501
8	.8215	.8686	.7762	.8413	.7682	.7499	.8686
9	.8962	.8131	.9055	.823	.823	.7682	.8871
10	.9522	.8501		.8413	.7682	.7207	.8501
11		.961	.9896	.9145	.8413	.7392	.8871
12	.9335	.9425	.9335	.8779	.8596	.7577	.8316
13	.9522	.961	.9896	.8779	.8962	.7392	.7947
14	.9709	.9896	1.0082	.3292	.8413	.7207	.7577
15	.9709	1.0082	1.0642	.9511	.823	.7207	.8316
16		1.0269	.9709	.9511	.8413	.7023	.8871
17	.9709	.9896	1.0082	.9145	.823	.7023	.8316
18	.961	.9522	1.0269	.9328	.8413	.7392	.9055
19	1.1643	1.1763	1.1389	1.0974	1.0317	.924	1.0719
20	1.2382		1.1888	1.1706	1.0059	.9979	1.0608
21	1.2382	1.2136	1.2071	1.1706	.9955	.9055	1.0059
22	1.1827	1.2136	1.1706	1.1706	1.0317	.9425	.9795
23	1.1273	1.2136	1.1523	1.1088	1.0425	.961	.8501
24	1.0164	1.1827	1.0829	1.0534		.8316	
Max	1.2382	1.2136	1.2071	1.1706	1.0425	.9979	1.0719
Min	.7842	.8131	.7577	.3292	.7682	.7023	.7207
Avg	.9719	.9967	.9690	.9291	.8909	.8176	.8644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 204 / 11 KV PERSISTENT FEEDER SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1478	.1478	.9694	.1478	.1463	.1294
2	.1848	.1663	.1478	.1463	.1478	.1646	.1294
3	.1848	.1663	.1478	.1463	.1478	.1646	.1294
4	.168	.1478	.1478	.1463	.1478	.1646	.1478
5	.168	.1294	.1663	.1463	.1463	.1509	.1478
6	.168	.1478	.1663	.1463	.1478	.1463	.1663
7	.1829	.1663	.1663	.1829	.1478	.1646	.1663
8	.1867	.2218	.2033	.2012	.1646	.1463	.3326
9	.2427	.2218	.2957	.3292	.1829	.1463	.3326
10	.3361	.3142		.3292	.1829	.1663	.2957
11	.3547	.3511	.3921	.3658	.2012	.1663	.3142
12	.3734	.4251	.4108	.3292	.2012	.1478	.3326
13	.3921	.3696	.3921	.4024	.1829	.1663	.3696
14	.4854	.4294	.3547	.4024	.2012	.1478	.3696
15	.3734	.3921	.3921	.3658	.2012	.1478	.3511
16	.4668	.3734	.3361	.3475	.2012	.1478	.3326
17	.4668	.4294	.3547	.4024	.2012	.1478	.3511
18	.3881		.3734	.3658	.1829	.1294	.3326
19	.3511	.3361	.3174	.3475	.1991	.1294	.2957
20	.3142	.3361	.2743	.2926	.2012	.1478	.3109
21	.2587	.3734	.2195	.2012	.1629	.1478	.2561
22	.2033	.168	.2012	.1646	.1629	.1478	.1848
23	.1663	.168	.1646	.1663	.1463	.1478	.1478
24	.1478	.1663	.168	.1646	.1478	.1848	
Max	.4854	.4294	.4108	.9694	.2012	.1848	.3696
Min	.1478	.1294	.1478	.1463	.1463	.1294	.1294
Avg	.2812	.2673	.2583	.2942	.1732	.1528	.2577

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 205 / 11 KV SHEWALKAR GARDEN SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3696	.3326	.3475	.3326	.3292	.3142
2	.3326	.3326	.3326	.3475	.3142	.3109	.3142
3	.3142	.3326	.3326	.3292	.3142	.3109	.3142
4	.3361	.3142	.3511	.3292	.3326	.2926	.3326
5	.3361	.3142	.3511	.3475	.3326	.2926	.3326
6	.3734	.3326	.3696	.3658	.3511	.3475	.3326
7	.3658	.3696	.3511	.3475	.3841	.2926	.3511
8	.3734	.3696	.4066	.3658	.3475	.3475	.3511
9	.3921	.3511	.3511	.3841	.3658	.3475	.3511
10	.4294	.3881		.3658	.3658	.3018	.3881
11	.4668	.462	.4668	.4938	.4755	.3142	.4251
12	.4854	.462	.4668	.439	.439	.3326	.4066
13	.4668	.4435	.4481	.439	.4755	.3326	.3696
14	.4481	.4805	.5041	.4024	.4572	.2957	.3696
15	.4481	.4481	.5228	.439	.4024	.2772	.3696
16	.5228	.4854	.5415	.4755	.4207	.3326	.3696
17	.5228	.5041	.5601	.4755	.439	.3511	.3881
18	.4435		.5228	.439	.4024	.3511	.4066
19	.462	.5228	.5041	.4572	.4163	.3696	.4251
20	.462	.5228	.439	.439	.4024	.3881	.4024
21	.4066	.5415	.439	.4024	.3982	.3696	.3841
22	.4066	.4294	.4024	.4024	.3801	.3881	.3511
23	.4066	.4294	.4207	.3841	.3841	.3326	.3326
24	.3511	.3696	.3921	.3658	.3696	.3142	
Max	.5228	.5415	.5601	.4938	.4755	.3881	.4251
Min	.3142	.3142	.3326	.3292	.3142	.2772	.3142
Avg	.4119	.4163	.4265	.3993	.3876	.3301	.3644

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 206 / 11KV ATREY LAY OUT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.6099	.4066	.5853	.5729	.5487	.4066
2	.5175	.5544	.4066	.5304	.5544	.5121	.4251
3	.499	.5175	.4066	.5121	.5175	.5121	.4251
4	.5041	.499	.4251	.5121	.5175	.4938	.4435
5	.4854	.499	.462	.4938	.499	.4755	.462
6	.4854	.4805	.499	.4755	.499	.439	.4805
7	.4938	.5175	.5175	.5304	.5304	.4207	.499
8	.5415	.5359	.4755	.5121	.5121	.4207	.5914
9	.5975	.5729	.5729	.567	.5853	.4755	.5914
10	.6161	.5544		.5853	.567	.5544	.5544
11		.6838	.7095	.5853	.7133	.5729	.6653
12	.7842	.7762	.7282	.6767	.7865	.5914	.6468
13	.6908	.7762	.7468	.6767	.7316	.5729	.6283
14	.6722	.6722	.7282	.6767	.7133	.499	.5544
15	.7282	.8215	.8402	.6401	.7499	.5175	.6099
16	.7468	.7468	.7468	.6584	.695	.499	.5729
17	.7468	.7655	.7468	.7316	.695	.5729	.5729
18	.7577		.7842	.695	.7682	.5914	.6283
19	.8501	.7842	.8215	.7865	.8326	.6838	.7023
20	.8501	.8402	.8413	.8048	.7865	.6653	.6584
21	.8131	.8402	.7682	.7682	.7783	.7023	.6401
22	.7577	.7655	.7316	.6767	.7059	.6468	.5914
23	.7762	.7655	.7133	.6653	.6219	.6283	.5175
24	.5914	.6838	.6908	.6584	.6099	.5544	
Max	.8501	.8402	.8413	.8048	.8326	.7023	.7023
Min	.4854	.4805	.4066	.4755	.499	.4207	.4066
Avg	.6548	.6636	.6421	.6252	.6476	.5479	.5595

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164823 / 33/11 KV IT PARK SUBSTATION

Feeder No / Name : 210 / 11 KV NAVNIRMAN-II

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6099	.6838	.499	.6767	1.4045	1.39	1.1088
2	.5729	.6653	.499	.6401	1.3676	1.3169	1.1088
3	.5729	.6283	.499	.6036	1.2936	1.2803	1.1088
4	.5415	.5914	.5175	.5853	1.2936	1.2254	1.1458
5	.5415	.5544	.5359	.567	1.3121	1.1706	1.1643
6	.5228	.5359	.5544	.5487	1.2936	1.0791	1.1827
7	.6219	.6838	.5914	.6036	1.2752	1.134	1.2012
8	.6722	.6653	.5914	.6219	1.2254	1.1523	1.3676
9	.6348	.6468	.5729	1.262	1.2803	1.2071	1.386
10	.6535	.6283		1.3169	1.2803	.2033	1.3121
11		.6653	.6535	1.4083	1.262	1.3306	1.3676
12	.7282	.6838	.7095		1.3535		1.2567
13	.7282	.6653	.6908	1.4083	1.4083	1.2567	1.2197
14	.6348	.6535	.7095	1.2254	1.3717	1.2197	1.1273
15	.7095	.7095	.7282	1.2254	1.267	1.1273	1.1458
16	.7095	.7468	.7095	1.2986	1.2803	1.1643	1.1458
17	.7095	.7468		1.3169	1.3352	1.1643	1.1643
18	.7947		.7842	1.4083	1.4266	1.2382	1.3676
19	.8686	.7095	.8775	1.701	1.6832		1.5893
20	.8871	.8402	.8413	1.7924	1.7375	1.5893	1.5546
21	.9055	.8589	.8413	1.7193	1.7013	1.5708	1.4998
22	.8871	.8215	.823	1.7372	1.6832	1.5524	1.4045
23	.8131	.8215	.8048	1.6632	1.6095	1.46	1.2382
24	.6468	.7577	.7655	.7316	1.5524	1.2567	
Max	.9055	.8589	.8775	1.7924	1.7375	1.5893	1.5893
Min	.5228	.5359	.499	.5487	1.2254	.2033	1.1088
Avg	.6942	.6941	.6727	1.1331	1.4041	1.2313	1.2681

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 201 / 11 KV Ekatmata Nagar SHEDDABLE URBAN

Feeder Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5413	.5593	.5774	.5413	.5413	.5593	.4871
2	.5413	.5418	.5593	.5413	.5413	.5232	.4871
3	.5232	.5418	.5413	.5232	.5194	.5232	.5413
4	.5014	.5232	.5413	.5232	.5194	.5232	.4691
5	.5014	.5232	.5413	.5052	.5014	.4871	.4691
6	.4656	.4871	.5232	.4691	.4835	.4656	.4511
7	.4477	.4871	.4511	.4511	.4477	.433	.433
8	.4119	.433	.415	.3789	.4119	.433	.4691
9	.415	.4511	.4511		.415	.433	.433
10	.3789	.415			.3608	.3789	.415
11	.3969	.3789	.3969	.3608	.3969	.3969	.415
12	.3969	.3789	.3608	.3582	.3969	.4511	.3789
13	.3969	.415	.3969	.3428	.3969	.3789	.3432
14	.433	.415	.415	.3789	.3969	.3608	.3251
15	.415	.415	.433	.3969	.3969	.3608	.3428
16	.433	.4511	.415	.4119		.3608	.3248
17	.3969	.415	.415	.3761	.3428	.3789	.3428
18	.3789	.3789	.415	.3761	.3969	.3608	.4298
19	.5052	.4691	.5232	.5014	.5232	.4871	.5194
20	.6495	.5954	.6676	.6268	.5954	.5593	.5413
21	.6856	.6495	.5954	.6268	.6134	.5954	.5552
22	.6676	.6856	.6134	.6315	.6495	.5954	.5593
23	.6315	.6676	.6315	.6268	.6134	.5593	.5057
24	.5552	.5954	.6134	.5954	.5954	.5774	.5232
Max	.6856	.6856	.6676	.6315	.6495	.5954	.5593
Min	.3789	.3789	.3608	.3428	.3428	.3608	.3248
Avg	.4862	.4947	.4997	.4793	.4807	.4659	.4484

MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for All Feeders

From 01-AUG-17 and 07-AUG-17

NAGPUR ZONE[069]

NAGPUR (U) CIRCLE[699]

NAGPUR CONGRESS NAGAR DIV[673]

TRIMURTI NAGAR S/DN.[683] BU 4683

Substation No/ Name :- 164836 / 33 KV Jaitala Substation

Feeder No / Name : 204 / 11 KV Shivangaon feeder SHEDDABLE URBAN
Feeder KV- 11 / OUTGOING

DATE	01-AUG-17	02-AUG-17	03-AUG-17	04-AUG-17	05-AUG-17	06-AUG-17	07-AUG-17
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1963	1.2712	1.291	1.2541	1.2147	1.2159	1.1065
2	1.1963	1.2356	1.2541	1.2356	1.1963	1.1791	1.0881
3	1.1595	1.1988	1.2356	1.2172	1.1706	1.1791	1.0697
4	1.134	1.1791	1.1988	1.1803	1.1523	1.1619	1.0512
5	1.134	1.1619	1.1988	1.1619	1.134	1.1065	1.0328
6	1.0608	1.1238	1.125	1.1065	1.0974	.9959	.9959
7	.9694	.9764	.9774	.9959	.9877	.958	.9406
8	.9145	.958	.9037	.9959	.8962	.9027	.9221
9	.9018	.9212	.9221		.9018	.9027	.9037
10	.8834	.8843	.9406		.9018	.9027	.8668
11	.8659	.8668	.9406	.865	.9027	.959	.9037
12	.8843	.8668	.9406	.8413	.9027	.9406	.8483
13	.8475	.8852	.9406	.865	.829	.8299	
14	.9212	.9406	.9774	.865	.8843	.793	.8115
15	.9396	.9774	1.0143	.9018	.8483	.793	.8299
16	.958	.9959	.959	.8779	.8483	.7746	.7377
17	.9406	.9221	.9774	.8779	.8483	.8299	.7561
18	.9221	.848	.959	.8962	.9212	.8299	.9877
19	1.2344	1.0512	1.2725	1.134	1.1975	1.0697	1.134
20	1.437	1.3647	1.4201	1.3535	1.3265	1.1988	1.1988
21	1.5107	1.4385	1.4385	1.39	1.3449	1.2172	1.2071
22	1.4923	1.5307	1.3832	1.4539	1.4186	1.3278	1.2541
23	1.4266	1.4754	1.3647	1.4083	1.3817	1.3094	1.2541
24	1.2437	1.3265	1.3832	1.3278	1.3251	1.2896	1.1988
Max	1.5107	1.5307	1.4385	1.4539	1.4186	1.3278	1.2541
Min	.8475	.848	.9037	.8413	.829	.7746	.7377
Avg	1.0906	1.1000	1.1258	1.1002	1.0680	1.0278	1.0043