

**nMaharashtra State Electricity Distribution Co. Ltd.'s
Consumer Grievance Redressal Forum
Nagpur Urban Zone, Nagpur**

Case No. CGRF(NUZ)/172/2006

Applicant : M/s. Vidarbha Star Industrial Escorts
Pvt. Ltd.,
J-1, MIDC, Hingna Road,
Nagpur.

Non-applicant : MSEDCL represented by
the Nodal Officer-
Executive Engineer,
MIDC Division, NUZ,
Nagpur.

Quorum Present : 1) Shri S.D. Jahagirdar,
Chairman,
Consumer Grievance Redressal
Forum,
Nagpur Urban Zone,
Nagpur.

2) Smt. Gouri Chandrayan,
Member,
Consumer Grievance Redressal
Forum,
Nagpur Urban Zone,
Nagpur.

3) Shri S.J. Bhargawa
Executive Engineer &
Member Secretary,
Consumer Grievance Redressal
Forum, Nagpur Urban Zone,
Nagpur.

ORDER (Passed on 30.12.2006)

The present grievance application has been filed on
12.12.2006 under Regulation 6.4 of the Maharashtra Electricity

Regulatory Commission (Consumer Grievance Redressal Forum & Electricity Ombudsman) Regulations, 2006 here-in-after referred-to-as the said Regulations.

The grievance of the applicant is in respect of non-sanction of enhancement of 45 HP load for the applicant's industrial unit.

Before approaching this Forum the applicant had filed his complaint before the Internal Grievance Redressal Cell (in short the Cell) by his complaint, being letter dated 27.09.2006. The Cell, upon enquiry, replied the applicant by letter, being letter no. 7618, that the request of the applicant for extension of his existing load to 65 HP amounts to a request for sanctioning of dedicated facility and in that, the applicant will have to bear the cost of the new transformer to be installed for the purpose of providing this dedicated facility to the applicant's unit. The Cell also informed the applicant that the existing near by 200 KVA transformer is already overloaded and that the applicant's load cannot be enhanced from this transformer. The applicant was not satisfied with the reply given to him by the Cell and hence, the present grievance application.

The matter was heard by us on 30.12.2006.

The applicant's case was presented before us by one Shri S. Khandekar as his nominated representative.

During the course of hearing, the applicant's representative submitted a written pursis that the non-applicant has already issued an order sanctioning extension of load to the applicant's unit and further that the non-applicant has also informed him that there is now

need to install a new transformer. In view of this position, he requested this Forum to permit him to withdraw his grievance case.

The non-applicant Company's Nodal Officer confirmed the fact that the applicant's request for extension of load is already sanctioned and also that there is no longer any need to install a new transformer.

Since the applicant's grievance has been solved during the pendency of this application, the applicant wants to withdraw his grievance case.

In the light of above, the applicant's grievance application stands disposed off as withdrawn.

Parties informed accordingly in open Court.

Sd/-	Sd/-	Sd/-
(S.J. Bhargawa)	(Smt. Gauri Chandrayan)	(S.D. Jahagirdar)
Member-Secretary	MEMBER	CHAIRMAN

**CONSUMER GRIEVANCE REDRESSAL FORUM
MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO LTD's
NAGPUR URBAN ZONE, NAGPUR.**

**Member-
Secretary
Consumer Grievance Redressal Forum,
Maharashtra State Electricity Distribution Co.Ltd.,
Nagpur Urban Zone, NAGPUR.**

