

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 201 / 11 KV AJARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.7316	.6805		.6036	.6219	.6036
2	.695	.6878	.6722	.6535	.5853	.5853	.5853
3	.695	.6584	.6535	.6348	.5853	.5487	.5487
4	.6584	.6219	.6535	.6348	.5487	.5487	.543
5	.6584	.6584	.6535	.5975	.5487	.5487	.5853
6	.7316	.695	.6722	.5914	.6036	.5853	.6219
7	.7499	.6584	.6722	.6722	.6767	.6584	.6584
8	.8413	.7316	.7095	.7095	.695	.6401	.6767
9	.8596	.7316	.7059	.6335	.724	.6697	.6697
10	.9877	.9328	.7964	.6697	.8507	.7421	.8688
11	1.0974	.8916	.8145		.905	.8326	.9231
12	1.0608	.8745	.8688		.9231	.7964	.8962
13	1.086	.8573	.8402		.8326	.8029	.8215
14	1.0136	.8573	.7888		.9231	.8501	.7468
15	.8688	.823	.7202			.8589	.7468
16	1.0498	.8402	.6859		.8417	.8589	.8589
17	.7783	.703	.7545	.7373	.8145	.7762	.7842
18	.7602	.7716	.703	.7373	.7602	.7468	.7468
19	.8688	.9259	.7716	.8573	.8326	.8962	.8589
20	.9231	.9088	.9088	.8573	.9593	.8962	.9335
21	.9231	.905	.8589	.8596	.8779	.8779	.8962
22	.905	.9335	.8589	.7865	.8413	.823	.823
23	.8413	.8501	.8215	.695	.7499	.7316	.7499
24	.7202	.7499	.7392	.6722	.6401	.6767	.6584
Max	1.0974	.9335	.9088	.8596	.9593	.8962	.9335
Min	.6584	.6219	.6535	.5914	.5487	.5487	.543
Avg	.8544	.7916	.7502	.7058	.7532	.7322	.7419

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 202 / 11 KV Bhadvan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.2926	.4481	.112	.1017	.1017	.0655
2	.8779	.2926	.4108	.1097	.1017	.0983	.0655
3	.8413	.2804	.3734	.1109	.1017	.0983	.0655
4	.8413	.2896	.4108	.1086	.1017	.1017	.0655
5	.823	.3224	.3982	.1109	.1017	.1017	.0655
6	1.134	.3582	.4908	.1307	.0983	.1017	.0655
7	1.5364	.4755	.5914	.1307	.0819	.1147	.0655
8		.5853	.6722	.1494	.0819	.1147	.0492
9	1.3717		.583	.1267	.0724	.0905	.0543
10	.2543	.1696	.181	.3224	.2715	.2172	.2658
11	.2926	.1372	.1991		.3429	.2149	.2835
12	.2458	.1543	.181		.3982	.2481	.3361
13	.2172	.1543	.12		.3012	.2241	.3734
14	.181	.1543	.1029		.3258	.2614	.2987
15	.181	.1372				.2987	.2801
16	.1448	.12			.2172	.3326	.2987
17		.1029			.2353	.3511	.2743
18		.1372			.1267	.0934	.1109
19		.1372	.1715	.1543	.1448	.112	.1307
20	.1448	.1543	.1715	.1543	.1448	.0934	.112
21	.1463	.1663	.1494	.1311	.1357	.1017	.1187
22	.1463	.1663	.1307	.1357	.1311	.0819	.1187
23	.128	.1848	.112	.1187	.1187	.0819	.0983
24	.8916	.3292	.4481	.1307	.0983	.0983	.0819
Max	1.5364	.5853	.6722	.3224	.3982	.3511	.3734
Min	.128	.1029	.1029	.1086	.0724	.0819	.0492
Avg	.5657	.2305	.3173	.1398	.1667	.1556	.1560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 203 / POLGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0848	.1097	.0934	.1848	.1357	.1147	.1311
2	.0678	.0914	.0747	.1867	.1147	.1147	.1311
3	.0655	.0914	.0739	.1867	.1187	.1187	.1311
4	.0655	.0914	.0701	.1867	.1187	.1187	.1311
5	.0678	.1086	.0934	.1867	.1187	.1187	.1311
6	.0678	.0905	.0924	.1848	.1187	.1311	.1475
7	.0678	.0701	.0905	.2054	.1357	.1526	.1802
8	.0678	.0549	.0732	.2427	.2035	.1966	.1966
9	.0492	.0549	.0543	.181	.1791	.181	.1772
10	.9328	.5487	.3898	.0543	.0543	.0724	
11	1.262	.4973	.5249			.0543	
12	1.3169	.4801	.6089			.0543	
13	1.1488	.4115	.5487			.0373	
14	1.0631	.3772	.5144			.0343	
15	.9602	.3944				.037	
16		.3086		.0514		.037	
17	.591	.2743	.2401	.0514		.0185	
18	.0905	.0857	.0686	.0857	.0905	.0747	.0934
19	.0905	.0857	.0686	.1029	.1086	.0934	.128
20	.1267	.1029	.0857	.1029	.0905	.0914	.1097
21	.128	.0934	.0934	.1017	.1017	.0983	.1017
22	.1097	.0934	.1097	.0848	.0848		.0983
23	.1097	.0934	.0914	.0848	.0819	.0819	.0848
24	.0857	.1086	.0934	.1867	.1311	.1147	.1475
Max	1.3169	.5487	.6089	.2427	.2035	.1966	.1966
Min	.0492	.0549	.0543	.0514	.0543	.0185	.0848
Avg	.3748	.1966	.1888	.1396	.1169	.0933	.1325

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 204 / 11 KV Watangi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1017	.128	.0934	.2614	.1638	.1147	.1802
2	.0983	.128	.0934	.2427	.1475	.1187	.1638
3	.1017	.1097	.0934	.2427	.1311	.1187	.1638
4	.0983	.1086	.0924	.2427	.1311	.1187	.1638
5	.1017	.128	.0934	.2427	.1311	.1187	.1638
6	.1311	.128	.112	.2427	.1475	.1475	.1638
7	.1526	.128	.112	.2241	.1638	.2035	.1638
8	.1638	.0914	.112	.2614	.1966	.213	.1802
9	.1865	.0848	.1086	.2534	.2149	.2328	.2126
10	1.0974	.7682		.0905	.0905	.0905	.0724
11	1.2803	.7545	.5552		.0724	.0362	.0724
12	1.4083	.7202	.3944		.0724	.0543	.0747
13	1.2346	.703	.463		.0543	.0373	
14	1.3032	.6516	.4115		.0905	.0373	
15	1.2174	.6344			.0905	.0373	
16	1.0099	.6173	.3086	.0686	.0724	.056	
17		.6001	.2915	.0857	.0905	.0747	
18		.0857	.0514	.0857	.0905	.056	.112
19		.0857	.0514	.1029	.0905	.0934	.0739
20		.12	.1029	.1029	.0905	.0934	.112
21	.1448	.112	.0934	.1017	.0819	.0819	.1017
22	.1433	.1086	.0934	.0819	.0848		.0819
23	.1254	.0934	.0934	.0678	.0678	.0655	.0819
24	.12	.128	.0934	.2614	.1638	.1311	.1966
Max	1.4083	.7682	.5552	.2614	.2149	.2328	.2126
Min	.0983	.0848	.0514	.0678	.0543	.0362	.0724
Avg	.5110	.3007	.1779	.1717	.1138	.1014	.1334



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 205 / 11 KV WATANGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4024	.3734		.3841	.333	.3366
2	.4024	.3801	.3361		.3841	.3366	.3439
3	.3841	.362	.3361		.3658	.3258	.3155
4	.4024	.3658	.3361		.3658	.3189	.3292
5	.4207	.394	.3734		.3841	.3189	.3544
6	.5121	.4755	.4108	.0181	.4024	.3721	.4207
7	.6219	.4887	.4854	.0187	.4755	.5304	.5487
8	.6401	.6584	.5228	.0171	.5853	.6219	.567
9	.7316	.6036	.5792	.3982	.5249	.6335	.5973
10	.695	.5853	.5249	.4163	.543	.5611	.4887
11	.5853	.4973	.543		.4706	.4525	.4706
12	.5304	.5316	.4525		.4344	.4344	.4294
13	.4344	.4973	.4458		.4706	.4108	.4066
14	.4525	.463	.4115		.4706	.3547	.4294
15	.5068	.463	.3429			.3921	.4854
16	.3982	.3772	.3772	.0343	.4344	.3734	.3361
17		.3429	.4801	.4801	.4706	.4805	.3921
18	.5249	.6001	.6001	.6687	.6335	.5544	.5041
19	.6878	.703	.6687	.8059	.7602	.8589	.7468
20	.8326	.8573	.8573	.8402	.8688	.9709	.9335
21	.695	.823	.8962	.823	.7316		.7316
22	.695	.6722	.5975	.695	.695		.6401
23	.5487	.4854	.4854	.4572	.439	.439	.4755
24	.4801	.4207	.3881	.3734	.4207	.3658	.362
Max	.8326	.8573	.8962	.8402	.8688	.9709	.9335
Min	.3841	.3429	.3361	.0171	.3658	.3189	.3155
Avg	.5487	.5187	.4927	.4319	.5093	.4745	.4852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 206 / 11 KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0549	.0554	.0373	.0492	.0492	.0492
2	.0492	.0549	.0554	.0373	.0492	.0492	.0492
3	.0509	.0549	.0526	.0373	.0509	.0492	.0492
4	.0509	.0543	.0526	.0373	.0509	.0492	.0492
5	.0492	.0543	.056	.0373	.0492	.0492	.0492
6	.0509	.0543	.056	.0373	.0492	.0655	.0509
7	.0509	.0549	.0554	.0373	.0492	.0492	.0492
8	.0492	.0366	.0543	.0373	.0492	.0339	.0655
9	.0678	.0655	.0724	.0362	.0543	.0543	.0724
10	.0678	.1187	.0724	.0362	.0724	.0724	.0724
11	.0848	.1029	.0724		.0724	.0905	.0724
12	.1357	.1029	.1086		.0905	.0724	.0686
13	.1086	.1029	.0686		.0724	.0514	.0747
14	.0905	.12	.0686		.0724	.0747	.056
15	.0905	.0857	.0686		.0724	.0739	.0747
16	.1086	.0171	.0686	.0343	.0724	.0747	.0747
17	.0543	.0171	.0686	.0343	.0724	.0739	.0747
18	.0724	.0857	.0857	.0514	.0724	.0739	
19	.0724	.0857	.0686	.0514	.0905	.0554	
20	.0543	.0686	.0686	.0514	.0543	.056	
21	.0543	.0747	.056	.0492	.0655	.0655	.0492
22	.0549	.0747	.056	.0492	.0678	.0655	.0655
23	.0537	.056	.056	.0509	.0655	.0655	.0509
24	.0514	.0543	.0543	.0373	.0509	.0655	.0655
Max	.1357	.12	.1086	.0514	.0905	.0905	.0747
Min	.0492	.0171	.0526	.0343	.0492	.0339	.0492
Avg	.0676	.0688	.0647	.0411	.0631	.0617	.0611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 207 / 11 KV Bhadvan Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4024	.4066	.3734	.4024	.3366	.3366
2	.3292	.3658	.3734	.3361	.4024	.3258	.3366
3	.3658	.362	.3506	.3361	.3658	.3189	.3475
4	.4024	.3258	.3921	.3361	.3658	.3189	.3366
5	.4024	.4572	.4294	.4207	.4024	.3544	.4024
6	.4207	.4887	.4854	.4207	.439	.4207	.4572
7	.5304	.5014	.499	.4382	.4572	.439	.5304
8	.5487	.5068	.5228	.5228	.4938	.4938	.567
9	.6036	.6036	.543	.4887	.5068	.5068	.5792
10	.6401	.6584	.5249	.4163	.5973	.4887	.5194
11	.6401	.5487	.4887		.5249	.4525	.5194
12	.5304	.4115	.4706		.5249	.5249	.4854
13	.4525	.5316	.4115		.5068	.3734	.3696
14	.5068	.4973	.3944		.4344	.3881	.3881
15	.4163	.4287			.4163	.3734	.3511
16	.4163	.4458	.1543		.4706	.3734	.4108
17		.4115	.4115		.5068	.3734	.4294
18		.4801	.4973	.3772	.543	.4294	.4854
19	.4887	.6173	.5316		.6878	.7655	.6036
20	.6878	.8059	.7716	.6173	.7964	.8215	.8589
21	.7316	.8589	.7468	.7316	.6767	.6767	.7499
22	.7316	.6722	.5975	.6219	.567	.5487	.6219
23	.6036	.5601	.5041	.4755	.4572	.4572	.4755
24	.4458	.439	.4481	.4108	.439	.3658	.3658
Max	.7316	.8589	.7716	.7316	.7964	.8215	.8589
Min	.3292	.3258	.1543	.3361	.3658	.3189	.3366
Avg	.5118	.5159	.4763	.4577	.4994	.4553	.4803

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 405 / 33 KV Amboli

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.4298
Max	.4298
Min	.4298
Avg	.4298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 406 / 33 KV CHITRI FEEDER Gen  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.052
Max	.052
Min	.052
Avg	.052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 201 / 11KV UtturVg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7095	.7164	.6653	.6161	.5975	.6805	.5788
2	.6722	.7164	.6283	.5914	.5228	.5373	.5601
3	.5975	.6805	.6283	.5975	.5228	.6089	.5415
4	.5975	.6805	.6283	.5544	.5788	.5895	.5415
5	.7095	.7164	.7023	.5975	.6348	.6805	.5975
6		.7522	.7392	.7577	.7095	.7164	.7095
7		.8238	.8501	.8215	.7842	.7522	.8029
8	.8962	.9313	.924	.8402	.8215	.8238	.8402
9	.9335	.9774		.8775	.8962	.8954	.8402
10	.9896	.9313	1.1016	.7468	.7095	.8596	.8589
11	.9671	.924	1.0829	.7468	.6805	.7655	.8131
12	.9313	.6283	1.1088	.7842	.7164	.6348	.7392
13	.9313	.5914	.5975	.8215	.7164	.8402	.6653
14	.8954		.6653	.8029	.7164	.8589	.7023
15	.8238		.8029	.7468	.7164	.7282	.6653
16		.6838	.8029	.6348	.6805	.7947	.8131
17		.6838	.8215	.6348	.788	.7468	.7762
18	.8596	.924	.9149	.8402	.788	.8402	.7762
19	.8954		1.1576	1.0829	.8596	1.1576	1.1827
20	1.2536	1.2936	1.3443	1.1763	1.0387	1.1389	1.4045
21	1.182	1.1827	1.1458	1.0456	1.0745	1.2136	1.2197
22	1.0387	1.0719	1.0269	.9335	.9313	1.0082	1.0719
23	.8238	.7392	.8775	.7655	.7522		.7392
24	.7468	.7522		.6535	.6348	.7164	.6161
Max	1.2536	1.2936	1.3443	1.1763	1.0745	1.2136	1.4045
Min	.5975	.5914	.5975	.5544	.5228	.5373	.5415
Avg	.8727	.8286	.8735	.7779	.7446	.8082	.7940

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 202 / 11KV Bahirewadi Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0503	.0162	.048	.1943	.2054	.1457	.125
2	.0514	.0648	.032	.1562	.168	.1619	.1107
3	.0514	.0648	.032	.1265	.168	.1619	.1094
4	.0514	.0486	.048	.1406	.1844	.1943	.1107
5	.0514	.0486	.048	.1581	.2054	.1943	.1107
6	.0514	.0486	.048	.2187	.2427	.2267	.1265
7		.0486	.048	.2846	.2801	.2267	.3005
8	.0671	.0648	.048	.3281	.3734	.2591	.3125
9	.0671	.0648	.048		.3734	.2267	.2688
10	.3734	.2915	.3479	.0158	.0503	.0486	.0503
11	.7773	.5601	.4586	.0168	.0486	.0469	.048
12	.9069	.6882	.4586	.0168	.0486	.0469	.048
13	1.1222	.6081	.5937	.0168	.0486	.0469	.048
14	.9717		.5468	.0335	.0486	.0474	.032
15	.9393		.5312	.0503	.0486	.0474	.048
16	.8436	.4001	.2343	.0335	.0486		.048
17		.3521	.3479	.0503	.0486	.0469	.048
18	.0648	.048	.0633	.048	.0486	.0463	.032
19	.0648		.0633	.0503	.0486	.0486	.048
20	.0648	.048	.0625	.0503	.0486	.0474	.032
21	.0648	.064	.0633	.0503	.0486	.0474	.032
22	.0648	.048	.0633	.0503	.0486	.0503	.048
23	.0648	.048	.0486	.0514	.0486		.032
24	.0503	.0648	.048	.2214	.2241	.1296	.1423
Max	1.1222	.6882	.5937	.3281	.3734	.2591	.3125
Min	.0503	.0162	.032	.0158	.0486	.0463	.032
Avg	.3098	.1757	.1805	.1027	.1295	.1135	.0963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 203 / MAHAGOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2172	.1753	.0175	.0373	.0181	.0173
2	.2427	.2534	.1753	.0177	.0354	.0181	.0175
3	.2241	.2534	.1753	.0173	.0354	.0181	.0173
4	.2801	.3258	.1772	.0181	.0354	.0181	.0173
5	.3174	.3258	.1772	.0173	.0354	.0181	.0173
6	.3547	.362	.2303	.0173	.0354	.0181	.0173
7		.3982	.2835	.0173	.0354	.0181	.0173
8	.5601	.4163	.3366	.0173	.0354	.0181	.0173
9	.7095	.4344	.3189	.0173	.0354	.0181	.0173
10	.0354	.0362	.0173	.0173	.0354	.2172	.0187
11	.0362	.0354	.0173	.168	.2172	.2601	.3012
12	.0362	.0354	.0173	.1494	.3258	.2601	.298
13	.0362	.0177	.0173	.1867	.362	.2774	.2629
14	.0362		.0175	.2614	.3258	.3506	.2629
15	.0362		.0173	.3361	.3258	.3467	.2279
16	.0181	.0177	.0347	.2614	.3077	.3353	.2454
17	.0181	.0177	.0347	.2614	.2896		.2454
18	.0181	.0177	.0347	.3361	.0362	.0173	.0175
19	.0181		.0347	.0354	.0362	.0173	.0175
20	.0181	.0354	.0351	.0354	.0181	.0173	.0354
21	.0181	.0177	.0347	.0354	.0181	.0173	.0354
22	.0181	.0177	.0351	.0354	.0181	.0173	.0354
23	.0181	.0177	.0347	.0354	.0181		.0354
24	.3361	.2172	.2126	.0351	.0354	.0181	.0168
Max	.7095	.4344	.3366	.3361	.362	.3506	.3012
Min	.0181	.0177	.0173	.0173	.0181	.0173	.0168
Avg	.1602	.1652	.1102	.0978	.1121	.1052	.0922



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 201 / 11 KV Kanoli Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4161	.7362	.362	.3467		.3121	.3696
2	.3814	.7049	.3582	.3121		.3121	.3292
3	.3814	.7087	.362	.3121		.3429	.3258
4	.4115	.7838	.3982	.3467		.3814	.362
5	.4508	.855	.4344	.3772		.4161	.394
6	.5201	.9213	.5068	.4458		.4161	.439
7	.5548	.9164	.5611	.4508		.4854	.5249
8	.583	.9517	.5792	.5201		.4854	.5731
9	.5548	1.0222	.6154	.5548		.5548	.6024
10	.6241	.9869	.5249				.5792
11	.6068	.9213	.5201				.4298
12	.5316	.4477	.5201		.5144	.4066	
13	.4973	.4298			.4801	.3881	.4508
14	.4801	.3982	.4508			.3696	.2774
15	.4115				.0514	.4163	.3641
16		.2172	.3988		.1372	.4163	.3814
17		.5249	.3467		.2915	.4706	.3814
18	.1029	.5973	.5721		.5658	.591	.3467
19	.3772	.724			.8402	.7602	.5548
20	.2229	.724	.7802		.7282	.7602	.7282
21	.2229	.6516	.6588		.6068	.6348	.6241
22	.463	.543					.5201
23	.4287	.4706	.4508		.3814		.4161
24	.4508	.8063	.4163	.3814		.3467	.3696
Max	.6241	1.0222	.7802	.5548	.8402	.7602	.7282
Min	.1029	.2172	.3467	.3121	.0514	.3121	.2774
Avg	.4397	.6975	.4908	.4048	.4597	.4633	.4497

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 202 / 11KV Sarambalwadi Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.1989	.0762	.0173	.0362		.0181
2	.6173	.1966	.08	.0173	.0362		.0183
3	.6588	.1955	.0914	.0173	.0362		.0181
4	.6935	.1932	.1067	.0173	.0362		.0181
5	.7282	.1943	.1189	.0173	.0181		.0379
6	.823	.1932	.1562	.0693	.0181	.0171	.0175
7	.9015	.2104	.1656	.0173	.0181	.0173	.0358
8	.8916	.282	.1656	.0173	.0181	.0173	.0373
9	1.0402	.3506	.1806	.0173	.0362	.0173	.0189
10	.0693	.035	.0179		.0543		.1174
11	.0173	.0352	.0173				.0892
12	.0171	.0181	.0173		.1029	.1467	
13	.0171	.0179			.1029	.1174	.1387
14	.0171	.0179	.0173			.0892	.1387
15	.0171	.0179			.0686	.088	.1387
16	.0171	.0181	.0173		.0686	.1433	.1387
17	.0171	.0175	.0171		.1029	.104	.1372
18		.0358	.0173		.0171	.0175	.0347
19		.0362			.0171	.0358	.0347
20		.0358	.0173		.0173	.0358	.0693
21		.0362	.0173		.0173	.0358	.0173
22	.0171	.0362				.0358	.0347
23	.0171	.0362	.0173		.0173	.0179	.0347
24	.6241	.2001	.0724	.0173			.0179
Max	1.0402	.3506	.1806	.0693	.1029	.1467	.1387
Min	.0171	.0175	.0171	.0173	.0171	.0171	.0173
Avg	.3909	.1087	.0694	.0225	.0420	.0585	.0592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 203 / 11 kv Kolindre Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1387		.0716	.1734			.0914
2	.1387		.0716	.1734	.1448		.088
3	.1387		.0716	.1734	.1448		
4	.1372		.0537	.1734	.1086		
5	.1387		.0716	.1734			.1054
6			.0716	.208		.1387	.1174
7	.1372		.0716	.2427		.1734	.1524
8	.1387		.0716	.2427		.1734	.1614
9	.1715	.2454	.0716	.2427		.1715	.1524
10	1.0056	.9259	.1086				.0358
11	1.0056	.9336	.3814				.0351
12	.945	.5068	.4161		.0686	.0358	
13	1.0631	.5068			.0686	.0358	.0347
14	.945	.427	.4508				.0343
15	.9755	.3963			.0171	.0351	.0693
16			.1734		.0171	.0358	.0693
17		.3749	.1734		.0343	.0358	.052
18	.1029	.0716			.0171	.0537	.0343
19	.12	.0716			.0171	.0537	.0693
20	.12	.1075	.0693		.0693	.0358	.0347
21		.0709	.0693		.0347	.0358	.0347
22	.12	.0716				.0358	.0347
23	.1029	.0716	.0693		.0347		.0343
24	.1387	.2081	.0716	.1734			.0914
Max	1.0631	.9336	.4508	.2427	.1448	.1734	.1614
Min	.1029	.0709	.0537	.1734	.0171	.0351	.0343
Avg	.3892	.3326	.1374	.1977	.0598	.0750	.0730

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 201 / 11 KV Devarde Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.181	.2172	.1867	.1867	.1663	.181
2	.2172	.1791	.2012	.1663	.1867	.1463	.1433
3	.2172	.1433	.1848	.1663	.1509	.1478	.1433
4	.2149	.1829	.1829	.1646	.1494	.1463	.1791
5	.2534		.2033	.1829	.1463	.1646	.1791
6	.3658		.2534	.2195	.2149	.2195	.2103
7	.3856		.3224	.3045	.2401	.2926	.2103
8	.4801	.1448	.3315	.3045	.3429	.2683	.2743
9	.4207		.3277	.3721	.4115	.3018	.2035
10	.3391	.3189	.4359	.3467	.3048	.2915	.2915
11	.3814	.4458	.4578		.4588	.1619	.2915
12	.3506	.421	.4835		.5243	.2949	.2058
13	.3155	.3978	.5201		.3437	.2881	.2454
14	.2454	.431	.463		.3395	.3048	.3155
15	.2035	.3429	.2401			.3563	.3086
16	.2267	.3155	.2947			.2622	.2804
17	.2035	.4481	.3366	.0189	.1989	.3315	.3403
18	.1772	.4298	.3045	.3772	.2896	.2915	.3086
19	.3506	.4908	.4572		.3658	.3772	.2865
20	.4252	.5853	.5194	.2835	.4755	.3582	.439
21	.3658	.4435	.3547	.2926	.3696	.3258	.3696
22	.2926	.4066	.2987	.3658	.3174	.2896	.2772
23	.2534	.2957	.2241	.2241	.1848	.2149	.2033
24	.2587	.2195	.2507	.1867	.1848	.1848	.1829
Max	.4801	.5853	.5201	.3772	.5243	.3772	.439
Min	.1772	.1433	.1829	.0189	.1463	.1463	.1433
Avg	.3000	.3412	.3277	.2449	.2903	.2578	.2529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 202 / 11 KV Velvatti Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0914	.1086	.0838	.0762	.0972	.0339
2	.1086	.0732	.1075	.0819	.0926	.0983	.0343
3	.1097	.0914	.1086	.0819	.0762	.1147	.0339
4	.1097	.0724	.1097	.0838	.0869	.0972	.0343
5	.1109	.0905	.1086	.0838	.0772	.1147	.0339
6	.1097	.0924	.1086	.0983	.0914	.1134	.0339
7	.1075	.0724	.1109	.1296	.1158	.1326	.0324
8	.1063		.0709	.2572	.1014	.0983	.0914
9	.1086		.0747	.2572	.1014	.0914	.0914
10	.4161		.2915	.0754	.0168	.0838	.0335
11	.6081		.2984		.0171	.0762	.0867
12	.583	.3353	.3688		.0332	.0457	.0716
13	.506	.3395	.4024		.0316	.0762	.0716
14	.4268	.3437	.3605		.0648	.0633	.0716
15	.4268					.0377	.0716
16	.4877	.0663			.0663	.0373	.0686
17		.0926	.0671		.0686	.0686	.0686
18		.0724	.0168	.0747	.0686	.0926	.0857
19		.0732	.0943	.0934	.1109	.1029	.0732
20	.0351	.1109	.0754	.0747	.1109	.1063	.0739
21	.0358	.1132	.0754	.0747	.0747	.1052	.0924
22	.0876	.1132	.0754	.0747	.0747	.104	.0914
23	.0739	.0943	.0754	.0747	.0739	.1029	.0905
24	.1097	.0739	.1097	.0838	.0914	.096	.0343
Max	.6081	.3437	.4024	.2572	.1158	.1326	.0924
Min	.0351	.0663	.0168	.0747	.0168	.0373	.0324
Avg	.2275	.1270	.1463	.1049	.0749	.0899	.0627

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 203 / 11 KV Kittawade Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5898	.2439	.3149	.0754	.0739	.0732	.0857
2	.5668	.2439	.2949	.0754	.0754	.0724	.0857
3	.5668	.2439	.2949	.0754	.0754	.0732	.0857
4	.5898	.2469	.3077	.0754	.0747	.0732	.0848
5	.6316	.2439	.3163	.0754	.0754	.0739	.0838
6	.7701	.2623	.3795	.0754	.0747	.0732	.0848
7	1.1568	.3201	.4999	.0754	.0914	.0739	.0857
8	1.3108		.5921	.0754	.0924		.0701
9	1.3094		.6226	.0754	.0747	.0732	.0678
10	.0943	.0554	.0537	.3944	.3506	.1886	.1219
11	.0566	.0732	.0747		.5121		.2347
12	.0566	.0724	.0886		.5093	.2134	.213
13	.0762	.0724	.0886		.5218	.2134	.2572
14	.0572	.0549	.0857		.4784	.1829	.1844
15	.0754	.0724				.1829	.1509
16	.0924	.0716			.0486	.216	.1311
17	.0934	.0724	.0177	.3521	.0328	.2656	.1509
18		.0732	.0739	.0876	.0168	.081	
19	.0181	.0724	.0754	.0934	.0895	.0934	
20	.0943	.0924	.0943	.0934	.0914	.0943	.0934
21	.0953	.0739	.0943	.0934	.0924	.0867	.0924
22	.0943	.0739	.0943	.0934	.0924	.1017	.0724
23	.0762	.0747	.0754	.0934	.0747	.0838	.0716
24	.5761	.2743	.3353	.0754	.0754	.0739	.0857
Max	1.3108	.3201	.6226	.3944	.5218	.2656	.2572
Min	.0181	.0549	.0177	.0754	.0168	.0724	.0678
Avg	.3934	.1402	.2216	.1142	.1606	.1211	.1179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 146006 / 220KV Gadhinglaj(Mumewadi)

Feeder No / Name : 408 / 33 KV Soot Girni

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.3921
Max	.3921
Min	.3921
Avg	.3921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 201 / 11 KV KOWAD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.5144		
7			.5487		
9				.5144	.6348
10	.6516			.5144	.7095
11	.6859			.5144	.5975
12					.5601
13					.4481
14					.4108
15				.5144	.5601
16					.5601
17					.5258
18					.5609
19					.7011
23		.5144			
24			.4115		.4024
Max	.6859	.5144	.5487	.5144	.7095
Min	.6516	.5144	.4115	.5144	.4024
Avg	.6688	.5144	.4915	.5144	.5559



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 202 / 11 KV Kagani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.2012	.1017
10	1.2742		.0381
11	1.7436		.0381
12			.0381
13			.0381
14			.0381
24			.0671
Max	1.7436	.2012	.1017
Min	1.2742	.2012	.0381
Avg	1.5089	.2012	.0513

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 203 / 11 KV Kudnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.4801		
7			.5487		
8					.3688
9				.4115	.7095
10	.6859			.4115	.7468
11	.6859			.1715	.7468
12					.7468
13					.6348
14					.4854
15				.3429	.4854
16					.4481
17					.4115
18					.4252
19					.7011
23		.4801			
24			.4801		
Max	.6859	.4801	.5487	.4115	.7468
Min	.6859	.4801	.4801	.1715	.3688
Avg	.6859	.4801	.5030	.3344	.5759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 204 / 11 KV KUDNOOR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
6	.0671		
7	.0671		
9			.0381
10		.2012	.096
11		.1677	.096
12			.128
13			.128
15		.1341	.128
16			.1494
17			.1372
24	.0671		
Max	.0671	.2012	.1494
Min	.0671	.1341	.0381
Avg	.0671	.1677	.1126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 205 / 11 KV KAGANI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.0686		
7			.0686		
9				.1372	.192
10	.1372			.1372	.1494
11	.1029			.1372	.1494
12					.112
13					.0747
14					.0747
15				.0686	.7468
16					.0747
17					.0701
18					.0724
19					.1448
23		.0686			
24			.0686		.0663
Max	.1372	.0686	.0686	.1372	.7468
Min	.1029	.0686	.0686	.0686	.0663
Avg	.1201	.0686	.0686	.1201	.1606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 206 / 11 KV Hemrus

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6			.0343		
7			.0343		
9					.0381
10	.0343				.0381
11	.0343				.0381
12					.0381
13					.0381
15				.0343	.0381
16					.0381
17					.0351
23		.0686			
24			.0686		.0335
Max	.0343	.0686	.0686	.0343	.0381
Min	.0343	.0686	.0343	.0343	.0335
Avg	.0343	.0686	.0457	.0343	.0373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 207 / Nrusinhwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
9		.7042	.1357
10	1.4083		.0381
11	2.4143		.0381
12			.0381
13			.0381
14			.0381
15			.0381
16			.0381
24			.0671
Max	2.4143	.7042	.1357
Min	1.4083	.7042	.0381
Avg	1.9113	.7042	.0522

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 208 / RAJGOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.2012		
7		.2012		
9				.0381
10			.1677	.4481
11			.1677	.4801
12				.4161
13				.3841
15			.1006	
24	.2058	.2012		
Max	.2058	.2012	.1677	.4801
Min	.2058	.2012	.1006	.0381
Avg	.2058	.2012	.1453	.3533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV SHINOLI EX.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.0754	.1132	.1187	.0983	.0754	.1187
2	.0678	.0377	.0377	.0678	.0648	.0377	.0678
3	.0339	.0377	.0377	.0339	.0328	.0377	.0328
4	.0339	.0377	.0377	.0339	.0377	.0377	.0324
5	.0339	.0377	.0377	.0339	.0377	.0377	.0328
6	.0339	.0377	.0377	.0339	.0377	.0377	.032
7	.032	.0377	.0377	.0339	.0377	.0377	.0339
8	.1357	.1509	.1509	.1326	.1509	.1509	.1357
9	.1357	.1509	.1509	.1357	.1698	.1509	.1357
10	.1463	.1463	.1509	.1448	.1463	.1463	.1357
11	.1097	.1448	.1357	.1448	.1463	.128	.1509
12	.1109	.1086	.1187	.1097	.1086	.1097	.1132
13	.1097	.1086	.1187		.1097	.1097	.1132
14	.0373	.037	.0339		.0373	.0373	.0328
15	.0377	.0373	.0339	.0373	.0377	.0373	.0377
16	.0373	.0373	.017	.0373		.0373	.0377
17	.0373	.0373	.0339	.0377	.0373	.0373	.0377
18	.0377	.0377	.0339	.0377	.0377	.0339	.0377
19	.0189	.0377	.0339	.0377	.0377	.0339	.0377
20	.132	.1509	.1357	.1509	.1509	.1357	
21	.1509	.1509	.1357	.1509	.1509	.1357	.132
22	.1509	.1509	.1357	.132	.1509	.1357	.1509
23	.1509	.1509	.1357	.1132	.1509	.1187	.1132
24	.1187	.1132	.1132	.1187	.1132	.1132	.1187
Max	.1509	.1509	.1509	.1509	.1698	.1509	.1509
Min	.0189	.037	.017	.0339	.0328	.0339	.032
Avg	.0838	.0855	.0837	.0853	.0906	.0814	.0813



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV Gaulwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0156	.0152	.4409	.2785	.1524	.1357
2	.017	.0156	.0152	.4409	.2915	.1372	.1311
3	.017	.0156	.0152	.4578	.3277	.1372	.1357
4	.017	.0154	.0152	.4578	.3605	.1372	.1357
5	.017	.0154	.0152	.5087	.3605	.1372	.1357
6	.017	.0154	.0152	.5304	.3932	.1372	.1311
7	.017	.0152	.0152	.5935	.4239	.1524	.1357
8	.017	.0164	.0152	.7461	.4191	.1677	.1696
9	.017	.0164	.0152	.7122	.426	.1524	.2035
10	.5138	.9069	.823	.0181	.0183	.0185	.017
11	1.3443	1.2498	1.17	.0183	.0185	.0185	.0164
12	1.2955	.2947	1.2378	.0185	.0185	.0185	.0162
13		1.326	1.1022		.0185	.0187	
14	1.3435	1.3717	1.0343		.0187	.0185	
15	1.1405	1.0669		.0187	.0187	.0187	
16	1.0159	.9172	.8478	.0187		.0185	.8356
17		.7362	.6274	.0187		.0187	.0162
18	.0156	.0152	.017	.0164	.0152	.017	.0162
19	.0164	.0152	.017	.0164	.0152	.017	.0164
20	.0156	.0152	.017	.0164	.0152	.017	
21	.0156	.0152	.017	.0164	.0152		.0162
22	.0156	.0152	.017	.0164	.0152	.017	.0164
23	.0164	.0152	.017	.0164	.0152	.017	.0164
24	.017	.0164	.0152	.4409	.2785	.1524	.1357
Max	1.3443	1.3717	1.2378	.7461	.426	.1677	.8356
Min	.0156	.0152	.0152	.0164	.0152	.017	.0162
Avg	.3145	.3383	.3085	.2518	.1710	.0738	.1216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV BELEBHAT Mix

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.1638	.2103	.1865	.1475	.1227	.1526
2	.1966	.1475	.1928	.1865		.1227	.1526
3	.2204	.1311	.1928	.1865	.1311	.1227	.1526
4	.2458	.1147	.1928	.2035	.1311	.1227	.1526
5	.2883	.1147	.2103	.2883	.1475	.1402	.2035
6	.3222	.2294	.2804	.3222	.2294	.1928	.2883
7	.4239	.3768	.4207	.3481	.4424	.2804	.39
8	.4973	.3768	.4733	.373	.3725	.3155	.39
9	.3391	.3605	.4382	.39	.3768	.2804	.373
10	.2713	.4191	.4382	.3481	.373	.298	.3391
11	.373	.2881	.4239	.39	.373	.2481	.3163
12	.2818	.2601	.373		.3012		.2458
13	.298	.2481	.3052		.2947	.2883	.1966
14	.3294	.1097	.3222	.3155	.2947	.3045	.1943
15	.333	.1075	.2883	.3121	.3429	.3012	.2429
16	.3155	.4207	.3052	.2835		.298	.1619
17	.4382	.4239	.3052	.3155	.3012	.3601	.2458
18	.4096	.3506	.4578	.2915	.298	.3561	.2785
19		.5434	.5087	.4049	.4733		.4424
20	.5079	.5434	.5316	.4752	.4557	.5426	
21	.4752	.4557	.4917	.3605	.3856	.4748	.4372
22	.4191	.3681	.3561	.3113	.2804	.3391	.3113
23	.2812	.2804	.2713	.1943	.1753	.2204	.1802
24	.2713	.2515	.2279	.2204	.1619	.1402	.1802
Max	.5079	.5434	.5316	.4752	.4733	.5426	.4424
Min	.1966	.1075	.1928	.1865	.1311	.1227	.1526
Avg	.3366	.2952	.3424	.3049	.2950	.2669	.2621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Gaulwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1696	.1989	.1928	.1357	.1311	.1402	.1357
2	.1696	.1581	.1753	.1326	.1147	.1402	.1357
3	.2035	.1311	.1886	.1372	.1147	.1402	.1357
4	.1966	.1311	.1753	.1457	.1134	.1402	.1526
5	.2035	.1475	.2103	.1526	.1638	.1753	.2035
6	.2374	.213	.2454	.2035	.1966	.1928	.2374
7	.2713	.2785	.2804	.2543	.2543	.2454	.2883
8	.3222	.3113	.3155	.3052	.2622	.2279	.2883
9	.373	.3113	.298	.2883	.2785	.298	.3222
10	.4239	.3681	.3155	.2601	.3641	.3155	.3391
11	.4161	.3155	.2883	.2947	.3506	.298	.3113
12	.3814	.298	.3052	.2481	.3429	.3155	.2622
13		.3391	.2883		.2774	.3258	.2622
14	.3506	.3121	.2543		.2835	.2835	.2267
15	.2883	.3121		.2713	.2658	.3121	
16	.3506	.3189	.2543	.2947		.2629	.2294
17		.3391	.2713	.2103	.3155	.2454	.2458
18	.3401	.3506	.3052	.2294	.333	.3052	.2458
19	.3688	.3856	.3222	.3353	.333	.407	.3441
20	.3932	.3506	.3391	.2785	.3155	.3222	
21	.3441	.3506	.2883	.2429	.2804	.2883	.2949
22	.3113	.333	.2713	.213	.2454	.2543	.2785
23	.213	.298	.2204	.1638	.1928	.2035	.1966
24	.2155	.213	.2279	.1865	.1457	.1578	.1638
Max	.4239	.3856	.3391	.3353	.3641	.407	.3441
Min	.1696	.1311	.1753	.1326	.1134	.1402	.1357
Avg	.2974	.2819	.2623	.2265	.2467	.2499	.2409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 207 / 11 KV Turkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.0625	.0457	.6443	.2785	.1981	.1865
2	.0164	.0492	.0457	.6783	.2915	.1829	.1865
3	.017	.0492	.0457	.6783	.2949	.1829	.1865
4	.0509	.0469	.0457	.763	.3113	.1829	.1865
5	.0509	.0633	.0457	.8478	.3239	.1829	.1865
6	.0509	.0819	.0457	.9667	.3441	.1829	.1865
7	.0678	.0972	.061	.9667	.3441	.1981	.2035
8	.0678	.0732	.061	1.153	.3768	.2286	.2949
9	.0678	.0732	.0762	1.1869	.3277	.2439	.2543
10	.8642	.2543	1.5546		.0554	.0549	.0509
11	2.2184	2.5587	2.6113	.0554	.0554	1.7187	.0486
12	2.5587	2.7006	2.0008	.0739	.0549	.0554	.0492
13	2.4684	2.4996	2.1136		.056	.0549	.0648
14	2.1605	2.2253	2.1704		.0554	.0554	.0486
15	2.0729	1.9566	1.4582	.0554	.0549	.0537	.0486
16	1.7394	1.8595	1.3904	.0554		.0554	.0486
17	1.4842	1.5741	1.3226	.0554	.0554	.056	.0492
18	.0983	.061	.0678	.0492	.0762	.0678	.0492
19	.0791	.061	.0678	.0486	.061	.0678	.0492
20	.081	.061	.0678	.0486	.061	.0509	
21	.0819	.061	.0678	.0492	.061	.0509	.0486
22	.0819	.061	.0678	.0469	.061	.0509	.0474
23	.0655	.061	.0678	.0328	.061	.0509	.0492
24	.0678	.0648	.061	.5935	.2785	.1981	.1696
Max	2.5587	2.7006	2.6113	1.1869	.3768	1.7187	.2949
Min	.0164	.0469	.0457	.0328	.0549	.0509	.0474
Avg	.6887	.6940	.6484	.4309	.1713	.1844	.1171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 208 / 11 KV Shivanage Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.2058
Max	.2058
Min	.2058
Avg	.2058

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 209 / 11 KV BELEBHAT Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6443	.2458	.3506	.017	.0328	.0305	.0492
2	.6443	.2294	.3353	.0509	.0328	.0305	.0486
3	.6783	.2294	.3353	.0509	.0312	.0305	.0492
4	.7122	.2622	.3353	.0509	.0328	.0305	.0497
5	.78	.2785	.3353	.0678	.0492	.0305	.0509
6	.8029	.2949	.3353	.0678	.0492	.0305	.0655
7	.9326	.2949	.442	.0678	.0486	.061	.0678
8	1.0322	.4534	.5639	.0509	.0486	.061	.0678
9	1.1869	.3932	.5639		.0486		.0509
10	.0543	.0366	.0457	.0537	.2103	.2058	.1696
11	.0549	.037	.0509	.333	.2229	.2103	.1619
12	.037	.0185	.0678	.3155	.3506	.1595	
13	.0554	.037	.0509	.2774	.298	.208	
14	.037	.037	.0509	.3155	.4694	.2126	
15	.0373	.0366		.2103	.4748	.1753	
16	.037	.037		.2126		.1734	
17	.037	.037	.0509	.2103		.1595	.1134
18		.0305	.0509	.0324		.0509	.0492
19	.0492	.061	.0655	.0492	.061		.0492
20	.0648	.0762	.0509	.0486	.061	.0678	
21	.0655	.061	.0509	.0486	.061	.0678	.0486
22	.0492	.061	.0509	.0324	.0457	.0509	.0486
23	.0492	.0457	.0509	.0324	.0457		.0486
24	.6783	.2458	.3506	.0509	.0312	.0457	.0509
Max	1.1869	.4534	.5639	.333	.4748	.2126	.1696
Min	.037	.0185	.0457	.017	.0312	.0305	.0486
Avg	.3791	.1475	.2084	.1151	.1288	.0996	.0689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 210 / Gad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2035	.1802	.1219		.0164	.0152	.0162
2	.2035	.1638	.1219		.0164	.0152	.0164
3	.2035	.1966	.1219		.0164	.0152	.017
4	.2035	.2622	.1219		.0164	.0152	.017
5	.2652	.2622	.1524		.0164	.0152	.0164
6	.3391	.2949	.1829		.0164	.0152	.017
7	.4578	.3441	.3048		.0164	.0152	.017
8	.6104	.4424	.381		.0164	.0152	.017
9	.6443	.4424	.3353		.0162	.0152	.017
10	.0183	.0181	.0152		.0701	.0886	.017
11	.0185	.0185	.017	.1402	.0914	.0876	.0492
12	.0185	.0187		.1595	.0716	.0701	
13	.0185	.0183	.017	.3052	.0185	.0716	
14	.0183	.0187	.017	.1417	.1372	.0537	
15	.0187	.0183	.017		.1543	.0732	
16	.0187	.0183	.017				.0324
17	.0183	.0187			.1063	.0177	.0164
18	.0164	.0152			.0152	.0164	.0156
19	.0162	.0152		.0164	.0152		.0156
20	.0164	.0152		.0162	.0152	.017	
21	.0164	.0152		.0162	.0152	.017	.0162
22	.0164	.0152		.0164	.0152	.017	.0162
23	.0164	.0152		.0156	.0152	.017	.0162
24	.017	.1802	.1067		.0164	.0152	.017
Max	.6443	.4424	.381	.3052	.1543	.0886	.0492
Min	.0162	.0152	.0152	.0156	.0152	.0152	.0156
Avg	.1414	.1253	.1282	.0919	.0393	.0318	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 201 / 11 KV Adkur Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0377	.0377	.0943	.0189	.0189	.0377
2	.0377	.0377	.0377	.0754	.0187	.0189	.0189
3	.0189	.0377	.0381	.0747	.0185	.0377	.0183
4	.0189	.0377	.0381	.0747	.0185	.0566	.0377
5	.0189	.0366	.0377	.0934	.0181	.0566	.0377
6	.0377	.0377	.0373	.1307	.0179	.0566	.056
7	.0566	.0377	.0358	.1463	.0537	.0566	.0747
8	.0754	.0566	.0366	.168	.0701	.0554	.0554
9	.0373	.056	.0366	.1905	.0549	.0554	.056
10	.0187	.037	.0362	.1334	.0362	.0185	.037
11	.0373	.0377	.0358	.1132	.0366	.037	.0183
12	.0366	.0189	.0183		.0183	.037	.0185
13	.037	.0183	.0185		.0183	.037	.0181
14	.0373	.0187	.0366		.0181	.037	.0183
15	.0366	.0189				.037	.0183
16	.0366	.0187	.0526			.037	.0366
17	.0373	.0362	.0543	.0526	.0354	.037	.0185
18	.056	.0549	.0537	.0543	.0358	.0554	.0532
19	.0914	.0924	.0732	.0924	.0543	.0739	.0739
20	.0914	.0924	.0747	.0924	.0934		.0934
21	.0747	.0762	.0754	.0943	.0732	.0739	.0754
22	.056	.0572	.0566	.0754	.0566	.056	.0566
23	.0566	.0377	.0377	.0377	.0373	.037	.0377
24	.0377	.0377	.0377	.0187	.0189	.0377	.0377
Max	.0914	.0924	.0754	.1905	.0934	.0739	.0934
Min	.0187	.0183	.0183	.0187	.0179	.0185	.0181
Avg	.0450	.0428	.0433	.0954	.0374	.0445	.0418



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 202 / 11 KV Kurtanwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943		.0857		.0747	.0943	.0943
2	.0943		.0514		.0747	.0754	.0943
3	.0554		.0509		.0554	.0754	.0943
4	.0566		.0509		.056	.0754	.0943
5	.0554		.061		.0739	.0754	.1132
6	.0934		.0995		.1109	.112	.112
7	.1494	.132	.1341		.1307	.1478	.1663
8	.1867	.2218	.1638		.1848	.1848	.2218
9	.2218	.2427	.2058		.1646	.1478	.2263
10	.2033	.1848	.132		.0709		.1867
11	.2614		.181		.1267		.1509
12	.2587	.2103	.1772	.1132	.1829		.1478
13	.2033	.1949	.1734	.0943	.1543		.197
14	.2218	.2241	.1595	.0934	.1543	.1294	.1663
15	.1867	.208		.112		.0924	.1294
16	.1663	.2204	.1612	.0943		.0924	.1646
17	.1663	.2347	.1791	.1109	.1663	.0924	.156
18	.2218	.2481	.1829	.1097	.1829	.1848	.1629
19	.2263	.2172	.2241	.168	.2241	.2218	.2054
20	.2772	.2427	.2241	.2587	.1991		.2427
21	.2378	.2103	.1886	.2075	.1791	.2402	.2075
22	.1886	.1715	.1715	.1715	.1463	.1848	.1509
23	.132	.1307	.1132	.112	.112	.1509	.0953
24	.132	.1132	.1132	.0934	.0934	.1132	.132
Max	.2772	.2481	.2241	.2587	.2241	.2402	.2427
Min	.0554	.1132	.0509	.0934	.0554	.0754	.0943
Avg	.1705	.2004	.1428	.1338	.1326	.1311	.1547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 203 / 11 KV Here Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0514	.0549	.0934	.3772	.0335	.037
2	.0543	.0514	.056	.0934	.3361	.0339	.0343
3	.0343	.0514	.056	.0739	.3361	.0335	.0343
4	.0343	.0514	.0732	.0732	.3326	.0339	.0343
5	.0343	.0701	.0886	.0914	.3734	.0343	.0514
6	.0724	.0876	.1097	.128	.4481	.052	.0686
7	.1307	.0905	.12	.1949	.4805	.0876	.0857
8	.124	.1227	.1677	.2103	.5914	.0914	.0857
9	.1029	.1029	.1372	.1267	.6268	.0747	.0693
10	.1029	.1052	.168	.1448		.0701	.0876
11	.0876	.0701	.0914	.1448	.5121	.0857	.052
12	.0914	.0693	.116	.1433	.3429	.0857	.0526
13	.0905	.0857	.1006	.1267	.3391	.0686	.0497
14	.0924	.0732	.1017	.3292			
15	.1086	.052		.3658		.0857	.0351
16	.1267	.1017	.104	.3511		.0686	.0532
17	.1267	.1029	.1433	.4119		.0686	.1075
18	.1052	.1867	.208	.4207	.1029	.0857	.0701
19	.1629	.2096	.2172	.5729	.1132	.1086	.1109
20	.1448	.2263	.1928	.8775	.12		.1494
21	.1267	.1905	.1791	.7545	.1052	.1029	.1132
22	.0857	.1307	.1086	.6224	.0686	.0686	.0934
23	.0514	.0943	.1075	.4338	.052	.0514	.0526
24	.0549	.0343	.0514	.112	.3961	.0358	.0554
Max	.1629	.2263	.2172	.8775	.6268	.1086	.1494
Min	.0343	.0343	.0514	.0732	.052	.0335	.0343
Avg	.0917	.1005	.1197	.2874	.3186	.0664	.0688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 204 / 11 KV Hambire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516		.0857	.0625	.0189	.017	.0183
2	.7202		.1372	.0158	.0187	.0171	.0183
3	.7202		.1387	.0158	.0187	.0171	.0183
4	.7716		.1402	.0156	.0189	.0175	.0183
5	.8059		.2378	.0154	.0189	.0189	.0183
6	.8402		.2279	.0154	.0189	.0187	.0185
7	.8916		.2279	.0154	.0189	.0171	.0185
8	.9774			.0143	.0189		.0185
9	1.0117	.1619	.1715	.0141	.0189	.0171	.0181
10	.1006	.0183	.0173	.2774	.2105	.1372	.0857
11	.1097	.0152	.0175	.3521	.1966	.1372	.1677
12	.1097	.0678	.0189	.3391	.1943	.1696	.1677
13	.0914	.017	.0189	.3391		.1696	.1844
14	.1097	.0171		.3467	.2105		
15	.0924	.0173		.3641		.1886	.1235
16	.0739	.0171	.0189	.3052		.2035	.0972
17	.0732	.0171		.3018	.0648	.2058	.0903
18	.0732	.017	.0164	.0189	.0187	.0739	.0189
19	.0914	.0166	.0716	.0189	.0189	.0732	.0189
20	.1097	.0747	.0895	.0754	.0754		.0189
21	.1097	.0187	.0732	.0189	.0655	.0739	.0189
22	.0914	.0739	.0686	.0189	.0693	.0924	.0189
23	.0914	.0187	.0678	.0187	.0171	.0183	.0189
24	.6173		.0732	.0625	.0189	.0171	.0183
Max	1.0117	.1619	.2378	.3641	.2105	.2058	.1844
Min	.0732	.0152	.0164	.0141	.0171	.017	.0181
Avg	.3890	.0379	.0959	.1268	.0633	.0810	.0528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 205 / 11 KV Kuratnwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0183		.017	.0991		.0975
2	.0189		.0171	.0991		.0975
3	.0185		.0171	.0991		.0975
4	.0183		.0168	.0894		.1128
5	.0183		.0168	.0894		.1128
6	.0732		.0168	.1183		.12
7	.0732		.0678	.1315		.1063
8			.0829	.2397		.1219
9	.1829		.1029	.1882		.1219
10	.6882		.7209	.0181		.0183
11	1.2346		1.0486	.0587		.0181
12	1.3717	1.2071	1.0562	.0168		.0166
13	1.3108	1.2209	.8025	.0162		.0152
14	1.3077	1.3169	.7042	.0181	.0185	.0156
15	1.1469	1.2894		.0181	.0185	.016
16	1.1469	1.3032		.0185	.0185	.017
17	.6554	1.0974		.0191	.0185	.0168
18		.0191	.0137		.0185	.0166
19		.0191	.0168		.0185	.0179
20		.0183	.0183			.0177
21		.0187	.0166		.0185	.0175
22		.0191	.0164		.0185	.0189
23		.0191	.0168		.0183	.0168
24	.0183		.0189	.084		.0827
Max	1.3717	1.3169	1.0562	.2397	.0185	.1219
Min	.0183	.0183	.0137	.0162	.0183	.0152
Avg	.5472	.6290	.2288	.0790	.0185	.0546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 206 / 11 KV Adkur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9503	.0572	.3018	.019	.0189	.0185	.0185
2	.9503	.0556	.2987	.0189	.0189	.0185	.0183
3	1.0159	.0556	.2926	.0189	.0189	.0185	.0183
4	1.065	.0556	.2957	.0187	.0189	.0185	.0183
5	1.1469	.0556	.3734	.0187	.0187	.0185	.0183
6		.0556	.4115	.0189	.0758	.0185	.0183
7	1.1961	.0556	.4801	.0187	.0943	.0185	.0183
8	1.278	.0572	.5609	.0189	.0191	.0181	.0183
9	1.1797	.0579	.5853	.0189	.0191	.0185	.0189
10	.0732	.0183	.0189	.141	.1113	.0819	.0869
11	.0732	.0189	.0189		2.1538	.1311	.1391
12	.1097	.0183	.0189		1.829	.1638	.1692
13	.1097	.0183	.0189		1.9022	.1966	.1446
14	.1097				1.9022	.1638	.1235
15	.0924	.0179				.1638	.1113
16	.0924	.0181				.1475	.0974
17		.0181	.0189	.1669	.7644	.1638	.1052
18	.0183	.0183	.0189	.0189	.0183	.0739	.0191
19	.0183	.0189	.0739	.0189	.0171	.0739	.0754
20	.0183	.0191	.0191	.0191	.0171		.0189
21	.0183	.0171	.0189	.0189	.0189	.0739	.0189
22	.0183	.0173	.0189	.0189	.0191	.0185	.0189
23	.0183	.0171	.0191	.0189	.0183	.0185	.0189
24	.9175	.0556	.2987	.0189	.0189	.0185	.0183
Max	1.278	.0579	.5853	.1669	2.1538	.1966	.1692
Min	.0183	.0171	.0189	.0187	.0171	.0181	.0183
Avg	.4759	.0347	.1982	.0339	.4133	.0720	.0555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 208 / 11 KV Chandgad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4251	.3881	.3121	.3772	.3206		.3696
2	.4066	.3696	.3086	.3772	.3018		.3696
3	.3696		.3052	.3361	.2987		.3696
4	.3696	.3696		.3361	.2801		.3696
5	.4108	.3696	.3052	.3772	.2829	.4481	.3696
6	.4481	.4066	.3429	.415	.3361	.5093	.4066
7	.4854	.4805	.4207	.4527	.4338	.4763	.4481
8	.4805	.499	.4115	.4481	.4805	.4572	.4435
9	.567	.7023	.4508	.5487	.5544	.4207	.5041
10	.6838	.6099	.5258	.5304	.7023	.3475	.6161
11	.6838	.7712	.6516	.5729	.7602	.6584	.5544
12	.7762	.7455	.7316	.6219	.695	.6584	.5914
13	.8316	.7455	.6516		.7023	.6653	.5914
14	.5729	.6584	.6584	.6283	.6584		
15	.6653	.5552		.6653		.6584	
16	.7947	.5201	.6154	.5914		.6838	.2254
17	.6653	.5258	.5792	.567	.5201	.6283	.3012
18	.5544	.6173	.4656	.567	.4207	.5729	.5853
19	.5544	.5087	.5249	.5729	.5487	.6099	.6722
20	.6653	.5138	.6099	.6283	.5373		.679
21	.6099	.5144	.5601	.5914	.5258	.5914	.6161
22	.5487	.5201	.4854	.5228	.5487	.499	.5415
23	.4805	.4161	.4527	.415	.5544	.4435	.4527
24	.4251	.4066	.3506	.3772	.3395	.4481	.4066
Max	.8316	.7712	.7316	.6653	.7602	.6838	.679
Min	.3696	.3696	.3052	.3361	.2801	.3475	.2254
Avg	.5614	.5310	.4873	.5009	.4910	.5431	.4765

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 201 / 11 KV VAIJANATH

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0857	.0857	.0914	.0857	.0857	.0857
2	.0857	.0857	.0857	.0914	.0857	.0857	.0857
3	.0857	.0857	.0857	.0914	.0857	.0857	.0857
4	.0857	.0857	.0934	.0914	.0857	.0857	.0857
5	.0857	.0857	.0857	.0914	.0857	.0857	.0857
6		.0857	.0857	.0914	.0857	.0857	.0857
7	.1715	.0857	.0857	.0914	.0857	.0857	.0857
8	.3429	.0857	.0857	.1829	.0857	.0857	.0857
9	.2572	.0857	.0857	.1829	.0857	.0857	.0857
10	.0857	.0857	.0914	.0857	.0857	.0857	.0857
11	.0857		.0914	.0857	.0857	.0857	.0857
12	.0857		.0914	.0857	.0857	.0857	.0857
13	.0857		.0914	.0857	.0857	.0857	.0857
14	.0857	.0857	.0914	.0857	.0857	.0857	.0857
15	.0857	.0857	.0914	.0857	.0857	.0857	
16	.0857	.0857	.0914	.0857	.0857	.0857	.0857
17		.0857	.0914	.0857	.0857	.0857	.0857
18		.0857	.0914	.0857	.0857	.0857	.0857
19	.0857	.0857	.0914	.0857	.0857	.0857	.0857
20	.0857	.0857	.1829	.0857	.0857	.0857	.1715
21	.0857	.0857	.1829	.0857	.0857	.0857	.0857
22	.0857	.0857	.0914	.0857	.0857	.0857	.0857
23	.0857	.0857	.0914	.0857	.0857	.0857	
24	.0857	.0857	.0857	.0914	.0857	.0857	.0857
Max	.3429	.0857	.1829	.1829	.0857	.0857	.1715
Min	.0857	.0857	.0857	.0857	.0857	.0857	.0857
Avg	.1102	.0857	.0970	.0957	.0857	.0857	.0896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 202 / 11 KV HITECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.6001	.6001	.4287	.6001	.6001
2	.6001	.6001	.6859	.5144	.3429	.5144	.6001
3	.6001	.5144	.6001	.5144	.3429	.3429	.6001
4	.6001	.4287	.5144	.5144	.3429	.3429	.6859
5	.6001	.5144	.4287	.4287	.3429	.2572	.7716
6	.6001	.4287	.5144	.4287	.3429	.1715	.8573
7	.6516	.4287	.5144	.4287	.3429	.1715	.7716
8	.8573	.3429	.5144	.3429	.4287	.2572	.6001
9	.8573	.6859	.6001	.3429	.4287	.3429	.6001
10	1.1145	.8573	.8573	.3048	.4287	1.3717	1.0288
11	1.4575	1.1145	1.0288	.3429	.8573	1.2003	1.3717
12	1.286	1.0288	1.2003	.3429	1.1145	1.1145	.8573
13	1.3717	1.1145	1.2003	.3429	.9335	1.2003	1.1145
14	1.6289	1.2003	1.286	.3429	.8573	1.286	1.3717
15	1.5432	1.4575	1.2003		1.286	1.2003	
16	1.7147	1.3717	1.2003		1.2003	1.1145	1.0288
17		1.3717	.8573	.3429	.8573	.7716	.9431
18		.7716	.7716	.4287	.7716	.5144	1.0288
19	.9431	.6859	.6859	.4287	.6859	.5144	.9431
20	1.0288	.6859	.6001	.4287	.5144	.5144	1.1145
21	.8573	.5144	.6859	.4287	.3429	.5144	.7716
22	.6001	.6859	.6859	.4287	.6859	.5144	.7716
23	.5144	.6001	.8573	.4287	.6859	.6001	
24	.6001	.6001	.6859	.6001	.4287	.6001	.6001
Max	1.7147	1.4575	1.286	.6001	1.286	1.3717	1.3717
Min	.5144	.3429	.4287	.3048	.3429	.1715	.6001
Avg	.9376	.7716	.7823	.4230	.6247	.668	.8651



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 203 / 11 KV Angolkar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.0857	.1715	.1715	.0857	.1715	.1715
2	.1715	.0857	.1715	.1715	.0857	.1715	.1715
3	.1715	.0857	.1715	.1715	.0857	.1715	.1715
4	.1715	.0857	.1715	.1715	.0857	.1715	.1715
5	.1715	.0857	.1715	.1715	.0857	.1715	.1715
6	.1715	.0857	.1715	.1715	.1715	.1715	.1715
7	.2058	.0857	.1715	.1715	.1715	.1715	.1715
8	.2058	.0857	.2572	.1715	.2058	.2058	.2572
9	.2572	.1715	.3429	.1715	.3429	.2572	
10	.4287	.2572	.3429	.1715	.3429	.3429	.2572
11	.3429	.3429	.3429	.1715	.5144	.2572	.3429
12	.3429	.3429	.3429	.0857	.4287	.2572	.1715
13	.4287	.3429	.3429	.0857	.2572	.2058	.2572
14	.4287	.2572	.3429	.0857	.2572	.2058	.2572
15	.3429	.3429	.3429	.0857	.3429	.2572	
16	.3429	.4287	.3429	.0857	.4287	.2572	.3429
17		.3429	.3429	.0857	.3429	.2572	.3429
18		.1715	.3429	.1715	.2572	.2572	.3429
19	.0857	.1715	.2572	.1715	.3429	.3429	.2572
20	.0857	.1715	.2058	.1715	.2572	.2572	.2572
21	.0857	.1715	.1715	.1715	.2058	.1715	.1715
22	.1715	.1715	.1715	.1715	.1715	.1715	.1715
23	.0857	.1715	.1715	.0857	.1715	.1715	
24	.1715	.0857	.1715	.1715	.0857	.1715	.1715
Max	.4287	.4287	.3429	.1715	.5144	.3429	.3429
Min	.0857	.0857	.1715	.0857	.0857	.1715	.1715
Avg	.2292	.1929	.2515	.1465	.2386	.2186	.2286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 204 / 11 KV Aqua

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6001	.6001	.724	.6001	.5144	.6001
2	.7716	.6859	.6859	.724	.6001	.5144	.6001
3	.6859	.6001	.5144	.6335	.5144	.6001	.6001
4	.6859	.5144	.6001	.6335	.5144	.6201	.5144
5	.6859	.5144	.5144	.6335	.5144	.6859	.5144
6	.6859	.6001	.6001	.6335	.5144	.6001	.6001
7	.6859	.6001	.6859	.6335	.5144	.6001	.6001
8	.5144	.7468	.6859	.724	.5144	.6001	.6859
9	.5144	.7716	.6001	.6335	.6859	.6859	.8573
10	.5144	.8573	.724	.6859	.6001	.6859	.7716
11	.5144	.6859	.724	.7716	.6001	.6859	.8573
12	.5144	.6001	.724	.6859	.5144	.6001	.8573
13	.4287	.7716	.8145	.6859	.5144	.6859	.6859
14	.4287	.6859	.905	.0857	.5144	.6859	.9431
15	.5144	.7716	.905		.6001	.6001	
16	.4287	.6859	.8145			.6001	.7716
17		.7716	.724	.0857	.6859	.6001	.6859
18		.6001	.724	.4287	.3429	.6001	.6859
19	.5144	.6859	.724	.5144	.6001	.6859	.8573
20		.6859	.8145	.6001	.6001	.6001	.9431
21	.6001	.6859	.724	.5144	.6001	.6001	.6859
22	.6859	.6859	.724	.6001	.6001	.6001	.9431
23	.6001	.7716	.724	.6001	.6001	.5144	
24	.6859	.6859	.6859	.724	.5144	.5144	.6001
Max	.7716	.8573	.905	.7716	.6859	.6859	.9431
Min	.4287	.5144	.5144	.0857	.3429	.5144	.5144
Avg	.5920	.6777	.7059	.5889	.5591	.6117	.7209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 201 / 11 KV AMROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1772	.1663	.1867		.1052	.1478	.1494
2	.1753	.168	.1494		.1052	.1494	.1494
3	.1402	.1494	.1494		.1052	.1494	.1494
4	.1417	.1478	.1494		.1052	.1494	.168
5	.1753	.1848	.1867		.1402	.1478	.1867
6	.2103	.2241	.2241		.1753	.168	.1867
7	.2454	.2801	.2614	.0895	.2279	.2427	.2241
8	.3155	.2218	.2614	.1612	.2629	.2587	.2241
9	.3506	.2987	.3734	.3761		.2587	.2987
10	.3506	.3734	.2614	.298		.2033	.2987
11		.2987	.2328	.2629		.1867	.2987
12	.2427	.2241	.197	.2126	.2054	.1867	.2686
13		.2241	.197	.2629	.1848	.1867	.2507
14			.1791	.2454		.1867	
15	.2241	.1867	.1991	.2279		.1494	
16		.1867	.2149	.2103		.1494	.2149
17		.1867	.2328	.2126		.1494	.2686
18		.2987	.2865	.2896		.1867	.3045
19		.3734		.4207		.3734	.4835
20	.4854	.4481	.5194	.443	.5304	.4854	.5014
21	.3921	.4108	.4477	.3544		.4481	.394
22	.2987	.3361	.2865	.2481	.3696	.4108	.2686
23	.2218	.2241	.2149	.1753	.2218	.2241	.197
24	.2103	.1867	.1867		.1402	.1663	.1867
Max	.4854	.4481	.5194	.443	.5304	.4854	.5014
Min	.1402	.1478	.1494	.0895	.1052	.1478	.1494
Avg	.2563	.2521	.2434	.2641	.2057	.2235	.2578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 202 / 11 KV BONJURDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2686	.3155	.1402	.0848
2				.2865	.3155	.1433	.1017
3				.3224	.3155	.1402	.1017
4				.3224	.333	.1402	.1017
5				.3045	.3856	.1402	.0848
6				.3224	.4207	.1791	.1526
7				.3403	.4382	.1753	.1865
8				.4298	.4961	.197	.1526
9				.5014		.1753	.1526
11		.7459	.8059				
12	1.3763	1.1934	.8954				
13		1.2431	.9492				
14		1.1603	.985				
15	1.4419	1.0608	1.1104				
16		1.0774					
17		.8453					
24				.2507	.333	.1402	.0848
Max	1.4419	1.2431	1.1104	.5014	.4961	.197	.1865
Min	1.3763	.7459	.8059	.2507	.3155	.1402	.0848
Avg	1.4091	1.0466	.9492	.3349	.3726	.1571	.1204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 204 / Adkur Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1227	.128	.1307	.1075	.1052	.0905	.112
2	.1227	.1267	.1307	.1075	.1052	.0914	.0934
3	.124	.1097	.112	.0905	.1052	.0905	.0934
4	.1402	.1097	.112	.0895	.1227	.1097	.112
5	.1578	.128	.1494	.0895	.1402	.1086	.1307
6	.1753	.128	.1867	.1433	.1753	.128	.1867
7	.1928	.1448	.1867	.197	.1928	.1646	.2241
8	.2103	.2195	.2241	.2149	.1753	.1448	.1867
9	.2103	.2195	.1867	.2328		.2012	.1867
10	.2279	.1867	.2241	.2103		.181	.1867
11		.2241	.2149	.1753		.1867	.1867
12	.1829	.1867	.197	.1753	.2012	.1867	.1791
13		.1867	.197	.1578	.1829	.1867	.1791
14		.1867	.197	.1753		.1494	.1791
15	.2195	.1867	.2149	.1753		.1494	.1629
16		.1867	.2149	.1578		.1867	.1433
17		.1867	.2149	.1402	.2033	.1867	.1791
18		.2241	.2149	.2103		.1867	.197
19		.2241	.2865	.2454		.2241	.2686
20	.3109	.2987	.3403	.2303	.2353	.2614	.3224
21	.2926	.2614	.3045	.2103		.2241	.2328
22	.2195	.2241	.2328	.1753	.1629	.1867	.1791
23	.1646	.1867	.1612	.1402	.1097	.1494	.1254
24	.1402	.1463	.1494	.1433	.1227	.1097	.112
Max	.3109	.2987	.3403	.2454	.2353	.2614	.3224
Min	.1227	.1097	.112	.0895	.1052	.0905	.0934
Avg	.1891	.1838	.1993	.1665	.1560	.1619	.1733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 205 / Satavane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2795	.4024	.2614				
2	1.2795	.3978	.2486				
3	1.2795	.3978	.2543				
4	1.3321	.4359	.2374				
5	1.4373	.4694					
6	1.6126	.503					
7	1.8404	.7377					
8	1.7878	.852					
9	1.8229	.9175					
10				.3856		.2804	.1017
11				.5434		.3391	.4239
12				.6836		.3688	.5014
13				.7186	.5243	.373	.4656
14				.7011		.3647	.4298
15				.7011		.2652	.3582
16				.6836		.2652	.2507
17				.5434	.4115	.3391	.1791
24	1.2269	.3688	.2155				
Max	1.8404	.9175	.2614	.7186	.5243	.373	.5014
Min	1.2269	.3688	.2155	.3856	.4115	.2652	.1017
Avg	1.4899	.5482	.2434	.6201	.4679	.3244	.3388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 201 / 11 KV Kurani Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
9		.2987
24	.2422	
Max	.2422	.2987
Min	.2422	.2987
Avg	.2422	.2987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 202 / Bijur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.941
Max	.941
Min	.941
Avg	.941



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 203 / Pundra AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0189
Max	.0189
Min	.0189
Avg	.0189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP NON SHEDDABLE EXPRESS HV FEEDERS

Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	.8779	.7373	.6722	.8779		1.0288
2	1.1203	1.0082	.6344	.8962	.9328		.9431
3	1.0269	1.1016	.6687	.9335	.7133		.8573
4	1.0642	.961	.7716	.9522	.7682		.7202
5	.9709	.1083	.7545	.7842	.8596		.8402
6	1.0498	.8589	.9088	.9335	.9511		.9259
7	1.0082	1.0719	1.0425	.9335	.8779		1.0288
8	1.0642	.8131	.9088	.6722	.6767		.7545
9	1.1016	.8962	.9431	.9522	.9511		1.046
10	.8029	1.0608	1.0117	1.0082	.9328		1.0631
11	.8215	.8402	.703	.7095	.7207		.7716
12	1.1458	.7373	1.0456	.9709	.9511	.9431	1.1203
13	.9231	.823	.6908	.8316	.9055	.703	.9425
14	.8676	1.0117	.7842	.7095	.9522	.9431	.9694
15	1.0164	.7545	1.0456	.9335	.9877	.9945	1.1273
16	.7865	.7202	.9149	.6722		.6859	.8131
17	.8589	1.046	1.0082	.7682		.7888	1.1016
18	1.0456	.7716	.9709	.8962		.9945	.8589
19	.7602	.9088	.7468	.7095	.0373	.7373	1.0974
20	.8131	.8402	1.0082	.9522	.6653	.9259	.9231
21	***	.7202	.9335	.9431	.8871	1.0631	.823
22	.7164	.9945	.6908	.695	.9149	.7373	1.0642
23	.7655	.9774	.9335	.9694	.6838	.9945	.8686
24	1.1389	1.0456	.7202	.9149	.8413		1.0974
Max	10.7187	1.1016	1.0456	1.0082	.9877	1.0631	1.1273
Min	.7164	.1083	.6344	.6722	.0373	.6859	.7202
Avg	1.3613	.8729	.8574	.8506	.8137	.8759	.9494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 202 / 11 KV Turkewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2241	.1715	.1629	.1829		.1715
2	.2054	.2218	.1543	.1646	.1646		.1543
3	.2012	.1848	.1372	.1629	.1646		.1543
4	.2241	.1848	.1372	.1646	.1646		.1543
5	.2427	.1867	.1715	.1829	.1829		.1715
6	.2614	.2195	.2058	.2195	.2378		.2229
7	.2801	.2987	.2572	.2743	.2743		.2743
8	.3361	.2896	.2743	.2561	.3658		.2915
9	.5415	.4066	.3772	.567	.5487		.583
10	.5601	.6219	.3429	.7421	.5853		.5144
11	.6722	.6348	.4458	.5415	.5975		
12	.7842	.5487	.3658	.6535	.8131	.5144	.5487
13	.6219	.4801	.3475	.5975	.6154	.583	.6348
14	.5228	.4115	.3658	.3961	.679	.6173	.3881
15	.5975	.4801	.5068	.3475	.6722	.5144	.439
16	.7023	.4458	.6154	.3547	.4435	.6001	.5544
17	.6653	.4115	.5068	.3174	.4481	.5144	.5281
18	.5121	.3772	.4706	.2801	.2587	.3429	.4066
19	.2926	.3601	.3292	.3361	.2957	.3258	.3361
20	.4024	.3772	.3801	.362	.4024	.3601	.4066
21	.362	.3429	.3439	.3292	.3361	.3086	.4066
22	.3326	.2743	.2896	.2926	.2926	.2743	.2865
23	.2241	.2401	.2353	.2241	.2195	.2058	.2218
24	.2241	.2218	.2058	.1991	.1829		.1886
Max	.7842	.6348	.6154	.7421	.8131	.6173	.6348
Min	.2012	.1848	.1372	.1629	.1646	.2058	.1543
Avg	.4156	.3519	.3182	.3387	.3803	.4301	.3495

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 203 / Megha Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.1109	.0686	.0754	.0183		.0343
2	.0187	.0732	.1029	.0566	.0183		.0343
3	.0366	.1294	.0857	.0377	.0183		.0171
4	.0187	.112	.0686	.0189	.0183		.0514
5	.0373	.1478	.0857	.0189	.0183		.0171
6	.0187	.1646	.1029	.0189	.0183		.0343
7	.0373	.1494	.12	.0189	.0366		.0171
8	.056	.1478	.12	.0189	.128		.0514
9	.0366	.1109	.1543	.0189	.128		.0343
10	.112	.2075	.3086	.0189	.2926		.12
11	.0732	.2587	.3086	.0183	.2926		.1029
12	.0934	.2229	.2452	.0187	.168	.1029	.1494
13	.037	.1715	.1509	.0187	.128	.0343	.0537
14	.0914	.2401	.3206	.0181	2.4579	.1715	.0924
15	.1132	.2058	.2452	.0187	.1663	.0686	.1307
16	.0895	.2229	.3395	.0187	.2614	.1886	.112
17	.1097	.2058	.3395	.0187	.2195	.0514	.0739
18	.037	.1372	.132	.0187	.1307	.0343	.0554
19	.0187	.12	.1132	.0187	.1478	.0171	.0362
20	.0185	.12	.0943	.0183	.0554	.0171	.1307
21	.0187	.1543	.1509	.0183	.0362	.0343	.1478
22	.0185	.0857	.1132	.0183	.1109	.0171	.1086
23	.0185	.1029	.0943	.0183	.0739	.0343	.9896
24	.0187	.0181	.0857	.1132	.0183		.0171
Max	.1132	.2587	.3395	.1132	2.4579	.1886	.9896
Min	.0185	.0181	.0686	.0181	.0183	.0171	.0171
Avg	.0478	.1508	.1646	.0273	.2067	.0643	.1088

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 201 / Parle Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2218	.2534	.2149		.2149	.2195
2	.2126	.181	.2149	.1791		.1772	.1791
3	.1829	.1494	.181	.181		.1753	.1829
4	.1867	.1829	.1772	.2149		.1463	.2241
5	.2218	.2218	.2195	.2126		.2149	.2587
6	.2865	.2865	.3258	.2835		.2896	.2987
7	.3544	.3898	.4207	.3506		.3856	.3224
8	.4115	.4508	.2561	.407		.4115	.3189
9	.4458	.4115	.4801	.4973		.4409	.3121
10	.4161	.3772	.431	.3481		.431	.3353
11	.3277	.3772	.426	.3315		.3429	.3277
12	.3052	.3772	.4161			.3429	.2949
13	.3086	.3944	.3239			.298	.2949
14	.3429	.3772	.2241			.3258	.2374
15	.3521	.2743	.2267			.3086	.2149
16	.3932	.3688	.192			.3086	.2241
17	.4656	.4024	.3841			.2572	.2347
18	.4961	.4024	.3887		.5373	.3086	
19	.5601	.6024	.5373		.6733	.4854	.5068
20	.5914	.5544	.5121		.6516	.5175	.5487
21	.4706	.6348	.5175		.543	.5281	.5068
22	.439	.415	.362		.5175	.4481	.4409
23	.2987	.2987	.2865		.3658	.3361	.2561
24	.2614	.2241		.2172		.2172	.2587
Max	.5914	.6348	.5373	.4973	.6733	.5281	.5487
Min	.1829	.1494	.1772	.1791	.3658	.1463	.1791
Avg	.3563	.3573	.3372	.2865	.5481	.3297	.3043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 202 / Here Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.2294	.1524	.0305		.0164	.0154
2	.3932	.2622	.1829	.0305		.0152	.0154
3	.4588	.2949	.1806	.0305		.0164	.0154
4	.5898	.3391	.2134	.0305		.0164	.0154
5	.5898	.3605	.2107	.0305		.0164	
6	.6554	.3932	.2743	.0305		.0164	.0154
7	.6882	.426	.301	.0305		.0164	.0154
8	.5243	.4915	.3913	.0305		.0164	.0154
9	.5243	.4475	.3612	.0305		.0164	.0154
10	.0164	.0335	.0301	.1718		.0164	.2347
11	.0164	.0335	.0301	.2294		.1989	.1524
12	.0154	.0335	.0151			.2321	.1524
13	.0154	.0335	.0151			.2012	.1524
14	.0154	.0335	.0151			.0514	.1204
15	.0154	.0335	.0151			.0503	.0903
16	.0154	.0343	.0151			.0335	.2408
17	.0164	.0343	.0151			.1677	.3612
18	.0164	.0343	.0305			.0343	.2641
19	.0164	.0152	.0305		.0164	.0347	.0293
20	.0164	.0305	.0305		.0164	.0152	
21	.0164	.0305	.0305		.0164	.0152	.0147
22	.0164	.0309	.0305		.0164	.0309	.0147
23	.0164	.0309	.0305		.0164	.0154	.0147
24	.2622	.2294	.1524	.0305		.0164	.0154
Max	.6882	.4915	.3913	.2294	.0164	.2321	.3612
Min	.0154	.0152	.0151	.0305	.0164	.0152	.0147
Avg	.2183	.1632	.1148	.0589	.0164	.0525	.0900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 203 / Patane ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0377	.0362	.1524		.096	.0732
2	.0175	.0373	.0366	.1543		.0926	.0716
3	.0187		.0362	.1966		.0633	.0724
4	.0189	.0377	.0358	.1966		.0625	.0716
5	.0191	.0362	.0362	.1829		.1017	.0724
6	.0187	.0377	.0366	.2134		.0655	.0724
7	.0189	.0343	.0373	.2294		.064	.064
8	.0183	.0373	.0189	.2241		.1311	.064
9	.0191	.0366	.0162	.2321		.096	.0972
10	.57	.7042	.6882	.0331		.0175	.0191
11	.9835	.9892	.8002	.0335		.0171	.0152
12	1.0174	1.0288	.8322			.0183	.0175
13	1.0174	1.046	.8002			.0179	.0185
14	1.0059	1.046	.7042			.0168	.0171
15	.8962	1.0802	.4161			.0168	.0166
16	.8421	.9474	.3391			.0168	.0168
17	.8817	.8048	.2812			.0166	.0185
18	.0381	.0343	.0362		.0179	.0335	.0181
19	.0377	.0189	.0377		.0187	.0347	.0185
20	.0381	.0381	.0183		.0189	.0175	.0362
21	.0377	.0381	.0181		.0173	.0185	.0179
22	.0373	.0377	.0179		.0179	.0181	.0175
23	.0373	.037	.0177		.0183	.0183	.017
24	.0152	.0362	.037	.1562		.0617	.0724
Max	1.0174	1.0802	.8322	.2321	.0189	.1311	.0972
Min	.0152	.0189	.0162	.0331	.0173	.0166	.0152
Avg	.3176	.3557	.2223	.1671	.0182	.0464	.0415

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 201 / 11 KV Mangao VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1109	.0732	.1075	.0934	.0732	.0724
2	.1109	.0934	.0724	.1075	.0747	.0732	.0554
3	.0924	.0934	.0709	.0895	.0739	.0554	.0747
4	.0934	.112	.0537	.0905	.0739	.0554	.0549
5	.1463	.1109	.1294	.1086	.0924	.0732	.1086
6	.1478	.1109	.1307	.1086	.1109	.0747	.1227
7	.1463	.1448	.128	.128	.1294	.0934	.1433
8	.1595	.1543	.1734	.1578	.1612	.1417	.1417
9	.1907	.1715	.1865	.1696	.1753	.1526	.156
10	.1844	.1886	.1907	.0701	.1865	.1677	.1543
11	.1715	.1715		.156	.1696	.1658	.1526
12	.1595	.1402		.124	.1372	.1063	.1357
13	.1017	.1696		.0905	.1526	.1492	.12
14	.1907	.1417	.1612	.0876	.1543	.1017	.0857
15	.1543	.1433	.124	.1086	.1372	.1029	
16	.1658	.1387	.124	.1595		.0995	.1029
17	.156	.1543	.1612	.1387	.1509	.12	.156
18	.2035	.1612	.1417	.1387	.1526	.1341	.1578
19	.2481	.2353	.1991	.2303	.1907	.2303	.1991
20	.2507	.2353	.2328	.2172	.2172	.2686	.2149
21	.2353	.2218	.2149	.2033	.1829	.2218	.2149
22	.2033	.1848	.197	.1663	.1463	.1646	.1612
23	.1646	.1478	.124	.112	.0934	.1294	.1086
24	.1307	.1294	.1307	.1075	.112	.0934	.128
Max	.2507	.2353	.2328	.2303	.2172	.2686	.2149
Min	.0924	.0934	.0537	.0701	.0739	.0554	.0549
Avg	.1641	.1527	.1438	.1324	.1378	.1270	.1314



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 202 / 11 KV Vargao AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0189	.0183	.048	.08	.0492	.0463
2	.0187	.0189	.0181	.032	.0633	.0328	.0316
3	.0179	.0189	.0179	.032	.0474	.032	.0312
4	.0183	.0187	.0187	.0316	.0474	.0324	.0486
5	.0181	.0187	.0185	.0474	.048	.048	.0332
6	.0181	.0181	.0181	.0474	.064	.0328	.0492
7	.0377	.0185	.0183	.0469	.208	.0162	.064
8	.0377	.0181	.0187	.0762	.3125	.048	.0791
9	.0187	.0185	.0377	.1189	.2968	.032	.081
10	.2214	.3277	.0156	.0181	.0185	.0175	.0185
11	.9282	.7042	.4687	.0185	.0147	.0162	.0177
12	.6401	.6401	.4938	.0189	.0179	.0168	.0179
13	.6167	.4374	.3161	.017	.0181	.0185	.0179
14	.4481	.3479		.0179	.0181	.0166	.0179
15	.3163	.3125	.3125	.0166	.0187	.0168	.0179
16	.2559	.2846	.0324	.0171		.0179	.0179
17	.1981	.25	.0324	.0158	.0187	.0181	.0179
18	.0187	.0183	.0189	.0183	.0187	.0191	.0181
19	.0187	.0181	.0191	.0187	.0189	.0187	.0183
20	.0189	.0183	.0191	.0187	.0189	.0189	.0185
21	.0187	.0181	.0191	.0187	.0189	.0189	.0187
22	.0187	.0183	.0191	.0187	.0187	.0185	.0189
23	.0187	.0181	.0191	.0187	.0185	.0185	.0189
24	.0373	.0187	.0179	.0474	.1147	.0328	.032
Max	.9282	.7042	.4938	.1189	.3125	.0492	.081
Min	.0179	.0181	.0156	.0158	.0147	.0162	.0177
Avg	.1665	.1500	.0864	.0325	.0661	.0253	.0313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 203 / 11 KV Lakkikate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3277	.104	.0781	.0377	.0189	.0189	.0189
2	.3201	.104	.0648	.0377	.0189	.0189	.0191
3	.2721	.1027	.0463	.0377	.0189	.0189	.0185
4	.2591	.1027	.0633	.0377	.0189	.0189	.0187
5	.2949	.1027	.112	.0377	.0189	.0187	.0189
6	.2949	.1027	.1296	.0377	.0189	.0187	.0191
7	.426	.2343	.1423	.0377	.0189	.0187	.0191
8	.5138	.3401	.2561	.0189	.0189	.0189	.0187
9	.57	.3887	.2561	.0377	.0189	.0189	.0189
10	.0189	.0189	.0189	.1389	.0678	.0724	.0412
11	.0189			.3201	.2591	.0579	.0372
12	.0187	.0189		.3563	.2688	.0263	.0372
13	.0189	.0191		.4049	.2812	.0377	.0248
14	.0187	.0189	.0189	.3361	.2812	.0533	.0248
15	.0189	.0189	.0189	.2915	.1981	.0526	.0305
16	.0168	.0191	.0189	.3239		.0495	
17	.0189	.0191	.0189	.2688	.125	.0533	.0312
18	.0187	.0191	.0189	.0187	.0189	.029	.0324
19	.0377	.0377	.0189	.0377	.0187	.0189	.0187
20	.0377	.0191	.0189	.0377	.0189	.0189	.0189
21	.0566	.0381	.0377	.0377	.0189	.0189	.0189
22	.0377	.0377	.0377	.0189	.0189	.0189	.0189
23	.0377	.0191	.0377	.0377	.0189	.0189	.0189
24	.3441	.104	.1067	.0377	.0189	.0189	.0187
Max	.57	.3887	.2561	.4049	.2812	.0724	.0412
Min	.0168	.0189	.0189	.0187	.0187	.0187	.0185
Avg	.1666	.0865	.0724	.1245	.0775	.0298	.0236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144120 / 33/11 KV Tudiye

Feeder No / Name : 201 / 11 KV Tudiye VG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4031	.3601	.3292	.3018	.2829	.208	.2263
2	.3641	.333	.3174	.3018	.2641		.2263
3	.3429	.3224	.2957	.2829	.2641		.2858
4	.373	.3109	.2926	.3018	.3395		.2858
5	.4024	.3429	.2804	.3018	.3772		.3206
6	.5256	.381	.2743	.3961	.415		.3395
7	.8848	.5228	.5281	.5281	.5093		.4854
8	1.2323	.6201	.3898	.6099	.5792		.5544
9	1.3763	.6588	.6706	.6283	.5611		.4557
10		.5847	.7011	.5853	.3898	.3898	.4973
11	.57	.6485	.6661			.4207	.4656
12	.9221		.6036		.5544	.4805	.4733
13	1.1633	.5493	.57		.6068	.439	.4298
14	.9389	.5068	.5083		.4251	.394	.3155
15	1.3763		.4252	***	.4508	.362	.218
16	1.4255	.2126	.4706	.4435		.4075	.1677
17	.9892	.3391	.4784	.499	.2515	.3761	.2012
18		.443	.5194		.3395	.4854	.2947
19	.5853	.567	.4908	.5658	.3696	.5658	.4207
20	.6036	.6036	.6413	.5847	.4294	.6036	.5359
21	.5243	.5658	.547	.5281	.3881	.5658	.4298
22	.4527	.4715	.5281	.415	.3121	.5228	.3506
23	.3768	.3772	.3584	.3395	.2515	.4108	.2865
24	.4031	.3688	.3547	.3206	.3206	.2401	.2641
Max	1.4255	.6588	.7011	11.374	.6068	.6036	.5544
Min	.3429	.2126	.2743	.2829	.2515	.208	.1677
Avg	.7380	.4586	.4684	1.0162	.3946	.4295	.3554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 401 / Aqua NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.3961
Max	.3961
Min	.3961
Avg	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 407 / 33 KV KEMPLAST

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2172
Max	.2172
Min	.2172
Avg	.2172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 805 / Hemrus NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 220 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.2896
Max	.2896
Min	.2896
Avg	.2896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 201 / 11 KV GADHINGLAJ

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.2071	1.0974	1.0974	.9145	.9511	.9511
2	1.1706	1.2071	1.0974	1.0974	.8779	.9145	.9145
3	1.0974	1.2071	1.0608	1.0608	.8413	.9145	.9145
4	1.0974	1.2071	1.0608	1.0608	.8413	.9145	.9145
5	1.0974	1.134	1.0608	1.0608	.8779	.9328	.9511
6	1.1706	1.134	1.0974	1.0974	.9877	.9877	.9877
7	1.2071	1.1706	1.134	1.134	1.0974	1.134	1.0608
8	1.2437	1.2071	1.1706	1.134	1.2071	1.2071	
9	1.262	1.3169	1.134	1.1218	1.2437	1.134	1.2071
10	1.448	1.3535	1.2437	1.1584	1.3717	1.2437	1.2803
11	1.4632	1.4632	1.4815	1.2071	1.3169	1.39	1.4266
12	1.4632		1.3717	1.1706	1.3535	1.4266	1.4266
13	1.6461	1.5364	1.3169	1.2437	1.3717	1.3169	1.2071
14	1.5364	1.4266	1.3717	1.2437	1.3169	1.3169	1.2071
15	1.5912	1.4632		1.2437		1.2803	
16	1.2071	1.4815		1.1523	1.1157	1.4632	1.39
17	1.39	1.3169	1.4266	1.134	1.262	1.5364	1.4266
18	1.5729	1.4266	1.6095	1.1706	1.39	1.6095	1.3717
19		1.7193	1.7375	1.4815	1.6095	1.6278	1.5546
20	1.6095	1.7375	1.8107	1.4998	1.6461	1.6461	
21	1.6095	1.5912	1.6095	1.3717	1.4632	1.3535	1.39
22	1.5364	1.4266	1.2803	1.3169	1.3352	1.2071	1.2803
23	1.2071	1.3169	1.1706	1.134	1.1523		1.0608
24	1.2071	1.1706	1.0974	1.134	.9877	.9511	.9877
Max	1.6461	1.7375	1.8107	1.4998	1.6461	1.6461	1.5546
Min	1.0974	1.134	1.0608	1.0608	.8413	.9145	.9145
Avg	1.3480	1.3574	1.2928	1.1886	1.1992	1.2374	1.1862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 204 / 11 KV Uttur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.2195	.2452	.2641	.6401	.3841	.4374
2	.8642	.2195	.2263	.2641	.6081	.3841	.4534
3	.8642	.2195	.2263	.2263	.583	.4161	.4534
4	.8802	.2195	.2452		.5761	.4161	.4534
5	.9602	.2195	.2641	.2263	.6081	.4481	.4858
6	1.1203	.2195	.2829	.2641	.7362	.4481	.5344
7	1.0883	.2926	.3206	.2641	1.0883	.663	.6316
8	1.3443	.2195	.415	.2263	1.2163	.7042	.7125
9	1.1443	.2641	.2641	.3191	.8907	.7125	1.4022
10	.9095	.8259	1.1523	.381	.2641	.3018	.4024
11	1.2929	1.3927	1.1523	.0724	.2641	.1698	.3658
12		1.4575	1.1523	.0876	.2829	.3772	.3658
13	1.278	1.4737	1.1523	.0754	.1509	.3772	.2926
14	1.0254	1.4575	1.4083	.381	.1132	.0754	.2926
15	1.4861	1.3927		.1886		.0943	.2926
16		1.1336		.1698		.0943	.2926
17		1.1888			.1509	.1886	.1886
18	.1829	.2263	.3018	.2263		.2452	.2263
19	.2561	.3206	.3395	.3018		.2641	.3018
20	.2561	.3395	.3395	.3584	.3395	.3206	
21	.2926	.3395	.415	.3395	.3206	.3018	.3018
22	.2926	.3206	.3395	.3018	.2829	.2829	.3018
23	.2561	.2641	.3018	.2263	.2452		.2263
24	.8962	.2561	.2452	.2641	.6478	.3841	.3887
Max	1.4861	1.4737	1.4083	.381	1.2163	.7125	1.4022
Min	.1829	.2195	.2263	.0724	.1132	.0754	.1886
Avg	.8375	.6034	.5138	.2467	.5005	.3502	.4263



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 205 / 11 KV Nool Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.0366	.0566	.0566	.0486		.0648
2	.4858	.0366	.0377	.0566	.0486	.048	.0648
3	.4481	.0366	.0377	.0566	.0486	.032	.0648
4	.4481	.0366	.0377	.0377	.0486	.032	.081
5	.5441	.0366	.0377	.0377	.048	.032	.081
6	.5601	.0366		.0377	.081	.048	.081
7	.6081	.0366	.0377	.0377	.1296	.096	.1134
8	.7362	.0366	.0377	.0377	.16	.096	.1134
9	.7335	.0377	.0566	.0248	.1296	.0983	.0869
10	.639	.5344	.5693	.0362	.0566	.0189	.0366
11	.7727	.7449	.8962	.0362	.0377	.0189	.0183
12	.7625	.7773	.8962		.0377	.0189	.0183
13	.7727	.7773	.8745	.0377	.0377		.0183
14	.8025	.7125	.8002	.0377	.0377		.0183
15	.7876	.6802		.0189			.0183
16	.8173	.664					.0183
17		.7537	.6802			.0189	.0189
18	.0732	.0377	.0754		.0189	.0189	.0189
19	.0732		.0754	.0189	.0377	.0377	.0189
20	.0732	.0566	.0566	.0366	.0377	.0377	
21	.0732	.0566	.0566	.0377	.0189	.0377	.0377
22	.0549	.0377	.0566	.0377	.0377	.0377	.0189
23	.0732	.2641	.0566	.0377	.0377		.0189
24	.4744	.0732	.0566	.0566	.0486	.048	.0486
Max	.8173	.7773	.8962	.0566	.16	.0983	.1134
Min	.0549	.0366	.0377	.0189	.0189	.0189	.0183
Avg	.4910	.2826	.2614	.0388	.0565	.0431	.0469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 207 / 11 KV WATERWORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2195	.3326	.3292	.3018	.3511	.3292
2	.2075	.1463	.2957	.2926	.2263	.3511	.3292
3	.2075	.1463	.2587	.2561	.2263	.3326	.2926
4	.2075	.1463	.2587	.2195	.2263	.3326	.2926
5	.2075	.1463	.2402	.2195	.2263	.2957	.2743
6	.2378	.1829	.2402	.2195	.2263	.2218	.2561
7	.2452	.2378	.2587	.2012	.2452	.2452	.2378
8	.2829	.2926	.2772	.2561	.3018	.3206	.2378
9	.4251	.3292	.415	.4344	.3292	.3772	.4024
10	.4066	.3475	.3772	.3801	.3292	.3772	.4024
11	.2772	.3109	.3395	.2772	.2561		.3292
12	.3326	.2926	.3018	.3142	.1829		.3292
13	.2957	.2926	.3018	.3584	.0549	.3206	.2926
14	.2957	.2561	.2829	.2452	.0366	.2641	.2926
15	.1663	.2561	.2195	.2263		.2263	.2926
16	.3142	.2195		.2452	.0183	.2452	.2561
17	.2195	.2402	.2195	.2641	.1663	.2195	.2452
18	.2378	.2402	.2561	.2263	.132	.2195	.2263
19		.1848	.2012	.1886		.2195	.2263
20	.2561	.3142	.2012	.2075		.2561	
21	.2926	.1663	.1829	.2829	.2075	.2926	.2452
22	.3292	.3142	.2561	.3206	.3961	.3841	.3584
23	.3292	.3326	.3658	.3584	.2772		.3584
24	.2829	.2926	.3511	.3658	.3395	.3511	.3658
Max	.4251	.3475	.415	.4344	.3961	.3841	.4024
Min	.1663	.1463	.1829	.1886	.0183	.2195	.2263
Avg	.2732	.2462	.2797	.2787	.2241	.2954	.2988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 210 / 11 KV Uttur VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.3658	.3658	.3658	.3258	.2926	.3292
2	.4024	.3658	.3658	.3292	.3292	.2926	.3292
3	.3982	.3292	.3292	.3658	.3292	.2507	.2926
4	.4024	.3292	.3292	.3292	.3292	.2865	.2926
5	.4024	.3292	.4024	.3292	.3658	.2865	.3292
6	.4207	.3658	.4024	.3841	.4024	.3292	.3658
7	.4572	.4024	.3841	.4024	.4024	.3658	.3658
8	.439	.4024	.3475	.439	.439	.3109	.3658
9	.4525	.3658	.4344	.4733	.4207	.4706	.439
10	.4344	.3475	.4024	.4075	.4207	.3841	.4024
11	.4298	.3658	.4024	.3475	.4024	.4207	.439
12		.3658	.439	.3292	.4207	.3292	.439
13	.4207	.3658	.4572	.4024	.3841	.3109	.3292
14	.4525	.3475	.4755	.3658	.3658	.3292	.2926
15	.5068	.3292		.3841		.3292	.2926
16	.4207	.3841		.2926	.3475	.3292	.439
17	.4024	.3982	.4024	.3292	.439	.3841	.4207
18	.3658	.4755	.4572	.3658		.439	.3658
19	.4024	.5249	.5487	.5487		.5121	.4572
20	.6219	.5601	.5487	.5853	.5853	.5487	
21	.5853	.5601	.567	.5121	.567	.5121	.4755
22	.5121	.4706	.4755	.4755	.4755	.4755	.439
23	.439	.4163	.4207	.4024	.3658		.3292
24	.4344	.3841	.3658	.4024	.3292	.2926	.3658
Max	.6219	.5601	.567	.5853	.5853	.5487	.4755
Min	.3658	.3292	.3292	.2926	.3258	.2507	.2926
Avg	.4453	.3980	.4238	.3987	.4022	.3688	.3737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 211 / 11KV Belbag

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8413	.8413	.811	.7316	.7133	.7545
2	.8779	.8413	.8048	.811	.695	.695	.7167
3	.8779	.8413	.8048	.8299	.695	.695	.7167
4	.8779	.8413	.8048	.8299	.695	.7133	.7167
5	.9145	.8048	.8413	.8676	.695	.7316	.7922
6	.8779	.8048	.8596	.9054	.7316	.7316	.8299
7	.8779	.8048	.823	.9054	.7682	.8596	.8865
8	.8779	.7682	.8413	.8676	.7316	.8413	.8488
9	.9593	.7922	.8779	.7362	.8488	.8596	.8413
10	.9955	.8299	.9145	.724	.8676	.8413	.8779
11	1.1641	.8676	.9877	.823	.9431	.9877	1.0242
12	1.1888	1.1317	.9877	.823	1.0562	1.0242	1.0242
13	1.134	1.094	1.0242	.8413	.8779	.9877	.9511
14	1.1523	.9808	.9694	.9145	.7865	.9877	.8779
15	1.1706	.9431		.9145		1.0059	.8779
16	1.134	1.0562	1.0562	.8596		1.0059	.9145
17	1.0242	1.0136	1.1317	.8048		1.094	1.0059
18	1.0974	1.1157	.9808	.7682	1.1706	1.1883	.9511
19	1.2803	1.2127	1.1317	1.1523	1.262	1.226	1.1706
20	1.2437	1.0082	1.094	1.1888	1.2254	1.2826	
21	1.134	1.0679	1.094	1.134	1.0974	1.094	.9877
22	1.0242	1.0242	1.0562	.9511	.9145	.9431	.9511
23	.9511	.9694	.9431	.8779	.823		.8048
24	.9328	.8596	.8413	.8299	.7682	.7133	.8488
Max	1.2803	1.2127	1.1317	1.1888	1.262	1.2826	1.1706
Min	.8779	.7682	.8048	.724	.695	.695	.7167
Avg	1.0284	.9381	.9440	.8821	.8754	.9227	.8857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 201 / 11 Kv Karambali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.2378	.1372	.1829	.5487	.4801	.5121
2	.9145	.2561	.1372	.1829	.6401	.4801	.5121
3	.9145	.2561	.1372	.1829	.6401	.4801	.5121
4	.9145	.2378	.1372	.1829	.6401	.4801	.5121
5	1.0974	.2561	.1372	.2012	.695	.4801	.5304
6	1.0974	.2561	.2229	.2012	.7316	.4801	.5853
7	1.2254	.2378		.2195	.8596	.6001	.695
8	1.4632	.2743	.2229	.2195	.9511	.7202	.8413
9		.2743	.2229	.2195	.4755	.6859	.823
10	1.3535	1.134	.8779	.2195		.0914	.128
11	1.3717	1.4998	1.4632	.1372	.1829	.1463	.1463
12	1.3717	1.5729	1.4449	.12	.1463	.1097	.1463
13	1.4266		1.4083	.128	.1463	.0914	.1463
14	1.3352	1.3535		.1463	.1463	.1097	.0914
15	1.2689	1.3717		.1463	.1097	.1097	.1097
16	1.0631	.9328		.1097	.1097	.1097	.1463
17		1.0791		.1097	.1372	.128	.1463
18	.1463	.1715	.0914	.0914	.1372	.128	.128
19	.2378	.1715	.128	.1829	.1715	.1646	.1463
20	.2743	.1886	.2195	.1829	.2058	.1829	.1646
21	.2561	.1715	.2378	.1646	.1886	.1829	.1829
22	.2561	.1886	.2195	.1646	.1715	.1646	.1646
23	.2743	.2058	.2378	.2012	.1372	.1646	.1646
24	.8779	.2378	.1715	.2012	.5304	.4801	.5121
Max	1.4632	1.5729	1.4632	.2195	.9511	.7202	.8413
Min	.1463	.1715	.0914	.0914	.1097	.0914	.0914
Avg	.9116	.5463	.4134	.1708	.3784	.3021	.3353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 202 / 11 KV Kaulage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2155				.0995	.0171	.0829
2	.2818				.0995	.0171	.0829
3	.2818				.0995	.0171	.0829
4	.2818				.0995	.0171	.0829
5	.3315				.116	.0171	.0829
6	.3315				.116	.0171	.0829
7	.3647				.1326	.0171	.116
8	.4475				.1658	.1029	.1492
9					.1658	.12	.1658
10	.4807	.0995	.1492				
11	.583	.1492	.2155				
12	.583	.1658	.2321				
13	.5801		.2321				
14	.5636						
15	.583	.1989					
16	.4287	.1492					
17		.1326					
23				.0829			.0663
24	.2818				.0829	.0171	.0829
Max	.583	.1989	.2321	.0829	.1658	.12	.1658
Min	.2155	.0995	.1492	.0829	.0829	.0171	.0663
Avg	.4138	.1492	.2072	.0829	.1177	.0360	.0980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 203 / 11 KV Ainapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	1.1469	1.166	.3563	.0648	.0686	.0324
2	.0819	1.1305	1.166	.3563	.0648	.0686	.0324
3	.0819	1.1305	1.166	.3563	.0648	.0686	.0324
4	.0819	1.1305	1.166	.3725	.0648	.0686	.0324
5	.0819	1.1469	1.2003	.3725	.0648	.0686	.0324
6	.0983	1.3108	1.4918	.3725	.0648	.0686	.0324
7	.0983	1.5238	1.869		.0648	.1029	.0324
8	.1475	1.7695	2.0576	.4858	.081	.1029	.0324
9	.1311	1.7859	2.0748	.5344	.081	.1029	.0486
10	.1311	.0819	.1134	.1943	.4049	.4534	.2105
11	.1311	.0972	.081	.2058	.4372	.3887	.2785
12	.1311	.0972	.081	.2058	.4858	.3401	.2949
13	.0655	.0972	.0486	.5079	.4534	.3401	.3113
14	.1147	.0972		.4915	.421	.3563	.2785
15	.1638	.1296		.5079	.3725	.3563	.2949
16	.1311	.1134		.4915	.3563	.2915	.2458
17	.0492				.3772		.3113
18	.0819	.1029		.081	.1029	.0324	.0648
19	.0819	.1029		.0648	.1029	.0324	.0739
20	.0819	.1372		.0648		.0324	
21	.0819	.12	.0648	.0648	.1029	.0324	.0648
22	.0819	.1372		.081	.0857	.0324	.0648
23	.0655	.12	.0648	.0648	.0857	.0324	.0648
24	.1311	1.0814	1.166	.3563	.081	.0686	.0324
Max	.1638	1.7859	2.0748	.5344	.4858	.4534	.3113
Min	.0492	.0819	.0486	.0648	.0648	.0324	.0324
Avg	.1004	.6344	.9361	.2995	.195	.1526	.1260

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.3696	.4115	.2957	.3881	.3086	.3142
2	.4435	.4066	.4115	.2957	.3881	.3086	.3142
3	.4435	.4066	.4115	.2957	.3881	.3086	.3142
4	.4435	.3511	.4115	.3326	.3881	.3086	.3326
5	.499	.4251	.4115	.3511	.3881	.3429	.3696
6	.5175	.4435	.4458	.3696	.4435	.3772	.3881
7	.5359	.4435	.4458	.4066	.4805	.4115	.4805
8	.4805	.462	.4458		.4805	.4458	.4435
9		.5359	.4801	.4066	.4805	.463	.5544
10	.5359	.5175	.3881	.4066	.5175	.3696	.4066
11	.4801	.5729	.6283	.3506	.4572	.5175	.5914
12	.4801	.4435	.5544	.3544		.499	.5175
13	.5175	.4435	.5359	.4066	.4251	.499	.4435
14	.4805	.4435		.3511	.4066	.462	.4066
15	.4973	.5175		.4066	.4066	.4251	.4805
16	.4973	.5359		.4435	.4251	.499	.462
17	.4801	.5359	.462		.4115	.3881	.5175
18	.5175	.4973	.462	.3142	.5144	.499	.4805
19	.6099	.5144	.5544	.5544	.6516	.6653	.5359
20	.6283	.6173	.6099	.6283		.6468	.5359
21	.6283	.5487	.5359	.5544	.583	.6099	.5544
22	.5544	.5487	.4805	.462	.5144	.5175	.5175
23	.499	.4801	.4066	.4066	.3772	.3881	.462
24	.6653	.4435	.4287	.3326	.3881	.3429	.3511
Max	.6653	.6173	.6283	.6283	.6516	.6653	.5914
Min	.4435	.3511	.3881	.2957	.3772	.3086	.3142
Avg	.5181	.4793	.4725	.3966	.4502	.4418	.4489



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 205 / KCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0189	.0191	.0191	.0189	.0191	.0191
2	.0189	.0189	.0191	.0191	.0189	.0191	.0191
3	.0189	.0189	.0191	.0191	.0189	.0191	.0191
4	.0189	.0189	.0191	.0191	.0189	.0191	.0191
5	.0189	.0189	.0191	.0191	.0189	.0191	.0191
6	.0189	.0189	.0191	.0191	.0189	.0191	.0191
7	.0189	.0189	.0191	.0191	.0189	.0191	.0191
8	.0189	.0189	.0191	.0191	.0189	.0191	.0191
9		.0189	.0191	.0191	.0189	.0191	.0191
10	.0189	.0189	.0189	.0191	.0189	.0189	.0191
11	.0191	.0191	.0189	.0191	.0191	.0189	.0189
12	.0191	.0191	.0189	.0191	.0191	.0189	.0189
13	.0189	.0191	.0189	.0189	.0191	.0189	.0189
14	.0189	.0191		.0189	.0191	.0189	.0189
15	.0191	.0191		.0189	.0191	.0189	.0189
16	.0191	.0191		.0189	.0191	.0189	.0189
17	.0191	.0191		.0189	.0191	.0189	.0189
18	.0189	.0191	.0191		.0191	.0191	.0189
19	.0189	.0191	.0191	.0189	.0191	.0191	.0189
20	.0189	.0191	.0191	.0189	.0191	.0191	.0189
21	.0189	.0191	.0191	.0189	.0191	.0191	.0189
22	.0189	.0191	.0191	.0189	.0191	.0191	.0189
23	.0189	.0191	.0191	.0189	.0191	.0191	.0189
24	.0171	.0189	.0191	.0191	.0189	.0191	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0171	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0189	.0190	.0191	.0190	.0190	.0190	.0190

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.4854	.5415	.0934	.0934	.112	.1307
2	.4481	.4668	.4481	.0934	.0747	.056	.1307
3	.3734	.4481	.4108	.0934	.056	.056	.112
4	.056	.3734	.4481	.0934	.056	.056	.112
5	.056	.0747	.4481	.0934	.056	.056	.0747
6	.056	.0747	.2801	.0934	.0373	.056	.056
7	.056	.112	.0934	.1307	.056	.0747	.056
8	.056	.112	.112	.1307	.056	.0747	.056
9	.056	.3547	.112	.0934		.0934	.4108
10	.0934	.4294	.1307	.0934	.056	.4668	.4668
11	.1494	.5041	.2054	.0373	.5228	.1867	.5415
12	.3734	.2054	.1867	.0187	.4668	.1494	.5415
13	.5415	.4668	.1867	.0373	.5041	.1307	.5041
14	.5975	.0934	.0934	.0373	.4294	.056	.4481
15	.5601	.2241	.1867	.0373	.3734	.168	.5415
16	.5415	.2054		.0747	.1494	.2241	
17		.168		.0747	.2241	.168	.1867
18	.3547	.112	.0934	.112	.1867	.0934	.112
19	.0934	.056		.112	.1307	.056	.0934
20	.0934	.0747	.1307	.0747	.112	.0747	.0747
21	.0934	.0934	.1307	.0373	.0747	.0747	.0747
22	.1494	.3547	.112	.0373	.0747	.0747	.0934
23	.4481	.5415	.0934	.112	.0934	.112	.0934
24	.4854	.4854	.5415	.0934	.0934	.1307	.1307
Max	.5975	.5415	.5415	.1307	.5228	.4668	.5415
Min	.056	.056	.0934	.0187	.0373	.056	.056
Avg	.2703	.2715	.2374	.0794	.1729	.1167	.2192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 202 / Shendri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.407	.3521	.0179	.0914	.0554	.0716
2	.0747	.373	.3521	.0179	.0732	.037	.0358
3	.056	.3391	.3521	.0179	.0732	.037	.0358
4	.056	.373	.3688	.0179	.0732	.0554	.0358
5	.0373	.5087	.4024	.0358	.0732	.0739	.0537
6	.056	.5426	.4694	.0358	.0914	.0924	.0895
7	.0934	.9835	.763	.0537	.1097	.1109	.1075
8	.0934	1.0174	.9892	.0716	.1097	.1109	.1075
9	.112	.8987	1.0004	.0716		.0716	.1463
10	.112	.0554	.0747	.0732		.0537	.3222
11	.1109	.056	.0537			.5596	.5426
12	.1109	.0934		.0732		.5426	.5426
13	.0739	.112	.0537	.0914	.7122	.5087	.407
14	.0924	.0747	.0895	.0732	.6443	.4578	.373
15	.0924	.056	.0537	.0732		.4917	.3561
16	.0924	.056		.0732	.373	.5087	.3561
17		.056		.0724	.4239	.5596	.3391
18	.0554	.056	.0358	.0905	.1109	.0537	.0905
19	.0924	.112		.1086	.1294	.1254	.1086
20	.0924	.0934	.0537	.1267	.1478	.0895	.1267
21	.0924	.0747	.0537	.1267	.1109	.0716	.1267
22	.0924	.0747	.0358	.1267	.1109	.0895	.1086
23	.0924	.056	.0358	.1086	.0924	.0895	.0905
24	.0747	.407	.3921	.0179	.0905	.0739	.0716
Max	.112	1.0174	1.0004	.1267	.7122	.5596	.5426
Min	.0373	.0554	.0358	.0179	.0732	.037	.0358
Avg	.0839	.2865	.2991	.0685	.1916	.205	.1936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 201 / Nool Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3506	.3898	.3544	.2835	.3012	.2481	
2	.3429	.3721	.3544	.2835	.2835	.2481	
3	.3429	.3544	.3544	.2835	.2835	.2481	
4	.3467	.3544	.3544	.2835	.2835	.2835	
5	.3391	.3721	.3721	.3012	.3012	.3012	
6	.3429	.4075	.4075	.3012	.3189	.3366	
7	.4031	.3721	.3721		.3898	.3898	.3721
8		.3898	.4075	.3189	.3721	.3898	.3721
9		.4854	.4572	.4477	.4344	.4525	.4706
10			.4908	.394	.5853	.3801	
11	.5258	.5144	.4908	.4572	.6036	.4706	.4525
12	.5895	.5658	.4961	.394	.4733	.3898	.4706
13	.5784	.4801	.5201	.3681	.4733	.3982	.4706
14	.5731	.5068	.4207	.3403		.3761	
15	.5373	.5258		.362		.3801	.3439
16	.362	.4854		.3258	.543	.3982	
17	.4525	.4887	.5068	.362	.5658	.4163	.4904
18	.543	.5068	.5093	.4904	.4527	.543	.4854
19	.5973	.5611	.5281	.6036	.679	.6335	.5847
20	.724	.6154		.7356		.6335	.6036
21	.5847	.5316	.6535	.5281	.5138		.6348
22	.5138	.4784	.5316	.4607	.4252		
23	.4252	.4075	.3721	.3721	.3012		.3048
24	.394	.3898	.3721	.3189	.3189	.2658	
Max	.724	.6154	.6535	.7356	.679	.6335	.6348
Min	.3391	.3544	.3544	.2835	.2835	.2481	.3048
Avg	.4699	.4589	.4441	.3920	.4240	.3897	.4659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 202 / Bhadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0876	1.2125	1.1305	.6062	.0492	.0655	.0492
2	.0914	1.2125	1.1305	.6062	.0492	.0492	.0492
3	.0914	1.1961	1.1305	.6062	.0492	.0492	.0492
4	.0732	1.0322	1.1797	.6226	.0492	.0492	.0492
5	.0724	1.278	1.2452	.6226	.0492	.0492	.0492
6	.1052	1.491	1.3435	.6882	.0492	.0492	.0492
7	.1267	.2949	1.6876		.0819	.0492	.0492
8		2.0317	1.8679	1.0322	.0655	.0492	.0492
9	.1698	1.8564	1.8679	1.065	.0549	.0514	.0905
10	.132	.0953	.1143	.6062	.7499	.4372	
11	.1886	.1143	.1334	.9012	1.3352	.7611	.8907
12	.1698	.1524	.1715	.9069	1.286	.8356	.8583
13	.1509	.1509	.0953	.9878	1.3523	.8259	.8583
14	.1886	.1524	.0572	.9393		.6062	
15	.1698	.1334		.9503		.6478	
16	.1267	.1524	.056	.9282	.5788	.6316	
17	.0905	.1372	.056	.9465	.567	.6964	
18	.1267	.1086	.0566	.056	.0549	.0543	.056
19	.1267	.1448	.056	.0754	.0732	.0905	.0566
20	.1267	.1448		.0943	.0754	.0905	.0943
21	.1311	.1147	.1307	.1494	.0819		.0953
22	.1147	.1147	.0983	.0819	.0655	.0655	.0762
23	.0983	.1147	.0492	.0655	.0492	.0492	.0566
24	.0876	1.1305	.9831	.5735	.0492	.0655	.0492
Max	.1886	2.0317	1.8679	1.065	1.3523	.8356	.8907
Min	.0724	.0953	.0492	.056	.0492	.0492	.0492
Avg	.1238	.6069	.6655	.6135	.3098	.2747	.1882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 203 / Chennikuppi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6783	.0983	.0983	.0983	.5571	.426	.3768
2	.6859	.0819	.0983	.0983	.5571	.426	.3768
3	.7802	.0819	.0983	.0983	.5571	.426	.3768
4	.7888	.0819	.0983	.0983	.639	.4588	.4096
5	.7888	.0983	.0983	.1147	.7209	.4915	.4424
6	.7362	.0983	.1147	.1147	.8848	.5407	.5079
7	1.153	.0983	.1311		1.0814	.6882	.7209
8		.1475	.1311	.1638	1.1797	.8684	.8356
9	1.0311	.1524	.1334	.1334	1.2803	.7773	.9069
10	.5864	.6401	.5851	.1334	.128	.0905	
11	.9488	1.0911	1.012	.0953	.1097	.0905	.9069
12	1.0911	1.1405	.9998	.0943		.1143	.1086
13	1.1385	1.0623	1.0494	.0943	.104	.1143	
14	.9488	.6249	.9998	.0943		.1143	
15	.9488	.9877		.0943		.1086	.0686
16	.9069	.9722	.6348	.0943	.0934	.0857	
17	.7935	.8097	.8488	.0934	.1097	.0905	
18	.0905	.1267	.1132	.132	.1097	.1448	
19	.1267	.1448	.1698	.1509	.1463	.1463	.1132
20	.1448	.1311		.1886	.1886	.1448	.1509
21	.1475	.1311	.1886	.1886	.1311		.1715
22	.1311	.1311	.1311	.1311	.1147	.1147	.132
23	.1147	.1147	.1311	.1147	.1147	.0983	.1132
24		.0983	.0983	.1147	.5407	.4096	.3441
Max	1.153	1.1405	1.0494	.1886	1.2803	.8684	.9069
Min	.0905	.0819	.0983	.0934	.0934	.0857	.0686
Avg	.6709	.3810	.3620	.1189	.4451	.3030	.3924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 204 / Guddai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4424	.5243				
2		.4424	.5243				
3		.426	.5243				
4		.3768	.5571				
5		.4588	.5571				
6		.5243	.6062				
7		.5898	.6882				
8		.6226	.7701				
9	.0886	.6401	.7748			.0678	
10	.0895	.0867	.0701		.2402	.1296	
11		.0895	.0905	.2006	.2829	.1457	
12	.0716	.0876	.1063	.2469	.3258	.125	.1457
13	.0724	.0701	.0886	.2031	.2865	.1433	.2035
14		.0716	.0886	.2315		.1235	.1619
15		.0867		.2187		.1296	.1457
16		.104		.2134		.1372	
17		.0686		.1629		.1781	.1132
19	.061						
20	.0857						
21	.0819						
22	.0655						
23	.0655						
24		.3932	.5243		.1311		
Max	.0895	.6401	.7748	.2469	.3258	.1781	.2035
Min	.061	.0686	.0701	.1629	.1311	.0678	.1132
Avg	.0757	.3101	.4330	.2110	.2533	.1311	.154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 205 / 11 KV JARALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.1311	.1311	.0819	.3768		
2	1.2003	.1311	.1311	.0819	.3768		
3	1.2717	.1311	.1311	.0819	.3768		
4	1.286	.1311	.1311	.0819	.4424		
5	1.3717	.1311	.1311	.0983	.5243		
6	1.1191	.1475	.1475	.0983	.639		
7	1.4413	.1638	.1475		.9012		.4915
8		.1638	.1475	.1311	.9831		.6554
9	1.7604	.1734	.2481	.128	1.0974		.421
10	1.1728		1.1603	.1227	.128		
11	1.8991	1.8945	1.8652	.128	.1097		.3401
12	1.9161	1.9161	1.7238	.1063	.1086		.3239
13	1.8778	1.8313	1.7238	.104	.1052	.5243	.3077
14	1.8313	1.8313	1.6244	.0914		.5243	.2591
15	1.8107	1.7269		.0943		.1372	
16	1.1336	1.7072		.104		.1029	
17		1.5546		.1097	.0914	.1029	.0747
18	.1372	.1357	.1867	.1494	.0732	.1372	.1132
19	.1696	.1696	.1509	.1509	.1097	.1543	.132
20	.1991	.1696		.1698		.1372	.1509
21	.1638	.1638	.1509	.1509			.1509
22	.1638	.1311	.1311	.1311			.132
23	.1311	.1311	.0983	.0655			.1132
24	1.1568	.1311	.1311	.0819	.3605		
Max	1.9161	1.9161	1.8652	.1698	1.0974	.5243	.6554
Min	.1311	.1311	.0983	.0655	.0732	.1029	.0747
Avg	1.1097	.6434	.5146	.1106	.4002	.2275	.2618



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 206 / 11 KV SAMARTHANAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1772	.1417	.1417	.1595	.1417	.1772
2	.181	.1772	.1417	.1417	.1595	.1417	.1595
3	.1629	.1772	.1417	.1417	.1595	.1417	.1595
4	.1612	.1772	.1417	.1417	.1595	.1417	.1595
5	.1791	.1772	.1595	.1417	.1772	.1417	.1595
6	.197	.1949	.1595	.1417	.1772	.1417	.1595
7	.1753	.1595	.1417		.1772	.124	.2303
8		.1595	.1417	.1595	.1772	.124	.1772
9	.2328	.2195	.168	.181	.181	.1509	.181
10	.2279	.2402	.1663	.2561	.1829	.1698	
11	.2572	.2241	.1698	.2103	.1829	.1629	.2075
12	.2534	.2614	.1698	.1886	.181		.3258
13	.2561	.2561	.1886	.1402	.1928	.1463	.2452
14	.2614	.2507	.1524	.1494		.1524	.2172
15	.2452	.2804		.1867		.1448	
16	.2353	.2402		.1543		.1886	
17	.2263	.2534	.056	.168	.1132	.1886	.2263
18	.1991	.2172	.1867	.1886	.1698	.2353	.2378
19	.2172	.2641	.2075	.2641	.2427	.2829	.2452
20	.3018	.2829		.3018	.2641	.2896	.2829
21	.2835	.2481	.2427	.2641	.2126		.2858
22	.2481	.2126	.2126	.2303	.1772	.2126	.2477
23	.2481	.1772	.1772	.1772	.1417	.1772	.1905
24	.1928	.2126	.1595	.1417	.1595	.1417	.1772
Max	.3018	.2829	.2427	.3018	.2641	.2896	.3258
Min	.1612	.1595	.056	.1402	.1132	.124	.1595
Avg	.2228	.2184	.1632	.1831	.1785	.1701	.2120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 201 / 11 KV Nilaji Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6401	.5716	.6478	.5716	.4191	.4904
2	.6036	.6401	.5716	.6413	.5716	.4191	.4954
3	.6036	.6401	.5716	.6478	.5716	.381	.4954
4	.6036	.6401	.5716	.6348	.5716	.4191	.4954
5	.5281		.6097	.679	.5716	.4954	.5335
6	.5601		.6859	.7468	.6287	.6097	.679
7	.5975	.7316	.679	.7621	.6535	.679	.7095
8	.6283	.695	.6722	.7842	.6516	.7392	.695
9	.6653	.7964	.6584	.8413	.5731	.6584	.7316
10	.788	.788	.6584	.7964	.6733	.6219	.695
11	.7442	.7011	.6584	.7522	.7087	.6154	.6401
12	.7087	.7087	.6401	.7316	.6447	.5068	.6401
13	.7164	.6219	.6401	.6878	.6805	.3696	.6219
14	.7316	.5853	.6413	.6516	.6733	.3658	.5487
15	.7316	.4656	.6219	.6516		.3658	.5121
16	.7316			.8779	.6219	.4706	.5068
17		.543	.6283	.9511		.4755	.6024
18	.6219	.6219	.7842	1.0349	.8131	.543	.6878
19	.6219	.8871		1.1088	.924	.961	.924
20	.8779	1.0829	1.2696	1.0456	1.0082	.9431	1.0082
21	1.134	.8962	1.2071	.9709	.8676	.8299	.9335
22	.7316	.8299	1.0562	.7922	.7545	.724	.7545
23	.7316	.724	1.1431	.6413	.5716	.6097	.6036
24	.6413	.6401	.6097	.7545	.5716	.4572	.5335
Max	1.134	1.0829	1.2696	1.1088	1.0082	.961	1.0082
Min	.5281	.4656	.5716	.6348	.5716	.3658	.4904
Avg	.6916	.7085	.7341	.7847	.6763	.5700	.6474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 202 / HITANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2534	.1829	.1494	.6642	.9717	.2267	.192
2	.2353	.1829	.1494	.6562	.9717	.2267	.192
3	.2353		.1494	.6483	.9831	.2267	.184
4	.2534	.1829	.1494	.6405	.9831	.2652	.176
5	.2686	.2743	.168	.6958	.9945	.2984	.1829
6	.2896	.3292	.2452	.8097	1.0277	.4239	.2667
7	.3658	.3841	.3511	1.1469	1.0898	.5426	.3858
8	.4024	.4207	.4024	1.2266	1.2378	.5693	.4207
9	.4207	.3506		1.21	1.5089	.4801	.6584
10	1.2071		1.4632	.362	.3109	.2657	
11	1.3108	1.7939	1.4632	.2926	.2772	.2218	.1463
12	1.4746	1.8107	1.4998		.2743	.2195	
13	1.5746				.2378	.1629	.1646
14	1.7375	1.7269	1.5181		.2427	.1629	.1463
15	1.7375	1.3272	1.3592			.1612	.1254
16	1.7375	1.3763			.128	.1629	.1254
17		1.1336	1.0059	.1478	.1463	.2195	.1254
18	.1646	.2926	.2715	.2402	.1478	.1829	.1829
19	.1829	.2587	.2561	.2241	.1867	.1663	.1494
20	.1829	.2452	.2241	.2241	.2263	.1478	.1307
21	.2012	.2241	.1886	.1867	.1698	.1307	.1494
22	.2012	.1848	.168	.1494	.1307	.112	.112
23	.2075	.1478	.132	.1307	.112	.0924	.0924
24	.2561	.1829	.1478	.7042	.9602	.2214	.1974
Max	1.7375	1.8107	1.5181	1.2266	1.5089	.5693	.6584
Min	.1646	.1478	.132	.1307	.112	.0924	.0924
Avg	.6478	.6196	.5458	.5453	.5791	.2454	.2048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 203 / HASURCHAMPU AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7116	1.0059	.6554	.0934	.0953	.0762	.0747
2	.7125	1.0059	.6554	.0943	.0953	.0762	.0747
3	.7209	1.0059	.6554	.0943	.0953	.0762	.0747
4	.7125	1.0059	.6554	.0943	.0953	.0762	.0739
5	.7537	1.0608	.6802	.1132	.0953	.0762	.0747
6	.7865	1.0974	.8192	.1307	.1143	.0953	.112
7	.9922	1.1888	1.0562	.1132	.1132	.1132	.1109
8	1.2003	1.1706	1.1523	.1132	.1132	.0747	.0732
9	1.0623	1.065	1.3169	.112	.0934	.0747	.128
10	.1132	.112	.0914	.7099	.6802	.2675	.2743
11	.128	.0934	.0914	.8223	.8962	.4115	.3292
12	.1086		.0914	.8539	.8745	.463	.3658
13	.0886		.0732	.8002	.9061	.4214	
14	.0914	.112	.0732	.7865	.8436	.3549	.3772
15	.0914	.0934	.0739	.7537		.3612	
16	.0914			.663		.3658	
17		.1086	.056	.6371		.3658	.2172
18	.0732	.1132	.0924	.112		.1109	.0747
19	.0732	.1663		.112	.112	.1132	.112
20	.0914	.1509	.1307	.0943	.1307	.1132	.1132
21	.1097	.1307	.0953	.0943	.0943	.0943	.0943
22	.1097	.1143	.1132	.0953	.0762	.0754	.0934
23	.1097	.1524	.1334	.0953	.0754	.0754	.0747
24	.7209	1.0059	.6554	.1132	.0953	.0762	.0754
Max	1.2003	1.1888	1.3169	.8539	.9061	.463	.3772
Min	.0732	.0934	.056	.0934	.0754	.0747	.0732
Avg	.4197	.5695	.4281	.3209	.2848	.1837	.1428

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025] BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 204 / 11KV Hirnyakeshi

Industrial Ex Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER MIDC EQUIVALENT  
HAVING WEEKLY STAGGERING

DATE	01-JUN-18	04-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
11		.0663	
12		.0648	.0914
13		.08	.0747
14	.0732	.0819	
15	.0732	.1006	
16	.0754	.1526	
17		.0781	
18	.0732		
Max	.0754	.1526	.0914
Min	.0732	.0648	.0747
Avg	.0738	.0892	.0831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 201 / 11 KV Halkarni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2472	.2667	.3307	.479	.5189	.4001
2	.1905	.2477	.2286	.3676	.5146	.4715	.3659
3	.1524	.2286	.2096	.4034	.6139	.4987	.3901
4	.1334	.2286	.1905	.4352	.6478	.489	.4162
5	.2286	.2852	.2667	.5218	.6958	.5351	.4572
6	.3416	.3412	.3405	.6257	.754	.5381	.5463
7	.3223	.3036	.3416	.7572	.8005	.7481	.5647
8	.2651	.321	.2844	.8866	.9206	.8539	.7398
9	.3197	.2835	.1696	.7935	.854	.8456	.7707
10	.5724	.6366		.2254	.2627	.2651	.2611
11	.7811	.8695	.8233	.1871	.3371	.2263	.1875
12	.8381	.9072	.8138	.1314	.2987	.1888	.2089
13	.8341	.8951	.8689	.132	.2275	.2081	.2268
14	.7735	.8189	.7846	.1485		.2079	.2275
15	.8312	.8917		.1696		.2832	.227
16		.7549		.1867	.2241		.2266
17		.6707		.2981	.2261		.2809
18	.1691	.1515		.3193	.2459	.3587	.2812
19	.3027	.3392	.3027	.3576	.3027	.3412	.358
20	.3602	.3395		.3776	.3039	.3226	.4158
21	.3795	.3791	.3223	.4158	.3036		.3223
22	.3223	.3989		.3027	.2849	.3042	.3033
23	.3036	.3602	.2846	.3595	.2659	.2849	.2657
24	.2472	.2852	.3036	.5007	.3768	.4707	.3873
Max	.8381	.9072	.8689	.8866	.9206	.8539	.7707
Min	.1334	.1515	.1696	.1314	.2241	.1888	.1875
Avg	.4036	.4660	.4001	.3847	.4518	.4267	.3680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Hiduggi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6067	1.065	.3144	.1503	.2195	.2064	.1474
2	.6983	1.0182	.2968	.1497	.2027	.1882	.1503
3	.8011	.9774	.2819	.1509	.1509	.1698	.1497
4	1.034	.9431	.2986	.1686	.1512	.1503	.1679
5	1.0936	1.0093	.3401	.1696	.1706	.1867	.1663
6	1.0835	1.2171	.4191	.2273	.2263	.2437	.2598
7	1.337	1.5646	.6913	.2838	.2815	.244	.2211
8	1.4685	1.615	1.0085	.2635	.3012	.2427	.2222
9	1.5135	1.5329	1.2764	.244	.2231	.2987	.1846
10	.2601	.222		.6271	.2575	1.0844	1.074
11	.2257	.2031	.1797	1.3603	1.3187	1.292	1.1418
12		.2405	.2112	1.3587	1.4318	1.1399	1.3492
13	.2236		.2489	1.2978	1.3337	1.2357	1.3247
14	.2261	.2614	.1993	1.3283		1.2857	1.1126
15	.2263	.242		1.1946		1.2559	1.0464
16	.1871			1.3386	1.2366		.9669
17			.1985	1.3206	1.0856		1.0105
18	.3131	.1033	.2526	.2518	.2497	1.2193	.2217
19	.2144	.2678	.2723	.3299	.2432	.2603	.2539
20	.3048			.3711	.2723	.2614	.3468
21	.3093	.1164	.2978	.3306	.2571		.2695
22	.309	.1139		.2896	.2405	.2574	.2462
23	.292	.0976	.2412	.2715	.2378	.2388	.2318
24	.4486	1.1129	.3437	.1867	.2547	.2218	.1708
Max	1.5135	1.615	1.2764	1.3603	1.4318	1.292	1.3492
Min	.1871	.0976	.1797	.1497	.1509	.1503	.1474
Avg	.5989	.6962	.3880	.5694	.4703	.5563	.5182

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV nagnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.2418	.3081	.2362	.1966
2				.1939	.2932	.2128	.2398
3				.2426		.2439	.2061
4				.2401	.2701	.2643	.2312
5				.2426	.2846	.2826	.2475
6				.2582	.3333	.3249	.2381
7				.39	.4106	.4332	.3443
8				.3768	.452	.4641	.4052
9				.3855	.3727	.4448	.4396
10		.2006	.2509				
11	.2579	.3391	.3934				
12	.2585	.3501	.3498				
13	.2887		.3644				
14	.2134	.3185	.3061				
15	.2332	.2995					
16	.2341	.306					
17		.2628	.2289				
18			.2338				
24				.3197	.3201	.1915	.2441
Max	.2887	.3501	.3934	.39	.452	.4641	.4396
Min	.2134	.2006	.2289	.1939	.2701	.1915	.1966
Avg	.2476	.2967	.3039	.2891	.3383	.3098	.2793



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV HALKARNI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2667	.2286	.1715	.1905	.1901	.1715
2	.1524	.2286	.1905	.1715	.1524	.1715	.1715
3	.1524	.2286	.1715	.1524	.1334	.1512	.1905
4	.1715	.2286	.1905	.1715	.1524	.1704	.1905
5	.1905	.2477	.2096		.1715	.1905	.1905
6	.2096	.2852	.2472	.2286	.2286	.2282	.2279
7	.2821	.3003	.2619	.2651	.2806	.2447	.2619
8	.2966	.2614	.1677	.2966	.2422	.2412	.2972
9	.296	.2887	.1863	.2417	.2206	.2373	.2601
10	.2526	.2853	.2489	.1858	.2419	.2475	.2683
11	.2678	.2814	.216	.1848	.2183	.2534	.2678
12	.2149	.2117	.2303	.1987	.2378	.2545	.2303
13	.1772	.2838	.2301	.1648	.219	.2393	.251
14	.2738	.2703	.2039	.1454		.239	.2033
15	.2378	.2569		.1402		.2579	.2204
16	.2211	.2641		.1462	.2167		.2669
17		.2768	.2441	.2316	.2494		.2795
18	.3182	.2254	.2459	.2286	.2549	.2686	.2902
19	.3521	.3051	.2973	.3241	.3254	.365	.3064
20	.4032	.3475		.3624	.332	.3881	.3443
21	.3558	.2948	.2806	.3155	.2447		.335
22	.3216	.3229		.2824	.2657	.3021	.3177
23	.2846	.3229	.2662	.2447	.2096	.2464	.2277
24	.2286	.2852	.2852	.1886	.2286	.1905	.1886
Max	.4032	.3475	.2973	.3624	.332	.3881	.3443
Min	.1524	.2117	.1677	.1402	.1334	.1512	.1715
Avg	.2544	.2737	.2301	.2192	.2280	.2418	.2483

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV Hidduggi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.0374	.7655	.567	1.1225	.9855	.5601
2	1.134	1.0017	.7167	.4734	1.0154	.9709	.6011
3	1.2084	1.0037	.5698	.4338	1.0951	.9412	.5636
4	1.2624	.9488	.4673	.6595	1.0584	.9383	.6224
5	1.1283	.9828	.4032	.567	1.0374	.9689	.7304
6	.6776	1.0342	.3757	.8307	.6374	1.0477	.8606
7	1.2433	.8935	.394	.8775	.5293	.9195	.9669
8	1.001	1.1681	.3727	.9035	.4656	.6251	1.0349
9	.9391	.5914	.4967	.9669	.5823	.4362	.5723
10	.4592	.5463	.4443	.2625	.5402	.4049	.4422
11	.4391	.5434	.4382	.3519	.4622	.4422	.3711
12	.3217	.4851	.4779	.1867	.4326	.4504	.3027
13	.5052		.4627	.2435	.3313	.4103	.3696
14	.4959	.4339	.407	.2054		.3768	.3223
15	.4639	.4087		.4091		.3788	.2641
16	.4207			.2978	.477		.3
17		.2155	.3457		.4558		.3628
18	.3825	.4088	.4141	.3309	.4382	.4534	.3547
19	.999	.475	.5111	.5217	1.2084	1.0456	.5481
20	1.3975	.7714		1.1564	1.3182	1.4385	1.102
21	1.363	.9946	1.0488	1.2136			1.4281
22	1.3083	.9335		.6674	1.3774	1.1271	1.2147
23	1.1482	.9709	.7913	1.3162	1.0456	.9719	1.1901
24	1.0269	1.0929	.9355	.7356	1.1016	1.0248	.7282
Max	1.3975	1.1681	1.0488	1.3162	1.3774	1.4385	1.4281
Min	.3217	.2155	.3457	.1867	.3313	.3768	.2641
Avg	.8861	.7701	.5419	.6164	.7968	.7790	.6589

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Nagnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.0159	.0175	.017	.0181	.0157	.0184
2	.0181	.016	.0176	.0175	.0189	.0168	.0183
3	.0181	.0163	.0176	.018	.0189	.0165	.0176
4	.0182	.0165	.0177	.0179	.0189	.0167	.0176
5	.0183	.017	.018	.0181	.0189	.0171	.0177
6	.0185	.0182	.0178	.0181	.0566	.018	.0176
7	.0189	.0178	.0178	.0182	.0748	.0179	.0179
8	.0183	.0175	.0168	.0184	.0697	.0176	.0174
9	.0183	.0163	.0169	.0179	.017	.0171	.0175
10		.0168	.0167	.0184	.0166	.0175	.0167
11	.0166	.0157	.0157	.0169	.0165	.0171	.0169
12		.0162	.0168	.017	.0169	.0171	.0167
13	.0163		.0159	.0171	.0165	.0168	.0151
14	.0158	.0155	.0161	.0176		.016	.0153
15	.0158	.0161		.0188		.0174	.0159
16	.017	.0156		.017			.017
17			.0182		.017		.0152
18	.0149	.0175		.0175	.0178	.0166	.016
19	.0174		.0175	.0175	.018	.0178	.0165
20	.0167	.0175		.0176	.0168	.018	.0163
21	.016	.0162	.0173	.0158			.0156
22	.0158	.0156		.0156	.0163	.0176	.0166
23	.0157	.0153	.0159	.0156	.0156	.0162	.0157
24	.0177	.0158	.0173	.016	.0175	.0156	.0164
Max	.0189	.0182	.0182	.0188	.0748	.018	.0184
Min	.0149	.0153	.0157	.0156	.0156	.0156	.0151
Avg	.0172	.0164	.0171	.0174	.0249	.0170	.0167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 201 / 11 KV Kowad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.1143	.0762	.0347	.0343	.0347	.0381
2	.9602	.0381	.0762	.0347	.0343	.0347	.0381
3	.9602	.1143	.0762	.0347	.0343	.0347	.0381
4	.9602	.1143	.0762	.0347	.0343	.0347	.0381
5	.9602	.1143	.0762	.0347	.0343	.0347	.0381
6	1.0288	.1143	.1143	.0347	.0343	.0347	.0381
7	1.0631	.1143	.1143	.0347	.0343	.0347	.0381
8	1.166	.1524	.1524	.0347	.0343	.0347	
9			.1417	.0343	.0347	.0347	
10	.0381	.0381	.0347	.0686	.0347	.0762	.1524
11	.0381	.0381	.0347	.0686		.0762	.1905
12	.0381	.0381		.0686	.2126	.1143	.1524
13	.0381	.0381	.0347		.2126	.1143	.1143
14		.0381	.0347		.2481	.1143	
15	.0381	.0381	.0347		.1772	.1143	.1524
16		.0381				.1143	.1143
17		.0381	.0347	.0686	.1417	.1143	.0762
18		.0381	.0347	.0343	.0347		.0381
19		.0381	.0347	.0343	.0347	.0381	.0381
20	.0381	.0381	.0347	.0343	.0347	.0381	.0381
21		.0381	.0347	.0343	.0347	.0381	.0381
22	.0381	.0381	.0347	.0343	.0347	.0381	.0381
23		.0381	.0347	.0343	.0347	.0381	.0381
24	.9602	.1143	.1143	.0347	.0343	.0347	.0381
Max	1.166	.1524	.1524	.0686	.2481	.1143	.1905
Min	.0381	.0381	.0347	.0343	.0343	.0347	.0381
Avg	.5804	.0663	.0652	.0413	.0718	.0598	.0708

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 202 / 11 KV Talewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.6097	.4572	.0347	.0343	.0347	.0381
2	1.2689	.6097	.4572	.0347	.0343	.0347	.0381
3	1.2689	.6097	.4572	.0347	.0343	.0347	.0381
4	1.2689	.6097	.4572	.0347	.0343	.0347	.0381
5	1.3032	.6097	.4572	.0347	.0343	.0347	.0381
6	1.3717	.6097	.5335	.0347	.0343	.0347	.0381
7	1.5089	.7621	.6097	.0347	.0343	.0347	.0381
8	1.6804	.0381	.6097	.0343	.0343	.0347	
9			.6379	.0343	.0347	.0347	
10	.0381	.0381	.0347	.3772	.0347	.1143	.2286
11	.0381	.0381	.0347	.4458	.3544	.2286	.2286
12	.0381	.0381		.3429	.4252	.1905	.1524
13	.0381	.0381	.0347		.4252	.2286	.2286
14		.0381	.0347		.4252	.2286	
15	.0381	.0381	.0347		.2835	.2286	
16		.0381				.2286	.0381
17		.0381	.0347	.2401	.2835	.2286	.1524
18	.0381	.0381	.0347	.0343	.0347		.0381
19	.0381	.0381	.0347	.0343	.0347	.0381	.0381
20	.0381	.0381	.0347	.0343	.0347	.0381	.0381
21		.0381	.0347	.0343	.0347	.0381	.0381
22	.0381	.0381	.0347	.0343	.0347	.0381	.0381
23		.0381	.0347	.0343	.0347	.0381	.0381
24	1.2003	.6097	.5335	.0347	.0343	.0347	.0381
Max	1.6804	.7621	.6379	.4458	.4252	.2286	.2286
Min	.0381	.0381	.0347	.0343	.0343	.0347	.0381
Avg	.6916	.2435	.2558	.0979	.1210	.0963	.0781

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 203 / 11 KV Batakanangle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0381	.0762	.7087	.6516	.567	
2	.0343	.0381	.0762	.7087	.6173	.567	
3	.0343	.0381	.0762	.7087	.6173	.567	
4	.0343	.0381	.0762	.7087	.6173	.567	
5	.0343	.0381	.0762	.7087	.6173	.567	
6	.0343	.0381	.0762	.7087	.6173	.567	
7	.0343	.0381	.0762	.8505	.7888	.6379	
8	.0343	.0381	.0762	.8505	.8573	.7796	
9			.0693	.823	.9214	.7796	
10	2.2862	.0381		.0343	.104	.0762	
11	2.6673	.7621	1.0631	.0343	.0693	.0762	
12	2.8197	.7621		.0343	.0693	.0381	.0381
13	2.8197	.8383	1.0631		.0693	.0762	
14		.9907	1.1694		.0693	.0762	
15	2.6673	1.2193			.0693	.0762	.7621
16				.0343		.0762	.7621
17		.3048	1.0631	.0343	.0693	.0762	.0381
18	.0381	.5335	.104	.0343	.0693		.0381
19	.0381	.0762	.104	.0343	.0693	.0762	.0381
20	.0381	.0762	.1734	.0343	.1063	.0762	.0381
21		.0381	.1772	.0343	.104	.0762	.0381
22	.0381	.0381	.1734	.0343	.104	.0762	.0381
23		.1143	.1734	.0343	.567		.0381
24	.0343	.0381	.1143	.7087	.6859	.567	
Max	2.8197	1.2193	1.1694	.8505	.9214	.7796	.7621
Min	.0343	.0381	.0693	.0343	.0693	.0381	.0381
Avg	.7623	.2789	.3029	.3744	.3709	.3201	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 204 / 11 KV Talewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2667	.2286	.1772	.1715	.1417	.1524
2	.2058	.2667	.2286	.1772	.1715	.1417	.1524
3	.2058	.2667	.2286	.1417	.1715	.1417	.1524
4	.2058	.0762	.2286	.1417	.1715	.1417	.1524
5	.2058	.2667	.2286	.1772	.1715	.1417	.1524
6	.2401	.2667	.2286	.2126	.2058	.2481	.2286
7	.2743	.2667		.2126	.2401	.2481	.2667
8	.2401	.3048	.3048	.2058	.2401	.2835	
9			.3189	.2401	.2481	.2481	
10	.3429	.3429	.2835	.2401	.2835	.2667	.2286
11	.3429	.3048	.2481	.2058	.2481	.3048	.1905
12	.2667	.2667		.1372	.2481	.2286	.1524
13	.2667	.2667	.2481		.2481	.2286	.1905
14		.2286	.2126		.2481	.2286	
15	.2667	.2667	.2126		.2481	.1905	
16		.2667				.1905	.1143
17		.2667	.2481	.2401	.2835	.1905	.3429
18	.3429	.381	.2835	.2743	.2835		.381
19	.4191	.4572	.3189	.3772	.3544	.381	.4191
20	.4954	.4572	.4252	.4115	.4252	.381	.4954
21		.4572	.3898	.3429	.3189	.3429	.4572
22	.3429	.381	.3544	.2743	.3189	.3048	.3429
23		.2286	.2126	.2058	.2126	.2286	.2286
24	.2401	.2667	.2286	.1772	.1715	.1772	.1905
Max	.4954	.4572	.4252	.4115	.4252	.381	.4954
Min	.2058	.0762	.2126	.1372	.1715	.1417	.1143
Avg	.2839	.2965	.2696	.2286	.2471	.2339	.2496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 205 / 11 KV Kowad Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.5716	.6097	.5316	.5144	.4961	.5335
2	.6516	.5716	.6097	.5316	.5144	.4961	.5335
3	.6516	.5716	.6097		.5144	.4961	.5335
4	.6516	.5716	.6097	.5316	.5144	.4961	.5335
5	.6516	.5716	.6097	.5316	.5144	.4961	.5335
6	.7202	.5716	.6478	.567	.583	.5316	.6097
7	.7202	.6097	.6859	.6733	.6859	.6733	.724
8	.823	.6097	.8002	.6733	.7202	.6733	
9			.7796	.7202	.7087	.815	
10	.8383	.8383	.8505	.6859	.7796	.7621	.8002
11	.9526	.8764	.815	.6516	.1417	.5716	.7621
12	.9526	.8002		.583	.6733	.6478	.7621
13	.8002	.7621	.7087		.6024	.6478	.724
14		.724	.7087		.5316	.6478	
15	.7621	.724			.5316	.6859	.5716
16		.6478		.6173		.6097	.6097
17		.6859	.8859	.6173	.5316	.6478	.724
18	.4572	.8383	.8859	.5144	.9922		.8002
19	.4572	1.0669	.815	.7888	1.0277	1.2574	.9907
20	.9907	1.105	1.0277	.9945	1.1694	1.1431	1.1431
21		1.0288	.9922	.8916	.9568	.9145	.9907
22	.8002	.8383	.8859	.7545	.7442	.724	.8002
23		.724	.6379	.6173	.567	.5716	.6097
24	.6859	.5716	.6859	.567	.5487	.5316	.5716
Max	.9907	1.105	1.0277	.9945	1.1694	1.2574	1.1431
Min	.4572	.5716	.6097	.5144	.1417	.4961	.5335
Avg	.7344	.7339	.7553	.6522	.6551	.6755	.7077



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5611	.543	.5121	.4527	.4755	.5121
2	.5487	.543	.5249	.5121	.415	.4755	.4755
3	.5121	.5249	.5249	.4557	.4527	.4755	.4755
4	.5121	.543	.543	.4755	.4715	.4755	.4755
5	.5121	.5792	.5611	.5121	.5093	.4755	.4755
6	.5853	.5973	.567	.5487	.5093	.5121	.5121
7	.6584	.5792	.5792	.5853	.5847	.5407	.5487
8	.6584	.5304	.6036	.5853	.547	.5853	.5853
9	.5487	.5487	.5853	.5487	.543	.9412	.547
10	.6219	.567	.5853	.5121	.5973	.6154	.5847
11	.5487	.5487	.5487		.6516		.6036
12	.439	.6219	.5068		.5973	.4904	.6036
13	.5853	.6219	.5249		.5658	.547	.5304
14	.5487	.5487	.543			.5093	.439
15	.6219	.5487	.5068	.5973	.4527	.4904	.439
16		.4755	.5611	.5792		.4904	.4572
17		.4755	.4887	.5611	.4715	.5281	.4938
18	.5853	.439	.543	.6154	.5658	.547	.5304
19	.695	.695	.5973	.7602	.7356	.6979	.6584
20	.7964	.7602	.695	.8507	.7733	.7733	.7499
21	.7602	.7059	.695	.7545	.7133	.7316	.695
22	.6516	.6516	.6584	.6979	.6401	.6584	.6584
23	.5973	.6154	.5487	.5658	.5304	.5487	.5487
24	.5853	.5792	.5792	.5487	.4904	.4755	.5258
Max	.7964	.7602	.695	.8507	.7733	.9412	.7499
Min	.439	.439	.4887	.4557	.415	.4755	.439
Avg	.5964	.5775	.5672	.5889	.5577	.5678	.5469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mahagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1267	.1267	.7362	.6219	.4424	.4557
2	.1227	.1267	.1267	.7362	.6584	.4424	.4557
3	.1227	.1267	.1267	.7362	.6036	.4424	.4557
4	.1227	.1227	.1267	.7712	.6584	.4938	.4908
5	.1227	.1267	.1267	.7712	.7133	.4424	.4908
6	.1227	.1267	.1267	.8063	.8413	.4424	.4908
7	.1402	.1448	.1267	1.0517	1.134	.5735	.4908
8	.1402	.1147	.1227	1.0867	1.2071	.5571	.5258
9	.1753	.1475	.1227	1.1919	1.2127	.724	.5487
10	1.4723	.8848	1.0517	.1052	.1267	.1267	.1097
11	2.3838	1.6385	1.5424		.1267		.0914
12	2.5941	1.7532	1.5746		.1267	.128	.0328
13	2.8045	1.893	1.6108		.0914	.0732	.0819
14	2.524	1.5074	1.8099			.0914	.0819
15	2.524	1.5424		.1267	.0914	.0914	.0819
16		1.4723	.1448	.1267		.0732	.0819
17		1.5074	.8326	.1267	.1097	.0732	.0819
18	.1052	.1402	.1267	.1448	.1097	.1097	.0819
19	.1227	.1227	.1267	.1402	.1097	.128	.1052
20	.1267	.1267	.1227	.1448	.128	.132	.1402
21	.1267	.1267	.1227	.1463	.1147	.1227	.1402
22	.1267	.1267	.1227	.1463	.1147	.1227	.1227
23	.1254	.1267	.1227	.128	.1147	.1227	.1052
24	.1402	.1267	.1267	.7011	.567	.426	.4908
Max	2.8045	1.893	1.8099	1.1919	1.2127	.724	.5487
Min	.1052	.1147	.1227	.1052	.0914	.0732	.0328
Avg	.7451	.5941	.4596	.4962	.4355	.2774	.2598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335	.0343	.0343	.0335	.032	.0328	.0335
2	.0335	.0343	.0343	.0335	.032	.0328	.0335
3	.0335	.0373	.0343	.0335	.032	.0328	.0335
4	.0335	.0343	.0343	.0335	.032	.0339	.0335
5	.0335	.0373	.0343	.0335	.032	.0328	.0335
6	.0335	.0343	.0343	.0335	.032	.0328	.0335
7	.0335	.0373	.0343	.0335	.032	.0328	.0335
8	.0335	.0328	.0343	.0335	.032	.0328	.0335
9	.0335	.0328	.0335	.0335	.0343	.0343	.032
10	.2515	.0655	.0335	.0335	.0362	.0343	.032
11	.3688	.1966	.1677	.0343	.0362	.032	.032
12	.3521	.1802	.1991	.0343	.0343	.032	.0328
13	.3688	.1509	.1991	.0343	.032	.032	.0328
14	.3521	.1006	.1715	.0343		.032	.0328
15	.3185	.1402	.0724	.0343	.032	.032	.0328
16		.1341	.0343	.0343		.032	.0328
17	.1006	.1341	.0343	.0343	.032	.032	.0328
18	.0335		.0343	.0343	.032	.032	.0328
19	.0335	.0335	.0362		.032	.032	.0335
20	.0343	.0343	.0335	.0362	.032	.032	.0335
21	.0343	.0343	.0335	.032	.0328	.0335	.0335
22	.0343	.0343	.0335	.032	.0328	.0335	.0335
23	.0343	.0343	.0335	.032	.0328	.0335	.0335
24	.0335	.0343	.0343	.0335	.032	.0328	.0335
Max	.3688	.1966	.1991	.0362	.0362	.0343	.0335
Min	.0335	.0328	.0335	.032	.032	.032	.032
Avg	.1153	.0705	.0608	.0337	.0327	.0327	.0331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 201 / 11 KV Aralgundi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0158	.0274	.0312	.0633	.0633	.0526	.0663
2	.0158	.0282	.0316	.0625	.0791	.0533	.0678
3	.0158	.0282	.032	.0617	.0949	.0572	.0503
4	.0162	.029	.0324	.0762	.108	.0572	.0663
5	.0162	.0305	.0328	.0772	.1265		.0819
6	.0328	.0339	.0332	.0781	.1235	.0892	.08
7	.0328	.0347	.0343	.176	.2241	.2439	.1614
8	.0305	.0293	.0324	.2056	.2656	.2778	.2229
9	.0293	.0267	.0486	.1698	.2006	.1957	.2591
10	.1128	.104	.1581	.017	.0312	.0324	.032
11	.1698	.1829	.2241	.0164	.0351	.0354	.0343
12	.1562	.1656	.1907	.017	.0354	.0351	.0328
13	.1372	.1355	.1551	.016			.016
14	.1219	.1219	.1429	.016		.0171	.0158
15	.1054	.1054	.1286	.0164	.0164	.0166	.0168
16	.1128	.1286		.0164	.0173	.0316	.0152
17		.1183	.104	.0151	.0156	.0312	.0151
18	.0259		.0297	.0332	.0476	.0312	.0316
19	.0312	.0305	.0339	.0362	.0362	.0339	.0358
20	.0312	.0328	.0362	.037	.0362	.0343	.0354
21	.0305	.0328	.0543	.0354	.0366	.0362	.0351
22	.0274	.0312	.0532	.0354	.0362	.0354	.0332
23	.0263	.0297	.0358	.0351	.0166	.0332	.0347
24	.0156	.0267	.032	.0617	.0633	.0503	.0671
Max	.1698	.1829	.2241	.2056	.2656	.2778	.2591
Min	.0156	.0267	.0297	.0151	.0156	.0166	.0151
Avg	.0569	.0658	.0734	.0573	.0777	.0673	.0628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 203 / Khandal Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0714	.0869	.1337	.0354	.0354	.0179	.0175
2	.0857	.0857	.1505	.0351	.0354	.0175	.0177
3	.0857	.0869	.1524	.0358	.0354	.0175	.0179
4	.0857	.0987	.2317	.0354	.0362	.0175	.0177
5	.1	.1505	.2494	.0358	.0362	.0177	.0175
6	.1	.1829	.2824	.037	.0362	.0179	.0358
7	.1143	.2591	.4475	.0358	.0362	.0362	.0175
8	.1907	.3704	.4877	.0362	.0171	.0179	.0177
9	.1715	.3353	.442	.0177	.0171	.0347	.0332
10	.0166	.0164	.0332	.3521	.0158	.2709	.2027
11	.0181	.0309	.0316	.4687	.4877	.3704	.3395
12	.0179	.0312	.0145	.4586	.5093	.427	.301
13	.0179	.0343	.0293	.442	.5247	.4115	.2675
14		.0343	.016	.4268	.4572	.4115	.2172
15		.0168	.0282	.4321	.4214	.3311	.2172
16	.0154	.0316		.4115	.4321	.3763	.2027
17		.0328	.0309	.3668	.4365	.3668	.1833
18	.0332	.0177	.0158	.0293	.0177	.0301	.0282
19	.0347	.0328	.0339	.0354	.0362	.0347	.0328
20	.0335	.0351	.037	.037	.0373	.0354	.0354
21	.0351	.0347	.0366	.0358	.0362	.0358	.0347
22	.0343	.0343	.0358	.0358	.0362	.0351	.0347
23	.0339	.0343	.0358	.0347	.0358	.0354	.0339
24	.0695	.0846	.1113	.0358	.0354	.0179	.0347
Max	.1907	.3704	.4877	.4687	.5247	.427	.3395
Min	.0154	.0164	.0145	.0177	.0158	.0175	.0175
Avg	.0650	.0899	.1334	.1628	.1585	.1410	.0983

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 201 / YADRAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9209	3.3234	3.8089	4.0329	3.6595	4.1076	3.7342
2	3.8089	3.2861	3.7342	3.9209	3.5848	4.0329	3.6969
3	3.7342	3.2114	3.6969	3.8462	3.5475	3.9209	3.7342
4	3.7715	3.1741	3.7342	3.7342	3.6222	3.8089	3.7715
5		3.2487	3.6595	3.8089	3.6595	3.8462	3.7342
6	2.9874	3.3234	3.7342	3.8462	3.6969	3.9209	3.8089
7	3.7342	3.3608	3.7342	3.8462	3.5101	3.9582	
8	3.3608	3.7342	3.7342	3.5848	3.7723	3.9095	3.3608
9	4.1076	4.369	4.481	3.3981	4.3004		4.3381
10	3.9956		4.5931		4.5645	.9431	4.3004
11	2.2032		4.6677		4.4513	4.5268	4.3381
12	2.3339		4.4437		4.3004	4.225	4.0552
13	3.3234		3.3981		3.6214	3.6969	3.3573
14	3.7342		4.0703		4.2627	4.1495	3.9609
15	3.7342		4.5557		4.489	4.489	3.5837
16	3.6969		4.2943		4.6399	4.489	
17	3.5475		4.4437	2.8006	4.5176		4.2627
18	3.5848		4.369	2.6886	4.4063	3.5475	4.2943
19	3.5101		4.168	2.8006	4.2943	3.9209	4.1823
20	3.1741		3.9209	2.9127	3.9209	4.1076	3.8462
21	3.1741		4.1076	3.3608	4.1076	4.2196	4.1823
22	3.1741		4.145	3.6222	4.2196		4.0329
23	3.2861		4.2196		4.1823		4.1076
24	4.1076	3.3608	3.9209	4.1076	3.7342	4.145	3.9209
Max	4.1076	4.369	4.6677	4.1076	4.6399	4.5268	4.3381
Min	2.2032	3.1741	3.3981	2.6886	3.5101	.9431	3.3573
Avg	3.4785	3.4392	4.0681	3.5195	4.0444	3.8983	3.9365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 203 / ARUNDATHI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1949	1.2696	1.1949	1.419	.8962	1.2323	1.2696
2	1.1576	1.2323	1.1576	3.7715	.8589	1.2323	1.2323
3	1.1203	1.2323	1.1203	1.3817	.8215	1.1949	1.1949
4	1.1203	1.1949	1.1203	1.3817	.8962	1.1576	1.1576
5		1.1949	1.0829	1.3443	.9709	1.1203	1.1949
6	.8962	1.1949	1.1576	1.307	1.0456	1.1203	1.0082
7	1.0082	1.3443	1.1203	1.307	1.0829	1.2071	
8	1.1576	1.419	1.1949	.8215	.9431	1.2826	
9	1.307	1.3817	1.3443	.8215	1.3203	1.3203	
10	1.3817		1.4563		1.5466	1.5089	1.358
11	1.419		1.4563		1.4335	1.5466	1.358
12	1.4563		1.4563		1.4712	1.5844	1.4335
13	1.2696		1.0829		1.1694	1.2071	1.1694
14	1.307		1.2696		1.3957	1.4712	1.2826
15	1.2696		1.419		1.358	1.4712	1.358
16	1.4563		1.531		1.3957	1.4335	1.4712
17	1.4563		1.4563	.7468	1.419		1.5089
18	1.3817		1.3817	.7468	1.4563	1.307	1.4563
19	1.3443		1.3817	.7842	1.419	1.3443	1.419
20	1.2826		1.3443	.8215	1.2696	1.307	1.307
21	1.307		1.3443	.7842	1.307	1.307	1.2696
22			1.419	.8589	1.307		1.1203
23	1.307		1.4563		1.2696		1.307
24	.4763	1.2696	1.2323	1.4563	.9335	1.2696	1.307
Max	1.4563	1.419	1.531	3.7715	1.5466	1.5844	1.5089
Min	.4763	1.1949	1.0829	.7468	.8215	1.1203	1.0082
Avg	1.2308	1.2734	1.2992	1.2346	1.2078	1.3155	1.2944

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 204 / SPM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.2323	1.1203	1.1576	1.1203	1.1949	1.1203
2	1.0829	1.2323	1.1203	1.1203	1.1576	1.1576	1.1203
3	1.0829	1.1949	1.0829	1.1203	1.1203	1.1576	1.0829
4	1.1203	1.1949	1.1203	1.0829	1.1203	1.1203	1.1203
5		1.1949	1.1576	1.0456	1.1203	1.1576	1.1203
6		1.2323	1.1949	1.0829	1.1203	1.1949	1.0456
7	.9335	1.1576	1.1203	1.0829	1.0456	1.1949	
8	1.0082	1.2549	1.1203	.9335	1.0562	1.1949	.9335
9	1.1949	1.307	1.1576	.9149	1.1317	1.2826	1.1694
10	1.2323		1.2323		1.2826	1.0751	1.2071
11	1.2323		1.2323		1.2449	1.2826	1.2071
12	1.2323		1.1576		1.2449	1.2449	1.2071
13	1.1949		1.0082		1.2071	1.1317	1.2071
14	1.1949		1.1576		1.2826	1.2449	1.2826
15	1.1949		1.1576		1.2826	1.2826	1.1694
16	1.1763		1.1576		1.2449	1.2449	1.2449
17	1.1949		1.2169	.8215	1.0829		1.2449
18	1.2323		1.2323	.8589	1.0456	1.0829	1.2696
19	1.1949		1.1949	.8215	1.0829	1.1576	1.307
20	1.1576		1.1789	.8962	1.1576	1.1203	1.307
21	1.1949		1.1949	.9335	1.1203	1.1576	1.2696
22	1.2323		1.2323	.9335	1.1576		1.0456
23	1.2323		1.1949		1.1949		1.1949
24	1.1203	1.2323	1.1203	1.1949	1.1203	1.1949	1.1576
Max	1.2323	1.307	1.2323	1.1949	1.2826	1.2826	1.307
Min	.9335	1.1576	1.0082	.8215	1.0456	1.0751	.9335
Avg	1.1618	1.2233	1.1610	1.0001	1.1560	1.1845	1.1754



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 205 / PADMAJA FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4272	2.1658	2.3152	2.3152	1.7177	2.3152	2.2032
2	2.3899	2.1285	2.2405	2.2405	1.6804	2.3525	2.1658
3	2.3525	2.0911	2.2032	2.1658	1.7177	2.3152	2.1285
4	2.3152	2.0538	2.1658	2.1285	1.7551	2.2405	2.0911
5	2.1658	2.0165	2.0538	2.0911	1.8671	2.2405	2.0538
6	2.0538	1.9418	1.9044	2.0538	2.0165	2.2032	2.0538
7	2.2032	2.0165	1.9418	2.0538	1.9044	2.2405	2.0538
8	2.0911	2.2405	2.3899	1.2323	2.0748	2.2779	2.0538
9	2.4646	2.6139	2.5019	1.1203	2.5463	2.4143	2.4143
10	2.6513		2.8006		2.7349	2.4897	2.9235
11			2.9874		2.9047	2.8669	2.9235
12	2.7633		2.9127		2.7538	3.0933	2.6406
13	2.2405		2.6886		2.5274	2.452	2.3765
14	2.6139		2.7633		2.6406	2.7161	2.7161
15	2.838		2.95		2.8669	2.9424	2.5463
16	2.8753		2.838		2.7538	2.5652	2.6406
17	2.838		2.4272	1.1203	2.5766		2.452
18	2.726		2.5393	1.0082	2.5393	2.2779	2.3525
19	2.6139		2.6139	.9709	2.3525	2.3339	2.2779
20	2.4272		2.452	1.307	2.1658	2.2405	2.2405
21	2.4272		2.5393	1.7551	2.0911	2.3525	2.2405
22	2.4272		2.5019	1.9044	1.9909		2.1285
23	2.1658		2.4272		2.2405		2.3899
24	2.4646	2.1658	2.3899	2.3525	1.7551	2.2779	2.2405
Max	2.8753	2.6139	2.9874	2.3525	2.9047	3.0933	2.9235
Min	2.0538	1.9418	1.9044	.9709	1.6804	2.2032	2.0538
Avg	2.4581	2.1434	2.4812	1.7387	2.2572	2.4385	2.3461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 206 / 11 KV YADRAV AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.213	.2012	.2294		.0095	
2	.2801	.1966	.2347	.2622		.0095	
3	.2614	.1966	.2347	.2622		.0095	
4	.3018	.213	.2515	.2622		.0095	
5		.2294	.2515	.2949		.0095	
6		.2622	.2683	.3277		.0095	
7		.3932	.2683	.3932		.0095	
8		.3277	.2683	.3768		.0095	
9	.1341	.0095		.3768			
10					.421	.3239	.2429
11	.1341				.502	.3887	.2429
12	.2012		.218		.5182	.4049	.2105
13	.2012		.2515		.502	.4534	.1943
14	.218		.2515		.4372	.4534	.1781
15					.4372	.4534	.1943
16			.0048		.4372	.4534	.1943
17			.0048		.426		.1619
18	.0095		.0095		.0095		.0095
19			.0095		.0095		.0095
20	.0191		.0084		.0095		.0095
21	.0191		.0095		.0095		.0095
22	.0191		.0095		.0095		.0095
23	.1966		.0572		.0095		.1147
24	.2683	.213	.2012	.2214		.0095	
Max	.3018	.3932	.2683	.3932	.5182	.4534	.2429
Min	.0095	.0095	.0048	.2214	.0095	.0095	.0095
Avg	.1710	.2254	.1507	.3007	.2670	.1885	.1272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 207 / TARDAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4854	.3932	.4024	.3932		.0476	
2	.4694	.3932	.4359	.3932		.0381	
3	.4694	.426	.4694	.426		.0381	
4	.503	.4588	.57	.426		.0333	
5		.6226	.7712	.4588		.0381	
6		.6226	.8718	.6226		.0476	
7	.4024	.7537	1.0059	.9503		.0476	
8	.6036	.9012	.9389	.8192		.0429	
9	.6371			.0381			
10					.779	.6133	.3812
11					.9779	.8288	.3812
12					.8453	.7293	.3812
13					.9282	.7127	.3149
14					.8122	.779	.3812
15					.8122	.9116	
16			.0381		.9116	.663	.4144
17			.0251		.7209		.4144
18	.0381		.0381		.0381		.0381
19	.0476		.0429		.0476		.0429
20	.0476		.0524		.0524		.0524
21	.0476				.0572		.0524
22	.0524		.0524		.0524		.0524
23	.3605		.3768		.0524		.0619
24	.4024	.3605	.4024	.3605		.0476	
Max	.6371	.9012	1.0059	.9503	.9779	.9116	.4144
Min	.0381	.3605	.0251	.0381	.0381	.0333	.0381
Avg	.3262	.5480	.4059	.4888	.5062	.3512	.2284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 402 / SUNIL INDUSTRIES  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4001	.3361	.4001	.3361	.3429	.3921
2	.3361	.4001		.4001	.2801	.4001	.3921
3	.3921	.3429	.3801	.3429	.2801	.3429	.3361
4	.3361	.3429	.3361	.3429	.2801	.4001	.3921
5	.2801	.3429	.3361	.3429	.3361	.4001	.4481
6	.2801	.3429	.2801	.3429	.3361	.4572	.3921
7	.3921	.3429	.3361	.4001	.3361	.4001	.3361
8	.3361	.3429	.2801	.2858	.2829	.4001	.3921
9	.3361	.3429	.2801	.2858	.3961	.3961	.3395
10	.3361		.3921		.3961	.3395	.3961
11	.3921		.3921		.3961	.3961	.3961
12	.3921		.2801		.3961	.3961	.3961
13	.3361		.2801		.3961	.3395	.3961
14	.3921		.2801		.3961	.3961	.3961
15	.3361		.2801		.3961	.3961	.3961
16	.3921		.3429		.3961	.3961	.3961
17	.4481		.2858	.2241	.4001		.4527
18	.4001		.3429	.2241	.4001	.3921	.4001
19	.4001		.3429	.2801	.4001	.3921	.4001
20	.4001		.3429	.3361		.3361	.4001
21	.4001		.3429	.3921	.4001	.3921	.4001
22	.3429		.3429	.3921		.4001	.4001
23	.4001		.3429			.3429	.4001
24	.3921	.4001	.3921	.4001	.2801	.4001	.4481
Max	.4481	.4001	.3921	.4001	.4001	.4572	.4527
Min	.2801	.3429	.2801	.2241	.2801	.3361	.3361
Avg	.3684	.3601	.3282	.3370	.3579	.3850	.3956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 703 / 33 KV MAIN VCB

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6969	3.2487	3.2487	3.4728	2.0165	2.9127	2.3525
2	3.5848	3.2487	3.2487	3.4728	1.9044	3.0247	2.3525
3	3.3608	3.1367	3.1367	3.3608	1.9044	2.9127	2.3525
4	3.3608	3.2487	3.2487	3.2487	1.9044	2.8006	2.3525
5	2.5766	3.3608	3.3608	3.3608	2.0165	2.9127	2.2405
6	2.5766	3.4728	3.4728	3.4728	2.2405	2.9127	2.4646
7	2.5766	3.9209	3.5848	4.0329	2.2405	2.9127	2.5766
8	3.2487	4.0329	3.9209	2.9127	2.6029	2.9127	2.3525
9	3.3608	3.1367	2.8006	1.5684	2.7161	3.0556	2.7161
10	3.1367		3.2487		4.1872	4.0741	3.7346
11	3.4728		3.3608		4.8663	4.4136	4.0741
12	3.4728		3.6969		4.8663	4.6399	3.6214
13	2.9127		3.4728		4.5268	4.0741	3.1687
14	3.4728		3.4728		4.5268	4.1872	3.7346
15	3.3608		3.4728		4.5268	4.7531	3.3951
16	3.4168		3.3608		4.7531	4.0741	3.6214
17	3.4728		2.9127	1.1203	4.369		3.5082
18	3.3608		3.1367	1.1203	3.1687	2.6886	3.0247
19	3.2487		3.2487	1.1203	3.0247	2.4646	2.9127
20	3.1367		3.0247	1.3443	2.8006		2.9127
21	3.1367		3.1367	2.3525	2.8006	2.5766	2.9127
22	3.1367		3.1367	2.2405	2.6886		2.8006
23	3.2487		3.4728		2.9127		3.2487
24	3.8089	3.2487	3.3608	3.4728	2.1285	2.9127	2.3525
Max	3.8089	4.0329	3.9209	4.0329	4.8663	4.7531	4.0741
Min	2.5766	3.1367	2.8006	1.1203	1.9044	2.4646	2.2405
Avg	3.2558	3.4056	3.3141	2.6046	3.1539	3.3608	2.9493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 201 / LAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3899	2.0911	2.0576	2.2405	1.4575	2.0165	2.6513
2	2.4272	2.0538	1.8004	2.2405	1.3717	1.9791	2.5766
3	2.4646	2.0165	1.7147	2.2032	1.286	1.9044	2.5393
4	2.4646	2.0165	1.5432	2.1658	1.2003	1.8671	2.4646
5	2.4272	2.0911	1.5432	2.0911	1.3717	1.9418	2.3899
6	2.4272		1.8861	2.0911	1.4575	1.9791	2.0538
7	2.4646	2.1658	2.0576	2.0538	1.5432	2.0165	2.2405
8	2.5019		1.9719	1.8298	1.1431	2.0538	2.0538
9	2.5766	2.3148	2.6513	1.4937	2.6139	2.4863	2.8753
10	2.838	2.8292	2.95	1.419	2.7633	2.915	2.9874
11	2.838	2.7435	3.2487		2.8753	2.915	2.8006
12	2.6139	2.8292	3.2114		2.838	3.0007	2.7633
13	2.6139	2.4863	2.9127		2.8753	2.4006	2.6886
14	2.6886	2.6578	2.838		3.1367	2.6578	2.6139
15	2.6139	2.572	3.3608	1.1949	3.0247	2.7435	
16	2.5393	2.572	3.3234	1.2323	3.062	3.0994	
17	2.4646	2.572	3.2861			3.062	2.572
18	2.4272	2.4863	2.5393		2.8753	3.0247	2.572
19	2.3899	2.572	2.7633		2.6139	3.0247	2.4863
20	2.3152	2.2291	2.5766		2.3899	2.95	2.4006
21	2.2405	2.3148	2.5393		2.2405	2.5766	2.4006
22	2.1658	2.4006	2.2405		2.1658	2.3899	2.3148
23	2.0911		2.2405		2.0538	2.7633	
24	2.3899		2.3148	2.2405	1.3717	2.0538	2.6513
Max	2.838	2.8292	3.3608	2.2405	3.1367	3.0994	2.9874
Min	2.0911	2.0165	1.5432	1.1949	1.1431	1.8671	2.0538
Avg	2.4739	2.4007	2.4821	1.8843	2.1622	2.4926	2.5284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 202 / MANIK  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5766	2.1658	2.5377	2.4272	1.4403	2.0538	2.5393
2	2.5393	2.0911	2.4348	2.3525	1.406	2.0165	2.4646
3	2.4646	2.1658	2.0405	2.2779	1.3717	2.0165	2.3899
4	2.4272	2.2032	1.9204	2.2779	1.4403	1.9044	2.3525
5	2.3899	2.2032	2.0576	2.1658	1.4746	1.9418	2.3152
6	2.5393	2.2405	2.1091	2.1285	1.5089	1.9418	2.3525
7	2.5766	2.3152	2.1605	2.0538	1.406	2.0911	2.3525
8	2.6513		2.2119	1.8298	1.5432	2.2405	2.726
9	3.062	2.3834	2.838	1.531	2.6886	2.3148	3.3234
10	3.0994	2.7435	3.0247	1.4563	2.95	2.915	3.2487
11	3.1367	2.8464	3.1367	1.3443	2.9127	2.9664	2.9127
12	2.838	2.9835	2.9874	1.2696	2.726	3.0178	2.838
13	2.8753	2.4006	2.5393	1.2696	2.4646	2.5034	2.8006
14	2.8006	2.6406	3.0994	1.307	2.5766	2.8464	2.9874
15	2.7633	2.7435	3.062	1.307	2.4646	3.1893	
16	2.6886	2.4006	3.1367	1.307	2.726	3.3234	
17	2.5393	2.8464	3.2861			3.2114	2.5034
18	2.3899	2.7092	2.95		2.8006	3.0994	2.6749
19	2.5393	2.5377	2.726		2.6139	2.838	2.572
20	2.3899	2.4691	2.726		2.4646	2.8006	2.4691
21	2.3152	2.5034	2.5766		2.3899	2.726	2.5549
22	2.2405	2.5377	2.5393		2.2405	2.6513	2.5034
23	2.2405		2.4646		1.9547	2.6513	
24	2.5766	2.1658	2.5549	2.4272	1.5261	2.1285	2.5766
Max	3.1367	2.9835	3.2861	2.4272	2.95	3.3234	3.3234
Min	2.2405	2.0911	1.9204	1.2696	1.3717	1.9044	2.3152
Avg	2.6108	2.4680	2.6300	1.8078	2.1344	2.5579	2.6408

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 204 / 11 KV AUTOLINE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	2.3152	2.3834	1.7177	.8402	1.9044	2.4646
2	1.1203	2.2405	2.2462	1.7177	.7888	1.7177	2.4272
3	1.2323	1.8298	2.2977	1.643	.8573	1.4937	2.3899
4	1.4563	1.2323	2.2291	1.7177	1.1831	1.4563	2.3899
5	1.7177	1.2696	2.1948	1.7924	1.2689	1.7177	2.5766
6	2.0538	1.9044	2.2634	1.9044	1.2174	1.8671	2.6513
7	2.1285		2.332	1.7924	1.286	1.9044	2.6513
8	2.2405		2.0405	1.3817	1.5261		1.0082
9	2.8753	1.8347	2.6886	1.1203	2.2592	1.8861	2.1285
10	2.8006	2.0062	2.838	.8962	2.7633	2.2805	2.3152
11	2.6139	2.0576	3.062	.8589	2.6139	2.6406	2.6139
12	2.4646	2.0919	2.95	.8215	2.4646	2.7606	2.9127
13	2.3899	1.7833	2.0538	.8215	1.4563	1.3889	
14	2.3152	1.8176	2.9127	.8215	2.5393	1.8861	2.3899
15	2.4272	1.7661	3.0247	.8215	2.5019	2.6406	
16	1.8671	1.9376	2.8753	.8589	1.7551	2.5766	
17	1.4563	2.0062	2.4272			2.4646	1.5432
18	1.643	2.2119	.8589		1.9044	2.5393	1.6804
19	2.3152	2.4177	1.8671		2.2779	2.6513	1.9204
20	2.4646	1.8347			2.4646	2.6886	2.2977
21	2.0165	1.9204	1.8298		2.3899	1.0082	2.332
22	2.2405	1.9547	1.7177		2.3152	2.7633	2.2634
23	2.2405		1.7924		2.2405	2.5766	
24	1.0456	2.3152	2.2977	1.7551	.7888	2.2405	2.4646
Max	2.8753	2.4177	3.062	1.9044	2.7633	2.7633	2.9127
Min	1.0456	1.2323	.8589	.8215	.7888	1.0082	1.0082
Avg	2.0087	1.9404	2.3123	1.3201	1.8132	2.1328	2.2710



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 206 / 11 KV MARUTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646	2.2634	2.5549	2.5393	1.4175	2.4646	2.4646
2	2.4272	2.5019	2.4348	2.4646	2.0233	2.4646	2.4272
3	2.3899	2.3899	2.2634	2.4646	1.8519	2.3899	2.3899
4	2.4272	2.3152	2.0233	2.5766	1.869	2.3152	2.3899
5	2.4646	2.2405	1.9204	2.6513	2.0405	2.4272	2.726
6	2.5019	2.2405	2.0576	2.6513	1.3946	2.4646	3.0247
7	2.5019	2.3152	2.1262	2.7633	2.1605	2.3899	2.9127
8	2.5393		2.2462	2.0538	2.332	2.4646	2.1658
9	2.5766	2.332	2.6513	2.0165	2.8006	2.1948	3.1367
10	2.7633		3.1367	1.9418	3.1367	2.1262	3.0247
11	2.838	2.6406	2.726	1.643	2.5766	2.5377	2.838
12	2.9874	2.5034	3.1367	1.406	2.6513	2.8121	2.8006
13		2.1262	2.838	1.5684	2.9127	2.5034	2.9874
14		2.5377	3.0247	1.643	2.8753	2.332	2.8753
15	2.6139	2.7778	3.2114	1.6057	2.838	2.2291	
16	2.6139	2.5377	3.1367		2.726	2.5766	
17	2.838	2.0919	3.0994			2.4646	2.3663
18	2.6139	2.1948	2.3899		2.4646	2.726	2.1948
19	2.4646	2.2634	3.1367		2.5393	2.9127	2.2291
20	2.5393	2.5377	2.9127		2.4646	2.726	2.1605
21	2.3899	2.6406	2.838		2.3899	2.9127	2.2634
22	2.4646	2.6749	2.726		2.4272	2.9127	2.1262
23	2.4646		2.6513		2.4272	2.3525	
24	2.4646	2.5019	2.6406	2.5766	2.1948	2.3899	2.4646
Max	2.9874	2.7778	3.2114	2.7633	3.1367	2.9127	3.1367
Min	2.3899	2.0919	1.9204	1.406	1.3946	2.1262	2.1262
Avg	2.5613	2.4108	2.6618	2.1604	2.3702	2.5037	2.5699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 401 / 33 KV LIE Industrial No 1 SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6886	2.6749	2.6235	2.8235	2.4177	2.9127	2.9127
2	2.6886	2.9687	2.572	2.9127	2.3663	2.9687	2.9127
3	2.5766	2.8006	2.5206	2.9127	1.5089	2.9127	3.0247
4	2.5766	2.6886	2.4691	2.8006	2.4177	2.8006	3.0247
5	2.8006	2.6886	2.572	2.8006	2.572	2.8006	3.0247
6	2.8006	2.9127	2.6235	2.9127	2.572	2.9127	3.0247
7	2.8006	3.0247	2.572	2.9127	2.6235		3.0247
8	2.8006		2.5206	2.8006	2.572		2.6886
9	2.9127	2.7263	2.9127	2.9127	2.8567	2.6235	2.8006
10	3.0247	2.8292	3.2487	2.9127	3.0247	2.7778	2.9127
11	3.1367	2.8807	3.0247	2.9687	2.9127	2.8292	3.0247
12	3.0247	2.9321	3.3608	3.0247	3.0247	2.7778	3.0807
13	3.1367	2.9321	3.1367	2.9127	3.0247	2.6749	2.9127
14	3.1367	2.8807	3.1367	2.9127	3.1367	2.7778	3.0247
15	3.0247	2.9321	3.1493	2.9127	3.2487	2.7263	
16	2.9127	2.7778	3.1367	3.0247	3.0247	2.8006	
17	3.0247	2.7263	3.0247			2.9127	2.7263
18	3.0247	2.7778	3.0247		2.9127	2.8006	2.7778
19	2.9127	2.6749	3.0247		3.0247	2.8006	2.6749
20	2.8006	2.7778	3.1367		2.6749	2.9127	2.572
21	2.8006	2.6749	3.0247		2.8006	2.6886	2.572
22	2.8006	2.8292	2.9127		2.6886	2.9127	2.5206
23	2.8006		2.9127		2.8006	3.0247	
24	2.6886	2.8006	2.6749	2.8006	2.4691	2.8006	2.9127
Max	3.1367	3.0247	3.3608	3.0247	3.2487	3.0247	3.0807
Min	2.5766	2.6749	2.4691	2.8006	1.5089	2.6235	2.5206
Avg	2.8706	2.8142	2.8881	2.8975	2.7250	2.8250	2.8643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 402 / 33 KV LIE INDUSTRIAL NO 2 SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.7924	1.6461	1.6804	1.3375	1.7924	1.7924
2	1.3443	1.9044	1.5432	1.5684	1.2346	1.9044	1.7924
3	1.3443	2.0165	1.5432	1.5684	1.2346	2.0165	1.7924
4	1.4563	1.9044	1.4403	1.6804	1.1317	2.0165	1.9044
5	1.4563	1.7924	1.5432	1.7924	1.0288	1.9044	1.9044
6	1.5684	1.9044	1.749	1.9044	1.1317	1.9044	1.9044
7	1.3443	1.9044	1.8519	2.1285	1.1317	1.9044	1.5684
8	1.2323		1.9547	1.7924	1.3443	2.0165	1.1946
9	1.1203	1.9547	2.1285	1.9044	1.5684	1.5546	1.9044
10	1.5684	2.0576	2.1285	1.6461	1.5684	1.6461	2.0165
11	1.5684	2.0576	2.2405	1.5684	2.0165	1.6461	2.1285
12	1.4563	2.0576	2.2405	1.3443	1.4563	1.749	1.9044
13	1.6804	1.8519	2.1285	1.3443	1.7924	1.749	2.0165
14	1.6804	2.1605	2.1285	1.2323	1.6804	1.8519	2.0165
15	1.6804	1.9547	2.3525	1.3443	1.5684	1.9547	
16	1.5684	1.9547	2.2405	1.3443	1.7924	1.5684	
17	1.5684	2.0576	2.2405			1.6804	1.749
18	1.6804	1.9547	2.0165		2.0165	1.7924	1.8519
19	1.6804	1.8519	1.5684		1.9044	1.9044	1.8519
20	1.8484	1.749	2.1285		2.0165	1.9044	1.749
21	.5601	1.8519	2.0165		1.9044	1.7924	1.5432
22	1.7924	1.8519	2.0165		2.0165	2.0165	1.3375
23	1.7924		1.5684		1.9044	1.9044	
24	1.2323	1.7924	1.749	1.6804	1.3375	1.9044	1.7924
Max	1.8484	2.1605	2.3525	2.1285	2.0165	2.0165	2.1285
Min	.5601	1.749	1.4403	1.2323	1.0288	1.5546	1.1946
Avg	1.4773	1.9263	1.9235	1.6191	1.5704	1.8366	1.7960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 201 / SAJANI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5601	.5601	.5788	.4805	.5601	.5658
2	.5228	.5228	.5228	.5415	.4435	.5228	.5281
3	.5228	.5228	.5041	.5041	.4435	.5228	.5281
4	.5228	.5601	.5041	.5041	.4435	.5228	.5281
5	.5601		.5228	.5228	.4805	.5415	.5281
6	.5601	.6348	.5975	.5601	.5175	.5788	.5658
7	.5601	.6722	.6161	.5601	.5544	.6161	.6036
8	.5601	.7167	.5975	.5228	.5914	.6161	.6036
9	.5601	.7468	.6161	.4108	.6283	.6722	.5975
10	.6099	.6908	.6348	.3326	.6722	.5975	.6283
11	.6653	.6348	.7095	.2772	.6722	.5601	.6283
12	.6653	.5975	.6161	.2772	.5601	.5041	.6468
13	.6283	.6161	.5975	.2957	.4854	.5415	.4435
14	.5914	.7095	.5788	.2957	.5228	.5415	.4805
15	.6099	.7095		.2957	.5601	.5228	.5544
16	.6099	.6908	.6348	.2957	.5975	.4904	.4805
17	.5914	.6908	.6348	.2957	.5975		.5175
18	.5544	.5601	.5975	.3326	.6348		.5544
19	.5544	.7282	.6535	.4435	.6535	.6979	.6653
20		.7095	.7468	.5175	.6722	.679	.6653
21	.6653	.7468	.6348	.5544	.7095	.679	.7023
22	.6722	.6535	.6161	.5914	.6908	.6413	.6283
23	.6722	.5975	.5975	.5544	.6161	.5601	.5544
24	.2286	.5975	.5975	.5788	.4805	.5975	.5601
Max	.6722	.7468	.7468	.5914	.7095	.6979	.7023
Min	.2286	.5228	.5041	.2772	.4435	.4904	.4435
Avg	.5760	.6465	.6040	.4435	.5712	.5803	.5733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 203 / PANCHAGANGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.8299	.7922	.6908	.6036	.7167	.6413
2	.7468	.7468	.7922	.7282	.5658	.6979	.6413
3	.7842	.7468	.7545	.7095	.5658	.679	.679
4	.7842	.8299	.811	.7095	.679	.7167	.6722
5	.8676	.9335	.8676	.7842	.811	.7356	.7545
6	.9335	1.1203	.9431	.8589	.8065	.7922	1.094
7	.9335	1.1576	.9054	.8962	.9488	.8676	1.1317
8	.7468	1.2136	.7922	.9335	.9488	.9054	1.1694
9	.9335	1.2071	.8676	.8215	.9831	.8488	1.0829
10	1.0185	1.0751	.9522	.7167	1.2826	.8589	.8299
11	1.0374	1.3203	.8962	.7167	1.2323	.8589	.8299
12		1.2826	.9709	.679	1.1317	.8589	.8676
13	.9054		.9335	.6602	1.094	.8299	.9808
14	.8299	1.2826	.9335	.6602	.9054	.8215	.7545
15	.8299	1.2637	.9709	.6413	.9808	.7842	.8676
16	.8676	1.2449	1.0082	.6224	.9808	.7095	.7922
17	1.0562	1.2071	.9335	.6036	.9431		1.0185
18	1.2826	1.2826	.7842	.679	.9619		.9431
19	1.2071	.7922	.9149	.7167	1.226	.8676	.7922
20		.9997	1.0456	.7545	1.1317	.8299	.8676
21	.8676	1.0562	.9896	.7545	1.0185	.7922	.8676
22	.9431	.9997	.9335	.7545	.9808	.7468	.7545
23	1.0185	.9054	.8589	.7167	.9431	.7095	.7167
24	.7468	.9054	.8488	.6908	.6413	.7545	.6348
Max	1.2826	1.3203	1.0456	.9335	1.2826	.9054	1.1694
Min	.7468	.7468	.7545	.6036	.5658	.679	.6348
Avg	.9131	1.061	.8958	.7291	.9319	.7901	.8493

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 204 / RUI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0671	.0838	.0838	.4024	.3605	.4694	.2347
2	.0671	.0838	.0838	.3688	.3605	.4694	.2347
3	.0671	.0838	.0838	.3688	.3605	.4527	.2347
4	.0663	.0838	.0838	.3856	.3768	.4527	.2347
5	.0671	.0838	.0838	.4191	.4096	.4694	.2347
6	.0671	.0838	.0838	.4527	.4588	.4862	.2683
7	.0671	.0838	.0838	.4862	.5079	.5365	.2683
8	.0671	.0838	.0838	.5365	.5243	.5365	.2683
9	.0838	.1006	.0838	.5365	.5571	.4862	.2515
10	.0819	.1006	.1006	.4915	.503	.4527	.2294
11	.7537	.8215	.8718	.0819	.0671	.0503	.0655
12	.7537	.8215	.7712	.0819	.0671	.0503	.0655
13	.7209	.8215	.7712	.0819	.0671	.0671	.0655
14	.6882	.8048	.7545	.0819	.0671	.0671	.0655
15	.6554	.788	.7545	.0819	.0671	.0671	.0819
16	.6226	.6203	.6874	.0655	.0671	.0671	.0819
17	.6226	.4527	.6706	.0655	.0671		.0819
18	.6554	.4527	.3688	.0819	.0671		.0819
19	.0819	.0838	.0671	.0819	.0838	.0838	.0819
20		.0838	.0838	.0983	.0671	.0838	.0819
21	.0983	.1006	.0838	.0983	.0838	.0838	.0819
22	.0838	.1006	.0838	.0819	.0838	.0671	.0819
23	.0838	.0838	.0671	.0819	.0838	.0671	.0655
24	.0671	.0838	.0838	.0838	.0819	.0838	.0671
Max	.7537	.8215	.8718	.5365	.5571	.5365	.2683
Min	.0663	.0838	.0671	.0655	.0671	.0503	.0655
Avg	.2865	.2913	.2906	.2332	.2267	.2568	.1462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 205 / MANGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2987	.2801	.2614	.2987	.2801	.2801
2	.2801	.2801	.2801	.2427	.2614	.2801	.2614
3	.2801	.2614	.2614	.2427	.2614	.2614	.2614
4	.2801	.2614	.2614	.2614	.2614	.2614	.2614
5		.2801	.2614	.2614	.2987	.2614	.2801
6	.2987	.2987	.2801	.2987	.2987	.2801	.2801
7	.2614	.3361	.2614	.2987	.3174	.3174	.3018
8	.2241	.2987	.2614	.2987	.2987	.2987	.3018
9	.2241	.2801	.2987	.2801	.2987	.2987	.2614
10	.2241	.2683	.2614	.2987	.2987	.2241	.2801
11	.3547	.2987	.2614		.2987	.2241	.2614
12	.3361	.3174	.2241		.3174	.2058	.2241
13	.3547	.3361	.2614		.3361	.2241	.1494
14	.3734	.3361	.2801		.2987	.2241	.1494
15	.3734	.3206	.2987		.2987	.2241	.1867
16	.3734	.2987	.2801		.2987	.2241	.2241
17	.3547	.2801	.2801	.3361	.2987		.2614
18	.3361	.2801	.2614	.3734	.2801		.2987
19	.3547	.2987	.3361	.3734	.2801	.4108	.3547
20		.3921	.4108	.3734	.3547	.3772	.3734
21	.4108	.3921	.3921	.3734	.4108	.3772	.4294
22	.3921	.3734	.3734	.3921	.3734	.3361	.3734
23	.3772	.3361	.3361	.3734	.3174	.3174	.3361
24	.3361	.3361	.2987	.2801	.3361	.2987	.2801
Max	.4108	.3921	.4108	.3921	.4108	.4108	.4294
Min	.2241	.2614	.2241	.2427	.2614	.2058	.1494
Avg	.3227	.3108	.2917	.3122	.3081	.2821	.2780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 206 / 11 KV MANGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0686	.0343	1.3375	1.262	1.3717	.8063
2	.0514	.0514	.0343	1.3546	1.262	1.3717	.7712
3	.0514	.0514	.0343	1.3375	1.2795	1.3889	.7712
4	.0514	.0514	.0343	1.3375	1.2971	1.406	.7712
5	.0514	.0514	.0343	1.3717	1.3146	1.406	.7712
6	.0514	.0686	.0343	1.3889	1.3847	1.3889	.7712
7	.0514	.0514	.0343	1.4232	1.4373	1.3889	.8063
8	.0514	.0514	.0343	1.4403	1.4373	1.406	
9	.0514	.0514	.0343	1.3717	1.4373	1.3717	
10	.0526	.0343	.0343	1.4022	1.3672	1.3375	
11	2.1559	2.2977	1.8861		.0351	.0343	
12	2.1735	2.3148	1.8519		.0351	.0343	
13	2.2786	2.4348	1.9376		.0351	.0343	
14	2.3838	2.4691	1.9204		.0351	.0343	
15	2.3663	2.6513	1.8652		.0343	.0343	
16	2.3137	1.8347	1.8176		.0343	.0377	
17	2.2786	1.8347		.0526	.0514		
18	2.2786	1.8519	1.5432	.0701	.0514		
19	.0526	.0343	.0343	.1052	.0514	.0351	.0351
20			.0343		.0514	.0351	.0351
21	.0701	.0343	.0343	.0876	.0514	.0351	.0351
22	.0686	.0343	.0343	.0701	.0343	.0351	.0351
23	.0857	.0343	.0343	.0701	.0343	.0351	.0351
24	.0514	.0686	.0343	.0343	.0701	.0343	.0351
Max	2.3838	2.6513	1.9376	1.4403	1.4373	1.406	.8063
Min	.0514	.0343	.0343	.0343	.0343	.0343	.0351
Avg	.8292	.8011	.5813	.8385	.5868	.6480	.4369



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 207 / 11 KV LAXMI AG. (SAJANI) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.0791	.0949		.5693	1.1385	.4744
2	.0937	.0791	.0949	.4961	.5693	1.1385	.4687
3	.0937	.0791	.0949	.5121	.5693	1.1702	.4687
4	.0937	.0791	.0949	.5441	.5693	1.1385	.4687
5	.0937	.0791	.1107	.5441	.6325	1.2018	.506
6	.0937	.0949	.1265	.5921	.9503	1.2492	.5937
7	.1094	.0949	.1423	.7042	1.1069	1.3283	.6642
8	.1094	.1107	.1107	.9122	1.0753	1.3125	.6562
9	.0937	.1107	.1107	.8802	1.0595	1.2334	.6874
10	.0949	.0949	.096	.8065	.9488	1.1092	.5693
11	1.8343	1.7078		.1107	.0633	.1094	.0633
12	1.8343	1.7711	1.5043	.1107	.0791	.1107	.0633
13	1.7869	1.7236	1.668	.1107	.0949	.1265	.0949
14	1.7394	1.6762	1.6644	.1107	.0949	.125	.0791
15	1.7394	1.6129	1.6644	.1107	.0791	.125	.0949
16	1.7078	1.4074	1.5364	.1107	.0791	.0937	.0949
17	1.5813	.9488	1.4723	.1107	.0791		.0949
18	1.4864	1.0753		.1107	.0791		.0949
19	.0949	.0791	.7042	.0949	.0791	.0949	.1107
20		.0949	.08	.0791	.0791	.0937	.1107
21	.1107	.0949	.08	.0791	.0791	.1006	.0949
22	.0949	.0949	.08	.0791	.0791	.0791	.0949
23	.0791	.0949	.08	.0791	.0791	.0838	.0791
24	.0949	.0791	.1006	.064	.0633	.0791	.0781
Max	1.8343	1.7711	1.668	.9122	1.1069	1.3283	.6874
Min	.0791	.0791	.08	.064	.0633	.0791	.0633
Avg	.6589	.5568	.5323	.3197	.3816	.6019	.2836

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 208 / 11 KV GOMTESH VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1715	.1715	.168	.1524	.1715	.1867
2	.1867	.1715	.1715	.168	.1524	.1715	.1867
3	.1867	.1715	.1715	.168	.1524	.1715	.1867
4	.1867	.1715	.1715	.168	.1524	.1715	.1867
5	.1867	.1715	.1715	.1867	.1715	.1715	.1867
6	.1867	.1905	.1905	.1867	.1698	.1715	.1886
7	.168	.1905	.2096	.1867	.1715	.1905	.1886
8	.1867	.2286	.3239	.168	.1905	.2096	.1886
9	.2427	.2667	.4382	.168	.2286	.2858	.2427
10	.4191	.3429	.4481	.1334	.3048	.3547	.3048
11	.4191	.2667	.4481	.1334	.3429	.3361	.3048
12	.381	.3048	.3734	.1905	.2667	.2987	.3048
13	.381	.3048	.2987	.2096	.2096	.2614	.2286
14	.4191	.2858	.3174	.2096	.2286	.2427	.2667
15	.4382	.2858	.3361	.2096	.2477	.2427	.3048
16	.381	.2477	.2801	.1905	.2667		.4191
17	.3429	.2667	.2801	.1905	.2667		.3429
18	.3048	.2667	.2241	.1905	.2667		.3048
19	.2286	.2858	.2054	.1715	.2477	.2452	.2667
20		.2096	.2054	.1715	.1905	.2263	.2667
21	.1905	.2286	.2054	.1715	.2286	.1886	.2286
22	.1715		.1867	.1715	.1905	.2054	.2286
23	.1715	.1715	.1867	.1715	.1713	.2054	.1905
24	.0762	.1715	.1715	.168	.1524	.1715	.2054
Max	.4382	.3429	.4481	.2096	.3429	.3547	.4191
Min	.0762	.1715	.1715	.1334	.1524	.1715	.1867
Avg	.2627	.2336	.2578	.1771	.2135	.2235	.2462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 401 / 33 KV MANGAON INDUSTRIAL  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6399	4.257	4.3004	3.9609	4.0009	4.481	4.1872
2	4.5268	4.1872	4.1872	4.1307	3.9438	4.537	4.3004
3	4.6399	4.0741	4.4136	4.0741	3.8866	4.537	4.357
4	4.5268	4.0741	4.4136	3.9609	3.7151	4.4136	4.3004
5	4.5268	3.9609	4.4702	3.8477	3.7723	4.4136	4.3004
6	4.7531	4.145	4.5268	3.8477	3.6008	4.5268	3.5648
7	4.6965	3.6214	4.5833	3.9043	3.7723	4.3004	4.357
8	4.5833	4.1307	4.6399	4.1307	4.0009	4.1872	4.5268
9	3.9609	4.5833	4.6965	4.0741	3.7723	4.8097	4.5833
10	4.8011	4.1872	4.6399	4.0581	3.315	3.7912	4.0581
11	4.8011	5.4321	5.2058	4.1152	4.1152	4.5268	
12	5.2012	5.2058	5.2058	4.0581	4.1152	4.5833	
13	5.2584	4.6491	4.1872	4.0009	4.2295	4.3004	
14	4.6296	5.0972	4.4136	4.0581	4.0009	4.0741	
15	4.8011	4.481	4.6965	3.9438	4.1307	3.9609	
16	5.2584	4.5268	4.9794	4.0009	4.1872		4.2867
17	4.0581	4.145	4.5268	4.0009	4.1872		4.6868
18	4.401	4.6965	5.0926	4.0009	4.1307		4.8011
19	4.401	4.0889	4.8663	4.0009	4.1872		4.8583
20	4.2295	4.1307	4.5833	4.0009	4.1307		4.5725
21	3.8295	4.7531	4.0741	4.0009	4.1307	2.7161	4.401
22	4.0741	4.6965	3.9609	4.0009	4.357	2.7726	4.2867
23	4.5268	4.5268	4.0741	3.7723	4.5833	3.1687	4.2295
24	4.9228	4.4582	4.4136	4.0175	4.0581	4.6965	3.6214
Max	5.2584	5.4321	5.2058	4.1307	4.5833	4.8097	4.8583
Min	3.8295	3.6214	3.9609	3.7723	3.315	2.7161	3.5648
Avg	4.5853	4.4212	4.5480	3.9984	4.0135	4.1472	4.3305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 201 / PUJARI MALA AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.1029	1.9204	1.6004	1.4918	.0686	.0762
2	.0914	.1029	1.2803	1.6004	1.6575	.0686	.0762
3	.0914	.1029	1.9547	1.6004	1.4918	.0686	.0762
4	.0914	.1029	1.9204	1.6004	1.4918	.0686	.0762
5	.0914	.1029	2.0233	1.6004	1.6118	.0686	.0762
6	.0914	.1029	2.0748	1.6309	1.749	.0686	.0762
7	.0914	.1029	2.0576	1.7833	1.869	.0686	.0762
8			2.1605	1.8747	1.8861	.0686	.0762
9	.0762	.1029	.0857		.061	.0686	.0762
10	1.9662	2.3663	.1029		.061	1.4575	1.448
11	2.0424	2.5377	.0857			2.1262	1.6461
12	2.2977	2.2558	.061		.061	2.4006	1.6156
13		2.1643	.061	.0686	.061	2.4863	
14	2.2805	2.0729	.061	.0686	.061	2.4863	1.3717
15	2.2805	2.0881	.061	.0686	.061	2.4348	1.448
16	2.3148	2.0119	.061	.0686		2.3491	1.6309
17	2.2634	2.2119		.0686		2.332	1.5546
18	.0857	.1029	.061	.0686		.0857	.0762
19	.1029	.1029	.061	.0686	.061	.0762	.0762
20	.1029	.1029	.061	.0686	.0686	.0762	.0762
21	.1029	.1029	.061	.0686	.0686	.0762	.0762
22	.1029	.1029	.061	.0686	.0686	.0914	.0762
23	.1029	1.7833	1.4784	1.4918	.0686	.0762	.0762
24	.0914	.1029	1.8519	1.5851	1.4918	.0686	.0762
Max	2.3148	2.5377	2.1605	1.8747	1.8861	2.4863	1.6461
Min	.0762	.1029	.061	.0686	.061	.0686	.0762
Avg	.7661	.9101	.8525	.8527	.7721	.8017	.5189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 202 / 11KV GANPATI MANDIR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.823					.8059
2		.823					.823
3	.7545	.823					.823
4	.7888	.8573					.823
5	.8916	.8916					
6	.9602	.8916					
7	.9602	.9602					
8	.9602	.9602					
10			1.166	1.2517	.9259	.9602	
11			1.3717	1.2517		1.0288	
12			1.3717		1.2689	1.166	
13			1.3717	1.2689	1.1317	1.166	
14			1.3717	1.3375	1.2517	1.0974	
15			1.3889	1.166	1.0974	1.166	
16			1.3717	1.1317		1.166	
17			1.3032	1.1317		1.0974	
23	.823					.8573	.4801
24	.7545	.823					.7545
Max	.9602	.9602	1.3889	1.3375	1.2689	1.166	.823
Min	.7545	.823	1.166	1.1317	.9259	.8573	.4801
Avg	.8616	.8725	1.3396	1.2199	1.1351	1.0783	.7516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 203 / SHIRADWAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.2743	.6173	.5792	.6173	.6687	.5639
2	.5487	.2743	.6516	.5792	.6173	.6516	.5182
3	.5487	.2743	.6516	.5792	.6173	.6516	.5182
4	.5487	.3086	.583	.5792	.6173	.6173	.5182
5	.5487	.3429	.6516	.5792	.4801	.6516	.5182
6	.5487	.3429	.6516	.6401	.4801	.6173	.5792
7	.5487	.3429	.3429	.5487	.6173	.583	.5792
8	.5335	.5487		.6097	.6173	.6859	.6097
9	.5792	.6859		.7164	.6173	.6859	.7011
10	.5792	.6859	.823	.7011	.5487	.6859	.6401
11	.5487	.823	.823	.7316		.6859	.7011
12	.5487	.6706	.6706	.7716	.7316	.7545	.6401
13	.6173	.4572	.4268		.4877	.5487	.3353
14		.5487	.5487	.6516	.5792	.7202	.503
15		.6401	.7316	.823	.4572	.6859	.6097
16	.3429		.7316	.2229		.6859	.5487
17	.3601	.703	.7316	.5487		.823	.5944
18	.3429	.7545	.7316	.7716		.6173	.5487
19	.3429	.6859	.6706	.6859	.4877	.5487	.503
20	.3429	.6344	.6401	.6859	.6001	.5487	.6706
21	.3429	.2743	.7011	.7545	.6859	.6097	.6097
22	.3429	.4973	.6401	.6859	.6687	.6401	.6097
23	.2058	.6344	.6401	.6859	.6687	.6097	.6097
24	.6097	.2743	.6173	.6097	.6859	.6859	.5944
Max	.6173	.823	.823	.823	.7316	.823	.7011
Min	.2058	.2743	.3429	.2229	.4572	.5487	.3353
Avg	.4764	.5078	.6490	.6409	.5941	.6526	.5760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 204 / ABDUL LAT AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8519	1.5947	.2401	.2229	.2229	.2572	
2	1.8519	1.5947	.2401	.2229	.2229	.2915	
3	1.8519	1.6461	.2401	.2229	.2229	.2915	1.4575
4	1.989	1.989	.2572	.2401	.2229	.2915	1.4575
5	1.8519	1.989	.2401	.2229	.2229	.2743	1.4575
6	1.869	2.4006	.2401	.2229	.2229	.2915	
7	2.2462	2.5549	.2401	.1886	.2229	.2401	
8	2.4006	.2229	.2058	.2572	.2572	.2743	
9	2.3834	.2229	.2229	.2401	.2401	.2743	.2058
10	.2572	.2229	3.4294	3.4808	3.3265	2.8978	.2401
11			3.6694	3.738		3.4637	.2229
12	.1886	.1886	3.738	3.5322	3.6523	3.3608	.2401
13	.2058	.2401	3.5665	3.4808	3.6523	3.1893	.1715
14	.2229	.2743	3.5322	3.5494	3.6351	3.1207	.1715
15	.2229	.2401	3.5151	3.5151	3.5494	3.0864	.1886
16	.2572	.1981	3.4979	2.8464		3.0178	.1886
17	.1886	.3086				2.7949	.1886
18	.2229	.2058	.2229	.1886		.2401	.2058
19	.2229	.2572	.2572	.1886	.3601	.2743	.2058
20	.2572	.3086	.2915	.2401	.2915	.2743	.2572
21	.2743	.3086	.2915	.2401	.2915	.2743	.2743
22	.2743	.2915	.2915	.2401	.2915	.2572	.2572
23	1.5261	.2229	.2572	.2229	.2572	1.4746	
24	1.8519	1.5947	.2572	.2401	.2229	.2572	
Max	2.4006	2.5549	3.738	3.738	3.6523	3.4637	1.4575
Min	.1886	.1886	.2058	.1886	.2229	.2401	.1715
Avg	1.0639	.8294	1.2584	1.2062	1.0794	1.2696	.4347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.2915	.2743	.2915	.2915	.2058	.12
2	.3086	.2915	.2743	.3086	.2915	.2058	.12
3	.3086	.2915	.3086	.2915	.2915	.1886	.12
4	.2743	.2915	.2743	.3086	.2915	.1886	.12
5	.2743	.2915	.2743	.3086	.2915	.2058	.12
6	.2401	.2915	.2743	.3429	.2915	.2058	.12
7	.2401	.2743	.2915	.3944	.2229	.2229	.1372
8	.2572	.2743	.2743	.2401	.2743	.2572	.1372
9	.2401		.2572	.0857	.3258	.2572	.1372
10	.2572	.3258	.3086	.1543	.2743	.2915	.12
11	.2401	.3086	.2915	.0857		.2229	.1372
12	.2229	.3944	.2915	.0686	.3258	.2229	.1372
13	.2229	.3429	.2572	.0686	.2229	.2058	.12
14	.2743	.3944	.2401	.0686	.2572	.2058	.12
15	.2401	.3258	.2915	.0686	.2743	.2229	.1372
16	.2401	.3601	.2743	.2229			.1372
17	.2401	.3601	.2915	.2058		.2229	.1372
18	.2229	.3258	.2572	.2229		.1886	.12
19	.2401	.2915	.2572	.1886	.2572	.1543	.1372
20	.2743	.3086	.2743	.1886	.2572	.12	.1372
21	.3086	.3086	.3086	.2229	.2229	.12	.1372
22	.3086	.3258	.3086	.2229	.2058	.1029	.1372
23	.2572	.2915	.3772	.2915	.2572	.12	.1372
24	.3601	.3429	.3086	.2743	.2915	.2229	.1372
Max	.3601	.3944	.3772	.3944	.3258	.2915	.1372
Min	.2229	.2743	.2401	.0686	.2058	.1029	.12
Avg	.2651	.3176	.2850	.2136	.2709	.1983	.1300



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 206 / 11 KV SOCIETY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1372	.2058	.2058	.2058	.2058	.1886
2	.2058	.1372	.1886	.1715	.2058	.1886	.1715
3	.2058	.1372	.1886	.1715	.2058	.1886	.1524
4	.2058	.1372	.2058	.1715	.2058	.1886	.1715
5	.1715	.1029	.2058	.1715	.2058	.1886	.1543
6	.1715	.1029	.2401	.1715	.2229	.2058	.1715
7	.2229	.1715	.2229	.1886	.2229	.1886	.2229
8	.2058	.2058	.2058	.2229	.2572	.2572	.2572
9	.2229	.3086	.1715	.2915	.3086	.2572	.2572
10	.2229	.2915	.2915	.3258	.3772	.3601	.3258
11	.2058	.3772	.2743	.2743		.3944	.3601
12	.1886	.4458	.3086	.3258	.3601	.3086	.3086
13	.1886	.2058	.1715	.3086	.2915	.2915	.2401
14	.2572	.2229	.2572	.2572	.2915	.2743	.2915
15	.1886	.2743	.2743	.3086	.2401	.2915	.3429
16	.2058	.2058	.2572	.3429		.3258	.3086
17	.1715	.2572	.2572	.3258		.2915	.3086
18	.1543	.2572	.2743	.3258		.2401	.3429
19	.12	.2058	.2743	.3258	.2401	.2572	.3086
20	.12	.2058	.2401	.2915	.2229	.2572	.2572
21	.12	.1886	.2229	.2915	.2572	.1886	.1886
22	.12	.1886	.1715	.2058	.2229	.1543	.1886
23	.1715	.1715	.1715	.2058	.2058	.2229	.1886
24	.2401	.1543	.1886	.2058	.2058	.2058	.2058
Max	.2572	.4458	.3086	.3429	.3772	.3944	.3601
Min	.12	.1029	.1715	.1715	.2058	.1543	.1524
Avg	.1872	.2122	.2279	.2536	.2478	.2472	.2464

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 402 / I-CO SPIN FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2867	4.2295	4.1152	4.1152	4.2867	4.2295	3.7723
2	4.2867	4.2295	4.1724	4.0581	4.2867	4.1152	3.8866
3	4.2867	4.2295	4.1724	4.1152	4.2867	4.1152	3.7151
4	4.2867	4.2295	4.2295	4.0009	4.2867	4.2295	3.7723
5	4.2867	4.1152	4.0009	4.0009	4.2295	4.2295	4.0009
6	4.2295	4.0009	3.9438	4.0581	4.1152	4.1152	3.8866
7	4.1724	4.0581	4.1724	4.2295	4.6868	4.3439	4.4582
8	4.5725	4.5725	4.2867	4.0581	4.3439	4.8011	4.1724
9	4.0009	4.2295	3.9438	4.2295		4.401	3.8866
10	4.0009	4.0581	4.1152	4.2295		4.401	4.0581
11	3.658	4.4582	4.6296	4.6868		4.2867	4.4582
12	4.0581	4.0581	4.1152	4.3439	4.1152	4.5725	4.0581
13	3.8866	4.5153	3.7723	4.2867	3.8866	4.1152	4.1152
14	4.4582	4.1724	3.8866	4.0009	4.4582	4.401	4.1152
15	4.2295	4.1152	4.5153	3.7723	4.3439	4.2867	4.5725
16	4.2867	3.8866	4.2295	4.401		4.2867	4.5725
17	3.7723	4.5725	3.9438	3.8866		4.5725	4.3439
18	3.7151	3.7151	4.1152	3.858		4.401	4.7439
19	3.3951	3.8866	4.3439	3.7551	3.4865	4.3439	4.0009
20	3.7723	3.658	3.9438	4.401	4.0581	4.3439	4.4582
21	3.7723	4.0581	4.2295	3.6523	4.5153	4.2295	4.1152
22	3.8866	4.0581	4.1152	4.1724	3.9438	4.6868	4.1152
23	4.2295	4.4582	4.3439	4.5153	4.6296	4.6868	
24	4.401	4.3439	4.1724	4.0009	4.5153	4.2295	3.9438
Max	4.5725	4.5725	4.6296	4.6868	4.6868	4.8011	4.7439
Min	3.3951	3.658	3.7723	3.6523	3.4865	4.1152	3.7151
Avg	4.0805	4.1629	4.1462	4.1178	4.2486	4.3510	4.1401

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 703 / 33 KV MAIN VCB

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	2.9721
Max	2.9721
Min	2.9721
Avg	2.9721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 201 / 11 KV SAHARANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487					.5624	.5668
2	.5182					.5468	.5668
3	.5182					.5312	.5506
4	.5182					.5155	.5344
5	.4877					.5155	.5344
6	.4572					.5155	.5344
7	.442					.5468	.5506
8	.5182				.5571	.5937	.5668
9	.6097				.6706	.6249	.6874
10	.6097			.6882	.7011		.7209
11	.5944		.7537	.6882	.6859	.7865	.7537
12	.5668			.6226	.6249		.6882
13	.3887			.4588	.5668	.5898	.5898
14	.3315		.4588	.5898	.506	.5243	.6226
15	.3277			.6554	.6097		.6882
16	.3353		.7373	.6554	.6405	.7209	.6882
17	.3601			.6554	.7186		.6882
18	.3292			.6554	.679		
19	.2012			.6554	.6562	.3563	
20	.2195				.6481	.5693	
21	.2561				.6249	.6483	
22	.3109			.6226	.6249	.6325	.6226
23	.3109				.571	.6325	.6226
24	.5487	.3292				.5937	.5851
Max	.6097	.3292	.7537	.6882	.7186	.7865	.7537
Min	.2012	.3292	.4588	.4588	.506	.3563	.5344
Avg	.4295	.3292	.6499	.6316	.6303	.5793	.6181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 202 / 11 KV BIRDEV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2186					1.1385	1.1069
2	1.1873					1.1385	1.1203
3	1.1248					1.1385	1.1203
4	.9842					1.1385	1.1336
5						1.1385	1.1336
6	1.0623					1.1702	1.2146
7	1.1248					1.2018	1.2146
8	1.2498				1.3077	1.2944	1.2003
9	1.3435				1.2955	1.4074	1.3717
10	1.3117			1.2803	1.3717		1.4327
11	1.2955		1.6263	1.3108	1.3717	1.643	1.5242
12	1.1574			1.2498	1.2346		1.4632
13	1.0526			.6249	1.1336	.9389	.7926
14	1.2146		1.4754	1.0974	1.2967	1.4754	1.2803
15	1.2146			1.1736	1.406		1.3413
16	.9831		1.5424	1.1888	1.406	1.576	1.2803
17	.8718			1.2041	1.4685		1.0974
18	.7842			1.3077	1.4548		
19	.5975			1.291	1.3125	.8907	
20	.7095				1.3125	1.2955	
21	.8215				1.3283	1.4232	
22	.9335			1.2742	1.3283		1.4251
23	.8962				1.2334	1.2651	1.3413
24	1.2654	.8962				1.1544	1.186
Max	1.3435	.8962	1.6263	1.3108	1.4685	1.643	1.5242
Min	.5975	.8962	1.4754	.6249	1.1336	.8907	.7926
Avg	1.0611	.8962	1.5480	1.1821	1.3289	1.2460	1.2390

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 203 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7206					2.753	2.6825
2	2.6886					2.7206	2.6825
3	2.6886					2.672	2.7435
4	2.6886					2.6397	2.7435
5	2.4006					2.5911	2.7435
6	2.4646					2.5911	2.8292
7	2.5606					2.6235	2.7978
8					2.4143	2.672	
9	2.6886				2.9492	3.0445	3.0312
10	3.0769			1.6057	2.9959		3.0087
11	3.1093		3.1352	1.4003	2.9959	3.1255	3.1047
12	2.9835			1.3443	2.8673		3.0087
13	2.5149			.8962	2.6825	2.4813	2.3045
14	2.6825		2.6825	.9335	2.8178	2.8669	2.8166
15	2.9835			.9709	2.9835		2.8487
16	2.9492		3.0849	.9709	2.9492	3.1017	2.7846
17	2.8502			.9709	2.8178		2.7206
18	2.6566			.8817	2.7854		
19	2.652			.8551	2.7854	2.0119	
20	2.652					2.4863	
21	2.652				2.7206	2.9835	
22	2.652			2.2131	2.672	3.0178	2.6825
23	2.7183				2.7854	2.934	2.9508
24	2.7206	2.7183				2.7854	2.8502
Max	3.1093	2.7183	3.1352	2.2131	2.9959	3.1255	3.1047
Min	2.4006	2.7183	2.6825	.8551	2.4143	2.0119	2.3045
Avg	2.7284	2.7183	2.9675	1.1857	2.8148	2.7422	2.8071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 205 / CHANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8			.905		
10	.9448				.6478
11	.9878			1.267	.8097
12	1.004				.8097
13	1.0526			1.3575	.6154
14	1.0526			1.3394	.583
15	1.1336				.5182
16	1.1336			1.3937	.5182
17	.9282				.5182
19				.9431	
23	.7545				
24		.8402			
Max	1.1336	.8402	.905	1.3937	.8097
Min	.7545	.8402	.905	.9431	.5182
Avg	.9991	.8402	.905	1.2601	.6275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 206 / 11 KV ABHAR PHATA  
INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0994					3.131	2.9235
2	3.0994					3.131	2.9235
3	3.062					3.1121	3.0178
4	3.062					3.0933	3.0178
5	3.062					3.131	2.9235
6	3.0247					3.1687	3.0178
7	2.9874					3.1687	3.0178
8	3.0247				3.1687	3.1687	3.0178
9	3.062				3.1121	3.131	3.1499
10	3.1121			2.7915	3.1121		3.1687
11	3.1121		3.2065	2.8292	3.2065	3.131	3.2065
12	3.0178			2.7538	3.0178		3.1687
13	2.8292			2.6406	2.9235	3.131	3.0178
14	3.1121			2.7161	3.2065	3.1687	3.1687
15	3.1121			2.7915	3.2065		3.2819
16	3.2065		3.3196	2.7915	3.1121	3.2819	3.2442
17	3.1121			2.7349	3.1121		3.2065
18	3.0556			2.7915	3.1121		
19	2.9424			2.7538	3.1121	3.1121	
20	2.9801				3.1121	3.1121	
21	3.0178				3.1687	3.1121	
22	3.0556			3.1687	3.2065	3.1121	3.0933
23	3.0178				3.2065	3.1121	.7167
24	3.0994	3.0178				3.131	3.0178
Max	3.2065	3.0178	3.3196	3.1687	3.2065	3.2819	3.2819
Min	2.8292	3.0178	3.2065	2.6406	2.9235	3.0933	.7167
Avg	3.0528	3.0178	3.2631	2.7966	3.1310	3.1389	2.9650



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 207 / 11 KV SONAR MALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.1191	.7459
2				1.1191	.7459
3				1.1317	.7459
4				1.1191	.7459
5				1.153	.7459
6				1.153	.7625
7				1.153	.779
8			1.2742	1.2003	.7459
10	1.5384				
11	1.587				
12	1.6194	1.5592			
13	1.587				
14	1.5708				
15	1.5497				
16	1.5181	1.5424			
17	1.5181				
23			1.0974	.7865	
24				1.1191	.779
Max	1.6194	1.5592	1.2742	1.2003	.779
Min	1.5181	1.5424	1.0974	.7865	.7459
Avg	1.5611	1.5508	1.1858	1.1054	.7551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 208 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2616					1.2125	1.2146
2	1.2289					1.2125	1.2146
3	1.1797					1.1797	1.2146
4	1.1305					1.1797	1.2146
5	1.1797					1.1797	1.2146
6	1.2289					1.1961	1.2955
7	1.2616					1.1961	1.2955
8	1.4419				1.0159	1.1961	1.2955
9	1.5074				1.3441		1.5023
10	1.4232			.9831	1.4232		1.5565
11	1.3916		1.5402	.9503	1.439	1.5729	1.5893
12	1.186			.8848	1.2803		1.5238
13	1.1069			.6554	1.1336	1.3108	1.278
14	1.186		1.3108	.6554	1.2803	1.4091	1.4419
15	1.3441			.6554	1.4232		1.5238
16	1.3441		1.5238	.6882	1.4232	1.5402	1.5565
17	1.3757			.6882	1.4864		1.6057
18	1.3108			.6226	1.5074		
19	1.1305			.5243	1.4419	.9717	
20	1.1469				1.3927	1.1336	
21	1.1469				1.3108	1.3603	
22	1.1797			.8848	1.2616	1.3603	1.3435
23	1.1797				1.2944	1.3123	1.3435
24	1.3108	1.1797				1.2289	1.2955
Max	1.5074	1.1797	1.5402	.9831	1.5074	1.5729	1.6057
Min	1.1069	1.1797	1.3108	.5243	1.0159	.9717	1.2146
Avg	1.2576	1.1797	1.4583	.7448	1.3411	1.2640	1.3760

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 209 / 11 KV JAIHIND FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413					.7545	.6979
2	.6413					.7545	.679
3	.6413					.7167	.679
4	.6413					.7167	.679
5	.6413					.7167	.679
6	.6602					.7167	.679
7	.679					.7167	.6979
8	.6413				.7167	.679	.7167
9	.6036				.8488	.7922	.8299
10	.7167			.6413	.8676		.7922
11	.7167		.7922	.679	.8488	.8676	.8299
12	.679			.6413	.7545		.8299
13	.6036			.6036	.6979	.679	.7922
14	.679		.7545	.6036	.7733	.8676	.8299
15	.7167			.6036	.811		.8676
16	.7167		.8299	.6036	.8299	.8299	.8676
17	.7167			.6036	.8299		.8299
18	.7167			.6036	.7922		
19	.679			.6036	.7545	.679	
20	.679				.7545	.7545	
21	.679				.7545	.7922	
22	.679			.679	.7545	.7545	.7545
23	.679				.7922	.7545	.7922
24	.679	.679				.7545	.7167
Max	.7167	.679	.8299	.679	.8676	.8676	.8676
Min	.6036	.679	.7545	.6036	.6979	.679	.679
Avg	.6719	.679	.7922	.6242	.7863	.7525	.762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 201 / 11KV TELEPHONE EXCHANGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1715	.1524	.1715	.1715	.1524	
2	.1867	.1524	.1524	.1524	.1524	.1524	
3	.1867	.1524	.1524	.1524	.1524	.1524	
4	.1867	.1524	.1524	.1715	.1524	.1524	
5	.1867	.1715	.1715	.1715	.1715	.1715	
6	.1867	.1905	.1715	.1715	.1715	.1715	
7	.1867	.2096	.1524	.1715	.1715	.1715	
8	.1867	.1905	.1524	.1715		.1715	
9	.1715	.1905	.1905	.1524		.1905	
10	.2286	.2096	.1905	.1715		.1867	.1715
11	.2477	.2477	.1905	.1524	.1715	.2054	.1715
12	.2477	.2286	.1905	.1715	.1905	.1867	.1905
13	.1905	.2096	.1715	.1715	.1715	.1867	.1905
14	.1715	.2096	.1715	.1524	.1715	.1867	.1524
15	.2096	.2477	.1905	.1715	.1905	.1867	.2096
16	.2286	.1715	.1905	.1715	.1905	.2054	.2096
17	.2096	.1905	.1905	.1715	.1905	.2241	.2096
18	.2286	.1715	.1715	.1524	.1715	.1867	.2286
19	.2096	.1715	.1715	.1905	.1715	.2241	.2096
20	.1905	.1715	.1524	.1905	.1524	.1867	.1715
21	.2096	.1715	.1715	.1715	.1524	.1867	.1905
22	.1905	.1524	.1715	.1715	.1715		.1905
23	.2096	.1524	.1524	.1524	.1715		.1905
24	.4763	.1715	.1524	.1715	.1715	.1715	
Max	.4763	.2477	.1905	.1905	.1905	.2241	.2286
Min	.1715	.1524	.1524	.1524	.1524	.1524	.1524
Avg	.2138	.1858	.1699	.1675	.1706	.1823	.1919

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 202 / 11 KV KHOTWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9511	.8215	.9335	.9145	.8215	.9335	
2	.8779	.8402	.8962	.8764	.7842	.8962	
3	.8048	.7842	.8962	.8383	.7468	.8962	
4	.7682	.7655	.9149	.8573	.7095	.9335	
5	.8413	.7842	.9149	.8764	.6722	.9335	
6	.8779	.8589	.9522	.8383	.7468	.9335	
7	.8779	.9149	1.0269	1.0288	.8029	1.0082	
8	.8779	1.0082	.9896	.7621	.8962	.9896	
9	1.0269	1.1389	1.1016	.8383	1.0082	1.0082	
10	1.0456	1.1576	1.2136	.8573	1.0642	1.0608	1.2136
11	1.1576	1.1763	1.2955	.7468	1.1576	1.0791	1.1203
12	1.0829	1.0829	1.1431	.7095		.9877	1.0642
13	.9709	.9709	1.0669	.6722		.8779	.6348
14	1.0829	.9522	.9526	.7095	1.1203	.9511	1.0456
15	1.0082	1.1203	1.105	.7655	1.1576	.9877	1.1763
16	1.0456	1.1763	1.105	.7468	1.1949	.9511	1.1203
17	.9335	1.1576	.9907	.7655	1.2136	.8779	1.1949
18	.9896	1.1203	1.0288	.7095	1.1203	.823	1.1763
19	1.0456	1.1203	1.0669	.6722	1.2323	.8779	1.1203
20	1.0829	1.0456	1.105	.7468	1.0456	.9145	1.0082
21	1.0456	1.0456	1.0669	.7842	1.0456	1.0608	1.0082
22	.9709	1.0642	1.0669	.8589	1.0082		1.0456
23	.9335	.9896	1.0098	.8962	.9709		.9896
24	.9145	.8962	.9709	.9907	.8589	.9335	
Max	1.1576	1.1763	1.2955	1.0288	1.2323	1.0791	1.2136
Min	.7682	.7655	.8962	.6722	.6722	.823	.6348
Avg	.9672	.9997	1.0339	.8109	.9717	.9507	1.0656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 203 / 11 KV SARITA POLYMER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4355	3.315	3.4675	3.3532	3.3532	3.3913	
2	3.2861	3.2769	3.4484	3.315	3.315	3.2769	
3	3.2114	3.2388	3.4294	3.3341	3.2769	3.2388	
4	3.2487	3.2007	3.3913	3.3532	3.2388	3.1436	
5	3.3608	3.2388	3.3913	3.3532	3.1626	3.0864	
6	3.3234	3.2769	3.5056	3.4294	3.1436	3.2007	
7	3.2674	3.3341		3.4294	3.2007	3.296	
8	3.2487	3.5437	3.3532	3.1245	3.2388	3.296	
9	3.4294	3.3532	3.5437	1.8861	3.3341	3.4675	
10	3.5246	3.5246	3.5246	2.2862	3.5246	3.4728	3.5437
11	3.7342	3.7342	3.5437	1.8671	3.4865	3.5101	3.5246
12	3.4675	3.5056	3.3913	1.7718	3.4103	3.4355	3.5437
13	3.5437	3.4484	3.5056	1.6766	3.3722	3.1927	3.4675
14	3.4294	3.5056	3.4675	1.6194	3.0102	3.2861	3.6199
15	3.3913	3.5818		1.5051	3.5818	3.3981	.6859
16	3.4294	3.4484	3.4865	1.6004	3.6199	3.5101	3.6389
17	3.5437	3.3913	3.3532	1.5242	3.4865	3.4728	3.5056
18	3.6389	3.5627	3.4294	1.5623	3.5056	3.4915	3.6199
19	3.5818	3.4865	3.4675	1.6004	3.6008	3.3794	3.658
20	3.5437	3.4484	3.5056	2.8578	3.4865	3.2861	3.4865
21	3.5818	3.5056	3.5437	3.2007	3.4484	3.4728	3.4294
22	3.7151	3.5818	3.5246	3.315	3.4294		3.4103
23	3.4675	3.5627	3.4675	3.3532	3.4484		3.5246
24	3.3981	3.3532	3.5246	3.5056	3.3913	3.4294	
Max	3.7342	3.7342	3.5437	3.5056	3.6199	3.5101	3.658
Min	3.2114	3.2007	3.3532	1.5051	3.0102	3.0864	.6859
Avg	3.4501	3.4341	3.4666	2.5760	3.3778	3.3516	3.3328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 204 / RENUKANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2314	1.5565	2.2624	2.2862	2.3891	2.1357	
2	2.1238	1.5203	2.1719	2.3243	2.3529	2.0814	
3	1.9753	1.4842	2.1357	2.21	2.3167	2.0271	
4	1.9387	1.5203	2.1357	2.2862	2.2805	1.9909	
5	2.0119	1.5927	2.1538	2.21	2.1719	1.9909	
6	1.9753	1.6289	2.1719	2.2481	2.1357	2.0271	
7	2.0302	1.6651	2.3167	2.3624	2.0995	2.1719	
8	1.957	1.6289	2.1719	2.0957	2.1357	2.0995	
9	2.2081	2.3891	2.5339	2.0576	2.3891	2.6063	
10	2.3167	2.5701	2.5339	2.4387	2.4615	2.5972	2.3891
11	2.2443	2.6063	2.8959	2.0814	2.3891	2.6337	2.4977
12	2.4434	2.6063	2.6673	2.0271	2.5339	2.4143	2.5339
13	2.3529	2.0271	2.5149	1.5927	2.0271	2.2862	1.8099
14	2.2624	2.1719	2.4387	1.6289	2.2443	2.4143	2.0995
15	2.2262	2.6063	2.5911	1.6651	2.4977	2.4874	2.2443
16	2.3167	2.5339	2.5911	1.6108	2.5339	2.524	2.2805
17	1.9004	2.5339	2.5149	1.9909	2.4615	2.4508	2.2443
18	1.7375	2.4615	2.4387	2.0814	2.3891	2.4143	2.3167
19	1.9909	2.4615	2.3243	2.1719	2.5339	2.3069	2.2443
20	1.8823	2.3167	2.2862	2.2624	2.2443	2.2314	2.1719
21	1.7737	2.3348	2.2862	2.3167	2.19	2.4143	2.2624
22	1.6651	2.4615	2.3243	2.3891	2.2443		2.3167
23	1.7013	2.3167	2.2862	2.3167	2.2443		2.2443
24	2.3045	1.5927	2.4006	2.3624	2.4253	2.1719	
Max	2.4434	2.6063	2.8959	2.4387	2.5339	2.6337	2.5339
Min	1.6651	1.4842	2.1357	1.5927	2.0271	1.9909	1.8099
Avg	2.0654	2.1078	2.3812	2.1257	2.3205	2.2944	2.2611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 205 / 11 KV Sanmati Vg Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	1.4998	2.0119	2.0957	1.829	2.0485	
2	2.1238	1.4632	1.9753	2.0386	1.7924	2.0119	
3	2.0485	1.4266	1.9753	2.0195	1.7558	1.9204	
4	2.0119	1.39	1.957	2.0005	1.7193	1.8656	
5	2.1216	1.5364	2.0119	2.0576	1.7924	1.8656	
6	2.1948	1.6095	2.0668	2.1719	1.829	2.0119	
7	2.1216	1.8107	2.0302	1.7147	1.8839	1.957	
8	1.829	1.9022	2.0851	1.6575	1.9753	1.9753	
9	2.0485	2.2314	2.4326		2.1765	2.1948	
10	2.1948	2.4143	2.4874	1.2384	2.2862	2.2862	2.396
11	2.3228	2.524	2.2862	1.0608	2.524	2.3411	2.3411
12		2.3777	2.2481	.9145	2.3411	2.1216	2.2497
13		1.829	2.0957	.8779	1.8298	1.9753	1.7741
14	1.9936	2.0851	2.1338	.9145	2.2131	2.1582	2.1582
15	2.1033	2.2862	2.3624	.9877	2.3411	2.1948	2.2862
16	2.2131	2.4143	2.4387	.8962	2.3777	2.1216	2.3777
17	1.829	2.2131	2.3624	.9877	2.3411	2.1033	2.3228
18	1.7558	2.2131	2.21	1.0242	2.1582	2.0119	2.2497
19	1.9387	2.2314	2.1338	1.0608	2.1216	1.9753	2.1033
20	1.9022	2.3228	2.1148	1.7193	2.1216	1.9387	2.0302
21	1.8656	2.2314	2.1338	1.7924	2.1033	2.1765	2.1033
22	1.8839	2.2862	2.1719	1.8473	2.0851		2.1582
23	1.7924	2.1948	2.21	1.829	2.1216		2.1765
24	2.1582	1.5364	2.1765	2.0576	1.8656	2.0851	
Max	2.3228	2.524	2.4874	2.1719	2.524	2.3411	2.396
Min	1.7558	1.39	1.957	.8779	1.7193	1.8656	1.7741
Avg	2.0253	2.0012	2.1713	1.5202	2.0660	2.0609	2.1948



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 206 / 11 KV SARADA FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.726		2.7625	2.7625	2.6292	2.7054	
2	2.6513	2.7435	2.7435	2.7816	2.5911	2.6673	
3	2.5766	2.7816	2.7435	2.8387	2.553	2.6673	
4	2.5766	2.8197	2.7816	2.7435	2.5149	2.6292	
5	2.6139	2.7435	2.8197	2.7816	2.4768	2.6482	
6	2.6513		2.7816	2.8197	2.4387	2.6482	
7	2.6886		2.8197	2.7435	2.4768	2.6101	
8	2.6513	2.8578	2.6673	2.7816	2.7054	2.6673	
9	2.8197	2.7625	2.8006	1.9052	2.8006	2.7244	
10	2.7816	3.0293	2.9531	1.7718	2.9912		2.934
11	3.0102	3.0674	2.934	1.6766	3.0674		2.9721
12	2.8578	2.8959	2.8197	1.7147	2.9531		2.9531
13	2.7625	2.915	2.7816	1.7337	2.6673		2.7816
14	2.8197	2.8959	2.8578	1.6766	2.934		3.0293
15	2.8578	2.9912	3.0102	1.7718	3.0102		2.9912
16	2.934	2.9531	2.934	1.6956	3.0293		3.0293
17	2.8578	2.915	2.9721	1.8671	3.0293		3.3722
18	2.915	2.934	2.934	1.829	2.7625		2.8959
19	2.8578	2.8578	2.8578	1.8671	2.8769		2.8959
20	2.8197	2.8387	.9907	2.0957	2.7625		2.7244
21	2.8578	2.8197	2.8578	2.3815	2.8387		2.7625
22	2.8769	2.8387	2.7816	2.572	2.8578		2.7054
23	2.7816	2.8769	2.8197	2.6292	2.7816		2.8578
24	2.6886	2.6673	2.8387	2.7816	2.6673	2.7625	
Max	3.0102	3.0674	3.0102	2.8387	3.0674	2.7625	3.3722
Min	2.5766	2.6673	.9907	1.6766	2.4387	2.6101	2.7054
Avg	2.7764	2.8669	2.7610	2.2592	2.7673	2.6730	2.9218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 207 / 11 KV MANAPASANT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0911	1.9433	2.1338	2.0576	1.5623	2.0957	2.21
2	2.0165	1.9052	2.0576	2.0957	1.5242	2.0386	2.1338
3	1.9791	1.8671	2.0005	2.0195	1.4861	1.9433	2.0576
4	1.9418	1.829	1.9433	2.0386	1.448	1.9052	2.0957
5	1.9791	1.8671	1.9433	2.0195	1.4861	2.0005	
6	2.0165	1.9052	2.0957	2.0576	1.5242	2.0957	
7	2.0538	1.9814	2.21	1.9433	1.5623	2.1719	
8	2.0165	1.9433	2.0195	1.829	1.5242	2.0576	
9	2.2862	2.2862	2.4387	1.4861	1.9814	2.2672	
10	2.4387	2.4387	2.3624	1.3336	2.21	2.4387	
11	2.4006	2.4768	2.553	1.2955	2.4006	2.5149	.9145
12	2.5149	2.4006	2.4768	1.2574	2.2862	2.3815	2.4006
13	2.4387	2.1719	2.3243	1.2193	2.0767	2.21	2.2481
14	2.3243	2.3053	2.21	1.1812	2.2672	2.3243	2.2672
15	2.2862	2.4958	2.1338		2.3053	2.2481	2.4387
16	2.4006	2.4387	2.3815	1.2003	2.3624	2.2862	2.4006
17	2.2481	2.3624	2.3243	1.1431	2.3053	2.3243	2.4387
18	2.2862	2.3053	2.21	1.1812	2.191	2.21	2.1338
19	2.4387	2.2862	2.2481	1.105	2.1719	2.1338	2.0576
20	2.0957	2.191	2.0957	1.2955	2.1338	2.191	1.9814
21	2.0195	2.1719	2.21	1.4098	2.1719	2.1338	2.0767
22	2.0576	2.21	2.1338	1.4861	2.2291	2.2481	2.21
23	2.0957	2.2672	2.0576		2.1719	2.1338	2.1719
24	2.2611	1.9814	2.2291	2.21	1.6004	2.1338	2.191
Max	2.5149	2.4958	2.553	2.21	2.4006	2.5149	2.4387
Min	1.9418	1.829	1.9433	1.105	1.448	1.9052	.9145
Avg	2.1953	2.1680	2.1997	1.5848	1.9576	2.187	2.1349

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 403 / 33 KV RUI-CHANDUR

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.4259	12.8601	14.9177	12.4486	13.4774	15.0206	13.8889
2	13.6831	12.8601	14.8148	12.7572	13.3745	14.6091	13.8889
3	13.3745	12.6029	14.712	13.3231		13.9918	13.786
4	13.5288	12.6029	14.4033	13.4774	13.5803	13.4774	13.786
5	13.8889	12.6543	14.3004	13.9403	13.8889	13.786	13.6317
6	13.4774	12.6543	14.3519	13.7346	13.9918	14.0947	13.4259
7	13.1687	13.5803	13.9918	14.1461	14.1461	14.6091	13.1173
8	11.1111	13.5288	13.6831	12.7058	14.5062	14.6091	12.963
9	13.6831	14.5062	14.6091	10.0823	14.3519	14.6091	14.4548
10	15.7408	16.4095	15.6379	10.391	14.3004	15.7408	14.5576
11	17.0268	17.5926	16.821	10.6996	14.8148	16.0494	15.535
12	15.9465	14.0432	11.1626	9.105	13.9403	14.3004	14.712
13	14.4033	14.1461	13.8889	8.642	12.5	14.1461	13.3745
14	16.1008	15.9465	15.1749	9.2078	13.6317	15.5864	13.9918
15	16.358	16.5638	16.358	9.465	14.3519	16.2552	14.9692
16	16.6152	16.5124	15.4321	9.3622	15.0206	15.8951	15.3292
17	15.9465		16.0494	9.2593	14.6605		14.5576
18	12.7572	15.072	15.6379	8.2305	14.0947		15.072
19	12.2428	13.9918	14.3004	9.1564	14.3519	11.2654	15.3292
20	11.9342	14.4033	13.5288	10.0309	13.8889	12.7572	14.1976
21	12.7058	14.4548	13.8375	12.2428	13.9918	13.786	14.3519
22	12.3457	14.3004	13.3745	12.2943	13.6317	13.5803	13.8375
23	13.3745	14.9692	13.1687	13.786	15.0206	13.8375	13.9918
24	8.2876	13.3745	14.8663	12.963	13.5288	15.072	13.8375
Max	17.0268	17.5926	16.821	14.1461	15.0206	16.2552	15.535
Min	8.2876	12.6029	11.1626	8.2305	12.5	11.2654	12.963
Avg	13.7970	14.3317	14.5426	11.3105	14.0455	14.4127	14.1911

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 404 / 33 KV KOROCHI

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9095	3.3951	4.4239	3.858	3.7037	3.7551	3.8066
2	3.9095	3.3951		3.8066	3.6008	3.6008	3.7551
3	3.8066	3.3436	4.1152	3.858	4.0638	3.6523	3.7551
4	3.858	3.678	4.0124	3.8066	3.7037	3.4979	3.7037
5	3.9609	3.3951	3.9095	3.7037	3.8066	3.5494	3.7037
6	3.9095	3.4979	3.7037	3.5494	3.8066	3.6523	3.8066
7	3.858	3.5494	3.858	3.4465	3.9095	3.8066	3.8066
8	3.8066	3.7037	3.9609	3.2922	3.8066	3.7551	3.9609
9	3.8066	4.0124	4.1152	3.3436	4.321	4.0124	4.2181
10	3.7551	3.9095	4.1152	3.4979	4.4239	3.9095	3.9609
11	3.858	4.2696	4.2696	3.3951	4.321	3.9609	4.2696
12	3.8066	3.9609	3.9609	3.4465	4.1152	4.321	4.1152
13	3.4979	3.6008	3.6523	3.2922	3.6008	3.8066	3.6523
14	3.6523	4.1152	3.9609	3.4979	4.1152	3.9095	3.8066
15	3.6523	4.2181	4.1152	3.6523	4.2181	4.2181	4.1152
16	3.7037	4.0638	4.2181	3.6523	4.321	4.2696	4.1667
17	3.3951		4.0124	3.6008	4.2696		4.0124
18	3.4465	4.1152	4.1152	3.4465	4.0124	.7202	4.0638
19	3.3951	2.8807	3.9609	3.4465	4.1152	3.8066	4.1152
20	3.4465	3.8066	3.9609	3.6008	4.0124	3.8066	3.6008
21	3.4979	3.9095	3.9609	3.858	3.9609	4.1152	4.1152
22	3.4979	4.0638	3.9095	3.8066	3.6008	3.9095	4.1152
23	3.4979	3.9609	3.858	3.8066	3.8066	3.8066	4.1152
24	7.1445	3.4979	4.4753	3.9609	3.8066	3.858	3.8066
Max	7.1445	4.2696	4.4753	3.9609	4.4239	4.321	4.2696
Min	3.3951	2.8807	3.6523	3.2922	3.6008	.7202	3.6008
Avg	3.8364	3.7540	4.0280	3.6094	3.9759	3.7261	3.9395

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 405 / 33 KV SAJANI-MANGAON

Feeder KV- 33 / INCOMING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	7.2017	7.7161	8.3333	7.0988	6.6873	8.179	6.1728
2	7.0473	7.7161	8.2305	7.4589	6.7901	8.0761	6.6873
3	7.2017	7.4589	7.8189	7.7161	6.893	8.8477	7.7161
4	7.0988	7.4589	7.7161	8.3333	6.9959	9.4136	8.4877
5	7.1502	7.4074	7.6132	8.7449	7.2017	9.7222	8.7449
6	6.9959	7.4074	7.5103	9.2593	7.5103	9.8766	8.8992
7	7.1502	7.356	2.3663	9.4136	9.7222	10.1338	9.3622
8	7.3045	7.6132	7.7161	9.3107	10.2366	10.1852	8.9506
9	7.0473	8.0247	7.9218	8.7963	9.5165	10.391	8.8992
10	7.3045	8.0761	7.9218	7.7161	9.8766	10.1852	7.7675
11	12.4486	12.8601	10.9568	5.8642	6.8416	7.9218	3.7551
12	12.3457	13.2202	11.7799	5.7099	7.2017	7.9733	3.3436
13	12.963	12.0371	10.8025	5.607	7.2017	7.5617	3.2922
14	13.3231	12.963	11.8313	5.5556	6.7901	6.5844	2.8807
15	12.6543	12.6543	12.8447	5.9156	7.0988	7.356	2.9835
16	13.2716	10.3395	11.9342	6.2757	7.9218	3.1893	7.7161
17	11.5226		9.465	8.7963	7.5617		7.9733
18	11.8313	11.214	9.2593	5.9671	7.3045	1.749	8.2305
19	8.1276	7.5103	8.1276	6.1728	7.6132	3.7037	7.4589
20	5.7613	7.8189	8.179	6.5844	7.4074	4.0124	8.1276
21	6.893	8.0247	7.3045	6.7387	7.6132	6.893	8.1276
22	8.0761	8.2305	6.893	6.7387	7.8704	6.7901	8.0247
23	7.9218	7.7675	6.7901	7.0473	7.6132	6.3786	7.6132
24	7.1445	7.8189	8.4362	6.6873	6.8416	7.9218	6.1728
Max	13.3231	13.2202	12.8447	9.4136	10.2366	10.391	9.3622
Min	5.7613	7.356	2.3663	5.5556	6.6873	1.749	2.8807
Avg	8.9911	9.0736	8.6564	7.2295	7.6796	7.5237	6.9745

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 406 / 33 KV INDUSTRIAL FEEDER

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7263	1.8004	1.9547	1.5432		1.0288	1.4403
2	1.3375	2.0576	2.3663	1.286		1.1317	2.0576
3	1.8004	2.0576	2.1605	.9774		.9259	2.0576
4	2.0062	1.8004	2.0576	1.1317		.823	2.1605
5	2.6749	1.8004	2.1605	1.0288		.9259	2.1605
6	2.5206	1.8519	2.3663	.9774		1.5432	2.2119
7	1.3889	1.8519	2.1605	.2058		1.2346	1.5432
8	2.4177	1.3375	1.8519	.3086		.823	2.6235
9	1.4403	1.1831	1.8004	.3086		.823	2.1091
10	.8745		1.3889		1.8519		2.2634
11	2.9321		2.8292		.2572	1.286	1.6975
12	2.6749		2.1605		.463	1.8004	2.1605
13	2.2634				1.286	1.6975	2.4177
14	1.749		2.2634		1.286	1.6975	2.572
15	1.9033		2.6749		1.0288	1.286	2.7263
16	2.0062		1.8004		.823	1.286	1.8004
17	1.8519		2.0576		1.3375	1.8519	.4115
18	.823		2.0062		.823	1.749	
19	1.3375		2.572		1.286	.7716	
20	1.8519		2.1091			.823	
21	1.286		.9774		1.1317	1.8519	
22	1.8519		2.572		1.286	1.8519	
23	1.8004		2.3148		1.1831	1.6461	
24	2.4691	1.8004	2.1605	2.0576		1.286	1.3889
Max	2.9321	2.0576	2.8292	2.0576	1.8519	1.8519	2.7263
Min	.823	1.1831	.9774	.2058	.2572	.7716	.4115
Avg	1.9162	1.7541	2.1202	.9825	1.0802	1.3106	1.9890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 202 / 11 KV ABDUL LAT GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0267	.1086	.0671	.0537	.0934	.0732
2	.0686	.0248	.112	.0671	.0549	.0747	.0732
3	.0701	.0263	.1006	.0671	.0354	.0754	.0709
4	.0686	.0274	.0914	.0671	.0362	.0739	.0739
5	.0686	.0286	.112	.0701	.056	.0747	.0934
6	.0732	.044	.1097	.0701	.0732	.0943	.0924
7	.0701	.0754	.0943	.1463	.1063	.1254	
8	.0701	.1075	.1448	.1132	.1357	.1612	
9	.1109	.1341	.1475	.1509	.1715	.181	.1387
10	.112	.1638	.1658	.1509	.1448	.1829	.1372
11	.1448	.2454	.2149	.0934	.2149	.2241	.1372
12	.1132	.2172	.1848	.1086	.2172	.2058	.1086
13	.1132		.1772	.0914	.1867	.1867	.1132
14	.112	.181	.1509	.0754	.1753	.1867	.1478
15	.112	.1463	.1086	.1029	.1463	.2263	.181
16	.0754	.1848	.1132	.0747	.1829	.2263	.208
17	.1132	.1753		.0924	.1848	.1696	.1433
18	.0526	.1052	.0671	.0754	.0924	.1052	.1097
19	.0312	.0934	.0663	.0526	.0943	.0943	.0732
20	.0419	.0934	.0671	.0314	.032	.0686	.0732
21	.0406	.1132	.0671	.0754	.0732	.0709	.1097
22	.0221	.1307	.0678	.0747	.0943	.0709	.1109
23	.0293	.1294	.0671	.0754	.1132	.0747	.112
24	.1052	.0244	.1097	.0671	.0754	.1132	.0739
Max	.1448	.2454	.2149	.1509	.2172	.2263	.208
Min	.0221	.0244	.0663	.0314	.032	.0686	.0709
Avg	.0786	.1086	.1152	.0859	.1146	.1317	.1116

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 204 / 11 KV GANGOBA MANDIR

GAOTHAN FEEDER

GOVTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.499	.6539	1.2072	.6733	.6485	.6687
2	.5571	.4854	.6299	1.0882	.6626	.6241	.5967
3	.5121	.439	.6516	1.0547	.583	.6241	.6036
4	.4858	.4458	.6539	1.14	.547	.6001	.724
5	.5304		.6554	1.2071	.5506	.631	.703
6	.5571	.5434	.6952	.6036	.6371	.631	.6836
7	.57	.5721	.6962	.6706	.6478	.6371	
8	.5636	.583	.6554	.6371	.6478	.6299	
9	.5571	.6516	.6802	.7042	.7362	.6554	.6962
10	.5967	.7209	.7209	.7042	.7773	.664	.7209
11	.6371	.7625	.7377	.6722	.7773	.7293	.7209
12	.5548	.7537	.6882	.6226	.7293	.6706	.6371
13	.5373	.6783	.6443	.5636	.6173	.6029	.5144
14	.543	.6588	.691	.5935	.7202	.6706	.5765
15	.5959	.7625	.7202	.6802	.7461	.7377	.6783
16	.6241	.7701	.6962	.664	.8048	.7625	.6962
17	.6135	.7432	.4908	.6562	.7362	.7712	.5441
18	.5258	.6554	.7122	.6226	.6958	.663	.7377
19	.5373	.6344	.6783	.5895	.6859	.6485	.6371
20	.5415	.6661	.6706	.5792	.6447	.6173	.5967
21	.5359	.7802	.7042	.7362	.7011	.7362	.7042
22	.5914	.7716	.6706	.7282	.7712	.7682	.7042
23	.5792	.7362	.6962	.7202	.7362	.703	.6554
24	.6371	.5175	.7087	1.2742	.6371	.6733	.691
Max	.6371	.7802	.7377	1.2742	.8048	.7712	.7377
Min	.4858	.439	.4908	.5636	.547	.6001	.5144
Avg	.5659	.6448	.6751	.7800	.6861	.6708	.6587



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 205 / 11 KV INDIRA NAGAR GOVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.2241	.5197	.5365	.5426	.5144	.503
2	.4641	.181	.4801	.4973	.5197	.5087	.4973
3	.431	.1867	.4424	.4694	.4973	.5028	.4428
4		.2263	.4424	.4359	.4733	.4908	.4372
5		.2641	.4694	.4915	.4801	.5144	.503
6		.2641	.503	.503	.4607	.5658	.4973
7		.2987	.5243	.503	.4854	.5426	
8		.362	.5921	.5636	.4641	.5898	
9	.5087	.5487	.6718	.663	.5898	.6316	.6154
10	.5365	.6371	.6958	.6706	.6554	.7362	.6009
11	.503	.6371	.7362	.6401	.7042	.7625	.6325
12	.4961	.6299	.5898	.5365	.6371	.6036	.5182
13	.3544	.5258	.5487	.503	.5487	.4694	.4458
14	.5014	.6036	.7293	.5087	.6299	.6371	.583
15	.4961	.6299	.7042	.6796	.6554	.663	.6154
16	.4207	.6371	.6882	.6401	.6226	.6036	.5864
17	.4075	.6642	.3696	.6009	.6401	.5967	.506
18	.3292	.6226	.57	.583	.6478	.5967	.6371
19	.3018	.5304	.663	.5571	.6325	.5937	.4973
20	.2561	.4973	.663	.5304	.57	.5365	.4973
21		.5533	.5967	.5426	.5765	.6173	.4973
22	.3018	.5487	.6036	.5487	.5548	.5365	.5636
23	.2829	.5365	.6036	.5487	.5316	.5535	.5636
24	.5121	.2641	.5487	.5636	.4748	.5144	.547
Max	.5365	.6642	.7362	.6796	.7042	.7625	.6371
Min	.2561	.181	.3696	.4359	.4607	.4694	.4372
Avg	.4213	.4614	.5815	.5549	.5664	.5784	.5358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 402 / TILAWANI MINOR

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 201 / 11KV TAKWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8596	.426	.6464	.7202	.7373	.7293	.7202
2	.7997	.3932	.6796	.6516	.6554	.6962	.7202
3	.7362	.3932	.6796	.6344	.6226	.663	.7202
4	.7011	.4096	.6796	.6173	.6226	.663	.6859
5		.3932	.6464	.6001	.6554	.663	.6687
6	.5434	.4096	.663	.6859	.6554		.6687
7	.7343	.4752	.7127	.7888	.7373	.663	.4458
8	.7011	.5735	.7293	.8453	.7865	.6962	.7545
9	.7712	.8356	.8785	.9088	.8684	.8048	.8745
10	.7602	.7865	.8785	.8482	.852	.8048	.823
11	.6626	.8573	.9503	.8453	.852	.8785	.8573
12	.6135	.8745	.9175	.8192	.9012	.8785	.7701
13	.547	.7545	.7045	.5801	.7127	.8238	.6226
14	.547	.8267	.7373	.8288	.7956	.823	.3768
15	.6464		.9339	.9282	.8951	.8916	.8684
16	.5636	.9431	.9503	.9779	.7956	.9448	.9175
17	.4973	.9602		.6133	.9431	.8785	.8684
18	.4144	.8916	.9012	.7459	.9431	.8402	.8192
19	.4641	.779	.852	.8453	.9259	.9088	.4424
20	.4475	.7888	.852	.8356	.8745	.8589	.7865
21	.426	.8122	.8745	.8356	.8785	.8951	.9259
22	.4752	.779	.8916	.8356	.8619	.8785	.8916
23	.4588	.8122	.8573	.8192	.8288	.823	.8402
24	.9114	.4424	.6962	.8059	.7701	.7293	.8059
Max	.9114	.9602	.9503	.9779	.9431	.9448	.9259
Min	.4144	.3932	.6464	.5801	.6226	.663	.3768
Avg	.6209	.6790	.7962	.7757	.7988	.8016	.7448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 202 / 11 KV PATIL MALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1984	.5636	1.0802	1.2178	1.0608	1.1934	1.086
2	1.1336	.4973	1.1831	1.182	1.0277	1.1934	1.3032
3	1.1498	.4641	1.1831	1.1393	1.0395	1.1603	1.3213
4	1.1012	.4641	1.1317	1.1218	1.0608	1.1271	1.2489
5		.5304	.9774	1.0867	1.0774	1.1105	1.086
6	.7611	.5304	.9945	1.1568	1.094	1.1105	1.1584
7	.9555	.5967	1.1317	1.2269	1.1934	1.21	1.3213
8	.8718	.9282	1.1831	1.262	1.2929	1.21	1.3575
9	.7125	1.2597	1.406	1.5432	1.4746	1.3592	1.4118
10	.7125	1.2929	1.3889	1.5249	1.4255	1.4083	1.5565
11	.7125	1.3032	1.4089	1.5249	1.326	1.442	1.5927
12	.6706	1.2548	1.3923		1.3923	1.326	1.3592
13	.5658	1.0174	1.0277	.8288	1.1403	1.1203	.9945
14	.6173	1.1317		1.326	1.267	1.2094	1.1065
15	.6859		1.326	1.4255	1.5384	1.5729	1.4255
16		1.406	1.4918	1.5083	1.6289	1.6632	1.3923
17	.5487	1.3763	1.1271	1.4586	1.5384	1.643	1.3923
18	.5316	1.3435	1.3923	1.3592	1.5384	1.4937	1.4255
19	.583	1.4373	1.4586	1.3923	1.5384	1.251	1.4255
20	.6344	1.3146	1.2266	1.2929	1.3937	1.307	1.2929
21	.663	1.3717	1.3717	1.2597	1.326	1.3575	1.5435
22	.6962	1.286	1.3717	1.326	1.2929	1.4299	1.531
23	.5967	1.3032		1.2929	1.326	1.3756	1.307
24	1.2955	.5636	1.2346	1.2269	1.1271	1.2763	1.3937
Max	1.2955	1.4373	1.4918	1.5432	1.6289	1.6632	1.5927
Min	.5316	.4641	.9774	.8288	1.0277	1.1105	.9945
Avg	.7908	1.0103	1.2495	1.2906	1.2967	1.3146	1.3347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	.57	.9774	.9995	.8619	.9389	.9259
2	1.1706	.5304	.9259	.9614	.8288	.9389	.8745
3	1.1222	.4973	.8745	.8848	.779	.9389	.8745
4	1.086	.4973	.8745	.8288	.7956	.9221	.8745
5		.5304	.823	.7865	.8288	.9221	.8402
6	.7316	.5304	.8573	.8619	.8288	.9221	.8573
7	1.0242	.6706	.9259	1.0159	1.0277	1.073	1.0288
8	1.0136	.8288	.9774	1.0814	.9945	1.1065	.9945
9	1.0242	1.2407	1.2689	1.2616	1.2266	1.1904	1.0288
10	1.0059	1.1934	1.278	1.2323	1.2597	1.2071	1.2689
11	1.1584	1.1873	1.4255	1.2498	1.326	1.291	1.3375
12	1.0498	1.2811	1.4255	1.2803	1.3592	1.291	1.2597
13	.8962	1.0753	1.0608	1.1401	1.1317	1.0212	
14	1.0387	1.0623	1.1984	1.1736	1.3203	1.0814	1.0277
15	1.0791		1.3923	1.3592	1.3717	1.3435	.6464
16		1.3599	1.4255	1.2929	1.406	1.3927	1.2929
17	.7316	1.3927	1.1736	1.291	1.3375	1.2266	1.2266
18	.6036	1.3923	1.326	.6874	1.286	1.094	1.2929
19	.8779	1.2431	1.2266	1.2239	1.286		1.2597
20	.823	1.0978	1.094	1.0608	1.2346		1.094
21	.6962	1.286	1.278	1.094	1.2071	1.2003	1.2289
22	.663	1.1831	1.1142	1.0562	1.1934	1.2174	1.1633
23	.6299	1.166	1.1305	1.094	1.1603	1.1488	1.1012
24	1.2851	.5761	1.0974	1.065	.8951	.9614	1.0631
Max	1.2851	1.3927	1.4255	1.3592	1.406	1.3927	1.3375
Min	.6036	.4973	.823	.6874	.779	.9221	.6464
Avg	.9502	.9736	1.1313	1.0826	1.1228	1.1104	1.0679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 205 / BALIRAJA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4588	.6062	.5571	.4915		
2		.4424	.639	.5735	.5079		
3		.426	.639	.5407	.4588		
4		.4588	.639	.5571	.4915		
5		.4915	.6554	.5898	.5243		
6		.5079	.6718	.639	.5407		
7		.6062	.7209	.6882	.6226		
8		.6062	.7373	.6718	.6718		
10					.7209	.6133	.3768
11		.1311			.8192	.7293	.426
12					.8029	.7956	.4096
13					.8192	.8097	.3605
14					.8356	.8356	.3605
15					.852	.8356	.3605
16					.4915	.8192	.3441
17					.6718	.7865	.3441
23	.4588	.5571	.5243	.4915			
24		.4752	.6226	.5571	.5243		
Max	.4588	.6062	.7373	.6882	.852	.8356	.426
Min	.4588	.1311	.5243	.4915	.4588	.6133	.3441
Avg	.4588	.4692	.6456	.5866	.6380	.7781	.3728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 201 / TAMBE MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.6859	1.2689	1.2483	1.3032	1.3375	1.4746
2	1.3717	.6859	1.2689	1.2186	1.3032	1.3032	1.406
3	1.3717	.6859	1.2346	1.1888	1.2346	1.2346	1.3717
4	1.3717	.6516	1.2346	1.1888	1.2346	1.166	1.3717
5	1.3717	.7202	1.2346	1.1591	1.2346	1.2003	1.3375
6	1.3717	.7545	1.1488	1.1294	1.3032	1.2689	1.3717
7	1.3717	.823	1.2517	1.1294	1.4403	1.406	1.4403
8	1.3717	.9602	1.5604	1.2483	1.4403	1.4746	1.5432
9	1.3717	1.6461	1.6461	1.2483	1.6461	1.6804	1.6461
10	1.3717	1.5775	1.6118	1.4415	1.6461	1.7147	1.6118
11	1.2346	1.5775	1.6118	1.4266	1.6804	1.7147	1.5775
12	1.0974	1.5432	1.5604	1.3672	1.1317	1.7147	1.5261
13	.7202	1.046	.9602	.8916	.9945	1.0974	1.046
14	1.0288	1.5089	1.5604	1.4861	1.5089	1.6804	1.5432
15	1.2346	1.6975	1.6118	1.4861	1.6975	1.6975	1.5604
16	.9259	1.6118	1.6461	1.4861	1.6461	1.6118	1.5604
17	.6859	1.5432	1.6632	1.4266		1.6461	1.5604
18	.6173	1.5775	1.6461	1.4266		1.7147	1.6632
19	.4801	1.5432	1.5261	1.4266		1.7147	1.4575
20	.5144	1.4403	1.406	1.3077		1.4746	1.4575
21	.5487	1.4746	1.406	1.3077		1.4746	1.5775
22	.6173	1.4403	1.4746	1.2483		1.5432	1.5261
23	.6859	1.4403	1.4746	1.1888	1.4403	1.5432	1.5261
24	1.3717	.6859	1.3032	1.278	1.3717	1.3717	1.4746
Max	1.3717	1.6975	1.6632	1.4861	1.6975	1.7147	1.6632
Min	.4801	.6516	.9602	.8916	.9945	1.0974	1.046
Avg	1.0617	1.2217	1.4296	1.2898	1.4032	1.4911	1.4846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 202 / UTTAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4403	1.0288	1.3032	1.6301	1.0974	1.1317	1.3717
2	1.4403	.9945	1.3032	1.5947	1.0288	1.0974	1.3032
3	1.4403	.9602	1.2689	1.5947	.9602	1.0288	1.2689
4	1.4403	.8916	1.2346	1.4529	.9602	.9602	1.2689
5	1.4403	.9602	1.2346		.9602	1.0288	1.2346
6	1.4403	1.0288	1.2003	1.0985	.9602	1.0974	1.2003
7	1.166	1.0974	1.2689	1.0985	1.0288	1.2346	1.3375
8	1.166	1.2003	1.5432	1.2226	1.0288	1.3375	1.2689
9	1.3717	1.4403	1.406	1.2226	1.3717	1.3717	1.3375
10	1.3717	1.3717	1.4746	1.2048	1.3717	1.4403	1.5432
11	1.3032	1.3717	1.4746	1.134	1.4575	1.4746	1.4918
12	1.0974	1.6118	1.5604	1.0631	1.2346	1.4918	1.4403
13	1.0631	1.1317	1.0974	1.0631	1.166	1.1317	.9774
14	1.0974	1.3375	1.5604	1.2757	1.3375	1.3032	1.3032
15	1.2346	1.4403	1.5432	1.2757	1.3203	1.3203	1.3032
16	1.2003	1.4918	1.5947	1.2757	1.3032	1.3032	1.3717
17	1.166	1.4918	1.6118	1.2757		1.3717	1.3717
18	1.2003	1.4403	1.6289	1.2757		1.4746	1.3889
19	1.2346	1.4746	1.6461	1.3466		1.4746	1.4918
20	1.166	1.4746	1.3889	1.3466		1.4746	1.4918
21	1.1317	1.4746	1.6461	1.3466		1.4403	1.4746
22	1.0974	1.4403	1.4403	1.2757		1.4746	1.3032
23	1.166	1.4746	1.6461	1.2757	1.2346	1.4403	1.3032
24	1.4403	1.0974	1.4403	1.701	1.166	1.166	1.406
Max	1.4403	1.6118	1.6461	1.701	1.4575	1.4918	1.5432
Min	1.0631	.8916	1.0974	1.0631	.9602	.9602	.9774
Avg	1.2631	1.2803	1.4382	1.3065	1.1660	1.2946	1.3439



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.332	.8573	2.4006	2.1643	2.4006	2.4006	2.572
2	2.332	.823	2.2291	2.1338	2.4006	2.332	2.4006
3	2.332	.7888	2.2634	2.1491	2.4006	2.2634	2.332
4	2.332	.7545	2.2291	2.1491	2.4006	2.1948	2.2977
5	2.332	1.0288	2.2291	2.1491	2.4006	2.332	2.2977
6	2.332	1.2003	2.1605	2.1491	2.4006	2.4006	2.2291
7	2.332	1.2003	2.3663	2.1491	2.4691	2.6406	2.5377
8	2.4691	1.5775	2.7435	2.1491	2.6063	2.7778	2.6063
9	1.9204	2.7435	2.7435	2.1491	2.8807	2.8807	2.8464
10	1.9204	2.7778	2.7778	2.4691	2.8807	2.7435	2.7435
11	1.7833	2.7778	2.7435	2.6825	2.8121	2.7778	2.8464
12	1.4746	2.692	2.572	2.6216	2.4348	2.6235	2.6235
13	1.0631	1.6632	1.6118	1.4632	1.6461	1.4403	1.749
14	1.4746	2.6749	2.572	2.4387	2.6749	1.7147	2.5034
15	1.6118	2.7778	2.7435	2.4387	2.7435	2.8121	2.7435
16	1.406	2.7092	2.7435	2.4387	2.7092	2.7778	1.8519
17	.823	2.6578	2.7092	2.4387		2.7778	2.7778
18	.6173	2.7435	2.6749	2.4387		2.8464	2.8121
19	.5144	2.6749	2.692	2.4387		2.8121	2.7092
20	.6173	2.4348	2.4691	2.3167		2.5034	2.7092
21	.823	2.5034	2.4691	2.3167		2.4691	2.7092
22	.8573	2.4348	2.4691	2.2558		2.7778	2.692
23	.9602	2.4691	2.4691	2.2558	2.6749	2.6749	2.6406
24	2.332	.8916	2.4348	2.1643	2.5377	2.4691	2.6406
Max	2.4691	2.7778	2.7778	2.6825	2.8807	2.8807	2.8464
Min	.5144	.7545	1.6118	1.4632	1.6461	1.4403	1.749
Avg	1.6247	1.9940	2.4799	2.2717	2.5263	2.5185	2.5363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 204 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.989	.823	1.989	2.0885	1.989	2.0233	1.4403
2	1.989	.7888	1.989	2.0885	1.989	1.989	1.406
3	1.989	.7202	1.9547	2.0553	1.989	1.9547	1.3717
4	1.989	.6859	1.9547	2.0553	1.989	1.8861	1.3032
5		.8916	1.9547	2.0388	1.989	1.989	1.3032
6		1.0974	2.0748	2.0388	1.989	2.0576	1.3032
7	.8573	1.2346	1.989	2.0388	1.989	2.1605	1.3032
8	.8573	1.4746	2.1948	2.0222	2.0576	2.2634	1.3032
9	1.166	2.2291	2.2977	2.0222	2.4006	2.3663	2.1605
10	1.166	2.332	2.332	2.1051	2.4006	2.0233	2.2634
11	1.0288	2.2977	2.2977	2.3205	2.332	2.332	2.3491
12	.8916	2.2805	1.9719	2.3205	2.1262	2.2291	1.4403
13		1.5432	1.4575	1.326	1.3717	1.406	.8059
14	.823	2.2977	1.9719	2.3205	2.2291	2.2977	2.1776
15	.8916	2.1948	2.2634	2.3205	2.2977	2.332	2.3663
16	.9602	2.2634	2.3491	2.3205	2.2634	2.2977	2.4006
17	.9259	2.2634	2.2291	2.1216		2.2291	2.4006
18	.8573	2.2291	2.2805	2.1216			2.2291
19		2.1605	2.1948	2.1216			2.2977
20	.6859	2.1605	2.2805	2.1216		.583	2.2977
21	.823	2.1605	2.1948	2.1216		1.5432	2.2634
22	.9602	2.0919	2.2805	2.0553		1.5432	2.1776
23	.8916	2.0919	2.2805	1.989	2.1262	1.5432	2.2291
24	1.989	.8573	2.0576	2.1216	2.0576	2.0576	1.4746
Max	1.989	2.332	2.3491	2.3205	2.4006	2.3663	2.4006
Min	.6859	.6859	1.4575	1.326	1.3717	.583	.8059
Avg	1.1865	1.7154	2.1183	2.0940	2.0881	1.9594	1.8361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 205 / DKTE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.823	1.2003	1.3535	.9602	.9602	1.2003
2	1.0288	.7888	1.1317	1.3169	.8916	.9259	1.0288
3	1.0288	.7545	1.1317	1.2803	.8916	.8916	1.0631
4	1.0288	.7202	1.0974	1.262	.8916	.8573	1.0288
5	1.0288	.7545	1.0631	.9877	.8916	.9259	1.0288
6	1.0288	.823	1.0288	.9511	.8916	1.0288	.8916
7	1.0288	.9602	1.0974	.7499	.823	1.0974	.9602
8	1.0288	1.0974	1.1317	1.2437	.8916	1.1317	1.0288
9	1.0288	1.166	1.2689	1.2437	1.166	1.2517	1.2689
10	1.166	1.2346	1.3032	1.2071	1.166	1.0974	1.3032
11	1.166	1.2346	1.3032	1.39	1.166	1.5775	1.3032
12	1.1317	1.2003	1.0802	1.3169	1.0974	1.2346	.8916
13	1.0974	1.0974	1.046	1.1706	1.0288	1.2346	1.046
14	1.0974	1.2346	1.0974	.8779	1.1317	1.2689	1.0974
15	1.0974	1.2689	1.2689	.8779	1.0974	1.3032	1.1145
16	1.1317	1.0974	1.3032	.8779	1.0631	1.2689	1.1145
17	1.1317	1.166	1.3032	1.2437		1.2346	1.1145
18	1.0974	1.1317	1.3032	1.2437		1.2689	1.1145
19	1.0631	1.1317	1.2003	1.3169		1.3032	1.1145
20	1.0288	1.3032	.12	1.3169		1.3032	1.1145
21	.9945	1.2689	1.2003	1.3169		1.2346	1.0974
22	.9602	1.3032	1.2003	1.2437		1.2346	1.0974
23	.8916	1.3032	1.3032	1.1706	1.0974	1.2346	1.0974
24	1.0288	.8573	1.2689	1.39	1.0288	1.0288	1.2346
Max	1.166	1.3032	1.3032	1.39	1.166	1.5775	1.3032
Min	.8916	.7202	.12	.7499	.823	.8573	.8916
Avg	1.0560	1.0717	1.1439	1.1812	1.0097	1.1624	1.0981

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 206 / GAON BHAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.6859	1.0631	1.0425	.9602	1.0288	1.0288
2	.9602	.6516	1.0288	1.0136	.9602	.9945	.9602
3	.8916	.6173	.9602	1.0136	.9602	.9602	.9259
4	.8916	.583	.9602	.9846	.9602	.9259	.8916
5	.8916	.6516	.8916	.9267	1.0288	1.0288	.8916
6		.7545	.8916	.8977	1.0288	1.0974	.8916
7	.6859	.823	1.1317	.8833	1.0974	1.166	1.0288
8	.823	.8916	1.2003	.9846	1.0974	1.2346	1.1317
9	1.0288	1.3032	1.2689	1.028	1.3032	1.3032	1.2689
10	1.0288	1.2346	1.2346		1.3032	1.1831	.7202
11	.9602	1.2689	1.2346	.9846	1.166	1.2346	
12	.8916	1.3032	1.2689	.8688	1.0974	1.2689	1.1488
13	.7888	1.0802	.9774	.7827	.9945	1.0288	1.0802
14	.8059	1.0288	1.2689	.9267	.9602	1.0288	.9088
15	.823	1.1831	1.2003	.9267	1.1145	1.0631	1.0631
16	.7888	1.2517	1.2003	.9267	1.0974	1.0288	1.1145
17	.7545		1.2174	.9267	1.0631	1.1488	1.1145
18	.7202	1.2346	1.2003	1.073	1.0974	1.2689	1.0974
19	.6859	1.2003	1.3032	.9846		1.2346	1.2346
20	.6859	1.2003	1.1831	.9846	1.166	1.1831	1.2346
21	.6859	1.3032	1.0288	.9846	1.2003	1.0974	1.2003
22	.6859	1.0288	1.2003	.9267	1.0974	1.1317	1.1317
23	.703	1.0288	1.2003	.8688	1.0631	1.1317	1.1317
24	1.0288	.6859	1.0974	1.0425	1.0288	1.0288	1.0974
Max	1.0288	1.3032	1.3032	1.073	1.3032	1.3032	1.2689
Min	.6859	.583	.8916	.7827	.9602	.9259	.7202
Avg	.8365	.9997	1.1338	.9558	1.0802	1.1167	1.0564

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 207 / 11 KV RAMNAGAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8807	2.4006	2.915	3.3846	2.0576	2.2977	3.0864
2	2.8807	2.3663	2.8464	3.3665	2.0576	2.2634	2.915
3	2.8807	2.332	2.8121	3.3303	2.0576	2.2291	2.915
4	2.8807	2.2291	2.7778	3.2941	2.0576	2.1605	2.7435
5	2.8807	2.4006	2.7778	3.2941	2.0576	2.332	2.8121
6	2.8807	2.5034	2.8464	3.2941	2.0576	2.6063	2.8464
7	3.0178	2.6063	3.0521	3.2941	2.6063	2.8464	3.1893
8	3.0178	2.8121	3.2922	2.9502	2.7435	3.2236	3.0178
9	3.4294	3.5151	3.618	3.0769	3.155	3.5837	3.4294
10	3.4294	3.5322		3.0769	3.155	3.5322	3.3265
11	3.3608	3.4979	3.6351	2.6063	3.4979	3.4979	3.4979
12	3.0864	3.4808	3.3093	2.5339	3.4294	3.4294	3.155
13	2.452	2.5034	2.5034	1.5927	2.2805	2.332	2.5034
14	3.1893	3.4122	3.2922	2.0271	3.4637	3.4294	3.2922
15	3.4294	3.5322	3.4294	2.0271	3.3265	3.5322	3.3608
16	3.2579	3.5322	3.5322	2.0271	3.3608	3.4979	3.5494
17	2.6749	3.5151	3.2579	1.8823		3.3951	3.5494
18	2.332	3.4294	3.3608	1.8823		3.3265	3.4294
19	1.8861	3.2579	3.3265	2.1719		3.4979	3.4122
20	2.0919	3.1207	3.0521	2.1719			3.4122
21	2.332	3.1893	3.0521	2.1719		3.155	3.4122
22	2.3663	3.0864	3.2236	2.1719		3.1893	3.1036
23	2.4691	3.1207	3.2065	2.1719		3.155	3.1036
24	3.135	2.4348	3.0864	3.3846	2.0576	2.332	3.1207
Max	3.4294	3.5322	3.6351	3.3846	3.4979	3.5837	3.5494
Min	1.8861	2.2291	2.5034	1.5927	2.0576	2.1605	2.5034
Avg	2.8434	2.9921	3.1394	2.6327	2.6719	2.9932	3.1743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 208 / 11 KV KRISHI GANGA SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2743	.2683	.3429		
2	.3772	.3429	.2683	.3429		
3	.3944	.3429	.2683	.3429		
4	.3944	.3429	.2683	.3429		
5	.4115	.3601	.2683	.3429		
6	.4115	.3601	.2683	.3429		
7	.3772	.3601	.2683	.3601		
8	.3429	.3772	.2683	.3429		
9				.3086		
10				.3429		
11				.4115		
12				.4458		.12
13				.4458	.4458	.1543
14				.4458	.4458	.12
15				.4458	.4458	.1543
16				.4287	.4115	.1543
17				.4115	.4115	
23	.2743	.2743	.3353			
24	.3429	.2743	.2683	.3429		
Max	.4115	.3772	.3353	.4458	.4458	.1543
Min	.2743	.2743	.2683	.3086	.4115	.12
Avg	.3669	.3309	.275	.3772	.4321	.1406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 209 / JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1715	.1886	.0514	.1715	.1715
2	.1715	.1715	.1715	.1886	.0514	.1715	.1715
3	.1715	.1715	.1715	.1886	.0514		.1715
4	.1715	.1715	.1715	.1886	.0514	.1715	.1715
5	.1715	.1715	.1715	.1886	.0514	.1715	.1715
6	.1715	.1715		.1886	.0514	.1715	.1715
7	.1715	.1715	.1715	.1886	.1715	.1715	.1715
8	.1715	.1715	.1715	.1886	.1715	.1886	.1715
9	.1715	.1715	.1715	.1886	.1715	.1715	
10	.1715	.1715	.1886	.1886	.1715	.1715	.1715
11	.1715	.1715	.1715	.1886	.1715	.1715	.1715
12	.1715	.1715	.1715	***	.1715	.1715	.1715
13		.1715	.1715	.1886	.1715	.1715	.1715
14		.1715	.1715	.1677	.1715	.1715	.1715
15		.1715	.1715	.1677	.1715	.1715	.1715
16		.1715	.1715	.1886	.1715	.1715	.1715
17		.1715	.1715	.1886		.1715	.1715
18		.1715	.1715	.1886	.1715	.1715	.1715
19		.1715	.1715	.1886	.1715	.1715	.1715
20	.1715	.1715	.1715	.1886	.1715	.1715	.1715
21	.1715	.1715	.1715	.0566	.1715	.1715	.1715
22	.1715	.1715	.1715	.0503	.1886	.1715	.1715
23	.1715	.1715	.1715	.0566	.1715	.1715	.1715
24	.1715	.1715	.1715	.1886	.0514	.1715	.1715
Max	.1715	.1715	.1886	16.1077	.1886	.1886	.1715
Min	.1715	.1715	.1715	.0503	.0514	.1715	.1715
Avg	.1715	.1715	.1722	.8334	.1357	.1722	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 210 / AVENUE SUPER MARKET  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0514	.0351	.0514	.0343	.0343
2	.0343	.0343	.0514	.0351	.0343	.0343	.0343
3	.0343	.0343	.0343	.0351	.0343	.0343	.0343
4	.0343	.0343	.0343	.0351	.0343	.0343	.0343
5	.0343	.0343	.0343	.0351	.0343	.0343	.0343
6	.0343	.0343	.0343	.0351	.0343	.0343	.0343
7	.0171	.0514	.0343	.0351	.0171	.0514	.0343
8	.0171	.0514	.0686	.0351	.0514	.0514	.0514
9	.0514	.0514	.0686	.0526	.0514	.0514	.0514
10	.2058	.0514	.0686	.0701	.0514	.0514	.0514
11	.1886	.0686	.1029	.0526	.0686	.0686	.0686
12	.1715	.1543	.1543	.1402	.12	.1372	.1372
13	.1029	.1543	.1372	.1402	.1372	.1029	.1543
14	.12	.1715	.1372	.1402	.12	.1029	.1543
15	.12	.1715	.1372	.1402	.1372	.12	.1372
16	.1372	.1715	.1715	.1402	.12	.1543	.1372
17	.1372	.1715		.1753	.1543	.1715	.1372
18	.1029	.1715	.2058	.1753	.1715	.1029	.1372
19	.1029	.1715	.2058	.1928	.1715	.12	.2058
20	.0857	.1715	.2058	.1718	.1715	.12	.2229
21	.0686	.1886	.1715	.1844	.1715	.1715	.2058
22	.0514	.0686	.1543	.1677	.1372	.12	.1715
23		.0514	.1372	.1341	.1029	.0686	.0686
24	.0171	.0343	.0514	.1402	.0686	.0686	.0514
Max	.2058	.1886	.2058	.1928	.1715	.1715	.2229
Min	.0171	.0343	.0343	.0351	.0171	.0343	.0343
Avg	.0827	.0972	.1066	.1041	.0936	.0850	.0993



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 211 / NAIKMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0919	1.2517	2.4006	2.1125	2.1948	2.2291	2.4006
2	2.0576	1.2003	2.332	2.1125	2.1948	2.1948	2.3663
3	2.0576	1.2003	2.2977	2.079	2.1948	2.1262	2.332
4	2.0576	1.166	2.2634	2.079	2.1948	1.989	2.2977
5		1.3032	2.2634	2.0454	2.1948	2.0576	2.2634
6		1.5432	2.2291	2.0622	2.2119	2.1948	2.2291
7	1.0631	1.8519	2.2634	2.0622	2.2119	2.2291	2.2634
8	1.0631	2.1262		2.079	2.2291	2.2977	2.2977
9	.5658	2.4691	2.5034	2.079	2.4691	2.332	2.4691
10	2.0748	2.4348	2.5377	2.079	2.4691	2.1262	2.4006
11	2.0576	2.4691	2.5377		2.5377	2.2291	2.3663
12	2.0233	1.7833	1.869	1.1065	2.4348	2.2291	2.2291
13	1.8861	1.7147	1.6461	1.6095	1.6975	1.8861	1.6804
14	1.9547	2.332	1.869	1.9784	2.5034	2.5034	2.5549
15	1.989	2.4348	1.869	1.9784	2.5377	2.572	2.5549
16	1.8861	2.4006	1.869	1.9784	2.5034	2.4691	2.5549
17	1.8519	2.7435	2.4691	1.9448	2.5206	2.5034	2.572
18	1.749	2.7435	2.5034	1.9448	2.5377		2.572
19	1.5775	2.6749	2.5034	2.2801	2.5377	2.4691	2.4006
20	1.5089	2.6406	2.5034	2.2801	2.5034	2.572	2.4006
21	1.406	2.5034	2.5034	2.2801	2.5034	2.572	2.4006
22	1.286	2.5034	2.1948	2.2466	2.4691	2.5034	2.3148
23	1.2689	2.4691	2.1948	2.2131	2.4006	2.4691	2.3148
24	2.0919	1.2346	2.4691	2.146	2.2291	2.2634	2.4691
Max	2.0919	2.7435	2.5377	2.2801	2.5377	2.572	2.572
Min	.5658	1.166	1.6461	1.1065	1.6975	1.8861	1.6804
Avg	1.7077	2.0498	2.2649	2.0338	2.3534	2.3051	2.3627

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 212 / MAHADEV NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3086	.3086	.3944	.3601	.3429	.3601
2	.3429	.2743	.3086	.3944	.3772	.3429	.3429
3	.3429	.2743	.3086	.3944	.3772	.3429	.3429
4	.3429	.2572	.2743	.3944	.3772	.3429	.3429
5	.3429	.2572	.2743	.3944	.3944	.3772	.3429
6	.3429	.2743	.2743	.3944	.3944	.3944	.3772
7	.3429	.2743	.3086	.3944	.3944	.3944	.3772
8	.3429	.2915	.3429	.3944	.4458	.4115	.3772
9	.3429	.4458	.4458	.4115	.4458	.3772	.4115
10	.3258	.4115	.4458	.4115	.4458	.4115	.3944
11	.3086	.4115	.4115	.3086	.1372	.4115	.4115
12	.2743	.3772	.3772	.3429	.3429	.4287	.4115
13	.2058	.3429	.3258	.3429	.3258	.3772	.3086
14	.2401	.3772	.3772	.4024	.3429	.4287	.3601
15	.2401	.3601	.3944	.4024	.3772	.4287	.3601
16	.2743	.3429	.4115	.4024	.3944	.4115	.3601
17	.3086	.4287	.3944	.4191		.4458	.3772
18	.3429	.4115	.3944	.4191	.4458	.3429	.3944
19	.3772	.3772	.3944	.3856	.4458	.3772	.3772
20	.3772	.3772	.4115	.3856	.4458	.4115	.3772
21	.3772	.4115	.583	.3856	.4287	.4115	.3772
22	.4115	.3772	.4115	.3688	.4115	.4115	.3772
23	.3772	.3429	.4115	.3688	.3944	.3772	.3772
24	.4239	.3429	.3429	.4115	.3601	.3601	.3772
Max	.4239	.4458	.583	.4191	.4458	.4458	.4115
Min	.2058	.2572	.2743	.3086	.1372	.3429	.3086
Avg	.3310	.3479	.3722	.3885	.3854	.3901	.3715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 704 / 33 KV Main VCB TILAWANI SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	14.9177	9.1564	15.4321	16.2895	12.8601	12.963	14.9177
2	14.4033	8.8992	14.9177	16.2895	12.3457	12.6543	14.4033
3	14.4033	8.7449	14.1976	15.7465	12.3457	12.2943	13.8889
4	11.3169	8.5905	14.0947	15.7465	12.3457	11.8313	13.8889
5	11.3169	9.7222	14.0947	15.6922	12.8601	12.5	13.3745
6	10.2881	10.6482	14.1976	15.6922	13.3745	13.3745	13.4774
7	11.7799	11.8313	14.9177	15.6922	14.0947	14.4033	14.4033
8	12.3457	12.963	16.4609	16.0723	16.6667	14.4033	14.5062
9	10.6996	16.4609	17.0782	16.6152	16.6667	17.3869	16.5124
10	10.751	16.6152	17.0782	16.2352	16.6667	14.0947	14.712
11	12.6543	16.6667	16.9753	14.4433	17.5412		16.9753
12	11.3683	16.6667	16.2037	13.1459	16.0494		13.8889
13	9.3622	11.9856	12.3457	10.99	12.2943	12.3457	11.7284
14	11.3169	16.5638	16.2037	14.1976	16.5638	17.6955	15.8951
15	13.4259	17.1297	17.1811	14.1976	17.3354	17.7984	17.284
16	11.6255	16.821	17.284	14.2501	16.0494	17.4897	17.284
17	10.0309	16.7181	16.6152	14.7148		17.1811	16.6152
18	9.3622	16.4609	16.9753	14.2501		12.0371	16.8725
19	7.7161	16.358	16.5638	14.1976		13.3745	16.5638
20	8.4362	16.2552	15.8436	14.1976		11.0597	16.1523
21	8.8992	16.2552	15.8436	14.1976		15.6379	16.5638
22	9.6194	15.3292	15.7408	15.2778		15.7408	15.7408
23	10.1852	15.7408	15.8436	14.3519		15.4321	15.7408
24	15.2264	9.465	15.6379	16.6152	13.3745	13.4259	15.4321
Max	15.2264	17.1297	17.284	16.6152	17.5412	17.7984	17.284
Min	7.7161	8.5905	12.3457	10.99	12.2943	11.0597	11.7284
Avg	11.3105	13.8353	15.7386	14.9624	14.6726	14.3238	15.2842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 202 / IND EST FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6476	1.3535	1.6461	1.5947	1.2071	1.749	1.6478
2	1.5947	1.3169	1.5775	1.5432	1.2567	1.6804	1.5947
3	1.5238	1.2178	1.5089	1.4706	1.1827		1.5061
4	1.4175	1.2197	1.4403	1.4175	1.1827	1.4922	1.5061
5	1.4327	1.2567	1.4403	1.4175	1.1827	1.4403	1.5238
6	1.5402	1.2803	1.4403	1.4118	1.2071	1.5089	1.5415
7	1.5043	1.4266	1.406	1.4118	1.2308	1.5775	1.5415
8	1.5592	1.4022	1.4232	.9955	1.3535	1.6461	1.5238
9	1.9547	2.0348	2.2634	.9568	2.1365	2.1605	1.9113
10	2.0454	2.2043	2.1948	1.0498	2.1795	2.2291	1.9951
11	2.2043	2.4006	2.2801	1.1949	2.4348	2.3137	2.2977
12	2.0908	2.1262	1.9547	1.0082	2.1262	2.2291	2.0919
13	1.8781	1.6461	1.6301	.7545	1.6804	1.8604	1.749
14	1.9281	2.1605	2.0233		2.1605	2.0957	1.989
15	2.1616	2.2634	2.079		2.2805	2.2131	2.0576
16	2.1262	2.2291	2.1963	.8779	2.2977	2.2801	2.0119
17	2.0332	1.2346	2.1795	.9145	2.2291	2.1776	2.0119
18	1.949	2.2462	2.0957		2.2634		2.1125
19	1.5775	2.0576	1.989	.7392	1.989	1.749	2.0119
20	1.3032	1.6461	1.4575	.7133	1.6461	1.6478	1.6461
21	1.4632	1.7147	1.7187	.9877	1.7833	1.7718	1.7147
22	1.4045	1.6632	1.6832	1.2071	1.749	1.6832	1.8176
23	1.382	1.6804	1.7718	1.2936	1.7147	1.7002	1.7833
24	1.7177	1.4045	1.6461	1.7147	1.2437	1.749	1.6832
Max	2.2043	2.4006	2.2801	1.7147	2.4348	2.3137	2.2977
Min	1.3032	1.2178	1.406	.7133	1.1827	1.4403	1.5061
Avg	1.7266	1.7161	1.7936	1.1750	1.7382	1.8616	1.8029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 204 / YASHWANT FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1694	1.1462	1.0082	.905	.7682	1.0082	.905
2	1.1694	1.1458	.9709	.8688	.7762	.9808	.8688
3	1.1694	1.1458	.9335	.8688	.7392	.9335	.8507
4	1.1694	1.1088	.8962	.8145	.7392	.9335	.8507
5	1.2071	1.134	.9328	.8145	1.4998	1.0185	.8869
6	1.2071	1.1706	.9896	.8507	.7682	1.0562	.9412
7	1.2071	1.134	.9431	.8507	.8048	1.094	.9593
8	1.1949	1.2012	.9431	.6516	.8779	1.2071	1.0136
9	1.3394	1.2437	.9602	.724	.9774	1.4377	1.3213
10	1.3575	1.4632	.9945		1.1946	1.419	1.4842
11		1.5466			1.3203	1.1403	1.5684
12	1.6632	1.3957	1.1403		1.307	1.086	1.587
13	1.3169	1.4003	1.0317			1.0136	1.3756
14	1.4632	1.3817	1.086	5.587	1.2696	1.0808	1.419
15	1.4998	1.4901	1.1222	.583	1.2437	1.086	1.531
16	1.4632	1.4563	1.1584	.6154	1.3392	1.1222	1.5466
17	1.4266	1.094	1.086	.6316	1.3392	1.1765	1.419
18	1.39	1.3817	1.0317	.57	1.1576	1.0136	1.3957
19	1.3466	1.419	1.0631	.5441	1.2071	1.1403	1.3957
20	1.3352	1.3203	1.0498	.5407	1.1128	.9412	1.3957
21	1.2254	1.2071	.9391	.8131	1.1203	.9774	1.3957
22	1.2382	1.1576	.905	.8686	1.1273	1.0136	1.3957
23	1.2382	1.094	.9214	.8048	1.1317	.9412	1.3203
24	1.1576	1.2323	1.0456	.9412	.7865	1.0642	.9412
Max	1.6632	1.5466	1.1584	5.587	1.4998	1.4377	1.587
Min	1.1576	1.094	.8962	.5407	.7392	.9335	.8507
Avg	1.3024	1.2696	1.0066	.9924	1.0699	1.0786	1.2403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 205 / IGM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	.7011	1.2346	1.3757	1.4089	1.2963	1.3125
2	1.4091	.6733	1.2037	1.3441	1.3748	1.2342	1.2631
3	1.3763	.631	1.0974	1.2146	1.2887	1.2041	1.2146
4	1.3435	.6241	1.0974	1.2146	1.2209	1.1728	1.2146
5	1.3435	.6935	1.0648	1.2146	1.2378	1.1584	1.2793
6	1.3108	.7282	1.1265	1.2631	1.2407	1.2037	1.3279
7	.6036	.7956	1.2186	1.3441	1.3108	1.358	1.3765
8	1.1984	.9054	1.4198	1.5813	1.4746	1.4403	1.3441
9	1.2651	1.6964	1.7284	1.7375	1.7532	1.7284	1.5432
10	1.3279	1.858	1.5586	1.6975	1.7204	1.7444	1.5741
11		1.7444	1.6821	1.7368	1.6975	1.6309	1.6762
12		1.5684	1.4352	1.6575	1.5586	1.4232	1.4998
13		1.0883	1.3279	1.1401	1.0402	1.0526	.9804
14	.5636	1.4327	1.4706	1.5581	1.4632	1.4232	
15	.7625	1.668	1.4937	1.6575	1.5741	1.5546	1.406
16	.7373	1.6644	1.6004	1.7204	1.6049	1.6204	1.6644
17	.7537	1.4815	1.7747	1.757	1.5546	1.6204	1.6004
18	.6706	1.7284	1.6667	1.6712	1.4937	1.6667	1.6644
19	.6371	1.5741	1.5741	1.704	1.5741	1.5123	1.6004
20	.6935	1.6324	1.5023	1.5238	1.4327	1.4232	1.4373
21	.6554	1.5741	1.5023	1.5402	1.5546	1.4864	1.4373
22	.8383	1.5043	1.4548	1.5074	1.4022	1.4232	1.406
23	.7202	1.358	1.4232	1.4918	1.5123	1.4232	1.4403
24	1.5043	.7011	1.3123	1.4232	1.4255	1.2803	1.3441
Max	1.5043	1.858	1.7747	1.757	1.7532	1.7444	1.6762
Min	.5636	.6241	1.0648	1.1401	1.0402	1.0526	.9804
Avg	1.0082	1.2511	1.4154	1.5032	1.4550	1.4201	1.4177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 206 / 11 K.V BHAJI MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	.9145	1.1523	1.086	.9922	1.1706	1.0099
2	1.134	.8779	1.134	1.0317	.9877	1.0974	.9391
3	1.134	.8413	1.0608	.9593	.9511	.9774	.9036
4	1.0974	.8145	1.0242	.9593	.9214	.9511	.9036
5		.8326	1.0791	.9593	.9593	.9511	.9568
6		.8688	1.0974	.9774	.9955	1.0059	.9745
7		.8507	1.0974	.9955	.9412	1.1041	1.0631
8		.905	1.2254	1.0985	1.1222	1.1523	1.1163
9		.1267	1.2254	1.1871	1.2489	1.2803	1.2934
10		1.1946	1.3352	1.2048	1.3394	1.3169	1.1871
11		1.4266	1.0985	1.2308	1.3535	1.2048	1.1584
12		1.2254	1.134	1.1706	1.2986	1.2048	1.1222
13		1.0425	1.0631	.9145	1.0791	.9922	.8688
14		1.2803	1.1694	.9412	1.262	1.0631	1.0136
15		1.3352	1.2048	1.086	1.2986	1.1517	1.1584
16		1.3352	1.258	1.1765	1.4266	1.3112	1.1946
17		1.3535	1.2226	1.1946	1.39	1.2757	1.267
18		1.3717	1.1871	1.1584	1.4083	1.258	1.1946
19	.7783	1.262	1.2226	1.1706	1.3535	1.4175	1.2178
20	.7865	1.262	1.134	1.1584	1.262	1.2226	1.1222
21	.8682	1.2437	1.1694	1.1222	1.2071	1.2226	1.1222
22	.9511	1.2254	1.1163	1.0808	1.2071	1.1517	1.1222
23	.9694	1.1523		1.134	1.1706	1.1517	1.1222
24	1.1584		1.1706	1.0985	1.0608	1.2254	1.0454
Max	1.1584	1.4266	1.3352	1.2308	1.4266	1.4175	1.2934
Min	.7783	.1267	1.0242	.9145	.9214	.9511	.8688
Avg	1.0036	1.0758	1.1557	1.0873	1.1765	1.1608	1.0865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 207 / 11 KV BALAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0159		.9831	1.0898	1.0442	1.0486	1.0111
2	1.0159		.8745	1.0395	.9762		.9448
3	1.0395		.9069	.9556	.9831	.9175	.9448
4	1.0059		.8642	.9221	.9831	.8848	.9116
5	1.0059		.8684	.9221	.9831	.9503	.9614
6	1.073		.8907	.9393	1.0159	.9831	.9945
7	1.1401		1.073	1.004	1.0395	1.0242	1.0442
8	.8848		1.0159	1.1603	1.1271	1.0814	1.0774
9	.8453		1.2003	1.21	1.2289	1.1961	1.1984
10	.8421		1.1797	1.166	1.2125	1.1683	1.166
11	.9036		1.2308	1.3077	1.2323	1.1984	1.2308
12	.7202		1.0364	1.073	1.1305	.9448	1.0364
13	.6859		.9614	.9389	.8718	.9282	.8421
14	.6859		1.094	.9614	1.1523	1.1163	1.0364
15	.7042		1.1336	1.0486	1.2452	1.1498	1.1336
16	.6443		1.2146	1.2125	1.2483	1.247	1.1984
17	.4915		1.0688	1.2431	1.2483	1.1984	1.1984
18		1.2239	1.1174	1.2574	1.1797	1.166	1.1203
19		1.1961	1.1822	1.2125	1.1523	1.1336	1.1203
20		1.0486	1.0442	1.0486	1.0402	1.0111	.9717
21		1.0562	1.1271	1.1065	1.0802	1.1603	1.0364
22		1.0814	1.1012	1.1401	1.0978	1.0774	1.1012
23		1.065	1.1603	1.1736	1.034	1.1105	1.0688
24	1.0364		1.065	1.1233	1.0814	1.1065	1.0608
Max	1.1401	1.2239	1.2308	1.3077	1.2483	1.247	1.2308
Min	.4915	1.0486	.8642	.9221	.8718	.8848	.8421
Avg	.8745	1.1119	1.0581	1.0940	1.0995	1.0784	1.0587



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 208 / 11 KV JIVESHWAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6126	1.267	1.5729	1.6655	1.2178	1.4746	1.3466
2	1.5775	1.1584	1.6095	1.5592	1.1694	1.4419	1.3466
3	1.5074	1.086	1.4243	1.4175	1.182	1.3763	1.2757
4	1.4373	1.0498	1.4251	1.3112	1.2308	1.2346	1.2757
5	1.4175	1.0242	1.4575	1.3112	1.3394	1.2125	1.3112
6	1.5947	1.0498	1.5261	1.2403	1.4327	1.3032	1.382
7	1.6301	1.4327	1.4419	1.2048	1.4175	1.5089	1.4529
8	1.5074	1.4373	1.2125	1.0136	1.3937	1.3923	1.4175
9	1.7718	1.8781	1.7695	1.0631	1.825	1.6057	1.8442
10		1.8313	1.7604	1.086	1.8031	1.8679	1.7772
11	1.749	1.7604	1.9113	.9568	1.8351	1.8778	1.8861
12	1.6301	1.3435	1.6461	.7164	1.6385	1.6655	1.749
13	1.5775	1.5729	1.6301	.543	1.5402	1.6655	1.5775
14	1.7718	1.6004	1.7974	.4298	1.7101	1.7736	1.749
15	1.8054	1.8023	1.7101	.5373	1.7695	1.7101	1.8861
16	1.8073	1.7859	1.7772		1.5729	1.8442	1.749
17	1.5775	1.7695	1.8107	1.086	1.5364	1.8107	1.6804
18	1.0136	1.7695	1.7101	.9774	1.704	1.166	1.6804
19	.9593	1.4746	1.406	.905	1.7295	1.749	1.8176
20	.8505	1.3123	1.382	1.086	1.3123	1.4175	1.4403
21	1.0745	1.3108	1.4175	1.182	1.278	1.5238	1.6118
22	1.4118	1.3435	1.6832	1.2536	1.6766	1.7364	1.749
23	1.4118	1.704	1.8781	1.267	1.6057	1.7718	1.7833
24	1.262	1.3394	1.6095	1.829	1.2536	1.5223	1.4529
Max	1.8073	1.8781	1.9113	1.829	1.8351	1.8778	1.8861
Min	.8505	1.0242	1.2125	.4298	1.1694	1.166	1.2757
Avg	1.4765	1.4627	1.6070	1.1149	1.5072	1.5688	1.5934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 201 / 11 KV JANTA TEX.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	3.7723	3.9609	3.81	3.8289	3.7723	3.9609
2	3.5837	3.5837	3.9609	3.7723	3.81	3.81	3.9609
3	3.5837	3.5837	3.7723	3.7723	3.8477	3.8477	3.8666
4	3.5837	3.5837	3.7723	3.678	3.8289	3.9232	3.7723
5		3.81	3.7723	3.6969	3.8666	3.9609	3.7723
6		3.81	3.7723	3.81	3.9609	3.9609	3.9043
7		4.0364	3.8666	3.9609	3.8855	4.0364	4.0741
8	3.9609	4.0741	4.7154	3.3981	3.7534	3.9209	4.1495
9	4.1495	4.0741	4.1495	3.0807	3.4328	4.0329	4.1872
10	4.1118	4.0741	4.1495	3.1741	4.0741	4.1076	4.1872
11	4.225	4.2196	4.1495	3.2442	4.1495	4.3381	4.1872
12	3.9986	4.145	4.1495		4.1118	4.2816	4.1495
13	3.9609	3.7342	4.1118	3.2065	4.0741	3.7723	4.1495
14	4.0741	4.0703	4.1495	3.2253	3.81	3.9986	4.1118
15	3.8477	3.9986	4.1495	3.2442	3.9232	4.0364	4.1495
16	3.8855	3.8855	4.2627	3.263	3.9609	4.0175	4.1118
17	3.8477	4.0552	4.1118	3.2442	3.9986		4.1684
18	3.81	4.0741	3.9986	3.1876	3.9609		4.2061
19	3.9232		4.0364	3.2065	3.9986		4.1495
20			3.8855	3.4894	3.9986	3.9232	3.9609
21	3.8666		3.9609	3.7723	3.9609	3.9986	3.81
22	3.9232		3.942	3.81	3.9609	4.0364	3.9609
23	3.8477		3.9986	3.8289	3.9232	3.9986	3.9798
24	3.7723	3.81	3.9609	3.81	3.8477	3.7346	4.0364
Max	4.225	4.2196	4.7154	3.9609	4.1495	4.3381	4.2061
Min	3.5837	3.5837	3.7723	3.0807	3.4328	3.7346	3.7723
Avg	3.8864	3.9155	4.0316	3.5081	3.9153	3.9766	4.0403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 202 / 11 KV DECCAN PROCESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0178	2.8292	3.2065	3.1367	2.7915	3.0178	3.1741
2	3.0178	3.0556	3.2065	3.1367	2.7915	3.0556	3.1741
3	2.8292	2.9801	3.0178	3.062	2.7538	3.0933	3.1367
4	2.8292	3.0556	3.0178	2.894	2.7915	3.0178	3.0247
5	3.0178	3.0178		2.9127	2.7915	3.0178	3.0434
6	3.0178	3.0933	3.0178	2.9874	2.7538	3.0178	3.1741
7	3.0178	3.131	3.0178	3.1181	2.7726	2.9801	3.1367
8	3.0178	3.0933	3.0178	2.6057	2.7726	3.1786	3.1181
9	3.2065	5.9414	3.2065	2.0513	2.0936	3.1417	3.1741
10	3.2442	3.131	3.2065	2.0328	3.131	3.2526	3.2301
11	3.2065	3.2526	3.2065	2.1125	3.2065	3.3608	3.3573
12	3.1499	3.1786	3.2065	2.0748	3.1121	3.1927	3.3196
13	3.0178	2.8753	3.0178	1.9993	2.9424	2.9127	3.2065
14	2.9801	2.9874	3.131	1.9805	3.0556	3.0434	3.1687
15	3.1121	3.2114	3.2442	1.9805	3.1121	3.3234	3.3196
16	3.0933	3.2114	3.3196	1.9427		3.3234	3.3573
17	3.1121	3.2674	3.3008		3.0556		3.3385
18	3.131	3.2487	3.2819	1.9239	3.0933		3.3196
19	3.0178		3.2114	1.9427	3.263	3.1741	3.3234
20	3.131		3.006	2.0748	3.1687	3.1741	3.131
21	2.999		3.1367	2.8292	3.0933	3.1741	3.2253
22	3.0178		3.1741	2.8669	3.0556	3.3421	3.1687
23	3.0933		3.1927	2.8669	3.131	3.3421	3.2065
24	3.0178	3.1687	3.2065	3.1741	2.8858	3.2065	3.1927
Max	3.2442	5.9414	3.3196	3.1741	3.263	3.3608	3.3573
Min	2.8292	2.8292	3.006	1.9239	2.0936	2.9127	3.0247
Avg	3.0540	3.2489	3.1544	2.5090	2.9399	3.1519	3.2092

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 203 / 11 KV ICH METALLOY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9805	1.8861	2.0748	2.1658	1.9993	2.1502	2.0911
2	1.9805	1.9239	2.0748	2.1285	2.0182	2.1879	2.0911
3	2.0748	1.9616	2.0748	2.1285	2.037	2.1879	2.0538
4	2.0748	2.1502	2.0748	2.0538	1.9993	2.2257	1.9978
5	2.0748	2.037	2.0748	2.0538	2.037	2.2257	2.0165
6	2.1691	1.9616	2.0748	2.0911	2.0748	2.1125	2.0538
7	2.1691	1.8484	2.1691	2.1285	2.0748	2.2257	2.1658
8	2.2634	1.9239	2.1691	1.9044	2.1125	2.2405	2.2405
9	2.2634	2.1502	2.2634	1.587	2.0748	2.3152	2.2779
10	2.3388	2.2257	2.2634	1.6244	2.3577	2.2779	2.3525
11	2.0919	2.3525	2.2634	1.6221	2.5274	2.4272	2.4143
12	2.037	2.2405	2.2257	1.5844	2.3765	2.3899	2.4143
13	1.9239	1.9791	2.1502	1.5089	2.1502		2.1879
14	2.1125	2.0911	2.2257	1.5089	2.1502	2.2592	2.3765
15	2.1879	2.2405	2.3011	1.4901	2.1879	2.3899	2.4143
16	2.1502	2.2032	2.3765		2.2634	2.3525	2.3954
17	2.1125	2.1472	2.3577	1.4146	2.2257		2.4143
18	2.0182	2.0538	2.32	1.3957	2.1502		2.4143
19	1.9239		2.2779	1.4335	2.0748	2.3152	2.3765
20	1.9805		2.2032	1.4712	2.1125	2.2592	2.3388
21	1.7918		2.2032	1.5089	2.1125	2.2032	2.1125
22	1.6975		2.2032	2.037	2.1125	2.2032	2.1502
23	1.773		2.1098	2.037	2.1502	2.2032	2.1691
24	1.9805	1.8484	2.0748	2.1658	2.0748	2.1125	2.1658
Max	2.3388	2.3525	2.3765	2.1658	2.5274	2.4272	2.4143
Min	1.6975	1.8484	2.0748	1.3957	1.9993	2.1125	1.9978
Avg	2.0488	2.0645	2.1919	1.7845	2.1439	2.2507	2.2369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 204 / 11 SHAHAPUR IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1691	2.1502	2.2634	2.1502	1.8107	2.1125	2.0748
2	2.1691	2.1879	2.2634	2.1125	1.8484	2.0748	2.0748
3	2.0748	2.3388	2.2634	2.0748	1.8296	2.0748	2.037
4	2.0748	2.0748	2.2634	2.037	1.8107	2.0748	1.9805
5	2.0748	2.1502	2.1691	2.037	1.8484	2.1125	1.9805
6	2.0748	2.1502	2.1691	2.0559	1.8296	2.1502	2.037
7	2.1691	2.0748	2.1691	2.0182	1.8484	2.037	2.1502
8	2.2634	2.2257	2.1691	1.8484	1.8861	2.0538	2.1691
9	2.3577	2.3011	2.2634	1.475	1.8484	2.1285	2.2257
10	2.4143	2.3388	2.3577	1.2696	2.0936		2.32
11	2.452	2.3899	2.3388	1.3203	2.2634	2.3765	2.4143
12	2.1879	2.2779	2.32	1.3392	2.3388	2.3011	2.452
13	2.2257	2.0351	1.9805	1.3203	1.8861	2.037	2.4143
14	2.1502	2.1658	2.2068	1.358	2.1125	2.1502	2.1879
15	2.2257	2.4143	2.2634	1.3203	2.1502	2.3577	2.3765
16	2.2634	2.4143	2.2634		2.1125	2.3388	2.3388
17	2.2822		2.2634	1.358	2.0748		2.3011
18	2.2634	2.3765	2.2634	1.3203	2.1125		2.3011
19	2.2257		2.2634	1.358	2.1125	2.1879	2.2634
20	2.1502		2.1313	1.4146	2.1125	2.1879	2.1879
21	2.037		2.1691	1.7353	2.0748	2.2257	2.0748
22	2.0559		2.1691	1.773	2.1691	2.2068	2.037
23	2.0748		2.1502	1.8107	2.1879	2.0748	2.0748
24	2.1691	2.1125	2.2634	2.1879	1.8484	2.1691	2.0748
Max	2.452	2.4143	2.3577	2.1879	2.3388	2.3765	2.452
Min	2.037	2.0351	1.9805	1.2696	1.8107	2.037	1.9805
Avg	2.1919	2.2322	2.2249	1.6824	2.0087	2.1634	2.1895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 205 / 11 KV RADHA KANHAIYA  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 207 / 11 K.V AMIT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5463	2.5463	2.452	2.6029	2.1125	2.3388	2.5463
2	2.5463	2.6406	2.452	2.5274	2.1125	2.4143	2.5463
3	2.452	2.452	2.2634	2.4897	2.0936	2.452	2.5086
4	2.452	2.452	2.2634	2.3765	2.1125	2.452	2.452
5	2.452	2.452	2.452	2.3577	2.0936	2.452	2.452
6	2.452	2.5652	2.6406	2.3577	2.1125	2.452	2.5274
7	2.452	2.4897	2.6406	2.452	2.0748	2.4143	2.5463
8	2.452	2.4143	2.6406	2.2779	2.0748	2.4272	2.5086
9	2.452	2.5652	2.6406	2.1285	1.8861	2.4646	2.5463
10	2.5652	2.4709	2.6406	2.0538	2.5652	2.3899	2.6217
11	2.6406	2.838	2.6217	2.0936	2.5652	2.7915	2.6783
12	2.3388	2.8104	2.6029	2.0748	2.7915	2.6595	2.6783
13	2.4143	2.4897	2.584	1.8861	2.4897	2.3011	2.5652
14	2.452	2.6595	2.6029	1.8861	2.4143		2.6595
15	2.7161	2.6783	2.6029	1.8673	2.5652		2.5652
16	2.7538	2.6217	2.5652		2.6406	2.5274	2.5652
17	2.5652	2.6406	2.584	1.8107	2.6783		2.5274
18	2.6217		2.6029	1.6975	2.6406		2.5274
19	2.5652		2.6406	1.7918	2.6783	2.5086	2.5463
20	2.6029		2.6217	1.8673	2.6406	2.452	2.4897
21	2.5652		2.584	1.9993	2.5652	2.584	2.452
22	2.5274		2.6217	2.1125	2.452	2.6406	2.5274
23	2.6406		2.6406	2.1125	2.4897	2.6217	2.5086
24	5.0926	2.6029	2.452	2.6783	2.1313	2.452	2.5463
Max	5.0926	2.838	2.6406	2.6783	2.7915	2.7915	2.6783
Min	2.3388	2.4143	2.2634	1.6975	1.8861	2.3011	2.452
Avg	2.6383	2.5772	2.5589	2.1523	2.3742	2.4898	2.5455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 208 / 11 K.V. TULJABHAVANI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5837	3.7723	3.7723	3.7723	3.5837	3.7723	3.7723
2	3.5837	3.7723	3.7723	3.7723	3.5837	3.7723	3.7723
3	3.5837	3.7723	3.5837	3.5837	3.5837	3.7723	3.5837
4	3.5837	3.7723	3.5837	3.3951	3.5837	3.7723	3.3951
5		3.5837	3.5837	3.3951	3.5837	3.7723	3.3951
6		3.5837	3.7723	3.5837	3.5837	3.7723	3.5837
7	3.7723	3.5837	3.7723	3.5837	3.5837	3.7723	3.5837
8	3.7723	3.7723	3.9609	3.3265	3.5837	3.7342	3.5837
9	3.5837	3.9609	4.1495	3.1417	3.3951	3.7342	3.7723
10	3.7723	4.1495	4.1495	3.3265	4.1495	3.7342	3.9609
11	3.7723	4.0657	4.1495	3.3951	4.1495	4.1495	4.1495
12	3.7723	3.8809	4.1495	3.2065	3.7723	3.9609	4.1495
13	3.7723	3.5113	3.7723	1.6975	3.5837	3.5837	3.7723
14	3.7723	3.8809	4.1495	1.7353	4.1495	3.9609	3.9609
15	3.9609	4.3381	4.1495	1.6975	4.1495	4.3381	3.9609
16	3.9609	4.3381	4.3381	1.9239	3.9609	4.3381	3.9609
17	3.7723	4.1495	4.1495	1.9805	3.9609		3.9609
18	3.7723	4.1495	4.1495	1.8861	3.9609		3.9609
19	3.7723		4.1495	1.9805	3.7723	3.9609	3.9609
20	3.7723		3.9609	2.2257	3.7723	3.7723	3.7723
21	3.7723		3.9609	3.3951	3.7723	3.7723	3.9609
22	3.7723		3.9609	3.5837	3.7723	3.7723	3.9609
23	3.7723		3.7723	3.5837	3.7723	3.7723	3.9609
24	5.0412	3.7723	3.7723	3.9609	3.5837	3.5837	3.7723
Max	5.0412	4.3381	4.3381	3.9609	4.1495	4.3381	4.1495
Min	3.5837	3.5113	3.5837	1.6975	3.3951	3.5837	3.3951
Avg	3.8043	3.8847	3.9452	2.9639	3.7644	3.8443	3.8195



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 209 / 11 K.V YOGASHRAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	.5658	1.3203	1.307	1.1317	1.3203	1.307
2	1.3203	.5658	1.3203	1.307	1.1317	1.3203	1.307
3	1.1317	.5658	1.1317	1.1203	1.1317	1.3203	1.1203
4		.5658	1.1317	.9335	1.1317	1.3203	.9335
5		.5658	1.1317	1.1203	1.1317	1.3203	1.1203
6		.5658	1.1317	1.1203	1.1317	1.3203	1.1203
7	.9431	.5658	1.3203	1.307	1.1317	1.3203	1.307
8	1.1317	1.1317	1.3203	1.4937	1.3203	1.307	1.307
9	1.1317	1.5089	1.5089	1.6804	1.1317	1.4937	1.4937
10	1.1317	1.6975	1.6975	1.4937	1.6975	1.4937	1.6804
11	1.3203	1.6804	1.6975	1.6975	1.6975	1.6804	1.6975
12	.9431	1.4937	1.6975	1.5089	1.3203	1.4937	1.6975
13	.9431	1.1203	1.1317	1.5089	1.1317	.9335	1.3203
14	.9431	1.307	1.5089	1.6975	1.3203	1.307	1.3203
15	1.1317	1.6804	1.6975	1.6975	1.5089	1.6804	1.6975
16	.9431	1.6804	1.6975	1.6975	1.6975	1.6804	1.6975
17	.7545	1.6804	1.6975	1.6975	1.6975		1.6975
18	.5658	1.4937	1.5089	1.5089	1.6975		1.6975
19	.5658		1.4937	1.5089	1.5089	1.4937	1.6975
20	.5658		1.307	1.5089	1.5089	1.4937	1.6975
21	.5658		1.4937	1.5089	1.5089	1.4937	1.5089
22	1.1317		1.4937	1.3203	1.5089	1.4937	1.5089
23	1.1317		1.4937	1.3203	1.3203	1.4937	1.5089
24	1.5089	1.1317	1.3203	1.307	1.3203	1.5089	1.307
Max	1.5089	1.6975	1.6975	1.6975	1.6975	1.6804	1.6975
Min	.5658	.5658	1.1317	.9335	1.1317	.9335	.9335
Avg	1.0149	1.1351	1.4272	1.4322	1.3675	1.4222	1.4480

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.452	2.452	1.5089	2.0386	1.3957	2.5652	2.0576
2	2.452	2.4897	1.5089	1.9814	1.4335	2.5274	1.7528
3	2.452	2.5274	1.5089	2.0195	1.4146	2.452	2.5911
4	2.452	2.6406	1.5089	1.9433	1.3957	2.452	2.5149
5		2.5652	1.8861	1.9814	1.4146	2.452	2.3053
6		2.5274	2.0748	1.9814	1.4146	2.452	2.0195
7		2.5274	2.0748	2.0576	1.4335	2.5274	2.0005
8	2.5463	2.452	2.0748	1.4563	1.3957	2.5393	1.9624
9	2.6406	2.5274	2.0748	.9425	.9808	2.4764	2.5911
10	2.6972	2.5652	2.0748	.8215	1.6975	2.5766	2.6292
11	2.7538	2.6513	2.1125	.8488	2.1125	2.7054	2.6595
12	2.584	2.5579	2.0748		2.037	2.0767	2.6406
13	2.4897	1.6804	1.905	.679	1.8861	1.4861	1.9239
14	2.4143	1.9418	2.0182	.6602	2.2257	2.0386	2.037
15	2.1125	2.0576	2.0748	.6413	2.3388	2.5149	2.0748
16	1.9805	1.829	2.0559	.6602	2.4143	2.4387	2.0936
17	2.3388	2.3053	2.037	.679	2.3577		2.0748
18	2.5086	2.1338	1.9993	.6602	2.5274		2.0559
19	2.5463		2.0005	.6979	2.584		2.0559
20			2.0195	.679	2.6029	1.9052	2.037
21	2.5463		2.0767	1.358	2.6406	1.848	2.6406
22	2.452		2.0005	1.4335	2.7161	2.5149	2.5274
23	2.6029		2.0957	1.4335	2.6783	2.6482	2.6029
24	2.5463	2.6029	1.4146	2.0195	1.4146	2.6406	2.4387
Max	2.7538	2.6513	2.1125	2.0576	2.7161	2.7054	2.6595
Min	1.9805	1.6804	1.4146	.6413	.9808	1.4861	1.7528
Avg	2.4784	2.3702	1.9242	1.2902	1.9380	2.3732	2.2620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 211 / 11 KV Mhashoba Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7918		1.5424	1.7541	1.8861	1.5424
2	1.6975		1.5424	1.7918	1.8861	1.5089
3	1.6975		1.5089	1.773	1.8861	1.4754
4	1.6975		1.4251	1.7918	2.0748	1.3748
5			1.4083	1.773	2.037	1.4083
6			1.4754	1.7541	1.9616	1.4419
7			1.5257	1.7918	1.8673	1.5592
8			1.829	1.8107	1.829	1.5927
9			1.9022	1.8861	2.0485	1.7604
10			1.8473	2.1502	2.1216	1.8275
11			1.9805	2.1879	2.0119	2.0936
12		2.037		1.8861	1.7101	
13		1.5655	1.9239	1.5278	1.5089	2.0748
14		2.0748	2.0182	1.6975	1.6933	1.8296
15		2.0936	2.0182	1.9239	1.9281	1.9993
16		2.1125	2.037	1.9993	1.8945	2.0936
17		2.0936	2.037	2.0748		1.9993
18		2.037	1.8861	2.1125		1.9805
19		1.7604	1.8861	1.9616		1.9993
20		1.6095	1.8484	1.9239	1.4419	1.8861
21		1.6263	1.8673	1.9616	1.6766	1.773
22		1.6263	1.8484	1.8484	1.6766	1.7918
23		1.576	1.8107	1.8861	1.6263	1.773
24	1.7918		1.5927	1.7918	1.9239	1.5592
Max	1.7918	2.1125	2.037	2.1879	2.1216	2.0936
Min	1.6975	1.5655	1.4083	1.5278	1.4419	1.3748
Avg	1.7352	1.8510	1.7722	1.8775	1.8424	1.7541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 402 / 33 KV JAY GANGATARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.5638	6.5638	6.4506	6.3375	6.3375	6.3375	6.5072
2	6.4506	6.5638	6.4506	6.3375	6.2243	6.3375	6.5072
3	6.4506	6.677	6.4506	6.2243	6.2243	6.4506	6.4506
4	6.3375	6.4506	6.3375	6.1677	6.2809	6.4506	6.2243
5	6.3375	6.4506	6.3375	6.1677	6.2243	6.3375	6.2243
6	6.3375	6.4506	6.3375	6.2243	6.1677	6.3375	6.3375
7	6.3375	6.4506	6.3375	6.2809	6.3375	6.3375	6.3375
8	6.3375	6.3375	6.4506	6.4506	6.2243	6.3855	6.677
9	6.4506	6.3375	6.5638	6.3295	6.3375	6.4975	6.7901
10	6.4506	6.3375	6.5638	6.1614	6.677	6.4975	6.7335
11	6.3375	6.7335	6.5072	6.2243	6.4506	6.8467	6.6204
12	6.7335	6.5638	6.4506	6.2243	6.677	6.7901	6.5638
13	6.4506	6.2809	6.5638	6.2243	6.3375	6.7335	6.394
14	6.4506	6.7335	6.5072	6.2243	6.4506	6.677	6.4506
15	6.5638	6.677	6.5638	6.3375	6.5638	6.6204	6.5638
16	6.5638	6.3375	6.5638	6.3375	6.677	6.677	6.5072
17	6.677	6.6204	6.5072	6.1111	6.3375		6.5638
18	6.7901	6.677	6.5072	5.7716	6.5638		6.677
19	6.5638		6.5638	6.2243	6.5638	1.1883	6.5638
20	6.5638		6.5638		6.2243	3.2253	6.2243
21	6.4506		6.3375	6.3375	6.2243	3.2253	6.394
22	6.4506		6.394	6.2243	6.3375	6.7901	6.3375
23	6.677		6.5638	6.5072	6.3375	6.6204	6.394
24	10.4504	6.5638	6.5638	6.3375	6.2243	6.3375	6.6204
Max	10.4504	6.7335	6.5638	6.5072	6.677	6.8467	6.7901
Min	6.3375	6.2809	6.3375	5.7716	6.1677	1.1883	6.2243
Avg	6.6574	6.5162	6.4766	6.2507	6.3752	5.9864	6.4860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 201 / 11 KV KABNOOR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.2689	1.5432	1.5432	1.5432	1.5432	1.5432
2	1.5432	1.2346	1.5432	1.5432	1.5432	1.5432	1.5432
3	1.5432	1.2346	1.5432	1.5432	1.5432	1.5432	1.5432
4	1.5432	1.2346	1.5432	1.5432	1.5432	1.5432	1.5432
5	1.5432	1.2346	1.6118	1.5432	1.5432	1.6118	1.5432
6	1.5432	1.2689	1.6118	1.5432	1.5432	1.6118	1.5432
7	1.5432	1.3032	1.6804	1.5432	1.6289	1.5432	1.5432
8	1.3717	1.4403	1.6804	1.5432	1.6289	1.5432	1.5775
9	1.4575	1.8347	1.9204	1.5432	1.8004	1.9547	1.8004
10	1.4575	2.0576	1.8861	1.8861		1.989	1.9719
11	1.4575	2.0576	1.8861	2.0576		2.1262	2.2291
12	1.3717	2.0576	1.7147	1.8861	1.9719	1.8861	1.8004
13	.9945	1.6461	1.3717	1.6289	2.0576	1.5432	1.3717
14	1.166	1.7147	1.7147	2.0576	1.8861	1.749	1.7147
15	1.2003	1.9547	1.8861	1.9719	2.0576	1.8861	1.8861
16	1.2003	2.0576	1.8861	2.0576	1.8861	2.0233	1.8861
17	1.2003	1.9547	1.8861	2.0576	1.8861	2.2291	1.8004
18	1.166	1.8861	1.9719	1.9719	1.989	2.1948	1.8004
19	1.0631	1.8861	1.8861	1.8861	2.0576	2.0576	1.7147
20	1.0631	1.9204	1.8004	1.8861	1.9204	1.9547	1.8861
21	1.2689	1.9204	1.8861	1.8861	1.9204	1.8861	1.9719
22	1.3203	1.8861	1.8861	1.8861	1.9204	1.8861	1.8861
23	1.3203	1.7833	1.8861	1.8004	1.8861	1.8861	1.8004
24	1.8004	1.3032	1.7147	1.8861	1.7147	1.7147	1.7147
Max	1.8004	2.0576	1.9719	2.0576	2.0576	2.2291	2.2291
Min	.9945	1.2346	1.3717	1.5432	1.5432	1.5432	1.3717
Avg	1.3653	1.6725	1.7475	1.7790	1.7942	1.8104	1.7340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 202 / CHANDUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8959	1.6461	3.2579	3.1722	3.2007	3.4294	3.4294
2	3.0864	1.6118	3.2579	3.1722	3.2579	3.4294	3.4294
3	3.0864	1.6118	3.2579	3.1722	3.2579	3.4294	3.4294
4	3.0864	1.6118	3.2579	3.1722	3.2579	3.4294	3.4294
5	3.0864	1.6118	3.2579	3.1722	3.3436	3.4294	3.4294
6	3.0864	1.6118	3.2579	3.1722	3.5151	3.4294	3.4294
7	3.1722	1.6118	3.4294	3.3436	3.5151	3.5322	3.6694
8	2.6578	1.8861	3.4294	3.4294	3.4294	3.4294	3.5665
9	2.4006	2.7092	4.3896	4.201	3.8104	4.3553	3.5056
10	2.6578	4.2867	4.4582	4.2867	4.4582	4.4239	3.7342
11	2.572	4.0486	4.7154	4.039	4.561	4.4582	3.9628
12	2.4006	4.1838	4.4582	3.5056	4.2867	4.2867	3.658
13		2.6749	2.7435	2.7435	2.8807	2.6406	2.6578
14	1.8861	4.1152	3.4294	3.3532	3.9438	4.0809	3.6008
15	2.0576	4.1838	4.4582	3.8866	4.4239	4.1495	3.7342
16	2.0748	4.2524	4.4582	3.8866	4.561	4.1667	3.7342
17	2.0576	3.8218	4.4582	3.658	4.1457	4.1667	3.7342
18	1.8861	3.7723	4.2867	3.658	4.1152	4.1152	3.5818
19	1.406		4.2867	3.658	3.738	3.9438	3.5056
20	1.8861	3.4294	3.6008	3.2007		3.8066	3.5056
21	1.749	3.7723	3.6008	3.2769	3.7723	3.9438	3.4294
22	1.749	3.7037	3.7723	3.2769	3.7723	3.9438	3.4294
23	1.749	3.6694	3.7723	3.4294	3.7723	3.9438	3.4294
24	4.7344	1.7147	3.2579	3.7723	3.2769	3.6008	3.6008
Max	4.7344	4.2867	4.7154	4.2867	4.561	4.4582	3.9628
Min	1.406	1.6118	2.7435	2.7435	2.8807	2.6406	2.6578
Avg	2.4967	2.9366	3.7730	3.4849	3.752	3.8152	3.5257

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 203 / 11 KV COLLAGE FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18
HR	Load (MW)
24	1.406
Max	1.406
Min	1.406
Avg	1.406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 205 / DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.7545	1.166	1.3717	1.2955	1.2955	1.5432
2	1.2955	.7545	1.166	1.3717	1.2955	1.2955	1.4575
3	1.2955	.7545	1.166	1.3717	1.2955	1.2955	1.3717
4	1.2955	.7545	1.166	1.3717	1.2955	1.2955	1.3717
5	1.2955	.7545	1.2308	1.3717	1.2955	1.3927	1.3717
6	1.2955	.7888	1.2308	1.3717	1.2955	1.3927	1.4575
7	1.2193	.823	1.3927	1.3717	1.448	1.5223	1.5432
8	1.0669	1.166	1.4575	1.5432	1.448	1.5223	1.5775
9	1.0669	1.7833	1.7814	1.9719	1.6766	1.8461	1.448
10	1.0669	1.9433	2.0576	1.9719	1.8623	1.9547	1.6766
11	1.2003	1.9433	2.0576	1.7528	1.9433	1.8861	1.9719
12	1.0974	1.8785	2.0576	1.6766	1.8461	1.7833	1.2003
13	.8916	1.1984	1.2003	1.2193	1.1336	1.3032	1.5242
14	.9259	1.6194	1.5432	1.6766	1.6194	1.749	1.6766
15	.9945	1.8138	1.9719	1.7528	1.8138	1.8861	
16	.9945	1.8785	1.9719	1.7528	1.8785	1.9204	1.6766
17	.9945	1.749	1.9719	1.6766	1.8785	1.9204	1.6004
18	.8916	1.749	1.8004	1.6766	1.8138	1.9204	1.6766
19	.7545	1.8138	1.8004	1.6766	1.7814		1.7528
20	.7545	1.7814	1.7147	1.5242	1.749		1.6766
21	.7888	1.6194	1.7147	1.5242	1.749	1.6804	1.6766
22	.7888	1.587	1.6289	1.5242	1.749	1.6804	1.6766
23	.7888	1.5546	1.6289	1.448	1.6194	1.7147	1.6004
24	1.5242	.7888	1.4575	1.6289	1.3717	1.6194	1.7147
Max	1.5242	1.9433	2.0576	1.9719	1.9433	1.9547	1.9719
Min	.7545	.7545	1.166	1.2193	1.1336	1.2955	1.2003
Avg	1.0691	1.3855	1.5973	1.5666	1.5898	1.6308	1.5758



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 207 / CHANDUR KARNUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3048	.0162	.0171	.0171	.0162	.2743
2	.381	.3353	.0162	.0171	.0171	.0162	.2743
3	.381	.381	.0162	.0171	.0171	.0162	.2743
4	.381	.381	.0162	.0171	.0171	.0162	.3048
5	.2286	.4572	.0162	.0171	.0171	.0162	.3353
6	.2743	.5487	.0162	.0171	.0171	.0162	.3658
7	.2743	.6097	.0162	.0171	.0171	.0162	.4268
8	.2439	.5792	.0162	.0171	.0171	.0162	.4268
9	.0171	.0152	.0162	.0171	.0171	.0162	.0171
10	.0171	.0162	.6859	.5144	.5668	.5487	.0171
11	.0152	.0162	.7716	.6859	.6478	.6097	.0171
12	.0152	.0162	.7716	.6859	.6478	.6401	.0171
13	.0152	.0162	.7716	.6097	.583	.6706	.0171
14	.0152	.0162	.7716	.6097	.583	.7011	.0171
15	.0152	.0162	.7716	.6097	.6173	.6706	.0171
16	.0152	.0162	.6001	.6097	.583	.6401	.0171
17	.0152		.5144	.5335	.583	.6097	.0171
18	.0152		.0171	.0171	.0162	.0152	.0171
19	.0152	1.3117	.0171	.0171	.0162	.0152	.0171
20	.0152	.0162	.0171	.0171	.0162	.0152	.0171
21	.0152	.0162		.0171	.0162	.0152	.0171
22	.0152	.0162		.0171	.0162	.0152	.0171
23	.2743	.0162	.0171	.0171	.0162	.3048	.3353
24	.381	.3048	.0162	.0171	.0171	.0162	.3048
Max	.381	1.3117	.7716	.6859	.6478	.7011	.4268
Min	.0152	.0152	.0162	.0171	.0162	.0152	.0171
Avg	.1424	.2458	.2677	.2138	.2117	.2347	.1484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.3772	.583	.6001	.6001	.583	.6173
2	.6001	.3429	.583	.6001	.6001	.583	.583
3	.6001	.3429	.583	.6001	.6001	.583	.583
4	.6001	.3429	.583	.6001	.6001	.583	.583
5	.6001	.3429	.583	.6001	.6001	.583	.583
6	.6001	.3429	.583	.6001	.6516	.583	.583
7	.6001	.3772	.583	.5144	.6001	.583	.6173
8		.5144	.583	.5144	.6001	.583	.5658
9	.4287	.7545	.7716	.6859	.6859	.6859	.6859
10	.4801	.7545	.6859	.6859	.7716	.6859	.7716
11	.4458	.7545	.6859	.6859	.7545	.7202	.7716
12	.4115	.7545	.6859	.6859	.7545	.7202	.6859
13	.3429	.583	.5144	.5144	.6516	.6516	.5144
14	.4115	3.7723	.6859	.6859	.6516	.6173	.6859
15	.4115	3.9438	.8573	.6859	.7202	.6859	.7716
16		.7888	.8573	.7716	.7545	.7202	.7716
17	.2915	.7202	.8573	.7716	.7545	.7202	.6859
18	.2915	.7202	.6859	.6859	.6859	.7202	.6859
19	.2915	.7202	.6859	.6859	.7202	.6859	.6859
20	.3086	.7202	.6859	.6001	.6859	.6859	.6859
21	.4115	.7202	.6859	.6859	.6859	.6859	.6859
22	.4458	.7202	.6859	.6859	.6859	.7202	.6859
23	.4458	.6859	.6859	.6859	.6859	.7202	.6859
24	1.4575	.4115	.6173	.6859	.6859	.6859	.6859
Max	1.4575	3.9438	.8573	.7716	.7716	.7202	.7716
Min	.2915	.3429	.5144	.5144	.6001	.583	.5144
Avg	.5074	.8545	.6666	.6466	.6745	.6573	.6609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 201 / 11 KV HANUMANNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	.5935	1.7147	1.7295	1.5623	1.6804	1.8861
2	1.5432	.6104	1.6804	1.6448	1.5466	1.6461	1.7661
3	1.3717	.5765	1.6804	1.6278	1.5466	1.6118	1.7661
4	1.3717	.6613	1.6289	1.6448	1.4842	1.6118	1.7147
5	1.4403	.7461	1.6289	1.6448	1.4998	1.5775	1.7147
6	1.4746	.78	1.6461	1.6787	1.5154	1.6804	1.8004
7	1.4746	.8648	1.7318	1.7804	1.6404	1.7833	1.8519
8	1.4403	1.5261	1.9547	2.0178	1.8591	1.8519	2.0062
9	1.3717	2.1704	2.1776	2.34	2.0622	2.2462	2.2805
10		2.2552	2.2634	2.2891	2.0466	2.2634	2.2977
11		2.2119	2.2891	2.1247	2.3663	2.2634	2.3061
12		2.1948	2.1874	1.9841	2.0576	1.9719	2.1534
13		1.5947	1.6278	1.4998	1.6461	1.6289	1.4074
14	.5426	1.869	2.0178	1.7341	1.9204	2.0919	1.9161
15	.6274	2.3491	2.2043	2.1403	2.2634	2.3148	2.2213
16	.6783	2.3663	2.3569	2.1715	2.2805	2.3148	2.2552
17	.6104	2.2462	2.2721	2.1091	2.2805	2.3148	2.2043
18	.4917	2.2119		2.0309	2.2462	2.3148	2.2213
19	.4917	2.0748	2.1026	1.9685	2.0919	2.3148	2.0517
20	.5426	1.869	2.0348	1.8122	2.0748	2.0576	2.0348
21	.7461	1.9376	2.0008	1.7966	2.1091	2.0576	2.0687
22	.6952	1.9204	1.8482	1.7654	1.9719	2.0233	1.9839
23	.6783	1.8861	1.9161	1.7185	1.8519	2.0233	2.0517
24	1.869	.6274	1.7147	1.8652	1.6091	1.7147	1.9719
Max	1.869	2.3663	2.3569	2.34	2.3663	2.3148	2.3061
Min	.4917	.5765	1.6278	1.4998	1.4842	1.5775	1.4074
Avg	1.0502	1.5893	1.9426	1.8799	1.8972	1.9733	1.9972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.4239	.8676	.7969	.788	.8676	.8573
2	.6001	.4239	.8299	.763	.788	.8299	.7716
3	.5144	.4239	.7922	.763	.7712	.7922	.7716
4	.5144	.4578	.7922	.763	.7545	.7922	.7373
5	.5144	.4578	.7922	.78	.7712	.7545	.7373
6	.0343	.4917	.811	.7969	.8383	.9054	.823
7	.5144	.5426	.8299	.7969	.8383	.9054	.8573
8	.6859	.7291	.9997	.8817	.8886	.9808	.9431
9	.8059	1.0004	1.1506		1.0562	1.1128	1.046
10	.8059	.9835	1.2071	1.0852	1.0059	1.1506	1.0288
11	.8309	1.1506	1.0682	1.0562	1.1694	1.0288	1.0343
12		1.1128	1.0174	1.0898	1.0562	.9945	.9835
13		.8299	.763	.7209	.8488	.7202	.7122
14	.6104	.9808	.9665	.9389	1.0374	.9431	.8987
15	.763	1.1128	1.0852	1.0059	1.0751	1.0631	1.0004
16	.8309	1.1506	1.1361	1.0227	1.094	1.0631	.9835
17	.7291	1.1694	1.0513	1.0395	1.1128	1.0631	.9496
18	.5256	1.1317	1.0682	.9724	1.094	1.0631	.9496
19	.4748	1.1128	.9835	.9892	1.0374	1.0288	.8478
20	.4748	1.0751	.9326	.9389	1.0185	.9945	.9156
21	.5087	1.0374	.9326	.9724	1.0751	.9431	.9665
22	.5087	.9997	.9156	.9054	1.0185	.8916	.8478
23	.4917	.9808	.8817	.8718	.9431	.8916	.8309
24	.8573	.4578	.9431	.8309	.8215	.9054	.8573
Max	.8573	1.1694	1.2071	1.0898	1.1694	1.1506	1.046
Min	.0343	.4239	.763	.7209	.7545	.7202	.7122
Avg	.6021	.8432	.9507	.9035	.9543	.9452	.8896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 204 / 11 KV NEW COLLAGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.5596	1.226	1.0004	1.0288	1.1317	1.0288
2	1.0288	.5087	1.1506	.8817	.9945	1.094	.9431
3	.8573	.5087	1.1317	.8817	.9774	1.094	.9431
4	.8573	.5087	1.094	.8987	.9259	1.0562	.8573
5	.8573	.5256	1.0751	.9156	.9259	1.0562	.8573
6	.9431	.5426	1.0751	.9156	.9602	1.0751	.9431
7	.9431	.5935	1.0374	.9326	.9602	1.1506	1.0288
8	.9431	.8139	1.1883	1.0513	1.1317	1.1883	1.0974
9	.8573	1.2039	1.3392	1.2717	1.286	1.4146	1.3032
10	.8745	1.2717	1.3957	1.2209	1.3203	1.3769	1.286
11	.8817	1.3769	1.2887	1.3032	1.4523	1.2517	1.0852
12	.6952	1.1694	1.1361	1.2174	1.2071	1.1317	.9156
13	.6274	.9997	.8309	.8573	.8676	.8059	.7291
14	.763	1.2826	1.0174	1.1317	1.2826	.9945	1.1022
15	.78	1.3392	1.17	1.166	1.3769	1.2346	1.153
16	.7969	1.3769	1.2039		1.3957	1.2689	1.2378
17	.6783	1.358	1.2378	1.3203	1.3769	1.2689	1.2039
18	.5426	1.358	1.2209	1.2174	1.4146	1.2346	1.2209
19	.5087	1.3203	1.153	1.2346	1.3392	1.2003	1.2039
20	.5596	1.1883	1.0852	.8745	1.2826	1.0974	1.1869
21	.6104	1.2826	1.1361	1.1831	1.3957	1.1317	1.2039
22	.6443	1.2637	1.1191	1.1831	1.2637	1.2003	1.1191
23	.6274	1.2449	1.153	1.1488	1.2449	1.2003	1.1022
24	1.4575	.5935	1.2637	1.0852	1.1317	1.1317	1.1145
Max	1.4575	1.3769	1.3957	1.3203	1.4523	1.4146	1.3032
Min	.5087	.5087	.8309	.8573	.8676	.8059	.7291
Avg	.8068	1.0080	1.1554	1.0823	1.1893	1.1579	1.0778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 201 / 11 KV Dhangarmal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2048	.9979	1.182	1.1218	1.1517	1.2178	1.1104
2	1.2178	.9979	1.1462	1.0745	1.134	1.1946	1.0745
3	1.134	.9709	1.086	1.0974	1.1104	1.2071	1.0498
4	1.0974	.9335	1.086	1.1706	1.0745	1.2437	1.0136
5	1.1462	.9709	1.1222	1.1458	1.1283	1.2936	1.0136
6	1.0867	1.0164	1.1999	1.1706	1.1462	1.2308	1.0924
7	1.0745	1.0974	1.1694	1.1568	1.1871	1.2178	1.1104
8	1.0288	1.0692	1.1919	.756	1.2226	1.2269	1.1517
9	1.0288	1.1789	1.2689	1.1317	1.3523	1.2689	1.2094
10	1.0517	1.2136	1.2483	1.1789	1.2689	1.2689	1.2094
11	1.0985	1.2483	1.2003	1.1568	1.2971	1.262	1.2483
12	1.0745	1.2269	1.2346	1.1568	1.2536	1.2403	1.2136
13	.9979	1.134	1.0867	1.1568	1.0745	1.0745	1.0745
14	.9671	1.2048	1.1871	1.1317	1.2489	1.267	1.134
15	.9922	1.2269	1.2536	1.1191	1.3611	1.2894	1.2136
16	1.0136	1.2689	1.2689	1.1317	1.3321	1.1946	1.1789
17	.9313	1.3032	1.2483	1.1568	1.2483		1.1096
18	.9335	1.1218	1.2269	.9774	1.2269		1.1568
19	.9149		1.2048	1.0387	1.1568	1.1462	1.1694
20	.9335	1.1222	1.1694	1.1104	1.182	1.182	1.2403
21	.9979	1.258	1.2178	1.1871	1.1104	1.2048	1.2178
22	1.0164	1.2403	1.1946	1.1694	1.0974	1.1871	1.2308
23	1.0349	1.2403	1.134	1.1871	1.2178	1.1641	1.1568
24	1.2048	1.0164	1.2178	1.1568	1.1694	1.2178	1.1462
Max	1.2178	1.3032	1.2689	1.1871	1.3611	1.2936	1.2483
Min	.9149	.9335	1.086	.756	1.0745	1.0745	1.0136
Avg	1.0492	1.1330	1.1894	1.1184	1.1980	1.2182	1.1469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 203 / 11 KV Ghorpade

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9054	1.0374	.9808	.9054	1.0185	.6413	1.0185
2	.9054	1.0185	.9808	.8299	1.0185	.679	.9808
3	.9431	.9431	.9431	.7545	.9431	.679	.9431
4	.9808	.9431	1.0185	.7167	.9619	.679	.9808
5	.9808	.9808	.9808	.7167	.9619	.6413	1.0185
6	1.0185	.9997	1.0185	.695	1.0185	.6413	1.0374
7	.9808	1.0562	.9997	.6413	1.0185	.6413	1.0562
8	1.0185	.9619	1.0562	.6036	.9997	.679	1.094
9	1.0185	1.0185	.9808	.5281	1.0562	.695	1.0562
10	.9808	1.0185	.9808	.4961	1.094	.7167	.9808
11	.9431	.9808	.9808	.5373	1.0562	.9431	1.0562
12	1.0562	.9431	.9808	.5487	1.0185	1.0185	1.0185
13	1.0562	.9808	.9808	.5014	1.0562	.9431	1.0185
14	1.0562	1.0185	1.0185	.724	1.0185	.9431	1.0185
15	.9808	1.0562	1.0562	.8676	1.0562	1.0562	1.0185
16	.9808	1.0185	1.0185	.8676	1.094	.9431	1.0185
17	1.0185	.9808	1.0185	.8676	1.0562		1.0185
18	1.0185	1.0185	1.0185	.8865	1.0562		.9808
19	.9808	.9808	.9431	.8299	1.0562	.9808	.9808
20	.9808		.9808	.9054	.9808	.9431	.9431
21	1.0185	.9808	.9808	.9431	.9808	1.0185	.9808
22	1.0374	.9808	.9431	.9808	.9054	1.0185	.9808
23	1.0185	.9619	.9431	.9997	.679	1.0185	.9808
24	.9054	1.0185	.9431	.9054	.9808	.6413	1.0185
Max	1.0562	1.0562	1.0562	.9997	1.094	1.0562	1.094
Min	.9054	.9431	.9431	.4961	.679	.6413	.9431
Avg	.9910	.9956	.9894	.7605	1.0036	.8255	1.0083

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochoi Sub Station

Feeder No / Name : 204 / 11 KV Chavan

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6598	1.4335	1.6975	1.6598	1.5844	1.6975	1.6598
2	1.6598	1.3957	1.6598	1.5844	1.5466	1.6598	1.6598
3	1.5089	1.358	1.5844	1.5089	1.5089	1.6598	1.6221
4	1.5466	1.358	1.5844	1.5089	1.5089	1.6975	1.5466
5	1.5844	1.358	1.6221	1.5466	1.5844	1.6975	1.5844
6	1.5089	1.4335	1.6598	1.5844	1.5844	1.6598	1.6221
7	1.5844	1.5089	1.6975	1.6598	1.6598	1.6598	1.6598
8	1.5844	1.5844	1.6975	1.6598	1.6598	1.6975	1.6598
9	1.5844	1.773	1.773	1.5089	1.8484	1.9239	1.8107
10	1.6221	1.773	1.8107	1.5844	1.9616	1.8107	1.773
11	1.6598	1.8107	1.773	1.5844	1.9239	1.8107	1.8861
12	1.6975	1.6975	1.7353	1.5844	1.8107	1.8107	1.7353
13	1.5089	1.5844	1.6221	1.5089	1.5844	1.6221	1.5089
14	1.5844	1.6975	1.6598	1.5466	1.6598	1.6975	1.7353
15	1.6598	1.7353	1.6975	1.5089	1.8484	1.8107	1.8107
16	1.6598	1.6975	1.7353	1.5089	1.8861	1.6975	1.773
17	1.5089	1.7353	1.773	1.5089	1.8107		1.8107
18	1.5844	1.8107	1.6598	1.4335	1.773		1.773
19	1.5466	1.773	1.6975	1.3957	1.7353	1.6598	1.6598
20	1.5089	1.7353	1.6598	1.5089	1.6975	1.6598	1.5844
21	1.5089	1.6975	1.6598	1.6221	1.6598	1.6975	1.5466
22	1.5089	1.6975	1.6221	1.5844	1.5844	1.6598	1.5089
23	1.5089	1.6975	1.5844	1.5844	1.7353	1.6598	1.6598
24	1.6598	1.4335	1.6975	1.6598	1.5844	1.6975	1.6221
Max	1.6975	1.8107	1.8107	1.6598	1.9616	1.9239	1.8861
Min	1.5089	1.358	1.5844	1.3957	1.5089	1.6221	1.5089
Avg	1.5812	1.6158	1.6818	1.5561	1.6975	1.7112	1.6755



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 205 / 11 KV VIVEKANAND NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6447	.4904	.5853	.5731	.5792	.6219	.6154
2	.6089	.4904	.5853	.5487	.543	.5544	.5853
3	.5792	.4527	.5544	.543	.4755	.5175	.5487
4	.5487	.415	.4854	.5121	.4435	.5853	.5175
5	.6447	.4527	.5175	.6283	.462	.5487	.5544
6	.5959	.5093	.5914	.6219	.4755	.5853	.5853
7	.6089	.5281	.6154	.5487	.5552	.6661	.6219
8	.583	.5853	.6556	.4755	.543	.6935	.6584
9	.6173	.7537	.7282	.5258	.6687	.6859	.7186
10	.5959	.6516	.6443	.5258	.6859	.6859	.5895
11	.583	.6516	.583	.5258	.7011	.6661	.6661
12	.679	.7011	.6241	.5609	.6661	.6447	.631
13	.3772	.4854	.4908	.5373	.4854	.5373	.5068
14	.5014	.5201	.5731	.583	.5373	.6878	.6089
15	.543	.6935	.631	.6173	.6154	.6733	.631
16	.5068	.6935	.6935	.6173	.6588	.6335	.631
17	.415	.6661	.7011	.6516	.6859		.6661
18	.3772	.6274	.6516	.631	.6661		.6935
19	.3292	.6024	.6089	.543	.5792	.5359	.5731
20	.4108	.6268	.5373	.5792	.5121	.5544	.5373
21	.4904	.7059	.5731	.5731	.5853	.6219	.6036
22	.4904	.6516	.6219	.5792	.5544	.6584	.6413
23	.4715	.6401	.6379	.5611	.6516	.6516	.7167
24	.6379	.4715	.6219	.5731	.5611	.6219	.6516
Max	.679	.7537	.7282	.6516	.7011	.6935	.7186
Min	.3292	.415	.4854	.4755	.4435	.5175	.5068
Avg	.535	.5861	.6047	.5682	.5788	.6196	.6147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 202 / 11KV SOOT GIRNI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 203 / 11KV URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 204 / 11 KV VITTHAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.5089
Max	1.5089
Min	1.5089
Avg	1.5089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 205 / 11KV JAWHARNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 209 / L-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 210 / 11 KV GANGA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 211 / 11 KV INDUSTRIAL EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 401 / 33 KV KABNOOR (METE&KSL)  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 402 / 33 KV ICHALKARANJI  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 403 / 33 KV SHAHAPUR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 404 / 33 KV KURUNDWAD

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 405 / 33 KV SHIRADWAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 406 / 33 KV KABNOOR VILLAGE  
Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 407 / 33KV SHAHAPUR ESTATE  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 408 / 33 KV YASHOLAXMI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 409 / 33 KV Parvati

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 201 / 11 kv Chokak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655	.0655	.0686	.4588	.4801	.9602	
2	.0655	.0655	.0686	.5243	.5487	.9602	
3	.0655	.0655	.0686	.5243	.5487	.9602	
4	.0655	.0655	.0686	.5571	.5487	.9602	
5		.0655	.0686	.5898	.6859	.9602	
6	.0983	.0655	.0857	.639	.9602	.9945	
7	.0983	.0819	.0686	1.0486	1.3717	1.2689	
8	.0655	.0819	.0686	1.1142	1.406	1.2689	
9			.0686	.9503	1.0631	.9602	.4287
10				.7716	.7888	.7209	.2743
11	1.1271	1.1317	1.0159	.0686	.0655		
12	1.1271	1.2003	.852	.0686	.0655	.0655	
13	1.2266	1.2346	1.0322	.0686	.0655	.0655	.0686
14		1.2003	.9831	.0686	.0655	.0655	
15		.8596	.9012	.0686	.0655	.0655	
16	1.0288	.9259	.8848	.0686	.0655	.0655	
17	.9831	.5487	.2949			.0655	
18	.7537	.4287		.0686			
19		.0686	.1147	.0686			
20		.0686	.0983	.0686	.0655		.0857
21	.0819	.0686	.0819	.0857	.0655		.0857
22	.0819	.0686	.0655	.0857	.0655		.0686
23		.0686	.0819		.0655		.0857
24	.0819	.0819	.0686	.0655	.0857	.0655	
Max	1.2266	1.2346	1.0322	1.1142	1.406	1.2689	.4287
Min	.0655	.0655	.0655	.0655	.0655	.0655	.0686
Avg	.4385	.3869	.3232	.3651	.4354	.6161	.1568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 202 / 11KV Mudshingi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.5089	1.6975	1.5089	1.3203	1.6057	
2	1.4146	1.5089	1.6032	1.4146	1.3203	1.531	
3	1.4146	1.4712	1.6032	1.4146	1.3203	1.4563	
4	1.5089	1.4712	1.6032	1.4712	1.3203	1.4563	
5	1.5844	1.5089	1.6598	1.4712	1.358	1.4937	
6	1.6975	1.5844	1.8861	1.5844	1.5089	1.4937	
7	1.8861	1.6975	1.8861	1.5089	1.6032	2.0165	
8	1.5089	1.6598	1.7918	1.3203	1.4712	1.8671	
9	1.3957	1.4523	1.6975	1.3203	1.6598	1.9044	1.4712
10	1.4335		1.6975	1.2826	1.8298	1.7353	1.4335
11	1.5089	1.307	1.6787	1.226	1.7924	1.773	1.5089
12	1.5089	1.3817	1.8484	1.226	1.7551	1.7353	1.6032
13	1.4335	1.4563	1.6032	1.0562	1.8298	1.8861	1.6032
14		1.6804	1.9239	1.226	1.8671	1.7918	1.8861
15		1.9418	1.8861	1.2826	2.0165	1.7353	1.7918
16		1.8298	1.8861	1.2826	2.0538	1.6975	1.7918
17	1.8861		1.773		1.9418	1.9239	1.8861
18	2.037	1.6032		1.358	.1867		2.0748
19		1.8861	1.8861	1.4712	2.6886		2.2634
20		1.9805	2.0748	1.6598	2.1658		2.2634
21	1.9805	1.9239	2.0748	1.8861	2.1658		2.0748
22	1.9616	1.8861	2.037	1.6598	2.0538		1.9805
23		1.9239	1.8484		1.8298		1.6975
24	1.8861	1.6598	1.7353	1.7353	1.358	1.6804	
Max	2.037	1.9805	2.0748	1.8861	2.6886	2.0165	2.2634
Min	1.3957	1.307	1.6032	1.0562	.1867	1.4563	1.4335
Avg	1.6420	1.6511	1.7992	1.4258	1.6840	1.7102	1.8220

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 203 / 11 KV HERLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.5601	.6348	.5601	.6348	.5601	
2	.5975	.5601	.5601	.5601	.5601	.5601	
3	.5975	.5601	.5601	.5601	.5601	.5601	
4	.6348		.5601	.5975	.5601	.5228	
5	.6722	.5975	.5975	.6348	.5975	.5228	
6	.7095	.6348	.6722	.7468	.679	.6348	
7	.7468	.6348	.6348	.5975	.6348	.6348	
8	.7095	.6348	.5975	.5975	.5975	.5601	
9	.7095	.6722	.5975	.6348	.5975	.6348	.5601
10	.6722		.7095	.6348	.5975	.6348	.5975
11	.6722	.7095	.7095	.6722	.7095	.6348	.583
12	.6348	.7468	.7468	.6722	.7468	.6348	.6348
13	.7468	.7842	.7468	.6348	.7468	.6348	.5975
14		.7468	.7842		.7095	.6348	.5975
15		.7468	.7468		.7095	.6348	.6348
16	.7095	.7842	.7842		.7095	.6722	.6348
17	.7095	.7095	.7468		.6722	.7468	.6348
18	.6908	.6722		.6722	.6348		.6722
19		.7842	.8402	.6859	.7468		.7468
20		.8589	.9335	.8215	.9335		.8402
21	.9335	.8589	.8402	.8215	.8589		.7842
22	.8215	.7842	.8215	.7842	.7842		.7468
23		.7468	.7468		.7095		.6348
24	.7468	.7468	.6722	.6722	.6722	.5975	
Max	.9335	.8589	.9335	.8215	.9335	.7468	.8402
Min	.5975	.5601	.5601	.5601	.5601	.5228	.5601
Avg	.7026	.7061	.7062	.6611	.6818	.6120	.6600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 204 / 11Kv Halondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3137	2.3472	1.7147	.1677	.1715	.1311	
2	2.2466	2.2634	1.8519	.1677	.1715	.1311	
3	2.2466	2.2634	2.0576	.1677	.1715	.1311	
4	2.2801	2.2801	2.2634	.1677	.1715	.1147	
5	2.3137	2.2969	2.6139	.1677	.1715	.1311	
6	2.4478	2.4478	2.5377	.1677	.2058	.1311	
7	2.8166	2.1293	2.8807	.1677	.2058	.1311	
8	2.9508	2.3472	2.8807	.1677	.2058	.1475	
9	2.7161	2.2969	2.7778	.1509	.2054	.1475	.2401
10	2.6063		2.5149	.1886	.1475	.2347	.2058
11	.1715	.1311	.1844	3.155		2.9843	2.4006
12	.1715	.1311	.1844	.6173	2.8807	3.0178	2.5034
13	.1715	.1311	.1509	2.9492	2.7778	2.934	2.5034
14		.1311	.1677	2.7435	2.2291	2.8502	2.4691
15		.1311	.1844	2.7778	2.4691	2.7161	2.4006
16	.1867	.1475	.1844	2.7778	2.7778	2.6993	2.332
17	.1844	.1311	.1844		2.4348	2.5652	2.2291
18	.1677	.1543		1.4918	1.3717		2.1262
19		.1715	.1844	.2058	.1475		.2229
20		.1715	.2012	.2058	.1475		.2401
21	.1677	.1715	.1844	.2058	.1475		.2401
22	.1677	.1715	.1844	.2058	.1475		.2229
23		.1715	.1844		.1311		.2229
24	.1677	.1677	.1543	.1677	.2058	.1311	
Max	2.9508	2.4478	2.8807	3.155	2.8807	3.0178	2.5034
Min	.1677	.1311	.1509	.1509	.1311	.1147	.2058
Avg	1.3945	.9907	1.149	.8720	.8563	1.1849	1.3706

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 205 / 11Kv Rukadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0686	.0514	1.5089	1.5432	1.8861	
2	.0514	.0686	.0514	1.6289	1.5775	1.9547	
3	.0514	.0686	.0514	1.6289	1.5775	1.989	
4	.0514	.0686	.0514	1.6118	1.5775	1.989	
5	.0514	.0686	.0514	1.6118	1.6289	2.0233	
6	.0686	.0686	.0514	1.6118	1.8861	2.0576	
7	.0514	.0686	.0343	1.9719	2.0233	2.1948	
8	.0514	.0686	.0514	2.0233	2.1262	2.0576	
9	.0343	.0686	.0343	1.8861	2.0576	1.4403	.9602
10	.0343			1.7147	1.9204	1.6804	.8916
11	2.915	2.915		.0514	.0492	.0514	.0343
12	3.0521	2.8464	1.4746	.0514	.0492	.0171	.0343
13	3.0864	2.7435	1.4746	.0343	.0492	.0171	.0343
14		2.7435	1.6804	.0514	.0492	.0171	.0343
15		2.7435	2.2291	.0514	.0492	.0171	.0343
16		2.572	2.4348	.0514	.0492	.0514	.0343
17	2.8978		2.2291		.0655	.0514	.0343
18	2.6578	.9774		.0514	.0492		.0343
19		.0514	1.4746	.0514	.0655		.0343
20		.0514	.0514	.0514	.0655		.0514
21	.0686	.0514	.0686	.0514	.0655		.0514
22	.0686	.0514	.0686	.0514	.0492		.0514
23		.0514	.0514		.0492		.0514
24		.0686	.0514	.0514	.0514	.1029	
Max	3.0864	2.915	2.4348	2.0233	2.1262	2.1948	.9602
Min	.0343	.0514	.0343	.0343	.0492	.0171	.0343
Avg	.8967	.8402	.6532	.8090	.7781	1.0888	.1577

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 201 / 11 KV Nimshirgaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0457	.0492	.125	.2031	.1219	.1219
2	.0469	.0457	.0492	.125	.2031	.1981	.1219
3	.0469	.0457	.0492	.1562	.2031	.2134	.1524
4	.0469	.0457	.0492	.1562	.2031	.2134	.1524
5	.0469	.0457	.0492	.1562	.2343	.2743	.1524
6	.0469	.0457	.0492	.1875	.2968	.3048	.1829
7	.0312	.061	.0492	.3125	.4531	.381	.2134
8	.0312	.0469	.0492	.3749	.5312	.4748	.2439
9	.0492	.0312	.0625	.3749	.4843	.4374	.2743
10	.0492	.0312	.0781	.3258	.3749	.3906	.1524
11	.4359	.4687	.5312		.0312	.0469	.061
12	.4191	.5312	.5468		.0312	.0625	.061
13	.4862	.5121	.5155		.0625	.0469	.0457
14	.4527	.4062	.4687		.0625	.0469	.0457
15	.4359	.3749	.4687	.0739	.0305	.0469	.0469
16	.3887	.4374	.4687	.0686	.061	.0469	.0625
17	.3239		.2812	.0625	.061	.0625	.0312
18	.3725	.2622	.1562	.0312	.061	.0312	.0469
19	.0648	.0492	.0312	.0469	.061	.0625	.0625
20	.061	.0655	.0625	.0625	.061	.0625	.0625
21	.061	.0655	.0625	.0625	.061	.0312	.0625
22	.061	.0492	.0625	.0469	.061	.0625	.0469
23	.0457	.0492	.0312	.0625	.0625	.0312	.0469
24	.0469	.0457	.0506	.0312	.0469	.061	.061
Max	.4862	.5312	.5468	.3749	.5312	.4748	.2743
Min	.0312	.0312	.0312	.0312	.0305	.0312	.0312
Avg	.1707	.1635	.1780	.1421	.1642	.1546	.1046

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 202 / 11 KV Alate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.25	.2343	.2785	.3125	.4531	.3125	.3125
2	.2343	.2343	.2785	.3749	.4687	.3125	.3125
3	.2343	.2343	.2622	.3749	.5937	.3437	.3749
4	.2343	.2343	.2785	.4374	.4687	.4374	.3749
5	.2343	.2343	.2949	.4999	.5937	.5312	.4374
6	.25	.25	.2949	.6874	.828	.7655	.5937
7	.2031	.2343	.2949	1.1561	1.4529	1.1092	.8124
8	.2031	.2343	.2614	1.3123	1.5466	1.1561	.9998
9	.1802	.2343	.1875	1.0936	1.406		.7811
10	.2294	.2187	.2812	.9831	1.3748	.4999	.4687
11	1.643	1.4998	1.6091	.1509	.1562	.125	.125
12	1.5592	1.656	1.5154	.1219	.1562	.1406	.1094
13	1.5257	1.4373	1.3592	.1509	.125	.125	.125
14	1.3413	1.2811	1.2498		.1562	.125	.125
15	1.291	1.1873		.1677	.125	.1406	.1094
16	1.2811	1.2811	1.3592	.2012	.125	.125	.125
17	1.4413			.1875	.2343	.0937	.1875
18	1.2887	.8029	.4999	.2187	.25	.125	.1718
19	.25	.2949	.2812	.2343	.2656	.25	.2031
20	.2812	.3441	.3658	.2812	.2968	.2656	.2656
21	.1406	.3441	.3292	.3749	.3125	.2812	.2656
22	.2343	.3277	.2812	.2812	.2812	.25	.2656
23	.2343	.3113	.25	.2656	.25	.25	.25
24	.2812	.2187	.2785	.25	.25	.25	.25
Max	1.643	1.656	1.6091	1.3123	1.5466	1.1561	.9998
Min	.1406	.2187	.1875	.1219	.125	.0937	.1094
Avg	.6269	.5795	.5496	.4399	.5071	.3485	.3352



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 203 / 11 Kv Atigre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4527	.4481	.3658		.4527	.4024
2	.4527	.4527	.4481	.3658	.3721	.4527	.3658
3	.4527	.4338	.4294	.3544	.3961	.4527	.3544
4	.4527	.4338	.4294	.3292	.3961	.415	.3658
5	.4527	.4338	.4294	.3292	.3898	.415	.4024
6	.4338	.4715	.4294	.4024	.415	.4338	.4024
7	.4338	.4338	.4294	.3658	.3961	.415	.4024
8	.3961	.4024	.3921	.3292	.3961	.3772	.4024
9	.4294	.4024	.415	.2561	.3772	.3772	.4024
10	.4668	.4024	.415	.2587	.3658		.4024
11	.4481	.4024	.4338	.2587	.4024	.5281	.4207
12	.4668	.439	.4527	.2957	.439	.4527	.3475
13	.4294		.3961	.2957	.3544	.3772	.3475
14	.4294	.3292	.4338		.4024	.415	.3841
15	.4668	.4755	.4527		.415	.4527	.4207
16	.4527	.4607	.4338	.2772	.4527	.415	.4024
17	.4715			.2561	.3961	.3658	.4755
18	.4527	.4481	.4024	.3395	.4715		.4715
19	.4715	.5228	.5487	.3772	.4904	.4755	.5281
20	.547	.5601	.5121	.5093	.5093	.4938	.5281
21	.5281	.5601	.4755	.5093	.5281	.5487	.547
22	.5093	.5415	.4755	.5281	.5281	.4755	.5281
23	.4904	.5228	.4252	.4527	.4904	.439	.4904
24	.5093	.4527	.4668	.3898	.415	.3961	.439
Max	.547	.5601	.5487	.5281	.5281	.5487	.547
Min	.3961	.3292	.3921	.2561	.3544	.3658	.3475
Avg	.4639	.4561	.4424	.3566	.4260	.4376	.4264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 206 / Jathar Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0195	2.0005	1.9814	1.9052	1.1812	1.1431	1.9814
2	1.9814	2.0005	1.9433	1.9052	1.1431	1.1431	1.9433
3	1.9814	2.0005	1.9814	1.8671	1.1431	1.1431	1.9433
4	1.9052	2.0005	1.9433	1.8671	1.1812	1.1431	1.9814
5	1.9052	2.0005	2.0195	1.9433	1.1812	1.1431	1.9433
6	1.9433	1.9052	1.9052	1.9814	1.1812	1.1431	1.9052
7	1.9814	1.9433	1.9433	1.9753	1.1812	1.3336	1.9814
8	1.9433	2.0005	1.9814	1.8073	1.1812	1.3336	1.9433
9	1.9433	2.0005	1.9814	1.5242	1.1812	1.2384	1.9814
10	2.0195	2.0576	2.0576	1.6194	1.1812	1.1812	2.0005
11	2.0195	2.0957	1.9433	1.5623	1.2193	1.1812	1.9052
12	1.9433	2.0195	1.9052	1.0669	1.2193	1.2955	1.9052
13	1.9814	2.0195	1.9616	1.105	1.2193	1.8671	1.9052
14	1.9814	2.0957	2.0195		1.2574	1.9052	1.8099
15	2.0576	2.1338	2.0195	.9907	1.2574	1.9052	2.0957
16	2.0005	1.9814	1.9433	1.0479	1.2574	1.9052	2.0957
17	1.3336		1.9814	1.0288	1.2384	1.829	1.9814
18	1.9433	1.9433	2.0195	1.0288	1.2384	1.9052	1.9433
19	1.9814	2.0195	1.9814	.9907	1.2384	1.9433	2.0005
20	2.0005	2.0576	1.9433	.9907	1.2384	1.9624	1.8671
21	1.9052	2.0576	1.9052	1.1812	1.1431	1.9814	1.9814
22	2.0005	2.0576	1.9052	1.1812	1.2384	1.9814	1.9433
23	2.0005	2.0195	1.9433	1.1812	1.2384	1.9052	1.9814
24	1.9814	2.0005	1.9814	1.9052	1.1812	1.2384	1.9433
Max	2.0576	2.1338	2.0576	1.9814	1.2574	1.9814	2.0957
Min	1.3336	1.9052	1.9052	.9907	1.1431	1.1431	1.8099
Avg	1.9481	2.0179	1.9663	1.4633	1.2050	1.5313	1.9568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 207 / 11KV ALATE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7545	.5975	.7316	1.1889	1.4861	.7442
2	.7167	.7545	.5601	.6219	1.1145	1.4861	.7682
3	.7167	.7545	.5601	.6584	1.1145	1.4861	.7316
4	.7167	.7545	.6348	.6584	1.1145	1.4861	.695
5	.7167	.7545	.7655	.695	1.1889	1.4861	.6584
6	.7167	.7545	.7842	.7316	1.1889	1.4861	.7682
7	.7922	.3772	.8402	.7682	1.3374	1.4861	.7442
8	.7922	.3658	.7468	.6219	1.5604	1.4861	.7316
9	.7842	.3658	2.0062	.5487	1.9319	2.0433	.9877
10	.9709	1.1706	1.9319	.4668	1.134	2.0433	1.0974
11	1.1203	1.1706	2.5263	.5228	1.0608	2.0062	.9145
12	1.0269	1.1706	2.3034	.4805	1.134	2.0804	.9145
13	.9335	.8779	1.7833	.462	.8505	1.8576	.823
14	.9896	1.0608	2.0804		.9511	1.9319	.9145
15	1.0456	.9877	2.3262	.5544	1.0185	2.1548	1.0059
16	1.0374	1.0242	2.2291	.5544	1.094	1.9022	1.8576
17	1.1317		.9568	.8917	1.0374	.8048	2.0062
18	.9431	.8215	1.0242	.743	.9619	.9145	.9808
19	.9054	.7282	.9511	.5658	.9431	.8779	.7922
20	.8145	.7468	.0732	.7545	.9431	.8413	.7922
21	.9431	.8029	.7316	.7545	.9431	.8048	.8488
22	.905	.7842	.8048	.7167	.9431	.7682	.9054
23	.7545	.7468	.8048	.6036	.8488	.815	.8676
24	.7922	.7545	.5975	.7682	1.1889	.7545	.7316
Max	1.1317	1.1706	2.5263	.8917	1.9319	2.1548	2.0062
Min	.7167	.3658	.0732	.462	.8488	.7545	.6584
Avg	.8758	.8036	1.1925	.6467	1.1163	1.4371	.9284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 208 / Laxminagar Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.0724	.0934	.0732	.0905	.0724	.0732
2	.0905	.0724	.0934	.0732	.0724	.0724	.0732
3	.0905	.0724	.0747	.0732	.0724	.0724	.0732
4	.0905	.0724	.0747	.0732	.0724	.0724	.0709
5	.0905	.1086	.0747	.1097	.0905	.0724	.0732
6	.0905	.1086	.0934	.1097	.1086	.1086	.1097
7	.0905	.1086	.0934	.0732	.1086	.1086	.1097
8	.0905	.128	.0934	.1063	.0905	.1086	.0732
9	.0934	.128	.1267	.0732	.1086	.1086	.1097
10	.1307	.0732	.0905	.1109	.1097	.1267	.128
11	.1307	.1097	.1086	.1478	.1097	.1267	.128
12	.112	.1097	.0905	.1307	.0732	.1267	.1097
13	.1307	.1097	.0905	.1307	.1097	.1267	.1063
14	.1307	.1097	.1086		.1463	.1629	.1097
15	.112	.1097	.0905	.112	.1086		.1097
16	.1267	.1463	.1086	.1294	.1086	.1448	.1097
17			.1097	.0732	.1086	.0732	.0732
18		.168	.0732	.0732	.1086	.1097	.1267
19		.112	.1097	.1086	.1086	.1463	.1463
20		.112	.1097	.1448	.1086	.1417	.1267
21		.1307	.0732	.1267	.1086	.1097	
22		.112	.1097	.1267	.1086	.1097	.1267
23	.1086	.112	.1063	.1086	.0905	.1097	.1086
24	.1086		.0934	.0732	.0905	.0905	.0732
Max	.1307	.168	.1267	.1478	.1463	.1629	.1463
Min	.0905	.0724	.0732	.0732	.0724	.0724	.0709
Avg	.1070	.1085	.0954	.1027	.1005	.1088	.1021

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 201 / 11 KV Hingangaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1401	.9945	1.3413	.0332	.0381	.0335	.0332
2	1.1736	1.0277	1.3413	.0332	.0381	.0335	.0332
3	1.1401	1.0277	1.3413	.0332	.0381	.0335	.0332
4	1.0059	1.0159	1.3413	.0332	.0381	.0335	.0332
5	1.0059	1.0486	1.3413	.0332	.0381	.0335	.0332
6	1.0059	1.1797	1.2071	.0332	.0381	.0335	.0332
7	1.3077	1.4419	1.2498	.0332	.0381	.0335	.0332
8	1.3413	1.5074	1.4419	.0332	.0381	.0335	.0332
9	1.3413	1.5249	1.3108	.0381	.0332	.0381	.0328
10	1.3413		1.3748	.0381	.0332	.0381	.0328
11	.0335	.0332		1.073	1.7238	1.5089	.852
12	.0335	.0332	.0335	1.3413	1.6244	1.5424	.7537
13	.0335		.0335	1.5089	1.5249	1.3413	.852
14	.0335		.0335	1.3413	1.3592	1.3413	.7865
15	.0335		.0335	1.3413	1.4586	1.3413	.6554
16	.0335		.0335	1.3413	1.4586	1.3413	.852
17	.0328	.0335	.0332	1.2071		.8619	.8718
18	.0328	.0335	.0332	.8383	1.2407	.7625	.6706
19	.0328	.0335	.0332	.0381	.0335	.0332	.0335
20	.0328	.0335	.0332	.0381	.0335	.0332	.0335
21	.0328	.0335	.0332	.0381	.0335	.0332	.0335
22	.0328	.0335	.0332	.0381	.0335	.0332	.0335
23	.0328	.0335	.0332	.0381	.0335	.0332	.0335
24	.0381	.0328	.0335	.0332	.0381	.0335	.0332
Max	1.3413	1.5249	1.4419	1.5089	1.7238	1.5424	.8718
Min	.0328	.0328	.0332	.0332	.0332	.0332	.0328
Avg	.5113	.5843	.5967	.4399	.4768	.4410	.2844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 202 / 11 KV Warana Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.081	.0829	.0838	1.2209	1.1401	1.1233	.9156
2	.081	.0829	.0838	1.2209	1.1904	1.1233	.9156
3	.081	.0829	.0838	1.2209	1.1904	1.1401	.8987
4	.081	.0829	.0838	1.2209	1.1904	1.1401	.8987
5	.081	.0829	.0838	1.2209	1.2071	1.1401	1.0004
6	.081	.0829	.0838	1.3395	1.2407	1.1736	1.0004
7		.0663	.0838	1.4413	1.4083	1.3077	1.0004
8		.0663	.0838	1.4413	1.5089	1.4083	1.0004
9		.0678	.0838	1.5257	1.4752	1.3413	1.0486
10			.0838	1.4419	1.4752	1.2574	1.065
11		1.6617	1.4754	.0648	.0678	.081	.0655
12	1.6766	1.5939	1.6598	.0648	.0848	.081	.0655
13	1.7101		1.8778		.0848	.081	.0655
14	1.7101		1.8778		.0678	.081	.0663
15	1.7101		1.8778		.0678	.081	.0663
16	1.6766		1.8778		.0678	.081	.0829
17	1.6221	1.5592	1.7974	.0648		.0509	.0671
18	1.4582	1.5592	1.7974	.0648	.0503	.0509	.0671
19	.0819	.0838	.0848	.081	.0503	.0848	.0671
20	.0829	.0838	.0848	.081	.0503	.0848	.0671
21	.0829	.1006	.0848	.081	.0838	.0848	.0838
22	.0848	.1006	.0848	.081	.0838	.0848	.0838
23	.0829	.0671	.0848	.081	.0838	.0848	.0838
24	.0648	.0829	.0671	.0848	.081	.0671	.0848
Max	1.7101	1.6617	1.8778	1.5257	1.5089	1.4083	1.065
Min	.0648	.0663	.0671	.0648	.0503	.0509	.0655
Avg	.6595	.3995	.6488	.7022	.6066	.5514	.4484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 203 / 11KV Kumbhoj Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.6348	.6653	.5792	.6584	.7023	.5068
2	.6219	.6348	.6283	.5792	.6584	.7023	.5068
3	.6219	.6348	.6653	.5975	.6584	.7023	.5792
4	.6219	.6348	.6653	.5792	.6584	.7023	.543
5	.6584	.6722	.6653	.5792	.6584	.7023	.5792
6	.7316	.7392	.7392	.6516	.695	.7023	.5792
7	.6584	.7023	.6653		.6219	.7023	.5792
8	.6219	.5914	.6283	.6154	.5853	.6283	.5792
9	.6653	.5792	.6283	.4024	.5792	.5487	.5487
10	.6653		.6283	.5487	.5792	.5121	.4755
11	.6283	.5792	.6653	.5121	.543	.5121	.5121
12	.6653	.6516	.6653	.6219	.6516	.5853	.5121
13	.7392		.7392	.6219	.6516	.6219	.5175
14	.7392		.7392	.6584	.6516	.6584	.5487
15	.7392		.7392	.6024	.6878	.6584	.5853
16	.7392		.6653	.6024	.6878	.6584	.5853
17	.6219	.6653	.6516	.567		.543	.5914
18		.6653		.6584	.6036	.724	.6283
19		.924	.6878	.7316	.961	.7602	.924
20	.924	.924	.8326	.8779	.961	.8326	.924
21	.8501	.8501	.7964	.8413	.924	.7602	.8871
22	.7468	.8871	.7964	.8048	.8871	.7602	.7392
23	.7095	.8131	.6878	.7316	.7762	.6516	.7023
24	.7316	.6348	.7392	.6878	.695	.7392	.6516
Max	.924	.924	.8326	.8779	.961	.8326	.924
Min	.6219	.5792	.6283	.4024	.543	.5121	.4755
Avg	.6965	.7062	.6950	.6370	.6971	.6696	.6161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 204 / 11 KV Bahubali Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0324	.0492	.0503	.3481	.503	.4694	.3481
2	.0324	.0492	.0503	.3481	.5197	.4694	.3481
3	.0324	.0492	.0503	.3481	.5533	.503	.3149
4	.0324	.0492	.0503	.3481	.5533	.503	.2486
5	.0324	.0492	.0503	.3481	.5868	.503	.3149
6	.0324	.0655		.431	.6203	.5868	.3149
7	.0324	.0492	.0671	.5636	.8048	.7377	.3149
8	.0324	.0328	.0671	.5636	.8551	.7209	.3149
9		.0332	.0671	.6371	.7293	.6706	.5407
10			.0671	.5868	.7293	.6036	.5506
11	.6874	.7956	.7712	.0324	.0332	.0324	.0324
12	.9556	.9282	.8551	.0324	.0332	.0324	.0324
13	.8551			.0324	.0332	.0324	.0324
14	.8551			.0324	.0332	.0324	.0328
15	.7042			.0324	.0332	.0324	.0328
16	.788		.7042	.0324	.0332	.0324	.0328
17	.7287	.5365	.7127	.0486		.0497	.0503
18	.6802	.5365	.7127	.0324	.0671	.0497	.0335
19	.0324	.0503	.0332	.0486	.0503	.0663	.0503
20	.0655	.0503	.0497	.0486	.0503	.0663	.0503
21	.0655	.0503	.0663	.0503	.0503	.0497	.0503
22	.0655	.0671	.0663	.0486	.0503	.0497	.0503
23	.0492	.0503	.0497	.0486	.0671	.0663	.0503
24	.0324	.0492	.0503	.0497	.0324	.0503	.0663
Max	.9556	.9282	.8551	.6371	.8551	.7377	.5506
Min	.0324	.0328	.0332	.0324	.0324	.0324	.0324
Avg	.3102	.1864	.2296	.2122	.3053	.2671	.1753



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 205 / 11 KV Narande Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1865	.1844	.9602	.9602	.9556	.8916
2	.1886	.1865	.1844	.9602	.9945	.9556	.8916
3	.1886	.1865	.1844	.9602	.9945	1.0395	.7545
4	.1886	.1865	.1844	.9602	1.0288	1.0395	.7716
5	.1886	.1865	.1844	.9602	1.0288	1.0395	.7716
6	.1886	.1865	.1844	1.046	1.0974	1.0898	.7716
7	.1886	.1865	.1844	1.0631	1.3717	1.3077	.7716
8	.1886	.1865	.1844	1.0631	1.3203	1.3245	.7716
9		.1886	.1844	1.166	1.3032	1.286	.6613
10	.1677		.1844	1.046	1.3032	1.2346	.6274
11	1.6766	1.6804	1.5089	.1715	.0857	.1715	.1696
12		1.5947	1.5699	.1715	.0857	.1715	.1696
13	1.6095		1.6095		.1715	.1715	.1696
14	1.6095		1.6095		.1715	.1715	.1696
15	1.576		1.6095		.1715	.1715	.1696
16	1.576		1.5257		.1715	.1715	.1638
17	1.6108	.7712	1.5604	.1715			.1677
18	1.3395	.8886	1.5604	.1715	.1677	.1715	.1677
19	.1865	.2012	.1886	.1886	.1844	.1886	.1844
20	.1865	.2012	.1886	.1886	.1844	.1886	.1844
21	.1865	.2012	.1886	.1886	.1844	.1715	.1844
22	.1865	.1844	.1886	.1886	.1844	.1715	.1844
23	.1865	.1844	.1886	.1886	.1844	.1715	.1844
24	.1886	.1865	.1844	.1886	.1886	.1844	.1715
Max	1.6766	1.6804	1.6095	1.166	1.3717	1.3245	.8916
Min	.1677	.1844	.1844	.1715	.0857	.1715	.1638
Avg	.6271	.4092	.6469	.6001	.5886	.5891	.4219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 206 / 11 KV Kumbhoj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0059	.9175	1.0059		.0381	.0335	.0332
2	1.0059		1.0059		.0381	.0335	.0332
3	1.0059	.9503	1.0059		.0381	.0335	.0332
4	.9724	.9503	1.0059		.0381	.0335	.0332
5		.9717	1.0059		.0381	.0335	.0332
6	.6706	1.0364	.945		.0381	.0335	.0332
7	1.0395	1.0688	1.1736		.0381	.0335	.0332
8	1.1736	1.0688	1.2071		.0381	.0335	.0332
9	1.1736	1.094	1.2071		.0332	.0381	.0328
10	1.1736		1.073		.0332	.0381	.0328
11			.0335		1.2929	1.073	.7537
12		.0332	.0335	1.0059	1.326	1.1401	.7865
13			.0335	1.2071	1.2266	1.1736	.7449
14			.0335	1.073	1.1271	1.1736	.7449
15			.0335	1.1065	1.094	1.1736	.7449
16			.0335	1.1736	1.094	1.1736	.7125
17		.0335	.0332	1.073		1.0277	.8048
18		.0335		.8383	1.0059	1.0277	.7377
19	.0324	.0335		.0381	.0335	.0332	.0335
20	.0324	.0335		.0381	.0335	.0332	.0335
21	.0324			.0381	.0335	.0332	.0335
22	.0324	.0335		.0381	.0335	.0332	.0335
23	.0328	.0335		.0381	.0335	.0332	.0335
24	.0381	.0328	.0335		.0381	.0335	.0332
Max	1.1736	1.094	1.2071	1.2071	1.326	1.1736	.8048
Min	.0324	.0328	.0332	.0381	.0332	.0332	.0328
Avg	.6281	.5203	.6057	.6390	.3801	.3961	.2734

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 207 / 11KV Bahubali-Nej Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1494	.1478	.1294	.1509	.1478	.1109
2	.1509	.1494	.1478	.1294	.1509	.1478	.1109
3	.132	.1494	.1478	.1294	.132	.1294	.1109
4	.132	.1494	.1478	.1294	.132	.1294	.1109
5	.132	.1494	.1478	.1294	.132	.1294	.1109
6	.132	.1494	.1478	.1294	.1509	.1294	.1109
7	.132	.1307	.1294	.1109	.132	.1663	.1109
8	.132	.1307	.1294	.1109	.1132	.1294	.1109
9	.1294	.1294	.1478	.1509	.1663	.132	.1867
10	.1294		.2402	.1132	.1663	.132	1.0608
11	.1478	.1294	.2587	.1509	.2402	.132	.1494
12	.1663	.2652	.2587	.1132	.2587	.132	.0934
13	.1478		.3142	.1698	.2218	.1132	.1307
14	.1478		.3142	.1886	.2402	.0943	.2427
15	.1478		.3142	.168	.2402	.1698	.2427
16	.1663		.2772	.168	.2402	.2075	.2801
17	.1307	.2402	.1619	.112		.2402	.2402
18	.1494	.2957	.1848	.168	.1478	.2402	.2587
19	.1494	.2402	.2033	.1867	.2218	.2218	.2587
20	.1867	.2402	.3142	.2054	.2218	.1848	.2218
21	.168	.2402	.2402	.1886	.2218	.1663	.2218
22	.1494	.2033	.2402	.1698	.1848	.1663	.1663
23	.1494	.1848	.1294	.1698	.1478	.1294	.1294
24	.1698	.1307	.1663	.1294	.1509	.1478	.1294
Max	.1867	.2957	.3142	.2054	.2587	.2402	1.0608
Min	.1294	.1294	.1294	.1109	.1132	.0943	.0934
Avg	.1471	.1820	.2046	.1479	.1811	.1549	.2042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 208 / Parshwanath LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5487	.463	.4207	.4458	.5609	.5506
4	.6516	.5144	.5609	.5487	.631	.502
5	.6516	.5144	.5609	.5658	.631	.5344
6	.6859	.5144		.5658	.7888	.5344
7	.6859	.3944	.5959	.4801	.7537	.5344
8	.7202	.3944	.5959	.4801	.7888	.5344
9	.7362	.3725	.5959	.4807	.7373	.5658
10	.7362		.5959	.4696	.703	.5144
11	.6135		.5959	.6802	.7373	.7716
12		.421	.5609	.6802	.6687	.7716
13	.5609		.5959	.6478	.7202	.7716
14	.6485		.5959	.5992	.7545	.7545
15	.6485		.5959	.583	.7716	.6687
16	.6485		.631	.583	.7545	.6687
17	.6001	.1753	.6478		.6802	.6836
18	.6001	.5959	.6478	.3155	.7449	.6836
Max	.7362	.5959	.6478	.6802	.7888	.7716
Min	.5487	.1753	.4207	.3155	.5609	.502
Avg	.6491	.4360	.5865	.5417	.7142	.6278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 201 / Tamadalage VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2452	.2743	.1886	.2427	.2229	.2263
2	.2263	.2263	.2401	.1698	.2263	.2058	.1886
3	.2263	.2263	.2401	.1886	.2263	.2058	.1509
4	.2263	.2263	.2229	.2353	.2263	.2058	.1463
5	.2641	.2641	.2229	.2614	.2641	.2229	.168
6	.3018	.3018	.2401	.3018	.3206	.2401	.1886
7	.3018	.2829	.2572	.2829	.2427	.2572	.2263
8	.2829	.3018	.2229	.2452	.2452	.2401	.2263
9	.3395	.3772	.2401	.2452	.2641	.2058	.2641
10	.2915	.3772	.3734	.2743	.3772	.3206	.2957
11	.3772	.3772	.4024	.2743	.3961	.2829	.3361
12	.3429	.415	.4024	.2572	.3696	.3734	.2957
13	.3086	.3961	.3841		.3395	.2829	.2452
14	.2743	.3206	.3547		.2641	.3018	.2829
15	.3086	.3772	.3772	.3086	.3772	.3206	.2829
16	.3429	.2452	.2829	.3086	.3018	.3018	.2641
17	.3429		.3174	.2915	.2572		.2641
18	.3018	.2572	.3395	.2641	.1715		.2263
19	.415	.4115	.415	.3018	.3772	.3961	.415
20	.4527	.4458	.4715	.3961	.4801	.3772	.4904
21	.4338	.4287	.4715	.3961	.4287	.415	.4338
22	.3772	.4287	.3961	.3584	.3429	.3395	.3772
23	.3395	.3772	.2829	.3018	.2572	.2829	.3018
24	.2641	.2829	.3086	.2263	.2641	.2572	.2263
Max	.4527	.4458	.4715	.3961	.4801	.415	.4904
Min	.2263	.2263	.2229	.1698	.1715	.2058	.1463
Avg	.3161	.3301	.3225	.2763	.3026	.2845	.2718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 202 / Nimshirgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0171	.1423	.1406	.1524	.1423
2	.0189	.0189	.0171	.1677	.1423	.1524	.1562
3	.0189	.0189	.0171	.1739	.1423	.1524	.1739
4	.0189	.0189	.0171	.2458	.1423	.1524	.1718
5	.0189	.0189	.0171	.2688	.1898	.2743	.2214
6	.0373	.0377	.0343	.3281	.253	.3658	.213
7	.0185	.0366	.0343	.3479	.3749	.3963	.2688
8	.0181	.0347	.0343	.3311	.4218	.4115	.2656
9	.0179	.037	.0343	.3086	.3749	.4268	.2846
10	.0343	.0339	.0173	.2743	.3086	.301	.2408
11	.4572	.4321	.4481	.0171	.0328	.0282	.0274
12	.4725	.4475	.4531	.0343	.0324	.0305	.0166
13	.4572	.4012	.3462		.0328	.0324	.016
14	.3506	.3395	.3125		.0189	.0358	.0187
15	.3353	.3395	.2968	.0343	.0377	.0351	.0171
16	.3353	.3637	.3281	.0343	.0377	.0259	.0181
17	.3353	.3858		.0343	.0343		.0332
18	.3201	.3353	.1406	.0316	.0343		.0189
19	.0335	.0343	.0309	.0358	.0343	.0164	.0187
20	.0358	.0343	.0312	.0187	.0343	.0377	.0187
21	.0366	.0343	.0339	.0189	.0343	.0373	.0187
22	.0373	.0343	.0343	.0377	.0343	.0377	.0187
23	.0377	.0343	.0339	.0189	.0343	.0339	.0187
24	.0189	.0189	.0171	.0339	.0189	.0343	.0377
Max	.4725	.4475	.4531	.3479	.4218	.4268	.2846
Min	.0179	.0189	.0171	.0171	.0189	.0164	.016
Avg	.1452	.1462	.1194	.1336	.1226	.1441	.1015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 203 / 11 KV Hatkanangale Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0149	.0171	.061	.0762	.0914	.0452
2	.0187	.0149	.0171	.0753	.0772	.0914	.0594
3	.0187	.0149	.0171	.0743	.0772	.0914	.0579
4	.0187	.0143	.0171	.0914	.0772	.0914	.061
5	.0187	.0137	.0171	.0903	.0926	.0914	.0743
6	.0183	.0131	.0171	.1067	.1219	.1524	.0714
7	.0183	.0114	.0171	.1054	.1635	.1829	.0869
8	.0177	.0109	.0171	.1128	.1635	.1677	.0753
9	.0175	.0107	.0171	.1014	.1635	.1677	.0753
10	.0171	.0152	.017	.1067	.1054	.1551	.0695
11	.1981	.253	.216	.0171	.0124	.0137	.0145
12	.2134	.2258	.2258	.0171	.0105		.0133
13	.1981	.1806	.1907		.0152		.0187
14	.1829	.1698	.1829	.0171	.0156		.0114
15	.1829	.1806	.1981	.0171	.0156	.0171	.0126
16	.1981	.2031	.1677	.0171	.0154	.0126	.0152
17	.1981	.1829	.1829	.0171	.0171		.013
18	.1593	.1677	.1189		.0171	.0152	.0185
19	.0116	.0171	.0151	.0175	.0171	.0154	.0185
20	.0116	.0171	.0152	.0183	.0171	.017	.0185
21	.0118	.0171	.0152	.0185	.0171	.017	.0185
22	.0124	.0171	.0156	.0185	.0171	.0152	.0185
23	.013	.0171	.0152	.0187	.0171	.0152	.0185
24	.0185	.0143	.0171	.0151	.0187	.0171	.0154
Max	.2134	.253	.2258	.1128	.1635	.1829	.0869
Min	.0116	.0107	.0151	.0151	.0105	.0126	.0114
Avg	.0747	.0749	.0728	.0516	.0559	.0719	.0376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 204 / 11 KV Ganeshnagar

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0686	.0747	.0754	.0857	.0754
2	.0566	.0566	.0686	.0566	.0566	.0686	.0566
3	.0566	.0566	.0514	.0566	.0566	.0686	.0566
4	.0566	.0566	.0514	.0566	.0566	.0514	.0566
5	.0754	.0566	.0514	.0747	.0566	.0514	.0754
6	.0943	.0724	.0686	.0754	.0754	.0686	.0566
7	.0943	.0914	.0857	.0754	.0754	.0857	.0747
8	.0943	.0943	.0686	.0566	.0747	.0857	.0754
9	.112	.132	.0857	.0943	.1417	.0686	.132
10	.1372	.1509	.1478	.1029	.1698	.1294	.1294
11	.1372	.1698	.1646	.12	.1886	.1294	.1663
12	.1372	.1509	.1829	.12	.1829	.1214	.1478
13	.1372	.132	.1463	.12	.1698	.1448	.1478
14	.1715	.132	.1463	.1029	.1509	.1494	.1294
15	.1543	.1509	.1646	.1372	.1698	.168	.1463
16	.1543	.1698	.1663	.1372	.1886	.1867	.1612
17	.1543	.1509	.1294	.1372	.1543		.1417
18	.1494	.12	.0943	.0943	.1372		.1254
19	.1132	.12	.0943	.0943	.1372		.132
20	.1132	.12	.132	.0943	.1372		.132
21	.1132	.12	.1132	.0943	.12	.132	.132
22	.1132	.12	.1132	.0943	.12	.132	.1132
23	.1132	.1029	.0943	.0943	.1029	.0943	.0943
24	.0754	.0943	.0686	.0943	.0754	.1029	.0943
Max	.1715	.1698	.1829	.1372	.1886	.1867	.1663
Min	.0566	.0566	.0514	.0566	.0566	.0514	.0566
Avg	.1121	.1123	.1066	.0941	.1197	.1062	.1105



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 201 / 11KV Udagaon

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0762	.0762		1.4251	1.2193	
2	.0189	.0762	.0762	1.7147	1.4754	1.2955	
3	.0187	.0762	.0762	1.7147	1.4922	1.2955	
4	.0187	.0762	.0762	1.8099	1.5261	1.2955	
5	.0187	.0762	.0762	1.8671	1.5947	1.4098	
6	.0187	.0762	.0762	1.9624	1.7147	1.5242	
7	.0747	.0762		2.0576	1.9547	1.6766	
8	.0189	.0762	.0762	2.2862	2.0919	1.6004	1.1241
9	.0762		.0187	2.0576	2.2862	1.291	.9717
10	.0762		.0187	1.829	1.7147	1.1022	.8002
11	2.0576		2.2712	.0762	.0762	.0189	.0953
12	1.9814			.0762	.0762	.0187	.0953
13	1.9814		2.4619	.0762	.0762	.0747	.0953
14	1.9814		2.6006	.0762	.0762	.0747	.0953
15	2.0576		2.1605	.0762	.0762	.0747	.0953
16	1.829		2.3152	.0762	.0762	.0747	.0953
17	1.6004		2.2862	.0747	.0762		.0754
18	1.3717		2.191		.0762		.0747
19	.0762		.0762	.0747	.0762		.0747
20	.0762		.0762	.0934	.0762		.0943
21	.0762		.0762	.0943	.0762		.0934
22	.0762		.0762	.0943	.0762		.0934
23	.0762		.0762	.0934	.0762		.0934
24	.0189	.0762	.0762	.0762	.0754	.0762	.0762
Max	2.0576	.0762	2.6006	2.2862	2.2862	1.6766	1.1241
Min	.0187	.0762	.0187	.0747	.0754	.0187	.0747
Avg	.6508	.0762	.7870	.8344	.7642	.8307	.2437

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 202 / 11KV Estate  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.037	1.7528	1.7147		1.2955	1.9814	
2	2.0195	1.6194	1.6004	1.8671	1.3146	1.9814	
3	1.7364	1.6004	1.6004	1.8099	1.2193	1.9052	
4	1.6617	1.5623	1.6004	1.7147	1.2574	1.7528	
5	1.643	1.5623	1.6004	1.6766	1.3146	1.7528	
6	1.531	1.5623	1.6766	1.6194	1.2765	1.6004	
7	1.9243	1.5242	1.6766	1.6385	1.5242	1.7528	
8	1.9433	1.9814	1.829	1.4861	1.5623	1.7528	
9	2.4387		2.0911	2.0576	2.0576	2.3243	1.8671
10	2.3624		2.2445	1.3717	2.3815	2.4272	1.6194
11	2.5911		2.5953	1.3717	2.553	2.8006	2.2862
12	2.2862		2.4958	1.3336	2.1529	2.3525	2.5911
13			2.4459		1.8671	2.4577	1.9052
14	2.4387		2.3577		2.191	2.5652	2.7054
15	2.3624		2.6673	1.1431	2.4768	2.3577	2.4958
16	2.572		2.7538	1.2193	2.5149	2.553	2.8959
17			2.6673	1.1812	2.4958		2.8769
18	2.1338		2.572	1.3146	1.9814		2.4006
19	2.2862			.4668	2.1338		
20	2.3243		2.4006	1.2765	1.9814		2.1502
21	2.0957		2.3243	1.3146	1.6766		2.1502
22	1.8671		2.0386	1.3336	1.7528		2.2779
23	2.0005		2.1338	1.3146	2.1338		2.21
24	2.0936	2.0005	1.8671	1.9814	1.3527	1.9814	1.9052
Max	2.5911	2.0005	2.7538	2.0576	2.553	2.8006	2.8959
Min	1.531	1.5242	1.6004	.4668	1.2193	1.6004	1.6194
Avg	2.1068	1.6851	2.1284	1.4520	1.8528	2.1352	2.2891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 204 / 11KV Mayur  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443	1.1812	1.2193	.9526	.8954	1.3336	
2	1.1389	1.105	1.2193	1.0479	.8573	1.2193	
3	1.0829	1.105	1.2193	1.0479	.8573		
4	1.0456	1.105	1.2193	1.105	.9145	1.2193	
5	1.0456	1.1431	1.2193	1.1812	.9145	1.2193	
6	1.0269	1.2574	1.2193	1.2574	.9335	1.2193	
7	1.4377	1.2384	1.2955	1.2955	1.0669	1.2193	
8	1.2323	1.0479	1.1431	.9526	1.1431	1.1317	1.0669
9	1.9052		1.7737	.9907	1.6385	1.6991	1.467
10	2.0576		1.6057	.9145	1.7718	1.8671	1.6004
11	1.9052		2.1719	.9145	2.1338	2.1338	1.6004
12	1.6766		2.21	.9145	2.0005	1.8296	1.5623
13	1.2955		1.7177	.9145	1.848	1.5813	1.3336
14	1.829		2.1313	.381	1.9433	1.7177	1.8671
15	1.7528		2.2862	.9907	2.0576	1.9624	1.7718
16	2.0957		2.2257		2.1338	2.0386	1.7528
17	1.9814		2.0957		2.0576		1.9052
18	1.6766		1.9052		1.6004		1.7541
19	1.7718		1.7147	.9526	1.448		1.7353
20	1.7147		1.448		1.3717		
21	1.4861		1.3336	.9335	1.1431		1.531
22	1.0669		1.0669	.8383	1.2193		1.307
23	1.1431		1.1812	.8764	1.3717		1.5497
24	1.4712	1.448	1.1431	1.1812	.9526	1.3717	
Max	2.0957	1.448	2.2862	1.2955	2.1338	2.1338	1.9052
Min	1.0269	1.0479	1.0669	.381	.8573	1.1317	1.0669
Avg	1.5077	1.1812	1.5735	.9821	1.4281	1.5477	1.5870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 205 / 11 KV Buvaphan AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0953	.0762		1.1401	1.3717	
2	.0754	.0953	.0762	1.2384	1.1904	1.448	
3	.0747	.0953	.0762	1.2384	1.2209	1.4098	
4	.0747	.0953	.0762	1.2955	1.2071	1.4098	
5	.0934	.0953	.0762	1.4861	1.3226	1.5242	
6	.0934	.0953	.0762	1.6004	1.5261	1.6766	
7	.0934	.0953	.0762	1.7528	1.9719	1.9814	
8	.0747	.0953	.0762	2.1529	2.0919	1.9814	1.0098
9	.0762		.0754	1.448	2.21	1.1317	1.2574
10	.0762		.0747	1.829	1.9433	1.1949	1.1812
11	2.21		2.3834	.0762	.0762	.0187	.0953
12	1.7528		2.4006	.0762	.0762	.0747	.0953
13			2.1948	.0762	.0762	.0934	.0953
14	1.9814		2.1534	.0762	.0762	.0747	.0953
15	1.9814		1.8143	.0762		.0934	.0953
16			1.9376	.0762	.0762	.0747	.0953
17	2.0576		1.9052	.0747	.0762		.0934
18	1.9814		1.8099	.0747	.0762		.0747
19	.0953		.0762	.0934	.0762		.0934
20	.0953			.0943	.0762		.0934
21	.0953			.0943	.0762		.0934
22	.0953			.0943	.0762		.0934
23	.0953		.0762	.0943	.0762		.0934
24	.41	.0953	.0762	.0762	.0943	.0762	.0762
Max	2.21	.0953	2.4006	2.1529	2.21	1.9814	1.2574
Min	.0747	.0953	.0747	.0747	.0762	.0187	.0747
Avg	.6208	.0953	.8375	.6606	.7319	.9197	.2783

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 206 / Jogeswari gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.724	.7621	.6287	.6859	.6097	
2	.7733	.6859	.6859	.6097	.6668	.6097	
3	.6859	.6668	.6097	.6097	.6668		
4	.6668	.6668	.6097	.6097	.6478	.6097	
5	.6859	.6668	.6097	.6287	.6859	.6097	
6	.7356	.6859	.6097	.6287	.7049	.6097	
7	.6602	.724	.6097	.724	.6224	.6097	
8	.6036	.6668	.5335	.5525	.6535	.5335	.6859
9	.8383		.7282	.724	.8192	.7282	.6859
10	.7621		.8775	.7621	.8954	.8029	.8002
11			.8962	.7621	.8573	.8215	.7621
12	.8383		.8589	.6859	.8002	.9054	.7621
13	.7621		.7468	.6097	.7621	.6348	.724
14	.6097		.7282	.5335	.724	.7095	.6097
15	.7621		.7468	.5716	.8954	.7468	.6097
16	.6859		.6535	.5335	.7049	.5975	.6097
17	.6478		.7049	.5228	.6478		.6348
18	.6097		.743	.7282	.5335		
19	.9717		.8192	.8962	.9907		.8029
20	1.1431		.9526	1.0562	.9907		1.1016
21	1.1431		1.0669	1.0456	1.0669		1.1883
22	1.086		.9145	1.0185	1.0288		1.0562
23	.9907		.9145	.811	.9145		.8676
24	.7545	.7621	.8764	.7621	.724	.6859	.6668
Max	1.1431	.7621	1.0669	1.0562	1.0669	.9054	1.1883
Min	.6036	.6668	.5335	.5228	.5335	.5335	.6097
Avg	.7909	.6943	.7608	.7089	.7787	.6765	.7855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 208 / 11 KV Krushna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0953	.0953	.0762	.0762	.0953	
4	.0953	.0953	.0953	.0762	.0953	
5	.0953	.0953	.0953	.0762	.0953	
6	.0953	.0953	.0953	.0762	.0953	
7	.0934	.0953	.0953	.0762	.0953	
8	.0905	.0953	.0953	.112	.0953	.0953
9			.0905	.1334	.0934	.0953
10			.1448	.1334	.0934	.0953
11			.1494	.1524	.0934	.0953
12	1.829		.1494	.1524	.0934	.0953
13	.1334		.1494	.1524	.0905	.0953
14	.1524		.1494	.1524	.0934	.0953
15	.1334		.1509	.1524	.0905	.0953
16	.0953		.1494	.1524	.0934	.0953
17	.1334		.1524	.1524		.0953
18	.0953		.0953	.0953		.0953
Max	1.829	.0953	.1524	.1524	.0953	.0953
Min	.0905	.0953	.0762	.0762	.0905	.0953
Avg	.2413	.0953	.1209	.1201	.0938	.0953

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 209 / KULKARNI POWER TOOLS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.3336	1.2574	1.2193	.8764	1.3717	
2	1.0829	1.086	1.3336	1.1431	.8954	1.2384	
3	.961	1.0669	1.2193	1.105	.8383	1.1431	
4	.8871	1.0479	1.0669	1.0479	.8192	1.1431	
5	.8686	1.0098	1.0288	.9907	.8192	1.0288	
6	.8962	.9907	.9526	.9526	.8192	.9145	
7	.9896	.9907	1.0479	.9526	.8954	1.2384	
8		.9907	1.0479	.8573	.9526	1.105	1.6004
9	1.4861		1.5684	.8573	1.4861	1.419	1.7147
10	1.6194		1.4523	.8002	1.8099	1.4003	1.8099
11	2.0005		1.7353	.7621	1.6194	1.848	1.8671
12	1.829		1.7364	.7621	1.9814	.7282	1.8671
13			1.5497	.7621	1.8099	1.475	1.7528
14	1.9052		1.643	.8002	1.9052		1.8671
15	1.9433		1.6804	.7621	2.0005	2.0195	1.8861
16	1.9052		2.0195	.8002	1.8099	1.9814	2.1148
17	1.9052		1.7147	.8383	1.7147		1.7147
18	1.7909		1.7147	.8383	1.1431		1.5623
19	1.5242		1.4289	.8764	1.5242		1.6244
20	1.5623		1.1622	.8764	.7621		1.2449
21	1.4861		1.2384	.9717	1.3336		1.2323
22	1.5242		1.2193	.9907	1.2574		1.2696
23	1.4861		1.2384	.9526	1.4098		1.2136
24	1.1949	1.4289	1.2193	1.2003	.8954	1.5242	1.5242
Max	2.0005	1.4289	2.0195	1.2193	2.0005	2.0195	2.1148
Min	.8686	.9907	.9526	.7621	.7621	.7282	1.2136
Avg	1.4536	1.1050	1.3865	.9216	1.3074	1.3487	1.6392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 210 / 11KV CH. SHAHU  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.724	.5335		.724	.5335	
2	.6224	.6668	.5335	.6287	.743	.5335	
3	.6224	.6478		.6478	.724	.5335	
4	.5975	.6478	.5335	.6478	.6859	.5335	
5	.5975	.6668	.5335	.6478	.7049	.5335	
6	.6413	.6668	.5335	1.0288	.743	.6097	
7	.6161	.724	.6097	.724	.7049	.6097	
8	.6348	.6287	.6097	.724	.743	.6097	.6478
9	.8383		.811	.724	.8764	.8002	.724
10	.8383		.811	.6859	.9145	.8402	.8383
11	.8383		.8962	.6097	1.0098	.9997	.8573
12	.7621		.9522	.6859	.8764	.9997	.8764
13	.7621		.8962	.6097	.8002	.8775	8.6687
14	.9145		.9242	.6859	.9335	.9431	1.0288
15	.8383		.7922	.6859	1.0098	.9709	1.0288
16	.9145		.9054	.6859	1.0479	1.0098	.9717
17	.9145		.8573	.7811	.8764		.8865
18	.8764		.7621	.7811	.7621		.8488
19	.8192		.724	.724	.6859		.811
20	.8002		.6859		.6859		.7545
21	.7621		.6859	.743	.6097		.6722
22	.743		.6668	.7049	.6097		.7545
23	.724		.6668	.7049	.6097		.6908
24	.7167	.7621	.5716	.6668	.724	.6097	.6097
Max	.9145	.7621	.9522	1.0288	1.0479	1.0098	8.6687
Min	.5975	.6287	.5335	.6097	.6097	.5335	.6097
Avg	.7523	.6816	.7172	.7058	.7835	.7381	1.2747



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 201 / 11KV LIS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.1143	2.0767	2.1338	2.8197	1.6004
2	.0953	.1143	.1143	2.1338	2.21	2.7816	1.6385
3	.0953	.1143	.1143	2.21	2.21	2.7435	1.6575
4	.0953	.1143	.1143	2.2481	2.2481	2.8197	1.6575
5	.1143	.1143	.1334	2.2481	2.4768	2.8387	1.6956
6	.1334	.1143	.1334	2.553	2.8197	2.8387	1.829
7	.1143	.1143	.1143	2.7435	3.0293	3.1626	1.829
8	.1143	.0953	.1143	2.8959	3.315	3.0293	1.8099
9	.0762	.0953	.0953	2.7244	3.2007	2.7054	1.8861
10	.1143	.0953	.1143	1.6956	2.0957	1.7718	1.3717
11	3.5437	3.5056	3.4675	.0953	.0953	.0762	.0762
12	3.5627	3.5246	3.677	.1143	.0953	.0953	.0762
13	3.5246	3.5437	3.7342	.1143	.0953		.0762
14	3.4675	3.5246	3.5437		.0953	.1143	.0762
15	3.4294	3.4484	3.4865	.1143	.1143	.0953	.0762
16	3.3532	3.4294	3.3913	.0953	.1143	.0953	.0762
17	3.296	2.3815	3.4103	.1143	.1143	.1143	
18	2.3243	2.3815	2.1148	.1143	.0953	.1334	
19		.1524		.1143	.1143	.1524	
20		.1334	.1143	.0381	.1715	.1715	
21		.1143	.1334	.0381	.1715	.1715	
22	.1524		.1334	.1143	.1524	.1715	
23	.1334	.1143	.1143	.1143	.1524	.1715	
24	.0953	.1143	.1143	.0953	.1143	.1334	.1524
Max	3.5627	3.5437	3.7342	2.8959	3.315	3.1626	1.8861
Min	.0762	.0953	.0953	.0381	.0953	.0762	.0762
Avg	1.3300	1.1937	1.2434	1.0785	1.1431	1.2699	1.0344

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 202 / 11KV Kothali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.8954	.9526		.0572	.0762	.0762
2	1.0288	.8954	.9145		.0572	.0762	.0762
3	1.0288	.8954	.9526		.0572	.0762	.0762
4	1.0098	.8954	.9717		.0572	.0762	.0762
5	1.0098	.9145	1.0098		.0762	.0762	.0953
6	1.0669	.9145	1.0288		.0762	.0762	.0953
7	1.2384	.9717	1.1431		.0572	.0762	.0953
8	1.2384	1.0288	1.1241		.0572	.0762	.0762
9	1.1622	.9907	1.0098	.0762	.0572	.0572	.0572
10	1.1812	.9335	1.0669	.1143	.0572	.0572	.0572
11	.0572	.0762	.0572	1.5242	2.0957	1.4861	.8764
12	.0572	.0762	.0762	1.5432	2.0576	1.5623	.8002
13	.0762	.0762	.0572	1.5051	2.1148	1.4861	.7811
14	.0762	.0762	.0572		2.0957	1.4098	.8383
15	.0762	.0572	.0572	1.5242	2.0957	1.4098	.8002
16	.0762	.0572	.0572	1.467	2.1148	1.3146	.724
17	.0762	.0762	.0953	1.5432	1.829	1.2574	
18	.0572	.0762	.0572	1.467	1.5432	1.2003	
19		.0762	.0762	.0572	.0762	.0762	
20		.0762	.0953	.0762	.0762	.0762	
21		.0762	.0953	.0762	.0762	.0953	
22	.0762	.0762	.0762	.0762	.0762	.0953	
23	.0572	.0762	.0762	.0762	.0762	.0953	
24	.0572	.0572	.0762		.0572	.0762	.0762
Max	1.2384	1.0288	1.1431	1.5432	2.1148	1.5623	.8764
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.5571	.4310	.466	.7947	.7081	.5152	.3340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 203 / 11KV Umalwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191		.9907	1.105	.6287
2	.0191	.0191	.0191		.9907	1.0669	.6668
3	.0191	.0191	.0191		1.0288	1.105	.7049
4	.0191	.0191	.0191		1.0288	1.1431	.6668
5	.0191	.0191	.0191		1.105	1.1812	.6668
6	.0191	.0191	.0191		1.2193	1.2193	.6859
7	.0191	.0191			1.3717	1.2955	.6859
8	.0191	.0191	.0191		1.4289	1.2955	.6859
9	.0191	.0191	.0191	1.086	1.4098	1.1431	.6668
10	.0191	.0191	.0191	1.105	1.3717	1.2003	.6478
11	1.6766	1.6766	1.7337	.0191	.0191	.0191	.0191
12	1.2955	1.6956	1.7909	.0191	.0191	.0191	.0191
13	1.6004	1.6194	1.7528	.0191	.0191	.0191	.0191
14	1.6004	1.6004	1.6766		.0191	.0191	.0191
15	1.5623	1.6385	1.6575	.0191	.0191	.0191	.0191
16	1.5623	1.6194	1.6004	.0191	.0191	.0191	.0191
17	1.5813	1.6004	1.5813	.0191	.0191		
18	1.4098	1.6004	1.1431	.0191	.0191	.0191	
19		.0191	.0191	.0191	.0191	.0191	
20		.0191	.0191	.0191	.0191	.0191	
21		.0191	.0191	.0191	.0191	.0191	
22	.0191	.0191	.0191	.0191	.0191	.0191	
23	.0191	.0191	.0191	.0191	.0191	.0191	
24	.0191	.0191	.0191		.0191	.0191	.0191
Max	1.6766	1.6956	1.7909	1.105	1.4289	1.2955	.7049
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.5970	.5565	.5749	.1729	.5089	.5219	.4024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 204 / 11KV Danoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	2.21	2.8578		.1905	.1905	.1905
2	2.0576	2.21	2.8578		.1715	.1715	.1905
3	2.1148	2.21	2.8197		.1715	.1715	.1715
4	2.1148	2.2291	2.8578		.1905	.1905	.1715
5	2.2862	2.2862	2.934		.2096	.2096	.1905
6	2.5911	2.6292	3.0102		.2286	.2286	.2096
7	3.4294	3.2388	3.6199		.2096	.1905	.1905
8	3.658	3.3913	3.7723		.1905	.1905	.1715
9	3.0864	3.315	3.7532	.1334	.1715	.1524	.1524
10	2.8578	3.0293	2.8959	.1524		.1524	.1715
11	.1715	.1524	.1524	4.0009	4.4772	3.9438	2.9912
12	.1715	.1524	.1715	3.7532	4.7249	4.039	3.0293
13	.1715	.1715	.1715		4.1152		3.0293
14	.1715	.1715	.1524		4.1914	2.8959	2.7625
15	.1715	.1524	.1524	3.2198	4.2295	3.8295	2.8769
16	.1905	.1524	.1524	3.5818	4.1724	3.5437	2.6863
17	.1524	.1524	.1715	3.6008	3.8485	3.1245	
18	.1524	.1715	.1524	3.3532	2.8769	2.8578	
19		.2286	.1715	.1905	.1905	.2096	
20		.2286	.1905	.2286	.2286	.2096	
21		.2286	.2096	.2286	.2286	.2096	
22	.2096	.2477	.2096	.2286	.2286	.2096	
23	.1905	.2286	.2096	.2096	.2096	.2096	
24	.2096	.1905	.2096		.1905	.1905	.1905
Max	3.658	3.3913	3.7723	4.0009	4.7249	4.039	3.0293
Min	.1524	.1524	.1524	.1334	.1715	.1524	.1524
Avg	1.34	1.2241	1.4106	1.7601	1.5498	1.1879	1.1398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 205 / 11KV Waranamai

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	1.9814	2.2862	.0381	.0381	.0381	.0381
2	2.0195	1.9814	2.3053	.0381	.0381	.0381	.0381
3	2.0576	1.9814	2.3053	.0381	.0381	.0381	.0381
4	2.0576	2.0195	2.3243	.0381	.0381	.0381	.0381
5	2.1148	2.0576	2.4387	.0381	.0381	.0572	.0381
6	2.1338	2.1338	2.4577	.0381	.0381	.0572	.0381
7	2.4006	2.2481	2.572	.0381	.0381	.0572	.0381
8	2.4387	2.3053	2.6673	.0572	.0381	.0381	.0381
9	2.4196		2.6673	.0381	.0381	.0381	.0381
10	2.3624	2.2862	2.6482	.0381	.0572	.0572	.0381
11	.0381	.0381	.0381	2.915	3.0864	3.1436	1.5051
12		.0381	.0381		3.4294	3.0483	1.6766
13	.0381	.0381	.0381		3.4103	2.915	1.6956
14	.0381	.0381	.0381		3.3913	2.4768	1.7528
15	.0381	.0381	.0381		3.4294	2.9721	
16	.0381	.0381	.0381		3.4865	2.8959	1.6385
17	.0381	.0381	.0381	2.5911	3.3341	.5525	
18	.0381	.0381	.0381	2.6673	3.1436	.5525	
19		.0381	.0381	.0381	.0381	.0381	
20		.0381	.0381	.0381	.0381	.0381	
21		.0381	.0381	.0381	.0381	.0381	
22	.0381	.0381	.0381	.0381	.0381	.0381	
23	.0381	.0381	.0381	.0381	.0381	.0381	
24	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Max	2.4387	2.3053	2.6673	2.915	3.4865	3.1436	1.7528
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	1.1184	.8490	1.0502	.4633	1.1392	.8018	.5430

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 206 / 11KV Danoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5335	.4954	.5335	.4572	.5335	.4382
2	.5144	.4954	.4572	.5335	.4572	.4954	.4382
3	.4763	.4954	.4954	.4954	.4763	.4572	.4001
4	.4763	.4954	.5335	.4954	.4763	.4954	.4572
5	.5335	.5335	.5716	.5525	.5335	.5716	.4954
6	.6097	.5906	.5525	.6097	.5716	.6097	.5525
7	.5525	.4191	.5335	.5525	.5525	.5335	.4954
8	.5525	.362	.5335	.4572	.5335	.5716	.4572
9	.4954	.3429	.4954	.4191	.4954	.5716	.4572
10	.4382	.3048	.4763	.5144	.4954	.5906	.4572
11	.5144	.4191	.5525	.4954	.5335	.5906	.4572
12	.4763	.4191	.5906	.4954	.5716	.5525	.4191
13	.5906	.4191	.6668	.4954	.5335	.5525	.4572
14	.5906	.4572	.6478		.5335	.5525	.4572
15	.6097	.4954	.6478	.5335	.5335	.5906	.4572
16	.7049	.4572	.6478	.5335	.5525	.5906	.4954
17	.7049	.4191	.6287	.5335	.6097		
18	.6859	.4191	.5335	.5525	.5716	.5716	
19		.6859	.6668	.5525	.6478	.7049	
20		.724	.6859	.6859	.7621	.8002	
21		.6859	.724	.6859	.7621	.6859	
22	.6478	.6097	.6859	.6478	.6097	.6287	
23	.6097	.5716	.6478	.5716	.5716	.5335	
24	.5716	.5335	.5716	.5716	.4954	.5716	.4572
Max	.7049	.724	.724	.6859	.7621	.8002	.5525
Min	.4382	.3048	.4572	.4191	.4572	.4572	.4001
Avg	.5661	.4954	.5851	.5442	.5557	.5807	.4617

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 207 / 11KV Umalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5716	.5335		.5335	.5716	.4954
2	.5525	.5335	.5335		.5335	.5335	.4763
3	.5525	.5335	.5716		.5335	.5335	.4763
4	.5716	.5335	.5716		.5525	.5716	.5335
5	.6097	.5716	.5525		.6097	.5716	.5716
6	.6478	.6478	.5716		.6478	.5716	.6097
7	.5716	.5716	.5716		.6097	.6097	.5716
8	.5335	.5335	.5716		.4763	.5716	.5144
9	.5144	.4954	.5335	.3429	.4954	.4763	.4763
10	.4572	.4954	.4954	.4572	.5335	.5525	.4572
11	.5525	.4954	.4954	.4382	.4572	.5144	.4382
12	.4572	.4572	.5716	.4954	.4954	.5906	.4572
13	.5335	.5335	.5525	.4572	.4954	.5335	.4191
14	.5335	.5335	.5525		.5335	.6097	.4191
15	.5716	.5716	.5525	.5525	.5335	.6668	.4572
16	.5716	.5716	.5335	.5335	.5335	.6478	.4382
17	.5525	.5335	.4572	.5144	.5335		
18	.6287	.4954	.5716	.4954		.5906	
19		.743	.6859	.5906	.6859	.724	
20		.7621	.724	.7049	.7621	.724	
21		.7621	.7049	.724	.7621	.7049	
22	.6859	.6859	.6668	.6859	.6859	.6478	
23	.6478	.6478	.6287	.6097	.6478	.5144	
24	.6097	.5716	.5716		.5716	.6097	.4954
Max	.6859	.7621	.724	.724	.7621	.724	.6097
Min	.4572	.4572	.4572	.3429	.4572	.4763	.4191
Avg	.5689	.5772	.5740	.5430	.5749	.5931	.4886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 201 / 11KV RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6448	.8131	.7682	.7602	.7577	.7865	.7059
2	1.5524	.7947	.7316	.7421	.7023	.7499	.6878
3	1.423	.7392	.695	.724	.5914	.7133	.695
4	1.2936	.7392	.695	.724	.6468	.695	.695
5	1.423	.7762	.7133	.7421	.7023	.7133	.7059
6	1.46	.7842	.7133	.7421	.7207	.7133	.724
7	1.4415	.7842	.7499	.8029	.8316	.8048	.7421
8		.7282	.7133	.8215	.7762	.8048	.8029
9	.2561	.7865	.8215	.8316	.8402	.7947	.8501
10	1.0608	.9328	.9896	.9979	1.0829	.961	.961
11	1.1157	1.0974	1.0642	1.0164	1.0829	1.0349	.961
12	1.0974	1.0974	1.0456	1.0534	1.1203	1.1273	.8871
13	1.134	1.0242	1.0082	1.0719	1.1016	1.0534	.924
14	1.1523	1.0059	1.0082	1.0903	1.0642	1.0164	.9979
15	1.0974	1.0059	1.0456	1.0164	1.0608	1.0349	.9055
16	1.1203	1.0425	1.0269	1.0349	1.0791	1.0642	.9795
17	1.1203	.9694	1.0456	1.0164	1.0791	1.2136	1.0349
18	1.1389	1.0059	.9709	1.0164	.9877	1.0269	.8686
19	1.251	1.0425	1.1389	1.0903	1.0608	1.1576	1.1273
20	1.2696	1.1706	1.1016	1.1273	1.2071	1.1763	1.2012
21	1.1576	1.0791	1.0456	1.0719	1.0974	1.1763	1.0719
22	1.0269	1.0059	.9335	.9795	.9808	.9335	.924
23	.9335	.9145	.8507	.8316	.9145	.8589	.8316
24	1.8111	.8589	.8048	.8029		.823	.7499
Max	1.8111	1.1706	1.1389	1.1273	1.2071	1.2136	1.2012
Min	.2561	.7282	.695	.724	.5914	.695	.6878
Avg	1.2166	.9249	.9034	.9212	.9343	.9347	.8764



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 202 / 11KV PINGARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7282	.7682	.6878	.6908	.6401	.6154
2	.6908	.6767	.7316	.6697	.6161	.6036	.5973
3	.6535	.6908	.7133	.6697	.5601	.5853	.5973
4	.6348	.7095	.695	.6335	.5975	.567	.5792
5	.6908	.7207	.7133	.6516	.6535	.567	.5792
6		.7842	.7316	.6516	.6722	.5853	.6516
7	.7133	.8029	.7499	.7842	.8402	.6584	.724
8	.7499	.7655	.7316	.8402	.7655	.7499	.8326
9	.695	.7316	.6535	.7282	.7655	.7842	.7468
10	.7316	.695	.7282	.7468	.8215	.7468	.7095
11	.7499	.7316	.7282	.6535	.8215	.7095	.5975
12	.6767	.7133	.7095	.7095	.7842	.6722	.5788
13	.6036	.7316	.6722	.6535	.7655	.6535	.5601
14	.5853	.7316	.6722	.7468	.7282	.6908	.5975
15	.6584	.7499	.6535	.7095	.7316	.7655	.5601
16	.6722	.7316	.6722	.7282	.7316	.6908	.5975
17	.7468	.6767	.7468	.6348	.6036	.7842	.5788
18	.6908	.7316	.7095		.5853	.7282	.6535
19	.9149	.7499	.8775	.9896	.695	.8215	.7468
20	.9709	.8779	.9335	.9709	.823	.8775	.8402
21	.9522	.8596	.8869	.9522	.7682	.8589	.8402
22	.9149	.8779	.8413	.9522	.7865	.8402	.8029
23	.8215	.823	.7682	.8402	.7316	.7133	.7282
24	.8029	.7468	.7865	.695	.7282	.6767	.6535
Max	.9709	.8779	.9335	.9896	.8402	.8775	.8402
Min	.5853	.6767	.6535	.6335	.5601	.567	.5601
Avg	.7421	.7516	.7448	.7521	.7195	.7071	.6654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 203 / 11KV SHAHUNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6468	.6036	.6401	.567	.5914	.5853	.5611
2	.5914	.5914	.6036	.543	.5175	.567	.543
3	.5544	.5914	.567	.5249	.5544	.5487	.5249
4	.5359	.5975	.5487	.5415	.5359	.5304	.5249
5	.5729	.6161	.5487		.5729	.5304	.5249
6	.6283	.6348	.567	.5487	.5914	.5487	.5611
7	.6099	.6348	.567	.6161	.6283	.6036	.5792
8	.5729	.5788	.5487	.5601	.6099	.6036	.6722
9	.5304	.5487	.6161	.5175	.5788	.6653	.5914
10	.5487	.5487	.5788	.499	.5415	.5544	.5544
11	.567	.5121	.6348		.5601	.462	.5175
12	.567	.5487	.5601		.5975	.5175	.5359
13	.5487	.5487	.5975		.5975	.5175	.462
14	.567	.5853	.5601		.5788	.5544	.5175
15	.6036	.6036	.6348		.567	.5914	.499
16	.6161	.6219	.6161		.567	.5788	.5544
17	.6348	.5487	.6722	.8501	.5853		.5175
18	.5975	.6219	.6348	.7023	.6036		.6099
19	.8215	.7133	.7655	.7947	.7865	.8402	.7392
20	.8589	.823	.7865	.8501	.8413	.8589	.8501
21	.7842	.7865	.7682	.8316	.8048	.8589	.7947
22	.8029	.8048	.7316	.8316	.8048	.8029	.7762
23	.7468	.7499	.6219	.7762	.695	.7282	.7023
24	.7023	.6535	.6767	.567	.6653	.6219	.6036
Max	.8589	.823	.7865	.8501	.8413	.8589	.8501
Min	.5304	.5121	.5487	.499	.5175	.462	.462
Avg	.6337	.6278	.6269	.6542	.6240	.6214	.5965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 201 / Jambhali gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 206 / 11KV SIDHESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.905
Max	.905
Min	.905
Avg	.905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 210 / Chipri (Hanuman)AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.3391
Max	.3391
Min	.3391
Avg	.3391

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 408 / Sidhivinayak  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.8292
Max	2.8292
Min	2.8292
Avg	2.8292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 409 / 33Kv Industrial  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	5.8356
Max	5.8356
Min	5.8356
Avg	5.8356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 201 / 11KV Takawade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1065	1.0059	.9555	.032	.0305	.0152	.032
2	1.1401	1.0059	.9555	.032	.0305	.016	.032
3	1.1401	1.0395	.9555	.032	.0305	.016	.032
4	1.1401	1.0395	.9717	.032	.0305	.016	.032
5	1.1065	1.0395	1.004	.032	.0305	.016	.032
6	1.1065	1.1401	1.1012	.032	.0305	.0171	.032
7	1.1904	1.4083	1.3279	.032	.0305	.0152	
8	1.3748	1.4419	1.4737	.0328	.0305	.0133	
9	1.3748	1.576	1.4737	.032			.0305
10	1.2631	1.4883	1.2742		.032	.0335	.0305
11	.0257	.032	.0305	1.587	1.8884	1.4754	.8718
12	.0257	.032		1.7004	1.9204	1.5089	.7712
13	.02			1.7328	1.8564	1.576	.7042
14		.032			1.8084	1.7436	.7042
15		.032		1.6518	1.6964	1.7436	.6371
16	.0533	.032	.032	1.749	1.7124	1.5424	.5365
17	.0335	.0133	.032	1.7772	1.6032	1.4403	.4694
18	.0335	.0133	.032	1.6766	1.3117	1.1683	.4694
19	.0335	.0133	.032	.0305	.0171	.0354	.0305
20	.0335	.0297	.032	.0305	.0198	.0354	.0305
21	.0335	.0171	.032	.0305	.0171	.0354	.0305
22	.0335	.0171	.032	.0305	.0171	.0354	.0305
23	.0335	.016	.032	.0305	.0152	.032	.0305
24	.0305	.0335	.0152	.032	.0305	.0152	.032
Max	1.3748	1.576	1.4737	1.7772	1.9204	1.7436	.8718
Min	.02	.0133	.0152	.0305	.0152	.0133	.0305
Avg	.5606	.5434	.5897	.5613	.6170	.5455	.2546



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 202 / Shirdhon, Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0937	.0671	.0743	1.2651	1.1736	1.2631	1.065
2	.0937	.0671	.0743	1.3717	1.2071	1.2631	1.0402
3	.0937	.0671	.0533	1.4529	1.2071	1.2631	1.0974
4	.125	.0671	.0533	1.4529	1.2071	1.2955	1.1222
5	.0625	.0671	.0533	1.4706	1.3077	1.3117	1.0402
6	.0625	.0671	.0743	1.5497	1.3077	1.3279	1.1641
7	.0937	.0671	.0533	1.5947	1.4251	1.3765	
8	.0625	.0671	.0427	1.6476	1.4419	1.4089	
9	.0937	.1006	.0297	1.4419	1.4754	1.2308	.7042
10	.1715	.0983	.0457	1.4575	1.5074	1.2407	.6097
11	1.7328	1.9826	1.8442	.1029	.0492	.0335	.0305
12	1.7166	1.9498		.0533	.0983	.0335	.0305
13	1.7652	2.0481	2.0119	.0533	.0983	.0335	.0305
14	1.7166	2.0317	2.0454	.0533	.0492	.0335	.0305
15	1.7166	1.9662		.0427	.0492	.0335	.0305
16	1.7004	1.9334	1.9006	.0533	.0655	.0335	.0457
17	1.7772	1.749	.9175	.0457	.0533	.0328	.0305
18	1.7436	1.7328	1.5565	.0305	.032	.0328	.0305
19	.0671	.0427	.0328	.0305	.0427	.0328	.0305
20	.0671	.0533	.0492	.0457	.0427	.0366	.0305
21	.0671	.0533	.0492	.061	.0533	.0328	.0305
22	.0671	.0686	.0549	.0305	.0297	.0328	.0305
23	.0671	.0533	.0492	.0457	.0297	.0328	.0305
24	.061	.0671	.0743	.0343	.0305	.02	.0328
Max	1.7772	2.0481	2.0454	1.6476	1.5074	1.4089	1.1641
Min	.061	.0427	.0297	.0305	.0297	.02	.0305
Avg	.6341	.6862	.5064	.6411	.5827	.5598	.3767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 204 / 11KV Shiradhon Takawade  
Vlg Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.57	.724	.6556	.7316	.7783	.6733
2	.8048	.57	.724	.124	.7316	.7964	.6379
3	.8048	.5365	.7421	.6379	.695	.7964	.6447
4	.8048	.5365	.724	.6379	.695	.7783	.6283
5	.8048	.57	.724	.6379	.7316	.7783	.6516
6	.8048	.6036	.7421	.6379	.7682	.7602	.6516
7	.7316	.57	.6878	.631	.6219	.7783	
8	.6219	.503	.6878	.5847	.6219	.6516	
9	.695	.6036	.6154	.5935	.6219	.6201	.7316
10	.7265	.8505	.5853	.6556	.7087		.7682
11	.7619	.7712	.6379	.691	.8048	.7377	.7682
12	.7087	.7628	.1829	.6878	.7087	.7377	.695
13	.6485	.7087	.2058	.691	.6379	.7042	.5853
14	.6733	.7796	.2195	.6878	.6767	.7377	.5853
15	.7796	.7865		.815	.8048	.7377	.7316
16	.7421	.7865	.5765	.8507	.1463	.7712	.695
17	.6036	.815	.6733	.8413	.1867	.8048	.7316
18	.5365	.815	.7087	.8413	.7442	.7316	.7682
19	.6706	.8145	.7796	.8779	.8238	.7796	.9145
20	.7712	.905	.7796	.8779	.9412	.8413	.9145
21	.7712	.905	.7796	.8413	.9412	.8505	.9511
22	.7377	.8688	.7796	.8779	.9231	.7712	.9145
23	.6706	.8688	.6379	.8048	.8688	.7087	.7316
24	.8048	.6371	.7783	.631	.7682	.8145	.7087
Max	.8048	.905	.7796	.8779	.9412	.8505	.9511
Min	.5365	.503	.1829	.124	.1463	.6201	.5853
Avg	.7255	.7141	.6389	.7005	.7043	.7594	.7310

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3658	.4024	.4252	.3292	.0038	.0377
4	.3658	.4024	.4207	.3292	.0038	.0377
5	.4024	.4024	.4207	.3292		.0377
6	.4024	.4024	.4207	.3292	.0038	.0377
7	.4207	.4024	.4207	.3292	.0038	
8	.4207	.4024	.4207	.3475	.0032	
9	.439	.4024	.4207	.3475	.0032	.0343
10	.4075	.4298	.3841	.3366		.0343
11	.4207	.4477	.4024	.3366	.3353	.0305
12	.4031	.4252	.4024	.0886	.4024	.0343
13	.4031	.4252	.3658	.1646	.4359	.0305
14		.4298	.3841	.1595	.4359	.0305
15		.4207		.1595	.4359	.0305
16	.4075	.3898	.3898	.1595	.4359	.0305
17	.3688	.4075	.4075	.056	.4423	.0305
18	.2012	.2561	.0354	.056	.0358	.0305
24	.3048					
Max	.439	.4477	.4252	.3475	.4423	.0377
Min	.2012	.2561	.0354	.056	.0032	.0305
Avg	.3822	.4030	.3814	.2411	.2129	.0334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1875	.2347	.2572	.2134	.2401	.0366
4	.1829	.2347	.3601	.2187	.2058	.0366
5	.1829	.2347	.3601	.2187	.2058	.0366
6	.2286	.2347	.3601	.2187	.2058	.0358
7	.2134	.2347	.3601	.2343	.2058	
8	.2968	.2347		.2286	.2058	
9	.3281	.2347	.2572	.2683	.2058	.0305
10	.3772	.2686	.2286	.2835	.2012	.1829
11	.3772	.2772	.3437	.2835	.1677	.1829
12	.3772		.3437	.2926	.1677	.1829
13	.3772	.2743	.3437	.2835	.1677	.1829
14	.3772	.4024	.3437	.2926	.2012	.1829
15	.3772	.3856		.2835	.2012	.1875
16	.3772	.394	.3269	.2835	.2012	.1562
17	.2683	.3429	.4294	.2743	.2195	.1718
18	.2683	.3258	.4075	.2743	.208	.0937
Max	.3772	.4024	.4294	.2926	.2401	.1875
Min	.1829	.2347	.2286	.2134	.1677	.0305
Avg	.2998	.2876	.3373	.2595	.2006	.1214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0492	.0347	.032	1.5249	1.2483	1.2452	.5761
2	.0492	.0351	.032	1.5249	1.2269	1.278	.5761
3	.0486	.0354	.032	1.5415	1.2403	1.278	.5441
4	.0492	.0537	.032	1.5402	1.2536	1.3108	.5441
5	.0492	.0543	.032	1.5729	1.3032	1.3108	.5441
6	.0492	.0366	.032	1.6057	1.4083	1.3763	.5761
7	.0492	.037	.032	1.6575	1.5524	1.4419	
8	.0492	.0373	.032	1.6907	1.6617	1.5074	
9	.0492	.0377	.032	1.6575	1.7541	1.5402	.064
10	.0492	.0486	.032	1.6575	1.6057	1.0402	
11	2.1845	2.5911	2.7183	.0347	.0492	.032	.0324
12	2.3487	2.7854	2.6543	.0351	.0492	.3681	.0328
13	2.3565	2.7206	2.6216	.0354	.0492	.032	.0332
14	2.4714	2.7206	2.6216	.0358	.0492	.032	.032
15	2.2986		2.5888	.0362	.0492	.032	.0328
16	2.3594	2.5911	2.4863	.0366	.0492	.0324	.0328
17	2.5133	2.3967	2.3205	.037	.0492	.032	.0328
18	2.5206	2.3967	1.8023	.0373	.0492		.0328
19	.0566	.0486	.0497	.0377	.0492	.032	.0332
20	.0514	.0486	.0492	.0343	.0655	.048	.0328
21	.052	.0486	.0497	.0351	.0492	.048	.0332
22	.0351	.0324	.0492	.0351	.0492	.048	.0328
23	.0354	.0324	.0492	.0354	.0492	.048	.0328
24	.0492	.0343	.0324	.0497	.0343	.0492	.048
Max	2.5206	2.7854	2.7183	1.6907	1.7541	1.5402	.5761
Min	.0351	.0324	.032	.0343	.0343	.032	.032
Avg	.8260	.8199	.8505	.6870	.6227	.6158	.1857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 202 / 11 kv Bastwad feeder AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.0347	.0332	2.8166	2.5139	2.4813	1.6575
2	.0328	.0351	.0332	2.7846	2.489	2.4813	1.6575
3	.0328	.0354	.0332	2.7515	2.516	2.4478	1.6244
4	.0332	.0358	.0332	2.7999	2.5789	2.4813	1.5912
5	.0328	.0362	.0332	2.8166	2.6425	2.5149	1.6244
6	.0332	.0366	.0332	2.8669	2.6337	2.5484	1.6244
7	.0335	.037		2.8837	2.8829	2.5987	
8	.0328	.0373		2.8837	2.9687	2.6155	
9	.0335	.0377		2.7526	3.1876	2.3472	1.3923
10	.0332	.0332		2.652	2.8166	2.1216	1.3757
11	.2601	3.2985		.0347	.0335	.0332	.0332
12	.2279	3.1659	3.2819	.0351	.0335	.0332	.0332
13	3.3133	3.1161	3.315	.0354	.0335	.0332	.0332
14	3.349	3.0167	3.315	.0358		.0332	.0328
15	3.2579	3.0167	3.3867	.0362	.0335	.0332	.0335
16	3.4019	3.0333	3.1824	.0366	.0335	.0332	.0332
17	3.4743	2.9338	2.8178	.037	.0335	.0332	.0335
18	3.1367	3.0498	2.8178	.0373	.0335	.0332	.0335
19	.0377	.0332	.0328	.0377	.0335	.0332	.0335
20	.0343	.0332	.0332	.0343	.0335	.0332	.0335
21	.0347	.0332	.0332	.0347	.0335	.0332	.0335
22	.0351	1.3592	.0335	.0351	.0335	.0332	.0335
23	.0354	.0332	.0335	.0354	.0335	.0332	.0332
24	.0335	.0343	.0332	.0335	.0343	.0335	.0332
Max	3.4743	3.2985	3.3867	2.8837	3.1876	2.6155	1.6575
Min	.0328	.0332	.0328	.0335	.0335	.0332	.0328
Avg	.8734	1.1048	1.1850	1.1878	1.2029	1.0460	.5915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 203 / HERWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.6241	.7842	.679	.6415	.7356	.6722
2	.6413	.5609	.7655	.6602	.6135	.7167	.6722
3	.6602	.4961	.7468	.6413	.6201	.7167	.7095
4	.679	.5014	.7655	.6602	.6268	.6979	.7095
5	.679	.7059	.7468	.679	.7059	.7356	.7468
6	.7545	.695	.7655	.7167	.695	.7468	.7468
7	.7167	.7392	.7655	.7922	.7762	.7655	
8	.7545	.7095	.7095	.695	.7095	.7356	
9	.7133	.6602	.7655	.6602	.6602	.6602	.4854
10	.7356	.5601	.6348	.5487		.6908	.5041
11	.6068	.6908	.6224	.5548	.5601		.5281
12	.7186	.5788	.6602		.6722	.3921	.4527
13	.6556	.6161	.6224	.6201	.6161	.6161	.6224
14	.6268	.6161	.6413		.7468	.5975	.6224
15	.6878	.6161	.679	.6335	.7842	.7282	.5281
16	.7133	.7282	.7545	.6584	.7842	.6908	.679
17	.7392	.7282	.7167	.6468	.8029		.679
18	.7468	.6348	.7356	.6908	.7095		.6413
19	.679	.7282	.8299	.6224	.6908	.6535	.6979
20	.6344	.8029	.7545	.5487	.8402		.7167
21	.6762	.8029	.7167	.6415	.8215		.679
22	.6836	.7842	.695	.6485	.8402	.7468	.679
23	.7265	.7842	.7167	.7087	.7842	.7095	.6413
24	.679	.703	.7842	.6979	.6687	.7282	.6722
Max	.7545	.8029	.8299	.7922	.8402	.7655	.7468
Min	.6068	.4961	.6224	.5487	.5601	.3921	.4527
Avg	.6903	.6695	.7241	.6548	.7118	.6876	.6403

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 204 / 11 kv water works feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0693	.0686	.0857	.0867	.0686	.1029
2	.0857	.0701	.0686	.0857	.0876	.0686	.1029
3	.0857	.0886	.0686	.0857	.0886	.0686	.1029
4	.0857	.0895	.0686	.0857	.0895	.0686	.1029
5	.0857	.0905	.0686	.0857	.0905	.0686	.1029
6	.0857	.0732	.0686	.0857	.0732	.0857	.1029
7	.0857	.0924	.1029	.0686	.0924	.0686	.1029
8	.0857	.0934	.1029	.0857	.0934	.0857	
9	.1029	.0943	.1029	.0857	.0377	.1029	.1029
10	.0857	.0857	.1029	.1029	.0857	.1029	.1029
11	.0867	.1029	.1029	.0867	.0686	.1029	.1029
12	.1052	.1029	.1029	.0876	.0686	.1029	.1029
13	.1063	.1029	.1029	.0354	.0857	.1029	.1029
14	.1075	.1029	.1029	.0716	.0686	.1029	.1029
15	.1086	.1029	.1029	.0905	.1029	.1029	.1029
16	.1097	.1029	.1029	.0914	.1029	.0686	.1017
17	.0924	.1029	.1029	.0924	.1029	.0686	.1029
18	.0747	.1029	.0857	.0934	.1029		.1029
19	.0943	.1029	.0857	.0754	.1029	.1029	.1017
20	.0857	.1029	.5801	.0857	.0857	.1029	.1029
21	.0867	.1029	.0857	.0867	.0857	.1029	.1029
22	.0876	.0686		.0876	.0857	.1029	.1029
23	.0709	.0686	.0857	.0886	.0686	.1029	.0857
24	.0914	.0686	.0686	.0857	.0857	.0686	.1029
Max	.1097	.1029	.5801	.1029	.1029	.1029	.1029
Min	.0709	.0686	.0686	.0354	.0377	.0686	.0857
Avg	.0909	.0910	.1102	.0840	.0851	.0880	.1020



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 205 / 11 Kv Herwad Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	.052	.064	2.1548	1.9071	1.8884	1.1843
2	.0663	.0526	.064	2.1548	1.893	1.9204	1.2163
3	.0663	.0532	.064	2.1216	1.9136	1.8884	1.2163
4	.0663	.0537	.064	2.1216	1.97	1.9204	1.1843
5	.0663	.0724	.064	2.1051	2.0271	1.9685	1.2163
6	.0663	.0732	.064	2.1548	2.1399	2.0805	1.1843
7	.0655	.0739	.064	2.3205	2.347		
8	.0663	.0747	.064	2.3868	2.5579	2.2885	
9	.0492	.064	.064	2.3868		2.0485	1.2483
10	.0655	.064	.064	2.2939	2.1765	1.9685	1.3123
11	2.4792	2.5926	2.7199	.052	.064		.0492
12	2.7343	2.5286	2.7846		.064	.064	.0497
13	2.6932	2.5606	2.8178	.0886		.064	.0492
14	2.7221	2.5606	2.8178	.0716		.064	.0492
15	2.7149	2.5606	2.8841	.0724	.08	.064	.0492
16	2.7435	2.4966	2.7183	.0549	.064	.064	.0497
17	2.7721	2.4646	2.5526	.0739	.08		.0497
18	2.6513	2.4006	2.3594	.056	.096		.0497
19	.0377	.064	.0663	.0754	.064	.064	.0497
20	.0686	.064	.0819	.0686	.08	.064	.0497
21	.0693	.064	.0829	.0693	.064	.064	.0497
22	.0701	.064	.0819	.0701	.064	.064	.0497
23	.0532	.064	.0663	.0709	.064	.064	.0497
24	.0335	.0514	.064	.0655	.0686	.064	.064
Max	2.7721	2.5926	2.8841	2.3868	2.5579	2.2885	1.3123
Min	.0335	.0514	.064	.052	.064	.064	.0492
Avg	.9370	.8821	.9474	1.0039	.9421	.9338	.4759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 206 / 11KV Kurundwad Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.2136	1.4091	1.2266	1.2483	1.1934	1.1469
2	1.0774	1.0517	1.3763	1.1934	1.1919	1.1934	1.1469
3	1.0608	.9745	1.3435	1.1603	1.1517	1.1271	1.1142
4	1.094	.985	1.3435	1.1934	1.2178	1.1271	1.1142
5	1.1271	1.267	1.3108	1.2266	1.267	1.1603	1.0814
6	1.1603	1.3169	1.278	1.2597	1.3169	1.2597	1.0814
7	1.1271	1.4045	1.2452	1.2266	1.3306	1.2929	
8	1.2266	1.4003	1.3108	1.1603	1.475	1.2929	
9	1.3923	1.6975	1.4091	1.3592	1.6409	1.4255	1.3435
10	1.5249	1.4582	1.4746	1.326	1.3757	1.3763	1.4091
11	1.7164	1.6057	1.5249	1.5083	1.5581	1.5074	1.4089
12	1.6651	1.6057	1.5415	1.56	1.5746	1.4419	1.2929
13	1.4529	1.3435	1.3923	1.2934	1.3426	1.3763	1.1603
14	1.3611	1.3108	1.3592	.9492	1.2763	1.3763	.9945
15	1.6289	1.5729	1.4586	1.5203	1.4918	1.4746	.9945
16	1.7924	1.6385	1.5912	1.6278	1.5415	1.5402	1.094
17	1.6817	1.5074	1.4586	1.6263	1.5074	1.5074	1.094
18	1.7551	1.4746	1.4918	1.7177	1.4419		1.0277
19	1.8673	1.6712	1.6907	1.7918	1.5249	1.4091	1.1603
20	1.6632	1.6057	1.5912	1.4403	1.5912	1.4091	1.1934
21	1.5604	1.5402	1.3923	1.543	1.2597	1.4419	1.1603
22	1.5424	1.5074	1.326	1.5424	1.4918	1.4746	1.1271
23	1.4529	1.4419	1.326	1.4529	1.4255	1.278	1.094
24	1.1271	1.3375	1.4091	1.2597	1.3032	1.326	1.1797
Max	1.8673	1.6975	1.6907	1.7918	1.6409	1.5402	1.4091
Min	1.0608	.9745	1.2452	.9492	1.1517	1.1271	.9945
Avg	1.4230	1.4138	1.4189	1.3819	1.3978	1.3483	1.1554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 207 / BASTWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2601	.298	.2561	.2601	.2926	.2454
2	.2743	.2454	.2804	.2402	.2629	.2926	.2454
3	.2957	.2481	.2804	.2587	.2658	.2926	.2629
4	.3109	.2686	.2629	.2743	.2686	.3109	.2804
5	.3292	.3077	.2804	.2926	.3077	.3292	.2804
6	.3475	.3109	.298	.3109	.3292	.3292	.298
7	.3475	.2772	.2629	.2926	.2957	.2926	
8	.3142	.2801	.2454	.3511	.2614	.2561	
9	.2743	.3018	.2454	.2218	.2452	.2561	.2629
10	.3292	.2629	.2629	.2561	.2378	.2103	.2279
11	.2774	.298		.3121	.3109	.2103	.2561
12	.298	.2804	.3292	.298	.3475	.1753	.2561
13	.3721	.3155	.3109	.3012	.3475	.2804	.2561
14	.3582		.2957	.3045	.3475	.2804	.2561
15	.3439		.3109	.3077	.3292	.2804	.2772
16	.3109	.298	.2957	.3109	.2926	.2629	.2926
17	.3142	.298		.2957	.3658	.2629	.3142
18	.3174	.2629	.2926	.2801	.2926	.2804	.3292
19	.3206	.3155	.2561	.3584	.3292		.2957
20	.3086	.3681	.2587	.3258	.3658	.298	.3292
21	.3121	.333	.3292	.3121	.3475	.298	.3326
22	.3155	.3155	.3292	.3155	.3658	.3155	.3109
23	.3189		.3142	.3012	.3292	.2804	.2926
24	.2926	.2915	.298	.2743	.2743	.3109	.2629
Max	.3721	.3681	.3292	.3584	.3658	.3292	.3326
Min	.2743	.2454	.2454	.2218	.2378	.1753	.2279
Avg	.3149	.2923	.2881	.2938	.3075	.2782	.2802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 208 / KURUNDWAD AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.0351	.0312	.2294	.1734	.2439	.1406
2	.0324	.0351	.0312	.2241	.1578	.2439	.1406
3	.0324	.0354	.0312	.2267	.1417	.2286	.1406
4	.0324	.0358	.0312	.213	.1433	.2286	.1562
5	.0324	.0362	.0312	.213	.1629	.2286	.1562
6	.0324	.0366	.0312	.213	.1646	.2286	.1562
7	.032	.037	.0312	.2622	.2772	.2439	
8	.0324	.0373	.0312	.2818	.2801	.2591	
9	.032	.0377	.0312	.2622	.3018	.2134	.1562
10	.0324	.0312	.0312	.2572	.2439	.2187	.1406
11	.3641	.3593	.3768	.0347	.0305	.0312	.0324
12	.2454	.3593	.3768	.0351	.0305	.0312	.0324
13	.3544	.3437	.2984	.0354	.0305	.0312	.032
14	.3582	.3437	.2984	.0358	.0305	.0312	.0328
15	.362	.3437	.2818	.0362	.0305	.0312	.0328
16	.3658	.3437	.3277	.0366	.0305	.0312	.0332
17	.3881	.3593	.2486	.037	.0305		.0328
18	.3734	.3437	.2294	.0373	.0305		.0324
19	.0377	.0312	.0324	.0377	.0305	.0312	.0324
20	.0343	.0312	.032	.0343	.0305	.0312	.0324
21	.0347	.0312	.0328	.0347	.0305	.0324	.0324
22	.0351	.0312	.032	.0351	.0305	.0312	.032
23	.0354	.0312	.0328	.0354	.0305	.0312	.0324
24	.0328	.0343	.0312	.0324	.0343	.0305	.0312
Max	.3881	.3593	.3768	.2818	.3018	.2591	.1562
Min	.032	.0312	.0312	.0324	.0305	.0305	.0312
Avg	.1393	.1393	.1226	.1200	.1032	.1233	.0746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 209 / 11KV Nrisinghwadi Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3121	.3982	.3475	.2947	.3045	.3258
2	.3511	.2804	.362	.3292	.2629	.3045	.362
3	.3292	.2835	.3258	.3109	.2658	.3045	.362
4	.3142	.3224	.362	.3292	.3045	.3224	.3258
5		.362	.3258	.3547	.3439	.3582	.3258
6		.4024	.3982	.4066	.3658	.394	.2896
7	.3475	.5175	.4706	.4805	.462	.4656	
8	.4066	.3921	.4344	.4755	.4481	.4298	
9	.4207	.4715	.3258	.4435	.3961	.4298	.4706
10	.462	.4706	.4344	.462	.4119	.3801	.4344
11	.4334	.4344	.4755	.4161	.4477	.4344	.439
12	.4031	.4706	.4755	.3681	.394	.3982	.4207
13	.4075	.4344	.439	.4075	.3582	.3982	.4066
14	.4477	.3982	.439	.394	.3582	.4344	.3658
15	.4706	.5068	.4572	.4706	.4656	.4344	.3658
16	.4938	.543	.5487	.4755	.4477	.4706	.4024
17	.499	.5068		.499	.4119	.4706	.439
18	.4854	.4706		.4854	.4477	.4344	.4024
19	.5281	.543	.6036	.5281	.5014	.4706	.4755
20	.4801	.5068	.6401	.4115	.5014	.4706	.4755
21	.4508	.5068	.5853	.3641	.4477	.4344	.439
22	.4382	.4706	.5487	.3681	.4298	.4344	.4207
23	.3898	.4344	.439	.3721	.4298	.362	.3658
24	.4066	.3429	.3982	.3658	.3258	.3403	.3258
Max	.5281	.543	.6401	.5281	.5014	.4706	.4755
Min	.3142	.2804	.3258	.3109	.2629	.3045	.2896
Avg	.4241	.4327	.4494	.4111	.3968	.4034	.3927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 201 / 11KV Takali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1334	.1334	.1524	.1524	.0953
2	.1334	.1524	.1334	.1334	.1524	.1524	.0953
3	.1334	.1524	.1334	.1143	.1524	.1524	.0953
4	.1334	.1524	.1334	.1334	.1524	.1524	.0953
5	.1524	.1524	.1334	.1524	.1524	.1524	.0953
6	.1715	.1524	.1524	.1715	.1524	.1524	.1143
7	.1524	.1524	.1524	.1524	.1715	.1524	
8	.1524	.1524	.1524	.1334	.1715	.1524	
9	.1524	.1524	.1334	.1334	.1524	.1524	.1524
10	.1524	.1334	.1334	.1143	.1524	.1143	.1524
11	.1524	.1524	.1524	.1334		.1143	.1524
12	.1524	.1524	.1715	.1524	.1524	.1524	.1524
13	.1524	.1524	.1715	.1524	.1524	.1334	.1524
14	.1524	.1524	.1715	.1524	.1524	.0953	.1334
15	.1524	.1715	.1715	.1524	.1524		.1334
16	.1524	.1524	.1524	.1524	.1524	.1334	.1334
17	.1524	.1334		.1524	.1524	.1334	.1524
18		.1524	.1334		.1524	.1524	.1524
19		.1715	.1715	.1524	.1905	.1524	.1905
20	.2286	.2096	.1905	.2096	.2096	.1715	.2096
21	.1905	.1905	.1524	.1905	.1905	.1715	.2096
22	.1524	.1524	.1524	.1905	.1715	.1524	.1905
23	.1524	.1334	.1334	.1524	.1524	.1334	.1524
24	.1524	.1524	.1334	.1334	.1524	.1524	.1143
Max	.2286	.2096	.1905	.2096	.2096	.1715	.2096
Min	.1334	.1334	.1334	.1143	.1524	.0953	.0953
Avg	.1559	.1556	.1499	.1499	.1607	.1450	.1420

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 202 / 11KV Takaliwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0402	1.4289	1.3908	.0381	.0446	.0572	.0446
2	1.0402	1.4289	1.3908	.0381	.0446	.0572	.0446
3	1.0402	1.4289	1.4098	.0381	.0446	.0572	.0446
4	1.0402	1.4289	1.4098	.0381	.0446	.0572	.0446
5	1.0402	1.4861	1.3908	.0381	.0446	.0572	.0446
6	1.07	1.6194	1.448	.0381	.0446	.0572	.0297
7	1.1888		1.6194	.0381	.0446	.0572	
8	1.2334		1.7718	.0381	.0446	.0762	
9	1.5242	1.6385	1.7337	.0381	.0297	.0572	.0297
10	1.4861	1.4861	1.6956	.0446		.0297	.0572
11	.0381	.0381	.0381	1.3375			1.448
12	.0762	.0381	.0381	1.4266	1.8671	1.4266	1.5242
13	.0572		.0381	1.3969	1.9433	1.3969	1.4861
14	.0572	.0381	.0381	1.3969	1.8671	1.3672	1.467
15	.0572	.0381	.0381	1.3375	1.7528	1.3375	1.4861
16	.0572	.0381	.0381		1.6766	1.2929	1.448
17	.0381			1.3375	1.6766	1.1888	1.3717
18	.0762	.0381	.0381	1.3672	1.6766	1.0402	1.1812
19	.0762	.0381	.0381	.0297	.0572	.0297	.0762
20	.0572	.0381	.0381	.0497	.0572	.0297	.0572
21	.0572	.0381	.0381	.0446	.0572	.0297	.0572
22	.0572	.0381	.0381	.0446	.0572	.0446	.0572
23	.0572	.0381	.0381	.0446	.0572	.0446	.0381
24	.0297	.0572	.0381	.0381	.0446	.0572	.0446
Max	1.5242	1.6385	1.7718	1.4266	1.9433	1.4266	1.5242
Min	.0297	.0381	.0381	.0297	.0297	.0297	.0297
Avg	.5207	.6211	.6850	.4452	.5990	.4282	.5492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 203 / 11KV Danwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0381	.0381	1.4289	.8951	.8764	.7956
2	.0332	.0381	.0381	1.4861	.8951	.8764	.7956
3	.0332	.0381	.0381	1.4861	.8951	.8764	.7956
4	.0332	.0381	.0381	1.5051	.9282	.8764	.7956
5	.0332	.0381	.0381	1.5051	.9282	.8764	.7956
6	.0332	.0381	.0381	1.5242	.9614	.9145	.7956
7	.0332	.0381	.0381	1.6194		.9526	
8	.0332	.0381	.0381	1.6575		.9907	
9	.0381	.0381	.0381	1.5813	.9448	1.0098	.779
10	.0381	.0381	.0381	1.326	1.0669	.8453	.8383
11	1.9052	2.2291	2.21	.0332		.0332	.0572
12	2.0195	2.2291	2.2862	.0332		.0332	.0572
13	2.0576		2.191	.0332	.0381	.0332	.0381
14	2.0195	2.1719	2.21	.0332	.0381	.0497	.0381
15	2.0195	2.1148	2.21	.0332	.0381	.0332	.0381
16	2.0957	2.1338	2.0957	.0332	.0381	.0332	.0381
17	2.0195	2.1148		.0332	.0381	.0332	.0381
18	1.9624	2.0957	1.6194	.0332	.0381	.0332	.0381
19	.0762	.0381	.0381	.0332	.0381	.0332	.0381
20	.0762	.0381	.0381	.0332	.0381	.0332	.0381
21	.0572	.0381	.0381	.0332	.0381	.0497	.0381
22	.0572	.0381	.0381	.0332	.0381	.0497	.0381
23	.0381	.0381	.0381	.0332	.0381	.0497	.0381
24	.7621	.0381	.0381	.0381	.0332	.0381	.0332
Max	2.0957	2.2291	2.2862	1.6575	1.0669	1.0098	.8383
Min	.0332	.0381	.0381	.0332	.0332	.0332	.0332
Avg	.7295	.6826	.6710	.6496	.3984	.4013	.3163



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 204 / 11KV Rajapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6244	.3048	2.0957	.0381	.0332	.0381	.0332
2	1.6244	.3048	2.0957	.0381	.0332	.0381	.0332
3	1.6244	.3048	2.0767	.0381	.0332	.0381	.0332
4	1.6244	.3048	2.0767	.0381	.0332	.0381	.0332
5		.3048	2.1338	.0381	.0332	.0381	.0332
6		.3048	2.21	.0381	.0332	.0381	.0332
7	.8288	.3048	2.3815	.0381	.0497	.0572	
8	.8453	.3048	2.4387	.0381	.0497	.0381	
9	.9526	.3048	2.4768	.0381	.0332	.0572	.0332
10	.8383	.3048	2.3815	.0332	.0381	.0332	
11	.0572	.0381	.0381	2.2377			2.0957
12	.0572	.0381	.0381	2.4034	3.1626	1.1768	2.0957
13			.0381	2.4034	2.9721		1.9433
14		.0381	.0381	2.4034	3.0483		1.9052
15		.0381	.0381	2.4863	3.1626		1.848
16		.0381	.0381	2.4863	3.1245	2.3205	1.7909
17				2.4863	3.0864	2.2377	1.6194
18		.0381	.0381	2.5194	2.8578	2.1714	1.5623
19		.0381	.0381	.0332	.0572	.0332	.0572
20	.0381	.0381	.0381	.0332	.0572	.0497	.0572
21	.0381	.0381	.0381	.0332	.0572	.0497	.0572
22	.0381	.0381	.0381	.0332	.0572	.0446	.0572
23	.0381	.0381	.0381	.0332	.0572	.0497	.0572
24	.0332	.0381	.0381	.0381	.0332	.0572	.0332
Max	1.6244	.3048	2.4768	2.5194	3.1626	2.3205	2.0957
Min	.0332	.0381	.0381	.0332	.0332	.0332	.0332
Avg	.6842	.1593	.9940	.8336	.9610	.4302	.7339

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 205 / Rajapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.2667	.2477	.2477	.2667	.2667
2	.2286	.2667	.2477	.2286	.2477	.2667	.2667
3	.2286	.2667	.2286	.2286	.2477	.2667	.2667
4	.1905	.2667	.2286	.2667	.2477	.2667	.2667
5	.1905	.2667	.2477	.2477	.2477	.3048	.2667
6	.1905	.2858	.2667	.2477	.2477	.3048	.2667
7	.1715	.3048	.2667	.2477	.2667	.2667	
8	.1715	.2477	.2286	.2477	.2667	.2286	
9	.1524	.2096	.2286	.2096	.2096	.1905	.2286
10	.1524	.2286	.2286	.1905	.2096	.1715	
11	.1905	.2477	.2286	.1905		.1524	.2477
12	.2667	.2477	.2477	.2286	.2286		.2286
13	.3048		.3048	.1905	.2667		.2096
14	.3048	.3048	.3048	.1905	.2667		.2096
15	.2477	.2667	.2858	.1905	.2286		.2096
16	.2477	.2858	.2667	.1905	.2286	.3048	.2096
17				.2286	.1905	.2858	.1905
18		.2286	.2286		.1905	.2858	.2096
19		.2858	.3239	.2858	.2858	.3429	.3048
20	.4382	.4001	.381	.362	.3429	.4001	.381
21	.4001	.381	.3429	.381	.3429	.4001	.3239
22	.362	.362	.3239	.3429	.3429	.3239	.3239
23	.3048	.3239	.2858	.2667	.3048	.3048	.2667
24	.2667	.2667	.2858	.2858	.2477	.2667	.2667
Max	.4382	.4001	.381	.381	.3429	.4001	.381
Min	.1524	.2096	.2286	.1905	.1905	.1524	.1905
Avg	.2495	.2823	.2717	.2477	.2568	.2801	.2576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 206 / Takaliwadi Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0762	.0572	.0762	.0762	.0762
2	.0762	.0762	.0762	.0572	.0762	.0762	.0762
3	.0762	.0762	.0572	.0572	.0762	.0762	.0762
4	.0762	.0762	.0572	.0572	.0762	.0762	.0762
5	.0762	.0762	.0572	.0572	.0762	.0762	.0762
6	.0762	.0762	.0762	.0572	.0762	.0762	.0762
7	.0572	.0762	.0762	.0953	.0762	.0762	.0762
8	.0572	.0572	.0762	.0762	.0762	.0762	
9	.0572	.0572	.0762	.0953	.0953	.0762	.0762
10	.0572	.0762	.0953	.1143	.0953	.0762	.0762
11	.0953	.0953	.1143	.1143		.0762	.0762
12	.0953	.0953	.0953	.1143	.0953	.0762	.0762
13	.0953		.0572	.1143	.0762	.0762	.0953
14	.0953	.0572	.0762	.0762	.0762	.0762	.0572
15	.0953	.0762	.0762	.0762	.0762	.0762	.0572
16	.0953	.0953	.0762	.0762	.0762	.0762	.0572
17	.0953			.0762	.0762	.0762	.0762
18		.0953	.0762	.0762	.0762	.0953	.0762
19		.0953	.0953	.0953	.1143	.0953	.1143
20	.1715	.1143	.1143	.1334	.1334	.1143	.1334
21	.1334	.1143	.1143	.1334	.1143	.1143	.1143
22	.1334	.0953	.1143	.1143	.0953	.1143	.1143
23	.1143	.0953	.0953	.0953	.0762	.0953	.0953
24	.0953	.0953	.0762	.0762	.0762	.0762	.0762
Max	.1715	.1143	.1143	.1334	.1334	.1143	.1334
Min	.0572	.0572	.0572	.0572	.0762	.0762	.0572
Avg	.0910	.0840	.0828	.0873	.0853	.0834	.0828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 207 / 11 KV TAKALI ( AG )

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				1.5242	1.5089	1.5623	.9724
2				1.5623	1.5089	1.5623	1.105
3				1.6194	1.5089	1.5623	1.105
4				1.6194	1.5089	1.5623	1.105
5				1.6385	1.5089	1.6385	1.105
6				1.6575	1.5424	1.7528	1.105
7				1.7718	1.5592	1.7147	
8				1.7718	1.5424	1.7528	
9				1.7718	1.5424	1.7528	1.086
10				1.5592	1.829	1.4419	1.0669
11	1.829	1.9243	1.9433				
12	1.9814	1.8099	2.0386				
13	1.9052		1.9433				
14	1.9433	1.9814	1.9052				
15	1.9052	1.829	1.7718				
16	1.7718	1.8099	1.9243				
17	1.829	1.8099					
18	1.7147	1.8861	1.4861				
Max	1.9814	1.9814	2.0386	1.7718	1.829	1.7528	1.105
Min	1.7147	1.8099	1.4861	1.5242	1.5089	1.4419	.9724
Avg	1.8600	1.8644	1.8589	1.6496	1.5560	1.6303	1.0813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 208 / 11 KV SANGAM AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.0381	.0381	1.105	1.0277	1.1431	.8619
2	.0332	.0381	.0381	1.105	1.0277	1.1431	.8619
3	.0332	.0381	.0381	1.1431	1.0277	1.1431	.8619
4	.0332	.0381	.0381	1.2003	1.0277	1.1431	.8619
5	.0332	.0381	.0381	1.2384	1.0277	1.1431	.9116
6	.0332	.0381	.0381	1.2384	1.0277	1.1431	.9116
7	.0332	.0381	.0381	1.2384	1.0442	1.1431	
8	.0332	.0381	.0381	1.2003	1.0442	1.1431	
9	.0381	.0381	.0381	1.2193	1.1105		.9116
10	.0381	.0381	.0381	1.0774	1.2955		1.0288
11	1.6004	1.8671	1.7718	.0332		.0332	.0381
12	1.7147	1.7528	1.829	.0332	.0381	.0332	.0381
13	1.7147		1.7909	.0332	.0381	.0332	.0381
14	1.7147	1.5813	1.8671	.0332	.0381	.0332	
15	1.7147	1.5242	1.9052	.0332	.0953	.0332	.0381
16	1.7147	1.6385	1.7909	.0332	.0381	.0332	.0381
17	1.6385	1.6385		.0332	.0381	.0332	.0381
18	1.6004	1.6766	1.5051	.0332	.0381	.0332	.0381
19	.0381	.0381	.0381	.0332	.0381	.0332	.0381
20	.0381	.0381	.0381	.0332	.0381	.0332	.0381
21	.0381	.0381	.0381	.0332	.0381	.0332	.0381
22	.0381	.0381	.0381	.0332	.0381	.0332	.0381
23	.0381	.0381	.0381	.0332	.0381	.0332	.0381
24	.0332	.0381	.0381	.0381	.0332	.0381	.0332
Max	1.7147	1.8671	1.9052	1.2384	1.2955	1.1431	1.0288
Min	.0332	.0381	.0381	.0332	.0332	.0332	.0332
Avg	.5824	.5343	.5682	.5098	.4873	.4370	.3667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 209 / 11 KV Danwad Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1143	.1143	.1143	.1334
2	.1334	.1334	.1334	.0953	.1143	.1143	.1334
3	.1334	.1334	.1334	.0953	.0995	.1143	.1334
4	.1334	.1334	.1334	.1143	.0995	.1143	.1334
5	.1334	.1334	.1334	.1143	.1143	.1143	.1334
6	.1334	.1524	.1334	.1334	.1143	.1334	.1334
7	.1334	.1715	.1334	.1334	.1524	.1334	
8	.1524	.1334	.1524	.1143	.1334	.1334	
9	.1524	.1334	.1334	.1143	.1334	.1334	.1524
10	.1334	.1334	.1334	.1143	.1334	.1334	.1334
11	.1334	.1524	.1143	.0953		.1334	.1334
12	.1524	.1334	.1524	.0953	.1334	.1143	.1334
13	.1334		.1524	.1143	.1334	.1143	.1334
14	.1334	.1334	.1334	.1143	.1524	.1143	.1143
15	.1334	.1334	.1334	.1334	.1143	.1143	.1143
16	.1143	.1143		.1334		.1143	.1143
17	.1143			.1334	.1143	.1143	.0953
18	.1143	.1143	.0953	.1334	.1143	.1143	.0953
19	.1143	.1143	.1524	.1334	.1334	.1334	.1143
20	.1905	.1905	.1715	.1524	.1715	.1524	.1524
21	.1524	.1905	.1715	.1524	.1715	.1524	.1524
22	.1524	.1715	.1524	.1334	.1524	.1715	.1524
23	.1334	.1524	.1334	.1334	.1334	.1334	.1334
24	.1334	.1334	.1334	.1334	.1143	.1143	.1334
Max	.1905	.1905	.1715	.1524	.1715	.1715	.1524
Min	.1143	.1143	.0953	.0953	.0995	.1143	.0953
Avg	.1366	.1420	.1386	.1223	.1294	.1262	.1299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 201 / 11 KV Santubai AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	.0457	.0486	2.0388	1.6872	2.0056	1.4737
2	.0486	.0457	.0486	2.0553	1.6872	2.0056	1.4737
3	.0486	.0457	.0486	2.0553	1.6872	2.0056	1.4575
4		.0457	.0486	2.0885	1.6872	2.0056	1.4899
5	.0486	.0457	.0486	2.0885	1.6872	2.0222	1.5061
6	.0486	.0457	.0486	2.1548	1.7185	2.0056	1.5384
7	.0486	.0457	.0648	2.1879	1.906	2.1548	
8	.0648	.0457	.0324	2.2045	2.0309	2.2874	
9	.0648	.0457	.0486	2.1714	2.0934	2.1879	
10	.0486		.0486	2.1216	2.0309		1.6194
11	2.1862	2.5263	2.3967	.0497	.0457	.0486	.0648
12	2.2653	2.5749	2.5692	.0457	.0332	1.3441	.0457
13	2.2965	2.5263	2.6852	.0457	.0332	.0486	.0457
14	2.2653	2.5425	2.6189	.0457	.0332	.0324	.0457
15	2.2653	2.4453	2.5692	.0457	.0497	.0486	.0305
16	2.2809	2.4453	2.5526	.0457	.0497	.0324	.0305
17	2.2653	2.4129		.0457	.0497	.0486	.0305
18	2.2184	2.3805	2.0885	.061	.0497	.0486	.0457
19	.061	.0648	.0663	.061	.0829	.0486	.0457
20	.0457	.0648	.0829	.061	.0829	.0486	.061
21	.0457	.0648	.0663	.061	.0995	.0486	.061
22	.0457	.0648	.0663	.0457	.0829	.0486	.061
23	.0457	.0486	.0663	.0457	.0663	.0486	.061
24	.0486	.0457	.0486	.0497	.0457	.0663	.0486
Max	2.2965	2.5749	2.6852	2.2045	2.0934	2.2874	1.6194
Min	.0457	.0457	.0324	.0457	.0332	.0324	.0305
Avg	.8176	.8965	.7984	.9115	.7925	.8975	.5351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2483	1.3748	1.3443	.0166	.0305	.0166	.032
2	1.2483	1.3748	1.3443	.0166	.0152	.0166	.032
3	1.2323	1.3748	1.3283	.0166	.0152	.0166	.032
4		1.3748	1.3283	.0166	.0152	.0166	.032
5	1.2163	1.3748	1.3443	.0166	.0152	.0166	.032
6	1.2323	1.406	1.3603	.0332	.0152	.0166	.032
7	1.2483	1.4373	1.3763	.0332	.0152	.0166	
8		1.4373	1.4243	.0332	.0152	.0166	
9	1.2803	1.4373	1.2483	.0166	.0152	.0166	.032
10	1.4083		1.2163	.0166	.0152	.0166	.032
11	.032	.032	.032	1.5415	1.3123	1.3123	1.2643
12	.0305	.032	.0166	1.531	1.4089	1.3283	1.2029
13	.0305	.032	.0166	1.531	1.442	1.3443	1.2029
14	.0305	.032	.0166	1.4373	1.442	1.2803	1.2498
15	.0305	.032	.0166	1.4373	1.5249		1.2498
16	.0305	.032	.0166	1.4373	1.4586	1.3763	1.2498
17	.0305	.032		1.3123	1.3923	1.3443	1.1873
18	.0305	.032	.0166	1.1561	1.3592	1.2003	1.0936
19	.0305	.032	.0166	.0305	.0166	.032	.0305
20	.0305	.032	.0332	.0305	.0166	.032	.0305
21	.0305	.032	.0332	.0305	.0166	.032	.0305
22	.0305	.032	.0332	.0305	.0166	.032	.0305
23	.0305	.032	.0332	.0305	.0166	.032	.0305
24	.032	.0305	.032	.0166	.0305	.0166	.032
Max	1.4083	1.4373	1.4243	1.5415	1.5249	1.3763	1.2643
Min	.0305	.0305	.0166	.0166	.0152	.0166	.0305
Avg	.4793	.5669	.5925	.4904	.4842	.4143	.4610



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 203 / 11 KV Ghosarawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1463	.1663	.1698	.1646	.132	.1478
2	.1663	.1463	.1663	.1698	.1646	.132	.1478
3	.1663	.1463	.1848	.1509	.1646	.1698	.1663
4		.1646	.2033	.1886	.1829	.2075	.1848
5	.1848	.2195	.2587	.2075	.1829	.2452	.2218
6	.2033	.3109	.3511	.2614	.2743	.2054	.2587
7	.3142	.2926	.3142	.2241	.2926	.2241	
8	.2957	.3109	.2957	.1848	.2195	.2772	
9	.2772	.2926	.2772	.2772	.2195	.2218	.2402
10	.2772		.2772	.2402	.2561	.2218	.2772
11	.2772	.2957	.2957	.2587	.2743	.2402	.2772
12	.2926	.3326	.2587	.2561	.2957	.2218	.2743
13	.2926	.3142	.2587	.2561	.2957	.1848	.2926
14	.2926	.3142	.2218	.1829	.3142	.2218	.1463
15	.2926	.2218	.2218	.1829	.2772	.2218	.1463
16	.1829	.2033	.2218	.1829	.2772	.2587	.1463
17	.1829	.2033		.2012	.2772		.1463
18	.2195	.1663	.1663	.1829	.2218	.1478	.2195
19	.2195	.2218	.1848	.1829	.1848	.1848	.2195
20	.2195	.2587	.2033	.2195	.1663	.2033	.2195
21	.2195	.2402	.2402	.2195	.1848	.1848	.2195
22	.2195	.2218	.2033	.2195	.1478	.1848	.2195
23	.2012	.1848	.1886	.1829	.1307	.1663	.1646
24	.1848	.1829	.1848	.1698	.1646	.132	.1478
Max	.3142	.3326	.3511	.2772	.3142	.2772	.2926
Min	.1663	.1463	.1663	.1509	.1307	.132	.1463
Avg	.2333	.2344	.2324	.2072	.2222	.1996	.2038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031] BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 204 / 11 kv Balumama AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0469	.0457	.0312	1.6129	1.4685	1.5497	1.3123
2	.0469	.0457	.0312	1.6129	1.4685	1.5497	1.3123
3	.0469	.0457	.0312	1.6129	1.4685	1.5497	1.2967
4		.0457	.0312	1.6446	1.4685	1.5655	1.2967
5	.0469	.0457		1.6446	1.4685	1.5655	1.3123
6	.0469	.0457		1.6446	1.4998	1.5655	1.3123
7	.0312	.0457	.0469	1.6762	1.531	1.5813	
8	.0312	.0457	.0469	1.6762	1.6248	1.6129	
9	.0312	.0457	.0469	1.6446	1.6404	1.6129	1.2654
10	.0312		.0625	1.6129	1.5623	1.5023	1.2498
11	1.7185	1.906	1.9528	.0316	.0305	.0312	.0312
12	1.8747	2.0309	1.9925	.0457	.0158	.0312	.0305
13	1.906	1.9841	2.0241	.0457	.0158	.0312	.0305
14	1.8747	1.906	1.9766	.0305	.0158	.0312	.0305
15	1.8747	1.8747	1.9766	.0305	.0474	.0312	.0305
16	1.7185	1.8591	1.9766	.0305	.0316	.0312	.0305
17	1.7185	1.8747		.0305	.0316	.0469	.0305
18	1.7185	1.781	1.5813	.0366	.0316	.0312	.0305
19	.0457	.0312	.0316	.0457	.0474	.0312	
20	.0457	.0469	.0474	.0305	.0474	.0312	.0457
21	.0457	.0469	.0474	.0457	.0474	.0469	.061
22	.0457	.0469	.0316	.0305	.0474	.0469	.1219
23		.0469	.0316	.0457	.0316	.0469	.0305
24	.0469	.0457	.0312	.0316	.0305	.0316	.0469
Max	1.906	2.0309	2.0241	1.6762	1.6404	1.6129	1.3123
Min	.0312	.0312	.0312	.0305	.0158	.0312	.0305
Avg	.6815	.6910	.6681	.7039	.6530	.6731	.5195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 205 / 11 KV Dattawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	1.2498	1.4091	.0332	.0305	.0332	.0328
2	1.4419	1.2498	1.3927	.0332	.0305	.0332	.0328
3	1.4255	1.2498	1.3763	.0332	.0305	.0332	.0328
4		1.2498	1.3927	.0332		.0332	.0328
5	1.4091	1.2498	1.4091	.0332	.0305	.0332	.0328
6	1.3927	1.3748	1.4255	.0332	.0305	.0332	.0328
7	1.4255	1.4998	1.4746	.0332	.0305		
8	1.5074	1.5935	1.5074	.0332	.0305	.0332	
9	1.5402	1.406	1.5238	.0332	.0305	.0497	.0328
10	1.5074		1.4419	.0332	.0305	.0332	.0328
11		.0492	.0492	1.5415	1.2811	1.0486	.8684
12	.0305	.0492	.0497	1.656	1.326	1.065	.9061
13	.0305	.0328	.0497	1.656	1.2763	1.1305	.9061
14	.0305	.0328	.0497	1.5623	1.21	1.1633	.7811
15	.0305	.0328	.0497	1.5623	1.21	1.1305	.7811
16	.0305	.0328	.0332	1.5623	1.1603	1.1142	.7811
17	.0457	.0328		1.406	1.1437	1.0159	.6249
18	.0457	.0328	.0166	1.406	1.0277	.9175	.6874
19	.0457	.0492	.0166	.0305	.0829	.0328	.0305
20	.0305	.0492	.0332	.0305	.0663	.0328	
21	.0305	.0492	.0332	.0457	.0497	.0328	.0305
22	.0305		.0332	.0305	.0332	.0328	.0305
23	.0305	.0492	.0332	.0457	.0332	.0492	.0305
24	.0328	.0305	.0328	.0332	.0305	.0332	.0328
Max	1.5402	1.5935	1.5238	1.656	1.326	1.1633	.9061
Min	.0305	.0305	.0166	.0305	.0305	.0328	.0305
Avg	.6153	.5748	.6449	.5375	.4437	.3963	.3216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 206 / 11 KV Dattawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.3292	.2926	.2829	.2561	.2641	.2926
2	.2926	.2926	.2926	.2829	.2561	.2641	.2926
3	.2926	.2926	.2926	.2829	.2561	.3018	.2926
4		.2926	.3109	.2829	.0732	.3018	.2926
5	.3292	.3292	.3292	.3018	.2926	.3361	.2926
6	.3292	.3658	.3292	.2987	.3292	.2987	.3109
7	.3109	.3658	.3109	.3174	.2926	.2772	
8	.2926	.2561	.3109	.2772		.2587	
9	.2926	.2926	.2926	.2587		.2957	.2926
10	.3109		.3109	.2772	.2926	.2957	.2926
11	.3292	.3475	.3658	.2957	.3292	.2926	.2743
12	.3658	.3658	.3696	.2561	.3326	.2926	.2561
13	.3658	.3109	.3696	.2561	.3696	.3292	.2561
14	.3658	.3658	.3696	.2926	.3696	.3292	.2561
15	.3658	.3658	.3696	.2926	.3142	.3292	.2561
16	.3658	.3292	.3696	.2926	.3142	.3292	.2561
17	.3658	.3292		.2926	.2957	.3109	.2195
18	.3658	.3109	.2957	.3658	.2957	.3109	.3292
19	.4024	.3841	.3326	.3292	.3326	.3658	.3292
20	.4024	.439	.4066	.4024	.4251	.4024	.4024
21	.3841	.4024	.4294	.3658	.3696	.3841	.3841
22	.3658	.3658	.3547	.3658	.3326	.3658	.3658
23	.3475	.3292	.3206	.3292	.2987	.3292	.3292
24	.3292	.3292	.2926	.2829	.2926	.2829	.2926
Max	.4024	.439	.4294	.4024	.4251	.4024	.4024
Min	.2926	.2561	.2926	.2561	.0732	.2587	.2195
Avg	.3427	.3388	.3356	.3034	.3055	.3145	.2985

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 207 / 11 KV Hanuman AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0517	.9374	1.0517	.0152	.0152	.0152	.0305
2	1.0364	.9374	1.0364	.0152	.0152	.0152	.0305
3	1.0059	.9374	1.0059	.0152	.0152	.0152	.0305
4		.9374	1.0059	.0152	.0152	.0152	.0305
5	.945	.9374	1.0212	.0152	.0152	.0152	.0305
6	.9297	.9998	1.0364	.0152	.0152	.0152	.0305
7	.9755	1.0936	1.0669	.0152	.0152	.0152	
8	.9755	1.0311	1.0669	.0152	.0152	.0151	
9	1.0517	1.1873	1.0669	.0152	.0152	.0151	.0152
10	1.1126		1.0669	.0152	.0152	.0151	.0152
11	.0152	.0152	.0152	1.3717	1.2498	1.326	1.2803
12	.0152	.0152	.0151	1.4373	1.2193	1.3413	1.2811
13	.0152	.0152	.0151	1.4373	1.2346	1.3108	1.2498
14	.0152	.0152	.0152	1.3279	1.2346	1.2803	1.1873
15	.0152	.0152	.0152	1.3279	1.3108	1.2955	1.1873
16	.0152	.0152	.0152	1.3279	1.2498	1.2803	1.1873
17	.0152	.0152		1.3123	1.2346	1.2651	1.0936
18	.0152	.0152	.0151	1.1561	1.2193		1.1248
19	.0152	.0152	.0151	.0152	.0151	.0305	.0152
20	.0152	.0305	.0152	.0152	.0305	.0305	.0305
21	.0152	.0305	.0152	.0152	.0305	.0152	.0305
22	.0152	.0305	.0152	.0152	.0305	.0152	.0305
23	.0152	.0305	.0152	.0152	.0305	.0305	.0305
24	.0152	.0152	.0152	.0151	.0152	.0152	.0305
Max	1.1126	1.1873	1.0669	1.4373	1.3108	1.3413	1.2811
Min	.0152	.0152	.0151	.0151	.0151	.0151	.0152
Avg	.4042	.4032	.4618	.4559	.4274	.4082	.4533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031] BU 1180

Substation No/ Name :- 146014 / 110KV KURUNDWAD

Feeder No / Name : 403 / 33KV Takali

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	2.2862
Max	2.2862
Min	2.2862
Avg	2.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031] BU 1180

Substation No/ Name :- 146014 / 110KV KURUNDWAD

Feeder No / Name : 404 / 33KV Ichalkaranji W/W  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-JUN-18
HR	Load (MW)
24	.6859
Max	.6859
Min	.6859
Avg	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 201 / 11KV Shirati Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1867	.168	.1753	.1753	.1867
2	.1494	.1867	.1867	.168	.1753	.1753	.1867
3	.1494	.1867	.168	.1494	.1753	.1753	.1867
4	.1494	.2054	.168	.1494	.1753	.1753	.2054
5		.2241	.1867	.168	.2103	.2103	.2427
6		.2427	.2054	.2241	.2279	.2454	.2801
7	.168	.2241	.2054	.2427	.2103	.2103	.2427
8	.2054	.1867	.168	.2241	.1753	.1928	.2241
9	.1867	.1867	.1867	.168	.1867	.1867	.2054
10	.2054	.2054	.168	.1867	.168	.2054	.1867
11	.2054	.2241	.1494	.1867	.2241	.2054	.2241
12	.2427		.1494	.168	.2241	.2241	.168
13	.2241	.2801		.1494	.2054	.2054	.1867
14	.1867	.2241		.168	.2054	.1867	.168
15	.1867	.2054	.1494	.168	.1867	.1867	.1494
16	.2241	.2054		.168	.1578	.1867	.1307
17	.1867	.1867		.1402	.1578		.181
18	.2054	.112	.2427	.1578	.1753	.2054	.181
19	.2427	.168	.2427	.181	.2103	.2614	.1991
20	.2427	.2241	.2427	.2103	.2279	.2614	.2353
21	.2614	.2427	.2427	.2103	.2103	.2427	.2172
22	.2427	.2241	.2614	.2103	.2103	.2241	.2172
23	.2054	.2241	.1867	.1928	.2103	.1867	.181
24	.1867	.2054	.2054	.1867	.1753	.1753	.1867
Max	.2614	.2801	.2614	.2427	.2279	.2614	.2801
Min	.1494	.112	.1494	.1402	.1578	.1753	.1307
Avg	.2020	.2070	.1951	.1811	.1942	.2045	.1989



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 202 / KUTWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	.823	.7537	.7888	.3361
2	.0373	.0373	.0373	.8402	.7537	.7888	.3361
3	.0373	.0373	.0373	.9896	.7537	.7888	.3361
4	.0373	.0373	.0373	.8916	.7537	.7888	.3361
5	.0373	.0373	.0373	.9602	.7537	.8589	.3361
6	.0373	.0373	.0373	.9945	.8589	.929	.3547
7	.0373	.0373	.0373	1.1203	.964	.9465	.3361
8	.0373	.0373	.0373	1.0288	1.0692	.9991	.3174
9	.0373	.0857	.0373	1.1763	1.1389	.9335	.2987
10	.0373	.0857	.0373	1.1576	1.251	.8215	.3361
11	1.6244	2.0538		.0373	.0373	.0187	.0373
12	1.7364	2.0911		.0373	.0373	.0187	.0373
13	1.7551	1.9605		.0373	.0373	.0187	.0373
14	1.6617	1.9791		.0373	.0373	.0187	.0373
15	1.6991	2.0165		.0373	.0373	.0187	.0373
16	1.6617	1.9791		.0373	.0373	.0187	.0373
17	1.6057	1.7924		.0351	.0351		.0362
18	1.587	1.7551	1.3443	.0175	.0351	.0373	.0362
19	.0373	.0373	.0343	.0351	.0175	.0373	.0362
20	.0373	.0373	.0343	.0351	.0351	.0373	.0362
21	.0373	.0373	.0343	.0351	.0175	.0373	.0362
22	.0373	.0373	.0373	.0175	.0175	.0373	.0362
23	.0373	.0373	.7716	.0175	.0175	.0373	.0181
24	.0373	.0373	.0373	.7888	.0175	.0175	.0373
Max	1.7551	2.0911	1.3443	1.1763	1.251	.9991	.3547
Min	.0373	.0373	.0343	.0175	.0175	.0175	.0181
Avg	.5803	.6801	.1568	.4662	.3945	.3912	.1592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 203 / SHIROL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0373	.0373	1.7177	1.5424	1.4022	.7655
2	.0373	.0373	.0373	1.7737	1.5424	1.4022	.7655
3	.0373	.0373	.0373	1.7924	1.5424	1.4022	.0373
4	.0373	.0373	.0373	1.8111	1.5424	1.4022	.0373
5		.0373	.0373	1.8298	1.5424	1.4373	.0373
6		.0373	.0373	1.8484	1.6126	1.5074	.0373
7		.0373	.0373	1.9418	1.6126	1.7002	
8		.0373	.0373	1.9418	1.6651	1.7353	
9	.0373	.0343	.0373	1.8858	1.8111		
10	.0373	.0343	.0373	1.8484	1.6991		
11	1.8858	2.4832	2.5019	.0373	.0373	.0187	
12	1.9418	2.5953		.0373	.0373	.0187	.0373
13	1.9791	2.4086		.0373	.0373	.0187	.0373
14	1.9978	2.4272		.0373	.0373	.0187	.0187
15	1.9605	2.2405		.0373	.0373	.0187	.0187
16	1.8671	2.2779			.0373	.0187	
17	1.9605	2.0911		.0351	.0351		.0181
18	1.9044	2.2592	2.0911	.0175	.0351	.0373	.0181
19	.0373	.0373	.0343	.0351	.0351	.0373	.0181
20	.0373	.0373	.0343	.0351	.0362		.0181
21	.0373	.0373	.0343	.0351	.0351	.0343	.0181
22	.0373	.0373	.0343	.0351	.0351	.0373	.0181
23	.0373	.0373	1.5604	.0351	.0351	.0373	.0181
24	.0373	.0373	.0373	1.5432	.0351	.0351	.0373
Max	1.9978	2.5953	2.5019	1.9418	1.8111	1.7353	.7655
Min	.0373	.0343	.0343	.0175	.0351	.0187	.0181
Avg	.7972	.8072	.3723	.8847	.6924	.6160	.1087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 204 / GHALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8962	.8745	.9149	.0934	.0701	.0701	.0747
2	.9335	.9709	.9149	.0857	.0701	.0701	.0747
3	.9335	.9709	.9335	.0857	.0701	.0701	.0747
4	.9709	.9896	.9709	.0857	.0701	.0701	.0747
5	1.0082	1.0082	1.0829	.0857	.0701	.0876	.0747
6	1.0269	1.0269	1.1203	.0857	.0701	.0701	.0747
7	1.0269	1.0456	1.1389	.0857	.0701	.0701	.0747
8	1.0269	1.1016	1.1763	.0686	.0701	.0701	.0747
9	1.0269	1.1576	1.1576	.0747	.0747	.0747	.0747
10	1.0456		1.1016	.0747	.0747	.0747	.0747
11				1.587	1.9605	1.1576	.7842
12	.0747			1.6244	1.9791	1.2136	.6908
13	.0747	.0343		1.643	1.8858	1.2323	.6722
14	.0747	.0686		1.6057	1.9044	1.2323	.6161
15	.0747	.0686		1.643	1.9605	1.2136	.5788
16	.0747	.0686		1.6057	1.9605	1.2136	.5975
17	.0747	.0747		1.5249	1.8229		.543
18	.0747	.0747		1.4373	1.8054		.1448
19	.0747	.0747	.0686	.0701	.0701	.0747	.0543
20	.0747	.0747	.0686	.0701	.0876	.0373	.0543
21	.0747	.0747	.0686	.0701	.0876	.0373	.0543
22	.0747	.0747	.0857	.0701	.0876	.0747	.0543
23	.0747	.0747	.0934	.0701	.0701	.0747	.0543
24	.0747	.0747	.0747	.0857	.0701	.0701	.0747
Max	1.0456	1.1576	1.1763	1.643	1.9791	1.2323	.7842
Min	.0747	.0343	.0686	.0686	.0701	.0373	.0543
Avg	.4725	.4754	.6857	.5805	.6859	.3800	.2384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 205 / 11KV Shirti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3256	.9149	1.1203	.0343	.0175	.0175	.0373
2	1.1949	.9522	1.1203	.0343	.0175	.0175	.0373
3	1.1576	.9522	1.1576	.0343	.0175	.0175	.0373
4	1.0082	.9522	1.1576	.0373	.0175	.0175	.0373
5	1.0269	1.0082	1.1949	.0343	.0175	.0175	.0373
6	1.0456	1.0829	1.2696	.0343	.0175	.0175	.0373
7	1.0456	1.1576	1.2883	.0343	.0175	.0175	.0373
8	1.0269	1.2323	1.363	.0343	.0175	.0175	.0373
9	.9709	1.1831	1.3256	.0376	.0187	.0187	.0373
10	.9896	1.2174	1.2696	.0373	.0187	.0187	.0373
11	.0373	.0343	.0373	1.475	1.6991	1.0456	.5975
12	.0373	.0343		1.5123	1.7177	1.0829	.5041
13	.0373	.0343		1.475	1.7177	1.1203	.5228
14	.0373	.0343		1.4937	1.7177	1.1203	.4294
15	.0373	.0343		1.363	1.6804	1.0642	.3734
16	.0373	.0343		1.3443	1.6804	1.0829	.3361
17	.0373	.0373		1.2971	1.4548		.2353
18	.0373	.0373	.0343	1.1744	1.3321	.8402	.2172
19	.0373	.0373	.0343	.0175	.0175	.0373	.0181
20	.0934	.0373	.0343	.0175	.0175	.0373	.0181
21	.0373	.0373	.0343	.0175	.0175	.0373	.0181
22	.0373	.0373	.0343	.0175	.0175	.0373	.0181
23	.0373	.0373	.0343	.0175	.0175	.0373	.0181
24	.0373	.0373	.0373	.0373	.0175	.0175	.0373
Max	1.3256	1.2323	1.363	1.5123	1.7177	1.1203	.5975
Min	.0373	.0343	.0343	.0175	.0175	.0175	.0181
Avg	.4738	.4649	.6971	.4838	.5534	.3364	.1549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 206 / Kutwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.168	.1494	.1494	.1494	.1402	.1402	.1307
2	.1494	.1494	.1494	.1494	.1402	.1402	.1307
3	.1494	.1494	.1494	.1494	.1402	.1402	.1307
4	.112	.168	.1494	.1494	.1402	.1402	.1494
5	.112	.168	.168	.168	.1578	.1578	.168
6	.1494	.1867	.168	.1867	.1578	.1753	.1867
7	.1494	.1867	.168	.1307	.1753	.1753	.168
8	.1307	.1494	.1494	.1494	.1402	.1402	.1494
9	.1307	.1448	.1307	.0934	.1494	.1307	.1494
10	.112	.1494	.1494	.0934	.1494	.1307	.1307
11	.1494	.1494	.1521	.0934	.1494	.1494	.112
12	.1521	.1494		.112	.168	.1494	.112
13	.168	.168		.1307	.1494	.1494	.1307
14	.168	.1494		.1307	.168	.1494	.1307
15	.1494	.2054		.1307	.168	.1494	.1307
16	.2054	.1715		.1307	.0876	.1307	.1307
17	.168	.168		.1402	.1227		.1448
18	.168	.168	.1867	.1227	.1227	.1867	.1086
19	.2241	.1867	.2241	.1578	.1753	.2241	.181
20	.2427	.2054	.2241	.1753	.2279	.2427	.181
21	.2241	.2054	.1867	.1753	.1928	.2054	.181
22	.1867	.1867	.2241	.1753	.1753	.168	.181
23	.168	.168	.1867	.1578	.1578	.1494	.1629
24	.168	.168	.168	.168	.1402	.1578	.1307
Max	.2427	.2054	.2241	.1867	.2279	.2427	.1867
Min	.112	.1448	.1307	.0934	.0876	.1307	.1086
Avg	.1627	.1688	.1713	.1425	.1540	.1601	.1463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 207 / Ghalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2614	.2987	.2427	.2279	.2454	.2427
2	.2614	.2614	.2801	.2427	.2279	.2454	.2427
3	.2614	.2614	.2614	.2241	.2279	.2454	.2427
4	.2241	.2614	.2241	.2241	.2279	.2454	.2427
5	.2241	.3174	.2241	.2427	.333	.333	.3174
6	.2987	.3921	.2614	.2801	.3681	.3681	.3921
7	.3361	.2987	.2987	.2801	.298	.298	.3547
8	.2614	.2801	.2801	.2614	.2629	.2629	.3174
9	.2801	.2427	.2801	.2801	.2241	.2801	.2801
10	.2801	.2801	.2241	.2801	.2801	.2801	.2614
11	.2614	.2614	.2054	.2987	.2987	.2614	.2427
12		.2801		.2801	.2614	.2801	.2614
13	.2801	.2614		.2614	.2614	.2614	.2427
14	.3361	.2427		.2614	.2241	.2614	.2241
15	.3174	.2987		.2427	.2427	.2801	.2054
16	.2801	.2801		.2241	.2427	.2427	.2241
17	.2801	.2427		.2103	.2103		.2353
18	.2614	.2241	.2987	.1991	.2103	.2617	.2715
19	.3361	.2987	.3921	.2629	.2629	.3921	.2896
20	.3547	.3361	.3734	.333	.333	.3734	.3439
21	.3734	.3547	.4108	.298	.3155	.3734	.3258
22	.3547	.3361	.3174	.3155	.3155	.3547	.3077
23	.3174	.3174	.2987	.2804	.298	.3174	.2534
24	.2801	.2987	.2987	.2572	.2629	.2629	.2614
Max	.3734	.3921	.4108	.333	.3681	.3921	.3921
Min	.2241	.2241	.2054	.1991	.2103	.2427	.2054
Avg	.2931	.2871	.2904	.2618	.2674	.2925	.2743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 201 / 11KV K'Guland

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0152	.0177	.9945	1.0059		.3978
2	.0162	.0152	.0177	.9945	1.0059		.3978
3	.0162	.0152	.0177	.9945	.9945		.3978
4	.0162	.0152	.0177	.9945	.9945		.3978
5		.0152	.017	1.0774	1.0774		.3978
6		.0152	.017	1.0774	1.1736		.3978
7		.0152	.017	1.1203	1.2574		.4144
8		.0152	.017	1.3413	1.3413	1.2742	.4144
9	.0152	.017	.0162	1.326	1.5261		.3647
10	.0152	.017	.0162	1.326	1.56	.9945	.3647
11	1.8107	1.8991	1.6575	.0162	.017	.0164	
12	1.8442	1.8991		.0162	.0177	.0164	
13	1.7101	1.8991		.0162	.0177	.0162	
14	1.7101	1.8313		.0162	.017	.0162	.0162
15	1.8107	1.7635		.0162		.0162	.0162
16	1.8442	1.6956		.0162	.0177	.0162	.016
17	1.8442	1.6956		.016	.017	.0162	.016
18	1.6766	1.6956	1.2431	.0162	.0177		.0162
19	.0152	.017	.0164	.0162	.017	.0162	.0162
20	.0152	.017	.0162	.0162	.017	.0162	.0162
21	.0152	.017	.0162	.0162	.017	.0162	.0162
22	.0152	.017	.0162	.0162	.017	.0162	.0162
23	.0152	.017	.0162	.0162	.017	.0162	.0162
24	.0162	.0152	.017	.0162	.0162		.0162
Max	1.8442	1.8991	1.6575	1.3413	1.56	1.2742	.4144
Min	.0152	.0152	.0162	.016	.0162	.0162	.016
Avg	.7219	.6098	.1761	.4780	.5287	.1760	.1963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 202 / 11KV Ganeshwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.5074	1.6278	.0162	.0162		.0162
2	1.6766	1.5402	1.6956	.0162	.0162		.0162
3	1.6575	1.6057	1.8313	.0162	.0162		.0162
4	1.6575	1.6057	1.8351	.0162	.016		.0162
5	1.6575	1.6876	1.9669	.0162	.016		.0162
6	1.7604	1.7695	2.2721	.0162	.016		.0162
7	1.8442	1.9334	2.34	.0158	.0162		.0162
8	1.9062	1.9662	2.4587	.016	.016	.0162	.0162
9	1.8842	2.0008	2.431	.0162	.017	.0162	.0162
10	1.8351	2.0348	1.9281	.0162	.017	.0162	.0162
11	.016	.017	.0164	2.0719	2.4806	1.989	1.5089
12	.016	.017		2.1795	2.3739	2.1548	1.326
13	.016	.017		2.1548	2.4417	2.1548	1.2431
14	.016	.017		2.0719	2.2721	2.0957	1.326
15	.016	.017		1.989	2.2043	2.0119	1.326
16	.016	.017		1.989	2.1704	2.0119	1.3413
17	.016	.017		1.9281	2.1704	1.8233	1.3077
18	.016	.017	.0162	1.9062	2.2148	1.8233	1.1603
19	.016	.017	.0162	.0162	.017	.0162	.0162
20	.016	.017	.0162	.0162	.017	.0162	.0162
21	.016	.017	.0162	.0162	.017	.0162	.0162
22	.016	.0183	.0162	.0162	.017	.0162	.0162
23	.016	.017	.0162	.0162	.017	.0162	.0162
24	.0166	.016	.0177	.0162	.0162		.0162
Max	1.9062	2.0348	2.4587	2.1795	2.4806	2.1548	1.5089
Min	.016	.016	.0162	.0158	.016	.0162	.0162
Avg	.7401	.7454	1.1399	.6895	.7747	1.0121	.4499



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 203 / 11KV Alas Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9465	1.0288	1.2209	.0162	.0162		.0162
2	.9816	1.0631	1.2209	.0162	.0162		.0162
3	.9816	1.0974	1.2209	.0162			.0162
4	.9465	1.0974	1.153	.0162			.0162
5	.9114	1.166	1.153	.0162			.016
6	.9114	1.2346	1.153	.0162			.016
7	1.0867	1.2346	1.2209	.016	.0162		.016
8	1.134	1.2346	1.2209	.016	.016	.0162	.016
9	1.1145	1.2209	1.3321	.016	.017	.0162	.0162
10	.9389	1.2209	1.2269	.0162	1.0852	.0162	.0162
11	.0152	.017	.0162	1.2269	1.1869		.8413
12	.0152	.017		1.262	1.2887	1.0517	.8413
13	.0152	.017		1.2971	1.3226	1.0166	.7011
14	.0152	.017		1.3394	1.3565	1.0166	.6733
15	.0152	.017		1.3032	1.3565	1.0166	.631
16	.0152	.017		1.1218		1.0277	.6135
17	.0152	.017		1.1218	1.1869	.9816	
18	.0152	.017	.0162		1.0174	.9816	.4382
19	.0152	.017	.0162	.0162	.017	.0162	.0164
20	.0152	.017	.0162	.0162	.017	.0162	.0162
21	.0152	.017	.0162	.0162	.017	.0162	.0162
22	.0152	.017	.0162	.0162	.017		.0162
23	.0152	.017	.0162	.0162	.017	.0162	.0162
24	.2058	.0152	.017	.0162	.0162		.0162
Max	1.134	1.2346	1.3321	1.3394	1.3565	1.0517	.8413
Min	.0152	.0152	.0162	.016	.016	.0162	.016
Avg	.4315	.4931	.6807	.3883	.5254	.5147	.2173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 204 / 11KV Alas Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5304	.5138	.4344	.5068		.4706
2	.5068	.5304	.5138	.4344	.5068		.4525
3	.5068	.4572	.5138	.4163			.4525
4	.5068	.4572	.5138	.4163			.4525
5	.5068	.5121	.4075	.4163			.4525
6	.5487	.5853	.4207	.4344			.5068
7	.5121	.5487	.443	.3856	.5487		.4706
8	.4706	.5121	.443	.3761	.5121	.4525	.4344
9	.439	.4784	.4525	.3224	.4252	.4525	.3982
10	.4572	.5138	.4887	.362	.443	.4163	.4163
11	.4938	.5138	.5487	.3982	.443	.4344	.4572
12	.5304	.5138		.4706	.4784	.4525	.4525
13	.6401	.5138		.4477	.5138	.5068	
14	.6036	.567		.4706	.4784	.5068	.4525
15	.6036	.567		.4706	.4784	.5068	.4706
16	.5853	.567		.4298	.443	.5068	.4525
17	.5853	.5138		.4298	.443	.5068	
18	.5121	.4252	.5792	.4887	.443	.5068	.5249
19	.5853		.6767	.5853		.6036	.5487
20	.6401		.7207	.695		.6099	.6401
21	.6584		.7023	.5853		.5544	.6219
22	.6401		.6219	.5853		.5304	.5487
23	.6219		.5068	.5487		.5068	.4706
24	.2103	.567	.567	.4344	.5068		.5068
Max	.6584	.5853	.7207	.695	.5487	.6099	.6401
Min	.2103	.4252	.4075	.3224	.4252	.4163	.3982
Avg	.5363	.5197	.5352	.4599	.4780	.5034	.4843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 205 / 11KV Ganeshwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4572	.4239	.3439	.3403		.3801
2	.362	.4572	.3898	.3439	.3224		.3801
3	.362	.439	.3544	.3258	.3224		.362
4	.3982	.439	.3544	.3258	.3224		.362
5	.3982	.439	.3544	.3982	.3582		.362
6	.3982	.439		.4207	.3801		.3982
7	.3439	.4024	.3189	.3982	.3801		.439
8	.3258	.4024	.3189	.3258	.2896	.362	.3801
9	.3109	.3721	.362	.3077	.3012	.362	.3258
10	.3292	.3721	.3077	.2715	.2883	.3077	.3077
11	.3475	.3721	.3077	.2896	.2835	.3258	.3439
12	.3658	.3898		.2715	.3544	.3077	.3439
13	.3658	.4252		.3224	.3544	.2896	.3258
14	.3841	.443		.362	.3898	.3258	.3258
15	.4572	.443		.3801	.3544	.362	.3077
16	.4938	.443		.362	.3366	.362	.3258
17	.4572	.4607		.3582	.3366	.362	.3801
18	.4755	.4252	.4525	.3439	.3898	.4024	.3439
19	.4755		.5121	.4163		.439	.4572
20	.5853		.5175	.5121		.4938	.499
21	.5853		.499	.5121		.4572	.4938
22	.5487		.4163	.4755		.4344	.4572
23	.5121		.362	.4024		.4163	.4207
24	.3658	.4755	.4607	.3439	.362		.3801
Max	.5853	.4755	.5175	.5121	.3898	.4938	.499
Min	.3109	.3721	.3077	.2715	.2835	.2896	.3077
Avg	.4171	.4262	.3948	.3672	.3403	.3756	.3792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 206 / 11KV Krishna Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3018	.3361	.3189	.3361		.3395
4	.3018	.3734	.3544	.3395		.3395
5	.3395	.3921		.3772		.3772
6	.3772	.3921	.3544	.3961		.3961
7	.3961	.3921	.3544	.3772		.3961
8	.415	.3734	.3544	.415	.415	.415
9	.4108	.3544	.3772	.3544	.415	.3772
10	.3734	.3544	.3772	.3544	.3772	.3772
11	.4108	.3544	.3772	.3544	.415	.3772
12	.4108	.3544		.3544	.3961	.3961
13	.4108	.3544		.3544	.415	.415
14	.4108	.3544		.3544	.3772	.3961
15	.4108	.3898			.3772	.415
16	.3921	.3898		.3544	.3961	.3772
17	.3734	.4024		.3544	.3772	
18	.3734	.3898	.3772	.3544	.3961	.3772
24	.1372					
Max	.415	.4024	.3772	.415	.415	.415
Min	.1372	.3361	.3189	.3361	.3772	.3395
Avg	.3674	.3723	.3606	.3620	.3961	.3848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 207 / 11KV Vijay-Ganesh

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1478	.362	.3012	.3361		.3361
4	.1294	.362	.3012	.3734		.3772
5	.1294	.362	.3544	.3734		.3772
6	.1294	.3077	.3544	.3921		.3772
7	.3921	.3077	.3544	.3734		.3772
8	.3921	.3258	.3721	.3772	.3921	.3921
9	.3801	.3544	.3734	.3898	.3361	.3921
10	.3982	.3052	.3921	.3898	.3961	.4108
11	.3801	.3052	.3921	.3898	.415	.3921
12	.3801	.3189		.3898	.3921	.4108
13	.3801	.3189		.3898	.3174	.3921
14	.3801	.3189		.3898	.3174	.3921
15	.3801	.3052		.3898	.3174	.3921
16	.3801	.3189		.3898	.3547	.3734
17	.3801	.3391			.3921	.3734
18	.2715		.1307		.2772	.2801
Max	.3982	.362	.3921	.3921	.415	.4108
Min	.1294	.3052	.1307	.3361	.2772	.2801
Avg	.3144	.3275	.3326	.3817	.3552	.3779

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 208 / 11 KV Bubnal Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2241	.2378	.2303	.2218		.1867
4	.2241	.2378	.2835	.2241		.2241
5	.2427	.2378	.2835	.2427		.2427
6	.2427	.2378	.2835	.2427		.2427
7	.2427	.3018	.2835	.2801		.2427
8	.2427	.3018	.2835	.3018	.2987	.2427
9	.3018	.2835	.2987	.2713	.2987	.2427
10	.3018	.2658	.2987	.2835	.2987	.1867
11	.3018	.2835	.2987	.2835	.2987	.1867
12	.3018	.2926		.2835	.2987	.1867
13	.3018	.2835		.2835	.3018	.1867
14	.3018	.2658		.2713	.3018	.1867
15	.3018	.2658		.2713	.3018	.1867
16	.3018	.2743		.2835	.3018	.1867
17	.3018	.2658		.2835	.3018	
18	.3018	.2658	.1478	.2835	.2801	.0934
24	.2103					
Max	.3018	.3018	.2987	.3018	.3018	.2427
Min	.2103	.2378	.1478	.2218	.2801	.0934
Avg	.2734	.2688	.2692	.2695	.2984	.2016

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 201 / 11 KV Nandani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.7842	.8131	.0187	.0175	.0187	.0181
2	.8002	.7842	.8131	.0187	.0175	.0187	.0181
3	.8002	.7842	.8215	.0187	.0175	.0187	.0181
4	.8002	.7842	.8589	.0187	.0175	.0187	.0181
5	.8002	.8962	.8589	.0187	.0175	.0187	.0181
6	.8215	.9335	.8962	.0187	.0175	.0187	.0187
7	.8764	1.0082	1.1203	.0187	.0175	.0187	
8	.9526	1.1203	1.1949	.0187	.0175	.0187	
9	.8589	1.1203	1.251	.0187	.0187	.0181	.0191
10	.0187	1.1203	1.1576	.0179	.0187	.0181	.0191
11	.0187	.0177	.0187	1.4045	1.3443	1.1203	.6859
12	.0187	.0175	.0187	1.419	1.3443	1.0829	.6097
13	.0187	.0175	.0187	1.4563	1.3817	1.0829	.5335
14	.0187	.0175	.0187	1.4335	1.4563	1.0456	.4572
15	.0187	.0175	.0187	1.3203	1.4563	1.0082	.4572
16	.0187	.0175	.0187	1.2826	1.3817	1.0082	.4572
17	.0187	.0175	.0187	1.3203	1.307	.9335	.4954
18	.0187	.0175	.0187	1.094	1.2696	.6722	.4572
19	.0187	.0175	.0187	.0179	.0187	.0181	.0191
20	.0187	.0175	.0187	.0175	.0187	.0181	.0191
21	.0187	.0175	.0187	.0175	.0187	.0187	.0191
22	.0187	.0175	.0187	.0175	.0187	.0181	.0191
23	.0187	.0175		.0175	.0187	.0181	.0191
24	.0187	.0187	.0175	.0187	.0175	.0187	.0181
Max	.9526	1.1203	1.251	1.4563	1.4563	1.1203	.6859
Min	.0187	.0175	.0175	.0175	.0175	.0181	.0181
Avg	.3240	.3993	.4360	.4593	.4679	.3437	.2007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 202 / 11 KV Nandani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4294	.4066	.4294	.3506	.3734	.362
2	.4001	.4108	.4066	.4108	.3506	.3734	.362
3	.4001	.4108	.3734	.4108	.3506	.3734	.362
4	.4191	.4108	.3734	.4108	.3856	.3734	.362
5	.4382	.3734	.4481	.4668	.4207	.4108	.3982
6	.4294	.3734	.4854	.4668	.4557	.4108	.4344
7	.4481	.4108	.4668	.5041	.4382	.4668	.4344
8	.4191	.4294	.3734	.4668	.4207	.4294	.4344
9	.4668	.4481	.4481	.4481	.4481	.4163	.4382
10	.4668	.4854	.5041	.4477	.4668	.4481	.4191
11	.4668	.4784	.5041	.462	.4668	.4668	.4572
12	.5041	.5258	.5228	.5041	.4668	.4854	.4954
13	.4668	.4733	.5228	.4854	.5228	.4668	.4382
14	.4481	.4207	.5228	.5093	.5228	.4294	.3239
15	.4668	.4207	.5788	.4904	.5228	.3734	.3239
16	.4668	.4908	.5601	.4904	.5415	.3734	.3429
17	.5601	.4557	.5228	.3772	.5601	.4294	.4191
18	.5975	.3856	.4854	.415	.3734		.4763
19	.5228	.4557	.4668	.4119	.4668	.3801	.5144
20	.4668	.5609	.4668	.4908	.5228	.4887	.5335
21	.4668	.4908	.4668	.4733	.5601	.4706	.4954
22	.5041	.4733	.4668	.4557	.4668	.4525	.381
23				.4207	.4481	.4163	.4382
24	.4572	.4294	.4207	.4294	.3506	.4294	.362
Max	.5975	.5609	.5788	.5093	.5601	.4887	.5335
Min	.4001	.3734	.3734	.3772	.3506	.3734	.3239
Avg	.4649	.4454	.4693	.4532	.4533	.4234	.4170



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 203 / Ganesh Bakery

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1494	.1663	.168	.1402	.1494	.1448
2	.1715	.1494	.1478	.168	.1402	.1494	.1448
3	.1715	.168	.1494	.1494	.1402	.1494	.1448
4	.1524	.168	.1494	.1494	.1753	.1867	.1448
5	.1715	.168	.168	.1494	.2103	.2614	.181
6	.2477	.1867	.1867	.1867	.2279	.2801	.2172
7	.2858	.1867	.3361	.2801	.3155	.3361	.2353
8	.3048	.2801	.3734	.3174	.3506	.3734	.2715
9	.3547	.3361	.3734	.3547	.3547	.3439	.4001
10	.3547	.3361	.3734	.3224	.3547	.3921	.362
11	.3734	.3189	.3734	.3326	.4108	.3361	.3429
12	.3921	.3506	.3734	.3921	.4108	.3547	.362
13	.3734	.2804	.3734	.3734	.4108	.3734	.3048
14	.3547	.2629	.3734	.3206	.3734	.3734	.2286
15	.3734	.3155	.3361	.3772	.3734	.3361	.2858
16	.3734	.3155	.3361	.415	.3547	.3361	.3239
17	.3734	.3506	.3361	.3961	.3547	.3361	.3048
18	.3734	.3155	.3361	.3206	.3547	.2987	.3239
19	.3734	.298	.2801	.3224	.3734	.2896	.2858
20	.3174	.2804	.2801	.2804	.3734	.2896	.2477
21	.2614	.2454	.2241	.2103	.2987	.2534	.2667
22	.1867	.2103	.2241	.1928	.2614	.181	.2286
23		.1753		.1753	.1867	.181	.1905
24	.0373	.1494	.1753	.168	.1578	.168	.1448
Max	.3921	.3506	.3734	.415	.4108	.3921	.4001
Min	.0373	.1494	.1478	.1494	.1402	.1494	.1448
Avg	.2839	.2499	.2802	.2718	.2960	.2804	.2536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 204 / 11 KV Agar Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2427	.2218	.2241	.2103	.2241	.2172
2	.2286	.2241	.1848	.2241	.2103	.2241	.2172
3	.2286	.2241	.1867	.1867	.2103	.2241	.2172
4	.2286	.2241	.1867	.1867	.2279	.2241	.2534
5	.2477	.2241	.2054	.1867	.2454	.2614	.2534
6	.2667	.2427	.2241	.1867	.2629	.2614	.2896
7	.2667	.2427	.2614	.2614	.2804	.2801	.3077
8	.2667	.2614	.2614	.2801	.2103	.2614	.3239
9	.2241	.2801	.2987	.2427	.2614	.2427	.3048
10	.2401	.3174	.2801	.1791	.2241	.2801	.3239
11	.2801	.3012	.2801	.2218	.2987	.2614	.2858
12	.3174	.333	.2801	.2801	.2987	.2801	.2286
13	.3174	.2454	.2614	.2614	.3174	.3361	.2667
14	.3174	.2804	.2614	.2641	.3361	.3361	.2667
15	.3174	.3155	.2614	.2641	.3361	.2987	.3239
16	.3174	.3506	.2801	.2641	.3547	.2987	.381
17	.2801	.3506	.2801	.2641	.3547	.2614	.3239
18	.2427	.2629	.2987	.2452	.3361	.2614	.2858
19	.2801	.2804	.2801	.2507	.3361	.2715	.3239
20	.2801	.3506	.2614	.3155	.3361	.362	.4001
21	.2801	.3155	.2801	.2804	.3361	.3258	.3429
22	.2987	.2804	.2801	.2454	.2801	.2896	.3048
23		.2629		.2454	.2614	.2534	.2667
24	.2477	.2427	.2279	.2241	.2103	.2241	.2172
Max	.3174	.3506	.2987	.3155	.3547	.362	.4001
Min	.2241	.2241	.1848	.1791	.2103	.2241	.2172
Avg	.2697	.2773	.2541	.2410	.2807	.2727	.2886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 205 / 11KV Dharangutti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1338	2.0911	1.6632		.0351	.0373	.0362
2	2.0957	2.0911	1.6632	.0373	.0351	.0373	.0362
3	2.0957	2.0538	1.7551	.0373	.0351	.0373	.0362
4	2.1338	2.0538	1.7551	.0373	.0351	.0373	.0362
5	2.0957	2.0911	1.8298	.0373	.0351	.0373	.0362
6	2.0957	2.0911	1.8671	.0373	.0351	.0373	.0362
7	2.0195	2.0911	2.1285	.0373	.0351	.0373	.0362
8	2.1338	2.0911	2.2405	.0373	.0351	.0373	.0362
9	1.9791	2.0538	2.2405	.0373	.0373	.0362	.0381
10	.0373	2.0165	2.2405	.0358	.0373	.0362	.0381
11	.0373	.0354	.0373	2.6242	2.8193		.4763
12	.0373	.0351	.0373	2.5579	2.8753	2.8567	.381
13	.0373	.0351	.0373	2.6139	2.9313	2.8193	.3429
14	.0373	.0351	.0373	2.6406	2.95	2.6513	
15	.0373	.0351	.0373	2.6029	2.95	2.5019	
16	.0373	.0351	.0373	2.6029	2.9127	2.5019	
17	.0373	.0351	.0373	2.584	2.894	2.4646	1.0479
18	.0373	.0351	.0373	2.452	2.838	.6348	.9907
19	.0373	.0351	.0373	.0358	.0373	.0362	.0381
20	.0373	.0351	.0373	.0351	.0373	.0362	.0381
21	.0373	.0351	.0373	.0351	.0373	.0362	.0381
22	.0373	.0351	.0373	.0351	.0373	.0362	.0381
23	.0373	.0351		.0351	.0373	.0362	.0381
24	.0381	.0373	.0351	.0373	.0351	.0373	.0362
Max	2.1338	2.0911	2.2405	2.6406	2.95	2.8567	1.0479
Min	.0373	.0351	.0351	.0351	.0351	.0362	.0362
Avg	.8060	.8841	.8637	.9229	.9895	.7400	.1824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 201 / MINCHE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.4534	.5182	.1966	.1943	.1943	.2058
2	.4024	.4534	.5182	.1966	.0648	.1943	.2058
3	.4024	.4534	.5182	.1966	.1943	.1943	.2241
4	.4024	.4534	.5182	.1966	.1943	.1943	.2058
5	.5898	.6154	.5182	.1966	.1943	.1943	.3772
6	.7865	.8421	.9069	.1966	.2591	.1943	.2058
7	.9831	1.004	1.0364	.2622	.2267	.2591	.2058
8	1.0486	1.1012	1.2631	.1966	.2267	.1943	.2241
9	.8745	1.1142	1.0486	.2622	.2401	.2058	.1943
10	.6478	.8192	.8192	.2743	.2374	.1715	.1943
11	.1943		.1715	1.166		.9831	
12	.2267	.2267	.1715	1.0814	1.0814	.9831	.9069
13	.1943		.1715	1.0486	.9831	.9831	.7773
14	.1943		.1715	.9175	.9175	.9175	.8097
15	.1943			.7865	.8192	.8192	.7773
16	.1943		.1966	.9503	.7865	.8192	.8097
17	.1943	.2591	.2294	.8848	.5898	.8192	.7125
18	.2267	.2591	.1966	.8097	.5182	.6173	.6478
19	.2915	.2915	.2622	.2267	.2591	.2743	.1943
20	.2915	.3239	.3395	.2915	.2591	.2743	.2267
21	.2915	.3239	.2949	.2915	.2591	.2743	.2591
22	.2591	.2915	.2622	.2915	.2267	.2743	.2591
23	.2267	.2591	.2622	.2591	.2267		.2591
24	.2743	.2267	.2591	.2294	.2267	.1943	.2058
Max	1.0486	1.1142	1.2631	1.166	1.0814	.9831	.9069
Min	.1943	.2267	.1715	.1966	.0648	.1715	.1943
Avg	.4081	.5143	.4632	.4754	.3994	.4448	.3951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 202 / NARANDE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0648	.7125	.583	.6154	.583	.7377
2	.1029	.0648	.0648	.583	.6154	.583	.7377
3	.1029	.0648	.0648	.583	.6154	.583	.7377
4	.1029	.0972	.0648	.583	.6154	.583	.7377
5	.1029	.0972	.0648	.583	.8745	.7773	.9389
6	.1029	.0972	.0972	1.004	1.1401	1.166	1.073
7	.1029	.0972	.0648	1.2955	1.1984	1.4251	1.1797
8	.1029	.0648	.0648	1.2308	1.2955	1.4251	1.2125
9	.0972	.0648	.0686	1.1012	1.3108	1.2452	1.166
10	.1296	.0648	.112	1.0159	1.0486	1.0486	1.1012
11	1.749	1.4251	1.7368	.1029	.0686	.0686	
12	1.6194	1.4251	1.6385	.1029	.0686	.1029	.0648
13	1.4899	1.4899	1.5729	.1029	.0686	.1029	
14	1.5546		1.5074	.1029	.0686	.1029	.0648
15	1.2955		1.1797	.1029	.0686	.1029	.0972
16	1.5684		1.2308	.1029	.1029	.1029	.0972
17	1.2955	1.2308	1.2308	.0972	.1029	.1029	.1296
18	.9069	1.3603	.9717	.0972	.0972	.1494	.0972
19	.0972	.1296	.0972	.0972	.1296	.1372	.1296
20	.0972	.1296	.1311	.0972	.1296	.1372	.1296
21	.0972	.1296	.1311	.0972	.1296	.1341	.1296
22	.0648	.0972	.0972	.0648	.1296	.1372	.1296
23	.0648	.7125	.0972	.0648	.1296		.1296
24	.1029	.0648	.7125	.0972	.0648	.0972	.1029
Max	1.749	1.4899	1.7368	1.2955	1.3108	1.4251	1.2125
Min	.0648	.0648	.0648	.0648	.0648	.0686	.0648
Avg	.5439	.4272	.5714	.4122	.4453	.4738	.4965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 203 / KHOCHI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0648	.0648	1.5074	1.5223	1.6194	1.1797
2	.0686	.0648	.0648	1.5074	1.5223	1.6194	1.1797
3	.0686	.0648	.0648	1.5074	1.5223	1.6194	1.1797
4	.0686	.0648	.0648	1.5074	1.5223	1.6194	1.1797
5	.0686	.0648	.0648	1.5074	1.6194	1.6194	1.2125
6	.0686	.0648	.0655	1.704	1.6842	1.6194	1.2452
7	.0686	.0648		1.9006	1.9433	1.9433	1.278
8	.0686	.0648		1.9334	2.0729	1.9433	1.3108
9	.0648	.0655	.0686	1.9662	1.9662	1.8351	1.2955
10	.0648	.0655	.0686	1.9334	1.9662	1.9334	1.2955
11	2.4531	2.5911	2.7526	.0686	.0686	.0686	
12	2.5857	2.7206	1.5729	.0686	.0171	.0686	.0648
13	2.5911		2.7526	.0686	.0686	.0686	.0648
14	2.4939		2.7526	.0686	.0686	.0686	.0648
15	2.2672		2.7199	.0686	.0686	.0686	.0648
16	2.332		2.6216	.0686	.0686	.0686	.0648
17	2.3967	2.2672	2.4905	.0686	.0686	.0686	.0648
18	2.2672	2.4615	2.4143	.0648	.0648	.0686	.0648
19		.0648	.0678	.0648	.0648	.0686	.0663
20		.0648	.0655	.0648	.0648	.0686	.0663
21	.0648	.0648	.0655	.0648	.0648	.0686	.0663
22	.0648	.0648	.0655	.0648	.0648	.0686	.0663
23	.0648	.0648	.0655		.0648		.0663
24	.0686	.0648	.0655	.0655	.0648	.0648	.0686
Max	2.5911	2.7206	2.7526	1.9662	2.0729	1.9433	1.3108
Min	.0648	.0648	.0648	.0648	.0171	.0648	.0648
Avg	.9240	.5539	.9545	.7758	.7593	.7939	.5743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 204 / BENDA VADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	1.587	1.4251	.0671	.0648	.0663	.0686
2	1.5729	1.643	1.4251	.0671	.0648	.0663	.0686
3	1.5729	1.587	1.4251	.0655	.0648	.0663	.0686
4	1.5729	1.587	1.4419	.0655	.0648	.0663	.0686
5	1.6385	1.6842	1.5546	.0671	.0648	.0648	
6	1.8351	1.8138	1.8138	.0655	.0648	.0663	
7	2.0317	1.9109	1.9109	.0655	.0648	.0663	.0686
8	2.0972	1.9433	1.9433	.0671	.0648	.0686	.0686
9	1.9757	2.0119	1.9662	.0671	.0171	.0686	.0648
10	1.9433	1.9448	2.2405	.0857	.0686	.0686	.0724
11	.0648	.0671	.0686	2.1628	2.4905	2.13	
12	.0663	.0648	.0686	2.3594	2.4249	2.13	1.6842
13	.0663	.0648	.0686	2.3594	2.3594	2.13	1.4251
14	.0648		.0171	1.9662	2.2939	2.13	1.6842
15	.0648		.0686	2.2939	2.2283	2.0972	1.7436
16	.0648		.0671	2.2283	2.0972	1.9989	1.7166
17	.0648	.0648	.0671	2.1628	1.9662	1.9006	1.8564
18	.0648	.0648	.0732	1.9433	2.1216	1.8351	1.7238
19	.0648	.0648	.0671	.0648	.0663	.0678	.0663
20	.0648	.0648	.0655	.0648	.0663	.0686	.0663
21	.0648	.0648	.0655	.0648	.0663	.0686	.0663
22	.0648	.0648	.0655	.0648	.0663	.0686	.0663
23	.0648	.0663	.0671		.0648		.0663
24	.0686	.0648	.0648	.0671	.0648	.0663	.0686
Max	2.0972	2.0119	2.2405	2.3594	2.4905	2.13	1.8564
Min	.0648	.0648	.0171	.0648	.0171	.0648	.0648
Avg	.7803	.8776	.7517	.8037	.7909	.7548	.6087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 205 / BENDA VADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.181	.181	.1829	.181	.181	.1867
2	.1867	.181	.1829	.1829	.181	.181	.1867
3	.1867	.181	.1829	.1829	.181	.181	.1867
4	.1867	.181	.1829	.1829	.181	.181	.1867
5	.1867	.181	.1829	.1829	.181	.181	.1867
6	.2241	.2172	.2195	.2195	.181	.181	.2241
7	.2241	.2172	.2172	.1829	.181	.181	.1867
8	.1867	.181	.181	.1829	.1448	.1867	.1867
9	.181	.181	.1494	.1463	.1494	.1867	.181
10	.181	.181	.1494	.1494	.1494	.1494	.181
11	.181	.1448	.1867	.1494	.1867	.1494	
12	.181	.1448	.1867	.1494	.1867	.1494	.1448
13	.2172	.1448	.1867	.1494	.1867	.1494	.1097
14	.2172		.1867	.1494	.1867	.1867	.1463
15	.2172		.1867	.1867	.1867	.1867	.1448
16	.2172		.1829	.1867	.1867	.1867	.1448
17	.2172	.181	.1829	.1886	.1867	.1867	.181
18	.2534	.181	.1829	.2172	.2172	.1867	.2172
19	.2534	.2534	.2195	.2534	.2172	.2614	.2534
20	.2534	.2896	.2195	.2534	.2534	.2614	.2534
21	.2534	.2896	.2195	.2534	.2172	.2614	.2534
22	.2534	.2896	.2195	.2172	.2172	.2241	.2172
23	.2172	.2172	.1829	.181	.181		.181
24	.1867	.181	.181	.1829	.181	.181	.1867
Max	.2534	.2896	.2195	.2534	.2534	.2614	.2534
Min	.181	.1448	.1494	.1463	.1448	.1494	.1097
Avg	.2104	.2000	.1897	.1881	.1876	.1896	.1881



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 206 / Khochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2534	.3658	.2561	.2534	.2987	.3361
2	.2987	.2534	.3658	.2561	.2267	.2987	.3361
3	.3018	.2534	.362	.2561	.2534	.2987	.3361
4	.2987	.2534	.3658	.2561	.2534	.2987	.3361
5	.2987	.2896	.3658	.2561	.2534	.2987	.3395
6	.2987	.2896	.3292	.2563	.2896	.2987	.2987
7	.2641	.2896	.2896	.2195	.2172	.2987	.2614
8	.2241	.2534	.2172	.2195	.2172	.2614	.2614
9	.2614	.3109	.1867	.2058	.2241	.2241	.2534
10	.2241	.231	.2987	.2241	.2241	.2241	.2987
11	.2241	.1372	.2614	.2241	.2241	.2241	
12	.2241	.2241	.2987	.2241	.1867	.2614	
13	.2987	.2987	.2987	.2241	.112	.2987	.0373
14	.2987		.2614	.1867	.2241	.2987	.2241
15	.1296		.2987	.1867	.2614	.2987	.2241
16	.2614		.2926	.1867	.2614	.2743	.2241
17	.2534	.2241	.2926	.2241	.2241	.2614	.2241
18	.2896	.3734	.2561		.2241	.2987	.2241
19	.4344	.3734	.3658	.3258	.3734	.3734	.2987
20	.4344	.3734	.3658	.3258	.4481	.4108	.3361
21	.4344	.3734	.3658	.3258	.3734	.4108	.3734
22	.362	.4481	.2926	.3258	.3734	.3734	.3734
23	.2896	.362	.2561	.3258	.2987		.3734
24	.2987	.2896	.3658	.2561	.2896	.2987	.3361
Max	.4344	.4481	.3658	.3258	.4481	.4108	.3734
Min	.1296	.1372	.1867	.1867	.112	.2241	.0373
Avg	.2918	.2931	.3091	.2499	.2620	.2993	.2867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 207 / Narand Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1448	.1463	.1463	.1086	.1494	.1494
2	.1494	.1448	.1494	.1463	.1086	.1494	.1494
3	.1494	.1448	.1494	.1494	.1086	.1494	.1494
4	.1494	.1448	.1463	.1463	.1086	.1494	.1494
5	.1494	.1448	.1829	.1494	.1448	.1494	.1494
6	.1494	.181	.1867	.1494	.1448	.1867	.1494
7	.1494	.181	.181	.112	.1448	.1494	.1494
8	.112	.1448	.181	.112	.1448	.1494	.1494
9	.1494	.0141	.1494	.112	.1494	.1494	.112
10	.1867	.1867	.1867	.112	.1867	.1494	.1494
11	.1494	.1867	.1867	.1494	.1494	.1867	
12	.1867	.1867	.1867	.1494	.1867	.1867	.2241
13	.1867		.1867	.112	.1867	.1867	.2241
14	.1867		.1867	.1372	.1867	.1867	.112
15	.1943		.1494	.1494	.1494	.1867	.112
16	.1494		.1494	.1494	.1494	.1494	.112
17	.1448	.1494	.1494	.1448	.1867	.1494	.112
18	.181	.1494	.1463	.2172	.1494	.1867	.112
19	.2172	.1867	.1494	.2172	.1867	.2241	.1867
20	.2534	.2241	.1829	.2172	.1867	.2241	.2241
21	.2534	.2241	.2103	.2172	.1867	.1867	.2241
22	.181	.2241	.1463	.181	.1867	.1494	.1867
23	.1448	.1867	.1494	.1448	.1494		.1494
24	.1494	.1448	.1494	.112	.1086	.1494	.1494
Max	.2534	.2241	.2103	.2172	.1867	.2241	.2241
Min	.112	.0141	.1463	.112	.1086	.1494	.112
Avg	.1697	.1647	.1662	.1514	.1541	.1689	.1559

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 208 / Minche Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.362	.3658	.362	.362	.3734	.3734
2	.3734	.362	.3658	.362	.362	.3734	.3734
3	.3734	.362	.3734	.362	.362	.3734	.3734
4	.3734	.362	.3734	.362	.362	.3734	.3734
5	.4481	.4344	.3734	.362	.362	.3734	.3734
6	.4481	.4344	.3734	.362	.4344	.4108	.4481
7	.4481	.4344	.362	.3982	.362	.3734	.3734
8	.4108	.362	.362	.3658	.362	.3734	.3734
9	.3563	.362	.3734	.3658	.3734	.3734	.3734
10	.4344	.3258	.4108	.3361	.4108	.3734	
11	.4481	.3982	.4108	.5228	.4108	.4108	
12	.439	.362	.4108	.3361	.3734	.4108	.2987
13	.3658	.3734	.4108	.3361	.3734	.4108	
14	.3982		.4108	.3361	.4108	.3734	.2987
15	.439		.2987	.3361	.4108	.3361	.2987
16	.439		.4024	.3734	.3734	.4108	.3734
17	.3887	.4108	.4024	.3734	.3361	.4108	.2987
18	.4534	.4481	.3658	.3982	.3734	.4481	.3734
19	.5068	.5228	.439	.4344	.4854	.5228	.4481
20	.5068	.5601	.5121	.4344	.5228	.5228	.4854
21	.4344	.5975	.4755	.4344	.5228	.5228	.5228
22	.3982	.5228	.439	.4344	.5228	.4481	.4481
23	.3982	.4481	.3506	.362	.4481		.3734
24	.3734	.3982	.3658	.362	.362	.4108	.3734
Max	.5068	.5975	.5121	.5228	.5228	.5228	.5228
Min	.3563	.3258	.2987	.3361	.3361	.3361	.2987
Avg	.4179	.4211	.3928	.3797	.4033	.4091	.3823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 209 / 11KV Buwache Wathar AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0648	1.0688	1.3951	1.3603	1.2955	1.1797
2	.0686	.0648	.0324	1.3904	1.3603	1.2955	1.1797
3	.0686	.0648	.0324	1.3904	1.3603	1.2955	1.1797
4	.0686	.0648	.0324	1.3904	1.3603	1.2955	1.1797
5	.0686	.0648	.0324	1.3904	1.4575	1.2955	1.278
6	.0686	.0648	.0648	1.4243	1.587	1.4899	1.3435
7	.0686	.0648	.0648	1.6278	1.6194	1.6385	1.4091
8	.0686	.0648	.0648	1.6617	1.7166	1.6712	1.4746
9	.0648	.0701	.0686	1.6617	1.7368	1.6057	1.4575
10	.0648	.0724	.0686	1.5729	1.704	1.6057	1.3927
11	1.8461	1.9753	1.9006	.0686	.0686	.0655	
12	1.8461	2.0995	1.8351	.0686	.0686	.0343	.0324
13	1.8461	2.0081	1.7695	.0686	.0686	.0343	.0324
14	1.8461		1.7695	.0686	.0686	.0686	.0324
15	1.8138		1.7695	.0686	.0686	.0686	.0324
16	1.8461		1.8652	.0686	.0686	.0686	.0324
17	1.749		1.8652	.0686	.0686	.0686	.0324
18	1.4251	1.6842	1.7974	.0648	.0324	.0686	.0324
19	.0648	.0648	.0648	.0648	.0324	.0686	.0324
20	.0648	.0648	.0732	.0648	.0324	.0686	.0324
21	.0648	.0648	.0732	.0648	.0324	.0686	.0324
22	.0648	.0648	.0732	.0648	.0324	.0686	.0324
23	.0648	1.1336	.0701	.0648	.0324		.0324
24	.0686	.0648	1.1012	.0732	.0648	.0324	.0686
Max	1.8461	2.0995	1.9006	1.6617	1.7368	1.6712	1.4746
Min	.0648	.0648	.0324	.0648	.0324	.0324	.0324
Avg	.6371	.4943	.7316	.6603	.6667	.6640	.5883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 210 / Khandoba AG (Bhendwade) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7773	.8097	.0316	.0324	.0324	.0343
2	.7377	.7773	.8097	.0316	.0324	.0324	.0343
3	.7377	.7773	.8097	.0316	.0324	.0324	.0343
4	.7377	.7773	.9069	.0316	.0324	.0324	.0343
5	.7712	.8745	.9393	.0316	.0324	.0324	.0343
6	.8192	.9393	1.004	.0316	.0324	.0324	.0343
7	.8848	.9717	1.0688	.0316	.0324	.0324	.0343
8	.9175	.9717	1.0688	.0316	.0324	.0324	.0343
9	.8745	1.004	1.0814	.0316	.0343	.0343	.0324
10	.7773	1.004	1.0486	.0343	.0686	.0343	
11	.0324	.0312	.0343	.9831	1.1469	1.1797	
12	.0324	.0312	.0343	.9831	1.1797	1.1797	.9393
13	.0324	.0324	.0343	.9831	1.1797	1.1797	.9069
14	.0324		.0343	.1372	.9831	1.1797	.9717
15	.0324		.0343	1.0814	1.0814	1.1797	1.0364
16	.0324		.0312	1.1142	1.1469	1.1142	1.004
17	.0324	.0324	.0312	1.1012	1.1469	1.0486	1.004
18	.0324	.0324	.0336	1.0364	1.0364	.9831	.9393
19	.0324	.0324	.0312	.0324	.0324	.0343	.0324
20	.0324	.0324	.0312	.0324	.0324	.0343	.0324
21	.0324	.0324	.0312	.0324	.0324	.0343	.0324
22	.0324	.0324	.0312	.0324	.0324	.0343	.0324
23	.0324	.0324	.0316	.0324	.0324		.0324
24	.0343	.0324	.0324	.0316	.0324	.0324	.0343
Max	.9175	1.004	1.0814	1.1142	1.1797	1.1797	1.0364
Min	.0324	.0312	.0312	.0316	.0324	.0324	.0324
Avg	.3354	.4394	.4168	.3305	.3941	.4149	.3320

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 401 / 33 kv Sharad Co-gen

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1097	.1097	.1097	.1097	.1097	.1029
2	.1029	.1097	.1097	.1097	.1097	.1097	.1029
3	.1029	.1097	.1097	.1097	.1097	.1097	.1029
4	.1029	.1097	.1097	.1097	.1097	.1097	.1029
5	.1029	.1097	.1097	.1097	.1097	.1097	.1029
6	.1029	.1097	.1097	.1097	.1097	.1097	.1029
7	.1029	.1097	.1029	.1097	.1097	.1097	.1029
8	.1029	.1097	.1029	.1097	.1097	.1097	.1029
9	.1097	.1097	.1029	.1097	.1029	.1029	
10	.1097	.1097	.1029	.1029	.1029	.1029	
11	.1097	.1097	.1029	.1029	.1029	.1029	
12	.1097	.1097	.1029	.1029	.1029	.1029	
13	.1086	.1097	.1029	.1029	.1029	.1029	.1097
14	.1097		.1029	.1029	.1029	.1029	.1097
15	.1086		.1029	.1029	.1029	.1029	.1097
16			.1097	.1029	.1029	.1029	.1097
17	.1097	.0972	.1097	.1029	.1029	.1029	.112
18	.1097	.1097	.1097	.1097		.1029	.112
19	.1097	.1097	.1097	.1097	.1017	.1029	.1097
20	.1097	.1097	.1097	.1097	.0972	.1029	.1097
21	.1097	.1097	.1097	.1097	.0972	.1029	.1097
22	.1097	.1097	.1097	.1097	.1097	.1029	.1097
23	.1097	.1097	.1097	.1097	.1097		.1086
24	.1097	.1097	.1097	.1097	.1097	.0972	.1029
Max	.1097	.1097	.1097	.1097	.1097	.1097	.112
Min	.1029	.0972	.1029	.1029	.0972	.0972	.1029
Avg	.1072	.1091	.1072	.1074	.1056	.1050	.1068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0191			1.0402	1.1523	.9998
2	.0305	.0191		.2915	1.0595	1.1843	1.0155
3	.0305	.0191		.2915	1.0722	1.1843	1.0155
4	.0305	.0191		.2915	1.085	1.2003	.9998
5	.0305	.0191		.3239	1.1683	1.2323	1.0311
6	.0305	.0229		.3239	1.2483	1.3441	1.0623
7	.0305	.0191		.421	1.2963	1.4403	1.1092
8	.0305	.0191		.4049	1.3763	1.4403	1.1561
9	.0305	.0191	.0305	.4049	1.3443	1.4243	1.1717
10			.0305	1.4413	1.3603	1.3443	1.1523
11	1.8278	.5182	1.8564	1.1405	.0191		
12	1.8591	.5506	2.0243		.0191		.0305
13	1.8747	1.8623	1.9364		.0191		.0191
14	1.8747		1.866		.0191		.0191
15	1.8747		1.8343		.0191		.0191
16	1.8435		1.8404		.0191		.0191
17	1.7497	1.7652	1.7604				.0191
18	1.6872	1.9433	1.6644	.0305	.0191		.0191
19	.0191		.0324	.0305	.0191		.0305
20			.0324	.0305	.0191		.0305
21			.0324	.0305	.0191		.0305
22	.0191		.0324	.0305	.0191		.0305
23	.0229		.0324	.0305	.0191		.0305
24	.0305	.0191		.0324	.0305	.0191	
Max	1.8747	1.9433	2.0243	1.4413	1.3763	1.4403	1.1717
Min	.0191	.0191	.0305	.0305	.0191	.0191	.0191
Avg	.7123	.4556	1.0004	.3265	.5352	1.1787	.5005

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 202 / 11KV Latwade AG Fdr

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8084	1.5708	1.6549	.0486	.0457	.0286	
2	1.8084	1.587	1.704	.0486	.0457	.0381	
3	1.7711	1.587	1.7204	.0486	.0457	.0286	
4	1.7711	1.6518	1.7204	.0486	.0457	.0286	
5	1.8884	1.8461	1.7695	.0486	.0457	.0286	
6	1.9524	1.9595	1.8351	.0486	.0457	.0286	
7	2.0165	2.0729	1.8842	.0486	.0457	.0286	
8	2.0165		1.9498	.0486	.0457	.0286	
9	1.9685	1.6194	1.9364	.0486	.0457	.0286	
10			2.0241	.0486	.0381	.0286	.0457
11		.0486	.0457	2.0481	2.1376	2.1464	
12		.0486	.0457	2.0481	2.0729	2.13	1.8564
13		.0486	.0457	2.1628	2.0081	2.0972	1.7328
14			.0457	2.0645	1.9919	2.0317	1.7814
15			.0457	2.0645	1.9757	2.0481	1.8299
16			.0457	2.0645	1.8947	2.0481	1.8947
17			.0457	1.9524		2.0481	1.8461
18		.0486	.0457	1.6484	1.587	2.0317	1.8299
19	.0381		.0486	.0457	.0286		.0457
20			.0486	.061	.0381		.0457
21	.0381		.0486	.061	.0286		.0457
22	.0381		.0486	.061	.0286		.0457
23	.0343		.0486	.061	.0286		.0457
24	.061	.0286		.0486	.061	.0286	
Max	2.0165	2.0729	2.0241	2.1628	2.1376	2.1464	1.8947
Min	.0343	.0286	.0457	.0457	.0286	.0286	.0457
Avg	1.2294	1.0860	.8177	.7032	.6231	.8898	1.0035



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 203 / 11KV Latwade Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4733	.4525	.567	.4344	.4557	.5068	.4755
2	.4607	.4344	.5304	.3982	.4557	.5068	.4572
3	.443	.4344	.5487	.3982	.4382	.5068	.4755
4	.443	.4706	.567	.4344	.443	.5792	.4938
5	.5014	.4887	.6036	.4706	.5258	.6335	.5853
6	.567	.5249	.6401	.5249	.5609	.6878	.695
7	.6135	.4706	.6584	.5611	.631	.7059	.6767
8	.567	.3982	.6219	.543	.5895	.6697	.6401
9	.5434	.362	.5609		.5487	.6516	.567
10			.5784	.4887	.6154	.6154	.5847
11	.5853	.3982	.6556	.5304	.6219	.6584	
12	.6036	.3982	.6485	.5853	.6335	.6584	.5493
13	.6401	.4163	.6485	.5853	.5792	.6401	.5493
14	.6401		.6556	.5487	.5973	.6401	.543
15	.6401		.6173	.5487	.6154	.6584	.5068
16	.6584		.6173	.567	.6154	.6584	.5792
17	.6219	.6516	.6516	.5258		.6767	.6154
18	.5853	.6335	.5552	.5138	.6516	.6219	.5249
19	.6335	.695	.6878	.5609	.724	.7682	.5959
20		.823	.6154	.6201	.8326	.695	.7011
21	.2172	.823	.3982	.6135	.7964	.695	.6661
22	.5792	.8048	.5249	.5959	.7602	.6401	.5959
23	.5304	.695	.543	.5258	.6335	.5487	.5316
24	.4961	.4706	.6036	.4525	.4607	.5249	.4755
Max	.6584	.823	.6878	.6201	.8326	.7682	.7011
Min	.2172	.362	.3982	.3982	.4382	.5068	.4572
Avg	.5474	.5423	.5958	.5229	.5994	.6312	.5689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 204 / Laxmi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0191		.4458	.6249	.6241	.5182
2	.061	.0191		.4458	.6642	.6241	.5487
3	.061	.0191		.4755	.6642	.6241	.5335
4	.061	.0191		.4755	.6958	.5944	.5487
5	.061	.0286		.5053	.7343	.5944	.5792
6	.061	.0286		.5944	.8436	.6836	.6706
7	.061	.0191		.7133	.953	.8025	.7316
8	.061	.0191		.7727	.9962	.8619	.7773
9	.061	.0191	.061	.6836	.8322	.8322	.7316
10			.061	.6539	.8128	.743	.6958
11		.9808	1.1873		.0229		
12	1.1584	.9808	1.2809		.0191		.061
13	1.0974	.9659	1.2498		.0286		.061
14	1.0669		1.2029		.0286		.0381
15	1.0669		1.1248		.0286		.0286
16	1.0364		1.0595		.0191		.0286
17	.9755	.8322	.9962	.0305			.0286
18	.9145	.8322	.9442	.0305	.0286		.0286
19	.0286		.0446	.0305	.0286		.061
20			.0446	.061	.0191		.061
21	.0343		.0446	.061	.0191		.061
22	.0286		.0446	.061	.0191		.061
23	.0191		.0297	.061	.0191		.061
24	.061	.0286		.0297	.061	.0191	
Max	1.1584	.9808	1.2809	.7727	.9962	.8619	.7773
Min	.0191	.0191	.0297	.0297	.0191	.0191	.0286
Avg	.3827	.3208	.6250	.3406	.3549	.6367	.3143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 205 / Tasgaon LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2949	.3086	.3086	.3018	.3086	.3086
4	.3018	.3086	.3086	.3018	.3086	.3086
5	.2949	.3086	.3086	.3086	.3086	.3086
6	.3018	.3086	.3086	.3052	.3086	.3086
7	.3018	.3086	.3086	.3052	.3086	.3086
8	.2949	.3086	.3086	.3086	.3086	.3086
9	.2949	.3086	.3018	.3086	.3086	.3086
10			.3018	.3086	.3086	.3052
11	.3086	.2915	.2949	.3086	.3086	
12	.3086	.2915	.3018	.3086	.3086	.3052
13	.3086	.2915	.3052	.3086	.3086	.3052
14	.3086		.3086	.3086	.3086	.3086
15	.3086		.3086	.3086	.3086	.3086
16	.3086		.3086	.3086	.3086	.3086
17	.3086		.3086		.3086	.3086
18	.3086		.3052	.3086	.3086	.3086
Max	.3086	.3086	.3086	.3086	.3086	.3086
Min	.2949	.2915	.2949	.3018	.3086	.3052
Avg	.3036	.3035	.3060	.3072	.3086	.3079

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 201 / SUT GIRNI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 202 / GHUNKI AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.6802
Max	.6802
Min	.6802
Avg	.6802

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 203 / BHADOLE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	2.7044
Max	2.7044
Min	2.7044
Avg	2.7044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 204 / VADGAON Vg FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032] BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 206 / Top Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.6001
Max	.6001
Min	.6001
Avg	.6001



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 208 / BHADOLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.8574
Max	.8574
Min	.8574
Avg	.8574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 209 / GHUNKI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 211 / Ambap Gaothan Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 405 / 33 KV R.M Mohite

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	6.1728
Max	6.1728
Min	6.1728
Avg	6.1728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 409 / 33 KV Preetam Enterprises NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 410 / 33 KV KODOLI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	7.7161
Max	7.7161
Min	7.7161
Avg	7.7161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 411 / 33 KV SARUD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1029
Max	.1029
Min	.1029
Avg	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 201 / 11 KV KATALI VILLAGE  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658			.037	.0924	.0754	.1132
2	.2957			.037	.0732	.0566	.0747
3	.2743		.0185	.0554	.0732	.0566	.0747
4	.2561		.0187	.0373	.0732	.0754	.0747
5	.2587		.0187	.0566	.0914	.0943	.0754
6	.1663		.037	.056	.1109	.1646	.1132
7			.0554	.056	.1448	.2195	.168
8	.2587		.0754	.056	.2378	.2561	.1867
9	.3292	.2241	.0924	.056	.2772	.1663	.1848
10	.2172	.1307	.3224	.0373	.2054	.1663	.1478
11	.2835	.3403		.0373	.2402	.1629	.1478
12	.3012	.3155	.3224		.2241	.1629	
13	.2743	.2058	.2865		.2218		.1478
14	.2572	.2543	.2835			.1629	.1478
15	.3185		.2658			.181	.1478
16	.0503		.0537		.2987		.1478
17	.2012	.0526	.2686	.1646	.2801	.181	.2195
18	.3077		.362	.1848	.2614	.2353	.2218
19	.2896	.0366	.4163	.3326		.2772	.2587
20	.3658	.0373	.362	.2987	.2686	.2587	.2587
21		.0377	.3439	.2772	.2481	.2241	.2218
22		.0377	.3584	.168	.1417	.132	.1478
23		.0373		.1478	.0886	.1132	.1109
24	.4307		.0566		.0754		.1132
Max	.4307	.3403	.4163	.3326	.2987	.2772	.2587
Min	.0503	.0366	.0185	.037	.0732	.0566	.0747
Avg	.2751	.1425	.2009	.1164	.1775	.1630	.1524



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 202 / 11 KV GAGAN BAWADA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0924		.056	.0739	.0554	.0566	.0754
2	.0924		.056	.0554	.0549	.0566	.0747
3	.0732		.0554		.0549	.0566	.0747
4	.0732		.056	.0747	.0732		.0747
5	.0924		.0747	.056	.0732	.0566	.0754
6	.0924		.0739	.0754	.0739	.0732	.0754
7	.0924		.0934	.0934	.0724	.0549	.0934
8	.1109		.1132	.0934	.0732	.0732	.0934
9	.1075	.1494	.0924	.0747	.0924	.0739	.0924
10	.0905	.1294	.0914	.0934	.112	.0924	.0739
11	.1063	.1075	.1075	.0934		.0905	.0732
12	.1063	.1052	.0895	.0554	.112	.0905	.0739
13	.1029	.1029	.1075	.0905	.0924	.0905	.0739
14	.12	.1187	.0886	.0905	.0934	.0724	.0924
15	.1006		.0886	.1086	.0747	.0724	.0924
16	.1174		.0895	.1254	.0747	.0905	.0924
17	.0838	.0876	.0895	.0914		.0724	.0895
18	.0905	.0886	.0905	.0739	.0747	.0724	.1109
19	.1267	.1097	.0905	.0934		.1109	.112
20	.128	.112	.1267	.112		.1109	.1109
21		.1132	.132	.0924	.0886	.112	.1109
22		.1132	.0943	.0934	.0886	.0943	.0924
23		.0934	.0747	.0924	.0709	.0943	.0924
24	.0934		.0566		.0566		.0754
Max	.128	.1494	.132	.1254	.112	.112	.112
Min	.0732	.0876	.0554	.0554	.0549	.0549	.0732
Avg	.0997	.1101	.0870	.0865	.0781	.0804	.0873

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 203 / 11 KV Andur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109		.0373	.0554	.0554	.0377	.0754
2	.0924		.056	.037	.037	.0377	.0747
3	.0914		.0554	.0373	.0366	.0377	.056
4	.0914		.037	.0373	.0366	.0377	.056
5	.1294		.0373	.0373	.0732		.0566
6	.1294			.0754	.0924	.0732	.0754
7	.1478		.0934	.0934	.0905	.0549	.0747
8	.1478		.132	.112	.0914	.1097	.1307
9	.12	.0747	.0924	.112	.1307	.0739	.1478
10	.1448	.1478	.0914	.0934	.0924	.0924	.1109
11	.1595	.1612	.1075	.0747	.1109	.0905	.1109
12	.1417	.1753	.1075	.0739	.112	.0905	.112
13	.1372	.1543	.0895	.0905	.0924	.0724	.1109
14	.1372	.1187		.0905	.0934	.0724	.0924
15	.1341		.0716	.0905	.0934	.0724	.1109
16	.1341		.1075	.0895	.0934	.0724	.1109
17	.1174	.0175	.1075	.0914	.0747	.1086	.128
18	.1267	.0354	.0724	.0739	.0747	.0724	.1294
19	.1448		.1086	.1294		.1294	.1478
20	.1646	.112	.1448	.112		.1109	.1478
21		.132	.1698	.1109	.1063	.1307	.1294
22		.0943	.0943	.0747	.0354	.0943	.1294
23		.056	.0747	.0554	.0354	.0943	.1109
24	.112		.0377		.0377		.0754
Max	.1646	.1753	.1698	.1294	.1307	.1307	.1478
Min	.0914	.0175	.037	.037	.0354	.0377	.056
Avg	.1293	.1066	.0875	.0803	.0771	.0803	.1043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 204 / 11 KV KATALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0187
Max	.0187
Min	.0187
Avg	.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 205 / 11 KV ANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185		.0187	.0185	.0185		.0189
2	.0187		.0187	.0185	.0183		.0187
3	.0183		.0185	.0187	.0183		.0187
4	.0185		.0185	.0187	.0183		.0187
5	.0185		.0187	.0187	.0185		.0189
6	.0187		.0185	.0187	.0183		.0189
7	.0185		.0187	.0187	.1294		.0747
8	.0185		.0185	.0187	.2195		.0934
9	.0185	.0187	.0185	.0187	.0185	.037	.037
10	1.1403	1.9404	.0183	.0187	.0187	.037	.0739
11	1.6301	1.6655	.5194	.0187	.0185	.0362	.0554
12	1.8073	1.7528	.5552	.0181	.0187	.0181	.037
13	1.8004	1.2689	.4477	.0185	.0185	.0181	.0554
14	1.869	1.56	.4961	.0181		.0181	.0924
15	1.6766		.4784	.0181	.0187	.0181	.1109
16	1.5089		.4477	.0179	.0187		.1109
17	1.5592	.0175	.4119	.0187	.0187	.0181	.1109
18	.0181	.0183		.0185		.0181	.0185
19	.0181		.0181	.0187		.0185	.0187
20	.0183	.0187	.0362	.0187		.0185	.0187
21		.0189	.0189	.0185	.0177	.0187	.0185
22		.0189		.0187	.0177	.0189	.0185
23		.0187	.0187	.0185	.0177	.0377	.0185
24	.0187		.0189		.0189		.0189
Max	1.869	1.9404	.5552	.0187	.2195	.0377	.1109
Min	.0181	.0175	.0181	.0179	.0177	.0181	.0185
Avg	.6301	.6931	.1660	.0185	.0340	.0237	.0456

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 201 / 11 KV Rasai Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0191			
2				.0191			
3				.0191	.0381		
4				.0191			
5				.0191			
6				.0191	.0381		.0191
7	.0572		.0191	.0191	.0381	.0191	.0191
8	.0572				.2641		
9	.0572	.0191					.0191
10	1.3769	1.1736		.0191	.0381		.132
11	1.6766	1.5939	1.2449	.0191	.0191		
12	1.829	1.6617	1.8296	.0191	.0191	.0191	.1478
13		1.6461			.0191	.0191	
14	2.0005	1.5604	1.6032	.0191			
15	2.1338	1.387	1.6221		.0191		
16		1.1443	1.6221	.0191	.0191		
17	1.6766	1.1488	1.5466		.0191		.1254
18	.0191	.0191	1.3253	.0381	.0191		.0191
19	.017		.0191			.0381	.0191
20	.017		.0191	.0381			.0191
21		.0191	.0191			.0381	.0191
22		.0191	.0191		.0191		.0191
23			.0191	.0381		.0381	.0191
24	.0572		.0191	.0191		.0191	
Max	2.1338	1.6617	1.8296	.0381	.2641	.0381	.1478
Min	.017	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.8443	.9494	.7805	.0227	.0438	.0272	.0481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 202 / 11 KV Tisangi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0791			
2				.0648			
3				.0648	.0953		
4				.0819			
5				.08			
6				.0949	.1905		.1905
7	.1905			.1235	.2096		.3048
8	.2286			.1677	.4954		.2858
9	.2477	.1658	.2439	.1562			.2477
10	2.4196	1.6956		.1543	.2286		.3429
11	2.4863	2.1296	2.1529	.1829	.1898		
12	1.9052	2.1491	2.3434	.1524	.1875	.1524	.2561
13	2.0005	.061			.1562		
14		2.037	2.1148	.1372	.1562		
15	2.3205	1.8435	1.5623		.1739	.2858	
16		1.4352	2.0576	.1372	.1562		
17	2.1338	1.448	1.9433		.1852		
18	.1524	.208	1.3283	.1905	.2241		.2031
19	.1524		.216			.4191	
20	.2439		.2343	.2477			.2469
21		.1981	.125			.3048	.1875
22		.1486	.1235		.0945		.1235
23			.0937	.1143		.1334	.0914
24	.1334		.0907	.0937		.06	
Max	2.4863	2.1491	2.3434	.2477	.4954	.4191	.3429
Min	.1334	.061	.0907	.0648	.0945	.06	.0914
Avg	1.1242	1.1266	1.0450	.1291	.1959	.2259	.2255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 203 / 11 KV Shenawade AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.5548			
2				.5201			
3				.5144	.0191		
4				.5087			
5				.5426			
6				.6516			.0191
7			1.3336	.8059	.0191	.0191	.0191
8					.0191		
9		.0166		.0191			.0191
10		.0166		.6859	.4578		.0191
11		.0177	.0191	.8383	.4458		
12		.0179	.0191	1.0669	.3814		.0191
13		.0191			.3944		
14			.0191	1.2955	.3467		
15			.0191		.2883	.2374	
16			.0191	1.2193	.2401		
17			.0191		.2058		.0191
18	.0191	.0191	.0191	.0191	.0191		.0191
19	.0191		.0191			.0191	.0191
20	.0191		.0191	.0191			.0191
21		.0191	.0191			.0191	.0191
22		.724	.0191		.0191		.0191
23			.5721	.0191		.0191	.1372
24	.0191		.7621	.583		.0191	
Max	.0191	.724	1.3336	1.2955	.4578	.2374	.1372
Min	.0191	.0166	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.1063	.2056	.5802	.2197	.0555	.0289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 204 / 11 KV TISANGI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.0191
Max	.0191
Min	.0191
Avg	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 205 / 11 KV RASAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0347			
2				.0351			
3				.0343	.0381		
4				.0347			
5				.0514			
6				.0686	.0754		.0566
7	.0754		.0953	.0678	.0943	.0762	.0747
8	.112			.0838	.0943		
9	.1132	.0655		.0686			.0943
10		.9221		.0678	.0943		.0943
11		1.2378	.8309	.0514	.0739		
12	1.1812	1.2742	.9774	.0305	.0549	.056	.0739
13		1.2763			.0358	.0566	
14	1.448	1.2407	1.0056	.0343	.0362		
15	1.7147	.0509	.9709		.0543		
16		.6859	.9816	.0305	.0716		
17	1.3717	.7628	.8669				.0895
18	1.3336	.1334	.7716	.0914	.1143		.1086
19	1.1603		.104			.1307	.1075
20	.0983		.1372	.112			.1254
21		.0762	.104			.112	.1086
22		.0572	.0686		.0953		.0701
23			.0514	.0377		.0373	.0532
24	.0554		.0305	.0514		.0381	
Max	1.7147	1.2763	1.0056	.112	.1143	.1307	.1254
Min	.0554	.0509	.0305	.0305	.0358	.0373	.0532
Avg	.7876	.6486	.4997	.0548	.0717	.0724	.0881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 206 / 11 KV SHENAWADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0152			
2				.0191			
3				.0152	.0191		
4				.0154			
5				.0151			
6				.0305	.0381		.0381
7	.0381		.0335	.061	.0381	.0686	.0381
8	.0762			.0617	.0572		
9	.0953	.0332		.0594			.0381
10	.0762	.0332		.061			.0381
11	.0305	.0648	.0381	.0339	.0309		
12	.0305	.0492	.0381	.0343	.0457		
13		.0486			.0309		
14	.0312		.0381	.0347	.0312		
15	.0305		.0381		.0305	.0381	
16			.0381	.0343	.0474		
17	.032		.0381				.0457
18	.0305	.1143	.061	.0381	.1143		.0633
19	.0328		.0753			.0953	.0762
20	.0648		.0903	.0572			.0937
21			.0617			.0953	.0762
22		.0762	.0463		.0343		.0457
23			.0305	.0381		.0381	.0312
24	.0191		.0152	.0152		.0156	
Max	.0953	.1143	.0903	.0617	.1143	.0953	.0937
Min	.0191	.0332	.0152	.0151	.0191	.0156	.0312
Avg	.0452	.0599	.0459	.0355	.0431	.0585	.0531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 207 / 11 KV KARVIIR EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0179			
2				.0183			
3				.0181	.0191		
4				.0179			
5				.0177			
6				.0181	.0191		
7	.0191		.0191	.0179	.0762	.0191	.0191
8	.0191			.0181	.0191		
9	.0191	.0497		.0179			.0351
10	.0191	.0671		.0362	.0191		.0351
11	.0381	.0732	.0377	.0381	.0366		
12	.0572	.0716	.056	.0572	.0554	.0358	.0514
13		.0354			.0549	.0347	
14	.0572	.0354	.0537	.0381	.0724		
15	.0762	.0358			.0537	.0354	
16		.0362	.0754	.0572	.0183		
17	.0762	.0358	.0377		.0179		.0179
18	.0762	.0381	.0358	.0189	.0191		.0181
19	.0678		.037			.0191	.0179
20	.0678		.0366	.0189			.0181
21			.0362			.0191	.0177
22		.0191	.0324		.0191		.0179
23			.0181	.0191		.0191	.0177
24	.0191		.0191	.0177		.0191	
Max	.0762	.0732	.0754	.0572	.0762	.0358	.0514
Min	.0191	.0191	.0181	.0177	.0179	.0191	.0177
Avg	.0471	.0452	.0381	.0257	.0357	.0252	.0242

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 201 / 11 KV Shiye Ag Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0655		.0819	***	1.6221	1.9989	
2	.0655		.0819	2.1068	1.6221	1.9662	
3	.0655		.0819	2.1285	1.6221	1.9662	
4	.0655		.0819		1.6712	2.0481	
5	.0655		3.1824		1.9006	2.1956	
6	.0655		.0819		1.9989	2.3266	
7	.0655		.0819		2.5396	2.6216	
8	.0655		.0819		2.6871	2.6216	
9	.0655	.0819	.0819	.0983	.0983	.0819	.0983
10	2.6216	.0914	2.5724	.0983	.1097	.0164	2.13
11	3.2769	3.1824	3.2278		.1307	.0164	
12	3.3589	3.5101	2.982		.112	.0164	1.9334
13	3.1131	3.5101	2.9492		.112	.0164	2.13
14	3.1131	3.0727	2.9001		.112	.0983	1.1142
15	3.1131		2.9165		.112	.0983	1.3108
16	3.1131		2.8509		.1097	.0983	1.3763
17	3.0476		3.0994		.112	.0983	2.0972
18	.0819	.0819	.112	.1147	.0983	.1494	.1147
19	.0819	.0819	.112	.1147	.0983	.1494	.1147
20		.0819	.112	.1147	.0819	.1494	.1147
21		.0819	.112	.1147	.0819	.1494	.1147
22		.0819	.112	.1147	.0819	.1494	.1147
23		1.6385	2.0538	1.491	1.6385	.112	.1147
24	.0655		.0819	2.0485	1.5893	2.0317	
Max	3.3589	3.5101	3.2278	21.2155	2.6871	2.6216	2.13
Min	.0655	.0819	.0819	.0983	.0819	.0164	.0983
Avg	1.2788	1.2914	1.2513	2.4800	.8476	.8823	.9199

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 202 / 11KV Water Supply -Shiye  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8682	.8238	.7712	.7842	.6733	.8238	
2	.8682	.8063	.7712	.7922	.6733	.8238	
3	.8505	.7888	.7712	.7922	.6733		
4	.8505	.7888	.7712		.4561	.8238	
5	.8682	.8063	.8413		.691	.9114	
6	.8859	.8238	.9114		.691	.9114	
7	1.0454	.8589	1.1919		.9214	.9816	
8	1.701	1.2971	1.858		1.4529	1.2094	
9	2.1085	1.9982	2.0376	.7461	2.0199	1.7528	2.3137
10	1.9281	2.5393	2.2325	.7362		1.9806	2.1033
11	1.8404	2.3899	2.2148	.631	2.4832	2.1033	
12	1.8404	2.0538	2.4806	.6135	2.0538	1.9631	1.9806
13	1.7878	1.8671	2.2148	.631	1.5684	1.9982	
14	1.5775		2.1262	.6661	2.3525	1.7528	2.2786
15	1.858		2.3034		2.3899	2.226	2.3838
16	1.9281		2.3034	.5258	2.3339	2.4539	2.489
17	1.893	2.2961	2.0911		2.2965	2.0683	1.5775
18	.964	2.2786	1.8858	.5316	2.1384	1.9791	2.6755
19	1.6289	1.4198	1.475	.5493	1.7703	1.2696	1.7541
20	.8764	1.2269	1.4377	.6201	1.1218	1.0456	1.3289
21	.8413	.9816	1.1203	.7265	.9465	1.0082	.9391
22	.8238	.8063	1.0082	.7442	.8939	1.0751	.9214
23	.8413	.7888	.9335	.7265	.8589	.9242	.8505
24	1.0717	.8238	.7888	.7842	.6733	.8413	
Max	2.1085	2.5393	2.4806	.7922	2.4832	2.4539	2.6755
Min	.8238	.7888	.7712	.5258	.4561	.8238	.8505
Avg	1.3228	1.3554	1.5225	.6824	1.3971	1.4316	1.8151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 203 / 11KV TOP II AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.407	.407	.4024	2.1216	1.5261	1.4754	
2	.407	.407	.4024	2.1216	1.6278	1.643	
3	.407	.407	.4024	2.1216	1.6617	1.7101	
4	.407	.407	.4024	***	1.6617	1.7772	
5	.407	.407	.4024	2.1582	1.8652	1.8778	
6	.407	.407	.4024	2.2032	1.9669	1.9433	
7	.407	.407	.4024	2.5206	2.4926	2.2634	
8	.407	.407	.4024		2.4587	1.1736	
9	.407	.407	.4024	2.1195	2.3739	.8139	.1865
10	.4024	.439	.407	1.56		.6783	.1865
11	2.3472	2.3228	2.2891	.39	.4108	.39	
12		2.7435		.407	.4108	.39	.8478
13	1.9616	2.8193	2.2043	.407	.4251	.39	1.1022
14	2.431		2.2891		.4481	.407	1.2209
15	2.4756		1.6787	.407	.4481	.39	1.2548
16	2.4587		2.0348	.39	.4481	.39	1.1361
17	2.4078	1.5927	2.5766	.407	.4481	.1865	1.1869
18	2.1195	1.6766	.5975	.39	.4024	.2054	1.2548
19	.407	.4024	.439	.407	.4024	.2054	.1865
20		.4024	.439	.407	.4024	.2054	.1865
21		.4024	.439	.407	.4207	.2054	.1865
22	.4239	.4024	.439		.4024	.2054	.1865
23	.5426	.4024	.4481	.407	.4024	.2195	.1865
24	.6105	.407	.4024	.4481	.407	.4024	
Max	2.4756	2.8193	2.5766	21.3626	2.4926	2.2634	1.2548
Min	.4024	.4024	.4024	.39	.4024	.1865	.1865
Avg	1.0596	.8417	.8828	2.0554	1.0223	.8145	.6649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039]

BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2614	.2614	.2241	.2614	.2427	
2	.2801	.2427	.2427	.2241	.2427	.2427	
3	.2801	.2427	.2427	.2241	.2427	.2427	
4	.2801	.2427	.2614	.2241	.2427	.2427	
5	.3174	.2614	.2801	.2427	.2614	.2614	
6	.3361	.2987	.2987	.2801	.2801	.2801	
7	.3361	.2987	.3361	.2801	.2614	.2801	
8	.2801	.2241	.2614		.2801	.2614	
9	.2614	.2987	.2801	.2801	.2427	.2614	.2987
10	.2614		.2241	.1867	.2801	.2614	.2801
11	.2241	.2427	.2241	.2054	.2801	.2241	.2614
12	.1867	.2801	.2987	.1307	.2801		.2241
13	.2241	.2801	.2801	.2241	.1867	.2614	.2241
14	.1867	.2801	.2801	.2241		.2801	.2054
15	.2054		.2801	.2054		.2427	.2241
16	.2241		.2987	.1867			.2241
17	.2614		.2987	.2054		.2987	.2427
18	.2427	.3361	.3174	.2614	.2614	.3734	.2987
19	.3361	.3921	.3361	.3174	.2987	.3761	.3361
20		.3921	.3734	.3734	.3734	.3921	.3921
21		.3734	.3734	.3547	.3734	.3921	.3547
22	.3921	.3361	.3734	.2987	.3361	.3547	.3547
23	.2987	.3174	.3361	.2987	.2987	.2987	.2987
24	.3361	.2801	.2987	.2241	.2801	.2614	
Max	.3921	.3921	.3734	.3734	.3734	.3921	.3921
Min	.1867	.2241	.2241	.1307	.1867	.2241	.2054
Avg	.2750	.2941	.2941	.2468	.2782	.2878	.2813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 202 / 11 KV NIGAWA GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.1509		.2241	.1867	.1886	.1698
2	.2286	.1494		.2241	.1886	.1886	.168
3	.1905	.1494		.2241	.1886	.1509	.1372
4	.1905	.1867		.2218	.1886	.1509	.1294
5	.2286	.1886		.2241	.1867	.1886	.1867
6	.2641	.2641		.2241	.2614	.2263	.2402
7	.2641	.2263		.2801	.2241	.2641	.2054
8	.2241	.2452		.2614	.2263	.2641	.2427
9	.208		.2075	.2534	.1905	.2402	.2241
10	.2229	.2801		.1848	.1886	.2772	.2033
11	.1907	.1867	.2641	.1848	.2096	.2587	.2427
12	.2279	.2987	.2241	.1829	.1905	.2241	.1886
13	.1949	.2241	.2241	.1886	.1886	.168	.1886
14	.1734	.2241	.1886	.1867		.1867	.2452
15	.1886	.2054	.2263	.1867	.2096	.2614	.2241
16	.1907	.2218	.2241	.1867	.2641	.2801	.2263
17	.2241	.2427	.2772	.2241	.2195	.2477	.2241
18	.2614	.2641	.2772	.2641	.2614	.2829	.2614
19	.2801	.2858	.2957	.2987	.2987	.2667	.2987
20	.3734	.3395	.3292	.3018	.3361	.3048	.3361
21		.3048	.3326	.2987	.2987	.2829	.3361
22	.3018	.3206	.2772	.3018	.2614	.2286	.2427
23	.2241	.2667	.2033		.2241	.1677	.2054
24	.4676	.1886	.2263	.2218	.2263	.1867	
Max	.4676	.3395	.3326	.3018	.3361	.3048	.3361
Min	.1734	.1494	.1886	.1829	.1867	.1509	.1294
Avg	.2412	.2354	.2518	.2326	.2269	.2286	.2229



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 204 / 11KV AMBEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.4588		.9717	.0857	.0762	.0762
2	.1143	.4694		.9282	.0857	.0762	.0762
3	.1143	.6226		.9393	.0857	.0762	.0762
4	.1143	.852		.9282	.0857	.0572	.0762
5	.1143	.9389		.9717	.0857	.0572	.0762
6	.1143	.9175		1.2803	.0857	.0762	.0747
7	.1143	1.3413		2.9473	.0857	.0762	.0754
8	.0953	1.4083		1.7604	.0857	.0572	.0762
9	.0953	.0676	.0857	.1334	.0762	.0526	.0686
10	.1132	.0676		1.9006	1.1317	.6401	.6554
11	.1143	.0667	.0857	2.13	1.3336	.8421	.5898
12		.0518	.0857	2.13	1.5242	.9175	.5571
13	.1143	.0518	.0857	2.1956	1.5089	.7449	.57
14	.1143	.0511	.0857	1.8842		.8002	.57
15	.1143	.0518	.0686	2.0645	.7621	.8962	.5765
16	.0754	.0747	.0686	1.9989	.8299	.9602	.5571
17	.0857	.0693	.0541	.7865	.7293	1.1203	.4858
18	.0857	.0762	.0676	.0857	.0762	.0754	.04
19	.0686	.0754	.0648	.0857	.0762	.0762	.0594
20	.0686	.0953	.0533	.0857	.0762	.0857	.0518
21		.1143	.0667	.0857	.0762	.0876	.0526
22	.0686	.0943	.0667	.0857	.0762	.0867	.0518
23	.0686	.7621	.9717		.0762	.0693	.0518
24	.1143	.0686	.9526	.9717	.0857	.0762	.0739
Max	.1143	1.4083	.9717	2.9473	1.5242	1.1203	.6554
Min	.0686	.0511	.0533	.0857	.0762	.0526	.04
Avg	.0998	.3686	.1909	1.1892	.3967	.3368	.2341

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 205 / 11 KV Kerli Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1365			.1372	.8642	.2947
2	2.1365			.1372	.8745	.3086
3	2.1365			.1372	.8642	.3222
4	2.1195			.1372	.8642	.3315
5	2.1795			.1372	1.012	.3353
6	2.3739			.1372	1.1469	
7	2.6452			.5243	1.3435	.2452
8	2.7349			.6371	1.4255	.2477
9						.2477
10	2.4478					
11	3.155		2.3594			.0514
12	3.4894		2.4905			
13	3.2388		2.3922			
14	3.2861	.9762	2.431			
15	3.0693	.8259	2.2611			
16	2.8622	2.1776	2.2466			
17	2.7496	2.5339	2.1714			
23		.4527		.6478	.285	.1111
24	2.4418		.4287	.1372	.8802	.3086
Max	3.4894	2.5339	2.4905	.6478	1.4255	.3353
Min	2.1195	.4527	.4287	.1372	.285	.0514
Avg	2.6590	1.3933	2.0976	.2770	.9560	.2549

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 206 / 11 KV VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.3772		.7468	.5658	.679	.6859
2	.7545	.3734		.7468	.5601	.6852	.6859
3	.7545	.3429		.7468	.5601	.679	.6478
4	.7545	.3734		.7392	.5601	.679	.6097
5	.7922	.3734		.7468	.679	.679	.7621
6	1.0082	.5281		.8215	.8299	.9335	.8299
7	.9979	.4481		.924	.8962	.924	.8383
8	.9877	.5658		.9335	.9054	.961	.8299
9	.9054		.8962	.8238	.9145	.8871	.8215
10	.9313	.9511		.8688	.9054	.8501	.8215
11	.8688	.905	.7468	.7164	.9526	.8589	.9054
12	.9511	.9511	.8962	.7164	.9907	.8501	.8215
13	.8669	.9511	.9054	.7682	.8299	.7392	.7545
14	.8131	.9511	.8215	.7316		.7392	.8299
15	.7468	.9877	.8299	.7316	.8383	.8775	.7922
16	.7796	1.086	.8215	.5792	.7545	.7164	.7545
17	.7545	.9511	.815		.7282	.7087	.724
18	.7468		.8596	.8962	.7282	.8688	.7164
19	.9054	.9709	.9511	.8299	.7762	.9054	.8131
20	.9709	.9335	.8871	.9054	.8962	.9054	.8501
21		.9054	.8589	.8215	.8299	.8383	.8299
22		.9907	.7468	.8299	.7922	.7922	.8589
23		.9054	.7545		.7545	.7621	.7545
24	.8002	.6722	.7621	.7468	.679	.679	.6722
Max	1.0082	1.086	.9511	.9335	.9907	.961	.9054
Min	.7468	.3429	.7468	.5792	.5601	.679	.6097
Avg	.8498	.7498	.8368	.7896	.7794	.7999	.7754

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 207 / 11 KV Nigave Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.9389		.8025	.1029	.0953	.1097
2	.1143	.9389		.7716	.1029	.0953	.1109
3	.1143	.9389		.7811	.1029	.0953	.112
4	.1143	1.0395		.8124	.1029	.1143	.1132
5	.1143	1.0159		.9061	.1029	.1334	.1132
6	.1334	1.4419		1.0936	.1029	.1524	.1524
7	.1524	2.0119		1.4251	.1029	.1524	.1509
8	.0953	2.2939		1.6194	.1029	.1334	.1334
9	.1524	.1132	.1029	.1143	.1143	.112	.1372
10	.1509	.1132		1.278	1.6975	1.1469	1.1797
11	.1463	.0943	.0857	1.704	1.5089	1.4746	1.0059
12	.1109	.112	.0857	1.6385	1.7147	1.6575	1.0059
13	.112	.0754	.1029	1.5074	1.7337	1.6004	1.0159
14	.1307	.0924	.1029	1.5074		1.6194	1.0059
15	.132	.0934	.1029	1.643	1.3717	1.6194	1.2071
16	.112	.1307	.1029	1.7436	1.5604	1.5813	1.4419
17	.1029	.1509	.0943	1.0486		1.5089	.8421
18	.1372	.0953	.1132	.1029	.1524	.1132	.0995
19	.1372	.132	.1307	.1029	.1524	.1143	.116
20	.1029	.1524	.1307	.1029	.1715	.1524	.1311
21		.132	.1307	.1029	.1715	.1334	.1478
22	.1029	.1524	.1307	.1029	.1715	.132	.1463
23	.3932	.9431	.759		.1524	.1334	.1307
24	.1143	.9175	1.0669	.8025	.1029	.0953	.1132
Max	.3932	2.2939	1.0669	1.7436	1.7337	1.6575	1.4419
Min	.0953	.0754	.0857	.1029	.1029	.0953	.0995
Avg	.1344	.5883	.2161	.9441	.5272	.5903	.4467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 208 / 11 KV Panhala Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4481		.4572	.4108	.4904	.4904
2	.5281	.4527		.4572	.415	.4904	.5093
3	.5335	.4481		.4572	.4108	.4527	.547
4	.5716	.5228		.4572	.415	.4527	.5658
5	.5335	.5281		.4527	.4715	.4904	.6668
6	.5658	.5658		.5281	.5281	.5975	.7167
7	.5658	.5658		.6979	.6535	.7095	.6859
8	.6722	.6161		.6348	.6348	.679	.5847
9	.7545	.5601	.6535	.4344	.6602	.7095	.5658
10	.7811	.6722		.4755	.5906	.6722	.5658
11	.8676	.7468	.7545	.5792	.5281	.6348	.6224
12	.7655	.7577	.7545	.5853	.6979	.6161	.6036
13	.7621	.7023	.7167	.6219	.6478	.6161	.5281
14	.743	.7095	.7095	.1387		.6161	.5281
15	.7545	.7842	.7545	.1494	.679	.6348	.6036
16	.7621	.7577	.7167	.6722	.6767	.6348	.6348
17	.724	.6722	.7468	.679	.6219	.6413	.6348
18	.6859	.7356	.7468	.6602	.7023	.7049	.6468
19	.724	.8383	.7468	.6979	.7468	.7621	.7095
20	.8029	.7392	.7468	.679	.7842	.6859	.7468
21		.724	.5175	.6908	.7468	.724	.7095
22	.6668	.7167	.6283	.679	.6722	.5716	.6283
23	.4108	.5906	.5415		.5228	.4904	.499
24	.7335	.4481	.5041	.4527	.4527	.4854	.462
Max	.8676	.8383	.7545	.6979	.7842	.7621	.7468
Min	.4108	.4481	.5041	.1387	.4108	.4527	.462
Avg	.6714	.6376	.6826	.5364	.5943	.6068	.6023

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 201 / 11 kv Yavaluj Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8288		.2515	.0166	.0177		.0166
2	.8619		.2713	.0166	.0177		.0164
3	.8619		.2949	.0166	.0177		.0166
4	.8048		.3315	.0166	.0177		.0166
5	1.0898		.3932	.0166	.0175		.0166
6	1.1736		.4641	.0166	.0175		.0168
7	1.6575		.5079	.0166	.0175		.0164
8	1.704		.5365	.0164	.0175	.0162	.0166
9			.0164	.0166	.0175	.0161	.0166
10		.0166	.0164	.7293		.2949	.1029
11		.0166	.0166	1.0395	.8102	.3812	.1543
12		.0166		1.1065	.7665	.4424	.1227
13		.0166		1.1736	.8335	.4424	
14				1.1233	.6922	.4641	.0351
15		.0166		1.17	.5545	.4144	.0351
16		.0168	.0166	1.0513	.5274	.4359	.0351
17			.0166	.8478	.4285	.3978	.0351
18			.0164	.0171		.0166	.0175
19		.0168	.0164	.0173	.0162	.0164	.0177
20	.0163		.0164	.0177	.0167	.0166	.0177
21		.0168	.0166	.0177	.0165	.0164	.0177
22		.0166	.0166	.0177	.0165	.0166	.0177
23		.213	.0166	.0177	.0162	.0166	.0351
24	.0164		.2458	.0166	.0177	.0165	.0164
Max	1.704	.213	.5365	1.1736	.8335	.4641	.1543
Min	.0163	.0166	.0164	.0164	.0162	.0161	.0164
Avg	.9015	.0363	.1739	.3547	.2214	.2012	.0352

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 202 / 11 KV YEVALUJ VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1595	.1267	.124	.1254	.1294		.1063
2	.1433	.1097	.1075	.1254	.112		.0886
3	.1254	.1086	.1075	.1109	.112		.1075
4	.1254	.1612	.1075	.1267	.112		.1254
5	.156	.1595	.1433	.1433	.1463		.1433
6	.1772	.1829	.1791	.1433	.1829		.181
7	.1772	.2126	.1791	.1254	.181		.1991
8	.1791	.1949	.197	.1433	.1629	.1783	.197
9			.197	.1075	.1791	.18	.197
10	.198	.197	.197	.1075		.1791	.1772
11	.216	.1991	.197	.124	.2004	.1791	.1772
12	.1639	.1629	.197	.1052	.216	.1612	.1595
13		.1629	.2149	.1052	.162	.1448	.1063
14		.1612	.197	.1063	.162	.1402	.1433
15		.1433	.1791	.1075	.162	.1448	.1433
16	.1612	.1433	.1791	.1075	.162	.1417	.1433
17	.1949	.1433	.1791	.1075	.162	.181	.1433
18	.197	.1254	.181	.1254		.1791	.1433
19	.1791	.1254	.1791	.1629	.2341	.197	.1791
20	.197	.2149	.2149	.1829	.1962	.181	.197
21		.2353	.1772	.1848	.2018	.1791	.181
22	.1595	.197	.1595	.1867	.1835	.1448	.1663
23	.1433	.1791	.1402	.1478	.1501	.1254	.1294
24	.1612	.124	.1254	.1267	.1478	.1275	.1075
Max	.216	.2353	.2149	.1867	.2341	.197	.1991
Min	.1254	.1086	.1075	.1052	.112	.1254	.0886
Avg	.1692	.1639	.1691	.1308	.1663	.1626	.1518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 203 / 11Kv Satarde sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164		.0162	.2218	.1715		
2	.0166		.0162	.2402	.1543		.0166
3	.0166		.0162	.2743	.1543		
4	.0166		.0162	.2743	.1543		.0166
5	.0166		.0162	.2926	.1543		
6	.0164		.016	.3109	.1543		.0166
7	.0164		.0164	.3077	.2572		.0166
8	.0164		.0162	.6447	.3944	.3461	.0168
9				.0175	.0175	.0162	.016
10	2.7006		1.0402	.0175			.1372
11	3.01		1.3094		.0162	.0162	.1715
12	2.4506		1.3927		.0166		.1417
13	2.784		1.2803			.0166	
14	2.8673						.0701
15	3.1327		1.2125		.0163		.0876
16	2.6852		1.1633	.0175	.0165	.0164	.1052
17	2.4863		1.065	.0173	.0162		.0876
18	.0164		.8848	.0173			.0177
19	.016		.0166	.0173	.0182	.0166	.0177
20	.016	.0164	.0164	.0173	.0171	.016	.0177
21		.0166	.0166	.0175	.0182		.0177
22		.0166	.0164	.0175	.0162		.0179
23			.1658	.2058	.1299	.0162	.0177
24	.0166		.0164	.1966	.2058	.1315	.0166
Max	3.1327	.0166	1.3927	.6447	.3944	.3461	.1715
Min	.016	.0164	.016	.0173	.0162	.016	.016
Avg	1.1157	.0165	.4421	.1645	.1050	.0658	.0512



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 204 / Majgaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185		.0187	.3224	.12		.1433
2	.0185			.4239	.1029		.1254
3	.0185		.0187	.4477	.104		.1629
4	.0187		.0185	.5853	.1029		.1772
5	.0187		.0183	.7682	.1372		.197
6	.0189		.0187	.8954	.1543		.2218
7	.0185		.0179	1.2489	.2058		.2195
8	.0187		.0185	1.6632	.2572	.211	.2561
9				.0187	.0173	.0165	.0185
10	2.8987					.0187	
11	3.2785		.8145		.0162	.0185	.0175
12	3.0823		1.0745		.0171	.0185	.0177
13	3.4483		1.829		.0173	.0185	.0177
14	3.5063		2.3712		.0165	.0166	.0177
15	3.8683		2.5606	.0175	.0162	.017	.0175
16	3.8504		2.5339	.0175	.0162	.0171	.0175
17	3.6355		2.5701		.0165	.0187	.0175
18	.0187	.3224	2.2028	.0175		.0185	.0177
19	.0187	.3582	.0162	.0177	.0163	.0179	.0177
20	.0167	.0183	.0187	.0177	.0163	.0187	.0177
21		.0185	.0185	.0175	.0165	.0187	.0177
22		.0181	.0185	.0177	.0167	.0185	.0177
23		.0179	.1867	.1372	.1024	.0914	.0177
24	.0189		.0179	.2218	.1372	.1318	.1494
Max	3.8683	.3582	2.5701	1.6632	.2572	.211	.2561
Min	.0167	.0179	.0162	.0175	.0162	.0165	.0175
Avg	1.3895	.1256	.7792	.3809	.0738	.0404	.0826

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 205 / Majgaon Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.1265	.1781	.1802	.1867		.1296
2	.176	.1296	.1638	.1823	.1848		.1326
3	.1823	.1457	.1619		.1848		.1638
4	.208	.1475	.1619	.1943	.2033		.176
5	.2241		.1739	.208	.2012		.1966
6	.2267		.1898	.2241	.2195		.2401
7	.2056		.1966	.2105	.2378		.2241
8	.213		.208	.208	.2353	.2881	.3077
9		.0648		.2056	.2303	.2501	.2401
10	.2483	.064	.2372		.2701		.2328
11	.2732	.096	.253		.2521	.2267	.2328
12	.2597	.0983	.253		2.6563	.2401	.2507
13	.2881	.128	.2561		.2569	.2321	.2686
14	.2667	.112	.2372		.255	.2294	.2149
15	.2914	.1475	.2561	.2658	.2368	.208	.2149
16	.2622	.16	.2561	.2658	.2521	.2241	.2328
17	.2591	.1966	.2429		.2752	.2591	.2686
18	.253	.192	.2688	.3224		.2753	.2896
19	.2812	.2241	.3005	.394	.3628	.3041	.3475
20	.3601	.2846	.3563	.3761	.3278	.3361	.3292
21		.3201	.3041	.0177	.2989	.3239	.3361
22	.3163	.2622	.2561	.0177	.2777	.253	.2801
23	.2372	.2429	.2155	.2241	.1821	.2241	.2402
24	.2105	.16	.1898	.1781	.1867	.1407	.144
Max	.3601	.3201	.3563	.394	2.6563	.3361	.3475
Min	.176	.064	.1619	.0177	.1821	.1407	.1296
Avg	.2471	.1651	.2312	.2162	.3467	.2509	.2372

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 206 / 11 KV Satarde Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3045	.2126	.2172	.2149	.1867		.1949
2	.2686	.2149	.2149	.2328	.1867		.1991
3	.2303	.2149	.2149	.1991	.1867		.2328
4	.2279	.2328	.2328	.197	.2218		.2328
5	.2865	.2507	.2686	.2715	.2561		.2715
6	.3582	.3045	.3258	.3258	.2926		.2865
7	.362	.333	.3077	.3403	.3258		.3761
8	.362	.3224	.3403	.3582	.3439	.3529	.3224
9		.3045	.3224	.3224	.3224	.3753	.3403
10	.4087	.3224	.3403	.3258		.3224	.3224
11	.3781	.3258	.3045	.3012	.3241	.2865	.3224
12	.3421	.3224	.3403	.2865	.3421	.2686	.2629
13	.3757	.2896	.3582	.2481	.3061	.2149	.2481
14	.3961		.3224		.3119	.2507	.2658
15	.3825		.3045		.3278	.3292	.2658
16		.4344	.2865	.2454	.3381	.2865	.2686
17		.3982	.3582	.2279	.3241	.2328	.2507
18		.3801	.3658	.2686		.3258	.2865
19		.3982	.362	.3582	.4501	.4119	.362
20	.4501	.4298	.4163	.3801	.4087	.394	.3921
21		.4207	.3982	.3734	.4141	.4119	.3881
22	.3045	.3258	.3258	.3361	.3421	.3155	.3326
23	.2686	.3258	.2686	.2241	.2855	.2715	.2614
24	.3012	.2103	.2378	.2149	.2241	.244	.2149
Max	.4501	.4344	.4163	.3801	.4501	.4119	.3921
Min	.2279	.2103	.2149	.197	.1867	.2149	.1949
Avg	.3338	.3170	.3098	.2842	.3055	.3114	.2875

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 201 / 11KV BORGOAN VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0166	.0175	.0175	.0187	.0168	.0351
2	.0191	.0166	.0175	.0181	.0187	.0168	.0351
3	.0191	.0166	.0175	.0183	.0373	.0168	.0351
4	.0381	.0168	.0173	.0179	.056	.0168	.0351
5	.0572	.0339	.0351	.0347	.056	.0168	.0351
6	.0572	.0526	.0526	.0526	.056	.0343	.0526
7	.056	.0526	.0526	.0526	.056	.0526	.0526
8	.056	.0526	.0526	.0509	.056	.0526	.0526
9	.0526	.0526	.0526	.0532	.056	.0526	.0526
10	.0526	.0526	.0509	.0514	.0526	.0526	.0509
11	.0526	.0526	.0509	.0514	.0526	.0526	.0509
12	.0526	.0526	.0497	.0514	.0526	.0526	.0339
13	.0526	.0526	.0509	.0526	.0526	.0526	.0347
14	.0526	.0526	.0509	.0526	.0526	.0526	.0335
15	.0526	.0526	.0509	.0526	.0526	.0526	.0339
16	.0526	.0526	.0526	.0526	.0526	.0526	.0526
17	.0526	.0526	.0526	.0526	.0526	.0526	.0526
18	.0526	.0526	.0532	.0526	.0526	.0526	.0532
19	.0709	.0526	.0526	.056	.0709		.0526
20	.0709	.0701	.0701	.056	.0709		.0709
21		.0526	.0532	.056	.0709		.0509
22		.0526	.0347	.056	.0526		.0354
23			.0175	.0373	.0343		.0175
24	.0381		.0175	.0175	.0373	.0343	.0351
Max	.0709	.0701	.0701	.056	.0709	.0526	.0709
Min	.0191	.0166	.0173	.0175	.0187	.0168	.0175
Avg	.0498	.0460	.0426	.0444	.0509	.0413	.0435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 202 / 11KV KARANJFEN AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.0162	.0175	.0175		.12	.0526
2	1.0288	.0162		.0175		.12	.0526
3	1.0117	.0162	.0173	.0181		.12	.0526
4	1.0117		.0175	.0177		.12	.0526
5	1.0802		.0175	.0175		.1372	.0526
6	1.166		.0175	.0175		.1753	.0526
7	1.3203		.0175	.0351		.2279	
8	1.8519		.0175	.0171		.2686	
9	.0343		.0175	.0175	.0187	.0166	
10	2.1719	.9816	.7537	.0171	.0171	.0175	.0168
11	2.2805	1.1393	.9835	.0171	.3189	.0175	.0175
12	2.2624	1.1043	1.0174	.0171	.0171	.0175	
13	2.2081	.9816	1.0174		.0171	.0175	.0177
14	2.2081	.9991	.9835		.0171	.0175	
15	2.2081	1.0166	.9835		.0171	.0175	.0177
16	2.2081	.8764	.9835		.0171	.0175	.0177
17	2.1538	.7011	.9556	.0175	.0171	.0175	.0175
18	.0168	.0175	.0339	.0175	.0171	.0175	.0177
19	.0168	.0175	.0339	.0187	.0171		.0177
20	.0166	.0175	.0339		.0171		.0177
21		.0175	.0177	.0187	.0171		.0177
22		.0175	.0177		.0171		.0175
23			.0177		.0876		.0351
24	.0189		.0175	.0177		.1227	.0526
Max	2.2805	1.1393	1.0174	.0351	.3189	.2686	.0526
Min	.0166	.0162	.0173	.0171	.0171	.0166	.0168
Avg	1.3002	.4960	.3474	.0186	.0420	.0835	.0314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 203 / 11KV PADASALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189		.2804	.2126	.0175	.0166	.0181
2	.0189		.2804	.2103	.0187	.0166	.0175
3	.0189			.2012	.0187	.0166	.0175
4	.0189		.2804	.2103	.0187	.0166	.0175
5	.0189		.2804	.2303	.0187	.0166	.0175
6	.0189		.3506	.2204	.0187	.0168	.0175
7	.0189		.4733	.2804	.0187	.0343	.0175
8	.0189		.5258	.3052	.0187	.0343	.0175
9	.0171	.0166	.0173	.0173	.0187	.0343	
10		.0175	.0177	.2915	.0876	.0351	
11	.0168	.0173		.3258	.0876		
12	.0168	.0173	.0177	.3429	.1052	.0351	
13	.0168	.0173		.4031	.1227	.0351	
14	.0168	.0173	.0175	.4031	.1227	.0351	.1928
15	.0168	.0173	.0177	.4031			.1928
16	.0166	.0173	.017	.1753	.2629		.2204
17	.0166	.0175	.017	.0175	.2835		.2303
18	.0166	.0175	.0164	.0187	.0171	.0175	.0177
19	.0166	.0175	.017	.0187	.0343		.0177
20	.0166	.0173	.017	.0187	.0343		.0175
21		.0175	.0177	.0187	.0343		.0177
22		.0175	.0175	.0187	.0171		.0177
23			.2279	.0187	.0171		
24	.0189		.2804	.2103	.0187	.0171	.0175
Max	.0189	.0175	.5258	.4031	.2835	.0351	.2303
Min	.0166	.0166	.0164	.0173	.0171	.0166	.0175
Avg	.0177	.0173	.1518	.1905	.0614	.0252	.0602

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 204 / 11 Kv Boragaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.333	.1417			
2		.2804	.1227			
3		.2804	.1267			
4		.2804	.1227			
5		.2804	.1267			
6		.3506	.1187			
7		.4382	.1734			
8		.4733	.2279			
9	.4961					
10			.2401		.0876	.1311
11			.3086	.1227	.0701	.0876
12			.2743	.1402	.0876	
13			.2629	.1402	.0876	.0886
14			.2454	.1402	.1052	.0848
15			.2629	.1402	.1052	.0838
16			.2454	.1227	.0876	.0526
17			.0876	.0876	.1402	.0532
23		.1578				
24		.3506	.1402			
Max	.4961	.4733	.3086	.1402	.1402	.1311
Min	.4961	.1578	.0876	.0876	.0701	.0526
Avg	.4961	.3225	.1899	.1277	.0964	.0831

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 205 / 11 KV PADASALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0857	.0876	.0709		.0686	.0701
2	.0953	.0857	.0876	.0701		.0686	.0701
3	.0953	.0857	.0876	.0709		.0686	.0701
4		.0857	.0876	.0709		.0686	.0701
5		.0857	.0876	.0709		.0867	.1052
6		.104	.1227	.1052		.1227	.1402
7		.1402	.1578	.1227	.112	.1595	.1578
8	.0189	.1595	.1753	.1402	.1307	.1772	.1753
9	.0686	.1772	.1928	.1402	.112	.1772	.1753
10		.1402	.1753	.1402	.1052		.1772
11	.1753	.1402	.1357	.1402	.1052	.1402	.1227
12	.1772	.1753	.124	.1402	.1417	.1402	.1017
13	.1772	.1402		.1402	.1595		.1174
14	.1772	.1402	.1227	.1227	.1595		.1417
15	.1949	.1753	.1187	.1052			.1357
16		.1928	.1357		.1772		.1402
17	.1949	.2103	.1402	.1402	.1772		.1753
18	.2126	.1753	.1658	.1753	.197	.1928	.1357
19	.2507	.1928	.1865	.1867	.2715		.2126
20	.2686	.2279	.2035	.1494	.2328		.208
21		.1928	.1928	.1494	.2149		.1696
22		.1402	.1402	.112	.1595		.124
23			.0876	.0747	.0876		.0876
24	.0914		.1052	.0701	.0754	.0686	.0701
Max	.2686	.2279	.2035	.1867	.2715	.1928	.2126
Min	.0189	.0857	.0876	.0701	.0754	.0686	.0701
Avg	.1529	.1479	.1357	.1178	.1541	.1184	.1314



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036]

BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 206 / 11 KV KARANJFEN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1402	.1227	.1086	.112	.1227	.1227
2	.1698	.1227	.1052	.1052	.112	.1227	.1227
3	.1509	.1227	.1052	.0905	.112	.1227	.1227
4	.1509	.1227	.1052	.1267	.112	.1227	.1227
5	.1509	.1227	.1753	.156	.1494	.1402	.1402
6	.2075	.1595	.2103	.2172	.2054	.1772	.1753
7	.2641	.2126	.2804	.2543	.2427	.2126	.2454
8	.2829	.2507	.298	.2454		.2686	.2629
9	.2865	.2686	.298	.2658	.2054	.2865	.2629
10		.2629	.2947	.298	.1949	.2804	.2629
11	.2865	.2629	.2713	.2629	.1949	.2804	.2103
12	.2865	.2629	.2543	.2629	.2686	.2804	.2035
13	.2865	.2629	.2804	.2454	.2865	.2804	.2658
14	.2865	.2629	.2374		.2865	.2629	.2629
15	.2865	.2629	.2347		.2865	.2454	.2658
16	.2865	.2629	.2543		.2865	.3155	.2658
17	.2865	.2629	.2543	.3155	.2865	.3155	.2507
18	.3224	.298	.2486	.3681	.3224	.333	.2374
19	.4344	.3506	.2949	.4294	.4525		.3814
20	.4525	.4031	.3429	.3921	.3982		.3721
21		.3155	.298	.3734	.3439		.298
22		.2629	.2103	.2241	.2149		.2254
23			.1595	.1494	.1595		.1595
24	.2075		.1227	.1052	.1307	.1402	.1402
Max	.4525	.4031	.3429	.4294	.4525	.333	.3814
Min	.1509	.1227	.1052	.0905	.112	.1227	.1227
Avg	.2637	.2389	.2274	.2379	.2332	.2268	.2241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 201 / 11 KV MHASURLI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
17	.1966
Max	.1966
Min	.1966
Avg	.1966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 202 / 11 KV MHASURLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.4108
Max	.4108
Min	.4108
Avg	.4108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 203 / 11 KV SULE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1966
Max	.1966
Min	.1966
Avg	.1966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144122 / 33/11 KV PAT PANHALA

Feeder No / Name : 202 / PATPANHALA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0377
Max	.0377
Min	.0377
Avg	.0377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 201 / 11 KV Salawan Sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.4239
Max	.4239
Min	.4239
Avg	.4239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 202 / 11 KV SAVARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.3052
Max	.3052
Min	.3052
Avg	.3052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 203 / 11 KV VETAVDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2035
Max	.2035
Min	.2035
Avg	.2035



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 204 / 11 KV Salawan Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.4668
Max	.4668
Min	.4668
Avg	.4668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 205 / 11 KV WALOLI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2241
Max	.2241
Min	.2241
Avg	.2241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 206 / Punal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
17	.1966
Max	.1966
Min	.1966
Avg	.1966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 207 / Punal Sawarde Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2801
Max	.2801
Min	.2801
Avg	.2801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 208 / 11 KV Waloli Sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
17	.7373
Max	.7373
Min	.7373
Avg	.7373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 209 / 11 KV VETWADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2241
Max	.2241
Min	.2241
Avg	.2241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 402 / 33 KV NAGRIKA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.4003
Max	1.4003
Min	1.4003
Avg	1.4003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 201 / 11 KV KAKHE AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1219	.1219	.1524	.2896	.3353	.2439
2	.1715	.1219	.1219	.1524	.2896	.3353	.2439
3	.1372	.0914	.1219	.1219	.2896	.3353	.2134
4	.1372	.0914	.1219	.1219	.2896	.3353	.2439
5	.1372	.0914	.1219	.1524	.3048	.4572	.3048
6	.1372	.0914	.1524	.1524	.442	.5335	.3353
7	.1372	.0914	.1524	.1524	.6859	.8078	.3658
8	.1372	.0914	.1219	.1524	.7011	.7621	.4268
9	.1524	.0914	.1372	.2058	.1067		.1029
10	2.1491	.6097	.7316	.1372	.1372	.1372	.3963
11	2.6063	.6706	.8993	.1219	.1219	.1372	.4572
12	2.5606	.7011	.7621		.1219	.12	.5944
13	2.2405	.6401	.7621	.0914	.0762	.1029	.6097
14	2.5911	.6097	.8078	.0914	.0914	.12	.6097
15	2.4387	.6097	.8383	.0914	.1067	.1372	.5792
16	1.3717	.6401	.6706	.1524		.1372	.4572
17		.503	.9145	.1372		.1219	.4458
18	.1067	.0914	.1219		.1524	.1067	.1029
19	.1524	.1524	.1524	.1715	.1372	.0914	.0857
20		.1524		.1715	.1524	.1524	.1372
21		.1524	.1829	.1715	.1219	.1219	.1372
22			.2743	.1715	.1219	.1219	.1372
23	.1524	.1219	.2439	.3429	.3353	.2439	.1029
24	.1886	.1219	.1219	.1829	.2896	.3353	.2439
Max	2.6063	.7011	.9145	.3429	.7011	.8078	.6097
Min	.1067	.0914	.1219	.0914	.0762	.0914	.0857
Avg	.8938	.2896	.3764	.1545	.2439	.2647	.3157



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.823	.8573	.7888	.823	.8573	.823
2	.9088	.7888	.823	.7545	.7716	.8059	.7888
3	.8916	.7202	.823	.7202	.7716	.8059	.7545
4	.8916	.7545	.823	.7545	.7716	.8059	.7888
5	.8916	.823	.823	.7888	.7888	.823	.823
6	.9431	.8573	.8916	.823	.8573	.9259	.8916
7	.9774	.9259	.9259	.8573	.8573	.9602	.9602
8	.9774	.8916	.9088	.8573	.9431	.9602	.9602
9	.9602	.8916	.8916	.8573	.8573	.9259	.8916
10	.9945	1.0117	.9259	.8916	.9602	.8573	.9088
11	.9431	.8916	.9774	.8573	.9602	.9602	.8745
12	1.0117	.9259	.9088	.8573	.9259	.9602	.8573
13	1.0288	.9259	.9259	.8573	.9259	.9088	.8573
14	1.046	.9774	.9259	.8573	.9259	.9259	.823
15	1.0631	.9259	.9088	.8745	.9259	.9259	.7716
16	1.0802	1.0288	.9259	.9259	.8916	.9431	.823
17	1.166	.9259	.9774	.8402	.9259	.9945	.9259
18	1.0802	.9774	.9602		.9774	1.0288	.6859
19	1.3375	1.1488	1.166	1.1488	1.1317	1.2003	1.1488
20		1.2689	.4801	1.2346	1.286	1.2689	1.3375
21	1.0974	1.2003	.6516	1.166	1.2174	1.166	1.2689
22	1.0802	1.1317	.6859	1.1317	1.166	1.166	1.2003
23	.9602	1.0802	.8573	.9602	.9774	1.0288	1.046
24	.9945	.8573	.9945	.823	.8402	.8745	.8573
Max	1.3375	1.2689	1.166	1.2346	1.286	1.2689	1.3375
Min	.8916	.7202	.4801	.7202	.7716	.8059	.6859
Avg	1.0117	.9481	.8766	.8968	.9366	.9616	.9195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 203 / 11 KV FACTORY VILLAGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	.6859	.7888	.6516	.823	.8402	.7545
2	.9774	.6516	.8059	.6173	.8745	.8402	.7888
3	.9774	.6173	.8059	.6173	.8745	.8402	.7545
4	.9945	.6173	.8059	.6516	.8573	.8402	.7202
5	1.0974	.6859	.8745	.6859	.8573	1.0631	.7888
6	1.2003	.8573	1.046	.7545	1.046	1.2174	.7926
7	1.2346	1.0631	.9945	.823	1.2003	1.2174	.9602
8	1.2003		1.286	.8916	1.2003	1.166	.9945
9	1.1317	1.0631	1.3203	.9602	1.0802	1.2003	.9602
10	1.2346	1.2003	1.286	.7202	1.166	1.3889	1.0802
11	1.0974	1.0631	1.286	.8745	1.1317	1.2346	.9602
12	1.046	.8573	.9602		1.1317	.9602	.8573
13	.9602	.8916	.9259		1.0288	1.0974	.9259
14	1.2346	1.0288	1.0974	1.0288	.9945	1.0802	.9945
15	1.3203	1.0288	1.2346	1.0802	1.0212	1.2003	1.0631
16	1.166	1.0631	1.1488	.9945	1.0974	1.1488	1.1145
17	1.1145	1.166	1.0212	1.0288	.8573	1.2003	1.0974
18	1.046	1.0802	1.0631		.8745	1.0974	1.046
19	1.1831	.9945	.884	1.0288	1.0802	1.0288	1.1317
20		1.0288		1.0974	1.286	1.0631	1.3375
21	1.2174		1.0631	1.0974	1.2003	.9945	1.2003
22	1.0117	.8573	.9602	1.0288	1.1145	.8573	1.0802
23	.6706	.7888	.8573	.9088	1.0288	.7545	.9431
24	.9945	.7202	.823	.6859	.8059	.8573	.7202
Max	1.3203	1.2003	1.3203	1.0974	1.286	1.3889	1.3375
Min	.6706	.6173	.7888	.6173	.8059	.7545	.7202
Avg	1.0900	.9096	1.0147	.8680	1.0263	1.0495	.9611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 204 / 11 KV POKHALE Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.2439	.3048	.3048	.5792	.5182	.4572
2	.3429	.2134	.3048	.2743	.5792	.5182	.4268
3	.3258	.2134	.3048	.2743	.5792	.5182	.3963
4	.3258	.2439	.3048	.2439	.5792	.5182	.4572
5	.3258	.2743	.3048	.2743	.7621	.7926	.5487
6	.3601	.3353	.381	.3048	1.2498	1.2193	.6401
7	.4287	.3963	.381	.3353	1.8442	1.8747	.7011
8	.3944	.3048	.3658	.3353	1.8138	1.7528	.9145
9	.3353	.3048	.3944	.3658	.2896	.3772	.2743
10	.8993	.6401	.8383	.3658	.3201	.3429	.8078
11	1.3413	1.1584	1.448	.3944	.3658	.3258	.6097
12	1.326	1.1584	1.4937	.3353	.3201	.3429	.5182
13	1.2803	1.0974	1.4327	.3353	.3048	.3258	1.1888
14	1.3889	1.0059	1.4327	.3048	.3048	.3258	1.2193
15	.4801	.9755	1.4022	.2896	.3353	.3086	1.2193
16	1.2193	1.0974	1.4784	.3506	.3353	.3944	1.1888
17	1.2193	1.0669	1.3413	.3601	.3658	.3201	1.1888
18	.3353	.3353	.3048		.3963	.3658	.4115
19	.3658	.3506	.3658	.4115	.381	.3658	.4115
20		.3658		.4115	.3963	.3658	.4287
21	.3048	.3658	.3048	.4287	.381	.3353	.4458
22	.2896	.3658	.3048	.3944	.3658	.3658	.4115
23	.2439	.3658	.3048	.5487	.503	.4268	.3601
24	.3601	.2439	.3353	.3048	.5639	.4877	.4877
Max	1.3889	1.1584	1.4937	.5487	1.8442	1.8747	1.2193
Min	.2439	.2134	.3048	.2439	.2896	.3086	.2743
Avg	.6189	.5468	.6884	.3456	.5798	.5620	.6547

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 205 / 11 KV AMRUT AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372		.1829	.1524	.6097	.7621	.5182
2	.1372		.1829	.1219	.703	.7468	.5182
3	.1372		.1829	.1219	.6249	.7468	.4877
4	.1372		.1829	.1219	.6249	.7926	.5182
5	.1543		.1677	.1219	.6554	.8383	.6097
6	.1543		.1677	.1524	.8383	.8383	.6401
7	.1543		.1829	.1829	1.1431	1.0212	.6706
8	.1543		.2134	.1829	1.1279	.9602	.7621
9	.1524		.2572	.1524	.1829	.2058	.1715
10	1.8138		1.2498	.1524		.1886	.8078
11	2.0576		1.5089	.1524		.1715	.884
12	.5792	.3658	1.5242			.1886	.9145
13	1.9662	.381	1.5546			.1715	.7316
14	1.8442	1.1584	1.448	.1524	.1524	.1543	.7926
15	1.8138	1.0669	1.4175	.1829	.2134	.12	.823
16	1.829	1.0059	1.4632	.1829	.2134	.2058	.8535
17	1.7528	1.1431	1.1888	.1886	.2134	.1981	.9145
18	.1372	.1677	.1524		.2134	.1829	.1886
19	.1524	.1981	.1524	.1886	.1981	.1829	.1886
20		.1981		.2058	.1981	.1829	.1886
21		.1829	.1524	.2229	.1981	.1829	.1715
22		.1829	.1524	.2058	.1829	.1829	.1715
23		.1829	.1524	.6097	.7164	.5335	.1543
24	.1372		.1829	.1524	.6249	.7621	.5182
Max	2.0576	1.1584	1.5546	.6097	1.1431	1.0212	.9145
Min	.1372	.1677	.1524	.1219	.1524	.12	.1543
Avg	.7701	.5195	.6096	.1861	.4817	.4384	.5500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.5487	.5144	.3772	.2743	.4458	.5658
2	.4801	.5144	.5487	.3429	.2915	.4115	.5658
3	.463	.4801	.4572	.3086	.2915	.4115	.5316
4	.4458	.4458	.5144	.3086	.2915	.4115	.4973
5	.4458	.4115	.4801	.2743	.2915	.4115	.4801
6	.4973	.4115	.4458	.2743	.3258	.4115	.4287
7	.463	.4115	.4458	.3086	.3429	.4287	.4458
8	.583	.4115	.4801	.3258	.3086	.4115	.3201
9	.583	.3772	.4287	.463	.3258	.4115	.3601
10	.5144	.4458	.4287	.463	.3944	.6859	.4115
11	.5487	.4458	.4458	.4458	.4115	.6687	.4287
12	.703	.4801	.583	.4287	.583	.6516	.4287
13	.6687	.6001	.6001	.3429	.5144	.6344	.463
14	.583	.6001	.6516	.2058	.4801	.7373	.4801
15	.5658	.5144	.6687	.1543	.4458	.6687	.5144
16	.6173	.4801	.6687	.1715	.4458	.5658	.583
17	.583	.5316	.6687	.4458	.4115	.442	.583
18	.4973	.5658	.6173		.5144	.5792	.3944
19	.5658	.5658	.5144	.4458	.4973	.6344	.5658
20		.583	.4801	.583	.583	.5639	.6173
21	.3086	.583	.6001	.5658	.703	.5487	.6344
22	.4458	.5144	.583	.5316	.6516	.5658	.6001
23	.503	.463	.5144	.4973	.6001	.5658	.5658
24	.926	.583	.5487	.4115	.2572	.5144	.583
Max	.926	.6001	.6687	.583	.703	.7373	.6344
Min	.3086	.3772	.4287	.1543	.2572	.4115	.3201
Avg	.5415	.4987	.5370	.3772	.4265	.5326	.5020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 207 / 11 KV Jakhoba LIS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1372	.1219	.1372	.1372	.1372	
4	.1372	.1219	.1372	.1372	.1372	
5	.1372	.1219	.1372	.1372	.1372	
6	.1372	.1219	.1372	.1372	.1372	
7	.1372	.1219	.1372	.1372	.1372	
8	.1372	.1219	.1372	.1372	.1372	
9	.0122	.1219	.1372	.1219	.1372	.1372
10	.0122	.1219	.1372	.1067	.1372	.1372
11	.0122	.1219	.1372	.1067	.1372	.1372
12	.0122	.1219	.1372	.1067	.1372	.1372
13	.0122	.0914	.1372	.1219	.1372	.1372
14	.0122	.0914	.1372	.1219	.1372	.1372
15	.0122	.1219	.1372	.1067	.1372	.1372
16	.0122	.1219	.1372	.1067	.1372	.1372
17	.0122	.1372	.1219	.1372	.1219	.1372
18	.0686	.12	.1219	.1372	.1219	.0686
Max	.1372	.1372	.1372	.1372	.1372	.1372
Min	.0122	.0914	.1219	.1067	.1219	.0686
Avg	.0626	.1189	.1353	.1248	.1353	.1303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 401 / 33 KV Biltube Express

Feeder Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3148	1.9033	3.1379	1.9547	2.7778	2.6749	2.6749
2	2.4691	1.8519	3.035	1.8519	2.7263	2.7778	2.8292
3	2.3663	1.749	2.7778	1.9547	2.6749	2.6749	2.7778
4	2.4691	2.0576	2.8807	2.0576	2.572	2.7778	2.572
5	2.572	2.2634	2.6749	2.2634	2.572	2.6749	2.4691
6	2.2119	2.3663	2.4177	2.4691	2.6749	2.7778	2.6749
7	2.9321	2.3148	.1029	2.572	2.572	2.9835	2.8807
8	2.6749	2.7263	1.3375	2.7778	2.7778	2.572	2.7778
9	2.3148	2.6749	2.572	2.6749	1.3889	2.7778	1.749
10	2.3148	2.8292	2.1091	2.4177	2.4177	2.9835	1.4403
11	2.4691	2.572	2.3148	2.6749	2.3148	3.3436	2.3663
12	2.5206	1.6461	2.5206	2.8292	1.6461	2.2119	2.572
13	2.6749	1.6975	2.1605	1.9547	2.572	2.7263	2.2119
14	2.2119	1.749	2.3663	2.0576	.6173	3.1893	2.3663
15	2.2119	2.2119	2.4177	2.0062	3.035	3.035	2.572
16	2.2634	2.3148	2.1605	2.6235	2.7778	2.8292	2.8807
17	2.4691	2.4691	2.0062	2.7263	2.6749	2.572	3.0864
18	2.3148	2.8807	2.572	2.6749	2.8292	2.8292	.5144
19	2.4177	2.3663	2.3663	3.035	2.4691	2.572	3.3436
20	2.1091	2.6749	1.9547	2.0576	2.3148	2.8807	3.1379
21	.9259	2.572	2.6749	2.6235	2.7778	2.7778	2.8807
22	2.3663	2.9835	1.9033	2.4691	2.6749	2.7778	2.1605
23	2.6749	3.1893	1.9547	2.3663	2.4691	2.7778	2.6235
24	2.1091	1.9033	3.0864	2.0576	2.9321	2.572	2.572
Max	2.9321	3.1893	3.1379	3.035	3.035	3.3436	3.3436
Min	.9259	1.6461	.1029	1.8519	.6173	2.2119	.5144
Avg	2.3491	2.3320	2.3127	2.3813	2.4691	2.7821	2.5056

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037]

BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 201 / Single Phasing Stave-  
Sawarde Feeder KV- 11 /  
OUTGOING

SINGLE PHASING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8478	.3086	.2149	.1791	.0905	.0895	.0716
2	.8817	.3086	.2149	.1791	.0905	.0716	.0716
3	.8817	.3086	.2149	.1791	.0724	.0716	.0716
4	.9156	.3086	.2149	.1715	.0701	.0716	.0716
5	1.0059	.3121	.2149	.1715	.0701	.0716	.0716
6	1.073	.0895	.2743	.2012	.0857	.0716	.0895
7	1.2125	.0732	.5365	.2321	.0838	.0857	.0857
8	1.2452	.3277	.5365	.2347	.0671	.0895	.0686
9	.0876	.0867	.0532	.0678	.0716	.0724	.0686
10	.0848	.0686	.0829		.3052	.2915	.0686
11	.0943	.0686	.0655		.407	.3887	.0686
12	.0754	.0514	.0663	.2347	.3932	.4858	.0514
13	.0943		.0663	.2622	.407	.5121	.0514
14	.0943		.0663	.3239	.407	.5761	.0514
15	.0953	.0343	.0663	.3401	.4115	.5761	.0514
16	.0953	.0686	.0857	.2241	.4115	.6325	
17	.0953	.0671	.0867	.2486	.3429	.583	
18	.0857	.0895	.1097	.1052	.0514	.0934	.0895
19	.1086	.1075	.128	.128	.128	.1307	.1097
20	.1402	.128	.1463	.1307	.1307	.1307	.1307
21	.1267	.128	.1478	.1494	.1307	.1307	.1307
22	.1109	.128	.1294	.1307	.1307	.1307	.1307
23	.3086	.2218	.2896	.0914	.0886	.1097	.2686
24	.1132	.3086	.2149	.2149	.0914	.0895	.0895
Max	1.2452	.3277	.5365	.3401	.4115	.6325	.2686
Min	.0754	.0343	.0532	.0678	.0514	.0716	.0514
Avg	.4114	.1633	.1761	.1909	.1891	.2315	.0892



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 202 / Single Phasing Stave-  
Mohare Feeder KV- 11 /  
OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1086	.1075	.1433
2					.1086	.1075	.1791
3					.1086	.1075	.2149
4					.1052	.1075	.2149
5					.1052	.1433	.2149
6					.1715	.1433	
7					.2012	.2058	
8					.2012	.2149	
10	1.6617	.0857	.4641				.0686
11	2.3765	.0857	.7209				.0686
12	2.452	.1372	.6962				.1029
13	2.4143	.1341	.7293				.1029
14	2.3765	.1341	.7293				.2058
15	2.3624	.1372	.7293				.1715
16	2.2862	.12	.8573				
17	2.21	.1174	.8669				.0686
23				.0914	.1063		
24					.1097	.1075	.1075
Max	2.452	.1372	.8669	.0914	.2012	.2149	.2149
Min	1.6617	.0857	.4641	.0914	.1052	.1075	.0686
Avg	2.2675	.1189	.7242	.0914	.1326	.1383	.1433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 203 / Single Phasing Stave- SINGLE PHASING  
 Satave Feeder KV- 11 /  
 OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7122	.3772	.2507	.2149	.1086	.0895	.0895
2	.78	.3772	.2865	.2149	.1086	.0895	.0895
3	.78	.3429	.2149	.2149	.0905	.0895	.0895
4	.8139	.3429	.2149	.2149	.0876	.0895	.0895
5	.9054	.3467	.2149	.2058	.0876	.0895	.0895
6	.9724	.1075	.2743	.2012	.0857	.0895	.1075
7	1.0159	.0914	.3353	.1989	.0838	.1029	.1029
8	1.0486	.3277	.3353	.2012	.0838	.1075	.0857
9	.0876	.0867	.0709	.0848	.0895	.0905	.0857
10	.1017	.0514	.0829	.208	.1696	.1943	.0686
11	.1132	.0514	.0655		.2713	.1943	.0686
12	.0566	.0686	.0829	.1677	.2622	.1781	.0686
13	.1509	.0671	.0829	.1802	.2622	.2241	.0514
14	.1509	.0503	.0829	.1943	.3052	.2401	.0686
15	.1524	.0686	.0829	.2267	.3429	.2401	.0514
16	.1334	.0686	.0857	.2561	.3086	.1898	.0514
17	.1334	.0671	.0867	.1989	.2743	.2591	.0514
18	.12	.1029	.128	.1052	.0686	.112	.0895
19	.1448	.1254	.1463	.1463	.1463	.1494	.1097
20	.1578	.1463	.1646	.1494	.1494	.1494	.1494
21		.1463	.1663	.1494	.1494	.1494	.1494
22	.1109	.1463	.1478	.1494	.1494	.1494	.1494
23	.3772	.2218	.2896	.128	.124	.128	.1791
24	.1132	.3772	.2507	.2507	.1097	.1075	.1075
Max	1.0486	.3772	.3353	.2561	.3429	.2591	.1791
Min	.0566	.0503	.0655	.0848	.0686	.0895	.0514
Avg	.3971	.1733	.1726	.1853	.1633	.1460	.0935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 204 / Bhairavnath LIS Satave  
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
3	.0848	
4	.0848	
5	.0838	
6	.0838	
7	.0819	
8	.0819	
9	.0876	.052
10	.0848	.0343
11	.0943	
12	.0943	
13	.0943	
14	.0943	
15	.0953	
16	.0953	
17	.0953	
Max	.0953	.052
Min	.0819	.0343
Avg	.0891	.0432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 201 / Shahuwadi-Maan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.128	.112	.1097	.0924	.1097	.0754
2	.168	.128	.112	.1097	.0732	.1097	.0754
3	.1663	.128	.112	.1097	.0732	.1097	.0754
4	.1494	.128	.112	.1097	.0924	.1097	.0934
5	.1848	.1463	.1494	.1463	.1109	.1097	.112
6	.1867	.1829	.1663	.1829	.1294	.128	.1478
7	.1829	.1829	.2103	.2012	.1448	.1463	.1463
8	.2218	.1753	.2374	.1715	.1715	.1433	.1267
9	.2229	.1715	.2012	.1357	.1326	.124	.1387
10	.2058	.1524	.2058	.1638	.1052	.1174	.1372
11	.1865	.156	.1715		.1174		.1509
12	.1227	.1677	.1372		.1174		.1341
13	.1928	.1677	.1543			.1094	.1147
14	.1791	.1802	.1543			.1134	.1341
15	.1949	.1543	.1578		.1006	.1174	.128
16	.1844	.104	.1578		.1174	.1235	.1265
17	.2058	.125	.1578		.1341	.1457	.1677
18	.2103	.1475	.1753		.1715	.1638	.2058
19	.2279	.1886	.1949	.1791	.2058	.2126	.2279
20	.2835		.2865	.2587	.2229	.2587	.2149
21	.2507	.2353	.2507	.2402	.2103	.2218	.1715
22	.2172	.2402	.2149	.2033	.1791	.1848	.1433
23	.1829	.1494	.181	.1663	.1254	.1494	.1254
24	.1829	.1463	.1307	.1463	.1109	.1086	.0943
Max	.2835	.2402	.2865	.2587	.2229	.2587	.2279
Min	.1227	.104	.112	.1097	.0732	.1086	.0754
Avg	.1949	.1602	.1726	.1646	.1336	.1417	.1361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 202 / Shahuwadi- Amba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.1509	.1886	.1509	.1509	.1509
2	.1867	.1886	.1509	.1886	.1509	.1509	.1509
3	.1848	.1886	.1509	.1886	.1509	.1509	.1509
4	.168	.1886	.1509	.1886	.1509	.1509	.1509
5	.168	.1886	.1867	.1886	.1509	.1509	.1509
6	.2218	.2075	.1867	.2263	.1698	.1886	.1886
7	.2614	.2263	.1867	.2263	.1867	.1886	.1886
8	.2957	.2241	.1848	.2241	.2033	.1867	.1886
9	.3547	.2195	.2378	.2218	.1991	.168	.2075
10	.333	.2561	.2378	.2172	.2353	.2012	.2033
11	.3366	.2686	.2561		.2507	.181	.2012
12	.3403	.2804	.2743		.2328	.181	.2033
13	.3582	.2804	.2743		.197	.197	.2012
14	.3582	.2507	.2926		.2149	.2149	.2149
15	.3366	.2149	.2926		.2195	.2103	.2195
16	.333	.2126	.2896		.2172	.2254	.2172
17	.3189	.2149	.2926		.2195	.2328	.2195
18	.2896	.2149	.2926		.2195	.2378	.2561
19	.2743	.2507	.2926	.2561	.2561	.1886	.2743
20	.3292	.2587	.3292	.3142	.2743	.2641	.2195
21	.2957	.2427	.3326	.2957	.2587	.2263	.2195
22	.2587	.2263	.2957	.2614	.2241	.1886	.1829
23	.2427	.2075	.2614	.2263	.1867	.1886	.1829
24	.2263	.2075	.1698	.2054	.1886		.1698
Max	.3582	.2804	.3326	.3142	.2743	.2641	.2743
Min	.168	.1886	.1509	.1886	.1509	.1509	.1509
Avg	.2775	.2253	.2404	.2261	.2045	.1923	.1964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 203 / Shahuwadi-sawe  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.056	.3018	.1132	.3018	.2641	.2263
2	.2587	.0373	.3018	.1132	.3018	.2641	.1886
3	.2614	.0373	.3018	.1132	.3018	.2641	.1886
4	.2587	.0373	.3018	.1132	.3395	.2641	.1886
5	.2957	.0549	.3018	.1509	.3772	.3018	.2263
6	.3361	.0549	.3395	.1886	.3841	.3395	.2829
7	.3326	.0549	.3395	.2075	.362	.3772	.2957
8	.3734	.0526	.3511	.1867	.3772	.3734	.3326
9	.3734	.0514	.4572		.3814	.3045	.3142
10	.3734	.1629			.3467	.3155	.3077
11	.3077	.4435			.3121	.3294	.2896
12	.2896	.462	.1829		.298	.2926	.2195
13	.2715	.439	.2378		.298	.2378	.2033
14	.2926	.4024	.5121		.3224	.2195	.1829
15	.3077	.3982	.4024		.3155	.1829	.2172
16	.3475	.4557	.4024		.3467	.2534	.2507
17		.5083	.4024		.3506	.2715	.2987
18	.4024	.4477	.4251		.394	.3258	.3361
19	.499	.543	.4481		.5121	.4024	.3921
20	.5975	.6036		.3109		.499	.4024
21		.5601		.3881	.439	.4481	.3734
22		.4715		.3511	.4066	.3734	.3734
23		.3961	.2263	.3395	.3395	.3018	.3361
24	.2829	.0747	.3395	.1509	.3018	.3018	.2452
Max	.5975	.6036	.5121	.3881	.5121	.499	.4024
Min	.2587	.0373	.1829	.1132	.298	.1829	.1829
Avg	.3371	.2836	.3461	.2098	.3526	.3128	.2780

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 204 / Shahuwadi-Kotoli Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0705	.0293			
2		.0705	.0297			
3		.0686	.0297			
4		.0667	.0297			
5		.08	.0297			
6		.0572	.0457			
7		.0648	.061			
8		.0714	.0671			
10				.176	.1265	.1781
11				.2105	.1875	.1802
12				.1943	.1875	.2012
13				.2241	.1852	.1943
14				.2012	.1698	.2012
15				.2012	.1677	.2012
16				.208	.1698	.1829
17				.1802	.2372	.1677
23	.08					
24		.0762				
Max	.08	.08	.0671	.2241	.2372	.2012
Min	.08	.0572	.0293	.176	.1265	.1677
Avg	.08	.0695	.0402	.1994	.1789	.1884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 205 / Shahuwadi - Malkapur  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.3772	.3772	.3772	.415	.3772	.3395
2	.4251	.3772	.3772	.3772	.3772	.3658	.3395
3	.4481	.3772	.3772	.3772	.3772	.3772	.3395
4	.4435	.3772	.3772	.3772	.3772	.3772	.3772
5	.4668	.415	.415	.415	.415	.3772	.415
6	.4854	.4527	.4715	.4527	.4715	.4527	.4715
7	.4805	.4715	.4854	.4904	.5228	.4715	.4854
8	.5228	.4668	.4805	.5415	.5487	.4668	.4854
9	.5544	.462	.4805	1.1949	.4805	.4207	.5359
10	.5601	.5359	.439	.8299	.5304	.4163	.5304
11	.6099	.5544	.4755		.6036	.4477	.5487
12	.6283	.6219	.439		.5175	.4755	.5487
13	.6468	.6584	.4024		.5121	.5121	.5304
14	.6535	.6584	.439		.5853	.5121	.5175
15	.6468	.6335	.4668		.5853	.5121	.5121
16	.6401		.4805		.6154	.4656	.4938
17	.6401	.5601	.5228		.0914	.5121	.5228
18	.6283	.6036	.6348		.6584	.5914	.5544
19	.6722	.6722	.6722	.5228	.7316	.6535	.6219
20	.7545	.7282	.7095	.924	.7499	.7095	.5853
21	.7167	.6348	.6722	.8215	.695	.1235	.5544
22	.679	.5975	.6036	.7095	.5975	.6036	.5228
23	.5658	.5093		.6036	.4904	.4904	.4481
24	.4527	.4527	.415	.4338	.4904	.4527	
Max	.7545	.7282	.7095	1.1949	.7499	.7095	.6219
Min	.4251	.3772	.3772	.3772	.0914	.1235	.3395
Avg	.5737	.5303	.4876	.5905	.5183	.4652	.4904



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 206 / Shahuwadi-Parale Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4287	.016	.0137	.0057	.0686	.0819	.0526
2	.4191	.016	.0137	.0057	.0686	.0819	.0526
3	.4287	.016	.0137	.0057	.0686	.0819	.0526
4	.4191	.016	.0137	.0057	.0686	.0819	.0566
5	.5304	.0152	.0137	.0057	.0876	.0983	.0537
6	.8718	.0145	.0143	.0057	.0886	.116	.0543
7	.8951	.0137	.0141	.0057	.0886	.1341	
8	.9389	.013	.0137	.0183	.1227	.1509	.0876
9		.0118	.0162	.0332	.0103	.0152	.0173
10	.823	.4917	.3563	.0335	.0162	.0105	.017
11	.8916	.5197	.5144		.0139		.0131
12	.9088	.5407	.583		.0069		.0137
13	.7461	.5365	.583			.0111	.0143
14	.8048	.4858	.583			.0105	.013
15	.8215	.4534	.5144		.013	.0152	.0111
16	.7287	.4218	.4801		.0109	.0154	.0111
17	.6226	.3841	.4115		.0111	.0156	.013
18	.0156	.016	.0137		.0111	.0122	.013
19	.0152	.0175	.0137	.0133	.0111	.0088	.0149
20	.0152	.0189	.0137	.013	.0114	.0124	.0137
21	.0152	.0175	.0122	.0141	.0114	.0124	.013
22	.0152	.0143	.0122	.0152	.0114	.0133	.013
23	.016	.0133	.0122	.0514	.1147	.0343	.0457
24	.0244	.016	.0133	.0057	.0514	.1311	.0526
Max	.9389	.5407	.583	.0514	.1227	.1509	.0876
Min	.0152	.0118	.0122	.0057	.0069	.0088	.0111
Avg	.4955	.1700	.1768	.0149	.0439	.0520	.0304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.0189	.0343			
2	.0316	.0189	.0343			
3	.032	.0189	.0343			
4	.032	.0189	.0343			
5	.0655	.0189	.0347			
6	.0819	.0189	.0351			
7	.0819	.0526	.0351			
8	.0503	.0671	.0351			
10				.0648	.0171	.0347
11				.0564	.0324	.0532
12				.0671	.0671	.0716
13				.0474	.0747	.0716
14					.0709	.0701
15				.032	.0503	.0686
16				.0332	.0474	.0716
17				.0335	.0709	.0671
23	.0189					
24	.0312	.0189	.0351			
Max	.0819	.0671	.0351	.0671	.0747	.0716
Min	.0189	.0189	.0343	.032	.0171	.0347
Avg	.0457	.028	.0347	.0478	.0539	.0636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 208 / Shahuwadi-Perid Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.061	.064	.0469
2					.0594	.064	.0469
3					.0594	.064	.0469
4					.0743	.064	.0469
5					.0869	.064	.0469
6					.0846	.0972	.0469
7						.1638	.0937
8					.1486	.1677	.1524
10	.3688	.2294	.192				.1572
11	.421	.3077	.2561				.1829
12	.4973	.2721	.2881				.1562
13	.4752	.2561	.3277				.1174
14	.4694	.2214	.3277				.1341
15	.4424	.2187	.3277				.1311
16	.427	.2408	.2949				.1524
17	.3353	.2134	.2458				.1677
23				.064		.125	
24					.064	.096	.0469
Max	.4973	.3077	.3277	.064	.1486	.1677	.1829
Min	.3353	.2134	.192	.064	.0594	.064	.0469
Avg	.4296	.2450	.2825	.064	.0798	.0970	.1043

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 209 / Shahuwadi-Ameni vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0191	.0943	.0191	.0754	.1132	.0189
2	.0381	.0191	.0754	.0191	.0754	.1132	.0189
3	.0381	.0191	.0754	.0191	.0754	.1132	.0189
4	.0381	.0191	.0754	.0191	.0943	.1132	.0381
5	.0381	.0191	.0943	.0191	.1132	.1132	.0381
6	.0381	.0381	.1132	.0381	.132	.1494	.0381
7	.0381	.0377	.1132	.0377	.1509	.1867	.0381
8	.0381		.0381	.4527	.1509	.1494	.0381
9	.0377	.0377	.0381	.4805	.1463	.1509	.0381
10	.0377	.0377	.0377	.4755	.1509	.132	.0381
11	.0377	.3772	.0377	.0381	.1509	.132	.0381
12	.0377	.6584	.0377		.128	.132	.0381
13	.0377	.6219	.0377		.1509	.1509	.0381
14	.0377	.6219	.0377		.1509	.132	.0381
15	.0377	.5914	.0377		.1478	.1132	.0381
16	.0377	.6767	.0377		.1463	.0934	.0381
17	.0377	.695	.0377		.1463	.1307	.0381
18	.0377	.7316	.0377		.1463	.1494	.0381
19	.0377	.2587	.0377	.3734	.1829	.0377	.0381
20	.0377	.2614	.0377	.2263	.1772	.0377	.0381
21	.0377	.2241	.0377	.1886	.2195	.0377	.0381
22	.0377	.1698	.0377	.132	.2241	.0381	.0381
23	.0377	.132	.0377	.1132	.1867	.0191	.0381
24	.0377	.0191	.0943	.0191	.0754	.1509	.0191
Max	.0381	.7316	.1132	.4805	.2241	.1867	.0381
Min	.0377	.0191	.0377	.0191	.0754	.0191	.0189
Avg	.0378	.2733	.0558	.1571	.1416	.1121	.0349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 201 / SARUD-BAMBAWADE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456		.9335		.9522	.9335	
2	.9522		.8962		.9149	.9335	
3	.9522		.9335		.9149	.9335	
4	.9522		.9335		.9149	.9335	
5	1.1016		1.1203		.9896	.9709	
6	1.2696		1.1203		1.0456	1.0082	
7	1.419		1.1576		1.0456	1.1203	
8	1.419		1.1016			1.2696	1.1949
9	1.3443	.9709	1.1949	1.1949	1.1576		1.1949
10	1.3817	1.4937	1.3443	1.2323	.8962		1.2136
11	1.3817	1.307	1.2696		1.1576	1.3443	1.2696
12	1.2323	.9709	1.1949		1.4003	1.2696	1.2323
13	1.2323		1.1949		1.4003	.9709	1.1576
14	1.2323	1.419	.9709		1.307	1.1203	.9709
15		1.419	1.1203		1.307	1.1203	1.1389
16		1.1576	1.1949		1.307		1.0829
17		1.1576			1.307		1.0082
18		1.1203	1.1949		1.307	1.1949	1.1576
19	1.4937	1.587		1.0829	1.4937		1.363
20		1.643		1.2883	1.4937	1.643	1.531
21		1.4003		1.531	1.307		1.6057
22		1.307		1.307	1.2696	1.3443	1.3817
23		1.1203		1.1576	1.1203	1.1949	1.1576
24	1.1576	.7468	.9335		1.0082	1.0082	.8962
Max	1.4937	1.643	1.3443	1.531	1.4937	1.643	1.6057
Min	.9522	.7468	.8962	1.0829	.8962	.9335	.8962
Avg	1.2230	1.2547	1.1005	1.2563	1.1747	1.1285	1.2092

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 202 / Sarud-Bhedasgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174		.3174		.3361	.3361	
2	.3174		.3361		.3174	.3174	
3	.2987		.3734		.3174	.3174	
4	.3174		.3734		.3174	.3174	
5	.3547		.4108		.3547	.3361	
6	.4294		.4481		.4108	.3734	
7	.4854		.4668		.4481	.4108	
8	.4668		.4668			.4481	.3734
9	.4108	.2987	.4481	.056	.4854		.4108
10	.4108	.2427	.4481	.056	.3734		.4108
11	.4108	.2801	.4854		.3734	.4108	.3921
12	.3734	.2987	.4481		.3734	.2987	.4108
13	.3734	.4481	.3734		.3361	.3361	.3174
14	.4108	.4668	.3734		.3734	.3361	.2987
15		.4668	.4481		.3734	.3734	.3174
16		.4668	.4481		.3734		.4108
17		.4668			.3734		.4481
18		.4481	.2987		.4854	.4481	.4854
19	.5975	.5041		.7655	.5228		.5415
20		.6908		.7095	.4668	.5975	.6348
21		.5601		.6348	.4481		.5601
22		.5415		.5415	.4481	.5228	.5228
23		.3734		.4108	.3734	.4108	.4108
24	.3361	.2987	.2987		.3547	.3734	.3361
Max	.5975	.6908	.4854	.7655	.5228	.5975	.6348
Min	.2987	.2427	.2987	.056	.3174	.2987	.2987
Avg	.3944	.4283	.4035	.4534	.3929	.3869	.4283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 203 / Sarud-Sarud Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241		.2241		.1867	.1494	
2	.2054		.2241		.1867	.1494	
3	.2054		.2241		.1867	.1494	
4	.2054		.2241		.1867	.1494	
5	.2241		.2241		.2054	.168	
6	.2427		.2241		.2241	.1867	
7	.2614		.2241		.2241	.2241	
8	.2614		.2241			.2054	.2614
9	.2614	.2614	.2241	.2614	.2241		.2987
10	.2987		.2241	.2614	.2801		.2427
11	.2987	.2054	.2614		.2987	.2987	.2614
12	.3734	.2241	.2987		.1867		.2614
13	.2614	.2241	.1867		.1494	.112	.2427
14	.2614	.2241	.2241		.2801	.2241	.1867
15		.2241	.2987		.3734	.2614	.2427
16		.2427	.3361		.3361		.2614
17		.2427			.2241		.2614
18		.2614			.2801	.3361	.2614
19	.4108	.2614		.3174	.2987		.3174
20		.2614		.4294	.2427	.3734	.3734
21		.2614		.4108	.168		.3361
22		.2614		.3361	.1494	.3361	.3361
23		.2241		.2987	.1494	.2987	.3174
24	.2427	.1867	.2241		.2427	.1494	.2614
Max	.4108	.2614	.3361	.4294	.3734	.3734	.3734
Min	.2054	.1867	.1867	.2614	.1494	.112	.1867
Avg	.2649	.2378	.2395	.3307	.2297	.2219	.2779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 204 / Sarud-Gogawe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601		.3361		.0187	.0187	
2	.5415		.3361		.0187	.0187	
3	.5415		.3734		.0187	.0187	
4	.5415		.3734		.0187	.0187	
5	.7095		.4108		.0187	.0187	
6	.8589		.4668		.0187	.0187	
7	1.1576		.5975		.0187	.0187	
8	1.251		.7095			.0187	.0191
9	.0187		.0187	.0191	.0187		.0191
10	.0191		.0191	.4108	.3734		.0187
11	.0191		.0191		.4668	.3734	.3361
12	.0191		.0191		.4668	.4481	.3361
13	.0191	.0187	.0191		.3361	.4481	.3734
14	.0191	.0187	.0191		.4108	.4108	.4108
15		.0187	.0191		.4481	.4481	.4108
16		.0187	.0191		.4108		.4294
17		.0187			.4108		.4481
18		.0187			.0187	.0191	.0187
19	.0191	.0187		.0187	.0187		.0187
20		.0187		.0187	.0187	.0191	.0187
21		.0187		.0187	.0187		.0187
22		.0187		.0187	.0187	.0191	.0187
23		.3174		.0187	.0187	.0191	.2054
24	.0187		.3174		.0187	.0187	.0191
Max	1.251	.3174	.7095	.4108	.4668	.4481	.4481
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.3946	.0459	.2396	.0748	.1567	.1318	.1835



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 205 / Sarud-Shirgaon Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307		.112		.0934	.0934	
2	.1307		.112		.0934	.0934	
3	.112		.112		.0934	.0934	
4	.112		.112		.0943	.0934	
5	.1307		.1307		.0934	.112	
6	.168		.1307		.0934	.1494	
7	.1494		.1494		.1307	.1494	
8	.1867		.1494			.112	.1494
9	.1867		.1494	.112	.1307	.1307	.1494
10	.1867		.1494	.112	.168		.1494
11	.168		.1494		.168	.1307	.1494
12	.1867	.1867	.1307		.1494	.1307	.0934
13	.168	.2054	.1494		.1307	.1307	.112
14	.1494	.2241	.1494		.1494	.1307	.1494
15		.2241			.1494	.0934	.0934
16		.2241	.1494		.168		.0934
17		.1867			.1867		.1494
18		.2054			.2054	.112	.1494
19	.1867	.2241		.168	.2241		.2427
20		.2614		.2614	.2241	.2614	.2614
21		.1867		.2241	.2054		.2241
22		.168		.168	.2054	.1867	.1867
23		.1494		.1307		.1494	.1494
24	.1494	.056	.112		.112	.112	.112
Max	.1867	.2614	.1494	.2614	.2241	.2614	.2614
Min	.112	.056	.112	.112	.0934	.0934	.0934
Avg	.1564	.1925	.1342	.1680	.1486	.1297	.1538

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 206 / Sarud-Salashi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829		.3361		.112	.0934	
2	1.0829		.3361		.0934	.0934	
3	1.0642		.3734		.0934	.112	
4	1.1016		.3734		.0934	.168	
5	1.1506		.4108		.112	.1867	
6	1.251		.4294		.1307	.1867	
7	1.6804		.4854		.1494	.1867	
8	1.7924		.5041			.2054	.1867
9	.2054	.0381	.1867	.2241	.168	.168	.2054
10	.2241	.0373	.168	.5601	.4854		.4481
11	.3361		.168		.5228	.4481	.5228
12	.2054		.1494		.5975	.5601	.5788
13	.2054	.1867			.5788	.5788	.6348
14	.2427	.168			.5975	.5975	.6161
15		.1494	.1867		.6161	.5415	.3361
16		.168	.1867		.7468		.2987
17		.2054			.7655		.5415
18		.1494			.2054	.1867	.168
19	.2241	.1494		.1494	.2054		.2054
20		.1494		.168	.2054	.1867	.2241
21		.1494		.1494	.1867		.168
22		.1494		.1307	.1867	.1867	.168
23		.3361		.112	.1867	.168	.3361
24	.2241	.3734	.3361		.112	.1494	.1494
Max	1.7924	.3734	.5041	.5601	.7655	.5975	.6348
Min	.2054	.0373	.1494	.112	.0934	.0934	.1494
Avg	.7546	.1721	.3087	.2134	.3109	.2634	.3405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 207 / Sarud-Thergaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187		.0187		.0747	.0747	
2	.0187		.0187		.0747	.0747	
3	.0187		.0187		.0747	.0747	
4	.0187		.0187		.0747	.0747	
5	.0187		.0187		.0934	.168	
6	.0187		.0187		.1307	.1867	
7	.0187		.0187		.2241	.2987	
8	.0187		.0187				.1867
9	.0187	.0191	.0187	.0191	.0187		.0191
10	1.1203	.0747	.5975	.0187	.0187		.0187
11	1.4937	.112	.7655		.0187	.0191	.0187
12	1.6804	.1494	.7842		.0187	.0191	.0187
13	1.6244	.2054	.7655		.0187	.0191	.0187
14	1.2986	.2801	.7282		.0187	.0191	.0187
15		.5601	.6908		.0187	.0191	.0187
16		.5601	.6908		.0187		.0187
17		.5415			.0187		.0187
18		.0187			.0187	.0191	.0187
19	.0191	.0187		.0187	.0187		.0187
20		.0187		.0187	.0187	.0191	.0187
21		.0187		.0187	.0187		.0187
22		.0187		.0187	.0187	.0191	.0187
23		.0187		.0747	.056	.0747	.0187
24	.0187	.0191	.0187		.0747	.056	.056
Max	1.6804	.5601	.7842	.0747	.2241	.2987	.1867
Min	.0187	.0187	.0187	.0187	.0187	.0191	.0187
Avg	.4640	.1646	.3064	.0268	.0495	.0727	.0308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 208 / 11 KV Haritkranti Bhadale

PURELY LIS FEEDERS

LIS Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)
3	.2614	
4	.2614	
5	.2614	
6	.2614	
7	.2614	
8	.2614	
9	.2614	
10	.2614	
11	.2614	
12	.2614	
13	.2614	
14	.2614	
16		.2614
17		.2614
Max	.2614	.2614
Min	.2614	.2614
Avg	.2614	.2614

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 209 / Sarud-Nerle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0373		.056	.056	
2	.0373		.0373		.056	.056	
3	.0373		.0373		.056	.056	
4	.0373		.0373		.056	.056	
5	.0373		.0373		.0747	.0747	
6	.0373		.0373		.0747	.112	
7	.0373		.0373		.112	.1494	
8	.0373		.0373			.1494	.112
9	.0373	.0381	.0373	.0381	.0373	.0373	.0381
10	.5975	.7842	.9335	.0373	.0373		.0373
11	.9335	.9335			.0373	.0366	.0373
12	1.134	.9522			.0373	.0373	.0373
13	1.2696	.9709	1.2803		.0373	.0381	.0373
14	1.307	.9522	1.3535		.0373	.0381	.0373
15		.9522	1.39		.0373	.0381	.0373
16		.9335	1.4266		.0373		
17		.8215			.0373		.0373
18		.0373			.0373	.0381	.0373
19	.0191	.0373		.0934	.0373		.0373
20		.0373		.0373	.0373	.0381	.0373
21		.0373			.0373		.0373
22		.0373		.0373	.0373	.0381	.0373
23				.0187	.056	.0754	.0373
24	.0373	.0381	.0373		.056	.056	
Max	1.307	.9709	1.4266	.0934	.112	.1494	.112
Min	.0191	.0373	.0373	.0187	.0373	.0366	.0373
Avg	.3521	.5042	.4505	.0437	.0487	.0621	.0423

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 202 / Manjare-Vishalgad  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.1886
Max	.1886
Min	.1886
Avg	.1886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 203 / Manjare- Anuskura Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 401 / 33 Kv Gelawade Generation

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.1052
Max	.1052
Min	.1052
Avg	.1052



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 201 / 11 Kv Warul-Amba

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3772	.4706				.3429
2		.3772	.4854				.3429
3		.3429	.4706				.3429
4		.3429	.5068				.3155
5		.381	.5601				.3086
6		.4527	.6516				.3086
7		.4805	.8048				.3086
8	.7011	.5853	.8215		.2804		.3856
9		.7316	.7316		.3258		.4031
10	.8145	.7282					.7011
11	.8048	.6516					.7975
12	.7316	.5548			.8145		.7975
13	.6348	.5144			.905		.8063
14	.6535	.6516			.905		.6379
15	.7682	.6687			.7888		.6379
16	.7712		.631		.583	.7087	
17	.7712		.4287			.7202	
18	.7316		.4115			.7545	
19	.8501		.5487			.8669	
20	.9709		.7291			.8916	
21			.6762			.8573	
22	.4338					.8048	
23	.5292	.5281				.6516	
24	.6224	.4338	.5121	.4287			
Max	.9709	.7316	.8215	.4287	.905	.8916	.8063
Min	.4338	.3429	.4115	.4287	.2804	.6516	.3086
Avg	.7193	.5178	.5900	.4287	.6575	.7820	.4958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 202 / 11 Kv Warul -Yelur  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7545	.6516			.0171
2		.6706	.6443			.0171
3		.57	.6516			.0171
4		.5426	.6783			.0171
5		.6036	.6783			.0171
6		.6706	.8478			.0171
7		.8048	.9431			.0171
8	1.1797	.9054		.0183		.0171
9		.0343		.0171		.017
10		.0173				.5765
11		.0171				.7209
12		.0173		.9614		.7042
13		.0171		1.0277		.7042
14		.0171		1.0277		.7712
15				1.0059		.7377
16	.0343		.0175	1.0513	.9339	
17	.0343				.9496	
18	.0343				.017	
19	.0343				.0171	
20	.0343				.0171	
21					.0171	
22	.0343				.0171	
23	.6706					
24	.0181	.6539	.6516			.0171
Max	1.1797	.9054	.9431	1.0513	.9496	.7712
Min	.0181	.0171	.0175	.0171	.017	.017
Avg	.2305	.4197	.6405	.7299	.2813	.2741

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 203 / 11Kv Warul- Bhendavade  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.3222
2						.3429
3						.3391
4						.373
5						.373
6						.407
7						.407
8					.3944	.4409
10	.7202	.5596				
11	1.0288	.6173				
12	1.0174	.6859				
13	.9496	.6687				
14	.823	.5658				
15	.7461	.5596				
16	.6097		.7108			
17	.6203		.6706			
24				.3185		.2883
Max	1.0288	.6859	.7108	.3185	.3944	.4409
Min	.6097	.5596	.6706	.3185	.3944	.2883
Avg	.8144	.6095	.6907	.3185	.3944	.3659

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 401 / 33 Kv Kadavi Generation

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	05-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0514	.0514
2		.0514	.0514	
3		.0514	.0514	
4		.0514	.0514	
5		.0514	.0514	
6		.0514	.0514	
7		.0514	.0514	
8	.0329	.0514	.0514	.0514
9		.0514	.0514	.0514
10			.0514	.0514
11			.0514	.0514
12			.0514	.0514
13			.0514	.0514
14			.0514	.0514
15				.0514
16	.0514		.0514	.0514
17	.0514			
18	.0514			
19	.0514			
20	.0514			
22	.1029			
23	.052	.0514		
24	.0329	.0514	.0514	.0514
Max	.1029	.0514	.0514	.0514
Min	.0329	.0514	.0514	.0514
Avg	.0531	.0514	.0514	.0514

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 201 / Turukwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.2401			
2			.2401			
3			.2374			
4			.2374			
5			.2374			
6			.2572			
7			.3561			
8			.3429			
10				.1867	.2012	.1612
11				.181	.3018	.2401
12		.2353		.208	.3561	.2683
13		.2926		.218	.3481	.2984
14		.2715		.2818	.3185	.3149
15		.2561		.2883	.3185	.3149
16		.2172		.2683	.3113	.3185
17		.2686		.2984	.2515	.3018
18		.2865				
19	.3045	.3189				
20		.4525				
21		.4163				
22		.3841				
23		.2883				
24			.2374			
Max	.3045	.4525	.3561	.2984	.3561	.3185
Min	.3045	.2172	.2374	.181	.2012	.1612
Avg	.3045	.3073	.2651	.2413	.3009	.2773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2378		.2534		.1029	.181	.2218
2	.2195		.2507		.1029	.181	.2033
3	.2195		.2507		.1029	.181	.2033
4	.2195		.2507		.1029	.181	.2033
5	.2378		.2507		.1052	.181	.2033
6	.2743		.2715		.1402	.2172	.2218
7	.2896		.2865		.1578	.2658	.2561
8	.3189		.3544		.1578	.3155	.2561
9	.3155		.3814		.1595	.3224	.2328
10	.3544		.3506		.1886	.3544	.2328
11	.3155		.3681		.1844	.333	.2012
12	.362		.3681		.1658	.2804	.2035
13	.3582		.3544		.0848	.298	
14	.3224		.3544		.1006	.298	.2035
15	.3189		.3544		.0876	.2774	.1823
16	.333		.3641		.1296	.3521	.2012
17	.3121		.333		.2214	.3561	.218
18	.2915				.3688	.3856	.3018
19	.3045		.3898		.3944	.4163	.2947
20			.394	.3012	.4119	.4435	.3841
21			.3077	.2835	.3658	.4066	.3258
22			.3077	.2481	.3258	.3326	.2896
23		.3077	.3077	.1578	.2507	.2587	.2172
24	.2587		.2507		.12	.2172	.2218
Max	.362	.3077	.394	.3012	.4119	.4435	.3841
Min	.2195	.3077	.2507	.1578	.0848	.181	.1823
Avg	.2932	.3077	.3198	.2477	.1888	.2932	.2382

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 203 / 11 KV Kandavan Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801		.1629		.1612	.128	.2241
2	.2587		.1629		.1612	.128	.2241
3	.2587		.1629		.1612	.128	.2241
4	.2587		.1629		.1612	.128	.2241
5	.2614		.1629		.1612	.128	.2241
6	.2987		.1991		.1791	.1829	.2801
7	.3511		.2012		.2149	.181	.3109
8	.3439		.2303		.2103	.2172	.3326
9	.3544				.2103	.1772	.2743
10	.3761		.0701		.208	.1696	
11	.3045				.2126	.1907	.2012
12	.2454				.1772	.156	.218
13	.2481				.1886	.1109	.2543
14	.2686				.2058	.112	.2427
15	.3012		.3898		.1907	.112	.1865
16	.333		.3988		.1475	.1417	.2347
17	.3429		.3601		.1509	.1402	.2818
18	.3391				.1989	.1772	.3185
19	.4835	.2572	.4908		.2601	.4887	.4239
20		.362	.5731	.394	.3258	.5175	.543
21		.2957	.4525	.3582	.2772	.4481	.4572
22		.2926	.4525	.2865	.2402	.4108	.3801
23		.2195	.4525	.2149	.1829	.2801	.2561
24	.2987		.181		.197	.1478	.2241
Max	.4835	.362	.5731	.394	.3258	.5175	.543
Min	.2454	.2195	.0701	.2149	.1475	.1109	.1865
Avg	.3103	.2854	.2926	.3134	.1993	.2084	.2844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 147018 / 132/33KV Bambawade

Feeder No / Name : 407 / 33KV Maruti Wind

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 201 / Sh-R- Panhala Hill Station  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1334	.1334	.1334	.12	.1143	.1143
2	.1334	.1334	.1334	.1334	.12	.1143	.1143
3	.1334	.1334	.1334	.1334	.12	.1143	.1143
4	.1334	.1334	.1334	.1334	.12	.1143	.1143
5	.1334	.1334	.1334	.1334	.12	.1143	.1334
6	.1524	.1715	.1715	.1524	.1372	.1524	.1715
7	.1715	.1715	.1715	.1524	.1372	.1524	.1905
8	.1524	.1715	.1715	.1715	.1372	.1524	.1524
9	.1524	.1715	.1715	.1543	.1372	.1715	.1372
10	.1715	.1715	.1715	.1372	.1334	.1715	.1372
11	.1905	.1715	.1715	.1372	.1334	.1524	.12
12	.1905	.1524	.0953	.1543		.1524	.1372
13	.1905	.1524	.0953	.12	.1524	.1524	.1372
14	.1715	.1715	.0953	.1372	.1524	.1524	.1372
15	.1715	.1905	.1143	.1715	.1524	.1524	.12
16	.1715	.1905	.1715	.1372	.1524	.1524	.1372
17	.1905	.2096	.1715	.1543	.1715	.1524	.1372
18	.1524	.2096	.1334	.1543	.1715	.1715	.1372
19	.2096	.2096	.1905	.1715	.1905	.2096	.1543
20	.2286	.1886	.2286	.1715	.1905	.2096	.1715
21	.2096	.2058	.2286	.1715	.1905	.2096	.1715
22	.1905	.2058	.2096	.1715	.1715	.1905	.1715
23	.1524	.2286	.1905	.1372	.1715	.1524	.1543
24	.1715	.1334	.1524	.1524	.1494	.1334	.1143
Max	.2286	.2286	.2286	.1715	.1905	.2096	.1905
Min	.1334	.1334	.0953	.12	.12	.1143	.1143
Avg	.1691	.1727	.1572	.1490	.1492	.1548	.1408

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1143	.1334	.1715	.1029	.1143	.1143
2	.1524	.1143	.1334	.1715	.1029	.1143	.1143
3	.1524	.1143	.1334	.1715	.1029	.1143	.1143
4	.1524	.1143	.1334	.1715	.12	.1143	.1143
5	.1905	.1143	.1334	.1905	.1372	.1143	.1334
6	.2096	.1524	.2286	.2096	.1543	.2096	.2096
7	.2096	.1905	.2286	.2286	.1372	.2096	.2286
8	.2096	.1524	.2477	.2286	.1372	.2286	.2286
9	.2096	.1715	.2096	.2058	.1372	.2058	.2229
10	.2286	.1334	.2286	.1886	.1715	.2058	.1715
11	.2286	.1334	.2477	.1886	.1715	.2058	.1543
12	.2286	.1334	.2096	.1715		.1886	.1715
13	.2477	.0953	.2286	.1886	.2286	.1715	.1715
14	.2286	.1334	.2286	.1886	.2667	.1905	.1715
15	.2286	.1715	.2286	.1715	.2667	.2096	.1543
16	.2286	.1715			.2667	.2096	.1715
17	.2286	.1829	.2286		.2286	.2286	.1543
18	.2286	.2286	.2286		.2667	.1905	.1886
19	.3048	.2286	.3239	.1372	.3048	.3048	.2401
20	.3239	.2058	.362	.2058	.3429	.3239	.2743
21	.2286	.2229	.3239	.1886	.3048	.2858	.2401
22	.2096	.2401	.2667	.1543	.2858	.2058	.2058
23	.1715	.1905	.2286	.1372	.1715	.1715	.1715
24	.1715	.1334	.1524	.1905	.1029	.1334	.1334
Max	.3239	.2401	.362	.2286	.3429	.3239	.2743
Min	.1524	.0953	.1334	.1372	.1029	.1143	.1143
Avg	.2135	.1601	.2203	.1838	.1962	.1938	.1773

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 203 / 11 KV NAVALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.3429	.381	.4191	.3944	.3429	.381
2	.5335	.3429	.381	.4191	.3944	.3429	.381
3	.5335	.3429	.381	.4191	.3944	.3429	.381
4	.5335	.3429	.381	.4191	.4287	.3429	.381
5	.5716	.381	.381	.4572	.463	.3429	.4191
6	.6287	.5335	.5525	.5716	.4973	.5906	.5716
7	.5906	.4954	.6097	.5716	.4973	.6287	.6478
8	.5716	.5716	.724	.5335	.5658	.6287	.6097
9	.5716	.4954	.6478	.4801	.5144	.7621	.5487
10	.6859	.6478	.6478	.4973	.6859	.724	.4973
11	.6478	.6478	.6097	.5316	.7049	.6859	.5487
12	.6478		.7621	.4801		.6859	.5144
13	.6478	.5525	.7621	.4458	.6097	.6097	.4458
14	.6478	.6097	.724	.4801	.3239	.6097	.463
15	.6097	.724	.724	.5487	.381	.6097	.4973
16	.6097	.7621	.7621	.463	.4763	.6478	.4115
17	.6478	.8383	.724	.6344	.8192	.6859	.6001
18	.6859	.8383	.724	.6344	.9145	.6478	.5658
19	.9145	.8573	.8383	.7202	.9907	.9526	.8059
20	.9526		.9526	.7716	1.0098	.9145	.8573
21	.5716		.8383	.6859	.9526	.8002	.7716
22	.4763		.724	.6173	.9145	.6859	.6687
23	.381	.5716	.5335	.5144	.5716	.5716	.5144
24	.5525	.3429	.381	.4572	.4287	.4382	.4191
Max	.9526	.8573	.9526	.7716	1.0098	.9526	.8573
Min	.381	.3429	.381	.4191	.3239	.3429	.381
Avg	.6145	.5620	.6311	.5322	.6058	.6081	.5376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1334	.1334	.12	.1334	.1334
2	.1524	.1524	.1334	.1334	.12	.1334	.1334
3	.1524	.1524	.1334	.1334	.12	.1334	.1334
4	.1524	.1524	.1334	.1334	.1372	.1334	.1334
5	.1524	.1524	.1334	.1334	.1543	.1334	.1524
6	.1905	.1905	.1905	.1715	.1715	.1715	.1905
7	.2286	.2096	.2096	.2477	.2229	.1715	.2286
8		.2477	.2286	.2286	.1715	.2477	.2096
9	.1905	.2096	.1715	.1886	.1886	.2096	.1886
10	.2667	.1905	.2286	.1715	.1905	.2286	.1372
11	.2477	.1905	.2477	.12	.2096	.2286	.2058
12	.2286	.1715	.2286	.1029		.2667	.2058
13	.2286	.2096	.1905	.12	.1524	.2286	.1543
14	.2096	.2286	.1715	.12	.1715	.2286	.1886
15	.1905	.2667	.1905	.1372	.1715	.2477	.2058
16	.2286	.2667	.2477	.1543		.2477	.2229
17	.2858	.3048	.2858	.1715	.2858	.2477	.2401
18	.2667	.3239	.2286	.1715	.2858	.3239	.2401
19	.3239	.2858	.2667	.2401	.3048	.3429	.2915
20	.3429		.3048	.2401	.3048	.2858	.3086
21			.2667	.2401	.2858	.2667	.2572
22	.1524		.2286	.1886	.2477	.2286	.2058
23	.1905	.2286	.1905	.1543	.1543	.1905	.1715
24	.1905	.1715	.1715	.1524	.1372	.1524	.1524
Max	.3429	.3239	.3048	.2477	.3048	.3429	.3086
Min	.1524	.1524	.1334	.1029	.12	.1334	.1334
Avg	.2148	.2123	.2048	.1662	.1958	.2159	.1955

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 205 / 11 KV INJOLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.0857	.1143	.0953
2	.1143	.1143	.1143	.1143	.0857	.1143	.0953
3	.1143	.1143	.1143	.1143	.0857	.1143	.0953
4	.1143	.1143	.1143	.1143	.0857	.1143	.0953
5		.1143	.1143	.1143	.1029	.1143	.1143
6		.1334	.1334	.1524	.12	.1524	.1524
7	.0762	.1334	.1334	.1524	.12	.1715	.1715
8	.0953	.1524	.1524	.1715	.1029	.1715	.1524
9	.0953	.1715	.2096	.1543	.12	.1905	.12
10	.1715	.1715	.1715		.1524	.1715	.1715
11	.1715	.1715	.1905	.1372	.1715	.1715	.1543
12	.1905	.1715	.1524	.3086		.1524	.1372
13	.1905	.1715	.1524	.24	.1524	.1524	.12
14	.1905	.1715	.1334	.12	.1524	.1524	.12
15	.1715	.1715	.1905	.1543	.1715	.1524	.12
16	.1715	.1715	.2858	.12	.1524	.1524	.12
17	.1905	.1334	.1715	.1494	.1715	.1715	.1372
18	.1715	.1715	.2096	.1886	.2096	.2286	.1543
19	.2667	.2286	.2667	.2229	.2286	.2477	.1715
20	.2858		.2858	.1886	.2667	.2667	.2058
21	.1524		.2477	.1543	.2477	.2477	.1715
22	.1334		.1905	.1029	.2286	.1905	.1543
23	.1143	.1524	.1524	.1029	.1143	.1524	.1372
24	.1334	.1143	.1524	.1143	.1029	.1143	.1143
Max	.2858	.2286	.2858	.3086	.2667	.2667	.2058
Min	.0762	.1143	.1143	.1029	.0857	.1143	.0953
Avg	.1559	.1506	.1731	.1524	.1492	.1659	.1367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 206 / 11kv Broadcast Express NON SHEDDABLE EXPRESS HV FEEDERS  
 feeder Feeder KV- 11 / OUTGOING (NON-CONTINOUS PROCESS)(NO  
 STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0514	.0572	.0572
2	.0572	.0572	.0572	.0572	.0514	.0572	.0572
3	.0572		.0572	.0572	.0514	.0572	.0572
4	.0572	.0572	.0572	.0572	.0514	.0572	.0572
5	.0572	.0191	.0572	.0572	.0514	.0572	.0572
6	.0762	.0191	.0572	.0762	.0686	.0762	.0572
7	.0762	.0191	.0572	.0762	.0686	.0762	.0762
8	.0762	.0762	.0572	.0762	.0686	.0762	.0762
9	.0762	.0762	.0762	.0686	.0686	.0762	.0686
10	.0762	.0762	.0762	.0686	.0762	.0762	.0686
11	.0762	.0762	.0762	.0171	.0762	.0762	.0686
12	.0762	.0762	.0762	.0686		.0762	.0686
13	.0762	.0762	.0762	.0686	.0762	.0762	.0686
14	.0762	.0762	.0762	.0686	.0762	.0762	.0686
15	.0762	.0762	.0762	.0686	.0762	.0762	.0686
16	.0762	.0762	.0762	.0686	.0762	.0762	.0686
17	.0762	.0762	.0762	.0686	.0762	.0762	
18	.0762	.0762	.0191	.0686	.0762	.0762	.0686
19	.0762	.0762	.0762	.0686	.0762	.0762	.0686
20	.0762		.0762	.0686	.0762	.0762	.0686
21	.0762		.0762	.0686	.0762	.0762	.0686
22	.0762		.0762	.0686		.0762	.0686
23	.0762	.0762	.0762	.0514	.0762	.0762	.0686
24	.0572	.0572	.0762	.0572	.0514	.0762	.0572
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0762
Min	.0572	.0191	.0191	.0171	.0514	.0572	.0572
Avg	.0715	.0638	.0675	.0638	.0681	.0722	.0658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 207 / 11Kv Mitharwadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1143	.1905	.1524	.2572	.2439	.3048
2	.1905	.1143	.1905	.1524	.2572	.2439	.3048
3	.1905	.1143	.1905	.1524	.2572	.2439	.3048
4	.1905	.1143	.1905	.1524	.2743	.2439	.3048
5	.1905	.1143	.1905	.1905	.2915	.2439	.3048
6	.1905	.1334	.2096	.2286	.3294	.2896	.3048
7	.2477	.1524	.2096	.2667	.4287	.3048	
8	.2286	.1524	.1905	.1905	.4115	.3201	.0762
9	.2096	.1715	.1905	.1715	.1886	.4191	.2229
10	.5335	.1219	.4572	.1715	.1905	.4191	.3258
11	.9145	.381	.6097	.1372	.2286	.4191	.2743
12	1.0288	.381	.5716	.1372		.4191	.1372
13	1.1431	.1677	.6097	.1372	.381	.4191	.4458
14	1.0669	.381	.6097	.1372	.381	.4191	.2743
15	.9907	.381	.6097	.1372	.381	.4191	.2915
16	.9145	.3353	.6859	.1886		.4191	.2743
17	.8383	.3048	.6478	.1715	.4572	.4191	.2915
18	.1524	.2096	.1715	.2058	.4572	.4191	.3258
19	.2286	.2286	.1905	.2401	.4763	.4191	.3601
20	.2286		.2286	.2058	.4763	.4382	.3601
21			.2286	.2229	.4763	.4382	.3601
22	.1524		.1905	.2229	.4763	.4191	.3601
23	.1524	.2286	.1905	.2572	.2439	.3048	.3086
24	.1905	.1334	.1905	.1715	.2572	.3048	.3048
Max	1.1431	.381	.6859	.2667	.4763	.4382	.4458
Min	.1524	.1143	.1715	.1372	.1886	.2439	.0762
Avg	.4506	.2112	.3310	.1834	.3445	.3604	.2966

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 208 / Waghave Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
2	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
3	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
4	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
5	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
6	1.1431	.0191	.0191	.0572	.0343	.0381	.0381
7	1.5432	.0191	.0191	.0762	.0343		.0381
8	1.5432	.0191	.0572	.0762	.0343	.0381	.0572
9	.0762	.0191	.4572	.0514	.0171	.0381	.0343
10	2.21	.0191	.7621	.0514	.0191	.0381	.0171
11	2.21	.0152		.0171	.0191	.0381	.0171
12	2.1719	.0152	.7621	.0171		.0191	
13	2.0957	.0152	.9526	.0171	.0191	.0381	
14	2.0195	.0191	1.1431	.0171	.0191	.0191	
15	1.9052	.2439	1.1431	.0171	.0191	.0191	
16	1.829	.2439		.0171	.0191	.0191	
17	1.7147	.2134	.9907	.0171	.0381	.0191	
18	.0762	.0762	.0572	.0171	.0572	.0191	.0343
19	.0762	.0762	.0762	.0171	.0381	.0191	.0343
20	.0762		.0762	.0171	.0381	.0381	.0343
21	.0191		.0762	.0171	.0381	.0381	.0171
22	.0191		.0572	.0171	.0381	.0381	.0171
23	.0191	.0381	.0572	.0343	.0381	.0381	.0343
24	.8192	.0191	.0381	.0572	.0343	.0381	.0381
Max	2.21	.2439	1.1431	.0762	.0572	.0381	.0572
Min	.0191	.0152	.0191	.0171	.0171	.0191	.0171
Avg	1.1368	.0555	.3109	.0373	.0316	.0323	.0334



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 209 / 11KV INJOLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.2286	.1829	.1905	.0171	.0191	.0191
2	.0191	.2286	.1829	.1905	.0171	.0191	.0191
3	.0191	.2286	.1829	.1905	.0171	.0191	.0191
4	.0191	.2286	.1829	.1905	.0171		.0191
5	.0191	.2286	.1829	.1905	.0171		.0191
6	.0191	.3048	.1829	.2286	.0171	.0191	.0191
7	.0191	.3239	.2286	.2667	.0171	.0191	.0191
8	.0191	.3429	.2743		.0171	.0191	.0191
9	.0191	.0191	.0191	.0171	.0171	.0191	.0171
10	.0191	.0191	.0191		.0762	.1143	.0857
11	.0191	.0191	.0191		.1219	.1334	.0857
12	.0191	.0191	.0191	.2229		.1334	.1029
13	.0191	.0191	.0191	.2229	.0762	.1334	.1029
14	.0191	.0191	.0191	.2401	.0762	.1334	.1029
15	.0191	.0191	.0191	.2572	.0762	.1143	.1029
16	.0191	.0191	.0191		.0762	.1143	.1029
17	.0191	.0191	.0191		.1067	.1143	.1029
18	.0191	.0191	.0191	.0171	.0191	.0191	.0171
19	.0191	.0191	.0191	.0171	.0191	.0191	.0171
20	.0191		.0191	.0171	.0191	.0191	.0171
21	.0191		.0191	.0171	.0191	.0191	.0171
22	.0191		.0191	.0171	.0191	.0191	.0171
23	.0191	.1981	.1905	.0171	.0191	.0191	.0171
24	.0191	.2286	.1829	.1905	.0171	.0191	.0191
Max	.0191	.3429	.2743	.2667	.1219	.1334	.1029
Min	.0191	.0191	.0191	.0171	.0171	.0191	.0171
Avg	.0191	.1310	.0934	.1422	.0389	.0572	.0450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 201 / 11 KV DIGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.12	.1372	.1029	.1509	.12	.1029
2	.1372	.12	.1372	.1029	.1509	.12	.1029
3	.1372	.12	.1372	.1029	.1509	.12	.1029
4	.1372	.12	.1372	.1029	.1509	.12	.1029
5	.1543	.12	.1543	.12	.1886	.1372	
6	.1715	.1372	.1543	.1372	.1848	.1543	
7	.1886	.1715	.1372	.1372	.1663	.1543	
8	.1886	.1543	.1543	.1543	.1629	.1543	.1886
9	.1886		.1612	.1372	.1612	.1372	.1715
10	.1715	.1372	.1791	.1543	.12	.1433	.1715
11	.1372	.1543	.1791	.1543	.1372	.1433	.1715
12	.1715	.1543	.1433	.12	.1372	.1433	.1715
13	.1715		.1433	.12	.12	.1254	.1715
14	.12	.1715	.1595	.1029	.1543	.1433	.1715
15	.1029	.1715	.1772	.12	.1372	.1433	.1715
16	.12	.1543	.1543	.12	.12	.1715	.1715
17	.2058	.1543	.12		.1372	.1543	.1734
18	.1715	.1543	.1543	.1791	.1543	.1715	.1753
19	.2058	.1886	.1886	.2561	.2058	.1543	.197
20	.2572	.2229	.1543	.2427	.2058	.1715	.2195
21		.2058	.1372	.2427	.1886	.1715	.2218
22		.2058	.1543	.1867	.1715	.1543	.2054
23	.12	.1372	.12	.168	.1372	.12	.168
24	.1698	.12	.1372	.1029	.1509	.12	.1029
Max	.2572	.2229	.1886	.2561	.2058	.1715	.2218
Min	.1029	.12	.12	.1029	.12	.12	.1029
Avg	.1628	.1543	.1505	.1464	.1560	.1437	.1636

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9755		.0457	.0857	.0343	.1829	.0686
2	1.0059		.0457	.0857	.0343	.1677	.0686
3	1.0059			.0857	.0343	.1677	.0686
4	1.0517			.0857	.0343	.1524	.0686
5	1.2346		.061	.0857	.0343	.1524	.0686
6	1.3717		.061	.1029	.0514	.1524	.0686
7	2.1186		.061	.12			.12
8	1.0288		.0762	.1372		.1829	
9	.0343		.0701	.1372		.0305	
10	2.4177		1.0486	1.2498		.0343	
11	2.5892		1.704	1.5699			
12	2.8807	.5792	1.7695	1.6004			
13	2.8121	.9755	1.7368	1.5851	.0686		
14	2.8121	1.326	1.7695	1.6004	.0686		
15	2.7778	1.3717	1.7695	1.5394	.0457		.0343
16	2.8121		1.5851		.0305	.0343	.0343
17	2.5034	1.387	1.5242		.0305	.0514	.0343
18	.1543	.1372	.0686		.0305	.0514	.0343
19	.0857	.0914	.12		.061	.0514	.0343
20	.0686	.061	.1029	.0514	.061	.0514	.0343
21		.061	.1029	.0343	.0457	.0343	.0343
22	.0686	.0457	.1029	.0343	.0457	.0343	.0343
23	.0686	.0457	.0857	.0343	.0457	.0762	.0457
24	.0914		.0457	.0857	.0343	.1829	.0762
Max	2.8807	1.387	1.7695	1.6004	.0686	.1829	.12
Min	.0343	.0457	.0457	.0343	.0305	.0305	.0343
Avg	1.3900	.5529	.6344	.5155	.0439	.0995	.0546

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 203 / 11 KV GHOTWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	.0857	.1543	.1372	.1509	.12	.1543
2	.1372	.0857	.1543	.1372	.1509	.12	.1543
3	.1372	.0857	.1543	.1372	.1509	.12	.1543
4	.1372	.0857	.1543	.1372	.1509	.12	.1543
5	.1543	.0857	.1715	.1543	.168	.1372	.1886
6	.1715	.0857	.2058	.1543	.2033	.1886	.2058
7	.2229	.0857	.2401	.1543	.2402	.2401	.2229
8	.2401		.2572	.2229	.2896	.2229	.2572
9	.2401		.2454	.1886	.2686	.1886	.2572
10	.2058	.1543	.2629	.1715	.2401	.2279	
11	.1715	.2401	.2279	.1715	.3944	.2103	.2058
12	.1372	.2229	.1928	.0686	.2229	.2454	.2058
13	.1715	.2401	.1928	.1543	.2401	.2454	.2229
14	.2058	.2572	.1753		.2229	.2103	.2058
15	.1715	.2229	.2103		.2401	.2279	.2058
16	.12	.1886	.2229			.2401	.2229
17	.2743	.2743	.2401		.2915	.2915	.2229
18	.2915	.2915	.2572	.0701	.3086	.3258	.2743
19	.4115	.3772	.3429	.3292	.3258	.3772	.3582
20	.4115	.3944	.3772	.3547	.3601	.3601	.3658
21		.3601	.3258	.3174	.3086	.3429	.3326
22	.1543	.2743	.2587	.2241	.2572	.2572	.2801
23		.1715	.1715	.1886	.1886	.1715	.1867
24	.1886	.0857	.1543	.1372	.1698	.12	.1543
Max	.4115	.3944	.3772	.3547	.3944	.3772	.3658
Min	.12	.0857	.1543	.0686	.1509	.12	.1543
Avg	.2050	.1980	.2229	.1805	.2410	.2213	.2258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 204 / 11 kv Digavade Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658		.0305	.0152	.0354	.0762	.0305
2	.3658		.0305	.0152	.0354	.0762	.0305
3	.4115		.0305	.0152	.0354	.0762	.0305
4	.4268		.0305	.0152	.0354	.0762	.0312
5	.5182		.0305	.0152	.0354	.0762	.0305
6	.6249		.0305	.0152	.0354	.0762	.0305
7	1.0669		.0305	.0152		.1067	.0762
8	1.6118		.0305	.0152		.1219	
9			.056	.0305		.0305	
10			.5761	.6097		.0343	.0343
11			.7362	.7621		.0343	
12	1.7147	.442	.8097	.7926	.0305	.0343	
13	1.5261	.4268	.8421	.8383	.0305	.0343	
14	1.8861	.4268		.8535	.0305	.0343	
15	1.9033		.8421	.8078	.0305	.0343	
16	1.8861	.381	.7926	.6249	.0305	.0305	
17	1.2803	.3506	.7164		.0305	.0305	
18	1.1584		.0305	.0532	.0305	.0305	
19	.9755	.0457	.0305	.0532	.0305	.0305	
20	.0343	.0457	.0305	.0354	.0305	.0305	.0343
21		.0514	.0305	.0354	.0305	.0305	.0343
22	.0343	.0343	.0305	.0354	.0305	.0305	.0343
23	.0343	.0305	.0305	.0354	.0305	.0305	.0457
24	.0324	.0343	.0343	.0305	.0354	.0762	.0305
Max	1.9033	.442	.8421	.8535	.0354	.1219	.0762
Min	.0324	.0305	.0305	.0152	.0305	.0305	.0305
Avg	.8929	.2063	.2536	.2487	.0323	.0518	.0364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2401	.2401	.2572	.2641	.2058	.2401
2	.2401	.2401	.2401	.2572	.2641	.2058	.2401
3	.2401	.2401	.2401	.2572	.2641	.2058	.2401
4	.2401	.2401	.2572	.2572	.2641	.2229	.2572
5	.2572	.2401	.2743	.2743	.2829	.2572	.2743
6	.2915	.2401	.2915	.2743	.3142	.2915	.3086
7	.2915	.2743	.2743	.2915	.3326	.2743	.3429
8	.2915		.2915	.3258	.3475	.3258	.3086
9	.3086	.3429	.3439	.3601	.3475	.3429	.3429
10	.2743	.3258	.3224	.3258	.4115	.3403	.3429
11	.2401	.3258	.3403	.3258		.3224	.3086
12	.2401	.3086	.3761	.3429	.3944	.3982	.2915
13	.2229	.3086	.3403	.3086	.4287	.3086	.2743
14	.3429	.2915	.3224	.2915	.3772	.2572	.2743
15	.3429		.394	.3258	.4115	.2572	
16	.3086	.3944	.3772	.2915	.3772	.3601	
17	.3944		.3601		.3944	.3944	.3856
18	.4115	.3944	.3772	.3761	.3601	.4115	.4298
19	.4458	.4801	.3772	.462	.463	.463	.4938
20	.463	.5144	.4973	.4668	.4801	.4801	.499
21		.4801	.4115	.4668	.4115	.4458	.4668
22	.3258	.4115	.3772	.3734	.3258	.3258	.3921
23	.2401	.3086	.3086	.3206	.2572	.2915	.2987
24	.2829	.2572	.2572	.2743	.2829	.2229	.2401
Max	.463	.5144	.4973	.4668	.4801	.4801	.499
Min	.2229	.2401	.2401	.2572	.2572	.2058	.2401
Avg	.3016	.3266	.3288	.3264	.3503	.3171	.3297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 206 / 11 KV GHOTWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2058	.0514	.0532		
2		.2058	.0514	.0532		
3		.2058	.0514	.0532		
4		.2915	.0514	.0532		
5		.2915	.0686	.0532		
6		.3772	.0686	.0709		
7		.4801	.1543	.0686		
8		.583		.0686		
9			.5281			
10				.0857	.0514	
11	.4801				.0514	
12	.5144			.2058	.0514	.2572
13				.1886		.2401
14				.0514	.2058	.2401
15				.0514	.2229	.1715
16						.1715
17					.1886	.1886
23	.2229	.2229				
24		.2229	.2229	.0709		
Max	.5144	.583	.5281	.2058	.2229	.2572
Min	.2229	.2058	.0514	.0514	.0514	.1715
Avg	.4058	.3087	.1387	.0806	.1286	.2115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	.0191		.0381		.0381	
2	1.5242	.0191	.6478	.0381		.0381	.0381
3	1.5242	.0191	.7621	.0381		.0381	.0381
4	1.6004	.0191	.8002	.0381		.0381	.0381
5	1.7147	.0191	.8573	.0381		.0381	.0381
6	2.0957	.0191	1.0288	.0381		.0381	.0381
7	2.2481	.0191	1.2193	.0381			.0381
8	2.3624	.0191	1.4861	.0381		.0381	.0381
9	.0381	.0381	.0381	.0381		.0381	.0381
10	.0381	.0381	.0381	1.0669		.381	.1524
11		.0381		1.3527	.0191	.381	.4382
12			.0381	1.6004	.381		.5335
13					.3429		.4572
14	.0381		.0381	1.7528		.5144	.4572
15	.0381			1.6575	.2667	.5144	.4572
16			.0381	1.5242	2.7435	.4954	.4572
17	.0381		.0381		.4191	.362	.5144
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381		.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21		.0381	.0381		.0381	.0381	.0381
22	.0191	.0381	.0381		.0381	.0381	.0381
23	.0191	.6097	.0381		.0381	.0381	.1715
24	1.4861	.0191	.5716	.0381		.0381	.0381
Max	2.3624	.6097	1.4861	1.7528	2.7435	.5144	.5335
Min	.0191	.0191	.0381	.0381	.0191	.0381	.0381
Avg	.8644	.0604	.3915	.5514	.3667	.1533	.1814



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 202 / 11 kv Chande Sheti Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.7621		.3429	.1143
2	.0381	.0381	.0381	.7621		.3429	.1143
3	.0381	.0381	.0381	.7621		.381	.1143
4	.0381	.0381	.0381	.8573		.381	.1143
5	.0381	.0381	.0381	.8573		.381	.1143
6	.0381	.0381	.0381	.9526		.381	.2286
7	.0381	.0381	.0381	1.2384			.2667
8	.0381	.0381	.0381	1.2574		.5525	.3239
9	.0381	.0381	.0381	.0381		.0381	.0381
10	3.1436	3.4294	1.7147	.0381	.0381	.0381	.0381
11	3.658	3.9057	1.8099	.0381	.0381		.0381
12	3.8866	3.7342	2.2672	.0381	.0381		.0381
13	4.1533	3.4294			.0381		.0381
14	4.1343		1.9624	.0381			.0381
15	3.5437				.0381		.0381
16	3.0483		1.9814				.0381
17	3.0674	1.9433	2.0005	.0381	.0381		.0381
18	.0381	.0381	.0381	.0381	.0381		.0381
19	.0381	.0381	.0381		.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21		.0381	.0381		.0381	.0381	.0381
22	.0381	.0381	.0381		.0381	.0381	.0381
23	.0381	.0381	.7621		.381	.1143	.0381
24	.0381	.0381	.0381	.7621		.3429	.1143
Max	4.1533	3.9057	2.2672	1.2574	.381	.5525	.3239
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	1.2699	.8120	.5941	.5299	.0667	.2299	.0865

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7147	1.4098	.381	.0381		.0381	.0381
2	1.7147	1.2193	.381	.0381		.0381	.0381
3	1.7147	1.2193	.381	.0381		.0381	.0381
4	1.7147	1.2193	.381	.0381		.0381	.0381
5	1.8671	1.3336	.0191	.0381		.0381	.0381
6	2.0576	1.5813	.0191	.0381		.0381	.0381
7	2.1719	2.2862	.4382	.0381			.0381
8	2.2672	2.5149	.743	.0381		.0381	.0381
9	.0381	.0381	.0381	.0381		.0381	.0381
10	.0381	.0381	.0381		.0381	.1905	.0953
11	.0381	.0381		.6478	.5716	.1905	.1715
12	.0381	.0381			.6478	.1905	.2667
13		.0381			.5144	.1905	.1905
14			.0381	.5716		.1905	.1715
15				.6478	.4382	.1905	.1524
16			.0381	.7621	.3239	.1905	.1524
17			.0381	.6287	.3048	.1905	.0953
18		.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381		.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21		.0381	.0381		.0381	.0381	.0381
22		.0381	.0381		.0381	.0381	.0381
23	1.2955	.4191	.0381		.0381	.0381	.0953
24	.4287	1.4098	.381	.0381			.0381
Max	2.2672	2.5149	.743	.7621	.6478	.1905	.2667
Min	.0381	.0381	.0191	.0381	.0381	.0381	.0381
Avg	1.0735	.7497	.1772	.2298	.2360	.0935	.0818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 204 / 11 KV Arale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.4763		.0381	.0381
2				.4763		.0762	.0381
3				.4763		.0762	.0381
4				.5716		.0953	.0381
5				.6668		.0953	.0762
6				.7621		.1334	.1524
7				.8192			.1905
8				.9335		.362	.2667
10	1.0098						
11	1.2765		.8192				
12	1.2384		1.0288				
13	1.3146	.7621					
14	1.2003						
15	1.1622						
16	1.0479		1.0669				
17	1.0669		1.0288				
18		.6668					
23			.4191		.0381	.0381	
24				.4763		.0381	.0381
Max	1.3146	.7621	1.0669	.9335	.0381	.362	.2667
Min	1.0098	.6668	.4191	.4763	.0381	.0381	.0381
Avg	1.1646	.7145	.8726	.6287	.0381	.1059	.0974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 205 / 11 kv M. Shirolgi Gaothan  
fdr Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2477	.2286	.2286	.2286	.2286
2	.2667	.2667	.2477	.2286	.2286	.2286	.2286
3	.2667	.2667	.2858	.2286	.2286	.2667	.2286
4	.2667	.3048	.2858	.2667	.2286	.3048	.2286
5	.3429	.1524	.2858	.3048	.2858	.362	.2667
6	.4572	.2286	.4191	.381	.381	.4001	.381
7	.4191	.362	.4001	.3048	.381		.4191
8	.381	.362	.381	.2667	.3429	.3239	.381
9	.3429	.381	.381	.3048	.2667	.3239	.3429
10	.3048	.3429	.381	.3048	.2286	.2667	.3429
11	.2477	.3429	.362	.3048	.2286	.2667	.3239
12	.2858	.2667	.381	.3048	.2286		.3239
13	.2667	.1905			.2286	.2667	.3048
14	.2667		.362	.3048			.2477
15	.3048			.3048		.2667	.3048
16	.2667		.2286	.3048	.2286	.2667	.3048
17	.2667		.362	.3048	.4001	.3048	.2477
18	.4191	.381	.381		.3429	.381	.3048
19	.4191	.4572	.4001		.4001	.4572	.4191
20	.5144	.5144	.4763		.4954	.4572	.4572
21	.381	.4572	.4572	.2667	.4001	.4191	.4572
22	.3239	.3048	.4001	.2667	.2667	.381	.4191
23	.2858	.2477	.2477	.2286	.2667	.2477	.3048
24	.1715	.2667	.2477	.2286	.2286	.2286	.2286
Max	.5144	.5144	.4763	.381	.4954	.4572	.4572
Min	.1715	.1524	.2286	.2286	.2286	.2286	.2286
Avg	.3223	.3181	.3464	.2819	.2962	.3166	.3207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 206 / 11 Kv Chande Gavthan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.0953	.1143	.1143	.1143
2	.1143	.1143	.1143	.0953	.1143	.1143	.1143
3	.1143	.1143	.1143	.0953	.1143	.1334	.1143
4	.1143	.1143	.1334	.1143	.1143	.1334	.1143
5	.1524	.1524	.1524	.1524	.1524	.1524	.1334
6	.1905	.2286	.1524	.2286	.2286	.1524	.1905
7	.1905	.2286	.1524	.1905	.1905		.2286
8	.1905	.2096	.1524	.1524	.1524	.1524	.2286
9	.1905	.1905	.1143	.1143	.1524	.1524	.1905
10	.1905	.1715	.1524	.1143	.1143	.1334	.1905
11	.1905	.1905	.1524	.1143	.1143	.1334	.1905
12	.1905	.1715	.1334	.1143	.0953	.1334	.1905
13	.1905	.1715			.0953	.1334	.1905
14	.1905		.1143	.1143		.1334	.2096
15	.2096			.1143	.1143	.1334	.2096
16	.2096		.1143	.1143	.1143	.1334	.2096
17	.2096		.1524	.1524	.1143	.1524	.1905
18	.2286	.1143	.1524	.1524	.1715	.2286	.1905
19	.2858	.1905	.1905		.2096	.2667	.1905
20	.3048	.2286	.2286		.1905	.2667	.2286
21		.1905	.2286	.1905	.1524	.2286	.1905
22	.2286	.1524	.1524	.1524		.1905	.1905
23	.1905	.1334	.1143	.1143	.1143	.1334	.1524
24	.1715	.1334	.1143	.0953	.1143	.1143	.1143
Max	.3048	.2286	.2286	.2286	.2286	.2667	.2286
Min	.1143	.1143	.1143	.0953	.0953	.1143	.1143
Avg	.1897	.1658	.1455	.1325	.1386	.1574	.1778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan

GAOTHAN FEEDER

Feed Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2667	.2667	.2858	.2667	.2667	.2477
2	.2667		.2858	.2858	.2667	.3048	.2477
3	.2667		.2858	.2858	.2667	.362	.2477
4	.2667		.3048	.3048	.2667	.4001	.2667
5	.3429		.3429	.381	.3429	.4572	.3429
6	.4572		.5335	.5335	.5716	.5335	.4191
7	.4572	.4572	.5335	.4954	.5335		.4572
8	.4572	.4572	.4954	.381	.5335	.4954	.4191
9	.381	.4382	.4763	.362	.381	.4191	.381
10	.381	.381	.4191	.362	.2667	.3048	.381
11	.381	.4001	.4001	.362	.1905		.381
12	.381	.381	.4382		.1905	.2858	.381
13	.381	.5335			.2667	.2858	.381
14	.381		.4191	.362		.2667	.3429
15	.4191			.362	.2858	.2667	.381
16			.381	.362	.3239	.2667	.381
17	.4191		.4191	.381	.3429	.3048	.381
18	.4191	.4382	.4572	.381	.4954	.4191	.4191
19	.5335	.5335	.4954		.5906	.4954	.4382
20	.5906	.5716	.5525		.5906	.4954	.4572
21	.4001	.4954	.5335	.5335	.5525	.4572	.4191
22	.4001	.362	.4572	.381	.362	.381	.4191
23		.2858	.3048	.3048	.2667	.2667	.3048
24	.2667	.2667	.2667	.2858	.2667	.2667	.2477
Max	.5906	.5716	.5525	.5335	.5906	.5335	.4572
Min	.2667	.2667	.2667	.2858	.1905	.2667	.2477
Avg	.3871	.4179	.4122	.3696	.3661	.3637	.3643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 208 / 11 kv ARALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0762	.0572
4	.0572	.0762	.0572	.0762	.0572	.0762	.0572
5	.0762	.0953	.0762	.0953	.0762		.0572
6	.1143	.1143	.1143	.1143	.1334	.1143	.0953
7	.1143	.1143	.1334	.0762	.1334		.1143
8	.0953	.0953	.1143	.0762	.0953	.0953	.1143
9	.0953	.0762	.0953	.0762	.0953	.0953	.0953
10	.0953	.0762	.0953		.0953	.0762	.0953
11	.0762	.0762	.0762	.0762	.0953	.0762	.0953
12	.0762	.0762	.0762	.0762	.0953	.0762	.0953
13	.0572	.0762			.0762	.0762	.0762
14	.0762		.0953	.0762		.0762	.0572
15	.0762			.0762	.0762	.0762	.0762
16	.0572		.0572	.0762	.0762	.0762	.0762
17	.0572		.0953	.0762	.0953	.0762	.0572
18	.1143	.1334	.1143	.0762	.1143	.0762	.0762
19	.1524	.1524	.1334		.1334	.1143	.1143
20	.1715	.1715	.1524		.1334	.1334	.1524
21		.1524	.1334	.0762	.1334	.1143	.1334
22	.1143	.1143	.1143	.0762	.0762	.0953	.1143
23	.0762	.1143	.0762	.0572	.0762	.0762	.0762
24	.1715	.0572	.0762	.0572	.0572	.0572	.0572
Max	.1715	.1715	.1524	.1143	.1334	.1334	.1524
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0911	.0972	.0935	.0743	.0911	.0840	.0858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 201 / 11 Kv Bachani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.8779	.1372	.0497	.0381	.0343	.0332
2	.7716	.8676	.1372	.0497	.0381	.0343	.0335
3	.7202	.7888	.1372	.0492	.0381	.0343	.0328
4	.7202	.823	.1372	.0509	.0381	.0343	.0332
5	.8059	1.0185	.1715	.0492	.0381	.0343	.0328
6	.8745	1.1317		.0492	.0381	.0343	.0328
7	1.5261	1.3717	.2058	.0492	.0381	.0343	.0328
8	1.5947	1.7353	.2572	.0492	.0381	.0343	.0328
9	.0566	.0332	.0514	.0343		.0343	.0332
10	.0377	.0328	.0572	.3429		.1905	.2294
11	.0377	.0328	.0572	.3772		.2096	.2294
12	.0354	.0328	.0572	.8299		.1334	.2294
13	.0377	.0328	.0381	.7922	.2401	.1334	.1966
14	.0366	.0492		.7545	.2401	.1334	.1638
15	.0566	.0492	.0381	.679	.2058	.1143	.1658
16	.0754		.0381	.6224		.0381	.1905
17	.0566	.0514	.0332	.4115	.0343	.0655	
18	.0549	.0514	.0332		.0343	.0497	.0381
19	.0377	.0514	.0328	.0762	.0343	.0328	
20	.0343	.0514	.0332	.0381	.0343	.0328	.0381
21	.0377	.0514	.0663	.0381	.0343	.0332	.0381
22	.0343	.0514	.0655	.0381	.0343	.0328	.0381
23		.1543	.0497	.0381		.0328	.0953
24	.823	.9054	.1372	.0492	.0381	.0343	.0328
Max	1.5947	1.7353	.2572	.8299	.2401	.2096	.2294
Min	.0343	.0328	.0328	.0343	.0343	.0328	.0328
Avg	.4016	.4455	.0896	.2399	.0686	.0656	.0901



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 202 / 11 Kv Nandgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.12			.0191	.0171	.1147
2	.1524	.128	.0171		.0381	.0171	.116
3	.1524	.12	.0171		.0381	.0171	.1475
4	.1524	.12	.0171		.0381	.0171	.1638
5	.1524	.1372	.0171		.0381	.0171	.1619
6	.1524	.1372	.0171		.0191	.0171	.1638
7	.1524	.1715	.0171		.0191	.0171	.1638
8	.1715	.2401	.0171		.0572	.0171	.2321
9	.1886	.2155	.0171			.0171	.0819
10	1.6221	1.989					.0819
11	2.4897	2.6023	.5144	.0943			.0995
12	2.5652	2.3137		.4801	.0686		.0655
13	2.6406	2.2939	.1524	.0754	.0686	.1905	.0655
14	2.6595	2.2775	.4801	.0686		.0762	.0655
15	2.6406	2.0481	.6516	.0857		.0762	.0663
16	2.5652		.6687	.1132		.1143	.0953
17	2.2634		.6062	.1143		.0983	.0762
18	.1509	.0171	.0819			.0983	.0762
19	.1829	.0171	.0819		.0171	.0819	.0953
20	.1715	.0171	.0829	.1905	.0171	.0819	.0381
21	.1543	.0171	.0819		.0171	.0819	.0953
22	.1372	.0171	.0819	.1715	.0171	.0655	.0953
23		.0171		.0191	.0171	.1658	.0953
24	.1524	.1372	.0171		.0191	.0171	
Max	2.6595	2.6023	.6687	.4801	.0686	.1905	.2321
Min	.1372	.0171	.0171	.0191	.0171	.0171	.0381
Avg	.9488	.6888	.1819	.1413	.0318	.0620	.1068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 203 / 11 kv Ispurli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2452	.1029	.6154	.6001	.3944	.2753
2	.2477	.2378	.1029	.6154	.6001	.3944	.2915
3	.2477	.2058	.1029	.6478	.583	.3944	.3239
4	.2477		.1029	.6478	.583	.3944	.3401
5	.2667	.2303	.1029	.6802	.6001	.3944	.3401
6	.2667	.2378	.1029	.664	.6516	.4115	.3563
7	.2858	.3429	.1029	.8097	.7373	.4115	.4049
8	.3239	.415	.1029	.9069	.7716	.6173	.5506
9	.3206	.3725		.1715		.1372	.1326
10	1.5844	1.668		.1715		.1905	.1296
11	2.3388	2.2834	.4458	.1715	.1372	.1524	.1296
12	2.3045	2.2996		.1698	.1715	.1524	.0972
13	2.1125	2.1538		.1372	.1543	.1524	.0972
14	2.0748	2.0809	.8573			.1524	.0983
15	2.1502	2.0481	.9259			.1524	.0972
16	2.1313		1.0117	.2075		.1715	.1334
17	1.9616		.9393	.2096		.1457	.1524
18	.2641	.1029	.1943		.12	.1457	.1524
19	.3018	.1029	.1781	.1905	.1372	.1457	.1905
20	.2572	.1029	.1457	.1905	.1372	.1457	.1715
21	.2401		.1296	.1715	.1372	.1457	.1715
22	.2058	.1029	.1619	.1715	.1372	.1296	.1715
23		.1029	.6478	.583	.4115	.3239	.1715
24	.2667	.2561	.1029	.5992	.6001	.3944	.2915
Max	2.3388	2.2996	1.0117	.9069	.7716	.6173	.5506
Min	.2058	.1029	.1029	.1372	.12	.1296	.0972
Avg	.8974	.7796	.3282	.4158	.4039	.2604	.2196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038]

BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 204 / 11 Kv Bachani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.4715	.4458	.4572	.4287	.4115	.4382
2	.4458	.4527	.4287	.4572	.4287	.3772	.4191
3	.4458	.4287	.463	.4763	.4458	.4115	.4572
4	.4973	.463	.5144	.5144	.4458	.4801	.5144
5	.5487	.5144	.583	.5906	.4973	.5144	.5335
6	.6687	.6767	.6516	.6478	.6001	.6173	.6478
7	.6001	.6224	.6001	.6859	.6001	.6173	.6478
8	.5316	.567	.5487	.6478	.5487	.5487	.5716
9		.5716	.5144	.547		.4973	.4954
10	.5658	.4572	.5316	.547		.4973	.4954
11	.5093	.5716	.4973	.4527	.4115	.4458	.381
12	.5658	.5335	.4973	.5281		.4458	.4572
13	.6036		.5144	.5281	.4973	.463	.381
14		.6097	.5316	.5093	.5144	.463	.4191
15		.5716	.5316	.547	.4801	.463	.4572
16	.6602		.4973	.5658	.5144	.4973	.4458
17	.6979	.4458	.6287	.4973	.5487	.5525	.5144
18	.5658	.5144	.5335		.6001	.6478	.5487
19	.7545	.6516	.6478	.6173	.6859	.724	.6173
20	.7356		.6859	.583	.6859	.724	.6516
21	.679	.583	.5906	.5316	.6687	.6478	.5487
22	.583	.5144	.5335	.4801		.5716	.4973
23		.4973	.4954	.463	.4287	.4954	.3944
24	.4801	.4904	.4458	.4382	.4287	.4287	.4382
Max	.7545	.6767	.6859	.6859	.6859	.724	.6516
Min	.4458	.4287	.4287	.4382	.4115	.3772	.381
Avg	.5809	.5337	.538	.5353	.5230	.5226	.4988

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 205 / 11 kv ispurli Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5316	.4973	.4973	.4954	.4458		.4572
2	.5316	.463	.4801	.5144	.463	.4287	.4572
3	.5144	.4801	.4973	.5335	.463	.4458	.4763
4	.5487	.583	.5487	.5716	.4801	.5487	.5144
5	.6516	.6173	.7202	.6097	.583	.6173	.5906
6	.7545	.8299	.7888	.7811	.7373	.703	.8192
7	.6859	.703	.6859	.6859	.6859	.6859	.6859
8	.6516	.6344	.6859	.6287	.6173	.6173	.724
9	.679	.6859	.6173	.6036		.6173	.6287
10	.6224	.6668		.5658		.5658	.6097
11	.6602	.6097	.5487	.547	.5144	.5487	.5716
12	.6224	.6478	.5487	.5144	.4801	.5144	.5335
13	.6224	.6478		.547	.4115	.4801	.4954
14	.6602	.7049	.5316	.5281		.4801	.5335
15	.6979	.5335	.583	.547	.5144	.5144	.4588
16	.7499		.6687	.567	.5144	.5316	.4115
17	.6584		.6668	.583	.583	.6478	.7373
18	.6979	.583	.6859		.6859	.724	.7202
19	.8299	.7202	.724	.6859	.7545	.7621	.6859
20	.7373	.7202	.8383	.6344	.7545	.7811	.7545
21	.6859	.6859	.7621	.5487	.7202	.724	.6859
22	.703	.6173		.463	.6173	.6478	.6001
23		.5487		.4801	.4801	.5716	.4801
24	.5487	.6036	.5144	.4954	.4458	.4458	.4954
Max	.8299	.8299	.8383	.7811	.7545	.7811	.8192
Min	.5144	.463	.4801	.463	.4115	.4287	.4115
Avg	.6541	.6265	.6297	.5709	.5691	.5914	.5886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 206 / 11 KV Renuka &amp; Hanuman

PURELY LIS FEEDERS

Express Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0762	.0686		.0191		.0191
4	.0762	.0686		.0191		.0191
5	.0953	.2012		.0191		.0191
6	.0953	.2075		.0191		.0191
7	.3429	.1886		.0191	.0171	.0191
8	.4115	.1886		.0191	.0171	.0191
9	.4527	.2096			.0171	.0191
10	.4115	.2096			.0191	.0191
11	.4527	.2096		.0171	.0191	.0191
12	.4527	.2096		.0171	.0191	.0191
13	.4527	.1802		.0171	.0191	.0191
14	.4527	.2096		.0171	.0191	.0191
15	.2012	.2096		.0171	.0191	.0191
16	.2075		.0191	.0171	.0191	.0191
17	.2075		.0191	.0171	.0191	.0191
18	.2075		.0191	.0171	.0191	.0191
23				.0343		
Max	.4527	.2096	.0191	.0343	.0191	.0191
Min	.0762	.0686	.0191	.0171	.0171	.0191
Avg	.2873	.1816	.0191	.0190	.0186	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 207 / 11 KV Kawane Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.5144	.0686	.0164	.0191	.0171	.0168
2	.5316	.5144	.0686	.0164	.0191	.0171	.0166
3	.5316	.6036	.0686	.0164	.0191	.0171	.0164
4	.6001	.583	.0686	.0164	.0191	.0171	.0166
5	.6344	.6344	.0686	.0164	.0191	.0171	.0166
6	.6687	.7545	.0686	.0164	.0191	.0171	.0168
7	.7545	1.046	.1029	.0164	.0191	.0171	.0168
8	1.0974	1.4632	.1372	.0164	.0191	.0171	.0164
9	.0171	.0164	.0171	.0171		.0171	.0164
10	.0183	.0164		.2915		.0191	.0164
11	.0171	.0164	.0191	.3018	.0171	.0191	.0166
12	.0183	.0164	.0191	.3206	.0171	.0191	.0164
13	.0189	.0164		.3018	.0857	.0191	.0164
14	.0189	.0166	.0191	.2743		.0191	.0166
15	.0189	.0164	.0191	.3018		.0191	.0164
16	.0189		.0191	.2743		.0191	.0191
17	.0189		.0168	.2667		.0168	.0191
18	.0183	.0171	.0164			.0166	.0191
19	.0183	.0171	.0164	.0191	.0171	.0168	.0191
20	.0171	.0171	.0166	.0191	.0171	.0164	
21	.0171	.0171	.0166	.0191	.0171	.0166	.0191
22	.0171	.0171	.0164	.0191	.0171	.0164	.0191
23		.0686	.0164	.0191	.0171	.0164	.0191
24	.4973	.463	.0686	.0164	.0191	.0171	.0164
Max	1.0974	1.4632	.1372	.3206	.0857	.0191	.0191
Min	.0171	.0164	.0164	.0164	.0171	.0164	.0164
Avg	.2637	.3112	.0431	.1127	.0222	.0175	.0173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.5041	.6584	.7682	.4294	.7682	.3961
2	.4755	.5041	.6584	.7682	.4294	.724	.3961
3	.4755	.5041	.6219	.7682	.4294	.7316	.3961
4	.4755	.5041		.7682	.4294	.724	.3961
5	.567	.5041	.724	.8048	.4481	.7682	.4066
6	.6584	.567	.6219	.9145	.4668	.7796	.5304
7	.567	.5304	.6584		.4668	.8413	.4755
8	.5083	.5304	.6584		.5041	.8779	.4755
9	.6024	.6401	.695		.6401	.8764	.543
10	.6836	.6584	.695		.6935	.8939	.6219
11	.7712	.695	.6767		.8842	.9465	.6219
12	.6588	.6173	.6401		.9536	.7712	.6584
13	.6588	.5853	.5853	.0914	.8939	.7712	.5487
14	.5895		.5487	.0914	.8063	.7282	.6219
15	.631		.5611	.0732	.5609	.7282	.695
16			.5611	.2561	.5548	.7362	.7316
17	.6836		.5792		.7712	.8589	
18	.6401		.8048	.3658	.8779	.6836	
19	.6878		.8962	.5304	.9145	.5121	
20	.6878		1.0242	.6219	.9145	.5914	
21	.6219		.9511	.6468	.8779	.5853	
22	.5487	.3292	.9145	.5788	.8413	.5175	
23	.5544		.8413	.5093	.8048	.4854	
24	.5121	.5041	.695	.7682	.4481	.7682	.3921
Max	.7712	.695	1.0242	.9145	.9536	.9465	.7316
Min	.4755	.3292	.5487	.0732	.4294	.4854	.3921
Avg	.5971	.5452	.7074	.5486	.6684	.7362	.5239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 202 / 11 KV RASHIWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7362	1.1191		.0351	.0187	.0514	.0095
2	.7712	1.2209		.0351	.0187	.0514	.0095
3	.7712	1.3077		.0351	.0187	.056	.0095
4	.7712	1.3413		.0351	.0187	.0549	.0095
5	.9114	1.4419		.0351	.0187	.0549	.0084
6	1.0692	1.6933		.0351	.0187	.0362	.0084
7	1.595	2.0622			.0187	.0373	.0156
8	1.7974	2.2382			.0187		.016
9	.036	.0457			.0187		.0156
10	.0213				.0648	.0389	.0732
11	.0198	.0343	.0171		.0389	.0495	.0686
12	.0206	.0343	.0366		.0648	.0389	.0732
13	.0206	.0343	.0373	.0343	.0518	.032	.0686
14	.0191		.0373	.0343	.0518	.0312	.0686
15	.0198		.0373	.0343	.0511	.0305	.0686
16			.0373	.1029	.0518	.0381	.0343
17	.0145		.0373	.1029	.0495	.0701	
18	.0457		.0351	.0187	.0514	.0095	
19	.0457		.0343	.0187	.0549	.0095	
20	.0457		.0351	.0185	.0549	.0095	
21	.0572		.0343	.0187	.0532	.0095	
22	.0457		.0351	.0187	.0514	.0084	
23	.5256		.0351	.0187	.0549	.0095	
24	.8551	1.0174		.0351	.0187	.0549	.0095
Max	1.7974	2.2382	.0373	.1029	.0648	.0701	.0732
Min	.0145	.0343	.0171	.0185	.0187	.0084	.0084
Avg	.4441	1.0454	.0346	.0370	.0388	.0356	.0333



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 203 / 11 KV KOULAV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0377	.0366	.2743	.0686	.1029	.0457
2	.0343	.0373	.0343	.2743	.0686	.1063	.0457
3	.0343	.0373		.2743	.0686	.1063	.0343
4	.0343	.0373	.0343	.2743	.0686	.1097	.0343
5	.0343	.0373	.0366	.2743	.0686	.1029	.0343
6	.0343	.0187	.0377	.2743	.0686	.1463	.0332
7	.0343	.0373	.0343		.1029	.1372	.0848
8	.0189	.0373	.0354		.1029	.1417	.1269
9	.0377	.0187	.0343		.0373	.0354	.0189
10	1.291	2.0729	.5256		.0377	.0189	.0343
11	2.1963	2.1338	.5935			.0189	.0343
12	2.4034	2.1559	.5935			.0189	.0343
13	2.3868	2.1445	.6443	.0343		.0189	.0343
14	2.3537		.6274	.0343	.0377	.0189	.0343
15	2.3537		.5765	.0343	.0189	.0189	.0354
16			.583	.0343	.0189	.0189	
17	1.9784		.5316		.0189	.0189	
18	2.0687		.0171		.0171	.0189	
19	.0187		.0171	.0373	.0377	.0189	
20	.0373		.0175	.0373	.0343	.0189	
21	.0373		.0351	.0373	.0354	.0189	
22	.0377	.0343	.0343	.0377	.0343	.0377	
23	.0377		.2743	.0686	.1029	.0332	
24	.0343	.0377	.0377	.2743	.0686	.1097	.0332
Max	2.4034	2.1559	.6443	.2743	.1029	.1463	.1269
Min	.0187	.0187	.0171	.0343	.0171	.0189	.0189
Avg	.7622	.5919	.2344	.1422	.0532	.0582	.0436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 204 / 11 KV NAGESHWAR GAVTHAN  
VG FD Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2195	.2075	.1886	.1829	.1886
2	.2263	.2241	.2012	.2075	.1886	.1646	.1886
3	.2263	.2263	.1829	.2075	.1886	.1646	.1886
4	.2263	.2263	.1772	.2075	.1886	.1646	.1886
5	.2263	.2263	.2012	.2075	.1886	.1646	.1886
6	.2263	.2075	.2012	.2075	.2054	.1829	.2075
7	.2075	.2054	.2195		.1867	.1646	.2012
8	.1646	.168	.2195		.1663	.1646	.1829
9	.1848	.1848	.1829		.1478	.1646	.1829
10	.1829	.2012	.1646		.1829	.2012	.2058
11	.1829	.1949	.2195		.2172	.2012	.2378
12	.2218	.2012	.2012		.2012	.1791	.2452
13	.2218	.2195	.2195	.2058	.2012	.1829	.2195
14	.2241		.2195	.2195	.2195	.2012	.2012
15	.2241		.2378	.2195	.2033	.1848	.2012
16			.2195	.2012	.2402	.1907	.1949
17	.2801		.2561	.2012	.2218	.2229	
18	.2378		.2126	.2033	.2378	.2378	
19	.2926		.2561	.2587	.2743	.2801	
20	.3439		.3292	.2561	.2926	.2987	
21	.2743		.3109	.2801	.2743	.2801	
22	.2957	.2926	.3018	.2641	.2561	.2641	
23	.2614		.2641	.2263	.2195	.2263	
24	.2452	.2427	.2195	.2263	.1886	.1829	.1886
Max	.3439	.2926	.3292	.2801	.2926	.2987	.2452
Min	.1646	.168	.1646	.2012	.1478	.1646	.1829
Avg	.2349	.2165	.2265	.2226	.2117	.2022	.2007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 205 / SHAHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
9	.0943
11	.1509
12	.1494
13	.1494
Max	.1509
Min	.0943
Avg	.136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 201 / 11 KV SHAHUNAGAR GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.0857
Max	.0857
Min	.0857
Avg	.0857

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 202 / 11 KV COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 203 / 11 KV KURDU

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 204 / 11 KV WASHI SHETI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.6858
Max	.6858
Min	.6858
Avg	.6858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 205 / 11 KV DEWALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.343
Max	.343
Min	.343
Avg	.343



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 206 / 11 KV TULASHI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
24	.2572
Max	.2572
Min	.2572
Avg	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 207 / 11 KV HIRAWADE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	.1714
Max	.1714
Min	.1714
Avg	.1714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 208 / 11KV KOTHALI SPPM

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 209 / 11 KV HANUMAN SPPM

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 401 / 33 Kv Puikhadi

Feeder KV- 33 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUN-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 402 / 33 KV Kanchanwadi Feeder  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 403 / Awali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.6296
Max	4.6296
Min	4.6296
Avg	4.6296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 404 / 33 KV Wadakshiwale Feeder  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.286
Max	1.286
Min	1.286
Avg	1.286



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 406 / Rajiwaji Sut Girani  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	1.4918
Max	1.4918
Min	1.4918
Avg	1.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 201 / 11 Kv Wakare Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0168	.017	.373	.0492	.0335	.0339
2	.0168	.0166	.017	.2713	.0497	.0332	.0339
3	.0168	.0164	.017	.2713	.0492	.0332	.0332
4	.0168	.0166	.017	.2713	.0486	.0332	.0332
5	.0168	.0164	.017	.3052	.0503	.0332	.0332
6	.0168	.0166	.017	.373	.0492	.0497	.0332
7	.0168	.0168	.017	.4409	.0648	.0663	.0328
8	.0168	.0168	.017	.5087	.0829	.0663	.0497
9	.017	.0168	.0166	.0168	.017	.017	.0164
10		.407	.5571	.0168		.017	.0164
11	1.1736	.4748	.6962	.0168	.0168	.017	.0164
12	1.2742	.5087	.6962	.0168	.0168	.017	.0164
13	1.3077	.5426	.7865	.0168	.0168	.017	.0164
14	1.2742	.7461	.7042	.0168	.0168	.017	.0164
15	1.2742	.78	.7712	.0168	.0168	.017	.0164
16	1.0059	.7122	.8288	.0168	.0168	.017	.0164
17	1.0608	.5765	.8139	.0168	.0168		.0168
18	.0168	.017	.017	.0168	.0168	.0166	.0168
19	.0168	.017	.017	.0168	.0168	.017	.0168
20	.0168	.017	.017	.0168	.0168	.017	.0168
21	.0168	.017	.017	.0168	.0168	.017	.0168
22	.0168	.017	.017	.0168	.0168	.017	.0168
23	.0168	.017	.3391	.0503	.0503	.0339	.0168
24	.0168	.0168	.017	.4409	.0503	.0335	.0339
Max	1.3077	.78	.8288	.5087	.0829	.0663	.0497
Min	.0168	.0164	.0166	.0168	.0168	.0166	.0164
Avg	.3756	.2090	.2687	.1475	.0332	.0277	.0236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 202 / 11 Kv Mahe Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3361	.3224	.3224	.3224	.2896	.2865
2	.362	.3224	.3224	.3258	.2835	.2896	.2865
3	.362	.3189	.3224	.2865	.2804	.2896	.2865
4	.3982	.3224	.3582	.3224	.2835	.3258	.3224
5	.4344	.4252	.394	.3582	.3258	.362	.3582
6	.5068	.5014	.4298	.4656	.4961	.4706	.4656
7	.4344	.4607	.4298	.4656	.4656	.4706	.4656
8	.4344	.4252	.4298	.4656	.4252	.4755	.5014
9	.5014	.4961		.4656	.4344	.4656	.4656
10	.5121	.5068	.4252	.4656	.4706	.4656	.4656
11	.5121	.5068	.4656	.3544	.543	.5014	.4298
12	.5792	.5014	.4961	.3224	.4706	.4656	.0191
13	.543	.5014	.5014	.3582	.4706	.3582	
14	.5373	.5731	.5316	.3898	.4706	.4298	
15	.4298	.5373	.4607	.4298		.394	.5068
16	.4706		.4252	.3582	.4344	.394	.4344
17	.4607	.4298	.4298	.3898	.4656	.3582	.4607
18	.5014	.5014	.4656	.4252	.4656	.394	.4298
19	.5731	.5373	.5014	.5014	.5014		.5373
20	.6024	.5373	.6089	.5316	.5731	.6447	.567
21	.5014	.5373	.5373	.4961	.5014	.5731	.5373
22	.4656	.4656	.4656	.4656	.4344	.4656	.4298
23	.4298	.394	.394	.394	.362	.3582	.3189
24	.3772	.3582	.3224	.3224	.3544	.3258	.2865
Max	.6024	.5731	.6089	.5316	.5731	.6447	.567
Min	.362	.3189	.3224	.2865	.2804	.2896	.0191
Avg	.4705	.4564	.4365	.4034	.4276	.4160	.4028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 203 / 11 Kv Bahireshwar Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1463	.1509	.1509	.1086	.1132	.1509
2	.181	.1448	.1509	.1132	.1075	.1132	.1509
3	.1829	.1463	.1509	.1132	.1086	.1132	.1509
4	.1829	.1448	.1509	.1132	.1097	.1132	.1509
5	.2195	.1772	.1886	.1509	.1433	.1509	.1886
6	.2195	.181	.1886	.1509	.181	.1867	.2218
7	.1829	.1829	.1848	.1109	.181	.1848	.2195
8	.1886	.181	.1663	.1494	.181	.1829	.2195
9	.1753	.1448	.1478	.1463	.1463	.1478	.181
10	.1829	.1463	.1463	.1448	.1448	.1463	.1433
11	.2195	.1867	.1829	.1086	.1867	.1448	.181
12	.2195	.2195	.181	.1097	.181	.181	.2195
13	.1829	.1829	.2195	.1097	.181	.1646	.1791
14	.1848	.2195	.2172	.1086	.1509	.2218	.1791
15	.1848	.1848	.2172	.1097	.1478	.1886	.181
16	.181	.1791	.181	.1448	.1463	.1848	.1494
17	.181	.1463	.1402	.181	.1494	.1463	.181
18	.1829	.181	.1478	.1463	.1478	.1772	.181
19	.1791	.2149	.1848	.181	.1848	.2172	.2195
20	.2195	.2075	.2263	.2195	.2241	.2241	.2149
21	.2195	.2263	.2263	.2172	.2241	.2241	.2126
22	.181	.1886	.1886	.1829	.1886	.2263	.1829
23	.181	.1698	.1509	.1463	.1509	.1509	.1829
24	.1829	.1463	.1509	.1509	.1097	.1509	.1509
Max	.2195	.2263	.2263	.2195	.2241	.2263	.2218
Min	.1753	.1448	.1402	.1086	.1075	.1132	.1433
Avg	.1916	.1770	.1767	.1442	.1577	.1690	.1830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 204 / 11 Kv Sangrul Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7042	.1658	.0332	.0162	.0166	.016	.0166
2	.7042	.1492	.0332	.0162	.0164	.016	.0166
3	.7042	.1509	.0332	.0162	.0166	.016	.0166
4	.8048	.1492	.0663	.0162	.0162	.016	.0166
5	1.0059	.1475	.0995	.0162	.016	.016	.0166
6	1.1065	.1509	.1326	.0162	.0164	.016	.0166
7	1.3077	.1492	.1492	.0162	.0166	.016	.0166
8	1.2071	.2012	.1989	.0162	.0166	.016	.0166
9	.0166	.0166	.0166	.0164	.0162	.0166	.016
10	.0166	.0162	.0166	.3481	.0972	.0332	.032
11	.0166	.0162	.0164	.4973	.0648	.0332	.032
12		.0162	.0166	.4475	.064	.0332	.032
13		.0162	.0164	.4973	.096	.0995	.032
14		.0162	.0162	.4973	.096	.0995	.032
15	.0166	.0162	.0166	.4973	.096	.0663	.032
16	.0166	.0162	.0164	.4475	.064	.0663	.032
17	.0166	.0166		.3978	.064	.0995	.0328
18	.0164	.0166	.0162	.0164	.016	.0166	.0166
19	.0166	.0166	.0162	.0164	.016	.0166	.0166
20	.0164	.0166	.0162	.0166	.016	.0166	.0166
21	.0164	.0166	.0162	.0164	.016	.0166	.0166
22	.0164	.0166	.0162	.0164	.016	.0166	.0166
23	.1989	.0332	.0162	.0164	.016	.0166	.0328
24	.7042	.1989	.0332	.0162	.0164	.016	.0166
Max	1.3077	.2012	.1989	.4973	.0972	.0995	.0328
Min	.0164	.0162	.0162	.0162	.016	.016	.016
Avg	.4109	.0719	.0438	.1621	.0376	.0330	.0224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 205 / 11 Kv Mahe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0181	.0191	.2743	.1457	.0633	.0457
2	.0168	.0187	.0191	.2812	.144	.0633	.0472
3	.0168	.0185	.0191	.2812	.144	.096	.0495
4	.0168	.0183	.0191	.3125	.1475	.096	.0495
5	.0168	.0185	.0191	.4062	.1475	.0949	.0518
6	.0168	.0183	.0191	.4999	.144	.0949	.08
7	.0168	.0185	.0191	.8421	.1638	.1265	.0987
8	.0168	.0191	.0191	1.0159	.208	.1543	.104
9	.0191	.0191	.0187	.0187	.0191	.0191	.0191
10	1.8107	1.4918	1.3757	.0187	.0191	.0191	.0191
11	2.6113	1.6244	1.3757	.0189	.0191	.0191	.0191
12	2.713	1.757	1.3927	.0187	.0191	.0191	.0191
13	2.5149	1.7772	1.3765	.0187	.0191	.0191	
14	2.4756	1.7101	1.3108	.0183	.0191	.0191	
15	2.3472	1.8107	1.3923	.0181		.0191	.0191
16	2.1879		1.2793	.0187	.0191	.0191	.0191
17	2.2211	.9831	1.0753	.0189	.0191	.0191	.0187
18	.0181	.0191	.0191	.0189	.0191	.0191	.0185
19	.0185	.0191	.0191	.0187	.0191	.0191	.0187
20	.0185	.0191	.0191	.0189	.0191	.0191	.0187
21	.0183	.0191	.0191	.0187	.0191	.0191	.0187
22	.0183	.0191	.0191		.0191	.0191	.0185
23	.0187	.0191	.2743	.1989	.0655	.0419	.0187
24	.0472	.0185	.0191	.2812	.1638	.0648	.0419
Max	2.713	1.8107	1.3927	1.0159	.208	.1543	.104
Min	.0168	.0181	.0187	.0181	.0191	.0191	.0185
Avg	.7997	.4980	.4641	.2016	.0749	.0485	.0370

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 206 / 11 Kv bahireshwar Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168	.0183	.0191	.8048	.0983	.064	.0427
2	.0168	.0187	.0191	.8048	.0937	.064	.0427
3	.0168	.0185	.0191	.7377	.0972	.0972	.0442
4	.0168	.0183	.0191	.7377	.0972	.0972	.0457
5	.0168	.0185	.0191	.8048	.0995	.128	.0457
6	.0168	.0183	.0191	.8383	.1311	.128	.0732
7	.0168	.0185	.0191	.9614	.1457	.1875	.0827
8	.0168	.0185	.0191	.9831	.1802	.1562	.1286
9	.0191	.0187	.0185	.0185	.0191	.0191	.0191
10	1.8233	1.2125	.9503	.0187	.0191	.0191	.0191
11	2.2939	1.4251	1.247	.0166	.0191	.0191	.0191
12	2.2283	1.5912	1.3279	.0185	.0191	.0191	.0191
13	2.2672	1.4746	1.2963	.0189	.0191	.0191	
14	2.3594	1.4575	1.3927	.0187	.0191	.0191	
15	2.2672	1.4255	1.3441	.0185		.0191	.0191
16	2.1052		1.4582	.0187	.0191	.0191	.0191
17	2.13	.9831	1.2955	.0187	.0191	.0191	.0171
18	.0181	.0191	.0191	.0189	.0191	.0191	.0187
19	.0187	.0191	.0191	.0189	.0191	.0191	.0187
20	.0185	.0191	.0191	.0189	.0191	.0191	.0185
21	.0187	.0191	.0191	.0185	.0191	.0191	.0183
22	.0181	.0191	.0191	.0189	.0191	.0191	.0187
23	.0185	.0191	.6706	.1311	.0648	.0533	.0185
24	.0168	.0185	.0191	.7865	.0995	.064	.0381
Max	2.3594	1.5912	1.4582	.9831	.1802	.1875	.1286
Min	.0168	.0183	.0185	.0166	.0191	.0191	.0171
Avg	.7398	.4291	.4695	.3271	.0589	.0545	.0358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 201 / 11 kv Nagdevwadi Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	.1524	.3429	.0686	.1067	.0686	.1219
2	1.2193	.1524	.3429	.0686	.1067	.0686	.1219
3	1.2193	.1524	.3429	.0686	.1067	.0686	.1219
4	1.2193	.2286	.3601	.0686	.1067	.0686	.1524
5	1.2498	.2286	.4287	.0686	.1067	.0686	.1524
6	1.448	.2286	.4801	.0686	.1067	.0686	.1524
7	1.6766	.3048	.6173	.0686	.1067	.0686	.2134
8	1.7223		.6516	.0686	.1067	.0686	.2439
9	.061			.0686	.1067	.0686	.0152
10	.061			1.7147	.884	.583	.0152
11	.061	.0152		1.7833	1.2193	.6706	.0171
12	.061	.0152			1.2193	.6401	.0171
13	.061	.0152		1.989	1.2498	.6401	.0171
14	.061	.061		1.9719	1.2193	.6554	
15	.061	.0762		2.0233	.7926	.6554	
16	.061	.061		1.989	.6859	.7011	.0171
17	.061	.061	.061		.6859	.6859	.0152
18	.061	.0686	.061	.061	.0762	.0152	.0152
19	.0305	.0686	.061	.061	.1067	.0152	.0152
20	.061	.0686	.061	.0914	.1067	.0152	.0152
21		.0686	.061	.0914	.0686	.0152	.0152
22		.0686	.061	.0914	.0686	.0152	.0152
23		.4115	.061	.1219	.0686	.0152	.0152
24	.0171	.1219	.3429	.0686	.1067	.0686	.1219
Max	1.7223	.4115	.6516	2.0233	1.2498	.7011	.2439
Min	.0171	.0152	.061	.061	.0686	.0152	.0152
Avg	.5546	.1252	.2710	.5762	.3966	.2504	.0731



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 202 / 11 kv Padali Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1219	.1543	.1543	.1372	.1543	.1372
2	.1543	.1372	.1543	.1543	.1372	.1543	.1372
3	.1543	.1219	.1543	.1543	.1372	.1543	.1372
4	.1715	.1524	.1543	.1715	.1372	.1543	.1543
5	.1715	.1524	.1543	.1715	.1372	.1715	.1715
6	.1886	.1524	.1715	.1715	.1372	.1715	.1715
7	.1372	.1524	.1715	.1715	.1372	.1543	.1886
8	.1372	.1524	.1543	.1715	.1372	.1372	.1715
9	.12	.1219		.1715	.1372	.1543	.1372
10	.12	.1219		.1372	.12	.1372	.1372
11	.1372	.1372		.1372	.1219	.12	.1372
12	.1219			.1543	.1219	.1372	.1029
13	.1524	.1715		.1543	.1524	.1543	.1372
14	.1715	.1715		.1543	.1524	.1029	.1372
15	.1715	.1715		.1543	.1219	.1543	.12
16	.1715	.1886		.1372	.1219	.1886	.12
17	.1715	.1543	.1715		.1524	.1372	.1715
18	.1829	.1543	.1715	.1715	.1543	.1886	.1715
19	.1829	.1715	.2058	.1543	.1715	.1886	.1886
20		.2058	.2058	.1543	.1886	.1829	.2058
21		.1715	.1715	.1715	.1715	.1715	.1715
22		.1715	.1715	.1543	.1543	.1543	.1715
23		.1543	.1543	.1543	.1543	.1219	.1543
24	.1867	.1219	.1543	.1543	.1543	.1543	.1372
Max	.1886	.2058	.2058	.1715	.1886	.1886	.2058
Min	.12	.1219	.1543	.1372	.12	.1029	.1029
Avg	.1588	.1536	.1672	.1581	.1437	.1542	.1529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 203 / 11 kv khupire Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.3048	.3429		.3429	.2743	.2915
2	.3601	.3048	.3429		.3429	.2743	.2915
3	.3601	.3048	.3429		.3429	.2743	.3086
4	.3601	.3048	.3429		.3429	.2743	.3086
5	.4115	.381	.3429		.3429	.3429	.3772
6	.463	.381	.3429		.4115	.3944	.4287
7	.4115	.3963	.3429		.4458	.3258	.4801
8	.4458	.4115	.4115		.4801	.3601	.463
9	.463	.381			.463	.3429	.4458
10	.4287				.3944	.3258	.3944
11	.4458	.463			.381	.3258	.4287
12	.4287	.4458			.3353	.3258	.3772
13	.4458	.4801			.4115	.2915	.4115
14	.4801	.4973			.381	.3429	.3944
15	.5144	.4973		.3601	.4572	.4973	.3772
16	.5316	.5144		.2401	.4115	.4973	.4801
17	.5658		.4458		.3658	.4458	.4973
18	.4268	.5316	.4458	.4458	.3944	.5144	.4458
19	.5658	.5487	.463	.463	.4115	.5144	.4973
20		.5658	.4801	.5487	.4287	.4801	.5487
21		.5316	.4458	.4973	.3944	.442	.4973
22		.5316	.4287	.463	.3429	.4287	.4287
23		.4115	.4115	.3772	.2915	.3601	.3601
24	.3961	.3048	.3601		.3601	.2743	.3086
Max	.5658	.5658	.4801	.5487	.4801	.5144	.5487
Min	.3601	.3048	.3429	.2401	.2915	.2743	.2915
Avg	.4432	.4315	.3933	.4244	.3865	.3721	.4101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 204 / 11 Kv Fulewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.8573	.823	.8916	.8402	.823	.8916
2	.8916	.8573	.823	.8916	.8402	.823	.8916
3	.8916	.8573	.823	.9259	.8402	.823	.9259
4	.8916	.8573	.823	.9259	.823	.8573	.9259
5	.9088	.9431	.8573	.9602	.8059	.8916	.9602
6	.9431	.9145	.8573	.9602	1.0288	.9259	1.0288
7	.9602	1.0288	.8916	.9602	1.0288	1.0288	1.0974
8	.9945	1.0288	.9602	.9945	1.0288	1.0288	1.0974
9	.9431	.8535		.9259	.9602	.9945	1.0288
10	.9431	.9945		.8916	.9602	.9259	.9602
11	.9259	.9602		.823	.9145	.9259	.9259
12	.9602	.8916		.8573	1.0288	.9259	.8573
13	.9602	.8916			1.1145	.9088	.7716
14	.9602	.8059			.9145	.8402	.823
15	.9602	.8916		1.2174	.9602	.823	.7545
16	.9602	.9431		.9945	.9431	.8059	.6859
17	.9602	.9602	.9431		.9945	.8573	.8573
18	.9431	.7716	.9602	1.1488	.9259	1.0852	.8059
19	1.0288	.9945	1.166		1.0974	1.2689	.9431
20		1.166	1.3032	1.5089	1.2517	1.3032	1.2174
21		1.1145	1.2346	1.3717	1.2346	1.0974	1.1488
22		1.1145	1.2174	1.3032	1.0631	1.0364	1.1145
23		.9945	1.0288	1.0974	.9945	.9259	.9431
24	1.076	.8573	.8573	.9945	.9088	.8573	.8573
Max	1.076	1.166	1.3032	1.5089	1.2517	1.3032	1.2174
Min	.8916	.7716	.823	.823	.8059	.8059	.6859
Avg	.9506	.9396	.9731	1.0322	.9793	.9493	.9381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 206 / 11 KV KUDITRE AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152		.0343	.4458	.2439	.1886	.0152
2	.0152		.0343	.4458	.2439	.1715	.0152
3	.0152		.0343	.4801	.2439	.1715	.0152
4	.0152		.0343	.5487	.2286	.1715	.0152
5	.0152		.0343	.5487	.2286	.1715	.0152
6	.0152		.0343	.6173	.3048	.1715	.0152
7	.0152		.0343	.7888	.4268	.3086	.0152
8	.0152		.0343	.9259	.5944	.3944	.0152
9	.0152			.0171	.0152		.0152
10	2.1643	.0343		.0171	.0152		.1524
11		.3048		.0171	.0343	.0152	.2743
12	2.9264	.3658			.0305	.0152	.2229
13	3.1703	.4572		.0171	.0152	.0152	.1372
14	3.1398	.4572		.0171	.0343	.0152	.1715
15	3.0483	.8078				.0152	.1372
16	2.8045			.0171	.0343	.0152	.2058
17	2.6216	.5639	.9145		.0305	.0152	.1829
18	.0305	.0343	.0152	.0152	.0305	.0152	.0152
19	.0343	.0343	.0152	.0152	.0152	.0152	.0152
20		.0343	.0152	.0152	.0152	.0152	.0152
21		.0343	.0152	.0152	.0171	.0152	.0152
22		.0343	.0152	.0152	.0171	.0152	.0152
23		.0343	.3658	.2439	.2058	.0152	.0152
24	.0191		.0343	.4115	.2439	.1886	.0152
Max	3.1703	.8078	.9145	.9259	.5944	.3944	.2743
Min	.0152	.0343	.0152	.0152	.0152	.0152	.0152
Avg	1.0577	.2459	.1041	.2683	.1421	.0971	.0720

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 207 / 11 KV FULEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.3353	.1524	.1067	
2				.3353	.1524	.1067	
3				.3353	.1372	.1067	
4				.3658	.1372	.1067	
5				.3658	.1372	.1219	
6				.4115	.1524	.1372	
7				.4572	.1829	.1524	
8				.503		.1677	
10	.8993	.7621					.1372
11	.945	.8383					.1524
12	1.1279	.884					.1067
13	1.1126	.8688					.0762
14	1.1279	.8383					.1219
15	1.0364	.8078					.1067
16	.9602	.6859					.1219
17	.9755	.3506	.7621				.1219
23				.1524			
24				.3048	.1524	.1067	
Max	1.1279	.884	.7621	.503	.1829	.1677	.1524
Min	.8993	.3506	.7621	.1524	.1372	.1067	.0762
Avg	1.0231	.7545	.7621	.3566	.1505	.1236	.1181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 208 / 11KV Padali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2498		.5487	.0152		.0152	.061
2	1.2498		.5487	.0152		.0152	.061
3	1.2498		.5487	.0152		.0152	.061
4	1.2803		.5639	.0152		.0152	.0914
5	1.3108		.5792	.0152		.0152	.0914
6	1.3565		.5944	.0152		.0152	.1219
7	1.5546		.6859	.0152		.0152	.1219
8	1.6918		.7773	.0152		.0152	.1219
9	.0152	.4572		.0171		.0152	.0152
10	.0152	.0305		1.3108		.2286	.0152
11	.0152	.0152		1.3413	.4572	.3048	.0152
12	.0152	.0152		1.4784	.5335		.0152
13	.0152	.0152		1.4632	.5792	.3048	.0152
14	.0152	.0152		1.5242	.5335	.2896	.0152
15	.0152	.0152		1.5242	.381	.2591	.0152
16	.0152				.4268	.0762	.0152
17	.0152		.0305		.4572	.2286	.0152
18		.0152	.0305			.0152	.0152
19	.0305	.0152	.0305		.0152	.0152	.0152
20		.0152	.0305		.0152	.0152	.0152
21		.0152	.0152		.0152	.0152	.0152
22		.0152	.0152		.0152	.0152	.0152
23		.5487	.0152		.0152	.061	.0914
24	.0152		.5639	.0152		.0152	.061
Max	1.6918	.5487	.7773	1.5242	.5792	.3048	.1219
Min	.0152	.0152	.0152	.0152	.0152	.0152	.0152
Avg	.5856	.0914	.3486	.5498	.2870	.0861	.0457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 209 / 11KV Khupire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.1524	.3353	.0152	.0152	.0152	.0914
2	.4572	.1524	.3353	.0152	.0152	.0152	.0914
3	.5487	.1524	.3353	.0152	.0152	.0152	.0914
4	.5487	.1524	.3658	.0152	.0152	.0152	.1219
5	.6097	.2286	.4877	.0152	.0152	.0152	.1524
6	.7926	.2286	.5487	.0152	.0152	.0305	.1524
7	1.3413	.3048	.8535	.0152	.0152	.0305	.1829
8	1.5699	.3048	.823		.0152	.0305	.1829
9	.1219	.0305		.0152	.0152	.0305	.0152
10	.061			.8535	.2896	.1524	.0152
11	.0152	.0152		1.1888	.4572	.1524	.0152
12		.0152		1.2803	.7621	.2134	
13	.0152	.0152		1.2193	.7621	.2134	.0152
14	.0171	.0152		1.1431	.8383	.2286	.0152
15	.0152	.0152		1.1279		.2286	.0152
16	.0152	.061		1.0974	.1524	.2591	.0152
17	.0152	.0152	.0305		.1524	.2591	.0152
18		.0305	.0305		.0305	.0152	.0152
19	.0152	.0305	.0305	.0152	.0152		.0152
20		.0305	.0305	.0152	.0152		.0152
21		.0305	.0305	.0152	.0152	.0152	.0152
22		.0305	.0305	.0152	.0152	.0152	.0152
23		.2134	.0305	.0152	.0152	.0914	.0914
24	.0151	.1524	.3353	.0152	.0152	.0152	.0914
Max	1.5699	.3048	.8535	1.2803	.8383	.2591	.1829
Min	.0151	.0152	.0305	.0152	.0152	.0152	.0152
Avg	.3684	.1034	.2896	.3868	.1597	.0935	.0629

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 210 / 11 Kv kuditre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.5144	.5487	.5487	.463	.4801	.4458
2	.6001	.5144	.5487	.5487	.463	.4801	.4458
3	.6001	.6001	.5487	.583	.463	.4801	.4458
4	.6001	.6859	.5658	.583	.4801	.4801	.4801
5	.6173	.6859	.6173	.6173	.5487	.6173	.5144
6	.7202	.7716	.6859	.6859	.6173	.6859	.5487
7	.6859	.6859	.6173	.6516	.6687	.6859	.6859
8	.6859	.6859	.6173	.583	.6859	.6859	.6516
9	.703	.6173		.6173	.6001	.583	.6516
10	.7888	.6859		.5487	.703	.6516	.7202
11	.7545	.7716		.4115	.6097	.7373	.6859
12	.7202	.7545			.7202	.703	.6516
13	.6401	.7202		.2743	.1715	.6687	.5658
14	.7545	.6859		.2401	.1524	.6001	.5487
15	.7202	.9602		.5487	.6859	.6516	.583
16		.7202		.5487	.4572	.6859	.6859
17	.823	.703	.6859		.5487	.6516	.5658
18	.6859	.7545	.6516	.6687	.7716	.7545	.6516
19	.7621	.7545	.7545	.7545	.8059	.7888	.7545
20		.7716	.823	.6859	.8573	.823	.823
21		.6859	.7888	.6516	.6859	.6706	.7888
22		.7545	.6859	.6173	.6516	.6173	.7545
23		.5487	.6516	.5144	.5487	.5144	.6173
24	.6942	.5144	.5487	.583	.4801	.5144	.4801
Max	.823	.9602	.823	.7545	.8573	.823	.823
Min	.6001	.5144	.5487	.2401	.1524	.4801	.4458
Avg	.6924	.6895	.6462	.5666	.5766	.6338	.6144



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 201 / 11 KV SANGRUL VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.4338	.415	.4527	.415	.4338	.415
2	.4904	.415	.3961	.4338	.415	.3961	.3961
3	.4904	.415	.3961	.4338	.415	.3961	.3961
4	.547	.4338	.3961	.4527	.4338	.3961	.3961
5	.5658	.5093	.4904	.5093	.4904	.4904	.5093
6	.7282	.6036	.6602	.5975	.5914	.6224	.6535
7	.7282	.5975	.5975	.4938	.5914	.5975	.6283
8	.6468	.5729	.5304	.4887	.5544	.6584	.5853
9	.5973	.5853	.4908	.4656	.5601	.5847	.5552
10	.567	.567	.5194	.4525	.5316	.5611	.4887
11	.6089	.5373	.5552	.4938	.4607	.5068	.4207
12	.4835	.5847	.5373	.4938			.4755
13	.5552		.6089		.6024	.4835	.4525
14	.6089	.6697	.6201	.4706	.5847	.4887	.4163
15	.5784	.631	.6024	.4525	.5316	.4706	.4525
16	.6068	.6173	.567	.4887	.567	.4854	.4477
17	.6687	.5373	.5316	.5068	.6154	.6068	.591
18	.7011	.6154	.6089	.5121	.6661	.7087	.6089
19	.8507	.7442	.7701	.7392	.788	.8131	.7947
20	.8962	.8316	.8686	.7655		.8402	.9242
21		.7545	.7577	.7733	.7468	.7545	.811
22	.6161	.679	.6413	.5658	.6224	.6036	.7167
23	.5281	.5281	.5093	.4527	.5093	.5093	.4904
24	.5622	.4527	.4338	.4527	.415	.4338	.415
Max	.8962	.8316	.8686	.7733	.788	.8402	.9242
Min	.4835	.415	.3961	.4338	.415	.3961	.3961
Avg	.6138	.5790	.5627	.5195	.5503	.5583	.5434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 202 / 11 KV KHATANGLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7459	.0232	.0259				
2	.763	.0232	.0259				
3	.7865	.0236	.0251				
4	.7865	.0225	.0251				
5	.9282	.0221	.0236				
6		.0221	.0236				
7	1.6907	.0518	.0564				
8	1.8313	.0533	.0743				
10				.0271	.16	.0549	.0495
11				.0274	.16	.1143	.0629
12				.044	.1623	.1	.0591
13					.1734	.0857	.045
14				.208	.1734	.096	.0427
15				.2258	.12	.1488	.0427
16				.3715	.12	.1036	.1433
17				.2526	.1067	.0894	.1143
23	.0394	.0271					.0572
24		.0248	.0267				
Max	1.8313	.0533	.0743	.3715	.1734	.1488	.1433
Min	.0394	.0221	.0236	.0271	.1067	.0549	.0427
Avg	.9464	.0294	.0341	.1652	.1470	.0991	.0685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 203 / 11 KV UPWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0191	.0189	.0354	.0532
2				.0191	.0189	.0351	.0532
3				.0191		.0351	.0532
4				.0191	.0189	.0351	.0532
5				.0191	.0189	.0351	.0532
6				.0191		.0351	.0532
7				.1696	.0187	.0362	.0709
8				.3561	.0187	.0526	.0354
10	.032	.4681	.6068				
11	.2721	.7712	.8745				
12	.6443	.9774	1.0343				
13	1.153	1.0867	1.0174				
14	1.0174	.9945	1.0004				
15	1.0004	.9665	1.0174				
16	.788	.8718	.8817				
17	.7291	.5426	.8573				
23			.0191	.0189	.0354	.0532	
24				.0191	.0189	.0354	.0532
Max	1.153	1.0867	1.0343	.3561	.0354	.0532	.0709
Min	.032	.4681	.0191	.0189	.0187	.0351	.0354
Avg	.7045	.8349	.8121	.0678	.0209	.0388	.0532

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 202 / 11 KV SHENAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.2667	.1334	.0191	.0191	.0191	.0191
2	.6668	.2667	.1143	.0191	.0191	.0191	.0191
3	.6668	.2477	.1143	.0191	.0191	.0191	.0191
4	.6668	.2286	.1143	.0191	.0191	.0191	.0191
5	.6859	.2477	.1143	.0191	.0191	.0191	.0191
6	.7811	.2096	.1143	.0191	.0191	.0191	.0191
7	1.2003	.2286	.1715	.0191	.0191	.0191	.0191
8	1.4098	.2286	.1524	.0191	.0191	.0191	.0191
9	1.1431	.0191	.1143	.0191	.0191	.0191	.0191
10	.0762	.0191	.0762	.0191	.0191	.0953	.0191
11		.0191	.0762	.0191	.1524	.0953	.0191
12		.0762	.0762	.1524	.1715	.0191	.0572
13		.0762	.0191	.1524	.1524	.0762	.0191
14	.0762	.0762	.0191	.0762	.1524	.1143	.1143
15	.0762		.0191	.1524	.1143	.1334	.1143
16	.0762		.0191	.1524	.1334	.1334	.1143
17			.0191	.0191	.1143	.1334	.0953
18	.0191		.0191	.1143	.1143	.1143	.0953
19	.0191	.1334	.0191	.0191	.0191	.0191	.0191
20	.0191	.1334	.0191	.0191	.0191	.0191	.0191
21	.0191	.0762	.0191	.0191	.0191	.0191	.0191
22	.0191	.0762	.0191	.0191	.0191	.0191	.0191
23	.3239	.0762	.0191	.0191	.0191	.0191	.0953
24	.6668	.2477	.1334	.0191	.0191	.0191	.0191
Max	1.4098	.2667	.1715	.1524	.1715	.1334	.1143
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.4639	.1477	.0715	.0477	.0588	.0501	.0421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPALGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7811	.7049	.7049	.6859	.6859	.6478
2	.7811	.7621	.6859	.6859	.6859	.7049	.6478
3	.7811	.743	.6859	.6668	.6859	.7049	.6478
4	.7811	.724	.6859	.6668	.6859	.724	.6478
5	.7811	.7049	.6859	.6668	.6859	.6668	.6478
6	.8002	.6287	.6859	.6668	.6859	.6287	.6859
7	.724	.6097	.6478	.6668	.6859	.7049	.6859
8	.7621	.6668	.6287	.6478	.7049	.6668	.724
9	.7621	.7049	.724	.724	.7621	.7621	.6859
10	.8383	.7621	.743	.743	.8573	.6668	.8764
11	.8383	.8192	.8954			.8002	.8954
12	.8002	.8573	.9145		.8573	.8764	.7811
13	.8002	.8573	.8192		.8764	.8764	.8002
14	.9526	.8573	.8383	1.0669	.8573	.8573	.8573
15	.9907		.8002	.9526	.8383	.8383	.7811
16	1.0669		.8573	.8383	.8002	.8192	.8954
17		.5335	.7811	.8383	.8383	.7621	.8573
18	1.0479	.4954	.8002	.9526	.7621	.8192	.8383
19	1.0669	.5335	1.1241	1.1622	1.1812	1.086	.9526
20	1.2955	1.0479	1.105	1.0479	1.2384	1.105	1.1812
21	1.2765	1.0288	1.0288	.9145	1.2193	.9907	1.1431
22	1.2003	.9526	.9526	.8383	1.1431	.8954	1.0669
23	.8573	.8192	.8383	.7621	.7621	.7621	.7621
24	.3772	.7811	.724	.724	.6859	.6668	.6668
Max	1.2955	1.0479	1.1241	1.1622	1.2384	1.105	1.1812
Min	.3772	.4954	.6287	.6478	.6859	.6287	.6478
Avg	.8853	.7577	.8065	.8065	.8342	.7946	.8073

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 204 / 11 KV MADILAGE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.2667	.362	.4191	.362	.3239	.3429
2	.4382	.2667	.3429	.4191	.362	.3239	.3429
3	.4382	.2477	.3429	.4191	.362	.362	.3429
4	.4572	.2286	.381	.4191	.381	.2858	.362
5	.4763	.2858	.4001	.4191	.4001	.362	.381
6	.4763	.3048	.4191	.4382	.4382	.4191	.4001
7	.4572	.3048	.4001	.4191	.4191	.4382	.4001
8	.4572	.3429	.381	.4191	.381	.381	.381
9	.4191	.381	.381	.381	.4191	.4001	.4191
10	.4382	.3239	.381	.4382	.4572	.381	.4191
11		.3239	.4191	.4191	.4191	.3239	.362
12		.2858		.381	.381	.4191	.381
13	.5525	.2858		.381	.381	.3429	.4001
14	.4572	.362		.381	.4001	.4191	.381
15	.4954			.3429	.4191	.4572	.381
16	.4954			.3429	.3048	.4191	.4382
17	.4954		.5525	.3429	.4382	.4191	.4001
18			.5525	.4191	.4763	.4954	.4382
19		.5716	.7049	.5335	.5335	.6097	.5144
20	.2667	.6287	.6478	.5144	.6097	.5906	.6097
21	.381	.5335	.6097	.4572	.5716	.5335	.5525
22	.4001	.4954	.5525	.4382	.5335	.4763	.4954
23	.3239		.4954	.4001	.4001	.4191	.4001
24	.4572	.2858	.362	.4191	.381	.3429	.362
Max	.5525	.6287	.7049	.5335	.6097	.6097	.6097
Min	.2667	.2286	.3429	.3429	.3048	.2858	.3429
Avg	.4410	.3540	.4572	.4151	.4263	.4144	.4128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 205 / 11 KV GARGOTI PWV EXPRESS NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0572	.0572	.0191	.0572	.0572	.0572
2	.0191	.0572	.0572	.0191	.0572	.0572	.0572
3	.0191	.0572	.0572	.0191	.0572	.0572	.0572
4	.0572	.0572	.0572	.0191	.0572	.0572	.0572
5	.0572	.0572	.0572	.0191	.0572	.0572	.0572
6	.0572	.0572	.0572	.0191	.0572	.0572	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572	.0572	.0572	.0191	.0572	.0572	.0572
11		.0572	.0572	.0191	.0572	.0572	.0572
12		.0572	.0572	.0191	.0572	.0572	.0572
13	.0572	.0572	.0572	.0191	.0572	.0572	.0191
14	.0572	.0572	.0572	.0191		.0572	.0572
15	.0191		.0572	.0191		.0762	.0572
16	.0191		.0572	.0191	.0572		.0572
17		.0572	.0572	.0191	.0572	.0191	.0572
18	.0191	.0572	.0572	.0191	.0572	.0762	.0191
19		.0572	.0572	.0191	.0572	.0572	.0572
20	.0572	.0572	.0572	.0572	.0572	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572	.0572		.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	.0724	.0572	.0572	.0191	.0572	.0572	.0572
Max	.0724	.0572	.0572	.0572	.0572	.0762	.0572
Min	.0191	.0572	.0572	.0191	.0572	.0191	.0191
Avg	.0465	.0572	.0572	.0290	.0572	.0572	.0540

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 206 / 11 KV PIMPALGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0381		.0381	.0381	.0191	.0191
2	.0762	.0381		.0381	.0381	.0191	.0191
3	.0762	.0381		.0381	.0381	.0191	.0191
4	.0762	.0381		.0381	.0381	.0191	.0191
5	.0762	.0381		.0381	.0381	.0191	.0191
6	.0953	.0381		.0381	.0381	.0191	.0191
7	.1524	.0381		.0381	.0381	.0191	.0191
8	.2096	.0381		.0381	.0381	.0191	.0191
9	.1334	.0191		.0381	.0381	.0191	.0191
10	.0381	.0191		.0381	.0381	.0191	.0191
11		.0381		.0381	.0381	.0381	.0191
12		.0381		.0381	.0381	.0191	.0191
13		.0381		.0381	.0381	.0191	.0191
14	.0381	.0381		.0381	.0381	.0191	.0191
15	.0381		.0191	.0381	.0381	.0381	.0191
16	.0381		.0191	.0381	.0381	.0381	.0191
17			.0191	.0381	.0381	.0381	.0191
18	.0381		.0191	.0381	.0381	.0381	.0191
19	.0381		.0191	.0381	.0191	.0191	.0191
20	.0381		.0381	.0381	.0191	.0191	.0191
21	.0381		.0381	.0381	.0191	.0191	.0191
22	.0381		.0381	.0381	.0191	.0191	.0191
23	.0572		.0381	.0381	.0191	.0191	.0191
24	.0572	.0381		.0381	.0381	.0191	.0191
Max	.2096	.0381	.0381	.0381	.0381	.0381	.0191
Min	.0381	.0191	.0191	.0381	.0191	.0191	.0191
Avg	.0715	.0356	.0275	.0381	.0341	.0231	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 207 / 11 KV GANGAPUR AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762		.1143	.0191	.0381	.0572
2	.0762		.1143	.0191	.0381	.0381
3	.0762		.1143	.0191		.0381
4	.0762		.1143	.0191	.0381	.0381
5	.0762		.1143	.0191	.0381	.0381
6	.0762		.1524	.0191	.0381	.0381
7	.0572		.1143	.0191	.0953	.0381
8	.0572		.1143	.0191	.1143	.0381
9	.0572		.1143	.0381	.0191	.0381
10	.0572		.0572	.0381	.0191	.0191
11			.0191	.0381	.0191	.0191
12			.1143	.0381	.0191	.0191
13	.7621		.1143	.0381	.0191	.0191
14	.7811		.1143	.0381	.0191	.0191
15	.8192		.1143	.0381	.0191	.0191
16	.4763		.1143	.0381	.0191	.0191
17		.1143	.1143	.0381	.0191	.0191
18		.1334	.0381	.0381	.0191	.0191
19		.0572	.0381	.0381	.0191	.0191
20		.0191	.0381	.0381	.0191	.0191
21		.0572	.0191	.0381	.0191	.0191
22		.0572	.0191	.0381	.0191	.0191
23		.0572	.0191	.0381	.0191	.0191
24	.0762		.1143	.0191	.0381	.0572
Max	.8192	.1334	.1524	.0381	.1143	.0572
Min	.0572	.0191	.0191	.0191	.0191	.0191
Avg	.2401	.0708	.0881	.0310	.0315	.0286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 208 / 11 KV DARWAD AG.

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191		.0191	.0191	.0191	.0191
2	.0191	.0191		.0191	.0191	.0191	.0191
3	.0191	.0191		.0191	.0191	.0191	.0191
4	.0191	.0191		.0191	.0191	.0191	.0191
5	.0191	.0191		.0191	.0191	.0191	.0191
6	.0191	.0191		.0191	.0191	.0191	.0191
7	.0191	.0191		.0381	.0191	.0191	.0191
8	.0191	.0191		.0572	.0381	.0191	.0191
9	.0191	.0191		.0381	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11		.0191	.0191	.0191	.0191	.0191	.0191
12		.0191	.0191	.0191	.0191	.0191	.0191
13	.2667	.0191	.0191	.0191	.0191	.0191	.0191
14	.2858	.0191	.0191	.0191	.0191	.0191	.0191
15	.2858		.0191	.0191	.0191	.0191	.0191
16	.2096		.0191		.0191	.0191	.0191
17			.0191	.0191		.0191	.0191
18			.0381	.0191	.0191	.0191	.0191
19	.0191		.0191	.0191	.0191	.0191	.0191
20	.0191		.0191	.0191	.0191	.0191	.0191
21	.0191		.0191	.0191	.0191	.0191	.0191
22	.0191		.0191	.0191	.0191	.0191	.0191
23	.0191		.0191	.0191	.0191	.0191	.0191
24	.0191	.0191		.0191	.0191	.0191	.0191
Max	.2858	.0191	.0381	.0572	.0381	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0677	.0191	.0205	.0224	.0199	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 209 / 11KV MADUR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3429	.3239	.362	.2667	.2858	.3048
2	.381	.3239	.3048	.3429	.2667	.2667	.3048
3	.381	.3239	.3048	.3429	.2477	.2667	.3048
4	.381	.3048	.3239	.3429	.2667	.2477	.3239
5	.381	.362	.362	.381	.3239	.2858	.362
6	.4572	.4572	.4001	.4001	.4001	.381	.381
7	.4191	.381	.4191	.4763	.4191	.4191	.4001
8	.4191	.4001	.4572	.4382	.381	.381	.381
9	.4001	.4001	.4001	.4572	.4001	.381	.4191
10	.4001	.381	.4191	.4001	.4191	.4001	.4001
11		.4191	.4001	.3429	.4001	.4191	.381
12		.4382	.3429	.3048	.381	.4191	.3239
13		.381	.4001	.2858	.381	.3048	.3429
14	.5335	.4001	.4382	.3239	.381	.3429	.381
15	.4763		.3429	.2858	.3048	.3048	.3239
16	.4572		.3239	.2477	.3239	.3048	.3048
17		.4763	.4191	.362		.362	.4001
18	.4763	.5144	.4763	.4572	.362	.4572	.381
19	.6097	.6097	.6097	.5335	.4954	.5716	.4191
20	.6668	.6287	.5335	.4572	.5716	.5335	.6097
21	.6859	.5525	.4954	.4001	.5525	.5335	.5525
22	.5716	.4763	.4572	.362	.4001	.4001	.4572
23	.4001	.381	.362	.3239	.3239	.3429	.381
24	.381	.3429	.3239	.362	.2667	.2858	.3048
Max	.6859	.6287	.6097	.5335	.5716	.5716	.6097
Min	.381	.3048	.3048	.2477	.2477	.2477	.3048
Avg	.4630	.4226	.4017	.3747	.3711	.3707	.3810

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV MANGNOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0019	.0075		.2054	.2054	.1698	.112
2	.0019	.0075		.168	.1867	.1509	.112
3	.0019	.0075		.168	.1848	.1698	.112
4	.0019	.0075		.168	.168	.1509	.1307
5	.0019	.0075		.1867	.1848	.1509	.1307
6	.0019	.0075		.2054	.2033	.1509	.1494
7	.0019	.0075		.2241	.2402	.2641	.2054
8	.0019	.0075		.2614	.2587	.3018	.2241
9	.0019	.0075		.2427	.168	.2263	.2054
10	.0019			.0019	.0075		
11	1.0059	.3772	.3658	.0075			.0019
12	1.0608	.547	.3734	.0075			.0019
13	1.0974	.5281	.2378				.0019
14	1.134	.6036	.439				.0019
15	1.134		.4207	.0075			.0019
16	.9145	.3772	.3292	.0075			.0019
17		.3772	.2926	.0075			.0019
18		.3018	.2987	.0075			.0019
19			.0019	.0075			.0019
20	.0075		.0019	.0075			.0019
21	.0075		.0019	.0075			.0019
22	.0075		.0019	.0075			.0019
23	.0075		.0019	.0075			.0019
24	.0019	.0075		.2241	.2218	.1698	.1307
Max	1.134	.6036	.439	.2614	.2587	.3018	.2241
Min	.0019	.0075	.0019	.0019	.0075	.1509	.0019
Avg	.3046	.1875	.2128	.0972	.1845	.1905	.0668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV ARALGUNDI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.1478	.2263	.0019	.0075		
2	.5121	.1494	.2263	.0019	.0075		
3	.4572	.1307	.2263	.0019	.0075		
4	.4938	.1478	.2452	.0019	.0075		
5	.5121	.1867	.2641	.0019	.0075		
6	.5853	.2218	.3018	.0019	.0075		
7	.7133	.2772	.3018	.0019	.0075		
8	.7842	.2587	.3018	.0019	.0075		
9	.7133	.2218	.2829	.0019	.0075		
10	.0019			.0019	.0075		
11			.0019	.2587	.3018	.2241	.2012
12			.0019	.2033	.3395	.2054	.1829
13	.0075		.0019	.2614	.3018	.1867	.2195
14	.0075		.0019	.2054		.2241	.2378
15	.0075		.0019	.2218		.2614	.2561
16	.0075		.0019	.1848	.2641	.2614	.2561
17			.0019	.1494	.2263	.2614	.2012
18	.0075		.0019	.0934	.2263	.2614	.1867
19	.0075		.0019	.0075			.0019
20	.0075		.0019	.0075			.0019
21	.0075		.0019	.0075			.0019
22	.0075		.0019	.0075			.0019
23	.0075		.0019	.0075			.0019
24	.5601	.168	.2452	.0019	.0075		
Max	.7842	.2772	.3018	.2614	.3395	.2614	.2561
Min	.0019	.1307	.0019	.0019	.0075	.1867	.0019
Avg	.2837	.1910	.1151	.0682	.1025	.2357	.1347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV ARALGUNDI VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.112	.1132	.1132	.0934	.0943	.0934
2	.1132	.0943	.1132	.0943	.0754	.0943	.0934
3	.0943		.0943	.0943	.0754	.0943	.0934
4	.0943	.0747	.0943	.1132	.0754	.0943	.0934
5	.0943	.0943	.132	.1132	.0747	.1132	.0934
6	.1132	.1307	.1509	.132	.0934	.1132	.0934
7	.1509	.1307	.1698	.1509	.168	.132	.112
8	.1509	.1494	.1509	.1886	.168	.1509	.1307
9	.1698	.1867	.1698	.1886	.168	.1698	.1307
10	.1886	.1132	.2075	.0754	.1867	.1698	.1307
11	.168	.1132	.1886	.0934	.1698	.168	.1494
12	.168	.1698	.1886	.0934	.1886	.1867	.1509
13	.1494	.1698	.1509	.0934	.1698	.1867	.1307
14	.1307	.1509	.132	.0934	.1698	.1307	.0934
15	.1494		.1132	.112	.1509	.1307	.1307
16	.1307		.112		.132	.1307	.1509
17		.0189		.168	.132	.1307	.132
18		.1886		.168	.1509	.1307	.1509
19	.1494	.2452	.1509	.2241	.2263	.2054	.1886
20	.2427	.2263	.2075	.2427	.3018	.2054	.2263
21	.2054	.1886	.2075	.168	.2263	.1867	.1867
22	.1867	.1886	.1886	.168	.1698	.1494	.1509
23	.1307	.1698	.1509	.1307	.132	.112	.1132
24	.132	.112	.132	.132	.1132	.1132	.0934
Max	.2427	.2452	.2075	.2427	.3018	.2054	.2263
Min	.0943	.0189	.0943	.0754	.0747	.0943	.0934
Avg	.1475	.1442	.1508	.1370	.1505	.1414	.1297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 205 / 11 KV BARVE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.1494	.1509		.1494	.1509	.1494
2	.1886	.132	.1509		.132	.132	.1307
3	.1886	.1307	.1509		.1307	.132	.1307
4	.2263	.1494	.1509		.1307	.132	.1307
5	.2641	.1867	.1886		.1307	.1509	.1494
6	.3018	.2218	.1886		.1867	.1886	.168
7	.3206	.2241	.2263		.2241	.2263	.168
8	.2641	.2241	.2641		.2587	.2452	.2054
9	.3395	.2614	.1698		.2772	.2829	.2614
10	.3395	.3018	.2452		.2987	.2452	.2801
11	.3174	.2263	.2641		.2075	.1867	.2054
12	.2614	.2263	.2075	.2801	.1698	.1867	.3018
13	.1867	.2263	.2829	.2987	.1698	.1494	.2801
14	.1867	.2075	.2641	.2987	.1698	.168	.1867
15	.3174		.2641	.2427		.2054	.2241
16	.1867	.1886	.2263	.1867		.1867	.2641
17		.1886		.0373		.1494	.3018
18	.1494	.3018		.2614	.2641	.2241	.3206
19		.3018	.3018	.3734	.3584	.3174	.2829
20	.3734	.3395	.3772	.3734	.3395	.3361	.3772
21	.3361	.3018	.3206	.2987	.3018	.2801	.3395
22	.2614	.2263	.2614	.2241	.2263	.2241	.2641
23	.2054	.1698		.168	.1886	.168	.2075
24	.1867	.168	.1698		.1494	.1698	.1494
Max	.3734	.3395	.3772	.3734	.3584	.3361	.3772
Min	.1494	.1307	.1509	.0373	.1307	.132	.1307
Avg	.2558	.2197	.2298	.2536	.2126	.2016	.2283

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 202 / 11 KV MHASARANG AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0747	.056	.3142	.3361	.8215	.2957
2	.0554	.0747	.056	.3361	.2987	.8215	.2987
3	.056	.0747	.0549	.3361	.2614	.8589	.2801
4	.056	.0747	.0549	.3361	.2241	.8589	.2614
5		.0739	.056	.3547	.2614	.8962	.2801
6		.0739	.056	.3511	.3361	.9896	.2801
7		.0747	.056	.3547		1.0456	.2801
8		.0739	.056	.2241		1.0082	.2801
9	.0747	.0739	.056	.3174		.9335	.2241
10	.0747	.0747	.056	.056		.056	.056
11	1.4632	.0747	.056	.056		.056	.056
12	1.8671	.0554	.056			.056	.0549
13	1.8671	.0554	.056		.056	.056	.0549
14	1.6804	.056	.056	.0747	.056	.056	.0543
15	1.8671	.056	.0373	.0747	.056	.056	.0537
16	1.6804	.056	.056	.168	.056	.056	.0537
17		.0566	.056	.0747	.056	.056	.0537
18		.0554		.0747	.056	.056	.0537
19		.056	.056	.0747	.056	.0747	.0543
20		.056	.0747	.0747	.056	.0747	.0537
21	.0747	.056	.0566	.0747	.056	.0747	.0537
22	.0747	.056	.3361	.0747	.056	.0747	.0537
23	.0747	.056	.3361	.0747	.9335	.056	.0537
24	.0554	.0747	.0549	.3361	.3734	.9335	.2772
Max	1.8671	.0747	.3361	.3547	.9335	1.0456	.2987
Min	.0554	.0554	.0373	.056	.056	.056	.0537
Avg	.6924	.0652	.0802	.1915	.1992	.4178	.1466



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV VENGRUL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373		.0373	.4251	.3734	.2987	
2	.0373		.0373	.4108	.3734	.2987	
3	.0373		.0373	.4108	.3361	.2987	
4	.0373		.056	.4108	.3361	.2801	
5	.0373		.056	.4294	.2614	.2987	
6	.0373		.056	.4481	.2241	.3361	
7	.0373	.056	.056	.4668	.1494	.3734	
8	.0373	.056	.056	.4854	.1494	.3361	
9	.0373	.056	.056	.4854	.1867	.2987	.0747
10	1.643	.056	.056	.0187	.056		.0739
11	2.1098	.0373	.056	.0187	.056	.0187	.0739
12	2.1285	.0373	.0187	.0187	.056	.0187	.0724
13	2.0911	.0373	.0187		.056	.0187	.0185
14	2.0538	.0373	.0187		.0554	.0187	.0181
15	1.9418	.0373	.0373		.0554	.0373	.0179
16	1.7924	.0373	.0373		.056	.0373	.0179
17		.056	.0373	.112	.056	.0373	.0179
18		.0373	.4481	.112		.0373	.0179
19		.0373	.0373	.056	.056	.0373	.0179
20		.0373	.0373	.056	.056	.0373	.0179
21		.0373	.056	.056	.056	.0373	.0179
22		.0373	.4481	.056	.056	.0373	.0179
23		.0373	.4294	.056	.3696	.0187	.0179
24	.037		.0373	.4294	.3547	.3361	
Max	2.1285	.056	.4481	.4854	.3734	.3734	.0747
Min	.037	.0373	.0187	.0187	.0554	.0187	.0179
Avg	.8314	.0428	.0926	.2481	.1646	.1542	.0328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 204 / 11 KV DONAWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174		.0187	.0187	.0187	.0189	.0185
2	.3174		.0187	.0187	.0187	.0187	.0185
3	.3547		.0187	.0187	.0187	.0187	.0185
4	.4481		.0187	.0187	.0187	.0187	.0185
5	.5228		.0187	.0187	.0187	.0187	.0187
6	.5601		.0187	.0187	.0187	.0187	.0185
7	.5788		.0187	.0187	.0187	.0185	.0187
8	.5914		.0187	.0187	.0187	.0187	.0187
9	.6348	.0187	.0187	.0187	.0187	.0185	.0187
10	.056	.0187	.0187	.0747	.0187	.0187	.0187
11	.0366	.0187	.0187	.0934	.1867	.0373	.0187
12	.0373	.0187	.0187		.168	.0373	
13	.0373	.0187	.0373		.1867	.0373	.0179
14	.037	.0187	.0373		.1867	.0373	.0179
15	.037	.0187	.0187	.0934	.1109	.0373	.0358
16	.0373	.0187	.0373	.0934	.0739	.0373	.0358
17		.0187	.056	.0754	.056	.0187	.0179
18		.0187	.056	.0747	.0373	.0373	.0177
19		.0187	.0373	.0187	.037	.0187	.0179
20		.0187	.0187	.0187	.037	.0187	.0177
21		.0187	.0187	.0187	.037	.0187	.0177
22		.0187	.0187	.0187	.037	.0187	.0177
23		.0187	.0187	.0187	.0185	.0187	.0177
24	.2957		.0187	.0187	.0187	.0185	.0187
Max	.6348	.0187	.056	.0934	.1867	.0373	.0358
Min	.0366	.0187	.0187	.0187	.0185	.0185	.0177
Avg	.2882	.0187	.0249	.0374	.0574	.0241	.0198

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 205 / 11 KV SHELOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.3734	.2801	.2987	.3361	.2241	.2427
2	.4108	.3361	.2801	.2587	.2987	.2241	.2241
3	.3921	.3361	.2801	.2614	.2987	.2241	.2241
4	.3734	.3361	.2801	.2801	.2614	.2241	.2241
5	.3734	.2987	.2801	.2801	.2614	.2402	.2427
6	.3734	.2987	.2614	.2987	.2614	.2427	.2801
7	.3734	.2614	.2987	.3174	.2614	.2614	.2987
8	.4481	.2987	.2987	.3361	.2987	.2614	.2801
9	.3921	.3174	.3361	.3174	.2987	.2614	.3361
10	.3921	.2987	.3734	.3174	.2987		.3174
11	.5601	.2987	.2987	.2614	.2987	.2614	.3326
12	.4854	.2987	.2987	.2641	.3361	.2614	.2865
13	.4854	.2614	.2614		.2614	.2614	.2715
14		.2614	.2987		.2587	.2987	.2353
15	.4668	.3326	.2801	.2614	.2587	.2614	.2353
16	.4108	.3734	.2427	.2241	.2218	.2987	.2328
17		.4108	.2614	.3547	.2241	.2801	.2715
18		.3696	.2987	.3547	.2614	.3174	.3045
19	.3921	.3734	.4108	.3734	.3734	.4481	.3582
20	.4854	.5228	.4854	.4108	.3326	.4108	.4298
21	.4481	.4435	.4481	.3361	.2987	.3734	.4119
22	.4481	.3734	.3734	.3734	.2957	.3174	.3224
23	.4108	.3361	.3361	.3734	.2772	.2801	.2534
24	.4108	.3734	.2987	.3361	.3361	.2587	.2427
Max	.5601	.5228	.4854	.4108	.3734	.4481	.4298
Min	.3734	.2614	.2427	.2241	.2218	.2241	.2241
Avg	.4259	.3410	.3151	.3132	.2879	.2823	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 206 / 11 KV KARADWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1494	.0747	.112	.1494	.0934	.0934
2	.1867	.1494	.0747	.112	.1494	.0934	.0924
3	.1867	.1132	.0747	.112	.112	.0934	.0924
4	.168	.1109	.0934	.1307	.112	.112	.112
5	.168	.1494	.112	.168	.1494	.112	.1478
6	.168	.1509	.1494	.1867	.1494	.1478	.1867
7	.168	.168	.1867	.2075	.1867	.1867	.2241
8	.1848	.1867	.1494	.2241	.2241	.1478	.1867
9	.2241	.2241			.2427	.1494	.168
10	.2427	.1867	.2241	.2054	.2241	.1478	.2033
11	.1867	.1494	.1867	.1494	.1867	.1494	.2033
12	.168	.1494	.2987		.1478	.1109	.1595
13	.1494	.1494	.2054		.1478	.1867	.0886
14	.1867	.1494	.2241		.1478	.1494	.1595
15	.1867	.2987	.1867	.1494	.1494	.1494	.181
16	.2241	.112	.2427	.2427	.1867	.1494	.1791
17		.112	.2801	.2614	.2241	.1867	.2149
18		.112	.2801	.2614	.2614	.168	.2507
19	.2614	.2241	.3018	.3547	.2801	.2614	.2328
20	.3361	.3734	.3734	.3174	.2987	.2987	.2865
21	.3174	.2801	.2987	.2987	.2241	.2614	.2835
22	.2614	.2614	.2427	.2614	.1867	.2054	.2126
23	.2241	.2241	.2054	.2241	.1494	.1494	.1433
24	.2054	.1867	.112	.1494	.1867	.112	.1109
Max	.3361	.3734	.3734	.3547	.2987	.2987	.2865
Min	.1494	.1109	.0747	.112	.112	.0934	.0886
Avg	.2095	.1821	.1990	.2064	.1865	.1592	.1755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 207 / 11 KV NANDOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2241	.1307	.1663	.1867	.112	.1294
2	.1867	.1867	.112	.1494	.1494	.112	.1294
3	.168	.1494	.1109	.1494	.1494	.112	.1307
4	.1867	.1494	.112	.168	.1494	.1307	.1494
5	.1867	.1848	.1307	.1867	.1867	.1494	.1494
6	.2054	.1867	.1494	.1867	.1867	.168	.168
7	.2054	.1867	.1867	.2054	.1867	.1867	.1867
8	.2241	.2241	.1867	.2241	.1494	.1663	.2033
9	.2054	.2427	.2054	.2241	.1494	.1494	.1867
10	.2054	.2054	.168	.1867	.168	.1494	.1848
11	.1867	.1867	.1494	.1867	.168	.1494	.1109
12	.1848	.168	.2054		.1478	.1307	.181
13	.1494	.168	.2054		.1307	.1307	.1448
14	.1867	.168	.2427	.168	.1307	.1307	.181
15	.2054	.1307	.2054	.168	.1307	.1307	.1433
16	.2054	.2054	.168	.168		.1494	.1267
17		.2054	.2241	.1867		.1867	.1448
18		.1867	.2241	.1867	.2241	.2054	.181
19	.2614	.2241	.2987	.2427	.2614	.2801	.2149
20	.3361	.2801	.3361	.2641	.2987	.2801	.2896
21	.3174	.2614	.2801	.2241	.2241	.2054	.2534
22	.3174	.2241	.2427	.2241	.1867	.1867	.2172
23	.2614	.1867	.1867	.1867	.1494	.1494	.1612
24	.2054	.2218	.1494	.1867	.1867	.1494	.1494
Max	.3361	.2801	.3361	.2641	.2987	.2801	.2896
Min	.1494	.1307	.1109	.1494	.1307	.112	.1109
Avg	.2180	.1982	.1921	.1927	.1773	.1625	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044] BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 208 / 11 KV VAKIGHOL AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
1		.0709
2		.0532
3		.0532
4		.0532
5		.0532
6		.0537
7		.0537
8		.0543
9		.0543
10		.0554
11		.0554
12		.0914
13		.0914
14		.0905
15		.3658
16		.3658
17		.3258
18		.2896
19		.0716
20		.0724
21	.0886	.0724
22	.0886	.0724
23	.0886	.0724
24		.0709
Max	.0886	.3658
Min	.0886	.0532
Avg	.0886	.1110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3993	.381	.3429	.4001	.3232	.3429	.3239
2	.3803	.381	.3048	.4001	.3042	.3429	.3048
3	.3803	.362	.2477	.381	.3033	.3239	.2667
4	.3803	.4001	.2286	.4001	.3042	.3429	.2858
5	.4183	.4191	.2858	.4191	.3419	.4001	.3429
6		.4191	.3048	.4572	.4175	.4191	.381
7	.4749	.4382	.3429	.4572	.4183	.4191	.4382
8	.4934	.4382	.3239		.4554	.4382	.4382
9	.4753	.4191	.3239		.4373	.4001	.4382
10	.4763	.4382	.3429	.3803	.4191	.4001	.4001
11	.4382	.4191		.4175	.4001	.4001	.4001
12	.4191	.4572	.5144	.4369	.4001	.3239	.4191
13	.4954	.4382	.4382	.3993	.4001	.381	.3429
14	.3048	.4191	.4382	.3799	.362	.362	.381
15	.4954		.4191	.3613	.4001	.3429	.381
16	.4572		.4763	.3416		.362	.381
17		.4191	.4572	.4559	.4763	.362	.4763
18		.5525	.4763	.5514	.5525	.4954	.4763
19	.6859	.7049	.5716	.6066	.8002	.7049	.6668
20	.6859	.7049	.7049	.6066	.7621	.6668	.7049
21	.6478	.6668	.6478	.5313	.5906	.6287	.6287
22	.5716	.5525	.5716	.4373	.5335	.5335	.4954
23		.4191	.5144	.3803	.362	.4001	.381
24	.4373	.381	.381	.4001	.3423	.3429	.362
Max	.6859	.7049	.7049	.6066	.8002	.7049	.7049
Min	.3048	.362	.2286	.3416	.3033	.3239	.2667
Avg	.4759	.4650	.4200	.4364	.4394	.4223	.4215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 202 / 11 KV HEDEWADE AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	02-JUN-18	03-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
1		.0762	
2		.0762	
3		.0762	
4		.0762	
5		.0762	
6		.0762	
7		.0762	
8	.1143	.0762	
9	.0762		
10	.0762		.0191
11	.2858		.0191
12	.2096		.0191
13	.1715		.0191
14	.1715		.0191
15			.0191
16			.0191
17	.0953		.0191
18	.0762		.0191
19	.0762		.0191
20	.0762		.0191
21	.0762		.0191
22	.0762		.0191
23	.0762		
24		.0762	
Max	.2858	.0762	.0191
Min	.0762	.0762	.0191
Avg	.1184	.0762	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 203 / 11 KV NILPAN AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0949	.0732		.0572	.057	.0549	.0572
2	.0761	.0732		.0572	.057	.0549	.0572
3	.0761	.0732		.0572	.057	.0549	.0572
4	.0761	.0732		.0572	.0569	.0549	.0572
5	.1139	.0732		.0572	.057	.0549	.0572
6	.2662	.0732		.0572	.057	.0552	.0572
7	.5313	.2012		.0572	.057	.0549	.0572
8	.6845	.2477	.0381		.057	.0549	.0572
9	.5108	.2667	.0381		.057	.0549	.0572
10	.0732	.0953	.0381	.0761	.0549	.0572	.0572
11	.0732	.0762		.133	.1097	.0381	.1143
12	.0732	.0953	.0762	.133	.1715		.0953
13	.0732	.0953	.0762	.1521	.1829	.0572	.0762
14		.0762	.0762	.1331	.1097	.0762	.0762
15			.0762	.152	.0732	.1334	.0762
16	.1097		.0762	.1137		.0572	.0572
17		.0762	.0572	.0951	.0732	.1143	.0572
18		.0762	.0762	.0951	.0549	.0381	.0381
19	.1097	.0762	.0762	.057	.0549	.0572	.0572
20	.1097	.0762	.0572	.057	.0549	.0572	.0572
21	.0732	.0762	.0572	.057	.0549	.0572	.0572
22	.0732	.0762	.0572	.057	.0549	.0572	.0572
23		.0762	.0572	.057	.0549	.0572	.0191
24	.1141	.0732		.0572	.057	.0549	.0572
Max	.6845	.2667	.0762	.1521	.1829	.1334	.1143
Min	.0732	.0732	.0381	.057	.0549	.0381	.0191
Avg	.1743	.1	.0622	.0830	.0728	.0612	.0612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 402 / 33 KV Shriram LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.0572			
2			.0572			
3			.0572			
4			.0572			
5			.0572			
6			.0572			
7			.0572			
8			.0572			
9			.0572			
10			.0572	.1143	.0572	.0572
11		.0572	.0572	.1143	.0572	.0572
12		.0572	.0572	.1143	.0572	.0572
13		.0572	.0572		.0572	.0572
14	.1143	.0572	.0572	.0572	.0572	.0572
23		.0572		.0572		.0572
24			.0572			
Max	.1143	.0572	.0572	.1143	.0572	.0572
Min	.1143	.0572	.0572	.0572	.0572	.0572
Avg	.1143	.0572	.0572	.0915	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 201 / 11 KV DASEWADI AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075		.0732		.2096	.0739	
2	.1063		.0732		.2096	.0554	
3	.1063		.0732		.2286	.0739	
4	.1052		.0724		.2667	.0747	
5	.1063		.0724		.2667	.0934	
6	.1063		.0724		.2858	.112	
7	.1052		.0724		.2858	.1109	
8	.1063		.0895		.4001	.1307	
9	.104		.0895	.5373	.3048	.0914	
10	.1052		.0716	.0554	.0572	.0537	.0572
11	1.2986		.0732	.0537	.0572	.0554	.0572
12	1.0679		.0732	.0686	.0572	.0549	
13	1.1403			.0686	.0572	.056	
14	1.0208		.0895	.0693	.0572	.0566	
15	.9991			.0724	.0366	.056	
16	.9114		.0867	.0537	.0366	.0554	.0532
17		.0549	.0953	.0549	.0358		.052
18		.0732	.4191	.0572	.0177		.0543
19		.0747	.0762	.0572	.0187		.056
20		.0934	.0762	.0572			.0377
21		.0739	.0953	.0191	.0191		.0377
22		.0739	.0953	.0191	.0191		.037
23		.0732		.0191	.0187		.0366
24	.1063		.0732		.1715	.0747	
Max	1.2986	.0934	.4191	.5373	.4001	.1307	.0572
Min	.104	.0549	.0716	.0191	.0177	.0537	.0366
Avg	.4472	.0739	.0959	.0842	.1355	.0752	.0479

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 202 / 11 KV PATGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0895		.0732			.0739	
2	.0895		.0549			.0554	
3	.0886		.0732			.0739	
4	.0886		.0905			.0739	
5	.0886		.1267			.0934	
6	.1595		.1267			.0934	
7	.1772		.1448			.1109	
8	.1578		.1254			.112	
9	.1402		.1254	.1075	.1334	.1448	
10	.1928		.128	.1478	.1524	.1254	.1715
11	.1829		.1294	.1612	.1715	.128	.0762
12	.1267		.128	.0343	.1524	.128	
13	.1433		.1254	.0343	.1143	.112	
14	.1075		.1254	.0347	.1143	.1698	
15	.1595				.1097		
16	.1578		.0867	.1254			.124
17		.1463	.0953	.1829			
18		.1463	.0953	.1715			.0347
19		.2054	.1905	.1715	.112		.2075
20		.2427	.2286	.1715	.1334		.2054
21		.2033		.1334	.1524		.1886
22		.1294		.1143	.1143		.1478
23		.128		.0953	.112		.1097
24	.1791		.1097		.0762	.0934	
Max	.1928	.2427	.2286	.1829	.1715	.1698	.2075
Min	.0886	.128	.0549	.0343	.0762	.0554	.0347
Avg	.1370	.1716	.1192	.1204	.1268	.1059	.1406

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 203 / 11 KV SHIVDAV AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6984		.0183			.0185	
2	.691		.0183			.0185	
3	.6379		.0183			.0185	
4			.0181			.0187	
5	.631		.0181			.0187	
6	.6733		.0181			.0187	
7	.7537		.0181			.0185	
8	.7888		.0358			.0373	
9	.7888		.0358	.0358	.0191	.0179	
10			.0549	.0554	.0191	.0179	.0381
11	.0549		.0554	.4835	.2096	.1109	.0572
12	.0543		.0554	.4287	.1524	.1097	
13	.0543		.0549	.4334	.1334	.056	
14	.0537		.0537	.3467	.1143	.0566	
15	.0532				.1097	.056	
16	.0526		.0347	.3224			
17		.0549	.0381	.3292	.0537		
18		.0366	.0381	.2858	.1063		.1063
19		.0373	.0381	.0381	.0373		
20		.0373	.0381	.0381	.0381		.0187
21		.037		.0381	.0381		.0187
22		.037		.0381	.0381		.0185
23		.0366		.0191	.0373		.0183
24	.6805		.0183			.0187	
Max	.7888	.0549	.0554	.4835	.2096	.1109	.1063
Min	.0526	.0366	.0181	.0191	.0191	.0179	.0183
Avg	.4444	.0395	.0339	.2066	.0790	.0382	.0394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 201 / SILVER ZONE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9922			.0343	.8682	1.046
2	.8682	.9568			.0343	.8682	.9259
3	.8328	.9036			.0343	.8505	.8745
4	.8328	.8682			.0343	.815	.8573
5	.815	.815			.0343	.7973	.8402
6	.815	.7796			.0343	.815	.8402
7	.8505	.8328			.0343	.815	.8402
8	.9745	1.0454			.0343	.7973	.8402
9	1.1163	1.3546			.0171		1.166
10	1.5421	1.7147			.0343		1.7718
11	1.5583	1.6118			.0343		2.0553
12	1.4934	1.8519			.0343		1.949
13	1.5258	1.749	.0343	.0162	1.6461		1.8073
14		1.6975	1.8427	.0162	1.9376		1.825
15		1.6804	1.8073		1.9204		1.4529
16	1.3473	1.6632			1.7833		1.5947
17	1.5421		1.3717		1.8861		1.9136
18		1.0064	1.286		1.8427	1.1145	1.382
19	1.4883	1.0389		.0343	1.7364	1.046	1.3717
20	1.4706	1.0389	.0343	.0343	1.2934	1.0288	1.0288
21	1.2934	1.0389	.0343	.0343	1.382	1.2003	1.0288
22	1.3466	1.0876	.0343	.0343	1.4352	1.3375	.8745
23	1.4529	1.1317	.0514	.0343	1.2934	1.286	
24	1.3112	1.0454			.0343	.9214	1.166
Max	1.5583	1.8519	1.8427	.0343	1.9376	1.3375	2.0553
Min	.815	.7796	.0343	.0162	.0171	.7973	.8402
Avg	1.2239	1.2132	.7218	.0291	.7744	.9707	1.2805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 202 / HUPARI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2048	1.134	1.2003	1.0974	.7716	1.0808	1.0974
2	1.1517	1.0808	1.166	1.046	.7716	1.0099	1.046
3	1.134	1.0277	.9945	1.0288	.823	.9391	1.0288
4	1.0808	.9922	.9945	1.0117	.8916	.8682	1.0117
5	1.0631	1.0099	1.0288	.9945	.9259	.9391	.9774
6	1.134	1.0454	1.046	.9774	.9602	1.0099	.9945
7	1.0631	1.0454	.9774	.9774	.9945	1.0099	.9945
8	1.0631	1.0277	.9415	1.046	.9945	.9922	1.0117
9	1.0454	1.0117	.9902	1.046	.9431		1.0117
10	1.6557	1.0802	1.2757	1.1363	1.2174		1.1871
11	1.7044	1.2517	1.5061	1.1525	1.4403		1.3289
12	1.5258	1.2689	1.5947	1.3148	1.4746		1.3289
13	1.4609	1.2346	1.5238	1.2986	1.4575		1.3643
14	1.4934	1.2003	1.3466	1.1525	1.2517		1.2071
15	1.4934	1.2346	1.4352	1.2174	1.3889		1.3112
16	1.5421	1.286	1.5415	1.166	1.3203		1.3643
17	1.4122	1.286	1.6124	.9602	1.4403		1.4175
18	1.4352	1.1687	1.3717	.9945	1.4706	1.5089	1.2757
19		1.2661	1.6289		1.4529	1.4575	1.2003
20		1.2661	1.5089	.703	1.5592	1.4232	1.2003
21		1.3148	1.3889	.7202	1.3435	1.3546	1.2003
22		1.331	1.3032	1.0631	1.382	1.286	1.286
23		1.3032	1.1831	1.0974	1.2226	1.2517	
24	1.2934		1.2346	1.1145	1.046	1.134	1.2003
Max	1.7044	1.331	1.6289	1.3148	1.5592	1.5089	1.4175
Min	1.0454	.9922	.9415	.703	.7716	.8682	.9774
Avg	1.3135	1.1681	1.2831	1.0572	1.1893	1.151	1.1759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 203 / YALGUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.7865	.7716	.0686	.0171	.0686	.0857
2	.6882	.8356	.7888	.0686	.0171	.0686	.0857
3	.7209	.852	.7888	.0686	.0171	.0686	.1029
4	.7209	.852	.823	.0686	.0171	.0857	.1029
5	.7373	.852	.8916	.0686	.0171	.0857	.0857
6	.8356	.9012	.9088	.0514	.0171	.0857	.1029
7	.9667	1.0486	1.0288	.0514	.0171	.0857	.0857
8	1.0322	1.0486	1.0064	.0514	.0171	.0857	.0514
9	.9995	1.0288	.9577	.0514	.0171		.0343
10	.0162	.0343	.0343	.0325	.0343		.0343
11	.0162	.0343		1.0226	.8573		.5735
12	.0162	.0343		1.0064	.8402		.5735
13	.0162			.9902	.8059		.5243
14				.9739	.8402		.4752
15	.0162	.0343	.0343		.6859		.4096
16	.0162	.0343	.0343		.703		.3932
17	.0162	.0343	.0514	.7716			.4588
18		.0325	.0343	.703		.6344	.4588
19	.0343	.0325	.0343	.0171	.0686	.0343	.0343
20	.0343		.0343	.0171	.0686	.0343	.0343
21	.0343		.0343	.0171	.0686	.0857	.0343
22	.0343	.0325	.0514	.0171	.0686	.0857	.0343
23	.0343	.0343	.0514	.0171	.0686	.0857	
24	.6718	.7865	.823	.0514	.0171	.0686	.0686
Max	1.0322	1.0486	1.0288	1.0226	.8573	.6344	.5735
Min	.0162	.0325	.0343	.0171	.0171	.0343	.0343
Avg	.3794	.4665	.4591	.2812	.2400	.1109	.2106



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 204 / RENDAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	1.5947	1.5432	1.5432	1.3717	1.5947	1.5432
2	1.2803	1.4632	1.3717	1.3717	1.3717	1.4632	1.5432
3	1.0974	1.2803	1.3717	1.3717	1.2003	1.2803	1.3717
4	1.0974	1.2803	1.2003	1.2003	1.2003	1.2803	1.3717
5	1.0974	1.2803	1.3717	1.2003	1.3717	1.4632	1.2003
6	1.2803	1.448	1.5432	1.5432	1.5432	1.5947	1.3717
7	1.2803	1.5947	1.7147	1.7147	1.7147	1.7147	1.5432
8		2.1795	2.1102	1.8861	2.0576	2.0119	
9	2.1795	2.915	2.7595	2.915	2.7435		1.0288
10	2.4348	3.0864	2.9492	2.7595	3.0864		1.0974
11	2.9218	3.2579	2.7854	2.7595	3.0864		.1829
12	2.4348	1.2003	3.1131	2.5972	3.0864		
13	1.6232	1.5432	2.0119	2.5972	1.8861		
14	2.5972	1.8861	1.7147	.9739	1.8861		.5487
15	2.5972	2.2291	2.6825	1.3717	2.915		.1829
16	2.7595	2.572	2.9492	2.0576	3.0864		.7316
17	2.9218	3.0864	2.9492	2.0576	3.0864		.7316
18		2.9218	3.2579	2.572	2.7854	2.4006	.7316
19	2.2939	2.4348	2.572	2.4006	2.4577		1.0288
20	1.7147	2.2725	2.4006	2.0576	2.0119	2.2291	1.0288
21	1.7147	2.1102	2.0576	2.0576	1.8442	2.0576	1.3717
22	1.7147	1.9479	1.8861	1.8861	1.8442	1.8861	1.3717
23	1.8442	1.8861	1.7147	1.8861	1.8442	1.8861	
24	1.4632	1.7147	1.8861	1.5432	1.7147	1.7147	1.7147
Max	2.9218	3.2579	3.2579	2.915	3.0864	2.4006	1.7147
Min	1.0974	1.2003	1.2003	.9739	1.2003	1.2803	.1829
Avg	1.8922	2.0494	2.1632	1.9302	2.1332	1.7555	1.0848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 207 / HUPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.0686	.0514	1.5089		1.6632	1.1317
2	.0686	.0686	.0514	***		1.6632	1.1831
3	.0686	.0686	.0514	1.6461		1.6461	1.2346
4	.0686	.0686	.0514	1.6975		1.6289	1.2689
5	.0686	.0686	.0514	1.7661		1.6461	1.3032
6	.0686	.0686	.0514	1.8176		1.6804	1.3203
7	.0686	.0514	.0514	1.8519		1.8004	1.3375
8	.0686	.0686	.0487	1.9719		1.7147	1.3375
9	.0686	.0686	.0487	1.8004			1.3032
10	.0649	.0686	.0857	.0487			.0686
11	.0162	1.9547	2.1948	.0487			.0686
12	1.7044	2.0748	2.1776	.0487	.0857		.0686
13	1.8667	2.0576	2.0919	.0487	.0686		.0686
14	1.818	2.0405	2.1262	.0487	.0686		.0686
15	1.7856	2.0405	2.1434	.0514	.0686		.0686
16	1.818	2.0576	1.9033	.0514	.0686		.0686
17	1.7856	1.8861	1.749		.0686		.0686
18		1.7693	1.749		.0686	.0514	.0686
19	.0686		.0686		.0686	.0686	.0686
20	.0686	.0487	.0514		.0686	.0686	.0686
21	.0686	.0487	.0514		.0686	.0857	.0686
22	.0686	.0487	.0514		.0686	.0686	.0686
23	.0686	.0514	.0514		.0686	.0857	
24	.0686	.0686	.0686	1.4232		1.6461	1.0802
Max	1.8667	2.0748	2.1948	15.998	.0857	1.8004	1.3375
Min	.0162	.0487	.0487	.0487	.0686	.0514	.0686
Avg	.5169	.7311	.7092	1.8722	.0700	1.0345	.5823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 208 / BIRDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.0343	.8745	.7716	.7701	.3258
2	.0343	.0343	.0343	.8573	.7888	.7865	.3429
3	.0354	.0343	.0343	.823	.7545	.7865	.3429
4	.0354	.0343	.0343	.7888	.7545	.8029	.3601
5	.0343	.0343	.0343	.7373	.823	.8356	.3772
6	.0343	.0343	.0343	.7202	.8745	.8684	.3944
7	.0343	.0343	.0343	.703	.7716	.9667	.3944
8	.0343	.0343	.0325	.8059		.9831	.3601
9	.0343	.0343	.0325	.6859	.6173		.3772
10	.0325	.0343	.0177	.0325	.0171		.0171
11	.7954	1.166	.124	.0325	.0171		.0171
12	1.0064	1.3889	1.1961	.0325	.0171		.0171
13	1.0389	1.3717	1.2289		.0171		.0171
14	1.0713	1.3375	1.278		.0171		.0171
15		1.286	1.2944		.0171		.0171
16	1.1363	1.2346	1.2289	.0343	.0171		.0171
17	1.0226	.5487		.0343	.0343		.0171
18		.0325	.5487	.0343	.0343	.0171	.0171
19	.0343	.0325	.0343	.0343	.0343	.0171	.0171
20	.0343	.0325	.0343	.0343	.0343	.0171	.0171
21	.0343	.0325	.0343	.0343	.0343	.0343	.0171
22	.0343	.0325	.0514	.0343	.0343	.0343	.0171
23	.0343	.0343	.0514	.0343	.0343	.0343	
24	.0343	.0343	.0343	.8573	.7373	.7209	.3086
Max	1.1363	1.3889	1.2944	.8745	.8745	.9831	.3944
Min	.0325	.0325	.0177	.0325	.0171	.0171	.0171
Avg	.3009	.3711	.3244	.3917	.3153	.5117	.1655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 201 / PATTANKODOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1262	2.0233	1.8347	.0686	.056		.0747
2	2.0576	2.0233	1.8004	.0686	.056		.0747
3	2.0576	2.0233	1.8004	.0686	.056		.0747
4	2.0748	2.0233	1.8176	.0686	.056		.0934
5	2.1605	2.0233	1.869	.0686	.056		.0934
6	2.2634	2.0919	1.9547	.0686	.056		.0934
7	2.4691	2.1605	2.1776	.0686	.056		.0934
8	2.4863	2.1948		.0686	.0747		.0747
9	2.3663	2.0919	1.5432	.0686	.056		.0747
10		.0514		.0686			
11	.0343	.0343	.0343			1.6804	1.3375
12	.0343	.0343	.0343	2.5206		1.7924	1.3375
13	.0343	.0343	.0343	2.5206	1.6804	1.8298	1.3375
14	.0343	.0343		2.5034	1.6804		1.1145
15	.0343	.0343		2.5377	1.2003	1.7737	1.0974
16	.0343	.0343		2.4006	1.2003	1.6804	1.0974
17	.0343				1.6804	1.7177	1.0974
18		.0343				.0747	
19		.0686		.0747		.0747	
20		.0686		.0747		.0747	
21		.0686		.0747		.0934	
22		.0686		.0747		.0934	
23		.0686		.056		.0934	
24	2.1262	.0343	1.8347	.0686	.056		.0747
Max	2.4863	2.1948	2.1776	2.5377	1.6804	1.8298	1.3375
Min	.0343	.0343	.0343	.056	.056	.0747	.0747
Avg	1.3193	.8402	1.3946	.6473	.5347	.9149	.5436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 202 / 11 kV INGALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343		.0343		1.1576		.4294
2	.0343		.0343		1.0829		.4294
3	.0343		.0343		1.0829		.4108
4	.0343		.0343		1.0829		.4294
5	.0343		.0343		1.1576		.4668
6	.0343		.0343		1.1203		.5228
7	.0343		.0343		1.1203		.5228
8	.0343		.0343		1.2696		.5228
9	.0343		.0343		.056		.0373
11	1.8861	2.1948	2.1262	.0343		.0373	.0343
12	1.8861	2.1948	2.1262	.0343		.0373	.0343
13	1.8004	1.9719		.0343		.0373	.0343
14	1.7833	1.8861		.0343		.0373	.0343
15	1.9204	1.8861		.0343		.056	.0343
16	1.9204	1.8861		.0343		.056	.0343
17						.056	.0343
18		1.5775				.056	
19		.0343		.056		.056	
20		.0343		.056		.056	
21		.0343		.056		.056	
22		.0343		.056		.056	
23		.0343		1.1763		.3734	
24	.0343		.0343		1.1203		.5228
Max	1.9204	2.1948	2.1262	1.1763	1.2696	.3734	.5228
Min	.0343	.0343	.0343	.0343	.056	.0373	.0343
Avg	.7212	1.1474	.3830	.1460	1.0250	.0747	.2667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 203 / 11 kV SANGWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.9774	.1029			.0747
2	.9774		.9431	.0686			.0747
3	.9774		.9431	.0686			.0747
4	1.0117		.9602	.1029			.0747
5	1.1145		1.0117	.1029			.0747
6	1.3546		1.1488	.1029			.0747
7	1.5604		1.3546	.1029			.0934
8	1.5775		1.3546	.1029			.0934
9	1.3889		1.286	.1029			.0934
10				.1029			
11	.0686	.0686	.0343				.823
12	.0686	.0686	.0343	1.8519			.823
13	.0686	.0686		1.8519			.823
14	.0686	.0686		1.8519	1.3717	.9149	.823
15	.0686	.0686		1.8519	.823	1.0269	.823
16	.0686	.0686			.823	1.0456	.7888
17						1.0269	.7888
18		.0686				.0934	
19		.0686				.0934	
20		.0686				.0747	
21		.0686				.0747	
22		.0686				.0747	
23		.0686				.0747	
24	1.0117	1.0288	.9774	.1029			.0747
Max	1.5775	1.0288	1.3546	1.8519	1.3717	1.0456	.823
Min	.0686	.0686	.0343	.0686	.823	.0747	.0747
Avg	.7590	.1425	.9188	.5647	1.0059	.4500	.3821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 204 / 11 KV INGALI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543		.1543	.1543			.1307
2	.1543		.1372	.1543			.1307
3	.1372		.1372	.1543			.1307
4	.1372		.1372	.1543			.1307
5	.1543		.1543				.1494
6	.1886		.1886				.2054
7	.1715		.1543				.2054
8	.1715		.1543				.2054
9	.1543		.1543		.168		.168
11	.1372	.1372	.1543	.1543		.1494	.1543
12	.1372	.1372	.1543	.1372		.168	.1543
13	.1372	.1372		.1372		.168	.1372
14	.1372	.1372		.1372		.168	.1372
15	.1372	.1372		.1372		.1494	.1372
16	.1372	.1372		.1372		.1307	.1372
17						.1494	.1372
18		.1372				.1307	
19		.1543		.168		.1307	
20		.2058		.1867		.1867	
21		.1886		.1867		.1867	
22				.1867		.1867	
23		.1715		.1494		.168	
24	.1715		.1543	.1543			.1307
Max	.1886	.2058	.1886	.1867	.168	.1867	.2054
Min	.1372	.1372	.1372	.1372	.168	.1307	.1307
Avg	.1511	.1528	.1529	.1556	.168	.1594	.1519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 205 / 11 KV SANGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.463	.4801	.4801	.4854		.5041
2	.4801	.463	.4801	.4458	.4668		.4668
3	.4801	.463	.4801	.4458	.4668		.4668
4	.5144	.463	.4801	.4458	.4668		.4668
5	.583	.5144	.5144	.4458	.5601		.5601
6	.6859	.6859	.6173	.4801	.5975		.5975
7	.6173	.7373	.6344	.4801	.6722		.7095
8	.6859	.823	.7202	.4801			.6722
9	.8916	.9602	1.0288	.4115	.7468		1.0456
10		1.166		.3944			
11	1.166	1.166		.3772		1.307	1.2003
12	1.166	1.166		.3772		1.1949	1.166
13	1.166	1.166				1.0456	1.166
14	1.166	1.166				.9709	1.166
15	1.2003	1.166				1.1203	1.166
16	1.2003	1.166				1.3443	1.166
17						1.4937	1.166
18		1.166				.6535	
19				.4668		.5601	
20		.6859		.5228		.5975	
21		.583		.5975		.5975	
22		.5487		.5601		.5601	
23		.5144		.5601		.5228	
24	.5144	.4801	.4801	.4801	.5228		.5228
Max	1.2003	1.166	1.0288	.5975	.7468	1.4937	1.2003
Min	.4801	.463	.4801	.3772	.4668	.5228	.4668
Avg	.8123	.8051	.5916	.4695	.5539	.9206	.8358



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6859	.7373	.7716	.7842		.7468
2	.703	.6859	.703	.7716	.7468		
3	.6859	.6859	.6859	.7716	.7468		.7095
4	.6859	.6859	.6859	.7716	.7468		.7095
5	.7373	.6859	.7202	.823	.7842		.7468
6	.823	.7888	.823	.8573	.8402		.8215
7	.823	.7888	.823	.823	.7468		.8215
8	.7888	.6859	.8059	.823			.9709
9	.7545	.6173	.7545	.823	.7468		.8215
10		.7373		.823			
11	.6859	.6859		.823		.7468	.6516
12	.6859	.6516		.823		.7468	.6516
13	.6516	.6516				.7468	.6516
14	.6516	.6516		.823		.6722	.6516
15	.6516	.6173				.7468	.6516
16	.6516	.6173				.7468	.6516
17						.8215	.6516
18		.6859				.7468	
19		.9602		.9335		.9709	
20		1.0631		1.1203			
21		1.0288		.9709		.9709	
22		.9774		.9335		.9335	
23		.8916		.9335		.8402	
24	.7888	.6859	.7545	.7716	.8402		.7468
Max	.823	1.0631	.823	1.1203	.8402	.9709	.9709
Min	.6516	.6173	.6859	.7716	.7468	.6722	.6516
Avg	.7202	.7485	.7493	.8522	.7759	.8075	.7285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 207 / 11 KV Vasagade Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		.9945		.0373		.0373
2	1.3717		.9602		.0373		.0373
3	1.3717		.9602		.0373		.0373
4	1.406		1.0117		.0373		.0373
5	1.4232		1.0631		.0373		.0373
6	1.4918		1.1831		.0373		.0373
7	1.5432		1.2003		.0373		.056
8	1.5261		1.2003				
9	1.4746		1.2003		.0373		
11	.0343		.0343	1.1317		.6535	
12	.0343			1.749		.6535	
13	.0343			1.749		1.6057	.823
14	.0343	.0343		1.749		1.531	.823
15	.0343	.0343		1.6804		1.6804	.7888
16	.0343	.0343		1.6461		1.643	.7888
17						1.643	.0343
18		.0343				.056	
19		.0686		.056		.056	
20		.0514		.056		.056	
21		.0514		.056		.056	
22		.0514		.0373		.056	
23		.0514		.0373		.056	
24	1.3546	1.1145	.9774		.0373		.0373
Max	1.5432	1.1145	1.2003	1.749	.0373	1.6804	.823
Min	.0343	.0343	.0343	.0373	.0373	.056	.0343
Avg	.9088	.1526	.9805	.9043	.0373	.7497	.275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 201 / 11 KV BRAMHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	1.5775	1.5257	.104	.0701	.0754	.0914
2	.6443	1.6476	1.5089	.1017	.0732	.0754	.0924
3	.6274	1.7924	1.5089	.0983	.0747	.0943	.0934
4	.6274	1.828	1.5257	.1006	.0739	.0943	.112
5	.6443	1.858	1.5927	.1029	.0895	.0943	.1075
6	.6443	1.8861	1.643	.104	.0914	.0943	.0914
7	.6443	1.861	1.7772	.104	.0905	.0943	.0924
8	.6299	1.7814	1.8275	.1006	.0924	.0943	.0876
9	1.7635	1.8275	1.6933	.1017	.0943	.0943	.0857
10	.1017	.0838	.0686		.0838	.0995	.0876
11	.1307	.0838	.0943		2.32	2.6029	1.8947
12	.1132	.0838	.0943	1.9376	2.3388	2.584	1.7328
13	.1132	.0838	.1132	2.0622	2.3011	2.5652	1.6194
14	.112	.1006	.1132	2.2611	2.2822	2.4832	1.5384
15	.1132	.0838	.1132	2.3777	2.2634	2.2965	1.5223
16				2.4143	2.2445	2.4832	1.4737
17	.112		.1132	2.3765	2.1125	2.5086	1.4413
18	.0934		.1132	1.5775	2.0559	1.8861	1.3927
19	.1052		.1006	.0781	.0663	.1052	.081
20	.1006	.0671	.0983	.0914	.0655	.1097	.0934
21	.08	.0671	.0995	.0924	.0671	.112	.0934
22	.1006	.0671	.1029	.0739	.0686	.112	.0934
23	1.5424	.0663	.104	.0732	.0678	.0914	.0934
24	.6485	1.5089	1.5257	.1029	.0739	.0754	.0934
Max	1.7635	1.8861	1.8275	2.4143	2.3388	2.6029	1.8947
Min	.08	.0663	.0686	.0732	.0655	.0754	.081
Avg	.4504	.9178	.7590	.7471	.7984	.8719	.5877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 202 / 11 KV PANCHGANGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5424	1.5844	1.4266
2	.2229	1.6095	1.6221	1.4415
3		1.6617	1.6598	1.475
4		1.6632	1.6975	1.475
5		1.6118	1.7353	1.4327
6		1.6644	1.773	1.4632
7		1.647	1.8107	1.4784
8		1.6817	1.773	
9		1.7164	1.7541	
23	.8573			
24	.8573	1.6078	1.5466	1.475
Max	.8573	1.7164	1.8107	1.4784
Min	.2229	1.5424	1.5466	1.4266
Avg	.6458	1.6406	1.6957	1.4584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.3155	.3258	.2254	.2454	.2641	.3292
2	.2204	.2865	.2896	.2204	.2561	.2641	.3326
3	.2374	.2926	.2715	.2294	.2801	.2829	.3547
4	.2374	.3258	.2715		.2957	.3018	.3734
5	.2035	.333	.3077	.2743	.3224	.3206	.3582
6	.2713	.3429	.3658	.2774	.3658	.3395	.3841
7	.2883	.3353	.3439	.2947	.362	.3584	.3881
8	.2984	.2915	.3258	.2683	.3696	.3772	.3506
9	.3647	.3521	.3658	.2883	.3772	.3961	.3601
10	.39	.4163	.3601	.2515	.3521	.3481	.3856
11	.4294	.4344	.4527	.2279	.4338	.3772	.3239
12	.4715	.3982	.415	.2743	.4527	.3584	.3077
13	.415	.4163	.3961	.2515	.4338	.3395	.2753
14	.4294	.362	.3772	.2279	.415	.3734	.2429
15	.4527	.362	.4338	.2743	.4527	.4294	.2753
16		.3801	.4715	.3018	.4715	.4668	.2591
17	.5601	.4344	.4904	.3018	.4527	.4338	.2753
18	.4854	.4024	.5093		.4715	.4527	.2591
19	.4207	.4163	.4359	.3125	.3812	.4908	.2801
20	.4024	.3982	.3932	.3658	.3277	.4938	.2987
21	.3521	.3982	.3647	.3881	.3018	.4854	.3174
22	.4024	.3841	.3258	.3696	.2743	.4294	.2753
23	.3681	.3801	.2774	.3109	.2374	.3841	.2987
24	.2279	.3429	.362	.2915	.2772	.2452	.3734
Max	.5601	.4344	.5093	.3881	.4715	.4938	.3881
Min	.2035	.2865	.2715	.2204	.2374	.2452	.2429
Avg	.3550	.3667	.3722	.2831	.3587	.3755	.3200

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 201 / 11 KV YELGUD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2926	.2987	.2229	.2126	.2481	.2058
2	.2987	.2926	.2987	.2058	.1928	.2303	.2058
3	.2987	.2926	.2772	.2058	.1907	.2303	.1886
4	.2772	.2896	.2772	.2058	.1886	.2328	.1886
5	.2772	.3077	.2587	.2229	.1886	.2507	.2058
6	.2587	.3045	.2353	.2134	.2035	.2481	.2058
7	.2686	.2658	.1006	.2439	.218	.2481	.2286
8	.2279	.2321	.2947	.2591	.2347	.2486	
9	.2543	.2347	.3052	.2286	.2515	.2515	.0914
10	.3734	.362	.3801	.2915	.3696	.3439	.1029
11	.3812	.3521	.381	.3521	.3856	.3086	.1147
12	.3978	.431	.442	.3521	.4031	.3772	.3353
13	.407	.4359	.381	.3353	.3856	.3772	.3121
14	.407	.431	.3506	.3185	.373	.3353	.3544
15	.373	.4024	.3506	.3018		.3048	.3582
16	.3391	.3978	.2896	.3018	.3018	.2915	.362
17	.3605	.3277	.2683		.3222	.2915	.3189
18	.3113	.3086	.3018		.2883	.3395	.3077
19	.381	.4001	.3961	.3206	.3174	.3086	.3696
20	.4001	.4191	.3772	.3239	.3239	.3429	.4191
21	.4001	.4191	.3429	.3239	.3048	.3429	.4001
22		.362	.2743	.3239	.3048	.3086	.3429
23	.381	.3734	.2743	.2667	.3048	.2743	.3429
24	.3142	.3292	.3361	.2134	.2303	.2481	.2401
Max	.407	.4359	.442	.3521	.4031	.3772	.4191
Min	.2279	.2321	.1006	.2058	.1886	.2303	.0914
Avg	.3342	.3443	.3122	.2743	.2824	.2910	.2696

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 202 / LAXMI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3361	.3658	.4108	.0343	.0177	.0177	
2	.3361	.3292	.4108	.0343	.0175	.0177	
3	.3174	.3292	.3881	.0343	.0173	.0177	
4	.3142	.3439	.3881	.0343	.0171	.0179	
5	.3326	.3982	.4066	.0343	.0171	.0358	
6	.3696	.4298	.4887	.0305	.0339	.0354	
7	.4298	.4607	.5365	.0343	.0335	.0177	
8	.4557	.5304	.5895	.0305	.0335	.0166	
9	.4409	.4359	.3052	.0305	.0335	.0168	
10	.0187	.0181	.0362	.0343	.0185	.0181	
11	.017	.0168	.0305	.7209	.503	.4973	
12	.0339	.0166		.788		.5316	
13	.0339	.0168	.0305	.7042	.6371		
14	.0339	.0166	.0305	.6539	.5765	.5316	
15		.0168	.0305	.5868	.57	.442	
16		.0332	.0305	.5197	.503	.3944	
17	.0164	.0164	.0335		.4748	.3944	
18	.0164	.0171	.0305		.3391		
19	.0381	.0381	.0377	.0189	.0187		.037
20	.0381	.0191	.0343	.0381	.0381		.0381
21		.0191	.0343	.0381	.0381		.0381
22		.0191	.0343	.0191	.0381		.0381
23	.0381	.0373	.0343	.0191	.0381		.0381
24	.3326	.3658	.4294	.0305	.0177	.0177	
Max	.4557	.5304	.5895	.788	.6371	.5316	.0381
Min	.0164	.0164	.0305	.0189	.0171	.0166	.037
Avg	.1975	.1788	.2079	.2031	.1753	.1777	.0379

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 203 / bajrang ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0366	.0373	.6859	.6556	.6024	.5316
2	.0373	.0366	.0373	.6859	.631	.6024	.4287
3		.0366	.037	.7202	.6241	.5847	.4458
4	.037	.0362	.037	.703	.6173	.591	.4458
5	.037	.0362	.037	.8059	.6516	.6268	.463
6	.037	.0358	.0362	.7773	.6443	.6733	.5144
7	.0358	.0354	.0335	.823	.6706	.691	.6097
8	.0175	.0332	.0173	.8383	.6706	.6962	
9	.017	.0335	.0339	.8383	.503	.6874	.583
10	.056	.0362	.0362	.0171	.0185	.0181	.0171
11	1.1603	1.3077	1.2498		.0168	.0171	.0164
12	1.326	1.3426	1.1584	.0168	.0175	.0343	.0168
13	1.3904	1.2742	1.1126	.0168	.0335	.0343	.0173
14	1.3226	.8785	1.1279	.0335	.0339	.0305	.0177
15	1.1869	1.0059	.9297	.0335	.0335	.0305	.0179
16	1.1191	1.0277	.9602	.0335	.0168	.0343	.0181
17	1.0486	.9339	.9221		.0339	.0343	.0177
18	.8848	.7545			.0339	.0343	.0362
19	.0572	.0381	.0377	.0377	.0373	.0514	.037
20	.0572	.0381	.0343	.0381	.0381	.0381	.0381
21		.0381	.0343	.0381	.0381	.0343	.0381
22		.0381	.0343	.0381	.0381	.0343	.0381
23	.0381	.0373	.0343	.0381	.0381	.0343	.0381
24	.037	.0366	.0373	.6249	.6556	.6024	.5487
Max	1.3904	1.3426	1.2498	.8383	.6706	.6962	.6097
Min	.017	.0332	.0173	.0168	.0168	.0171	.0164
Avg	.4733	.3795	.3485	.3735	.2813	.2841	.2146



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 201 / GADMUDSHINGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2298	1.9448	1.2574	.1143	.1143	.132	.1143
2	2.2298	1.9448	1.2717	.1143	.1143	.1132	.1143
3	2.2634	1.9281		.1143	.0953	.1132	.1334
4	2.3472	1.9448	1.3056	.1143	.1143	.132	.1334
5	2.4478	1.9616	1.4922	.1334	.1334	.132	.1334
6	2.5316	2.2131	1.6263	.1715	.1524	.1509	.1334
7	2.9005	2.0957	1.7436	.1524	.1524	.1509	.1334
8	2.6155	2.364	1.7772	.1524	.1715	.1509	.1715
9	2.3137	2.1776	1.5424	.1334	.1886	.1334	.1143
10	.1524	.1509	.1143	.1524	.1509	.1334	.1143
11	.1905	.1715	.1334		2.6113	2.5652	1.3916
12	.1715	.1524	.1524		2.7496	2.4981	1.3413
13		.1715	.1143		2.6993	2.4143	1.3916
14	.1524	.1905	.1143	1.9784	2.6155	2.2969	1.3916
15	.1715	.1905	.1143	2.2298	1.6465	2.2466	1.3077
16	.1715	.2263		2.4143	2.5149	2.1795	1.3748
17	.1905				2.1795	2.2466	1.3748
18	.1524	.2075	.1905	1.861	2.2634		1.2407
19	.2096	.2096	.1715	.1334	.132	.1524	.1334
20		.1886	.1905	.1524	.1509	.1334	.1143
21	.1715	.1886	.1905	.1524	.1509	.1334	.1143
22	.1905	.1886	.1524	.1334	.1509	.1524	.1524
23	.1715	.1886	.1334	.1143	.1509	.1143	.1143
24	2.2131	2.0119	1.3056	.1334	.1143	.132	.1143
Max	2.9005	2.364	1.7772	2.4143	2.7496	2.5652	1.3916
Min	.1524	.1509	.1143	.1143	.0953	.1132	.1143
Avg	1.1904	1.0005	.7188	.5328	.8966	.809	.5355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 202 / KALAMWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1848	.1698	.1509	.168	.1698	.1307
2	.1494	.1848	.1698	.1494	.168	.1698	.1307
3	.1494	.1848	.1698	.1478	.1494		.1494
4	.168	.1848	.1698	.1494	.1494	.1698	.1494
5	.1867	.1848	.1886	.1494	.168	.1886	.1494
6	.2054	.1848	.1886	.168	.168	.1886	.1494
7	.1867	.168	.2075	.1867	.1867	.1886	.168
8	.168	.1867	.1886	.168	.2241	.2075	.168
9	.2452	.2263	.2263	.168	.2263	.2241	.1867
10	.2641	.2829	.2263	.168	.2263	.2054	.1867
11	.2641	.2829	.2452		.2452	.2241	.2075
12	.2829	.2829	.2641		.2829	.2054	.2263
13	.2263	.2263	.2075	.168	.2452	.1867	.2263
14	.2263	.2452	.1886	.168	.2452	.2241	.2054
15	.2452	.2452	.1886	.168	.2641	.2241	.1494
16	.2452	.3018	.1698	.168	.2641	.1867	.1886
17	.2829		.2263	.2241	.2829	.2427	.2452
18	.2829	.2263	.1886	.2054	.2263	.2241	.2075
19	.2641	.2263	.1886	.2054		.2241	.2263
20	.2641	.2641	.2263	.2054	.2452	.1867	.2263
21	.2263	.2452	.2075	.1867	.2452	.2054	.2075
22	.2263	.2263	.1509	.1867	.2075	.1867	.1886
23	.2033	.2075	.1509	.1867	.1886	.168	.181
24	.1867	.1848	.1886	.1494	.1867	.1886	.1494
Max	.2829	.3018	.2641	.2241	.2829	.2427	.2452
Min	.1494	.168	.1509	.1478	.1494	.168	.1307
Avg	.2223	.2234	.1957	.1740	.2158	.1995	.1835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 203 / GADMUDSHINGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5228	.5093	.5093	.4854	.5281	.4481
2	.5228	.5228	.5093	.5658	.5228	.5281	.4294
3	.5228	.5228	.5281	.6036	.5228	.5093	.4294
4	.5415	.5228	.547	.6036	.4481	.547	.4668
5	.5601	.5415	.5847	.4904	.4668	.6036	.4854
6	.6348	.679	.6224	.5041	.4854	.7167	.6161
7	.6348	.6413	.6979	.5041	.5041	.7545	.7095
8	.5975	.5847	.5281	.5041	.5975	.5281	.5415
9	.6602	.5658	.5658	.5601	.5847	.5788	.5847
10	.7356	.5093	.6413	.5041	.6224	.5788	.6979
11	.5228	.6602	.6979		.679	.6161	.679
12	.6036	.6602	.7545		.6036	.5975	.5847
13	.6602	.7167	.7167		.6036	.5788	.5847
14	.6602	.6036	.7922	.6722	.5658	.6535	.5041
15	.7545	.7356	.7167	.6161	.547	.7655	.5041
16	.5658	.5847	.5658	.5975	.5281	.5228	.5228
17	.4294		.6036	.5041	.6979	.5228	.6036
18	.6979	.6224	.7167	.5041	.6602	.5975	.6602
19	.7167	.8299	.7733	.5415	.7356	.8029	.7545
20	.7545	.8865	.8676	.5415	.8676	.7655	.8488
21	.7167	.8865	.7922	.6348	.7733	.7842	.8488
22	.679	.8676	.6224	.5788	.811	.7468	.8299
23	.7356	.7922	.5847	.5041	.7545	.6722	.7356
24	.5975	.5228	.5847	.547	.4668	.547	.5228
Max	.7545	.8865	.8676	.6722	.8676	.8029	.8488
Min	.4294	.5093	.5093	.4904	.4481	.5093	.4294
Avg	.6277	.6514	.6468	.5519	.6056	.6269	.6080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 204 / sarnobatwadi ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.1143	.0943	.3696	.1417	.1543	.0709
2	.1143	.1143	.1143	.3696	.1417	.1372	.0709
3	.1143	.1143	.1143	.3696	.1595	.1372	.0709
4	.0953	.1143	.1143	.3696	.1595	.1696	.0709
5	.0953	.1334	.1334	.3696	.1772	.2713	.0886
6	.1143	.1334	.1698	.3696	.2126	.3185	.0886
7	.1905	.1524	.1509	.3077	.2658	.3185	.1595
8	.1715	.1334	.1698	.3258	.3544	.3185	.1772
9	.1905	.1886	.1524	.2658	.2835	.3012	.1715
10	.1334	.1886	.1524	.1905	.132	.1334	.1143
11	.4973	.631	.6588		.1509	.1143	.0953
12	.5487	.6836	.6068		.1509	.1715	.1143
13	.5935	.6135	.6135	.1715	.1698	.1524	.0953
14	.5256	.5959	.6024	.1905	.1663	.1143	.0953
15	.5596	.5784	.5959	.1715	.1886	.1905	.0953
16	.5935	.5434	.5258	.1905	.1829	.1143	.0953
17	.6001		.5258		.1478	.1715	
18	.2454	.2865	.3189	.1334	.1494	.1143	.0953
19	.2096	.132	.1334	.1524	.168	.0953	.0953
20	.1715	.132	.1715	.1524	.168	.1143	.0953
21	.1334	.132	.1715	.1524	.168	.0953	.0953
22	.1334	.1132	.1334	.1334	.132	.0953	.0953
23	.1143	.0943	.1334	.1334	.1494	.0953	.0953
24	.1143	.1143	.0943	.3696	.1595	.1543	.0886
Max	.6001	.6836	.6588	.3696	.3544	.3185	.1772
Min	.0953	.0943	.0943	.1334	.132	.0953	.0709
Avg	.2648	.2625	.2771	.2504	.1783	.1689	.1015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 201 / EKONDI Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144		1.0059			.1433	
2	.128		.9892			.1254	
3	.128		.9724			.1254	
4	.1457		.9892			.1254	
5	.1638		1.0059			.1254	
6	.1638		1.0277			.1254	
7	.144		1.1603			.1254	
8				.4161		.1254	
9	.1433	2.3205		.4973			
10	.1791	.1417	.128	.0179		.08	
11	.1791	.1417	.128	.431		.7373	
12	.2149	.1417	.1296	.4641		.7209	
13	.2149	.1417	.1311			.7373	
14	.2149	.1463	.1134			.7865	
15	.2149	.1772	.128			.7373	
16	.2149					.7042	
17		.1791	.1595			.7042	.6958
18					.8951	.7042	.6642
19			.1387		.1433	.1063	.128
20		.1433			.1433	.1052	.128
21		.1433			.1433	.1052	.1107
22						.1063	.112
23						.1063	
24	.144		1.0059	1.1934		.1433	
Max	.2149	2.3205	1.1603	1.1934	.8951	.7865	.6958
Min	.128	.1417	.1134	.0179	.1433	.08	.1107
Avg	.1711	.3677	.5758	.5033	.3313	.3307	.3065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 202 / Siddhanerli- Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032		.9724			.0362	
2	.0316		.9389			.0362	
3	.0316		.9724			.0362	
4	.032		.9614			.0362	
5	.032		1.0277			.0362	
6			1.2266			.0362	
7	.0316		1.3592			.0358	
8				1.4586		.0358	
9	.0358	1.4419		1.7072			
10	.0358			.0179		.032	
19		.0179	.0183		.0358	.0183	
20		.0179			.0358	.0183	.0316
21		.0179			.0358	.0183	.0316
22						.0183	.0316
23						.0179	
24	.032		1.0059	.9503		.0358	
Max	.0358	1.4419	1.3592	1.7072	.0358	.0362	.0316
Min	.0316	.0179	.0183	.0179	.0358	.0179	.0316
Avg	.0327	.3739	.9425	1.0335	.0358	.0298	.0316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 203 / 11KV Shendur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7287		.0716			.2515	
2	.7287		.0716			.2515	
3	.7773		.0716			.2515	
4	.852		.0716			.2515	
5	.8848		.0716			.2515	
6	1.0159		.0716			.2486	
7	1.4419		.0716			.3315	
8				.0886		.3018	
9	1.989	.1063		.0895			
10	.1075	.1063	.064	.0895		.112	
11	2.4034	2.4863	1.9662	.0895		.112	
12	2.3205	2.4863	2.13			.064	
13	2.2874	2.5194	1.9725				
14	2.0553	2.431				.096	
15	2.0953	2.2298	1.9334			.096	
16	1.8233					.08	
17		1.1603	1.6078		.0716	.0886	.08
18		.9945	1.2071		.0716	.0716	.064
19		.0716	.0886		.0716	.0709	.0633
20		.0716			.0716	.0709	.064
21		.0716			.0716		.064
22						.0709	.064
23						.0709	
24	.7611		.0716	.0886		.2683	
Max	2.4034	2.5194	2.13	.0895	.0716	.3315	.08
Min	.1075	.0716	.064	.0886	.0716	.064	.0633
Avg	1.3920	1.2279	.7214	.0891	.0716	.1625	.0666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975		.5335			.5335	
2	.5544		.5335			.4954	
3	.5228		.5335			.4954	
4	.5228		.5335			.4954	
5	.6348		.5716			.5335	
6	.5601		.6859			.6478	
7	.5601		.6413			.6097	
8				.6653		.5658	
9	.6224	.6584		.6535			
10	.4481	.6767	.7095	.6348		.5571	
11	.7095	.6283	.7095	.5552			
12	.7468	.7392		.5975		.5228	
13	.6348	.6099	.5975			.5228	
14	.6722	.5729	.5975			.5228	
15	.5975	.1791	.5544			.5041	
16	.5228					.5228	
17		.5975	.5487		.5729	.5121	.4435
18		.5601	.439		.5544	.6036	.4435
19		.6908	.7468		.7842	.7316	.5975
20		.8962			.8775	.7499	.7468
21		.8589			.7922	.7316	.7468
22						.6838	.6722
23						.5544	
24	.5975		.5716	.5544		.5716	
Max	.7468	.8962	.7468	.6653	.8775	.7499	.7468
Min	.4481	.1791	.439	.5544	.5544	.4954	.4435
Avg	.5940	.639	.5942	.6101	.7162	.5758	.6084



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 205 / 11 kv Shendur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4435		.3395			.3734	
2	.4294		.3395			.3772	
3	.4108		.3395			.3772	
4	.4251		.3395			.3772	
5	.4435		.3772			.3921	
6	.4108		.4338			.4668	
7	.4066		.4338			.4668	
8				.5175		.362	
9	.3982	.3658		.362			
10	.4298	.4572	.4066	.3982		.4066	
11	.4075	.4755	.4251	.3761		.3734	
12	.3856	.439	.4251			.3696	
13	.4207	.4755	.4066			.3292	
14	.4108	.4572	.4108			.3734	
15	.4607	.4572	.3696			.3326	
16	.4607					.3511	
17		.443	.3658		.4382	.3658	.3881
18		.4557	.4938		.5083		.4066
19		.5731	.5914		.6135	.1463	.5175
20		.5792			.6379		.5914
21		.5487			.6154	.4938	.5601
22						.4938	.5175
23						.4024	
24	.4435		.3584	.439		.4108	
Max	.4607	.5792	.5914	.5175	.6379	.4938	.5914
Min	.3856	.3658	.3395	.362	.4382	.1463	.3881
Avg	.4242	.4773	.4033	.4186	.5627	.3829	.4969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 206 / Octega Green

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
8				.0351	
9		.0351			
12	.0343				
17			.0347		.0343
23					.0343
24				.0347	
Max	.0343	.0351	.0347	.0351	.0343
Min	.0343	.0351	.0347	.0347	.0343
Avg	.0343	.0351	.0347	.0349	.0343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 207 / 11KV Vitthal Shivaji LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3605		.4607		.1063	
4	.426		.4961		.1417	
5	.4534		.4908		.1417	
6	.426		.5138		.1417	
7	.4588		.5083		.1402	
8					.1417	
9	.4908					
10	.5083		.4694		.1478	
11			.4908		.1311	
12	.4908		.4588		.128	
13	.4908		.4694		.128	
14	.4908		.4641			
15	.4908		.4694		.128	
16	.4908				.128	
17			.5138	.4784	.1402	.112
18		.0181	.5083	.5138	.124	
Max	.5083	.0181	.5138	.5138	.1478	.112
Min	.3605	.0181	.4588	.4784	.1063	.112
Avg	.4648	.0181	.4857	.4961	.1335	.112

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 402 / 33 KV Shahu LIS -SDH-  
Feeder KV- 33 / OUTGOING

SHEDDABLE HV(AGRICULTURE)

DATE	01-JUN-18	03-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)
3	2.9835	1.0059	.1006
4	3.195	1.1065	.1006
5	3.8786	1.2071	.1006
6	4.177	1.2929	.1006
7	5.0297	1.2929	
9	5.072		
10	5.2584	3.3196	
11	5.3109	3.195	
12	5.072	3.1824	.0503
13	4.9726	3.2322	.0497
14	5.0223	3.2819	
15	5.0223	3.195	.048
16	4.9726		.0492
17		3.2322	.0549
<b>Max</b>	<b>5.3109</b>	<b>3.3196</b>	<b>.1006</b>
<b>Min</b>	<b>2.9835</b>	<b>1.0059</b>	<b>.048</b>
<b>Avg</b>	<b>4.6128</b>	<b>2.3786</b>	<b>.0727</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 201 / Kagal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5144	.5335	.0191		.0191	.0191
2	.5906		.5335			.0191	.0191
3	.5906	.5335	.5335	.0191		.0191	.0191
4	.6097	.5335	.5335	.0191		.0191	.0191
5	.6097	.5906	.5716	.0191		.0191	.0191
6	.6668	.743	.6668	.0191		.0191	.0191
7	.8954	.8954	.8383	.0191		.0191	.0191
8	.9526	.9145	.9145	.0191		.0191	.0191
9	.8954	.8573	.8383	.0191		.0191	.0191
10		.0191	.0191	.0191		.0191	.0191
11		.0191	.0191	1.0479		.3429	.5144
12	.0191		.0191	1.086	.3048	.362	.4763
13	.0191		.0191	1.0479	.4954	.381	.4382
14	.0191	.0191	.0191	1.0098	.4572	.3429	.4572
15	.0191	.0191	.0191	1.0098	.4382	.5144	.4763
16	.0191				.4382	.5335	.4382
17	.0191	.0191			.1715	.5335	.362
18	.0191	.0191	.0191		.2858	.4572	.381
19	.0381	.0191	.0191		.0191	.0381	.0191
20	.0381	.0191	.0191		.0191	.0381	.0191
21	.0381	.0191	.0191		.0191	.0381	.0191
22	.0381	.0191	.0191		.0191	.0381	.0191
23	.0381	.0191	.0191			.0191	.0191
24	.5906	.6478	.5525	.0191		.0191	.0191
Max	.9526	.9145	.9145	1.086	.4954	.5335	.5144
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3326	.3220	.3066	.3595	.2425	.1604	.1604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 202 / Kagal-Sugar Factory Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.0191	.0191	.0191
2	.0191	.0191	.0191	.0191	.0191	.0191	.0191
3	.0191	.0191	.0191	.0191	.0191	.0191	.0191
4	.0191	.0191	.0191	.0191	.0191	.0191	.0191
5	.0191	.0191	.0191	.0191	.0191	.0191	.0191
6	.0191	.0191	.0191	.0191	.0191	.0191	.0191
7	.0191	.0191	.0191	.0191	.0191	.0191	.0191
8	.0191	.0191	.0191	.0191	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191	.0191	.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	.0191
12	.0191	.0191	.0191	.0191		.0191	.0191
13	.0191	.0191	.0191	.0191	.0191	.0191	.0191
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191	.0191	.4382	.0191	.0191
16	.0191		.0191		.0191	.0191	.0191
17	.0191	.0191	.0191		.0191	.0191	
18	.0191	.0191	.0191		.0191	.0191	.0191
19	.0191	.0191	.0191		.0191	.0191	.0191
20	.0191	.0191	.0191		.0191	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	.0191
22	.0191	.0191	.0191		.0191	.0191	.0191
23	.0191	.0191	.0191			1.0098	.0191
24	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Max	.0191	.0191	.0191	.0191	.4382	1.0098	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0191	.0382	.0604	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant SHEDDABLE FEEDER HAVING WEEKLY  
 Roto Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.5242	1.5813	2.0957	.7621	1.4289	.4763
2	1.1241	1.3717	1.3146	2.0576	.8383	1.4861	1.6194
3	1.2765	1.4098	1.3336	1.9433	.8383	1.4289	1.6194
4	1.3527	1.3717	1.2955	1.9052	.8383	1.4098	1.6004
5	1.4289	1.3908	1.3527	1.848	.8573	1.3527	1.6004
6	1.3717	1.6004	1.4861	1.6385	.8954	1.467	1.6004
7	1.4861	1.7147	1.5623	1.5623	.9907	1.7528	1.8099
8	1.7718	1.7528	1.6385	1.4861	.743	1.6575	1.6956
9	1.6766	1.5623	1.6575	.8954	1.1622	1.7337	1.9052
10	1.8099	1.7718	1.8861	.5335	1.4098	1.6385	2.1338
11	1.8861	1.9052	2.0386	.5525	2.0957	1.7528	2.4768
12	2.0195	2.0386	1.848	.5716	2.0386	2.0005	2.4006
13	2.0386	1.9624	2.191	.5716	1.9814	1.9243	2.2291
14	2.1148	2.0005	1.9433	.5716	1.6194	1.9814	2.3243
15	2.2481	1.9433	1.6956	.5716	1.5623	1.086	2.3053
16	2.0386				1.9433	1.5623	2.1338
17	2.0767	1.5623			1.8861	2.3624	1.8861
18	1.9433	2.0767	.8002		2.0576	1.9433	1.9814
19	2.0957	2.1529	1.7909		2.0005	2.2672	2.2672
20	2.1338	2.0576	2.0195		2.0767	2.0957	1.9243
21	1.6004	1.8099	1.7337		2.0005	2.0195	1.8861
22	1.7909	1.829	2.0195		1.8671	2.0195	2.0386
23	1.7528	1.8861	2.1148			1.8671	1.5623
24	1.2003	1.7147	1.6194	2.1148	.6668	1.7147	1.6194
Max	2.2481	2.1529	2.191	2.1148	2.0957	2.3624	2.4768
Min	1.1241	1.3717	.8002	.5335	.6668	1.086	.4763
Avg	1.7258	1.7569	1.6783	1.3075	1.4405	1.7480	1.8790

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 204 / Laxmi Ind

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8192	.7621	.9145	.8192	.8002	.5716	.7049
2	.7811	.724	.8002	.7621	.7811	.6859	.724
3	.8383	.7621	.7811	.8002	.7811	.724	.6859
4	.8764	.7811	.8002	.7811	.7621	.6859	.6859
5	.8954	.8573		.7621	.7621	.7049	.6668
6	.9145	.9526	.724	.724	.743	.8573	.6668
7	.8383	1.0288		.6478	.6478	.6668	.6478
8	.6478	.7621	.743	.6287	.6097	.7621	.724
9	1.1241	.7811	.8764	.6859	.7621	.9526	.8383
10	1.0288	1.0288	.8002	.6859	.8954	.9335	.9335
11	1.1622	1.1622	.9907	.6859	.9526	1.086	.8764
12	1.105	.8764	.9717	.6859	.743	.8764	1.0288
13	1.1431	.9145	.9907	.6859	.8002	.9717	1.0669
14	.9526	.9335	.9526	.7049	.7621	.9907	1.0098
15	1.0669	1.1622	.8954	.6859	.7621	.9145	1.0288
16	1.086	1.0288			.8573	.8764	.9717
17	.9907	1.086	.8954		.8573	.9907	1.0669
18	.9526	.8764	.8383		.8192	.9526	.7621
19	.7621	.9526	.6478		.8764	.8764	.9335
20	.7621	1.2193	.6859		.8764	.9145	.8764
21	.743	1.1431	.6859		.8764	.6859	.9145
22	.9907	1.1431	.724		.9717	.6859	.9907
23	.9526	1.0669	.8002			.724	.9335
24	.9717	.8383	.9907	.8002	.8002	.8002	.6859
Max	1.1622	1.2193	.9907	.8192	.9717	1.086	1.0669
Min	.6478	.724	.6478	.6287	.6097	.5716	.6478
Avg	.9336	.9518	.8338	.7216	.8043	.8288	.8510



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 205 / K.Sangaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4572	.4763	.4954	.4382	.4382	.362
2	.4763	.4572	.4572	.4763	.4191	.4382	.362
3	.5335	.4572	.4572	.4763	.4572	.4382	.362
4	.5716	.4572	.5144	.4382	.4763	.4954	.362
5	.5906	.5906	.5906	.4572	.5525	.5144	.4954
6	.6097	.5906	.5716	.4572	.5716	.5525	.5525
7	.6859	.5906	.6287	.4572	.5716	.5335	.5716
8	.6478	.5906	.6287	.4382	.5525	.5716	.5716
9	.5525	.5525	.5906	.4191	.5144	.5335	.5144
10	.5335	.5525	.5335	.4001	.4954	.4191	.4954
11	.5525	.5144	.5716	.4382	.4954	.4763	.4572
12	.5525	.5525	.5335	.381	.5906	.4572	.4191
13	.6287	.5906	.5906	.362	.5335	.4763	.4191
14	.5716	.6097	.5716	.4191	.5525	.4763	.4382
15	.5906	.6287	.5716	.4382	.5144	.4954	.4954
16	.6478				.4572	.4191	.4763
17	.6478	.381	.4001		.4382	.4382	.4572
18	.5716	.4954	.4763		.4572	.4954	.4382
19	.5716	.5716	.5906		.5144	.5906	.5144
20	.6478	.6668	.724		.6287	.6478	.6478
21	.6287	.7049	.6859		.6287	.5906	.6097
22	.6859	.6668	.6668		.6287	.5716	.5716
23	.5906	.6287	.5716			.4572	.4763
24	.5716	.4763	.4954	.4954	.4382	.4191	.381
Max	.6859	.7049	.724	.4954	.6287	.6478	.6478
Min	.4763	.381	.4001	.362	.4191	.4191	.362
Avg	.5914	.5558	.5608	.4406	.5185	.4977	.4771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 206 / Laxmi-Ag Feeder-

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.0479	1.1622	.0381	.0381	.0381	.0191
2	1.1431	1.0479	1.1241	.0381	.0381	.0381	.0191
3	1.1622	1.0479	1.1241	.0381	.0381	.0381	.0191
4	1.1622	1.0479	1.1622	.0381	.0381	.0381	.0191
5	1.1622	1.105	1.2193	.0381	.0381	.0381	.0191
6	1.2574	1.2955	1.3717	.0381	.0572	.0381	.0191
7	1.5051	1.5432	1.6956	.0381	.0381	.0381	.0191
8	1.5623	1.6004	1.7909	.0381	.0381	.0381	.0191
9	1.467	1.5432	.6097	.0381	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0191	.0381	.0381
11	.0381	.0381	.0381	2.0576	.8954	.8002	.6097
12	.0381	.0381	.0381	1.8861	.9907	.8573	.6287
13	.0381	.0381	.0381	1.7718	.9717	.8954	.6287
14	.0381		.0381	1.7337	.8383	.9335	.5906
15	.0381	.0381	.0381	1.7909	.8954	.9526	.5906
16	.0381				.6287	.9335	.5906
17		.0381	.0381		.6097	.9526	.5525
18	.0191	.0381	.0381		.6097	.8954	.4763
19	.0381	.0381	.0381		.0381	.0381	.0381
20	.0381	.0381	.0381		.0381	.0381	.0381
21	.0381	.0381	.0381		.0381	.0381	.0381
22	.0381	.0381	.0381		.0381	.0381	.0381
23	.0381	.0381	.0381			.0191	.0381
24	1.086	1.0669	1.1622	.0381	.0381	.0381	.0191
Max	1.5623	1.6004	1.7909	2.0576	.9907	.9526	.6287
Min	.0191	.0381	.0381	.0381	.0191	.0191	.0191
Avg	.5691	.5820	.5616	.6037	.3048	.3255	.2128

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 207 / S.Kharkhan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0191	1.9624		1.2193	1.2193
2	.0572	.0572	.0191	1.9433		1.2193	1.1622
3	.0762	.0572	.0191	1.9243		1.1812	1.1431
4	.0762	.0572	.0191	1.9243		1.1812	1.1431
5	.0381	.0572	.0381	1.9814		1.1241	1.1431
6	.0381	.0762	.0381	2.21		1.2003	1.105
7	.1143	.0762	.0381	2.4196		1.3336	1.2765
8	.0762	.0762	.0381	2.553		1.3717	1.3336
9	.0572	.0762		2.4768		1.3336	1.3336
10	.0572	.0381		.0191		.0191	.0381
11	2.8387	2.8578		.0381		.0191	.0381
12	2.7054	2.9531		.0191		.0191	.0191
13	2.8387	2.7054		.0191	1.2955	.0191	.0191
14	2.7435	2.7816		.0191	1.7147	.0191	.0191
15	2.553	2.6292		.0191	1.7147	.0191	.0191
16	2.4577				.0381	.0191	.0191
17	2.7244	2.5149	2.7625		.0572	.0191	.0191
18	2.6482	2.4768	2.572		.0381	.0381	.0191
19	.0762	.0572	.0381		.0572	.0381	.0191
20	.0762		.0191		.0572	.0381	.0381
21	.0762		.0381		.0191	.0381	.0381
22	.0572		.0381		.0191	.0381	.0381
23	.0572	.0381	.0381			.0381	.0381
24	.0572	.0572	.0381	1.9243		1.2384	1.1622
Max	2.8387	2.9531	2.7625	2.553	1.7147	1.3717	1.3336
Min	.0381	.0381	.0191	.0191	.0191	.0191	.0191
Avg	.9399	.9850	.3608	1.3408	.5011	.5327	.5168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 208 / Kagal Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669	1.0288	.9907	1.0098	1.0098	.8573	.8192
2	1.0098	1.0098	.9717	1.0098	.9526	.8383	.8383
3	1.0098	.9907	.9717	.9717	.9526	.8383	.8383
4	1.0288	.9907	.9717	.9717	.9335	.8573	.8383
5	1.0098	.9907	.9717	.9335	.9335	.8573	.8573
6	.9907	.9717	.9526	.9717	.9717	.8764	.8954
7	.9907	.9335	.9526	.9335	.9145	.8954	.8954
8	.9526	.9335	.8764	.8954	.9145	.8383	.9145
9	.9145	.9335		.9335	.7621	.9145	.9145
10	1.0098	.9526		.9526	.9145	.8383	.8954
11	1.0288	1.0479		.9526	.4954	.9145	.9526
12	1.105	1.1241			1.0479	.8954	.8954
13	1.105	1.105			1.105	.9145	.8573
14	1.105	1.105			.9907	.9717	.8764
15	1.105	1.1812			.9907	.9526	.8954
16	1.1241				.9717	.9335	.8764
17	1.0669	.9526	.8383		.9335	.8954	.8954
18	1.105	.9526	.9526		.8954	1.0479	.9145
19	1.3146	1.1622	1.1431		1.105	1.2193	1.105
20	1.448	1.2765	1.3146		1.2955	1.2574	1.3336
21	1.2955	1.2574	1.2574		1.1812	1.1812	1.2384
22	1.2574	1.2384	1.2193		1.086	1.1241	1.1622
23	1.1812	1.1622	1.1241			1.0098	1.0669
24	1.1241	1.0669	1.0479	1.0288	1.0479	.8954	.8954
Max	1.448	1.2765	1.3146	1.0288	1.2955	1.2574	1.3336
Min	.9145	.9335	.8383	.8954	.4954	.8383	.8192
Avg	1.0979	1.0595	1.0348	.9637	.9741	.9510	.9446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 402 / 33KV Shahu LIS - KGL-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.9717	.9145	.4572		.0572	.0572
4	1.1431	.9145	.6859		.0572	.0572
5	1.2574	.9145	.6859		.0572	.0572
6	1.2574	.9717	1.3717		.0572	.0572
7	1.3146	1.1431	1.3717		.0572	.0572
8	1.2574	1.3146	1.3717		.0572	.0572
9	1.2574	1.3146		.0572	.0572	.0572
10	1.3146	1.3146		.0572	.0572	.0572
11	1.3146	1.3146		.0572	.0572	.0572
12	1.3146	1.3717		.0572	.0572	.0572
13	1.3146	1.3146		.0572	.0572	.0572
14	1.2574	1.3146		.0572	.0572	.0572
15	1.3146	1.3146		.0572	.0572	.0572
16	1.2574	1.2574		.0572	.0572	.0572
17	1.2574	1.3146	1.3146	.0572	.0572	.0572
18	.743	.8573	.8002	.0572	.0572	.0572
Max	1.3146	1.3717	1.3717	.0572	.0572	.0572
Min	.743	.8573	.4572	.0572	.0572	.0572
Avg	1.2217	1.1788	1.0074	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 403 / 33 KV Padmavati

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	2.0576	1.2574	2.0576	.8002	2.5149	2.2862
2	1.9433	1.829	2.0576	1.9433	.8002	1.2574	1.4861
3	1.7147	2.2862	2.2862	1.7147	.8002	2.0576	1.829
4	1.6004	1.7147	2.1719	2.0576	.8002	2.1719	1.2574
5	1.3717	1.1431	2.2862	1.9433	.8002	1.3717	.5716
6	2.0576	1.2574	1.3717	.0572	.8002	2.1719	1.2574
7	1.9433	.6859	1.3717	.4572	.8002	2.2862	1.2574
8		1.3717	1.9433	.5716		1.4861	.5716
9	1.4861	2.1719		.8002	1.9433	1.0288	2.4006
10	2.0576	2.4006		.6859	1.7147	1.7147	1.829
11	2.0576	2.2862		.6859	1.2574	2.4006	.8002
12	1.0288	2.4006		.6859	.8002	1.6004	.3429
13	1.829	2.1719		.8002	1.1431	1.3717	1.1431
14	1.9433	1.4861		.8002	1.4861	1.829	1.4861
15	1.7147	1.3717		.6859	2.4006	1.1431	2.2862
16	1.0288	1.3717			1.829	1.4861	1.3717
17	1.4861	2.4006	2.0576		2.5149	1.829	1.3717
18	1.829	2.4006	1.0288		2.4006	.6859	1.1431
19	2.1719	2.0576	2.0576		1.3717	1.3717	1.2574
20	1.1431	2.2862	2.2862		1.829	2.2862	1.2574
21	1.3717	2.1719	1.829		2.2862	2.4006	2.1719
22	2.0576	1.2574	1.9433		1.0288	1.829	1.9433
23	.9145	1.1431	1.9433			2.4006	1.1431
24	1.3717	2.2862	2.2862	2.1719	.8002	1.829	2.0576
Max	2.1719	2.4006	2.2862	2.1719	2.5149	2.5149	2.4006
Min	.9145	.6859	1.0288	.0572	.8002	.6859	.3429
Avg	1.6650	1.8337	1.8861	1.1324	1.3821	1.7718	1.4384

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 201 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	1.5623	1.6766	1.6766	1.4861	1.6385	1.6575
2	1.467	1.6194	1.5242	1.6575	1.4861	1.6004	1.5432
3	1.448	1.5813	1.4289	1.4098	1.467	1.5242	1.5051
4	1.467	1.5242	1.3908	1.4861	1.4861	1.4861	1.5623
5	1.467	1.467	1.448	1.4289	1.5242	1.5051	1.4861
6	1.4289	1.3527	1.467	1.4289	1.5242	1.4861	1.4098
7	1.448	1.3527	1.448	1.3336	1.4098	1.467	1.4098
8	1.5242	1.3717	1.4098	1.4098	1.4861	1.5242	1.4289
9	1.7147	2.21	1.9052	1.4289	1.5242	2.2481	1.6766
10	2.1338	2.3624	2.6292	1.448	2.4768	2.7244	1.9243
11	2.0195	2.6673	2.7244	1.4289	1.8099	2.2291	2.3624
12	1.9624	2.3624	1.9624	1.2955	2.4006	2.0767	2.6482
13	1.848	1.7718	1.7337	1.3146	2.0576	2.0576	1.6575
14	2.3243	2.8006	1.829	1.2955	2.7054	2.3243	2.7625
15	2.2672	2.7625	2.21	1.2574	2.9531	2.21	2.5911
16	2.4196	2.6101	1.7909	1.448	2.2291	2.5911	2.5911
17	2.0957		1.7337		1.7909	2.553	2.5149
18	1.7718	1.2574	1.8861		1.7909	1.6575	1.9052
19	1.8671	1.8671	1.8099	1.467	1.8099	1.848	2.0195
20	1.6956	1.9243	1.6766	1.467	1.6575	1.7147	1.848
21	1.7909		1.4098	1.467	1.4289	1.5623	1.4098
22	1.4098	1.5623	1.5242	1.4289	1.5813	1.4098	1.6194
23	1.829	1.7147	1.5623		2.0195	1.6385	2.0195
24	1.6004	1.6385	1.4098	1.2955	1.4289	1.7147	1.6194
Max	2.4196	2.8006	2.7244	1.6766	2.9531	2.7244	2.7625
Min	1.4098	1.2574	1.3908	1.2574	1.4098	1.4098	1.4098
Avg	1.7703	1.8792	1.7329	1.4225	1.8139	1.8663	1.8822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 202 / 11KV West Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3815	2.8578	2.0957	2.191	1.829	2.0957	2.4768
2	2.191	2.6673	2.0957	2.191	1.829	2.2862	2.2862
3	2.0957	2.4768	2.0195	2.0957	1.848	2.2862	2.2862
4	2.0957	2.4768	2.0195	1.9052	1.829	2.4768	2.0957
5	2.0957	2.2862	2.0957	2.0957	1.848	2.4768	2.191
6	2.2862	2.2862	2.0386	2.0957	1.848	2.4768	2.191
7	2.3815	2.6673	2.2862	1.9052	1.848	2.4768	2.4768
8	2.4768	3.0483	2.5339	1.9052	2.0005	2.0957	2.3815
9	2.9721	3.8104	3.5627	1.8099	2.5339	3.6199	3.8104
10	3.5627	4.5725	4.5344	1.9052	3.6199	3.8485	4.5725
11	3.6961	4.382	4.382	1.9052	3.5246	5.0869	4.6868
12	3.3341	3.8104	4.1724	1.9052	3.5246	4.6487	4.9535
13	3.315	3.2388	3.296	1.9052	3.2388	3.7532	4.1914
14	3.658	4.1914	3.7723	1.9052	3.9057	4.0771	4.5725
15	3.8104	3.3341	3.5056	1.9052	4.1914	4.2676	3.8104
16	4.0009	4.1914	3.2388	1.9052	3.8104	4.0009	4.5725
17	3.4294	3.0483	3.3341		3.2388	4.0962	4.1724
18	2.6673	2.9721	3.0483		3.0483	3.4294	3.1626
19	2.2862	2.7054	2.6673	1.9243	2.8578	2.8578	3.3913
20	2.2862	2.5149	2.3815	1.9052	3.2388	2.572	2.4387
21	2.2862	2.3815	2.0957	1.8671	2.0957	2.0957	2.3243
22	2.8578	2.4768	2.191	1.9243	2.2862	2.4768	2.4577
23	3.0483	2.2481	2.2862		2.2862	2.2862	2.7054
24	2.6673	3.0483	2.0957	2.191	1.8671	2.2862	2.2862
Max	4.0009	4.5725	4.5344	2.191	4.1914	5.0869	4.9535
Min	2.0957	2.2481	2.0195	1.8099	1.829	2.0957	2.0957
Avg	2.8284	3.0705	2.8229	1.9687	2.6728	3.0864	3.1872



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 203 / KANERI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.9526	.8192	.8192		.8383	.9145
2	.9145	.8764	.8192	.8383		.8383	.8573
3	.9145	.8573	.8002	.7811		.8573	.7811
4	.9145	.9145		.8192		.8764	.743
5	.9145	.8954	.8002	.7811		.9145	.743
6	.9526	.9717	.8954	.8383		.9526	.9717
7	.9907	1.2193	1.1431	.8954		.9717	1.1622
8	1.2003	1.0288	1.086	.8573		1.1622	.9907
9	1.2955	1.3146	.9145	.743		1.1622	1.4098
10	1.2955	1.0479	1.2003	.5335		1.3717	1.6385
11	1.5051	1.7147	1.1431	.4572		1.6004	1.3717
12	1.448	1.448	1.7337	.4763		1.2955	.9907
13	1.2574	1.3908	1.2384	.5716		1.4098	1.2765
14	1.2574	1.5432	1.7147	.6097		1.3146	1.2574
15	1.467	1.6575	1.5051	.5906		1.467	1.6575
16	1.3908	1.2003	.9335	.5716	1.7147	.9717	1.4098
17	1.3336	.9526	1.0098		1.105	.8954	.9145
18	1.1622	1.5813	.8764		1.1812	1.1812	1.3717
19	1.3908	1.6956	1.3908	.743	1.2384	1.2193	1.3908
20	1.7337	1.8099	1.4861	.8573	1.2193	1.2384	1.5432
21	1.086	1.2384	1.6194	1.0288	1.2193	1.2003	.9335
22	1.7528	1.6194	1.2765	.9907	1.086	1.5813	1.0288
23	.9717	1.4289	1.0288		1.3717	1.0098	1.2193
24	.9145	1.2003	.8573	.8764		.8002	.9907
Max	1.7528	1.8099	1.7337	1.0288	1.7147	1.6004	1.6575
Min	.9145	.8573	.8002	.4572	1.086	.8002	.743
Avg	1.2074	1.2733	1.1431	.7466	1.2670	1.1304	1.1487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 204 / 11 KV PANCHAGANGA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.2862	2.6673	1.9052	.7621	2.0957	1.9052
2	2.191	2.0957	2.4768	2.0957	.7621	2.2862	1.8099
3	2.191	2.2862	2.0957	2.2862	.7621	2.0957	2.0005
4	2.0957	2.0957	1.9052	2.2862	.7621	2.2862	1.7147
5	2.0005	2.2862	2.2862	1.9052	.9526	2.4768	1.8099
6	2.3815	2.2862	2.4768	2.0957	.9526	2.2862	1.9052
7	2.6673	2.8578	3.3341	2.191	1.2384	2.6673	2.6673
8	2.0005	2.4768	2.6673	1.6194	1.3336	2.2862	1.9052
9	3.6199	3.0483	3.5246	1.0479	2.6673	2.0957	2.2862
10	3.5246	3.4294	3.7151	1.3336	2.9531	2.2862	1.7147
11	3.6199	3.0483	4.0009		3.0483	2.4768	2.6673
12	3.0102	2.9531	2.6673	.381	2.191	2.2862	2.0957
13	3.4294	2.2862	3.0483	.381	2.6673	2.2862	2.6673
14	3.0483	3.0483	3.4294	.381	2.572	2.9531	2.8578
15	3.6199	3.0483	3.8104	.381	2.2862	2.0957	2.6673
16	2.4768	2.9531	3.4294	.381	2.8578	1.5242	1.7147
17	2.4768	1.9052	4.0009		2.6673	2.6673	2.6673
18	2.4768	3.0483	3.5246		2.6673	2.4768	2.572
19	2.4768	2.9531	2.572	.9526	2.8578	2.9531	2.4768
20	2.2862	2.191	2.572	.9526	2.0957	2.7625	2.4768
21	1.5242	2.2862	2.6673	.7621	2.6673	2.3815	1.6194
22	2.4768	1.9052	2.0957	.9526	2.6673	2.2862	2.191
23	2.2862	2.8578	2.0957		2.6673	2.3815	2.6673
24	2.3815	2.2862	2.2862	2.4768	.7621	2.4768	1.6194
Max	3.6199	3.4294	4.0009	2.4768	3.0483	2.9531	2.8578
Min	1.5242	1.9052	1.9052	.381	.7621	1.5242	1.6194
Avg	2.6062	2.5800	2.8896	1.3384	1.9925	2.3696	2.1950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 205 / 11KV MainRoad

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	1.2574	.9907	.5716	1.1241	1.3336	1.2955
2	1.2003	1.2384	1.1431	.5906	1.1431	1.2955	1.3527
3	1.1812	1.105	1.2193	.5716	1.105	1.1812	1.3336
4	1.1622	1.0669	1.2574	.5716	1.0479	1.1431	1.3717
5	1.1622	1.086	1.0479	.5525	.9526	1.105	1.2955
6	1.1431	1.105	.5716	.5906	.9335	1.1431	1.2384
7	1.086	.9717	.5335	.5144	1.105	1.2003	1.0098
8	.9335	.9717	.7621	.5906	.8383	1.0288	1.0669
9	.8573	.9335	.9907	.6097	1.2003	.9526	1.1241
10	1.105	.8573	.9145	.5906	1.0098	1.3908	1.4861
11	1.086	.8383	1.1431		1.5813	1.4861	1.2384
12	1.1431	.9145	1.1812	.8002	1.3336	1.5432	1.6766
13	1.0098	.8573	.724	.8192	1.2003	1.4861	1.7337
14	1.105	1.1431	1.0098	.8192	1.6194	1.448	1.5051
15	1.0479	1.105	.8383	.8192	1.1431	1.7528	1.848
16	1.105	1.2574	.9145	.8192	.9907	1.6956	1.3717
17	1.0669	.8383	.7811		1.0669	1.5813	1.0669
18	.9145	.7811	1.0479		1.105	1.3527	1.3908
19	.9907	.724	.7811	.8002	1.1622	1.2003	.9335
20	.9335	.7811	.5525	.8192	.9335	1.1431	1.0669
21	.724	.7621	.6287	.8383	1.0669	1.1431	.8383
22	.9335	.8383	.8002	.8383	1.086	1.086	.7811
23	1.2384	1.2765	.7049		1.3717	1.2955	1.1622
24	1.2384	1.2765	.724	.5906	1.1241	1.3527	1.1812
Max	1.2384	1.2765	1.2574	.8383	1.6194	1.7528	1.848
Min	.724	.724	.5335	.5144	.8383	.9526	.7811
Avg	1.0661	.9994	.8859	.6859	1.1352	1.3059	1.2654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 206 / 11KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9433	1.9433	2.0576	2.0195	1.9052	2.0195	1.9433
2	1.6766	2.0195	2.0195	1.9814	1.9052	1.9433	2.0195
3	1.7528	1.9052	1.9052	2.1338	1.9052	1.8671	1.8671
4	2.0957	1.9052	1.9052	1.8671	2.0957	1.7909	1.7909
5	2.1719	1.7147	1.8671	1.9052	2.21	1.9433	1.9052
6	2.2862	1.9814	1.9814	1.7909	2.2862	1.9814	2.0576
7	2.3243	2.2862	2.2862	1.5623	2.0957	2.0195	1.9052
8	1.7528	1.5623	1.7147	1.448	2.5911	1.9433	1.829
9	1.9433	2.3624	2.8197	1.448	3.0864	2.3624	2.21
10	2.7816	2.5911	2.8578	1.4098	2.934	2.8197	2.2862
11	2.8578	3.1626	2.9721	1.4098	3.5818	2.7054	3.0483
12	3.0102	2.934	3.0483	1.4098	3.8104	2.6673	3.0483
13	2.5149	2.4387	2.5911	1.4098	2.4768	2.2862	2.7816
14	3.2007	2.5911	3.0102	1.4098	2.5911	3.0483	2.5911
15	2.934	2.553	2.7435	1.4098	2.5149	2.8197	3.2007
16	3.0483	2.3243	2.7435	1.2955	2.4768	2.7435	2.6673
17	2.6673	2.21	2.7054		2.1719	2.9721	2.7435
18	2.2862	2.0195	2.4387		2.0957	2.553	2.553
19	1.9433	1.7147	1.9052	1.3717	1.7147	2.21	2.4768
20	1.8671	1.5623	1.6766	1.3336	1.7909	1.9052	1.829
21	1.7909	1.6004	1.6766	1.4098	1.9814	1.9814	1.7147
22	1.7909	1.5623	1.6766	1.4098	2.0576	1.829	2.1719
23	1.9433	1.7528	2.0195		2.1338	2.0195	2.2862
24	1.9814	2.0576	2.0576	2.0195	1.9052	1.9814	1.9814
Max	3.2007	3.1626	3.0483	2.1338	3.8104	3.0483	3.2007
Min	1.6766	1.5623	1.6766	1.2955	1.7147	1.7909	1.7147
Avg	2.2735	2.1148	2.2783	1.5931	2.3466	2.2672	2.2878

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 207 / 11 KV UJALAIWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3336	1.2574	1.1622		.4763
2	1.1431	1.2955	1.2574	1.1622		.4191
3	1.1431	1.2384	1.2193	1.1241		.362
4	1.2955	1.2574		1.1241		.362
5	1.3146	1.2193		1.1812		.4001
6	1.4098	1.3336	.4954	1.2955		.4572
7	1.467	1.5432	1.5432	1.467		.5144
8	1.3908	1.4289	1.448	1.4289		.5144
9	1.2955	1.448	1.3336	1.2384	.5906	.4572
10	1.5813	1.5242	1.4098	1.1812	.6097	.5144
11	1.5242	1.6385	1.3908	1.1812	.6859	.5335
12	1.7337		1.5051	1.1431	.5335	.5906
13	1.5813	1.5813	1.5813	1.1241	.6287	.5144
14	1.4098	1.5242	1.4098	1.2384	.4954	.4572
15	1.5432	1.5432	1.4098	1.2193	.4954	.5525
16	1.5813			1.1812	.5335	.5335
17	1.5242	1.4861	1.6956		.5335	.5335
18	1.467	1.4098	1.4098		.4954	.5144
19	1.6004	1.4861	1.5242	1.3336	.4572	.5716
20	1.6956	1.5813	1.7337	1.467	.5525	.6287
21		1.5623	1.6385	1.3908	.5144	.5906
22	1.829	1.5623	1.5051	1.3717	.5335	.5525
23	1.5432	1.4289	1.4289		.5525	.5525
24	1.5394	1.448	1.2384	1.2765		.4954
Max	1.829	1.6385	1.7337	1.467	.6859	.6287
Min	1.1431	1.2193	.4954	1.1241	.4572	.362
Avg	1.4759	1.4488	1.4017	1.2520	.5474	.5041

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 208 / KANERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	1.5242	.5525	.724		.1143	.0762
2	.1334	1.3336	.5525	.724		.1143	.0762
3	.1334	1.2574	.5335	.724		.1143	.0762
4	.1143	1.2193	.5335	.743		.1143	.0762
5	.1143	1.1812	.5144	.7811		.1334	.0953
6	.1143	1.3527	.5906	.8573		.1524	.1143
7	.1334	1.6956	.6668	1.086		.1715	.1334
8	.1143	1.8099	.7811	1.105		.1143	.0953
9	.1715	1.4289	1.086	1.1812		.1334	.1143
10	.1334	.1524	.1143	.1334		.1143	.1143
11	.0191	.1334	.1334	1.0669		.5525	.5335
12	.1715	.1715	.1143	1.0098		.6097	.5335
13	.1524	.1524	.0953	1.0098	.4382	.6287	.5335
14	.1524		.0953	1.0098	.4763	.6668	.362
15	.1143		.1143	1.0288	.381	.5716	.3048
16	.1334	.1715	.1143	1.0288	.3048	.6287	.3239
17	.1524	.1715	.1143		.3429	.4954	.5906
18	.1715	.1905	.0953		.3429	.4382	.5525
19	.1524	.1334	.0953	.0953	.0762	.0953	.0953
20	.1524	.1143	.1334	.0953	.1524	.0953	.0953
21	.1334	.1143	.1143	.0953	.1334	.0953	.1143
22	.1334	.1143	.0953	.0762	.1143	.0953	.0953
23	.1334	.0953	.0953		.1143	.0762	.0762
24	1.3535	1.7528	.6287	.724		.1143	.0762
Max	1.3535	1.8099	1.086	1.1812	.4763	.6668	.5906
Min	.0191	.0953	.0953	.0762	.0762	.0762	.0762
Avg	.1842	.7396	.3318	.7285	.2615	.2683	.2191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 209 / UJALAIWADI SHETI PUMP  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384			.0953		.1524	.0381
2	1.2384			.0762		.1905	.0381
3	1.1622			.0762		.2286	.0381
4	1.105			.0762		.2286	.0381
5	1.086			.0953		.2286	.0381
6	1.2384			.0953		.2286	.0381
7	1.6194			.1334		.2477	.0572
8	1.6575		.0381	.0762		.1905	.0572
9	1.467	.0191	.0381	.1334		.2667	.0381
10	.1334	1.7528	.0762	.1334		.0381	
11	1.467		.8764	.0381		.0191	
12	1.829	2.0767	.8573	.0381		.0381	.0381
13	1.7337	2.0386	.8192	.0381		.0381	.0191
14	1.5242	1.7718	.8573	.0191		.2477	.0191
15	1.6575	1.7147	.724	.0191		.0572	.0381
16	1.7528		.9145	.0191		.0381	.0381
17	1.4861		.9335		.0381	.0572	.0762
18	1.3717		.6859		.0381	.0572	.0191
19	.1143		.0762		.0381		.0762
20	.1143				.0381	.0191	.0572
21			.1143		.0572	.0191	.0572
22			.0953		.0381	.0191	.0381
23			.0953		.0381	.0381	.0381
24	1.5384			.0762		.1524	.0381
Max	1.829	2.0767	.9335	.1334	.0572	.2667	.0762
Min	.1143	.0191	.0381	.0191	.0381	.0191	.0191
Avg	1.2636	1.5623	.4801	.0729	.0408	.1218	.0424

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 201 / 11KV Randeviwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0566	.0572	1.7004	
2	.0572	.0566	.0572	1.6842	
3	.0572	.0566	.0572	1.6842	
4	.0572	.0566	.0572	1.6842	
5	.0572	.0566	.0572	1.749	
6	.0572	.0566	.0572	1.8138	
7	.0572	.0566	.0572	2.0729	
8	.0572	.0566	.0572	2.332	
9	.0572	.0566	.0572	2.2348	
10	.0572	.0566	.0486	.0486	
11	2.6558	2.9165	2.9959	.0572	
12	2.5617	3.0182	3.0931	.0572	
13	2.6715	2.9843	2.9797	.0572	
14	2.6566	2.9504	3.0445	.0572	
15	2.6566	2.8826	3.0445	.0572	
16	2.5152	2.696	2.8178	.0572	.1943
17	2.4669	2.5774	2.6235		.2429
18	2.3045	2.5095	2.4291		.2915
19	.0566	.0572	.0486		.0486
20	.0566	.0572	.0486		.0486
21	.0566	.0572	.0486		.0486
22	.0566	.0572	.0486		.0486
23	.0566	.0572	.0486		.0486
24	.0762	.0566	.0572	1.7166	
Max	2.6715	3.0182	3.0931	2.332	.2915
Min	.0566	.0566	.0486	.0486	.0486
Avg	.8925	.9768	.9955	1.1214	.1215



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 202 / M Sangaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.7522	.6516	.5658		.7059	
2	.7356	.7059	.6335	.5316		.6516	
3	.743	.0566	.724	.5487		.6099	
4	.6859	.6584	.724	.6173		.6516	
5	.6413	.7059	.7421	.6859		.7059	
6	.8764	.8939	.6516	.6859		.8059	
7	.9242	.7522	.7602	.8059		.7973	
8	.7282	.7973	.7602	.7545		.7442	
9	.6348	.7442	.7602	.6687		.7059	
10	.7095	.7602	.703	.6344		.7059	
11	.724	.6335	.6859	.6653		.7602	
12	.7059	.724	.6344	.6468		.7964	.5658
13	.8059	.724	.6173	.7023	.6099	.724	.5144
14	.8059	.7122	.6859	.7392	.6584	.7964	.6173
15	.8059	.763	.6859	.7392	.6584	.6516	.6173
16	.724	.8326	.6687	.7207		.5792	.6859
17	.6584	.7602	.6516		.7059	.6516	.6859
18	.6036	.7602	.6859		.7602	.7964	.6859
19	.8413	.8145	.7888		.8413	.8869	.823
20	.8939	.8688	.9259		.9465	.905	.7888
21	.8939	.7602	.8573		.8939	.8869	.823
22	.8413	.905	.823		.7973	.8145	.7888
23	.7973	.8507	.7202		.7602	.6335	.6859
24	.847	.7522	.6697	.583		.7059	
Max	.9242	.905	.9259	.8059	.9465	.905	.823
Min	.6036	.0566	.6173	.5316	.6099	.5792	.5144
Avg	.7667	.7370	.7171	.6644	.7632	.7364	.6902

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 203 / Sulkud AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2793	1.442	1.4922	.0648		
2	1.247	1.3916	1.4243	.0486		
3	1.247	1.3916	1.4074	.0486		
4	1.278	1.4251	1.4074	.0486		
5		1.6409	1.4074	.0648		
6		1.7695	1.7635	.0648		
7		2.1376	2.1704	.0648		
8	.1898	2.1605	2.2382	.0648		
9		1.9757	2.0856	.081		
10		.0943	.081	.081		
11	1.3413	.0953	.081	2.4981		
12	.0943	.0953		2.2708		.081
13	.0943	.0762	.081	2.4034		.081
14		.0762	.0648	2.3371		.0648
15		.0762	.081	2.4813		.0486
16		.0762	.081	2.3371		.3887
17	.0943	.0762	.081			1.2146
18	.0943	.0953	.0648		.8063	1.166
19	.1132	.0953				.081
20	.1132	.0953	.081			.081
21	.1132	.0953	.081			.081
22	.1132	.0953	.081			.0686
23	.0943	.1143	.0648			.0648
24	1.2955	1.358	1.5261	.0648		
Max	1.3413	2.1605	2.2382	2.4981	.8063	1.2146
Min	.0943	.0762	.0648	.0486	.8063	.0486
Avg	.5501	.7479	.8112	.8838	.8063	.2851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 204 / 11 KV LINGNOOR (VG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2801	.2534	.2058	.2241	.2427	
2	.2452	.2427	.2534	.2058	.2241	.2241	
3	.2477	.2427	.2715	.2058	.2241	.2241	
4	.2829	.2614	.2896	.2229	.2801	.2241	
5	.3395	.2801	.3439	.2401	.3361	.2801	
6	.3584	.3361	.362	.2572	.3174	.3361	
7	.3018	.3361	.2896	.2229	.2801	.3361	
8	.2378	.2801	.2896	.2058	.2614	.2801	
9	.2195	.2427	.2715	.1715	.2427	.2801	
10	.2378	.2427	.2572	.1715	.2427	.2172	
11	.2427	.2715	.2743	.1848	.2614	.2172	
12	.2987	.2715	.2743	.2033	.2801	.2353	.1372
13	.2987	.2715	.2743	.2218	.2801	.181	.1543
14	.2801	.2715	.2743	.2218	.2427	.1991	.1372
15	.2801	.2715	.2401	.2241	.2427	.1991	.12
16	.2801	.2353	.2401	.2054	.168	.2172	.1372
17	.2987	.2353	.2572		.1867	.1991	.1715
18	.2427	.2353	.2401		.2241	.2353	.1886
19	.3361	.2715	.2572		.2801	.2896	.2401
20	.3921	.3439	.3086		.3361	.3258	.2915
21	.3921	.3258	.3086		.3361	.3077	.2915
22	.3361	.3258	.2915		.3361	.2715	.2743
23	.2987	.2896	.2401		.2801	.2353	.2229
24	.2477	.2801	.2534	.2229	.2241	.2427	
Max	.3921	.3439	.362	.2572	.3361	.3361	.2915
Min	.2195	.2353	.2401	.1715	.168	.181	.12
Avg	.2892	.2769	.2757	.2114	.2630	.2500	.1972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 205 / 11 KV RTO Check Post  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
1	.0381
2	.0381
3	.0381
4	.0381
24	.0381
Max	.0381
Min	.0381
Avg	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 201 / 11KV Arya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5844	1.5775	2.0182	2.838	.2606	1.9044	2.4897
2	1.6598	1.6289	2.0748	2.7633	.2606	2.0538	2.7915
3	1.7924	1.7528	1.8861	2.8006	.2534	2.1125	2.9047
4	1.9231	1.8099	1.9427	2.2032	.3172	1.8861	2.4143
5	1.8671	1.885	1.8107	1.5123	.4458	1.5729	2.1502
6	1.885	1.9022	1.9605	1.363	.583	1.7926	1.3435
7	2.1879	1.9404	1.0111	1.1203	.6556	1.4632	2.037
8	1.3394	2.1538	1.5729	1.2136	.7282	1.4352	1.6461
9	1.9993	2.3765	2.1125	.8962	1.1576	2.2068	2.3388
10	1.9231	2.0538	2.5393	.8589	1.2752	1.9239	2.7726
11	2.3899	2.1658	4.7798	.7842	1.4335	1.7353	2.9801
12	2.7073	2.0538	2.9127	.7842	1.6385	2.452	2.3765
13	2.5579	1.3443	2.3525	.7842	1.6004	1.6221	2.6406
14	2.3899	2.3525	2.0538	.2801	1.6004	1.3203	2.8292
15	2.95	2.6139	2.1658	.2934	2.2672	2.3388	2.6406
16	3.0807	2.2634	2.2405	.2126	1.6598	2.7349	2.3954
17	2.8006	2.3339	2.7633		1.7353	2.8292	2.2445
18	2.5953	2.9801	3.3981		2.0559	1.6827	1.8861
19	1.8671	2.7726	2.7073		2.0936	2.6783	2.9047
20	1.9231	2.6029	2.782	.1166	1.9993	1.7375	2.5652
21	2.0351	2.3011	2.2032	.1166	1.4415	1.5384	2.6406
22	1.5565	2.8669	2.2032	.144	1.4998	2.6029	2.5274
23	1.5927	2.2257	2.7633	.2126	1.9993	2.5274	1.5729
24	1.7375	1.3375	1.7375	2.4832	.1372	1.7551	1.9239
Max	3.0807	2.9801	4.7798	2.838	2.2672	2.8292	2.9801
Min	1.3394	1.3375	1.0111	.1166	.1372	1.3203	1.3435
Avg	2.0977	2.1373	2.3330	1.1324	1.2125	1.9961	2.3757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 202 / 11 KV Managal Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6068	.3658	.4115	.8589	.2191	.4544	.4382
2	.5853	.4024	.4938	.8775	.2469	.4477	.4382
3	.5487	.4108	.4668	.8775	.2103	.4477	.4382
4	.5194	.3828	.439	.8589	.2328	.439	.4382
5	.5228	.3475	.4755	.8775	.4481	.4207	.4382
6	.5906	.4755	.5335	.8402	.4572	.4755	.4382
7	1.2742	1.4575	1.2631	.8589	.5049	1.2548	.9659
8	1.5432	1.2929	1.4089	.8402	.6866	.9808	1.4632
9	1.7741	1.9589	1.9993	.8402	.9722	.9065	1.7558
10	1.9044	2.1658	2.1658	.8402	1.5546	1.9616	1.4575
11	1.9791	2.2405	2.4272	.8402	1.4998	1.9993	2.4086
12	2.0351	1.587	2.0538	.8215	1.5939	2.0748	1.905
13	2.0911	2.0165	1.7177	.8589	1.9879	2.0748	1.9022
14	2.2965	2.2405	1.7737	.1791	2.0165	2.2634	2.0538
15	2.3525	2.3339	1.6804	.1425	2.1807	2.1502	2.0485
16	1.7924	2.0851	1.6057	.1457	2.0513	2.2257	1.9978
17	1.2308	1.9993	1.7924		1.5927	1.8861	2.2032
18	.9878	1.5775	1.8111		1.5043	2.5463	1.382
19	.9995	1.21	1.5497		1.3523	1.3108	1.21
20	.6161	1.0978	1.1016	.1543	.7034	1.2289	.9362
21	.5944	.644	.8215	.1425	.5434	.8916	.7922
22	.5761	.6836	.8402	.1286	.5578	.5335	.7628
23	.5761	.631	.8215	.176	.5346	.4755	.4733
24	.5975	.5321	.5788	.8589	.2058	.5171	.4287
Max	2.3525	2.3339	2.4272	.8775	2.1807	2.5463	2.4086
Min	.5194	.3475	.4115	.1286	.2058	.4207	.4287
Avg	1.1914	1.2558	1.2597	.6199	.9940	1.2486	1.1990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 203 / 11 KV KORGAONKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6979	.6602	.6413	.7468	.6348	.7049	.7167
2	.6979	.679	.6722	.7468	.6348	.7049	.7167
3	.679	.6722	.6908	.7468	.6535	.6602	.7167
4	.6348	.6602	.6722	.6722	.5975	.6668	.7167
5	.6535	.6668	.6908	.6348	.6348	.6224	.679
6	.6602	.6413	.6979	.6722	.5975	.6859	.6036
7	.7356	.724	.6224	.8029	.5975	.6668	.6413
8	.7545	.6478	.7545	.8029	.7468	.7621	.6602
9	.9054	.7621	.8488	.7095	.7842	.7545	.7922
10	.9335	.6722	.8775	.7468	.8383	.8299	.811
11	.8962	.6722	1.0642	.7842	.8764	.9054	.811
12	.8962	.7095	.8589	.7842	.8954	.7545	.7356
13	.8402	.6722	.8402	.7842	.7811	.7545	.7922
14	.8962	.7095	.8775	.823	.8002		.8299
15	.9335	.7468	.8589	.8402	.8954	.811	.7922
16	.9149	.7167	.7202	.8507	.8488	.7922	.9054
17	.9335	.7167	.8215		.8573	.8676	.8865
18	.7621	.6979	.7095		.8002	.8488	.8299
19	.7167	.7167	.7282		.8002	.8299	.8488
20	.7733	.6979	.7842	.4572	.7811	.7922	.7545
21	.743	.679	.7095		.7621	.7167	.7922
22	.8002	.6413	.7095	.6219	.8192	.7167	.811
23	.743	.6979	.7282	.6161	.8383	.7545	.7922
24	.7049	.6602	.6602	.7095	.5544	.6668	.679
Max	.9335	.7621	1.0642	.8507	.8954	.9054	.9054
Min	.6348	.6413	.6224	.4572	.5544	.6224	.6036
Avg	.7878	.6883	.7600	.7276	.7512	.7508	.7631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 204 / 11 KV Silver Zone

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.037	1.8671	2.452	2.782	1.0425	1.0562	.8173
2	1.9791	1.8671	2.584	2.8006	1.0425	1.0456	.6916
3	1.9605	1.9231	2.7161	2.5579	1.0242	1.0562	.6497
4	1.8671	1.9427	2.4897	2.4272	1.0425	1.0185	.6497
5	1.8484	1.8484	2.5652	2.2405	1.0269	1.0185	.6916
6	1.8462	1.9044	2.6029	2.2218	1.0608	1.0374	.6996
7	1.8861	1.9418	2.6029	2.2218	1.0642	.9997	.6478
8	1.9239	1.8673	2.6783	2.0165	1.1576	1.0185	.6811
9	2.1879	2.3577	3.6214	2.3152	1.419	1.1506	.9288
10	2.3152	2.3899	3.7342	2.4646	1.8296	1.1869	1.2826
11	2.3899	2.3525	3.4541	2.5206	2.0936	1.2071	1.4335
12	2.4646	2.4646	2.3339	2.4272	1.9239	1.1797	1.4146
13	2.2592	2.4272	2.9874	2.1658	1.2071	1.1393	1.3203
14		2.4272	2.2032	2.0351	1.2637	1.0105	2.6406
15	3.6782	2.4646	2.2032	2.0911	1.2955	.9574	2.7161
16	2.2779	2.4143	2.1658	2.2862	1.226	.9054	2.6406
17	2.3011	2.4143	2.1285		1.1883	.9328	2.7161
18	2.3388	3.7157	1.9978		1.1128	.8676	2.5652
19	2.2862	1.7737	1.8861		1.1317	1.0155	2.4143
20	2.0957	1.905	3.2114	.8402	1.1506	.7042	2.2634
21	2.0748	1.9616	3.0807	.6722	1.0751	.7183	2.2634
22	2.0936	1.9616	2.7073	1.0642	1.0562	.8322	2.1125
23	2.1502	1.9805	2.5953	1.0456	1.1128	.7255	2.0748
24	2.037	2.037	2.3525	3.062		1.0751	.9054
Max	3.6782	3.7157	3.7342	3.062	2.0936	1.2071	2.7161
Min	1.8462	1.7737	1.8861	.6722	1.0242	.7042	.6478
Avg	2.1869	2.1754	2.6397	2.1075	1.2412	.9941	1.5509



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 205 / 11 kV VILSON ROOFING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3381	4.1076	4.2816	5.1905	2.0332	4.1684	3.2442
2	4.5268	4.1872	4.382	5.0412	1.9281	4.1495	3.9609
3	4.2061	4.1684	4.5153	5.0412	1.8519	4.0962	4.3004
4	4.0703	4.201	4.0741	5.0785	2.0452	3.9609	4.3759
5	4.201	4.2756	3.9819	4.9851	1.9185	3.3196	4.1495
6	4.425	4.9535	4.1872	4.5744	1.8642	4.3439	4.0364
7	3.6214	4.4702	4.0741	4.4997	1.829	3.5648	4.1118
8	2.8669	2.5766	2.6139	3.0247	1.2574	3.0994	2.8292
9	1.957	3.9232	3.5082	3.1181	2.4691	3.7723	4.1914
10	3.7902	4.8544	4.6304	2.9874	3.5818	5.8471	4.9417
11	3.8462	4.7798	3.2674	2.1472	3.5837	4.5645	4.9983
12	3.9209	4.1823	3.6035	2.5206	3.658	4.6106	4.5268
13	2.9874	4.7798	3.2114	1.8671	3.4139	4.2867	3.8477
14	2.4832	4.7424	4.9478	1.3565	4.8011	4.9983	4.6588
15	3.1741	4.6677	4.8544	1.406	3.6969	4.5344	4.4702
16	3.1927	4.5268	2.7073	1.4413	3.8477	3.7723	4.0552
17	3.3951		4.9478		5.1492	4.2627	4.7531
18	3.9043	4.3381	4.9478		4.4324	4.5725	4.772
19	4.3381	4.6399	4.9665		4.1307	4.7154	4.9983
20	3.2895	3.6403	3.6782	.9031	3.6222	4.1118	5.0926
21	3.9956	4.904	3.8836	1.286	4.2627	4.6776	4.2627
22	4.0581	5.2812	4.5744	1.2136	4.3947	3.8666	3.9609
23	3.308	4.772	3.7715	1.9589	4.225	3.2065	4.2816
24	4.6296	4.1076	4.1118	4.2943	1.8351	3.1499	2.9801
Max	4.6296	5.2812	4.9665	5.1905	5.1492	5.8471	5.0926
Min	1.957	2.5766	2.6139	.9031	1.2574	3.0994	2.8292
Avg	3.6886	4.3948	4.0718	3.0445	3.1597	4.1522	4.2417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 206 / 11KV Mahalaxmi

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8673	.4715	1.8484	1.7737	.2467	1.6244	1.8484
2	2.1313	.4715	2.452	1.9605	.2824	2.0538	1.9239
3	2.4272	.4382	2.2068	2.0538	.2881	2.0182	1.9616
4	2.2592	.4382	2.037	1.8671	.2915	2.0165	1.9993
5	2.1502	.3258	1.7924	1.6991	.3525	.5573	2.0748
6	2.3765	.3772	1.9616	1.7551	.3567	.5916	2.037
7	1.39	.4382	2.5652	1.7551	.3822	.6626	.6554
8	1.3253	.8741	2.0182	.7095	.6358	.6222	
9	1.5746	1.0576	3.1687	.6535	2.1658	2.8292	1.6095
10	1.8671	1.8671	2.6139	.6348	1.2178	3.0178	3.0178
11	1.9044	1.6804	2.8753	.5601	1.9616	2.8292	3.4328
12	1.9231	1.9231	2.7633	.5975	1.7924	2.1691	3.2065
13	1.4563	1.7551	1.2136	.5228	1.7741	2.7538	2.6406
14	1.9044	1.4937	3.2674	.1955	2.1472	3.1687	3.4139
15	1.3817	1.4563	3.3608	.2134	3.5627	2.5652	3.263
16	1.6804	1.6975	2.5393	.2185	2.1285	1.8484	1.6032
17	1.6289	1.086	2.9874		1.6078	2.1125	3.5082
18	1.286	3.0556	1.6804		1.4266	2.4143	3.8289
19	1.2403	2.8292	2.0538		1.6409	2.5463	3.2065
20	.6047	2.7538	1.5123		1.8858	1.6221	3.2442
21	.5434	2.3577	2.5206		.6718	.4755	2.2822
22	.5144	1.4449	3.0247	.2267	1.7187	2.1502	2.6406
23	.5144	2.037	1.0456	.6321	2.1879	1.7924	.9088
24	2.1691	.5258	.8326	2.1845	.2534	1.386	1.3435
Max	2.4272	3.0556	3.3608	2.1845	3.5627	3.1687	3.8289
Min	.5144	.3258	.8326	.1955	.2467	.4755	.6554
Avg	1.5883	1.3690	2.2642	1.0639	1.2908	1.9095	2.4196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 201 / 11 KV Vardhaman Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.2862	2.0386	2.2862	1.2193	2.4387	2.2862
2	1.9052	2.6673	1.9243	1.9052	1.2384	2.0576	2.1338
3	2.0576	2.2481	2.0386	1.9052	1.1431	2.1338	2.3624
4	2.0386	1.9052	1.9052	1.829	1.1431	1.9052	2.2481
5	2.0957	1.8099	2.0576	1.7147	1.2384	1.8671	2.2481
6	1.9624	1.8671	1.9814	1.7909	1.3336	1.7147	2.21
7	2.0767	2.0957	2.0767	1.2955	1.2193	2.0767	1.7147
8	1.7147	1.6194	2.2481	1.3146	1.3336	1.4289	1.6004
9	1.6385	2.7816	2.21	1.2193	2.4196	2.7244	2.3243
10	2.8578	3.0483	2.8769	1.2384	2.7054	3.1626	2.3815
11	2.8578	3.1626	3.0864	1.2384	2.4768	3.1817	2.4768
12	2.8197	2.4958	2.5339	1.2384	3.0102	2.7244	2.7816
13	1.7147	2.8769	2.572	1.2955	2.1148	2.3243	2.8197
14	2.7435	2.8959	2.934	1.2955	2.6482	3.0293	1.8671
15	2.8578	3.1626	2.9912	1.2955	2.7625	2.8387	2.6673
16	2.8197	2.6673	2.7625	1.2955	2.2862	2.8578	2.9912
17	1.829		2.1148	1.2765	2.2481	2.6482	2.7244
18	2.0957	2.0957	2.4958	1.2955	2.3815	2.3434	1.8671
19	2.7435	2.5339	2.8959	1.2574	2.8578	2.6673	2.21
20	2.3815	1.4861	2.2862	1.2765	2.2291	2.2862	2.4958
21	2.0767	1.9814	2.4768	1.2574	1.6004	1.448	2.3624
22	2.4768	2.0576	2.553	1.2384	2.5911	1.848	2.0005
23	2.8197	2.0005	2.4768	1.2384	2.8959	2.4387	2.2481
24	2.553	2.4768	2.0576	2.4768	1.1812	2.6673	2.7625
Max	2.8578	3.1626	3.0864	2.4768	3.0102	3.1817	2.9912
Min	1.6385	1.4861	1.9052	1.2193	1.1431	1.4289	1.6004
Avg	2.3013	2.3575	2.3998	1.4781	2.0116	2.3672	2.3243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 202 / 11 KV Mather & Platt  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6575	1.5242	1.6004	1.4861	1.4098	1.5623	1.6004
2	1.6194	1.5242	1.4861	1.3717	1.3336	1.5623	1.5813
3	1.5623	1.4289	1.4861	1.467	1.2955	1.5242	1.5623
4	1.6004	1.3717	1.5623	1.3717	1.2384	1.5623	1.5242
5	1.5432	1.3336	1.467	1.3336	1.3336	1.5623	1.5432
6	1.5051	1.4289	1.4861	1.448	1.3908	1.5623	1.5242
7	1.5242	1.5242	1.5242	1.4289	1.3908	1.5051	1.5242
8	1.6956	1.5623	1.6004	1.5051	1.2574	1.5813	1.5242
9	2.1529	2.3053	1.6956	1.3336	1.7528	2.0005	2.191
10	2.3815	2.5149	2.1148	1.3717	2.0005	2.0386	2.4196
11	2.1338	2.6673	2.1148	1.105	2.3243	2.5149	2.572
12	2.0957	2.3053			2.4006	1.7718	2.3243
13	2.0957	2.4006	2.0957		2.2672	2.0195	2.3815
14	2.0195	2.3053	2.1529	.9907	2.5149	2.4768	2.191
15	2.191	2.5339	1.9433	.8383	2.572	2.2481	2.6863
16	2.1529	2.1529	2.0576	.9526	2.4768	2.4577	2.0576
17	1.9052		1.829	.9526	2.1338	2.2481	2.1719
18	1.8099	1.9814	1.6766	.9526	2.0195	1.9433	1.7528
19	1.7718	1.7718	1.6194	1.4289	1.7909	1.7718	1.5242
20	1.4861	1.5813	1.5432	1.448	1.7718	1.7147	1.3717
21	1.5242	1.5051	1.4098	1.4289	1.5432	1.5432	1.4098
22	1.6956	1.6004	1.467	1.4098	1.6004	1.6956	1.5242
23	1.5623	1.6575	1.4289	1.4098	1.6004	1.6385	1.6385
24	1.6194	1.5242	1.5623	1.448	1.4098	1.6004	1.6194
Max	2.3815	2.6673	2.1529	1.5051	2.572	2.5149	2.6863
Min	1.4861	1.3336	1.4098	.8383	1.2384	1.5051	1.3717
Avg	1.8044	1.8481	1.6923	1.2947	1.7845	1.8377	1.8425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 204 / Tamgoan VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381		.4954	.4763	1.6194	1.5242	1.0669
2	.381		.4954	.4954	1.6766	1.4861	1.0479
3	.4191		.381	.4572	1.7147	1.4861	1.0288
4	.4572		.4191	.4191	1.6194	1.5242	1.0288
5	.4191		.4572	.4572	1.5242	1.5813	1.0479
6	.4763		.4001	.4763	1.6385	1.7147	1.1431
7	.5525		.4382	.5335	1.9052		1.1812
8	.4572		.4001	.5335	1.7147	1.7337	1.3146
9	.4572		.3239	.4001	1.8671	1.4289	1.2955
10	.5716		.4001	.4382	2.0005	1.3717	1.3336
11	.5906	.1715	.4191	.381	2.0005	1.2765	1.3717
12	.5525	.4191		.362	2.0957	1.2765	1.3908
13	.5144	.5144	.6287	.2286	2.0005	1.1241	1.2384
14	.5335	.4382	.5525	.0381	1.9433	1.1812	1.2193
15	.5716	.5144	.4954	.0381	1.7909	1.2765	1.2193
16	.5906	.5716	.5716		1.8671	1.2765	1.1431
17	.5716		.5716	.381	1.9052	1.2765	1.2955
18	.5716	.0381	.5716	.2667	1.7528	1.3717	1.2574
19	.5716	.0381	.6097	.4191	1.9814	1.5242	1.3908
20	.5525	.5525	.6478	.4763	2.2481	1.5242	1.6385
21		.5335	.5716	.4763	2.1338	1.467	1.4861
22		.5716	.5335	.4763	2.0767	1.4098	1.4289
23		.5335	.5144	.4001	1.7909	1.1812	1.2765
24	.4191		.5335	.5716	.381	1.5623	1.1431
Max	.5906	.5716	.6478	.5716	2.2481	1.7337	1.6385
Min	.381	.0381	.3239	.0381	.381	1.1241	1.0288
Avg	.5053	.4080	.4970	.4001	1.8020	1.4165	1.2495

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 205 / 11 KV Patel Petro feeder      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6766	1.2384	1.086	1.2384	.9907	1.6766	1.1431
2	1.6575	1.1622	1.105	1.1622	1.0479	1.6766	1.1431
3	1.6956	1.1431	1.1812	1.1812	.9145	1.2574	.9526
4	1.5432	1.105	1.1622	1.1241	.8573	1.2193	.8002
5	1.467	1.0479	1.2955	.9717	.9145	1.1812	.7621
6	1.4289	1.105	1.3336	.9335	1.086	1.1812	.7621
7	.9526	1.105	1.6575	.6478	1.2955	.9717	.9907
8	1.4289	.9526	1.4098	.7049	1.2955	1.4861	1.0098
9	1.9243	1.7909	1.8861	.6668	1.7528	1.8671	1.9814
10	2.2481	1.9243	2.0576	.6478	1.9814	1.9624	1.6575
11	2.1529	2.0957	2.8578	.6478	1.2765	2.6673	1.7528
12	2.1719	2.3053	1.8671	.6287	2.0957	2.4768	1.6194
13	1.7147	2.0957	2.2672	.6859	1.9052	2.0576	1.5813
14	2.2291	2.2862	2.4196	.7049	2.7816	2.6482	1.5623
15	2.7244	2.191	2.4958	.7049	2.4577	2.553	2.191
16	2.4387	2.3243	2.3624	.7049	2.4387	2.5911	2.6292
17	2.4196		2.0957	.7049	1.9243	2.4958	2.6673
18	1.7147	1.7337	1.6575	.724	1.7147	1.5242	2.3434
19	1.2193	.8764	1.3717	.7049	1.6766	1.5813	1.6194
20	1.0479	.9145	1.4289	.7049	.8954	1.5242	1.0669
21	1.2574	.6668	1.448	.743	1.2955	.7621	.8764
22	1.3146	.7621	1.5242	.9145	1.6004	.9907	.8954
23	1.2384	.8002	1.467	.8573	1.6575	1.1431	.9145
24	1.7337	1.2193	.8383	1.3717	.9526	1.848	1.1812
Max	2.7244	2.3243	2.8578	1.3717	2.7816	2.6673	2.6673
Min	.9526	.6668	.8383	.6287	.8573	.7621	.7621
Avg	1.725	1.4281	1.6782	.8367	1.5337	1.7226	1.4210

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 206 / 11KV Devi gas

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2384	1.4098	1.3336	.8002	1.4289	1.1431
2	1.4098	1.1431	1.3336	1.3146	.7621	1.3717	1.0288
3	1.467	1.105	1.3527	1.3717	.8002	1.4098	.9907
4	1.3717	1.105	1.467	1.3336	.7621	1.3336	
5	1.3336	1.1431	1.4289	1.3527	.724	1.3717	1.105
6	1.1812	1.2193	1.448	1.3908	.8764	1.3527	1.105
7	1.467	1.2384	1.1812	1.1241	.8764	1.467	1.1431
8	1.5051	1.0479	1.5813	.8002	.9526	1.5432	1.3717
9	1.6575	1.5813	1.6004	.6668	1.3908	1.848	1.5051
10	1.9433	1.6575	1.5051	.7621	1.1622	2.1148	1.8671
11	1.9052	1.7718	2.2481	.7621	1.9052	2.3624	1.829
12	1.9624	2.0386	2.0957	.7621	1.8861	2.1529	1.8099
13	1.6766	1.7528	1.7528	.7811	1.9243	2.1529	1.9433
14	1.8671	1.7718	2.1529	.7811	2.3815	1.829	1.9624
15	1.7528	1.9052	2.0195	.7811	1.7909	2.2291	1.7337
16	1.9433	1.5432	1.848		2.1338	2.0767	1.9433
17	.0191		1.7909	.8002	2.0957	2.0767	1.8671
18	1.5242	1.3908	1.6194		2.0386	1.7909	1.2574
19	1.3717	1.5242	1.7909	.7621	1.7909	1.7337	1.467
20	1.2955	1.6575	1.6004	.7621	1.7147	1.7147	.9526
21	1.3146	1.3336	1.6194	.7621	1.9052	1.6194	1.3908
22	1.3527	1.467	1.6575		1.467	1.6575	1.5242
23	1.1812	1.3717	1.6766	.7621	1.5623	1.5623	1.4098
24	1.5242	1.2574	1.3717	1.3717	.8002		1.2384
Max	1.9624	2.0386	2.2481	1.3908	2.3815	2.3624	1.9624
Min	.0191	1.0479	1.1812	.6668	.724	1.3336	.9526
Avg	1.4749	1.4463	1.6480	.978	1.4376	1.7478	1.4604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 201 / Mhakve AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7969	.8916	.9259		.0762	.0514	.0381
2	.7969	.8916	.9259		.0762	.0514	.0381
3	.788	.8916	.9259		.0762	.0514	.0381
4	.7969	.8916	.9259		.0762	.0514	.0381
5	1.0174	.9259	.9431		.0762	.0514	.0381
6	1.2717	1.0117	1.166		.1143	.0514	.0381
7	1.3735	1.5261	1.4575		.1143	.0514	.0381
8	1.3565	1.7661	1.6118		.0762		
9	1.448	1.7147	1.4232		.0762	.0762	.0381
10	.0381	.1029	.1715		.0953	.0572	.0381
11	.0953	.1543	.1524	1.7337	1.286	1.105	.7621
12	.0953	.1372	.1715		1.3375	1.105	.8002
13	.1029	.12	.1715	2.2291	1.3717	1.1431	
14	.1029	.12	.1715	2.553	1.3717	1.1622	.7621
15	.12	.1543	.1905	2.5339	1.2003	1.1431	.6859
16	.1372		.1715	2.4387		1.1622	.6478
17	.1372		.1524				
18	.1029		.1334		.703	.9526	.5144
19	.1543		.1715		.0514	.0381	.0572
20	.12	.1029	.1715		.0514	.0381	.0572
21	.12	.1029	.1524		.0514		.0572
22	.12	.1029			.0514		.0572
23	.1029	.0857		.0762	.0514	.0381	.0572
24	2.5605	.9259	.9431		.0762	.0514	.0381
Max	2.5605	1.7661	1.6118	2.553	1.3717	1.1622	.8002
Min	.0381	.0857	.1334	.0762	.0514	.0381	.0381
Avg	.5731	.6310	.6014	1.9274	.3846	.4216	.2305



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 202 / Mhakve Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3475	.3361	.3361	.3429	.3429	.3174	.3048
2	.3475	.3361	.3361	.3429	.3429	.2987	.3048
3	.3475	.3361	.3361	.3429	.3429	.2987	.3048
4	.3475	.3361	.3361	.3429	.3429	.2987	.3048
5	.3658	.3547	.3174	.362	.362	.3174	.3239
6	.3292	.3734	.3174	.4191	.381	.3361	.381
7	.3292	.3361	.3547	.4001	.3429	.3547	.362
8	.3109	.3361	.3361	.362	.3429		
9	.3239	.3361	.3361		.3239	.3239	.3429
10	.3239	.3174	.3048		.3239	.3048	.3429
11	.3429	.3547	.4191	.3429	.3547	.3239	.381
12	.3429	.3547	.4001		.3547	.3239	.2858
13	.3361	.3547	.4191	.3239	.3734	.3429	
14	.3361	.3361	.4191	.3239	.3734	.3429	.3239
15	.3361	.3734	.4191	.3239	.2801	.3239	.3239
16	.3361		.4191	.3429	.3361	.3429	.3048
17	.3361		.4001	.362			
18	.3174	.4294	.381		.2987	.381	.2858
19	.3734	.5975	.4191		.2614	.5716	.4954
20	.5601	.5601	.5716		.5601	.5335	.6287
21	.5228	.5415	.5525		.4668		.5335
22	.4481	.4854	.5144		.4854		.4191
23	.4108	.5041	.4001	.381	.4108	.381	.3429
24	1.9166	.3547	.3547	.362	.3429	.3547	.3429
Max	1.9166	.5975	.5716	.4191	.5601	.5716	.6287
Min	.3109	.3174	.3048	.3239	.2614	.2987	.2858
Avg	.4287	.3929	.3917	.3548	.3629	.3536	.3638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 203 / Kenavade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0857	.1029	1.1431	.6097	.2401	.1905
2	.0838	.0857	.1029	1.1241	.5716	.2401	.1905
3	.0838	.0857	.1029	1.1241	.5716	.2401	.1905
4	.0838	.0857	.1029	1.1241	.5716	.2401	.1905
5	.1006	.1029	.1029	1.1241	.5716	.2572	.1905
6	.1006	.1372	.1029	1.4098	.5716	.3258	.2096
7	.1174	.1372	.1372	1.7147	.724	.4801	.2667
8	.1509	.1715	.1715	1.7909	.8002		
9	.1524	.1715	.1029	1.1622	.724	.4954	.3429
10		.1543			.0762	.0572	.0572
11	.1524	1.8519	2.0767	.0953	.0686	.0762	.0572
12	1.9624	1.9376	2.0576		.0857	.0762	.0572
13	1.749	1.9204	2.0957	.0381	.0857	.0762	
14	1.6118	1.869	1.829	.1524	.0857	.0762	.0572
15	1.7318	1.869	1.9814	.1524	.0857	.0762	.0572
16	1.7661		1.8671	.1524	.0686	.0762	.0762
17	1.5261	1.1317	1.7337	.1715	.0857		.0762
18	1.3717	1.0631	1.467		.0857	.0762	.0762
19	.1372	.0857	.1524		.0857	.0762	.0762
20	.1372	.1029	.1334		.0857	.0762	.0762
21	.1372	.12	.1334		.0686		.0762
22	.1372	.12	.0953		.0686		.0762
23	.0857	.1029	.0762	.0572	.0686	.0572	.0762
24	3.2114	.0857	.1029		.6478	.2572	.1905
Max	3.2114	1.9376	2.0957	1.7909	.8002	.4954	.3429
Min	.0838	.0857	.0762	.0381	.0686	.0572	.0572
Avg	.7250	.5860	.7318	.7835	.3112	.1788	.1299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144119 / PIMPALGAON KH

Feeder No / Name : 201 / 11 KV PIMPALGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.1523
Max	1.1523
Min	1.1523
Avg	1.1523

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 144119 / PIMPALGAON KH

Feeder No / Name : 203 / 11 KV Vhannur AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	1.6448
Max	1.6448
Min	1.6448
Avg	1.6448

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 404 / 33 KV Samir

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
22	1.6244
24	4.4993
Max	4.4993
Min	1.6244
Avg	3.0619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 406 / 33 KV Menon BRG

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	5.7488
Max	5.7488
Min	5.7488
Avg	5.7488

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 601 / 110KV Shahu CoGen

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	4.8903
Max	4.8903
Min	4.8903
Avg	4.8903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 402 / 33KV MIDC

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	1.5912
Max	1.5912
Min	1.5912
Avg	1.5912



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 403 / 33 kv pattankodoli

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 404 / 33Kv Raymond

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.9851
Max	4.9851
Min	4.9851
Avg	4.9851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 603 / 110 kV Ichalkaranji NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(Jawahar + Feeder KV- 100 / (CONTINOUS PROCESS)(NO STAGGERING  
INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	21.0438
Max	21.0438
Min	21.0438
Avg	21.0438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 401 / 33KV Oswal Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.6584
Max	.6584
Min	.6584
Avg	.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 402 / 33KV Metro Feeder  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(NON CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	6.749
Max	6.749
Min	6.749
Avg	6.749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 403 / 33KV Jai Ambey Feeder

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
22	.0566
24	.1132
Max	.1132
Min	.0566
Avg	.0849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 404 / 33KV Kirloskar Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	5.7716
Max	5.7716
Min	5.7716
Avg	5.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 405 / 33KV Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.5206
Max	2.5206
Min	2.5206
Avg	2.5206



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 406 / 33KV Apple Spong NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	5.2675
Max	5.2675
Min	5.2675
Avg	5.2675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 407 / Mantri Metal

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.1367
Max	3.1367
Min	3.1367
Avg	3.1367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 408 / 33KV KOEL Exp NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	4.7611
Max	4.7611
Min	4.7611
Avg	4.7611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 409 / 33KV UTP

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.6037
Max	3.6037
Min	3.6037
Avg	3.6037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 410 / 33KV GPI

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	2.5789
Max	2.5789
Min	2.5789
Avg	2.5789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 411 / 33 kv Hupari Feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	7.7161
Max	7.7161
Min	7.7161
Avg	7.7161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 201 / 11KV KAPASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5716		.3048	.0572	.0381		.0381
2	.5335		.3048	.0572	.0381		.0381
3	.5335		.3048	.0572	.0381		.0381
4	.5335		.3048	.0572	.0381		.0381
5	.5906		.3048	.0572	.0381		.0381
6	.6668		.3239	.0381	.0381		.0381
7	.8192		.4572	.0381	.0381		.0381
8	.9145		.4572	.0572	.0381		.0381
9	.8002		.4191	.0572	.0381		.0381
10	.0762		.0572	.0953	.0572		.0381
11	.1334		.0762	.381	.3048	.2858	.381
12	.1143	.4382	.0953	.381	.3239	.2667	.3429
13	.1143	.4572	.0953	.381	.3048	.3048	.3239
14	.0762	.4001	.0953		.2667	.2667	.2477
15	.0762	.381	.0953	.3239	.2477	.2667	.2667
16	.0762	.0572		.2858	.2096	.3048	.2477
17		.0572	.0762	.2667	.2096	.3429	
18		.0762	.0572	.2096	.2096	.2667	.1715
19		.0572	.0572	.0381	.0381	.0381	.0381
20		.0572	.0572	.0381		.0381	.0572
21		.0572	.0572	.0381		.0381	.0381
22		.0572	.0572	.0381		.0381	.0572
23		.0572	.0572	.0381		.0381	.0381
24	.5716		.3239	.0381	.0381		.0381
Max	.9145	.4572	.4572	.381	.3239	.3429	.381
Min	.0762	.0572	.0572	.0381	.0381	.0381	.0381
Avg	.4236	.1794	.1930	.1317	.1277	.1920	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 202 / 11 KV Hasoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.0381	.0381	.3239	.2858	.1905	.1905
2	.1905	.0381	.0381	.3429	.2858	.1905	.1905
3	.1905	.0381	.0381	.3239	.2858	.1905	.1905
4	.1905	.0381	.0381	.3239	.2667	.1905	.1715
5	.1905	.0381	.0381	.381	.2667	.1905	.1715
6	.2858	.0381	.0762	.4191	.2667	.1905	.1715
7	.2858	.0762	.0381	.5144	.3239	.2286	.1905
8	.3048	.1334	.0381	.4954	.381	.2667	.2096
9	.3048	.0953	.0381	.381	.362	.2667	.2477
10	.2667	.0953	.0762	.0762	.0762	.0381	.0381
11	2.0957	.6859	.583	.0953		.0381	.0381
12	1.9433	.7049	.6344	.0953	.0762	.0381	.0381
13	1.8671	.6478	.6344	.0762	.0762	.0381	.0381
14	1.6766	.5525	.6173	.0953	.0762	.0381	.0381
15	1.5242	.4954	.6001	.0762	.1143	.0381	.0381
16	1.4289	.4382		.0381	.0762		.0381
17	1.0098	.4191	.5335	.0381	.0762	.0762	.0381
18	.7621	.381	.4572		.0762		.0381
19		.0381	.0762	.0762	.0572		.0381
20	.0762	.0381		.0762	.0381	.0381	.0381
21	.0762	.0381		.0762	.0191	.0381	.0381
22	.0762	.0381		.0381	.0381	.0381	.0381
23	.0762	.0381	.0953	.0381	.0191	.0381	.0381
24	.1905	.0381	.0381	.3048	.2858	.2096	.1905
Max	2.0957	.7049	.6344	.5144	.381	.2667	.2477
Min	.0762	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.6610	.2159	.2363	.2046	.1665	.1225	.1024



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 203 / 11 KV MUGALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4191	.724	.1524	.0953	.0762	.0381
2		.4001	.7049	.1524	.0953	.0762	.0381
3		.381	.7049	.1524	.0953	.0762	.0381
4		.381	.7049	.1524	.0953	.0762	.0381
5		.362	.7049	.1334	.0953	.0762	.0381
6		.381	.7049	.1334	.1143	.0762	.0381
7		.4763	.8764	.1524	.1143	.0953	.0381
8		.6287	.8573	.1334	.1143	.0953	.0381
9	1.3908	.5525	.8059	.1334	.1143	.0762	
10	1.5432	.0762	.1143	.1143	.1143	.0381	.0381
11	1.448	.0762	.1143	.9526	.724	.5716	.0381
12	.1524		.1334	1.0288	.8573	.5716	.5716
13	.1524			.9907	.8383	.6097	.6097
14	.1524	.0762		.9526	.8192	.6287	.6097
15	.1524	.0762		.9145	.7811	.5716	.5525
16	.1334	.0762		.8573		.6097	.4763
17		.0381		.724	.6478	.7049	.4572
18		.0381	.1334	.6668	.5716	.5716	.4954
19			.1334	.0953	.0381		.0381
20	.0381	.1334	.1524	.0953	.0381	.0381	.0381
21	.0381	.1143	.1334	.0953	.0381	.0381	.0381
22	.0381	.1143	.1524	.0953	.0381	.0381	.0381
23	.0381	.1143	.1524	.0953	.0762	.0381	.0381
24		.4191	.7621	.1334	.0953	.0762	.0381
Max	1.5432	.6287	.8764	1.0288	.8573	.7049	.6097
Min	.0381	.0381	.1143	.0953	.0381	.0381	.0381
Avg	.4398	.2540	.4616	.3795	.2874	.2535	.1905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 204 / 11 KV LINGNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143		.0381	.724	.6097	.5716	.3429
2	.1143		.0381	.7049	.5716	.5716	.3239
3	.1143		.0381	.743	.5716	.5716	.3239
4	.1143		.0381	.7049	.5716	.5716	.3048
5			.0381	.6859	.6478	.6097	.3048
6			.0381	.8383	.8002	.6478	.3239
7			.0381	1.105	1.0669	.7621	.362
8			.0381	1.1812	1.1241	.9145	.4191
9			.0381	.9526	.823	.8002	.381
10	.0953		.0381	.0191		.0381	.0381
11	1.7337		1.3032	.0762		.0381	.0381
12	1.6766	1.0974	1.2346	.0381		.0381	.0381
13	1.5242	.7373		.0381		.0381	.0381
14	1.4289	.8402		.0381		.0381	.0381
15	1.3717	.6859		.0381		.0381	.0381
16	1.3336	1.046		.0381		.0381	.0381
17		1.1431		.0381		.0381	.0381
18		.8954	.9145	.0381	.0381		.0381
19		.0381	.0762	.0381	.0381		.0381
20		.0762		.0381	.0381	.0381	.0381
21		.0381		.0381	.0381	.0381	.0953
22		.0381		.0381	.0381	.0381	.0381
23		.0381		.0381	.0191	.0381	.0381
24	.1143		.0381	.724	.6097	.5716	.3429
Max	1.7337	1.1431	1.3032	1.1812	1.1241	.9145	.4191
Min	.0953	.0381	.0381	.0191	.0191	.0381	.0381
Avg	.8113	.5562	.2632	.3715	.4754	.3204	.1675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 205 / 11 KV Arjunwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.5716		.0953	.1143	.0381
2	.381	.5335		.0953	.0953	.0381
3	.381			.0953	.0953	.0381
4	.381			.0953	.0953	.0381
5	.381	.5716		.0953	.0953	.0381
6	.381	.724		.1143	.1143	.0381
7	.381	.8383		.1524	.0953	.0381
8	.4191	.9145		.1143	.0953	.0381
9	.4191	.8192		.1143	.0953	.0762
10	.1143	.0953		.1334	.0762	.0762
11	.1524	.1334		.9526	.5716	.7049
12	.1334	.1143		.9145	.5716	.6478
13	.1334	.1524		.9526	.6097	.5716
14	.1334	.1334	.8573	.8764	.6097	.5716
15	.1334	.1143	.8573		.6097	.5716
16	.1143	.1143	.7621	.5906		.5716
17	.1334	.0381	.8002	.5716	.7621	.6097
18	.1905	.0381	.6668	.5716	.6478	.5525
19		.0381	.1143	.1143		
20	.1143	.0381	.0953	.1143	.0381	.0381
21	.1143	.0381	.1143	.1143	.0381	.0762
22	.0953	.0381	.0953	.1143	.0381	.0762
23	.0762	.0381	.0953	.1143	.0381	.0762
24	.381	.6668		.0953	.1143	.0381
Max	.4191	.9145	.8573	.9526	.7621	.7049
Min	.0762	.0381	.0953	.0953	.0381	.0381
Avg	.2402	.3074	.4458	.3131	.2555	.2419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 206 / 11 KV Vadgaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.3429	.3429	.3429	.3048	.3048	.2858
2	.3429	.3239	.3239	.3048	.2858	.3048	.2667
3	.3429	.3048	.3239	.3048	.2858	.3048	.2667
4	.3429	.3048	.3239	.3048	.2858	.3048	.2667
5	.4001	.3429	.3429	.3239	.3239	.3429	.2858
6	.4382	.381	.381	.362	.4001	.381	.3429
7	.4191	.4382	.381	.4001	.4382	.4001	.4001
8	.4191	.4191	.381	.4001	.4382	.4001	.4191
9	.4382	.4191	.381	.381	.4001	.381	.4001
10	.381	.4191	.362	.3048	.4382	.3239	.3429
11	.3239	.362	.3429	.2858	.3239	.3048	.2858
12	.362	.3239	.3429	.2858	.2667	.3048	.2667
13	.362	.3239	.3429	.2858	.3429	.2667	.2667
14	.362	.3239	.3239	.3048	.3048	.2667	.2477
15	.4001		.3239	.3048		.2858	.2858
16	.381	.3048		.2667	.3048	.2858	.3239
17	.362	.4763	.3429	.2667	.3429	.3048	.381
18	.362	.4763	.4001	.4572	.381	.4763	.4191
19		.5906	.5144	.5525	.6097	.5906	.5716
20	.724	.6478	.6668	.6097	.724	.6287	.724
21	.6097	.5335	.5716	.5525	.5906	.5716	.6478
22	.5525	.4763	.5335	.4763	.4572	.4572	.5525
23	.381	.4763	.4191	.4001	.381	.362	.4001
24	.4001	.3429	.3429	.362	.362	.3239	.3048
Max	.724	.6478	.6668	.6097	.724	.6287	.724
Min	.3239	.3048	.3239	.2667	.2667	.2667	.2477
Avg	.4117	.4067	.3918	.3683	.3910	.3699	.3731

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.2477	.2286	.2096	.2096	.2096
2	.2667	.2477	.2477	.2286	.1905	.2096	.2096
3	.2667	.2286	.2477	.2286	.1905	.2096	.2096
4	.2667	.2286	.2477	.2286	.1905	.2096	.2096
5	.3048	.2667	.2667	.2667	.2286	.2286	.2286
6	.362	.362	.3048	.2858	.2858	.2858	.2858
7	.362	.381	.3239	.3048	.3239	.3239	.3048
8	.362	.362	.2858	.2858	.3048	.3048	.3048
9	.2858	.3239	.2858	.2858	.2858	.2858	.2477
10	.3048	.3048	.3239	.2667	.2858	.2858	.2858
11	.3429	.3048	.3239	.1905	.3048	.2858	.2096
12	.3239	.3048	.2858	.1715	.2096	.2286	.2286
13	.3048	.2286	.1905	.2667	.2667	.2477	.2096
14	.3239	.3048	.1715		.2667	.2477	.2096
15	.3239	.2858	.2096	.3239	.2477	.2286	.2096
16	.3239	.2667		.2477	.2286	.2477	.2286
17		.2667	.2667	.2477	.2286	.2477	.3048
18		.3239	.3048	.2858	.2858	.362	.3048
19		.381	.4001	.362	.4382	.381	.4191
20	.4572	.4572	.4954	.4001	.4763	.4191	.4954
21	.4954	.4001	.4763	.4001	.4191	.362	.381
22	.4191	.381	.381	.3239	.3429	.3048	.3429
23	.3239	.3048	.3048	.2667	.2667	.2477	.2667
24	.3429	.2667	.2477	.2477	.2286	.2286	.2286
Max	.4954	.4572	.4954	.4001	.4763	.4191	.4954
Min	.2667	.2286	.1715	.1715	.1905	.2096	.2096
Avg	.3366	.3104	.2974	.2758	.2794	.2747	.2723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6478	.6478	.6668	.6097		.6097
2	.6859	.6097	.6478	.6478	.5716	.6097	.6097
3	.6859	.6097	.6478	.6287	.5716	.6097	.6097
4	.6859	.6097	.6478	.6287	.5716	.6097	.5906
5	.7049	.6478	.6668	.6478	.6287	.6478	.6287
6	.724	.724	.6859	.743	.724	.6859	.724
7	.6668	.6859	.6668	.724	.6668	.6668	.7049
8	.5716	.6097	.6097	.6097	.6097	.6478	.6287
9	.6668	.6097	.5716	.5906	.5716	.5906	.5716
10	.6668	.6668	.6287	.5906	.6097	.5906	.5906
11	.743	.724	.5906	.4572	.6478	.6097	.5525
12	.6478	.7049	.6097	.4954	.5716	.6097	.4763
13	.6859	.724		.6287	.5335	.6097	.4572
14	.7049	.724		.6097	.5525	.5716	.4763
15	.7049	.6859		.6478		.5906	.5144
16	.6859	.724		.5716	.6478	.4382	.5335
17	.724	.6097	.8192		.6097	.4763	.4572
18	.7621	.6859	.7621		.6668	.8192	.5906
19			.8002	.6478	.8573	.8192	.8192
20	1.086	.9907	1.0288	.9145	.9907	.9717	1.0479
21	1.0098	.8954	.9907	.8764	.8954	.9335	.9145
22	.9335	.8573	.8954	.7811	.8192	.7811	.8383
23	.7811	.724	.7811	.6859	.6859	.6668	.6859
24	.7621	.6668	.6668	.7049	.6478	.6287	.6287
Max	1.086	.9907	1.0288	.9145	.9907	.9717	1.0479
Min	.5716	.6097	.5716	.4572	.5335	.4382	.4572
Avg	.7397	.7016	.7183	.6590	.6635	.6602	.6359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 209 / 11 KV Madyal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.0762	.0381	.4382	.3239		.3048
2	.1334	.0572	.0381	.4382	.3239		.3048
3	.1334	.0572	.0381	.4191	.3239		.3048
4	.1334	.0572	.0381	.4382	.3239		.3048
5	.1334	.0762	.0381	.4382	.3239		.3048
6	.1524	.0762	.0381	.4572	.3429		.3048
7	.1715	.0762	.0381	.5525	.4382		.3048
8	.1715	.0762	.0953	.5525	.4191		.381
9	.1715	.0762	.0953	.4763	.4001		.362
10	.1334		.0762	.0953	.0762		.0381
11	1.448	.7621	.5525	.0762			.0381
12	1.4098	.703	.5658	.0762			.0381
13	1.3336	.7373	.5487	.0381	.0762		.0381
14	1.2765	.6859	.5144	.0381			.0381
15	1.2003	.6097	.5144	.0381	.0762	.4572	.0381
16	1.1622	.5335		.0381		.4191	.0381
17	.5144	.5525	.4763	.0381		.0381	.0381
18	.4954	.5144	.4763	.0381	.0381		.0381
19		.0381	.0762	.0762	.0381		.0381
20	.0762	.0381	.1143	.0762	.0381	.0381	.0381
21	.0762	.0381	.0953	.0762	.0191	.0381	.0381
22	.0762	.0381	.0953	.0762	.0191	.0381	.0381
23	.0762	.0381	.0953	.0762	.0191	.0381	.0381
24	.1334	.0762	.0381	.4001	.3239		.3048
Max	1.448	.7621	.5658	.5525	.4382	.4572	.381
Min	.0762	.0381	.0381	.0381	.0191	.0381	.0381
Avg	.4672	.2606	.2042	.2278	.2076	.1524	.1548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 201 / 11 Kv Sonage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0162		1.0059			
2	.0181	.0162	.0164	.9724		.57	
3	.0181	.0162		.9724			
4	.0181	.016		.9724		.503	
5	.0181	.0162	.0162	1.2239			
6	.0181	.0152		1.3748		.5365	
7	.0179	.0162	.0164	1.7436		.5365	
8	.0177	.0162	.0164	1.8107		.7545	
9	.0175	.0162	.0164	1.9113		.788	
10			.1402	.0983			.0162
11	2.5318	1.8107	2.5377		.0168		.0162
12	2.6513			.0972	.0168		.0162
13	2.7633	2.4813	2.572				.0162
14	2.7166	2.5484	2.838	.0983			.0162
15	2.726		2.5892				.0162
16	2.6513			.0983			.0162
17	2.1845	1.9418	2.1091	.0983			.0162
18	1.9185	1.4003					.0162
19	.0162						
20	.0162	.0164		.0179			.0162
21	.0162			.0175			.0162
22	.0162	.0164		.0179			
23	.0162	.0164		.0179			.0162
24	.0181	.0162	.0164	1.0059	.6335	.57	
Max	2.7633	2.5484	2.838	1.9113	.6335	.788	.0162
Min	.0162	.0152	.0162	.0175	.0168	.503	.0162
Avg	.8871	.5774	1.0737	.7134	.2224	.6084	.0162



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.086	.8573	.4572		.0181		.0181
2	1.0498	.823	.4251	.0168	.0181	.0168	.0181
3	1.0498	.823					.0181
4	1.0498	.8916		.0168		.0168	.0181
5	1.086	1.0174	.4435				.0181
6	1.1283	1.2548	.4805	.0168			.0181
7		1.7126	.9055		.0179	.0168	.0177
8	1.4529	1.5939	.9709	.0168	.0177	.0168	.0177
9	1.2094	1.4754	.7842	.0168	.0177	.0168	.0177
10			.0175	.0164		.0177	.0162
11	.0164	.0168	.0175	1.4377		1.4918	1.1831
12	.0162		.0175	2.4646	1.5424	1.5775	1.153
13				2.5206		1.4918	
14	.0164			2.4646	1.3916	1.4403	.8478
15				2.3712	1.2763	1.5089	.8309
16	.0164			2.2032	.9389	1.5604	
17	.0164			1.6991	.8718	1.4918	.8987
18	.0162			1.2757			.8402
19	.0162			.0177			
20	.0162	.0164		.0179			.0162
21	.0162			.0179		.0179	.0162
22	.0162	.0164		.0179		.0181	
23	.0162	.0164		.0179		.0181	.0162
24	1.086	.8573	.4572	.0168	.0181	.0168	.0181
Max	1.4529	1.7126	.9709	2.5206	1.5424	1.5775	1.1831
Min	.0162	.0164	.0175	.0164	.0177	.0168	.0162
Avg	.5189	.8123	.4524	.8322	.5571	.6315	.2999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 203 / 11 KV ARJUNNAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.2957		.2241		.2241
2	.2801	.2987	.2587	.2926	.2241	.2195	.2241
3	.2801	.2987			.2241		.2241
4	.2801	.3018		.2195	.2427	.2195	.2427
5	.2987	.3511	.2772		.2614		.2614
6	.3142	.2957	.2957	.2743	.2772	.2926	.2801
7	.2926	.2926	.2587		.2926	.2561	.2772
8	.2561	.2378	.2402	.2378	.2561	.2561	.2561
9	.2534	.2378	.2402	.2195	.2561	.2378	.2378
10	.2402		.2686	.2402		.2534	.2012
11	.2218	.2195	.2149	.2218		.2534	.2561
12	.2402		.2686	.2218	.2561	.2172	.2195
13	.2218			.2587	1.3916	.2507	
14	.2402			.2587	.2926	.2686	.2378
15	.2587			.2587	.2743	.2149	.1829
16	.2402			.2402	.2195	.2715	.1991
17	.2402	.2957		.4435		.2353	.2172
18	.2743	.2987		.2172			.2561
19	.3658	.3547		.3658			
20	.4344	.4294		.3475			.4066
21	.4344	.4066		.3658		.4066	.4024
22	.4207	.4108		.3326		.3696	.3475
23	.3696	.3696		.2957		.3142	.2957
24	.3361	.3547	.3142	.3475	.2614	.2378	.2427
Max	.4344	.4294	.3142	.4435	1.3916	.4066	.4066
Min	.2218	.2195	.2149	.2172	.2195	.2149	.1829
Avg	.2955	.3217	.2666	.2830	.3303	.2653	.2587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.4294	.4251	.4024	.3734		.3734
2	.4108	.4294	.4066		.3734	.3658	.3734
3	.4108	.4108		.3658	.3734		.3734
4	.4481	.4294		.3658	.4108	.3475	.4108
5	.5041		.4251	.439	.4481		.4854
6	.5788	.567	.5544	.5853	.5359	.5121	.6283
7	.5853	.5304	.5788	.5121	.6219	.5853	.5853
8	.567	.5121	.5601	.4527	.5487	.503	.6036
9	.5249	.0162	.5788	.4938	.567	.5304	.5304
10	.499		.4887	.4805		.5068	.4755
11	.5729	.5121		.4251		.4706	.4755
12	.5175			.4435	.5304	.5611	.4755
13	.5729	.5853	.4119	.462		.5373	.4755
14	.5175	.567	.5552	.4435	.4755	.4656	.439
15	.5175		.5373	.4251	.439	.4477	.4207
16	.5175				.4024	.4163	.1463
17	.3696			.4435	.439	.4887	.4207
18	.3841	.5788		.4706	.5304	.5487	.5487
19	.543	.6348		.6219		.6653	
20	.6697	.7095		.5487		.7392	.7207
21	.6447	.6722		.5121		.6283	.6653
22	.5487	.5975		.499		.5544	.4572
23	.5041	.5175		.462		.4251	.462
24	.4668	.4481	.4435	.4207	.4294	.4024	.4108
Max	.6697	.7095	.5788	.6219	.6219	.7392	.7207
Min	.3696	.0162	.4066	.3658	.3734	.3475	.1463
Avg	.5119	.5082	.4971	.4671	.4687	.5096	.4764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 205 / 11 KV Banage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	1.2346	1.4003	.1006	.1086		.0724
2	.724	1.2003	1.4003	.1006	.1086	.0838	.0724
3	.724	1.2003		.1006	.1086		.0724
4	.7602	1.3032		.1006	.1086	.0838	.0724
5	.8688	1.4403	1.4563	.1006	.1086		.0724
6	.9231	1.6118	1.531	.1006	.1086	.0838	.0724
7	1.2894	2.0058	1.8111		.1075	.0838	.0724
8	1.4175	1.989	1.9791		.1063	.0838	.0709
9	1.3321	1.8861	1.9978		.1063	.0838	.0709
10	.1638					.0895	
11		.1509		2.9313		1.6289	.9362
12				3.1927	1.8442	1.6289	.8916
13				3.0994	1.8442	1.6461	.8573
14				3.0994	1.7604	1.6289	.7545
15				2.894	1.4251	1.5604	.6859
16				2.7073	1.1736	1.4918	.7545
17				2.3525	1.0898	1.3203	.6859
18				2.0058		1.1393	.4458
19						.0895	
20		.1147		.1254		.0895	.0648
21		.1147		.1075		.0895	.0678
22		.1147		.1075		.0905	
23		.1147		.1075		.0905	.0655
24	.7602	1.2483	1.3443	.1006	.1086	.0838	.0724
Max	1.4175	2.0058	1.9978	3.1927	1.8442	1.6461	.9362
Min	.1638	.1147	1.3443	.1006	.1063	.0838	.0648
Avg	.8806	1.0486	1.6150	1.2334	.6386	.6272	.3300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 206 / CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.081	.0328		.6878		.3982
2	.0543	.081	.0328	1.0059	.6878	.4694	.362
3	.0543	.081			.6697		.362
4		.0819		1.0395	.6335	.503	.362
5	.0724	.081	.0328		.6154		.3439
6		.081		1.2071	.6154	.5365	.394
7	.1075	.081	.0492		.8417	.5365	.4835
8	.0716	.081	.0492	1.5424	.8764	.6036	.5316
9	.0701	.081	.0164	1.4251	.8589	.7042	.5493
10			.0351	.0492		.0709	.0162
11	1.8298	1.6095	1.5947			.0701	.0162
12	1.8298	1.7101	1.6118	.0648	.0503	.0701	.0162
13	1.6804	1.6766	1.4575			.0701	
14	1.7177	1.576	1.4746	.0164		.0701	.0162
15	1.643		1.4232			.0701	.0162
16	1.531			.0164		.0175	.0162
17	1.251	1.1203		.0162		.0175	.0162
18	1.1022	.9709		.0177			.0162
19	.0648			.0177			
20	.0648	.0328		.0177			.0162
21	.0655			.0537			.0162
22	.0648	.0328		.0537		.0181	
23	.0648	.0328		.0537		.0181	.0162
24	.0543	.081	.0328	1.073	.7059	.503	.3982
Max	1.8298	1.7101	1.6118	1.5424	.8764	.7042	.5493
Min	.0543	.0328	.0164	.0162	.0503	.0175	.0162
Avg	.6404	.5038	.6033	.4512	.6584	.2558	.2078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 201 / 11 KV MURGUD Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2	.4458	.1543	.1715		.0876		
4	.4287	.1372	.2229		.0876		
6	.8059	.2401	.3429		.0876		
7							.0753
8	.8745	.3258	.4287		.0876		
9			.4049				
10				.0701			
11					.9069	.301	.1619
12				.583	.9717		.1943
13					.9717		.1619
14				.6859	.8421		.1619
15					.7125		.2267
16				.6859	.4696		.1943
17					.3887		.1943
18	.0876			.5316	.3563		.1457
20	.0526			.0876			
22	.0526			.0876			
23					.0762		.0648
24	.463	.1715	.2058		.0876		
Max	.8745	.3258	.4287	.6859	.9717	.301	.2267
Min	.0526	.1372	.1715	.0701	.0762	.301	.0648
Avg	.4013	.2058	.2961	.3902	.4381	.301	.1581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 208 / 11 KV Murgud VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.7023		.6653	
2	.6516	.5611	.583	.7023	.5068	.6283	
3				.6653		.6283	.5426
4	.5973	.4887	.6173	.6653	.4887	.6283	
5				.7023		.6653	
6	.6878	.6154	.6859	.7468	.5792	.7023	.5087
7				.6348		.6653	.5426
8	.6485	.5784	.6001	.6348	.631	.6722	.5975
9			.6154		.6348		.5975
10		.6687	.6878	.6135	.7095		.6348
11			.6584		.7392		.4435
12		.703	.695	.631	.7392		.7023
13	.6859		.7023		.7762		.5914
14		.7202	.6653	.7011	.7392		.5914
15			.695		.7023		.6219
16	.583		.5853	.6661			.6722
17			.6283		.6722		.6348
18	.6516	.7716	.7468	.7011	.724		.7023
19			.8589		.8131		.7842
20	.8688		1.0082	.724	.9335		.9335
21			.9335		.8589		.8215
22	.724		.8589	.6878	.8215		.7468
23			.7468		.7095		.6722
24	.7059	.6516	.6516	.7023	.5973	.6653	.5765
Max	.8688	.7716	1.0082	.7468	.9335	.7023	.9335
Min	.583	.4887	.583	.6135	.4887	.6283	.4435
Avg	.6804	.6399	.7112	.6801	.7040	.6578	.6459

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 201 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0389	.0509	.4049	.3944	.2543	.1715
2	.0457	.0389	.0509	.3887	.3944	.2374	
3	.0457	.0389	.0509	.3887	.3944	.2374	
4	.0457	.0389	.0509	.4049	.3944	.2543	
5	.0457	.0389	.0509	.4696	.4458	.2713	
6	.061	.0389	.0509	.583	.5658	.2883	
7	.061		.0509	.8097	.823	.3561	.1524
8	.061		.0509	1.0526	.9431	.3391	.2058
9	.061		.0509	.9231	.7202		.1067
10	.0442		.0509	.061	.0509	.017	.04
11	1.2689	1.3056	1.3889	.0514	.0509	.04	.0267
12		1.4074	1.6804	.0686	.0509	.04	.0221
13	1.3375	1.6278	1.6461	.0686	.0509	.04	.0111
14	.6173		1.4746	.0686	.0509	.04	.0332
15	.6173	1.3735	1.4746	.0686	.0339	.04	.0332
16	.9945			.0686	.0339	.04	.0332
17		.8309	.9717	.0305	.0509	.04	.0332
18	.6859	.763	.8907	.0857	.0509	.0457	.0389
19	.0442	.0509	.0686	.0686	.0509	.0762	.0442
20	.0389	.0509	.061	.0686	.0678	.061	.0518
21	.0648	.0509	.061	.061	.0509	.0762	.0442
22	.0518	.0509	.061	.0762	.0509	.0857	.0442
23	.0518	.0509	.061	.061	.0509	.0857	.0442
24	.061	.0389	.0509	.4696	.4115	.2543	.1715
Max	1.3375	1.6278	1.6804	1.0526	.9431	.3561	.2058
Min	.0389	.0389	.0509	.0305	.0339	.017	.0111
Avg	.2894	.4353	.4522	.2834	.2576	.14	.0688



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 202 / Sonali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6539	1.3032		.0914	.0442	.0509	.0286
2	.5868	1.286		.0762	.0442	.0509	.0286
3	.5506	1.286		.0762	.0457	.0509	.0286
4	.5668	1.286		.0762	.0518	.0509	.0286
5	.5992	1.5775		.0762	.0518	.0509	.0286
6	.7287	1.7147		.0762	.0518	.0474	.0286
7	1.2039	1.8519		.0914	.0518	.0509	.0286
8	1.4575	2.1434		.0762	.0457	.0509	.0343
9	1.4746			.1067	.0648	.0509	.0343
10	.0777	.0884		.1067	.0848	.0509	.0343
11	.1036	.1357		2.5339	1.7804	.6874	.5316
12	.1036	.1357		2.7149	1.8821	.7712	.5144
13		.1357	.0914	2.5892	1.8482	.788	.5487
14		.1526	.0914	2.452	1.7804	.7377	.5658
15			.0914	2.5892	1.6108	.7545	.5144
16				2.572	1.1191	.8573	.4801
17	.0553		.0914	2.2805		.8745	.4458
18	.0884		.0914	1.7661	.8478	.7545	.3429
19	.1219		.12	.0762	.0509	.061	.0332
20	.1174	.0509	.12	.061	.0509	.0457	.0332
21	.1067	.0509	.12	.061	.0509	.0533	
22	.0892	.0509	.0914	.061	.0509	.04	.0332
23	.0857	.0339	.8259	.061	.0509	.04	.0332
24	.663	1.2689		.8048	.061	.0509	.0286
Max	1.4746	2.1434	.8259	2.7149	1.8821	.8745	.5658
Min	.0553	.0339	.0914	.061	.0442	.04	.0286
Avg	.4717	.8085	.1734	.8948	.5096	.2926	.1917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 203 / Sawarde VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.6154	.6104	.6859	.5973	.5087	.6097
2	.724	.5973	.6104	.6859	.5973	.4917	.6097
3	.724	.5973	.5335	.6859	.6036	.4748	.5906
4	.724	.5973	.5935	.6859	.5973	.4917	.5906
5	.743	.6516	.6274	.724	.6516	.6274	.6097
6	.811	.7499	.6443	.7655	.724	.6613	.679
7	.7655	.6878	.6613	.7577	.7059	.6443	.7468
8	.7023	.6697	.6613	.7392	.6584	.5935	.7095
9	.7682	.7059	.5765	.7095	.6335	.5596	.5041
10	.724	.6878	.5935	.6468	.5935	.5426	.5788
11	.695	.6783	.6219	.5611	.5935	1.5154	.5914
12	.4887	.6613	.6697	.5658	.5765	.6584	.5792
13	.6697	.6613	.6584	.5249	.5596	1.2382	.3801
14	.5973	.6443	.6036	.5611	.5765	.5853	.4525
15	.5611	.5426	.6036	.5068	.4694	.6099	.4887
16	.5973	.5087		.5249	.4409	.5175	.4525
17		.5596	.6401	.4344	.5087	.5914	.5249
18	.6878	.6952	.6344	.5973	.5935	.6653	.5973
19	.8507	.8478	.9055	.8145	.8309	.8589	.8688
20	1.0136	1.0343	1.1273	.7602	.9156	.9896	.9774
21	.9145	.9326	1.0534	.7602	.8478	.9335	.9231
22	.8145	.8309	.9709	.6697	.7291	.8383	.7783
23	.7059	.7122	.7842	.6154	.5765	.6859	.6516
24	.7811	.6516	.6274	.724	.6036	.5256	.6287
Max	1.0136	1.0343	1.1273	.8145	.9156	1.5154	.9774
Min	.4887	.5087	.5335	.4344	.4409	.4748	.3801
Avg	.7307	.6884	.6962	.6544	.6327	.7004	.6301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 204 / MALAGE AGRICULTURAL  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0111	.017	.3887	.3429	.1017	.0857
2	.0514	.0111	.017	.3887	.3258	.0848	.0762
3	.0343	.0111	.017	.3887	.3086	.1017	.0762
4	.0152	.0111	.017	.4049	.3086	.1017	.0762
5	.0152	.0111	.017	.4372	.3944	.1187	.0762
6	.0152	.0111	.0152	.583	.5487	.1187	.1067
7	.0305	.013	.017	.9069	.7888	.0189	.1829
8	.0457	.0111	.017	1.0526	.9431	.2883	.2401
9	.0457		.017	.8259	.8745	.2543	.2229
10	.0553	.0111	.017	.0305	.0339	.017	.0133
11	1.2003	1.17	1.406	.0221	.017	.0133	.0133
12	1.3203	1.4074	1.5775	.0389	.017		.0111
13	1.5089	1.4582	1.5089	.0389	.0339	.0152	.0111
14	1.4403	1.4074	1.4746	.0259	.0339	.0152	.0111
15	1.3717	1.3226	1.4403	.0259	.0339	.0152	.0111
16	1.3717	.9156		.0305	.017	.0152	.0389
17	.8745	.78	1.1012	.0457	.017	.0152	.0259
18	.7716	.7291	.9231	.0457	.017	.0152	.0111
19	.0152	.017	.0152	.0457	.017	.0152	
20	.0152	.017	.0152	.0457	.017	.0152	
21	.0152	.017	.0152	.0457	.017	.0152	
22	.0152	.0152	.0152	.0305	.017	.0152	.0111
23	.0152	.017	.0152	.0457	.017	.0152	.0111
24	.0514	.0111	.0152	.4049	.3429	.1017	.0857
Max	1.5089	1.4582	1.5775	1.0526	.9431	.2883	.2401
Min	.0152	.0111	.0152	.0221	.017	.0133	.0111
Avg	.4311	.4081	.4213	.2625	.2285	.0647	.0666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 148020 / 220/33KV Hamidwada S.St.

Feeder No / Name : 401 / 33KV Hamidwada

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1017
Max	.1017
Min	.1017
Avg	.1017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 148020 / 220/33KV Hamidwada S.St.

Feeder No / Name : 405 / SHRI DUTT INDIA INDUSTRIAL NON SHEDDABLE EXPRESS HV FEEDERS  
EXP Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1526
Max	.1526
Min	.1526
Avg	.1526

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 202 / 11KV SHELEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18
HR	Load (MW)
24	2.2634
Max	2.2634
Min	2.2634
Avg	2.2634

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 203 / 11 KV THIKPURLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584		.567	.6219			.4961
2	.6401	.6219	.543	.6219	.5068	.5228	.4835
3	.6584		.5258	.6036	.543	.5359	.4784
4	.695		.5959	.6219	.5792	.5359	.5316
5	.7865	.7316	.6661	.7133	.6878		.6516
6	.9425	.8962	.7265	.8779	.8326	.8589	.823
7	.8413	.7865	.6626	.7682	.7602		.8682
8	.7316	.7499	.5258	.695	.7059		.7186
9	.695	.7011	.5083	.6767		.6653	.6767
10	.6219	.695	.5304	.3475	.6283	.6838	.6219
11	.695	.5959	.7499		.6468	.5611	.1463
12	.6219	.6201	.6767			.5434	.3658
13	.6219	.5959	.695		.5975	.5847	.4207
14	.6219		.695			.6556	.6036
15	.6219	.695	.7133		.5359	.6401	.4572
16			.6584			.6767	.5853
17	.823		.6401			.6379	.6767
18	.7865	.2561	.7133	.6878		.631	.695
19	.8779	.3012	.823	.6516	.7468	.6836	.8048
20		.5792	.8596			.8063	.8596
21	.8413	.5959	.8413			.7265	.823
22	.7865	.6219	.695		.7023	.691	.7133
23		.6401	.6584	.5792		.5609	.5853
24	.6584	.6219	.6036	.6584	.543	.5601	.5083
Max	.9425	.8962	.8596	.8779	.8326	.8589	.8682
Min	.6219	.2561	.5083	.3475	.5068	.5228	.1463
Avg	.7251	.6281	.6614	.6518	.6440	.6381	.6081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 204 / 11 KV ARJUNWADA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)
24	2.4006	2.0576
Max	2.4006	2.0576
Min	2.4006	2.0576
Avg	2.4006	2.0576



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 205 / 11 Kv Gahininath Ag LIS  
Expres Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	01-JUN-18	02-JUN-18
HR	Load (MW)	Load (MW)
9	.0579	.0876
10	.0781	.0876
11	.0781	.0876
12		.0876
13	.0772	.0914
14	.0926	
15	.0926	.0876
17		.0914
18		.0914
Max	.0926	.0914
Min	.0579	.0876
Avg	.0794	.0890

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 201 / 11 KV DHAMOD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0526	
2						.0526	
3		.0191				.0526	.052
4						.0526	
5						.0526	
6	.0175				.0526	.1052	
7	.0175	.0191			.1402	.1227	.1214
8	.0175		.0191		.124	.1578	.1214
9		.0191				.1578	.0191
10	.0191			.0177	.0177		.0191
11	1.3176	1.2715		.0177	.0177	.0191	
12				.0177			.0191
13	1.543	1.3253		.0177			
14				.0177		.0191	.0191
15		1.1641		.0177			
16				.0177			.0191
17				.0177		.0191	
18				.0177		.0191	
19		.0191			.0177		.0191
20		.0191		.0177	.0177	.0191	
21	.0191	.0191		.0177	.0177		
22				.0177	.0177	.0191	
23				.0701	.0175		
24		.0191	.0191			.0701	.052
Max	1.543	1.3253	.0191	.0701	.1402	.1578	.1214
Min	.0175	.0191	.0191	.0177	.0175	.0191	.0191
Avg	.4216	.3895	.0191	.0217	.0441	.0620	.0461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 202 / 11 KV KELOSHI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.0175	
2						.0175	
3						.0175	.0191
4						.0175	
5						.0175	
6	1.1269				.0175	.0177	
7	1.387	.1907			.0175	.0175	.0191
8	1.335		.1075		.0175	.0175	.0191
9		.1907				.0175	.0191
10	.0191			.0175	.0175		.0191
11	.0173	.0191		.1052	.0526	.0381	
12					.0526		.0358
13	.0191	.0191					
14							.0716
15		.0191		.0876			
16				.1578			.0537
17	.0191			.1227		.0693	
18				.0876		.0693	
19					.0177		.0191
20		.0191		.0175	.0177	.0191	
21	.0191	.0191		.0175	.0177		
22		.0191		.0175	.0177	.0191	
23				.0175	.0177		
24	.8842	.0867	.0358		.0175	.0175	.0191
Max	1.387	.1907	.1075	.1578	.0526	.0693	.0716
Min	.0173	.0191	.0358	.0175	.0175	.0175	.0191
Avg	.5363	.0647	.0717	.0648	.0234	.0260	.0295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI

GAOTHAN FEEDER

VILLAGE Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.1402	
2						.1402	
3		.156				.1402	.1387
4						.1402	
5						.1753	
6	.2743				.2572	.2454	
7	.2743	.2947			.3121	.2629	.2947
8	.2572		.2865		.2947	.2454	.2947
9	.2601	.2774				.2279	.2774
10	.2601			.2774	.2601		.2947
11	.2254	.2507		.208	.2279	.156	
12				.1734			.197
13	.208	.197		.1214			
14				.0876		.1214	.197
15		.197		.1578			
16				.156			.197
17	.3121			.156		.2254	
18				.1907		.2601	
19		.2865			.3506		.3582
20		.4119		.3121	.3506	.3641	
21	.3814	.3045			.2804		
22		.2507		.208	.1928	.2601	
23				.1734	.1578		
24	.1734	.156	.1433		.1387	.1402	.1387
Max	.3814	.4119	.2865	.3121	.3506	.3641	.3582
Min	.1734	.156	.1433	.0876	.1387	.1214	.1387
Avg	.2626	.2529	.2149	.1852	.2566	.2028	.2388

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 204 / 11 KV BURAMBALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.0175	
2				.0175	
3				.0175	.052
4				.0175	
5				.0175	
6				.0175	
7				.0876	.1387
8					.1734
9				.1578	.1387
10			.0175		
11	1.387	.8417			
13	1.595	1.1462			
15		.8954			
17	.7802				
24				.0175	.0173
Max	1.595	1.1462	.0175	.1578	.1734
Min	.7802	.8417	.0175	.0175	.0173
Avg	1.2541	.9611	.0175	.0409	.1040

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 201 / 11KV TARALE AG (TARLE)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736	.5144	.4748				
2	1.1736	.4748	.4748				
3	1.1736	.4801	.4748				
4	1.1736	.5533	.5365				
5	1.3413	.7291	.7545				
6	1.4754	.8402	.8048				
7	1.7436	1.4083	1.0395				
8	1.7635	1.5947	1.3413				
9		1.6956	1.1401				
11				1.6575	1.1568	.0492	
12				1.6766	1.2763	.1341	.1326
13				1.7436	1.0898	.0838	.1658
14				1.8107	1.3094	.1006	.1658
15				1.8991	1.1437	.1006	.1492
16				1.8652		.0838	.1492
17				1.5424	.0335	.0671	.1492
18				1.3413	.0335	.0335	.1658
23							.0497
24	1.1869	.5087	.4409				
Max	1.7635	1.6956	1.3413	1.8991	1.3094	.1341	.1658
Min	1.1736	.4748	.4409	1.3413	.0335	.0335	.0497
Avg	1.3561	.8799	.7482	1.6921	.8633	.0816	.1409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 202 / 11 KV TARALE

GAOTHAN FEEDER

VILLAGE(TARLE) Feeder KV- 11  
/ OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.2801	.2534	.2896	.2896	.2195	.2507
2	.3511	.2587	.2534	.2896	.2896	.2195	.2328
3	.3326	.2587	.2534	.2896	.2865	.2195	.2402
4	.3326	.2801	.2926	.3077	.2865	.2402	.2353
5	.3696	.3174	.3475	.3292	.3734	.3142	.2715
6	.5228	.3772	.4024	.3841	.4715	.3921	.3109
7	.5041	.3921	.4024	.4024	.3734	.4108	.3475
8	.4066	.3841	.3475	.3658	.3511	.3511	.3658
9	.3881	.4294	.2926	.3292	.3292	.3734	.4024
10	.1867	.3881	.3658	.3292	.3439	.3439	.3475
11	.1991	.4066	.3292	.3292	.3721	.3582	.3658
12	.2149	.3292	.3292	.2926	.333	.3403	.3475
13	.4066	.4207	.3292	.3045	.333	.3403	.3292
14	.4119	.4024	.3292	.3224	.3012	.3224	.3292
15	.4298		.3475	.3224	.2454	.3224	.3292
16	.3326	.4024	.3475	.3189		.3439	.3292
17	.4161	.3475	.3658	.3045	.298	.3658	.3475
18	.4119	.4024	.4572	.362	.3045	.4024	.3658
19	.4706	.439	.4938	.4805	.3547	.439	.4207
20	.5359	.4755	.4755	.4805	.4481	.4572	.4938
21	.5175	.439	.439	.4435	.3881	.439	.4755
22	.3174	.4024	.4024	.3361	.2987	.4024	.439
23	.2987	.3292	.3258	.2957	.2587	.3077	.3258
24	.3696	.2801	.2926	.2896	.2926	.2402	.2686
Max	.5359	.4755	.4938	.4805	.4715	.4572	.4938
Min	.1867	.2587	.2534	.2896	.2454	.2195	.2328
Avg	.3790	.3671	.3531	.3416	.3314	.3402	.3405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 201 / 11 KV SHIRGAON AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	02-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.0663		
2	.12	.0663		
3	.12	.0671		
4	.12	.1006		
5	.1696	.1677		
6	.2743	.2683		
7	.3052	.3018		
8	.3391	.3353		
9	.3353	.3521		
11			.0335	.0158
12				.0158
13			.032	.0156
14				.0154
15				.016
16				.0158
17			.0164	.0158
18			.0164	.0158
24	.116	.0671		
Max	.3391	.3521	.0335	.016
Min	.116	.0663	.0164	.0154
Avg	.2020	.1793	.0246	.0158



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 202 / 11 KV PARITE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18
HR	Load (MW)
24	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
11		2.2405
24	2.6139	
Max	2.6139	2.2405
Min	2.6139	2.2405
Avg	2.6139	2.2405

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 205 / 11 KV AWALI VG

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18
HR	Load (MW)
24	.1867
Max	.1867
Min	.1867
Avg	.1867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 206 / 11KV KANTHEWADI AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2622	.1802			
2	.2622	.1781			
3	.2622	.1966			
4	.2949	.2458			
5	.3277	.2818			
6	.4588	.3315			
7	.5079	.426			
8	.6062	.5243			
9	.5735	.5365			
11			.2347	.0937	.0949
12				.0972	.1147
13			.2881	.1311	.1107
14				.1107	.128
15				.112	.1107
16				.0949	.0617
17			.0492	.1107	.0474
18			.0492	.0633	
24	.2486	.1802			
Max	.6062	.5365	.2881	.1311	.128
Min	.2486	.1781	.0492	.0633	.0474
Avg	.3804	.3081	.1553	.1017	.0954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 207 / 11 KV SHIRGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3881	.3292	.3326		.3326	.3292
2	.3772	.3658	.3292	.3326		.3142	.3142
3	.3772	.3292	.3326	.3109	.1132	.2926	.3174
4	.4108	.3696	.3658	.3658	.1886	.3292	.3326
5	.4668	.4251	.4066	.439	.1886	.4024	.4024
6	.6036	.5175	.4755	.6099	.2452	.6468	.6099
7	.5729	.5175	.5304	.5729	.2263	.6099	.543
8	.4938	.4435	.4435	.4755		.4938	.439
9	.3898	.4207	.3841	.2743		.4024	.4344
10	.4119		.439	.2195		.3475	.4207
11	.4207		.3658	.1829	.394	.3439	.3582
12	.4024		.3658	.3292		.362	.394
13	.124		.3658	.3475	.394	.3658	.4119
14	.3658		.3658			.362	.3761
15	.3881		.3841			.362	.3544
16			.439			.3881	.3988
17	.4805		.439		.5552	.4572	.4334
18	.499		.439		.5304	.5359	.4835
19	.5914		.5729		.6161	.6348	.6653
20	.6535		.6335			.6283	.6283
21	.5601		.6036		.6161	.5359	.6099
22	.5228		.4805		.5041	.439	.5041
23	.4294		.4251		.4108	.4066	.4108
24	.3772	.3921	.362	.362	.3395	.3547	.3326
Max	.6535	.5175	.6335	.6099	.6161	.6468	.6653
Min	.124	.3292	.3292	.1829	.1132	.2926	.3142
Avg	.4477	.4169	.4282	.3682	.3802	.4312	.4377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144028 / 33/11KV HASANE SUB-STATION

Feeder No / Name : 201 / 11KV DIGAS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	03-JUN-18
HR	Load (MW)	Load (MW)
11		.1886
24	.1867	
Max	.1867	.1886
Min	.1867	.1886
Avg	.1867	.1886

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 201 / 11 KV SOLANKUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6201	.3258					
2		.3258					
3		.3258					
4		.3258					
5		.3429					
6		.6344					
7		1.2174					
8		1.4746					
9			.0532				
11				.7087	.9313		.12
12				.7973	.9492	.0343	.12
13					1.0745	.12	.1372
14					.929	.1543	.1372
15					.2481	.12	.1029
16						.12	.12
17					.0526	.12	.1029
18					.0351		.0686
24	.6379	.3258					
Max	.6379	1.4746	.0532	.7973	1.0745	.1543	.1372
Min	.6201	.3258	.0532	.7087	.0351	.0343	.0686
Avg	.629	.5887	.0532	.753	.6028	.1114	.1136

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 202 / 11KV KALAMMAWADI

FEEDER SEPERATION/PURE AG

AG(SOLANKUR) Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.0857	
2				.0739	.0857	
3					.0857	
4				.0747	.0857	
5					.0857	
6				.0934	.0857	
7				.2033	.1715	
8				.3142	.1886	.0351
9				.2587	.1715	.0351
11	.8859	.7888	.4115			
12	.9391	.7202	.4458			
13	.8939	.7545	.4481			
14	.8238	.7202				
15	.815					
16	.6485		.2534			
17	.5658	.2743	.2534			
18		.2658	.2172			
24				.0739	.0857	
Max	.9391	.7888	.4481	.3142	.1886	.0351
Min	.5658	.2658	.2172	.0739	.0857	.0351
Avg	.796	.5873	.3382	.1560	.1132	.0351



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 203 / 11KV SOLANKUR VILLEGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6733	.5487	.5847		.5487		
2		.5144	.5609	.6535	.5487	.5258	.5975
3		.4801	.5609		.5487	.5434	
4		.4801	.5959	.6722	.583	.5784	.6348
5		.6173	.7087		.6516	.6135	
6		.7888	.8238	.8402	.7202	.7362	.8131
7		.7202	.8063	.8215	.7202	.7888	
8		.6859	.7186	.7842	.6516	.7087	.8215
9			.6836	.7023	.6001	.6733	.7468
10	.7442	.6859	.7545	.6485	.7023	.6516	.7202
11	.7796	.6859	.6859	.6485	.6653		.7202
12	.7087	.6516	.6859	.4908	.6283	.6516	.6516
13	.7442	.6859		.5959	.6653	.6173	.6173
14	.7973	.6859		.5609	.631	.6859	.5487
15	.7796			.5784	.7011	.6516	.6173
16	.7537		.7023	.6135		.6516	.7202
17	.6859	.7888	.8131	.7442	.7362	.7202	.6859
18		.8859	.7392	.7545	.7011	.9979	.7545
19	.9259	.9745	.9979	.8916	.8413		.9259
20	1.0974	1.0454	1.1827	.7888	.964		1.0288
21	.9602	.9465	1.1203	.7888	.929	.961	.9602
22	.8573	.8682		.6516	.8063	.8501	.7202
23	.6859	.6733		.5487	.6135		.5487
24	.6733	.6516	.5847	.6653	.5487	.5493	.6535
Max	1.0974	1.0454	1.1827	.8916	.964	.9979	1.0288
Min	.6733	.4801	.5609	.4908	.5487	.5258	.5487
Avg	.7911	.7174	.7532	.6878	.6829	.6924	.7243

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 204 / 11KV AAINI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2303	.1715	.1402	.2241	.1715	.1578	
2		.1372	.1402	.2033	.1543	.1578	.2241
3		.1372	.1402		.1543	.1578	
4		.1715	.1578	.2054	.1715	.1753	.2241
5		.2058	.1753	.2054	.2058	.1753	
6		.2401	.2103	.2241	.2401	.2279	.2614
7		.2058	.2279	.2241	.2401	.2454	
8		.2401	.2103	.2614	.2058	.2629	.2801
9			.2103	.2587	.2401	.2629	.2987
10	.1417	.2743	.2058	.3898	.2241	.3086	.2743
11	.1417	.2058		.2454	.2402		.2058
12	.1949	.1715		.1402	.1478	.2743	.2058
13	.2454	.2058		.1227	.1663	.2743	.2401
14	.333			.1578	.1227	.2401	.1715
15	.2103			.1753	.2454	.2401	.2401
16	.298		.2218	.1578		.2743	.2401
17	.2743	.2743	.2218	.2835	.2629	.2401	.2401
18		.3366	.2957	.3086	.3155	.3326	.2401
19	.3086	.3544	.3326	.4115	.2804		.3086
20	.3429	.2835	.4108	.3086	.3856		.3429
21	.3086	.3189	.3326	.2743	.3506	.3326	.3429
22	.2743	.2103		.2058	.2804	.2587	.2743
23	.2058	.2126		.2058	.2454		.2058
24	.2303	.1715	.1402	.2218	.1886	.1753	
Max	.3429	.3544	.4108	.4115	.3856	.3326	.3429
Min	.1417	.1372	.1402	.1227	.1227	.1578	.1715
Avg	.2493	.2264	.2220	.2355	.2278	.2387	.2537

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 201 / 11 KV KALAMMAVADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3326	.2587	.3142	.3511	.2957	.2957
2	.3511	.3142	.2402	.3142	.3326	.2957	.2957
3	.3511	.3142	.2402	.3142	.3326	.2957	.2957
4	.3511	.3142	.2587	.3142	.3326	.2957	.2957
5	.3511	.3326	.2801	.3142	.3326	.3142	.3326
6	.4251	.4066	.3142	.3326	.3696	.4066	.4066
7	.4251	.4251	.3511	.3881	.3881	.4066	.4251
8	.4066	.4251	.3696	.4066	.4251	.4251	.4066
9	.4435	.4251	.4066	.3881	.462	.4435	
10	.462	.4435	.3881	.3696	.4251	.4251	
11	.5359	.4805	.499	.3696	.462	.4435	
12	.5175	.4251	.499	.4066	.4435	.4066	
13	.4805	.4435	.5041	.3696	.4805	.4435	
14	.4805	.4805	.4435	.3696	.4435	.4251	
15	.4251		.4435	.3696	.4805	.4435	
16	.3511		.3881	.3511		.4251	
17	.3696	.4435	.3881	.4066	.4805	.5175	
18		.4066	.4251	.462	.4805	.4435	
19	.6099	.4435	.462	.499	.4805	.5359	
20	.6283	.4805	.5729	.499	.4805	.5175	
21	.5914	.462	.5729	.4805	.4854	.4805	
22	.499	.3881	.4435		.3881	.3881	
23	.6895	.3511	.3881	.3881	.3326	.3511	
24	.3696	.3511	.2587	.3326	.3511	.2957	.3142
Max	.6895	.4805	.5729	.499	.4854	.5359	.4251
Min	.3511	.3142	.2402	.3142	.3326	.2957	.2957
Avg	.4550	.4041	.3915	.3809	.4148	.4050	.3409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 202 / 11 KV KUDUTRI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.112	.112	.112	.0747	.0934	.1307
2	.1307	.112	.112	.0934	.0747	.0934	.1307
3	.1307	.112	.112	.0934	.056	.0934	.112
4	.1307	.112	.112	.0934	.056	.0934	.112
5	.1307	.1307	.1307	.0934	.056	.0934	.1307
6	.1494	.1848	.1867	.1307	.0934	.1494	.1867
7	.1494	.168	.1867	.1307	.112	.168	.168
8	.1867	.1867	.1867	.1494	.112	.1494	.168
9	.1867	.2241	.2054	.112	.1494	.168	
10	.1867	.1867	.1848		.112		
11	.2054	.2054	.2054	.0934		.168	
12	.168	.1867	.2054	.112	.1867	.1307	
13	.168	.1494	.112	.168	.112	.2241	
14	.168	.168	.2054	.1307	.1307	.1867	
15	.168		.1494	.1307		.2054	
16	.1307		.0747	.112			
17	.168	.1867	.0747	.112	.0373	.2054	
18		.2054	.1494	.168	.1307	.2241	
19	.2614	.2241	.2054	.2054	.168	.3174	
20	.2987	.2614	.2801	.1307	.2427	.2987	
21	.2614	.2427	.2614	.1494	.2427	.2801	
22	.2241	.2241	.2054	.112	.2054	.2054	
23	.1494	.1494	.1307	.0934	.1307	.1307	.0857
24	.3879	.112	.112	.112	.0934	.0934	.1307
Max	.3879	.2614	.2801	.2054	.2427	.3174	.1867
Min	.1307	.112	.0747	.0934	.0373	.0934	.0857
Avg	.1857	.1747	.1625	.1234	.1227	.1715	.1355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 203 / Fejiwade Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4359			.1311	.0503	
2	.4359			.1311	.0509	
3	.4527			.1311	.0509	
4	.4527			.1311	.0509	
5	.4694			.1311	.0509	
6				.1966	.0509	.0335
7				.2458	.0509	.0335
8				.2458	.0509	.0335
9	.5596				.0671	
11	.6443	.6706	.0339			
12	.7461	.7042	.0848			
13	.763	.7377	.2058			
14	.763	.7209	.3429			
15	.7122		.2572			
16	.5596		.2743			
17	.5256		.2401			
18			.2058			
24	.4359			.1475	.0503	
Max	.763	.7377	.3429	.2458	.0671	.0335
Min	.4359	.6706	.0339	.1311	.0503	.0335
Avg	.5683	.7084	.2056	.1657	.0524	.0335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 204 / 11 KV PIRAL AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4807	.1006		
2		.4807	.1006		
3		.4807	.1006		
4		.4973	.1006		
5		.5967	.1006		
6		.7459	.1006		
7		1.1271	.4359		
8		1.2929	.7209		
9		1.1105	.6706	.1326	
11				.7956	
12				1.0111	1.1065
13				1.1271	1.1568
14				1.0608	.9892
15				1.1105	
16				1.0277	
24	2.2405	.4807	.0838		
Max	2.2405	1.2929	.7209	1.1271	1.1568
Min	2.2405	.4807	.0838	.1326	.9892
Avg	2.2405	.7293	.2515	.8951	1.0842

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 146004 / 110KV/33KV/11KV RHE

Feeder No / Name : 601 / R.M.MOHITE HYDRO GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 148019 / 220/110/33 KV BIDRI

Feeder No / Name : 601 / DVSSK BIDRI CO-GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.1715
Max	.1715
Min	.1715
Avg	.1715



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 201 / 11KV I.T.Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	.0187	.0354	.0362	.0187	.0354	.0181
2	.0373	.0187	.0354	.0362	.0187	.0354	.0181
3	.0373	.0187	.0354	.0362	.0187	.0354	.0181
4	.0373	.0187	.0354	.0362	.0187	.0354	.0181
5	.0187	.0187	.0354	.0362	.0187	.0354	.0181
6	.0187	.0373	.0354	.0362	.0373	.0354	.0362
7	.0187	.0373	.0354	.0362	.0373	.0354	.0362
8	.0373		.0354	.0543	.0373	.0354	.0362
9	.0373	.0373	.0354	.0362	.0373	.0354	.0362
10	.0532	.0362	.0373	.0532	.0362	.0373	.0373
11	.0709	.0362	.0373	.0532	.0543	.056	.0373
12	.0709	.0543	.0373	.0709	.0724	.056	.0373
13	.0709	.056	.0373	.056	.0543	.056	.056
14	.0709	.0362	.0373	.0537	.0543	.056	.056
15	.0709	.0362	.0373	.0709	.0543	.056	.056
16	.0709	.0362	.0373	.0709	.0709	.0747	.056
17	.056	.0532	.0362	.056	.0532	.0543	.056
18	.0747	.0354	.0362	.056	.0354	.0543	.056
19	.0747	.0358	.0362	.056	.0532	.0724	.056
20	.056	.0354	.0362	.0373	.0532	.0543	.056
21	.0373	.0354	.0362	.0373	.0532	.0543	.0373
22	.0373	.0354	.0362	.0373	.0354	.0362	.0373
23	.0373	.0354	.0362	.0373	.0354	.0362	
24	.0373	.0373	.0354	.0362	.0187	.0354	.0362
Max	.0747	.056	.0373	.0709	.0724	.0747	.056
Min	.0187	.0187	.0354	.0362	.0187	.0354	.0181
Avg	.0487	.0348	.0362	.0469	.0407	.0462	.0394

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 202 / HOCKY STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1433	.1478	.1307	.1433	.1294
2	.1494	.1307	.1254	.1478	.1307	.1254	.1294
3	.1494	.1307	.1254	.1478	.1307	.0354	.1294
4	.168	.1307	.1254	.1478	.1307	.1254	.1294
5	.2427	.1307	.1254	.1478	.1307	.1254	.1294
6	.2241	.112	.1075	.1294	.1494	.1075	.1294
7	.2241	.0934	.1075	.1109	.112	.1075	.1294
8	.2054		.1075	.1109	.112	.1075	.1109
9	.2241	.0934	.1075	.1109	.1494	.1433	.1294
10	.1254	.1294	.112	.1433	.1478	.1494	.168
11	.1433	.1294	.1307	.1254	.1478	.1307	.1494
12	.1612	.1478	.1494	.1254	.1294	.1307	.1307
13	.1612	.1294	.112	.1307	.1109	.112	.1307
14	.1254	.1109	.112	.0895	.1109	.112	.112
15	.1433	.1109	.112	.1254	.1109	.112	.1494
16	.1433	.1109	.112	.1254	.1075	.112	.1307
17	.1307	.1075	.0924	.112	.1075	.1109	.0934
18	.1494	.1254	.1109	.1307	.1075	.1294	.0934
19		.1433	.1478	.168	.1075	.1478	.1494
20	.1867	.1791	.1663	.1867	.1612	.1848	.168
21	.168	.1791	.1663	.1867	.1791	.1848	.168
22	.168	.1791	.1848	.1867	.1791	.1663	.1867
23	.1307	.1612	.1663	.168	.1612	.1663	
24	.168	.1307	.1433	.1478	.1494	.1433	.1478
Max	.2427	.1791	.1848	.1867	.1791	.1848	.1867
Min	.1254	.0934	.0924	.0895	.1075	.0354	.0934
Avg	.1670	.1316	.1289	.1397	.1331	.1297	.1358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 203 / 11KV SUB STATION

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	03-JUN-18
HR	Load (MW)
16	.9522
Max	.9522
Min	.9522
Avg	.9522

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 204 / RENUKA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0829	1.0456	1.0288	.9522	1.7177	.9145	.8775
2	1.0082		.9907	.8962	1.643	.9145	.8402
3	.9896	.9335	.9526	.8962	1.587	.8954	.8402
4	.9522	.9335	.9526	.8962	1.587	.8954	.8402
5	.9709	.9335	.9335	.8962	1.5684	.8573	.8402
6	.9896	.8589	.9145	.8775	1.5497	.8383	.8589
7	.9709	.8962	.8764	.8962	1.587	.8573	.8402
8	.9335	.8962	.8764	.8962	1.6617	.8764	.9335
9	1.0082	.9709	.9145	.9335	1.7924	.9717	.9896
10	1.0098	1.0456	.9896	.9526	2.1098	1.0269	1.0269
11	1.0098	1.0456	1.0082	.0953	1.1576	1.1016	1.0829
12	1.1622	1.1576	1.0642		1.1016	1.0642	.9522
13	1.1241	1.1203	.9896		1.1203	.9896	.9709
14	1.1241	1.0456	1.0082		1.0456	.9335	1.0082
15	1.1812	1.0269	1.0269		1.0082	.9896	.9335
16	1.1622	1.0456	.9522	1.3527	.9907	1.0269	.9709
17	1.1016	.9526	.9335	2.0538	.9526	.9522	.8962
18	1.0642	.9907	.9709	1.9418	.9335	1.0456	.9522
19	1.1576	1.0479	1.0642	1.2136	.9907	1.1389	1.1576
20	1.2696	1.1812	1.1576	2.6139	1.1431	1.2136	1.2323
21	1.363	1.2003	1.1763	2.3152	1.1241	1.1389	1.1203
22	1.1389	1.1622	1.1389	2.1658	1.105	1.1203	1.1576
23	1.1576	1.1431	1.0829	2.0165	1.0669	1.0456	1.1203
24	1.2323	1.0456	1.0669	1.0456	1.8671	.9335	.9335
Max	1.363	1.2003	1.1763	2.6139	2.1098	1.2136	1.2323
Min	.9335	.8589	.8764	.0953	.9335	.8383	.8402
Avg	1.0902	1.0295	1.0029	1.2954	1.3504	.9892	.974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 205 / SUBHASH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.9335	.9335	.9335	.8962	.8383	.8029
2	.9896	.8962	.8954	.8962	.8215	.8383	.7655
3	.9896	.8962	.8954	.8589	.8029	.8192	.7655
4		.8962	.8954	.8589	.8029	.8002	.7655
5	.6348	.8962	.8573	.8589	.8029	.8002	.7655
6	.7282	.8215	.8192	.8775	.8215	.8192	.8215
7	.7095	.8029	.7811	.7842	.8402	.8764	.7655
8	.7842	.8962	.9145	.8775	.9149	.8573	.8775
9	.8029	.9335	.9335	.8775	.9335	.8954	.9335
10		.9522	.9149	.8383	.8775	.9149	.8402
11		.9149	.9522	.8764	.8962	.8775	.7842
12	1.105	.9896	.9149	.8192	.7842	.7842	.7655
13	1.1431	.9335	.9149	.8029	.8029	.8215	.7468
14	1.0098	.8962	.9335		.8962	.8215	.7095
15	1.0288	.9522	.9522	.8954	.7842	.8215	.7095
16	.9717	.8962	.9149	.743	.743	.6348	.7282
17	.8215	.6668	.8215	.7468	.6478	.5415	.6722
18		.9335	.9149	.9522	.7621	1.1389	.7095
19	1.2136	1.0098	1.1203	1.1203	.9907	1.2136	1.1016
20	1.363	1.2574	1.2696	1.1763	1.2384	1.1949	1.2136
21	1.1203	1.2193	1.1016	1.1016	1.0669	1.1016	1.0642
22	1.1576	1.1241	1.0829	1.0829	1.0479	1.0456	1.0642
23	1.1203	1.105	1.0642	1.0269	1.0098	.9896	1.0082
24	1.1016	1.0269	.9907	.9896	.9335	.8764	.8775
Max	1.363	1.2574	1.2696	1.1763	1.2384	1.2136	1.2136
Min	.6348	.6668	.7811	.743	.6478	.5415	.6722
Avg	.9902	.9521	.9495	.9128	.8799	.8884	.8441

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 201 / SAMBHAJI NAGAR CZ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.1128	1.0374	1.0751	.9431	.9054	1.0185
2	1.0185	.9997	.9431	1.0185	.8676	.8488	.9431
3	.9431	.9242	.8865	1.0082	.7922	.7922	.9431
4	.9431	.9054	.9054	1.0562	.7922	.7922	.9619
5	.9242	.9431	.9431	1.1128	.7733	.811	1.0185
6	1.0562	1.0374	.9997	.9997	.9149	.8865	.9808
7	.9619	.9054	.9054	.9242	.8676	.9054	.9997
8	.9431	.9054	.8488	.9619	.8865	.9431	.9242
9	.9997	.9808	.9619	.9054	.9242	.9997	.9997
10	1.1128	1.0374	1.0751	.8676	1.0374	.9808	
11	1.0751	1.0562	1.094		1.094	.9997	1.0374
12	1.0751	1.0562	1.094		1.0751	.9431	.9808
13	1.0562	1.0374		.7922	.9619	.6036	1.0185
14	1.0185		1.0185	.811	.9808	.8676	.9431
15	1.226	1.094		.9619	.9619	.9619	.9431
16	1.1883	.9997	1.0374		.9808	.9431	.9054
17	1.1883	1.0374	1.0562		.9808	1.0185	.9808
18	1.1883	1.0374	1.0562		.9808	1.2071	1.0751
19	1.3957	1.251	1.363	1.3957	1.1694	1.4146	1.2449
20	1.5844	1.4523	1.3957	1.3957	1.358	1.4146	1.3957
21	1.4146	1.358	1.3769	1.3769	1.3203	1.358	
22	1.358	1.3203	1.3392	1.3014	1.2637	1.3014	1.2637
23	1.3392	1.2826	1.2637	1.226	1.1883	1.1694	1.1506
24	1.3014	1.1694	1.1317	1.1317		.9808	1.0562
Max	1.5844	1.4523	1.3957	1.3957	1.358	1.4146	1.3957
Min	.9242	.9054	.8488	.7922	.7733	.6036	.9054
Avg	1.1419	1.0828	1.0788	1.0696	1.0050	1.0020	1.0357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 202 / JAIL KOLHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4108	.415	.3734	.3734	.6348	.6535	.5914
2	.3734	.3772	.3547	.3361	.5975	.6161	.5544
3	.3547	.3584	.3361	.2987	.5975	.5601	.5544
4	.3547	.3584	.3361	.2987	.5975	.5415	.5729
5	.3361	.3772	.3547	.3174	.6161	.5601	.6348
6	.4108	.3734	.3734	.3174	.6722	.5729	.6535
7	.3361	.3361	.3174	.3361	.6161	.6468	.6535
8	.3921	.3547	.3547	.2987	.6908	.6468	.6908
9	.4668	.4668	.3696	.5041	.7842	.7947	.7655
10	.4854	.4481	.3547	.5041	.8215	.7842	.8215
11	.4108	.3921	.3174		.7468	.7842	.5601
12	.2801	.3547	.2987		.6161	.5788	.5975
13	.4294	.3547			.6908	.5975	.5975
14	.4481	.4668	.3174		.6908	.6722	.7468
15	.4108	.3921			.5975	.5788	.5601
16	.4294	.3547	.3174	.924	.6535	.6348	.5601
17	.4294	.3734	.3174	.7842	.6348	.6535	.5975
18	.4108	.4108	.2614		.6653	.7468	.5975
19	.5415	.5228	.4481	.9709	.7577	.9149	.8589
20	.5788	.5788	.4854	1.0642	.961	.9522	.9709
21	.4854	.4854	.4668	.9896	.8871	.9149	
22	.5041	.5041	.4668	.9709	.8871	.9149	.8962
23	.4668	.4481	.4294	.8488	.7947	.7655	.7655
24	.4854	.4715	.4294	.3921	.7282	.6908	.6722
Max	.5788	.5788	.4854	1.0642	.961	.9522	.9709
Min	.2801	.3361	.2614	.2987	.5975	.5415	.5544
Avg	.4263	.4156	.3673	.5850	.7058	.6990	.6728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 204 / KALAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2752	1.2136	1.0164	1.1273	.8871	.7023	.7207
2	1.2197	1.1389	.961	1.0534	.7392	.6653	.6468
3	1.1827	1.1016	.924	1.0534	.7392	.6283	.6468
4	1.1458	1.0829	.9709	1.1088	.7577	.6283	.7023
5	1.1458	1.1203	1.0456	1.1643	.7762	.6838	.7842
6	1.2567	1.2382	1.1576	1.2136	.8402	.7762	.8316
7	1.3121	1.3121	1.1949	1.2382	.924	.8871	.8871
8	1.2752	1.2012	1.1763	1.2752	.8962	.8501	.8686
9	1.2567	1.2012	1.1576	1.2012	.8686	.8501	.8962
10	1.2197	1.1643	1.0903	1.0974	.7762	.7392	.7468
11	1.1888	1.1458	1.1273		.7655	.7468	.7095
12	1.1458	1.1458	1.2012		.7095	.7392	.6838
13	1.1827	1.2012			.7842	.7282	.7095
14	1.1827	1.1088	1.1203		.7392	.6908	.6838
15	1.2382	1.251			.6653	.6722	.5914
16	1.2567	1.1576	1.1273	.9979	.6283	.7207	.5914
17	1.2197	1.0349	1.1203		.7023	.7468	.6468
18	1.1643	1.0456	1.1088		.7023	.9149	.6653
19	1.4969	1.46	1.587	1.0164	.8871	1.0719	.9055
20	1.7741	1.6263	1.6263	1.2382	1.1273	1.1273	1.1088
21		1.5524	1.587	1.1949	1.1273	1.1016	
22	1.6448	1.5339	1.5154	1.1203	1.0534	1.0164	1.0642
23	1.46	1.386	1.3676	.924	.8871	.8316	.8686
24	1.386	1.2936	1.2197	1.2012	.9979	.7577	.7577
Max	1.7741	1.6263	1.6263	1.2752	1.1273	1.1273	1.1088
Min	1.1458	1.0349	.924	.924	.6283	.6283	.5914
Avg	1.2883	1.2382	1.2001	1.1309	.8326	.8032	.7703



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 205 / JARAG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1827	1.1389	.9511	.9979	.8501	.9425	.9055
2	1.1088	1.0829	.9145	.9979	.8131	.9055	.8316
3	.9979	1.0082	.8779	.9425	.7762	.8316	.8316
4	.961	.9709	.8779	.9979	.7762	.8131	.8686
5	.961	.9522	.9145	1.0349	.8029	.7947	.9055
6	1.0164	.924	.9511	.9795	.8871	.8779	.924
7	.961	.924	.823	.8686	.8316	.8413	.8871
8	.924	.9328	.8596	.924	.8501	.823	.9055
9	.9335	.9145	.8779	.9145	.8775	.9055	.9335
10	.9145	.823	.8686	.5487	.8048	.8316	.7316
11	.9145	.823	.9055	.4887	.5121	.8871	.823
12	.9231	.8131	.924	.4572	1.5339	.8131	.823
13	.9955	1.0164		.9145	.924	.7865	.7865
14	.9774	.9795	.9425	.9425	.8871	.7865	.8048
15	1.0317	.9145		.9145	.8131	.823	.7499
16	.9955	.9425	.924	.7133	.6099	.8131	.695
17	.9231	.8131	.8871	.6584	.4572	.8048	.7762
18	.9694	.823	.8596		.4887	1.0719	.8131
19	1.2536	1.2308	1.3676	1.2936	1.1523	1.3676	1.2197
20	1.5364	1.4083	1.4415	1.4045	1.4449	1.46	1.423
21	1.4083	1.3937	1.386	1.4415	1.39	1.4045	
22	1.4083	1.3213	1.3491	1.386	1.262	1.3491	1.2936
23	1.3169	1.262	1.2197	1.1389	1.1706	1.1273	1.1458
24	1.2936	1.2136	1.086	1.0791	1.0164	.9877	.9795
Max	1.5364	1.4083	1.4415	1.4415	1.5339	1.46	1.423
Min	.9145	.8131	.823	.4572	.4572	.7865	.695
Avg	1.0795	1.0261	1.0095	.9582	.9138	.9604	.9155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 206 / 11KV I.T.I.FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0171	.0183	.0187	.0189	.0171	.0187
2	.0189	.0171	.0183	.0187	.0189	.0171	.0187
3	.0189	.0171	.0183	.0187	.0189	.0171	.0187
4	.0189	.0171	.0183	.0187	.0189	.0171	.0187
5	.0189	.0171	.0183	.0187	.0189	.0171	.0187
6	.0189	.0171	.0183	.0187	.0189	.0171	.0185
7	.0189	.0171	.0183	.0187	.0189	.0171	.0185
8	.0189	.0171	.0183	.0187	.0189	.0171	.0185
9	.0189	.0171	.0183	.0171	.0189	.0171	.0187
10	.0171	.0373	.0189	.0171	.0183	.0189	.0183
11	.0171	.037	.0189	.0171	.0183	.0189	.0183
12	.0343	.037	.0189	.0171	.037	.0377	.0183
13	.0343	.0373		.0171	.0373	.0366	.0183
14	.0343	.037	.0189	.0171	.037	.0366	.0183
15	.0343	.0373			.037	.0183	.0183
16	.0343	.0187	.0189	.0171	.0185	.0183	.0185
17	.0171	.0185	.0189	.0171	.0185	.0185	.0189
18	.0171	.0183	.0187		.0171	.0187	.0189
19	.0171	.0183	.0187	.0189	.0171	.0187	.0189
20	.0171	.0183	.0185	.0189	.0171	.0187	.0189
21	.0171	.0183	.0187	.0189	.0171	.0185	
22	.0171	.0183	.0187	.0189	.0171	.0187	.0189
23	.0171	.0183	.0185	.0189	.0171	.0187	.0189
24	.0171	.0171	.0183	.0187	.0189	.0171	.0187
Max	.0343	.0373	.0189	.0189	.0373	.0377	.0189
Min	.0171	.0171	.0183	.0171	.0171	.0171	.0183
Avg	.0213	.0225	.0186	.0182	.0214	.0203	.0186

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 412 / 33kv Shenda Park out going NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3244	4.145	3.6591	3.6037	4.3244	3.4168	3.3265
2	3.77	3.9769	3.3265	3.3819	3.9918	3.2487	2.9938
3	3.6037	3.6408	3.1047	3.3819	3.8809	3.1367	2.9938
4	3.5482	3.4728	3.2156	3.4928	3.8809	3.0807	3.1602
5	3.5482	3.4728	3.3265	3.7146	3.9363	3.2487	3.3265
6	3.6591	3.4928	3.5482	3.5848	3.9918	3.3819	3.3819
7	3.6037	3.5482	3.3265	3.4728	4.201	3.3265	3.3265
8	3.7146	3.6591	3.3819	3.5848	4.269	3.5482	3.5482
9	3.77	3.7146	3.5482	3.4374	4.4907	3.8255	3.6591
10	2.9384	3.6591	3.5482	3.4374	4.7125	3.6591	3.7146
11	2.8275	3.6591	3.5482	1.8296	2.7721	3.4928	3.5482
12	4.1027		3.6591	1.6632	3.5482	3.3819	3.3819
13	4.201			1.6078	3.6037	3.3265	3.271
14	4.0329		3.6037	1.5524	3.5482	3.2156	3.2156
15	4.0889			1.7741	3.271	3.3265	3.1602
16	4.0329		3.5482	2.9938	3.2487	3.271	3.1602
17	3.8649	3.4374	3.4374	3.4928	3.1602	3.0493	3.0493
18	3.8089	3.4928	3.5482		3.3265	4.1581	3.1602
19	4.5462	4.2135	4.5462	4.9343	3.8809	4.6016	4.1581
20	5.2092	4.8788	4.8234	6.4866	4.768	4.7125	4.8234
21	4.6016	4.5462	4.5931	6.0985	4.4907	4.4907	
22	4.6571	4.5462	4.4353	5.8213	4.4353	4.3244	4.3244
23	4.4907	4.4353	4.1581	5.3224	4.0889	3.5482	3.9918
24	4.6016	4.257	3.9918	3.8809	4.6571	3.6969	
Max	5.2092	4.8788	4.8234	6.4866	4.768	4.7125	4.8234
Min	2.8275	3.4374	3.1047	1.5524	2.7721	3.0493	2.9938
Avg	3.9811	3.9078	3.7217	3.5891	3.9366	3.6029	3.4852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 208 / RAJARAMPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.7167	.679	.679	.6224	.6602	.6602
2	.724	.6602	.6413	.6413	.6036	.6036	.6036
3	.743	.6224	.6224	.6224	.5658	.5847	.5847
4	.7049	.6602	.6036	.6036	.5658	.5847	
5	.7049	.6979	.6036	.6036	.5658	.5847	.5847
6	.6859	.7356	.6413	.6602	.6224	.6224	.6224
7	.724	.7545	.6413	.6979	.6979	.7167	.7167
8	.7811	.7733	.6413	.7167	.7545	.7167	.7356
9	.811	.811	.7167	.7545	.7545	.7621	.8299
10	1.0562	.9808	.7733	.9431	.9808	.9335	.9054
11	1.6032	1.4335	1.3014	1.4335	1.4712	1.4289	1.3392
12	1.7164	1.6032	1.3392	1.5466		1.4289	1.4523
13	1.7164	1.6221	1.358	1.5466	2.0005	1.4289	1.4146
14	1.6409	1.5089	1.3203	1.4901	1.6575	1.3146	1.358
15	1.6409	1.4335	1.226	1.4335	1.3203	1.3908	1.2637
16	1.6787	1.4712	1.226	1.4901	1.3957	1.3527	1.3392
17	1.6409	1.358	1.2071	1.3203	1.4146	1.4146	1.3908
18	1.7918	1.3957	1.3014	1.4335	1.4146	1.6032	1.3717
19	1.9427	1.5844	1.5655	1.6032	1.6221	1.6598	1.5623
20	1.8107	1.6032	1.5466	1.4901	1.6221	1.5466	1.6575
21	1.3957	1.3769	1.2449	1.2826	1.3769		1.3717
22	.9808	.9997	.9619	.9431	.9808		.9526
23	.9054	.8676	.8488	.7922	.8299		.8002
24	.7811	.7922	.7356	.7545	.6979	.7167	.6979
Max	1.9427	1.6221	1.5655	1.6032	2.0005	1.6598	1.6575
Min	.6859	.6224	.6036	.6036	.5658	.5847	.5847
Avg	1.2052	1.1026	.9894	1.0618	1.0669	1.0502	1.0528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 209 / 11 KV VARDHAMAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3206	.3206	.3018	.3018	.2829	.2829
2	.3429	.3018	.3206	.6413	.3018	.2829	.2829
3	.3429	.2829	.3018	.3018	.2641	.2829	.2829
4	.3239	.2829	.3018	.3018	.2641	.2829	.3018
5	.3239	.3206	.3018	.3206	.2829	.2829	.3018
6	.362	.3206	.3206	.3206	.3206	.3206	.3206
7	.362	.3584	.3395	.3395	.3584	.3395	.3584
8	.381	.3772	.3584	.3395	.3584	.3961	.3584
9	.4338	.415	.3772	.3395	.3772	.4191	.3772
10	.4715	.6036	.3772	.415	.4527	.381	.415
11	.4904	.5093	.4527	.4904	.5093	.4191	.4904
12	.6413	.5658	.4715	.5281	.547	.5525	.4904
13	.6036	.5847	.4715	.5281	.6097	.5525	.5093
14	.5658	.5093	.4527	.4904	.5335	.4954	.4715
15	.547	.5281	.4338	.4904	.5093	.4572	.4715
16	.4904	.4338	.415	.4715	.4715	.4572	.4527
17	.6224	.4527	.4338	.4527	.4904	.4527	.4763
18	.6224	.415	.4338	.4527	.4904	.547	.5144
19	.6224	.5847	.5093	.547	.547	.6036	.5525
20	.6224	.5847	.547	.5658	.5847	.547	.5906
21	.547	.5093	.4715	.4904	.5093		.5144
22	.415	.4338	.415	.415	.415		.4191
23	.3961	.3961	.3772	.3395	.3772		.362
24	.381	.3584	.3395	.3395	.3206	.3206	.3018
Max	.6413	.6036	.547	.6413	.6097	.6036	.5906
Min	.3239	.2829	.3018	.3018	.2641	.2829	.2829
Avg	.4689	.4354	.3977	.4260	.4249	.4131	.4125

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.679	.7167	.6602	.6036	.6224	.6224
2	.724	.6413	.6602	.6413	.6036	.6224	.6224
3	.7049	.6224	.6413	.6224	.5658	.6036	.6036
4	.743	.6036	.6224	.6224	.5847	.6036	.5847
5	.724	.6036	.6224	.6602	.5658	.6036	.5847
6	.724	.6224	.6602	.6602	.6036	.6413	.6036
7	.7049	.6224	.6413	.6979	.6036	.6224	.6036
8	.743	.679	.6413	.6413	.679	.679	.6979
9	.9054	.8865	.679	.8865	.8488	.9526	.8676
10	1.3203	1.3014	.7733	1.2637	1.3203	1.2193	1.1317
11	1.7918	1.5844	1.0562	1.6032	1.6975	1.5432	1.4712
12	1.7918	1.6221	1.1506	1.773	1.8107	1.6194	1.5655
13	1.9616	1.6975	1.2449	1.7918	1.9433	1.7909	1.7353
14	1.8673	1.6975	1.1694	1.7918	1.7918	1.8099	1.6787
15	1.8673	1.6598	1.1506	1.8296	1.6032	1.6575	1.6409
16	1.9427	1.7353	1.1883	1.8673	1.6975	1.7528	1.6598
17	1.8673	1.5466	1.1694	1.5466	1.6032	1.6975	1.6194
18	1.6975	1.3203	1.0374		1.4523	1.6975	1.4098
19	1.6221	1.3392	1.1128	.6224	1.5278	1.4712	1.5432
20	1.4901	1.358	1.2449	1.4523	1.3392	1.3014	1.448
21	1.0751	1.1506	1.0185	1.1317	1.0562		
22	.9054	.9431	.9431	.9431	.8676		1.105
23	.811	.9054	.8865	.8488	.8676		.8764
24	.8383	.7356	.7545	.7733	.7167	.7545	.7356
Max	1.9616	1.7353	1.2449	1.8673	1.9433	1.8099	1.7353
Min	.7049	.6036	.6224	.6224	.5658	.6036	.5847
Avg	1.2327	1.1065	.9077	1.1013	1.1231	1.1555	1.1048

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 211 / Takala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8299	.7167	.7733	.679	.6413	.6413
2	.724	.7733	.679	.679	.6602	.6224	.6224
3	.743	.7356	.6413	.6413	.6224	.5847	.5847
4	.743	.7356	.6413	.6413	.6413	.5847	.5847
5	.6668	.7356	.6413	.6979	.6413	.5658	.6413
6	.6859	.7545	.679		.6602	.6413	.679
7	.7049	.7545	.6413	.7733	.7356	.679	.7167
8	.7049	.7545	.6602	.7545	.679	.679	.7545
9	.7545	.811	.6413	.7167	.679	.7049	.7356
10	.5093	.7733	.6979	.6224	.6979	.6668	.7922
11	.5093	.0189	.7356	.6224	.7545	.6668	.7733
12	.8299	.8676	.6979	.6224	.7167	.6478	.7545
13	.8299	.7922	.7167	.679	.6859	.6097	.679
14	.7545	.7733	.7167	.6602	.6478	.6097	.679
15	.7922	.7733	.7733	.7545	.6036	.5906	.6602
16	.8299	.8299	.7167	.7356	.6602	.6097	.6036
17	.811	.6602	.6979		.6036	.6979	.6097
18	.8488	.6413	.679	.7545	.6036	.7356	.6287
19	.8488	.7733	.7545	.8676	.7167	.8865	.6668
20	.9808	.9431	.9054	.9054	.8299	.9242	.8764
21		.8488	.9054	.9054	.8299		.8192
22	.0189	.8488	.9054	.9054	.811		.7811
23	1.0185	.8488	.9054	.8299	.7545		.724
24	.8954	.8865	.7733	.8488	.7922	.6979	.9242
Max	1.0185	.9431	.9054	.9054	.8299	.9242	.9242
Min	.0189	.0189	.6413	.6224	.6036	.5658	.5847
Avg	.7377	.7568	.7301	.7450	.6961	.6689	.7055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 212 / 11 KV SHAHUMILL KOP.MAULI

SHEDDABLE URBAN

FEED Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6413	.6413	.6224	.6036	.5847	.5847
2	.6859	.6224	.6413	.6036	.5847	.5658	.5658
3	.7049	.6036	.6036	.6036	.5658	.5658	.5658
4	.7049	.6036	.6036	.6036	.5847	.5658	.5658
5	.6859	.6224	.6036	.5847	.5847	.5658	.6036
6	.6859	.6413	.6602	.6036	.6224	.6036	.6036
7	.6859	.6413	.6036	.6413	.5847	.6036	.6036
8	.6668	.6224	.6224	.6413	.5847	.6602	.6413
9	.6602	.6036	.6036	.6036	.6413	.6287	.6036
10	.679	.5847	.5847	.6413	.6036	.6287	.6036
11	.7922	.5281	.6224	.6413	.6979	.6859	.6413
12	.811	.6036	.7545	.6602	.7356	.7049	.6602
13	.811	.7356	.7733	.6413	.8002	.724	.679
14	.7922	.811	.6979	.7733	.8383	.6668	.679
15	.7922	.7733	.6602	.7545	.6979	.743	.6036
16	.811	.7922	.6602	.6602	.6602	.6668	.547
17	.8865	.679	.7356	.679	.7356	.7545	.7049
18	.9808	.7733	.7733	.7922	.7167	.9054	.743
19	1.0751	.8865	.8676	.9054	.9054	.9808	.9145
20	1.094	1.0374	1.0562	.9242	.9808	.9808	1.0098
21	.9431	.9431	.9242	.9054	.9054		.9335
22	.8299	.8488	.8299	.8299	.811		.8192
23	.7922	.7922	.7733	.7356	.7356		.6287
24	.8002	.6979	.679	.6602	.6413	.6413	.6413
Max	1.094	1.0374	1.0562	.9242	.9808	.9808	1.0098
Min	.6602	.5281	.5847	.5847	.5658	.5658	.547
Avg	.7956	.7120	.7073	.6963	.7009	.6870	.6728



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 213 / Panjarpol

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0943	.1132	.0754	.0754	.0943	.0566
2	.0953	.0754	.1132	.0754	.0754	.0943	.0566
3	.0953	.0566	.1132	.0566	.0754	.0943	.0566
4	.0953	.0566	.0943	.0566	.0754	.0943	.0566
5	.0953	.0566	.0943	.0566	.0754	.0943	.0566
6	.0953	.0566	.0943	.0566	.0754	.0943	.0754
7	.0953	.0754	.0943	.0566	.0754	.0943	.0754
8	.0953	.1132	.132	.0754	.0754	.1132	.0943
9	.132	.1132	.1132	.0754	.0754	.1143	.1132
10	.1698	.132	.132	.0754	.132	.2096	.1509
11	.2263	.2075	.2075	.0189	.1886	.2096	.2075
12	.2263	.2263	.2263	.0189	.2075	.2096	.1698
13	.1886	.2075	.1698	.0189	.2096	.1905	.1886
14	.1509	.132	.132	.0754	.1334	.1524	.1509
15	.2075	.1698	.1698	.0754	.1886	.1905	.132
16	.2263	.2263	.2263	.0566	.2075	.1715	.1509
17	.2452	.2263	.2452	.0566	.2075	.1886	.2477
18	.2075	.1886	.1509	.0566	.2075	.1509	.1334
19	.1509	.132	.1698	.0754	.1509	.132	.1524
20	.1132	.1509	.1132	.0754	.132	.1132	.1334
21	.0943	.0943	.0943	.0754	.0943		.0953
22	.0943	.132		.0754	.0943		.0953
23	.1132	.132	.0943	.0754	.0943		.0953
24	.1143	.1132	.132	.0754	.0754	.0943	.0754
Max	.2452	.2263	.2452	.0754	.2096	.2096	.2477
Min	.0943	.0566	.0943	.0189	.0754	.0943	.0566
Avg	.1426	.1320	.1402	.0621	.1251	.1381	.1175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 411 / 33 KV Incomer No. I MIDC NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDE Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.401	4.1307	4.0175	3.9609	3.678	3.678	3.6214
2	4.1724	3.9043	3.8477	3.7346	3.5648	3.5648	3.5648
3	4.2295	3.7346	3.7346	3.6214	3.3385	3.4517	3.4517
4	4.2295	3.7346	3.6214	3.5648	3.3951	3.4517	3.3951
5	4.1152	3.8477	3.6214	3.7346	3.4517	3.4517	3.5082
6	4.1152	3.9609	3.9043	3.8477	3.6214	3.678	3.678
7	4.1152	4.0741	3.7346	4.0175	3.7912	3.8477	3.9043
8	4.3439	4.2438	3.9043	4.0175	3.9609	4.1307	4.1872
9	4.6965	4.5268	4.0741	4.357	4.3004	4.5153	4.4136
10	5.2624	5.4321	4.357	4.9228	5.2058	5.0297	4.9794
11	6.677	5.4887	5.6019		6.5072	6.0585	6.0545
12	7.2994	6.7901	5.8848		5.3189	6.4015	6.2809
13	7.5257	6.9599	5.8282		7.6017	6.6301	6.3375
14	7.1296	6.677	5.5453		6.9159	6.2872	6.1111
15	7.1862	6.5072	5.4887	6.5072	5.5041	6.23	5.8282
16	7.356	6.7335	5.6019	6.4506	6.3375	6.1728	5.7716
17	7.4126	6.1677	5.6019	5.9414	6.2809	6.3375	6.1728
18	7.5823	5.998	5.6019	4.4702	6.1111	6.9033	6.0014
19	7.8087	6.6204	6.9033	6.0545	7.0165	7.356	6.6873
20	7.8087	7.1862	6.8467	6.7901	7.0731	6.9599	7.2588
21	5.6019	6.3375	5.998	6.0545	6.1111		6.1728
22	4.4702	5.4887	5.3755	5.3755	5.1492		5.144
23	5.1492	5.036	5.036	4.6965	4.6965		4.6296
24	4.8583	4.5268	4.357	4.4136	4.0741	4.0741	4.0741
Max	7.8087	7.1862	6.9033	6.7901	7.6017	7.356	7.2588
Min	4.1152	3.7346	3.6214	3.5648	3.3385	3.4517	3.3951
Avg	5.7311	5.3378	4.937	4.8266	5.1252	5.1529	5.0512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 201 / 11 KV Udymnagar

KOP.INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.6859	.6478	.6097	.6097	.6859	.6097
2	.5716	.6097	.6478	.6478	.5716	.6859	
3	.5716	.6097	.6478	.6478	.5716	.6859	
4	.6097	.6097	.6478	.6478	.6097	.6859	
5	.6097	.6478	.6478	.6478	.6097	.6478	
6	.6097	.6859	.6478	.6478	.6097	.7049	
7	.6097	.6859	.6097	.6478	.6097	.6097	
8	.6478	.8002	.6097	.6859	.6097	.5716	.6097
9	.6478	.6097	.5716	.6478	.5335	.5335	.5335
10	.7621	.8002	.8002	.6478	.7621	.8002	.7621
11	.8002	.9145	.9526	.6478	.8764	.9145	.724
12	.7621	.8383	.8383	.6097	.8002	.8383	.724
13	.8002	.8002	.8002	.6097	.7621	.8002	.724
14	.8002	.7621	.8002	.6478	.7621	.724	.7621
15	.8383	.8764	.9145	.6859	.9145	.8764	.8002
16	.8002	.8383	.8383	.6478	.8383	.8764	.9145
17	.7621	.724	.724		.7621	.8383	.7621
18	.6097	.6478	.6097	.6097	.6097	.6097	.6097
19	.5335	.5335	.5716	.6097	.5335	.5716	.5335
20	.6097	.4954	.6097	.6097	.4954	.5716	.4954
21	.6859	.5716	.6097	.6097	.5335	.5335	.5716
22	.6478	.6097	.6097	.6097	.6478	.6859	.6478
23	.6478	.6097	.6859	.6097	.6478	.6478	.6478
24	.5335	.6478	.6097	.6097	.6097	.6478	.6859
Max	.8383	.9145	.9526	.6859	.9145	.9145	.9145
Min	.5335	.4954	.5716	.6097	.4954	.5335	.4954
Avg	.6669	.6923	.6938	.6345	.6621	.6978	.6732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 202 / 11 KV SAMARAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8871	.8002	.7621	.6859	.7023	.6859	.6859
2	.8131	.7621	.724	.6478	.6653	.6859	.6478
3	.8131	.7621	.6859	.6097	.6653	.6478	.6478
4	.7762	.7621	.6478	.6097	.6283	.6478	.6097
5	.7762	.7621	.6478	.6478	.6283	.6478	
6	.7762	.7621	.6859	.6859	.7023	.6859	.724
7	.7762	.7621	.6859	.6859	.6283	.6859	.724
8	.7023	.724	.6478	.724	.6283	.724	.7621
9	.7023	.7621	.6478	.6478	.5914	.6859	.7621
10	.7621	.7621	.7023	.6478	.6859	.6653	.7621
11	.724	.724	.7023	.6097	.6859	.6653	.7621
12	.7621	.724	.7023	.6478	.6859	.6283	.724
13	.8002	.724	.6653	.6859	.6859	.6653	.6478
14	.8002	.7621	.6653	.6859	.6859	.6653	.6478
15	.8383	.7621	.6653	.724	.6097	.7023	.6478
16	.7621	.7621	.6859	.6478	.6097	.6653	.6097
17	.7621	.6478	.6478		.5716	.6859	.5914
18	.724	.6859	.6859	.7762	.5716	.7621	.5914
19	.8383	.7621	.7621	.7762	.6478	.8383	.7762
20	.9145	.8383	.8764	.8501	.8002	.8764	.8131
21	.8764	.8764	.8383	.8871	.8383	.8764	.8131
22	.9145	.8764	.8764	.8501	.8764	.9145	.8131
23	9.6403	.8764	.8764	.8131	.8002	.8383	.8131
24	.961	.8383	.8002	.8002	.7392	.7621	.724
Max	9.6403	.8764	.8764	.8871	.8764	.9145	.8131
Min	.7023	.6478	.6478	.6097	.5716	.6283	.5914
Avg	1.1710	.7700	.7203	.7107	.6806	.7212	.7087

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 203 / 11 KV HUTATMA PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.8764	.8383	.8383	.8002	.8383	.8383
2	.8002	.8383	.8383	.8383	.8002	.8383	.8383
3	.8002	.8002	.8383	.8383	.8002	.8383	.8383
4	.8002	.8002	.8383	.8383	.8383	.8383	.8383
5	.8383	.8383	.8383	.8383	.8383	.8383	.8764
6	.8383	.9145	.8383	.8764	.8764	.8764	.9145
7	.8002	.8764	.8383	.8383	.8383	.8764	.8764
8	.8383	.9145	.8764	.8764	.8764	.9145	.8764
9	.8764	.9145	.9526	.8383	.9526	.9145	.8764
10	1.1431	1.2193	1.0669	.7621	1.0669	1.0669	1.0669
11	1.105	1.5242	1.2574	.7621	1.4098	1.2574	1.105
12	1.2193	1.4098	1.3336	.8383	1.3336	1.2955	1.1812
13	1.3717	1.4861	1.2574	.9526	1.2574	1.3336	1.1431
14	1.448	1.2955	1.1812	.8764	1.1812	1.2193	.7621
15	1.4861	1.4098	1.2955	.7621	1.2574	1.3717	1.2193
16	1.5242	1.5242	1.3336	.7621	1.2574	1.4098	1.2955
17	1.3717	1.2574	1.1431		1.2193	1.2955	1.1812
18	1.2955	1.105	1.0669	.8383	1.1431	1.2574	1.105
19	1.105	.9907	.9145	.8383	1.0288	1.0669	.9907
20	.9145	.8764	.8764	.8764	.8383	.8383	.8764
21	.8383	.8383	.8383	.8764	.8383	.8764	.8002
22	.9145	.8383	.8383	.8383	.8764	.9145	.8002
23	.9145	.8383	.8383	.8764	.8764	.8383	.8383
24	.8383	.9145	.8383	.8764	.8383	.8383	.8383
Max	1.5242	1.5242	1.3336	.9526	1.4098	1.4098	1.2955
Min	.8002	.8002	.8383	.7621	.8002	.8383	.7621
Avg	1.0383	1.0542	.9907	.8416	1.0018	1.0272	.9574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 205 / RADHA KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2936	1.0669	1.0288	1.0288	1.1088	.9907	1.0288
2	1.2567	.9907	.9907	.9526	1.0719	.9526	.9526
3	1.1458	.9907	.9145	.9145	.9979	.9145	.9145
4	1.0719	.9907	.8764	.9145	.924	.8764	.8764
5	.9979	.9907	.8764	.9145	.8501	.8764	.8764
6	.961	.9907	.9145	.9145	.924	.9145	.9145
7	.961	.9907	.9145	.9526	.924	.9526	.9526
8	.9979	.9907	.9907	1.0669	.961	.9907	1.2955
9	1.2936	1.2955	1.2574	1.2574	1.2567	1.3336	1.2955
10	1.6004	1.7147	1.4784	1.6766	1.6766	1.5154	1.6385
11	2.3243	2.3624	1.7372	2.2481	2.21	2.0328	2.1338
12	2.4006	2.6673	1.848		2.4006	2.2916	2.2481
13	2.4768	2.553	1.8111		2.4768	2.3285	2.3624
14	2.5149	2.3624	1.7741	2.7435	2.3624		2.2862
15	2.5149	2.4387	1.8111	2.4387	2.1719	2.2177	2.2862
16	2.5911	2.3624	1.829	2.1338	2.3624	2.2546	2.2862
17	2.5911	2.21	1.9052		2.3243	2.4387	2.3285
18	2.6292	2.0195	1.8671	2.2177	2.2481	2.4768	2.2177
19	2.5911	2.1338	1.9052	2.1807	2.2481	2.4387	2.2546
20	2.3243	2.0195	1.9814	2.0698	2.0576	2.0576	2.0698
21	1.7147	1.7909	1.5623	1.7741	1.8671	1.9052	1.7741
22	1.4861	1.3717	1.4098	1.4045	1.4861	1.4861	1.4784
23	1.3717	1.2574	1.3336	1.3306	1.2955	1.3717	1.3676
24	1.4045	1.2955	1.2193	1.2193	1.1458	1.1812	1.2193
Max	2.6292	2.6673	1.9814	2.7435	2.4768	2.4768	2.3624
Min	.961	.9907	.8764	.9145	.8501	.8764	.8764
Avg	1.7715	1.6607	1.4265	1.5407	1.6397	1.5999	1.6274

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 411 / 33 KV Incomer no I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.2295	4.0009	3.7723	3.658		3.658	3.6008
2	4.1152	3.7151	3.658	3.5437		3.6008	3.4865
3	3.8866	3.6008	3.5437	3.4865		3.5437	3.4294
4	3.7723	3.6008	3.4294	3.4865		3.4294	3.4294
5	3.7723	3.7151	3.4294	3.5437		3.4294	3.4865
6	3.7151	3.9438	3.6008	3.6008		3.5437	3.658
7	3.7151	3.8295	3.5437	3.658	3.4865	3.6008	3.658
8		4.0581	3.6008	3.9438	3.7151	3.7723	4.1152
9	4.1724	4.1724	3.8866	4.0009	4.0009	4.0009	4.0009
10	4.2867	5.144	4.6296	4.3439	4.8011	4.6296	4.9154
11	5.6584	6.1157	5.144	4.8583	5.7728	5.487	5.4298
12	5.9442	6.2872	5.3727	2.6292	5.8299	5.6584	5.5441
13	6.23	6.1728	5.144	2.8578	5.7728	5.8299	5.4298
14	6.2872	5.8299	5.0297	5.5441	5.6013	5.487	5.4298
15	6.3443	6.1728	5.2584	5.2584	5.487	5.7156	5.5441
16	6.3443	6.1157	5.2012	4.8011	5.6013	5.7728	5.6584
17	6.1728	5.4298	4.9154		5.3727	5.6013	5.487
18	5.9442	5.0297	4.7439		5.0297	5.8299	5.144
19	5.8299	5.0869	4.8011		5.0297	5.6013	5.2584
20	5.5441	4.9154	5.0297		4.8583	5.0297	5.0297
21	2.0576	4.6868	4.5153		4.6868	4.8583	4.6296
22	4.6868	4.3439	4.3439		4.5153	4.6868	4.4582
23	4.5725	4.2295	4.3439		4.2295	4.2867	4.3439
24	4.4582	4.2867	4.0009	4.1152		3.9438	4.0009
Max	6.3443	6.2872	5.3727	5.5441	5.8299	5.8299	5.6584
Min	2.0576	3.6008	3.4294	2.6292	3.4865	3.4294	3.4294
Avg	4.8582	4.7701	4.3724	3.9606	4.9289	4.6249	4.5487

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 201 / 11 KV AMBAI DEFENCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4563	.415	.3982	.4338	.3803	.3961	.3772
2	.3993	.3961	.362	.415	.3423	.3961	.3395
3	.3803	.3961	.3582	.415	.3232	.3772	.3018
4	.3423	.3772	.3224	.415	.3232	.3584	.2829
5	.3042	.3584	.3045	.3584	.2852	.3206	.2829
6	.3042	.3395	.3077	.2829	.3042	.2641	.3018
7	.3232	.3206	.3077	.3174	.3042	.3018	.3395
8	.3613	.3206	.3077	.2987	.3232	.3395	.3584
9	.3042	.2987	.2987	.3018	.3042	.3018	.3018
10	.2987	.2987	.3077	.2641	.3232	.3018	.3395
11	.3174	.3077	.2987		.2987	.2829	.2715
12	.3174	.2715	.2987		.2801	.2829	.2534
13	.2987	.2896	.2987		.2614	.2641	.2534
14	.3361	.2534	.2801		.2801	.2829	.2534
15	.3361	.3292	.3174	.2852	.2801	.2641	.2561
16	.3361	.3258	.2987	.3042	.2801	.2829	.2587
17	.3361	.3077	.2801	.3423	.2614	.2829	.2534
18	.3174	.2534	.2801	.3232	.2614	.3206	.2353
19	.3361	.2534	.3361	.3423	.2801	.4338	.4668
20	.4668	.4163	.4108	.4183	.4108	.415	.4481
21	.4294	.4024	.4294	.4373	.4108	.415	.4435
22	.4294	.4163	.4715	.4563	.4294	.4338	.4207
23	.4338	.4163	.4527	.4373	.4338	.415	.394
24	.5134	.4338	.4163	.4338	.3993	.4108	.3961
Max	.5134	.4338	.4715	.4563	.4338	.4338	.4668
Min	.2987	.2534	.2801	.2641	.2614	.2641	.2353
Avg	.3616	.3416	.3393	.3641	.3242	.3393	.3262



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 202 / 11 KV VIDYAPEETH  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2092		.1833	.2452	.2064	.2263	.2263
2	.1877		.1646	.2452	.1877	.2263	.2075
3	.1877		.16	.2263	.1877	.2263	.2075
4	.2064		.1509	.2263	.1877	.2075	.2075
5	.2064		.1833	.2452	.2064	.2075	.2263
6	.2252		.1974	.2452	.2064	.2263	.2452
7	.2252		.1932	.2263	.2252	.2075	.2452
8	.2092		.1738	.2263	.2252	.2075	.2452
9	.1689		.1635	.2075	.2064	.2075	.2263
10	.2427		.1086	.2075	.2064	.1886	.2263
11	.2987		.1867		.2987	.2452	.2947
12	.3174		.1867	.319	.2801	.2641	.333
13	.2801	.0412	.1867	.2627	.2614	.3206	.2835
14	.2987	.2606	.2054	.2627	.3174	.2452	.3012
15	.3734	.2824	.2241	.2815	.2801	.3018	.3155
16	.3734	.2972	.2054	.319	.3361	.3395	.3155
17	.3547	.3086	.2241	.3566	.2987	.3395	
18	.2987	.2601	.2427	.3003	.2427	.2641	.2572
19	.2614	.2829	.2427	.244	.2054	.2641	.2486
20	.2427	.2641	.2427	.244	.2241	.2452	.2241
21		.2614	.2427	.244	.2241	.2452	.2
22		.2507	.2452	.244	.2241	.2452	.2027
23		.2328	.2452	.244		.2452	.1882
24	.2252		.1932	.2452	.2252	.2263	.2452
Max	.3734	.3086	.2452	.3566	.3361	.3395	.333
Min	.1689	.0412	.1086	.2075	.1877	.1886	.1882
Avg	.2568	.2493	.1980	.2551	.2375	.2468	.2466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 203 / Siber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7986	.7922	.6722	.679	.6084	.6602	.6602
2	.7415	.7733	.6099	.679	.5704	.6602	.6224
3	.7035	.7356	.6099	.6602	.5704	.6413	.6036
4	.6655	.7356	.5914	.6602	.5514	.6413	.5847
5	.6535	.6979	.5975	.6413	.5894	.6036	.6036
6	.6722	.6979	.6535	.6413	.6084	.6602	.6413
7	.6908	.679	.6535	.6413	.6465	.5847	.6413
8	.6161	.6413	.6348	.5658	.6845	.6036	.6036
9	.6535	.6348	.5788	.6224	.6465	.6602	.679
10	.6908	.6535	.5975	.6224	.5894	.6224	.6413
11	.7095	.6908	.5975	.5894	.6161	.6036	.6161
12	.6535	.6161	.5601	.6084	.6722	.6413	.5975
13	.6348	.6348	.5228	.5514	.6161	.547	.5415
14	.6535	.6161	.5228	.5514	.6348	.5658	.5415
15	.7468	.6908	.5601	.5704	.5788	.6224	.5601
16	.8589	.6908	.6161	.6084	.7095	.679	.5415
17	.7282	.6535	.5601	.6655	.6161	.6036	.5788
18	.6908	.5601	.5601	.5894	.5228	.6413	.5415
19	.7282	.6722	.6535	.7225	.6348	.7733	.8402
20	.8775	.8215	.7842	.7796	.8029	.811	.8029
21	.8215	.7842	.7468	.7796		.7733	.7842
22	.8215	.8029	.7733	.7606	.7282	.7545	.7655
23	.8299	.7842	.7545	.7415	.6979	.6979	.6653
24	.8366	.8299	.7095	.7167	.6845	.679	.679
Max	.8775	.8299	.7842	.7796	.8029	.811	.8402
Min	.6161	.5601	.5228	.5514	.5228	.547	.5415
Avg	.7282	.7037	.6300	.6520	.6339	.6554	.6390

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 411 / 33 KV Incomer no I

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4831	1.1883	1.3443	1.358	1.1979	1.3014	1.2449
2	1.312	1.1883	1.2323	1.358	1.0838	1.3014	1.1883
3	1.2549	1.1317	1.2323	1.3014	1.0838	1.2449	1.1317
4	1.1979	1.1317	1.1203	1.3014	1.0838	1.1883	1.0751
5	1.1979	1.0751	1.1763	1.2449	1.0838	1.1317	1.1317
6	1.1979	1.0185	1.2323	1.1883	1.1408	1.1317	1.1883
7	1.2549	1.0185	1.2323	1.1883	1.1979	1.0751	1.2449
8	1.1979	.9619	1.1763	1.0751	1.2549	1.1317	1.1883
9	1.1408	.9522	1.0642	1.1317	1.1408	1.1883	1.1883
10	1.2323	.9522	1.1203	1.0751	1.1408	1.1317	1.1883
11	1.3443	1.0082	1.0642	.5704	1.2323	1.1317	1.2323
12	1.2883	.8962	1.0642	.9127	1.2323	1.1883	1.2323
13	1.2323	1.0082	1.0082	.7986	1.1203	1.1317	1.1203
14	1.2883	1.2323	1.0082	.7986	1.2323	1.0751	1.1203
15	1.4563	1.4003	1.1203	1.1408	1.1203	1.1883	1.1763
16	1.5684	1.4003	1.1203	1.2549	1.3443	1.3014	1.1203
17	1.4003	1.2883	1.0642	1.369	1.1763	1.2449	1.1763
18	1.2883	1.1203	1.0642	1.1979	1.0082	1.2449	1.0642
19	1.3443	1.2323	1.2323	1.312	1.1203	1.4712	1.5684
20	1.5684	1.5123	1.4563	1.426	1.4563	1.4712	1.5123
21	1.2323	1.4563	1.4003	1.4831	1.4003	1.4146	1.5123
22	1.2449	1.5123	1.4712	1.4831	1.4003	1.4146	1.4563
23	1.2449	1.4563	1.4712	1.426	1.1317	1.358	1.3443
24	1.5972	1.2449	1.4003	1.4146	1.312	1.3014	1.3014
Max	1.5972	1.5123	1.4712	1.4831	1.4563	1.4712	1.5684
Min	1.1408	.8962	1.0082	.5704	1.0082	1.0751	1.0642
Avg	1.3153	1.1828	1.2032	1.2004	1.1956	1.2401	1.2378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 201 / 11KV KASABA BAWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.3394	1.3937		1.2308	1.267
2	1.448	1.3756	1.3032	1.3032	1.267	1.1946	1.1946
3		1.3394	1.3032	1.3032		1.1765	1.1946
4	1.4118	1.3394	1.3032	1.3032	1.1946	1.1765	1.1946
5		1.3575	1.3213	1.3213		1.1946	1.2489
6	1.5023	1.3937	1.3937	1.3213	1.3032	1.3575	1.3575
7	1.4842	1.4118	1.4118	1.3575	1.3213	1.3937	1.3575
8	1.5203	1.4299	1.4299	1.3756	1.3756	1.4299	1.4842
9	1.4661	1.3937	1.4118	1.3575	1.3756	1.4842	1.3937
10	1.4842	1.4842	1.448	1.3756	1.3575	1.2489	1.3575
11	1.5203	1.4842	1.448	1.3394	1.5023	1.2489	1.3032
12	1.5023	1.4299	1.4217	1.5023	1.4299	1.2851	1.1946
13	1.448	1.4842	1.4299	1.3575	1.3575	1.1403	1.0679
14	1.448	1.4842	1.4299	1.4842	1.2851	1.2851	1.2127
15	1.5023	1.4661	1.3937	1.4661	1.2851	1.267	1.1041
16	1.448	1.0679	1.4118	1.4661	1.2851	1.2127	1.1403
17	1.5023	.9593	1.448	1.448	1.267	1.3937	1.3032
18	1.3394	.9774	1.448	1.5023	1.2851	1.6108	1.3032
19	1.7013	1.6832	1.7918	1.6832	1.5565	1.7918	1.5203
20	2.0452	1.9004	1.9004	1.7556	1.8642	1.8099	1.7918
21	1.7556	1.828	1.7918	1.7556	1.7737	1.8099	1.7194
22	1.7194	1.7918	1.7375	1.5927	1.7013	1.7375	1.647
23	1.6108	1.647	1.6108	1.448	1.5565	1.5384	1.5565
24	1.6289	1.4661	1.4842	1.5023	1.3756	1.3575	1.3575
Max	2.0452	1.9004	1.9004	1.7556	1.8642	1.8099	1.7918
Min	1.3394	.9593	1.3032	1.3032	1.1946	1.1403	1.0679
Avg	1.5471	1.4433	1.4755	1.4465	1.4152	1.3907	1.3447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2667	.2641	.3018		.2858	.2801
2	.2641	.2641	.2641	.3048	.3206	.2858	.2772
3		.2641		.3048		.2667	.2743
4	.2641	.2829		.2858	.3206	.2858	.2743
5		.2829	.2829	.2858		.2667	.2743
6	.2641	.3395	.3772	.2858	.3395	.3239	.2743
7	.2641	.3921	.3584	.2858	.3018	.3239	.2743
8	.2641	.3772	.2641	.2641	.2829	.2829	.2743
9	.3395	.4108	.3018	.3921	.2641	.4001	.2987
10	.3772	.3772	.3395	.415	.3361	.415	.3206
11	.3772	.3772	.3395	.3961	.3696	.3772	.3018
12	.3772	.3772	.3206		.3734	.3961	.2829
13	.3395	.3772	.3547	.3772	.4108	.4338	.3206
14	.3395	.3395	.3772	.415	.3584	.3395	.3772
15	.3206	.3772	.3772	.415	.4108	.3018	.381
16	.3395	.3772	.415	.415	.3734	.3395	.4001
17	.3361	.3206	.3772	.3584	.3361	.3395	.3206
18	.3734	.3206	.3584	.3395	.3547	.3395	.3584
19	.3734	.3018	.3395	.3584	.3584	.3206	.3206
20	.3547	.3961	.3395	.2829	.3395	.2926	.3206
21	.3018	.3772	.3734	.3018	.2829	.3326	.3584
22	.3048	.2829	.3018	.3395	.2829	.2987	.2641
23	.2858	.2829	.2858	.3395	.2858	.3174	.3206
24	.2452	.2858	.2641	.2829	.3395	.3018	.2987
Max	.3772	.4108	.415	.415	.4108	.4338	.4001
Min	.2452	.2641	.2641	.2641	.2641	.2667	.2641
Avg	.3193	.3355	.3307	.3368	.3353	.3278	.3103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 203 / 11KV ULAPEMALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1097	.0914	.128		.0914	.1097
2	.128	.1097	.0914	.128	.1097	.0914	.0914
3		.0914	.0943	.128		.0914	.0914
4	.128	.0914	.0943	.128	.1097	.1097	.0914
5		.0914	.0914	.128		.1097	.0914
6	.1646	.1097	.1097	.128	.1097	.1097	.1097
7	.128	.0914	.0914	.128	.1097	.1463	.1097
8	.1463	.0914	.1097	.1097	.128	.1463	.128
9	.2378	.1829	.128	.2012	.1829	.1646	.1829
10	.2743	.2378	.1463	.2561	.2378	.1829	.2012
11	.2378	.3292	.1097	.2743	.2195	.1646	.1829
12	.2926	.3109	.1463	.2561	.2561	.2195	.1829
13	.2378	.2378	.1463	.2561	.2012	.1829	.1646
14	.2378	.2561	.1463	.2378	.2561	.2195	.1463
15	.2743	.2195	.1097	.2926	.2195	.2012	.2012
16	.2561	.2378	.128	.2743	.2743	.2012	.2012
17	.2378	.2195	.1463	.2195	.2378	.1829	.2012
18	.2012	.1646	.128	.1829	.1829	.1463	.2012
19	.2195	.2012	.1463	.1829	.1829	.1829	.2195
20	.1646	.2012	.128	.2012	.2012	.1646	.2378
21	.128	.2012	.128	.1829	.2012	.1829	.2195
22	.128	.2012	.128	.2012	.2195	.1829	.2012
23	.1646	.1829	.128	.2012	.2012	.1646	.2012
24	.1463	.1463	.1463	.128	.1463	.128	.128
Max	.2926	.3292	.1463	.2926	.2743	.2195	.2378
Min	.128	.0914	.0914	.1097	.1097	.0914	.0914
Avg	.1968	.1798	.1214	.1898	.1899	.1570	.1623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6653	.7023	.6468		.6283	.6283
2	.7023	.6653	.6838	.6283	.6283	.6283	.6099
3		.6468	.6838	.6283		.6099	.6099
4	.6838	.6468	.6838	.6468	.6283	.6099	.6099
5		.6468	.7023	.6468		.6099	.6468
6	.7577	.6653	.7392	.6838	.7023	.6468	.7023
7	.7392	.6653	.6838	.6653	.6653	.7023	.6838
8	.6468	.6099	.6468	.6653	.6468	1.5708	.6653
9	.6468	.6838	.6838	.6099	.7023	.6653	.6838
10	.6838	.6283	.7023	.6468	.6468	.6283	.6283
11	.6838	.6838	.7577	.6653	.6653	.6838	.6283
12	.7023	.6838	.7392	.2033	.7023	.7023	.5544
13	.6468	.6468		.2033	.6838	.6653	.5175
14	.6468	.7392	1.4599	.2218	.2033	.6283	.5544
15	.7392	.8686	.7392	.2402	.7023	.6468	.5359
16	.7392	.7023	1.4414	.2218	.6653	.6468	.6099
17	.5914		.7023		.6653	.6468	.5914
18	.6468	.8131	.6838	.8131	.6099	.7207	.5729
19	.8131	.8316	.8316	.8871	.7947	.8316	.7577
20	.961	.9795	.924	.9055	.8686	.9055	.9055
21	.9055	.9795	.8501	.8871	.8871	.8501	.8686
22	.8501	.9425	.8316	.8501	.8501	.8131	.8131
23	.7762	.8501	.7577	.7207	.7392	.6838	.7392
24	.7577	.6838	.7392	.6838	.7023	.6468	.6283
Max	.961	.9795	1.4599	.9055	.8871	1.5708	.9055
Min	.5914	.6099	.6468	.2033	.2033	.6099	.5175
Avg	.7295	.7360	.7987	.6074	.6838	.7238	.6561

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 205 / 11 KV Sarwal AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1						.4161	.3294
2					.3641	.3988	.3294
3						.3814	.3294
4					.3641	.3641	.3294
5						.3641	.3121
6					.3814	.3814	.3641
7					.4508	.4161	.4161
8					.4161	.3814	.4161
9	.7628	.7282	.6415				.4508
10	.7108	.7802	.7282				.5375
11	.6241	.7802	.7282				.5548
12	.6935	.7802	.6762				.4681
13	.7455	.7802					.5201
14	.7108	.7628	.6588				.5201
15	.7108	.7282	.6588				.5375
16	.7108	.6935	.6415				.5201
23				.3988	.3988	.3294	
24					.3814	.4334	.3294
Max	.7628	.7802	.7282	.3988	.4508	.4334	.5548
Min	.6241	.6935	.6415	.3988	.3641	.3294	.3121
Avg	.7086	.7542	.6762	.3988	.3938	.3866	.4273



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 201 / 11 KV NAGALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
4			.0351			
9			.0905			.0532
10				.0701	.0693	
12						.056
13				.0526	.0693	
15				.0693	.0701	
16					.0701	.0351
17				.0686		
24	.0867	.0867	.0526			
Max	.0867	.0867	.0905	.0701	.0701	.056
Min	.0867	.0867	.0351	.0526	.0693	.0351
Avg	.0867	.0867	.0594	.0652	.0697	.0481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9522		
4				.8589		.8299	
6					.8589		.8775
7					.8775		.9335
8					.9896	.9709	1.0456
9			.8962	1.0562	1.0642		1.0456
10		1.0562			1.1317	1.0164	
11	1.1643						
12	1.1389	1.0642					
13		1.0903			1.0269	1.0456	
15					1.0164	.9335	
16		1.0456		.9335	.9896		.8589
17				.6348	.9709	.8962	
18				1.1016		.9896	
19				1.0082			
20			1.0642	1.0642			1.0829
21	1.1576	1.1016	1.0829		1.0829		1.1203
22				1.1389			1.0829
23						1.0456	
24	1.251	1.1016	1.0562	1.0642	1.0082	.9896	.9335
Max	1.251	1.1016	1.0829	1.1389	1.1317	1.0456	1.1203
Min	1.1389	1.0456	.8962	.6348	.8589	.8299	.8589
Avg	1.1780	1.0766	1.0249	.9845	.9974	.9686	.9979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 203 / 11KV AKASHWANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.8775		
4				.8215		.8215	
6					.8215		.8775
7					.8215		.9335
8					.8865	.8962	.9896
9			.8676	.8865	.8962		.9896
10		1.0829				1.0642	
12	1.6644	1.1506					
13		1.1016			1.0719	1.0829	
15					1.0456	1.0269	
16		1.1576		1.1576			.9522
17				1.0269	.9896	1.0456	
18				.9896		1.0829	
19				.8962			
20			1.0456	1.0829	1.1203		1.1523
21	1.1016	1.0829	1.0642				1.0719
22				1.0456			1.0242
23						1.0456	
24	1.2136	1.0456	1.0456	1.0269	.9425	.9335	.9149
Max	1.6644	1.1576	1.0642	1.1576	1.1203	1.0829	1.1523
Min	1.1016	1.0456	.8676	.8215	.8215	.8215	.8775
Avg	1.3265	1.1035	1.0058	.9926	.9473	.9999	.9895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 205 / 11KV LAXMIPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.1867		
4				.9054		.7842	
6					.1478		.8215
7					.168		.9335
8				.9335	.3395	.9522	.9522
9			.9522	.9522	.1867		1.0269
10		1.3491				1.2197	
11	1.6448						
12	1.9044	1.7372					
13		1.7551			1.7551	1.6991	
15					1.587	1.5684	
16		1.7177		1.6617			1.6057
17					1.4937	1.587	
18				.2614		1.6057	
19				1.6617			
20			1.419	.2427			1.6078
21	1.3443	1.3443	1.1949		1.4003		1.363
22				.2054			1.2323
23						1.1016	
24	2.1948	1.1203	1.094	1.0829	.2054	1.0185	.9896
Max	2.1948	1.7551	1.419	1.6617	1.7551	1.6991	1.6078
Min	1.3443	1.1203	.9522	.2054	.1478	.7842	.8215
Avg	1.7721	1.5040	1.1650	.8785	.7470	1.2818	1.1703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.9522		
4				.8962		.8215	
6					.9431		.8589
7					.9522		.8775
8					.9619	.9709	.9149
9			.9808	1.0829	1.1016		1.0269
10		1.307				1.3256	
11	1.7924						
12	1.8671	1.5497					
13		1.6804			1.7737	1.643	
15						1.6244	
16		1.6804		2.0538	1.5684		1.5497
17					1.5497	1.6617	
18				1.6617		1.587	
19				1.2696			
20			1.2323	1.4003			1.358
21	1.307	1.2323	1.1576		1.1763		1.2136
22				1.1949			1.1203
23						1.1016	
24	1.2826	1.1317	1.1317	1.0829	1.0456	1.0082	.9709
Max	1.8671	1.6804	1.2323	2.0538	1.7737	1.6617	1.5497
Min	1.2826	1.1317	.9808	.8962	.9431	.8215	.8589
Avg	1.5623	1.4303	1.1256	1.3303	1.2025	1.3049	1.0990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.5601		
4				.4854		.4854	
5	.7392						
6					.5041		.5041
7					.5415		.5601
8					.5788	.6161	.5788
9			.5729	.6161	.6283		.6535
10		.8316				.7842	
11	.9979						
12	1.0534	.9896					
13		1.0164			.9896	.9522	
15						.9335	
16		.9877		1.0269	.9709		.9335
17				1.0269	.9149	.9335	
18				.9709		.9335	
19				.7468			
20			.8029	.8402			.9522
21	.8589	.8215	.7282		.8029		.8402
22				.7392			.7392
23						.6908	
24		.6908	.6908	.6099	.6099	.6161	.6161
Max	1.0534	1.0164	.8029	1.0269	.9896	.9522	.9522
Min	.7392	.6908	.5729	.4854	.5041	.4854	.5041
Avg	.9124	.8896	.6987	.7847	.7101	.7717	.7086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 411 / 33 KV NAGALA PARK

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					5.1532		5.6573
2							5.4332
3							5.1532
4				5.2126		4.9954	5.2092
6					4.8097		5.4332
7					4.8731		
8					5.2092	5.9934	6.1054
9			5.9374	6.3529	5.7133		6.6095
10		7.8418				7.572	
11	8.57						
12	10.9785	9.0181					
13		9.5782			9.7668	9.4376	
15						8.6694	
16		9.2421		10.0263	9.0741	8.9986	8.3951
17				2.6886	7.0576	9.0741	
18				7.2257		9.4662	
20			8.682	7.8418			8.9592
21	8.1219	8.0098	7.6738		7.0016		7.4932
22				6.4975			7.1696
23						6.8896	
24	7.3303	6.733	6.733	6.4615	5.6573	6.0814	6.1614
Max	10.9785	9.5782	8.682	10.0263	9.7668	9.4662	8.9592
Min	7.3303	6.733	5.9374	2.6886	4.8097	4.9954	5.1532
Avg	8.7502	8.4038	7.2566	6.5384	6.4316	7.7178	6.4816

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 201 / 11KV S.T. STAND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2637	1.1389	1.2826	.9619		1.0562	1.0047
2	1.1317			.9431			.9997
3	1.094	1.0269	1.1883	.9431		.9522	.9808
4	1.0751			.9431	.9335		.9808
5	1.0374		1.0642	.9431		.8865	.9619
6	1.0374	.9522		.9431			.9808
7	1.0616		1.0456	.8865		.9431	.9997
8	1.1128	1.1763		1.0374	1.1389		1.2449
9	1.3957	1.2323	1.2071	1.1883	1.307	1.2637	1.2826
10			1.3014			1.2449	
11	1.7737	1.5844	1.3957	2.1472	1.5684	1.5278	1.5684
12		1.6409	1.3957		1.5655	1.6032	1.5684
13			1.4335	2.2218		1.7164	
14		1.6598	1.4712			1.1317	1.5123
15	1.8671	1.773	1.5089	1.7177		1.0185	
16			1.3957		1.6787	1.6975	1.5123
17	1.8858	1.5655	1.3203			1.6409	
18			1.3957	1.531		1.5655	1.5497
19	1.9791	1.6787	1.7164			1.7918	
20		1.7541	1.773	1.587	1.6598	1.6409	1.7737
21	1.8484		1.6221	1.5497	1.5844	1.6221	1.6804
22			1.5278	1.531		1.5089	1.6244
23	1.5466	1.3957	1.358	1.3256	1.226	1.3392	1.3256
24	1.3203	1.307	1.3203	1.1317	1.1389	1.0642	1.0374
Max	1.9791	1.773	1.773	2.2218	1.6787	1.7918	1.7737
Min	1.0374	.9522	1.0456	.8865	.9335	.8865	.9619
Avg	1.4019	1.4204	1.3862	1.3074	1.3801	1.3608	1.2941



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304		.462	.4668		.4435	.4481
2	.5228			.4481	.4668		.4481
3	.4854	.5415	.3841	.4481		.3511	.4481
4	.4854			.4294	.4294		.4481
5	.4854		.3696	.4294		.3841	.4481
6	.4668	.4854		.4294	.4481		.4294
7	.4864		.4207	.4294		.4435	.4668
8	.4854	.4294		.4854	.4668		.5228
9	.5304	.4668	.4066	.4435	.5415	.4481	.4755
10			.4755			.4572	
11	.5415	.4572	.4755	.5041	.0549	.439	.4668
12		.5121	.439		.4938	.4938	.5041
13			.439	.4854		.5121	
14		.4938				.4755	.4481
15	.5601	.5304	.4755	.499		.4572	
16			.4572		.439	.4706	
17	.5228	.4755	.4572		.4251	.4938	
18			.439	.4668		.5175	.4294
19	.6161	.4938	.6219			.6283	
20		.6401	.6219	.6348	.6401	.6283	.6535
21	.6535		.6036	.6535	.6036	.6283	.6161
22			.567	.6161		.5853	.6161
23	.5788	.5304	.5487	.5415	.5304	.5121	.5041
24			.4755	.5041	.5041	.4572	.4572
Max	.6535	.6401	.6219	.6535	.6401	.6283	.6535
Min	.4668	.4294	.3696	.4294	.0549	.3511	.4294
Avg	.5301	.5047	.4810	.4953	.4649	.4913	.4906

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 203 / 11 KV EXCISE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9239	1.7364	1.7918			1.6598	1.5466
2	1.7918			1.6221	1.6804		1.4937
3	1.7541	1.643	1.6975	1.6032		1.5655	1.4937
4	1.7353			1.6032	1.4091		1.4563
5	1.7353		1.643	1.5844		1.4563	1.4377
6	1.6922	1.5729		1.5655	1.6244		1.475
7	1.773		1.6598	1.6787		1.5655	1.7177
8	1.7353	1.7177		1.6409	1.7737		1.773
9	1.8861	1.6991	1.643	1.7353	1.8671	1.7164	1.8296
10			1.6787			1.8671	
11	2.0538	2.0911	1.8861	2.1658	2.1313	1.8673	2.0351
12		1.9791	2.0559		2.1691	1.9805	
13			1.9616	2.1098		2.0559	
14		2.0748	1.9616			1.8296	2.2218
15	2.3712	2.1472	1.9427	2.2218		1.8107	
16			1.773		1.8861	1.905	
17	2.3152	1.8671	1.6598		1.8484	1.9239	
18			1.6221	1.9605		1.9022	2.0351
19	2.4086	1.9791	1.9418			2.0851	
20		2.1502	2.1879	2.0725	2.0182	2.1658	2.1472
21	2.4086		2.1125	2.0725	2.0748	2.1098	2.1472
22			2.0559	2.0725		1.9993	1.9791
23	2.0351	1.9805	2.0182	1.9791	1.905	1.9044	1.8298
24			1.8671	1.7918	1.7924	1.6804	1.7164
Max	2.4086	2.1502	2.1879	2.2218	2.1691	2.1658	2.2218
Min	1.6922	1.5729	1.6221	1.5655	1.4091	1.4563	1.4377
Avg	1.9746	1.8952	1.858	1.8517	1.86	1.8525	1.7844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.0425	1.094	.9431		.9619	.9522
2	1.0562			.8488	.9335		.9335
3	1.0185	.9522	.9522	.8299		.8775	.9335
4	.9997			.811	.8962		.8962
5	.9808		.8676	.7922		.9054	.8962
6	.9619	.9335		.7922	.8775		.8589
7	.9808		.9149	.7545		.8775	.8589
8	1.0562	.9709		.7733	.9522		1.0082
9	1.0751	1.0456	.9522	1.0185	1.0082	1.0562	.9709
10			.9522			.9808	
11	1.0269	.9896	.9896			.8488	.8962
12		.9522	.9149			.8962	.8962
13			.9709	1.1317		.8775	
14		.9709	.9522			.9335	.8402
15	1.1016	1.0456	.9335	1.0269		.8686	
16			.9335		.9709	.8686	
17	1.0642	.9522	.8596		.8865	.8871	
18			.8962	.9522		.9896	.7842
19	1.7551	1.0082	1.1203			1.1763	
20		1.2136	1.0456	1.0829	1.1389	1.1949	1.1763
21	1.251		1.1576	1.1016	1.1883	1.1203	1.1389
22			1.1949	1.0829		1.0642	1.1576
23	1.0456	1.2323	1.1763	1.0456	1.1016	1.1203	1.1203
24	1.2449		1.1203	1.094	1.0082	.9997	.9149
Max	1.7551	1.2323	1.1949	1.1317	1.1883	1.1949	1.1763
Min	.9619	.9335	.8596	.7545	.8775	.8488	.7842
Avg	1.1094	1.0238	.9999	.9460	.9965	.9752	.9574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 205 / RAW WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4108	.3018	.3921		.3174	.3961
2	.415			.3961	.3361		.3681
3	.415	.3547	.2801	.3921		.2987	.3681
4	.415			.3921	.2987		.3961
5	.3961		.2987	.3921		.2829	.3961
6	.3921	.4108		.3856	.4108		.3961
7	.3921		.3174	.3921		.2987	.3961
8	.3961	.3696		.3921	.4108		.415
9	.4338	.4481	.3018	.4668		.3734	.4725
10			.415			.197	
11	.5601	.5093	.3961	.5975	.547	.2686	.6161
12		.4668	.3961		.5041	.2957	.5788
13			.3921	.5788		.2772	
14		.4294	.3961			.2987	.2987
15	.5601	.4294	.3772	.5975		.2543	
16			.4338		.415	.2515	
17	.5415	.4294	.415		.4668	.2818	
18			.4066	.5601		.2054	.4854
19	.4668	.3584	.4024			.2054	
20		.3109	.4024	.4481	.3547	.4294	.4481
21	.4108		.3841	.4294	.3395	.4294	.4108
22			.3961	.2452		.1886	.2614
23	.1867	.3395	.415	.4294	.3174	.3961	.4294
24	.415	.168	.3174	.3961	.3734	.3206	.2987
Max	.5601	.5093	.4338	.5975	.547	.4294	.6161
Min	.1867	.168	.2801	.2452	.2987	.1886	.2614
Avg	.4257	.3882	.3723	.4380	.3979	.2935	.4129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 206 / APPLE HOSPITAL.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747		.0693		.0732	.0914
2	.0693			.0693			.0914
3	.0693	.056	.0709	.0693		.0549	.0914
4	.0693			.0693	.0747		.0914
5	.0701		.0554	.0693		.0886	.0914
6	.0693	.0747		.0693	.0934		.0914
7	.1214		.0747	.0867		.0914	.1097
8	.0867	.112		.104	.0747		.128
9	.1214	.112	.0914	.1214	.168	.0886	.128
10			.0867			.1578	
11	.1307	.1063	.104	.1494	.128	.1214	.1494
12		.1417	.0867		.1646	.1214	.168
13			.0867	.1698		.1214	
14		.1829	.0876			.104	.1307
15	.168	.128	.0867	.1307		.1387	
16			.0693		.1646	.168	.1307
17	.168	.1097	.0701		.128	.112	
18			.0867	.1307		.128	.1867
19	.1663	.1097	.104			.1097	
20		.0732	.0867	.112	.0914	.0848	.0934
21	.112		.0693	.0934	.0934	.0934	.0934
22			.1052	.0934		.0876	.112
23	.0747		.0701	.112	.0732	.104	.0934
24	.0693	.0747	.0549	.0693	.0747	.0709	.0876
Max	.168	.1829	.1052	.1698	.168	.168	.1867
Min	.0693	.056	.0549	.0693	.0732	.0549	.0876
Avg	.1044	.1043	.0814	.0994	.1107	.1060	.1137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 207 / 11 KV STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4908	.4108	.3841	.2427		.2427	.4207
2	.4755			.5784			.4216
3	.4024	.3547	.3696	.2629		.2195	.4031
4	.3658			.2454	.2427		.3856
5	.3658		.3361	.2454		.2743	.4031
6	.2743	.2075		.2641	.056		.3681
7	.4435		.4108	.2804		.4066	.3155
8	.6468	.6722		.1949	.2241		.1578
9	.2033	.2054	.5415	.2865	.3921	.4481	.3155
10			.439			.4252	
11	.4338	.2801	.4938	.2241	.4607	.2483	.2829
12		.3547	.439		.4458	.6024	.5847
13			.128	.2641		.3224	
14		.4108	.1646			.2686	.6979
15	.4108	.4294	.2926	.2614		.1734	
16			.3841		.5975	.4161	
17	.6722	.6036	.3109		.2801	.2427	
18			.2195	.5975		.4508	.2427
19	.2614	.4294	.4572			.4161	
20		.6161	.0914	.6722	.2402	.407	.2452
21	.6348		.4557	.6348	.5228	.4075	.5041
22			.4334	.4481		.4207	.3921
23	.3772	.6036	.4161	.4481	.4481	.2378	
24	.3641	.5228	.4108	.2195	.3772	.2614	.4207
Max	.6722	.6722	.5415	.6722	.5975	.6024	.6979
Min	.2033	.2054	.0914	.1949	.056	.1734	.1578
Avg	.4264	.4358	.3589	.3539	.3573	.3446	.3860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 202 / 11KV RANKALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	1.4937	1.4632	1.307	1.1827	1.2437	1.2136
2	1.2936	1.3443	1.3717	1.1949	1.1706	1.1888	1.1949
3	1.2936	1.3203	1.3717	1.1949	1.2197	1.1888	1.1576
4	1.2936	1.3203	1.3717	1.1949	1.2071	1.1888	1.1576
5	1.358	1.3203	1.2803	1.2323	1.2197	1.1706	1.1949
6	1.3306	1.358	1.262	1.2696	1.1706	1.134	1.1949
7	1.386	1.2883	1.2437	1.307	1.2803	1.2437	1.3121
8	1.3676	1.3443	1.2254	1.3306	1.2437	1.2986	
9	1.2936	1.2437	1.2437	1.2567	1.2254	1.3717	1.267
10	1.2986	1.2986	1.262	1.2254	1.1888	1.1706	1.1706
11	1.0425	1.2437	1.2803	1.134	1.1888	1.1523	1.0974
12	1.4083	1.2071	1.2308	1.0974	1.2254	1.1888	1.1584
13	1.3169	1.2986	1.2437	1.134	1.2437	1.134	1.0974
14	1.3352	1.3121	1.2696	1.1888	1.2567	1.1523	1.1088
15	1.39	1.3676	1.2696	1.2437	1.1458	1.1888	1.1088
16	1.4815	1.3306	1.1827	1.0059	1.1273	1.1888	1.1088
17	1.4083		1.1827		1.1273	1.1827	1.0349
18	1.2894	1.4083	1.1827	1.3352	1.1157	1.4045	1.1088
19	1.6476	1.647	1.5729	1.5364	1.3717	1.701	1.4784
20	1.8099	1.8099	1.7558	1.7193	1.7558	1.7375	1.8111
21	1.6827	1.7013	1.701	1.7193	1.7193	1.6832	1.7372
22	1.7002	1.7556	1.6644	1.4998	1.6461	1.6278	1.6632
23	1.6804	1.647	1.6448	1.4998	1.5364	1.4815	1.5708
24	1.6804	1.5684	1.5203	1.4377	1.3535	1.3392	1.2696
Max	1.8099	1.8099	1.7558	1.7193	1.7558	1.7375	1.8111
Min	1.0425	1.2071	1.1827	1.0059	1.1157	1.134	1.0349
Avg	1.4272	1.4187	1.3665	1.3072	1.2884	1.3067	1.2703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 203 / 11KV MAHALAXMI SANEGURUJI SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.2012	1.0498	1.0029	.8954	.905	.8954
2	1.0974	1.1389	.9955	.8954	.8954	.8688	.8596
3	.9671	1.0082	.9955	.8954	.8954	.8326	.788
4	.9877	1.0185	.9955	.9313	.8779	.8326	.8238
5	1.0185	1.0374	.9671	.9313	.8596	.8326	.8596
6	1.0029	1.0562	.9492	.985	.8596	.8059	.9492
7	.9511	.9997	.9313	.9671	.9431	.9134	.9671
8	.9328	.9979	.8954	.9671	.8954	.9134	1.0029
9	.9808	.9694	.8775	.9134	.9313	.9313	.9671
10	.9313	.985	.9511	.8775	.4835	.8871	.9593
11	.9492	.8954	.9328		.6626	1.0534	.8413
12	.9313	.9313	.9313		.9313	.8316	.9412
13	.9671	.9492	.8954	.4119	.9134	.8131	.7964
14	.9134	.9313	.9511	.4207	.9134	.8131	.7964
15	.9492	.9492	.9511	1.1641	.5552	.7947	.7964
16	1.0387	.8954	.9694	1.0029	.788	.8131	.5249
17	.9492		.8596		.8417	.7762	.6154
18	1.0277	1.0745	.9145	1.0425	.8059	.961	.8145
19	1.3466	1.2536	1.2715	1.2254	1.0208	1.3969	1.086
20	1.5203	1.3969	1.4969	1.39	1.3969	1.4506	1.3575
21	1.4815	1.3969	1.3969	1.39	1.3611	1.4148	1.3394
22	1.4784	1.3432	1.3969	1.1706	1.2894	1.3611	1.2851
23	1.4045	1.2715	1.2357	1.1888	1.2637	1.1104	1.2127
24	1.2254	1.2752	1.1104	1.0745	1.0029	1.0208	1.0208
Max	1.5203	1.3969	1.4969	1.39	1.3969	1.4506	1.3575
Min	.9134	.8954	.8596	.4119	.4835	.7762	.5249
Avg	1.0934	1.0859	1.0384	.9928	.9285	.9722	.9375



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 205 / PUIKHADI WATER WORKS NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4904	.5093	.5093	.4904	.4904	.5093	.4904
2	.4904	.5093	.5093	.4904	.4904	.5093	.4904
3	.4904	.5281	.5093	.5281	.5281	.5093	.5281
4	.5281	.5281	.5093	.5281	.5658	.5093	.5281
5	.5281	.547	.5281	.5658	.5658	.5281	.5658
6	.547	.5658	.5658	.5658	.6036	.5281	.6413
7	.5658	.5658		.5658	.547	.5281	.6036
8	.6036	.547	.5658	.5658	.547	.5847	.5658
9	.5847	.5093	.5281	.5281	.6036	.5281	.5658
10	.5093	.5658	.5093	.5281	.5281	.4904	.5093
11	.5093	.5658	.547	.5281	.5281		.6036
12	.5093	.5658	.547	.5281	.5658	.5281	.5847
13	.5093	.5281	.547		.5281	.5281	.5281
14	.5093	.5281	.5281		.4904	.5281	.679
15	.4527	.5281	.547	.5093	.4904	.5281	
16	.5093	.5281	.4904	.5093	.5281	.4715	
17	.5093		.5281		.6036	.5281	.5093
18	.5658	.547	.547	.5281	.5658	.5281	.547
19	.5658	.4904	.5281	.5658	.4715	.6036	.5281
20	.2263	.4904	.4904	.5281	.4715	.5281	.4904
21	.2075	.4904	.5281	.5281	.4904	.5281	.4904
22		.4904	.5281	.5281	.5281	.5658	.5281
23	.1698	.4904	.4904	.5093	.5281	.5658	.4715
24	.5281	.5281	.4904	.5281	.5093	.5281	.5658
Max	.6036	.5658	.5658	.5658	.6036	.6036	.679
Min	.1698	.4904	.4904	.4904	.4715	.4715	.4715
Avg	.4830	.5281	.5248	.5308	.5320	.5298	.5461

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 206 / K N Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5525	.5175	.4668	.4435	.4108	.3734
2	.5228	.5144	.4854	.4481	.439	.3734	.3734
3	.5228	.5144	.4854	.4481	.439	.3734	.3361
4	.5175	.5144	.4854	.4668	.4755	.3734	.3361
5	.5228	.5525	.5041	.4668	.4755	.3921	.3734
6	.5601	.6097	.5228	.4668	.5093	.4251	.4668
7	.6161	.5658	.5228	.4805	.567	.4805	.5175
8	.6348	.5658	.5601	.5359	.499	.5175	.5914
9	.5975	.5975	.5228	.499	.499	.5359	.5359
10	.5544	.5359	.5175	.4435	.4755	.462	.4805
11	.499	.4805	.462	.4435		.4251	
12	.5359	.499	.462	.4251	.4207	.3696	
13	.499	.4938	.4805	.4435	.439	.3881	
14	.5729	.4805	.4527	.4435	.4066	.3696	.6089
15	.499	.462	.4715	.4066	.3511	.3881	.5175
16	.5544	.5175	.4481	.4251	.3696	.3511	.4668
17	.4805		.4435		.4066	.3696	.4251
18	.5068	.462	.4805	.462	.4251	.5175	.462
19	.6697	.6283	.5853	.5175	.5175	.6219	.5359
20	.7762	.7023	.6767	.6283	.6468	.6584	.6767
21	.7095	.6468	.6219	.6283	.6283	.6219	.695
22	.7167	.7023	.5853	.7392	.6099	.5853	.6036
23	.679	.6468	.5729	.5175	.5359	.5487	.5487
24	.5914	.5847	.5729	.5041	.462	.4435	.4294
Max	.7762	.7023	.6767	.7392	.6468	.6584	.695
Min	.4805	.462	.4435	.4066	.3511	.3511	.3361
Avg	.5789	.5578	.5183	.4916	.4801	.4584	.4931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 201 / 11 KV MASKUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7577	.6535	.7282	.7207	.6722	.6535	.6468
2	.7023	.6348	.6348	.6838	.6535	.6161	.6283
3	.6468	.6161	.5975	.6468	.6348	.5975	.6283
4	.6468	.5975	.5975	.6283	.6348		.6099
5	.6468	.5788	.5975	.6283	.5415		.6099
6	.6653	.5658	.5975	.5914	.5415	.5228	.6283
7	.6838	.5847	.5601	.6099	.5415	.6224	.5914
8	.6838	.6099	.5914	.6468	.5975	.5914	.5914
9	.6653	.6219	.6584	.6653	.6722	.6584	.6283
10	.6838	.499	.6878		.6653	.6516	.6099
11	.695	.499	.724	.6516	.6154	.6154	.5373
12	.7316	.499	.7701	.6447	.6805	.6268	.6447
13	.7133	.7577	.7964	.6516	.6516	.6626	.6201
14	.7316	.6767	.7577	.6653	.6283	.591	.6099
15	.7316	.7392	.7282	.6908	.6283	.6468	.5729
16	.7133	.2587	.7207	.6584	.6401	.6401	.5544
17		.7762	.7316	.6283		.6401	.6335
18	.7265	.7392	.7392	.7059	.6268	.7577	.6089
19	.9492	.9412	.8686	.9492	.8238	.961	.8059
20	.9313	.9774	.9795	.8775	.9391	.9795	.9412
21	.9313	.8962	.9425	.9231	.8688	.9055	.9328
22	.8779	.8596	.9055	.8962	.8779	.8686	.8779
23	.8131	.8871	.8501	.8048	.8131	.7947	.8501
24	.8316	.7468	.7655	.7762	.7282	.6908	.6838
Max	.9492	.9774	.9795	.9492	.9391	.9795	.9412
Min	.6468	.2587	.5601	.5914	.5415	.5228	.5373
Avg	.7461	.6757	.7304	.7106	.6816	.6952	.6686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 202 / 11KV GANGAVES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587	.2452	.2075	.2241	.2427	.2241	.2241
2	.2402	.2452	.1886	.2241	.2427	.2263	.2075
3	.2218	.2452	.1886	.2054	.2218	.2075	.2075
4	.2033	.2452	.1886	.2054	.2218	.2075	.2075
5	.2033	.2452	.1886	.2054	.2033	.2075	.2075
6	.2402	.2452	.1886	.2241	.2033	.2263	.2241
7	.2402	.2263	.1886	.1848	.1848	.2263	.2033
8	.2587	.2452	.1886	.2033	.2218	.2452	.2033
9	.2772	.2801	.2263	.2402	.2587	.2614	.2402
10	.3696	.3326	.2427		.3174	.3326	.3326
11	.462	.3696	.3326	.4251	.3658	.3881	.4024
12	.4805	.3696	.3475	.4755	.4435	.439	.439
13	.499	.3881	.3475	.4887	.3982	.4572	.439
14	.4805	.037	.3547	.499	.439	.4207	.4066
15	.462	.4251	.3584	.4435	.4207	.4435	.4066
16	.462	.4435	.3361	.5121	.4938	.4938	.439
17	.462	.4251	.3881	.5175		.4938	.4938
18	.4706	.462	.3696	.5068	.4163	.499	.4755
19	.591	.462	.4251	.543	.5304	.499	.5121
20	.5249	.439	.4435	.5068	.5068	.4435	.5487
21	.3841	.3109	.3511	.4024	.3801	.3696	.4207
22	.3109	.2743	.2772	.2957	.2957	.2772	.3109
23	.2987	.2614	.2772	.2772	.2801	.2587	.2772
24	.2772	.2801	.2263	.2587	.2614	.2427	.2402
Max	.591	.462	.4435	.543	.5304	.499	.5487
Min	.2033	.037	.1886	.1848	.1848	.2075	.2033
Avg	.3616	.3126	.2847	.3508	.3283	.3371	.3362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 203 / 11KV MAHADWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	1.251	1.1763	1.2012	1.1389	1.1458	1.1273
2	1.2803	1.2323	1.1203	1.1273	1.1203	1.1203	
3	1.2071	1.1949	1.0829	1.1088	1.0829	1.0829	1.0903
4	1.1888	1.1763	1.0456	1.0719	1.0829	1.0642	1.0719
5	1.0608	1.1389	1.0456	1.0719	1.0829	1.0456	1.0719
6	1.0791	1.1128	1.0456	.9979	1.1203		1.0534
7	1.0791	1.1203	1.0082	1.0608	1.1389	1.0642	1.0791
8	1.1523	1.1763	1.0642	1.0791	1.1763	1.1203	1.1157
9	1.262	1.3306	1.1273	1.2254	1.2883	1.3352	1.2437
10	1.4632	1.4083	1.2254		1.4045	1.3535	1.2803
11	1.5181	1.4449	1.4415	1.1946	1.4969	1.4998	1.4998
12	1.7193	1.4815	1.5729	1.3213	1.5546	1.5203	1.5384
13	1.7741	1.4815	1.5729	1.3032	1.5524	1.6108	1.5746
14	1.7741	1.4815	1.4632	1.7193	1.5524	1.4661	1.5154
15	1.7193	1.5181	1.475	1.6632	1.4842	1.5154	1.4083
16	1.6644	1.39	1.46	1.6448	1.4969	1.4969	1.423
17	1.5912	1.4632	1.46	1.7193		1.5181	1.5181
18	1.7918	1.5364	1.4449	1.4327	1.4842	1.7741	1.5927
19	2.2986	1.957	1.8839	1.9909	1.8642	2.0851	1.9185
20	2.5158	2.0271	2.0302	2.0633	2.1176	1.957	2.1538
21	1.9004	1.6832	1.8107	1.8642	1.8642	1.7375	1.9185
22	1.6644	1.5546	1.5729	1.6461	1.6095	1.4998	1.6289
23	1.5524	1.423	1.4266	1.39	1.423	1.3717	1.4449
24	1.4632	1.4003	1.2936	1.3169	1.2752	1.2012	1.2071
Max	2.5158	2.0271	2.0302	2.0633	2.1176	2.0851	2.1538
Min	1.0608	1.1128	1.0082	.9979	1.0829	1.0456	1.0534
Avg	1.5432	1.416	1.3687	1.4006	1.4092	1.4168	1.4120

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 204 / MIRABAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1888	1.1763	1.1389	1.0974	1.0164	1.0164	.9694
2	1.1523	1.1389	1.0829	1.0608	1.0164	.9896	.9511
3	1.134	1.1203	1.0456	1.0242	1.0164	.9709	.9511
4	1.0974	1.1016	1.0082	1.0059	.961	.9335	.8779
5	1.0425	1.0829	1.0082	.9877	.924	.8962	.8779
6	.9877	1.0456	.9335	.9145	.924	.8686	.9145
7	.9877	.9709	.9335	.9694	.9425	.8962	.9328
8	1.0242	1.0164	.9979	.9877	.9425	.961	1.0242
9	1.0974	1.0349	.9328	1.0059	.9425	1.0425	.8962
10	1.2254	1.1157	1.0974		1.0534	1.0136	1.0242
11	1.2071	1.1706	1.2071	1.0679	1.0974	1.0498	.9492
12	1.262	1.1706	1.2254	1.0317	1.086	1.0498	1.0387
13	1.2437	1.1706	1.0974	1.1041	1.0974	1.0566	.9671
14	1.2437	1.2254	1.1949	1.1706	1.0349	.985	.9511
15	1.2437	1.2437	1.1949	1.1273	.9694	.9979	.8962
16	1.2803		1.1706	1.2071	1.0425	1.0136	.8507
17	1.2803	1.134	1.1523	1.0425		1.0317	.9313
18	1.258	1.1157	1.1523	1.1523	.964	1.2071	1.0208
19	1.5384	1.4299	1.3717	1.5746	1.1694	1.4998	1.2715
20	1.7193	1.6095	1.6095	1.4815		1.5364	1.5223
21		1.5181	1.5912	1.5181	1.5546	1.4815	1.5023
22	.2263	1.4415	1.4083	1.46	1.4449	1.3535	1.4083
23	1.419	1.363	1.2803	1.1827	1.2567	1.2254	1.2936
24	1.3169	1.3121	1.2323	1.1706	1.1088	1.0903	1.0242
Max	1.7193	1.6095	1.6095	1.5746	1.5546	1.5364	1.5223
Min	.2263	.9709	.9328	.9145	.924	.8686	.8507
Avg	1.1816	1.2047	1.1695	1.1454	1.0711	1.0903	1.0436

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 206 / 11 KV SAKOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4938	.4481	.4481	.439	.4294	.4251	.4024
2	.4755	.4481	.4481	.439	.4108		.3841
3	.4572	.4481	.4108	.4207	.4066	.4108	.3658
4	.4024	.4294	.4108	.4207	.4066	.3921	.3658
5	.4024	.4294	.4481	.4207	.3881	.3921	.3658
6	.4207	.4294	.4481	.4024	.4108	.3921	.3841
7	.4207	.4805	.4668	.4572	.4066	.4251	.439
8	.4572	.499	.462	.4755	.4435	.4572	.4755
9	.5304	.4938	.439	.4755	.5175	.5068	.5121
10	.5853	.4755	.5068		.5304	.4656	.4755
11	.5304	.5304	.5304	.4706	.5249	.4656	.4961
12	.5487	.5304	.4835	.4525	.5138	.4961	.4656
13	.5853	.5304	.5014	.5068	.5121	.5138	.443
14	.5853	.5487	.5175	.5068	.4938	.4784	.4706
15	.5853	.5487	.5359	.499	.4755	.5068	.4251
16	.5487	.439	.5121	1.6448	.5068	.4706	.4207
17	.567	.5121	.4887	.5373		.5068	.4477
18	.5611	.4938	.4755	.5373	.4508	.5487	.4733
19	.7059	.6401	.567	.6335	.5434	.6401	.5784
20	.6878	.6154	.5853	.6089	.6268	.6219	.5847
21	.6516	.5973	.5853	.6154	.5973	.6219	.6335
22	.6036	.5792	.5304	.5853	.5611	.5304	.5792
23	.5729	.567	.5121	.5121	.5304	.4938	.5359
24	.567	.5175	.5228	.4755	.4805	.4435	.4207
Max	.7059	.6401	.5853	1.6448	.6268	.6401	.6335
Min	.4024	.4294	.4108	.4024	.3881	.3921	.3658
Avg	.5394	.5096	.4932	.5451	.4855	.4872	.4644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 207 / SHUKRAWAR GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7865	.7282	.6908	.6767	.6908	.6653	.6767
2	.7682	.7282	.6348	.6584	.6653	.6535	.6584
3	.7499	.7095	.5975	.6584	.6653	.6908	.6584
4	.7499	.7095	.5975	.6401	.6468	.6348	.6584
5	.7316	.6908	.6348	.6401	.6468	.6535	.6584
6	.7316	.7095	.6535	.6584	.6161	.6722	.6401
7	.7316	.7282	.5975	.6767	.6099	.6535	.6767
8	.7499	.7207	.6653	.7133	.6838	.7207	.7133
9	.7865	.7762	.6584	.7316	.7655	.7316	.7682
10	.8048	.7865	.695		.7392	.7316	.7316
11	.8413	.7865	.6878	.7421	.8145	.7682	.7421
12	.8596	.823	.7701	.7783	.7522	.7421	.7522
13	.8962	.823	.7522	.7602	.8145	.7343	.7164
14	.8413	.8048	.7682	.7865	.7133	.6984	.724
15	.8413	.8596	.7577	.7762	.7133	.7392	.695
16	.8048	.7682	.7577	.8048	.7316	.6767	.6767
17	.8048	.8048	.7602	.7499		.7602	.7421
18	.8417	.7133	.7682	.8417	.7442	.9328	.7442
19	1.134	1.0136	1.0425	1.1104	.9492	1.0974	.9568
20	1.1163	1.0208	1.0974	1.0029	1.0277	1.0791	1.0454
21	1.0029	.9134	.9877	.985	.985	1.0425	1.0277
22	.9955	.9492	.9328	.9231	.9412	.9694	.9774
23	.9425	.8501	.8413	.8145	.8413	.823	.8596
24	.8413	.8402	.7392	.7499	.7577	.7207	.7133
Max	1.134	1.0208	1.0974	1.1104	1.0277	1.0974	1.0454
Min	.7316	.6908	.5975	.6401	.6099	.6348	.6401
Avg	.8481	.8024	.7537	.7774	.7615	.7746	.7589



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 208 / 11 KV LAXTIRTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6379	.6161	.5359	.5194	.5415	.5228	.5014
2	.5847	.6161	.5175	.4835	.499	.5041	.4835
3	.5316	.5975	.4805	.4835	.4887	.5041	.4656
4	.5316	.5975	.4805	.4887	.4706	.4854	.4656
5	.5316	.5975	.4805	.4656	.4706	.4668	.4656
6	.5493	.5788	.4805	.4656	.4706	.4481	.4477
7	.5731	.5228	.462	.4656	.3801	.4527	.4656
8	.5731	.499	.4251	.4835	.3982	.4435	.4477
9	.5552	.5304	.4706	.5194	.3982	.4572	.4298
10	.6089	.5194	.4784		.3982	.4163	.4298
11	.591	.4835	.5014	.4835	.4119	.4163	.4252
12	.6089	.5194	.5258	.5083	.4298	.4075	.3856
13		.5194	.5847	.5201	.4477	.4207	.3641
14		.5611	.5973	.567	.4075	.4031	.3801
15		.5552	.5792	.5731	.4163	.4706	.3696
16		.4835	.567	.567	.4163	.4298	.362
17		.4656	.5258	.4835		.4252	.3601
18	.6104	.5014	.4835	.4835	.407	.5014	.4287
19	.7265	.591	.5552	.6335	.5316	.6089	.5144
20	.7701	.6984	.6805	.6878	.691	.6805	.6588
21	.6805	.6447	.6626	.6697	.6626	.6447	.6805
22	.7421	.6584	.6268	.695	.6584	.6626	.6767
23	.7207	.6283	.6447	.6036	.6099	.6089	.6283
24	.7087	.6653	.5729	.5731	.5729	.5415	.5194
Max	.7701	.6984	.6805	.695	.691	.6805	.6805
Min	.5316	.4656	.4251	.4656	.3801	.4031	.3601
Avg	.6229	.5688	.5383	.5402	.4860	.4968	.4732

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 146017 / 110/33KV CHAMBUKHADI

Feeder No / Name : 401 / 33KV DUDHALI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	.0109
Max	.0109
Min	.0109
Avg	.0109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 201 / 11KV TRYAMBOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.6722	.5175	.5601	.5175	.5975	.5228
2	.5601	.5975	.5228	.5228	.5175	.5975	.5175
3	.5544	.5975	.5228	.5228	.5228	.5975	.5175
4	.5544	.5975	.5175	.5175	.5228	.5975	.5228
5	.5601	.5975	.5175	.5601	.5228	.5975	.5228
6	.5601	.5975	.5228		.5228	.5975	.5175
7	.5228	.5228	.5228	.5228	.5228	.5228	.4805
8	.5175	.5175	.4435	.5175	.4805	.5175	.439
9	.5175	.5121	.4481	.4435	.4435	.5121	.4435
10	.5121	.5121	.4344	.439	.5121	.4435	.4344
11	.4805	.4344	.439	.439	.439	.4344	.4344
12	.5175	.4344	.4755		.439	.4344	.4298
13	.5175	.4344	.4706		.4344	.439	.4298
14	.5228	.5014	.4435		.3734	.5121	.5121
15	.5228	.5228	.5175	.6468	.3696	.5175	.4435
16	.5228	.5228	.4805	.5914	.439	.4435	.4435
17	.5121	.4298	.4755	.5068	.4252	.4344	.4344
18	.5121	.5014	.4908	.631	.3544	.5014	.4298
19	.7164	.4344	.567	.6447	.4961	.6447	.567
20	.8688	.6516	.724	.6878	.7164	.6516	.7164
21	.7964	.6584	.6878	.6878	.7964	.6584	.724
22	.7316	.6584	.6584	.6767	.7316	.6584	.7316
23	.7392	.5914	.6653	.6283	.6653	.5975	.6653
24	.5975	.6722	.5544	.5975	.5601	.5975	.5601
Max	.8688	.6722	.724	.6878	.7964	.6584	.7316
Min	.4805	.4298	.4344	.439	.3544	.4344	.4298
Avg	.5839	.5488	.5258	.5672	.5135	.5461	.5183

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 411 / 33KC I/C-1 GPI

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18
HR	Load (MW)
23	2.009
24	2.009
Max	2.009
Min	2.009
Avg	2.009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 201 / 11KV Panchganga Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1492		.0983			
2		.1475		.0983			
3		.1311		.0983			
4		.1326		.0983			
5		.1326		.0983			
6		.1326		.1147			
7		.1326		.1147			
8		.1326		.1147			
9					.0328	.1143	.116
10					.0655	.1334	.1492
11					.0819	.1524	.1492
12					.0819	.1715	
13					.0819		.1492
14					.0819	.1715	.1326
15					.0819	.1334	.1326
16					.0819	.1715	.1326
23	.1475		.0983				
24		.1492	.1219	.0983			
Max	.1475	.1492	.1219	.1147	.0819	.1715	.1492
Min	.1475	.1311	.0983	.0983	.0328	.1143	.116
Avg	.1475	.1378	.1101	.1038	.0737	.1497	.1373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 202 / Shirol

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2574		1.358	1.086		1.2637
2	1.2384	1.2193		1.2637	1.0479		
3	1.2003	1.1622		1.2637	1.0098		1.2071
4	1.2193	1.1431		1.2826	1.0288		1.1883
5	1.2574	1.2003		1.2826	1.0669		1.1883
6	1.2955	1.2765		1.3392	1.105		1.2071
7	1.5051	1.4098		1.3203	1.1431		1.358
8	1.467	1.5051		1.2826	1.2003		1.5089
9		1.9239	1.9243		1.358	1.5432	1.7337
10		2.1472	2.0957		1.587	1.6385	1.9433
11		2.2405	2.2862		1.8298	1.8861	1.9814
12		2.0725	2.2291		1.7737	1.7528	1.8671
13		2.1658	2.0386		1.5123		1.7337
14		2.1845	1.9814		1.643	1.7147	1.7147
15		2.2779	2.1338		1.7364	1.8099	1.7337
16			2.0386		1.7353	1.9433	1.7147
17	2.2862		2.0538	1.1812		1.9044	1.8861
18	1.9814		1.9791	1.1622		1.8671	1.7909
19	2.0767		2.0165	1.2574		1.8111	1.7147
20	1.8861			1.2384		1.6598	1.6004
21	1.3908		1.531	1.2574		1.5466	1.4289
22	1.5051		1.5497	1.2955		1.4712	1.3717
23	1.4098		1.5466	1.2003		1.3203	1.2384
24	1.4098	1.3336	1.1822	1.3957	1.105	.9717	1.3203
Max	2.2862	2.2779	2.2862	1.3957	1.8298	1.9433	1.9814
Min	1.2003	1.1431	1.1822	1.1622	1.0098	.9717	1.1883
Avg	1.5289	1.6575	1.9058	1.2738	1.3511	1.6560	1.5520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 204 / Tarabai Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0328	1.7924		1.7372	1.7556		1.6448
2	1.9418	1.6461		1.6632	1.6991		1.5708
3	1.8861	1.5729		1.6078	1.643		1.5154
4	1.8484	1.5729		1.5364	1.6032		1.4969
5	1.7924	1.6095		1.5364	1.6221		1.5154
6	1.7187	1.6644		1.5546	1.6057		1.5708
7	1.6817	1.6095		1.5912	1.5154		1.6078
8	1.6632	1.6095		1.6461	1.6078		1.5729
9		1.6461	1.7556		1.7924	1.8111	1.829
10			1.8296		1.8839	1.6448	1.7558
11		1.9204	1.8665		1.8107	1.6301	1.7741
12		1.9022	1.8296		1.829	1.7926	1.7558
13		1.9387	1.8861		1.7375		1.7193
14		1.8839	1.8665		1.8473	1.848	1.7375
15		2.0119	1.9589		1.8107	1.8665	1.7193
16			1.9404		1.8107	1.8473	
17	2.0668		1.9022	1.8111		1.7558	1.701
18	1.9936		1.7558	1.848		1.8473	1.6644
19	2.3411		2.0485	2.0883		2.2497	2.0302
20	2.5057			2.1033		2.384	
21	2.3777		2.2131	2.1216		2.2177	2.1948
22	2.2131			1.9936		2.1399	2.1216
23	2.0485		2.0485	1.9774		1.957	1.9204
24	2.1992	1.9387	1.7833	1.9022	1.7556	1.6461	1.7926
Max	2.5057	2.0119	2.2131	2.1216	1.8839	2.384	2.1948
Min	1.6632	1.5729	1.7556	1.5364	1.5154	1.6301	1.4969
Avg	2.0194	1.7546	1.9060	1.7949	1.7253	1.9092	1.7368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 206 / Vikramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2071		1.0642	1.0288		1.0269
2	1.226	1.1694		1.0082	.9997		.9522
3	1.2003	1.1317		.9896	.9717		.9522
4	1.1694	1.0751		.9896	.9717		.9335
5	1.1506	1.1128		1.0082	.9526		.9522
6	1.1622	1.1506		1.0082	.9907		.9709
7	1.0751	1.094		1.0269	.9997		1.0082
8	1.0562	1.094		1.0456	.9907		1.0829
9		1.0456	1.0479		1.0082	1.0479	1.0562
10		1.0829	.9808		1.0082	.9717	1.0185
11		1.0829	1.0374		1.0269	.9997	1.0374
12		1.0456	1.0562		.9896	.9431	.9808
13		1.0456	1.0288		.9896		.9242
14		1.0829	1.105		1.0269	.9619	.9054
15		1.1763	1.1128		.9522	1.0185	.9808
16			1.1317		.9709	.9997	.811
17	1.2071		1.0829	.9907		1.0082	.9431
18	1.1506		.9709	1.0374		1.1949	.9242
19	1.2071		1.2323	1.1506		1.2883	1.1506
20	1.4335			1.2826		1.363	1.3957
21	1.358		1.2883	1.3014		1.363	1.358
22	1.3957		1.2883	1.358		1.3256	1.3392
23	1.358		1.307	1.226		1.2136	1.3014
24	1.4146	1.2826	1.1145	1.1763	1.1317	1.0117	1.0829
Max	1.4335	1.2826	1.307	1.358	1.1317	1.363	1.3957
Min	1.0562	1.0456	.9709	.9896	.9522	.9431	.811
Avg	1.2436	1.1174	1.1190	1.1040	1.0006	1.1141	1.0454



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 207 / Industrial Bapat Camp MYZ SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5906	.5716		.547	.4954		.6413
2	.5716	.5716		.5093	.4954		.6224
3	.5525	.5525		.4904	.5144		.6036
4	.5335	.5335		.4904	.4954		.5658
5	.5335	.5335		.5093	.4954		.5281
6	.5716	.5335		.5093	.5144		.4904
7	.5525	.5335		.4904	.5144		.4904
8	.5144	.5906		.4715	.4954		.5093
9		.7545	.6668		.7167	.6287	.7621
10		1.0185	.8573		.7356	.7811	.9145
11		1.094	.8192		.8865	.8954	.9526
12		1.0562	.8573		.811	.7811	.9526
13		.9896	.7621		.811		.9335
14		.8299	.6668		.7468	.724	.9145
15		1.0185	.8954		.8589	.9717	.9717
16			.8954		.8488	1.0479	.9907
17	1.1812		.8488	.5716		1.0374	.8383
18	.9907		.7167	.6097		.9431	.8383
19	.9526		.6413	.5716		.8865	.6859
20			.6602	.5525		.7167	.6478
21			.6413	.5335		.5975	.6287
22	.8002		.6036	.5525		.6979	.724
23	.743		.6224	.5525		.679	.6859
24	.6097	.724	.4534	.5658	.5144	.4801	.6979
Max	1.1812	1.094	.8954	.6097	.8865	1.0479	.9907
Min	.5144	.5335	.4534	.4715	.4954	.4801	.4904
Avg	.6927	.7441	.7255	.5330	.6441	.7912	.7329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 209 / DYP DF EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2477		.2829	.2667		.3018
2	.2286	.2096		.2263	.2286		.2263
3	.1905	.1905		.2075	.1905		.2263
4	.1905	.1905		.1886	.1905		.2075
5	.2096	.2096		.2075	.1905		.2263
6	.2667	.2477		.2263	.2286		.2641
7		.3429		.2641	.362		.3584
8	.4001	.4001		.3961	.4191		.3961
9		.4715	.5335		.4338	.4382	.4572
10		.547	.6668		.5658	.5144	.4382
11		.7167	.8383		.7167	.6859	.6668
12		.9431	1.0098		.8299	.7811	.7049
13		1.1883	1.105		.8299		.743
14		1.3014	1.105		.7922	.7811	.7621
15		1.1389	1.1241		.7167	.8383	.8002
16			1.0288		.7545	.7621	.743
17	.9717		.8865	.9717		.7733	.7621
18	.9145		.8676	.8764		.7733	.743
19	1.1431		.8865	.8954		.8676	.8383
20	1.0669			.8383		.9431	.8954
21	.9526		.8865	.7811		.9242	.8383
22	.6097		.7167	.5525		.6602	.5525
23	.5525		.5847	.4382		.547	.5144
24	.4001	.3429	.415	.3206	.3048	.3395	.3395
Max	1.1431	1.3014	1.1241	.9717	.8299	.9431	.8954
Min	.1905	.1905	.415	.1886	.1905	.3395	.2075
Avg	.5601	.5430	.8437	.4796	.4718	.7086	.5419

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 201 / Kay Industry  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858		.2614	.2858	.2858		.056
2	.3048		.2614	.2858	.2667		.056
3	.3048		.2614	.2858	.2858		.056
4	.2858		.2614	.2858	.2858		.2614
5	.2858		.2614	.2858	.2667		.2614
6	.2858	.2858	.2614	.2858	.3048		.2801
7		.2858	.2614	.2858	.3048		.2987
8	.3048	.2858	.2614	.3048	.3048		.2987
9	.3048	.2858	.2614	.0572	.3048	.2667	.2987
10	.2801	.2858	.3048		.2667	.2667	
11	.2614	.2858	.3048	.056	.2667	.3048	
12	.2614	.3048	.2667	.056	.2667	.2667	
13	.2614	.2858	.2667	.056	.2667	.2667	
14	.2614	.2667	.2477	.056	.2667	.2667	
15	.2614	.2667	.2667			.2667	.2667
16	.3048	.2667	.2667	.056	.3048	.2667	.3048
17	.3048	.056	.0572	.056	.3048	.2667	.3048
18	.2667	.056	.0572	.0572		.2987	.2858
19	.2667	.056		.0572		.2987	.2858
20		.056	.0572	.0572		.2801	.2858
21		.056	.0572	.0572		.2987	.0572
22		.056	.0572	.2477		.2622	.0572
23		.056	.0572	.2858			.0572
24	.2858		.2614	.2667	.2858	.0572	.056
Max	.3048	.3048	.3048	.3048	.3048	.3048	.3048
Min	.2614	.056	.0572	.056	.2667	.0572	.056
Avg	.2831	.1943	.2122	.1694	.2846	.2623	.2015

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 202 / Sakal Press DBlock Shirol  
 Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
 STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2574		1.1203	1.2955	1.086		1.0642
2	1.2765		1.0829	1.2765	1.2003		1.1203
3	1.2384		1.0269	1.2384	1.0288		1.1016
4	1.0288		.9709	1.2384	.8764		1.0829
5	.9145		.9522	.9145	.8954		1.0456
6	.8573	.8383	.9149	.8192	.8573		1.0269
7	.8192	.8383	.8402	.8192	.8764		1.0456
8	.8192	.8002	.8589	.8383	.8764		.9896
9	.9145	.8002	.9335	.7621	.9717	.9145	.9896
10	.8775	1.105	1.0288	.7468	1.0098	.8002	
11	.8215	1.0669	1.086	.7282	.9717	.9145	
12	.8402	1.105	1.105	.7468	.8954	.8954	
13	.9335	1.2003		.7842	1.2003	.7049	
14	1.0059	1.2574	.9145	.7655	1.2384	.8954	
15	1.2136	1.2193	.9526	.7842	.9717	.8954	1.2765
16	1.1812	1.2193	1.1431	.8402	.9145	.9907	1.2384
17	1.086	.7655	1.0288	.8402	.9907	1.1431	1.2384
18	1.2384	.9522	.724	.8573		1.0829	.9526
19	1.1622	1.0082	.9335	.8764		1.0269	.9526
20		.9896	.9907	.8764		.9709	.8573
21		.9709	1.1241	.8764		.9709	.8383
22		.9709	1.1622	.8573		.9522	.8573
23		1.0082	1.2003	.8002		.9709	.9145
24	1.2003		1.0642	1.2193	.9145	1.0288	1.0829
Max	1.2765	1.2574	1.2003	1.2955	1.2384	1.1431	1.2765
Min	.8192	.7655	.724	.7282	.8573	.7049	.8383
Avg	1.0343	1.0064	1.0069	.9084	.9875	.9474	1.0355

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 203 / Menon Metallica  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859		.6722	.6859	.3429		.5041
2	.6859		.6722	.7049	.3429		.4854
3	.6668		.6535	.6668	.3429		.4668
4	.6668		.6535	.6668	.381		.4481
5	.6478		.6348	.6859	.381		.4668
6	.6478	.5144	.6908	.6859	.362		.4854
7	.6287	.5716	.6535	.5716	.381	.4382	.4481
8	.6478	.7621	.6348	.3429	.3429		.7468
9	.5525	.7621	1.0456	.362	.8764	.7621	.8589
10	.7468	1.2955	.9526	.3547	.8383	1.2574	
11	.7842	1.1241	1.2574	.3547	1.105	1.3527	
12	.8029	.8764	.9526	.3734	1.1622	1.2765	
13	.8589	1.3527	.7811	.3734	1.2193	.8764	
14	.8775	1.4289	1.3908		1.2384	.8764	
15	.9149	1.2955	.8764	.3174	1.3146	.9907	.5906
16	.5906	.8764	1.2574	.2987	1.3717	.9717	.5335
17	.8383	1.0642	1.1241	.2987	1.2384	1.0098	.5335
18	.8002	.9709		.3429		1.1203	1.1622
19	.6859	.7282		.362		1.1949	.6668
20		1.8671		.3429		1.1203	.4954
21		1.643		.3429		.9335	.4763
22		1.3443	.6478	.3239		.4481	.4763
23		.7095	.6287	.3239		.4481	.4763
24	.6668		.6908	.6287	.3429	.4382	.4854
Max	.9149	1.8671	1.3908	.7049	1.3717	1.3527	1.1622
Min	.5525	.5144	.6287	.2987	.3429	.4382	.4481
Avg	.7199	1.0659	.8435	.4526	.7547	.9127	.5688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 204 / Budhale

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146		1.1233	1.3146	.8002		1.307
2			1.2136	1.2765	.8002		1.307
3	1.3146		1.1949	1.2574	.7811		1.2883
4	1.2574		1.1576	1.2955	.8002		1.2696
5	1.086		1.1763	1.2955	.7621		1.2136
6	1.105	1.105	1.1763	1.3146	.9145		1.0269
7	1.0098		1.1203	1.0479	.9145		.8589
8	.9335		.9149	.8192	.7621		1.0269
9	1.105	1.0669	1.5123	.8954	.9907	1.2193	1.0829
10	1.3443	2.0767	1.7718	.8775	.9907	1.6766	
11	1.531	1.6956	1.3908	.8775		2.0195	
12	1.531	1.4861	1.3146	.8589	1.6194	1.5242	
13	1.3256	1.6004	1.5432	.8589	1.7718	1.6575	
14	1.4937	1.6575	1.3336	.8402	1.9052	1.8671	
15	1.6617	1.5813	1.9243	.7842	1.8671	1.3527	1.8861
16	1.6004	1.4861	1.2003	.7468	1.7528	2.0195	1.5813
17	1.4289	1.5684	1.3527	.7282	1.6004	1.7147	1.5813
18	1.105	1.8298	1.5051	.7621		1.7177	1.5242
19	1.3527	1.9418	1.2193	.8002		1.5123	1.3527
20		.7468	1.105	.8192		1.3443	1.0479
21		.6535	1.0669	.8002		1.3256	1.0098
22		.5975	1.0669	.8002		1.307	1.0288
23		1.307	1.105	.7811		1.307	1.0288
24	1.1812		1.2696	1.0669	.7811	1.6766	1.3256
Max	1.6617	2.0767	1.9243	1.3146	1.9052	2.0195	1.8861
Min	.9335	.5975	.9149	.7282	.7621	1.2193	.8589
Avg	1.2990	1.4000	1.2816	.9549	1.1655	1.5776	1.2499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 205 / Chintamani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002		.5788	.6478	.5906		.5788
2	.8192		.5601	.6478	.6097		.5601
3	.7811		.5601	.6287	.6097		.5415
4	.743		.5415	.6097	.6097		.5228
5	.743		.5975	.5525	.6287		.5041
6	.7049	.6097	.6348	.5335	.6478		.4854
7	.7049		1.4563	.5525	.6859		.6161
8	.743		1.7924	.5906	.6859		.7842
9	.8764	.6668	.7842	.5906	.7811	.5906	.8215
10	.9335	1.1622	1.0669	.5975	.9526	1.3908	
11	.9709	1.1241	1.3527		1.4861	1.7528	
12	1.0082	1.1622	1.086		1.5242	1.086	
13	.9149	1.4861	.8383		1.4098	.8954	
14	1.8298	1.5623	1.1241		1.2384	1.0098	
15	1.9978		1.2384		1.4861	1.4289	1.4098
16	1.2574	1.2955	1.2955	.4481	1.5432	1.2003	1.086
17	1.3908	1.2696	1.1431	.5975	1.3908	1.2193	1.086
18	1.0098	1.307	.9717	.6287		1.1203	.8764
19	1.1241	.7377	.9145	.6287		.8029	1.0098
20		.7468	.6859	.6287		.7468	1.086
21		.6535	.6668	.6097		.5228	.9145
22		.5975	.5906	.5716		.5788	.5906
23		.5975	.6287	.5716		.5975	.6097
24	.8002		.5788	.6097	.5716	.5716	.5975
Max	1.9978	1.5623	1.7924	.6478	1.5432	1.7528	1.4098
Min	.7049	.5975	.5415	.4481	.5716	.5228	.4854
Avg	1.0077	.9986	.9037	.5919	.9696	.9697	.7727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 206 / Gainmax

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0669		1.307	1.3146	.381		.9149
2	1.105		1.2696	1.3717	.381		.8962
3	1.0479		1.2136	1.3527	.381		.8589
4	1.2003		1.2696	1.2955	.381		.8775
5	1.6956		1.4003	1.2003	.381		.8962
6	1.7909	1.467	1.7737	1.0669	.381		.9149
7	1.848		1.587	.6478	.381		.9522
8	1.8671		1.251	.5335	.362		2.2032
9	2.1338	1.3336	1.6804	.5525	.4763	.9526	2.2405
10	1.7737	2.2481	1.7909	.5228	1.0288	1.6956	
11	1.7364	2.1719	2.3053	.4854	.9145	2.3624	
12	2.0538	2.1529	1.7909	.5041	.5716	1.1622	
13	1.5497	2.191	1.4861	.5228	1.3146	1.467	
14	1.4003	2.2481	2.21	.5041	1.5813	2.1719	
15	1.1576	2.0767	2.2481		1.5813	2.191	2.2862
16	1.5242	2.0386	1.4861		1.6194	1.5623	2.1338
17	1.0288	2.0725	2.1338		1.0288	1.7718	2.0767
18	1.5623	1.587	2.0767	.381		1.8298	1.848
19	1.1431	1.475	1.9624	.3429		1.6057	1.2193
20		1.4003	1.5432	.3429		1.4003	.9717
21		1.363	1.3908	.3429		1.2136	1.0098
22		1.3817	.9526	.381		.8589	.9526
23		1.3817	1.0098	.381		.8989	.9907
24	.8764		1.3443	1.0288	.381	1.5242	.9335
Max	2.1338	2.2481	2.3053	1.3717	1.6194	2.3624	2.2862
Min	.8764	1.3336	.9526	.3429	.362	.8589	.8589
Avg	1.4781	1.7868	1.6035	.7179	.7515	1.5418	1.3251



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 411 / 33 KV I/C DBLOCK

Feeder KV- 33 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.4298		5.1532	5.5441	3.4865		4.425
2	5.5441		5.0972	5.5441	3.6008		4.425
3	5.3727		4.8731	5.4298	3.4294		4.313
4	5.2012		4.8171	5.3727	3.315		4.425
5	5.3727		4.9851	4.9154	3.315		4.369
6	5.3727	4.8011	5.4332	4.6868	3.4865		4.2353
7	5.3155	4.8583	5.8814	3.9438	3.5437		4.201
8	5.3155	4.9154	5.7133	3.4294	3.315		6.0494
9	5.8871	4.9154	6.2174	3.2007	4.401	4.6868	6.2734
10	5.9374	8.1733	6.9159	3.0807	4.3439	7.0873	
11	6.1054	7.4874	7.7161	2.4646	6.1728	8.6877	
12	6.4975	7.0873	6.5158	2.5206	6.0585	6.23	
13	5.8253	8.1162	4.9154	2.5766	7.2017	5.8871	
14	6.9456	8.4019	7.2017	2.1285	7.4303	7.0873	
15	7.1696	7.8875	7.4874	1.8484	7.4874	7.1445	7.7161
16	6.4586	7.2017	6.6301	2.3525	7.4874	7.0302	6.8587
17	6.0585	6.7776	6.8587	2.5206	6.5729	7.1445	6.8016
18	6.0014	6.6655	6.1157	3.0293		7.1696	6.6301
19	5.7156	5.9934	5.8299	3.0864		6.4415	5.487
20		5.7693	4.8011	3.0864		5.8253	4.7439
21		5.3772	4.8583	3.0293		5.2652	4.2867
22		5.0412	4.4582	3.2007		4.369	3.9438
23		5.0412	4.6296	3.1436		4.0238	4.0581
24	5.0297		5.2092	4.8011	3.2579	5.3155	4.481
Max	7.1696	8.4019	7.7161	5.5441	7.4874	8.6877	7.7161
Min	5.0297	4.8011	4.4582	1.8484	3.2579	4.0238	3.9438
Avg	5.8278	6.3617	5.7631	3.5390	4.8837	6.2122	5.1433

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 204 / INDIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.5601	.6161	.6161	.5228	.5975	.6535
2	.7468	.5041	.5975	.5975	.5228	.5601	.6348
3	.7468	.5041	.5601	.5601	.5228	.5228	.5975
4	.7095	.5041	.5601	.5228	.5228	.4854	.5601
5	.6348	.5041	.5228	.5228	.5228	.4668	.5228
6	.6348	.5228	.4854	.5601	.5228	.5041	.5228
7	.5544	.5415	.5041	.6161	.5601	.5415	.5415
8	.6653	.5601	.5415	.6535	.5228	.7095	.5415
9	.6908	.5975	.5788	.6348	.5041	.5487	.6348
10	.6722	.6908	.5975	.6348	.7095	.7865	.7468
11	.8589	.8215	.7468	.8215	.8962	.7865	.8131
12	.9709	.9335	.8402	.8589	.9335	.8779	.8871
13	.9709	1.0059	.8316	.9335	.9709	.9511	.9335
14	.9896		.8402	.8962	.9335	.9145	.9335
15	1.0082	1.1763	.6535	.8962	.9335	.8962	.9335
16	1.0082	1.0829	.8215	.8775	.9335	.9335	.2801
17	1.0082	.9522	.7095	.8589	.8688	.9335	.8589
18	1.0269	.9335	.6908	.9214	.8962	.9709	.8962
19	1.0269	1.0082	.7392	.8954	.9335	.9896	.9335
20	1.0642	1.0082	.7468	.8775	.9896	.9709	.9335
21		.8962	.6535	.8059	.8589	.8589	.8402
22		.7468	.6722		.7468	.7095	.7095
23		.6722	.6535		.6535	.6908	.6535
24	.8396	.5975	.6348	.6535	.5601	.6348	.6722
Max	1.0642	1.1763	.8402	.9335	.9896	.9896	.9335
Min	.5544	.5041	.4854	.5228	.5041	.4668	.2801
Avg	.8369	.7532	.6583	.7370	.7309	.7434	.7181

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 205 / GANESH TAIKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	.924	.961	.9979	.961	.961	.9979
2	1.2012	.9055	.961	.961	.924	.924	.9979
3	1.2012	.8871	.924	.924	.8871	.8871	.961
4	1.1827	.8871	.924	.8871	.8871	.8316	.924
5	1.1088	.8871	.8871	.8871	.8871	.7762	.8871
6	1.1088	.8871	.8686	.9055	.8871	.7947	.8686
7	1.1088	.8871	.8686	.961	.924	.8131	.924
8	.924	.8871	.8871	.961	.924	.8501	.924
9	1.0719	.8871	.924	.961	.924	.924	.924
10	1.0719	1.0903	1.1088		.9979	1.1888	.924
11	1.4045	1.2382	1.1827	1.1458	1.2567	1.1888	1.2012
12	1.4784		1.1827	1.3306	1.4784	1.2803	1.2936
13	1.5154	1.5524	1.2567	1.3676	1.4784	1.3535	1.39
14	1.4784		1.2567	1.3676	1.4784	1.3717	1.39
15	1.4901	1.7926	1.2567	1.386	1.4415	1.3717	1.4045
16	1.5684	1.7372	1.1827		1.4415	1.3717	1.3817
17	1.4784	1.3676	1.1643	1.4969	1.4415	1.4003	1.3817
18	1.5708	1.4784	1.1088	1.5708	1.4045	1.4045	1.3491
19	1.6632	1.5708	1.1458	1.5708	1.4415	1.5154	1.46
20	1.6263	1.4784	1.1458	1.4784	1.4969	1.5154	1.5154
21		1.386	1.0349	1.5524	1.386	1.2936	1.3432
22		1.1088	.9979		1.1827	1.0719	1.0534
23		.961	.9979		.9979	1.0349	.961
24	1.2936	.924	.9979	1.0349	.9979	.9979	1.0349
Max	1.6632	1.7926	1.2567	1.5708	1.4969	1.5154	1.5154
Min	.924	.8871	.8686	.8871	.8871	.7762	.8686
Avg	1.3213	1.1693	1.0511	1.1874	1.1720	1.1301	1.1455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 206 / 11 KV Industrial

GANDHINAGAR Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2096	.3239	.2667	.0381	.2858	.1905
2	.3048	.2096	.3048	.2452	.0381	.2858	.1715
3	.3048	.2096	.2858	.2286	.0381	.2667	.1715
4	.2858	.2096	.2858	.2286	.0381		.1715
5	.2667	.2096	.3048	.2263	.0381	.2096	.1715
6	.2667	.2096	.3048	.2263	.0381	.2286	.1886
7	.2667	.2667	.3048	.2286	.0381	.2096	.1905
8	.2858	.2477	.2858	.1132	.1143	.1905	.1715
9	.3048	.2667	.2477	.0381	.2096	.2096	.2286
10	.362	.3048	.3429	.0381	.2477	.4191	.2286
11	.362	.3429	.381	.0762	.4191	.4191	.381
12	.3429	.4001	.4001	.0762	.4763	.4572	.4382
13	.4191	.4572	.381	.0762	.381	.4382	.4382
14	.4001		.3239	.0953	.3429	.4572	.4382
15	.4191	.3429		.0953		.4572	.381
16	.4001	.4191	.3048	.0953	.4382	.362	.381
17	.4001	.3239	.362	.0953	.4191	.4191	.381
18	.381	.381	.3048	.0953	.4763	.381	.362
19	.381	.3429	.2667	.0953	.381	.2858	.362
20	.381	.362	.3239	.0953	.4191	.2858	.3429
21		.381	.3048	.0953	.3239	.2667	.3239
22		.3048	.2667		.3048	.2286	.2286
23		.2858	.2858		.2858	.2286	.1905
24	.3429	.2096	.3239	.2667	.0381	.2477	.1905
Max	.4191	.4572	.4001	.2667	.4763	.4572	.4382
Min	.2667	.2096	.2477	.0381	.0381	.1905	.1715
Avg	.3420	.2999	.3139	.1408	.2410	.3148	.2801

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 401 / 33KV Gandhinagar I/C  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8649	3.2036	2.5766	2.4646	2.0513	2.4897	2.4086
2	3.8089	3.1493	2.5463	2.3525	1.9959	2.3765	2.3525
3	3.7529	3.1493	2.3765	2.2405	1.9404	2.2634	2.2405
4	3.6037	3.1493	2.4086	2.1285	1.9404	2.1502	2.1285
5	3.7146	3.2036	2.4331	2.1845	1.9404	2.037	2.1285
6	3.8255	3.3122	2.3525	2.3525	1.9959	2.1502	2.2068
7	3.8255	3.4208	2.3525	2.4086	2.1068	2.2068	2.2405
8	2.6057	3.4751	2.3525	2.2965	2.1068	2.2068	2.2405
9	2.6326	2.2965	2.2965	2.1845	2.1068	2.2405	2.3525
10	2.7446	2.7161	2.6612	2.9687	3.3122	3.6969	2.7446
11	3.3048	3.0807	2.9687	3.3608	4.0181	3.5848	3.1927
12	3.4728	3.4728	3.1367	3.678	4.2896	3.6969	3.4168
13	3.5848	3.7529	3.1367	3.6969	4.2353	4.0889	3.5288
14	3.5848		3.4374	2.9687	4.1152	4.0329	3.5288
15	3.6408	4.145	2.8275	2.2405	4.225	4.0329	3.4728
16	3.7529	4.0472	2.9384	2.2405	4.2798	3.9209	3.3608
17	3.6408	3.1927	2.8275	3.1927	4.1152	3.9769	3.4168
18	3.7529	3.4728	2.7721	3.1602	3.4168	3.4168	
19	3.8649	3.6408	2.8275	3.1927	3.4168	3.4728	3.4374
20	3.9209	3.6408	2.9938	3.1602	3.6969	3.4728	3.4928
21		3.4168	2.6612	3.1047		3.0807	3.271
22		2.9127	2.6886			2.6886	2.7166
23		2.6886	2.6326		2.6326	2.5766	2.4714
24	4.0329	3.2036	2.6326	2.5766	2.1622	2.5206	2.5206
Max	4.0329	4.145	3.4374	3.6969	4.2896	4.0889	3.5288
Min	2.6057	2.2965	2.2965	2.1285	1.9404	2.037	2.1285
Avg	3.5682	3.2932	2.7016	2.7343	3.0046	3.0159	2.8205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 201 / 11KV SARALASHKAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8573		.8573	.8573	.9526	.8573
2	.7621	.7621		.8573	.9526	.8573	.7621
3	.7621	.7621		.7621	.9526	.8573	.8573
4	.7621	.7621		.7621	.8573	.7621	.7621
5	.8573	.7621		.7621	.7621	.8573	.7621
6	.8573	.8573		.7621	.8573	.8573	.8573
7	.9526	.8573		.7621	.8573	1.1431	.9526
8	1.4289	1.0479	.8573	.8573	.9526	1.1431	1.2384
9		1.2384	1.2384	.7621	.9526	1.5242	1.3336
10		1.7147	1.7147	.8573	1.5242	1.6194	1.6194
11		1.3336	1.7147	.8573	1.5242	1.4289	1.6194
12		1.6194	1.6194	.8573	1.6194	1.2384	1.6194
13		1.6194	1.4289	.8573	1.5242	1.4289	1.4289
14		1.7147	1.3336	.8573	1.8099	1.5242	1.4289
15		1.6194	1.5242	.8573	1.7147	1.7147	1.8099
16	1.7147	1.3336	1.4289	.8573	1.6194	1.5242	1.7147
17	1.5242	1.5242	1.5242	.8573	1.3336	1.5242	1.6194
18	1.1431		1.1431	.8573	1.1431	1.1431	1.5242
19	1.0479		1.3336	.9526	1.4289	1.4289	1.1431
20	1.1431		1.3336	.9526	1.2384	1.1431	.9526
21	1.4289		1.3336	.8573	1.1431	.9526	1.3336
22	1.3336		.9526	.8573	1.0479	1.2384	.9526
23	1.3336		1.1431	.9526	.9526	.9526	.7621
24	.8573	.9526		.9526	.9526	.8573	.8573
Max	1.7147	1.7147	1.7147	.9526	1.8099	1.7147	1.8099
Min	.7621	.7621	.8573	.7621	.7621	.7621	.7621
Avg	1.0983	1.1855	1.3515	.8494	1.1907	1.1947	1.1987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 202 / 11 KV MAULI FEEDER MIDC SHEDDABLE FEEDER HAVING WEEKLY  
 Shirol Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8573		.9526	.9526	.8573	.7621
2	.9526	.8573		.8573		.8573	.7621
3	.8573	.8573		.7621	.9526	.8573	.7621
4	.8573	.7621		.7621	.9526	.8573	.8573
5	.9526	.7621		.8573	.9526	.8573	.8573
6	.9526	.8573		.8573	.9526	.8573	.8573
7	.9526	.8573		.8573	.9526	.8573	.8573
8	.9526	.9526	.9526	.9526	.9526	.8573	.8573
9		1.0479	.9526	.8573	1.1431	.9526	1.0479
10		1.2384	.8573	.9526	1.1431	1.1431	1.2384
11		1.3336	1.0479	.8573	1.1431	1.2384	1.2384
12		1.0479	1.1431	.8573	1.1431	.9526	1.2384
13		1.1431	1.1431		.9526	.9526	1.0479
14		1.1431	1.1431	.8573	1.2384	1.1431	1.2384
15		1.1431	1.1431	.8573	1.2384	1.1431	1.1431
16	1.2384	1.0479	1.1431	.8573	.9526	1.0479	1.1431
17	1.0479	.9526	.9526	.9526	.9526	.9526	.9526
18	.9526		.8573	.8573	.9526	.9526	.9526
19	.9526		.8573	.9526	.8573	.9526	.9526
20	.9526		.8573	.9526	.9526	.9526	.8573
21	.9526		.8573	.9526	.9526	.8573	.9526
22	.9526		.9526	.9526	.9526	.9526	.8573
23	.9869		.9526	.9526	.8573	.8573	.9526
24	.9697	.9526		.9526	.9526	.8573	.8573
Max	1.2384	1.3336	1.1431	.9526	1.2384	1.2384	1.2384
Min	.8573	.7621	.8573	.7621	.8573	.8573	.7621
Avg	.9668	.9896	.9883	.8905	1.0023	.9486	.9685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 203 / G' BLOCK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.4289		1.3336	1.4289	1.4289	1.3336
2	1.4289	1.3336		1.3336	1.3336	1.4289	1.4289
3	1.5242	1.3336		1.4289	1.3336	1.3336	1.3336
4	1.3336	1.3336		1.3336	1.3336	1.3336	1.2384
5	1.3336	1.4289		1.4289	1.5242	1.3336	1.3336
6	1.3336	1.4289		1.4289	1.5242	1.5242	1.4289
7	1.6194	1.4289		1.4289	1.5242	1.5242	1.3336
8	1.7147			1.3336	1.6194	1.6194	1.5242
9		1.7147	2.191	1.3336	1.5242	2.191	2.191
10		2.4768	2.4768	1.3336	1.6194	2.0957	2.6673
11		2.6673	2.3815	1.3336	1.5242	2.6673	2.6673
12		2.191	2.0957	1.3336	1.6194	2.191	2.572
13		2.2862	2.4768	1.4289	2.0957	1.8099	1.8099
14		2.4768	.2477	1.4289	2.4768	2.0957	2.2862
15		2.2862	2.3815	1.4289	2.3815	2.4768	2.3815
16	2.191	2.2862	2.191	1.4289	2.3815	2.3815	2.4768
17	1.9052	2.0957	2.191	1.3336	2.0957	2.191	2.2862
18	1.4289		1.6194	1.4289	1.5242	2.0005	1.9052
19	1.4289		1.5242	1.4289	1.4289	1.5242	1.5242
20			1.5242	1.4289	1.4289	1.5242	1.3336
21	1.4289		1.3336	1.5242	1.4289	1.3336	1.4289
22	1.4289		1.4289	1.5242	1.4289	1.3336	1.3336
23	1.4289		1.4289	1.5242	1.3336	1.4289	1.4289
24	1.4289	1.4289		1.4289	1.5242	1.5242	1.4289
Max	2.191	2.6673	2.4768	1.5242	2.4768	2.6673	2.6673
Min	1.3336	1.3336	.2477	1.3336	1.3336	1.3336	1.2384
Avg	1.5301	1.8604	1.8328	1.4051	1.6432	1.7623	1.7782



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV Maharashtra Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.7621		.7621	.5716	.9526	.7621
2	.9526	.7621		.7621	.5716	.7621	.8573
3	.8573	.7621		.8573	.5716	.7621	.8573
4	.7621	.6668		.7621	.5716	.7621	.7621
5	.8573	.6668		.8573	.5716	.7621	.7621
6	.8573	.7621		.8573	.5716	.7621	.8573
7	.6668	.6668		.9526	.5716	.8573	.9526
8	.5716	.6668		.6668	.6668	.7621	.9526
9		.7621	1.0479	.5716	.6668	.8573	.9526
10		.7621	1.0479	.381	.5716	.6668	.6668
11		.7621	.9526	.381	.5716	.5716	.6668
12		.7621	.8573	.381	.5716	.6668	.6668
13		.7621	.8573	.381	.6668	.6668	.6668
14		.7621	.7621	.381	.7621	.6668	.7621
15		.7621	.6668	.381	.7621	.6668	.6668
16	.7621	.7621	.7621	.381	.6668	.7621	.7621
17	.6668	.4763	.6668	.5716	.6668	.7621	.6668
18	.6668		.8573	.5716	.9526	.9526	.7621
19			.8573	.5716	.9526	.9526	.9526
20	.6668		.7621	.5716	.9526	.9526	.7621
21	.7621		.7621	.6668	.9526	.7621	.9526
22	.6668		.9526	.6668	.9526	.9526	.8573
23	.6668		.9526	.5716	.9526	.8573	.7621
24	.9526	.7621		.9526	.5716	.9526	.7621
Max	.9526	.7621	1.0479	.9526	.9526	.9526	.9526
Min	.5716	.4763	.6668	.381	.5716	.5716	.6668
Avg	.7680	.7250	.8510	.6192	.7026	.7938	.7938

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 206 / DEVAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.3336		1.3336	.5716	1.5242	1.3336
2	1.1431	1.3336		1.3336	.5716	1.4289	1.4289
3	1.2384	1.2384		1.3336	.5716	1.4289	1.4289
4	1.3336	1.2384		1.1431	.5716	1.3336	1.3336
5	1.3336	1.2384		1.3336	.5716	1.5242	1.2384
6	1.4289	1.2384		1.5242	.5716	1.7147	1.2384
7	1.5242	1.6194		1.2384	.5716	1.3336	1.3336
8	1.1431	1.2384		1.2384	.5716	1.9052	.5716
9		2.0957	2.191	1.0479	1.5242	2.0957	2.0005
10		1.9052	2.2862	.7621	1.7147	2.0957	1.7147
11		2.0005	2.2862	.7621	2.2862	2.6673	2.0957
12		1.7147	1.7147	.6668	2.572	2.7625	2.191
13		2.0957	2.0957		2.4768	1.6194	1.4289
14		2.191	2.3815		2.6673	1.7147	1.4289
15		2.0957	1.8099		2.572	1.9052	2.191
16	2.0957	2.0957	1.9052	.6668	2.572	1.9052	2.3815
17	2.4768	1.3336	1.4289	.5716	2.0957	2.6673	1.4289
18	1.9052		1.3336	.5716	2.0005	2.0005	2.191
19	1.7147		1.3336	.5716	1.9052	1.5242	2.2862
20	1.9052		1.3336	.5716	2.0957	1.9052	1.9052
21	1.3336		1.1431	.5716	1.9052	1.5242	1.9052
22	1.7147		1.7147	.5716	2.191	1.1431	1.7147
23	1.7147		1.5242	.5716	1.4289	1.3336	1.7147
24	1.3336	1.6194		1.5242	.5716	1.5242	1.5242
Max	2.4768	2.191	2.3815	1.5242	2.6673	2.7625	2.3815
Min	1.1431	1.2384	1.1431	.5716	.5716	1.1431	.5716
Avg	1.5634	1.6459	1.7655	.9481	1.5480	1.7742	1.6671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 401 / 33KV MIDC SHIROLI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.2584	5.144	5.2584		5.7156	5.0297
2		5.0297	4.9726	5.144		5.3155	5.2584
3		4.9726	4.7439	5.144		5.2584	5.2584
4		4.7439	4.7439	4.7439		5.0297	4.9726
5		4.8583	5.144	5.2584		5.3155	4.9726
6		5.144	4.9726	5.4298		5.7156	5.2584
7		5.4298	4.9726	5.2584		5.7156	5.4298
8		5.3155	6.0014	5.0297		6.2872	5.144
9		6.8587	5.7156	4.5725	5.8299	7.6017	7.5446
10		8.1162		4.2867	4.6868	7.6017	7.8875
11		8.1162		4.1724	7.0302	8.5734	8.2876
12		7.316		4.1152	7.5446	7.8304	8.2876
13		7.8875		4.1724	7.7161	6.4586	6.4015
14		8.2876		4.1724	8.9735	7.1445	7.1445
15				4.1724	8.6877	7.8875	
16	8.0018				8.1733	7.6017	8.4591
17	7.6017				7.1445		6.973
18	6.1157				6.5729	7.0302	7.316
19	5.8299				6.5729	6.4015	6.8587
20	4.6868				6.6873	6.4586	5.8299
21	5.8871				6.4015	5.4298	6.5729
22	6.1157				6.5729	5.6013	5.7156
23	6.1157				5.5441	5.4298	5.6013
24	5.2669	5.7156	5.2584	5.8299		5.7156	5.4298
Max	8.0018	8.2876	6.0014	5.8299	8.9735	8.5734	8.4591
Min	4.6868	4.7439	4.7439	4.1152	4.6868	5.0297	4.9726
Avg	6.1801	6.2033	5.1669	4.7975	6.9425	6.3965	6.3319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 201 / 11KV TOUGH CASTING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.724	.724	.5906	.5335	.6478	.6097
2	.6287	.743	.6668	.5906	.5144	.6097	.5906
3	.6097	.7621	.6478	.5716	.4763	.5716	.5716
4	.6097	.6668	.5525	.5525	.4954	.5335	.5716
5	.6668	.6287	.5525	.5525	.5716	.5716	.5906
6	.6859	.6097	.6097	.5525	.5525	.6478	.5906
7	.743	.6097	.6668	.5716	.6097	.6859	.5716
8	.7049	.5716	.6478	.5906	.5906	.6478	.6287
9	.7811	.724	.7811	.5716	.5144	.8383	.6859
10	1.086	1.0288	.6859	.5906		.8764	.9526
11	.9335	.8002	1.0098	.6097		.743	1.0288
12	.7621	.743	1.1431	.6287		1.1431	1.086
13	.6668	.743	1.0288	.6478		.8192	.9907
14	.8002	1.0479	1.0098	.6478		1.2193	.8383
15	.8192	.6478	1.2003	.6478		1.0098	.6668
16	.6287	.6668	.8002	.6287		1.1812	.9145
17	.724	.8954	.8192	.6478		.9907	.9526
18	.7811	.8954	.8383	.6668		1.1622	1.105
19	.6097	.8192	.6478	.6668	.724	1.086	.6097
20		.724	.6287	.6668	.5525	.8764	.724
21	.7811	.6287	.6097	.6478	.7049	.7621	.6668
22	.6287	.8002	.6097	.6097	.6859	.5906	.6859
23	.7811	.7811	.6287	.5906	.5906	.6859	.7049
24	.6859	.7621	.7621	.6097	.5716	.6097	.6478
Max	1.086	1.0479	1.2003	.6668	.724	1.2193	1.105
Min	.6097	.5716	.5525	.5525	.4763	.5335	.5716
Avg	.7298	.7510	.7613	.6105	.5792	.8129	.7494

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 202 / 11KV ACCURATECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5623	1.1812	1.2003	.724	1.6385	1.448
2	1.5242	1.5242	1.105	1.3146	.724	1.5623	1.3717
3	1.4289	1.4289	.9145	1.3336	.6478	1.6004	***
4	1.467		.9335	1.2955	.6097	1.5242	1.4098
5	1.6004	1.3336	.9907	1.3717	.724	1.6766	1.3717
6	1.5432	1.2955	1.0288	1.2384	.7621	1.6956	1.3908
7	1.448	1.0288	1.0669	1.1812	.8002	1.5623	1.3146
8	1.3527	1.4861	1.5813	1.1431	.8383	1.3527	1.3336
9	1.6766	1.6956	1.7147	.7811	1.4098	1.2003	1.1431
10	1.3908	1.6004	1.3527	.743		1.086	1.6956
11	1.3146	1.2384	1.2193	.724		1.8099	1.6194
12	1.2765	1.6194	1.5432	.743		1.6766	1.3908
13	1.2193	1.7337	1.2574	.8002		1.1812	1.6004
14	1.3146	1.6956	1.7718	.7811		1.4098	1.848
15	1.7718	1.7147	1.7337	.7621		1.829	1.7909
16	1.7718	1.6575	1.7337	.8192		1.3527	1.8099
17	1.6004	1.3908	1.7147	.8764		1.7147	1.6004
18	1.6385	1.5242	1.6766	.8764		1.7528	1.3146
19	1.6766	1.6385	.8764	.8954		1.7147	1.7147
20		1.3717	1.5623	.8192		1.6575	1.6385
21	1.5432	1.086	1.5432	.8192		1.7337	1.6194
22	1.5813	1.1241	1.5813	.8002		1.6385	1.6385
23	1.5813	1.5051	1.5242	.8002		1.6194	1.6004
24	1.5623		1.4098	1.2384	.7621	1.6004	1.4289
Max	1.7718	1.7337	1.7718	1.3717	1.4098	1.829	18.5566
Min	1.2193	1.0288	.8764	.724	.6097	1.086	1.1431
Avg	1.5134	1.4661	1.3757	.9732	.8002	1.5662	2.2354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 203 / 11KV SHIROLI PULACHI  
(RENUKA-N Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.2096	.2096	.1715	.1905	.2096
2	.1905	.1905	.1905	.1905	.1524	.1715	.1905
3	.1715	.1524	.1715	.1715	.1524	.1524	.1905
4	.1524	.1715	.1524	.1715	.1715	.1524	.1715
5	.1524	.2286	.1524	.1905	.2096	.1715	.1715
6	.1715	.2096	.2096	.2096	.2286	.1905	.2096
7	.2286	.2286	.2286	.2286	.2096	.1905	.2096
8	.2667	.2286	.2286	.2477	.2286	.2096	.2477
9	.3048	.2858	.2858	.2286	.2477	.2286	.2858
10	.3429	.3048	.2667	.2286		.2286	.2667
11	.3429	.3048	.3048	.2286		.2667	.2477
12	.3239	.2667	.2477	.2096		.2477	.2286
13	.3048	.3048	.2667	.2477		.2858	.2286
14	.3048	.3048	.3048	.2477		.2858	.2286
15	.2858	.3048	.2667	.2286		.2667	.2286
16	.3239	.2858	.2667	.2096		.2858	.2286
17	.3239	.2096	.3048	.1715		.2858	.2477
18	.3048	.2477	.2667	.1715		.2667	.2096
19	.3048	.2477	.3048	.2096	.2667	.2667	.2286
20		.2858	.2858	.2286	.2477	.2477	.2477
21	.2667	.2858	.2667	.2286	.2477	.2286	.2286
22	.2667	.2858	.2477	.2286	.2667	.2286	.2477
23	.2477	.2667	.2286	.2096	.2477	.2286	.2286
24	.2286	.2286	.2667	.2286	.1905	.2096	.2286
Max	.3429	.3048	.3048	.2477	.2667	.2858	.2858
Min	.1524	.1524	.1524	.1715	.1524	.1524	.1715
Avg	.2609	.2508	.2469	.2135	.2159	.2286	.2255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 204 / 11KV SAGAR SHOT BLASTING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.743	.724	.6668	.6097	.5716	.7621	.724
2	.724	.7049	.6097	.5906	.5906	.8002	.7049
3	.724	.7621	.6478	.5716	.4763	.724	.6668
4	.6859	.6668	.5716	.5335	.5335	.8383	.724
5	.743	.724	.5525	.5335	.5716	.8764	.743
6	.8573	.6668	.6859	.5525	.6097	.8002	.7621
7	.9145	.7049	.7621	.5716	.6287	.8573	.8002
8	.9526	.7621	.9145	.6287	.7049	.8764	.8573
9	1.2003	.9145	.9717	.6287	.8002	.9907	.8002
10	1.105	.9526	1.0669	.6478		1.105	.9526
11	1.2003	.9717	1.0479	.6097		1.105	.9907
12	1.1431	.8383	.9526	.6097		1.0479	.9145
13	1.0479	.9145	.9717	.6478		1.0479	
14	1.0288	.8192	1.0669	.6097		1.086	.9145
15	1.105	.8573	1.086	.6097		1.105	.9526
16	.8383	.8764	1.1241	.6097			.9145
17	.9335	.7811	.9526	.6287		1.0479	.9335
18	.8002	.7811	.8954	.6287		.9717	.8383
19	.8192	.7049	.8573	.6478	.6859	.9145	.8192
20		.724	.6478	.6287	.743	.8192	.8192
21	.724	.743	.6287	.6478	.7049	.7621	.7621
22	.7049	.724	.6097	.6287	.7621	.7049	.8573
23	.7049	.6478	.6287	.6097	.724	.7621	.7811
24	.7621	.7621	.7049	.6287	.6097	.8002	.7621
Max	1.2003	.9717	1.1241	.6478	.8002	1.105	.9907
Min	.6859	.6478	.5525	.5335	.4763	.7049	.6668
Avg	.8896	.7803	.8177	.6089	.6478	.9046	.8259

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 205 / 11KV CHOUGULE FOUNDRY  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18	02-JUN-18	03-JUN-18	04-JUN-18	05-JUN-18	06-JUN-18	07-JUN-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.4768	2.0957	2.2862	1.2193	1.9052	2.3434
2	2.3053	2.2862	2.0386	1.9243	.9907	1.6575	2.2672
3	2.1529	2.191	1.9433	1.8099	.6859	1.6004	2.0957
4	2.1338	2.4768	1.6004	1.7337	.8383	1.5051	2.0195
5	1.9052		1.8099	1.6004	.9907	1.6956	2.191
6	1.848	1.9052	2.553	1.8671	1.1622	1.6004	2.2862
7	2.0957	1.6004	2.7054	2.0957	1.467	1.6575	2.1529
8	2.191	2.3243	2.21	1.9433	1.4098	.9717	1.9243
9	2.9912	3.1817	2.3434	1.3527	2.6292	2.4958	2.915
10	3.2007	2.5339	2.4387			2.4387	3.2388
11	2.0005	2.4958	3.1245	1.0479		3.1436	3.1055
12	3.1055	1.6575	1.9624	1.0288		1.6766	2.4006
13	2.9721	1.6385	1.7718	.8002		2.3053	2.5149
14	3.296	3.0483	3.3913	.8573		3.2198	2.572
15	3.2198	3.2388	2.6482	1.0479		2.934	3.2007
16	2.4387	2.4006	3.0293	.8573		1.5432	3.2388
17	2.7435	2.6292	2.553	.743		3.0674	2.8578
18	2.915	3.0293	2.9721	1.0479		3.0293	2.9912
19	2.3243	2.5339	3.0864	.724	1.9243	2.7054	2.5911
20		2.4387	1.6766	.8573	1.105	2.915	2.3053
21	2.2862	2.3434	1.5623	.724	1.5432	2.6482	2.9721
22	2.6673	2.3815	1.6956	.9907	2.3624	2.4387	1.6956
23	2.2481	1.7909	1.5813	1.1812	2.1338	3.1436	2.8959
24	2.8769	2.7625	2.191	2.7625	1.105	2.2481	2.6673
Max	3.296	3.2388	3.3913	2.7625	2.6292	3.2198	3.2388
Min	1.848	1.6004	1.5623	.724	.6859	.9717	1.6956
Avg	2.5405	2.4072	2.2910	1.3601	1.4378	2.2728	2.5601



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 401 / 33KV Gandhinagar

Feeder KV- 33 / INCOMING

DATE	01-JUN-18
HR	Load (MW)
24	1.9605
Max	1.9605
Min	1.9605
Avg	1.9605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 405 / Shahumill

Feeder KV- 33 / INCOMING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	5.7065
Max	5.7065
Min	5.7065
Avg	5.7065

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146001 / 132/33 KV BAPAT CAMP

Feeder No / Name : 407 / 33KV Bapat Camp Minor  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
24	3.9209
Max	3.9209
Min	3.9209
Avg	3.9209

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 203 / Panchganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
1	.381
24	.3696
Max	.381
Min	.3696
Avg	.3753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirol i S/stn

Feeder No / Name : 204 / MAHALAXMI EHV Shirol i  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
1	.7811
24	.7682
Max	.7811
Min	.7682
Avg	.7747

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 205 / 11KV HIGHWAY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
1	2.9912
24	3.1508
Max	3.1508
Min	2.9912
Avg	3.071

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 206 / JUMBO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
1	2.3434
24	2.3777
Max	2.3777
Min	2.3434
Avg	2.3606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirol i S/stn

Feeder No / Name : 207 / 11KV SWARAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-JUN-18
HR	Load (MW)
1	2.3434
24	2.2731
Max	2.3434
Min	2.2731
Avg	2.3083



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 401 / 33 KV MPM

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
24	4.4993
Max	4.4993
Min	4.4993
Avg	4.4993

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 403 / 33KV Shirolī Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
1	4.8011
24	4.6091
Max	4.8011
Min	4.6091
Avg	4.7051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirol i S/stn

Feeder No / Name : 404 / 33KV D Block

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-JUN-18
HR	Load (MW)
1	4.8011
24	4.6571
Max	4.8011
Min	4.6571
Avg	4.7291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 405 / 33 KV Saroj

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
1	9.6022
24	9.1221
Max	9.6022
Min	9.1221
Avg	9.3622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 406 / 33 KV Kolhapur Steel  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-JUN-18	04-JUN-18
HR	Load (MW)	Load (MW)
1	.2858	
24		.2715
Max	.2858	.2715
Min	.2858	.2715
Avg	.2858	.2715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 01-JUN-18 and 07-JUN-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 407 / Hind Gear

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-JUN-18
HR	Load (MW)
1	2.4006
Max	2.4006
Min	2.4006
Avg	2.4006