

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 201 / 11 KV AJARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.3292	.3658	.2896	.3077	.3258
2	.362	.3258	.362	.2715	.2896	.2896
3	.362	.3292	.362	.2715	.2896	.2896
4	.3658	.3155	.362	.2715	.2715	.2896
5	.439	.3841	.4207	.2715	.2715	.2896
6	.4938	.4207	.4706	.362	.4525	.4525
7	.6036	.6219	.5611	.4656	.5611	.543
8	.7133	.6584	.6036	.543	.5611	.5973
9	.6878	.6697		.5731	.583	.6722
10	.7421	.7468		.5792	.6687	.7011
11	.7964	.8326		.5973	.7095	.8688
12	.7888	.7373		.5068	.5973	.8779
13	.6516	.695		.5304	.6767	.7316
14	.6173	.6584		.4938	.5853	.7499
15	.6859	.6516		.5121	.7133	.6767
16	.6173	.6878		.5068	.6767	.7059
17	.6516	.6516		.5487	.7499	.7316
18	.7545	.7059		.6219	.6584	.7499
19	.9114	.8779		.7865	.8596	.8779
20	.8573	.8413		.7682	.8413	.8596
21	.8413	.823		.7059	.7701	.7783
22	.7316	.7316		.5611	.6335	.6335
23	.5304	.5487		.362	.4706	.4163
24	.4207	.3658	.4024	.3077	.3258	.3801
Max	.9114	.8779	.6036	.7865	.8596	.8779
Min	.362	.3155	.362	.2715	.2715	.2896
Avg	.6262	.6087	.4345	.4878	.5635	.6037

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 202 / 11 KV Bhadvan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1475	1.7013	1.0288	.1772	.1595	.1417
2	.1475	1.5927	.9945	.1772	.1417	.1417
3	.1475	1.5364	.9945	.1772	.1417	
4	.1475	1.448	.9945	.1772	.1417	
5	.1475	1.5181	1.0974	.1595	.1417	
6	.1638	1.5912	1.2517	.1417	.1595	.1417
7	.1475	2.0302	1.5729	.1417	.1595	
8	.1475	1.6804	1.5261	.1772	.1949	.1772
9	2.1605	.2303		1.5089	1.7147	1.9909
10	2.692	.2126		2.0062	2.3348	2.5579
11	3.1036	.2126		2.2634	2.2977	2.3529
12	3.1207	.1886		2.2805	2.1658	2.572
13	3.1036	.1543		2.0919		2.5549
14	2.9664	.1543		2.2862	2.4143	2.7618
15	3.0864	.181		2.1765	2.5423	2.7801
16	2.8464	.2279		2.2081	2.4691	2.652
17	.0343	.1991		.1966	.0164	.2035
18	.0343	.2572		.1865	.0164	.2294
19		.2353		.2229	.0164	.1966
20	.12	.2103		.2294	.2401	.1966
21	.1311	.1802		.1949	.1949	.2126
22	.1311	.1696		.1772	.1595	.1772
23	1.6644	1.0608		.1595	.1417	.1595
24	.1638	1.6975	1.046	.1949	.1595	.1417
Max	3.1207	2.0302	1.5729	2.2862	2.5423	2.7801
Min	.0343	.1543	.9945	.1417	.0164	.1417
Avg	1.1546	.7779	1.1674	.8214	.7880	1.1171

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 203 / POLGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.1017	.1017	.9745	1.3289	1.3496
2	1.3169	.1017	.1017	.9568	1.3112	1.3289
3	1.267	.1017	.1017	.9568	1.2757	1.2757
4	1.2803	.1017	.1017	.9568	1.2757	1.2757
5	.8882	.1017	.1017	.9745	1.2757	1.2757
6	1.3998	.1017	.1017	1.0099	1.3289	1.3112
7	1.6461	.1357	.1017	1.0808	1.4022	1.5775
8	1.6461	.1187	.1017	1.0341	1.5074	1.5769
9	.1949	1.869		.0886	.0747	.0857
10	.124	2.2291		.0532	.0914	.0543
11	.1063	2.4348			.0732	.0549
12	.0857	2.5377			.0732	.0549
13	.0857	2.2462			.0509	.0509
14	.0914	2.1434			.0492	.0492
15	.0514	2.1262			.0492	.0492
16	.0514	2.1605			.0678	.0678
17	.0514	.0343			.0655	.0655
18	.0857	.0905			.0678	.0655
19	.128	.1267			.1017	.081
20	.12	.1097			.1187	.0848
21	.1187	.1147			.0886	.0886
22	.1147	.1147		.1063	.0886	.0886
23	.1187	.1017		1.4352	1.6124	1.5775
24	1.4815	.1017	.1017	.9745	1.3466	1.5775
Max	1.6461	2.5377	.1017	1.4352	1.6124	1.5775
Min	.0514	.0343	.1017	.0532	.0492	.0492
Avg	.5761	.8086	.1017	.8155	.6136	.6278

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 204 / 11 KV Watangi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7558	.2458	.2572	1.9631	2.0683	2.0233
2	1.7013	.2294	.2543	1.9456	2.0332	1.989
3	1.6289	.2294	.2294	1.9281	2.0199	1.9547
4	1.6289	.2374	.2374	1.9281	2.0199	1.9376
5	1.6827	.2294	.2374	1.9631	1.9845	
6	1.7375	.2458	.2543	1.9418	2.1033	
7	1.8099	.2622	.3052	2.0919	2.3232	.5138
8	2.0119	.2713	.2883	1.9765	2.2462	.5138
9	.2835	1.9719		.3189		
10	.2835	2.3834		.3189	.0514	.2353
11	.2658	2.332			.0343	.2279
12	.2743	2.332			.2572	.2561
13	.2572	2.3148			.2543	.2204
14	.2743	2.5206			.2713	.2204
15	.2401	2.4348				.2374
16	.0171	2.726			.2543	.2572
17	.2915	.2229			.2543	.2658
18	.3258	.2715			.2883	.2374
19	.2572	.333		.2915	.2915	.2926
20	.2743	.2915		.3086		.2915
21	.2622	.2883		.3189	.3189	.3189
22	.2622	.3052		.3189	.3189	.3012
23	.2622	.2785		2.1434	2.1091	2.4348
24	1.8473	.2622	.2713	1.9806	2.1033	2.0405
Max	2.0119	2.726	.3052	2.1434	2.3232	2.4348
Min	.0171	.2229	.2294	.2915	.0343	.2204
Avg	.8181	.9675	.2594	1.3586	1.1241	.7986



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 205 / 11 KV WATANGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.2103	.2401	.2172	.2896	.2353
2	.2058	.2103	.2058	.2172	.2715	.2172
3	.2012	.2058	.2058	.2172	.2715	.2172
4	.1991	.2058	.2058	.1991	.2534	.2172
5	.2561	.2374	.2572	.1991	.2534	.2172
6	.2926	.2926	.3258	.3077	.362	.3077
7	.4572	.4115	.463	.4163	.4835	.4656
8	.5304	.4801	.5121	.4656	.5014	.5316
9	.5249	.5068		.4298	.5487	.5316
10	.4525	.4887		.3801	.5658	.5611
11		.4706			.5121	.4344
12	.2743	.4458				.4801
13	.2915	.3601			.0492	.463
14	.4115	.3258			.0339	.4755
15	.3601	.2743				.3292
16	.3772	.2401			.3841	.3841
17	.2743	.3429			.6036	.4938
18	.4458	.4801			.567	.5249
19	.7373	.7059		.7682	.7964	.7316
20	.8745	.8059		.9511	1.0059	.9145
21	.7783	.7133		.7602	.7701	.7796
22	.6219	.5487		.543	.4887	.543
23	.3801	.3841		.3439	.3077	.2896
24	.2715	.2378	.2743	.2353	.3077	.2534
Max	.8745	.8059	.5121	.9511	1.0059	.9145
Min	.1991	.2058	.2058	.1991	.0339	.2172
Avg	.4097	.3994	.2989	.4157	.4376	.4416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 206 / 11 KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0509	.0328	.0509	.0187	.0187	.056
2	.0492	.0339	.0509	.0187	.0187	.056
3	.0509	.0339	.0509	.0187	.0187	.056
4	.0492	.0328	.0514	.0187	.0187	.056
5	.0492	.0339	.0509	.0187	.0187	.056
6	.0492	.0492	.0509	.0187	.0187	.056
7	.0549	.0492	.0509	.0187	.0373	.0554
8	.0678	.0509	.0339	.0187	.0373	.0187
9	.0747	.0747		.0187	.0686	.0362
10	.0747	.0747		.0187	.0686	.1029
11	.0934	.0747		.0373	.0914	.1097
12	.0857	.1029		.0187		.1086
13	.0857	.0857		.017	.1017	.1017
14	.1029	.1029		.0164	.1017	.1017
15	.0686	.0686		.0678	.0983	.1017
16	.1029	.0701		.0328	.0848	.1187
17	.0857	.0686		.0339	.0848	.1017
18	.1029	.0686		.0328	.0848	.1017
19	.1029	.0701		.0492	.0848	.0819
20	.0686	.0526		.0509	.0848	.0848
21	.0678	.0509		.0187	.056	.056
22	.0509	.0339		.0187	.0187	.0187
23	.0328	.0328		.056	.056	.0187
24	.0655	.0492	.0509	.0187	.0187	.056
Max	.1029	.1029	.0514	.0678	.1017	.1187
Min	.0328	.0328	.0339	.0164	.0187	.0187
Avg	.0703	.0582	.0491	.0273	.0561	.0713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 207 / 11 KV Bhadvan Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.1886	.2058	.1991	.1991	.1829
2	.1865	.1886	.1886	.181	.181	.1646
3	.1696	.1886	.1886	.1772	.1829	.1646
4	.1715	.1886	.1886	.181	.1646	.1646
5	.2058	.2058	.2353	.181	.1646	.1646
6	.2572	.2401	.2572	.2172	.2896	.2534
7	.2743	.3429	.3601	.2715	.362	.3224
8	.3841	.3944		.3439	.3801	.3982
9	.362	.3801		.3045	.4207	.3772
10	.4163	.3439		.3077	.3801	.4163
11	.362	.3258			.2926	.3772
12	.3258	.3086			.2896	.3155
13	.2915	.2743		.2058		.3086
14	.2572	.2572		.181	.2561	.2743
15	.2915	.2572		.1696	.3258	.3077
16	.2743	.2572		.1886	.3601	.2926
17	.2896	.2401		.2058	.3292	.3292
18	.3258	.3258		.3109	.3841	.362
19		.4973		.5304	.5304	.567
20	.7373	.631		.6516	.7499	.6584
21	.6154	.5316		.5552	.5731	.567
22	.4938	.4706		.3801	.3801	.4075
23	.3077	.2926		.2353	.2534	.2534
24	.2058	.2058	.2378	.1991	.1991	
Max	.7373	.631	.3601	.6516	.7499	.6584
Min	.1696	.1886	.1886	.1696	.1646	.1646
Avg	.3215	.3140	.2328	.2808	.3325	.3317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 201 / 11KV UtturVg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5415	.4108	.5175	.5014	.6348	.5731	.5544
2	.5228	.3734	.4805	.5014	.5975	.5373	.5175
3	.4668	.3696	.4805	.5014	.5228	.5014	.4805
4	.5041	.3326	.4805	.5014	.5228	.5014	.4805
5	.5975	.3734	.5175	.6089	.5601	.6447	.5544
6	.6908	.5041	.6283	.6805	.6348	.788	.7023
7	.7842	.7468	.8501	.8238	.8029	.8596	.924
8	.8402		.8131	.8596	.8589	.8954	.8871
9	.8962	.6468	.8131	.9335	.8402	.8954	.7023
10	.8775	.7842	.788	.8962	.7842	.8596	.924
11	.8402	.8775	.788	.9335	.788	.8316	.8962
12	.7842	.8589	.788	.8962	.8238	.8501	.8589
13	.6348	.6908	.788	.7842	.8238	.8131	.8215
14	.7468	.4108	.788	.7468	.7522	.7023	.7095
15	.7282	.6653	.7522	.6722	.7164	.7392	.6722
16	.7282	.7392	.7522	.7468	.7164	.7392	.7842
17	.7468	.7762	.8238	.7842	.6805	.8501	.8589
18	.8215	.8871	1.0387	.9896	.8596	.961	.9709
19	1.251	1.2567	1.2536	1.1576	1.0745	1.3306	1.2883
20	.6535	1.3306	1.3969	1.4563	1.2894	1.4784	1.4377
21	.9896	1.2197	1.1104	1.2696	1.182	1.2197	1.1949
22	.8402	1.1088	.9313	1.1203	.8954	1.0349	1.0269
23	.5601	.6653	.7164	.7468	.7522	.7762	.7095
24	.5601	.4294	.5175	.5731	.6535	.6805	.5914
Max	1.251	1.3306	1.3969	1.4563	1.2894	1.4784	1.4377
Min	.4668	.3326	.4805	.5014	.5228	.5014	.4805
Avg	.7336	.7156	.7839	.8202	.7819	.8360	.8145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 202 / 11KV Bahirewadi Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.032	.032	.0648	.6722	.5506	.5761
2	.5601	.0324	.032	.0648	.6348	.583	.5761
3	.5228	.032	.032	.064	.5788	.583	.5761
4	.5228	.0324	.032	.0648	.5788	.6802	.5761
5	.6348	.0316	.048	.0648	.6161	.7773	.6401
6	.6722	.0328	.048	.0648	.6722	.9393	.7522
7	1.1576	.032	.064	.0648	1.1389	1.1984	1.3763
8	1.4563	.0474	.048	.0648	1.3443	1.3765	1.5043
9	.0671	.68	.9922	.7842	.0671	.0324	.048
10	.0503	1.1248	1.2955	1.531	.0503	.0324	.048
11	.0486	1.3125	1.3603	1.587	.0324	.048	.0486
12	.0492	1.4864	1.4251	1.6804	.0324	.048	.0474
13	.0474	1.4706	1.4899	1.643	.0324	.048	.0633
14	.0486	1.5223	1.5061	1.6617	.0324	.032	.0633
15	.0474	1.4883	1.5223	1.6804	.0324	.032	.0633
16	.0791	1.5043	1.5223	1.7924	.0324	.032	.064
17	.0972	.048	.0648	.0686	.0324	.032	.0633
18	.0633	.08	.0648	.0671	.0324	.096	.0633
19	.0486	.048	.0648	.0686	.0324	.064	.0486
20	.0474	.048	.0648	.0671	.0486	.048	.048
21	.0486	.048	.0648	.0671	.0486	.048	.0474
22	.0474	.048	.0648	.0671	.5506	.048	.0474
23	.0316	.048	.0648	.5975	.5506	.6562	.6325
24	.6722	.0316	.048	.0648	.7095	.5506	.5921
Max	1.4563	1.5223	1.5223	1.7924	1.3443	1.3765	1.5043
Min	.0316	.0316	.032	.064	.0324	.032	.0474
Avg	.3190	.4692	.4980	.5811	.3564	.3557	.3569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 203 / MAHAGOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.9816	1.5947	.6154	.0335	.0181	.0354
2	.0354	.9431	1.5592	.6154	.0354	.0181	.0354
3	.0354	.9536	1.5769	.6335	.0373	.0181	.0354
4	.0354	.9465	1.5769	.6878	.0354	.0181	.0354
5	.0354	.964	1.6301	.6878	.0354	.0181	.0354
6	.0354	.964	1.701	.724	.0354	.0181	.0354
7	.0354	1.2346	1.8781	.7602	.0354	.0181	.0354
8	.0351	1.1919	1.8073	.8145	.0114	.0181	.0354
9	1.5497	.0177	.0354	.0177	1.307	.6516	1.6301
10	2.2592	.0177	.0362	.0354	2.1658	1.0679	2.1262
11	2.3137	.0175	.0181	.0354	1.6108	2.1262	2.0683
12	2.3405	.0175	.0181	.0175	1.1765	1.949	2.0285
13	1.858	.0177	.0181	.0175	1.1584	1.8427	1.9845
14	.8669	.0175	.0181	.0175	1.1222	2.0908	1.8004
15	1.7101	.0177	.0181	.0175	1.0498	1.9845	1.5777
16	1.4563	.0177	.0181	.0354	.9774	1.9845	1.7318
17	.0177	.0354	.0181	.0351	.0362	.0354	.0347
18	.0173	.0354	.0181	.0351	.0181	.0354	.0351
19	.0175	.0354	.0181	.0354	.0181	.0354	.0351
20	.0351	.0354	.0181	.0366	.0181	.0354	.0351
21	.0175	.0354	.0181	.0354	.0181	.0354	.0347
22	.0177	.0354	.0181	.0354	.0181	.0354	.0351
23	1.0166	1.5592	.5792	.0354	.0181	.0354	.0351
24	.0354	.9882	1.5947	.6154	.0351	.0181	.0354
Max	2.3405	1.5592	1.8781	.8145	2.1658	2.1262	2.1262
Min	.0173	.0175	.0181	.0175	.0114	.0181	.0347
Avg	.6588	.4617	.6578	.2748	.4586	.5878	.6463

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 201 / 11 KV Kanoli Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.362	.2587	.2774	.2896	.3121	.2957
2	.3086	.362	.2587	.2774	.2896	.2743	
3	.3258	.3258	.2587	.3121	.2896	.2774	.2772
4	.3429	.3258	.2772	.2743	.3258	.3121	.3326
5	.3772	.3258	.2772	.3467	.362	.3467	.3696
6	.4115	.362	.2801	.4161	.3982	.4161	.4435
7	.4458	.3258	.3547	.4508	.4344	.4458	.5359
8	.4801	.3258	.5228		.5249	.4854	.5729
9	.4801	.5973	.5788	.4854	.5792	.5201	.5359
10	.4458	.543	.5041	.4854	.4163	.4508	
11	.3429	.4525	.3467	.4161	.3988		.4334
12		.4163	.3467	.3944	.3121	.3801	.3429
13		.3326	.3467	.3772		.3696	.3467
14		.3881	.3121	.3772	.3467	.3475	.3121
15		.3982		.4163	.2774	.3258	.3814
16		.4163		.362	.3121		.3641
17		.4344	.3814	.4706	.3121	.4572	.4161
18		.4805		.5068	.3467	.5487	.5895
19		.7207	.6173	.6878	.5895	.7783	.6588
20		.6722	.6935	.6154		.724	.6859
21		.6161		.6516	.5895	.6401	.6344
22		.5175		.4344	.4854	.2926	.5316
23		.3511	.3467	.362	.3814	.3475	.3429
24	.3086	.362	.2772	.3121	.3258	.3467	.2926
Max	.4801	.7207	.6935	.6878	.5895	.7783	.6859
Min	.3086	.3258	.2587	.2743	.2774	.2743	.2772
Avg	.3815	.4339	.3810	.4222	.3903	.4272	.4407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 202 / 11KV Sarambalwadi Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	1.1222	1.0883	1.1096	.0362	.0693	.0537
2	.0686	1.1222	1.0753	1.1096	.0362	.0693	.0537
3	.0686	1.2308	1.0883	1.1789	.0181	.0693	.0537
4	.0686	1.267	1.1203	1.1789	.0181	.0693	.0537
5	.0686	1.3394	1.2003	1.1096	.0181	.0693	.0537
6	.0686	1.3756	1.2803	1.1096	.0181	.0693	.0716
7	.0686	1.448	1.3603	1.2346	.0362	.0693	.0716
8	.0686	1.448	1.2483		.0362	.0693	.0716
9	1.0974	.0543	.0716	.0347	1.448	1.387	1.448
10	1.4632	.0543	.0537	.0347	1.448	1.7147	
11	1.5242	.0537	.0693	.0173	1.5089		1.8031
12		.0543	.0693	.0181	1.595	1.4403	1.8031
13		.0362	.0693	.0181		1.4548	1.8031
14		.0181	.0693	.0362	1.6644	1.5684	1.7337
15		.0179		.0362	1.6461	1.6324	1.7337
16		.0362		.0362	1.5775	1.6446	1.7337
17		.0358	.0693	.0362	.0347	.0716	.0347
18		.0543		.0362	.0343	.0716	.0693
19		.0716	.0693	.0362	.0693	.0716	.0693
20		.0716	.0693	.0362		.0716	.0686
21		.0716		.0362	.0693	.0716	.0514
22		.0739		.0362	.0693	.0716	.0514
23		1.0242	1.2483	.0362	.0693	.0716	.0514
24	.0686	1.1222	1.0402	1.2136	.0362	.0693	.0537
Max	1.5242	1.448	1.3603	1.2346	1.6644	1.7147	1.8031
Min	.0686	.0179	.0537	.0173	.0181	.0693	.0347
Avg	.3919	.5501	.6505	.4230	.5222	.5203	.5648



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 203 / 11 kv Kolindre Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1584	.181	.2328	.208	1.448	1.3176	1.4083
2	1.1584	.181	.2328	.208	1.448	1.2689	1.3923
3	1.1584	.1448	.2328	.208	1.4842	1.283	1.3923
4	1.1888	.1448	.2328	.2058	1.5746	1.3321	1.3603
5	1.2193	.1448	.2328	.208	1.5565	1.3176	1.3603
6	1.2193	.2172	.2865	.2058	1.448	1.3032	1.3283
7	1.2498	.181	.3224	.2103	1.5384	1.2483	1.4685
8	1.2803	.2172	.2507		1.5565	1.4403	1.3969
9	.1886	1.448	1.4403	1.7337	.2534	.208	.197
10	.2058	1.5203	1.6004	1.7337	.2534	.2427	
11	.2229	1.8099	1.8378	1.8176	.1734		.1734
12		1.6964	1.8176	1.8099	.208	.2103	.0693
13		1.7284	1.8176	1.7147		.2149	.0693
14		1.6964	1.7147	1.6956	.1715	.2149	.0693
15		1.8625		1.7147	.1734	.2328	.0693
16		1.6324		1.7147	.2058	.2328	.0693
17		.2149	.208	.181	.2401	.2328	.208
18		.2353		.181	.2058	.2507	.2427
19		.2865	.2427	.181	.208	.2686	.2427
20		.2865	.2427	.2172		.2507	.1886
21		.2865		.181	.208	.2507	.2058
22		.2715		.181	.208	.2507	.2058
23		.2865	.208	1.448	1.3717	1.3443	1.0059
24	1.1584	.181	.2686	.2058	1.448	1.387	1.4403
Max	1.2803	1.8625	1.8378	1.8176	1.5746	1.4403	1.4685
Min	.1886	.1448	.208	.181	.1715	.208	.0693
Avg	.9507	.7023	.7064	.7898	.7901	.7088	.6767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 201 / 11 KV Devarde Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1052	.128	.1402	.1109	.1294	.1509	.1494
2	.1052	.1254	.124	.1097	.1097	.1132	.1307
3	.1063	.1075	.1214	.1097	.112	.1132	.1294
4	.1052	.1086	.1402	.1097	.1097	.1109	.112
5	.1417	.124	.1753	.1097	.1109	.1294	.1294
6	.1772	.1578	.181	.1326	.1867	.1991	.1848
7	.2896	.2481	.2561	.2218	.2172	.2715	.2587
8	.3189	.3506	.3506	.2835	.2172	.2835	.3045
9	.3224	.3155	.3429	.3045	.3506	.3045	.3898
10	.3982	.3224	.3506	.3258	.3506	.3582	.394
11	.3467	.362	.3224	.1734	.3052	.3506	2.4097
12	.3856	.3258	.4298	.1734	.3222	.2103	.3772
13	.3544	.1417	.2149	.1867	.1677	.2103	.3086
14	.2883	.1372	.2454	.3395		.1417	.3086
15	.3121	.1372	.3155	.2427	.1543	.2126	.3121
16	.3467	.1715	.3506	.3429	.2818	.298	.3429
17	.4161	.208	.3224	.4252		.3109	.4207
18	.3582	.2865	.3982	.4458	.3521	.3696	.3121
19	.5121	.3658	.4755	.4557	.4066	.4854	.5487
20	.4572	.439	.462	.4706	.5041	.7577	.5121
21	.3921	.3326	.3696	.362	.3734	.4024	.3734
22	.1867	.2587	.2587	.2561	.3174	.2614	.2587
23	.1663	.2126	.168	.1478	.2801	.2218	.181
24	.1433	.1646	.1417	.1294	.1448	.1867	.1848
Max	.5121	.439	.4755	.4706	.5041	.7577	2.4097
Min	.1052	.1075	.1214	.1097	.1097	.1109	.112
Avg	.2807	.2305	.2774	.2487	.2502	.2689	.3764

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 202 / 11 KV Velvatti Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9709	.0747	.1086	.0905	1.6644	.2458	.2347
2	.9259	.0747	.1097	.0914	1.6118	.2458	.2204
3	.9015	.0747	.1109	.0924	1.6297	.2401	.218
4	.8916	.0747	.1086	.0914	1.6461	.2401	.2374
5	.9259	.0747	.1109	.0914	1.6644	.2343	.2486
6	1.0288	.0905	.1097	.0924	1.7147	.25	.2984
7	1.2483	.0924	.1109	.0934	1.7337	.5365	.426
8	1.387	.0914	.1086	.1109	1.893	.5636	.4748
9	.0747	1.4746	1.6651	1.8347	.0905	.1109	.0895
10	.0924	2.2085	2.5415	2.6452	.0747		.0724
11	.0943	2.3137	1.0288	2.2365	.0754		.0739
12	.0943	2.5591	2.4417	1.8347	.0747	.0716	.0549
13	.0924	1.9281	.7545	2.0376	.0739	.0716	.0543
14	.0914	2.5065	2.3703	2.4539	.0335	.0724	.0724
15	.0739	2.191	2.1956	2.5941	.0328	.0732	.0549
16	.0724	2.2085	2.5857	2.4539	.0335	.0549	.0693
17	.0739	.0747	.0716	.0943		.0366	.0732
18	.0739	.0934	.0905	.0895	.0164	.0732	.0924
19	.0934	.0943	.1097	.1052	.0373	.0914	.112
20	.0943	.0934	.1109	.112	.112	.0924	.1109
21	.0943	.112	.0924	.1086	.112	.0924	.112
22	.0754	.112	.0924	.1307	.1109	.0739	.0934
23	.0724	.1132	.0924	1.7353	.2683	.2543	.3258
24	1.0402	.0724	.1097	.0905	1.6651	.2458	.2347
Max	1.387	2.5591	2.5857	2.6452	1.893	.5636	.4748
Min	.0724	.0724	.0716	.0895	.0164	.0366	.0543
Avg	.4410	.7835	.7179	.8879	.7117	.1805	.1689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 203 / 11 KV Kittawade Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	1.0288	1.2209		.1132	.1132	.1294
2	.132	.9259	1.2039	1.6448	.1307	.1132	.1294
3	.132	.9054	1.2174	1.6448	.1132	.1132	.1307
4	.1307	.9054	1.2517	1.6278	.1132	.1132	.1294
5	.1509	.9389	1.2717	1.6632	.1132	.1132	.1307
6	.1509	.9389	1.3203	1.6617	.1132	.1132	.1478
7	.1494	1.2239	1.6632	1.8313	.132	.0943	.1478
8	.112	1.3056	1.5432	1.6933	.1494	.0943	.132
9	1.4043	.0754	.132	.1086	1.262	1.3176	1.4403
10	1.9839	.0943	.1132	.1097	1.7661	1.8054	1.9161
11	2.2611	.0934	.1294	.0934	2.226	1.8861	2.0332
12	2.2611	.0943	.128	.0943	2.0978	1.7635	2.0332
13	2.1735	.1132	.1086	.0943	2.1325	1.7269	1.9418
14	2.2365	.1132	.1086	.0943	2.0405	1.7804	1.8347
15	2.2365	.0747	.1086	.0943	2.0062	1.7436	1.8378
16	2.3232	.0943	.0732	.112	2.0919	1.7772	1.8724
17	.0943	.0943	.1267	.1132		.1267	.0953
18	.0943	.0943	.1294	.1086	.0754	.128	.1524
19	.132	.1524	.1478	.112	.1132	.1463	.1509
20	.132	.1905	.1663	.1509	.1132	.1478	.1509
21	.132	.1698	.1663	.1509	.1509	.1307	.1509
22	.132	.168	.1307	.1509	.132	.1478	.1524
23	1.0562	1.1831	1.6991	.132	.132	.1478	.1509
24	.1509	1.0059	1.2378	1.749	.132	.1132	.1307
Max	2.3232	1.3056	1.6991	1.8313	2.226	1.8861	2.0332
Min	.0943	.0747	.0732	.0934	.0754	.0943	.0953
Avg	.8289	.4993	.6416	.6624	.7587	.6565	.7134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 146006 / 220KV Gadhinglaj(Mumewadi)

Feeder No / Name : 408 / 33 KV Soot Girni

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18
HR	Load (MW)
16	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 201 / 11 KV KOWAD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3361			.1966	.2987	
2	.1696	.3361				.2987	.1677
3		.3361			.1677	.2987	
4	.2012	.3361			.2012	.2987	.2012
5		.3361		.2561		.3361	
6	.3052	.4108	.4115	.3658	.2713	.4108	.3052
7	.5144	.5975	.5487	.5487	.5087	.5601	.5144
8		.6348	.5144	.5853	.5121	.5228	
9	.5487	.567	.5765	.5975	.5068	.543	.5975
10	.5487	.567	.5487	.6722	.543	.5853	.5228
11	.4801	.5121		.5228	.4024	.5853	.5601
12		.4961	.5487			.4755	.5975
13	.3772	.4607	.5487	.5228			.4854
14		.3658	.5087	.4854	.3658		.4854
15	.4458	.3658	.4458	.4108	.4024	.4024	.5228
16	.3772	.4115	.407	.4481	.3734	.4344	.4854
17	.4481	.5144	.5487	.407	.5228		.4409
18	.5601		.543		.5228	.583	
19	.8048	.7545	.7682	.7202	.7842		.7888
20	.9335		.8413		.8962		
21	.7095		.7682		.7842		
22	.6722		.6219		.7095		
23	.4481	.4115	.3658		.4108		
24	.3353	.3361	.5765	.3292	.3018	.2987	.3353
Max	.9335	.7545	.8413	.7202	.8962	.5853	.7888
Min	.1696	.3361	.3658	.2561	.1677	.2987	.1677
Avg	.4933	.4543	.5607	.4909	.4692	.4333	.4674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 202 / 11 KV Kagani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381			1.6617	1.2803	
2	1.0867	.0381				1.2803	1.5604
3		.0381			1.6827	1.2803	
4	1.1096	.0381				1.2955	1.6297
5		.0381			1.5939	1.2955	
6	1.1317	.0381			1.6297	1.2803	1.6461
7	1.1694	.0381			1.5432	1.3443	1.701
8		.0381			1.6827	1.3123	
9		1.5238	.7712	1.6644			.0381
10		2.0995	1.0288	.9602			.0381
11		2.1948		.9602			.0381
12		2.1262	1.7177				.0381
13		2.3777	1.9071	2.2382			.0381
14		2.3777	2.2436	2.34			
15		2.3777	2.2885	2.3061			.0381
16		2.0119	2.2977	2.3739	.0381		.0381
17	.0381				.0381		
18	.0381				.0381		
19	.0381				.0381		
20	.0381				.0381		
21	.0381				.0381		
22	.0381				.0381		
23	.0381				1.1984		
24	1.0174	.0381			1.7147	1.2955	1.56
Max	1.1694	2.3777	2.2977	2.3739	1.7147	1.3443	1.701
Min	.0381	.0381	.7712	.9602	.0381	1.2803	.0381
Avg	.4818	1.0254	1.7507	1.8347	.8649	1.2960	.6970

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 203 / 11 KV Kudnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2987			.1638	.5601	
2		.6584				.5601	.1677
3	.1638	.6722			.1658	.5601	
4		.6722				.5601	.1638
5	.1989			.5121	.2012	.5601	
6	.2713	.7468	.5487	.5487	.2683	.5975	.2652
7	.5426	.8962	.583	.5487	.5765	.6722	.6443
8		.6348	.5487	.5487	.4755	.7468	
9	.6173	.7087	.5087	.6722	.3658	.6447	.8589
10	.6173	.7682	.503	.6722	.3658	.724	.7468
11	.6859	.6379		.7468	.3658	.7316	.7842
12		.7316	.5304		.3658	.5487	.2987
13	.5144	.6584	.5765	.7468	.3658		.6722
14		.5853	.5087	.5228	.3658		.2987
15	.4801	.439	.503	.5228	.3658	.0732	.5975
16	.4801	.4801	.5365	.5601	.4481	.5487	.5975
17	.5975	.6173	.5487	.4359	.2987		.4748
18	.5601		.5121		.2987	.4748	
19	.7468	.6859	.6584	.6104	.4854		.6783
20	.7316		.7316		.5975		
21	.6722		.5853		.5975		
22	.4854		.5853		.6722		
23	.2987	.4801	.4344		.5975		
24	.2683	.2987		.439	.2683	.5228	.2683
Max	.7468	.8962	.7316	.7468	.6722	.7468	.8589
Min	.1638	.2987	.4344	.4359	.1638	.0732	.1638
Avg	.4807	.6142	.5531	.5777	.3943	.5678	.5011



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 204 / 11 KV KUDNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4481				.0381	
2		.4481				.0381	
3		.4481				.0381	
4		.4481				.0381	
5		.4481		.3658		.0381	
6		.4801	.5365	.5853		.0381	
7		.6081	.6036	.6584		.0381	
8		.6722	.6706	.7316		.0381	
9	.6706	.0354		.0381	.5121		.8962
10	1.0059	.0366		.0381	.6584	.7316	1.0562
11	1.073			.0381	.5853	.7316	1.0883
12					.567	.8048	1.0883
13	1.0059			.0381	.5792		1.0242
14				.0381	.5853		1.0242
15	.9724			.0381	.5853	.9412	
16	1.0059			.0381	.5121	1.0242	.2561
17	.0381				.0381		
18	.0381				.0381		
19	.0381				.0381		
20	.0381				.0381		
21	.0381				.0381		
22	.0381				.0381		
23	.4481	.4024	.3658		.0381		
24		.4481	.4694	.3658		.0381	
Max	1.073	.6722	.6706	.7316	.6584	1.0242	1.0883
Min	.0381	.0354	.3658	.0381	.0381	.0381	.2561
Avg	.4931	.4103	.5292	.2478	.3234	.3269	.9191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 205 / 11 KV KAGANI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0747			.0335	.0747	
2	.0335	.0747				.0762	.0328
3		.0747			.0332	.0762	
4	.0328	.0747				.0762	.0332
5		.0747		.0362	.0663	.0762	
6	.1006	.0747	.0686	.0732	.1006	.0762	.1017
7	.1357	.112	.1029	.1097	.1357	.112	.1372
8		.1494	.1715	.1463	.1463	.0747	
9	.1372	.1063	.1341	.1494	.1463	.1463	.1494
10	.1372	.1063	.1357	.1494	.1097	.1097	.1494
11	.1029	.1097	.1029	.1494	.1097	.1097	.1494
12		.0709	.0663		.0366	.0732	.0747
13	.0686	.0366	.0671	.112	.0366		.0747
14		.0366	.0671	.0747	.0732		.0747
15	.0686	.0366	.0671	.0747	.0732	.0362	.0747
16	.0686	.0343		.0747	.0381	.0362	.0747
17	.0747	.0686	.0732	.1006	.0747		.0671
18	.0747		.0732		.0747	.1017	
19	.1867	.1715	.1417	.1357	.1494		.1696
20	.2241		.1829		.1867		
21	.1867		.1448		.2195		
22	.1494		.1097		.1494		
23	.0747	.1029	.0732		.0747		
24	.0671	.0747	.0686	.0732	.0671	.0747	.0671
Max	.2241	.1715	.1829	.1494	.2195	.1463	.1696
Min	.0328	.0343	.0663	.0362	.0332	.0362	.0328
Avg	.1069	.0832	.1028	.1042	.0971	.0831	.0954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 206 / 11 KV Hemrus

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0381			.0678	.0747	
2	.0671	.0747			.0663	.0747	.0671
3		.0747				.0747	
4	.0663	.0747			.0335	.0373	.0663
5		.0747		.0366		.0381	
6	.0671	.0747	.0343		.0332	.0381	.0671
7	.0678	.0747	.0343		.0328	.0381	.0678
8		.0747	.0343			.0381	
9	.0686	.0724	.0335	.0381		.0732	.0747
10	.0686	.0709	.0332	.0381		.0732	.0747
11	.0686	.0709		.0762	.0732	.0732	.0747
12		.0732	.0339		.0732	.0732	.0747
13	.0686	.0732	.0678	.0747	.0732		.0747
14			.0671	.0747	.0732		.0747
15	.0686		.0678	.0747	.0732	.0732	.0747
16	.0686	.0343		.0747	.0747	.0732	.0747
17	.0747	.0343	.0732	.0663	.0747		.0663
18	.0747		.0732		.0747	.0671	
19	.0747	.0343	.0732	.0335	.0747		.0678
20	.0373		.0724		.0747		
21	.0381		.0732		.0747		
22	.0381		.0732		.0747		
23	.0381	.0686	.0709		.0747		
24		.0381	.0686	.0732	.0671	.0747	.0335
Max	.0747	.0747	.0732	.0762	.0747	.0747	.0747
Min	.0373	.0343	.0332	.0335	.0328	.0373	.0335
Avg	.0621	.0628	.0579	.0601	.0665	.0622	.0689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 207 / Nrusinhwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5365	.0381			.9362	.7042	
2	.5426	.0381					.8764
3		.0381			.9259		
4	.5765	.0381			.9465	.7125	.9015
5		.0381				.7125	
6	.583	.0381			.9816	.7042	.8916
7	.5895	.0381			.9709	.8322	.9214
8		.0381			.9511	.8642	
9		1.829	1.153	1.3123			.0381
10		2.3388	1.4403	1.5364			.0381
11		2.5606	1.6617	1.5043			.0381
12		2.5606	1.7833				.0381
13		2.6703	1.9281	1.4723			.0381
14		2.3777	1.8652	1.4723			.0381
15		2.1948	1.9281	1.5364			.0381
16		2.0119		1.5364	.0381		.0381
17	.0381				.0381		
18	.0381				.0381		
19	.0381				.0381		
20	.0381				.0381		
21	.0381				.0381		
22	.0381				.0381		
23	.0381				.8097		
24	.5426	.0381			.9259	.8097	.8573
Max	.5895	2.6703	1.9281	1.5364	.9816	.8642	.9214
Min	.0381	.0381	1.153	1.3123	.0381	.7042	.0381
Avg	.2798	1.1110	1.6800	1.4815	.5143	.7628	.3656

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 208 / RAJGOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1843				.0381	
2		1.1843				.0381	
3		1.1843				.0381	
4		1.1843				.0381	
5		1.1843		1.0242		.0381	
6		1.2163		1.1706		.0381	
7		1.3443	1.2071	1.2437		.0381	
8		1.2803	1.2071	1.1706		.0381	
9	1.5424			.0381	1.3169	1.5364	1.4723
10	1.7772			.0381	1.6827	1.7558	1.6964
11	1.7436			.0381	1.6095	1.7558	1.6324
12					1.6827	1.829	1.7924
13	1.8107			.0381	1.5927		1.6644
14				.0381	1.5729		1.6964
15	1.7772			.0381	1.5364	1.829	1.7604
16	1.8778			.0381	1.3443	1.829	1.7604
17	.0381				.0381		
18	.0381				.0381		
19	.0381				.0381		
20					.0381		
21	.0381				.0381		
22	.0381				.0381		
23	1.2803	1.0059	1.0974		.0381		
24		1.1843	1.073	1.0974		.0381	
Max	1.8778	1.3443	1.2071	1.2437	1.6827	1.829	1.7924
Min	.0381	1.0059	1.073	.0381	.0381	.0381	1.4723
Avg	1	1.1953	1.1462	.4978	.8403	.7252	1.6844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV SHINOLI EX.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1187	.1132	.0754	.1357	.0754	.0754	.1147
2	.0678	.0377	.0377	.0678	.0377	.0377	.0663
3	.0328	.0377	.0189	.0339	.0377	.0377	.0339
4	.0339	.0377	.0377	.0339	.0377	.0377	.0339
5	.0339	.0377	.0377	.0339	.0377	.0377	.0332
6	.0339	.0377	.0377	.0339	.0377	.0754	.0678
7	.0339	.1132	.1132	.0339	.1132	.1132	.1326
8	.1187	.1132	.132	.1357	.1509	.1132	.1187
9	.1357		.0377	.1357	.1509	.1509	.1357
10	.1478	.1417	.1509	.1357	.1294	.1463	.1494
11	.124	.1267	.1075	.1132	.1097	.037	.1109
12	.1052	.1132	.1109	.1132	.1097	.1109	.1109
13	.1052	.1132	.1086	.1132	.1132	.112	.0366
14	.1097	.0377	.0366	.1132	.112	.1109	.0373
15	.037	.0377	.0171	.0377	.037	.0373	1.1888
16	.0373	.0377	.0185	.0377	.037	.0373	.0373
17	.0373	.0377	.0187	.0377	.0377	.0373	.0377
18	.0377	.0377	.0339	.0377	.0377	.0339	.0377
19	.0377	.0377	.017	.0377	.0377	.017	.0377
20	.1509	.1132	.1187	.0914	.1132	.017	.1509
21	.1509	.1509	.1357	.1509	.1509	.1357	.1509
22	.1509	.1509	.1357	.1219	.1509	.1017	.1509
23	.1509	.1132	.1187	.1509	.1132	.1326	.1509
24	.1372	.1132	.1132	.1187	.1132	.1132	.1187
Max	.1509	.1509	.1509	.1509	.1509	.1509	1.1888
Min	.0328	.0377	.017	.0339	.037	.017	.0332
Avg	.0887	.0822	.0737	.0856	.0867	.0775	.1351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV Gaulwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	.0179	.0152	.017	1.1584	1.2308	1.2887
2	1.1145	.0181	.0152	.017	1.0974	1.2407	1.2209
3	1.1869	.0175	.0152	.017	1.0669	1.2574	1.1869
4	1.3395	.0179	.0152	.017	1.0669	1.2146	1.2548
5	1.3565	.0173	.0152	.017	1.0669	1.1498	1.3226
6	1.4243	.0177	.0152	.017	1.0822	1.166	1.3735
7	1.5581	.0173	.0152	.017	1.3108	1.1561	1.5261
8	1.6278	.0179	.0152	.017	1.4632	1.5384	1.6278
9	.017	1.9566	.8886	.8987	.0152	.0156	.017
10	.0173	1.9753	.9054		.0177	.0175	.0175
11	.0175	2.6155	.8278	1.7375	.0177	.0177	.0177
12	.0175	2.9508		2.0424	.0179	.0177	.0175
13	.017	2.6825	.8642	2.0119	.0152	.0175	.0173
14	.0175		.7526	2.0576	.0177	.0175	.0177
15	.0175	1.6278	.9156	2.1643	.0175	.0177	.0175
16	.0177	1.6598	.8179	2.3777	.0177	.0173	.0177
17	.0173	.0168	.0175	.0152	.0156	.0183	.0152
18	.0152		.017	.0152	.0152	.017	.0152
19	.0152	.0156	.017	.0152	.0152	.017	.0152
20	.0152	.0151	.017	.0152	.0152	.017	.0152
21	.0152	.0168	.017	.0152	.0152	.017	.0152
22	.0152	.0151	.017	.0152	.0156	.017	.0152
23	.0152	.0151	.017	1.3108	1.3279	1.5091	1.4327
24	1.153	.0183	.0152	.017	1.2193	1.2616	1.3395
Max	1.6278	2.9508	.9156	2.3777	1.4632	1.5384	1.6278
Min	.0152	.0151	.0152	.0152	.0152	.0156	.0152
Avg	.5029	.7147	.2708	.6454	.5037	.5403	.5752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Gaulwadi Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	23-FEB-18
HR	Load (MW)
1	.0152
2	.0152
3	.0152
4	.0152
5	.0152
6	.0152
7	.0152
8	.0152
24	.0152
Max	.0152
Min	.0152
Avg	.0152



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 208 / 11 KV Shivanage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.6097	1.8442	1.8233	.0152	.0152	.017
2	.0166	.6097		1.7404	.0152	.0152	.017
3	.0166	.6097	1.8275	1.7465	.0152	.0156	.017
4	.017	.5792	1.8313	1.6787	.0152	.0152	.017
5	.0166	.5335	1.749	1.6617	.0152	.0152	.017
6	.017	.5335	1.7328	1.8313	.0152	.0156	.017
7	.017	.7468	1.7939	2.0008	.0152	.0152	.017
8	.017	.7164	1.9364	2.0517	.0152	.0162	.017
9	1.4074	.0177	.0152	.0678	1.1431	1.3441	1.5261
10	1.3889	.0171	.0152		1.5278	1.4148	1.5954
11	1.3763	.0183	.0173		1.531	1.475	1.5954
12	1.4706	.0151	.052		1.5364	1.475	1.5586
13	1.3272	.0152	.052	.0152	1.6549	1.4861	1.4712
14	1.3125	.0151	.0716	.0152	1.3847	1.4449	1.5202
15	1.3443	.0151	.0678	.0152	1.335	1.4266	1.5306
16	1.2191	.0156	.0716	.0152	1.3847	1.3969	1.4563
17	.0358	.0151	.0886	.0152	.0152	.0179	.0152
18	.0152		.0848	.0305	.0152	.017	.0152
19	.0152	.0162	.0848	.0152	.0162	.017	.0152
20	.0152	.0152	.0678	.0152	.0164	.017	.0152
21	.0152	.0152	.0678	.0152	.0152	.017	.0152
22		.0152	.0678	.0152	.0152	.017	.0152
23	.6401	1.9433	2.2043	.0152	.0156	.017	.0152
24	.017	.6249	1.7328	2.0517	.0152	.0156	.017
Max	1.4706	1.9433	2.2043	2.0517	1.6549	1.4861	1.5954
Min	.0152	.0151	.0152	.0152	.0152	.0152	.0152
Avg	.5102	.3353	.7598	.8017	.4893	.4884	.5214

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 210 / Gad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.6554	.7545	.7122	.0152	.0156	.017
2	.0166	.6097	.7712	.6783	.0152	.0156	.017
3	.0164	.6097	.7712	.6443	.0152		.017
4	.0166	.5792	.8139	.6613	.0152	.0156	.017
5	.0166	.5792	.8383	.6613	.0152	.0162	.017
6	.017	.6249	.788	.6952	.0152	.0152	.017
7	.0166	.7011	.788	.7291	.0152	.0152	.017
8	.0166	.6859	.7209	.6274	.0152	.0162	.017
9	1.0513	.0175	.0152	.017	.823	1.1633	1.2039
10	1.1683	.0179	.0152	.017	1.0957	1.25	1.1728
11	1.2163	.0175	.0177	.0152	1.3279	1.3735	1.5154
12	1.0082	.0151	.0175	.0152	1.2492	1.2346	1.2342
13	1.1574	.0152	.0175	.0152	1.3748	1.2492	1.0837
14	1.2037	.0152	.0175	.0152	1.25	1.2191	1.1883
15	1.2631	1.2041	.017	.0152	1.2191	1.2346	1.1584
16	1.2176	.0149		.0152	1.2342	1.189	1.2041
17	.0177	.0189	.0183	.0152	.0152	.0181	.0152
18	.0152	.0189	.017	.0152	.0152	.017	.0152
19	.0152	.0162	.017	.0152	.0152	.017	.0152
20	.0152	.0151	.017	.0152		.017	.0152
21	.0152	.0151	.017	.0152	.0152	.017	.0152
22	.0152	.0152	.0166	.0152	.0152	.017	.0152
23	.6554	.8551	.7122	.0152	.0156	.017	.0152
24	.0162	.6859	.7545	.7461	.0152	.0152	.017
Max	1.2631	1.2041	.8383	.7461	1.3748	1.3735	1.5154
Min	.0152	.0149	.0152	.0152	.0152	.0152	.0152
Avg	.4244	.3335	.3449	.2661	.4262	.4417	.4175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 201 / 11 KV Adkur Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0191	.0191	.0189		.0191
2	.0191	.0191	.0191	.0189	.0189		.0191
3	.0191	.0189	.0191	.0189	.0189		.0191
4	.0191	.0189	.0191	.0187	.0187		.0191
5	.0189	.0189	.0191	.0185	.0187		.0189
6	.0187	.0187	.0381	.0366	.0373		.0377
7	.0187	.0554	.0566	.0366	.0549		.0549
8	.0532	.0709	.056	.0701	.0724		.0554
9	.0724	.0543	.0549	.0187	.0543	.0934	.0549
10	.037	.0362	.0366	.0373	.0537	.0366	.0366
11	.0362	.0183	.0189	.0189	.0185	.037	.0373
12	.0189	.037	.0189	.0187	.0347	.0377	.0366
13	.0187	.037	.0183	.0183	.0183	.0354	.0366
14	.0183	.0366	.0181	.0179	.0177	.0179	.0373
15	.0181	.0366	.0187	.0181	.0185	.0183	.0366
16	.0183		.0181	.0189	.0183	.0366	.0373
17	.0343	.0366	.0187	.0185	.0177	.0175	.0187
18	.0701	.0549	.0671	.0497	.0686	.0526	.0686
19	.0924	.0934	.0732	.0914	.0924	.0914	.1086
20	.0934	.0914	.1109	.0934	.0934	.0914	.0934
21	.0754	.0732	.0934	.0754	.0572	.0732	.0934
22	.0566	.0549	.0754	.056	.0572	.0572	.0566
23	.0191	.0377	.0191	.0191	.0189	.0377	.0191
24	.0189	.0189	.0381	.0191	.0189	.0189	.0189
Max	.0934	.0934	.1109	.0934	.0934	.0934	.1086
Min	.0181	.0183	.0181	.0179	.0177	.0175	.0187
Avg	.0368	.0416	.0394	.0345	.0382	.0471	.0431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 202 / 11 KV Kurtanwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.056	.0566	.0543	.0867	.0663	.0566
2	.037	.0566	.0377	.037	.0701	.0663	.0566
3	.037	.0566	.0377	.0373	.0732	.0497	.0566
4	.0187	.056	.0377	.037	.0732	.0514	.0566
5	.0373	.056	.0566	.056	.0732	.056	.0747
6	.0754	.0943	.1132	.1132	.112	.0747	.1097
7	.1143	.132	.128	.132	.1478	.1307	.132
8	.1509	.1698	.132	.1829	.1886	.1698	.1463
9	.1307	.1509	.1294	.1663	.1715	.2263	.1629
10	.132	.1334	.1132	.1294	.1698	.2195	.1307
11	.132	.1334	.1494	.1387	.1509	.1848	.1663
12	.1294	.1294	.1109	.1433	.1524	.1848	.1829
13	.112	.1109	.0914	.1949	.0934	.1463	.1829
14	.112	.1109		.1267	.1132	.1463	.1097
15	.112	.1109	.1097	.1402	.1646	.1829	.1829
16	.1417	.1097	.1402	.1494	.1509	.2172	.2218
17	.1052	.1097	.1227	.1526	.124	.2155	.2126
18	.1595	.1463	.1578	.1848	.1928	.0876	.2254
19	.2452	.2195	.2378	.2452	.2263	.2402	.2353
20	.2614	.2378	.2957	.2614	.2378	.2743	.2801
21	.1905	.2218	.2241	.2241	.2033	.2218	.2427
22	.1509	.1494	.1698	.168	.1494	.1646	.1886
23	.0934	.112	.0924	.1029	.0739	.0924	.1109
24	.0554	.0554	.0754	.0724	.0829	.0747	.0754
Max	.2614	.2378	.2957	.2614	.2378	.2743	.2801
Min	.0187	.0554	.0377	.037	.0701	.0497	.0566
Avg	.1162	.1216	.1226	.1354	.1367	.1477	.1500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 203 / 11 KV Here Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
1	.056
2	.0373
3	.0373
4	.0373
5	.0747
6	.1097
7	.1307
8	.1867
9	.1646
10	.1227
11	.1097
12	.1372
13	.0905
14	.128
15	.1097
16	.128
17	.1475
18	.1638
19	.1991
20	.2033
21	.1867
22	.1494
23	.0914
24	.056
Max	.2033
Min	.0373
Avg	.1191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 204 / 11 KV Hambire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.8322	1.0174	.9114	.1109	.0724	.0914
2	.0754	.7712	1.0288	.9015	.0914	.0724	.0914
3	.0189	.7712	.8573	.9431	.0914	.0732	.0914
4	.0189	.7888	.8573	.9945	.0924	.0739	.0914
5	.0187	.7802	.8745	1.0402	.0924	.0747	.0914
6	.0177	.9709	1.0288	1.0631	.1086	.0754	.1097
7	.0886	1.0631	1.2003	1.0974	.1052	.1075	.1097
8	.128	1.1191	1.166	1.1022	.1075	.1063	.1097
9	1.0402	.0671	.0914	.1052	1.2269	1.3717	.9945
10	1.326	.1492	.1052	.1086	1.6118	1.0174	1.6632
11	1.4752	.1509	.0693	.0876	1.7147	1.56	1.7318
12	1.4746	.1097	.1075	.1086	1.7147	.8817	1.749
13	1.5947	.1097	.1075	.0693	1.6278	.9602	1.4754
14	1.1401	.0732	.1086	.0914	1.3032	1.56	1.5769
15	.7042	.0732	.1086		1.283	1.4582	
16	1.3889	.1097	.1086	.0179	1.2346		1.9547
17	.1132	.1097	.1075	.1086		.1097	.128
18	.132	.0914	.1463	.0895		.0914	.1478
19	.1509	.128	.1086	.1063			.1478
20	.1509	.1097	.1075	.0876		.1097	.1478
21	.1307	.1097	.1254	.0867	.1494	.128	.1463
22	.1294	.1097	.1307	.1075	.1294	.128	.1463
23	.9189	.7537	.9536	.1086	.1075	.0914	.1075
24	.0876	.8764	.9831	.9114	.1097	.1075	.1097
Max	1.5947	1.1191	1.2003	1.1022	1.7147	1.56	1.9547
Min	.0177	.0671	.0693	.0179	.0914	.0724	.0914
Avg	.5164	.4262	.4792	.4456	.6506	.4650	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 205 / 11 KV Kuratnwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.663	.0166	.0183	.0171	1.0277	1.1271	1.3226
2	.663	.0166	.0183	.0171	.8684	.9945	1.2452
3	.663	.0164	.0183	.0168	.8619	.9945	1.2452
4	.6706	.0166	.0183	.0166	.8619	.9945	1.2452
5	.6706	.0168	.0183	.0162	.8785	.9831	1.278
6	.8139	.0709	.0732	.0162	1.094	1.3108	1.3565
7	.9831	.0895	.0732	.016	1.3245	1.3108	1.3735
8	.1905	.1494	.0914	.1663	1.291	1.326	1.3435
9		1.4251	1.6278	1.8143	.0686	.218	.3048
10	.1509	2.0178	1.8442	2.1195	.0171	.2561	.2452
11	.112	2.0233	1.9204	2.1605	.0724	.1829	.439
12	.1509	1.9204	1.9204	1.9839	.0739	.1829	.2195
13	.1509	2.0576		2.0348	.0709	.2378	.1829
14	.1509	2.1948	.8259	2.1026	.0716	.1886	.2012
15	.1698	2.1026	2.2805	1.9951	.0724	.2096	.2195
16	.1886	2.1262	2.2382	2.2291	.0914	.2667	.1463
17	.2286	.1829	.1867	.1715	.0914	.3429	.1886
18	.1509	.1829	.1829	.1663	.1715	.2641	.2263
19	.1307	.1097	.128	.1494	.1494	.2195	.2263
20	.1097	.0914		.1494	.0678	.1829	.1886
21	.0678	.0732	.0716	.1086	.0663	.1463	.1509
22	.0693	.0732	.0709	.0876	.0168	.1097	.1294
23	.0876	.0732	.0686	1.0608	1.0883	1.3763	1.5091
24	.663	.0164		.0171	1.0608	1.1271	1.2944
Max	.9831	2.1948	2.2805	2.2291	1.3245	1.3763	1.5091
Min	.0678	.0164	.0183	.016	.0168	.1097	.1294
Avg	.3434	.7110	.6522	.7764	.4774	.6064	.6784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 206 / 11 KV Adkur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	1.1401	1.1469	1.2071	.0177	.0739	.0183
2	.0183	1.0562	1.065	1.1736	.0177	.0185	.0183
3	.0185	1.0277	1.065	1.1603	.0183	.0187	.0189
4	.0185	1.0277	1.065	1.1736	.0183	.0187	.0183
5	.0739	1.0486	.7373	1.3306	.0185	.0747	.0183
6	.0747	1.1142	.9831	1.2071	.0185	.0747	.0914
7	.0739	1.2944	1.153	1.1934	.0732	.0943	.1097
8	.1132		1.1142	1.1984	.0943	.0943	.1097
9	1.4754		.1524	.1132	.8907	1.8861	1.4091
10	1.7436	.1905	.1132	.1905	1.2431	1.6385	1.6549
11	1.6324	.1509	.132	.1132	1.1934	1.7368	1.7695
12	1.6263	.1463	.132	.1132	1.2071	1.6385	1.7859
13	1.8067	.1097	.1132	.1143	1.2452	1.6575	1.7695
14	1.8652	.1463	.0943	.1524	.8962	1.7368	1.6385
15	1.8275	.1829	.132	.1132	1.012	1.7101	1.7695
16	1.7101	.1829	.132	.1143	1.1934	1.6078	1.7859
17	.0739	.1463	.132	.1524	.132	.128	.1132
18	.1509	.128	.1698	.1143	.0943	.0914	.1109
19	.132	.1097	.1524	.1132	.132	.2012	.1509
20	.132	.0914	.0943	.1132	.1132	.0732	.112
21	.1132	.0914	.0185	.1132	.1132	.0732	.112
22	.1109	.0914	.0747	.0762	.0747	.0732	.0924
23	1.2239	.9831	1.0898	.0189	.0739	.0732	.0732
24	.0183	1.2266	1.1469	1.2071	.0175	.0739	.0183
Max	1.8652	1.2944	1.153	1.3306	1.2452	1.8861	1.7859
Min	.0183	.0914	.0185	.0189	.0175	.0185	.0183
Avg	.6688	.5312	.5087	.5240	.4129	.6195	.6154



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 208 / 11 KV Chandgad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
1	.2195
2	.1829
3	.1829
4	.1848
5	.2241
6	.3326
7	.4435
8	.499
9	.5601
10	.6401
11	.6584
12	.5975
13	.5487
14	.5601
16	.5853
17	.6219
18	.499
19	.6219
20	.6908
21	.6099
22	.5415
23	.3772
24	.2195
Max	.6908
Min	.1829
Avg	.4609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 201 / 11 KV VAIJANATH

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0762	.0914	.0857	.0857	.0857	.0857
2	.0857	.0762	.0914	.0857	.0857	.0857	.0857
3	.0857	.0762	.0914	.0857	.0857	.0857	.0857
4	.0857	.0762	.0914	.0857	.0857	.0857	.0857
5	.0857	.0762	.1829	.1715	.1715	.1715	.0857
6	.1715	.0762	.3658		.4287	.2572	.1715
7	.6001	.5335	.6401	.6859	.6001	.6859	.6859
8	1.2003	.7316	1.0974	1.1145	1.0288	1.0288	.9431
9	1.1145	.823	1.0974	1.2003	1.1145	1.0288	1.1145
10	.9907	.9145	.8573	1.0288	.8573	.8573	.9145
11	.7621	.823		.8573	.6001	.6859	.9145
12	.7621	.7545	.5144	.8573		.6001	.3658
13	.6859	.7316	.6859	.6859		.6001	.5487
14	.6859	.6401	.6859	.4287		.5144	.7316
15	.4572	.7316	.6859	.3429		.4287	.7545
16	.4572	.7316	.7716	.6001	.1715	.6859	
17	.4572	.9145	.6859	.7716	.6001	1.0288	1.0974
18	.381	1.0974	.6001	1.1145		1.0288	1.1888
19	.381	.7316	.5144	.6859	.8573	.7716	.9145
20	.381	.4572	.4287	.4287	.5144	.5144	.7316
21	.3048	.3658	.3429	.3429	.4287	.4287	.3658
22	.1524	.3658	.1715	.0857	.1715	.2572	.2743
23	.0762	.2743	.1715	.0857	.0857	.2572	.1829
24	.0857	.0762	.1829	.0857	.0857	.0857	.0857
Max	1.2003	1.0974	1.0974	1.2003	1.1145	1.0288	1.1888
Min	.0762	.0762	.0914	.0857	.0857	.0857	.0857
Avg	.4390	.5065	.4804	.5181	.4241	.5108	.5397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 202 / 11 KV HITECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.9145	.6859	.6001	.6001	.4287	.6859
2	.6001	.7621	.6001	.6859	.5144	.4287	.6859
3	.6001	.6097	.5144	.6001	.4287	.3429	.6001
4	.5144	.5335	.5144	.5144	.5144	.3429	.6001
5	.5144	.4572	.5144	.4287	.6001	.3429	.6001
6	.6001	.6859	.5144	.5144	.5144	.3429	.5144
7	.6001	.4572	.5144	.6001	.4287	.3429	.5144
8	.6859	.8573	.6001	.7716	.3429	.4287	.4287
9	.6859	1.2003	.6859	.7716	.3429	.5144	.6001
10	.9145	1.3717	.6859	1.2003	.3429	1.1145	1.2003
11	1.0669	1.2003	.8573	1.4575	.4287	1.286	1.0288
12	1.1431	1.0288	1.5432	1.3717	.4287	1.0288	.7716
13	1.448		1.8861	1.5432	.4287	1.1145	1.0288
14	1.6004		1.5432	1.6289	.4287	1.2003	1.286
15	1.5242	1.3717	1.3717	1.5432	.5144	1.3717	.9431
16	1.6004	1.286	1.286	1.3717	.4287	1.3717	.7716
17	1.448	1.286	1.4575	1.2003	.4287	1.286	.8573
18	1.2193	1.286	1.3717	1.0288	.4287	1.0288	.8573
19	1.1431	.8573	.7716	.5144	.4287	1.286	.8573
20	1.0669	.5144	.5144	.6859	.5144	1.3717	.6859
21	1.0669	.5144	.3429	.6859	.4287	1.286	.6859
22	.6859	.5144	.8573	.6001	.4287	.7716	.8573
23	.9907	.6001	.7716	.5144	.4287	.7716	1.2003
24	.5144	.9907	.6859	.6859	.6001	.4287	.6859
Max	1.6004	1.3717	1.8861	1.6289	.6001	1.3717	1.286
Min	.5144	.4572	.3429	.4287	.3429	.3429	.4287
Avg	.9478	.8773	.8788	.8966	.4573	.8430	.7895

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 203 / 11 KV Angolkar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2058	.1524	.2058	.1715	.1715	.2058	.2058
2	.2058	.1524	.1715	.1715	.1715	.2058	.2058
3	.2058	.1524	.1715	.1715	.1715	.2058	.2058
4	.2058	.1524	.1715	.1715	.1715	.2058	.2058
5	.2058	.1524	.2058	.1715	.1715	.2058	.2058
6	.2058	.1524	.2058	.1715	.1715	.2572	.2058
7	.2058	.1829	.2058	.1715	.2572	.2572	.2058
8	.2058	.2572	.2058	.1715	.2572	.2572	.2058
9	.3429	.2572	.3429	.3429	.2058	.2572	.2572
10	.381	.3429	.5144	.3429	.2058	.2572	.3429
11	.4572	.3429	.4287	.4287	.2058	.4287	.3429
12	.4572	.3429	.4287	.3429	.2058	.4287	.3429
13	.4572	.3429	.3429	.3429	.2058	.4287	.3429
14	.4572	.5144	.5144	.4287	.2058	.4287	.3429
15	.4572	.5144	.4287	.3429	.2058	.4287	.3429
16	.4572	.4287	.3429	.4287	.2058	.4287	.4287
17	.4572	.3429	.4287	.4287	.2058	.4287	.4287
18	.3048	.5144	.3429	.3429	.2572	.3429	.3429
19	.2286	.3429	.3429	.3429	.2572	.3429	.3429
20	.2286	.2058	.2572	.1715	.2572	.2572	.2572
21	.1524	.2058	.2572	.2572	.2572	.2572	.2572
22	.1524	.2058	.1715	.1715	.2058	.2572	.2572
23	.1524	.2058	.1715	.1715	.2058	.2572	.2572
24	.2058	.1524	.2058	.1715	.1715	.2058	.2058
Max	.4572	.5144	.5144	.4287	.2572	.4287	.4287
Min	.1524	.1524	.1715	.1715	.1715	.2058	.2058
Avg	.2915	.2757	.2944	.2679	.2086	.3015	.2808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 204 / 11 KV Aqua

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6859	.724	.7716	.6001	.7716	.7716
2	.6859	.6859	.724	.6859	.5144	.7716	.7716
3	.6859	.6097	.724	.6001	.4287	.6859	.6859
4	.6001	.6097	.724	.6859	.5144	.6859	.6859
5	.6001	.6097	.8145	.6001	.4287	.6859	.6859
6	.6001	.6859	.8145	.6001	.5144	.6859	.7716
7	.6001	.6097	.8145	.6859	.6001	.6859	.7716
8	.6859	.724	.724	.7716	.6859	.7716	.7716
9	.8573	.905	1.086	.5144	.8573	1.0288	1.0288
10	.7621	.905	.9431	.5144	.8573	.9431	1.267
11	.7621	.8145	.7716	.4287	.9431	1.0288	1.086
12	.6859	.724	.8573	.4287	.7716	.1715	.9955
13	.6859	.724	.8573	.5144	.7716	.6001	.905
14	.6097	.905	.8573	.5144	.8573	.6859	.905
15	.7621	.905	.7716	.4287	.9431		.905
16	.7621	.905	.7716	.5144	1.0288	.8573	.905
17	.6859	.8145	.8573	.4287	.9431	.7716	.905
18	.7621	.8145	.7716	.5144	.8573	1.1145	.905
19	.7621	.905	.8573	.5144	.8573	.9431	.905
20	.7621	1.086	.9431	.5144	.7716	.7716	.905
21	.6097	.905	.8573	.6859	.7716	.7716	.905
22	.7621	.905	.9431	.6001	.8573	.8573	.905
23	.7621	.8145	.8573	.5144	.8573	.7716	.905
24	.7716	.7621	.724	.8573	.6001	.7716	.7716
Max	.8573	1.086	1.086	.8573	1.0288	1.1145	1.267
Min	.6001	.6097	.724	.4287	.4287	.1715	.6859
Avg	.7081	.7923	.8246	.5787	.7430	.7753	.8758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 201 / 11 KV AMROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0876	.0895	.1109	.0876	.112	.0876
2	.1132	.0876	.0724	.1097	.0876	.112	.0876
3	.1132	.0876	.0716	.1097	.0876	.1109	.0886
4	.112	.0886	.0724	.1109	.0876	.1109	.0876
5	.112	.1063	.0716	.1097	.1227	.112	.1052
6	.1307	.1402	.1254	.1294	.1578	.1307	.1402
7	.2054	.2103	.197	.2195	.1928	.2241	.1928
8	.2241	.2103	.2328	.2926	.2279	.2614	.1928
9	.2218	.2103	.2328	.2241	.2629	.2587	.2058
10	.2218	.2279	.2149	.2614	.1928	.2587	.1734
11	.1928	.2865	.2054	.2103	.2012	.2279	.197
12	.2103	.2149	.2427	.1928	.2561	.1928	.1791
13	.2103	.1791	.2241	.1928	.1829	.1578	.1791
14	.1402	.1433	.1307	.2012	.1448	.1417	.181
15	.124	.1086	.1294	.1578	.1463	.1402	.1612
16	.1402	.1254	.1478	.1753	.1478	.1402	.1254
17	.1753	.1612	.1867	.2103	.1663	.1402	.1791
18	.2454	.2865	.2427	.2804	.2402	.1753	.2328
19	.4382	.394	.3174	.3506	.3772	.3856	.3582
20	.3506	.4656	.4668	.3856	.4481	.4031	.4607
21	.2454	.3045	.3547	.3155	.3734	.3506	.394
22	.2103	.2149	.2987	.2454	.2614	.2804	.2507
23	.1753	.1612	.1848	.1753	.2054	.1753	.1612
24	.1307	.1052	.1075	.1294	.1227	.1307	.1227
Max	.4382	.4656	.4668	.3856	.4481	.4031	.4607
Min	.112	.0876	.0716	.1097	.0876	.1109	.0876
Avg	.1898	.1920	.1925	.2042	.1992	.1972	.1893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 202 / 11 KV BONJURDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1736				1.5089	1.4083	1.4723
2	1.2003				1.5424	1.3923	1.4548
3	1.1736				1.5424	1.3923	1.4548
4	1.1401				1.5424	1.4083	1.4548
5	1.065				1.56	1.3413	1.4373
6	1.0608				1.5775	1.2742	1.4022
7	1.2071			.0366	1.5775	1.3426	1.3321
8	1.2071			.0366	1.4899	1.3599	1.3496
9		1.7528	2.167	1.8442			
10		2.1616	2.5789	2.2298			
11		2.2207	2.5149	2.6292			
12		2.5072	2.4863	2.524			
13		2.5072	2.4478	2.4188			
14		2.6147	.6706	2.3663			
15		2.4177	2.0645	2.3312			
16		2.4893	2.0119	2.226			
17		.0716					
18		.0716	.0549				
19		.0724	.0549		.0549		.1254
20		.0905	.0549		.0554		.1267
21		.0905	.0549		.0554		.1267
22		.0716	.0549		.0549		.1267
23			.0549	1.5424	1.4251	1.4723	1.3611
24	1.2574				1.5089	1.4586	1.4723
Max	1.2574	2.6147	2.5789	2.6292	1.5775	1.4723	1.4723
Min	1.0608	.0716	.0549	.0366	.0549	1.2742	.1254
Avg	1.165	1.3671	1.2337	1.8350	1.1068	1.3850	1.0498

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 201 / 11 KV Kurani Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1295	.13	.112	.1296	.1296	.112	.1116
2	.1296	.1295	.112	.111	.1115	.112	.1116
3	.1295	.13	.112	.1109	.111	.112	.1116
4	.1109	.1111	.112	.111	.1111	.112	.1115
5	.1295	.1295	.1494	.1109	.1111	.112	.1116
6	.1663	.1481	.1867	.1296	.1296	.1494	.1488
7	.2587	.2415	.2427	.185	.185	.2241	.2045
8	.3326	.2963	.2801	.2407	.2204	.2427	.2603
9	.296	.3901	.2614	.222	.3529	.2987	.2231
10	.4259	.3145	.222	.2614	.2593	.2405	.2801
11	.4074	.259	.1848	.2614	.2786	.1861	.2054
12	.3158	.333	.1665	.1867	.2417	.2048	
13	.2407	.185	.2035	.168	.1302	.1852	
14	.2037	.259	.1667	.168	.1674	.1861	
15	.2043	.2587	.1295	.1494	.1488	.1861	
16	.296	.148	.148	.1494	.1302	.1861	
17	.2963	.2593	.1848	.1494	.1488	.1861	
18	.4272	.2614	.2963	.2043	.2054	.2045	
19	.5926	.4294	.444	.3704	.4294	.3905	
20	.5	.5601	.5185	.3715	.4854	.4835	
21	.4458	.4854	.407	.407	.4294	.4277	
22	.333	.2987	.296	.2963	.2987	.2789	
23	.1665	.1867	.1665	.13	.168	.1302	
24	.148	.1481	.1307	.148	.1296	.112	.1488
Max	.5926	.5601	.5185	.407	.4854	.4835	.2801
Min	.1109	.1111	.112	.1109	.111	.112	.1115
Avg	.2786	.2539	.2180	.1988	.2130	.2110	.1691



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 203 / Pundra AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2374	.017	.0187	.017	.373	.3391	.2713
2	.2204	.017	.0187	.017	.3391	.3391	.2713
3	.2543	.017	.0187	.017	.3391	.3391	.2713
4	.2543	.017	.017	.017	.3561	.3391	.2713
5	.2713	.017		.017	.373	.3391	.2713
6	.3052	.017	.0187	.017	.407	.3391	.3052
7	.373	.017	.0187	.017	.4409	.373	.3561
8	.4409	.017	.0373	.017	.4578	.3391	.3561
9	.017	.3222	.4239	.6274	.017	.017	.017
10	.017	.5256	.6613	.8139	.017	.017	.017
11	.017	.4917	.78	.8139	.017	.017	.017
12	.017	.5087	.8139	.8817	.017	.017	
13	.0339	.4748	.78	.8139	.017	.017	
14	.017	.5087	.78	.8139	.017	.017	
15	.0339	.39	.8139	.78	.017	.017	
16	.0339	.5256	.8139	.6783	.017	.017	
17	.0339	.0339	.017	.0339	.017	.0339	
18	.0339	.0339	.0339	.0339	.0339	.017	
19	.0339	.0339	.017	.0152	.017	.017	
20	.0339	.0339	.0339	.017	.017	.017	
21	.017	.0339	.017	.017	.017	.0339	
22	.017	.0339	.017	.017	.017	.0339	
23	.017	.017	.017	.373	.373	.2883	
24	.2543	.017	.017	.017	.373	.3391	.2543
Max	.4409	.5256	.8139	.8817	.4578	.373	.3561
Min	.017	.017	.017	.0152	.017	.017	.017
Avg	.1244	.1717	.2689	.2868	.1703	.1526	.2233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP NON SHEDDABLE EXPRESS HV FEEDERS

Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7947	.8779	.8048	.961	.8871	.7796	1.0082
2	1.0719	.7682	.9522	.6283	1.0349	.7973	1.0719
3	1.1273	.7316	.8589	.9425	1.1273	.7442	.961
4	.8686	.6401	.9795	.6838	.8316	.7442	1.0974
5		.6219	.7655	.9795	1.1088	.8859	1.0456
6	.8316	1.0608	.8962	.7762	1.1273	.929	1.1458
7	1.0719	1.0974	.9511	.6653	.8501	.8859	1.0059
8	.8871	1.0867	.6219	.8686	1.1643	.8859	1.0608
9	1.1458	1.0099	.9522	.8501	1.1273	.6733	1.1523
10	1.1458	1.0631	.7023	1.0349	.8131	.815	1.0903
11	.9795	.7888	.9145	1.0719	1.0631	.7712	1.0642
12	1.0974	.7947	.9694	1.0425	.8859	1.1016	1.0164
13	.823	1.0534	.6401	1.0751	.9991	.7655	1.0719
14	1.1523	.7282	.9511	.8299	1.0679	1.0164	.7762
15	.8779	1.0974	.6767	.9896	1.0029	.8131	1.1273
16	1.1523	.7842	.8596	1.0974	1.0099	1.1203	.8316
17	1.1706	1.0242	.9328	.7316	1.0692	.8779	1.1273
18	.823	1.0903	.823	1.0242	.9391	1.1157	.7392
19	1.1706	.8501	.6036	.7973	.815	1.1763	1.0719
20	.8779	1.1706	.961		.6485	.8596	.7762
21	1.0791	1.1949	.6653	1.1157	.5847	1.1088	1.0903
22	.9145	.8686	.6838	.8596	.6733	1.1157	1.1273
23	.8413	.8775	.9795	1.0974	.7973	.9335	.7762
24	1.0534	1.0791	.8686	.6838	1.1458	.8859	1.0349
Max	1.1706	1.1949	.9795	1.1157	1.1643	1.1763	1.1523
Min	.7947	.6219	.6036	.6283	.5847	.6733	.7392
Avg	.9982	.9317	.8339	.9046	.9489	.9084	1.0113

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 202 / 11 KV Turkewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1629	.1715	.1494	.1463	.1646	.1494	.1848
2	.1448	.1417	.1463	.1267	.1417	.128	.1463
3	.1448	.1417	.1478	.1267	.1463	.1307	.1478
4	.1463	.1417	.1494	.128	.1448	.1307	.1463
5	.1646	.1372	.1848	.1417	.1629	.1478	.1867
6	.2378	.2229	.2195	.2126	.1829	.2195	.2614
7	.4024	.4115	.3292	.3077	.3658	.4251	.4435
8	.5487	.463	.4481	.362	.5228	.3921	.439
9	.4938	.6516	.8048	.5068	.6584	.6099	.5975
10	.7087	.7545	.788	.5068	.6733	.6653	.6219
11	.8505	.6859	.5975	.3721	.7442	.7842	.6283
12	.6859	.6722	.4572	.439	.4287	.6283	.5304
13	.7316	.5487	.7316	.2743	.4801	.5914	.439
14	.4024	.4435	.4938	.3772	.3772	.4755	.5784
15	.6584	.7023	.5853	.3206	.3772	.6348	.443
16	.5487	.6722	.6036	.3475	.2743	.4805	.4572
17	.5144	.0366	.5304	.4527	.2229	.4108	.3841
18	.5487	.0373	.5093	.4755	.1543	.5228	.2743
19	.4287	.0373	.4715	.4207	.3429	.6219	.3982
20	.4115	.5544	.439		.4115	.4435	.4525
21	.3944	.4435	.4207	.4024	.4115	.4108	.4075
22	.3429	.3696	.3292	.2926	.3326	.3292	.3109
23	.2401	.2241	.2012	.2195	.2172	.2195	.2378
24	.181	.2058	.1867	.1629	.181	.1663	.2241
Max	.8505	.7545	.8048	.5068	.7442	.7842	.6283
Min	.1448	.0366	.1463	.1267	.1417	.128	.1463
Avg	.4206	.3696	.4135	.3097	.3383	.4049	.3725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 203 / Megha Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.0886	.0934	.0732	.0183	.0171	.0185
2	.0724	.1063	.1463	.1097	.0183	.0177	.0183
3	.0537	.0732	.0924	.0732	.0183	.0177	.0187
4	.0362	.1052	.128	.0914	.0183	.0177	.0183
5	.0543	.124	.1097	.0914	.0183	.0171	.0185
6	.0537	.0886	.056	.0549	.0183	.0171	.0187
7	.0179	.128	.0554	.0732	.0183	.0177	.0187
8	.0179	.1646	.056	.1829	.0183	.0171	.0185
9	.0362	.1417	.0732	.2195	.0183	.0686	.0747
10	.1448	.1772	.0554	.128	.0183	.0857	.1663
11	.1254	.1417	.1478	.0732	.0183	.1029	.1646
12	.2378	.168		.0549	.0177	.0924	.0914
13	.1097	.1848		.0366	.0177	.0747	.0549
14	.0914	.2054		.0905	.0179	.0924	.0914
15	.2012	.1867		.0732	.0177	.0924	.0732
16	.1097	.2195	.0732	.1646	.0532	.0732	.0732
17	.1448	.2033	.112	.0549	.0177	.1646	.0732
18	.0914	.168	.0943	.0183	.0183	.056	.0732
19	.0914	.112	.0732	.0183	.0177	.0185	.0183
20	.0732	.1307	.0537		.0177	.0187	.0183
21	.0549	.0924	.0179	.0183	.0177	.0187	.0183
22	.0549	.1307	.0366	.0914	.0177	.0185	.0183
23	.0183	.0924	.0914	.0183	.0177	.0187	.0914
24	.0537	.0886	.1307	.0914	.0183	.0177	.0185
Max	.2378	.2195	.1478	.2195	.0532	.1646	.1663
Min	.0179	.0732	.0179	.0183	.0177	.0171	.0183
Avg	.0847	.1384	.0848	.0827	.0195	.0480	.0528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 201 / Parle Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1463	.1433	.1433	.1448	.1433	.1494
2	.1463	.1433	.128	.1448	.1433	.104	.1478
3	.1109	.1109	.124	.1433	.1063	.1086	.1097
4	.1463	.1448	.1433	.181	.1417	.1829	.181
5	.1867	.2195	.1829	.2172	.1791	.2241	.2561
6	.2587	.2614	.2507	.2614	.2507	.2454	.2957
7	.2926	.3258	.3361	.3258	.3292	.3224	.3326
8	.4252	.3814	.4557	.4115	.394	.3898	.3982
9	.5144	.4161	.4409	.4458	.4252	.4508	.4161
10	.463	.3688	.39	.4115	.3772	.2774	.3391
11	.4557	.3201	.333	.3887	.2984	.3086	.407
12	.3506	.2743	.2804	.4062	.2881		.3913
13	.3155	.2743	.3155	.2652	.253	.1372	.3311
14	.3155	.2713		.2683	.2241	.1372	.2622
15	.4382	.2561		.2743	.1966	.3155	.3277
16	.3292	.3391	.333	.2804	.3052	.2804	.421
17	.3761	.3521	.3506	.2949	.2743	.3155	.4111
18	.4012	.4908	.421	.3277	.4801	.3688	.5144
19	.6219	.6379	.5487	.5853	.5792	.5121	.5792
20	.5975	.6447	.5914	.5853	.6516	.5853	.6516
21	.4854	.5175	.5544	.5175	.5792	.5544	.5487
22	.2987	.4435	.4108	.3696	.4024	.4066	.4066
23	.2241	.1848	.2241	.1848	.2195	.2263	.2534
24	.1829	.1848	.1829	.181	.1433	.1448	.1494
Max	.6219	.6447	.5914	.5853	.6516	.5853	.6516
Min	.1109	.1109	.124	.1433	.1063	.104	.1097
Avg	.3369	.3212	.3246	.3173	.3078	.2931	.3450

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 202 / Here Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328		.5898	.4915	.0328	.0328	.0316
2	.0328		.5571	.4588	.0328	.0328	.0328
3	.0328		.5571	.3932	.0328	.0328	.0328
4	.0328		.5571	.426	.0328	.0328	.0328
5	.0328		.6226	.5243	.0328	.0328	.0328
6	.0328		.6226	.6554	.0328	.0328	.0328
7	.0328		.6554	.7209	.0328	.0328	.0328
8	.0328		.6882	.6554	.0328	.0328	.0328
9	.7865		.0164	.0328	.6554	.852	.852
10	1.1633	.016	.0168	.0164	.9831	1.2944	1.1797
11	1.0978	.0164	.0166	.0164	.9995	1.278	1.3108
12	1.0814	.0164	.0166	.0164	.9831	1.278	1.1797
13	1.1105	.0164	.0168	.0164	.9831	.9831	1.3108
14	1.1271	.0164		.0171	.9831	.9831	1.2452
15	1.1869	.0164		.0171	.9831	.9945	1.278
16	1.1736	.0164	.0168	.0164	.9831	1.2763	1.2452
17	.0335	.0164	.0168	.0164	.0164	.0335	.0164
18	.0335	.0328	.0328	.0164	.0328	.0328	.0164
19	.0335	.0328	.0328	.0328	.0328	.0328	.0164
20	.0328	.0328	.0328	.0328	.0328	.0328	.0328
21	.0328	.0328	.0328	.0343	.0328	.0328	.0328
22	.0328	.0328	.0328	.0339	.0328	.0328	.0328
23		.6554	.6783	.0328	.0328	.0328	
24	.0328		.6226	.6226	.0328	.0328	.0328
Max	1.1869	.6554	.6882	.7209	.9995	1.2944	1.3108
Min	.0328	.016	.0164	.0164	.0164	.0328	.0164
Avg	.4009	.0679	.2923	.2207	.3359	.3944	.4367

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 203 / Patane ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2652	.0335	.0168	.061	.8817	.6371	.8817
2	.1989	.0339	.017	.0602	.8848	.5636	.7712
3	.1677	.0347	.0168	.0579	.8951	.503	.6554
4	.3688	.0362	.017	.0587	.8745	.5243	.7461
5	.503	.0366	.017	.061	.9259	.6081	.8139
6	.5304	.0362	.017	.0579	.9156	.8048	.9156
7	.57	.0373		.0587	.8573	.9496	1.0513
8	.5426	.0373	.017	.0747	.961	.9156	1.0631
9	.037	.8048	1.1142	1.073	.0739	.0686	.0747
10	.0366	1.3108	1.5424	1.7295	.0739	.0686	
11	.0366	1.2452	1.5089	1.7924	.0351	.0514	.0181
12	.0366	1.1797	1.5432	1.6956	.0351	.0514	.0358
13	.0358	1.4083	1.5775	1.6956	.0351	.0549	.0732
14	.0351	1.4083		1.4746	.0343	.0514	.0362
15	.0175	1.4922		1.4403	.0339	.0335	.0739
16	.0171	1.3904	1.5604	1.406	.0347	.0335	.0754
17	.0171	.0328	1.5604	.0133	.0358	.0335	.0754
18	.0351	.0347	.0143	.0105	.0366	.0301	.0747
19	.0347	.0358	.0305	.0347	.037	.0305	.0739
20	.0343	.0339	.032	.0343	.0366	.0724	.0648
21	.0347	.0305	.064	.0343	.0358	.0693	.0663
22	.0347	.0339	.064	.0339	.0732	.0351	.0301
23	.0347	.0255	.0579	.8478	.8139	.9496	1.2071
24	.57	.0339	.0335	.0572	.8478	.8478	.9835
Max	.57	1.4922	1.5775	1.7924	.961	.9496	1.2071
Min	.0171	.0255	.0143	.0105	.0339	.0301	.0181
Avg	.1748	.4494	.5153	.5776	.3945	.3328	.4288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 201 / 11 KV Mangao VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0732	.0914	.0895	.0914	.0739	.0895
2	.0747	.0554	.0739	.0905	.0739	.0724	.0905
3	.0747	.0716	.0732	.0732	.0739	.0549	.0732
4	.0747	.0532	.0543	.0724	.0739	.0732	.0709
5	.0747	.0943	.0732	.0905	.0739	.1075	.0709
6	.0934	.1307	.1097	.1097	.1097	.128	.1075
7	.128	.1433	.1294	.1463	.1646	.1448	.1402
8	.1791	.1595	.1772	.1595	.1791	.1772	.1402
9	.156	.1526	.1387	.1715	.156	.1578	.1433
10	.156	.1844	.1578	.1865	.1734	.1402	.1433
11	.1526	.1387	.1387	.1417	.1029	.12	.1086
12	.1311	.1372	.1387	.1357	.1174	.1311	.1075
13	.116	.116	.112	.0995	.1063	.1357	.1075
14	.0693	.1311	.1097	.1029	.0686	.1372	.1433
15	.0701	.104	.0747	.0848	.0848	.1357	.1402
16	.0671	.1017	.0876	.1227	.0876	.1052	.1433
17	.0995	.1326	.0995	.1017	.0867	.1227	.1595
18	.1402	.1214	.1753	.1214	.1017	.2195	.1526
19	.2012	.2012	.2279	.2172	.2353	.2195	.2328
20	.2507	.2534	.2534	.2686	.2686	.2534	.2378
21	.2172	.2534	.2353	.2534	.2195	.2353	.2378
22	.1829	.2012	.2218	.2012	.1829	.181	.2012
23	.1109	.1463	.1646	.1478	.1267	.1086	.1307
24	.112	.0905	.1097	.1086	.1109	.0934	.0914
Max	.2507	.2534	.2534	.2686	.2686	.2534	.2378
Min	.0671	.0532	.0543	.0724	.0686	.0549	.0709
Avg	.1261	.1353	.1345	.1374	.1279	.1387	.1360



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 202 / 11 KV Vargao AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3887	.0162	.0133	.0316	.2984	.2656	.192
2	.3239	.0324	.013	.0328	.2984	.2896	.1943
3	.3239	.016	.0137	.0332	.2949	.3441	.176
4	.3277	.0312	.0141	.0316	.3113	.4001	.1781
5	.2949	.0152	.0137	.0324	.426	.4744	.1943
6	.2984	.0332	.0282	.0328	.7865	1.0277	.2105
7	.7773	.0316	.029	.0312	1.065	1.0526	.2915
8	.7935	.0351	.0316	.0339	.7773	.9393	.2561
9	.0537	.6562	.8097	.8907	.0492	.052	.0187
10	.0147	1.0082	1.004	1.0562	.0309	.0335	.0189
11	.016	.8356	.8907	.7935	.0526	.0537	.0189
12	.0354	.8029	.7362	.6964	.0112	.0537	.0377
13	.0347	.7773	.7287	.6802	.0137	.0537	.0189
14	.0166	.6401	.6478	.5992	.0335	.0358	.0187
15	.0347	.7287	.5668	.5693	.0514	.0343	.0187
16	.0328	.8162	.8907	.8421	.0532	.0324	.0377
17	.0332	.032	.0267	.0324	.0347	.0189	.0566
18	.0156	.0312	.0286	.032	.0381	.0754	.0572
19	.0309	.0312	.0305	.0343	.0335	.0754	.0572
20	.032	.0309	.0324	.0328	.0328	.0572	.0566
21	.0154	.0312	.0305	.0324	.0297	.0572	.0189
22	.032	.0309	.0293	.0309	.032	.0572	.0187
23	.0305	.0131	.0332	.3315	.1718	.1943	.2294
24	.4588	.0316	.013	.0316	.2984	.2458	.192
Max	.7935	1.0082	1.004	1.0562	1.065	1.0526	.2915
Min	.0147	.0131	.013	.0309	.0112	.0189	.0187
Avg	.1840	.2795	.2773	.2894	.2177	.2468	.1070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 203 / 11 KV Lakkikate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.6874	.5735	.5571	.0566	.0373	.056
2	.0358	.7202	.4588	.5506	.0566	.0554	.0566
3	.0358	.7274	.4801	.5506	.0566	.0572	.0566
4	.0358	.788	.5121	.5601	.0566	.0381	.0566
5	.0358	.8139	.583	.5668	.0566	.056	.0566
6	.0358	.8259	.6401	.6081	.0566	.0566	.0566
7	.0549	.8356	.6882	.663	.0754	.0566	.056
8	.0358	.8259	.664	.7125	.1132	.0754	.0754
9	1.7772	.0187	.0373	.0328	1.0159	1.2125	1.2929
10	2.2043	.0185	.0377	.0377	1.4255	1.2616	1.4419
11	2.323	.0377		.0189	1.3435	1.1498	1.4251
12	2.2298	.0377	.0377	.0189	1.4582	1.2146	1.3765
13	2.1293	.0377	.0189	.0189	1.3927		1.2963
14	2.0222	.0377	.0189	.0189	1.4419	1.2146	1.3117
15	1.7901	.0566	.0189	.0189	1.3592	1.2125	1.2955
16	1.8399	.0187	.0189	.0377	1.278	1.2289	1.2955
17	.0181	.0187	.0377	.0189	.0377	.0358	.0924
18	.0187	.0377	.0377	.0377	.0187	.0358	.0747
19	.056	.0754	.0566	.0566	.0566	.0747	.1132
20	.056	.0754	.0566	.0566	.0566	.0554	.0754
21	.056	.0754	.0566	.0566	.0566	.0747	.0754
22	.0377	.0754	.0566	.0566	.0566	.0549	.0754
23	.6962	.663	.5868	.0566	.0566	.0747	.0747
24	.0358	.7127	.6464	.5801	.0566	.0566	.056
Max	2.323	.8356	.6882	.7125	1.4582	1.2616	1.4419
Min	.0181	.0185	.0189	.0189	.0187	.0358	.056
Avg	.7332	.3426	.2749	.2455	.4850	.4082	.4935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144120 / 33/11 KV Tudiye

Feeder No / Name : 201 / 11 KV Tudiye VG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661	.5548	.6161		.5914		.9671
2	.6201	.5373	.5729		.5544		.8596
3	.5487	.4656	.5228		.5228		.695
4	.6661	.4784	.6468		.5487		.6626
5	.7087	.4961	.8962		.7316		.8413
6	.788	.7265	1.1641		1.0029		1.1393
7	1.406	1.3056	1.4352		1.5769		2.0405
8	2.4143	2.0454	2.1963		2.332		2.6658
9	1.6956	2.9127	2.7161		2.8656		2.5724
10	2.7808	2.5434		2.8502	2.4697		2.8121
11	2.934	2.5194		3.0664		2.6189	.431
12	2.8166	2.652		2.8012		2.9835	1.1683
13	2.8669	2.5194		2.7183		2.6355	1.186
14	2.8826	2.3304		2.6852		2.7328	1.1142
15	2.4813	2.1963		2.5232		2.6189	.0051
16	2.9007	2.696		2.9504		1.2346	3.5608
17	2.9172	2.6113		1.6278		1.2289	3.0864
18	2.9338	2.8317		2.7161			.9393
19	1.9765	1.6301		2.332		2.5377	.9465
20	1.4899			1.5415		1.9938	.7973
21	1.1462	1.0791		1.2403		1.6991	.6878
22	.9922			1.1104		.4681	.5792
23	.7796	.8131		.8688		1.262	.4656
24	.7164	.6135	.7207		.7682		1.0517
Max	2.934	2.9127	2.7161	3.0664	2.8656	2.9835	3.5608
Min	.5487	.4656	.5228	.8688	.5228	.4681	.0051
Avg	1.7553	1.6617	1.1487	2.2166	1.2695	2.0012	1.3031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 401 / Aqua

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18
HR	Load (MW)
24	.6173
Max	.6173
Min	.6173
Avg	.6173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 407 / 33 KV KEMPLAST NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18
HR	Load (MW)
23	.3989
Max	.3989
Min	.3989
Avg	.3989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 201 / 11 KV GADHINGLAJ

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.8048	.6219	.6219	.6036	.6584	.6584
2	.6036	.8048	.5853	.5853	.6036	.6584	.6379
3	.6036	.7682	.5853	.5914	.5853	.6219	.6036
4	.6036	.7682	.5853	.5853	.5853	.6219	.6036
5	.6584	.8048	.7316	.6584	.6219	.6584	.6036
6	1.0059	.9511	1.0242	.8048	.8413	.8048	1.0608
7	1.2803	1.2437	1.2071	1.0242	1.0985	1.2071	1.1157
8	1.3169	1.3717	1.2803	1.1706	1.2803	1.3169	1.3169
9	1.2323	1.2803	1.1706	1.134	1.1088	1.1949	1.3169
10	1.1949	1.1827	1.2071	1.2567	1.1203	1.2071	1.2437
11	1.2567	1.0974	1.2071	1.2437	1.1203	1.1827	1.3717
12	1.2696		1.1706	1.2071	1.1203	1.1706	1.3169
13	1.1949	1.134	1.0608	1.134	1.0242	1.2437	1.2071
14	1.1949	1.0242	1.0242	1.0974	.9877	1.1706	1.2071
15	1.1827	1.0974	1.0059	1.0974	1.0974	1.1949	1.3169
16	1.1706	1.2567		1.134	1.0974	1.2323	1.3169
17	1.2071	1.2803		1.0974	1.0608	1.134	1.2803
18	1.2803	1.419	1.1706	1.0974	1.0974	1.2437	1.4266
19	1.6827	1.7924	1.6095	1.6095	1.5729	1.6278	1.6461
20	1.6461	1.7193	1.4998	1.3169	1.4998	1.3535	1.4998
21	1.4815	1.4563	1.3169	1.0974	1.3717	1.3535	1.2048
22	1.2437	1.2197	1.1827	1.0608	1.2071	1.1157	
23	.9877	.9511	.8871		.8779	.9877	
24	.6219	.823	.7682	.7316	.7316	.695	.695
Max	1.6827	1.7924	1.6095	1.6095	1.5729	1.6278	1.6461
Min	.6036	.7682	.5853	.5853	.5853	.6219	.6036
Avg	1.1059	1.1414	1.0410	1.0155	1.0131	1.0690	1.1205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 204 / 11 KV Uttur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631	1.1385	.2195	.2195	.2641	1.3283	1.3927
2	1.2308	1.0753	.2195	.2195	.2641	1.2967	1.4089
3	1.2308	1.0883	.2195	.2195	.2263	1.2498	1.4251
4	1.2308	1.0883	.2195	.2195	.2263	1.2651	1.4251
5	1.3927	1.1523	.2561	.2195	.2263	1.3283	1.587
6	1.5223	1.3123	.3292	.2587	.2641	1.4723	1.6842
7	1.8299	1.5181	.4024	.2957	.3772	2.2771	2.2186
8	2.1052	1.9845	.439	.3658	.3961	2.5301	2.5911
9	.2614	1.6004	1.6032	1.8244	.056	.3734	.3772
10	.2614	2.1125	2.0729	2.5606	.3361	.3734	.3018
11	.1494	2.4006	2.4291	2.5606	.2987	.3658	.3018
12	.1867	2.5301	2.5101	2.4326	.2957	.2926	.2263
13	.2241	2.3045	2.5263	2.3685	.2926	.2926	.3018
14	.2218	2.4036	2.1052	2.4326	.2926	.2926	.2452
15	.2241	2.3087	2.4777	2.5301	.2378	.2241	.2452
16	.2195	2.2771		2.6566	.2926	.1867	.1886
17	.2641	.3658	.2957	.3395	.3206	.2263	.2641
18	.415	.3658	.2926	.3018	.3772	.2641	.3584
19	.4527	.4572	.3696	.4715	.4715	.415	.5093
20	.4338	.439	.4435	.4715	.4904	.415	.4527
21	.415	.4481	.3658	.4527	.4527	.415	.415
22	.3772	.3696	.4024	.3961	.415	.415	
23	1.1523	.0366	.2926		1.3279	1.2955	
24	1.2631	1.1523	.2195	.2195	.2641	1.3283	1.3927
Max	2.1052	2.5301	2.5263	2.6566	1.3279	2.5301	2.5911
Min	.1494	.0366	.2195	.2195	.056	.1867	.1886
Avg	.7636	1.3304	.9005	1.0451	.3528	.8301	.8779

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 205 / 11 KV Nool Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6401	.0366	.037	.0566	.7274	.7611
2	.6478	.6081	.0366	.037	.0377	.7116	.7611
3	.6478	.6081	.0366	.037	.0377	.7116	.7611
4	.6478	.6009	.0366	.037	.0377	.7202	.7773
5	.7125	.6478	.0366	.037	.0377	.7202	.7773
6	.7773	.7042	.0366	.037	.0377	.759	.7773
7	.8583	.7682	.0366	.037	.0754	.8855	.8745
8	.8745	.8962	.0549	.0366	.0566	.9922	.8907
9	.0373	.8322	.8259	.8421	.056	.037	.0566
10	.0373	.9717	.9069	1.1385	.0373	.3658	.0566
11	.0739	.8962	1.1012	1.0883	.8215	.056	.0754
12	.0747	1.0242	1.166	1.0242	.0373	.0732	.0754
13	.0747	1.0883	1.166	1.1385	.0549	.0732	.0754
14	.0373	1.0562	1.0688	1.0753	.0549	.0732	.0754
15	.0747	1.0883	1.1498	1.0437	.0366	.056	.0754
16	.0366	1.0242		1.0562	.0366	.0754	.0754
17	.0754	.0732		.0377	.0566	.0566	.0566
18	.0754	.0914	.0732	.0377	.0566	.0566	.0566
19	.0754	.0732	.037	.0566	.0566	.0566	.0566
20	.0754	.0549	.037	.0566	.0754	.0566	.0566
21	.0754	.0373	.0366	.0566	.0566	.0566	.0566
22	.0754	.037	.0366	.0566	.0566	.0566	
23	.6722	.0366	.037		.7362	.6802	
24	.6154	.6478	.0366	.037	.0566	.7432	.7449
Max	.8745	1.0883	1.166	1.1385	.8215	.9922	.8907
Min	.0366	.0366	.0366	.0366	.0366	.037	.0566
Avg	.3333	.6044	.3632	.3931	.1110	.3667	.3625



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 207 / 11 KV WATERWORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.3018	.2195	.3292	.3292	.2641	.2561
2	.2195	.2263	.1829	.2195	.2926	.2263	.2012
3	.2195	.2263	.1829	.1829	.2195	.2263	.2012
4	.2012	.2263	.1829	.1829	.2195	.2263	.2012
5	.2012	.2263	.1829	.1829	.1646	.2263	.2195
6	.2012	.2263	.2195	.2195	.1646	.2452	.2195
7	.2012	.2452	.2378	.2195	.2195	.2641	.2378
8	.2378		.2926	.2926	.2926	.3206	.2378
9	.4108	.1848	.3475	.415	.4066	.4108	.3772
10	.3734	.2033	.3475	.3961	.3734	.3658	.415
11	.4108	.4024	.3475	.415	.3734	.3881	.3772
12	.2987	.2926		.3206	.3734	.3658	.3206
13	.2987	.2926	.2012	.3018	.2926	.3292	.3018
14	.2987	.3292	.2926	.3018	.2926	.3292	.3018
15	.2587	.2926	.2926	.2829	.2926	.2957	.3018
16	.2561	.2195		.2452	.2561	.2241	.2641
17	.2263	.2241	.2218	.2195	.2263	.2012	.2195
18	.1052	.2241	.2561	.1646	.1402	.2012	.1829
19	.2452	.0732	.1478	.2012	.1509	.1097	.2012
20	.2075	.1829	.1478	.2012	.2263	.1097	.2012
21	.2452	.2427	.2195	.1829	.2452	.2378	.2195
22	.3395	.3326	.3292	.2561	.3018	.2926	
23	.415	.3292	.2926		.3395	.3841	
24	.3658	.3395		.3696	.3292	.3395	.3658
Max	.415	.4024	.3475	.415	.4066	.4108	.415
Min	.1052	.0732	.1478	.1646	.1402	.1097	.1829
Avg	.2706	.2541	.2450	.2653	.2718	.2743	.2647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 210 / 11 KV Uttur VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2172	.2195	.2195	.2195	.2172	.2195
2	.2561	.2172	.1829	.2195	.2195	.2172	.2195
3	.2195	.2172	.1829	.1829	.2012	.2172	.2195
4	.2195	.2172	.1829	.1829	.2012	.2172	
5	.1829	.2534	.1829	.2587	.1646	.2195	.2195
6	.2195	.2896	.3292	.3292	.2561	.2715	.2561
7	.3475	.362	.4024	.4024	.3292	.3475	.2926
8	.3658	.3982	.4024	.3658	.3841	.3258	.3841
9	.4435	.3696	.3658	.4163	.4108	.3734	.3982
10	.4481	.3658	.3658	.3982	.4435	.3734	.3982
11	.6653	.439	.4024	.3982	.4481	.4108	.4344
12	.4805	.439	.3841	.3982	.4481	.4024	.4344
13	.3734	.3658	.2926	.3801	.4572	.3841	.3658
14	.3696	.3292	.3841	.362	.439	.4024	.362
15	.3361	.3326	.3109	.362	.2926	.3734	.362
16	.3658	.3658		.362	.2926	.4481	.4344
17	.3982	.3658	.4066	.3658	.362	.3841	.4207
18	.4344	.439	.4435	.3658	.3982	.439	.439
19	.6335	.5853	.5914	.567	.5792	.5304	.5853
20	.6154	.6584	.6283	.5121	.6154	.4938	.5487
21	.5068	.5121	.5121	.4755	.4887	.439	.5121
22	.4163	.4108	.439	.3841	.4344	.3841	
23	.2534	.2195	.2926		.2896	.2378	
24	.2926	.2172	.2195	.2195	.2561	.2172	.2195
Max	.6653	.6584	.6283	.567	.6154	.5304	.5853
Min	.1829	.2172	.1829	.1829	.1646	.2172	.2195
Avg	.3792	.3578	.3532	.3534	.3596	.3469	.3679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 211 / 11KV Belbag

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.6219	.5487	.5487	.5281	.5853	.6036
2	.6036	.5853	.5121	.5121	.5281	.5487	.6036
3	.6036	.5853	.5121	.5121	.5281	.5487	.6036
4	.6036	.5853	.5121	.5121	.5281	.543	.679
5	.7167	.6219	.5487	.5121	.5658	.5853	.7167
6	.7922	.695	.695	.6219	.679	.695	.7545
7	.8488	.8048	.8048	.695	.8488	.7682	.8676
8	.9619	.9511	.8779	.7392	.8299	.9145	.9997
9	.9335	.9877	.7922	.7682	.9335	.8962	.9511
10	.8589	.8413	.8299	.8779	.8589	.8215	.8779
11	.8215	.8779	.8488	.8413	.8215	.8962	.8413
12	.8215	.8871	.9619	.8048	.8215	.8413	.9511
13	.8962	.8048	.8676	.823	.7499	.7316	.9511
14	.8131	.7682	.8299	.823	.7316	.7316	.8596
15	.8501	.7316	.8299	.8048	.6584	.7842	.8779
16	.8779	.8871		.7865	.7316	.8215	.8596
17		.8779	.8131	.9054	.7682	.9619	.9054
18	1.1706	.9877	.961	.9619	.8413	1.0562	
19	1.3169	1.2437	1.2437	1.3014	1.134	1.2071	1.3392
20	1.2437	1.2437	1.1827	1.1694	1.134	1.1128	1.226
21	1.0242	1.0082	1.0242	1.0185	.9877	1.094	1.0185
22	.8779	.9335	.8413	.8676	.8779	.8488	
23	.695	.8413	.695		.6584	.6036	
24	.6224	.6219	.5487	.5853	.6036	.5853	.6036
Max	1.3169	1.2437	1.2437	1.3014	1.134	1.2071	1.3392
Min	.6036	.5853	.5121	.5121	.5281	.543	.6036
Avg	.8503	.8331	.7948	.7823	.7645	.7993	.8615

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 201 / 11 Kv Karambali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1523	.9511	.2195	.1715	.1829	1.0974	1.166
2	1.134	.9328	.2195	.1715	.2195	1.0608	1.166
3	1.134	.9328	.2378	.1715	.2561	1.0974	1.166
4	1.0974	.9328	.2195	.1886	.2743	1.134	1.166
5	.9877	.9877	.2195	.1886	.2743	1.1888	1.1488
6	1.0974	1.0608	.2195	.2058	.2926	1.1888	1.1488
7	1.4083	1.2986	.2378	.2058	.3292	1.5364	1.4746
8	1.6095	1.4998	.3109	.2058	.3658	1.7924	1.6118
9	.2926	1.3535	1.5729	1.2689	.3658	.2926	.2401
10	.2926	1.7558	1.9387	1.7833	.3658	.1829	.2743
11	.2926	1.8347	1.9753	2.1948	.3086	.2561	.2195
12	.3292	1.749	1.829	1.9204	.2058	.2561	.2378
13	.3109	1.7833	1.9022	1.9022	.1886	.2561	.2195
14	.3292	1.7147	1.7193	1.8839		.1829	.2012
15	.3658	1.829	1.7741	1.829	.1829	.128	.2195
16	.3658	1.9753	1.7193	1.9204	.2058	.3109	
17		.2926	.1886	.3109	.2378	.3475	.3658
18	.2195	.3292	.2743	.3292	.2743	.2743	.3109
19	.3658	.3658	.2743	.3292	.2561	.3429	.3475
20	.3475	.3109	.2743	.3109	.2926	.2401	.3841
21		.2926	.2572	.2926	.2561	.2572	.3658
22	.3109	.3121	.2058	.2378	.2195	.2058	.2195
23	1.0608		.1715	.2012	1.2254	1.2346	1.1706
24	1.1523	.9877	.1829	.1715	.2012	1.2437	1.2003
Max	1.6095	1.9753	1.9753	2.1948	1.2254	1.7924	1.6118
Min	.2195	.2926	.1715	.1715	.1829	.128	.2012
Avg	.7116	1.1079	.7560	.7665	.3035	.6712	.6967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 202 / 11 KV Kaulage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8097	.7625				.7125	.6401
2	.8097	.7459				.7125	.6401
3	.8421	.7459				.7287	.6401
4	.8288	.7459				.7773	.6401
5	.8122	.7459				.7773	.6401
6	.9116	.7459				.8097	.7011
7	.9448	.8619				.8421	.7468
8	.9116	.8951				.7127	.7468
9		.8288	.9614	.7316			
10		1.1271	1.1271	1.1831			
11		1.0974	1.1603	1.0277			
12		1.0364	1.0774	1.0774			
13		1.0974	1.1437	.9945			
14		1.0059	1.1768	1.1934			
15		1.0277	1.0442	1.1768			
16		1.1603	1.1437	1.1271			
23	.8122				.6796	.6401	
24	.8288	.7956				.6962	.6554
Max	.9448	1.1603	1.1768	1.1934	.6796	.8421	.7468
Min	.8097	.7459	.9614	.7316	.6796	.6401	.6401
Avg	.8512	.9074	1.1043	1.0640	.6796	.7409	.6723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 203 / 11 KV Ainapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.749	1.6766	1.8187		
2		1.7814	1.6156	1.8023		
3		1.6194	1.6156	1.8023		
4		1.587	1.6156	1.8023		
5		1.5384	1.9814	1.8351		
6		1.5384	2.2634	1.8515		
7		1.9919	2.0119	2.0809		
8		2.1376	2.0271	2.4249		
9	2.4939			2.1792	2.0081	1.9204
10	2.7692			2.7526	2.8178	2.4291
11	2.8178			2.7435	2.8837	2.5911
12	2.8178			2.5606	2.7526	2.5101
13	2.753			2.4539	2.3266	2.5587
14	2.7206			2.4996	2.5232	2.6882
15	2.7854			2.4387	2.4577	2.7206
16	2.5911			2.3777	2.3922	2.6073
18					.0457	
23		1.9204	1.6549			
24		1.7652	1.768	1.8351		
Max	2.8178	2.1376	2.2634	2.7526	2.8837	2.7206
Min	2.4939	1.5384	1.6156	1.8023	.0457	1.9204
Avg	2.7186	1.7629	1.8230	2.1917	2.2453	2.5032

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2587	.2772	.2401	.2772	.2587	.2743
2	.2218	.2402	.2772	.2401	.2402	.2587	.2743
3	.2218	.2402	.2772	.2401	.2402	.2772	.2743
4	.2218	.2772	.2772	.2401	.2402	.2587	.2743
5	.2957	.3326	.3326	.2401	.2772	.3326	.3086
6	.4066	.3881	.3696	.2743	.2957	.3696	.3429
7	.4251	.4435	.4435	.4115	.3696	.4805	.4115
8	.462	.4251	.4435	.4287	.4066	.4066	.4458
9	.4805	.462	.499	.4287	.3696	.4435	.4458
10	.462	.4251	.462	.4115	.4066	.5175	.4251
11	.4251	.3944	.5359	.4805	.3601	.4251	.4805
12	.3696	.3086	.3881	.4435	.2743	.3658	.462
13	.2957	.3086	.2957	.3326	.2401	.4066	.4251
14	.2772	.2915	.2957	.2957	.2401	.4066	.3696
15	.3696	.3326	.3881	.3326	.2401	.4024	.3881
16	.3881	.3881	.3881	.3696	.3086	.4805	.4066
17	.3881	.4066	.4801	.4251	.3142	.4805	.4251
18	.5175	.5729	.4801	.4435	.2591	.4115	.5175
19	.6838	.6468	.6173	.6099	.4372	.6344	.6283
20	.6653	.6099	.583	.7023	.5544	.583	.6283
21		.6283	.4973	.5729	.6283	.6173	.5544
22	.4805	.6099	.4458	.4805	.5359	.4801	.5175
23	.3511		.3086	.3326	.3511	.3258	.3142
24	.2218	.3142	.2587	.2572	.2772	.3326	.3086
Max	.6838	.6468	.6173	.7023	.6283	.6344	.6283
Min	.2218	.2402	.2587	.2401	.2401	.2587	.2743
Avg	.3849	.4046	.4009	.3847	.3393	.4148	.4126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 205 / KCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0189	.0191	.0189	.0189	.0191
2	.0189	.0191	.0189	.0191	.0189	.0189	.0191
3	.0189	.0191	.0189	.0191	.0189	.0189	.0191
4	.0189	.0191	.0189	.0191	.0189	.0189	.0191
5	.0189	.0191	.0189	.0191	.0189	.0189	.0191
6	.0189	.0191	.0189	.0191	.0189	.0189	.0191
7	.0189	.0191	.0189	.0191	.0189	.0189	.0191
8	.0189	.0191	.0189	.0191	.0189	.0189	.0191
9	.0189	.0191	.0191	.0191	.0189	.0189	.0191
10	.0189	.0191	.0191	.0191	.0189	.0189	.0189
11	.0189	.0191	.0191	.0189	.0191		.0189
12	.0189	.0191	.0191	.0189	.0191	.0189	.0189
13	.0189	.0191	.0191	.0189	.0191	.0189	.0189
14	.0189	.0191	.0191	.0189	.0191	.0189	.0189
15	.0189	.0189	.0191	.0189	.0191	.0189	.0189
16	.0189	.0189	.0191	.0189	.0171	.0189	.0189
17	.0191	.0189	.0191	.0189	.0189	.0189	.0191
18	.0191	.0189	.0191	.0189	.0189	.0191	.0191
19	.0191	.0189	.0191	.0189	.0189	.0191	.0191
20	.0191	.0189	.0191	.0189	.0189	.0191	.0191
21		.0189	.0191	.0189	.0189	.0191	.0191
22	.0191	.0189	.0191	.0189	.0189	.0191	.0191
23	.0191		.0191	.0189	.0189	.0191	.0191
24	.0189	.0191	.0189	.0191	.0189	.0189	.0191
Max	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Min	.0189	.0189	.0189	.0189	.0171	.0189	.0189
Avg	.0190	.0190	.0190	.0190	.0189	.0190	.0190



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.112	.112	.0934	.1307	.112	.056
2	.1494	.0747	.056	.0934	.1494	.056	.056
3	.1494	.056	.056	.0747	.0934	.0373	.056
4	.0747	.056	.056	.0747	.056	.0373	.056
5	.0747	.056	.056	.0747	.0373	.0373	.0747
6	.056	.056	.056	.056	.0373	.0373	.0747
7	.056	.056	.056	.056	.0373	.056	.056
8	.056	.056	.056	.056	.0373	.0373	.056
9	.0747	.056	.056	.056	.056	.056	.0747
10	.0934	.056	.4294	.112	.056	.3547	.0934
11	.112	.112	.4854	.2054	.1307	.4108	.1867
12	.168	.4854	.4854	.1867	.0373	.1867	.1867
13	.168	.2614	.4854	.168	.1494	.4854	.1867
14	.1494	.1307	.1494	.1307	.1307	.4668	.1494
15	.2054	.2054	.1494	.3734	.0747	.2241	.1867
16	.1867	.1867	.2054	.3921	.0747	.5041	.1867
17	.1867	.168	.168	.3734	.1494	.5041	.1494
18	.168	.4108	.1494	.168	.1494	.5228	.1494
19	.1494	.4854	.112	.1307	.168	.1494	.1494
20	.168	.0747	.0747	.112	.1307	.0934	.1052
21	.1307	.0934	.056	.0373	.112	.0747	.0747
22	.1307	.056	.0934	.112	.1494	.0747	.3734
23	.1307	.112	.112	.112	.1307	.1307	.4481
24	.1307	.112	.112	.0934	.112	.112	.112
Max	.2054	.4854	.4854	.3921	.168	.5228	.4481
Min	.056	.056	.056	.0373	.0373	.0373	.056
Avg	.1299	.1470	.1595	.1393	.0996	.1984	.1374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 202 / Shendri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0187	.5935	.5426	.4578	.0362	.0187
2	.0747	.0187	.5596	.5426	.4578	.0362	.0187
3	.0373	.0187	.5596	.5426	.4578	.0181	.0187
4	.0373	.0187	.5596	.5426	.5087	.0181	.0187
5	.056	.0373	.5935	.5426	.5596	.0181	.0187
6	.0747	.056	.6443	.5596	.4578	.0543	.0373
7	.1132	.0747	.8139	.9326	.6613	.0905	.0934
8	.1478	.112	1.0682	1.0174	.78	.1086	.112
9	.7122	.0934	.0724	.0934	.6952	.6443	.8029
10	1.0802	.1109	.0701	.0943	1.0513	1.0288	1.1401
11	1.1831	.1267	.0876	.0739	1.153	1.3032	1.3056
12	1.1317	.1086	.0701		.8987	1.3226	1.2209
13	1.1145	.1267	.0701	.0554	1.0513	1.2346	1.1361
14	1.1317	.1267	.0701	.0377	.9835	1.0898	1.1191
15	1.0974	.1086	.0701	.0373	1.0174	1.1736	.9326
16	1.5604	.1086	.0526	.0377	.8817	1.2209	1.0852
17	.1086	.1267			.0724	.0554	.0701
18	.112	.1448	.0701		.0724	.1097	.0701
19	.0934	.1448	.0701	.0754	.1267	.112	.1227
20	.0934	.1448	.1052	.0377	.1086	.0554	.1052
21	.0934	.1267	.0876	.0934	.0905	.056	.0876
22	.0934	.1086	.0701	.0747	.0724		.0701
23	.056	.4917	.5256	.4239	.0543	.0373	.0701
24	.0566	.0373	.6443	.5426	.4578	.0362	.0187
Max	1.5604	.4917	1.0682	1.0174	1.153	1.3226	1.3056
Min	.0373	.0187	.0526	.0373	.0543	.0181	.0187
Avg	.4298	.1079	.3273	.3286	.547	.4287	.4039

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 201 / Nool Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2263	.2801	.2452	.2353	.2172	.2172
2	.2012	.2263	.2801	.2427	.181	.181	.1867
3	.2012	.2286	.2772	.2402	.181	.181	.181
4	.2012	.2286	.2801	2.5206	.181	.2172	.2172
5	.2561	.2452	.2772	.2801	.2534	.2896	.2534
6	.3109	.3395	.4805	.3772	.3801	.3439	.3982
7	.3898	.4066	.4066	.4435	.3982	.362	.4887
8	.4024	.4066	.3681	.3982	.362	.4163	.3801
9	.5068	.3801	.4344	.407	.39	.407	.4207
10	.4163	.4163	.4525	.4239	.4144	.426	.3391
11	.3801	.3439	.3982	.3544	.3647	.3605	.373
12	.3801	.4525	.543	.373	.3932	.3647	.39
13	.2896	.4706	.4525	.39	.3605	.3647	.3768
14	.362	.3982	.3258	.373		.2949	.3605
15	.362	.2715	.2534	.373	.2543	.3391	.3239
16	.3258	.3258	.4344	.3856	.2321	.3315	
17	.3734	.3734	.3721	.443	.3189	.4481	.4477
18	.3506	.3734	.4252	.4607	.3544	.4344	.4681
19	.6908	.6859	.7442	.691	.4961	.5959	.7164
20	.7468	.8215	.7619	.7265	.5316	.7373	.7087
21	.5914	.695	.708	.7059	.5847	.5611	.6335
22	.415	.4481	.4854	.4887		.3982	.3982
23	.2641	.3511	.3109	.3258	.3258	.2715	.2353
24	.2195	.2263	.3174	.2772	.2896	.2896	.2534
Max	.7468	.8215	.7619	2.5206	.5847	.7373	.7164
Min	.2012	.2263	.2534	.2402	.181	.181	.181
Avg	.3690	.3892	.4196	.4978	.3401	.3680	.3812

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 202 / Bhadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0648	.0754	1.3272	1.1822	1.4089	.0724	.0724
2	.0648	.0754	1.326	1.1469	1.3765	.0724	.0747
3	.0648	.0754	1.3108	1.1603	1.3765	.0724	.0724
4	.0648	.0762	1.326	1.1469	1.3765	.0724	.0724
5	.0648	.0943	1.3108	1.1603	1.3765	.0724	.0724
6	.0648	.132	1.4255	1.2929	1.4586	.0724	.0905
7	.0486	.132	1.7404	1.4586	1.7166	.1086	.0905
8	.0648	.1698	1.668	1.5402	1.9433	.1267	.1086
9	1.5223	.1448	.181	.1307	1.6244	1.5581	1.7635
10	2.0081	.1991	.1991	.1791	2.1765	2.1872	2.3205
11	2.0891	.1991	.181	.1715	2.2447	2.4371	2.4939
12	2.0729	.1448	.2172	.1526	1.587	2.4215	2.5911
13	2.0567	.1629	.2353	.1357	1.9524	2.5029	2.4741
14	2.0891	.1629	.1629	.1387		2.343	2.2672
15	2.0891	.1629	.1629	.1387	2.0405	2.4366	2.3205
16	1.9595	.1629	.1448	.1509	2.3525	2.2725	2.3758
17	.1494	.1867	.1802	.1296	.0972	.112	.2096
18	.1433	.1867	.1475	.1134	.0972	.1307	.1715
19	.1867	.112	.1638	.1296	.1134	.1267	.1524
20	.1867	.1097	.1475	.1296	.1134	.1372	.1524
21	.1715	.1334	.1509	.1448	.0972	.1448	.1629
22	.1334	.0943	.132	.1267	.0905	.1086	.1086
23	.1132	1.3426	1.1633	1.3927	.0747	.0724	.0905
24	.081	.0943	1.358	1.21	1.4413	.0724	.0724
Max	2.0891	1.3426	1.7404	1.5402	2.3525	2.5029	2.5911
Min	.0486	.0754	.132	.1134	.0747	.0724	.0724
Avg	.7314	.1846	.6818	.6109	1.2233	.8222	.8492

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 203 / Chennikuppi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6882	.6325	.0943	.0754	.0724	.5992	.5668
2	.6554	.6249	.0953	.0747	.0724	.5992	.5668
3	.6554	.6173	.0943	.0739	.0905	.5992	.583
4	.6554	.6249	.0934	.0747	.0905	.6478	.583
5	.7537	.6249	.0943	.0739	.0934	.6478	.6478
6	.852	.6483	.132	.1132	.1086	.7125	.7125
7	1.1797	.8802	.1334	.0943	.1267	1.1012	.9231
8	1.2452	1.0562	.1334	.1334	.1448	1.1984	1.1822
9	.1448	.8421	.6478	.7712	.1017	.1357	.1052
10		1.247	1.1174	1.1869	.0995	.08	.1017
11	.1086	1.3603	1.166	1.2378	.0983	.0995	.0995
12	.1086	1.3279	1.1174	1.1736	.0995	.0983	.1311
13	.1267	1.247	1.1174	1.1401	.081	.1147	.0983
14	.1267	1.2308	1.0688	1.153		.1311	.0972
15	.1267		1.0688	1.153	.0497	.1326	.0983
16	.1448	1.3603	1.1174	1.1736		.1311	.0972
17	.2054	.0747	.0983	.0983	.1311	.168	.1715
18	.1612	.112	.0983	.0983	.1311	.1829	.1905
19	.2054	.1867	.1311	.1638	.1475	.2241	.1905
20	.2054	.1829	.1475		.1638	.2058	.1905
21	.1905	.1715	.1715	.1448	.1638	.181	.181
22	.1509	.1334	.1132	.1267	.1267	.1494	.1448
23	.6401	.0953	.0924	.0905	.5992	.583	.1086
24	.6882	.6325	.0943	.0739	.0724	.5992	.583
Max	1.2452	1.3603	1.166	1.2378	.5992	1.1984	1.1822
Min	.1086	.0747	.0924	.0739	.0497	.08	.0972
Avg	.4356	.6919	.4266	.4565	.1302	.3884	.3481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 204 / Guddai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1				.426	.4049		
2				.431	.3887		
3				.421	.4049		
4				.4752	.4049		
5				.426	.4049		
6				.4049	.4049		
7	.0655			.4807	.4534		
8	.0819				.4696		
9	.7935				.3315	.4973	.4578
10	1.0364					.6554	.6443
11	1.0688		.7125			.6962	.664
12	1.0526		.8259			.6783	.6952
13	.8259		.9069			.6478	.6478
14	.9555					.6554	.6478
15	.9717		.7611		.5967	.663	.6478
16	.9717		.8583		.663	.663	.6478
17			.9175		.6882		
18			.7865		.6554		
19			.0819		.0819		.0747
20			.0655		.0655		.0709
21		.0739	.0724				
22		.0747					
23				.4049			
24				.4588	.4049		
Max	1.0688	.0747	.9175	.4807	.6882	.6962	.6952
Min	.0655	.0739	.0655	.4049	.0655	.4973	.0709
Avg	.7824	.0743	.5989	.4365	.4265	.6446	.5198

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 205 / 11 KV JARALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3927	1.3904		.1509	.1448	1.4251	1.1736
2	.852	1.3592		.1494	.1448	1.4251	1.1336
3	1.3435	1.3226		.1478	.1448		1.1336
4	1.3435	1.2929		.1478	.1448	1.4575	1.166
5	1.3763	1.3077		.1494	.1448	1.5223	1.1822
6	1.4255	1.4413		.1612	.1629	1.5708	5.7651
7	1.4746	1.6956		.2241	.1991	1.9595	1.6194
8	1.9006	2.1948		.2534	.1696	2.0729	1.749
9	.181	1.9109	1.8138	1.95	.1989	.1823	.1734
10	.1629	2.4777	2.4615	2.6621		.176	.1543
11	.1448	2.5425	2.3158	2.6189	.1989	.1802	.1509
12	.1448	2.5425	2.17	2.42	.1966	.1865	.1311
13	.1267	2.2996	2.2348	2.3537	.1658	.1658	.0983
14	.1267	2.2348	2.2024		.1658	.1296	.096
15	.1267	2.2186	1.6518	2.4078	.1658	.1311	.0972
16	.1448	2.251	2.1052	2.42	.1658	.1311	.1187
17	.1867	.1867	.1638	.1475	.1475	.1867	.1254
18	.1753	.1867	.1638	.1475	.1475	.181	.1402
19	.2427	.2241	.213	.1802	.1802	.1991	.1886
20	.2241	.2195	.1966	.1638	.1802	.1907	.1886
21	.1886	.2195	.1867	.181	.1638	.181	.1629
22	.168	.1991	.1646	.1629	.1448	.1448	.1267
23	1.4403		.1448	.1448	1.4413	1.1498	.0905
24	1.3927	1.4243		.2715	.1448	1.4575	1.166
Max	1.9006	2.5425	2.4615	2.6621	1.4413	2.0729	5.7651
Min	.1267	.1867	.1448	.1448	.1448	.1296	.0905
Avg	.6786	1.4410	1.2126	.8529	.2201	.7133	.7555

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 206 / 11 KV SAMARTHANAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1307	.1307	.132	.1086	.1448	.1448
2	.128	.1294	.1294	.132	.1086	.1307	.1267
3	.128	.128	.1307	.1334	.1086	.1267	.1267
4	.128	.1267	.132	.1334	.1086	.1448	.1448
5	.1646	.1433	.132	.132	.1267		.1448
6	.2195	.1886	.181	.1663	.1448	.181	.1991
7	.2743	.1715	.2587	.2452	.1991	.2353	.2353
8	.2926	.1848	.2254	.2279	.2353	.2353	.1991
9	.2172	.1991	.2172	.2035	.2204	.2229	.1753
10	.2715	.2534	.3077	.1753		.2486	.2401
11	.2896	.2172	.2534	.1753	.2321	.1844	.2035
12	.2715	.181	.2353	.1509	.1658	.2204	.2035
13	.2054	.181	.0905	.1543	.1989	.1492	.2458
14	.181	.2353	.0724	.156	.1989	.1943	.1943
15	.181	.2172	.1086	.156	.1357	.2374	.1475
16	.181	.1991	.1629	.1696	.1696	2.2996	.1802
17	.1867	.1494	.1772	.2126	.2126	.1494	.2601
18	.2172	.1867	.1595	.2303	.1595	.1463	.2401
19	.2614	.2713	.2658	.2303	.2481	.2241	.2957
20	.2801	.2926	.2835	.2835	.3012	.2572	.3174
21	.2801	.2801	.2801	.2715	.2835	.2896	.2896
22	.2241	.2427	.2263	.2172	.2534	.2353	.2353
23	.1698	.1698	.1509	.1448	.1629	.181	.1448
24	.1463	.132	.1494	.1509	.1267	.1448	.1629
Max	.2926	.2926	.3077	.2835	.3012	2.2996	.3174
Min	.128	.1267	.0724	.132	.1086	.1267	.1267
Avg	.2102	.1921	.1859	.1827	.1830	.2862	.2024



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 201 / 11 KV Nilaji Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.4904	.3841	.381	.3772		.4572
2	.5487	.4527	.3841	.3429	.3772		.4191
3	.5487	.4527	.3841	.3429	.3772		.381
4	.5487	.4572	.3841	.3429	.3772		.381
5	.7316	.5281	.5853	.4572	.4191		.4572
6	.8048	.6097	.6584	.5335	.5716		.6859
7	.8413	.7922	.7682	.724	.7545		.7621
8	.8048	.7842	.8402	.7545	.7095		.8002
9	.7316	.679	.5914	.695	.6283	.6219	.6722
10	.6401	.7392	.6379	.5853	.6283	.695	.7316
11	.5487		.6447	.5487	.5853	.6653	.6089
12	.5121	.5792	.567	.5658	.4344	.5853	.5959
13	.4755	.5014	.4755	.5121	.439	.5487	.5014
14	.4344	.4656	.4755	.5121	.394	.5487	.5068
15	.4805	.543	.4706	.4755		.5121	.543
16	.543	.5068	.4656	.4252		.5487	.5487
17	.6219		.4607	.4557		.5487	.5175
18	.5853	.6401	.5487	.4607		.6283	.6154
19	.9808	.8962	.9709	.924		1.0082	.8871
20	1.094	.9877	1.0829	.9808		1.0456	1.0829
21	.9709	1.0242	.9054	.8676		.9431	.9709
22	.8676	.8413	.7621	.7167		.8002	.8676
23	.679	.5853	.5716	.5281		.5716	.6097
24	.6219	.5335	.3841	.4191	.415		.4572
Max	1.094	1.0242	1.0829	.9808	.7545	1.0456	1.0829
Min	.4344	.4527	.3841	.3429	.3772	.5121	.381
Avg	.6758	.6404	.6001	.5646	.4992	.6848	.6275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 202 / HITANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1033	1.7436	.4024	.3048	.2743		1.1603
2	2.1033	1.7635	.4024	.3584	.2715		1.1736
3	2.1033	1.7635	.4024	.3018	.2715		1.1736
4	2.2862	1.7635	.4024	.3018	.2743		1.2407
5	2.268	1.7974	.4024	.3734	.2896		1.4243
6	2.4691	2.0008	.4755	.4435	.3511		1.5261
7	2.5972	2.3491	.5121	.5304	.5304		1.6289
8	2.8166	2.6063	.6036	.5601	.5853		1.6975
9	.2195	2.4006	2.5377	3.2922	.5373	.4805	.3734
10	.2743	2.8121	2.7435	3.3653	.4835	.439	.3142
11	.2926	2.4348	2.8464	3.2922	.4163	.4435	.2715
12	.2926	2.915	2.8978	3.2007	.3403	.4066	.2241
13	.2926	2.9492	2.8147	3.2007	.3582	.4066	.2126
14	.2896	2.6749	3.0178	3.3008	.3189	.4024	.1991
15	.2743		2.9664	3.0007		.439	.197
16	.3292	.6962	1.3032	2.915		.2587	.1991
17	.3696		.4382	.3547		.2534	.2378
18	.3475	.3658	.4706	.4572		.2926	.298
19	.4066	.3658	.4904	.5121		.2926	.2957
20	.3734	.4024	.4527	.4854		.2614	.2263
21	.362	.4024	.415	.4108		.2263	.1886
22	.3361	.4024	.3772	.3475		.1905	.1494
23	1.7465	.4024	.3174	.3258		1.094	.8583
24	2.1399	1.7635	.4024	.3239	.2926		1.1271
Max	2.8166	2.9492	3.0178	3.3653	.5853	1.094	1.6975
Min	.2195	.3658	.3174	.3018	.2715	.1905	.1494
Avg	1.1289	1.6716	1.1706	1.3316	.3730	.3925	.6832

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 203 / HASURCHAMPU AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0953	1.39	.9717	.9393		.0953
2	.0914	.0943	1.39	.9717	.8539		.0953
3	.0914	.0943	1.39	.9717	.8065		.0953
4	.0914	.0953	1.39	1.0364	.8223		.1143
5	.1097	.1132	1.4632	1.1336	.8223		.1143
6	.128	.1334	1.6095	1.2308	.8907		.1334
7	.1463	.1698	1.701	1.3279	1.1469		.1524
8	1.5546	.1509	1.4899	1.3763	1.3441		.1715
9	2.0748	.132	.132	.1463	1.1544	1.4251	1.3763
10		.168	.132	.1463	1.4413	1.8351	1.7901
11	2.0119		.0934	.1463	1.6057	1.7814	1.8896
12	2.0119	.1143	.1307	.1463	1.2163	1.6644	1.7328
13	1.829	.0732	.1132	.1097	1.5546	1.6964	1.7004
14	1.6004		.0943	.0914		1.6964	1.5708
15	1.5384	.0754	.0934	.0934		1.6644	1.5384
16	1.5364	.0924	.1132	.0905		1.587	1.5565
17	.1132	.112	.1334	.0895		.112	.1132
18	.1132	.128	.1478	.128		.1509	.1254
19	.0762	.132	.1494	.168		.1715	.1524
20	.132	.132	.1715	.1698		.1524	.1524
21	.132	.128		.1509		.1524	.1524
22	.1143	.128	.1143	.132		.1334	.1524
23	.0953	1.1888	.9231	.9393		.1143	.1334
24	.1097	.0943	1.39	1.004	.9282		.0953
Max	2.0748	1.1888	1.701	1.3763	1.6057	1.8351	1.8896
Min	.0762	.0732	.0934	.0895	.8065	.112	.0953
Avg	.6874	.1657	.6850	.5322	1.1090	.9558	.6335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 204 / 11KV Hirnyakeshi

SHEDDABLE FEEDER MIDC EQUIVALENT

Industrial Ex Feeder KV- 11 /  
OUTGOING

HAVING WEEKLY STAGGERING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0732	.0762
2		.0953	.0732	
3	.0754	.0762	.0732	.0762
4	.0732	.0762	.0732	.0762
5	.0914	.0762	.0914	.0762
6	.0914	.0953	.0914	.0762
7	.0914	.0953	.1097	.0762
8	.0732	.0953	.0943	.0762
9	.0732	.0953	.0754	.0732
10	.0914	.0633	.0747	.0732
11	.1097	.1524	.1307	.0732
12	.128	.1524	.1509	.0732
13	.1463	.128	.1524	.0943
14	.1509	.1334	.132	.0914
15	.1132	.1109	.1494	.0934
16	.1509	.1509	.1402	
17	.1109	.132	.1478	.1075
18	.1524	.1097	.132	
19	.132	.1097	.0739	
20	.0943	.0732	.0724	
21	.0762	.0732	.0934	
22		.0732		
23	.0953	.0732	.0762	
24		.0762	.0732	.0762
Max	.1524	.1524	.1524	.1075
Min	.0732	.0633	.0724	.0732
Avg	.1060	.0997	.1024	.0806

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 201 / 11 KV Halkarni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7339	.2277	.2286	.2667	.8059	.7535	.6958
2	.6939	.2282	.2273	.2096	.7253	.6933	.665
3	.7268	.2096	.2087	.1905	.6447	.759	.6348
4	.7832	.2096	.2268	.1524	.7964	.7204	.6783
5	.9047	.2277	.2477	.1334	.9962	.7764	.7073
6	1.0437	.2841	.2849	.2667	1.1468	.9907	.7571
7	1.2525	.3598	.3409	.381	1.4318	1.1427	.9844
8	1.2631	.3395	.303	.3772	1.465	1.1829	
9	.3385	1.0064	1.0836	1.1962	.1867	.3537	.2818
10	.3598	1.5746	1.5509	1.5565	.3723	.3374	.3018
11	.2993	1.7159	1.6059	1.6372	.2771	.2603	.32
12		1.6741	1.6164	1.602	.3197	.2241	.3368
13		1.562	1.0498	1.5777	.2643		.2627
14		1.5238	1.5766	1.5115	.245	.2966	.2252
15	.1886	1.562	1.5782	1.4598	.2638	.2987	.2254
16	.2231	1.5276	1.5964	1.1276	.2643	.3006	.2633
17	.2978	.1704	.2622	.2054	.2068	.3723	.2993
18	.3354	.2832	.3727	.3364	.3177	.3385	.335
19	.4518	.3392	.4154	.4504	.3187	.321	.3765
20	.415	.3602	.3961	.4668	.3776	.2844	.454
21	.4137	.3416	.3969	.3749	.378	.2657	.3788
22	.3216	.2846	.3584	.3409	.3027	.3021	.2649
23	.2841	.2659	.2662	1.0267	.8055	.6924	.6611
24	.8059	.2651	.2472	.2286	.9602	.7792	.6759
Max	1.2631	1.7159	1.6164	1.6372	1.465	1.1829	.9844
Min	.1886	.1704	.2087	.1334	.1867	.2241	.2252
Avg	.5779	.6893	.6850	.7115	.5780	.5411	.4689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Hiduggi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.128	1.2147	1.2559	1.0218	.1691	.189	.1871
2	.1307		1.2105	1.0311	.1698	.1901	.1504
3	.1503	1.186	1.2772	1.0963	.1517	.1708	.132
4	.1507	1.2305	1.226	1.2643	.1494	.1713	.1512
5	.1701	1.262	1.267	1.3894	.1662	.1896	.1896
6	.2467	1.292	1.3698	1.5384	.3018	.2266	.2452
7	.3033	1.6285	1.6279	1.7593	.3039	.1884	.2464
8	.2462	1.8136	1.7037	1.7839	.2467	.2614	.2066
9	1.4117	.2085	.2275	.2263	.8002	1.333	1.5357
10	1.9457	.1706	.2079	.1691	1.7583	1.7243	1.6327
11	1.8992	.1622	.2257	.1886	1.8992	1.8498	1.7382
12	.7534	.1509	.2058	.1875	1.8063	1.8962	1.7541
13	1.5966	.185	.2056	.1457	1.8317		1.7689
14	1.8974	.1663	.1877	.1624	1.7668	1.4974	1.6229
15	1.9388	.1488	.2238	.1789	1.6996	1.7647	1.6466
16	1.9617	.1867	.2215	.2338	1.6966	1.7753	1.694
17	.2078	.2133	.2566	.2505	.1514	.1494	.1789
18	.1974	.2467	.2835	.2753	.1951	.2593	.2108
19	.2627	.3033	.323	.3482	.2247	.2875	.2587
20	.2627	.303	.2996	.3727	.2829	.3457	.3006
21	.2625	.2638	.2821	.3299	.3006	.222	.2987
22	.244	.2818	.2625	.3309	.263	.2809	.242
23	1.2727	1.3807	.7964	.3	.2277	.2457	.2254
24	.1453	1.2432	1.2982	.9946	.1867	.2089	.2056
Max	1.9617	1.8136	1.7037	1.7839	1.8992	1.8962	1.7689
Min	.128	.1488	.1877	.1457	.1494	.1494	.132
Avg	.7411	.6627	.6852	.6491	.6979	.6708	.7009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV nagnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4961				.3982	.286	.3084
2	.4636				.3676	.2649	.3254
3	.4588				.314	.2679	.2949
4	.491				.3163	.2542	.3109
5	.53				.3441	.2548	.3254
6	.5376				.3433	.3223	.3413
7	.6914				.4691	.525	.3481
8	.7167				.5796	.5727	.571
9		.5445	.5735	.5032			
10		.909	.7201	.5575			
11		.8192	.7397	.6462			
12		.8755	.7402	.6786			
13		.7309	.6409	.5995			
14		.6325	.6168	.4492			
15		.7344	.6045	.5724			
16		.7335	.6562	.6033			
23				.3325	.3008	.3569	.2929
24	.5451				.365	.2986	.2888
Max	.7167	.909	.7402	.6786	.5796	.5727	.571
Min	.4588	.5445	.5735	.3325	.3008	.2542	.2888
Avg	.5478	.7474	.6615	.5492	.3798	.3403	.3407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV HALKARNI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.1331	.1524	.1334	.1323	.1334
2	.1334	.1334	.1143	.1334	.1334	.1141	.1143
3	.1143	.1334	.1326	.1143	.1524	.1143	.1143
4	.1334	.1524	.1518	.1334	.1524	.1328	.1524
5	.1334	.1715	.1715	.1524	.1715	.1515	.1715
6	.2096	.2096	.2286	.1715	.2096	.1524	.1905
7	.2646	.2651	.3024	.2286	.2266	.2275	.2464
8	.2622	.2815	.2614	.3155	.2627	.2795	.2678
9	.2218	.2769	.2035	.2204	.1686	.2574	.2706
10	.2712	.2202	.1825	.2539	.2412	.2518	.2186
11	.1999	.1469	.176	.2306	.2006	.216	.1951
12	.1434	.1307	.1755	.2241	.1819	.1791	.2096
13	.1402	.185	.1962	.1642	.1462		.2276
14	.1468	.2126	.1791	.1591	.1488	.18	.1962
15	.1667	.1787	.1755	.146	.1478	.1428	.2133
16	.1401	.1776	.1778	.515	.1624	.1428	.2119
17	.2142	.2048	.231	.242	.1389	.2241	.2589
18	.2863	.2472	.2307	.2603	.2546	.2575	.2369
19	.3302	.3138	.3835	.3605	.2945	.3248	.3801
20	.334	.3333	.3673	.4298	.3371	.2606	.481
21	.3197	.2826	.2641	.2957	.2829	.2199	.3184
22	.2464	.2092	.2092	.2257	.2275	.2089	.2467
23	.1715	.1524	.1905	.0191	.1524	.1524	.1524
24	.1334	.1521	.1324	.1524	.1524	.1334	.1334
Max	.334	.3333	.3835	.515	.3371	.3248	.481
Min	.1143	.1307	.1143	.0191	.1334	.1141	.1143
Avg	.2013	.2043	.2071	.2208	.1950	.1937	.2226



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV Hidduggi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8094	.5716	.7914	.9164	.7514	.8316	.9054
2	.789	.5716	.7733	.8131	.7392	.7606	.8316
3	.7109	.6275	.756	.898	.7326	.724	.7954
4	.716	.6642	.7153	.8811	.5601	.6824	.756
5	.7938	.7545	.7922	.8889	.5538	.6432	.811
6	.8676	.9976	.959	.7938	.5185	.7211	.7914
7	.5228	1.0321	1.0807	.5889	.4696	.959	.4065
8	.3909	.9542	.9297	.4882	.9689	1.1529	
9	.4246	.9278	.9046	.3681	.4481	.9149	.4132
10	.3781	.8722	.4141	.3113	.7979	.7377	.4007
11	.3673	.3905	.3597	.2954	.3003		.3805
12	.2795	.2859	.3361	.2966	.2809	.3578	.3282
13	.3333	.323	.3142	.2701	.3155		.3654
14	.3161	.299	.3643	.2585	.3132	.3234	.3432
15	.2957	.2818	.3471	.2763	.3511	.3275	.3457
16	.3158	.3299	.3344	.2735	.2601	.2975	.3119
17	.3224	.3333	.3399	.2643	.3224	.3906	.2862
18	.3628	.3061	.3631	.2838	.4074	.475	.3189
19	.5233	.4859	.5865	.463	.4884	.5527	.5159
20	.6674	1.1237	1.2074	.9896	1.2111	.5343	.924
21	.7632	1.0858	1.2458	1.1791	.5647	.7738	1.0242
22	.9795	.959	1.0796	.962	1.1005	.9483	.5975
23	.5882	.303	.9928	.8589	.8989	.9017	.8299
24	.8078	.6655	.8207	.9425	.8453	.8676	.8411
Max	.9795	1.1237	1.2458	1.1791	1.2111	1.1529	1.0242
Min	.2795	.2818	.3142	.2585	.2601	.2975	.2862
Avg	.5552	.6311	.7003	.6067	.5917	.6763	.5880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Nagnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1139	.0953	.1334	.1143	.0762	.1143
2	.1143	.1139	.0758	.1143	.1143	.0759	.0762
3	.1334	.0953	.0945	.0762	.1334	.0951	.0762
4	.1334	.0953	.1141	.0762	.132	.0953	.1334
5	.1331	.1141	.1334	.1334	.1509	.1139	.1334
6	.1518	.1704	.152	.1706	.151	.1517	.1515
7	.2266	.2266	.2252	.2447	.2266	.2252	.1901
8	.2247	.2247	.167	.1795	.1884	.1682	.2245
9	.1867	.1687	.1477	.168	.1698	.1507	.185
10	.1486	.1489	.1631	.1457	.165	.1469	.1469
11	.1115	.1284	.1436	.0179	.1486	.1463	.111
12	.11	.1494	.127	.1581	.1276	.1311	.1292
13	.1091	.1288	.0912	.1234	.125		.1446
14	.0751	.1272	.1634	.1223	.1398	.1392	.1108
15	.1102	.1463	.1282	.1255	.0922	.1414	.1116
16	.1451	.1478	.1566	.1056	.1372	.1425	.1451
17	.1297	.1398	.148	.1644	.1581	.137	.1751
18	.1724	.1909	.2315	.2195	.1696	.1755	.1717
19	.3306	.3145	.333	.3074	.2603	.2407	.3316
20	.37	.2975	.3326	.4481	.3145	.238	.4513
21	.2981	.2617	.2806	.2987	.2638	.205	.2987
22	.2259		.2073	.2241	.1691	.188	.1884
23	.1328	.1133	.189	.1497	.1128	.1504	.1139
24	.1143	.1137	.0947	.1524	.1315	.0945	.132
Max	.37	.3145	.333	.4481	.3145	.2407	.4513
Min	.0751	.0953	.0758	.0179	.0922	.0759	.0762
Avg	.1667	.1622	.1665	.1691	.1623	.1491	.1686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 201 / 11 KV Kowad Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.8573	.8505	.6733	.0381	.0347	.0381
2	.0381	.8573	.8505	.6733	.0381	.0347	.0381
3	.0381	.8573	.8505	.6733	.0381	.0347	.0381
4	.0381	.8573	.8505	.6733	.0381	.0347	.0381
5	.0381	.8573	.8505	.6733	.0381	.0347	.0381
6	.0381	.8573	.8505	.6733	.0381	.0347	.0381
7	.0381	.7202	.9568	.7796	.0381	.0347	.0381
8	.0381	.823	.8859	.7796	.0381	.0347	.0381
9	1.2574	.0343	.0347	.0381	1.0288	1.2048	.8383
10	1.448	.0343	.0347	.0381	1.1812	1.382	
11	1.448	.0343	.0347	.0381	1.2193	1.382	1.3336
12	1.1431	.0343	.0347	.0381	1.2955	1.382	1.5623
13	1.4861	.0343	.0347	.0381	1.4098	.8859	1.6385
14	1.5242	.0343	.0347	.0381	1.448	1.1694	1.7147
15	3.1245	.0343	.0347	.0381	1.2955	1.3112	1.6004
16	1.3717	.0343	.0347	.0381	1.2574	1.134	1.6004
17	.0381	.0343	.0347	.0381	.0381	.0347	.0381
18	.0381	.0343	.0347	.0381	.0381	.0347	.0381
19	.0381	.0343	.0347	.0381	.0381	.0347	.0381
20	.0381		.0347	.0381	.0381	.0347	
21	.0381	.0381	.0347	.0381	.0381	.0381	.0381
22	.0381	.0381	.0347	.0381	.0381	.0381	.0381
23	1.0288	.9145	.6733	.0381	.0381	.0381	.0381
24	.0381	.9526	.9145	.7087	.0381	.0381	.0381
Max	3.1245	.9526	.9568	.7796	1.448	1.382	1.7147
Min	.0381	.0343	.0347	.0381	.0381	.0347	.0381
Avg	.6001	.3916	.3758	.2866	.4477	.4342	.4936

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 202 / 11 KV Talewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.7147	1.6301	1.701	.0381	.0347	.0381
2	.0381	1.7147	1.6301	1.701	.0381	.0347	
3	.0381	1.7147	1.6301	1.701	.0381	.0347	.0381
4	.0381	1.7147	1.6301	1.701	.0381	.0347	.0381
5	.0381	1.7147	1.6301	1.701	.0381	.0347	.0381
6	.0381	1.7147	1.6301	1.4175	.0381	.0347	.0381
7	.0381	2.0576	1.9136	.2126	.0381	.0347	.0381
8	.0381	2.1262	1.9845	1.9136	.0381	.0347	.0381
9	2.6673	.0343	.0347	.0381	2.21	2.1971	2.7435
10	2.7435	.0343	.0347	.0381	2.8197	3.0476	3.0483
11	3.1245	.0343	.0347	.0381	2.8197	2.6223	3.2007
12	2.9721	.0343	.0347	.0381	2.8197	2.7641	3.1245
13	3.0483	.0343	.0347	.0381	2.8959	2.8349	3.4675
14	3.2007	.0343	.0347	.0381	3.1245	2.8349	3.2007
15	3.1245	.0343	.0347	.0381	3.0483	3.0476	3.2769
16	3.2769	.0343	.0347	.0381	2.8959	.0347	3.4675
17	.0381	.0343	.0347	.0381	.0381		.0381
18	.0381	.0343	.0347	.0381	.0381	.0347	.0381
19	.0381	.0343	.0347	.0381	.0381	.0347	.0381
20	.0381		.0347		.0381	.0347	
21	.0381	.0381	.0347	.0381	.0381	.0381	.0381
22	.0381	.0381	.0347	.0381	.0381	.0381	.0381
23	1.9052	1.6766	1.6301	.0381	.0381	.0381	.0381
24	.0381	1.9052	1.7528	1.701	.0381	.0381	.0381
Max	3.2769	2.1262	1.9845	1.9136	3.1245	3.0476	3.4675
Min	.0381	.0343	.0347	.0381	.0381	.0347	.0381
Avg	1.1098	.8047	.7311	.6210	.9685	.8660	1.1847

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 203 / 11 KV Batakanangle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4387	.0343	.0347	.1387	2.6673	2.268	2.2862
2	2.4387	.0343	.0347	.1387	2.6673	2.268	2.2862
3	2.4387	.0343	.0347	.1387	2.6673	2.268	2.2862
4	2.4387	.0343	.0347	.1387	2.6673	2.268	2.2862
5	2.4387	.0343	.0347	.1387	2.6673	2.268	2.2862
6	2.4387	.0343	.0347	.1402	2.6673	2.268	2.2862
7	2.9721	.0343	.0347	.1387	3.0483		2.8197
8	3.0483	.0343	.0347	.1387	2.9721	2.6223	3.0483
9	.0381		2.6932	2.5911	.1143	.1387	.0381
10	.0381	2.2977	2.7641	3.0483	.1143	.1387	.0381
11	.0381	2.6406	3.0476	2.8959	.1143	.1063	.0381
12	.0381	2.5377	2.8349	3.0483	.1143	.1063	.0381
13	.0381	2.6749	2.8349	3.0483	.1143	.1387	.0381
14	.0381	2.7092	2.7641	3.0483	.1143	.0693	.0381
15	.0381	2.8121	2.7641	3.1245	.1143	.0693	.0381
16	.0381	2.7435	2.7641	3.0483	.1143	.104	.0381
17	.0381	.0343	.1387	.1524	.1143	.1387	.0381
18	.0381	.0343	.1387	.1524	.1143	.104	.0381
19	.0381	.0343	.1734	.1524	.1143	.1387	.0381
20	.0381		.1772	.0381	.1143	.208	
21	.0381	.0381	.1734	.0381	.1143	.0381	.0381
22	.0381	.0381	.1734	.0381	.1143	.0381	.0381
23	.0381	.0381	.1387	2.6673	2.4387	2.2862	2.6673
24	2.4387	.0381	.0381	.1387	2.6673	2.4387	2.2862
Max	3.0483	2.8121	3.0476	3.1245	3.0483	2.6223	3.0483
Min	.0381	.0343	.0347	.0381	.1143	.0381	.0381
Avg	.9860	.8612	.9957	1.1809	1.1971	.9779	1.0884

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 204 / 11 KV Talewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1029	.1417	.1417	.1524	.1417	.1524
2	.1143	.1029	.1417	.1417	.1524	.1417	.1524
3	.1143	.1029	.1417	.1417	.1524	.1417	.1524
4	.1143	.1029	.1417	.1417	.1524	.1417	.1524
5	.1143	.1029	.1417	.1417	.1524	.1417	.1524
6	.1524	.1029	.1417	.1417	.1524	.1772	.1524
7	.1905	.2058	.2481		.2286	.2481	.2667
8	.2667	.2401	.2481		.2667	.2835	.3048
9	.2667	.2743	.2126	.381	.2667	.2481	.2667
10	.2667	.3429	.3189	.381	.2286	.2835	.3429
11	.2667	.3086	.1417	.3429	.2667	.2835	.3429
12	.1905	.2743	.1417	.3429	.2667	.2481	.3429
13	.2286	.2401	.2126	.2286	.2286		.2667
14	.1905	.2401	.2126	.2286	.1905	.208	.2667
15	.1905	.2401	.2126	.2286	.1905	.2126	.2667
16	.1905	.2401	.3189	.2286	.1905	.2126	.2667
17	.2286	.2401	.2835	.3048	.1905	.2126	.2667
18	.2667	.3429	.2835	.3048	.1905	.2835	.2667
19	.381	.3772	.4161	.381		.4252	.4572
20	.4191		.4607	.4954	.5335	.4607	
21	.3429	.4191	.4252	.3429	.381	.4572	.4191
22	.2667	.3429	.2835	.3429	.3048	.3048	.3429
23	.1905	.1905	.2126	.1905	.2286	.1905	.1905
24	.1524	.1143	.1524	.1772	.1524	.1524	.1524
Max	.4191	.4191	.4607	.4954	.5335	.4607	.4572
Min	.1143	.1029	.1417	.1417	.1524	.1417	.1524
Avg	.2175	.2283	.2348	.2615	.2269	.2435	.2584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 205 / 11 KV Kowad Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.3429	.3544	.3898	.4191	.3898	.4572
2	.4191	.3429	.3544		.4191	.3898	.4572
3	.4191	.3429	.3544	.3544	.4191	.3898	.4572
4	.4191	.3429	.3544	.3544	.4191	.3898	.4572
5	.381	.3429	.3544	.3544	.4191	.3898	.4572
6	.4572	.3429	.3544	.4607	.4191	.4252	.4572
7	.724	.6173	.7087	.6024	.6859	.7087	.6478
8	.7621	.6173	.6379	.7442	.724	.6379	.724
9	.7621	.6516	.6379	.8383	.7621	.567	.7621
10	.8002	.6516	.6024	.724	.6859	.5316	
11	.724	.6516	.7442	.724			.6859
12	.6097	.6173	.7087	.724	.5716	.3898	.6859
13	.6859	.6173	.6733	.6097	.5335	.3544	.724
14	.6097	.5487	.6379	.6097	.5716	.3189	.6097
15	.4954	.5487	.567	.5716	.5716	.6024	.6097
16	.5335	.5487	.6379	.5716	.5716	.6024	.6478
17	.5716	.583	.7087	.7621	.4954	.6379	.6478
18	.6859	.7202	.6733	.7621	.5335		.6859
19	.9526	.9945	.8859	.724	.8002	1.0277	.9526
20	1.0669		1.0631	1.1431	.9907	.9922	
21	.9526	.9526	.9214	1.0669	.9145	1.0669	.9907
22	.8002	.8383	.7442	.8764	.7621	.8002	.8002
23	.4954	.4572	.4961	.4954	.4954	.5335	.5335
24	.4572	.381	.381	.3898	.4191	.4191	.4572
Max	1.0669	.9945	1.0631	1.1431	.9907	1.0669	.9907
Min	.381	.3429	.3544	.3544	.4191	.3189	.4572
Avg	.6335	.5676	.6065	.6458	.5914	.5711	.6322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3681	.4706	.4755	.4024	.3395	.3395
2	.3395	.3582	.4525	.4572	.3658	.3395	.3395
3	.3772	.3475	.4525	.4572	.3658	.3772	.3395
4	.4338	.333	.4854	.4938	.3475	.4527	.3395
5	.5093	.3506	.4887	.4908	.3506	.4904	.3772
6	.547	.4207	.5249	.543	.4706	.547	.415
7	.6036	.567	.5973	.5847	.5853	.5847	.6036
8	.6036	.5853	.5731	.6878	.5487	.6224	.6036
9	.5847	.5487	.5658	.5792	.4755	.5249	.5249
10	.6602	.5258	.6036	.5611	.5121	.5792	.5068
11	.6413	.4706	.6413	.5249	.5304	.5611	.5068
12	.5093		.5281	.5228	.5068	.5249	.5249
13	.4904	.4344	.4938	.4525	.4755	.5658	.5847
14	.3584	.3982	.5014	.4344	.4525	.4338	.5281
15	.3395	.4557	.4656	.4525	.4344	.4527	.5281
16	.4904	.5121	.4298	.4525	.362	.4904	.4904
17	.5281	.5853	.6154	.4706	.4163	.4527	.4904
18	.6224	.5121	.6219	.4887	.4525	.6036	.5658
19	.7733	.6584	.8048	.6335	.7602	.8299	.8299
20	.7733	.8048	.8779	.6584	.8299	.9054	.8676
21	.7316	.724	.7059	.6584	.679	.7545	.7865
22	.6584	.6697	.5973	.5487	.6413	.6602	.6219
23	.4024	.543	.4887	.439	.4527	.4527	.4572
24	.3961	.3982	.5041	.4755	.4024	.3961	.3772
Max	.7733	.8048	.8779	.6878	.8299	.9054	.8676
Min	.3395	.333	.4298	.4344	.3475	.3395	.3395
Avg	.5313	.5031	.5621	.5226	.4925	.5392	.5229



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mahagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0302	.1227	.1448	.1402	2.2786	2.3011	2.0157
2	1.9753	.1052	.1448	.1402	2.3137	2.3954	2.0157
3	1.8351	.1052	.1494	.1402	2.3137		2.0157
4	1.8187	.1052	.1448	.1402	2.3137		2.0157
5	2.2068	.1227	.1448	.1402	2.3487		2.0157
6	2.3388	.1227	.1448	.1402	2.3838		2.1033
7	2.5652	.1227	.1448	.1578	2.4539		2.4714
8	2.7161	.1402	.1433	.1578	2.5941		2.489
9	.1132	2.3137	2.489	2.524	.1402	1.8099	.1448
10	.0943	2.8045	3.3653	3.3303	.1402	2.0452	.1448
11	.0943	3.5056	3.3653	3.4208	.1402	2.0995	.1448
12	.0943		3.4004	3.4751	.1463	.1509	.1448
13	.0876	3.2251	3.4705	3.5837	.1448	.1132	.1132
14	.0876	3.3303	3.4705	3.2579	.1448	.132	.0943
15	.0876	3.4705	3.4355	3.3122	.1448	.132	.1132
16	.0876	3.5056	3.4705	3.2398	.1448	.132	.1132
17	.1227	.1402	.1402	.1448	.1448	.1132	.132
18	.1227	.1402	.1402	.1448	.1448	.132	.1509
19	.1227	.1402	.1578	.1448	.1629	.1509	.1509
20	.1578	.1402	.1578	.1402	.1698	.1698	.1509
21	.1578	.1448	.168	.1402	.1509	.1402	.1402
22	.1578	.1448	.1463	.1402	.1509	.1402	.1402
23	.1402	.1448	.1448	2.1033	2.037	2.0508	2.1948
24	2.0936	.1227	.1448	.1402	2.2786	2.1502	2.0157
Max	2.7161	3.5056	3.4705	3.5837	2.5941	2.3954	2.489
Min	.0876	.1052	.1402	.1402	.1402	.1132	.0943
Avg	.8878	1.0530	1.2012	1.2666	1.0578	.9088	.9680

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4801	.0335	.0343	.0335	.3856	.4706	.3113
2	.4641	.0335	.0351	.0335	.3856	.4706	.2949
3	.4801	.0335	.0343	.0335	.3688	.4321	.2949
4	.4641	.0335	.0343	.0335	.3688	.4908	.2949
5	.4801	.0335	.0343	.0335	.3856	.4481	.2949
6	.4961	.0335	.0343	.0335	.4191	.4752	.2949
7	.4961	.0335	.0343	.0335	.4191	.4915	.2785
8	.4961	.0335	.0358	.0335	.4527	.4588	.2949
9	.032	.4359	.4915	.0335	.0335	.0362	.0373
10	.032	.57	.5407	.6154	.0335	.0362	.0343
11	.032	.6036	.5898	.5868	.0335	.0362	.0373
12	.032	.6036	.6226	.5868	.0362	.0343	.0343
13	.0328	.5868	.6371	.57	.0343	.032	.032
14	.0328	.5868	.5868	.57	.0362	.032	.032
15	.0328	.6371	.6371	.57	.0343	.032	.032
16	.0328	.6036	.6859	.5533	.0343	.032	.032
17	.0328	.0335	.0343	.0335	.0362	.032	.032
18	.0328	.0335	.0335	.0335	.0362	.032	.032
19	.0328	.0335	.0335	.0335		.032	.032
20	.0335	.0335	.0335	.0335	.0362	.032	.032
21	.0335		.0362	.0335	.032	.0328	.0335
22	.0335		.0362	.0335	.032	.0328	.0335
23	.0335		.0362	.4031	.3841	.3113	.3185
24	.4961	.0335	.0343	.0335	.4031	.426	.3277
Max	.4961	.6371	.6859	.6154	.4527	.4915	.3277
Min	.032	.0335	.0335	.0335	.032	.032	.032
Avg	.2019	.2411	.2227	.2080	.1922	.2058	.1447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 201 / 11 KV Aralgundi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4419	.0514	.0549	.0526	1.1633	.8356	.0914
2	1.4586	.052	.0549	.0532	1.1336	.8097	.1219
3	1.3923	.0509	.0554	.0537	1.1633	.8162	.1067
4	1.4251	.0514	.0554	.0543	1.1603	.8192	.1067
5	1.4752	.0526	.0554	.0549	1.1797	.8065	.1543
6	1.5089	.0509	.0554	.0554	1.1633	.8583	.216
7	1.6766	.0514	.0554	.0554	1.1633	.9282	.2623
8	1.7101	.052	.0543	.0497	1.1305	.9878	.2972
9	.0332	1.5249	1.6095	1.2452	.0514	.0492	.0514
10	.0497	1.6741	1.6907	1.5074	.0469	.0492	.0543
11	.0509	1.7939	1.8107	1.6057	.0463	.0497	.0537
12	.0503	1.7939	1.6907	1.6409	.0457	.0429	.0532
13	.0503	1.7404	1.6385	1.6057	.0457	.0434	.052
14	.0514	1.6244	1.6409	1.5565	.044	.0377	.0514
15	.0509	1.6907	1.5384	1.5565	.0406	.04	.0526
16	.0497	1.6244	1.5384	1.4575	.0406	.0429	.0354
17	.0492	.0446	.0423	.0457	.04		.0532
18	.0686	.0457	.0633	.0474	.0497		.0526
19	.0724	.0474	.0686	.0678	.0532	.0503	.0549
20	.0732	.0747	.0701	.0671	.0537	.0537	.0732
21	.0732	.0739	.0543	.0497	.0526	.037	.0724
22	.0543	.0543	.0532	.0486	.0514	.0358	.0549
23	.0537	.0549	.0526	1.1305	.8192	.0892	.1524
24	1.442	.0526	.0549	.0543	1.1633	.8356	.0914
Max	1.7101	1.7939	1.8107	1.6409	1.1797	.9878	.2972
Min	.0332	.0446	.0423	.0457	.04	.0358	.0354
Avg	.5984	.5970	.5858	.5882	.4959	.3781	.0986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 203 / Khandal Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7202	.0173	.0181	.0173	.6562	.571	.0572
2	.7116	.0175	.0187	.0175	.6636	.6081	.0714
3	.7202	.0177	.0187	.0177	.6562	.5792	.0714
4	.7362	.0179	.0187	.0179	.6718	.6019	.0892
5	.7682	.0173	.0187	.0181	.68	.5937	.1189
6	.759	.0175	.0373	.0366	.7274	.6958	.1783
7	.8162	.0351	.0373	.0373	.8381	.8179	.2229
8	.8223	.0358	.0366	.0332	.8065	.8697	.2195
9	.017	.7907	.8322	.7407	.0187	.0177	.0305
10	.0162	1.012	1.1043	.9877	.0354	.0164	.0166
11	.0164	1.085	1.1012	1.0623	.0166	.0162	
12	.016	1.1233	1.1227	.9686	.0164	.0141	
13	.0164	1.1043	.9877	.9297	.0162	.0143	
14	.0173	1.0883	1.0279	.9414	.0156	.0137	.0158
15	.016	1.0279	.9105	.945	.0149		.0166
16	.0158	1.0279	.9297	.888	.0147		.017
17	.0154	.0152	.0469	.0328	.0145		.0332
18	.0339	.0335	.0343	.032	.0332		.0347
19	.0362	.0335	.0497	.0474	.0366	.0305	.0537
20	.0366	.0377	.0514		.037	.0354	.0347
21	.0362	.0366	.0366	.0324	.0366	.0358	.0351
22	.0362	.0366	.0366	.0332	.0362	.0358	.0354
23	.0183	.0177	.0362	.6401	.5624	.0619	.0495
24	.6958	.0175	.0181	.0366	.6481	.5693	.0714
Max	.8223	1.1233	1.1227	1.0623	.8381	.8697	.2229
Min	.0154	.0152	.0181	.0173	.0145	.0137	.0158
Avg	.2956	.3610	.3554	.3702	.3022	.3099	.0701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 201 / YADRAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.062	3.3234	3.0247	3.3794	3.6595	3.3196	3.5475
2	3.0247	3.2861	2.9874	3.3234	3.6222	3.2442	3.5101
3	2.9874	3.2114	2.95	3.2487	3.5848	3.2065	3.4728
4	3.0247	3.2114	2.9127	3.2861	3.5475	3.1687	3.4355
5	2.9874	3.1741	2.8753	3.3234	3.5475	3.2442	3.3981
6	2.9874	3.1741	2.8753	3.5101	3.4355	3.3196	3.3608
7	3.3608	3.3608	2.9874	3.6969	3.4168	3.4705	3.6222
8	3.3234	3.2114	3.1367	3.4355	3.1927	3.3196	3.6969
9	4.0329	3.6969	4.1076	3.9582	3.3608	4.0741	4.1076
10	4.0329	3.8089	4.369	4.481		4.2196	4.0703
11	4.3317	3.7342	4.5184	4.6677		4.2196	4.2196
12	3.6222	3.4355	4.4063	4.6304	3.0556	4.0329	3.9956
13	3.3608	3.1741	4.1823	3.7342	3.0178	3.7342	3.2301
14	3.7342	3.4355	3.9209	4.0703	3.0556	3.9209	3.5288
15	4.4063	3.5475	4.3317	4.2196	3.0178	4.1823	4.0703
16	4.1076	3.5475	4.2943	4.2943	3.0556	4.369	4.257
17	3.8462	3.4728	4.0329	4.1823	3.0178	4.369	4.145
18	3.9209	3.1741	3.9209	4.1823	2.7161	4.0329	4.1636
19	3.6595	2.9874	3.7902	3.8836	2.6406	3.8462	3.81
20	3.4728	3.0247	3.6969	3.6408	2.6406	3.4728	3.8477
21	3.5101	3.0994	3.6969	3.6969	3.5837	3.5101	3.8855
22	3.5848	3.062	3.7155	3.6782	3.6214	3.7342	4.0364
23	3.4541		3.7529	3.6222	3.6969	3.5475	4.0741
24	3.0994	3.4355	2.9874	3.6222	3.6969	3.3951	3.6222
Max	4.4063	3.8089	4.5184	4.6677	3.6969	4.369	4.257
Min	2.9874	2.9874	2.8753	3.2487	2.6406	3.1687	3.2301
Avg	3.5389	3.3299	3.6447	3.8237	3.2811	3.7064	3.7962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 203 / ARUNDATHI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	1.251	1.307	1.2323	1.2883	.9431	1.1576
2	1.1576	1.1949	1.307	1.1576	1.2323	.9054	1.1576
3	1.1203	1.1949	1.2696	1.1203	1.1949	.9054	1.1203
4	1.0829	1.2136	1.2323	1.1576	1.1576	.8676	1.1576
5	1.0829	1.2323	1.1949	1.1576	1.1203	.9054	1.1203
6	1.1203	1.2323	1.1949	1.1763	1.1203	.9431	1.1203
7	1.1203	1.2696	1.1949	1.1763	1.0829	.9431	1.1576
8	1.1203	1.1576	1.2323	1.2883	.9896	.9431	1.1576
9	1.3817	1.2323	1.3443	1.2883	.7842	1.2826	1.3443
10	1.4563	1.3817	1.419	1.531		1.419	1.3817
11	1.419	1.419	1.3817	1.531		1.4563	1.4563
12	1.3817	1.3817		1.531	.7545	1.419	1.363
13	1.307	1.307	1.3817	1.3817	.679	1.307	1.1949
14	1.3443	1.3817	1.419	1.3817	.7167	1.3443	1.2696
15	1.3817	1.419	1.531	1.419	.679	1.3817	1.419
16	1.3817	1.4563	1.5684	1.531	.7167	1.307	1.307
17	1.3443	1.419	1.5684	1.6057	.7167	1.307	1.419
18	1.4563	1.4563	1.4563	1.3443	.679	1.3443	1.419
19	1.4003	1.3817	1.419	1.4377	.679	1.307	1.358
20	1.2696	1.307	1.307	1.3443	.7545	1.2696	1.358
21	1.2696	1.2323	1.3443	1.307	.9431	1.2323	1.3203
22	1.251	1.2696	1.3817	1.3256	.9431	1.2696	1.3203
23	1.307		1.419	1.3817	.9431	1.2323	1.3203
24	1.1203	1.2323	1.3443	1.3443	1.363	.9808	1.1949
Max	1.4563	1.4563	1.5684	1.6057	1.363	1.4563	1.4563
Min	1.0829	1.1576	1.1949	1.1203	.679	.8676	1.1203
Avg	1.2665	1.3054	1.3573	1.3397	.9335	1.1757	1.2748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 204 / SPM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.6057	1.5684	1.6057	1.643	1.4712	1.5684
2	1.643	1.5684	1.531	1.5684	1.587	1.4712	1.5684
3	1.6057	1.531	1.5844	1.5497	1.5497	1.4712	1.531
4	1.643	1.4937	1.531	1.531		1.4712	1.531
5	1.6804	1.5684	1.4937	1.531	1.4937	1.4712	1.4937
6	1.643	1.6057	1.531	1.5497	1.4937	1.4712	1.5684
7	1.531	1.643	1.4563	1.5684	1.4563	1.5089	1.643
8	1.643	1.587	1.5684	1.6804	1.363	1.5466	1.6057
9	1.7924	1.643	1.8298	1.7364	1.1016	1.6221	1.7551
10	1.8298	1.7551	1.7924	1.8671		1.7924	1.6057
11	1.7924	1.8298	1.7924	1.6804		1.9418	1.7551
12	1.7551	1.7924	1.6804	1.6804	.9431	1.7924	1.6991
13	1.6804	1.643	1.643	1.531	1.0185	1.6804	1.6244
14	1.7924	1.7177	1.6804	1.5684	1.094	1.7177	1.643
15	1.8298	1.7924	1.643	1.7551	1.1317	1.7551	1.6804
16	1.7551	1.7924	1.7177	1.7924	1.1694	1.9418	1.5123
17	1.7924	1.7924	1.7177	1.7551	1.2071	1.7551	1.6057
18	1.8671	1.7177	1.531	1.7364	1.1317	1.7177	1.6244
19	1.8298	1.7177	1.5123	1.7924	1.1317	1.6804	1.6409
20	1.7364	1.6804	1.4937	1.6244	1.2826	1.643	1.6598
21	1.6991	1.5684	1.6057	1.7551	1.4712	1.643	1.6598
22	1.6617	1.643	1.587	1.6804	1.358	1.643	1.6975
23	1.7177		1.6057	1.8298	1.4335		1.6975
24	1.6804	1.6804	1.6057	1.6057	1.6804	1.4712	1.6057
Max	1.8671	1.8298	1.8298	1.8671	1.6804	1.9418	1.7551
Min	1.531	1.4937	1.4563	1.531	.9431	1.4712	1.4937
Avg	1.7201	1.6682	1.6126	1.6656	1.3210	1.6383	1.624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 205 / PADMAJA FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3443		1.3443		1.2449	1.2696
2	1.3443		1.307		1.2071	1.2696
3	1.307		1.3443		1.1694	1.2323
4	1.307		1.3817		1.1694	1.2696
5	1.307		1.3817		1.1317	1.307
6	1.2696		1.307		1.1317	1.3443
7	1.307		1.3443		1.2826	1.3443
8	1.2323		1.419		1.2449	1.358
9	1.4861		1.4937		1.5844	1.6975
10	1.7551	1.5684	1.7551		1.6057	1.5844
11	1.7924	1.6057	1.7924		1.9418	1.6032
12		1.4937	1.6804			1.6221
13	1.5684	1.419	1.6057			1.3957
14	1.6804	1.5684	1.643		1.7177	1.5089
15	1.7551	1.7177	1.7551	.7545	1.7551	1.5466
16	1.7551	1.7924		.7545	1.643	1.6221
17	1.7924	1.7551			1.5684	1.5844
18		1.4937		.7545	1.531	1.5844
19		1.7924		.7545	1.531	1.4146
20		1.7551		.9431		1.4335
21		1.5684		1.2449	1.4937	1.4712
22		1.4563		1.2449	1.3817	1.5466
23				1.2826	1.3443	1.5844
24	1.3817		1.3817		1.2826	1.307
Max	1.7924	1.7924	1.7924	1.2826	1.9418	1.6975
Min	1.2323	1.419	1.307	.7545	1.1317	1.2323
Avg	1.4932	1.6143	1.4960	.9667	1.4268	1.4542



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 206 / 11 KV YADRAV AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2683	.2347	.285	.285		
2		.3018	.2683	.3018	.3018		
3		.3018	.3018	.3018	.3018		
4		.3521	.3018	.3521	.3018		
5		.4108	.3688	.3688	.3353		
6		.3688	.3353	.3688	.3353		
7		.5365	.6036	.5365	.4359		
8	.0048	.7042	.8215	.6706	.5533		
9	.0048	.7701	.7468	.5735	.6371		
10	.0095	.7209	.7468	.6226	.6722		
11	.8848	.0095	.0095	.0095		.852	.9389
12	.9503	.0095	.0095	.0095		1.0159	.9054
13	1.0456	.0095	.0048	.0095		.9831	.9221
14	.8848	.0095	.0095	.0095		.9503	.9556
15	.7865	.0095	.0095	.0095		.8848	.9556
16	.8848	.0095				.9709	.9389
17	.852					.8383	.9054
18	.7712					.8048	
Max	1.0456	.7701	.8215	.6706	.6722	1.0159	.9556
Min	.0048	.0095	.0048	.0095	.285	.8048	.9054
Avg	.6436	.2995	.3181	.2953	.4160	.9125	.9317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 207 / TARDAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.3018	.3018	.285	.285		
2		.3018	.3688	.3018	.3018		
3		.3018	.4024		.3018		
4		.3353	.3688	.3353	.3353	.1509	
5		.3521	.4359	.3688	.3688		
6		.3521	.4024	.57	.57		
7		.6371	.7377	.6706	.7042		
8	.0747	.8718	.9831	1.0059	1.0395		
9	.0238	.9012	1.0486	1.0814	1.0227		
10	.0429	.9175	1.0814	1.0159	1.0159	.1311	
11	1.0814	.0429	.0333	.0333		1.2452	1.1568
12	1.2899	.0381		.0286			1.3077
13	1.2452	.0381		.0381		1.3435	1.2407
14	1.0159	.0429		.0333		1.3108	1.1401
15	1.2125	.0429	.0333	.0381		1.2944	1.2071
16	1.065	.0381				1.475	1.291
17	1.0814					1.2407	1.1736
18	.9221					1.0456	1.1568
Max	1.2899	.9175	1.0814	1.0814	1.0395	1.475	1.3077
Min	.0238	.0381	.0333	.0286	.285	.1311	1.1401
Avg	.7639	.3447	.5165	.4147	.5945	1.0264	1.2092

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 402 / SUNIL INDUSTRIES  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5601	.4481	.5041	.4481	.4527	.4481
2	.4481	.5041	.5041	.5041	.4481	.4527	.5041
3	.5041	.4481	.4481	.5041	.4481	.4527	.4481
4	.4481	.5041	.5041	.5041	.4481	.4527	.4481
5	.4481	.4481	.4481	.5041	.4481	.4527	.5041
6	.5041	.5041	.5041	.5041	.4481	.4527	.4481
7	.4481	.5041	.5041	.5041	.4481	.4527	.4481
8	.5041	.5041	.4001	.5041	.3921	.4527	.5041
9	.4481	.5716	.4572	.5144	.3921	.4527	.4481
10	.5041	.5144	.5144	.4572	.3961	.4572	.5041
11	.4572	.5144	.5144	.4572	.3961	.5144	.5601
12	.5144	.5144	.5144	.4572	.3961	.5144	.5601
13	.4572	.5144	.5144	.4572	.3961	.5144	.5041
14	.5144	.5144	.5144	.5144	.4527	.4572	.4481
15	.5144	.5144	.5144	.5144	.3961	.5144	.4481
16	.5144	.5144	.4481	.4481	.3961	.5144	.4481
17	.5144	.4481	.4481	.4481	.2263	.5041	.4481
18	.4481	.3921	.5041	.4481	.3961	.5041	.4481
19	.5041	.3921	.5041	.4481	.3961	.4481	.4527
20	.4481	.4481	.5041	.4481	.3961	.5041	.4527
21	.4481	.5041	.5041	.4481	.4527	.4481	.4527
22	.5041	.4481	.5041	.4481	.4527	.4481	.4527
23	.5041		.5041	.4481	.4527	.3921	.5093
24	.5041	.5041	.5041	.5041	.4481	.4527	.4481
Max	.5144	.5716	.5144	.5144	.4527	.5144	.5601
Min	.4481	.3921	.4001	.4481	.2263	.3921	.4481
Avg	.4813	.4907	.4887	.4789	.4155	.4693	.4724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 703 / 33 KV MAIN VCB

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	2.6886	2.0165	2.4646	2.3525	1.6975	1.7924
2	1.6804	2.5766	2.1285	2.4646	2.3525	1.5844	1.6804
3	1.7924	2.5766	2.1285	2.4646	2.3525	1.5844	1.5684
4	1.7924	2.6886	2.2405	2.5766	2.4646	1.5844	1.5684
5	1.7924	2.5766	2.4646	2.5766	2.5766	1.5844	1.7924
6	1.7924	2.6886	2.5766	2.8006		1.5844	1.9044
7	1.7924	2.5766	3.1367	3.1367	2.9127	1.6975	1.9044
8	1.7924	3.4728	3.4728	3.6969	3.1367	1.8107	1.7924
9	2.0165	3.9209	3.6969	4.0329	2.9127	2.037	2.1285
10	2.4646	4.0329	4.257	3.9209	3.0556	1.9433	2.3525
11	4.481	2.3525	2.3525	2.2405	.4527	4.9291	4.481
12	4.5931	2.2405	2.2405	2.2405	.3961	5.2652	4.7051
13	4.481	2.1285	2.1285	2.1285	.4527	4.8171	4.369
14	4.369	2.3525	2.2405	2.2405	.4527	4.8171	4.257
15	4.5931	2.4646	2.4646	2.3525	.9054	4.8171	4.369
16	4.481	2.5766	2.4646	2.1285	.7922	4.5931	4.5931
17	4.481	2.4646	2.4646	2.3525	.7922	4.481	4.369
18	3.9209	2.0165	2.4646	1.9044	.7922	3.9209	4.257
19	2.2405	2.1285	2.5766	2.2405	1.0185	1.9605	2.1502
20	2.1285	2.0165	2.4646	2.2405	.9054	2.0165	2.037
21	2.0165	2.1285	2.2405	2.1285	1.5844	1.9605	1.9239
22	2.1285	2.1285	2.2405	2.1285	1.5844	1.9044	1.9239
23	2.0165		2.2405	2.0165	1.5844	1.9044	2.037
24	1.7924	2.0165	2.1285	2.1285	2.0165	1.6975	1.6804
Max	4.5931	4.0329	4.257	4.0329	3.1367	5.2652	4.7051
Min	1.6804	2.0165	2.0165	1.9044	.3961	1.5844	1.5684
Avg	2.7633	2.5571	2.5346	2.5252	1.6455	2.7580	2.7349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 201 / LAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.8006		2.4646	
2	2.2405	2.7633		2.3899	
3	2.2032	2.6886		2.3525	
4	2.2405	2.5766		2.2779	
5	2.4272	2.4646		2.3152	
6	2.6139	2.3525		2.2405	
7	2.4272	2.2405		2.0538	
8	2.2405	2.2405		2.6139	
9	2.2405		2.9127	1.1576	
10	2.9874		2.9874		
11	3.1741		2.9874		
12	3.1741		2.8753		
13	2.838		2.8006		
14	2.8006		2.838		
15	2.8753		2.7633		
16	3.0994		2.8006		
17	3.1741		2.726		3.0994
18	2.7633		2.7633		2.8753
19	2.9874		2.726		2.726
20	2.6139		2.2405		2.2405
21	2.4272		2.4272		2.3152
22	2.4646		2.5019		2.3525
23	2.4646		2.8006		2.3152
24	2.2405	2.8006		2.4646	
Max	3.1741	2.8006	2.9874	2.6139	3.0994
Min	2.2032	2.2405	2.2405	1.1576	2.2405
Avg	2.6233	2.5475	2.7434	2.2331	2.5606

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 202 / MANIK  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2405	2.3525		2.3899	
2	2.2405	2.2405		2.3525	
3	2.1472	2.2032		2.3152	
4	2.0538	2.0911		2.2405	
5	2.0538	2.0538		2.0538	
6	2.2032	2.0538		2.0538	
7	2.1658	2.0911		2.2032	
8	2.1285	2.3525		1.8298	
9	2.3152		2.726	1.7177	
10	2.95		2.9127		
11	3.0994		3.0247		
12	3.2114		2.9874		
13	2.6139		2.9127		
14	2.5393		2.6886		
15	2.8006		2.726		
16	2.838		2.6513		
17	2.95		2.6139		2.9127
18	2.5766		2.4646		2.6886
19	2.5393		2.4646		2.4272
20	2.4646		2.6513		2.4646
21	2.3525		2.5766		2.4272
22	2.3152		2.5019		2.3899
23	2.3899		2.4646		2.3152
24	2.0538	2.3525		2.3899	
Max	3.2114	2.3525	3.0247	2.3899	2.9127
Min	2.0538	2.0538	2.4646	1.7177	2.3152
Avg	2.4685	2.199	2.6911	2.1546	2.5179

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 204 / 11 KV AUTOLINE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0165	2.0233	1.8298	2.0911	1.7924	1.5089	2.2405
2	1.9605	2.1262	1.7551	2.0538	1.8298	1.5089	2.0538
3	1.7177	2.0576	1.7177	1.8298	2.0538	1.4746	1.7551
4		2.1948	1.8671	1.4937	2.0911	1.4746	
5		2.2291	2.0538	1.419	2.0911	1.5432	
6		2.2805	2.0538	1.7924	2.2405	1.6289	
7		2.2291	2.2032		2.4646	1.5432	
8		1.6118	1.1576		1.1203	.7545	
9	2.1948	2.1285	1.7551	1.5684	.8589		2.0576
10	2.2291	2.9127	1.9418	1.643	.7888	2.0165	1.0974
11	2.3148	2.9874	2.2405	2.726	.823	2.0165	2.1605
12	2.2291	2.2032	2.4646	2.6886	.7545	2.4646	2.2462
13	1.4746	2.1658	2.6139	2.6513	.7545	2.4646	2.2291
14	1.5089	2.7633	2.5393	2.6886	.7545	2.4646	2.2634
15	1.8861	2.6886	2.6139		.7545	2.5393	2.2634
16	2.1262	2.5019	2.0165		.7716	2.3899	2.0919
17	2.332	2.1658	1.7551	2.0538	.7888	1.4937	2.2779
18	2.4177	1.0829	2.3152	2.2405	.823	2.0165	2.2405
19	2.332	2.3525	2.4646	2.0538	.8573	2.2405	2.2405
20		2.5019	2.3899	2.4646	.8916	2.0165	2.0538
21	2.0576	2.6513	2.3152	2.5019	.9602	2.2405	2.2405
22	2.0748	2.5393	2.2405	2.5019	.9774	2.2405	2.2779
23	2.0233	2.6886	2.2405	2.5766	1.2346	2.2405	1.9418
24	1.9418	1.8861	1.7924		1.7177	1.5089	2.2405
Max	2.4177	2.9874	2.6139	2.726	2.4646	2.5393	2.2779
Min	1.4746	1.0829	1.1576	1.419	.7545	.7545	1.0974
Avg	2.0465	2.2905	2.0974	2.1599	1.2581	1.9039	2.1038

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 206 / 11 KV MARUTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4272	2.2805	2.1658	2.4272	2.838	2.1262	2.3152
2	2.3899	2.2977	2.0538	2.3899	2.8753	2.0576	2.3899
3	2.3152	2.3148	2.0538	2.3899	2.838		2.4646
4		2.332	1.8298	2.3152	2.6513	2.0233	
5		2.2291	2.0538	2.3525	2.726	2.0233	
6		2.2977	2.3152	2.3899	2.726	7.8875	
7		2.2634	2.4646		2.95	2.1434	
8		1.6118	2.0538		2.726	2.2291	
9	2.4006	2.4272	2.726		2.7633		2.4006
10	2.5377	2.838	2.8006		2.2977	2.9127	2.6063
11	2.5377	2.8753	2.9127		2.2634	3.0178	2.5034
12	2.4691	2.6513	2.9874	2.8006	1.7833	2.9127	2.1262
13	2.4348	2.6886	2.838	2.7633	1.7833	2.838	2.1948
14	2.4691	2.2032	2.8006	2.838	1.749	2.8006	2.2291
15	2.4006	2.2779	2.7633		1.7147	2.7633	2.572
16	2.4348	2.5766	2.8006		1.6461	2.8006	2.7435
17	2.2291	2.8753	2.7633	2.6513	1.6118	2.8006	2.9127
18	2.2977	2.726	2.6139	2.726	1.6804	2.7633	2.726
19	2.332	2.838	2.6139	2.6139	1.7147	2.6139	2.5766
20	2.2291	2.9127	2.5393	2.2032	1.8861	2.6139	2.2405
21	2.3148	2.6513	2.4646	2.2405	1.9204	2.4646	2.3152
22	2.332	2.5766	2.4646	2.4646	1.989	2.3899	2.3525
23	2.2977	2.6513	2.4646	2.726	2.0576	2.3152	2.726
24	2.4646	2.2634	2.1658	2.4646	2.838	2.1948	2.3152
Max	2.5377	2.9127	2.9874	2.838	2.95	7.8875	2.9127
Min	2.2291	1.6118	1.8298	2.2032	1.6118	2.0233	2.1262
Avg	2.3849	2.4858	2.4879	2.5151	2.2512	2.7587	2.4584



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 401 / 33 KV LIE Industrial No 1 SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0247	2.4691	2.5766	2.8006	2.5766	2.3663	2.8006
2	2.8006	2.4177	2.6886	2.6886	2.6886	2.3148	2.6886
3	2.6326	2.3148	2.6886	2.6326	2.5766	2.2634	2.9127
4		2.2634	2.8006	2.6886	2.4646	2.2634	
5		2.3148	2.8006	2.8006	2.5766	2.3148	
6		2.4691	2.9127	2.8006	2.6886	2.3663	
7		2.4691	2.9127		2.8006	2.4177	
8		2.4691	2.8006		2.6886	2.5206	
9	2.572	2.7446		2.9127	2.8006		2.572
10	2.6749	2.8006	2.9127	2.9127	2.6235	3.0247	2.7263
11	2.6749	2.9127	3.0247	2.8006	2.6235	2.9127	2.8292
12	2.6749	3.1367	3.0807	2.9127	2.6749	3.0247	2.8807
13	2.6749	2.9127	2.9127	2.9127	2.6749	2.8006	2.7778
14	2.6235	2.9127	2.8006	2.8006	2.572	2.8006	2.6749
15	2.6235	2.9127	2.9127	2.9127	2.6749	2.9127	2.6749
16	2.6749	3.0247	3.0247	2.9127	2.7778	2.9687	2.6235
17	2.6749	3.1367	2.9687	2.9127	2.7778	2.8006	2.8006
18		3.1367	2.9127	2.9127	2.7263	2.8006	2.8006
19		3.0247	2.9687	2.8006	2.6749	2.6886	2.9127
20	2.6235	3.1367	2.8006	3.0247	2.6749	2.6886	2.9127
21		2.9127	2.6886	2.9127	2.572	2.8006	2.6886
22		2.8006	2.6886	2.9127	2.6235	2.6886	2.5766
23	2.572	2.8006	2.8006	2.8006	2.572	2.6886	3.1367
24	3.0247	2.5206	2.6886	2.8006	2.5766	2.3663	2.8006
Max	3.0247	3.1367	3.0807	3.0247	2.8006	3.0247	3.1367
Min	2.572	2.2634	2.5766	2.6326	2.4646	2.2634	2.572
Avg	2.7031	2.7506	2.8420	2.8439	2.6534	2.6432	2.7784

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 402 / 33 KV LIE INDUSTRIAL NO 2  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.6804	1.8519	1.7924
2	1.9044	1.8004	1.7924
3	1.7924	1.749	1.9044
4		1.749	1.9044
5		1.6461	1.9044
6		1.8519	2.0165
7		1.6461	1.9044
8		1.2346	1.7924
9	1.749	1.4003	2.0165
10	1.8519	2.0165	2.1285
11	1.8519	2.2405	2.1845
12	1.749	2.2405	2.2405
13	1.8004	1.7924	2.2405
14		2.0165	2.1285
15		1.9044	1.9044
16			1.7924
17	1.749		1.7924
18	1.8004		1.7924
19	1.8004		1.7924
20	1.749		1.9044
21	1.6975		2.0165
22	1.8004		1.9044
23	1.8519		2.0165
24	1.4563	1.8519	1.6804
Max	1.9044	2.2405	2.2405
Min	1.4563	1.2346	1.6804
Avg	1.7678	1.812	1.9394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 201 / SAJANI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4805	.4668	.4854	.4481	.4435	.3734	.4435
2	.4435	.4668	.4481	.4108	.4066	.3734	.4066
3	.4435	.4854	.4481	.3734	.4066	.4108	.4066
4	.4435	.4854	.4527	.3734	.4066	.4108	.4066
5	.4805	.5041	.4854	.4294	.4066	.4481	.4435
6	.5175	.5415	.5228	.4854	.4435	.4668	.4805
7	.5544	.5601	.5601	.4854	.4805	.4854	.5175
8	.5544	.5788	.5975	.5788	.3696	.5041	.5914
9	.5914	.6348	.5601	.5601	.3511	.5975	.6283
10	.5228	.5788	.5175	.5228	.3361	.5729	.5601
11	.5228	.4854	.5544	.3734	.2801	.6283	.5228
12	.5228	.5415	.5914	.3921	.2054	.6283	.5041
13	.5415	.5415	.5544	.3921	.2054	.4805	.4481
14	.5415	.6161	.5359	.5041	.2054		.4668
15	.5041	.5601	.499	.5601	.2054	.5544	.5041
16	.4854	.5601	.5228	.5601	.2075	.5544	.5228
17	.4854	.6535	.5228	.5788	.2054	.5544	.5601
18	.5975	.6722	.5601	.5729	.2427	.6283	.5975
19	.6908	.7095	.6908	.6653	.4668	.6653	.7282
20	.6535	.7095	.6535	.6653	.5415	.6653	.7095
21	.6161	.6722	.6161	.7023	.5228	.6283	.6722
22	.5975	.6348	.5788	.6283	.5228	.5544	.5975
23	.5788	.5975	.5228	.5544	.4668	.5175	.5415
24	.499	.5041	.5228	.4854	.499	.3734	.4805
Max	.6908	.7095	.6908	.7023	.5415	.6653	.7282
Min	.4435	.4668	.4481	.3734	.2054	.3734	.4066
Avg	.5362	.5734	.5418	.5126	.3678	.5250	.5308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 203 / PANCHAGANGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5601	.5601	.547	.5228	.4854	.4668
2	.4904	.5601	.5601		.4854	.4854	.4481
3	.4904	.5975	.5601	.5093	.4854	.5228	.4481
4	.5658	.6722		.5281	.5228	.5601	.4854
5	.679	.7468	.7842	.6224	.5975	.6722	.5601
6	.7922	.8215	.9709	.7167	.6348	.7282	.6535
7	.9054	.8589	.9896	.811	.7095	.8589	.7655
8	.9242	.8215	.8029	.7733	.6908	1.0082	.7655
9	.9431	.7468	.7468	.811	.6722	.9055	.7842
10	.9335	.8676	.9522	.8215	.6036	1.0082	.6535
11	1.0642	.8865	.9709	.7842	.6036	.8402	.7282
12	1.0829	.9619	1.0082		.5658	.8029	.7655
13	.9335	.7922	1.0456	.8029	.4715	.8402	.6722
14	.8962	.679	1.0642	.8215	.4904		.6348
15	.8215	.6979	1.0642	.8402	.4904	.9709	.6722
16	.7842	.7733	1.0562	.8215	.4338	.9709	.6348
17	.7095	.7545	.9997	.8962	.4854	1.0082	.6722
18	1.0642	.7842	.9431	.8676	.5601	.9896	.7356
19	1.0829	.8589	.679	.9522	.6348	.9709	.811
20	.9335	.8589	.679	.8962	.6908	.9335	.8299
21	.8962	.8215	.6602	.8402	.6908	.8589	.811
22	.8215	.7468	.8865	.7167	.6535	.7842	.7545
23	.6908	.6908	.6224	.5601	.5228	.6722	.679
24	.5658	.5975	.6161	.6036	.5601	.5093	.4668
Max	1.0829	.9619	1.0642	.9522	.7095	1.0082	.8299
Min	.4904	.5601	.5601	.5093	.4338	.4854	.4481
Avg	.8166	.7565	.8357	.7520	.5741	.7994	.6624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 204 / RUI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.1006	.0671	.0671	.2515	.2515	.2683
2	.3052	.1006	.0671	.0671	.2515	.2683	.2683
3	.3052	.1006	.0671	.0671	.2515	.2683	.2683
4	.3391	.1174	.0838	.0671	.3018	.3353	.3688
5	.407	.1174	.0838	.0838	.3688	.3688	.4359
6	.4409	.1174	.0838	.1006	.4359	.4024	.4694
7	.5087	.1174	.0838	.1174	.503	.4694	.503
8	.5426	.1006	.0838	.0838	.5197	.5868	.5533
9	.5765	.0838	.0838	.1006	.5197	.5801	.6371
10	.1006	.0838	.0848	.1174	.0671	.0678	.1006
11	.1006	.7545	.7122	.7209	.0671	.0848	.0838
12	.1006	.7377	.7461		.0671	.0848	.0838
13	.0934	.788	.7461	.7209	.0838	.0848	.0838
14	.0838	.8048	.7122	.7209	.0838		.0838
15	.0671	.7545	.7122	.7042	.0838	.0848	.0838
16	.0838	.7209	.7042	.7042	.0671	.0848	.0838
17	.0838	.6539	.6371	.6203	.0648	.0848	.1006
18	.1006	.6036	.6036	.5765	.0838	.0838	.1006
19	.1006	.1006	.1174	.1017	.1006	.1006	.1341
20	.1174	.1174	.1174	.1017	.1006	.1006	.1341
21	.1174	.0995	.1006	.1017	.1006	.0838	.1174
22	.1174	.0838	.1006	.0838	.1006	.0838	.1174
23	.1174	.0838	.1006	.0838	.0838	.0848	.1006
24	.3052	.1006	.0838	.1006	.2515	.2515	.2683
Max	.5765	.8048	.7461	.7209	.5197	.5868	.6371
Min	.0671	.0838	.0671	.0671	.0648	.0678	.0838
Avg	.2258	.3101	.2910	.2701	.2004	.2129	.2270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 205 / MANGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.2241	.1867	.1867	.1848	.1867	.1848
2	.1848	.2054	.1867	.1886	.1848	.1867	.1848
3	.1848	.2054	.1867	.1867	.1848	.1867	.1848
4	.1848	.2427	.1867	.1867	.1848	.2054	.1848
5	.2218	.2427	.2054	.1867	.1848	.2054	.2033
6	.2587	.2801	.2241	.2241	.2033	.2241	.2402
7	.3326	.2427	.2614	.2987	.2218	.2427	.2587
8	.3174	.2614	.2801	.2614	.2402	.2267	.2402
9	.2987	.2241	.2614	.2614	.2587	.2587	.2218
10	.2614	.2614	.2218	.2614	.2241	.2587	.2241
11	.2241	.2614	.2218	.2614	.2241	.2587	.2241
12	.2241	.2427	.2218	.2241	.2241	.2402	.2241
13	.2427	.2427	.2218	.2241	.2427	.2402	.2054
14	.2614	.2614	.2218	.2054	.2241		.2241
15	.2427	.2641	.2218	.2241	.2263	.2402	.2427
16	.2427	.2427	.2241	.2241	.2075	.2402	.2614
17	.2401	.2614	.2241	.2614	.2054	.2402	.2614
18	.2614	.2987	.2614	.2957	.2427	.2772	.2614
19	.2987	.3361	.3921	.3326	.2987	.3142	.3584
20	.3921	.3734	.3734	.3511	.3547	.3326	.3772
21	.3361	.3734	.3361	.3696	.3361	.3142	.3921
22	.2987	.3174	.2987	.2957	.3174	.3142	.3734
23	.2801	.2801	.2427	.2218	.2241	.2772	.2614
24	.2402	.2241	.2241	.1867	.2033	.2054	.1848
Max	.3921	.3734	.3921	.3696	.3547	.3326	.3921
Min	.1848	.2054	.1867	.1867	.1848	.1867	.1848
Avg	.2605	.2654	.2453	.2467	.2335	.2468	.2491

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 206 / 11 KV MANGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.0343	.0343	.0343	1.3717	1.286	1.286
2	1.0288	.0343	.0343	.0343	1.3717	1.286	1.286
3	1.0288	.0343	.0343	.0343	1.3717	1.3203	1.286
4	1.0288	.0343	.0343	.0343	1.406	1.3203	1.286
5	1.046	.0343	.0343	.0343	1.4403	1.3375	1.3032
6	1.0631	.0343	.0343	.0343	1.4746		1.3032
7	1.0802	.0343	.0343	.0343	1.5089	1.406	1.3032
8	1.0974	.0343		.0343	1.5089	1.4232	1.3203
9	1.1317	.0343	.0343	.0343	1.4746	1.4083	1.3375
10	.0514	.0343	.0343	.0343	.0343	.0343	.0343
11	.0343	1.8861	1.9547	1.9204	.0343		.0343
12	.0343	1.9033	1.989	1.7661	.0343	.0343	.0343
13	.0343	1.9204	1.9376	1.8176	.0377	.0343	.0343
14	.0343	1.9376	1.9033	1.8347	.0343		.0343
15	.0343	1.9376	1.8861	1.8519	.0343	.0343	.0343
16	.0343	1.8004	1.869	1.8519	.0343	.0343	.0343
17	.0343	1.7833	1.8347	1.8004	.0343	.0343	.0343
18	.0343	1.7661	1.8004	1.6461	.0343	.0343	.0343
19	.0514	.0343	.0514	.0343	.0343	.0343	.0343
20	.0343	.0343	.0343	.0343	.0343	.0343	.0343
21	.0514	.0343	.0343	.0343	.0343	.0343	.0343
22	.0343	.0343	.0514	.0343	.0343	.0343	.0343
23	.0343	.0343	.0514	.0343	.0343	1.286	.0343
24	1.0288	.0343	.0343	.0514	1.3717	1.286	1.286
Max	1.1317	1.9376	1.989	1.9204	1.5089	1.4232	1.3375
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4622	.6452	.6844	.6273	.6160	.6541	.5616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 207 / 11 KV LAXMI AG. (SAJANI) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6249	.064	.0625	.081	.6562	.7042	.6562
2	.6325	.0648	.0625	.081		.7449	.6562
3	.6325	.081	.0781	.081	.6562	.7449	.6874
4	.7274	.081	.0781	.0648	.7499	.8097	.7499
5	.8223	.081	.0949	.0648	.8436	.8745	.8749
6	.9804	.081	.0949	.081	.9374	.9393	1.1561
7	1.1385	.081	.1094	.1134	1.0311	1.2955	1.2654
8	1.2334	.0972	.1094	.1134	1.1561	1.4899	1.3435
9	1.2967		.0625	.1341	1.2654	1.4706	1.4373
10	.0633	.081	.0633	.0972	.0972	.0781	.0972
11	.0633	1.5708	1.9605	1.5384	.081		.081
12	.0625	1.4089	1.6762		.081	.0937	.081
13	.0781	1.5708	1.5813	1.587	.0648	.0937	.081
14	.0781	1.4737	1.5339	1.6032	.0648		.096
15	.0781	1.4575	1.5023	1.5844	.1134	.0781	.096
16	.0781	1.5384	1.5223	1.5684		.0937	.112
17	.0781		1.4899	1.6004		.125	.128
18	.081	1.2811	1.4575	1.5181	.0972	.125	.0972
19	.081	.0937	.1457	1.1069	.0972	.1094	.1134
20	.081	.1094	.1296	.0633	.0972	.1094	.1134
21	.081	.1094	.1134	.0633	.096	.0781	.0972
22	.081	.0937	.0972	.0625	.081	.0625	.0972
23	.0648	.0625	.0972	.0625	.0648	.0625	.0476
24	.6249	.0648	.0625	.0972	.6562	.7042	.6562
Max	1.2967	1.5708	1.9605	1.6032	1.2654	1.4899	1.4373
Min	.0625	.0625	.0625	.0625	.0648	.0625	.0476
Avg	.4068	.5249	.5910	.5812	.4280	.4949	.4509



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 208 / 11 KV GOMTESH VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1494	.1867	.1715	.1698	.1494	.1886
2	.1698	.1494	.168	.1715	.1509	.1509	.1886
3	.1698	.168	.168	.1715	.1509	.1494	.1886
4	.1698	.168	.168	.1524	.1509	.168	.1886
5	.1698	.1867	.168	.1715	.1509	.168	.1886
6	.1698	.1867	.1867	.1905	.1698	.168	.1886
7	.1886	.1867	.2054	.1905	.1886	.1867	.2075
8	.2263	.2241	.2241	.2286	.1886	.1867	.2641
9	.2452	.2614	.2801	.2286	.1886	.2241	.3018
10	.3734	.2667	.3018	.3921	.1677	.3206	.3734
11	.3429	.3429	.4527	.3734	.1698	.415	.5228
12	.2987	.3429	.4527	.2801	.1715	.415	.4854
13		.2477	.4904	.2427	.1715	.3206	.3734
14	.2241	.3048	.4527	.2614	.1713		.4854
15	.2801	.2858	.4904		.1524	.3584	.5281
16	.2987	.2858	.4763	.3174	.1524	.3772	.4854
17	.3174	.2667	.381	.2427	.1494	.3772	.4481
18	.2987	.2427	.3429	.2641	.168	.3018	.3772
19	.2515	.2614	.2665	.2641	.168	.2641	.2641
20	.2241	.2614	.2477	.2641	.1494	.2641	.2452
21	.2241	.2241	.2263	.2641	.1494	.2452	.2286
22	.2054	.2241	.2452	.2263	.168	.2452	.1905
23	.1867	.1867	.2263	.2075	.168	.2263	.1905
24	.1886	.168	.1867	.1905	.1886	.1494	.2263
Max	.3734	.3429	.4904	.3921	.1886	.415	.5281
Min	.1698	.1494	.168	.1524	.1494	.1494	.1886
Avg	.2345	.2330	.2914	.2377	.1656	.2535	.3054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 401 / 33 KV MANGAON INDUSTRIAL  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.4582	4.8097	4.7531	4.7531	5.036	4.1872	4.1307
2	4.5153	4.6965	4.6399	4.6399	4.9794	4.0329	4.4136
3	4.5725	4.6965	4.5268	4.8663	4.8663	4.0741	4.5268
4	4.4582	4.5268	4.5268	4.6399	4.9794	3.9609	4.6399
5	4.3439	4.5268	4.5833	4.4136	4.8663	3.8477	4.6965
6	4.401	4.6399	4.5833		4.8663	3.7346	4.4702
7	4.2295	4.7531	3.9609	4.357	4.8663	3.9043	4.1872
8	4.0581	4.1872	4.3004	4.8663	4.9794	4.1307	4.5268
9	4.2295	4.7531	4.0741	4.9794	4.1872	4.0741	4.6399
10	4.2438	4.8663	4.9228	4.8097	4.3004	4.6399	4.5268
11	5.036	4.4136	4.8663	4.9228	4.257	4.8097	4.5833
12	4.9794	5.0926	5.0926	4.8663	4.0741	4.1872	4.9794
13	4.2438		5.036	4.6965	4.0741	4.6399	4.7531
14	4.1307	4.6399	4.5268	4.6965	3.8649		4.0741
15	4.1872	4.9794	4.4136	4.9794	4.0329	4.8097	4.7531
16	4.4136	4.9228	4.5268	5.3755	4.145		4.9794
17	4.6965	4.9794	5.0926	5.2058	4.1307	4.7531	4.7531
18	4.7531	4.6399	4.6965	4.9794	3.9609	4.8097	4.1307
19	4.8663	4.9794	4.8663	4.9794	3.9769	4.1872	4.8663
20	4.6965	5.036	4.5833	4.9794	3.9209	4.2438	4.8097
21	4.5268	4.9794	4.8663	4.9794	4.0741	4.8663	4.8663
22	5.0926	4.9228	4.6965	4.9794	4.2438	4.3004	4.8663
23	5.2058	4.9794	4.4136	4.9794	4.1307	4.3004	4.9228
24	4.5153	4.8097	5.036	5.036	5.2058	4.3004	5.0926
Max	5.2058	5.0926	5.0926	5.3755	5.2058	4.8663	5.0926
Min	4.0581	4.1872	3.9609	4.357	3.8649	3.7346	4.0741
Avg	4.5356	4.7752	4.6494	4.8687	4.4175	4.3088	4.6329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 201 / PUJARI MALA AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.061	.0314	.0686	1.1736	1.1142	.9602	.0667
2	.061	.0314	.0686	1.1888	1.0883	.9907	.0667
3	.061	.032	.0686	1.1888	1.0883	.9907	.0686
4	.061	.0332	.0686	1.1888	1.1012	1.0212	.0686
5	.061	.0343	.0686	1.1888	1.1523	1.0212	.0648
6	.061	.0457	.0686	1.2041	1.2308	1.0212	.0648
7	.061	.0427	.0686	1.2803	1.3435	1.0974	.0648
8	.061	.0457	.0686	1.4784	1.4582	1.2498	.0667
9	.061	.0419	.0686	1.5089	1.4918	1.326	.0857
10	.061	.0442	.061	1.4784	1.4746		.0857
11	1.6613	2.0481		.061	.0572	.0762	1.8861
12	1.9393	2.1776	2.0919	.0686	.0762	.0762	2.0062
13	1.9559	2.1948	2.1776	.0686	.0762		2.0405
14	1.9334	2.1776	2.1434	.0686	.0762		2.0748
15	1.8084	2.1434	2.0748	.0686	.0857	.0305	2.1434
16	1.9062	2.0919	2.0576	.0857	.0762		2.1262
17	1.8947	2.0233	2.0233	.0857	.0762		1.9033
18	1.8564	1.9719	1.8347	.0857	.0762		2.0233
19	.061	.0686		.0857	.0762		.0762
20	.061	.0686	.061	.0524	.0762	.0572	.0762
21	.061	.0686	.061	.0572	.0762	.0619	.0762
22	.061	.0686	.061	.0638	.0762	.0572	.0762
23	.061	.0686	.061	.0476	.0762	.0572	.0762
24	.061	.0427	.0686	.061	.0476	.0762	.0553
Max	1.9559	2.1948	2.1776	1.5089	1.4918	1.326	2.1434
Min	.061	.0314	.061	.0476	.0476	.0305	.0553
Avg	.6638	.7332	.6997	.5766	.5655	.5983	.7226

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 202 / 11KV GANPATI MANDIR AG      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6036	.6859				
2	.6859	.57	.6859				
3	.6859	.5765	.6859				
4	.6859	.5765	.6859				
5	.6859	.6173	.6859				
6	.6859	.6173	.6859				
7	.703	.6859	.6173				
8	.7888	.6859	.6859				
9	.8059	.7461	.6859				
10	.823	.6706	.6859				
11				1.0631	1.166	1.0802	1.1317
12				1.0631	1.2003	1.166	1.2346
13				1.1317	1.2346	1.166	1.2346
14				1.1317	1.3032	1.166	1.2346
15				1.166	1.3032	1.166	1.2517
16				1.166	1.2346	1.0974	1.2346
17				1.1317	1.2346	1.0974	1.1317
18				1.1317	1.166	.9755	1.0631
Max	.823	.7461	.6859	1.166	1.3032	1.166	1.2517
Min	.6859	.57	.6173	1.0631	1.166	.9755	1.0631
Avg	.7236	.6350	.6790	1.1231	1.2303	1.1143	1.1896

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 203 / SHIRADWAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4877	.5571	.2058	.4115	.426	.4268	.5243
2	.4877	.5182	.2058	.3963	.421	.4115	.4858
3	.4725	.4915	.2058	.4115	.431	.4268	.4915
4	.503	.4973	.2401	.4115	.421	.4268	.4973
5	.4877	.4801	.3086	.4115	.4534	.4572	.5182
6	.5182	.4999	.3429	.4268	.4588	.4877	.5506
7	.5182	.5182	.3429	.4572	.503	.503	.5243
8	.5335	.4858	.4115	.4877	.5571	.5487	.5571
9	.6401	.6154	.5487	.6401	.6783	.6859	.6859
10	.6249	.5761	.5487	.5944	.6478		.6859
11	.6401	.5761	.6173	.5792	.6554	.7011	.6859
12	.6401	.4801	.6344	.6001	.5639	.6097	.6859
13	.4801	.3086	.6001	.463	.3658	.4115	.4973
14	.583	.4287	.583	.5144	.4877	6.8435	.5316
15	.6226	.4801	.6859	.583	.5487	.6097	.6859
16	.6874	.2743	.6859	.6001	.6097	.6097	.703
17	.7042	.4115	.703	.6516	.6097	.6097	.7716
18	.663	.3429	.6173	.6516	.5487	.6859	.6859
19	.7316	.3601			.6249	.6097	.7011
20	.6097	.2743	.4572	.5441	.5792	.6154	.5944
21	.6097	.2743	.4877	.5243	.6097	.6401	.6401
22	.6097	.2743	.4572	.4744	.5792	.6226	.5487
23	.5487	.2058	.4572	.4481	.5182	.5967	.5487
24	.5335	.5761	.2058	.442	.4062	.4877	.5636
Max	.7316	.6154	.703	.6516	.6783	6.8435	.7716
Min	.4725	.2058	.2058	.3963	.3658	.4115	.4858
Avg	.5807	.4378	.4588	.5098	.5294	.8273	.5985

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 204 / ABDUL LAT AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.4575	1.4746	.1543	.0914	.1372	.1097
2	1.2689	1.3763	1.4746	.1543	.0914	.1372	.1067
3	1.2517	1.3283	1.4746	.1543	.0945	.1372	.1036
4	1.2689	1.3283	1.4746	.1543	.1132	.1372	.1052
5	1.3032	1.3763	1.4746	.1886	.1238	.1715	.12
6	1.3203	1.4419	1.4746	.1886	.1362	.1886	.1132
7	1.6804	1.8515	1.7661	.2058	.1181	.1886	.1425
8	2.0748	2.0485	1.9719	.2058	.1257	.2058	.1555
9	2.2291	2.1605	2.1262	.1886	.1362	.1886	.2058
10	2.1091	2.0885	2.0919	.1886	.1257		.2058
11	.12	.0914	.1543	2.7778	2.625	2.7092	2.6578
12	.096	.1372	.1715	3.035	2.9664	2.9664	2.9664
13	.1012	.1372	.1715	2.915	2.7778	2.5206	2.8635
14	.096	.1372	.1372	2.8807	2.7778	2.7435	2.7949
15	.0838	.1372	.12	2.8635	2.7263	2.7435	2.8978
16	.0914	.1372	.1543	2.8635		2.692	2.7606
17	.1029	.1372	.1886	2.8464		2.6235	2.6749
18	.1349	.1886	.2058	2.7435			2.4863
19		.2229			.2058	1.869	.2229
20	.1829	.2401	.2572	.1387	.2058	.1372	.2401
21	.2229	.2229	.2401	.1536	.2229	.1555	.2401
22	.1886	.2058	.2058	.1802	.1886	.1067	.2229
23	.1543	.1715	.1886	.1362	.1715	.0995	.1886
24	.1715	.1143	.1715	.1715	.0914	.1543	.096
Max	2.2291	2.1605	2.1262	3.035	2.9664	2.9664	2.9664
Min	.0838	.0914	.12	.1362	.0914	.0995	.096
Avg	.7603	.7808	.8335	1.1082	.7674	1.0460	1.0284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.0949	.0686	.0857	.0671	.0686	.0671
2	.0857	.0937	.0686	.0857	.0663	.0686	.0655
3	.0686	.0819	.0686	.0857	.0829	.0857	.0838
4	.0686	.0829	.0686	.0857	.0848	.0857	.0857
5	.1029	.0972	.0857	.1029	.0838	.0857	.0857
6	.1029	.1174	.0857	.1029	.08	.0857	.1006
7	.12	.1174	.12	.1029	.0857	.12	.1006
8	.12	.1006	.12	.12	.0905	.0857	.1006
9	.12	.0983	.1372	.12	.0354	.12	.0686
10	.0857	.0972		.1029	.0343		.1029
11	.12	.0819	.0686	.0686	.0339	.1029	.1029
12	.0972	.1029	.12	.1029		.12	.12
13	.08	.0686	.12	.0686		.0686	.0857
14	.081	.0857	.1029	.1029		.0343	.0857
15	.0791	.1029	.0857	.1029		.0686	.12
16	.0633	.1029	.1029	.0857		.1029	.1029
17	.1134	.12	.0857	.12		.12	.12
18	.1107	.12	.12	.1029		.1029	.12
19	.12	.12			.0343	.1029	.12
20	.1029	.12	.1029	.0819	.0343	.0995	.1029
21	.1029	.1029	.1029	.0829	.1029	.1029	
22	.1029	.0857	.0686	.0905	.0686	.0995	.1029
23	.0857	.1029	.1029	.0857	.0857	.0838	.0857
24	.0857	.0937	.0686	.0686	.0686	.0857	.0655
Max	.12	.12	.1372	.12	.1029	.12	.12
Min	.0633	.0686	.0686	.0686	.0339	.0343	.0655
Avg	.0968	.0997	.0943	.0938	.0670	.0913	.0954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 206 / 11 KV SOCIETY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.1543	.1886	.2401	.2058	.2012
2	.2401	.2035	.1543	.2058	.2058	.2058	.2012
3	.2058	.2058	.1543	.1886	.2035	.1886	.2012
4	.2229	.1966	.1543	.2229	.2035	.2058	.2035
5	.2058	.2035	.1543	.2572	.218	.2058	.218
6	.2058	.2401	.1543	.2572	.2347	.2058	.2204
7	.2572	.2713	.1715	.2401	.2454	.2401	.2374
8	.2401	.2572	.1372	.2743	.2279	.2572	.2374
9	.3429	.2058	.3086	.3772	.3121	.3258	.3086
10	.3086	.2204	.3086	.3429	.3086		.3258
11	.3429	.2543		.2915	.3086	.3258	.3258
12	.3185	.2401	.3258	.2572	.2915	.3258	.2915
13	.2683	.1886	.3258	.2229	.2572	.2058	.2058
14	.2347	.2058	.2915	.2572	.2743	.2572	.2058
15	.2683	.2572	.2572	.2572	.2915	.2915	.2915
16	.285	.2743	.2572	.2743	.3086	.3258	.2743
17	.2543	.2229	.2743	.2743	.3086	.2915	.2743
18	.2915	.2229	.2229	.2743	.3086	.2743	.2743
19	.3086	.1543		.2401	.2915	.3086	.2743
20	.2572	.1372	.2572	.2515	.2743	.2572	.2743
21	.2401	.1372	.2572	.2105	.2743	.2629	.2401
22		.1372	.1886	.1715	.1715	.2454	.1886
23	.2058	.1715	.2572	.2229		.2204	.2229
24	.2401	.2347	.1543	.2229	.2347	.2229	.218
Max	.3429	.2743	.3258	.3772	.3121	.3258	.3258
Min	.2058	.1372	.1372	.1715	.1715	.1886	.1886
Avg	.2595	.2103	.2237	.2493	.2606	.2546	.2465



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 402 / I-CO SPIN FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.3439	4.1152	4.2295	4.0009	3.8866	4.2295	4.0009
2	4.401	3.8866	4.2295	4.0009	3.8866	4.2867	3.9438
3	4.2867	3.8866	4.2295	4.1724	4.0009	4.1724	3.9438
4	4.2295	3.7723	4.2295	4.1152	4.0009	4.1152	4.0009
5	4.401	3.7723	4.2295	4.1724	4.1152	4.0009	4.1152
6	4.4582	3.7151	4.2295	4.2295	4.2295	4.2295	4.2295
7	4.3439	3.9438	4.5725	4.3439	4.0009	4.1152	4.4582
8	4.5725	3.7151	4.401	4.6868	4.1152	4.1724	4.0581
9	3.658	4.2295	4.3439	4.2867	4.1724	4.4582	4.6296
10	3.3722	4.1724	3.8066	4.5153	4.1152		3.8866
11	4.1152	4.0581		4.2867	4.1152	4.0581	4.2867
12	3.7723	4.4582		4.2295	3.8295	4.4582	4.7439
13	4.0581	4.1724	4.5725	4.5725	3.658	4.401	4.6296
14	3.7151	4.1724	4.401	4.5725	4.2867	4.4582	4.5725
15	4.1152	4.1152	3.7723	4.5153	4.1152	4.5153	4.7439
16	4.0009	4.5153	4.7439	4.8011	4.5153	4.8011	4.3439
17	3.8866	4.1152	4.4582	4.2867	4.1724	4.1152	4.1724
18	3.7723	4.2867	4.1152	4.2867	4.4582	4.4582	4.4582
19	3.658	4.2867			4.0009	4.0581	4.0009
20	3.2007	3.9438	4.0009	3.5437	4.0009	4.1152	3.8866
21	3.4294	4.3439	3.9438	3.9438	3.8866	4.1724	3.8866
22	3.8295	4.1152	4.1724	3.9438	3.8866	4.0009	4.1724
23	3.8295	4.5725	4.401	4.2867	4.401	4.1152	4.2867
24	4.5725	4.0009	4.1152	4.5153	3.8295	3.9438	4.1152
Max	4.5725	4.5725	4.7439	4.8011	4.5153	4.8011	4.7439
Min	3.2007	3.7151	3.7723	3.5437	3.658	3.9438	3.8866
Avg	4.0009	4.0986	4.2475	4.2743	4.0700	4.2370	4.2319

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 201 / 11 KV SAHARANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5624	.6226	.1494	.4049	.503	.4588	.4268
2	.5155		.1494	.3725	.4191		.3963
3	.5155		.1494	.3725	.4191		.3963
4	.4999		.1494	.3563	.4191		.3963
5	.4999		.1494	.3563	.4191		.3963
6	.4999		.1867	.3563	.4191	.426	.4115
7	.5312		.2075	.3725	.4191	.426	.4268
8	.5312	.4915	.2427	.5344	.503	.426	.4572
9	.5937	.5401	.5668		.5468	.5792	.5571
10	.6874	.5468	.6478		.5624	.6097	.5898
11	.6874	.5182	.6478	.6554	.5668	.6249	.6554
12	.6874	.4858	.5668	.5243	.5658	.5639	.5571
13	.5155	.3887	.3239	.3277		.4999	.3605
14	.5937	.2915	.4372	.5853	.4049	.583	.5243
15	.6249	.3961	.6154		.4858	.578	.6226
16	.5937	.3479	.6478	.6882	.5344	.6093	.6554
17	.6554	.2801	.602	.6478	.5571	.5944	.6154
18	.7209	.2241	.5719	.6478	.5735	.5944	.6478
19	.6554	.2241	.5639	.6478		.5647	.6478
20	.5571	.1867	.5487	.6154	.426	.5201	.6154
21	.5898	.2054	.5468	.6478		.4755	.6478
22	.6226	.1867	.5468	.5668	.5079	.4458	.5668
23	.6226	.168	.5155	.5668		.431	.5668
24	.5937	.6226	.1494	.4531	.5668	.4588	.4161
Max	.7209	.6226	.6478	.6882	.5735	.6249	.6554
Min	.4999	.168	.1494	.3277	.4049	.426	.3605
Avg	.5899	.3737	.4118	.5095	.4909	.5235	.5231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 202 / 11 KV BIRDEV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2186	1.4754	.6733	1.1069	1.1336	1.1736	1.2041
2	1.2186		.6733	1.0402	1.1336	1.1736	1.1888
3	1.2186		.7087	1.0402	1.1012	1.1736	1.1888
4	1.2186		.7087	1.0402	1.1012	1.1736	1.1888
5	1.2483		.7087	1.0526	1.1336	1.1736	1.1888
6	1.2483		.7619	1.1429	1.1336		1.189
7	1.2631		.8505	1.1336	1.2146	1.1736	1.2041
8	1.2186	1.4083	.9922	1.2955	1.3765	1.3077	1.2037
9	1.278	1.3889	1.3765			1.3717	.0151
10	1.382	1.4661	1.5384		1.406	1.448	1.6095
11	1.4118	1.4661	1.6194	1.6598	1.4575	1.448	1.7269
12	1.2334	1.3279	1.3765	1.2071	1.2955	1.2955	1.1904
13	.9065	1.0526	.9717	.9054		1.0155	.9724
14	1.3375	1.2003	1.4575	1.3413	1.2146	1.2651	1.3077
15	1.4415	1.0526	1.5384		1.2146	1.4842	1.5592
16	1.4861	1.0526	1.6194	1.5424	1.2651	1.4842	1.5592
17	1.643	.7442	1.4661	1.4575	1.4083	1.4148	1.4899
18	1.6095	.6379	1.448	1.4575	1.4419	1.3847	1.5384
19	1.5424	.6733	1.406	1.3765		1.3847	1.4575
20	1.4419	.7087	1.2193	1.4575	1.2742	1.3546	1.2955
21	1.4754	.7442	1.3117	1.3765		1.3696	1.3765
22	1.5257	.7442	1.2498	1.3765	1.2742	1.2944	1.3603
23	1.5089	.7796	1.1717	1.2955		1.0837	1.2955
24	1.2334	1.4754	.6024	1.0936	1.2146	1.1736	1.2191
Max	1.643	1.4754	1.6194	1.6598	1.4575	1.4842	1.7269
Min	.9065	.6379	.6024	.9054	1.1012	1.0155	.0151
Avg	1.3462	1.0777	1.1438	1.2571	1.2523	1.2879	1.2721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 203 / 11 KV INDUSTRIAL  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7206	2.6825	2.5888	2.5987	2.5987	1.8442	2.5587
2	2.6886		2.5396	2.5149	2.5149	1.8442	2.5101
3	2.6406		2.4905	2.5149	2.5149		2.5249
4	2.5926		2.4249	2.572	2.431		2.4615
5	2.5286		2.4249	2.6578	2.431		2.4615
6	2.4646		2.4249	2.572	2.431		2.4615
7	2.5606		2.4577	2.6578	2.3472	1.8107	2.5911
8	2.6886	2.6825	2.5396	2.6825	2.0119	2.146	2.672
9	2.8166	2.915	2.915		1.326	2.6216	2.9508
10	3.0087	2.9959	3.0864		1.2003	2.8178	3.0849
11	3.0087	2.9959	3.1017	3.2023	1.1736	2.9835	3.2526
12	2.7526	2.9492	2.6825	2.4143	1.0288	2.8178	2.5819
13	2.3482	2.7664	2.431	2.431		2.5692	2.3137
14	2.6886	2.3472	3.0178	2.7161	.7716	2.8502	2.7161
15	2.8166	2.6825	3.0178		.7716	2.915	2.9675
16		2.9492	3.1017	3.0011	.7716	3.0664	3.0011
17	3.0849	2.8837	2.915	3.1722	.7377	2.9635	3.0178
18	3.0514	2.7526	2.834	3.0521	.7042	2.915	3.1017
19	2.9508	2.7526	2.7854	2.8502		2.915	3.0178
20	2.8166	2.7199	2.8178	2.934	.8215	2.8826	2.934
21	2.7496	2.7035	2.8509	2.8166		2.915	2.934
22	2.6825	2.6871	2.8178	2.6825	1.7939	2.8502	2.8502
23	2.7328	2.6543	2.7349	2.6825		2.672	2.934
24	2.7526	2.6825	2.6216	2.652	2.6825	1.9113	2.5911
Max	3.0849	2.9959	3.1017	3.2023	2.6825	3.0664	3.2526
Min	2.3482	2.3472	2.4249	2.4143	.7042	1.8107	2.3137
Avg	2.7455	2.7668	2.7343	2.7323	1.6532	2.6156	2.7704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 205 / CHANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7095	.4915	.4534	.5068	
2			.7468	.503	.4534	.5068	
3			.7468	.503	.4858		
4			.7468	.503	.4858		
5			.7468	.5365	.5668		
6			.7842	.6036	.5668		
7			.8589	.6706	.6478	.6516	
8			.9335	.7545	.583	.6878	
9					.6203	.663	
10			.4858		.6154	.7459	
11	1.2071	1.1012	.6478				1.2489
12	1.3375	1.1469					1.3213
13	1.3077	1.1961					1.3937
14	1.3817	1.21					1.3937
15	1.307	1.2125					1.4118
16	1.363	1.1633					1.3575
17	1.267	1.1142					1.0526
18	1.2127	1.0159					.9717
Max	1.3817	1.2125	.9335	.7545	.6478	.7459	1.4118
Min	1.2071	1.0159	.4858	.4915	.4534	.5068	.9717
Avg	1.2980	1.1450	.7407	.5707	.5479	.6270	1.2689

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 206 / 11 KV ABHAR PHATA  
INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.131	3.1687	3.0933	3.1121	3.1121	3.0556	3.0178
2	3.0933		3.0933	3.1121	3.2065		2.9801
3	3.0933		3.0556	3.0178	3.1121	3.0933	2.9801
4	3.0933		3.0556	3.0178	3.0178		2.9801
5	3.0933		3.0556	3.1121	3.0178		3.0178
6	3.1121		3.0556	3.0178	3.1121		3.0556
7	3.131		3.0556	3.1121	3.1121	3.0556	3.0556
8	3.1687	3.0933	3.0556	3.0178	2.9235	2.9424	3.0556
9	3.1121	3.2065	3.2065		2.7349	3.1121	3.0556
10	3.0556	3.2065	3.1121		2.6406	3.2065	3.0178
11	3.0933	3.2065	3.2065	3.1687	2.6406	3.2065	3.131
12	3.0178	3.1121	3.1121	3.2065	2.452	3.0178	2.7915
13	3.0178	2.9235	3.0178	2.9801		2.8292	2.9047
14	3.131	3.2065	3.3951	3.131	2.3577	3.0178	3.0178
15	3.2065	3.2065	3.3008		2.452	3.2065	3.1687
16	3.0178	3.2065	3.3008	3.2065	2.452	3.2065	2.9801
17	3.1687	3.1687	3.2065	3.1121	2.4143	3.2065	2.8292
18	3.2442	3.0744	3.1121	3.1121	2.3765	3.2442	3.0178
19	3.2065	3.0933	3.1121	3.2065		3.2065	2.9235
20	3.1687	3.1121	3.0178	3.0178	2.6029	3.131	2.8292
21	1.8861	3.1121	3.2065	3.1687		3.0556	3.0178
22	3.1687	3.1121	3.1121	3.1687	3.0933	3.131	2.9801
23	3.131	3.0933	3.2065	3.2065		3.2065	3.1687
24	3.1687	3.131	3.1121	3.2065	3.1121	3.0933	3.0556
Max	3.2442	3.2065	3.3951	3.2065	3.2065	3.2442	3.1687
Min	1.8861	2.9235	3.0178	2.9801	2.3577	2.8292	2.7915
Avg	3.0713	3.1352	3.1357	3.1148	2.7971	3.1112	3.0013

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 207 / 11 KV SONAR MALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8048				.8907	.7377	.8048
2	.9389				.9393	.8718	.8718
3	.9389				.9717	.8718	.8718
4	.9389				.9717	.9724	.8718
5	.9602				.9717	1.0395	.8718
6	.9724				1.0526	1.0395	.9054
7	1.0059				1.0526	1.0395	.9724
8	1.0395				1.1336	1.073	1.0562
9	1.0059				1.1336	1.0526	1.0562
10	.9724				1.1336	1.1174	1.0562
11		1.2967	1.5384	1.643			
12		1.3441	1.6194	1.643			
13		1.4746	1.5384	1.6598			
14		1.5384	1.6194	1.6933			
15		1.5384	1.6194	1.6095			
16			1.6194	1.5424			
17		1.6095	1.587	1.3765			
18		1.6095	1.4899	1.2955			
Max	1.0395	1.6095	1.6194	1.6933	1.1336	1.1174	1.0562
Min	.8048	1.2967	1.4899	1.2955	.8907	.7377	.8048
Avg	.9578	1.4873	1.5789	1.5579	1.0251	.9815	.9338

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 208 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3123	1.278	1.1203	1.1203	1.2146	.6882	1.1523
2	1.2803		1.1203	1.0402	1.1336	.7209	1.1203
3	1.2483		1.0883	1.0402	1.166		1.1203
4	1.2003		1.0883	1.0402	1.1822		1.0883
5	1.2003		1.0883	1.0402	1.1336		1.0883
6	1.2003		1.1043	1.085	1.166		1.1043
7	1.2003		1.1203	1.1203	1.1336	.8848	1.1203
8	1.2003	1.4091	1.1523	1.186	1.1336	.9831	1.1363
9	1.3123	1.406	1.3765		.9717	1.186	1.278
10	1.4243	1.406	1.3765		.9393	1.2651	1.4091
11	1.4575	1.406	1.4575	1.4091	.9393	1.4232	1.4419
12	1.3603	1.2651	1.2955	1.2125	.8097	1.2651	1.2125
13	1.0688	.9488	1.1012	1.1142		.9488	1.0159
14	1.3123	1.1523	1.2955	1.2452	.4858	1.2003	1.2452
15	1.3763	1.2955	1.3765		.4858	1.2967	1.3763
16	1.4243	1.3603	1.4575	1.3435	.5344	1.3279	1.3763
17	1.4746	1.2803	1.4232	1.3765		1.3763	1.3603
18	1.4746	1.2323	1.3441	1.3765	.4096	1.3923	1.3765
19	1.4091	1.2323	1.3441	1.3765		1.3603	1.3279
20	1.3435	1.2003	1.2651	1.4575	.5243	1.3443	1.2955
21	1.3763	1.2003	1.3125	1.3765		1.3123	1.3279
22	1.3763	1.2003	1.2334	1.2955	.7865	1.2803	1.2955
23	1.3108	1.2003	1.2003	1.2146		1.2163	1.2955
24	1.3443	1.3108	1.1523	1.2483	1.2955	.6882	1.1843
Max	1.4746	1.4091	1.4575	1.4575	1.2955	1.4232	1.4419
Min	1.0688	.9488	1.0883	1.0402	.4096	.6882	1.0159
Avg	1.3203	1.2658	1.2456	1.2247	.9182	1.1580	1.2395



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 209 / 11 KV JAIHIND FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.7167	.5658	.6979	.7167	.679	.679
2	.7167		.5658	.6979	.6979		.679
3	.679		.5281	.679	.6979		.6413
4	.679		.5281	.679	.679		.6413
5	.679		.5281	.679	.6602		.6413
6	.679		.5658	.679	.6602		.679
7	.679		.6036	.6979	.6602	.679	.679
8	.679	.679	.679	.6602	.7545	.6413	.679
9	.7545	.6979	.7545		.6602	.6979	.7167
10	.7922	.6979	.7545		.6413	.7167	.7167
11	.7922	.679	.7922	.7922	.6413	.7356	.7545
12	.7167	.6413	.7545	.6036	.6036	.679	.6413
13	.6413	.5658	.6602	.679		.6036	.679
14	.7167	.6224	.7545	.7167	.6413	.6602	.7167
15	.7545	.6413	.7545		.6413	.7545	.7545
16	.7922	.6036	.7922		.6036	.7733	.7545
17	.7922	.6036	.7733	.7545	.6413	.7545	.7167
18	.7545	.6036	.7545	.679	.6413	.7545	.7545
19	.7167	.6036	.7545	.7545		.7545	.7545
20	.679	.5658	.6979	.7922	.6036	.7167	.7545
21	.7167	.6036	.6979	.7545		.7167	.7545
22	.7545	.6036	.6979	.7545	.679	.7167	.7167
23	.7167	.6413	.679	.7545		.7167	.7167
24	.7167	.7167	.6036	.7356	.7545	.679	.679
Max	.7922	.7167	.7922	.7922	.7545	.7733	.7545
Min	.6413	.5658	.5281	.6036	.6036	.6036	.6413
Avg	.7214	.6382	.6767	.7120	.6639	.7068	.7042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 201 / 11KV TELEPHONE EXCHANGE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1524	.1307		.1334	.1334	.1307
2	.1143	.1334	.1307		.1143	.1334	.1307
3	.1143	.1334	.1307		.1143	.1143	.1307
4	.1143	.1334	.1307		.1143	.1143	.1307
5	.1334	.1524	.1307		.1143	.1143	.1494
6	.1334	.1715	.1494		.1334	.1334	.168
7	.1334	.1905			.1524	.1524	.168
8	.1334	.1334			.1524	.1715	.168
9	.1524	.1715			.1524	.1494	.1715
10	.1715	.168	.1905	.1905	.1715	.1494	.1905
11	.1905	.168	.2096	.1905	.1524	.1494	.1905
12	.1715	.1867	.1905	.1715	.1524	.168	.1715
13	.1524	.1867	.1715	.1715	.1715	.168	.1715
14	.1715	.1867	.1715	.1524	.1905	.168	.1715
15	.1715	.1867	.1905	.1905	.1905	.168	.1524
16	.1524	.1867	.1905	.1905	.1905	.1869	.1524
17	.1715	.1867	.1715	.1715	.1715	.1867	.1715
18	.1905	.1867	.1715	.1715	.1905	.1829	.1905
19	.1905	.1867	.1905	.1715	.2096	.1867	.1524
20	.1715	.1867	.1715	.1524	.1715	.168	.1524
21	.1524	.168	.1715	.1524		.168	.1524
22	.1524	.168	.1715	.1524	.1715	.1646	.1524
23	.1524	.1494	.1524	.1524	.1524	.1494	.1524
24	.1334	.1334	.1494		.1524	.1334	.1494
Max	.1905	.1905	.2096	.1905	.2096	.1869	.1905
Min	.1143	.1334	.1307	.1524	.1143	.1143	.1307
Avg	.1516	.1670	.1651	.1701	.1574	.1547	.1592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 202 / 11 KV KHOTWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.7095	.7682		.7095	.7842	.8048
2	.6535	.6722	.695		.6722	.7468	.7682
3	.6348	.6348	.6584		.6722	.7095	.695
4	.6348	.7095	.6584		.6722	.6722	.7316
5	.6348	.7468	.7316		.7095	.6348	.8048
6	.6535	.7842	.8413		.7468	.6722	.8413
7	.6722	.8215			.7842	.7468	
8	.6722	.8962			.7468	.8215	
9	.8589	.8962			.8215	.9145	.9526
10	1.0082	.9877	1.0082	1.0456	.7468	1.0242	1.0669
11	.9709	1.0608	1.0669	1.0829	.8215	1.1157	1.1812
12	.9709	.9145	1.0288	1.0082	.7095	.9877	1.105
13	.8962	.8779	1.0479	.8215	.6722	.8962	1.0669
14	.7468	1.0082	1.0669	.8589	.6348	.9145	.9907
15	1.0082	1.0059	1.0829	.8589	.6722	.9877	1.0669
16	.9709	.9877	1.0288	.9709	.6722	1.0059	1.0479
17	1.0082	.9511	.9907	.9709	.6535	.9511	1.0098
18	1.0082	.9877	.9526	.9335	.6348	1.0059	1.0288
19	1.0082	.9511	1.0288	.8962	.7468	1.0608	.9526
20	.9335	.8779	.9526	.8962	.8962	1.0059	.9907
21	.8589	.9145	.9145	.8589	.7842	1.0608	.9145
22	.8215	.8413	.9526	.8962	.8962	1.0059	.8954
23	.7842	.8779	.8764	.7468	.8589	.9877	.8764
24	.6722	.7468	.8048		.7095	.8215	.8779
Max	1.0082	1.0608	1.0829	1.0829	.8962	1.1157	1.1812
Min	.6348	.6348	.6584	.7468	.6348	.6348	.695
Avg	.8223	.8692	.9122	.9175	.7352	.8973	.9395

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 203 / 11 KV SARITA POLYMER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5818	3.3913	3.3981		3.4294	3.2388	3.1741
2	3.5437	3.3532	3.3234		3.3913	3.2007	3.2114
3	3.5246	3.315	3.2114		3.3722	3.1626	3.1367
4	3.5056	3.3913	3.4355		3.3341	3.1245	3.0994
5	3.4865	3.5246	3.5101		3.3341	3.1626	3.1741
6	3.4675	3.5818			3.315	3.2007	3.2674
7	3.4865	3.677			3.3341	3.2198	3.2556
8	3.3532	3.7151	3.5288		3.2388	3.315	3.1927
9	3.6389	3.7342			2.3243	3.3234	3.3341
10	3.7913	3.6222	3.7723	3.4865	2.1338	3.4355	3.3532
11	3.4865	3.6969	3.7342	3.6961	2.1338	3.6222	3.4294
12	3.7723	3.5101	3.6961	3.5818		3.5475	3.3532
13	3.658	3.2861	3.7151	3.5818		3.4355	3.2388
14	3.6008	3.4355		3.5818	1.7147	3.5101	3.5627
15	3.7913	3.5848	3.7342	3.4675	1.7147	3.5848	3.5437
16	3.5818	3.5662	3.658	3.5246	1.7337	3.4728	3.4294
17	3.6199	3.5475	3.6199	3.5056	1.7147	3.4168	3.5056
18	3.6389	3.6969	3.5437	3.5437	1.6766	3.4541	3.5627
19	3.8104	3.7529	3.5818	3.7151	1.6956	3.2487	3.4294
20	3.6199	3.5475	3.5437	3.4865	1.8099	3.1367	3.3532
21	3.4675	3.6595	3.5627	3.4484	3.3341	3.3421	3.3913
22	3.4294	3.5848	3.3532	3.4294	3.3913	3.2487	3.3532
23	3.4865	3.5698		3.4865	3.3532	3.1367	3.4294
24	3.6199	3.4294	3.5101		3.4484	3.2579	3.1927
Max	3.8104	3.7529	3.7723	3.7151	3.4484	3.6222	3.5627
Min	3.3532	3.2861	3.2114	3.4294	1.6766	3.1245	3.0994
Avg	3.5818	3.5489	3.5491	3.5382	2.6785	3.3249	3.3322

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 204 / RENUKANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.19	2.1719	1.4815		1.8099	1.8099	1.7558
2	2.1719	2.1357	1.3535		1.8099	1.7737	1.6095
3	2.1357	2.0995	1.419		1.7737	1.7375	1.5364
4	2.0814	2.0633	1.4266		1.7375	1.7013	1.6095
5	2.0452	1.9909	1.4815		1.7013	1.6651	1.6644
6	2.0271	1.9547	1.5364		1.6651	1.7013	1.6827
7	2.0271	1.8823			1.6651	1.7375	1.9387
8	1.9547	1.7737			1.7375	1.7737	2.0485
9	2.3891	1.8823			1.8823	2.1948	2.21
10	2.5339	1.9204	2.2862	2.2443	1.9547	2.2862	2.2862
11	2.4615	1.9753	2.3624	2.3167	1.9547	2.2314	2.2862
12	2.2443	1.7558	2.2862	2.0995		2.0911	2.3243
13	2.1357	1.6827	2.3243	1.9909		1.9753	2.2862
14	2.0271	1.7558	2.3624	1.9547	1.7375	2.1216	2.1338
15	2.2262	1.8473	2.3624	2.0271	1.8823	2.2314	2.1338
16	2.1719	1.7924	2.2862	2.0271	1.8823	2.1582	2.1719
17	2.2443	1.6827		1.9547	1.8642	2.1948	2.21
18	2.2443	1.6461	2.2862	1.8823	1.8823	2.2314	2.2862
19	2.2443	1.4632	2.3624	1.8099	1.8823	2.0485	2.1216
20	2.2081	1.4632	2.2481	1.8099	1.8099	1.8473	2.2481
21		1.6057	2.1338	1.8099	1.8823	1.9418	2.2032
22	1.9909	1.6095	2.1719	1.8099	1.9185	1.8473	2.2405
23	2.2443	1.5546	2.1338	1.8823	1.8461	1.9204	2.0911
24	2.2443	2.2081	1.5546		1.8461	1.8642	1.8656
Max	2.5339	2.2081	2.3624	2.3167	1.9547	2.2862	2.3243
Min	1.9547	1.4632	1.3535	1.8099	1.6651	1.6651	1.5364
Avg	2.1845	1.8299	1.9930	1.9728	1.8239	1.9619	2.0393

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 205 / 11 KV Sanmati Vg Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4815	1.1706	1.4998		1.7924	1.39	1.8107
2	1.4632	1.134	1.4083		1.7558	1.3535	1.7193
3	1.4632	1.0974	1.3535		1.7558	1.3169	1.6827
4	1.4449	1.1706	1.5123		1.6827	1.2803	1.7375
5	1.4449	1.2071	1.5729		1.6461	1.3535	1.7558
6	1.4266	1.2437	1.6278		1.6095	1.4266	1.8092
7	1.4266	1.3169			1.4632	1.4998	1.8473
8	1.4449	1.39			1.4449	1.5729	1.6461
9	1.7193	1.8473			1.2803	2.0302	1.9052
10	1.7558	1.9387	2.2481	2.1582	1.2254	2.1216	2.0165
11		1.9753	2.4006	2.2497	1.2071	2.0851	2.1813
12	1.6461	1.8656	2.2862	2.0851	1.0242	1.8473	2.1338
13	1.5729	1.7193	2.3624	2.0485	.9877	1.9753	2.0957
14	1.5364	1.8107	2.2862	1.8473	.8962	2.0119	1.9433
15	1.8107	1.9204	2.3434	2.1765	1.0059	2.0119	2.0957
16	1.7924	1.8656	2.2862	2.1399	.9877	2.0485	2.1719
17	1.8107	1.829	2.21	1.957	.9694	2.0302	2.2862
18	1.6461	1.8656	2.2481	1.957	.9145	2.0119	2.3243
19	1.262	1.7741	2.1719	1.9753	1.1157	1.9753	
20	1.2437	1.5364	2.1338	1.6278	1.2803	1.9204	2.0576
21	1.262	1.6827	2.0957	1.9753	1.4998	2.0851	2.0485
22	1.2071	1.6461	2.1338	1.9753	1.5364	2.0302	2.0576
23	1.2437	1.5364	2.0957	1.8656	1.4632	1.9136	1.9052
24	1.5181	1.2071	1.5546		1.8473	1.4266	1.8656
Max	1.8107	1.9753	2.4006	2.2497	1.8473	2.1216	2.3243
Min	1.2071	1.0974	1.3535	1.6278	.8962	1.2803	1.6461
Avg	1.5053	1.5729	1.9920	2.0028	1.3496	1.7799	1.9607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 206 / 11 KV SARADA FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18
HR	Load (MW)
1	2.8197
2	2.7816
3	2.7816
4	2.7625
5	2.7625
6	2.7816
7	2.8006
8	2.7054
9	2.934
10	2.9721
11	3.0102
12	2.934
13	2.8578
14	2.8959
15	3.0483
24	2.8197
Max	3.0483
Min	2.7054
Avg	2.8542

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 207 / 11 KV MANAPASANT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18
HR	Load (MW)
1	2.0957
2	2.0957
3	2.0576
4	2.0576
5	2.0576
6	2.0767
7	2.0767
8	2.0195
9	2.2862
10	2.1719
11	2.21
12	2.3624
24	2.1338
Max	2.3624
Min	2.0195
Avg	2.1309



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 406 / 33 KV INDUSTRIAL FEEDER

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	1.3889	1.8004	1.2346	2.6749	.463	1.749
2	1.8004	1.2346	1.8004	1.1317	1.9547	.463	1.6461
3	1.9547	1.2346	2.0576	1.6461	2.4691	.463	1.4403
4	2.0062	1.1831	2.0576	1.749	2.572	.463	2.3148
5	2.3148	1.2346	1.9547	1.4403	2.5206	.463	1.749
6	2.5206	1.286	1.9547	1.749	2.6749	.5658	2.3663
7	1.3375	1.2346	1.8519	1.3375	2.6749	.5658	2.6749
8	2.6235	.7716	2.2119	1.8519	2.572	.8745	1.2346
9	.8745	1.3375	1.8519	1.3375	1.749	1.4918	.9259
10	1.1317	1.1831	1.3889	1.9033	.463	1.3375	1.1317
11	1.8004	.8745	1.1317	1.286	.4115	1.2346	1.2346
12	1.9547	1.3375	.4115	1.1317	.4115	1.749	1.3375
13	1.1317	1.286	.7716	1.1317	.463	1.5947	1.749
14	1.6461	.823	1.0802	2.572	.463		1.8004
15	1.9547	.6687	1.8519	2.1605	.463	1.286	1.8519
16	1.9547	1.3889	1.3889	1.9033	.463	1.2346	
17	1.5432	1.2346	1.1317	2.572	.463	1.749	1.749
18	1.749	1.3375	1.2346	2.572	.463	.3601	1.1831
19	.8745	.3601	1.8004	.8745	.463	1.8519	1.8004
20	.4115	.8745	1.749	1.2346	.463	1.3375	1.2346
21	1.8004	1.3375	1.3375	2.1091	.463	2.0062	1.8519
22	1.1831	2.0062	1.2346	2.0062	.463	2.3663	2.0062
23	1.3375	2.1091	1.749	2.572	.463	2.6235	2.5206
24	2.4177	1.4403	1.9033	1.8004	2.5206	.463	2.3663
Max	2.6235	2.1091	2.2119	2.572	2.6749	2.6235	2.6749
Min	.4115	.3601	.4115	.8745	.4115	.3601	.9259
Avg	1.6825	1.2153	1.5711	1.7211	1.2817	1.1742	1.7356

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 202 / 11 KV ABDUL LAT GOVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0412	.0396	.0572	.06	.032	.06	.0572
2	.0381	.0396	.0457	.0543	.029	.0543	.048
3	.0305	.0412	.0524	.0412	.032	.0412	.0442
4	.0305	.0533	.0553	.0448	.0305	.0448	.0412
5	.0429	.0663	.0629	.0429	.04	.0358	.0457
6	.0412	.0686	.0674	.0537	.0391	.0381	.0524
7	.0543	.0709	.0777	.0617	.0549	.0581	.0924
8	.0934	.0762	.0465	.064	.0671	.0714	.0541
9	.1494	.1052	.1132	.1294	.1017	.1075	.1132
10	.1772	.1029	.1494	.1829	.1509		.1433
11	.2149	.2075	.1509	.1509	.1867	.1886	.2126
12	.1886	.2054	.1886	.1494	.1698	.1478	.7163
13		.1848	.1509	.1494	.132		.5144
14		.1478	.7575	.1509	.112		.1867
15		.1886	.7255	.0937	.1132		.1867
16			.0579	.1509	.1509		.1494
17		.0781	.1219	.112	.1509		.1848
18	.1029	.0869	.0781	.0739	.0701		.1402
19	.0914	.0606	.0648	.5933	.081	.072	.1029
20	.0686	.048	.0743	.4908	.0537	.0629	.0876
21	.0926	.0892	.0789	.0709	.048	.0686	.0591
22		.08	.088	.0686	.0457	.0772	.0553
23		.0629	.0734	.0524	.0434	.0892	.0533
24	.0389	.0524	.0686	.0667	.0438	.0419	.0629
Max	.2149	.2075	.7575	.5933	.1867	.1886	.7163
Min	.0305	.0396	.0457	.0412	.029	.0358	.0412
Avg	.0880	.0937	.1420	.1295	.0824	.0741	.1418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 204 / 11 KV GANGOBA MANDIR

GAOTHAN FEEDER

GOVTHAN Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3841	.3681	.3439	.4557	.4287	.4557	.4578
2	.3761	.3429	.3155	.4525	.3856	.4525	.463
3	.3801	.3681	.3155	.4252	.3605	.4252	.4508
4	.362	.394	.285	.4031	.3749	.4075	.4382
5	.362	.4024	.3174	.4207	.3944	.3856	.4854
6	.3841	.4207	.4066	.4287	.4298	.4207	.5144
7	.4784	.5014	.4908	.4748	.5201	.4908	.5658
8	.4917	.5068	.4458	.5304	.5144	.4908	.5765
9	.5182	.4557	.6009	.6226	.6241	.5693	.6401
10	.5693	.4458	.5937	.6325	.6588	.6325	.6226
11	.5506	.4207	.6371	.6226	.583	.6325	.6401
12	.4915	.4409	.5609	.5506	.4588	.5535	.5376
13		.4382	.5144	.3978	.4024		.4801
14		.3801	.5487	.5426	.503		.5243
15		.4458	.6036	.583	.5121		.6226
16			.6371	.6081	.5376		.7042
17		.4527	.7011	.506	.506		.6562
18	.583	.431	.6661	.5624	.4843		.7042
19	.5487	.4805	.6344	.5761	.5373	.5304	.6642
20	.4961	.4527	.631	.6036	.5316	.5087	.6836
21	.5014	.4435	.5765	.5365	.5548	.6859	.6539
22		.4481	.5609	.4915	.5609	.6241	.6371
23		.3734	.4801	.4801	.4854	.5256	.547
24	.3982	.4108	.3361	.4733	.4508	.4161	.4694
Max	.583	.5068	.7011	.6325	.6588	.6859	.7042
Min	.362	.3429	.285	.3978	.3605	.3856	.4382
Avg	.4633	.4271	.5085	.5159	.4916	.5115	.5725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 205 / 11 KV INDIRA NAGAR GOVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2218	.1753	.1698	.4115	.381	.4115	.4144
2	.2054	.1543	.1372	.4031	.3932	.4031	.39
3	.1886	.1372	.1341	.4031	.3812	.39	.3944
4	.1886	.1753	.125	.3688	.3601	.3772	.3641
5	.1886		.1494	.3856	.3856	.373	.4161
6	.2263	.1753	.1867	.4161	.3814	.4409	.4908
7	.2241	.2263	.2241	.4287	.4854	.3898	.4854
8	.2926	.3018	.2401	.4024	.4915	.4641	.5596
9	.4024	.3506	.5182	.506	.5441	.6081	.6154
10	.4525	.3155	.6036	.5376	.4999	.663	.6036
11	.5201	.4207	.583	.5312	.5506	.578	.7122
12	.3467	.3326	.503	.4858	.3688	.4752	
13	.3506	.3547	.3437	.3506	.3222		
14	.3898	.2949		.4801	.5182		.6036
15	.4207	.3547		.5556	.4586		.6443
16	.3814		.4961	.4801	.5376		.6935
17	.3856	.3077	.6226	.5182	.5376		.6154
18	.4607	.2896	.5761	.5487	.5247		.6706
19	.3544	.3395	.5535	.4999	.4973	.3395	.6401
20	.2454	.1894	.5228	.4268	.4252	.4066	.5138
21	.2401	.2058	.5365	.4687	.5087	.5487	.5487
22	.2058	.2033	.5365	.4572	.4748	.5144	.5087
23	.2103	.1886	.4586	.3841	.3978	.4696	.4801
24	.2427	.1715	.168	.4578	.4062	.4144	.426
Max	.5201	.4207	.6226	.5556	.5506	.663	.7122
Min	.1886	.1372	.125	.3506	.3222	.3395	.3641
Avg	.3061	.2575	.3813	.4545	.4513	.4593	.5359

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 201 / 11KV TAKWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4694	.5801	.2896	.5898	.5304	.5898	.5304
2	.57	.5801	.2926	.5898	.5304	.5898	.499
3	.6036	.5636	.2686	.5571	.5304	.5571	.4641
4	.6036	.5636	.2507	.5571	.5304	.5571	.5138
5	.57	.5636	.2865	.5898	.5304	.5243	.5138
6	.6036	.5636	.4525	.5898	.5304	.5243	.5304
7	.6539	.6133	.543	.5735	.6299	.6554	.6464
8	.6874	.4475	.543	.639	.6299	.6882	.663
9	.7712	.4641	.7682	.7701	.779	.7537	.8288
10	.7712	.4807	.7202	.7701	.7293	.7373	
11	.7459	.4973	.7811	.7537	.7956	.5243	.8288
12	.7625	.4807	.7537	.7537	.7373	.7537	.7459
13	.547	.4382	.6554	.6464	.6554	.6299	.6539
14	.663	.4706	.639	.5801	.6062	.6796	.6371
15	.7459	.5487	.7537	.7459	.7865	.7537	.7712
16	.7625	.4835	.7701	.7625	.7537	.8288	.8048
17	.779	.4163	.7373	.7459	.7045	.7537	.788
18	.7625	.4435	.7865	.779	.7373	.7625	.7712
19	.663	.3292	.7865	.7459	.7209	.6802	.8048
20	.6299	.3109	.7373	.6796	.6796	.6401	.7042
21	.6796	.3224	.6718	.7293	.639	.6882	.7545
22	.663	.3258	.6554	.6962	.6062	.663	.6706
23	.6464	.3258	.5898	.6299	.5898	.6796	.6706
24	.6706	.6133	.296	.6062	.5967	.6226	.5967
Max	.779	.6133	.7865	.779	.7956	.8288	.8288
Min	.4694	.3109	.2507	.5571	.5304	.5243	.4641
Avg	.6677	.4761	.5845	.6700	.6483	.6599	.6692

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 202 / 11 KV PATIL MALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9878	1.1934	.4801	1.1603	1.0774	1.1934	1.0437
2	1.0688	1.1271	.4428	1.1271	1.0277	1.1603	1.0402
3	1.085	1.0774	.4428	1.0608	1.0277	1.1271	1.0242
4	1.0364	1.0774	.4428	1.0608	.9614	1.1271	.9762
5	.9717	1.0277		1.0277	.9282	1.0608	.9602
6	1.004	.9945	.5376	1.0277	.8951	1.0277	.9488
7	1.0688	1.0277	.6009	1.1271	1.1271	1.094	1.1702
8	1.1174	.8453	.6958	1.1603	1.1271	1.094	1.1271
9	1.4089	.7293	1.2651	1.3923	1.3923	1.3923	1.4255
10	1.3765	.7625	1.4232	1.326	1.3426	1.3923	1.4586
11	1.3923	.663	1.3283	1.4586	1.326	1.4586	1.4255
12	1.2929	.663	1.1934	1.2929	1.278	1.3592	1.3923
13	.9945	.4902	.9614		.8619	.8381	.9231
14	1.1603	.4801	1.094	1.1271	1.1271	.9804	1.0688
15	1.3923	.5281	1.3094		1.4255	1.2967	1.3279
16	1.3923	.4902	1.326	1.3592	1.3923	1.3599	1.4089
17	1.326	.506	1.1934	1.3923	1.3592	1.3443	1.3603
18	1.326	.4961	1.326	1.3592	1.2929	1.3283	1.3441
19	1.4255	.5761	1.3923	1.4586	1.4586	1.4243	1.4251
20	1.326	.6356	.8951	1.326	1.2929	1.2803	1.3279
21	1.3592	.6401	1.326	1.3592	1.3592	1.3283	1.3441
22	1.2929	.6401	1.1934	1.2929	1.326	1.2334	1.2955
23	1.326	.5376	1.1934	1.21	1.2597	1.2334	1.3279
24	1.166	1.2597	.4801	1.1934	1.1603	1.2266	1.1069
Max	1.4255	1.2597	1.4232	1.4586	1.4586	1.4586	1.4586
Min	.9717	.4801	.4428	1.0277	.8619	.8381	.9231
Avg	1.2207	.7695	.9801	1.2409	1.2011	1.2234	1.2189

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.6575	1.3817	1.6244	1.5746	1.6575	.7522
2	1.6289	1.6575	1.3957	1.5912	1.5746	1.6244	.7164
3	1.6651	1.6766	1.307	1.5912	1.5746	1.5912	.6516
4	1.6651	1.6766	1.2696	1.5581	1.5746	1.5912	.6516
5	1.5746	1.643	1.358	1.5581	1.5581	1.6244	.7202
6	1.7013	1.643	1.6804	1.5249	1.5581	1.6244	.823
7	2.1176	1.9616	1.7918	1.8233	1.8107	1.8564	1.0517
8	2.3034	1.6244	1.9993	1.9559	1.8442	1.989	1.0395
9	2.4966		2.4006	2.3205	2.1879	2.2874	1.1401
10	2.5549		2.5034	2.0222	2.1879	2.2542	1.2071
11	2.2874	1.8233	2.4691	2.0222	1.6575	2.2211	1.2574
12	2.1795	1.7101	2.3868	2.1548	2.0553	2.1216	1.1736
13	1.9559	1.7924	1.9227	1.7101	1.8896	1.8755	.852
14	1.8067	1.5893	1.8896	1.6766	2.0222	1.9033	.9503
15	2.2466	1.8296	1.6907	1.8945	2.1548	2.1033	1.0202
16	2.2377	1.1203	1.989	2.1216	2.0885	2.4714	1.166
17	2.2708		1.9559	1.7901	2.1216	2.3838	1.1174
18	2.2542		2.1879	2.0553	2.2542	1.2308	1.1498
19	2.4478	2.0165	2.1216	2.2542	2.3537	1.1203	1.2631
20	2.2542	1.9404	1.9227	2.0454	2.1879	1.0277	.9717
21	2.3205	1.848	2.0885	2.1216	2.1879	1.094	1.1012
22	2.2801	1.6804	1.9227	1.9062	2.1051	1.0059	1.004
23	1.9616	1.5684	1.7901	1.8564	1.8564	.9448	.9231
24	1.8267	1.7772	1.4563	1.6907	1.6907	1.6907	.8063
Max	2.5549	2.0165	2.5034	2.3205	2.3537	2.4714	1.2631
Min	1.5746	1.1203	1.2696	1.5249	1.5581	.9448	.6516
Avg	2.0694	1.7118	1.8700	1.8696	1.9196	1.7206	.9796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 205 / BALIRAJA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.3932	.4915	.4144	.3277	
2			.3932	.5243	.4144	.3605	
3			.4096	.4588	.4144	.3605	
4			.3768	.426	.4144	.3277	
5			.426	.4915	.431	.3932	
6			.4588	.5243	.4641	.3932	
7			.5243	.639	.5636	.4752	
8			.6062	.6554	.6299	.5571	
9			.6478	.6718	.6796	.6226	
10		.8288	.6478	.6882	.663	.7537	
11	.8619					.8029	.7377
12	.9282					.8848	.8619
13	.9282					.9012	.9393
14	.9282					.8848	.9069
15	.9282					.7449	.8907
16	.9116					.8785	.8745
17	.8785					.8848	.9231
18	.7956					.8192	.8745
20						.1372	
Max	.9282	.8288	.6478	.6882	.6796	.9012	.9393
Min	.7956	.8288	.3768	.426	.4144	.1372	.7377
Avg	.8951	.8288	.4884	.5571	.5089	.6058	.8761



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 201 / TAMBE MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.3717	.503	1.2003	1.3032	1.1728	1.3375
2	1.3717	1.2346	.503	1.2003	1.3032	1.1728	1.3032
3	1.3717		.5365		1.3032	1.1728	1.2689
4	1.3717	1.166	.503	1.2003	1.3032	1.1728	1.2689
5	1.3375	1.0288	.5365	1.2003	1.3032	1.1728	1.2689
6	1.3375	1.1145	.503	1.2003	1.406	1.1728	1.2689
7	1.3717	1.1317	.5365	1.2003	1.406	1.3117	1.3375
8	1.3889	1.166	.9389	1.2174	1.5775	1.2963	1.4403
9	1.5415	1.166	1.4419	1.6632	1.5775	1.4815	
10	1.5238	1.166	1.5089	1.6632	1.5775	1.358	
11	1.4091	1.166	1.6095	1.6632	1.6804	1.358	
12	1.3108	1.0288	1.3748	1.0631	.9431	1.034	
13	1.3435		.9724	.9488	1.0374		
14	1.3904	.9259	1.291	1.1069	1.2689	1.3375	
15	1.3108	.9602	1.5424	1.2018	1.2689	1.5775	
16	1.278	.8916	1.576	1.2651	1.3032	1.5775	
17	1.1271	.6859	1.5089	1.3916	1.3717	1.5775	
18	1.5074	.6173	1.5424	1.3283	1.2689	1.6461	
19	1.4403	.5487	1.4419	1.3599	1.3032	1.6461	
20	1.4083	.583	1.3748	1.1702	1.3717	1.6289	
21	1.4582	.6001	1.3748	1.3077	1.5844	1.3717	
22	1.3763	.5487	1.3077	1.2742	1.4403	1.3717	
23	1.3763	.5487	1.291	1.2742	1.5278	1.3717	1.4232
24	1.406	1.406	.5365	1.2003	1.3032	1.1728	1.2193
Max	1.5415	1.406	1.6095	1.6632	1.6804	1.6461	1.4403
Min	1.1271	.5487	.503	.9488	.9431	1.034	1.2193
Avg	1.3804	.9571	1.0940	1.2740	1.3639	1.3546	1.3137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 202 / UTTAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.262	1.0974	.9808	1.1488	1.166	1.2269	1.1317
2	1.262	1.0631	1.0185	1.1317	1.166	1.1919	1.1317
3	1.166	1.0288	.9808	1.1317	1.166	1.1919	1.0974
4	1.166	.9602	1.0185	1.0974	1.166	1.1568	1.0631
5	1.1919	.9945	.9808	1.0974	1.166	1.1568	1.0631
6	1.2346	1.0974	.9808	1.1317	1.3032	1.1568	1.0974
7	1.2346	1.166	1.0185	1.1145	1.3032	1.3672	1.0974
8	1.262	1.2689	1.3014	1.1831	1.3717	1.3321	1.3032
9	1.3599	1.2346	1.3957	1.406	1.4403	1.4022	1.5466
10	1.3599	1.2346	1.4335	1.286	1.4403	1.3321	1.406
11	1.278	1.2346	1.5655	1.3717	1.2689	1.3321	1.5089
12	1.2125	1.0288	1.5278	1.1317	1.0974	1.2094	1.5089
13	.9831	1.0288	1.2826	1.086	1.0288		1.1883
14	1.0883	1.0288	1.3392	1.3032	1.307	1.166	1.4335
15	1.1797	1.0288	1.4335	1.3394	1.3032	1.3717	1.5089
16	1.0852	1.0288	1.4335	1.3394	1.3032	1.3717	1.5278
17	.9831	1.0288	1.5089	1.3756	1.5089	1.3717	
18	1.3108	1.0288	1.6032	1.5203	1.406	1.3717	
19	1.278	1.0631	1.773	1.5927	1.406	1.3717	
20	1.278	1.0288	1.6221	1.5203	1.4403	1.3032	
21	1.2452	1.0288	1.6032	1.3756	1.4335	1.2346	
22	1.2452	1.0288	1.4335	1.2308	1.6032	1.2346	
23	1.1142	.9259	1.358	1.2308	1.4523	1.2003	1.286
24	1.3321	1.166	1.0185	1.1488	1.166	1.262	1.307
Max	1.3599	1.2689	1.773	1.5927	1.6032	1.4022	1.5466
Min	.9831	.9259	.9808	1.086	1.0288	1.1568	1.0631
Avg	1.2130	1.0760	1.3172	1.2623	1.3089	1.2746	1.2893

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6505	2.4348	.7888	2.4006	2.4691	2.3205	2.572
2	2.5034	2.3663	.7888	2.3663	2.4691	2.1125	2.5034
3	2.5591	2.2977	.7545	1.7147	2.4691	2.1216	2.4691
4	2.5591	2.1605	.7545	1.8519	2.4691	2.0622	2.7161
5	2.5591	2.0576	.7202	2.0576	2.4691	2.1051	2.6783
6	2.4863	1.989	.7545	2.1776	2.4691	2.1382	2.6783
7	2.5968	1.9204	1.0288	2.2119	2.4691	2.2708	2.5034
8	2.4863	1.8519	1.6461	2.4006	2.6063	2.1714	2.7538
9	2.6543	1.749	2.7435	2.8464	2.7435	2.1216	3.1121
10	2.6543	1.6804	2.915	2.6578	2.7435	2.7183	3.131
11	2.6216	1.6461	2.7778	2.7435	2.8292	2.7183	3.0556
12	2.5888	1.4746	2.5377	2.4006	1.7147	1.7238	2.6029
13	2.4577	.9602	1.4746	1.5813	1.6461		1.7918
14	2.5724	1.3032	2.572	2.1506	2.4006	2.5034	2.9801
15	2.5232	1.3717	2.6578	2.3087	2.4348	2.8807	3.0367
16	2.4577	1.2003	2.7778	2.2771	2.4691	2.8807	3.131
17	2.2939	.7888	2.572	2.4669	2.5034	2.8807	
18	2.5232	.7545	2.692	2.3403	2.4348	2.8807	
19	2.556	.6859	2.9235	2.2455	2.6406	2.8807	
20	2.556	.6859	2.452	2.2455	2.4006	2.7778	
21	2.5232	.6859	2.4863	2.3087	2.6063	2.6063	
22	2.4905	.823	2.4006	2.2138	2.572	2.6406	
23	2.4249	.7888	2.4348	2.2771	2.5034	2.6406	2.6406
24	2.6505	2.5034	.7888	2.4348	2.4691	2.3703	2.6406
Max	2.6543	2.5034	2.9235	2.8464	2.8292	2.8807	3.131
Min	2.2939	.6859	.7202	1.5813	1.6461	1.7238	1.7918
Avg	2.5395	1.5075	1.9351	2.2783	2.4584	2.4577	2.7220

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 204 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0233	1.989	.8573	1.8861	2.0576	1.989	1.989
2	1.989	1.9204	.823	1.8861	2.0576	1.9559	1.989
3	1.989	1.8861	.7888	1.8519	2.0576	1.8233	1.9547
4	1.9547	1.8176	.823	1.7147	2.0576	1.8233	1.9547
5	1.9547	2.1262	.7888	1.8004	2.0576	1.8564	1.9204
6	1.9204	2.332	.7888	1.8861	2.0576	1.8896	1.9547
7	1.989	2.6063	.9602	2.0062	2.0576	1.9227	2.0405
8	2.0233	2.572	1.5775	2.0062	2.1948	1.989	2.2634
9	2.2611	2.0576	2.1605	2.3663	2.2634	2.1879	2.5274
10	2.34	1.166	2.2291	2.2634	2.2634	2.1216	2.5274
11	2.1956	1.166	2.4006	2.2634	2.2977	2.1216	2.584
12	2.13	1.0288	2.0233	1.8861	1.6461	1.4255	1.9427
13	2.0317	.8573	1.3717	1.5939	1.5947		1.6221
14	2.13	1.0288	2.1091	2.0348	1.9547	2.2291	2.3388
15	2.0972	1.0631	2.2462	2.0348	1.989	2.1948	2.5274
16	2.0645	.9602	2.1948	2.0687	2.0576	2.1948	2.4143
17	1.9662	.6859	2.0919	2.1026	2.0576	2.2634	
18	2.1956	.6859	2.2977	2.1026	2.0919	2.2634	
19	2.1628	.6859	2.1948	2.1026	2.1262	2.2634	
20	2.2382	.6859	2.1091	2.1026	2.3765	2.2977	
21	2.13	.6859	2.1262	2.0687	2.0919	2.2977	
22	2.0972	.8916	2.1262	2.0687	2.0919	2.0405	
23	2.0645	.8573	2.1262	2.0348	2.1948	2.0576	2.1948
24	2.1491	2.0576	.8573	2.0576	2.0576	2.0719	2.0576
Max	2.34	2.6063	2.4006	2.3663	2.3765	2.2977	2.584
Min	1.9204	.6859	.7888	1.5939	1.5947	1.4255	1.6221
Avg	2.0874	1.4089	1.6697	2.0079	2.0730	2.0557	2.1557

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 205 / DKTE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
1		.9709
2		.8573
3		.8573
4		.823
5		.823
6		.8916
7		.9259
8		.9602
17	.7545	
18	1.2346	
19	1.2346	
21	1.0288	
22	1.0288	
23	.9602	1.046
24		1.0082
<b>Max</b>	<b>1.2346</b>	<b>1.046</b>
<b>Min</b>	<b>.7545</b>	<b>.823</b>
<b>Avg</b>	<b>1.0403</b>	<b>.9163</b>

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 206 / GAON BHAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.9945	.57	.9602	.8916	.7526	.8535
2	1.2003	.9602	.5365	.9602	.8916	.6923	.8535
3	1.166	.9259	.5365	.9602	.8916	.6923	.823
4	1.166	.8573	.57	.9602	.823	.6622	.7926
5	1.1488	.8916	.5365	.9602	.8916	.7225	.8916
6	1.1488	.8916		.9602	.9602	.7375	.9259
7	1.1488	.9259	.57	.9945	1.0288	.873	.8383
8	1.1488	.9259	.7377	.9945	1.0974	.9181	1.0288
9	1.2125	.8573	.9389	1.1831	1.166	1.0837	
10	1.2125	.6859	1.0059	1.2689	1.166	1.0235	
11	1.1142	.8573	.9389	1.2689	1.0631	1.0536	
12	1.0486	.7888	1.0227	.823	.6173	1.0536	
13	.7865	.5487	.9724	.7362	.6173		
14	.8192	.6859	.9054	.8642		.9259	
15	.7865	.6859	1.0227	.8322		1.0974	
16	.7865	.6173	1.0562	.8642		1.0974	
17	.78	.5487	1.073	.8962		1.0974	
18	.8288	.6859	1.1317	1.0242	1.0974	1.0974	
19	1.0852	.7545	1.2239	1.1401	1.0974	1.0974	
20	1.1191	.7202	1.1401	1.0562	1.1317	1.0631	
21	1.0486	.7202	1.1904	1.0883	1.1317	1.0288	
22	1.0159	.6859	1.0227	.9602	1.0974	1.0288	
23	1.0159	.6173	1.0059	.8962	1.0288	1.0288	1.0288
24	1.2346	1.0288	.6036	.9602	.8916	.8128	.9145
Max	1.2346	1.0288	1.2239	1.2689	1.166	1.0974	1.0288
Min	.78	.5487	.5365	.7362	.6173	.6622	.7926
Avg	1.0524	.7859	.8831	.9839	.9791	.9409	.8951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 207 / 11 KV RAMNAGAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1161	2.8807	2.6406	2.915	2.8807	2.7759	2.915
2	3.0803	2.8464	2.5652	2.9492	2.7435	2.6863	2.7435
3	2.9492	2.8121	2.5652	2.9492	2.7435	2.5789	2.7778
4	2.9492	2.7092	2.5274	2.7435	2.7435	2.5789	2.6749
5	2.915	2.7435	2.5652	2.8464	2.7435	2.5789	2.6749
6	2.9492	2.8121	2.5652	2.8464	2.7435	2.5968	2.6749
7	2.9492	2.8807	2.7161	2.915	2.7435	2.7759	2.7435
8	3.0178	2.915	2.8669	3.0864	2.8807	2.8296	2.915
9	3.4082	3.0864	3.0556	3.4808	2.7435	3.5818	
10	3.2769	3.2579	3.7723	3.4637	2.7435	3.725	
11	3.2114	3.2579	3.9043	3.5322	2.6406	3.725	
12	3.2217	2.7435	3.5837	2.6749		2.7042	
13	2.9492	2.2291	2.584	2.6063			
14	3.1131	2.915	3.6214	2.4253		3.2922	
15	3.1161	3.2579	3.6591	3.1855	2.1879	3.5665	
16	2.9492	3.0864	3.8855	3.3665	2.1879	3.5665	
17	3.3261	2.7435	3.2861	3.4389	2.1262	3.4294	
18	3.2114	2.4006	3.6591	3.5113	2.1605	3.5665	
19	3.1459	1.6461	3.81	3.5475	2.2291	3.5665	
20	3.0803	1.6118	3.4139	3.1855	2.2291	3.0178	
21	3.0803	1.5775	3.5082	3.2579	2.6749	2.9835	
22	3.0148	2.5034	3.4328	3.2579	2.6406	3.0178	
23	2.9492	2.4348	3.4328	3.1855	2.7263	3.0178	3.1722
24	3.1161	2.8635	2.6783	3.0521	2.9492	2.7759	2.9835
Max	3.4082	3.2579	3.9043	3.5475	2.9492	3.725	3.1722
Min	2.915	1.5775	2.5274	2.4253	2.1262	2.5789	2.6749
Avg	3.0873	2.6756	3.1791	3.1010	2.5934	3.0842	2.8275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 208 / 11 KV KRISHI GANGA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1886	.2058	.2058	.2683
2		.2263	.2401	.2058	.2683
3		.2263	.2401	.2058	.2743
4		.3018	.2572	.2058	.2683
5		.3395	.2743	.2058	.3018
6		.3772	.2743	.2743	.3018
7		.415	.3086	.2743	.3155
8		.415	.2915	.2743	.3353
9		.3772	.3258	.2743	.2683
10		.3772	.3429	.2743	.2683
11	.3605				.4908
12	.3932				.4694
13	.426				
14	.426				.3429
15	.4588				.3429
16					.3429
17	.3277				.3429
18	.3932				.3429
23					.2683
24			.1886	.2058	.2683
Max	.4588	.415	.3429	.2743	.4908
Min	.3277	.1886	.1886	.2058	.2683
Avg	.3979	.3244	.2681	.2369	.3201



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 209 / JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.0343	.0377	.0343	.0343	.0373	.0377
2	.1791	.0343	.0377	.0343	.0343	.0373	.0377
3	.1791	.0343	.0377	.0343	.0343	.0373	.0377
4	.1791	.0343	.0377	.0343	.0343	.0373	.0377
5	.1791	.0343	.0377	.0343	.0343	.1867	.0377
6	.1791	.1715	.1886	.1715	.1886	.1867	.1886
7	.1791	.1715	.1886	.1715	.1886	.1867	.2075
8	.1791	.1715	.2075	.1715	.1886	.1867	.2075
9	.1638	.1715	.2075	.1715	.1886	.1867	.2075
10	.1638	.1715	.2075	.1715	.1886	.1867	.2075
11	.1638	.1886	.2075	.1715	.1886	.1867	.2075
12	.1638	.1886	.1886	.1886	.1886	.1867	.1886
13	.1638	.1886	.1886	.2075	.1886		.1886
14	.1802	.1886	.1886	.2075	.2075	.1715	.1886
15	.1802	.1886	.1886	.2075	.2075	.1715	.1886
16	.1802	.1886	.1886	.2075	.2075	.1715	.1886
17	.1823	.1886	.1886	.2075	.2075	.1715	
18	.1802	.1886	.1886	.2075	.2075	.1715	
19	.1638	.1886	.1886	.2075	.2075	.1715	
20	.1802	.1886	.1886	.1844	.1886	.1715	
21	.1638	.1886	.1886	.2075	.2075	.1886	
22	.0328	.1886	.1886	.1844	.1886		
23	.0339	.0686	.0377	.0377	.0377	.1886	.0343
24	.1791	.0343	.0754	.0343	.0343	.0373	.2075
Max	.1823	.1886	.2075	.2075	.2075	.1886	.2075
Min	.0328	.0343	.0377	.0343	.0343	.0373	.0343
Avg	.1629	.1415	.1493	.1454	.1493	.1481	.1444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 210 / AVENUE SUPER MARKET

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0343	.0343	.0343	.0343	.0373	.0343
2		.0343	.0343	.0343	.0343	.0373	.0343
3		.0343	.0343	.0343	.0343	.0373	.0343
4		.0343	.0343	.0343	.0343	.0373	.0343
5		.0343	.0343	.0343	.0343	.0373	.0343
6		.0514	.0343	.0343		.0373	.0343
7		.0686	.0343	.0343	.0343	.0373	.0514
8		.0686	.0514	.0343	.0857	.056	.0514
9		.0857	.0686	.0686	.1029	.1867	
10		.0857	.0857	.1029	.1543	.2241	
11		.0857	.1372	.1029	.1543	.2241	
12		.1029	.12	.1029	.1029	.1867	
13		.1029	.12	.112	.1029		
14		.1029	.12	.112	.1029	.1029	
15		.1029	.1029	.112	.12	.1029	
16		.1715	.12	.1494	.12	.1029	
17	.0819	.1715	.1372	.1867	.1372	.1029	
18	.1475	.1715	.1372	.1867	.1372	.1715	
19	.1311	.1715	.1886	.1867	.1715	.1715	
20	.1147	.1715	.1715	.1867	.1715	.1715	
21	.1017	.1715	.1715	.1867	.1715	.1715	
22	.0655	.0686	.1372	.112	.0754	.1715	
23	.0655	.0686	.0343	.112	.0754	.0514	.0686
24		.0514	.0514	.0343	.0343	.056	.0514
Max	.1475	.1715	.1886	.1867	.1715	.2241	.0686
Min	.0655	.0343	.0343	.0343	.0343	.0373	.0343
Avg	.1011	.0936	.0915	.0970	.0968	.1094	.0429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 211 / NAIKMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.4348	1.2003	2.4006	2.0576	2.5766	2.332
2	2.5377	2.4006	1.166	2.3663	2.0576	2.5393	2.2977
3	2.5034		1.1317	2.332	2.0576	2.2801	2.2634
4	2.4006	2.332	1.1317	2.332	2.0576	2.2634	2.2291
5	2.4006	2.1948	1.166	2.332	2.0576	2.2634	2.2291
6	2.5034	2.2291	1.166	2.332	2.0919	2.2634	2.2634
7	2.5034	2.2634	1.3375	2.332	2.0919	2.2634	2.4006
8	2.5377	2.2977	1.7147	2.4006	2.1262	2.3472	2.4006
9	2.6621	2.2634	2.5034	2.7778	2.1434	2.3472	
10	2.556	2.2291	2.5892	2.6578	2.1434	2.5484	
11	2.4905	2.2634	2.6578	2.7435	2.2291	2.5652	
12	2.3922		2.5034	2.2291	1.8861	2.5819	
13	2.3739	1.2517	1.749	1.8442	1.7147		
14	2.6216	2.0576	2.5206	2.4478	2.0576	2.7435	
15	2.556	2.1605	2.7435	2.5149	2.1262	3.1036	
16	2.4905	1.989	2.6063	2.6155	2.1262	3.1036	
17	2.3205	1.7318	2.7263	2.5484	2.1262	3.0864	
18	2.6189	1.7147	2.7092	2.4478	2.1605	3.1036	
19	2.556	1.5604	2.6235	2.4813	2.1605	2.6578	
20	2.4905	1.5432	2.4348	2.4478	2.2291	2.5034	
21	2.4249	1.4746	2.452	2.4143	2.1948		
22	2.4086	1.4746	2.4177	2.2801	2.3834	2.4348	
23	2.3922	1.2003	2.5206	2.2801	2.4348	2.4006	2.5377
24	2.572	2.4691	1.2003	2.4863	2.2291	2.3137	2.4006
Max	2.6621	2.4691	2.7435	2.7778	2.4348	3.1036	2.5377
Min	2.3205	1.2003	1.1317	1.8442	1.7147	2.2634	2.2291
Avg	2.4952	1.9789	2.0405	2.4185	2.1226	2.5587	2.3354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 212 / MAHADEV NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.3086	.1543	.3429	.3086	.3018	.3772
2	.3086	.3086	.1543	.3429	.3086	.3018	.3353
3	.3086	.2743	.1543	.3429	.3086	.285	.3353
4	.3086	.2743	.1543	.3086	.3086	.2683	.3353
5	.3086	.2915	.1543	.3258	.3086	.285	.3353
6	.3086	.3086	.1543	.3258	.3429	.3018	.3772
7	.3429	.3086	.1715	.3258	.3601	.3185	.3772
8	.3429	.3258	.2401	.3429	.3772	.3353	.3772
9	.4096	.3429	.3772	.4115	.3944	.4024	
10	.4096	.3429	.4287	.4115	.3944	.4024	
11	.3932	.3772	.4115	.4115	.4115	.4024	
12	.3605	.3429	.3429	.4115	.2743	.3688	
13	.3277	.1715	.2743	.3353	.2572		
14	.373	.1715	.3258	.3688	.3772	.3429	
15	.3441	.1715	.3944	.3688	.3772	.3601	
16	.3277	.1886	.4115	.3688	.3772	.3601	
17	.2949	.1886	.3944	.3688	.4287	.3601	
18	.3932	.1886	.3944	.3688	.4115	.3601	
19	.3812	.1886	.4115	.4024	.4115	.3601	
20	.3812	.1715	.3772	.4024	.4115	.3772	
21	.3605	.1715	.3772	.3688	.4115	.3772	
22	.3647	.1715	.3429	.3688	.3601	.3772	
23	.3315	.1715	.3429	.3688	.3429	.3772	.3601
24	.3582	.3429	.1715	.3429	.3429	.3185	.415
Max	.4096	.3772	.4287	.4115	.4287	.4024	.415
Min	.2949	.1715	.1543	.3086	.2572	.2683	.3353
Avg	.3478	.2543	.2965	.3640	.3586	.3454	.3625

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 704 / 33 KV Main VCB TILAWANI SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	13.6717	12.8601	8.1482	12.4486	12.7572	12.252	15.2778
2	13.6717	12.5515	8.035	12.4486	12.3457	12.0416	15.2778
3	13.6717	12.3457	8.035	10.6996	12.3457	11.9365	
4	13.1459	11.6255	7.9218	11.4198	12.3457	11.5684	
5	12.62	11.8827	8.035	11.8313	12.7572	12.0942	
6	13.6717	12.2428	8.1482	12.3457	13.3745	12.252	
7	13.7769	12.7058	9.2798	12.6543	13.3745	13.0407	15.2778
8	14.3027	11.5226	11.6564	13.1173	14.3004	13.1459	16.2397
9	14.8446	12.0371	15.8436	15.3807	14.1976	15.4596	18.2202
10	14.8446	11.3683	16.4095	15.1235	14.1976	15.4596	18.2768
11	14.2056	11.4198	16.5792	15.4321	14.4033	15.4596	18.3899
12	13.714	11.3169	13.9198	11.3169	8.2305	12.7252	15.1646
13	12.7309	8.0247	10.9774	9.0535	7.8189		13.2408
14	14.0089	9.2593	15.0515	14.1976	12.4486	14.6091	16.8622
15	13.5665	10.1338	15.9002	14.7234	13.0144	15.2264	18.3334
16	12.6818	9.2593	16.0134	14.8286	13.5803	15.2264	18.5031
17	12.2885	8.5391	15.8436	14.9337	13.6369	15.2264	
18	14.3039	7.5103	16.2397	14.2844	14.712	15.2264	
19	13.9106	7.5103	16.1266	14.7234	14.8251	16.2037	
20	13.8123	7.4074	15.1646	14.3027	14.9383	15.9465	
21	13.4682	7.8189	15.6173	14.7234	16.1831	14.712	
22	13.3699	8.0761	14.5988	13.9872	14.3159	14.7634	
23	13.1733	7.5103	14.5422	13.4088	14.1461	14.9177	16.2397
24	13.7769	13.3231	8.1482	12.6029	12.6543	12.3571	14.712
Max	14.8446	13.3231	16.5792	15.4321	16.1831	16.2037	18.5031
Min	12.2885	7.4074	7.9218	9.0535	7.8189	11.5684	13.2408
Avg	13.6347	10.3438	12.7598	13.3328	13.2043	13.9935	16.4297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 202 / IND EST FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.5415	1.7375	
2	1.5384	1.7375	
3	1.5384	1.6476	
4	1.5384	1.5775	
5	1.5384	1.6289	
6	1.5384	1.6289	
7	1.5061	1.6651	
8	1.701	1.6651	
9	2.0957	2.0119	
10	2.2131	2.1795	
11	2.4143	2.1948	
12	2.1795	2.0805	
13	1.6095		
14	2.0119		
15	2.2801		
16	2.3137		
17	2.2801		
18	2.1795		
19	1.8747		2.1262
20	1.6766		1.6832
21	1.6766		1.7187
22	1.6461		1.7718
23	1.7147		1.7718
24	1.5947	1.8099	
Max	2.4143	2.1948	2.1262
Min	1.5061	1.5775	1.6832
Avg	1.8417	1.8127	1.8143

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 204 / YASHWANT FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0059	1.0829	
2	.9511	1.094	
3	.9511	1.0562	
4	.9955	1.0562	
5	.9955	1.0185	
6	1.0498	1.0185	
7	1.086	1.0562	
8	1.0136	1.0185	
9	1.1584	1.1949	
10		1.2936	
11	1.4045	1.2567	
12	1.4784	1.3169	
13	1.2567		
14	1.3306		
15	1.2936		
16	1.2323		
17	1.3443		
18	1.2936		
19	1.3676		1.2936
20	1.1203		1.1765
21	1.1203		1.0498
22	1.1203		1.1088
23	1.1203		1.0317
24	1.0164	1.1203	
Max	1.4784	1.3169	1.2936
Min	.9511	1.0185	1.0317
Avg	1.1611	1.1218	1.1321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 205 / IGM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631	1.3927	.3704	1.1934	1.2631	1.2631	1.2498
2	1.2146	1.3603	.4024	1.1736	1.2146	1.2146	1.1728
3	1.2146	1.2955	.3353	1.1105	1.2146	1.1469	1.2018
4	1.1822	1.2955	.3391	1.094	1.2146	1.0814	1.2018
5	1.1822	1.2597	.4694	1.1271	1.2146	1.0814	1.1248
6	1.1984	1.2597	.5243	1.1271	1.2146	1.1142	1.1248
7	1.2018	1.326	.5121	1.166	1.2146	1.278	1.1111
8	1.4232	1.0608	1.4083	1.278	1.2651	1.3279	1.2346
9	1.6004	1.2163	1.4815	1.6842	1.5623	1.6842	1.6049
10	1.5546	1.0883	1.6049	1.7814	1.5623		1.6248
11	1.6667	1.2071	1.704	1.6004	1.6842	1.4815	1.7284
12		.9709	1.5729	1.3441	1.587	1.5364	1.5181
13	1.2498	.9389	.9175	1.1012	1.0486	1.5123	1.1336
14	1.4998	.8048	1.4419	1.3441	1.5074	1.358	1.6204
15	1.6248	.8048	1.5402	1.4998	1.5074	1.3413	
16	1.6248	.823	1.4419	1.5242	1.6385	1.4998	1.6204
17	1.5623	.8048	1.5402	1.5242	1.5546	1.4998	1.6248
18	1.6248	.5243	1.5729	1.4937	1.6385	1.5181	1.6204
19	1.6248	.5365	1.4918	1.5242	1.6907	1.6644	1.6604
20	1.406	.5182	1.4091	1.3441	1.4746	1.5364	1.4232
21	1.4575	.506	1.5089	1.4548	1.5074	1.5432	1.4706
22	1.4373	.5365	1.3923	1.3441	1.4419	1.358	1.4232
23	1.4373	.5365	1.3077	1.3441	1.3435		1.3916
24	1.2651	1.4575	.4024	1.2742	1.2955	1.3108	1.2346
Max	1.6667	1.4575	1.704	1.7814	1.6907	1.6842	1.7284
Min	1.1822	.506	.3353	1.094	1.0486	1.0814	1.1111
Avg	1.4137	.9802	1.1121	1.3522	1.4108	1.3796	1.3966



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 206 / 11 K.V BHAJI MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0317	1.0498	.7682	1.0317	.905	.9412	.9145
2	.9955	1.0498	.7316	1.0242	.8507	.9412	.8871
3	.9955	1.0498	.695	.9877	.8145	.9145	.8131
4	.9593	1.0136	.695	.9877	.8145	.8779	.8589
5	.9593	1.0136	.7602	.9774	.8869	.8779	.8779
6	1.0136	1.0608	.7602	1.0136	.9412	.9145	.9145
7	.9774	1.0608	.8326	1.0136	1.0454	.9231	.8962
8	1.134	1.0608	1.0974	1.1222	1.1163	1.0679	1.0791
9	1.2226	1.086	1.2254	1.2489	1.2048	1.1946	1.1523
10	1.2757	1.0498	1.134	1.267	1.134	1.1584	1.262
11	1.3394	1.0719	1.2489	1.3289	1.1403	1.2437	1.262
12	1.1946	.9877	1.2308	1.1871	1.086	1.0974	1.134
13	1.0498	.9979	1.2071	.9593	.8779		
14	1.1584	.924	1.1523	1.0498	1.0242	1.0791	1.1765
15	1.2308	.9511	1.1888	1.1517	1.086	1.1706	1.2757
16	1.1584	.1463	1.2308	1.2048		1.0974	1.2803
17	1.1946	.1494	1.267	1.2226		1.1706	1.262
18	1.2308	.7842	1.3032	1.1871	1.134	1.2071	1.3289
19	1.267	.8871	1.3352	1.1694	1.1584	1.2803	1.3289
20	1.267	.8596	1.2803	1.0099	1.0974	1.1523	1.258
21	1.1946		1.1888	1.1517	1.0498	1.2437	1.1584
22	1.086	.8596	1.1403	1.0985	1.0242	1.0608	1.0985
23	1.086	.8413	1.1041	1.0985	.9774	1.0791	1.0631
24	1.0454	1.086	.7682	1.0974	.9412	.9511	.9328
Max	1.3394	1.086	1.3352	1.3289	1.2048	1.2803	1.3289
Min	.9593	.1463	.695	.9593	.8145	.8779	.8131
Avg	1.1278	.9148	1.0561	1.1079	1.0141	1.0715	1.0963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 207 / 11 KV BALAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.788	.8745	.3521	.8288	.779	.852	.8642
2	.7545	.8745	.3441	.788	.7459	.8619	.9156
3	.7545	.8848	.3201	.7461	.7127	.8288	.8718
4	.7209	.852	.3479	.7122	.7127	.8288	.8817
5	.7956	.852	.4161	.7122	.7459	.7956	.9054
6	.8453	.9054	.4752		.8122	.8029	.8987
7	.9116	.8848	.5256	.8551	.8785	.8288	.9602
8	.9779	.6802	.9389	.9175	.8785	.9221	.9892
9	1.1768	.7537	1.065	1.0774	1.0688	1.0774	1.1736
10	1.1336	.6802	1.1401	1.1233	1.0688		1.0802
11	1.166	.7377	1.1142	1.1469	1.0978	1.2071	1.1822
12			1.0322	.9116	1.0277	.9724	.9231
13	.8745		.8288	.7459	.779	1.0059	.8288
14	1.004		.9779	.9779	.9393	1.0227	.9614
15	1.1012	.2743	.9945	1.004	1.0562	1.0608	1.085
16	1.166	.4024	1.0978	1.065	1.1271	1.0978	1.0883
17	1.1012	.7377	1.1271	1.1498	1.1401	1.073	1.1233
18	1.1012	.3391	1.1305	1.1498	1.1142	1.1065	1.1498
19	.9717	.3353	1.0898	1.0814	1.1271	1.0814	1.0364
20	.9393	.3563	.9221	.9614	.9448	.9724	.9282
21	.9393	.3887	.9724	.9614	1.0227	1.0395	.9614
22	.9393	.4359	.9389	.8951	.9614	.9389	.9448
23	.9069	.3768	.9116	.9116	.8951	.8642	.8951
24	.8383	.9069	.3521	.9054	.8383	.8718	.8642
Max	1.1768	.9069	1.1401	1.1498	1.1401	1.2071	1.1822
Min	.7209	.2743	.3201	.7122	.7127	.7956	.8288
Avg	.9525	.6444	.8090	.9403	.9364	.9614	.9797

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 208 / 11 KV JIVESHWAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4175	1.5775	1.073	1.2757	1.4175	1.0277	1.4937
2	1.3466	1.5432	1.0059	1.2536	1.4175	1.0029	1.2742
3	1.2403	1.5432	1.0159	1.2536	1.3466	.9492	1.2407
4	1.2403	1.4723	1.0395	1.2178	1.2757	.9412	1.2452
5	1.3112	1.4723	1.1142	1.2178	1.2757	.9568	1.2452
6	1.2757	1.5074	1.1736	1.2403	1.2048	.9568	1.1869
7	1.2757	1.2971	1.0174	1.2048	1.2048	1.0277	1.1401
8	1.3523	1.2003	1.4083	1.3466	.9922	1.1517	1.4243
9	1.7772	1.6461	1.7436	1.6124	1.0631	1.7337	1.7436
10	1.7436	1.6461	1.6385	1.4899	1.0277	1.7337	1.6712
11	1.8652	1.6956	1.8176	1.6766	.8859	1.7695	1.5775
12	1.4746	1.5729	1.6644	1.5775	.8505	1.5074	1.5775
13	1.5089	1.6095	1.1317	1.4723	.5316	1.6095	1.4022
14	1.749	1.6278	1.3321	1.6476	.6485	1.6095	1.5592
15	1.7772	1.6118	1.5604	1.7147	.7343	1.6057	1.6956
16	1.5424	1.5402	1.5432		.7796	1.6956	1.8656
17	1.9791	1.3717	1.576	1.7635	.8859	1.5729	1.7368
18	1.5089	.9602	1.5402	1.4403	.8596	1.704	1.7833
19	1.4419	.9175	1.3112	1.406	.7973	1.3763	1.6804
20	1.3748	.7865	1.2094	1.2757	.7973	1.39	1.2003
21	1.5432	1.2071	1.2971	1.2689	1.1041	1.3108	1.3466
22	1.6766	1.2452	1.3112	1.6461	1.0808	1.2266	1.4883
23	1.6461	1.2071	1.2757	1.6461	1.0631	1.5089	1.4175
24	1.4883	1.5775	1.1142	1.0985	1.5238	1.0387	1.3435
Max	1.9791	1.6956	1.8176	1.7635	1.5238	1.7695	1.8656
Min	1.2403	.7865	1.0059	1.0985	.5316	.9412	1.1401
Avg	1.5232	1.4098	1.3298	1.4238	1.0320	1.3503	1.4725

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 209 / 11 KV NIGHT COLLAGE FEEDER SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	1.1949	1.0974	1.0745	1.0349	.6733	1.134
2	.9979	1.1694	1.0242	1.086	.9979	.6805	1.1203
3	.9979	1.1694	.9156	1.0498	.9979	.6024	1.0829
4	1.0349	1.1694	1.0829	1.0136	.924	.6024	1.0608
5	.9979	1.2071	1.0974	1.0029	.924	.7087	1.0456
6	1.0498	1.2071	1.1694	1.0277	.8688	.7619	1.1317
7	1.1458	1.358	1.0185	1.1222	.8871	.8328	1.2071
8	1.0349	1.2449	1.1203	1.1946	.7023	.8059	1.1203
9	1.1946	1.3957	1.3817	1.267	.7023	1.086	1.4563
10	1.4415	1.3817	1.2323	1.2536	.5914	1.1765	1.3817
11	1.4937	1.4937	1.2269	1.2308	.583	1.307	1.1827
12	1.3443	1.3443	1.2894	1.3306	.5087	1.2696	1.0349
13	1.1576	1.3443	1.0387	1.1458	.5087	1.307	1.0719
14	1.3817	1.2689	1.2178	1.1088	.4681	1.1706	1.1827
15	1.3817	1.3443	1.2536	1.2567	.5258	1.3957	1.3306
16	1.419	1.307	1.3969	1.3306	.503	1.3443	1.4712
17	1.4563	1.5684	1.3611	1.2567	.4801	1.3203	1.5466
18	1.4563	1.1949	1.3032	1.2197	.5144	1.307	1.3306
19	1.4563	1.1706	1.3756	1.1458	.5373	1.3443	1.2936
20	1.2323	1.1694	1.2308	1.0719	.5144	1.2696	1.1458
21	1.2323	1.1203	1.0136	1.0349	.6626	1.2696	1.2197
22	1.1949	1.0608	1.086	1.0719	.7164	1.2071	1.1458
23	1.2323	1.0974	1.1584	1.0349	.7164	1.1576	1.1088
24	1.1827	1.1949	1.1317	1.1222	1.1088	.6805	1.1694
Max	1.4937	1.5684	1.3969	1.3306	1.1088	1.3957	1.5466
Min	.9979	1.0608	.9156	1.0029	.4681	.6024	1.0349
Avg	1.2344	1.2574	1.1760	1.1439	.7074	1.0534	1.2073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 201 / 11 KV JANTA TEX.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7346	3.8666	3.6969	3.5837	3.6969	3.2819	3.5837
2	3.7723	3.8666	3.6591	3.5837	3.6969	3.3196	3.4389
3	3.7346	3.8666	3.6591	3.6214	3.7346	3.2819	3.3484
4	3.7346		3.6969	3.6214	3.6969	3.3008	3.3484
5	3.7723	3.7723	3.7346	3.5837	3.6969	3.3008	3.4389
6	3.7723	3.7723	3.6969	3.6214	3.7346	3.3196	3.6199
7	3.7723	3.7723	3.7346	3.5837	3.7346	3.3196	3.6199
8	3.7723	3.7723	3.7346	3.4894	3.5837	3.4705	3.6199
9		3.7723	3.81	3.7723	3.0178	3.5837	3.6199
10	3.8666	3.7723		3.7723	2.9424	3.6214	3.6199
11		3.9609		3.7723	2.7349	3.5837	3.5837
12	3.7723	3.9609	3.7723	3.7723	2.7349	3.4894	3.2579
13	3.4894	3.7723	3.7723	3.7723	2.7349	3.3951	3.1674
14	3.7723	3.7723	3.7723	3.7723	2.7726	3.5837	3.2579
15	3.7723	3.7723	3.7723	3.7346	2.7349	3.5837	3.4389
16	3.8666	3.6969	3.7723	3.7723	2.7161		3.5837
17	3.8666	3.7346	3.7723	3.7346	2.7349		3.4389
18	3.8666	3.6214	3.7723	3.7346	2.7349		3.3484
19	3.9609	3.6214	3.6214	3.6969	2.7538		3.3484
20	3.7723	3.6591	3.5837	3.7346	2.8669	3.3951	3.3484
21	3.7723	3.6969	3.5837	3.6969	3.3196	9.0535	3.4389
22		3.6214	3.5082	3.7346	3.2819	3.4894	3.4389
23		3.6591	3.5837	3.6969	3.3008	3.4894	3.3484
24	3.7723	3.8666	3.6969	3.6214	3.6969	3.3008	3.5837
Max	3.9609	3.9609	3.81	3.7723	3.7346	9.0535	3.6199
Min	3.4894	3.6214	3.5082	3.4894	2.7161	3.2819	3.1674
Avg	3.7808	3.7674	3.7003	3.6867	3.1939	3.7082	3.4517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 202 / 11 KV DECCAN PROCESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		3.2065	3.1687	3.131	3.0744	2.8292	3.0178
2		3.2065	3.1121	3.1121	3.0556	2.7915	3.0178
3			3.131	3.0178	3.0744	2.7538	3.0178
4			3.131	3.1121	3.0744	2.7538	3.0178
5			3.0556	3.131	3.0178	2.7915	3.0178
6			3.0367	3.0178	3.0178	2.7349	3.0178
7	3.3196		3.0367	3.0178	3.0178	2.7915	3.0178
8	3.3573	3.2065	3.1687	3.0178	2.6783	3.0178	3.2065
9	3.4705	3.3951	3.3196	3.2442	2.452	3.2819	3.3951
10	3.4894	3.3951	3.3196	3.3196	2.4331	3.3196	3.3951
11	3.4894	3.3951	3.3196	3.3573	2.452	3.3008	3.3951
12	3.3951	3.3951	3.3573	3.3573	2.1125	3.2065	3.3951
13	3.0178	3.0178	3.0178	3.2442	2.0748	3.0178	3.0178
14	3.2065	3.0178	3.2065	3.2065	2.1125	3.2065	4.904
15	3.3951	3.1121	3.2065	3.2442	2.0748	3.2065	3.0178
16	3.3951	3.0933	3.2065	3.2065	2.1125		3.0178
17	3.3951	3.0178		3.0556	2.1125		3.0178
18	3.3951	3.0178	3.2819	3.0556	2.1125		3.0178
19	3.3951	3.0178	3.2065	3.0556	2.1691		3.0178
20	3.2065	3.0556	3.1687	3.0556	2.5652	3.0178	3.0178
21	3.2065	3.1687	3.1687	3.0556	2.9424	3.0178	3.0178
22		3.2065	3.1687	3.0556	2.9424	3.0178	3.0178
23		3.2065	3.3196	3.0556	2.9424	3.0178	3.0178
24		3.2065	3.1687	3.1687	3.0744	2.9047	3.0178
Max	3.4894	3.3951	3.3573	3.3573	3.0744	3.3196	4.904
Min	3.0178	3.0178	3.0178	3.0178	2.0748	2.7349	3.0178
Avg	3.3423	3.1757	3.1859	3.1373	2.6123	2.9990	3.1671

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 203 / 11 KV ICH METALLOY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9805	1.9805	1.8861	1.9805	1.8107	1.7353	1.8861
2	1.9805	1.9805	1.8861	1.8484	1.8107	1.7353	1.8861
3	1.9805	1.9805	1.9239	1.8296	1.7918	1.7164	1.8861
4	1.8861	1.8861	1.9616	1.8107	1.7918	1.6975	1.8861
5	1.8861	1.8861	1.8861	1.8484	1.8107	1.7353	1.8861
6	1.8861	1.8861	1.8484	1.8107	1.8107	1.6975	1.8861
7	1.9239	1.9805	1.8296	1.8484	1.8107	1.7353	1.9805
8		2.0748	1.8861	2.037	1.6975	1.8107	2.0748
9	2.2634	2.1691	1.8861	2.1691	1.6032	2.0748	2.1691
10	2.1691	2.1691	2.1313	2.1879	1.5089	2.1125	2.1691
11	2.1691		2.1125	2.1879	1.5089	2.0748	2.1691
12	2.0748	2.2634	2.0748	2.1879	1.358	1.9805	2.0748
13	1.8861	1.9805	1.9993	2.1125	1.3203	1.8861	2.0748
14	2.0748	1.9993	2.2634	2.0748	1.3203	1.9805	2.0748
15	2.1691	1.9993	2.3011	2.037	1.3014	2.3577	2.2634
16	2.1691	1.9616	2.3388	1.9993	1.226		2.2634
17	2.1691	1.9427	2.3765	1.9993	1.2826		2.2634
18	2.0748	1.8861	2.3577	1.8673	1.2449		2.0748
19	2.0748	1.8861	2.1313	1.8861	1.2637		2.0748
20	1.9805	1.8861	2.0748	1.8484	1.4335	2.0748	2.0748
21	1.9805	1.9616	2.037	1.8107	1.6975	2.0748	2.0748
22		1.9993	2.037	1.8484	1.7353	1.9805	1.9805
23	2.0748	2.037	1.9805	1.8107	1.7353	1.9805	1.8861
24	1.9805	1.9805	1.9993	1.9805	1.7918	1.6975	1.8861
Max	2.2634	2.2634	2.3765	2.1879	1.8107	2.3577	2.2634
Min	1.8861	1.8861	1.8296	1.8107	1.226	1.6975	1.8861
Avg	2.0379	1.9903	2.0504	1.9592	1.5694	1.9069	2.0394

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 204 / 11 SHAHPUR IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0748	2.0748	2.2634	2.1125	1.9616	1.8107	2.2634
2	2.037	2.0748	2.2445	2.1125	2.037	1.8296	2.1691
3	2.0748	2.0748	2.2257	2.0748	1.9993	1.8484	2.1691
4	2.037	1.9805	2.2445	2.1125	1.9993	1.8484	2.0748
5	2.0559	2.0748	2.2634	2.0748	2.0748	1.8296	2.0748
6	2.037	2.1691	2.2257	2.1125	2.1125	1.8107	2.0748
7	2.0748	2.1691	2.2257	2.1125	2.1502	1.8484	2.1691
8	2.1691	2.1691	2.2445	2.2257	2.0748	1.8861	2.1691
9	2.2634	2.2634	2.3765	2.3765	1.7918	2.2257	2.2634
10	2.3577	2.2634	2.4143	2.4143	1.6975	2.2634	2.452
11	2.3577	2.3577	2.4143	2.4143	1.6975	2.2634	2.2634
12	2.2634	2.3577	2.2634	2.3765	1.6032	2.2634	2.1691
13	2.0748	2.2634	2.1879	2.3765	1.6032		2.1691
14	2.0748	2.2634	2.3577	2.3388	1.5844	2.1691	2.2634
15	2.2634	2.2634	2.3765	2.3388	1.6032	2.2634	2.3577
16	2.3577	2.2634	2.4143	2.3011	1.6032	1.8861	2.3577
17	2.3577	2.2634	2.3765	2.3011	1.6221		2.3577
18	2.3577	2.2634	2.4143	2.3011	1.6032		2.2634
19	2.2634	2.2634	2.1879	2.3011	1.6032		2.2634
20	2.1691	2.2634	2.1879	2.3388	1.6598	2.2634	2.2634
21	2.0748	2.2634	2.2257	2.3388	1.8484	2.2634	2.2634
22		2.2634	2.2257	2.037	1.8673	2.2634	2.2634
23		2.2634	2.1502	1.9993	1.8861	2.2634	2.2634
24	2.0748	2.0748	2.2634	2.1313	1.9616	1.8484	2.2634
Max	2.3577	2.3577	2.4143	2.4143	2.1502	2.2634	2.452
Min	2.037	1.9805	2.1502	1.9993	1.5844	1.8107	2.0748
Avg	2.1759	2.2084	2.2822	2.2343	1.8186	2.0474	2.2359



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 205 / 11 KV RADHA KANHAIYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7375	1.6032	1.0562	1.5655	1.8861	1.5278	1.8861
2	1.8296	1.5089	1.0562	1.4842	1.8861	1.5466	1.8861
3	1.8484	1.5089	1.0562	1.5089	1.7918	1.5655	1.6975
4	1.8107	1.5089	1.0562	1.5278	1.8296	1.5278	1.6975
5	1.8296	1.3203	1.0562	1.5466	1.8107	1.5466	1.6975
6	1.6221	1.3203	1.0562	1.5089	1.8107	1.5089	1.6289
7	1.6289	1.3203	1.0562	1.5466	1.7541	1.5466	1.7194
8	1.7737	1.1317	1.2449	1.6598	1.6975	1.6598	1.8099
9	1.8861	.9431	1.358	1.8484	1.5089	1.9616	1.8099
10	1.9805	.9431	1.7353	1.8861	1.5089	1.9805	1.8099
11	2.0748	1.1317	1.6975	1.9239	1.448	1.9805	1.8861
12	1.8861	1.226	1.6975	1.8861	1.226	1.8861	1.7918
13	1.5089	1.0374	1.5089	1.9239	1.2071	1.6975	1.7918
14	1.6975	1.0562	1.8673	1.8861	1.2637	1.8861	1.8099
15	1.8861	1.094	1.7737	1.8861	1.2826	1.8861	1.9004
16	1.8861	1.094	1.8861	1.9239	1.2826		1.9004
17	1.8861	1.0562	1.8861	1.8861	1.3014		
18	1.8861	1.0562	1.8861	1.8861	1.2826		1.8099
19	1.8861	1.0562	1.8861	1.8861	1.2826		1.7194
20	1.8861	1.0562	1.8107	1.8861	1.226	1.8861	1.7194
21	1.8861	1.0562	1.7013	1.9805	1.6032	1.8861	1.7194
22		1.094	1.7353	1.8861	1.6221	1.8861	1.8099
23		1.094	1.6975	1.8861	1.6221	1.8861	1.8099
24	1.8296	1.6032	1.0562	1.6787	1.8861	1.5655	1.8861
Max	2.0748	1.6032	1.8861	1.9805	1.8861	1.9805	1.9004
Min	1.5089	.9431	1.0562	1.4842	1.2071	1.5089	1.6289
Avg	1.8249	1.2008	1.4926	1.7704	1.5425	1.7409	1.7912

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 207 / 11 K.V AMIT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2257	2.2634	2.3388	2.0748	2.3011	2.1879	2.452
2	2.1879	2.2634	2.2634	2.1125	2.3011	2.1879	2.452
3	2.2257	2.2634	2.2257	2.1125	2.3388	2.1691	2.2634
4	2.1879	2.1691	2.2634	2.0748	2.3765	2.2068	2.2634
5	2.2257	2.1691	2.2257	2.1125	2.3011	2.1879	2.2634
6	2.1879	2.1691	2.2445	2.1125	2.3011	2.1879	2.452
7	2.2257	2.1691	2.1125	2.1125	2.4331	2.1879	2.452
8	2.452	2.2634	2.3765	2.1313	2.2634	2.2634	2.452
9	2.5652	2.3577	2.452	2.3577	2.0748	2.452	2.452
10	2.5463	2.3577	2.6217	2.4143	1.9993	2.5652	2.452
11	2.5463	2.5463		2.4143	1.9805	2.5463	2.452
12	2.452	2.5463	2.3577	2.4143	1.9805	2.5463	2.3577
13	2.2634	2.452	2.1502	2.4143	1.9805	2.2634	2.3577
14	2.2634	2.452	2.452	2.3765	1.9805	2.452	2.3577
15	2.452	2.3765	2.5652	2.3765	1.9805	2.452	2.452
16	2.452	2.4143	2.5652	2.3388	1.9239		2.452
17	2.5463	2.2634	2.5463	2.4143	1.9805		
18	2.452		2.5274	2.3388	1.9805		2.452
19	2.452	2.3765	2.4143	2.3765	1.9805		2.452
20	2.2634	2.4143	2.2634	2.3388	1.9805	2.3577	2.452
21	2.2634	2.452	2.1879	2.3388	2.3577	2.3577	2.452
22		2.3765	2.1313	2.3011	2.32	2.452	2.452
23		2.3388	2.1125	2.3011	2.32	2.452	2.452
24	2.2257	2.2634	2.3388	2.1125	2.3011	2.2257	2.452
Max	2.5652	2.5463	2.6217	2.4143	2.4331	2.5652	2.452
Min	2.1879	2.1691	2.1125	2.0748	1.9239	2.1691	2.2634
Avg	2.3483	2.3356	2.3364	2.2697	2.1557	2.3351	2.4151

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 208 / 11 K.V. TULJABHAVANI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5837	3.7723	3.7723	3.5837	3.5837	3.3951	3.4389
2	3.5837	3.7723	3.7912	3.3951	3.5837	3.2065	3.5837
3	3.5837	3.5837	3.7723	3.3951	3.5837	3.3951	3.3608
4	3.5837	3.5837	3.7723	3.3951	3.6214	3.3951	3.2579
5	3.5837	3.5837	3.7346	3.3951	3.5837	3.3951	3.4389
6	3.5837	3.5837	3.6969	3.3951	3.5837	3.2065	3.4389
7	3.5837	3.5837	3.5837	3.3951	3.5837	3.2065	3.5837
8	3.5837	3.5837	3.5837	3.3951	3.5837	3.2065	3.7723
9	3.7723	3.7723	3.5837	3.9609	3.3008	3.7723	3.9609
10	3.7723	3.7723	3.7723	3.9609	3.2065	3.7723	3.9609
11	4.1495	3.7723		3.9609	2.6972	3.7723	3.9609
12	3.9609	3.7723	3.7723	3.9609	2.6406	3.5837	3.7723
13	3.5837	3.5837	3.5837	3.9609	2.6406	3.5837	3.5837
14	3.7723	3.5837	3.7723	3.9609	2.6406	3.7723	3.6199
15	3.9609	3.5837	3.7723	3.7723	2.6406	7.7898	3.8009
16	3.9609	3.7723	3.7723	3.7723	2.6406		3.9209
17	3.9609	3.7723	3.7723	3.7723	2.6406		3.9209
18	3.9609	3.7723	3.7723	3.7723	2.6406		3.6199
19	3.7723	3.7723	3.5837	3.7723	2.6406		3.6199
20	3.3951	3.7346	3.5837	3.7723	3.0178	3.3608	3.4389
21	3.5837	3.7346	3.5837	3.9609	3.3951	3.1855	3.4389
22		3.7723	3.5837	3.8666	3.3951	3.5837	3.4389
23		3.7723	3.5837	3.5837	3.3951	3.5837	3.4389
24	3.5837	3.7723	3.7723	3.5837	3.5837	3.3951	3.5837
Max	4.1495	3.7723	3.7912	3.9609	3.6214	7.7898	3.9609
Min	3.3951	3.5837	3.5837	3.3951	2.6406	3.1855	3.2579
Avg	3.7209	3.6984	3.6944	3.6976	3.1593	3.6781	3.6231

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 209 / 11 K.V YOGASHRAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1317	1.3203	.7545	.9431	1.2803	1.1317	1.3203
2	1.1317	1.3203	.5487	.9431	1.2536	1.1317	1.3203
3	1.1317	1.267	.5373	.9431	1.0745	1.1317	1.1317
4	1.1317	1.1317	.5487	.9431	1.1888	1.1317	1.1317
5	1.1317	1.086	.5601	.9431	1.2012	1.1317	1.086
6	1.1317	1.086	.543	.9431	1.1317	1.1317	1.086
7	1.1317	1.086		.9431	1.0974	1.1317	1.086
8	1.5089	1.0517	1.0974	1.1317	1.0974	1.3203	1.2269
9	1.6975	.7164	1.2536	1.5089	1.4327	1.6975	1.267
10	1.6975	.7164	1.4632	1.5089	1.5089	1.6975	1.448
11	1.6975	1.0745		1.5089	1.5089	1.3203	1.5089
12	1.5089	1.0974	1.5089	1.5089	1.1317	1.1317	1.086
13	.9431	.5658	.7545	1.5089	1.3203	1.1317	.724
14	1.5089	.5373	1.5089	1.4632	1.3203	1.3203	1.267
15	1.6975	.5373	1.5089	1.387	1.3203	1.5089	1.6289
16	1.6975	.543	1.5089	1.2803	1.3203	1.3413	1.6289
17	1.5089	.5373	1.5089	1.2536	1.3203	1.3413	1.6289
18	1.5089	.5487	1.5089	1.3203	1.3203		1.448
19	1.5089	.7087	1.5089	1.3203	1.3203	1.2955	1.448
20	1.5089	.724	1.5089	1.2536	1.1317	1.5089	1.267
21	1.5089	.8954	1.5089	1.2536	1.3203	1.5089	1.267
22			1.3203	1.358	1.3203	1.307	1.448
23		.7164	1.3203	1.2536	1.3203	1.267	1.6289
24	1.1317	1.3203	.7545	1.1317	1.3203	1.1317	1.3203
Max	1.6975	1.3203	1.5089	1.5089	1.5089	1.6975	1.6289
Min	.9431	.5373	.5373	.9431	1.0745	1.1317	.724
Avg	1.3889	.8951	1.1380	1.2314	1.2734	1.2936	1.3085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4897	1.6975	2.5274	2.3011	2.8104	1.4901	2.1719
2	2.452	1.6975	2.5274	2.8292	2.6406	1.5655	2.3339
3	2.4331		2.5652	2.2822	2.6029	1.5466	2.3577
4	2.4709	2.0748	2.4897	2.32	2.5652	1.5089	2.452
5	2.2634	2.2634	2.5086	2.2634	2.3765	1.5278	2.3529
6	2.0748	2.452	2.5086	1.4335	2.1879	1.5466	2.3529
7	2.037	2.5463	2.5086	1.5089	2.1879	1.5655	2.3577
8	2.0748	2.6406	2.6029	1.7164	2.0748	1.5844	2.2624
9	1.5844	2.6406	2.7161	2.0748	1.5089	1.9805	1.9909
10	2.2634	2.3577	2.7161	2.1125	1.3203	2.0182	1.9004
11	2.6406	2.6406	2.7161	2.1502	1.3203	1.9805	1.9805
12	2.452	2.6406	2.5652	2.1879	1.1317	1.9805	2.2624
13	1.5089	1.8861	2.0748	2.2257	1.094	1.8861	2.3529
14	2.2634	2.2634	2.1879	2.3011	1.1128	1.9805	2.2634
15	2.6406	2.3011	2.2257	2.4897	1.1128	1.9805	1.4937
16	2.2634	2.3388	2.2068	2.5652	1.0751		1.8861
17	2.0748	2.452	2.2445	2.6029	1.094		2.0748
18	2.0748	2.4897	2.2445	2.6029	1.0751		1.9909
19	2.2634	2.5463	2.2634	2.6406	1.1128		2.2624
20	2.3577	2.6029	1.9805	2.6595	1.2449	1.8861	2.4434
21	2.3577	2.5652	1.9993	2.6972	1.3014	2.0748	2.3529
22		2.5274	1.9239		1.3203	2.2405	2.1719
23		2.5652	2.2634	2.6972	1.3203	2.2405	1.9004
24	2.4143	1.6975	2.5274	2.2257	2.7349	1.4146	2.2634
Max	2.6406	2.6406	2.7161	2.8292	2.8104	2.2405	2.452
Min	1.5089	1.6975	1.9239	1.4335	1.0751	1.4146	1.4937
Avg	2.2480	2.3429	2.3789	2.2995	1.6802	1.7999	2.1763

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 211 / 11 KV Mhashoba Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7918	.7682	1.6409	1.6975	1.5466	1.5089
2		1.7918	.9175	1.6032	1.6975	1.5089	1.6289
3			.852	1.6221	1.6221	1.5466	1.4251
4		1.6975	.8848	1.5844	1.6598	1.5466	
5			.9175	1.6221	1.5655	1.5655	1.4251
6		1.6975	.9503	1.5844	1.6032	1.5089	1.5089
7	1.4586	1.6975	1.0159	1.6221	1.5655	1.5466	1.6289
8	1.9993		1.5089	1.773	1.5844	1.6409	1.7194
9			1.7918	2.037	1.6975	1.9993	1.8099
10	2.0748		2.037	2.0748	1.7353	1.9805	1.9909
11			1.8461	1.7394	1.7353	1.8861	1.8861
12	1.8442		1.8484	1.7604	1.5466	1.7918	1.6804
13			1.4712	1.8023	1.7353	1.6975	1.448
14	1.6766	.9431	1.7353	2.0748	1.7541	1.8861	1.8099
15		.9808	1.7918	2.037	1.773	1.9805	1.9909
16	2.0748	.7545	1.8296	2.037	1.773		1.8861
17		.7545	1.8484	2.037	1.7918		1.8861
18	2.0748	.679	1.8484	1.7695	1.773		1.8099
19		.6554	1.8861	1.6964	1.773		1.8099
20	1.8861	.7209	1.7541	1.9616	1.6409	1.6766	1.6289
21	1.8861	.7362	1.7353	1.8861	1.6975	1.5089	1.6289
22		.7122	1.7164	1.8107	1.6975	1.3413	1.7194
23		.7461	1.6787	1.7353	1.7164	1.3413	1.7194
24		1.7918	.7537	1.6598	1.6975	1.5844	1.5089
Max	2.0748	1.7918	2.037	2.0748	1.7918	1.9993	1.9909
Min	1.4586	.6554	.7537	1.5844	1.5466	1.3413	1.4251
Avg	1.8861	1.1344	1.4745	1.7988	1.6889	1.6542	1.6982

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 201 / 11 KV KABNOOR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.448	1.1088	1.4575	1.3375	1.6289	1.3717
2	.5144	1.448	1.0288	1.4575	1.3375	1.5546	1.3717
3	1.3717	1.448	1.0288	1.4575	1.3375	1.4632	1.3717
4	1.3717	1.448	1.0288	1.4575	1.3375	1.4632	1.3717
5	1.3717	1.448		1.4575	1.3375	1.4632	1.5432
6	1.3717	1.448		1.4575	1.3375	1.4632	1.5432
7	1.5775	1.6289		1.4575	1.406	1.6289	1.5432
8	1.6461	1.2696	1.3203	1.7147	1.5089	1.7194	1.6461
9	1.8176	1.2437	1.8604	1.8004	1.8176	1.8004	1.8519
10	1.8652	1.2003	1.9719	1.9719	1.9071	1.9547	1.9204
11	1.8652	1.2003	2.0576	1.9719	1.9071	1.9547	1.8861
12	1.7147		1.9547	1.7147	1.8604	1.8861	1.7528
13	1.4327		1.406	1.2003	1.5384	1.4746	1.4632
14	1.6118	.8573	1.7147	1.5432	1.7718	1.7147	1.6832
15	1.8861	.8573	2.0576	1.8861	1.9281	1.7833	1.9071
16	1.9071	.8573	1.989	1.8861	1.8404	1.8176	1.9071
17	1.8861	.8573	1.989	1.8861	1.8404	1.8176	1.9071
18	1.9909	.9526	1.9204	1.8861	1.8404	1.9547	2.0376
19	2.0633	1.1431	1.8861	1.8861	1.8404	1.9547	2.1262
20	2.0633	1.1431	1.7147	1.749	1.8604	1.9547	1.97
21	1.9185	1.3203	1.7147	1.7147	1.8804	1.7147	1.8604
22	1.8461	1.3203	1.5432	1.7147	1.7909	1.7147	1.8604
23	1.6289	1.307	1.5432	1.7147	1.7909	1.5775	1.7909
24	1.5432	1.6289	1.1317	1.5432	1.5432	1.8099	1.5432
Max	2.0633	1.6289	2.0576	1.9719	1.9281	1.9547	2.1262
Min	.5144	.8573	1.0288	1.2003	1.3375	1.4632	1.3717
Avg	1.6516	1.2489	1.6176	1.6661	1.6624	1.7196	1.7179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 202 / CHANDUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2579	3.4027	2.2291	2.915	2.915	3.3303	2.915
2	3.2579	3.3669	2.2291	2.915	2.915	3.155	2.915
3	3.2579	3.3669	2.2291	2.915	2.915	3.1893	2.915
4	3.2579	3.3669	2.2291	2.915	2.915	3.1893	2.915
5	3.2579	3.3669		2.915	2.915	3.1893	3.0864
6	3.4294	3.3669		2.915	2.915	3.1893	3.0864
7	3.4294	3.3669		2.915	2.9492	3.1893	3.1893
8	3.4294	2.5133	2.1691	3.1722	2.915	3.3665	3.0864
9	4.0809	2.6242	3.9438	3.4294	3.6275	4.0295	4.0466
10	4.0573	2.1605	4.201	4.201	4.0295	4.2867	4.0695
11	4.3239	2.1434	4.201	4.201	4.1543	4.0486	4.2391
12	3.3436	1.6289	4.0809	2.7435	3.5056	4.1152	3.3808
13	2.7149	1.2003	2.4006	2.7435	2.5072	2.4348	2.6797
14	2.955	1.3717	3.0864	3.4294	3.6808	3.2579	3.6408
15	4.1914	1.5432	3.858	3.9438	4.0295	3.8409	3.9847
16	4.0609	1.3717	3.9438	3.9438	3.9438	3.8066	3.94
17	4.0609	1.286	3.9438	3.7723	3.9438	4.0124	3.94
18	4.0295	1.4289	3.8752	3.8409	3.9438	4.0466	3.8152
19	3.9438	1.4289		3.8409	3.7723	3.8752	3.6866
20	3.7723	1.9052	3.1722	3.2579	3.4294	3.5151	3.3303
21	3.8066	2.2634	3.1722	3.2922	3.4675	3.4979	3.3808
22	3.8489	2.3339	3.1722	3.2922	3.5932	3.4979	3.3808
23	3.6408	2.2291	3.0864	3.2579	3.5932	3.4294	3.4675
24	3.6008	3.6408	2.2291	3.0864	3.0864	3.5056	3.4294
Max	4.3239	3.6408	4.201	4.201	4.1543	4.2867	4.2391
Min	2.7149	1.2003	2.1691	2.7435	2.5072	2.4348	2.6797
Avg	3.6254	2.3616	3.1726	3.3272	3.4026	3.5416	3.4383



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 205 / DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	1.3817	.6859	1.286	1.3032	1.3717	1.2346
2	1.2346	1.3817	.6859	1.286	1.3032	1.286	1.2346
3	1.2346	1.3817	.6859	1.286	1.3032	1.286	1.2346
4	1.2346	1.3817	.6859	1.286	1.3032	1.286	1.2346
5	1.2346	1.3817		1.286	1.3032	1.286	1.3032
6	1.3375	1.4563		1.286	1.3032	1.286	1.3032
7	1.4251	1.6804		1.286	1.3603	1.4575	1.4746
8	1.5089	1.2323	1.0288	1.5432	1.4251	1.5432	1.5089
9	1.9113	1.1506	1.8861	1.7147	1.6518	1.8004	1.749
10	1.9204	1.0288	1.7814	1.8861	1.8004	1.9113	1.7375
11	2.0119	1.0288	1.7814	1.8861	1.8861	1.9113	1.7528
12	1.6956	.8573	1.749	1.6289	1.6289	1.8861	1.8004
13	1.3717	.5144	1.2003	1.0288	1.2003	1.1145	.8573
14	1.6956	.6859	1.5432	1.3717	1.6289	1.3717	1.3717
15	1.8861	.8573	1.8004	1.8861	1.8004		1.5242
16	1.8861	.8573	1.8138	1.8861	1.7147	.583	1.5242
17	1.7147		1.8138	1.7147	1.7147		1.6004
18	1.9605	.9526	1.8861	1.7833	1.7147	1.5432	1.8004
19	2.0165	.8573	1.8861	1.7833	1.6289	1.5775	1.8861
20	1.8671	.8573	1.7147	1.5546	1.6289	1.6461	1.7147
21	1.7924	.9526	1.6289	1.4575	1.6289	1.6461	1.6289
22	1.7924	.9431	1.6289	1.4575	1.5432	1.6461	1.6289
23	1.7551	.8573	1.6289	1.5432	1.5432	1.5432	1.3717
24	1.5089	1.7177	.6859	1.6289	1.4575	1.4575	1.5432
Max	2.0165	1.7177	1.8861	1.8861	1.8861	1.9113	1.8861
Min	1.2346	.5144	.6859	1.0288	1.2003	.583	.8573
Avg	1.6346	1.1042	1.4382	1.5315	1.5323	1.4746	1.5008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 207 / CHANDUR KABNUR AG FEEDER      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3239	.2846	.2743	.0171	.0171	.0171	.0171
2	.3239	.2846	.2743	.0171	.0162	.0171	.0162
3	.3239	.3163	.2743	.0171	.0162	.0171	.0162
4	.3239	.3163	.2743	.0171	.0162	.0171	.0162
5	.3239	.3163		.0171	.0162	.0171	.0162
6	.3563	.3479			.0162	.0171	.0162
7	.4534	.506		.0171	.0162	.0171	.0171
8	.5182	.5218	.4572	.0171	.0162	.0171	
9	.5182	.5693	.5335	.0171	.0162	.0162	.0162
10	.5487	.583	.5668	.0171	.0171	.0162	.0171
11	.0171	.0171	.4858	.6859	.6859	.6478	.6859
12	.0171	.0171	.4534	.7716	.7316	.7773	.7316
13	.0171	.0171	.0162	.8573	.7316	.7773	.7316
14	.0171	.0171	.0171	.7716	.6859	.7773	.6859
15	.0171	.0171	.0171	.7716	.6859	.583	.6859
16	.0171	.0171	.0162	.7716	.6097	.6478	.6859
17	.0171	.0171	.0162	.7716	.6097	.6478	.6097
18	.0152	.0171	.0171	.6478	.6097	.6478	.6097
19	.0152	.0171	.0171	.0162	.0171	.0162	.0171
20	.0152	.0171	.0171	.0162	.0171	.0162	.0171
21	.0152	.0171	.0171	.0162	.0171	.0162	.0171
22	.0152	.0171	.0171	.0162	.0171	.0162	.0171
23	.0152	.0171	.0171	.0162	.0171	.0162	.0171
24	.0162	.0152	.0171	.0171	.0162	.0171	.0162
Max	.5487	.583	.5668	.8573	.7316	.7773	.7316
Min	.0152	.0152	.0162	.0162	.0162	.0162	.0162
Avg	.1767	.1785	.1808	.2740	.2340	.2406	.2468

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5658	.3429	.5144	.4458	.5144	.5487
2	.5144	.5658	.3429	.5144	.4458	.5144	.5487
3	.5144	.5658	.3429	.5144	.4458	.5144	.5487
4	.5144	.5658	.3429	.5144	.4458	.5144	.5487
5	.5144	.5658		.5144	.4458	.5144	.5487
6	.5144	.5658		.5144	.4458	.5144	.5487
7	.6173	.6036		.5144	.4801	.6001	.6173
8	.6859	.5281	.4287	.5144	.5144	.6001	.6859
9	.7545	.4854	.6859	.5144	.7545	.7716	.7202
10	.7545	.4458	.6859	.6859	.7716	.7545	.7202
11	.7716	.4287	.6859	.6859	.7716	.7545	.7716
12	.6859	.3429	.6859	.6001	.6097	.6859	.6516
13	.6001	.2572	.5144	.3429	.4572	.5144	.5144
14	.6859	.3429	.5144	.5144	.5335	.6173	.6859
15	.6859	.4287	.6859	.6001	.6097	.6859	.6859
16	.6859	.3429	.6859	.6859	.6859	.6516	.6859
17	.6859	.3429	.6859	.6859	.6859	.6516	.6859
18	.8488	.381	.6859	.6516	.6859	.7202	.6859
19	.8488	.381	.6859	.6516	.6859	.7716	.7716
20	.7545	.381	.6001	.583	.6859	.7545	.6859
21	.7545	.381	.6001	.583	.6859	.6516	.6859
22	.7545	.381	.6001	.583	.6516	.6516	.6859
23	.7545	.3429	.6001	.583	.6516	.6173	.6859
24	.6173	.679	.3429	.6001	.5144	.6001	.5487
Max	.8488	.679	.6859	.6859	.7716	.7716	.7716
Min	.5144	.2572	.3429	.3429	.4458	.5144	.5144
Avg	.6680	.4530	.5593	.5694	.5879	.6309	.6445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 201 / 11 KV HANUMANNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4175	1.5432	.5426	1.4175	1.7147	1.4175	1.5432
2	1.4175	1.5432	.5087	1.4175		1.4175	1.5432
3	1.4022	1.4575	.4917	1.3717	1.4575	1.326	1.5432
4	1.3413	1.4575	.5087	1.2803	1.4575	1.326	1.5432
5	1.3717	1.4575	.5596	1.2803	1.4575	1.3717	1.5432
6	1.3717	1.4575	.6443	1.2955	1.4746	1.3717	1.5432
7	1.4632	1.4746	.6783	1.3413	1.3108	1.3717	1.5432
8	1.6461	1.2193	1.2717	1.6004	1.448	1.5089	1.3717
9	2.0271	1.1736	2.0517	1.9662	1.9052	1.9814	1.8595
10	2.0271	1.1736	2.0856	1.9204	1.9052	1.9662	2.0576
11	2.0119	1.153	1.9204	2.0119	1.9052	2.3148	2.0729
12	1.7528	.763	1.8747	1.7528	1.5394	2.2291	1.7528
13	1.5432	.5596	1.326	1.326	1.3108	1.3717	1.4022
14	2.0748	.78	1.6004	1.6004	1.6004	1.8861	1.829
15	2.1948	.8478	1.829	1.9719	1.829	2.0576	1.9509
16	2.2119	.8817	1.89	2.0919	1.829	2.1434	1.9509
17	2.2119	.8309	1.9204	2.1091	1.829	2.1434	1.9509
18	2.2119	.373	1.9052	2.1091	1.829	2.1434	2.1434
19	2.2119	.4409	1.8747	2.0576	1.768	2.1434	2.0576
20	2.1948	.5426	1.7375	1.8519	1.6156	2.1434	1.9719
21	2.0919	.6613	1.7071	1.8004	1.6004	2.0576	1.9204
22	1.9033	.6783	1.6004	1.7318	1.5699	1.8004	1.8861
23	1.8861	.6613	1.5546	1.7147	1.6004	1.8004	1.749
24	1.4632	1.8861	.6104	1.4632	1.7147	1.5089	1.7147
Max	2.2119	1.8861	2.0856	2.1091	1.9052	2.3148	2.1434
Min	1.3413	.373	.4917	1.2803	1.3108	1.326	1.3717
Avg	1.8104	1.0424	1.3622	1.6868	1.6379	1.7834	1.7685

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.7716	.3052	.6154	.7202	.6316	.6001
2	.6316	.7716	.3052	.6154	.6859	.6316	.6001
3	.6316	.6173	.3052	.583	.6859	.5992	.6001
4	.583	.6173	.3222	.583	.6173	.583	.6001
5	.583	.6173	.3222	.5506	.6173	.583	.6001
6	.6316	.6173	.3561	.5506	.6173	.583	.6001
7	.6802	.6687	.4578	.6154	.5944	.6802	.6859
8	.7287	.6097	.5426	.7287	.7316	.6964	.6097
9	.9393	.6554	.9496	.9231	.9145	.8907	.7926
10	.9231	.6706	.9496	.9069	.9145	.8583	.8535
11	.8688	.6783	.9717	.9231	.9145	.9431	.8688
12	.7773	.6104	.9231	.9069	.6401	.8573	.6859
13	.6173	.4409	.583	.6316	.503		.5639
14	.7716	.5087	.7773	.7287	.7287		.7316
15	.9431	.5596	.9393	.8916	.8259	.8573	.8383
16	.9431	.5256	.9555	.9431	.8421	1.0288	.8383
17	.9431	.5087	.9069	.9602	.8421	1.0288	.8993
18	.9431	.373	.9231	.9602	.8745	.8573	.9431
19	.9431	.407	.9231	.9259	.8907	.8573	.9431
20	.9431	.4409	.8421	.8916	.8745	.8573	.9259
21	.8916	.4239	.8745	.8573	.8259	.7716	.8916
22	.8745		.8259	.7888	.7773	.7716	.8573
23	.8573	.3561	.7773	.7888	.7449	.7716	.823
24	.6802	.8573	.3391	.6802	.7202	.6802	.7716
Max	.9431	.8573	.9717	.9602	.9145	1.0288	.9431
Min	.583	.3561	.3052	.5506	.503	.583	.5639
Avg	.7907	.5786	.6824	.7729	.7543	.7736	.7552

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 204 / 11 KV NEW COLLAGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.9602	.5087	.7956	.8573	.7956	.6859
2	.7956	.9602	.4578	.7459	.8573	.7956	.6859
3	.7956	.8916	.4409	.7459	.8573	.6962	.6859
4	.7459	.8916	.4409	.663	.8573	.7042	.6859
5	.7459	.8916	.4578	.6962	.8916	.6962	.6859
6	.7956	.8916	.4917	.6962	.8916	.6962	.6859
7	.9945	.9259	.6274	.8288	.823	.8951	.9431
8	1.0442	.8535	.78	.9614	.8688	.8951	.8383
9	1.1934	.8535	1.2209	1.1603	1.0974	1.1271	1.0059
10	1.1584	.823	1.2209	1.2266	1.0974	1.1603	1.0974
11	1.1584	.8478	1.1934	1.094	1.0974	1.2003	1.1279
12	1.0974	.6443	1.094	1.094	1.0059	1.0288	1.0669
13	.7888	.5256	.6962	.6962	.7011	.6859	.7621
14	.7888	.6104	.9945	.9614	.9945	.9431	.945
15	1.2003	.6783	1.0608	1.0288	1.0277	1.0288	1.0364
16	1.2003	.6443	1.1105	1.1317	1.1271	1.0288	1.0364
17	1.2003	.6104	1.1603	1.1317	1.1271	1.0288	.9145
18	1.2346	.4917	1.1934	1.1317	1.1271	1.1145	1.166
19	1.2346	.5596	1.2266	1.1317	1.1603	1.2003	1.0288
20	1.2346	.5426	1.0608	1.1145	1.094	1.2003	.9945
21	1.2003	.5935	1.0608	1.0288	1.0608	1.0288	1.0288
22	1.1145	.6274	.9945	.9945	1.0442	1.0288	1.0974
23	1.0631	.6274	.9282	.9945	.9614	1.0288	1.0288
24	.9389	1.0631	.5765	.8951	.9431	.8951	.8573
Max	1.2346	1.0631	1.2266	1.2266	1.1603	1.2003	1.166
Min	.7459	.4917	.4409	.663	.7011	.6859	.6859
Avg	1.0217	.7504	.8749	.9562	.9821	.9543	.9205

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 201 / 11 KV Dhangarmal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.086	.8589	1.1222	1.0974	1.0974	1.086
2	1.0974	1.0608	.8215	1.086	1.0608	1.0608	1.0608
3	1.0974	1.0242	.8299	1.0608	1.0719	1.0242	1.0608
4	1.0608	.9979	.8299	1.0242	1.0349	1.0242	1.0608
5	1.134	1.0719	.9054	1.0242	1.0974	1.0974	1.086
6	1.2071	1.1458	.9808	1.0608	1.2071	1.1706	1.1584
7	1.2437	1.1088	1.0185	1.1222	1.2071	1.2437	1.2437
8	1.2803	1.0608	1.1317	1.1946	1.1946	1.2071	1.182
9	1.39	1.1584	1.2826	1.2403	1.2178	1.2803	1.262
10	1.2269	1.0745	1.1218	1.1919	1.134	1.3112	1.1919
11	1.1919	1.086	1.262	1.2269	1.1104	1.2403	1.1919
12	1.134	1.086	.9431	1.1919	1.1222	1.134	1.0517
13	.9877	.9511	1.134	1.2269	.9593	1.2403	1.2048
14	1.0387	1.0974	1.0985	1.1462	1.0631		1.2178
15	1.1694	1.0608	1.1919	1.2403	1.0985	1.1694	1.2048
16	1.2048	1.0498	1.1919	1.262	1.0745	1.2048	1.2048
17	1.1568	1.0136	1.2136	1.2136	1.0745	1.1694	1.1789
18	1.262	1.0562	1.2483	1.2403	1.1104	1.1919	1.2178
19	1.2308	1.0608	1.2308	1.2308	1.1104	1.2308	1.2308
20	1.1946	1.0185	1.2178	1.2308	1.1104	1.2308	1.2071
21	1.1584	.9431	1.182	1.1946	1.2178	1.2536	1.2071
22	1.1584	.9431	1.182	1.1584	1.1462	1.182	1.2071
23	1.1222	.9431	1.182	1.1222	1.1462	1.1462	1.1946
24	1.1104	1.1222	.8962	1.1584	1.134	1.134	1.1222
Max	1.39	1.1584	1.2826	1.262	1.2178	1.3112	1.262
Min	.9877	.9431	.8215	1.0242	.9593	1.0242	1.0517
Avg	1.1648	1.0509	1.0815	1.1654	1.1167	1.1758	1.1681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 203 / 11 KV Ghorpade

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.0185	.9808	.9808	.9808	.9808	.9808
2	1.0562	.9808	.9808	.9808	.9431	.9431	.9431
3	1.0185	.9431	.9808	.9431	.9054	.9431	.9054
4	1.0185	.9431	.9431	.9431	.9054	.9431	.9054
5	1.0185	.9808	.9431	.9054	.9431	.9808	.9431
6	1.0562	.9808	.9431	.9431	.9431	.9808	.9431
7	1.0562	.9431	.9431	.9431	.9808	.9808	1.0185
8	1.0185	.9054	.9808	.9808	.9808	.9808	1.0185
9	.9431	1.0185	.9808	1.0185	.9808	.9431	.9808
10	.9808	1.0185	.9054	.9808	.7922	.9808	.9808
11	.7922	1.0185	.9808	.9808	.9808	.9431	1.0185
12	1.0185	.9431	.9431	.9808	.9431	.9808	.9808
13	.9808	.9808	.9808	.9808	.9808	.9431	1.0185
14	.9431	.9431	.9431	.9808	.9808		.9808
15	1.0562	1.0185	.9808	.9808	.9431	1.0185	.9808
16	1.0185	1.0185	.9808	.9808	.9808	.9808	1.0185
17	1.0185	1.0185	1.0562	1.0185	.9054	.9808	.9808
18	1.0185	1.0185	.9808	1.0185	.9054	1.0185	.9808
19	.9808	1.0185	.9808	.9808	.9054	1.0185	1.0185
20	.9808	.9808	.9808	.9431	.9054	.9431	.8676
21	1.0185	.9808	.9808	.9054	1.0185	.8676	.9808
22	.9808	1.0185	1.0185	.9431	.9808	.9431	.9808
23	.9808	.9808	1.0185	1.0185	.9431	.9431	1.0185
24	1.0185	1.0185	.9808	.9808	.9431	.9808	.9431
Max	1.0562	1.0185	1.0562	1.0185	1.0185	1.0185	1.0185
Min	.7922	.9054	.9054	.9054	.7922	.8676	.8676
Avg	1.0012	.9871	.9745	.9714	.9447	.9660	.9745



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochoi Sub Station

Feeder No / Name : 204 / 11 KV Chavan

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5089	1.6598	1.4335	1.5844	1.5844	1.4335	1.5089
2	1.5089	1.5844	1.4335	1.5089	1.5089	1.3957	1.5089
3	1.4335	1.5089	1.4712	1.5089	1.4335	1.3957	1.4335
4	1.4335	1.4335	1.3957	1.4335	1.4335	1.3957	1.4335
5	1.5089	1.5089	1.3957	1.4335	1.5089	1.4335	1.4335
6	1.5844	1.6598	1.4335	1.5844	1.5844	1.5089	1.5089
7	1.5844	1.5844	1.5089	1.5844	1.6598	1.5844	1.6598
8	1.5844	1.5089	1.4335	1.6598	1.5089	1.5466	1.5844
9	1.7353	1.6598	1.7353	1.8107	1.5844	1.6598	1.7353
10	1.7353	1.6598	1.8107	1.8861	1.5844	1.7353	1.7353
11	1.8107	1.6598	1.8861	1.8861	1.5844	1.6598	1.6598
12	1.7353	1.5844	1.7353	1.6598	1.5089	1.5844	1.6598
13	1.3717	1.5089	1.5844	1.6598	1.358	1.6598	1.6598
14	1.6598	1.5844	1.6598	1.5844	1.3203		1.6975
15	1.5844	1.5844	1.7353	1.8861	1.2826	1.6598	1.7353
16	1.8107	1.5844	1.7353	1.7353	1.3203	1.7353	1.7353
17	1.7353	1.6598	1.7353	1.7353	1.358	1.6598	1.7353
18	1.7353	1.5089	1.7353	1.7353	1.3203	1.7353	1.5844
19	1.7353	1.5844	1.6598	1.7353	1.4335	1.6598	1.6598
20	1.7353	1.5844	1.6598	1.6598	1.4335	1.6598	1.5844
21	1.6598	1.5844	1.7353	1.5844	1.5844	1.6598	1.6221
22	1.6598	1.4335	1.6598	1.5844	1.6598	1.5844	1.5844
23	1.6598	1.358	1.6598	1.6598	1.5089	1.5844	1.5844
24	1.5844	1.6598	1.3957	1.5844	1.5844	1.4335	1.5844
Max	1.8107	1.6598	1.8861	1.8861	1.6598	1.7353	1.7353
Min	1.3717	1.358	1.3957	1.4335	1.2826	1.3957	1.4335
Avg	1.6290	1.5687	1.6095	1.6535	1.4854	1.5811	1.6095

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 205 / 11 KV VIVEKANAND NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5544	.3361	.5601	.5175	.4527	.4805
2	.5601	.5175	.3018	.5228	.5175	.3772	.4481
3	.5601	.4805	.3018	.4904	.4805	.3772	.4481
4	.5601	.4854	.3018	.4527	.4481	.3772	.4108
5	.5975	.5228	.3395	.4854	.4854	.415	.4481
6	.5975	.5601	.415	.5601	.5228	.4527	.4854
7	.7023	.5544	.4904	.5228	.5601	.4904	.5175
8	.7023	.5914	.4481		.5175	.5658	.5121
9	.7392	.5731	.5601	.631	.5895	.679	.5895
10	.6443	.543	.5316	.631	.5609	.6516	.6516
11	.6859	.543	.5426	.6379	.6516	.6379	.4908
12	.6661		.5014	.6024	.4458	.6024	.567
13	.4854		.3018	.6089	.6036	.6024	.4961
14	.5792		.4706	.6089	.6036		.5609
15	.5548	.1547	.5609	.6024	.5959	.6588	.6588
16	.6661	.216	.5258	.6588	.5609	.6241	.6516
17	.6935	.2507	.5609	.5144	.567	.6516	.6516
18	.5959	.2481	.5201	.631	.5316	.6859	.6447
19	.6447	.2804	.5121	.6379	.5316	.6661	.6089
20	.6089	.2835	.5544	.6447	.4961	.6447	.5792
21	.6516	.4252	.5601	.6584	.5658	.6154	.7164
22	.6878	.4252	.5914	.6283	.5658	.543	.679
23	.6584	.394	.6219	.6283	.5281	.5121	.6219
24	.6447	.5914	.3696	.5975	.5544	.4904	.4805
Max	.7392	.5914	.6219	.6588	.6516	.6859	.7164
Min	.4854	.1547	.3018	.4527	.4458	.3772	.4108
Avg	.6280	.4378	.4675	.5877	.5417	.5554	.5583

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 201 / 11 kv Chokak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.431				.431	.4752	.426
2	.431				.431	.4752	.426
3	.431				.431	.4752	.426
4	.431				.431	.4915	.426
5	.4641				.4641	.5571	.5243
6	.5441				.5304	.6226	.6882
7	.9282			.0655	.7956	.8684	.9503
8	1.0608	.0655	.0655		1.1603	1.1142	1.2452
9	1.0608	.0655	.0655		1.0277	1.1142	1.278
10		.0663	.0655				
11		.9282	1.3717	1.3435	.0655		
12		1.4586	1.5432	1.4746			.0655
13		1.3923	1.4575	1.4419			.0819
14		1.2929	1.3717	1.3435			
15		1.326	1.3717	1.2452			
16	.0655	1.3592	1.3717	1.2125			
17		1.3592	1.3717	.9945			
18		1.1469	1.1142	1.0277			
19		.0655		.0829	.0655	.0819	.0663
20	.0655	.0655		.0663	.0655	.0819	.0663
21	.0655	.0655		.0663	.0819		.0663
22					.0655		
24	.3315				.3647	.2622	.3932
Max	1.0608	1.4586	1.5432	1.4746	1.1603	1.1142	1.278
Min	.0655	.0655	.0655	.0655	.0655	.0819	.0655
Avg	.4854	.7612	1.0154	.8637	.4274	.5516	.4753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 202 / 11KV Mudshingi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2826	1.307	1.1317	1.1317	1.1317	1.1317	1.1203
2	1.2449	1.2323	1.1317	1.1317	1.094	1.094	1.1203
3	1.2449	1.1203	1.1317	1.1317	1.094	1.094	1.1203
4	1.2449	1.1203	1.2071	1.1694	1.094	1.1317	1.1203
5	1.3203		1.2826	1.226	1.1317		1.2696
6	1.5089	1.531	1.5089	1.4146	1.2826	1.5466	1.5089
7	1.6975	1.7551	1.6975	1.4335	1.5466	1.6032	1.587
8	1.6975	1.8671	1.6598	1.643	1.5089	1.6409	1.7737
9	1.6598	1.6804	1.5466		1.2826	1.5655	1.643
10	1.6032	1.5089	1.5684	1.7918	1.226	1.4712	1.5089
11	1.5466	1.8107	1.531	1.4146	1.2136	1.4712	1.3203
12	1.5089	1.773	1.4563	1.4712	.8402	1.3957	1.1317
13	1.5089	1.6598	1.4563	1.2826	1.1203	1.5466	1.2071
14	1.5466	1.4712	1.3443	1.226	1.2136	1.2826	1.1694
15	1.6032	1.358		1.3203	1.2696	1.5089	1.358
16	1.6975	1.3957	1.5684	1.3203		1.5844	1.4712
17		1.5089	1.6804	1.358		1.6221	1.4523
18		1.5089	1.5466	1.358		1.6975	1.4712
19		1.773	1.7918	1.6975	1.8107	1.9805	1.8484
20	2.1285	1.9239	1.8484	1.8484	1.8861	2.0165	1.8861
21	2.0538	1.773	1.773	1.6975	1.7541	1.9805	1.8484
22	1.8671	1.5089	1.6598	1.6598	1.6787	1.7918	1.773
23	1.7177	1.4712	1.358	1.3203	1.4146		1.5089
24	1.3203	1.4563	1.2449	1.226	1.1317	1.226	1.2136
Max	2.1285	1.9239	1.8484	1.8484	1.8861	2.0165	1.8861
Min	1.2449	1.1203	1.1317	1.1317	.8402	1.094	1.1203
Avg	1.5716	1.5441	1.4837	1.4032	1.3203	1.5174	1.4347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 203 / 11 KV HERLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.3734	.3734	.3734	.4108	.3734	.3734
2	.3734	.3361	.3734	.3734	.3734	.3734	.3734
3	.3734	.3361	.3734	.3734	.3734	.3734	.3734
4	.3734	.3361	.4108	.3734	.3734	.4108	.3734
5	.4481	.4108	.4108	.4668	.4108	.4854	.4481
6	.5601	.5975	.5041	.5601	.5601		.5975
7	.6722	.5601	.6722	.5975	.6348	.6348	.6722
8	.6348	.5601	.5975	.5975	.5487	.6348	.6348
9	.5601	.4108	.5228		.6348	.6161	.5975
10	.5228	.4481	.5975	.5788	.5228	.4481	.5601
11	.5228	.5601	.5228	.5228	.4854	.4854	.5601
12	.4481	.6722	.5601	.4108	.4854	.4854	.5228
13	.4481	.5228	.5228	.5415	.5601	.5228	.5601
14	.4481	.5601		.5228	.5228	.5228	.5788
15	.4854	.5228	.5601	.5415	.4854	.4854	.5601
16	.4481	.5228	.5601	.5601	.4854		.5975
17		.4481		.4854	.4481	.5601	.6161
18	.5975	.5788	.6348	.4854	.4854	.5601	.5601
19	.7468	.7842	.7842	.7468	.7095	.8215	.8215
20	.7468	.8029	.8215	.6859	.7468	.8402	.7842
21	.7468	.7468	.7095	.7095	.7468	.7095	.7468
22	.6722	.5415	.6722	.6348	.6348	.6348	.6722
23	.5601	.5415	.4854	.5228	.4854		.5228
24	.4481	.4481	.4854	.4108	.4108	.4294	.4108
Max	.7468	.8029	.8215	.7468	.7468	.8402	.8215
Min	.3734	.3361	.3734	.3734	.3734	.3734	.3734
Avg	.5327	.5259	.5525	.5250	.5223	.5432	.5632

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 204 / 11Kv Halondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	1.3717	1.2407	1.1869	.1543	.1677	.1715
2	.1543	1.406	1.2407	1.2209	.1543	.1677	.1715
3	.1543	1.406	1.2407	1.2209	.1543	.1677	.1715
4	.1543	1.406	1.2742	1.2887	.1543	.1677	.1715
5	.1543	1.4403	1.3077	1.3565	.1543	.1677	.1715
6	.1543	1.5089	1.4754	1.5261	.1543	.1844	.1715
7	.1543	2.0576	1.7269	1.7635	.1543	.2012	.1715
8	.1543	2.4006	1.9281	1.8991	.1543	.2012	.1715
9	.1543	2.4006	1.9113		.1372	.1844	.1715
10	.1696	.1543	.1494	.1677	.1696	.1715	.1844
11	2.5774	.1372	.1494	.1677	2.6282	2.9492	3.0849
12	2.713	.1372	.1311	.1509	2.6452	3.1893	2.9843
13	2.713	.1372	.1311	.1677	2.6113	2.9492	3.0178
14	2.6791	.1372	.1311	.1677	2.5774	2.5034	2.9508
15	2.6452	.1372	.1311	.1677	2.5434	2.0405	2.9508
16	2.5377	.1372		.1677	2.713		2.9675
17		.1372		.1372	2.6452		2.8334
18	2.332	.1677	.1696	.1543	2.4478	2.1026	2.2977
19	.1311	.2012	.1886	.1715	.2012	.2035	.1886
20	.1311	.2012	.1865	.1715	.2012	.1865	.1886
21	.1311	.2012	.1865	.1715	.2012	.1865	.1886
22	.1311	.1844	.1865	.1715	.1677	.1696	.1715
23	.1311	.1844	.1715	.1543	.1677		.1715
24	.1543	1.3108	1.1736	1.1869	.1543	.1844	.1696
Max	2.713	2.4006	1.9281	1.8991	2.713	3.1893	3.0849
Min	.1311	.1372	.1311	.1372	.1372	.1677	.1696
Avg	.8942	.7901	.7469	.6495	.9769	.8784	1.0789

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 205 / 11Kv Rukadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2346	.0328	.0343	.0351	1.749	1.6804	1.6461
2	1.2346	.0328	.0343	.0351	1.749	1.6804	1.6461
3	1.2346	.0328	.0343	.0351	1.749	1.6975	1.6461
4	1.2346	.0328	.0343	.0351	1.749	1.7147	1.6804
5	1.2346	.0328	.0343	.0351	1.749	1.7833	1.7147
6	1.2689	.0328	.0343	.0351	1.7833	1.869	1.749
7	1.4403	.0328	.0514	.0351	1.8519	1.9547	1.9547
8	1.5432	.0328		.0526	2.1948	2.1262	2.0233
9	1.5775	.0328	.0686		2.2634	2.1434	2.1033
10	.0351	.0343	.0343	.0343	.0351	.0343	.0514
11	.0351	2.4691	2.9492	2.9492	.0351	.0343	.0343
12	.0175	2.8121	2.9492	2.8978	.0351	.0343	.0343
13	.0175	2.8807	3.155	2.6578	.0351	.0343	.0343
14	.0175	2.915	2.8807		.0351	.0343	.0343
15	.0175	2.915	2.7435	2.7435	.0351	.0343	.0343
16	.0701		2.8807	2.7263	.0351	.0343	.0514
17		2.8464	2.7435	2.7435	.0351	.0343	.0514
18	.0328	3.006	2.5377	2.7778	.0343	.0526	.0343
19	.0492	.0514	.0526	.0686	.0514	.0526	.0514
20	.0328	.0686	.0514	.0686	.0514	.0526	.0686
21	.0328	.0686	.0526	.0686	.0514	.0526	.0686
22	.0305	.0343	.0526	.0514	.0373	.0351	.0686
23	.0328	.0343	.0351	.0051	.0343		.0514
24	1.2003	.0328	.0343	.0343	1.6118	1.6804	.0686
Max	1.5775	3.006	3.155	2.9492	2.2634	2.1434	2.1033
Min	.0175	.0328	.0343	.0051	.0343	.0343	.0343
Avg	.5924	.8897	1.0208	.9148	.7913	.8196	.7042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 201 / 11 KV Nimshirgaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1677	.0457	.0457	.0328	.125	.1372	.1867
2	.1677	.0457	.0457	.0328	.125	.1372	.1638
3	.1677	.0457	.0457	.0328	.1562	.1372	.2054
4	.1677	.061	.0457	.0328	.1562	.1372	.1802
5	.1829	.061	.0457	.0328	.1562	.1524	.1966
6	.2286	.061	.0457	.0328	.1943	.1981	.2294
7	.3658		.0457	.0492	.3749	.2743	.4024
8	2.4451	.061	.0312	.0492	.4999	.442	.4862
9	.5182	.0457	.0312	.0492	.4999	.5182	.5533
10	.0469	.0492	.0469	.0457	.0492	.0312	.0625
11	.0469	.503	.5937	.5959	.0469	.0312	.0469
12	.0514	.5868	.5937	.6154	.0469	.0312	.0625
13	.0514	.5868	.5624	.5959	.0625	.0469	.0457
14	.0514	.6535	.5344	.5487	.0754	.0312	.061
15	.0457	.4694	.5365	.5182	.0655	.0312	.0526
16	.061	.503	.5365	.5182	.0469	.0625	.0526
17	.0457	.6733	.6203	.5639	.061	.0328	.0625
18	.061	.6653	.4915	.4999	.061	.0655	.0312
19	.061	.0457	.0492	.0312	.061	.0492	.0625
20		.0457	.0492	.0625	.061	.0492	.0625
21	.061	.0457	.0492	.0625	.061	.0655	.0312
22	.061	.0457	.0492	.0312	.061	.0492	.0312
23	.0457	.0457	.0492	.0312	.0457	.0492	.0312
24	.1524	.061	.0457	.0492	.125	.1372	.1475
Max	2.4451	.6733	.6203	.6154	.4999	.5182	.5533
Min	.0457	.0457	.0312	.0312	.0457	.0312	.0312
Avg	.2284	.2351	.2162	.2131	.1341	.1207	.1437



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 202 / 11 KV Alate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3437	.2343	.1875	.1638	.2812	.3281	.3605
2	.3437	.2187	.1875	.1638	.2812	.3281	.3605
3	.3437	.2187	.1875	.1638	.3125	.3281	.3932
4	.3437	.2187	.1875	.1802	.3749	.3437	.3932
5	.4374	.2187	.2031	.1802	.4062	.3749	.4424
6	.5624	.2656	.2343	.1966	.4687	.5624	.5735
7	.9998	.25	.25	.1966	.8749		1.2071
8	1.4373	.2656	.2187	.1802	1.2742	1.4685	1.6263
9	1.4175	.1875	.1875	.1802	1.0311	1.4842	1.5592
10	.1562	.213	.1562	.1875	.1638	.125	.1457
11	.1718	1.6598	1.406	1.6118	.1406	.125	.1619
12	.1718	1.7604	1.531	1.8176	.1406	.125	.1619
13	.125	1.7939	1.5623	1.7147	.25	.1457	.1718
14	.1406	1.7436	1.406	1.6118	.1638	.125	.1562
15	.1406	1.6598		1.4373	.1311	.125	.1562
16	.1562	1.6095	1.643	1.531	.1406	.125	.1715
17	.2031	1.701	1.643	1.5623		.1802	.2187
18	.2187	1.4003	1.0486		.1406	.213	.2187
19	.2656	.2343	.2294		.2031	.2622	.25
20		.2343	.2458	.25	.25	.2622	.3125
21	.3125	.2656	.2294	.2267	.2343		.2812
22	.25	.25	.2458	.2187	.2187		.2187
23	.2343	.2343		.1562	.1718	.1802	.1875
24	.2968	.2343	.2031	.1802	.2187	.2968	.3605
Max	1.4373	1.7939	1.643	1.8176	1.2742	1.4842	1.6263
Min	.125	.1875	.1562	.1562	.1311	.125	.1457
Avg	.3945	.7113	.6088	.6414	.3423	.3575	.4204

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 203 / 11 Kv Atigre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3395	.3395	.3734	.3292	.3395	.3361
2	.3206	.2829	.3206	.3734	.2926	.3206	.3174
3	.3206	.2829	.3206	.3361	.2926	.3206	.3174
4	.3206	.2829	.3206	.3361	.3189	.3206	.3174
5	.3395	.3395	.3206	.3921	.3658	.3395	.3734
6	.3584	.3961	.415	.4108	.4024	.3961	.4108
7	.4338	.4527	.415	.4294	.4024		.4108
8	.415	.4527	.3772	.3734	.3292	.4527	.4294
9	.3721	.4527	.3361	.4108	.2812	.415	.4108
10	.3734	.3547		.415	.2801	.3658	.415
11	.3547	.3361	.3841	.3961	.2452	.3292	.3772
12	.3584	.3547	.3841	.3772	.2263	.3189	.3206
13	.2987	.3547	.3292	.3961	.2075	.2926	.3018
14	.3361	.3174	.439	.3584	.2263	.2804	.3584
15	.3584	.3547	.3772	.3584	.2241	.3292	.3584
16	.3584	.3547	.3772	.3395	.2263	.3292	.3772
17	.2452	.3772	.3734	.3772	.2452	.3734	.3658
18	.3961	.3961	.4108	.3658	.2641	.4108	.439
19	.5093	.5093	.5228	.5487	.4338	.5041	.5487
20		.5093	.5415	.5121	.4904	.5041	.5853
21	.4904	.5093	.5228	.5121	.4904	.5415	.5487
22	.4715	.4527	.4854	.4755	.4527	.4854	.4755
23	.3961	.3772	.4108	.4024	.3772	.3921	.3658
24	.3772	.3584	.3584	.3734	.3658	.3395	.3547
Max	.5093	.5093	.5415	.5487	.4904	.5415	.5853
Min	.2452	.2829	.3206	.3361	.2075	.2804	.3018
Avg	.3715	.3833	.3949	.4018	.3237	.3783	.3965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 206 / Jathar Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242	1.5242	1.5242	1.6004	1.3336	1.5242
2	1.4861	1.5242	1.5242	1.5242	1.5623	1.3336	1.4861
3	1.4861	1.5242	1.5242	1.5242	1.5242	1.3336	1.4861
4	1.4861	1.5242	1.5242	1.5242	1.448	1.3336	1.5242
5	1.5242	1.5242	1.5242	1.5623	1.448	1.3717	1.4861
6	1.5623	1.5242	1.5242	1.6004	1.4861	1.3717	1.4861
7	1.4861	1.5242	1.3336	1.5242	1.5623	1.4098	1.5623
8	1.4861	1.4289	1.3717	1.5242	1.448		1.5242
9	1.4861	1.5242	1.4098	1.5242	1.1431	1.4098	1.5242
10	1.5242	1.5242	1.5242	1.5242	1.0288	1.4861	1.5242
11	1.5242	1.5242	1.5623	1.5623		1.4861	1.4861
12	1.5242	1.5242	1.5432	1.5242		1.4098	1.4861
13	1.4289		1.4861	1.5242		1.5242	1.5242
14	1.5242	1.5242	1.5242	1.5623		1.5242	1.4289
15	1.5242	1.5242	1.5623	1.5623		1.5242	1.5242
16	1.5242	1.5242	1.6004	1.5242	.9907	1.5242	1.5242
17	1.5242	1.5242	1.5242	1.5242	.9526	1.5242	
18	1.5242	1.5242	1.5242	1.5242	1.1431	1.6004	1.4861
19	1.4861	1.5242	1.5623	1.5242	1.1431	1.4861	1.4861
20		1.5242	1.5242	1.5623	1.1431	1.5242	1.6004
21	1.5242	1.5242	1.5242	1.5242	1.3717	1.5623	1.5623
22	1.5242	1.5242	1.5623	1.6004	1.3336	1.5242	1.4861
23	1.5242	1.5242	1.5242	1.6004	1.3336	1.5623	1.5242
24	1.4861	1.5242	1.5242	1.5242	1.6385	1.3336	1.5242
Max	1.5623	1.5242	1.6004	1.6004	1.6385	1.6004	1.6004
Min	1.4289	1.4289	1.3336	1.5242	.9526	1.3336	1.4289
Avg	1.5085	1.5201	1.5139	1.5417	1.3316	1.4562	1.5118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 207 / 11KV ALATE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.7167	.5658	.5975	.5487	.415	.4854
2	.5658	.6602	.5658	.5601	.5487	.3772	.4481
3	.5658	.6602	.5658	.5415	.5853	.3772	.4481
4	.5658	.6036	.5658	.5415	.5853	.415	.4854
5	.6036	.6036	.6036	.5601	.6219	.4904	.5601
6	.7167	.7545	.7545	.5788	.5853	.5281	.5975
7	.7545	.7545	.7545	.6722	.5487	.5281	.6535
8	.7167	.7545	.8215	.6535	.439	.5281	.5975
9	.9054	.9431	.7842	.8029	.439	.7167	.7095
10	1.0269	.9335	1.0374	.9808	.4854	.8413	.9709
11	1.0269	.9335	.9145	.9431	.4854	.8413	.9335
12	.9997	.9709	.9511	.8488	.4854	.8048	.8962
13	.7545	.5975	.695	.6602	.4108	.6401	1.3003
14	.8775	.8402	.823	.7922	.5093	.6024	1.4861
15	1.0374	.9335	.7545	.7922	.4854	1.6096	1.6718
16	1.0374	.7842	.7922	.7167		.7682	1.4784
17	.9431	.8865	.7842	.7167	.415	.7842	.8048
18	.9431	.9431	.7842	.6219	.415	.6722	.695
19	.8299	.9431	.8215	.7316	.5658	.6348	.8413
20		.8488	.8029	.7682	.6036	.7282	.7682
21	.7922	.7545	.8962	.695	.5658	.7095	.8048
22	.9431	.7545	.7655	.695	.5658	.5975	.6219
23	.7545	.6036	.7468	.5487	.4904	.5415	.695
24	.6413	.6097	.5658	.6535	.5121	.415	.4854
Max	1.0374	.9709	1.0374	.9808	.6219	1.6096	1.6718
Min	.5658	.5975	.5658	.5415	.4108	.3772	.4481
Avg	.8089	.7828	.7548	.6947	.5173	.6486	.8099

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 208 / Laxminagar Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0543	.0724	.0724	.056	.0732	.0543	.0747
2	.0543	.0724	.0724	.056	.0366	.0543	.0747
3	.0543	.0724	.0724	.056	.0366	.0543	.0747
4	.0543	.0724	.0724	.056	.0366	.0543	
5	.0724	.1086	.0905	.056	.0732	.0543	.056
6	.0724	.1086	.1086	.056	.0732	.0543	.056
7	.1086	.1086	.1086	.0934	.0366	.0905	.0934
8	.1086	.1086	.0754	.0934	.0762	.0724	.0747
9	.1086	.1086	.0754	.0934	.0366	.0724	.112
10	.0943	.0934	.0943	.0905	.0747	.0732	.0934
11	.0934	.0747	.0914	.0934		.0732	.112
12	.0934	.0934	.0914	.0934		.0754	.112
13	.112	.0934	.0732	.0934		.0914	.0905
14	.0934	.0934	.0914	.0934	.0934	.0732	.0905
15	.0905	.0934	.0377	.0724	.0747	.0732	.0724
16	.1086	.0934	.0754	.0724	.0747	.1097	.0934
17	.0905	.0905	.0934	.0724	.0905	.0934	.0732
18	.1086	.0905	.0934	.1097	.1086	.0934	.0732
19	.0905	.1086	.0934	.0732	.0905	.112	.0732
20		.1086	.0934	.0732	.0905	.0934	.1097
21	.0905	.1086	.0934	.0732	.0905	.0747	.0732
22	.0905	.1086	.0747	.1097	.0724	.0747	.0732
23	.0905	.0905	.0747	.0732	.0724	.0747	.0732
24	.0724	.0724	.0724	.0747	.0366	.0543	.0747
Max	.112	.1086	.1086	.1097	.1086	.112	.112
Min	.0543	.0724	.0377	.056	.0366	.0543	.056
Avg	.0873	.0936	.0830	.0785	.0690	.0750	.0828

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 201 / 11 KV Hingangaon Ag

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.7042	.6154	.7712	.0332	.0381	.0328
2	.0332	.7042	.6478	.7712	.0332	.0381	.0328
3	.0332	.6706	.6478	.7712	.0332	.0381	.0328
4	.0332	.6706	.6478	.7712	.0332	.0381	.0328
5	.0332	.7042	.6478	.7712	.0332		.0328
6	.0332	.7377	.6722	.7712	.0332	.0381	.0324
7	.0332	.8718	.7362	.8718	.0332	.0381	.0324
8	.0332	1.1401	.9172	1.073	.0332	.0381	.0324
9	.0324	1.1736	.9945	1.1736	.032	.0332	.0381
10	.0324	.0335	.0332	.0381	.032	.0332	.0381
11	1.5223	.0335	.0332	.0381	1.4548	1.7238	1.6766
12	1.5223	.0335	.0332	.0381	1.5684	1.7238	1.6766
13	1.5402	.0335	.0332	.0381	1.5364	1.3923	1.6263
14	1.4575	.0335	.0332	.0381	.8642	1.3923	1.5927
15	1.3603	.0335	.0332	.0381	1.2803	1.5581	1.5927
16	1.3279		.0332	.0381	1.4723	1.5912	1.5927
17	1.3413		.0335	.0332	1.5424	1.5684	1.4255
18	1.3077	.0324	.0335	.0332	1.5424	1.587	1.4255
19	.0381	.0324	.0335	.0332	.0381	.0324	.0332
20	.0381	.0324	.0335	.0332	.0381	.0324	.0332
21	.0381	.0328	.0335	.0332	.0381	.0328	.0332
22	.0381	.0328	.0335	.0332	.0381	.0328	.0332
23	.0381	.0324	.0335	.0332	.0381	.0324	
24	.0332	.6882	.5506	.7042	.0332	.0381	.0324
Max	1.5402	1.1736	.9945	1.1736	1.5684	1.7238	1.6766
Min	.0324	.0324	.0332	.0332	.032	.0324	.0324
Avg	.4972	.3846	.3143	.3729	.4923	.5683	.5701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 202 / 11 KV Warana Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6952	.0655	.0819	.0838	.7291	.8048	.7209
2	.6952	.0655	.0819	.0838	.7291	.8048	.7209
3	.6952	.0655	.0819	.0838	.7291	.7712	.7209
4	.6952	.0655	.0819	.0838	.7291	.8048	.7209
5	.6952	.0819	.0819	.0838	.7291	.8383	.7209
6	.6952	.0983	.0819	.0838	.7291	.8383	.7125
7	.7969	.0983	.0972	.0838	.78	.9724	.8421
8	.8648	.0819	.08	.0819	.8987	1.0227	.6316
9	.8322	.0671	.0678	.0655	.9069	1.0682	.9054
10	.048	.0838	.0678	.0655	.064	.0678	.0503
11	.064	1.4083	1.4413	1.5424	.064	.0509	.0492
12	.064	1.4586	1.4413	1.4754	.048	.0509	.0655
13	.0648	1.4083	1.4413	1.3916	.048	.0509	.0655
14	.0648	1.4083	1.4413	1.3413	.048	.0509	.0655
15	.064	1.3245	1.5091	1.2574	.048	.0509	.0655
16			1.4752	1.2407		.0509	.0655
17	.0655		1.4251	1.1869	.0492	.0486	.0678
18	.0655	.08	1.4083	1.1869	.0492	.0486	.0678
19	.0655	.08		.0678	.0655	.0829	.0678
20	.0819	.08		.0848	.0819	.0829	.0848
21	.0819	.081	.0838	.0848	.0655	.0829	.0848
22	.0819	.0819	.0838	.0848	.0655	.0829	.0848
23	.0819	.081	.0838	.0678	.0655	.0663	.0678
24	.7461	.0655	.081	.0838	.7291	.8048	.7209
Max	.8648	1.4586	1.5091	1.5424	.9069	1.0682	.9054
Min	.048	.0655	.0678	.0655	.048	.0486	.0492
Avg	.3611	.3787	.5782	.4957	.3675	.3999	.3487

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 203 / 11KV Kumbhoj Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4024	.4904	.499	.362	.362	.4904
2	.362	.4024	.4527	.4066	.362	.362	.4527
3	.362	.4024	.4481	.4066	.362	.362	.4527
4	.362	.439	.4481	.4066	.362	.3982	.4527
5	.362	.4755	.5601	.4066	.362	.4344	.4904
6	.5792	.5914	.6722	.4435	.5792	.543	.6348
7	.6878	.695	.6653	.6653	.5792	.6154	.6653
8	.5792	.6283	.6283	.5792	.5792	.543	.6219
9	.5316	.5544	.543	.5121	.5373	.543	.543
10	.4961	.5544	.543	.5068	.4656	.543	.5487
11	.4961	.5175	.5068	.5068	.4344	.543	.4344
12	.4961	.5175	.5068	.4706	.4706	.5068	.5121
13	.4656	.5175	.5068	.543	.5014	.5068	.5068
14	.4607	.5175	.5068	.5068	.3898	.5068	.5068
15	.4908	.5914	.5068	.5068	.4298	.5068	.5068
16	.4607		.5068	.543	.4656	.543	.543
17	.4706		.4805	.543	.4706	.543	.543
18	.5792	.7682	.5544	.543	.543	.5792	.543
19	.724	.8501	.7762	.7602	.6878	.6878	.724
20	.724	.8871	.7392	.8688	.724	.7762	.7602
21	.6878	.8501	.6653	.7964	.6401	.7392	.5792
22	.679	.7392	.6653	.724	.5487	.6283	.5792
23	.5601	.6348	.5914	.5792	.439	.5228	.5792
24	.5792	.4024	.5601	.5544	.4706	.3982	.4904
Max	.724	.8871	.7762	.8688	.724	.7762	.7602
Min	.362	.4024	.4481	.4066	.362	.362	.4344
Avg	.5232	.5881	.5635	.5533	.4902	.5289	.5484



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 204 / 11 KV Bahubali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4807	.0492	.0492	.0503	.3978	.3688	.3768
2	.4807	.0492	.0492	.0503	.3978	.3688	.3768
3	.4807	.0492	.0492	.0503	.3978	.4024	.3768
4	.4807	.0492	.0492	.0503	.3978	.4024	.3768
5	.4807	.0492	.0492	.0503	.3978	.4359	.4096
6	.4807	.0492	.0492	.0503	.3978	.4694	.4858
7	.547	.0655	.0648	.0671	.4807	.6203	.5668
8	.6962	.0655	.032	.0492	.5636	.7209	.664
9	.6722	.0503	.0332	.0492	.5601	.6133	.6874
10	.032	.0503	.0332	.0492	.032	.0332	.0492
11	.0324	.8048	.9614	.8886		.0332	.0328
12	.0324	.8886	.9614	.8383		.0332	.0328
13	.0328	.8886	.9614	.8383		.0332	.0328
14	.032	.8886	.9614	.8383		.0332	.0328
15	.0324	.8048	.9448	.8551		.0332	.0328
16	.032		.9448	.8551		.0332	.0328
17	.0328		.9556	.8288		.0324	.0332
18	.0328	.0324	.9054	.8288		.0324	.0332
19	.0492	.0324	.0503	.0497	.0819	.0328	.0497
20	.0655	.0486	.0671	.0663	.0492	.0492	.0497
21	.0655	.0648	.0671	.0663	.0492	.0492	.0497
22	.0655	.0648	.0671	.0663	.0492	.0492	.0497
23	.0492	.0486	.0671	.0497	.0492	.0492	.0497
24	.2652	.0492	.0486	.0503	.3149	.3353	.3605
Max	.6962	.8886	.9614	.8886	.5636	.7209	.6874
Min	.032	.0324	.032	.0492	.032	.0324	.0328
Avg	.2355	.2338	.3509	.3182	.2886	.2193	.2184

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 205 / 11 KV Narande Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.703	.1886	.1865	.1844	1.0288	.7888	.9156
2	.703	.1886	.1865	.1844	1.0288	.8573	.9326
3	.703	.1886	.1865	.1844	1.0288	.8573	.9326
4	.703	.1886	.1865	.1844	1.0288	.8573	.9326
5	.703	.2058	.1865	.1844	1.0288	.9259	.9326
6	.703	.2058	.2035	.1844	1.0288	.9945	.9665
7	.8573	.2058	.1865	.2012	1.1488	1.2003	1.0852
8	1.0117	.1886	.1865	.1886	1.2174	1.2689	1.3226
9	1.1022	.1844	.1886	.1886	1.2887	1.3032	1.3546
10	.1865	.1844	.1886	.1886	.1696	.1886	.1715
11	.1865	1.358	1.4918	1.6289		.1886	.1715
12	.1865	1.4754	1.4918	1.6804		.1886	.1715
13	.1696	1.5089	1.4918	1.6461		.1886	.1715
14	.1865	1.5089	1.4918	1.6118		.1886	.1715
15	.1865	1.3916	1.5947	1.5775		.1886	.1715
16	.1865		1.6118	1.5775		.1886	.1715
17	.1886		1.5424	1.5432		.1865	.1715
18	.1886	.1696	1.4083	1.5432		.1865	.1715
19	.1886	.1696	.2012	.2058	.1886	.1865	.1886
20	.2058	.2035	.2012	.2058	.1886	.1865	.1886
21	.2058	.2035	.2012	.1886	.1886	.1865	.1886
22	.2058	.2035	.2012	.1886	.1886	.1865	3.4465
23	.1886	.1865	.2012	.1886	.1802	.1865	.1886
24	.583	.1886	.1865	.1844	.3086	.7888	.8139
Max	1.1022	1.5089	1.6118	1.6804	1.2887	1.3032	3.4465
Min	.1696	.1696	.1865	.1844	.1696	.1865	.1715
Avg	.4347	.4771	.6335	.6602	.7025	.5195	.6639

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 206 / 11 KV Kumbhoj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0332	.6706	.5761	.6706	.0332	.0381	.0328
2	.0332	.6706	.6401	.6706	.0332	.0381	.0328
3	.0332	.7042	.6401	.6706	.0332	.0381	.0328
4	.0332	.7377	.6401	.6706	.0332	.0381	.0328
5	.0332	.7377	.6722	.6706	.0332	.0381	.0324
6	.0332	.8048	.7274	.6706	.0332	.0381	.0324
7	.0332	.8718	.759	.7712	.0332	.0381	.0324
8	.0332	.9389	.759	.7712	.0332	.0381	.0324
9	.032	.9389	.7293	.7377	.032	.0332	.0381
10	.032	.0335	.0332	.0381	.0316	.0332	.0381
11	1.1523	.0335	.0332	.0381	1.0936	1.2266	1.1736
12	1.3123	.0335	.0332	.0381	1.1069	1.2266	1.2071
13	1.2955	.0335	.0332	.0381	1.1702	.9614	1.2407
14	1.2483	.0335	.0332	.0381	1.2018	1.1603	1.2742
15	1.2163	.0335	.0332	.0381	1.1702	1.2266	1.2742
16	1.1843		.0332	.0381	1.1385	1.2266	1.3077
17	1.2071		.0335	.0332	1.1736	1.1843	1.2929
18	1.1401	.032	.0335	.0332	1.1736	1.1843	1.2929
19	.0381	.032	.0335	.0332	.0381	.0324	.0332
20	.0381	.032	.0335	.0332	.0381	.0324	.0332
21	.0381	.0324	.0335	.0332	.0381	.0324	.0332
22	.0381	.0324	.0335	.0332	.0381	.0328	.0332
23	.0381	.032	.0335	.0332	.0381	.0324	.0332
24	.0332	.6706	.4428	.5365	.0332	.0381	.0324
Max	1.3123	.9389	.759	.7712	1.2018	1.2266	1.3077
Min	.032	.032	.0332	.0332	.0316	.0324	.0324
Avg	.4296	.3700	.2939	.3058	.4076	.4154	.4416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 207 / 11KV Bahubali-Nej Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.1132	.1132	.1294	.1109	.1132	.1132
2	.1109	.1132	.1132	.1109	.1109	.1132	.1132
3	.1109	.1132	.1132	.1109	.1109	.1132	.1132
4	.1109	.1132	.1132	.1109	.1109	.1132	.1132
5	.1109	.132	.132	.1109	.1109	.132	.1132
6	.1109	.132	.1494	.1109	.1478	.132	.1509
7	.1478	.1509	.1494	.1478	.1478	.1698	.1867
8	.1478	.1509	.1307	.1509	.1478	.132	.168
9	.1494	.1294	.1663	.1698	.112	.1109	.1509
10	.1307	.1109	.1663	.132	.1307	.1109	.132
11	.1494	.1006	.1663	.1509	.1307	.1478	.1509
12	.112	.1109	.1663	.1698	.1307	.1294	.1509
13	.1307	.1109	.1663	.132	.1307	.1478	.1509
14	.1509	.1109	.1663	.132	.1307	.1478	.1698
15	.1494	.1109	.1478	.1509	.1494	.1478	.1698
16	.1494		.1294	.1509	.1494	.1663	.1509
17	.1509		.1478	.1478	.1509	.1478	.1663
18	.1509	.168	.1478	.1478	.1509	.1663	.1663
19	.1886	.2054	.1848	.2218	.1698	.1848	.2033
20	.1886	.2263	.2033	.2402	.1886	.1867	.1848
21	.1509	.2075	.1478	.1663	.1698	.168	.1848
22	.132	.1886	.1478	.1478	.132	.1307	.1848
23	.132	.1509	.1109	.1294	.1132	.1307	.1294
24	.1109	.1132	.1132	.1294	.1109	.1132	.112
Max	.1886	.2263	.2033	.2402	.1886	.1867	.2033
Min	.1109	.1006	.1109	.1109	.1109	.1109	.112
Avg	.1370	.1392	.1455	.1459	.1353	.1398	.1512

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 208 / Parshwanath LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.6964	.1715	.3121	.2804		.6001	.4854
4	.6964	.2401	.3467	.5609		.6001	.5895
5	.6964	.2743	.3467	.5609		.6859	.6241
6	.6964	.2915	.3641	.5609		.703	.6588
7	.7287	.5658	.5375	.5609		.6859	.7108
8	.7287	.7545	.5895	.583		.6859	.703
9	.7628	.7712	.6154	.6344		.6802	.703
10	.7455	.7712	.6478	.6173		.6802	.703
11	.7282	.7712		.7202		.6802	.7202
12	.7282	.7712	.6802	.703		.6802	.7202
13	.7455	.7362	.6802	.703		.664	.7202
14	.7282	.7362	.6802	.703		.6316	.703
15	.6935	.5609	.6802	.703		.6316	.703
16	.6935		.6802	.703		.6154	.703
17	.6859		.7186	.6478		.6588	.6478
18	.5487		.7362	.6478		.6762	.6478
23					.0381		
Max	.7628	.7712	.7362	.7202	.0381	.703	.7202
Min	.5487	.1715	.3121	.2804	.0381	.6001	.4854
Avg	.7064	.5704	.5744	.6181	.0381	.6600	.6714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 201 / Tamadalage VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1612	.1848	.1715	.1886	.1698	.2058
2	.1698	.1417	.168	.1543	.1509	.1463	.1372
3	.1509	.1509	.168	.1543	.132	.1448	.1372
4	.1509	.1509	.1663	.1372	.1886	.1417	.1372
5	.1886	.1886	.2218	.1372	.2075	.1772	.1372
6	.2075	.2452	.2772	.2058	.2452	.2614	.2058
7	.3018	.3206	.3361	.2401	.3018	.3206	.2743
8	.2452	.2058	.2772	.2401	.2829	.2829	.2572
9	.2263	.2058	.2587	.2401	.2987		.2572
10	.3361	.2401	.2452	.3174	.2572	.3772	.3395
11	.3361	.2743	.2641	.2829	.2572	.3018	.3772
12	.3326	.2572	.2641	.2987	.2572	.2801	.3547
13	.2241	.2229	.2452	.2614	.2229	.2263	.2452
14	.2241	.2058	.2263	.2427	.2058	.1991	.2641
15	.3174	.2058	.2829	.2801	.2401	.2641	.3584
16	.3361	.2229	.2641	.2987	.2572		.3584
17	.2587	.2229	.3018	.2829	.2401	.3395	.2987
18	.2641	.2427	.2229	.2641	.2452	.4115	.3206
19	.3961	.3361	.3944	.4338	.4527	.5144	.4527
20	.415	.4435	.4287	.4527	.4904	.4458	.5093
21	.3961	.4108	.3944	.4338	.4527	.3944	.4715
22	.3547	.3696	.3429	.415	.3772	.3772	.3961
23	.2641	.2987	.2743	.3018	.3206	.3429	.3395
24	.1886	.1949	.2218	.2058	.2075	.2075	.2401
Max	.415	.4435	.4287	.4527	.4904	.5144	.5093
Min	.1509	.1417	.1663	.1372	.132	.1417	.1372
Avg	.2689	.2466	.2680	.2689	.2700	.2876	.2948

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 202 / Nimshirgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1107	.0185	.0185	.0171	.1107	.1235	.1219
2	.1265	.0185	.0185	.0171	.1265	.1235	.1219
3	.1457	.0185	.0185	.0171	.1265	.1235	.1219
4	.1581	.0185	.0185	.0171	.1562	.1235	.1219
5	.1581	.0185	.0185	.0171	.1739	.1543	.1372
6	.1966		.0185	.0171	.2294	.1852	.2286
7	.3163	.0185	.0185	.0171	.2656	.2623	.2743
8	.3479	.0185	.0181	.0171	.4115	.3704	.381
9	.4374	.0171	.0335	.0171	.4858	.3953	.3963
10	.0156	.0457	.0324	.0343	.0343	.0339	.0358
11	.0156	.381	.4111	.3953	.0171	.0339	.0158
12	.0166	.442	.4843	.4218	.0171	.032	.0156
13	.0158	.4268	.4999		.0171	.0324	.0312
14	.0175	.4268	.4374	.3086	.0343	.0158	.0154
15	.0177	.4268	.4475	.3395	.0343	.0316	.0171
16	.0166	.442	.4687	.3858	.0343	.0316	
17	.0343	.4268	.4843	.4167	.0343	.0316	.0309
18	.0324	.4374	.381	.3963	.0316	.0171	.0324
19	.0183	.0175	.0171	.0173	.0358	.0171	.0328
20	.0183	.0354	.0343	.0173	.0351	.0343	.0324
21	.0183	.0332	.0343	.017	.0358	.0343	.0324
22	.0187	.0177	.0171	.0175	.0358	.0343	.0316
23	.0185	.0181	.0171	.0175	.0171	.0171	.0162
24	.1067	.0183	.0185	.0171	.1067	.1543	.1219
Max	.4374	.442	.4999	.4218	.4858	.3953	.3963
Min	.0156	.0171	.0171	.017	.0171	.0158	.0154
Avg	.0991	.1627	.1653	.1285	.1086	.1005	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 203 / 11 KV Hatkanangale Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0189	.0114	.0171	.061	.0452	.061
2	.0762	.0187	.0114	.0171	.0617	.0452	.061
3	.0762	.0187	.0111	.0171	.061	.0452	.061
4	.0633	.0187	.0111	.0171	.0762	.0452	.061
5	.0937	.0187	.0105	.0171	.0762	.0452	.061
6	.0926	.0187	.0105	.0171	.0762	.0762	.1219
7	.1265	.0187	.0105	.0171	.1067	.1219	.1372
8	.1486	.0187	.0095	.0171	.1486	.1524	.1524
9	.1656	.0171	.0095	.0171	.1524		.1677
10	.0097	.0171	.0152	.0171	.0171	.0171	.0189
11	.008	.1981	.2006	.1852	.0171	.0162	.0154
12	.0114	.2134	.2187	.216	.0171	.0152	.0154
13	.0143	.2134	.2829	.216	.0171	.0158	.0154
14	.012	.2286	.1981	.1698	.0171	.0164	.0154
15	.0151	.1981	.1957	.1543	.0171	.0152	.0171
16	.0114	.1829	.216	.1829	.0171	.0152	.0154
17	.0152	.1829	.1981	.1981	.0171	.0152	.0154
18	.0189	.1614	.1829	.1614	.0189	.0171	.0152
19	.0189	.0143	.0171	.0166	.0185	.0171	.0156
20	.0189	.012	.0171	.0152	.0189	.0171	.0152
21	.0189	.0151	.0171	.0162	.0189	.0171	.0152
22	.0189	.0147	.0171	.017	.0189	.0171	.0152
23	.0189	.0128	.0171	.0171	.0189	.0171	.0152
24	.0602	.0189	.012	.0171	.0446	.0446	.061
Max	.1656	.2286	.2829	.216	.1524	.1524	.1677
Min	.008	.012	.0095	.0152	.0171	.0152	.0152
Avg	.0496	.0771	.0792	.0731	.0464	.0370	.0486



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 204 / 11 KV Ganeshnagar

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0724	.0754	.0514	.0754	.0566	.0514
2	.0566	.0566	.0566	.0514	.0566	.0377	.0514
3	.0566	.0566	.0566	.0514	.0377	.0377	.0514
4	.0566	.0566	.0566	.0514	.0566	.0377	.0514
5	.0566	.0566	.0566	.0514	.0566	.0358	.0514
6	.0754	.0732	.0566	.0514	.0754	.0358	.0686
7	.0754	.0709	.056	.0514	.0754	.0537	.0857
8	.0754	.0754	.0554	.0514	.0754	.0895	.0857
9	.0943	.1029	.112	.0514	.0905		.1029
10	.112	.12		.1097	.0686	.132	.1867
11	.112	.12	.1509	.1307	.1029	.1267	.1307
12	.1478	.1372	.1509	.1132	.1029	.1509	.1463
13	.1494	.1372	.132	.1086	.1029	.132	.1267
14	.1494	.1372	.1509	.132	.0857	.1509	.1254
15	.1307	.1372	.1509	.1402	.1029	.1509	.124
16	.1494	.1543	.1698	.128	.1029	.1509	.1417
17	.1478	.1543	.132	.1097	.1029	.132	.1417
18	.1294	.112	.12	.1132	.0747	.1372	.1132
19	.1509	.1307	.12	.1132	.0943	.1372	.132
20	.132	.1109	.1029	.1132	.1132	.12	.132
21	.1132		.1029	.1132	.0943	.1029	.1132
22	.1132	.0747	.1029	.0943	.0754	.1029	.0943
23	.0943	.0754	.0857	.0754	.0754	.0857	.0943
24	.0754	.0724	.0754	.0686	.0754	.0566	.0686
Max	.1509	.1543	.1698	.1402	.1132	.1509	.1867
Min	.0566	.0566	.0554	.0514	.0377	.0358	.0514
Avg	.1054	.0998	.1013	.0886	.0823	.0980	.1029

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 201 / 11KV Udagaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	.0189	.0762	.0762	1.2193	1.0059	1.1431
2	1.1622	.0189	.0762	.0762	1.2193	.9835	1.1431
3	1.1431	.0189	.0762	.0762	1.2193	.9724	1.1431
4	1.1431	.0189	.0762	.0762	1.2384	.9892	1.1431
5	1.1431	.0187	.0762	.0762	1.2955	1.0513	1.2574
6		.0187	.0762	.0762	1.3908	1.153	1.3717
7		.0189	.0762	.0191	1.5813	1.3056	1.6004
8	1.5242	.0187	.0762	.0762	1.8099	1.5091	1.7528
9	1.6004	.0191	.0181	.0164	1.5242	1.7528	1.5261
10	1.3717	.0191	.0189	.0189	.0762	.0762	.017
11	.9145	2.2862	2.2131	2.2213	.0762	.0762	.0187
12	.0191	2.3624	2.1963	2.3061	.0762	.0762	.0187
13	.0191	2.2862	2.2891	2.2634	.0762	.0762	.0187
14	.0191	2.2862	2.323	2.2119	.0762	.0762	.0168
15	.0191	2.2862	2.2382	2.0008	.0762	.0762	.0175
16	.0187	2.2862	2.146	2.0405	.0762	.0762	.0187
17	.0187	2.191	2.2862	2.1338	.0187	.0762	.0762
18	.0189	2.0195	2.0576	1.8099	.0185	.0762	.0762
19	.0187	.0762	.0762	.0762	.0189	.0762	.0762
20	.0187	.0762	.0762	.0762	.0189	.0762	.0762
21	.0189	.0762	.0762	.0762	.0189	.0762	.0762
22	.0189	.0762	.0762	.0762	.0189	.0762	1.0669
23	.0189	.0762	.0762	.0762	.0189	.0762	1.2574
24	1.1431	.0189	.0762	.0762	1.2384	1.0227	1.0669
Max	1.6004	2.3624	2.323	2.3061	1.8099	1.7528	1.7528
Min	.0187	.0187	.0181	.0164	.0185	.0762	.0168
Avg	.5697	.7747	.7856	.7514	.6001	.5338	.6658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 202 / 11KV Estate

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9052	1.9605	1.9433	1.9052	1.7147	1.2384	1.9052
2	1.7528	1.8111	1.9052	1.829	1.5813	1.1622	1.829
3	1.6766	1.7528	1.8671	1.7909	1.5242	1.1431	1.7528
4	1.6385	1.7918	1.829	1.7909	1.4861	1.1241	1.7528
5	1.6194	1.5497	***	1.7147	1.4289	1.2003	1.7528
6		1.4937	1.7147	1.6004	1.3717	1.2384	1.6766
7		1.6032	1.6766	1.6004	1.4098	1.5051	1.6766
8	1.9052	1.6804	1.8671	1.829	1.5242	1.3146	1.7528
9	2.21	2.2862	2.4006	2.2257	1.2193	1.8099	2.4958
10		2.2862	2.5911	2.3243	.9907	1.9433	2.6783
11	2.6673	2.2862	2.4387	2.4768	1.0288	2.2481	2.6673
12	2.21	2.1338	2.553	2.4768	1.1431	.5716	2.7816
13	2.2862	2.21	2.037	1.9993	1.0288	1.848	2.6292
14	2.5911	***	2.3053	2.1472	1.2193	2.0576	2.572
15	2.5911	2.2862	2.4387	2.4196	1.1431	2.0957	2.5339
16	2.3624	2.3624	2.3053	2.0748	1.1431	2.4006	2.7054
17	2.3624	2.2862	2.2862	2.4006	1.2384		***
18	2.21	2.0005	2.2862	2.2862	1.086	1.6766	2.3053
19	2.4006	2.2291		2.0957	.8573	1.9052	2.572
20	2.4006	2.3434		2.0195	1.2955	1.448	2.2481
21	2.037	2.0957	2.1338	1.8671	1.2955	1.9814	2.3243
22	2.3954	2.0195	1.9814	2.191		2.1338	2.1529
23	2.21	2.191	1.9814	1.9624	1.3908	2.2862	2.2862
24	2.0576	2.21	2.0005	1.9814	2.191	1.3146	2.1338
Max	2.6673	22.9767	17.6231	2.4768	2.191	2.4006	25.2439
Min	1.6194	1.4937	1.6766	1.6004	.8573	.5716	1.6766
Avg	2.1662	2.9103	2.8257	2.0420	1.3179	1.6368	3.1845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 204 / 11KV Mayur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.8484	1.7147	1.5623	1.8671	1.6194	1.7528
2	1.6385	1.6804	1.6004	1.448	1.8099	1.6385	1.6766
3	1.6766	1.5043	1.6004	1.448	1.7147	1.6385	1.6004
4	1.6766	1.4529	1.6194	1.448		1.6004	1.6004
5	1.6575	1.5074	1.6766	1.448	1.5623	1.5813	1.6004
6	1.6385	1.7558	1.7528	1.5242	1.5623	1.5813	1.7528
7	1.6766	1.7924	1.8099	1.829	1.7528	1.6004	1.829
8	1.7147	1.6651	1.829	1.5242	1.6194	1.6004	1.6766
9	2.21	2.3624	2.32	2.2822	1.448	2.2862	2.3434
10	2.6673	2.2862	2.4958	2.3053	1.6004	2.191	2.5149
11	2.7435	2.4387	2.8197	2.9721	1.6004	2.4768	2.7054
12	2.4387	2.3624	2.4958	2.934		2.2862	2.8769
13	2.1338	2.2862	2.1125	2.21		2.3624	2.1502
14	2.4387	2.3624	2.6863	2.8578		2.7054	2.8197
15	2.3624	2.3624	2.8197	2.7625		2.7244	2.8578
16	2.5911	2.3624	2.572	2.934		2.6863	2.6673
17	2.4006	2.5149	2.0957	2.5339		2.6673	2.8578
18	2.191	2.6101	2.1338	2.5149	1.7147	2.4387	2.8006
19	2.1313	2.4006	2.0576	2.0957	1.7147	2.3624	2.191
20	1.9814	2.0005	1.9052	1.9052	1.6385	1.9052	2.0576
21	1.905	1.9052	1.9052	1.9052	1.5623	1.9814	2.1148
22	1.8484	1.829	1.9052	2.0005	1.6575	1.7528	1.9433
23	1.9993	2.0957	2.0576	1.9433	1.6385	2.1338	2.2481
24	2.0576	2.0957	1.9433	1.7528	2.0386	1.6385	1.9052
Max	2.7435	2.6101	2.8197	2.9721	2.0386	2.7244	2.8769
Min	1.6385	1.4529	1.6004	1.448	1.448	1.5813	1.6004
Avg	2.0654	2.0617	2.0804	2.0892	1.6766	2.0608	2.1893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 205 / 11 KV Buvaphan AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.1059	.0934	.1143	.0762	.8954	.9326	1.0669
2	.9526	.0934	.0953	.0762	.8954	.9496	1.0669
3	.9907	.0943	.0953	.0762	.9145	.9175	1.0669
4	1.0479	.1132	.1143	.0762	.9526	.9503	1.0669
5	1.1431	.112	.1143	.0762	.9907	.9945	1.105
6	1.2955	.112	.1143	.0762	1.0479	1.0227	1.1431
7	1.3717	.1307	.1143	.0762	1.2765	1.3413	1.448
8	1.5623	.112	.1143	.0762	1.5813	1.6278	1.7528
9	1.6766	.0762	.112	.132	1.6004	1.9433	1.749
10		.0762	.1494	.1494	.0762	.0762	.1086
11	1.6766	2.1338	2.0622	1.8679	.0762	.0762	.0905
12		2.2862	1.9839	1.9669	.0762	.0762	.112
13			2.1195	1.8299	.0762	.0762	.0724
14		2.1338	1.933	1.7436	.0762	.0762	.0724
15	.0191	2.1338	1.9376	1.5893	.0762	.0762	.0934
16	.0189	2.1338	1.8299	1.7269	.0762	.0762	.112
17	.0189	2.0957	2.0957	1.9433	.0181	.0762	.1143
18	.0179	1.9624	1.829	1.848	.0177	.0762	.1143
19	.1086	.1334	.0762	.1143	.1132	.0762	.1143
20	.112	.1334	.0762	.1143	.0934	.0762	.1524
21	.1132	.1334	.0762	.1143	.0934	.0762	.1524
22	.1132	.1334	.0762	.0953	.0943		
23	.1132	.0762	.0762	.0762	.0943	.0762	1.086
24	.9145	.0943	.1143	.0762	.8764	.9054	.9907
Max	5.1059	2.2862	2.1195	1.9669	1.6004	1.9433	1.7528
Min	.0179	.0762	.0762	.0762	.0177	.0762	.0724
Avg	.9186	.7216	.7260	.6666	.5037	.5468	.6457

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 206 / Jogeswari gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5144	.4954	.4572	.4763	.4382	.4191
2	.4954	.4954	.4572	.4572	.4382	.4382	.4191
3	.4763	.4382	.4572	.4572	.4382	.4191	.4191
4	.4763	.4191	.4763	.4572	.4572	.4191	.4191
5	.4954	.4382	.5335	.4572	.4763	.4572	.5335
6	.5335	.6097	.6097	.5335	.5335	.5144	.6097
7	.6097	.7049	.7049	.5335	.6478	.6036	.6097
8	.6859	.7545	.5335	.6097	.5335	.6036	.7621
9	.6859	.7621	.6535	.7842	.6859	.724	.7095
10	.6859	.6097	.6722	.7842	.6097	.8002	.6722
11	.6859	.7621	.5601	.6908	.6097	.6859	.6908
12	.6097	.6859	.6036	.6535	.5335	.6097	.6535
13	.6097	.4954	.5788	.6348	.4572	.3239	.6161
14	.6097	.5335	.5041	.5975	.6097	.4763	.5228
15	.6097	.5335	.6722	.7023	.6097	.5335	.5601
16	.5228	.5335	.5228	.4854	.4572	.5335	.5228
17	.5228	.4954	.5335	.4572	.3881	.5335	.5716
18	.5415	.5144	.5335	.5144	.4481	.5335	.7621
19	.9522	.9526	.9145	.9335	.9242	.9145	.9907
20	.9808	.9145	.9907		.9335	.9907	1.0288
21	.9431	.9145	.9145	.9335	.9145	.9145	1.0479
22	.9619	.8764	.8383	.8002	.8383	.8383	.9145
23	.6287	.7621	.7621	.6859	.6287	.6097	.6287
24	.5144	.5335	.5335	.5335	.5144	.4572	.4572
Max	.9808	.9526	.9907	.9335	.9335	.9907	1.0479
Min	.4763	.4191	.4572	.4572	.3881	.3239	.4191
Avg	.6389	.6356	.6273	.6154	.5901	.5988	.6475

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 208 / 11 KV Krushna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0572	.1143	.0572	.0572	.0953	.0762
4	.0572	.1143	.0572	.0953	.0953	.0762
5	.0572	.0953	.0953	.0953	.1143	.0953
6	.0953	.0953	.0953	.0953	.1143	.0953
7	.0953	.1143	.0953	.0953	.0953	.0953
8	.0953	.1006	.0953	.0953	.0953	.0953
9	.1524	.1334	.1307	.0953	.1334	.1294
10	.1334	.1524	.1307	.128	.1524	.1509
11	.1524	.1524	.1698	.1509	.1524	.1509
12	.1524	.1524	.1509	.1509	.1524	.1509
13	.1524	.1524	.1509	.1509	.1905	.1509
14	.1524	.1524	.1509	.1509	.1905	.1509
15	.1524	.1524	.132	.1509	.1905	.1509
16	.1509	.1524	.132	.1509	.1905	.1509
17	.1509	.1524	.1334	.1334	.1524	.1524
18	.0924	.0953	.0953	.0953	.1143	.0953
20				1.2765		
Max	.1524	.1524	.1698	1.2765	.1905	.1524
Min	.0572	.0953	.0572	.0572	.0953	.0762
Avg	.1187	.1301	.1170	.1863	.1393	.1229

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 209 / KULKARNI POWER TOOLS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.2883	1.2955	1.0479	1.086	1.0098	1.1431
2	1.1622	1.2136	1.2384	1.0479	1.0479	.9717	1.1431
3	1.1431	1.0498	1.2003	1.0479	.9907	.9335	1.1431
4	1.086	1.0029	1.1812	.9907	.9717	.9145	1.1431
5	1.086	1.0059	1.1431	.9907	.9526	.9145	1.1431
6		1.0608	1.2384	.9907	.9526	.9526	1.1431
7		1.0498	1.105	1.0288	.9717	.9335	1.0479
8	1.0479	1.0456	1.0479	1.0669	.8573	1.0669	1.0479
9	1.5242	1.6766	1.4712	1.8099	.7621	1.6766	1.419
10	1.7147	1.7147	1.9814	1.7528	.7621	1.7528	1.6385
11	1.829	1.7147	1.7718	1.8861	.6859	1.5813	1.7909
12	1.8671	1.7147	1.6032	2.0767	.8002	1.6766	1.9624
13	1.7528	1.7718	1.3957	1.4335	.7621	1.3336	1.6032
14	1.7147	1.7718	2.0005	1.5844	.7621	1.8861	1.9624
15	1.7147	1.9052	1.7909	1.6221	.7621	1.7337	1.8099
16	2.0957	1.9814	1.9814	1.8099		1.7718	1.9052
17	1.5242	1.9433	1.9052	1.6004	.8192	1.6385	1.9052
18	1.4523	1.9052	1.6004	1.4289	.8192	1.3336	1.848
19	1.5655	1.8671	1.4861	1.3717		1.7147	.0762
20	1.419	1.5813	1.1431		.8954	1.4289	1.4098
21	1.307	1.4289	1.2193	1.3146	.9717	1.3336	1.1812
22	1.3256	1.3336	1.2955	1.5242	.9145	1.2384	1.467
23	1.3256	1.6004	1.3336	1.2193	.9145	1.4289	1.4861
24	1.448	1.3908	1.3717	1.2193	1.1241	1.0669	1.2384
Max	2.0957	1.9814	2.0005	2.0767	1.1241	1.8861	1.9624
Min	1.0479	1.0029	1.0479	.9907	.6859	.9145	.0762
Avg	1.4745	1.5008	1.4500	1.3854	.8903	1.3455	1.4024



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 201 / 11KV LIS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0386	.1143		.0953	1.848		2.0195
2	2.0767	.0953		.0953	1.848		2.0386
3	2.0767	.1334		.0953	1.8099		1.9814
4	2.1148	.1334		.0953	1.8099		2.0005
5	2.1529	.1524		.1143	1.8861		2.0957
6	2.4196	.1524		.1143	2.1338		2.2862
7	2.7435	.1715			2.4387		2.7244
8	3.0483	.1334		.1143	2.7435		2.6482
9		.0953	.1143	.0953	2.3624	2.3243	2.1338
10		.0953	.0953	.1143		.0953	.1143
11		4.0581	3.5231	3.7723	.0762	.1334	.1143
12		3.9819	3.9057	3.7342	.0762	.1143	.0762
13		3.9247	3.9819	3.7532	.0762	.1143	.0762
14		3.9628	3.8866	3.7342	.0953	.1143	.0762
15		3.7532	3.5246	3.5437	.0953	.1143	.0953
16		3.8485	3.5818	3.5437	.0953	.1143	.0953
17	.0953		3.658	3.5818	.0953	.0953	.0953
18	.0953		2.6101	2.4387	.0953	.1143	
19	.1334		.0953	.1334	.1524	.1143	.1334
20	.1334		.1334	.1334	.1524	.1334	.1334
21	.1334		.1334	.1143	.1524	.1334	.1334
22	.1334		.1143	.1143	.1334	.1143	2.4577
23			.1143	.1143	.1334	.1143	2.553
24	1.7295	.0953		.0953	1.7718		2.0195
Max	3.0483	4.0581	3.9819	3.7723	2.7435	2.3243	2.7244
Min	.0953	.0953	.0953	.0953	.0762	.0953	.0762
Avg	1.4083	1.4648	1.9648	1.2931	.9601	.2629	1.2218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 202 / 11KV Kothali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.9526		.9907	.0572		.0572
2	.0572	.9526		.9907	.0381		.0572
3	.0572	.9907		1.0098	.0381		.0572
4	.0572	1.0288		1.0098	.0572		.0572
5	.0762	1.0669		1.0288	.0572		.0762
6	.0762	1.086		1.1812	.0762		.0762
7	.0762	1.2003		1.3336	.0762		.0762
8	.0762	1.3146		1.4861	.0762		.0572
9		1.3527	1.4098	1.4098	.0953	.0572	.0762
10		.0762	.0572	.0572		.0762	.0572
11		.0762	.0572	.0762	2.1719	2.3243	2.4577
12		.0762	.0572	.0762	2.1338	2.4196	2.4958
13		.0572	.0572	.0762	2.1719	2.5339	2.6292
14		.0572	.0572	.0762	2.0195	2.3434	2.553
15		.0572	.0381	.0572	1.9624	2.3434	2.4768
16		.0572	.0381	.0572	1.9052	2.1148	2.0386
17	1.9433		.0572	.0572	1.9052	1.9624	2.1719
18	1.8861		.0572	.0762	1.9243	2.0957	
19	.0762		.0762	.0762	.0762	.0572	
20	.0762		.0762	.0953	.0762	.0762	.0953
21	.0762		.0762	.0953	.0762	.0762	.0953
22	.0762		.0762	.0762	.0762	.0762	.0762
23			.0572	.0572	.0762	.0572	.0572
24	.0572	.9717		.9907	.0572		
Max	1.9433	1.3527	1.4098	1.4861	2.1719	2.5339	2.6292
Min	.0572	.0572	.0381	.0572	.0381	.0572	.0572
Avg	.315	.6691	.1499	.5184	.7480	1.2409	.8474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 203 / 11KV Umalwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5967	.0191		.0191	.9526		.7049
2	.6036	.0191		.0191	.9145		.7049
3	.57	.0191		.0191	.9145		.724
4	.5533	.0191		.0191	.9145		.724
5	.5533	.0191		.0191	.9335		.724
6	.6036	.0191		.0191	.9907		.7621
7	.7209	.0191		.0191	1.0669		.9145
8	.9335	.0762		.0191	1.2574		1.105
9		.0191	.0191	.0191	1.2193	1.1431	1.0669
10		.0191	.0191	.0191		.0191	.0191
11		1.7528	1.4243	1.6004	.0191	.0191	.0191
12		1.7147	1.6766	1.7147	.0191	.0191	
13		1.7147	1.6766	1.6385	.0191	.0191	.0191
14		1.7147	1.6385	1.5623	.0191	.0191	.0191
15		1.6385	1.6194	1.5432	.0191	.0191	.0191
16		1.5432	1.5813	1.6004	.0191	.0191	.0191
17	.0191		1.5623	1.4861	.0191	.0191	.0191
18	.0191		1.5242	1.3908	.0191	.0191	.0191
19	.0191		.0191	.0191	.0191	.0191	.0191
20	.0191		.0191	.0191	.0191	.0191	.0191
21	.0191		.0191	.0191	.0191	.0191	.0191
22	.0191		.0191	.0191	.0191	.0191	.5898
23			.0191	.0191	.0191	.0191	.724
24	.5801	.0191		.0191	.9907		.7049
Max	.9335	1.7528	1.6766	1.7147	1.2574	1.1431	1.105
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.3886	.6086	.8558	.5351	.4523	.0940	.4200

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 204 / 11KV Danoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	1.4861		1.6385	.1334		.1143
2	.1143	1.448		1.6385	.1143		.0953
3	.0953	1.5051		1.6385	.1143		.0953
4	.1334	1.6385		1.6766	.1334		.1143
5	.1524	1.7147		1.7147	.1524		.1524
6	.1905	1.8861		1.9052	.1905		.1715
7	.2286	2.3243		2.4958	.1905		.1905
8	.2096	2.8769		3.0293	.1715		.1905
9		2.8769	2.8578	3.1055	.1905	.1715	.1524
10		.1334	.1334	.0953		.1334	.1524
11		.1143	.1143	.1143	3.296	3.3532	3.1817
12		.1334	.1334	.2286	3.5246	3.5056	3.315
13		.1334	.1334	.1143	3.2769	3.6961	3.4675
14		.1143	.1334	.1334	3.4294	3.677	3.7913
15		.1143	.1334	.1334	3.3722	3.6389	3.7342
16		.1143	.1334	.1143		3.6008	2.5911
17	3.2198		.1334	.1143	3.658	3.677	3.0102
18	3.1436		.1334	.1334	3.4294	3.7151	3.0864
19	.2286		.1715	.1715	.1715	.1334	.2096
20	.2096		.2096	.1905	.1905	.1715	.2096
21	.1905		.1905	.1905	.1905	.1715	.2096
22	.1715		.1715	.1715	.1524	.1524	.1715
23			.1334	.1334	.1334	.1334	.1524
24	.1143	1.4861		1.3527	.1334		.1143
Max	3.2198	2.8769	2.8578	3.1055	3.658	3.7151	3.7913
Min	.0953	.1143	.1143	.0953	.1143	.1334	.0953
Avg	.5678	1.1824	.3277	.9264	1.1977	1.9954	1.1947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 205 / 11KV Waranamai

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.4289		1.5051	.0381		.0381
2	.0572	1.3717		1.5051	.0381		.0381
3	.0572	1.4098		1.5242	.0381		.0381
4	.0572	1.448		1.5242	.0381		.0381
5	.0572	1.5242		1.5623	.0381		.0381
6	.0572	1.5813		1.6766	.0381		.0381
7	.0572	1.6385			.0572		.0381
8	.0572	1.7337		1.9052	.0572		.0381
9		1.7718	1.8099	1.9814	.0572	.0572	.0572
10		.0762	.0572	.0381		.0572	.0572
11		.0572	.0381	.0572	2.572		.7621
12		.0572	.0381	.0572	2.5149	2.2291	.7049
13		.0572	.0381	.0381	2.5149	2.7816	2.7816
14		.0572	.0381	.0381	2.5149	2.8387	2.8578
15		.0572	.0381	.0381	2.4006	2.9531	2.7816
16		.0572		.0572	2.553	2.8006	2.7435
17	2.4006		.0572	.0572	2.4577	2.7435	2.4006
18	2.4387		.0381	.0572	2.4006	2.8197	2.4768
19	.0381		.0572	.0381	.0572	.0381	.0572
20	.0381		.0572	.0572	.0572	.0381	.0572
21	.0572		.0572	.0572	.0572	.0381	.0572
22	.0572		.0572	.0381	.0572	.0381	.0572
23			.0572	.0381	.0572	.0381	.0381
24	.0572	1.448		1.5051	.0381		.0381
Max	2.4387	1.7718	1.8099	1.9814	2.572	2.9531	2.8578
Min	.0381	.0572	.0381	.0381	.0381	.0381	.0381
Avg	.3709	.9280	.1742	.6677	.8980	1.3908	.7597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 206 / 11KV Danoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191		.3429	.3429		.4191
2	.381	.4191		.3429	.3429		.381
3	.381	.4572		.3429	.3429		.381
4	.381	.4954		.3429	.362		.381
5	.4572	.5716		.4191	.381		.4382
6	.5525	.5716		.5716	.4191		.5716
7	.5716	.5716		.5906	.4382		.6097
8	.5525	.381		.5716	.4191		.5906
9		.5525	.5144	.5335	.3429	.5335	.5335
10		.5144	.4763	.4954		.5144	.4954
11		.5335	.4954	.5335	.4382	.5144	.4954
12		.5144	.4954	.4572	.4572	.4954	
13		.4954	.4954	.4572	.4382	.4763	.4954
14		.4954	.4954	.4572		.4763	.4954
15		.4954	.4954	.4954	.4191	.4763	.4763
16		.5144	.5144	.4572	.4382	.5144	.4954
17	.5144		.5335	.4763	.4382	.5335	.5525
18	.5716		.6097	.4382	.4572	.5906	.5716
19	.724		.6859	.6287	.4763	.7621	.724
20	.6859		.724	.6668	.4954	.743	.7049
21	.6478		.6859	.6097	.4954	.6478	.6287
22	.5716		.5716	.5144	.4763	.5335	.5144
23			.4954	.3429	.4382	.4954	.4572
24	.4572	.4572		.4572	.381		.4572
Max	.724	.5716	.724	.6668	.4954	.7621	.724
Min	.381	.381	.4763	.3429	.3429	.4763	.381
Avg	.5246	.4976	.5525	.4811	.4200	.5538	.5161

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 207 / 11KV Umalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4191		.4382	.4572		.4382
2	.4763	.4191		.4191	.4382		.4191
3	.4382	.4572		.4191	.4382		.4191
4	.4382	.4954		.4191	.4382		.4572
5	.5335	.5335		.4572	.5335		.4954
6	.6478	.5716		.6097	.6287		.6287
7	.6668	.5716		.6478	.6478		.6097
8	.5525	.5335		.5716	.6097		.5335
9		.4954	.4572	.4954	.5144	.4954	.4954
10		.4763	.4572	.4572		.4572	.4572
11		.4572	.4191	.4763	.4572	.4382	.4572
12		.4763	.4382	.4572	.4001	.4382	.4572
13		.4382	.4572	.4191	.362	.4763	.4572
14		.4954	.4382	.4572	.5335	.4382	.4572
15		.4572	.4382	.4191	.4572	.4572	.4572
16		.5144	.4572	.4572	.4572	.4954	.4572
17	.4954		.4763	.4954	.4382	.4954	.1905
18	.4954		.4954	.5525	.4572	.5144	.1905
19	.6859		.724	.724	.6859	.724	.3048
20	.6859		.7811	.7811	.6859	.7811	.6859
21	.6859		.724	.724	.6097	.724	.5716
22	.5716		.6859	.6287	.5716	.5906	.4763
23			.5335	.5144	.4763	.4954	.4191
24	.5144	.4572		.4572	.4763		.4572
Max	.6859	.5716	.7811	.7811	.6859	.7811	.6859
Min	.4382	.4191	.4191	.4191	.362	.4382	.1905
Avg	.5576	.4864	.5322	.5207	.5119	.5347	.4580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 201 / 11KV RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6219	.5914	.5975	.5847	.567	.499	.5853
2	.6036	.5359	.5975	.567	.5487	.4805	.567
3	.6036	.499	.5975	.5316	.5487	.462	.5487
4	.6219	.5175	.6161	.5138	.567	.462	.567
5	.6401	.5544	.6348	.4961	.6036	.499	.5853
6	.6584	.6838	.7095	.6089	.6219	.6348	.6036
7	.695	.8131	.8029	.6626	.7316	.7762	.7682
8	.7865	.8686	.8029	.7059	.7316	.7762	.7316
9	.8029	.8413	.7095	.7682	.7392	.7392	.7947
10	.7655	.8596	.8589	.823	.8131	.8029	.8686
11	.8589	.8413	.8215	.8048	.8131	.8775	.8131
12	.9335	.8413	.8029	.7865	.7762	.8029	.8501
13	.8589	.823	.4668	.7865	.7947	.8962	.8131
14	.8402	.823	.8029	.7499	.7577	.8775	.8316
15	.8589	.823	.8029	.7133	.7023	.8048	.8501
16	.8775	.8596	.8775	.7682	.8316	.8048	.8686
17	.8501	.9149	.8962	.7865		.8596	.8962
18	.961	.9709	.8589	.8779	.8871	.8779	.9709
19	1.1273	1.1016	1.0829	1.0242	1.0349	1.1157	1.1576
20	1.0349	1.0829	1.0829	1.0608	1.0719	1.1157	1.1763
21	.9979	.9896	.9896	.9145	.9055	.9694	1.0082
22	.8686	.7842	.8589	.8048	.8131	.7865	.8215
23	.7023	.7095	.7468	.6767	.6653	.695	.6908
24	.6219	.6099	.6161	.5895	.567	.5359	.567
Max	1.1273	1.1016	1.0829	1.0608	1.0719	1.1157	1.1763
Min	.6036	.499	.4668	.4961	.5487	.462	.5487
Avg	.7996	.7891	.7764	.7336	.7432	.7563	.7890



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 202 / 11KV PINGARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5041	.5415	.4961	.5121	.4668	.5304
2	.4938	.4854	.5228	.4784	.4938	.4294	.5121
3	.4938	.4668	.5228	.4607	.4938	.4108	.4938
4	.5304	.4481	.5228	.4607	.5121	.4108	.5121
5	.5487	.4854	.5975	.4607	.5121	.4854	.5304
6	.5853	.6161	.6722	.6268	.5487	.5601	.5487
7	.7499	.7842	.8215	.6805	.7682	.7282	.8048
8	.7316	.7842	.7842	.7619	.8413	.8029	.8413
9	.7095	.7316	.7655	.7316	.7095	.7468	.8962
10	.5975	.7316	.8402	.6767	.5601	.7095	.6722
11	.6535		.7468	.6401	.5601	.6722	.6535
12	.4668	.7316	.6722	.5487	.5975	.6348	.6161
13	.5228	.6767	.6722	.4938	.5415	.6535	.6348
14	.5788	.6219	.6161	.4755	.5788	.5415	.6348
15	.5601	.6219	.5975	.4572	.5601	.5415	.5788
16	.5788	.6219	.6908	.5304	.5228	.6036	.6348
17	.5041	.5975	.5415	.5121	.5041	.6219	.5975
18	.5975	.6161	.5041	.6401	.5975	.695	.6535
19	.7842	.8962	.8215	.823	.8029	.823	.8215
20	.8402	.8775	.8589	.8596	.8215	.8413	.8589
21	.8029	.8029	.8029	.7499	.7282	.8048	.8402
22	.7655	.7468	.7468	.7499	.7468	.7499	.7468
23	.6535	.6535	.6535	.6401	.6161	.6584	.6201
24	.5121	.5415	.5601	.5028	.5121	.5041	.5304
Max	.8402	.8962	.8589	.8596	.8413	.8413	.8962
Min	.4668	.4481	.5041	.4572	.4938	.4108	.4938
Avg	.6156	.6541	.6698	.6024	.6101	.6290	.6568

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 203 / 11KV SHAHUNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4755	.4435	.4668	.4252	.439	.4066	.4572
2	.4572	.4066	.4668	.4075	.4207	.3696	.439
3	.4572	.3881	.4668	.4075		.3511	.439
4	.4938	.4251	.4668	.3898	.439	.3696	.4572
5	.5304	.4435	.5228	.3721	.4572	.4066	.4755
6	.5487	.5914	.5788	.5194	.4755	.499	.5121
7	.5853	.6468	.6161	.5975	.6219	.6468	.6036
8	.6219	.6653	.5601	.5973	.6219	.6283	.6401
9	.5601	.5487	.4481	.5304	.462	.5228	.499
10	.5415	.4938	.4294	.4755	.3881	.4668	.4435
11	.4668	.4024	.4108	.439	.3696	.3361	.4251
12	.4108	.3658	.4294	.4251	.3326	.4108	.4251
13	.4108	.3475	.4668	.4024	.3696	.3921	.4251
14	.4294	.3658	.415	.3841	.3881	.3921	.4251
15	.4294	.3109	.4294	.4024	.3881	.3658	.462
16	.4294	.3475	.4481	.439	.3881	.4024	.462
17	.4435	.3921	.4481	.439	.3881	.4755	.4854
18	.5729	.5228	.5228	.4938	.4805	.5487	.5415
19	.7762	.7468	.7468	.7316	.6838	.7133	.7655
20	.7577	.7282	.7282	.7865	.7392	.7865	.8029
21	.7577	.7842	.7095	.695	.7207	.7316	.7468
22	.7392	.6722	.6908	.6584	.6468	.6767	.6722
23	.6099	.5601	.5788	.5304	.5359	.567	.5493
24	.4755	.4805	.4854	.4508	.439	.4251	.4572
Max	.7762	.7842	.7468	.7865	.7392	.7865	.8029
Min	.4108	.3109	.4108	.3721	.3326	.3361	.4251
Avg	.5409	.5033	.5222	.5000	.4868	.4955	.5255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 201 / 11KV Takawade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	.7042	.6706	.7449	.032	.0335	.0257
2	.032	.7682	.6706	.7449	.032	.0335	.0343
3	.032	.7682	.6706	.7449	.032	.0335	.0257
4	.032	.8002	.6706	.7449	.032	.0335	.0343
5	.032	.8802	.7377	.7611	.032	.0335	.0257
6	.032	1.0277	.8048	.7611	.032	.0335	.0257
7	.032	.9995	1.1401	.9393	.032	.0335	.0274
8	.032	1.1523	1.1736	1.1498	.032	.0335	.0257
9	.032	1.1523	1.2742	1.1174	.032	.0335	.0297
10	.0335	.0427	.032	.0305	.0257		.0305
11	1.6766	.0297	.032		1.4899	1.6164	1.8067
12	1.6766	.0257	.032	.0305	1.5384	1.6004	1.8564
13	1.6766	.0495	.032	.0305	1.6194	1.6164	1.8067
14	1.576	.0396	.032	.0305	1.6356	1.6712	1.7901
15	1.576	.0396	.032	.032		1.5844	1.757
16	1.4754	.0343	.032	.032	1.5089	1.5684	1.757
17	1.3763	.0671	.0257	.032	1.5424	1.4089	1.6164
18	1.2643	.0335	.0297	.032	1.5089	1.4575	1.5364
19	.032	.0335	.032	.032	.0335	.032	.032
20	.032	.0335	.0396	.032	.0335	.032	.032
21	.032	.0671	.0257	.032	.0335	.0297	.032
22	.032	.0671	.0343	.032	.0335	.0257	.032
23	.032	.0671	.0343	.032	.0335	.024	.032
24	.032	.7042	.6706	.7287	.032	.0335	.024
Max	1.6766	1.1523	1.2742	1.1498	1.6356	1.6712	1.8564
Min	.032	.0257	.0257	.0305	.0257	.024	.024
Avg	.5338	.3995	.3720	.3847	.4938	.5653	.5998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 202 / Shirdhon, Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6226	.0328	.1006	.0257	.9339	.8718	.8259
2	.6226	.0328	.1006	.0257	.9339	.8718	.8421
3	.6554	.0328	.1006	.0257	.9831	.8718	.8421
4	.6554	.0328	.1006	.024	.9831	.8718	.8421
5	.6554	.0328	.1006	.0257	.9831	.8718	.8421
6	.6718	.0328	.1006	.0297	1.0159	.9389	.8421
7	.6718	.0328	.1006	.0297	1.065	1.0059	.8907
8	.7537		.1006	.0297	1.0486	1.073	.9231
9	.8029	.0328	.1341	.0048	1.0978	1.1401	.9717
10	.0335	.0396	.0328	.0305	.0257		.0305
11	.0335	1.247	1.7204	1.6575	.0495	.0328	.0305
12	.0335	1.587	1.7368	1.757	.0533	.0328	.0305
13	.1006	1.6194	1.6549		.0495	.0328	.0305
14	.1006	1.6356	1.6221	1.6244	.0495	.048	.0305
15	.1006	1.6194	1.6221	1.6549	.0495	.0366	.0305
16	.0671	1.5708	1.6057	1.6057	.1006	.0328	.0305
17	.0328		1.5061	1.5893	.1006	.0297	.0492
18	.0354	1.4754	1.4899	1.4243	.1006	.0396	.0492
19	.0328	.1006	.0297	.0328	.0335	.0297	.0328
20	.0328	.1006	.0495	.0328	.0335	.0297	.0328
21	.0328	.1006	.0495	.0328	.0335	.0257	.0328
22	.0328	.1006	.0366	.0328	.0335	.0229	.7537
23	.0328	.1006	.0257	.0328	.0335	.0229	.7537
24	.6226	.0328	.1006	.0229	.9339	.8718	.8097
Max	.8029	1.6356	1.7368	1.757	1.0978	1.1401	.9717
Min	.0328	.0328	.0257	.0048	.0257	.0229	.0305
Avg	.3098	.5269	.5926	.5109	.4469	.4263	.4396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 204 / 11KV Shiradhon Takawade  
Vlg Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5487	.4024	.4344	.4572	.4359	.4572
2	.4961	.5373	.4024	.4344	.4656	.4359	.4572
3	.5194	.5731	.4024	.4163	.4706	.4359	.4525
4	.5487	.5731	.4024	.4163	.4656	.4359	.4706
5	.567	.5731	.4359	.4163	.4755	.4694	.4706
6	.567	.5731	.4694	.4887	.439	.503	.5068
7	.5847	.5731	.4694	.5249	.4298	.503	.5973
8	.5847	.5609	.4694	.5068	.5194	.503	.567
9	.5304	.5853	.4694	.4784	.5304	.4694	.5493
10	.503	.567	.6024	.4887	.5316		.5792
11	.5365		.6089	.1086	.5083	.5194	.5068
12	.503	.5973	.6379	.5121	.5493	.5304	.5068
13	.4024	.5138	.3582	.4755	.4252	.4298	.5068
14	.503	.4961	.5853	.4706	.4252	.5194	.5068
15	.503	.5784	.5487	.4656	.4961	.5853	.5068
16	.503	.5609	.5316	.5083	.4359	.6733	.5068
17	.5853	.503	.5784	.4607	.1006	.6024	.7164
18	.6201	.4694	.5847	.4961	.4024	.5316	.7392
19	.7796	.6371	.8145	.7164	.6706	.7783	
20	.8048	.6706	.7964	.7164	.7377	.7602	
21	.7339	.6706	.724	.6878	.7377	.7602	
22	.6984	.6036	.6697	.6584	.6036	.6516	.6908
23	.6154	.4694	.362	.462	.503	.5487	.5249
24	.4938	.5138	.4359	.5249	.4572	.4359	.4887
Max	.8048	.6706	.8145	.7164	.7377	.7783	.7392
Min	.4024	.4694	.3582	.1086	.1006	.4298	.4525
Avg	.5706	.5630	.5317	.4945	.4932	.5443	.5385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3189	.394	.4024	.4207	.3018	.4252
4	.3292	.4024	.4024	.4252	.3018	.4207
5	.3366	.4207	.4024	.4252	.3018	.4207
6	.3366	.4207	.4359	.4252	.3018	.4207
7	.3366	.4252	.4024	.4252	.3018	.4252
8	.3366	.4252	.4024	.4252	.3018	.4252
9	.3292	.4252	.4024	.4207	.4024	.4031
10	.4024	.4207	.4252	.4344		.4344
11	.4024	.4252	.443		.4344	.4344
12	.4024	.4207	.439	.4144	.4252	.4344
13	.4024	.4031	.4252	.4344	.439	.4344
14	.4024	.4207	.4252	.4344	.4887	.4525
15	.4024	.3856	.443	.439	.4252	.4298
16	.4024	.4075	.4252	.4344	.4344	.4344
17	.4298	.4024	.4207	.4207	.4031	.443
18	.2033	.2012	.2058	.1949	.2279	.056
Max	.4298	.4252	.443	.439	.4887	.4525
Min	.2033	.2012	.2058	.1949	.2279	.056
Avg	.3609	.4000	.4064	.4116	.3661	.4059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2258	.1829	.2683	.2012	.2012	.2012
4	.2458	.2149	.2683	.1844	.2012	.285
5	.2743	.2561	.2683	.1844	.2012	.285
6	.2258	.2561	.2683	.1844	.2012	.285
7	.2743	.2926		.1844	.2347	.285
8	.2743	.3109	.3353	.2401	.2683	.285
9	.2658	.3841	.3353	.3185	.3018	.285
10	.2683	.3521	.3841	.2896		.2439
11	.3018	.3521	.3841	.2896	.3326	.2896
12	.3018	.3521	.3898	.2896	.2824	.2896
13	.3018	.3353	.4024	.2896	.2824	.3125
14	.3018	.3688	.3841	.2896	.2824	.3125
15	.3018	.3688	.394	.3582	.3403	.3048
16	.3018	.3688	.4024	.3582	.3403	.3125
17	.3475		.3688		.3185	.3881
18	.3292	.1006	.3688	.3475	.3018	.3281
Max	.3475	.3841	.4024	.3582	.3403	.3881
Min	.2258	.1006	.2683	.1844	.2012	.2012
Avg	.2839	.2997	.3482	.2673	.2727	.2933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322	.0316	.0474	.052	1.2955	1.0749	.8642
2	.8002	.0316	.0316	.0526	1.2955	1.0517	.8642
3	.8002	.0474	.0316	.0532	1.2631	1.0631	.8421
4	.8002	.0316	.0474	.0537	1.278	1.1462	.8642
5	.8322	.0316	.0474	.0543	1.2955	1.1765	.8962
6	.8642	.0316	.048	.0549	1.3603	1.2254	.9922
7	1.0242	.0474	.0474	.0554	1.4575	1.3306	1.0883
8	1.1043	.0474	.0474	.056	1.5074	1.4937	1.1961
9	1.1544	.0474	.0474	.0377	1.4723	1.6032	1.2308
10	.0316	.0514	.048	.0514	.032	.0686	.08
11	.0633	2.4792	2.7046	2.4806	.052	.0633	.0867
12	.0633	2.5941	2.9973	2.4966	.0526	.048	.0701
13	.0633	2.6578	2.8704	2.5606	.0532	.0474	.0709
14	.0633	2.758	2.8117	2.4806	.0537	.0474	.0537
15	.0633	2.8054	2.8959	2.4291	.0543	.0474	.0543
16	.0633	2.7801	2.8166	2.4249	.0549	.048	.0732
17	.0316	2.6797	2.809	2.332	.0554	.048	.0739
18	.0316	2.2138	2.726	2.1052	.056	.0633	.0747
19	.0316	.048	.0566	.048	.0566	.0633	.0566
20	.0316	.0474	.0686	.0474	.0514	.0474	.0686
21	.0316	.0474	.052	.0474	.052	.0474	.052
22	.0474	.0474	.0526	.0474	.0526	.0474	1.0692
23	.0316	.0474	.0532	.048	.0532	.048	1.0808
24	.7682	.0316	.0474	.0514	1.3123	1.0974	.8962
Max	1.1544	2.8054	2.9973	2.5606	1.5074	1.6032	1.2308
Min	.0316	.0316	.0316	.0377	.032	.0474	.052
Avg	.4012	.9015	.9752	.8384	.5945	.5416	.5291



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 202 / 11 kv Bastwad feeder AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.073	.0332	.0335	.0347	1.576	1.3696	1.1603
2	1.0395	.0332	.0335	.0351	1.5249	1.3672	1.1401
3	1.0395	.0332	.0335	.0354	1.5074	1.382	1.1401
4	1.073	.0332	.0335	.0358	1.5402	1.3969	1.1736
5	1.1401	.0332	.0335	.0362	1.6057	1.4118	1.2071
6	1.1736	.0332	.0335	.0366	1.6842	1.5364	1.2742
7	1.3077	.0332	.0335	.037	1.8842	1.6817	1.3748
8	1.4419	.0332	.0335	.0373	1.9784	1.8111	1.5729
9	1.4586	.0332	.0335	.0377	1.9559	1.8673	1.6057
10	.0332	.0343	.0335	.0343	.0332	.0343	.0335
11	.0332	2.3232	2.5659	2.6216	.0347	.0335	.0347
12	.0332	2.6116	2.6292	2.6825		.0328	.0351
13	.0332	2.3525	2.6755	2.7831	.0354	.0335	.0354
14	.032	2.3878	2.6147	2.7496	.0358	.0335	.0358
15	.0332	2.3365	2.7511	2.6825	.0362	.0335	.0362
16	.0332	2.3205	2.6703	2.4966	.0366	.0335	.0366
17	.0332	2.251	2.7905	2.5194	.037	.0335	.037
18	.0332	2.2672	2.6886	2.3594	.0373	.0328	.0373
19	.0332	.0328	.0377	.0335		.0335	.0377
20	.0332	.0328	.0343	.0335	.0343	.0335	.0343
21	.0332	.0328	.0347	.0328	.0347	.0335	.0347
22	.0332	.0328	.0351	.0335	.0351	.0335	1.3847
23	.0332	.0335	.0354	.0328	.0354	.0335	1.3998
24	1.1065	.0332	.0332	.0343	1.576	1.3546	1.1904
Max	1.4586	2.6116	2.7905	2.7831	1.9784	1.8673	1.6057
Min	.032	.0328	.0332	.0328	.0332	.0328	.0335
Avg	.5132	.8076	.9138	.8940	.7845	.6520	.6688

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 203 / HERWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6161	.5975	.5281	.4508	.4904	.4681	.5281
2	.5601	.6161	.5281	.4207	.4715	.4382	.5281
3	.5601	.6348	.5093	.4252	.4904	.443	.5093
4	.5975	.6535	.5281	.4656	.5093	.4477	.5281
5	.6348	.6722	.5658	.543	.5281	.4887	.5658
6	.7095	.7095	.6413	.6767	.6413	.7133	.6413
7	.7655	.7282	.6979	.7392	.7545	.6838	.679
8	.7095	.7095	.6224	.6908	.6602	.7655	.7356
9	.7095	.6161	.6036	.6036	.6413	.679	.6602
10	.6722	.4801	.5281	.583	.6413	.4973	.6413
11	.6535	.6241	.4334	.7545	.5721	.6224	.4854
12	.5788	.6485	.631	.679	.5609	.5658	.4908
13	.5415	.567	.5493	.6224	.5847	.5658	.4784
14	.5601	.591	.5731	.5658	.5373	.6036	.4477
15	.5415	.5792	.5973	.6602	.5973	.6413	.5973
16	.5975	.6219	.5304	.679	.6219	.679	.6401
17	.6722		.6468	.7167	.5544	.7167	.6099
18	.7095	.7545	.7282	.5658	.5975	.7167	.7282
19	.7468	.8865	.8488	.7356	.8299	.7545	.8865
20	.8589	.7545	.7545	.6413	.6859	.7167	.7202
21	.7842	.8299	.7455	.6413	.7108	.679	.7455
22	.7468	.7167	.6836	.6036	.6661	.6413	.6661
23	.5415	.6224	.6024	.5658	.5847	.5658	.5847
24	.6348	.5975	.5658	.4458	.5093	.5487	.5658
Max	.8589	.8865	.8488	.7545	.8299	.7655	.8865
Min	.5415	.4801	.4334	.4207	.4715	.4382	.4477
Avg	.6543	.6614	.6101	.6031	.6017	.6101	.6110

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 204 / 11 kv water works feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.1029	.0857	.0867	.0857	.0867	.0857
2	.0838	.1029	.0857	.0876	.0857	.0876	.0857
3	.0838	.1029	.0857	.0886	.0857	.0886	.0857
4	.0838	.1029	.0857	.0895	.0857	.0895	.0857
5	.0838	.1029	.0857	.1086	.0857	.0905	.0857
6	.0838	.1029	.0857	.0914	.0857	.0914	.0857
7	.0838	.1029	.0857	.0924	.0857	.0924	.0857
8	.0848	.1029	.0857	.0934	.0857	.0934	.0857
9	.1029	.1029	.0857	.0943	.0686	.1132	.0857
10	.1029	.0686	.0857	.0686	.0857	.0514	.0686
11	.0686	.0693	.0693	.0857	.0693	.0857	.0693
12	.0686	.0876	.0876	.0857	.0526	.0857	.0876
13	.0857	.0886	.0709	.0857	.0709	.0857	.0886
14	.0686	.0895	.0895	.0857	.0716	.0848	.0895
15	.0686	.0905	.0905	.0857	.0724	.0857	.0905
16	.0686	.0914	.0914	.0857	.0732	.0857	.0914
17	.0686	.0924	.0924	.0857	.0554	.0857	.0739
18	.0686	.0857	.0934	.0857	.0934	.0857	.0934
19	.0686	.0857	.0943	.0857	.0943	.0857	.0943
20	.0686	.0857	.0857	.0857	.0857	.0857	.0857
21	.1029	.0857	.0867	.0857	.0867	.0857	.0867
22	.1029	.0857	.0876	.0857	.0876	.0857	.0876
23	.1029	.0857	.0886	.0857	.0886	.0857	.0886
24	.0867	.1029	.0857	.0857	.0857	.0857	.0857
Max	.1029	.1029	.0943	.1086	.0943	.1132	.0943
Min	.0686	.0686	.0693	.0686	.0526	.0514	.0686
Avg	.0823	.0925	.0863	.0875	.0803	.0868	.0855

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 205 / 11 Kv Herwad Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1873	.0474	.0492	.0347	1.5074	1.4737	1.3592
2	1.1561	.0474	.0328	.0351	1.5074	1.4723	1.3108
3	1.1561	.0316	.0497	.0354	1.5581	1.4883	1.326
4	1.1561	.0316	.0492	.0358	1.5402	1.5223	1.278
5	1.1717	.0316	.0492	.0362	1.5729	1.5565	1.326
6	1.1873	.0316	.0492	.0366	1.6057	1.6461	1.4091
7	1.2498	.0633	.0492	.0554	1.7204	1.8665	1.5402
8	1.4998	.0633	.0492	.0747	1.8023	2.0351	1.757
9	1.6004	.0633	.0497	.0566	1.9334	2.1313	1.7695
10	.032	.0686	.0492	.0514	.0492	.0686	.0655
11	.032	2.2885	2.3405	2.3868	.0693	.0492	.052
12	.032	2.4539	2.4539	2.3266	.0526	.0492	.0526
13	.032	2.5337	2.4451	2.2348	.0532	.0492	.0709
14	.0316	2.5252	2.561	2.2283	.0537	.0492	.0358
15	.032	2.5158	2.5339	2.2283	.0543	.0655	.0362
16	.0316	2.524	2.5423	2.1628	.0549	.0492	.0549
17	.0316	2.5318	2.5318	2.13	.0554	.0492	.037
18	.0474	2.2119	2.4272	2.13	.056	.0655	.0373
19	.0633		.0566	.0655	.0943	.0655	.0754
20	.0633	.0492	.0514	.0492	.0514	.0655	.0686
21	.0633	.0492	.052	.0492	.052	.0492	.0693
22	.0474	.0492	.0526	.0492	.0351	.0492	1.4899
23	.0474	.0492	.0354	.0492	.0532	.0492	1.5061
24	1.2029	.0474	.0492	.0343	1.5402	1.4403	1.3435
Max	1.6004	2.5337	2.561	2.3868	1.9334	2.1313	1.7695
Min	.0316	.0316	.0328	.0343	.0351	.0492	.0358
Avg	.5481	.8830	.8587	.7740	.7114	.7252	.7530

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 206 / 11KV Kurundwad Urban

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8855	.7287	.7865	.8669	.8288	.9189	.8848
2	.8223	.7611	.7625	.7888	.7865	.7888	.8785
3	.8223	.7611	.7625	.7973	.7956	.7796	.8619
4	.7907	.7449	.7956	.8059	.8288	.8238	.8951
5	.8539	.7773	.8288	.8688	.8192	.8688	.9282
6	.9172	.8097	.9282	1.0974	.9175	1.0425	.9503
7	1.012	.9717	1.1271	1.1458	1.0277	1.1458	1.0486
8	1.1069	1.1012	1.1934	1.3256	1.1469	1.307	1.1271
9	1.2003	1.2955	1.2597	1.4901	1.326	1.4523	.9282
10	1.2803	1.4746	1.3592	1.3889	1.1797	1.3203	.9175
11	1.166	1.387	1.3523	1.2616	1.283	1.2929	1.3696
12	1.1523	1.4548	1.4198	1.1469	1.262	1.2125	1.4899
13	.9602	1.1163	1.1163	.9175	.9745	.9614	1.134
14	.9922	1.0387	.985	.852	.9492	1.0159	.985
15	1.004	1.2127	1.2308	1.0814	1.2127	1.1142	1.2851
16	.9717	1.4815	1.4266	1.1142	1.2803	1.2125	1.4266
17	.9393	1.5339	1.4045	1.1603	1.3306	1.278	1.3121
18	.9393	1.3435	1.643	1.278	1.4377	1.3763	1.5497
19	1.0364	1.6575	1.7918	1.5249	1.6975	1.5402	1.8107
20	1.1336	1.4746	1.4575	1.4918	1.406	1.4918	1.5432
21	1.0688	1.3108	1.4043	1.2452	1.3523	1.3108	
22	1.004	1.2452	1.3321	1.1469	1.3321	1.2597	1.3496
23	.8745	1.2266	1.1871	1.0608	1.1517	.9945	1.1517
24	.9488	.7125	.8192	1.0288	.8684	.9431	.9175
Max	1.2803	1.6575	1.7918	1.5249	1.6975	1.5402	1.8107
Min	.7907	.7125	.7625	.7888	.7865	.7796	.8619
Avg	.9951	1.1509	1.1822	1.1202	1.1331	1.1438	1.1628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 207 / BASTWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2279	.2195	.156	.1829	.208	.1829
2	.1848	.2629	.2033	.1578	.1646	.1578	.1646
3	.1867	.2454	.2012	.1595	.1646	.1595	.1646
4	.2241	.2804	.2195	.1612	.1829	.1612	.1829
5	.2987	.2804	.2378	.2172	.2195	.2172	.2012
6	.3734	.3155	.2926	.3109	.2561	.3109	.2926
7	.3475	.333	.3475	.2957	.2926	.3142	.3475
8	.3109	.3189	.2926	.2801	.3292	.3547	.3658
9	.2804	.2658	.2926	.2452	.3292	.3206	.2926
10	.2629	.2401	.2926	.2572	.2926	.2572	.2743
11	.2629	.208	.2254	.2561	.2254	.2926	.2427
12	.2865	.2629	.2279	.2402	.2279	.2743	.2279
13	.2804	.2658	.2481	.2561	.2303	.2743	.2658
14	.2629	.2328	.2149	.2378	.1791	.2561	.2149
15	.2279	.2172	.2172	.2561	.1629	.2378	.2715
16	.2481	.2195	.2378	.2743	.2012	.2926	.2378
17	.2658	.2218	.2218	.3109	.2218	.3109	.2218
18	.2658	.2743	.2427	.3292	.2614	.3292	.2241
19	.3189	.4024	.3584	.4024	.3584	.4024	.3584
20	.3544	.3658	.3086	.3658	.3429	.3658	.3258
21	.3155	.3658	.2947	.3658	.3467	.3292	.2947
22	.3012	.3109	.298	.2926	.298	.2926	.298
23	.2481	.2926	.2303	.2561	.2481	.2561	.2303
24	.2195	.2103	.2378	.1886	.2195	.2229	.2195
Max	.3734	.4024	.3584	.4024	.3584	.4024	.3658
Min	.1848	.208	.2012	.156	.1629	.1578	.1646
Avg	.2720	.2759	.2568	.2614	.2474	.2749	.2543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 208 / KURUNDWAD AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1094	.032	.0316	.0347	.1423	.0173	.1107
2	.0937	.032	.0316	.0351	.1423	.1052	.1107
3	.0937	.032	.032	.0354	.144	.1063	.1107
4	.0937	.032	.0316	.0358	.1423	.1075	.1265
5	.1094	.032	.0316	.0362	.1619	.1267	.1265
6	.1094	.032	.0316	.0366	.1581	.128	.1423
7	.1406	.032		.037	.1739	.1478	.176
8	.125	.0358	.0316	.0373	.1966	.2054	.1781
9	.1265	.032		.0377	.1898	.2452	.1898
10	.0316	.0343	.032	.0343	.0316	.0343	.0316
11	.0316	.2427	.2774	.2753	.0347	.0316	.0347
12	.0316	.2629	.2804	.2721	.0351	.0316	.0351
13	.0316	.3012	.2658	.2688	.0354	.032	.0354
14	.0316	.2507	.2686	.2688	.0358	.0316	.0358
15	.0316	.2715	.2534	.2372	.0362	.0316	.0362
16	.032	.2926	.2743	.2056	.0366	.0316	.0366
17	.032	.2772	.1848	.1966		.0316	.037
18	.032	.2241	.2427	.1898	.0373	.0316	.0373
19	.032	.0328	.0377	.0316	.0377	.0316	.0377
20	.032	.0316	.0343	.0316	.0343	.0316	.0343
21	.032	.0328	.0347	.0316	.0347	.0316	.0347
22	.032	.0316	.0351	.0316	.0351	.0316	.1227
23	.032	.0316	.0354	.0316	.0354	.0316	.124
24	.1094	.032	.0316	.0343	.1423	.12	.1265
Max	.1406	.3012	.2804	.2753	.1966	.2452	.1898
Min	.0316	.0316	.0316	.0316	.0316	.0173	.0316
Avg	.0649	.1101	.1141	.1028	.0893	.0731	.0863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 209 / 11KV Nrisinghwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2149	.2454	.2172	.208	.2195	.1907	.2012
2	.197	.2454	.2012	.1753	.2012	.1753	.1829
3	.197	.2629	.2012	.1772	.2012	.1772	.2012
4	.2149	.2629	.2195	.197	.2195	.1791	.2378
5	.2328	.2804	.2561	.2353	.2561	.2195	.2378
6	.2507	.2804	.2926	.2743	.2926	.2743	.2926
7	.3045	.333	.3475	.3326	.3658	.3696	.3658
8	.3582	.3856	.3658	.4108	.4024	.4294	.3658
9	.298	.3506	.3292	.415	.3841	.4024	.3109
10	.3155	.3429	.3658	.3601	.3841	.4024	.3109
11	.2804	.3467	.3294	.3292	.3467	.3658	.3467
12	.2507	.333	.3681	.2926	.333	.3292	.3506
13	.3292	.2835	.2835	.3292	.3012	.3292	.2835
14	.2926	.2865	.3224	.2926	.2686	.2926	.2686
15	.2926	.3258	.3801	.3658	.2896	.3292	.3439
16	.3155	.3841	.3658	.3475	.3109	.3292	.3841
17	.3506	.3696	.3326	.3292	.3326	.3475	.3881
18	.3506	.3658	.3547	.4207	.2987	.3658	.3734
19	.3856	.4163	.4338	.439	.4338	.4024	.4904
20	.3856	.4024	.3601	.4024	.3429	.4024	.3772
21	.3506	.3475	.3121	.3658	.3294	.3658	.3467
22	.3506	.3292	.3155	.3109	.3155	.3292	.298
23	.2804	.2926	.2835	.2926	.2481	.2743	.2481
24	.2149	.2103	.2378	.2401	.2195	.2058	.2195
Max	.3856	.4163	.4338	.439	.4338	.4294	.4904
Min	.197	.2103	.2012	.1753	.2012	.1753	.1829
Avg	.2922	.3201	.3115	.3143	.3040	.3120	.3094



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 201 / 11KV Takali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1143	.0762	.0762	.0762	.0762	.0762
2	.0572	.1143	.0762	.0762	.0762	.0762	.0762
3	.0762	.1143	.0762	.0762	.0762	.0762	.0572
4	.1334	.1143	.0762	.0762	.0953	.0762	.0762
5	.1334	.1143	.0762	.1143	.0762	.0762	.0953
6	.1143	.1143	.1143	.1334	.1143	.1143	.1143
7	.1143	.1334	.1524	.1334	.1334	.1524	.1334
8	.1143		.1524	.1143	.0953	.1334	.1143
9	.0953	.1143	.1143	.1143	.0762	.0953	.1143
10	.0953	.0953	.1143	.2858	.0953	.1143	.1143
11	.0953	.1143	.0953	.0953	.0953	.0762	.1143
12	.1143	.0953	.0953	.0953	.0953	.0953	.1143
13	.1143	.0953	.0953	.0953	.0953	.0762	.1143
14	.1143	.0953	.0953	.0953	.0953	.0953	.1143
15	.1143	.0953	.0953	.0953	.0953	.0953	.1143
16	.1143	.0953	.1143	.0953	.0953	.0762	.1334
17	.1143	.0953	.1143	.0953	.0953	.1143	.1334
18	.1143	.1143	.0953	.0953	.1143	.1143	.1334
19	.1524	.1715	.1715	.1524	.1524	.1715	.1715
20	.1715	.1905	.1905	.1524	.1715	.1905	.1715
21	.1524	.1715	.1715	.1334	.1524	.1524	.1334
22	.1143	.1524	.1524	.1143	.1334	.1143	.1334
23	.1143	.1143	.1143	.0953	.0953	.0953	.1143
24	.0762	.1143	.0953	.0953	.0762	.0762	.0762
Max	.1715	.1905	.1905	.2858	.1715	.1905	.1715
Min	.0572	.0953	.0762	.0762	.0762	.0762	.0572
Avg	.1111	.1193	.1135	.1127	.1032	.1056	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 202 / 11KV Takaliwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.8916	1.2384	1.1812	.0381	.0381	.0381
2	.0381	.8916	1.2384	1.2003	.0381	.0381	.0381
3	.0381	.8916	1.2384	1.2003	.0381	.0381	.0381
4	.0381	.8916	1.2384	1.2193	.0381	.0381	.0381
5	.0381	.9214	1.2384	1.2193	.0381	.0381	.0381
6	.0381	.9511	1.2955	1.2384	.0381	.0381	.0381
7	.0381	.9957	1.3717	1.3527	.0381	.0381	.0381
8	.0381	1.1294	1.5813	1.5242	.0381	.0381	.0381
9	.0381	1.5051	1.4098	1.5242	.0381	.0381	.0381
10	.0297	.0381	.0381	.0381	.0381	.0381	.0297
11	1.3375	.0381	.0381	.0381	1.8099	1.848	1.382
12	1.2483	.0381	.0381	.0381	1.9243	1.9052	1.5604
13	1.2186	.0381	.0381	.0381	1.8671	1.848	1.5455
14	1.1888	.0381	.0381	.0381	1.829	1.8099	1.4861
15	1.1888	.0381	.0381	.0381	1.7909	1.7528	1.4861
16	1.1888	.0381	.0381	.0381	1.7909	1.6385	1.4563
17	1.1888		.0381	.0381	1.8099	1.6766	1.4266
18	1.1888		.0381	.0381	1.7909	1.5242	1.382
19	.0297	.0381	.0381	.0381	.0381	.0381	.0446
20	.0446	.0572	.0381	.0381	.0381	.0381	.0446
21	.0332	.0381	.0381	.0381	.0381	.0381	.0446
22	.0297	.0381	.0381	.0381	.0381	.0381	.0297
23	.0297	.0381	.0381	.0381	.0381	.0381	.0297
24	.0381	.8916	1.2384	1.1812	.0381	.0381	.0381
Max	1.3375	1.5051	1.5813	1.5242	1.9243	1.9052	1.5604
Min	.0297	.0381	.0381	.0381	.0381	.0381	.0297
Avg	.4303	.4744	.5676	.5573	.6343	.6089	.5137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 203 / 11KV Danwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.0332	.0381	.0381	.9526	.8954	.8573
2	.6478	.0332	.0381	.0381	.9335	.9335	.8002
3	.6478	.0332	.0381	.0381	.9526	.9335	.8383
4	.6859	.0332	.0381	.0381	.9907	.9145	.9145
5	.743	.0332	.0381	.0381	.9907	.9145	.9526
6	.7621	.0332	.0381	.0381	1.0669	.9526	1.0098
7	.8002	.0332	.0381	.0381	1.105	1.0669	1.0479
8	.9145	.0332	.0381	.0381	1.2003	1.2384	1.086
9	.9717	.0572	.0381	.0381	1.2003	.9717	1.1622
10		.0381	.0381	.0381	.0381	.0381	.0332
11		1.3146	1.6004	1.5432	.0381	.0381	.0332
12	.0332	1.4289	1.5623	1.5623	.0381	.0381	.0332
13	.0332	1.448	1.5623	1.5242	.0381	.0381	.0332
14	.0332	1.3527	1.5432	1.448	.0381	.0381	.0332
15	.0332	1.3717	1.5242	1.448	.0381	.0381	.0332
16	.0332	1.3527	1.5051	1.3908	.0381	.0381	.0332
17	.0332	1.2955	1.5051	1.3527	.0381	.0381	.0332
18	.0332	1.3717	1.4861	1.2955	.0381	.0381	.0332
19	.0332	.0381	.0381	.0381	.0381	.0381	.0332
20	.0497	.0381	.0381	.0381	.0381	.0381	.0332
21	.0663	.0381	.0381	.0381	.0381	.0381	.0332
22	.0497	.0381	.0381	.0381	.0381	.0381	.7459
23	.0332	.0381	.0381	.0381	.0381	.0381	.7459
24	.6478	.0332	.0381	.0381	.9526	.8954	.8573
Max	.9717	1.448	1.6004	1.5623	1.2003	1.2384	1.1622
Min	.0332	.0332	.0381	.0381	.0381	.0381	.0332
Avg	.3589	.4800	.5374	.5073	.4533	.4271	.4757

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 204 / 11KV Rajapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9614	.7621	.8002	.0381	.0381	.0381
2	.0381	.9614	.7621	.8002	.0381	.0381	.0381
3	.0381	.9614	.7621	.8383	.0381	.0381	.0381
4	.0381	.9614	.7621	.8383	.0381	.0381	.0381
5	.0381	.9945	.7621	.8192	.0381	.0381	.0381
6	.0381	.9945	.8383	.8192	.0381	.0381	.0381
7	.0381	1.0277	.9526	.8764	.0381	.0381	.0381
8	.0381	1.1934	1.1812	1.086	.0381	.0381	.0381
9	.0381	1.1603	1.2193	1.1622	.0381	.0381	.0381
10	.0332	.0381	.0381	.0381	.0381	.0381	.0332
11	1.7238	.0381	.0381	.0381	1.8099	2.0195	1.7238
12	1.7736	.0381	.0381	.0381	1.9814	2.0767	1.7736
13	1.7404	.0381	.0381	.0381	1.9624	1.8099	1.7404
14	1.7072	.0381	.0381	.0381	1.9814	1.829	1.7072
15	1.6575	.0381	.0381	.0381	1.9243	1.8861	1.6741
16	1.5912	.0381	.0381	.0381	1.9052	1.9052	1.6575
17	1.5249	.0381	.0381	.0381	1.8671	1.7528	1.5912
18	1.4918	.0381	.0381	.0381	1.7909	1.7337	1.5581
19	.0497	.0762	.0381	.0381	.0381		.0332
20	.0497	.0762	.0381	.0381	.0381	.0381	.0332
21	.0663	.0381	.0381	.0381	.0381	.0381	.0332
22	.0497	.0381	.0381	.0381	.0381	.0381	.0332
23	.0497	.0381	.0381	.0381	.0381	.0381	.0332
24	.0381	.9614	.7621	.7621	.0381	.0381	.0381
Max	1.7736	1.1934	1.2193	1.1622	1.9814	2.0767	1.7736
Min	.0332	.0381	.0381	.0381	.0381	.0381	.0332
Avg	.5787	.4495	.3874	.3890	.6597	.6776	.5836

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 205 / Rajapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1524	.1524	.1524	.1715	.1334	.1524
2	.1334	.1524	.1524	.1334	.1524	.1334	.1334
3	.1524	.1524	.1524	.1334	.1524	.1334	.1524
4	.1715	.1524	.1524	.1334	.1715	.1524	.1905
5	.2096	.1524	.1524	.1905	.1715	.1905	.2477
6	.2477	.1905	.2286	.2667	.2286	.2477	.2858
7	.2667	.2858	.2858	.2667	.2286	.2858	.2286
8	.2477	.2477	.2477	.2286	.2096	.2667	.2667
9	.2286	.2286	.2286	.1715	.1715	.2477	.2286
10	.1715	.1715	.1715	.1715	.1524	.1905	.1905
11	.1524	.1715	.1524	.1905	.1524	.1715	.1905
12		.1905	.1524	.1715	.1524	.1905	.1905
13	.1905	.1715	.1524	.1905	.1334	.1905	.1905
14	.1905	.1715	.1334	.1905	.1334		.1905
15	.1905	.1715	.1334	.1715	.1524	.1715	.1905
16	.1715	.1524	.1143	.1715	.1524	.1715	.1905
17	.0152	.1524	.1524	.1524	.1524	.1715	.1905
18	.1715	.1715	.1524	.1715	.1905	.1905	.1715
19	.2858	.2858	.2667	.3048	.2858	.3239	.3429
20	.3048	.3239	.3239	.3239	.3239	.3239	.3429
21	.3048	.2667	.3048	.3048	.3048	.3048	.3239
22	.2667	.2667	.2667	.2477	.2667	.2667	.2477
23	.1905	.2096	.2286	.1715	.1905	.1905	.1905
24	.1715		.1715	.1905	.1715	.1524	.1524
Max	.3048	.3239	.3239	.3239	.3239	.3239	.3429
Min	.0152	.1524	.1143	.1334	.1334	.1334	.1334
Avg	.1995	.1996	.1929	.2001	.1905	.2087	.2159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 206 / Takaliwadi Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.0572	.0381	.0381	.0381	.0572
2	.0381	.0572	.0572	.0381	.0381	.0381	.0762
3	.0381	.0572	.0572	.0381	.0572	.0381	.0572
4	.0572	.0572	.0572	.0381	.0381	.0381	.0381
5	.0762	.0572	.0572	.0381	.0381	.0572	.0572
6	.0762	.0762	.0572	.0572	.0572	.0572	.0381
7	.0762	.0762	.0762	.0762	.0572	.0762	.0762
8	.0762	.0762	.0572	.0762	.0572	.0762	.0762
9	.0572	.0572	.0762	.0762	.0572	.0762	.0572
10	.0572	.0572	.0762	.0572	.0762	.0572	.0953
11	.0953	.0762	.0953	.0762	.0762	.1143	.0572
12	.0762	.0953	.1143	.0762	.0762	.0953	.0953
13	.0572	.0762	.0762	.0762	.0762	.0762	.0953
14	.0381	.0762	.0762	.0572	.0381	.0572	.0572
15	.0381	.0572	.0762	.0381	.0381	.0572	
16	.0572	.0572	.0762	.0381	.0572	.0572	.0762
17	.0762	.0762	.0953	.0572	.0572	.0762	.0762
18	.0762	.0762	.1143	.0572	.0762	.0762	.0762
19	.1143	.1143	.1143	.0762	.0953	.1143	.1143
20	.1334	.1143	.1334	.1143	.1143	.1143	.1334
21	.1143	.1143	.1143	.0953	.1143	.1143	.1143
22	.0953	.0953	.0953	.0762	.0953	.0953	.0953
23	.0572	.0762	.0762	.0381	.0762	.0762	.0762
24	.0572	.0572	.0572	.0572	.0381	.0572	.0572
Max	.1334	.1143	.1334	.1143	.1143	.1143	.1334
Min	.0381	.0572	.0572	.0381	.0381	.0381	.0381
Avg	.0713	.0746	.0810	.0611	.0643	.0723	.0762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 207 / 11 KV TAKALI ( AG )

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668				.9907	1.2574	1.1431
2	.7049				.9526	1.2765	1.105
3	.7621				.9907	1.2574	1.1812
4	.8002				1.0288	1.2765	1.2384
5	.9145				1.0288	1.2765	1.2955
6	.9526				1.086	1.3146	1.3146
7	.9717				1.1431	1.4289	1.2955
8	1.0288				1.2384	1.448	1.3336
9	1.0669				1.1622	1.5432	1.3336
10				.0381			
11		1.5051	1.829	1.8671			
12		1.7909	1.8099	1.829			
13		1.829	1.9243	1.8099			
14		1.8099	1.9243	1.7718			
15		1.848	1.9052	1.7528			
16		1.7718	1.8671	1.5623			
17		1.7528	1.8671	1.5432			
18		1.829	1.829	1.467			
22							.8048
23							.9054
24	.5906				.9907	1.2384	1.105
Max	1.0669	1.848	1.9243	1.8671	1.2384	1.5432	1.3336
Min	.5906	1.5051	1.8099	.0381	.9526	1.2384	.8048
Avg	.8459	1.7671	1.8695	1.5157	1.0612	1.3317	1.1713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 208 / 11 KV SANGAM AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.0332	.0381	.0381	.9335	.7621	.8764
2	.724	.0332	.0381	.0381	.9145	.7811	.8383
3	.7049	.0332	.0381	.0381	.8954	.7811	.8002
4	.6859	.0332	.0381	.0381	.9145	.8002	.8383
5	.743	.0332	.0381	.0381	.8954	.8002	.8573
6	.7621	.0332	.0381	.0381	.9526	.8383	.8764
7	.7621	.0332	.0381	.0381	1.0669	.9907	.9717
8	.8192	.0332	.0381	.0381	1.0479	.9907	1.0669
9	.8383	.0381	.0381	.0381	1.086	1.0288	1.0288
10	.0332	.0381	.0381	.0381	.0381	.0381	.0332
11	.0332	1.2574	1.5242	1.5623	.0381	.0381	.0332
12	.0332	1.4098	1.5432	1.5051	.0381	.0381	.0332
13	.0332	1.4861	1.4861	1.5051	.0381	.0381	.0332
14	.0332	1.4861	1.5242	1.4861	.0381	.0381	.0332
15	.0332	1.4861	1.4861	1.448	.0381	.0381	.0332
16		1.448	1.448	1.448	.0381	.0381	.0332
17	.0332	1.3527	1.3908	1.3908	.0381	.0381	.0332
18	.0332	1.2955	1.4098	1.3527	.0381	.0381	.0332
19	.0332	.0381	.0381	.0381	.0381		.0332
20	.0332	.0381	.0381	.0381	.0381	.0381	.0332
21	.0332	.0381	.0381	.0381	.0381	.0381	.0332
22	.0332	.0381	.0381	.0381	.0381	.0381	.6796
23	.0332	.0381	.0381	.0381	.0381	.0381	.663
24	.6478	.0332	.0381	.0381	.9335	.7621	.8764
Max	.8383	1.4861	1.5432	1.5623	1.086	1.0288	1.0669
Min	.0332	.0332	.0381	.0381	.0381	.0381	.0332
Avg	.3410	.4911	.5176	.5128	.4239	.3926	.4488



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 209 / 11 KV Danwad Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0762	.0953	.0762	.0762		.0762
2	.0572	.0762	.0953	.0762	.0572	.0572	.0762
3	.0572	.0762	.0953	.0762	.0381		.0572
4	.0953	.0762	.0953	.0762	.0572	.0572	.0762
5	.0762	.0762	.0953	.0953	.0572	.0762	.0953
6	.1143	.1143	.1143	.1334	.1143	.0953	.0953
7	.1334	.1524	.1334	.1143	.1334	.1524	.1143
8	.1334	.1334	.1143	.0953	.1143	.1334	.1143
9	.1143	.1143	.1143	.1334	.0953	.1334	.1143
10	.0953	.1143	.1143	.1143	.1143	.1143	.0953
11	.0953	.0762	.0953	.0953	.0953	.1143	.0953
12	.0953	.0953	.1143	.1143	.0953	.0953	.0953
13	.0953	.0762	.0953	.0953	.1143	.1143	.0953
14	.0762	.0762	.0953	.0953	.0953	.0572	.0953
15	.0762	.0762	.0762	.0762	.0953	.0762	.0953
16	.0953	.0953	.0762	.0953	.0953	.0762	.0953
17	.1143	.0762	.0762	.0762	.0953	.0953	.0953
18	.1143	.0953	.0572	.0953	.0953	.1143	.0953
19	.1524	.1334	.1715	.1334	.1334	.1524	.1715
20	.1715	.1524	.1905	.1524	.1715	.1715	.1905
21	.1715	.1524	.1524	.1524	.1334	.1715	.1715
22	.1334	.1524	.1334	.1143	.1143	.1143	.1524
23	.0953	.1143	.1143	.0953	.0762	.0762	.1143
24	.0762	.0762	.0953	.0953	.0762	.0762	.0762
Max	.1715	.1524	.1905	.1524	.1715	.1715	.1905
Min	.0572	.0762	.0572	.0762	.0381	.0572	.0572
Avg	.1048	.1024	.1088	.1032	.0977	.1057	.1064

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 201 / 11 KV Santubai AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3435	.0457	.0332	.0324	1.3748	1.3123	1.3923
2	1.3435	.0305	.0332	.0324	1.3748	1.3123	1.3923
3	1.3435	.0305	.0332	.0324	1.406	1.3123	1.4255
4	1.3435	.0457	.0332	.0486	1.4373	1.3123	1.4586
5	1.3748	.061	.0328	.0486	1.4548	1.3435	1.4918
6	1.406	.0762	.0332	.0648	1.5402	1.3748	1.5249
7	1.4998	.0762	.0332	.0486	1.5364	1.4685	1.5581
8		.0762	.0497	.0648	1.6309	1.6248	1.6907
9	1.6248	.0762	.048	.0324	1.6804	1.6872	1.7736
10	.0457	.0457	.0324	.0486	.0457	.0457	.0497
11	.0457	1.8747	2.0243	2.1862	.0457	.0332	.0332
12	.061	2.0885	2.1052	2.2085	.0457	.0332	.0469
13	.0762	2.1714	2.1862	2.1862	.0305	.0497	.0469
14	.0762	2.1714	2.1214	2.0934	.0305	.0497	.0457
15	.0762	2.1548	2.1052	2.1376	.0305	.0497	.0625
16	.0762	2.0885	2.0891	2.1376	.0305	.0497	.0625
17	.061	2.0719	2.0567	2.0567	.0457	.0497	.0781
18	.061	2.0553	2.0405	1.9757	.0457	.0497	.0762
19	.0762	.0497	.0486	.061	.061	.0497	.0972
20	.0762	.0497	.0486	.0457	.0457	.0497	.081
21	.0762	.0497	.0486	.0457	.0457	.0497	.081
22	.061	.0497	.0486	.0457	.0457	.0497	1.4413
23	.061	.0332	.0486	.0305	.0305	.0332	1.5223
24	1.3435	.0457	.0332	.0324	1.3413	1.3123	1.3923
Max	1.6248	2.1714	2.1862	2.2085	1.6804	1.6872	1.7736
Min	.0457	.0305	.0324	.0305	.0305	.0332	.0332
Avg	.5892	.7299	.7236	.7374	.6398	.6126	.7844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031] BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.823	.7956	.7522	.0152	.0152	
2	.0152	.8535	.8122	.7362	.0152	.0152	.0332
3	.0152	.8535	.8288		.0156	.0152	.0332
4	.0152	.9061	.8002	.7522	.0152	.0152	.0332
5	.0152	.9145	.8619	.7682	.0152	.0152	.0332
6	.0152	.9686	.8951	.7842	.0156	.0305	.0332
7	.0152	.945	.9116	.8322	.0152	.0305	.0332
8		1.0623	.9448	.8482	.0152	.0152	.0332
9	.0152	.9907	1.0111	.8482	.0156	.0152	.0332
10	.0152	.0152	.016	.016	.0152		.0166
11	1.2029	.0156	.016	.016	1.1279	1.4089	1.3426
12	1.2631	.0166	.016	.0162	1.2186	1.4089	1.3592
13	1.2342	.0166	.016	.0156	1.2811	1.4089	1.3765
14	1.2346	.0166	.016	.0156	1.2811	1.4089	1.2498
15	1.2041	.0166	.016	.0156	1.2811	1.3592	1.2186
16	1.2186	.0166	.016	.0152	1.2811	1.326	
17	1.1092	.0166	.016	.0152	1.2498	1.3094	1.2146
18	1.0364		.016	.0152	1.2498	1.2929	1.1873
19	.0305	.0166	.016	.0305	.0305	.0332	.016
20	.0305	.0166		.0305	.0152	.0332	.048
21	.0305	.0166	.016	.0312	.0152	.0332	.048
22	.0305	.0166	.016		.0152	.0332	.048
23	.0152	.0166	.016	.0152	.0152	.0332	.048
24	.0152	.8436	.7956	.7522	.0152	.0152	.0332
Max	1.2631	1.0623	1.0111	.8482	1.2811	1.4089	1.3765
Min	.0152	.0152	.016	.0152	.0152	.0152	.016
Avg	.4258	.4076	.3854	.3328	.4263	.4901	.4305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 203 / 11 KV Ghosarawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.0914	.0943	.1109	.0914	.1097	.0943
2	.1097	.0914	.0943	.0924	.0914	.0914	.0943
3	.1097	.0905	.0943	.0924	.0914	.0914	.0943
4	.1097	.128	.168	.1294	.1097	.0914	.132
5	.1097	.181	.2054	.1663	.1463	.1097	.168
6	.1829	.2195	.2587	.2033	.1829	.1829	.2241
7	.3292	.2896	.2957	.2402	.1991	.2561	.1848
8		.2561	.2587	.2957	.2172	.2561	.1848
9	.2561	.2195	.2402	.2587	.1991	.2195	.1663
10	.2195	.2012	.2402	.2402	.1829	.2195	.1109
11	.2561	.2012	.2402	.2402		.1829	.1109
12	.1829	.2218	.2218	.2378	.1829	.1663	.128
13	.1829	.2587	.2587	.2195	.1829	.1294	.1097
14	.2012	.1848	.2402	.2195		.1294	.1086
15	.2012	.1663	.2402	.2378	.1097	.1294	.1097
16	.1829	.1478	.2218	.2195	.1097	.1478	.1097
17	.1463	.1478	.1478	.128	.128	.1478	.1097
18	.2012	.1478	.1478	.1267	.1097	.1663	.1097
19	.2561	.2033	.2033	.1646	.1829	.2218	.1848
20	.2195	.2427	.2402	.2012	.2195	.2402	.2033
21	.1829	.2587	.1848	.1829	.1829	.2033	.2033
22	.1646	.1663	.1663	.1646	.1463	.1663	.1663
23	.1097	.1307	.1294	.1097	.1097	.112	.1294
24	.1097	.1097	.1132	.1109	.1097	.1097	.1132
Max	.3292	.2896	.2957	.2957	.2195	.2561	.2241
Min	.1097	.0905	.0943	.0924	.0914	.0914	.0943
Avg	.1797	.1815	.1961	.1830	.1493	.1617	.1396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 204 / 11 kv Balumama AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8749	.0312	.0316	.0312	1.1405	1.0311	1.0595
2	.8749	.0312	.0316	.0312	1.1405	1.0311	1.0595
3	.8749	.0312	.0316	.0312	1.1561	1.0311	1.1043
4	.8749	.0312	.0316	.0312	1.1584	1.0311	1.1203
5	.9061	.0312	.0316	.0312	1.2631	1.0311	1.1523
6	.9061	.0324	.0316	.0312	1.2186	1.0623	1.1523
7	.9686	.0305	.0316	.0312	1.2186	1.1405	1.1544
8		.0312	.0316	.0312	1.2498	1.2186	1.2176
9	1.1561	.0312	.0316	.0312	1.2193	1.2811	1.2967
10	.0305	.0305	.0312	.0312	.0152		.0474
11	.0305	1.4575	1.6716	1.531	.0156		.0316
12	.0305	1.5181	1.7029	1.6842	.0152	.0158	.0312
13	.0305	1.6446	1.7029	1.6356	.0305	.0158	.0312
14	.0152	1.6129	1.6872	1.5623	.0305	.0158	.0312
15	.0152	1.6129	1.6872	1.6091	.0305	.0158	
16	.0152	1.6129	1.5935	1.6518	.0305	.0158	.0305
17	.0152	1.6129	1.6248	1.4998	.0305	.0158	.0305
18	.0152	1.6446	1.6404	1.4327	.0305	.0158	.0312
19	.0152	.0316	.0312	.0305	.0305	.0158	.0312
20	.0152	.0316	.0469	.0305	.0305	.0316	.0312
21	.0305	.0316	.0469	.0305	.0305	.0316	.0312
22	.0305	.0316	.0312	.0305	.0305	.0316	1.1248
23	.0305	.0316	.0312	.0305	.0305	.0316	1.1561
24	.8749	.0305	.0316	.0312	1.1126	1.0311	1.0595
Max	1.1561	1.6446	1.7029	1.6842	1.2631	1.2811	1.2967
Min	.0152	.0305	.0312	.0305	.0152	.0158	.0305
Avg	.3753	.5507	.5769	.5459	.5108	.5065	.6094

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 205 / 11 KV Dattawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	1.0202	.9282	.6062	.0305	.0152	.0332
2	.0152	1.0364	.9282	.5898	.0312	.0152	.0332
3	.0152	1.0688	.9614	.5898	.0312	.0152	.0332
4	.0152	1.0364	.9614	.5898	.0312	.0152	.0332
5	.0152	1.1336	.9945	.6062	.0305	.0305	.0332
6	.0152	1.166	.9945	.6062	.0312	.0305	.0332
7	.0152	1.1126	1.0277	.6718	.0305	.0305	.0332
8		1.2146	1.1105	.7373	.0312	.0152	.0332
9	.0152	1.2146	1.1105	.7701	.0305	.0152	.0332
10	.0152	.0305	.0328	.0328	.0305	.0305	.0497
11	1.6872	.0486	.0328	.0328	1.2955	1.5935	1.6078
12	1.6248	.0332		.0324	1.3904	1.6244	1.4413
13	1.6091	.0332			1.3748	1.5581	1.4998
14	1.5089	.0332		.0312	1.3435	1.4918	1.5223
15	1.4784	.0332	.0328	.0312	1.3435	1.5415	1.4217
16	1.448	.0332	.0328	.0312	1.3435	1.6078	1.4575
17	1.4022	.0332	.0328	.0324	1.3435	1.6409	1.3927
18	1.2654	.0332	.0328	.0305	1.3435	1.5415	1.2955
19	.0305	.0332	.0492	.0469	.0305	.0332	.0328
20	.0305	.0332	.0492	.0457	.0152	.0332	.0328
21	.0305	.0332	.0492	.0305	.0152	.0332	.0328
22	.0305	.0332	.0328	.0305	.0152	.0332	.0328
23	.0305	.0332	.0328	.0305	.0152	.0332	.0328
24	.0305	.9602	.9282	.6718	.0305	.0152	.0332
Max	1.6872	1.2146	1.1105	.7701	1.3904	1.6409	1.6078
Min	.0152	.0305	.0328	.0305	.0152	.0152	.0328
Avg	.5367	.4767	.4931	.2990	.4670	.5414	.5077

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 206 / 11 KV Dattawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1463	.1698	.1829	.1448	.1463	.1698
2	.1829	.128	.1698	.1646	.1448	.1463	.1698
3	.1829	.128	.1698	.1646	.1448	.1463	.1698
4	.1829	.128	.1886	.1829	.1629	.1463	.1886
5	.2195	.1829	.2054	.2195	.1829	.1829	.2241
6	.2561	.3109	.2614	.2926	.2195	.2195	.2587
7	.2926	.2896	.2957	.2926	.2561	.2561	.2957
8		.2561	.2402	.2926	.2896	.2561	.2402
9	.2561	.2561	.2772	.2561	.2743	.2561	.2772
10	.2561	.2561	.2743	.2561	.2195		.2587
11	.2195	.2926	.2743	.2561		.2195	.2957
12	.1097	.2587	.2561	.2561		.2218	.2743
13	.1097	.2587	.2561	.2561		.2218	.2743
14	.2926	.2402	.2378	.2561	.2195	.2587	.2561
15	.2561	.2402	.2561	.2195	.2195	.2587	.2561
16	.2561	.2587	.2378	.2195	.2195	.2772	.2561
17	.2561	.2587	.2561	.2561	.2561	.2957	.2561
18	.3109	.2957	.2926	.2896	.2926	.2772	.3292
19	.4024	.3326	.4024	.3658	.3658	.3142	.4024
20	.4024	.3881	.4207	.3982	.4024	.4435	.4024
21	.3658	.4435	.3292	.3292	.3658	.3696	.3658
22	.2926	.2987	.2743	.2561	.2926	.2957	.3109
23	.2195	.2241	.2378	.2195	.2195	.2241	.2378
24	.1829	.1829	.1886	.1829	.1829	.1829	.1886
Max	.4024	.4435	.4207	.3982	.4024	.4435	.4024
Min	.1097	.128	.1698	.1646	.1448	.1463	.1698
Avg	.2473	.2523	.2572	.2527	.2417	.2442	.2649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 207 / 11 KV Hanuman AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.7164	.7375	.7011	.0152	.0152	.0152
2	.0152	.7164	.7375	.6859	.0152	.0152	.0152
3	.0152	.7499	.7526	.6859	.0152	.0152	.0152
4	.0152	.7316	.7526	.6706	.0152	.0152	.0152
5	.0152	.7316	.7827	.6706	.0152	.0152	.0152
6	.0152	.7186	.7926	.6706	.0152	.0152	.0152
7	.0152	.703	.7827	.6706	.0152	.0152	.0151
8		.7621	.8688	.7011	.0152	.0152	.0151
9	.0152	.8078	.873	.7164	.0152	.0152	.0151
10	.0152	.0152	.0152	.0152	.0152		.0151
11	.9998	.0156	.0152	.0152	.9907	1.1092	1.0385
12	.9755	.0151	.0152	.0152	.9686	1.0536	1.1248
13	.9998	.0151	.0152	.0152	.9686	1.0235	1.2029
14	.9755	.0151	.0152	.0152	.9686	.0152	1.1279
15	.9755	.0151	.0152	.0152	.9686	1.0235	1.1717
16	.945	.0152	.0152	.0152	.9686	1.0536	1.2146
17	.9145	.017	.0152	.0152	.9686	1.0987	1.1584
18	.9145	.0151	.0152	.0152	.9686	1.0536	1.1405
19	.0152	.0151	.0152	.0152	.0152	.0151	.0152
20	.0152	.0151	.0152	.0152	.0152	.0151	.0152
21	.0152	.0151	.0152	.0152	.0152	.0151	.0152
22	.0152	.0151	.0152	.0152	.0152	.0151	.0152
23	.0152	.0151	.0152	.0152	.0152	.0151	.0152
24	.0152	.7164	.7375	.7011	.0152	.0152	.0151
Max	.9998	.8078	.873	.7164	.9907	1.1092	1.2146
Min	.0152	.0151	.0152	.0152	.0152	.0151	.0151
Avg	.3447	.3153	.3346	.2953	.3339	.3330	.3926



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 201 / 11KV Shirati Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1307	.1052		.0934	.112	.1052
2	.112	.1307	.1052		.0934	.112	.1052
3	.112	.1307	.1052		.0934	.112	.1052
4	.1307	.1494	.1052		.0934	.1494	.1052
5	.1494	.1867	.1402		.1307	.1867	.1227
6	.2427	.2427	.2279		.2241	.2241	.2279
7	.2427	.2427	.2279		.2054	.2241	.2279
8	.2054	.2054	.1715		.1867	.2054	.1928
9	.1715	.168	.168	.168	.1543	.1867	.1867
10	.1543	.168	.1494	.168	.12	.1494	.1494
11	.1715	.1494	.1307	.168	.12	.168	.168
12	.1543	.1494	.1307	.1494	.12	.168	.1494
13	.12	.1307	.1307	.168	.12	.1307	.1494
14	.1029	.112	.112	.1494	.12	.1307	.1307
15	.12	.1307	.1494	.1494	.12	.1307	.112
16	.12	.1307	.1307	.112	.1029	.1029	.0934
17	.112	.1029		.1494	.112	.1029	.112
18	.1307	.1448		.1494	.112	.12	.1307
19	.2054	.1991		.2241	.1867	.2058	.2241
20	.2427	.2172		.2427	.2054	.2229	.2241
21	.2054			.2054	.2054	.1991	.2054
22	.1867	.181		.168	.168	.1448	.1867
23	.1494	.1448		.1307	.1494	.1227	.1494
24	.12	.1307	.1227		.112	.112	.1052
Max	.2427	.2427	.2279	.2427	.2241	.2241	.2279
Min	.1029	.1029	.1052	.112	.0934	.1029	.0934
Avg	.1572	.1599	.1419	.1668	.1395	.1551	.1529

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 202 / KUTWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.0373	.0175		.6859	.7468	.7362
2	.583	.0373	.0175		.6859	.7468	.7362
3	.583	.0373	.0175		.7202	.7842	.7362
4	.6001	.0373	.0175		.7202	.7842	.7362
5	.6173	.0373	.0175		.7373	.8215	.8413
6	.6516	.0373	.0175		.7888	.8962	.8764
7	.7202	.0373	.0175		.8745	.8962	.964
8	.7888	.0373	.0343		.9431	1.0829	1.1043
9	.7888	.0373	.0343	.0373	1.0117	1.0631	1.1763
10	.0171	.0373	.0343	.168	.0171	.0343	.0373
11	.0343	1.4937	1.6804	1.8298	.0171	.0343	.0373
12	.0171	1.5497	1.7147	1.7737		.0343	.0373
13	.0343	1.4937	1.749	1.7177		.0343	.0373
14	.0171	1.5123	1.7147	1.6991	.0343	.0343	.0373
15	.0171	1.5123	1.7147	1.6804	.0373	.0343	.0373
16		1.4937	1.5775	1.587	.0373	.0343	.0373
17	.0187	1.3375		1.3546	.0373	.0343	.0343
18	.0373	1.3717		1.4003	.0373	.0343	.0343
19	.0373	.0181		.112	.0373	.0171	.0343
20	.0373	.0362		.2058	.0373	.0343	.0343
21	.0373	.0351		.3944	.0373	.0351	.0343
22	.0373	.0362		.1886	.0373	.0351	.6859
23	.0373	.0362		.2229	.0373	.0351	.8029
24	.5658	.0373	.0175		.6516	.7282	.7362
Max	.7888	1.5497	1.749	1.8298	1.0117	1.0829	1.1763
Min	.0171	.0181	.0175	.0373	.0171	.0171	.0343
Avg	.2983	.5140	.6114	.9581	.3738	.3756	.4402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 203 / SHIROL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9088	.0373	.0351		1.2346	1.1763	1.0517
2	.8916	.0373	.0351		1.2346	1.2696	1.0517
3	.9088	.0373	.0351		1.2517	1.2696	1.0517
4	1.0269	.0373	.0351		1.2517	1.307	1.0517
5	.9774	.0373	.0351		1.286	1.3443	1.1043
6	1.0802	.0373	.0351		1.3546	1.3443	1.1919
7	1.2003	.0373	.0351		1.5089	1.4003	1.3146
8	1.286	.0373	.0351		1.5947	1.5497	1.5074
9	1.3032	.0373	.0343	.0373		1.4746	1.6057
10	.0171	.0373	.0343	.0373	.0171	.0343	.0373
11	.0171	1.9044	2.3525	2.4646	.0343	.0343	.0373
12	.0171	2.0351	2.5206	2.5393	.0343	.0343	.0373
13	.0343	2.0911	2.3899	2.1285	.0343		.0373
14	.0171	2.1658	2.3152	2.2032	.0373		.0373
15	.0343	2.1845	2.2405	2.1658	.0373		.0373
16	.0343	2.1472	2.2032	2.0911			.0373
17	.0373	1.9719		2.1098	.0373		.0514
18	.0373	1.9719		2.0911	.0373	.0343	.0514
19	.0373	.0343		.0373	.0373	.0343	.0514
20	.0373	.0343		.0373	.0373	.0343	.0514
21	.0373	.0343		.0373	.0373	.0351	.0514
22	.0373	.0343		.0343	.0373	.0351	1.1203
23	.0373	.0343		.0373	.0373	.0362	1.1016
24	.9522	.0373	.0351		1.2003	1.1763	1.0517
Max	1.3032	2.1845	2.5206	2.5393	1.5947	1.5497	1.6057
Min	.0171	.0343	.0343	.0343	.0171	.0343	.0373
Avg	.4570	.7106	.8474	1.2034	.5624	.7171	.6134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 204 / GHALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.7842	.8413		.1029	.112	.1052
2	.1029	.7842	.8413		.1029	.112	.1052
3	.1029	.7655	.8413		.1029	.112	.1052
4	.1029	.7842	.8413		.1029	.112	.1052
5		.8775	.964		.1029	.112	.1052
6	.1029	1.0269	.9816		.1029	.112	.1052
7	.1029	1.1016	1.0867		.1029	.112	.1052
8	.1029	1.1576	1.0974		.1029	.112	.1052
9	.1029	1.1576	.1029	1.2136	.1029	.1029	.112
10	.1029	.112	.056	.112	.1029	.1029	.112
11	1.7833	.112	.1029	.112	1.7147	2.0165	2.1658
12	1.8861	.112	.0343	.112	1.7147	2.1472	2.1658
13	1.8519	.112	.0343	.112	1.749	2.1658	2.1472
14	1.8347	.112	.1029	.112	1.9978	2.1472	2.2218
15	1.8004	.112	.1029	.112	1.9791	1.989	2.2032
16	1.7147	.112	.1029	.112	1.9978	2.1098	2.1845
17	1.8671	.1029		.112	1.9418	1.9033	2.0351
18	1.7177	.1029		.1029	1.8858	1.8861	1.9791
19	.112	.1029		.112	.112	.1029	.112
20	.112	.1029		.1029	.112	.1029	.1029
21	.112	.1029		.1029	.112	.1052	.1029
22	.112	.1029		.1029	.112	.1052	.112
23	.0373	.1029		.1029	.112	.1052	.112
24	.0343	.7655	.8413		.1029	.112	.1052
Max	1.8861	1.1576	1.0974	1.2136	1.9978	2.1658	2.2218
Min	.0343	.1029	.0343	.1029	.1029	.1029	.1029
Avg	.6914	.4462	.5280	.1824	.6947	.7542	.7840

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 205 / 11KV Shirti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.8402	.6661		.0514	.0373	.0175
2	.0343	.8589	.6661		.0514	.0373	.0175
3	.0343	.8589	.6661		.0514	.0373	.0175
4	.0343	.8775	.6661		.0514	.0373	.0175
5	.0343	.9335	.6661		.0514	.0373	.0175
6	.0343	1.0082	.7537		.0514	.0373	.0175
7	.0343	1.1016	.929		.0514	.0373	.0175
8	.0343	1.1763	.9431		.0514	.0373	.0175
9	.0343	1.1763	.9431	.9709	.0514	.0514	.0187
10	.0343	.0373	.0373	.0373	.0514	.0514	.0187
11	1.9204	.0373	.0343	.0373	1.6118	1.6632	2.0538
12	1.989	.0373	.0343	.0373	1.6289	2.0538	2.0725
13	1.8861	.0373	.0343	.0373	1.5947	1.9204	2.0725
14	1.9033	.0373	.0343	.0373	1.5947	1.869	2.0725
15	1.8347	.0373	.0343	.0373	1.5947	1.9605	2.0538
16	1.749	.0373	.0343	.0373	1.6118	1.9791	1.9605
17	1.7737	.0343		.0373	1.7177	1.6632	1.8858
18	1.6057	.0343		.0343	1.6617	1.6289	1.8858
19	.0373	.0181		.0343	.0373	.0171	.0373
20	.0373	.0181		.0343	.0373	.0171	.0373
21	.0373	.0181		.0343	.0373	.0181	.0373
22	.0373	.0181		.0343	.0373	.0175	.0373
23	.0373	.0175			.0373	.0175	.0343
24	.0343	.8029	.6661		.0373	.0373	.0175
Max	1.989	1.1763	.9431	.9709	1.7177	2.0538	2.0725
Min	.0343	.0175	.0343	.0343	.0373	.0171	.0175
Avg	.6344	.4189	.4593	.1029	.5731	.6360	.6848

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 206 / Kutwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0934	.0876		.0747	.0747	.0876
2		.0934	.0876		.0747	.0747	.0876
3		.0934	.0876		.0747	.0747	.0876
4		.112	.0876		.0747	.1494	.0876
5		.1307	.1052		.112	.1494	.0876
6		.1494	.1578		.1307	.1494	.1402
7		.168	.1402		.112	.168	.1578
8		.1494	.1372		.112	.1494	.1402
9	.12	.1494	.1038	.1307	.0686	.1307	.1307
10	.1029	.112	.0857	.112	.0514	.112	.112
11	.1029	.1494	.0934	.1307	.0514	.1029	.112
12	.1029	.112	.112	.0747		.112	.112
13	.1029	.112	.0934	.1307		.12	.112
14	.0857	.0934	.0934	.112	.0857	.1029	.112
15	.1029	.112	.0934	.112	.0857	.0857	.112
16	.0857	.112	.0934	.112	.0857	.1029	.0934
17	.0747	.1029		.0747	.0934	.1029	.0934
18	.0934	.0857		.0934	.0934	.1029	.112
19	.168	.181		.168	.1494	.1715	.168
20	.2054	.1753		.1867	.168	.1715	.1715
21	.1867	.1578		.168	.1494	.1629	.1867
22	.1494	.1448		.1307	.1307	.1267	.1494
23	.112	.1086		.0934	.0934	.1086	.1307
24		.0934	.0876		.0747	.0747	.0876
Max	.2054	.181	.1578	.1867	.168	.1715	.1867
Min	.0747	.0857	.0857	.0747	.0514	.0747	.0876
Avg	.1197	.1246	.1028	.1220	.0976	.1200	.1197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 207 / Ghalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1753		.1307	.1307	.2279
2		.1867	.1753		.1307	.1307	.2279
3		.1867	.1753		.1372	.112	.2279
4		.2241	.1753		.1715	.112	.2279
5		.2614	.2103		.2614	.2241	.2804
6		.3361	.333		.3174	.2987	.3506
7		.3361	.298		.2987	.3734	.3506
8		.2801	.2743		.2801	.3174	.2804
9	.2915	.2614	.2614	.3174	.2743	.2987	.2614
10	.2915	.2614	.2427	.3361	.2229	.2058	.2427
11	.2915	.2241	.168	.3361	.2401	.2058	.2427
12	.1886	.2614	.2614	.2614	.2572	.1715	.2241
13	.1715	.2427	.2054	.1867	.2401	.2054	.1867
14	.2058	.2427	.2054	.168	.2241	.1867	.168
15	.1543	.2241	.1867	.168	.2427	.1886	.1867
16	.1543	.2801	.1867	.1867	.1867	.1867	.1867
17	.168	.2058	.1867	.1867	.2241	.2229	.1867
18	.168	.2229	.1867	.2054	.2241	.2229	.2427
19	.2614	.3429	.2987	.2801	.3174	.3258	.2614
20	.3174	.3601	.3361	.3174	.3547	.3258	.3361
21	.2987	.2572	.3361	.2801	.3547	.2896	.2987
22	.2614	.2401	.2987	.2427	.1867	.2896	.2572
23	.2241	.2058	.2614	.2054	.1867	.2534	.168
24		.2054	.1753		.1307	.168	.2279
Max	.3174	.3601	.3361	.3361	.3547	.3734	.3506
Min	.1543	.1867	.168	.168	.1307	.112	.168
Avg	.2299	.2515	.2339	.2452	.2331	.2269	.2438

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 201 / 11KV K'Guland

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.0162	.0164	.8288	.7209	
2	.0152	.0162	.0162	.8288	.7209	
3	.0152	.0162	.0164	.8383	.7209	
4	.0152	.016	.0164	.9221	.7209	
5	.0152	.0162	.0162	.9221	.7209	
6	.0152	.0162	.0164	.9945	.788	
7	.0152	.016	.0164	.9945	.8383	
8	.0152	.016	.0164	.9945	.9389	.8718
9	.0152	.016	.0164	.9945	.9892	.9389
10	.0152	.016	.0162	.0152		.0152
11	1.4632	.2984	1.326	.0164		.0152
12	1.4632	1.326	1.3413	.0164		.0152
13	1.4632	1.3923	1.3413	.0164		.0152
14	1.4632	1.2071	1.3413	.0164		.0152
15	1.5364	1.2071	1.3413	.0164		.0152
16	1.5364	1.2071	1.2574	.0164		.0152
17	1.4632	1.2071	1.2574	.0164		.0152
18	1.5364	1.2071	1.1736	.0164		.0152
19	1.4632	.0162	.0162	.0164		.0152
20	.0147	.0162	.0162	.0164		.0152
21	.0141	.0162	.0162	.0164		.0152
22	.0141	.0162	.0162	.0164		.7209
23	.0141	.0162	.0162	.0164		.7042
24	.0164	.0162	.0164	.7545	.7209	
Max	1.5364	1.3923	1.3413	.9945	.9892	.9389
Min	.0141	.016	.0162	.0152	.7209	.0152
Avg	.5673	.3879	.4434	.3875	.7880	.2136



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 202 / 11KV Ganeshwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9602	1.0059	.9945	.016	.016	
2	1.0242	1.0059	1.1233	.016	.016	
3	1.0242	1.073	1.2239	.016	.016	
4	1.0242	1.0608	1.2742	.016	.016	
5	1.0242	1.2574	1.3413	.016	.016	
6	1.2003	1.3077	1.4083	.0162	.016	
7	1.3603	1.3413	1.4754	.0162	.016	
8	1.5364	1.5089	1.4754	.016	.016	.016
9	1.4883	1.6278	1.2071	.016	.016	.016
10	.016	.0162	.0164	.016	.016	.016
11		.0162	.0164	1.9204		1.9845
12	.0141	.0162	.0164	1.9204		2.0645
13	.0141	.0162	.016	1.9204		1.9685
14	.0141	.0162	.0162	1.9044		1.9524
15	.0141	.0162	.0162	1.9044		1.8404
16	.0141	.016	.0162	1.8884		1.8884
17	.0147	.016	.0162	1.8244		1.8884
18	.0141	.016	.0162	1.8084		.016
19	.0141	.016	.0162	.016		.016
20	.0141	.016	.016	.016		.016
21	.0141	.0162	.016	.016		.016
22	.0141	.0162	.016	.016		.016
23	.0147	.0162	.016	.016		.016
24	.9282	.9724	.9116	.0162	.016	
Max	1.5364	1.6278	1.4754	1.9204	.016	2.0645
Min	.0141	.016	.016	.016	.016	.016
Avg	.5112	.5161	.5276	.6395	.016	.8582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 203 / 11KV Alas Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0143	.6161	.5765	.1357	.016	.0152	
2	.0143	.6161	.6104	.1372	.016	.0152	
3	.0143	.6348	.6104	.1543	.016	.0152	
4	.0143	.6348	.6104	.1715	.016	.0152	
5	.0143	.6348	.6371	.1753	.016	.0152	
6	.0143	.6722	.6859	.1772	.0162	.0152	
7	.0143	.7282	.6859	.1829	.0162	.0152	
8	.0143	.8402	.6783	.2195	.016	.0152	.0152
9	.0143	.8589	.7545	.6584	.016		.0152
10	.0143	.0143	.0162	.0171	.0143		.0152
11	.9389		.0162	.0171	.9389	1.2209	1.3256
12	1.0562		.0162	.017	1.0898	1.2209	1.3817
13	1.0395		.0162	.0164	.9389	1.1869	1.419
14	1.073		.0162	.0162	.9389	1.153	1.419
15	1.0395		.0162	.0162	.9389		1.3817
16	1.0059		.016	.0162	.9892		1.3817
17			.016	.0162	.9892		1.4937
18			.016	.0162	.9892		1.3817
19			.016	.0162	.0143		.0152
20			.064	.016	.0143		.0152
21				.016	.0152		.0152
22			.016	.016	.0152		.0152
23			.016	.016	.0152		.0152
24	.0143	.5601	.5087	.1357	.016	.0152	
Max	1.073	.8589	.7545	.6584	1.0898	1.2209	1.4937
Min	.0143	.0143	.016	.016	.0143	.0152	.0152
Avg	.3712	.6191	.2876	.0990	.3359	.3783	.7066

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 204 / 11KV Alas Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3155	.2896	.2896	.2353	.3258	
2	.3155	.2896	.2865	.2328	.3258	
3	.298	.3077	.2507	.2328	.2715	
4	.298	.3109	.2507	.2328	.2715	
5	.298		.3045	.2686	.3258	
6	.3506	.3658	.3439	.3439	.4344	
7	.4733	.4572	.3982	.3077	.4706	
8	.4557	.3841	.3801	.2896	.4163	.362
9	.4207	.3658	.362	.2896	.4344	.362
10	.3856	.3658	.3077	.2896	.4344	.362
11	.381	.3658	.3658	.2896		.362
12	.2743	.3658	.3292	.2353	.3841	.362
13	.2896	.3658	.362	.2353	.3658	.4163
14	.3201	.3841	.362	.2715	.3658	.4344
15	.3201	.3658	.3258	.2715		.362
16	.3201	.3658	.2896	.2715		.4344
17		.3658	.2534	.3077	.3841	.3982
18	.3201	.3658	.3077	.3982		.3982
19	.4725	.5121	.4572	.5249		.543
20	.4862	.4572	.5121	.5973		.5853
21	.381	.439	.4572	.543		.543
22	.3048	.4024	.3841	.4525		.4706
23	.2286	.3658	.2534	.3439		.3982
24	.3506	.2896	.362	.2534	.3077	
Max	.4862	.5121	.5121	.5973	.4706	.5853
Min	.2286	.2896	.2507	.2328	.2715	.362
Avg	.3504	.3716	.3415	.3216	.3679	.4246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 205 / 11KV Ganeshwadi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2629	.2926	.3292	.2534	.2561	
2	.2629	.2715	.3292	.2353	.2561	
3	.2804	.2715	.3109	.2353	.2561	
4	.2804	.3475	.2896	.2172	.2561	
5	.3475	.3292	.2534	.2353	.3292	
6	.4207	.3658	.2353	.3658	.4024	
7	.4572	.3841	.2353	.3841	.3841	
8	.4024	.3292	.3292	.3292	.3292	.2743
9	.3292	.3109	.2926	.2743	.2743	.2561
10	.298	.3109	.3475	.2743	.2743	.2926
11	.2143	.3109	.3109	.2561		.2926
12	.2286	.3109	.3292	.2743	.2801	.2926
13	.2429	.2743	.3109	.2743	.2801	.2926
14	.2429	.3109	.3077	.2561		.2926
15	.2429	.3109	.3109	.2561		.2926
16	.2715	.2926	.3109	.2743		.2561
17	.3048	.3292	.3109	.2926		.2743
18	.3201	.3841	.3475	.3292	.2743	.3658
19	.4268	.499	.4572	.4706		.439
20	.381	.4435	.4572	.4755		.4755
21	.3048	.4024	.4207	.439		.4572
22	.2743	.3658	.3658	.3658		.3658
23	.2572	.3292	.2534	.2926		.3109
24	.2804	.2926	.3258	.2534	.2561	
Max	.4572	.499	.4572	.4755	.4024	.4755
Min	.2143	.2715	.2353	.2172	.2561	.2561
Avg	.3056	.3362	.3238	.3048	.2935	.3269

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 206 / 11KV Krishna Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2452	.2402	.0025	.0762	
4	.2829	.2801	.181	.0762	
5	.2829	.2801	.2218	.0762	
6	.2829	.2801	.2801	.2241	
7	.2829	.2829	.2801	.2987	
8	.2829	.2829	.2829	.2987	.2801
9	.2829	.3206	.3584	.2987	.2801
10	.3395	.3961	.3395		.3734
11	.3048	.3772	.3961	.3658	.3361
12	.3048	.3772		.3658	.3547
13	.3048	.3772	.3772	.3658	.3547
14	.3048	.3584	.3772	.3658	.3734
15	.3048	.3584	.3772		.3547
16	.3048	.3395	.3772		.3361
17		.3395	.3772		.3361
18	.3048	.3395	.3584		.3361
19	.3048				
Max	.3395	.3961	.3961	.3658	.3734
Min	.2452	.2402	.0025	.0762	.2801
Avg	.2950	.3269	.3058	.2556	.3378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 207 / 11KV Vijay-Ganesh

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2534	.0924	.2772	.181	
4	.2534	.1848	.3174	.181	
5	.2896	.2587	.3734	.1991	
6	.362	.2587	.3734	.1991	
7	.3801	.2614	.3734	.1991	
8	.3801	.3921	.3734	.2896	.3801
9	.3801	.3921	.3921	.2353	.3801
10	.3801	.2614	.3734		.3982
11	.3401	.3921	.3921		.3681
12	.3201	.3734	.3921		.3801
13	.3201	.3734	.3921		.3801
14	.3201	.3921	.3734		.3801
15	.3201	.3734	.3734		.362
16	.3401	.3734	.3734		.3801
17	.3201	.3734	.3734		.3801
18	.3048	.3696	.3734		.362
19	.2286				
Max	.3801	.3921	.3921	.2896	.3982
Min	.2286	.0924	.2772	.181	.362
Avg	.3231	.3202	.3686	.2120	.3774

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 208 / 11 KV Bubnal Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.2353	.2402	.128	.2075	
4	.2353	.2402	.1267	.2452	
5	.2353	.2402	.1294	.2452	
6	.2353	.2402	.1294	.2452	
7	.2353	.2402	.1294	.2452	
8	.2353	.2957	.1294	.2452	.2452
9	.2896	.2987	.2987	.2452	.2452
10	.2896	.2801	.2926	.2452	.2452
11		.2987	.2926	.2378	.2241
12		.2987	.2801	.2427	.2241
13		.2987	.2987	.2378	.2427
14		.3142	.2614	.2427	.2427
15		.2987	.2241		.2241
16		.2801	.2218		.2427
17		.2801	.2218		.2427
18		.2801	.2241		.2241
Max	.2896	.3142	.2987	.2452	.2452
Min	.2353	.2402	.1267	.2075	.2241
Avg	.2489	.2766	.2118	.2404	.2366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 201 / 11 KV Nandani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0179	.6722	.6722	.8215	.0181	.0175	.0175
2	.0179	.6722	.6722	.7842	.0181	.0175	.0175
3	.0179	.6653	.6722	.7842	.0181	.0175	.0175
4	.0181	.7095	.7095	.7842	.0181	.0175	.0187
5	.0181	.7095	.7095	.7468	.0181	.0175	.0175
6	.0181	.7842	.7095	.7468	.0181	.0175	.0175
7	.0181	.8962	.7842	.8962	.0181	.0175	.0175
8	.0181	.9709	.8962	1.1203	.0179	.0175	.0175
9	.0181	.9709	1.0829	1.0498	.0179	.0175	.0175
10	.0181	.0187	.0179	.0181	.0187	.0179	.0175
11	1.3032	.0187	.0179	.0175	1.3443	1.419	1.307
12	1.3306	.0187	.0179	.0175	1.3817	1.3817	1.307
13	1.2197	.0187	.0181	.0175	1.3817	1.3957	1.2323
14	1.2197	.0187	.0181	.0175	1.307	1.3957	1.1576
15	1.2197	.0187	.0181	.0175	1.1203	1.307	1.1203
16	1.2936	.0187	.0181	.0175	1.1576	1.1949	1.2323
17	1.2696	.0187	.0181	.0175	1.251	1.3443	1.2323
18	.8573	.0187	.0187	.0179	1.1222	1.2696	1.2071
19	.0187	.0187	.0187	.0179	.0175	.0187	.0181
20	.0187	.0187	.0187	.0179	.0175	.0187	.0181
21	.0187	.0187	.0187	.0179	.0175	.0187	.0181
22	.0187	.0187	.0187	.0179	.0175	.0187	.0179
23	.0187	.0187	.0187	.0179	.0175	.0175	.0179
24	.0179	.6348	.6348	.8215	.0181	.0175	.0175
Max	1.3306	.9709	1.0829	1.1203	1.3817	1.419	1.307
Min	.0179	.0187	.0179	.0175	.0175	.0175	.0175
Avg	.4169	.3311	.3250	.3668	.4314	.4580	.4200



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 202 / 11 KV Nandani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2896	.2801	.2987	.2534	.2454	.2454
2	.2896	.2801	.2987	.2534	.2454	.2454
3	.2896	.2801	.2801	.2534	.2454	.2454
4	.2896	.2801	.2801	.3258	.2454	.2454
5	.362	.3361	.3734	.362	.298	.298
6	.4344	.4108	.4108	.4163	.298	.333
7	.4706	.4668	.4294	.4525	.3681	.4031
8	.4344	.3921	.4108	.4119	.4031	.3856
9	.362	.3547	.3921	.394	.333	.3506
10	.362	.3772	.3734	.4294	.3403	.3547
11	.3982	.4108	.3734	.3921	.3734	.3547
12	.3982	.3593	.4108	.3921	.4108	.3696
13	.2715	.3734	.4108	.2427	.2641	.2614
14	.2896	.2915	.3734	.2614	.2641	.3174
15	.3982	.3734	.3734	.2801	.3361	.2054
16	.362	.4108	.4108	.3361	.3734	.3361
17	.3982	.4294	.4108	.3921	.3511	.3734
18	.362	.3361	.4108	.2987	.2987	.3772
19	.4887	.4668	.4481	.3681	.4294	.4344
20	.4706	.4108	.4481	.4207	.5228	.4706
21	.4344	.3734	.4668	.4557	.4108	.3982
22	.3982	.3174	.4294	.3506	.3921	.3582
23	.3258	.3361	.3547	.3155	.3361	.3224
24	.3258	.2987	.3361	.2896	.2804	.2804
Max	.4887	.4668	.4668	.4557	.5228	.4706
Min	.2715	.2801	.2801	.2427	.2454	.2054
Avg	.3711	.3603	.3835	.3478	.3361	.3319

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 203 / Ganesh Bakery

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.112	.0934	.0934	.1086	.1402	.1227
2	.1075	.112	.112	.0934	.1086	.1402	.1227
3	.1075	.112	.112	.0934	.1086	.1402	.1402
4	.1254	.0934	.0934	.0934	.1267	.1052	.1402
5	.1448	.1307		.0934	.1448	.1052	.1227
6	.181	.1867	.1867	.1307	.181	.1402	.1402
7	.1991	.2241	.3174	.1867	.1991	.1753	.1928
8	.2353	.1867	.2987	.2241	.2149	.2103	.2241
9	.2534	.2801	.3361	.2172	.2402	.2454	.2279
10	.2353	.2614	.2686	.2715	.2427	.1791	.2454
11	.2896	.1943	.3045	.2629	.2614	.2427	.2614
12	.2957	.3174	.2865	.2629	.2801	.2614	.2987
13	.2957	.2987	.3077	.2454	.2987	.2452	.2614
14	.2218	.2614	.2896	.2279	.2427	.2641	.2801
15	.2772	.2801	.2715	.2279	.2801	.2427	.2801
16	.2587	.2987	.3077	.2279	.2801	.2427	.2987
17	.2614	.3174	.2534	.2454	.2987	.2427	
18	.2987	.2614	.2427	.2507	.2715	.2614	.2641
19	.2801	.2614	.2054	.2507	.2454	.2241	.2353
20	.2427	.1867	.1867	.2149	.2103	.1867	.2172
21	.2241	.168	.1494	.1791	.1753	.168	.181
22	.1867	.1494	.1307	.1612	.1227	.1307	.1612
23	.0373	.1494	.112	.1433	.1227	.1052	.1433
24	.1075	.0373	.0934	.112	.1267	.1052	.1227
Max	.2987	.3174	.3361	.2715	.2987	.2641	.2987
Min	.0373	.0373	.0934	.0934	.1086	.1052	.1227
Avg	.2073	.2034	.2156	.1879	.2038	.1877	.2037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 204 / 11 KV Agar Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.181	.1867	.1867	.0191	.181	.2172	.2103
2	.181	.1867	.1867	.1867	.181	.2103	.2103
3	.181	.2054	.2054	.2096	.181	.2103	.2103
4	.181	.1867	.2229	.1905	.181	.2103	.2103
5	.2172	.2427	.2427	.2477	.1991	.2103	.2103
6	.2172	.218	.1867	.2477	.2172	.2103	.2103
7	.2353	.2614	.2614	.2667	.2353	.2454	.2454
8	.2896	.3174	.2915	.3239	.2507	.2454	.2629
9	.3077	.3361	.3734	.3429	.2507	.298	.3155
10	.2715	.3361	.3361	.3429	.2241	.2507	.2801
11	.2896	.2987	.2241	.3048	.2427	.3547	.2987
12	.3258	.2572	.7716	.2858	.2241	.2987	.2772
13	.3258	.2427	.2987	.2477	.168	.2641	.2614
14	.2534	.2801	.2801	.2858	.2054	.2263	.2801
15	.2715	.2403	.3174	.2667	.2241		
16	.2534	.2801	.2987	.2858	.1867		.3361
17	.2534	.2987	.2801	.3048	.2241	.2772	.3547
18		.3174	.2801	.3239	.2801	.2987	.3395
19	.3258	.3174	.2614	.3429	.2804	.3361	.362
20	.3077	.3361	.2801	.2858	.3155	.3547	.3258
21	.2715	.2427	.2987	.2477	.2804	.2801	.2896
22	.2534	.2614	.2614	.2667	.2454	.2614	.2507
23	.2172	.2054	.2241	.2096	.2103	.2241	.2149
24	.2172	.1867	.1867	.1867	.2172	.1753	.1753
Max	.3258	.3361	.7716	.3429	.3155	.3547	.362
Min	.181	.1867	.1867	.0191	.168	.1753	.1753
Avg	.2534	.2601	.2815	.2593	.2252	.2573	.2666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 205 / 11KV Dharangutti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	1.9605	1.8298	1.6244	.0362	.0351	.0351
2	.0358	1.9605	1.9044	1.7177	.0362	.0351	.0351
3	.0358	1.9978	1.9605	1.7551	.0362	.0351	.0351
4	.0358	1.9605	1.9978	1.7551	.0362	.0351	.0351
5	.0362	1.9791	1.9791	1.9044	.0362	.0351	.0351
6	.0362	2.2218	1.9231	1.9044	.0362	.0351	.0351
7	.0362	2.2965	1.9605	2.2405	.0362	.0351	.0351
8	.0362	2.4646	2.2405	2.2032	.0358	.0351	.0351
9	.0362	2.4832	2.4086	2.1719	.0179	.0351	.0351
10	.0362	.0373	.0358	.0362	.0373	.0358	.0351
11	3.0769	.0373	.0358	.0351	2.8006	2.9874	3.1741
12	3.1417	.0373	.0358	.0351	2.8753	3.0434	3.0994
13	3.1047	.0373	.0362	.0351	2.894	3.0367	2.9687
14		.0373	.0362	.0351	2.8006	2.9801	2.95
15	2.8645	.0373	.0362	.0351	2.7446	2.8753	2.8753
16	2.9199	.0373	.0362	.0351	2.5579	2.8567	2.9313
17	2.95	.0373	.0362	.0351	2.5953	2.9313	2.838
18	2.8006	.0373	.0373	.0358	2.4253	2.8006	2.9424
19	.0373	.0373	.0373	.0358	.0351	.0373	.0362
20	.0373	.0373	.0373	.0358	.0351	.0373	.0362
21	.0373	.0362	.0373	.0358	.0351	.0373	.0362
22	.0373	.0934	.0373	.0358	.0351	.0373	.0358
23	.0373	.0373	.0373	.0358	.0351	.0351	.0358
24	.0358	1.9044	1.8298	1.6244	.0362	.0351	.0351
Max	3.1417	2.4832	2.4086	2.2405	2.894	3.0434	3.1741
Min	.0358	.0362	.0358	.0351	.0179	.0351	.0351
Avg	.9322	.9086	.8561	.8082	.9271	1.0034	1.0144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 201 / MINCHE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1943	.421	.3887	.3887	.2294	.2267	.2267
2	.1943	.421	.3887	.3887	.2294	.2267	.2267
3	.1943	.421	.3887	.3887	.2294	.2267	.2267
4	.1943	.421	.3887	.421	.2294	.2267	.2267
5	.1943	.4858	.5182	.4858	.2622	.2267	.2267
6	.2267	.7125	.7125	.7449	.2622	.2591	.2591
7	.2591	.9717	1.1336	1.1012	.2622	.2591	.2267
8	.3077		1.2955	1.3603	.2949	.2294	.2591
9	.1943	1.2308	1.3108	1.3763	.2267	.2294	.1943
10	.1943	.1943	.1966	.1966	.2267	.1966	.1943
11	1.166	.1943	.1966	.1966	1.2955	1.1469	1.2308
12	1.2631	.1943	.1311	.1966	1.3603	1.3108	1.3603
13	1.2631	.1943	.1311	.1966	1.4251	1.3108	1.2955
14	1.4251	.1943	.1311	.1966	1.3923	1.278	1.2955
15	1.3927	.1943	.1311	.1966	1.2955	1.2452	1.166
16	1.2955		.1311	.2294	1.2955	1.3108	1.2308
17	1.2631		.1943	.2294	1.3603	1.2452	1.2452
18	.9717	.2267	.2591	.2622	1.2631	.6478	1.0486
19	.2915	.3239	.3239	.3277	.3239	.3239	.2949
20	.3239	.3239	.3239	.3605	.3239	.2915	.2949
21	.2915	.2591	.2915	.3277	.2591	.2591	.2622
22	.2267	.2534	.2591	.3277	.2591	.2591	.2622
23	.1943	.2267	.2591	.2622	.2267	.2267	.2622
24	.1943	.421	.3887	.3887	.2294	.2267	.2267
Max	1.4251	1.2308	1.3108	1.3763	1.4251	1.3108	1.3603
Min	.1943	.1943	.1311	.1966	.2267	.1966	.1943
Avg	.5715	.3945	.4114	.4396	.6151	.5579	.5726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 202 / NARANDE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4534	.0648	.0648	.0648	.4801	.4858	.583
2	.4534	.0648	.0648	.0648	.4801	.4858	.583
3	.4534	.0648	.0648	.0648	.4801	.4858	.583
4	.4534	.0648	.0648	.0648	.4801	.4858	.583
5	.4858	.0648	.0648	.0648	.5121	.7125	.583
6	.6478	.0648	.0648	.0648	.6401	.7773	.6478
7	.8421	.0972	.0648	.0972	.8962	.9069	.9717
8	1.0688	.096	.0648	.0648	1.0883	.9602	1.166
9	1.1012	.096	.064	.064	1.1336	1.1203	1.0688
10	.0648	.0914	.064	.064	.0648	.064	.0648
11	.0648	1.2803	1.4723	1.4083	.0648	.064	.0648
12	.0648	1.4899	1.4723	1.4723	.0648	.064	.0648
13	.0648	1.4899	1.5684	1.3763	.065	.064	.0648
14	.0648	1.4575	1.5364	1.3443	.0671	.0643	.0648
15	.0648	1.2631	1.5364	1.3763	.0648	.064	.0648
16	.0648		1.5364	1.5729	.0648	.0643	.0648
17	.0648		1.5223	1.2803	.0648	.064	.096
18	.0972	.7773	.9717	1.1843	.0972	.0648	.096
19	.0972	.0972	.0972	.096	.0972	.0972	.096
20	.0972	.0972	.0972	.096	.0972	.0972	.096
21	.0648	.0972	.0972	.096	.0972	.0972	.096
22	.0648	.0648	.0972	.064	.0648	.0648	.096
23	.0648	.0648	.0972	.064	.0648	.0648	.064
24	.4534	.0648	.0648	.0648	.4801	.4858	.583
Max	1.1012	1.4899	1.5684	1.5729	1.1336	1.1203	1.166
Min	.0648	.0648	.064	.064	.0648	.064	.064
Avg	.3090	.4097	.5339	.5073	.3213	.3294	.3519

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 203 / KHOCHI AG FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7125	.1296	.1296	.0648	1.1336	2.1376	1.0364
2	.7125	.1296	.1296	.0648	1.1336	2.1376	1.0364
3	.7125	.1296	.1296	.0648	1.1336	2.1376	1.0364
4	.7125	.1296	.1296	.0648	1.1336	2.1376	1.0364
5	.8097	.1296	.1296	.0648	1.166	2.2672	1.1012
6	1.0364	.1296	.1296	.0648	1.2631	2.3968	1.166
7	1.1012	.1296	.1296	.0648	1.3603	2.591	1.2955
8	1.2308	.1296	.1296	.0648	1.5546	1.5223	2.7206
9	2.3967	.1296	.0648	.0648	1.4899	1.6194	2.7854
10	.0648	.1296	.0648	.0648	.0648	.0648	.1296
11	.0648	3.8866	2.2024	2.1765	.0648	.0648	.0663
12	.0648	4.1458	2.2672	2.2672	.0648	.0648	.0663
13	.0648	4.1458	2.1376	2.2024	.0648	.0648	.0648
14	.0648	4.1458	2.2024	2.2024	.0648	.0648	.0613
15	.0648	3.8866	2.2024	2.1376	.061	.0648	.0648
16	.0648		2.2024	2.0405	.1296	.0648	.0648
17	.0648		2.1376	2.0081	.1296	.0648	.0648
18	.0648	3.5628	2.0081	1.9433	.1296	.0648	.0648
19	.1296	.1296	.0648	.0648	.1296	.0648	.0648
20	.1296	.1296	.0648	.0648	.1296	.0648	.0648
21	.1296	.1296		.0648	.1296	.0648	.0648
22	.1296	.0648	.061	.0648	.1296	.0648	.0648
23	.0648	.0648	.0648	.0648	.1296	.0648	.0648
24	.7125	.1296	.1296	.0648	1.1336	2.1376	1.0364
Max	2.3967	4.1458	2.2672	2.2672	1.5546	2.591	2.7854
Min	.0648	.0648	.061	.0648	.061	.0648	.0613
Avg	.4710	1.1690	.8222	.7506	.5802	.9163	.6343

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 204 / BENDA VADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	1.0364	.9717	1.0608	.0648	.0648	.0663
2	.0663	1.0364	.9717	1.0608	.0648	.0648	.0663
3	.0663	1.0364	.9717	1.0608	.0648	.0648	.0663
4	.0663	1.0364	.9717	1.0608	.0648	.0648	.0663
5	.0663	1.0364	.9717	1.1271	.0648	.0648	.0663
6	.0663	1.1336	1.0364	1.1934	.0648	.0648	.0663
7	.0663	1.326	1.1984	1.326	.0648	.0648	.0663
8	.0663	1.4586	1.4251	1.5912	.0648	.0648	.0663
9	.0648	1.4586	1.4251	1.5546	.0663	.0648	.0648
10	.0648	.0663	.0648	.0648	.0663	.0648	.0648
11	1.8138	.0663	.0648	.0648	1.7238	1.6194	1.989
12	2.0271	.0663	.0648	.0648	1.989	1.9433	1.989
13	1.8138	.0648	.0648	.0648	1.989	1.9433	1.989
14	1.8138	.0648	.0648	.0648	1.8564	1.9433	1.8564
15	1.8138	.0648		.0648	1.8564	1.8138	2.0271
16	1.8138		.0648	.0648	1.8564	1.8138	1.8564
17	1.829		.0663	.0648	1.8138	1.8138	1.8138
18	1.2955	.0648	.0663	.0648	1.6194	1.8138	1.6194
19	.0648	.0648	.0663	.0648	.0648	.0663	.0648
20	.0648	.0648	.0663	.064	.0648	.0663	.0648
21	.0648	.0648	.0663	.0648	.0648	.0663	.0648
22	.0648	.0648	.0648	.0648	.0648	.0663	.0648
23	.0648	.0648	.0648	.0648	.0648	.0663	.0732
24	.0663	1.0364	.9717	1.0608	.0648	.0648	.0663
Max	2.0271	1.4586	1.4251	1.5912	1.989	1.9433	2.0271
Min	.0648	.0648	.0648	.064	.0648	.0648	.0648
Avg	.6363	.5626	.5115	.5418	.656	.6562	.6750



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 205 / BENDA VADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	.1086	.1086	.1086	.1097	.1086	.1086
2	.1086	.1086	.1086	.1086	.1097	.1086	.1086
3	.1086	.1086	.1086	.1086	.1097	.1086	.112
4	.1086	.1086	.1086	.1086	.1097	.1086	.1086
5	.1086	.1086	.1448	.1086	.1097	.1448	.1086
6	.1448	.1448	.1448	.1086	.1463	.1448	.1448
7	.1448	.181	.1448	.1448	.1463	.181	.181
8	.1448	.1448	.1448	.1448	.1463	.1463	.181
9	.1448	.1448	.1463	.1463	.1448	.1463	.1448
10	.1448	.1448	.1463	.1463	.1448	.1463	.1448
11	.1448	.1086	.1097	.1097	.1086	.1463	.1448
12	.1448	.1448	.1463	.1463	.1086	.1097	.1819
13	.1448	.1448	.1097	.1463	.1448	.1097	.1086
14	.1448	.1086	.1097	.1463	.1448	.1097	.1448
15	.1448	.1086	.1097	.1463	.1086	.1463	.1448
16	.1448		.1463	.1463	.1448	.1463	.1494
17	.1448		.1448	.1463	.1086	.1463	.1829
18	.181	.181	.1448	.1463	.1448	.1448	.1829
19	.2172	.2172	.181	.2195	.2172	.181	.2195
20	.2172	.2172	.2172	.2561	.2172	.181	.2195
21	.181	.181	.181	.2195	.181	.181	.2195
22	.1448	.1448	.1448	.1829	.1448	.1448	.1829
23	.1086	.1086	.1448	.1097	.1086	.1086	.1463
24	.1086	.1086	.1086	.1086	.1097	.1086	.1086
Max	.2172	.2172	.2172	.2561	.2172	.181	.2195
Min	.1086	.1086	.1086	.1086	.1086	.1086	.1086
Avg	.1433	.1399	.1377	.1443	.1362	.1378	.1533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 206 / Khochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2534	.2534	.2241	.2195	.2534	.2614
2	.2241	.2534	.2534	.2241	.2195	.2534	.2614
3	.2241	.2534	.2534	.2241	.2195	.2534	.2614
4	.2241	.2534	.2534	.2241		.2534	.2614
5	.2614	.2896	.2896	.2614	.2195	.2896	.2614
6	.2987	.362	.362	.3361	.3658	.362	.2987
7	.2987	.3734	.2896	.3734	.2926	.3258	.2241
8	.2987	.2614	.2896	.3734	.2561	.2926	.2534
9	.2172	.2241	.2926	.2926	.2241	.2926	.2172
10	.2172	.1867	.2926	.2926	.1867	.2561	.2172
11	.2172	.2241	.2561	.1097	.1494	.2195	.1867
12	.2172	.2241	.2561	.2926	.1494	.2561	.1867
13	.181	.2172	.2926	.2561	.1867	.2561	.1494
14	.1448	.2172	.2561	.2926	.1867	.2561	.1494
15	.1448	.2172	.2561	.2926	.2241	.2926	.2241
16	.181		.2561	.2926	.2241	.2926	.2241
17	.2534		.2987	.2926	.2534	.2561	.2926
18	.2896	.362	.3361	.2926	.2896	.3734	.3292
19	.3982	.4344	.4481	.439	.4344	.5228	.3658
20	.4344	.4344	.4481	.439	.4344	.4481	.3658
21	.362	.362	.3734	.4024	.362	.3734	.3658
22	.2896	.2896	.3361	.3292	.362	.3361	.3292
23	.2534	.2534	.2987	.2561	.2896	.2987	.2926
24	.2241	.2534	.2534	.2241	.2195	.2534	.2614
Max	.4344	.4344	.4481	.439	.4344	.5228	.3658
Min	.1448	.1867	.2534	.1097	.1494	.2195	.1494
Avg	.2533	.2818	.2998	.2932	.2595	.3028	.2600

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 207 / Narand Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0724	.1086	.112	.0732	.1086	.0747
2	.0747	.0724	.1086	.112	.0732	.1086	.0747
3	.0747	.0724	.1086	.112	.0732	.1086	.0747
4	.0747	.0724	.1086	.112	.0732	.1086	.0747
5	.0747	.1086	.1448	.112	.1097	.1086	.0112
6	.112	.1448	.1448	.112	.1097	.1448	.1494
7	.1494	.1494	.1448	.1494	.1463	.1448	.112
8	.112	.112	.1086	.112	.1097	.1463	.1086
9	.1086	.112	.1097	.1097	.112	.1097	.1086
10	.1086	.1494	.1463	.1097	.112	.0732	.0747
11	.1086	.112	.1463	.1463	.0747	.0732	.0747
12	.1086	.1494	.1463	.1463	.0747	.1097	.0747
13	.1086	.1086	.1097	.1097	.0747	.1097	.0732
14	.1448	.1448	.1097	.1097	.0747	.1097	.0747
15	.1448	.1448	.1463	.1463	.0747	.1097	.1097
16	.1448		.1463	.1463	.0747	.0732	.112
17	.1448		.1494	.1463	.0724	.1097	.1463
18	.181	.1448	.112	.1463	.1448	.112	.1463
19	.2172	.2172	.2241	.1829	.2172	.1867	.2195
20	.2172	.2172	.1867	.1829	.2172	.1867	.2195
21	.181	.181	.1867	.1829	.181	.1867	.1829
22	.1448	.1448	.1494	.1463	.1448	.1494	.1463
23	.1086	.1086	.112	.1097	.1086	.0747	.1097
24	.0747	.1086	.1086	.112	.1097	.1086	.0747
Max	.2172	.2172	.2241	.1829	.2172	.1867	.2195
Min	.0747	.0724	.1086	.1097	.0724	.0732	.0112
Avg	.1247	.1294	.1361	.1319	.1098	.1192	.1095

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 208 / Minche Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2534	.2172	.2614	.2195	.2534	.2614
2	.2241	.2534	.2172	.2614	.2195	.2534	.2614
3	.2241	.2534	.2172	.2614	.2195	.2534	.2614
4	.2241	.2534	.2172	.2614	.2195	.2534	.2614
5	.2241	.2896	.2896	.2987	.2195	.2896	.2987
6	.2987	.362	.362	.2987	.2926	.3258	.3361
7	.3734	.3734	.362	.3734	.2926	.362	.3734
8	.3361	.3361	.362	.2987	.2926	.2926	.3734
9	.362	.2987	.2926	.3658	.2987	.2926	.2896
10	.2896	.3361	.2926	.3292	.2241	.2926	.2896
11	.2896	.3734	.2926	.3292	.1943	.2926	.3734
12	.2896	.2987	.2926	.3292	.2241	.2926	.2987
13	.2534	.2534	.2926	.2926	.2241	.2926	.2241
14	.2896	.2534	.2926	.2561	.2241	.2926	.2987
15	.2896	.2534	.2926	.2561	.2241	.2926	.3361
16	.2896		.2926	.2926	.1867	.2926	.3361
17	.3258		.2987	.3292	.3258	.2926	.2926
18	.0324	.362	.3734	.3292	.3258	.3734	.3658
19	.5068	.5068	.5228	.4755	.4344	.4481	.439
20	.5068	.5068	.5228	.4755	.4344	.4481	.4755
21	.5068	.4344	.4854	.4755	.4344	.4481	.439
22	.362	.3258	.3734	.439	.3982	.3734	.3658
23	.2534	.2534	.2987	.2926	.2896	.2987	.3292
24	.2241	.2534	.2172	.2614	.2195	.2534	.2614
Max	.5068	.5068	.5228	.4755	.4344	.4481	.4755
Min	.0324	.2534	.2172	.2561	.1867	.2534	.2241
Avg	.3000	.3220	.3199	.3268	.2766	.3150	.3267

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 209 / 11KV Buwache Wathar AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.0324	.0324	.0305	1.0852	.9717	.9717
2	.8192	.0324	.0324	.0305	1.0852	.9717	.9717
3	.8192	.0032	.0324	.0305	1.0852	.9717	.9717
4	.8383	.0324	.0324	.0305	1.0852	.9717	.9145
5	.8383	.0324	.0324	.0305	1.0852	.9717	.9717
6	.9724	.0324	.0324	.0305	1.1869	1.1984	.9717
7	1.073	.0312	.0324	.0305	1.2548	1.2955	1.1012
8	1.1065	.0312	.0324	.0305	1.3904	1.3226	1.1984
9	1.1336	.0305	.0339	.0339	1.3279	1.3226	1.2308
10	.0324	.0305	.0339	.0339	.0324	.0351	.0324
11	.0324	1.4899	1.643	1.7772	.0324	.0351	.0305
12	.0324	1.5546	1.6766	1.7974	.0312	.0351	.0305
13	.0324	1.5546	1.7101	1.7436	.0324	.0351	.0305
14	.0324	1.4575	1.6766	1.7295	.0312	.0351	.061
15	.0324	1.4575	1.6766	1.6956	.0312	.0351	.0305
16	.0324		1.6766	1.6278	.0305	.0351	.0305
17	.0324		1.587	1.6095	.0324	.034	.0351
18	.0324	.7449	1.4251	1.5939	.0324	.0305	.0351
19	.0324	.0648	.0312	.0351	.0324	.0305	.0351
20	.0324	.0648	.0305	.0366	.0324	.0305	.0351
21	.0324	.0648	.0312	.0366	.0324	.0305	.0351
22	.0324	.0324	.0305	.0366	.0324	.0305	.0351
23	.0324	.0324	.0305	.0328	.0324	.0305	.0351
24	.8097	.0324	.0324	.0305	1.0852	.9717	.9717
Max	1.1336	1.5546	1.7101	1.7974	1.3904	1.3226	1.2308
Min	.0324	.0032	.0305	.0305	.0305	.0305	.0305
Avg	.4043	.4018	.5660	.5873	.5050	.4763	.4486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 210 / Khandoba AG (Bhendwade) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.5506	.5182	.5975	.0312	.0324	.0324
2	.0312	.5506	.5182	.5182	.0312	.0324	.0305
3	.0312	.5506	.5182	.5182	.0312	.0324	.0305
4	.0312	.5506	.5182	.583	.0312	.0324	.0305
5	.0312	.583	.5182	.6478	.0312	.0324	.0305
6	.0312	.6478	.583	.6478	.0312	.0324	.0305
7	.0324	.7449	.6478	.7449	.0312	.0324	.0305
8	.0312	.7773	.7449	.8097	.0313	.0312	.0305
9	.0324	.8097	.7449	.8002	.0312	.0312	.0324
10	.0324	.0324	.0328	.032	.0324	.0312	.0324
11	.9717	.0324	.032	.0312	1.1222	1.0242	1.0364
12	.9717	.0305	.0313	.0312	.9686	1.0883	1.1012
13	.9717	.0324	.0312	.0312	.9686	1.0883	1.1012
14	.9717	.0324	.0312	.0312	.9686	1.0562	1.0364
15	.9717	.0324	.0312	.0312	.8421	1.0242	1.004
16	1.0364		.0312	.0312	.9069	1.0242	1.004
17	1.0364		.0312	.0312	.9069	1.0242	1.0242
18	.9069	.0324	.0312	.0312	.0324	.9393	.9602
19	.0324	.0324	.0312	.0312	.0324	.0324	.0312
20	.0324	.0324	.0312	.0312	.0324	.0305	.0312
21	.0324	.0324	.0305	.0312	.0324	.0305	.0312
22	.0324	.0324	.0312	.0312	.0324	.0305	.0312
23	.0324	.0324	.0312	.0312	.0324	.0305	.0312
24	.0324	.5506	.5182	.5182	.0312	.0324	.0324
Max	1.0364	.8097	.7449	.8097	1.1222	1.0883	1.1012
Min	.0305	.0305	.0305	.0312	.0312	.0305	.0305
Avg	.3478	.3047	.2612	.2843	.3010	.3657	.3653

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 401 / 33 kv Sharad Co-gen

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.048	4.8285	4.9383		4.6091	4.3896	4.9291
2	4.9291	4.9383	4.9383	4.9291		4.3896	4.481
3	4.9291	4.9383	4.9383	5.1532	4.4993	4.6091	4.9291
4	4.481	4.9383	4.9383	4.7051	4.8285	4.6091	5.2675
5	4.9291	5.3772	4.9383	4.8834	4.1701	4.6091	4.9291
6	5.2675	5.3772	4.9383	5.144	5.2675	4.9383	4.257
7	4.481	6.0357	4.9383	4.5268	5.048	4.3896	4.1701
8	5.6013	5.2126	4.9383	4.5268	.1097	4.9383	4.3896
9	5.048	4.7782	5.487	5.487	.0983	5.9259	4.3896
10	5.3772	3.2579	4.8285	4.8285		5.487	4.3896
11	4.9383	4.3439	5.9259	4.3896	.1097	4.3896	4.9291
12	.4938	5.647	5.7065	6.5844	.1086	4.6091	5.3772
13	4.9383	.1097	4.9383	4.8285	.0972	4.8285	5.2675
14	4.9383	4.8285	5.1578	5.487	.0972		5.2675
15	4.9383	5.487	5.2675	5.487	.0972	4.6091	4.3439
16	4.9383		4.8285	5.2675	.112	4.8285	5.3772
17	4.9383		5.3212	4.8285	.1097	4.7188	4.8285
18	5.487		5.2126	4.3896	.1097	5.1532	5.048
19	5.487	4.3896	4.7782	4.3896	.1097	4.481	4.3896
20	5.1578	4.9383	4.3439	4.3896	.1097	4.3896	4.3896
21	4.9383	4.9383	3.2036	4.1701	4.3896	3.9506	4.3896
22	4.9383	4.9383		4.3896	.1097	4.481	4.4993
23	5.2675	4.9383		3.5117	4.3896	5.2675	4.3896
24	5.3772	4.8285	4.9383	4.7051	4.3896	4.3896	4.9291
Max	5.6013	6.0357	5.9259	6.5844	5.2675	5.9259	5.3772
Min	.4938	.1097	3.2036	3.5117	.0972	3.9506	4.1701
Avg	4.8695	4.7176	4.9747	4.8262	1.9532	4.7122	4.7316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6802	.0191	.0305		.9804	1.0402	1.004
2	.6964	.0191	.0305		.9962	1.0402	1.0364
3	.6964	.0191	.0305		1.0082	1.0402	1.0364
4	.7287	.0191	.0305		.9762	1.0082	1.0364
5	.7773	.0191	.0305		1.0402	.9922	1.0688
6	.8097	.0191	.0305		1.0883	.9922	1.1174
7	.8745	.0191	.0305		1.1069	1.1336	1.2146
8	.9231	.0191	.0305		1.1873	1.2483	1.2955
9	.8907		.0305		1.2323	1.2803	1.247
10	.0324	.0191	.0305		.0305	.0191	.0324
11	.0191	1.8122	1.6842	1.9997		.0324	.0305
12	.0191	1.781	1.7004	1.7604		.0324	.0305
13	.0191	1.8278	1.7166	1.7394		.0324	.0191
14	.0191	1.8122	1.6194	1.7394		.0324	.0191
15	.0191	1.8278	1.6842	1.6804		.0324	.0191
16	.0191		1.6842	1.6004		.0324	.0305
17	.0191		1.6518	1.5043		.0324	.0305
18	.0191	1.6324	1.587	1.4083		.0324	.0305
19	.0191	.0305			.0191	.0324	
20	.0191	.0305		.0305	.0191	.0324	
21	.0191	.0305		.0305	.0191		
22	.0191	.0305		.0305		.0324	
23	.0191	.0305		.0305		.0324	
24	.6316	.0191	.0305		.9686	.9922	1.004
Max	.9231	1.8278	1.7166	1.9997	1.2323	1.2803	1.2955
Min	.0191	.0191	.0305	.0305	.0191	.0191	.0191
Avg	.3329	.5256	.7191	1.1295	.7623	.4859	.5949



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 202 / 11KV Latwade AG Fdr

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.0774	1.0279	1.0159	.061	.0381	.081
2	.0648	1.0774	1.0402	1.065	.061	.0381	.081
3	.0648	1.0774	1.0242	1.065	.061	.0381	.081
4	.0648	1.0442	1.012	1.0978	.061	.0381	.081
5	.0648	1.0277	1.0437	1.1633	.061	.0381	.081
6	.081	1.0277	1.1069	1.2125	.061	.0381	.081
7	.081	1.2266	1.1363	1.278	.061	.0381	.081
8	.081	1.3279	1.2018	1.4419	.061	.0381	.0648
9	.0648	1.2308	1.2334	1.5074	.061	.0381	.0648
10	.081	.0381	.061		.061	.0381	.081
11	1.3279		.0648		1.7695	1.668	1.7604
12	1.4575		.0648	.061	1.9662	1.8785	1.7764
13	1.6518		.0648	.061	1.9006	1.8461	1.8947
14	1.6518		.0648	.061	1.9006	1.8461	1.8623
15	1.6194		.0648	.061	1.8842	1.8947	1.7814
16	1.6356		.0648	.061	1.6876	1.8299	1.7236
17	1.6194		.0648	.061	1.7204	1.749	1.7236
18	1.6032	.061	.0486	.061	1.7695	1.7004	.4321
19	.0381	.061		.061	.0381	.081	
20	.0191	.061		.0305	.0381	.081	
21	.0381	.061		.061	.0381	.081	
22	.0381	.061		.061	.0381	.081	
23	.0381	.061		.061	.0381	.081	
24		1.0526	1.012	.9503	.061	.0381	.081
Max	1.6518	1.3279	1.2334	1.5074	1.9662	1.8947	1.8947
Min	.0191	.0381	.0486	.0305	.0381	.0381	.0648
Avg	.6085	.6808	.6001	.5681	.6442	.6349	.7270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 203 / 11KV Latwade Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.3258	.3224	.3109	.2454	.2715	.2715
2	.2534	.3077	.3224	.2926	.2303	.2534	.2534
3	.2534	.2896	.2835	.2926	.2126	.2534	.2534
4	.3258	.2896	.2835	.3109	.2126	.3077	.3258
5		.3801	.3366	.3658	.3012	.3982	.3982
6		.5792	.5138	.5121	.4382	.5068	.5792
7		.6516	.6485	.6036	.5258	.5249	.6154
8		.6154	.5434	.6219	.5014	.5611	.5792
9		.5068	.4733	.5487	.4382	.5068	.5249
10	.5068	.4344	.443	.4755	.443	.543	.4887
11	.5068	.4938	.4163	.5121	.4207	.4887	.4733
12	.5249	.4938	.4344	.4784	.4572	.5249	.4733
13	.5611	.5487	.4344	.4382	.4572	.5068	.5068
14	.4706	.4938	.4525	.3681	.4207	.4706	.5068
15	.4534	.4572	.4525	.4031	.4024	.4887	.5068
16	.5068		.4706	.4382	.3841	.5249	.4908
17	.4706		.4706	.4607	.3475	.543	.5138
18	.5792	.5434	.5249	.4784	.4755	.5792	.4784
19	.6154	.6485	.6219	.631	.543	.6878	.6036
20	.6154	.691	.5853	.5609	.5304	.6154	.6219
21	.5249	.6201	.4938	.5258	.4938	.543	.5487
22	.5068	.567	.4755	.4908	.4344	.4525	.439
23	.4163	.4075	.4207	.3506	.362	.5068	.3658
24	.2896	.3258	.3403	.3109	.2454	.2715	.2715
Max	.6154	.691	.6485	.631	.543	.6878	.6219
Min	.2534	.2896	.2835	.2926	.2126	.2534	.2534
Avg	.4554	.4850	.4485	.4492	.3968	.4721	.4621

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 204 / Laxmi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0191	.0305		.4999	.5053	.4755
2		.0191	.0305		.4999	.5053	.4755
3		.0191	.0305		.4687	.5053	.4755
4	.4161	.0191	.0305		.4687	.5053	.5053
5		.0191	.0305		.5247	.535	.5053
6	.4755	.0191	.0305		.6097	.5647	.535
7	.4755	.0191	.0305		.6401	.6836	.5944
8	.6241	.0191	.0305		.7968	.8025	.7133
9	.6539	.0191	.0305		.6874	.8025	.7133
10	.0297	.0191	.0305		.0305	.0191	.0305
11	.0191	.945	1.1888	.9907		.0297	.0305
12	.0191	1.0059	1.2186	1.1717		.0297	.0305
13	.0191	1.1126	1.1888	1.1717		.0297	.0191
14	.0191	1.0974	1.0997	1.1561		.0297	.0191
15	.0191	1.0364	1.07	.9755		.0297	.0191
16	.0191		1.0402	.9061		.0297	.0305
17	.0191		1.0402	.8436		.0297	.0305
18	.0191	.7811	.9511	.7811		.0297	.0305
19	.0191	.0305		.0305	.0191	.0446	
20	.0191	.0305		.061	.0191	.0486	
21	.0191	.0305		.061	.0191		
22	.0191	.0305		.0305	.0191		
23	.0191	.0305		.0305	.0191	.0297	
24		.0191	.0305		.4877	.5053	.4755
Max	.6539	1.1126	1.2186	1.1717	.7968	.8025	.7133
Min	.0191	.0191	.0305	.0305	.0191	.0191	.0191
Avg	.1538	.2882	.4807	.6315	.3631	.2861	.3005

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 205 / Tasgaon LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6		.2743	.3401			
7	.3401	.3601	.3401	.3601	.3601	.1619
8	.3401	.3601	.3441	.3601	.3601	.1619
9	.3401	.3601	.3521	.3601	.3601	.1619
10	.3401	.3601	.3441	.3601	.3601	.1619
11	.3601	.3601	.3401	.3601	.3401	.3277
12	.3601	.3601	.3401	.3521	.3401	.3401
13	.3601	.3601	.3401	.3401	.3401	.3601
14	.3601	.3601	.3401	.3401	.3401	.3601
15	.3772	.3601	.3401	.3441	.3401	.3601
16	.3601		.3401	.3521	.3401	.3521
17	.3601		.3401	.3521	.3401	.3441
18	.3601		.3401	.3521	.3401	.3521
Max	.3772	.3601	.3521	.3601	.3601	.3601
Min	.3401	.2743	.3401	.3401	.3401	.1619
Avg	.3549	.3515	.3416	.3528	.3468	.287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 201 / 11 KV KATALI VILLAGE  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.5721	.5544	.7316	.3982	.1109	.0503
2	.0724	.5201	.5175	.7207	.3801	.0924	.0335
3	.0716	.4458	.4706	.7316	.3658	.0747	.0339
4	.0716	.4115	.4344	.6984	.3658	.0886	.0509
5	.1086	.4287	.439	.7059	.3696	.0924	.052
6	.1448	.4748	.4251	.394	.4251	.124	.104
7	.1949	.5935	.5121	.5194	.6283	.2303	.2229
8	.3688	.3521	.1715	.2469	1.0985	1.3112	1.4706
9	.3441	.3315	.1174	.3048	.7265	1.6124	1.5775
10	.3521	.4024	.16	.3048	1.4266	1.9281	1.0802
11	.4096	.3353	.1698	.2896	1.4883		1.4413
12	.426	.3696	.1524	.25	1.5592	1.9281	1.4074
13	.4287	.4251	.1806		1.2757	1.949	1.6632
14	.4096	.3881	.216	.3048	1.5238	1.8625	1.6804
15	.4287	.3801	.3086	.3201	1.3466	1.6827	1.4582
16	.4108	.3429	.3761	.3403	.3361	1.5604	.9709
17	.4251	.3734	.4344	.4066	.3881	.4854	.4607
18	.415	.0554	.394	.415	.4066	.5316	.4287
19	.3961	.0373	.3696	.4066	.4668	.4024	.3326
20	.3174	.2427	.2896	.3582	.3511	.3696	.3547
21	.2452	.5041	.2865	.4706	.3142	.3584	
22	.8131	.7207	.8859	.5083	.1772	.208	.1907
23	.7186	.6283	.8238	.5194	.1417	.1402	
24	.0732	.5784	.5914	.7499	.4656	.128	.1006
Max	.8131	.7207	.8859	.7499	1.5592	1.949	1.6804
Min	.0716	.0373	.1174	.2469	.1417	.0747	.0335
Avg	.3216	.4131	.3867	.4651	.6844	.7509	.6893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 205 / 11 KV ANDUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.0171			.0181	1.3169	1.2071
2	1.2308	.0173		.0185	.0181		1.1736
3	1.1999	.0171	.0187	.0183	.0181	1.3535	1.1869
4	1.2178	.017	.0187	.0179	.0183	1.2757	1.1191
5	1.2489	.0171	.0187	.0181	.0185	1.3352	1.1269
6	1.267	.017	.0185	.0179	.0185	1.2757	1.1789
7	1.2934	.017	.0185	.0179	.0185	1.382	1.1831
8	1.8107	2.079	1.8023	1.8827	.0177	1.2934	.0177
9	1.9281	2.2043	2.0119	2.0119	.0185	.0177	.0175
10	1.8023	2.3137	1.9524	2.0119	.0185	.0175	.0171
11	1.8976	2.2131	1.929	1.8138	.0185	.0175	.017
12	1.8976	.037	1.8595	1.9841	.0185	.0175	
13	1.9204	.4066	1.8663		.017	.0177	.0171
14	1.8442	.924	1.8519	1.6461	.0177	.0175	.0171
15	1.8652	1.9728	1.5741	1.6004	.0177	.0175	.017
16	.0187	1.9376		.0179	.0187	.0173	.0173
17	.0185	1.8519	.0181	.0185	.0185	.0173	
18	.0189	.0187	.0179	.0189	.0185	.0177	.0171
19	.0377	.0187	.0185	.0185	.0187	.0183	.0185
20	.0187	.0187	.0181	.0179	.0185	.0185	.0187
21	.0189	.0185	.0179	.0181	.0185	.0189	
22	.0185	.0185	.0177	.0175	1.2269	1.283	1.3176
23	.0175	.0185	.0179	.0179	1.3998	1.3321	1.2717
24	1.3169	.0175	.0185	.0183	.0179	1.3575	1.2407
Max	1.9281	2.3137	2.0119	2.0119	1.3998	1.382	1.3176
Min	.0175	.017	.0177	.0175	.017	.0173	.017
Avg	1.0495	.6745	.7183	.6010	.1262	.5842	.5808

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 207 / 11 KV KARVIIR EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0351	.0191	.0191	.0191	.0175	.0377	.0381
2	.0366	.0191	.0191	.0191	.0177	.0377	.0381
3	.0362	.0191	.0191	.0191	.0175	.0373	.0381
4	.0366	.0191	.0191	.0191	.0175	.0377	.0381
5	.0373	.0191	.0191	.0191	.0175	.0373	.0381
6	.037	.0191	.0191	.0191	.0177	.0373	.0381
7	.037	.0191	.0191	.0377	.0181	.0373	.0381
8	.0351	.0191	.0171	.0381	.0181	.0377	
9		.0191	.017	.0191	.0351	.0185	.0191
10	.0554	.0191	.0509	.0377	.0354	.0187	.0381
11	.056	.0191	.0543	.052	.0191	.0191	.0191
12	.0537	.0191	.0486	.0543	.0191	.0191	.0191
13		.0191			.0191	.0191	.0191
14	.0543	.0191	.0358	.0526	.0377	.0381	.037
15	.0537	.0191	.0187	.0526	.056	.0572	.0189
16	.0543	.0191	.0358	.0526	.056	.0381	.0189
17	.0181	.0191	.0362	.0181	.0191	.0381	.0187
18	.0191	.0171	.0191	.0181	.0191	.0191	.0189
19	.0191	.0191	.0191	.0175	.0191	.0191	.0187
20	.0191	.0191	.0191	.0177	.0191	.0191	.0185
21	.0191	.0191	.0191	.0175	.0191	.0191	.0373
22	.0191	.0191	.0191	.0175	.0191	.0191	.056
23	.0191	.0191	.0191	.0177	.0377	.0191	.0373
24	.0187	.0191	.0191	.0191	.0175	.0373	.0191
Max	.056	.0191	.0543	.0543	.056	.0572	.056
Min	.0181	.0171	.017	.0175	.0175	.0185	.0185
Avg	.0350	.0190	.0253	.0285	.0245	.0299	.0296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 201 / 11 KV Shiye Ag Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0655	.0655	.0655	.0819	.0819	.0747
2	.0819	.0655	.0655	.0655	.0819	.0819	.0655
3	.0819	.0655	.0655	.0655	.0819	.0819	.0747
4	.0819	.0655	.0655	.0655	.0819	.0819	.0655
5	.0819	.0655	.0655	.0655	.0819	.0819	.0655
6	.0819	.0655	.0655	.0655	.0819	.0819	.0655
7	.0819	.0655	.0655	.0655	.0819	.0819	.0655
8	.0819	.0655	.0655	.0655	.0819	.0819	.0655
9	.0838	.0655	.0655	.0655	.0819	.0819	.0655
10	.0819	.0819	.0671	.0819	.0819		.0819
11	1.8023	2.13	2.1125	2.2775	1.8023	2.2939	2.5396
12	2.2939	2.1628	2.3137	2.2447	2.2119	2.2939	2.3403
13	2.2939	2.2939	2.3137	2.1792	2.13	2.2283	2.4741
14	2.2283	2.2283	2.146	2.1792	1.9662	2.1628	2.3266
15	2.13	2.1628	2.079	2.1464	1.9662	2.13	2.3102
16	2.0481	2.13	2.146	2.2119	1.307	2.5019	2.4086
17	1.3108	2.13		2.2283	1.1469	2.2119	2.4086
18	1.1797	1.9662	2.13	2.1795	1.9498	2.2119	2.4143
19	.0655	.0655	.0655	.0819	.0819	.0655	.0838
20	.0655	.0655	.0655	.0819	.0819	.0655	.0838
21	.0655	.0655	.0655	.0819	.0819	.0655	.0838
22	.0655	.0655	.0655	.0819	.0819	.0655	.0838
23	.0655	.0655	.0655	.0819	.0819	.0655	.0819
24	.0819	.0655	.0655	.0655	.0848	.0819	.0655
Max	2.2939	2.2939	2.3137	2.2775	2.2119	2.5019	2.5396
Min	.0655	.0655	.0655	.0655	.0819	.0655	.0655
Avg	.6882	.7612	.7083	.7830	.6581	.8340	.8498



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 202 / 11KV Water Supply -Shiye  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.7619	.8063	.703	.7842	.815	.6874
2	.8589	.7619	.7888	.703	.7842	.815	.6874
3	.8215	.7442	.7888	.703	.7922	.7796	.7186
4	.8215	.7442	.7888	.8029	.8589	.7796	.7499
5	.9709	.7973	.8589	.8124	.8962	.7973	.8124
6	1.1203	.8859	.9816	.8749	.9431	.8328	.9374
7	1.3817	1.1517	1.1218	1.0936	.9522	.8682	1.0936
8	1.5684	1.5061	1.2795	1.3123	.8962	1.2757	1.2498
9	2.1098	1.949	1.9982	1.531	.9335	1.5947	1.8435
10	1.7185	1.6091	2.3339	2.0908	.8764	1.7528	2.1616
11	1.7966	1.7966	2.4272	2.4274	.7186	1.8755	1.9313
12	1.6248	1.0155		2.073	.6562	2.0157	2.073
13	1.0936	1.2498		1.3466	.6249		1.4352
14	1.1717	1.3748	1.5935	1.382	.6874	1.2795	1.5769
15	1.3748	1.6404		1.9313	.6874	2.0332	1.9313
16	1.4529	1.6716	1.7966	1.9313	.6718	1.9281	2.073
17	1.406	1.7654	1.8278	1.701	.6718	1.7528	1.6478
18	1.134	2.1735	1.0936	1.1389	.7619	.0187	1.1203
19	.9745	1.0517	.8124	1.0456	.8328	.9339	.9425
20	.8859	.929	.7811	.9896	.8328	.8436	.8962
21	.8505	.4207	.7811	.8962	.8328	.7968	.8215
22	.815	.8764	.7499	.8775	.8505	.7655	.8029
23	.7973	.8764	.7343	.8215	.8328	.7343	.7947
24	.8962	.7973	.8238	.7186	.7842	.8328	.703
Max	2.1098	2.1735	2.4272	2.4274	.9522	2.0332	2.1616
Min	.7973	.4207	.7343	.703	.6249	.0187	.6874
Avg	1.1873	1.1896	1.1985	1.2461	.7985	1.1357	1.2371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 203 / 11KV TOP II AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4207		.4239	.3887	1.4083		1.2071
2	.4207		.4239	.4024	1.5089		1.3413
3	.4075		.4239	.4024	1.5424		1.4419
4	.4294		.4239	.4024	1.6476		1.5424
5	.4075		.4239	.4024	1.7002		1.643
6	.4294		.4239	.4024	1.9281		1.7604
7	.4031		.4239	.4024	1.9376		.6706
8	.3856		.407	.4024	.8063		2.0119
9	.3856		.407	.4024	.9991		1.9281
10	.3688	.4024	.4382		.39	.407	.407
11	1.9281	2.1293	2.1312		.4024	.407	.407
12	2.3472	2.1795			.4024	.407	.407
13	2.5149	2.0454			.4024		.407
14	2.5819	2.0119			.4024	.407	.407
15	2.5484	2.0119			.4024	.407	.407
16	2.6322	2.0119			.4024	.407	.407
17	2.4646	2.0119	2.0454		.4024	.407	.407
18		1.3565	1.4754	1.7101		.4024	.4024
19		.407	.4024	.4024		.4024	.3932
20		.407	.4024	.4024		.4024	.4024
21		.407	.4024	.0366		.4024	.4024
22		.4239	.4024	.4024		.4024	.3932
23		.4239	.4024	.4024		.4024	.4024
24	.4207		.4239	.4024	1.2742		.8383
Max	2.6322	2.1795	2.1312	1.7101	1.9376	.407	2.0119
Min	.3688	.4024	.4024	.0366	.39	.4024	.3932
Avg	1.1942	1.3021	.6478	.4604	.9978	.4049	.8349

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.168	.168	.1867	.1494	.1494
2	.1867	.1867	.168	.1494	.1867	.1494	.1494
3	.1867	.1867	.168	.1494	.1867	.1494	.1494
4	.1867	.1867	.168	.1494	.1867	.1494	.1494
5	.2263	.2427	.1867	.168	.2241	.1867	.1867
6	.2614	.2987	.2241	.2054	.2427	.2801	.2241
7	.2801	.2801	.2801	.2801	.2801	.2987	.2614
8	.2801	.2614	.2987	.2427	.3361	.2427	.2801
9	.1886	.2427	.2241	.2241	.2241	.2614	.2241
10	.1867	.2241	.2801	.2427	.1867	.2427	.2054
11	.2534	.2614	.2427	.2801	.1494	.1867	.168
12	.2054	.2241		.2241	.168	.1867	.168
13	.1867	.2054		.168	.1307		.1494
14	.168	.1494	.1494	.168	.1307	.1307	.1494
15	.1494	.1307		.168	.1307	.1307	.1494
16	.168	.1867	.1867	.2054	.1494	.1867	.1867
17	.1867	.2241	.1867	.2241		.1867	.2614
18	.2614	.2427	.2241	.2054	.1867	.1867	.2614
19	.3547	.3361	.3174	.3174	.3174	.3174	.3547
20	.3174	.3734	.3361	.3174	.3547	.3547	.3547
21	.3174	.3547	.3174	.3174	.3361	.3174	.3174
22	.2987	.3174	.2801	.2743	.2987	.2987	.2641
23	.2054	.2427	.2241	.2241	.2054	.2241	.1867
24	.1867	.1867	.168	.1867	.1867	.1867	.1867
Max	.3547	.3734	.3361	.3174	.3547	.3547	.3547
Min	.1494	.1307	.1494	.1494	.1307	.1307	.1494
Avg	.2262	.2388	.2285	.2192	.2167	.2176	.2141

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 202 / 11 KV NIGAWA GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1132	.1143		.1334	.132	.132
2	.1524	.112	.1143		.1334	.132	.1132
3	.1334	.112	.1143		.1334	.132	.1132
4	.1334	.112	.1524		.1334	.132	.1132
5	.1524	.1509	.1715		.1334	.132	.1886
6	.2286	.1867	.2641		.2286	.1886	.2641
7	.2829	.2614	.2614		.2829	.2641	.2667
8	.2427	.2614	.2561	.2614	.2829	.2614	.2772
9	.2587	.3077	.2801	.3189	.2614	.2987	.2241
10	.2715	.3292	.2241	.362	.2452	.2715	.2427
11	.3361	.2883	.2054	.333	.1949	.2507	.2012
12	.1772	.1886	.2172	.2835	.1543	.2534	.2075
13	.181	.1715	.2195	.2149	.1753	.1829	.1886
14	.181	.2629	.16	.2534	.1612	.1463	.1509
15	.2401	.2126	.1457	.1646	.1991	.1949	
16	.1772	.2204	.2012	.2035	.1753	.1791	.2054
17	.2402	.2195	.2926	.2427	.1886	.2103	.2427
18	.2926	.2715	.2402	.2328	.2054	.2658	.2987
19	.3292	.3547	.2987	.3547	.3584	.3881	.3018
20	.3772	.3361	.3547	.3584	.3395	.3547	.2801
21	.3174	.3018	.2614	.2987		.3206	.2987
22	.2241	.2667	.2641	.2667	.2641	.1524	.2587
23	.1886	.1905	.1867	.0189	.1886	.1524	
24	.1524	.1509	.1524		.1334	.1307	.132
Max	.3772	.3547	.3547	.362	.3584	.3881	.3018
Min	.1334	.112	.1143	.0189	.1334	.1307	.1132
Avg	.2259	.2243	.2147	.2605	.2046	.2136	.2137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 204 / 11KV AMBEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0518	.0686	.0762		.0488	.0514	.0564
2	.0526		.0762		.0511	.0514	.0556
3	.0526	.0686	.0762		.0518	.0514	.0412
4	.0533	.0686	.0762		.0472	.0514	.0406
5	.0533	.0686	.0762		.0465	.0514	.0533
6	.0541	.0686	.0762		.0472	.0514	.0587
7	.0533	.0686	.0762		.0488	.0514	.0594
8	.0526	.0686	.0762	.0514	.0503	.0514	.0556
9	.0762	.0434	.0533	.0389	.0488	.0406	.0686
10	.0762	.0747	.0533	.0533	.0503	.0389	.0686
11	1.094	1.1603	1.0014	1.4586	1.1336	1.3413	1.3108
12	1.1469	1.1469	1.3108	1.3413	1.1469	1.326	1.3108
13	1.1797	1.1603	1.3435	1.4251	1.1336	1.3413	1.2452
14	1.1797	1.1736	1.2803	1.1469	.9831	1.2308	1.2407
15	1.0242	1.1317	1.166	1.2407	.9945	1.0364	
16	1.0486	1.0814	1.0486	1.1469	.9602	.9922	1.1736
17		1.0159	.9945	.9069	.9831	.9831	1.0688
18	.8192	.7125	.57	.8002	.7377	.7796	.8642
19	.0686	.0762	.0686	.0549	.0686	.0754	.0579
20	.0686	.0762	.0686	.0541	.0686	.0747	.0587
21	.0686	.0762	.0686	.0533	.0514	.0686	.0526
22	.0686	.0762	.0686	.0472	.0514		.0533
23	.0686	.0762	.0686	.0518	.0514	.0533	.0541
24	.0533	.0686	.0762		.0518	.0514	.0564
Max	1.1797	1.1736	1.3435	1.4586	1.1469	1.3413	1.3108
Min	.0518	.0434	.0533	.0389	.0465	.0389	.0406
Avg	.3680	.4187	.4104	.6170	.3711	.4280	.3959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 205 / 11 KV Kerli Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.096	.12	.1334		.1021	.12	.1067
2	.0975	.12	.1334		.0564	.12	.1067
3	.0975	.12	.1334		.1036	.12	.1113
4	.0991	.12	.1334		.1036	.12	.1097
5	.1006	.1372	.1524		.1006	.1372	.1082
6	.0975	.1372	.1524		.1006	.1372	.1097
7	.0434	.1372	.1524		.1128	.1372	.1067
8	.1021	.1372	.1524	.12	.1036	.1372	.1097
9	.1334	.084	.0854	.084	.1082	.08	.1372
10	.1334	.0827	.1006	.088	.0934	.092	.1372
11	2.0576	2.6993	2.7515	2.1963		2.7831	2.4966
12	2.2891	3.0178	2.8841	3.2065		2.9508	2.9492
13	2.3807	2.834	2.9165	3.1207		2.7206	2.8837
14	2.1963	2.7526	2.753	2.8647	1.3599	2.7183	2.7854
15	2.1628	2.7018	2.753	2.9312	2.4366	2.8346	2.7526
16	2.2211	2.6246	2.8673	2.7989	2.7046	2.915	2.7018
17	1.9826	2.6882	2.7199	2.7199	.5853	2.9165	2.6882
18	1.5581	1.9989	1.0395	2.1559	.5975	2.4177	2.0165
19	.1372	.1524	.1372	.2427	.2229	.1097	.0423
20	.1372	.1715	.1715	.2452	.1372	.1189	.056
21	.1372	.1715	.1715	.2241	.1372	.1143	.0579
22	.1372	.1524	.1372	.2452	.1372	.1113	.04
23	.1372	.1524	.12	.1006	.1372	.1174	.04
24	.0697	.1372	.1334		.1036	.1372	.0975
Max	2.3807	3.0178	2.9165	3.2065	2.7046	2.9508	2.9492
Min	.0434	.0827	.0854	.084	.0564	.08	.04
Avg	.7752	.9771	.9535	1.4590	.4545	1.0069	.9480

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 206 / 11 KV VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.415	.5281		.5228	.5281	.4527
2	.5281	.415	.5281		.5281	.4294	.4715
3	.5281	.4108	.5658		.5175	.5228	.3772
4	.5281	.7167	.6036		.5601	.5601	.3961
5	.5658	.7468	.6722		.5601	.7842	.5658
6	.8299	.9054	.9979		.8131	.8962	.8962
7	.9709	.9709	1.0974		.9511	1.0456	1.0562
8	.9877	1.0562	1.1222	1.0562	1.0136	1.1317	.9145
9	1.1222	.6615	1.0029	1.0745	1.086	1.0745	1.0562
10	.9313	.8505	.9922	1.086	.788	1.0136	.9808
11	.9774	1.0402	1.0517	1.0631	.8413	.9313	.9808
12	.9568	.823	.9465	.7964	.7011	.9511	.9054
13	.8859	.8322	.7796	.6935	.7087	.7712	.9054
14		.7712	.7087	.6935	.7087	.815	.9054
15	.7442	.8916	.7164	.7545	.567	.8322	.9054
16	.7796	.8322	.7011	.7628	.4854	.7712	.9054
17	.8048	.8322	.8413	.8063	.5853	.7011	.7011
18	.8215	.8063	.8215	.7545	.5975	.823	.7087
19	1.0562	.9511	.9054	.961	.8962	.8413	.9709
20	.9808	.9709	.9054	.8962	.9054	.8215	.9335
21	.8215	.8962	.7545	.8215	.8299	.7545	.8299
22	.7545	.8299	.6722	.7545	.7468	.7545	.8299
23	.679	.6413	.5601	.6036	.7095	.5281	.6097
24	.5335	.415	.5658		.5601	.5658	.4527
Max	1.1222	1.0562	1.1222	1.086	1.086	1.1317	1.0562
Min	.5281	.4108	.5281	.6036	.4854	.4294	.3772
Avg	.7966	.7784	.7934	.8486	.7160	.7853	.7796

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 201 / 11 kv Yavaluj Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18
HR	Load (MW)
1	.016
2	.016
3	.016
4	.0162
5	.0162
6	.0162
7	.0162
8	1.3279
9	1.4083
10	1.3765
11	1.2963
13	1.4243
14	1.3117
15	1.1843
24	.016
Max	1.4243
Min	.016
Avg	.6305



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 202 / 11 KV YEVALUJ VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18
HR	Load (MW)
1	.0701
2	.0701
3	.0701
4	.0876
5	.1227
6	.156
7	.1907
8	.1734
9	.1734
10	.156
11	.1543
13	.1214
14	.1372
15	.1402
24	.104
Max	.1907
Min	.0701
Avg	.1285

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 203 / 11Kv Satarde sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18
HR	Load (MW)
1	.0164
2	.0164
3	.0164
4	.0164
5	.0164
6	.0164
7	.0164
8	1.9989
9	2.8673
10	2.7526
11	2.7044
12	2.6406
13	2.4615
14	2.4453
15	2.1605
24	.0164
Max	2.8673
Min	.0164
Avg	1.2601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 204 / Majgaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18
HR	Load (MW)
1	1.3717
2	1.3032
3	1.2346
4	1.166
5	1.0288
6	.9259
7	.9431
8	.0173
9	.0173
10	.0168
11	.017
12	.017
13	.0162
14	.0164
15	.017
24	1.5089
Max	1.5089
Min	.0162
Avg	.6011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 205 / Majgaon Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18
HR	Load (MW)
1	.1254
2	.1254
3	.1254
4	.1254
5	.1433
6	.1791
7	.2328
8	.2149
9	.2149
10	.208
11	.2254
12	.2103
13	.2303
14	.2279
15	.2279
24	.1254
Max	.2328
Min	.1254
Avg	.1839

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 206 / 11 KV Satarde Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18
HR	Load (MW)
1	.1417
2	.124
3	.124
4	.1417
5	.2126
6	.2835
7	.3544
8	.3189
9	.3189
10	.3988
11	.298
12	.2804
13	.2629
14	.2629
15	.2629
24	.1595
Max	.3988
Min	.124
Avg	.2466

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 201 / 11 KV KAKHE AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1126	.1372	.1372	.1067	.1219	1.4327	1.3413
2	1.0974	.1372	.1372	.1067	.0914	1.3565	1.2955
3	1.0974	.1372	.1372	.1067	.0914	1.3413	1.2955
4	1.0974	.1372	.1372	.1067	.1219	1.3413	1.2955
5	1.2498	.1372	.1715	.1067		1.3717	1.2955
6	1.3413	.1715	.1715	.1067	.1524	1.5546	1.4022
7	1.4327	.2058	.1715	.1524	.1829	1.6766	1.5242
8	1.829	2.1338		2.3777	.1829	.1715	.1829
9	2.1338	2.5149		2.6063	.1524	.1219	.1715
10	2.2558	2.6368	2.4844	3.0178	.1524	.1219	.1543
11	2.1643	2.4082	2.652	2.6673	.0122	.1219	.1543
12	2.1643	2.5911	2.7587	2.652		.1219	.1543
13	2.2558	2.5149	2.5758	2.6216	.1219	.1219	.1372
14	2.2558	2.4387	2.5606	2.4691	.1219	.1372	.1372
15	2.2558	2.0119	2.5758	2.2558	.1219	.2134	.1715
16	.12	.0122	2.3777	.1372	.1524	.1219	.1886
17	.1372	.0122	.1219	.1524	.1715	.1219	.1886
18	.1715	.2058	.1829	.1829	.1715	.1981	.2058
19	.2058	.1886	.1524	.1829	.2572	.2286	.2058
20	.2058	.1715	.1524	.1829	.2058	.2286	.1886
21	.2058	.1715	.1372	.1829	.2058	.2286	.1715
22	.1886	.1715	.1372	.1524	1.7528	1.6156	1.4937
23	.1543	.1543	.1372	.1524	1.6766	1.5394	1.4632
24	1.1431	.1372	.1372	.1067	.1219	1.5699	1.3717
Max	2.2558	2.6368	2.7587	3.0178	1.7528	1.6766	1.5242
Min	.12	.0122	.1219	.1067	.0122	.1219	.1372
Avg	1.1781	.8974	.9185	.9539	.2883	.7108	.6746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.583	.5487	.5487	.5144	.5487	.5144
2	.5144	.5487	.5144	.5144	.4801	.5316	.5144
3	.4801	.5487	.5144	.5144	.4801	.5144	.5144
4	.4801	.5487	.6173	.5144	.5144	.5144	.5144
5	.5144	.583	.8059	.5144	.6859	.5487	.5144
6	.7545	.7716	.7888	.703	.823	.6859	.7888
7	.9259	.9602	.9259	.8745	.8916	.9259	.9602
8	.9602	.9945	.8916	.9259	.9259	.9602	.9774
9	.9259	.9431	.8573	.9431	.8573	.8916	.9259
10	.9088	.8916	.7888	.9088	.7888	.7545	.8745
11	.7545	.7545	.7888		.7202	.7202	.7716
12	.7545	1.0974	.7373	.8573	.6859	.703	.7888
13	.7545	.7545	.7373	.7716	.6516	.7202	.7202
14	.703	.6859	.703	.7373	.6344	.6344	.7202
15	.6859	.6859	.6344	.703	.6173	.6344	.7202
16	.6859	.823	.6516	.703	.6344	.7373	.8059
17	.823	.8402	.7373		.6173	.7888	.8745
18	.9088	1.0288	.8916	.8916	.703	.9431	.9945
19	1.2517	1.2003	1.2517	1.2346	1.046	1.166	1.2346
20	1.286	1.2174	1.1317	1.2003	1.1317	1.2003	1.1831
21	1.1488	1.0974	1.0631	1.0974	1.0631	1.1145	1.0631
22	1.0288	.9431	.9259	.9945	.9259	.9602	.9088
23	.8059	.7888	.7373	.6859	.7202	.6859	.6859
24	.6516	.6516	.583	.6001	.5144	.5658	.5316
Max	1.286	1.2174	1.2517	1.2346	1.1317	1.2003	1.2346
Min	.4801	.5487	.5144	.5144	.4801	.5144	.5144
Avg	.8023	.8309	.7845	.7926	.7345	.7688	.7959

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037]

BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 203 / 11 KV FACTORY VILLAGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7888	.6516	.8573	.7545	.823	.823
2	.6859	.8402	.6173	.7716	.6859	.8059	.8059
3	.583	.823	.6173	.7716	.6516	.7888	.7888
4	.583	.8402	.6516	.7716	.6859	.7888	.7888
5	.7202	.8916	.7202	.7716	.823	.8059	.7888
6	1.0288	1.2003	1.0117	.8573	.9259	1.0631	1.0631
7	1.3717	1.406	1.4232	1.2174	1.2003	1.4232	1.4403
8	1.2003	1.3546	1.3375	1.406	1.2689	1.4403	1.4403
9	1.3375	1.3375	1.2689	1.3889	1.2346	1.3203	1.3203
10	1.286	.823	1.3203	1.3375	1.1488	1.3717	1.2174
11	1.0802	1.2174	1.1488	1.286	1.0288	1.1488	1.0974
12	.9945	1.0974	.9431	.9602	.7202	1.0631	1.0288
13	1.0288	.9774	.703	.9602	.7888	.9602	.9774
14	.9602	.9774	.9945	.9774	.8573	.8916	1.0631
15	.9602	1.0802	1.0288	.9945	.823	.9259	1.0288
16	1.0288	1.046	.9602	1.0802	.8573	.9774	1.0974
17	1.0631	1.1317	1.1145	1.0974	.8916	1.0974	1.1317
18	1.1317	1.2003	1.1317	1.0059		1.1317	1.1488
19	1.5089	1.2689	1.4403	1.406	1.1145	1.166	1.406
20	1.3203	1.2003	1.406	1.2003	1.2517	1.2003	1.2517
21	1.2003	1.2174	1.3717	1.0974	1.0974	1.0974	1.0631
22	1.166	1.2003	1.2003	.945	1.0631	1.0288	1.1317
23	1.0288	1.0288	.9945	.9259	1.0288	1.0117	.8745
24	.8573	.7202	.6859	.9259	.7011	.8573	.8573
Max	1.5089	1.406	1.4403	1.406	1.2689	1.4403	1.4403
Min	.583	.7202	.6173	.7716	.6516	.7888	.7888
Avg	1.0367	1.0695	1.0310	1.0422	.9393	1.0495	1.0681



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 204 / 11 KV POKHALE Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.884	.3086	.2915	.2743	.2439	1.2955	1.0974
2	.7621	.3086	.2743	.2591	.2286	1.0974	1.0364
3	.6706	.3086	.2743	.2591	.2286	1.0974	1.0364
4	.6706	.3086	.2915	.2591	.2743	1.0669	1.0364
5	.9755	.3429	.3086	.2591	.3048	1.0974	1.0364
6	1.1279	.3944	.3601	.3658	.381	1.3108	1.2803
7	1.2803	.4801		.3963	.3963	1.5851	1.4632
8	1.768	1.9509	1.7071	2.0729	.4268	.4801	.3048
9	2.0424	2.2253	2.1033	2.4387	.4268		
10	2.0424	2.2862	2.1491	2.4844	.381	.2439	.3086
11	2.2253	2.1948	2.1643	2.3777	.4268	.2439	.2572
12	2.1795	2.1033	2.1338	2.2862	.381	.2286	.2572
13	2.1033	2.0119	2.0119	1.5242	.3201	.381	.2915
14	2.0119	1.8595	2.0119	2.1491	.3201	.381	.2572
15	1.8595	1.5546	1.89	1.9052	.3201	.381	.2743
16	.4287	.3963	.3963	.4287	.4115	.2134	.6001
17	.4458	.3963	.4115	.3658	.4801	.2286	.5487
18	.463	.3258	.4115	.3963	.4801		.6516
19	.463	.3086	.4268	.3963	.4801	.1524	.583
20	.463	.4287	.3963	.3963	.4458	.2134	.5487
21	.4287	.4287	.3963	.4268	.4458	.3963	.5658
22	.4115	.3944	.3658	.3658	1.7528	1.6613	1.326
23	.3429	.3601	.3048	.3048	1.6918	1.6156	1.2193
24	.9145	.3086	.3086	.2896	.2591	1.448	1.2955
Max	2.2253	2.2862	2.1643	2.4844	1.7528	1.6613	1.4632
Min	.3429	.3086	.2743	.2591	.2286	.1524	.2572
Avg	1.1235	.9161	.9300	.9451	.4795	.7645	.7511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 205 / 11 KV AMRUT AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	.1543	.1372	.1219	.1219	1.3717	1.3108
2	1.3375	.1543	.1372	.1219	.1219	1.3413	1.2803
3	1.1584	.1543	.1372	.1219	.1219	1.2803	1.2803
4		.1543	.1372	.1219	.1219	1.2803	1.2803
5	1.1279	.1543	.1543	.1219	.1372	1.2955	1.2803
6	1.1584	.1715	.1886	.1219	.1524	1.2955	1.3717
7	1.1888	.2058	.2058	.1677	.1677	1.4175	.1829
8	1.3108	2.271	2.0729	2.0881	.1829	.1524	
9	1.6461	2.4539	2.2253	2.1643	.1677	.1677	.2401
10	1.829	1.7528	2.3624	2.2862	.1372	.1829	.2401
11	2.21	2.4387	2.3472	1.9966	.1372	.1677	.2401
12	2.2405	2.3167	2.3624	2.3015	.1372	.1677	.2058
13	2.3472	2.2862	2.3777	2.271	.1372	.1677	.1886
14	2.3167	2.1643	2.332	2.2253	.1219	.1829	
15	2.2862	1.9357	2.2558	2.1948	.1219	.1829	
16	.1886	.1677	.1677	.1715	.1219	.1829	
17	.1886	.1524	.1677	.1677	.1372	.1829	.2229
18	.1886	.2058	.1677	.1677	.1715	.1829	.1715
19	.2058	.2229	.1677	.1981	.1886	.1829	.2058
20	.1886	.1886	.1677		.1886	.1677	.2058
21	.2058	.2058	.1677	.1677	.1715	.1524	.1715
22	.1886	.2058	.1524	.1524	1.5851	1.4784	1.0364
23	.1886	.1715	.1219	.1524	1.5699	1.4632	1.0364
24	1.2803	.1543	.1543	.1219	.1372	1.4175	1.3717
Max	2.3472	2.4539	2.3777	2.3015	1.5851	1.4784	1.3717
Min	.1886	.1524	.1219	.1219	.1219	.1524	.1715
Avg	1.1473	.8518	.8695	.8577	.2650	.6694	.6762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3601	.4458	.3086	.4801	.4572	.4973	.3601
2	.3429	.3601	.3086	.463	.4115	.4801	.3601
3	.3429	.3429	.3086	.4458	.4287	.4458	.3601
4	.3772	.3429	.3772	.4458	.3772	.463	.3601
5	.4115	.3601	.4801	.4458	.4115	.4458	.3601
6	.4287	.4115	.4801	.4287	.4458	.4458	.4115
7	.4287	.463	.4973	.4287	.463	.4287	.4973
8	.3258	.5487	.2915	.3429	.4458	.3601	.3258
9	.2915	.4973	.2743	.3772	.3258	.3944	.2915
10	.3601	.5144	.3258	.3772	.3772	.463	.3429
11	.3944	.6344	.4287	.463	.4287	.5487	.3429
12	.3772	.6344	.4458	.6001	.3772	.6001	.3429
13	.2229	.4801	.5658	.583	.3944	.6001	.3429
14	.5144	.4458	.583	.6173	.4572	.5144	.3258
15	.4973	.3601	.583	.583	.583	.3772	.4458
16	.5487	.3944	.583	.5658	.5658	.3506	
17	.583	.5144	.4973	.503	.5487	.4973	.5316
18	.5144	.5487	.5487	.1829	.5487	.4115	.4801
19	.6173	.6173	.583	.4572	.5144	.6516	.5487
20	.463	.6173	.5316	.5487	.463	.6344	.5144
21	.463	.4801	.5316	.463	.4458	.6001	.4801
22	.4458	.4458	.5658	.5658	.5487	.583	.4458
23	.4973	.3772	.5487	.5487	.5144	.3601	.4115
24	.3601	.5144	.3429	.5144	.5316	.4973	.3772
Max	.6173	.6344	.583	.6173	.583	.6516	.5487
Min	.2229	.3429	.2743	.1829	.3258	.3506	.2915
Avg	.4237	.4730	.4580	.4763	.4611	.4854	.4026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 207 / 11 KV Jakhoba LIS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.12	.1372	.1372		.12	
4	.12	.1372	.1372		.12	
5	.1372	.1372	.1372		.12	
6	.1372	.1372	.1372		.12	
7	.1372	.1372	.1372		.12	
8	.1372	.1372	.1372		.1372	
9	.1372	.1372	.0122	.1372	.1219	.0857
10	.1372	.12	.0122	.1372	.1219	.1372
11	.1372	.12	.1219	.1372	.1219	.1372
12	.1372	.1067	.0122	.1372	.1219	.1372
13	.1372	.0122	.1219	.1372	.1219	.1372
14	.1372	.1372	.1219	.1372	.1219	.1372
15	.1372	.1219	.1219	.1372	.1219	.1372
16	.12	.0122	.1219	.1372	.1219	.1372
17	.1372	.0122	.1372	.1219	.12	.1372
18	.1372	.12	.12	.1219	.12	.1372
Max	.1372	.1372	.1372	.1372	.1372	.1372
Min	.12	.0122	.0122	.1219	.12	.0857
Avg	.1340	.1077	.1079	.1341	.1220	.1321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037]

BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 401 / 33 KV Biltube Express

Feeder Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.572	2.4691	2.2634	2.1605	2.4691	2.2634	2.2634
2	2.4691	2.4177	2.3148	2.1605	2.3663	2.0576	2.1605
3	2.3663		2.2634	2.3663	2.3663	2.1605	2.2634
4	2.2634	2.4691	2.4177	2.4691	2.1605	2.3663	2.1605
5	2.3663	2.4177	2.4691	2.3663	2.3663	2.3148	2.3148
6	2.4691	2.6749	2.4177	2.572	2.4691	2.4177	2.3663
7	2.3663	2.2119	2.3663	2.5206	2.572	2.2634	2.4177
8	2.9321	2.6235	2.572	1.5947	2.8292	2.2634	2.4691
9	3.4979	2.4691	1.5432	2.4177	2.3148	2.0576	2.4691
10	3.0864	2.3148	2.6235	1.8519	3.1379	2.4177	2.572
11	2.4691	2.4691	2.572	2.4177	2.4177	2.4177	2.3663
12	2.5206	2.4177	2.4177	2.1605	2.572	2.6235	2.6235
13	3.035	.2572	1.9033	2.2634	2.6749	2.6235	2.5206
14	3.1379	2.4177	1.9547	2.2119	2.572	2.4177	2.8292
15	2.6235	1.4403	2.7263	2.3148	2.4691	2.7263	2.572
16	3.0864	2.3663	2.4177	1.9033	2.1605	2.8807	2.7692
17	2.4177	2.6235	2.8292	2.2634	2.2634	2.2634	2.9835
18	2.572	2.4691	2.2634	2.1605	2.4177	2.9835	2.7778
19	2.8807	2.572	2.3663	2.3663	2.1605	2.572	2.4691
20	2.5206	2.2634	1.9033	2.2119	1.9547	2.6235	2.5206
21	2.4177	2.3663	2.572	1.6975	2.1091	2.6749	2.7778
22	2.5206	2.4691	2.6749	2.3148	2.4691	2.5206	3.1893
23	2.6235	2.8807	2.6749	2.3663	2.0576	2.4691	2.7263
24	2.8292	2.4691	2.1605	2.0576	2.572	2.4691	2.3148
Max	3.4979	2.8807	2.8292	2.572	3.1379	2.9835	3.1893
Min	2.2634	.2572	1.5432	1.5947	1.9547	2.0576	2.1605
Avg	2.6685	2.3282	2.3620	2.2162	2.4134	2.4520	2.5374

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 201 / Single Phasing Stave- SINGLE PHASING  
 Sawarde Feeder KV- 11 /  
 OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0532	1.1812	.9503	.8619	.8951	.052	.0566
2	.0532	1.1812	.9339	.8619	.8951	.0514	.0566
3	.0532	1.1812	.9339	.8619	.852	.0514	.0566
4	.0532	1.1812	.9339	.7956	.852	.0514	.0566
5	.0526	1.2003	.9614	.7956	.8619	.0693	.0754
6	.0701	1.2384	.9945	.8048	.9831	.0867	.0943
7	.1052	1.2384	1.0814	.9282	1.2071	.1052	.0943
8	.0953	.0953	.0686	.0762	1.3717	1.5684	1.6598
9	.0762	.0754	.0762	.0762	1.7353	1.7741	1.9404
10	.0762	.0762	.0572	.0572	1.8107	1.8671	1.9044
11	.0762	.0762	.0572	.0566	1.9418	1.8671	1.922
12	.0572	.0572	.0572	.0572	1.7353	1.5089	1.8111
13	.0572	.0572	.0572	.0572	1.7353	1.6598	1.8111
14	.0572	.0572	.0572	.0572	1.7353	1.7177	1.7372
15	.0572	.0572	.0572	.0381	1.6598	1.6598	1.6804
16	.0566	.0566	.056	.0362	.037	.0754	.0537
17	.0537	.0377	.0549	.0358	.0724	.0537	.0701
18	.0724	.0905	.0549	.0549	.0554	.0732	.0716
19	.0943	.132	.132	.1307	.1132	.132	.132
20	.132	.1509	.1509	.1494	.132	.1509	.1509
21	.132	.132	.1509	.1494	.132	.132	.132
22	1.326	1.0277	1.0608	1.0288	.104	.104	.1132
23	1.3957	1.0159	.9945	.9614	.0693	.0754	.0754
24	.0532	1.2574	.9831	.9282	.9282	.052	.0566
Max	1.3957	1.2574	1.0814	1.0288	1.9418	1.8671	1.9404
Min	.0526	.0377	.0549	.0358	.037	.0514	.0537
Avg	.1796	.5356	.4548	.4109	.9131	.6225	.6588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 202 / Single Phasing Stave-  
Mohare Feeder KV- 11 /  
OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0985					1.7337	1.9805
2	1.0985					1.6461	1.9805
3	1.0985					1.6118	1.9805
4	1.0985					1.5775	1.9805
5	1.1568					1.595	1.9239
6	1.2269					1.595	1.8484
7	1.2971					1.6827	1.7918
8	2.1338	2.2481	1.989	2.2862			
9	2.4387	2.5274	2.5149	2.5911			
10	2.5911	2.5911	2.5911	2.8197			
11	2.5149	2.7435	2.6673	2.7915			
12	2.3624	2.6673	2.6673	2.6673			
13	2.3624	2.5911	2.5149	2.6673			
14	2.3624	2.5911	2.4387	2.6673			
15	2.3624	2.4387	2.2862	2.4387			
22					1.8724	1.9071	1.9239
23					1.8724	2.037	1.9239
24	1.1694					1.8031	1.9805
Max	2.5911	2.7435	2.6673	2.8197	1.8724	2.037	1.9805
Min	1.0985	2.2481	1.989	2.2862	1.8724	1.5775	1.7918
Avg	1.7733	2.5498	2.4587	2.6161	1.8724	1.7189	1.9314

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 203 / Single Phasing Stave- SINGLE PHASING  
 Satave Feeder KV- 11 /  
 OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0709	.9145	.7209	.7293	.6962	.0693	.0754
2	.0709	.9145	.7045	.7293	.6962	.0686	.0754
3	.0709	.9145	.7045	.7293	.6554	.0686	.0754
4	.0709	.9145	.7045	.7293	.6554	.0686	.0754
5	.0701	.8954	.7293	.7293	.663	.0693	.0943
6	.0876	.8573	.7459	.8048	.7865	.0867	.1132
7	.1052	.9526	.7537	.7956	.9389	.1227	.1132
8	.1143	.1143	.0857	.0953	1.0974	1.3817	1.2826
9	.0762	.0943	.0762	.0953	1.358	1.5154	1.4045
10	.0762	.0953	.0762	.0572	1.4335	1.531	1.2696
11	.0762	.0762	.0762	.0754	1.419	1.4937	1.4784
12	.0762	.0572	.0762	.0762	1.3443	1.0562	1.3676
13	.0572	.0572	.0762	.0762	1.2071	1.2826	1.423
14	.0572	.0572	.0762	.0762	1.358	1.3443	1.423
15	.0572	.0572	.0572	.0762	1.4335	1.358	1.3817
16	.0566	.0566	.056	.0724	.0739	.0754	
17	.0537	.0566	.0549	.0537	.0905	.0716	
18	.0724	.0905	.0549	.0366	.0924	.0732	.1075
19	.132	.132	.132	.1307	.1509	.1509	.1509
20	.1509	.1509	.1509	.1494	.1509	.1509	.1509
21	.1509	.132	.1509	.1494	.132	.1509	.1509
22	1.0277	.8122	.7956	.823	.1214	.104	.132
23	1.0562	.7865	.7956	.7625	.0867	.0754	.0943
24	.0709	.9907	.7537	.7956	.7293	.0693	.0754
Max	1.0562	.9907	.7956	.823	1.4335	1.531	1.4784
Min	.0537	.0566	.0549	.0366	.0739	.0686	.0754
Avg	.1629	.4242	.3587	.3687	.7238	.5183	.5688



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 204 / Bhairavnath LIS Satave  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0532	.0953	.0492	.0663	.0514	.0943
4	.0886	.0953	.0492	.0829	.0857	.0943
5	.0876	.0953	.0497	.0829	.0867	.0943
6	.0876	.0953	.0497	.0829	.0867	.0943
7	.0876	.0953	.0492	.0829	.0876	.0943
8	.0953	.0953	.0857	.0953	.0934	.0943
9	.0953	.0943	.0953	.0953	.0924	.0924
10	.0953	.0953	.0953	.0953	.0934	.0934
11	.0953	.0953	.0953	.0943	.0934	.0924
12	.0953	.0953	.0953	.0953	.0943	.0924
13		.0572	.0953	.0953	.0943	.0924
14	.0381	.0953	.0953	.0953	.0934	.0924
15	.0953	.0953	.0953	.0953	.0943	.0934
16	.0943	.0943	.0934	.0905	.0943	.0895
17	.0895	.0943	.0914	.0895	.0895	.0876
18	.0905	.0905	.0914	.0732	.0914	.0895
Max	.0953	.0953	.0953	.0953	.0943	.0943
Min	.0381	.0572	.0492	.0663	.0514	.0876
Avg	.0859	.0924	.0798	.0883	.0889	.0926

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 201 / Shahuwadi-Maan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0732	.0549	.0351	.0549	.0526	.0549
2	.0351	.0724	.0549	.0351	.0549	.0526	.0549
3	.0351	.0549	.0549	.0351	.0549	.0526	.0549
4	.0526	.056	.0549	.0526	.0549	.0709	.0549
5	.0895	.0747	.0914	.0716	.0732	.0895	.0732
6	.1086	.0747		.1075	.1097	.1254	.128
7	.1478	.1463	.128	.1629	.1829	.1646	.1829
8	.1433	.1663	.1463	.1772	.2195	.181	.2195
9	.1578	.1791	.1463	.2103	.2195	.1612	.2012
10	.1886	.1791	.1267	.2058	.2012	.1372	.1463
11	.1715	.1753	.1006	.1715	.1526	.1341	.1753
12	.1696	.0876	.1029	.1715	.1341	.1052	.1715
13	.1492	.1075	.1094	.1017	.1357	.112	.1802
14	.1509	.12	.0995	.1067	.1341	.1372	.1658
15	.1158	.116	.1341	.1006	.144	.1341	.1475
16	.1341	.1311	.125		.1526	.1357	.1823
17	.1357	.1214	.1311	.1357	.128	.1457	.1475
18	.1526	.1772	.1734	.1526	.1715	.2058	.2058
19	.1753	.2481	.2149	.2401	.2172	.2279	.2454
20	.2254	.2534	.2378	.2303	.2561	.2103	.2454
21	.2149	.2195	.2241	.2149	.2402	.1928	.2279
22	.1715	.1829	.1494	.1829	.1646	.181	.181
23	.1029	.1097	.0886	.1097	.1052	.1097	.1463
24	.0701	.0924	.0732		.0732	.0526	.0732
Max	.2254	.2534	.2378	.2401	.2561	.2279	.2454
Min	.0351	.0549	.0549	.0351	.0549	.0526	.0549
Avg	.1313	.1341	.1227	.1369	.1431	.1322	.1527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 202 / Shahuwadi- Amba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.1109	.0943	.0754	.0754	.0754	.0747
2	.0754	.0905	.0943	.0754	.0754	.0754	.0747
3	.0754	.0914	.0943	.0754	.0754	.0754	.0747
4	.0943	.0914	.0943	.0943	.0754	.0943	.0747
5	.132	.1086	.1132	.1132	.1132	.132	.112
6	.1886	.1463	.1509	.132	.1509	.1886	.1494
7	.2075	.2218	.2054	.1509	.1867	.2263	.2054
8	.2772	.2614	.2614	.1886	.2241	.2587	.2801
9	.3109	.2772	.2987	.2614	.2614	.3292	.3174
10	.3403	.2926	.2987	.2772	.2801	.3292	.2987
11	.3544	.2896	.2534	.3258	.2865	.3045	.3224
12	.3366	.3258	.2353	.2926	.2804	.2658	.2896
13	.3012	.3258	.2195	.2454	.2804	.2865	.2658
14	.3045	.3109	.2012	.2507	.2507	.2804	.2865
15	.298	.298	.2218	.1753	.2534	.2804	.3155
16	.3224	.2658	.2328		.2804	.2427	.3189
17	.2804	.2686	.2353	.2561	.2865	.3121	.333
18	.2686	.2926	.2378	.3155	.2896	.2103	.2507
19	.2534	.2926	.2402	.2865	.3142	.2507	.2896
20	.2561	.2743	.2614	.2926	.2987	.2507	.2926
21	.2507	.2561	.2263	.2614	.2427	.2378	.2561
22	.1829	.2241	.2075	.2241	.2054	.1848	.2195
23	.1448		.1132	.1494	.168	.1307	.1307
24	.1132	.1097	.132	.0754	.0943	.1132	.0934
Max	.3544	.3258	.2987	.3258	.3142	.3292	.333
Min	.0754	.0905	.0943	.0754	.0754	.0754	.0747
Avg	.2268	.2272	.1968	.1998	.2104	.2140	.2219

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 203 / Shahuwadi-sawe  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.1494	.1886	.1886	.0171	.0754	.0943
2	.1509	.1509	.1886	.1509	.0171	.0754	.0943
3	.1509	.1509	.1509	.1509	.0171	.0754	.0943
4	.1886	.1509	.1509	.1509	.0171	.0943	.0943
5	.2263	.1867	.1886	.1886	.0171	.0943	.1132
6	.3018	.2587	.2829	.2641	.0171	.1132	.132
7	.3584	.3292	.3772	.3395	.0171	.1509	.1509
8	.3547	.362	.415	.3395	.0173	.1848	.1509
9	.3511	.4207	.4338	.3734	.0173	.1829	.1132
10	.3982	.4119	.4527	.4108		.1791	.1132
11	.3511	.4251	.4066	.3921		.1753	.1578
12	.3206	.2987	.3361	.3696		.1595	
13	.2402	.2987	.3361	.2241	.1478	.1433	.1387
14	.2195	.2587	.2614	.2402	.181	.1612	.1402
15	.181	.2012	.2587		.1417	.1402	.1543
16	.2534	.2896	.2195		.1543	.1372	.1734
17	.3292	.2957	.2561		.1696	.1509	.1907
18	.362	.4854			.2103	.2058	.2149
19	.439	.5601	.5041		.2715	.2572	.2715
20	.499	.5788	.5228		.2772	.2629	.2743
21	.4477	.5093	.5093		.2614	.2279	.2427
22	.3734	.3772	.4338	.0171	.2241	.1867	.1886
23	.2587	.3018	.2829	.0171	.132	.1307	.1132
24	.1886	.1848	.2075	.2263	.0171	.0943	.0943
Max	.499	.5788	.5228	.4108	.2772	.2629	.2743
Min	.1509	.1494	.1509	.0171	.0171	.0754	.0943
Avg	.2956	.3182	.3202	.2379	.1115	.1525	.1524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 204 / Shahuwadi-Kotoli Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.125	.2683	.1543		
2			.125	.2683	.1543		
3			.125	.2347	.1543		
4			.125	.2401	.1543		
5			.16	.2401	.1543		
6			.208	.2401	.2241		
7			.192	.2401	.3277		
8	.4115				.3768	.4024	.3932
9	.4287				.4096	.5487	.5533
10	.5658				.4424	.5487	.57
11	.583				.5087	.4862	.5596
12	.583				.503	.503	.5365
13	.5256				.4641	.4694	.503
14	.4694				.503	.4359	.5365
15	.426				.4694	.4191	.5365
22		.1562	.285	.1852			
23		.125	.285	.1543			
24			.125	.2683	.1543		
Max	.583	.1562	.285	.2683	.5087	.5487	.57
Min	.4115	.125	.125	.1543	.1543	.4024	.3932
Avg	.4991	.1406	.1755	.2340	.3222	.4767	.5236

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 205 / Shahuwadi - Malkapur  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.181	.1886	.1886	.1886	.1886	.1886
2	.1886	.1867	.1886	.1886	.1886	.1886	.1886
3	.1886	.1867	.1886	.1886	.1886	.1886	.1886
4	.2263	.1663	.1886	.2263	.1886	.2263	.1886
5	.3018	.2263	.2452	.2641	.2263	.2641	.2452
6	.3395	.3206	.3018	.3018	.3018	.3395	.3395
7	.415	.3734	.3772	.3395	.3734	.415	.415
8	.4294	.4066	.3921	.4294	.4108	.4108	.4294
9	.3681	.439	.4108	.4435	.4294	.4481	.4294
10	.4435	.4435	.4108	.4481	.4481	.4481	.4108
11	.4207	.439	.4066	.462		.5121	.4435
12	.4066	.4207	.3734	.4108	.3696	.4656	
13	.4163	.394	.3881		.4108	.4755	.3258
14	.4298	.3856	.4207	.4024	.4066	.4298	.3696
15	.4252	.4075	.4024	.3258	.3881	.4207	.4207
16	.4298	.4656	.362		.4108	.4207	.4572
17	.4755	.4572	.439		.4251	.4024	.462
18	.4656	.5487	.5175	.5194	.5228	.5487	.5601
19	.5373	.6099	.5914	.6036	.6161	.6099	.6161
20	.5853	.5975	.6348	.5853	.6348	.5975	.5975
21	.567	.5601	.5601	.5487	.5658	.5415	.5601
22	.4435	.4481	.4715	.4854	.415	.4904	.4527
23	.3696	.3395	.3395	.3734	.2829	.3772	.3018
24	.2263	.2195	.2263	.2263	.2452	.2263	.2263
Max	.5853	.6099	.6348	.6036	.6348	.6099	.6161
Min	.1886	.1663	.1886	.1886	.1886	.1886	.1886
Avg	.3870	.3843	.3761	.3791	.3756	.4015	.3834

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 206 / Shahuwadi-Parale Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.583	.5365	.0091	.0206	.0095	.7545	.6859
2	.583	.5365	.0091	.0206	.0095	.6859	.6859
3	.5487	.4915	.0091	.0191	.0095	.6516	.6859
4	.5487	.4973	.0091		.0095	.6516	.6859
5	.5144	.5898	.0091	.0191	.0099	.583	.631
6	.5144	.2347	.0091	.0183	.0099	.583	.6201
7	.4973	.2652	.0091	.0175	.0198	.5487	.5847
8	.0116	1.0395	.9816	1.0288	.0194	.0114	.0118
9	.144	1.1401	1.0985	1.0288	.0198	.0171	.0118
10	.0118	1.1191	1.1163	.9602	.0198	.0137	.0118
11	.0328	1.0004	1.1317	1.1789	.0221	.013	.0114
12	.0084	1.0229	1.1488	1.1568	.0133	.0152	.013
13	.0076	.9945	.9665	.6516	.013	.0149	.0143
14	.0111	.8951	1.0288	.9389	.0074	.0141	.0147
15	.0111	.788	.9326	.78	.008	.0137	.0145
16	.0112	.0116	.0202		.0072	.0137	.0133
17	.013	.0126	.021		.0156	.0162	.0328
18	.0162	.0152	.0236	.0236	.0149	.0152	.0267
19	.0156	.0152	.0259	.0229	.0141	.0143	.0251
20	.0156	.0152	.0236	.0229	.0118	.0133	.0251
21	.0152	.016	.0213	.0221	.0095	.0133	.0251
22	.5365	.0171	.021	.0105	.7545	.7888	.6859
23	.583	.0086	.021	.0095	.8573	.7545	.823
24	.6173	.583	.0091	.0221	.0095	.7888	.6859
Max	.6173	1.1401	1.1488	1.1789	.8573	.7888	.823
Min	.0076	.0086	.0091	.0095	.0072	.0114	.0114
Avg	.2438	.4936	.3606	.3797	.0790	.2912	.2927

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.1006	.2949	.2012		
2			.1006	.2949	.2012		
3			.1006	.2622	.2012		
4			.1006	.2622	.2012		
5			.1341	.2294	.2012		
6			.2572	.2294	.3086		
7			.2915	.2294	.4458		
8	.3077				.5197	.5365	.1677
9	.5138				.5487	.5868	.2347
10	.6401				.5658	.6036	.2515
11	.5636					.5967	.6371
12	.5304				.4973	.426	
13	.5571				.4024	.4359	.6464
14	.57				.3978	.3605	.6371
15	.4801				.4588	.2949	.6133
22		.1341	.2591	.2347			
23		.1006	.3239	.2012			
24			.1006	.3277	.2012		
Max	.6401	.1341	.3239	.3277	.5658	.6036	.6464
Min	.3077	.1006	.1006	.2012	.2012	.2949	.1677
Avg	.5204	.1174	.1769	.2566	.3568	.4801	.4554



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 208 / Shahuwadi-Perid Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561					.3353	.3018
2	.2561					.3353	.2915
3	.2561					.3353	.2915
4	.2561					.3353	.2915
5	.2591					.3018	.2915
6	.2591					.3018	.3353
7	.2949					.2622	.3353
8	.4588	.6962	.7042	.6706			
9	.6962	.7956	.7712	.8718			
10	.7537	.8718	.8048	.8817			
11	.788	.9088	.8573	.7461			
12	.7459	.8309	.8402	.7377			
13	.8356	.8048	.8648	.3315			
14	.8048	.7209	.8139	.8048			
15	.7373	.6478	.664	.4858			
22					.4024	.3688	.3688
23					.4024	.3353	.4024
24	.2561					.3688	.3353
Max	.8356	.9088	.8648	.8817	.4024	.3688	.4024
Min	.2561	.6478	.664	.3315	.4024	.2622	.2915
Avg	.4946	.7846	.7901	.6913	.4024	.3280	.3245

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 209 / Shahuwadi-Ameni vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191		.0189	.0191	.0189	.0191
2	.0189	.0191	.0191	.0189	.0191	.0189	.0191
3	.0189	.0191	.0191	.0189	.0191	.0189	.0191
4	.0189	.0191	.0191	.0189	.0191	.0189	.0191
5	.0189	.0191	.0191	.0189	.0191	.0189	.0191
6	.0189	.0191	.0381	.0189	.0191	.0189	.0377
7	.0381	.0191	.0377	.0377	.0377	.0377	.0377
8	.0381	.0191	.0377	.0381	.0377	.0381	.0377
9	.0381	.0191	.0377	.0381	.0373	.0381	.0377
10	.0381	.0381	.0377	.0381	.0187	.0381	.0377
11	.0381	.0381	.0381	.0381	.0377	.0381	.0381
12	.0381	.0381	.0381	.0381	.0381	.0381	.0381
13	.0381	.0381	.0381	.0381	.0381	.0381	.0381
14	.0381	.0381	.0381	.0381	.0381	.0381	.0381
15	.0381	.0381	.0381	.0381	.0381	.0381	.0381
16	.0381	.0381	.0381		.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0377	.0381	.0381	.0381	.0377	.0377
19	.0191	.0377	.0381	.0377	.0381	.0377	.0377
20	.0191	.0377	.0381	.0377	.0381	.0377	.0377
21	.0191	.0377	.0381	.0377	.0189	.0377	.0377
22	.0191	.0191	.0189	.0189	.0189	.0191	.0191
23	.0191	.0191	.0189	.0189	.0189	.0191	.0191
24	.0189	.0191	.0191	.0189	.0191	.0189	.0191
Max	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Min	.0189	.0191	.0189	.0189	.0187	.0189	.0191
Avg	.0285	.0285	.0322	.0305	.0293	.0308	.0316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 201 / SARUD-BAMBAWADE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4668	.4481	.5228	.5601	.5601	.7468
2	.3734	.4668	.4481	.5228	.5601	.5601	.6908
3	.3734	.4481	.4668	.4854	.5601	.5601	.6722
4	.3734	.4854	.4668	.5228	.5601	.5601	.6348
5	.5601	.6722	.5601	.5975	.7468	.7468	.7095
6	.7468	.7468	.8029	.7468	.8215	.8402	1.0456
7	.9896	1.0269	1.0642	1.0269	1.1203	.9335	1.251
8	1.1389	1.0269	1.0269	1.2136	1.2696	.9335	1.2136
9	1.1203	1.0642	1.0269	1.1389	1.3443	1.0642	1.363
10	1.0642	1.2136	1.0829	1.251	1.1949	1.419	1.363
11	1.0642	1.0642	1.1763	1.2136	1.1203	1.3443	1.4003
12	1.0269	.9149	.9709	1.2136	1.0456	1.0829	1.3256
13	.9149	.9149	.9522	.9896	.9709	1.0456	1.1763
14	.8402	.9149	.9522	1.0456	.7468	.9709	1.0269
15	.8402	.9896	1.0269	1.0456	.7468	.9709	.9896
16	.9335	1.0642	1.0269	1.1016	.8962	.9335	1.307
17	.9335	1.0642	1.1203	1.1016	1.0456	1.2696	1.3256
18	1.1203	1.0642	1.1203	1.1389	1.2323	1.1949	1.2323
19	1.1203	1.2136	1.2696	1.363	1.3817	1.4937	1.3443
20	1.5497	1.4003	1.3443	1.5684	1.4937	1.643	1.7177
21	1.4003	1.1576	1.1203	1.4937	1.4563	1.4937	1.4563
22	1.1763	.9335	1.1203	1.1949	1.0456	1.419	1.1949
23	.7655	.7468	.8215	.9335	.7468		.6722
24	.4668	.5228	.5228	.5601	.6535	.5975	.7842
Max	1.5497	1.4003	1.3443	1.5684	1.4937	1.643	1.7177
Min	.3734	.4481	.4481	.4854	.5601	.5601	.6348
Avg	.8861	.8993	.9141	.9997	.9717	1.0277	1.1101

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 202 / Sarud-Bhedasgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2427	.2241	.2241	.2241	.2263	.2241
2	.2241	.2054	.2241	.2241	.1867	.1867	.1867
3	.1867	.2054	.2241	.2241	.1867	.1867	.1867
4	.1867	.2054	.2801	.2614	.1867	.1867	.2241
5	.2614	.2614	.3361	.2987	.3361	.2801	.2987
6	.3734	.4668	.4108	.4108	.3734	.3734	.4481
7	.4854	.5601	.4854	.5041	.4481	.5228	.5228
8	.5228	.4854	.5415	.5228	.4668	.5228	.5601
9	.5228	.5415	.5415	.5228	.4668	.5228	.5601
10	.5228	.5228	.5041	.5041	.4481	.5041	.5415
11	.4668	.4854	.4854	.4854	.3361	.4854	.4481
12	.4108	.4108	.4481	.4854	.3361	.4108	.4481
13	.4108	.4481	.4854	.4854	.4108	.3734	.4481
14	.4108	.3734	.4854	.4854	.4108	.4108	.4481
15	.3921	.3361	.4294		.2987	.3734	.4481
16	.3921	.3734	.4294	.5041	.3734	.3734	.4668
17	.3921	.4108	.4668	.4854	.3361		.4668
18	.4481	.4481	.4481	.5228	.3921	.5228	.4854
19	.6161	.5228	.5228	.6161	.4668	.5975	.5975
20	.6348	.5601	.6348	.6161	.5228	.5975	
21	.5788	.5601	.5975	.5415	.5228	.5975	.5788
22	.4854	.3734	.4854	.4481	.3734	.4481	.4481
23	.3361	.2987	.2614	.3361	.2801		.2987
24	.2241	.2427	.2427	.2427	.2241	.2241	.2614
Max	.6348	.5601	.6348	.6161	.5228	.5975	.5975
Min	.1867	.2054	.2241	.2241	.1867	.1867	.1867
Avg	.4045	.3975	.4248	.4327	.3587	.4058	.4173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 203 / Sarud-Sarud Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.1307	.112	.112	.112	.112	.1494
2	.0747	.112	.112	.112	.112	.112	.1307
3	.0747	.112	.112	.112	.112	.112	.1494
4	.0747	.112	.1307	.1307	.1494	.112	.1867
5	.1029	.1494	.1307	.1494	.168	.1867	.1867
6	.1867	.2427	.1494	.2241	.1867	.2241	.1867
7	.2614	.2801	.2054	.2614	.2241	.2801	.2987
8	.2801	.2427	.2241	.2987	.2614	.2801	.2614
9	.2241	.2427	.2427	.2614	.2614	.1867	.2614
10	.2427	.2987	.2241	.2614	.2614	.2054	.2614
11	.2427	.2241	.2241	.2614	.2987	.2241	.2054
12	.1867	.2241	.2054	.2427	.2614	.2241	.2241
13	.1867	.2241	.2054	.2427	.1867	.1867	.2241
14	.168	.2241	.2054	.1867	.1867	.2054	.2241
15	.168	.2241	.2427		.1867	.1494	.2427
16	.2241	.2614	.2427	.2614	.1867	.1494	.2427
17	.2427	.2614	.2614	.2987	.2241		.2614
18	.2427	.2987	.2987	.3361	.2241	.2987	.2987
19	.3547	.3734	.3734	.3734	.2614	.3734	.2987
20	.4108	.3361	.3734	.3734	.2987	.3734	.3361
21	.3361	.2987	.3734	.2987		.3361	.2987
22	.3174	.1867	.2987	.2987		.2614	.2614
23	.1886	.1494	.1867	.1867			.1867
24	.1307	.1307	.1307	.1307	.112	.1494	.1494
Max	.4108	.3734	.3734	.3734	.2987	.3734	.3361
Min	.0747	.112	.112	.112	.112	.112	.1307
Avg	.2090	.2225	.2194	.2354	.2036	.2156	.2303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 204 / Sarud-Gogawe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	1.0082	.7468	.7468	.0191	.0187	.0187
2		.9335	.7095	.7095	.0191	.0187	.0187
3	.0191	.9335	.7095	.6722	.0191	.0187	.0187
4	.0191	.9335	.7468	.7095	.0191	.0187	.0187
5	.0191	.9335	.7468	.7468	.0191	.0187	.0187
6	.0191	.9522	.7468	.7468	.0191	.0187	.0187
7	.0191	.9709	.7468	.8215	.0191	.0187	.0187
8	1.8442	.0187	.0187	.0191	1.6785	1.2696	2.0911
9	1.9281	.0187	.0187	.0191	1.848	1.2742	2.1437
10	2.2405	.0191	.0187	.0187	2.0698	1.9281	2.2218
11	2.2405	.0191	.0187	.0187	2.1437	1.8778	2.1098
12	2.0911	.0191	.0187	.0187	2.0911	1.8442	2.1472
13	2.1658	.0191	.0187	.0187	2.0485	1.8778	2.1098
14	1.9605	.0191	.0187	.0187	1.848	1.8107	2.0538
15	1.8671	.0191	.0187	.0187	1.848	1.6766	1.9231
16	.0187	.0191	.0187	.0187	.0191		.0187
17	.0187	.0191	.0187	.0187	.0191	.0187	.0187
18	.0187	.0187	.0191	.0191	.0187	.0191	.0191
19	.0187	.0187	.0191	.0191	.0187	.0191	.0191
20	.0187	.0187	.0191	.0191	.0187	.0191	.0191
21	.0187	.0187		.0191		.0191	.0191
22	1.3256	.7468	.961	.0191		.0191	.0187
23	1.1763	.8215	.961	.0191			.0191
24	.0191	1.1389	.7842	.7842	.0191	.0187	.0187
Max	2.2405	1.1389	.961	.8215	2.1437	1.9281	2.2218
Min	.0187	.0187	.0187	.0187	.0187	.0187	.0187
Avg	.8298	.4016	.3523	.2600	.7535	.6283	.7126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 205 / Sarud-Shirgaon Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0747	.0754	.0762	.056	.0747
2	.0747	.0747	.0747	.056	.0762	.056	.0747
3	.0747	.0747	.0747	.056	.0762	.056	.0747
4	.0747	.0747	.0747	.0934	.0762	.056	.0934
5	.112	.0934	.112	.112	.0762	.0934	.112
6	.1494	.1307	.1307	.1494	.1307	.112	.1307
7	.168	.1867	.1867	.1494	.168	.1494	.1307
8	.1677	.2054	.1867	.1867	.1867	.168	
9	.1677	.2054	.2054	.2054	.168	.1715	.1867
10	.1867	.2054	.2054	.2241	.1494	.168	.168
11	.1494	.1867	.2054	.1867	.1867	.1715	.1494
12	.1307	.1494	.2241	.1307	.1494	.168	
13	.112	.112	.168	.1494	.1307	.168	.1307
14	.112	.1494	.1307	.1494	.1307	.168	.112
15	.112	.1494	.1307		.112	.112	.112
16	.168	.1494	.1494	.168	.112	.1307	.1307
17	.1867	.1307	.2054	.168	.1307		.1307
18	.1494	.1494	.1867	.1867	.168	.1494	.1494
19	.2801	.2427	.2054	.2427	.2614	.2241	.2427
20	.2987	.2801	.2614	.2241	.2614	.2801	.2801
21	.2427	.2427	.2427	.1867		.2427	.2241
22	.168	.1494	.1867	.168		.168	.168
23	.112	.0934	.0934	.1307			.0934
24	.0934	.0934	.0934	.0747	.0762	.0747	.0934
Max	.2987	.2801	.2614	.2427	.2614	.2801	.2801
Min	.0747	.0747	.0747	.056	.0762	.056	.0747
Avg	.1493	.1509	.1587	.1510	.1382	.1429	.1392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 206 / Sarud-Salashi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.8298	1.7924	1.8671	.1905	.1867	.2241
2	.1524	1.7924	1.7551	1.7551	.1905	.1867	.2241
3	.1524	1.7924	1.7737	1.6804	.1905	.1867	.2241
4	.1524	1.7924	1.7924	1.643	.1905	.1867	.2614
5	.1524	1.8484	1.7924	1.6804	.1905	.2614	.2614
6	.1524	1.8671	1.7924	1.7177	.2477	.2987	.3018
7	.1524	1.9231	1.6057	1.7924	.3734	.3361	.3361
8	2.8669	.2801	.2987	.3361	2.9874	3.3048	3.0247
9	2.934	.3547	.2987	.2987	2.7664	2.9843	3.2114
10	3.4728	.2801	.3174	.2987	2.963	2.9959	3.3421
11	3.0807	.2427	.2801	.2801	3.3471	2.8502	3.3794
12	2.9127	.2801	.2987	.2241	3.4355	2.3472	3.0807
13	2.9874	.2801	.2614	.2054	3.1131	2.431	2.9874
14	2.6139	.2054	.2241	.1867	3.1232	2.5149	2.9874
15	2.4272	.2614	.2427	.2241	2.9874	2.1795	2.7446
16	.2614	.2801	.2427		.1494	.1867	.2054
17		.2614		.2987			.2427
18		.2987	.2614	.2987	.2427	.2614	.2427
19	.3174	.3174	.2054	.3361	.2614	.3174	.2858
20	.3361	.3174	.2987	.2801	.3361	.2987	.3239
21	.3361	.3174	.2987	.2801		.3174	.2987
22	1.8484	1.7737	2.0119	.2801		.2987	.2987
23	1.9044	1.8858	1.9404	.2241			.2614
24	.1524	1.8298	1.8298	1.8671	.1905	.2427	.2614
Max	3.4728	1.9231	2.0119	1.8671	3.4355	3.3048	3.3794
Min	.1524	.2054	.2054	.1867	.1494	.1867	.2054
Avg	1.3418	.9297	.9398	.785	1.3738	1.1443	1.2088



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 207 / Sarud-Thergaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.0187	.0187	.0191	.6706	.5601	.5228
2	.3353	.0187	.0187	.0191	.5601	.5601	.5228
3	.3353	.0187	.0187	.0191	.503	.5601	.4854
4	.3353	.0187	.0187	.0191	.503	.5415	.5228
5	.503	.0187	.0187	.0191	.503	.5228	.5601
6	.503	.0187	.0187	.0191	.57	.6348	.5975
7	.5533	.0187	.0187	.0191	.6371	.6908	.7095
8	.0187	1.5684	1.7737	1.643		.0181	.0187
9	.0191	1.7737	1.9231	1.6804	.0187	.0191	.0191
10	.0187	1.8298	1.6804	1.643	.0191	.0191	.0187
11	.0187	1.8484	1.6991	1.643	.0191	.0191	.0187
12	.0187	1.7737	1.7737	1.4937	.0191	.0191	.0187
13	.0187	1.7364	1.6991	1.6057	.0191	.0191	.0187
14	.0187	1.6817	1.6057	1.4937	.0191	.0191	.0187
15	.0187	1.4937	1.4937	1.2323	.0191	.0191	.0187
16	.0187	.0191	.0187	.0187	.0191	.0187	.0187
17	.0187	.0191	.0187	.0187	.0187		.0187
18	.0187	.0187	.0191	.0191	.0187	.0191	.0191
19	.0187	.0187	.0191	.0191	.0187	.0191	.0191
20	.0187	.0187	.0191	.0191	.0187	.0191	.0191
21	.0187	.0187	.0191	.0191		.0191	.0191
22	.0187	.0187	.0191	.6874		.6908	.7042
23	.0187	.0187	.0191	.7468			.6539
24	.3361	.0187	.0187	.0191	.6706	.5415	.5228
Max	.5533	1.8484	1.9231	1.6804	.6706	.6908	.7095
Min	.0187	.0187	.0187	.0187	.0187	.0181	.0187
Avg	.1473	.5836	.5813	.5890	.2422	.2522	.2527

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 208 / 11 KV Haritkranti Bhadale

PURELY LIS FEEDERS

LIS Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
5					.0934	
6	.2515	.2801	.0934		.2801	
7	.2515	.2801	.2801	.0934	.2801	.0934
8	.2515	.2801	.2801	.2801	.2801	.2801
9		.2801	.2801	.2801	.2518	.2801
10	.2801	.2801	.2801	.2801	.2683	.2801
11	.2801	.2801	.2801	.2801	.2683	.2801
12	.2801	.2801	.2801	.2801	.2683	.2801
13	.112	.2801	.2801	.2801	.2683	.2801
14	.2801	.2801	.2801	.2801	.2683	.2801
15	.2801	.2801	.2801	.2801	.2683	.2801
16		.2801	.2801	.2801	.2683	.2801
17		.2801		.2801		.2801
18		.2801	.2801		.2987	.2515
Max	.2801	.2801	.2801	.2801	.2987	.2801
Min	.112	.2801	.0934	.0934	.0934	.0934
Avg	.2519	.2801	.2645	.2631	.2586	.2622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 209 / Sarud-Nerle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5868	.0373	.0373	.0381	.8383	.9335	.8402
2	.503	.0373	.0373	.0381	.8383	1.0456	.8215
3	.503	.0373	.0373	.0381	.6706	.7842	.7468
4	.503	.0373	.0373	.0381	.6706	.7842	.7842
5	.503	.0373	.0373	.0381	.6706	.7468	.7468
6	.4694	.0373	.0373	.0381	.8048	.7095	.8029
7	.4694	.0373	.0373	.0381	.8048	.7468	.7095
8	.0381	2.1472	2.2779	1.9589	.0335	.0187	.0373
9	.0381	2.4459	2.3712	2.1992	.0373	.0381	.0381
10	.0373	2.5019	2.5579	2.1472	.0373	.0381	.0373
11	.0373	2.4025	2.5019	.3174	.0381	.0381	.0373
12	.0373	2.3339	2.2405		.0381	.0381	.0373
13	.0373	2.4209	2.1285	2.3712	.0381	.0381	.0373
14	.0373	2.4272	2.1472		.0381	.0381	.0373
15	.0373	2.2361	1.9978		.0373	.0381	.0373
16	.0373	.0373		1.6991	.0381	.0373	.0373
17	.0373	.0381		1.6617	.0373		.0373
18	.0373	.0373		.0381	.0373	.0381	.0373
19	.0373	.0373	.0381	.0381	.0373	.0381	.0381
20	.0373	.0373	.0381	.0381	.0373	.0381	
21	.0373	.0373	.0381	.0381		.0381	.0373
22	.0373	.0373	.0381	1.2071		1.1576	1.073
23	.0373	.0373	.0381	1.1736			.9724
24	.6706	.0373	.0373	.0381	1.0059	.9522	.9335
Max	.6706	2.5019	2.5579	2.3712	1.0059	1.1576	1.073
Min	.0373	.0373	.0373	.0381	.0335	.0187	.0373
Avg	.2003	.8131	.8910	.7235	.3233	.3789	.3877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 201 / 11 Kv Warul-Amba

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	28-FEB-18
HR	Load (MW)
8	.7796
9	.815
10	.7888
11	.7628
12	.7796
13	.7202
14	.6201
15	.691
16	.6089
Max	.815
Min	.6089
Avg	.7296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 202 / 11 Kv Warul -Yelur  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	28-FEB-18
HR	Load (MW)
8	1.6385
9	1.6194
10	1.6004
11	1.6004
12	1.6842
13	1.6964
14	1.6842
15	1.6164
16	.0179
Max	1.6964
Min	.0179
Avg	1.4620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 203 / 11Kv Warul- Bhendavade  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	28-FEB-18
HR	Load (MW)
23	.9389
Max	.9389
Min	.9389
Avg	.9389

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 401 / 33 Kv Kadavi Generation

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0514	.0514		.0514	.0514	
2		.0514	.0514		.0514	.0514	
3		.0514	.0514			.0514	
4		.0514	.0514		.0514	.0514	
5	.0514	.0514	.0514		.0514	.0514	
6	.0514	.0514	.0514		.0514	.0514	
7	.0514	.0514	.0514		.0514	.0514	
8		.0514	.9259		.0514	.0514	.0163
9		.0514	.9465	.9259	.8745	.0514	
10	.0503	.0514	.9465	.9259	.9036	.0514	.9568
11	.0554	.0514	.9465	.9259	.9036	.0514	.9465
12	.0514	.0514	.9259	.9259	.8939	.0514	.9568
13	.0514	.0514	.9259	.8745	1.1317	.0514	.9568
14	.0514	.0514	.0543	.0514	1.2226	.0514	.8939
15		.0514	.0543		1.1568	.052	.9036
16		.0514	.0526		.0514	.052	.0532
17		.0514			.0514		
18		.0514			.0514		
19					.0514		
20					.0514		
21		.0514			.0514		
22		.0514			.0514		
23		.0514			.0514		
24	.0514	.0514	.0514	.0514	.0514	.0514	
Max	.0554	.0514	.9465	.9259	1.2226	.052	.9568
Min	.0503	.0514	.0514	.0514	.0514	.0514	.0163
Avg	.0517	.0514	.3641	.6687	.3439	.0515	.7105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 201 / Turukwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.663	.5735	.8048		
2			.4973	.4915	.7545		
3			.4973	.4915	.7042		
4			.4973	.4915	.7042		
5			.4973	.4915	.7209		
6			.547	.5365	.7377		
7			.5801	.57	.7545		
8	1.4083				1.2407	1.2003	1.2239
9	1.7318				1.3916	1.5249	1.543
10	1.6956				1.4922	1.4586	1.543
11	1.6108				1.6108	1.4419	1.56
12	1.5424				1.5089	1.4746	1.543
13	1.4089				1.4255	1.3763	1.4089
14	1.278				1.3435	1.4074	1.3592
15	1.1498				1.278	1.3735	1.326
22		1.0513	.9448	1.0174			
23		.9614	.8288	1.0174			
24			.8619	.7865	.8886		
Max	1.7318	1.0513	.9448	1.0174	1.6108	1.5249	1.56
Min	1.1498	.9614	.4973	.4915	.7042	1.2003	1.2239
Avg	1.4782	1.0064	.6415	.6467	1.0850	1.4072	1.4384



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2126	.1949	.2103	.1595	.1928	.1928	.2279
2	.1949	.1949	.1928	.1595	.1928	.1928	.2279
3	.1949	.1949	.1928	.1595	.1928	.1928	.2279
4	.1949	.1949	.1928	.1595	.1928	.1928	.2279
5	.2126	.197	.2103	.1595	.1928	.2103	.2279
6	.2658	.1991	.2658	.2328	.2103	.2658	.2629
7	.3224	.2743	.3366	.2686	.2686	.3439	.2896
8	.3189	.3544	.3012	.3189	.2804	.3391	.3582
9	.3366	.3506	.3467	.4031	.3641	.3601	.3856
10	.3467	.3467	.3467	.3856	.39	.3944	.4382
11	.3467	.3856	.333	.3641	.3988	.39	.3856
12	.3467	.3721	.3506	.3155	.3814	.3601	.3641
13	.3467	.3681	.3155	.3506	.3814	.2713	.3641
14	.3467	.3429	.3155	.3224	.3601	.3121	.3258
15	.3222	.3429	.298	.2984	.3772	.3506	.3429
16	.3814	.3429	.2804		.3772	.3814	.3467
17	.3429		.298	.3441	.39	.3772	.3988
18	.4298		.3856	.3353	.4239	.463	.4161
19	.4525		.4298	.463	.4908	.5493	.4784
20	.4755		.4294	.4656	.5014	.4525	.5304
21	.439		.3921	.3982	.4835	.4207	.4066
22	.3658	.362	.3292	.3258	.3761	.3658	.3841
23	.2481	.2686	.2507	.2279	.2804	.2835	.2715
24	.2279	.2126	.2279	.1772	.1928	.2454	.2303
Max	.4755	.3856	.4298	.4656	.5014	.5493	.5304
Min	.1949	.1949	.1928	.1595	.1928	.1928	.2279
Avg	.3197	.2894	.3013	.2954	.3289	.3295	.3383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 203 / 11 KV Kandavan Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1848	.1478	.1307	.1663	.1646	.1463
2	.1463	.1848	.1478	.1307	.1646	.1646	.128
3	.1463	.1848	.1478	.1307	.168	.1646	.128
4	.1463	.1848	.1478	.1433	.1646	.1646	.128
5	.1829	.2218	.1848	.181	.1663	.1829	.2195
6	.2587	.2772	.2614	.2587	.2614	.2195	.2743
7	.3841	.4024	.4108	.3734	.3734	.3696	.439
8	.3982	.4163	.3658	.3881	.3841	.362	.3801
9	.3898	.3856	.4119	.4163	.443	.394	.3582
10	.3681	.3467	.3988	.4119	.3391		.3681
11	.3155	.3189	.3506	.4252	.3052	.2774	.3155
12	.2947	.2835	.3258	.3506	.2629	.2601	.2601
13	.2915	.3155	.2686	.3294	.2229	.2303	.1907
14	.2374	.2601	.2686	.2804	.1865		.2229
15	.2713	.2572	.2686		.1907	.298	.2427
16	.3222	.2401	.2658		.2401	.3052	.2126
17	.373	.2915	.3224	.3521	.2543	.3401	.2865
18	.4298	.3601	.3224	.4024	.2713	.39	.3641
19	.5544	.5487	.4668	.5434	.4207	.5316	.5792
20	.5601	.5601	.5281	.5249	.5544	.5304	.5359
21	.5093	.4338	.415	.4572	.4481	.4572	.4481
22	.415	.3395	.3018	.3658	.3326	.3881	.3584
23	.2427	.2263	.1867	.2353	.1848	.2378	.2241
24	.168	.1867	.168	.1307	.1612	.1848	.1829
Max	.5601	.5601	.5281	.5434	.5544	.5316	.5792
Min	.1463	.1848	.1478	.1307	.1612	.1646	.128
Avg	.3147	.3088	.2952	.3165	.2778	.3008	.2914

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 201 / Sh-R- Panhala Hill Station

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1143	.1143	.0953	.0857	.1143	.0857
2	.0857	.1143	.1143	.0953	.0857	.1143	.0857
3	.0857	.1143	.1143	.0953	.0857	.1143	.0857
4	.0857	.1143	.1143	.0953	.1029	.1143	.1029
5	.1029	.1334	.1143	.0953	.12	.1334	.12
6	.1372	.1715	.1715	.1524	.1372	.1715	.1372
7	.1715	.1715	.1715	.1524	.1715	.1905	.1715
8	.1543	.2096	.1905	.1715	.1886	.2286	.2058
9	.1543	.1715	.1524	.2096	.1715	.1905	.1715
10	.1905	.1524	.1715	.1372	.2096	.1886	.1524
11	.1715	.1524	.1524	.12	.1905	.1543	.1524
12	.1715	.1524	.1715	.12	.1334	.1524	.1524
13	.1715	.1715	.1524	.1372	.1524	.1524	
14	.1524	.1715	.1524	.12	.1715	.1524	.1715
15	.1524	.1524	.1715	.1372	.1715	.1524	.1905
16	.1715	.1905	.1715	.1372	.1715	.1372	.1905
17	.1715	.1905	.1524	.1372	.1715	.12	.1905
18	.1905	.2286	.1524	.12	.1905	.12	.1905
19	.2286	.2667	.2286	.2058	.2667	.2096	.2667
20	.2667	.2286	.2477	.2401	.2858	.1886	.2667
21	.2477	.2286	.2477	.2229	.2667	.1886	.2667
22	.2286	.2096	.2096	.2058	.2477	.1715	.2477
23	.1715	.1905	.1524	.1715	.1905	.1543	.1905
24	.1029	.1334	.1334	.1143	.1029	.1334	.1029
Max	.2667	.2667	.2477	.2401	.2858	.2286	.2667
Min	.0857	.1143	.1143	.0953	.0857	.1143	.0857
Avg	.1605	.1723	.1635	.1454	.1696	.1561	.1695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1334	.1143	.0953	.0857	.0953	.0857
2	.0857	.1334	.1143	.0953	.0857	.0953	.0857
3	.0857	.1334	.1143	.0953	.0857	.0953	.0857
4	.0857	.1334	.1143	.0953	.0857	.0953	.1029
5	.1372	.1524	.1524	.0953	.12	.0953	.1372
6	.1886	.2667	.2477	.2286	.1715	.1905	.1715
7	.2572	.2667	.2477	.2286	.2229	.2286	.2058
8	.2229	.2477	.2858	.2477	.2401	.2096	.2058
9	.2058	.2667	.2477	.2477	.2229	.2667	.2229
10	.2096	.2667	.2286	.2229	.2858	.1886	.1524
11	.1905	.2858	.2477	.2058	.2477	.1715	.1524
12	.1905	.2286	.2477	.1372	.2096	.1715	.1715
13	.1524	.1905	.2286	.1372	.2096	.1715	.1524
14	.1334	.1905	.1905	.1372	.1905	.1524	.1524
15	.1334	.2286	.2286	.1372	.2096	.1524	.1715
16	.1905	.2286	.1715	.1372	.2286	.1715	.1715
17	.2286	.2286	.2096	.1543	.2477	.1543	.2286
18	.2477	.3048	.2477	.1715	.1715	.1886	.2286
19	.3429	.3429	.3239	.2401	.2667	.362	.3429
20	.2858	.381	.3239	.3429	.2477	.2572	.362
21	.2858	.3048	.3239	.3086	.2667	.2229	.3429
22	.2286	.1905	.2096	.2229	.1905	.1543	.1905
23	.1715	.1524	.1524	.1543	.1143	.1029	.1334
24	.1029	.1334	.1143	.1143	.1029	.0953	.0857
Max	.3429	.381	.3239	.3429	.2858	.362	.362
Min	.0857	.1334	.1143	.0953	.0857	.0953	.0857
Avg	.1854	.2246	.2120	.1772	.1879	.1704	.1809

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035]

BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 203 / 11 KV NAVALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2667	.3048	.3048	.1886	.2286	.2058
2	.2229	.2667	.3048	.3048	.1886	.2286	.2058
3	.2229	.2667	.3048	.3048	.1886	.2286	.2058
4	.2572	.2667	.3048	.3048	.2229	.2286	.2572
5	.3429	.3048	.3239	.3048	.3086	.3048	.3086
6	.4115	.4572	.5335	.4954	.4115	.4572	.3772
7	.5144	.6478	.6097	.5525	.4973	.5716	.5144
8	.5144	.6097	.6097	.5525	.463	.5716	.4973
9	.4801	.6097	.6478	.6097	.463	.6097	.3086
10	.5716	.5716	.6668	.6344	.5335	.5316	.3429
11	.5716	.5716	.6478	.5658	.381	.4458	.4954
12	.4954	.4191	.6478	.5144	.4572	.5144	.4763
13	.4572	.4572	.5144	.4458	.381	.4382	.4954
14	.4191	.4572	.4763	.463	.3429	.4572	.5335
15	.381	.4191	.5144	.4973	.4191	.4954	.5716
16	.4572	.5716	.6097	.583	.4191	.583	.6859
17	.5335	.6478	.6097	.583	.4572	.5658	.724
18	.5335	.6478	.6287	.5144	.4954	.5487	.7621
19	.8383	.8002	.8764	.7545	.8002	.8383	.9145
20	.8764	.9526	.8954	.7716	.8383	.7888	.8764
21	.7621	.8002	.7621	.6687	.7621	.7202	.8002
22	.6097	.6097	.6287	.5487	.6097	.5144	.6287
23	.381	.4572	.381	.3086	.381	.3429	.381
24	.2572	.3048	.3239	.3429	.2229	.2667	.2401
Max	.8764	.9526	.8954	.7716	.8383	.8383	.9145
Min	.2229	.2667	.3048	.3048	.1886	.2286	.2058
Avg	.4723	.5160	.5470	.4971	.4347	.4784	.4920

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035]

BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.0953	.1143	.1143	.0857	.0953	.0857
2	.0857	.0953	.1143	.1143	.0857	.0953	.0857
3	.0857	.0953	.1143	.1143	.0857	.0953	.0857
4	.0857	.0953	.1143	.1143	.0857	.0953	.1029
5	.1029	.1143	.1143	.1143	.1029	.1143	.12
6	.1372	.1524	.1524	.1715	.1372	.1524	.1543
7	.1715	.2096	.2286	.2286	.1715	.1905	.1886
8	.1715	.2096	.2096	.2477	.1886	.2096	.2058
9	.1715	.1715	.1905	.2477	.2058	.1905	.1715
10	.1524	.1905	.1524	.1372	.1905	.1543	.2286
11	.1905	.1905	.1143	.12	.1905	.1715	.2286
12	.2096	.1905	.1905	.1886	.1524	.1905	.2096
13	.1715	.1905	.1715	.12	.1524	.1524	.1715
14	.1524	.1524	.1524	.1543	.1334	.1524	.1524
15	.2096	.1524	.1524	.1543	.1524	.1524	.2096
16	.1905	.1905	.1715	.1715	.1524	.1372	.2667
17	.2667	.2286	.2096	.1543	.1715	.1715	.2667
18	.2286	.2477	.2667	.2058	.2477	.2058	.2667
19	.3048	.2667	.3048	.2058	.3048	.3429	.3429
20	.2858	.2858	.3048	.2572	.3048	.2572	.3048
21	.2096	.2477	.2858	.2401	.2667	.2401	.2667
22	.2096	.2096	.2286	.2058	.2096	.2058	.1905
23	.1715	.1905	.1524	.1029	.1524	.1543	.1524
24	.1029	.1143	.1334	.1334	.1029	.1143	.1029
Max	.3048	.2858	.3048	.2572	.3048	.3429	.3429
Min	.0857	.0953	.1143	.1029	.0857	.0953	.0857
Avg	.1731	.1786	.1810	.1674	.1681	.1684	.1900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 205 / 11 KV INJOLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0857	.1334	.1524	.1334	.1029	.1334	.1029
2	.0857	.1334	.1524	.1334	.1029	.1334	.1029
3	.0857	.1334	.1524	.1334	.1029	.1334	.1029
4	.1029	.1334	.1524	.1334	.12	.1334	.1372
5	.1543	.1524	.1524	.1334	.1543	.1524	.1715
6	.2058	.2286	.2667	.2286	.1886	.2286	.2058
7	.2572	.3048	.3048	.2858	.2401	.2858	.2401
8	.2743	.2858	.3048	.2477	.2401	.2858	.2401
9	.2058	.2667	.2858	.2286	.2572	.2477	.2229
10	.2286	.1905	.2477	.1886	.2096	.1715	.2286
11	.1905	.1905	.2286	.2572	.2286	.1715	.2096
12	.2096	.2286	.1905	.2229	.1905	.1524	.2096
13	.2286	.1905	.2096	.2058	.1715	.1524	.2096
14	.2286	.1715	.2477	.1886	.1715	.1905	.2096
15	.2096	.2286	.2667	.1886	.2096	.1905	.2286
16	.3048	.2477	.2667	.2058	.2096	.1886	.2667
17	.1905	.2667	.2667	.2229	.2286	.1886	.2477
18	.2096	.2858	.2667	.2572	.2477	.1886	.2667
19	.362	.3239	.362	.3429	.3429	.381	.362
20	.4001	.362	.3429	.3429	.381	.3429	.362
21	.3429	.3429	.3429	.3086	.3429	.3258	.3429
22	.2477	.2858	.2667	.2572	.2667	.2572	.3048
23	.1905	.2477	.1905	.1543	.1905	.1886	.1905
24	.12	.1334	.1905	.1524	.12	.1524	.1372
Max	.4001	.362	.362	.3429	.381	.381	.362
Min	.0857	.1334	.1524	.1334	.1029	.1334	.1029
Avg	.2134	.2278	.2421	.2147	.2092	.2074	.2209

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 206 / 11kv Broadcast Express NON SHEDDABLE EXPRESS HV FEEDERS  
 feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0572	.0381	.0762	.0514	.0381	.0514
2	.0514	.0572	.0381	.0762	.0514	.0381	.0514
3	.0514	.0572	.0381	.0762	.0514	.0381	.0514
4	.0514	.0572	.0381	.0762	.0514	.0381	.0514
5	.0514	.0572	.0381	.0762	.0514	.0381	.0514
6	.0686	.0572	.0762	.0762	.0514	.0381	.0686
7	.0686	.0762	.0762	.0762	.0686	.0762	.0686
8	.0686	.0762	.0762	.0762	.0716	.0762	.0686
9	.0686	.0762	.0762	.0762	.0686	.0762	.0686
10	.0762	.0762	.0762	.0686	.0762	.0686	.0762
11	.0762	.0762	.0762	.0686	.0762	.0686	.0762
12	.0762	.0762	.0762	.0686	.0762	.0762	.0762
13	.0762	.0762	.0762	.0686	.0762	.0762	.0762
14	.0762	.0762	.0762	.2058	.0762	.0762	.0762
15	.0762	.0762	.0762	.0693	.0762	.0762	.0762
16	.0762	.0762	.0762	.0686	.0762	.0686	.0762
17	.0762	.0762	.0762	.0686	.0762	.0686	.0762
18	.0762	.0762	.0762	.0686	.0762	.0686	.0762
19	.0762	.0762	.0762	.0686	.0762	.0762	.0762
20	.0762	.0191	.0762	.0686	.0762	.0686	.0762
21	.0762	.0762	.0762	.0686	.0762	.0686	.0762
22	.0762	.0762	.0762	.0686	.0762	.0686	.0762
23	.0762	.0762	.0762	.0514	.0762	.0686	.0762
24	.0514	.0572	.0762	.0762	.0514	.0572	.0514
Max	.0762	.0762	.0762	.2058	.0762	.0762	.0762
Min	.0514	.0191	.0381	.0514	.0514	.0381	.0514
Avg	.0687	.0683	.0683	.0768	.0681	.0630	.0687



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 207 / 11Kv Mitharwadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1905	.1524	.1715	.1543	.7621	.9431
2	.6859	.1905	.1524	.1715	.1543	.7621	.9088
3	.6859	.1905	.1524	.1715	.1543	.6859	.8745
4	.6859	.1905	.1524	.1715	.1543	.6859	.8573
5	.7202	.1905	.1905	.1715	.1886	.6859	.823
6	.7373	.2286	.2286	.2667	.2229	.8002	.7545
7	.7545	.2667	.2286	.3429	.2743	.9145	.823
8	.9945	1.2193	.9907	.9755	.2743	.3429	.2058
9	1.166	1.4098	1.5242	1.3717	.2401	.2667	.2401
10	1.6766	1.5242	1.2498	1.5089	.2286	.2401	.2286
11	1.6004	1.5242	1.2193	1.3717	.2667	.2401	.2286
12	1.6004	1.448	1.5242	1.3717	.3048	.2477	.2286
13	1.5242	1.448	1.0974	1.3717	.2286	.1905	.2286
14	1.448	1.2193	1.0669	1.166	.1905	.1905	.1905
15	1.2193	1.1431	1.0364	.9602	.2286	.1905	.1905
16	.1905	.2286	.2286	.2058	.2286	.2058	.2286
17	.2667	.2286	.2667	.2743	.2477	.2743	.2667
18	.3429	.2667	.3048	.2915	.3048	.2743	.3048
19	.3048	.3429	.3429	.2572	.3048	.3239	.3048
20	.2667	.362	.2667	.2058	.2477	.2572	.2667
21	.2286	.2667	.2667	.1886	.2667	.2401	.2667
22	.2286	.2667	.2667	.2058	1.2955	1.166	.6706
23	.1905	.2286	.2286	.1715	1.2193	1.0974	.6097
24	.7545	.1905	.2286	.2096	.1715	.9145	.9945
Max	1.6766	1.5242	1.5242	1.5089	1.2955	1.166	.9945
Min	.1905	.1905	.1524	.1715	.1543	.1905	.1905
Avg	.7900	.6152	.5569	.5656	.3147	.4983	.4849

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 208 / Waghawe Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.9145	.0191	.0191	.0171	.9145	.1372
2	.6859	.9145	.0191	.0191	.0171	.9145	.9431
3	.6001	.9145	.0191	.0191	.0171	.8764	.8916
4	.5658	.9145	.0191	.0191	.0171	.8764	.8573
5	.5487	.9145	.0191	.0191	.0171	.8764	.823
6	.5316	1.0288	.0191	.0191	.0171	1.0288	.7716
7	.5144	1.1431	.0191	.0191	.0171	1.1431	.823
8	.0171	1.7147	2.191	1.829	.0171	.0191	.1029
9	.0171	1.9052	2.5149	1.9204	.0171	.0191	.0857
10	.0191	2.2862	1.829	2.0919	.0191	.0171	.0191
11	.0191	2.2862	1.829	2.0576	.0191	.0171	.0191
12	.0191	2.2862	1.829	2.0576	.0191	.0191	.0191
13	.0191	2.0957	1.6918	2.0405	.0191	.0191	.0191
14	.0191	2.0957	1.7223	1.9719	.0191	.0191	.0191
15	.0191	1.829	1.5546	1.4746	.0191	.0191	.0191
16	.0191	.0191	.0191	.0171	.0191	.0171	.0191
17	.0191	.0191	.0191	.0171	.0191	.0171	.0191
18	.0191	.0191	.0191	.0171	.0191	.0171	.0191
19	.0191	.0191	.0191	.0171	.0191	.0191	.0191
20	.0191	.0191	.0191	.0171	.0191	.0171	.0191
21	.0191	.0191	.0191	.0171	.0191	.0171	.0191
22	1.0288	.0191	.0191	.0171	1.6004	1.3375	1.3717
23	1.0288	.0191	.0191	.0171	1.4861	1.166	1.3717
24	.8573	.9145	.0191	.0191	.0171	1.1431	1.0288
Max	1.0288	2.2862	2.5149	2.0919	1.6004	1.3375	1.3717
Min	.0171	.0191	.0191	.0171	.0171	.0171	.0191
Avg	.3082	1.0129	.6445	.6555	.1453	.4388	.3932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 209 / 11KV INJOLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191	.6097	.4268	.0514	.0191	.0171
2	.0171	.0191	.6097	.4268	.4801	.0191	.0171
3	.0171	.0191	.6097	.4268	.4801	.0191	.0171
4	.0171	.0191	.6097	.4268	.4801	.0191	.0171
5	.0171	.0191	.6097	.4268	.4801	.0191	.0171
6	.0171	.0191	.6097	.442	.4973	.0191	.0171
7	.0171	.0191	.6097	.5335	.5144	.0191	.0171
8	.6173	.0191	.0191	.0191	.6001	.6859	.6859
9	.6516	.0191	.0191	.0191		.6859	.7202
10	.7621	.0191	.0191	.0171	.2667	.6344	.8002
11	.7621	.0191	.0191	.0171	.724	.6344	.8002
12	.7621	.0191	.0191	.0171	.7621	.7049	.6097
13	.724	.0191	.0191	.0171	.724	.724	.7621
14	.724	.0191	.0191	.0171	.724	.724	.6097
15	.6478	.0191	.0191	.0171	.6859	.724	.4877
16	.0191	.0191	.0191	.0171	.0191	.0171	.0191
17	.0191	.0191	.0191	.0171	.0191	.0171	.0191
18	.0191	.0191	.0191	.0171	.0191	.0171	.0191
19	.0191	.0191	.0191	.0171	.0191	.0191	.0191
20	.0191	.0191	.0191	.0171	.0191	.0171	.0191
21	.0191	.0191	.0191	.0171	.0191	.0171	.0191
22	.0191	.724	.5487	.583	.0191	.0171	.0191
23	.0191	.724	.6097	.5487	.0191	.0171	.0191
24	.0171	.0191	.724	.4572	.5487	.0191	.0171
Max	.7621	.724	.724	.583	.7621	.724	.8002
Min	.0171	.0191	.0191	.0171	.0191	.0171	.0171
Avg	.2475	.0778	.2674	.2059	.3553	.2420	.2402

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 201 / 11 KV DIGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0566	.0514	.0514	.0514	.0566	.0514
2	.0514	.0566	.0514	.0514	.0514	.0566	.0514
3	.0514	.0566	.0514	.0514	.0514	.0566	.0514
4	.0857	.0739	.0514	.0857	.0686	.0754	.0514
5	.1029	.1097	.1372	.1029	.0857	.0754	.0686
6	.12	.1448	.1886	.1372	.1372	.0857	.1029
7	.1715	.1791	.1886	.1372	.12	.1715	.1372
8	.1543	.1753	.1715	.1372	.1886	.1543	.1372
9	.1372	.1402	.1715	.1715	.1886	.1372	.1372
10	.1494	.1543	.12	.1402	.12	.1543	.1402
11	.1372	.12	.1372	.1734	.1372	.1372	.1029
12	.1372	.1372	.1372	.0867	.1372	.12	.12
13	.1372	.12	.1029	.0867	.1372	.1372	.12
14	.0857	.1372	.12	.1029	.1372	.0857	.1372
15	.12	.1029	.1543	.1029	.1029	.12	.12
16	.0857	.12	.0857	.12	.0857	.12	.1372
17	.12	.12	.12	.12	.1372	.1372	.1543
18	.1715	.1372	.12	.1543	.1372	.1372	.2058
19	.197	.2058	.1715	.1543	.1715	.1715	.2058
20	.2033	.2058	.1715	.1543	.1543	.1543	.2058
21	.1867	.1886	.12	.1543	.1372	.1372	.2058
22	.1509	.0857	.1029	.12	.1132	.1029	.1715
23	.0943	.0686	.0857	.0686	.0754	.0686	.0686
24	.0514	.0754	.0514	.0686	.0514	.0566	.0514
Max	.2033	.2058	.1886	.1734	.1886	.1715	.2058
Min	.0514	.0566	.0514	.0514	.0514	.0566	.0514
Avg	.1231	.1238	.1193	.1139	.1157	.1129	.1223

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	1.094	.0343	.0305	.0343	.0343	1.4327
2	.8573	1.0608	.0343	.0343	.0343	.0343	1.387
3	.8573	1.0608	.0343	.0305	.0343	.0343	1.3413
4	.8916	1.0608	.0343	.0305	.0343	.0343	1.2955
5	.9088	1.0608	.0343	.0305	.0343	.0343	1.2498
6	.8916	1.2266	.0343	.0305	.0343	.0305	1.2041
7	1.0288	1.8778	.0343	.0305	.0343	.0305	1.2041
8	.0343	2.4143	1.9547	2.4844	2.4691	.0305	.0305
9	.0343	3.0849	3.0007	2.6825	2.4387	.0457	.0305
10	.0305	2.8197	3.1207	2.9172	2.5149	.0343	.0343
11	.0343	2.6825	2.9492	2.9172	2.4234	.0343	.0343
12	.0343	2.5758	2.915	2.8178	2.4387	.0343	.0514
13	.0343	2.6063		2.7183	2.5301	.0343	.0514
14	.0343	2.5453	2.7949		2.3015	.0343	.0857
15	.0514	2.3624	2.5206	2.2542	2.0119	.0343	.0686
16	.0343	.0305	.0343	.0343	.0305	.0343	.0686
17		.0343	.0305		.0343	.0305	.0343
18	.0514	.0343	.0305		.0343	.0305	.0686
19	.0514	.0343	.0305	.0343	.0343	.0305	.0686
20	.0514	.0343	.0305	.0343	.0343	.0305	.0324
21	.0514	.0343	.0305	.0343	.0343	.0305	.0324
22	1.326	.0343	.0305	.0343	.0343	1.8138	1.5261
23	1.326	.0343	.0305	.0343	.0343	1.6461	1.5775
24	.9431	1.1271	.0343	.0305	.0343	.0343	1.4632
Max	1.326	3.0849	3.1207	2.9172	2.5301	1.8138	1.5775
Min	.0305	.0305	.0305	.0305	.0305	.0305	.0305
Avg	.4543	1.2888	.8599	.9164	.8197	.1748	.5989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 203 / 11 KV GHOTWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0566	.0686	.0514	.0514	.0566	.0514
2	.0514	.0566	.0686	.0514	.0514	.0566	.0514
3	.0514	.0566	.0686	.0514	.0514	.0566	.0514
4	.0857	.0566	.0857	.0686	.0514	.0566	.0686
5	.12	.0747	.12	.1029	.0857	.0566	.0857
6	.1372	.1294	.1715	.1372	.1029	.12	.1372
7	.1886	.2149	.2058	.1543	.1372	.2058	.2058
8	.2229	.2126	.1886	.2229	.1372	.2058	.2058
9	.2401	.2303	.1886	.2058	.1372	.2229	.2058
10	.2058	.2058	.1886	.2103	.1372	.1886	.1753
11	.2058	.12	.1372	.156	.12	.1543	.1387
12	.2058	.1372	.12	.1214	.1029	.1543	.1387
13	.1715	.1372	.12	.12	.1029	.1372	.12
14	.1372	.12	.0857	.12	.12	.12	.12
15	.12	.12	.1029	.1029	.1372	.1372	.12
16	.1372	.1543	.1029	.1372	.12	.1543	.1543
17	.1543	.1715	.1029	.1372	.1543	.12	.1372
18	.2401	.2058	.1372	.1886	.1886	.2058	.2401
19	.3582	.2572	.3258	.2915	.2915	.3086	.2743
20	.3547	.2743	.3086	.2915	.2915	.3086	.2743
21	.2641	.2572	.2743	.2572	.2743	.2572	.2743
22	.1886	.1886	.1715	.1715	.1698	.12	.12
23	.0943	.1372	.0857	.0686	.0754	.0686	.0514
24	.0514	.0754	.0686	.0514	.0514	.0566	.0514
Max	.3582	.2743	.3258	.2915	.2915	.3086	.2743
Min	.0514	.0566	.0686	.0514	.0514	.0566	.0514
Avg	.1682	.1521	.1457	.1446	.1310	.1470	.1439

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 204 / 11 kv Digavade Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2881	.0343	.0305	.0305	.0171	.4268
2	.2743	.2881	.0343	.0305	.0305	.0189	.4115
3	.2896	.2881	.0343	.0305	.0305	.0171	.4115
4	.3353	.2881	.0343	.0305	.0305	.0171	.442
5	.4115	.3041	.0343	.0305	.0305	.0171	.5182
6	.503	.4049	.0343	.0305	.0305	.0152	.6097
7	.5944	.8356	.0343	.0305	.0305	.0152	.6249
8	.0305	1.3592	.7202	1.6004	1.4327	.0305	.0305
9	.0305	1.7072	1.5851	1.7375	1.7528	.0305	.0305
10	.0343	1.5394	1.9204	1.7901	1.6766	.0305	.0343
11	.0324	1.5394	1.6309	1.7238	1.6156	.0305	.0343
12	.0305	1.5851	1.6004	1.6575	1.4784	.0305	.0343
13	.0309	1.4937	1.5242	1.6907	1.4022	.0305	.0343
14	.0305	1.4632	1.4632	1.6575	1.2193	.0305	.0343
15	.0343	1.3108	1.5775	1.4089	.9297	.0305	.0343
16		.0305	.0305	.0343	.0305	.0305	.0343
17		.0343	.0305	.0305	.0305		.0305
18	.0343	.0343	.0305		.0305	.0305	.0343
19	.0343	.0343	.0305	.0305	.0305	.0305	.0343
20	.0343	.0343	.0343	.0305	.0305	.0305	.0305
21	.0343	.0343	.0305	.0305	.0305	.0305	.0324
22	.421	.0305	.0305	.0305	.0171	.6249	.442
23	.3361	.0343	.0305	.0305	.0171	.5792	.6478
24	.3353	.2881	.0343	.0305	.0305	.0171	.4572
Max	.5944	1.7072	1.9204	1.7901	1.7528	.6249	.6478
Min	.0305	.0305	.0305	.0305	.0171	.0152	.0305
Avg	.1894	.6354	.5227	.5969	.4987	.0755	.2273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1509	.1372	.1372	.1372	.1132	.12
2	.12	.132	.1372	.1372	.1372	.1132	.12
3	.12	.132	.1886	.1372	.1372	.1132	.12
4	.1543	.1509	.2058	.1886	.1372	.132	.1372
5	.2572	.168	.2572	.2058	.1372	.132	.1715
6	.3086	.3142	.3258	.2401	.2401	.1715	.2229
7	.3944	.4119	.3772	.3086	.3772	.3429	.3601
8	.4287	.3582	.3772	.3258	.3601	.3086	.3258
9	.3944	.443	.3429	.3258	.3258	.3601	.3429
10	.3944	.3086	.3429	.3506	.3086	.3258	.3506
11	.3601	.3601	.3944	.333	.3086	.3258	.3121
12	.3429	.2743	.3429	.2601	.2915	.3086	.2915
13	.4287	.2572	.3601	.3294	.2401	.3086	.2915
14	.3086	.2743	.3258	.2572	.2572	.2058	.2229
15	.3086	.2915	.2743	.2401	.2401	.3086	.2743
16	.3429	.3086	.2743	.3258	.3258	.3086	.2915
17	.3258	.3601	.3944	.3258	.3258	.3086	.2915
18	.3258	.3772	.3258	.3258	.3258	.3429	.4287
19	.5194	.4801	.463	.463	.3944	.463	.4458
20	.5601	.4801	.4458	.463	.463	.463	.463
21	.4527	.4115	.3944	.3772	.4287	.4287	.4801
22	.3772	.2058	.3086	.3086	.3018	.2401	.3429
23	.1886	.1696	.1715	.1715	.1698	.1715	.1886
24	.1543	.1698	.1372	.1372	.1372	.132	.1372
Max	.5601	.4801	.463	.463	.463	.463	.4801
Min	.12	.132	.1372	.1372	.1372	.1132	.12
Avg	.3210	.2912	.3044	.2781	.2712	.2678	.2805



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 206 / 11 KV GHOTWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.8861	1.7318	1.8004		
2			1.5432	1.7147	1.6289		
3			1.6461	1.6461	1.5432		
4			1.6975	1.5604	1.3717		
5				1.4575	1.1145		
6				1.3203	1.0288		
7				1.3717	1.2689		
8	3.3779					2.0576	2.7435
9	3.6694					3.4808	3.2579
10	3.2579					3.4808	3.5231
11	2.8654					3.6351	3.2777
12	3.2579					3.5151	3.12
13	3.0864					3.5322	3.1725
14	2.915					3.3608	3.2251
15	2.6749					3.1207	3.3653
16			1.2174			3.1036	
17			1.2517			2.4691	
18						2.2977	
22		2.0576	2.2805	2.4006	2.5065		
23		2.0576	2.1091	2.0919	2.3312		
24			2.0576	1.749	1.869	.0857	
Max	3.6694	2.0576	2.2805	2.4006	2.5065	3.6351	3.5231
Min	2.6749	2.0576	1.2174	1.3203	1.0288	.0857	2.7435
Avg	3.1381	2.0576	1.7432	1.7044	1.6463	2.8449	3.2106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9907	.8383	.8383	.0381	.0381	.0381
2	.0381	.9145	.7621	.7621	.0381	.0381	.0381
3	.0381	.9145	.7621	.7621	.0381	.0381	
4	.0381	.8002	.7621	.7621	.0381	.0381	.0381
5	.0381	.8002	.8002	.7621	.0381	.0381	.0381
6	.0381	.8383	.8002	.7621	.0381	.0381	.0381
7	.0381	.8954	.8764	.8192	.0381	.0381	.0381
8	.0381	.0381	.0381	.0381	2.4768	2.7625	2.6292
9	2.8197	.0381	.0381	.0381	2.8959	3.0483	2.8578
10	2.7816	.0381	.0381	.0381	2.6673	2.934	5.8109
11	2.0386	.0381	.0381	.0381	2.934	2.8578	2.8578
12	2.2862	.0381	.0381	.0381	2.6673	2.2862	2.6673
13	2.3053	.0381	.0381	.0381	2.572	2.5911	2.4768
14	2.3053	.0381	.0381	.0381	2.4006	2.1719	2.4768
15	1.8671	.0381	.0381	.0381	2.3053	2.0195	
16	.0381	.0381	.0381	.0381	.0381	.0381	.0381
17	.0381	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	1.3336	1.0669	1.0288	.0381	.0381	.0381	.0381
23	1.2384	.9907	.9526	.0381	.0381	.0381	.0381
24	.0381	1.105	.9145	.8764	.0381	.0381	.0381
Max	2.8197	1.105	1.0288	.8764	2.934	3.0483	5.8109
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.8145	.4104	.3763	.2898	.8970	.8867	1.0158

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 202 / 11 kv Chande Sheti Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	.0381	.0381	.0381	2.1529	1.9052	1.9052
2	2.0005	.0381	.0381	.0381	2.0767	1.9052	1.6766
3	1.9052	.0381	.0381	.0381	2.0576	1.8671	1.6766
4	1.8671	.0381	.0381	.0381	2.0576	1.8671	1.5242
5	1.8671	.0381	.0381	.0381	2.0576	1.829	1.5242
6	1.9052	.0381	.0381	.0381	2.1148	1.8099	1.5242
7	1.9243	.0381	.0381	.0381	2.1338	1.7718	1.5623
8		3.8104	3.7342	3.5056	.0381	.0381	
9	.0381	3.8295		3.5627	.0381	.0381	.0381
10		3.658	3.5627	3.3341	.0381	.0381	.0381
11	.0381	3.7342	3.4675	3.5818		.0381	.0381
12		3.7532	3.9628	3.4294		.0381	.0381
13		3.7913		3.4294		.0381	.0381
14		3.6199	3.8866	3.0483		.0381	.0381
15		3.2007	3.6389	2.9531		.0381	.0381
16	.0381	.0381	3.4675	.0381			.0381
17	.0381	.0381	.0381	.0381			.0381
18	.0381	.0381	.0381	.0381			.0381
19	.0381	.0381	.0381	.0381	.0381		.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	2.5911	2.4387	2.0957	2.0957
23	.0381	.0381	.0381	2.4006	2.4768	2.0957	2.0957
24	2.3053	.0381	.0381	.0381	2.2672	2.2862	2.0957
Max	2.3053	3.8295	3.9628	3.5818	2.4768	2.2862	2.0957
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.9029	1.2503	1.1951	1.3487	1.3789	.9907	.7902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.1431	1.1431	1.1431	.0381	.0381	.0381
2	.0381	1.0479	1.0669	1.0669	.0381	.0381	.0381
3	.0381	1.0479	1.0669	1.0669	.0381	.0381	.0381
4	.0381	1.0479	1.105	1.0669	.0381	.0381	.0381
5	.0381	1.0479	1.105	1.0669	.0381	.0381	.0381
6	.0381	1.0479	1.1812	1.0669	.0381	.0381	.0381
7	.0381	1.105	1.1812	1.105	.0381	.0381	.0381
8		.0381	.0381	.0381	2.3434	2.553	
9		.0381	.0381	.0381	2.6482	2.7435	2.7244
10		.0381	.0381	.0381	2.3053	2.3815	2.3243
11		.0381	.0381	.0381	2.3243	2.3624	2.3624
12	2.915	.0381	.0381	.0381	2.191	2.1529	2.2862
13	2.915	.0381	.0381	.0381	2.2481	2.2291	2.2862
14	2.553	.0381	.0381	.0381	2.0957	1.7337	2.2862
15	2.0386		.0381	.0381	1.8099	1.848	1.9052
16	1.9814	.0381	.0381	.0381	.0381	.0381	.0381
17	1.9243	.0381	.0381	.0381	.0381	.0381	.0381
18	.0381	.0381	.0381	.0381	.0381	.0381	.0381
19	.0381	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	1.4861	1.6385	1.448	.0381	.0381	.0381	.0381
23	1.3336	1.4861	1.2955	.0381	.0381	.0381	.0381
24	.0381	1.1431	1.1812	1.1431	.0381	.0381	.0381
Max	2.915	1.6385	1.448	1.1431	2.6482	2.7435	2.7244
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.8802	.5326	.5128	.3890	.7740	.7756	.7298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 204 / 11 KV Arale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724				.5716	.7621	.7621
2	.6859				.5144	.7621	.5716
3	.6859				.5144	.6668	.5716
4	.6859				.6097	.6668	.5335
5	.724				.6478	.5716	.5335
6	.724				.6859	.5716	.5525
7	.743				.6859	.5906	.6478
8		1.3908	1.2003	1.3908			
9		1.3717	1.3717	1.3717			
10		1.4861	1.3908	1.2955	.6859		
11		1.2765	1.3336	1.2003			
12		1.2955	1.2955	1.2574			
13		1.1812	1.2574	1.2003			
14		1.1241	1.2193	1.0479			
15		1.0288	1.0479	.9526			
22				.724	1.0479	.7621	.8954
23				.6668	.9526	.7621	.8954
24	.724				.5716	.8573	.7621
Max	.743	1.4861	1.3908	1.3908	1.0479	.8573	.8954
Min	.6859	1.0288	1.0479	.6668	.5144	.5716	.5335
Avg	.7121	1.2693	1.2646	1.1107	.6807	.6973	.6726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 205 / 11 kv M. Shirolgi Gaothan  
fdr Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1905	.1524	.1524	.1524	.1524	.1524
2	.1715	.1905	.1524	.1524	.1524	.1524	.1524
3	.1715	.1905	.2477	.1524	.1905	.1524	.1524
4	.1905	.1905	.3239	.1524	.362	.1715	.1524
5	.2667	.2667	.4001	.2286	.362	.2286	.2286
6	.4572	.3429	.4572	.381	.4382	.3048	.3429
7	.4572	.4382	.4572	.4191	.4191	.4572	.4191
8		.381	.381	.3429	.3239	.3239	
9	.4191	.3048	.3048	.3048	.2286	.362	.2858
10	.3048	.2667	.2286	.2286	.2286	.2667	.2858
11	.2286	.2858	.1905	.2286	.1715	.2667	.2858
12	.1905	.2286	.1905	.3048	.1715	.2286	.2286
13	.1905	.1905	.1905	.3048	.1905	.2858	.2286
14	.1905	.2477	.1715	.3048	.1715	.2286	.2286
15	.1905	.2286	.1715	.3048	.1715	.0953	.1905
16	.1905	.2858	.1715	.3048	.1905	.1143	.2477
17	.2286	.2858	.1905	.3048	.1905	.3239	.2477
18	.3048	.3239	.2477	.3048	.2096	.3239	.3239
19	.381	.4382	.3429	.4191	.4191	.381	.4572
20	.4572	.4191	.4572	.4763	.4572	.4191	.4572
21	.4572	.4191	.4191	.4382	.4382	.3429	.381
22	.381	.3048	.3048	.362	.3048	.2286	.3239
23	.3048	.2667	.2667	.1715	.1715	.1524	.2286
24	.1715	.1905	.1524	.1524	.1524	.1524	.1524
Max	.4572	.4382	.4572	.4763	.4572	.4572	.4572
Min	.1715	.1905	.1524	.1524	.1524	.0953	.1524
Avg	.2816	.2866	.2739	.2873	.2612	.2548	.2675

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038]

BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 206 / 11 Kv Chande Gavthan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.0953	.0762	.0762	.0762	.0762	.0762
2	.0762	.0953	.0762	.0762	.0762	.0762	.0762
3	.0762	.0953	.0762	.0762	.0762	.0762	.0762
4	.0762	.0953	.0953	.0762	.0953	.0953	.0762
5	.1143		.0953	.1143	.1143	.1143	.1143
6	.1905	.1905	.1524	.1905	.1524	.1524	.381
7	.2286	.2286	.1715	.2286	.1524	.2286	.2286
8		.1905	.1524	.1905	.1143	.1905	.1905
9	.1905	.1715	.1334	.1905	.0953	.1524	.1143
10		.1334	.1334	.1524	.0953	.1143	.1143
11	.1905	.1143	.1334	.1524	.1143	.0953	.1143
12	.1524	.0953	.1334	.1524	.1143	.0953	.1143
13	.1143	.0953	.1143	.1524	.1143	.0953	.1143
14	.1143	.0953	.0953	.1524	.1143	.0953	.1143
15	.0953	.0953	.0953	.1524	.1143	.0953	.1143
16	.0953	.0953		.1524	.0953	.1143	.1143
17	.1143	.0953	.1143	.1524	.1143	.1143	.1143
18	.1524	.1143	.1334	.1524	.1143	.1143	.1524
19	.2286	.1524	.1334	.1905	.1524	.2286	.1905
20	.2477	.1524	.2477	.1905	.2286	.2286	.1905
21	.2477	.1524	.2477	.1334	.1905	.1905	.1905
22	.1905	.1143	.1905	.1143	.1524	.1143	.1524
23	.1715	.0953	.1334	.0953	.1143	.0762	.0762
24	.0762	.0953	.0762	.0762	.0762	.0762	.0762
Max	.2477	.2286	.2477	.2286	.2286	.2286	.381
Min	.0762	.0953	.0762	.0762	.0762	.0762	.0762
Avg	.1464	.1243	.1309	.1413	.1191	.1254	.1365

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038]

BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan

GAOTHAN FEEDER

Feed Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1905	.1905	.1905	.1905	.1905	.1524
2	.1905	.1905	.1905	.1905	.1905	.1715	.1524
3	.2286	.1905	.2667	.1905	.2477	.1715	.1524
4	.2286	.1905	.3429	.2286	.2477	.1905	.1524
5	.3048	.3429	.4191	.3429	.4191	.2667	.1905
6	.4954	.381	.4954	.4191	.4954	.3429	.4191
7	.5335	.4572	.5335	.4572	.5144	.5335	.4954
8		.4191	.4954	.4191	.4954	.4572	.4191
9	.4954	.3429	.4382	.3429	.4382	.4191	.381
10		.3429	.3048	.3429	.381	.381	.381
11	.3048	.3048	.2477	.3429	.3429		.381
12	.2286	.2858	.2286	.3429	.3429	.3048	.3429
13	.1905	.2858	.2286	.3429	.3429	.3048	.3429
14	.1905	.2858	.1905	.3429	.3429	.3048	.3429
15	.1905	.3048	.1905	.3429	.3048	.3048	.3429
16	.1905	.3048	.1905	.3429	.2667	.381	.3429
17	.2286	.3048	.2286	.381	.3048	.381	.3429
18	.3048	.362	.2667	.4191	.4001	.381	.4191
19	.381	.5335	.3429	.4572	.5144	.4954	.4954
20	.4572	.5525	.4572	.4954	.5525	.4954	.4954
21	.4572	.4763	.4572	.4763	.4572	.4191	
22	.381	.3239	.3429	.362	.3429	.3048	.3429
23	.3048	.2477	.2667	.2477	.2286	.1905	.3048
24	.1905	.1905	.1905	.1905	.1905	.1905	.1905
Max	.5335	.5525	.5335	.4954	.5525	.5335	.4954
Min	.1905	.1905	.1905	.1905	.1905	.1715	.1524
Avg	.3031	.3255	.3128	.3421	.3564	.3297	.3297



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 208 / 11 kv ARALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.0381	.0381	.0381	.0381	.0381	.0381
2	.0381	.0381	.0381	.0381	.0381	.0381	.0381
3	.0381	.0381	.0381	.0381	.0381	.0381	.0381
4	.0381	.0381	.0572	.0381	.0572	.0572	.0381
5	.0572	.0572	.0762	.0762	.0953	.0762	.0762
6	.1143	.0953	.1143	.0953	.1143	.0953	.0953
7	.1524	.1143	.1334	.1143	.1334	.1334	.1334
8		.0953		.0953	.0953	.1334	
9	.1143	.0762	.0762	.0762	.0953	.0953	.0762
10	.0953	.0762	.0762	.0953	.0572	.0762	.0762
11	.0762	.0762	.0572	.0953	.0572	.0762	.0762
12	.0762	.0762	.0572	.0953	.0572	.0762	.0762
13	.0572	.0762	.0572	.0953	.0572	.0762	.0762
14	.0572	.0572	.0572	.0953	.0572	.0381	.0762
15	.0572	.0572	.0572	.0953	.0572	.0381	.0572
16	.0572	.0762	.0572	.0953	.0572	.0572	.0762
17	.0762	.0953		.0953	.0762		.0762
18	.0762	.1143	.0572	.0953	.0762	.1334	.0953
19	.0953	.1524	.0762	.1334	.1143	.1715	.1715
20	.1143	.1334	.1334	.1334	.1524	.1715	.1524
21	.1143	.1524	.1334	.1334	.1334	.1334	.1143
22	.0953		.0953	.0953	.0762	.0953	.0953
23	.0762	.0572	.0572	.0381	.0762	.0762	.0572
24	.0572	.0572	.0381	.0381	.0381	.0572	.0381
Max	.1524	.1524	.1334	.1334	.1524	.1715	.1715
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.0770	.0804	.0719	.0850	.0770	.0862	.0804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 201 / 11 Kv Bachani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.0631	.8916	1.1694	.0492	.0514	.0377
2	.0514	1.0288	.7716	1.1317	.0497	.0514	.0366
3	.0514	1.046	.7545	1.1317	.0492	.0514	.0514
4	.0549	1.0117	.7545	1.0608	.0497	.0514	.0566
5	.055	.9259	.8573	1.094	.0492	.0514	.0549
6	.0566	1.0117	.9602	1.1128	.0492	.0514	.0549
7	.0549	1.0974	1.0288	1.134	.0497	.0514	.0549
8	2.2822	.0572		.0549	1.8564	1.7833	2.1948
9	2.1262	.0377	.0663	.0572	2.4331	2.0719	2.0748
10	2.2291	.0366	.0655	.0572	2.3045	2.0645	1.3946
11		.0366	.0663	.0572	2.3388	1.9227	2.2291
12	1.989	.0377	.0663	.0572	2.1948	1.8023	2.0576
13	2.0233	.0377	.0663	.0572	2.0119	1.6741	1.7833
14	1.9547	.0549	.0655	.0572	1.9387	1.6549	1.7147
15	1.7833	.0549	.0663	.0572	1.9993	1.5581	1.5775
16	.0686	.0732	.0663	.0572	.0549	.0497	.0514
17	.0686	.0686	.0914	.0492	.0514	.0754	.0492
18	.0686	.0686	.0914	.0655	.0514	.0754	.0497
19	.0686	.0686	.0732	.0663	.0514	.0549	.0497
20	.0686	.0686	.0754	.0663	.0514	.0549	.0497
21	.0762	.0686	.0724	.0663	.0514	.0549	.0492
22	.5611		1.4523	.0663	.0514	.0549	.0332
23	.5792	1.1145	1.267	.0497	.0514		.0332
24	.0514	1.0631	1.0631	1.134	.0497		.0377
Max	2.2822	1.1145	1.4523	1.1694	2.4331	2.0719	2.2291
Min	.0514	.0366	.0655	.0492	.0492	.0497	.0332
Avg	.7119	.4405	.4667	.4129	.7453	.6960	.6574

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 202 / 11 Kv Nandgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	.0762	.0857	.128	1.3599		2.1948
2	1.6461	.0762	.0857	.128	1.3916		
3	1.6827	.0762	.1029	.132	1.3592		
4	1.6461	.0953	.12	.128			2.0119
5	1.6461	.0953	.1372	.1463	1.3757		1.9022
6	1.6095	.0953	.1372	.1463	1.4255		1.9239
7	1.6461	.1143	.1372		1.4586		1.9022
8	.1463	2.7435	2.7435		.0497		.1509
9	.1372		2.7854	2.7778	.1097		.1372
10	.1372	3.4385	2.7515	2.8978	.1097		.1372
11	.0857	3.2922	2.7846	2.7263	.1097		.12
12	.0857	3.1824	2.6543	2.6578	.1097		.12
13	.0857	2.9264	2.5194	2.5892	.1132	.0497	.1372
14	.1372	2.6749	2.4413		.0857	.0492	.12
15	.1372	2.7435	2.2542	2.2291	.0914	.0332	.0857
16	.1372	.1463	.1492		.0566	.1326	.0857
17	.1372	.1372	.1829	.116	.0686	.1829	.0983
18	.12	.1372	.1886	.0983	.1029	.1886	.0995
19	.12	.1372	.1698	.0983	.1029	.1463	.0995
20	.1334	.1372	.1463	.0995	.1029		.0995
21	.1334	.1372	.1463	.0995	.1029	.1463	.1147
22	.1143			.5636		2.3011	1.8023
23	.0953	.12	.1509	1.3748			1.8067
24	1.6827	.0953	.0857	.128	1.4089		2.268
Max	1.6827	3.4385	2.7854	2.8978	1.4586	2.3011	2.268
Min	.0857	.0762	.0857	.0983	.0497	.0332	.0857
Avg	.6312	1.0308	.9983	.9632	.5283	.3589	.7917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 203 / 11 kv Ispurli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	.1905	.1715	.1829	1.4413	1.4403	1.7918
2	1.39	.1715	.1715	.1698	1.3927	1.3375	1.7375
3	1.39	.1905	.1715	.1698	1.3765	1.3032	1.7193
4	1.4712	.2096	.1886	.1829	1.3108	1.3717	1.7193
5	1.4632	.2096	.2058	.2012	1.2793	1.5432	1.6461
6	1.5089	.2096	.2058	.2172	1.278	1.5775	1.7353
7	1.6827	.2858	.2058	.2926	1.6356	1.8176	1.8861
8		2.9321	2.4006	2.5514	.1781	.2572	.2829
9	.0686		2.753	2.8978	.2263	.2591	.2743
10	.12	3.3836	2.3967	2.332	.2241	.2267	.2401
11	.2401	3.5117	2.7035	2.8121	.2277	.2267	.2058
12	.2401	3.2922	2.5263	2.572	.2195	.2267	.2058
13	.2229	3.1642	2.5425	2.5377	.2012	.2294	.2058
14	.2058	2.8532	2.2672		.1829	.2294	.2058
15	.1715	2.7435	2.251	1.989	.1886	.2321	.1715
16	.1715	2.1948	.1619		.1829	.2105	
17	.2058		.2012	.2105	.1715	.2561	.1943
18	.1715	.2058	.2195	.1943	.2058	.2561	.2267
19	.2058	.2401	.2195	.2267	.2229	.2829	.2267
20	.2058	.2401	.2561	.2429	.2401	.2378	.2267
21	.2286	.2229	.2378	.2267	.2058	.2452	.1943
22	.2096		.2195	1.6194	1.9376	2.1948	1.9757
23	.1905	.1372	.2012	1.7004	1.8347		1.668
24	1.3717	.1905	.1715	.2012	1.6518	1.7147	1.6461
Max	1.6827	3.5117	2.753	2.8978	1.9376	2.1948	1.9757
Min	.0686	.1372	.1619	.1698	.1715	.2105	.1715
Avg	.6351	1.2752	.9604	1.0787	.7507	.7685	.8863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038]

BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 204 / 11 Kv Bachani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3429	.2915	.3584	.3429	.2915	.2926
2	.3109	.3239	.2915	.3395	.3429	.2743	.2926
3	.3584	.362	.3429	.3475	.3239	.3258	.3395
4	.3841	.381	.4115	.439	.362	.4115	.4252
5	.4527	.381	.4801	.4904	.4382	.5144	.5304
6	.5281	.4287	.6001	.5493	.6097	.6173	.6401
7	.6602	.6173	.6001	.6401	.6859	.6344	.695
8	.6036	.5973	.5316	.6401	.6478	.583	.6401
9	.5144	.5487	.5716	.5611	.5281	.5335	.5487
10	.4801	.4572	.4572	.4887	.3772	.4191	.4287
11		.4755	.4572	.4525	.439	.381	.3944
12	.3772	.3961	.4191	.4163	.3658	.381	.3772
13	.2915	.3658	.4191	.362	.3658	.3239	.3086
14	.3429	.3801	.381	.3258	.3658	.3239	.3086
15	.3429	.4024	.381	.3982	.3772	.381	.3772
16	.3772	.4715	.4572	.4706	.3772	.4191	.4115
17	.4115	.4458	.439	.4763	.3772	.5121	.4763
18	.4458	.463	.4755	.4954	.463	.5093	.4572
19	.4801	.6687	.6602	.6859	.583	.6979	.6478
20	.6516	.6687	.7316	.6859	.6173	.7545	.724
21	.6154	.583	.6401	.6478	.583	.6401	.6478
22	.5068		.5304	.4954	.4801	.5304	.4572
23	.362	.3772	.4554	.4001	.3429		.381
24	.3584	.3429	.3086	.4706	.362	.3086	.2926
Max	.6602	.6687	.7316	.6859	.6859	.7545	.724
Min	.2915	.3239	.2915	.3258	.3239	.2743	.2926
Avg	.4428	.4557	.4722	.4849	.4482	.4682	.4623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 205 / 11 kv ispurli Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3395	.3258	.3086	.3658	.381	.3086	.3584
2	.3292	.3086	.3086	.3475	.362	.2743	.3475
3	.3584	.3086	.3429	.3475	.362	.3086	.3841
4	.4572	.3429	.4115	.4115	.4191	.3772	.4755
5	.5304	.3601	.5144	.5121	.4763	.583	.5487
6	.6036	.4973	.6859	.6584	.6097	.703	.695
7	.7545	.7202	.6859	.7316	.7049	.7202	.7682
8	.7499	.6516	.6173	.6697	.6668	.6173	.7356
9	.6173		.6287	.6516	.5121		.6173
10	.5144	.547	.6287	.5068	.4755		.5487
11	.4801	.5281	.5716	.4706	.439		.5144
12	.4458	.4755	.5335	.4887	.4024		.4801
13	.3772	.439	.5335	.4344	.4527	.5335	.4458
14	.3429	.4904	.5144		.3658	.4191	.4458
15	.3944	.5121	.4763	.4525	.3658	.381	.3944
16	.4287	.5121	.5335		.4572	.5525	.4287
17	.5144	.5487	.5658	.6859	.4458	.5304	.6668
18	.5487	.583	.6219	.7049	.5144	.5304	.6478
19	.7716	.7545	.8048	.8002	.6859	.7499	.8573
20	.823	.823	.9054	.9717	.7716	.9054	.8954
21	.6859	.7202		.8192	.7202	.8048	.8383
22	.5792			.724	.6173	.6767	.6478
23	.3982	.4115	.4938	.4572	.3944		.4572
24	.3772	.3258	.3429	.3841	.4191	.3601	.3658
Max	.823	.823	.9054	.9717	.7716	.9054	.8954
Min	.3292	.3086	.3086	.3475	.362	.2743	.3475
Avg	.5176	.5085	.5468	.5725	.5009	.544	.5652

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 206 / 11 KV Renuka &amp; Hanuman

PURELY LIS FEEDERS

Express Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.3658	.1334	.2058	.1646	.3772	.4024
4	.3772	.1715	.1372	.1543	.3772	.4024
5	.3841	.1905	.2058	.1829	.3772	.415
6	.4338	.1905	.2058	.1715	.3772	.4024
7	.4024	.3982	.3429	.3841	.3772	.4024
8	.4024	.3982	.4287	.3841	.3772	.4024
9	.3772	.4572	.4763	.3982	.4191	.3772
10	.3772	.4572	.4954	.3982	.4191	.3772
11		.4572	.4954	.3982	.4191	.3772
12	.3772	.4715	.4954	.3982	.2286	.3772
13	.3772	.4572	.4763	.3982	.4001	.3601
14	.3772	.4904	.4763	.3982	.4001	.3429
15	.3772	.4949	.4763	.3801	.4001	.4287
16	.3772	.4755	.4763	.3801	.4001	.4287
17	.4287	.4458	.4572	.4191	.3841	.4763
18	.0686	.4458	.4715	.4191	.3821	.4763
19			.4572			
Max	.4338	.4949	.4954	.4191	.4191	.4763
Min	.0686	.1334	.1372	.1543	.2286	.3429
Avg	.3669	.3834	.3988	.3393	.3822	.4031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 207 / 11 KV Kawane Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.5316	.4801	.6173	.0164	.0171	.0171
2	.0171	.4973	.4115	.6584	.0164	.0171	.0183
3	.0171	.4973	.4115	.6413	.0164	.0171	.0183
4	.0114		.4115	.6219	.0166	.0171	.0171
5	.0171	.4287	.4287	.5853	.0166	.0171	.0189
6	.0171	.5144	.4458	.5658	.0166	.0171	.0171
7	.0183	.5316	.5144	.5853	.0164	.0171	.0183
8	1.3169	.0191	.0171	.0183	1.1105	1.2346	1.3169
9	1.2689	.0183	.0166	.0191	1.5123	1.2431	1.3032
10	.8745	.0171	.0166	.0191	1.4712	1.1768	1.286
11	1.3032	.0171	.0166	.0191	1.39	1.1105	1.2346
12	1.3375	.0171	.0166	.0191	1.3717	.7459	1.2003
13	1.2346	.0171		.0191	1.3169	.7625	1.0974
14	1.2003	.0189	.0166		1.2803	.9831	1.0288
15	1.0974	.0189	.0166	.0191	1.3203	.8288	.7545
16	.0171	.0189	.0166	.0191	.0183	.0166	.0171
17	.0171	.0171	.0183	.0166	.0171	.0189	.0166
18	.0171	.0171	.0189	.0166	.0171	.0177	.0166
19	.0171	.0171	.0183	.0166	.0171	.0189	.0164
20	.0171	.0171	.0183	.0166	.0171	.0183	.0164
21	.0191	.0171	.0183	.0166	.0171	.0171	.0164
22			.7133	.0166	.0171	.0189	.0166
23	.5611	.583	.7095	.0166	.0171		.0166
24	.0171	.5316	.5487	.7211	.0166	.0171	.0171
Max	1.3375	.583	.7133	.7211	1.5123	1.2431	1.3169
Min	.0114	.0171	.0166	.0166	.0164	.0166	.0164
Avg	.4535	.1983	.2305	.2289	.4601	.3630	.3957



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2126	.2614	.2378	.2263	.2452	.2534
2	.2427	.2172	.2829	.2378	.2263	.2641	.2561
3	.2195	.2195	.2614	.2402	.2263	.2427	.2534
4	.2126	.2126	.2829	.2378	.2263	.2641	.2534
5	.2896	.3658	.415	.2743	.3361	.3361	.2926
6	.3544	.4024	.5041	.5304	.5041	.5041	.5249
7	.4961	.439	.5487	.4887	.5175	.5415	.5068
8	.3898	.4557	.4938	.4344	.4668	.5041	.439
9	.439	.3772	.4938	.4525	.4668	.4938	.4887
10	.4755	.543	.4887	.5304	.3898	.4706	.5487
11	.4755	.4298	.5973	.4938	.3429	.5792	.543
12	.4755	.4656	.5373	.4784	.3506	.4344	.4938
13	.3544	.3366	.394	.4207	.3086	.3801	.3841
14	.3189	.3077	.3801	.3721	.2743	.3582	.3292
15	.4252	.3761	.4119	.3898	.3086	.362	.439
16	.4755	.4382	.5014		.3544	.4887	.5121
17	.4961	.4031	.6154	.5493	.4024	.4755	.4961
18	.4115	.4938	.4835	.3921	.3841	.4755	.5487
19	.5487	.4938	.6401	.5601	.6283	.5853	.6219
20	.4961	.5853	.5792	.5975	.567	.5611	.5853
21	.5121	.567	.5601	.5601	.5729	.5487	.5487
22	.4252	.499	.4668	.5041	.4481	.4938	.4755
23	.2561	.3961	.3109		.3584	.3174	.4024
24	.2743	.2195	.2641	.2561	.2641	.2641	.2743
Max	.5487	.5853	.6401	.5975	.6283	.5853	.6219
Min	.2126	.2126	.2614	.2378	.2263	.2427	.2534
Avg	.3884	.3940	.4490	.4199	.3813	.4246	.4363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 202 / 11 KV RASHIWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.0631	1.153	1.0174	.0297	.0354	.052
2	.0514	.9945	1.1361	.9835	.0297	.0372	.052
3	.0514	.9945	1.1361	.9835	.0274	.0354	.052
4	.0514	.9602	1.1191	.9835	.0263	.0372	.0514
5	.0514	.9602	1.0852	.9835	.0314	.0372	.052
6	.0514	1.0288	1.0682	.9835	.032	.0372	.052
7	.0514	1.0288	1.0852	.9156	.032	.0354	.052
8	2.4006	.0343	.0372	.0509		1.9839	2.1365
9	2.572	.0343	.0372	.0339	.3429	2.1874	2.5434
10	2.4352	.0572	.0339	.0372	1.989	1.989	2.713
11		.0566	.0347	1.1145	2.0919	2.1879	2.5943
12	2.5484	.0566	.0509	.0229	2.0919	2.0553	2.323
13	2.4806	.0566	.0509	.0372	2.0233	2.0687	2.4417
14	2.2786	.0326	.0339	.0372	1.9204	1.9227	2.4006
15	1.989	.0332	.0509	.0343	1.8519	1.7901	2.2721
16	.0343	.0171	.0509	.0229	.0343	.052	.0354
17	.0354	.024	.0509	.0229	.0366	.0509	.0354
18	.0343	.0248	.0339	.0202	.0372	.0509	.0532
19	.0366	.0372	.0339	.0198	.0372	.0509	.0343
20	.0514	.036	.0509	.0202	.0354	.0509	.0514
21	.0514	.0372	.0339	.0198	.0354	.0509	.0532
22	1.3717	1.4922	1.2209	.0263	.0354	.0509	
23	1.2071	1.4243	1.1869	.0263	.0354	.0509	.0514
24	.0514	1.166	1.153	1.1191	.0263	.0372	.0509
Max	2.572	1.4922	1.2209	1.1191	2.0919	2.1879	2.713
Min	.0343	.0171	.0339	.0198	.0263	.0354	.0343
Avg	.8669	.4854	.4970	.3965	.5580	.7036	.8762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 203 / 11 KV KOULAV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.0343	.0377	.0347	1.1736	1.4243	1.4413
2	1.0974	.0343	.0373	.0347	1.1736	1.4243	1.3757
3	1.0974	.0343	.0377	.0347	1.1869	1.3889	1.3904
4	1.1317	.0343	.0373	.0347		1.3735	1.3717
5	1.1317	.0343	.0373	.0347	1.1736	1.3735	1.3565
6	1.1317	.0351	.0373	.0347	1.1736	1.3565	1.2266
7	1.1317	.0343	.0377	.0347	1.2071	1.3735	1.2717
8	.0343	2.2291	2.1534	2.0056	.0191	.056	.0347
9	.0343	2.2634	2.4926	2.2211	.0381	.056	.0347
10	.0354	2.3205	2.3205	2.4078	.0354	.0526	.056
11		2.4863	2.2024	2.5549	.0343	.0526	.056
12	.0343	2.42	2.3205	2.5943	.0343	.0526	.056
13	.0354	2.4034	2.2211	2.4247	.0343	.052	.056
14	.0343	2.3205	2.0719	2.2891	.0343	.052	.056
15	.0343	2.2211	1.9227	2.1874	.0343	.052	.056
16	.0343	.0381	.0173	.0373	.0343	.0347	.056
17	.0343	.0377	.0173	.0373	.0366	.0347	.0373
18	.0343	.0373	.0173	.0381	.0373	.0347	.0354
19		.056	.0173	.0381	.056	.0347	.0354
20	.0514	.056	.0347	.0377	.0373	.0347	.0354
21	.0514	.056	.0347	.0377	.0373	.0347	.0354
22	.0343	.0373	.0347	1.4922	1.7465	1.4922	1.5775
23	.0343	.0373	.0347	1.3565	1.6787	1.5939	1.5432
24	1.1317	.0343	.0377	.0347	1.1869	1.4243	1.5261
Max	1.1317	2.4863	2.4926	2.5943	1.7465	1.5939	1.5775
Min	.0343	.0343	.0173	.0347	.0191	.0347	.0347
Avg	.4303	.8040	.7589	.9182	.5306	.6191	.6134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 204 / 11 KV NAGESHWAR GAVTHAN

GAOTHAN FEEDER

VG FD Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0886	.1086	.0943	.0943	.1132	.0943	.0943
2	.0886	.0914	.0943	.0943	.0943	.0934	.0943
3	.0914	.0914	.0747	.0943	.0943	.0943	.0943
4	.0886	.0914	.0747	.0943	.0943	.0934	.0943
5	.1063	.0905	.112	.1132	.1132	.112	.1132
6	.124	.1463	.1494	.1698	.132	.1509	.1509
7	.1772	.1991	.2012	.1829	.1867	.2054	.1886
8	.1595	.1928	.1949	.1867	.1886	.1867	.1867
9	.1417	.1578	.1595	.1829	.1886	.1494	.1494
10	.1463	.1402	.1254	.1629	.1417	.1543	.1463
11	.128	.1402	.1402	.1646	.12	.12	.128
12	.128	.1227	.1227	.1417	.1227	.12	.1417
13	.1227	.1578	.1254	.124	.1063	.1052	.128
14	.1052	.1227	.1433	.1063	.1097	.1227	.124
15	.12	.1254	.1433	.124	.1029	.1433	.124
16	.1715	.156	.1402	.1402	.1029	.1402	.1463
17	.1829	.156	.1578	.1772	.0914	.1791	.1772
18	.2195	.1772	.1886	.1578	.128	.1791	.2012
19	.298	.2303	.2561	.2743	.2241	.2378	.2835
20	.2835	.3045	.2987	.2957	.2241	.2801	.2743
21	.2229	.2772	.2452	.2587	.2241	.2427	.2303
22	.2058	.2427	.2263	.2075	.1886	.2054	.2229
23	.1646	.1698	.1509	.1509	.132	.132	
24	.1063	.1097	.0943	.1132	.1132	.0943	.0943
Max	.298	.3045	.2987	.2957	.2241	.2801	.2835
Min	.0886	.0905	.0747	.0943	.0914	.0934	.0943
Avg	.1530	.1584	.1547	.1588	.1390	.1515	.156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 205 / SHAHU LIS

Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	22-FEB-18
HR	Load (MW)
7	.1646
Max	.1646
Min	.1646
Avg	.1646

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 201 / 11 Kv Wakare Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4973	.0168	.0168	.0168	.57	.1989	.3353
2	.503	.0168	.0168	.0168	.57	.1638	.3018
3	.503	.0168	.0168	.0168	.57	.1658	.2683
4	.4694	.0168	.0168	.0168	.57	.1658	.2683
5	.4694	.0168	.0168	.0168	.6036	.1989	.3018
6	.4694	.0168	.0166	.0168	.6036	.2458	.3353
7	.4694	.0168	.0168	.0168	.57	.2984	.3688
8	.0168	.8718	.9054	.8718	.0168	.0168	.0168
9	.0168	1.0395	1.0059	.9389	.0168	.0166	.0168
10	.0162	1.0059	1.0277	.9556	.0168	.0168	.0168
11	.0164	1.0059	1.0059	.9054	.0168	.0168	.0168
12	.0166	1.0395	.9282	.8718		.0166	.0168
13	.0168	1.0059	.9389	.8718	.0168	.0168	.0168
14	.0017	.9724	.8718	.8383	.0168		.0168
15	.0166	.7712	.7377	.7712	.0168		.0168
16	.0168		.0168	.0168	.0168	.0168	.0168
17	.0168	.0168	.0168	.0168	.0166	.0168	.0168
18	.0168	.0166	.0168	.0168	.0166	.0168	.0168
19	.0168	.0168	.0168	.0168	.0164	.0168	.0168
20	.0168	.0168	.0168	.0168	.0168	.0168	.0168
21	.0168	.0168	.0168	.0168	.0166	.0168	.0168
22	.0168	.0168	.0168	.6371	.2652	.4359	.6036
23	.0168	.0168	.0168	.57	.2347	.4024	.6036
24	.5365	.0168	.0168	.0168	.57	.1677	.3353
Max	.5365	1.0395	1.0277	.9556	.6036	.4359	.6036
Min	.0017	.0166	.0166	.0168	.0164	.0166	.0168
Avg	.1737	.3463	.3204	.3528	.2324	.1202	.1649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 202 / 11 Kv Mahe Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2195	.2126	.2172	.2126	.1772	.1417	.1829
2	.2195	.2126	.2172	.2126	.1772	.1063	.1595
3	.2195	.2126	.2172	.2126	.1772	.1063	.1595
4	.2926	.2303	.2534	.2126	.2126	.1075	.1595
5	.439	.2835	.2896	.2481	.2481	.1772	.2126
6	.4755	.4607	.4344	.4252	.4252	.4298	.3544
7	.4755	.4607	.4706	.3898	.4252	.4607	.4252
8	.439	.443	.4344	.4607	.4252	.4607	.3898
9	.3898	.3898	.3898	.3898	.3898	.4252	.3898
10	.3898	.4607	.4252	.3898	.3544	.3982	.4252
11	.3898	.4252	.4656	.4252	.2835	.4344	.3898
12	.3898	.4252	.4252	.3898		.3982	.3898
13		.3898	.4252	.3898	.2126	.362	.3544
14		.2835	.3189	.3544	.2126	.362	.3544
15		.3544	.3898	.3898	.2481	.362	.3189
16		.3544	.3544	.3898	.2835	.3898	.3544
17	.4961	.4252	.3544	.3898		.3898	.3982
18	.4961	.4252	.3544	.4252	.3898	.439	.3315
19	.6024	.5316	.5121	.5316	.4961	.5316	.5068
20	.567	.5316	.567	.5316	.5014	.567	.5068
21	.5316	.5068	.5316	.4784	.4961	.4607	.4344
22	.4252	.362	.3898	.3366	.3544	.3898	.2896
23	.2481	.2896	.2561	.1772	.2126	.2481	.2172
24	.2172	.2126	.2172	.2126	.1772	.1772	.1772
Max	.6024	.5316	.567	.5316	.5014	.567	.5068
Min	.2172	.2126	.2172	.1772	.1772	.1063	.1595
Avg	.3962	.3702	.3713	.3573	.3127	.3469	.3284

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 203 / 11 Kv Bahireshwar Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1097	.1063	.1063	.0716	.0716	.0716	.0732
2	.1097	.1063	.1063	.0709	.0716	.0716	.0732
3	.1097	.1063	.1063	.0716	.0709	.0716	.0732
4	.1097	.1063	.1063	.0716	.0716	.0716	.0747
5	.1463	.1417	.1417	.1075	.1075	.1075	.112
6	.2195	.2126	.1772	.1791	.1791	.2149	.1867
7	.1829	.2195	.2126	.1772	.1791	.2149	.1867
8	.1829	.2126	.1772	.1772	.1612	.1791	.1829
9	.1463	.1595	.1772	.1791	.1612		.1463
10	.181		.1829	.1791	.1791	.1791	.1372
11	.1791	.1772	.1772	.1791	.1433	.1791	.1715
12	.1829	.1063	.1772	.1791		.1791	.1715
13	.181	.1063	.1772	.1791	.1433	.1791	.208
14	.1772	.1063	.1772	.1791	.1075	.1772	.1734
15	.1463	.1772	.1772	.1433	.1075	.1772	.1402
16	.1772	.1772	.1772	.1433	.1075	.1772	.1578
17	.1417	.2126	.1417	.1433	.1433	.1417	.1829
18		.1772	.1417	.1791	.1791	.1433	.181
19	.2835	.1772	.1772	.2149	.2149	.1791	.2172
20	.2481	.2126	.2126	.2149	.2172	.2195	.2195
21	.2481	.2126	.1772	.2149	.1791	.1829	.2172
22	.2126	.1772	.1417	.1791	.1075	.1463	.181
23	.1063	.1417	.1097	.1075	.1075	.1097	.1097
24	.1097	.1063	.1063	.0709	.0716	.0716	.0732
Max	.2835	.2195	.2126	.2149	.2172	.2195	.2195
Min	.1063	.1063	.1063	.0709	.0709	.0716	.0732
Avg	.1692	.1582	.1569	.1505	.1340	.1498	.1521



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 204 / 11 Kv Sangrul Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0166	.5636	.5967	.4641	.0166	.0164	.0166
2	.0166	.5304	.5304	.4641	.0166	.0166	.0166
3	.0166	.5304	.5304	.4641	.0166	.0164	.0166
4	.0166	.5138	.5365	.4641	.0166	.0164	.0166
5	.0166	.5138	.5304	.4973	.0166	.0164	.0166
6	.0166	.5138	.5304	.4973	.0166	.0164	.0166
7	.0166	.5138	.5304	.5304	.0166	.0164	.0166
8	1.1934	.0166	.0166	.0166	1.2266	1.1934	1.1934
9	1.4752	.0166	.0166	.0166	1.2266	1.4582	1.4918
10			.0164	.0166	1.3923	1.3923	1.442
11	1.2929	.0166	.0164	.0166	1.2929	1.1934	1.326
12	1.3108	.0166	.0164	.0166		1.2929	1.1603
13	1.2929	.0166	.0164	.0166	1.1271	1.2929	1.1603
14	1.1934	.0166	.0166	.0166	1.094	1.2929	1.1934
15	1.0814	.0166	.0164	.0166	1.094	1.094	1.1271
16	.0166	.0164	.0166	.0166	.0166	.0166	.0166
17	.0166	.0166	.0166	.0166	.0166	.0166	.0166
18	.0166	.0164	.0166	.0168	.0164	.0166	.0166
19	.0166	.0164	.0166	.0166	.0166	.0166	.0166
20	.0166	.0164	.0166	.0166	.0164	.0166	.0166
21	.0166	.0166	.0166	.0166	.0166	.0166	.0166
22	.6464	.5967	.6299	.0166	.0164	.0166	.0168
23	.6133	.5967	.5304	.0166	.0164	.0166	.0168
24	.0166	.5801	.5967	.4973	.0166	.0168	.0166
Max	1.4752	.5967	.6299	.5304	1.3923	1.4582	1.4918
Min	.0166	.0164	.0164	.0166	.0164	.0164	.0166
Avg	.4492	.2464	.2406	.1727	.3791	.4364	.4317

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 205 / 11 Kv Mahe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9724	.0189	.0189	.0189	1.0277	1.2407	.8855
2	.8718	.0189	.0189	.0189	.9945	1.1603	.8002
3	.8718	.0189	.0189	.0189	.9614	1.1401	.6562
4	.8048	.0189		.0189	.9282	1.0898	.6874
5	.6706	.0189	.0189	.0189	.9389	1.0442	.7186
6	.8048	.0189	.0189	.0189	.9389	1.0277	.8002
7	.8048	.0189	.0189	.0189	.9389	1.0059	.8421
8	.0168	1.8233	1.989	1.8564	.0168	.0189	.0191
9	.0175	2.4756	2.3472	2.1879	.0189	.0189	.0191
10	.0177	2.4577	2.3137	2.2211	.0189	.0189	.0189
11	.0177	2.42	2.1714	2.2211	.0189	.0189	.0191
12	.0175	2.3537	2.1628	2.0885		.0189	.0191
13		2.1548	2.0222	2.0222	.0189	.0189	.0191
14	.0191	2.0885	1.9062	1.7901	.0189	.0189	.0191
15	.0191	1.9227	1.757	1.5912	.0189	.0189	.0191
16	.0191	.0189	.0189	.0189	.0189	.0189	.0191
17	.0191	.0189	.0189	.0189	.0189	.0191	.0168
18	.0191	.0189	.0189	.0189	.0189	.0191	.0168
19	.0189	.0189	.0189	.0189	.0189	.0191	.0168
20	.0189	.0189	.0189	.0189	.0189	.0191	.0168
21	.0189	.0189	.0189	.0189	.0189	.0191	.0168
22	.0189	.0189	.0189	1.326	1.4251	1.2308	1.2742
23	.0189	.0189	.0189	1.1603	1.291	1.0883	1.2742
24	1.0059	.0189	.0189	.0189	1.0608	1.2574	.9804
Max	1.0059	2.4756	2.3472	2.2211	1.4251	1.2574	1.2742
Min	.0168	.0189	.0189	.0189	.0168	.0189	.0168
Avg	.3080	.7499	.7371	.7804	.4673	.4813	.3823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 206 / 11 Kv bahireshwar Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4946	.0189	.0189	.0189	1.326	1.0774	1.2689
2	.4946	.0189	.0189	.0189	1.326	1.0608	1.166
3	.4946	.0189	.0189	.0189	1.326	1.0442	1.0974
4	.4946	.0189	.0189	.0189	1.2929	1.0277	1.0974
5	.4946	.0189	.0189	.0189	1.2929	1.0277	1.1401
6	.4946	.0189	.0189	.0189	1.2929	1.0608	1.1736
7	.4946	.0189	.0189	.0189	1.326	1.1603	1.2346
8	.0095	1.7238	1.9227	2.0885	.0189	.0189	.0191
9	.008	1.8896	2.1216	2.2542	.0189	.0189	.0191
10	.0078		2.1216	2.1879	.0189	.0189	.0191
11	.0086	2.2211	2.1714	2.1216	.0189	.0189	.0191
12	.0091	2.2211	2.1382	2.0885		.0189	.0191
13			2.0885	1.9559	.0189	.0189	.0191
14	.0189		1.989	1.9227	.0189	.0189	.0191
15	.0189	1.989	1.873	1.8233	.0189	.0189	.0191
16	.0189	.0189	.0189	.0189	.0189	.0189	.0191
17	.0189	.0189	.0189	.0189	.0189	.0183	.0166
18	.0189	.0189	.0189	.0189	.0189	.0187	.0166
19	.0189	.0189	.0189	.0189	.0189	.0187	.0166
20	.0189	.0189	.0189	.0189	.0189	.0187	.0166
21	.0189	.0189	.0189	.0189	.0189	.0187	.0166
22	.0189	.0189	.0189	1.3923	1.21	1.3032	1.0608
23	.0189	.0189	.0189	1.326	1.1603	1.2689	1.0608
24	.5396	.0189	.0189	.0189	1.326	1.1271	1.2689
Max	.5396	2.2211	2.1714	2.2542	1.326	1.3032	1.2689
Min	.0078	.0189	.0189	.0189	.0189	.0183	.0166
Avg	.1841	.4927	.6970	.8094	.5706	.4759	.4926

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 203 / 11 kv khupire Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2058	.1829	.2229	.2058	.1886	.1829
2	.1715	.2058	.2286	.2058	.206	.1886	.1524
3	.1886	.2058	.3048	.2058	.2229	.2058	.1524
4	.1829	.2058	.3048	.2058	.2401	.2058	.2286
5	.2743	.2401	.381	.2572	.3086	.2229	.3048
6	.3429	.3601	.7621	.3429	.3429	.3429	.3353
7	.3601	.4801	.4572	.3944	.3429	.4115	.381
8		.5144	.4572	.4458	.4287	.5658	.381
9		.3944	.4572	.3772	.3772	.5487	.3658
10	.3086	.3772	.4572	.3944	.3429	.463	.3048
11	.3086	.4115	.3772	.381	.3601	.4973	.3048
12	.4973	.4115	.463	.381	.3353	.4458	.3944
13	.4801	.4287	.4458	.3963	.381	.4801	.4115
14	.4801	.4115	.463	.3353	.381	.4458	.3944
15	.4801	.463	.5144	.4115	.3506	.3944	
16	.3944	.4115	.3944	.4572	.3506	.4458	.463
17	.4458	.3601	.463	.463	.3658	.4115	.463
18	.4287	.4572	.4973	.4115	.4458	.4572	.5144
19	.463	.4877	.5658	.4458	.4973	.4877	.6001
20	.4973	.503	.583	.4268	.5658	.4572	.5487
21	.4458	.381	.4973	.4973	.4115	.381	.4801
22	.3772	.3201	.4287	.4287	.3601	.3353	.3258
23	.2743	.2286	.2743	.3258	.2401	.2286	.2058
24	.2058	.2058	.1829	.2229	.2401	.2058	.1829
Max	.4973	.5144	.7621	.4973	.5658	.5658	.6001
Min	.1715	.2058	.1829	.2058	.2058	.1886	.1524
Avg	.3536	.3613	.4226	.3598	.3460	.3757	.3512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040]

BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 204 / 11 Kv Fulewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6859	.5335	.6516	.6516	.6516	.5792
2	.6859	.6859	.6001	.6516	.6344	.6173	.5792
3	.6516	.6516	.5335	.6516	.6859	.6173	.5792
4	.7202	.6516	.6097	.6687	.7202	.6516	.6097
5	.823	.6859	.6859	.9259	.823	.6516	.6097
6	.8916	.8573	.7621	1.0631	.8573	.8573	.6859
7	1.1738	1.1145	.9145	.9259	1.0974	1.0288	.8535
8	1.0974	1.1488	1.0288	1.0974	1.0631	1.1488	.9145
9	.9602	1.0117	.7926	.9774	.9259	1.0117	.9602
10	.7202	.8916	.8573	.8916	.823	.8573	.7621
11	.7202		.9431	.7926	.7202	.7545	.6859
12	.823	.823	.8745	.8573	.3048	.8573	.7545
13	.7716	.7545	.8745	.6859	.381	.823	1.0974
14	.6516	.6516	.7716	.6097	.3048	.7545	.8059
15	.6516	.7545	.7373	.6097	.3048	.7202	.8059
16	.7545	.823	.7888	.6859	.3429	.7545	.8402
17	.8573	.8573	.823	.6859	.3429	.7888	.8745
18	.9259	.8383	.8573	.8916	.3086	.9602	1.1317
19	1.1831	1.0059	1.2346	1.2689	1.3203	1.0669	1.3717
20	1.286	1.2003	1.2346	1.2346	1.3717	1.0974	1.2346
21	1.2689	1.0669	1.2346	1.0974	1.2689	1.0364	1.0974
22	1.166	.9907		1.0288	1.2174	.9145	1.1317
23	.9431	.8535	.9945	.8573	.9431	.8573	.823
24	.7202	.7373	.6859	.6859	.6859	.7373	.6859
Max	1.286	1.2003	1.2346	1.2689	1.3717	1.1488	1.3717
Min	.6097	.6516	.5335	.6097	.3048	.6173	.5792
Avg	.8774	.8583	.8423	.8540	.7541	.8423	.8531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 207 / 11 KV FULEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.3658	.1981	.2286
2					.3658	.1981	.2286
3					.3353	.1981	.2286
4					.3353	.2286	.2439
5					.3658	.2591	.2439
6					.3048	.2439	.2286
7					.1524	.2743	.3048
8	.7621	.8383	.8383	.8688			
9	.8993	.9145	.9145	.945			
10	.9602	.9602	.9145	.9755			
11	.945	.945	.884	.9907			
12	.823	.9145	.8993	.9145			
13	.823	.884	.823	.9145			
14	.7011	.8688	.8078	.9145			
15	.6859	.8078	.7621	.7621			
22				.4115	.2439	.3048	
23				.381	.2591	.2743	
24					.3973	.2286	.2743
Max	.9602	.9602	.9145	.9907	.3973	.3048	.3048
Min	.6859	.8078	.7621	.381	.1524	.1981	.2286
Avg	.8250	.8916	.8554	.8078	.3126	.2408	.2477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 208 / 11KV Padali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.7621	.7621	.945	.0914	.1219	.1219
2	1.0974	.7621	.7621	.945	.0914	.1219	.1219
3	1.2003	.7926	.7621	.945	.1067	.1219	.1219
4	1.0669	.7926	.7621	.9602	.1524	.1219	.1524
5	1.0059	.823	.7621	1.0364	.1524	.1219	.1524
6	.9755	.7926	.9907	1.0822	.1524	.1524	.1524
7	1.0669	.823	.9907	1.0364		.1677	.1829
8	.1219	.1372	.1524	.1524	1.5242	1.829	1.829
9	.1219	.1372	.1219	.1677	1.6461	2.0271	1.9814
10	.1219	.1219	.1524	.1677	1.7071	1.9814	1.9814
11	.1219	.1067	.1219	.1219	1.4632	1.9814	1.829
12	.0914	.1067	.1219	.1524	1.2193	1.6461	1.6613
13	.0914	.1067	.1219	.1219	1.3717	1.7071	1.7071
14	.1219	.0914	.1219	.1219	1.5242	1.6766	1.6156
15	.0914	.1067	.1219	.1219	.1219	1.5242	
16	.3354	.1219	.1372	.1524	.1524	.1524	.1372
17	.1067	.1524	.1677	.1524	.1372	.1524	.1372
18	.1372	.1524	.1677	.1524	.1372	.1829	.1524
19	.1829	.1981	.1677	.1524	.1524	.1829	.1829
20	.1829	.1981	.1829	.1829	.1829	.1524	.1524
21	.1829	.1829	.1829	.1829	.6401	.1829	.1219
22	.9602	.9145	1.0669	.1524	.1829	.1829	1.2498
23	.8383	1.0669	1.0364	.1067	.1372	.1219	1.2193
24	1.1279	.7926	.9145	.9602	.1067	.1219	.1219
Max	1.2003	1.0669	1.0669	1.0822	1.7071	2.0271	1.9814
Min	.0914	.0914	.1219	.1067	.0914	.1219	.1219
Avg	.5187	.4268	.4522	.4280	.5719	.6973	.7429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 209 / 11KV Khupire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9509	1.5242	1.3717	1.3717	1.3108	1.0974	.9145
2	1.829	1.5242	1.2193	1.3717	1.3108	1.0669	.7621
3	1.8595	1.4937	1.2193	1.3565	1.2803	1.0974	.7621
4	1.8595	1.4937	1.2193	1.3413	1.2498	1.0974	.9145
5	1.829	1.4784	1.2955	1.3413	1.2498	1.0974	.9145
6	1.829	1.6156	1.3717	1.3413	1.2803	1.1126	.9907
7	1.89	1.7833	1.5242	1.4632	1.4022	1.3565	.9907
8	2.1338		2.2862	2.5606	3.0483	3.0178	3.3436
9	2.7435		2.5149	2.9416	3.3532	3.5361	3.858
10	2.8349		2.7435	1.89	3.7037	3.5361	3.3532
11	2.8197		2.2253	2.4387	3.3532	3.4141	3.0483
12	2.4387	2.8045	2.2253	2.5149	3.0483	3.3532	1.8595
13	2.4387	2.774	2.5758	2.4387	3.0483	3.2922	2.9264
14	2.4387	2.7435	2.4996	2.6578	3.2007	3.0483	2.9264
15	2.0729	.6706	2.3167	1.7071	2.7435	2.6825	2.6368
16	.0305	1.9509	.0152	.0305	.0305	.0305	
17	.0305	1.829	.0152		.0305	.0305	.0152
18	.0152	.0305	.0152	.0305	.0152	.0305	.0305
19	.0152	.0343	.0152	.0305	.0152	.0305	.0305
20	.0152	.0305	.0152	.0305	.0152	.0305	.0305
21	.0152	.0305	.0152	.0305	.0152	.0305	.0305
22	1.9204	2.1338	1.829	1.4632	1.6004	1.3717	1.829
23	1.9204	1.829	1.5242	1.3717	1.4327	1.2193	1.7071
24	1.9814	1.7223	1.6766	1.3717	1.3413	1.1888	1.2193
Max	2.8349	2.8045	2.7435	2.9416	3.7037	3.5361	3.858
Min	.0152	.0305	.0152	.0305	.0152	.0305	.0152
Avg	1.6213	1.4748	1.4054	1.4389	1.6283	1.5737	1.5258



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 210 / 11 Kv kuditre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.4115	.3048	.4458	.3772	.3601	
2	.3429	.4115	.3048	.4287	.3772	.3601	
3	.3601	.4115	.3048	.4287	.4115	.3601	.381
4	.4115	.4287	.4572	.4458	.4801	.3772	.5144
5	.6173	.4801	.5335	.5487	.583	.4458	.4572
6	.6859	.6344	.6097	.6859	.6516	.6516	.6097
7	.7202	.7373	.7716	.6859	.7202	.7545	.6097
8	.6516	.7545	.6859	.6859	.6859	.7373	.5487
9	.6516	.7545	.5487	.6344	.583	.6687	.6097
10	.7545	.7373	.6859	.6516	.5487	.6173	.5487
11	.6859	.4801	.6516	.5944	.5144	.6516	.6173
12	.5144	.6173	.6516	.5944	.4572	.6516	.5144
13	.5316	.583	.6173	.4877	.3048	.6173	.5658
14	.5316	.6173	.5487	.4877	.3048	.583	.5658
15	.4801	.5144	.5658		.3048	.5144	.583
16	.6173	.6173	.6173	.4877	.3429	.6516	.6516
17	.6173	.7545	.6173		.3429	.6516	.6516
18	.6859	.6097	.6344	.6516	.5487	.6097	.7888
19	.7716	.6097	.8573	.8573	.703	.7621	.8916
20	.8402		.7888	.8916	.7888	.7621	.8916
21	.7545	.6401	.6859	.823	.7373	.6097	.823
22	.6001	.5487	.6516	.7202	.6859	.5487	.6859
23	.4973	.4572	.4973	.5144	.4973	.5144	.4801
24	.3601	.4287	.381	.4458	.4115	.3772	.3772
Max	.8402	.7545	.8573	.8916	.7888	.7621	.8916
Min	.3048	.4115	.3048	.4287	.3048	.3601	.3772
Avg	.5828	.5756	.5822	.5999	.5151	.5766	.6076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 201 / 11 KV SANGRUL VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2263	.2263	.2263	.1886	.2263
2	.2075	.2263	.2263	.2075	.2075	.1886	.2075
3	.1886	.2263	.2263	.1886	.2075	.1886	.2075
4	.1886	.3395	.2452	.1886	.2263	.1886	.2263
5	.3206	.415	.3395	.2641	.3395	.2263	.3018
6	.5601	.5601	.5658	.547	.5415	.4715	.5847
7	.6468	.6348	.6348	.5847	.6099	.5415	.6348
8	.5729	.5601	.5601	.5601		.5041	.5914
9	.5304	.499	.4755	.5359	.4435	.5121	.5121
10	.4835	.4207	.443	.462	.462	.5138	.4572
11	.4252	.394	.3898	.4435	.3982		.4344
12	.4344	.3761	.4784	.4298	.3982	.4382	.4163
13	.3761	.3582	.3982	.4163	.362	.3544	.3982
14	.3761	.3761	.3982	.4344	.2743	.3681	.3982
15		.394	.4119	.4706	.3366	.4119	.4344
16	.4207	.4207	.4656	.4887	.3366	.4075	.5068
17	.4887	.4801	.5375	.5611	.4298	.5548	.5792
18	.6268	.5548	.6201	.6401	.5014	.5258	
19	.823	.7865	.7865	.8029	.7207	.7499	.8775
20	.8402	.8215	.8402	.8865	.7095	.8501	.8402
21	.7922	.7545	.7356	.7733	.6348	.7655	.7922
22	.5658	.5658	.5847	.5281	.415	.5658	.5847
23	.3206	.3206	.3018	.3395	.2641	.3395	.3584
24	.2641	.2452	.2452	.2641	.2452	.2075	.2075
Max	.8402	.8215	.8402	.8865	.7207	.8501	.8775
Min	.1886	.2263	.2263	.1886	.2075	.1886	.2075
Avg	.4643	.4565	.4640	.4685	.4039	.4375	.4686

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 202 / 11 KV KHATANGLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5087	.4915	.5761			
2		.4694	.4534	.583			
3		.4694	.4534	.5735			
4		.4973	.4534	.5668			
5		.5138	.4858	.5992			
6		.5967	.5668	.664			
7		.6796	.5506	.7701			
8	1.3763				1.7404	1.9281	2.0008
9	1.5729				2.2043	2.3137	2.0165
10	1.6766				2.4078	2.323	2.1776
11	1.7604				2.3472	2.079	2.0178
12	1.7101				2.1795	1.873	2.0814
13	1.7072				2.0957	1.9559	1.6108
14	1.6575				1.873	1.757	1.8861
15					1.1961	1.2407	1.6118
22	.6036	.852	.7956				.57
23	.503	.7865	.7701				
24		.4694	.5571	.5898			
Max	1.7604	.852	.7956	.7701	2.4078	2.323	2.1776
Min	.503	.4694	.4534	.5668	1.1961	1.2407	.57
Avg	1.3964	.5843	.5578	.6153	2.0055	1.9338	1.7748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 203 / 11 KV UPWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191				.3391	.0469	.3185
2	.0191				.3391	.0469	.2035
3	.0191				.3391	.0457	.2012
4	.0191				.3521		.2035
5	.0191				.3521		.2204
6	.0191				.3688		.2374
7	.0191				.3521		.2713
8		1.1361	.8139	.7712			
9		1.0774	.7956	.7956			
10		.779	.6299	.7459			
11		.8453	.4807	.6796			
12		.7293	.6226	.6371			
13		.6554	.57	.5935			
14		.4752	.5407	.5426			
15		.407	.4694	.4409			
16						.8402	
17						.823	
22				.3856	.0381	.7373	.57
23				.3688	.0492	.6516	.4973
24	.0191				.3647	.0486	.6274
Max	.0191	1.1361	.8139	.7956	.3688	.8402	.6274
Min	.0191	.407	.4694	.3688	.0381	.0457	.2012
Avg	.0191	.7631	.6154	.5961	.2894	.4050	.3351

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 202 / 11 KV SHENAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	1.1431	.9717	.8383	.0953	.1143	.0191
2	1.7718	1.1622	1.0479	.8383	.0953	.1143	.0191
3	.1143	1.1622	1.0479	.8192	.0953	.1143	.0191
4	.1143	1.1812	1.0288	.8573	.0953	.1143	.0191
5	.1143	1.2193	1.0479	.9526	.0953	.1143	.0191
6	.1143	1.2955	1.1241	1.2003	.1143	.1143	.0191
7	.1143	1.6004	1.5242	1.6004	.1143	.1143	.0191
8	.1143	2.21	1.9433	1.9052	.1143	.1143	.0191
9	.1143	2.1338	1.9052	1.5432	.1143	.1143	.0191
10	.1143	.0953	.0953	.0191	.0953	.1143	.0191
11	2.8197	.0953		.0762	2.8006	3.0483	3.1626
12	2.9721	.0953	.0762	.0191	2.9721	3.1626	
13	2.8959	.0953	.0762	.0953	2.9721		3.5056
14	2.7435	.0762	.0762	.0953	3.0483		3.3341
15	2.5911	.0762	.0953	.0953	2.934	3.3913	3.0864
16	2.7435	.0762	.0953	.0953	2.8769	3.1436	3.2388
17	2.3624	.0762	.0191	.0953	2.8959	3.2388	2.915
18	2.0576	.0762	.0191	.0953	2.4768	2.8197	2.553
19	.0953	.0762	.0953	.1143	.1143	.0191	.1143
20	.0953	.0762	.0953	.0953	.1143	.0191	.1143
21	.0953	.0762	.0953	.0953	.1143	.0191	.1143
22	.0953	.0762	.0953	.0953	.1143	.0191	.1143
23	.0953	.0762	.0953	.0953	.1143	.0191	.1334
24	.1143	1.1431	.9526	.8573	.0953	.1143	.0191
Max	2.9721	2.21	1.9433	1.9052	3.0483	3.3913	3.5056
Min	.0953	.0762	.0191	.0191	.0953	.0191	.0191
Avg	1.0240	.6414	.5923	.5247	1.0280	.9162	.9824

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPALGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4572	.4382	.5144	.4572	.4572	.4572	.5144
2	.4572	.4382	.4954	.4572	.4572	.4572	.4954
3	.4572	.4382	.5335	.4572	.4572	.4572	.4763
4	.4763	.4572	.5335	.4763	.4572	.4572	.4763
5	.5144	.4572	.5335	.4954		.4763	.4763
6	.6097	.6097	.5716	.6097	.5335	.5716	.5716
7	.6859	.7621	.6859	.6287	.6859	.6859	.6859
8	.7621	.7621	.7049	.6668	.743	.8002	.7811
9	.6668	.7621	.6668	.6859	.743	.8002	.8573
10	.6668	.6287	.6097	.6478	.6859	.724	.6668
11	.6859	.6668	.6097	.743	.6478	.6287	.6859
12	.6859	.7049	.6287	.724	.6097	.6859	.724
13	.6478	.6478	.6097	.6478	.6478	.6287	.6097
14	.6478	.6287	.5335	.6097	.6287		.7049
15	.6478	.6859		.6097	.5716	.6287	.6859
16	.7049	.6287	.5716	.5906	.6097	.6859	.724
17	.7621	.6478	.6287	.743	.6287	.7049	.724
18	.7621	.7621	.6287	.724	.6287	.7049	.7621
19	1.1431	.8573	.9907	1.0098	.9717	.7811	1.1431
20	1.1431	.8764	.9907	1.0669	1.105	.8573	1.1241
21	.9907	.8954	.9145	.9335	.9145	.8383	
22	.7621	.8002	.8383	.8002	.8573	.8383	
23	.5716	.6097	.6287	.4954	.5906	.724	
24	.4954	.4954	.5144	.4954	.4954	.4954	.5144
Max	1.1431	.8954	.9907	1.0669	1.105	.8573	1.1431
Min	.4572	.4382	.4954	.4572	.4572	.4572	.4763
Avg	.6835	.6525	.6494	.6573	.6577	.6560	.6859

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 204 / 11 KV MADILAGE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.2286	.2477	.2286	.1905	.1905	.2096
2	.1905	.2096	.1905	.2096	.1905	.1905	.1905
3	.1905	.2096	.1905	.2096	.1905	.1905	.1905
4	.2096	.2286	.2096	.2286	.1905	.2096	.1905
5	.2477	.2667	.2667	.2667	.2286	.2667	.2286
6	.381	.381	.362	.362	.2858	.362	.362
7	.4001	.4191	.4382	.4001	.381	.4191	.381
8	.4001	.4001	.362	.4191	.3429	.4191	.381
9	.381	.362	.362	.4382	.362	.381	.4001
10	.4191	.3429	.362	.362	.3239	.362	.4001
11	.4191	.3429	.381		.2858	.381	.3429
12	.362	.3239	.3239	.3048	.2477	.3239	.3239
13	.362	.3239	.3048	.3429	.2286	.3239	.2667
14	.3048	.2858	.2858	.3239	.2286		.362
15	.4191	.3239	.2858	.3048	.2858	.2858	.381
16	.381	.3239	.3239	.3429	.2667	.362	.362
17	.4001	.3429	.3429	.4954	.2858	.362	.381
18	.4001	.381	.4572	.4191	.381	.4572	.4001
19	.5906	.5525	.5716	.5716	.5525	.5716	.6097
20	.5335	.5906	.5335	.5525	.5335	.5716	.5525
21	.4572	.5335	.4763	.4763	.4954	.4954	.4763
22	.381	.4191	.4382	.381	.4001	.4382	.4001
23	.2667	.2858	.2667	.2477	.2286	.2477	.2477
24	.2286	.2286	.2477	.2286	.1905	.1905	.2096
Max	.5906	.5906	.5716	.5716	.5525	.5716	.6097
Min	.1905	.2096	.1905	.2096	.1905	.1905	.1905
Avg	.3556	.3461	.3429	.3529	.3040	.3479	.3437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 205 / 11 KV GARGOTI PWV EXPRESS NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0191		.0572
2	.0572	.0572	.0572	.0572	.0191	.0572	.0572
3	.0572	.0572	.0572	.0572	.0191	.0572	.0572
4	.0572	.0572	.0572	.0572	.0191	.0572	.0572
5	.0572	.0572	.0572	.0572	.0191	.0572	.0572
6	.0572	.0572	.0572	.0572	.0191	.0572	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572	.0572	.0572	.0191	.0572	.0572
10	.0572	.0572	.0572	.0572	.0191	.0572	.0572
11	.0572	.0572	.0572		.0191	.0572	.0572
12	.0572	.0572	.0572	.0572	.0191		.0191
13	.0572	.0572	.0572	.0572	.0191		.0572
14	.0572	.0572	.0572	.0572	.0191		.0572
15	.0572	.0572		.0572	.0191	.0572	.0572
16	.0572	.0572	.0572	.0572	.0191	.0191	.0572
17	.0191	.0191	.0191	.0191	.0191	.0191	.0191
18	.0191	.0191	.0572	.0191	.0191	.0191	.0572
19	.0572	.0572	.0572	.0572	.0191	.0191	.0572
20	.0572	.0572	.0572	.0572	.0191	.0191	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	
22	.0572	.0572	.0572	.0572	.0572	.0572	
23	.0572	.0572	.0572	.0572	.0572	.0572	
24	.0572	.0572	.0572	.0572	.0191	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0540	.0540	.0555	.0539	.0270	.0477	.0536



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 206 / 11 KV PIMPALGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.1905	.1905	.2286	.0572	.0572	.0381
2	.0572	.1905	.1905	.2286	.0572	.0572	.0381
3	.0572	.1905	.1715	.2286	.0572	.0572	.0381
4	.0572	.1905	.1715	.2286	.0572	.0572	.0572
5	.0572	.1905	.2286	.2286	.0572	.0572	.0572
6	.0572	.2096	.2858	.2286	.0572	.0572	.0572
7	.0381	.2667	.3239	.2858	.0572	.0572	.0572
8	.0381	.3429	.381	.362	.0572	.0572	.0381
9	.0381	.3048	.381	.362	.0572	.0572	.0381
10	.0191	.0381	.0572	.0381	.0572	.0381	.0381
11	.3048	.0381	.0572		.362	.3429	.381
12	.362	.0381	.0572	.0381	.362	.362	.381
13	.3429	.0381	.0572	.0381	.362	.3429	.362
14	.3429	.0381	.0572	.0381	.3239		.362
15	.362	.0572	.0572	.0381	.3429	.3048	.3239
16	.3429	.0572	.0572	.0381	.3429	.3239	.3429
17	.362	.0572	.0572	.0381	.3429	.362	.362
18	.2477	.0572	.0572	.0572	.2858	.3239	.3239
19		.0572	.0572	.0572	.0572	.0381	.0381
20	.0572	.0572	.0572	.0572	.0572	.0381	.0381
21	.0572	.0572	.0572	.0572	.0381	.0381	.0381
22	.0572	.0572	.0572	.0572	.0572	.0381	.0381
23	.0572	.0572	.0572	.0572	.0572	.0381	.0572
24	.0572	.1905	.0572	.1905	.0572	.0572	.0381
Max	.362	.3429	.381	.362	.362	.362	.381
Min	.0191	.0381	.0572	.0381	.0381	.0381	.0381
Avg	.1491	.1238	.1326	.1383	.1509	.1375	.1477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 207 / 11 KV GANGAPUR AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.1524	.1905	.1715	.7621	.9145	.9526
2	.6859	.1524	.1905	.1715	.7621	.9145	.9526
3	.6859	.1524	.1905	.1715	.7621	.9145	.9907
4	.724	.1524	.1905	.1715	.8764	1.0288	1.0479
5	.7811	.1524	.1905	.1715	.9907	1.1812	1.1431
6	1.086	.1524	.1905		1.2384	1.4289	1.3336
7	1.5623	.1524	.1905	.1715	1.7528	1.8099	1.848
8	1.8671	.1524	.1905	.1905	2.2481	2.5339	2.3815
9	1.7718	.1715	.1905	.1905	2.0386	2.3434	2.2672
10	.1524	.2096	.1905	.1905	.1905	.1905	.2096
11	.1524	2.8006	2.8578		.1715	.1715	.1905
12	.1524	2.9721	2.7244	2.9912	.1715	.1715	.1905
13	.1524	3.1245	3.2769	2.9721	.1715	.1715	.1905
14	.1524	3.1055	3.1055	2.9531	.1715		.1905
15	.1524	2.934	2.9721	2.7054	.1715	.1715	.1715
16	.1524	2.8006	2.7244	2.8197	.1715	.1715	.1715
17	.1524	2.5339	2.5339	2.6292	.1715	.1715	.1905
18	.1715	2.21	2.3624	2.0386	.1715	.1715	.1905
19	.1524	.1905	.1905	.1715	.1715	.1715	.1905
20	.1524	.1905	.1905	.1524	.1524	.1715	.1715
21	.1524	.1905	.1905	.1524	.1524	.1715	.1715
22	.1524	.1905	.1905	.1524	.1715	.1715	.1715
23	.1524	.1905	.1715	.1524	.1524	.1715	.1715
24	.6478	.1524	.1905	.1715	.724	.8764	.9335
Max	1.8671	3.1245	3.2769	2.9912	2.2481	2.5339	2.3815
Min	.1524	.1524	.1715	.1524	.1524	.1715	.1715
Avg	.5271	1.0494	1.0661	.9847	.6049	.7041	.6843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 208 / 11 KV DARWAD AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0381	.1334	.0762	.1143
2	.0191	.0191	.0191	.0381	.1334	.0762	.1334
3	.0191	.0191	.0191	.0381	.1334	.0762	.1334
4	.0191	.0191	.0191	.0381	.1524	.0762	.1524
5	.0191	.0191	.0191	.0381	.1715	.0953	.1905
6	.0191	.0191		.0381	.1715	.1143	.2096
7	.0191	.0191	.0191	.0381	.2477	.2858	.2858
8	.0191	.0191	.0191	.0381	.381	.381	.362
9	.0191	.0191	.0191	.0381	.3429	.3429	.362
10	.0381	.0191	.0191	.0381	.0191	.0191	
11	.5335	.4954	.6097		.0191	.0191	.0191
12	.6478	.5716	.6478	.6478	.0191	.0191	.0191
13	.6668	.6287	.6668	.6287	.0191	.0191	.0191
14	.5906	.6287	.6097	.6097	.0191		.0191
15	.5716	.5716	.6287	.6097	.0191	.0191	.0191
16	.5716	.5525	.6097	.5906	.0191	.6287	.0191
17	.5144	.4763	.5525	.5144	.0191	.0191	.0191
18	.381	.381	.4572	.381	.0191	.0191	.0191
19	.0191	.0191	.0381	.0191	.0191	.0191	.0191
20	.0191	.0191	.0381	.0191	.0191	.0191	.0191
21	.0191	.0191	.0381	.0191	.0191	.0191	.0191
22	.0191	.0191	.0381	.0191	.0191	.0191	.0191
23	.0191	.0191	.0381	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0381	.1334	.0762	.1143
Max	.6668	.6287	.6668	.6478	.381	.6287	.362
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2001	.1921	.2245	.1955	.0945	.1069	.1003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 209 / 11KV MADUR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1905	.1905	.1905	.1905	.1905	.1715
2	.1905	.1715	.1715	.1905	.1905	.1905	.1524
3	.1905	.0572	.1715	.1905	.1905	.1905	.1905
4	.2096	.1715	.2286	.1905	.1905	.1905	.2286
5	.2667	.2096	.2667	.2096	.1905	.2286	.2667
6	.3239	.3429	.3239	.3048	.2667	.3239	.3239
7	.4191	.381	.4001		.362	.381	.4382
8	.4001	.381	.4001	.4001	.362	.4382	.4191
9	.4191	.4001	.4001	.4001	.381	.4572	.4382
10	.362	.4001	.3429	.4191	.3239	.381	.4191
11	.3239	.3239	.362		.2667	.3048	.362
12	.381	.2858	.362	.3429	.2858	.3429	.3429
13	.362	.3239	.3239	.3429	.2858	.362	.3048
14	.2858	.3048	.2858	.3048	.1905		.2667
15	.3048	.2858	.362	.2667	.2286	.2667	.2667
16	.3429	.3239	.3048	.3048	.2286	.3048	.2667
17	.381	.3429	.3239	.3048	.2667	.4001	.362
18	.381	.1905	.3048	.381	.3239	.4001	.381
19	.5335	.5144	.6097	.5525	.4954	.5335	.5906
20	.5525	.5144	.6097	.6097	.5716	.5525	.6287
21	.4954	.4954	.5335	.4954	.5335	.5716	.5335
22	.381	.4191	.4572	.4191	.4382	.4763	.4572
23	.2477	.2477	.2667	.2477	.2286	.2858	.2667
24	.2096	.1905	.1905	.2096	.1905	.1905	.1715
Max	.5525	.5144	.6097	.6097	.5716	.5716	.6287
Min	.1905	.0572	.1715	.1905	.1905	.1905	.1524
Avg	.3406	.3112	.3414	.3308	.2993	.3462	.3437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV MANGNOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	.0019		.0075	1.0269
2	1.0562	.0019		.0075	1.0562
3	1.0562	.0019		.0075	1.0456
4	1.0562	.0019		.0075	1.1203
5	1.2449	.0019		.0075	1.1949
6	1.3392	.0019		.0075	1.307
7	1.6598	.0019		.0075	1.5655
8	1.9616	.0019		.0075	1.7541
9	1.8296	.0019		.0075	1.7924
10		.0019		.0019	.0019
11	.0019	1.8298	1.7741	1.8671	
12	.0019	1.905	1.8656	1.7924	
13	.0019	1.773	1.6827	.7922	
14	.0019	1.7177	1.6827	.8589	
15	.0019	1.7353	1.6827	.9522	
16	.0019	1.8673	1.7375	1.0456	
17	.0019	1.7353	1.6827	.9896	
18	.0019	1.6221	1.5364	1.587	
19	.0019		.0075	.0019	
20	.0019		.0075	.0019	
21	.0019		.0075	.0019	
22	.0019		.0075	.0019	
23	.0019		.0075	.0019	
24	.9808	.0019		.0075	1.0456
Max	1.9616	1.905	1.8656	1.8671	1.7924
Min	.0019	.0019	.0075	.0019	.0019
Avg	.5751	.7477	1.0525	.4155	1.1737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV ARALGUNDI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18
HR	Load (MW)
11	2.2032
12	2.3712
13	2.1658
14	2.0538
15	.0019
Max	2.3712
Min	.0019
Avg	1.7592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV ARALGUNDI VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0377	.0754	.0747	.0566	.0754	.0747
2	.0943	.0377	.0566	.0754	.0377	.0566	.056
3	.0754	.0377	.0566	.0377	.0377	.0566	.056
4	.0566	.0377	.0566	.0377	.0377	.0566	.0747
5	.0566	.0566	.0754	.0754	.0566	.0566	.0934
6	.1132	.0943	.1132	.0747	.0754	.0566	.112
7	.132	.1132	.1132	.112	.1132	.1132	.1307
8	.132	.132	.132	.1307	.1509	.1509	.112
9	.132	.132	.132	.112	.1132	.132	.112
10	.1509	.132	.132	.1132	.1132	.1132	.0934
11	.132	.112	.112	.132	.1132	.0934	.1494
12	.0943	.1132	.1307	.1132	.1307	.0934	.0934
13	.0943	.1132	.0934	.0943	.132	.0934	.0943
14	.0943	.112	.0943	.0943	.1132	.0934	.0934
15	.0754	.0943	.0943	.0943	.0943	.112	.112
16	.0754	.0943	.112	.0943	.0943	.112	.0934
17	.0754	.0943	.0747	.0754	.1132	.112	.112
18	.1132	.132	.112	.1132	.1132	.112	.112
19	.1698	.2075	.1494	.1886	.1698	.1867	.1867
20	.2075	.2263	.1867	.2263	.1698	.2054	.2054
21	.1886	.1698	.168	.1698	.1698	.168	.1698
22	.132	.132	.1307	.132	.1509	.1307	.1307
23	.0754	.0943	.112	.0943	.132	.112	.1132
24	.1132	.0566	.0943	.0747	.0754	.0943	.0747
Max	.2075	.2263	.1867	.2263	.1698	.2054	.2054
Min	.0566	.0377	.0566	.0377	.0377	.0566	.056
Avg	.1124	.1068	.1086	.1058	.1068	.1078	.1106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 205 / 11 KV BARVE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.0754	.132	.1307	.0943
2	.1132	.0754	.1132	.1132	.0754
3	.0943	.0754	.1132	.0934	.0754
4	.0943	.0754	.1132	.0943	.0943
5	.0943	.0943	.132	.112	.1132
6	.132	.132	.1509	.1307	.1509
7	.1698	.1698	.1886	.1663	.1698
8	.1886	.1886	.2263	.2054	.2075
9	.1698	.2263	.2263	.1848	.1886
10	.1698	.2263	.2075	.1698	.1886
11	.2075	.2241	.2033	.2263	.2452
12	.2263	.2452	.2149	.1886	.2614
13	.2263	.1509	.168	.1886	.2075
14		.2054	.1494	.1509	.1509
15		.1886	.1494	.1509	
16		.2263	.2218	.1698	
17		.2452	.2402	.2075	
18	.1886	.2452	.2402	.1509	
19	.3018	.3395	.2614	.2641	
20	.3174	.3772	.3142	.3206	
21	.2641	.2641	.2772	.3018	
22	.1886	.2263	.2218	.2075	
23	.132	.1509	.1867	.132	
24	.1509	.0754	.1509	.1307	.1132
Max	.3174	.3772	.3142	.3206	.2614
Min	.0943	.0754	.1132	.0934	.0754
Avg	.1781	.1876	.1918	.1746	.1557



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 202 / 11 KV MHASARANG AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
1	1.5181	.0747
2	1.4998	.0747
3	1.448	.0747
4	1.4998	.0747
5	1.5546	.0747
6	1.6651	.0747
7	1.9547	.0747
8		.0747
9	2.3529	.0747
10	.0739	
11	.0739	3.8462
12		3.8649
13	.0732	3.7529
14	.0747	3.7342
15	.0732	
16	.0747	
17	.0747	
18	.0747	
19	.0747	
20	.0747	
21	.0732	
22	.0747	
23	.0747	
24	1.5364	.0747
Max	2.3529	3.8649
Min	.0732	.0747
Avg	.7270	1.1389

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV VENGRUL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	26-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.3717	.0373	
2	1.3394	.0373	
3	1.3169	.0373	
4	1.3352	.0373	
5	1.39	.0373	
6	1.4118	.0373	
7	1.6289	.0373	
8	1.6289	.0373	
9	1.6289	.0373	
10	.0543	.0373	
11	.0554	2.7633	
12	.0373	2.8006	
13	.056	2.8753	
14	.056	2.8006	2.8006
15	.056	2.8567	
16	.056	2.7633	
17	.0373	2.6513	
18	.0373		
19	.0373		
20	.0373		
21	.0373		
22	.0373		
23	.0373		
24	1.39	.0373	
Max	1.6289	2.8753	2.8006
Min	.0373	.0373	2.8006
Avg	.6281	1.1067	2.8006

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 204 / 11 KV DONAWADE AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
1	.1478	2.5206
2	.1494	2.4272
3	.1494	2.6139
4	.1494	2.7435
5	.1494	3.3608
6	.1848	3.6408
7	.168	3.7342
8	.181	3.9209
9	.1991	4.0703
10	.1448	.1463
11	3.8009	.1867
12	4.4437	
13	5.4138	
14	2.5579	
15	3.7494	
16	4.313	
17	3.7311	
18	3.6031	
19	.2614	
20	.2614	
21	.1867	
22	.1867	
23	.1867	
24	.1663	2.8006
Max	5.4138	4.0703
Min	.1448	.1463
Avg	1.4369	2.6805

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 205 / 11 KV SHELOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.168	.2241	.2054	.2926	.1494
2	.1478	.168	.1867	.1867	.2614	.1494
3	.1478	.1494	.1867	.2054	.2614	.1494
4	.1478	.1494	.2054	.2241	.2987	.168
5	.1478	.1867	.2241	.2614	.2987	.1867
6	.1478	.2241	.2427	.2987	.3361	.1867
7	.2561	.2614	.2614	.3361	.3734	.1867
8	.2743	.2614	.2614	.3475	.4481	.1867
9	.2957	.2926	.2614	.3547	.4481	.1867
10	.2172	.3174	.3361	.4108	.3658	.2614
11	.2012	.2427	.3361	.3547	.3361	
12	.2987	.2614	.2054	.3734	.2054	
13	.2241	.2987		.3734		.2572
14	.2614	.2614	.3547	.3734		.2915
15	.2987	.2614	.3361	.3734		.3086
16	.2987	.2241	.2427	.3921		
17	.2801	.2241	.2614	.4108		
18	.2926	.2987	.3547	.4294		
19	.3921	.4481	.4668	.4481	.5228	
20	.4294	.4854	.4481	.4854	.439	
21	.4481		.4108	.4481	.4108	
22		.2481	.3547	.4108	.3361	
23	.2801		.2614	.3361	.1867	
24	.1848	.1867	.2241	.2241	.2987	.1463
Max	.4481	.4854	.4668	.4854	.5228	.3086
Min	.1478	.1494	.1867	.1867	.1867	.1463
Avg	.2539	.2554	.289	.3443	.3400	.2011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 206 / 11 KV KARADWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	.0934	.112	.0934	.0747	.1867
2	.0747	.0747	.0934	.0747	.0747	.112
3	.0747	.0747	.0914	.0747	.0747	.0934
4	.0747	.0934	.1097	.0934	.0934	.0934
5	.0747	.0934	.1307	.1097	.1307	.112
6	.112	.112	.128	.1463	.1494	.1494
7	.1867	.112	.1463	.1646	.1494	.1463
8	.1848	.1494	.1463	.1867	.168	.168
9	.1848	.1494	.1463	.168	.168	.1829
10	.1478	.1494	.1097		.168	.1829
11	.1109	.0934	.0732	.1307	.112	.0857
12	.112	.0934	.0914	.128		.1715
13	.0747	.0747		.128		.1029
14	.0732	.0747	.1097	.1097		.0686
15	.0914	.0914	.1097	.128		.0686
16	.0914	.0934	.1463	.1463		
17	.1494	.128	.1646	.1463		
18	.1829	.1463	.1646	.1646		
19	.2614	.2241	.2427	.2561	.3547	
20	.2614	.2987	.3292	.2987	.2987	
21	.2987	.2801	.2801	.2427	.2614	
22	.2614	.2241	.2054	.2195	.2195	
23	.1867	.1494	.1307	.1463	.2427	
24	.0924	.1307	.112	.0934	.0934	.2427
Max	.2987	.2987	.3292	.2987	.3547	.2427
Min	.0732	.0747	.0732	.0747	.0747	.0686
Avg	.1432	.1335	.1467	.1500	.1667	.1354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.2096	.1901	.2477	.2286	.1715	.1901
2	.1524	.1905	.1711	.2477	.2286	.1524	.171
3	.1334	.1905	.152	.2286	.2096	.1334	.1521
4	.1524	.1715	.1521	.3048	.2286	.1905	.1521
5	.2286	.2286	.2092	.362	.362	.2858	.2279
6	.3048	.3048	.3232	.4001	.381	.3429	.3036
7	.4382	.4382	.4373	.4382	.4191	.4572	.436
8	.4763	.4954	.3993	.4191	.5335		.4753
9	.4191	.5144	.3989	.4382	.4954		.455
10	.4382	.4944	.381	.4001	.4191	.4749	.4001
11	.381	.4749	.362	.4001	.3239	.4563	.381
12	.4191	.4373	.3239	.3239	.3239	.3795	.381
13	.3239	.2852	.2858	.3239	.2667	.3232	.3429
14	.362	.3042	.2667	.3048	.2858	.2852	.3239
15	.3239	.3613		.3048	.3048	.3791	.3429
16	.362	.3993	.3048	.2477	.381	.4183	.3429
17	.3239	.3613	.381	.3048	.362	.3803	.3429
18	.4001	.4753		.3048	.4382	.4373	.4191
19	.6097	.7035		.6668	.7049	.6845	.6287
20	.7621	.7415	.6097	.7049		.7028	.6097
21	.6287	.6275	.4954	.5906		.6084	.5716
22	.4572	.4563	.4382	.4763		.4373	.4191
23	.2858	.3042	.3048	.3239	.2667	.2662	.3239
24	.2096	.2286	.2282	.2667	.2477	.2096	.2282
Max	.7621	.7415	.6097	.7049	.7049	.7028	.6287
Min	.1334	.1715	.152	.2286	.2096	.1334	.1521
Avg	.3660	.3916	.3245	.3763	.3529	.3717	.3592

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 202 / 11 KV HEDEWADE AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18
HR	Load (MW)	Load (MW)
1	.1334	.2096
2	.0953	.2096
3	.0953	.2096
4	.1334	.2096
5	.1905	.2096
6	.2286	.2096
7	1.6194	.2096
8	1.8099	.2096
9	1.6956	.2286
10	.2096	.2469
11	.0953	.4753
12	.0953	.3232
13	.0953	2.4272
14	.0953	2.5527
15	.0953	2.5105
16	.0953	1.848
17	.0953	1.5972
18	.2096	.3429
19	.2096	
20	.2096	
21	.2096	
22	.2096	
23	.2096	
24	.1905	.2096
Max	1.8099	2.5527
Min	.0953	.2096
Avg	.3469	.7599

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 203 / 11 KV NILPAN AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.0953	.1521	.2012	.1143	.1143	.1141
2	.1143	.0953	.1517	.2012	.1143	.1143	.1141
3	.1143	.0953	.1521	.2378	.1143	.1143	.1141
4	.1143	.1524	.1708	.4207	.1143	.1143	.114
5	.1143	.1524	.2282	.6767	.1143	.1143	.1141
6	.1143	.2477	.3223	.7316	.1143	.1143	.1139
7	.1143	.6478	.7679	.7316	.1334	.1334	.1331
8	.1143	1.0479	1.0413	.9511	.1334		.1494
9	.1334	1.1241	.9896	.8954	.1905		.1698
10	.1143	.1141	.128	.1143	.1524	.1521	.1829
11	1.448	.1141	.1097	.0953	1.2384	1.1564	1.8839
12	1.4098	.1331	.1097	.1334	1.2003	.9896	1.9387
13	1.2574	.1331	.1097	.1143	1.1431	.9739	1.829
14	1.1431	.1331	.128	.1143	1.086	.789	1.829
15	.9907	.1307		.1334	1.0098	.7316	1.7558
16	1.0098	.1331	.1097	.1143	.9145	.8531	1.6827
17	.6668	.1331		.1143	.9335	.778	1.39
18	.4191	.1331		.1334	.5716	.4739	1.1523
19	.1143	.1141		.1334	.1143	.1141	.1463
20	.1143	.112	.1097	.1143	.1143	.1141	.1463
21	.1143	.1141	.1097	.1143	.1143	.1141	.1463
22	.1143	.1141		.1143	.1143	.1141	.1463
23	.1143	.1141	.1097	.1143	.1143	.1141	.1463
24	.1143	.1143	.1328	.2012	.1143	.1143	.1141
Max	1.448	1.1241	1.0413	.9511	1.2384	1.1564	1.9387
Min	.1143	.0953	.1097	.0953	.1143	.1141	.1139
Avg	.4247	.2291	.2701	.2878	.4199	.3819	.6511



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 402 / 33 KV Shriram LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572		.0572		.0572	
2	.0572	.0572		.0572		.0572	
3	.0572	.0572		.0572		.0572	
4	.0572	.0572		.1143		.0572	
5	.0572	.0572		.1143		.0572	.1141
6	.0572	.0572		.1143		.0572	.1141
7	.0572	.0572	.1141	.1143		.0572	.1141
8	.0572	.0572	.1141	.1143		.0572	.114
9	.0572	.0572	.1141	.0572		.0572	.1141
10	.0572	.1141	.1143	.0572		.1141	.1143
11	.0572	.1141	.1143	.0572		.1141	.1143
12	.0572	.1141	.1143	.0572		.1141	.1143
13	.0572	.1141	.1143	.0572		.1141	.1143
14	.0572		.1143	.0572			.1143
23	.0572		.0572		.0572		.0572
24		.0572		.0572		.0572	
Max	.0572	.1141	.1143	.1143	.0572	.1141	.1143
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0735	.1079	.0762	.0572	.0735	.1090

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 201 / 11 KV DASEWADI AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.086	.1267	.1267
2	1.086	.1267	.1267
3	1.086	.1254	.1254
4	1.1641	.1254	.1254
5	1.182	.1254	.1254
6	1.3073	.124	.124
7	1.3998	.1063	.124
8	1.5947	.1214	.124
9	1.7541	.1227	.1227
10	.1214	.12	
11	.132	2.3388	2.5086
12	.132	2.4709	2.2218
13	.1307	2.3624	
14	.1097	2.2257	2.2634
15	.1052	2.0911	2.0936
16	.1052	2.037	2.0559
17	.1214	2.037	1.9791
18	.1227	2.0538	1.5261
19	.124	.1478	
20	.1307	.1524	.1494
21	.1307	.1294	.1294
22	.1254	.1294	.1267
23	.1267	.1433	.128
24	1.0498	.1267	.1448
Max	1.7541	2.4709	2.5086
Min	.1052	.1063	.1227
Avg	.6012	.8196	.7834

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 202 / 11 KV PATGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0905	.0716	.0905	.0709
2	.0724	.0716	.0724	.0709
3	.0724	.0716	.0716	.0709
4	.0895	.0709	.0895	.0716
5	.1075	.0709	.1075	.0886
6	.1433	.0895	.1595	
7	.1772	.1595	.1949	
8	.1949	.1907	.2126	
9	.2303	.2427	.2629	
10	.2427	.2601	.2401	
11		.2829	.2075	
12	.2241	.2263	.1867	
13	.1578	.1715		
14	.1646	.1509	.1886	
15	.1402	.1494	.1886	
16	.1227	.132	.2263	
17	.2103	.2075	.1307	
18	.2103	.2054	.1907	
19	.3189	.2957	.2614	
20	.3018	.3239	.3018	
21	.2987	.3142	.3109	
22	.2172	.2772	.2353	
23	.1267	.1791	.1629	
24	.1086	.0905	.1086	.0709
Max	.3189	.3239	.3109	.0886
Min	.0724	.0709	.0716	.0709
Avg	.1749	.1794	.1827	.0740

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 203 / 11 KV SHIVDAV AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
1	.1086	.9774	.9774
2	.1086	.9671	1.086
3	.1086	.9671	1.0745
4	.1075	1.0029	1.1104
5	.1075	1.0277	1.182
6	.1075	1.0387	1.2757
7	.1063	1.1871	1.382
8	.1063	1.3003	1.4352
9	.1063	1.335	1.4198
10	.104	.0876	.0857
11	1.8861	.0754	.0747
12	1.905	.0566	.0754
13	1.8673	.0572	
14	1.8111	.0566	.0934
15	1.6827	.056	.0754
16	1.7187	.0566	.0566
17	1.5604	.0566	.0566
18	1.3672	.056	.0693
19	.1063	.0924	.0943
20	.1132	.0953	.112
21	.112	.1109	.1109
22	.1075	.1109	.1097
23	.1086	.1075	.1086
24	.1086	.9774	.9412
Max	1.905	1.335	1.4352
Min	.104	.056	.0566
Avg	.6469	.4940	.5655

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 201 / SILVER ZONE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.9036	.8573	.8573	.823	.8859	.8916
2	.8573	.9036	.8745	.8573	.8402	.8682	.8916
3	.8573	.9036	.8745	.8916	.8402	.8682	.8573
4	.8573	.9214	.8573	.8916	.8573	.8505	.8573
5	.8573	.9391	.8573	.8916	.8573	.8505	.8573
6	.8573	.9391	.8573	.8916	.8745	.8682	.8573
7	.9259	.9745	.9259	.8916	.8745	.8328	.8573
8	.9945	.9568	.9431	.9431	.8745	.8859	.9088
9		.9892	1.0117	1.0288	.823	.9568	1.0631
10	1.2757	1.1317	1.2337	1.1736	.8682	.9415	1.382
11	1.382	1.6461	1.4934	1.6095	.815	1.2661	1.5415
12	1.4529	1.4746	1.331	1.5927	.8328	1.4771	1.5415
13	1.0277	1.5089	1.0226	1.5432	.8682	1.2174	1.382
14	.7619	1.5261	1.2499	1.5089	.8682	1.2661	1.4175
15	1.6301	1.5089	1.3635	1.2517	.7973	1.2824	1.3998
16	1.6124	1.5775	1.4771	1.2517	.7973	1.185	1.1517
17	1.2403	1.5604	1.1363	1.166	.815	1.1363	1.0454
18	1.0985	1.1145	1.0551	1.0802	.815	1.0389	.9568
19	1.134	1.0288	1.0288	.9945	.8505	1.0631	.9259
20	1.0099	.9431	1.0288	.8402	.815	1.0631	.8916
21	1.1517	.8745	1.0288	.8745	.815	1.0631	.8916
22	1.0808	.8573	.8573	.8573	.8505	.9602	.8745
23	.9391	.823		.8573	.8328		.8745
24	.8916	.8859	.823	.8573	.823	.8859	.8916
Max	1.6301	1.6461	1.4934	1.6095	.8745	1.4771	1.5415
Min	.7619	.823	.823	.8402	.7973	.8328	.8573
Avg	1.0777	1.1205	1.0517	1.0668	.8387	1.0310	1.0504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 202 / HUPARI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.7265	.7202	1.0288	.8916	.6733	1.0288
2	1.0288	.6733	.6516	1.0288	.8573	.6733	1.0288
3	1.0288	.6733	.6516	1.0288	.8402	.6379	1.0288
4	1.0288	.691	.6859	1.0288	.823	.6556	1.0288
5	1.0288	.7442	.7373	1.0288	.8059	.7265	1.0288
6	1.0288	.8682	.823	1.0288	.7716	.8682	1.0288
7	1.0631	.9391	.9431	.8916	.8573	.9214	1.0288
8	1.0288	.9922	.9602	.8916	.9431	.9745	.9431
9		.9431	.9088	1.0288	.9259	.9214	.9922
10	1.1163	1.046	.8928	1.0117	1.0099	.9739	1.0808
11	1.2226	1.1831	.9415	1.1831	1.134	1.0551	1.1871
12	1.2048	1.2174	.9252	1.2003	1.1694	1.1038	1.258
13	1.2403	1.0288	.909	1.2003	1.134	1.0713	1.2934
14	1.0099	.9602	.8765	1.1145	.9391	1.0226	1.0099
15	1.1163	1.046	.8441	1.0117	1.0099	.9415	1.0808
16	1.2226	1.1831	.8116	1.0631	1.0277	1.0389	1.2226
17	1.1871	1.1488	.8603	1.1145	1.1163		1.2934
18	1.258	1.2003	.8928	1.2003	1.0985	1.2012	1.2934
19	1.5415	1.286	1.0288	1.1831	1.4706	1.0631	1.4746
20	1.4352	1.3032	1.2346	1.1831	1.4529	1.0631	1.3375
21	1.3466	1.3375	1.2003	1.166	1.3112	1.0631	1.0631
22	1.134	1.0802	1.0974	1.0974	1.0631	1.1317	.9945
23	1.0454	.9945		1.0117	.9568		.8573
24	1.0288	.815	.8059	1.0288	.9259	.7619	1.0288
Max	1.5415	1.3375	1.2346	1.2003	1.4706	1.2012	1.4746
Min	1.0099	.6733	.6516	.8916	.7716	.6379	.8573
Avg	1.1467	1.0034	.8871	1.0731	1.0223	.9338	1.1088

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 203 / YALGUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.4588	.4694	.6859	.0343	.0343	.0343
2	.0343	.4588	.4694	.6859	.0343	.0343	.0343
3	.0171	.4588	.4694	.6859	.0343	.0343	.0343
4	.0171	.4588	.4694	.6859	.0343	.0343	.0343
5	.0171	.4752	.4862	.6859	.0343	.0343	.0343
6	.0171	.4752	.503	.6859	.0343	.0343	.0343
7	.0343	.639	.6539	.6859	.0343	.0343	.0343
8	.0343	.7373	.8059	.703	.0343	.0343	.0343
9		.8122	.8048	.6859	.0343	.0343	.0343
10	.0343	.0343	.7792	.0343	.0343	.0325	.0343
11	1.065	.0343	.0162	.0343	.8356	1.1363	.9995
12	1.0978	.0343	.0162	.0343	.9995	1.1363	1.0814
13	.9667	.0343	.0325	.0343	1.0159	1.1038	.8356
14	.9339	.0343	.0325	.0343	1.0159	1.0876	.9012
15	.9175	.0343	.0162	.0343	.9831	1.0551	.9339
16	.852	.0343	.0325	.0343	.7701	1.0226	.9339
17	.9339	.0343	.0325	.0343	.7865	.9902	.7045
18	.8192	.0514	.0325	.0343	.9339	.9739	.7373
19	.0343	.0514	.0171	.0343	.0343	.0171	.0343
20	.0343	.0514	.0171		.0343	.0171	.0343
21	.0343	.0514	.0171	.0343	.0343	.0171	
22	.0343	.0343	.0171	.0343	.0343	.0171	.0343
23	.0343	.0343		.0343	.0343		.0343
24	.0343	.4424	.4527	.5487	.0343	.0343	.0343
Max	1.0978	.8122	.8059	.703	1.0159	1.1363	1.0814
Min	.0171	.0343	.0162	.0343	.0343	.0171	.0343
Avg	.3492	.2485	.2888	.3124	.3287	.3891	.3323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 204 / RENDAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5432	1.0974	1.0288	1.5432	1.5432	1.2803	1.5432
2	1.5432	1.0974	1.0288	1.5432	1.5432	1.2803	1.5432
3	1.5432	1.0974	1.0288	1.5432	1.5432	1.2803	1.5432
4	1.5432	1.0974	1.0288	1.5432	1.5432	1.2803	1.5432
5	1.5432	1.0974	1.0288	1.7147	1.5432	1.2803	1.5432
6	1.5432	1.2803	1.3717	1.7147	1.3717	1.4632	1.5432
7	1.5432	1.2803	1.7147	1.7147	1.7147	1.5947	1.5432
8	1.5432	1.4327	2.0119	1.8861	1.8861	1.7147	1.5432
9		2.3472	2.5149	2.4006	2.572	2.2939	1.8442
10	1.6461	2.5149	2.5972	2.8502	2.6216	2.2725	2.0119
11	1.4632	2.8502	2.7595	2.8502	2.7854	2.4348	2.0119
12	1.0974	2.6825	2.7595	2.8502		2.2725	2.0119
13	1.0974	1.7147	1.6232	2.8178	1.8442	1.1363	1.2803
14	1.0974	1.3717	1.9479	2.6825	1.8442	1.4609	1.2803
15	1.0974	2.3472	2.2725	2.6825	2.4577	1.7856	1.5947
16	1.0974	2.8502	2.5972	2.8502	2.2939	1.7856	1.7147
17	1.0974	2.6825	2.4348	2.6825	1.8442	1.9479	1.5947
18		2.6825		2.6825	2.6216	2.1102	1.3717
19	1.2803	2.3472	1.8861	2.5149	2.3205	2.0576	1.3717
20	1.4632	2.0119	1.7147	2.3472	1.7147	1.7147	1.3717
21	1.4632	1.8442	1.7147	1.8861	1.7147	1.7147	1.3717
22	1.4632	1.5432	1.8861	1.7147	1.7147	1.5432	1.3717
23	1.2803	1.3717		1.7147	1.5947		1.3717
24	1.7147	1.2803	1.2003	1.5432	1.5432	1.4327	1.5432
Max	1.7147	2.8502	2.7595	2.8502	2.7854	2.4348	2.0119
Min	1.0974	1.0974	1.0288	1.5432	1.3717	1.1363	1.2803
Avg	1.3956	1.8301	1.8250	2.1780	1.9207	1.7016	1.5610



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 207 / HUPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	.0343	.0343	.0343	.8402	1.0802	1.0288
2	1.2003	.0343	.0343	.0343	.9088	1.0631	1.0288
3	1.2003	.0343	.0343	.0343	1.0117	1.0631	1.3717
4	1.166	.0343	.0343	.0343	1.0631	1.0802	1.3717
5	1.166	.0343	.0343	.0343	1.166	1.0974	1.3717
6	1.166	.0343	.0343	.0343	1.2346	1.0974	1.3717
7	1.0631	.0343	.0343	.0343	1.286	1.2346	1.3717
8	1.0631	.0343	.0514	.0343	1.3375	1.3546	1.406
9		.0171	.0343	.0343	1.4403	1.3546	1.3717
10	.0343	.0171	.0325	.0343	.0343	.0325	.0343
11	.0343	1.491	1.4609	1.7368	.0343	.0325	.0343
12		1.5565	1.4122	1.7859	.0343	.0325	.0343
13		1.5592	1.5583	1.7695	.0171	.0325	.0343
14		1.5089	1.5421	1.6385	.0343	.0325	.0343
15	.0343	1.5257	1.5258	1.6057	.0343	.0325	.0343
16	.0343	1.4586	1.5096	1.6712	.0343	.0325	.0343
17	.0343	1.4419	1.4609	1.5927	.0343	.0325	.0343
18	.0343	1.3413	1.4284	1.4754	.0343	.0325	.0343
19	.0343	.0343	.0343	.0514	.0343	.0343	.0343
20	.0343	.0343	.0343	.0514	.0514	.0343	.0343
21	.0343	.0343	.0343	.0343	.0343	.0343	.0514
22	.0343	.0343	.0343	.0343	.0343	.0343	.0514
23	.0343	.0343		.0343	.0343		.0343
24	1.2003	.0343	.0343	.0343	.823	1.0802	.7202
Max	1.2003	1.5592	1.5583	1.7859	1.4403	1.3546	1.406
Min	.0343	.0171	.0325	.0343	.0171	.0325	.0343
Avg	.5401	.5166	.5403	.5774	.4830	.5189	.5387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 208 / BIRDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0171	.0343	.0343	.4458	.5079	.6859
2	.0514	.0171	.0343	.0343	.463	.5079	.6859
3	.0514	.0171	.0343	.0171	.4801	.5243	.6859
4	.0514	.0171	.0343	.0171	.4973	.5243	.7202
5	.0514	.0171	.0171	.0171	.5144	.5243	.7202
6	.0343	.0171	.0171	.0171	.5316	.5407	.7202
7	.0343	.0171	.0343	.0171	.6516	.639	.7202
8	.3429	.0171	.0171	.0171	.8059	.7537	.7716
9		.0343	.0171	.0171	.8402	.7865	.7701
10	.0171	.0514	.0162	.0343	.0343	.0162	.0171
11	.0171	.9556	1.0064	1.1437	.0343	.0162	.0171
12	.0171	.8383	1.0389	1.1603	.0343	.0162	.0171
13	.0171	.8718	1.0713	1.1736	.0343	.0162	.0171
14	.0171	.9054	1.0713	1.0898	.0343	.0162	.0171
15	.0171	1.1065	1.0876	.9892	.0343	.0162	.0171
16	.0171	1.0562	1.0876	1.073	.0343	.0162	.0171
17	.0171	1.0059	1.0713	.8383	.0343	.0162	.0171
18	.0343	1.0395	1.0551	.7926	.0343	.0162	.0171
19	.0343	.0343	.0343	.0343	.0343	.0171	.0343
20	.0343	.0343	.0343	.0171	.0343	.0171	.0343
21	.0343	.0343	.0343		.0343	.0171	.0343
22	.0343	.0343	.0343	.0343	.0343	.0171	.0343
23	.0343	.0343		.0343	.0343		.0343
24	.3429	.0171	.0343	.0343		.4915	.703
Max	.3429	1.1065	1.0876	1.1736	.8402	.7865	.7716
Min	.0171	.0171	.0162	.0171	.0343	.0162	.0171
Avg	.0589	.3413	.3877	.3755	.2483	.2615	.3129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 201 / PATTANKODOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	1.1145	1.2003	1.166	.0514	.0366	.0514
2	.0366	1.1145	1.2003	1.166	.0343	.0366	.0514
3	.0358	1.0802	1.2003	1.166	.0343	.0366	.0514
4	.0537	1.0631	1.2003	1.166	.0343	.0362	.0514
5	.0543	1.1488	1.2689	1.166	.0514	.0362	.0514
6	.0537	1.3889	1.6118	1.2174	.0514	.0362	.0514
7	.0537	1.6118	1.8004	1.3375	.0514	.0549	.0514
8	.0537	1.6804	1.9204	1.4746	.0343	.0514	.0514
9	.0549	1.7147	1.8176	1.5089	.0343	.0543	.0514
10	.0543	.0514	.0343	.0343		.0537	.0514
11	2.1434	.0514	.0343	.0514		2.7435	2.6063
12	2.1434	.0514	.0343	.0514	2.6863	2.6749	2.6235
13	2.1434	.0514	.0514	.0514	1.9879	2.6406	2.5892
14	2.1434	.0514		.0514	2.4177	2.4348	2.5549
15	2.1434	.0514		.0514	1.8625	2.332	2.5377
16	2.1434	.0514		.0514	1.7909	2.2462	2.5034
17	2.1434			.0514		2.2291	2.4691
18	1.5089			.0514	2.0595	2.1605	2.3148
19	.0514			.0514	.0358	.0514	.0686
20	.0514			.0514	.0537	.0514	.0686
21	.0514			.0514	.0537	.0514	.0514
22	.0514			.0514	.0537	.0514	.0514
23	.0514			.0514	.0358	.0514	.1715
24	.0362	1.1317	1.2517	1.166	.0514	.0366	.0514
Max	2.1434	1.7147	1.9204	1.5089	2.6863	2.7435	2.6235
Min	.0358	.0514	.0343	.0343	.0343	.0362	.0514
Avg	.7206	.7887	1.0447	.5515	.6412	.8412	.8823

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 202 / 11 kV INGALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.0343	.0514	.7202	.7682	.7545
2	.724	.0343	.0343	.7202	.7682	.7202
3	.724	.0343	.0343	.6859	.7316	.6859
4	.7602	.0343	.0343	.6859	.8145	.6859
5	.823	.0343	.0343	.7545	.8145	.7202
6	.9145	.0343	.0343	.823	.9774	.823
7	1.0608	.0343	.0343	.9602	1.086	1.0288
8	1.0791	.0343	.0343	1.0288	1.3169	1.1145
9	.9145	.0343	.0343	1.0288	1.2437	1.166
10	.0366	.0343	.0343		.0366	.0514
11		1.6118	1.6461	.0362	.0343	.0514
12	.0171	1.6461	1.8176	.0362	.0343	.0343
13		1.6461	1.7147	.0358	.0343	.0343
14	.0171	1.7147	1.5432	.0358	.0343	.0343
15	.0171	1.7147		.0362	.0343	.0343
16			1.4403	.0362	.0343	.0343
17	.0171		1.3717		.0343	.0343
18	.0171	1.7147	1.2689	.0362	.0343	.0343
19	.0343		.0343	.0362	.0343	.0343
20	.0343		.0343	.0362	.0343	.0343
21	.0343		.0343	.0543	.0343	.0343
22	.0343		.0343	.0549	.0343	.0514
23	.0343		.0343	.0549	.0343	.1715
24	.724	.0343	.0514	.6859	.823	.6859
Max	1.0791	1.7147	1.8176	1.0288	1.3169	1.166
Min	.0171	.0343	.0343	.0358	.0343	.0343
Avg	.4159	.6133	.4950	.3901	.4094	.3772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 203 / 11 kV SANGWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.6516	.7202	.7545	.0686	.0543	.0686
2	.0549	.6516	.7202	.7545	.0686	.0366	.0686
3	.0549	.6173	.7202	.7545	.0686	.0549	.0686
4	.0549	.6173	.7716	.7545	.0686	.0549	.0686
5	.0732	.6687	.7716	.823	.0686	.0543	.0686
6	.0732	.7888	.9259	.9945	.0686	.0549	.0686
7	.0732	1.1831	1.2346	1.2174	.0686	.0549	.0857
8	.0732	1.2689	1.286	1.4232	.0686	.0914	.0857
9	.0732	1.406	1.286	1.4403	.0686	.0914	.0857
10	.0914	.1029	.0857	.0857			.0686
11	1.7147	.12	.0857	.0857	1.7551	1.749	1.869
12	1.7147	.12		.1029	1.773	1.8347	1.8861
13	1.7147	.1372		.1029	1.7013	1.8004	1.8176
14	1.7147	.12		.0857		1.7661	1.7833
15	1.7147	.12		.0857	1.6278	1.6804	1.749
16	3.0864	.12		.0857	1.5939	1.5775	1.7147
17	1.5089			.0857		1.5432	1.6461
18	1.2346			.0857	1.4864	1.4403	1.406
19	.1029			.12	.0537	.1029	.1029
20	.0857			.1029	.0724	.0857	.1029
21	.0857			.0857	.0543	.0857	.1029
22	.0857			.0857	.0537	.0857	.1029
23	.0857			.0686	.0537	.0857	.1029
24	.0549	.6173	.7373	.7545	.0686	.0549	.0686
Max	3.0864	1.406	1.286	1.4403	1.773	1.8347	1.8861
Min	.0549	.1029	.0857	.0686	.0537	.0366	.0686
Avg	.6492	.5477	.7788	.4558	.5196	.6278	.6330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 204 / 11 KV INGALI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0857	.1029	.0857	.0857	.0905	.0857
2	.0732	.0686	.1029	.0857	.0686	.0905	.0686
3	.0732	.0686	.1029	.0857	.0686	.0905	.0686
4	.0732	.0686	.1029	.0857	.0686	.1267	.0686
5	.1254	.0857	.12	.0857	.0857	.1267	.0857
6	.197	.1715		.12	.1543	.2012	.1543
7	.181	.1715		.1715	.1543	.1829	.1715
8	.1646	.1372		.1372	.1543	.181	.1715
9	.1463	.12		.1372	.1543	.1463	.1372
10	.128	.12		.1029		.1463	.1029
11	.0857	.0857		.0857	.0905	.1029	.0857
12	.0857	.1029		.0857	.0905	.12	.1029
13	.0857	.1029		.0857	.1075	.1029	.1029
14	.0857	.1029		.1029	.0895	.1029	.1029
15	.0857	.0857		.1029	.1267		.1029
16	.0857	.0857		.1029	.0905		.1029
17	.0857			.1029			.0857
18	.0857			.1029	.1086		.0857
19	.1543			.1715	.1448		.1543
20	.1715			.1715	.1629		.1543
21	.1372			.1372	.1267	.1543	.1372
22	.0857			.12	.1086	.1372	.12
23	.0857			.1029	.0905	.12	.0686
24	.0549	.1029	.1029	.0857	.0857	.0914	.0857
Max	.197	.1715	.12	.1715	.1629	.2012	.1715
Min	.0549	.0686	.1029	.0857	.0686	.0905	.0686
Avg	.1080	.1039	.1058	.1107	.1099	.1286	.1086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 205 / 11 KV SANGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3086	.3429	.3429	.2743	.2715	.2743
2	.2715	.2743	.3429	.3429	.2572	.2715	.2572
3	.2743	.2743	.3429	.3429	.2572	.2743	.2572
4	.2743	.2743	.3429	.3429	.2572	.2743	.2572
5	.2743	.3429	.3772	.3772	.2915	.3658	.3086
6	.5121	.4801	.5144	.4973	.3429	.4961	.4458
7	.6401	.5487	.6173	.6516	.4801	.5487	.6173
8	.8048	.6516	.5487	.6687	.4458	.7059	.6516
9	.9511	.9602	1.0631	1.1145	.4801	.9877	.823
10	1.2254	1.2346	1.3717	1.0631		1.2437	1.3375
11	1.0288	1.166	1.3203	1.3203	.362	.8916	1.3375
12	1.0288	1.1488	1.2689	1.3717	.3582	.8916	.8573
13	2.0576	1.0288	1.0974	1.2174	.2896	.8916	.823
14	1.0288	.9259		.9259	.2896	.6859	.7716
15	1.0288	.823		.7545	.3258	.9602	.823
16	1.0288	.9602		1.0288	.3292	.8916	.823
17	1.0288			1.0117		.823	.9602
18	1.0288			.9945	.4525	1.0974	.8916
19	.823			.6859	.6584	.6516	.6859
20	.6859			.5487	.6767	.6173	.5144
21	.6173			.4115	.543	.6173	.4801
22	.4973				.362	.5487	.4458
23	.4115			.3601	.2715	.3772	.1715
24	.3658	.3429	.3429	.3429	.2743	.2743	.2743
Max	2.0576	1.2346	1.3717	1.3717	.6767	1.2437	1.3375
Min	.2715	.2743	.3429	.3429	.2572	.2715	.1715
Avg	.7590	.6909	.7067	.7269	.3763	.6525	.6287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3429	.4458	.3601	.3772	.3658	.4115
2	.3292	.3086	.4458	.3601	.3429	.3292	.3601
3	.3292	.3086	.4458	.3601	.3429	.2743	.3601
4	.3292	.3086	.4458	.3601	.3429	.2743	.3601
5	.4572	.4115	.4801	.3944	.4458	.4024	.4458
6	.7682	.6173	.5487	.7888	.6173	.6767	.5487
7	.9145	.823	.703	.7716	.7545	.8596	.823
8	.8962	.7373	.7373	.7888	.7373	.8048	.823
9	.7682	.6859	.6859	.6859	.6859	.7316	.7545
10	.7133	.6173	.6516	.7545		.695	.7202
11	.6173	.6859	.6859	.6516		.6173	.6516
12	.6173	.6516	.6516	.6173	.6878	.5487	.6859
13	1.2346	.6173	.6173	.6173		.5487	.5487
14	.6173	.583		.5487	.5792	.5487	.4458
15	.6173	.5487		.4801	.5731	.4115	.4458
16	.6173	.5487		.5658	.6335	.5144	.4458
17	.6516			.5658		.5487	.4801
18	.6516			.583	.7682	.6173	
19	.8916			.9602	1.1157	.823	.9602
20	.9602			.9259	1.086	.8573	.8916
21	.8573			.8059	.905	.823	.8745
22	.7545			.7545	.6335	.6859	.4801
23	.6001			.5487	.543	.5487	.1715
24	.4572	.4458	.4458	.3772	.4115	.362	.4115
Max	1.2346	.823	.7373	.9602	1.1157	.8596	.9602
Min	.3292	.3086	.4458	.3601	.3429	.2743	.1715
Avg	.6673	.5436	.5707	.6094	.6292	.5779	.5696



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 207 / 11 KV Vasagade Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.583	.4801	.0514	.0366	.0514
2	.0366	.5487	.4801	.0514	.0366	.0514
3	.0366	.5487	.4801	.0514	.0366	.0514
4	.0366	.5487	.4801	.0514	.0366	.0514
5	.0366	.6001	.5144	.0514	.0366	.0514
6	.0549	.703	.7373	.0514	.0549	.0514
7	.0549	.9088	.9774	.0514	.0366	.0514
8	.0549	.9602	1.0974	.0514	.0549	.0514
9	.0549	1.046	1.046	.0514	.0549	.0514
10	.0549	.0514	.0343		.0549	.0514
11	1.3717	.0514	.0343	1.7193	1.5261	1.6118
12	1.3717	.0514	.0343	1.7194	1.6461	1.6632
13	1.3717	.0514	.0343	1.6289	1.6461	1.6118
14	1.3717	.0514	.0343	1.5746	1.6461	1.5947
15	1.3717	.0514	.0343	1.5384	1.5432	1.5604
16	1.3717	.0514	.0343	1.4842	1.4746	1.5261
17	1.3717		.0343		1.406	1.4918
18	1.1488		.0514	1.3575	1.3032	1.4746
19	.0514		.0514	.0366	.0514	.0686
20	.0514		.0514	.0549	.0514	.0686
21	.0514		.0514	.0537	.0514	.0514
22	.0514		.0514	.0537	.0514	.0514
23	.0514		.0514	.0543	.0514	.0514
24	.0366	.583	.4801	.0514	.0366	.0514
Max	1.3717	1.046	1.0974	1.7194	1.6461	1.6632
Min	.0366	.0514	.0343	.0366	.0366	.0514
Avg	.4792	.4347	.3065	.5359	.5385	.5580

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 201 / 11 KV BRAMHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.048	1.5546	1.1797	1.1498	.0492	.0469	.0486
2	.0486	1.5708	1.1111	1.1736	.0497	.0474	.0486
3	.0497	1.5708	1.2574	1.1336	.0514	.0492	.0503
4	.0492	1.5708	1.4022	1.1822	.0526	.0503	.0497
5	.0503	1.5546	1.4083	1.2574	.0537	.0617	.0497
6	.0486	1.5708	1.4998	1.3413	.0543	.064	.0503
7	.0474	1.6194	1.6057	1.4754	.0526	.0671	.0671
8	.0566	1.7004	1.7101	1.5708	.0566	.0678	.0671
9	.0754	1.6804	1.9105	1.5708	.0566	.0663	.0671
10	.0663	.0671	.0486	.0503	.0663	.0648	.0503
11	2.4897	.0754	.0503	.0566		2.251	2.6406
12	2.5463	.0566	.0486	.0566		2.0567	2.6139
13	2.3577	.0566	.0503	.0566	2.2822	2.2119	2.5953
14	2.2257	.0566	.0503	.0566	2.2779	2.1125	2.5766
15	2.1879	.0377	.0335	.0566	1.7924	2.2466	2.5393
16	2.1879	.0377	.1134	.0566	1.8945	2.1376	2.5579
17	2.1691	.0189	.1174	.0754	1.8515	2.1795	2.3525
18	2.1125	.0189		.0754	1.9448	2.1125	2.3152
19	.052	.0474		.0492	.0463	.0486	.0492
20	.0554	.0492		.0486	.0671	.0503	.0486
21	.0554	.0526	.0503	.0474	.0625	.0503	.0474
22	.0373	.0354	.0486	.0463	.0463	.0486	.0469
23	1.5546	.0351	.0503	.0469	.0655	.0486	.1715
24	.0492	1.5546	1.0936	1.1498	.048	.0514	.0503
Max	2.5463	1.7004	1.9105	1.5708	2.2822	2.251	2.6406
Min	.0373	.0189	.0335	.0463	.0463	.0469	.0469
Avg	.8592	.6914	.7067	.5743	.5874	.7580	.8814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 202 / 11 KV PANCHGANGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562				1.1469	1.2186	1.0562
2	1.1012				1.1934	1.2492	1.0395
3	1.1603				1.2689	1.2944	1.0277
4	1.1797				1.3672	1.3413	1.0442
5	1.2407				1.4327	1.2346	1.0608
6	1.1822				1.4842	1.3123	1.0774
7	1.1702				1.4899	1.358	1.1233
8	1.3769				1.6409	1.3565	1.2407
9	1.358				1.6787	1.3757	1.2239
11		1.905	1.8107	1.9805			
12		1.9427	1.749	1.9427			
13		1.9993	1.8275	1.9616			
14		1.9993	1.8442	1.9239			
15		2.037	1.7269	1.905			
16		1.9616	1.7101	1.8861			
17		1.8296	1.7101	1.8484			
18		1.8484	1.7101	1.8296			
23							.1715
24	1.0486				1.0883	1.3546	1.073
Max	1.3769	2.037	1.8442	1.9805	1.6787	1.3757	1.2407
Min	1.0486	1.8296	1.7101	1.8296	1.0883	1.2186	.1715
Avg	1.1874	1.9404	1.7611	1.9097	1.3791	1.3095	1.0126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.208	.1781	.1966	.2353	.1966	.1718	.1991
2	.1943	.1781	.1852	.2353	.1989	.1739	.1991
3	.1989	.1619	.2347	.2149	.2401	.1966	.2172
4	.2294	.1619	.2804	.2353	.2804	.2347	.2507
5	.2683	.1943	.2881	.2507	.3045	.2469	.2865
6	.2753	.1943	.3125	.2686	.3258	.2881	.3077
7	.3005	.2429	.3277	.3439	.333	.3353	.3439
8	.3584	.2915	.3353	.3439	.3206	.3222	.362
9	.3584	.3201	.333	.3982	.2829	.3647	.3258
10	.3315	.3353	.3801	.3521	.2818	.4163	.3258
11	.3772	.3961	.3353	.3772		.362	.3584
12	.2452	.3772	.3688	.3772		.3801	.3734
13	.2452	.3018	.2896	.3584	.2452	.3439	.3921
14	.2641	.3018	.2534	.3206	.2987	.2896	.3921
15	.2829	.3961	.3258	.3395	.168	.3353	.4108
16	.2829	.3772	.362	.3584	.2515	.3982	.4108
17	.2829	.415	.362	.3772	.213	.4163	.3921
18	.2641	.3961		.3961	.285	.4344	.4294
19	.2774	.3637		.3605	.3086	.4344	.3932
20	.3142	.3932		.3725	.3277	.4163	.3401
21	.2772	.3681	.3258	.3163	.2812	.3801	.3005
22	.2033	.3544	.3077	.2778	.2623	.3258	.25
23	.1781	.2804	.2896	.25	.2294	.2715	.1715
24	.2458	.1943	.2187	.2534	.208	.2058	.2172
Max	.3772	.415	.3801	.3982	.333	.4344	.4294
Min	.1781	.1619	.1852	.2149	.168	.1718	.1715
Avg	.2693	.2989	.3006	.3172	.2656	.3227	.3187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 201 / 11 KV YELGUD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2054	.1991	.2033	.1867	.1753	.1578
2	.1372	.1867	.181	.1663	.168	.1402	.1578
3	.1372	.168	.1612	.1663	.1478	.1402	.156
4	.1372	.1494	.1612	.1646	.1478	.1402	.156
5	.1543	.1663	.1753	.1829	.1646	.1578	.1907
6	.2058	.1848	.1928	.1991	.2149	.1907	.2058
7	.3086	.1991	.3121	.2172	.298	.2058	.2743
8	.2743	.2835	.3121	.2743	.2915	.2543	.3048
9	.2591	.2743	.285	.2543	.2572	.2818	.2543
10	.3258	.3658	.381	.3439	.285	.3292	.3174
11	.3018	.3856	.3561	.3185	.285	.3086	
12	.3185	.3688	.2486	.3018	.2818	.2915	.3258
13	.285		.2818	.2321	.2652	.3561	.2915
14	.2347	.3018	.2984	.3018	.2652	.2713	.2572
15	.285	.2515		.3018	.2683	.2713	
16	.3185	.2683	.2818	.3018	.2012	.2683	
17	.3258	.2713	.2486	.285	.2515	.3052	.3086
18		.3018	.2515	.2515	.1844	.2058	
19	.3584	.3239	.3239	.3547	.2858	.3429	.3239
20	.362	.3429	.3429	.381	.3239	.3239	.3239
21	.3239		.3239	.3239	.3239	.3429	.3239
22	.2858	.2858	.2858	.3048	.2858	.2858	.2858
23	.2667	.2477	.2667	.2667	.2477	.2477	.2477
24	.2103	.2263	.2012	.2218	.2241	.2103	.1772
Max	.362	.3856	.381	.381	.3239	.3561	.3258
Min	.1372	.1494	.1612	.1646	.1478	.1402	.156
Avg	.2603	.2618	.264	.2633	.2440	.2520	.2520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 202 / LAXMI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.2614	.3258	.2772	.0373	.0351	.0175
2	.0171	.2614	.3258	.2587	.0373	.0351	.0175
3	.0171	.2427	.3258	.2587	.037	.0351	.0175
4	.0171		.3189	.2561	.037	.0351	.0173
5	.0171	.2587	.3506	.3292	.0366	.0351	.0173
6	.0343	.2957	.4207	.4163	.0358	.0347	.0171
7	.0343	.3982	.4854	.4525	.0351	.0171	.0171
8	.0152	.4252	.4854	.4973	.0343	.017	.0191
9	.0152	.4458	.4694	.5256	.0343	.0166	.017
10	.0171	.0183	.0191	.0181	.0191	.0183	.0187
11	.5868	.0168	.017	.0168		.6001	
12	.57	.0168	.0166	.0168	.7293	.6516	.6344
13	.5868		.0166	.0166	.7459	.6104	.6173
14	.5868	.0168	.0166	.0168	.7293	.6274	.6001
15	.503	.0335	.0166	.0168	.7377	.6274	
16	.5533	.0168	.0166	.0168	.6706	.5197	
17	.5658	.017	.0166	.0168	.6203	.5426	.583
18	.5373	.0168	.0168	.0168	.5868	.5316	
19	.0377	.0381	.0381	.0373	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0572	.0381
21	.0381		.0381	.0381	.0381	.0381	.0381
22	.0191	.0381	.0381	.0381	.0381	.0381	.0381
23	.0191	.0381	.0381	.0381	.0381	.0381	.0381
24	.0351	.2641	.2743	.2772	.0373	.0351	.0354
Max	.5868	.4458	.4854	.5256	.7459	.6516	.6344
Min	.0152	.0168	.0166	.0166	.0191	.0166	.017
Avg	.2033	.1504	.1719	.1621	.2344	.2181	.1418

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 203 / bajrang ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.0373	.0181	.0185	.7282	.7011	.7888
2	.5487		.0181	.0185	.7282	.6661	.8063
3	.5658	.0373	.0181	.0185	.7023	.6661	.8063
4	.5487	.0373	.0177	.0183	.7023	.6836	.7975
5	.583	.037	.0175	.0366	.7133	.7712	.8669
6	.6344	.037	.0175	.0362	.7522	.9015	.9259
7	.8402	.0362	.0173	.0362	.9114	1.0288	1.0117
8	.7926	.0354	.0173	.0171	1.0288	1.1022	1.2384
9	.884	.0171	.0168	.017	1.0288	1.094	1.0852
10	.0171	.0183	.0191	.0181	.0381	.0183	.0187
11	.0168	1.3077	1.2548	1.3413	.0335	.0171	
12	.0168	1.3748	1.326	1.4251	.0166		.0343
13	.0168		1.326	1.2763	.0166		.0171
14	.0168	1.3413	1.2929	1.2239	.0166	.017	.0171
15		1.1736	1.2266	1.2071	.0168	.017	
16		1.1736	1.1603	1.1736	.0168	.0168	
17	.0171	1.153	1.1768	1.1401		.017	.0171
18	.0179	1.0395	1.0898	1.0395	.0335	.0171	
19	.0377	.0191	.0191	.0187	.0381	.0191	.0381
20	.0381	.0381	.0381	.0381	.0381	.0191	
21	.0381		.0381	.0381	.0381	.0381	.0381
22	.0381	.0191	.0381	.0381	.0381	.0191	.0191
23	.0381	.0191	.0191	.0191	.0381	.0191	.0191
24	.6135	.0377	.0183	.0185	.7095	.7011	.7973
Max	.884	1.3748	1.326	1.4251	1.0288	1.1022	1.2384
Min	.0168	.0171	.0168	.017	.0166	.0168	.0171
Avg	.3122	.4281	.4251	.4264	.3645	.3887	.4917

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 201 / GADMUDSHINGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.8097	1.1065	1.286	.0953	.1143	.12
2	.1143	.8097	1.1065	1.2517	.0953	.0953	.12
3	.1143	.8259	1.2071	1.286	.0953	.0953	.12
4	.1143	.8907	1.3413	1.286	.1143	.0953	.12
5	.1334	1.0526	1.4922	1.4746	.1334	.1143	.1372
6	.1524	1.1401	1.7404	1.6289	.1524	.1334	.1715
7	.1715	1.6263	1.8233	1.9376	.1715	.1715	.1543
8	.1524	1.8187	2.0119	2.0919	.1524	.1905	.1372
9	.1509	1.8519	1.9784	2.0287	.132	.1143	.1524
10	.1509	.0857	.1143	.0762	.1698	.1524	.1334
11	2.4478	.0857	.1334	.0762	2.4813	2.5316	2.6322
12	2.4646	.0857	.1334	.0762	2.2801	2.5484	2.6155
13	2.3205	.0857	.0191	.0572	2.4006	2.364	2.4646
14	2.1714	.0857	.0191	.0572	2.2805	2.2634	2.3137
15	2.0222	.0857	.0191	.0572	2.2634	2.3137	2.2969
16	2.0454	.0857	.0191	.0572	2.1776	2.3807	2.3908
17	2.0287	.0857		.1334	2.1293	2.332	2.364
18	1.8275	.12		.1715		2.1262	2.2634
19	.1334	.1372		.1715	.1715	.1543	.1905
20	.1715	.1509	.1543	.1715	.1715	.1543	.1715
21	.1334	.1509	.1543	.1524	.1334	.1372	.1715
22	.1524	.1509	.1372	.1334	.1334	.1543	.1715
23	.1334	.132	.1029	.1143	.1334	.12	.1715
24	.1143	.6802	1.1736	1.2174	.1143	.1143	.12
Max	2.4646	1.8519	2.0119	2.0919	2.4813	2.5484	2.6322
Min	.1143	.0857	.0191	.0572	.0953	.0953	.12
Avg	.8140	.5431	.7613	.7081	.7905	.8738	.9043



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 202 / KALAMWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1109	.132	.12	.0934	.0732	.1372
2	.112	.1109	.1132	.1029	.0934	.0732	.1029
3	.112	.1109	.1132	.1029		.0732	.1029
4	.112	.1307	.132	.1029	.112	.0732	.1029
5	.1307	.1494	.132	.1372	.1307	.0914	.12
6	.1307	.1494	.1698	.1543	.1494	.0934	.1543
7	.1307	.168	.1886	.1372	.168	.1494	.1372
8	.1307	.1494	.1698	.1543		.1494	.1543
9	.1886	.1543	.2054	.0924	.1132	.168	.168
10	.1698	.1543	.1867	.2075	.132	.2054	.2054
11	.1698	.1886	.1867	.2075	.132	.1867	.2241
12	.1886	.1886	.2241	.2172	.1132	.1867	.2241
13	.1698	.1886	.1867	.1848	.1029	.2054	.168
14	.1698	.1543	.168	.1867	.1029	.1494	.168
15	.1698	.1715	.2054	.2054	.1029	.1867	.1867
16	.1698	.1886	.2054	.2054	.1029	.2241	.2054
17	.1698	.1543	.2058	.2427	.112	.2229	.168
18	.1698		.2229	.168		.2058	.1867
19	.1698	.1715	.1715	.2241	.1494	.1886	.2054
20	.1886	.1886	.1543	.1867	.1509	.1715	.2054
21	.1698	.1886	.1543	.1494	.1509	.1543	.1867
22	.1509	.1698	.1543	.1494	.1132	.1543	.1867
23	.1698	.1886	.1372	.1307	.112	.1543	.168
24	.1307	.1294	.1509	.12	.112	.0924	.1372
Max	.1886	.1886	.2241	.2427	.168	.2241	.2241
Min	.112	.1109	.1132	.0924	.0934	.0732	.1029
Avg	.1544	.1591	.1696	.1621	.1214	.1514	.1669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 203 / GADMUDSHINGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4294	.3881	.3961	.3772	.3734	.3109	.3601
2	.4294	.3696	.3772	.3429	.3734	.2926	.4287
3	.4481	.3696	.3772	.3429	.3921	.2926	.4115
4	.4481	.4066	.4338	.3429	.3921	.2926	.4287
5	.4668	.5359	.547	.463	.4294	.3658	.4801
6	.5041	.5788	.6036	.5316	.4854	.3921	.5316
7	.5975	.5601	.6413	.4801	.6535	.4481	.583
8	.4668	.4108	.4338	.3944	.4668	.4108	.4115
9	.5658	.4458	.5228	.4854	.4527	.4294	.4668
10	.6979	.4287	.5041	.6224	.4338	.4854	
11	.5847	.3601	.5788	.6413	.3961	.4668	.4481
12	.4338	.3772	.6348	.394	.3772	.5975	.3921
13	.547	.4115	.5601	.4668	.3258	.5601	
14	.6036	.3944	.5601	.4854	.3601	.5788	.4668
15	.4904	.3944	.5788	.4481	.4115	.5788	.4294
16	.415	.4287	.3921	.3921	.3429	.3734	.4294
17	.4854	.3772	.4115	.3921	.3734	.3601	.4481
18	.6224	.4801	.583	.5228		.5487	.6161
19	.7356	.5487	.6687	.6535	.5788	.703	.6908
20	.6979	.7733	.6687	.6908	.5847	.703	.7468
21	.7356	.7356	.6859	.7468	.5093	.6859	.7468
22	.017	.7545	.6001	.5975	.4854	.703	.7095
23	.6224	.6036	.5658	.4668	.3921	.5316	.6161
24	.5415	.4481	.4527	.3944	.3921	.3326	.3772
Max	.7356	.7733	.6859	.7468	.6535	.703	.7468
Min	.017	.3601	.3772	.3429	.3258	.2926	.3601
Avg	.5244	.4826	.5324	.4865	.434	.4768	.5100

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 204 / sarnobatwadi ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3189	.0572	.0566	.0514	.2614	.2801	.2058
2	.3189	.0572	.0566	.0514	.2614	.2801	.2058
3	.3544	.0572	.0566	.0514	.2835	.2801	.1886
4	.3544	.0953	.0566	.0514	.2835	.2801	.1886
5	.3721	.1334	.0754	.0514	.3189	.2801	.2229
6	.4075	.1524	.0943	.0857	.3189	.2987	.2572
7	.4252	.1715	.0934	.1029	.3734	.394	.3772
8	.5316	.1905	.112	.0857	.4252	.3856	.4287
9	.5087	.1543	.1334	.0381	.6859	.3898	.2229
10	.0943	.0857	.0953	.1334	.3048	.0953	.0953
11	.1132	.4287	.5138	.6516	.0943	.1143	.0953
12	.1509	.463	.5316	.703	.1132	.1143	.0762
13	.132	.6516		.6516	.0857	.1715	.0953
14	.132	.6173	.567	.583		.0953	.0953
15	.132	.583	.5316	.5658	.0686	.0953	.1143
16	.1509	.583	.5316	.5487	.1029	.1334	.0953
17	.1334	.6001	.4801	.567	.1143	.12	.0953
18	.1334	.3944	.3429	.3721		.1029	.0953
19	.0762	.0686	.0686	.0953	.1143	.0857	.1143
20	.0762	.0754	.0686	.0953	.0762	.0857	.0762
21	.0572	.0754	.0686	.0762	.0762	.0857	.0953
22	.0572	.0566	.0686	.0762	.0762	.0857	.0953
23	.0572	.056	.0686	.0572	.0572	.0514	.1715
24	.3366	.0572	.0566	.0514	.1417	.2614	.2058
Max	.5316	.6516	.567	.703	.6859	.394	.4287
Min	.0572	.056	.0566	.0381	.0572	.0514	.0762
Avg	.2260	.2444	.2056	.2416	.2108	.1903	.1631

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 201 / EKONDI Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.112		1.5074	1.6575		.1448
2	.1254	.112		1.5729	1.6575		.1448
3	.128	.1134		1.5912	1.6575		.1448
4	.1254	.112		1.5912	1.6385		.1463
5	.1254	.1134		1.6907	1.7404		.1463
6	.1254	.1107		1.8896	1.9062		.1448
7	.1402	.128		2.3205	2.1879		.1629
8	.1595	.128		2.4531	2.8509		.181
9		.1448	2.4326	2.5888	2.9835	.1772	
10		.1448	.128	.124	.1417	.1772	
11		.1448	.128	.1417	2.8178	2.9835	
12		.1227	.1311	.1417	2.8509	3.315	3.658
13		.1063	.1311	.1402	2.5194	2.9835	
14		.1063	.112	.1417	2.42	2.9835	
15		.124	.1134	.1543	2.3868	2.9007	
16		.1433	.1134	.1595	2.3594	2.7846	
17	2.6886		.1267	.1772		2.4905	2.7846
18	2.2996		.1629	.1753		2.2542	2.4034
19	.1311		.1753	.1595		.1612	.1791
20	.1296		.1753	.1595		.1612	.1791
21	.128		.1753	.1417		.1629	.1791
22			.181	.1417		.1448	.1612
23			.1448	.1417		.1448	.1433
24	.124	.112		1.4251	1.6575		.1448
Max	2.6886	.1448	2.4326	2.5888	2.9835	3.315	3.658
Min	.124	.1063	.112	.124	.1417	.1448	.1433
Avg	.4683	.1223	.2954	.8638	2.0843	1.5883	.6499

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 202 / Siddhanerli- Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0358	.0316		.7625	.6706		.0366
2	.0354	.0316		.8288	.6783		.0366
3	.0358	.0316		.8288	.663		.0366
4	.0354	.032		.8288	.7545		.0362
5	.0358	.0312		.9282	.763		.0366
6	.0362	.0312		1.0277	.9945		.0366
7	.0358	.0316		1.2266	1.1934		.0362
8	.0358	.0312		1.2929	1.3923		.0366
9		.0362	1.2163	.9831	1.4586	.0366	
10		.0362					
12							2.4196
19			.0362			.0362	.0366
20			.0362	.0366		.0362	.0366
21			.0366	.0366		.0362	.0366
22			.0366	.0366		.0362	.0366
23			.0366	.0366		.0366	.0366
24	.0366	.0312		.6882	.6706		.0366
Max	.0366	.0362	1.2163	1.2929	1.4586	.0366	2.4196
Min	.0354	.0312	.0362	.0366	.663	.0362	.0362
Avg	.0358	.0323	.2331	.6816	.9239	.0363	.1954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 203 / 11KV Shendur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9389	1.004		.0905	.0886		.7293
2	.9389	.9717		.0905	.1075		.7293
3	.9389	.9393		.0905	.1075		.7377
4	.9389	.9175		.0905	.1086		.7712
5	.9724	.9717		.0905	.1254		.8288
6	1.1603	1.065		.0905	.1267		.9945
7	1.4586	1.1797		.1086	.1448		1.4918
8	1.9006	2.0719		.1086	.1254		
9		2.3266	.096	.1075	.0905	1.7238	
10			.0972	.1097	.1063	.0732	
11		2.6189	2.4086	2.5194	.1063	.0895	
12		2.6543	2.9007	2.652	.0876	.0914	.0953
13		2.5232	2.8178	2.7349		.0914	
14		2.3537	2.7526	2.5194	.0709	.0716	
15		2.3205	2.5692	2.3537	.061	.1097	
16		2.2542	2.3537	2.3537	.0724	.1097	
17	.081		2.1956	2.1548		.1267	.1063
18	.081		1.704	1.7072		.1267	.1254
19	.0983		.0905	.1063		.1267	.124
20	.096		.0905	.0914		.1086	.1075
21	.096		.0905	.0895		.1086	.1075
22			.0895	.0905		.0905	.1075
23			.0905	.0905		.0914	.1086
24	.8848	.7373		.0905	.0886		.7042
Max	1.9006	2.6543	2.9007	2.7349	.1448	1.7238	1.4918
Min	.081	.7373	.0895	.0895	.061	.0716	.0953
Avg	.7560	1.6818	1.3565	.8555	.1011	.2093	.4918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3696	.3841		.3206	.3658		.3429
2	.3326	.3696		.3239	.362		.3048
3	.3326	.3326		.3239	.3841		.3048
4	.3326	.3292		.3239	.3658		.3048
5	.3881	.5121		.381	.362		.3429
6	.5601	.5975		.5335	.439		.5716
7	.6908	.6348		.6097	.567		.6097
8	.5601	.5975		.5335	.5304		.5658
9		.5601	.5975	.6089	.5228	.5914	
10		.5975	.5544	.5487	.4805	.567	
11		.5041	.5601	.5487		.5304	
12		.4805	.5041	.4938	.4435	.6219	.5335
13		.4854	.462	.4938	.4066	.5121	
14		.4481	.4481	.3475	.3696	.4024	
15		.4481	.4435	.4207	.3696	.4938	
16		.4481	.4108	.4938	.3734	.4755	
17	.3658		.3696	.5121		.5544	.4755
18	.4066		.5601	.4435		.5601	.5853
19	.7468		.6908	.6908		.7095	.6838
20	.8488		.7468	.6908			.7468
21	.7468		.6722	.6099		.6036	.7316
22			.5601	.6161		.5975	.6283
23			.4481	.4755		.4572	.5121
24	.3841	.4066		.3174	.4207		.381
Max	.8488	.6348	.7468	.6908	.567	.7095	.7468
Min	.3326	.3292	.3696	.3174	.362	.4024	.3048
Avg	.5047	.4786	.5352	.4859	.4227	.5483	.5074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 205 / 11 kv Shendur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3109	.2957		.2614	.2328		.2587
2	.2743	.2957		.2614	.2328		.2427
3	.2743	.2743		.2614	.2507		.2427
4	.2743	.2561		.2614	.2715		.2427
5	.3077	.3109		.2987	.2686		.2801
6	.4435	.3292		.3734	.3258		.3734
7	.4435	.3361		.4108	.4344		.4066
8	.4251	.3174		.4435	.439		.4207
9		.3506	.3658	.3189	.3012	.3658	
10			.3292	.3721	.3086	.3658	
11		.2835	.3361	.3292	.2915	.3142	
12		.2804	.2957	.3366	.2543	.3109	.3048
13		.2629	.2957	.3403		.2865	
14		.2629	.2743	.3224	.2629	.3109	
15		.2804	.2772	.3292	.2601	.2743	
16		.3155	.2801	.3475	.2401	.3403	
17	.2926		.2743	.3841		.3601	.3224
18	.3326		.3561	.3292		.4161	.4835
19	.5121		.4908	.5914		.5434	.5014
20	.6348		.4908	.6468		.5792	.5487
21	.5601		.4298	.5487		.5121	.5304
22			.3582	.4572		.439	.439
23			.3292	.3658		.3326	.3045
24	.2926	.2957		.2926	.2561		.2772
Max	.6348	.3506	.4908	.6468	.439	.5792	.5487
Min	.2743	.2561	.2743	.2614	.2328	.2743	.2427
Avg	.3842	.2967	.3456	.3702	.2894	.3834	.3635



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 206 / Octega Green  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	26-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
12		.0381
24	.0343	
Max	.0343	.0381
Min	.0343	.0381
Avg	.0343	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 207 / 11KV Vitthal Shivaji LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1417	.1402		.362		.4207
4	.1417	.3189		.3856		.5258
5	.1402	.394		.4207		.5258
6	.2279	.4298		.4207		.5201
7	.407	.394				.4854
8	.3721	.4298		.0332		.4908
9		.4024	.4207	.2835	.4748	
10		.2012	.4207	.4287	.5138	
11		.2629	.443	.4115	.4973	
12		.2743	.4207	.4382	.5201	.5716
13		.0181	.4207	.1753	.5201	
14		.0179	.4207	.1772	.5258	
15		.2481	.4207	.4382	.5258	
16		.2481	.3681	.1595	.5201	
17	.5014		.3856		.5144	.5258
18	.4733		.4207	.1417	.4908	.5434
Max	.5014	.4298	.443	.4382	.5258	.5716
Min	.1402	.0179	.3681	.0332	.4748	.4207
Avg	.3007	.2700	.4142	.3054	.5103	.5122

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 402 / 33 KV Shahu LIS -SDH-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	3.2808	2.7846				2.0576
4	3.4008	3.1579				3.0178
5	3.4008	3.4008				3.0178
6	3.6374	3.4408				3.083
7	4.6205	4.4753				4.2764
8	4.2753	4.768				4.8731
9			3.9781	2.6543	3.1459	
10			3.834	4.0775	3.1824	
11			3.9781	4.1289	3.1824	
12			3.9781	4.1289	3.0121	5.487
13			4.177	3.9369	3.0476	
14			4.3759	4.0306	3.0476	
15			4.5748	3.9781	3.0476	
16			4.4239	4.4239	3.083	
17	4.9429		4.4753	4.4239	3.0121	4.7737
18	.9259					
Max	4.9429	4.768	4.5748	4.4239	3.1824	5.487
Min	.9259	2.7846	3.834	2.6543	3.0121	2.0576
Avg	3.5606	3.6712	4.1995	3.9759	3.0845	3.8233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 201 / Kagal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.5813	2.0576	1.9052	.0762	.0953	.0762
2	.0953	1.829	2.1148	1.9624	.0762	.0953	.0762
3	.0953	1.8099	2.1148	1.9433	.0762	.0953	.0762
4	.0762	1.848	2.1719	1.9433	.0762	.0762	.0762
5	.0762	1.8861	2.1719	1.9814	.0762	.0762	.0762
6	.1143	2.0957	2.191	2.0957	.0953	.0953	.0953
7	.1143	2.5149	2.5149	2.4196	.0953	.0953	.0762
8	.0953	2.8197	2.7435	2.6863	.1143	.0953	.0953
9	.0953	2.7816	2.6673	2.553	.0762	.0762	.0762
10	.0953	.1143	.0762	.0572	.0762	.0953	.0762
11	3.1436	.0953	.0762	.0572	2.8959	3.2198	3.4294
12		.0953	.0572	.0762	3.2007	3.296	3.4294
13	3.0864	.0953	.0762	.0572	2.9912	3.4103	3.2388
14	.381		.0762	.0572	2.915	3.0483	3.1055
15	.381		.0762	.0572	2.7816	2.934	3.2007
16	3.0864	.0381	.0762	.0762	.7811	2.9721	2.9721
17	3.0293	.0762	.0572	.0762	.8002	2.9912	3.0293
18	2.7054	.0953	.0572	.0953	.7811	2.8387	2.934
19	.0953	.0762	.0762	.1143	.0191	.0953	.1143
20	.1143	.1143	.0953	.1143	.1143	.1143	.0953
21	.1143	.1143	.0953	.0953	.1143	.0953	.1143
22	.0953	.0953	.0762	.0953	.0762	.0953	.0953
23	.0762	2.0767	.0762	.0762	.0762	.0762	.0953
24	.0953	1.3336		2.0005	.0762	.0762	.0762
Max	3.1436	2.8197	2.7435	2.6863	3.2007	3.4103	3.4294
Min	.0762	.0381	.0572	.0572	.0191	.0762	.0762
Avg	.7538	1.0721	.9476	.9415	.7692	1.0899	1.1138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 202 / Kagal-Sugar Factory Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2477	.2477	.1905	.1715	.2096	.1905
2	.2286	.2286	.2477	.1905	.1715	.2096	.1905
3	.2286	.2286	.2477	.1905	.1715	.2477	.1905
4	.2667	.2477	.2477	.1905	.1905	.2667	.1905
5	.3048	.2477	.2858	.2286	.2096	.2667	.2477
6	.4191	.4572	.4191	.3048	.3048	.362	.3429
7	.5525	.4763	.4382	.4191	.3239	.4001	.4572
8	.5525	.6478	.5335	.6668	.2858	.6097	.724
9	.6859	.6097	.5525	.6097	.3239	.5906	.6097
10	.381	.5716	.6668	.7621	.2667	.5144	.6287
11	.5716	.5716	.6859	.724	.2477	.5525	.6859
12	.381	.5525	.6668	.4954	.2096	.6478	.724
13	.381		.6478	.6478	.2096	.6097	.5335
14	.7621	.5906	.6097	.5525	.2096	.4572	.5906
15	.6668	.4001	.6668	.4572		.6097	.6668
16	.6097	.4001	.6097	.5335	.2096	.5525	.6668
17	.5144	.4763	.5716	.381	.2096	.6478	.7049
18	.5335	.5525	.5335	.6859	.2286	.5716	.7621
19	.5525	.5525	.5525	.5525	.4001	.5335	.5525
20	.5716	.5335	.4954	.4954	.4572	.5335	.5716
21	.5335	.5144	.4572	.4572	.5525	.4954	.5335
22	.381	.4001	.4191	.3239	.381	.3429	.4191
23	.2858	.3048	.2477		.3048	.2477	.2858
24	.2477	.2667	.2477	.1905	.1905	.2096	.2096
Max	.7621	.6478	.6859	.7621	.5525	.6478	.7621
Min	.2286	.2286	.2477	.1905	.1715	.2096	.1905
Avg	.4517	.4382	.4708	.4456	.2709	.4454	.4866

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant SHEDDABLE FEEDER HAVING WEEKLY  
 Roto Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5051	1.3527	1.086	1.5051	1.6766	.7621	1.3336
2	1.5051	1.3336	1.3336	1.3908	1.7147	.724	1.3527
3	1.5432	1.5623	1.3527	1.6004	1.6956	.7811	1.3717
4	1.4861	1.5623	1.3336	1.4861	1.7147	.8002	1.3908
5	1.5051	1.5623	1.3527	1.5242	1.2384	.8192	1.3717
6	1.5432	1.5432	1.448	1.5623	1.3146	.8573	1.5432
7	1.9052	2.0767	1.6004	1.7909	1.4289	1.105	1.5432
8	1.7147	1.7337	1.7147	1.829	1.4861	1.1622	1.6956
9	1.6575	1.467	1.3717	1.7528	.6478	1.1241	1.6194
10	2.0767	1.829	2.0005	1.9814	.6478	1.5623	1.8099
11	2.191	2.0005	2.4387	2.0195	.6478	2.0386	2.0767
12	2.3624	2.1338	2.21	2.2291	.6478	1.9624	2.1529
13	1.9814	2.0195	2.2291	2.1338	.6668	1.7909	1.8099
14	2.191	1.8671	2.0005	2.1148	.6859	1.2955	
15	2.3243	2.0195	2.4577	2.0767	.6478	1.9814	
16	1.8861	2.0576	2.21		.6668	1.9052	1.9052
17	1.829	1.9624	2.4006	2.0195	.6668	1.6004	1.9814
18	1.7909	2.0005	2.2862	2.2672	.6668	1.5813	2.0195
19	2.1148	1.9433	2.3815	2.3815	.6859	1.8671	1.9814
20	1.5813	2.0195	2.3624	2.0386	.5906	1.9624	1.7337
21	1.2765	1.3908	1.848	1.4289	.6097	1.448	1.448
22	1.3527	1.3336	1.3336	1.6766	.6287	1.448	1.4289
23	1.3527	1.3146	1.3336	1.5623	.7049	1.4098	1.1812
24	1.5813	1.3527	1.105	1.5242	1.5813	.7811	1.1812
Max	2.3624	2.1338	2.4577	2.3815	1.7147	2.0386	2.1529
Min	1.2765	1.3146	1.086	1.3908	.5906	.724	1.1812
Avg	1.7607	1.7266	1.7996	1.8216	.9860	1.3654	1.6333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 204 / Laxmi Ind

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8954	.743	.9145	.9907	.6097	.6478	.8383
2	.8002	.6859	.7811	.724	.6478	.6478	.8002
3	.724	.8383	.724	.724	.7049	.6478	.8002
4	.7049	.8383	.6859	.6478	.724	.6287	.7049
5	.743	.8192	.8383	.5906	.7049	.6287	.6097
6	.7621	.8002	1.0288	.6478	.6478	.6859	.6478
7	.8573	.8764	.9145	.5906	.5906	.7049	.6478
8	.6478	.7621	.743	.743	.5906	.6287	.6287
9	.9526	.9335	.743	.9526	.5906	.8002	.7811
10	1.0288	.8764	.9526	1.105	.6097	.6478	1.105
11	1.105	.9335	1.0098	1.1431	.6287	.7811	1.1431
12	1.1431	.9526	1.0479	.7811	.6097	.9717	1.1431
13	.8383	.7621	.9145	.7811	.6668	1.0098	.8002
14	.9717	.8954	.9145	.8383	.6478	.7621	.7049
15	1.0479	.724	.9526	.8954	.6478	.7621	1.0098
16	1.1622	.743	.8954	.9717	.6478	.724	.8764
17	1.1622	.5716	1.1241	.9335	.6478	.724	.743
18	.9335	.5716	.8002	.9145	.6097	.6668	.7621
19	1.0288	.8954	.8383	.8002	.6478	.6859	.9526
20	.9145	.9145	1.1431	.9145	.6478	.7811	.8002
21	.8002	.6859	.8002	.8573	.6478	.6668	.6287
22	.8383	.8192	.8002	.6478	.6668	.8764	.9907
23	.8764	.9907	.7811	.6668	.6478	.8954	.9145
24	.8764	.7811	.8954	.724	.4572	.6287	.8954
Max	1.1622	.9907	1.1431	1.1431	.724	1.0098	1.1431
Min	.6478	.5716	.6859	.5906	.4572	.6287	.6097
Avg	.9089	.8089	.8851	.8161	.6351	.7335	.8304

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 205 / K.Sangaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4382	.4191	.4001	.3429	.3429	.4001
2	.3048	.381	.381	.5716	.3429	.3239	.4001
3	.3048	.4191	.4191	.4001	.3048	.4001	.4001
4	.3429	.4572	.4191	.4001	.3048	.4382	.4191
5	.362	.4763	.4763	.4572	.3048	.4763	.4763
6	.4001	.5906	.6097	.5144	.4382		.5716
7	.5335	.743	.724	.6478	.4954	.6668	.6668
8	.6097	.7621	.7049	.6478	.4954	.743	.7049
9	.5906	.5906	.6478	.6287	.4382	.6668	.6478
10	.5716	.5525	.5906	.6097	.4001	.6478	.6478
11	.5716	.6287	.5906	.5906	.4001	.6097	.5906
12	.381		.6097	.5716	.3429	.6097	.5906
13	.5335	.6478		.5525	.4001	.6478	.6097
14	.5525	.5906	.6287	.5525	.3239	.5335	.5906
15	.5525	.6287	.5906	.5335	.362	.5716	.6097
16	.5716	.5716	.5716	.4954	.362	.5525	.5906
17	.5906	.5144	.5716	.5144	.381	.5525	.6097
18	.5525	.5525	.5525	.5906	.4954	.5525	.5716
19		.6859	.6668	.6287	.6287	.6668	.7049
20	.7811	.6859	.6668	.6478	.6668	.6859	.7049
21	.7049	.6478	.6097	.6287	.6668	.6668	.6859
22	.6287	.6287	.6287	.6097	.5906	.6097	.6478
23	.5716	.5335	.4954	.4572	.381	.5525	.5716
24		.4763	.4382	.4191	.4001	.381	.4572
Max	.7811	.7621	.724	.6478	.6668	.743	.7049
Min	.3048	.381	.381	.4001	.3048	.3239	.4001
Avg	.5170	.5740	.5658	.5446	.4279	.5608	.5779



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 206 / Laxmi-Ag Feeder-

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.7621	.8002	.6668	.0381	.0381	.0381
2	.0381	.7621	.8002	.6668	.0381	.0381	.0381
3	.0381	.7621	.8002	.6668	.0381	.0381	.0381
4	.0381	.7811	.8002	.6668	.0381	.0381	.0381
5	.0381	.8002	.8002	.724	.0381	.0381	.0381
6	.0381	.9145	.8954	.8573	.0381	.0381	.0381
7	.0381	1.1812	1.0288	1.0669	.0381	.0381	.0381
8	.0381	1.3527	1.2193	1.2765	.0381	.0381	2.2291
9	.0381	1.3146	1.3146	.9907	.0381	.0381	.0381
10	.0381	.0381	.0381	.0381	.0381		.0381
11	1.5623	.0381	.0381	.0381	1.5623	.5335	1.9814
12	1.6385	.0381	.0381	.0381	1.6766	1.6004	1.9433
13	1.6766	.0381	.0381	.0381	1.5813	1.7147	1.9052
14		.0381	.0381	.0381	1.5432	1.2384	1.8861
15	1.4098	.0381	.0381	.0381	1.6385	1.6766	1.8671
16	1.3717	.0381	.0381	.0381	1.5432	1.7909	1.7718
17	1.5242	.0381	.0381	.0381	1.5432	1.7909	1.6385
18	1.3717	.0381	.0381	.0381	1.4098	1.6956	1.5242
19	.0381	.0381	.0381	.0381	.0381	.0572	.0381
20	.0381	.0572	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.7621	.8192	.6478	.0381	.0381	.0381
Max	1.6766	1.3527	1.3146	1.2765	1.6766	1.7909	2.2291
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.4854	.4144	.4088	.3652	.5462	.5492	.7216

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 207 / S.Kharkhan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4861	.0572	.0572	.0572	1.4289	.8192	1.3717
2	1.4861	.4382	.0572	.0572	1.4289	1.448	1.3908
3	1.4861	.0572	.0572	.0572	1.4289	1.5623	1.3908
4	1.5051	.0572	.0572	.0572	1.467	1.6194	1.3908
5	1.5051	.0572	.0572	.0572	1.4861	1.6575	1.4098
6	1.5432	.0572	.0572	.0572	1.7528	1.7718	1.7147
7	2.0005	.0572	.0572	.0572	1.9433	2.0957	1.9433
8	2.2291	.0572	.0572	.0572	2.2291	2.2291	2.2291
9	2.3053	.0381	.0572	.0381	2.3434	2.3624	2.2862
10	.0381	.0381	.0381	.0572	.0381	.0381	.0381
11	.0381	3.0102	3.0102	2.9531	.0381	.0381	.0191
12	.0381	3.1817	2.8387	2.8959	.0381	.0381	.0381
13	.0381	3.2579	3.1436	2.7816	.0381	.0381	.0381
14	.0381	3.0293	3.1817	2.6863	.0381	.0381	.0381
15	.0381	3.0483	2.8006	2.5911	.0381	.0381	.0381
16	.0381	3.0293	2.6292	2.8006	.0381	.0381	.0381
17	.0381	2.9531	2.6863	2.7816	.0381	.0762	.0381
18	.0381	2.553	2.7054	2.3815	.0381	.0572	.0381
19	.0572	.0572	.0572	.0953	.0572	.0572	.0572
20	.0572	.0572	.0572	.0572	.0572	.0762	.0762
21	.0572	.0572	.0572	.0572	.0572	.0762	.0572
22	.0572	.0572	.0572	.0762	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	.0572
24	1.448	.0572	.0572	.0572	1.3908	1.3336	1.2955
Max	2.3053	3.2579	3.1817	2.9531	2.3434	2.3624	2.2862
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0191
Avg	.7343	1.0550	.9955	.9510	.7303	.7343	.7105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 208 / Kagal Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6287	.6859	.6478	.6478	.5716	.6097	.5906
2	.6097	.6287	.6287	.6478		.5716	.5906
3	.6097	.6287	.6097	.6097	.5525	.5716	.5716
4	.5906	.6478	.6097	.5906	.5525	.5906	.5716
5	.6668	.6478	.6287	.6287	.5716	.5716	.6097
6	.7049	.7621	.7621	.724	.743	.6668	.7811
7	.8764	.8954	.8764	.7811	.7811	.8002	.8573
8	.9145	.9145	.8573	.8383	.9145	.8764	.8383
9	.8192	.8764	.8002	.8383	.8192	.2096	.8192
10	.7621	.7811	.7049	.8192	.7049	.7811	.7811
11	.7811	.8573	.7049	.7811	.7621	.743	.8002
12		.8573	.743	.7049	.6668	.724	.7621
13	.5144	.8192	.724	.6668	.6668	.7049	
14		.743	.6859	.6287	.6859	.7049	.743
15	.8573	.7811	.6859	.5906	.724	.743	.7811
16	.8573	.8192	.6668	.6287	.7621	.7811	.8192
17	.8764	.8383	.743	.724	.724	.8383	.8192
18	.9335	.8573	.8383	.8002	.7811	.8573	.8002
19	1.2384	1.1622	1.1812	1.105	1.105	1.2003	1.1812
20	1.2193	1.2193	1.1431	1.1241	1.1622	1.2193	
21	1.105	1.105	1.0669	1.0098	1.0479	1.0479	1.1622
22	1.0288	.9907	1.0098	.9145	.9526	.9526	1.0098
23		.8383	.8192	.7621	.8002	.7811	.8002
24	.7049	.743	.6859	.7049		.6287	.6478
Max	1.2384	1.2193	1.1812	1.1241	1.1622	1.2193	1.1812
Min	.5144	.6287	.6097	.5906	.5525	.2096	.5716
Avg	.8238	.8375	.7843	.7613	.7751	.7573	.7881

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 402 / 33KV Shahu LIS - KGL-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4001	.5716	.5716	.6287		.9145
4	.6859	.8002	1.0288	.6859		1.3717
5	.743	1.0288	1.0288	.6859		1.3717
6	1.086	1.2574	1.0288	.6859		1.3717
7	1.2003	1.4289	1.3717	.743		1.3717
8	1.1431	1.3146	1.4289	.743		1.4289
9	1.2574	1.3717	1.3717	.6859	1.2003	1.3717
10	1.3146	1.3146	1.3717	.743	1.3717	1.3717
11	1.3146	1.3717	1.3717	.743	1.4289	1.4289
12		1.3717	1.3717	.6859	1.4289	1.4289
13	1.3146	1.3717	1.3717	.6859	1.3717	1.3717
14	1.3146	1.3717	1.3717	.6859	.6859	1.3717
15	1.3146	1.3146	1.3717	.6859	1.3717	1.3717
16	1.3146	1.3146	1.3717	.6859	1.3146	1.3717
17	1.3146	1.2574	.9717	.5144	1.3146	1.3717
18	.743	.8002	.1715	.1715	.743	.8002
Max	1.3146	1.4289	1.4289	.743	1.4289	1.4289
Min	.4001	.5716	.1715	.1715	.6859	.8002
Avg	1.0974	1.2038	1.1610	.6537	1.2231	1.3181

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 403 / 33 KV Padmavati

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.3717	1.2574	1.3717	1.2574		2.2862
2		1.2574	1.829	1.2574	2.0576		2.1719
3		1.829	2.0576	2.4006	2.2862		2.1719
4		2.1148	1.3717	2.2862	1.3717		2.2862
5		2.4006	1.829	1.2574	2.4006		2.4006
6		2.5149	1.3717	1.3717	1.829		2.2862
7		2.5149	2.0576	1.4861	1.2574		2.2862
8	1.7147	1.4861	1.1431	1.9433	.8002		1.6004
9	1.7147	1.829	1.3717	2.2862	.8002	2.0576	1.0288
10	1.3717	1.9433	1.3717	2.4006	.8002	2.2862	2.1719
11	1.3717	2.0576		1.3717	.8002	2.4006	1.4289
12		2.2862	1.3717	2.4006	.5716	2.2862	.6859
13	1.3717	1.2574	1.2574	1.1431	6.5158	2.4006	1.0288
14	2.2862	1.3717	1.3717	1.1431	.5716	1.7147	1.2574
15	1.3717	2.4006	1.3717	1.1431	.5716	.9145	1.4861
16	1.1431	1.2574	1.2574	2.1719	.5716	.4572	1.4861
17	1.1431	1.2574	.5716	1.829	.5716	1.3717	1.4861
18	1.3717	1.2574	.5716	.5716	.5716	.5716	.6859
19	1.4861	.4572	.8002	.8002		.8002	.5716
20	1.9433	.8002	.8002	.8002	.6859	.8002	.5716
21	1.9433	.9145	.8002	.8002	.8002	.8002	.5716
22	1.1431	.5716	1.0288	1.0288	.8002	.8002	2.1719
23	1.3717		2.1719	2.1719	.8002	1.3717	2.4006
24		1.3717	2.4006	2.4006	1.3717		1.9433
Max	2.2862	2.5149	2.4006	2.4006	6.5158	2.4006	2.4006
Min	1.1431	.4572	.5716	.5716	.5716	.4572	.5716
Avg	1.5165	1.5879	1.3668	1.5766	1.3071	1.4022	1.6028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 201 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.9052	1.7147	1.8671	1.8671	1.5623	1.8099
2	1.5242	1.7909	1.6194	1.6766	1.7528	1.5813	1.448
3	1.5051	1.7147	1.6004	1.6575	1.6575	1.5623	1.5242
4	1.5051	1.6194	1.5623	1.6575	1.5623	1.5813	1.4861
5	1.5051	1.5813	1.6004	1.6575	1.5432	1.5813	1.5623
6	1.5242	1.6004	1.5432	1.5242	1.4861	1.5623	1.5432
7	1.5051	1.5813	1.4861	1.5051	1.4289	1.5623	1.5051
8	1.6385	1.5242	1.5242	1.4861	1.467	1.5242	1.5242
9	2.0576	1.8671	1.7147	1.8861	1.5051	1.9814	1.7909
10	2.0005	1.9052	2.0195	2.2672	1.448	2.553	2.1719
11	2.0957	2.0386	2.5149	2.0195	1.448	2.9721	2.0957
12	2.21	2.0576	1.8671	2.0005	1.4289	2.4387	2.0005
13	1.7718	1.829	1.7337	1.6004	1.4861	1.8099	1.829
14	2.1338	2.3243	2.4958	2.0386	1.467	2.2481	2.7816
15	1.7337	1.9814	2.4006	2.0195	1.448	2.3053	2.0386
16	1.8861	2.1529	2.0767	1.7147	1.467	1.8861	2.3815
17	1.829	2.2862	1.9433	2.2481	1.467	1.8861	2.2862
18	1.5813	1.9814	1.829	1.4289	1.5051	1.829	1.8861
19	1.7909	1.9433	1.9052	1.8671	1.5051	1.9433	1.6575
20	2.0195	1.9052	1.8099	2.0005	1.5051	1.6766	1.8671
21	1.6766	1.6575	1.5051	1.8861	1.448	1.8099	1.8671
22	1.9624	1.4289	1.5623	1.5051	1.5051	1.7909	1.9433
23	1.9814	1.8861	1.8099	1.5242	1.5242	1.8671	1.6956
24	1.5813	1.9624	2.0005	1.9624	1.9052	1.5623	1.848
Max	2.21	2.3243	2.5149	2.2672	1.9052	2.9721	2.7816
Min	1.5051	1.4289	1.4861	1.4289	1.4289	1.5242	1.448
Avg	1.7758	1.8552	1.8266	1.7917	1.5345	1.8782	1.8560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 202 / 11KV West Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5149	2.3815	2.0957	2.3624	2.3815	1.7909	2.2862
2	2.5149	2.2862	2.4768	2.3624	2.2862	1.829	2.2862
3	2.4768	2.3815	2.2862	2.2862	2.2862	1.829	2.0957
4	2.3624	2.2862	2.0957	2.2862	2.0957	1.7909	2.2862
5	2.3243	2.3815	2.2862	2.2862	2.0005	1.7528	2.0957
6	2.2481	2.191	2.0957	2.191	1.9052	1.829	2.0957
7	2.2481	2.0957	2.2862	2.2862	1.9052	1.9624	2.0957
8	2.0957	2.3815	2.2862	2.191	1.8099	1.9052	2.6673
9	3.0864	3.2388	3.0483	3.4294	1.8099	2.191	3.0864
10	4.0009	3.8104	4.2867	3.3341	1.829	3.3341	4.1533
11	3.8104	4.039	4.2867	3.1436	1.7718	3.6199	4.4582
12	3.0483	3.2198	3.7151	3.677	1.7528	3.6199	4.02
13	3.6199	2.9721	3.5246	3.3341	1.848	2.7625	2.6673
14	4.1914	3.9057	3.6199	3.8104	1.848	3.2388	4.1914
15	4.1914	3.8866	4.2867	3.315	1.9433	3.9057	4.039
16	3.8104	3.7913	4.0009	3.3341	1.7909	3.8104	4.2867
17	3.7913	3.6199	3.8104	3.0483	1.829	3.0483	3.7151
18	3.296	3.4294	3.4294	3.0483	1.8861	2.8578	3.1436
19	2.8578	3.0483	2.8578	2.572	1.829	2.2862	2.3815
20	2.0957	2.2862	2.4768	2.0957	1.829	2.2862	2.3815
21	2.2862	2.2862	2.2862	2.0957	1.7909	1.9052	2.0957
22	2.4768	2.4768	2.4768	2.191	1.8671	2.0957	2.2862
23	2.5911	2.6673	2.4387	2.2862	1.829	2.2862	2.4768
24	2.4006	2.4768	2.2862	2.553	2.4768	1.829	2.2862
Max	4.1914	4.039	4.2867	3.8104	2.4768	3.9057	4.4582
Min	2.0957	2.0957	2.0957	2.0957	1.7528	1.7528	2.0957
Avg	2.9308	2.8975	2.9475	2.7300	1.9417	2.4903	2.8991

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 203 / KANERI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6478	.5716	.6668	.7621	.6097	.5906
2	.6478	.6097	.5335	.6287	.5335	.6097	.5525
3	.6287	.5716	.4954	.6097	.4763	.6097	.5335
4	.6287	.6097	.5525	.6097	.4763	.6287	.4954
5	.6287	.6478	.6097	.6097	.6097	.6478	.6097
6	.7811	1.1431	.8383	.743	.7621	.9526	.7811
7	1.2003	.9907	1.2574	.9335	.9335	1.0479	1.2384
8	.8954	1.1241	1.1622	1.1812	.8192	1.2574	.9717
9	1.2765	1.2765	1.1812	1.3336	.743	1.1812	1.1431
10	1.7147	1.3717	1.8671	1.2574	.4763	1.2193	1.0288
11	1.7337	1.3908	1.3527	1.5242	.5525	1.2765	1.105
12	1.7718	1.6766	1.1812	1.6766	.4382	1.2574	1.3336
13	1.1622	1.2193	.9526	1.0288	.381	1.5242	1.0669
14	1.4861	1.3336	1.4861	1.5051	.4382	1.5242	1.6194
15	1.086	1.5242	1.2193	1.3908	.4572	1.0479	1.3146
16	1.1812	1.2193	1.7147	1.2384	.381	1.0479	1.2765
17	1.6385	1.4098	1.2193	1.4289	.4763	1.4861	1.3336
18	1.3717	.8954	1.1241	1.2955	.4954	1.2574	1.1812
19	1.4289	.9907	1.6004	1.3908	.7049	1.3146	1.6385
20	1.4289	1.0479	1.1241	1.2193	.8002	1.1431	1.105
21	.8764	1.0288	.9907	1.5623	.7621	.9717	1.2003
22	1.2003	1.448	1.2384	1.2955	.8002	1.2384	1.2003
23	1.086	1.0288	.9145	.9145	.7049	1.2765	.8192
24	.6859	.6668	.6668	.8764	.8192	.6287	.6859
Max	1.7718	1.6766	1.8671	1.6766	.9335	1.5242	1.6385
Min	.6287	.5716	.4954	.6097	.381	.6097	.4954
Avg	1.1328	1.0780	1.0772	1.1217	.6168	1.0733	1.0344



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 204 / 11 KV PANCHAGANGA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		2.6673	2.0957	1.0479	2.2862
2		2.6673	2.0957	1.0479	2.4768
3		2.2862	1.9052	1.0479	2.2862
4		2.2862	1.8099	1.0479	2.4768
5		2.2862	2.0005	1.0479	2.4768
6		2.3815	1.9052	1.0479	2.6673
7		2.2862	1.9052	1.0479	1.9052
8		2.191	1.2384	1.1431	2.0957
9		1.5242	1.1431	2.0957	2.6673
10		2.4768	.9526	2.0005	2.4768
11		2.6673		1.7147	2.572
12	1.9052	2.3815		1.5242	2.3815
13	2.0957	2.4768		2.0957	2.4768
14	2.572	2.6673	1.0479	2.4768	2.4768
15	2.2862	1.9052	1.2384	2.7625	3.0483
16	1.8099	2.2481	1.0479	2.8578	2.8578
17	2.572	2.0957	1.1431	2.6673	3.0483
18	2.4768	2.2862	1.1431	2.6673	1.9052
19	2.6673	2.4768	1.1431	2.2862	2.4768
20	1.9052	1.7147	1.1431	2.0957	2.0957
21	2.572	2.4768	1.1431	1.9052	1.9052
22	2.6673	1.7147	1.1431	2.8578	2.6673
23	2.6673	2.0957	1.1431	2.6673	2.4768
24		1.9052	1.7147	1.0479	1.9052
Max	2.6673	2.6673	2.0957	2.8578	3.0483
Min	1.8099	1.5242	.9526	1.0479	1.9052
Avg	2.3497	2.2569	1.4334	1.8417	2.4212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 205 / 11KV MainRoad

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8764	.7621	.8764	.8573	.7811	.7811
2	.8573	.8573	.8002	.8383	.9145	.7811	.8954
3	.8573	.8573	.8192	.8192	.7811	.7811	.8573
4	.8573	.8002	.8002	.8192	.8383	.7811	.8002
5	.8573	.8002	.8383	.8192	.724	.7811	.7621
6	.7811	.8573	.8573	.7621	.6859	.8002	.743
7	.8383	.8002	.8573	.7811	.6668	.8192	.8954
8	1.2193	1.3527	1.0288	.9526	.8002	.8192	1.4289
9	.8764	1.1431	1.3717	1.4098	.8002	.7049	1.3146
10	1.1812	1.467	1.7718	1.5432	.8192		1.4861
11	1.3336	1.7147	1.2955	1.5813		1.467	1.2193
12	1.5813	1.7337	1.9052	1.5813		1.3336	1.2003
13	.9335	1.467	1.6575	1.4861		1.086	1.1431
14	1.3908	1.4289	1.4289	1.2384	.743	.9717	1.467
15	1.448	1.0288	1.2574	1.6194	.724	1.105	1.5813
16	1.4098	1.2384	1.3527	1.3717	.724	1.1622	1.3717
17	1.3146	1.4861	1.4861	1.2955	.7049	1.1241	1.7147
18	1.1812	1.105	1.2384	1.0288	.7621	1.0288	1.2574
19	1.1622	.9526	1.0669	1.1241	.743	1.2574	1.105
20	.8002	.8954	.8002	.9145	.743	1.1431	.9907
21	1.0288	1.105	1.0669	1.0669	.7811	1.0669	1.1241
22	.8764	.9335	.8954	1.105	.7811	1.0669	1.086
23	.9145	.9526	1.0479		.7621	.9526	1.467
24	1.1622	.8954	.8573	.8002	.7049	.7811	.9335
Max	1.5813	1.7337	1.9052	1.6194	.9145	1.467	1.7147
Min	.7811	.8002	.7621	.7621	.6668	.7049	.743
Avg	1.0748	1.1145	1.1360	1.1232	.7648	.9824	1.1511

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 206 / 11KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1719	1.7528	1.9433	2.21	2.1719	1.2955	2.0957
2	1.9052	1.7528	2.0957	2.21	1.9814	1.2574	2.0576
3	1.8671	1.7147	1.9052	2.1719	2.0957	1.2574	1.9433
4	1.829	1.7147	1.7909	2.1338	1.8671	1.2574	1.9052
5	1.7909	1.7147	1.9052	2.1338	1.9433	1.2574	1.9433
6	1.829	1.448	2.1719	1.829	2.0576	1.3717	1.9814
7	2.0957	1.7528	2.0576	2.21	1.6766	1.448	1.6766
8	1.9052	1.7147	1.7909	1.9814	1.448	1.5242	1.7909
9	2.3243	2.1719	2.3624	2.7435	1.3717	1.6766	2.2862
10	2.2862	2.21	2.7816	2.7816	1.3717	2.0576	2.6673
11	2.4768	2.5911	2.8959	2.553	1.4098	2.2862	2.1338
12	2.7816	2.5149	2.553	2.3624	1.2955	2.5149	2.6673
13	2.3243	2.3624	2.2862	2.21	1.3336	2.2862	2.0957
14	2.7816	2.7435	2.3243	2.4387	1.2955	2.5149	2.553
15	2.7816	2.3243	2.5149	2.0957	1.2955	2.5149	2.4768
16	2.6673	2.4768	2.4006	2.4768	1.3336	2.0957	2.5149
17	2.2481	2.4006	2.0576	2.4387	1.3336	2.0957	2.21
18	2.3243	2.0576	2.5911	2.4768	1.2955	2.1719	2.553
19	2.1338	1.9433	2.2481	2.0576	1.3336	1.9052	2.1338
20	1.6385	1.5242	1.6766	1.6004	1.2574	1.3336	1.7528
21	1.6766	1.7528	1.7147	1.7147	1.3336	1.6004	1.8671
22	2.0957	2.0195	1.829	1.9052	1.3336	1.6004	1.7909
23	2.2862	2.1719	1.9433	2.1719	1.3336	1.829	2.21
24	2.1719	1.7528	2.21	2.1338	2.21	1.2955	1.9814
Max	2.7816	2.7435	2.8959	2.7816	2.21	2.5149	2.6673
Min	1.6385	1.448	1.6766	1.6004	1.2574	1.2574	1.6766
Avg	2.1830	2.0243	2.1688	2.2100	1.5575	1.7687	2.137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 207 / 11 KV UJALAIWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4191	.4191	.381	.4382	.3429	.381	.4191
2	.4191	.381	.381	.4001	.3429	.362	.4001
3	.4191	.362	.4191	.4001	.3048	.3429	.381
4	.4191	.381	.4572	.4001	.3048	.3429	.4572
5	.4191	.4001	.4954	.4001	.4191	.362	.4954
6	.5335	.5144	.5525	.4763	.4572	.4572	.5525
7	.6287	.6287	.6287	.5906	.5716	.5716	.743
8	.6478	.6097	.5906	.6287	.5525	.5716	.6287
9	.5716	.5525	.5716	.5906	.4954	.5716	.5335
10	.6478	.6668	.5906	.6097	.4954	.5906	.5906
11	.5906	.7049	.6097	.5716	.4191	.5335	.6478
12	.5525	.6668	.5335	.6287	.4382	.6097	.6668
13	.5906	.6668	.6097	.6097	.4001	.5716	.5906
14	.4763	.5335	.5144	.4954	.362	.4763	.5144
15	.5525	.5335	.6097	.4954	.362	.6097	
16	.6097	.4572	.5716	.4954		.5716	
17	.5906	.6097	.6097	.4763	.3429	.5716	
18	.6097	.5716	.5906	.5525	.4572	.5525	
19	.6859	.6478	.7049	.7621	.5525	.724	.7621
20	.743	.724	.724	.7049	.6097	.6859	.6859
21	.6859	.7049	.7049	.5906	.6097	.6668	.7049
22	.6668	.6478	.6478	.5525	.5144	.6287	.6668
23	.5525	.5335	.5716	.4382	.4572	.4954	.5144
24	.4763	.4572	.4572	.5144	.381	.4191	.4382
Max	.743	.724	.724	.7621	.6097	.724	.7621
Min	.4191	.362	.381	.4001	.3048	.3429	.381
Avg	.5628	.5573	.5636	.5343	.4432	.5279	.5697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 208 / KANERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1334	.1143	1.0288	1.3717	1.1431	.2096	.2286
2	.1334	.1334	.9907	1.3717	1.1431	.1905	.1905
3	.1334	.1334	.9526	1.3717	1.1622	.1524	.1905
4	.1334	.1334	1.1431	1.3717	1.2003	.1715	.2286
5	.1334	.1334	1.2193	1.3717	1.2384	.1334	.2286
6	.1715	.1524	1.2955	1.5432	1.3908	.1524	.2286
7	.1715	.1334	1.5813	1.8861	1.6194	.1715	.1524
8	.1524	.1715	2.0386	1.8671	2.1338	.2286	1.5623
9	.1905	.1524	1.9814	2.0005	1.8671	.1524	.2286
10	.1905	.1715	.1143	.1143	.1905	.2858	.2667
11	2.2862	.1524	.2667	.2858	2.0957	2.0386	2.2291
12	2.2481	.1524	.2477	.2477	2.1529	2.191	1.9624
13	2.2672	.1524	.2858	.1143	2.0576	2.21	2.2672
14	1.848	.1334	.2286	.1334	1.829	2.1529	1.9814
15	1.9433	.1334	.2667	.1143	2.0005	2.3053	2.1338
16	2.1529	.0953	.2858	.1334		2.2862	2.191
17	1.6194	.1334	.2858	.2858	1.9052	2.2862	2.191
18	1.6575	.1524	.1334	.1334	2.0195	1.7528	2.191
19	.1334	.1334	.1524	.1334	.1524	.1143	.1715
20	.1334	.0953	.1524	.1334	.1524	.1143	.1334
21	.1334	.1143	.2858	.1334	.2667	.1143	.1524
22	.1143	.1334	.3048	.1143	.2477	.1143	.1524
23	.1143	.1334	.2667	.1143	.2667	.2286	.1524
24	.1334	.1143	1.0098	1.2765	1.1622	.2286	.2477
Max	2.2862	.1715	2.0386	2.0005	2.1529	2.3053	2.2672
Min	.1143	.0953	.1143	.1143	.1524	.1143	.1334
Avg	.7637	.1358	.6883	.7343	1.2781	.8327	.9026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 209 / UJALAIWADI SHETI PUMP  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8383	.7621	.0572	.0572	.0381	.7621	.7049
2	.8192	.7621	.0572	.0572	.0381	.7811	.743
3	.8002	.8002		.0572	.0381	.7811	.7621
4	.8002	.8002	.0572	.0572	.0381	.8002	.7811
5	.8002	.8002	.0572	.0572	.0381	.8383	.8192
6	.9907	.8764	.0572	.0572	.0572	1.0288	.8573
7	1.3717	1.1812	.0762	.0572	.0762	1.2384	1.3336
8	1.5813	1.3908	.0762	.0572	.0572	1.5242	1.6194
9	1.5432	1.467	.0953	.0762	.0762	1.2384	1.5623
10	.0572	.1334	.1334	.0572	.0572	.0572	.0572
11	.0572	1.5432	1.7147	1.6956	.0572	.0572	.0572
12	.0572	1.448	1.7147	1.6385	.0381	.0572	.0572
13	.0572	1.5242	1.7147	1.6956	.0381	.0572	.0381
14	.0381	1.4289	1.6766	1.6004	.0572	.0572	.0381
15	.0762	1.0479	1.6766	1.4861	.0572	.0572	.0381
16	.0762	1.2384	1.6385	1.4861	.0381	.0572	.0572
17	.0572	1.5242	1.5813	1.5051	.0572	.0572	.0572
18	.0762	1.4289	1.3908	1.5242	.0762	.0572	.0762
19	.0953	.0572	.0572	.0762	.0762	.0762	.0762
20	.0762	.0762	.0572	.0572	.0572	.0762	.0762
21	.0572	.0572	.0572	.0572	.0572	.0953	.0762
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0381	.0572	.0572
24	.8192	.743	.0572	.0572	.0381	.7621	.724
Max	1.5813	1.5432	1.7147	1.6956	.0762	1.5242	1.6194
Min	.0381	.0572	.0572	.0572	.0381	.0572	.0381
Avg	.4692	.8836	.6138	.5660	.0524	.4430	.4469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 201 / 11KV Randeviwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2517	.0566	.0324	.0572	1.3413	1.4403	1.5546
2	1.2346	.0566	.0324	.0572	1.3077	1.406	1.5061
3	1.2174	.0566	.0324	.0572		1.3717	
4	1.2346	.0566	.0324	.0572			
5	1.286	.0566	.0486	.0572		.4287	
6	1.3717	.0566	.0486	.0572		.5144	.2915
7	1.5261	.0566	.0486	.0572		.7202	.6478
8	1.6118	.0566	.0486	.0572		.8573	.7449
9	1.7661	.0566	.0486	.0572	1.2209	2.0405	.7287
10	.0572	.0566	.0486	.0572	1.7901	1.9433	2.0729
11	.0566	2.4486	2.572	2.4827	.0572	.0486	2.0243
12	.0566	2.753	2.7263	2.4669	.0572	.0324	2.1376
13		2.6558	2.5892	2.372	.0572	.0324	2.1376
14		2.6235	2.5377	2.3525	.0572	.0324	.0566
15		2.4615	2.572	2.2405	.0572	.0324	.0566
16		2.4291	2.4691	2.2186	.0572	.0324	.0566
17		2.2834	2.7435	2.2186		.0324	.0566
18		2.2672	2.4348	2.0891	.0572	.0486	.0566
19	.0566	.0648	.0572	.0566	.0572	.0648	.0566
20	.0566	.0648	.0572	.0566	.0572	.0648	.0566
21	.0566	.0486	.0572	.0566	.0572	.0486	.0566
22	.0566	.0486	.0572	.0566	.0572	.0486	.0566
23	.0566	.0486	.0572	.0566	.0572	.0486	.0566
24	1.2689	.0566	.0324	.0572	1.358	1.4746	1.587
Max	1.7661	2.753	2.7435	2.4827	1.7901	2.0405	2.1376
Min	.0566	.0486	.0324	.0566	.0572	.0324	.0566
Avg	.7901	.8675	.8910	.8064	.4532	.5550	.7619

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 202 / M Sangaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.499	.5316	.6859	.5729	.5335	.4115
2	.5335	.4481	.4801	.5906	.499	.5335	.3601
3	.5525	.4481	.4801	.5716	.4481	.5144	.3601
4	.6287	.5544	.5316	.5716	.5544	.5716	.4115
5	.743	.7133	.6687	.724	.7133	.4763	.5144
6	.9242	.8505	.8573	.8002	.7602	.9054	.823
7	1.0374	.9991	.9259	1.0642	.9036	.9997	.9602
8	1.0456	.9882	.9602	.9795	.8413	1.0642	.9602
9	.8131	.8939	.7716	.924	.8059	.9055	.823
10	.7133	.7133	.6173	.8131	.7602	.6001	.6859
11	.6401	.7522	.7316	.695	.6219	.6001	.583
12	.6099	.6859	.6516	.7133	.543	.5316	.7602
13	.7133	.6859	.7059	.5544	.5853	.6687	.7133
14	.6653	.6516	.3658	.7133	.4481	.6344	.6653
15	.6099	.4801	.7316	.7316	.5853	.6344	.7133
16	.7133	.6173	.7682	.7316		.6516	.7059
17	.7133	.5144	.7865	.7316	.6584	.6859	.8059
18	.7682	.6859	.6722	.6099	.6767	.6859	.7602
19	.9991	.8916	1.0456	.9036	.8962	.7373	.9568
20	1.0402	1.0288	1.1389	1.0517	1.0185	1.0288	1.0517
21	.9465	.7716	1.0562	.9465	.9054	.9259	.9036
22	.8939	.8573	.8383	.8939	.9054	.8573	.9036
23	.6653	.6173	.6668	.6584	.7167	.6687	.6584
24	.5335	.5544	.6173	.7356	.6099	.5525	.4801
Max	1.0456	1.0288	1.1389	1.0642	1.0185	1.0642	1.0517
Min	.5335	.4481	.3658	.5544	.4481	.4763	.3601
Avg	.7515	.7043	.7334	.7665	.6969	.7070	.7071



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 203 / Sulkud AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	1.0802	.9393	1.0814	.0566	.0762	.0324
2	.0572	1.0402	.9393	1.1012	.0566	.0572	.0324
3	.0572	1.0402	.9717	1.1012	.0566	.0572	.0324
4	.0572	1.1317	1.0202	1.1012	.0566	.0572	.0324
5	.0572	1.2209	1.1012	1.1984	.0754	.0572	.0486
6	.0572	1.358	1.166	1.3272	.0943	.0762	
7	.0762	1.4918	1.3441	1.491	.0754	.0762	.0486
8	.0953	1.6575	1.6032	1.6518	.0754	.0762	.0486
9	.0762	1.6907	1.668	1.6221	.0754	.0762	.0486
10	.0762	.0754	.081	.0762	.0754	.0648	.0486
11	2.0567	.0754	.0572	.0754	2.5484	2.7435	2.5425
12	2.1605	.0648	.0572	.0754	2.5149	2.5911	2.6566
13	2.2138	.0648	.0762	.0754	2.2874	2.6397	2.6726
14	2.1925	.0648	.0762	.0754	2.3371	2.5101	2.5286
15	2.0972	.0648	.0762	.0566	2.3205	2.5425	2.4806
16	2.0645	.0648	.0762	.0566	2.13	2.4453	2.4129
17	1.917	.0648	.0572	.0566	2.1628	2.3805	2.3644
18	1.7532	.0486	.0572	.0566	2.1714	2.2834	2.2672
19	.0754	.0648	.0953	.0754	.0953	.081	.0754
20	.0943	.081	.0762	.0943	.0953	.081	.0943
21	.0943	.081	.0762	.0943	.0762	.0648	.0943
22	.0754	.0648	.0762	.0943	.0762	.0486	.0754
23	.0754	.0486	.0762	.0754	.0762	.0486	.0754
24	.0572	1.1145	.9717	1.0486		.0762	.0486
Max	2.2138	1.6907	1.668	1.6518	2.5484	2.7435	2.6726
Min	.0572	.0486	.0572	.0566	.0566	.0486	.0324
Avg	.7331	.5731	.5308	.5734	.8517	.8838	.9027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 204 / 11 KV LINGNOOR (VG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0566	.0566	.0514	.0739	.0566	.0754	.0514
2	.0554	.0566	.0514	.0554	.0566	.0754	.0514
3	.0554	.0566	.0514	.0554	.0566	.056	.0514
4	.056	.0566	.0514	.056	.0566	.056	.0514
5	.0754	.1132	.0857	.0754	.0943	.0566	.0686
6	.1143	.168	.12	.1143	.132	.1132	.1029
7	.1524	.168	.1372	.1334	.1509	.1509	.12
8	.1307	.1494	.1029	.1307	.0943	.1307	.12
9	.1097	.1132	.0857	.0924	.0943	.0934	.0857
10	.0732	.0943	.0686	.0943	.0943	.0857	.0686
11	.0754		.0747	.0754	.0554	.0686	.0686
12	.0754	.0857	.0934	.0943	.0566	.0686	.0754
13	.0754	.0857	.0934	.0943	.0572	.0686	.0754
14	.0754	.0857	.0762	.0943	.0572	.0686	.0754
15	.0754	.0857	.0754	.0754	.0572	.0514	.0754
16	.0566	.0857	.0762	.0754	.0572	.0514	.0754
17	.0566	.0857	.0762	.0754	.0762	.0514	.0754
18	.0754	.0857	.0572	.0754	.0953	.0857	.0754
19	.1494	.1543	.1663	.1494	.1494	.1372	.1494
20	.1867	.1715	.1698	.1867	.1715	.1543	.1867
21	.1867	.1372	.1715	.1867	.1524	.1543	.1867
22	.1494	.12	.1143	.1494	.1334	.12	.1494
23	.1132	.0857	.0953	.0943	.0943	.0857	.0943
24	.0762	.0754	.0686	.0739	.0566	.0754	.0686
Max	.1867	.1715	.1715	.1867	.1715	.1543	.1867
Min	.0554	.0566	.0514	.0554	.0554	.0514	.0514
Avg	.0961	.1033	.0923	.0992	.0899	.0889	.0918

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 205 / 11 KV RTO Check Post  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)
1		.0171
2		.0171
3		.0171
4		.0171
5		.0171
6		.0171
22	.0171	
23	.0171	
24		.0171
Max	.0171	.0171
Min	.0171	.0171
Avg	.0171	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 201 / 11KV Arya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8099	2.1125	1.5223	1.307	1.4022	.7649	1.9791
2	1.9589	2.1502	1.6289	1.3957	1.5364	.7335	2.0748
3	2.1098	2.2257	1.7013	1.3352	1.5927	.7602	2.1098
4	1.9418	2.1879	1.7194	1.2209	1.5546	.7602	1.9605
5	1.8671	2.1502	1.6476	1.2003	1.5746	.7183	1.7741
6	1.7193	2.0748	1.8461	1.1633	1.5939	.7305	1.5249
7	1.387	1.9239	1.3466	1.1797	.5239	.8387	1.3413
8	1.4937	2.0748	1.6651	1.7353	.8939	.9682	1.5746
9	1.448	1.6032	1.3937	1.7353	.4081	2.0725	2.3899
10	1.7364	2.2779	1.7924	2.4143	.2801	2.0538	2.4272
11	2.8769	2.3339	2.2405	2.3011	.6602	1.9418	2.4646
12	2.9912	2.838	2.6139	2.3388	.5441	2.5086	2.6139
13	2.32	2.3339	2.4646	1.9791	.4725	2.452	2.0538
14	1.7002	2.4272	2.4897	1.4449	.4572	2.6699	2.2405
15	2.1879	2.4272	2.6972	2.0748	.4641	2.6029	2.4646
16	2.3954	2.0538	2.4832	2.2445	.4954	1.9978	2.1125
17	2.2291	1.7924	2.3339	2.2445	.1677	2.3339	2.5652
18	2.2405	1.7918	2.3765	2.4143	.176	2.8567	2.4897
19	2.3152	2.0165	2.1691	2.4272	.2683	1.9427	2.452
20	2.3525	2.1845	1.9239	2.3954	.4024	1.9044	2.5463
21	2.4143	2.3899	1.9805	2.3388	.2138	1.9616	2.5652
22	2.2634	2.0144	1.9805	1.922	1.1789	1.8298	2.5463
23	2.8292	2.5274	2.1691	1.4723	1.2003	1.9978	2.3577
24	1.6118	1.8484	2.0144	1.9805	1.5684	.7788	1.2239
Max	2.9912	2.838	2.6972	2.4272	1.5939	2.8567	2.6139
Min	1.387	1.6032	1.3466	1.1633	.1677	.7183	1.2239
Avg	2.0916	2.1567	2.0084	1.8444	.8179	1.6741	2.1605

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 202 / 11 KV Managal Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3384	.4572	.4298	.3292	.4572	.2239	.4477
2	.3239	.4382	.4191	.2926	.4115	.2328	.3944
3	.3134	.4382	.4191	.2561	.3681	.2229	.3277
4	.2743	.4001	.4024	.2926	.3001	.2418	.3086
5	.2542	.3887	.4001	.3292	.3001	.2763	.3403
6	.3841	.3963	.4858	.5304	.2892	.2096	.5251
7	.9145	.663	.9145	.8779	.2507	.8042	.8368
8	1.4089	1.4998	1.5261	1.2407	.4908	1.1574	1.4754
9	1.5927	1.5089	1.7375	1.7918	.2928	1.3443	1.8298
10	1.7741	1.9418	2.3101	2.1253	.2801	2.0119	1.8671
11	1.9404	2.0911	1.5339	2.0144	.2572	2.2592	1.9978
12	2.2177	2.1658	1.9774	1.7924	.2401	2.2965	1.8671
13	2.0119	1.7551	1.9163	1.439	.3475	2.0119	1.7177
14	2.0351	2.2032	1.9404	1.8107	.285	2.2779	2.0538
15	2.0698	1.9044	1.6095	2.0911	.3258	2.2405	2.0538
16	2.1285	1.8671	1.9978	1.9959	.333	2.2131	1.8484
17	1.8656	1.4937	2.0119	1.7193	.1372	1.7924	1.6095
18	1.3817	1.9728	1.9993	1.4723	.14	1.4899	1.6278
19	1.1949	1.7187	1.531	1.4243	.1463	1.1869	1.5775
20	1.6804	.7335	.663	1.0682	.1646	1.1271	.7773
21	.4755	.4664	.4382	.6382	.2012	.6706	.7042
22	.4382	.5927	.4755	.5304	.2427	.5239	.4572
23	.4854	.4119	.362	.4656	.2147	.4298	.3475
24	.4207	.3841	.3734		.439	.2572	.4755
Max	2.2177	2.2032	2.3101	2.1253	.4908	2.2965	2.0538
Min	.2542	.3841	.362	.2561	.1372	.2096	.3086
Avg	1.1635	1.1622	1.1614	1.1534	.2881	1.1459	1.1445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 203 / 11 KV KORGAONKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6413	.7167	.6668	.7167	.679	.7468	.6859
2	.6535	.7167	.6602	.7167	.6722	.7545	.6979
3	.6722	.7189	.6602	.7167	.6348	.6979	.6535
4	.6283	.7167	.6478	.7167	.6161	.7049	.6413
5	.6283	.679	.6478	.7167	.5975	.6478	.679
6	.6722	.6602	.6224	.6979	.6161	.6224	.6979
7	.6535	.7545	.7545	.679	.6722	.6036	.7356
8	.679	.7922	.7621	.7545	.7167	.6859	.7655
9	.7468	.7922	.8192	.7167	.8676	.7049	.7842
10	.9526	.9335	.9808	.8299	.9808	.9619	.8962
11	1.0185	.9709	.9997	.8192	1.0374	.9717	.9335
12	.9335	.9335	.8865	.8002	.9431	.8002	.8962
13	.8954	.8962	.8676	.743	.9054	.8488	.7468
14	1.1317	.8215	.9522	.7545	.9054	.9242	.8962
15	1.1622	.8589	.9242	.7545	.8676	.9431	.8962
16	1.1622	.9335	.9149	.6668	.9054	.9431	.8488
17	1.105	.9709	.8488	.7621	1.0185	.9997	.8488
18	.9335	.9717		.6602	.9431	1.0562	.8299
19	.9709	.9526	.8299	.7545	.8764	.9431	.7922
20	.9335	.7811	.7545	.7167	.9335	1.0185	.7545
21	.8488	.7621	.7922	.6979	.8573	.7049	
22	.7167	.724	.7167	.679	.8764	.7356	.7545
23	.6602	.6859	.6413	.679	.8383	.6979	
24	.5975	.7167	.6413	.679	.6535	.8383	.6602
Max	1.1622	.9717	.9997	.8299	1.0374	1.0562	.9335
Min	.5975	.6602	.6224	.6602	.5975	.6036	.6413
Avg	.8332	.8108	.7822	.7262	.8173	.8148	.7770

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 204 / 11 KV Silver Zone

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	1.8484	1.8671	1.7375	1.6057	1.6804	1.8298
2	1.7737	1.8484	1.8671	1.7918	1.587	1.6804	1.7741
3	1.7364	1.8484	1.8673	1.7918	1.587	1.773	1.7558
4	1.6632	1.8107	1.8673	1.7918	1.5339	1.7541	1.7372
5	1.5912	1.773	1.6991	1.773	1.531	1.7551	1.6827
6	1.6448	1.6827	1.6644	1.6975	1.5154	1.6617	1.6827
7	1.5546	1.6975	1.6644	1.5546	1.5181	1.6644	1.6244
8	1.6804	1.8484	1.5893	1.4998	1.3575	1.5223	1.6617
9	1.7924	1.9239	1.9035	1.7353	1.4266	1.8107	1.8858
10	2.1502	2.2032	2.0538	1.9239	1.5154	2.1502	
11	2.3388	2.2405	2.1691	2.0182	1.5729	2.1502	2.2032
12	2.2068	2.2405	2.2257	2.0936	1.6301	2.1879	2.2032
13	2.0182	2.1658	1.9791	1.6078	1.3717	1.8858	2.0165
14	2.1313	2.1472	2.0748	1.773	1.5364	2.1879	2.0538
15	2.2068	2.1658	2.1313	1.9239	1.4842	2.1472	2.0911
16	2.2634	2.1285		1.9052	1.5424	2.1502	2.0748
17	2.1313	2.0538	1.9805	1.9427	1.6461	2.1879	2.2257
18	2.0911	1.9231	1.8861	1.7372	1.4266	2.1313	2.1125
19	2.0538	2.0911	1.9805	1.8296	1.5729	2.0748	2.0748
20	1.9418	1.9239	1.7918	1.643	1.5181	1.9239	1.9239
21	1.9239	1.7372	1.8107	1.6617	1.6991	1.8861	1.9239
22	1.773	1.8484	1.6975	1.643	1.8296	1.9239	1.9239
23	1.8484	1.8671	1.8484	1.6057	1.7741	1.905	1.8484
24	1.848		1.8484	1.8107	1.587	1.7551	1.7924
Max	2.3388	2.2405	2.2257	2.0936	1.8296	2.1879	2.2257
Min	1.5546	1.6827	1.5893	1.4998	1.3575	1.5223	1.6244
Avg	1.9224	1.9573	1.8899	1.7705	1.5570	1.9146	1.9175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 205 / 11 kV VILSON ROOFING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.8836	4.4136	3.4705	3.4894	3.7723	1.8023	3.6595
2	4.1636	4.3004	3.3608	3.7346	3.8836	2.0576	3.9043
3	4.3759	4.1872	3.5271	3.81	3.9769	2.0062	4.0175
4	4.0889	4.7154	3.3008	3.8104	3.7529	2.0062	3.8477
5	4.0842	4.9916	3.1554	3.8477	3.9609	2.1491	3.6969
6	3.8462	5.0926	3.5082	3.81	3.9956	2.3529	3.4915
7	3.4541	4.5725	2.9613	3.6591	3.5837	2.1312	3.3608
8	2.4272	3.3573	2.3819	2.3388	2.5873	2.3228	2.5206
9	4.6677	4.3381	3.4865	3.5837	3.1687	3.546	4.0516
10	4.4963	4.481	3.81	3.8855	3.8104	4.5268	4.481
11	4.7821	5.0412	2.6029	4.1872	2.6783	4.369	4.6677
12	4.7249	4.0329	3.0367	4.1152	2.5463	4.225	4.481
13	4.7531	2.9874	3.0178	3.2065	2.452	4.1263	4.1823
14	3.3762	2.9874	3.1687	3.4168	2.5652	3.8477	4.1823
15	5.0869	3.3234	3.1687	2.9127	2.1472	4.1118	4.1076
16	4.4702	3.4541	2.8567	2.4331	2.1125	3.4915	3.2065
17	5.3536	3.5475	3.8477	2.4459	2.2634	3.5837	4.6776
18	5.3772	3.7157	3.3951	3.2819	2.7538	4.0703	3.9247
19	4.9291	3.942	3.3008	4.225	2.5206	3.4355	3.2065
20	3.7342	3.2819	2.452	3.2674	2.6057	3.5662	4.5268
21	2.5463	3.0744	2.8669	3.7723	2.0774	3.6595	4.6677
22	3.546	2.8292	3.3008	3.8666	2.4646	3.2674	4.763
23	3.9232	2.9199	2.9235	4.0552	2.0814	3.1181	4.489
24	3.5848	3.4894	3.4328	3.4894	3.6222	1.7368	3.8462
Max	5.3772	5.0926	3.8477	4.225	3.9956	4.5268	4.763
Min	2.4272	2.8292	2.3819	2.3388	2.0774	1.7368	2.5206
Avg	4.1531	3.8782	3.1806	3.5269	2.9743	3.1462	3.9983



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 206 / 11KV Mahalaxmi

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6632	1.8484	1.9993	1.3394	2.584	.8383	2.0748
2	2.1502	1.9616	2.0538	1.4373	2.4143	.9907	2.1879
3	2.2822	1.9993	2.1845	1.6461	2.2822	1.0526	2.2965
4	2.0165	2.0748	2.2405	1.8484	2.2032	1.085	2.0538
5	2.1098	2.1125	1.182	1.9239	1.9993	1.2715	1.9231
6	1.8671	2.037	1.9044	1.9993	1.2178	1.134	1.7372
7	1.4784	2.0748	2.1125	2.037	1.9427	1.3112	2.0182
8	.8573	.6811	.8987	.3041	.4938	.598	1.166
9	2.0748	1.8484	2.8481	1.8861	.2058	1.8665	1.8484
10	3.5648	2.3525	2.9874	3.1055	.2	3.7912	2.9874
11	3.3913	2.8006	3.7346	3.81		2.4958	3.1741
12	3.6199	2.4272	3.9247	2.6406	.2073	3.0483	3.8089
13	1.8107	2.2405	2.8669	2.2257	.1829	3.263	1.6804
14	2.6482	3.9209	2.5579	3.2579	.2073	3.2065	2.0538
15	2.3954	2.4272	3.6214	1.9239	.2073	3.0483	2.5019
16	2.6673	2.5393	1.8298	1.7541	.2332	2.4897	2.3577
17	3.1055	2.7073	2.6406	3.1055	.1219	1.7551	2.1125
18	1.7924	3.5437	2.4897	2.8006	.1486	3.263	2.9801
19	2.5393	1.8861	2.452	2.2634	.21	2.8669	3.3951
20	2.9874	1.5278	1.6095	1.4045	.1858	1.6078	3.4328
21	1.9805	1.8673	.3601	2.1658	.1709	2.1658	2.8292
22	2.1691	1.4045	.3201	2.0915	.2397	2.1313	3.3008
23	.3658	2.5274	2.6406	2.1691	.7164	2.0911	2.1691
24	.8288	1.1736	.4934	.2721	1.3611	.5418	.4664
Max	3.6199	3.9209	3.9247	3.81	2.584	3.7912	3.8089
Min	.3658	.6811	.3201	.2721	.1219	.5418	.4664
Avg	2.1819	2.1660	2.1647	2.0588	.8581	1.9964	2.3565

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 201 / 11 KV Vardhaman Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	2.4387	2.4768	2.2862	2.2291	1.3908	2.7625
2	2.4768	2.2481	2.2862	1.8861	1.7718	1.3717	2.6673
3	2.2862	2.1338	2.0576	1.9052	1.7147	1.3908	2.5149
4	2.3624	2.2481	1.9052	1.6956	1.6766	1.448	2.4768
5	2.21	2.3243	1.9052	1.4861	1.5051	1.5432	2.3815
6	2.2862	2.2862	1.9433	1.5242	1.8099	1.4289	2.1148
7	2.2481	1.9052	2.0576	1.9814	1.5623	1.5242	2.5911
8	1.7147	1.6575	1.6385	1.6004	1.448	1.6766	2.0957
9	2.0195	1.9052	2.4958	2.4577	1.2955	2.3815	2.572
10	2.8769	2.8197	2.4387	2.8197	1.3336	2.8578	3.1055
11	3.1436	2.8387	2.7816	2.8197	1.3527	2.7816	2.8578
12	2.6673	2.3243	2.8197	2.8959	1.3336	***	2.572
13	2.3434	2.7054	2.7435	2.6673	1.3717	2.0195	2.6673
14	3.0293	2.7054	2.7054	2.6673	1.3717	3.0102	2.8578
15	2.6673	2.9531	2.3624	2.7625	1.2955	2.6673	2.5911
16	2.8387	2.915	1.9814	2.6673	1.2765	2.7435	2.7625
17	1.6956	2.3053	2.4196	1.829	1.2765	2.5911	2.4768
18	2.1148	2.1338	2.3243	2.21	1.3717	2.5149	2.2481
19	2.1529	2.5149	2.0576	2.4387	1.2955	2.8959	2.7435
20	2.1529	2.553	1.8671	2.0195	1.2765	1.9052	1.7909
21	2.0957	1.9814	2.4387	1.9052	1.2955	1.9814	1.8861
22	2.572	2.4387	2.4577	2.4006	1.3717	2.5911	2.4958
23	2.6292	1.9624	2.4196	2.4577	1.3908	2.9531	2.0195
24	2.7816	2.8197	2.572	2.4768	2.4387	1.4098	2.8197
Max	3.1436	2.9531	2.8197	2.8959	2.4387	10.5739	3.1055
Min	1.6956	1.6575	1.6385	1.4861	1.2765	1.3717	1.7909
Avg	2.4148	2.3799	2.2981	2.2442	1.5027	2.4855	2.5030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 202 / 11 KV Mather & Platt  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.448	1.3717	1.4289	1.3717	1.2574	1.5242
2	1.4098	1.448	1.4289	1.3908	1.2384	1.2574	1.4861
3	1.3717	1.467	1.3336	1.3717	1.2193	1.2574	1.4289
4	1.3336	1.4861	1.4098	1.3336	1.1812	1.2384	1.3336
5	1.3717	1.4861	1.3717	1.3146	1.2384	1.2384	1.3908
6	1.4098	1.4861	1.3336	1.3717	1.2955	1.2193	1.3908
7	1.4098	1.4098	1.448	1.3527	1.3336	1.3717	1.3908
8	1.5242	1.6575	1.6766	1.4098	1.3717	1.448	1.6575
9	1.9814	2.0957	1.8861	1.5051	1.3908	1.6385	1.7147
10	2.1719	2.191	2.2862	1.6575	1.3717	2.191	2.4006
11	2.21	2.3815	2.5149	1.5813	1.4098	2.3624	2.1338
12	2.0005	1.6575	1.7909	1.5242	1.2384	2.0957	1.8671
13	1.8671	1.8861	1.9052	1.5623	1.1431	2.0576	1.829
14	2.0957	2.0195	2.0957	1.6385	1.2003	2.2862	2.0767
15	2.1148	1.9243	1.9052	1.7337	1.0479	2.3243	1.9814
16	1.9433	2.0005	1.9433	1.5623	1.2384	2.3624	2.3243
17	1.5813	1.9814	1.9052	1.5623	1.0669	2.2481	2.0957
18	1.848	1.8671	1.8671	1.448	1.3336	1.9052	1.8099
19	1.6575	1.8671	1.6385	1.5623	1.3336	1.8099	1.7718
20	1.4289	1.4289	1.4861	1.3336	1.2955	1.5432	1.3908
21	1.5813	1.4861	1.5623	1.2955	1.3336	1.4861	1.3908
22	1.6385	1.5623	1.448	1.4098	1.3146	1.5051	1.6385
23	1.448	1.6194	1.467	1.3908	1.2955	1.5242	1.5813
24	1.448	1.4289	1.3717	1.4098	1.448	1.2765	1.5242
Max	2.21	2.3815	2.5149	1.7337	1.448	2.3624	2.4006
Min	1.3336	1.4098	1.3336	1.2955	1.0479	1.2193	1.3336
Avg	1.6790	1.7202	1.6853	1.4646	1.2796	1.7044	1.7139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 204 / Tamgoan VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	1.0288	.9526	1.2384	1.2003	.9145	.9526
2	.8764	.9907	.9145	1.1431	1.1431	.8764	.9145
3	.8383	.9526	.8573	1.0479	1.105	.8764	.8573
4	.8002	.9526	.8954	1.0669	.9526	.8764	.9526
5	.8383	1.0288	.9907	1.105	.9335	.9145	1.0479
6	.9526	1.1812	1.086	1.1241	1.1241	1.1241	1.1812
7	1.2955	1.3527	1.3527	1.2003	1.3146	1.3717	1.3527
8	1.448	1.5432	1.3908	1.3908	1.448	1.6004	1.5242
9	1.2955	1.448	1.3146	1.3717	1.3527	.9907	1.4098
10	1.2384	1.2384	1.3336	1.467	1.105	1.0479	1.3717
11	1.2955	1.1431	1.2193	***	.724	1.3527	1.3336
12	1.1431	1.0288	1.3336	1.2574	.6668	1.2193	1.3717
13	1.086	1.0288	1.105	1.0288	.6668	1.1431	1.2574
14	1.2193	1.0669	1.0669	1.0669	.6859	1.0288	1.2765
15	1.1812	1.1241	1.105	1.105	.7049	1.0669	1.105
16	1.086	1.1622	1.105	1.105	.743	1.2574	1.2765
17	1.2574	1.2003	1.2193	1.1812	.7049	1.3336	1.1812
18	1.2955	1.2765	1.3146	1.1431	.743	1.4098	1.2955
19	1.6004	1.5242	1.6766	1.5623	1.0288	1.6194	1.6385
20	1.6385	1.4861	1.5242	1.6004	1.4861	1.5242	1.6956
21	1.5623	1.3908	1.467	1.4098	1.3717	1.3908	1.448
22	1.448	1.3527	1.3717	1.3336	1.2574	1.3908	1.3908
23	1.1812	1.1431	1.3336	1.3717	1.0669	1.1241	1.1241
24	.9526	1.0098	.9526	1.2955	1.2384	.9526	.9717
Max	1.6385	1.5432	1.6766	10.3262	1.4861	1.6194	1.6956
Min	.8002	.9526	.8573	1.0288	.6668	.8764	.8573
Avg	1.1868	1.1939	1.2034	1.6226	1.0320	1.1836	1.2471

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 205 / 11 KV Patel Petro feeder      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.8192	1.3908	.9526	1.1241	.6859	1.2955
2	1.105	.8383	1.3336	.9526	.7621	.6859	1.2384
3	1.0669	.9526	1.2384	1.0098	.6097	.6859	1.1431
4	1.1431	.9526	1.2955	.9907	.6478	.6859	1.0479
5	1.1812	.9907	1.2955	1.0288	.5906	.7621	.9526
6	1.2193	1.086	1.4289	1.0098	.743	.7811	.9526
7	1.448	.9907	.9526	1.105	.8573	.8002	1.3146
8	.9526	1.0288	1.4289	1.2955	.3239	.8573	1.4098
9	2.2481	1.7718	2.4768	1.1241	.6668	1.6956	1.7147
10	2.5339	1.6956	2.21	1.7909	.6097	2.4006	1.8861
11	2.0386	2.0957	2.2862	1.5242	.6668	2.6101	2.191
12	1.9052	1.2384	1.9052	1.5051	.6668	2.4006	1.8861
13	2.2481	2.2291	1.9814	1.829	.6097	1.6385	2.0195
14	2.0005	1.5051	2.1719	2.21	.6287	1.9814	2.7054
15	2.4196	2.5911	1.3717	2.572	.6097	1.7528	2.0576
16	2.3815	2.4958	2.7054	2.5911	.6097	1.7147	1.9243
17	1.8671	2.4387	2.4387	2.4958	.6097	2.2862	1.448
18	2.3053	1.7147	1.8671	1.1812	.6668	1.4289	1.5813
19	1.3908	1.1431	1.2193	1.6385	.6478	1.6004	1.1241
20	.9717	.9907	1.448	1.448	.6859	1.2574	1.3527
21	1.2384	1.4861	1.3146	1.448	.6859	1.3336	1.4098
22	1.3908	1.448	1.086	1.3908	.6859	1.4289	1.0288
23	1.1812	1.467	1.0479	1.4289	.6859	1.3527	1.3908
24	1.4861	.8764	1.3717	1.0479	1.2574	.6859	1.2955
Max	2.5339	2.5911	2.7054	2.5911	1.2574	2.6101	2.7054
Min	.9526	.8192	.9526	.9526	.3239	.6859	.9526
Avg	1.6115	1.4519	1.6361	1.4821	.6938	1.3964	1.5154

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 206 / 11KV Devi gas

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.9526	1.1431	1.0479	1.1431	.7621	1.6766
2	1.0669	.9907	1.105	1.0288	1.086	.7621	1.5242
3	1.0288	.9907	1.0479	1.1241	.9526	.7621	1.4289
4	.9907	1.0288	1.1812	1.105	.9145	.724	1.4098
5	1.0669	1.0288	1.1431	1.0288	.9907	.6478	1.1431
6	1.105	1.0669	1.2574	1.1431	.9717	.6668	1.0479
7	1.105	1.2193	1.105	1.1431	1.1431	.6859	1.6004
8	.9907	1.086	.8954	1.3908	.8573	.743	1.4098
9	.9907	1.4289	1.6004	1.6004	.724	1.2765	1.5432
10	1.5242	1.5623	1.6385	1.6956	.6287	1.6575	1.7909
11	1.5242	1.6575	1.6766	2.1719	.6287	2.0576	2.0386
12	1.4289	1.9433	1.8671	1.848	.724	1.9624	1.7528
13	1.2955	1.6956	1.829	1.8671		1.7147	2.0576
14	1.448	1.9624		1.5242		1.829	1.8861
15	1.3717	1.6385	1.6004	1.9624		1.9052	2.0195
16	1.5623	1.7337	1.6385	2.0957		1.9433	1.6575
17	1.5623	1.6004	1.6385	1.6575		1.5242	1.467
18	1.2955	1.5051	.9717	1.4861	.6287	1.3336	1.848
19	1.0288	1.467	1.105	1.6004	.724	1.3717	1.3717
20	1.1431	1.3146	1.5432	1.105	.7621	1.2955	1.5432
21	1.2003	1.3336	1.3336	1.1812	.7621	1.5813	1.3336
22	1.2384	1.3717	1.3336	1.2765	.7621	1.2765	1.3146
23	1.2193	1.4289	1.2384	1.2955	.7621	1.6194	1.6004
24	1.2955	1.2003	1.1431	1.1812	1.2384	.743	1.6385
Max	1.5623	1.9624	1.8671	2.1719	1.2384	2.0576	2.0576
Min	.9907	.9526	.8954	1.0288	.6287	.6478	1.0479
Avg	1.2296	1.3837	1.3494	1.4400	.8634	1.2852	1.5877

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 201 / Mhakve AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.4115	.3353	.4001	.0343	.0381	.0335
2	.0381	.4115	.3353	.4001	.0343	.0381	.0335
3	.0381	.4115	.3353	.4001	.0343	.0381	.0335
4	.0381	.4115	.3353	.4001	.0343	.0381	.0335
5	.0381	.4287	.5197	.4458	.0343	.0381	.0505
6	.0381	.6516	.7042	.6173	.0343	.0381	.0503
7	.0381	.8745	.8551	.8573	.0343	.0572	.0671
8	.0381	1.094	1.0395	1.0631		.0572	.0671
9	.0381	1.1437	1.1904	1.0802		.0762	.0335
10	.0381	.064	.0762	.0514	.0762	.0572	
11	1.5775	.0671	.0572	.0686		1.9044	1.8099
12	1.7661	.0503	.0762	.0686	2.0005	1.9044	
13	1.5947	.0671	.0953	.0857	1.9624	1.5083	
14	1.5261	.0671	.0953	.0857	1.829	1.4918	1.9052
15	1.3546	.0838	.0953	.0857	1.7909		1.829
16	1.3717	.0671	.0762	.0857	1.7528	1.3923	
17	1.286	.0838	.0953	.0857	1.6004	1.3592	1.7147
18	1.1576	.0503	.0572	.0857	1.4289	1.2239	
19	.0514	.0503	.0572	.0857	.0572	.0503	.0572
20	.0514	.0503	.0572	.0686	.0572	.0503	
21	.0514	.0503	.0381	.0686	.0572	.0671	.0572
22	.0514	.0503	.0381	.0686		.0335	
23	.0514	.0503		.0514	.0381	.0335	.0381
24	.0381	.3944	.3521	.4001	.0343	.0381	.0335
Max	1.7661	1.1437	1.1904	1.0802	2.0005	1.9044	1.9052
Min	.0381	.0503	.0381	.0514	.0343	.0335	.0335
Avg	.5129	.2952	.3007	.2962	.6463	.5015	.4616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 202 / Mhakve Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1867	.1663	.1905	.2241	.1524	.1663
2	.1905	.1867	.1663	.1905	.168	.1524	.1663
3	.1905	.1867	.1663	.1905	.168	.1524	.1663
4	.1905	.1867	.1663	.1905	.168	.1524	.1663
5	.2286	.2054	.2614	.2096	.1867	.1905	.2587
6	.2858	.2987	.3326	.2987	.2987	.3239	.2957
7	.3429	.3361	.3142	.3361	.3734	.3429	.3326
8	.4001	.3174	.3142			.3239	.3142
9	.4191	.2987	.2957	.2987		.3239	.2587
10	.3361	.2987	.2858	.2987	.3048	.3048	
11	.3174	.2614	.2858	.3174		.2987	.2858
12	.2987	.3361	.2858	.2987	.2858	.2241	
13	.2241	.1867	.3239	.2614	.2858	.2427	
14	.2614	.2241	.2667	.2614	.3048	.2241	.2667
15	.2801	.1867	.2667	.2054	.3048		.2858
16	.2427	.2054	.2667	.2987	.2858	.2054	
17	.2987	.2614	.2858	.2987	.2858	.2614	.3239
18	.3361	.2614	.3048	.3174	.3048	.3142	
19	.5041	.4854	.4191	.5041	.5335	.499	.5525
20	.5228	.4801	.5335	.5228	.5525	.5175	
21	.4854	.4854	.4382	.4668	.4954	.4805	.5335
22	.4294	.4108	.4001	.4294		.2218	
23	.2614	.2054		.3174	.2667	.2218	.3048
24	.1905	.2054	.1848	.2667	.2241	.1905	.1848
Max	.5228	.4854	.5335	.5228	.5525	.5175	.5525
Min	.1905	.1867	.1663	.1905	.168	.1524	.1663
Avg	.3146	.2791	.2927	.3030	.3011	.2748	.2861



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 203 / Kenavade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.0514	.0492	.0572	.2058	.1905	.1989
2	.2286	.0514	.0492	.0572	.2058	.1905	.1989
3	.2286	.0514	.0492	.0572	.2058	.1905	.1989
4	.2286	.0514	.0492	.0572	.2058	.1905	.1989
5	.2286	.0514	.0492	.0572	.2401	.2667	.2486
6	.381	.0686	.0655	.0686	.2572	.381	.3149
7	.5335	.0686	.0655	.1029	.4458	.724	.5801
8	.8764	.0838	.0819	.1029		.9907	.9282
9	.9145	.1006	.0983	.12		.9526	1.0774
10	.1334	.0838	.0953	.1029	.1143	.0762	
11	.1029	1.0059	1.2003	.9088		.0829	.1334
12		1.0059	1.3336	1.046	.0762	.0829	
13	.0686	.9724	1.1812	.8916	.0572	.0829	
14	.1029	.9724	1.1622	.8059	.0572	.0829	.1334
15	.0857	.9221	1.0479	.7716	.0762		.1524
16	.1029	.9221	1.0098	.8745	.0572	.0995	
17	.1029	.9054	.8764	.7545	.0762		.1524
18	.0857	.6203	.7049	.583	.1143	.116	
19	.0686	.0838	.1334	.0857	.0953	.0995	.1524
20	.0686	.0671	.0953	.0857	.0953	.0995	
21	.0514	.0671	.0953	.0857	.0762	.0995	.1334
22	.0514	.0503	.0762	.0686		.0663	
23	.0514	.0503	.0762	.0686	.0572	.0663	.0762
24	.2286	.0514	.0492	.0762	.2058	.1905	.2321
Max	.9145	1.0059	1.3336	1.046	.4458	.9907	1.0774
Min	.0514	.0503	.0492	.0572	.0572	.0663	.0762
Avg	.2241	.3483	.4039	.3287	.1462	.2419	.3006

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144119 / 33/11 KV PIMPALGAON KH

Feeder No / Name : 203 / 11 KV Vhannur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0171	.6516	.6516	.823	.0171	.0171
2	.0171	.0171	.6859	.6516	.8916	.0171	.0171
3	.0171	.0171	.6859	.6687	.9431	.0171	.0171
4	.0171	.0171	.7202	.6687	1.0631	.0171	.0171
5	.0171	.0171	.7202	1.0288	1.0974	.0171	.0171
6	.0171	.0171	.7716	1.1317	1.0631	.0171	.0171
7	.0171	.0171	.9431	1.166	1.0288	.0171	.0171
8	.0171	.0171	1.166	1.2346	1.2174	.0171	.0171
9	.0171	.0171	1.166	1.2689	1.3717	.0171	.0171
10	.0171	.0171	.0171	.0171	.0171	.0171	.0171
11	1.3203	.0171	.0171	.0171	1.2346	1.2689	1.3546
12	1.3717	.0171	.0171	.0171	1.286	1.2689	.0171
13	1.3546	.0171	.0171	.0171	1.0117	1.2689	1.3889
14	1.286	.0171	.0171	.0171	.9431	1.2346	1.3032
15	1.2517	.0171	.0171	.0171	.9945	1.166	1.3032
16	1.2174		.0171	.0171	1.0117	1.166	1.286
17	1.166	.0171	.0171	.0171	.6744	1.2003	1.2689
18	1.0802	.0171	.0171	.0171	.9602	1.0288	.0171
19	.0171	.0171	.0171	.0171	.0171	.0171	.0171
20	.0171	.0171	.0171	.0171	.0171	.0171	.0171
21	.0171	.0171	.0171	.0171	.0171	.0171	.0171
22	.0171	.0171	.0171	.0171	.0171	.0171	.0171
23	.0171	.0171	.0171	.0171	.0171	.0171	.0171
24	.0171	.0171	.6516	.6516	.7373	.0171	.0171
Max	1.3717	.0171	1.166	1.2689	1.3717	1.2689	1.3889
Min	.0171	.0171	.0171	.0171	.0171	.0171	.0171
Avg	.4301	.0171	.3501	.3901	.7690	.4115	.3422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 407 / MUDSHINGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	28-FEB-18
HR	Load (MW)
23	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 201 / 11KV KAPASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	.381	.3239	.4191	.0381	.0343	.0381
2	.0762	.381	.3239	.4191	.0381	.0343	.0381
3	.0572	.381	.3239	.4191	.0381	.0343	.0381
4	.0572	.381	.3239	.4191	.0381	.0343	.0381
5	.0572	.362	.3077	.4382	.0381	.0343	.0572
6	.0572	.3429	.3401	.4763	.0381	.0343	.0572
7	.0762	.6859	.5992	.8002	.0381	.0514	.0572
8	.0762	.9145	.9393	1.1622	.0762	.0514	.0572
9	.0572		.9686	1.2193	.0572	.0514	.0572
10	.0762	.0572		.0762	.0514	.0514	.0762
11	1.0288	.0762	.0572	.0953	1.2003	1.2574	.8907
12	1.0288	.0762	.0572	.0953	1.5089	1.2955	1.0364
13	1.1241	.0762	.0572	.0953	1.0974	1.2193	1.004
14	1.2193	.0762	.0953	.0953	1.2517	1.2384	1.004
15	1.1431	.0762	.0572	.1143	1.2689	1.2384	.9878
16	1.0669	.0762	.0572	.1524	1.2689	1.1431	.9555
17	1.0098	.0762			1.1488	.8573	.9069
18	.8383	.0953		.0572	.9259	.7049	.7773
19	.0572	.0762	.0572	.0572	.0514	.0762	.0953
20	.0572	.0762	.0572	.0572	.0514	.0762	.1334
21	.0381	.0762	.0381	.0381	.0514	.0762	.0762
22	.0572	.1143	.0381	.0381	.0343	.0762	.0762
23	.0381	.0572	.0381	.0381	.0343	.0572	.0762
24	.0953	.4001	.3239	.4001	.0381	.0343	.0381
Max	1.2193	.9145	.9686	1.2193	1.5089	1.2955	1.0364
Min	.0381	.0572	.0381	.0381	.0343	.0343	.0381
Avg	.3946	.2311	.2564	.3123	.4326	.4068	.3572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 202 / 11 KV Hasoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763						1.9052
2	.4382						1.7147
3	.4572						1.5242
4	.4572						1.3336
5	.4763						1.3336
6	.5335						1.3717
7	.724						1.5623
8	1.0288						1.6766
9	.8764						1.5242
10	.0762						.1715
11	.0762						.2096
12	.0762	1.3336	1.5623	.9526		.362	.1905
13	.0762					.3429	.1905
14	.0953					.3048	.1905
15						.3429	.2096
16						.381	.0381
17						.381	.2858
18						.381	.2667
19						.3429	.2477
20						.3429	.2096
21						.3239	.1905
22						.3239	.1715
23						.3048	.1524
24	.4954	.0762	.1143	.0762	.1715	2.21	2.1719
Max	1.0288	1.3336	1.5623	.9526	.1715	2.21	2.1719
Min	.0762	.0762	.1143	.0762	.1715	.3048	.0381
Avg	.4242	.7049	.8383	.5144	.1715	.488	.7851

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 203 / 11 KV MUGALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905						.2477
2	.1715						.2286
3	.1715						.2286
4	.1715						.2286
5	.1905						.2477
6	.1905						.2477
7	.3048						.2667
8	.2477						.2858
9	.2858						.2667
10	.2096						.2667
11	1.6194						.9717
12	1.5432	.2096	.2096	.2096	1.2955	1.2765	.9393
13	1.3908					1.0669	.9069
14	1.3336					1.086	.9069
15						1.0288	.9393
16						1.0288	.9393
17						.9907	.7773
18						.9526	.6802
19						.2477	.2667
20						.2667	.2667
21						.2667	.2667
22						.2286	.2667
23						.2286	.2667
24	.1905	.8573	.8764	.8573	.2286	.2286	.2477
Max	1.6194	.8573	.8764	.8573	1.2955	1.2765	.9717
Min	.1715	.2096	.2096	.2096	.2286	.2286	.2286
Avg	.5474	.5335	.543	.5335	.7621	.6844	.4649

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 204 / 11 KV LINGNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145						.9145
2	.8764						.9145
3	.8383						.8764
4	.8383						.8764
5	.8764						.9145
6	1.0098						.9145
7	1.1241						1.1812
8	1.2193						1.4289
9	1.2384						1.3717
10	.0381						.0953
11	.0572						.0953
12	.0572	1.7909	1.6194	1.5623	.0762	.0953	.0762
13	.0572					.0381	.0953
14	.0381					.0381	.0953
15						.0762	.0953
16						.0953	.1143
17						.1143	.0953
18						.1334	.0953
19						.1143	.1143
20						.0953	.0953
21						.0953	.0953
22						.0953	.0381
23						.0953	.0381
24	.9145	.0381	.0381	.0381	.8954	.8954	.9145
Max	1.2384	1.7909	1.6194	1.5623	.8954	.8954	1.4289
Min	.0381	.0381	.0381	.0381	.0762	.0381	.0381
Avg	.6732	.9145	.8288	.8002	.4858	.1524	.4811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 205 / 11 KV Arjunwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762						.0762
2	.0572						.0762
3	.0572						.0762
4	.0762						.0762
5	.0762						.0953
6	.0953						.0762
7	.0953						.1143
8							.1143
9	.1334						.1143
10	.1143						.1143
11	.9907						.8745
12	1.1241	.0953	.0762		1.2955	1.0288	.8745
13	1.1431					.9526	.9069
14	1.105					.9526	.9069
15						.9145	.8745
16						.9526	.8745
17						.9145	.8097
18						.8764	.0648
19						.1143	.0762
20						.0953	.0381
21						.0953	.0762
22						.0953	.0762
23						.0953	.0953
24	.0762	.5906	.7049	.5906	.0953	.0762	.0762
Max	1.1431	.5906	.7049	.5906	1.2955	1.0288	.9069
Min	.0572	.0953	.0762	.5906	.0953	.0762	.0381
Avg	.3729	.3430	.3906	.5906	.6954	.5511	.3149



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 206 / 11 KV Vadgaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096						.2667
2	.1905						.2667
3	.1715						.2477
4	.1715						.2477
5	.2096						.2477
6	.2858						.2667
7	.362						.4001
8	.4382						.4382
9	.4001						.4382
10	.3239						.362
11	.2477						.362
12	.2286	.2667	.2858	.3048	.3239	.3048	.3239
13	.2667					.2858	.2858
14	.2286					.2477	.2667
15						.3429	.2667
16						.2858	.3048
17						.3239	.3429
18						.4001	.381
19						.6287	.5525
20						.7621	.6859
21						.6859	.5906
22						.5335	.4763
23						.381	.3048
24	.2286	.2286	.2096	.2667	.2477	.2858	.2858
Max	.4382	.2667	.2858	.3048	.3239	.7621	.6859
Min	.1715	.2286	.2096	.2667	.2477	.2477	.2477
Avg	.2642	.2477	.2477	.2858	.2858	.4206	.3588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1334	.1334	.1524	.1334	.1267	.1334
2	.1715	.1334	.1334	.1524	.1334	.1267	.1334
3	.1524	.1334	.1334	.1524	.1334	.1267	.1334
4	.1524	.1334	.1334	.1524	.1334	.1267	.1334
5	.1905	.1715	.1715	.1715	.1524	.1629	.1524
6	.2286	.2096	.2096	.2096	.1715	.181	.2096
7	.2858	.2667	.2667	.2858	.3048	.2534	.3048
8	.3239	.2667	.2667	.2858	.2667	.2715	.3048
9	.3239	.2286	.2477	.2477	.2286	.2534	.2667
10	.2858	.2286	.2477	.2667	.181	.1991	.2286
11	.2477	.2286	.2477	.2096	.1629	.181	.2096
12	.2477	.2286	.2286	.2286	.1629	.1905	.2096
13	.2286	.2096	.1715		.1629	.1524	.2096
14	.1715	.1715	.1905		.1629	.1334	.1905
15	.1905	.2096	.2286		.181	.1715	.1905
16	.2286	.2286	.2286	.2667	.181	.2286	.3239
17	.2858	.2858	.1905	.2667	.181	.2477	.2286
18	.2858	.2667	.2667	.2858	.2534	.2667	.3048
19	.4382	.4191	.4001	.4001	.3801	.4001	.4001
20	.4382	.4763	.4001	.4382	.3801	.4191	.4191
21		.4001	.3429	.362	.362	.4001	.4382
22	.3429	.2858	.2477	.2858	.2896	.2858	.3239
23	.2286	.2096	.1905	.2096	.1991	.1905	.2096
24	.2096	.1524	.1524	.1524	.1629	.1629	.1524
Max	.4382	.4763	.4001	.4382	.3801	.4191	.4382
Min	.1524	.1334	.1334	.1524	.1334	.1267	.1334
Avg	.2535	.2366	.2262	.2468	.2109	.2191	.2421

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4382	.4001	.381	.4001	.3429	.3077	.3429
2	.4191	.4001	.381	.381	.3239	.2915	.3429
3	.4001	.4001	.381	.381	.3239	.2915	.3429
4	.4001	.4001	.381	.381	.3239	.3077	.3429
5	.4191	.4382	.4763	.4191	.3429	.3982	.381
6	.5335	.5906	.6097	.5906	.381	.5068	.5716
7	.6859	.6478	.724	.743	.743	.6697	.6668
8	.6668	.6097	.6668	.6859	.6287	.6154	.6287
9	.5906	.5906	.5716	.6668	.6097	.5792	.5906
10	.5906	.5906	.5144	.6668	.4706	.5792	.5525
11	.5144	.5144	.4954	.6287	.4706	.543	.5525
12	.5335	.4954	.4572	.6097	.3801	.4954	.6097
13	.4763	.4763	.5144	.4954	.4163	.4954	.5335
14	.4572	.4382	.4763	.5716	.3801	.4191	.4954
15	.4763	.4191	.4001	.4954	.3258	.4382	.5335
16	.5335	1.086	.4001	.5525		.4954	.5525
17	.5716	.4954	.4001	.6287	.4887	.5144	.6478
18	.5906	.5525	.6668	.5716	.4887	.5335	.6668
19	.9717	.8954	.9526	.9717	.724	1.0098	.9145
20	.9717	1.0098	1.0479	1.0479	.8326	1.0669	1.0479
21	.8954	.9145	.8764	.8764	.7602	.9145	.9526
22	.724	.724	.6859	.6668	.6516	.7049	.724
23	.4954	.5144	.4954	.4191	.4163	.4382	.4572
24	.4572	.4191	.4001	.4191	.362	.3258	.362
Max	.9717	1.086	1.0479	1.0479	.8326	1.0669	1.0479
Min	.4001	.4001	.381	.381	.3239	.2915	.3429
Avg	.5755	.5843	.5565	.5946	.4864	.5392	.5755

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 209 / 11 KV Madyal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.0381	.0381	.0381	.0381	1.4403	1.2574
2	.5335	.0381	.0381	.0381	.0381	1.4232	1.2193
3	.5144	.0381	.0381	.0381	.0381	1.406	1.2003
4	.5335	.0381	.0381	.0381	.0381	1.406	1.2003
5	.5335	.0381	.0381	.0381	.0381	1.406	1.2003
6	.5716	.0381	.0381	.0381	.0381	1.4232	1.2193
7	.743	.0953	.0381	.0381	.0953	1.6289	1.2574
8	.7811	.0953	.0381	.0762	.1524	1.6804	1.2574
9	.7811	.0953	.0762	.0762	.1905	1.7661	1.2574
10	.0572	.0953	.0381	.0953		.1543	.0953
11	.0381	.8916	.5335	1.0479		.2058	.1334
12	.0762	.9145	1.0288	1.0288		.2286	.1524
13	.0953	.8916	1.086	1.0288		.2477	.1524
14	.0762	.8259	.9335	.9907		.2858	.1334
15	.0762	.8421	1.0669	.8954		.2286	.1334
16	.0953	.8097	.9145	.743		.2477	.1715
17	.1143		.9526	.8383		.2667	.1715
18	.0953	.3258	.8002	.724		.2858	.1334
19	.0762	.0381	.0762	.0381	.2058	.2858	.1715
20	.0762	.0381	.0381	.0381	.2401	.2286	.1715
21	.0762	.0762	.0381	.0381	.2058	.2477	.1524
22	.0762	.0762	.0381	.0381	.2058	.2477	.1334
23	.0381	.0762	.0381	.0381	.2058	.1905	.1334
24	.5716	.0381	.0381	.0381	.0381	1.5775	1.2955
Max	.7811	.9145	1.086	1.0479	.2401	1.7661	1.2955
Min	.0381	.0381	.0381	.0381	.0381	.1543	.0953
Avg	.2993	.2806	.3334	.3350	.1179	.7712	.6001

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 201 / 11 Kv Sonage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6706		.0162				.8402
2	.6706		.0162				.8029
3	.6706		.0162		.7377		.8029
4	.6706		.0162				.8215
5	.6706		.0162				.8962
6	.7377		.0162	.0164			.9896
7	1.073		.0162		.8718		1.4003
8	1.2071		.0162	.0164	1.1065		1.4937
9	1.1065		.0162	.0164	1.4083		1.0082
10	.0162	.0162			.0164		
11	.0162	2.5393	2.0119		.0162	.0168	
12	.0162	2.4086					
13	.0162	2.5393	2.1795				
14	.0162	2.5393					
15	.0162	2.3899			.0162	.0168	
16	.0162	2.2405	2.146		.0164	.0168	
17		2.0911	2.2218			.0168	
18		1.7194	2.4459				
19		.0162					
20		.0162					
21		.0162	.0164				
22		.0162				.0164	
23		.0162	.0162			.0162	
24	.6874		.0162		.8383		.8775
Max	1.2071	2.5393	2.4459	.0164	1.4083	.0168	1.4937
Min	.0162	.0162	.0162	.0164	.0162	.0162	.8029
Avg	.4869	1.3260	.6588	.0164	.5586	.0166	.9933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
2			.0162
5			.0162
6			.0164
7			.0162
8	.0838		.0162
9	.0838		.0164
10	.0648		.0175
11	2.3525	2.431	2.0858
12	2.4086		2.2085
13	2.4459		2.2611
14	2.3712		2.226
15	2.2405	2.0622	2.1384
16	2.1658	2.1125	2.0683
17		1.9281	
18		1.7737	
19		.0162	
22		.0164	
23		.0164	
24	.0838		.0164
Max	2.4459	2.431	2.2611
Min	.0648	.0162	.0162
Avg	1.4301	1.2946	.9371

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 203 / 11 KV ARJUNNAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1829	.1867	.2054				.1848
2	.1463	.1867	.1867	.1663			.1663
3	.1463	.1867	.1886		.1463	.1509	.1663
4	.1463	.2241	.2075			.1886	.1848
5	.1829	.2614	.2614	.2402			.2218
6	.2195	.3361	.3547	.2801		.3174	.2772
7	.2561	.2957	.3326	.3361	.2743	.3475	.2987
8	.2561	.2743	.2743	.3361	.2743	.3109	.2614
9	.2378	.2561	.2926	.2402	.1829	.1829	.2614
10	.1829	.2218		.2172	.1848		.2353
11	.2012	.1848		.181	.1663	.1677	.1991
12	.1829	.1663	.1463	.3077	.2033		.1629
13	.1991	.1663		.181	.1663		.181
14	.181	.1848		.181	.1478		.181
15	.2172	.2402		.181	.1294	.2195	.181
16	.2353	.2427	.2195	.2172	.2033	.2378	.2534
17	.2172	.2801	.2218	.2534	.2353	.1829	
18		.3658	.2801		.2715	.2772	
19	.439	.4207	.4481		.439	.3881	
20	.4755	.439	.4294		.4207	.4481	
21	.3841	.4024	.4108		.3658	.4108	
22	.3326	.3326	.3511		.3326	.3326	
23	.2427	.2587	.2587		.2587	.2402	
24	.1829	.1867	.1867	.2218	.1646	.1867	.2033
Max	.4755	.439	.4481	.3361	.439	.4481	.2987
Min	.1463	.1663	.1463	.1663	.1294	.1509	.1629
Avg	.2369	.2625	.2766	.2360	.2404	.2700	.2129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2561	.2241	.2241			.1867	.2218
2	.2195	.1867	.2054	.2218		.1867	.1848
3	.2195	.1867	.2054		.1829	.1867	
4	.1829	.2241	.2263			.2241	
5	.1829	.2987		.3142		.2987	.3174
6	.2561	.5601		.4294		.4481	.5228
7	.5487	.5729	.5487	.5788	.439	.567	.5415
8	.5487	.5853	.5121	.5601	.439	.5304	.5228
9	.5121	.4938	.4755	.4854	.4024	.4755	.4481
10	.4755	.4668	.439	.4344	.3174		.4163
11	.4207	.3921		.5068	.3511	.4024	.4706
12	.4207	.4294	.439	.4706	.3326		.4163
13	.4163	.4481		.4163	.2957		.3982
14	.3439	.3696		.362	.3142		.362
15	.3077	.3696		.3077	.2957	.3841	.3982
16	.3982	.3734	.3511	.3258	.3734	.3475	.3439
17	.4163	.3361	.3921	.4525	.3258	.3109	
18	.4024	.4668	.3921		.3439	.3696	
19	.6584	.6584	.5788		.6584	.6348	
20	.695	.6767	.6348		.6219	.6348	
21	.6219	.5853	.5975		.5853	.6161	
22	.4251	.4435	.4854		.462	.4668	
23	.3174	.3142	.3326		.2614	.2987	.3109
24	.2926	.2614	.2427	.2772	.2195	.2241	.2957
Max	.695	.6767	.6348	.5788	.6584	.6348	.5415
Min	.1829	.1867	.2054	.2218	.1829	.1867	.1848
Avg	.3974	.4135	.4046	.4095	.3801	.3897	.3857



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 205 / 11 KV Banage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2534	.2774			.0724	
2		.2534	.2601	.3142		.0747	.0655
3		.2534	.2629			.0724	
4		.2896	.3814			.0724	
5		.3258	.5201	.3696			.0648
6		.4344	.6588	.4108		.0905	.0655
7		.5792	.6859	.6535		.1075	
8	.0671	.8596	.9602	.9335	.0671	.1075	.0648
9	.0671	.8413	.9015	.9149	.0671	.0876	.0648
10	.0648	.0655		.0701	.0655		.0895
11	1.166			.0701	1.4563	1.4083	1.448
12	1.2003	.0655		.1052	1.4937		1.6476
13	1.2209			.0351	1.5684		1.7528
14	1.1869			.0876	1.4937		1.7528
15	1.0513			.0701	.5175	1.1568	
16	1.0174	.0648	.0671	.1052	.1494	1.2136	
17	.929	.0655	.0655	.0876	1.1919	1.0059	
18	.8063	.0648	.0655		1.0517	.9335	
19	.0716	.0648			.0895	.081	
20	.0716	.0648			.0895		
21	.0716	.0648	.0655		.0895		
22	.0724	.0648			.0895	.0648	
23	.0724	.0648	.0648		.0905	.0648	
24	.0671	.2534	.3121	.3696	.0671	.0905	.0648
Max	1.2209	.8596	.9602	.9335	1.5684	1.4083	1.7528
Min	.0648	.0648	.0648	.0351	.0655	.0648	.0648
Avg	.5414	.2497	.3699	.3065	.5669	.3944	.6437

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 206 / CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9221	.0362	.0486			.8145	.8402
2	.9054	.0362	.0486	.0328		.7964	.8215
3	.8718	.0362	.0486		.8048	.7964	.8029
4	.8718	.0543	.0486				.8029
5	.8718	.0724	.0655				.8589
6	.9054	.0724	.0648	.0486			.9149
7	1.0059	.0905	.0648		1.0442	1.1222	1.1576
8	1.2071	.0716	.0486	.0486	1.2071	1.3969	1.5497
9	1.3413	.0716	.0648	.0655	1.3245	1.3321	1.4563
10	.0648	.0972		.0876	.0648		.0526
11	.0648	1.9791		1.6651	.0648	.0503	.0701
12	.0648	2.0911		1.7177			.0701
13	.0648	2.0911	1.7939	1.7002			.0876
14	.0486	2.0538		1.6301			.0876
15	.0648	2.0165		1.595	.0655	.0503	.0701
16	.0648	1.9044	1.7101	1.6126	.0655	.0503	.0876
17		1.9044	1.6804	1.5249	.0532	.0503	
18	.0179	1.6644	1.5684		.0709	.0648	
19	.0716	.0486			.0716	.0648	
20	.0716	.0486			.0716		
21	.0537	.0486	.0486		.0716		
22	.0543	.0486			.0537	.0492	
23	.0543	.0486	.0492		.0543	.0486	
24	.9556	.0362	.0486	.0492	.9389	.8145	.8775
Max	1.3413	2.0911	1.7939	1.7177	1.3245	1.3969	1.5497
Min	.0179	.0362	.0486	.0328	.0532	.0486	.0526
Avg	.4617	.6926	.4626	.9060	.3767	.5001	.6240

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 201 / 11 KV MURGUD Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2							.0667
7							.08
8		1.5524	1.4723	1.2963			.0594
10							.1029
11							2.332
12	2.0805						2.332
13					2.0805	2.0805	2.0083
14							2.1664
15							2.1506
16							.3841
17							2.0165
18							1.8244
19							.1067
24							.0667
Max	2.0805	1.5524	1.4723	1.2963	2.0805	2.0805	2.332
Min	2.0805	1.5524	1.4723	1.2963	2.0805	2.0805	.0594
Avg	2.0805	1.5524	1.4723	1.2963	2.0805	2.0805	1.1212

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 208 / 11 KV Murgud VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658						
2	.3292	.3429	.3429	.3681	.3429	.3506	.3086
3	.3292						
4	.3326	.3429	.3258	.3506	.3429	.333	.3086
5	.3696						
6	.5175	.4115	.6001	.4908	.4973	.5083	.4115
7		.5487				.5784	.5144
8		.583	.6173	.5784	.5658	.5083	.5487
9		.5487	.5609				.5373
10	.4801	.5658	.4908	.6001	.4557		.543
11		.5487	.5434	.5487			
12	.4801		.5258	.5316	.4733	.4115	.6089
13		.5316	.5258	.463			.5144
14	.4115	.4801	.4382	.4973	.4382		.5144
15	.4115	.5144	.5258	.463			.5487
16	.4458	.5316	.4733	.4801	.5083		.5792
17		.5487	.5959	.4973			.6516
18	.583	.6516	.631	.6516	.8238		.6878
19		.823		.823			.8501
20	.823	.8402	.7712	.7716			.8501
21		.7716					.8131
22		.6859	.6485	.6173			
23	.4458						
24	.3982	.3772	.4287	.3856	.4287	.3681	.3429
Max	.823	.8402	.7712	.823	.8238	.5784	.8501
Min	.3292	.3429	.3258	.3506	.3429	.333	.3086
Avg	.4482	.5604	.5321	.5364	.4877	.4369	.5630

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 403 / 33 KV Sonali LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0543				.0549	
4	.0543			.0549		.0297
5	.3258	.1183			.2743	.0892
6	.4344	.16	.112	.2743		
7		.2401		.3841	.3841	.1189
8		.2401	.2801	.3841	.4938	.2
9		.3361	.2195			.2715
10	.4001	.3361	.2743	.3921		.2715
11		.3361	.3841	.3921		.2172
12	.3704		.3841	.3361	.3601	.2172
13		.3361	.3292	.2801		
14	.3601	.3361	.3841	.3361		.2172
15	.3601	.3361	.3292	.3921		.3258
16	.3201	.112	.3292	.2801		.3258
17		.3361	.3292	.3361		.3258
18		.056		.056		.0543
Max	.4344	.3361	.3841	.3921	.4938	.3258
Min	.0543	.056	.112	.0549	.0549	.0297
Avg	.2977	.2522	.305	.2999	.3134	.2049

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 201 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4409						
2	.4409						
3	.4239						
4	.4239						
5	.4917						
6	.7461						
12		1.9616	1.3203	1.6289	.0373	.037	.0343
13							.0343
14							.0543
15							.0543
16							.0514
17							.0514
18							.0543
19							.0339
20							.0509
21							.0509
22							.0509
23							.0509
24	.4578		.0686	.0549	.4835	.5194	.5138
Max	.7461	1.9616	1.3203	1.6289	.4835	.5194	.5138
Min	.4239	1.9616	.0686	.0549	.0373	.037	.0339
Avg	.4893	1.9616	.6945	.8419	.2604	.2782	.0835

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 202 / Sonali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0678						.061
2	.0678						.061
3	.0678						.061
4	.0678						.061
5	.0678						.061
6	.0678						.061
7	.0678						.0762
8	.0848						.0829
9	.0848						.0857
10	.0848						.0514
11	1.6632						1.6289
12	1.7318	.0857					1.7736
13	1.6804						1.8778
14	1.4918						1.9784
15	1.406						1.9616
16	1.2136						1.9784
17	1.1963					.6443	1.8945
18						.5243	1.7974
19						.0686	.1357
20						.0532	.1187
21						.061	.1187
22						.061	.1017
23						.061	.1017
24	.0678	.4578	.6783	.4239	.0678	.0678	.061
Max	1.7318	.4578	.6783	.4239	.0678	.6443	1.9784
Min	.0678	.0857	.6783	.4239	.0678	.0532	.0514
Avg	.6211	.2718	.6783	.4239	.0678	.1927	.6746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 203 / Sawarde VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.39						
2	.373						
3	.373						
4	.373						
5	.4409						
6	.5426						
12		.4706	.5121	.5544	.4435	.4805	.5304
13							.4805
14							.4572
15							.2241
16							.1886
17	.5041						.2263
18							.5544
19							.78
20							.9326
21							.78
22							.5935
23							.407
24	.407		.4294	.3734	.3547	.3547	.3547
Max	.5426	.4706	.5121	.5544	.4435	.4805	.9326
Min	.373	.4706	.4294	.3734	.3547	.3547	.1886
Avg	.4255	.4706	.4708	.4639	.3991	.4176	.5007



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 204 / MALAGE AGRICULTURAL  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3561	.056	.0343	.0532	.5765	.5144	.4858
2	.3391	.056	.0343	.0532	.5596	.5144	.5144
3	.3391	.056	.0343	.052	.5596	.5316	.5316
4	.3391	.056	.0343	.0351	.5596	.5658	.5487
5	.4409	.056	.0343	.0354	.5765	.6516	.583
6	.5426	.056	.0686	.0354	.6783	.7888	.6516
7	.6783	.056	.0686	.0362	.9156	1.0631	.7956
8	.9835	.056	.0343	.0693	1.0822	1.2887	1.2431
9	.9496		.0343	.0625	1.2378	1.3395	1.1401
10	.017	.056	.0339	.0492	.017	.0543	.0514
11	.0187	1.7101	1.7804	1.5089	.0693	.0339	.0514
12	.0187	1.757	1.8313	1.6907		.0509	.0514
13	.0373	1.7939	1.7465	1.5592		.0509	.0543
14	.0373	1.7269	1.6617	1.5261		.0339	.0543
15	.0373	1.7238	1.5939		.0566	.0339	.0701
16	.0373	1.6598	1.6108		.0724	.0347	.0189
17	.0747	1.5415	1.3904	1.406	.0732	.0347	.0187
18	.0747	1.2431	1.1904	1.283	.0724	.0701	.0724
19	.056		.0543	.0339	.0693	.0648	.0509
20	.056	.0514	.0532		.0724	.0532	.0509
21	.056	.0514	.052	.017	.0543	.0457	.0339
22	.056	.0514	.0526	.017	.0543	.0457	.0339
23	.056	.0343	.0526	.5596	.0543	.0457	.0339
24	.373	.056	.0343	.0532	.5935	.5144	.4801
Max	.9835	1.7939	1.8313	1.6907	1.2378	1.3395	1.2431
Min	.017	.0343	.0339	.017	.017	.0339	.0187
Avg	.2489	.6320	.5632	.4827	.3812	.3510	.3175

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 148020 / 220/33KV Hamidwada S.St.

Feeder No / Name : 405 / SHRI DUTT INDIA INDUSTRIAL NON SHEDDABLE EXPRESS HV FEEDERS  
EXP Feeder KV- 33 / OUTGOING (CONTINOUS PROCESS)(NO STAGGERING)

DATE	26-FEB-18
HR	Load (MW)
14	.2801
Max	.2801
Min	.2801
Avg	.2801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 201 / 11KV WALWA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3326	.3696		.3292	.3326		.3189
2		.3881		.3155	.3142		.3189
3	.3142	.3841	.3045	.3366	.3142		.3658
4	.3696	.3658		.3856			.4435
5	.5544	.7682	.6089	.5316	.462		.543
6	.9795	.9877	1.1157	.985	.8215	1.0608	1.0164
7	1.0719	1.1888	1.0425	.9593	.961	1.134	.9816
8	.8871	.9328	.8413	.9328	.924	.9877	
9	.8316	.823	.823	.7682	.7392	.9145	.8871
10	.7316	.8048	.7602	.7392	.6219	.6268	.7577
11	.6767	.7316	.6268		.4938	.6024	.6283
12	.5853	.6219	.6154	.6653	.4938	.591	.5729
13	.5853	.5853	.5792	.6099	.5121		.5914
14	.5853	.5853	.5853	.5544	.4207	.5194	
15	.5487	.5853	.567	.5914		.4784	.5359
16	.6036	.6584	.5487	.6653		.5028	.6653
17	.6036	.6584	.6805	.7023	.4938	.6401	.6468
18	.6584	.8048	.7164	.7392	.6219	.7087	
19	.8596		.7499		.7682	.9134	1.0349
20	.8779	.8962	.9745		.8779	.8328	.9522
21	.8048	.823	.6836	.8686	.8048	.7011	
22	.6219	.6584	.6468		.6767	.5731	.6653
23	.3841	.4024	.4119		.4298	.4207	
24	.3326	.3109	.298	.3258	.3511	.3856	.3224
Max	1.0719	1.1888	1.1157	.985	.961	1.134	1.0349
Min	.3142	.3109	.298	.3155	.3142	.3856	.3189
Avg	.6435	.6667	.6752	.6319	.5922	.6996	.6446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 205 / 11 Kv Gahininath Ag LIS  
Expres Feeder KV- 11 / OUTGOING

PURELY LIS FEEDERS

DATE	22-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)
6		.0869	
7			.0924
8		.1014	
9		.1014	.0924
10	.0905	.124	.0924
11	.0905	.0867	.0924
12		.0876	.0924
13		.0895	.0924
14		.0895	
15		.0895	.0924
16		.0895	.0924
17		.0895	.0924
18		.0895	
Max	.0905	.124	.0924
Min	.0905	.0867	.0924
Avg	.0905	.0938	.0924

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 201 / 11 KV DHAMOD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6661				.7362		
2	.6935				.7362		.9313
3	.7011				.7712		
4	.7186				.8063		
5	.8413				.8764		.9709
6	.8842				.929		
7				.0173	1.1744		1.0056
8	1.1616		.0191	.0175	1.3146	1.1462	
9	1.1393				1.2795		1.1616
10	.0175				.0177		
11			1.3696		.0191		.0175
12			1.387	1.2136		.0191	
13			1.4737	1.4899			.0175
14			1.335		.0191		.0175
15			1.1789				.0175
16		1.4864	1.283	1.4217	.0191	.0191	.0173
17			1.335	1.3847			.0175
18			1.2795	1.2309	.0191	.0191	.0175
19			.0177	1.1568	.0191	.0191	.0177
20			.0175	.0175	.0191		.0177
21			.0177	.0177	.0191		.0175
22			.0177	.0175	.0191	.0191	.0177
23			.0175	.0177	.0191		.0177
24	.5721		.0191	.0173	.7108	.9313	.8322
Max	1.1616	1.4864	1.4737	1.4899	1.3146	1.1462	1.1616
Min	.0175	1.4864	.0175	.0173	.0177	.0191	.0173
Avg	.7395	1.4864	.7179	.6169	.4762	.3104	.3007

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 202 / 11 KV KELOSHI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177			.0177		
2	.0175			.0175		.0191
3	.0175			.0177		
4	.0175			.0177		
5	.0175			.0175		.0191
6	.0175			.0175		
7			.823	.0175		.0191
8	.0177	1.3253			.0191	
9	.0175			.0175		.0191
10	.0177			.0177		
11		.0173		2.1312		
12		.0173	.0177		2.1672	
13			.0177			
14				2.2565		2.2634
15						2.3663
16			.0177	2.1849	2.3059	2.3834
17			.0175			2.1776
18			.0171	1.7193	2.0285	1.9071
19			.0177	.0191	.0191	1.7511
20		.0175	.0177	.0191		.0173
21		.0175	.0175	.0191		.0173
22		.0175	.0175	.0191	.0191	.0173
23		.0175	.0175	.0191		.0173
24	.0177	1.0387	.6588	.0177	.0191	.0191
Max	.0177	1.3253	.823	2.2565	2.3059	2.3834
Min	.0175	.0173	.0171	.0175	.0191	.0173
Avg	.0176	.3086	.1381	.4507	.9397	.8676

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI

GAOTHAN FEEDER

VILLAGE Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1063				.1052		
2	.1063				.1052		.104
3	.1063				.1052		
4	.1227				.1052		
5	.1543				.1227		.104
6	.1907				.1753		
7	.1063			.3086	.333		.2947
8	.298		.3224	.2915	.298	.3045	
9	.2629				.298		.2601
10	.2279				.2454		
11			.2058		.197		.2254
12			.1734	.2126		.1734	
13			.1886	.1928			.1734
14			.1543		.1254		.1372
15			.156				.12
16		.1254	.1387	.1578	.1433	.1387	.1715
17			.208	.2454			.2058
18			.2254	.298	.2149	.2328	.2254
19			.3814	.3988	.3403	.3121	.3429
20			.3814	.4207	.3403		.3988
21			.3294	.3681	.2865		.3294
22			.2254	.2279	.2149	.2254	.2254
23			.1387	.1402	.1433		.156
24			.0895	.104	.1052	.1075	.104
Max	.298	.1254	.3814	.4207	.3403	.3121	.3988
Min	.1063	.1254	.0895	.104	.1052	.1075	.104
Avg	.1682	.1254	.2212	.2590	.2002	.2135	.2105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 204 / 11 KV BURAMBALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8322				1.0402		
2	.8842				1.0692		1.0576
3	.9114						
4	.9114				1.1393		
5	1.1096				1.1789		1.2136
6	1.2483				1.2483		
7					1.2656		1.1789
8	1.335				1.4723	1.5402	
9	1.387				1.4198		1.2136
11			1.283				
12			1.3176	1.6817			
13			1.387	1.595			
14			1.543		.0191		
15			1.5604				
16		1.4685	1.6124	1.5074			
17			1.3523	1.6644			
18			1.387	1.439			
24	.7888				.9816	1.0387	.9709
Max	1.387	1.4685	1.6124	1.6817	1.4723	1.5402	1.2136
Min	.7888	1.4685	1.283	1.439	.0191	1.0387	.9709
Avg	1.0453	1.4685	1.4303	1.5775	1.0834	1.2895	1.1269



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 202 / 11 KV TARALE

GAOTHAN FEEDER

VILLAGE(TARLE) Feeder KV- 11  
/ OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.144	.1423	.1423	.1406	.1829	.1612	.1612
2	.144	.144	.1265	.125	.1629	.1612	.1629
3	.144	.144	.1265	.1265	.1612	.1629	.1612
4	.144	.144	.1265	.1423	.1629	.1629	.1791
5	.2429	.2267	.1739	.2267	.2172	.2534	.2561
6	.3401	.3441	.2561	.3841	.3772	.3658	.3696
7	.426	.3887	.3841	.4001	.5041	.4854	.4668
8	.3932	.3563	.3521	.3953	.4294	.4481	.4108
9	.3239	.2881	.3201	.3521	.3734	.3696	.2957
10	.2881	.2688	.2561	.2688	.3142	.3142	.2926
11	.2561	.253	.2721	.2881	.2926	.2926	.2686
12	.253	.2372	.2753		.2926	.2774	.2507
13	.253	.2372	.2401	.3294	.2926	.2347	
14	.253	.208	.2241	.298	.3109	.2229	.2507
15	.253	.2401	.2187	.2743	.3077	.2401	.2561
16	.253	.2561	.2561	.2572	.3258	.2401	.2561
17	.2846	.2561	.2561	.3155	.3258	.2686	.2743
18	.3521	.2721	.3401	.3681	.3439	.2865	.3292
19	.4161	.4001	.4321	.5121	.4938	.5014	.462
20	.4321	.4161	.4001	.4805	.4706	.499	.4435
21	.3841	.3681	.3281	.3921	.4525	.439	.4066
22	.2561	.2846	.2721	.3174	.3258	.3475	.3292
23	.2056	.2056	.2105	.2614	.2353	.2218	.2378
24	.1581	.1581	.16	.16	.2033	.1791	.1829
Max	.4321	.4161	.4321	.5121	.5041	.5014	.4668
Min	.144	.1423	.1265	.125	.1612	.1612	.1612
Avg	.2750	.2600	.2562	.2963	.3149	.2973	.2915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 201 / 11 KV SHIRGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1107	.2846	.1341			
2		.1311	.3005	.1341			
3		.16	.3321	.1341			
4		.1638	.506	.1658			
5		.192	.6009	.1989			
6		.2372	.6325	.2683			
7		.3201	.759	.3353			
8		.3201	.8223	.2321			
9		.3163	.759	.2949			
11	.4915				.4973	.4694	.4999
12	.5441				.4641	.4641	.5506
13	.5624				.4641	.4915	.5441
14	.4687				.4641	.4915	.5506
15	.4687					.4915	.4801
16	.4062				.4111	.4915	.4858
17	.4062					.4588	.4801
18	.3749				.2846	.426	.3521
24		.112	.253	.0983			
Max	.5624	.3201	.8223	.3353	.4973	.4915	.5506
Min	.3749	.1107	.253	.0983	.2846	.426	.3521
Avg	.4653	.2063	.5250	.1996	.4309	.4730	.4929

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 202 / 11 KV PARITE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2214	.2372	.3768			
2		.2241	.2688	.3768			
3		.253	.2688	.3647			
4		.3239	.3321	.3932			
5		.4481	.4111	.426			
6		.5121	.4586	.5079			
7		.6882	.5792	.7125			
8		.7537	.8065	.7373			
9		.6722	.7748	.6562			
11	.6958				1.0442	1.0322	.9922
12	1.1385				1.1233	1.0978	1.0242
13	1.1203				.9892	1.0883	.9442
14	1.0911				1.0395	.9442	.9922
15	1.0562					.9922	.9069
16	1.0279				.933	1.0562	1.0402
17	.9061					.8802	1.0242
18	.7499				.6642	.8002	.9122
24		.2031	.2056	.3041			
Max	1.1385	.7537	.8065	.7373	1.1233	1.0978	1.0402
Min	.6958	.2031	.2056	.3041	.6642	.8002	.9069
Avg	.9732	.4300	.4343	.4856	.9656	.9864	.9795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2949	.2846	.3441			
2		.3201	.3321	.3441			
3		.3521	.4111	.3605			
4		.4801	.4428	.3563			
5		.6325	.5376	.421			
6		.7287	.5851	.7293			
7		.9122	.7274	.8122			
8		.9393	.933	1.0322			
9		.8322	.9172	.9762			
11	1.0911				1.2742		1.1523
12	1.2163				1.3916	1.4255	1.1683
13	1.2163				1.3916	1.2452	1.2483
14	1.0911				1.358	1.1523	1.2631
15	1.1012					1.2163	1.2323
16	1.1069				1.186	1.2003	1.2003
17	.9488					1.1203	1.0562
18	.7042				.9804	1.065	.8642
24		.2401	.2372	.2241			
Max	1.2163	.9393	.933	1.0322	1.3916	1.4255	1.2631
Min	.7042	.2401	.2372	.2241	.9804	1.065	.8642
Avg	1.0595	.5732	.5408	.56	1.2636	1.2036	1.1481

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 205 / 11 KV AWALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2218	.2075	.3174	.2614	.2075	.2427
2	.2075	.1829	.1886	.3174	.2587	.1886	.2427
3	.2075	.1848	.1886	.2957	.2743	.1886	.2218
4	.3403	.2957	.2075	.3174	.3142	.2075	.2614
5	.3734	.3696	.4527	.4108	.4066	.3961	.3734
6	.6036	.6283	.6348	.6535	.6348	.6036	.6413
7	.7167	.7392	.6979	.7842	.7762	.6413	.8215
8	.6348	.6878	.7095	.7392	.7392	.7023	.7023
9	.499	.5228	.5658	.6154	.6283	.5544	.5601
10	.4298	.4066	.4755	.4755	.4755	.4805	.4344
11	.3696		.4344	.4344	.3258	.3292	.3696
12	.3658		.3258	.4024	.3224	.3189	.3658
13	.3696	.3696	.3224	.4066	.3403	.3544	.3696
14	.3511	.3696	.3045	.924	.3224	.3391	.3696
15	.4066		.4557	.4435		.3429	.4572
16	.5175	.5544	.4908	.4755	.3658	.3988	.4706
17	.5175	.4805	.5014	.5975		.5609	.5068
18	.5175	.5914	.5493	.5975	.4706	.5609	.543
19	.8131	.8131	.8131	.7842		.788	.8871
20	.8131		.8962	.7392		.8589	.8779
21	.695	.6653	.7842	.7095	.3696	.7468	.7095
22	.5914	.4805	.5975	.5601	.3772	.5788	.5914
23	.3326	.2829	.4108	.3326	.3206	.3361	.3696
24	.2829	.2587	.2641	.3326	.2957	.2452	.2614
Max	.8131	.8131	.8962	.924	.7762	.8589	.8871
Min	.2075	.1829	.1886	.2957	.2587	.1886	.2218
Avg	.4659	.4553	.4783	.5278	.4140	.4554	.4854

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 206 / 11KV KANTHEWADI AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.16	.253	.2347			
2		.1966	.3163	.2347			
3		.2214	.3163	.2294			
4		.2591	.3163	.2622			
5		.2949	.3321	.2949			
6		.3239	.3479	.3277			
7		.4858	.4428	.4588			
8		.5182	.5376	.5304			
9		.5121	.5693	.5636			
11	.6642				.8139	.7712	.6401
12	.8002				.8478	.8139	.7449
13	.8322				.8648	.8139	.8097
14	.7274				.78	.7956	.8421
15	.7682					.7625	.8002
16	.6958				.759	.7712	.7773
17	.6009					.7362	.6874
18	.6154				.6009	.6962	.6154
24		.1406	.1898	.16			
Max	.8322	.5182	.5693	.5636	.8648	.8139	.8421
Min	.6009	.1406	.1898	.16	.6009	.6962	.6154
Avg	.7130	.3113	.3621	.3296	.7777	.7701	.7396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 207 / 11 KV SHIRGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.181	.1698	.2427	.2033	.1698	.2241
2	.168	.1663	.1698	.2427	.1848	.1698	.2054
3	.168	.1663	.1698	.2587	.1829	.1698	.2033
4	.2614	.2195	.1698	.2614	.2353	.1698	.2218
5	.3174	.3142	.2263	.3361	.3326	.3395	.2987
6	.5093	.5601	.5281	.5601	1.0679	.4904	.5281
7	.6535	.4435	.6036	.6535	.5973	.6036	.6535
8	.5788	.5544	.5281	.5175	.5228	.5658	.5544
9	.462	.4435	.3921	.4024	.4251	.439	.4481
10	.333	.3734	.3292	.3292	.3142	.3696	.3439
11	.3142		.2715	.3801	.2743	.3292	.2896
12	.2957		.2926	.3142	.3077	.3012	.3077
13	.2987	.2957	.2865	.2957	.2686	.2481	.2561
14	.2926	.2587	.2686	.2614	.2481	.2629	.2743
15	.2772		.2835	.2987		.298	.2402
16	.2957	.3511	.3012	.3326	.2378	.3681	.3109
17	.3292	.3881	.4119	.3658		.4031	.4024
18	.462	.4251	.443	.462	.3475	.4075	.4251
19	.5359	.5914	.6099	.5975		.5373	.5914
20	.5729		.5975	.5729		.5415	.5544
21	.5359	.4805	.5228	.462	.5359	.4854	.4668
22	.3881	.3326	.4294	.3511	.3961	.3734	.3921
23	.2957	.2614	.2427	.2772	.2452	.2801	.2402
24	.2263	.2218	.2075	.2402	.2218	.1886	.2241
Max	.6535	.5914	.6099	.6535	1.0679	.6036	.6535
Min	.168	.1663	.1698	.2402	.1829	.1698	.2033
Avg	.3650	.3514	.3523	.3757	.3575	.3546	.3607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 201 / 11 KV SOLANKUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3086	.3429	.3224			
2		.3086	.3601	.3224			
3		.3086	.3601	.3224			
4		.3086	.4801	.362			
5		.4115	.5487	.5434			
6		.5487	.6001	.7522			
7		1.2003	.1029	1.2894			
8		1.5775	1.5604	1.7909			
9		1.5432	1.4918	1.6655			
11	2.2291				2.1262	2.1948	2.4863
12	2.4348				2.2291	2.323	2.7435
13	2.3663				2.2634	2.2213	2.5892
14	2.3491				2.1776	2.1195	2.5549
15	2.1434				1.9719	2.0348	2.3834
16	1.9547				1.9547	2.0008	2.3148
17	1.8519				1.8004	1.9719	2.0919
18	1.3203				1.5043	1.4918	1.6956
24		.2915	.3429	.3224			
Max	2.4348	1.5775	1.5604	1.7909	2.2634	2.323	2.7435
Min	1.3203	.2915	.1029	.3224	1.5043	1.4918	1.6956
Avg	2.0812	.6807	.619	.7693	2.0035	2.0447	2.3575



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 202 / 11KV KALAMMAWADI

FEEDER SEPERATION/PURE AG

AG(SOLANKUR) Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2587				.1478	.2629	.3086
2					.1478	.2715	.3086
3	.2587				.1478	.2629	.3086
4	.2772				.1494	.2686	.3429
5	.2957				.1494	.2896	.3772
6	.3326				.2033	.3258	.4458
7	.4805					.4477	.5487
8	.5914				.5359	.5373	.6173
9	.6099				.4755	.5792	.583
11		.6805	.583	.6516			
12		.4877	.7202	.6516			
13		.7522	.703	.6516			
14		.6878	.6859	.6859			
15		.6335	.6935	.6173			
16		.6036	.6241	.583			
17		.5068	.591	.5144			
18		.4298	.4656				
21				.3734			
24	.2957				.112	.2686	.3086
Max	.6099	.7522	.7202	.6859	.5359	.5792	.6173
Min	.2587	.4298	.4656	.3734	.112	.2629	.3086
Avg	.3778	.5977	.6333	.5911	.2299	.3514	.4149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 203 / 11KV SOLANKUR VILLEGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.3086	.3086	.3077	.2987	.2686	.3086
2		.3086	.3086	.3045	.2987	.2686	.3086
3	.2987	.3086	.3086	.3077	.2987	.2804	.3086
4	.3361	.3429	.3429	.3258	.2987	.2865	.3429
5	.4481	.4458	.4801	.394	.4108	.3856	.4115
6	.7468	.6859	.6516	.6626	.6348	.6268	.6173
7	.8589	.823	.6859	.8059	.4108	.7362	.7888
8	.8589	.7545	.7392	.8059	.7392	.7164	.7202
9	.7468	.6516	.6283	.6697	.6653	.591	.583
10	.583	.6154	.6099	.583	.5144	.6283	.5658
11	.5487	.5373	.5544	.583	.4458	.4805	.5144
12	.4458	.5068	.5175	.4801	.4115	.5175	.5144
13	.4115	.4887	.5175	.4458	.4115	.4805	.4458
14	.4115	.4477	.4066	.4458	.3772	.4805	.4801
15	.4115	.362	.4481	.3772	.3772	.5175	.4458
16	.5144	.5611	.4854	.4115	.4115	.5228	.5487
17	.5144	.5792	.6516	.583	.4557	.6516	.5487
18	.6859	.6697	.6154	.7095	.6268	.6173	.6653
19	.9602	.8573	.9134	.961	.8954	.9259	.9979
20	.9945	.9945	.985	1.1088	1.0745	.9602	.961
21	.8573	.823	.8869	.8131	.8596	.7888	.7762
22	.6344	.6516	.6697		.6516	.6516	.6653
23	.4458	.4115	.4119		.3982	.4458	
24	.3361	.3086	.3086	.3258	.3361	.2865	.3429
Max	.9945	.9945	.985	1.1088	1.0745	.9602	.9979
Min	.2987	.3086	.3086	.3045	.2987	.2686	.3086
Avg	.5826	.5602	.5598	.5642	.5126	.5465	.5592

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 204 / 11KV AAINI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1029	.0686	.1075	.112	.0876	.0686
2		.1029	.0686	.1075	.112	.0905	.0686
3	.1307	.1029	.0686	.1075	.112	.0895	.0686
4	.1307	.1029	.0686	.1052	.112	.1052	.0686
5	.1307	.12	.1372	.1267	.1478	.1402	.1372
6	.1867	.1715	.1715	.1791	.1867	.181	.1715
7	.2614	.2401	.2058	.2149		.2328	.2058
8	.259	.2743	.2058	.2507	.2614	.2103	.2743
9	.2241	.3086	.1715	.2378	.2587	.1928	.2058
10	.2058	.2865	.1848	.1715	.2058	.168	.2743
11	.1029	.1991	.2218	.1029	.2401	.1494	.2915
12	.1029	.1991	.2957	.1029	.2058	.1663	.2401
13	.1372	.1227	.1848	.1029	.12	.2427	.12
14	.1372	.1254	.1294		.12	.2957	.1715
15	.1029	.1612	.1294	.1715	.1886	.2587	.1543
16	.1029	.181	.1663	.583	.2058	.2241	.2058
17	.2058	.2715	.197	.1715	.2149	.1372	.2058
18	.3086	.2865	.2149	.1867	.3224	.2058	.2218
19	.2401	.3077	.3506	.2614	.394	.2743	.2587
20	.2743	.3086	.3403	.2987	.3582	.3086	.2987
21	.2401	.2058	.2715	.3326	.2686	.2743	.2427
22	.1886	.1715	.2686		.1791	.1715	.1867
23	.1543	.1029	.1791		.1448	.1029	
24	.1294	.1029	.0686	.1086	.112	.0895	.0686
Max	.3086	.3086	.3506	.583	.394	.3086	.2987
Min	.1029	.1029	.0686	.1029	.112	.0876	.0686
Avg	.1777	.1899	.1820	.1920	.1992	.1833	.1830

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 201 / 11 KV KALAMMAVADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1663	.1848	.2033	.1478	.1663	.1848
2	.1663	.1663	.1663	.1848	.1478	.1663	.1848
3	.1663	.1663	.1663	.1848	.1478	.1478	.1663
4	.1663	.1663	.1663	.1848	.1478	.1478	.1848
5	.2033	.2033	.1848	.2033	.1848	.1663	.2033
6	.2587	.2772	.2772	.2587	.2402	.2587	.2587
7	.3511	.3696	.3696	.3511	.2957	.3696	.3326
8	.4066	.3696	.3511	.3881	.3326	.3881	.3881
9	.3511	.3696	.3142	.3881	.2957	.3511	.3511
10	.3142	.3511	.3142	.3881	.2772	.3142	.3142
11	.3142	.3142	.2957	.3326	.2402	.2772	.3142
12	.3142	.3511	.0554	.2957	.2218	.3142	.2772
13	.3142	.3142	.2587	.2957	.2772	.2772	.2587
14	.3142	.3142	.2218	.2587	.2402	.2772	.2587
15	.3142	.2957	.2772	.2772	.2402	.2772	.2772
16	.3142	.2957	.2957	.2957	.2587	.3326	.2957
17	.3511	.2957	.3511	.3142	.2772	.3326	.3326
18	.3326	.4066	.3696	.3511	.3142	.3696	.4066
19	.5359	.499	.5359	.4435	.462	.5729	.5359
20	.499	.4805	.499	.499	.4805	.499	.462
21	.4435	.4435	.4805	.4251	.4066	.4251	.462
22	.3511	.3511	.3696	.3326	.3142	.3511	.3881
23	.2218	.2218	.2587	.2218	.2218	.2402	.2957
24	.2033	.1848	.1848	.2218	.1663	.1663	.2033
Max	.5359	.499	.5359	.499	.4805	.5729	.5359
Min	.1663	.1663	.0554	.1848	.1478	.1478	.1663
Avg	.3072	.3072	.2895	.3042	.2641	.2995	.3057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 202 / 11 KV KUDUTRI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0373	.056	.0373	.0373	.0373	.0373
2	.0373	.0373	.0373	.0373	.0373	.0373	.0373
3	.0373	.0373	.0373	.0373	.0373	.0373	.0373
4	.0373	.056	.0373	.0373	.0373	.0373	.037
5	.056	.0747	.056	.056	.056	.056	.0747
6	.132	.1494	.1494	.1307	.112	.1307	.112
7	.1867	.1867	.1867	.168	.168	.1867	.1494
8	.168	.1867	.1867	.168	.1494	.168	.168
9	.1867	.2054	.1294	.1867	.1494	.1867	.1867
10	.1867	.168	.1294	.168	.168	.1307	.1494
11	.1307	.1307	.1478	.1494	.0934	.112	.1307
12	.1494	.1307	.1478	.112	.112	.1494	.1307
13	.0924	.0747	.0924	.112	.0934	.1494	.0747
14	.0934	.0934	.0924	.1307	.0924	.1307	.1307
15	.0934	.0934	.1294	.112	.0924	.1307	.0934
16	.112	.0934	.1294	.1307	.112	.1307	.1867
17	.1867	.1294	.1307	.1494	.0934	.1494	.1494
18	.1494	.1494	.1494	.1307	.1494	.1494	.2241
19	.2427	.2427	.2614	.1867	.2614	.2427	.2987
20	.2427	.2801	.2801	.2241	.2614	.2427	.2801
21	.2241	.2427	.2614	.2054	.2241	.2054	.2614
22	.1494	.1494	.1867	.1307	.1307	.1307	.168
23	.0747	.0934	.112	.056	.0747	.056	.0934
24	.0747	.056	.0747	.056	.0373	.056	.0373
Max	.2427	.2801	.2801	.2241	.2614	.2427	.2987
Min	.0373	.0373	.0373	.0373	.0373	.0373	.037
Avg	.1292	.1291	.1334	.1214	.1158	.1268	.1354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 203 / Fejiwade Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3052	.3222			.2204	.3391
2	.3222	.3052			.2035	.3052
3	.3222	.3052			.2035	.3052
4	.3222	.3052			.2035	.3052
5	.373	.3222			.2374	.3561
6	.39	.3222			.39	.3812
7	.5868	.4578			.4917	.4807
8	.5365	.5426			.5765	.5967
9	.6036	.5868			.5365	.6036
11		.8718	.8131	.7122		
12		.8383	.7461	.763		
13		.7712	.7461	.7122		
14		.788	.7122	.6443		
15		.788	.763	.6613		
16		.7209	.7291	.6783		
17		.6299	.6274	.6443		
18		.4578	.5087	.6348		
24	.2374	.3222			.2204	.2204
Max	.6036	.8718	.8131	.763	.5765	.6036
Min	.2374	.3052	.5087	.6348	.2035	.2204
Avg	.3999	.5365	.7057	.6813	.3283	.3893

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 204 / 11 KV PIRAL AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	22-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6133	.7293	.8309		
2		.6133	.7293	.8215		
3		.6133	.7127	.8215		
4		.6464	.7127	.8383		
5		.7625	.7956	.8886		
6		.9779	.9614	1.073		
7		1.4752	1.4918	1.643		
8		1.8896	1.8067	2.0622		
9		1.7072	1.326	2.2377		
11	2.2939			2.6242	2.8012	2.5857
12	2.4086			2.4034	2.8841	2.6852
13	1.8023			2.3205	2.8012	2.7515
14	2.2611			2.5149	2.5857	2.9172
15	2.2447			2.5149	2.1879	2.6023
16	2.2119			2.3868	2.5526	2.536
17	1.9662			2.1051	2.536	2.4034
18	1.5729			2.1051	2.0719	1.9227
24		.6133	.5801	.6952		
Max	2.4086	1.8896	1.8067	2.6242	2.8841	2.9172
Min	1.5729	.6133	.5801	.6952	2.0719	1.9227
Avg	2.0952	.9912	.9846	1.7159	2.5526	2.5505

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 201 / 11KV I.T.Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.0187	.0187	.0177	.0181	.0187	.0187
2	.0181	.0187	.0187	.0177	.0181	.0187	.0187
3	.0181	.0187	.0187	.0177	.0181	.0187	.0187
4	.0181	.0187	.0187	.0177	.0181	.0187	.0187
5	.0181	.0187	.0187	.0177	.0181	.0187	.0187
6	.0181	.0187	.0187	.0177	.0181	.0187	.0187
7	.0181	.0187	.0187	.0177	.0181	.0187	.0187
8	.0181	.0373	.0187	.0177		.0187	.0185
9	.0362	.0373	.0187	.0177	.0362	.0187	.0187
10	.0354	.0354	.0181	.0187	.0177	.0362	.0373
11	.0354	.0354	.0181	.0187	.0354	.0362	.0373
12	.0354	.0532	.0181	.0187	.0354	.0362	.0373
13	.0354	.0532	.0181	.0187	.0354	.0362	.0373
14	.0532	.0532	.0181	.0187	.0354	.0362	.0373
15	.0532	.0532	.0181	.0187	.0532	.0543	.0373
16			.0181	.0187	.0532	.0543	.056
17	.056	.056	.0177	.0181	.0373	.0532	.0543
18	.056	.0373	.0177	.0181	.0373	.0532	.0543
19	.0373	.0373	.0177	.0185	.0373	.0354	.0362
20	.0373	.0373	.0177	.0181	.0373	.0354	.0362
21	.0373	.0373	.0177	.0181	.0187	.0354	.0181
22	.0187	.0373	.0177	.0181	.0187	.0187	.0181
23	.0373	.0187	.0177	.0181	.0187	.0187	.0181
24	.0181	.0187	.0187	.0177	.0181	.0187	.0187
Max	.056	.056	.0187	.0187	.0532	.0543	.056
Min	.0181	.0187	.0177	.0177	.0177	.0187	.0181
Avg	.0316	.0334	.0182	.0181	.0283	.0303	.0292



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 202 / HOCKY STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1109	.112	.1307	.1075	.1109	.112	.112
2	.1109	.112	.112	.1075	.1109	.112	.112
3	.1109	.112	1.2323	.1075	.1109	.112	.112
4	.1109	.112	.112	.0895	.1109	.112	.112
5	.1109	.112	.112	.0895	.1109	.112	.112
6	.1109	.1307	.1307	.0895	.1109	.112	.1307
7	.1109	.112	.1307	.1075	.1109	.112	.112
8	.1109	.168	.1494	.1254		.1494	.1494
9	.1294	.168	.1494	.1612	.1478	.168	.168
10	.1075	.1433	.1294	.168	.1433	.1478	.1494
11	.1433	.1254	.1109	.168	.1254	.1294	.1307
12	.1075	.1254	.1294	.1307	.1075	.1478	.1307
13	.1254	.1075	.1109	.1307	.1075	.1109	.1307
14	.1075	.1254	.1109	.0934	.1075	.0924	.112
15	.1075	.1075	.1109	.0934	.1075	.0924	.112
16			.1109	.112	.1254	.1109	.112
17	.112	.112	.1075	.1109	.112	.1075	.0924
18	.112	.112	.1254	.1109	.112	.1075	.1109
19	.2054	.1867	.1791	.1848	.1867	.1791	.1663
20	.1867	.1867	.1791	.1848	.1867	.1791	.1848
21	.1867	.1867	.1791	.1663	.1867	.1791	.1848
22	.1867	.1867	.1612	.1663	.1867	.1867	.1663
23	.168	.168	.1612	.1294	.1307	.168	.1478
24	.1294	.1307	.1494	.1254	.1109	.1307	.112
Max	.2054	.1867	1.2323	.1848	.1867	.1867	.1848
Min	.1075	.1075	.1075	.0895	.1075	.0924	.0924
Avg	.1305	.1366	.1798	.1275	.1287	.1321	.1318

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 204 / RENUKA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.8029	.8402	.8402	.7655	.7655	.8215
2	.7468	.7655	.7842	.8215	.7282	.7095	.7095
3	.7468	.7655	.7842	.8029	.7282	.7095	.7095
4	.7468	.7655	.7842	.8029	.7282	.7095	.7095
5	.7468	.7655	.7842	.7842	.7655	.7282	.7468
6	.8402	.8402	.8215	.8215	.8402	.8215	.8215
7	.8775	.9335	.9149	.8589	.8775	.8215	.8589
8	.9522	.9149	.9335	.8402	.9335	.8775	.9522
9	.9896	1.0269	.0934	.9522	.9522	.9522	.9335
10	.9335	.9335	.9709	.9795	.9149	.9522	.9335
11	.9145	.9709	.9896	.924	.8029	.9335	.9149
12	.8764	.8775	.8402	.8686	.7842	.9896	1.0269
13	1.7353	.8589	.9522	.8131	.8402	.9335	.9149
14	.8029	.8402	.9149	.8131	.8402	.9522	.9522
15	.8402	.8402	.8775	.8131	.8029	.8775	.9709
16	.8589	.8029	.8589	.8131	.7842	.8962	.9709
17	.8962	.9522	.8589	.7762	.7842	.8764	.8962
18	.9335	1.2136	.9149	.8589	.7842	1.1812	.9335
19	1.2136	1.2136	1.1203	1.1389	1.0082	1.2384	1.2323
20	2.4272	1.251	1.1576	1.1763	1.2323	1.2003	1.2136
21	1.1763	1.1949	1.0829	1.1088	1.0642	1.1812	1.1576
22	1.1203	1.1203	1.0269	1.0456	1.0456	1.0829	1.1016
23	1.0082	1.1016	.9522	.9709	.9896	1.0269	1.0269
24	.8775	.8589	.8962	.8962	.8215	.8402	.8775
Max	2.4272	1.251	1.1576	1.1763	1.2323	1.2384	1.2323
Min	.7468	.7655	.0934	.7762	.7282	.7095	.7095
Avg	1.0019	.9421	.8814	.8967	.8674	.9274	.9328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 205 / SUBHASH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6535	.6722	.6722	.6859	.5975	.5975	.6161
2	.6161	.6348	.6535	.6668	.5415	.5601	.5601
3	.6161	.6348	.6535	.6478	.5359	.5601	.5601
4	.6161	.6348	.6535	.6478	.5359	.5601	.5601
5	.6283	.6348	.6722	.6668	.5601	.5788	.5975
6	.6908	.7095	.7282	.743	.6722	.6722	.6535
7	.8402	.8215	.7468	.8002	.7468	.8402	.9149
8	.8775	.9149	.7842	.8764		.9149	.9335
9	.8402	.9335	.8215	.8573	.7842	.8962	.8962
10	.7811	.7621	.8215	.8215	.724	.8215	.8029
11	.743	.6859	.7468	.7842	.6287	.6161	.7282
12	.743	.724	.6535	.7282	.6097	.5975	.7468
13	.6478	.6668	.7095	.6535	.6287	.5788	.7468
14	.6668	.6287	.6908	.6348		.5975	.7842
15	.6859	.6287	.6535	.6348		.5601	.7842
16	.6535		.6535	.6348	.8573	.6722	.7095
17	.5975	.5601	.5335	.6161	.7468	.6668	.6348
18	.7842	.6908	.743	.7282	.7468	.743	.7842
19	1.1389	1.0829	1.1241	1.0642	1.0456	1.1431	1.1203
20	1.2136	1.1203	1.1622	1.0829	1.1016	1.1431	.9522
21	1.0269	1.0642	.9717	.9709	.9896	1.1241	.9896
22	1.0082	.9896	.8954	.8962	.8962	.9522	.9522
23	.9149	.8962	.8383	.7842	.8029	.8589	.8402
24	.7282	.7468	.7468	.724	.6535	.6722	.6908
Max	1.2136	1.1203	1.1622	1.0829	1.1016	1.1431	1.1203
Min	.5975	.5601	.5335	.6161	.5359	.5601	.5601
Avg	.7797	.7756	.7637	.7646	.7336	.7470	.7733

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 201 / SAMBHAJI NAGAR CZ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7922	.7545	.8299	.7947	.7577	.7023	.7392
2	.7356		.7545	.7392	.7207	.6653	.7023
3	.7356	.6979	.7167	.7023	.7207	.6838	.6838
4	.811		.7545	.7023	.7392	.6838	.6838
5	.8488	.7167	.7733	.7207	.7947	.7392	.7207
6	.8865		.8676	.7577	.8316	.8316	.8131
7	.9054	.8676	.8676	.8316	.8775	.9055	.924
8	.9242	.9431	.8865	.8589	.9055	.9055	.8686
9	.9808	1.0562	.9242	.9425	.8501	.961	.9709
10	.8865	.8488	.9242	.961	.8029	.924	.8962
11	.9054	.9242	.9054	.8501	.6838	.8316	.8501
12	.7922	.8488	.811	.8686	.6283	.7947	.8686
13	.7356	.9054	.6979	.7577	.6283	.7392	.7762
14	.7922	.6979	.7545	.7392	.6283	.7392	.7392
15	.811	.8299	.811	.7577	.6653	.8131	.7947
16	.8865	.9054	.7922	.8402	.6653	.8131	.8501
17	.8299		.8299	.8686	.6838	.8131	.924
18	.9431	1.905	.9242	.8871	.7392	.9896	.9425
19		1.3203	1.3014	1.2382	1.1458	1.3306	1.2936
20	1.3203	1.2826	1.2826	1.2197	1.1827	1.3121	1.2382
21		1.2449	1.2071	1.2012	1.1643	1.2382	1.2012
22	1.1883	1.1506	1.1506	1.1088	1.1273	1.1088	1.1088
23	.9808	.9997	1.0374	.961	.9425	.9795	.9979
24	.8488	.8488	.8488	.8501	.8131	.7762	.7947
Max	1.3203	1.905	1.3014	1.2382	1.1827	1.3306	1.2936
Min	.7356	.6979	.6979	.7023	.6283	.6653	.6838
Avg	.8882	.9874	.9022	.8816	.8208	.8867	.8909

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 202 / JAIL KOLHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2801	.2218	.2957	.2987	.2427	.2218	.2614
2	.2614		.2561	.2614	.2054		.2427
3	.2614	.2012	.2218	.2427	.2054	.2033	.2241
4	.2801		.2218	.2427	.2241		.2241
5	.3174	.2772	.2587	.2801	.2801	.2402	.2614
6	.3361		.3326	.3174	.3174		.3361
7	.3361	.3326	.3326	.2987	.3361	.3326	.3547
8	.3547	.3142	.3547	.3361	.3547	.3511	.3547
9	.4481	.4024	.3734	.3361	.3734	.3881	.4805
10		.3547	.3734	.2561	.4066	.3361	.3696
11	.3658	.3511	.3547	.2587	.3142	.3142	.3475
12	.2402	.2587	.2614		.2241	.2241	.2743
13	.2561	.2587	.3174	.2033	.2241	.2241	.7842
14	.2926	.3361	.3174		.3361	.3361	
15	.2195	.2427	.2427	.2195	.2587	.2614	.2561
16	.2957	.3174	.3174		.2957	.2987	
17	.3109	.2957	.3174	.2378	.3511	.2957	.3292
18	.2587	.3109	.3547	.2241		.2987	.3361
19		.4755	.5601	.4108	.499	.5415	.4854
20	.5359	.499	.5975	.4527		.5788	.4668
21		.4435	.4481	.4481	.439	.4481	.4668
22	.4251	.4435	.4294	.4108	.439	.4294	.4294
23	.3696	.3734	.3734	.3547		.3734	.3734
24	.3174	.2957	.3326	.3361	.2801	.2587	.2987
Max	.5359	.499	.5975	.4527	.499	.5788	.7842
Min	.2195	.2012	.2218	.2033	.2054	.2033	.2241
Avg	.3220	.3336	.3435	.3060	.3146	.3312	.3617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 204 / KALAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8501	.8413	.8501	.924	.8596	.8779	.8316
2	.8316		.7762	.8686	.823		.8131
3	.8316	.7316	.7392	.8131	.823	.8413	.7947
4	.924		.7947	.7762	.9145		.8131
5	1.0534	.823	.8501	.7947	1.0242	.9511	.8501
6	1.1827		1.0974	.9979	1.1888		1.0164
7	1.2752	1.2986	1.3491	1.1523	1.3169	1.3535	1.3121
8	1.262	1.4083	1.3443	1.3121	1.3535	1.3717	1.3676
9	1.1706	1.2254	1.1088	1.2752	1.1888	1.134	1.1827
10	1.0242	1.0791	.9511	1.0974	.9877	.9979	.9877
11	.8596	.8962	.8596	1.0608	.8316	.8501	.8779
12	.9511	.9328	.9328			.9522	.9145
13	.9145	.8962	.9145	.1829		.9522	.9055
14	.823	.8413	.9877				
15	.8596	1.0059	.8962	1.0059	.9335	.8316	.9328
16	.8871	.9511	.439		.9055	.9055	
17	1.0242	.9511	1.0242	1.0242	.9425	.8871	.9694
18	.9511	1.0059	1.0425	1.1706		1.1458	1.0242
19		1.5339	1.46	1.5546	1.4449	1.5524	1.5364
20	1.5364	1.6632	1.5893	1.4815		1.6078	1.5729
21		1.6078	1.46	1.4266	1.4632	1.5339	1.4632
22	1.3717	1.5154	1.386	1.3535	1.3169	1.386	1.3535
23	1.0974	1.2012	1.2012	1.0974		1.1273	1.134
24	.924	.9511	.9709	.9979	.9145	.9328	.8871
Max	1.5364	1.6632	1.5893	1.5546	1.4632	1.6078	1.5729
Min	.823	.7316	.439	.1829	.823	.8316	.7947
Avg	1.0275	1.1124	1.0427	1.0651	1.0685	1.1096	1.0700

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 205 / JARAG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8131	.823	.7865	.7316	
2		.7762	.7682	.7316	.695	.695
3		.7392	.7316	.7316	.6584	.6767
4		.7577	.7316	.7682	.6584	.6767
5		.7762	.7499	.823	.695	.7133
6		.8316	.7499	.8596	.8596	.823
7		.9328	.7865	.8596	.9328	.8962
8		.8686	.8413	.8962	.8962	.9694
9		.7947	.8596	.9145	.8962	.8962
10		.7392	.8048	.7499	.7682	.7499
11		.7762	.7865	.6767	.695	.695
12		.7947	.7499	.6767	.6767	.6767
13		.6767	.7133	.6219	.6767	.7316
14		.6584	.7316	.6401	.6767	.695
15		.6401	.6584	.6036	.6584	.695
16	.7316	.6401	.6767	.6401	.6401	.695
17	.7316	.6584	.695	.6584	.6584	.7499
18	.823	.7499	.8048	.7133	.8413	.823
19	1.2803	1.3169	1.2986	1.2254	1.3535	1.3352
20	1.3352	1.3676	1.2986	1.2986	1.3717	1.3535
21	1.3352	1.2986	1.262	1.3169	1.3352	1.2986
22	1.2803	1.2071	1.2071	1.1888	1.2071	1.2437
23	1.0608	1.0791	.9511	.9694	1.0242	1.0242
24		.8413	.8962	.823	.8048	.823
Max	1.3352	1.3676	1.2986	1.3169	1.3717	1.3535
Min	.7316	.6401	.6584	.6036	.6401	.6767
Avg	1.0723	.8639	.8573	.8406	.8505	.8668

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 206 / 11KV I.T.I.FEEDER

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0171	.0171	.0171	.0189	.0189
2		.0171	.0171	.0171	.0189	.0189
3		.0171	.0171	.0171	.0189	.0189
4		.0171	.0171	.0171	.0189	.0189
5		.0171	.0171	.0171	.0189	.0189
6		.0171	.0171	.0171	.0189	.0189
7		.0171	.0171	.0171	.0189	.0189
8		.0171	.0171	.0171	.0189	.0189
9		.0171	.0171	.0171	.0189	.0189
10		.0171	.0171	.0171	.0189	.0189
11		.0171	.0171	.0171	.0189	.0189
12		.0171	.0171	.0171	.0189	.0189
13		.0171	.0171	.0171	.0189	.0189
14		.0171	.0171	.0171	.0189	.0189
15		.0171	.0171	.0171	.0189	.0189
16		.0171	.0171	.0171	.0189	.0189
17		.0171	.0171	.0171	.0189	.0189
18	.0171	.0171	.0171	.0171	.0189	.0189
19	.0171	.0171	.0171	.0171	.0189	.0189
20	.0171	.0171	.0171	.0171	.0189	.0189
21	.0171	.0171	.0171	.0171	.0189	.0189
22	.0171	.0171	.0171	.0171	.0189	.0189
23	.0171	.0171	.0171	.0171	.0189	.0189
24		.0171	.0171	.0171		.0189
Max	.0171	.0171	.0171	.0171	.0189	.0189
Min	.0171	.0171	.0171	.0171	.0189	.0189
Avg	.0171	.0171	.0171	.0171	.0189	.0189



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 412 / 33kv Shenda Park out going NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.9938	2.963	2.9938	2.9938	2.8275	2.7721	2.9938
2	2.7721		2.8829	2.8829	2.6057		2.8829
3	2.7721	2.7435	2.7721	2.8275	2.6057	2.4949	2.7721
4	2.9384		2.7721	2.8275	2.7721		2.7721
5	3.1602	2.9384	2.8829	2.8275	3.1047	2.6612	2.9384
6	3.4374		3.2156	2.8829	3.3265		3.2156
7	3.7146	3.77	3.5482	3.1602	3.5482	3.6591	3.6591
8	3.9918	4.0472	3.7146	3.7146	3.8809	3.8809	3.8809
9	3.77	3.8255	3.6591	3.77	3.7146	3.7146	3.77
10	3.5482	3.4374	3.3265	3.4374	3.3819	3.4928	3.4374
11	3.2156	3.3265	3.2156	3.3265	3.0493	3.1047	3.271
12	3.0493	3.271	2.963		2.5503	2.9384	3.1602
13	2.8829	2.9384	2.9938	2.8829	2.2177	2.8829	2.9384
14	2.7721	2.8829	2.8829		2.2177	2.7721	
15	2.9938	2.8829	2.6612	2.7721	2.1622	2.7166	2.9938
16	2.9938	2.8829	2.7721		2.1622	2.9384	
17	2.9384	2.9384	2.7721	2.8829	2.9384	2.9384	3.1047
18	3.3819	3.0493	3.2156	3.1602		3.3265	3.4374
19		4.269	4.4353	4.4353	4.5462	4.7125	4.8234
20	4.768	4.3799	4.6016	4.4353		4.768	4.8788
21		4.4907	4.269	4.269	4.3244	4.4353	4.4353
22	4.4353	4.3244	4.1027	4.1027	4.1027	4.269	4.1581
23	3.8809	3.8255	3.7146	3.4374		3.77	3.77
24	3.1602	3.2156	3.2156	3.1602	2.9938	2.9938	3.1602
Max	4.768	4.4907	4.6016	4.4353	4.5462	4.768	4.8788
Min	2.7721	2.7435	2.6612	2.7721	2.1622	2.4949	2.7721
Avg	3.3441	3.4477	3.3160	3.3423	3.0968	3.3925	3.4752

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 208 / RAJARAMPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.547	.5281	.5716	.5658	.4904	.5093	.5281
2	.5281	.5093	.5716	.5658	.4904	.4904	.5281
3	.4904	.4904	.5335	.5093	.4527	.4715	.4904
4	.4904	.4904	.5335	.5093	.4527	.4715	.4904
5	.4904	.5093	.5335	.547	.4904	.4715	.547
6	.5281	.5658	.5525	.547	.5281	.5093	.6036
7	.679	.6602	.6859	.5847	.7167	.679	.7167
8	.7922	.7545	.743	.679	.8676	.7733	.7545
9	.7733	.7733	.7545	.7356	.7733	.7545	.811
10	.8573	.8488	.8299	.7356	.7733	.8488	.8192
11	1.1431	1.2637	1.1694	.9808	1.1317	1.1622	1.086
12	1.1812	1.2637	1.3769	1.0562	1.1694	1.2003	1.2003
13	1.2003	1.3203	1.2637	1.0374	1.105	1.2193	1.086
14	1.0669	1.1317	1.0374	.8865	1.105	1.1431	1.0669
15	1.0669	1.094	1.0562	.8865	1.0288	1.0669	1.086
16	1.0374	1.1694	.9997	.9242	1.0185	1.2071	
17	1.1694	1.2765	1.0374	1.0374	1.1506	1.2449	1.2449
18	1.2637	1.3717	1.2071	1.0562	1.1883		1.3203
19	1.6409	1.6766	1.4901	1.4146	1.5844	1.6975	1.5655
20	1.6221	1.5242	1.4712	1.4523	1.4901		1.5278
21	1.2826	1.2193	.9997	1.1694	1.2449	1.2449	1.2826
22	.8676	.8954	.9054	.8299	.8299	.8676	.8488
23	.7167	.743	.7733	.679	.7356	.679	.7356
24	.6036	.6036	.6287	.6036	.5658	.5658	.5658
Max	1.6409	1.6766	1.4901	1.4523	1.5844	1.6975	1.5655
Min	.4904	.4904	.5335	.5093	.4527	.4715	.4904
Avg	.9183	.9451	.9052	.8330	.8910	.8763	.9089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 209 / 11 KV VARDHAMAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2829	.2641	.2286	.2263	.2263	.2641	.2641
2	.2829	.2452	.2286	.2263	.2263	.2263	.2641
3	.2452	.2263	.2286	.2075	.2263	.2263	.2641
4	.2452	.2263	.2286	.2075	.2263	.2263	.2641
5	.2829	.2452	.2667	.2452	.2641	.2452	.2641
6	.3395	.3206	.2667	.2829	.3018	.2641	.3018
7	.3584	.3395	.381	.3395	.3584	.3395	.3772
8	.3961	.415	.4191	.3772	.3772	.415	.3961
9	.3772	.415	.3772	.3772	.3772	.3772	.3772
10	.381	.3772	.3395	.3584	.3772	.3772	.4191
11	.4382	.4527	.4338	.415	.415	.4572	.4763
12	.4572	.4527	.5281	.3584	.4527	.4191	.4572
13	.4572	.4527	.4527	.3395	.4191	.4191	.4191
14	.4001	.3772	.3961	.3206	.381	.4191	.4191
15	.3429	.3772	.3772	.3206	.381	.381	.381
16	.3772	.3772	.3772	.3395	.3584	.3772	
17	.3772	.4191	.415	.3206	.3961	.3772	.3772
18	.4527	.4191	.4527	.3772	.415	.4338	.4527
19	.5658	.5716	.5281	.5847	.547	.6036	.6036
20		.5716	.6036	.5281	.547	.5658	.5281
21	.4715	.4954	.4715	.4527	.4715	.4715	.4527
22	.415	.4191	.3772	.3772	.3772	.415	.3772
23	.3395	.3429	.3018		.3206	.3395	.3772
24	.3206	.2641	.2858	.2641	.2641	.2829	.3018
Max	.5658	.5716	.6036	.5847	.547	.6036	.6036
Min	.2452	.2263	.2286	.2075	.2263	.2263	.2641
Avg	.3742	.3778	.3736	.3411	.3628	.3718	.3833

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.547	.5525	.6036	.5093	.5658	.547
2		.5281	.5525	.5658	.5093	.5281	.547
3		.5093	.5716	.5658	.4715	.4904	.5093
4		.5093	.5716	.5658	.4715	.4904	.5093
5		.5093	.5906	.5847	.4904	.4904	.547
6		.5847	.6478	.5847	.5658	.5658	.6036
7		.6413	.6478	.5847	.6602	.5847	.6413
8		.6979	.6859	.6036	.679	.6413	.679
9		.8676	.7733	.6413	.7922	.7545	.7922
10	1.105	1.094	.8865	.6602	.9997	.9997	1.105
11	1.3527	1.4146	1.1506	.9054	1.2071	1.3717	1.2955
12	1.4861	1.4335	1.3957	.8865	1.3014	1.3336	1.2955
13	1.467	1.5278	1.358	.9431	1.448	1.4861	1.4861
14	1.3527	1.4901	1.3203	.9431	1.3908	1.4098	1.3527
15	1.4289	1.3957	1.226	.8676	1.4098	1.3527	1.3908
16	1.3957	1.4523	1.3014	.9808	1.4712	1.4901	
17	1.3769	1.5242	1.226	.9619	1.3203	1.4712	1.3769
18	1.3392	1.4098	1.1694	.8676	1.2637	1.358	1.4146
19	1.4523	1.5813	1.4146	1.1506	1.358	1.4712	1.5278
20	1.3203	1.467	1.2826	1.1317	1.2826	1.226	1.2449
21	1.0374	1.086	.9997	.9619	1.0374	1.0185	1.0751
22	.811	.8764	.9242	.811	.8299	.7922	.9054
23	.7733	.8192	.8488	.6979	.679	.7922	.7733
24		.6036	.6478	.679	.6036	.5847	.6413
Max	1.4861	1.5813	1.4146	1.1506	1.4712	1.4901	1.5278
Min	.7733	.5093	.5525	.5658	.4715	.4904	.5093
Avg	1.2642	1.0238	.9477	.7812	.9480	.9695	.9679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 211 / Takala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.679	.6287	.6413	.5847	.6036	.6036
2	.6036	.6224	.5906	.5847	.5847	.5658	.6036
3	.5658	.5847	.6097	.5847	.5658	.5281	.5658
4	.5658	.6036	.6097	.6224	.5658	.5281	.5658
5	.6036	.6602	.6478	.6979	.6036	.5281	.6413
6	.6979	.7167	.6859	.7356	.7356	.7167	.6979
7	.8676	.8865	.8383	.7733	.7922	.9054	.8676
8	.9054	.9431	.8764	.7733	.9431	.9808	.8676
9	.8676	.9054	.9242	.8865	.9431	.9431	.9431
10	.8192		.811	.8865	.8488	.811	.8764
11	.7621	.811	.7922	.7545	.7922	.7811	.8002
12	.7621	.7545	.7545	.7545	.7545	.724	.7621
13	.724	.7545	.7545	.6602	.7049	.7621	.7811
14	.743	.7545	.679	.7167	.6668	.7049	.743
15	.7621	.7167	.6413	.6979	.6668	.7049	.743
16	.811	.7545	.7167	.6224	.6602	.7167	
17	.7545	.7811	.7167	.6979	.7733	.7167	.8299
18	.7733	.7621	.7356	.6979	.7733	.7545	.8488
19	1.0185	.9335	1.0185	.9242	1.0185	.9808	.9808
20	1.1128	1.105	1.0185	.9619	1.0185	1.0562	1.094
21	1.0562	.9717	.9997	.8865	.9997	.9619	1.0374
22	.9997	.9717	.9619	.8676	.9242	.9431	.9619
23	.8488	.8192	.9054	.7922	.8488	.7733	.8488
24	.679	.7356	.724	.6979	.6413	.6413	.679
Max	1.1128	1.105	1.0185	.9619	1.0185	1.0562	1.094
Min	.5658	.5847	.5906	.5847	.5658	.5281	.5658
Avg	.7878	.7925	.7767	.7466	.7671	.7638	.7975

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 212 / 11 KV SHAHUMILL KOP.MAULI

SHEDDABLE URBAN

FEED Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4715	.5093	.4954	.4904	.4527	.4904	.4904
2	.4338	.4715	.4763	.4527	.415	.4338	.4527
3	.4338	.4527	.4763	.4527	.415	.415	.4527
4	.415	.4527	.4954	.4715	.415	.4338	.4527
5	.415	.4527	.5144	.4715	.4338	.4527	.4904
6	.4904	.5093	.5335	.5093	.4715	.5281	.5658
7	.6413	.6224	.6668	.5093	.547	.5658	.5847
8	.6413	.6036	.5906	.5658	.679	.6036	.6602
9	.6224	.6602	.5658	.6036	.5847	.6036	.6224
10	.5906	.6036	.547	.547	.5847	.547	.5906
11	.6097	.6224	.5658	.5281	.5658	.5716	.6097
12	.5906	.5658	.679	.547	.5658	.6097	.6097
13	.6097	.6413	.6224	.5658	.5906	.5906	.6478
14	.5906	.6036	.5658	.4904	.6097	.5906	.6287
15	.5716	.5847	.5658	.4904	.5906	.5716	.6097
16	.547	.5847	.5658	.4904	.5093	.5281	
17	.5658	.5906	.6224	.5281	.547	.6036	.6413
18	.679	.7049	.6602	.6413	.5847	.6979	.679
19	.9054	.9526	.8865	.8676	.8865	.8299	.9054
20	.9997	.9907	.9242	.9431	.8865	.9619	.9997
21	.9054		.8488	.811	.8865	.8865	.8488
22	.7733	.7621	.7545	.7356	.7356	.7545	
23	.679	.6478	.6413	.6036	.6036	.6413	.6602
24	.547	.547	.5335	.5281	.5281	.5093	.5281
Max	.9997	.9907	.9242	.9431	.8865	.9619	.9997
Min	.415	.4527	.4763	.4527	.415	.415	.4527
Avg	.6137	.6146	.6166	.5768	.5870	.6009	.6241

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 213 / Panjarpol

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0762	.0754	.0754	.0566	.0754
2	.0754	.0566	.0762	.0566	.0566	.0566	.0754
3	.0566	.0566	.0762	.0566	.0566	.0566	.0566
4	.0566	.0566	.0572	.0566	.0566	.0566	.0566
5	.0754	.0566	.0566	.0566	.0566	.0566	.0754
6	.0943	.0754	.0572	.0566	.0566	.0566	.0943
7	.0943	.0754	.0754	.0566	.0566	.0566	.0943
8	.0943	.0754	.0943	.0566	.0566	.0566	.0754
9	.132	.0943	.0943	.0566	.0566	.0754	.1132
10	.2096	.1509	.1698	.0754	.0754	.132	.1334
11	.2286	.1886	.2075	.2075	.0566	.2096	.2096
12	.2858	.2641	.2641	.2075	.0566	.2286	.2667
13	.2096	.2075	.2263	.1509	.0572	.1524	.1715
14	.1334	.132	.132	.1132	.0572	.1334	.1143
15	.1905	.1698	.1509	.132		.1524	.1715
16	.2075	.2641	.1886	.1886	.0566	.2263	
17	.2075	.2286	.1886	.1509	.0566	.2263	.2075
18	.1509	.1715	.1886	.1698	.0566	.1698	.1698
19	.1886	.1334	.1886	.1886	.0943	.1886	.1886
20	.132	.1524	.132	.1132	.0754	.1509	.1509
21	.0754	.0762	.1132	.1132	.0566	.0754	.0943
22	.0943	.0953	.0943	.0754	.0566	.0754	.0943
23	.0754	.0953	.0754	.0754	.0566	.1132	.0754
24	.0754	.0754	.0762	.0754	.0754	.0566	.0754
Max	.2858	.2641	.2641	.2075	.0943	.2286	.2667
Min	.0566	.0566	.0566	.0566	.0566	.0566	.0566
Avg	.1341	.1261	.1275	.1069	.0616	.1175	.1235

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 411 / 33 KV Incomer No. I MIDC NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDE Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2253	3.2819	3.2007	3.3385	2.9424	3.0556	3.1687
2	3.1121	3.0556	3.1436	3.1121	2.8858	2.8858	3.1121
3	2.8292	2.8858	3.1436	2.999	2.7726	2.7161	2.9424
4	2.8292	2.9424	3.1436	3.0556	2.7726	2.7726	2.9424
5	2.9424	2.999	3.2579	3.2819	2.8858	2.7726	3.2253
6	3.3385	3.4517	3.4294	3.3951	3.3385	3.3385	3.5648
7	4.0175	3.9609	4.0581	3.5648	3.8477	3.8477	4.0175
8	4.357	4.357	4.2867	3.7912	4.4702	4.2438	4.3004
9	4.4702	4.5833	4.357	4.1872	4.357	4.357	4.5268
10	4.8583	4.9794	4.4702	4.1307	4.5268	4.5833	4.8583
11	5.5441	5.7716	5.3189	4.6399	5.0926		5.487
12	5.8299	5.8282	6.2243	4.6399	5.2624	5.5441	5.7156
13	5.7156	5.9414		4.5268	5.3155	5.6584	5.6584
14	5.2584	5.3755	5.036	4.3004	5.144	5.3727	5.3155
15	5.3155	5.3189	4.9228	4.2438	5.0297	4.9726	5.3155
16	5.2624	5.5453	5.0926	4.4702	4.8663	5.3189	
17	5.3189	5.8299	5.1492	4.5833	5.036	5.6584	
18	5.715	5.9442	5.3755	4.8097	5.2624	5.8282	5.998
19	7.1862	7.3731	6.8467	6.4506	6.9033	7.2428	7.2994
20	7.2994	7.4303	6.7335	6.394	6.7335	7.0165	7.0165
21	6.1677	6.0585	5.6584	5.5453	5.8848	5.998	5.998
22	4.9794	5.144	5.036	4.8097	4.7531	4.9228	4.9794
23	4.357	4.401	4.4702	4.1307	4.1307	4.2438	4.357
24	3.6214	3.5082	3.658	3.6214	3.3951	3.3385	3.5082
Max	7.2994	7.4303	6.8467	6.4506	6.9033	7.2428	7.2994
Min	2.8292	2.8858	3.1436	2.999	2.7726	2.7161	2.9424
Avg	4.7313	4.8320	4.6093	4.2509	4.4837	4.5952	4.6958



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 412 / 33 KV Incomer no .II  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	24-FEB-18
HR	Load (MW)
13	5.8282
Max	5.8282
Min	5.8282
Avg	5.8282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 201 / 11 KV Udymnagar

KOP.INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.724	.6859	.6478	.6097	.6478	.6097	.6859
2	.724	.6859	.6478	.6097	.6478	.6097	.6859
3	.724	.6859	.6478	.6097	.6478	.6097	.6859
4	.6859	.724	.6478	.6097		.6478	.6859
5	.6859	.724	.6478	.6097	.6097	.6478	.6859
6	.724	.7621	.6859	.6478	.6478	.6478	.724
7	.724	.7621	.6859	.6478	.6478	.6478	.724
8	.6478	.724	.7621	.6478	.6859	.7621	.8383
9	.4572	.5335	.5335	.5335	.6097	.6859	.5716
10	.6859	.724	.8002	.724	.6097	.724	.8383
11	.9145	.8002	.8383	.7621	.6097	.8383	.8383
12	.724	.7621	.724	.7621	.6097	.7621	.8383
13	.6478	.6859	.6859	.7621	.6097	.8002	.8002
14	.6097	.6859	.6859	.6859	.6478	.8002	.7621
15	.7621	.7621	.7621	.7621	.6478	.8383	.8002
16	.8002	.9145	.8764	.724	.6478	.9145	.9526
17	.724	.8383	.724	.6478	.1524	.8764	.7621
18	.6859	.6478	.6097	.5335	.6097	.6859	.6478
19	.6097	.5716	.5716	.5716	.6097	.6097	.6097
20	.6097	.6097	.4572	.6097	.6478	.6478	.6859
21	.6478	.5335	.4572	.6478	.6097	.6478	.724
22	.6859	.6478	.6097	.6097	.6478	.6859	.6859
23	.724	.6859	.6097	.6097	.6478	.6859	.6859
24	.6859	.724	.6478	.6097	.6097	.6478	.6859
Max	.9145	.9145	.8764	.7621	.6859	.9145	.9526
Min	.4572	.5335	.4572	.5335	.1524	.6097	.5716
Avg	.6922	.7034	.6653	.6478	.6114	.7097	.7335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 202 / 11 KV SAMARAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4954	.5914	.5335	.4954	.4572	.4805	.4954
2	.4191	.5544	.4954	.4954	.4191	.4435	.4954
3	.4191	.5544	.4954		.4191	.4435	.4572
4	.4572	.5544	.4954	.4572	.4191	.4805	.4572
5	.4954	.5914	.4954	.4954	.4572	.5175	.4954
6	.5716	.5914	.6097	.5716	.5335	.5544	.5716
7	.6478	.7842	.6097	.5716	.6097	.6348	.5716
8	.6859	.7468	.6478	.6478	.6478	.6348	.6478
9	.6097	.7468	.6478	.6478	.6859	.6348	.6478
10	.6097	.6859	.6097	.5601	.5716	.5716	.5975
11	.5716	.6097	.6097	.5228	.381	.5335	.5228
12	.5335	.6097	.5716	.5228	.3429	.4954	.4854
13	.6097	.5716	.5335	.4854	.3429	.5335	.4854
14	.5716	.5335	.8383	.4481	.3429	.5335	.5228
15	.5335	.5335	.6097	.4854	.4954	.4954	.5228
16	.5335	.4954	.4954	.3734	.4572	.4954	.5228
17	.4854	.5335	.4954	.4954	.4481	.4954	.5335
18	.5975	.5335		.5335	.4854	.5335	.5335
19	.7842	.7621	.6859	.6859	.5601	.7621	.724
20	.8589	.8002	.724	.724	.7095	.7621	.7621
21	.8589	.7621	.7621	.724	.7095	.7621	.724
22	.8215	.724	.6859	.724	.7095	.724	.724
23	.7095	.6859	.6097	.6478	.6348	.6478	.6478
24	.5716	.6348	.5716	.5716	.5335	.5228	.5335
Max	.8589	.8002	.8383	.724	.7095	.7621	.7621
Min	.4191	.4954	.4954	.3734	.3429	.4435	.4572
Avg	.6022	.6329	.6014	.5603	.5155	.5705	.5701

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 203 / 11 KV HUTATMA PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9145	.8764	.8383	.8764	.8383	.8383	.8002
2	.8764	.8383	.8383	.8764	.8383	.8002	.8002
3	.8764	.8383	.8383	.8383	.8383	.8002	.8002
4	.8764	.8383	.8383	.8383	.8383	.8002	.8002
5	.9145	.8764	.8383	.8764	.8764	.8383	.8002
6	.9145	.8764	.8383	.8764	.8764	.8383	.8002
7	.8383	.8383	.8002	.8383	.8383	.8002	.8002
8	.8764	.9145	.8002	.8002	.8383	.8002	.8383
9	.8764	.8764	.8383	.8383	.8383	.8002	.7621
10	.9907	1.0669	.9526	.9145	.8002	.9907	.9907
11	1.3336	1.2955	1.2193	1.0669	.8002	1.1431	1.1812
12	1.2193	1.2193	1.105	1.105	.8002	1.1431	1.2193
13	1.105	1.1431	1.1431	.9526	.8383	1.1431	1.1812
14	1.1431	.9907	1.0669	.8764	.8764	1.0669	1.0669
15	1.2955	1.2193	1.1812	1.0669	.8383	1.1431	1.2193
16	1.2955	1.2193	1.2955	1.0669	.8764	1.2193	1.2193
17	1.2955	1.1812	1.1431	.9907	.8383	1.2193	1.1812
18	1.105	1.1431		.9145	.8764	1.0669	1.1431
19	1.0669	.9907	.9907	.9145	.8764	1.0288	1.0669
20	.8764	.8764	.8764	.8383	.8764	.8383	.9145
21	.9145	.8383	.8383	.8002	.8383	.7621	.8383
22	.8764	.8383	.8383	.8002	.8002	.8002	.8383
23	.8383	.8383	.8764	.8383	.8383	.8002	.8383
24	.9145	.9145	.8764	.8764	.8383	.8383	.8383
Max	1.3336	1.2955	1.2955	1.105	.8764	1.2193	1.2193
Min	.8383	.8383	.8002	.8002	.8002	.7621	.7621
Avg	1.0098	.9812	.9509	.9034	.8431	.9383	.9558

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 205 / RADHA KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	.9979	.9145	.8764	.8383	.924	.9907
2	.9145	.961	.8764	.8383	.8002	.8501	.9145
3	.8764	.924	.8383	.8002	.8002	.8131	.8383
4	.8764	.8871	.8002	.8002	.7621	.7762	.8002
5	.8764	.8871	.8002	.8002	.7621	.7762	.8002
6	.8764	.8501	.8383	.8383	.7621	.7762	.8764
7	.9526	.9335	.8764	.8764	.8764	.8215	.9526
8	1.0288	1.0456	.9907	.9145	.9145	.9335	.9907
9	1.2574	1.2323	1.1431	1.1431	.4954	1.1203	1.2193
10	1.4098	1.5242	1.2955		1.2193	1.2955	1.3817
11	1.6385	1.8671	1.1812	1.307	1.448	1.7528	1.643
12	1.8671	1.9433	1.829	1.419	1.5242	1.9052	1.8671
13	1.2955	1.9433	1.829	1.419	1.5623	1.829	1.9044
14	1.9052	2.0576	1.829	1.3443	1.5623	1.9052	1.9044
15	1.9052	1.9433	1.7528	1.3443	1.6004	1.7909	1.9044
16	1.8671	2.0957	1.7528	1.3717	1.6385	1.8671	1.9418
17	1.8671	2.0957	1.8671	1.448	1.6804	1.829	
18	1.9418	2.1338	1.9052	1.5242	1.7177	1.829	2.0195
19	2.2032	2.21	2.1338	1.7528	1.8671	2.2862	2.2862
20	2.0538	2.1338	1.7147	1.4861	1.7924	1.9052	2.0576
21	1.6057	1.6766	1.4861	1.448	1.419	1.6385	1.6385
22	1.3443	1.4861	1.3336	1.2955	1.307	1.448	1.4098
23	1.2323	1.2955	1.1431	1.0669	1.1203	1.2574	1.2193
24	1.1431	1.0829	1.1431	1.0669	.9526	1.0082	1.105
Max	2.2032	2.21	2.1338	1.7528	1.8671	2.2862	2.2862
Min	.8764	.8501	.8002	.8002	.4954	.7762	.8002
Avg	1.4137	1.5086	1.3448	1.1818	1.2260	1.3891	1.4202

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 411 / 33 KV Incomer no I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5437	3.658	3.315	3.2579	3.1436	3.2579	3.3722
2	3.315	3.5437	3.2579	3.2007	3.0864	3.0864	3.2579
3	3.2579	3.4865	3.2007	3.0864	3.0864	3.0864	3.1436
4	3.2579	3.4865	3.1436	3.0864	2.9721	3.1436	3.0864
5	3.3722	3.5437	3.1436	3.1436	3.0864	3.2007	3.1436
6	3.5437	3.5437	3.4294	3.315	3.2007	3.2579	3.315
7	3.658	3.8295	3.4294	3.3722	3.4294	3.4294	3.5437
8	3.7723	4.0009	3.7723	3.4294	3.6008	3.7151	3.7723
9	3.7723	3.9438	3.7151	3.6008	3.7151	3.7723	3.7723
10		4.4582	4.1724	3.7723	3.658	4.1152	4.3439
11	4.9726	4.9726	4.2867	4.1152	3.658	4.7439	4.6868
12	4.8583	5.0297	4.6868	4.2295	3.7723	4.7439	4.9726
13	4.1724	9.6022	4.5725	4.0581	3.7723	4.7439	4.8583
14	4.6296	4.6868	4.8011	3.7723	3.8295	4.8011	4.7439
15	4.9726	4.9154	4.6868	4.0581	.8573	4.6868	4.9154
16	4.9726	5.144	4.8583	3.8866	4.0581	4.9726	5.0869
17	4.8583	4.9726	4.6296	3.9438	3.6008	4.9154	4.9154
18	4.8011	4.9726	4.6868	4.0009	4.1724	4.1152	4.9154
19	5.2584	5.2012	5.0869	4.4582	4.5153	5.3727	5.3155
20	5.0869	5.0297	4.401	4.2295	4.6868	4.8011	5.0297
21	4.6868	4.5153	4.1724	4.2867	4.2295	4.4582	4.5725
22	4.401	4.2295	4.1152	4.1152	4.0581	4.2295	4.2295
23	4.0581	4.0009	3.7723	3.658	3.7723	3.8866	3.8866
24	3.7723	3.658	3.7151	3.5437	3.315	3.4294	3.658
Max	5.2584	9.6022	5.0869	4.4582	4.6868	5.3727	5.3155
Min	3.2579	3.4865	3.1436	3.0864	.8573	3.0864	3.0864
Avg	4.2171	4.5177	4.0438	3.7342	3.5532	4.0819	4.1891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 201 / 11 KV AMBAI DEFENCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.3042	.2804	.2987	.3042	.2481	.2852
2	.2263	.3042	.2629	.2614	.2852	.2454	.2852
3	.2263	.2852	.2658	.2614	.2662	.2279	.2662
4	.2641	.2852	.2534	.2614	.2852	.2427	.2852
5	.2829	.3042	.2715	.2614	.2852	.2715	.2852
6	.3018	.3232	.3077	.2801	.3042	.2715	.3042
7	.3206	.3423	.3109	.2801	.3232	.3109	.3423
8	.3584	.3613	.3475	.3142	.3613	.3475	.3423
9	.3018	.3232	.2896	.2987	.3042	.2715	.3042
10	.2987	.3232	.2896	.2801	.2852	.2852	.3042
11	.2662	.2481	.2987	.2852	.2353	.2852	.2896
12	.2662	.2481	.3206	.2472	.2172	.2282	.2534
13	.2662	.2353		.2472	.1991	.2282	.2534
14	.2282	.2353	.415	.2282	.1991	.2092	.2534
15	.2282	.2353	.2614	.2092	.2172	.2282	.2534
16	.2472	.2172	.2614	.2282	.2172	.2282	.2353
17	.2282	.2534	.2641	.2282	.2172	.2662	.2715
18	.2472	.2743	.2801	.2282	.2172	.2852	.2561
19	.4183	.3077	.3734	.3993	.3258	.3803	.3841
20	.4183	.4075	.4108	.4183	.3982	.4183	.3982
21	.3993	.3801	.3734	.3803	.3801	.3993	.3721
22	.3803	.3801	.3658	.3803	.3544	.3803	.3721
23	.3613	.3366	.3547	.3423	.3366	.3423	.3189
24	.3018	.3232	.3012	.3174	.3042	.2835	.3042
Max	.4183	.4075	.415	.4183	.3982	.4183	.3982
Min	.2263	.2172	.2534	.2092	.1991	.2092	.2353
Avg	.2959	.3016	.3113	.2890	.2843	.2869	.3008

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 202 / 11 KV VIDYAPEETH  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2852	.2429	.2378	.244	.2374	.244
2	.2263	.2627	.2241	.2378	.2252	.208	.2252
3	.2263	.2627	.2241	.2378	.2252	.2031	.2252
4	.2263	.2815	.2229	.2614	.2627	.2107	.2627
5	.2829	.3003	.2683	.2561	.2815	.2258	.2815
6	.3018	.3003	.2915	.2926	.2815	.2713	.319
7	.3395	.3378	.333	.3077	.319	.3155	.3566
8	.3395	.319	.2835	.2926	.319	.3155	.3003
9	.2987	.319	.2804	.2561	.3003	.3189	.3003
10	.2987	.3566	.3109	.2715	.2815	.319	.3042
11	.3566	.4108	.2534	.2252	.3658	.3378	.3189
12	.3566	.3772	.1448	.2064	.3921	.3753	.3544
13	.319	.3361		.2252	.4024	.3566	.3511
14	.3378	.3658	.0905	.2252	.4066	.3378	.3547
15	.3566	.3841	.2896	.2252	.362	.3378	.3547
16	.3941	.415	.2561	.2252	.3403	.3566	.4024
17	.3566	.4066	.2743	.244	.3801	.3566	.4119
18	.319	.3366	.2957	.2627	.3258	.3232	.3366
19	.3003	.2835	.2743	.2815	.2865	.3003	.3189
20	.3003	.298	.2926	.2815	.3012	.3003	.3012
21	.3003	.3012	.2926	.2627	.2658	.319	.298
22	.3003	.298	.2743	.2627	.2629	.319	.2947
23	.3003	.2713	.2743	.2815	.2543	.2852	.2622
24	.2641	.2852	.2543	.2561	.2627	.2241	.2627
Max	.3941	.415	.333	.3077	.4066	.3753	.4119
Min	.2263	.2627	.0905	.2064	.2252	.2031	.2252
Avg	.3061	.3248	.2586	.2549	.3062	.2981	.3101



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 203 / Siber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5093	.5514	.5068	.4854	.4944	.4755	.5324
2	.4338	.5134	.4887	.4294	.4753	.4525	.5324
3	.4338	.5134	.4887	.4294	.4753	.4525	.5134
4	.4527	.5255	.5487	.4854	.5134	.4887	.5514
5	.5281	.5704	.5853	.5228	.5514	.5544	.5704
6	.6413	.6084	.6401	.6161	.5704	.6348	.6084
7	.6224	.6465	.6283	.5729	.6275	.6348	.6465
8	.6602	.6655	.5975	.5175	.5704	.6161	.6084
9	.6413	.6084	.5487	.5729	.5894	.6161	.6084
10	.6161	.5704	.5601	.5228	.5894	.5894	.6275
11	.5894	.5853	.5415	.4563	.5487	.5324	.5788
12	.5894	.543	.5175	.4753	.5228	.5514	.5601
13	.5324	.5228		.4183	.5121	.5514	.5175
14	.5324	.5359	.7095	.3803	.5121	.5324	.5359
15	.5514	.5544	.5975	.3993	.5304	.5894	.5601
16	.5704	.5788	.5415	.4183	.543	.6275	.567
17	.5324	.5601	.4668	.4183	.4887	.5324	.5729
18	.5134	.6036	.4668	.4183	.439	.5324	.4805
19	.7796	.7095	.6979	.6756	.7059	.7606	.7095
20	.7415	.7059	.6908	.6655	.7421	.7225	.7282
21	.7225	.695	.6878	.6655	.7133	.7035	.7059
22	.6845	.6767	.6401	.6084	.6335	.6845	.6697
23	.6275	.5853	.6161	.5704	.5853	.5894	.5973
24	.5658	.5894	.5068	.5601	.5324	.4887	.5514
Max	.7796	.7095	.7095	.6756	.7421	.7606	.7282
Min	.4338	.5134	.4668	.3803	.439	.4525	.4805
Avg	.5863	.5925	.5771	.5119	.5611	.5797	.5889

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 411 / 33 KV Incomer no I

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0185	1.1408	1.1203	1.0082	1.0268	.9979	1.0838
2	.9054	1.0838	1.0642	.9522	.9697	.9425	1.0268
3	.9054	1.0838	1.0534	.9522	.9697	.9425	1.0268
4	.9619	1.0838	1.1088	1.0082		1.0082	1.0838
5	1.0751	1.1979	1.1763	1.0642	1.1408	1.1203	1.1408
6	1.2449	1.2549	1.2883	1.1763	1.1408	1.2449	1.2549
7	1.3014	1.312	1.2883	1.1763	1.2549	1.3014	1.369
8	1.358	1.369	1.2323	1.1203	1.2549	1.3014	1.2549
9	1.2449	1.2549	1.1763	1.1203	1.1979	1.2323	1.1979
10	1.2323	1.2549	1.1763	1.0642	1.1408	1.1979	1.2549
11	1.1979	1.2883	1.1203	.9697	1.1763	1.1979	1.2323
12	1.1979	1.1763	1.0082	.9127	1.1203	1.1408	1.1763
13	1.1408	1.1203		.9127	1.1203	1.1408	1.1203
14	1.0838	1.1763	1.2449	.8556	1.1203	1.0838	1.1763
15	1.1408	1.1763	1.1763	.8556	1.1203	1.1408	1.1763
16	1.1979	1.2323	1.0642	.8556	1.1203	1.1979	1.2323
17	1.1408	1.2323	1.0185	.9127	1.1203	1.1408	1.2883
18	1.0838	1.2323	1.0751	.9127	1.0082	1.1408	1.1203
19	1.4831	1.3443	1.358	1.369	1.3443	1.426	1.4563
20	1.4831	1.4563	1.4003	1.369	1.5123	1.426	1.4563
21	1.426	1.4003	1.4003	1.312	1.4003	1.426	1.4563
22	1.369	1.4003	1.2883	1.2549	1.2883	1.369	1.4003
23	1.312	1.2323	1.2323	1.1979	1.2323	1.1979	1.2323
24	1.1317	1.1979	1.1203	1.1203	1.0838	1.0642	1.1408
Max	1.4831	1.4563	1.4003	1.369	1.5123	1.426	1.4563
Min	.9054	1.0838	1.0082	.8556	.9697	.9425	1.0268
Avg	1.1932	1.2376	1.1822	1.0605	1.1680	1.1826	1.2233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 201 / 11KV KASABA BAWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0136	1.086	1.0317	1.0136	.9955	1.0498	.9955
2	.9593	.9955	.9955	.9412	.9231	.9955	.9774
3	.9593	.9593	.9412	.9412	.9231	.9593	.9412
4	.9593	.9593	.9412	.9412	.9231	.9593	.9412
5	1.0498	1.0498	.9774	.9955	.9774	1.0317	.9593
6	1.2308	1.2308	1.1403	1.0679	1.1403	1.1584	1.1584
7	1.4661	1.4842	1.3756	1.2308	1.3394	1.448	1.4118
8	1.5023	1.5023	1.4118	1.3213	1.4299	1.4661	1.4842
9	1.3937	1.3575	1.3213	1.3937	1.3213	1.3575	1.3756
10	1.2308	1.2308	1.2308	1.267	1.1765	1.2308	1.1946
11	1.1765	1.1584	1.1403	1.1584	1.0317	1.1403	1.1403
12	1.1584	1.1403	1.1765	1.086	.9774	1.086	1.1041
13	1.1403	1.1041	1.0679	1.0498	1.0317	1.086	1.1946
14	1.0317	1.0498	1.0679	.9412	.9412	.9955	1.1222
15	1.0679	1.0679	.9774	.9593	.9231	1.0136	1.0679
16	1.0498	1.0136	1.0136	1.0317	.9412	1.0679	1.1041
17	1.1403	1.2308	1.1403	1.1222	1.1041	1.1584	1.1584
18	1.3032	1.3032	1.1765	1.1946	1.086	1.3213	1.2851
19	1.8099	1.7194	1.7013	1.7194	1.5023	1.8099	1.7194
20	1.7737	1.7013	1.7194	1.7013	1.647	1.7737	1.7737
21	1.6832	1.647	1.6289	1.5927	1.6108	1.6651	1.6289
22	1.6108	1.5746	1.4842	1.4842	1.5203	1.5927	1.5203
23	1.3394	1.3575	1.267	1.2851	1.3032	1.3032	1.3213
24	1.1403	1.1403	1.1222	1.1584	1.1041	1.1041	1.086
Max	1.8099	1.7194	1.7194	1.7194	1.647	1.8099	1.7737
Min	.9593	.9593	.9412	.9412	.9231	.9593	.9412
Avg	1.2579	1.2527	1.2104	1.1916	1.1614	1.2406	1.2361

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0747	.0754	.0739	.0754	.0754	.0943
2	.1132	.0747	.0754	.0739	.0762	.0747	.0754
3	.1143	.0747	.0754	.0732	.0762	.0754	.0754
4	.1143	.0747	.112	.0724	.0762	.0747	.0754
5	.1143	.0747	.1307	.0724	.0762	.0754	.0754
6	.1143	.0747	.1494	.0732	.0953	.0754	.0754
7	.0943	.132	.0953	.132	.0943	.0754	.048
8	.0953	.132	.0953	.1698	.0754	.0754	.0497
9	.1132	.1886	.1143	.1886	.132	.1132	.1132
10	.1132	.132	.1132	.1509	.1886	.132	.132
11	.132	.1715	.132	.1886	.1886	.1143	.1886
12	.132	.1886	.132	.1698	.1886	.1132	.1886
13	.132	.132	.132	.1867	.1886	.0953	.1509
14	.1132	.1698	.1132	.1886	.1886	.0914	.1698
15	.132	.2075	.1132	.1886	.1886	.1698	.1698
16	.1132	.1698	.0914	.1886	.1886	.1886	.1886
17	.1307	.1132	.132	.132	.1307	.1509	.132
18	.1307	.1509	.1698	.1307	.112	.1494	.1132
19	.1698	.1698	.1509	.1294	.132	.132	.1307
20	.132	.1494	.1267	.1509	.132	.0762	.1494
21	.1307	.1509	.1509	.1509	.132	.0943	.1307
22	.0747	.1663	.0943	.0943	.0754	.0754	.0953
23	.0747	.0953	.0943	.0754	.0754	.0943	.0943
24	.1132	.0747	.0943	.0943	.0762	.0943	.0943
Max	.1698	.2075	.1698	.1886	.1886	.1886	.1886
Min	.0747	.0747	.0754	.0724	.0754	.0747	.048
Avg	.1171	.1309	.1151	.1312	.1235	.1036	.1171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 203 / 11KV ULAPEMALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.0914	.0914	.0914	.0914	.0914
2	.0914	.0914	.0914	.0914	.0732	.0914	.0914
3	.0914	.0914	.0732	.0914	.0732	.0914	.0914
4	.0914		.0732	.0914	.0732	.0914	.0914
5	.0914	.1097	.0732	.0914	.0732	.0914	.0914
6	.0914	.1097	.0914	.0914	.0914	.0914	.1097
7	.1097	.0914	.0914	.0914	.0914	.0914	.1097
8	.1097	.128	.0914	.1097	.0914	.1097	
9	.1097	.0914	.0914	.0914	.128	.1097	.0914
10	.1097	.1097	.0914	.0914	.128	.1097	.0732
11	.1097	.1097	.0914	.0914	.1097	.1097	.0914
12	.128	.128	.0914	.0914	.1097	.0914	.0914
13	.128	.1097	.0914	.1097	.0914	.1097	.0914
14	.128	.1097	.0914	.128	.1097	.0914	.0914
15	.128	.1097	.0732	.1097	.128	.0914	.0914
16	.1097	.1097	.0914	.1097	.1463	.1097	.0914
17	.1097	.1097	.0732	.1097	.128	.1097	.1097
18	.128	.128	.0914	.1097	.1097	.1097	.1097
19	.1463	.128	.128	.1463	.1463	.1463	.128
20	.1463	.1097	.128	.1463	.128	.1463	.128
21	.128	.1097	.1097	.128	.1097	.128	.0914
22	.128	.1097	.128	.128	.1097	.1097	.1097
23	.1097	.0914	.1097	.1097	.1097	.1097	.0914
24	.0914	.0914	.0914	.1097	.0914	.1097	.0914
Max	.1463	.128	.128	.1463	.1463	.1463	.128
Min	.0914	.0914	.0732	.0914	.0732	.0914	.0732
Avg	.1128	.1073	.0937	.1067	.1059	.1059	.0978

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.462	.462	.462	.462	.4435	.4435	.4435
2	.4251	.4435	.4435	.4435	.4251	.4066	.4251
3	.4251	.4435	.4251	.4435	.4251	.4066	.4251
4	.4251	.4805	.4251	.4435	.4251	.4435	.4435
5	.5175	.5544	.462	.5359	.5175	.4805	.462
6	.6468	.6468	.6468	.5914	.5914	.6283	.6099
7	.7392	.7762	.7392	.7207	.7023	.6838	.7577
8	.7392	.7023	.6838	.7392	.6653	.7023	.7392
9	.6653	.6468	.6099	.6468	.6283	.6283	.6099
10	.5544	.5729	.5729	.6838	.5729	.5359	.5914
11	.5544	.5359	.5729	.6283	.499	.5729	.5729
12	.5729	.5359	.5359	.6099	.5175	.5175	.5175
13	.5544	.5175	.5729	.3881	.5359	.5175	.5359
14	.499	.5175	.499	.5544	.4805	.499	.5175
15	.499	.4805	.4805	.4805	.499	.462	.5729
16	.499	.4805	.499	.499	.499	.462	.5544
17	.5175	.5175	.5175	.5359	.4435	.499	.4805
18	.5544	.5544	.5175	.5359	.499	.4805	.5729
19	.7947	.7392	.8131	.7762	.7023	.7577	.7762
20	.8501	.8131	.8501	.8131	.8131	.8316	.8316
21	.7947	.7947	.7947	.7762	.7947	.7762	.7947
22	.7577	.7577	.7392	.7023	.7207	.7392	.7392
23	.6099	.6099	.6099	.5729	.5729	.6099	.5914
24	.499	.499	.499	.5175	.462	.4805	.499
Max	.8501	.8131	.8501	.8131	.8131	.8316	.8316
Min	.4251	.4435	.4251	.3881	.4251	.4066	.4251
Avg	.5899	.5868	.5821	.5875	.5598	.5652	.5860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 205 / 11 KV Sarwal AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.104					.0693	.0867
2	.104					.0693	.0693
3	.104					.0867	.0693
4	.104					.0867	.0693
5	.1387					.104	.0693
6	.208					.1214	.1214
7	.2254					.1734	.156
8	.3121					.1734	.2254
9	.3467					.208	.2601
10	.4161	.3988	.4681	.4161			
11	.5028	.5721	.5895	.5895	.499		
12	.1734	.5548	.5895	.5721			
13	.4681	.4681	.5201	.4681			
14	.4681	.5201	.5028	.5028			
15	.4161	.5201	.4854	.5201			
16	.3814	.4681	.4681	.5028			
17	.3814	.4508	.4161	.4508			
24	.104					.0693	.0693
Max	.5028	.5721	.5895	.5895	.499	.208	.2601
Min	.104	.3988	.4161	.4161	.499	.0693	.0693
Avg	.2755	.4941	.5050	.5028	.499	.1162	.1196

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6908		.6979	.6535		.6348
4						.7095	
6	.7468	.7922	.7733	.7095	.6979		.7468
7	.9709	.9522	.9619	.7545	.9054		.9335
8	1.1016	1.1317	1.0751	.9149	1.0374		.9709
9	1.0456	1.0751	1.1317	.9522		1.0456	1.0269
10	1.0082					.8962	1.0082
11	.9522		1.0534	.9709			.9335
12	.9522		.9511	.8775	.9149	.9522	.8962
13	.9709			.8589		.8775	.9149
14				.8402		.7655	.7655
15	.7468			.7282		.7655	
16	.8402	.8215		.7655	.7842	.7922	.7842
17	.8402	.8316			.7655	.7655	
18	.8215	.8316			.7468		
19	1.0082						
20	1.0751	1.0829					
21	1.0269	1.0456	1.0082	.9709	.9997	1.0082	1.0082
22	1.0082		1.0082	.9335		.9808	
23		.9431					
24	.7733	.7922	.811	.8215	.7167	.7095	.7545
Max	1.1016	1.1317	1.1317	.9709	1.0374	1.0456	1.0269
Min	.7468	.6908	.7733	.6979	.6535	.7095	.6348
Avg	.9346	.9159	.9749	.8426	.8222	.8557	.8752



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 203 / 11KV AKASHWANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6908		.7356	.6979		.6535
4						.5975	
6	.7468	.7733	.7356	.7167	.7356		.7356
7	.9242	.9619	.9242	.7922	.8676		.8962
8	1.0374	1.0269	.9619	.8865	.9808		1.0185
9	1.0456	1.0562	.9896	.9522		1.0082	1.0269
10	1.0456					1.0456	.9896
11	1.1203		.9709	.9149			.9896
12	1.0269		.7282	.8215	.9709	1.0642	1.0269
13	.9709			.8215		1.0082	.9522
14				.7655		.9335	.9522
15	.9335			.7468		.9522	
16	.9149	.9522		.7282		.9149	.9149
17	.9149	.9149			1.0829	.8775	
18	.9149	.9149			.9522		
19	1.0082						
20	1.1389	1.1088					
21	1.0456	1.0719	1.0642	.9709	1.0082	1.0269	1.0082
22	1.0082		1.0269	.9242		.9522	
23		.9335					
24	.7842	.7842	.7842	.8029	.7356	.7655	.7545
Max	1.1389	1.1088	1.0642	.9709	1.0829	1.0642	1.0269
Min	.7468	.6908	.7282	.7167	.6979	.5975	.6535
Avg	.9754	.9325	.9095	.8271	.8924	.9289	.9168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 205 / 11KV LAXMIPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.7922		.7733	.6224		.7282
4						.6722	
6	.8029	.8029	.7655	.7733	.7545		.7733
7	.9054	.9808	.8299	.7655	.8488		.8676
8	.9425	.9149	.8676	.7922	.811		.9054
9	.9979	1.0269	.9522	.8215		1.0082	.9335
10	1.2136					1.1576	1.1949
11	1.419		1.1949	1.0751			1.2136
12	1.4003		1.262	1.0829	1.3256	1.4377	1.5123
13	1.3817			.9896		1.363	1.4377
14				.9335		1.2883	1.3256
15	1.363			.8775		1.3256	
16	1.3256	1.363		.8775	1.251	1.3256	1.3256
17	1.2696	1.3169			1.2437	1.4003	
18	1.4377	1.3491			1.2071		
19	1.6617						
20		1.4969					
21	1.251	1.2136	1.1949	1.1389	1.1763	1.2323	1.251
22	1.1389		1.0642	1.0562		1.1317	
23		1.0082					
24	.8676	.8962	.8676	.8402	.7842	.8215	.8029
Max	1.6617	1.4969	1.262	1.1389	1.3256	1.4377	1.5123
Min	.8029	.7922	.7655	.7655	.6224	.6722	.7282
Avg	1.2112	1.0968	.9999	.9141	1.0025	1.1803	1.0978

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8402		.8676	.7733		.7842
4						.7095	
6	.8488	.8676	.8676	.8299	.7733		.7655
7	.8962	.9808	.9335	.8402	.8488		.8865
8	.9808	.9997	.9619	.8865	.9242		.9619
9	1.0269	.9709		.9896		.9522	.9808
10	1.1949					1.1016	1.0829
11	1.4003		1.2637	1.0269			1.307
12	1.3443		1.2826	1.0269	1.363	1.307	1.307
13	1.363			1.0456		1.307	1.3256
14				1.0456		1.307	1.307
15	1.363			1.0269		1.2136	
16	1.3256	1.363		1.0642	1.2323	1.3256	1.2883
17	1.3256	1.3256			1.2136	1.307	
18	1.3817	1.4003			1.251		
19	1.4377						
20	1.3817	1.307					
21	1.1763	1.2071	1.1203	1.0269	1.094	1.0642	1.1576
22	1.1203		1.0829	1.0374		.9896	
23		1.0829					
24	.9431	.9242	.9619	.9335	.8488	.8962	.8488
Max	1.4377	1.4003	1.2826	1.0642	1.363	1.3256	1.3256
Min	.8488	.8402	.8676	.8299	.7733	.7095	.7655
Avg	1.2065	1.1058	1.0593	.9748	1.0322	1.1234	1.0772

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5041		.5093	.4527		.4854
4						.4481	
6	.5175	.5093	.5281	.4904	.4668		.4854
7	.5601	.5281	.547	.5093	.4904		.5093
8	.5415	.5415	.547	.5041	.4904		.5788
9	.6348	.6348	.6036	.5228		.6161	.5788
10						.7655	.7655
11	.8775		.7947	.6348			.8215
12	.8962		.8215	.5975	.0497	.8589	.8402
13	.8589			.5788		.9149	.8402
14				.5788		.8215	.8589
15	.8962			.5975		.8589	
16	.9149	.9335		.5788	.056	.9149	.8962
17	.9335	.9149			1.2071	.8962	
18	.8775	.8962			1.1203		
19	.9335						
20	.8589	.8501					
21	.7655	.7842	.7282	.6908	.8589	.8029	.7842
22	.7095		.6722	.6224		.7095	
23		.6535					
24	.547	.5658	.5788	.547	.5041	.5601	.5415
Max	.9335	.9335	.8215	.6908	1.2071	.9149	.8962
Min	.5175	.5041	.5281	.4904	.0497	.4481	.4854
Avg	.7702	.693	.6468	.5687	.5696	.7640	.6912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 411 / 33 KV NAGALA PARK

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		5.036		4.8731	4.425		4.6965
4						4.0724	
6	5.1532	5.0412	5.2624	4.9794	4.6965		4.9794
7	5.7716	5.8282	5.6584	5.1492	5.3755		5.5453
8	6.2809	6.3375	5.998	5.4887	5.9414		6.0545
9	6.4975	6.5535	6.5072	5.8814		6.0814	6.3295
10						7.3377	7.4497
11	8.2339		7.2977	6.7776			8.1779
12	8.1779		7.1331	6.6095	7.6178	8.514	8.57
13	8.1779			6.5535		8.626	8.682
14				6.2174		7.9538	8.4019
15	7.6178			5.8814		7.9538	
16	7.7298	7.9538		6.0494	5.9934	8.2899	8.3459
17	7.6738	7.7366			7.8464	8.4019	
18	8.0098	7.8464			7.6269		
19	9.1301						
20	9.0741	8.5791					
21	7.5057	7.3846	7.2257	6.9456	7.2428	7.2817	7.5057
22	7.0016		6.7215	6.3855		6.6655	
23		6.2734					
24	5.3212	5.3755	5.3772	5.2652	4.9291	4.8834	5.0412
Max	9.1301	8.5791	7.2977	6.9456	7.8464	8.626	8.682
Min	5.1532	5.036	5.2624	4.8731	4.425	4.0724	4.6965
Avg	7.3348	6.6622	6.3535	5.9326	6.1695	7.1718	6.9061

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 412 / 33 KV INCOMER NO. 1

Feeder KV- 33 / INCOMING

DATE	22-FEB-18	25-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			10.5864	10.7545
11	11.5947	9.6902		12.4349
12	11.9868	9.9143	12.939	13.4991
13	12.0428	9.6902	13.5551	14.0032
14		8.906	12.4349	13.4991
15	11.1466	8.3459	12.4349	
16	11.2586	8.794	13.051	13.3871
17	11.0906			
18	12.1548			
19	14.3393			
20	13.8912			
21	10.5304			
Max	14.3393	9.9143	13.5551	14.0032
Min	10.5304	8.3459	10.5864	10.7545
Avg	12.0036	9.2234	12.5002	12.9297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 201 / 11KV S.T. STAND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.8871	.8589	.7811	.6979		.724
2	.7468	.8048		.7049	.679	.7842	.7049
3	.7167	.7762	.8402	.6859	.6722		.7049
4	.6908	.7316		.6859	.6602	.7468	.7049
5	.7356	.7762	.8215	.6859	.7356		.6859
6	.8029	.8131		.7621	.7733	.7842	.8192
7	.8488	.9511		.8764	.8402		.8954
8	.9808	1.0349		.9526	.8402	.9709	1.1241
9	.9997	1.1576	1.0082	.8764	.9335	.9522	1.086
10	1.1955	1.2071	1.0974		1.0973	1.0374	1.1576
11	1.1765	1.2136	1.1458	1.0269	1.212	1.6598	1.251
12	1.2334	1.2826	1.1458		1.2108	1.6598	1.1949
13		1.2071	1.2012	1.0082	1.1351	1.6617	1.2883
14	1.3203	1.251	1.1273	.9522	1.154	1.587	1.2136
15	1.2449	1.1694	1.1506	1.0269	1.212	1.5655	1.307
16	1.2637	1.2637	1.1273	1.0456	1.1955	1.6598	1.2936
17	1.2696	1.3256	1.2675	1.0374		1.8217	1.3014
18	1.3256	1.3443	1.2675	1.094	1.2696	1.3243	1.2323
19	1.5684		1.5702	1.2826	1.4003	1.537	1.4146
20	1.5466		1.515	1.3392		1.556	1.4335
21	1.4563	1.3817	1.4567	1.2449		1.4422	1.358
22	1.2197		1.3663	1.0374		1.2524	1.3014
23	1.1643	1.1016	1.1184	1.0185	1.0456	1.1765	1.094
24	.811	.924	.8962	.8349	.7356	.8299	.8002
Max	1.5684	1.3817	1.5702	1.3392	1.4003	1.8217	1.4335
Min	.6908	.7316	.8215	.6859	.6602	.7468	.6859
Avg	1.0909	1.0764	1.1569	.9527	.9750	1.3005	1.0871

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3921	.4024	.4108	.3921	.3511		.3584
2	.3511	.3658		.3772	.3547	.3734	.3395
3	.3361	.3292	.3921	.3395	.3174		.3395
4	.3361	.3292		.3395	.3326	.3292	.3361
5	.3881	.362	.3921	.3361	.3921		.3547
6	.4294			.3921	.4066	.3547	.4904
7	.4854	.5304	.4854	.4481	.4668		.547
8	.5601	.567		.5041	.499	.5601	.5658
9	.5228	.5729	.5041	.5041	.462	.5068	.4904
10	.5121	.4854	.462		.4938	.4668	.499
11	.4755	.4854	.462	.4481	.4163	.4294	.499
12	.4938	.4854	.462		.2427	.4668	.462
13	.4715	.4854	.4066	.3734	.2353	.4108	.4668
14	.439	.4294	.3881	.3921	.4024	.4435	.4251
15	.4755	.4294	.3696	.3921	.4207	.4294	.4251
16	.439	.3547	.3326	.3734	.3921	.4108	.4481
17	.4251		.4024	.4108		.4189	.4668
18	.4435	.439	.4408	.3734	.4108	.4572	.4251
19	.6348		.6036	.6161	.5788	.6219	.5975
20	.6722	.6722	.6036	.5601		.6401	.6161
21	.6099	.6161	.5682	.5788		.5853	.5788
22	.567		.5601	.5041		.5544	.5228
23	.5121	.4854	.5041	.4527	.4668	.4755	.4668
24	.4108	.4207	.4294	.4108	.3921	.3921	.3961
Max	.6722	.6722	.6036	.6161	.5788	.6401	.6161
Min	.3361	.3292	.3326	.3361	.2353	.3292	.3361
Avg	.4743	.4624	.4590	.4327	.4017	.4664	.4632



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 203 / 11 KV EXCISE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3769	1.3676	1.4003	1.3527	1.2826		1.3908
2	1.3256	1.3443		1.2765	1.2637	1.2696	1.2955
3	1.3014	1.307	1.475	1.2193	1.2384		1.2574
4	1.2637	1.2826		1.2003	1.226	1.2136	1.2765
5	1.2883	1.3203	1.2752	1.2193	1.3392		1.2384
6	1.4003	1.4335		1.2574	1.4003	1.3256	1.4289
7	1.5278	1.6787	1.531	1.3908	1.5089		1.5242
8	1.7364	1.7551		1.6194	1.6787	1.5684	1.6194
9	1.6057	1.7364	1.7177	1.6575	1.6385	1.5684	1.7528
10	1.7164	1.7364	1.6617		1.6975	1.5844	1.6632
11	1.8107	1.6975	1.6078	1.587	1.773	1.363	1.7372
12	1.7164	1.7737	1.6448		1.7164	1.2071	1.7918
13	1.643	1.7541	1.6244	1.5497	1.6409	1.1763	1.773
14	1.6032	1.5278	1.531	1.5497	1.5734	1.0751	1.6804
15	1.5655	1.5844	1.5524	1.4377		1.0751	1.6975
16	1.5684	1.5844	1.5684	1.3817	1.6303	1.251	1.6804
17	1.6617		1.6393	1.3957		1.2108	1.7541
18	1.6787	1.6804	1.6048	1.358	1.6804	1.7335	1.8296
19	1.9616		2.0559	1.7353	1.9418	2.1691	2.0559
20	2.0559	2.0911	2.0182	1.8296		2.0936	2.1125
21	2.0559	1.9978	1.9297	1.8484		2.037	
22	1.8671		1.7909	1.6598		1.8673	1.773
23	1.6804	1.5497	1.7337	1.5466	1.5684	1.6509	1.5844
24	1.4146	1.4377	1.3769	1.467	1.3146	1.307	1.6004
Max	2.0559	2.0911	2.0559	1.8484	1.9418	2.1691	2.1125
Min	1.2637	1.2826	1.2752	1.2003	1.226	1.0751	1.2384
Avg	1.6177	1.6019	1.6370	1.4791	1.5323	1.4873	1.6312

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7733	.8131	.823	.724	.7545		.7049
2	.7282	.7842		.6859	.7545	.7282	.6859
3	.7095	.7392	.8131	.6668	.6979		.6668
4	.6979	.7133		.6478	.6602	.6878	.6668
5	.7655	.7682	.8402	.6478	.7282		.6668
6	.8488	.8131		.6859	.811	.7842	.8002
7	.9149	.9896	.9149	.7621	.8775		.9526
8	1.0751	1.0456		.9717	1.0562	1.0136	.9907
9	.9431	.9795	.9896	1.0027	.9431	.9335	1.0288
10	.8865	.9149	.924		.8676	.8299	.9055
11	.7922	.8676	.8686	.6908	.7733	.8029	.8316
12	.8676	.8299	.7682		.7356	.7468	.8316
13	1.1506	.811	.7392	.6348	.7401	.7545	.7842
14	.7545	.7545		.6722	.7189	.7095	.7577
15	.7356	.7356	.7468	.7095	.6979	.6979	.7207
16	.7378	.7167	.7282	.5415	.6602	.7282	.7207
17	.7577		.4715	.6722		.7545	.7655
18		.8402	.4919	.8299	.7468	.8299	.811
19	1.0269		1.1919	1.0185	1.0082	1.094	1.0374
20	1.1016	1.0829	1.0784	1.0185		1.0456	1.1317
21	1.0829	1.1016	1.0816	1.0082		1.0751	1.0562
22	1.0059		1.0288	.9709		1.0374	1.0269
23	.9328	.8775	.9335	.8962	.8775	.9639	.9709
24	.811	.8316	.8589	.8192	.7922	.7655	.8002
Max	1.1506	1.1016	1.1919	1.0185	1.0562	1.094	1.1317
Min	.6979	.7133	.4715	.5415	.6602	.6878	.6668
Avg	.8739	.8576	.8575	.7853	.7951	.8491	.8465

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 205 / RAW WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.3696	.3734	.4108	.2987		.3795
2	.2801	.3326		.4108	.2772	.3921	.3772
3	.2614	.2957	.3547	.4108	.2801		.3772
4	.2587	.2561		.3921	.3142	.3547	.3772
5	.2987	.3326	.3174	.3921	.3326		.3772
6	.3174	.4066		.3921	.3174	.3921	.3961
7	.3142	.3881	.4108	.4108	.3174		.3961
8	.3174	.3881		.3734	.3174	.2987	.3602
9	.3734	.4207	.415	.4108	.3696	.4668	.3973
10	.4481	.3696	.4251		.4744	.4294	.462
11		.4805	.4805	.3174	.5281	.499	.4805
12	.5041	.4435	.4481		.5297	.4805	.5359
13	.5415	.4435	.4435	.3921	.5281	.4481	.499
14	.5041	.4251	.7392	.3734	.5281	.4251	.4854
15	.5228	.462	.3881	.3921	.5486	.4481	.499
16	.4854	.4435	.4435	.3921	.5041	.4481	.499
17			.3734	.3174		.5658	.4294
18	.4805	.4481	.4108	.2987	.4854	.4884	.3881
19	.4251		.4527	.3361	.4854	.4527	.3734
20	.4435	.4481	.4527	.3361		.4527	.3547
21	.4481	.3547	.4294	.3361		.3921	.2772
22	.2658		.4294	.2427		.3121	.2614
23	.4207	.4294	.4294	.3142	.4294	.4163	.3174
24	.3174	.4024	.3734	.4108	.3142	.4108	.3738
Max	.5415	.4805	.7392	.4108	.5486	.5658	.5359
Min	.2587	.2561	.3174	.2427	.2772	.2987	.2614
Avg	.3884	.3972	.4295	.3665	.4090	.4287	.4031

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 206 / APPLE HOSPITAL.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	.0549	.0747	.0747	.0739		.0732
2	.0549	.0549		.0747	.0739	.056	.056
3	.0543	.0554	.056	.0747	.0549		.056
4	.0554	.0549		.056	.0747	.056	.0747
5	.0747	.0732	.056	.056	.0747		.0747
6	.0747			.0747	.0554	.0747	.0747
7	.0914	.0924	.0747	.0747	.0739		.0747
8	.0905	.1097		.0747	.0739	.0747	.0747
9	.0739	.1109	.0934	.0716	.0739	.0934	.0914
10	.112	.1294	.0924		.1086	.1294	.1109
11	.128	.1267	.1097	.0934	.1267	.1097	.1463
12	.1307	.1646	.1663		.1267	.128	.1494
13	.1097	.0914	.1294	.0934	.128	.0934	.1294
14	.1307	.128	.1109	.0934	.128		.1294
15	.112	.1109	.0924	.0934	.0914	.1307	.1294
16	.1307	.0924	.1478	.0934	.128	.1254	.1646
17	.1109	.1307	.112	.1109		.1307	.128
18	.1109	.1307	.132	.0739	.1494	.0934	.0914
19	.1294		.112	.0739	.0747	.0747	.0924
20	.1307	.112	.0747	.0739		.0934	.0739
21	.1294	.0747	.1132	.0739		.0747	.0732
22	.0724		.0934	.0739		.112	.0739
23	.0732	.0934	.0747	.0724	.0934	.0747	.0924
24	.0732	.0732	.0747	.0747	.0943	.0747	.0751
Max	.1307	.1646	.1663	.1109	.1494	.1307	.1646
Min	.0543	.0549	.056	.056	.0549	.056	.056
Avg	.0970	.0983	.0995	.0785	.0939	.0947	.0962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 207 / 11 KV STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.3658	.547	.5847	.3584		.415
2	.6161	.3326		.3361	.3174	.3961	.4554
3	.5788	.2926	.3772	.3174	.3174		.4364
4	.3547	.3142		.3216	.2987	.3361	.4527
5	.2801	.3292	.5788	.3405	.3734		.415
6	.2801	.3658		.6036	.4108	.4481	.4175
7	.2427	.3475	.6161	.6036	.4715		.6262
8	.6979	.5853		.4338	.679	.5788	.8919
9	.3921	.3881	.5975	.6036	.5975	.5788	.5658
10	.3961	.8676			.6054	.4481	.6468
11	.4715	.4715	.4435	.6036	.7545	.4481	.6722
12	.8676	.6413	.6283		.5601	.5601	.7023
13	.4338	.679	.499	.5975	.679	.5788	.6838
14	.8488	.4108	.3881	.6908	.2263	.6036	.7577
15	.4527	.6348	.5975	.5601	.415	.6413	.5853
16	.7842	.6602	.4207	.6535	.5847	.6161	.6722
17	.8501	.7095	.4338	.3547		.6224	.6161
18	.3696	.6161	.3961	.6161	.5658	.3734	.547
19	.5788		.679	.6722	.3547	.6535	.6535
20	.3881	.7095	.3961	.7167		.6413	.3584
21	.5228	.4481	.3795	.4527		.6348	.4904
22	.5487		.5658	.4715		.4294	.6036
23	.3982	.3961	.3584	.3921	.5847	.4481	.3961
24	.6602	.3841	.567		.3734	.4294	.3799
Max	.8676	.8676	.679	.7167	.7545	.6535	.8919
Min	.2427	.2926	.3584	.3174	.2263	.3361	.3584
Avg	.5265	.4977	.4984	.5203	.4764	.5233	.5601

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 202 / 11KV RANKALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0562	1.0562	1.0456	1.0059	1.0562	.9877	.9511
2	.9431	.9431	.9808	.9511	.9808	.9877	.9511
3	.9054	.9054	.9808	.9511	.9808	.9511	.9511
4	.9054	.9054	1.0185	.9511	1.0185		.9511
5	.9808	.9431	1.0562	.9877	.9619	1.0242	1.0242
6	1.094	1.1506	1.1317	1.0242	1.094	1.0974	1.1041
7	1.2449	1.3203	1.1949	1.086	1.2826	1.262	1.1765
8	1.4377	1.3014	1.1827	1.1222	1.2696	1.2437	1.2851
9	1.2197	1.3392	1.1827	1.1403	1.2323	1.1706	1.267
10	1.0242	1.0974	1.0974	1.1765	1.0608	1.0719	.9877
11	1.0029	1.0242	.9593	1.1946	.9511	1.0059	.9709
12	.9114	1.0242	.9922	.9774	.9328	.9492	1.0029
13	.8688	.9511	1.0317	1.086	.9145	.9313	.9313
14	.8779	.8962	.9671	1.1946	.8596	.9492	.9313
15	.8779	.8962	.9492	.9593	.8779	.9412	.9511
16	.8779	.8962	.9694	.9593	.8779	.905	.9511
17	.8688	.9511	.9694	.9593	.9511	.905	.9511
18	1.1041	1.0029	1.0974	1.0631	.9955		1.0387
19	1.6108	1.5927	1.5181	1.5223	1.4842	1.5927	1.6289
20	1.647	1.5927	1.5384	1.6108	1.5203	1.6289	1.6827
21	1.6108	1.6095	1.5203	1.5364	1.5023	1.5927	1.5912
22	1.4661	1.4784	1.448	1.4415	1.448	1.448	1.4969
23	1.3769	1.2696	1.267	1.2567	1.2308	1.2308	1.4003
24	1.094	1.2449	1.1203	1.086	1.0829	1.0317	1.0498
Max	1.647	1.6095	1.5384	1.6108	1.5203	1.6289	1.6827
Min	.8688	.8962	.9492	.9511	.8596	.905	.9313
Avg	1.1253	1.1413	1.1341	1.1351	1.1069	1.1322	1.1345

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 203 / 11KV MAHALAXMI SANEGURUJI SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.7522	.7842	.8326	.7522	.7522	.7964
2	.6805	.6805	.6908	.7602	.7164	.7164	.7602
3	.6805	.7164	.6908	.724	.7164	.7164	.7602
4	.7164	.7682	.7095	.724		.7522	.7602
5	.7522	.788	.8215	.7421	.7522	.788	.8145
6	.8059	.8238	.9335	.7701	.8059	.8238	.8507
7	1.0029		1.0374	.8238	.9492	.9492	.8954
8	1.0029	.9492	.9511	.9134	.9492	.9134	.9134
9	1.0566	.9313	.9145	.985	.9134	.8775	.9671
10	.8145	.7701	.8059	.9134	.788	.8238	.788
11	.7783	.788	.7701	.7701	.7522	.6805	.7602
12	.7421	.7343	.7343	.7522	.6626	.6805	.7087
13	.6154	.7164	.6805	.6984	.6268	.6805	.7421
14	.6401	.6805	.6447	.6626	.6447	.6447	.6697
15	.6335	.6805	.6089	.6626	.6447	.6447	.7421
16	.695	.6626	.6984		.679	.6805	.7133
17	.7133	.6984	.7164	.7343	.6805	.7164	.7783
18	.7865	.788	.8059	.8059	.6984	.8059	.8059
19	1.2986	1.1946	1.182	1.2178	1.1462	1.2536	1.2715
20	1.3352	1.3394	1.2536	1.2536	1.2178	1.2894	1.2894
21	1.3352	1.2986	1.2178	1.2357	1.2357	1.2536	1.2536
22	1.262	1.2752	1.1641	1.1462	1.182	1.1999	1.1999
23	1.0566	1.0791	1.0029	1.0745	.985	.9313	1.0745
24	.8238	.8238	.8962	.8775	.788	.788	.8238
Max	1.3352	1.3394	1.2536	1.2536	1.2357	1.2894	1.2894
Min	.6154	.6626	.6089	.6626	.6268	.6447	.6697
Avg	.8742	.8669	.8631	.8730	.8385	.8484	.8808

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 205 / PUIKHADI WATER WORKS NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4904	.5093	.4904	.4904	.4904	.4904
2	.4904	.4904	.5093	.4904	.4904	.4904	.4904
3	.5281	.5281	.4904	.5093	.5281	.5281	.4904
4	.5281	.5658	.4904	.4904	.5281	.5658	.4904
5	.5658	.547	.547	.5093	.5658	.5281	.5093
6	.6036	.547	.5847	.5281	.5658	.5281	.5281
7	.5658	.5093	.6036	.5281	.6036	.5093	.5281
8	.6036	.547	.5658	.5658	.6036	.547	.5093
9	.5281	.5093	.4904	.5658	.4904	.5093	.5281
10	.5658	.4527	.4527	.5281	.4715	.5281	.4904
11	.5093	.5093	.4904	.4904	.4904	.5281	.6036
12	.5093	.5093	.5281	.5093	.4904	.5281	.5658
13	.5093	.4904	.5281	.5093	.5093	.4904	.5093
14	.4715	.4527	.4904	.4715	.4527	.4904	.4715
15	.5281	.4207	.4904	.4715	.4904	.4904	.5281
16	.4715	.4527	.4904		.4527	.4904	.5093
17	.5281	.4904	.5281	.5093	.4904	.5281	.5281
18	.5658	.5281	.5093	.5014	.4904	.5093	.5281
19	.5304	.5281	.5093	.4904	.5281	.4715	.4904
20	.4904	.4904	.4904	.6036	.4904	.4527	.4904
21	.547	.547	.5093	.5281	.5281	.4904	.5281
22	.5281	.547	.5093	.5281	.5281	.5093	.5281
23	.5093	.4904	.5093	.5281	.547	.5093	.5281
24	.5281	.5281	.5281	.5093	.5281	.5281	.5093
Max	.6036	.5658	.6036	.6036	.6036	.5658	.6036
Min	.4715	.4207	.4527	.4715	.4527	.4527	.4715
Avg	.5307	.5072	.5148	.5155	.5148	.5100	.5155



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 206 / K N Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.381	.3772	.3429	.3361	.381	.3511	.3361
2	.3048	.3395	.3429	.2987	.3429	.3511	.2801
3	.3048	.3395	.3429	.2987	.3048	.3696	.2801
4	.3429	.3395	.3429	.2987	.3048	.3696	.2801
5	.3429	.415	.4001	.3361	.3429	.4024	.3547
6	.4191	.4527	.4763	.3881	.4001	.4207	.4251
7	.5716	.547	.5847	.5175	.5335	.5729	.5175
8	.6224	.5847	.5281	.5914	.5658	.5544	.5729
9	.547	.5658	.4294	.5914	.547	.5359	.5544
10	.4251	.4251	.3881	.499	.4435	.4294	.4251
11	.3761	.4066	.4207	.4805	.4066	.3921	.3982
12	.394	.3881	.3761	.4066	.3696	.362	.3761
13	.3326	.3696	.3475	.3881	.3326	.362	.362
14	.3511	.3326	.3475	.3326	.3326	.3658	.362
15	.3881	.3511	.3439	.3511	.3142	.3475	.3696
16	.3511	.3511	.3881	.3696	.3142	.3326	.3881
17	.3696	.4066	.4024	.3881	.3326	.3475	.3982
18	.4251	.4163	.4066	.4298	.3511	.4024	.4344
19	.5729	.5914	.5544	.5853	.5359	.567	.6099
20	.6283	.6161	.6283	.6099	.6099	.6099	.6161
21	.6099	.6224	.6099	.6161	.5729	.5914	.5975
22	.5611	.6036	.5729	.5847	.5544	.5729	.5847
23	.4904	.4954	.4435	.4904	.4435	.4805	.5281
24	.4001	.3961	.4001	.4066	.381	.3511	.3696
Max	.6283	.6224	.6283	.6161	.6099	.6099	.6161
Min	.3048	.3326	.3429	.2987	.3048	.3326	.2801
Avg	.438	.4472	.4342	.4415	.4174	.4351	.4342

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 201 / 11 KV MASKUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5304	.5487	.547	.5544	.5304	.5304	.4854
2	.4572	.5304	.5281	.5544	.5121	.4938	.4668
3	.4572	.5121	.5093	.5175	.5121	.4938	.4481
4	.4572	.5121	.5093	.5175	.5121	.4938	.4481
5	.4755	.5487	.5281	.5544	.5304	.5121	.4668
6	.5304	.567	.5658	.5544	.5487	.567	.5975
7	.567	.6154	.5658	.5175	.5853	.6036	.547
8	.5853	.6516	.5788	.5544	.5853	.6036	.6348
9	.6584	.6516	.6036	.6516	.5853	.5853	.6283
10	.5853	.6154	.5853	.5973	.567	.6036	.5729
11	.5487	.543	.543	.5304	.567	.5121	.4755
12	.543	.543	.543	.5304	.5121	.5487	.5487
13	.5014	.4706	.5249	.5304	.4755	.5487	.5853
14	.4656	.4706	.5068	.4938	.4755	.5121	.5121
15	.4835	.394	.4755	.4755	.4656	.4938	.5304
16	.4887	.543	.4572	.4572	.4755	.4938	.5121
17	.5249	.5792	.439	.5121	.4755	.5487	.543
18	.6154	.591	.6154	.6219	.5121	.6135	.6401
19	.8869	.8954	.905	.8962	.823	.443	.8962
20	.905		.905	.8962	.8596	.9134	.8962
21	.8869	.8596	.8326	.8596	.823	.8596	.8413
22	.8326	.8238	.8145	.7865	.7865	.8326	.8048
23	.724	.7059	.724	.695	.6767	.7207	.695
24	.5853	.5792	.6161	.5853	.567	.567	.5601
Max	.905	.8954	.905	.8962	.8596	.9134	.8962
Min	.4572	.394	.439	.4572	.4656	.443	.4481
Avg	.5957	.5979	.6010	.6018	.5818	.5873	.5974

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 202 / 11KV GANGAVES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1663	.1663	.1886	.1509	.1663	.1663	.1905
2	.1478	.1478	.1905	.1509	.1294	.1294	.1715
3	.1478	.1478	.1715	.132	.1294	.1294	.1715
4	.1478	.1478	.1524	.132	.1294	.1294	.1524
5	.1478	.1478	.1524	.1509	.1478	.1478	.1524
6	.1663	.1848	.1715	.1886	.1663	.1663	.1905
7	.1848	.2033	.1715	.1886	.2033	.1848	.2096
8	.2033	.2033	.1905	.1886	.2033	.1848	.1905
9	.2218	.2218	.2033	.2218	.2033	.2218	.2452
10	.2957	.3142	.2402	.2218	.2772	.2402	.2801
11	.3326	.3696	.2772	.2772	.3326	.3326	.3511
12	.3658	.3696	.2957	.2772	.3696	.3326	.3881
13	.3292	.3696	.2772	.2772	.3696	.3326	.3658
14	.3326	.3658	.2772	.2402	.3142	.2957	.3475
15	.3326	.3292	.2957	.2402	.3142	.3142	.3142
16	.3511	.3658	.2957	.2772	.3696	.3696	.3658
17	.3511	.4207	.2957	.2772	.3881	.3696	.3881
18	.3881	.4024	.3326	.2772	.2957	.3841	.4066
19	.5175	.4887	.4435	.4066		.5068	.499
20	.499	.4755	.4024	.4066	.4805	.4706	.462
21	.3511	.3696	.3292	.3326	.3696	.3658	.3696
22	.2587	.2772	.2587	.2587	.2772	.2772	.2772
23	.2402	.2427	.2218	.2218	.2218	.2452	.2402
24	.1848	.2033	.2075	.2241	.2033	.1848	.1886
Max	.5175	.4887	.4435	.4066	.4805	.5068	.499
Min	.1478	.1478	.1524	.132	.1294	.1294	.1524
Avg	.2777	.2889	.2518	.2383	.2636	.2701	.2883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 203 / 11KV MAHADWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9328	.9328	.9425	.961	.9877	.9511	.9055
2	.8779	.8962	.9055	.961	.9511	.8596	.8871
3	.8779	.8962	.8871	.8871	.8779	.8596	.8775
4	.8779	.8962	.8962	.8871	.8779	.8596	.8775
5	.9511	.9145		.961	.8779	.8962	.8962
6	1.0242	1.0425	1.0456	.9979	.9511	.9511	1.0456
7	1.0608	1.134	1.1016	.9979	1.0059	1.0425	1.0719
8	1.2071	1.2254	1.2012	1.1458	1.134	1.134	1.1643
9	1.1888	1.2254	1.1946	1.1584	1.2254	1.2071	1.2567
10	1.2254	1.2308	1.1765	1.2127	1.262	1.262	1.3491
11	1.39	1.267	1.1946	1.2308	1.3169	1.2986	1.3169
12	1.3756	1.4118	1.2308	1.1765	1.2986	1.39	1.3032
13	1.3073	1.3394	1.2127	1.1888	1.2803	1.3756	1.3213
14	1.267	1.3394	1.1765	1.0974	1.1641	1.2489	1.267
15	1.1999	1.267	1.1041	1.0242	1.182	1.1523	1.2127
16	1.2048	1.267	1.1403	1.0608	1.1462	1.2308	1.1403
17	1.2851	1.3213	1.1403	1.134	1.182	1.3032	1.2851
18	1.4842	1.4661	1.3756	1.3352	1.3717	1.4529	1.4815
19	2.1033	2.0237	1.9185	1.9753	1.9204	2.0595	2.0485
20	2.1399	2.0595	1.9547	2.0302	2.0302	2.0774	2.0302
21	1.7193	1.7372	1.6832	1.701	1.7193	1.7372	1.701
22	1.4998	1.4506	1.4118	1.4266	1.4266	1.4661	1.4815
23	1.2437	1.2489	1.2308	1.2071	1.1523	1.2071	1.2437
24	1.0242	1.0425	1.0719	1.0242	1.0242	.9877	1.0164
Max	2.1399	2.0595	1.9547	2.0302	2.0302	2.0774	2.0485
Min	.8779	.8962	.8871	.8871	.8779	.8596	.8775
Avg	1.2695	1.2765	1.2259	1.1993	1.2236	1.2504	1.2575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 204 / MIRABAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8326	.8507	.8962	.8779	.8507	.8507	.8048
2	.7964	.7783	.8589	.8779	.8326	.8326	.7947
3	.7602	.7602	.8402	.8413	.8326	.8326	.7762
4	.7602	.7602	.8402	.8413	.8326	.8326	.7762
5	.7682	.8145	.8589	.8779	.8688	.8507	.8029
6	.8688	.905	1.0082	.9145	.8869	.8688	.9709
7	.9231	.9231	.9709	.9877	.9231	.8869	.9431
8	.9774	1.0498	1.0082	.9877	1.0317	1.0136	
9	.9231	.9593	.9694	1.0498	.9774	.9774	.961
10	.9955	.9671	.9877	1.0679	.9955	.9774	1.0242
11	.9412	1.0029	1.0136	1.086	.9412	.9412	1.0059
12	.9134	1.0029	.9774	1.0136	.905	.9774	.9774
13	.8775	.9313	.9412	1.0136	.905	.9774	.905
14	.905	.8954	.8869	.9231	.8238	.8326	.9231
15	.8775	.8326	.905	.905	.8326	.8145	.9231
16	.8688	.9313	.905	.905	.8869	.8688	.9231
17	.8954	.9134	.9774	.9671	.905	.9412	.9412
18	1.0136	.9671	1.0498	1.0136	.8869	.9568	.9774
19	1.4299	1.4506	1.448	1.4842	1.3032	1.4148	1.4299
20	1.4842	1.4864	1.4327	1.4842	1.3575	1.4632	1.4661
21	1.3756	1.4148	1.3575	1.3756	1.3575	1.3352	1.3575
22	1.267	1.3213	1.2489	1.2489	1.2489	1.2986	1.3032
23	1.0679	1.1041	1.086	1.0679	1.0317	1.0534	1.0679
24	.9231	.8688	.9979	.905	.8869	.8688	.9145
Max	1.4842	1.4864	1.448	1.4842	1.3575	1.4632	1.4661
Min	.7602	.7602	.8402	.8413	.8238	.8145	.7762
Avg	.9769	.9955	1.0194	1.0299	.971	.9861	.9987

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 206 / 11 KV SAKOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3258	.3206	.3326	.3292	.3109	.2987
2	.2561	.3077	.3174	.3326	.3109	.2743	.2801
3	.2561	.3077	.2987	.2587	.2743	.2743	.2614
4	.2561	.3077	.2987	.2587	.2743	.2743	.2614
5	.3292	.3258	.3174	.3326	.2926	.3109	.2801
6	.3841	.362	.3734	.3696	.3475	.3511	.3547
7	.4572	.4706	.4668	.4066	.439	.439	.4481
8	.5121	.4887	.4805	.4805	.4572	.4572	.4854
9	.4938	.5068	.4706	.4344	.4755	.4572	.4755
10	.4938	.4706	.4755	.4344	.439	.4572	.4938
11	.4344		.4525	.4525	.4207	.3982	.439
12	.4119	.4706	.4344	.4163	.4024	.4344	.4344
13	.4075	.4706	.4344	.4163	.439	.4344	.4344
14	.4119	.4525	.4163	.3439	.3982	.4163	.4344
15	.3982	.3982	.4163	.3439	.4163	.4163	.4163
16	.3841	.4344	.4344	.3439	.3658	.3982	.4163
17	.4163	.4344	.4344	.3982	.3801	.4344	.4525
18	.4525	.4656	.4706	.4344	.4344	.4784	.4706
19	.6154	.6201	.6154	.5792	.567	.591	.5973
20	.6154	.6089	.6154	.5611	.5853	.5792	.5973
21	.5792	.543	.5611	.5068	.5853	.543	.5611
22	.543	.5249	.5068	.5121	.5304	.5304	.5068
23	.4525	.4572	.4344	.4572	.439	.4435	.4344
24	.3658	.362	.3921	.3658	.3658	.3475	.3734
Max	.6154	.6201	.6154	.5792	.5853	.591	.5973
Min	.2561	.3077	.2987	.2587	.2743	.2743	.2614
Avg	.4273	.4398	.4349	.4072	.4154	.4188	.4253

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 207 / SHUKRAWAR GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.5611	.5415	.5914	.5611	.5611	.5175
2	.4887	.5249	.5228	.5914	.543	.5249	.499
3	.4887	.5249	.5041	.5544	.5611	.5249	.5041
4	.4887	.5249	.5041	.5544	.5611	.5249	.4854
5	.5249	.543	.5041	.5544	.5611	.543	.5041
6	.5792	.6154	.5601	.5544	.5792	.5611	.5975
7	.6697	.6697	.6161	.5487	.6154	.5973	.6535
8	.6878	.7059	.6908	.7023	.6878	.7059	.7282
9	.7421	.7421	.724	.724	.7059	.724	.7577
10	.6878	.7059	.6697	.6878	.6697	.6697	.7133
11	.6335	.6878	.6335	.6516	.6516	.6154	.6767
12	.6447	.6878	.6516	.6154	.6154	.6154	.6584
13	.6089	.6516	.6335	.6154	.6154	.6154	.6878
14	.5731	.6154	.6099	.5249	.5973	.6154	.6335
15	.5792	.6154	.5792	.543	.5792	.5792	.6154
16	.5731	.6154	.5792	.5792	.5792	.6154	.6335
17	.6154	.6335	.6516	.5792	.5792	.6697	.6878
18	.7421	.7602	.724	.6697	.6335	.7011	.7783
19	1.0136	1.0208	1.0498	1.0136	.9593	1.0208	1.0679
20	1.0317	1.0208	1.0029	.9955	.9593	1.0277	1.0136
21	.9774	.9774	.9412	.9231	.9412	.9492	.9774
22	.8869	.9145	.8869	.8507	.8507	.8596	.8688
23	.7421	.7865	.7602	.7421	.7059	.7421	.724
24	.6335	.5973	.6468	.6219	.6335	.5792	.5914
Max	1.0317	1.0208	1.0498	1.0136	.9593	1.0277	1.0679
Min	.4887	.5249	.5041	.5249	.543	.5249	.4854
Avg	.6719	.6959	.6745	.6662	.6644	.6726	.6906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 208 / 11 KV LAXTIRTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4298	.4108	.439	.439	.4572	.4066
2	.3658	.4119	.3921	.439	.4024	.4024	.3881
3	.3292	.4119	.3734	.4024	.4024	.4024	.3734
4	.3292	.4119	.3734	.4024	.4024	.4024	.3734
5	.3292	.4298	.3921	.4435	.4207	.4024	.3921
6	.4207	.4656	.4668	.4572	.439	.4207	.4668
7	.5121	.4961	.4668	.4755	.4572	.4207	.4715
8	.5304	.5014	.4938	.5121	.4938	.4572	.5041
9	.5304	.5194	.4835	.5552	.5304	.4938	.499
10	.5121	.5014	.4298	.5014	.5121	.439	.5121
11	.4755	.4656	.4298	.4835	.4755	.4835	.4344
12	.4607	.4656	.4784	.4835	.4755	.4298	.4887
13	.4287	.4298	.4477	.4477	.5121	.4298	.5068
14	.407	.394	.4656	.4298	.4382	.4119	.4706
15	.4334	.4298	.4656	.4656	.4334	.4298	.4887
16	.4031	.4298	.4835	.4298	.4508	.4477	.4887
17	.443	.4075	.4656	.4298	.4161	.4477	.4656
18	.4607	.4607	.5014	.4119	.4784	.4458	.5014
19	.6626	.6447	.7164	.6447	.695	.6661	.6626
20	.7343	.6733	.7164	.6626	.6767	.7087	.6805
21	.6626	.6447	.6626	.6268	.6767	.6805	.6447
22	.6268	.6335	.6268	.5853	.6219	.6516	.6268
23	.5194	.5304	.5373	.5304	.5121	.5487	.5373
24	.4755	.4477	.4668	.4706	.4572	.4207	.4435
Max	.7343	.6733	.7164	.6626	.695	.7087	.6805
Min	.3292	.394	.3734	.4024	.4024	.4024	.3734
Avg	.4788	.4848	.4894	.4887	.4925	.4792	.4928



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 201 / 11KV TRYAMBOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.4481	.3734	.3163	.3734	.3734	.3734
2	.3696	.4481	.3734	.3239	.3326	.3734	.3734
3	.3696	.4435	.3734	.3125	.3361	.3696	.3734
4	.3734	.4435	.3734	.3048	.3361	.3734	.3734
5	.4481	.4854	.3734	.2743	.4481	.4481	.3734
6	.5228	.5175	.5228	.3429	.4854	.4854	.5175
7	.4805	.4805	.5975	.3429	.5281	.5281	.5228
8	.4435	.439	.5228	.3429	.4854	.5228	.5975
9	.4435	.4435	.4435	.4527	.4481	.5228	.5175
10	.2926	.3696	.3658	.3658	.4024	.3734	.3658
11	.2926	.3658	.3582	.3658	.2926	.3658	.362
12	.2896	.362	.3582	.3582	.2926	.2896	.3582
13	.2896	.3658	.3582	.3658	.2896	.3658	.362
14	.3772	.3696	.3658	.2926	.2926	.2957	.3696
15	.3696	.3734	.3658	.2957	.2957	.3734	.3696
16	.3658	.3696	.2987	.2987	.0754	.2987	.3734
17	.362	.3658	.3658	.3658	.362	.3658	.3658
18	.3582	.3658	.362	.4252	.3582	.4298	.3582
19	.6447	.6447	.567	.5731	.5068	.6379	.631
20	.6584	.724	.5792	.7164	.6154	.7164	.6516
21	.5853	.6653	.5853	.6516	.5853	.724	.5792
22	.5853	.6653	.5914	.5853	.5914	.6584	.5853
23	.5228	.5975	.5175	.5175	.5228	.5175	.5175
24	.3658	.4481	.4481	.3749	.3734	.4481	.4481
Max	.6584	.724	.5975	.7164	.6154	.724	.6516
Min	.2896	.362	.2987	.2743	.0754	.2896	.3582
Avg	.4243	.4667	.4350	.3986	.4012	.4524	.4467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 201 / 11KV Panchganga Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0324		.0655		
2		.0324		.0648		
3		.0324		.0648		
4		.0648		.0648		
5		.0648		.081		
6		.081		.081		
7		.0972		.081		
8		.0972		.081		
9		.081	.0953			
10	.0972				.1134	.1334
11	.1134				.1296	.1715
12	.1296				.1457	.1715
13	.1134				1.2955	.1715
14	.1134				.1296	.1524
15	.0648				.1296	.1334
16	.0972				.1296	.1715
17	.0953			.1334		.1296
24		.0324	.061	.0648		
Max	.1296	.0972	.0953	.1334	1.2955	.1715
Min	.0648	.0324	.061	.0648	.1134	.1296
Avg	.1030	.0616	.0782	.0782	.2961	.1544

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 202 / Shirol

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0374	.9907	.9526		.9242	.8383	
2	.9997	.9717	.9335		.9054	.8002	
3	.9808	.9526	.9145		.8865	.8002	
4	.9808	.9526	.9145		.9054	.8192	
5	.9997	.9717	.9907		.9242	.8383	
6	1.0374	1.0288	1.105		.9808	.8954	
7	1.2071	1.2003	1.1812		1.1317	1.086	
8	1.3203	1.3717	1.1622		1.1317	1.2384	
9	1.4289		1.3957	1.3908		1.358	1.5051
10	1.5813		1.6409	1.5623		1.5844	1.5242
11	1.848		1.7164	1.6194		1.6221	1.5813
12	1.6385		1.6221	1.5242		1.5844	1.4861
13	1.5242		1.4523	1.2384		1.5089	1.4098
14	1.5623		1.5089	1.2955		1.5089	1.467
15	1.5813		1.5844	1.4098		1.5844	1.7337
16	1.5623		1.7164	1.3717		1.6598	1.7337
17	1.5623	1.7337		1.4335	.4763		1.6221
18	1.6575	1.6385		1.3957	.4954		1.5655
19	1.6385	1.6575		1.5089	1.2955		1.7353
20	1.5623	1.5242		1.3392	1.2193		1.5089
21		1.3336		1.3014	1.1622		1.3392
22	1.2955	1.2574		1.226	1.1241		1.226
23	1.1622	1.086		1.0185	.9526		1.0751
24	1.0562	1.0288	.9907	.8421	.9808	.8764	.8421
Max	1.848	1.7337	1.7164	1.6194	1.2955	1.6598	1.7353
Min	.9808	.9526	.9145	.8421	.4763	.8002	.8421
Avg	1.3576	1.2312	1.2813	1.3423	.9685	1.2120	1.4597

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 204 / Tarabai Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2437	1.3014	1.2437		1.1888	1.2574	
2	1.1523	1.2193	1.1523		1.134	1.2003	
3	1.134	1.1812	1.134		1.0974	1.1622	
4	1.0974	1.2003	1.134		1.0608	1.1812	
5	1.134	1.2384	1.2437		1.0974	1.2193	
6	1.4449	1.531	1.3535		1.262	1.4045	
7	1.6095	1.6263	1.4998		1.4998	1.5524	
8	1.7193	1.7187	1.5912		1.5364	1.6263	
9	1.5912		1.6095	1.6575		1.6644	1.6448
10	1.6095		1.6278	1.5154		1.4998	1.5154
11	1.5912		1.4815	1.5708		1.4815	1.4563
12	1.5364		1.5546	1.46		1.5364	1.4415
13	1.4632		1.5364	1.4045		1.4815	1.5339
14	1.4266		1.4632			1.4266	1.4969
15	1.4449		1.4632	1.386		1.4998	1.5154
16			1.4266	1.3121		1.4815	1.5339
17	1.4784	1.4632		1.3535	1.4969		1.5546
18	1.5154	1.5364		1.39	1.5893		1.6461
19	2.1253	2.0668		1.9387	1.922		2.0485
20	2.1992	2.1399		2.1033	2.0513		2.2131
21	2.0883	2.0851		2.0851	1.9774		2.1033
22	1.9959	1.9022		1.829	1.8296		1.9204
23	1.7737	1.6644		1.5912	1.5684		1.6461
24	1.4083	1.4523	1.39	1.286	1.3169	1.3443	1.2689
Max	2.1992	2.1399	1.6278	2.1033	2.0513	1.6644	2.2131
Min	1.0974	1.1812	1.134	1.286	1.0608	1.1622	1.2689
Avg	1.5558	1.5829	1.4062	1.5922	1.4768	1.4129	1.6587

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 206 / Vikramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7655	.8002	.811		.7282	.743	
2	.7282	.7621	.7733		.6908	.7049	
3	.7095	.724	.7545		.6535	.6668	
4	.7095	.724	.7545		.6722	.6859	
5	.7468	.7621	.7922		.679	.6859	
6	.8402	.8573	.8865		.811	.8192	
7	.8775	.9907	.9808		.9149	.9145	
8	.9431	1.0098	.9997		.8962	.9717	
9	.9054		.9431	.9145		.9522	1.0098
10	.9054		.9522	.9907		.8775	
11	.811		.9709	.8573		.8402	.9145
12	.9054		.8775			.6722	.8764
13	.7356		.811	.724		.7842	.8002
14	.7545		.7167	.743		.8589	.7545
15	.7733		.7842	.7621		.7655	.8488
16	.7545		.7842	.724		.811	1.1431
17	.7621	.8299		.8029	.743		.9431
18	.8954	.8676		.7468	.8002		.8865
19	1.2193	1.2637		1.1576	1.1431		1.1883
20	1.2955	1.2826		1.2136	1.1812		1.1949
21	1.2384	1.2449			1.1431		1.1763
22	1.1241	1.1883		1.0642	1.086		1.1203
23	1.0562	1.0751		1.1203	.9717		.9896
24	.8402	.8954	.8865	.823	.8215	.8383	.7545
Max	1.2955	1.2826	.9997	1.2136	1.1812	.9717	1.1949
Min	.7095	.724	.7167	.724	.6535	.6668	.7545
Avg	.8874	.9549	.8517	.9031	.8710	.7995	.9734

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 207 / Industrial Bapat Camp MYZ      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5281	.5335	.6097		.5847	.5906	
2	.5093	.5144	.5716		.5847	.5716	
3	.4904	.4954	.5716		.5658	.5525	
4	.4904	.4954	.5716		.547	.5525	
5	.5093	.5144	.6097			.5906	
6	.5658	.5335	.6478		.1132	.6478	
7	.547	.5525	.6478			.6097	
8	.5281	.5144	.6478		.3961	.5906	
9	.6097		.7922	.7049		.7545	.9145
10	.7811		1.0374	.9145		.9808	
11	.7621		1.0374	.8954		1.0374	.8954
12	.7049		1.0185	.8954		.9997	.9907
13	.7621		.9808	.7049		.8865	1.0288
14	.7811		.9997	.724		.7733	.8192
15	.8573		1.1506	.743		.9619	1.0098
16	.9335		1.1128	.5906		1.0374	1.0098
17	.8383	1.2384		.7922	.743		1.0374
18	.7621	.9145		.7922	.6478		.9808
19	.8383	1.0098		.7922	.7621		1.0562
20	.7049	.7621		.7167	.7049		.811
21	.6097	.5906		.6602	.7049		.6413
22	.5906	.6859		.6413	.6668		.6224
23	.5335	.6859		1.7353	.6287		.5658
24	.5093	.5335	.6097	.583	.5658	.5906	.5658
Max	.9335	1.2384	1.1506	1.7353	.7621	1.0374	1.0562
Min	.4904	.4954	.5716	.583	.1132	.5525	.5658
Avg	.6561	.6609	.8010	.8054	.5868	.7487	.8633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 209 / DYP DF EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3239	.3239		.2641	.2477	
2	.2263	.2286	.2477			.1905	
3	.2075	.1905	.1905		.1698	.1715	
4	.1886	.1905	.1905		.1698	.1715	
5	.2075	.2096	.2096		.1698	.1715	
6	.2452	.2477	.2286		.1886	.1905	
7	.3018	.3239	.2858		.2075	.2667	
8	.2829	.362	.3429		.2829	.2667	
9	.381		.4338	.4001		.3395	.381
10	.5335		.5093	.4382		.4715	.4572
11	.5335		.5658	.6287		.547	.6668
12	.6097		.7545	.6859		.7167	.724
13	.724		.7733	.8573		.7167	.7049
14	.6859		.7733	.8002		.7167	.7049
15	.724		.811	.9526		.7545	.724
16	.7049		.7733	.9717		.7733	.7621
17	.743	.7621		.8676	.7049		.7733
18	.6859	.7049		.8676	.743		.8865
19	.8383	.8764		.9242	.8383		.9054
20	.8764	.8192		.8676	.8192		.9619
21	.8954	.7811		.7167	.724		.7922
22	.6668	.5525		.6224	.5335		.6036
23	.5716	.5335		.415	.4382		.4904
24	.3772	.4191	.4191	.3584	.3018	.3239	.3395
Max	.8954	.8764	.811	.9717	.8383	.7733	.9619
Min	.1886	.1905	.1905	.3584	.1698	.1715	.3395
Avg	.5309	.4703	.4608	.7109	.4370	.4139	.6799

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 201 / Kay Industry  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2614	.2858	.2858	.2614	.2614	.2987	.2614
2	.2614	.2858	.2858	.2614	.2614	.2987	.2614
3	.2614	.2667	.2858	.2801	.2801	.2801	.2614
4	.2801	.2858	.2667	.2801	.2801	.2801	.2614
5	.2801	.3239	.2858	.2801	.2801	.2987	.2614
6	.2614	.2858	.2858	.2801	.2801	.2987	.2614
7	.2614	.2858	.2858	.2987	.2801	.2987	.2614
8	.2614	.2858	.2858	.2987		.2614	.2614
9	.2801	.2858	.2858	.2987	.2614	.2801	.2614
10	.2858	.2667	.3048	.2858		.2858	.2667
11	.2858	.2858	.3048	.2858		.2667	.2667
12	.2667	.0381	.3048	.2667		.2667	.3048
13	.2667	.2667	.2667	.2667		.2667	.2858
14	.2667	.2667	.2667	.2667		.3048	
15	.2667	.3048	.2667	.3048		.3048	.2667
16	.2667	.3048	.2667	.3048		.3048	.2667
17	.3048	.2801	.2614	.2667		.0381	.2667
18	.0381	.0373	.0373	.2667		.0381	.2667
19	.0381	.0373	.0373	.0381	.0381	.0381	.2667
20	.0381	.0373	.0373	.0381	.2667	.0381	.0381
21	.0381	.0373	.0373	.0381	.2667	.0381	.0381
22	.2667	.0373	.0373	.0381	.3239	.0381	.0381
23	.2667	.2667	.2614	.0373	.2987	.2614	.0373
24	.2614	.2667	.2667	.2614	.2614	.2987	.2614
Max	.3048	.3239	.3048	.3048	.3239	.3048	.3048
Min	.0381	.0373	.0373	.0373	.0381	.0381	.0373
Avg	.2319	.2219	.2296	.2294	.2600	.2243	.2271



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 202 / Sakal Press DBlock Shirol  
 Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
 STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1016	1.2955	1.4861	1.0829	1.1016	1.0829	1.0456
2	1.1203	1.2765	1.467	1.1016	1.1203	1.0642	1.0269
3	1.1389	1.2384	1.4289	1.1203	1.1389	1.0456	.9709
4	1.1203	.9717	1.0288	1.1203	1.1203	1.0269	.9335
5	1.0829	.9335	.8383	1.0642	1.0829	.9709	.8962
6	.9335	.8764		1.0269	.9709	.8962	.8589
7	.8589	.8573	.9335	.8215		.8589	.7842
8	.8962	.8954	.9335	.8775	.8029	.8775	.9335
9	.8775	.7811	.8002	.8962	.8589	.8962	1.0642
10	.9526	.724	.8573	1.0479		.8954	1.0098
11		.9717	1.1431	1.2193		.8573	.8764
12	.8573	.8764	1.0669	1.2193		.8573	.8002
13	.8954	.8002	.9335	.9526		.8764	.8192
14	.8954	.8573	.7811	.7621		.9526	.9145
15	.8954	.8764	1.1241	1.1812		.9335	.8192
16	.8954	.7621	1.1431	1.0669		.8954	.9145
17	.9526	.8402	1.0829	.8764		.8954	.9145
18	.8954	.8962	.9709	.8764		.8954	.8954
19	.8764		.8402	.8383	.6478	.8954	.8954
20	.8954	.9335	.8029	.8573	.7621	.8573	.8954
21	.8573	.8029	.8215	.9145	.6859	.7621	.8954
22	.8383	.9335	.8962	1.0479	.7621	.7621	.8954
23	.8954	.9907	.9335	1.0082	.8402	.7842	1.0082
24	1.0829	1.105	1.0669	1.0829	1.0456	.9335	.9054
Max	1.1389	1.2955	1.4861	1.2193	1.1389	1.0829	1.0642
Min	.8383	.724	.7811	.7621	.6478	.7621	.7842
Avg	.9485	.9346	1.0165	1.0026	.9243	.9072	.9155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 203 / Menon Metallics  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.6859	.6668	.6348	.5601	.4108	.5041
2	.4668	.6668	.6478	.6348	.5415	.3921	.5041
3	.5228	.6287	.6478	.5788	.5228	.3921	.4854
4	.5041	.6478	.5906	.5788	.5415	.3921	.5415
5	.4854	.6287	.5525	.5975	.5601	.4108	.5601
6	.5601	.6287	.5906	.5788	.5975	.4108	.5975
7	.6535	.6478	.6097	.6348	.6161	.4108	.6161
8	.6535	.5144	.6478	.6348		.5601	.5601
9	.6535	.6287	.5525	.6161	.3174	.5975	.5041
10	.6668	.9717	.7621	.8002		.5335	.5716
11	.6859	1.1241	.8954	1.105		.6859	.6097
12	.6859	.7049	.8573	1.0669		.8383	.5144
13	.7621	.7811	.7811	1.0098		.8002	
14	.9526	.7621	.7811	.743		.7811	.8954
15	1.0288	.9907	1.1241	.5525		.9145	.5906
16	1.0098	1.1812	.7811	.8383		1.105	.9717
17	.7049	1.0829	.7468	.6859		.9526	.9526
18	.6859	.6535	.6908	.6287		.9526	.9526
19	.6287	.4854	.6535	.6097	.4191	.6668	.6668
20	.6097	.4854	.6348	.6287	.4001	.5716	.6478
21	.6478	.4668	.6161	.6478	.4001	.4954	.6478
22	.6859	.4668	.6535	.4954	.4001	.4572	.6097
23	.6478	.5144	.6908	.5228	.3921	.4668	.6535
24	.4294	.6478	.5906	.6535	.5415	.4108	.4854
Max	1.0288	1.1812	1.1241	1.105	.6161	1.105	.9717
Min	.4294	.4668	.5525	.4954	.3174	.3921	.4854
Avg	.6575	.7082	.6986	.6866	.4864	.6087	.6366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 204 / Budhale

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1576	1.5432	1.6004	.8775	1.2696	.7842	.9522
2	1.1203	1.5813	1.5813	.8589	1.2136	.7468	.9335
3	1.0829	1.448	1.5051	.9335	1.1763	.7282	.8962
4	1.0642	1.1622	1.2955	.9522	1.1576	.7095	.8775
5	1.1203	.8573	.9335	1.0829	1.1389	.7282	.9335
6	1.1576	.8573	.8954	1.1016	1.1949	.8215	1.0829
7	1.1763	.8954	.8764	1.1949	1.1949	.8775	1.1949
8	1.307	1.1812	.9145	1.307		.9149	1.307
9	1.3256	1.3908	1.086	1.3256	.9709	.9522	1.4937
10	1.5242	1.6385	1.1241	2.0195		1.2193	1.848
11	1.5623	1.8671	2.2862	1.7528		1.6956	2.2672
12	1.5623	1.3717	1.9814	1.1812		1.9243	1.467
13	1.5623	1.7909	1.1622	1.4861		1.9814	1.448
14	1.8099	1.5432	1.9814	1.448		2.2291	1.5432
15	1.848	1.9624	1.7337	1.8671		2.2291	2.0767
16	1.8671	1.7147	1.9624	1.8099		1.848	1.448
17	1.4289	1.7177	1.8298	1.8671		1.8099	1.4861
18	1.7528	1.7364	1.4563	1.6385		1.8099	1.5242
19	1.6766	1.7551	1.1389	1.3527	.8383	1.7528	1.3336
20	1.5623	1.587	1.0829	1.1241	.8383	1.5242	1.3336
21	1.448	1.251	.8775	.9335	.8573	1.3336	1.2384
22	1.2955	1.251	.8775	1.2765	.8573	.9526	1.1431
23	1.3527	1.4098	.8775	1.2696	.8402	.9522	1.251
24	1.1576	1.3717	1.5432	.8962	1.2883	.8029	.9709
Max	1.8671	1.9624	2.2862	2.0195	1.2883	2.2291	2.2672
Min	1.0642	.8573	.8764	.8589	.8383	.7095	.8775
Avg	1.4134	1.4535	1.3585	1.3149	1.0597	1.3053	1.3354

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 205 / Chintamani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5806	.6859	.6478	.5041	.4887	.5041	.5228
2	.5601	.6478	.6478	.4854	.5228	.5041	.5041
3	.5415	.6478	.6287	.4668	.5415	.4854	.4854
4	.5415	.6287	.6287	.5228	.5041	.4854	.4854
5	.5228	.6478	.6287	.5415	.4854	.5601	.4668
6	.5601	.6287	.6478	.5975	.4668	.5975	.4854
7	.6161	.6478	.6478	.7095	.5228	.6161	.5041
8	.7095	.6668	.6097	.7842		.5601	.5601
9	.7468	.5906	.743	.8402	.5415	.5041	.5788
10	8.7068	.9717	.8573	1.0098		.9907	1.0669
11	1.1241	1.7337	1.1812	1.5051		.9526	.9717
12	1.1431	1.1812	1.5813	1.7718		.9717	1.2765
13	1.0669	.7621	1.2765	.8383		1.0098	1.1622
14	1.5242	1.5623	1.2003	1.086		1.1431	1.0669
15	1.6194	1.0098	1.2003	1.0669		1.2574	1.105
16	1.6385	1.1812	1.5242	1.3146		1.1812	1.3146
17	.8764	.9709	1.4003	1.2574		1.2955	1.2955
18	1.2003	.7655	1.0829	1.2955		1.2955	1.1431
19	1.105	.7282	.8589		.5144	1.3336	.9526
20	.9907	.6535	.7095	.6097	.5716	1.2384	.9526
21	.8573	.5228	.4481	.5716	.5716	.4954	.8383
22	.5906	.5228	.5228	.5144	.5335	.5335	.7621
23	.6097	.5716	.5041	.5228	.5228	.5228	.6908
24	.5975	.6097	.5906	.5228	.5415	.5228	.5415
Max	8.7068	1.7337	1.5813	1.7718	.5716	1.3336	1.3146
Min	.5228	.5228	.4481	.4668	.4668	.4854	.4668
Avg	1.2096	.8141	.8653	.8408	.5235	.8150	.8222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 206 / Gainmax

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	1.6194	1.6004	.8589	.9709	.5788	.9709
2	.5601	1.5813	1.6194	.9335	.9522	.5601	.9522
3	.5788	1.4861	1.5813	.9522	.9335	.5415	.9335
4	.5975	1.3336	1.2384	.9335	.9149	.5415	.8962
5	.6161	1.2765	.724	.8962	.8962	.5228	.8775
6	.6535	1.4098	.9145	1.0269	.8775	.5601	.9335
7	.6722	1.467	1.0098	1.0082	.9149	.5788	.9522
8	.7468	.724	.6097	1.4937		1.4563	1.5123
9	.7655	1.2574	1.0479	1.6244	.5228	1.587	1.6991
10	.8383	1.2384	1.1241	1.7718		1.6956	1.1812
11	1.3336	1.6575	1.0669	1.7147		1.6575	1.7909
12	1.3336	1.7718		1.7147		1.6956	1.6575
13	1.1812	1.5813	1.3336	1.105		1.3908	1.4289
14	1.5242	1.7528	1.6766	1.2384		1.2193	1.2003
15	1.6004	1.6575	1.7147	1.7528		1.3908	1.6575
16	1.6004	1.2574	1.1622	1.086		.9335	1.1431
17	1.6194	1.1576	1.1576	1.105		.9907	1.1431
18	1.5432	1.1203	1.1763	1.105		.9907	1.105
19	1.5051	1.0642	1.1389	.9717	.5716	1.086	1.0479
20	1.1241	.9709	.9522	.8954	.6478	.9526	.9907
21	.8383	.9522	.6348	.9145	.6287	.9335	.9907
22	.6859	1.0269	.8215	1.0098	.6097	.9335	.9907
23	1.0288	1.2003	.8029	1.0082	.5975	.9149	.5975
24	.5228	1.0288	1.2955	.8402	1.0269	.5788	.9522
Max	1.6194	1.7718	1.7147	1.7718	1.0269	1.6956	1.7909
Min	.5228	.724	.6097	.8402	.5228	.5228	.5975
Avg	.9997	1.3164	1.1480	1.1650	.7904	1.0121	1.1502

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 411 / 33 KV I/C DBLOCK

Feeder KV- 33 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.0329	6.1157	6.2872	4.201	4.6491	3.6408	4.257
2	4.0889	6.0585	6.23	4.257	4.5931	3.5288	1.1946
3	4.0889	5.7156	6.0585	4.313	4.5931	3.4728	4.0329
4	3.9209	5.0297	5.0297	4.257	4.481	3.4168	3.8552
5	4.0889	4.6868	3.9438	4.425	4.425	3.4168	3.8146
6	4.0889	4.6868	4.2295	4.5931	4.369	3.5848	4.0295
7	4.201	4.8011	4.3439	4.6491	4.313	3.6408	4.137
8	4.537	4.2867	4.0009	5.3772		4.5931	5.0972
9	4.6491	4.9154	4.5153	5.6013	3.4728	4.8171	5.6013
10	5.144	5.8299	5.0297	6.9159		5.6013	5.9442
11	4.9726	7.6589	6.8587	7.6017		6.1157	6.8016
12	5.8299	5.9442	5.7728	7.2017		6.5729	6.0014
13	5.7156	6.0014	5.7728	5.6584		6.6301	5.8871
14	6.973	6.7444	6.6873	5.5441		6.3443	5.8871
15	7.2588	6.8016	7.1445	6.7444		7.0302	6.5158
16	7.2588	6.4015	6.8587	6.4015		6.2872	6.0585
17	5.8871	6.0494	6.4415	6.0585		6.0014	6.0014
18	6.1157	5.2092	5.3772	5.8299		6.0014	5.8871
19	5.8299	4.9851	4.6491	4.9726	3.0293	5.7728	5.0869
20	5.2012	4.6491	4.201	4.1724	3.4865	5.2012	4.8583
21	4.6868	4.0329	3.4168	4.0009	3.4294	4.0581	4.6868
22	4.3439	4.201	3.8089	4.401	3.4865	3.658	4.4582
23	4.8011	4.9726	4.0329	4.369	3.4728	3.8649	4.9851
24	4.0329	5.144	5.3727	4.257	4.7051	3.5288	4.0889
Max	7.2588	7.6589	7.1445	7.6017	4.7051	7.0302	6.8016
Min	3.9209	4.0329	3.4168	4.0009	3.0293	3.4168	1.1946
Avg	5.0728	5.4551	5.2526	5.2418	4.0361	4.8658	4.9653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 204 / INDIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5041	.5041	.4854	.4481	.4481	.5601	.4668
2	.5041	.5041	.4481	.4108	.4108	.5228	.4294
3	.4481	.4481	.4108	.3734	.4108	.5228	.4108
4	.4481	.4481	.4108	.3547	.3734	.4854	.3734
5	.4481	.4481	.4108	.3734	.3734	.4854	.3734
6	.4481	.4481	.4481	.3734	.4108	.4481	.3921
7	.4668	.4668	.4854	.4108	.4854	.4481	.4481
8	.4668	.4668	.4854	.4481	.5601	.5041	.5415
9	.5788	.5601	.5975	.5041	.5415	.4854	.5788
10	.6161	.6161	.6161	.7095		.5601	.6535
11	.7095	.7468	.7842	.7095		.7842	.7282
12	.7095	.8215	.8402	.7468		.8589	.7842
13	.8029	.8029	.9149	.7468		.8962	.7842
14	.7468	.7842	.8775	.7468		.8029	.7842
15	.7842	.7468	.8215	.6535		.8402	.8215
16	.8029	.7842		.5975	.8962	.8589	.7842
17	.7282		.8029	.5975	.8775	.8402	.7468
18	.8402	.7655	.8215	.6161	.9149	.8402	.7468
19	.8402	.9335	.8962	.7095	.9709	.8962	.9335
20	.8402	.8402		.6535	.9149	.8962	.8962
21	.7655	.7282	.7842	.5601	.7468	.7842	.7468
22	.7468	.6535	.6161	.5975	.6348	.5975	.5975
23	.5788	.5975	.5228	.5228	.5601	.5415	.5601
24	.5601	.5601	.5601	.4854	.4854	.5601	.5041
Max	.8402	.9335	.9149	.7468	.9709	.8962	.9335
Min	.4481	.4481	.4108	.3547	.3734	.4481	.3734
Avg	.6410	.6381	.6382	.5562	.6120	.6675	.6286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 205 / GANESH TAIKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7392	.7468	.7762	.7023	.7023	.7207	.6653
2	.7023	.7468	.7392	.6653	.6653	.7023	.6283
3	.6653	.7468	.6653	.6468	.6283	.6722	.5914
4	.6653	.7392	.6653	.6468	.5914	.6653	.5914
5	.6653	.7095	.6653	.7207	.6099	.6283	.6283
6	.7023	.8215	.7392	.6838	.7023	.6653	.6283
7	.7392	.8501	.7947	.7392	.8316	.7762	.7392
8	.8501	.924	.8871	.7762	.8871	.8316	.7762
9	.8871	.961	.924	.8871	.924	.924	.8501
10		1.0164	.961	.924	.924	.924	.924
11		1.1643	1.0719	.961	.9979	1.1088	.961
12	1.0719	1.2936	1.2012	.924	1.0719	1.2012	1.1827
13	.7392	1.2012	1.2567	.924	.5175	1.1458	1.1827
14	.6468	1.1643	1.1827	.924	.4805	1.1088	.0168
15	.5914	1.1088	1.1458	.8871	.4805	1.1088	1.1458
16	.5544	1.1273	1.1458	.8871	1.2197	1.1088	1.1088
17			1.0719	.8871	1.2197	1.1088	1.1458
18	1.6804	1.2012	1.1458	.961	1.307	1.2012	1.1458
19	1.6804	1.4415	1.4045	1.0349	1.4563	1.4415	1.423
20	1.6617	1.4045	1.4415	1.0349	1.4003	1.4045	1.386
21	1.4784	1.2012	1.2197	.961	1.307	1.2567	1.1458
22	1.1088	.961	.924	.9055	.9709	.8871	.924
23	.961	.924	.8131	.8316	.924	.7762	.8686
24	.7947	.8402	.8316	.7392	.7392	.7762	.7392
Max	1.6804	1.4415	1.4415	1.0349	1.4563	1.4415	1.423
Min	.5544	.7095	.6653	.6468	.4805	.6283	.0168
Avg	.9326	1.0128	.9864	.8439	.8983	.9643	.8916



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 206 / 11 KV Industrial

GANDHINAGAR Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2858	.2477	.2286	.0191	.1905
2	.1905	.1905	.2667	.2477	.2096	.0191	.1905
3	.1905	.1905	.2667	.2286	.1905	.0191	.1905
4	.1905	.1905	.2286	.2286	.1905	.0191	.1905
5	.1905	.2286	.2286	.2477	.1905	.0191	.2096
6	.1905	.2286	.2286	.2286	.2096	.0191	.2286
7	.2096	.1905	.2286	.2477	.2096	.0191	.2286
8	.1905	.2286	.2667	.2667	.1524	.0191	.2667
9	.2096	.2286	.2667	.3048	.0381	.1334	.2667
10	.3239	.2667	.2858	.3429	.0953	.2096	.3429
11	.3239	.3048	.362	.362	.1143	.2667	.4191
12	.4001	.4001	.4191	.362	.1524	.381	.3048
13	.2858	.4001	.4001	.2858	.1524	.381	.3239
14	.2858	.381	.3429	.3429	.1143	.3429	.3239
15	.3429	.381	.3239	.3239	.2286	.3429	.3429
16	.2858	.362	.362	.3239		.381	.381
17	.362		.4001	.3048	.3048	.3429	.4001
18	.362	.381	.4001	.2858	.1524	.362	.381
19	.362	.3429	.362	.2858	.1524	.362	.4191
20	.3239	.3239	.362	.2858	.1524	.3429	.381
21	.3239	.2858	.2858	.2286	.1524	.2858	.3048
22	.3239	.2858	.2286	.1905	.0762	.3048	.2477
23	.2286	.3048	.2286	.2477	.0762	.2858	.2477
24	.2286	.2286	.3048	.2858	.2286	.0381	.2096
Max	.4001	.4001	.4191	.362	.3048	.381	.4191
Min	.1905	.1905	.2286	.1905	.0381	.0191	.1905
Avg	.2731	.2849	.3056	.2794	.1640	.2048	.2913

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 401 / 33KV Gandhinagar I/C

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	2.4646	2.4434	2.2068	1.7541	1.5123	1.6804
2	1.7364	2.3525	2.2805	2.0936	1.6409	1.5684	1.5684
3	1.6409	2.2965	2.1948	1.9605	1.4403	1.5684	1.5278
4	1.5844	2.2965	2.1068	1.9605	1.4712	1.5123	1.5278
5	1.6409	2.2731	2.0513	2.1502	1.5278	1.5123	1.6409
6	1.8107	2.5766	2.2731	2.1845	1.8107	1.5123	1.7364
7	1.9805	2.6326	2.4394	2.3525	2.0936	1.7924	1.9605
8	3.095	2.384	2.2405	2.0165	2.8475	1.8484	3.1927
9	3.1893	2.3525	2.3525	2.2405	3.0087	3.3048	3.4168
10	2.3388	2.3525	2.3525	2.5206		3.3488	3.5665
11	2.4983	2.7446	2.6886	2.5206		3.8683	3.8409
12	3.5082	3.0807	2.9687	2.5206		3.922	3.9209
13	3.1893	2.8829	3.0807	2.4086		3.774	3.9209
14	2.8704	2.8006	2.9127	2.4646		3.5997	3.9209
15	2.9235	2.7446	2.8006	2.2965	1.5123	3.5837	3.7311
16	2.0199	2.8006	2.8006	2.2405	2.8006	2.9127	2.7721
17	1.5912		2.8006	2.2731	2.7446	2.8567	2.7166
18	3.6214	2.9687	2.9127	2.3525	2.8006	2.8567	2.8567
19	3.77	3.4728	3.3608	4.145	3.1367	3.4168	3.5288
20	3.4928	3.2487	2.4646	2.6612	3.0247	3.3608	3.4168
21	3.2487	2.8567	2.9127	2.4086	2.5206	2.9687	2.8567
22	3.3608	2.9864	2.8006	2.2177	2.2405	2.4086	2.4646
23	2.9127	2.7692	2.5206	2.0513	2.0725	2.0725	2.1845
24	2.0725	2.6886	2.6063	2.3525	1.8673	1.7364	1.8484
Max	3.77	3.4728	3.3608	4.145	3.1367	3.922	3.9209
Min	1.5844	2.2731	2.0513	1.9605	1.4403	1.5123	1.5278
Avg	2.5810	2.6968	2.5986	2.3583	2.2271	2.6174	2.7416

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 201 / 11KV SARALASHKAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.7621	.7621	.8573	.7621	.6668	.7621
2	.7621	.7621	.7621	.7621	.8573	.7621	.6668
3	.8573	.6668	.7621	.7621	.7621	.7621	.7621
4	.8573	.7621	.7621	.7621	.7621	.7621	.6668
5	.8573	.6668	.7621	.7621	.8573	.7621	.7621
6	.7621	.7621	.7621	.8573	.7621	.7621	.7621
7	.7621	.7621	.7621	.7621	.7621	.7621	.7621
8	.8573	1.2384	1.0479	1.0479	.7621	.9526	.9526
9	1.1431	1.1431	1.2384				1.4289
10	1.4289	1.2384	1.5242	1.2384		.9526	1.4289
11	1.4289	1.3336	1.4289	1.3336		1.5242	1.5242
12	1.3336	1.3336	1.8099	1.3336		1.6194	1.5242
13	1.2384	1.2384	1.2384	1.5242		1.5242	1.5242
14	1.1431	1.7147	1.8099	1.5242		1.4289	1.6194
15	.9526	1.7147	1.9052	1.6194		1.5242	1.2384
16	.9526	1.2384	1.9052	1.3336		1.6194	1.4289
17	.9526	1.3336	1.6194	1.5242		1.2384	1.3336
18	1.5242	1.4289	1.6194	1.4289		.9526	1.3336
19	1.3336	1.3336	1.5242	1.0479	.6668	.9526	1.3336
20	1.1431	1.2384	1.3336	.9526	.7621	1.0479	1.1431
21	1.0479	1.0479	.9526		.6668	.9526	1.1431
22	.7621	.9526	1.0479	1.1431	.6668	.9526	.9526
23	.7621	.7621	.9526	.9526	.6668	.8573	.8573
24	.7621	.7621	.7621	.7621	.7621	.5716	.7621
Max	1.5242	1.7147	1.9052	1.6194	.8573	1.6194	1.6194
Min	.7621	.6668	.7621	.7621	.6668	.5716	.6668
Avg	1.0161	1.0915	1.2106	1.1042	.7485	1.0396	1.1114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 202 / 11 KV MAULI FEEDER MIDC SHEDDABLE FEEDER HAVING WEEKLY  
 Shirol Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.7621	.7621	.8573	.8573	.7621
2	.7621	.7621	.7621	.7621	.7621	.8573	.7621
3	.7621	.7621	.7621	.8573	.7621	.8573	.8573
4	.7621	.7621	.7621	.8573	.8573	.8573	.7621
5	.7621	.7621	.7621	.8573	.8573	.8573	.8573
6	.7621	.8573	.7621	.7621	.8573	.8573	.8573
7	.8573	.8573	.8573	.8573	.8573	.8573	.9526
8	.8573	.8573	.8573	.8573	.8573	.8573	.9526
9	.9526	.8573	.9526				1.0479
10	1.1431	.8573	1.0479	.8573		1.0479	1.0479
11	1.1431	1.1431	1.1431	.9526		1.1431	.9526
12	.9526	1.1431	.9526	.9526		.9526	.9526
13	.9526	1.0479	.9526	.9526		.9526	.9526
14	.9526	1.1431	1.1431	.8573		1.1431	1.1431
15	1.0479	1.1431	1.1431	1.0479		1.1431	1.1431
16	.9526	1.1431	1.0479	.9526		1.0479	1.1431
17	.9526	.9526	.9526	1.0479		.9526	1.0479
18	.8573	.8573	.9526	.7621		.8573	.9526
19	.9526	.8573	.8573	.7621	.8573	.8573	.9526
20	.9526	.9526	.8573	.7621	.8573	.8573	.9526
21	.7621	1.1431	.8573	.9526	.8573	.8573	.9526
22	.7621	.9526	.8573	.8573	.8573	.8573	.9526
23	.7621	.7621	.8573	.8573	.8573	.7621	.8573
24	.8573	.8573	.7621	.8573	.8573	.8573	.8573
Max	1.1431	1.1431	1.1431	1.0479	.8573	1.1431	1.1431
Min	.7621	.7621	.7621	.7621	.7621	.7621	.7621
Avg	.8891	.9288	.9010	.8698	.8437	.9194	.9447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 203 / G' BLOCK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.3336	1.3336	1.4289	1.4289	1.3336	1.3336
2	1.2384	1.2384	1.4289	1.4289	1.4289	1.3336	1.3336
3	1.2384	1.2384	1.4289	1.3336	1.3336	.1905	1.2384
4	1.3336	1.3336	1.3336	1.4289	1.4289	1.3336	1.2384
5	1.3336	1.3336	1.3336	1.3336	1.3336	1.3336	1.3336
6	1.5242	1.5242	1.4289	1.4289	1.3336	1.4289	1.3336
7	1.3336	1.3336	1.4289	1.4289	1.3336	1.5242	1.3336
8	1.6194	1.6194	1.5242	1.4289	1.3336	1.5242	1.5242
9	1.9052	1.7147	1.9052				1.8099
10	2.2862	1.9052	2.0957	1.8099		2.2862	1.9052
11	2.191	2.0957		1.9052		2.2862	2.0957
12	1.9052	2.2862	2.0005	1.9052		1.8099	1.9052
13	1.5242	1.8099		1.8099		1.5242	1.8099
14	1.8099	2.4768	2.0005	2.0957		2.0957	2.0957
15	2.191	2.2862	2.191	2.2862		2.0005	2.2862
16	2.191	2.0957	1.9052	2.0005		2.0957	1.8099
17	2.0957	1.9052	2.0957	2.0957		1.9052	2.0957
18	1.6194	1.9052	1.9052	1.9052		1.7147	1.5242
19	1.9052	1.7147	1.5242	1.5242		1.5242	1.6194
20	2.0005	1.6194	1.4289	1.5242	.8573	1.5242	1.3336
21	1.7147	1.4289	1.3336	1.3336	1.3336	1.3336	1.3336
22	1.3336	1.4289	1.3336	1.3336	1.3336	1.3336	1.3336
23	1.5242	1.4289	1.3336		1.3336	1.3336	1.3336
24	1.3336	1.5242	1.4289	1.3336	1.3336	1.3336	1.5242
Max	2.2862	2.4768	2.191	2.2862	1.4289	2.2862	2.2862
Min	1.2384	1.2384	1.3336	1.3336	.8573	.1905	1.2384
Avg	1.6829	1.6909	1.6237	1.6411	1.3190	1.5697	1.6035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV Maharashtra Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.9526	.9526	.9526	.4763	.8573
2	.9526	.9526	.9526	.9526	.9526	.4763	.8573
3	.8573	.8573	.9526	.8573	.8573	.4763	.7621
4	.8573	.8573	.9526	.6668	.7621	.4763	.7621
5	.8573	.8573	.9526	.8573	.8573	.4763	.7621
6	.9526	.9526	.9526	.9526	.8573	.4763	.8573
7	.9526	.9526	.9526	1.0479	.9526	.4763	.7621
8	.9526	.9526	.9526	.8573	.5716	.5716	.7621
9	.8573	1.0479	.8573				.8573
10	.7621	1.0479	.8573	.9526		.8573	.8573
11	.6668	.9526	.5716	.8573		.9526	.7621
12	.6668	.8573	.6668	.7621		.8573	.8573
13	.6668	.7621	.5716	.6668		.7621	.7621
14		.8573	.6668	.7621		.8573	.7621
15		.7621	.7621	.7621		.9526	.7621
16	.6668	.7621	.7621	.7621		.9526	.8573
17	.7621	.8573	.6668	.6668		.7621	.8573
18	.8573	.9526	.7621	.6668		.7621	.7621
19	.9526	.9526	.7621	.8573	.381	.7621	.8573
20	.9526	.9526	.9526	.9526	.381	.8573	.8573
21	1.1431	1.0479	1.0479	.9526	.381	.8573	.8573
22	1.0479	1.0479	1.0479	.9526	.381	.7621	.8573
23	.7621	.9526	.9526		.4763	.8573	.7621
24	.9526	.7621	.9526	1.0479	1.0479	.4763	.9526
Max	1.1431	1.0479	1.0479	1.0479	1.0479	.9526	.9526
Min	.6668	.7621	.5716	.6668	.381	.4763	.7621
Avg	.8617	.9089	.8534	.8530	.7008	.7041	.8176

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 206 / DEVAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.4289	1.6194	1.5242	1.6194	.5716	1.2384
2	1.5242	1.5242	1.5242	1.4289	1.5242	.5716	1.2384
3	1.5242	1.5242	1.5242	1.5242	1.5242	.6668	1.1431
4	1.4289	1.4289	1.5242	.7621	1.4289	.6668	1.3336
5	1.4289	1.3336	1.5242		1.3336	.6668	1.2384
6	1.3336	1.4289	1.5242	1.5242	1.5242	.6668	1.3336
7	1.3336	1.6194	1.5242	1.7147	1.7147	.6668	1.3336
8	.8573	1.7147	1.0479	1.7147	.9526	.6668	.8573
9	1.6194	1.1431	1.4289				2.3815
10	2.2862	1.7147	1.6194	2.0957		1.1431	2.0957
11	2.0005	2.0957	1.9052	2.2862		1.4289	2.2862
12	2.0005	2.7625	1.7147	2.0957		1.2384	2.0957
13	2.3815	2.2862	2.0957	2.191		1.3336	1.8099
14	2.2862	2.0957	2.4768	1.8099		2.0957	1.8099
15	2.4768	2.8578	2.2862	1.9052		2.191	1.7147
16	2.4768	2.3815	2.0005	2.0957		2.0957	2.2862
17	2.2862	2.191	2.0957	2.0957		1.3336	1.8099
18	1.5242	1.8099	1.9052	1.4289		1.0479	1.6194
19	1.2384	1.7147	1.7147	1.5242	.5716	.9526	1.5242
20	1.3336	1.8099	1.7147	1.5242	.6668	1.3336	1.6194
21	1.2384	1.9052	1.2384	1.3336	.6668	.8573	1.6194
22	1.3336	1.8099	1.3336	1.1431	.6668	.8573	1.5242
23	1.3336	1.7147	1.5242	1.4289	.6668	.8573	1.6194
24	1.5242	1.5242	1.5242	1.6194	1.7147	.5716	1.1431
Max	2.4768	2.8578	2.4768	2.2862	1.7147	2.191	2.3815
Min	.8573	1.1431	1.0479	.7621	.5716	.5716	.8573
Avg	1.6750	1.8258	1.6829	1.6714	1.1840	1.0644	1.6115

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 22-FEB-18 and 28-FEB-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 401 / 33KV MIDC SHIROLI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	22-FEB-18	23-FEB-18	24-FEB-18	25-FEB-18	26-FEB-18	27-FEB-18	28-FEB-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.144	5.2584	5.4298	5.5441	5.6013	3.8866	4.9154
2	5.2584	5.2584	5.3155	5.3155	5.5441	4.1152	4.8583
3	5.144	5.0297	5.4298	5.3155	5.2584	2.9721	4.7439
4	5.2584	5.144	5.3155	4.4582	5.2584	4.1152	4.7439
5	5.2584	4.9726	5.3155	5.144	5.2584	4.1152	4.9726
6	5.3155	5.5441	5.4298	5.5441	5.3155	4.1724	5.144
7	5.2584	5.5441	5.5441	5.8299	5.6013	4.2867	5.144
8	5.144	6.4015	5.3155	5.8871	4.4582	4.5725	5.0297
9	6.4586	5.8871	6.4015				7.5446
10	7.8875	6.7444	7.316	6.973		6.2872	7.316
11	7.4303	7.6017	7.7161	7.316		7.316	7.6017
12	6.8587	8.4019	7.1445	7.0302		6.4586	7.316
13	6.7444	7.1445	6.5729	7.1445		6.1157	6.8587
14	6.8587	8.2876	8.1162	7.0302		7.6017	7.4303
15	7.4303	8.7449	8.2876	7.6017		7.8304	7.1445
16	7.316	7.6017	7.6017	7.1445		7.8304	7.5446
17	7.0302	7.2588	7.4303	7.4303		6.1728	7.1445
18	6.4015	6.973	7.1445	6.1728		5.3155	6.1728
19	6.4015	6.5729	6.4015	5.7156	2.4577	6.1728	6.2872
20	6.4015	6.5729	6.2872	5.7156	3.5437	5.6013	5.8871
21	5.8871	6.5729	5.4298	4.5725	3.8866	4.8583	5.8871
22	5.2584	6.1728	5.6013	5.4298	3.8866	4.9154	5.6013
23	5.144	5.6013	5.6013	5.5441	4.0009	4.6868	5.4298
24	5.4298	5.4298	5.4298	5.6013	5.7156	3.8295	5.2584
Max	7.8875	8.7449	8.2876	7.6017	5.7156	7.8304	7.6017
Min	5.144	4.9726	5.3155	4.4582	2.4577	2.9721	4.7439
Avg	6.1133	6.4467	6.3157	6.0635	4.6991	5.3578	6.0824