

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 201 / 11 KV AJARA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5788	.5658	.5792	.4458	.6036	.6401
2	.4801	.5144	.4287	.5144	.4115	.6036	.6219
3	.4458	.4458	.4458	.4458	.3734	.6036	.567
4	.4287	.4481	.4458	.4481	.3944	.6036	.5853
5	.4801	.5415	.6348	.4458	.4854	.6036	.6219
6	.5609	.6173	.583	.5493	.5144	.6401	.6584
7	.5658	.6722	.6584	.6224	.5853	.695	.695
8	.7316	.6722	.6584	.6516	.5552	.695	.6584
9	.6767	.724	.695	.6859	.5853	.7282	.6516
10	.7682	.7783	.7499	.7202	.6584	.8589	.7716
11	.823	.7964	.8413	.7888	.6219	.8589	.823
12	.8779	.9145	.8413	.7545	.6401	.9335	.8573
13	.8145	.8048	.7202	.7202	.6001	.8589	.7888
14	.7964	.7316	.6687	.6687	.6001	.7888	.7888
15	.7522	.7865	.7373	.8402	.6173	.8775	.823
16	.7421	.7682	.703	.5487		.8962	.823
17	.7522	.7865	.7545	.8059		.9145	.7888
18	.7602	.7865	.7716	.7373	.8745	.7888	.7888
19	.9955	.9511	.9431	.9088	.8573	1.0082	.8573
20	.9593	.9877	.9328	.8916	.8916	.9259	.8745
21	.9145	.8573	.823	.7888	.8779	.9511	.9511
22	.7888	.8573	.7888	.8589	.8413	.9328	.9511
23	.823	.7373	.724	.6722	.7316	.8048	.7865
24	.583	.6722	.6516	.6722	.6036	.6401	.7133
Max	.9955	.9877	.9431	.9088	.8916	1.0082	.9511
Min	.4287	.4458	.4287	.4458	.3734	.6036	.567
Avg	.7098	.7263	.6986	.6800	.6257	.7840	.7536

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 202 / 11 KV Bhadvan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.6644	1.475	1.2308	.1463	.1475	.1638
2	.1543	1.6289	1.3717	1.166	.1372	.1475	.1696
3	.1372	1.4937	1.1203	1.1203	.1646	.1475	.1696
4	.1886	1.2803	1.1694	.9602	.1543	.1475	.1638
5	.1715	1.3321	1.6975	1.3032	.168	.1475	.1638
6	.1886	1.6975	1.749	1.4118	.1543	.1475	.1696
7	.2054	2.0668	1.989	1.5729	.1867	.1966	.1865
8	.1991	2.3525	2.0576	1.9185	.2054	.2103	.1802
9	.2035	2.0919	2.2497	1.6975	.1966	.2401	.2401
10	.1865	1.989	2.0119	.1715	.2035	.2401	.2401
11	2.0668	.2328		.2058	2.0485	2.332	2.5377
12	2.7618	.2035	.2204	.1886	2.1262	2.4177	2.692
13	2.6406	.1802	.1886	.1886	2.1262	2.4006	2.7606
14	2.6235	.2035	.1543	.2229	2.2462	2.3834	2.5549
15	2.572	.1865	.2229	.2229	2.332	2.5034	2.6749
16	2.5377	.1966	.2229	.2572		2.5034	2.7435
17	2.3834	.2035	.2229	.2915		2.6139	2.6063
18	2.3348	.2035	.2229	.2572		2.2805	2.4006
19	.2481	.2035	.2229	.2743	.2058	.2743	.2743
20	.2172	.2035	.1886	.2172	.2229	.2401	.2401
21	.2353	.2058	.1886	.1991	.213	.2458	.213
22	.2058	.2058	.1543	.2054	.213	.213	.2035
23	.2229	.2058	.1372	.168	.1802	.1966	.1865
24	.1715	.2058	.2195	.1372	.1543	.1802	.1802
Max	2.7618	2.3525	2.2497	1.9185	2.332	2.6139	2.7606
Min	.1372	.1802	.1372	.1372	.1372	.1475	.1638
Avg	.9595	.8516	.8460	.6495	.6564	.9399	1.0048

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 203 / POLGAON AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9431	.128	.1372	.1646	1.307	1.1888	1.3169
2	.9945	.1029	.1372	.1372	1.1946	1.1523	1.2803
3	.8573	.1052	.12	.1307	1.0517	1.0974	1.2437
4	.8573	.1052	.1029	.1086	1.0288	1.0974	1.2437
5	1.3032	.1029	.1029	.1402	1.2752	1.1706	1.3169
6	1.406	.128	.1372	.1433	1.3717	1.3112	1.4449
7	1.6644	.128	.1543	.181	1.6651	1.7375	1.829
8	1.9387	.1463	.1646	.1646	1.9022	1.8473	2.0668
9	1.9022	.1267	.1357	.1715	1.9387	1.749	1.749
10	1.8427	.1086	.1311	.1029	.1147	.1029	.1029
11	.0164	2.2885	2.4874	2.3148	.0848	.1029	.0686
12	.0339	2.6703	2.6337	2.3663	.0848	.0686	.0857
13	.0362	2.7252	2.4348	2.4006	.0857	.0686	.0732
14	.0362	2.4691	2.3148	2.2634	.0857	.0747	.0686
15	.0905	2.6337	2.2977	2.2634	.0686	.1029	.0686
16	.1086	2.6886	2.4348	2.3491		.0732	.1097
17	.0905	2.396	2.3663	2.2805		.0732	.0857
18	.1086	2.3045	2.1434	2.0405	.0686	.0914	.1097
19	.1629	.1638	.2058	.1886	.1715	.181	.1646
20	.1629	.1696	.2195	.1886	.2058	.2012	.1829
21	.1646	.168	.1886	.1886	.1802	.1966	.1802
22	.1646	.1646	.181	.1829	.1802	.1802	.1696
23	.128	.1463	.1646	.1646	.2012	.1696	.1696
24	.0914	.128	.1463	.1646	1.39	1.1523	1.3535
Max	1.9387	2.7252	2.6337	2.4006	1.9387	1.8473	2.0668
Min	.0164	.1029	.1029	.1029	.0686	.0686	.0686
Avg	.6294	.9291	.8976	.8667	.7117	.6330	.6868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 204 / 11 KV Watangi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717		.3772	.3944	1.3717	1.701	1.6461
2	1.4575		.3429	.3429	1.3032	1.6461	1.5729
3	1.4266		.4458	.2743	1.0288	1.6095	1.5729
4	1.4632		.2058	.3361	1.2136	1.6095	1.5546
5	1.7558		.2058	.3921	1.7924	1.7193	1.6461
6	1.7661			.4163	1.749	1.957	1.7558
7	1.8054	.4108	.4115	.4115	1.8519	2.1582	1.9204
8	1.9204	.4108	.3772	.4481	2.2032	2.2131	2.0485
9	1.9313	.3841	.3601	.3944	2.1216	1.9719	1.749
10	1.9204	.3982	.4024	.3944	.4207	.3944	.3429
11	.3475	1.9204	2.1216	2.1091	.4207	.4108	.3086
12	.3475	2.2497	2.1765	2.0919	.3658	.4024	.2915
13	.2715	2.3594	2.0919	2.0748	.3086		.3361
14	.2353	2.3228	2.0405	2.0576	.3086		.3086
15	.2715	2.3228	2.0233	2.0576	.2915		.2987
16	.3077	2.3045	2.0062	2.0576			.3086
17	.3982	2.1765	1.9547	2.0233			.3361
18	.4075	2.1033	1.9033	1.9376	.3429		.3361
19	.3721	.4207	.3944	.3921	.4115	.463	.3429
20	.4163	.4252	.4287	.4108		.463	.3429
21	.4108	.4458	.3772	.3944		.4572	.4024
22	.3772	.4755	.4108	.3944		.4207	.3475
23	.3841	.4294	.3944	.3856	.3898	.3856	.3658
24	.3429	.3429	.4108	.3944	1.6617	1.7375	1.6827
Max	1.9313	2.3594	2.1765	2.1091	2.2032	2.2131	2.0485
Min	.2353	.3429	.2058	.2743	.2915	.3856	.2915
Avg	.9045	1.2168	.9506	.9411	1.0293	1.2067	.9091



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 205 / 11 KV WATANGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3086	.1886	.3086	.3086	.3475	.4024
2	.3086	.2743	.1867	.2743	.2743	.3475	.4024
3	.2743	.2987	.1715	.2401	.3258	.3292	.4024
4	.3429	.3258	.1715	.2987	.3086	.3292	.4024
5	.3856	.4024	.2401	.4908	.3601	.3841	.4024
6	.439	.4344	.2743	.4251	.4481	.4207	.439
7	.4973	.4287	.3601	.4525	.4572	.5853	.5121
8	.4733	.5228	.4287	.5144	.4115	.567	.5304
9	.5487	.5792	.5487	.6001	.4938	.5601	.5316
10	.567	.5792	.5853	.5316	.4938	.5487	.5316
11	.4755	.4525	.4572	.4801	.439	.5487	.5144
12	.4572	.439	.4755	.4458	.4024	.5144	.463
13	.4344	.4207	.4458	.4458	.3772	.4458	.3944
14	.4163	.4024	.3601	.4115	.3772	.3944	.9774
15	.4887	.3841	.3772	.463	.3601	.4287	.4294
16	.5068	.3841	.463	.4458		.5144	.4854
17	.4706	.3841	.5144	.4801		.4973	.463
18	.5552	.4938	.5487	.5144	.4973	.6908	.4287
19	.8326	.6767	.7888	.7202	.6173	.7373	.7545
20	.8869	.8779	.7888	.8573	.8916	.8573	.8745
21	.7202	.703	.7373	.7202	.8413	.823	.7499
22	.5658	.6535	.583	.5975	.6767	.6584	.6219
23	.4458	.4854	.4572	.4481	.4938	.4938	.4755
24	.3681	.3429		.3601	.3429	.4024	.439
Max	.8869	.8779	.7888	.8573	.8916	.8573	.9774
Min	.2743	.2743	.1715	.2401	.2743	.3292	.3944
Avg	.4918	.4689	.4414	.4803	.4636	.5178	.5262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 206 / 11 KV MIDC feeder

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0514	.0514	.0514	.0373	.0328	.0509
2	.0514	.0514	.0514	.0514	.0351	.0328	.0509
3	.0514	.0343	.0343	.0514	.0343	.0328	.0509
4	.0514	.0351	.0343	.0514	.0366	.0328	.0492
5	.0526	.0373	.0514	.0514	.0343	.0328	.0492
6	.0514	.0343	.0526	.0526	.0373	.0492	.0678
7	.0514	.0343	.0549	.0514	.0351	.0492	.0509
8	.0514	.0373	.0514	.0373	.0351	.0328	.0339
9	.0655	.0549	.0509	.0514	.0328	.0373	.0514
10	.1029	.0732	.0655	.0857	.0339	.0343	.0857
11	.1187	.0724	.0848	.12	.0492	.0343	.0514
12	.1187	.1017	.0678	.0686	.0509	.0857	.0514
13	.0905	.1372	.0686	.0514	.0514	.1097	.1097
14	.0905	.1372	.0686	.0857	.0514	.128	.1029
15	.0905	.0857	.0514	.0857	.0514	.0857	.0686
16	.1086	.0848	.0686	.0857		.1029	.0686
17	.0724	.0678	.0514	.1029		.056	.0514
18	.0732	.0678	.0514	.0686	.0343		.0686
19	.0549	.0514	.0514	.0514	.0343	.0686	.0686
20	.0543	.0732	.0514	.0514	.0343	.0686	.0514
21	.0543	.0514	.0514	.0514	.0509	.0678	.0678
22	.056	.056	.0549	.0343	.0509	.0848	.0678
23	.0343		.0514	.0373	.0328	.0678	.0678
24	.0516	.0514	.0514	.0514	.0373	.0509	.0509
Max	.1187	.1372	.0848	.12	.0514	.128	.1097
Min	.0343	.0343	.0343	.0343	.0328	.0328	.0339
Avg	.0687	.0644	.0551	.0617	.0400	.0599	.0620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 207 / 11 KV Bhadvan Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.2743	.2915	.2587	.2401	.2926	.3292
2	.3292	.2572	.2743	.2058	.2743	.2896	.3292
3	.3258	.2401	.2572	.2229	.2804	.2743	.3292
4	.3086	.2058	.2614	.2401	.2987	.2743	.3292
5	.3258	.2743	.3361	.2743	.2743	.2926	.3292
6	.3258	.3429	.3658	.3174	.2743	.3292	.3475
7	.2926	.3658	.3841	.3086	.2561	.4024	.3841
8	.3601	.3856	.3801	.3881	.2896	.4207	.4207
9	.3898	.4344	.3841	.4115	.2926	.3601	.3429
10	.4024	.3982	.3841	.4115	.2926	.3944	.3429
11	.4572	.3224	.362	.3772	.2279	.3944	.3429
12	.5121	.3292	.3658	.3429	.2378	.3601	.3601
13	.3258	.3475	.3429	.3258	.2229	.3429	.3696
14	.3258	.3475	.3086	.3086	.2229	.3601	.2743
15	.3439	.2926	.3258	.3086	.2401	.3086	.2987
16	.362	.3475	.2915	.2743		.3086	.2743
17	.3366	.3292	.3086			.3258	.2743
18	.3982	.4024	.3258	.3258	.3258	.4207	.3086
19	.5611	.5487	.583	.5144	.4973	.5144	.4801
20	.724	.7316	.7282	.7655	.703	.7682	.6516
21	.6154	.5658	.5853	.6161	.6219	.6401	.6036
22	.463	.5304	.463	.439	.5304	.5487	.5487
23	.3658	.4024	.3086	.2743	.3841	.439	.3841
24	.3292	.2743	.3086	.2804	.2534	.3292	.3475
Max	.724	.7316	.7282	.7655	.703	.7682	.6516
Min	.2743	.2058	.2572	.2058	.2229	.2743	.2743
Avg	.3939	.3729	.3719	.3562	.3291	.3913	.3751

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022] BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 405 / 33 KV Amboli

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.6224
Max	.6224
Min	.6224
Avg	.6224

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144063 / 33/11 KV AJARA

Feeder No / Name : 406 / 33 KV CHITRI FEEDER Gen  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.0566
Max	.0566
Min	.0566
Avg	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 201 / 11KV UtturVg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7164	.7023	.5975	.7095	.7023	.7842	.7468
2	.6805	.6653	.5975	.6722	.6283	.7468	.6908
3	.6805	.6653	.5601	.5975	.5914	.7023	.6348
4	.6447	.6653	.5601	.5975	.5914	.6348	.7095
5	.6447	.7392	.6722	.6722	.6653	.6722	.7655
6	.7164	.7762	.7842	.8215	.8131	.8316	.8029
7	.7164	.8871	.8402	.8775	.8131	.9709	.9149
8	.7522	.961	.8589	.8962	.8131	.9709	.9335
9	.8596	.8501	.8402	.8589	.8131	.8589	.8962
10	.7522	.8962	.8775	.8962	.8131	.7842	.8589
11	.7762	.8589	.7655	.924	.8402	.8962	.8775
12	.961	.8215	.8215		.8962	.8029	.9335
13		.8589	.7842	.8501	.8589	.8402	.9335
14	.924	.8589	.8871	.8131	.8215	.8589	.9149
15	.924	.8029	.9149	.7762	.7468	.8589	.6722
16	.7023	.7842	.8775	.7762	.7468	.8402	.924
17	.7392	.8402	.8215	.8131	.7468	.8775	1.0829
18	.8131	.8962	.8589	.924	.8589	.8962	.8402
19	1.1458	1.1576	1.1827	1.2936	1.1016	1.1203	1.1389
20	1.3676	1.4563	1.4003	1.386	1.4045	1.3443	1.3817
21	1.2012	1.1949	1.2323	1.2197	1.2696	1.2696	1.1949
22	1.1088	1.1203	1.0456	1.1458	1.1949	1.1203	1.0719
23	.8501	.9522	.8215	.8131	.8962	.9522	.8775
24	.788	.7392	.6348	.7468	.7392	.8029	.7842
Max	1.3676	1.4563	1.4003	1.386	1.4045	1.3443	1.3817
Min	.6447	.6653	.5601	.5975	.5914	.6348	.6348
Avg	.8463	.8813	.8432	.8731	.8486	.8932	.8992

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 202 / 11KV Bahirewadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5506	.048	.0503	.0474	.4801	.5155	.7095
2	.583	.032	.0503	.0316	.4961	.5093	.6535
3	.583	.032	.0503	.0316	.4961	.506	.5975
4	.6154	.048	.0503	.0312	.5121	.506	.7282
5	.7449	.048	.0503	.0312	.5441	.5556	
6	.9393	.048	.0503	.0633	.6882	.8025	.9709
7	1.2631	.064	.056	.0625	1.1203	1.2186	1.4937
8	1.4575	.08	.0671	.0791	1.3123	1.5893	1.6617
9	1.4251	.08	.0838	.0791	1.2003	1.4685	1.5592
10	1.0364	.0838	.0671	.0949	.064	.0671	.0671
11	.064	1.1233	1.2809	1.4563	.0791	.0671	.0633
12	.064	.8551	1.4074		.0791	.0671	.0633
13		1.6057	1.3125	1.4403	.0791	.0671	.0474
14	.064	1.3916	1.2498	1.3283	.08	.0671	.0316
15	.048	1.3916	1.2334	1.3443	.0474	.0335	.0316
16	.064	1.5257	1.4232	1.4723	.0492	.0671	.0633
17	.048	1.7101	1.4198	1.4883	.0633	.0838	.0791
18	.096	1.7364	1.3599	1.3763	.0949	.0838	.08
19	.064	.0671	.08	.048	.0949	.1006	.0791
20	.064	.0671	.0633	.064	.08	.0838	.0781
21	.048	.0671	.0474	.048	.0474	.0686	.0633
22	.048	.0503	.0474	.048	.0474	.0503	.0633
23	.048	.0503	.0474	.048	.0633	.0503	.0791
24	.0648	.048	.0503	.0474	.4801	.5155	.6722
Max	1.4575	1.7364	1.4232	1.4883	1.3123	1.5893	1.6617
Min	.048	.032	.0474	.0312	.0474	.0335	.0316
Avg	.4340	.5106	.4833	.4679	.3458	.3810	.432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144084 / 33/11 KV Uttur

Feeder No / Name : 203 / MAHAGOND AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.7619	.8402	.8669	.0354	.0347	.0177
2	.0179	.7796	.7842	.8573	.0354	.0351	.0177
3	.0181	.7796	.7095	.8669	.0354	.0351	.0177
4	.0181	.7442	.7095	.8383	.0354	.0354	.0177
5	.0179	.7796	.8402	.8573	.0354	.0347	.0187
6	.0181	1.0985	1.0631	.9556	.0354	.0347	.0354
7		1.4529	1.419	1.387	.0354	.0351	.0354
8		1.5592	1.4937	1.6095	.0354	.0347	.0354
9	.0181	1.4175	1.643	1.5927	.0532	.0351	.0354
10	.0181	1.4563	1.382	.0177	.0354	.0354	.0354
11	2.0199	.0177	.0347	.0354	2.3579	2.7633	2.2184
12	2.0553	.0187	.0347		2.3122	2.8753	2.13
13		.0177	.0351	.0354	2.2455	2.4832	2.1293
14	1.7718	.0177	.0173	.0366	2.2969	2.6886	1.7394
15	1.5947	.0177	.0175	.0354	2.4813	2.4272	1.6446
16	1.6301	.0177	.0177	.0354	2.4813	2.6326	1.6842
17	1.6301	.0177	.0177	.0354	2.4646	2.6513	1.7436
18	1.5947	.0177	.0177	.0354	2.3312	2.2405	.5434
19	.0354	.0177	.0354	.0354	.0351	.0354	.0354
20	.0354	.0354	.0316	.0354	.0347	.0354	.0351
21	.0354	.0354	.0351	.0354	.0347	.0354	.0354
22	.0354	.0354	.0354	.0354	.0351	.0354	.0354
23	.0354	.0354	.0351	.0354	.0354	.0177	.0351
24	.0181	.0354	.0354	.0351	.0354	.0347	.0177
Max	2.0553	1.5592	1.643	1.6095	2.4813	2.8753	2.2184
Min	.0179	.0177	.0173	.0177	.0347	.0177	.0177
Avg	.6017	.4653	.4702	.4483	.8147	.8878	.5956



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 201 / 11 KV Kanoli Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.362	.362	.3772	.5068	.4115	.362
2	.3429	.362	.3258	.3467	.5068	.3772	.3292
3	.3429	.362	.3224	.3429	.4706	.3772	.3292
4	.3772	.3258	.3582	.4161	.4706	.3601	.3658
5	.4115	.3258	.439	.4161	.4344	.3944	.4024
6	.4801	.4344	.4344	.4508	.5068	.4458	.439
7	.5144	.543	.543	.3988	.5068	.4801	.5121
8	1.0927	.543	.5487	.5201	.543	.5316	.5853
9	1.1631	.543	.5552	.4334	.5068	.5487	.5611
10	1.0927	.543	.5731	.3814		.5144	.5611
11		.5068	.4508	.4508	.4887	.4801	.5144
12	.543	.4656	.4508	.4887	.4115	.4298	.4854
13	.5068	.4656	.3814	.4706	.4115	.3898	.4115
14	.5068	.4706		.4344	.4115	.3898	
15	.5249	.4477	.4334	.4706	.4115	.3544	
16	.543	.4706		.4706	.4115	.4298	.4458
17	.5068	.4887		.5068	.463	.5201	.4854
18	.6154	.543		.543	.4458	.5552	
19	.7059	.7602	.6241	.6516	.6859	.8059	.7802
20	.7602	.7701	.6935	.8145	.7545	.7602	
21	.6878	.7392	.6241	.724	.6687	.7468	.6935
22	.5973	.5973	.5895	.6335	.583	.6468	.5895
23	.543	.5121	.4801		.4458	.4805	.5201
24	.4115	.4344	.4024	.4508	.5068	.4287	.3982
Max	1.1631	.7701	.6935	.8145	.7545	.8059	.7802
Min	.3429	.3258	.3224	.3429	.4115	.3544	.3292
Avg	.5934	.5007	.4796	.4867	.5023	.4941	.4886

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 202 / 11KV Sarambalwadi Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	1.7147	.8962	.9709	.0724	.0686	.0716
2	.0686	1.7147	.9061	1.0056	.0543	.0686	.0724
3	.0686	1.5432	.9282	1.0288	.0543	.0686	.0724
4	.0686	1.6118	.9374	1.0517	.0543	.0686	.0716
5	.0686	1.6461	.9804	1.1789	.0543	.0686	.0724
6	.0686	1.7013	.9998	1.1789	.0543	.0686	.0716
7	.0686	1.6118	1.1523	.9015	.0543	.0686	.0895
8	.141	1.5432	1.3123	.9015	.0724	.0686	.0716
9	.1057	1.5089	1.3123	.9709	.0724	.0514	
10	.0705	1.5089	1.1523	.0693	.0543	.0514	
11	1.6461	.0724	.0693	.0693	1.7147	1.5242	1.8724
12	1.7147	.0716	.0693	.0724	1.5242	1.6004	1.8031
13	1.7147	.0716	.0693	.0724	1.8519	1.5684	1.8031
14	1.7147	.0716		.0724	1.7071	1.6248	
15	1.7833	.0716	.0693	.0724	1.7071	1.6324	1.8031
16	1.8861	.0716		.0724	1.7071	1.6446	1.8031
17	1.7147	.0716		.0724	1.5851	1.6964	1.8031
18	1.8519	.0724		.0724		1.6004	
19	.0724	.0724	.0686	.0724	.0686	.0716	.0693
20	.0724	.0905	.0693	.0724	.0686	.0716	
21	.0724	.0724	.0693	.0724	.0686	.0924	.104
22	.0724	.0724	.0693	.0724	.0686	.0732	.1029
23	.0724	.0716	.0693		.0686	.0732	.104
24	.0686	.0724	.0716	.0693	.0724	.0686	.0716
Max	1.8861	1.7147	1.3123	1.1789	1.8519	1.6964	1.8724
Min	.0686	.0716	.0686	.0693	.0543	.0514	.0693
Avg	.6356	.7138	.5636	.4432	.5570	.5831	.6280

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144087 / 33/11 Maligre

Feeder No / Name : 203 / 11 kv Kolindre Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4632	.2172	.2561	.2743	2.0576	1.5242	1.5935
2	1.5242	.181	.2561	.2401	2.0576	1.5242	1.6129
3	1.5242	.181	.2743	.2427	1.9909	1.6461	1.6644
4	1.5851	.181	.2743	.2427	1.9909	1.7071	1.6872
5	1.6461	.2172	.2715	.2427	2.1719	1.7071	1.781
6	1.768	.2172	.2896	.2427	2.1719	1.989	1.8343
7	1.8595	.181	.2896	.2774	2.1719	1.829	1.8884
8	4.1343	.181	.2715	.2774	2.1719	1.829	1.9524
9	3.8675	.2172	.2507	.208	1.8861	1.829	
10	3.7342	.181	.2328	.2427	.2172	.2229	
11	.2534	1.8652	1.8176	1.9418	.2534	.2572	.208
12	.1086	1.7284	1.9765	1.9547	.2401	.2686	.208
13	.0905	1.7604	1.9418	2.1948	.2401	.2686	.208
14	.1448	1.8122		3.7723	.2743	.2328	
15	.181	1.8884	1.0402	2.1719	.2743	.2328	.1734
16	.2172	1.8884		1.7147	.2743	.2353	.2427
17	.3258	1.9204		1.7147	.3086	.2686	.2427
18	.2172	1.8564		2.0576	.2401	.2534	
19	.2534	.2507	.2774	.2896		.2686	.2427
20	.2172	.2896		.2534		.2865	
21	.2172	.2926	.2743	.2172	.2743	.2926	.2427
22	.2172	.2743	.2774		.2915	.2534	.2058
23	.181	.2896	.2774		.2572	.2561	.208
24	.2572	.2172	.2865	.2774	1.7147	1.3717	1.5684
Max	4.1343	1.9204	1.9765	3.7723	2.1719	1.989	1.9524
Min	.0905	.181	.2328	.208	.2172	.2229	.1734
Avg	1.0828	.7620	.5703	.9569	1.0696	.8564	.9350

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 201 / 11 KV Devarde Vg.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1829	.1663	.1494	.1417	.1463	.1448
2	.1478	.168	.1663	.1463	.1433	.1463	.1463
3	.1463	.168	.1494	.1463	.124	.1463	.1463
4	.1494	.1646	.1494	.1478	.1254	.1478	.1448
5	.1509	.1646	.1663	.1448	.1433	.1848	.1478
6	.2263	.1829	.2241	.2195	.2172	.2353	.181
7	.2587	.2629	.2957	.2126	.2865	.3761	.3898
8	.3429	.4161	.2804	.3018	.3121	.3641	.394
9	.3772	.3772	.3155	.407	.4161	.3944	.4458
10	.2743	.2915	.4115	.4024	.4458		.3605
11	.2915	.3086	.4024	.3814	.3506	.4973	.3898
12	.4334	.2454	.4656	.4115	.2572	.5087	.4115
13	.4144	.2103	.4656	.3772	.2401	.3841	.4207
14	.3544	.2804	.4024	.4801	.2743	.2865	.3772
15	.4031	.2601	.394	.3467	.1578	.3391	.3506
16	.4115	.2454	.4458	.407		.4161	.3772
17	.3944	.2126	.4161	.4687		.3353	.503
18	.4359	.3155	.4207	.4062		.3856	.3978
19	.5552	.3898	.4557	.4706	.691		.4656
20	.5792	.4706	.5316	.4706	.6485	.5731	.4755
21	.4755	.394	.439	.3696	.5121	.439	.4344
22	.4066	.3292	.3292	.2614	.3881	.3326	.3292
23	.3109	.2587	.2218	.2218	.3174	.2561	.2172
24	.1886	.2012	.1867	.1463	.181	.1629	.181
Max	.5792	.4706	.5316	.4801	.691	.5731	.503
Min	.1463	.1646	.1494	.1448	.124	.1463	.1448
Avg	.3282	.2709	.3292	.3124	.3035	.3208	.3263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 202 / 11 KV Velvatti Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347	.1097	.1294	.1494	.216	.2401	.2622
2	.2543	.1109	.112	.128	.2187	.2401	.2652
3	.2515	.1109	.112	.128	.2187	.218	.2683
4	.2543	.1109	.112	.1307	.216	.218	.2713
5	.2543	.1109	.1109	.128	.2187	.2515	.2622
6	.3353	.1109	.112	.1494	.2812	.3185	.3429
7	.503	.1294	.1109	.1463	.4961	.57	.6173
8	.503	.1109	.1109	.124	.5735	.5868	.583
9	.5596	.112	.1109	.1086	.4801	.5533	.5243
10	.4694	.112	.1097	.1132	.0867	.1029	.1052
11	.0701	.6274	.5243	.5197	.0876	.0876	.0895
12	.0747	.6036	.5365	.5243	.0716	.0914	.1097
13	.0934	.5426	.5365	.503	.0905	.1097	.0867
14	.0867	.4862	.5087	.4748	.0895	.0905	.1029
15	.0747	.4694	.4748	.4359	.0857	.0895	.0867
16	.0747	.4748	.5087	.426		.0943	.0686
17	.0895	.4458	.4572	.4062		.1063	.1052
18	.128	.4287	.3658	.3749		.1132	.1433
19	.1294	.1086	.1494	.1294	.1494	.1307	.1478
20	.1494	.128	.1307	.1307	.1478	.1307	.1494
21	.1494	.128	.1307	.1307	.1494	.1494	.1494
22	.1478	.1294	.1494	.1494	.1307	.1494	.1494
23	.1478	.1307	.1494	.1294	.1307	.1478	.1494
24	.1307	.1097	.1307	.1463	.1981	.2507	.2572
Max	.5596	.6274	.5365	.5243	.5735	.5868	.6173
Min	.0701	.1086	.1097	.1086	.0716	.0876	.0686
Avg	.2152	.2476	.2451	.2411	.2065	.2100	.2207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 144107 / 33/11 KV Gavase

Feeder No / Name : 203 / 11 KV Kittawade Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.7373	.7202	.8848	.1698	.1698	.1509
2	.1494	.703	.6952	.8951	.168	.1698	.1307
3	.1509	.6874	.6706	.9496	.1698	.1698	.1307
4	.1509	.7042	.6783	.9496	.1698	.1698	.1109
5	.1524	.7122	.8745	.9945	.1698	.1698	.1097
6	.1509	.9496	.9835	1.2407	.1698	.1698	.128
7	.1307	1.2689	1.4232	1.3748	.1509	.1698	.1494
8	.0943	1.543	1.5947	1.4922	.132	.132	.112
9	.0747	1.5777	1.5939	1.4586	.1524	.132	.0943
10	.1307	1.4563	1.4746	.1509	.1509	.132	.0754
11	.218	.1086	.0754	.0943	1.543	2.0157	1.9281
12	1.9982	.1075	.0943	.112	1.7318	2.0683	2.0332
13	1.8551		.0953	.0943	1.7857	1.9719	1.9765
14	1.7337	.1254	.0943	.112	1.6804	2.0157	1.8551
15	1.7511	.1267	.0943	.1143	1.4746	2.1033	1.9071
16	1.7857	.1086	.0754	.0953		1.9631	2.0111
17	1.8004	.1097	.0754	.1509		2.0285	1.8519
18	1.56	.1097	.0754	.1509		1.8176	1.6975
19	.132	.1267	.1307	.1715	.1698	.132	.1509
20	.1886	.1463	.1494	.1629	.1698	.1698	.1698
21	.168	.1646	.1307	.1886	.1698	.1886	.1886
22	.1698	.1663	.1509	.1698	.1698	.1509	.1886
23	.1698	.1494	.1509	.1698	.1698	.1698	.1886
24	.1509	.1509	.1494	.1509	.1698		.1509
Max	1.9982	1.5777	1.5947	1.4922	1.7857	2.1033	2.0332
Min	.0747	.1075	.0754	.0943	.132	.132	.0754
Avg	.6257	.5235	.5104	.5137	.5161	.7991	.7287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

AJARA[022]

BU 1155

Substation No/ Name :- 146006 / 220KV Gadhinglaj(Mumewadi)

Feeder No / Name : 408 / 33 KV Soot Girni

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.3961
Max	.3961
Min	.3961
Avg	.3961

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 201 / 11 KV KOWAD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2347		.4108				.415
2			.4108				.4108
3	.1989		.4108				.415
4			.4108				.4108
5	.2622		.4108				.4108
6	.3391	.4801	.5601	.4801		.5144	.4854
7	.5487	.5144	.5975	.4801	.5426	.5487	.5601
8			.6348			.6516	.6722
9	.7095	.6878	.6516	.6783	.5975	.6443	.6516
10		.724	.6878	.7202		.7122	.5144
11	.7468	.724	.631	.7461	.5601		.5487
12	.6348	.7011	.6516	.6783			
13			.543		.5601		
14		.4908	.4706	.57	.5228		.5144
15		.543	.543		.4481		
16			.5258	.5426	.5228	.57	.5144
17		.5487	.5258		.5144	.5975	.5765
18	.6173	.6859	.6173	.6104	.5487	.7468	
19		.9709	.7202			.8413	.8139
20	.8573	.9877				.9877	
21			.7545			.8215	.823
22		.7842				.7095	
23	.5144	.5601	.5144		.4801	.5601	.5765
24	.407	.4115	.4481	.4115	.4024	.4115	.415
Max	.8573	.9877	.7545	.7461	.5975	.9877	.823
Min	.1989	.4115	.4108	.4115	.4024	.4115	.4108
Avg	.5059	.6543	.5514	.5918	.5181	.6655	.5405



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 202 / 11 KV Kagani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6118		.0381				1.8896
2			.0381				1.933
3	1.9071		.0381				1.8244
4			.0381				
5	1.8861		.0381				1.933
6	1.8652		.0381			2.079	2.0317
7	1.8861		.0381		2.4078	2.1125	2.2405
8			.0381				2.8826
9					2.4966	2.332	2.6825
10					.0381		
11		1.086	1.448	2.4006	.0381		
12		1.2269	1.6289		.0381		
13			1.6289		.0381		
14			1.6289	2.7435	.0381		
15			1.6289	2.8147	.0381		
16			1.8099	2.774			
17		1.1603	1.8099			.0381	
18		1.1603	1.6766	2.6406		.0381	
19						.0381	
20						.0381	
21		.0381				.0381	
22		.0381				.0381	
23		.0381				.0381	
24			.0381		1.5424	1.8442	1.933
Max	1.9071	1.2269	1.8099	2.8147	2.4966	2.332	2.8826
Min	1.6118	.0381	.0381	2.4006	.0381	.0381	1.8244
Avg	1.8313	.6783	.8002	2.6747	.7417	.7849	2.1500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 203 / 11 KV Kudnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012		.5975				.4481
2			.5975				.4481
3	.1677		.5975				.4481
4			.5975				.4481
5	.2321		.5975				.4481
6	.3018	.5487	.7468	.5144		.5487	.5601
7	.5426	.5487	.5975	.5144	.4694	.5144	.6348
8			.5975			.5487	.6348
9	.7095	.6516	.631	.6706	.4481		.7545
10	.8962	.7602	.7602	.6783	.4481	.6783	.6859
11	.7468	.724	.905	.6859	.5228		.6859
12	.7468	.724	.7011		.4481		
13			.7964		.4481		
14	.5228		.5609	.503	.3734		.5487
15	.5228		.5792		.4108		
16	.5601		.6878	.407	.3734	.4748	.4801
17		.5228	.5792		.3429	.5601	.5087
18	.5487	.5601	.5144	.4748	.4115	.5975	
19		.7468	.7202			.7468	.6371
20	.6859	.8779				.7316	
21		.8779	.5487			.6722	.6443
22		.8589				.5975	
23	.4801	.5975	.4801		.3429	.5975	.407
24	.4359	.4801	.5975	.4801	.4024	.3086	.4481
Max	.8962	.8779	.905	.6859	.5228	.7468	.7545
Min	.1677	.4801	.4801	.407	.3429	.3086	.407
Avg	.5188	.6771	.6360	.5476	.4186	.5828	.5484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 204 / 11 KV KUDNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.7682				.0381
2			.7682				
3			.7773				.0381
4			.7682				.0381
5			.7865				.0381
6			.8745	.7377			.0381
7			1.1523	.8718			.0381
8			1.2163				.0381
9	.0381	.9412	1.267	.8573	.0381		
10	.0381	.7964	1.1584		.0381		
11	1.2483				1.3763		1.6095
12	1.4083				1.5364		
13					1.6004		
14	1.3443				1.5364		1.5424
15	1.2163				1.4083		
16	1.2163				1.4243	1.7833	1.1401
17		.0381			1.3413	1.5043	.9496
18	1.073	.0381			1.2742	1.4083	
19		.0381				.0381	
20		.0381				.0381	
21		.0381				.0381	
22		.0381				.0381	
23		.0381				.0381	
24			.0381				.0381
Max	1.4083	.9412	1.267	.8718	1.6004	1.7833	1.6095
Min	.0381	.0381	.0381	.7377	.0381	.0381	.0381
Avg	.9478	.2227	.8705	.8223	1.1574	.6108	.4622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 205 / 11 KV KAGANI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0335		.1494				.0747
2			.1494				.0747
3	.0328		.1494				.0747
4			.1494				.0747
5	.0671		.1494				.0747
6	.0995	.1029	.1494	.1029		.1029	.0747
7	.1357	.1029	.1524	.1029	.1357	.1029	.112
8			.1494			.1372	.112
9	.1494	.0724	.1448	.1341	.1494		.1372
10	.1494	.1448	.1417	.1017	.112	.1357	.1029
11	.112		.1448	.1017	.0747		.1029
12	.1494		.1052	.0671	.0747		
13	.112		.0701		.0747		
14	.0747		.0724		.0747		.0686
15	.0747		.1086		.0747		
16	.0747			.0678	.0747	.0671	.0686
17		.0747			.1029	.0747	
18	.1029	.112	.0686	.1006	.1029	.112	
19		.1867	.1372			.2241	
20	.2058	.2614				.1867	
21		.2241	.1715			.1867	.2035
22		.2241				.112	.1357
23	.1029	.1867	.1029		.1029	.0747	.0995
24	.0671	.1029	.1494	.0686	.0671	.0686	.0747
Max	.2058	.2614	.1715	.1341	.1494	.2241	.2035
Min	.0328	.0724	.0686	.0671	.0671	.0671	.0686
Avg	.1026	.1496	.1308	.0942	.0939	.1219	.0980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 206 / 11 KV Hemrus

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663		.0762				.0762
2			.0762				.0762
3	.0655		.0762				.0762
4			.0762				.0762
5	.0335		.0762				.0762
6	.0335	.0686	.0762	.0686		.0343	.0381
7	.0335	.0686	.0747	.0686	.0335	.0343	.0381
8			.0747				.0381
9	.0381	.0724	.0724	.0671	.0381	.0335	.0343
10	.0381	.0701	.0701	.0671	.0381	.0335	.0343
11	.0381	.0724	.0724	.0671	.0381		.0686
12	.0381	.0724	.0701	.0671	.0747		
13	.0381		.0701		.0747		
14	.0381		.0724	.0671	.0747		.0686
15	.0381		.0709	.0671	.0747		
16	.0381		.0701	.0663	.0747	.0671	.0686
17		.0747	.0724		.0686	.0747	.0678
18	.0343	.0747	.0686	.0671	.0686	.0747	
19		.0747	.0686			.0747	.0663
20	.0686	.0747				.0747	
21		.0762	.0686			.0747	.0663
22		.0762				.0747	
23	.0686	.0762	.0686		.0686	.0747	.0671
24	.0663	.0686	.0747	.0686	.0671	.0686	.0747
Max	.0686	.0762	.0762	.0686	.0747	.0747	.0762
Min	.0335	.0686	.0686	.0663	.0335	.0335	.0343
Avg	.0456	.0729	.0726	.0674	.0611	.0611	.0618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 207 / Nrusinhwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8139		.0381				1.1523
2			.0381				1.1523
3	.8573		.0381				1.1523
4			.0381				1.1523
5	.8817		.0381				1.1523
6			.0381			1.8442	1.4723
7	.9602		.0381		2.1026	2.5149	2.0165
8			.0381			2.8502	2.4006
9					.0747	2.9835	2.3472
10					.0381		
11		.905	1.6289	2.2043	.0381		
12		1.267	1.8099		.0381		
13			1.8099	2.2634	.0381		
14			1.6289		.0381		
15			1.4842	2.2721	.0381		
16	.0381		1.5203		.0381		
17		1.7284	1.6289	1.9669		.0381	
18		1.6244	1.3413	1.7635		.0381	
19		.0381				.0381	
20		.0381				.0381	
21		.0381				.0381	
22		.0381				.0381	
23		.0381				.0381	
24			.0381		1.4083	1.6095	1.1934
Max	.9602	1.7284	1.8099	2.2721	2.1026	2.9835	2.4006
Min	.0381	.0381	.0381	1.7635	.0381	.0381	1.1523
Avg	.7102	.6350	.7762	2.0940	.3852	1.0058	1.5192

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144059 / 33/11 KOWAD

Feeder No / Name : 208 / RAJGOLI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			1.1843				.0381
2			1.1843				.0381
3			1.1843				.0381
4			1.1843				.0381
5			1.1984				.0381
6		1.2071		1.1736			.0381
7		1.5424	1.3123	1.2742			.0381
8			1.5684				.0381
9	.0381	1.7375	1.6126	1.3565	.0381		
10	.0381	1.5775	1.6289		.0381		
11	1.7924				1.6644		2.0119
12	1.9524				1.9524		
13					1.9524		
14	1.9204				2.0165		2.079
15	1.8564				1.9524		
16	1.8884				1.9845	1.8652	1.8778
17		.0381			2.0119	2.0165	1.8652
18	1.5424	.0381			1.9448	1.6644	
19		.0381				.0381	
20		.0381				.0381	
21		.0381				.0381	
22		.0381				.0381	
23		.0381				.0381	
24			.0381				.0381
Max	1.9524	1.7375	1.6289	1.3565	2.0165	2.0165	2.079
Min	.0381	.0381	.0381	1.1736	.0381	.0381	.0381
Avg	1.3786	.5756	1.2096	1.2681	1.5556	.7171	.6290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV SHINOLI EX.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.1187	.1132	.1132	.1187	.0754	.1132
2	.0754	.0678	.0754	.0754	.0678		.0377
3	.0377	.0339	.0377	.0377	.0339	.0377	.0377
4	.0377	.0343	.0377	.0377	.0339	.0377	.0377
5	.0377	.0343	.0377	.0377	.0332	.0377	.0377
6	.0377	.0339	.0377	.0377	.0339	.0377	.0377
7	.0377	.0339	.0377	.0377	.0339	.0377	.0377
8	.132	.1187	.132	.1132	.1326	.1509	.1132
9	.132	.1448	.1509	.132	.1311	.1509	.1509
10	.1509	.1448	.1478	.1509	.1478	.1463	.1478
11	.1294	.1463	.1463	.1509	.1478	.128	.112
12	.1109	.132	.1109		.1109	.112	.1307
13	.1109	.112		.1357	.1109	.1109	.1109
14	.0373	.0373	.037	.1187	.1109	.0373	.112
15	.0373	.0373	.0373	.0339	.0373	.0373	.0373
16	.0373	.0377	.0373	.0339	.0373	.0377	.0377
17	.0339	.0377	.0377	.0339	.0377	.0377	.0377
18		.0377	.0377	.017	.0377	.0377	.0377
19	.0339	.0377	.0377	.017	.0377	.0377	.0339
20	.1357	.1132	.0377	.1187	.1509	.0377	.1357
21	.1357	.132	.1509	.1357	.1509	.1509	.1357
22	.1372	.132	.132	.1357	.1509	.1509	.1357
23	.1357	.132	.132	.1357	.1509	.1509	.1187
24	.1132	.1187	.1132	.1132	.1187	.1132	.1132
Max	.1509	.1463	.1509	.1509	.1509	.1509	.1509
Min	.0339	.0339	.037	.017	.0332	.0373	.0339
Avg	.0861	.0837	.0807	.0849	.0899	.0823	.0850



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV Gaulwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8848	.017	.0156	.0152	.7291	.7621	.9503
2	.9496	.017	.0156	.0164	.6802	.7621	.8097
3	.9389	.017	.0164	.0164	.7293	.7316	.852
4	.9503	.017	.0156	.0164	.7537	.7316	.8817
5	.9831	.017	.0164	.0162	.8619	.7926	.9831
6	1.3413	.017	.0164	.0164	.9835	.8535	1.1797
7		.017	.0152	.0164	1.1523	1.0974	1.3435
8	1.5729	.017	.0152	.0162	1.5091	1.4632	1.5729
9	1.6221		.0164	.0164	1.4413	1.4327	1.4899
10	1.6598	.0173	.0181	.0164	.0177	.0181	.0181
11	.0179	1.4506	1.5023	1.8023	.0181	.0181	.0181
12	.0183	1.7814	1.5497		.0179	.0181	.0183
13	.0185	1.5851		1.6108	.0181	.0181	.0179
14	.0181	1.5546	1.4352	1.6108	.0185	.0185	.0183
15	.0185	1.4937	1.4632	1.6278	.0181	.0183	.0181
16	.0183	1.6956	1.4575	.8309	.0179	.0164	.0183
17	.017	1.5074	1.3523	.78	.0177		.0185
18		1.4746	1.3245	1.3904			.0183
19	.017	.0168	.0152	.017	.0152	.0164	.017
20	.017	.0162	.0164	.017	.0152	.0164	.017
21	.017	.0162	.0164	.017		.0162	.0171
22	.017	.0164	.0164	.017	.0152	.0162	.017
23	.0183	.0156	.0162	.017	.0152	.0164	.017
24	.0164	.017	.0164	.2058	.7969	.7316	.9054
Max	1.6598	1.7814	1.5497	1.8023	1.5091	1.4632	1.5729
Min	.0164	.0156	.0152	.0152	.0152	.0162	.017
Avg	.5060	.5563	.4497	.4394	.4474	.4348	.4674

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV BELEBHAT Mix

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1311	.2035	.1475	.1457	.1696	.1753	.1311
2	.1311	.1526	.1475	.1296	.1526	.1578	.1311
3		.1526	.1296	.1147	.1526	.1578	.1147
4	.1147	.1696	.1311	.1147	.1526	.1578	.1147
5	.1638	.2374	.1638	.1475	.1989	.1928	.1067
6	.2949	.2883	.2622	.2294	.2294	.2454	.2294
7	.4372	.4578	.3605	.3563	.3391	.4207	.4096
8	.2915	.4748	.3768	.421	.4578	.4207	.4578
9	.3725	.4424	.3441	.3768	.373	.3681	.4588
10	.3605	.4239	.3155	.3605	.3467	.3641	.3768
11	.3441	.3281	.3315	.373	.298	.3467	.3481
12	.3277	.3441	.2947		.2303	.2804	
13		.3077		.3052	.2454	.298	.3647
14	.2818	.3045	.2328	.2883	.2774	.2804	
15	.2883	.2947	.2126	.2883	.2835	.2947	.3113
16	.2984	.2743	.2686	.3391	.3544	.2785	.3481
17	.373	.3441	.2881	.3391	.3761	.3544	.3479
18		.39	.3681	.4239	.4031	.3605	.3641
19	.5426	.3932	.4752	.4973	.5258	.6062	
20	.5935	.6203	.5992	.5935	.631	.6036	.6952
21	.5935	.5243	.4915	.5256	.5434	.4744	.5935
22	.4409	.4321	.3688	.4239	.4382	.4424	.4578
23	.3052	.0183	.2458	.3052	.2804	.2785	.3052
24	.1943	.2035	.1966	.1802	.2204	.1928	.1966
Max	.5935	.6203	.5992	.5935	.631	.6062	.6952
Min	.1147	.0183	.1296	.1147	.1526	.1578	.1067
Avg	.3276	.3243	.2936	.3165	.3200	.323	.3268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Gaulwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1147	.1865	.1475	.1475	.1357	.1753	.1619
2	.1134	.1357	.1341	.1311	.1357	.1578	.1311
3	.0983	.1357	.0983	.0983	.1357	.1578	.1134
4	.0983	.1357	.0995	.0983	.1357	.1578	.1147
5	.1638	.1696	.1475		.1492	.1928	.1475
6	.2458	.2204	.2458	.1311	.1989	.2629	.1966
7	.3113	.2713	.2785	.2785	.3052	.3155	.3113
8	.2949	.3222	.2785	.2743	.3429	.298	.2785
9	.3113	.3721	.2622	.3113	.2818	.2804	.2785
10	.3077	.3506	.3224	.2622	.2804	.2865	.3366
11	.3189	.3544	.298	.2622	.2686	.3155	.3544
12	.3292	.3521	.298		.2629	.3294	.3155
13	.3258	.3052		.3222	.2481	.3012	.2658
14	.2481	.2865	.2896	.3149	.2328	.2534	.3189
15	.2652	.298	.2427	.3052	.2454	.2658	.3045
16	.2686	.3113	.2658	.2883	.2279	.3052	.3189
17	.3222	.2949	.3045	.2883	.2481		.3292
18		.2713	.3121	.3222			.3506
19	.3561	.3561	.3561	.39	.4031	.3658	.4239
20	.3561	.3768	.3932	.39	.4207	.4578	.4239
21	.3222	.3605	.3605	.3429	.3506	.3277	.3561
22	.3052	.2785	.3113	.3052	.333	.2949	.2883
23	.2543	.218	.1966	.2374	.2454	.2294	.2486
24	.1966	.2035	.1638	.1677	.1989	.2103	.2012
Max	.3561	.3768	.3932	.39	.4207	.4578	.4239
Min	.0983	.1357	.0983	.0983	.1357	.1578	.1134
Avg	.2577	.2736	.2525	.2577	.2516	.2701	.2737

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 207 / 11 KV Turkewadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5402	.0509	.0328	.0486	1.3904	1.326	1.6221
2	1.576	.0509	.0328	.0486	1.3904	1.3413	1.4582
3	1.3272	.0509	.0324	.0328	1.3904	1.3413	1.4022
4	1.3272	.0509	.0324	.0324	1.4243	1.3717	1.5074
5	1.6221	.0509	.0492	.0328	1.5261	1.4327	1.5565
6	1.6766	.0509	.0492	.0324	1.6278	1.5394	1.6385
7	1.8143	.0509	.0332	.0328	1.8482	1.9052	
8	1.9839	.0509	.0328		2.3569	2.271	2.5101
9	2.0481		.0335		2.3739	2.271	2.3758
10	1.9662	.0492	.0362	.0486	.0537	.0543	.0549
11	.0354	2.2878	2.7092	2.8502	.0366	.0532	.0739
12	.037	2.9172	2.7492	3.0521	.0354	.0532	.0183
13	.037	2.6749		3.0182	.0366	.0543	.0181
14	.0366	2.6452	2.5587	2.7808	.0362	.0554	.0185
15	.0366	2.5263	2.5263	2.6791	.0362	.0543	.0554
16	.0554	2.9673	2.452	2.6452	.0362	.0335	.037
17	.0509	2.769	2.5114	2.5265	.0366	.0358	.0366
18		2.5232	2.348	2.2552	.0457	.0625	.0554
19	.0509	.0503	.0492	.0509	.0457	.0469	.0509
20	.0509	.0486	.0492	.0509	.0457	.0655	.0509
21	.0509	.0486	.0509	.0509	.0457	.0492	.0509
22	.0509	.0492	.0486	.0509	.0457	.0492	.0509
23	.0509	.0486	.0469	.0497	.0457	.0492	.0509
24	.0509	.0509	.0328	.0492	1.543		1.6549
Max	2.0481	2.9673	2.7492	3.0521	2.3739	2.271	2.5101
Min	.0354	.0486	.0324	.0324	.0354	.0335	.0181
Avg	.7598	.9593	.8042	1.0190	.7272	.6746	.7108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 208 / 11 KV Shivanage Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 209 / 11 KV BELEBHAT Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0457	1.2209	.9831		.0509	.0457	.0324
2	.0486	1.2209	.9667		.0509	.0457	.0328
3	.0509	1.2887	.9667		.0509	.0457	.0328
4	.0328	1.4243	1.0159		.0509	.0457	.0492
5	.0324	1.7126	1.17		.0678	.0457	.0655
6	.0492	1.8482	1.3927		.0678	.0457	.0655
7	.0492	1.8991	1.7859		.0848	.061	.0655
8	.0781	2.2721	2.1136		.0848	.061	.0474
9	.0781		2.13	.213	.0678	.061	.0655
10	.0503	1.8827	1.8982		.0532	.0549	.0709
11	2.1373	.0709	.0358	.0164		2.6452	2.664
12	2.6189	.0492	.0366			2.4669	2.6749
13		.0716		.0509		2.649	1.5851
14	2.3457	.0543	.0709	.0497	1.3413	2.556	2.6749
15	2.4684	.0549	.0709	.0509	1.7295	2.5135	2.452
16	2.2878	.0486	.0543	.0509	1.6857	2.7854	2.625
17	2.6113	.0492	.0543		1.5546	2.452	2.4383
18		.0492	.0537	.0678	1.829	2.4413	2.2588
19	.0678	.0486	.0486	.0509	.061	.0655	.0678
20	.0678	.0655	.064	.0509	.061	.0492	.0678
21	.0678	.0486	.0492	.0663	.061	.0486	.0509
22	.0663		.0486	.0509	.061	.0492	.0509
23	.0678	.0492	.0324	.0509	.0457	.0492	.0509
24	.0162	.0514	.0328	.0324	.0509	.0457	.0324
Max	2.6189	2.2721	2.13	.213	1.829	2.7854	2.6749
Min	.0162	.0486	.0324	.0164	.0457	.0457	.0324
Avg	.6972	.7037	.6554	.0617	.4338	.8887	.8426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144060 / 33/11 KV HALKARNI

Feeder No / Name : 210 / Gad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.823	.6882	.5571	.0187	.0152	.0162
2	.0152	.6613	.7373	.6226	.0183	.0152	.0156
3	.0152	.6104	.6882	.6554	.0179	.0152	.0164
4	.0162	.6443	.6874	.9012	.0183	.0152	.0164
5	.0164	.7461	.8192	.8192	.0187	.0152	.0162
6	.0162	.8817	.9995	.9175	.0187	.0152	.0164
7	.0164	1.0852	1.0159	.9012	.0187	.0152	.0158
8	.0162	1.1869	1.0322	.9717	.0187	.0152	.0162
9	.0162	.9877	1.0227	1.0227	.0187	.0152	.0183
10	.0181	.9339	.8421	.0164	.0187	.0185	.0179
11	1.2498	.0181	.0181	.017	.5864	1.2346	1.2346
12	1.531	.0152	.0185		.6401	1.4998	1.3696
13		.0185		.017	.602	1.3413	1.278
14	.4527	.0185	.0187	.017	.6481	1.2346	1.3763
15	1.4352	.0373	.0187		.6472	1.2811	1.2803
16	1.2334		.0187		.5792	1.3763	1.2334
17	1.2209	.0164	.0185	.017	.587	1.2498	1.1984
18	1.153	.0152	.0187	.017	.6249	1.0688	.9686
19	.017	.0164	.0162	.017	.0152	.0162	
20	.017	.0164	.0164	.017	.0152	.0164	.017
21	.017	.0164	.0164	.017	.0152	.0164	.017
22	.017	.0168	.0164	.0183	.0152	.0164	.017
23	.017	.0164		.0183	.0152	.0164	.017
24	.0164	.017	.0152	.0162	.0187	.0152	.0164
Max	1.531	1.1869	1.0322	1.0227	.6481	1.4998	1.3763
Min	.0152	.0152	.0152	.0162	.0152	.0152	.0156
Avg	.3713	.3826	.3974	.3607	.2165	.4391	.443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 201 / 11 KV Adkur Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0191	.0191	.0189	.0189	.0183
2	.0189	.0191	.0191	.0191	.0189	.0191	.0183
3	.0189	.0189	.0191	.0189	.0187	.0381	.0189
4	.0187	.0377	.0191	.0187	.0187	.0377	.0185
5	.0187	.0373	.0189	.0189	.0366	.037	.0189
6	.0373	.0373	.0377	.037	.0373	.0549	.0373
7	.0554	.056	.0566	.0543	.0543	.0724	.0566
8	.0716	.0537	.0549	.0709	.0532	.0709	.0566
9	.0549	.0377	.056	.0716	.0362	.0537	.0377
10	.0366	.0189	.0366	.0373	.0347	.0373	.0366
11	.0377	.037	.0366	.0189		.0377	.0191
12	.0377	.0366	.0366	.0189		.0366	.0185
13	.037	.0366	.0366		.0187	.0366	.0373
14	.037	.0366	.0366	.0187	.0377	.0366	.0189
15	.037	.0366	.0366	.0187	.0354	.0366	.0187
16	.0373	.0366	.0366	.0189	.0358	.037	.0187
17	.037	.0366	.0187	.0189	.0354	.0366	.0189
18	.037	.0549	.0537	.037	.0549	.0549	.0532
19	.0732	.0732	.0566	.0934	.0924	.0739	.0924
20	.0934	.1109	.0934	.0924	.0943	.0747	.1294
21	.0754	.0934	.0943	.0754	.0739	.0754	.0943
22	.0566	.0732	.0762	.0754	.0566	.0549	.0754
23	.0377	.0366	.0377	.0377	.0189	.0377	.0566
24	.0189	.0189	.0189	.0189	.0189	.0189	.0183
Max	.0934	.1109	.0943	.0934	.0943	.0754	.1294
Min	.0187	.0189	.0187	.0187	.0187	.0189	.0183
Avg	.0418	.0439	.0419	.0395	.0409	.0453	.0411



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 202 / 11 KV Kurtanwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.0934	.0754	.0747	.0747	.0953	.0554
2	.0754	.0747	.0762	.0754	.0747	.0953	.0554
3	.0747	.0739	.0762	.0566	.0566	.0762	.0554
4	.0754	.0739	.0732	.056	.0566	.0566	.0554
5	.0747	.0747	.0943	.0754	.0747	.1132	.0739
6	.1132	.0943	.1097	.112	.112	.1143	.1698
7	.1334	.132	.1509	.1509	.1509	.132	.1509
8	.1848	.1509	.2012	.2561	.1663	.1143	.128
9	.1629	.2218	.2012	.2534	.1478	.1629	.1109
10	.1646	.1867	.1463	.181	.0953	.197	.128
11	.1698	.2587	.2353	.2218		.2772	.132
12	.2427	.2012	.2075	.2402		.2218	.1267
13	.1663	.1109	.1294	.1829	.1417	.2033	.1294
14	.1848	.128	.1463	.1478	.1886	.1663	.1143
15	.1867	.1463	.1478	.1132	.1509	.2033	1.8298
16	.2012	.1829	.1734	.1267	.1494	.2033	.1543
17	.1629	.1646	.1886	.1734	.1524	.1646	.2012
18	.1829	.2012	.1509	.1097	.2195	.1663	.1646
19	.16	.1829	.2378	.1848	.2347	.2195	.2195
20	.2218	.2561	.2507	.2427	.2374	.2402	.2957
21	.2241	.2033	.2075	.2241	.2054	.2033	.2263
22	.1698	.1829	.1715	.1886	.1886	.1463	.1848
23	.1143	.1097	.1143	.132	.1334	.1109	.1494
24		.0943	.0914	.0953	.0943	.1132	.0754
Max	.2427	.2587	.2507	.2561	.2374	.2772	1.8298
Min	.0747	.0739	.0732	.056	.0566	.0566	.0554
Avg	.1539	.1500	.1524	.1531	.1412	.1582	.2078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 203 / 11 KV Here Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0537	.0537	.0526	.056	.0537	.056	.0514
2	.0537	.0358	.0351	.0554	.0537	.0373	.0343
3	.0358	.0377	.0351	.0373	.0362	.0366	.0343
4	.0362	.0381		.037	.0358	.0366	.0343
5	.0543	.0572		.0362	.0543	.0716	.0343
6	.0895	.0943		.0549	.0886	.0886	.0857
7	.1086	.1227		.0905	.1075	.1052	
8	.181	.1402		.1734	.1387	.1052	.1829
9	.208	.1629	.0514	.2058	.12	.1086	.1543
10	.1715	.1658	.0343	.1372	.1063	.0949	.1433
11	.1433	.12	.0914	.12		.0857	.1433
12	.1402	.1029	.1372	.124		.1029	.1417
13	.1387	.1267	.1372	.1063	.0867	.1029	.124
14	.1227	.1097	.1109	.1052	.0943	.1029	.1227
15	.1417	.1267	.1029	.1029	.0953	.1097	.1063
16	.124	.1463	.1029	.1029	.1143	.1372	.1214
17	.1612	.1463	.1715	.1006	.1886	.1543	.1372
18	.1433	.1646	.1387	.124	.112	.1463	.1334
19	.1457	.1646	.181	.1463	.168	.1463	.1829
20	.2054	.181	.2054	.1867	.1867	.1886	.2054
21	.1698	.1646	.1848	.168	.1478	.1372	.168
22	.1187	.1307	.132	.1132	.1509	.1097	.1307
23	.0686	.0724	.0905	.0732	.0762	.0924	.0724
24	.0543	.0678	.0543	.0543	.0537	.0554	.0549
Max	.208	.181	.2054	.2058	.1886	.1886	.2054
Min	.0358	.0358	.0343	.0362	.0358	.0366	.0343
Avg	.1196	.1139	.1079	.1046	.1032	.1005	.1130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 204 / 11 KV Hambire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.8413	.9431	.964	.0867	.0747	.128
2	.104	1.0185	.9431	1.0517	.0876	.0754	.1097
3	.104	1.1694	.9602	1.0402	.1052	.0693	.1097
4	.0876	1.1401	.7545	1.1393	.104	.0701	.1097
5	.0867	1.2346	1.2003	1.166	.1029	.0701	.1097
6	.1017	1.3176	1.2003	1.2483	.1187	.1063	.1097
7	.0972	1.387	1.3717	1.3203	.0995	.104	.128
8	.1006	1.5775	1.4746	1.6278	.0772	.1017	.128
9	.1341	1.6827	1.5432	1.7147	.0983	.0686	.128
10	.1006	1.6651	1.5729	.0867	.1214	.104	.128
11	1.8724	.1097	.0914	.104		1.6461	1.9938
12	1.8861	.1372	.0914	.1029		1.6975	2.0285
13	1.7857	.128	.0914	.1029	1.5775	1.6118	2.0748
14	1.8378	.1097	.0183	.0829	1.4563	1.5432	1.989
15	1.9204	.1097	.0732	.1006	1.6118	1.6289	1.8031
16	1.7684	.1097	.0819	.1017	1.7375	1.5432	1.9033
17	1.8031	.128	.0867	.1063	1.9022	1.6118	.9259
18	1.6461	.1097	.104	.0829	1.5089	1.4746	1.3226
19	.1134	.128	.1463	.0876	.112	.1478	.1402
20	.1017	.128	.124	.1448	.0934	.1463	.1417
21	.1017	.1463	.1063	.1448	.1387	.1463	.1214
22	.1029	.128	.1254	.1433	.1448	.1463	.1387
23	.1227	.1097	.124	.1214	.1227	.128	.1017
24	.1187	.0995	.1097	.124	.1029	.112	.128
Max	1.9204	1.6827	1.5729	1.7147	1.9022	1.6975	2.0748
Min	.0867	.0995	.0183	.0829	.0772	.0686	.1017
Avg	.6750	.6131	.5557	.5379	.5232	.6012	.6667

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 205 / 11 KV Kuratnwadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.0164	.0183	.0162	.8951	.8215	.7537
2	.8048	.0164	.0183	.0168	.9054	.8215	.78
3	.7956	.0168	.0183	.0168	.8718	.8871	.78
4	.7625	.017	.0183	.0171	.8619	.8688	.78
5	.8383	.0171	.0183	.0175	.8718	.8669	1.0174
6	1.1401	.0179	.0183	.0175	1.1401	.8916	1.2003
7	1.0343	.1097	.0732	.0716	1.326	.8817	1.3565
8	1.4754	.1867	.1829	.1886	1.5089	1.2209	1.6278
9	1.4752	.1715	.2561	.2667	1.5089	1.3032	1.56
10	1.1768	.1905	.1829	.1509	.1109	.017	.1829
11	.1509	1.1736	1.4266	2.0233		.0183	.1698
12	.1698	1.4419	1.2452	2.3059		.0183	.1886
13	.132	1.3592	1.3108	2.0919	.0177	.0183	.3395
14	.1307	1.4243	1.2452	2.1262	.0914	.0183	.1886
15	.1698	1.4419	1.2452	1.8861	.112	.0183	.1509
16	.1886	1.3763	1.3413	1.989	.1494	.0185	.1905
17	.168	1.3108	1.3426	1.989	.1494	.0732	.2477
18	.2263	1.153	1.6108	1.8107	.1715	.0924	.2829
19	.1989	.128	.1478	.0716	.1463	.0739	.1509
20	.1307	.1097	.0895	.0724	.0732	.1097	.0377
21	.1307	.0914	.0716	.0171	.0171	.0739	.0175
22	.0693	.0732	.1097	.0179	.0173	.0183	.0173
23	.0171	.0732	.0164	.0171	.017	.0183	.0168
24	.0732	.017	.0183		.8619	.8131	.7716
Max	1.4754	1.4419	1.6108	2.3059	1.5089	1.3032	1.6278
Min	.0171	.0164	.0164	.0162	.017	.017	.0168
Avg	.5092	.4972	.5011	.7477	.5375	.4151	.5337

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 206 / 11 KV Adkur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0732	1.2696	1.0814	1.0774	.0724	.0187	
2	.0739	1.2696	1.1469	1.1736	.0739	.0189	
3	.0747	1.358	1.1469	1.2597	.0732	.0189	
4	.0747	1.6598	1.1469	1.3413	.0739	.0189	
5	.112	1.5242	1.3108	1.3748	.0914	.0191	
6	.132	1.7353	1.3108	1.5708	.1097	.0754	
7	.1494	1.6095	1.5074	1.4586	.1097	.1109	
8	.1509	1.829	1.6712	1.5746	.1097	.0181	
9	.132	1.8313	1.704	1.6095	.1494		
10	.132	1.6095	1.5238	.112	.1143	.1509	
11	1.3413	.1109	.0183	.112		.9831	1.7147
12	1.8861	.1463	.0183	.1109		1.3763	1.8482
13	2.0348	.128	.1478	.0754	1.4548	1.5729	1.8143
14	1.8482	.1829	.128	.1509	1.3923	1.5565	1.5769
15	1.989	.1829	.128	.1097	1.2346	1.5729	1.4922
16	1.8991	.1829	.1886	.0173	1.2308	1.5729	1.7295
17	1.6956	.1463	.1886	.1086	1.419	1.5565	1.5927
18	1.6095	.1646	.2075	.1478	1.419	1.3435	1.4089
19	.1109	.1097	.1867	.1494	.0934	.1097	.0747
20	.1494	.128	.1478	.112	.0924	.1097	.0187
21	.1402	.0914	.0924	.0914	.0934	.0924	.0187
22	.0914	.0732	.1097	.0905	.0934		.0754
23	.0724	.0732	.0724	.0943	.0183		.0187
24	.0739	.0716	.0914	.0183	.0724	.0187	
Max	2.0348	1.8313	1.704	1.6095	1.4548	1.5729	1.8482
Min	.0724	.0716	.0183	.0173	.0183	.0181	.0187
Avg	.6686	.7287	.6365	.5809	.4360	.5864	1.0295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144061 / 33/11 KV CHANDGAD

Feeder No / Name : 208 / 11 KV Chandgad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772		.3361	.3395	.3395	.3467	.3326
2	.3395	.2263	.3174	.2829	.3206	.3155	.3142
3	.3361	.2858	.3174	.2829	.3206	.2686	.3142
4	.3361	.2858	.3174	.2572	.3206	.2658	.3142
5	.3018	.3395	.3361	.2801	.3361	.2772	.3142
6	.3961	.3772	.3734	.3395	.4527	.3658	.3696
7	.4527	.3772	.4481	.3772	.4854	.439	.499
8	.4904	.4481	.4108	.4527	.4854	.4481	.439
9	.5228	.6722	.5487	.5228	.5415	.4715	
10	.5487	.6722	.4938	.5373	.5731	.3772	.6036
11	.5975	.5601	.5487	.5975		.7282	.5175
12	.5975	.6036	.6036	.5228		.6722	.7207
13	.5175	.5601	.5487	.4715	.5544	.6161	.6722
14	.5041	.5487	.6099	.5228	.5716	.7133	.6908
15	.5228	.5853	.5487	.5601	.5716	.6584	.7282
16	.5228	.5788	.5975	.5281	.5658	.5487	.6535
17	.4854	.5853	.5041	.5041	.5121	.6036	.5975
18	.4481	.5487	.5415	.4572	.5601	.5487	.5601
19	.5281	.5487	.6097	.6036	.6036	.6722	.6287
20	.631	.6722	.7468	.6859	.6584	.6584	.7095
21	.6733	.6036	.6468	.6161	.6348	.6099	.6535
22	.5601	.4938	.5716	.5228	.5487	.5487	.5975
23	.439	.439	.4904	.4527	.5121	.4435	.4854
24	.415	.3361	.3292	.3961	.3395	.4161	.3921
Max	.6733	.6722	.7468	.6859	.6584	.7282	.7282
Min	.3018	.2263	.3174	.2572	.3206	.2658	.3142
Avg	.4810	.4934	.4915	.4631	.4913	.5006	.5264

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 201 / 11 KV VAIJANATH

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1829	.2572	.2286	.1715	.1715
2	.1715	.1524	.1829	.2572	.2286	.1715	.1715
3	.1715	.1524	.1829	.2572	.2286	.1715	.1715
4	.1715	.1524	.1829	.2572	.2286	.1715	.1715
5	.3429	.1524	.3658	.3429	.3048	.3429	.3429
6	.5144	.2286	.9145	.4287	.381	.5144	.6001
7	.7716	.7621	.9145	.7716	.8383	.8573	.8573
8	1.2003		1.1888	1.2003	1.0669	1.0288	1.1145
9	.9431	.8383	1.0059	.9431	.8573	.6001	.8573
10	.6859	.7316	.6001	.5335	.6001	.6859	.7316
11	.6097	.7316	.5144	.4572	.5144	.4287	.7316
12	.5335	.6401	.5144	.381	.4287	.5144	.5487
13	.0762	.5487	.0857	.3048	.3429	.4287	.5487
14	.3048	.5487	.5144		.1715	.4287	.4572
15	.381	.5487	.5144	.3048	.1715	.4287	.5487
16	.6097	.5487	.6001	.4572	.3429	.5144	.6401
17	.9145			.6859	.7716	.7716	.823
18	.9145		1.286	.6859	.6859	.8573	1.0059
19	.7621	.9431	.6859	.6097	.6001	.6859	.9145
20	.5335	.7316	.5144	.4572	.5144	.5144	.7316
21	.4572	.5487	.4287	.381	.4287	.5144	.4572
22	.3048		.3429	.3048	.1715	.4287	.3658
23	.2286	.2743	.3429	.2286		.3429	.2743
24	.1715	.1524	.1829	.2572	.2286	.1715	.2572
Max	1.2003	.9431	1.286	1.2003	1.0669	1.0288	1.1145
Min	.0762	.1524	.0857	.2286	.1715	.1715	.1715
Avg	.4977	.4770	.5325	.4680	.4494	.4894	.5623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 202 / 11 KV HITECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6001	.6097	.6859	.6859	.6097	.4287	.8573
2	.5144	.5335	.6001	.6859	.6097	.5144	.8573
3	.6859	.5335	.5144	.6001	.6097	.6001	.7716
4	.6001	.5335	.5144	.6859	.5335	.5144	.6001
5	.6001	.5335	.6001	.7716	.4572	.4287	.6001
6	.5144	.5335	.6859	.7716	.4572	.4287	.6001
7	.6001	.5335	.7716	.6859	.4572	.4287	.6001
8	.4287			.7716	.381	.5144	.8573
9	.3429	.9145	.5144	1.0288	.4287	.5144	1.2003
10	.5144	1.6289	.6859	1.2193	.3429	.5144	1.1145
11	1.1431	1.7147	.7716	1.2955	.4287	1.1145	1.2003
12	1.3717	1.7147	.7716	1.0669	.3429	.6859	1.4937
13	.9145	1.8004	1.1145	1.448	.3429	.5144	1.5432
14	1.5242	1.8861	.9431	1.6766	.4287	.6001	1.7147
15	1.3717	1.7147	1.0288	1.3717	.4287	.8573	1.5432
16	1.2955	1.5432	1.286	1.5242	.4287	1.1145	1.286
17	.9907		1.5432	1.5242	.4287	.6001	1.2003
18	.6097		1.1145	.8383	.4287	.6859	1.1145
19	.6097	.6859	.6001	.5335	.4287	.7716	.8573
20	.4572	.6859	.8573	.5335	.5144	.6859	.6859
21	.381	.5144	.5144	.5335	.5144	.7716	.6001
22	.4572	.8573	.7716	.6097	.5144	1.1145	.5144
23	.5335	1.2003	.6859	.6859		1.0288	.5144
24	.6001	.6097	.6859	.6859	.6859	.5144	.9431
Max	1.5242	1.8861	1.5432	1.6766	.6859	1.1145	1.7147
Min	.3429	.5144	.5144	.5335	.3429	.4287	.5144
Avg	.7359	1.0134	.7940	.9264	.4697	.6644	.9696



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 203 / 11 KV Angolkar

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.2058		.1524	.1715	.1715
2	.1715	.1524	.1715	.1715	.1524	.1715	.1715
3	.1715	.1524	.1715	.1715	.1524	.1715	.1715
4	.1715	.1524	.1715	.1715	.1524	.1715	.1715
5	.1715	.1524	.1715	.1715	.1524	.1715	.1715
6	.1715	.1524	.2058	.1715	.1524	.1715	.1715
7	.1715	.1829	.2572	.1715	.1524	.1715	.1715
8	.2572			.1715	.1524	.2572	.2572
9	.2572	.3048	.3429	.1715	.2058	.2572	.3429
10	.5144	.4287	.3429	.1524	.1715	.3429	.3429
11	.381	.3429	.3429	.1524	.1715	.3429	.3429
12	.3048	.3429	.3429	.1524	.1715	.3429	.2572
13	.381	.3429	.3429	.1524	.1715	.2572	.2572
14	.381	.3429	.3429	.1524	.1715	.2572	.3429
15	.381	.3429	.3429	.1829	.1715	.3429	.3429
16	.381	.2572	.4287	.1524	.1715	.3429	.4287
17	.381		.4287	.0762	.1715	.3429	.3429
18	.3048		.4287	.2286	.1715	.3429	.2572
19	.3048	.3429	.3429	.2286	.1715	.3429	.2572
20	.2286	.2572	.3429	.1524	.1715	.2572	.2572
21	.2286	.2572	.2572	.1524	.1715	.2572	.2058
22	.1524	.2572	.2572	.1524	.1715	.2572	.2058
23	.1524	.2572	.2572	.1524		.2572	.2058
24	.1715	.1524	.2572	.2572	.1524	.1715	.1715
Max	.5144	.4287	.4287	.2572	.2058	.3429	.4287
Min	.1524	.1524	.1715	.0762	.1524	.1715	.1715
Avg	.2651	.2536	.2937	.1682	.1655	.2572	.2508

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144062 / 33/11 KV SHINOLI S/STN

Feeder No / Name : 204 / 11 KV Aqua

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7716	.6859	.724	.6859	.6097	.5144	.7716
2	.6859	.6859	.724	.6859	.6097	.6001	.7716
3	.7716	.6097	.724	.6001	.6097	.5144	.6859
4	.8573	.6859	.724	.6001	.5335	.4287	.6859
5	.6859	.6097	.724	.6001	.5335	.5144	.6001
6	.7716	.6097	.8145	.6001	.5335	.4287	.6001
7	.6859	.6097	.8145	.6001	.5335	.5144	.6001
8	.6859		.724	.6859	.4572	.5144	.7716
9	.7716	.8383	.905	.5144	.5144	.6859	.7716
10	.9431	1.086	.8573	.4572	.6859	.6859	.905
11	.9145	.9955	1.0288	.4572	.6001	.6859	.905
12	.9145	.905	1.1145	.4572	.5144	.6001	.905
13	.0762	.905	.8573	.4572	.6001	.6001	.905
14	.0762	.905	.7716	.4572	.4287	.7716	.905
15	.9145	.905	.7716	.4572	.4287	.6859	.905
16	.9145	.905	.8573	.4572	.5144	.6859	.724
17	.8383		.8573	.6859	.6001	.8573	.724
18	.7621		.8573	.6097	.6001	.6859	.8145
19	.7621	.8145	.8573		.6001	.8573	.724
20	.6859	.724	.9431	.6097	.5144	.8573	.724
21	.7621	.724	.7716	.5335	.6001	.6859	.724
22	.7621	.905	.9431	.5335	.6859	.7716	.724
23	.6859	.905	.8573	.6097		.7716	.724
24	.8573	.7621	.724	.6859	.6097	.6001	.7716
Max	.9431	1.086	1.1145	.6859	.6859	.8573	.905
Min	.0762	.6097	.724	.4572	.4287	.4287	.6001
Avg	.7315	.7989	.8311	.5670	.5616	.6466	.7643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 201 / 11 KV AMROLI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1254	.0876	.1254	.1227	.1307	.1254	.1052
2	.1075	.0876	.1075	.1052	.1294	.1075	.0876
3	.0895	.0876	.0895	.1052	.1307	.1075	.0876
4	.0895	.0876	.0895	.1052	.1307	.1075	.0876
5	.0895	.1227	.0895	.1402	.1494	.1075	.1402
6	.1433	.1753	.1612	.1753	.168	.1791	.1753
7	.1791	.2103	.197	.1928	.2241	.2328	.2279
8	.2149	.208	.2149	.2279	.2241	.2328	.0158
9	.2507	.2103	.2686	.2454	.2427	.2507	.2454
10	.2149	.2454	.3045	.2454	.2241	.2686	.2103
11	.1772	.2454	.2454	.2987	.1791	.2454	.2149
12	.1595	.2279	.2279	.2614	.1433	.2454	.197
13	.1753	.2865	.2103	.1848	.1254	.2103	.197
14	.1753	.2507	.1402	.1848	.1791	.1753	.197
15	.1417	.2149	.1753	.1848	.1791	.1928	.197
16	.1402	.2328	.1928	.1494	.1791	.2103	.1791
17	.208	.2507	.2454	.168	.1791	.2454	.1612
18	.2454	.2328	.2804	.1867	.197	.2629	.2149
19	.4075	.3224	.4382	.4668	.3224	.4784	.394
20	.4207	.4656	.4557	.4854	.4477	.4961	.4784
21	.3506	.394	.3856	.4108	.394	.3856	.4119
22	.2804	.2686	.3155	.3734	.2865	.3155	.2149
23	.2103	.2149	.1928	.2801	.197	.1772	.1791
24	.1433	.1052	.1612	.1402	.168	.1433	.1052
Max	.4207	.4656	.4557	.4854	.4477	.4961	.4784
Min	.0895	.0876	.0895	.1052	.1254	.1075	.0158
Avg	.1975	.2181	.2214	.2267	.2054	.2293	.1969

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 202 / 11 KV BONJURDI

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1641				1.1961	1.3611	1.4373
2	1.2357				1.21	1.5939	1.4723
3	1.2894				1.21	1.6297	1.4723
4	1.3432				1.2125	1.6834	1.4723
5	1.379				1.2125	1.7193	1.5775
6	1.4148				1.4045	1.7909	1.6126
7	1.4148				1.5729	1.8267	1.7353
8	1.5223				1.7695	1.9521	1.8229
9	1.6476				1.6518	1.8983	1.7703
10	1.576	2.5591				.0537	
11			2.3312	2.2447			
12		2.2085	2.4539	1.9989			
13		2.5431	2.5415	1.9662			
14		2.5968	2.489	2.1628			
15		2.4983	2.3663	2.1862			
16		2.4356	2.3137	2.2611			
17		2.5431	2.3487	2.2119	.0724		
18		2.4356	2.3663	1.9334	.0724		.0543
19		.0895			.0716		.0905
20		.0895			.0895		.0905
21		.0724			.0895		.0905
22		.0724			.0895		.0905
23		.0543			.0716		.0724
24	.0543		.0543		1.1961	1.182	1.4373
Max	1.6476	2.5968	2.5415	2.2611	1.7695	1.9521	1.8229
Min	.0543	.0543	.0543	1.9334	.0716	.0537	.0543
Avg	1.2765	1.5537	2.1405	2.1207	.8348	1.5174	1.0187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 204 / Adkur Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1075	.1052	.1075	.0876	.1097	.1254	.0876
2	.0895	.1052	.0895	.0876	.1086	.1075	.0876
3	.0895	.1063	.0905	.0876	.1097	.0895	.0876
4	.0895	.1052	.0724	.0876	.1097	.0895	.1052
5	.0895	.1402	.0716	.1402	.1267	.0895	.1402
6	.1612	.1753	.1433	.1753	.1463	.1612	.1578
7	.197	.1753	.197	.1928	.1829	.2149	.1928
8	.197	.1928	.197	.1753	.1829	.2149	.1772
9	.2328	.1928	.2149	.1753	.1848	.197	.1928
10	.2149	.1928	.2149	.1753	.1829	.1791	.1928
11	.2454	.2103	.156	.1646	.1612	.1753	.197
12	.2303	.1928	.1595	.1646	.1612	.2103	.2149
13	.1949	.197	.1578	.1463	.1791	.2103	.2149
14	.1734	.197	.1578	.1463	.1791	.2103	.2149
15	.1772	.1791	.1753	.1448	.1791	.1753	.2172
16	.1949	.2149	.1578	.1646	.1612	.1578	.197
17	.2126	.2149	.1772	.1646	.1791	.1753	.1791
18	.2126	.197	.2103	.2218	.197	.208	.2328
19	.3366	.2686	.333	.3511	.2686	.298	.3045
20	.3544	.3403	.333	.3511	.3366	.3155	.3582
21	.2835	.2865	.298	.2926	.2865	.2804	.2328
22	.2103	.2328	.2103	.2218	.2328	.1949	.1791
23	.1772	.197	.1753	.1848	.1791	.1402	.1612
24	.1254	.1227	.1433	.1052	.1097	.1433	.1052
Max	.3544	.3403	.333	.3511	.3366	.3155	.3582
Min	.0895	.1052	.0716	.0876	.1086	.0895	.0876
Avg	.1915	.1893	.1768	.1754	.1773	.1818	.1846

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144071 / 33/11 KV ADKUR

Feeder No / Name : 205 / Satavane Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5074	1.3611	1.4723			
2		1.5074	1.5223	1.5238			
3		1.5238	1.7551	1.5074			
4		1.6126	1.9879	1.5415			
5		1.7364	2.0774	1.6301			
6		1.8229	2.1491	1.825			
7		2.2085	2.2565	2.226			
8		2.3487	2.4188	2.3838			
9		2.4714	2.5065	2.5591			
10		2.4539	2.2611				
11	2.8086				2.5072	2.1091	2.1849
12	2.9271				2.5789	2.3487	2.4714
13	2.7641				2.6505	2.4188	2.7759
14	2.6578				2.7042	2.489	2.7221
15	2.5591				2.6505	2.524	
16	2.4629				2.6147	2.5941	2.7401
17	2.524				2.561	2.4188	2.7042
18	2.6006				2.5072	2.3137	2.7221
Max	2.9271	2.4714	2.5065	2.5591	2.7042	2.5941	2.7759
Min	2.4629	1.5074	1.3611	1.4723	2.5072	2.1091	2.1849
Avg	2.6630	1.9193	2.0296	1.8521	2.5968	2.4020	2.6172

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 201 / 11 KV Kurani Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1314	.167	.1494	.1512	.1132	.1494	.1331
2	.1127	.1485	.1494	.1501	.1126	.1494	.1294
3	.1128	.1485	.1494	.1517	.1127	.1494	.1294
4	.1126	.1485	.1494	.1512	.1126		.13
5	.1314	.167	.1867	.1708	.1126	.1867	.1486
6	.1691	.2227	.2427	.2079	.1691	.2614	.1955
7	.2442	.2598	.2801	.2457	.2442	.2614	.2402
8	.2815	.2993	.2614	.2641	.3003	.2614	.2614
9	.3378	.3742	.2801	.3083	.2442	.2427	.2975
10	.2987	.2993	.2993	.2987	.2578	.3378	.2432
11	.168	.2534	.2619	.2801	.2812	.3003	.2619
12	.2054		.2245	.2241	.1547	.2627	.2058
13	.2241	.1901	.2432	.2241	.2041	.2442	.2245
14	.2419	.1901	.2432	.2241	.2415	.2252	.2058
15	.1867	.1711	.2432	.2241	.1867	.1698	.168
16	.1494	.1698	.2245	.2427	.2427	.2651	.2054
17	.1555	.197	.2432	.2427	.2022	.2518	.2427
18	.2957	.2987	.2686	.263	.2427	.3345	.2252
19	.5185	.4854	.4321	.3566	.4481	.4577	.4133
20	.5175	.5041	.4692	.4904	.4668	.421	.5636
21	.462	.4668	.4549	.4527	.4294	.4378	.4884
22	.3881	.3734	.378	.3378	.3361	.3788	.3803
23	.2218	.2987	.3033	.2066	.1867	.1901	.2282
24	.1879	.1858	.1867	.1672	.1501	.168	.16
Max	.5185	.5041	.4692	.4904	.4668	.4577	.5636
Min	.1126	.1485	.1494	.1501	.1126	.1494	.1294
Avg	.2439	.2617	.2635	.2515	.2313	.2655	.2451

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 202 / Bijur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0346	1.1179	1.1751		.0346	.0346	.0381
2	.0346	1.1304	1.1751		.0346	.0346	.038
3	.0346	1.1304	1.1751		.0346	.0346	.038
4	.0346	1.1304	1.1751		.0346	.0346	.038
5	.0346	1.1647	1.1751		.0346	.0346	.0381
6	.0346	1.3531	1.3824		.0346	.0346	.038
7	.0346	1.5758	1.5898		.0346	.0346	.0381
8	.0346	1.8628	1.8663		.0346	.0339	.0372
9	.0346	1.8286	1.7971		.0346	.0339	.036
10	.0346	1.455	1.5552		.0344	.0346	.0342
11	2.0045	.0368	.0342		2.3996	1.3306	1.9482
12	2.2119	.0367	.0342		2.3328	1.2269	
13	1.9354	.0374	.0342		2.2119	1.3306	2.0508
14	2.0045	.0374	.0342		2.0736	1.2615	1.9824
15	2.1427	.0375	.0342	.0346	2.1427	1.2442	1.6711
16	1.9354	.0358	.0342	.0346	2.2464	1.3306	1.978
17	1.8991	.0373	.0342	.0346	2.2464	1.4343	2.0632
18	1.8004	.0346	.0368	.0346	2.0736	1.3727	1.9008
19	.0346	.0346	.0372	.0346	.0346	.0337	.0346
20	.0867	.0346	.0368	.0346	.0346	.0379	.0346
21	.0693	.0346	.0368	.0346	.0346	.0379	.0346
22	.0867	.0346	.037	.0346	.0346	.0379	.0346
23	.0867	.0346	.0372	.0346	.0346	.038	.0346
24	.0346	.0867	.0346	.0372	.0346	.0346	.0379
Max	2.2119	1.8628	1.8663	.0372	2.3996	1.4343	2.0632
Min	.0346	.0346	.0342	.0346	.0344	.0337	.0342
Avg	.6949	.5959	.6068	.0349	.7617	.4623	.6165



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144080 / 33/11 KV Kanoor Sub Station

Feeder No / Name : 203 / Pundra AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2543	.017	.017	.0191	.3052	.3391	.2801
2	.2543	.017	.017	.0191	.2883	.3391	.2824
3	.2883	.017	.017	.0191	.2713	.3391	.2855
4	.2883	.017	.017	.0171	.2713	.3391	.3429
5	.3222	.017	.017	.0171	.2883	.3391	.381
6	.4239	.017	.017	.0168	.3052	.373	.381
7	.5087	.017	.017	.0191	.4239	.4748	.5335
8	.5765	.019	.017	.0183	.5596	.5426	.6859
9	.6104	.019	.017	.0132	.6274	.5765	.6287
10	.5935	.019	.0171	.017	.0191	.017	
11	.017	.7554	.7879	.9496	.0191	.017	.0171
12	.017	.8748	.9078	.9156	.0191	.017	.0171
13	.017	.703	.9249	.864	.017	.017	.0171
14	.017	.7219	.8221	.8294	.017	.017	.0171
15	.017	.6249	.8221	.6566	.017	.017	.0171
16	.017	.3231	.8221	.6783	.0191	.018	.0171
17	.017	.8371	.8735	.7461	.017	.0188	.0171
18	.0173	.6783	.7339	.7122	.017	.019	.017
19	.0173	.017	.0168	.017	.017	.0188	.017
20	.017	.017	.0171	.017	.017	.0191	.017
21	.017	.017	.0171	.017	.017	.0191	.017
22	.017	.017	.0171	.017	.017	.0191	.017
23	.017	.017	.0168	.017	.017	.0191	.017
24	.017	.0171	.017	.0161	.3052	.3391	.2569
Max	.6104	.8748	.9249	.9496	.6274	.5765	.6859
Min	.017	.017	.0168	.0132	.017	.017	.017
Avg	.1816	.2415	.2903	.2762	.1622	.1773	.1861

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 201 / RAVIKIRAN PAPERMILL EXP NON SHEDDABLE EXPRESS HV FEEDERS

Feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.9335	.9088	1.0269	1.0269	1.0829	.6173
2	.0187	.6535	.6344	1.1157	.8402	.9709	.6344
3	.0187	.8215	.3429	1.0349	1.1203	1.0974	.5658
4	.7095	.9335	.2401	1.1763	1.1016	.8871	.583
5	.8962	.6722	.2229	1.0082	.9511	.9522	.6687
6	.8775	.9522	.1715	.8048	.8215	1.0642	.8916
7	.8775	.6908	.0171	.8131	.9335	1.0456	.9602
8	.6535	.9335	.0171	1.1203	1.0269	.8871	.7202
9	.9149	.9896	.703	.8686		1.0719	
10	.9328	.6908	.9259	.9795	1.1203	.8215	
11	.7095	.9709	.8573	.8048	1.0534	1.1088	.8029
12	.5601	.6344	.9877	1.1016	1.1016	.9945	1.0456
13	.9335	.8059	.7468	.7655	1.0719	.7545	.823
14	.9335	.8916	1.0349	1.0642	1.0269	.9945	1.0642
15	.6908	.6344	1.0349	1.1203	.8048	.7373	.8215
16	.9335	.8059	.7133	.8402	1.0456	.9774	.8029
17	.6908	.823	1.0082	.8402	.9145	.7373	1.0642
18	.9335	.7202	.9955	.8402	1.1157	.9431	.8215
19	.8215	.8745	1.0269	1.1763	1.1203	.9602	1.0456
20		.6001	1.0242	1.1389	.8871	.9259	.823
21	.9335	.8573	.7468	.8775		.9088	1.0456
22	.6908	.6516	1.0456	1.1016		.6859	.9877
23	.9335	.9602	.7947	.9335		.9431	.679
24	.0187	.6722	.9259	1.0974	1.1128	.8131	.6859
Max	.9335	.9896	1.0456	1.1763	1.1203	1.1088	1.0642
Min	.0187	.6001	.0171	.7655	.8048	.6859	.5658
Avg	.6827	.7989	.7136	.9854	1.0098	.9319	.8252

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 202 / 11 KV Turkewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1629	.1372	.1829	.1867	.1463	.1372
2	.1829	.1646	.1372	.1867	.1494	.1494	.1372
3	.168	.1463	.1372	.1829	.1494	.1478	.1543
4	.168	.1463	.1715	.1848	.1494	.1478	.1372
5	.2054	.1646	.1715	.1867	.1867	.1867	.1715
6	.2427	.2378	.2058	.2195	.2926	.2614	.2058
7	.3361	.3258	.2572	.2987	.3361	.3696	.3258
8	.4108	.4207	.3086	.2957		.5014	.3772
9	.5975	.695	.4287	.4854		.7023	
10	.6908	.7468	.4801	.4066	.4108	.8962	
11	.5228	.5304	.4458	.5228	.3921	.8413	.7095
12	.4607	.5487	.7762	.5228	.4066	.8059	.7282
13	.5304	.6173	.6219	.5041	.4024	.6173	.4108
14	.3898	.583	.4805	.3174	.3658	.5487	.5788
15	.5316	.5487	.6219	.2801	.4108	.4801	.5975
16	.5316	.6859	.5014	.3734	.4066	.6173	.5041
17	.4706	.4801	.695	.3361	.3361	.6173	.4481
18	.4252		.4805	.2987	.2614	.5487	.2801
19	.4075	.4458	.4024	.4294	.2957	.3601	.4294
20		.4115	.4066	.4481	.4024	.4287	.4294
21	.3544	.3601	.4108	.4108		.3772	.3921
22	.3012	.2915	.3292	.2987		.3086	.3361
23	.2303	.2058	.2218	.2241		.2401	.2241
24	.2241	.1949	.1886	.1848	.2054	.1867	.1886
Max	.6908	.7468	.7762	.5228	.4108	.8962	.7282
Min	.168	.1463	.1372	.1829	.1494	.1463	.1372
Avg	.3734	.3963	.3757	.3242	.3024	.4370	.3592

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144098 / 33/11 KV Halkarni MIDC

Feeder No / Name : 203 / Megha Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0189	.0686	.0185	.0187	.0185	.0343
2	.0187	.0189	.0857	.0366	.0183	.0185	.0171
3	.0187	.0189	.12	.0185	.0179	.0183	.0171
4	.0187	.0189	.1029	.0373	.0187	.0187	.0171
5	.0187	.0189	.12	.0179	.0187	.0183	.0171
6	.0187	.0189	.0686	.0187	.0187	.0185	.0171
7	.0187	.0566	.0857	.0183	.0183	.0185	.0171
8	.0187	.0566	.0686	.0181	.0187	.0183	.0171
9	.0187	.0377	.0686	.0185		.0373	
10	.0934	.1886	.1886	.0924	.0187	.0924	
11	.0934	.0754	.2058	.112	.0187	.2054	.2241
12	.0943	.1543	.0934	.0747	.0183	.1029	.2427
13	.0754	.0857	.056	.0747	.0185	.1029	.0934
14	.112	.1715	.1109	.112	.0187	.1372	.2427
15	.1132	.1715	.168	.0934	.0185	.0857	.0934
16		.1029	.0924	.112	.0183	.0857	.2241
17	.1886	.1543	.128	.0373	.0185	.0857	.1867
18	.0566	.0514	.056	.0747	.0187	.0343	.0373
19	.0189	.0171	.0366	.0187	.0185	.0171	.0183
20		.0171	.037	.0187	.0187	.0171	.0187
21	.0189	.0171	.0373	.0187		.0171	.0187
22	.0189	.0171	.037	.0187		.0171	.0187
23	.0373	.0343	.0187	.0187		.0171	.0373
24	.0187	.0189	.0343	.0187	.0187	.0185	
Max	.1886	.1886	.2058	.112	.0187	.2054	.2427
Min	.0187	.0171	.0187	.0179	.0179	.0171	.0171
Avg	.0504	.0642	.0870	.0457	.0185	.0509	.0767

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 201 / Parle Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2427	.2058	.2172	.208	.2454	.1848	.2172
2	.208	.1734	.1791	.181	.2218	.181	.1829
3	.1402	.1753	.1772	.1791	.1867	.1463	.181
4	.1772	.1772	.1494	.2126	.1753	.1867	.2149
5	.2507	.2149	.1867	.2427	.208	.2241	.2896
6	.2865	.3189	.2926	.2454	.3052	.2926	.3544
7	.3898	.3856	.4252	.3155	.4115	.3982	.4207
8	.4557	.4207	.4298	.4161	.4115	.3814	.4748
9	.4508	.3544	.3506	.4161	.4344	.5144	.4115
10	.4207	.3544	.3841	.2401	.4344	.4801	.3963
11	.3772	.3429	.3563	.3772	.3647	.3086	.3647
12	.3605	.3086	.3315	.3429	.3277	.3429	.2949
13	.3521	.3086	.2294	.2804	.2622	.3601	.3201
14	.3391	.2915	.3277	.3155	.2915	.3429	.3437
15	.3277	.2743	.3605	.2915	.2846	.3086	.3521
16	.3239	.3086	.3932	.3086	.2622	.1715	.3688
17	.3353	.3277	.3841	.4115	.2846		.3563
18	.3353	.3563	.3521	.4115	.57		.4321
19	.5487	.5316	.5316	.4687	.5609		.5731
20	.6447	.6447	.6447	.4961	.5731	.7087	.6516
21	.5731	.5792	.6089	.4656	.5373	.6447	.6219
22	.4656	.5175	.439	.4435	.4298	.5068	.4024
23	.3544	.4481	.3292	.4161	.2743	.3292	.2896
24	.2804	.2774	.2957	.2774	.3121	.2195	.2195
Max	.6447	.6447	.6447	.4961	.5731	.7087	.6516
Min	.1402	.1734	.1494	.1791	.1753	.1463	.181
Avg	.3600	.3457	.3490	.3318	.3487	.3444	.3639

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 202 / Here Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.3978	.426	.4588	.0328	.0164	.0164
2	.0328	.4641	.4915	.4588	.0328	.0168	.0164
3	.0328	.4641	.5571	.4915	.0328	.0168	.0164
4	.0328	.4973	.6554	.5243	.0328	.0164	.0164
5	.0328	.5636	.6554	.6226	.0328	.0164	.0164
6	.0328	.6299	.7537	.7209	.0328	.0168	.0164
7	.0328	.6962	.8192	.852	.0328	.0164	.0164
8	.0328	.6962	.8848	1.0486	.0328	.0164	.0164
9	.0328	.8619	1.1142	1.0159	.0335	.0168	.0164
10	.0328	.8619	.9831	.0335	.0332	.0168	.0164
11	1.2452	.0335	.0164	.0335	1.0242	.0168	1.1469
12	1.2597	.0335	.0164	.0332	1.004	.7377	1.1797
13	1.4918	.0335	.0166	.0332	.9945	.7209	1.0486
14	1.3592	.0168	.0166	.0332	1.0277	.7209	.9831
15	1.2929	.0168	.0166	.0335	1.0159	.7293	1.0814
16	1.1934	.0168	.0166	.0335	1.0159	.7459	1.0814
17	1.2266	.0164	.0166	.0335	.9831		1.1142
18	1.0277	.0164	.0166	.0328	.8192		.0164
19	.0332	.0328	.0166	.0328	.0164		.0164
20	.0381	.0328	.0332	.0328	.0164	.0164	.0164
21	.0663	.0328	.0663	.0328	.0164	.0164	.0164
22	.0332	.0328	.0663	.0328	.0164	.0164	.0164
23	.0332	.0328	.0332	.0328	.0164	.0164	.0164
24	.0328	.0332	.0328	.0166	.0328	.0164	.0164
Max	1.4918	.8619	1.1142	1.0486	1.0277	.7459	1.1797
Min	.0328	.0164	.0164	.0166	.0164	.0164	.0164
Avg	.4442	.2714	.3217	.2781	.3470	.1866	.3298

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144099 / 33 /11 KV Parle Substation

Feeder No / Name : 203 / Patane ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.0181	.0351	.0181	.7202	.8383	.6371
2	.6878	.0181	.0354	.0183	.7461	.8817	.5967
3	.7842	.0183	.037	.0177	.8669	.9054	.6371
4	.9054	.0187	.0373	.0179	.9671	.8421	.663
5	.9156	.0185	.0347	.0177	1.0166	.9503	.7125
6	1.0395	.0183	.0354	.0181	1.1096	.9488	
7	1.166	.0373	.0358	.0183	1.2757	1.1065	1.1401
8	1.2548	.0747	.0351	.0189	1.3592	1.1736	1.2407
9	1.2071	.0335	.0339	.0191	1.3077	1.1736	1.2548
10	1.1736	.0754	.0377	.0169	.0185		.0189
11	.0373	1.6632	1.4083	1.5912	.0166	.0166	.0191
12	.0377	1.5775	1.6964	1.6057	.0191	.0166	.0189
13	.0189	1.6827	1.6766	1.5402	.0191	.0166	.0177
14	.0189	1.7002	1.643	1.6057	.0191	.0166	.0179
15	.0189		1.6095	1.5083	.0187	.0332	.0191
16	.0189	1.5089	1.6095	1.5746	.0189	.0332	.0191
17	.0377	1.4083	1.5424	1.5249	.0191	.0332	.0181
18	.0189	1.3748	1.3923	1.3279	.0189		.0716
19	.037	.0381	.0191	.0373	.0189		.0724
20	.0762	.0377	.0381	.037	.0187	.0187	.0754
21	.0381	.0373	.0377	.0358	.0187	.0189	.0762
22	.0373	.037	.0377	.0362	.0189	.0187	.0762
23	.037	.0373	.0747	.0351	.0175	.0175	.0754
24	.0366	.0366	.0347	.0185	.6226	.7293	.6299
Max	1.2548	1.7002	1.6964	1.6057	1.3592	1.1736	1.2548
Min	.0189	.0181	.0191	.0169	.0166	.0166	.0177
Avg	.4258	.4987	.5491	.5275	.4272	.4662	.3525

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 201 / 11 KV Mangao VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0739	.1097	.1075	.0943	.0934	.0732
2	.0924	.0549	.1109	.1075	.0934	.0934	.0724
3	.0747	.0724	.1109	.1075	.0747	.0754	.0526
4	.0732	.0739	.0914	.1075	.0566	.0754	.0716
5	.0914	.0905	.128	.1075	.0754	.0934	.0934
6	.1294	.1097	.1629	.1075	.1132	.1132	.128
7	.1478	.1646	.1612	.1433	.1307	.1478	.1463
8	.1949	.1734	.1753		.1753	.1612	.1387
9	.208	.156	.156	.1696	.1543	.1227	.1357
10	.2035	.1372	.1865	.1696	.1326	.156	.1174
11	.156	.1052	.1417	.1886		.156	
12	.0693		.1402	.1543	.1433	.1844	.1227
13	.0655	.1214	.1227	.1227	.124	.1526	.1214
14	.0655	.1227	.124	.1372	.1075	.1387	.1214
15	.0663	.1949	.124	.1214	.1254	.1402	.1214
16	.0655	.1949	.1402	.1227	.1075	.156	.1214
17	.081	.1949	.1402	.1509	.1214	.1658	.1214
18	.0791	.1772	.1526	.1187	.1417	.1475	.1372
19	.2126	.2629	.2303	.1791	.2353	.2279	.2126
20	.3045	.2835	.2686	.2218	.2686	.2686	.2686
21	.2865	.2378	.2328	.2033	.2378	.2353	.2561
22	.2378	.2195	.1612	.168	.2054	.1848	.2218
23	.1663	.1646	.1433	.132	.1294	.1463	.1663
24	.1294	.128	.1663	.1294	.1132	.112	.1294
Max	.3045	.2835	.2686	.2218	.2686	.2686	.2686
Min	.0655	.0549	.0914	.1075	.0566	.0754	.0526
Avg	.1380	.1528	.1534	.1425	.1374	.1478	.137



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 202 / 11 KV Vargao AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.16	.0566	.0377	.0377	.2561	.4239	.4001
2	.2267	.0566	.0377	.0377	.2372	.407	.4372
3	.2458	.0572	.0377	.0377	.253	.3944	.4752
4	.2721	.0572	.0377	.0377	.2949	.39	.4961
5	.2915	.0566	.0377	.0377	.3041	.3353	.5407
6	.3201	.0572	.0377	.0377	.421	.3401	.5668
7	.7842	.0566	.0572	.0377	.7116		.5921
8	1.1683	.0566	.0754		.9842	1.1469	.9804
9	.8124	.0189	.0377	.0377	.6093	.7373	.7432
10	.4374	.0187	.0189	.0377	.0189	.0189	.0191
11	.0381	1.2955	1.1984	1.1984		.0185	.0189
12	.0381		1.1984	.7748	.0377	.0189	.0187
13	.0377	.5992	.8907	.506	.0189	.0189	.0189
14	.0377	.583	.8907	.4111	.0189	.0185	.0189
15	.0381	.3563	.4049	.3841	.0187	.0187	.0189
16	.0377	.4858	.4049	.5921	.0189	.0187	.0189
17	.0377	.6478	.4858	.7209	.0187	.0189	.0377
18	.0566	.6642	.7773	.6093	.0377	.0191	.0377
19	.0572	.0189	.0187	.0189	.0377	.0189	.0377
20	.0377	.0377	.0377	.0377	.0377	.0381	.0377
21	.0377	.0377	.0377	.0566	.0377	.0189	.0377
22	.0566	.0377	.0377	.0566	.0377	.0189	.0377
23	.0566	.0377	.0377	.0566	.0189	.0189	.0377
24	.0373	.0566	.0566	.0377	.2721	.4525	.4001
Max	1.1683	1.2955	1.1984	1.1984	.9842	1.1469	.9804
Min	.0373	.0187	.0187	.0189	.0187	.0185	.0187
Avg	.2218	.2326	.2872	.2522	.2044	.2135	.2512

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144117 / 33/11 KV Mangaon

Feeder No / Name : 203 / 11 KV Lakkikate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.6802	.8162		.0189	.0267	.029
2	.0537	.7373	.8802		.0189	.0267	.0297
3	.0358	.7865	.8802		.0189	.0263	.0474
4	.0366	.8259	.8745		.0189	.0248	.0309
5	.0543	.8848	.8745		.0189	.0248	.0492
6	.0543	.9831	.9717		.0189	.0244	.048
7	.0537	1.0322	1.0883		.0189	.0271	.048
8	.0739	1.5249	1.5238		.0189	.0709	.0671
9	.0747	1.4918	1.5238		.0377	.0503	.0554
10	.0358	1.2308	1.1105		.037	.0309	.0452
11	2.079	.0179	.017	.056		2.1026	2.0576
12	2.0719		.0377	.0566	2.0576	2.1874	2.0348
13	1.917	.0377	.0377	.0566	2.0576	2.1704	1.9281
14	1.704	.0377	.0377	.0566	2.2291	2.0178	2.0062
15	1.6712	.0377	.0377	.0566	2.0576	2.1026	2.0062
16	1.6549	.0373	.0377	.0566	1.9719	2.2291	2.0062
17	1.7368	.0754	.0566	.0754	1.9719	2.1026	2.0119
18	1.3117	.0566	.0566	.0747	1.8898	2.0119	1.7126
19	.0566	.0566	.0566	.0189	.048	.0282	.0373
20	.056	.0566	.0754	.0377	.0463	.0457	.0328
21	.0566	.0566	.0754	.0189	.0282	.0452	.0312
22	.056	.0566	.0566	.0189	.0282	.0452	.0377
23	.0566	.0566	.0566	.0189	.044	.0452	.0377
24	.0543	.056	.0566	.0566	.0189	.0412	.0271
Max	2.079	1.5249	1.5238	.0754	2.2291	2.2291	2.0576
Min	.0358	.0179	.017	.0189	.0189	.0244	.0271
Avg	.6254	.4703	.4683	.0471	.6380	.7295	.6841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 144120 / 33/11 KV Tudiye

Feeder No / Name : 201 / 11 KV Tudiye VG

SHEDDABLE RURAL

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5375	1.0898	.905	.9391	.9955	1.0166	.8859
2	.5258	1.0288	.8417	.8328	.8779	.8859	.7973
3	.4961	.964	.7712	.7602	.823	.7888	.7701
4	.6089	1.0387	.7701	.8688	.7682	.7973	.8764
5	.631	.9362	.8764	.9214		1.0749	1.0166
6	.9362		1.0808	.9145		1.3003	1.4548
7	1.8778		1.6956	2.1382	1.6617	2.1434	2.2291
8		1.2717	2.3371	2.7183	2.3703	2.5396	2.9675
9	2.9508	3.219	2.7831	3.2156	2.4863	2.5888	2.9005
10	2.6791	3.0864	2.4813	2.7349	2.3472	2.6216	2.8502
11	2.9334	3.3404	2.4478	1.4251	2.2708	2.4813	2.9673
12	2.5484	1.5415	2.6825	2.1464	2.3137	1.5912	1.3717
13		2.7328	2.3472	2.2708	2.0222	2.2611	2.4086
14	1.7101	2.649	2.2377	2.4247	1.4419	2.3868	2.2874
15	2.364	1.8275	2.3594	2.5604	1.9448	2.5857	2.5484
16	2.8669	2.5652	2.4577	2.8841	2.4756	2.9338	2.5526
17	1.3123	3.2023	2.1795	3.0001	2.649	3.0996	3.0148
18	2.0165	3.0498	2.9329	2.8016	2.8502	3.3532	2.769
19	1.4419	2.4813	1.3426	2.2977	2.2634	2.34	2.1963
20	1.7164	1.7833	1.3735	1.6991	1.5432	1.8519	1.7164
21	1.5604	1.6118	1.1568	1.4327	1.439	1.6301	1.4737
22	1.5257	1.3466	1.1317	1.258	1.335	1.4548	1.335
23	1.291	1.2048	1.0631	1.1641	1.1393	1.2403	1.1145
24	.6089	1.1401	.9671	.9362	1.0387	1.0517	.9922
Max	2.9508	3.3404	2.9329	3.2156	2.8502	3.3532	3.0148
Min	.4961	.9362	.7701	.7602	.7682	.7888	.7701
Avg	1.5972	1.9596	1.7176	1.8477	1.7753	1.9174	1.8957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023] BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 401 / Aqua NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.6516
Max	.6516
Min	.6516
Avg	.6516

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

CHANDGAD[023]

BU 1147

Substation No/ Name :- 148016 / 220 KV Halkarni Substation

Feeder No / Name : 407 / 33 KV KEMPLAST

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.0566
Max	.0566
Min	.0566
Avg	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 201 / 11 KV GADHINGLAJ

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	1.134	1.134	1.2071	1.1706	1.134	
2	1.0974	1.0974	1.0974	1.2071	1.1706	1.0974	
3	1.0608	1.0608	1.0608	1.134	1.134	1.0608	
4	1.0608	1.0719	1.0608	1.134	1.134		1.0974
5	1.134	1.0608	1.134	1.0608	1.0974	1.0608	
6	1.1706	1.134	1.2803	1.0608	1.134	1.134	
7	1.1706	1.2071	1.2437	1.0974	1.2437	1.2437	
8	1.3169	1.3169	1.2437	1.1888	1.2803	1.2803	1.2803
9	1.3169	1.2437		1.3169	1.2071	1.3169	1.2071
10	1.3169	1.3169	1.3535	1.3169	1.1827	1.4266	1.2803
11	1.39	1.4815	1.3169	1.2071		1.39	1.4266
12	1.2437	1.4266	1.3169	1.2803		1.39	1.4998
13	1.1706	1.3169	1.2803	1.2437		1.4266	1.5364
14	1.2803	1.1888	1.2437	1.2437		1.4266	1.4632
15	1.2803	1.3169	1.2437	1.2071	1.6644	1.39	1.5729
16	1.4815	1.3169	1.2437	1.3169	1.5364	1.3717	1.4998
17	2.5606	1.4563	1.39	1.3535	1.4266	1.3169	
18	2.7435	1.39	1.3169	1.5729	1.4266	1.5364	1.5364
19	1.7924	1.829	1.6827	1.7924	1.7924	1.9022	1.7193
20	1.885	1.7558	1.7558	1.5729	1.8656		1.5729
21	1.6461	1.6827	1.6461	1.4266	1.7924	1.6827	1.4998
22	1.5546	1.5729	1.4998	1.4266	1.6461	1.6461	1.5364
23	1.3169	1.2803	1.4266	1.1706	1.3169	1.39	
24	1.0974	1.134	1.2071	1.2071	1.0974	1.1706	1.2437
Max	2.7435	1.829	1.7558	1.7924	1.8656	1.9022	1.7193
Min	1.0608	1.0608	1.0608	1.0608	1.0974	1.0608	1.0974
Avg	1.4244	1.3247	1.3121	1.2811	1.3660	1.3543	1.4358

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 204 / 11 KV Uttur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0688	.2829	.3658	.2641	1.1012	1.2003	1.1248
2	1.0688	.2641	.3658	.2641	1.1012	1.1385	
3	1.1012	.2641	.3658	.2641	1.1012	1.1385	1.2811
4	1.1012	.2641	.3658	.2957	1.1012	1.1523	1.3108
5	1.2308	.2641	.3658	.2957	1.3765	1.2334	1.3443
6	1.4575	.3395	.3658	.3018	1.587	1.8564	1.7985
7	2.2672	.4715	.0732	.3584	1.8138	2.4036	
8		.3772	.3658	.3395	2.17	2.8807	
9		.4527	.3584	.3961	2.0424	2.9473	2.5301
10		.3018	.3584	.3018	.3511	.3018	.3018
11	2.3167	2.6886	2.17	2.5606		.2829	.3961
12	2.0119	2.9767	2.2024	2.5934	.2452	.2452	.3395
13	.2561	2.7526	1.1336	2.5606	.2263	.2452	.3395
14	.2561	2.3045	2.0081	2.4036		.2641	.3018
15	.2561	2.2725	2.2348	2.4326	.1886	.2829	.3018
16	.3658	2.5606	2.2672	2.4036	.2641	.3961	.3018
17		2.4387	2.4326	1.9757	.3018	.3772	
18		2.1399	2.3685	2.3644	.4338	.3841	.3018
19	.4338	.439	.415	.3772	.4338	.4024	.3292
20	.415	.3658	.4338	.3772	.4527		.3772
21	.4527	.3658	.415	.3961	.3961	.3658	.4207
22	.415	.3658		.3395	.3772	.3658	
23	.3395	.2926	.3018	.2641	.3018	.3292	
24	1.0688	.2829	.3658	.2641	1.0688	1.186	1.3123
Max	2.3167	2.9767	2.4326	2.5934	2.17	2.9473	2.5301
Min	.2561	.2641	.0732	.2641	.1886	.2452	.3018
Avg	.9412	1.0637	.9608	1.0164	.8380	.9296	.8007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 205 / 11 KV Nool Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154	.0754	.0732	.0754	.6802	.6642	.5761
2	.6154	.0754	.0732	.0566	.7125	.6325	.7682
3	.6154	.0754	.0732	.0566	.7125	.6325	.7316
4	.6478	.0754	.0732	.0566	.7125	.6401	.7316
5	.6478	.0754	.0549	.0554	.7449	.7042	.8779
6	.7125	.0754	.0549	.0554	.7773	.8539	.9877
7	.8583	.0754	.0732	.0566	.8259	.9922	1.2437
8		.0754	.0732	.0377	.8907	1.1069	1.3169
9	.7682	.0754	.0754	.0566	.7682	1.1336	1.0437
10	.7682	.0754	.0754	.0566	.0739	.0754	.0566
11	.0366	1.0562	1.1012	1.1385		.0943	.0566
12	.0732	1.1523	1.1012	1.1385	.0943	.0943	.0754
13	.0732	1.2163	1.1336	1.2018	.0754	.0943	.0754
14	.0732	1.1843		1.2018		.0754	.0754
15	.0732	1.1797	1.1012	1.1069	.0566	.0754	.0754
16	.0732	1.1203	1.0364	1.1385	.0943	.0754	.0754
17		.9328	1.0883	.7125	.0943	.0754	
18		.8779	1.0242	.9717	.0943	.0732	
19	.0754	.0732	.0905	.0754	.0943	.0732	.0566
20	.0754	.0732	.0754	.0754	.0943		.0566
21	.0754	.0549	.0754	.0754	.0754	.0549	.0566
22	.0754	.0732		.0754	.0943	.0549	
23	.0754	.0732	.0754	.0566	.0754	.0732	
24	.0754	.0754	.0732	.0754	.6478	.6722	.6722
Max	.8583	1.2163	1.1336	1.2018	.8907	1.1336	1.3169
Min	.0366	.0549	.0549	.0377	.0566	.0549	.0566
Avg	.3383	.4124	.3944	.4003	.3859	.3922	.4805



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 207 / 11 KV WATERWORKS

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2926	.3018	.2926	.2587	.2926	.2452	.1715
2	.2195	.2263	.1829	.2587	.2926	.2263	
3	.2195	.2263	.1829	.2218	.2012	.2263	.1715
4	.2012	.2263	.1829	.2218	.2012	.2263	.1715
5	.2012	.2263	.1829	.2218	.2195	.2263	.1638
6	.2195	.2263	.2195	.2218	.2195	.2452	
7	.2378	.2452	.2378	.2402	.2195	.2452	
8		.3018	.2561	.2957	.2743	.2829	
9	.4066	.4435	.2926	.415	.2561	.2926	.415
10	.3658	.3511	.4024	.3772	.3511	.3292	.415
11	.3658	.3881	.3658	.415		.3841	.3772
12	.3292	.3142	.3292	.3395	.0185	.2926	.3206
13	.3292	.2957		.3395	.0185	.2926	.3018
14	.3292	.2772	.2926	.3018		.2926	.3018
15	.3292	.2772	.2561	.3018	.0185	.2561	.2263
16	.2561	.2402	.2378	.2452	.2772	.2378	.2829
17		.1829	.2402	.1829	.2452	.2195	
18		.1463	.2218	.1829	.2263	.0732	.2743
19	.2263	.2195	.2218	.2012	.2452	.1097	.2195
20	.1372	.2195	.2033	.2012	.2641		.2926
21	.2263	.2195	.1848	.1829	.415	.3658	.3658
22	.3109	.2926		.2926	.415	.4024	
23	.3395	.4024	.3511	.3658	.2829	.3292	
24	.3292	.3772	.3475	.3142	.3658	.2829	.1943
Max	.4066	.4435	.4024	.415	.415	.4024	.415
Min	.1372	.1463	.1829	.1829	.0185	.0732	.1638
Avg	.2796	.2761	.2584	.2750	.2418	.2645	.2744

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 210 / 11 KV Uttur VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.4024	.3292	.3658	.3658	.3292	.3658
2	.3658	.4024	.3292	.3292	.3292	.2926	.3292
3	.3658	.3658	.3292	.3292	.3292	.2926	.3292
4	.3658	.3658	.3292	.2926	.3292	.2926	.3292
5	.4024	.3658	.3658	.3292	.3292	.3292	.3292
6	.4024	.4344	.439	.3292	.3841	.4024	.3658
7	.439	.4755	.5121	.3292	.4755	.4344	
8		.4706	.4755	.3658	.4755	.4163	.439
9	.5228	.5611	.439	.4755	.4755	.439	.4024
10	.5121	.567	.439	.4755	.4805	.5121	.5068
11	.5121	.5853	.439	.4755		.5121	.4755
12	.4024	.4755	.439	.4572	.4024	.4755	.4755
13	.4755	.3841	.439	.4706	.3658	.4755	.4572
14	.4755	.4938		.4344			.4706
15	.4755	.5304	.4024	.439	.3475	.4755	.5068
16	.5121	.5121	.439	.3658	.3658	.4755	.5121
17		.5121	.439	.3658	.4572	.4938	
18		.5487	.439	.439	.4755	.6219	.5304
19	.8048	.6584	.567	.6036	.5853	.5853	.5853
20	.7964	.5853	.6584	.695	.5611		.5853
21	.6767	.5853	.5853	.6767	.5487	.6219	.5487
22	.5792	.6036		.4755	.5487	.5487	
23	.4755	.439	.4755	.4207	.4024	.4024	
24	.4024	.4024	.4024	.3841	.3658	.3292	.3658
Max	.8048	.6584	.6584	.695	.5853	.6219	.5853
Min	.3658	.3658	.3292	.2926	.3292	.2926	.3292
Avg	.4919	.4886	.4415	.4302	.4273	.4435	.4455

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144056 / 33/11 KV GADHINGLAJ

Feeder No / Name : 211 / 11KV Belbag

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.8413	.8048	.8048	.8048	.8413	.8413
2	.7545	.8048	.8048	.7682	.8299	.8048	.7682
3	.7545	.8131	.8048	.7682	.8299	.8048	.7682
4	.7545	.8048	.8048	.8048	.8299	.8131	.7682
5	.7922	.823	.8413	.8048	.8488	.8048	.8779
6	.8488	.8413	.8779	.8048	.8488	.8779	.9145
7	.9997		.8779	.823	.8865	.823	.9511
8		.9145	.8413	.8779	.8676	.823	.8779
9	.8871	.8962	.8676	.7865	.8413	.9054	.8779
10	1.0242	.9145	.9054	.8779	.8871	.9808	1.0242
11	1.0242	1.0608	.9997	1.0242			1.0974
12	1.0974	1.0425	.9431	.9877	.9694	.8299	1.0608
13	1.134	1.0242	.6224	.9877	1.0059	.8299	1.0974
14	1.134	.9145		.9511		.8488	1.0974
15	1.134	1.0059	.7356	1.0242	1.0974	.8488	1.134
16	1.0242	1.0425	.9808	1.0425	1.0425	.8676	1.1706
17		1.0974	.9877	1.2071	.9511	.8299	
18		1.0974	1.0059	1.2449	.9511	.5853	1.2071
19	1.2437	1.3169	1.3169	1.2637	1.3169	1.39	
20	1.2071	1.2437	1.39	1.2071	1.39		1.094
21	1.1523	1.134	1.2071	1.1317	1.1706	1.0974	1.2449
22	1.0974	1.0242		1.0185	1.134	1.0974	
23	.9511	.9511	.9328	.9431	.9511	.9511	
24	.7922	.8413	.8048	.8048	.8299	.8779	.9511
Max	1.2437	1.3169	1.39	1.2637	1.39	1.39	1.2449
Min	.7545	.8048	.6224	.7682	.8048	.5853	.7682
Avg	.9791	.9761	.9253	.9566	.9675	.8879	.9912

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 201 / 11 Kv Karambali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.134	.2561	.2926	.2195	.2561	1.7558	1.5775
2	1.134	.2561	.2743	.2743	.2378	1.6827	1.5775
3	1.134	.2561	.2743	.2743	.2378	1.7193	1.5775
4	1.1706	.2743	.2743	.2743	.2561	1.6827	1.5775
5	1.2437	.2743	.2926	.2926	.2743	1.7193	1.5775
6	1.3169	.2378	.2926	.3109	.2926	2.1582	1.8861
7	1.7193	.3292	.3475	.3292	.3475	2.2862	1.989
8	1.8656	.3475	.2195	.4024	.1829	2.524	2.4691
9	1.8656	.3658	.3475	.3475	.3658	2.3777	2.4006
10	1.6461	.3658	.2743	2.4326		.2561	.3086
11	.2378	1.749	1.7741	2.0668	.2401	.2195	.3475
12	.2561	1.8519	2.0668	2.1399	.2401	.2012	.2561
13	.2926	1.7147	1.9753	2.3228	.2401	.2195	
14	.2561	1.749	1.829	2.3045	.2743	.2195	.2743
15	.2743	1.7833	1.8107	2.3411	.2743	.2378	.2561
16	.2743	1.869	1.7741	2.3777	.2401	.2378	.2561
17	.3841	2.0851	1.9387	2.3594	.3658	.3841	.3658
18	.3841	2.0119		2.2361	.3658	.2401	.3142
19	.3109	.2926	.3292	.2926	.2926		.3109
20	.3658	.2926	.3292	.2926	.3658	.2743	.3292
21	.3292	.2743	.3475	.2926	.3292	.3429	.3142
22	.3109	.2743	.3109	.2926	.3109	.2743	.2743
23	.2926	.2561	.2195	.2743	.2195	.2572	.2926
24	.2561	.2743	.2743	.2195	.2561	1.7558	1.5775
Max	1.8656	2.0851	2.0668	2.4326	.3658	2.524	2.4691
Min	.2378	.2378	.2195	.2195	.1829	.2012	.2561
Avg	.7689	.8100	.7769	1.0404	.2811	1.0011	.9613

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 202 / 11 KV Kaulage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962				.8619	.7316
2	.6962				.4973	.7316
3	.6962				.779	.7316
4	.6962				.7625	.7316
5	.7293				.779	.7316
6	.7625				.8951	.8535
7					.9282	1.0669
8	.9282				1.0277	1.0974
9	.9614				.9945	1.0669
10	.8785					
11		.8535	1.0277	.8785		
12		.9755	.9779	1.1437		
13		.9755	1.1603	1.1271		
14		.884	1.1271	1.1603		
15		1.0974	1.0608	1.1768		
16		.8535	1.1012	1.1768		
17		1.0608	1.1437	1.1768		
18		1.0277	1.065	1.0608		
24					.7459	.7316
Max	.9614	1.0974	1.1603	1.1768	1.0277	1.0974
Min	.6962	.8535	.9779	.8785	.4973	.7316
Avg	.7827	.9660	1.0830	1.1126	.8271	.8474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 203 / 11 KV Ainapur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7814	.5735	2.1052	1.749		
2		1.7814	.5898	2.1052	1.749		
3		1.8623	.6226	2.1052	1.749		
4		1.9595	.6554	2.1376	1.7166		
5		2.0243	.639	2.4034	1.8138		
6		2.0243	.639	2.4291	1.9757		
7		2.2348	.7045	2.4777	2.0891		
8		2.5911	.7373	2.7368			
9		2.5587	2.3266	2.6882			
10		2.672	2.2834				
11	2.7526					3.0769	2.2119
12	2.9656				2.8045		3.3589
13	2.8346				2.8654	2.9473	3.1131
14	2.9492				2.8045	.5182	3.0476
15	2.8673				2.9721	2.9473	3.2769
16	2.7035				2.7435	1.8461	3.1623
17	2.5101				2.9984	2.9959	3.0476
18					2.8673	2.6216	
24					1.7814		
Max	2.9656	2.672	2.3266	2.7368	2.9984	3.0769	3.3589
Min	2.5101	1.7814	.5735	2.1052	1.7166	.5182	2.2119
Avg	2.7976	2.1490	.9771	2.3543	2.3120	2.4219	3.0312

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 204 / 11 KV Hiralge(karmbali) Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3511	.4251	.3881	.4066	.3326	.3696	.3086
2	.3511	.4435	.3696	.3696	.3326	.3696	.2743
3	.3511	.4435	.3326	.3696	.3326	.4066	.3086
4	.3511	.462	.3326	.3696	.3696	.4066	.2743
5	.4251	.462	.4251	.4251	.4066	.3881	.3086
6	.462	.4805	.499	.462	.4251	.4435	.3429
7	.5175	.4805	.5175	.5175	.4251	.499	.4115
8	.462	.4805	.4805	.4805	.4435	.5359	.4115
9	.5729	.5544	.5729	.5359	.4066	.5729	.4115
10	.5544	.4805	.499	.4805		.499	.4458
11	.6283	.4801	.462	.5175	.4115	.5175	.5359
12	.5359	.4115	.5359	.499	.3772	.5175	.6219
13	.5359	.3429	.4805	.4066	.4115	.3696	.5175
14	.4251	.3429	.462	.4251	.2915	.3881	.4066
15	.4805	.3429	.4435	.4251	.2915	.4435	.5175
16	.5729	.4115	.499	.4066	.3772	.5175	.5914
17	.499	.4251	.5175	.3881	.4805	.5914	.5914
18		.5544	.5914	.5175	.5914	.583	.5544
19	.7392	.6283	.6653	.6099	.5544	.5487	.6653
20	.7207	.695	.7023	.6653	.7023	.6859	.7947
21	.5914	.6099	.6653	.7023	.6283	.5487	.7207
22	.5544	.5544	.5544	.5544	.5914	.4801	.5729
23	.462	.462	.4066	.462	.499	.4115	.499
24	.4066	.4251	.3881	.5175	.3696	.4251	.3429
Max	.7392	.695	.7023	.7023	.7023	.6859	.7947
Min	.3511	.3429	.3326	.3696	.2915	.3696	.2743
Avg	.5022	.4749	.4913	.4797	.4370	.4800	.4762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144069 / 33/11 KV KAULAGE

Feeder No / Name : 205 / KCL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191		.0189	.0189	.0191	.0189	.0191
2	.0191		.0189	.0189	.0191	.0189	.0191
3	.0191		.0189	.0189	.0191	.0189	.0191
4	.0191		.0189	.0189	.0191	.0189	.0191
5	.0191		.0189	.0189	.0191	.0189	.0191
6	.0191		.0189	.0189	.0191	.0189	.0191
7	.0191		.0189	.0189	.0191	.0189	.0191
8	.0191		.0189	.0189	.0191	.0189	.0191
9	.0191	.0189	.0189	.0189	.0191	.0189	.0191
10	.0189	.0189	.0189	.0189		.0189	.0191
11	.0189	.0191	.0189	.0189	.0191	.0191	.0189
12	.0189	.0191	.0189	.0189	.0191	.0191	.0189
13	.0189	.0191	.0189	.0189	.0191	.0191	.0189
14	.0189	.0191	.0189	.0189	.0191	.0191	.0189
15	.0189	.0191	.0189	.0189	.0191	.0191	.0189
16	.0189		.0189	.0189	.0191	.0191	.0189
17	.0189	.0189	.0189	.0189	.0189	.0191	.0189
18		.0189	.0189	.0191	.0189	.0191	.0191
19	.0189	.0189	.0189	.0191	.0189	.0191	.0191
20	.0189	.0189	.0189	.0191	.0189	.0191	.0191
21	.0189	.0189	.0189	.0191	.0189	.0191	.0191
22	.0189	.0189	.0189	.0191	.0189	.0191	.0191
23	.0189	.0189	.0189	.0191	.0189	.0191	
24	.0191	.0189	.0189	.0189	.0191	.0189	.0191
Max	.0191	.0191	.0189	.0191	.0191	.0191	.0191
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0190	.0190	.0189	.0190	.0190	.0190	.0190



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 201 / 11 KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.056	.1307	.1307	.1307	.056	.1307
2	.1494	.056	.056	.1307	.1307	.0373	.112
3	.1494	.056	.056	.0747	.1307	.056	.0934
4	.112	.056	.056	.0747	.112	.056	.0934
5	.0747	.056	.056	.0747	.0747	.056	.0934
6	.056	.0747	.056	.0747	.056	.056	.0934
7	.056	.056	.056	.0747	.056	.056	.3921
8	.056	.056	.0747	.0373	.056	.056	.3921
9	.056	.0747	.2054	.056	.056	.056	.4108
10	.3921	.4108	.3921	.3734	.0747	.0747	.4294
11	.4668	.5228	.2054	.4854	.1494	.1867	.4854
12	.1867	.5228	.1867	.5041	.1494	.168	.1494
13	.4668	.5041	.168	.112	.1307	.168	.1307
14	.0739	.112	.0934	.0747		.0934	.0678
15	.1867	.2241	.0934	.1494		.1867	.1867
16	.5041	.2054	.0934	.1494	.1494	.1867	.1867
17	.4854	.1867	.0747	.1867	.168	.1867	.1867
18	.5228	.168	.168	.1867	.1867	.1867	.1867
19	.168	.168	.1494	.168	.1494	.168	.1494
20	.0934	.0934	.168	.1494	.1307	.0747	.0934
21	.056	.0747	.1867	.0934	.056	.0747	.0747
22	.0747	.1494	.1494	.0934	.1307	.112	.0934
23	.1307	.1307	.168	.1307	.1307	.1307	.168
24	.1494	.1307	.1307	.1307	.1307	.112	.1307
Max	.5228	.5228	.3921	.5041	.1867	.1867	.4854
Min	.056	.056	.056	.0373	.056	.0373	.0678
Avg	.2007	.1727	.1323	.1548	.1154	.1081	.1888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144075 / 33/11 KV MIDC Sub-Station

Feeder No / Name : 202 / Shendri AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0701	.4191	.373		.4239	.056	.0554
2	.0351	.4191	.2543		.4409	.0373	.0554
3	.0351	.4191	.2883		.4239	.0373	.037
4	.0351	.4359	.3391		.4748	.056	.037
5	.0526	.4527	.4239			.056	.056
6	.0876	.503	.5087		.5256	.0747	.0554
7	.1227	.7042	.8139		.7461	.0934	.1109
8	.0876	.9556	1.0513		.8987	.0934	.1294
9	.0876	.9724	1.0513	.8817	.9326	.0934	.0924
10	.1227	.8048	.9156	.9665	.0701	.1294	.1109
11	.9556	.0739	.0924	.8309		1.0513	1.0513
12	1.2407	.0739	.0739	.0526		1.1544	1.153
13	1.1401	.0739	.0739	.0701	.8718	1.1822	1.153
14	1.1233	.0739	.0739	.1052		1.1498	1.153
15	.9892	.0739	.0739	.0701		1.153	1.2209
16	1.073	.0739	.0924		.7209	1.1822	1.2209
17	1.1233	.0905	.0924	.1052	1.0562	1.2146	1.0513
18	.9556	.0905	.0739	.1052	.9389	1.1869	.9156
19	.0934	.1267	.1294	.1052	.112	.0739	.128
20	.112	.1448	.1109	.0701	.1109	.1294	.128
21	.112	.1448	.112	.0876	.1307	.112	.1097
22	.112	.1086	.112	.0876	.112	.1109	.1097
23	.0924	.1086	.0924	.0526	.0747	.0739	.0914
24	.0876	.0747	.0905	.0924	.4239	.0747	.0739
Max	1.2407	.9724	1.0513	.9665	1.0562	1.2146	1.2209
Min	.0351	.0739	.0739	.0526	.0701	.0373	.037
Avg	.4144	.3091	.3047	.2455	.4994	.4407	.4291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 201 / Nool Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547	.3801	.3544	.3898	.3189	.3189	.3189
2	.362	.362	.3544	.3898	.3189	.3189	.3189
3	.3982	.3734	.3544	.3898	.3189	.3189	.3189
4	.3982	.4481	.3898	.4252	.3366	.3544	.3898
5	.394	.4755	.4252	.4784	.3544	.3898	.4252
6	.4207	.4748	.4607	.5138	.3544	.443	.5138
7	.4207	.4668	.4075	.443	.3898	.4252	.5316
8	.4382	.4344	.4075	.443	.4075	.443	.5316
9	.443	.4161	.3856	.4344	.4163	.4854	.4344
10	.443	.4801	.4681	.3258	.4163	.5093	.4668
11	.4784	.4252	.3982	.4525	.3801	.6154	.4706
12	.4607	.4298	.3982	.4706	.2353		.4344
13	.4252	.5014	.4607	.4525	.2353	.5249	.4344
14	.443	.4854	.4961	.5068	.2353		.1294
15	.3721	.4557	.5068	.4706	.181	.5068	.4607
16	.4252	.4854	.4758	.3801	.3258	.4706	.394
17	.4163	.4706	.4458	.4481	.4557	.4854	
18	.4344	.4887	.5201	.4481	.5373	.5601	.3772
19	.7059	.4887	.6661	.7291	.6722		.6584
20	.7059	.4887	.8688	.8029	.7783	.7842	.3801
21	.6783	.443	.691	.8029	.7087	.6379	.5316
22	.5601	.5493	.5316	.6556	.5138	.5316	
23	.4668	.443	.4784	.4075	.4075	.4607	.3898
24	.4163	.3921	.3721	.4252	.3544	.3189	.3189
Max	.7059	.5493	.8688	.8029	.7783	.7842	.6584
Min	.3547	.362	.3544	.3258	.181	.3189	.1294
Avg	.4609	.4524	.4716	.4869	.4022	.4716	.4195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 202 / Bhadgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	.6783	.9555	1.0364	.0972	.081	.0972
2	.0914		.9878	1.0364	.0819	.0648	.0972
3	.0701	.7459	.9878	1.0688	.081	.0648	.0972
4	.0701	.8288	1.0526	1.1498	.081	.081	.0972
5	.0701	1.1603	1.166	1.2146	.0972	.0972	.1134
6	.0686	1.3426	1.3603	1.3603	.1134	.1296	.1296
7	.1187	1.7126	1.7976	1.5708	.1296	.1134	.1457
8	.1578	1.8233	1.8842	1.8785	.1943	.1619	.1781
9	.1638	1.5384	1.8842	1.2631	.2641	.1629	.2353
10	.1619	1.6907	1.8067	.1307	.2534	.1629	.1991
11	2.0729	.2286	.1905	.2035	1.8947	1.9595	2.0729
12	1.8947	.2096	.2286	.2195	1.9595		2.2708
13	2.0729	.1715	.1524	.1991	1.9433		2.2283
14		.1715	.1715	.0943	1.9271		2.2298
15	1.8138	.1715	.1905	.0934	1.9595		1.8778
16	1.8785	.1715	.1905	.0905	2.0891	2.332	
17	1.9919	.1629	.1905	.0934	2.0553	2.2382	
18	1.7814	.168	.2263	.0747	1.917	2.0856	1.6766
19	.1448	.181	.2075	.2054	.1867		.2096
20	.1267	.181	.2096	.2054	.181	.2054	.1698
21	.1357	.1619	.1943	.1357	.1457	.1619	.1457
22	.112	.1296	.1475	.1296	.1147	.1772	
23	.112	.1134	.1457	.0972	.0972	.1296	.1134
24	.0905	.0905	.0972	.1457	.0972	.081	.1134
Max	2.0729	1.8233	1.8842	1.8785	2.0891	2.332	2.2708
Min	.0686	.0905	.0972	.0747	.081	.0648	.0972
Avg	.6649	.6015	.6844	.5707	.7484	.5521	.6904

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 203 / Chennikuppi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348	.0848	.0983	.0983	.5898	.639	.6554
2	.5935	.0848	.0819	.0983	.5898	.639	.6554
3	.6443	.1029	.0819	.0983	.5898	.6718	.6554
4	.6783	.1187	.0983	.0983	.639	.7045	.6882
5	.7042	.1187	.1311	.0983	.6718	.7865	.7865
6	.7625	.1187	.1475	.1147	.7537	.9175	.9667
7	1.1191	.1494	.1475	.1638	1.065	1.2289	1.1469
8	1.2887	.1448	.1475	.1802	1.1961	1.4419	1.3435
9	1.2125	.1524	.1524	.181	1.1336	1.0395	1.2793
10	1.1142	.1524	.1524	.181	.1086	.1267	.1086
11	.1147	1.2163	1.0753	1.1174	.1448	.1086	.1494
12	.1147	1.2176	1.1385	1.1174	.1267		.1905
13	.1311	1.1717	1.1728	1.1336	.1267	.1086	.1905
14	.1311	1.012	1.1405	1.1012	.1448		.1334
15	.0972	1.1203	1.2186	1.1174	.1448	.1086	.1143
16	.1311	1.2334	1.2498	1.166	.1448	.0905	.1509
17	.1448	1.2631	1.2498	1.3565	.1524	.1307	
18	.1886	1.2631	1.1561	1.262	.1715	.1494	.1143
19	.1629	.181	.2286	.2241	.1867		.1715
20	.181	.181	.2096	.2241	.2172	.2054	.1696
21	.1526	.1638	.1619	.8029	.1802	.1802	.1802
22	.1307	.1475	.1457	.1638	.1638	.1457	
23	.0934	.1147	.1147	.1311	.1311	.1311	.1311
24	.1448	.0934	.0983	.0983	.5571	.5735	.6062
Max	1.2887	1.2631	1.2498	1.3565	1.1961	1.4419	1.3435
Min	.0934	.0848	.0819	.0983	.1086	.0905	.1086
Avg	.4446	.4836	.4833	.5137	.4137	.4823	.4813

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 204 / Guddai AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3506	.5243	.6062			
2		.4382	.5243	.5898			
3		.5068	.5243	.5898			
4		.5087	.5571	.5898			
5		.5935	.5898	.639			
6		.6783	.6443	.6882			
7		.7969	.7045	.7701		.0655	.0655
8		.8478	.8356	.8356	.0655	.0819	.0983
9	.0655	.9069	.8421	.8907	.0905	.0724	.0754
10		.8421	.7935	.0905		.0905	.0943
11	.8848			.0724	.9231	.8421	1.0364
12	.852	.0732			.9393		1.0883
13	.9667	.0739			.9393	1.1012	1.0688
14	.9339	.0905		.0724	.9393		1.0402
15	1.0486	.0709		.0724	.9878	1.004	1.1012
16	1.0277			.0724	1.0202	1.0526	1.065
17	1.0364			.0934	.9014	1.0974	
18	1.004			.0934	.8855	1.1203	.664
19	.0724		.0895	.0934	.0934		.0693
20	.0724		.0886	.112	.1086	.0934	.0724
21				.0934	.0819	.0819	.0655
22	.0747		.0655	.0655	.0655		
23			.0709				
Max	1.0486	.9069	.8421	.8907	1.0202	1.1203	1.1012
Min	.0655	.0709	.0655	.0655	.0655	.0655	.0655
Avg	.6699	.4842	.4896	.3565	.5744	.5586	.5432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 205 / 11 KV JARALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7522	.0876	.1311	.0983	.9175	1.0159	.9175
2	.78	.0848	.1311	.0983	.9503	1.0159	.9175
3	.8478	.1187	.1311	.0983	.9503		.9175
4	.9116	.12	.1311	.0983	.9995	1.0978	.9503
5	1.0774	.12	.1311	.1147	1.0978	1.1633	.9503
6	1.4243	.12	.1311	.1311	1.2125	1.3272	1.0486
7	1.8652	.1829	.1475	.1475	1.5074	1.5238	
8	1.9839	.181	.1638	.1638	1.6385	1.7532	1.3763
9	1.8187	.1753	.1595	.1991	1.6356	1.7013	1.4575
10	1.7204	.1646	.1791	.2241	.1991	.1448	.1629
11	.1475	2.0233	2.1026	1.9109	.1509	.1357	.168
12	.1311	1.4255	2.2382	1.9757	.1086		.1478
13	.1311	2.1026	2.079	2.0081	.1132	.1448	.1433
14	.1311	1.6956	2.0454	1.8947	.1086		.1052
15	.1311	1.989	2.0622		.1086	.1448	.1227
16	.1311	2.1026	2.1704	1.8947	.1494	.1448	.1402
17	.1629	2.0622	2.0454	2.0517	.1734		
18	.2075	1.9595	1.9113	1.8991	.1907	.2054	.1578
19	.1629	.1991	.2012	.1867	.2427		.1753
20	.181	.1991	.181	.1867	.2172	.1867	.1448
21	.1526	.1638		.168	.1802	.1475	.1311
22	.1494	.1475	.1311	.1475	.1475	.1311	
23	.112	.1311	.1311	.1147	.1311	.1311	.1311
24	.1463	.0934	.1311	.1147	.8848	.9831	.852
Max	1.9839	2.1026	2.2382	2.0517	1.6385	1.7532	1.4575
Min	.112	.0848	.1311	.0983	.1086	.1311	.1052
Avg	.6358	.7354	.8203	.6925	.5840	.6894	.5294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144089 / 33/11KV Bhadgaon s/stn

Feeder No / Name : 206 / 11 KV SAMARTHANAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.1865	.1772	.1595	.1772	.1417	.1417
2	.1865	.1753	.1595	.1595	.1772	.1417	.1417
3	.2058	.181	.1595	.1595	.1772	.1417	.1417
4	.2035	.1886	.1772	.1595	.1949	.1595	.1595
5	.2035	.1886	.1949	.1772	.2303	.1595	
6	.2374	.2035	.2303	.1949	.2658	.1949	.1949
7	.2279	.2614	.2303	.1949	.2481	.2835	.1949
8	.2012	.2427	.2481	.2126	.2303	.2126	.1772
9	.2303	.2149	.2303	.1509	.2452	.181	.1991
10	.1772	.1886	.2172	.1886	.2715	.2641	.2263
11	.1772	.2241	.2804	.1886	.2614	.2353	.2263
12		.1791	.3467	.1886	.2263		.2195
13	.1772	.1524	.1886		.2172	.1267	.1829
14	.1772	.1524	.2454	.1509	.1991		.2075
15	.2126	.2096	.2534	.1448	.1448	.181	.2218
16	.2303	.2172	.2195	.1698	.1629	.1448	1.9784
17	.2075	.2263	.2254	.1867	.1463	.1867	
18	.2172	.181	.208	.1928	.1595	.168	.1867
19	.3077	.3258	.2772	.2801	.2427		.2801
20	.3439	.3395	.3142	.3361	.2715	.3361	.3258
21	.3174	.3189	.2303	.2987	.2658	.3189	.2835
22	.2987	.2658	.2303	.2658	.2481	.2835	
23	.2614	.2126	.1949	.2126	.2126	.2481	.2126
24	.1991	.2054	.1772	.1772	.1949	.1772	.1772
Max	.3439	.3395	.3467	.3361	.2715	.3361	1.9784
Min	.1772	.1524	.1595	.1448	.1448	.1267	.1417
Avg	.2264	.2184	.2257	.1978	.2155	.2041	.2895



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 201 / 11 KV Nilaji Gaothan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.679	.695	.5716	.6413	.695	.6283
2	.5716	.6413	.695	.5716	.6413	.695	.5914
3	.5716	.6413	.695	.5716	.6413	.695	.5914
4	.5716	.6413	.695	.6097	.5658	.695	.5544
5	.6478	.679	.7133	.6478	.6413	.695	.6219
6	.8383	.8299	.7682	.6859	.8299	.7682	.6653
7	.7545	.8501	.8048	.7545	.7167	.8413	.7762
8	.6722	.7682	.7316	.6722	.7167	.8048	.7316
9	.6584	.8589	.7316	.7762	.5853	.7682	.695
10	.6584	.8871	.7602	.6401	.6584	.8048	
11	.6584	.8589	.7164	.6401	.6584	.7682	
12	.6584	.7796	.724	.6401	.6219	.7316	.6089
13	.6767	.7392	.5373	.5853	.5121	.7023	.5792
14	.695	.5175	.5792	.5487		.6584	.6154
15	.7316	.6219	.5609	.695	.5487	.6584	.5792
16	.7316	.6219	.567	.5068	.5487	.695	.6089
17	.6447	.6219	.6024	.6219	.5487	.6584	.6379
18	.6661	.7316	.6584	.6584	.695	.5853	.6733
19	.9709	.8779	.9335	.8871	.9242	.9511	.961
20	1.2071	1.0242	1.094	1.0456	1.0185	1.1827	1.1203
21	1.1694	1.0242	.9808	.9709	1.0242	1.0974	1.0185
22	1.0562	.9145	.9054	.9431	.9145	.9511	.8764
23	.9054	.8413	.8002	.7922	.7682	.8048	.7621
24	.724	.7545	.695	.6859	.679	.695	.6584
Max	1.2071	1.0242	1.094	1.0456	1.0242	1.1827	1.1203
Min	.5716	.5175	.5373	.5068	.5121	.5853	.5544
Avg	.7537	.7669	.7352	.6968	.7000	.7751	.7070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 202 / HITANI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.852	.1132	.1829	.1307	.8684	1.0059	.5182
2	.8356	.1132	.1829	.1307	.9175	1.0059	.5243
3	.8356	.112	.1829	.1307	.9175	1.0059	.5121
4	.8848	.1132	.1829	.1307	.9012	1.0059	.5693
5	.9339	.1509	.2561	.168	.8951	1.0059	.6722
6	1.0277	.2987	.3292		.7377	1.0974	.8642
7	1.3923	.3734	.3475	.3395	1.1736	1.3169	1.0753
8		.3326	.4024	.4435	1.4413	1.1544	1.2334
9	1.39	.3292	.3696	.5359	1.1702	1.1683	1.1271
10	1.39	.3475	.3475	.5304	.2172	.3142	
11	.1097	1.5729	1.4752	1.4632	.2195	.2957	
12	.1463	1.6907	1.5083	1.4998	.2195	.2587	.2328
13	.1646	1.6244	1.4251	1.5546	.2012	.2195	.2328
14	.1646	1.3765	1.3765	1.5546		.2195	.2149
15	.1646	1.6461	1.3279	1.5729	.1646	.1829	.1595
16	.1578	1.6461	1.4575	1.3763	.1646	.128	.1772
17	.2328		1.5729	1.3279	.1698	.181	.1772
18	.2378	1.6461	1.4419	1.2146		.2561	.197
19	.2378	.1463	.2427	.2241	.1646	.2195	.1867
20	.2241	.1463	.2263	.2241	.1646	.2507	.2452
21	.1886	.1463	.168	.2075	.1463	.2561	.2054
22	.1867	.1646	.1698	.168	.128	.2195	.1867
23	.1509	.1646	.1494	.1494	.128	.1478	.1629
24	.112	.132	.1829	.1509	.8192	1.0059	.5182
Max	1.3923	1.6907	1.5729	1.5729	1.4413	1.3169	1.2334
Min	.1097	.112	.1494	.1307	.128	.128	.1595
Avg	.5226	.6255	.6462	.6621	.5423	.5801	.4542

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 203 / HASURCHAMPU AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.8356	1.3717	.9012	.1307	.1097	.1109
2	.1143	.8065	1.3717	.9012	.1307	.1646	.1109
3	.1143	.8162	1.3717	.9012	.1307	.1097	.1097
4	.1334	.8259	1.3717	.9012	.1294	.1097	.1109
5	.1524	.8848	1.4266	.9503	.1294	.1097	.128
6	.168	.9393	1.4815	.9945	.1867	.128	.128
7	.1905	1.3441	1.6644	1.2955	.168	.1463	.1478
8	.168	1.4899		1.5364	.1307	.1097	.1294
9	.1698	1.3272	1.3904	1.4918	.1294	.1097	.1132
10	.1646	1.2955	1.2654	1.6461	.1463	.128	
11	1.7918	.1478	.1294	.0732	1.3599	1.4232	
12	1.829	.1294	.128	.0914	1.5364	1.6518	1.587
13	1.9204	.1109	.1086	.1097	1.4548	1.5684	1.4899
14	1.9204		.1086	.1097		1.5813	1.3763
15	1.9239	.1097	.1294	.1097	1.4563	1.5364	1.3763
16	1.6194	.128	.1478	.128	1.6461	1.4864	1.278
17	1.5497	.128	.1294	.128	1.6975	1.4723	
18	1.3748	.128	.168	.1494	1.6032	1.2651	.7537
19	.168	.128	.1698	.1867	.1097	.128	.1334
20	.168	.128	.1509	.1867	.1097	.1463	.1334
21	.1867	.128	.1524	.1867	.1097	.1478	.1334
22	.1663	.128	.1524	.1478	.1097	.128	.1143
23	.1478	.128	.1334	.128	.128	.1109	.0934
24	.1524	.1109	.128	.1143	.1294	.1097	.1097
Max	1.9239	1.4899	1.6644	1.6461	1.6975	1.6518	1.587
Min	.1143	.1097	.1086	.0732	.1097	.1097	.0934
Avg	.6837	.5303	.6370	.5570	.5592	.5825	.4604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

GADHINGLAJ[025]

BU 1121

Substation No/ Name :- 144096 / 33/11KV Hebbal (K Nool)

Feeder No / Name : 204 / 11KV Hirnyakeshi

SHEDDABLE FEEDER MIDC EQUIVALENT

Industrial Ex Feeder KV- 11 /  
OUTGOING

HAVING WEEKLY STAGGERING

DATE	30-MAR-18	31-MAR-18	01-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0914	.0762	
2		.0914	.0762	
3		.0914	.0762	
4		.0914	.0762	
5		.0914	.0762	
6	.0754	.0914		
7	.0943	.0914		
8	.0943	.0914		
9	.0754	.0943		
10	.0914	.1132		
11	.1509	.0709		
12	.1143	.0914		
13	.132	.1307		.112
14	.1109	.1509		.1132
15	.1097	.1143		.1132
16	.1097	.1109		.1132
17	.1097	.0934		.1132
18	.1097	.112		.1109
19	.1097	.0953		.0747
20	.1097	.0724		
21	.1097	.0762		
22	.1097	.0762		
23	.1097	.0762		.0732
24		.1097	.0762	
Max	.1509	.1509	.0762	.1132
Min	.0754	.0709	.0762	.0732
Avg	.1070	.0966	.0762	.1030

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 201 / 11 KV Halkarni Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9415	.1905	.2282	.1905	.4795	.5922	.5133
2	.8907	.1715	.2096	.1524	.471	.5468	.6139
3	.8792	.1698	.2087	.1334	.4999	.5481	.7287
4	.8431	.1898	.2275	.1524	.5588	.628	.8116
5	.933	.2464	.2667	.1905	.6394	.7056	.8492
6		.3409	.3402	.3036	.7655	.7711	.8172
7	.8894	.3772	.3395	.3402	1.0487	1.0267	1.1095
8	1.1254	.354	.2649	.3006	1.1502	1.1069	1.3117
9	1.2004	.3187	.2641	.3184	1.1083	.7572	1.18
10	.9506	.2603	.2996	.2996	.2071	.2945	.2627
11	.2268	.9854	1.0242	1.1688	.2222	.1877	.2635
12	.2254	.8845	1.0501	1.0229	.1858	.189	.2243
13	.2447	1.0084	.9419	1.0068	.2218	.1698	.263
14	.2263	1.0286	.8642	.9521	.2412	.1894	.2079
15	.189	1.0531	.9061	.9521	.2603	.2268	.2081
16	.2064	1.0858	1.0084	1.0936	.2614	.2263	.2625
17	.3354		.9576	1.1321	.3566	.2257	.2821
18	.3749	1.0235	.8685	.9816	.3576	.3537	.3381
19	.3761	.3405	.3395	.3933	.3969	.3378	.3761
20	.3965	.3784	.3784	.3969	.3977	.3973	.415
21	.3412	.3772	.3412		.4351	.3803	
22	.3784	.3584	.2849	.3788	.3598	.3409	.3412
23	.2469	.3036	.2846	.2657	.303	.3226	.3027
24	.3027		.2659	.2469	.5305	.5893	.439
Max	1.2004	1.0858	1.0501	1.1688	1.1502	1.1069	1.3117
Min	.189	.1698	.2087	.1334	.1858	.1698	.2079
Avg	.5532	.5203	.5069	.5380	.4774	.4631	.5270

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 202 / 11 KV Hiduggi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2252	.7116	.9755	.5937	.1886	.2273	.2068
2	.2263	.7636	.9662	.6916	.1701	.2087	.2241
3	.2079	.6394	1.0059	.758	.1698	.2092	.2464
4	.2085	.7159	.9476	.8467	.1905	.1898	.2662
5	.1899	.9194	.9851	1.0947	.1905	.2275	.2667
6		1.1372	1.1509	1.2551	.2662	.2657	.2858
7	.2273	1.2727	1.4481	1.5026	.3039	.2841	.3048
8	.2259	1.5181	1.652	1.7181	.2654	.245	.3223
9	.2263	1.5191	1.6347	1.6485	.2158	.2275	.3033
10	.2698	1.3326	1.4811	.2259	.2395	.2021	.2766
11	1.4108	.1696	.2072	.2399	1.4793	1.3441	1.6452
12	1.5327	.1884	.2054	.2702	1.6624	1.3748	1.6964
13	1.5016	.1882	.1968	.244	1.4547	1.4335	1.6307
14	1.3625	.1869		.2257	1.4932	1.4146	1.3376
15	1.4009	.2054	.2341	.32	1.439	1.3966	1.573
16	1.486	.225		.2179	1.49	1.3714	1.6684
17	1.6304	.2427	.1998	.1872	1.4864		1.3667
18	1.4925	.2625	.2264	.2791	1.4355	1.0287	1.1168
19	.2179	.3203	.298	.296	.2518		.2593
20	.259	.32	.332	.3381	.2758	.32	.2987
21	.2587	.3203	.3519		.2809	.3562	
22	.2587	.3	.332	.2987	.2625	.3197	.2917
23	.2587	.2993	.3354	.2598	.2625	.3009	.2963
24	.2435	.2587	.263	.322	.2462	.2457	.2617
Max	1.6304	1.5191	1.652	1.7181	1.6624	1.4335	1.6964
Min	.1899	.1696	.1968	.1872	.1698	.1898	.2068
Avg	.6661	.5840	.7013	.6015	.6550	.5997	.7020

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 203 / 11 KV nagnoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5568				.2401	.2361	.3157
2	.5237				.2545	.2214	.333
3	.4687				.2558	.2227	.2977
4	.4715				.3163	.2401	.2792
5	.5218	.0191			.3227	.2898	.3106
6		.0191			.325	.3266	.3258
7	.4215				.4566	.4225	.4577
8	.5139				.5133	.4841	.585
9	.463				.4481	.3786	.5275
10	.4059						
11		.4707	.4091	.4181			
12		.502	.3909	.4116			
13		.4502	.3508	.4067			
14		.4492	.3056	.3382			
15		.4102	.3225	.3558			
16		.4558	.3849	.4057			
17		.4624	.4542	.4721			
18		.3844	.4422	.4348			
24					.2259	.2355	.3049
Max	.5568	.502	.4542	.4721	.5133	.4841	.585
Min	.4059	.0191	.3056	.3382	.2259	.2214	.2792
Avg	.4830	.3623	.3825	.4054	.3358	.3057	.3737

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 204 / 11 KV HALKARNI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2092	.1905	.2286	.1905	.2286	.2286	.2286
2	.2096	.1715	.2089	.1524	.1715	.2286	.2286
3	.1905	.1715	.189	.1715	.1524	.2096	.2096
4	.1905	.1905	.1905	.1334	.1715	.2096	
5	.1905	.2286	.2085	.1524	.2286	.2667	.2477
6		.2662	.2667	.2477	.2667	.3042	.2858
7	.2996	.3395	.321	.2625	.3003	.3015	.3015
8	.2781	.296	.2593	.2929	.2609	.2945	.2609
9	.2561	.2537	.2561	.2531	.2209	.2218	.24
10	.2271	.2154	.3022	.2529	.2124	.2256	.2124
11	.2459	.216	.2318	.2534	.1804	.2817	.2518
12	.2286	.2177	.2301	.282	.2179	.2804	.2481
13	.2499	.2746	.3012	.2598	.2336	.2303	.2881
14	.2507	.2012		.2131	.2388	.2526	.2365
15	.2365	.2215	.2195	.2336	.2243	.2518	.2726
16	.251	.2301	.2491	.2454	.1844	.2686	.2515
17	.2798	.2454	.2371	.3049	.2343	.3353	.2632
18	.3045	.31	.2774	.2743	.2808	.2782	.3002
19	.3498	.428	.341	.357	.3054	.3737	.3559
20	.4335	.4367	.3845	.4176	.3547	.4041	.4399
21	.3333	.3742	.2545		.3742	.3727	
22	.3006	.3381	.3197	.3757	.321	.3388	.3385
23	.2643	.2662	.2657	.3027	.2657	.2844	.303
24	.2279	.2462	.2472	.2286	.2659	.2667	.2641
Max	.4335	.4367	.3845	.4176	.3742	.4041	.4399
Min	.1905	.1715	.189	.1334	.1524	.2096	.2096
Avg	.2612	.2637	.2604	.2547	.2456	.2796	.2740



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 205 / 11 KV Hidduggi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9044	.8029	.9768	.9531	.7138	.756	.9531
2	.8488	.7514	.9174	1.0028	.6528	.7196	.9347
3	.8505	.6555	.8916	.9097	.5613	.7182	.8843
4	.8151	.7282	.8448	.877	.7095	.7545	.963
5	.759	.7898	.8257	.955	.5618	.9205	1.0982
6		1.0829	.8907	1.0686	.4513	1.2235	1.1354
7	.5201	.9393	1.2856	1.1434	.4467	.6309	.5527
8	1.1446	1.2109	1.1487	1.1523	.3885	1.0641	.9907
9	1.1352	.4266	1.1669	1.0018	1.0686	.9887	.3813
10	.4248	.4306	1.069	.4243	.9918	.486	.3494
11	.3685	.3813		.3658	.7073	.3643	.3654
12	.3857	.4307	.2987	.3994	.3482	.3805	.365
13	.2497	.3805	.3845	.3354	.3344	.3685	.3869
14		.3443	.3833	.3184	.3696	.3841	.3837
15	.3662	.3635	.3901	.3479	.4091	.3869	.3837
16	.4028	.4262	.4242	.3631	.4041	.3719	.3861
17	.3781	.422	.4348	.3906	.4015	.4243	.428
18	.4154	.4641	.3805	.3902	.4376	.4166	.4137
19	.5487	.5447	.6936	.6128	.5153	.5804	.6433
20	1.2012	1.3059	1.2109	1.3224	1.2395	1.4355	.8333
21	1.3251	1.0881	1.1988		1.1505	1.2803	
22	.6728	1.008	1.173	1.1852	1.2096	1.2369	1.11
23	.9307	.9997	.9699	.956	1.0847	1.1296	1.1986
24	.9383	.898	.9906	.9561	.8215	.7922	1.0608
Max	1.3251	1.3059	1.2856	1.3224	1.2395	1.4355	1.1986
Min	.2497	.3443	.2987	.3184	.3344	.3643	.3494
Avg	.7084	.7031	.8239	.7579	.6658	.7423	.7044

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144057 / 33/11 KV HALKARNI

Feeder No / Name : 206 / 11 KV Nagnoor Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1704	.1711	.1326	.1327	.1334	.1701	.1524
2	.1708	.1711	.1143	.0761	.1334	.1515	.1143
3	.1521	.1524	.1141	.076		.1328	.1334
4	.1521	.1524	.1328	.1326		.1331	.1524
5	.1715	.1715	.1524	.1521	.1715	.1896	.1715
6		.1706	.1899	.152	.1892	.2268	.1892
7	.2257	.1509	.1884	.1869	.1875	.2243	.2062
8	.2041	.1837	.1636	.1991	.1819	.2031	.1829
9	.1475	.1451	.1619	.16	.1428	.181	.148
10	.1755	.1407	.1416	.1564	.1402	.1559	.1696
11	.1469	.106	.143	.1396	.1468	.1417	.1446
12	.165	.1234	.1291	.1562	.1405	.1596	.1093
13	.1804	.1439	.1443	.1569	.1463	.1622	.1471
14	.1636	.1276	.1108	.1442	.166	.1646	.1478
15	.1477	.1283	.1466	.1608	.1648	.1475	.1276
16	.15	.1584	.143	.1595	.1605	.168	.1411
17	.1408	.1699	.1379	.1753	.2058	.1698	.1554
18	.1734	.1717	.1878	.1707	.2241	.1757	.1732
19	.2529	.2741	.341	.2908	.322	.3275	.2569
20	.3658	.3326	.3125	.3306	.3526	.3711	.3326
21	.3168	.2804	.2579		.3361	.3	
22	.2641	.2083	.2259	.2442	.2638	.2445	.2257
23	.2263	.1509	.1886	.1689	.2247	.2064	.1879
24	.2077	.1882	.1512	.1512	.1506	.1886	.1512
Max	.3658	.3326	.341	.3306	.3526	.3711	.3326
Min	.1408	.106	.1108	.076	.1334	.1328	.1093
Avg	.1944	.1739	.1713	.1684	.1948	.1956	.1704

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 201 / 11 KV Kowad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.9145	.7888	.8505	.0381	.0381	.0347
2	.0343	.9145	.7888	.8505	.0381	.0381	.0347
3	.0343	.9145	.7888	.8505	.0381	.0381	.0347
4	.0343	.9145	.7888	.8505	.0381	.0381	.0347
5		.9145	.7888	.8505	.0381	.0381	.0347
6	.0343	.9145	.7888	.8505	.0381	.0381	.0347
7	.0343	1.1812	.8916	.9568	.0381	.0381	.0347
8		1.3717	.9602	1.1694	.0381	.0381	.0347
9	.0347	1.2193	1.0288	1.2403	.0381	.0343	.0347
10	.0347	1.2574	.8916	.0347	.0381	.0343	
11	1.2757	.0381	.0343	.0347		1.3717	.8505
12	1.3112	.0381	.0343	.0354		1.4403	1.5592
13	1.4175	.0381	.0343	.0347		1.5432	1.5238
14	1.4175	.0381	.0343	.0347		1.5089	1.5238
15	1.382	.0953	.0343	.0347	1.3336	1.3717	1.4883
16	1.3466	.0381	.0343	.0347	1.4098	1.3717	1.4883
17	1.3112	.0381	.0343	.0347	1.4098	1.3717	1.4883
18	1.2757	.0381	.0343	.0347	1.3717		1.4529
19	.0347	.0381	.0343	.0347	.0381		.0347
20	.0347	.0381		.0347	.0381		.0347
21		.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381		.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0343	.0381	.0381	.9145	.0381	.0381	.0381
Max	1.4175	1.3717	1.0288	1.2403	1.4098	1.5432	1.5592
Min	.0343	.0381	.0343	.0347	.0381	.0343	.0347
Avg	.5330	.4628	.4058	.4117	.3067	.5002	.5178

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 202 / 11 KV Talewadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	1.5242	1.3717	1.4175	.0381	.0381	.0347
2	.0343	1.5242	1.3717	1.4175	.0381	.0381	.0347
3	.0343	1.5242	1.3717	1.4175	.0381	.0381	.0347
4	.0343	1.5242	1.3717	1.4175	.0381		.0347
5	.0343	1.5242	1.3717	1.4175	.0381	.0381	.0347
6	.0343	1.5242	1.3717	1.4175	.0381	.0381	.0347
7	.0343	2.2862	1.8519	1.9136	.0381	.0381	.0347
8		2.5149	2.1948	2.4143	.0381	.0381	.0347
9	.0347	2.2862	2.2634	2.4806	.0381	.0343	.0347
10	.0347	2.4387	2.0576	.0347	.0381	.0343	
11	2.4097	.0381	.0343	.0347		2.4006	2.6223
12	2.6223	.0381	.0343	.0347		2.5034	2.8349
13	2.8349	.0381	.0343	.0347		2.6406	2.6932
14	2.8349	.0381	.0343	.0347		2.572	2.8349
15	2.7641	.0381	.0343	.0347	2.5911		2.5514
16	2.6932	.0381	.0343	.0347	2.7435		2.268
17	2.4806	.0381	.0343	.0347	2.7435		2.5514
18	2.3388	.0381	.0343	.0347	2.8959		2.4097
19	.0347	.0381	.0343	.0347	.0381		.0347
20	.0347	.0381		.0347	.0381		.0347
21		.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381		.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0343	.0381	.0381		.0381	.0381	.0381
Max	2.8349	2.5149	2.2634	2.4806	2.8959	2.6406	2.8349
Min	.0343	.0381	.0343	.0347	.0381	.0343	.0347
Avg	.9758	.8002	.7737	.6874	.5792	.6238	.9261

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 203 / 11 KV Batakanangle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0919	.0381	.0343	.0347	2.6673	2.3624	2.4806
2	2.0919	.0381	.0343	.0347	2.6673	2.3624	2.4806
3	2.0576	.0381	.0343	.0347	2.6673	2.3624	2.4806
4	2.0576	.0381	.0343	.0347	2.6673	2.3624	2.4806
5	2.0919	.0381	.0343		2.6673	2.3624	2.4806
6	2.1262	.0381	.0343	.0347	2.6673	2.4387	2.4806
7	2.5377	.0381	.0343	.0347	3.0483	2.6673	3.0476
8		.0381	.0343	.0347	3.1245	2.8959	3.0476
9	2.6932	.0381	.0343	.1734	3.1245	2.5377	2.9767
10	2.4806	.0381	.0343	.1387		.0343	
11	.104	2.7435	2.1948	2.8349		.0343	.104
12	.104	3.2769	2.7435	2.9058		.0343	.104
13	.104	3.2769	2.8464	2.8349		.0343	.104
14	.104	3.1245	2.915	2.8349		.0343	.104
15	.104	3.2007	2.915	2.9058	.0762	.0343	.104
16	.104	3.2769	2.9835	3.0476	.0762	.0343	.104
17	.1387	3.3532	3.0178	2.9767	.0762	.0343	.104
18	.1387	3.0483	2.8121	2.8349	.0762		.1387
19	.1734	.0762	.0343	.104	.0762		.1734
20	.208	.0762		.208	.0762		.208
21		.0381	.0381	.0381	.0762	.0381	.0381
22	.0381	.0381		.0381	.0762	.0381	.0381
23	.0381	.0381	.0381	.0381	.0762	.0381	.0381
24	.0343	.0381	.0381	.0381	2.6673	2.2862	2.6673
Max	2.6932	3.3532	3.0178	3.0476	3.1245	2.8959	3.0476
Min	.0343	.0381	.0343	.0347	.0762	.0343	.0381
Avg	.9828	1.0828	1.0418	1.0520	1.5081	1.1917	1.2167

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 204 / 11 KV Talewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1524	.1372	.1417	.1524	.1905	.2481
2	.1715	.1524	.1372	.1417	.1524	.1905	.2481
3	.1715	.1524	.1372	.1417	.1524	.1905	.2481
4	.1715	.1524	.1372	.1417	.1524	.1905	.2481
5	.1715	.1524	.1372	.1417	.1524	.1905	.2481
6	.1715	.1524	.1372	.1417	.1524	.2286	.2481
7	.2743	.2667	.2058	.1772	.2286	.3429	.2835
8		.2667	.2401	.2126		.381	
9	.2835	.2667	.2401	.2481	.2667	.2743	.2481
10	.2774	.2667	.2401	.2126	.2667	.2401	
11	.2427	.3048	.2058	.2481		.2743	.2481
12	.2481	.2667	.2401	.2481		.2058	.2481
13	.2481	.2667	.2058	.2481		.2058	.2481
14	.2481	.2286	.2058	.2481		.2058	.2835
15	.2481	.2286	.2058	.2481	.2286	.2058	.2481
16	.2126	.2667	.2743	.2481	.3048	.2058	.2481
17	.2126	.2286	.2401	.2481	.2286		.2481
18	.2481	.2667	.2743	.2835	.3048		.2835
19	.2835	.4191	.3772	.3898	.4954		.4252
20	.4508	.4954		.4961	.5335		.4607
21		.381	.4572	.381	.4954	.381	.4954
22	.3429	.2667		.3048	.3429	.381	.3429
23	.2286	.2286	.2667	.2286	.2667	.3048	.2286
24	.2058	.1905	.1905	.1524	.1524	.1905	.2667
Max	.4508	.4954	.4572	.4961	.5335	.381	.4954
Min	.1715	.1524	.1372	.1417	.1524	.1905	.2286
Avg	.2402	.2508	.2224	.2364	.2647	.249	.2862

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144058 / 33/11 KV NESARI

Feeder No / Name : 205 / 11 KV Kowad Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.5335	.4801	.4961	.5716	.5335	.567
2	.4801	.5335	.4801	.4961	.5716	.5335	.567
3	.4801	.5335	.4801	.4961	.5716	.5335	.567
4	.5144	.5335	.4801	.4961	.5716	.5335	.567
5	.5144	.5335	.4801	.4961	.5716	.5335	.567
6	.583	.5335	.4801	.4961	.5716	.6097	.567
7	.6859	.6859	.6516	.6024	.724	.7621	.6733
8		.8002	.7202	.6733	.724	.7621	.6733
9	.7087	.8383	.6173	.7442	.724	.6173	.7087
10	.7796	.7621	.6173	.6379	.724	.6516	
11	.7087	.8002	.6173	.6379		.7888	.6379
12	.815	.8002	.6859	.7087		.7888	.815
13	.7087	.8002	.6173	.7442		.7202	.7442
14	.7087	.724	.6516	.7442		.7202	.7442
15	.7087	.724	.6516	.7087	.724	.6859	.6379
16	.6379	.6859	.6173	.6733	.724	.7888	.567
17	.6379	.724	.6859	.7442	2.7435	.7202	.6379
18	.7282	.724	.7545	.6733	.724		.7087
19	.9568	1.0288	.9259	.8505	1.105		.9214
20	1.134	1.1431		1.0631	1.1812		1.0985
21		.9526	1.105	.9526	1.105	1.1431	1.0288
22	.9907	.9145		.8764	1.0288	1.0288	.9907
23	.7621	.724	.7621	.724	.6859	.7621	.6859
24	.5144	.5716	.6097	.5716	.5716	.5716	.6097
Max	1.134	1.1431	1.105	1.0631	2.7435	1.1431	1.0985
Min	.4801	.5335	.4801	.4961	.5716	.5335	.567
Avg	.6942	.7335	.6441	.6795	.8459	.7042	.7080

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 201 / 11 KV MAHAGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6036	.5487	.5249	.5249	.5121	.4938	.5121
2	.4904	.5121	.5068	.5068	.5121	.4938	.5121
3	.5281	.4755	.5068	.5359	.5121	.4938	.5121
4	.5658	.4557	.5249	.543	.5121	.4938	.5121
5	.6036	.4755	.543	.543	.5121	.4938	.5487
6	.6413	.5121	.5611	.5788	.5853	.6036	.6219
7	.679	.6219	.5973	.5792	.5853	.6401	.6584
8	.6602	.695	.6036	.5487	.5487	.6401	.6584
9	.679	.7167	.695	.5853	.543	.6878	.679
10	.6979	.811	.6584	.6584	.5792	.5068	
11	.7356	.7167	.6036	.6219		.7059	.7356
12	.6602	.6401		.5487		.6878	.6979
13	.6219	.5853		.5415		.7356	.7167
14	.5853	.5487	.5853	.543	.543	.6224	.6036
15	.5487	.5258	.5853	.543	.5611	.6036	.6036
16	.5304	.5487	.5853	.543	.5973	.6036	.5611
17	.5487	.5304	.5487	.5249	.5973	.6219	.5792
18	.6036	.5487	.5487	.5068	.6154	.6224	.5973
19	.8779	.7682	.6154	.905	.7964	.7922	.7059
20	.8596	.8326	.724	.8688	.8326	.8676	.8596
21	.8048	.7964	.6878	.7499		.8048	.8413
22	.7362	.724	.6516	.695	.7682	.7316	.7316
23	.6584	.5973	.5792	.5853	.6219	.6584	.5959
24	.6224	.567	.543	.5359	.5175	.5487	.5304
Max	.8779	.8326	.724	.905	.8326	.8676	.8596
Min	.4904	.4557	.5068	.5068	.5121	.4938	.5121
Avg	.6476	.6148	.5900	.5965	.5926	.6314	.6337



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 203 / 11 KV Mahagaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1216	.1402	.1448	.1448	2.3388	2.0405	2.0576
2	2.2131	.1402	.1448		2.3388	2.0405	2.0576
3	2.1216	.1402	.1448	.1448	2.3152	2.0405	2.0576
4	2.1948	.1402	.1448	.1463	2.3388	2.0405	2.0576
5	2.268	.1341	.1448	.1448	2.3388	2.0405	2.1948
6	2.3411	.1402	.1448	.1448	2.6886	2.4863	2.5206
7	2.7618	.1402	.1448	.1578	3.3608	2.7606	2.915
8	2.8166	.1402	.1187	.1402	3.1367	2.8978	3.1036
9	2.8166	.128	.1187	.1402	3.1131	3.0407	3.1824
10	2.5972	.1097	.1187	.1402	.1448	.1629	
11	.1097	.7865	.6783	2.8746		.1629	.128
12	.1097	3.0148	.78	3.0148		.1629	.1646
13	.12	.0526		3.3846		.128	.1463
14	.1017	3.6458	3.2251	3.4389		.1463	.128
15	.1017	3.6458	3.5406	3.5482	.1629	.1463	.128
16	.1017	3.5757	3.3303	3.5848	.1629	.128	.1448
17	.1187	3.3303	3.2952	3.6199	.1629	.1463	.1448
18	.1357	3.2251	3.2952	3.035	.1646	.1463	.1448
19	.1526	.1402	.1629	.1629	.1629	.1646	.1448
20	.1526	.1448	.168	.1629	.1629	.1646	.1448
21	.1578	.1448	.1448	.1357	.1543	.1372	.1402
22	.1402	.1448	.1448	.1357	.1372	.1372	.1402
23	.1402	.1448	.1629	.12	.1372	.1372	.1402
24	.1463	.1402	.1448	.1646	2.0576	1.9376	1.989
Max	2.8166	3.6458	3.5406	3.6199	3.3608	3.0407	3.1824
Min	.1017	.0526	.1187	.12	.1372	.128	.128
Avg	1.0850	.9787	.8888	1.2472	1.3790	1.0582	1.1294

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144068 / 33/11 KV MAHAGAON

Feeder No / Name : 205 / 11 KV Nadighat Ag Feeder      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3041	.0335	.0343	.0343	.3647	.3932	.3932
2	.3361	.0335	.0362		.3605	.3932	.3932
3	.3201	.0335	.0343	.0343	.3605	.3932	.3932
4	.3277	.0335	.0343	.0343	.3605	.3932	.3932
5	.3441	.0335	.0343	.0343	.3605	.3932	.3932
6	.3681	.0335	.0343	.0343	.4096	.4096	.3932
7	.4161	.0335	.0343	.0351	.426	.4424	.4588
8	.4161		.0328	.0335	.4588	.4915	.4915
9	.4321	.032	.0328	.0335	.4706	.543	.4961
10	.4321	.032	.0328	.0335	.0343	.0362	
11	.032	.5121	.4424	.6203		.0343	.032
12	.032	.5609	.5243	.6203		.0362	.032
13	.0328	.5959		.6661		.032	.032
14	.0324	.503	.5533	.6697	.0362	.032	.032
15	.0328	.503	.57	.6697	.0351	.032	.032
16	.0328	.4694	.57	.6878	.0343	.032	.0362
17	.0328	.4694	.5533	.6878	.0343	.032	.0362
18	.0328	.4694	.5533	.5973	.0343	.032	.0362
19	.0328	.0335	.0362	.0343	.0343	.032	
20	.0328	.0343	.0362	.0343	.0343	.032	.0362
21	.0335	.0343	.0373	.0328	.0328	.0328	.0335
22	.0335	.0343	.0362	.0328	.0328	.0328	.0335
23	.0335	.0343	.0362	.0328	.0328	.0328	.0335
24	.032	.0335	.0343	.0343	.3441	.3605	.3605
Max	.4321	.5959	.57	.6878	.4706	.543	.4961
Min	.032	.032	.0328	.0328	.0328	.032	.032
Avg	.1731	.1994	.1880	.2490	.2043	.1948	.2078

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 201 / 11 KV Aralgundi AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0366	.0183	.0179	.0892	.0695	.0762
2		.0362	.0181	.0171	.1027	.0846	.0892
3	.0743	.0362	.0179	.0343	.1014	.0846	.0892
4	.0743	.0366	.0183	.0343	.0892	.0846	.104
5	.088	.037	.0187	.0343	.088	.1054	.1174
6	.132	.056	.0377	.0343	.1204	.1543	.1486
7	.176	.0554	.0377	.0339	.1852	.2214	.1907
8	.2641	.0532	.0297	.0332	.2107	.2812	.2286
9	.1783	.0335	.029	.0305	.2134	.25	.2286
10	.1814	.0497	.0297	.0297	.032	.0267	.0282
11	.0286	.2315	.2343	.2315	.0133	.0324	.0145
12	.0332	.2107	.2134	.2408	.0141	.0149	.0149
13	.0324	.2469	.1524	.2201	.0151	.0149	.0145
14		.1932	.1486	.1715		.0149	.0147
15	.0175	.1783	.132	.1235	.0179	.0145	.0145
16	.0173	.1467	.1932	.1391	.0156	.0139	
17	.0274	.1882	.208	.1623	.0152	.0267	.0145
18	.0339	.1738	.176	.1429	.0156		.0297
19	.0347	.0339	.0343	.0339	.0335	.0343	.0486
20	.0351	.0373	.0351	.0358	.0351	.037	.0514
21	.0358	.0377	.0358	.0358	.0354	.0362	.0497
22	.0354	.0377	.0358		.0354	.0514	.0474
23	.0358	.037	.0179	.0332	.017	.0343	.0469
24		.0362	.0181		.0892	.0686	.061
Max	.2641	.2469	.2343	.2408	.2134	.2812	.2286
Min	.0173	.0335	.0179	.0171	.0133	.0139	.0145
Avg	.0768	.0925	.0788	.0850	.0689	.0764	.0749

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

GADHINGLAJ DIVISION[112]

NESARI[024]

BU 1139

Substation No/ Name :- 144112 / 33/11 Kv Nangnur

Feeder No / Name : 203 / Khandal Ag.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0602	.0362	.0185	.0179	.0518	.0549	.061
2	.0602	.0366	.0183	.0183	.0657	.0564	.0762
3	.0753	.0183	.0185	.0183	.0511	.0714	.0594
4	.0753	.0185	.0187	.0183	.0526	.0714	.0743
5	.0857	.0373	.0185	.0183	.0667	.0869	.088
6	.1143	.037	.0373	.0366	.1235	.1372	.1143
7	.1669	.0373	.0377	.0366	.176	.2315	.2
8	.2679	.0358	.0343	.0358	.1858	.2408	.2572
9	.2397	.0343	.0332		.2027	.2258	.2715
10	.1867	.0166	.0328	.0128	.032	.0309	.016
11	.0152	.2623	.1981	.1829	.0332	.0316	.017
12	.0183	.2932	.1981	.2201	.0354	.0343	.0171
13	.0183	.2743	.1677	.2172	.0343	.0175	.017
14	.0183	.2559	.1635	.2		.0175	.0166
15	.0183	.2258	.176	.1669	.0179	.0177	.0164
16	.0183	.2258	.1907	.2	.0171	.0171	.016
17	.0324	.2378	.2054	.2115	.0166		.0162
18	.0332	.2027	.2027	.1646	.016	.0149	.0158
19	.0343	.0335	.0339	.0339	.0316	.0354	.0343
20	.0354	.037	.0358	.0362	.0351	.0366	.0354
21	.0358	.0373	.0366	.0362	.0358	.0366	.0354
22	.0351	.0377	.0366	.0358	.0362	.0362	.0347
23	.0354	.0185	.0358	.0354	.0358	.0354	.0332
24	.0177	.0358	.0183	.0179	.0526	.0541	.0633
Max	.2679	.2932	.2054	.2201	.2027	.2408	.2715
Min	.0152	.0166	.0183	.0128	.016	.0149	.0158
Avg	.0708	.1036	.0820	.0857	.0611	.0692	.0661

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 201 / YADRAV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7342	3.9209	3.3234	3.81	3.6969	3.2819	3.7342
2	3.6969	3.8462	3.2861	3.7723	3.6595	3.2065	3.6969
3	3.6595	3.7715	3.2487	3.6591	3.5475	3.1687	3.6595
4	3.6222	3.7342	3.1741	3.5837	3.5848	3.1687	3.6969
5	3.6969	3.7715	3.2114	3.6969	3.5848	3.2442	3.8089
6	3.8462	3.7342	3.2861	3.7723	3.5475	3.3573	3.9209
7	3.7342	3.7342	3.1741	3.81	3.6595	3.4705	3.8462
8	3.6969	3.3981	3.2487	3.6214	2.8753	3.4328	3.6595
9	4.0703	3.6969	4.1495	3.9609	3.0994	4.1076	4.2943
10	4.1823	3.5848	3.9609	4.3759	3.0247	4.1076	4.5931
11	4.2383	3.6222	4.225	4.4513	2.95	4.3317	4.5557
12	4.0703	3.3234	3.6969	3.9986	2.8753		4.1076
13	3.1741	2.8753	3.0556	3.0556	2.1285		3.5082
14	3.8089	3.0247	3.5837	3.8477	2.2405	4.1823	3.9209
15	4.2943	3.3608	3.9986	3.6969	1.7737	4.369	4.5184
16	4.2383	3.2301	4.0741	4.3381	2.6513	4.5931	4.5931
17	4.1823	3.2301	4.0703	3.9609	2.7349	4.369	4.2943
18	4.0329	3.1741	4.0329	3.8855	2.452	4.5931	4.3381
19	3.9956	3.0247	3.7342	3.6591	2.452		4.1872
20	3.9209	3.0994	3.7342	3.6214	2.452	3.8462	3.7346
21	4.1076	3.1741	3.5475	3.7723	3.546	3.7342	4.1872
22	4.2196	3.2114	4.0329	3.9609	3.4705	3.9582	4.1872
23		3.2861	4.1076	3.8477	3.4705		4.1872
24	3.8089	4.0364	3.3608	.4763	3.7342	3.3573	3.8462
Max	4.2943	4.0364	4.225	4.4513	3.7342	4.5931	4.5931
Min	3.1741	2.8753	3.0556	.4763	1.7737	3.1687	3.5082
Avg	3.9144	3.4527	3.6382	3.6931	3.0505	3.7940	4.0448

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 203 / ARUNDATHI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2696	1.3817	1.3443	1.2826	1.2323	.7545	1.2696
2	1.2696	1.3443	1.307	1.2449	1.1949	.7545	1.1949
3	1.3203	1.3443	1.2696	1.2449	1.1203	.7167	1.1949
4	1.3443	1.307	1.2696	1.2826	1.0829	.7167	1.2323
5	1.3443	1.307	1.307	1.2826	1.0456	.7545	1.2323
6	1.3817	1.2696	1.3443	1.3203	1.0082	.7545	1.1576
7	1.1949	1.307	1.2696	1.2071	1.0082	.7545	1.1949
8	1.1949	1.2696	1.2696	1.2071	.7842	.9054	1.1949
9	1.307	1.2696	1.358	1.3203	.7095	1.0829	1.307
10	1.4563	1.531	1.3203	1.358			1.4937
11	1.3817	1.5497	1.5466	1.3203		1.3443	1.419
12	1.4377	1.307	1.4335	1.2826			1.307
13	1.251	1.419	1.1694	1.2826			1.1949
14	1.3256	1.5123	1.358	1.2826	.7095	1.307	1.307
15	1.4563	1.475	1.3957	1.2449	.6348	1.3817	1.307
16	1.4563	1.4563	1.4712	1.3203	.6722	1.3443	1.3443
17	1.5497	1.4377	1.3957	1.3957	.6036	1.307	1.3817
18	1.419	1.419	1.4563	1.358		1.2323	1.3957
19	1.419	1.3817	1.419	1.3203	.6036	1.3443	1.4335
20	1.3443	1.3443	1.3443	1.358	.679	1.2696	1.2826
21	1.3817	1.307	1.2696	1.2449	.7545	1.307	1.3203
22	1.419	1.307	1.307	1.1694	.7922	1.307	1.3203
23		1.3443	1.2696	1.2071	.7545		1.3203
24	1.307	1.419	1.3817	.4763	1.307	.7545	1.307
Max	1.5497	1.5497	1.5466	1.3957	1.307	1.3817	1.4937
Min	1.1949	1.2696	1.1694	.4763	.6036	.7167	1.1576
Avg	1.3579	1.3754	1.3449	1.2506	.8788	1.0547	1.2964

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 204 / SPM

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7177	1.7177	1.8298	1.8107	1.8298	1.5844	1.6804
2	1.6804	1.6804	1.7924	1.773	1.7924	1.5844	1.6804
3	1.6804	1.6804	1.7177	1.773	1.773	1.6221	1.643
4	1.7177	1.643	1.7551	1.8107	1.773	1.6221	1.643
5	1.6804	1.7177	1.7924	1.8107	1.8107	1.6598	1.6804
6	1.6804	1.7551	1.8298	1.8484	1.8107	1.7353	1.6804
7	1.7551	1.7551	1.7551	1.8107	1.773	1.6975	1.6804
8	1.8671	1.7551	1.6804	1.8484	1.2449	1.6975	1.7177
9	1.9791	1.8671	1.9239	1.8861	1.094	1.7924	1.6804
10	1.9418	1.7551	1.9427	1.9239	1.094	1.8671	1.9791
11	1.9791	1.8671	1.9616	1.9993	1.1317	1.9791	2.0165
12	1.4563	1.8858	1.9239	1.8861	1.1694		1.8671
13	1.9231	1.6991	1.8484	1.9239	.8488		1.7551
14	1.9231	1.8111	1.9805	1.8861	.9054	1.9418	1.8671
15	1.9418	1.8671	2.037	1.6975	.4715	1.9791	1.9791
16	1.8671	1.7924	1.9993	2.0748	.8865	1.8671	1.9418
17	1.9231	1.8484	2.0748	1.9616	.8865	1.7924	1.9791
18	1.9791	1.9044	1.9791	1.9616	.811	1.9044	1.9616
19	1.7551	1.8671	1.9044	1.8861	.7545	1.7551	1.8107
20	1.7924	1.7924	1.8671	1.773	1.1694	1.7551	1.8861
21	1.8298	1.8671	1.8298	1.9616	1.5844	1.7924	1.9616
22	1.8671	1.9044	1.9044	1.8861	1.6221	1.8298	1.9239
23		1.8671	1.8671	1.6975	1.6221		1.8861
24	1.773	1.7551	1.8671	1.8298	1.8671	1.5844	
Max	1.9791	1.9044	2.0748	2.0748	1.8671	1.9791	2.0165
Min	1.4563	1.643	1.6804	1.6975	.4715	1.5844	1.643
Avg	1.8135	1.7940	1.8777	1.8634	1.3219	1.7640	1.8218

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 205 / PADMAJA FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2323	1.2696	1.2323	1.3203	1.2696	1.2071	1.307
2	1.1949	1.2696	1.2323	1.3203	1.2323		1.307
3	1.2323	1.2323	1.1949	1.2826	1.2323	1.2071	1.2696
4	1.2696	1.2696	1.2323	1.2071	1.1949		1.307
5	1.2323	1.3443	1.2696	1.2449	1.2323	1.1694	1.307
6	1.2696	1.4563	1.307	1.2449	1.1949	1.2071	1.307
7	1.1949	1.2696	1.3443	1.2826	1.2136	1.1694	1.3817
8	1.1576	1.3443	1.2323	1.2449	.7842	1.2449	1.307
9	1.4563	1.643	1.5089	1.4335	.7655	1.6057	1.7551
10	1.7737	1.8858	1.773	1.9993	.7655	1.7177	2.0538
11	1.7551	1.8671	1.8484	1.9239	.7842	1.9791	1.6804
12	1.6057	1.7177	1.6975	1.8861	.7095	2.0165	1.7551
13	1.3256	1.419	1.5844	1.5089	.6908	1.8671	1.7177
14	1.363	1.4937		1.773	.7095	1.9791	1.7551
15	1.5684	1.7551	1.5844	1.8107	.7095	1.9044	1.8671
16	1.643	1.5497	1.5466	1.773	.7095	1.9418	1.9418
17	1.6057	1.531	1.5466	1.5466	.7356	1.6804	1.8671
18	1.4563	1.4937	1.4937	1.5844		1.307	1.7353
19	1.307	1.419	1.3817	1.5089	.7545	1.4937	1.8107
20	1.3817	1.3817	1.3443	1.3957	.7545	1.4563	1.6221
21	1.3443	1.307	1.307	1.2826	1.094	1.4937	1.6221
22	1.419	1.3443	1.3443	1.2826	1.1694	1.4563	1.6221
23		1.307	1.307	1.3203	1.2071		1.5844
24	1.2696	1.307	1.2826	1.3443	1.307	1.2071	1.3443
Max	1.7737	1.8858	1.8484	1.9993	1.307	2.0165	2.0538
Min	1.1576	1.2323	1.1949	1.2071	.6908	1.1694	1.2696
Avg	1.3938	1.4532	1.4172	1.4801	.9661	1.5386	1.5928



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 206 / 11 KV YADRAV AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3688	.3768	.3681	.3688		
2		.3353	.4096	.4001	.3688		
3		.4024	.4588	.4001	.3353		
4		.4694	.4915	.4321	.4024		
5		.57		.4801	.4359		
6		.6706	.5571	.6081	.4694		
7		.7377	.8192	.7842	.6036		
8		.8048	.852	.8162			.0048
9		.8048	.8482	.8322		.8848	.852
10						1.065	1.0814
11	.8383					1.0814	1.0814
12	.8886					1.0486	1.0486
13	.8383					1.0159	1.1576
14	.9389					.9831	1.0829
15	.8886					.9831	.9896
16	.8551					1.0159	.9503
17						.0095	.0095
18	.57	.0095	.0191				
19		.0191	.0191				
20		.0286	.0238				
21		.0286	.0238				
22		.0286	.0191	.3201			
23		.0191	.0191	.3521			
24		.4024	.3441	.3441	.4024		
Max	.9389	.8048	.852	.8322	.6036	1.0814	1.1576
Min	.57	.0095	.0191	.3201	.3353	.0095	.0048
Avg	.8311	.3562	.3521	.5115	.4233	.8986	.8258

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 207 / TARDAL AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4359	.4915	.4588	.3688		
2		.4694	.5243	.4915	.4024		
3		.503	.5571	.5243	.4359		
4		.57	.5571	.5571	.503		
5		.6371	.6062	.5898	.57		
6		.6706	.7045	.6882	.7377		
7		1.073	1.0159	1.1469	1.073		
8		1.2071	1.2452	1.3108			.0238
9		1.3413	1.2289	1.2452		.9667	1.1797
10						1.2452	1.3763
11	1.358	.168				1.3272	1.3763
12	1.2742					1.3108	1.3108
13	1.2742					1.278	1.2125
14	1.2742					1.1797	1.1797
15	1.2239					1.278	1.1469
16	1.2574					1.3599	1.2125
17	1.3077					.0381	.0381
18	1.073	.0476	.0476				
19		.2241	.0572				
20	.1494	.2614	.0572				
21		.2614	.0572				
22		.0667	.0572	.3932			
23		.0572	.0476	.3277			
24		.4024	.4588	.4096	.4024		
Max	1.358	1.3413	1.2452	1.3108	1.073	1.3599	1.3763
Min	.1494	.0476	.0476	.3277	.3688	.0381	.0238
Avg	1.1324	.4939	.4821	.6786	.5617	1.1093	1.0057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 402 / SUNIL INDUSTRIES  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.4481	.4572	.3429	.3921	.2829	.5041
2	.4481	.4481	.4572	.3429	.4481	.2829	.4481
3	.3921	.5041	.4572	.3429	.3921	.2829	.4481
4	.4481	.4481	.4572	.3395	.4481	.2829	.5041
5	.4481	.4481	.4001	.3395	.4481	.3395	.4481
6	.5041	.5041	.4001	.3395	.5041	.3395	.5041
7	.4481	.5041	.4001	.3395	.4481	.2829	.5041
8	.5041	.4481	.4001	.3395	.5041	.2263	.4572
9	.5041	.5041	.3961	.3395		.4001	.5144
10	.4481	.3921	.3395	.2829		.4572	.2858
11	.4481	.4481	.3395	.2829		.4572	.2858
12	.4481	.3921	.3961	.2829		.4001	.2858
13	.4481	.3921	.3961	.3961		.4001	.2858
14	.3921	.3361	.3395	.3961		.4001	.2858
15	.3921	.3921	.3961	.3961		.3921	.3429
16	.3921	.3921	.3961	.3961		.4001	.3429
17	.3921	.4481	.3395	.4527		.3429	.3429
18	.5041	.4572	.3429	.5093	.1132	.3921	.3395
19	.4481	.4001	.3429	.4527	.1132	.3921	.2829
20	.5041	.4001	.3429	.4527	.2263	.4481	.3395
21	.4481	.4001	.3429	.4527	.2829	.5041	.3395
22	.5041	.4001	.3429	.4527	.2829	.4481	.3395
23		.4001	.3429	.5093	.2829		.3395
24	.4481	.5041	.4572	.3429	.5041	.2829	.4481
Max	.5041	.5041	.4572	.5093	.5041	.5041	.5144
Min	.3921	.3361	.3395	.2829	.1132	.2263	.2829
Avg	.4505	.4338	.3868	.3802	.3594	.3668	.3841

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144052 / 33/11 KV YADRAV

Feeder No / Name : 703 / 33 KV MAIN VCB

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	2.3525	2.7435	2.7161	2.3525	1.4712	1.6804
2	1.5684	2.3525	2.8578	2.7161	2.2405	1.4712	1.6804
3	1.5684	2.4646	2.8006	2.7161	2.2405	1.4712	1.6804
4	1.5684	2.5766	2.9721	2.7161	2.3525	1.4146	1.7924
5	1.5684	2.8006	2.9721	2.8292	2.5766	1.4146	1.7924
6	1.5684	3.0247	3.1367	3.1687	2.8006	1.4712	1.6804
7	1.5684	3.5848	3.9209	3.9609	3.2487	1.358	1.6804
8	1.5684	3.9209	4.0329	4.0741	1.0082	1.4712	1.6804
9	1.7924	4.257	4.4136	4.1872	.9522	3.8089	4.369
10	2.4646		2.1502	2.3765	.7842	4.481	5.1532
11	4.7051	2.5766	1.9239	2.1502	.9522	5.2652	4.8171
12	4.481	2.3525	2.037	2.037	.8962	5.1532	4.8171
13	4.145	2.0165	1.9239	1.8107	.8402	4.9291	4.5931
14	4.257	2.0165	.3395	2.1502	.8962	4.9291	4.481
15	4.369	2.3525	1.9239	2.2634	.8962	4.9291	4.5931
16	4.369	2.1285	1.8107	2.1502	.8962	5.0412	4.8171
17	3.4728	2.2405	1.8107	1.9805	.9619	2.2405	2.4646
18	3.9209	2.2405	2.1285	1.9239		1.9044	2.2634
19	1.7924	2.1285	2.0165	1.9239	.679	1.9044	2.037
20	1.7924	2.2405	2.0165	1.8107	.679	2.0165	1.8107
21	1.7924	2.1285	2.0165	1.8107	1.358	1.9044	1.9239
22	1.7924	2.1285	2.0165	2.3765	1.358	1.9605	1.8107
23		2.0165	1.9044	2.3765	1.358		1.8107
24	1.6804	2.5766	2.6886	2.3525	2.4646	1.4712	1.7924
Max	4.7051	4.257	4.4136	4.1872	3.2487	5.2652	5.1532
Min	1.5684	2.0165	.3395	1.8107	.679	1.358	1.6804
Avg	2.5863	2.5425	2.4399	2.5241	1.5127	2.7601	2.8009

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 201 / LAXMI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3525	1.9044	1.8347		2.2405	1.5684	2.0538
2	2.2779	1.8671	1.7833		2.2405	1.6057	2.0538
3	2.2405	1.8298	1.7147		2.0538	1.6057	2.2405
4	2.1658	1.7924	1.7661		2.0538	1.6057	2.2405
5	2.2032	1.7924	1.8004		2.0165	1.643	2.0538
6	2.2405	1.8298	1.8347		1.8671	1.643	2.0538
7	2.2779	1.8298	1.9204		1.8298	1.643	2.1658
8	2.2032	1.8671	2.1262		1.2323		2.1285
9	2.9801		2.5393	2.6139	1.1576	1.9044	2.2779
10	2.7435		2.6886	3.0247	1.307	2.6886	
11	2.8807		2.6513	3.1367		2.8753	
12	2.9492		2.838	3.1741		3.0247	
13	2.8807		2.2779	3.1367		2.0911	
14	2.915		2.6513	3.0994		2.726	
15	2.8978		2.838	2.9127		2.6513	
16	2.8292		2.6513	2.9874		3.062	
17	2.9127	2.915	2.726	2.6139		2.95	
18	2.6139	2.4006	2.726	2.3899	1.2696		
19	2.3152	2.332		2.3152	1.4937		
20	2.2405	2.1091		2.0538	1.4937		
21	2.0165	2.0576		1.8671	1.5684	2.0538	
22	1.9418	1.8861		2.0538	1.5684	2.0538	
23	1.9418	1.8004		2.2405	1.5684	2.0538	
24	2.3899	1.9044	1.8347		2.2405	1.5684	2.0538
Max	2.9801	2.915	2.838	3.1741	2.2405	3.062	2.2779
Min	1.9418	1.7924	1.7147	1.8671	1.1576	1.5684	2.0538
Avg	2.4754	2.0074	2.2738	2.6413	1.7177	2.1509	2.1322

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 202 / MANIK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646	2.0911	2.3663		2.4646	1.643	2.4272
2	2.4646	2.0538	2.332		2.3899	1.643	2.4646
3		2.0538	2.2634		2.3899	1.643	2.3899
4	2.5019	2.0165	2.0576		2.3152	1.6804	2.3525
5	2.3525	1.9418	2.2291		2.2405	1.6804	2.2405
6	2.3899	2.0165	2.2634		2.2405	1.7177	2.2405
7	2.5766	2.1285	2.3148		2.0538	1.7737	2.3152
8	2.4646	2.2405	2.4006		1.7551		2.6886
9	3.2487		2.6513	2.4646	1.7551		2.8753
10	2.9492		2.5393	2.838	1.419		
11	2.9835			2.9874	1.3032	2.838	
12	3.0521		2.838	2.9127	1.2346	2.8753	
13	2.8807		2.5393	2.9127	1.2003	2.4646	
14	2.9492		2.6139	3.062	1.2003	2.4646	
15	2.9835		3.0994	2.9874	1.2346	2.4272	
16	2.915		2.9874	2.9127	1.2689	2.7633	
17	3.1367	2.5549	2.9127	2.8006	1.419	2.838	
18	2.9127	2.4691	2.838	2.5766	1.4937		
19	2.6886	2.4006		2.726	1.531		
20	2.3899	2.1948		2.6513	1.5684		
21	2.2405	2.1262		2.4646	1.643	2.5766	
22	2.2405	2.2291		2.4646	1.643	2.5019	
23	2.2405	2.3148		2.5393	1.643	2.5393	
24	2.5019	2.1658	2.4006		2.4646	1.643	2.4272
Max	3.2487	2.5549	3.0994	3.062	2.4646	2.8753	2.8753
Min	2.2405	1.9418	2.0576	2.4646	1.2003	1.643	2.2405
Avg	2.6751	2.1874	2.5360	2.7534	1.7446	2.2063	2.4422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 204 / 11 KV AUTOLINE

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6139	1.9418	1.2346	2.2291	.8589	1.0829	2.0538
2	2.5766	1.9418	1.2003	2.1605	.8215	1.1203	2.2405
3	2.4646	1.8671	1.2003	2.0233	.8589	1.1576	2.2405
4	2.3525	1.8298	1.2517	1.9033	.8962	1.1576	2.3525
5	2.2405	1.7924	1.2689	1.7833	1.0456	1.1949	2.4646
6	2.0748	1.7924	1.286	1.6975	1.2696	1.2323	2.5393
7	1.6057	1.419	1.2003	1.5775	2.0538	1.2323	2.4272
8	.8215	1.1203	1.046	1.7147	1.1949		.9335
9	2.2779	1.7147	2.2405	2.2405	.8215	1.2696	2.2405
10	2.2291	2.4006	2.8753	2.4646	.8589	1.419	1.8861
11	2.5034	2.0405	2.838	2.6139	.823	2.3525	1.3032
12	2.572	1.6804	3.0247	2.0165	.823	2.2032	1.406
13	2.5034	1.749	2.9127	2.4272	.8059	2.6886	1.5089
14	2.4006	1.989	2.7633	2.3152	.7888	1.7924	1.5432
15	2.4691	2.1948	3.0247	2.3525	.7888	2.0538	1.6118
16	2.4006	2.3663	1.6057	1.643	.7888	2.7633	1.4918
17	2.2405	2.5892	1.643	1.6804		2.6139	1.8861
18	1.643	1.9719	2.2032	1.7551	.8962	1.8004	2.1948
19		1.8861		1.643	.9335	1.7147	1.7147
20	2.3152	1.2003		1.6057	.9335	1.6804	1.3375
21	2.0165	1.2174		1.5684	.9709	1.3443	
22	2.0165	1.2174		1.4563	.9709	1.8671	
23	2.0165	1.2517		.9335	.9709	2.1658	
24	2.6513	2.0165	1.2517	2.1262	.8962	.9709	2.0538
Max	2.6513	2.5892	3.0247	2.6139	2.0538	2.7633	2.5393
Min	.8215	1.1203	1.046	.9335	.7888	.9709	.9335
Avg	2.2176	1.7996	1.8985	1.9138	.9596	1.6903	1.8776

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 206 / 11 KV MARUTI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6886	2.4646	2.332	2.2119	2.6513	1.9791	2.0538
2	2.6513	2.5393	2.4006	2.0576	2.5766	2.0165	2.0538
3	2.6139	2.6139	2.3663	2.1605	2.5019	2.0165	2.2405
4	2.5766	2.6513	2.5377	2.2805	2.4646	2.0538	2.2405
5	2.6513	2.3899	2.572	2.4691	2.5393		2.3525
6	2.5393	2.3899	2.7435	2.5892	2.5393	2.0911	2.4646
7	2.1285	2.4646	2.572	2.6749	2.6886	2.0165	
8	2.3899	2.5393	2.0576	2.6063	2.0911	2.0538	
9	2.838	2.2805	2.3152	2.9127	1.7551	2.2405	2.3899
10	2.572	2.2462	2.0538	2.9874	1.8671	2.2405	2.332
11	2.7092	2.5034	2.8753	2.9127	1.6118	2.3899	2.4006
12	2.4177	2.7092	3.0247	2.9874	1.5432		2.5549
13	2.572	2.4348	2.2779	2.9127	1.6804	3.4728	2.7606
14	2.7778	2.572	2.4646	2.7633	1.6461	3.0247	2.8121
15	2.8807	2.5034	2.5019	2.6886	1.6289	2.9127	2.5892
16	2.7435	2.4691	2.3899	2.7633	1.6118	2.838	2.452
17	2.838	2.6063	3.0247	2.5393	1.7551	3.1367	2.6406
18	2.7633	2.7435	3.1367	2.95	1.7924	2.4006	2.7949
19	2.5393	2.7092		2.7633	1.7924	2.5549	2.6406
20	2.5766	2.2291		2.3899	1.7924	2.6749	2.572
21	2.4646	2.0576		1.9044	1.8671	2.1658	
22	2.3899	2.1262		2.3152	1.9044	2.2405	
23	2.4646	2.1605		2.726	1.9044	2.2779	
24	2.726	2.4646	2.1948	2.0748	2.6139	1.9418	2.2405
Max	2.8807	2.7435	3.1367	2.9874	2.6886	3.4728	2.8121
Min	2.1285	2.0576	2.0538	1.9044	1.5432	1.9418	2.0538
Avg	2.6047	2.4529	2.5180	2.5684	2.0341	2.3973	2.4519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 401 / 33 KV LIE Industrial No 1 SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.1367	2.6886	2.572	2.572	2.9127	2.5766	3.0247
2	3.0247	2.6326	2.5206	2.5206	2.9127	2.5206	2.9127
3	3.0247	2.6886	2.3148	2.4691	2.8006	2.4646	2.9127
4	2.9127	2.9127	2.3148	2.5206	2.8006	2.5206	3.0247
5	2.8006	2.9127	2.3148	2.572	2.9127	2.4646	3.1367
6	3.0247	2.8006	2.4177	2.6235	3.0247	2.4646	2.9127
7	2.9127	2.9127	2.5206	2.572	2.8006	2.5766	3.0247
8	2.6886	2.6886	2.572	2.4691	2.6886	2.6326	2.9127
9	2.9127	2.6749	2.6886	2.9127	2.9127	2.8006	2.9127
10	2.572	2.7778	1.4563	3.0247	2.8006	2.9127	2.7778
11	2.7778	2.7263	2.6886	2.8006		2.9127	2.8292
12	2.9321	2.8292	3.1367	2.9127		2.6886	2.8807
13	2.8807	2.572	3.0247	3.0247		2.5766	2.7778
14	2.8292	2.6749	2.9127	2.9127		2.6886	2.8292
15	2.8292	2.7263	3.1367	2.8006		3.0247	2.7263
16	2.6749	2.7778	3.0247	3.0247		2.9127	2.8807
17	2.9687	2.8807	3.0247	2.9127		3.1367	2.8292
18	2.8006	2.8807	2.9127	2.8006	1.4563	2.8807	2.7778
19	2.8006	2.8292		2.6886	1.7924	2.8807	2.7263
20	2.9127	2.7778		2.8006	2.5766	2.8292	2.8292
21	2.8006	2.7263		2.9127	2.5766	2.9127	
22	2.8006	2.6749			2.5766	2.9127	
23	2.8006	2.6235		2.9127	2.5766	2.9127	
24	3.1367	2.6886	2.6235	2.4691	2.9127	2.5766	3.0247
Max	3.1367	2.9127	3.1367	3.0247	3.0247	3.1367	3.1367
Min	2.572	2.572	1.4563	2.4691	1.4563	2.4646	2.7263
Avg	2.8731	2.7533	2.6409	2.7491	2.6491	2.7408	2.8887

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144053 / 33/11 KV TILAWANI

Feeder No / Name : 402 / 33 KV LIE INDUSTRIAL NO 2 SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7924	1.9605	1.9547		1.4563	1.5123	1.7924
2	1.6804	2.0165	1.8004		1.4563	1.5123	1.5684
3	1.5684	2.0165	1.5432		1.5684	1.5684	1.4563
4	1.5684	2.1285	1.5432		1.6804	1.4563	1.5684
5	1.4563	2.1285	1.4403		1.6804	1.5684	1.6804
6	1.3443	2.1285	1.4403		1.7924	1.5684	1.7924
7	1.3443	2.0165	1.4918		1.9044	1.5684	1.9044
8	1.7924	1.9044	1.3889		1.3443	1.5684	1.5684
9	1.2323		1.5684	1.6804	1.6804	1.7924	2.0165
10	1.5432		1.5203	1.7924	1.6804	1.7924	
11			1.5684	1.6804	1.5432	2.1285	
12	1.9547		1.4563	1.9044	1.4403	2.0165	
13	2.0062		1.4563	1.6804	1.1317	1.9044	
14	2.0576		1.4563	1.5684	1.2346	2.1285	
15	2.1605		1.3032	1.5684	1.4403	2.2405	
16	2.1605		1.6804	1.4563	1.5432	2.2405	
17	2.2405	1.9547	1.4563	1.4563	1.6804	2.0165	
18	2.1285	2.0576	1.6804	1.4563	1.5684		
19	2.0165	1.4918		1.3443	1.5684		
20	2.0725	1.6461		1.3443	1.4563		
21	1.7924	1.5947		1.3443	1.5684	1.9044	
22	1.9044	1.6461		1.4563	1.4563	2.0165	
23	1.9044	1.8004		1.4563	1.4563	2.1285	
24	1.9044	1.7924	2.0062		1.4563	1.4563	1.7924
Max	2.2405	2.1285	2.0062	1.9044	1.9044	2.2405	2.0165
Min	1.2323	1.4918	1.3032	1.3443	1.1317	1.4563	1.4563
Avg	1.8098	1.8927	1.5661	1.5459	1.5328	1.8138	1.714

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 201 / SAJANI FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5228	.5601	.5415	.5228	.5228	.5601	.5228
2	.4854	.5228	.5228	.4854	.4854	.5228	.4854
3	.4854	.4854	.5228	.4854	.4854	.5228	.4854
4	.4854	.5228	.5228	.4854	.4481	.5601	.4854
5	.5228	.5228		.4854	.4668	.5601	.5228
6	.5601	.5415	.5601	.5228	.4854	.5975	.5601
7	.6161	.5415	.5415	.5601	.5601	.6348	.5975
8	.5788	.5228	.5601	.5601	.5041	.6535	.5914
9	.5601	.5041	.6348	.5975	.3361	.5601	.5544
10	.5975	.6161		.6348	.3361	.5788	.6348
11	.5975	.6348	.5041	.6161	.3018	.6161	.6348
12	.5228	.5975	.4854	.6535	.2987	.5975	.6348
13	.5601		.4668	.6283	.3361	.5601	.6161
14	.5601	.5788	.4668	.6468	.3361	.6348	.6161
15	.5601	.6161	.5228	.6348	.3174	.7095	.5975
16	.5601	.6535	.5975	.6535	.3174	.6722	.6161
17	.6535	.6161	.6348	.6722	.2987	.5601	.5975
18		.6535	.6535	.7095	.3361	.5975	.6348
19	.6161	.7095	.6722	.7095	.4481	.6722	.7468
20	.6535	.7655	.6722	.7282	.5041	.7468	.7468
21	.6722	.6722	.6348	.7282	.6908	.6722	.6722
22	.6348	.5975	.5975	.7095	.6722	.6161	.5975
23	.6161	.5601	.5601	.6348	.6161	.5601	.5975
24	.5601	.5975	.5601	.5601		.5601	.5601
Max	.6722	.7655	.6722	.7282	.6908	.7468	.7468
Min	.4854	.4854	.4668	.4854	.2987	.5228	.4854
Avg	.5731	.5910	.5652	.6094	.4393	.6052	.5962

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 203 / PANCHAGANGA

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.5975	.6348	.5658	.679	.5601	.7167
2	.679	.5975	.6348	.5281	.6348	.5601	.679
3	.679	.6161	.6348	.5281	.6413	.5975	.6413
4	.7545	.6348	.7095	.6036	.6161	.6722	.679
5	.8676	.7095	.8215	.7167	.6161	.7468	.7167
6	.9431	.7842	1.1576	.8299	.7167	1.0082	.7922
7	1.1694	.8962	1.1576	.759	.8215	1.0642	.8676
8	1.1317	.8589	1.1203	.8299	.8488	1.0456	.8488
9	1.1317	.7655	1.1389	.7545	.7733	1.0082	.8488
10	1.0456	.9431		.8402	.5658	.8676	.9335
11	1.0456	.9242	.8299	.8589	.5975	.9054	.9335
12	1.0082	.8865	.9997	.9149	.5975	.8676	.9431
13	1.0269		1.1317	.8589	.6161	.8299	.8215
14	1.0269	.8299	1.0562	.7842	.6161	.9431	.7655
15	.9335	.9054	.9997	.8215	.5975	1.1694	.8402
16	.8962	.9808	.9431	.8775	.5975	1.0562	.8402
17	.8029	.9619	.9997	.8775	.6535	.9431	.9896
18		.9335	1.1317	.8962	.6535	.9054	.8865
19	1.1576	.9896	1.2071	.9431	.6348	.9997	.9997
20	1.0456	.9522	1.1317	.9431	.7095	1.094	.9431
21	.8962	.8962	.9808	.7545	.7842	1.0562	.8488
22	.8215	.7468	.8676	.7545	.7842	.9431	.811
23	.7842	.6722	.7545	.7356	.7468	.811	.7545
24	.7922	.6348	.7282	.6602	.7356	.5975	.7545
Max	1.1694	.9896	1.2071	.9431	.8488	1.1694	.9997
Min	.679	.5975	.6348	.5281	.5658	.5601	.6413
Avg	.9302	.8138	.9466	.7765	.6766	.8855	.8273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 204 / RUI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.57	.1006	.1006	.0995	.3856	.4191	.3978
2	.5365	.0838	.1006	.0829	.4024	.4191	.3749
3	.5365	.0829	.1006	.0829	.4024	.4359	.431
4	.57	.0829	.1006	.0829	.4024	.4359	.4641
5	.6036	.1006	.1006	.0829	.4024	.4694	.4973
6	.6371	.1006	.1006	.0995	.503	.5228	.5304
7	.6371	.1006	.0995	.0995	.6036	.5533	.5967
8	.0838	.1006	.1006	.0995	.6371	.5533	.5636
9	.0838	.7956	.788	.0995	.5533	.5868	.5636
10	.0838	.7545		.0838	.0762	.0838	.1006
11	.0838	.8718	.7042	.8551	.0671	.1006	.0838
12	.0838	.8048	.7712	.8288	.0671	.0838	.0838
13	.0838		.8383	.7956	.0671	.0838	.0671
14	.0838	.7712	.8048	.7459	.0671	.0838	.0671
15	.1006	.788	.6962	.7042	.0671	.0829	.0671
16	.1006	.788	.6371	.6706	.0671	.0838	.0671
17	.0838	.6539	.0671	.6706	.0838	.0838	.1006
18		.1174	.0838	.6371	.0838	.0838	.1006
19	.0838	.1174	.1006	.1509	.1006	.0838	.1006
20	.1006	.1174	.1006	.1006	.1006	.1174	.1174
21	.1006	.1174	.1006	.1174	.1341	.1006	.1174
22	.1006	.1174	.1006	.1174	.1341	.0838	.1174
23	.1006	.1174	.0995	.1174	.1174	.0838	.1006
24	.57	.1006	.1006	.0995	.3856	.3353	.3978
Max	.6371	.8718	.8383	.8551	.6371	.5868	.5967
Min	.0838	.0829	.0671	.0829	.0671	.0829	.0671
Avg	.2617	.3385	.2955	.3135	.2463	.2488	.2545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 205 / MANGAON

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2614	.2801	.2241	.2614	.2614	.2614
2	.2054	.2427	.2801	.2241	.2427	.2427	.2427
3	.2054	.2241	.2801	.2054	.2427	.2427	.2427
4	.2054	.2241	.2801	.2427	.2427	.2614	.2427
5	.2241	.2427	.2801	.2614	.2614	.2801	.2427
6	.2427	.2427	.2987	.2801	.2614	.3174	.2614
7	.2614	.2801		.2801	.2987	.2987	.2801
8	.2427	.2801	.2987	.2801	.3174	.2987	.2614
9	.2427	.2427	.2614	.2801	.2614	.2427	.2241
10	.2241	.2427		.2801	.2614	.2801	.2241
11	.2427	.2801	.2241	.2987	.2801	.2801	.2241
12	.2614	.2614	.2427	.2801	.2801	.2801	.2241
13	.2801		.2614	.2614	.2801	.2614	.2801
14	.2801	.3361	.2614	.2987	.2801	.2801	.2801
15	.2801	.3174	.2614	.2987	.2801	.2987	.2801
16	.2801	.2987	.2801	.2801	.2801	.2987	.2801
17	.2801	.2241	.2987	.2987	.2614	.3361	.2987
18		.2987	.3361	.3174	.2614	.3547	.2801
19	.2987	.4108	.3734	.3174	.3547	.3734	.3547
20	.3734	.4294	.4108	.3734	.3734	.4294	.415
21	.3921		.4108	.4108	.3921	.4294	.4108
22	.3547	.3734	.3734	.3547	.3547	.3734	.3734
23	.3174	.3361	.3361	.3174	.3174	.2987	.2987
24	.2427	.2801	.2987	.2801	.2801	.2614	.2801
Max	.3921	.4294	.4108	.4108	.3921	.4294	.415
Min	.2054	.2241	.2241	.2054	.2427	.2427	.2241
Avg	.2671	.2877	.3013	.2894	.2886	.3034	.2818

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 206 / 11 KV MANGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6461	.0343	.0343	.0343	1.8861	1.7147	1.7528
2	1.6461	.0343	.0343	.0343	1.869	1.7147	1.7528
3	1.6461	.0343	.0343	.0343	1.8519	1.6804	1.7528
4	1.6461	.0343	.0343	.0343	1.8519	1.6804	1.7878
5	1.6804	.0343	.0343	.0343	1.8176	1.6804	1.8229
6	1.7147	.0343	.0343	.0343	1.9204	1.6804	1.893
7	1.7661	.0343	.0343	.0343	1.9204	1.6804	1.9281
8	.0343	.0343	.0343	.0343	2.0062	1.7147	1.9631
9	.0343	2.1948	2.4006	.0514	2.0062	1.7318	1.9982
10	.0343	2.1605		.0343	.12	.0343	.0514
11	.0343	2.3148	2.3663	2.2462	.0514	.0343	
12	.0343	2.2291	2.332	2.3491	.0514	.0343	
13	.0343		2.2977	2.332	.0343	.0343	
14	.0343	2.332	2.2634	2.2805	.0686	.0343	.0686
15	.0343	2.3663	2.2634	2.2291	.0343	.0343	.12
16	.0343	2.3834	2.2634	2.1948	.0343	.0343	.0514
17	.0343	2.2805	.0514	2.1605	.0857	.0343	.0686
18		.0343	.0343	2.0576	.0686	.0343	.0514
19	.0343	.0343	.0343	.0343	.0514	.0343	.0514
20	.0343	.0343	.0343	.0343	.0514	.0343	.0514
21	.0343	.0343	.0343	.0343	.0686	.052	.0514
22	.0343	.0343	.0343	.0343	.0514	.0526	.0514
23	.0343	.0343	.0343	.0343	.0514	.0526	.0514
24	1.6461	.0343	.0343	.0343	1.7661	1.749	1.7528
Max	1.7661	2.3834	2.4006	2.3491	2.0062	1.749	1.9982
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0514
Avg	.6046	.8163	.7284	.7673	.8216	.7317	.9082

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 207 / 11 KV LAXMI AG. (SAJANI) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2334	.081	.0781	.0791	.8745	.9878	.8436
2	1.2018	.081	.0781	.0791	.8745	1.004	.8539
3	1.2018	.08	.0781	.0791	.9069	1.004	.9488
4	1.2967	.08	.0781	.0949	.9069	1.0688	1.0279
5	1.3599	.0972	.0949	.1107	.9555	1.1523	1.1385
6	1.4232	.096	.1094	.1265	1.004	1.2803	1.2651
7	1.4548	.096	.1406	.1265	1.0688	1.5524	1.3916
8	.0791	.096	.1265	.1107	1.085	1.6004	1.3916
9	.0949	1.7764	1.656	.0949	1.3441	1.6644	1.3748
10	.0937	1.9109		.096		.0791	.0625
11	.0949	1.9919	1.6129	1.8564	.0625	.0633	.0625
12	.0791	1.9433	1.6129	1.6324	.0625	.0633	
13	.0781		1.5971	1.8244	.0625	.0633	.1094
14	.0791	1.7976	1.5813	1.7764	.0625	.0791	.1094
15	.0633	1.8461	1.5813	1.7284	.0625	.0949	.125
16	.0633	1.8785	1.5813	1.6644	.0625	.0791	.125
17	.0937	1.8461	.0633	1.5684	.0937	.0791	.1562
18		.1094	.0791	1.4083	.08		.1296
19	.08	.1406	.1107	.0972	.08	.0791	.1134
20	.0972	.0937	.1107	.081	.08	.1107	.1134
21	.132	.1562	.0949	.081	.112	.1107	.1134
22	.096	.0937	.0949	.0972	.1134	.0949	.1134
23	.081	.0937	.0791	.0972	.112	.0949	.0972
24	1.2334	.081	.0937	.0791	.7773	.8907	.8436
Max	1.4548	1.9919	1.656	1.8564	1.3441	1.6644	1.3916
Min	.0633	.08	.0633	.0791	.0625	.0633	.0625
Avg	.5091	.7159	.5536	.6246	.4715	.5781	.5439



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 208 / 11 KV GOMTESH VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1698	.1867	.1494	.1698	.1715	.168	.1698
2	.1698	.168	.1494	.1698	.1524	.1494	.1698
3	.1698	.168	.1494	.1698	.1524	.1494	.1698
4	.1698	.168	.1494	.1698	.1524	.1494	.1698
5	.1698	.1867	.1494	.1698	.1715	.1494	.1698
6	.1886	.1867	.1867	.1886	.1715	.168	.1698
7	.2075	.1867	.168	.2075	.1905	.168	.1886
8	.2263	.1867	.1494	.2263	.2096	.168	.2263
9	.2641	.2801	.1867	.2641	.1524	.2054	.2641
10	.3361	.3048		.2801	.1905	.2641	.3921
11	.3361	.3048	.2452	.2614	.1494	.3395	.3921
12	.2614	.3048	.2452	.2614	.1494	.3395	.3921
13	.2241		.2452	.2614	.1494	.3018	.3361
14	.2241	.1715	.2641	.2241	.1494	.2829	.2241
15	.2614	.2286	.2452	.2054	.1494	.2829	.3174
16	.2801	.2667	.2263	.2054	.1494	.2641	.3174
17	.2987	.2477	.2641	.2241	.1494	.2829	.3921
18		.2241	.2641	.2614	.1494	.2829	.3048
19	.2614	.2241	.2829	.2477	.168	.2641	.2477
20	.2054	.2241	.2641	.2286	.168	.2075	.2286
21	.2054	.2054	.2263	.1905	.168	.2075	.2286
22	.2054	.1867	.1886		.168	.2075	.1905
23	.1867	.168	.1698	.1905	.168	.2263	.1905
24	.1886	.1867	.168	.1698	.1715	.168	.1698
Max	.3361	.3048	.2829	.2801	.2096	.3395	.3921
Min	.1698	.168	.1494	.1698	.1494	.1494	.1698
Avg	.2265	.2159	.2060	.2151	.1634	.2249	.2509

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144054 / 33/11KV Mangaon

Feeder No / Name : 401 / 33 KV MANGAON INDUSTRIAL  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5268	4.4136	4.9228	4.5268	4.4702	4.4136	4.6399
2	4.4702	4.4136	4.6399	4.4702	4.5268	4.3004	4.5268
3	4.357	3.9609	4.5268	4.4136	4.4136	4.2438	4.4136
4	4.4136	4.6399	4.5268	4.357	4.4136	4.2438	4.3004
5	4.4702	4.4136	4.0741	4.4136	4.0741	4.1307	4.4136
6	4.6965	4.1872	4.2438	4.3004	3.7346	4.1307	4.5268
7	4.8663	4.0741	4.8097	4.6965	3.7346	4.201	4.5833
8	4.5268	4.1307	4.8097	4.6399	3.6214	4.5268	4.3004
9	4.2438	4.8097	4.8097	4.1872	3.9043	4.2438	4.9794
10	4.8097	4.4702		4.7531	3.7912	4.8097	4.6399
11	5.2058	5.6019	5.4887	5.0926	3.8477	4.3004	4.9228
12	5.3755	5.4887	5.7716	4.9228	3.8477	4.0741	4.9794
13	4.8097		5.3189	5.0926	3.9609	4.1872	4.8663
14	4.4136	4.7531	4.8663	4.9228	3.9609	4.5268	4.8097
15	4.8097	5.3189	5.1492	4.9794	3.9609	4.8097	4.7531
16	4.9794	4.8663	5.715	5.0926	3.9609	4.8097	4.5268
17	5.0926	4.9794	4.9228	4.9228	3.9043	4.8097	4.7531
18		5.2058	5.2624	4.8663	3.9043	4.0741	4.8663
19	5.2058	4.6965	5.0926	4.9794	3.8477	4.5268	4.3004
20	4.4136	4.357	4.5268	4.3004	3.9609	4.8663	4.6399
21	4.5833	4.6399	4.5833	3.7912	4.0741	4.8097	4.8663
22	4.6399	4.7531	4.6399	4.2438	4.1307	4.8663	4.1307
23	4.1872	4.7531	4.7531	3.678	4.1307	4.8097	4.4136
24	4.5833	4.6399	4.6399	4.7531	4.6399	4.1872	4.8663
Max	5.3755	5.6019	5.7716	5.0926	4.6399	4.8663	4.9794
Min	4.1872	3.9609	4.0741	3.678	3.6214	4.0741	4.1307
Avg	4.6818	4.6768	4.8736	4.5998	4.034	4.4543	4.6258

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 201 / PUJARI MALA AG FEEDER  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.0914	.061	1.6118	1.4022	1.7833	.08
2	.0914	.0914	.061	1.6118	1.3717	1.7833	.08
3	.0914	.0914	.061	1.6118	1.3717	1.7833	.08
4	.0914	.0914	.061	1.6461	1.3717	1.7833	.0823
5	.0914	.1029	.061	1.749	1.3717	1.7833	.0857
6	.0914	.1029	.061	1.8347	1.4327	1.749	.0857
7	.0914	.1029	.061	1.9547	1.4937	1.8519	.0714
8	.0914	.1029	.061	2.0405	.0762	.0914	.0724
9	.0914	.0857	.061	2.0576	.0762	.0914	1.7976
10	.0914	.1029	.061	.0914	.0762	.0762	1.9757
11	2.1948	2.3148	2.0881	.0857	.0762	.0914	2.4348
12	2.3663	2.3148	2.4006	.0857	.0667	.1029	2.4348
13	2.3663	2.4863	2.332	.0857	.0667	.1029	2.3663
14	2.3834	2.4691	1.8861	.0857	.0714	.0857	2.0919
15	2.452	2.452	2.2291	.0857	.0714	.0857	2.0405
16	2.4177	2.4177	2.2462	.0857	.0714	.0857	2.1776
17	2.3491	2.2977	2.2805	.0857	.0714	.0857	.0171
18	2.2462	2.2805	2.2977	.0857	.0686	.0857	
19	.0762	.061	.0857	.0857	.0762	.0857	.0762
20	.0914	.061	.1029	.0914	.0762	.08	.0762
21	.0914	.061	.1029	.0914	.0762	.0892	.0914
22	.1029	.061	.1029	1.2803	1.7833	.0914	.0914
23		.061	.1029	1.326	1.7833	.08	.0914
24	.0914	.0914	.061	1.6118	1.4022	1.7833	.08
Max	2.452	2.4863	2.4006	2.0576	1.7833	1.8519	2.4348
Min	.0762	.061	.061	.0857	.0667	.0762	.0171
Avg	.8758	.8498	.7887	.8909	.6586	.6547	.8035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 202 / 11KV GANPATI MANDIR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.823	.7888				
2	.9945	.823	.7888				
3	.9945	.823	.7888				
4	.9945	.823	.7888				
5	.9945	.8916	.7888				
6	.9945	.9602	.8059				
7	.9945	.8916	.7888				
8	1.0288	.9602	.8059				
9	.9945	.9602	.823	.9602	1.1831	1.3717	1.3032
10				1.0974	1.2689	1.3032	1.0974
11				1.3717	1.2517	1.3717	1.2346
12				1.2689	1.2209	1.2346	1.3717
13				1.3375	1.2887	1.2346	1.2689
14				1.3717	1.2887	1.3717	1.286
15				1.0974	1.153	.8573	1.3032
16				1.2689	1.153	1.2346	1.3032
22							1.0631
23							1.0974
24	.9945	.7316	.7545				
Max	1.0288	.9602	.823	1.3717	1.2887	1.3717	1.3717
Min	.9945	.7316	.7545	.9602	1.153	.8573	1.0631
Avg	.9979	.8687	.7922	1.2217	1.226	1.2474	1.2329

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 203 / SHIRADWAD FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.6173	.2286	.583	.5182	.6173	.583
2	.4877	.5487	.2134	.583	.4877	.6173	.5636
3	.4877	.5487	.2134	.583	.4877	.6173	.5636
4	.4877	.5487	.2134	.583	.4877	.6173	.5506
5	.5487	.583	.2439	.583	.4877	.6173	.5967
6	.5639	.5487	.3353	.6173	.5182	.5487	.5898
7	.5487	.5487	.2743	.6173	.5487	.6173	.5967
8	.5944	.6173	.4115	.6859	.5639	.5792	.6299
9	.6554	.6859	.6097	.823	.7011	.7545	.7125
10	.7011	.6173	.6706	.823	.6859	.7316	.7125
11	.7316	.6516	.7164	.823	.7011	.823	.7888
12	.7888	.6001	.6859	.6859	.663	.6859	.6859
13	.5144	.3772	.5487	.463	.5304	.5487	.5316
14	.6344	.463	.4458	.6001	.6036	.6344	.6173
15	.6859	.5658	.4287	.6344	.663	.6859	.6859
16	.8059	.4973	.7545	.7716	.7293	.6859	.7888
17	.7888	.4287	.7716	.6859	.6554	.7545	.7888
18	.7716	.3772	.7545	.6859	.6706	.7545	.7545
19	.6706		.6859	.8059	.7545	.823	.7316
20	.6173	.3048	.6173	.6554	.6859	.6706	.6706
21	.6859	.3048	.6516	.6401	.6859	.663	.7164
22	.6859	.2896	.6173	.6097	.6859	.663	.6554
23	.6516	.2591	.6173	.6097	.6859	.6706	.5944
24	.5944	.5487	.2439	.583	.5792	.6859	.6783
Max	.8059	.6859	.7716	.823	.7545	.823	.7888
Min	.4877	.2591	.2134	.463	.4877	.5487	.5316
Avg	.6355	.5014	.4981	.6556	.6159	.6694	.6578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 204 / ABDUL LAT AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8004	1.9033	1.8519	.2229	.2229	.2572	.1808
2	1.8004	1.9033	1.8519	.2229	.2058	.2572	.16
3	1.8004	1.9033	1.8519	.2229	.2058	.2572	.1669
4	1.8347	1.9033	1.8861	.2229	.2058	.2572	.1715
5	1.9204	2.0576	1.9719	.2401	.2058	.2572	.1858
6	2.1605	2.1948	2.1605	.2572	.2743	.2572	.2172
7	2.5892	2.692	2.5034	.2401	.2743	.2743	.2229
8	2.9664	2.8807	2.7263	.2401	.2743	.3086	.2429
9	2.915	2.8292	2.7435	2.2977	3.035	3.3779	3.2226
10	2.6406	.2401	.2229	3.0521	3.5151	3.275	3.3482
11	.2229	.2058	.1372	3.3265	3.7037	3.6008	3.618
12	.1886	.12	.1372	3.4979	3.4736	3.1207	3.5151
13	.2058	.1372	.12	3.2922	3.2693	2.7435	3.3608
14	.2058	.2058	.1372	3.2407	3.2693	3.0178	3.2065
15	.2058	.2058	.1886	2.9664	3.219	3.0521	3.2236
16	.2058	.2572	.1886	3.0521	3.2526	3.1207	3.4294
17	.1886	.2401		.2572		.2058	.2572
18	.2058		.2058	.2743	.2	.2401	.2401
19	.1981	.2915	.3086	.2915	.2743	.2915	.2743
20	.2743	.3086	.3429	.3429	.3086	.2429	.2915
21	.2743	.3258	.3429	.3258	.3086	.2559	.3258
22	.2572	.2915	.2915	.2915	.2743	.2559	2.0748
23	.2229	.2743	.2743	.2401	.2572	.2	2.0919
24	1.7318	1.9033	1.7833	.2229	.2401	.2572	.1734
Max	2.9664	2.8807	2.7435	3.4979	3.7037	3.6008	3.618
Min	.1886	.12	.12	.2229	.2	.2	.16
Avg	1.1257	1.0989	1.0534	1.2017	1.3248	1.2243	1.4251

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 205 / 11 KV LATWAD GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.2229	.12	.0686	.0686	.0857	.0924
2	.1886	.2229	.0857	.0686	.0686	.0857	.0905
3	.1886	.2229	.1029	.0686	.0686	.0857	.0914
4	.2229	.2229	.12	.0686	.0686	.0857	.0934
5	.2401	.2229	.1029	.0686	.0686	.0857	.1086
6	.2572	.2401	.12	.0514	.0857	.1029	.0924
7	.2401	.1715	.1543	.0343	.1029	.1029	.0914
8	.2401	.1715	.1543	.0686	.1715	.1715	.0724
9	.2401	.1543	.2058	.1029	.2401	.1543	.1402
10	.2572	.1543	.2401	.0343	.2229	.1543	.181
11	.2401	.1715	.1372	.0343	.2401	.2058	.12
12	.2229	.1543	.1543	.0343	.1715	.1886	.1543
13	.1715	.1715	.2058	.0343	.1928	.1715	.1543
14	.1715	.1715	.1715	.0686	.1696	.1715	.1372
15	.2229	.1715	.2229	.0343	.1886	.1715	.1715
16	.2229	.1543	.1886	.0857	.1886	.1715	.1715
17	.2229		.2058	.1029	.2229	.1543	.1372
18	.2401		.1715	.12	.2204	.1543	.1372
19	.1981	.2229	.2229	.0514	.1372	.1715	.1715
20	.1372	.2058	.1886	.0857	.1029	.1696	.1715
21	.2058	.1543	.1372	.0514	.0686	.1526	.2058
22	.2401	.1715	.1715	.0857	.0857	.1886	.2572
23	.2229	.0857	.1715	.1029	.0857	.0905	.1372
24	.1886	.2229	.1372	.0686	.0857	.0857	.0914
Max	.2572	.2401	.2401	.12	.2401	.2058	.2572
Min	.1372	.0857	.0857	.0343	.0686	.0857	.0724
Avg	.2147	.1847	.1622	.0664	.1386	.1401	.1363

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 206 / 11 KV SOCIETY FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2401	.12	.1715	.2229		.1448
2	.2229	.2401	.1372	.1715	.2058		.1433
3	.2058	.2401	.12	.1715	.1886		.1478
4	.2058	.2401	.12	.1715	.1886		.1267
5	.1886	.2229	.12	.1715	.1886		.1294
6	.2058	.2058	.1372	.1715	.1886		.132
7	.2229	.2058	.12	.1372	.2401		.128
8	.2229	.2229	.12	.2058	.2572		.1267
9	.3258	.2572	.1886	.2058	.2915		.2572
10	.3086	.2572	.2401	.2743	.3086		.2915
11	.3258	.2572	.2401	.2743	.2743		.3258
12	.2401	.1886	.2743	.2915	.2572	.1886	.2915
13	.2058	.12	.1543	.1886	.181	.1886	.2401
14	.2401	.2058	.2401	.2401	.2303	.2401	.2401
15	.2572	.2229	.2401	.2401	.2481	.2572	.2572
16	.2572	.2058	.2401	.2401	.2629	.2743	.2915
17	.2572	.2058	.2401	.2229	.3155	.2229	.3258
18	.2743		.2743	.2572	.2915	.2915	.2915
19	.2591	.1715	.2401		.2743	.2743	.2915
20	.2401	.1372	.2229	.2572	.2401	.2454	.2743
21	.2401	.12	.1886	.2229	.2401	.2229	.2229
22	.2229	.12	.1715	.2058	.2229	.2126	.2229
23	.2229	.1372	.2058	.2058	.2229	.2481	.2229
24	.2401	.2572	.12	.2058	.2401		.1227
Max	.3258	.2572	.2743	.2915	.3155	.2915	.3258
Min	.1886	.12	.12	.1372	.181	.1886	.1227
Avg	.2423	.2035	.1865	.2132	.2409	.2389	.2187



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144055 / 33/11 KV SHIRADWAD

Feeder No / Name : 402 / I-CO SPIN FEEDER

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.5153	4.2181	4.5725	4.5725	4.1152	4.5153	4.6868
2	4.4582	4.2181	4.5153	4.5725	4.0009	4.5153	4.8011
3	4.2867	4.6868	4.7439	4.5725	4.1152	4.5153	4.8011
4	4.401	4.6868	4.6868	4.5725	4.401	4.5725	4.7439
5	4.2867	.0514	4.8011	4.1152	4.401	4.6868	4.8011
6	4.1724	4.5153	4.8011	3.8866	4.2867	4.8011	5.0297
7	4.2295	4.2696	4.8011	3.7151	4.5725	4.9154	4.9726
8	4.7439	4.1152	4.5725	3.3436	5.0297	4.8011	4.5725
9	4.401	4.6868	4.8011	3.1893	4.8011	5.0869	4.7439
10	4.8011	4.2867	4.0009	3.4294	4.4582	4.1724	4.8583
11	4.4582	4.3439	4.1152	3.658	4.4582	4.2295	5.3727
12	5.0869	4.4582	4.5725	3.6008	4.5725	4.2867	4.5153
13	4.6868	4.5725	4.0638	3.5437	4.5725	4.0638	4.8011
14	4.401	4.3439	4.7439	3.7723	4.5725	4.2696	4.8011
15	4.6868	3.9438	4.6868	3.7723	4.7439	4.6296	4.6868
16	4.6868	4.8583	4.8011	3.9438	5.2584	5.0869	5.0869
17	4.7439		4.3724	3.6008	4.5725	4.9154	4.5153
18	4.8583	4.6868	4.8583	3.7151	4.7439	4.3439	4.2867
19	4.3439	4.4582	4.9726	3.4865	4.1724	4.2181	4.0581
20	4.401	4.5153	4.6868	3.658	4.1724	4.3439	4.2295
21	4.5725	4.5153	4.9726	3.6008	4.1724	4.7439	4.2295
22	4.6868	4.6296	4.7439	4.1724	4.5725	4.8011	4.5725
23	4.5153	4.9154	4.7439	4.1724	4.8583	4.8583	5.0869
24	4.6868	4.9726	4.8583	4.2181	3.7723	4.5153	4.5725
Max	5.0869	4.9726	4.9726	4.5725	5.2584	5.0869	5.3727
Min	4.1724	.0514	4.0009	3.1893	3.7723	4.0638	4.0581
Avg	4.5463	4.3021	4.6454	3.8702	4.4748	4.5787	4.7011

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 201 / 11 KV SAHARANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6154		.2241	.6335	.583		.5487
2	.583		.1867	.5853	.5506		.5487
3	.5668		.1867	.5544	.4858		.5182
4	.5506		.1867	.543	.5182		.5182
5	.5506		.1867	.5544	.4858		.503
6	.5506		.2241	.5121	.4858		.503
7	.5668	.5243	.2987	.6036	.4858		.5335
8	.6154	.5243	.3547		.5668	.5571	.5639
9	.6241	.6154	.7842		.5575	.6478	
10	.6687	.6556	.8215	.7209	.6161	.6802	.7362
11	.6836	.6516	.8402	.8192	.6455	.7287	
12	.5944	.5068	.6348		.5868	.6802	.639
13	.4161	.3224	.5609		.3961	.4534	.4588
14	.5944	.3258	.5784		.4694	.6478	.5571
15	.6241	.4607	.7095		.5868	.6802	
16	.6687	.4557	.7842		.6455	.7125	.7537
17		.3734	.7392	.6802		.6455	.6802
18	.7209	.2054	.7783	.6964		.6602	.7125
19		.2054	.7577	.7125		.6455	.7449
20	.6226	.1867	.6516	.6802		.6161	.6802
21		.2241	.6697	.6478		.5868	.6478
22		.2614	.6335	.6478		.5868	.6802
23	.6554	.2614	.7133	.6802		.5868	.6478
24	.6478	.6226	.2241	.6219	.6154	.5898	.5792
Max	.7209	.6556	.8402	.8192	.6455	.7287	.7537
Min	.4161	.1867	.1867	.5121	.3961	.4534	.4588
Avg	.606	.4102	.5304	.6408	.5459	.6297	.6074

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 202 / 11 KV BIRDEV

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631		.7499	1.2548	1.2071		1.3108
2	1.2146		.7499	1.1869	1.1736		1.3108
3			.7316	1.1736	1.1401		1.278
4	1.166		.7316	1.2071	1.1401		1.2452
5	1.1984		.7316	1.2407	1.1736		1.2452
6	1.166		.8048	1.3413	1.2071		1.3108
7	1.2631	1.3413	.9145	1.3565	1.3077		1.3108
8	1.3603	1.3413	1.0059		1.3748	1.4251	1.4255
9	1.3375	1.3592	1.701		1.247	1.4899	
10	1.4118	1.4918	1.7375	1.6598	1.291	1.5384	1.643
11	1.4563	1.4746	1.7375	1.7604	1.3203	1.6194	1.7436
12	1.1294	1.1469	1.2071		1.247	1.3765	.8718
13	.8916	.6962	1.0974		.7335	.8907	.9389
14	1.3077	1.1984	1.5546		1.1149	1.4251	1.4754
15	1.4415	1.2955	1.6827		1.2029	1.4899	
16	1.4118	1.1469	1.7558	1.5927	1.2616	1.5384	1.6095
17		.7316	1.56	1.4899		1.4815	1.5223
18	1.5089	.6401	1.5089	1.4575		1.5123	1.4899
19		.695	1.5432	1.4251		1.4815	1.4899
20	1.4083	.7316	1.4255	1.4575		1.4373	1.4575
21		.7865	1.4413	1.3927		1.4217	1.3927
22		.823	1.4083	1.4575		1.3426	1.4251
23	1.4419	.823	1.4922	1.4089		1.2654	1.4089
24	1.2955	1.4083	.7865	1.3108	1.2574	1.2742	1.3435
Max	1.5089	1.4918	1.7558	1.7604	1.3748	1.6194	1.7436
Min	.8916	.6401	.7316	1.1736	.7335	.8907	.8718
Avg	1.2986	1.0628	1.2525	1.3985	1.2000	1.4123	1.3750

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 203 / 11 KV INDUSTRIAL

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.7664		2.5606	2.4034	2.8166		2.6566
2	2.8166		2.4966	2.4531	2.6825		2.5926
3	2.6825		2.4326	2.4905	2.7664		2.5286
4	2.6825		2.3644	2.5194	2.5987		2.5286
5	2.5987		2.2672	2.556	2.6825		2.4646
6	2.5987		2.3365	2.652	2.6825		2.4646
7	2.6825	2.7328	2.4966	2.652	2.6825		2.5926
8	2.8837	2.7328	2.5926		1.7604	2.3472	2.7206
9	2.915	2.8826	2.9607		1.2826	2.8166	
10	2.9959	3.0849	3.0727	3.0178	1.2449	2.9843	2.8837
11	2.7206	3.2556	3.1687	3.219	1.2071	3.1017	3.1017
12	2.5911	2.8487	2.4326		1.1317	2.9508	2.146
13	2.4291	2.2291	2.4006		.7545	2.1052	2.5652
14	2.8502	2.6063	2.6886		.7545	2.7206	3.0011
15	2.9959	2.9172	2.8166		.7545	2.8178	
16	3.0121	3.12	2.8166	3.1184	.7545	2.8502	3.1184
17		2.8807	2.9172	3.0849		2.8487	3.0514
18	3.0849	2.7526	2.9843	3.0514		2.8807	2.915
19		2.7526	2.9508	2.9843		2.8807	2.915
20	2.7161	2.7206	2.1216	2.9172		2.8166	2.8826
21		2.7526	2.9172	2.9508		2.8807	3.1017
22		2.7854	2.7846	2.934		2.8166	2.9843
23	2.9508	2.7206	2.9843	2.8837		2.7526	2.0119
24	2.8837	2.8502	2.6566	2.8837	2.9508	1.9784	2.6886
Max	3.0849	3.2556	3.1687	3.219	2.9508	3.1017	3.1184
Min	2.4291	2.2291	2.1216	2.4034	.7545	1.9784	2.0119
Avg	2.7929	2.8125	2.6759	2.8206	1.8534	2.7382	2.7234

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 205 / CHANDUR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1			.6478	.663	.6478		
2			.6401	.6706	.6802		
3			.6401	.6962	.6154		
4			.6154	.7377	.6478		
5			.583	.7293	.6478		
6			.6241	.8048	.6478		
7				.852	.6478		
8			.6154				
9			.8421				
10							1.3032
11	1.1142	1.4083					1.3394
12	1.2289	1.326					
13	1.4091	1.3108					1.3394
14	1.3763	1.3108					1.3032
15	1.3108	1.1934					
16	1.2944	1.1934					1.2489
17		1.1203					
18	1.448	1.0883					
22				.5668			
23				.6478			
24			.583	.6706	.6478	.8145	
Max	1.448	1.4083	.8421	.852	.6802	.8145	1.3394
Min	1.1142	1.0883	.583	.5668	.6154	.8145	1.2489
Avg	1.3117	1.2439	.6434	.7039	.6478	.8145	1.3068

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 206 / 11 KV ABHAR PHATA  
INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.0556		3.0178	3.1741	3.1121		3.131
2	3.0178		2.9801	3.1741	3.0933		3.0933
3	3.0556		2.9801	3.1367	3.131		3.0933
4	3.0933		2.9424	3.1459	3.1687		3.0933
5	3.1687		2.9424	3.1741	3.2065		3.131
6	3.1121		2.9801	3.131	3.131		3.1687
7	3.1687	3.131	3.0178	3.1741	3.0933		3.1687
8	3.0933	3.0556	3.0933		3.0178	3.0556	3.0178
9	3.131	3.1047	3.2065		2.8669	3.2065	
10	3.1687	3.2674	3.2065	3.2442	2.7349	3.1687	2.9801
11	3.1687	3.2526	3.2442	3.2819	2.6406	3.2442	3.1687
12	3.0556	3.1121	3.0178		2.4897	3.131	2.7538
13	3.0933	2.9569	2.9235		2.2634	3.1121	2.7538
14	3.2442	3.1417	3.2065		2.3765	3.2065	2.9424
15	3.3196	3.1417	3.2442		2.452	3.2442	
16	3.2065	3.2065	3.2442	3.2442	2.3765	3.2442	2.9424
17		3.131	3.2065	3.3008		3.0933	3.0178
18	3.1687	3.0178	3.1741	3.2819		***	2.9235
19		3.0556	3.2114	3.2065		3.0178	2.9801
20	3.0556	3.0933	3.2114	3.2442		2.9801	3.2442
21		3.131	3.2861	3.1687		3.0933	3.2065
22		3.0933	3.1131	3.2065		3.0933	3.1687
23	3.1687	3.0556	3.2487	3.131		3.131	3.1687
24	3.1121	3.0933	3.0178	3.2114	3.1687	3.131	3.131
Max	3.3196	3.2674	3.2861	3.3008	3.2065	30.9328	3.2442
Min	3.0178	2.9569	2.9235	3.131	2.2634	2.9801	2.7538
Avg	3.1329	3.1134	3.1132	3.2017	2.8425	4.7697	3.0581

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 207 / 11 KV SONAR MALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631				1.1822		1.3077
2	1.2308				1.2146		1.2742
3	1.2631				1.2308		1.2742
4	1.2955				1.2631		1.2742
5	1.2955				1.2308		1.2742
6	1.2955				1.2631		1.2742
7	1.2955				1.2146		1.3077
8	1.2955						
9	1.2742						
10				1.3748			
11		1.5424	1.6933	1.7436			
12		1.6766					
13		1.6575	1.6766				
14		1.6575	1.6766				
15		1.587	1.643	1.7436			
16		1.5912	1.576	1.6933			
17		1.6095	1.576				
18		1.576	1.5729				
22				1.2146		1.2071	1.2146
23				1.2955		1.3077	1.2955
24	1.2146				1.2146	1.2574	1.3077
Max	1.2955	1.6766	1.6933	1.7436	1.2631	1.3077	1.3077
Min	1.2146	1.5424	1.5729	1.2146	1.1822	1.2071	1.2146
Avg	1.2723	1.6122	1.6306	1.5109	1.2267	1.2574	1.2804

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 208 / 11 KV MAULI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2631		1.166	1.1469	1.2631		1.2125
2	1.1984		1.1336	1.1336	1.2308		1.2125
3	1.166		1.1336	1.1142	1.2146		1.1797
4	1.2146		1.1174	1.1271	1.166		1.1797
5	1.1984		1.1174	1.1469	1.166		.9877
6	1.2631		1.1498	1.1934	1.1984		1.1797
7	1.3117	1.3108	1.1984	1.2125	1.1984		1.2616
8	1.247	1.3435	1.2955		1.0526	1.1142	1.3108
9	1.3765	1.3763	1.4413		.9962	1.2631	
10	1.4737	1.4746	1.4575	1.4091	.9488	1.3603	1.3763
11	1.4899	1.4091	1.4575	1.4419	.933	1.4575	1.5074
12	1.3117	1.3923	1.2631		.8223	1.3279	1.278
13	1.1012	1.073	1.166			1.1336	1.1142
14	1.2631	1.1469	1.1822		.3795	1.2955	1.4091
15	1.3279	1.3108	1.3279		.4428	1.3765	
16	1.4089	1.3763	1.3765	1.4255	.4586	1.4251	1.3763
17		1.2146	1.3603	1.4575		1.4575	1.3927
18	1.4419	1.1012	1.4091	1.4251		1.4737	1.4089
19		1.1336	1.3592	1.4575		1.4575	1.4251
20	1.3435	1.1984	1.2631	1.4251		1.3927	1.3603
21		1.2793	1.4746	1.3279		1.3441	1.4089
22		1.2631	1.3108	1.3603		1.2955	1.3279
23	1.4091	1.2631	1.3763	1.2955		1.2631	1.2955
24	1.2146	***	1.2146	1.3279	1.2955	.8848	1.2742
Max	1.4899	10.1585	1.4746	1.4575	1.2955	1.4737	1.5074
Min	1.1012	1.073	1.1174	1.1142	.3795	.8848	.9877
Avg	1.3012	1.7681	1.2813	1.3016	.9854	1.3131	1.2945



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144072 / 33/11 KV CHANDUR

Feeder No / Name : 209 / 11 KV JAIHIND FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167		.6036	.6516	.7167		.679
2	.679		.5658	.6154	.679		.679
3	.679		.5658	.6219	.679		.679
4	.7167		.5658	.6584	.7167		.679
5	.679		.5658	.6653	.7167		.679
6	.7167		.5658	.7095	.7545		.7167
7	.679	.679	.5658	.695	.679		.7167
8	.7167	.679	.6036		.679	.6413	.679
9	.7167	.6348	.7167		.679	.679	
10	.7167	.6653	.7095	.7545	.679	.679	.7167
11	.7167	.6154	.7095	8.8838	.679	.7167	.7922
12	.6413	.6154	.5975		.6036	.7167	.6413
13	.679	.5792	.5658		.5658	.6413	.6036
14	.7545	.5144	.7167		.6036	.679	.679
15	.7922	.6219	.7167		.6413	.679	
16	.7922	.6154	.679	.7545	.6413	.7167	.7167
17		.6413	.7023	.7545		.7167	.7167
18	.7545	.6036	.7316	.7922		.7167	.7167
19		.6036	.6878	.7545		.7167	.7167
20	.7167	.6036	.7023	.7545		.7167	.7545
21		.6413	.6516	.7167		.7167	.7545
22		.6413	.6878	.7545		.7167	.7545
23	.2263	.6036	.6653	.7167		.7167	.7167
24	.679	.7167	.6036	.6722	.7167	.7167	.7167
Max	.7922	.7167	.7316	8.8838	.7545	.7167	.7922
Min	.2263	.5144	.5658	.6154	.5658	.6413	.6036
Avg	.6884	.6264	.6436	1.1625	.6723	.6990	.7047

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 201 / 11KV TELEPHONE EXCHANGE SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	.1715	.1524	.1524	.1494	.1524	.1524
2	.1524	.1524	.1524	.1524	.1494	.1524	.1524
3	.1524	.1524	.1334	.1715	.1494	.1524	.1334
4		.1715	.1334	.1715	.1494	.1524	.1334
5	.1715	.1715	.1334	.1524	.1494	.1524	.1334
6	.1715	.1524		.1524	.1494	.1524	.1524
7	.1715	.1715	.1715	.1524	.168	.1524	.1715
8	.1715	.1524	.1334	.1524	.1524	.1524	.1524
9	.1524	.1905	.2096	.1494	.1524	.1524	.1867
10	.2096	.2096	.2096	.1867	.1524	.2096	.1867
11	.2286	.2096	.1905	.2054	.1524	.1905	.2241
12	.1905	.1905	.1905	.2054	.1524	.1715	.2241
13	.1905	.1715	.1715	.168	.1715	.1334	.1867
14	.2096	.1524	.1524	.1867	.1715	.1524	.1867
15	.2286	.1715	.1715	.1867	.1524	.1905	.1867
16	.2096	.1905	.1905	.1867	.1524	.2096	.2054
17		.2096	.1905	.1867	.1715	.1905	
18	.1905	.2096	.1905	.1867	.1715	.1905	
19	.1905	.2096	.1905	.2054	.2096	.1905	
20	.1524	.1524	.1715	.1867	.2096	.1715	
21	.1715	.1524	.1715	.1867	.1524	.1715	
22	.1905	.1715	.1715	.168	.1524	.1905	
23	.1905	.1524	.1905	.168	.1524	.1905	
24	.1905	.1905	.1715	.4763	.168	.1524	.1715
Max	.2286	.2096	.2096	.4763	.2096	.2096	.2241
Min	.1524	.1524	.1334	.1494	.1494	.1334	.1334
Avg	.1845	.1762	.1715	.1874	.1609	.1699	.1729

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 202 / 11 KV KHOTWADI

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9907	.8962	.8589	.8413	.8215	.9709
2	.8962	1.0288	.8589	.8215	.7842	.7842	.9335
3	.8962	.9526	.8215	.7842	.7316	.7842	.8962
4	.8589	.9145	.7842	.8029	.695	.7842	.8589
5	.8589	.8764	.7468	.8402	.695	.8215	.8215
6	1.0082	.9145	.7842	.8215	.7316	.8215	.8962
7	1.0082	1.0669	.8215	1.0082	.7682	.8589	.9709
8	.8962	.8962	.8962	.8589	.7095	.8215	.9335
9	1.1203	.9709	.9526	1.0425	.6348	.9335	1.134
10	1.0669	1.0829	1.0288	.9877	.5975	.8962	1.1706
11	1.1812	1.1203	1.105	1.0242	.7095	1.1949	1.0608
12	1.105	1.0829	.9907	.9511	.5601	1.1203	1.0608
13	1.0669	1.0456	.9526	.8779	.5228	.9335	.9511
14	1.1431	.9335	.8764	.9877	.4854	.9149	1.0425
15	1.0288	.9709	1.105	1.0608	.6348	1.0082	1.1157
16	1.105	1.0082	1.0288	1.0974	.6722	1.0829	1.1706
17	1.2193	1.0456	.9526	1.0242	.6348	1.0456	
18	1.1431	1.0082	.9907	1.0059	.6348	1.0082	
19	1.0669	1.0829	1.0098	.9511	.6722	1.1576	
20	1.0479	1.0456	1.0288	.8779	.6722	1.1203	
21	1.0479	.9709	.9526	.9511	.7842	1.0456	
22	.9907	1.0082	.9145	1.0059	.7842	.9709	
23	.9526	.9709	.8764	.8779	.8215	1.0669	
24	.9709	.9526	.9335	.8764	.823	.8215	1.0082
Max	1.2193	1.1203	1.105	1.0974	.8413	1.1949	1.1706
Min	.8589	.8764	.7468	.7842	.4854	.7842	.8215
Avg	1.0255	.9975	.9295	.9332	.6917	.9508	.9998

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 203 / 11 KV SARITA POLYMER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5818	3.5818	3.5056	3.6199	3.3794	3.4294	3.5056
2	3.5437	3.4865	3.4675	3.5818	3.2861	3.3913	3.4675
3	3.5437	3.5056	3.4294	3.4294	3.2114	3.3913	3.4294
4	3.5056	3.5246	3.3913	3.3913	3.1367	3.3722	3.3913
5	3.5056	3.5437	3.4294	3.3532	3.0994	3.4294	3.3532
6	3.5246	3.5818	3.4675	3.4294	3.1741	3.5056	3.315
7	3.5627	3.658	3.5246	3.5056	3.1927	3.1817	3.4103
8	3.5437	3.4675	3.5818	1.6385	2.5149	3.1436	3.3913
9	3.5818	3.7342	3.658	3.5101	2.21	3.2769	3.6595
10	3.8104	3.7913	3.6961	3.4541	2.0957	3.296	3.6408
11	3.7913	3.8104	3.7723	3.6408	2.0005	3.4484	3.5848
12	3.7342	3.4675	3.7151	3.5662	1.9433	3.3913	3.5101
13	3.6199	3.3913	3.5437	3.4355	1.6194	3.296	3.2114
14	3.5437	3.2388	3.4294	3.5101	1.7337	3.3341	3.3234
15	3.8866	3.4294	3.3532	3.5848	1.7147	3.4294	3.3608
16	3.8104	3.5818	3.7342	3.4728	1.7147	3.6199	3.2674
17	3.8676	3.6199	3.7151	3.5101	1.6575	3.5818	3.3981
18	3.8104		3.6961	3.5848	1.6385	3.5627	3.4541
19	3.7723	3.5818	3.658	3.5475	1.6004	3.5818	3.5101
20	3.7342	3.6199	3.6199	3.3981	1.8861	3.5437	3.3794
21	3.658	3.658	3.677	3.4385	3.3722	3.5056	
22	3.7342	3.7151		3.5475	3.4484	3.5818	
23	3.6961	3.658	3.677	3.5662	3.4103	3.6199	
24	3.5818	3.6199	3.5437	3.658	3.4355	3.4294	3.5246
Max	3.8866	3.8104	3.7723	3.658	3.4484	3.6199	3.6595
Min	3.5056	3.2388	3.3532	1.6385	1.6004	3.1436	3.2114
Avg	3.6643	3.5768	3.5776	3.4323	2.5198	3.4310	3.4328

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ES

Feeder No / Name : 204 / RENUKANAGAR

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3167	2.1719	1.5927	2.1176	2.1216	2.1357	2.2805
2	2.2805	2.21	1.5565	2.0995	2.1033	2.0995	2.2443
3	2.2805	2.0538	1.5203	2.0271	2.0485		2.2081
4	2.2624	2.21	1.4842	2.0633	1.9753	1.9909	2.1719
5	2.2624	2.1719	1.448	2.0995	2.0538	2.0271	2.1357
6	2.2443	2.0957	1.5565		2.0485	2.0271	2.0995
7	2.3891	2.21	1.6651		2.1216	2.2805	2.2443
8	2.1719	1.9547	1.5565	2.1357	2.0271	2.0995	2.1719
9	2.5339	2.1719	2.191	2.4143	2.0995	2.3891	
10	2.5911	2.2443	2.553	2.524	2.1719	2.4615	
11	2.6673	2.3529	2.6673	2.6337		2.5339	
12	2.5149	1.8823	2.5149	2.4143		2.3891	
13	2.2862	1.8099	2.4387	2.3899	1.5203	2.2624	
14	2.3243	1.7737	2.3243	2.4874	2.0271	2.4072	
15	2.5911	1.7013	2.553	2.5972	2.0633	2.4977	
16	2.4768	1.6651	2.5911	2.6337	2.0995	2.5339	
17	2.4387	1.7375	2.5149	2.5393	2.0271	2.4977	
18	2.3624	1.7737	2.5911	2.4143	2.1719	2.4615	
19	2.3815	1.6651	2.553	2.3411	2.1719	2.3891	
20	2.3243	1.7375	2.4768	2.2314	2.0271	2.3529	
21	2.4387	1.7013	2.4387	2.3045	2.3167	2.2805	
22	2.3243	1.6651	2.3624	2.2862	2.2443	2.3167	
23	2.2862	1.5927	2.2862	2.268	2.1719	2.3529	
24	2.371	2.2481	1.7147	2.1437	2.2131	2.1719	2.3167
Max	2.6673	2.3529	2.6673	2.6337	2.3167	2.5339	2.3167
Min	2.1719	1.5927	1.448	2.0271	1.5203	1.9909	2.0995
Avg	2.3800	1.9500	2.1313	2.3257	2.0830	2.3025	2.2081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 205 / 11 KV Sanmati Vg Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8473	1.9814	1.5729	1.6461	1.6827	1.7924	1.9022
2	1.829	1.8671	1.5364		1.6095	1.829	1.8656
3	1.829	1.829	1.4998	1.5364	1.5364	1.829	1.829
4	1.7924	1.848	1.4632	1.4998	1.5546	1.8473	1.7924
5		1.9052	1.5364	1.5364	1.6095	1.8473	1.829
6	1.9022	1.9243	1.6095	1.5546	1.6461	1.8839	1.8656
7	1.9936	1.9433	1.701	1.6095	1.6644	1.7375	1.9204
8	1.7741	1.7193	1.7375	1.4632	1.4815	1.701	1.9022
9	2.0668	1.9936	2.2862	1.7558	1.1523	2.268	
10	2.2862	2.0668	2.3624	1.9753	1.0974	2.3045	
11	2.2445	2.1582	2.3243	2.0302	1.2254	2.3777	
12	2.1769	1.957	2.2862	1.9387	1.134	2.2862	
13	2.1719	1.9022	2.21	1.8473	.7499	2.1948	
14	2.1791	1.8656	2.21	1.9204	.7682	2.3228	
15	2.2481	1.9022	2.0957	1.9387	.8048	2.3594	
16	2.21	1.9387	2.1338	1.957	.823	2.3777	
17	2.2565	1.9753	2.21	2.0119	.7499	2.2862	
18	2.3152	1.9387	.9526	2.0302	.823	2.1033	
19	2.2779	1.7924	1.829	1.9753	.8596	2.1582	
20	2.2862	1.7558	1.7147	1.9204	.9511	2.0119	
21	2.2405	1.7193	1.7909	1.9387	1.8107	1.9753	
22	2.21	1.6644	1.7147	1.9204	1.7924	1.9204	
23	2.1719	1.6461	1.829	1.9022	1.7924	1.9753	
24	1.8473	2.0005	1.6095	1.6766	1.7558	1.7924	1.9387
Max	2.3152	2.1582	2.3624	2.0302	1.8107	2.3777	1.9387
Min	1.7741	1.6461	.9526	1.4632	.7499	1.701	1.7924
Avg	2.0938	1.8873	1.8423	1.8080	1.2948	2.0492	1.8717

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL  
ESFeeder No / Name : 206 / 11 KV SARADA FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8578	2.8197	2.8959	2.7816	4.8286	2.5339	2.6673
2	2.8197	2.7816	2.8578	2.6673	4.904	2.5149	2.6292
3	2.7816	2.7435	2.8197	2.6292	4.7531	2.5149	2.5911
4	2.7816	2.7625	2.7816	2.5911	4.6022	2.5149	2.6292
5	2.8197	2.8197	2.7435	2.5911	4.7531	2.572	2.6673
6	2.8387	2.7816	2.8197	2.6673	4.8286	2.6101	2.7435
7	2.8387		2.8578	2.7054	4.9417	2.5339	2.7816
8	2.7816	2.7816	2.6482	2.7816	2.21	2.5149	2.5911
9	2.8197	2.9531	2.9721	2.8959	1.8671	2.8769	
10	2.8959	2.9721	2.9721	2.7816	1.9814	2.8578	
11	2.8959	3.0483	3.0483	2.6673	2.0576	2.8959	
12	2.8578	2.934	2.934	2.5911	2.0386	2.9721	
13	2.8387	2.8578	2.8959	2.5149	1.9433	2.8006	
14	2.8578	2.7816	2.8578	2.7054	1.9243	2.8197	
15	2.9721	2.8578	2.934	2.7435	1.9433	2.934	
16	2.934	2.9721	2.8959	2.6673	1.9624	3.0102	
17	3.0483	3.0102	2.934	2.5911	1.9433	2.9721	
18	2.9721		2.8578	2.6292	1.9624	2.8578	
19	2.934	2.9912	2.7816	2.553	1.9052	3.0102	
20	2.915	2.9721	2.8197	4.7798	2.0957	2.9721	
21	2.8959	2.934	2.7816	4.9795	2.553	2.934	
22	2.8578	2.8578	2.8197	5.0926	2.6292	2.8578	
23	2.8197	2.8387	2.7816	4.9417	2.5911	2.7435	
24	2.8769	2.7816	2.934	2.8197	5.1307	2.572	2.7054
Max	3.0483	3.0483	3.0483	5.0926	5.1307	3.0102	2.7816
Min	2.7816	2.7435	2.6482	2.5149	1.8671	2.5149	2.5911
Avg	2.8713	2.8751	2.8602	3.0570	3.0146	2.7665	2.6673

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144108 / 33/11 KV PARVATI INDUSTRIAL

ES

Feeder No / Name : 207 / 11 KV MANAPASANT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9814	2.1338	1.7909		1.5684	1.4861	2.0576
2	1.9814	2.0576	1.7528	2.2481	1.4377	1.5242	2.0195
3	2.0195	2.0957	1.7147		1.3443	1.5242	1.9814
4	2.0195	2.0957	1.7528	2.1338	1.2696	1.5051	1.9433
5	2.0195	2.1338	1.8099	2.0767	1.3256	1.5051	1.9052
6	2.0386	2.0957	1.8671		1.419	1.5432	2.0195
7	2.1338	2.191	1.9052	2.191	1.4937	1.6004	2.0576
8	2.0576	2.2862	1.829	2.1338		1.6194	2.0195
9	2.191	2.1719	2.2862	2.1658		2.0005	
10	2.1719	2.2481	2.3243	2.0165	1.2574	2.1719	
11	2.5149	2.2862	2.3624	1.9044	1.2193	2.21	
12	2.4768	2.2862	2.3243	1.7924	1.2193	2.0957	
13	2.5149	2.191	2.21	1.7177	1.2384	2.0005	
14	2.21	2.0576	2.2481		1.2193	2.0576	
15	2.3624	2.0957	2.1719	1.9605	1.2384	2.1338	
16	2.2862	2.1719	2.3243	1.8671	1.2193	2.21	
17	2.2862	2.1338	2.3624	1.8484	1.2193	2.191	
18	2.21	2.1719	2.2862	1.7177	1.1812	2.0576	
19	2.2481	2.0957	2.21	1.6804	1.1622	2.21	
20	2.1338		2.1338	1.643	1.1431	2.1719	
21	2.0957	1.8671	2.0957	1.7177	1.4861	2.1338	
22	2.1719	1.829	2.0767	1.7737	1.5051	2.0957	
23	2.1338	1.7909	2.0576	1.643	1.4861	2.1338	
24	2.0005	2.0957	1.829	2.0005	1.587	1.4861	2.0957
Max	2.5149	2.2862	2.3624	2.2481	1.587	2.21	2.0957
Min	1.9814	1.7909	1.7147	1.643	1.1431	1.4861	1.9052
Avg	2.1775	2.1123	2.0719	1.9116	1.3291	1.9028	2.0110



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING  
STATI

Feeder No / Name : 404 / 33 KV KOROCHI

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144114 / 33/33 KV LAXMI SWITCHING

STATI

Feeder No / Name : 406 / 33 KV INDUSTRIAL FEEDER

Feeder KV- 33 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3375	1.749	1.3889	2.1605	.7716		
2	1.5432	2.0062	1.5432	1.9033			
3	1.5432	2.0576	1.5432	1.749	.4115		
4	1.6461	2.1605	1.6461	1.4403			
5	2.0062	2.0576	1.6461	1.749			.2572
6	1.1317	1.9033	1.6975	1.9547			.3086
7	1.6461	2.7263	1.1831	1.0288			.2572
8	1.8004	.8745	1.5947	1.8004		.2058	
9	1.3375	1.9547	1.5947	1.0802			.3601
10	.9259	2.572	1.6461	1.286			.6687
11	1.6975	1.9033	.3601	1.8004			1.3889
12	1.9033		1.749	1.0288			1.3889
13	1.749	.7716	1.749	1.2346			.823
14	1.3375	1.5432	1.6975				.3601
15	1.3375	2.3148	1.3375	.3086			1.3889
16	1.3375	2.0062	1.8519	.2572			1.3375
17	1.3375	2.8807	1.749				.8745
18	1.9033	1.8004	1.749				.8745
19	2.0062	1.2346	1.749				.9259
20	2.0576	1.8004	2.2634				1.1831
21	2.1605	1.749	2.6749	.7716			1.1317
22	2.2634	1.6461	1.6461	1.1831			1.2346
23		1.8519	1.9033				1.286
24	1.5432	1.5432	1.3889	1.286	1.1317		
Max	2.2634	2.8807	2.6749	2.1605	1.1317	.2058	1.3889
Min	.9259	.7716	.3601	.2572	.4115	.2058	.2572
Avg	1.6327	1.8742	1.6397	1.3346	.7716	.2058	.8916

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 202 / 11 KV ABDUL LAT GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0819	.0754	.0366	.0686	.0686	.0671	.0716
2	.0594	.0739	.0518	.0701	.0503	.0648	.0709
3	.0549	.0671	.0648	.0671	.0486	.0663	.0709
4	.0587	.0663	.0419	.0671	.0492	.064	.0686
5	.0838	.0663	.0358	.0686	.0503	.061	.0678
6	.0829	.0678	.0333	.0732	.064	.0572	.0663
7	.0714	.0678	.0391	.0754	.061	.0867	.0905
8	.0372	.0754	.0452	.0671	.0572	.0754	.1132
9	.112	.1132	.181	.1829	.0648	.1494	.1494
10	.1132	.1848	.1886	.1867	.1478	.2172	.2172
11	.1867	.2054	.1494	.1829	.1509	.2195	.2218
12	.1509	.1494	.112	.1848	.1494	.2054	.1867
13	.1132	.1267	.112	.1494	.132	.2033	.1509
14	.1509	.1109	.112	.1886	.1509	.2195	.1494
15	.1494	.128	.0934	.2172	.1132	.2172	.1509
16	.1132	.1307	.112	.1867	.1509	.1867	.0934
17	.1132	.0934	.0739	.1509	.1307	.1663	.0934
18	.1494	.0427	.1132	.1132	.0716	.1006	.0739
19		.0465	.0747	.0924	.0732	.0671	.0829
20	.0739	.0377	.1109	.0602	.0572	.0572	.0602
21	.1109	.0373	.0739	.0686	.0709	.0739	.0791
22	.1109	.04	.0732	.0701	.0686	.0747	.0886
23	.0943	.0352	.0701	.0693	.0739	.0732	.0914
24	.081	.0754	.0333	.0686	.0678	.0701	.0732
Max	.1867	.2054	.1886	.2172	.1509	.2195	.2218
Min	.0372	.0352	.0333	.0602	.0486	.0572	.0602
Avg	.1023	.0882	.0847	.1137	.0885	.1185	.1076

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 204 / 11 KV GANGOBA MANDIR

GAOTHAN FEEDER

GOVTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6478	.6539	.4801	.5937	.6485	.6173	.6344
2	.6154	.5792	.4359	.6133	.6516	.6068	.6135
3	.6203	.5639	.4144	.5898	.6401	.5895	.5959
4	.6274	.5761	.4115	.5601	.6089	.5487	.583
5	.6154	.5898	.4908	.5761	.6173	.5959	.6241
6	.6874	.6371	.5373	.6554	.631	.6104	.6661
7	.7045	.6371	.5548	.6554	.6706	.6706	.6783
8	.7116	.57	.5182	.6036	.6081	.5571	.6344
9	.6958	.5898	.6722	.6325	.6401	.6562	.664
10	.6481	.5533	.6874	.7042	.7023	.7562	.7042
11	.6958	.6133	.6722	.663	.6405	.7186	.7712
12	.6722	.5535	.6226	.6554	.5668	.6964	.7377
13	.583	.4784	.5571	.583	.5256	.6062	.5636
14	.663	.4835	.6226	.5765	.5801	.6554	.663
15	.6642	.5316	.7042	.6554	.6478	.8326	.7377
16	.7042	.6371	.7377	.6962	.6325	.7773	.7712
17	.7042	.5898	.7712	.6802	.6249		.7712
18	.6562	.5138	.7377	.6958	.4534	.788	.7537
19	.7042	.4801	.7712	.8048	.5426	.7449	.7432
20	.7042	.5853	.6882	.7202	.5731	.7712	.763
21	.78	.5853	.7209	.7712	.7461	.7975	.78
22	.7712	.6447	.6882	.7042	.7545	.7186	.7802
23	.6706	.567	.6554	.6443	.6783	.7455	.7042
24	.6796	.6706	.5316	.6554	.6516	.6443	.6588
Max	.78	.6706	.7712	.8048	.7545	.8326	.7802
Min	.583	.4784	.4115	.5601	.4534	.5487	.5636
Avg	.6761	.5785	.6118	.6537	.6265	.6828	.6915

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 144116 / 33/11 KV ABDUL LAT

Feeder No / Name : 205 / 11 KV INDIRA NAGAR GOVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4858	.5533	.2772	.5281	.4915	.5407	.547
2	.4807	.4877	.2534	.4999	.4807	.5304	.5079
3	.4908	.4843	.2149	.4843	.4748	.5426	.4752
4	.463	.4687	.2058	.4687	.421	.5144	.4748
5	.4694	.4801	.2534	.4641	.4481	.4973	.4862
6	.5316	.5243	.2987	.4801	.4915	.4973	.503
7	.4999	.5243	.3658	.4915	.5121	.5761	.5304
8	.5636	.4915	.3582	.5571	.5365	.6009	.5992
9	.6958	.5571	.6401	.6562	.6009	.6249	.6642
10	.6722	.5304	.6401	.7186	.6249	.68	.5761
11	.6325	.5144	.6325	.6481	.6097	.6874	.6226
12	.57	.3544	.6081	.6036		.5967	.57
13	.4409	.3292	.4915	.5365		.5365	.5365
14	.5967	.394	.6226	.6036	.6241	.6483	.663
15	.5426	.5068	.6036	.5967	.6241	.6722	.7042
16	.583	.4973	.6706	.5967	.5937	.6249	.6882
17	.5898	.5028	.7377	.6081	.6249	.68	.6882
18	.6722	.3982	.7209	.6481	.6019	.664	.7209
19	.7209	.3018	.6249	.6401	.5624	.6401	.7125
20	.5898	.3018	.6081	.5967	.5243	.6562	.6706
21	.6554	.3018	.6081	.5761	.5937	.6062	.6081
22	.5571	.3018	.5312	.5506	.583	.6036	.5801
23	.57	.2987	.5312	.5441	.5506	.5636	.6036
24	.506	.57	.2987	.5636	.4858	.5441	.5506
Max	.7209	.57	.7377	.7186	.6249	.6874	.7209
Min	.4409	.2987	.2058	.4641	.421	.4973	.4748
Avg	.5658	.4448	.4916	.5692	.5482	.5970	.5951

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 402 / TILAWANI MINOR

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	1.4289
Max	1.4289
Min	1.4289
Avg	1.4289

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARANJI(RURAL)[027] BU 9121

Substation No/ Name :- 148015 / 220 KV TILAWANI

Feeder No / Name : 403 / 33KV MANGAON

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	8.2876
Max	8.2876
Min	8.2876
Avg	8.2876

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 201 / 11KV TAKWADE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7209	.6962	.2984	.6299	.6554	.663	.6464
2	.6882	.6962	.2818	.6371	.6226	.6706	.663
3	.6882	.663	.2818	.5365	.6226	.6299	.663
4	.6882	.663	.2984	.503	.6226	.6299	.6464
5	.7209	.6299	.2984		.6226	.5801	.6464
6	.7209	.6299	.3315	.5365	.6062	.5868	.6299
7	.7209	.7127	.3978	.5533	.6882	.7459	.7293
8	.7209	.6706	.3978	.6722	.7045	.663	.7293
9	.852	.6371	.7459	.8259	.8356	.788	.8288
10	.7865	.6133	.7956	.7282	.7045	.7712	.8288
11	.852		.7956	.7526	.8122	.8453	.7956
12	.7373	.5197	.7343	.8029	.6962	.7956	.8619
13	.7459	.3647	.4843	.639	.6036	.6299	.7449
14	.7127	.3481	.664	.6226		.663	.6562
15	.8288	.2984	.7186		.8048	.663	.7811
16	.8619	.3481	.8223	.7537	.788	.5967	.7926
17	.8288	.3647	.7682	.7045	.7956	.779	.7935
18	.8453	.2818	.7362	.7209	.8288	.8122	.7773
19	.8288	.3149	.6882	.8192	.5636	.7956	.8097
20	.8288	.3481	.7202	.7209	.7625	.779	.7537
21	.8288	.3481	.7293	.7209	.7625	.7956	.7935
22	.7956	.3315	.7127	.6882	.7625	.7127	.7611
23	.7459	.3481	.7459	.6554	.7293	.7293	.8192
24	.7537	.7293	.3149	.6796	.6882	.7127	.6796
Max	.8619	.7293	.8223	.8259	.8356	.8453	.8619
Min	.6882	.2818	.2818	.503	.5636	.5801	.6299
Avg	.7709	.5025	.5734	.6774	.7079	.7099	.7430



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 202 / 11 KV PATIL MALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3592	1.3426	.5344	1.286	1.2597	1.326	1.1336
2	1.2929	1.2929	.583	1.166	1.2266	1.3077	1.2146
3	1.2597	1.2431	.583	1.1012	1.1934	1.2929	1.2146
4	1.2266	1.2431	.5992	1.0486	1.1934	1.2431	1.166
5	1.2266	1.1934	.6154	1.0159	1.1271	1.2071	1.1174
6	1.1934	1.1934	.6478	1.0364	1.1271	1.2071	1.166
7	1.1934	1.0277	.6316	1.0437	1.1603	1.2742	1.2308
8	1.1934	.8383	.7773	1.1523	1.1934	1.2763	1.2955
9	1.4586	.9221	1.3441	1.4083	1.3923	1.4586	1.4413
10	1.4255	.9556	1.3927	1.4232	1.4918	1.3923	1.4575
11	1.5249	.7712	1.4089	1.4563	1.3923	1.5249	1.4413
12	1.3923	.7042	1.2967	1.3592	1.3923	1.4251	1.4089
13	.9945	.502	.9014	.9945	1.0608	1.0364	1.0753
14	1.1401	.6154	1.2003	1.1271	1.1603	1.1822	1.2492
15	1.4586		1.3443		1.4083	1.3927	1.3916
16	1.4918		1.4083	1.3592	1.3923	1.3279	1.4548
17	1.2929	.3887	1.3923	1.3923	1.4419	1.4899	1.3923
18	1.3592	.5344	1.3443	1.4083	1.4754	1.4737	1.4548
19	1.5249	.6478	1.3123	1.4918	1.5912	1.4899	1.439
20	1.4918	.6964	1.2803	1.3592	1.4419	1.4575	1.3092
21	1.4918	.7287	1.3443	1.4255	1.4586	1.4575	1.4083
22	1.4918	.7287	1.3123	1.3923	1.4754	1.3441	1.4083
23	1.4255	.6802	1.2803	1.326	1.4419	1.3927	1.4243
24	1.3923	1.4089	.664	1.2323	1.2929	1.3592	1.3117
Max	1.5249	1.4089	1.4089	1.4918	1.5912	1.5249	1.4575
Min	.9945	.3887	.5344	.9945	1.0608	1.0364	1.0753
Avg	1.3459	.8936	1.0499	1.2611	1.3246	1.3475	1.3169

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 204 / 11 KV DRAINAJE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	1.0059	.6161	.9054	.9614	1.0059	1.0288
2	1.0277	.9724	.5601	.8383	.8951	.9724	1.0288
3	.9945	.9724	.5601	.8139	.9054	.9724	.9945
4	1.0059	.9724	.5975	.7712	.9282	.9221	.9945
5	.9614	.9221	.6348	.788	.9282	.8551	.9602
6	.9614	.8718	.6161	.8048	.8619	.8048	.9774
7	.9614	.8718	.7059	.8383	.9614	1.0059	1.1317
8	1.0059	.7377	.6687	.884	.9945	1.1065	1.1488
9	1.1603	.8551	1.085	1.0059	1.1271	1.2929	1.2597
10	1.1934	.788	1.1012	1.0623	1.0608	1.3094	1.2308
11	1.2266	.8383	1.2308	1.1126	1.2071	1.3592	1.2944
12	1.094	.8383	1.1142	1.1603	1.3923	1.2266	1.2431
13	.7956	.7133	.9175	.8288	.9054	1.0059	1.0322
14	.9614	.6201	.9503	.9614	1.094	1.1401	1.1984
15		.7716	1.1469		1.3413	1.3094	1.2631
16	1.2431		1.2597		1.3077	1.2793	1.3279
17	1.2266		1.1142	1.3592	1.3413	1.3765	1.3765
18	1.1934		1.2125	1.3748	1.3748	1.278	1.3123
19	1.1934	.905	1.1603	1.2266	1.2266	1.2452	1.2631
20	1.2239	.8869	1.0608	1.1271	1.1271	1.1963	1.0364
21	1.2597	.8869	1.1568	1.2266	1.1934	1.286	1.2308
22	1.2431	.924	1.0395	1.1271	1.1271	1.2346	1.1401
23	1.1271	.8402	1.0898	1.094	1.1271	1.2003	1.1568
24	1.1271	1.0277	.7468	.9835	.9945	1.0277	1.0852
Max	1.2597	1.0277	1.2597	1.3748	1.3923	1.3765	1.3765
Min	.7956	.6201	.5601	.7712	.8619	.8048	.9602
Avg	1.0992	.8677	.9311	1.0134	1.0993	1.1422	1.1548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 205 / BALIRAJA

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.5735	.6226	.6882	.663	
2		.5898	.663	.6554	.6299	
3		.5898	.6226	.6226	.6299	
4		.5898	.6706	.5898	.6299	
5		.5898	.6962	.6226	.6133	
6		.5898	.7459	.6882	.6133	
7		.639	.8048	.7045	.663	
8		.7373	.6562			
9		.7373			.7625	
10					.8619	.8848
11	.9503				.8785	.9012
12	1.0159				.9614	.9503
13	.9945				.9175	.8855
14	.9831				.9175	.8855
15	.9175				.9175	.8962
16	.852				.9503	.8583
17	.9448					
18	.9116					
22			.5735	.663		
23			.6554	.6962		
24		.5571	.6062	.6554	.663	
Max	1.0159	.7373	.8048	.7045	.9614	.9503
Min	.852	.5571	.5735	.5898	.6133	.8583
Avg	.9462	.6193	.6652	.6586	.7670	.8945

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144047 / 33/11 KV AMRAI

Feeder No / Name : 704 / 33 KV Main VCB SHIRDHON  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	02-APR-18
HR	Load (MW)
15	4.4753
Max	4.4753
Min	4.4753
Avg	4.4753

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 201 / TAMBE MAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.2597	.6173	1.2955		1.2346	1.4403
2	1.3108	1.2452	.583	1.2308		1.2346	1.406
3	1.2803	1.2452	.5487	1.1984		1.2346	1.3717
4	1.2803	1.2452	.5144	1.166		1.2346	1.406
5		1.3108	.583	1.0688		1.2346	1.406
6	1.2498	1.3108	.6001	1.0688		1.3032	1.406
7	1.2498	1.3108		1.2955		1.3717	1.4232
8	1.2803	1.1797		1.4251		1.4403	1.5775
9	1.5242	1.1797	1.5089		1.6194	1.6461	
10	1.5242	1.1934	1.6804		1.6194	1.6118	1.3032
11	1.5242		1.6804		1.668	1.5775	1.3032
12	1.4022		1.5775		1.587	1.5432	1.406
13	1.2193	.9175	.9945		1.0364	1.3717	1.3717
14	1.3413	.9831	1.3032		1.3603	1.4403	1.5775
15	1.4632	.8619	1.4746		1.5546	1.5089	1.5775
16	1.6095	.7956	1.5432		1.587	1.6118	1.5775
17	1.4632	.7122	1.4403		1.5061	1.6118	1.5775
18	1.4632	.6299	1.6118		1.5546	1.5947	1.749
19	1.4632	.5304	1.5432		1.4899	1.5775	1.7147
20	1.4632	.5967	1.4746		1.4899	1.5432	1.7147
21	1.4022	.6226	1.4403		1.4899	1.5775	1.6118
22	1.4022	.663	1.3717		1.2955	1.5775	1.5775
23	1.3413	.663	1.3032		1.2308	1.6118	1.5089
24	1.4327	1.3435	.6516	1.2955		1.3032	1.5089
Max	1.6095	1.3435	1.6804	1.4251	1.668	1.6461	1.749
Min	1.2193	.5304	.5144	1.0688	1.0364	1.2346	1.3032
Avg	1.3940	.9909	1.1839	1.2272	1.4726	1.4582	1.5007

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 202 / UTTAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3672	1.2452	.9602	1.2403		1.2346	1.3717
2	1.3321	1.1797	.9602	1.2048		1.2346	1.3032
3	1.2971	1.1934	.9259	1.1694		1.2346	1.2689
4	1.262	1.1142	.8916	1.1694		1.2346	1.2003
5	1.262	1.1142	.9259	1.0985		1.2346	1.2346
6	1.2269	1.1271	.9602	1.134		1.2346	1.4403
7	1.3321	1.1934	1.0288	1.4175		1.3032	1.4403
8	1.3321	1.1271		1.4175		1.3717	1.3717
9	1.4723	1.1142	1.406		1.1871	1.5775	1.4403
10	1.4723	1.1271	1.4746		1.1871	1.5432	1.406
11	1.5424	1.0486	1.4746		1.3112	1.5089	1.4403
12	1.4022	1.0174	1.406		1.2757	1.4403	1.3032
13	1.4022	.9496	1.166		1.0631	1.3375	1.2689
14	1.4022	1.0513	1.3032		1.2048	1.3717	1.3032
15	1.6827		1.4403		1.2403	1.4403	1.3375
16	1.6827		1.4746		1.3112	1.4746	1.3375
17	1.6827		1.4403		.5138	1.5775	1.4746
18	1.6827	1.1934	1.4746		.5316	1.6461	1.5775
19	1.6827	1.326	1.5432		1.3466	1.6804	1.5432
20	1.6827	1.2452	1.4746		1.3466	1.7147	1.5432
21	1.5424	1.1797	1.4403		1.3466	1.6461	1.5432
22	1.5424	1.1142	1.3717		1.3466	1.5775	1.5261
23	1.4022	1.0486	1.3717		1.3466	1.5089	1.5432
24	1.4022	1.3108	1.0288	1.2403		1.3032	1.3717
Max	1.6827	1.326	1.5432	1.4175	1.3466	1.7147	1.5775
Min	1.2269	.9496	.8916	1.0985	.5138	1.2346	1.2003
Avg	1.4621	1.1438	1.2584	1.2324	1.1706	1.4346	1.3996

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 203 / 11 KV CHANDUR ROAD FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4371	2.3594	.9602	2.3434		2.5377	2.6749
2	2.4059	2.3594	.9259	2.3122		2.4691	2.5377
3	2.3434	2.3594	.9259	2.2809		2.4691	2.6063
4	2.3434	2.3594	.823	2.2497		2.4691	2.4006
5	2.2809	2.3594	.8573	1.9685		2.4691	2.4691
6	2.2809	2.3868	.8573	1.9372		2.4691	2.5377
7	2.4371	2.3868	.8916	2.4996		2.4691	2.6063
8	2.3434	1.704		2.4996		2.4691	2.7435
9	2.5934	1.7635	2.8464		2.6558	3.0178	3.0178
10	2.5934	1.7238	2.8807		2.6558	2.9492	2.9835
11	2.5934	1.5912	2.8807		2.6246	2.8121	3.0178
12	2.5309	1.4746	2.8464		2.5621	2.7435	1.9547
13	2.1872	1.326	1.3717		1.406	2.2291	1.9376
14	2.4996	1.4243	2.4348		2.4528	2.5034	2.6749
15	2.6246	1.1603	2.572		2.5621	2.8464	2.6749
16	2.6246	1.0277	2.6749		2.609	2.9835	2.6406
17	2.6246	.663	2.6406		2.5465	2.9492	2.7778
18	2.6246	.5967	2.7435		2.5777	2.8807	2.8464
19	2.6246	.5304	2.6406		2.4996	2.8121	2.8121
20	2.4996	.6104	2.5377		2.4996	2.7435	2.8464
21	2.4996	.7122	2.5034		2.4996	2.7435	2.8121
22	2.4996	.8951	2.572		2.3746	2.7778	2.572
23	2.3746	.9282	2.5034		2.3746	2.8121	2.7778
24	2.4996	2.4905	.9945	2.4996		2.6063	2.7435
Max	2.6246	2.4905	2.8807	2.4996	2.6558	3.0178	3.0178
Min	2.1872	.5304	.823	1.9372	1.406	2.2291	1.9376
Avg	2.4736	1.5497	1.9950	2.2879	2.4600	2.6763	2.6528

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 204 / WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1795	1.9662	.8573	2.0348		1.9204	2.1605
2	2.0454	1.9669	.8573	1.9669		1.9204	2.0919
3	2.0454	1.9669	.823	1.9669		1.9204	2.0576
4	2.0119	1.9006	.7888	1.9669		1.9204	2.0576
5	2.0119	1.8991	.823	1.8652		1.9204	2.0919
6	2.0119	1.8991	.823	1.8652		1.9204	2.1262
7	2.1125	1.8351	.8916	2.2382		1.989	2.1605
8	2.146	.9831		2.2382		1.989	2.1948
9	2.3472	.9945	2.2291		2.2382	2.2634	2.2634
10	2.3472	.9831	2.2291		2.2382	2.4006	2.2291
11	2.3472	.9614	2.2291		2.2382	2.332	2.2634
12	2.2131	.9282	2.2634		2.1365	2.2634	1.5432
13	2.1795	.8139	1.2689		1.3226	2.0576	1.4746
14	2.2801	.8288	1.9547		2.0856	2.1948	2.2291
15	2.3472	.7956	2.2291		2.2382	2.2634	2.2291
16	2.3472	.7625	2.2634		2.2891	2.332	2.2291
17	2.3472	.7293	2.2291		2.2043	2.2977	
18	2.2131	.6962	2.2291		2.2382	2.2634	2.2634
19	2.2131	.663	2.1605		2.1704	2.2291	2.2634
20	2.2131	.7293	2.1262		2.1704	2.1948	2.2291
21	2.146	.7625	2.0919		2.1704	2.2291	2.1605
22	2.146	.7956	2.1605		2.1704	2.2634	2.2291
23	2.0119	.8951	2.1262		2.1704	2.2977	2.1262
24	2.2131	1.989	.8916	2.1026		2.0576	2.2291
Max	2.3472	1.989	2.2634	2.2382	2.2891	2.4006	2.2634
Min	2.0119	.663	.7888	1.8652	1.3226	1.9204	1.4746
Avg	2.1865	1.1977	1.6759	2.0272	2.1387	2.1434	2.1262



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 205 / DKTE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3169	.9831	.8573	1.1576		.9602	.9602
2	1.2803	.9282	.823	1.1203		.8916	.9259
3	1.2803	.9175	.7888	1.0456		.8916	.9259
4	1.2071	.8619	.7202	1.0456		.8916	.8573
5	1.1706	.8619	.7545	.9335		.9602	.9602
6	1.1706	.9175	.823	.9335		.9602	1.0631
7	1.2071	.9831	.9259	.9709		1.0288	1.166
8	1.2071	.9945		1.0456		1.0974	1.0974
9	1.2437	.9945	1.2003		1.307	1.166	1.2689
10	1.2437	.9831	1.166		1.307	1.2346	1.2346
11	1.39	.9282	1.2003		1.3817	1.2003	1.2689
12	1.39	.8642	1.0974		1.4377	1.166	1.3717
13	1.0974	.8288	1.0288		1.2696	.9945	1.3032
14	1.1706	.8619	1.0288		1.1576	1.0974	1.3717
15	1.2437	.9282	1.0631		1.307	1.2346	1.3717
16	1.2437	.9602	1.0974		1.3817	1.3717	1.3717
17	1.2437	1.0852	1.0631		1.3443	1.3375	1.0288
18	1.4632	1.1271	1.0974		1.2696	1.3032	1.0974
19	1.4632	1.2266	1.1317		1.3443	1.3375	1.1317
20	1.4632	1.1271	1.0974		1.3443	1.3717	1.2346
21	1.39	1.0277	1.0974		1.3443	1.3375	1.3032
22	1.3169	.9282	1.1317		1.2696	1.2346	1.2689
23	1.2437	.8619	1.0974		1.1949	1.166	1.2346
24	1.3535	1.0486	.8573	1.1949		1.0288	1.0631
Max	1.4632	1.2266	1.2003	1.1949	1.4377	1.3717	1.3717
Min	1.0974	.8288	.7202	.9335	1.1576	.8916	.8573
Avg	1.2833	.9679	1.0064	1.0497	1.3107	1.1360	1.1617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 206 / GAON BHAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9214	.8619	.6173	.7621		.9602	1.0631
2	.9214	.8619	.583	.7468		.8916	1.0288
3	.8916	.8619	.5487	.7316		.8916	1.0288
4	.8322	.852	.5144	.7316		.8916	.9945
5	.8322	.8817	.583	.7316		.8916	1.0288
6	.8322	.9282	.6859	.7316		1.0288	1.0288
7	.9808	.9496	.6859	.9145		1.0974	1.0631
8	1.0105	.8619		.9755		1.0974	1.1317
9	1.1591	.852	1.2689		1.0669	1.166	1.3032
10	1.1888	.852	1.3032		1.0974	1.1317	1.2689
11	1.4937	.7956	1.3032			1.166	1.3032
12	1.0105	.7293	1.2346			1.1317	1.2689
13	.8322	.5243	.9602		.4725	1.0288	1.2346
14	.8916	.5967	.8916		.945	1.0631	1.0288
15	.9511	.6226	1.0631		.945	1.0974	1.2346
16	.9511	.6882	1.0631		.9907	1.166	1.2346
17	.9511	.7291	1.0288		.9907	1.2003	1.2346
18	1.1294	.7293	1.0288		.945	1.2346	1.166
19	1.1294	.7459	1.2689		1.0974	1.2346	1.1317
20	1.1294	.7625	1.2003		1.0974	1.2689	1.1317
21	1.0105	.7459	1.1317		1.0974	1.2346	1.3717
22	1.0105	.7459	1.0288		1.0364	1.2003	1.2346
23	.9511	.6226	1.0288		.9755	1.166	1.2689
24	1.0105	.9831	.6173	.8535		1.0288	1.0974
Max	1.4937	.9831	1.3032	.9755	1.0974	1.2689	1.3717
Min	.8322	.5243	.5144	.7316	.4725	.8916	.9945
Avg	1.0009	.7827	.9408	.7976	.9813	1.0945	1.1617

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 207 / 11 KV RAMNAGAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2579	3.12	2.1262			2.7435	2.8807
2	3.1855	2.8182	2.0576	3.2556		2.7435	2.8464
3	3.1855	2.8509	1.989	3.219		2.7435	2.8121
4	3.1493	2.8182	1.8519	3.1459		2.7435	2.6749
5	3.0769	2.7831	2.0576	3.1093		2.7435	2.7778
6	3.0769	2.8837	2.2634	3.1459		2.7435	2.8807
7	3.3665	2.9172	2.4348	3.2922		2.7435	2.8807
8	3.3665	3.2769		3.658		3.0864	2.8464
9	3.6561	3.315	3.5322		3.0769	3.4294	3.3608
10	3.6561	3.3913	3.4294		3.0769	3.4294	3.3265
11	3.6199	3.2114	3.5322		2.7873	3.3951	3.3608
12	3.3303	3.2556	3.5322		2.6425	3.3608	2.5034
13	3.2579	2.6852	2.572	3.2922	1.6289	2.7435	2.4348
14	3.6199	2.8509	3.0864		2.3348	3.2578	3.155
15	3.6199	2.6871	3.5322		2.3529	3.3608	3.0178
16	3.6199	2.5194	3.5837		2.3891	3.4294	3.0178
17	3.6199	2.2542	3.4979		2.3167	3.3608	3.3436
18	3.6199	1.9662	3.4979		2.0995	3.2922	3.4637
19	3.6199	1.8564	3.4294		2.1719	3.2236	3.0864
20	3.3303	1.9662	3.4294		3.0407	3.155	3.1893
21	3.6199	1.989	3.1893		3.0407	3.1893	3.2579
22	3.6199	2.2542	3.1893		2.8959	3.1893	3.0521
23	3.3303	2.2542	3.155		2.8959	3.155	3.0864
24	3.3303	3.12	2.2291	3.5482		2.7435	2.9492
Max	3.6561	3.3913	3.5837	3.658	3.0769	3.4294	3.4637
Min	3.0769	1.8564	1.8519	3.1093	1.6289	2.7435	2.4348
Avg	3.4223	2.7102	2.9217	3.2963	2.5834	3.0836	3.0086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 208 / 11 KV KRISHI GANGA  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.2743	.2683	.2347	.2743	
2		.2743	.3018	.2683	.2743	
3		.3086	.3353	.2683	.2743	
4		.3429	.3353	.2515	.2743	
5		.3772	.3353	.285	.2743	
6		.3944	.3353	.3018	.2743	
7		.4115	.3353	.3185	.3429	
8			.4024			
9		.4115			.4115	.4458
10					.4458	.4458
11	.5365				.4801	.4458
12	.5365				.5144	.4801
13	.5365				.4801	.5144
14	.5365				.4973	.5144
15	.5365				.4973	.5144
16	.5365				.4801	.4801
17	.5365					
18	.5365					
22				.2683		
23				.2683		
24		.2401	.2347	.2347	.2743	
Max	.5365	.4115	.4024	.3185	.5144	.5144
Min	.5365	.2401	.2347	.2347	.2743	.4458
Avg	.5365	.3372	.3204	.2699	.3794	.4801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 209 / JACKWELL

Feeder KV- 11 / OUTGOING

NON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1638	.0343	.1886		.1715	.1715
2	.1867	.1638		.1886		.1715	.1715
3	.1867	.1638	.0343	.1886		.1715	.1715
4	.1867	.1638	.0343	.1867		.1715	.1715
5	.1867	.1638	.0343	.1886		.1715	.1715
6	.1867	.1638	.1715	.1886		.1715	.1715
7	.1867	.1658	.1715	.1886			.1886
8	.1867	.1638		.1886		.1715	.1715
9	.1867	.1638	.1715	.1715	.1886	.1715	.1886
10	.1867		.1715	.1715	.1886	.1715	.1715
11	.1867	.1638	.1715	.1715	.1886	.1715	.1715
12	.1867	.1638	.1715	.1715	.1886	.1715	.1715
13	.1867	.1638	.1715	.1715	.1886	.1715	.1715
14	.1867	.1658	.1715	.1715	.1886	.1715	.1715
15	.1867	.1658	.1715	.1715	.1886	.1715	.1715
16	.1867	.1658	.1715	.1715	.1886	.1886	.1715
17	.1867	.1658	.1715		.1886	.1715	.1715
18	.1867	.1658	.1715		.1886	.1715	.1715
19	.1867	.1658	.1715		.1886	.1715	.1715
20	.1867	.1638	.1715		.1886	.1886	.1715
21	.1867	.1658	.1715		.1886	.1886	.1715
22	.1867	.1658	.1715		.1886	.1715	.1715
23	.1867	.16	.1715		.1886	.1715	.1715
24	.1677	.1658	.0343	.1867		.1715	.1715
Max	.1867	.1658	.1715	.1886	.1886	.1886	.1886
Min	.1677	.16	.0343	.1715	.1886	.1715	.1715
Avg	.1859	.1645	.1403	.1803	.1886	.1737	.1729

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 210 / AVENUE SUPER MARKET

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.056	.0492	.0514	.056		.0514	.0343
2	.0373	.0497	.0343	.0373		.0343	.0343
3	.0373	.0492	.0343	.0373		.0343	.0343
4	.0373	.0819	.0343	.0373		.0343	.0343
5	.0373	.0332	.0343	.0373		.0343	.0343
6	.0373	.0492	.0343	.0373		.0343	.0343
7	.0373	.0663	.0343	.0373		.0343	.0343
8	.0373	.0655		.0747		.0686	.0343
9	.0747	.1475	.1543		.0934	.0686	.0514
10	.0747	.0663	.2058		.112	.0857	.0514
11	.1494	.1492	.1715		.168	.1029	.0857
12	.1494	.1326	.1372		.1402	.1372	.1372
13	.1867	.0829	.1372		.112	.1029	.1372
14	.1867	.0995	.1372		.112	.12	.12
15	.1867	.116	.12		.112	.12	.1372
16	.1867	.1326	.12		.1052	.1372	.1372
17	.1867	.1311	.12		.1052	.1543	.12
18	.1867	.1475	.1372		.1494	.1543	.1372
19	.1867	.1311	.1715		.1494	.1715	.1372
20	.1867	.1017	.1715		.1494	.1715	.1715
21	.1867	.0838	.1715			.1372	.1715
22	.1867	.0678	.1372		.1341	.1029	.1029
23	.112	.0663	.0686		.1006	.0514	.0686
24	.0747	.0655	.0686	.056		.0343	.0514
Max	.1867	.1492	.2058	.0747	.168	.1715	.1715
Min	.0373	.0332	.0343	.0373	.0934	.0343	.0343
Avg	.1175	.0902	.1081	.0456	.1245	.0907	.0872

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 211 / NAIKMALA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3472	2.3205	1.1317	2.4143		2.4006	2.4691
2	2.2131	2.13	1.0974	2.3807		2.4006	2.4348
3	2.1795	1.9662	1.0631	2.2801		2.4006	2.4006
4	2.1795	1.989	.9602	2.2801		2.4006	2.4006
5	2.2131	1.989	.9945	2.1628		2.4006	2.4691
6	2.1795	1.989	1.0288	2.1795		2.4006	2.6063
7	2.4478	1.9006	1.0631	2.3472		2.3663	2.6749
8	2.4478	1.9006		2.5652		2.4006	2.7435
9	2.6825	1.8564	2.1605		1.9448	2.7092	2.8121
10	2.6825	1.8564	2.7778		1.9448	2.6063	2.7778
11	2.6825	1.8023	2.7778		1.9281	2.5034	2.7778
12	1.9113	1.7901	1.8861		1.8778	2.4691	1.6461
13	2.3472	1.6385	1.5432		1.0059	2.332	1.6118
14	2.6322	1.8023	2.1605		1.9281	2.4006	2.7435
15	2.6322	1.7695	2.6063		2.0957	2.5034	2.7435
16	2.6322	1.7238	2.6406		2.1293	2.7092	2.7435
17	2.6322	1.6575	2.6406		2.146	2.6749	2.6749
18	2.9127	1.6278	2.6063		2.0957	2.6406	2.6749
19	2.6155	1.5249	2.572		2.6139	2.6063	2.6406
20	2.5484	1.3923	2.5034		2.3472	2.572	2.6063
21	2.5484	1.3226	2.5034		2.3472	2.572	2.692
22	2.5484	1.2378	2.5377		2.3472	2.5377	2.6749
23	2.4813	1.1797	2.5034		2.3472	2.5377	2.6406
24	2.2801	2.4249	1.166	2.4478		2.4006	2.5034
Max	2.9127	2.4249	2.7778	2.5652	2.6139	2.7092	2.8121
Min	1.9113	1.1797	.9602	2.1628	1.0059	2.332	1.6118
Avg	2.4574	1.7830	1.9532	2.3397	2.0733	2.4977	2.5484

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 212 / MAHADEV NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3353	.3315	.1715	.3018		.3601	.3429
2	.3018	.3277	.1715	.2683		.3429	.3429
3	.3018	.3277	.1715	.2683		.3429	.3429
4	.3018	.3315	.1543	.2683		.3429	.3429
5	.3018	.3391	.1372	.2683		.3429	.3772
6	.3018	.3315	.1372	.2683		.3429	.4115
7	.3521	.3391	.1543	.4359		.3772	.4458
8	.3772	.3391		.4359		.4115	.4458
9	.4527	.3113	.3429		.4527	.4287	.4801
10	.4359	.3005	.4458		.4854	.4458	.463
11	.4359	.2881	.4458		.4862	.4287	.463
12	.3688	.2785	.3258		.0151	.4287	.3772
13	.4024	.2321	.2743		.3185	.3772	.3772
14	.4024	.2458	.3429		.3353	.4115	.4115
15	.4359	.2622	.3772		.4024	.4115	.3772
16	.4359	.2785	.3772		.4024	.4287	.3944
17	.4359	.2949	.3772		.3856	.4287	.4115
18	.4359	.2652	.3772		.3856	.4287	.4287
19	.4359	.2321	.4115		.4191	.4115	.4115
20	.3688	.1989	.3772		.4191	.4115	.4115
21	.3521	.1989	.3772		.4191	.3944	.4458
22	.3521	.1658	.3429		.4024	.3772	.4115
23	.3353	.1658	.3429		.3856	.3601	.4115
24	.3353	.3315	.1715	.3353		.3772	.3429
Max	.4527	.3391	.4458	.4359	.4862	.4458	.4801
Min	.3018	.1658	.1372	.2683	.0151	.3429	.3429
Avg	.3748	.2799	.2960	.3167	.3810	.3922	.4029



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI A S/DN.[710] BU 4710

Substation No/ Name :- 144048 / 33/11 KV Awade mala S/S

Feeder No / Name : 704 / 33 KV Main VCB TILAWANI SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 33 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	16.3009	13.9232	8.3333	15.2492		13.9918	14.3519
2	15.7751	13.4259	7.9733	14.7234		13.9918	13.9918
3	15.2492	13.2716	7.7161	12.4097		13.9918	13.6831
4	15.5647	12.7801	7.3045	11.5684		13.8889	13.3231
5	15.5647	13.2716	7.7675	13.514		13.8889	13.8375
6	15.5647	13.5665	8.3333	14.0924		13.8889	14.3004
7	16.3009	14.6502	9.6708	16.8267		14.5062	15.4321
8	16.7216	11.797		17.0371		14.5062	15.7408
9	18.1939	11.9936	16.9239	16.9753	15.5121	17.3354	16.2552
10	18.0887	12.412	16.6667	17.2325	15.5121	16.9239	16.821
11	15.6699	10.3927	16.9239	17.2325	14.3553	16.5124	16.821
12	15.6699	9.6342	16.7696	16.9753	13.5665	16.2552	14.1976
13	15.2492	9.3393	11.1626	15.4321	9.5702	14.249	12.963
14	17.3526	10.7905	14.4033	16.4609	13.3036	15.1235	16.9753
15	19.6045	8.8969	15.9465	16.4609	14.7234	16.358	16.9753
16		8.602	16.2037	16.5638	15.1441	17.6441	16.2552
17	18.4042	7.8647	16.2552		13.8295	16.5124	16.5638
18	18.4042	8.6511	16.358		.5818	16.4095	17.0268
19	18.4042	8.6511	16.6152		14.0924	16.3066	16.9753
20	17.3526	8.5037	16.2552		15.7751	16.6152	16.9239
21	17.1422	8.4054	15.9465		15.8951	16.0494	17.1297
22	17.1422	9.4616	15.9465		15.7751	15.9465	16.4609
23	16.8267	8.9461	15.535		14.7234	16.4095	16.5638
24	16.8267	14.7462	8.9506	15.7751		14.4033	14.9692
Max	19.6045	14.7462	16.9239	17.2325	15.8951	17.6441	17.1297
Min	15.2492	7.8647	7.3045	11.5684	.5818	13.8889	12.963
Avg	16.8423	10.9991	13.2157	15.5605	13.4906	15.4879	15.6057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 202 / IND EST FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6832	1.6804	1.4685	1.5947	1.6832	1.0631	1.5402
2	1.6301	1.6461	1.448	1.6118	1.6301	1.0174	1.4842
3	1.5947	1.6461	1.4083	1.5565	1.5061	.9602	1.448
4	1.5947	1.5775	1.39	1.5565	1.5061	.9602	1.3756
5	1.5947	1.5261	1.4449	1.5203	1.4175	1.0288	1.3756
6	1.5947	1.5089	1.4842	1.5364	1.3466	1.0802	1.3969
7	1.5947	1.6118		1.448	1.2403	1.1488	1.5074
8	1.5432	1.6118	1.4529	1.6289	1.0498	1.448	1.576
9	2.146	1.989	2.1672	2.1033	1.086	1.4842	2.1365
10	2.1125	2.0576	2.2382	2.2085	1.086	2.0622	2.1704
11	2.5701	2.1704	2.3739	2.1795	1.0974	2.2043	2.2634
12	2.4006	2.1091	1.9113	1.8861	.9175	2.0687	2.1091
13	1.8519	1.6297	1.6278		.4733	1.595	1.6804
14	2.0576	1.858	2.0576	1.9547	.6325	2.0805	2.0119
15	2.332	2.0683	2.0576	1.8442	.7449	2.2382	2.0622
16	2.332	2.0805	2.2291	2.0957		2.2721	2.2466
17	2.3579	2.0805	2.1605	1.9281	.6859	2.2043	2.2131
18	2.2977	1.6644	2.1262	2.0454	.7716	2.1776	2.0957
19	2.0233	1.5074	1.9547	1.8442	.6554	2.0576	
20	1.749	1.4266	1.5432	1.5947	.6859	1.6118	
21	1.7833	1.4632	1.5775	1.5947	.8916	1.6804	1.3375
22	1.749	1.5364	1.701	1.6832	1.1831	1.7551	1.6461
23	1.8519	1.5402	1.7528	1.6832	1.2003	1.7703	1.8004
24	1.6832	1.6804	1.4842	1.6476	1.6832	1.0631	1.5947
Max	2.5701	2.1704	2.3739	2.2085	1.6832	2.2721	2.2634
Min	1.5432	1.4266	1.39	1.448	.4733	.9602	1.3375
Avg	1.922	1.7363	1.7852	1.7716	1.0945	1.6263	1.7760

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 204 / YASHWANT FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1765	1.2323	1.2071	1.2323	1.1222	.7964	1.0974
2	1.1222	1.1949	1.2437	1.2449	1.086	.6859	1.0974
3	1.086	1.1317	1.2254	1.2071	1.086	.6859	1.0719
4	1.086	1.0829	1.1888	1.2071	1.0498	.6613	1.0349
5	1.0631	1.1088	1.1458	1.1694	.9955	.7537	1.0242
6	1.1163	1.1576	1.1706	1.1694	.9955	.823	1.0608
7	1.2308	1.226		1.2071	.9955	.8505	.9877
8	1.1765	1.2071	1.2308	1.2449	.8145	.905	.9412
9	1.2308	1.4335	1.3394	1.419	.8145	1.1584	1.1946
10	1.448	1.4632	1.3756	1.5089	.905	1.3032	1.3756
11	1.5089	1.448	1.4937	1.448	.7545	1.4118	1.4118
12	1.6263	1.448	1.4937	1.5023	.7682	1.3394	1.4842
13	1.3817	1.3756	1.307		.5117	1.267	1.3756
14	1.3957	1.1946	1.3443	1.4937	.4923	1.1946	1.5023
15	1.5278	1.3756	1.3443	.9922	.4995	1.3394	1.4352
16	1.5089	1.4266	1.4937	1.6078	.6348	1.3756	1.5384
17	1.3957	1.4118	1.4937	1.4175	.5093	1.3394	1.5565
18	1.3203	1.3756	1.3817	1.4299	.5441	1.2308	1.5203
19	1.5844	1.4118	1.4937	1.4842	.6062	1.3032	1.3937
20	1.358	1.2752	1.307	1.267	.6299	1.2071	1.3575
21	1.2323	1.2437	1.307	1.3575	.8505	1.0985	1.3213
22	1.2323	1.2071	1.3443	1.1765	.9431	1.134	1.267
23	1.2826	1.2894	1.307	1.1765	.7209	1.0974	1.2048
24	1.1765	1.2696	1.2071		1.1946		1.0974
Max	1.6263	1.4632	1.4937	1.6078	1.1946	1.4118	1.5565
Min	1.0631	1.0829	1.1458	.9922	.4923	.6613	.9412
Avg	1.3028	1.2913	1.3237	1.3165	.8135	1.0853	1.2647

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 205 / IGM FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.358	.6062	1.4091	1.2955	1.3923	1.3927
2	1.4251	1.3283	.5761	1.3108	1.247	1.2963	1.3108
3	1.3765	1.2809	.5441	1.2452	1.2146	1.2193	1.278
4	1.3765	1.2651	.5636	1.2125	1.2146	1.2346	1.2431
5	1.3765	1.1111	.5761	1.166	1.2146	1.2654	1.2452
6	1.3765	1.2452	.5898	1.2071	1.2631	1.3272	1.278
7	1.3765	1.2037		1.3413	1.3765	1.3272	1.3435
8	1.4232	1.1728	.7865	1.4575	1.4575	1.4198	1.4091
9	1.5181	1.3272	1.7238	1.7604	1.6821	1.6049	1.749
10	1.6604	1.2803	6.6522	1.749	1.5895	1.6766	1.8023
11	1.7814	1.1984	1.6358	1.7284	1.7284	1.7814	1.6204
12	1.7166	1.0159	1.4373	1.4232	1.5741	1.7368	1.3599
13	1.0185	.6554	.9998		1.0802	1.1797	1.1336
14	1.4198	1.3927	1.4373	1.3763	1.4506	1.6385	1.5384
15	1.6324	1.0486	1.4998	1.5935	1.2037	1.7695	1.6613
16	1.6975	1.0486	1.656	1.6204	1.7604	1.7368	1.7223
17	1.6324	.9503	1.5623	1.5895	1.6358	1.6712	1.6461
18	1.7604	.6226	1.6872	1.5813		1.9909	1.7528
19	1.6975	.6299	1.656	1.6604	1.8244	1.7695	1.7223
20	1.6004	.6226	1.5623	1.4232	1.4937	1.6385	1.4842
21	1.531	.6554	1.4998	1.5813	1.5123	1.704	1.5813
22	1.5402	.6882	1.4685	1.5384	1.531	1.5074	1.5497
23	1.5364	.6882	1.4998	1.4232	1.4815	1.6057	1.5023
24	1.4575	1.3889	.6226	1.4403	1.2955	1.3426	1.4419
Max	1.7814	1.3927	6.6522	1.7604	1.8244	1.9909	1.8023
Min	1.0185	.6226	.5441	1.166	1.0802	1.1797	1.1336
Avg	1.5162	1.0491	1.4280	1.4712	1.4403	1.5348	1.4903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 206 / 11 K.V BHAJI MARKET

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1163	1.134	.9231	1.086	1.0317	.9955	1.1523
2	1.0631	1.086	.8962	1.086	1.0317	.9877	1.1458
3	1.0099	1.0136	.8505	1.0242	.9593	.9511	1.0791
4	1.0099	.9774	.815	1.0242	.9593	.905	1.0608
5	.9745	1.0242	.8779	.9877	.9955	.8779	1.0974
6	1.0277	1.086	.905	.9877	1.0498	.9877	1.1041
7	1.0454	1.0242		.9979	1.0631	1.0974	1.0679
8	1.2226	.8962	.9774	1.1088	1.1163	1.0974	1.1765
9	1.2934	.8413	1.1871	1.3032	1.1694	1.134	1.3032
10	1.7718	.823	1.3253	1.267	1.1517	1.258	1.3213
11	1.4083	.905	1.3466	1.2403	1.262	1.3394	1.2226
12	1.3169	.7421	1.3112	1.134	1.1706	1.3032	1.3289
13	1.1888	.724	.9214		.9328	1.086	1.0808
14	1.2071	.724	1.134		1.0974	1.2308	1.1694
15	1.2803	.7602	1.1694	1.2048	1.0974	1.4118	1.1822
16	1.3717	.7964	1.2757	1.2048	.9694	1.4118	1.3466
17	1.3352	.6878	1.3466	1.1694	.9511	1.3575	1.2757
18	1.3169	.724	1.3466	1.1517	1.1888	1.2757	1.2934
19	1.3535	.7316	1.4529	1.2048	1.1888	1.39	1.3466
20	1.2803	.8962	1.2757	1.2403	1.1403	1.3535	1.1163
21	1.3169	.8962	1.2403	1.258	.9831	1.2308	1.2226
22	1.2437	.9145	1.1694	1.2403	1.0395	1.2226	1.1517
23	1.262	.9568	1.1462	1.258	1.0974	1.2308	1.1694
24	1.1871	1.1706	.9511	1.1222	1.0808	1.0059	1.1888
Max	1.7718	1.1706	1.4529	1.3032	1.262	1.4118	1.3466
Min	.9745	.6878	.815	.9877	.9328	.8779	1.0608
Avg	1.2335	.8973	1.1237	1.1501	1.0720	1.1726	1.1918

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 207 / 11 KV BALAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9389	.9012	.4424	.9054	.8718	.9831	.9503
2	.8718	.8684	.431	.8745	.8215	.9724	.9448
3	.8383	.852	.4359	.8421	.7545	.9175	.9116
4	.8288	.8192	.4527	.8097	.7545	.852	.8642
5	.8383	.8482	.503	.8097	.8048	.8718	.9175
6	.8886	.8745	.5138	.852	.8383	.8848	.9339
7	.9892	.8951		.9389	.9221	.8905	.9339
8	.9448	.7865	.6464	.9054	.9389	.8215	.9503
9	1.1012	.6944	1.0486	1.1142	1.1437	.9717	1.0978
10	1.1105	.7202	1.0814	1.1065	1.0364	.9393	1.0486
11	1.1736	.7373	1.0688	1.1174	1.0486	.9667	1.1336
12	1.0814	.5243	.8745	.8453	.9831	.8192	.9614
13	.7621	.4191	.7449	.8785	.7164	.7449	.7625
14	1.0227	.4144	.8745	.9779	.884	.7373	.9614
15	1.1043	.4475	.9069	1.0688	.8848	.9012	1.085
16	1.0883	.4588	1.0883	1.085	.9259	.8848	1.1498
17	1.0648	.3932	.9717	1.1336		.9503	1.1498
18	1.1203	.3481	1.1142	1.1336	1.0814	.9339	1.085
19	1.065	.3688	1.0364	1.085	1.0814	.8951	1.1271
20	.8855	.3856	.8745	.9389	.8488	.8356	.9779
21	.8951	.4359	.9175	1.0111		.8848	1.1105
22	.9667	.4475	.9503	.9116		.9339	1.0774
23	1.065	.4641	1.004	1.0277	1.0395	.9831	1.0111
24	.9724	.9282	.4475	.8745	.9221	.9995	.9614
Max	1.1736	.9282	1.1142	1.1336	1.1437	.9995	1.1498
Min	.7621	.3481	.431	.8097	.7164	.7373	.7625
Avg	.9841	.6264	.8013	.9686	.9192	.8990	1.0045

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 208 / 11 KV JIVESHWAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5775	1.6804	1.2757	1.2003	1.0974	1.0513	1.5947
2	1.4746	1.3413	1.1694	1.2269	1.0631	.9503	1.5604
3	1.406	1.3763	1.1222	1.1919	1.0277	.9389	1.4563
4	1.3717	1.2651	1.0317	1.1568	1.0277	.852	1.5424
5	1.3717	1.166	1.0029	1.1568	1.0985	.8718	1.6476
6	1.3717	1.1469	1.0387	1.2269	1.0985	.9175	1.6461
7	1.3717	1.0974		1.2269	1.2048	.9831	1.595
8	1.6461	1.2803	1.0517	1.3321	1.134	.9717	1.6827
9	1.8778	1.7772	1.4582	1.5775	1.134	1.7364	1.6804
10	1.6766	1.704	1.5769	1.5775	.9214	1.8107	1.9281
11	1.9559	1.8233	1.5424	1.5089	.8848	1.8991	1.9784
12	1.8652	1.6991	1.406	1.2689	.5792	1.7318	1.749
13	1.4548	1.4746	1.1603	1.3375	.5571	1.4746	1.382
14	1.704	1.4883	1.4403	1.406	.7773	1.7833	1.7833
15	1.8679	1.6476	1.4746	1.5089	.6802	1.8482	1.8107
16	1.9448	1.6827	1.4746	1.4419	.7099	1.8652	1.8778
17	1.5729	1.2209	1.5074	1.4403	.8718	1.5769	
18	1.8564	1.0498	1.406	1.5089	.8322	1.5424	1.6766
19	1.4419	.9412	1.3717	1.3717	.8025	1.6108	1.5775
20	1.2803	.9774	1.2689	1.2403	.9511	1.4582	1.3717
21	1.8671	1.086	1.3321	1.3466	.9717	1.4352	1.749
22	1.6766	1.448	1.4632	1.3466	1.0814	1.7147	1.7364
23	1.7436	1.4327	1.3321	1.3375	1.1142	1.6827	1.749
24	1.701	1.587	1.2757	1.2269	1.134	1.0395	1.6655
Max	1.9559	1.8233	1.5769	1.5775	1.2048	1.8991	1.9784
Min	1.2803	.9412	1.0029	1.1568	.5571	.852	1.3717
Avg	1.6282	1.3914	1.3123	1.3402	.9481	1.4061	1.6713

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144049 / 33/11 KV B S/S

Feeder No / Name : 209 / 11 KV NIGHT COLLAGE FEEDER  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	04-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 201 / 11 KV JANTA TEX.

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6591	3.7723	3.5082	3.6591	3.6591	3.5475	3.6969
2	3.6969	3.7723	3.4705	3.6591	3.5837	3.5475	3.7346
3	3.6214	3.7723	3.5082	3.5837	3.5837	3.5475	3.6591
4	3.6969	3.7346	3.4705	3.5082	3.4705	3.5475	3.6214
5	3.6591	3.7346	3.4894	3.5082	3.4705	3.5475	3.6591
6	3.6969	3.7723	3.4894	3.6214	3.546	3.6595	3.7346
7	3.6969	3.6969	3.546	3.6969	3.7346	3.5475	3.6969
8	3.7346	3.6969	3.5837	3.5837	3.3608	3.6969	3.6214
9	3.81	3.6969	3.6214	3.6591	3.1181	3.6595	3.7342
10	3.9232		3.5848	3.6214	2.8753	3.6969	3.8836
11	4.0741	3.7723	3.6595	3.8666	2.8753	3.9609	3.8666
12	3.7157	3.6595	3.6969	3.7534	2.8753	3.7723	3.7723
13	3.5837	3.6222	3.6591	3.5837	2.8006	3.6214	3.7723
14	3.4894	3.5848	3.6969	3.6969	2.8006	3.6591	3.7723
15		3.6222	3.6969	3.678	2.8006	3.7346	3.8666
16	3.5667	3.6222	3.6969	3.678	2.8006	3.7723	3.8666
17	3.7346	3.6214	3.6591	3.6214	2.726	3.7346	3.8666
18	3.5082	3.6591	3.6591	3.6214	2.726	3.6214	3.8666
19	3.6969	3.6403	3.6969	3.6214	2.726	3.6214	3.7723
20	3.6591	3.6214	3.5837	3.546	2.6337	3.5837	3.7723
21	3.6591	3.5837	3.6969	3.5837	3.1741	3.6591	3.7723
22	3.6969	3.546	3.6969	3.7346	3.3608	3.6591	3.7723
23	3.7723	3.5082	3.678	3.7346	3.3234	3.7346	3.7723
24	3.6969	3.7723	3.5271	3.6214	3.7157	3.3608	3.6969
Max	4.0741	3.7723	3.6969	3.8666	3.7346	3.9609	3.8836
Min	3.4894	3.5082	3.4705	3.5082	2.6337	3.3608	3.6214
Avg	3.6978	3.6732	3.6073	3.6434	3.1559	3.6455	3.7604

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 202 / 11 KV DECCAN PROCESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.2442	3.2819	3.2819	3.2114	3.3234	2.9874	3.2819
2	3.2065	3.2819	3.2442	3.1741	3.3234	2.9874	3.2819
3	3.2442	3.2442	3.2442	3.1741	3.2861	2.9874	3.3196
4	3.2442	3.2065	3.2819	3.0994	3.1741	2.9874	3.3196
5	3.2065	3.2065	3.2819	3.0807	3.1741	2.9874	3.2819
6	3.2442	3.2065	3.3008	3.2114	3.3048	3.062	3.3196
7	3.2819	3.2253	3.2442	3.3981	3.3794	3.1741	3.2442
8	3.3196	3.3196	3.3196	3.3794	2.8006	3.1741	3.2442
9	3.4705	3.3008	3.2442	3.4355	2.6139	3.1417	3.2895
10	3.4705	3.3573	3.2156			3.1786	3.4004
11	3.4541	3.3573	3.1786	3.5848		3.3951	3.3951
12	3.3421	3.1786	3.2442	3.4541		3.3196	3.3008
13	3.0434	3.2895	3.3196	3.2114	1.4937	3.2442	3.2065
14	3.2114	3.2526	3.3573	3.3608	1.4937	3.2819	3.2065
15	3.2301	3.2895	3.2442	3.4541	1.7551	3.3196	3.3951
16	3.4168	3.2526	3.3573	3.4355	1.7551	3.2819	3.4894
17	3.3234	3.3196	3.3573	3.3421	1.7551	3.3196	3.4894
18	3.3048	3.2442	3.3196	3.3981	1.7924	3.263	3.3951
19	3.3762	3.2065	3.3573	3.4355	1.7924	3.2442	3.3951
20	3.3573	3.1687	2.9874	3.3608	2.2405	3.3196	3.3951
21	3.3573	3.2065	3.2674	3.4168	2.8006	3.3573	3.3951
22	3.2819	3.2442	3.2674	3.4541	2.9874	3.3196	3.3951
23	3.3196	3.2442	3.2114	3.3608	2.9874	3.3196	3.2065
24	3.2442	3.2819	3.2065	3.1927	3.3421	2.9874	3.2819
Max	3.4705	3.3573	3.3573	3.5848	3.3794	3.3951	3.4894
Min	3.0434	3.1687	2.9874	3.0807	1.4937	2.9874	3.2065
Avg	3.2998	3.2569	3.2639	3.3316	2.5988	3.1933	3.3304

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 203 / 11 KV ICH METALLOY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1502	2.2445	1.8484	2.0538	1.9418	1.8671	2.0182
2	2.1125	2.1879	1.8861	2.0538	1.9418	1.8671	1.9805
3	2.1502	2.2257	1.8861	2.0165	1.8671	1.8671	2.037
4	2.1502	2.1879	1.8673	1.9418	1.7924	1.7924	1.9993
5	2.1313	2.1879	1.8861	1.9418	1.7924	1.7924	2.037
6	2.1125	2.0748	1.8861	1.9605	1.8298	1.8671	2.1125
7	2.1502	2.0748	1.8861	2.0911	1.9418	1.9418	2.0748
8	2.2634	2.1502	2.037	2.1098	1.7177	1.9418	1.9239
9	2.2634	2.1502	2.2634	2.2032	1.4937	2.0538	2.1658
10	2.3388	2.1879	2.3525	2.1845	1.3443	2.2405	2.2405
11	2.3152	2.1879	2.3899	2.2592	1.3256	2.3388	2.2634
12	2.2965	2.1658	2.4143	2.2965	1.1949	2.1879	2.2634
13	1.9978	2.1285	2.452	2.0911	1.1203	2.1125	2.0748
14	2.1313	2.0911	2.2445	2.2032	1.1203	2.1879	2.1691
15	2.2032	2.1285	2.1879	2.3152	.9709	2.1313	2.2634
16	2.2218	2.0911	2.2257	2.2965	.9709	2.1879	2.3577
17	2.2405	2.0748	2.1879	2.1472	.9709	2.1502	2.3577
18	2.2405	1.9805	2.1879	2.0911	.9709	2.1313	2.3577
19	2.2634	1.8861	2.2445	2.0538	.9709	2.1125	2.2634
20	2.2634	1.8861	2.0725	2.0165	1.1203	2.0748	2.2634
21	2.2257	1.8861	2.0911	2.0538	1.7551	2.0748	2.1691
22	2.2445	1.8861	2.1285	2.0538	1.8671	2.037	2.1691
23	2.2634	1.8861	2.1285	1.9791	1.7924	1.9805	2.1691
24	2.1502	2.2445	1.8673	2.0911	1.9791	1.8671	1.9993
Max	2.3388	2.2445	2.452	2.3152	1.9791	2.3388	2.3577
Min	1.9978	1.8861	1.8484	1.9418	.9709	1.7924	1.9239
Avg	2.2033	2.0915	2.1092	2.1044	1.4914	2.0336	2.1554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 204 / 11 SHAHPUR IND

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9993	2.1879	2.1125	2.1879	2.1691	1.8671	2.2257
2	1.9805	2.1879	2.0748	2.1879	2.1691	1.8298	2.2257
3	1.9805	2.2257	2.0748	2.1125	2.0748	1.8298	2.1879
4	1.9993	2.1879	2.1125	2.0748	2.0182	1.7924	2.2634
5	1.9805	2.1879	2.0748	2.0748	2.0182	1.7924	2.2257
6	1.9616	2.1879	2.0748	2.1125	2.0748	1.8298	2.2445
7	1.9805	2.2257	2.1125	2.1313	2.1125	2.0165	2.1125
8	2.1879	2.2257	2.1879	2.1125	1.8484	2.0538	2.1879
9	2.3011	2.2634	2.2634	2.3577	1.6221	2.2405	2.4646
10	2.3577	2.3011	2.3339	2.3765	1.4712	2.3525	2.4832
11	2.4897	2.3577	2.3899	2.5652	1.4335	2.5652	2.452
12	2.32	2.4646	2.4143	2.452	1.419	2.3388	2.452
13	2.0182	2.4272	2.3388	2.2257	1.3817	2.9801	2.2634
14	2.1691	2.4646	2.3765	2.32	1.3817	2.452	2.2634
15	2.3388	2.4646	2.3011	2.4143	1.3443	2.4897	2.452
16	2.3011	2.3152	2.3388	2.4143	1.3817	2.4897	2.452
17	2.2634	2.3011	2.32	2.3011	1.419	2.452	2.452
18	2.3011	2.2634	2.3388	2.2822	1.419	2.3577	2.452
19	2.2445	2.1879	2.3765	2.2822	1.419	2.3388	2.2634
20	2.2445	2.1125	2.1125	2.2257	1.419	2.3011	2.2634
21	2.2257	2.1125	2.1125	2.1125	1.7924	2.32	2.1691
22	2.1879	2.037	2.2068	2.1691	1.8671	2.3011	2.1691
23		2.0748	2.2257	2.2068	1.9044	2.2634	2.2634
24	2.0182	2.1879	2.0748	2.2068	2.1879	1.9044	2.1879
Max	2.4897	2.4646	2.4143	2.5652	2.1879	2.9801	2.4832
Min	1.9616	2.037	2.0748	2.0748	1.3443	1.7924	2.1125
Avg	2.1674	2.2480	2.2229	2.2461	1.7228	2.2149	2.2990

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 205 / 11 KV RADHA KANHAIYA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.9427	1.9616	1.4335	1.8298	1.8298	1.8298	1.9805
2	1.8484	1.9239	1.4712	1.8484	1.8298	1.7924	1.9993
3	1.8673	1.8861	1.4146	1.7737	1.7924	1.7551	1.9616
4	1.8673	1.8861	1.4335	1.7177	1.7177	1.7177	1.9239
5	1.8484	1.8484	1.4523	1.7177	1.7177	1.7177	1.9427
6	1.8484	1.8107	1.4335	1.7364	1.7737	1.7551	1.8861
7	1.8484	1.7353	1.4901	1.8298	1.7551	1.7551	1.8484
8	1.8107	1.7353	1.5089	1.8298	1.7177	1.8671	1.8107
9	2.2257	1.8107	2.1125	1.8671	1.6804	1.9959	1.9959
10	2.1125	.7922	2.0328	1.9231	1.6804	1.9589	2.0698
11	2.1658	1.3203	2.0698	2.0911	1.7924	1.9993	2.0748
12	2.0725	1.4784	2.1125	1.9231	1.6057	1.9616	1.8861
13	1.7177	1.4784	2.0748	1.7177	1.3203	1.9239	1.8861
14	1.8298	1.5154	2.0748	1.7924	1.307	1.9616	1.8861
15	2.0538	1.5154	1.9993	1.9978	1.5684	2.037	2.0748
16	2.2218	1.4784	1.9616	1.9791	1.5684	2.0182	2.0748
17	1.9791	1.5466	1.905	1.9231	1.6057	2.037	2.0748
18	2.1472	1.226	1.9616	1.8858	1.6057	2.037	2.0748
19	2.1879	1.2071	1.9239	1.8858	1.6057	1.9993	2.0748
20	2.1502	1.226	1.8671	1.8484	1.4937	2.037	1.9805
21	2.0748	1.4146	1.9791	1.9231	1.6804	2.0182	2.0748
22	2.037	1.4335	1.9605	1.9418	1.7924	2.0182	2.6406
23	2.0559	1.4712	1.8858	1.9231	1.8298	2.037	2.0748
24	1.9239	2.037	1.4523	1.8671	1.8858	1.8298	1.9993
Max	2.2257	2.037	2.1125	2.0911	1.8858	2.037	2.6406
Min	1.7177	.7922	1.4146	1.7177	1.307	1.7177	1.8107
Avg	1.9932	1.5724	1.7921	1.8655	1.6732	1.9192	2.0123

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 207 / 11 K.V AMIT

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5274	2.6406	2.5463	2.6029	2.4897	2.3152	2.6029
2	2.5274	2.6406	2.5652	2.6029	2.4897	2.2779	2.5652
3	2.5652	2.452	2.5274	2.5652	2.452	2.2779	2.6029
4	2.5274	2.452	2.5652	2.5086	2.3765	2.2405	2.5652
5	2.5274	2.5274	2.5463	2.4897	2.3765	2.2405	2.6029
6	2.5652	2.452	2.5652	2.5652	2.452	2.2779	2.584
7	2.5652	2.3954	2.5652	2.6029	2.5274	2.3899	2.5274
8	2.6406	2.5652	2.584	2.5652	2.2257	2.3152	2.4897
9	2.6783	2.6406	2.6029	2.6029	2.1691	2.4646	2.5766
10	2.6972	2.6783	2.726	2.6406	2.1125	2.5393	2.6513
11	2.7161	2.6783	2.7633	2.8104	2.037	2.7161	2.7349
12	2.7161	2.726	2.7915	2.7726	1.7177	2.584	2.7349
13	2.4897	2.5766	2.7161	2.452	1.5684	2.5652	2.452
14	2.3954	2.5393	2.6783	2.5652	1.5684	2.5274	2.452
15	2.7726	2.5766	2.6406	2.6029	1.5684	2.6029	2.5463
16	2.6783	2.5393	2.6406	2.6029	1.5684	2.5652	2.5652
17	2.6783	2.584	2.6029	2.6217	1.4937	2.5274	2.5463
18	2.6595	2.5652	2.6406	2.6217	1.4937	2.4897	2.5463
19	2.6029	2.4897	2.6406	2.6217	1.4937	2.452	2.452
20	2.5652	2.452	2.5652	2.5463	1.6804	2.5652	2.452
21	***	2.4897	2.6029	2.4331	1.8671	2.6029	2.452
22	2.5274	2.5086	2.6029	2.452	2.2779	2.6029	2.452
23	2.5652	2.5652	2.6029	2.4709	2.3152	2.6406	2.452
24	2.5652	2.6406	2.5274	2.584	2.5274	2.3152	2.6029
Max	11.8639	2.726	2.7915	2.8104	2.5274	2.7161	2.7349
Min	2.3954	2.3954	2.5274	2.4331	1.4937	2.2405	2.452
Avg	2.9840	2.5573	2.6171	2.5793	2.0354	2.4623	2.5504

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 208 / 11 K.V. TULJABHAVANI  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.7723	3.7723	3.7723	3.7723	3.3951	3.3608	3.5837
2	3.5837	3.7723	3.5837	3.7723	3.3951	3.3608	3.5837
3	3.7723	3.7723	3.7723	3.5837	3.3951	3.3608	3.5837
4	3.7723	3.7723	3.7723	3.3951	3.2065	3.1741	3.5837
5	3.5837	3.7723	3.5837	3.3951	3.2065	3.1741	3.5837
6	3.7723	3.7723	3.7723	3.5837	3.5837	3.3608	3.5837
7	3.5837	3.7723	3.7723	3.9609	3.5837	3.3608	3.5837
8	3.5837	3.7723	3.9609	3.7723	2.9874	3.3608	3.3951
9	3.7723	3.7723	3.9609	3.7723	2.4272	3.7342	3.6961
10	3.9609	3.9609	3.7342	3.7723	2.2405	3.7342	3.8809
11	4.3381	3.9609	4.1076	3.9609		3.9609	3.9609
12	3.9609	3.9209	4.1495	3.5837		3.7723	3.7723
13	3.3951	3.9209	4.1495	3.3951		3.7723	3.3951
14	3.7723	3.9209	4.0552	3.7723		3.7723	3.7723
15	3.9609	3.9209	3.8666	3.9609	1.4937	3.9609	3.9609
16	3.9209	3.7342	3.9609	3.9609	1.4937	3.9609	4.1495
17	3.9609	3.9609	3.9609	3.5837	1.6804	3.9609	4.1495
18	3.9609	3.9609	3.9609	3.7723	1.6804	3.7723	3.9609
19	3.7723	3.9609	3.9609	3.7723	1.8671	3.7723	3.9609
20	3.6969	3.7723	3.7723	3.5837	2.8006	3.5837	3.7723
21	3.7723	3.7723	3.7723	3.7723	3.3608	3.7723	3.7723
22	3.7723	3.7723	3.7723	3.7723	3.3608	3.7723	3.7723
23	3.7723	3.7723	3.5837	3.7723	3.3608	3.5837	3.7723
24	3.7723	3.7723	3.7723	5.2298	3.3951	3.3608	3.5837
Max	4.3381	3.9609	4.1495	5.2298	3.5837	3.9609	4.1495
Min	3.3951	3.7342	3.5837	3.3951	1.4937	3.1741	3.3951
Avg	3.7911	3.8348	3.8554	3.7780	2.7957	3.6150	3.7422

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 209 / 11 K.V YOGASHRAM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.4327	.5658	1.307	1.307	1.4937	1.5089
2	1.3203	1.4632	.5658	1.307	1.307	1.4937	1.3203
3	1.3203	1.6461	.5658	1.1203	1.1203	1.307	1.3203
4	1.3203	1.6461	.5658	.9335	.9335	1.307	1.3203
5	1.3203	1.4632	.5658	.9335	.9335	1.1203	1.3203
6	1.3203	1.2803	.5658	1.1203	1.1203	1.1203	1.3203
7	1.3203	1.0974	.5658	1.1203	1.1203	1.307	1.3203
8	.9431	1.1317	.7545	1.1317	1.307	1.307	1.3203
9	1.6975	1.1317	1.5089	1.307	1.4937	1.6804	1.4937
10	1.6975	1.0974	1.6804	1.4937	1.4937	1.6804	1.6804
11	1.6804	1.6461	1.6804	1.6804	1.6804	1.6975	1.6975
12	1.4937	.9335	1.6975	1.4937	1.4937	1.3203	1.5089
13	.9335	.9335	1.6975	1.1203	.7468	1.3203	1.5089
14	1.1203	1.0829	1.6461	1.307	.7468	1.3203	1.6975
15	1.6804	.9335	1.5546	1.6804	1.4937		1.6975
16	1.6804	.9335	1.6461	1.6804	1.4937	1.6975	1.6975
17	1.6804	.9431	1.5089	1.4937	1.4937	1.6975	1.6975
18	1.6804	.5658	1.6975	1.4937	1.4937	1.6975	
19	1.4327	.5658	1.6032	1.4937	1.4937	1.6975	1.6975
20	1.4632	.5658	1.307	1.307	1.307	1.6975	1.6975
21	1.5089	.5658	1.307	1.4937	1.4937	1.6975	1.6975
22	1.4632	.5658	1.307	1.4937	1.4937	1.6975	1.6975
23	1.5089	.5658	1.307	1.4937	1.4937	1.5089	1.5089
24	1.5089	1.4632	.5658	1.307	1.4937	1.4937	1.5089
Max	1.6975	1.6461	1.6975	1.6804	1.6804	1.6975	1.6975
Min	.9335	.5658	.5658	.9335	.7468	1.1203	1.3203
Avg	1.4340	1.0689	1.1846	1.3464	1.3148	1.4939	1.5321



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 210 / 11 KV New Supereme Feeder SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4143	2.2634	1.9427	2.5149	2.0576	1.307	1.9805
2	2.3011	2.2257	1.9616	2.572	2.0005	1.2323	1.9993
3	2.2257	2.1879	1.9239	2.0005	1.9433	1.2323	2.0182
4	2.2822	2.1125	1.8861	2.6292	1.8099	1.2323	1.9993
5	2.2634	2.0748	1.9239	2.572	1.7528	1.307	1.9805
6	2.037	2.037	1.4523	2.0195	2.0005	1.3817	1.6975
7	2.4897	1.9993	2.4143	2.6482	2.0005	1.419	1.8861
8	2.6217	2.6029	2.452	1.8861	1.6766	2.0538	1.9616
9	2.584	2.5652	2.5019	1.7528	1.3717	1.4937	2.0698
10	2.0936	2.6029	2.3712	1.4861	1.2003	1.419	2.1253
11	2.6863	2.8104	2.0911	2.6292	1.1431	1.9993	2.0748
12	2.4768	2.4949	2.1879	2.572	1.0456	1.3769	2.0748
13	2.4768	2.4394	2.2257	1.4861	.9335	1.4712	1.905
14	1.9433	2.4764	2.3011	1.7718	.9335	1.4335	2.0748
15		2.4209	2.32	2.6673	.9709	1.4146	2.0748
16	2.572	1.922	2.5086	2.553	.9709	1.4712	2.1691
17	1.848	2.2257	2.5086	1.8861	.9709	1.4335	2.1691
18	2.0005	2.3954	2.5086	1.7337	1.0082	1.3392	2.1691
19	1.8484	1.9427	2.5274	1.4289	1.0829	1.4335	2.452
20	1.8861	1.9805	2.4958	1.4289	1.2323	1.4712	2.452
21	1.6221	1.9993	2.6292	1.4289	1.307	1.5089	2.6406
22	2.1879	1.9993	2.0195	1.829	1.3443	1.4712	2.6406
23	2.32	1.9427	2.5911	2.1529	1.3443	2.0182	2.2634
24	2.32	2.2634	1.9805	2.5911	2.0576	1.307	1.9239
Max	2.6863	2.8104	2.6292	2.6673	2.0576	2.0538	2.6406
Min	1.6221	1.922	1.4523	1.4289	.9335	1.2323	1.6975
Avg	2.2392	2.2494	2.2385	2.0933	1.4233	1.4678	2.1168

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 211 / 11 KV Mhashoba Mandir

SHEDDABLE URBAN

Feeder Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8296	1.704	1.1506	1.5927	1.6108	1.7551	1.7353
2	1.7918	1.6385	1.1694	1.576	1.5927	1.6804	1.773
3	1.8107	1.6004	1.1317	1.6975	1.5424	1.6804	1.7353
4	1.7918	1.6221	1.1694	1.4251	1.4419	1.6057	1.7541
5	1.7918	1.8484	1.1694	1.4251	1.4419	1.6057	1.7353
6	1.773	1.6057	1.1317	1.4754	1.4754	1.6804	1.7164
7	1.7918	1.8484	1.1694	1.5592	1.576	1.7551	1.7541
8	1.8673	1.8484	1.2826	1.6095	1.7924	1.8671	1.8861
9	2.1313	1.6221	1.905	1.7604	1.829	2.0485	2.0748
10	2.2068	1.3443		1.8275	1.8839	2.1216	2.0748
11	2.0119	1.3763	2.0119	1.9448	1.9753	2.1125	2.0748
12	1.7939	1.134	1.8023	1.6933	1.8671	1.9427	1.8861
13	1.358	1.0974	1.8023	1.5089	1.39	1.9239	1.7918
14	1.6598	1.134	1.7859	1.643	1.4937	1.9427	1.8861
15		1.1157	1.7695	1.8107	1.8671	2.037	2.0748
16	2.2497	1.134	1.7859	1.8442	1.8656	2.0182	2.0748
17	1.9784	1.1317	1.7284	1.7939	1.9387	2.037	2.0748
18	1.9616	.6979	1.7284	1.7269	1.8671	2.037	2.0748
19	1.7695	.6602	2.0559	1.6598	1.7924	1.9993	1.9805
20	1.7532	.7356	1.6263	1.6263	1.5684	2.0748	1.8861
21	1.6712	1.1317	1.6933	1.6933	1.6827	1.9993	1.8861
22	1.704	1.1506	1.6766	1.7269	1.7924	1.9239	1.8861
23	1.7695	1.1694	1.643	1.6766	1.7558	1.8296	1.8861
24	1.9239	1.7368	1.1317	1.643	1.643	1.7924	1.7918
Max	2.2497	1.8484	2.0559	1.9448	1.9753	2.1216	2.0748
Min	1.358	.6602	1.1317	1.4251	1.39	1.6057	1.7164
Avg	1.8431	1.3370	1.5444	1.6642	1.6952	1.8946	1.8956

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144050 / 33/11 KV SHAHPUR S/S

Feeder No / Name : 402 / 33 KV JAY GANGATARA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	6.4506	6.5072	6.2734	6.6204	6.677	6.3855	6.3855
2	6.4975	6.5638	6.2734	6.5638	6.677	6.3855	6.4975
3	6.4975	6.5638	6.3855	6.5638	6.5638	6.3855	6.4975
4	6.3855	6.5638	6.3855	6.4506	6.4506	6.3855	6.3855
5	6.4975	6.5072	6.2734	6.4506	6.4506	6.3855	6.4975
6	6.4415	6.5638	6.4975	6.5638	6.5638	6.3855	6.3855
7	6.3855	6.5638	6.3855	6.677	6.5072	6.3855	6.3855
8		6.5638	6.3855	6.394		6.2734	6.2734
9	5.8814	6.5638	6.4415	6.5072		6.2734	6.4975
10	5.8253	6.5638	6.4975	6.5072		6.2734	6.6655
11	6.1614	6.5638	6.7215	6.5638		6.7901	6.5072
12	6.2243	6.677	6.7901	6.5072	5.6013	6.3375	6.4506
13	5.9414	6.5638	6.677	6.5638	5.6013	6.4506	6.3375
14	6.0545	6.5638	6.677	6.6204	5.6013	6.5638	6.5638
15	6.2809	6.5072	6.5638	7.0165	5.6013	6.677	6.677
16	6.2243	6.4506	6.5638	6.677	5.4893	6.5638	6.677
17	6.5638	6.5638	6.5638	6.677	5.4893	6.677	6.5638
18	6.5072	6.4506	6.4506	6.5072	5.6013	6.5638	6.4506
19	6.2809	6.5638	6.4506	6.7335	5.6013	6.3375	6.4506
20	6.4506	6.2243	6.677	6.7901	5.7133	6.3375	6.3375
21	6.4506	6.4506	6.5072	6.6204	5.9374	6.3375	6.2243
22	6.5072	6.4506	6.6204	6.8467	6.1614	6.4506	6.3375
23	6.5638		6.3375	6.8467	6.2734	6.5638	6.4506
24	6.5638	6.5072	6.3855	10.9928	6.7335	6.3855	6.4975
Max	6.5638	6.677	6.7901	10.9928	6.7335	6.7901	6.677
Min	5.8253	6.2243	6.2734	6.394	5.4893	6.2734	6.2243
Avg	6.3320	6.5244	6.4910	6.8026	6.0648	6.4398	6.4582

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 201 / 11 KV KABNOOR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6289	1.7194	1.2003	1.4575	1.5546	1.6289	1.6289
2	1.6289	1.6461	1.2003	1.4575	1.5546	1.5546	1.6289
3	1.6289	1.6461	1.2003	1.4575	1.5708	1.5546	1.6289
4	1.6289	1.6461	1.2003	1.4575	1.5708	1.5546	1.6289
5	1.8099	1.6461	1.2346	1.4575	1.587	1.5546	1.6289
6	1.9004	1.6461	1.2346	1.4575	1.5708	1.5546	1.6289
7	1.9004	1.6289	1.2346	1.4575	1.6461	1.6461	1.6289
8	1.6476	1.5947	1.3717	1.5432	1.7718	1.6118	1.7147
9	1.8652	1.5947	1.8519	1.8861	2.0458	1.8378	1.8861
10	1.95	1.5432	1.9204	1.9719	1.8652		1.8861
11	1.9719	1.3717	1.9719	2.0805	2.1704	1.8861	1.949
12	1.8204		1.8861	1.949	1.8861	1.8004	1.949
13	1.5061		1.0288	1.5384	1.6461	1.3717	1.6289
14	1.7528	1.0288	1.3717	1.6651	1.701	1.8861	1.8625
15	1.9719	1.0631	1.9719	1.8604	1.7364	1.8861	1.8781
16	1.8861	1.0631	1.9719	2.0576	1.8073	1.8861	1.8781
17	1.8861	1.0631	1.9719	1.9071		1.8004	3.8752
18	1.8861	1.0631	1.9719	1.9071			2.0576
19	1.8404	1.286	1.9719	1.9281		1.8004	2.0576
20	1.97	1.286	1.9719	2.0157	1.267	1.8004	2.1357
21	1.949	1.4403	1.8861	2.0595	1.8461	1.8004	2.2325
22	1.97	1.4403	1.7147	2.0595	1.8461	1.9719	2.1491
23	1.9004	1.5089	1.7147	1.9004	1.8461	1.9719	2.0058
24	1.9909	1.8099	1.2003	1.7147	1.7194	1.7737	1.9719
Max	1.9909	1.8099	1.9719	2.0805	2.1704	1.9719	3.8752
Min	1.5061	1.0288	1.0288	1.4575	1.267	1.3717	1.6289
Avg	1.8288	1.4425	1.5939	1.7603	1.7243	1.7333	1.9383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 202 / CHANDUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.5056	3.2579	2.0576	3.1722	3.5542	3.5665	3.4294
2	3.5056	3.2074	2.0576	3.1722	3.5056	3.5542	3.4294
3	3.5056	3.2427	2.0576	3.1722	3.5056	3.5056	3.4294
4	3.5056	3.2779	2.0576	3.1722	3.5056	3.5056	3.4294
5	3.5056	3.2779	2.2291	3.1722	3.5056	3.5056	3.4294
6	3.6808	3.2779	2.4006	3.1722	3.5056	3.5056	3.6866
7	3.6808	3.2779	2.572	3.1722	3.5056	3.6458	3.6866
8	3.5021	2.8959	2.572		3.4179	3.6062	3.9438
9	4.2391	2.392	4.1838	4.0295	4.0695	4.225	4.201
10	4.0238	2.4006	4.2867	4.1076	4.0238	4.2867	4.2867
11	3.94	2.0576	4.2867	4.4429	4.292	***	4.3343
12	2.652	2.0576	4.1152	3.5056	3.3532	4.201	3.7795
13		1.5432	2.915	2.8349	2.7511	2.915	2.7221
14	3.4294	1.5432	3.4294	3.6008	3.4873	3.4294	3.7795
15	4.0695	1.7147	4.0295	3.9847	4.1244	4.2867	4.2052
16	4.1914		3.9438	4.0695	4.1244	4.2867	4.2052
17	4.0695		3.858	3.8999	4.0444	4.2867	4.1244
18	3.8999		3.858	3.7304	3.9449	4.1152	3.9232
19	3.6456	1.4403	3.858	3.7304	4.0356	4.1152	3.9438
20	3.7304	1.4403		3.7304	3.7304	3.4294	3.5715
21	3.7304	2.0576		3.7723	3.8321	3.4294	3.9678
22	3.6456	2.0576	3.6008	3.7275	3.8999	3.6008	3.7723
23	3.6456	2.0576	7.2016	3.858	3.8999	3.6008	3.738
24	3.6008	3.4294	2.0576	5.0583	3.6866	3.7304	3.6008
Max	4.2391	3.4294	7.2016	5.0583	4.292	10.631	4.3343
Min	2.652	1.4403	2.0576	2.8349	2.7511	2.915	2.7221
Avg	3.6915	2.4718	3.3467	3.6647	3.7211	4.0402	3.7758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 203 / 11 KV COLLAGE FEEDER  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 205 / DATTA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.326	1.2955	.7202	1.286	1.2955	1.4251	1.3413
2	1.326	1.2955	.7202	1.286	1.2193	1.3413	1.3717
3	1.326	1.2955	.7202	1.286		1.3413	1.3717
4	1.326	1.2955	.7202	1.286	1.2193	1.3413	1.3717
5	1.326	1.2955	.7202	1.286	1.2193	1.3413	1.3717
6	1.3923	1.2955	.7202	1.286	1.2193	1.3413	1.3717
7	1.4918	1.2193	.823	1.286	1.3717	1.4754	1.3717
8	1.5061	1.0669	.8383	1.1145	1.3717	1.4864	1.5432
9	1.6766	.9145	1.7814	1.8861	1.7528	1.7901	1.7814
10	1.6766	1.1145		1.6004	1.7394	1.9547	1.7394
11	1.6766	1.0631		1.7985		1.9719	1.7394
12	1.1431	1.0631		1.5242		1.9719	1.7078
13		.823		1.0669		1.2003	1.286
14	1.448	.823		1.2193		1.5432	1.5813
15	1.6766	.9602			1.8435	1.9719	1.866
16	1.7528		1.8861	1.7528	1.8747	1.9719	1.866
17	1.7528		1.8004	1.6766	1.829	1.9719	1.7985
18	1.6766		1.8004	1.6766	1.7375	1.9719	1.768
19	1.6766	.9602	1.8861	1.6766	1.7375	1.8861	1.8027
20	1.6766	.9602	1.8861	1.5242	1.6766	1.8004	1.6712
21	1.6004	.9259	1.7147	1.5242	1.7394	1.7147	1.6004
22	1.6004	.8745	1.7147	1.3717	1.6004	1.6289	1.6194
23	1.5242	1.0288	1.7147	1.3717	1.5364	1.6289	1.6194
24	1.4918	1.3717	1.0288	1.7147	1.3717	1.4575	1.5927
Max	1.7528	1.3717	1.8861	1.8861	1.8747	1.9719	1.866
Min	1.1431	.823	.7202	1.0669	1.2193	1.2003	1.286
Avg	1.5248	1.0925	1.2887	1.4566	1.545	1.6471	1.5898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 207 / CHANDUR KARNUR AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.381	.3239	.0171	.0171	.0152	.0171
2	.3163	.381	.3887	.0171	.0171	.0152	.0171
3	.3163	.381	.4115	.0171	.0171	.0152	.0171
4	.3953	.381	.3887	.0171	.0171	.0152	.0171
5	.3953	.4572	.4534	.0171	.0171	.0152	.0171
6	.4744	.5335	.4534	.0171	.0171	.0152	.0171
7	.5851	.6097	.583	.0171	.0171	.0152	.0171
8	.6958	.6859	.6478	.0171	.0171	.0152	.0171
9	.6859	.6859	.7125	.6859	.7316	.6958	.7716
10	.0171	.0162	.0171	.7316	.8223	.7545	.7716
11	.0171	.0162	.0171	.7926	.8223	.7716	.6958
12	.0171	.0171	.0171	.7926	.7907	.6859	.68
13		.0171	.0171	.6859	.7116	.7716	.68
14	.0171	.0171	.0171	.6859	.7116	.7716	.6958
15	.0171	.0171	.0171	.6859	.7116	.7716	.6958
16	.0171	.0171	.0171	.6859	.7116	.7716	.68
17	.0171	.0171	.0171	.0171	.0152	.0171	.0152
18	.0171	.0171	.0171	.0171	.0152		.0152
19	.0171	.0171	.0171	.0171	.0152	.0171	.0152
20	.0171	.0171	.0171	.0171	.0152	.0171	.0152
21	.0171	.0162	.0171	.0171	.0152	.0171	.0152
22	.0171	.0162	.0171	.0171	.0152	.0171	.4744
23	.0171	.0162	.0171	.0171	.0152	.0171	.4902
24	.2846	.3048	.3239	.0171	.0171	.0152	.0171
Max	.6958	.6859	.7125	.7926	.8223	.7716	.7716
Min	.0171	.0162	.0171	.0171	.0152	.0152	.0152
Avg	.2024	.2098	.2053	.2508	.2614	.2710	.2860



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144051 / 33/11 KV KABNOOR

Feeder No / Name : 208 / 11 KV Dhuleshwar Nagar  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.6001	.4115	.5144	.6001	.7545	.6602
2	.7545	.6001	.4115	.5144	.6001	.6413	.6602
3	.7167	.6001	.4115	.5144	.5144	.6413	.6602
4	.7167	.6001	.4115	.5144	.5144	.6036	.6602
5	.7167	.6001	.4115	.5144	.6001	.6036	.6602
6	.7167	.6001	.4115	.5144	.6001	.6413	.6602
7	.7167	.6001	.4458	.5144	.6001	.6413	.6602
8	.7545	.5144	.4801	.6001	.6001	.7167	.6602
9	.7716	.5144	.7545	.6859	.6859	.811	.7545
10	.7716	.5144		.6859	.8488	.7545	.7545
11	.6859	.4115		.7716	.8299	.7716	.7922
12	.0171	.4115		.6859	.7545	.6859	.7922
13		.3429		.5144	.6413	.5144	.6413
14	.6859	.3429		.6001	.7922	.6859	.7922
15	.7716	.5144		.6859	.8299	.6859	.8676
16	.7716	.5144	.7716	.7716	.8299	.6859	.8676
17	.7716	.5144	.6859	.6859	.8299	.6859	.8676
18	.7716	.5144	.7716	.6859	.8676	.7716	.8299
19	.7716	.3429	.7716	.6859	.8299	.7716	.8299
20	.7716	.3429	.7716	.6859	.7922	.6859	.8299
21	.7716	.4115	.6859	.6859	.7922	.7545	.8299
22	.7716	.4115	.6859	.6859	.8299	.7545	.8299
23	.7716	.4115	.6859	.6859	.8299	.7545	.7922
24	.7922	.6859	.4115	.6859	.6859	.7922	.7545
Max	.7922	.6859	.7716	.7716	.8676	.811	.8676
Min	.0171	.3429	.4115	.5144	.5144	.5144	.6413
Avg	.7181	.4965	.5773	.6287	.7208	.7004	.7545

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 201 / 11 KV HANUMANNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6004	1.7147	.6401	1.4243	1.8107	1.5432	1.6804
2	1.6004	1.7147	.6401	1.3565	1.7353	1.5432	1.6289
3	1.5546	1.4575	.6249	1.3395	1.6598	1.5432	1.5947
4	1.4937	1.4575	.6097	1.3395	1.6598	1.5432	1.7353
5	1.5089	1.4575	.6097	1.3565	1.6032	1.5432	1.7164
6	1.5546	1.4918	.6554	1.3904	1.8107	1.6289	1.7147
7	1.5699	1.5432	.6706	1.4752	1.7318	1.7147	1.7661
8	1.6918	1.5432	1.0822	1.7295	1.8861	1.7985	1.9719
9	2.0271	1.5432	1.9204	2.1874	2.2119	2.0576	2.2977
10	2.0576	1.4918	1.9814	2.2213	2.1776	1.9509	2.2291
11	2.2805	1.2955	2.2213	2.2805	2.1776	2.3148	2.1874
12	2.1948	.9602	1.8821	2.0233	1.8861	2.0919	2.0687
13	1.4918	.5944	1.4413	1.6787	1.5775	1.5947	1.5939
14	1.8347	.7773	2.0008	1.8519	1.9719	1.9376	1.9839
15	2.2291	.8383	2.0517	2.1091	2.1434	2.2634	2.2043
16	2.2634	.8535	2.1365	2.1434	2.2119	2.332	2.2891
17	2.2634	.7773	1.95	2.1091	2.2119	2.1434	2.2552
18	2.2119	.503	2.0687	2.0233	2.1434	2.2119	2.2891
19	2.1091	.4268	1.9669	2.1091	2.0405	2.0748	2.1534
20	2.1091	.4572	1.7974	1.8861	1.9719	2.0233	2.0178
21	2.0576	.6097	1.8313	1.9204	1.9204	2.0062	1.9839
22	1.9547	.6401	1.7974	1.8347	1.869	1.7833	1.9669
23	1.8861	.6401	1.6956	1.8004	1.7147	1.8519	1.933
24	1.6918	1.8861	.6401	1.5261	1.7147	1.7147	1.749
Max	2.2805	1.8861	2.2213	2.2805	2.2119	2.332	2.2977
Min	1.4918	.4268	.6097	1.3395	1.5775	1.5432	1.5939
Avg	1.8849	1.1114	1.4548	1.7965	1.9101	1.8838	1.9588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 203 / 11 KV SWAMI APPARTMENT

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7956	.6859	.4144	.6104	.7922	.6859	.8299
2	.7956	.6859	.4144	.5765	.7545	.6859	.7922
3	.779	.6859	.4144	.5765	.7167	.6859	.7545
4	.7459	.6859	.3978	.5765	.7167	.6859	.7167
5	.7459	.6859	.3978	.6104	.6979	.7716	.7167
6	.7459	.7202	.431	.6613	.7545	.7716	.8865
7	.8122	.7716	.4807	.6443	.8488	.823	.8865
8	.8453	.7716	.5967	.78	.9431	.9088	.9997
9	1.0442	.823	.9282	1.0174	1.1128	1.0288	1.1883
10	1.0277	.7545	1.0111	.9835	1.1317	.9145	1.1694
11	1.1145	.7293	1.0004	1.094	1.0288	1.1317	1.0343
12	1.0288	.7127	.9496	1.0562	.823	1.0562	1.0174
13	.6859	.4144	.6613	.7167	.6687	.8676	.8309
14	.9602	.547	.8309	.9054	.7716	.9054	.8817
15	1.0288	.5967	.9156	1.0562	1.0288	1.094	.9665
16	1.046	.6299	.9835	1.0751	1.0288	1.1317	1.0343
17	1.046	.5967	.9835	1.0374	1.0288	1.094	.9665
18	1.0288	.431	.9326	1.0751	1.0288	1.0562	1.0004
19	.9259	.4641	.9326	1.1317	1.0288	1.1128	1.0174
20	.9259	.4973	.9326	.9997	1.0288	1.0562	1.0174
21	.9602	.4973	.8817	1.0562	1.0288	1.094	1.0004
22	.9602	.4973	.8478	1.0185	.9602	.9997	.9665
23	.9259	.4641	.8309	.9431	.9431	.9808	.9326
24	.8453	.9259	.4475	.7209	.8299	.8573	.8676
Max	1.1145	.9259	1.0111	1.1317	1.1317	1.1317	1.1883
Min	.6859	.4144	.3978	.5765	.6687	.6859	.7167
Avg	.9092	.6364	.7340	.8718	.9040	.9333	.9364

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144111 / 33/11 KV Hanumannagar

Feeder No / Name : 204 / 11 KV NEW COLLAGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0174	1.0974	.5658	.9326	1.0374	1.0288	1.1317
2	1.0174	1.0974	.5658	.8817	.9431	1.0288	1.0562
3	.9835	.9774	.5487	.7969	.8299	.9431	1.0185
4	.9156	.9774	.5144	.7969	.8299	.9431	.9808
5	.9156	.9774	.5144	.8309	.7356	.9431	.9808
6	.9496	1.0288	.5144	.8648	.9808	.9431	1.1506
7	1.0852	1.046	.6001	.9156	1.0185	1.0288	1.1883
8	1.1022	1.046	.7202	.9835	1.0185	1.0974	1.1694
9	1.3565	.8916	1.286	1.2378	1.3203	1.0974	1.4146
10	1.2717	.8402	1.3032	1.2039	1.3392	1.0974	1.4335
11	1.3375	.823	1.2887	1.3957	1.2174	1.3203	1.2548
12	1.2003	.7716	1.0174	1.1883	1.0974	1.1317	1.0174
13	.8573	.5658	.8309	.9054	.8573	.9242	.7969
14	.9945	.6687	1.1869	1.1883	1.0288	1.1506	1.0004
15	1.2003	.6173	1.1869	1.3014	1.2689	1.3203	1.2039
16	1.2517	.5144	1.17	1.2826	1.2689	1.3392	1.2548
17	1.2517	.5144	1.1869	1.2826	1.2689	1.358	1.2548
18	1.2517	.4801	1.1869	1.226	1.2346	1.358	1.2209
19	1.2346	.4973	1.1869	1.3203	1.1831	1.3769	1.2717
20	1.2346	.5658	1.1361	1.2826	1.2003	1.3392	1.2209
21	1.2346	.6173	1.153	1.2209	1.2346	1.3957	1.2548
22	1.2689	.6687	1.1361	1.2071	1.2174	1.358	1.2717
23	1.2003	.6173	1.1022	1.226	1.2003	1.3392	1.2548
24	1.17	1.2003	.6001	1.0174	1.1317	1.2003	1.226
Max	1.3565	1.2003	1.3032	1.3957	1.3392	1.3957	1.4335
Min	.8573	.4801	.5144	.7969	.7356	.9242	.7969
Avg	1.1376	.7959	.9376	1.1037	1.1026	1.1693	1.1678

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 201 / 11 KV Dhangarmal

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1946	1.1462	.9979	1.1222	1.1827	1.1222	1.1462
2	1.1946	1.1462	.9412	1.0974		1.0974	1.182
3	1.1706	1.1222	.905	1.0608	1.1706	1.0608	1.2308
4	1.134	1.134	.9145	1.0719	1.1946	1.0608	1.1584
5	1.1584	1.1584	.9671	1.1088	1.2071	1.1222	1.0749
6	1.2308	1.1946	1.0498	1.1706	1.1584	1.2437	1.1096
7	1.2536	1.2308	1.0745	1.1222	1.1946	1.182	1.1568
8	1.2403	1.0136	1.1104	1.134	1.1919	1.182	1.182
9	1.283	1.0745	1.1222	1.134	1.2178	1.262	1.2003
10	1.3817	1.0136	1.2403	1.0867	1.1694	1.2269	1.2971
11	1.283	1.0745	1.2269	1.1919	1.1218	1.1443	1.262
12	1.3112		1.1393	1.2178	1.134	1.2449	1.2269
13	1.0867	.9054	1.134	1.0745	.9568	1.0608	1.0498
14	1.0745	.9431	1.1462	1.1222	1.0631	1.182	1.1222
15	1.2048	.961	1.1694	1.1827	1.134	1.2269	1.3169
16	1.1919	1.0242	1.1919	1.1568	1.134	1.2178	1.2757
17	1.2483	.9054	1.2483	1.1789	1.1694	1.1919	1.2894
18	1.2483	.8871	1.2136	1.2483	1.1218	1.182	1.262
19	1.2048	.8238	1.2536	1.182	1.182	1.1584	1.2403
20	1.2178	.8596	1.2536	1.182	1.1584	1.1584	1.2308
21	1.2757	.8688	1.2308	1.1584	1.182	1.1462	1.2894
22	1.2536	.9313	1.1946	1.1584	1.1462	1.182	1.2536
23	1.2178	.905	1.1584	1.134	1.1222	1.182	1.2403
24	1.2308	1.182	.9979	1.1584	1.1827	1.1222	
Max	1.3817	1.2308	1.2536	1.2483	1.2178	1.262	1.3169
Min	1.0745	.8238	.905	1.0608	.9568	1.0608	1.0498
Avg	1.2205	1.0220	1.1201	1.1440	1.1520	1.1650	1.2086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 203 / 11 KV Ghorpade

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9808	.9808	.9431	.9808	.9054	.9431	.9431
2	.9431	.9808	.9054	.9431	.9054	.9431	.9054
3	.9054	.9431	.9054	.9054	.8676	.9054	.9054
4	.9054	.9054	.9054	.9054	.9054	.9054	.8676
5	.9808	.9054	.9808	.9431	.9054	.9808	.9054
6	1.0185	1.0185	.9431	.9808	.9431	.9808	.9808
7	1.0185	1.0185	.9431	.9808	.9808	.9808	.9431
8	.9808	1.0185	.9054	.9431	.8676	.9808	.9431
9	.9431	.9808	1.094	.9808	.8676	.9431	.9808
10	.9808	.9808	.4458	.9054	.9431	.9431	1.0562
11	.9431	1.0185	.9808	.9808	.9054	.9431	.9808
12	.9431		.9808	.9808	.8676	.9808	.9808
13	.9431	.9431	.9431	.9431	.7922	.9054	.9808
14	.9431	.9808	1.0185	.9808	.8299	.9431	.9808
15	.9808	.9808	.9808	.9808	.8299	.9431	.9431
16	.9808	1.0185	.9808	.9431	.8299	.9431	.9808
17	1.0185	.9808	.9431	.9808	.8299	.9808	1.0185
18	.9431	.9808	.9431	.9808	.8676	.9808	.9808
19	.9431	.9808	.9808	.9808	.9054	.9808	.9808
20	.9431	1.0185	.9431	.9808	.8676	.9431	.9431
21	1.0185	.9431	1.0185	.9431	.9431	.9431	.8676
22	.9808	.9054	.9808	.9054	.9808	.9808	.9054
23	1.0185	.9054	.9431	.9431	.9808	.9808	.9808
24	.9808	.9431	.9431	1.0185	.9054	.9431	.9431
Max	1.0185	1.0185	1.094	1.0185	.9808	.9808	1.0562
Min	.9054	.9054	.4458	.9054	.7922	.9054	.8676
Avg	.9682	.9710	.9397	.9588	.8928	.9541	.9541

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochoi Sub Station

Feeder No / Name : 204 / 11 KV Chavan

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6598	1.7353	1.5089	1.7353	1.6975	1.5844	1.6221
2	1.5844	1.6598	1.4712	1.6598	1.6598	1.5089	1.6598
3	1.5844	1.5844	1.4712	1.5844	1.6221	1.4335	1.6598
4	1.5089	1.5844	1.5089	1.5844	1.6598	1.358	1.6975
5	1.5844	1.6221	1.5466	1.5844	1.6598	1.5089	1.7353
6	1.6598	1.6975	1.6598	1.6598	1.6095	1.6975	1.6975
7	1.7353	1.7353	1.6221	1.7353	1.6598	1.6975	1.7353
8		1.6598	1.5089	1.7353	1.5089	1.7353	1.7353
9	1.8484	1.6598	1.6598	1.8107	1.5089	1.8107	1.9239
10	1.8861	1.7353	1.6598	1.8861	1.358	1.9616	1.8861
11	1.8861	1.7353	1.8861	1.8861	1.358	1.8107	1.9616
12	1.8861		1.8861	1.8107	1.358	1.7353	1.8107
13	1.5089	1.5089	1.5844	1.4335	1.2071	1.6598	1.6598
14	1.5844	1.5466	1.6975	1.7353	1.2826	1.7353	1.8107
15	1.773	1.5844	1.773	1.7353	1.2826	1.8107	1.8107
16	1.8861	1.6598	1.8107	1.8861	1.2826	1.8107	1.8107
17	1.8107	1.5844	1.8107	1.8861	1.2696	1.8861	1.8107
18	1.8484	1.5844	1.8861	1.8107	1.1706	1.8861	1.8484
19	1.7353	1.5844	1.8861	1.8107	1.1706	1.8484	1.8107
20	1.7353	1.6221	1.7353	1.8107	1.5089	1.8107	1.773
21	1.8107	1.5466	1.7353	1.773	1.5844	1.8107	1.773
22	1.7353	1.5089	1.7353	1.7353	1.5844	1.8484	1.773
23	1.7353	1.5466	1.7353	1.6975	1.6598	1.8484	1.8107
24	1.6598	1.7353	1.5089	1.7353	1.6975	1.5844	1.6221
Max	1.8861	1.7353	1.8861	1.8861	1.6975	1.9616	1.9616
Min	1.5089	1.5089	1.4712	1.4335	1.1706	1.358	1.6221
Avg	1.7238	1.6270	1.6787	1.7384	1.4734	1.7243	1.7683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 144118 / 33/11 KV Korochi Sub Station

Feeder No / Name : 205 / 11 KV VIVEKANAND NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.6219	.4755	.5544	.5544	.5487	.6283
2	.5121	.5853	.4435	.5544	.5853	.5121	.5487
3	.4805	.5853	.4344	.5228	.5121	.5175	.5487
4	.4481	.5544	.5068	.4854	.5792	.4481	.5175
5	.4755	.5544	.5068	.5228	.6154	.4481	.6154
6	.5121	.6283	.5014	.5975	.6154	.4854	.5258
7	.5792	.6219	.5068	.6219	.6089	.5121	.5258
8	.5609	.6154	.6089	.6516	.5373	.5731	.5144
9	.6443	.5373	.7362	.6173	.5373	.6588	.6516
10	.6516	.543	.5895	.5201	.6241	.6516	.6859
11	.6783	.5014	.6783	.7202	.6241	.6706	.7282
12	.6859		.6859	.724	.6241	.6036	.6241
13	.5068	.3772	.4805	.4854	.3467	.4854	.4481
14	.5731	.4904	.724	.6722	.4508	.5975	.5975
15	.6024	.4904	.6805	.6722	.5201	.6661	.7095
16	.6516	.4854	.6516	.6516	.5895	.6661	.7282
17	.6104	.415	.6783	.6516	.5201	.6516	.6935
18	.6859	.394	.6516	.6024	.4607	.6661	.6588
19	.6379	.3506	.631	.6447	.4706	.695	.6379
20	.6379	.3582	.6447		.5068	.6516	.6154
21	.6379	.3982	.695	.6154	.6089	.6447	.6805
22	.6379	.4755	.6584	.6516	.6089	.6653	.6878
23	.6089	.439	.6653	.6219	.6089	.6584	.6878
24	.543	.6219	.4805	.5914	.5544	.5487	.6283
Max	.6859	.6283	.7362	.724	.6241	.695	.7282
Min	.4481	.3506	.4344	.4854	.3467	.4481	.4481
Avg	.5864	.5063	.5965	.6066	.5527	.5928	.6203



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 202 / 11KV SOOT GIRNI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
23	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 203 / 11KV URBAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 204 / 11 KV VITTHAL NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 205 / 11KV JAWHARNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 209 / L-3

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 210 / 11 KV GANGA NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 211 / 11 KV INDUSTRIAL EXPRESS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	1.4575
Max	1.4575
Min	1.4575
Avg	1.4575

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 401 / 33 KV KABNOOR (METE&KSL)  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 402 / 33 KV ICHALKARANJI  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 403 / 33 KV SHAHAPUR

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 404 / 33 KV KURUNDWAD

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 405 / 33 KV SHIRADWAD

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 406 / 33 KV KABNOOR VILLAGE  
Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 407 / 33KV SHAHAPUR ESTATE  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 408 / 33 KV YASHOLAXMI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

ICHALKARANJI DIVISION[502]

ICHALKARNJI B S/DN.[711] BU 4711

Substation No/ Name :- 146003 / 110KV ICHALKARANJI

Feeder No / Name : 409 / 33 KV Parvati

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	4.3724
Max	4.3724
Min	4.3724
Avg	4.3724



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 201 / 11 kv Chokak Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7625	.0655	.0655	.0655	.663	.6554	.5243
2	.7625	.0655	.0655	.0655	.663	.6554	.5243
3	.7293	.0655	.0655	.0655	.663	.6882	.5243
4	.7293	.0655	.0655	.0655	.663	.7865	.6554
5	.7293	.0655	.0655	.0655	.7293	.8684	.8192
6	.7956	.0655	.0983	.0655	.7956	.9831	1.0159
7	.9282	.0819	.0655	.0655	.8951	1.3927	1.3435
8		.0655	.0819	.0655	1.2597	1.3763	1.4419
9		1.4746	1.4419	.0655	.9175	1.3435	1.2452
10			1.3717	.0655			
11	.0655	1.7238	1.3717	1.704		.0663	
12	.0819	1.7901	1.7147	1.7695		.0663	.0655
13	.426	1.6244	1.6461	1.6385			
14	.0655	1.7238	1.6461	1.5238			
15	.0655	1.6244	1.3032	1.4746			
16	.0655	1.4586		1.3927			
17	.0819		.0655	1.0322			
18			.0655	.8619	.0655	.0655	
19	.0655	.0819	.0655	.0663	.0819	.0819	.0663
20		.0819	.0655	.0829	.0819	.0983	.0829
21	.0819	.0819	.0655	.0829	.0819	.0983	.0829
22	.0819	.0819	.0655		.0819	.0819	.0829
23	.0819	.0655	.0655	.0663		.0655	.0663
24	.8122	.0655	.0655	.0655	.3315	.4424	.4915
Max	.9282	1.7901	1.7147	1.7695	1.2597	1.3927	1.4419
Min	.0655	.0655	.0655	.0655	.0655	.0655	.0655
Avg	.3901	.5914	.5040	.5398	.5316	.5453	.5645

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 202 / 11KV Mudshingi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4712	1.4712	1.5089	1.3443	1.358	1.3203	1.358
2	1.4335	1.4335	1.5089	1.3443	1.3203	1.3203	1.3203
3	1.4335	1.4335	1.5844	1.307	1.3203	1.3957	1.3203
4	1.4335	1.4335	1.6221	1.307	1.3203	1.4335	
5	1.5089	1.5466	1.6598	1.4937	1.358	1.5844	1.4335
6	1.7353	1.7918	1.7353	1.6804	1.4712	1.7353	1.7353
7	1.6598	1.8107	1.7541	1.4937	1.6598	1.7353	1.8484
8	1.5466	1.6975	1.9616	1.4563	1.358	1.4523	1.7918
9	1.5466	1.643	1.7541	1.4937	1.2449	1.5466	1.6598
10	1.6032		1.307	1.5089	1.358	1.9239	1.6975
11	1.6975	1.7353	1.419	1.226		1.9616	1.5466
12	1.7353	1.8484	1.5684	1.5089		1.9616	1.8861
13	1.6221	1.8107	1.3443	1.4146		1.9239	1.7918
14	1.6975	1.6221	1.7177	1.7541		1.9239	1.8107
15	1.7353	1.773	1.8298	1.4712	.9335	2.1125	1.8484
16	.9808	1.6221	1.5684	1.5089	1.6804	2.0748	1.7918
17	1.7918	1.7353	1.6804	1.5089	1.6409	2.0748	1.7353
18	1.5466	1.6975	1.7551	1.5844	1.6032	1.9239	1.6975
19	1.8861	1.9616	2.0165	2.0748	1.7918	2.1125	1.9616
20		2.1125	2.0538	2.1125	2.037	2.1125	2.1502
21	2.0748	2.0748	2.0165	2.0748	2.0748	2.0748	2.0748
22	1.8861	1.9616	1.8671		1.9805	1.9805	1.9616
23	1.773	1.7353	1.643	1.7353	1.7353	1.6975	1.8107
24	1.5089	1.5089	1.6975	1.4563	1.5089	1.5466	1.4712
Max	2.0748	2.1125	2.0538	2.1125	2.0748	2.1125	2.1502
Min	.9808	1.4335	1.307	1.226	.9335	1.3203	1.3203
Avg	1.6221	1.7157	1.6906	1.5591	1.5378	1.7887	1.7262

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 203 / 11 KV HERLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5975	.5601	.5601	.5601	.5975	.5601	.7468
2	.5601	.5601	.5228	.5601	.5601	.5601	.7095
3	.5601	.5601	.5228	.5601	.5601	.5601	.6535
4	.5601	.5601	.5601	.5601	.5601	.6348	.6535
5	.6348	.5601	.6348	.6348	.5975	.6722	.6535
6	.7095	.7095	.7095	.7095	.6722	.7095	.7468
7	.6722	.6722	.5975	.6348	.6348	.6722	.7095
8	.6348	.6722	.6348	.5601	.5975	.6348	.6348
9	.6535	.6722	.5601	.5975	.5601	.5975	.6348
10	.6348			.7095	.5228	.5975	.6161
11	.5975	.5601		.6161	.5601	.6348	.6348
12	.6722	.5601		.7655	.5601	.5975	.6161
13	.7095	.6722		.7095	.6348	.5975	.6722
14	.7095	.6722		.6908		.6348	.6722
15	.6722	.7095	.6348	.6722	.6348	.6722	.7095
16	.7468	.5975	.6348	.6535	.6348	.7468	.6348
17	.6348		.6348	.7095		.583	.5975
18	.6348	.7842	.6348	.7095	.6722	.7095	.6722
19	.8589	.8962	.8589	.8589	.8029	.9335	.8589
20		.9709	.8589	.8962	.9335	.8962	.9335
21	.8215	.8962	.8215	.8215	.9335	.8589	.8962
22	.7468	.8589	.7468		.8589	.7842	.8589
23	.6722	.7095	.6722	.6722	.7468	.6722	.7468
24	.5975	.5975	.6348	.6348	.5975	.5975	.7842
Max	.8589	.9709	.8589	.8962	.9335	.9335	.9335
Min	.5601	.5601	.5228	.5601	.5228	.5601	.5975
Avg	.6649	.6823	.6545	.6738	.6560	.6716	.7103

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 204 / 11Kv Halondi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1543	1.8004	1.5927	1.7147	.1372	.1341	.1715
2	.1543	1.7833	1.5927	1.5775	.1372	.1341	.1715
3	.1543	1.7833	1.5089	1.5775	.1372	.1341	.1715
4	.1543	1.7833	1.5089	***	.1372	.1341	.1867
5	.1543	1.8176	1.5089	1.5432	.1372	.1341	.1715
6	.1543	1.8861	1.5424	1.5432	.1372	.1341	.1886
7	.1543	1.8519	1.6095	1.6804	.1372		.1886
8	.1543	.1372	.1341	1.5261	.1372	.1677	.1886
9	2.5377	.1372	.1509	1.4937	.1372	.2012	.1844
10	2.7435	.1543	.1475	.1341	.1543	.1715	.1677
11	2.6749	.0686	.1475	.1341	2.7435	2.7435	2.8502
12	2.6063	.0686	.168	.1341	3.0178	2.915	2.9508
13	2.5034	.0686	.1543	.1341	2.9492	2.8464	2.8166
14	2.5377		.1311	.1341			2.6825
15	2.5377	.0686	.1311	.1509	2.8121	2.7435	2.6322
16	2.1262	.0686	.1311	.1509	2.7435	2.7092	2.4813
17	.12	.0686	.1475	.1509	2.6063	2.1262	2.5149
18	.1372	.2012	.1475	.1543	2.2801	2.1948	2.4006
19	.1543	.2012	.1475	.1543	.1341	.2058	.1886
20		.1677	.1475	.1543	.1509	.2058	.1886
21	.1543	.1677	.1475		.1677	.2058	.1886
22	1.7147	1.576	1.7833	.1543	.1341	.1886	.1886
23	1.7833	1.643	1.8347	.1543	.1341	.1886	.1886
24	.1543	1.8004	1.5927	1.7833	.1372	.1341	.1886
Max	2.7435	1.8861	1.8347	15.7751	3.0178	2.915	2.9508
Min	.12	.0686	.1311	.1341	.1341	.1341	.1677
Avg	1.1183	.8393	.7545	1.3961	.9304	.9433	1.0105

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144039 / 33/11 KV CHOKAK S/STN

Feeder No / Name : 205 / 11Kv Rukadi Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2291	.0514	.1029	.0492	2.4348		2.2291
2	2.2291	.0514	.1029	.0492	2.4348	2.3899	2.2291
3	2.1605	.0514	.1029	.0492	2.4348	2.1948	2.2291
4	2.1605	.0514	.1029	.0492	2.4348	2.2291	2.2291
5	2.1262	.0514	.1029	.0492	2.4691	2.4006	2.3148
6	2.0919	.0514	.12	.0492	2.5034	2.452	2.4863
7	2.0919	.0514	.12	.0492	3.0521	2.7606	2.6749
8	.0343	.0686	.0686	.056	2.9492	2.7778	2.6749
9	.0514	3.155	3.2236	.056	2.7435	2.5892	2.7092
10	.0343	3.2922	3.2922	.0686	.0686	.0686	.0514
11	.0171	.1715	3.0864	2.8292	.0343	.0514	.0343
12	.0686	2.0919	3.2236	2.9492	.0351	.0686	.0343
13	.0514	2.2977	3.2236	3.1893	.0351	.0686	.0343
14	.0857	3.2579	3.155	3.2922		.0686	.0343
15	.0857		3.0864	3.2922	.0343	.0686	.0514
16	.1029	3.0864	3.0178	3.3265	.0514	.0686	.0514
17	.1029	.0343	.0492	3.0864	.0343	.0686	.0514
18	.1029	.12	.1475	2.9492	.0343	.0343	.0514
19	.1029	.1029	.0492	.0514	.0686	.0514	.0514
20		.12	.0492	.0686	.0857	.0514	.0686
21	.0857	.12	.0492	.0686	.0686	.0514	.0686
22	.0514	.12	.0492	.0514	.0686	.0514	.0686
23	.0514	.12	.0492	.0514	.0686	.0514	.0686
24	2.2634	.0514	.1029	.0492	2.2634	2.0576	2.1948
Max	2.2634	3.2922	3.2922	3.3265	3.0521	2.7778	2.7092
Min	.0171	.0343	.0492	.0492	.0343	.0343	.0343
Avg	.7992	.8074	1.1116	1.0742	1.1481	.9858	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 201 / 11 KV Nimshirgaon AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.0469	.0781	.0492	.125	.2016	.2458
2	.3086	.0469	.0781	.0492	.1562	.1875	.2458
3	.3086	.0469	.0625	.0492	.1562	.1875	.2622
4	.2743	.0469	.0625	.0492	.1875	.2031	.2785
5	.2743	.0469	.0625	.0492	.2187	.2343	.3174
6	.3772	.0625	.0838	.0492	.25	.2968	.3441
7	.5144	.0625	.0781	.0492	.5624	.4687	.4862
8	.0514	.061	.0625	.0469	.4999	.5468	.503
9	.0514	.6097	.5312	.0469	.4915	.5312	.4843
10	.0514	.724	.6249	.0312	.0492	.0312	.0469
11	.0709	.7602	.6249	.6249	.0492	.0312	.0625
12	.061	.724	.5937	.6249	.0492	.0469	.0469
13	.061	.6878	.5624	.5624	.0655	.0312	.0469
14	.061	.6516	.5312	.4687	.0655	.0514	.0469
15	.0457	.6584	.5624	.5155	.0747	.0686	.0469
16	.0686	.6878	.4999	.5155	.0514	.0312	.0625
17	.0686	.061	.0492	.5312	.0469	.0514	.0625
18	.0686	.061	.0492	.4687	.0469	.0492	.0625
19	.061	.061	.0492	.0625	.0469	.0492	.0312
20	.061	.0625	.0492	.0625	.0625	.0492	.0625
21	.0625	.0625	.0492	.0312	.0625	.0492	.0312
22	.0625	.0781	.0492	.0312	.0625	.0492	.0625
23	.0625	.0781	.0492	.0312	.0625	.0492	.0625
24	.3239	.0469	.0781	.0492	.125	.1718	.2294
Max	.5144	.7602	.6249	.6249	.5624	.5468	.503
Min	.0457	.0469	.0492	.0312	.0469	.0312	.0312
Avg	.1525	.2681	.2301	.2104	.1487	.1528	.1721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 202 / 11 KV Alate AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.2656	.25	.213	.4374	.5624	.5898
2	.823	.2591	.2343	.213	.4687	.5624	.5898
3	.823	.25	.2343	.1966	.4687	.5624	.6226
4	.8573	.25	.25	.213	.5312	.5937	.6718
5	.8573	.25	.25	.2458	.5937	.6562	.7209
6	1.2003	.2656	.2812	.2458	.7499	.8905	1.0814
7	1.5775	.2343	.25	.1966	1.3123	1.531	1.6598
8	.2401	.2343	.2187	.2294	1.3123	1.6248	1.7436
9	.2401	2.1384	1.6404	.1875	1.278	1.4685	1.4373
10	.2229	2.0633	1.781	.1875			.2031
11	.2103	2.2443	1.781	1.9372			.2656
12	.1875	2.1285	1.656	1.9372			.125
13	.1718	1.9909	1.5623	1.7185	.1638		.125
14	.1875	1.8298	1.4998	1.4217	.1638	.12	.1094
15	.1875	1.8298	1.531	1.4685	.1638	.2401	.1094
16	.2058	1.643	1.4998	1.5466	.1886	.125	.1406
17	.2915	.1677	.1966	1.4685	.2031	.1543	.1406
18	.2401	.2187	.2294	1.3765	.2187	.2294	.125
19	.3281	.2812	.2949	.3125	.2656	.1966	.25
20	.3125	.3281	.3113	.3125	.2968	.2458	.2812
21	.3281	.3125	.3277	.3125	.3125	.2458	.25
22	.3125	.2968	.2949	.3125	.3125	.2294	.25
23	.2812	.2656	.2622	.25	.25	.213	.2187
24	.7907	.2812	.25	.2458	.3749	.5155	.5407
Max	1.5775	2.2443	1.781	1.9372	1.3123	1.6248	1.7436
Min	.1718	.1677	.1966	.1875	.1638	.12	.1094
Avg	.4889	.8345	.7120	.6979	.4793	.5483	.5105

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 203 / 11 Kv Atigre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.415	.4527	.4527	.4294	.439	.4338	.4668
2	.3772	.4338	.4338	.4294	.3749	.415	.4481
3	.3772	.4338	.4338	.3921	.439	.415	.4108
4	.415	.4338	.4338	.3921	.439	.415	.4108
5	.4527	.4527	.4527	.4108	.439	.4338	.4481
6	.5093	.4715	.4904	.4108	.4755	.4527	.5041
7	.4715	.4527	.4715	.4294	.439	.4527	.5041
8	.415	.3961	.415	.3921	.4024	.3584	.4294
9	.415	.3961	.4024	.4031	.2614	.3658	.415
10	.4251	.3395	.3856	.4024	.2614	.3658	.415
11	.4251	.415	.4207	.4024	.2614	.3658	.415
12	.415	.4294	.439	.4024	.2801	.4024	.3961
13	.3206	.3961	.4024	.3506	.2614	.4024	.3772
14	.3772	.3772	.3658	.3772	.2801	.3881	.4338
15	.4338	.415	.4024	.415	.3174	.4251	.4527
16	.4338	.4527	.4207	.415	.2452	.4252	.4338
17	.4715	.415	.4108	.4338	.2641	.3881	.4024
18	.4715	.4527	.4668	.4024	.3018	.3734	.439
19	.6036	.5281	.5415	.5487	.4338	.5228	.5487
20	.5847	.5658	.5601	.5487	.5281	.5601	.567
21	.5658	.547	.5788	.5487	.5847	.5788	.5853
22	.5658	.547	.5415	.5487	.547	.5601	.5487
23	.5281	.5281	.5228	.5121	.5093	.5228	.5121
24	.4527	.4715	.4715	.4294	.4755	.4527	.4668
Max	.6036	.5658	.5788	.5487	.5847	.5788	.5853
Min	.3206	.3395	.3658	.3506	.2452	.3584	.3772
Avg	.4551	.4501	.4549	.4344	.3859	.4365	.4596



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 206 / Jathar Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6194	1.7147	1.7147	1.7147	1.7909	1.6004	1.6766
2	1.6766	1.6766	1.6766	1.6766	1.7909	1.5623	1.6766
3	1.6766	1.6766	1.6766	1.6385	1.829	1.5623	1.7147
4	1.6766	1.6766	1.7147	1.6385	1.7909	1.5623	1.7147
5	1.7147	1.7147	1.7528	1.7528	1.7528	1.6004	1.7528
6	1.8099	1.7528	1.7147	1.8099	1.829	1.6766	1.6766
7	1.7147	1.7528	1.7147	1.7909	1.7909	1.6766	1.6766
8	1.7147	1.7147	1.6766	1.7909	1.7147	1.6385	1.6766
9	1.7147	1.8099	1.5623	1.7909	1.3336	1.5242	1.7528
10	1.7147	1.9052	1.6004	1.829	1.1431	1.6385	1.7528
11	1.6194	1.7147	1.7147	1.7909	1.105	1.7147	1.7147
12	1.7147	1.7147	1.6385	1.7528	1.105	1.6194	1.6194
13	1.7147	1.7147	1.5623	1.6461	.1143	1.6385	1.6766
14	1.8099	1.6194	1.6004	1.7528	1.105	1.6194	1.6766
15	1.848	1.6575	1.5623	1.7147	1.105	1.6385	1.6766
16	1.7528	1.7147	1.6385	1.7909	1.1241	1.7147	1.5623
17	1.7147	1.6385	1.7909	1.7909	1.1431	1.6766	1.4998
18	1.7147	1.7147	1.7909	1.7147	1.105	1.6004	1.6766
19	1.7528	1.8099	1.829	1.7528	1.1431	1.6766	1.6766
20	1.7147	1.7528	1.7147	1.7147	1.3717	1.6766	1.7528
21	1.7147	1.7147	1.7147	1.7528	1.6766	1.6766	1.7147
22	1.7147	1.7528	1.7909	1.7909	1.6766	1.6766	1.7147
23	1.7147	1.7528	1.7147	1.829	1.5623	1.6766	1.7147
24	1.7147	1.7147	1.7147		1.7528	1.5242	1.6766
Max	1.848	1.9052	1.829	1.829	1.829	1.7147	1.7528
Min	1.6194	1.6194	1.5623	1.6385	.1143	1.5242	1.4998
Avg	1.7187	1.7242	1.6909	1.7490	1.4106	1.6321	1.6843

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 207 / 11KV ALATE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7545	.7167	.7167	.6722	.6219	.6036	.7468
2	.7545	.679	.7167	.6535	.6219	.5658	.7095
3	.7545	.679	.7545	.6348	.6584	.5658	.7095
4	.7545	.7167	.7167	.6348	.6584	.6036	.6908
5	.7545	.7545	.7167	.6908	.695	.6036	.7468
6	.7545	.8488	.7545	.7468	.7316	.679	.7468
7	.7545	.9054	.7922	.7655	.6584	.7167	.8589
8	.7545	.6602	.7167	.6348	.5853	.6036	.7842
9	.7922	.8488	.7316	.8413	.4294	.695	.8962
10	.9431	1.0374	.8779	1.0608	.6348	.8413	1.1317
11	1.0164	1.1317	.9511	1.0608	.6535	.9145	1.1203
12	1.1317	1.0374	.8779	.9877	.4668	.823	.9335
13	.7545	.9431	.8413	.8048	.6161		.9335
14	.9431	.8488	.8413	.9431	.6161	.5228	.9709
15	.9054	1.0374	.9145	1.1317	.5975	.9335	1.0185
16	.7922	.9431	.8779	.9808	.3961	.8779	1.094
17	.7545	.9808	.9335	1.0374	.3772	.961	.9511
18	.7545	1.0374	.9335	1.0059	.5281	.8962	.9568
19	.7545	.7545	.8962	.8048	.6036	.8962	.9511
20	.8488	.9054	.8589	.9145	.7167	.9335	.9877
21	.7545	.9054	.8402	.8413	.7545	.9335	.9511
22	.7545	.9054	.7842	.8779	.7545	.8962	
23	.7545	.7922	.7655	.7316	.7167	.9149	.9877
24	.7545	.7167	.7167	.6722	.6584	.6036	.7468
Max	1.1317	1.1317	.9511	1.1317	.7545	.961	1.1317
Min	.7545	.6602	.7167	.6348	.3772	.5228	.6908
Avg	.8102	.8661	.8136	.8387	.6146	.7646	.8967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144040 / 33/11 KV HATKANGALE

Feeder No / Name : 208 / Laxminagar Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0724	.0905	.0747	.0732	.0724	.0934
2	.0377	.0724	.0724	.0747	.0732	.0724	.0747
3	.0377	.0724	.0724	.0747	.0732	.0724	.0747
4	.0377	.0724	.0724	.0747	.0732	.0724	.0747
5	.0943	.0724	.0905	.0747	.0732	.0724	.0934
6	.1132	.0905	.0905	.0747	.0732	.0905	.0934
7	.1132	.0905	.0905	.0934	.0732	.0905	.112
8	.1132	.1086	.0905	.0934	.0732	.0905	.0747
9	.1132	.1086	.0914	.1097	.0724	.1097	.0905
10	.132	.1086	.0732	.0732	.0905	.1097	.1086
11	.0934	.0905	.0732	.0732	.0905	.0732	.1086
12	.0905	.1086	.0732	.0732	.1086	.1097	.1086
13	.1086	.1086	.0732	.0732	.0905	.1097	.1086
14	.1086	.0905	.1097	.0905	.112	.112	.1086
15	.1086	.1086	.1097	.0905	.112	.112	.1086
16	.1132	.1086	.1097	.0905		.1097	.1086
17	.1132	.1086	.112	.1086	.1086	.1097	.1097
18	.1086	.1086	.112	.1097	.0905	.112	.1097
19		.1132	.1307	.0732	.1086	.0934	.0732
20	.1086	.1086	.112	.0732	.1267	.0934	.1097
21	.1086	.1086	.112	.1063	.1086	.112	.1097
22	.1086	.0905	.112	.1097	.1086	.112	.1097
23	.0905	.1086	.0934	.1097	.1086	.112	.1097
24	.0905		.0905	.0747	.0732	.0905	.0934
Max	.132	.1132	.1307	.1097	.1267	.112	.112
Min	.0377	.0724	.0724	.0732	.0724	.0724	.0732
Avg	.0965	.0970	.0941	.0864	.0911	.0964	.0986

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 201 / 11 KV Hingangaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.278	1.4419	1.3413		.0335	.0381
2		1.2452	1.4091	1.3413		.0335	.0381
3		1.278	1.4091	1.3413		.0335	.0381
4		1.278	1.4091	1.3413		.0335	.0381
5		1.3108	1.4091	1.3413		.0335	.0381
6		1.3279	1.4419	1.4083		.0335	.0381
7		1.3603	1.4251	1.3413	.0332	.0335	.0381
8		.0328	.0324	1.4754	.0332	.0328	.0381
9	2.0081		.0332	1.3748	.0335	.0328	.0381
10	2.1052	.0335	.0332	.0381	.0335	.0328	.0381
11	1.9433	.0335		.0381	2.079	2.0081	2.1795
12	1.7814	.0335		.0381	2.1125	2.17	2.1795
13	1.8138	.0335		.0381	2.0454	2.1445	2.0957
14	1.8138	.0335		.0381	2.2131	2.17	2.0119
15		.0335		.0381	2.2131	2.1376	1.9448
16	1.7166	.0335		.0381	2.2131	2.1052	1.9281
17	.0328	.0324	.0335		2.1795	2.0454	1.8461
18	.0328	.0324	.0335		2.079	1.8778	1.7166
19	.0328	.0328	.0335		.0335	.0381	.0324
20	.0328	.0328	.0335		.0335	.0381	.0324
21	.0328	.0324	.0335		.0335	.0381	.0328
22	1.3763	1.5546	1.5089		.0335	.0381	.0328
23	1.3279	1.4899	1.4419		.0335	.0381	.0328
24		1.2955	1.4251	1.4419		.0335	.0381
Max	2.1052	1.5546	1.5089	1.4754	2.2131	2.17	2.1795
Min	.0328	.0324	.0324	.0381	.0332	.0328	.0324
Avg	1.1465	.6021	.8104	.8244	1.0256	.7173	.6869

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 202 / 11 KV Warana Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0655	.0655	.0671		1.1904	1.0898
2		.0655	.0655	.0671		1.1904	1.1904
3		.0655	.0655	.0671		1.2071	1.2239
4		.0655	.0655	.0671		1.2071	1.2239
5		.0655	.0655	.0671		1.2071	1.2574
6		.0655	.0819	.0838		1.3077	1.291
7		.0663	.0655	.0671	1.3565	1.4083	1.3077
8		.0486	.0655	.0671	1.4582	1.3599	1.291
9	.0655	1.576	1.8143	.0655	1.0059	1.2944	1.3413
10	.0655	1.5927	1.8143	.0655	.0671	.0492	.0655
11	.0655	1.5927		1.7604	.0671	.0492	.0655
12	.0648	1.6933		1.8275	.0671	.0655	.0655
13	.081	1.5927		1.7436	.0671	.0655	.0655
14	.0648	1.5927		1.643	.0671	.0655	.0655
15	.0648	1.6263		1.5927	.0671	.0819	.0655
16	.0486	1.5257		1.3413	.0671	.0648	.0655
17	.0492	.0819	.0838		.0671	.0492	.0492
18	.0497	.0655	.0838		.0671	.0492	.0492
19	.0663	.0983	.0671		.0671	.0655	.0663
20	.0829	.1147	.0671		.0671	.0819	.0829
21	.0829	.0819	.0838		.0671	.0819	.0819
22	.0663	.0819	.0671		.0671	.0819	.0819
23	.0655	.0655	.0671		.0671	.0655	.0663
24		.0655	.0655	.0671		.8718	.9724
Max	.0829	1.6933	1.8143	1.8275	1.4582	1.4083	1.3413
Min	.0486	.0486	.0655	.0655	.0671	.0492	.0492
Avg	.0656	.5815	.2641	.6271	.28	.5484	.5469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 203 / 11KV Kumbhoj Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6348	.5658	.5544		.5544	.4755
2		.6036	.5658	.5544		.5544	.4755
3		.5658	.5658	.5544		.5175	.4755
4		.5658	.6036	.5544		.5175	.4755
5		.6413	.6413	.5544		.5175	.6401
6		.7468	.7468	.7023			.7316
7		.6653	.6653	.6653	.6516	.6283	.6219
8		.5914	.5975	.5914	.5792	.543	.5487
9	.5853	.5544	.5792	.5853	.4805	.5373	.5121
10	.5731	.5544	.5792	.5487	.4805	.5373	.5121
11	.5731	.5544		.5487	.5544	.5731	.5487
12	.5731	.5914			.5544	.5853	.5853
13	.5731	.6283		.5853	.5914	.6089	.5853
14	.6089	.6283		.6584	.5914	.6089	.6219
15	.6089	.6283		.6219	.5914	.6089	.6219
16	.5731	.5914		.6219	.5914	.6089	.6219
17	.5792	.6089	.5914		.5914	.5853	.6154
18	.6283	.6089	.5544		.6283	.6219	.5853
19	.8131	.8413	.8131		.7023	.7682	.8131
20	.8501	.9335	.7762		.8871	.8779	.8501
21	.8215	.8589	.7762		.8871	.8779	.8215
22	.8215	.8215	.7762		.8131	.7316	.7842
23	.7468	.6722	.7023		.7392	.6219	.7023
24		.6722	.5975	.5914		.5544	.5487
Max	.8501	.9335	.8131	.7023	.8871	.8779	.8501
Min	.5731	.5544	.5544	.5487	.4805	.5175	.4755
Avg	.6619	.6568	.6499	.5933	.6420	.6148	.6156

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 204 / 11 KV Bahubali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0492	.0492	.0503		.503	.503
2		.0492	.0492	.0503		.503	.5365
3		.0492	.0492	.0503		.503	.5365
4		.0492	.0492	.0503		.503	.57
5		.0492	.0492	.0503		.57	.6036
6		.0655	.0655	.0503		.6036	.6706
7		.0655	.0648	.0503	.6962	.8048	.8048
8		.0648	.0492	.0503	.7293	.7701	.8718
9	.0328	1.0059	.8785	.0328	.3018	.7209	.788
10	.0324	1.073	1.5432	.0328	.0335	.0328	.0328
11	.0324	1.073		.9892	.0335	.0324	.0328
12	.0324	1.0395		1.0562	.0335	.0486	.0335
13	.0324	.7545		.9892	.0503	.0324	.0328
14	.0324	.7545		.9389	.0503	.0324	.0328
15	.0486	.9221		.8886	.0503	.0486	.0328
16	.0486	.8718		.4862	.0503	.0486	.0328
17	.0492	.0328	.0335		.0503	.0492	.0328
18	.0492	.0492	.0335		.0503	.0328	.0328
19	.0663	.0492	.0335		.0503	.0492	.0328
20	.0663	.0492	.0335		.0503	.0655	.0328
21	.0663	.0655	.0503		.0671	.0655	.0492
22	.0655	.0655	.0503		.0671	.0655	.0492
23	.0648	.0492	.0503		.0671	.0655	.0492
24		.0486	.0492	.0503		.3688	.3521
Max	.0663	1.073	1.5432	1.0562	.7293	.8048	.8718
Min	.0324	.0328	.0335	.0328	.0335	.0324	.0328
Avg	.0480	.3477	.1767	.3451	.1430	.2716	.2811

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 205 / 11 KV Narande Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1865	.1865	.1844		1.1233	1.0288
2		.1865	.1865	.1844		1.1233	1.2003
3		.1865	.1865	.1844		1.1736	1.2689
4		.1865	.1865	.1844		1.1736	1.3717
5		.1865	.1865	.1844		1.1736	1.3717
6		.1865	.1802	.2012		1.2574	1.406
7		.1865	.1865	.1844	1.3375	1.3916	1.5947
8		.1865	.1696	.1844	1.3546	1.5261	1.6118
9	.1357	1.6598	1.5432	.1886	.6036	1.3735	1.5775
10	.1357	1.7604		.1886	.1677	.1696	.1715
11	.1357	1.7604		1.6632	.1677	.1696	.1715
12	.1357	1.3748		1.7661	.1677	.1696	.1715
13	.1357	1.5424		1.7661	.1509	.1696	
14	.1696	1.5424		1.6975	.1677	.1696	.1715
15	.1696	1.4586		1.6289	.1677	.1696	.1715
16	.1696	1.3077		.9431	.1677	.1619	.1715
17	.1696	.1696	.1844		.1677	.1715	.1696
18	.1865	.1865	.1844		.1677	.1886	.1696
19	.1865	.1865	.1844		.1844	.1886	.1865
20	.1865	.1865	.1844		.1844	.1886	.1865
21	.1865	.1865	.2012		.1844	.1886	.1865
22	.1865		.1844		.1677	.1886	.1865
23	.1865	.1865	.1844		.1677	.1886	.1865
24		.1865	.1865	.1844		.5197	.7202
Max	.1865	1.7604	1.5432	1.7661	1.3546	1.5261	1.6118
Min	.1357	.1696	.1696	.1844	.1509	.1619	.1696
Avg	.1651	.6603	.2651	.6776	.3339	.5966	.6718



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 206 / 11 KV Kumbhoj AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9831	1.0159	.9389		.0335	.0381
2		.9503	1.0159	.9389		.0335	.0381
3		.9503	1.0159	.9389		.0335	.0381
4		.9503	1.0159	.9389		.0335	.0381
5		.9503	1.0159	.9389		.0335	.0381
6		.9393	1.004	.9389		.0335	.0381
7		.9717	1.004	.9054	.0332	.0335	.0381
8		.0328	.0324	.9054	.0332	.0328	.0381
9	1.3603	.0335	.0332	.9054	.0335	.0328	.0381
10	1.4251	.0335	.0332	.0381	.0335	.0328	.0381
11	1.3927	.0335		.0381	1.2742	1.5364	1.3413
12	1.3279	.0335		.0381		1.6194	1.4083
13	1.2955	.0335		.0381	1.2071	1.5364	1.4419
14	1.2955	.0335		.0381	1.576	1.5223	1.5089
15	1.2955	.0335		.0381	1.576	1.4575	1.5424
16	1.0688	.0335		.0381	1.576	1.4251	1.5089
17	.0328	.0324	.0335		1.576	1.3748	1.3927
18	.0328	.0324	.0335		1.576	1.3413	1.2955
19	.0328	.0328	.0335		.0335	.0381	.0324
20	.0328	.0328	.0335		.0335	.0381	.0324
21	.0328	.0324	.0335		.0335	.0381	.0328
22	1.0159	1.004	1.0059		.0335	.0381	.0328
23	1.004	1.004	1.0059		.0335	.0381	.0328
24		.9717	1.004	1.0059		.0335	.0381
Max	1.4251	1.004	1.0159	1.0059	1.576	1.6194	1.5424
Min	.0328	.0324	.0324	.0381	.0332	.0328	.0324
Avg	.8430	.4224	.5761	.5660	.6664	.5154	.5009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 207 / 11KV Bahubali-Nej Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1509	.1509	.1294		.1294	.1509
2		.1509	.1509	.1294		.1294	.1509
3		.1509	.1509	.1294		.1294	.1509
4		.1509	.1509	.1294		.1294	.1509
5		.1509	.1509	.1294		.1294	.1698
6		.1509	.1698	.1478		.1663	.1698
7		.132	.1494	.1109	.1294	.1478	.1509
8		.1867	.1307	.1294	.1109	.2054	.132
9	.1886	.2402	.3326	.2263	.1294	.1478	.1886
10	.1886	.1663	.0018	.2075	.1294	.1848	.1509
11	.1886	.1663		.2452	.1294	.1663	.1886
12	.168	.2218		.2263	.1294	.2033	.1698
13	.168	.1663		.1886	.1478	.1294	.1698
14	.1886	.1663		.1698	.1294	.1848	.1886
15	.2075	.2587		.1698	.1294	.2054	.2263
16	.2614	.1478		.132	.1294	.1867	.1886
17	.2263	.1663	.1848		.1294	.1886	.1848
18	.1886	.2957	.1663		.1109	.1509	.1663
19	.2075	.2587	.1848		.1294	.2075	.168
20	.2263	.2241	.1848		.1848	.2075	.168
21	.1698	.1698	.1478		.1848	.2075	.1698
22	.1509	.1698	.1478		.1663	.1886	.1509
23	.1509	.1698	.1663		.1478	.1698	.1494
24		.1509	.1509	.1294		.1294	.1509
Max	.2614	.2957	.3326	.2452	.1848	.2075	.2263
Min	.1509	.132	.0018	.1109	.1109	.1294	.132
Avg	.1920	.1818	.1596	.1606	.1381	.1677	.1669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144041 / 33/11 KV KUMBHOJ S/STN (HTK)

Feeder No / Name : 208 / Parshwanath LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.5487	.4115	.631	.4557	.5144
4		.6173	.5144	.631	.4557	.6173
5		.6173	.5487	.631	.631	.6173
6		.6173	.5487	.631	.631	.6344
7		.7373	.7545	.631	.631	.6344
8		.7373	.7545	.631	.6173	.6344
9	.7202	.7888	.7449	.6173	.6173	.6344
10	.7202	.7888	.7773	.6173	.6344	.6344
11	.7202	.7888		.6344	.6344	.6344
12	.703	.7888		.6344	.6687	.583
13	.6859	.7888		.6344	.583	.6859
14	.6859	.7888		.6344	.583	.7716
15	.6516	.7186		.6173	.5658	.7716
16	.6687	.631		.2572	.583	.7373
17	.6687	.7373	.2279		.6001	.7373
18	.6516	.7545	.0351		.5658	.7373
Max	.7202	.7888	.7773	.6344	.6687	.7716
Min	.6516	.5487	.0351	.2572	.4557	.5144
Avg	.6876	.7156	.5318	.6023	.5911	.6612

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 201 / Tamadalage VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2452	.2452	.2452	.2058	.2263	.2075	.2452
2	.2263	.2195	.2263	.2058	.1886	.2075	.2263
3	.1886	.2149	.2263	.1715	.1698	.1791	.2241
4	.1886	.2126	.2263	.1543	.1509	.181	.2263
5	.2075	.2149	.2641	.1543	.1886	.2241	.2452
6	.2263	.2829	.3018	.1715	.2452	.2829	.2829
7	.2641	.2829	.2452	.2572	.3018	.2829	.2452
8	.2263	.2263	.2263	.2743	.2075	.2263	.2263
9	.2641	.2452	.2263	.2572	.2641	.2402	.2829
10	.3326	.3086	.3018	.3206	.2743	.2641	.3174
11	.2957	.3086	.3584	.3772	.2572	.3018	.3511
12	.3696	.2743	.3018	.3734	.2572	.3018	.3174
13	.2772	.3086	.2641	.2452	.2401	.2263	.2801
14	.3326	.3086	.2641	.2829	.2743	.3018	.2263
15	.4066	.2743	.3018	.3018	.3086	.3018	.2987
16	.4251	.2915	.3772	.3206	.3086	.2829	.3018
17	.3206	.2915	.3206	.3018	.2572	.2829	.3018
18	.2263	.2641	.3429	.1886	.1886	.2452	.2452
19		.415	.4115	.4338	.415	.415	.3772
20		.4715	.4458	.4904	.4904	.4904	.415
21	.5093	.4715	.4115	.4715	.4527	.4527	.3961
22	.4715	.4715	.3353	.4338	.3961	.4338	.3395
23	.3395	.3961	.3429	.3772	.3018	.3772	.2829
24	.2641	.2641	.2829	.2401	.2641	.2263	.2452
Max	.5093	.4715	.4458	.4904	.4904	.4904	.415
Min	.1886	.2126	.2263	.1543	.1509	.1791	.2241
Avg	.3004	.3027	.3021	.2921	.2762	.2890	.2875

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 202 / Nimshirgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2846	.0185	.0187	.0171	.1581	.1739	.1852
2	.2656	.0185	.0187	.0171	.1562	.1739	.1852
3	.2429	.0185	.0187	.0171	.1265	.1739	.1852
4	.2401	.0185	.0187	.0171	.1619	.1739	.1852
5	.427	.0185	.0187	.0171	.2031	.2214	.2315
6	.4687	.0185	.0185	.0343	.3163	.3005	.3125
7	.427	.0339	.0179	.0343	.3681	.427	.4531
8	.037	.0324	.0185	.0343	.4111	.4586	.4843
9	.037	.4111	.4428	.0514	.3749	.4586	.4428
10	.0149	.5335	.5624	.0312	.0343	.037	.0175
11	.0166	.5335	.5441	.5155	.0343	.0332	.0162
12	.0164	.5335	.5281	.5468	.0343	.0312	.032
13	.0171	.5335	.5121	.5312	.0343	.0312	.0297
14	.0173	.503	.4687	.4687	.0343	.0181	.0171
15	.0335	.4877	.4531	.4687	.0343	.037	.0335
16	.0305	.4725	.4531	.4843	.0343	.037	.0351
17	.0343	.0343	.0332	.4999	.0343	.0543	.0316
18	.0339	.0316	.0343	.4214	.032	.0297	.0362
19	.0332	.0324	.0343	.0373	.0171	.0171	.0362
20		.0173	.0343	.0351	.0177	.0362	.0373
21	.037	.0183	.0343	.0362	.0177	.037	.0362
22	.037	.0185	.0343	.037	.0181	.037	.0351
23	.0185	.0185	.0171	.0185	.0181	.0187	.0185
24	.3005	.0185	.0185	.0171	.1423	.1423	.1389
Max	.4687	.5335	.5624	.5468	.4111	.4586	.4843
Min	.0149	.0173	.0171	.0171	.0171	.0171	.0162
Avg	.1335	.1823	.1814	.1829	.1172	.1316	.1340

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029] BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 203 / 11 KV Hatkanangale Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1219	.0183	.0124	.0171	.0762	.0937	.0762
2	.1219	.0183	.013	.0171	.096	.0937	.0762
3	.108	.0187	.013	.0171	.0781	.0781	.0762
4	.1094	.0187	.0124	.0171	.0926	.0781	.0762
5	.1524	.0187	.0122	.0171	.1067	.1094	.0762
6	.1677	.0185	.012	.0171	.1543	.1406	.1372
7	.1698	.0168	.0122	.0171	.1875	.2187	.1957
8	.0171	.016	.0175	.0171	.2187	.2134	.2107
9	.0156	.2006	.216	.0171	.1981	.2134	.2134
10	.0124	.2591	.2286	.0154	.0171	.0171	.0171
11	.0141	.2286	.2656	.2469	.0171	.0162	
12	.0156	.2286	.2623	.2778	.0171	.0152	
13	.013	.2134	.2469	.3086	.0171	.0152	
14	.0133	.2134	.2591	.2932	.0171	.017	
15	.0137	.2439	.2623	.2469	.0171	.0175	.0166
16	.0143	.2439	.2469	.216	.0171	.0162	.0171
17	.0171	.0171	.0162	.216	.0171	.0171	.0154
18	.0168	.0112	.0171	.2054	.0156	.0105	.0162
19	.0164	.013	.0171	.0171	.0168	.0133	.0179
20	.0171	.0162	.0171	.0171	.0173	.0122	.0171
21	.0183	.0133	.0171	.017	.0173	.0133	.0171
22	.0183	.0137	.0171	.0171	.0177	.0133	.0171
23	.0183	.0128	.0171	.0187	.0177	.012	.0171
24	.1235	.0183	.0137	.0171	.0762	.0781	.0762
Max	.1698	.2591	.2656	.3086	.2187	.2187	.2134
Min	.0124	.0112	.012	.0154	.0156	.0105	.0154
Avg	.0553	.0871	.0927	.0952	.0635	.0635	.0691

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

HATKANANGALE[029]

BU 1163

Substation No/ Name :- 144113 / 33/11Kv Awade Park

Feeder No / Name : 204 / 11 KV Ganeshnagar

SEPARATED GAOTHAN FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0754	.0747	.0686		.0724	.0754
2	.0566	.0754	.0754	.0686	.0754	.0732	.0754
3	.0566	.0566	.0566	.0514	.0566	.0549	.0754
4	.0566	.0566	.056	.0514	.0566	.0549	.0754
5	.0754	.0754	.0747	.0514	.0754	.0739	.0754
6	.0754	.0943	.0747	.0686	.0943	.0754	.0754
7	.0754	.0754	.0747	.1029	.1132	.0754	.0943
8	.0943	.0943	.0754	.12	.0943	.0943	.0943
9	.1132	.1267	.1132	.1029	.0754	.0934	.112
10	.1463	.1543	.1132	.1132	.0857	.1132	.1307
11	.1463	.1715	.132	.1463	.1029	.132	.1663
12	.1463	.1543	.1132	.132	.12	.1509	.1494
13	.1463	.1715	.132	.1509	.12	.1132	
14	.128	.1715	.1132	.132	.12	.132	.1494
15	.128	.1543	.1509	.132	.12	.1509	.168
16	.1646	.1543	.1509	.132	.12	.1509	.1663
17	.1478	.1543	.1509	.1132	.12	.132	.1294
18	.1097	.1307	.1372	.1132	.0943	.112	.1132
19	.132	.132	.1372	.132	.132	.1307	.132
20	.132	.1132	.1372	.1509	.0943	.132	.132
21	.132	.132	.1372	.1132	.0943	.1132	.1132
22	.1509	.1307	.12	.132	.0943	.1132	.132
23	.1132	.112	.1029	.132	.0943	.1132	.1132
24	.0754	.0943	.0934	.0857	.0943	.0716	.0943
Max	.1646	.1715	.1509	.1509	.132	.1509	.168
Min	.0566	.0566	.056	.0514	.0566	.0549	.0754
Avg	.1116	.1192	.1082	.1082	.0977	.1054	.1149

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 201 / 11KV Udagaon  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7741	.0191	.0183	.0762	1.3717	1.5424	1.3717
2	1.7193	.0191	.0183	.0762	1.3717	1.5939	1.3717
3	1.6827	.0191	.0183	.0762	1.3527	1.5939	1.3717
4	1.6827	.0191	.0183	.0762	1.3527	1.6095	1.3717
5	1.7193	.0191	.0183	.0762	1.5242	1.6787	1.5242
6	1.7193	.0762	.0183	.0762	2.1148	1.7804	1.6766
7	1.7741	.0762	.0183	.0762	2.0957	2.0178	1.9814
8	.0183	.0762	.0183	.0762	2.0386	2.2382	2.0576
9	.0191	2.3061	2.4006	.0187	2.1338	2.4006	1.9052
10	.0191	2.6452	2.5377	.0189	.0762	.0762	.0762
11	.0191	2.6749	2.5549	2.3148	.0762	.0762	.0762
12	.0191	2.7092	2.3739	2.3739	.0762	.0762	.0762
13	.0191	2.6063	2.3061	2.2634	.0762	.0762	.0762
14	.0191	2.5206	1.3245	2.572	.0762		.0762
15	.0191	2.6063	1.8861	2.4348		.0762	.0762
16	.0191	2.3491	1.7269	2.4863		.0762	.0762
17	.0187	.0183	.0183	2.5149	.0168	.0762	.0762
18	.0187	.0183	.0183	2.2862	.0187	.0762	.0762
19	.0189	.0183	.0183	.0762	.0187	.0762	.0762
20	.0189	.0183	.0183	.0762	.0187	.0762	.0762
21	.0189		.0191	.0762	.0187	.0762	.0762
22	.0191	.0183	.0191	.0762	.0181	.0762	.0762
23	.0191	.0183	.0191	.0762	.0189	.0762	.0762
24	1.8107	.0191	.0183	.0762	1.3908	1.2887	1.3717
Max	1.8107	2.7092	2.5549	2.572	2.1338	2.4006	2.0576
Min	.0183	.0183	.0183	.0187	.0168	.0762	.0762
Avg	.5911	.9074	.7252	.8479	.7844	.8146	.7113



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 202 / 11KV Estate

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0119	1.9814	1.7924	2.2862	2.0957	1.3717	1.829
2	1.9022	1.9814	1.7193	2.0576	2.0957	1.4098	1.6766
3	1.7193	1.7909	1.5181	1.9433	1.9052	1.3336	1.6766
4	1.6827	1.7147	1.4083	1.9433	1.8671	1.3527	1.6766
5	1.6461	1.7147	1.3535	1.7909	1.8671	1.4289	1.6004
6	1.6461	1.6004	1.3717	1.6766	1.3908	1.467	1.5242
7	1.7558	1.7528	1.5729	1.9052	1.6575	1.5813	1.6766
8	1.829	2.0576	1.6095		1.4098	1.5623	1.7528
9	2.3624	2.2068	2.3815	2.037	1.2193	2.0386	2.1338
10	2.5149		2.3011	2.1691	1.2193	2.0957	2.5149
11	2.6673	2.7054	2.6101	2.0911	1.2955	2.4196	2.6673
12	2.6673	2.5149	2.6482	2.3765	1.2193	2.0767	2.6673
13	2.5149	2.2257	2.1285	2.2068	1.1431	2.3434	2.6292
14	2.6673	1.9805	2.1313	2.3577	1.2193	2.3053	2.3434
15	2.5911	2.4387	2.3388	2.2032		2.2862	2.4196
16	2.4387	2.3765	2.6292	2.1691		2.4196	2.6673
17	2.5911	2.1582	2.3411	2.4958	1.2323	2.6673	2.572
18	2.5911	2.0119	2.1216	2.1719	1.2384	2.2862	2.0957
19	2.6101	1.9387	2.2862	2.3243	1.2955	2.1338	2.4768
20	2.1098	1.829	2.4143	2.2862	1.3717	2.0576	2.1338
21	2.1879	2.2314	2.2481	2.2481	1.2955	1.9814	2.4768
22	2.0576	2.0485	2.2862	2.0576	1.5242	2.1338	2.4577
23	2.0576	2.0302	2.2862	2.0576	1.2955	1.829	2.5149
24	2.1399	2.0576	1.957	1.9814	2.3624	1.3908	1.9814
Max	2.6673	2.7054	2.6482	2.4958	2.3624	2.6673	2.6673
Min	1.6461	1.6004	1.3535	1.6766	1.1431	1.3336	1.5242
Avg	2.2068	2.0586	2.0606	2.1233	1.5100	1.9155	2.1735

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 204 / 11KV Mayur

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	.9907	.9694	1.3717	1.3717	.8764	1.3717
2	1.0242	.9907	.8779	1.0669	1.3717	.8954	1.2955
3	.9877		.8596	1.0669	1.3336	.8573	1.2955
4	1.0059		.8962	1.0669	1.3336	.8573	1.2955
5	1.134		.9145	1.1431	1.2955	.8764	1.3717
6	1.2437		.9511	1.2193	1.2193	.8764	1.448
7	1.2437		1.2437	1.2193	1.1431	1.1431	1.5242
8	.9694	1.1431	1.1157		.8573	.9907	1.1431
9	1.829	1.5844	1.6787	1.5089	.8383	2.0386	
10	2.21	1.905	1.4563	1.3717	.8383	1.3908	1.8671
11	2.2862	2.3243	1.8673	1.6221	.9145	1.7909	1.829
12	2.2862	2.0957	1.7528	1.6975	.9145	1.7147	1.8671
13	1.9814	1.531	1.773	1.3908	.9145	1.3717	1.6385
14	2.0576	2.1125	1.8296	1.9805	.9145	1.848	2.0005
15	2.21	2.1338	1.9624	1.7909		1.9052	2.0386
16	2.2481	2.0767	2.0576	1.773		2.0576	1.7528
17	2.21	1.9022	1.9022	1.7528	.9145	1.829	2.1719
18	1.8861	1.829	1.8473	1.9243	.8383	1.5242	1.9814
19	1.4901	1.6644	1.3169	1.9433	.8573	1.829	1.4861
20	1.1763	1.4632	1.0974	1.3146	.8573	1.7909	1.3717
21	1.4003	1.134	1.1431	1.3146		1.3717	1.5242
22	1.1431	1.0425	1.2955	1.1812	.9335	1.2193	1.448
23	1.4098	1.1706	1.3717	1.5813	.8764	1.3717	1.4861
24	1.262	1.2574	1.0425	1.1431	1.4098	.8764	1.5242
Max	2.2862	2.3243	2.0576	1.9805	1.4098	2.0576	2.1719
Min	.9694	.9907	.8596	1.0669	.8383	.8573	1.1431
Avg	1.5754	1.5974	1.3843	1.4541	1.0451	1.3876	1.5971

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 205 / 11 KV Buvaphan AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	.0762	.0732	.0762	1.1431	1.1469	1.3717
2	1.4449	.0762	.0732	.0762	1.1241	1.1633	1.3717
3	1.3535	.0762	.0732	.0762	1.1241	1.2071	1.3717
4	1.39	.0762	.0732	.0762	1.1431	1.1797	1.3717
5	1.4815	.0762	.0732	.0762	1.3336	1.278	1.4861
6	1.5729	.0762	.0732	.0762	1.5051	1.4586	1.6004
7	1.7558	.0762	.0732	.0762	1.9243	1.7604	1.829
8	.0914		.0732		2.1148	1.933	1.9814
9		2.2969	2.2462	.112	1.9814	2.0957	2.1338
10		2.8292	2.4247	.112	.0762	.0762	.0953
11	.0762	2.431	2.4417	2.5766	.0191	.0762	.0953
12	.0762	2.4813	2.2969	2.3061	.0191	.0762	.0953
13	.0762	2.3908	2.1195	2.3061	.0191	.0762	.0953
14	.0953	2.4078	2.0287	2.2805	.0191	.0762	.0953
15	.0953	2.4417	2.1365	2.2977		.0762	.0953
16	.0953	2.3061	2.079	2.2443		.0762	.0953
17	.0747	.0732	.0732	2.3624	.0747	.1143	.0762
18	.0747	.0732	.0732	2.2672	.0934		.0762
19	.0934	.0732	.0732	.0762	.112	.0953	.0762
20	.0934	.0732	.0732	.0953	.112		.0762
21	.0754	.0732	.0762	.0762	.112		.0762
22	.0762	.0732	.0762	.0762	.1132		.0762
23	.0762	.0732	.0762	.0762	.0943	.0953	.0762
24	1.6461	.0762	.0732	.4115	1.1622	1.0978	1.2955
Max	1.7558	2.8292	2.4417	2.5766	2.1148	2.0957	2.1338
Min	.0747	.0732	.0732	.0762	.0191	.0762	.0762
Avg	.6060	.9003	.7897	.8787	.7009	.7579	.7089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 206 / Jogeswari gaonthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.6097	.7133	.6097	.6668	.6859	.6097
2	.5853	.6097	.6584	.6097	.6478	.6668	.6097
3	.5853	.6097	.6401	.6097	.6097	.6478	.6097
4	.6219	.6097	.6401	.6097	.6097	.6478	.6097
5	.6584	.6097	.6584	.6097	.6287	.6668	.6097
6	.695	.6859	.6767	.6859	.6668	.724	.6859
7	.6767	.6859	.6219	.5335	.5716	.6413	.6097
8	.7133	.6097	.567		.5525	.6979	.4572
9	.7621	.7282	.7282	.7468	.6097	.7621	
10	.7621	.7842	.7468	.8029	.6097	.7811	.724
11	.7621		.8215	.8215	.7621	.743	.7621
12	.7621	.7842	.6908	.8029	.6859	.8764	.7621
13	.6859	.5975	.6722	.7655	.6859	.724	.6478
14	.6859	.6535	.6535	.7167	.6859	.6668	.724
15	.6859	.6908	.6413	.6348		.6478	.6859
16	.6478	.6348	.6535	.5975		.6478	.6097
17	.5415	.4572	.5304	.5906	.6224	.5335	.6287
18	.5975	.5853	.567	.5906	.5975	.6097	.6287
19	.8029	.9511	1.0242	.9907	.8775	.8383	.9717
20	1.0456	1.0974	1.0608	1.0479	1.0751	1.0669	1.1622
21	1.2071	1.0974	1.105	1.1812	1.1694	1.1431	1.1812
22	1.0669	1.0608	.9145	1.0479	1.0562	.9907	1.1431
23	.7621	.8048	.8383	.9145	.9242	.9145	.8954
24	.7499	.6859	.7682	.6097	.7049	.724	.6859
Max	1.2071	1.0974	1.105	1.1812	1.1694	1.1431	1.1812
Min	.5415	.4572	.5304	.5335	.5525	.5335	.4572
Avg	.7399	.7236	.7330	.7448	.7282	.752	.7397

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 208 / 11 KV Krushna LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0914	.0953	.0914	.0953	.0953	.1334
4	.128	.0953	.128	.1143	.0953	.1524
5	.128	.1334	.128	.1334	.0953	.1524
6	.128	.1334	.128	.1334	.0953	.1524
7	.128	.1334	.128	.1334	.0953	.1334
8	.128	.1334	.128	.1524	.0953	.1334
9	.1334	.132	.1509	.1509	.0762	.1905
10	.1905	.1509	.1886	.1509	.0953	.1715
11	.1905	.1509	.1867	.1886	.1905	.1524
12	.1905	.1509	.1886	.1886	.1905	.1905
13	.1524	.1509	.1886	.1509		.1715
14	.1524	.1509	.1509	.1509	.1905	.1524
15	.1524	.1509	.1509	.1509	.1905	.1524
16	.1524	.1509	.9242	.1509	.1905	.1524
17	.1509	.1463	.1463	.1143	.1905	.1524
18	.0924	.0914		.1143	.0953	.1524
Max	.1905	.1509	.9242	.1886	.1905	.1905
Min	.0914	.0914	.0914	.0953	.0762	.1334
Avg	.1431	.1344	.2005	.1421	.1321	.1560

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 209 / KULKARNI POWER TOOLS  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2986	1.2574	1.2254	1.0288	1.1241	.8383	1.1431
2	1.2986	1.2574	1.134	1.1431	1.1241	.8192	1.0669
3	1.262	1.1431	.9328	1.0288	1.105	.8192	1.0288
4	1.2254	1.1431	.7865	1.0288	1.105	.8573	.9907
5	1.1157	1.1431	.8048	1.0288	1.086	.8192	.9907
6	1.0242	.9145	.8048	1.0288	.8573	.8573	.9907
7	1.0242	.9526	.8596	.9145	.8192	.8764	1.1431
8	1.0608	.9145	.9877	.9145	.7811	.9717	.9907
9	1.5242	1.448	1.3203	1.5466	.7621	1.2574	1.4289
10	1.6575	1.7528	1.848	1.6385	.7621	1.4098	1.8671
11	1.9052	2.0005	1.773	1.7918	.7621	1.7147	1.9624
12	2.0005	2.0195	1.9433	1.7164	.7621	1.7909	1.9052
13	1.9052	1.5466	1.4712	1.4563	.7621		1.4861
14	2.1338	1.6598	1.8861	1.7337	.7621	1.829	1.5813
15	2.0576	1.9433	1.9814	1.7718		1.8671	1.7528
16	2.0005	1.7924	1.7551	1.7337		1.7147	2.0005
17	1.7909	1.6278	1.7193	1.5242	.724	1.9052	1.848
18	1.848	1.4632	1.5364	1.3336	.8002	1.3717	1.6194
19	1.6032	1.6278	1.3717	1.3336	.8002	1.6194	1.6385
20	1.251	1.4632	1.1706	1.1622	.8192	1.5242	1.3717
21	1.251	1.4083	1.105	1.2384	.8589	1.3336	1.1431
22	1.3717	1.3535	1.2384	1.1812	.8573	1.3717	1.448
23	1.4098	1.39	1.3336	1.3527	.8192	1.4098	1.105
24	1.3352	1.3336	1.2803	1.2193	1.1431	.8573	1.2193
Max	2.1338	2.0195	1.9814	1.7918	1.1431	1.9052	2.0005
Min	1.0242	.9145	.7865	.9145	.724	.8192	.9907
Avg	1.5148	1.4398	1.3446	1.3271	.8817	1.2972	1.4051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144036 / 33/11KV SHIROL

Feeder No / Name : 210 / 11KV CH. SHAHU

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6584	.6097	.5487	.6859	.6097	.7621	.6097
2	.6219		.5121	.6097	.6097	.743	.6097
3	.5853	.6097	.4938	.6097	.5716	.724	.6097
4	.5853	.6097	.5304	.6097	.5716	.743	.6097
5	.6036	.6097	.5853	.6859	.6097	.743	.6097
6	.6036	.6859	.6767	.6859	.6668	.7621	.6097
7	.8048	.6859	.6767	.6859	.6478	.743	.6097
8	.6219	.6097	.6584	.6859	.7049	.743	.6859
9	.7621	.7922	.7167	.7922	.6859	.724	.724
10	.9145	.9526	.8676	.8764	.6859	.8192	.9145
11	.9145	1.1241	.8865	.8029	.7621	.8954	.9907
12	.9145	1.086	.8383	.9054	.7621	.8573	.9526
13	.9145	.7356	.7167	.7922	.7621		.8954
14	.8573	.8865	.8299	.9242	.7621	.9335	.9526
15	.8383	.9526	.8299	.7922		.9145	.9717
16	.9145	.9907	.9335	.9054		.9145	.9526
17	.7655	.8048	.7682	.8002	.7811	.8383	.8764
18	.8383	.7865	.7499	.743	.9145	.7621	.7621
19	.7842	.7316	.7316	.6859	.743	.6859	.6859
20	.8029	.6767		.7049	.743	.6859	.7049
21	.7468	.6584	.7049	.6097	.7621	.6097	.724
22	.6859	.695	.6859	.724	.7811	.6859	.724
23	.6859	.6584	.7621	.6668	.8002	.6097	.6478
24	.695	.6478	.6036	.6859	.6287	.7811	.6859
Max	.9145	1.1241	.9335	.9242	.9145	.9335	.9907
Min	.5853	.6097	.4938	.6097	.5716	.6097	.6097
Avg	.7550	.7652	.7090	.7362	.7075	.7687	.7550

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 201 / 11KV LIS

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.8769	.0953	.0953	.1524	2.572	2.2862	
2	2.8578	.0953	.0953	.1334	2.6292	2.2481	
3	2.8578	.0953	.1143	.1334	2.6292	2.3243	
4	2.8959	.0953	.1143	.1524	2.6673	2.6673	
5	2.9912	.1143	.1334	.1524	2.7054	2.8197	
6	3.1626	.1334	.1524	.1715	3.1055	3.1245	
7	2.2672	.1524	.1334	.1524	3.6008	3.5437	
8	.1143	.1143	.1524	.1524	3.4865	3.6199	3.3341
9	.1143	3.9819	4.1533	.1334		3.5437	2.3243
10	.0953	4.2676		.1524		.0953	.0953
11	.0953	4.3248	4.1724	4.1343		.1334	.1143
12	.1143	2.3624	4.0771	3.9819		.1334	.1334
13	.0762	3.4103	4.0962	4.1724		.0953	.1143
14	.0953	3.4294	4.0009	4.02		.1334	
15	.1143	3.6199		4.039		.1143	
16	.0953	3.3341	2.9912	3.9628		.1143	
17	.0762	.0953	.1334	3.8866	.0762		.1334
18	.0953		.1143	2.9531	.1143		.1334
19	.0953	.1524	.1715	.1905	.1715		.1334
20	.1334	.1524	.1715	.1715	.1715		.1524
21	.1524	.1524	.1715	.1715	.1905		.1524
22	.1334	.1334	.1524	.1715	.1524		.1524
23	.1334	.1143	.1524	.1524	.1524		.1334
24	2.8769	.1143	.0953	.1524	2.4768	2.2862	
Max	3.1626	4.3248	4.1724	4.1724	3.6008	3.6199	3.3341
Min	.0762	.0953	.0953	.1334	.0762	.0953	.0953
Avg	1.0217	1.3278	1.1656	1.4019	1.6813	1.7225	.5467



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 202 / 11KV Kothali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0762	1.7147	1.7147	1.5623	.0762	.0762	
2	.0762	1.7147	1.6766	1.5623	.0762	.0762	
3	.0762	1.6575	1.6766	1.5242	.0762	.0762	
4	.0762	1.6194	1.6385	1.5242	.0762	.0762	
5	.0953	1.6194	1.6575	1.5051	.0953	.0953	
6	.0953	1.6956	1.6575	1.5813	.1143	.0953	
7	.0762	1.7528	1.6766	1.6194	.0953	.0762	
8	.0572	.0762	.0762	.0572	.0762	.0762	.0572
9	2.7625	.0953	.0762	.0762		.0953	.0762
10	2.8769	.0572	.0762	.0572		.0953	.0762
11	2.934	.0762	.0762	.0953		2.7816	3.1436
12	3.0102	.0953		.0762		2.934	2.8197
13	2.934	.0762	.0762	.0762		2.8578	2.8959
14	2.934	.0762	.0762	.0762		2.7625	
15	2.7435	.0762	.0762	.0762		2.7816	
16	2.5911	.0762	.0762	.0762		2.7054	
17	.0762	.0572	.0762	.0762	2.5149		2.4958
18	.0572		.0572	.0572	2.4387		2.4768
19	.0762	.0953	.0762	.0762	.0762		.0762
20	.0762	.0953	.0762	.0762	.0762		.0953
21	.0762	.0953	.0953	.0953	.0762		.0953
22	1.9624	1.7909	1.6956	.0953	.0953		.0953
23	1.829	1.7528	1.6004	.0762	.0762		.0762
24	.0762	1.7909	1.7337	1.6385	.0762	.0762	
Max	3.0102	1.7909	1.7337	1.6385	2.5149	2.934	3.1436
Min	.0572	.0572	.0572	.0572	.0762	.0762	.0572
Avg	1.1519	.7894	.7704	.5724	.3822	1.0434	1.1138

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 203 / 11KV Umalwad Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1622	.0191	.0191	.0191	1.1431	.9526	
2	1.1622	.0191	.0191	.0191	1.105	.9717	
3	1.1431	.0191	.0191	.0191	1.105	.9526	
4	1.1241	.0191	.0191	.0191	1.086	.9907	
5	1.1241	.0191	.0191	.0191	1.1241	1.0669	
6	1.2955	.0191	.0191	.0191	1.2955	1.1431	
7	1.3336	.0191	.0191	.0191	1.3527	1.2955	
8	.0191	.0191	.0191	.0191	1.448	1.2955	1.3717
9	.0191	1.6766	1.6004	.0191		1.3336	1.2193
10	.0191	1.8861	1.6956	.0191		.0191	.0191
11	.0191	1.9433	1.7909	1.829		.0191	.0191
12	.0191	1.9052	1.8861	1.8861		.0191	.0191
13	.0191	1.8671	1.848	1.848		.0191	.0191
14	.0191	1.8861	1.8099	1.7718		.0191	
15	.0191	1.8671	1.7147	1.7337		.0191	
16	.0191	1.829	1.6004	1.7147		.0191	
17	.0191	.0191	.0191	1.6575	.0191		.0191
18	.0191		.0191	1.2003	.0191		.0191
19	.0191	.0191	.0191	.0191	.0191		.0191
20	.0191	.0191	.0191	.0191	.0191		.0191
21	.0191	.0191	.0191	.0191	.0191		.0191
22	.0191	.0191	.0191	.0191	.0191		.0191
23	.0191	.0191	.0191	.0191	.0191		.0191
24	1.2003	.0191	.0191	.0191	1.1431	.9907	
Max	1.3336	1.9433	1.8861	1.8861	1.448	1.3336	1.3717
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.4104	.6586	.5938	.5811	.6835	.6545	.2155

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 204 / 11KV Danoli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	2.915	3.2388	2.934	.1524	.1524	
2	.1715	2.8959	3.2007	2.8959	.1334	.1715	
3	.1715	2.8578	3.2388	2.8959	.1334	.1905	
4	.1905	2.8387	3.2769	2.8578	.1334	.2096	
5	.1905	2.8387	3.3532	2.8197	.1905	.2096	
6	.2286	3.2007	3.4294	3.2769	.2286	.2286	
7	.2096	3.6199	1.467	3.6961	.1905	.2286	
8	.1905	.1905	.1524	.1905	.1905	.1715	.1905
9	4.1914	.1715	.1524	.1715		.1524	.1524
10	4.4582	.1715	.1524	.1905		.1905	.1715
11	4.3439	.1715	.1524	.1715		4.2676	4.5534
12	4.1533	.1715	.1524	.1524		4.8392	4.4391
13	3.4294	.1715	.1524	.1524		4.763	4.4391
14	3.7913	.1715	.1524	.1334		4.5344	
15	3.8295	.1524	.1715	.1524		4.3629	
16	3.5627	.1524	.0191	.1524		4.2295	
17	.1524	.1334	.1715	.1524	4.2486		4.1343
18	.2096		.1524	.1715	4.2867		3.8676
19	.2096	.2286	.1905	.2096	.2096		.2096
20	.2477	.2096	.2096	.2096	.2286		.2477
21	.2477	.2096	.2286	.2286	.2286		.2477
22	3.0674	3.4294	3.3722	.2096	.2096		.2286
23	3.0483	3.3341	2.8197	.1905	.1905		.1905
24	.1715	2.9912	3.2579	3.0293	.1715	.1524	
Max	4.4582	3.6199	3.4294	3.6961	4.2867	4.8392	4.5534
Min	.1524	.1334	.0191	.1334	.1334	.1524	.1524
Avg	1.6933	1.4446	1.3694	1.1352	.6954	1.7091	1.7748

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 205 / 11KV Waranamai

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	2.6673	2.7625	2.6673	.0381	.0381	
2	.0381	2.6673	2.7435	2.6673	.0381	.0381	
3	.0572	2.6482	2.7816	2.6101	.0381	.0381	
4	.0572	2.6482	2.7625	2.6101	.0381	.0572	
5	.0572	2.6101	2.7625	2.6101	.0381	.0572	
6	.0381	2.7625	2.7625	2.6863	.0381	.0572	
7	.0572	2.7816	2.6673	2.8197	.0381	.0381	
8	.0381	.0572	.0572	.0381	.0381	.0572	.0572
9	3.0102	.0381	.0381	.0381		.0572	.0381
10	3.3722	.0381	.0381	.0381		.0572	.0572
11	3.3913	.0381	.0381	.0381		3.4294	3.3913
12	3.4103	.0381	.0381	.0381		3.4865	3.4294
13	3.0674	.0381	.0381	.0381		3.5246	3.296
14	3.5437	.0381	.0381	.0381		3.5818	
15	3.4294	.0381	.0381	.0381		3.3722	
16	2.7054	.0381	.0381	.0381		3.2388	
17	.0381	.0381	.0381	.0381	3.1055		3.0864
18	.0381		.0381	.0381	3.1245		3.1055
19	.0381	.0381	.0381	.0381	.0381		.0572
20	.0381	.0381	.0381	.0381	.0572		.0572
21	.0381	.0381	.0381	.0381	.0572		.0572
22	2.4006	2.6673	2.6673	.0381	.0572		.0953
23	2.7054	2.7625	2.7816	.0381	.0381		.0953
24	.0381	2.6863	2.8006	2.7625	.0381	.0381	
Max	3.5437	2.7816	2.8006	2.8197	3.1245	3.5818	3.4294
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	1.3186	1.1920	1.1685	.9185	.4263	1.2451	1.2941

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 206 / 11KV Danoli Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5525	.5716	.4572	.5716	.5335	
2	.5335	.5335	.5335	.4572	.4954	.5335	
3	.5335	.5335	.5525	.4572	.4382	.5716	
4	.5716	.5525	.5716	.4763	.4382	.5716	
5	.6097	.5906	.6478	.4954	.4763	.6097	
6	.6668	.6287	.6859	.5525	.6097		
7	.4763	.6097	.5716	.4763	.4191	.5716	
8	.4001	.5716	.5335	.4954	.362	.5716	.5335
9	.5525	.5716	.5144	.4572		.5335	.5335
10	.4572	.5525	.5335	.4954		.4954	
11	.4572	.5716	.5335	.4954		.5525	
12	.4763	.5716	.5525	.5335		.5716	.5716
13	.4191	.5716	.5335	.5335		.5906	.5716
14	.4382	.5716	.5335	.5335		.5906	.4954
15	.4572	.5716	.5716	.5335		.5906	.5716
16	.4572	.6097	.5716	.5144		.5906	.5716
17	.4572	.6097	.5525	.5335	.3429		.5716
18	.4954		.6097	.4763	.381		.6287
19	.5716	.6859	.724	.5906	.5335		.6478
20	.6287	.7621	.743	.724	.5716		.7621
21	.6287	.7621	.7049	.743	.5716		.6859
22	.5716	.6859	.6478	.724	.6097		.6478
23	.6097	.6668	.5525	.6668	.5716		.5335
24	.5906	.6287	.5906	.4954	.5906	.5716	
Max	.6668	.7621	.743	.743	.6097	.6097	.7621
Min	.4001	.5335	.5144	.4572	.3429	.4954	.4954
Avg	.5247	.6072	.5890	.5382	.4989	.5656	.5947

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144042 / 33/11 KV Kothali

Feeder No / Name : 207 / 11KV Umalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5525	.5525	.5335	.4954	.5335	.5335	
2	.5525	.5335	.5335	.4954	.5144	.5335	
3	.5525	.5335	.5716	.4954	.5144	.5525	
4	.5906	.5335	.6097	.5335	.4763	.5716	
5	.6478	.6478	.6478	.5716	.5335	.5906	
6	.7621	.724	.6859	.5906	.6859	.6097	
7	.6478	.6097	.5716	.5335	.5906	.5335	
8	.5716	.5335	.5716	.5906	.4954	.4572	.4954
9	.5144	.4954	.5144	.4954		.4191	.381
10	.4954	.4763	.4954	.5144		.4191	.4191
11	.4954	.4191	.4954	.5335		.4191	.4572
12	.4954	.5335	.4954	.5144		.4382	.4572
13	.2096	.5335	.5144	.5335		.4572	.4954
14	.5335	.5335	.4954	.5716		.5144	
15	.4954	.5716	.5906	.5335		.4954	
16	.4763	.5335	.5144	.5716		.4954	
17	.5335	.5335	.4954	.5335	.4572		.4763
18	.5335		.5525	.2286	.4954		.4954
19	.6859	.8383	.724	.7621	.6859		.6478
20	.7811	.8002	.8383	.8573	.8002		.7621
21	.8002	.8002	.8002	.8002	.7621		.724
22	.7621	.7621	.6859	.743	.724		.7049
23	.6478	.6668	.5906	.6859	.6859		.6287
24	.5906	.6097	.5716	.5335	.5716	.5716	
Max	.8002	.8383	.8383	.8573	.8002	.6097	.7621
Min	.2096	.4191	.4954	.2286	.4572	.4191	.381
Avg	.5803	.5989	.5875	.5716	.5954	.5066	.5496

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 201 / 11KV RAILWAY

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8316	.7888	1.6655	.8402	.7865	.8215	.8316
2	.7577	.7712	1.701	.7842	.7682	.7842	.7577
3	.7207	.7537	1.5947	.7468	.7499	.7468	.7207
4	.6653	.7011	1.5061	.7468	.7499	.7468	.7392
5	.7023	.7011	1.4883	.7842	.7682	.7842	.7577
6	.7762	.7265	1.5043	.7468	.7682	.8402	.7947
7	.8501	.7964	1.5729	.7842	.7865	.9335	.924
8	.8316	.8048	1.531	.8029	.8048	.8029	.7947
9	.8215	.8686	1.5497	.7865	.8029	.924	.9145
10	.9896	1.0164	1.8111	.8596	.9149	.961	.9694
11	1.0829	1.0903	1.0456	.9694	.9896	1.0534	1.0059
12	1.0456	1.0903	1.0269	.9877		1.1088	1.0608
13	1.0082	.9877	1.0642	.9328		1.0719	1.0974
14	1.0269	1.0242	1.0642	.9145	.3361	1.0719	1.1157
15	1.0269	1.0059	1.0456	.9511	.3734	1.1088	1.0974
16	1.0456	1.0059	1.0456	.9877	.4108	1.1088	1.0974
17	.9896	1.0136	1.0829	.9694	.4668	1.1273	1.1203
18	.9896	1.0425	1.1203	.9328	.4668	1.1458	1.1576
19	1.1949	1.2752	1.251	1.134	1.4563	1.2936	
20	1.2323	1.2803	1.2323	1.134	1.4003	1.3121	1.3817
21	1.1949	1.1706	1.1203	1.0791	1.307	1.1643	1.419
22	1.1016	2.268	1.0456	1.0242	1.1763	1.0903	1.3443
23	1.0456	2.0119	.9335		1.0456	1.0164	1.1203
24	.8871	.8063	1.7193	.8775	.8413	.8962	.8686
Max	1.2323	2.268	1.8111	1.134	1.4563	1.3121	1.419
Min	.6653	.7011	.9335	.7468	.3361	.7468	.7207
Avg	.9508	1.0417	1.3217	.9033	.8259	.9964	1.0039

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 202 / 11KV PINGARA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7282	.6836	.691	.7468	.7316	.7468	.7468
2	.6722	.6556	.6733	.7282	.7133	.7095	.6908
3	.5975	.6379	.6556	.7095	.695	.6908	.6535
4	.5788	.631	.6556	.7095	.695	.6722	.6722
5	.6535	.6485	.6733	.7095	.7133	.7095	.6722
6	.7655	.6556	.7087	.6908	.7316	.7655	.7468
7	.7655	.724	.7499	.7842	.7865	.8029	.8029
8	.8215	.8048	.8775	.8402	.8596	.8029	.8215
9	.7842	.8029	.7468	.695	.7282	.7655	.823
10	.7842	.8215	.7468	.6767	.7095	.8589	.8413
11	.7468	.7842	.8029	.6401		.8775	.8596
12	.7095	.6838	.7282	.6401		.8029	.7499
13	.7468	.7133	.7468	.6036		.8402	.7865
14	.7282	.7095	.6535	.6036			.8048
15	.7655	.7316	.6908	.5853		.8775	.823
16	.7095	.695	.6722	.5853		.7842	.7865
17	.7842	.6767	.7468	.6036		.7655	.8029
18	.7468	.7468	.8215	.6401	.8215	.7655	.8029
19	.8402	.8775	.9522	.9145	1.1203	.9896	.9896
20	.9709	.9896	.9335	.9328	1.0456	1.0456	1.0642
21	.9709	.8962	.9149	.9145	1.0082	1.0082	1.0082
22	.9522	.9328	.8962	.9145	.9896	1.0082	.9335
23	.8589	.8596	.8402		.8589	.9335	.8402
24	.7842	.7186	.7164	.7842	.7316	.7468	.8029
Max	.9709	.9896	.9522	.9328	1.1203	1.0456	1.0642
Min	.5788	.631	.6535	.5853	.695	.6722	.6535
Avg	.7694	.7534	.7623	.7240	.8200	.8248	.8136



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030]

BU 1171

Substation No/ Name :- 144074 / 33/11 KV jaysingpur

Feeder No / Name : 203 / 11KV SHAHUNAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6283	.631	.6024	.6535	.6584	.6161	.6283
2	.5914	.6024	.5847	.6161	.6401	.5975	.5914
3	.5359	.5959	.5847	.5975	.6219	.5975	.5729
4	.5175	.6135	.6024	.5975	.6401	.5975	.5914
5	.5359	.6201	.6201	.6161	.6584	.6161	.6099
6	.6099	.5959	.6556	.6161	.6767	.6535	.7023
7	.6838	.6697	.695	.6161	.6767	.6722	.6653
8	.6283	.6219	.5788	.5975	.6036	.6535	.6099
9	.5975	.5544	.5228	.4938	.4854	.5359	.567
10	.5788	.5359	.5041	.5304	.4668	.462	.5121
11	.5601	.5359	.5228	.5487	.4854	.4805	.4755
12	.5415	.567	.4854	.5853	.5228	.462	.5304
13	.5601	.5487	.5228	.567		.499	.5487
14	.5788	.567	.5788	.567		.5175	.567
15	.5975	.5853	.5601	.5853		.5544	.5853
16	.5788	.5853	.5601	.567	.6535	.5544	.5487
17	.5041	.5853	.5975	.5853	.6348	.5914	.6535
18	.6348	.6535	.6722	.6036	.7095	.7023	.6908
19	.8215	.7842	.8402	.7682	.8029	.8501	.8589
20	.8962	.8775	.8402	.8596	.8962	.9055	.9896
21	.8775	.8413	.8131	.823	.9149	.924	.8775
22	.8962	.8413	.8215	.823	.8962	.8871	.8402
23	.8029	.8048	.7468		.7468	.7947	.7468
24	.6838	.6485	.6447	.6722	.6401	.6535	.6838
Max	.8962	.8775	.8402	.8596	.9149	.924	.9896
Min	.5041	.5359	.4854	.4938	.4668	.462	.4755
Avg	.6434	.6444	.6315	.6300	.6682	.6408	.6520

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144123 / 33/11kV Kondigre

Feeder No / Name : 201 / 11kv Datta Mandir VG  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.3506
Max	.3506
Min	.3506
Avg	.3506

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144123 / 33/11kV Kondigre

Feeder No / Name : 202 / 11kV Haroli AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144123 / 33/11kV Kondigre

Feeder No / Name : 204 / 11 KV Chipari AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	1.0059
Max	1.0059
Min	1.0059
Avg	1.0059

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 144123 / 33/11kV Kondigre

Feeder No / Name : 205 / 11 kv Kondigre Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.8718
Max	.8718
Min	.8718
Avg	.8718

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 201 / Jambhali gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 205 / 11KV WATER WORKS  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	01-APR-18
HR	Load (MW)
24	.0905
Max	.0905
Min	.0905
Avg	.0905

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 206 / 11KV SIDHESHWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.362
Max	.362
Min	.362
Avg	.362



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 209 / Kondigre Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.8383
Max	.8383
Min	.8383
Avg	.8383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 210 / Chipri (Hanuman)AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	1.4937
Max	1.4937
Min	1.4937
Avg	1.4937

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 211 / Venkateshwara Express ind  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	.2263
Max	.2263
Min	.2263
Avg	.2263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 407 / 33KV SUPERCRAFT  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.086
Max	1.086
Min	1.086
Avg	1.086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 408 / Sidhivinayak  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

JAYSINGPUR[030] BU 1171

Substation No/ Name :- 146005 / 110/33KV JSP

Feeder No / Name : 409 / 33Kv Industrial  
Feeder KV- 33 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	6.0928
Max	6.0928
Min	6.0928
Avg	6.0928

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 201 / 11KV Takawade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	1.5748	1.2071	1.0364	.0354	.0305	.0171
2	.032	1.3443	1.2071	1.0364	.0362	.0305	.0171
3	.032	1.3923	1.1736	1.0364	.0366	.0305	.0171
4	.032	1.3443	1.1736	1.0364	.0366	.0305	.0171
5	.032	1.3443	1.1736	1.0688	.0358	.0305	.0171
6	.032	1.3443	1.2742	1.1984	.0366	.0305	.0171
7	.032	1.3443	1.4419	1.4575	.032	.0305	.0198
8	.032	.0366	.0335	1.4089	.032	.0305	.0198
9	1.8724	.032	.0335	.0133	.0362	.0305	.0171
10	2.079	.0133	.032	.0305	.0297	.0366	.0305
11	2.1795	.0061	.032	.0305	2.0567	2.3045	2.2045
12	2.079	.0057	.032	.0305	2.2466	1.9524	
13	2.079	.0133	.032	.0305	2.1214	2.1879	2.1879
14	2.0119	.0133	.032	.0305	2.0729	2.1925	2.1216
15	2.0119	.0133	.032	.0305	2.1538	2.2611	2.0885
16	1.8442	.0057	.032	.0305	2.0567	2.2085	1.9204
17	.0328	.0133	.0343	.032	2.0885	2.1376	1.8404
18	.032	.0335	.0133	.032	1.989	2.0405	1.6484
19	.032	.0335	.02	.032	.0305	.0198	.032
20	.032	.0335	.0297	.032	.0305	.0297	.032
21	.032	.0335	.0297	.0324	.0305	.0297	.032
22	1.5684	1.2407	.0257	.032	.0305	.0257	.032
23	1.3443	1.2407	.9717	.032	.0305	.0257	.032
24	.0332	1.3443	1.2071	1.1012	.0366	.0305	.0257
Max	2.1795	1.5748	1.4419	1.4575	2.2466	2.3045	2.2045
Min	.032	.0057	.0133	.0133	.0297	.0198	.0171
Avg	.8133	.5750	.4697	.4513	.7217	.7399	.6255

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 202 / Shirdhon, Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0486	.0655	.1677	.1943	1.0159	1.094	.9393
2	1.0322	.0492	.1677	.1943	1.0486	1.094	.9231
3	1.0322	.0366	.1677	.1943	1.2437	1.094	.9231
4	1.0322	.0328	.1677	.1943	1.1469	1.1271	.9231
5	1.0159	.0328	.1677	.1943	1.2209	1.1271	.9393
6	1.0159	.0366	.1677	.1943	1.1797	1.1603	.9878
7	1.0159	.0328	.1677	.1943	1.2209	1.1768	1.0688
8	.0328	.0362	.1006	.1781	1.4118	1.1934	1.1012
9	.0328	1.5074	1.8442	.1943	1.2944	1.2597	1.1498
10		1.7328	1.8842	.0457	.02	.0549	.0457
11	.1006	1.749	1.7604	1.8896		.0328	.0305
12	.0671	1.7976	1.7695	1.8896		.0492	.0469
13	.0671	1.8623	1.7695	1.8233		.0339	.0305
14	.1006	1.8461	2.0119	1.8233	.0495	.0509	.0469
15	.1006	1.8785	1.7204	1.757	.0495	.0549	.0469
16	.1006	1.7976	1.704	1.7901	.0343	.0509	.0328
17	.128	.1677	.0495	1.7204	.0457	.08	.0328
18	.0328	.1677	.1372	1.6221	.0457	.1143	.0492
19	.0328	.2012	.1372	.0328	.0457	.1	.0328
20	.032	.2012	.1524	.0328	.0305	.1143	.0328
21	.0328	.1677	.1981	.0328	.0305	.1097	.0328
22	.0366	.1677	.1829	.0328	.0305	.096	.0328
23	.0328	.1677	.2267	.0366	.0305	.0533	.0328
24	1.0486	.0633	.1677	.1943	.9831	1.0608	.9069
Max	1.0486	1.8785	2.0119	1.8896	1.4118	1.2597	1.1498
Min	.032	.0328	.0495	.0328	.02	.0328	.0305
Avg	.3988	.6583	.7079	.6857	.5799	.5159	.4329



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 204 / 11KV Shiradhon Takawade  
Vlg Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5853	.5898	.57	.724	.6516	.6219	.6878
2	.5853	.6379	.57	.6154	.6584	.6219	.6733
3	.5373	.5853	.57	.5668	.5792	.5487	.6379
4	.5487	.5853	.57	.6516	.5853	.5487	.631
5	.4961	.6219	.57	.6201	.6219	.6219	.6379
6	.6089	.6219	.6371	.5847	.6154	.6584	.6733
7	.6767	.6201	.57	.5609	.6036	.6584	.5973
8	.6584	.6584	.5365	.4908	.567	.6219	.5493
9	.6516	.5853	.57	.5959	.6036	.6584	.6379
10	.6036	.6661	.7316	.5068	.631	.6036	.6584
11	.6706	.7011	.7316	.543	.6024	.695	.6584
12	.5365	.691	.6516	.5487	.1006	.7316	.695
13		.5784	.567	.5487	.1578	.6516	.6584
14	.7042	.631	.7095	.5853	.1578	.6584	.6584
15	.7042	.691	.7316	.5853	.1578	.7316	.6584
16	.7377	.6485	.7087	.5853	.1402	.7095	.6733
17	.7087	.631	.4031	.6055	.5121	.7011	.7164
18	.7545	.503	.7186	.6516	.6219	.6661	.8048
19	.9511	.7377	.9214	.7316	.8413	.8063	.9511
20	.8688	.7377	.9114	.7796	.9145	.9214	.8779
21	.8779	.7712	.8413	.7964	.8779	.8505	.8779
22	.7964	.6706	.8859	.7964	.8413	.8326	.8779
23	.724	.6036	.7796	.7316	.6584	.8413	.7316
24	.6626	.6554	.6036	.7343	.695	.6219	.7011
Max	.9511	.7712	.9214	.7964	.9145	.9214	.9511
Min	.4961	.503	.4031	.4908	.1006	.5487	.5493
Avg	.6804	.6426	.6692	.6308	.5582	.6909	.7052

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 205 / JAMBHALI-TAKWADE LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.394	.3311	.4024	.443	.0305	.2103
4	.3982	.4024	.4024	.4207	.0305	.3155
5	.4075	.4207	.4024	.4207	.0305	.2629
6	.4075	.4207	.4024	.443	.0305	.3155
7	.4481	.439	.4359	.4252	.0305	.3155
8	.439	.439	.4024	.4207	.0305	.3155
9	.4298	.4252	.4024	.4252	.0305	.3155
10	.4024	.4207	.4344	.4344	.0328	.4163
11	.4359	.4207	.3658	.4344	.0366	.3475
12	.4024	.443	.4668	.4163	.0543	.3658
13	.4024	.4207	.4252	.4163	.0486	.362
14	.4024	.4207	.4252	.439	.0549	.3658
15	.4024	.4382	.4252	.439	.0366	.3658
16	.4024	.4207	.439	.439	.0366	.3292
17	.4252	.4382	.3258	.439	.0171	.3292
18	.2012	.0671	.2454	.0549	.0095	.0366
Max	.4481	.443	.4668	.443	.0549	.4163
Min	.2012	.0671	.2454	.0549	.0095	.0366
Avg	.4001	.3980	.4002	.4069	.0338	.3106

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144043 / 33/11 KV SHIRDHON

Feeder No / Name : 206 / JAYHIND-JAWAHAR LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1635	.1635	.2683	.2012	.1829	.2515
4	.1614	.1781	.2683	.285	.1829	.285
5	.208	.2347	.2683	.285	.1829	.285
6	.2378	.2591	.2683	.285	.2134	.285
7	.3109	.2591	.2683	.285	.2134	.285
8	.3561	.2896	.2683	.285	.2286	.3353
9	.3582	.2824	.3353	.3353	.3048	.3353
10	.3688	.3185	.3475	.3125	.3475	.3125
11	.3688	.3353	.3439	.3125	.3475	.362
12	.3688	.3429	.3222	.3125	.3475	.3048
13	.3688	.3521	.3475	.3125	.3475	.3048
14	.3688	.3353	.3366	.3048	.3475	.3048
15	.3688	.3521	.3475	.3125	.3658	.3048
16	.3353	.3353	.3544	.3048	.362	.3048
17	.3721	.3353	.3018	.362	.3353	.3109
18	.3544	.3353	.285	.3658	.3353	.3658
Max	.3721	.3521	.3544	.3658	.3658	.3658
Min	.1614	.1635	.2683	.2012	.1829	.2515
Avg	.3169	.2943	.3082	.3038	.2903	.3086

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 201 / 11 Kv Shridatt Feeder AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5181	.0324		.0486	1.9418	1.4918	1.387
2	1.4548	.0324	.0474	.0486	1.9982	1.4918	1.3672
3	1.4232	.0324	.0474	.0486	1.9845	1.4918	1.382
4	1.3916	.0324	.0633	.0486	2.0058	1.4918	1.4327
5	1.4232	.0324	.0633	.0486	2.0271	1.5249	1.4661
6	1.3599	.0324	.0633	.048	2.0302	1.5912	1.4815
7	1.3916	.0648	.0633	.0486	2.2546	1.6907	1.7187
8	.0474	.0486	.0633	.0486	2.2405	1.757	1.8298
9	.0474	2.4777	2.8306	.0486	2.2257	1.7736	1.9616
10	.0474	2.8664	2.9492	.0486	.0486	.0497	.0492
11	.0486	2.8938	3.0445	2.9473	.0486	.0693	.0486
12	.0486	2.7989	3.0476	3.12	.0497	.0701	.0492
13	.0486	2.6566	2.9504	3.1361	.0497	.0709	.0486
14	.0486	2.6566	2.8182	3.1161	.0497	.0716	.0492
15	.0486	2.6566	2.753	2.9321	.0497	.0724	.0486
16	.0486	2.6408	2.5911	3.1276	.0497	.0732	.0486
17	.0648	.0474		2.9199	.0497	.0739	.0328
18	.0486	.0474		2.8006	.0497	.0747	.0648
19	.0486	.0474		.0754	.0332	.0566	.0648
20	.0486	.0633	.0648	.0686	.0332	.0514	.0648
21	.0486	.0474	.064	.0693	.0332	.0347	.064
22	.0486	.0474	.0648	.0701	.0332	.0351	.0486
23	.0324	.0633	.0648	.0709	.0332	.0354	.0486
24	1.5181	.0324	.0474	.0655	1.8519	1.3923	1.3203
Max	1.5181	2.8938	3.0476	3.1361	2.2546	1.7736	1.9616
Min	.0324	.0324	.0474	.048	.0332	.0347	.0328
Avg	.5106	.9313	1.1851	1.0419	.8821	.6890	.6699

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 202 / 11 kv Bastwad feeder AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7901	.0335	.0332	.0335	2.0978	2.0348	1.8551
2	1.8233	.0335	.0332	.0335	2.1209	2.0348	1.8755
3	1.8233	.0335	.0332	.0335	2.1262	2.0348	1.8959
4	1.8067	.0335	.0332	.0335	2.1849	2.0687	1.9521
5	1.8233	.0335	.0332	.0335	2.2624	2.1026	2.0452
6	1.8399	.0335	.0332	.0335	2.396		2.1033
7	1.8067	.0335	.0332	.0335	2.5873	2.1534	2.4394
8	.0332	.0335	.0332	.0335	2.6513	2.2043	2.5206
9	.0332	2.5316	2.8344	.0335	2.584	2.2721	2.5463
10	.0332	2.8837	2.6322	.0343	.0335	.0339	.0328
11	.0335	2.9007	3.2526	3.1554		.0347	.0328
12	.0335	2.9835	3.0514	3.1901		.0351	.0335
13	.0335	2.9835	3.0312	3.1361		.0354	.0328
14	.0335	2.8675	2.9835	3.2057		.0358	.0492
15	.0335	2.9007	2.9492	3.1312		.0362	.0335
16	.0335	2.9338	2.9165	3.1459	.0335	.0366	.0328
17	.0335	.0332	.0335	3.0678	.0335	.037	.0328
18	.0335	.0332	.0335	2.894	.0335	.0373	.0328
19	.0335	.0332	.0328	.0377	.0335	.0377	.0328
20	.0335	.0332	.0328	.0343	.0335	.0343	.0328
21	.0335	.0332	.0328	.0347	.0335	.0347	.0328
22	.0335	.0332	.0335		.0335	.0351	.0328
23	.0335	.0332	.0335	.0354	.0335	.0354	.0335
24	1.757	.0335	.0332	.0335	1.9376	2.0008	1.8861
Max	1.8399	2.9835	3.2526	3.2057	2.6513	2.2721	2.5463
Min	.0332	.0332	.0328	.0335	.0335	.0339	.0328
Avg	.6252	.9800	1.0076	1.1060	1.2237	.8437	.8999

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 203 / HERWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5788	.679	.7095	.6602	.6415	.6979	.6241
2	.6161	.6413	.7282	.6413	.5609	.6602	.5959
3	.6348	.6413	.7282	.6413	.567	.6602	.567
4	.6722	.679		.6602	.5731	.6979	.6089
5	.7095	.7167	.7655	.679	.6516	.7167	.6516
6	.7842	.811	.7655	.7356	.7682	.811	.8048
7	.7468	.7545	.6908	.7545	.7207	.811	.7392
8	.7655	.7167	.6722	.679	.6161	.6979	.7468
9	.6908	.679	.6535	.679	.6224	.6224	.6602
10	.7282	.6413	.7167	.5487	.6224	.7167	.6979
11	.6979	.5975	.7356	.5721	.5847	.6241	.679
12	.6413	.6161	.6602	.5959	.6224	.6661	.7167
13	.679	.6908	.6602	.5138	.6224	.691	.7167
14	.7167	.6535	.6602	.5194	.6413	.6268	.679
15	.6979	.7282	.7167	.7059	.6602	.6878	.7167
16	.7545	.7282	.7545	.7133	.6413	.695	.7356
17	.7356	.6908	.7167	.6838	.679	.7023	.7167
18	.7167	.6161	.7167	.7095	.6602	.7468	.6602
19	.7545	.7655	.7545	.7167	.679	.7167	.7356
20	.7922	.7655	.7356	.6516	.7356	.6859	.7167
21	.6979	.7842	.679	.6415	.6979	.6762	.679
22	.8299	.7842	.7167	.6661	.6979	.6836	.7167
23	.7356	.7468	.679	.7265	.7733	.7442	.679
24	.5788	.6979	.7095	.679	.6344	.7167	.6001
Max	.8299	.811	.7655	.7545	.7733	.811	.8048
Min	.5788	.5975	.6535	.5138	.5609	.6224	.567
Avg	.7065	.7010	.7098	.6572	.6531	.6981	.6852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 204 / 11 kv water works feeder  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE WATER SUPPLY AND  
UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0686	.1006	.0857	.104	.0848	.0867
2	.0838	.0686	.1006	.0857	.1052	.0848	.0876
3	.0838	.0857	.1006	.0857	.0886	.0848	.0886
4	.1006	.0857	.1006	.0857	.0895	.0848	.0895
5	.1006	.0857	.1006	.0857	.0724	.1017	.0905
6	.1006	.0857	.1006	.0857	.0732	.1017	.1097
7	.0671	.1029	.0671	.0857	.1109	.1017	.0739
8	.1006	.1029	.1006	.0857	.112	.1017	.112
9	.0671	.0686	.0671	.0857	.0943	.1017	.0754
10	.0671	.0686	.0857	.0857	.1029	.1017	.1029
11	.0686	.0671	.0857	.0693	.1029	.052	.0857
12	.0686	.1006	.0857	.0876	.1029	.0526	.0857
13	.0686	.1006	.0514	.0886	.0857	.0532	.0857
14	.0686	.1006	.0857	.0895	.0857	.1075	.0857
15	.0686	.1006	.0857	.0905	.1017	.0905	.0857
16	.0857	.0671	.0857	.1097	.0678	.0914	.0857
17	.0857	.0671	.0857	.0739	.0848	.1109	.0857
18	.0857	.0671	.0857	.112	.0848	.0934	.0857
19	.0857	.0671	.0857	.1132	.0509	.0943	.0857
20	.0857	.1006	.0857	.1029	.017	.0857	.0857
21	.0686	.0838	.0857	.0867	.017	.0867	.0857
22	.0686	.0838	.0857	.0876	.017	.0876	.0857
23	.0857	.0671	.0857	.0709	.0339	.0886	.0857
24	.0838	.0686	.1006	.3048	.0514	.0848	.0857
Max	.1006	.1029	.1006	.3048	.112	.1109	.112
Min	.0671	.0671	.0514	.0693	.017	.052	.0739
Avg	.0806	.0819	.0877	.0977	.0774	.0887	.0882

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 205 / 11 Kv Herwad Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8244	.032	.048	.0492	1.9591	1.6964	1.7337
2	1.7924	.032	.048	.0492	2.0157	1.6644	1.7177
3	1.7924	.032	.048	.0492	1.9845	1.6644	1.7364
4	1.7604	.032	.064	.0503	2.0058	1.6644	1.7551
5	1.7604	.032	.064	.0497	2.0452	1.6964	1.7918
6	1.7284	.032	.064	.0492	2.1399	1.7444	2.0119
7	1.9204	.048	.064	.0497	2.2731	1.8884	2.347
8	.064	.048	.064	.0492	2.4086	2.0165	2.3152
9	.064	2.4486	2.4966	.0492	2.4143	1.8404	2.4709
10	.032	2.6566	2.7846	.0514	.048	.032	.0492
11	.032	2.6246	2.7199	2.8086		.052	.0492
12	.048	2.5606	2.6543	2.8395		.0701	.0497
13	.048	2.5606	2.7199	2.8704		.0886	.0497
14	.048	2.4486	2.5526	2.9012	.064	.0895	.0492
15	.048	2.3045	2.556	2.8054	.064	.0905	.0492
16	.048	2.3685	2.652	2.8532	.064	.0732	.0497
17	.048	.064	.0492	2.809	.048	.0924	.0492
18	.048	.064	.0492	2.7633	.048	.0934	.0663
19	.048	.064	.0663	.0566	.064	.0943	.0663
20	.048	.064	.0663	.0686	.064	.0857	.0663
21	.048	.064	.0663	.0693	.064	.0867	.0663
22	.048	.064	.0655	.0701	.064	.0876	.0497
23	.032	.048	.0492	.0532	.048	.0709	.0492
24	1.8564	.032	.048	.0492	1.869	1.6804	1.6632
Max	1.9204	2.6566	2.7846	2.9012	2.4143	2.0165	2.4709
Min	.032	.032	.048	.0492	.048	.032	.0492
Avg	.6328	.8635	.9192	.9797	1.0360	.7776	.8459



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 206 / 11KV Kurundwad Urban  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3763	.9503	1.278	1.2597	1.3003	1.2125	1.3176
2	1.3108	.8848	1.278	1.2597	1.1919	1.1797	1.1393
3	1.278	.8848	1.2452	1.2289	1.0985	1.1469	1.0631
4	1.2452	.9503	1.278	1.2597	1.1104	1.1469	1.1104
5	1.2125	.9831	1.2452	1.2266	1.1946	1.1797	1.2308
6	1.1797	1.0159	1.2452	1.1934	1.3352	1.2452	1.4083
7	1.1797	1.1142	1.278	1.2597	1.4415	1.2452	1.423
8	1.2452	1.2452	1.278	1.2929	1.5123	1.2125	1.475
9	1.3108	1.4419	1.3435	1.3592	1.5466	1.4091	1.6598
10	1.3435	1.4091	1.326	1.5261	1.4091	1.4746	1.442
11	1.4091	1.5074	1.4586	1.543	1.4419	1.5604	1.4091
12	1.3108	1.4419	1.4586	1.5424	1.4419	1.5775	1.4586
13	1.1469	1.1469	1.1934	1.2757	1.2125	1.3998	1.326
14	1.0814	1.1142	1.2597	1.3432	1.1469	1.3073	1.3592
15	1.1469	1.3435	1.326	1.5023	1.4091	1.5746	1.3923
16	1.3435	1.4419	1.4255	1.5729	1.4091	1.6644	1.4255
17	1.1797	1.4091	1.326	1.5893	1.4419	1.6448	1.4746
18	1.0159	1.4419	1.4255	1.6991	1.4419	1.7177	1.6057
19	1.3763	1.6385	1.6907	1.9427	1.6385	1.9993	1.7404
20	1.3435	1.6385	1.6244	1.6804	1.6057	1.7147	1.6575
21	1.2125	1.5074	1.6244	1.6297	1.5729	1.6644	1.5912
22	1.278	1.5074	1.6078	1.6476	1.5729	1.6476	1.5912
23	1.1142	1.4419	1.3592	1.5061	1.4746	1.5592	1.4586
24	1.3763	1.0159	1.278	1.2929	1.3717	1.278	1.3375
Max	1.4091	1.6385	1.6907	1.9427	1.6385	1.9993	1.7404
Min	1.0159	.8848	1.1934	1.1934	1.0985	1.1469	1.0631
Avg	1.2507	1.2698	1.3689	1.4431	1.3884	1.4484	1.4207

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 207 / BASTWAD VILLEGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.333	.3361	.3258	.3292	.2947	.3174	.3121
2	.3506	.2987	.333	.3109	.2804	.2987	.2804
3	.3681	.2987	.3506	.3109	.2481	.2987	.2658
4	.3681	.3174	.3506	.3292	.2507	.2987	.3045
5	.3856	.3361	.3506	.3696	.3077	.3361	.3439
6	.3856	.3547	.3681	.3881	.3841	.3734	.3841
7	.3506	.3511	.333	.3511	.3511	.3547	.3511
8	.3155	.2926	.298	.3292	.2801	.2957	.3174
9	.2804	.2926	.2454	.3109	.2829	.3142	.3018
10	.298	.3109	.2926	.2743	.3109	.2957	.2926
11	.3224	.2804	.2926	.3121	.3109	.2947	.3292
12	.3658	.333	.3109	.333	.2926	.3506	.3511
13	.3224	.298	.3292	.3012	.3077	.3898	.3292
14	.3258	.298	.3292	.2865	.3109	.3582	.3109
15	.3439	.2804	.3326	.2896	.2743	.3439	.3475
16	.3841	.298	.3142	.3109	.2507	.3292	.3511
17	.3292	.2454		.2587	.2507	.2957	.3658
18	.3142	.2279		.2427	.2353	.2987	.3658
19	.4066	.3681		.3584	.3511	.4338	.4207
20	.4251	.3856	.4024	.3429	.4066	.3772	.4024
21	.4435	.3681	.3658	.3294	.3696	.3641	.3475
22	.4066	.3506	.5121	.3506	.4066	.3681	.4024
23	.3696	.333	.4024	.3544	.3696	.3721	.3475
24	.333	.3511	.3155	.3048	.2915	.3142	.3258
Max	.4435	.3856	.5121	.3881	.4066	.4338	.4207
Min	.2804	.2279	.2454	.2427	.2353	.2947	.2658
Avg	.3553	.3169	.3407	.3199	.3091	.3364	.3396

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 208 / KURUNDWAD AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1875	.0312	.0312	.0324	.208	.1524	.1907
2	.1875	.0312	.0312	.0324	.2103	.1524	.1753
3	.2187	.0312	.0312	.0324	.1949	.1524	.1772
4	.2187	.0312	.0312	.0324	.197	.1524	.1791
5	.2187	.0312	.0312	.0332	.2172	.1829	.1991
6	.1875	.0312	.0312	.0324	.2378	.1981	.2012
7	.2187	.0312	.0312	.0332	.2772	.2286	.2218
8	.0312	.0312	.0312	.0324	.2987	.2286	.2801
9	.0312	.2187	.3125	.0324	.3206	.2286	.2829
10	.0312	.2968	.3361	.0343	.0312	.0305	.0324
11	.0312	.3125	.3277	.3467	.0312	.0347	.032
12	.0312	.3125	.3113	.3155	.0312	.0351	.0324
13	.0312	.3125	.3113	.3721	.0312	.0354	.0324
14	.0312	.3125	.2915	.3582	.0312	.0358	.0324
15	.0312	.3125	.2915	.3258	.0312	.0362	.0316
16	.0312	.3125	.2785	.3292	.0312	.0366	.032
17	.0312	.0312	.0328	.3142	.0312	.037	.0324
18	.0312	.0312	.032	.2987	.0312	.0373	.0328
19	.0312	.0312	.0324	.0377	.0305	.0377	.032
20	.0312	.0312	.032	.0343	.0305	.0343	.032
21	.0312	.0312	.0324	.0347	.0305	.0347	.0324
22	.0312	.0312	.0324	.0351	.0305	.0351	.0328
23	.0312	.0312	.032	.0354	.0305	.0354	.032
24	.1875	.0312	.0312	.3048	.1886	.1524	.1715
Max	.2187	.3125	.3361	.3721	.3206	.2286	.2829
Min	.0312	.0312	.0312	.0324	.0305	.0305	.0316
Avg	.0885	.1204	.1236	.1446	.1160	.0969	.1054

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144044 / 33/11KV KURUNDWAD

Feeder No / Name : 209 / 11KV Nrisinghwadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3258	.3258	.362	.3658	.2947	.2715	.2774
2	.362	.2896	.3258	.3475	.2629	.2715	.2454
3	.362	.2896	.3258	.3292	.2658	.2715	.2481
4	.3982	.3258	.362	.3292	.2686	.2896	.2686
5	.3982	.362	.3982	.3475	.3077	.2896	.3077
6	.362	.4163	.3982	.3881	.3292	.3258	.2926
7	.3982	.4344	.4706	.4066	.4251	.3982	.3881
8	.394	.4887	.4706	.4251	.3921	.3801	.4108
9	.4298	.4344	.3982	.3841	.3961	.362	.3772
10	.4344	.4344	.439	.3944	.3982	.4344	.3658
11	.3982	.394	.439	.4161	.4344	.3467	.3841
12	.4344	.4298	.439	.3681	.3982	.3856	.439
13	.3982	.4298	.4024		.362	.3544	.3658
14	.4344	.3582	.4024	.394	.362	.3582	.4024
15	.4525	.4706	.4024	.3801	.362	.3801	.4024
16	.4525	.4298	.4435	.4572	.4525	.4207	.4207
17	.4525	.4298	.439	.4251	.362	.4251	.4024
18	.4706	.4344	.4207	.4294	.3982	.3921	.4024
19	.4706	.543	.5121	.4904	.4706	.4338	.4938
20	.4344	.5068	.4755	.3944	.4887	.4115	.4572
21	.4344	.4706	.439	.3814	.3801	.3814	.4024
22	.4344	.4706	.439	.3856	.3982	.3506	.4066
23	.3982	.3982	.4024	.3189	.3258	.3366	.3511
24	.3224	.362	.362	.3658	.2915	.2896	.2915
Max	.4706	.543	.5121	.4904	.4887	.4344	.4938
Min	.3224	.2896	.3258	.3189	.2629	.2715	.2454
Avg	.4105	.4137	.4154	.388	.3678	.3567	.3668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 201 / 11KV Takali Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1334	.0762	.1334	.1143	.0953	.1334
2	.1143	.1334	.0762	.1143	.1143	.0953	.1334
3	.1334	.1334	.1143	.1143	.1334	.0953	.1334
4	.1334	.1334	.1143	.1143	.1334	.0953	.1334
5	.1715	.1334	.1143	.1334	.1334	.0953	.1334
6	.2096	.1524	.1334	.1524	.1524	.1143	.1524
7	.1905	.1524	.1334	.1715	.1143	.1334	.1524
8	.1715	.1524	.1334	.1524	.1334	.1524	.1524
9	.1524	.1524	.1143	.1334	.0953	.1334	.1334
10	.1524	.1524	.1143	.1334	.0953	.1334	.1334
11	.1524	.1334	.1143	.1334	.0762	.1334	.1334
12	.1524	.1334	.1143	.1334	.0762	.1334	.1334
13	.1524	.1334	.1143	.1524	.0953	.1334	.1524
14	.1524	.1334	.1334	.1334	.1143	.1334	.1524
15	.1524	.1334	.1334	.1334		.1334	.1334
16	.1524	.1524	.1143	.1334	.1524	.1334	.1143
17	.1524	.1524	.1334	.1524	.1524	.1334	.1143
18	.1143	.1334	.1143	.1143	.1334	.1334	.1143
19	.1905	.1715	.1715	.1715	.1905	.1524	.1715
20	.1905	.1905	.2096	.1905	.1905	.1905	.2096
21	.1905	.1905	.2096	.1524	.1905	.1905	.1715
22	.1905	.1524	.1715	.1524	.1524	.1524	.1524
23	.1524	.1334	.1524	.1334	.1143	.1334	
24	.1334	.1334	.1143	.1334	.1143	.1143	.1334
Max	.2096	.1905	.2096	.1905	.1905	.1905	.2096
Min	.1143	.1334	.0762	.1143	.0762	.0953	.1143
Avg	.1572	.1461	.1302	.1405	.1292	.1310	.1425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 202 / 11KV Takaliwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.5242	1.2483	1.5051	.0381	.0297	.0381
2	.0381	1.5242	1.2483	1.5432	.0381	.0297	.0381
3	.0381	1.5242	1.3923	1.5051	.0381	.0297	.0381
4	.0381	1.5242	1.2483	1.5242	.0381	.0297	.0381
5	.0381	1.5242	1.2483	1.5242	.0381	.0297	.0381
6	.0381	1.4861	1.2483	1.5623	.0381	.0297	.0381
7	.0381	1.5623	1.2483	1.7337	.0381	.0297	.0381
8	.0381	.0381	.0297	1.7337	.0381	.0297	.0381
9	1.7909	.0381	.0297	1.6766	.0381	.0446	.0381
10	1.9052	.0297	.0381	.0381	.0297	.0381	.0381
11	2.0195	.0297	.0381	.0381	1.4861	2.0767	2.0957
12	2.0386	.0446	.0381	.0381		2.0386	2.3243
13	1.9433	.0297	.0381	.0381		1.9624	2.0005
14	1.9052	.0297	.0381		1.4712	1.9624	2.0005
15	1.8099	.0297	.0381	.0381		1.9814	1.9433
16	1.7909	.0297	.0381	.0381	1.5901	2.0005	1.9433
17	.0381	.0297	.0381	.0381	1.5901	2.0005	1.9243
18	.0572	.0297	.0381	.0381	1.5901	1.9624	1.848
19	.0572	.0446	.0381	.0381	.0297	.0381	.0381
20	.0572	.0446	.0381	.0381	.0497	.0381	.0381
21	.0572	.0297	.0381	.0381	.0446	.0381	.0381
22	1.6004	1.278	.0381	.0381	.0446	.0381	.0381
23	1.5242	1.278	.0381	.0381	.0297	.0381	.0381
24	.0381	1.5242	1.2483	1.5051	.0381	.0297	.0381
Max	2.0386	1.5623	1.3923	1.7337	1.5901	2.0767	2.3243
Min	.0381	.0297	.0297	.0381	.0297	.0297	.0381
Avg	.7891	.6345	.4468	.7091	.3970	.6886	.6954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 203 / 11KV Danwad AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2955	.0381	.0332	.0381	1.3717	1.0277	1.1812
2	1.2574	.0381	.0332	.0381	1.3336	1.0277	1.2193
3	1.2193	.0381	.0332	.0381	1.3717	1.0277	1.2003
4	1.2003	.0381	.0332	.0381	1.4098	1.0277	1.1812
5	1.2003	.0381	.0497	.0381	1.448	.0332	1.2003
6	1.2003	.0381	.0572	.0381	1.467	1.1271	1.2384
7		.0381	.0663	.0381	1.6385	1.2266	1.2574
8	.0381	.0381	.0497	.0381	1.6385	1.2763	1.3336
9	.0381	1.829	1.6409	.0381	1.6385	1.21	1.3527
10	.0381	1.6575	1.9814	.0381	.0332	.0381	.0381
11	.0381	1.7404	2.0957	2.1148	.0332	.0381	.0381
12	.0381	1.6575	2.1529	2.1148	.0332	.0381	.0381
13	.0381	1.6244	2.0957	2.0576	.0332	.0381	.0381
14	.0381	1.6244	2.0195		.0332	.0381	.0381
15	.0381	1.6409	1.9814	1.7718		.0381	.0381
16	.0381	1.6575	1.9433	1.9052	.0332	.0381	.0381
17			.0381	1.8671	.0332	.0381	.0381
18	.0381	.0332	.0381	1.8099	.0497	.0381	.0381
19	.0381	.0497	.0381	.0381	.0497	.0381	.0381
20	.0381	.0497	.0381	.0381	.0497	.0381	.0381
21	.0381	.0332	.0381	.0381	.0332	.0381	.0381
22	.0381	.0332	.0381	.0381	.0332	.0381	.0381
23	.0381	.0332	.0381	.0381	.0332	.0381	.0381
24	1.2955	.0381	.0332	.7621	1.3717	1.0277	1.105
Max	1.2955	1.829	2.1529	2.1148	1.6385	1.2763	1.3527
Min	.0381	.0332	.0332	.0381	.0332	.0332	.0381
Avg	.4200	.6090	.6903	.6511	.6596	.4394	.5335

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 204 / 11KV Rajapur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.6385	1.3592	1.2765	.0381	.0332	.0381
2	.0381	1.6385	1.3592	1.2765	.0381	.0332	.0381
3	.0381	1.6385	1.3592	1.2574	.0381	.0332	.0381
4	.0381	1.6385	1.3592	1.2574	.0381	.0332	.0381
5	.0381	1.6385	1.3923	1.2955	.0381	.0332	.0381
6	.0381	1.5813	1.3923	1.3908	.0381	.0332	.0381
7	.0381	1.6385	1.4586	1.5432	.0381	.0332	.0381
8	.0381	.0572	.0332	1.448	.0381	.0332	.0381
9	2.2862	.0572	.0332	1.3908	.0381	.0332	.0381
10		.0497	.0381	.0381	.0332	.0381	.0381
11	2.21	.0332	.0381	.0381	1.989	2.4006	2.191
12	2.3624	.0332	.0381	.0381	2.0222	2.3053	2.4768
13	2.3624	.0332	.0381	.0381		2.3053	2.4768
14	2.3624	.0332	.0381	.0381	2.0222	2.3053	2.4768
15	2.3434	.0332	.0381	.0381		2.4006	2.3434
16	2.2862	.0332	.0381	.0381	2.0222	2.3624	2.3434
17	.0381	.0332	.0381	.0381	1.989	2.2672	2.3243
18	.0381	.0332	.0381	.0381	1.9559	2.1719	2.2672
19	.0572	.0332	.0381	.0381	.0332	.0381	.0381
20	.0572	.0332	.0381	.0381	.0497	.0381	.0381
21	.0572	.0332		.0381	.0497	.0381	.0381
22	1.7909	1.3923	.0381	.0381	.0497	.0381	.0381
23	1.7147	1.3923	.0381	.0381	.0332	.0381	.0381
24	.0381	1.6385	1.3592	1.2193	.0381	.0332	.0381
Max	2.3624	1.6385	1.4586	1.5432	2.0222	2.4006	2.4768
Min	.0381	.0332	.0332	.0381	.0332	.0332	.0381
Avg	.8830	.6819	.5044	.5787	.5741	.7950	.8129



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 205 / Rajapur Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2667	.2667	.2286	.2667	.2667	.2286
2	.2858	.2667	.2667	.2096	.2477	.2667	.2286
3	.2858	.2667	.2667	.2096	.2477	.2286	.2286
4	.2667	.2667	.2667	.2096	.2858	.2286	.2477
5	.3429	.3048	.2667	.2667	.3048	.2286	.2858
6	.3429	.3239	.2858	.3239	.3048	.2667	.3429
7	.2858	.2858	.3048	.2858	.2286	.2667	.3048
8	.2667	.3048	.2286	.2477	.2096	.2477	.3048
9	.2286	.2667	.1905	.2477	.1905	.2286	.2477
10		.2286	.1905	.2286	.1905		.2286
11	.1905	.1905	.1905	.2286		.1524	.2286
12	.2477	.2286	.2477	.2286		.1715	.2667
13	.2667	.2667	.2096	.2477		.1715	.2858
14	.2667	.2477	.2286	.2667		.1715	.2667
15	.2858	.2286	.2286	.2667		.1905	.2667
16	.2286	.2286	.2477	.2667	.3048	.1715	.2286
17	.2096	.2286	.2096	.2477	.3048	.1715	.2286
18	.2096	.2667	.2096	.2096	.2858		.2096
19	.3239	.3429	.2858	.2858	.362	.381	.3239
20	.381	.381	.381	.4001	.4001	.4001	.3239
21	.381	.381	.381	.381	.381	.4001	.381
22	.362	.3429	.362	.3429	.3429	.381	.362
23	.3048	.3048	.3048	.2858	.3048	.3239	.2858
24	.3048	.2667	.2667	.2477	.2667	.2667	.2667
Max	.381	.381	.381	.4001	.4001	.4001	.381
Min	.1905	.1905	.1905	.2096	.1905	.1524	.2096
Avg	.2858	.2786	.2620	.2651	.2858	.2537	.2739

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 206 / Takaliwadi Vlg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0572	.0762	.0762	.0572	.0572	.0762
2	.0762	.0572	.0762	.0572	.0572	.0572	.0572
3	.0762	.0572	.0762	.0572	.0572	.0572	.0572
4	.0762	.0572	.0762	.0572	.0762	.0572	.0572
5	.0762	.0572	.0762	.0762	.0762	.0572	.0572
6	.0762	.0572	.0762	.0762	.0762	.0762	.0572
7	.0762	.0572	.0762	.0762	.0762	.0953	.0762
8	.0572	.0572	.0762	.0762	.0572	.0762	.0762
9	.0572	.0572	.0762	.0762	.0762	.0572	.0572
10	.0762	.0762	.0953	.0953	.0762	.0762	.0762
11	.0762	.1143	.1143	.0953		.1334	.0953
12	.0762	.1143	.1143	.1143	.0762	.0953	.0953
13	.0953	.0953	.1143	.1143	.0762	.0953	.0762
14	.0953	.0953	.0762	.0953	.0762	.0953	.0953
15	.0572	.0762	.0762	.0762		.0762	.0572
16	.0762	.0762	.0762	.0762	.0762	.0381	.0572
17	.0762	.0762	.0953	.0953	.0762	.0953	.0572
18	.0953	.0953	.1143	.1143	.0572	.0953	.0762
19	.1143	.0953	.1143	.1143	.1143	.1143	.1143
20	.1334	.1143	.1334	.1143	.1334	.1334	.1334
21	.1334	.1334	.1334	.1334	.1143	.1334	.1143
22	.1143	.1143	.1143	.1143	.1143	.1143	.1143
23	.0762	.0762	.0953	.0762	.0953	.0953	.0762
24	.0953	.0762	.0762	.0762	.0762	.0762	.0762
Max	.1334	.1334	.1334	.1334	.1334	.1334	.1334
Min	.0572	.0572	.0762	.0572	.0572	.0381	.0572
Avg	.0857	.0810	.0929	.0889	.0805	.0858	.0786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031] BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 207 / 11 KV TAKALI ( AG )

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193				1.467	1.1401	1.3717
2	1.2193				1.4289		1.3908
3	1.1812				1.4289	1.2955	1.4098
4	1.1812				1.3717	1.2955	1.4098
5	1.2574				1.3717	1.1736	1.448
6	1.2765				1.3336	1.1736	1.5242
7	1.3146				1.4289	1.2071	1.5813
8					1.467	1.2574	1.6575
9		1.9433	1.7772		1.3527	1.2742	1.6956
10		1.7939	2.1338				
11		1.9281	2.21	2.0957			
12		1.9281	2.2291	2.0386			
13		1.9113	2.191	1.9814			
14		1.9113	1.8861	1.9433			
15		1.8778	1.8671	1.9433			
16		1.8945	1.9243	1.9243			
17				1.9433			
18				1.9243			
24	1.2384				1.467	1.2955	1.2574
Max	1.3146	1.9433	2.2291	2.0957	1.467	1.2955	1.6956
Min	1.1812	1.7939	1.7772	1.9243	1.3336	1.1401	1.2574
Avg	1.2360	1.8985	2.0273	1.9743	1.4117	1.2347	1.4746

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 208 / 11 KV SANGAM AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0288	.0381	.0332	.0381	1.2574	1.0442	.9145
2	1.0669	.0381	.0332	.0381	1.2003	1.0442	.9145
3	1.1431	.0381	.0332	.0381	1.1812	1.0442	.8764
4	1.2003		.0332	.0381	1.2384	1.0442	.8383
5	.9335		.0332	.0381	1.2384	1.0608	.8002
6	.7621		.0332	.0381	1.2574	.9945	.8192
7	1.0098	.0381	.0332	.0381	1.3146	.9448	.8192
8	.0381	.0381	.0332	.0381	1.3336	.9945	.7621
9	.0381	1.4289	1.3592	.0381	1.3908	.9779	.7621
10	.0381	1.3592	1.6385	.0381	.0332	.0381	.0381
11	.0381	1.442	1.7337	1.6766	.0332	.0381	.0381
12	.0381	1.442	1.6004	1.5813	.0332	.0381	.0381
13	.0381	1.442	1.6004	1.5623	.0332	.0953	.0381
14	.0381	1.442	1.6004	1.5242	.0332	.0381	.0381
15	.0381	1.4255	1.5813	1.5242		.0381	.0381
16	.0381	1.4752	1.6004	1.5623	.0332	.0381	.0381
17	.0381		.0381	1.5623	.0332	.0381	.0381
18	.0381	.0332	.0381	1.467	.0332	.0381	.0381
19	.0381	.0332	.0381	.0381	.0332	.0381	.0381
20	.0381	.0332	.0381	.0381	.0332		.0381
21	.0381	.0332	.0381	.0381	.0332	.0381	.0381
22	.0381	.0332	.0381	.0381	.0332	.0381	.0381
23	.0381	.0332	.0381	.0381	.0332	.0381	.0381
24	1.0288	.0381	.0332	.0381	1.2574	1.0442	.8954
Max	1.2003	1.4752	1.7337	1.6766	1.3908	1.0608	.9145
Min	.0381	.0332	.0332	.0381	.0332	.0381	.0381
Avg	.3660	.5942	.5533	.5446	.5696	.4672	.3723

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144045 / 33/11KV TAKALI

Feeder No / Name : 209 / 11 KV Danwad Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.1334	.1143	.1143		.1143	.1334
2	.1143	.1334	.1143	.1143		.0953	.1143
3	.1334	.1334	.1143	.1143		.0953	.1143
4	.1334	.1334	.1143	.1143		.0953	.1143
5	.1524	.1334	.1143	.1143		.0829	.1334
6	.1524	.1524	.1334	.1143		.1143	.1524
7	.1524	.1334	.1524	.1334		.1143	.1524
8	.1334	.1334	.1334	.0953	.1143	.1143	.1143
9	.1334	.1334	.1143	.0953	.1334	.0953	.1334
10	.1334	.1334	.1143	.1143	.1334	.1143	.1143
11	.1334	.1334	.0953	.0762	.1334	.0762	.1143
12	.1334	.1334	.1334	.1143	.1143	.1143	.1143
13	.1334	.1334	.1334	.1334	.1143	.1334	.1334
14	.1334	.1334	.0953		.1524	.1334	.1143
15	.1334	.1334	.0953	.1334		.1334	.1524
16	.1334	.1143	.1143	.1334	.1524	.1334	.1334
17	.1143	.1143	.1143	.1143	.1524	.0762	.1334
18	.0953	.1524	.1143	.1334	.1524	.0953	.1143
19	.1524	.1715	.1524	.1334	.1905	.1524	.1905
20	.1715	.1715	.2096	.1715	.2096	.2096	.1905
21	.1715	.1524	.1905	.1524	.1905	.1905	.2096
22	.1524	.1524	.1524	.1715	.1715	.1715	.1715
23	.1524	.1334	.1334	.1524	.1334	.1524	.1334
24	.1524	.1334	.1143	.1143	.1334	.1143	.1334
Max	.1715	.1715	.2096	.1715	.2096	.2096	.2096
Min	.0953	.1143	.0953	.0762	.1143	.0762	.1143
Avg	.1397	.1382	.1278	.1243	.1489	.1217	.1381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 201 / 11 KV Santubai AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8299	.0497	.0663	.0648	1.5623	1.6156	1.7185
2	1.8138	.0497	.0497	.0648	1.5623	1.6872	1.7185
3	1.8138	.0497	.0497	.0648	1.5623	1.749	1.7185
4	1.8138	.0497	.0497	.081	1.5623	1.7814	1.7185
5	1.8138	.0497	.0663	.081	1.5623	1.8461	1.7185
6	1.8138	.0497	.0829	.0972	1.7966	1.9109	1.8122
7	1.8947	.0497	.0829	.0648	1.9372	2.0081	
8	.0648	.0663	.0829	.081	1.9372	1.9433	1.9372
9	.081	2.4863	2.3703	.0972	1.781	1.8747	1.9685
10	.081	2.5029	2.3537	.0972	.0457	.0457	.0457
11	.0972	2.4697	2.536	2.17	.0457	.061	.0457
12	.081	2.4366	2.4939	2.3434	.0457	.0457	.0497
13	.0486	2.4034	2.3644	2.1872	.0457	.0457	.0663
14	.0497		2.2996	2.1872	.0457	.0457	.0829
15	.0829	2.4863	2.3158	2.1872	.0457	.0457	.0663
16	.0829	2.3868	2.2348	2.1247	.0457	.0305	.0829
17	.0829	.0663	.0648	2.1247		.0457	.0829
18	.0829	.0829	.0972	2.0309	.0914	.0457	.0829
19	.0829	.0829	.1134	.061	.0914	.061	.0663
20	.0829	.0829	.1134	.061	.0914	.061	.0663
21	.0995	.0995	.1134	.0457	.0914	.061	.0663
22	.0829	.0995	.081	.0457	.061	.061	.0663
23	.0497	.0995	.081	.0457	.061	.0457	.0497
24	1.8299	.0497	.0663	.7621	1.6404	1.656	1.7497
Max	1.8947	2.5029	2.536	2.3434	1.9372	2.0081	1.9685
Min	.0486	.0497	.0497	.0457	.0457	.0305	.0457
Avg	.6607	.7935	.8429	.7988	.7701	.7822	.7383

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 202 / 11 kv Ghosarawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.032	1.2763	1.21	1.0883	.0305	.0305	.0305
2	.032	1.2597	1.21	1.0883	.0305	.0305	.0305
3	.032	1.2597	1.21	1.1203	.0152	.0305	.0305
4	.032	1.2431	1.1934	1.1203	.0152	.0305	.0305
5	.032	1.2431	1.1934	1.1363	.0152	.0305	.0305
6	.032	1.2266	1.1934	1.1523	.0305	.0305	.0305
7	.032	1.1768	1.1603	1.1683	.0305	.0305	.0305
8	.032	.0332	.0332	1.1683	.0305	.0305	.0305
9	1.3923	.0332	.0332	1.1523	.0305	.0305	.0305
10	1.3923	.0332	.0332	.032	.0305	.0305	.0305
11	1.5203	.0332	.0332	.032	1.4373	1.4373	1.531
12	1.4723	.0332	.032	.0305	1.3717	1.4842	1.6907
13	1.4243	.0332	.032	.0305	1.406	1.5623	1.7072
14	1.3603	.0332	.032	.0305	1.4327	1.406	1.7736
15	1.3592	.0332	.032	.0305	1.4685	1.406	1.7736
16	1.2431	.032	.032	.0305	1.4529	1.406	1.757
17	.0332	.0332	.032	.0305	1.4529	1.406	1.6244
18	.0332	.0332	.032	.0305	1.4089	1.2498	1.5249
19	.0332	.0332	.032	.0305		.0305	.0332
20	.0332	.0332	.032	.0305	.0305	.0305	.0332
21	.0332	.0332	.032	.0305		.0305	.0332
22	1.326	1.2266	.032	.0305	.0305	.0305	.0332
23	1.2763	1.21	.016	.0305	.0305	.0305	.0332
24	.032	1.2763	1.21	1.0722	.0305	.0305	.0305
Max	1.5203	1.2763	1.21	1.1683	1.4685	1.5623	1.7736
Min	.032	.032	.016	.0305	.0152	.0305	.0305
Avg	.5925	.5359	.4201	.4874	.5369	.4936	.5785

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 203 / 11 KV Ghosarawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1294	.1698	.1509	.1478	.1463	.1463	.1463
2	.1294	.1698	.1509	.1294	.1463	.1267	.1463
3	.1294	.1698	.1509	.1294	.1463	.1267	.1463
4	.1478	.1886	.1698	.1478	.1646	.1448	.1463
5	.1848	.2427	.1867	.1663	.1829	.181	.1829
6	.2218	.2801	.2241	.1848	.2926	.2534	.2561
7	.2218	.3142	.2218	.2218	.2561	.2896	.2926
8	.2218	.2587	.1848	.1663	.2561	.2715	.2561
9	.1848	.1848	.1848	.1848	.2561	.2378	.2926
10	.1663	.1478	.1663	.2218	.1829	.3109	.2195
11	.1848	.1109	.1663	.2033	.2195	.2743	.2561
12	.2033	.1478	.1848	.2195	.2378	.3292	.2587
13	.2033	.1848	.2033	.1829	.2378	.2743	.2587
14	.2033	.1848	.2033	.2561	.2561	.2195	.2587
15	.2033	.1848	.1848	.2561	.2561	.2561	.2218
16	.1848	.1848	.2033	.2926	.2378	.2195	.1848
17	.2218	.1848	.2033	.2926	.1463	.2561	.1663
18	.2218	.1848	.1848	.2926	.2353	.1829	.1478
19	.2587	.2218	.2587	.2378	.2534	.1463	.1848
20	.2987	.2587	.2587	.2195	.2195	.2195	.2402
21	.2957	.2987	.2218	.2012	.2195	.2195	.2218
22	.2772	.2241	.1848	.2195	.2012	.2195	.2054
23	.2427	.1867	.1663	.1829	.1646	.1829	.1886
24	.1478	.1867	.1509	.1478	.1463	.1463	.1463
Max	.2987	.3142	.2587	.2926	.2926	.3292	.2926
Min	.1294	.1109	.1509	.1294	.1463	.1267	.1463
Avg	.2035	.2029	.1903	.2044	.2109	.2181	.2094



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 204 / 11 kv Balumama AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4842	.0316	.0316	.0312	1.2811	1.3748	1.3123
2	1.4685	.0316	.0316	.0312	1.2811	1.3904	1.3123
3	1.4685	.0316	.0316	.0312	1.2811	1.406	1.3123
4	1.4685	.0316	.0316	.0312	1.2811	1.4022	1.3123
5	1.4685	.0316	.0316	.0312	1.2811	1.4998	1.3123
6	1.4685	.0474	.0316	.0312	1.406	1.4937	1.406
7	1.4842	.0474	.0474	.0469	1.5623	1.5242	1.4685
8	.0625	.0316	.0474	.0469	1.5623	1.5242	1.4998
9	.0469	1.8976	1.7394	.0312	1.5623	1.5466	1.4685
10	.0469	1.9134	1.8501	.0312	.0305	.0305	.0305
11	.0312	1.945	1.9134	1.906	.0305	.0305	
12	.0312	1.8976	1.8435	1.9685	.0469	.0305	
13	.0312	1.8501	1.8122	1.8747	.0457		
14	.0316	1.8027	1.781	1.8747	.0457	.0305	
15	.0316	1.7764	1.781	1.7185	.0469	.0305	
16	.0316	1.8501	1.7341	1.5935	.0305	.0305	
17	.0316	.0316	.0469	1.5935	.0305	.0305	.0316
18	.032	.032	.0312	1.5935	.0305	.0152	.0316
19	.0316	.0316	.0312	.0305	.0457	.0305	.0316
20	.0316	.0316	.0469	.0305	.0457	.0305	.0316
21	.0316	.0316		.0305	.0457	.0305	.0316
22	.032	.0316	.0312	.0305	.0305	.0305	.0316
23	.0316	.0316	.0469	.0305	.0305	.0305	.0316
24	1.4842	.0332	.0316	.0312	1.2811	1.3413	1.3435
Max	1.4842	1.945	1.9134	1.9685	1.5623	1.5466	1.4998
Min	.0312	.0316	.0312	.0305	.0305	.0152	.0305
Avg	.5151	.6447	.6524	.6104	.5965	.6471	.7778

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 205 / 11 KV Dattawad AG Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	1.5912	1.4255	1.2452	.0305	.0305	.0305
2	.0328	1.5912	1.4255	1.2452	.0305	.0305	.0305
3	.0328	1.5415	1.3923	1.2616	.0305	.0152	.0305
4	.0328	1.5415	1.3592	1.278	.0305	.0152	.0305
5	.0328	1.5249	1.3426	1.278	.0305	.0152	.0305
6	.0328	1.5083		1.3108	.0305	.0152	.0305
7	.0328	1.5083		1.3108	.0305	.0152	.0305
8	.0328	.0332		1.3108	.0305	.0152	.0305
9	1.9498	.0332	.0497	1.3435	.0305	.0305	.0305
10	2.0645	.0332	.0497	.0164	.0305	.0457	.0305
11	2.0809	.0332	.0497	.0164	1.7497	1.7833	1.8122
12	2.1136	.0332	.0492	.0305	1.7497	1.8435	2.0553
13	2.0645	.0332	.0328	.0305	1.6766	1.8747	2.0553
14	1.989	.0332	.0328	.0305	1.6872	1.8435	2.0388
15	1.9227	.0332	.0328	.0305	1.6872	1.7185	2.0388
16	1.9062	.0332	.0328	.0305	1.656	1.7185	2.0056
17	.0332	.0332	.0328	.0305	1.5935	1.7185	1.9559
18	.0332	.0332	.0328	.0305	1.5466	1.5623	1.8896
19	.0332	.0332	.0328	.0305	.0305	.0305	.0332
20	.0332	.0332	.0328	.0305	.0305	.0305	.0497
21	.0332	.0332	.0328	.0305	.0305	.0305	.0332
22	1.5415	1.5415	.0328	.0305	.0305	.0305	.0332
23	1.5912	1.4918	.0328	.0305	.0305	.0305	.0332
24	.0328	1.5912	1.4918	1.2452	.0305	.0305	.0305
Max	2.1136	1.5912	1.4918	1.3435	1.7497	1.8747	2.0553
Min	.0328	.0332	.0328	.0164	.0305	.0152	.0305
Avg	.8202	.6623	.4284	.5512	.5764	.6031	.6821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 206 / 11 KV Dattawad VG

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2743	.3361	.2641	.2743	.2561	.2926	.2561
2	.2561	.2987	.2641	.2561	.2561	.2534	.2561
3	.2561	.2987	.2641	.2561	.2561	.2534	.2561
4	.2926	.3018	.2987	.2743	.2561	.2926	.2561
5	.3109	.3395	.3361	.2926	.2561	.3258	.2926
6	.3292	.3361	.4066	.3109	.3292	.3475	.3658
7	.3292	.3174	.3696	.3109	.2561	.3658	.3292
8	.3292	.3361	.3142	.2926	.2561	.3292	.2561
9	.3109	.3326	.2772	.2743	.2561	.2926	.2926
10	.3475	.3696	.3326	.3292	.2926	.3292	.3292
11	.3658	.3511	.3326	.2926	.2926	.3658	.3292
12	.3658	.3511	.3658	.3292	.362	.3292	.3696
13	.3292	.3734	.3292	.2926	.3292	.3292	.3696
14	.3326	.3696	.3292	.2926	.3258	.3658	.3696
15	.3696	.3696	.3475	.2926	.3292	.3658	.3696
16	.3696	.3696	.3658	.3292	.3658	.3292	.3696
17	.3696	.3326	.3658	.3292	.362	.3292	.3511
18	.4066	.3326	.3658	.3658	.362	.3658	.3511
19	.462	.3696	.4024	.439	.3982	.3658	.4435
20	.499	.499	.439	.4024	.4755	.439	.4805
21	.4251	.4481	.4024	.3658	.4024	.439	.4668
22	.4066	.4108	.3658	.3658	.4024	.439	.4108
23	.3734	.3361	.3292	.3292	.3658	.3658	.3734
24	.2926	.3734	.3018	.3048	.2926	.3292	.3292
Max	.499	.499	.439	.439	.4755	.439	.4805
Min	.2561	.2987	.2641	.2561	.2561	.2534	.2561
Avg	.3501	.3564	.3404	.3168	.3223	.3433	.3447

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

KURUNDWAD[031]

BU 1180

Substation No/ Name :- 144086 / 33/11kv Ghosarawad

Feeder No / Name : 207 / 11 KV Hanuman AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0152	.9332	1.0084	.945	.0152	.0152	.0152
2	.0152	.945	1.0084	.945	.0152	.0152	.0152
3	.0152	.945	1.1361	.9297	.0152	.0152	.0305
4	.0152	.9332	.9934	.9145	.0152	.0152	.0152
5	.0152	.9602	1.0059	.8993	.0152	.0152	.0152
6	.0152	.9602	1.0059	.8993	.0152	.0152	.0152
7	.0152	.945	1.0059	1.0517	.0152	.0152	.0152
8	.0152	.0152	.0152	1.0364	.0152	.0152	.0152
9	1.2193	.0152	.0151	1.0517	.0152	.0152	.0152
10	1.2346	.0152	.0152	.0152	.0152	.0152	.0152
11	1.2346	.0152	.0152	.0152	1.2498		1.2811
12	1.1888	.0152	.0152	.0152	1.2811	.7186	1.2492
13	1.1279	.0151	.0152	.0152	1.1873	.7499	1.2041
14	1.1138	.0151	.0152	.0152	1.1584	.7499	1.189
15	1.1138	.0151	.0152	.0152	1.1584	.7811	1.1439
16	1.0837	.0151	.0152	.0152	1.1431	.7811	1.1279
17	.0152	.0151	.0152	.0152		.7811	1.2041
18	.0152	.0152	.0152	.0152		.6249	1.2651
19	.0151	.0151	.0152	.0152	.0152	.0152	.0152
20	.0151	.0151	.0152	.0152		.0152	.0152
21	.0151	.0151	.0152	.0152		.0152	.0151
22	.9482	1.0364	.0152	.0152	.0152	.0152	.0151
23	.945	1.0084	.0152	.0152	.0152	.0152	.0152
24	.0152	.9332	1.0084	1.0212	.0152	.0152	.0152
Max	1.2346	1.0364	1.1361	1.0517	1.2811	.7811	1.2811
Min	.0151	.0151	.0151	.0152	.0152	.0152	.0151
Avg	.4759	.4088	.3506	.4128	.3695	.2361	.4134

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 201 / 11KV Shirati Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.1867	.1715	.168		.168	.1867
2	.1867	.1494	.1715	.1494		.168	.168
3	.1867	.1494	.1715	.1494		.168	.168
4	.2054	.112	.1715	.168		.168	.1867
5	.2241	.112	.2229	.1867		.2241	.2054
6	.2614	.1867	.2743	.2801		.2801	.2614
7	.2241	.2054	.2058	.2241		.2614	.2054
8	.1867	.1867	.1715	.2054		.2054	.1867
9	.1886	.1867	.1867	.2054	.168	.1867	.1867
10	.1715	.168	.2054	.2054	.112	.1867	.168
11	.1715	.1867	.2054	.2054	.1509	.1867	
12	.1886	.1494	.2054	.2054	.168	.2054	.2054
13	.1715	.168	.1867	.2241	.1494	.1867	.1867
14	.1715	.1867	.168	.2241	.1867	.2054	.1867
15	.1715	.168	.168	.2054	.1867	.1867	
16	.1715	.1867	.1867	.1867	.1543	.1867	.2054
17	.1494	.1629	.168	.1715	.1578	.2054	.1928
18	.1307	.1448	.1307	.1715	.1402	.1494	.2103
19	.2427	.2172	.1494	.2058	.1715	.2427	.2454
20	.2241	.2534	.2614	.2534	.2401	.2614	.298
21	.2241	.2401	.2427	.2353	.2378	.2427	.2629
22	.2427	.2229	.2241	.2229	.2378	.2427	.2454
23	.2054	.2058	.2054	.1991	.1928	.2054	.2103
24	.1867	.1867	.1715	.1867		.1867	.2054
Max	.2614	.2534	.2743	.2801	.2401	.2801	.298
Min	.1307	.112	.1307	.1494	.112	.1494	.168
Avg	.1947	.1801	.1928	.2016	.1769	.2046	.2081

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 202 / KUTWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0082	.0373	.0171			1.0269	.8402
2	1.0082	.0373	.0171			1.0269	.8916
3	1.0082	.0373	.0171			1.0269	.9088
4	1.0269	.0373	.0171			1.0269	.9896
5	1.0269	.0373	.0171			1.1389	.9259
6	1.0456	.0373	.0171			1.251	.9774
7	1.1016	.0373	.0343			1.419	1.2883
8	.0373	.0373	.0343			1.4377	1.2003
9	.0343	1.531	2.0165	.0373	1.3394		1.3256
10	.0171	1.9978	2.1098	.0373	.0343	.0373	.0373
11	.0171	2.0725	2.2032	2.1285	.0343	.0373	.0373
12	.0343	1.9418	2.2592	2.1845	.0343		.0373
13	.0343	2.0165	2.2405	2.0538	.0343	.0373	.0373
14	.0343	2.0351	2.1658	2.0911	.0343	.0373	.0373
15	.0343	1.9978	2.1845	2.0351	.0343	.0373	.0373
16	.0343	1.9791	2.0911	1.9791	.0343	.0373	.0373
17	.0373	.0362	.0343	1.8004	.0343	.0343	.0351
18	.0373	.0362	.0343	1.749	.0343	.1715	.0351
19	.0373	.0362	.0343	.0362	.0362	.1715	.0351
20	.0373	.0362	.0343	.0362	.0343	.1715	.0351
21	.0373	.0171	.0343	.0362	.0362	.1715	.0351
22	.0373	.0171	.0343	.0362	.0362	.0857	.0351
23	.0373	.0171	.0343	.9278	.0351	.0857	.0351
24	1.0456	.0373	.0171	.9259		.9896	.8059
Max	1.1016	2.0725	2.2592	2.1845	1.3394	1.4377	1.3256
Min	.0171	.0171	.0171	.0362	.0343	.0343	.0351
Avg	.3671	.6710	.7375	1.1309	.1217	.5209	.4442

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 203 / SHIROL AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6804	.0373	.0343			1.7924	1.6804
2	1.6804	.0373	.0343			1.7924	1.7177
3	1.6804	.0373	.0343			1.7924	1.6804
4	1.6804	.0373	.0171			1.7924	1.6478
5	1.6057	.0373	.0171			1.8111	1.7737
6	1.643	.0373	.0343			1.8298	1.9791
7	1.7924	.0373	.0343			2.0538	1.9791
8	.0373	.0373	.0343			2.0165	2.1658
9	.0343	2.4272	2.5206	.0373		1.9418	2.1098
10	.0343	2.6139	2.6139	.0373		.0373	.0373
11	.0171	2.8006	2.6513	2.6139		.0373	
12	.0171	2.5579	2.4086	2.6513		.0373	.0373
13	.0343	2.5206	2.4272	2.6139		.0373	.0373
14	.0343	2.5766	2.4086	2.5766	1.7364	.0373	.0373
15	.0343	2.5393	2.3899	2.5206	1.749	.0376	.0373
16	.0343	2.726	2.2032	2.5579	1.8347	.0373	.0373
17	.0373	.0362			.0343	.0343	.0351
18	.0373	.0181		2.0576	.0343		.0351
19	.0373	.0362	.0343	.0362	.0343		.0351
20	.0373	.0362	.0343	.0543	.0514	.0343	.0351
21	.0373	.0343	.0343		.0526	.0343	.0351
22	.0373	.0171	.0343	.0181	.0526	.0343	.0351
23	.0373	.0343	.0373	.0181	1.5775	.0373	.0351
24	1.7177	.0373	.0343	.0343		1.6804	1.6617
Max	1.7924	2.8006	2.6513	2.6513	1.8347	2.0538	2.1658
Min	.0171	.0171	.0171	.0181	.0343	.0343	.0351
Avg	.5841	.8879	.9124	1.2734	.7157	.8609	.8202

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 204 / GHALWAD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	1.7924	1.6289			.0934	.0857
2	.0934	1.7924	1.6289			.0934	.0857
3	.0934	1.7924	1.6289			.0934	.0857
4	.0934	1.7924	1.6289			.0934	.0857
5	.0934	1.8298	1.6632			.0934	.0857
6	.0934	1.8671	1.6118			.0934	.0857
7	.0934	1.8671	1.5947			.0934	.0857
8	.0934	.0373	.0857			.0934	.0857
9	2.1091	.0934	.0934	.0934	.0857	.0934	.0934
10	2.2977	.0934	.0934	.0934	.0857	.0934	.0934
11	2.3148	.0934	.0934	.0934	2.0062	2.3152	2.3152
12	2.1776	.0934	.0934	.0934	2.4272	2.3152	2.5766
13	2.1091	.0934	.0934	.0934	2.4646	2.3712	2.5206
14		.0934	.0934	.0934	2.4272	2.4646	2.4646
15	2.1776	.0934	.0934	.0934	2.4086	2.4272	2.4272
16	2.0919	.0934	.0934	.0934	2.0919	2.4459	2.2779
17	.0934	.0905	.0857	.0857	2.0576	2.2779	2.0858
18	.0934	.0905	.0857	.0857	.1886	2.2032	2.1033
19	.0934	.0905	.0857		.0343	.0934	.0876
20	.0934	.0905	.0857		.0905	.0857	.0876
21	.0934	.0857	.0857		.0905	.0857	.0876
22	1.8671	1.5089	1.5432		.0905	.0857	.0876
23	1.8671	1.5947	1.5261		.0876	.0857	.0876
24	.0934	1.8298	1.6289	1.643		.0938	.0857
Max	2.3148	1.8671	1.6632	1.643	2.4646	2.4646	2.5766
Min	.0934	.0373	.0857	.0857	.0343	.0857	.0857
Avg	.8835	.7875	.7227	.2329	1.1091	.8452	.8403



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 205 / 11KV Shirti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0373	1.4937	1.2346			.0373	.0343
2	.0373	1.4563	1.262			.0373	.0343
3	.0373	1.4563	1.2346			.0373	.0343
4	.0373	1.3443	1.2003			.0373	.0343
5	.0373	1.251	1.1488			.0373	.0343
6	.0373	1.251	1.166			.0373	.0343
7	.0373	1.251	1.1145			.0373	.0343
8	.0373	.0373	.0171			.0187	.0343
9	2.0233	.0373	.0187	.0373	.0343	.0187	
10	2.1948	.0373	.0373	.0373	.0343	.0187	.0373
11	2.3663	.0373	.0373	.0373	2.1948	2.8006	
12	2.0576	.0373	.0373	.0373	2.6699	2.8193	2.8193
13	2.2291	.0373	.0373	.0373	2.6139	2.782	2.7446
14	2.2291	.0373	.0373	.0373	2.4646	2.8193	2.782
15	2.2291	.0373	.0373	.0373	2.4272	2.8006	2.6326
16	2.0062	.0373	.0373	.0373	2.0748	2.7633	2.5766
17	.0187	.0362	.0373	.0343	2.0233	2.3899	2.2436
18	.0373	.0181	.0373	.0171	2.0332	2.2032	2.1735
19	.0373	.0181	.0343	.0181	.0343	.0373	.0175
20	.0373	.0181	.0343	.0181	.0343	.0373	.0175
21	.0373	.0171	.0373	.0181	.0183	.0373	.0175
22	1.643	1.286	1.1576	.0181	.0181	.0343	.0175
23	1.6244	1.3203	1.166	.0181	.0171	.0373	.0175
24	.0373	1.5123	1.286	1.251		.0187	.0343
Max	2.3663	1.5123	1.286	1.251	2.6699	2.8193	2.8193
Min	.0187	.0171	.0171	.0171	.0171	.0187	.0175
Avg	.8794	.5861	.5187	.1057	1.2462	.9124	.8366

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 206 / Kutwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1372			.1494	.12
2	.1494	.1307	.1372			.1494	.1307
3	.1494	.112	.1372			.1494	.1307
4	.168	.112	.1372			.1494	.1494
5	.168	.1494	.1543			.1494	.168
6	.1867	.1494	.1886			.1867	.2054
7	.168	.168	.1543			.1494	.168
8	.1494	.1494	.1372			.1494	.1494
9	.12	.1307	.112	.1494	.0747		.1494
10	.1372	.1307	.1494	.1307	.0747	.1494	.1307
11	.1372	.1307	.1494	.1494	.0747	.1494	.1307
12	.1372	.112	.168	.168	.0747	.168	.168
13	.1372	.1307	.1494	.1494	.0747	.168	.168
14	.1715	.168	.168	.168	.1307	.168	.1494
15	.1543	.1494	.1494	.168	.1494	.168	.1494
16	.1372	.168	.1307		.12	.1494	.1307
17	.112	.1629	.1307	.1372	.1029	.1494	.1227
18	.112	.1267	.112	.1372	.1372	.1494	.1052
19	.168	.181	.168	.1629	.1448	.2241	.1578
20	.1867	.2172	.2054	.1715	.2058	.2241	.2103
21	.1867	.1886	.2054	.181	.2012	.2241	.1928
22	.1867	.1886	.2054	.181	.1928	.1867	.1928
23	.1494	.1543	.168	.1629	.1578	.1494	.1753
24	.1494	.1494	.1372	.1494			.1494
Max	.1867	.2172	.2054	.181	.2058	.2241	.2103
Min	.112	.112	.112	.1307	.0747	.1494	.1052
Avg	.1530	.1496	.1538	.1577	.1277	.1664	.1543

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144037 / 33/11 KV SHIRATI

Feeder No / Name : 207 / Ghalwad Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2241	.2401			.3174	.2241
2	.2241	.2241	.2401			.3174	.2241
3	.2241	.2614	.2401			.3174	.2427
4	.2241	.3361	.2401			.3174	.2427
5	.2614	.3361	.3086			.3734	.2987
6	.3921	.3734	.3086			.4854	.3921
7	.3174	.3921	.3086			.3547	.3174
8	.2801	.3174	.3086			.3361	.3547
9	.3258	.3361	.3361	.2987	.2614	.3174	.3547
10	.3086	.3547	.3361	.2987	.2427	.3361	.2987
11	.2915	.2801	.3734	.2987	.2987	.3547	.3547
12	.3086	.2427	.3547	.2801	.2801	.3174	.3361
13	.2058	.2614	.3547	.2614	.2801	.2987	.3174
14	.2572	.2614	.3361	.2614	.2427	.2801	.2987
15	.2401	.2427	.3174	.2427	.2614	.2614	.3174
16	.2229	.2427	.2987	.2427	.2353	.2427	.2801
17	.2427	.2172	.2572	.1886	.2279	.2058	.2804
18	.2054	.2715	.2614	.2058	.2279	.2229	.2629
19	.3361	.3077	.3734		.2401	.3086	.3681
20	.3174	.362	.3921		.3155	.3258	.4031
21	.4108	.3086	.3429		.3681	.3086	.3856
22	.4108	.3086	.3921		.3681	.3429	.3856
23	.3174	.2743	.3361		.333	.3086	.3506
24	.2427	.2801	.2401	.3174		.3364	.2058
Max	.4108	.3921	.3921	.3174	.3681	.4854	.4031
Min	.2054	.2172	.2401	.1886	.2279	.2058	.2058
Avg	.2830	.2924	.3124	.2633	.2789	.3161	.3124

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 201 / 11KV K'Guland

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0152	.016	.017	1.0669		1.1869
2		.0152	.016	.017	1.2071		1.0852
3		.0152	.016	.017	1.1279		1.153
4		.0152	.016	.017	1.1984		1.1869
5		.0152	.0162	.017	1.1279		1.1869
6		.0152	.0162	.017	1.1888		1.2548
7		.0152	.0162	.017	1.2955		1.2548
8		.0152			1.3603		1.3226
9	.016	1.5261	1.4575	.017	1.3108		1.3565
10	.016	1.6956	1.6804	.016	.0164	.0143	.0162
11	.016	1.6956	1.7147	1.7604	.0162	.0137	.016
12	.016	1.7635	1.8229	1.8233	.0166	.0137	.0162
13	.016	1.8313	1.893	1.6575	.0162	.0137	.0162
14	.016	1.7635	1.7878	1.5746	.0162	.0137	.016
15	.016	1.6956	1.8229	1.6575	.016	.0137	.0162
16	.016		1.7528	1.6575	.016	.0137	.016
17	.0152	.0177	.017	1.1393	.016	.0137	.0143
18	.0152	.016	.0177	1.6827		.017	.0143
19	.0152	.016	.017	.0137		.017	.0143
20	.0152	.016	.0177	.0137		.017	.0143
21	.0152	.016	.017	.0143		.017	.0143
22	.0152	.016	.017	.0143		.017	.0143
23	.0152	.0162	.0177	.0143		.017	.0143
24		.0152	.016	.0152	1.1336		.4458
Max	.016	1.8313	1.893	1.8233	1.3603	.017	1.3565
Min	.0152	.0152	.016	.0137	.016	.0137	.0143
Avg	.0156	.5314	.6166	.5735	.6748	.0152	.4853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 202 / 11KV Ganeshwadi

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.8351	1.8233	1.8652	.0143		.017
2		1.7532	1.8233	1.8313	.0137		.017
3		1.7532	1.8233	1.8652	.0143		.0177
4		1.7532	1.8233	1.8652	.0143		.017
5		1.8023	1.8442	2.0908	.0143		.017
6		1.8842	2.0119	2.0008	.0143		.017
7		1.9826	2.0119	2.1704	.0143		.017
8		.016		.017	.0143		.017
9	2.4577	.017	.0137	.017	.0143		.017
10	2.7854	.0177	.0143	.016	.0162	.0143	.0162
11	2.7035	.017	.0135	.016	2.4863	3.0308	2.5987
12	2.652	.017	.0137	.016	2.6825	2.8959	2.6825
13	2.652	.017	.0137	.016	2.652	2.8959	2.6825
14	2.6189	.017	.0137	.016	2.652	2.9874	2.652
15	2.5194	.017	.0137	.016	2.0719	3.0247	2.6825
16	2.4863	.017	.0137	.016	2.5149	2.9264	2.5149
17	.016	.017	.0177	.0137	.4024	2.8235	2.572
18	.016	.016	.017	.0137		2.516	2.6292
19	.016	.016	.017	.0137		.017	.0143
20	.016	.016	.017	.0137		.0177	.0143
21	.016	.016	.017	.0143	.0133	.017	.0145
22	1.8351	1.6575	1.9669	.0143	.0149	.017	.0141
23	1.9006	1.8233	1.933	.0143	.0137	.017	.0143
24	.016	1.8679	1.8233	.0143			.017
Max	2.7854	1.9826	2.0119	2.1704	2.6825	3.0308	2.6825
Min	.016	.016	.0135	.0137	.0133	.0143	.0141
Avg	1.5442	.7644	.8296	.5811	.7824	1.6572	.8864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 203 / 11KV Alas Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8215	.7956	.7087	.0137	.017	.017
2		.8215	.8048	.6783	.0137	.017	.017
3		.8215	.8589	.6783	.0137	.017	.017
4		.8215	.8501	.6783	.0137	.017	.017
5		.8215	.8589	.7461	.0137	.017	.017
6		.8215	.8962	.7461	.0137	.017	.017
7		.8383	.8962	.7796	.0137	.017	.017
8		.0152		.017	.0137	.017	.017
9	1.2431	.017	.0137	.017	.0137	.017	.017
10	1.2431	.017	.0143	.016	.016	.0137	.0162
11	1.3413	.017	.0135	.016	1.0059	1.2346	1.1203
12	1.3077	.017	.0137	.016	1.0898	1.1984	1.2936
13	1.2431	.017	.0137	.016	1.1401	1.2452	1.307
14	1.2266	.017	.0133	.016	1.1401	1.2631	1.3443
15	1.0608	.017	.0137	.016	1.1065	1.2955	1.2209
16	1.0608	.017	.0137	.016	1.1271	1.4251	1.2971
17	.0152	.017	.017	.0137	1.1401	1.2452	1.1012
18	.0152	.016	.017	.0137		1.153	1.1012
19	.0152	.016	.017	.0135		.017	
20	.0152	.016	.017	.0137		.017	.0137
21	.0152	.016	.017	.0137	.0137	.017	.0139
22	.8551	.663	.6783	.0137	.0137	.017	.0137
23	.8215	.8048	.6783	.0137	.0137	.017	.0139
24		.8215	.8048	.9114	.0137	.017	.017
Max	1.3413	.8383	.8962	.9114	1.1401	1.4251	1.3443
Min	.0152	.0152	.0133	.0135	.0137	.0137	.0137
Avg	.7653	.3454	.3616	.2570	.3783	.4304	.4360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 204 / 11KV Alas Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4706	.4755	.4252	.381	.443	.4252
2		.4706	.4572	.4252	.381		.3721
3		.4344	.4525	.443	.381		.3721
4		.4344	.4525	.443	.3658		.3366
5		.4344	.4572	.4784	.3658		.3189
6		.5249	.4938	.4961	.3311		.3544
7		.543	.5121	.4961	.3311		.3721
8		.4887		.4784	.3161		.3721
9	.4755	.4607	.3749	.443	.2972		.3721
10	.4755	.4252	.3086	.4755	.362	.3906	.439
11	.5121	.443	.4049	.5175	.362	.3749	.4755
12	.5121	.5138	.4694	.5544	.3658	.4062	.4755
13	.5121	.5138	.4588	.5914	.4024	.4534	.5121
14	.5487	.5138	.4696	.567	.4572	.4268	.4938
15	.5121	.5138	.4752	.567	.4755	.4534	.4755
16	.4938	.5138	.4586	.5121	.439	.4161	.439
17	.5068	.443	.443	.3567		.3612	.3906
18	.5068	.4207	.3721	.2972		.3561	.3269
19	.543	.5853	.4252	.4428		.4252	.3567
20	.6516	.695	.5138	.583		.4961	.4012
21	.5792	.6219	.5138	.5182	.5506	.6024	.4374
22	.543	.5487	.4784	.4572	.5344	.567	.4744
23	.543	.5487		.4572	.4744		.506
24		.4706	.5121	.3761	.4428	.4961	.4961
Max	.6516	.695	.5138	.5914	.5506	.6024	.5121
Min	.4755	.4207	.3086	.2972	.2972	.3561	.3189
Avg	.5277	.5014	.4536	.4751	.4008	.4446	.4165

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 205 / 11KV Ganeshwadi Gaotthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4024	.4207	.3189	.2709		.3898
2		.4024	.4024	.2835	.286		.4024
3		.4024	.4024	.2835	.2675		.3544
4		.4024	.3658	.3189	.2709		.3544
5		.439	.3658	.3189	.2675		.3544
6		.4755	.4024	.3366	.2675		.3475
7		.4207	.4024	.3366	.2675		.3475
8		.3475		.3012	.2675		.3366
9	.3658	.3189	.2932	.2658	.208		.3366
10	.3658	.3189	.2439	.2926	.2926	.2343	.2926
11	.3292	.3189	.2846	.2926	.2715	.2343	.3292
12	.3292	.3189	.3113	.3109	.2743	.2812	.3292
13	.3475	.3544	.2881	.3292	.2926	1.2967	.3475
14	.4024	.3544	.3321	.3841	.3109	.3048	.3658
15	.3658	.3544	.3321	.3658	.3292	.3048	.3658
16	.3475	.3898	.3361	.3475	.3109	.2972	.3658
17	.3439	.3841	.3544	.3161	.3109	.3269	.3321
18	.3439	.3658	.3721	.2824		.3366	.3281
19	.4525	.4755	.4252	.3353		.3721	.3479
20	.4887	.5487	.4938	.3906		.4252	.3795
21	.5068	.5304	.4607	.3418	.3637	.4607	.3795
22	.4706	.4938	.4252	.3418	.3637	.4961	.3795
23	.3982	.4572		.3048	.3125		.3795
24		.4024	.4572	.2401	.2968		.4252
Max	.5068	.5487	.4938	.3906	.3637	1.2967	.4252
Min	.3292	.3189	.2439	.2401	.208	.2343	.2926
Avg	.3905	.4033	.3715	.3183	.2906	.4131	.3571



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 206 / 11KV Krishna Feeder

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.3361	.2987	.2835		.1417
4		.3361	.3772	.3544		.1772
5		.3734	.3772	.3544		.2658
6		.3734	.3772	.3544		.3544
7		.3734	.3772	.3544		.3544
8		.3734		.3544		.3544
9	.3961	.3544	.3163	.3544		.3544
10	.415	.3544	.2968	.3395	.3125	.3772
11	.3772	.3544	.3125	.3772	.3048	.3772
12	.3961	.3658	.3125	.3772	.3048	.415
13	.3961	.3544	.3201	.3772	.3048	.3772
14	.3772	.3544	.3163	.3961	.3125	.3772
15	.3772	.3544	.3125	.3772	.3125	.3772
16	.3772	.3544	.3163	.3772	.2972	.3772
17	.3734	.3658	.3544	.301	.2972	.2972
18	.3734	.3772	.3658	.301	.3544	.2972
24				.1372		
Max	.415	.3772	.3772	.3961	.3544	.415
Min	.3734	.3361	.2968	.1372	.2972	.1417
Avg	.3859	.3597	.3354	.3395	.3112	.3297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 207 / 11KV Vijay-Ganesh

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.2715	.2587	.2658		.1772
4		.2715	.2987	.2835		.2658
5		.3982	.2987	.3544		.3898
6		.3982	.2987	.3898		.3898
7		.3982	.3395	.3898		.3898
8		.3982		.3898		.4075
9	.4108	.3898	.3479	.3898		.4075
10	.3921	.3898	.3479	.4108	.3048	.4108
11	.4108	.3898	.3163	.4294	.3281	.4108
12	.415	.373	.3125	.4338	.3048	.3734
13	.3961	.373	.3201	.415	.3048	.3734
14	.4338	.373	.3521	.415	.2972	.3961
15	.4338	.373	.3281	.415	.3121	.415
16	.4108	.3898	.3361	.415	.2972	.415
17	.3982	.3898	.3544	.3048	.2972	.3269
18	.3982	.3961	.2835	.2526	.3544	.2972
Max	.4338	.3982	.3544	.4338	.3544	.415
Min	.3921	.2715	.2587	.2526	.2972	.1772
Avg	.4100	.3733	.3195	.3721	.3112	.3654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144038 / 33/11 KV KAVATHE-GULAND

Feeder No / Name : 208 / 11 KV Bubnal Express

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3		.2378	.2772	.2743		.1417
4		.2378	.2801	.2658		.2303
5		.2378	.2987	.2835		.2303
6		.2561	.2987	.2835		.2835
7		.2378	.2987	.2835		.2835
8		.2378	.253	.2926		.2835
9	.168	.2303	.2561	.2835		.2835
10	.1886	.2303	.2408	.2987	.2343	.3018
11	.2452	.2126	.2378	.2987	.2378	.3018
12	.2452	.2303	.2378	.2987	.2378	.3018
13	.2427	.2835	.253	.2987	.2378	.3018
14	.2427	.2835	.25	.3018	.1189	.3018
15	.2452	.2835	.25	.3018	.1189	.3018
16	.016	.2987	.25	.3018	.1158	.3018
17	.2378	.2835	.2835	.2378	.1158	.2378
18	.2378	.3018	.2835	.2378	.1417	.2378
24				.1402		
Max	.2452	.3018	.2987	.3018	.2378	.3018
Min	.016	.2126	.2378	.1402	.1158	.1417
Avg	.2069	.2552	.2656	.2755	.1732	.2703

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 201 / 11 KV Nandani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181	.9335	.9335	1.0456	.0175	.0187	.0187
2	.0181	.9335	.9335	1.0456	.0175	.0187	.0187
3	.0181	.9522	.9522	1.1203	.0175	.0187	.0187
4	.0181	.9522	.9522	1.1203	.0175	.0187	.0187
5	.0181	.9335	1.0082	1.2323	.0175	.0187	.0187
6	.0181	1.0082	1.0829	1.307	.0175	.0187	.0187
7	.0181	1.1203	1.1949	1.3443	.0175	.0187	.0187
8	.0181	.0187	.0187	.0181	.0177	.0187	.0187
9	1.2323	.0187	.0187	.0181	.0187	.0187	.0187
10	1.4937	.0187	.0179	.0179	.0187	.0187	.0187
11	1.4563	.0187	.0179	.0177	1.4937	1.4563	1.419
12	1.419	.0187	.0177	.0177		1.5684	1.4563
13	1.3443	.0187	.0181	.0177	1.419	1.4937	1.419
14	1.3817	.0187	.0181	.0177	1.3443	1.419	1.419
15	1.3443	.0187	.0181	.0175	1.307	1.4563	1.4937
16	1.307	.0187	.0181	.0175	1.2696	1.4563	1.4937
17	.0187	.0187	.0181	.0175	1.3443	1.4563	1.4563
18	.0187	.0187	.0181	.0177	1.1949	1.419	1.3817
19	.0187	.0187	.0181	.0177	.0187	.0187	.0181
20	.0187	.0187	.0181	.0175	.0187	.0187	.0181
21	.0187	.0187	.0181	.0175	.0187	.0187	.0181
22	1.0082	1.1203	1.1576	.0175	.0187	.0187	.0181
23	1.0082	1.1203	1.1203	.0175	.0187	.0187	.0181
24	.0181	.9335	1.0829	1.0456	.0175	.0187	.0187
Max	1.4937	1.1203	1.1949	1.3443	1.4937	1.5684	1.4937
Min	.0181	.0187	.0177	.0175	.0175	.0187	.0181
Avg	.5521	.4279	.4447	.3977	.4201	.5010	.4931

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 202 / 11 KV Nandani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3077	.3361	.3361	.3734	.3506	.3734	.3734
2	.2534	.3174	.3174	.3734	.3506		.3547
3	.2534	.2801	.3174	.3174	.3155	.3547	.3547
4	.2534	.2801	.2801	.3174	.3155	.3734	.3734
5	.2896	.2987	.2801	.3174	.3506	.4481	.4481
6	.3258	.4294	.2987	.4108	.3856	.4854	.4854
7	.4163	.4854	.3361	.4481	.4207	.4294	.4668
8	.3801	.4294	.3174	.4163	.3898	.4294	.4668
9	.3921	.4294	.3361	.3801	.3734	.4108	.3734
10	.3921	.4481	.3224	.4298	.3921	.4108	.4668
11	.4668	.4481	.3582	.4252	.4294	.4294	.4668
12	.4294	.4668	.3721	.4607	.4294	.5041	.5041
13	.4668	.4294	.362	.4961	.3921	.4294	.5041
14	.4294	.3921	.362	.4607	.3734	.3734	.4668
15	.3921	.4294	.3801	.4557	.4294	.4294	.3921
16	.3174	.4481	.3801	.4207	.4668	.4854	.4668
17	.4294	.4668	.4706	.4207	.4668	.4854	.4481
18	.4287	.4854	.4344	.3544	.4294	.4668	.3921
19	.4374	.5041	.6154	.4607	.5228	.4854	.4668
20	.4973	.5601	.6154	.5258	.5316	.4854	.5975
21	.5228	.5228	.6154	.4908	.5601	.4854	.543
22	.5041	.4668	.5601	.4733	.4668	.4668	.5249
23	.4294	.4108	.4481	.4557	.4668	.4481	.4163
24	.3258	.3734	.3734	.3921	.4207	.4481	.3921
Max	.5228	.5601	.6154	.5258	.5601	.5041	.5975
Min	.2534	.2801	.2801	.3174	.3155	.3547	.3547
Avg	.3892	.4224	.3954	.4199	.4179	.4408	.4477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 203 / Ganesh Bakery

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.168	.168	.112	.1402	.1494	.112
2	.1267	.1494	.1494	.0934	.1402	.1494	.1494
3	.1267	.1307	.1307	.0934	.1402	.1494	.1494
4	.1267	.1307	.1307	.0934	.1753	.12	.1307
5	.1629	.1494	.1494	.1307	.2103	.1494	.1867
6	.2172	.1867	.1494	.1867	.2279	.168	.2614
7	.2715	.2427	.1494	.2427	.2454	.2427	.3174
8	.362	.2801	.1494	.2353	.2835	.2801	.3174
9	.3547	.2987	.1307	.2715	.2987	.3921	.3174
10	.3547	.3361	.1075	.2686	.3052	.3361	.3174
11	.3361	.3174	.1254	.2835	.4108	.3921	.3361
12	.3361	.3361	.124	.2835	.3734	.3174	.3547
13	.3174		.1448	.2658	.3361	.3174	.3174
14	.3361	.2073	.181	.2658	.3174	.2614	.3361
15	.3174	.2987	.1267	.2804	.3174	.2987	.3361
16	.3547	.3174	.1267	.2804	.3547	.3547	.3174
17	.3174	.2987	.112	.298	.3174	.3361	.3361
18	.2572	.2987	.1086	.2835	.3174	.3361	.2614
19	.2915	.2614	.1267	.3012	.2614	.2241	.3174
20	.2614	.2427	.1086	.2454	.2229	.2241	.2801
21	.2614	.2427	.1086	.2103	.2229	.2054	.2353
22	.2241	.1867	.112	.1578	.2054	.168	.1991
23	.1494	.168	.1307	.1578	.1867	.112	.1267
24	.1267	.168	.168	.112	.1402	.1494	.112
Max	.362	.3361	.181	.3012	.4108	.3921	.3547
Min	.1267	.1307	.1075	.0934	.1402	.112	.112
Avg	.2549	.2355	.1341	.2147	.2563	.2431	.2552

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 204 / 11 KV Agar Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2172	.2241	.2241	.2241	.2103	.2241	.2241
2	.181	.2241	.2241	.1867	.2103	.2241	.2241
3	.181	.2241	.2241	.1867	.2103	.2241	.2241
4	.181	.1867	.1867	.1867	.2103	.2427	.2427
5	.181		.1867	.1867	.2279	.2427	.2427
6	.2172	.2427	.2427	.2172	.2454	.2241	.2427
7	.2172	.2801	.2801	.2427	.2454	.2801	.2241
8	.2534	.2801	.2241	.2534	.2658	.2614	.2241
9	.3174	.3547	.2614	.3077	.2427	.2801	.3361
10	.2241	.2801	.2686	.2686	.2427	.2987	.3734
11	.2054	.2801	.2686	.2481	.2241	.2614	.3174
12	.2801	.2801	.3189	.2303	.2614	.3547	.3921
13	.2614	.2801	.2715	.2303	.2614	.2801	.3734
14	.3361	.2801	.2353	.2481	.2614	.2427	.3734
15	.3734	.2987	.3174	.2454	.2427	.2614	.4108
16	.3547	.2987	.2353	.2103	.2614	.3547	.2614
17	.2987	.2987	.3801	.2103	.2987	.2987	.2987
18	.2743	.3174	.3077	.2303	.2987	.3547	.2801
19	.3361	.3174	.2987	.3012	.3174	.3361	.3174
20	.3174	.3361	.3801	.3506	.3547	.3174	.3921
21	.2987	.3174	.3258	.3155	.3361	.2801	.362
22	.2801	.2801	.2801	.2804	.2987	.2987	.3258
23	.2427	.2241	.2427	.2454	.2801	.2614	.2353
24	.2172	.2241	.2241	.2241	.2454	.2534	.2241
Max	.3734	.3547	.3801	.3506	.3547	.3547	.4108
Min	.181	.1867	.1867	.1867	.2103	.2241	.2241
Avg	.2603	.2752	.2670	.2430	.2606	.2774	.2968

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

SHIROL[917]

BU 9148

Substation No/ Name :- 144090 / 33 / 11 KV Nandani

Substation

Feeder No / Name : 205 / 11KV Dharangutti Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0362	2.3712	2.3712	2.3525	.0351	.0373	.0373
2	.0362	2.3712	2.3712	2.3899	.0351	.0373	.0373
3	.0362	2.3899	2.3899	2.3899	.0351	.0373	.0373
4	.0362	2.2291	2.4272	2.4272	.0351	.0373	.0373
5	.0362	2.4086	2.4646	2.4272	.0351	.0373	.0373
6	.0362	2.4272	2.4646	2.5206	.0351	.0373	.0373
7	.0362	2.2462	2.5953	2.5579	.0351	.0373	.0373
8	.0362	.056	.0373	.0362	.0354	.0373	.0373
9	3.3608	.0373	.0373	.0362	.056	.0373	.0373
10	3.3608	.0373	.0358	.0358	.056	.0373	.0373
11	3.6035	.0373	.0358	.0354	3.1927	3.4541	3.6035
12	3.4355	.0373	.0354	.0354	3.4355	3.5288	3.6408
13	3.3794	.0373	.0362	.0354	3.4541	3.4541	2.3148
14	3.3608	.0373	.0362	.0354	3.5101	3.4728	3.5848
15	3.2674	.0373	.0362	.0351	3.4541	3.4541	3.5848
16	2.894	.0373	.0362	.0351	3.1741	3.4168	3.5662
17	.0373	.0373	.0362	.0351	3.1741	3.3608	3.6035
18	.0373	.0373	.0362	.0354	3.0807	3.3421	3.1554
19	.0373	.0934	.0362	.0354	.0373	.0373	.0362
20	.0373	.0373	.0362	.0362	.0343	.0373	.0362
21	.0373	.0373	.0362	.0351	.0373	.0373	.0362
22	2.4646	2.4272	2.4832	.0351	.0373	.0373	.0362
23	2.3712	2.4646	2.4832	.0351	.0373	.0373	.0362
24	.0362	2.3712	2.4272	2.3525	.0351	.0373	.0373
Max	3.6035	2.4646	2.5953	2.5579	3.5101	3.5288	3.6408
Min	.0362	.0373	.0354	.0351	.0343	.0373	.0362
Avg	1.3338	1.0126	1.0410	.8327	1.1286	1.1700	1.1519



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 201 / MINCHE AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2294	.7545	1.0364	.852	.2401	.1943	.1966
2	.2294	.7545	1.0364	.8192	.2401	.1943	.2035
3	.2294	.7377	1.0364	.8192	.2401	.1943	.2035
4	.2241	.7377	1.0364	.7865	.2401	.1943	.2035
5	.1966	.8048	1.0364	.7865	.2401	.1943	.2035
6	.2622	1.0059	1.0364		.2401	.2267	.2713
7	.1966	1.1736	1.166		.2572	.2267	.1966
8	.1966	.1943	.1619		.2374	.1943	.1966
9	1.2452	.1619	.1966		.2267	.2622	.2401
10	1.5074	.2591	.1966	.2743	.2591	.2374	.2401
11	1.4746	.2591	.1966	.2743	1.6194	1.704	1.4746
12	1.4091	.2591	.2294	.2743	1.6842	1.6712	1.4746
13		.2267	.1966	.2401	1.6194	1.5729	1.3435
14	1.2452	.2267	.1966	.2058	1.4899	1.4419	1.2452
15	1.1797	.1943	.1966	.2058	1.2955	1.4419	1.1469
16	1.1142	.2267	.1966	.1715		1.3763	1.3435
17	.2401	.2591	.2294	.2401		1.3108	1.3435
18	.2401	.2915	.2622	.2401	.6478	1.1797	1.278
19	.2949	.3239	.2622	.3086	.3239	.2713	.2294
20	.3086	.3239	.2949	.3429	.2591	.3155	.3086
21	.3086	.3239	.2949	.3429	.2591	.2949	.3086
22	.7377	.9686	.9503	.3086	.2591	.2949	.3086
23	.7377	1.0364	.9503	.2743	.2267	.2294	.2743
24	.2294	.7209	1.0364	.852	.2743	.1943	.2294
Max	1.5074	1.1736	1.166	.852	1.6842	1.704	1.4746
Min	.1966	.1619	.1619	.1715	.2267	.1943	.1966
Avg	.6103	.5094	.5597	.4310	.5627	.6424	.6027

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 202 / NARANDE Ag FEEDER

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1203	.1029	.0972	.096	.6554	.583	.8642
2	1.1203	.1029	.0972	.096	.6554	.583	.8642
3	1.0562	.1029	.0972	.096	.6554	.583	.8642
4	1.0562	.1029	.0972	.096	.6554	.583	.8642
5	.9922	.1029	.0972	.096	.8192	.6478	.8962
6	1.0883	.1029	.0972	.096	1.0159	.7773	.9922
7	1.1523	.1029	.0972	.096	1.278	1.2955	1.2803
8	.128	.1029	.1296	.112	1.2452	1.3927	1.4083
9	.1029	1.4251	1.4723	.1029	1.1336	1.2803	1.3763
10	.112	1.6194	1.6964	.1029	.0648	.0747	.0686
11	.1029	1.6842	1.7284	1.6385	.0648	.064	.0686
12	.112	1.749	1.6004	1.7695	.0648	.064	.0686
13	.1029	1.6518	1.5684	1.7695	.0648	.064	.0686
14	.1029	1.6194	1.5364	1.6712	.0648	.064	.0686
15	.1029	1.6194	1.4723	1.5729	.0648	.064	.0686
16	.1029	1.4899	1.4083	1.0486	.0648	.064	.0686
17	.1029	.0972	.064	1.3763	.0972	.064	.0686
18	.1029	.0972	.064	1.2498	.0648	.064	.1029
19	.1372	.112	.096	.1029	.0972	.128	.1029
20	.1372	.0972	.128	.1372	.0972	.128	.1372
21	.1372	.0972	.128	.1029	.0972	.128	.1372
22	.1372	.0972	.128	.1029	.1296	.128	.1372
23	.1372	.0972	.096	.1029	.1296	.096	.1029
24	1.1523	.1029	.0972	.096	.5898	.583	.7042
Max	1.1523	1.749	1.7284	1.7695	1.278	1.3927	1.4083
Min	.1029	.0972	.064	.096	.0648	.064	.0686
Avg	.4416	.6033	.5873	.5721	.4112	.3960	.4743

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 203 / KHOCHI AG FEEDER

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5729	.0686	.0648	.0655	1.3108	1.2308	1.4419
2	1.5729	.0686	.0648	.0663	1.3108	1.2308	1.4419
3	1.5729	.0686	.0648	.0655	1.3108	1.2308	1.4419
4	1.5402	.0686	.0648	.0655	1.3108	1.2308	1.4419
5	1.5074	.0686	.0648	.0655	1.3108	1.2955	1.4746
6	1.5729	.0686	.0648	.0655	1.4746	1.4575	1.5729
7	1.704	.0686	.0648	.0655	1.704	1.8138	1.8107
8	.0655	.0648	.0625	.0671	1.7695	1.8138	1.8778
9	.0686	2.2672	2.7526	.0686	1.7814	1.5074	1.8351
10	.0686	2.3967	2.6871	.0747	.0648	.0655	.0686
11	.0686	2.4291	2.8837	2.5232	.0648	.0655	.0686
12	.0686	2.4615	2.6216	2.6216	.0648	.0655	.0686
13	.0686	2.4615	2.5819	2.6216	.0648	.0655	.0686
14	.0686	2.4291	2.6155	2.556	.0648	.0655	.0686
15	.0686	2.3967	2.3472	2.4905	.0648	.0655	.0686
16	.0686	2.332	2.3472	2.0645	.0648	.0655	.0686
17	.0686	.0648	.0655	2.0645	.0648	.0655	.0686
18	.0686	.0648	.0655	2.0317	.0648	.0655	.0686
19	.0686	.0648	.0655	.0686	.0648	.0655	.0686
20	.0686	.0648	.0655		.0648	.0655	.0686
21	.0686	.0648	.0655	.0686	.0663	.0671	.0686
22	.0686	.0648	.0655	.0686	.0648	.0655	.0686
23	.0686	.0648	.0655	.0686	.0648	.0655	.0686
24	1.5729	.0686	.0648	.0655	1.3413	1.2308	1.3413
Max	1.704	2.4615	2.8837	2.6216	1.7814	1.8138	1.8778
Min	.0655	.0648	.0625	.0655	.0648	.0655	.0686
Avg	.5713	.8434	.9115	.8688	.6472	.6234	.6934

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 204 / BENDA VADE AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0663	1.7695	1.8564	1.5729	.0686	.0663	.0655
2	.0663	1.7695	1.8564	1.5729	.0686	.0663	.0655
3	.0663	1.7695	1.8564	1.5729	.0686	.0663	.0655
4	.0663	1.7695	1.8564	1.5729	.0686	.0663	.0655
5	.0663	1.7695	1.8564	1.5729	.0686	.0648	.0655
6	.0663	1.8351	1.8564	1.5729	.0686	.0663	.0655
7	.0663	1.8679	1.8564	1.7695	.0686		.0655
8	.0663	.0663	.0663	1.6385	.0686	.0663	.0655
9	2.4646	.0663	.0663	1.5729	.0648	.0663	.0686
10	2.4249	.0663	.0663	.0686	.0648	.0663	.0686
11	2.4249		.0671	.0686	2.332	2.6825	2.3594
12	2.4249		.0671	.0686	2.42	2.6155	2.3594
13	2.4143	.0663	.0671	.0686	2.3644	2.4905	2.2939
14	2.2611	.0663	.0663	.0686	2.332	2.2542	2.2611
15	2.1628	.0663	.0663	.0686	2.0729	2.3594	2.2283
16	2.0972	.0663	.0663	.0686	1.9433	2.3594	2.1956
17	.0686	.0663	.0671	.0686	2.0729	2.2283	2.1956
18	.0689	.0663	.0655	.0686	1.8351	2.0972	2.0972
19	.0686	.0663	.0655	.0686	.0655	.0655	.0686
20	.0343	.0663	.0671	.0686	.0648	.0655	.0686
21	.0686	.0663	.0663	.0686	.0663	.0655	.0686
22	1.8351	1.8564	1.7436	.0686	.0648	.0655	.0686
23	1.7695	1.8138	1.7436	.0686	.0663	.0655	.0686
24	.0663	1.7695	1.8564	1.6385	.0686	.0663	.0655
Max	2.4646	1.8679	1.8564	1.7695	2.42	2.6825	2.3594
Min	.0343	.0663	.0655	.0686	.0648	.0648	.0655
Avg	.9660	.8539	.8029	.7091	.7686	.8729	.7942

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 205 / BENDA VADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1463	.1494	.1448	.1463	.1867	.1448	.1829
2	.1463	.1494	.1448	.1463	.1867	.1448	.1829
3	.1463	.1494	.1448	.1463	.1867	.1448	.1829
4	.1463	.1494	.1448	.1463	.1867	.1448	.1829
5	.1463	.1867	.1448	.1463	.1867	.1448	.1829
6	.1829	.1867	.181	.1829	.2241	.181	.2195
7	.1463	.1867	.181	.1829	.2241	.2172	.2561
8	.1829	.1448	.1086	.1829	.1867	.181	.1829
9	.1494	.181	.1463	.1867	.1629	.1829	.1867
10	.1494	.1448	.1463	.1867	.1448	.1829	.1867
11	.1494	.1448	.1463	.1867	.1097	.1829	.1867
12	.1867	.1448	.1463	.1494	.1448	.1829	.1867
13	.2241	.1494	.1463	.1867	.1448	.2195	.1867
14	.1867	.1448	.1463	.2241	.181	.2195	.2241
15	.1867	.1494	.1463	.2241	.1448	.2172	.2241
16	.2241	.1494	.1463	.1867	.1448	.2195	.2241
17	.2241	.1448	.1829	.2241	.1448	.2195	.2241
18	.2241	.181	.1463	.2241	.181	.2195	.2241
19	.2614	.2241	.1829	.2614	.181	.2561	.2241
20	.2614	.2561	.2195	.2614	.2241	.2561	.2614
21	.2614	.2534	.1829	.2241	.2195	.2561	.2614
22	.2241	.2172	.1829	.2241	.2172	.2641	.2241
23	.1867	.181	.1829	.1867	.181	.2195	.1867
24	.1463	.1494	.1494	.1829	.1867	.1448	.1829
Max	.2614	.2561	.2195	.2614	.2241	.2641	.2614
Min	.1463	.1448	.1086	.1463	.1097	.1448	.1829
Avg	.1871	.1716	.1581	.1917	.1784	.1978	.2070

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 206 / Khochi Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.3361	.3734	.2987	.3361	.2241	.2987
2	.2987	.3361	.3239	.2987	.3361	.2241	.2987
3	.2987	.3361	.3734	.2987	.3361	.2241	.2987
4	.2987	.3361	.3734	.2987	.3361	.2241	.2987
5	.3361	.3361	.3734	.2987	.3361	.2241	.3361
6	.2987	.2987	.3734	.3734	.3361	.2614	.3734
7	.2614	.3361	.2987	.3361	.3361	.2987	.2587
8	.2218	.3361	.2987	.3734	.3361	.2241	.2987
9	.2614	.2915	.2926	.2241	.3361	.2241	.2987
10	.2614	.2987	.2561	.1867	.2896	.2241	.2614
11	.2614	.3361	.2241	.2987	.3734	.2614	.2614
12	.2614	.3734	.2614	.3361	.3361	.2926	.2987
13	.3361	.3361	.2614	.3361	.3361	.2987	.3361
14	.3361	.2987	.2614	.3361	.3361	.3361	.3361
15	.3361	.2987	.2987	.3361	.3361	.3361	.3361
16	.3361	.2987	.2987	.2987	.2987	.3361	.3361
17	.3361	.3361	.2987	.3361	.2987	.3292	.3361
18	.3361	.3734	.2987	.3361	.2987	.3292	.3734
19	.4108	.3734	.4108	.4481	.2926	.4108	.4108
20	.4481	.4481	.4481	.4854	.3361	.4481	.4481
21	.4108	.4481	.4481	.4854	.3361	.4481	.4481
22	.4108	.4481	.3734	.4481	.3361	.4108	.3734
23	.3734	.3734	.3734	.3734	.2987	.3734	.3361
24	.2957	.3361	.3734	.3361	.3361	.2241	.2987
Max	.4481	.4481	.4481	.4854	.3734	.4481	.4481
Min	.2218	.2915	.2241	.1867	.2896	.2241	.2587
Avg	.3219	.3467	.3320	.3407	.3277	.2995	.3313

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 207 / Narand Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.112	.112	.112	.112	.1132	.112
2	.112	.112	.112	.112	.112	.112	.112
3	.112	.112	.112	.112	.112	.1097	.112
4	.112	.112	.112	.112	.112	.1097	.112
5	.112	.1494	.1494	.112	.112	.1494	.112
6	.1494	.1494	.1494	.1494	.1494	.1494	.1494
7	.112	.1867	.112	.112	.1494	.1494	.1494
8	.112	.1494	.112	.112	.112	.112	.112
9	.112	.1494	.1494	.112	.112	.112	.112
10	.1494	.1494	.1494	.112	.112	.112	.112
11	.1494	.1867	.112	.112	.112	.1494	.112
12	.1494	.1867	.112	.1494	.1494	.1463	.1494
13	.1494	.1867	.112	.112	.1494	.112	.1494
14	.1494	.1867	.1494	.1494	.1494	.112	.1494
15	.1494	.1494	.112	.112	.1494	.1494	.1494
16	.1494	.1494	.112	.112	.1494	.1127	.1494
17	.1494	.1494	.1494	.112	.1494	.1494	.1494
18	.1494	.1494	.1494	.1494	.112	.1494	.1494
19	.1867	.1867	.1867	.2241	.1867	.1867	.1867
20	.2241	.1867	.2241	.2241	.1867	.1867	.2241
21	.2241	.1867	.1867	.1867	.1867	.1867	.1867
22	.1867	.1494	.1867	.1867	.1494	.1867	.1867
23	.1494	.1494	.1494	.1494	.112	.1494	.1494
24	.112	.1494	.112	.1494	.1494	.112	.1494
Max	.2241	.1867	.2241	.2241	.1867	.1867	.2241
Min	.112	.112	.112	.112	.112	.1097	.112
Avg	.1447	.1556	.1385	.1369	.1369	.1382	.1432

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 208 / Minche Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3292	.3734	.3734	.2926	.3361	.2926	.2926
2	.3292	.3734	.3734	.2926	.3361	.2987	.2926
3	.3292	.3361	.3734	.2926	.3361	.2926	.2926
4	.3292	.3361	.3734	.2926	.3361	.2987	.2926
5	.3658	.3361	.4108	.2926	.3734	.3361	.3292
6	.4024	.3734	.4481	.3658	.3734	.3734	.3658
7	.3734	.3734	.3734	.2926	.3734	.3734	.3658
8	.3658	.3734	.3734	.3658	.2987	.2987	.2926
9	.3734	.3734	.3658	.2987	.2987	.2926	.3361
10	.3734	.3658	.3292	.3361	.2987	.2926	.3361
11	.3734	.3734	.3658	.3734		.3658	.2987
12	.3361	.3734	.3734	.3734		.2835	.3734
13	.3734	.2987	.2926	.3361		.3292	.3734
14	.3361	.2591	.3292	.2987		.2926	.3734
15	.3734	.3361	.3658	.2987		.3292	.3734
16	.3734	.3734	.3292	.2987	.2987	.3292	.3734
17	.3734	.3734	.3292	.3734	.2987	.3658	.3734
18	.3734	.4481	.3658	.4108	.2987	.3658	.3734
19	.5228	.5228	.439	.5228	.4481	.4805	.5228
20	.5601	.5975	.5121	.5601	.5228	.5228	.5601
21	.5228	.5228	.439	.5228		.5121	.5228
22	.4854	.4854	.439	.4481	.4481	.4755	.4481
23	.4108	.4481	.3658	.3734	.3734	.3658	.4108
24	.3292	.3734	.4108	.3292	.3361	.2987	.3361
Max	.5601	.5975	.5121	.5601	.5228	.5228	.5601
Min	.3292	.2591	.2926	.2926	.2987	.2835	.2926
Avg	.3881	.3917	.3813	.3601	.3547	.3527	.3712



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 209 / 11KV Buwache Wathar AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4243	.0686	.0312	.0747	1.3108	1.2631	1.4339
2	1.4243	.0686	.0312	.0747	1.3108	1.2631	1.4339
3	1.4243	.0686	.0312	.0747	1.3108	1.2631	1.4243
4	1.4243	.0686	.0312	.0747	1.3108	1.2631	1.4243
5	1.3904	.0686	.0648	.0747	1.3108	1.3279	1.4582
6	1.4243	.0686	.0625	.0747	1.4091	1.4251	1.3904
7	1.4243	.0678	.0625	.0747	1.5402	1.587	1.5261
8	.0732	.0686	.0625	.0683	1.5074	1.587	1.5939
9	.0686	1.7497	1.9802	.0686	1.4899	1.7071	1.5729
10	.0686	1.6842	2.0485	.0686	.0324	.0683	.0678
11	.0686	1.7166	2.0143	1.9334	.0312	.0747	.0686
12	.0686	1.7166	1.9119	1.9662	.0305	.0747	.0686
13	.0686	1.749	1.8095	1.9662	.0324	.0747	.0686
14	.0686	1.749	1.8778	1.9662	.0312	.0747	.0686
15	.0686	1.749	1.8095	1.9334	.0305	.0747	.0686
16	.0686	1.9418	1.8095	1.4091	.0312	.0747	.0686
17	.0686	.0312	.0762	1.6385	.0305	.0747	.0686
18	.0686	.0312	.0747	1.6385	.0312	.0747	.0686
19	.0686	.0312	.0747	.0686	.061	.0747	.0689
20	.0686	.0625	.0747	.0686	.061	.0747	.0686
21	.0686	.061	.0747	.0686	.0305	.0747	.0686
22	.0686	.0312	.0747	.0686	.0305	.0747	.0686
23	.0686	.0312	.0747	.0686	.0312	.0747	.0686
24	1.4339	.0686	.0324	.0747	1.3032	1.2631	1.2163
Max	1.4339	1.9418	2.0485	1.9662	1.5402	1.7071	1.5939
Min	.0686	.0312	.0312	.0683	.0305	.0683	.0678
Avg	.5197	.623	.6748	.6499	.5958	.6245	.6431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 210 / Khandoba AG (Bhendwade) SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0316	.9831	.9069	.8642	.0343	.0312	.0316
2	.0316	1.0059	.9069	.8642	.0343	.0312	.0316
3	.0316	1.0059	.9069	.8642	.0343	.0312	.0316
4	.0316	1.0059	.9069	.8642	.0343	.0312	.0316
5	.0316	.9831	.9069	.8642	.0343	.0312	.0316
6	.0316	1.0159	.9069	.8322	.0343	.0312	.0316
7	.0316	1.0159	.9069	.8962		.0316	.0316
8	.0316	.0343	.0324	.8322	.0343	.0316	.0316
9	1.1142	.0305	.0316	.852	.0312	.0316	.0343
10	1.2452	.0312	.0316	.0343	.0312	.0341	.0343
11	1.1797	.0324	.0316	.0343	1.0311	1.2291	1.2125
12	1.1142	.0324	.0316	.0343	1.0974	1.2974	1.2125
13	1.0814	.0312	.0316	.0343	1.0936	1.1702	1.2125
14	1.0814	.0312	.0316	.0343	1.0059	1.1843	1.1797
15	1.0486	.0312	.0316	.0343		1.1843	1.1797
16	1.0159	.0312	.0316	.0343		1.1843	1.1469
17	.0343	.0312	.0312	.0343	.9717	1.1523	1.1469
18	.0343	.0312	.0312	.0343	.6478	1.0753	1.1142
19	.0343	.0312	.0312	.0343	.0306	.0316	.0339
20	.0343	.0316	.0316	.0343	.0312	.0316	.0343
21	.0343	.0324	.0316	.0343	.0312	.0316	.0343
22	.9831	.8745	.9282	.0343	.0312	.0316	.0343
23	1.0288	.9069	.8962	.0343	.0312	.0316	.0343
24	.0316	.9831	.9069	.8642	.0343	.0324	.0316
Max	1.2452	1.0159	.9282	.8962	1.0974	1.2974	1.2125
Min	.0316	.0305	.0312	.0343	.0306	.0312	.0316
Avg	.4729	.4260	.3967	.3783	.3019	.4160	.4137

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144046 / 33/11 KV SAWARDE S/STN

Feeder No / Name : 401 / 33 kv Sharad Co-gen

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.2675	4.3256	4.481	4.8285	4.5268	5.2675	4.1701
2	5.048	4.3256	4.9291	4.9383	4.5268	5.5441	4.0604
3	5.487	4.3256	5.048	4.7188	4.5268	5.1532	4.3896
4	5.3772	4.3256	4.8285	5.048	4.5268	5.2675	4.6091
5	5.2675	4.3256	4.6091	5.3772	4.5268	5.7065	3.2922
6	5.487	4.3256	4.8285	5.2675	5.0297	5.8253	4.7188
7	4.8285	5.8345	4.8285	4.1701	6.0357	5.7659	6.5844
8	4.8285	5.0297	4.9291	4.3896	5.0297	6.5844	6.1454
9	5.0297	5.3772	.1097	4.225	6.7215	5.487	5.4321
10	4.225	4.1747	4.9383	4.8285	5.487	4.0604	3.5208
11	4.9154	5.4893	4.9383	4.8285	.439	4.2798	3.6008
12	5.0297	6.4975	4.8285	5.0297	.823	6.5844	6.0357
13	4.8171	6.1614	4.9383	5.0297	.2241	5.3772	6.0357
14	4.0238	5.6013	4.8285	5.0297	.5487	5.487	6.0357
15	5.0297	5.2675	5.487	4.0238	.5487	5.9259	3.0178
16	5.0297	4.7051	5.487		.5316	6.1454	4.5268
17	4.5268	4.7188	4.3896	4.3256	.6584	5.487	4.5268
18	4.5268	4.9291	4.3896	4.225	.8962		
19	4.0238	4.8285	4.1701	4.4262	.3361		
20	4.1152	4.9794	4.1701	4.0238	.2241		
21	4.0238	4.7817	4.8285	4.0238	.4481	4.3896	
22	4.3256	5.487	5.048	4.0238	.6584	2.6337	
23	4.3256	4.481	5.2675	4.1152	2.0165	4.8285	
24	4.8285	4.3256	4.7051	5.1578	4.0238	5.2675	4.8285
Max	5.487	6.4975	5.487	5.3772	6.7215	6.5844	6.5844
Min	4.0238	4.1747	.1097	4.0238	.2241	2.6337	3.0178
Avg	4.7661	4.9426	4.6252	4.6110	2.6381	5.2889	4.7517

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 201 / 11KV Bhokari (Bhadole) AG SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.278	.0305		.0191	1.3272	1.2163	1.1717
2	1.247	.0305		.0191	1.3108	1.2163	1.1873
3	1.2308	.0305		.0191	1.3108	1.2163	1.1873
4	1.2308	.0305		.0191	1.3435	1.1843	1.2186
5	1.1984	.0305		.0191	1.3927	1.186	1.2342
6	1.1984	.0305		.0191	1.491	1.4232	1.2654
7	1.2631	.0305		.0191	1.5729	1.4864	1.3592
8	.0324	.0305		.0191	1.5565	1.5364	1.406
9	.0324	1.7604	1.7497	.0191		1.4883	1.406
10	.0324	1.8084	1.8084	.0191	.0324	.0305	
11	.0191	1.8435	1.8404	1.8564		.0324	.0191
12	.0191	1.7497	1.7924	1.7924		.0324	.0191
13	.0191	1.7185	1.7604	1.7976		.0324	.0191
14	.0191	1.7185	1.6964	1.7604		.0324	.0191
15	.0191	1.6872	1.6324	1.7124		.0324	.0191
16	.0191	1.6872	1.5844	1.4723		.0324	.0191
17	.0191		.0191	1.5844	.0191	.0324	.0191
18	.0305		.0191	1.5684	.0191		.0191
19	.0305		.0286	.0324	.0305		.0324
20	.0305		.0286	.0324	.0305		.0324
21	.0305		.0191	.0324	.0305		.0324
22	.0305		.0229	.0324	.0305		.0324
23	.0305		.0191	.0324	.0305		.0324
24	1.2631	.0305		.0191	1.2308	1.0911	1.2146
Max	1.278	1.8435	1.8404	1.8564	1.5729	1.5364	1.406
Min	.0191	.0305	.0191	.0191	.0191	.0305	.0191
Avg	.4301	.8381	.9347	.5799	.7505	.7390	.5637

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 202 / 11KV Latwade AG Fdr

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0486	1.7284	1.8351	1.6518	.0486	.0457	
2	.0486	1.7124	1.8023	1.6518	.0486	.0457	
3	.0486	1.6762	1.8023	1.6194	.0486	.0457	
4	.0486	1.6762	1.8351	1.6194	.0486	.0457	
5	.0486	1.7553	1.8679	1.587	.0486	.0457	
6	.0486	1.7764	1.8842	1.587	.0486	.0457	
7	.0486	1.7869	1.917	1.6842	.0486	.0457	
8		.0457		1.6032	.0648	.0457	
9	.0486	.0457		1.6356	.0486	.0457	
10	2.1214	.0457	.0191	.0191	.0486	.0457	
11	2.3158		.0286	.0457	2.0645	2.3266	2.2186
12	2.2834		.0191	.0457	2.1628	2.343	2.2024
13	2.251		.0191	.0457	2.2283	2.2611	2.0567
14	2.1538		.0191	.0457	2.2119	2.1628	2.0481
15	2.1214			.0457	2.2283	2.1956	2.0081
16	2.1052			.0457	2.0645	2.1956	2.1052
17	.0191			.0457	2.0081	2.1506	2.0081
18	.0457		.0191	.0457	1.9109	2.1956	1.8842
19	.0457		.0286	.0486	.0457		.0486
20	.0457		.0286	.0486	.0457		.0486
21	.0457		.0286	.0486	.0457		.0486
22	1.7924	1.8842	1.6518	.0486	.0457		.0486
23	1.7924	1.917	1.6194	.0486	.0457		.0486
24	.0486	1.7604	1.8842	1.6194	.0486	.0457	
Max	2.3158	1.917	1.917	1.6842	2.2283	2.343	2.2186
Min	.0191	.0457	.0191	.0191	.0457	.0457	.0486
Avg	.8511	1.3700	.9636	.7036	.7358	.9649	1.2903

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 203 / 11KV Latwade Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4163	.4119	.4572	.4344	.4344	.3898	.4755
2	.4344	.394	.4572	.4163	.3982	.394	.4572
3	.3982	.3761	.439	.4163	.3982	.3761	.439
4	.4525	.3761	.439	.4706	.4344	.3761	.439
5	.5068	.443	.4755	.4908	.5068	.4477	
6	.6154	.567	.5853	.6697	.5973	.567	.5853
7	.6154	.6201	.6767	.5973	.543	.6201	.6584
8	.5973	.567	.5853	.5249	.4887	.5609	.6036
9	.5068	.5434	.5853	.5973	.4525	.5316	.5853
10	.543	.567	.543	.5792	.5249	.5784	.5487
11	.5973	.5853	.543	.5493	.5121	.5792	.5611
12	.6335	.6219	.5611	.567	.5304	.5973	.6154
13	.6335	.5853	.543	.5258	.5487	.6516	.6154
14	.6154	.5853	.543	.5434	.5304	.5973	.6154
15	.6154	.5853	.5611	.567	.5121	.5792	.5973
16	.5973	.5487	.543	.4557	.5487	.6154	.6154
17	.5973	.5853	.543		.5068	.543	.6154
18	.691	.5853	.5249	.6024	.5068	.6219	.543
19	.7011	.695	.6878	.6878	.6024	.7133	.6878
20	.7011	.6584	.724	.6516	.6485	.695	.7964
21	.631	.6219	.6335	.6697	.6379	.695	.724
22	.5847	.5853	.6154	.6154	.5847	.6767	.5249
23	.5121	.5304	.5249	.5068	.5138	.5487	.4887
24	.4344	.443	.4755	.4344	.4344	.4075	.4938
Max	.7011	.695	.724	.6878	.6485	.7133	.7964
Min	.3982	.3761	.439	.4163	.3982	.3761	.439
Avg	.5680	.5451	.5528	.5467	.5165	.5568	.5777

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 204 / Laxmi AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6241	.061		.0191	.5944	.7116	.6706
2	.5944	.061		.0191	.5944	.7116	.6706
3	.5944	.061		.0191	.5944	.7116	.6859
4	.5647	.061		.0191	.6241	.68	.7164
5	.5647	.061		.0286	.6241	.7274	.7316
6	.5796	.061		.0191	.6539	.7811	.7621
7	.639	.061		.0191	.8322	.7968	.8535
8	.0297	.061		.0191	.8619	.9172	.884
9	.0446	1.1683	1.2193	.0286	.7727	.933	.9145
10	.0594	1.1702	1.2631	.0286	.0297	.061	
11	.0191	1.1888	1.1888	1.3592		.0297	.0191
12	.0191	1.0974	1.1294	1.3748		.0297	.0191
13	.0286	1.0669	1.0402	1.1873		.0446	.0191
14	.0191	1.0364	1.0105	1.1873		.0446	.0191
15	.0381	.9297	.9511	1.1544		.0297	.0191
16	.0191	.9145	.8916	.9014		.0297	.0191
17	.0191		.0191	.9646	.0191	.0297	.0191
18	.0457		.0191	.9014	.0191		.0191
19	.061		.0191	.0297	.061		.0297
20	.061		.0286	.0297	.061		.0297
21	.061		.0286	.0297	.061		.0446
22	.061		.0286	.0297	.061		.0594
23	.061		.0286	.0297	.061		.0446
24	.639	.061		.0286	.5647	.6562	.6706
Max	.639	1.1888	1.2631	1.3748	.8619	.933	.9145
Min	.0191	.061	.0191	.0191	.0191	.0297	.0191
Avg	.2269	.5365	.5910	.3928	.3939	.4403	.3444

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 144081 / 33/11KV Latwade Sub station

Feeder No / Name : 205 / Tasgaon LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1457	.2949	.3086	.2401	.2267	.2401
4	.1457	.3018	.3086	.2401	.2267	.3086
5	.1457	.2949	.3086	.2401	.2294	.3086
6	.1457	.3018	.3086	.2401	.2294	.3086
7	.1457	.3018	.3086	.2401	.2294	.3086
8	.1457	.2949	.2572	.2401	.2294	.3086
9	.1457	.2949	.2401	.2401	.2294	.3086
10	.1457	.2949	.2401	.2401	.2294	.3086
11	.1715	.3258	.2401	.2515	.2267	.3086
12	.3258	.3258	.2401	.2515	.2267	.3086
13	.3258	.3258	.2401	.2458	.3077	.3086
14	.3258	.3258	.2401	.2294	.3077	.3086
15	.3258	.3258	.2401	.2294	.3077	.3086
16	.3258	.3258	.2401		.3077	.3258
17	.3258	.3086	.2401	.2294	.3077	.3258
18	.3018	.3086	.2401	.2294	.3086	.3258
Max	.3258	.3258	.3086	.2515	.3086	.3258
Min	.1457	.2949	.2401	.2294	.2267	.2401
Avg	.2246	.3095	.2626	.2391	.2581	.3075



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 201 / SUT GIRNI FEEDER

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 202 / GHUNKI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.6097
Max	.6097
Min	.6097
Avg	.6097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 204 / VADGAON Vg FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 208 / BHADOLE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 405 / 33 KV R.M Mohite

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 409 / 33 KV Preetam Enterprises NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

JAYASINGPUR DIVISION[503]

VADGAON[032]

BU 1198

Substation No/ Name :- 146008 / 110/33/11KV K.Wathar S/Stn.

Feeder No / Name : 410 / 33 KV KODOLI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	6.1728
Max	6.1728
Min	6.1728
Avg	6.1728

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 201 / 11 KV KATALI VILLAGE  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0914	.9945	.703	.7316	.1086	.0838	.0895
2	.0724	.9431	.7343	.7282	.0914	.0829	.0886
3	.0709	1.0269	.7343	.7392	.0914	.0829	.0716
4	.0701	1.0288	.7421	.7499	.0905	.0838	.0701
5	.0857		.8507	.7392	.1086	.0914	.104
6	.1187	.8859	.8688	.7682	.2865	.1524	.1715
7	.2883	1.0174	1.0136	.8048	.3439	.2623	.3018
8	.373	.4668	.4163	.815	.2012	.2743	.3521
9	.2915	.4435	.3658	.4382	.3142	.2896	.3521
10	.3292	.4887	.3898	.4287	.6653	1.2269	1.046
11	.3366	.4115	.3982	.3772	1.0498	1.5257	.964
12	.3189	.3725	.1802	.2883	1.0341	1.5565	1.4217
13	.3189	.3201	.3315	.2683	.9991	1.4937	
14	.2896	.2688	.3018	.2347	.9922	1.3717	1.2269
15	.2713	.2915	.2683	.2374	.9882	1.2309	1.2309
16	.3018	.2812	.3521	.3185	1.0056	1.3466	1.2445
17	.3605	.3163	.3315	.2374	.964	1.4148	1.3112
18	.3018	.3479	.2984	.3121	1.0808	1.2136	1.1765
19		.3361	.3391	.3506	.3045	.373	.3582
20	.3361	.3353	.3142	.3761	.3294	.3391	.3881
21	.3361	.2241	.5544	.3109	.2915	.2743	.2587
22	1.2071	.9835	1.0566	.3326	.12	.2012	.2075
23	1.1576	.9326	.7701	.3439	.104	.1214	.1132
24	.112	1.0288	.8383	.0573	.362	.0838	.1052
Max	1.2071	1.0288	1.0566	.815	1.0808	1.5565	1.4217
Min	.0701	.2241	.1802	.0573	.0905	.0829	.0701
Avg	.3235	.5976	.5481	.4578	.4970	.6324	.5502



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 202 / 11 KV GAGAN BAWADA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0549	.0373	.0686	.0549	.0543	.0671	.0537
2	.0543	.0373	.0716	.056	.0549	.0663	.0532
3	.0532	.0373	.0716	.0554	.0549	.0663	.0537
4	.0526	.0373	.0724	.0549	.0543	.0671	.0701
5	.0514	.0686	.0724	.0739	.0537	.061	.0693
6	.0678	.0709	.0724	.0732	.0716	.061	.0686
7	.0509	.0686	.0724	.0732	.0724	.0772	.0671
8	.0678	.0747	.0905	.0886	.0732	.0762	.0838
9	.0732	.0739	.0914	.0848	.0739	.061	.0671
10	.0709	.0724	.0709	.0686	.0739	.0701	.0686
11		.0857	.0724	.0686	.0724	.0693	.0876
12	.0709	.0648	.0655	.0848	.0876	.0905	.0693
13	.0686	.096	.0663	.0678	.0876	.112	
14	.0709	.0791	.0671	.0671	.0709	.1097	.0701
15	.0678	.081	.0671	.0678	.0867	.0867	.0693
16	.0671	.0625	.0671	.0678	.0693	.0886	.0876
17	.0739	.0633	.0663	.0678	.1052	.0895	.0709
18	.0671	.0633	.0663	.0867	.0886	.0934	.0905
19	.1017	.08	.0848	.1052	.1075	.1017	.1086
20	.112	.1006	.1294	.1254	.1214	.1017	.1294
21	.112	.096	.1109	.1097	.1029	.12	.112
22	.0914	.0848	.0895	.0924	.1029	.1006	.1132
23	.0732	.0678	.0886	.0724	.0867	.0867	.0943
24	.0747	.0373	.0671	.0716	.0724	.0671	.0701
Max	.112	.1006	.1294	.1254	.1214	.12	.1294
Min	.0509	.0373	.0655	.0549	.0537	.061	.0532
Avg	.0717	.0684	.0776	.0766	.0791	.0830	.0795

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 203 / 11 KV Andur Gaothan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0366	.0934	.0514	.0549	.0362	.0503	.0537
2	.0362	.0747	.0537	.056	.0366	.0497	.0532
3	.0354	.0747	.0543	.0554	.0366	.0497	.0537
4	.0354	.0857	.0543	.0549	.0362	.0503	.0526
5	.0526	.1029	.0543	.0739	.0537	.061	.0693
6	.0678	.12	.0905	.0914	.1075	.0914	.1029
7	.1017	.12	.1086	.1097	.1448	.108	.1341
8	.1017	.1307	.1448	.1417	.128	.1219	.1174
9		.1109	.1463	.1357	.1294	.1067	.1174
10	.0934	.1267	.124	.0678	.1294	.1402	.1029
11	.1097	.1029	.1086	.0848	.1267	.1214	.1052
12	.124	.0972	.0983	.0678	.0876	.1086	.104
13	.0886	.08	.0829	.1017	.0876	.1307	
14	.0914	.0791	.1006	.1006	.0886	.1097	.1052
15	.0848	.081	.1006	.1017	.104	.1214	.104
16	.1017	.0781	.1174	.1174	.0693	.124	.1052
17	.12	.0949	.116	.1187	.1052	.1433	.124
18	.1174	.0949	.0995	.1214	.124	.1307	.1254
19	.1357	.128	.1357	.1402	.1254	.1357	.0181
20	.1494	.1341	.1478	.1612	.1214	.1357	.1478
21	.168	.128	.1294	.1463	.1372	.12	.1307
22	.1307	.1017	.0895	.1109	.1029		.1132
23	.112	.0848	.0709	.0724	.0693	.0867	.0754
24	.056	.1097	.0671	.0537	.0543	.0503	.0701
Max	.168	.1341	.1478	.1612	.1448	.1433	.1478
Min	.0354	.0747	.0514	.0537	.0362	.0497	.0181
Avg	.0935	.1014	.0978	.0975	.0934	.1021	.0950

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 204 / 11 KV KATALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.0187	.0171	.0183	.0181	.3353	.3582
2	.2896	.0187	.0179	.0187	.0183	.2984	.3898
3	.3189	.0187	.0179	.0185	.0181	.2984	.394
4	.3155	.0187	.0181	.0183	.0183	.3018	.3681
5	.2915	.0171	.0181	.0185	.0179	.3048	.3814
6	.3391	.0183	.0181	.0183	.0181	.3658	.4115
7	.407	.0187	.0181	.0183	.0183	.4938	.4694
8	.5087	.0187	.0181	.0177	.0185	.4572	.503
9	.567	.0183	.0183	.017	.0185	.4877	.4694
10	.0183	.0181	.0177	.3391	.0181	.0175	.0171
11	.0183	.0171	.0181	.4458	.0181	.0173	.0175
12	.4961	.5668	.6226	.6104	.0175	.0181	.0173
13	.5144	.5761	.6796	.5868	.0175	.0187	
14		.5693	.6371	.5365	.0177	.0183	.0175
15	.5596	.583	.5868	.5087	.0173	.0173	.0173
16		.5624	.57	.5365	.0171	.0177	.0175
17	.5533	.506	.5967	.5087	.0175	.0179	.0177
18	.503	.5693	.5801	.0173	.0177	.0187	.0181
19	.4748	.4481	.5426	.0175	.0179	.017	.0181
20	.5228	.0168	.0185	.0179	.0173	.017	.0185
21		.016	.0185	.0183	.0171	.0171	.0187
22	.0164	.017	.0179	.0185	.0173	.0168	.0189
23	.0187	.017	.0177	.0181	.2683	.0173	.0189
24	.2614	.0187	.0168	.0179	.0181	.2683	.3155
Max	.567	.583	.6796	.6104	.2683	.4938	.503
Min	.0164	.016	.0168	.017	.0171	.0168	.0171
Avg	.3460	.1945	.2126	.1817	.0283	.1608	.1867

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144006 / 33/11 KV GAGANBAWDA S/STN

Feeder No / Name : 205 / 11 KV ANDUR AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18
HR	Load (MW)	Load (MW)	Load (MW)
1	1.0608	.0187	.0171
2	1.086	.0187	.0179
3	1.0631	.0187	.0179
4	1.0867	.0171	.0181
5	1.0974	.0187	.0181
6		.0183	.0181
7		.0187	.0181
8	.9835	.0187	.0181
9		.0185	.0183
10	1.7147	.0181	.0177
11	2.0553	1.989	.0181
12	2.2148	2.2024	2.1136
13	2.1434	2.3045	2.2542
14	2.4806	2.2613	2.1795
15	2.3739	2.2348	2.146
16	2.1795	1.9685	2.0119
17	2.1795	2.0715	2.1714
18	2.1795	1.8027	2.1216
19	2.1195	1.7604	2.0008
20	.0187	.0168	
21	.0187	.016	
22	.0187	.017	
23	.0187	.017	
24	1.0642	.0171	.0168
Max	2.4806	2.3045	2.2542
Min	.0187	.016	.0168
Avg	1.3884	.7860	.8607

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 201 / 11 KV Rasai Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0181		3.4294	1.6766	.0191		.2667
2	.0191		3.4294	1.6956	.0191		.2667
3	.0191		3.4294	1.7147	.0191		.2667
4	.0179		3.4294	1.7147	.0191		.2667
5	.0173		3.2769	1.7147	.0191		.2858
6	.0191		3.2388	1.9052	.0191		.2858
7	.0183		3.0483	2.4387	.0191	2.0182	.3429
8	.0191	2.999	3.1055	2.934	.0191	2.1502	.3429
9	.0191	4.2438	2.8959		.0191	2.037	.2667
10	.0191	3.9798	.0191	1.2384	.0191	.0377	.0572
11	.0191	3.9798	.0191	3.5648	.0191	.0185	.0572
12	.0168	.0166		3.9609	.0572		.0572
13	.0191	.0181	.0191	3.8289	.0191		
14	.0191	.017	.0191	1.1694	.0191		
15	.0191	.017			.0191	.0191	
16			.0191			.0191	
17	.0191		.0191	3.7677	.0191	.0191	
18	.0191		.0953	3.786	.0191	.0191	.0191
19	.0191	.0572	.1143	3.5818	.0381	.0191	.0191
20	.0191	.0572	.1143		.0381	.0191	.0191
21	.0191	.0381	.1143		.0381	.0191	
22	.0191	2.1338	.0572	.0191	.0381	.0191	
23	.0191	3.2388	.0572	.0191	.0381	3.2769	
24	.0191		3.5056		.0191	2.7915	
Max	.0191	4.2438	3.5056	3.9609	.0572	3.2769	.3429
Min	.0168	.0166	.0191	.0191	.0191	.0185	.0191
Avg	.0188	1.5997	1.5207	2.2628	.0249	.8322	.1880

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 202 / 11 KV Tisangi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2037		.0648	.0381			1.2163
2	1.2186		.061	.0591	.0633		1.2003
3	1.2492		.061	.06	.0633		1.2003
4	1.25		.061	.0372	.0625		1.2003
5	1.3123		.0648	.0581	.0633		1.6004
6	1.5123		.092	.1052	.0949		1.7284
7	2.0119	.1905	.1372	.1296	.1235	2.6482	2.3045
8	2.4371	.1905	.1315	.1296	.1406	2.7435	2.2405
9	2.0348	.1905	.1334	.1488	.1372	2.5911	2.3045
10	.2204	.2286	.1692	1.9204	.1406	.2096	.1932
11	.218	.1623	.1783	2.9912	.1252	.1739	.2286
12	2.652	2.2558		3.1626	.1052	.1718	.2096
13	2.7515	2.2253	2.0729	3.2579	.0934	.1698	
14	2.8012	2.652	2.5587	3.2007	.1189	.1562	.1524
15	2.7515	2.2253			.1082	.1852	
16	2.5301	2.2558	2.625		.1067	.1875	
17		2.5606	2.6402	2.4326	.1235	.1698	.2096
18	2.915	2.4249	2.5606		.1715	.16	.1543
19	2.6292	2.2939	2.4985	.1852	.2667	.2408	.2187
20	2.4768	.1555	.2164		.2667	.2086	.2343
21	.2286	.1981	.1867		.2286	.208	
22	.1715	.12	.1046	.128	.1905	.1362	
23	.1334	.0975	.0469	.0772	.1334	.0914	
24	1.2346	.0953	.0743	.0305	.0772	1.7147	.9739
Max	2.915	2.652	2.6402	3.2579	.2667	2.7435	2.3045
Min	.1334	.0953	.0469	.0305	.0625	.0914	.1524
Avg	1.6497	1.1401	.7609	.9554	.1306	.6759	.9761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 203 / 11 KV Shenawade AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3146		.0191	.0191	1.4998		.0191
2	1.3003		.0191	.0191	1.4217		.0191
3	1.3321		.0191	.0191	1.4403		.0191
4	1.3496		.0191	.0191	1.8652		.0191
5	1.4327		.0191	.0191	1.9244		.0191
6	1.6655	.0191	.0191	.0191	2.0233		.0191
7	2.1312	.0191	.0191	.0191	2.1498		.0191
8	2.3579	.0191	.0191	.0191	2.2291	.0191	.0191
9	2.2801	.0191	.0191	.0191	2.3059	.0191	.0191
10	.0191	.0191	.0191	.0191	2.3838	1.56	1.6194
11	.0191	.0191	.0191	.0191	2.553	2.5206	2.5034
12	2.3703	2.3205		.0191	2.6673	2.8953	2.8433
13	2.4352		2.774	.0191	2.6673	2.8807	
14	2.5526		2.5941			2.8656	2.7393
15		2.4577			2.8197	2.8978	
16	2.4291	2.4291			2.7054	2.9473	
17	2.3434	3.0483		.0191	2.5149	2.7606	2.6006
18	2.3569	2.8197	1.6385	.0191	.0191	.0191	.0175
19	2.1874	2.5911	1.6766	.0191	.0191	.0191	.0191
20	2.1534	.0191	.0191		.0191	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	1.3176	.0191	.0191	.0191
24	1.3523	.0191	.0191	.0191	1.4175	.0191	.0191
Max	2.5526	3.0483	2.774	1.3176	2.8197	2.9473	2.8433
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0175
Avg	1.5409	.9339	.4494	.0874	1.5958	1.2647	.6295

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 204 / 11 KV TISANGI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191		.0191		.0191
2	.0191	.0191	.0191	.0191	.0191		.0191
3	.0191	.0191	.0191	.0191	.0191		.0191
4	.0191	.0191	.0191	.0191	.0191		.0191
5	.0191	.0191	.0191	.0191	.0191		.0191
6	.0191	.0191	.0191	.0191	.0191		.0191
7	.0191	.0191	.0191	.0191	.0191		.0191
8	.0191	.0191	.0191	.0762	.0191	.0191	.0191
9	.0191	.0191	.0191	.0191	.0191	.0191	.0191
10	.0191	.0191	.0191	.0191		.0191	.0191
11	.0191	.0191	.0191	.0191	.0191	.0191	
12	.0191	.0191	.0191	.0191	.0191	.0191	.0191
13	.0191	.0191	.0191	.0762	.0191	.0191	
14	.0191	.0191	.0191	.0191	.0191	.0191	.0191
15	.0191	.0191	.0191		.0191	.0191	.0191
16	.0191	.0191	.0191		.0191	.0191	
17	.0191	.0191	.0191		.0191	.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191		.0191	.0191	.0191
21	.0191	.0191	.0191		.0191	.0191	.0191
22	.0191	.0191	.0191	.0762	.0191		
23	.0191	.0191	.0191	.0191	.0191		
24	.0191	.0191	.0191	.0191	.0191		.0191
Max	.0191	.0191	.0191	.0762	.0191	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.0191	.0191	.0191	.0286	.0191	.0191	.0191



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 205 / 11 KV RASAI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171		.0171	.0152	.0171		.017
2	.0171		.0171	.0152	.0175		.0152
3	.0173		.0173	.0149	.0177		.0152
4	.0175		.017	.0149	.0179		.017
5	.0343		.016	.0149	.0171		.0373
6	.0354	.0566	.032	.0305	.0343		.0762
7	.0686	.0754	.096	.0762	.0678	.0566	.0953
8	.0867	.0754	.096	.1143	.0838	.0754	.0953
9	.0848	.0754	.1143		.0655	.0754	.0762
10	.0686	.0566	.0953	.0572	.0633	.0566	.0381
11	.0686	.0566	.0543	.0566	.0373	.0554	
12	.0678	.0492		.0377	.0343		.0566
13	.0663	.0497	.0343	.0566	.0381		
14	.0671	.0486	.0343	.0566	.0381		
15	.0655	.0474			.0191	.0532	
16	.0328					.0537	
17	.032		.0343	.0554	.0191	.0867	
18	.0905		.0312	.0537	.0943	.0953	.0554
19	.1097	.1334	.1143	.0886	.0943		.1097
20	.112	.1715	.1334		.0943	.1132	.1063
21	.0943	.1334	.1334		.0754	.1143	
22	.056	.0381	.0762	.0716	.0566	.0953	
23	.0377	.0339	.0339	.0347	.0377	.0305	
24	.0171	.0189	.017	.0152	.0351	.0377	.0152
Max	.112	.1715	.1334	.1143	.0943	.1143	.1097
Min	.0171	.0189	.016	.0149	.0171	.0305	.0152
Avg	.0569	.0700	.0578	.0463	.0468	.0714	.0551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 206 / 11 KV SHENAWADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0168		.0133	.017	.0185		.0152
2	.0168		.0133	.017	.0183		.0152
3	.017		.0135	.0171	.0173		.016
4	.0166		.0137	.0171	.0175		.016
5	.0168		.0133	.0171	.0175		.0158
6	.017	.0381	.0263	.0339	.0177		.032
7	.0332	.0953	.0743	.0943	.0328	.0572	.048
8	.0671	.0762	.061	.1143	.0663	.0572	.0762
9	.0848	.0953	.0772	.0762	.0671	.0762	.0762
10	.0678	.0572	.0332	.0572		.0572	.0381
11	.0678	.0429	.0463	.0572	.0381	.0429	
12	.0633	.0423		.0572	.0381	.029	.0381
13	.0625	.0423	.0463	.0381	.0171	.029	
14	.0625		.0316			.029	.0381
15	.0617	.0497			.0191	.0297	
16	.0633	.0423			.0191	.029	
17	.0469	.0267	.0347	.0446	.0191	.0297	.04
18	.0762	.0267	.0762	.0452	.0572	.0309	
19	.0953	.0953	.0953	.0781	.0953	.1143	.0705
20	.0953	.0953	.0953		.0953	.0953	.0857
21	.0762	.0953	.0953		.0762	.0953	
22	.0572	.0301	.0381	.048	.0572	.0572	
23	.0191	.0131	.0312	.0328	.0381	.0339	
24	.0166	.0191	.013	.0152	.0179	.0191	.0152
Max	.0953	.0953	.0953	.1143	.0953	.1143	.0857
Min	.0166	.0131	.013	.0152	.0171	.0191	.0152
Avg	.0507	.0546	.0449	.0462	.0391	.0507	.0398

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 207 / 11 KV KARVIIR EXPRESS NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDER Feeder KV- 11 / (CONTINUOUS PROCESS)(NO STAGGERING)  
 OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0175		.0191	.0381	.0185		.0191
2	.0175		.0191	.0381	.0183		.0191
3	.0179		.0191	.0381	.0179		.0191
4	.0171		.0191	.0572	.0177		.0191
5	.0181		.0572	.0572	.0179		.0381
6	.0183	.0189	.0572	.0572	.0177		.0381
7	.0177	.0189	.0572	.0572	.0173	.0377	.0381
8	.0351	.0189	.0381	.0381	.0354	.0377	.0381
9	.0339	.0189	.0381	.0572	.0351	.0377	.0381
10	.0339	.0189	.0381	.0572	.0347	.0377	.0381
11	.0343	.0187		.0377	.0189	.0373	
12	.0339	.0175	.0366	.0566	.0381	.0554	.037
13	.0332	.0166	.0351	.0566	.0381	.0537	
14	.0332	.0162	.0351	.0566	.0381	.052	.0373
15	.0324	.016			.0381	.0526	
16	.0162	.0316			.0381	.0532	
17	.0156	.0343	.0173	.0187	.0381	.0179	.0189
18	.0189	.0191	.0191	.0179	.0189	.0191	.0191
19	.0189	.0572	.0191	.0181	.0191	.0191	.0185
20	.0189	.0572	.0191		.0191	.0189	.0181
21	.0189	.0381	.0191		.0191	.0191	
22	.0189	.0191	.0191	.0183	.0191	.0191	
23	.0189	.0191	.0191	.0185	.0191	.0191	.0185
24	.0173	.0189	.0191	.0191	.0183	.0191	.0191
Max	.0351	.0572	.0572	.0572	.0381	.0554	.0381
Min	.0156	.016	.0173	.0179	.0173	.0179	.0181
Avg	.0232	.0250	.0295	.0407	.0254	.0337	.0273

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

GAGANBAWADA S/DN.[807] BU 4807

Substation No/ Name :- 144070 / 33/11 KV MARGEWADI (NIVADE)

Feeder No / Name : 208 / 11 KV Banchode Ag  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)
10		.0381	
11	.0381		.0381
12			.0381
13		.0381	
14		.0381	
Max	.0381	.0381	.0381
Min	.0381	.0381	.0381
Avg	.0381	.0381	.0381

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 201 / 11 KV Shiye Ag Feeder  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0838	.0655	.0819	.0819	.0838	.0655	.0819
2	.0838	.0655	.0819	.0819	.0838	.0655	.0819
3	.0838	.0655	.0819	.0819	.0838	.0655	.0819
4	.0838	.0655	.0819	.0819	.0838	.0655	.0819
5	.0838	.0819	.0819	.0819	.0838	.0655	.0819
6	.0838	.0819	.0819	.0819	.0838	.0655	.0819
7	.0838	.0819	.0819	.0819	.0838	.0819	.0819
8	.0838	.0819	.0819	.0819	.0819	.0655	.0819
9	.1006	.0819	.0819	.0819	.0819	.0655	.0819
10	.0983	.0819	.0838	.0819	.0819	.0655	.0819
11	1.7368	3.195	3.3196	3.2769		3.3097	3.3261
12	1.6385	3.4408		3.3097		3.5063	3.4736
13	1.6385	3.4408	3.0514	3.1459		3.6214	3.2933
14	1.5565	3.7342	3.1855	3.0312		3.6549	3.3097
15	1.5893	3.2769	3.219	3.0967		3.5208	3.1786
16	1.704	3.4408	3.219	3.0148	1.5729	3.3532	
17	2.6216	3.4408	3.3867	3.1459	2.9492	2.9508	
18	1.4746	3.2769	3.1786	2.934	3.1131	3.3097	
19	.0819	.0819	.0819	.0838	.0819	.0819	.0838
20	.0819	.0819	.0819	.0838	.0655	.0819	.0838
21	.0819	.0819	.0819	.0838	.0655	.0819	.0838
22	.0819	.0819	.0819	.0838	.0655	.0819	.0838
23	.0819	.0819	.0819	.0838	.0655	.0819	.0838
24	.0838	.0655	.0819	.0819	.0838	.0655	.0819
Max	2.6216	3.7342	3.3867	3.3097	3.1131	3.6549	3.4736
Min	.0819	.0655	.0819	.0819	.0655	.0655	.0819
Avg	.6384	1.1864	1.0379	1.0948	.4682	1.1822	.8524

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 202 / 11KV Water Supply -Shiye  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8215	.7619	.7712	.6249	.7922	.7265	.7537
2	.8131	.7619	.7712	.6249	.7842	.7087	.7011
3	.8215	.7442	.7712	.6249	.7842	.6733	.7011
4	.8299	.7087	.7712	.6249	.7842	.6733	.7011
5	.8589	.7265	.7712	.6874	.8029	.7087	.8413
6	.9709	.7442	.7712	.7499	.8215	.7265	.9465
7	1.1576	1.0808	1.0517	.8749	.8215	.8328	1.1043
8	1.643	1.5238	1.1218	1.2654	.7468	1.2403	1.3146
9	2.1209	1.9841	1.6827	1.7497	.7186	1.949	1.9631
10	2.0683	2.1403	2.1658	2.3565	.6485	2.1559	2.392
11	2.4539	2.1795	1.8671	2.1262	.6661	2.1384	2.3565
12	2.226	2.0622	1.5524	2.073	.7011	1.7353	2.3034
13	1.4373	1.6404	1.1827	1.6301	.6485	1.7551	1.5592
14	1.6301	1.8747	1.1949	1.2757	.6485	1.6632	1.5769
15	2.1384	1.7966	1.5684	1.6655	.6661	2.0911	2.3388
16	2.2436	1.8435	1.5684	1.6832	.7011	2.0538	
17	1.9281	1.7185	1.5524	1.7541	.6836	.9335	
18	1.382	1.3279	1.0623	2.0816	.7087	1.6651	2.0351
19	1.2403	1.1218	.7499	1.2696	.7442	1.2971	1.6244
20	.8505	.9816	.7186	.8402	.7973	1.0166	1.2696
21	.8505	.8413	.6874	.8402	.7087	.8939	1.0642
22	.7973	.8063	.6874	.8215	.7087	.8413	.9709
23	.7619	.7712	.6718	.8029	.7087	.8063	.8589
24	.8589	.7442	.7712	.6718	.7842	.7265	.7888
Max	2.4539	2.1795	2.1658	2.3565	.8215	2.1559	2.392
Min	.7619	.7087	.6718	.6249	.6485	.6733	.7011
Avg	1.3710	1.2869	1.1035	1.2383	.7325	1.2505	1.3712

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 203 / 11KV TOP II AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4024	.407	.407	.4024	.9816	1.4243	1.4251
2	.4481	.407	.407	.4024	.9816	1.4922	1.7604
3	.4207	.407	.407	.4024	.9816	1.4922	1.7604
4	.3887	.407	.407	.4024	1.6126	1.56	1.8107
5	.4207	.407	.407	.4024	1.1568	1.7635	1.9281
6	.4207	.407	.407	.4024	1.1919	1.8652	2.0119
7	.4207	.407	.407	.4024	1.1744	2.3739	2.2634
8	.4024	.407	.407	.4024	1.1744	2.34	2.2634
9	1.9784	1.7604	1.3904	.4024	1.0513	2.2043	2.2634
10	1.56	2.1795	2.191	.407	.407	.407	.407
11	1.6108	2.2634	2.7343	1.1869	.407	.407	.407
12	1.4413	2.2466	2.5941	1.9839	.407	.407	.407
13	1.4074	2.3472	2.524	1.8482	.4024	.4024	.407
14	1.3904	2.3472	2.489	1.8652	.4024	.3856	.407
15	1.5261	2.3472		1.8313	.4024	.4024	.407
16	1.6108	1.8442	2.4539	1.6617	.4024		
17	.39	.4024	.3856	1.6108	.4024	.3856	
18	.407	.4024	.4024	1.3748	.407	.4024	.4031
19	.407	.407	.4024	.4382	.407	.4024	.4207
20	.407	.4239	.4024	.4191	.407	.4024	.4207
21	.407	.4239	.4024	.4191	.407	.4024	.4207
22	.407	.407	.4024	.4024	.407		.4024
23	.407	.407	.4024	.4024	.3932		.4207
24	.4024	.407	.407	.6059	.8413	.9665	.9221
Max	1.9784	2.3472	2.7343	1.9839	1.6126	2.3739	2.2634
Min	.3887	.4024	.3856	.4024	.3932	.3856	.4024
Avg	.7952	.9947	.9930	.8366	.7004	1.0423	1.0609

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144001 / 33/11KV SHIYE

Feeder No / Name : 204 / HANUMAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2241	.2614	.2241	.2054	.2241	.2427	.1867
2	.2241	.2614	.2241	.2054	.2241	.2427	.1867
3	.2241	.2427	.2241	.2054	.2241	.2427	.1867
4	.2241	.2427	.2241	.2241	.2241	.2614	.2054
5	.2427	.2801	.2427	.2614	.2614	.2987	.2241
6	.2614	.3361	.2614	.2987	.2987	.3547	.2801
7	.3174	.3361	.2801	.3174	.2987	.3174	.2801
8	.2614	.2614	.2614	.2987	.2614	.2614	.2614
9	.2801	.2241	.2987	.2614	.2241	.2054	.2801
10	.2614	.3174	.2801	.2241	.2614	.2614	.2241
11	.2801	.2614	.2614	.2054	.1867	.2801	.2614
12	.2427	.3174	.2743	.2241	.2054	.3174	.2614
13	.2801	.2614	.2614	.2241	.2241	.2241	.2987
14	.2241	.2614	.2054	.2241	.2241	.2054	.2614
15	.2427	.2614	.2241	.2054	.2054	.2614	.2241
16	.2801	.2801	.2614	.2427	.2054		
17	.3361	.2614	.2614	.2614	.2054	.2614	
18	.2241	.2614	.2614	.2614	.1867	.2801	.2987
19	.3921	.3734	.3361	.3361	.3361	.3174	.3734
20	.3921	.3734	.3547	.3921	.3921	.3734	.4294
21	.3734	.3921	.3547	.3921	.3921	.3361	.3696
22	.3361	.3547	.3547	.3734	.3361	.3174	.3361
23	.2987	.3174	.2987	.3547	.2801	.2801	.2987
24	.2427	.2614	.2614	.2241	.2614	.2614	.2241
Max	.3921	.3921	.3547	.3921	.3921	.3734	.4294
Min	.2241	.2241	.2054	.2054	.1867	.2054	.1867
Avg	.2777	.2917	.2705	.2676	.2560	.2784	.2706



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 202 / 11 KV NIGAWA GAVTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1905	.1867	.1905	.1886	.2427	.2096	.1886
2	.1905	.1867	.1905	.1867	.2427	.1905	.1886
3	.1905	.1867	.1905	.1886	.2402	.2096	.1886
4	.2286	.1867	.1905	.2241	.2427	.1905	.1886
5	.2263	.1886	.1905	.2263	.2614	.2286	.1886
6	.2641	.2263	.2667	.2614	.2801	.2829	.2614
7	.2801	.2452	.2987	.3395	.2614	.3239	.2614
8	.2987	.2641	.2614	.5601	.2614	.2957	.2614
9	.2195	.2772	.2957	.2378	.2614	.2614	.2477
10	.2534	.2987	.3326	.2957	.2241	.2801	.2667
11	.2195	.298	.2241	.3547	.2614	.2987	.2926
12	.2195	.2658	.2427	.3018	.2614	.2987	.2033
13	.2534	.197	.1867	.2286	.2241	.2957	.2241
14	.181	.1991	.1867	.2096	.2241	.2427	.1991
15	.1829	.2195	.2054	.2667	.2054	.2054	.1829
16	.2926		.2075	.3077	.2241	.2614	.3109
17	.2987	.2865	.2054	.2427	.2402	.2561	.2957
18	.2926	.2957	.2641	.2772	.2614	.2561	.3142
19	.3772	.4572	.3772	.3511	.1886	.3326	.3326
20	.3584	.4435	.415	.3584	.362	.3326	.3696
21	.3584	.3734	.3395	.3584	.362	.3361	.3696
22	.2829	.3361	.2829	.3584	.3239	.3361	.2957
23	.1886	.2641	.2452	.3018	.2286	.2614	.2772
24	.2286	.1886	.1905	.461	.2427	.2096	.1886
Max	.3772	.4572	.415	.5601	.362	.3361	.3696
Min	.181	.1867	.1867	.1867	.1886	.1905	.1829
Avg	.2532	.2640	.2492	.2953	.2553	.2665	.2541

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 204 / 11KV AMBEWADI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0514	.0762	.0572	.0503	.0343	.0762
2	.0526	.0514	.0762	.0572	.0488	.036	.0762
3	.0533	.0514	.0762	.0572	.0495	.0366	.0762
4	.0533	.0514	.0762	.0572	.0518	.036	.0762
5	.0526	.0514	.0762	.0572	.0465	.0349	.0762
6	.0526	.0514	.0762	.0572	.0518	.0343	.0762
7	.0533	.0514	.0762	.0572	.0396	.0349	.0762
8	.0541	.0514	.0762	.0572	.0518	.0337	.0762
9	.0762	.0434	.0526	.0314	.0762	.0343	.0754
10	.0953	.0587	.0526	.0427		.0533	.0762
11	1.3927	1.6575	1.4899	1.086		1.7814	2.0348
12	1.4746	1.6766	1.6842	1.6575		1.3108	2.0576
13	1.4746	1.7147	1.6385	1.6766		1.8351	2.0957
14	1.3435	1.5604	1.5546	1.5242		1.8023	1.9052
15	1.2452	1.4022	1.4899	1.5242	1.4091	1.6842	1.7147
16	1.1797	1.5089	1.4403	1.1336	1.704		1.6575
17	.9503	1.3923	1.2071	1.4861	1.6766	1.8842	1.6385
18	.9054	1.1469	1.0364	.8962	1.3717	1.4918	1.4251
19	.0514	.0762	.0514	.0533	.052	.0518	.0518
20	.0514	.0762	.0514	.0533	.0686	.0762	.0526
21	.0514	.0762	.0514	.0533	.052	.0762	
22	.0514	.0762	.0514	.0533	.0514	.0762	
23	.0514	.0762	.0514	.0518	.052	.0762	.0934
24	.0518		.0762	.2549	.0511	.0349	.0762
Max	1.4746	1.7147	1.6842	1.6766	1.704	1.8842	2.0957
Min	.0514	.0434	.0514	.0314	.0396	.0337	.0518
Avg	.4529	.5632	.5245	.5015	.3660	.5456	.7075

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 205 / 11 KV Kerli Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.125	.1029	.1905	.1334	.0945	.2667	
2	.125	.1029	.1905	.1334	.096	.2667	
3		.1029	.1905	.1334	.096	.2667	
4		.1029	.1905	.1334	.036	.2667	
5		.1372	.1905	.1334	.0366	.2667	
6		.1372	.1905	.1524	.0366	.2667	
7	.104	.1372	.1905	.1524	.0383	.2858	
8	.0903	.1372	.1905	.1524	.1715	.2667	
9	.1143	.1235	.1391	.1886	.1334	.2507	.2477
10	.1143	.1296	.1372	.1524		.2328	.2263
11	1.7072	1.491	2.2969	3.4705		3.493	3.2047
12	2.0119	1.6385	3.3316	3.7134		3.3532	2.8807
13	1.8107	2.0748	2.2939	3.4476		3.7304	2.3061
14	1.9113	2.2885	2.9007	3.4705		3.9095	3.6523
15	2.0553	3.1007	2.1956	3.2769	2.13		3.7342
16	2.079	2.304	2.1628	2.2466	3.8226		3.7723
17	1.9448	2.3137	2.7854	3.4145	3.6965	4.2052	3.6866
18	1.9281	3.0148	2.9005	2.9984	3.5494	3.5303	3.315
19	.1372	.1905	.1715	.0434	.2601		
20	.1372	.2096	.1715	.0394	.2572		
21	.1372	.2096	.1715	.0412	.2601		
22	.12	.2096	.1372	.0406	.2572		
23	.1029	.1905	.1372	.1036	.2667		
24	.1235	.1029	.1905	.514	.1063	.2667	
Max	2.079	3.1007	3.3316	3.7134	3.8226	4.2052	3.7723
Min	.0903	.1029	.1372	.0394	.036	.2328	.2263
Avg	.8440	.8563	.9853	1.1786	.8076	1.4779	2.7026

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 206 / 11 KV VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.5658	.6859	.5658	.6478	.7621	.7167
2	.7621	.5601	.6859	.5601	.6478	.7811	.7167
3	.7545	.5658	.6859	.5658	.6478	.8002	.724
4	.7621	.7095	.6859	.5975		.8192	.724
5	.7922	.7545	.7167	.7922	.724	.8573	.7621
6	.8676	.9054	.9877	.8962	.9054	.8962	.9431
7	.8131	.9054	.9979	.9054	.8505	.8779	.9511
8	.7964	1.0562	.9412	.9808	.8596	.8596	.8505
9	.788	.8413	.8505	.8688	.8505	.8859	.8688
10	.8322	.8413	.9313	.8048	.7796	.9671	.8779
11	.7964	1.0517	.788	.8871		.9313	.8505
12	.788	.8413	.815	.8505		.9412	.8413
13	.724	.823	.7164	.8413		.8688	.8688
14	.695	.8322	.7164	.8322		.8779	.8779
15	.7164	.8413	.788	.7712		.8326	.9054
16	.724	.823	.7011	.7628		.8779	.8596
17	.8215	.9214	.7468	.7796	.8596	.8596	.7964
18	.8215	.8669	.6722	.815	.8505	.7282	.8413
19	.9709	1.086	.8962	1.0242	1.0974	.924	.961
20	.9709	1.1088	.9808	.9979	1.1088	.9979	1.0349
21	.9054	1.0082	.9054	.8589	1.1088	1.0082	1.0185
22	.8299	.9054	.7922	.7545	1.1203	.9335	.9054
23		.8299	.7545	.7545	.8299	.8215	.7922
24	.7545	.6036	.6859	.6036	.679	.7545	.7545
Max	.9709	1.1088	.9979	1.0242	1.1203	1.0082	1.0349
Min	.695	.5601	.6722	.5601	.6478	.7282	.7167
Avg	.8021	.8437	.7970	.7946	.8569	.8693	.8518

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 207 / 11 KV Nigave Ag.  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1029	.1334	.1143	.128	.0549	.1334
2	.132	.1029	.1334	.1143	.128	.056	.1334
3	.132	.1029	.1334	.1143	.1294	.0554	.1334
4	.132	.1029	.1334	.1143	.1294	.0732	.1334
5	.1509	.1029	.1334	.1143	.1463	.0924	.1334
6	.168	.1715	.1524	.1524	.1646	.1463	.1524
7	.1307	.1372	.1524	.1905	.1448	.1494	.1334
8	.1509	.1372	.1524	.1334	.1463	.1132	.1334
9	.1524	.1143	.112	.1524	.1143	.1307	.1143
10	.1524	.1905	.1698	.1143	.1334	.112	.1143
11	2.4478	2.3472	2.6452	2.2634	1.989	2.2672	2.713
12	2.6825	2.5149	1.7436	2.0119	1.989	2.1052	2.572
13	2.4143	1.8861	2.3472	1.8023	1.8351	2.0645	2.5434
14	2.3807	2.0805	2.2672	1.6575	1.7166	2.0317	2.4006
15	2.2131	2.1795	2.556	1.6004		2.0119	2.0348
16	2.1125	2.3739	1.9227	1.8023	1.8442	2.3739	2.3472
17	1.8023	2.5149	1.8442		2.1548	2.5434	1.9559
18	1.8442	2.2377	1.8107	1.5059	1.3413	2.2874	2.1628
19	.1372	.1524	.1372	.1509	.1509	.112	.168
20	.1372	.1334	.12	.1494	.1334	.1494	.0739
21	.1372	.1524	.12	.1509	.1109	.1494	.1478
22	.12	.1334	.1372	.1715	.112	.1524	.1494
23	.1029	.1334	.1029	.1509	.1132	.1524	.1494
24	.1307	.1029	.1334	.1029	.1448	.0537	.1334
Max	2.6825	2.5149	2.6452	2.2634	2.1548	2.5434	2.713
Min	.1029	.1029	.1029	.1029	.1109	.0537	.0739
Avg	.8373	.8420	.8039	.6450	.6522	.8099	.8694

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KADAMWADI[039] BU 6173

Substation No/ Name :- 144003 / 33/11 KV KERLE

Feeder No / Name : 208 / 11 KV Panhala Feeder  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.4854	.4954	.4904	.5175	.4572	.5281
2	.5335	.4904	.4954	.4904	.5228	.4763	.4572
3	.5335	.4854	.4954	.4854	.4854	.4763	.4572
4	.5335	.4854	.4954	.5228	.4904	.5716	.4572
5	.5281	.5658	.5335	.5658	.5228	.5716	.5658
6	.6036	.5658	.679	.6036	.5914	.6535	.6348
7	.5281	.5847	.6722	.5658	.5487	.679	.6722
8	.547	.6036	.6653	.5658	.5544	.6036	.5601
9	.5487	.6036	.6535	.5487	.5853	.5175	.5525
10	.6219	.5544	.6161	.5914	.6584	.5175	.5335
11	.6379	.5853	.6161	.5601	.5914	.5228	.6535
12	.591	.4435	.5975	.6838	.5228	.5975	.6413
13	.5914	.5415	.5228	.5601	.5228	.6283	.6287
14	.5914	.5658	.5228	.5281	.5228	.6348	.6097
15	.5914	.5906	.5601	.6287	.5228	.6722	.5601
16	.5914	.5906	.5601	.6154	.5601	.7392	.6283
17	.5658	.6219	.5658	.6516	.5175	.695	.6219
18	.5601	.6219	.5601	.6468	.5975	.6584	.6653
19	.7545	.7468	.7922	.7392	.7922	.7762	.7468
20	.7922	.7922	.811	.7164	.743	.7762	.8215
21	.7167	.7842	.7655	.724	.6413	.7468	.8215
22	.679	.7095	.7167	.6653	.6097	.7095	.7392
23	.5658	.5658	.5281	.5788	.5335	.6348	.5601
24	.5716	.5093	.4954	.7411	.5415	.4572	.5658
Max	.7922	.7922	.811	.7411	.7922	.7762	.8215
Min	.5281	.4435	.4954	.4854	.4854	.4572	.4572
Avg	.5963	.5872	.6006	.6029	.5707	.6155	.6118

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 201 / 11 kv Yavaluj Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0167	.6962	.7377	.8688		.0166	.0173
2	.0167	.7293	.7545	.9511		.0168	.0175
3	.0144	.7209	.7545	.9511		.0166	.0175
4	.0162	.663	.8383	.823		.0166	.0175
5	.015	.8383	.9054	1.1088		.0166	.0175
6	.0167	.8951	1.1233	1.3169		.0166	.0173
7	.0143	1.3094	1.4586	1.5893		.0164	.0175
8	.0165	1.4918	1.4918	1.9044	.0167	.0166	.017
9	.015	1.3904	1.5581		.0167	.016	.017
10	.0164	.0168	1.6827	.0165	.9945	1.5089	1.2567
11	.0164	.0168	.0183		1.3748	1.4419	1.7741
12	1.5424	.0168				1.8679	1.8111
13	1.5074	.0168			1.5729	1.9334	1.8665
14	1.543	.0168			1.6057	1.7859	1.8099
15	1.5424	.0168		.016	1.6575	1.7736	1.7194
16	1.5415	.0168		.0182		1.7072	1.9909
17	1.4746	.0168		.0163	1.5729	1.6766	1.8461
18	1.3565	.0168	.0171	.0167	1.5939	.0168	.0173
19	.9717	.0168	.0173	.0162	.0166	.017	.0179
20	.0164	.017	.0171		.0166	.017	.0177
21	.017	.017	.0173	.0163	.0166	.017	.0173
22	.0164	.0171	.0173	.0161	.0166	.017	.0175
23	.0164	.0168	.2926	.0167	.0166	.0171	.0175
24	.0161	.5735	.7209	.8596	.015	.0166	.0171
Max	1.543	1.4918	1.6827	1.9044	1.6575	1.9334	1.9909
Min	.0143	.0168	.0171	.016	.015	.016	.017
Avg	.4890	.3977	.6902	.5846	.7002	.5818	.5980

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 202 / 11 KV YEVALUJ VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1274	.1052	.1109	.1097	.126	.1075	.1433
2	.1274	.1052	.1109	.0914	.127	.1052	.1254
3	.1136	.1052	.1109	.0905	.1088	.1052	.1254
4	.127	.116	.1109	.0905	.108	.1267	.1267
5	.1672	.1463	.1463	.1097	.1436	.1629	.1448
6	.1835	.1578	.1463	.128	.1639	.1949	.1991
7	.1974	.1402	.1829	.1663	.18	.1417	.1772
8	.2001	.1886	.1829	.1267	.2024	.1928	.1753
9	.216	.1753	.1991		.144	.1578	.1578
10	.1907	.1928	.1829	.1955		.1928	.1646
11	.1715	.2103	.1463	.1934		.2058	.1646
12	.1907	.1928	.1478	.108		.208	.1663
13	.1029	.1753	.1663	.1456		.1886	.1848
14	.0867	.1578	.2012	.2001		.1886	.1848
15	.1029	.1907	.181	.1821	.1402	.1886	.1848
16	.1227		.1663	.1631	.1372	.1886	.2012
17	.2229	.1753	.1478	.1821	.1715	.1886	.1829
18	.2454	.2126	.1848	.2229	.1734	.2058	.2033
19	.2572	.2481	.2033	.2365	.2103	.2572	.2195
20	.2303	.2328	.2218		.2229	.2743	.2012
21	.2103	.197	.1991	.198	.2103	.2401	.1848
22	.1734	.1791	.181	.2001	.1928	.2126	.2218
23	.1402	.1463	.1478	.144	.1417	.1772	.1646
24	.144	.12	.128	.128	.1275	.1227	.1612
Max	.2572	.2481	.2218	.2365	.2229	.2743	.2218
Min	.0867	.1052	.1109	.0905	.108	.1052	.1254
Avg	.1688	.1683	.1628	.1551	.1596	.1806	.1736



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 203 / 11Kv Satarde sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	.0166	.017	.0173	1.0713	.9945	.9221
2	.0166	.0166	.0171	.0173	1.171	1.1283	.9221
3	.0167	.0168	.0171	.0173	1.3699	1.1283	1.0227
4	.015	.0164	.0171	.0175	1.5337	.9945	1.0774
5	.015	.0171	.0171	.0175	1.7837	1.2483	1.21
6	.0163	.0166	.0171	.0173	1.9873	1.5089	1.6078
7	.015	.0168	.017	.0171	2.1314	2.6818	2.3703
8	.0161	.0171	.017	.0175	2.0929	2.9664	2.4863
9	.0163	.0168	.017		2.0171	2.4863	2.5526
10	.0166	.0166	.0171	1.9448	.0162	.0166	.0173
11	.0164	.0168	.0175	2.6303	.0164	.0171	.0175
12	3.152	3.7555	3.1786	2.7006	.0168	.0171	.0175
13	3.1207	3.6466	3.1417	2.7506	.0168	.0173	.0173
14	3.3846	3.5803	3.2156	2.8566	.0168	.0173	.0173
15	3.4808	3.3316	3.1786		.0162	.0173	.0173
16	3.3684	3.2487	2.963	2.6353	.0166	.0171	.0173
17	3.4057	3.1327	2.7351	2.1201	.0162	.0171	.0171
18	3.0996	2.7664	2.268	.0163	.0164	.0173	.0171
19	2.5194	2.2466	2.0144	.0161	.0164	.0173	.0175
20	.0162	.017	.0173	2.5339	.0166	.0171	.0173
21	.0166	.0171	.0173	.0161	.0162	.0171	.0175
22	.0164	.0171	.0173	.0161	.016	.0171	.0171
23	.0166	.017	.0175	.0167	.0164	.017	.0171
24	.0163	.0168	.017	.0173	.8002	.8951	.8718
Max	3.4808	3.7555	3.2156	2.8566	2.1314	2.9664	2.5526
Min	.015	.0164	.017	.0161	.016	.0166	.0171
Avg	1.0746	1.0824	.9571	.9277	.6745	.6780	.6369

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 204 / Majgaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1336	.0181	.0173	.0173	1.6155	1.6461	1.4754
2	1.1687	.0181	.0173	.0175	1.8031	1.7187	1.5089
3	1.2583	.0187	.0173	.0173	1.8992	1.5565	1.5249
4	1.1666	.0175	.0173	.0173	1.8246	1.4998	1.6907
5	1.3192	.0181	.0173	.0173	2.1655	1.848	1.8067
6	1.7531	.0185	.0173	.0175	2.3172	2.0144	2.1464
7	2.2154	.0175	.0173	.0173	2.2369	2.8959	2.6216
8	2.2805	.0175	.0173	.0173	2.2434	3.2579	2.649
9	2.3452	.0181	.0173		2.6646	2.8645	2.5987
10	.0171	.0173	.0171	2.6094	.0179	.0173	.0173
11	.0171	.0173	.0173	3.1674		.0173	.0171
12	.0185	2.8837	3.5113	3.1602		.0173	.0171
13	.0183	2.934	3.5482	3.2674		.0173	.0171
14	.0181	2.9675	3.4004	3.0007		.0173	.0173
15	.0181	2.9172	3.3288	2.8006	.0181	.0175	.0175
16	.0185	3.0691	3.3265	2.6339	.0181	.0175	.0173
17	.0185	2.7978	2.9938	2.4952	.0181	.0175	.0175
18	.0183	2.4417	2.7721	.0163	.0179	.0175	.0175
19	.0183	2.3061	2.3655	.0169	.0181	.0173	.0173
20	.0183		.0173			.0173	.0175
21	.0181		.0173	.0167	.0181	.0175	.0173
22	.0183		.0173	.0161	.0181	.0175	.0171
23	.0181	.0173	.0173	.0167	.0183	.0175	.0171
24	.9739	.0183	.0173	.0173	1.3336	1.4842	1.4083
Max	2.3452	3.0691	3.5482	3.2674	2.6646	3.2579	2.649
Min	.0171	.0173	.0171	.0161	.0179	.0173	.0171
Avg	.6612	1.0738	1.0635	1.0624	1.0666	.8762	.8197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 205 / Majgaon Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1167	.1112	.1448	.1463	.18	.1174	.1433
2	.114	.116	.1448	.128	.18	.1219	.1433
3	.1203	.128	.1267	.1294	.1445	.125	.1448
4	.15	.1619	.1267	.1294	.15	.1429	.1791
5	.1732	.2058	.1448	.1478	.1792	.1698	.2149
6	.2	.2229	.1612	.1848	.2363	.192	.2126
7	.2284	.208	.1791	.2587	.2334	.2155	.2303
8	.2459	.2454	.2149	.2587	.2501	.1989	.2454
9	.2489	.213	.2126		.2167	.208	.2481
10	.2267	.2126	.2378	.2183	.176	.2303	.2587
11	.2543	.2126	.2195	.2179		.2103	.2587
12	.1943	.2126	.0924	.2186		.1907	.2587
13	.2254	.2279	.0895	.2001		.1907	.2561
14	.2401	.2454	.0895	.198		.2103	.2561
15	.2401	.2454	.0914		.2427	.2454	.2772
16	.2486	.2481	.2587	.2108	.2561	.2804	.2926
17	.2401	.2686	.2926		.2753	.3155	.3292
18	.2429	.2686	.3142	.3461	.2622	.2804	.3326
19	.3086	.2686	.3696	.3781	.3281	.3155	.3658
20	.3437	.2896	.4108	.2368	.3856	.3761	.3921
21	.333	.3258	.3326	.3001	.2949	.3582	.4108
22	.2591	.3077	.2926	.2341	.2469	.3045	.3326
23	.2031	.2353	.2241	.1974	.1783	.2507	.2534
24	.1303	.128	.1448	.181	.198	.1269	.1791
Max	.3437	.3258	.4108	.3781	.3856	.3761	.4108
Min	.114	.112	.0895	.128	.1445	.1174	.1433
Avg	.2203	.2212	.2048	.2153	.2307	.2241	.2590

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144007 / 33/11 KV PADAL

Feeder No / Name : 206 / 11 KV Satarde Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2022	.1753	.1829	.2195	.2183	.2033	.197
2	.2071	.1595	.1646	.1829	.2341	.1829	.1791
3	.1821	.1595	.1646	.1848	.2217	.1715	.181
4	.1999	.2103	.1829	.1848	.2638	.2103	.1791
5	.2368	.2401	.2172	.2218	.3061	.2454	.2149
6	.3061	.3155	.2686	.2957	.3241	.298	.3189
7	.3457	.3467	.3403	.3511	.3421	.3155	.3012
8	.3781	.298	.3582	.3511	.3601	.3189	.3189
9	.3781	.4207	.394		.3241	.3506	
10	.3086	.3898	.3696	.3681	.3582	.3366	.3841
11	.3506	.3898	.3511	.3381	.2865	.3467	.3326
12	.333	.298	.3547	.309	.3077	.3155	.3696
13	.3012	.3155	.3734	.3275		.298	.4251
14	.3681	.3506	.3511	.3093		.3294	.3326
15	.3294	.333	.3292	.3241	.2629	.3467	.3142
16	.3155	.3544	.3326	.3601	.2915	.3506	.3734
17	.3681	.3544	.3326	.3562	.2629	.3681	.3511
18	.3898	.3761	.3326	.4141	.3681	.3856	.3921
19	.3856	.394	.3696	.4501	.4207	.4252	.462
20	.4557	.4298	.4755		.4207	.443	.4668
21	.4382	.4572	.4572	.4186	.4207	.4607	.4668
22	.3856	.4207	.3292	.4141	.3681	.3761	.4294
23	.3155	.3292	.2957	.3128	.2835	.3224	.3326
24	.2601	.2229	.2561	.2743	.2	.2279	.2507
Max	.4557	.4572	.4755	.4501	.4207	.4607	.4668
Min	.1821	.1595	.1646	.1829	.2	.1715	.1791
Avg	.3225	.3225	.3160	.3167	.3112	.3179	.3293

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036]

BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 201 / 11KV BORGOAN VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0171	.0175	.0175	.0187	.0171	.0351
2	.0191	.0171	.0177	.0175	.0187	.0171	.0351
3	.0191	.0171	.0179	.0175	.0187	.0171	.0351
4	.0381	.0171	.0175	.0175	.0373	.0171	.0351
5	.0572	.0171	.0358	.0351	.056	.0171	.0351
6	.0566	.0347	.0354	.0526	.056	.0343	.0526
7	.0566	.0526	.0532	.0526	.0554	.0526	.0526
8	.0537	.0526	.0532	.0526	.0549	.0526	.0526
9	.0537	.0526	.0532	.0526	.0549	.0526	.0526
10	.0526	.0526		.0532	.0526	.0526	.0532
11	.0526	.0532	.0526	.0532	.0526	.0526	.0526
12	.0526	.0532	.0526	.0532	.0526	.0526	.0526
13	.0526	.0532	.0526	.0532	.0526	.0526	.0532
14	.0526	.0532	.0526	.0537	.0526	.0526	.0532
15	.0526	.0526	.0526	.0537	.0526	.0526	.0532
16	.0526	.0532	.0526	.0537		.0526	.0526
17	.0526	.0526	.0526	.0537	.0526	.0526	.0526
18	.0526	.0532	.0526	.0566	.0526	.0526	.0532
19	.0709	.0532	.0701	.0566	.0709	.0701	.0526
20	.0709	.0709	.0526	.0566	.0716	.0526	.0709
21	.0701	.0709	.0526	.0566	.0716	.0526	.0532
22	.0526	.0526		.0381	.0526		.0351
23	.0343	.0354	.0351	.0381	.0343		.0175
24	.0381	.0171	.0175	.0351	.0362	.0171	.0351
Max	.0709	.0709	.0701	.0566	.0716	.0701	.0709
Min	.0191	.0171	.0175	.0175	.0187	.0171	.0175
Avg	.0493	.0440	.0432	.0450	.0491	.0429	.0469

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 202 / 11KV KARANJFEN AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2539	1.8099	.8063	.7011	.6762	1.9004	1.9281
2	2.2539	1.8099	.815	.7362	.6935	1.9004	2.1033
3	2.2539	1.8099	.8505	.7888	.7108	1.9004	2.3034
4	2.2539	1.8099	.9214	.8413	.7282		2.3663
5	2.2712	1.9366	1.0745	.8764	.7455	2.0814	2.4539
6	2.2712	2.1719	1.1283	.929	.8495	2.3529	2.6292
7	2.8117	2.5882	1.3889	.9991	1.0749	3.1131	3.0674
8	3.2415	3.2579	1.5775	1.3146	1.1616	3.3484	3.2427
9	2.826	3.5656	1.5947	1.4022	1.491		3.0674
10	.0343	.0351	.0526	2.3148	1.379	1.4022	1.491
11	.0343	.0347	.0351	3.2065	1.379	1.5775	1.6126
12	1.6834	3.6046	3.6808	3.618	1.3969	1.5775	1.6289
13	1.6476	3.5208	3.7685	3.618			1.6126
14	1.6476	4.0295	3.8561	3.6928		1.5775	1.6289
15	1.6476	4.0489	3.5056	3.5021		1.6651	1.5927
16	1.576	4.0139	3.155	3.4328	1.4685	1.7528	1.5261
17	1.5223	3.9613	3.2427	3.4155		1.5775	1.7804
18	1.4327	3.5932	3.3303	.0377	.0343	.0526	.0351
19	.985	3.2047	2.4539	.0377	.0343	.0526	.0343
20	.0343	.0526	.0351	.0377	.0343	.0526	.0526
21	.0343	.0532	.0351	.0377	.0343	.0381	.052
22	.0343	.0509	.0354	.0377	.0343		.0351
23	.0343	.0354	.0351	.0377	.0343		.0351
24	1.7147	1.8461	.7796	.6556	.6068	1.9004	1.8604
Max	3.2415	4.0489	3.8561	3.6928	1.491	3.3484	3.2427
Min	.0343	.0347	.0351	.0377	.0343	.0381	.0343
Avg	1.5208	2.2019	1.5899	1.5113	.7284	1.5697	1.5891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 203 / 11KV PADASALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0377	.0343	2.2085	1.9281	1.8551	.0343	.0351
2	.0377	.0343	2.2325	1.9281	2.0538	.0343	.0351
3	.0377	.0343	2.2786	2.191		.0343	.0351
4	.0377	.0343	2.4451	2.3663	1.9765	.0343	.0351
5	.0377	.0343	2.6223	2.4539	2.0458	.0343	.0351
6	.0377	.0343	2.9058	2.6292	2.2365	.0343	.0351
7	.0358	.0343	3.155	2.8395	2.8953	.0343	.0351
8	.0358	.0343	3.155	2.9797	3.6582	.0343	.0351
9	.0358	.0343	2.9508	2.8045	3.6235		.0351
10	.0343	.0351	.0351	.0354	2.6425	2.6292	3.0864
11	.0343	.0351	.0351	.0354	3.0769	3.3303	3.738
12	3.9276	.0351	.0351	.0354	3.2579	3.9438	3.9952
13	3.9819	.0351	.0351	.0354	3.2579	4.0314	
14	4.2534	.0339	.0351	.0358	3.1312	3.5056	3.6408
15	4.1629	.0343	.0351	.0358	2.9321	3.5056	3.9438
16	4.0181	.0351	.0351	.0358	2.8416	2.8045	3.6808
17	3.7828	.0354	.0351	.0358	2.7149	3.5757	3.7304
18	3.3122	.0332	.0351	.0377	.0343	.0351	3.2251
19	2.8054	.0339	.0351	.0377	.0343	.0351	.0351
20	.0343	.052	.0351	.0377	.0343	.0351	.0526
21	.0343	.0503	.0351	.0377	.0343	.0351	.0509
22	.0343	.0354	.0351	.0377	.0343		.0354
23	.0343	.0354	.0351	.0377	.0343		.0354
24	.0377	.0343	2.1971	1.7878	1.6804	.0343	.0351
Max	4.2534	.052	3.155	2.9797	3.6582	4.0314	3.9952
Min	.0343	.0332	.0351	.0354	.0343	.0343	.0351
Avg	1.2842	.0359	1.1101	1.0175	2.0037	1.3226	1.2870

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 204 / 11 Kv Boragaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.8859	.8413			
2		.8954	.8859	.8322		
3		.8859	.964	.7975		
4		.8939	.964	.7975		
5		.9114	1.0517	.7975		
6		.9391	1.1393	.8669		
7		1.1043	1.262			
8		1.2971	1.3321	.9362		
9		1.2309	1.3146	1.0923		
10				1.1283	1.2971	1.3289
11				1.1283	1.5249	1.5592
12	1.5581			1.3432	1.3847	1.491
13	1.5746			1.1641	1.5775	1.4723
14	1.5565			1.1641	1.4723	1.4022
15	1.4864			1.3073	1.4373	1.3672
16	1.4327			1.3073	1.4022	1.3672
17	1.379			1.3073	1.2269	1.3146
18	1.2536					
19	1.0387					
24		.8859	.8238	.8745		
Max	1.5746	1.2971	1.3321	1.3432	1.5775	1.5592
Min	1.0387	.8859	.8238	.7975	1.2269	1.3146
Avg	1.4100	.9930	1.0579	1.0528	1.4154	1.4128



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 205 / 11 KV PADASALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.8059	.0709	.0701	.0754	.8954	.9816
2	.0572	.8059	.0701	.0701	.0754	.8954	1.0341
3	.0572	.8059	.0701	.0701	.0754	.8954	1.0692
4	.0762	1.1641	.0886	.0701	.0754	.8954	1.1393
5	.0953	.9313	.1052	.0701	.0943	.985	1.2094
6	.7922	1.1151	.1417	.0876	.1509	1.0566	1.2795
7	1.1283	1.1641	.1753	.1402	.1698	1.2536	1.3672
8	1.2715	1.182	.1715	.1578	.1478	1.2536	1.262
9	1.2894	1.2178	.1402	.1402	.1109		1.2269
10	.1402	.1357	.1052	.8682	.1227	.1227	.1417
11	.1227	.1017	.1227	1.1694	.1052	.1578	.1052
12	.1227	1.2269	1.2795	1.2403	.1227	.1578	.1063
13	.1227	1.2795	1.262	1.2757	.1227	.1578	.1063
14	.1227	1.1869	1.2445	1.182	.1227	.1578	.1063
15	.1227	1.2378	1.2269	1.1999	.1227	.1402	.1227
16	.1227	1.2548	1.1218	1.1462	.1227	.1227	.1227
17	.1402	1.2209	1.0867	1.1283	.1227	.1928	.1227
18	.1772	1.1869	1.1043	.1698	.1402	.1753	.1578
19	.2149	1.0898	1.0517	.1886	.2149	.2279	.1928
20	.2328	.2303	.2279	.2263	.2328	.2103	.2279
21	.2149	.2303	.2279	.1886	.1949	.1753	.1865
22	.1578	.1417	.1753	.1524	.1402		.1402
23	.1052	.1052	.1052	.0953	.0857		.1052
24	.0762	.8238	.0709	.0701	.0953	.8954	.964
Max	1.2894	1.2795	1.2795	1.2757	.2328	1.2536	1.3672
Min	.0572	.1017	.0701	.0701	.0754	.1227	.1052
Avg	.2925	.8602	.4769	.4657	.1268	.5250	.5616

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144008 / 33/11KV S//S BAJAR BHOGOAN

Feeder No / Name : 206 / 11 KV KARANJFEN GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0953	.0857	.0895	.0876	.112	.1029	.0876
2	.0953	.0857	.0886	.0876	.0934	.1029	.0876
3	.0953	.0857	.0886	.0876	.0934	.1029	.0876
4	.0953	.0857	.124	.0876	.0934	.1029	.0876
5	.1143	.104	.1595	.1052	.112	.12	.1052
6	.1886	.1578	.2103	.1402	.2054	.1753	.1402
7	.2829	.2149	.2658	.2103	.2801	.2507	.2279
8	.2686	.2686	.2774	.2629	.2772	.2686	.2629
9	.2686	.2865	.2629	.2629	.2743		.2629
10	.2865	.2804	.2454	.2658	.2686	.2629	.2658
11	.2686	.2629	.2629	.2658	.2686	.2629	.2481
12	.2686	.2572	.2454	.2658	.2686		.2658
13	.2686	.2427	.2454	.2658			.2543
14	.2686	.2401	.2454	.2686		.2629	.2543
15	.2686	.2347	.2454	.2686		.2629	.2572
16	.2686	.2543		.2686	.2686	.2629	.2454
17	.2686	.2543	.2629	.2865	.2865	.2804	.2629
18	.2865	.2804	.2804	.3018	.2865	.3155	.3155
19	.4163	.3506	.4031	.415	.4344	.4207	.3429
20	.3801	.4075	.3506	.415	.4344	.3856	.3856
21	.3224	.3856	.333	.3772	.362	.3506	.3467
22	.2149	.2949	.2629	.2858	.2507		.2835
23	.1402	.2126	.1753	.2096	.1417		.1949
24	.1143	.1029	.1075	.0876	.132	.1029	.0876
Max	.4163	.4075	.4031	.415	.4344	.4207	.3856
Min	.0953	.0857	.0886	.0876	.0934	.1029	.0876
Avg	.2311	.2265	.2275	.2325	.2354	.2314	.2233

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 201 / 11 KV MHASURLI AG  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-APR-18
HR	Load (MW)
24	.1989
Max	.1989
Min	.1989
Avg	.1989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 202 / 11 KV MHASURLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.1829
Max	.1829
Min	.1829
Avg	.1829

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 144115 / 33/11KV VETAVADE S/STN

Feeder No / Name : 203 / 11 KV SULE AG

Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	01-APR-18
HR	Load (MW)
24	.4144
Max	.4144
Min	.4144
Avg	.4144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 201 / 11 KV Salawan Sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
18	.39
Max	.39
Min	.39
Avg	.39

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 202 / 11 KV SAVARDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.373
Max	.373
Min	.373
Avg	.373

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 203 / 11 KV VETAVDE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2035
Max	.2035
Min	.2035
Avg	.2035



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 204 / 11 KV Salawan Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.2378
Max	.2378
Min	.2378
Avg	.2378

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 205 / 11 KV WALOLI GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.2195
Max	.2195
Min	.2195
Avg	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 206 / Punal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.2035
Max	.2035
Min	.2035
Avg	.2035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 207 / Punal Sawarde Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2195
Max	.2195
Min	.2195
Avg	.2195

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 208 / 11 KV Waloli Sheti  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.2155
Max	.2155
Min	.2155
Avg	.2155

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 209 / 11 KV VETWADE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.2427
Max	.2427
Min	.2427
Avg	.2427

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KALE[036] BU 6149

Substation No/ Name :- 146007 / 110/33/11 KV Kale S/Stn

Feeder No / Name : 402 / 33 KV NAGRIKA

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.4003
Max	1.4003
Min	1.4003
Avg	1.4003

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 201 / 11 KV KAKHE AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3413	.1715	.12	.1524	.1067	1.6004	1.4022
2	1.3413	.1715	.12	.1219	.0914	1.6004	1.4327
3	1.3413	.1715	.12	.1219	.0914	1.5851	1.4632
4	1.3717	.1715	.1372	.1524	.0914	1.6004	1.4632
5	1.4327	.1715	.1715	.1677	.1219	1.7071	1.5546
6	1.6766	.2058	.2058	.1829	.1524	1.8595	1.7071
7		.2058	.2058	.1829	.1829	2.3777	2.1643
8		.2229	.2058	.1829	.1829	2.332	2.2862
9	.8535	.1829	.1524	.1829	.2743	2.1033	2.2253
10	2.2558	.0137	.0914	2.1338	.1219	.1524	.12
11	1.1888	.1524	.1219	2.5606	.1219	.1372	.1715
12	2.2405		2.7587	2.1338	.1219	.1372	.1543
13	2.7892	2.8502	2.7282	2.774	.1715	.0122	.1715
14	2.652	2.8807	2.8045	2.5301	.1715	.0122	.1715
15	2.8654	2.8197	2.6978	2.652	.1372	.0122	.1715
16	2.1948	2.9111	2.6673	2.6825	.1219	.0122	.1715
17	2.1491	2.7892	2.5758	2.652		.1543	.1981
18	2.2558	2.6216	2.4387	.1829	.1715	.2401	.1829
19	2.0576	2.1338	2.1338	.1829	.1715	.2572	.1829
20	.2229	.1886	.1829	.1829	.2058	.2401	.1829
21	.2058	.2058	.1829	.1829	.1715	.2058	.1829
22	.2058	.1886	.1677	.1524	.1715	.1886	.1829
23	.1715	.1543	.1524	.1219	.1372	.1886	.1524
24	1.3108	.1715	.1372	.1524	.1219	1.5546	1.3717
Max	2.8654	2.9111	2.8045	2.774	.2743	2.3777	2.2862
Min	.1715	.0137	.0914	.1219	.0914	.0122	.12
Avg	1.5511	.9459	.9700	.9469	.1484	.8446	.8111



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 202 / 11KV KODOLI URBAN VILLAGE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8059	.7888	.7888	.7373	.823	.8059
2	.7888	.7716	.7888	.7202	.6859	.7716	.8059
3	.7888	.7716	.7888	.6859	.6516	.7716	.8059
4	.7888	.7716	.8573	.7202	.6859	.7716	.8573
5	.823	.823	.8916	.7716	.7545	.7888	.9259
6	.8573	.8916	.9602	.823	.8573	.9774	.9774
7	.9602	.9602	.9431	.8916	.9259	1.046	.9945
8	.9945	1.0117	.9945	.8916	.9602	.9774	.9431
9	.9259	.9259	.8916	.9259	.8573	.8573	.9088
10	.9259	.9602	.8745	.8916	.8402	.7888	.9088
11	.9259	.8916	.8573	.9088	.5487	.8745	.9431
12	.8745		.9259	.8916	.5144	.8573	.9774
13	.9602	.9259	.8745	.8573	.5144	.9259	.9774
14	.9088	.9431	.8745	.823	.9259	.9259	.9088
15	.9259	.8916	.8573	.8916	.8916	.9431	.9088
16	.9259	.9259	.8573	.8916	.8916	.9602	.9259
17	.9774	.9602	.8916	.8573	.8573	1.0117	.9431
18	1.0117	1.0974	.9259	.9602	.9088	1.0631	1.0974
19	1.3032	1.3375	1.2003	1.2689	1.2346	1.3717	1.3717
20	1.3546	1.3717	1.2689	1.2689	1.3546	1.406	1.4746
21	1.2346	1.286	1.2346	1.166	1.2517	1.2689	1.2003
22	1.166	1.2003	1.0974	1.0631	1.2003	1.166	1.2003
23	.9945	.9945	.9259	.9945	1.046	.9602	.9602
24	.8573	.8402	.823	.823	.7888	.8573	.823
Max	1.3546	1.3717	1.2689	1.2689	1.3546	1.406	1.4746
Min	.7888	.7716	.7888	.6859	.5144	.7716	.8059
Avg	.9624	.9721	.9331	.9073	.8702	.9652	.9852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 203 / 11 KV FACTORY VILLAGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9945	.8573	.823	.7316	.8916	.8916	.7888
2	.9602	.823	.823	.7545	.823	.9259	.7716
3	.9602	.823	.7888	.7888	.7545	.8916	.7716
4	.9945	.8573	.823	.823	.7888	.8916	.823
5	1.0974	1.0631	1.0288	.9945	.8916	.8573	.9945
6	1.2689	1.2003	1.2174	1.166	.945	1.1317	1.2003
7	1.286	1.2346	1.406	1.3717	1.2346	1.2346	1.1145
8	1.3032	1.2517	1.3375	1.3717	1.2689	1.2346	1.166
9	1.3375	1.3032	1.1431	1.4403	1.1317	1.1145	1.2003
10		1.286	1.1431	1.2498	1.1831	1.2003	1.2174
11			1.0974	1.1126	.823	1.166	.9774
12	1.2346		1.0631	.823	.823	1.0288	.9259
13	1.166	1.2689	.9945	.8916	1.0288	1.1145	.9774
14	1.1831	1.166	1.2174	.8916	1.0288	1.0822	1.0802
15	1.2689	1.3203	1.2174	1.0974	1.0631	1.1831	1.0288
16	1.2346	1.1831	1.0117	1.1317	.8573	1.0802	1.1317
17	1.2517	1.2174	1.0974	1.0974	.9259	1.1831	
18	1.2346	1.166	1.0974	1.0288	1.046	1.2346	
19	1.3375	1.3032	1.0974	1.3717	1.286	1.3717	
20	1.4746	1.2346	1.166	1.2346	1.3032	1.406	.945
21	1.4232	1.3546	1.166	1.166	1.2689	1.3375	1.0288
22	1.3375	1.3717	.9145	1.0974	1.3032	1.2003	1.1317
23	1.0117	1.166	.7621	.9945	1.0631	.9945	.8916
24	1.0288	.8745	.8573	.8916	.823	.8573	.823
Max	1.4746	1.3717	1.406	1.4403	1.3032	1.406	1.2174
Min	.9602	.823	.7621	.7316	.7545	.8573	.7716
Avg	1.1995	1.1512	1.0539	1.0634	1.0232	1.1089	.9995

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 204 / 11 KV POKHALE Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.3258	.3429	.2743	.2743	1.0364	.9145
2	.7926	.3086	.3429	.2591	.2439	1.0212	.945
3	.7926	.3086	.3429	.2439	.2134	1.0212	.945
4	.823	.3086	.3429	.2439	.2439	1.0364	1.0059
5	.9145	.3429	.3772	.2743	.2743	1.1888	1.1584
6	1.0974	.3944	.4458	.3353	.3048	1.5699	1.3717
7	1.6156	.463	.463	.3963	.3658	2.21	1.89
8	1.6156	.4458	.4287	.3658	.3658	2.1948	1.9204
9	1.5546	.381	.3506	.3353	.4115	1.829	1.6766
10	.3258	.4268	.3658	1.0669	.3201	.2743	.3086
11	.4287	.4115	.3963	1.5089	.3353	.2439	.3772
12	1.4937		2.0271	1.829	.3353	.2439	.3772
13	1.5394	2.1795	1.9966	1.829	.3258	.3048	.3429
14	1.5242	2.1033	1.7833	1.7375	.3258	.2591	.3258
15	1.4784	1.9052	1.6156	1.6766	.3429	.2591	.3429
16	1.6156	2.0271	1.7071	1.9814	.3201	.3201	.3601
17	1.7223	2.0271	1.6461	1.9814	.3772	.4287	.381
18	1.4784	1.7985	1.3717	.3353	.4115	.4115	.381
19	1.0974	1.2193	1.0974	.3658	.4458	.4458	.4268
20	.3601	.3772	.3201	.3658	.4458	.4458	.3658
21	.4115	.3601	.3048	.3353	.463	.4458	.381
22	.3601	.3944	.3201	.3201	.4287	.4287	.3658
23	.3429	.3601	.3048	.3048	.4115	.4115	.3658
24	.7888	.3258	.3601	.2896	.3048	1.0364	.8535
Max	1.7223	2.1795	2.0271	1.9814	.463	2.21	1.9204
Min	.3258	.3086	.3048	.2439	.2134	.2439	.3086
Avg	1.0390	.8345	.7939	.7773	.3455	.7945	.7410

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 205 / 11 KV AMRUT AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2803	.1715	.12	.1219	.1219	1.6156	1.5242
2	1.3108	.1886	.12	.1067	.1067	1.6309	1.5242
3	1.3108	.1543	.12	.1067	.0914	1.6309	1.5242
4	1.3108	.1543	.12	.1372	.0914	1.6156	1.5546
5	1.5432	.1715	.1372	.1524	.1219	1.5546	1.6004
6	1.5699	.1715	.1715	.1677	.1524	1.8861	1.6766
7	1.8595	.2058	.2058	.1677	.1829	2.1033	2.0729
8	1.9052	.2058	.1715	.1981	.1829	2.1643	2.1338
9	1.9509	.1829	.1677	.1829	.2058	2.0119	2.0729
10	.1715	.1829	.1372	1.829	.1524	.1829	.2058
11	.1886	.2286	.1372	2.2253		.1829	.1543
12	2.0424		2.3929	2.2862		.2134	.1715
13	2.1643		2.4387	2.1033		.2134	.1715
14	2.21	2.4234	2.3472	2.1338		.1829	.2401
15	2.1491	2.5453	2.2253	2.1338		.2134	.2229
16	2.0729	2.4234	2.2253	2.2558		.2134	.1715
17	2.3148	2.4082	2.2558	2.1643	.2058	.2229	.2286
18	1.9966	2.2558	2.1033	.1524	.2229	.2401	.2439
19	1.7375	2.0424	1.829	.1677	.2572	.2058	.1677
20	.2229	.2229	.1829	.1524	.2401	.2058	.1677
21	.2058	.2058	.1829	.1372	.2229	.1886	.1829
22	.2058	.1886	.1524	.1524	.2229	.1715	.1829
23	.1886	.1715	.1372	.1524		.1372	.1524
24	1.2498	.1715	.1372	.1219	.1219	1.6004	1.5394
Max	2.3148	2.5453	2.4387	2.2862	.2572	2.1643	2.1338
Min	.1715	.1543	.12	.1067	.0914	.1372	.1524
Avg	1.3818	.7762	.8424	.8129	.1708	.8578	.8286

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 206 / 11 KV KAKHE VILLAGE FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.3944	.3772	.3429	.4458	.5487	.5144
2	.5144	.4115	.3772	.3086	.3658	.583	.5144
3	.4801	.3772	.3772	.3086	.3353	.5144	.5144
4	.4458	.3772	.4115	.3048	.3658	.4801	.5144
5	.4287	.4801	.5144	.3772	.3963	.463	.5487
6	.4287	.6173	.6859	.381	.4801	.463	.5144
7	.463	.6173	.4801	.4801	.4801	.463	.6173
8	.4458	.5487	.926	.4801	.4572	.4458	.5658
9	.4287	.4287	.4973	.5487	.4458	.4287	.6516
10	.4801	.463	.463	.5316	.3658	.4801	.6687
11	.5658	.4973	.4801	.4115	.4572	.463	.6173
12	.6687		.5316	.381	.5487	.6344	.4801
13	.6516	.4287	.5487	.3601	.6344	.6001	.5144
14	.6344	.4973	.5487	.3772	.6344	.4115	.4973
15	.6001	.4973	.5487	.4115	.4801	.4458	.4801
16	.5658	.5144	.4801	.5144	.3944	.4458	.4973
17	.5487	.4973	.3772	.4801	.3772	.6344	.5144
18	.5144	.5487	.5335	.4801	.3429	.5658	.4458
19	.6173	.6173	.5335	.6001	.583	.6001	.4268
20	.5487	.6687	.6859	.6516	1.2002	.6516	.463
21	.4801	.5658	.6001	.6344	1.3374	.6173	.5658
22	.4973	.4287	.4268	.6001	.5144	.5487	.5144
23	.4458	.3944	.3086	.5658	.5144	.5144	.3429
24	.583	.4115	.3944	.3429	.4801	.5658	.5487
Max	.6687	.6687	.926	.6516	1.3374	.6516	.6687
Min	.4287	.3772	.3086	.3048	.3353	.4115	.3429
Avg	.5244	.4906	.5045	.4531	.5265	.5237	.5222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 207 / 11 KV Jakhoba LIS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.1372		.12	.1219	.1372	.1372
4	.1372		.1372	.1219	.1372	.1372
5	.1372		.1372	.1219	.1372	.1372
6	.1372		.1372	.1219	.1372	.1372
7	.1372		.1372	.1219	.1372	.1372
8	.1372		.12	.1219	.1372	.1372
9	.1372		.1219	.1219	.0122	.1372
10	.1372		.1219	.1219	.0122	.1372
11	.1372		.1219	.1219	.0122	.1372
12	.1372	.0122	.0122	.1219	.0122	.1372
13	.1372	.0122	.0122	.1219	.0107	.1372
14	.1372	.0122	.0122	.1219	.0122	.1372
15	.1372	.1372	.0122	.1219	.0122	.1372
16	.1372	.1372	.0122	.1219	.0122	.1372
17	.1372	.1372	.1219	.1219	.1372	.1219
18	.1372	.1372	.1219	.1219	.0857	.0914
Max	.1372	.1372	.1372	.1219	.1372	.1372
Min	.1372	.0122	.0122	.1219	.0107	.0914
Avg	.1372	.0836	.0912	.1219	.0714	.1334

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144002 / 33/11 KV KODOLI

Feeder No / Name : 401 / 33 KV Biltube Express

Feeder Feeder KV- 33 /  
OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.3663	2.3663		2.0576	2.3663	2.4691	.4115
2	2.2634	2.5206	2.572	1.9547	2.4691	2.6749	.5144
3	2.1605	2.3148	2.3663	1.9547	2.4691	2.6749	.6173
4	2.2634	2.2634	2.4691	2.0576	2.2634	2.572	1.4403
5	2.3663	2.3663	2.4691	2.1605	2.1605	2.5206	1.5432
6	2.3148	2.4691	2.572	2.2634	2.0576	1.8519	1.6461
7	2.7778	2.6749	2.4691	2.0576	2.2634	2.6749	1.9547
8	2.572	2.6749	2.1605	1.9547	2.4177	2.4177	2.3663
9	2.572	2.4177	2.4691	2.0576	2.8807	2.572	2.1091
10	2.572	2.6749	2.6749	2.1605	2.3148	2.3148	2.9321
11	2.6235	2.6235	2.4691	2.8292	2.3148	2.1091	2.4691
12	2.9835	2.4691	2.8807	1.9033	2.3148	2.3663	2.3663
13	2.8292	2.3663	2.5206	2.0576	2.8807	2.572	2.3663
14	2.6235	2.6235	2.3148	2.4177	2.572	1.5432	2.4177
15	2.7263	2.6749	2.8292	2.5206	2.572	.0514	2.572
16	2.572	3.0864	2.8292	1.7375	2.4691	.0514	2.572
17	2.8292	1.4918	2.6235	1.9547	2.3148	.0514	2.4177
18	2.572	.9259	3.2922	2.4177	2.8292	.0514	2.5206
19	2.5206	2.7263	3.0864	2.4177	2.5206	.0514	2.6749
20	2.5206	2.4691	2.0576	2.2634	2.8807	.0514	2.6235
21	2.4177	2.3663	2.0576	2.6749	2.6749	.0514	2.7778
22	2.7778	2.9835		2.2634	2.8292	.2572	3.0864
23	2.3663	2.7778	2.1091	2.1091	2.4691	.3086	2.8807
24	2.4177		2.572	2.1605	2.3663	2.5206	.3601
Max	2.9835	3.0864	3.2922	2.8292	2.8807	2.6749	3.0864
Min	2.1605	.9259	2.0576	1.7375	2.0576	.0514	.3601
Avg	2.5420	2.4490	2.5393	2.1836	2.4863	1.5325	2.0683

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 201 / Single Phasing Stave- SINGLE PHASING  
 Sawarde Feeder KV- 11 /  
 OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0934	1.0395	.8817	.8478	.8478	.0693	.0754
2	.0934	1.0608	.9496	.9156	.8478	.0693	.0754
3	.0943	1.0608	.9496	1.0829	1.0174	.0686	.0754
4	.0943	1.0486	.9496	1.0174	1.0174	.0686	.0754
5	.1132	1.1142	1.0852	1.1869	1.0174	.0857	.0754
6	.1143	1.2597	1.2209	1.3904	1.3443	.104	.1132
7	.0953	1.7924	1.6598	1.7924	1.5684	.0953	.0943
8	.0762	1.848	1.8107	1.8861	1.7353	.0762	.0754
9	.0762	1.848	1.8107	1.7353	1.7528	.0572	.0566
10	.0716	.0537	.0747	.0566	1.0669	.9831	1.2826
11	.0716			.0572	1.6004	1.6598	1.7741
12	.0572			.0572	1.6766	1.8861	1.848
13	.0572		.0762	.0572	1.6766	1.7924	1.848
14	.0572		.0572	.0572	1.643	1.7177	1.6057
15	.0572		.0572	.0572	1.7177	1.7924	1.7177
16	.0572		.0572	.0572	1.7177	1.7924	1.7741
17	.0572		.0572	.0572	1.1523	1.7177	1.7002
18	.0762	.0953	.0762	.0762	.0724	.0716	.0724
19	.1334	.1143	.1494	.1132	.1307	.132	.1132
20	.1509	.1509	.1494	.1509	.1509	.1509	.1509
21	.1509	.1509	.1494	.1509	.1509	.1509	.1509
22	.1132	.132	.1307	.132	.132	.132	.132
23	.0953	.1132	.112	.1132	.0953	.0943	.0943
24	.0934	.8817	.8139	.823	.8573	.0693	.0943
Max	.1509	1.848	1.8107	1.8861	1.7528	1.8861	1.848
Min	.0572	.0537	.0572	.0566	.0724	.0572	.0566
Avg	.0896	.8096	.6036	.5780	1.0412	.6182	.6281



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 202 / Single Phasing Stave-  
Mohare Feeder KV- 11 /  
OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6975				2.0111	2.0748
2	1.7353				2.0111	2.1125
3	1.8484				1.989	2.1125
4	1.8861				1.989	2.1502
5	2.0957				2.0576	2.2634
6	2.2481				2.2192	2.3577
7	2.3624				2.6673	2.452
8	2.5149				2.6673	2.5274
9	2.6673				2.5149	2.4897
10				1.7353		
11				2.5911		
12	2.6673	2.6673		2.6673		
13	2.7435	2.7435	2.8197	2.6673		
14	2.7435	2.7435	2.8197	2.5149		
15	2.5911	2.4143	2.8197	2.5149		
16	2.5911	2.5911	2.8197	2.5149		
17	2.5149	2.5911	2.8197	2.4387		
18	2.4387	2.4387	2.6673			
19	2.21	2.21	2.3899			
24	1.643				1.9418	1.8861
Max	2.7435	2.7435	2.8197	2.6673	2.6673	2.5274
Min	1.643	2.21	2.3899	1.7353	1.9418	1.8861
Avg	2.2888	2.5499	2.7365	2.4556	2.2068	2.2426

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 203 / Single Phasing Stave- SINGLE PHASING  
 Satave Feeder KV- 11 /  
 OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.9724	.8139	.8478	.8139	.104	.0943
2	.0943	.9614	.8817	.9156	.8478	.0867	.0943
3	.0943	.9614	.8817	.9835	.8478	.0857	.0943
4	.1132	.9503	.8817	1.0174	.8817	.0857	.0943
5	.1334	1.0486	.8817	1.0852	.8817	.1029	.0943
6	.1334	1.1271	1.0174	1.153	1.1203	.1214	.132
7	.0953	1.419	1.358	1.3443	1.1949	.1143	.1132
8	.0953	1.4045	1.358	1.358	1.2826	.0953	.0943
9	.0953	1.3676	1.358	1.2071	1.2955	.0953	.0754
10	.0895	.0537	.0943	.0566	.9145	1.0486	1.358
11	.0716			.0572	1.1431	1.5089	1.4784
12	.0572			.0572	1.2955	1.5844	1.6263
13	.0572		.0762	.0762	1.3717	1.5684	1.6263
14	.0572		.0762	.0762	1.3443	1.419	1.4937
15	.0572		.0762	.0572	1.2696	1.4937	1.5684
16	.0762		.0762	.0572	1.307	1.4937	1.5524
17	.0572		.0762	.0572		1.4937	1.4784
18	.0953	.1143	.0953	.0943		.1075	.0905
19	.1524	.1334	.1307	.132	.168	.1509	.132
20	.1698	.1509	.1494	.1509	.1698	.1509	.1698
21	.1698	.1509	.1494	.1509	.1698	.1509	.1698
22	.1509	.1509	.1494	.1509	.1509	.1509	.1509
23	.1334	.132	.1307	.132	.1334	.132	.132
24	.0934	.8817	.7461	.78	.823	.1214	.1132
Max	.1698	1.419	1.358	1.358	1.3717	1.5844	1.6263
Min	.0572	.0537	.0762	.0566	.1334	.0857	.0754
Avg	.1015	.7047	.5208	.4999	.8830	.5611	.5844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

KODOLI[037] BU 6157

Substation No/ Name :- 144014 / 33/11 KV SATAVE

Feeder No / Name : 204 / Bhairavnath LIS Satave  
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0566	.0829	.0848	.0848	.0514	.0566
4	.0566	.0819	.0848	.0848	.0857	.0943
5	.0943	.0819	.0848	.0848	.0857	.0943
6	.0953	.0829	.0848	.0848	.0867	.0943
7	.0953	.0934	.0943	.0934	.0953	.0943
8	.0953	.0924	.0943	.0943	.0953	.0943
9	.0953	.0924	.0943	.0943	.0953	.0943
10	.0895	.0895	.0934	.0943	.0819	.0943
11	.0895	.0876	.0934	.0953	.0943	.0924
12	.0953	.0953	.0953	.0953	.0943	.0924
13	.0953	.0953	.0953	.0953	.0934	.0924
14	.0953	.0953	.0953	.0953	.0934	.0747
15	.0953	.0953	.0953	.0953	.0934	.0934
16	.0953	.0953	.0953	.0953	.0934	.0924
17	.0953	.0953	.0953	.0953	.0934	.0924
18	.0953	.0953	.0953	.0943	.0895	.0905
Max	.0953	.0953	.0953	.0953	.0953	.0943
Min	.0566	.0819	.0848	.0848	.0514	.0566
Avg	.0897	.0908	.0923	.0923	.0889	.0898

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 201 / Shahuwadi-Maan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0739	.0732	.0686	.0716	.0566	.0732	.0732
2	.0732	.0732	.0686	.0716	.0566	.0732	.0732
3	.0732	.0732	.0678	.0716	.0566	.0732	.0732
4	.0914	.0732	.0671	.0895	.0566	.0914	.0732
5	.1097	.1097	.0838	.1267	.0754	.128	.0732
6	.1478	.1463	.1357	.1448	.1132	.1646	.1463
7	.181	.1829	.1715	.1612	.1509	.2149	.1463
8	.2126	.1829	.1886	.1928	.1791	.2427	.1646
9	.1928	.1907	.1715	.2058	.1715	.2126	.1715
10	.1791	.1753	.1341	.1715	.1696	.1907	.1865
11		.1791	.1326	.112	.1492	.2035	.1886
12		.12	.1387	.144	.1677	.1734	.1907
13	.1886	.0857	.1638	.128	.1966	.1715	.1865
14	.2012	.0905	.1658	.1311	.1823	.1677	.1526
15	.2035	.1052	.1677	.128	.1677	.156	.1387
16	.1823	.128	.2035	.125	.1658	.1543	.1387
17	.1886	.1402	.2401	.1094	.1823	.1753	.1753
18	.2058	.1629	.2454	.1372	.2058	.1949	.2126
19	.2401	.1629	.2658	.1829	.2353	.2126	.2353
20	.2629	.1646	.2715	.2378	.2896	.2507	.2561
21	.2279	.1478	.2743	.2218	.2896	.2149	.2195
22	.1791	.1294	.2195	.1698	.2534	.181	.1867
23	.1463	.112	.1267	.0943	.168	.1463	.1494
24	.1294	.1097	.0857	.1075	.0754	.112	.1097
Max	.2629	.1907	.2743	.2378	.2896	.2507	.2561
Min	.0732	.0732	.0671	.0716	.0566	.0732	.0732
Avg	.1677	.1299	.1608	.1390	.1590	.1658	.1551

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 202 / Shahuwadi- Amba

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1509	.112	.1646	.132	.1132	.1509	.1494
2	.1132	.112	.1646	.1132	.1132	.132	.1494
3	.1132	.112	.1463	.1132	.1132	.132	.1494
4	.132	.112	.1448		.1509	.132	.1494
5	.1886	.168	.1612	.1509	.1698	.1886	.1867
6	.2075	.2614	.2195	.1698	.2075	.2452	.2241
7	.2587	.2987	.2534	.2241	.2641	.2987	.2957
8	.2957	.3361	.2926	.2957	.2896	.3326	.3658
9	.3292	.3582	.3361	.3224	.3045	.3801	.3761
10	.3326	.3582	.3403	.3582	.3258	.3582	.3898
11	.2865	.3841	.3658	.3582		.3403	.3258
12		.3761	.3801	.3582	.2926	.3582	.3224
13	.2926	.3658	.3258	.3258	.3258	.3258	.3439
14	.4024	.2896	.3439	.3258	.3258	.3439	.3077
15	.4163	.2865	.3403	.2865	.3292	.3224	.3439
16	.3077	.2481	.3403	.2896	.3258	.3224	.3439
17	.3109	.2534	.3258	.2353	.2715	.3258	.3439
18	.3292	.2896	.3258	.2561	.3258	.3292	.362
19	.3475	.3206	.3292	.2957	.3801	.3292	.3801
20	.3658	.2835	.3292	.2987	.3658	.3475	.3658
21	.2926	.2534	.2957	.2829	.3142	.2987	.3326
22	.2587	.2218	.2614	.2452	.2641	.2614	.3018
23	.1867	.2218	.1886	.2263	.2263	.2241	.2452
24	.1886	.1494	.181	.1698	.1509	.1886	.1867
Max	.4163	.3841	.3801	.3582	.3801	.3801	.3898
Min	.1132	.112	.1448	.1132	.1132	.132	.1494
Avg	.2655	.2572	.2732	.2536	.2587	.2778	.2892

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 203 / Shahuwadi-sawe  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.2801	.2641	.2263	.2263	.2263
2	.2263	.2263	.2614	.2263	.2263	.2263	.2263
3	.2263	.2263	.2587	.2263	.2263	.2263	.2263
4	.2641	.2263	.2614	.2263	.2641	.2263	.2263
5	.2641	.2641	.2987	.2641	.2641	.2641	.3018
6	.3395	.3395	.3326	.2829	.3018		.3584
7	.3734	.3772	.3734	.3361	.3395	.3734	.415
8	.4108	.415	.4715	.3696	.3547	.4251	.4481
9	.4435	.4207	.462	.4163	.362	.4344	.4938
10	.4024	.4251	.4572	.4207	.4251	.4163	.4525
11	.4251	.4251	.4066	.439	.4525	.3326	.4207
12	.4108	.4066	.3361	.4024	.4024	.3696	.3511
13	.3841	.3734	.3326	.4024	.3439	.3142	.3174
14	.362	.3206	.2801	.4024	.3696	.3841	.2614
15	.3109	.2987	.2801	.4024	.3734	.3801	.2801
16	.3077	.2587	.3475	.3658	.3475	.3801	.3841
17	.3292	.2987	.4024	.3658	.3658	.4024	.4024
18	.4755	.3734	.4435	.4024	.4435	.4755	.439
19	.5487	.4904	.4854	.462	.499	.5487	.4938
20	.5853	.4481	.5601	.5975	.5601	.5853	.5544
21	.5121	.4066	.5601	.547	.5415	.5544	.4805
22	.4435	.3734	.4854	.4527	.4527	.4854	.4527
23	.3734	.3395	.3772	.3206	.3395	.3961	.3961
24	.2829	.2641	.3018	.2829	.2641	.2641	.2829
Max	.5853	.4904	.5601	.5975	.5601	.5853	.5544
Min	.2263	.2263	.2587	.2263	.2263	.2263	.2263
Avg	.3720	.3427	.3773	.3699	.3644	.3779	.3705

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 204 / Shahuwadi-Kotoli Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1677	.192	.2012		
2		.1658	.192	.2012		
3		.1677	.1966	.2347		
4		.1658	.2294	.2347		
5		.2683	.2622	.2515		
6		.3353	.2949	.285		
7		.4024	.3688	.4024		
8		.4191	.4359	.4807		
9		.3647	.4359	.5365		
10				.4917	.4409	.4409
11				.4641	.5658	.5487
12	.6036			.5304	.6001	.5596
13	.6344			.5868	.583	.5533
14	.5898			.5197	.5596	.5365
15	.5765			.5304	.5935	.5365
16	.5365			.5365	.5765	.5087
17	.503			.4694	.4973	
18	.4588					
19	.3932					
24			.1739	.1677		
Max	.6344	.4191	.4359	.5868	.6001	.5596
Min	.3932	.1658	.1739	.1677	.4409	.4409
Avg	.5370	.2730	.2782	.3958	.5521	.5263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 205 / Shahuwadi - Malkapur  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.3018	.3772	.2641	.2641	.2641	.3018
2	.3018	.3018	.3734	.2641	.2641	.2641	.3018
3	.3018	.3018	.3584	.2641	.0754	.2641	.3018
4	.3395	.3018	.3584	.2641	.3018	.2641	.3018
5	.3772	.3395	.3734	.3018	.3395	.3395	.3772
6	.415	.3772	.415	.3772	.415	.3961	.3961
7	.415	.4338	.4481	.4108	.4481	.4481	.4481
8	.4527		.4527	.4481	.4668	.4854	.4668
9	.4854	.5041	.4481	.462	.499	.4668	.4854
10	.5175	.5175	.5175	.499	.4668	.5041	.499
11	.5415	.5228	.5228	.499	.5041	.5228	.4251
12	.5175	.499	.5228	.4805	.499	.5228	.5041
13	.5041	.5175	.5041	.4805	.5041	.5415	.5359
14	.5175	.5041	.5415	.4572	.5041	.5729	.5359
15	.5359	.5175	.5281	.4755	.5544	.5914	.5729
16	.5121	.5228	.5041	.4755	.5601	.5853	.5228
17	.5121	.5415	.5228	.5121	.5041	.6036	.5975
18	.5487	.5914	.5601	.5544	.5601	.6722	.6348
19	.6219	.6089	.6161	.5975	.6348	.7282	.7468
20	.7023	.5853	.6722	.6348	.6722	.7468	.7095
21	.6283	.543	.6413	.5658	.6413	.6722	.5975
22	.5601	.5175	.5658	.5281	.5281	.6036	.5228
23	.4904	.4481	.4338	.4338	.4338	.4527	.4527
24	.3772	.3772	.3734	.3584	.3395	.3395	.3772
Max	.7023	.6089	.6722	.6348	.6722	.7468	.7468
Min	.3018	.3018	.3584	.2641	.0754	.2641	.3018
Avg	.4782	.4642	.4846	.4420	.4575	.4938	.4840



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 206 / Shahuwadi-Parale Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.5487	.0137	.0076	.0076	.5487	.5487
2	.5487	.5487	.0088	.0076	.0076	.5487	.5487
3	.583	.5487	.013	.008	.0076	.6516	.5487
4	.6241	.5487	.0107	.008	.0076	.7545	.583
5	.6661	.6173	.0099	.0084	.0076	.823	.6516
6	.7011	.7545	.0105	.0088	.0072	.8573	.7537
7	.8669	.9114	.013	.0099	.0084	.9602	.9114
8	.9602	1.0867	.013	.0122	.0118	1.0288	.964
9	.8842	.7969	.013	.012	.0128	.9882	.8916
10	.0198	.0259	.013	.9945	.0198	.0251	.008
11		.0347	.0111	1.0288	.0111	.0194	.0156
12		.9496	1.0229	1.1317	.008	.0091	.008
13	.0171	.9389	1.0974	1.166	.007	.0145	.0088
14	.0183	.9054	.9945	1.166	.0069	.0164	.0091
15	.0191	.8718	1.046	1.166	.0072	.0152	.0084
16	.005	.7956	1.0631	1.1191	.0059	.0156	.0217
17	.0057	.7625	1.0288	1.0513	.0065	.016	.0206
18	.0137	.6882	.9259	.0152	.0099	.016	.0198
19	.0152	.6203	.8817	.013	.0128	.016	.0191
20	.016	.0248	.0297	.0084	.0095	.016	
21	.016	.021	.0179	.0095	.008	.0168	.0152
22	.0175	.0091	.0091	.0072	.0076	.0168	.013
23	.0175	.0105	.0093	.007	.0076	.0175	.0114
24		.5487	.013		.0076	.4801	.6173
Max	.9602	1.0867	1.0974	1.166	.0198	1.0288	.964
Min	.005	.0091	.0088	.007	.0059	.0091	.008
Avg	.3126	.5654	.3445	.3898	.0089	.3280	.3129

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 207 / Shahuwadi-Bajagewadi Ag FEEDER SEPERATION/PURE AG  
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3812	.3353	.3772		
2		.3605	.3353	.3772		
3		.3688	.3353	.3772		
4		.3647	.3353	.3772		
5		.4359	.3688	.4115		
6		.503	.3856	.4287		
7		.5304	.4694	.4801		
8		.5312	.5533	.5365		
9		.57	.503	.5868		
10				.5487	.5426	.4917
11				.4807	.6443	.6344
12	.6036			.5365	.5935	.6443
13	.6613			.5801	.5144	.5935
14	.6539			.547	.5426	.5935
15	.6613			.5365	.5765	.5658
16	.6371			.5487		.5765
17	.503			.5365	.6173	.583
18	.5243					
19	.4588					
24		.4024	.3391	.3429		
Max	.6613	.57	.5533	.5868	.6443	.6443
Min	.4588	.3605	.3353	.3429	.5144	.4917
Avg	.5879	.4448	.3960	.4783	.5759	.5853

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 208 / Shahuwadi-Perid Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2774				.3429	.3277
2	.2774				.3429	.3277
3	.2774				.4115	.3277
4	.3121				.4115	.3277
5	.3814				.4458	.3688
6	.4161				.4801	.4024
7	.6241				.6173	.5487
8	.7362				.7202	.6859
9	.8669				.6415	.6687
10				.631		
11				.6859		
12	.8383	.8149	.9536			
13	.8987	.8916	.9088	.823		
14	.8916	.9945	.9536	.823		
15	.8139	.9389	.9015	.7377		
16	.8215	.8916	.7888	.6706		
17	.7042	.8573	.7545	.6371		
18	.6859	.7545	.6859			
19	.5487	.5868	.6036			
24	.2774				.3086	.3605
Max	.8987	.9945	.9536	.823	.7202	.6859
Min	.2774	.5868	.6036	.631	.3086	.3277
Avg	.5916	.8413	.8188	.7155	.4722	.4346

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144011 / 33/11 KV SHAHUWADI

Feeder No / Name : 209 / Shahuwadi-Ameni vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191	.0191	.0189	.0189	.0189	.0191
2	.0189	.0191	.0191	.0189	.0189	.0189	.0191
3	.0189	.0191	.0191	.0189	.0189	.0189	.0191
4	.0189	.0191	.0191	.0189	.0189	.0189	.0191
5	.0189	.0191	.0191	.0189	.0189	.0189	.0191
6	.0189	.0377	.0191	.0189	.0189	.0189	.0381
7	.0377	.0377	.0191	.0377	.0377	.0377	.0377
8	.0377	.0377	.0381	.0377	.0377	.0377	.0377
9	.0377	.0377	.0191	.0377	.0377	.0377	.0381
10	.0377	.0377		.0377	.0377	.0377	.0381
11	.0377	.0377	.0377	.0377	.0377	.0377	.0377
12	.0377	.0377	.0377	.0377	.0377	.0377	.0377
13	.0377	.0377	.0377	.0377	.0377	.0377	.0377
14	.0377	.0377	.0377	.0377	.0377	.0377	.0377
15	.0377	.0377	.0377	.0377	.0377	.0377	.0377
16	.0377	.0377	.0377	.0377	.0377	.0377	.0377
17	.0377	.0377	.0377	.0377	.0377	.0377	.0377
18	.0377	.0377	.0377	.0377	.0377	.0377	.0377
19	.0377	.0377	.0377	.0377	.0377	.0377	.0377
20	.0377	.0189	.0377	.0377	.0377	.0377	.0377
21	.0377	.0191	.0377	.0377	.0377	.0377	.0377
22	.0377	.0191	.0377	.0377	.0377	.0377	.0377
23	.0191	.0377	.0189	.0189	.0189	.0191	.0189
24	.0189	.0191	.0191	.0189	.0189	.0189	.0191
Max	.0377	.0377	.0381	.0377	.0377	.0377	.0381
Min	.0189	.0189	.0189	.0189	.0189	.0189	.0189
Avg	.0314	.0307	.0296	.0314	.0314	.0314	.0323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 201 / SARUD-BAMBAWADE VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.8402	.8402	.8589	.8962		.8962
2	.9335	.7842	.8402	.8215	.8402		.8402
3	.9335	.7842	.7842	.8215	.8402		.8402
4	.9335	.7842	.8215	.8962	.8402		.9335
5	1.1203	.7842	1.0269	.9709	.8962		1.0456
6	1.1576	.9522	1.1203	1.0456	.9896		1.1203
7	1.1763	1.0829	1.1389	1.1389	1.2136		1.307
8	1.2883	1.2323	1.1389	1.2136	1.2696		1.1389
9	1.1949	1.2323	.9896	1.2136	.9522		.9896
10	1.2883	1.2696	1.0269	1.2136	1.0456	1.1576	.9896
11	1.307	1.1203	1.0829	1.1389	.8215	1.2136	1.1576
12	1.1763	1.0456	1.2136	1.1016	1.1203	1.1763	.9709
13	1.0642		1.363	1.0269		1.1763	1.0269
14	.9896	.9149	1.1576	1.0269	.9709	1.1763	1.0829
15	1.1203	1.2136	1.0829	1.0642	.7468	1.0642	1.0829
16	1.1389	1.2136	1.1576	1.0642		1.1389	1.0456
17	1.0269	1.2136	1.1576	1.1389	1.1203	1.2136	1.0642
18	.8402	1.2136	1.4377	1.3817	1.2696	1.2136	1.2883
19	1.4563	1.1203	1.3443	1.3256	1.3443	1.4937	1.3817
20	1.643	1.1203	1.4937	1.6804	1.4937	1.643	1.7551
21	1.587	1.1203		1.531	1.4937	1.4937	1.6057
22	1.475	1.1203	1.419	1.3817	1.363	1.419	1.307
23	1.0829	1.0456	1.0456	1.0456	1.1203	1.0456	1.0829
24	.9335	.9335	.9335	.8962	.9522		.8962
Max	1.643	1.2696	1.4937	1.6804	1.4937	1.643	1.7551
Min	.8402	.7842	.7842	.8215	.7468	1.0456	.8402
Avg	1.1584	1.0496	1.1138	1.1249	1.0727	1.2590	1.1187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 202 / Sarud-Bhedasgaon

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2987	.2987	.2801	.2987		.3361
2	.2801	.2801	.2801	.2614	.2987		.2987
3	.2801	.2801	.2801	.2614	.2801		.2987
4	.2801	.2801	.2801	.2987	.2801		.3361
5	.2987	.3361	.3361	.3734	.2987		.3734
6	.3734	.4481	.3734	.4108	.3921		.4481
7	.4668	.4854	.4481	.4108	.4854		.4481
8	.5228	.5041	.5228	.4854	.5415		.4481
9	.5228	.5041	.4668	.5228	.5228		.4481
10	.5041	.5228	.4481	.4481	.4108	.5415	.4481
11	.4108	.4481	.4294	.3921	.4481	.5228	.4108
12	.4481	.4481	.4481	.3734	.4481	.5041	.4481
13	.4668		.4481	.4108		.4854	.4294
14	.4854	.4854	.4294	.4481	.3361	.4854	.4481
15	.4668	.4854	.3734	.4481	.2987	.4854	.4108
16	.4668	.4854	.4108	.4481		.4854	.4668
17	.5228	.5228	.4108	.4668	.3734	.5601	.4854
18	.4854	.5228	.4108	.4854		.5228	.5041
19	.5601	.5228	.5601	.5228	.5975	.5601	.5228
20	.6348	.4854	.5975	.5975	.6722	.6348	.6161
21	.6348	.4481		.5601	.6348	.5975	.6161
22	.5601	.4481	.5228	.5041	.5601	.4854	.5228
23	.4108		.3361	.4294	.4108	.4108	.4854
24	.2987	.3361	.3734	.2987	.3361		.3361
Max	.6348	.5228	.5975	.5975	.6722	.6348	.6161
Min	.2801	.2801	.2801	.2614	.2801	.4108	.2987
Avg	.4450	.4354	.4124	.4224	.4250	.5201	.4411

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 203 / Sarud-Sarud Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1867	.168	.1494	.1867	.1867		.1867
2	.1867	.1494	.1494	.1509	.168		
3	.181	.1494	.1494	.1494	.168		.168
4	.1867	.1494	.1494	.168	.168		.2241
5	.2241	.1867	.168	.2241	.1867		.2241
6	.2427	.2427	.1867	.2614	.2241		.2614
7	.2427	.2614	.2054	.2614	.2427		.2614
8	.2172	.2614	.2241	.2241	.2427		.2614
9	.2987	.2427	.2241	.2614	.2427		.2241
10	.2614	.2241	.2241	.2614	.2241		.2241
11	.2241	.2241	.2427	.2241	.2614	.2427	.2427
12	.2241	.2241	.2427	.2241	.2614	.2054	.2054
13	.2241		.2427	.1867		.2987	.2054
14	.2241	.2614	.2054	.1494	.1867	.2801	.2241
15	.2241	.2241	.1867	.2054	.2614	.2801	.2241
16	.2427	.2614	.2241	.2241		.2801	.2427
17	.2987	.2987	.2241	.2241	.1867	.2987	
18	.2987	.2801	.2614	.2614	.2241	.2987	.3174
19	.2987	.2614	.2987	.2614	.3174	.3734	.3361
20	.4294	.2614	.3734	.3547	.3734	.3734	.4294
21	.3921	.2427		.3361	.2987	.3361	.3734
22	.3361	.2241	.2987	.3174	.2427	.2987	.3361
23	.2801	.1867	.2614	.2614	.2241	.2614	.2614
24	.2241	.2054	.1867	.2054	.2054		.2241
Max	.4294	.2987	.3734	.3547	.3734	.3734	.4294
Min	.181	.1494	.1494	.1494	.168	.2054	.168
Avg	.2562	.2257	.2208	.2327	.2317	.2944	.2572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 204 / Sarud-Gogawe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	1.0456	1.1203	.8215	.0187		.0191
2	.0191	1.0269	1.1203	.7842	.0187		.0191
3	.0191	1.0269	1.1576	.7468	.0187		.0191
4	.0191	1.0642	1.1576	.8589	.0187		.0191
5	.0191		1.2136	1.0456	.0187		.0191
6	.0191	1.7364	1.4937	1.1827	.0187		.0191
7	.0191	1.9605	1.7177	1.6095	.0187		.0191
8	.0191	2.1658	2.0165	1.829	.0187		.0191
9	.0191	1.9605	2.0165	1.8671	.0187		.0191
10	.0187	.0191	.0191	.0187	1.829	2.3525	1.8442
11	.0187	.0191	.0191	.0187	2.2405	2.4272	1.6766
12	.0187	.0191	.0191	.0187	2.2405	2.4832	1.7604
13	2.4646		.0191	.0187		2.3339	1.7604
14	2.4272	.0191	.0191	.0187	2.1948	2.2405	1.8442
15	2.3152	.0191	.0191	.0187	2.2405	2.2405	1.9281
16	2.3152	2.3152	.0187	.0187		2.3525	1.8442
17	2.2405	2.2405	.0191	.0187	2.2405	2.2592	1.9605
18	2.1472	2.1472	.0191	.0187	.0191	.0191	.0187
19	1.6804	1.6804	.0191	.0187	.0191	.0191	.0187
20	.0187	.0187	.0191	.0187	.0191	.0191	.0187
21	.0187	.0187		.0187	.0191	.0191	.0187
22	.0187	.0187	.0191	.0187	.0191	.0191	.0187
23	.0187	.0187	.0191	.0187	.0191	.0191	.0187
24	.0191	1.0456	1.0269	.8215	.0187		.0191
Max	2.4646	2.3152	2.0165	1.8671	2.2405	2.4832	1.9605
Min	.0187	.0187	.0187	.0187	.0187	.0191	.0187
Avg	.6630	.9812	.6212	.4929	.6040	1.3432	.6217



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 205 / Sarud-Shirgaon Village  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.112	.112	.1132	.112		.112
2	.0953	.0934	.112	.0943	.0934		.0934
3	.0953	.0934	.112	.0943	.0934		.0934
4	.0953	.0934	.112	.112	.0934		.112
5	.1524	.112	.1494	.1494	.112		.1307
6	.0191	.1494	.168	.168	.1307		.1494
7	.0191	.2054	.1867	.1867	.1494		.168
8	.1905	.1867	.1867	.2054	.2054		.168
9	.1867	.2054	.1867	.2054	.1867		.1867
10	.2241	.2054	.1867	.2054	.2241	.2054	.1867
11	.2241	.1867	.1867	.168	.168	.2054	.1494
12		.1494	.1867	.168	.1494	.1867	.168
13	.1494	.1494	.1494	.1494		.1307	.1494
14	.1494	.1307	.168	.1307	.1494	.1307	.1494
15	.1494	.1494	.1494	.1494	.1307	.1307	.168
16	.1494	.168	.112	.1494		.1494	.1494
17	.1867	.1867	.1494	.168	.1494	.1307	.1307
18	.2241	.2241	.1867	.168	.168	.1494	.1307
19	.2614	.2614	.2241	.2241	.2614	.2614	.2427
20	.2987	.2241	.2614	.2987	.2801	.2987	.2987
21	.2427	.2054		.2801	.2427	.2427	.2427
22	.2054	.1867	.2427	.1867	.1867	.2241	.2054
23	.1494	.1494	.1867	.1494	.1494	.1494	.168
24	.1143	.112	.112	.112	.112		.1307
Max	.2987	.2614	.2614	.2987	.2801	.2987	.2987
Min	.0191	.0934	.112	.0943	.0934	.1307	.0934
Avg	.1607	.1642	.1664	.1682	.1613	.1854	.1618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 206 / Sarud-Salashi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	1.4937	1.531	1.4449	.2427		.2614
2		1.4937	1.4937	1.419	.2427		.2614
3		1.531	1.531	1.39	.2427		.2614
4		1.587	1.587	1.4632	.2427		.2987
5		1.7924	1.7737	1.6095	.2614		.2987
6		2.2965	2.6139	2.0328	.2987		.3174
7		2.6326	2.6699	2.6612	.3174		.3361
8		2.782	2.8753	3.0123	.3547		.3734
9	.3547	2.5766	2.7073	2.7446	.2987		.3734
10	.2987	.2987	.2801	.2614	2.1658	2.1285	2.2466
11	.2987	.2427	.2801	.3361	1.1389	3.0247	2.6825
12	.2987	.2614	.2801	.2614	3.1554	3.1927	2.9874
13	3.0807	.2614	.2801	.2801		2.7446	2.7161
14	2.9874	.2427	.2801	.3174	2.9081	2.838	2.6825
15	2.8006	.2614	.2801	.3361	2.9874	2.8567	2.4646
16	2.7073	.3361	.3174	.3547		2.8753	2.5987
17	2.6886	.2987	.3174	.2801	2.7446	2.8753	1.7604
18	2.5579	.3174	.1867	.3174	.2858	.3361	.056
19	2.1098	.3361	.3734	.3361	.3429	.3734	.3734
20	.2801	.2987	.3361	.3547	.381	.3734	.3734
21	.2801	.2801		.2801	.3429	.3361	.3734
22	.2241	.2614	.2987	.2801	.3048	.2987	.3174
23	.2614	.2427	.2801	.2801	.3048	.2987	.2801
24	.2286	1.5123	1.4937	1.475	.2829		.2987
Max	3.0807	2.782	2.8753	3.0123	3.1554	3.1927	2.9874
Min	.2241	.2427	.1867	.2614	.2427	.2987	.056
Avg	1.2756	.9849	1.0464	.9803	.9021	1.7537	1.0414

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 207 / Sarud-Thergaon Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0187	.0373	.0191	.5975		.5601
2		.0187		.0191	.5975		.5601
3		.0187	.0373	.0191	.5975		.5601
4		.0187	.0373	.0191	.5975		.6722
5		.0187	.0373	.0191	.6722		.7842
6		.0187	.0373	.0191	.7655		1.0456
7		.0187	.0373	.0191	1.2696		1.4045
8		.0187	.0373	.0191	1.3256		1.6263
9	1.4937	.0187	.0373	.0191	1.1763		1.3817
10	.0187	.0191	.0191	1.251	.0191	.0187	.0191
11	.0187	.0191	.0191	1.5497	.0191	.0187	.0191
12		1.9035	1.5089	1.643	.0191		.0191
13	.0373	1.9418	1.5592	1.531		.0187	.0191
14	.0373	1.848	1.4586	1.5497	.0191	.0187	.0191
15	.0373	1.7924	1.5424	1.587	.0191	.0187	.0191
16	.0373	1.7737	1.5089	1.6057		.0187	.0191
17	.0373	1.7375	1.5089	1.531	.0191	.0187	.0191
18	.0373	1.587	1.5123	.0187	.0191	.0191	.0187
19	.0373	1.363	1.307	.0187	.0191	.0191	.0187
20	.0373	.0373	.0191	.0187	.0191	.0191	.0187
21	.0373	.0373		.0187	.0191	.0191	.0187
22	.0373	.0373	.0191	.0187	.0191	.0191	.0187
23	.0187	.0373	.0191	.0187	.0191	.0191	.0187
24		.0187	.0373	.0191	.5975		.5975
Max	1.4937	1.9418	1.5592	1.643	1.3256	.0191	1.6263
Min	.0187	.0187	.0191	.0187	.0191	.0187	.0187
Avg	.1373	.5967	.5608	.5230	.3830	.0189	.3941

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 208 / 11 KV Haritkranti Bhadale

PURELY LIS FEEDERS

LIS Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
7			.2054	.2075		.2801
8			.2801	.2801		.2801
9	.2896		.2801	.2801		.2801
10	.2801			.2801		.2515
11	.2801		.2515	.2801	.2801	.2515
12	.2801		.2515	.2801	.2801	.2515
13	.2801		.2515	.2801	.2801	.2515
14	.2801	.2801	.2515	.2801	.2801	.2515
15	.2801	.2801	.2515	.2801	.2801	.2515
16	.2801	.2801	1.0395	.2801	.2801	.2683
17	.2801	.2801	.2515	.2801	.2801	
18	.2801	.2801	.2801	.2801	.2801	
Max	.2896	.2801	1.0395	.2801	.2801	.2801
Min	.2801	.2801	.2054	.2075	.2801	.2515
Avg	.2811	.2801	.3267	.2741	.2801	.2618

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144012 / 33 /11 KV SARUD

Feeder No / Name : 209 / Sarud-Nerle Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0373	.0373	.0381			.8402
2		.0373	.0373	.0381	.9896		.8215
3		.0373	.0373	.0381	.9896		.8215
4		.0373	.0373	.0381	.9896		.8962
5		.0373	.0373	.0381	1.1389		1.1016
6		.0373	.0373	.0381	1.2883		1.5708
7		.0373	.0373	.0381	1.8484		1.8296
8		.0373	.0373	.0381	1.9231		2.0144
9	2.0119	.0373	.0373	.0381	1.6991		1.7177
10	.0373	.0381	.0373	1.5684	.0381	.0373	.0381
11	.0373	.0381	.0373	2.4459	.0381	.0373	.0381
12	.0373	2.7351	1.6766	1.6057	.0381	.0373	.0381
13	.0373		1.8442			.0373	.0381
14	.0373	2.6242	.3353	2.3525	.0381	.0373	.0381
15	.0373	2.7633		2.4272	.0381	.0373	.0381
16	.0373	2.6326	2.3472	2.4459		.0373	.0381
17	.0373	2.4326	2.3807	1.9791	.0381	.0373	.0373
18		2.3899	2.2779	.0373	.0381	.0381	.0373
19		1.9231	1.9978	.0373	.0381	.0381	.0373
20		.0373	.0381	.0373	.0381	.0381	.0373
21		.0373		.0373	.0381	.0381	.0373
22	.0373	.0373	.0381	.0373	.0747	.0381	.0373
23	.0373	.0373	.0381	.0373	.0762	.0381	.0373
24		.0373	.0373	.0381	1.0082		.8775
Max	2.0119	2.7633	2.3807	2.4459	1.9231	.0381	2.0144
Min	.0373	.0373	.0373	.0373	.0381	.0373	.0373
Avg	.2168	.7869	.6101	.6708	.5908	.0376	.5425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 202 / Manjare-Vishalgad

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.197
Max	.197
Min	.197
Avg	.197

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 203 / Manjare- Anuskura Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.0171
Max	.0171
Min	.0171
Avg	.0171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144077 / 33/11 Kv Manjare

Feeder No / Name : 401 / 33 Kv Gelawade Generation

Feeder KV- 33 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.0572
Max	.0572
Min	.0572
Avg	.0572



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 201 / 11 Kv Warul-Amba

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4527	.1886		.3772	.3258	
2	.3982	.415	.1905		.3772	.3077	
3	.3658	.415	.1905		.381	.2743	
4	.3696	.4191	.1905		.381	.3258	.3475
5	.4435	.4572	.2263		.4001	.3982	
6	.5316	.6097	.2614		.5144	.4835	.5853
7	.6838	.7167	.3511		.6348	.6733	
8	.8939	.8686	.5601	.6733	.6838	.6733	.7164
9	.929	.8413	.6722	.8505	.6767	.691	.8764
10	.6241	.6697	.5144		.7602	.7265	.4115
11	.8413	.8059	.8745			.6878	.39
12	.8954	.7522	.7362		.6401	.6516	.373
13	.7701	.6805			.6219	.5138	.4578
14	.7522	.6516			.6154	.5847	.6588
15	.7164	.724			.6154	.6379	.7975
16	.7164	.724			.6219	.6447	.703
17		.6762			.724	.691	.7455
18		.724			.7442	.7087	.6371
19		.8871			.9036	.905	.8573
20		.9709			.9214	.9134	.8745
21		.8488			.8954	.8059	.7888
22		.8488			.8688	.7343	.6935
23	.5228	.679			.543	.543	.6344
24	.583	.4481	.5281	.4344	.4108	.3841	.4024
Max	.929	.9709	.8745	.8505	.9214	.9134	.8764
Min	.3658	.415	.1886	.4344	.3772	.2743	.3475
Avg	.6492	.6786	.4219	.6527	.6223	.5952	.6290

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 202 / 11 Kv Warul -Yelur  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.017	.9835	.9724		.0171		
2	.0168	.9724	1.0059		.0171		
3	.0171	.9835	1.0174		.0171		
4	.0168	1.0174	1.0059		.0171		
5	.0168	1.0852	1.1191		.0171		
6		1.1736	1.2887		.0171		.0187
7	.0171	1.4752	1.5769		.0171		
8	.0171	1.6766	1.8442	1.668	.0171	.0177	.0181
9		1.7295	1.4419		.0171		.0179
10	.0171	.0343			1.2407	1.4091	1.4083
11	.0171				1.6766	1.7924	1.5091
12	1.8313	.0343			1.9784	1.8785	2.0008
13	1.9669	.0343			1.9669	1.6032	2.0178
14	1.9669	.0343			1.8945	1.917	2.0454
15	2.2043	.0343			1.8945	1.9271	2.079
16	2.1125	.0343			1.8945	1.9109	1.8778
17		.0343				1.704	.0343
18		.0343				.0183	.0335
19		.0343					.0343
20		.0343					.0173
21		.0343					.0347
22		.0343					.0171
23	.0343	.0343				.0181	.017
24	.0168	.9892	1.0395	1.0814	.0171	.0177	.0181
Max	2.2043	1.7295	1.8442	1.668	1.9784	1.9271	2.079
Min	.0168	.0343	.9724	1.0814	.0171	.0177	.017
Avg	.6429	.5449	1.2312	1.3747	.7481	1.1845	.7333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 203 / 11Kv Warul- Bhendavade  
Feeder KV- 11 / OUTGOING

FEEDER SEPERATION/PURE AG

DATE	29-MAR-18	30-MAR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6962		.78		
2	.8048		.8048	.639	
3	.8383		.8383		
4	.8139		.8122	.6882	.6874
5	.8478		.9116		
6	.8215		1.0059	.8745	.6062
7	.8718		1.0513		
8	1.0631		1.0395	1.1305	.9503
9	1.0631		1.0395		.9717
12		1.1603			
13		1.1736			
14		1.1603			
15		1.2763			
16		1.2071			
17		1.2717			
18		1.2378			
19		1.0513			
24	.4917		.7461	.5079	.6226
Max	1.0631	1.2763	1.0513	1.1305	.9717
Min	.4917	1.0513	.7461	.5079	.6062
Avg	.8312	1.1923	.9029	.7680	.7676

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144088 / 33/11 KV Warul

Feeder No / Name : 401 / 33 Kv Kadavi Generation

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0526	.0514	.0514		1.2894		
2	.0514	.0514	.0514		1.2894		
3	.0526	.0514	.0514		1.2894		
4	.0514	.0514	.0514		1.2894		
5	.0514	.0514	.0514		1.2894		
6	.0509	.0514	.0514		1.2894		
7	.0526	.0514	.0514		1.3432		
8	.0532	.0514	.0514	1.3146	1.2757	.0549	.0537
9	.0526	.0514	.0514		1.3575		.0543
10	.0514	.0514			1.3575		.0514
11	.0514	.0514			1.2757		.0543
12	.0514	.0514			1.2894		.0514
13	.0514	.7602			1.2757		.0509
14	.0514	.7522			1.2757		.0514
15	.0514	.7522			1.2757		.052
16	.0514	.7442			1.2757	.0549	
17		.691					.1029
18		.7973				.0543	.1029
19		.0514					
20		.0514					
21		.0514					
22		.0514					.1029
23	.0514	.0514					.0514
24	.0514	.0514	.0514	1.4003	1.2757	.0544	.0543
Max	.0532	.7973	.0514	1.4003	1.3575	.0549	.1029
Min	.0509	.0514	.0514	1.3146	1.2757	.0543	.0509
Avg	.0517	.2259	.0514	1.3575	1.2949	.0546	.0641

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 201 / Turukwadi Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.2887		1.1488		
2		1.2887		1.1022		
3		1.2071		1.1022		
4		1.2717		1.1488		
5		1.3565		1.1488		
6		1.5261		1.2689		
7		1.7833		1.5261		
8		2.0178		1.749		
9		2.0348		1.9204		
10				1.7833	1.4251	1.4754
11				1.8313	2.0405	1.9204
12	2.1534			1.8482	2.1091	1.869
13	2.332		1.5775	1.6598	1.9669	1.9839
14	2.0517		1.7147	1.6933	1.7295	2.0062
15	2.1195		1.9244	1.7465	1.6933	2.0919
16	2.1534		1.9591	1.5927	1.7804	1.9376
17	1.8896			1.5927	1.5927	1.8991
18	1.7635					
19	1.4922					
24		1.2887		1.0395		
Max	2.332	2.0348	1.9591	1.9204	2.1091	2.0919
Min	1.4922	1.2071	1.5775	1.0395	1.4251	1.4754
Avg	1.9944	1.5063	1.7939	1.4946	1.7922	1.8979

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 202 / 11 KV Thawade - Udagiri Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2715	.2743	.2743	.2629	.2378	.2328	.2561
2	.2534	.2378	.2561	.2629	.2195	.2149	.2561
3	.2534	.2378	.2561	.2629	.2195	.2126	.2561
4	.2534	.2378	.2561	.2629	.2195	.2126	.2561
5	.2561	.2378	.2743	.2629	.2218	.2481	.2561
6	.2772	.2587	.3326	.2835	.2378	.3012	.2957
7	.3582	.3475	.3658	.3582	.2715	.362	.3982
8	.3544	.3801	.394	.3761	.3155	.3982	.394
9	.443	.4298	.3898	.4207	.3544	.4477	.3544
10	.4161	.4207	.4031	.4334	.3189	.4207	.3544
11	.443	.4207	.4525	.4207	.3155	.4119	.3898
12	.4119	.4252	.4207	.3898	.3429	.4252	.4075
13	.4119	.4252	.4119	.4119	.3561	.3898	.3681
14	.3189	.3898	.3856	.394	.3814	.3898	.2835
15	.3544	.3898	.3814	.394	.3658	.3856	.3761
16	.4252	.3898	.3944	.394	.3544	.4161	.362
17	.3944	.3772	.3814	.3582	.3814	.3944	.333
18	.4382	.3944	.3772	.3814	.3944	.4287	.3898
19	.4784		.4733	.4252	.4656	.4656	.4344
20	.5304	.462		.4024	.5138	.5121	.4572
21	.499	.4435	.4706	.3881	.4706	.4805	.4066
22	.4066	.4066	.3982	.3326	.3801	.4251	.3511
23	.3292	.3292	.3403	.2896	.2715	.3292	.2896
24	.2865	.2926	.2743	.298	.2534	.2534	.2743
Max	.5304	.462	.4733	.4334	.5138	.5121	.4572
Min	.2534	.2378	.2561	.2629	.2195	.2126	.2561
Avg	.3694	.3569	.3637	.3528	.3276	.3649	.3417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 144109 / 33/11 KV Thawade

Feeder No / Name : 203 / 11 KV Kandavan Village

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1886	.2054	.2075	.1829	.2241	.2054	.1886
2	.1698	.2054	.2075	.1829	.1867	.1867	.1886
3	.1698	.2054	.2075	.1829	.1867	.1867	.1886
4	.1698	.2054	.2075	.1829	.1867	.1867	.1886
5	.2075	.2801	.2263	.2195	.1867	.2263	.2075
6	.2829	.2641	.2829	.2772	.2614	.2829	.3018
7	.3658	.3881	.3921	.3258	.3511	.3658	.3921
8	.4119	.4207	.3841	.4119	.3982	.394	.3658
9	.3856	.333	.3761	.3467	.3544	.3189	.3189
10	.4031	.3506	.3467	.3467	.3189	.3155	.298
11	.3681	.3189	.298	.2507	.2454	.3189	.2328
12	.3681	.3045	.3045	.2507	.2481	.3012	.2172
13	.3012	.2865	.2835	.2743	.2126	.2686	.2507
14	.2507	.2507	.2427	.2218	.2149	.2561	.2172
15	.2804	.2658	.2713	.2561	.2279	.2629	.2353
16	.3467	.298	.3018	.2353	.2804	.2743	.2835
17	.3222	.2572	.2984	.2303	.3012	.3429	.2658
18	.3681	.3641	.285	.2804	.3429	.3772	.3544
19	.4835		.4607	.4207	.4572	.4755	.439
20	.5544	.567	.5611	.5249	.5611	.5359	.5544
21	.4904	.5041	.462	.4481	.462	.4668	.4668
22	.3961	.4481	.3881	.3961	.3881	.415	.3961
23	.2801	.3018	.2926	.2829	.2641	.2641	.2987
24	.2075	.2241	.2075	.2378	.2241	.2241	.1886
Max	.5544	.567	.5611	.5249	.5611	.5359	.5544
Min	.1698	.2054	.2075	.1829	.1867	.1867	.1886
Avg	.3238	.3152	.3123	.2904	.2952	.3105	.2933

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

MALKAPUR[041] BU 6190

Substation No/ Name :- 147018 / 132/33KV Bambawade

Feeder No / Name : 407 / 33KV Maruti Wind

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
13	.0572
Max	.0572
Min	.0572
Avg	.0572



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 201 / Sh-R- Panhala Hill Station  
Feeder KV- 11 / OUTGOING

SHEDDABLE URBAN

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1334	.1334	.1524	.1029	.1334	.1029
2	.1029	.1334	.1334	.1524	.1029	.1334	.1029
3	.1029	.1334	.1334	.1524	.1029	.1334	.1029
4	.1029	.1334	.1334	.1524	.12	.1334	.12
5	.12	.1524	.1334	.1524	.1372	.1334	.1372
6	.1372	.1905	.1524	.1905	.1543	.1905	.1543
7	.1543	.1905	.1905	.1905	.1715	.2096	.1372
8	.1715	.1905	.2286	.2286	.1543	.1715	.1372
9	.1543	.2096	.1905	.2058	.1543	.1715	.1543
10	.1905	.1715	.1905	.1715	.1905	.1543	.1715
11	.1715	.1905	.1715	.1543	.1905	.1715	.1715
12	.1905	.1334	.1905	.1715	.1905	.1715	.1905
13	.1905	.1715	.1905	.1543	.1905	.1543	.1715
14	.2096	.2096	.1905	.1543		.1543	.1715
15	.1905	.2096	.1905	.1372		.1372	.1715
16	.1905	.1905	.1905	.1372		.1715	.2286
17	.1905	.1715	.1905	.1372	.1905	.1543	.2096
18	.1715	.1905	.2286	.1543	.2096	.1886	.2096
19	.2477	.2477	.2477	.2229	.2096	.2058	.2477
20	.2667	.2667	.3048	.2572	.2477	.2401	.2477
21	.2667	.2477	.2667	.2401	.2477	.2229	.2286
22	.2477	.2286	.2477	.1886	.2286	.2058	.1905
23	.1905	.1905	.2096	.1543	.1905	.1372	.1715
24	.1029	.1524	.1524	.1524	.1372	.1524	.1372
Max	.2667	.2667	.3048	.2572	.2477	.2401	.2477
Min	.1029	.1334	.1334	.1372	.1029	.1334	.1029
Avg	.1736	.1850	.1913	.1735	.1726	.1680	.1695

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 202 / SH-R- 11 KV WAGHAWE

GAOTHAN FEEDER

GAVTHAN Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1524	.1334	.1334	.1029		.12
2	.1029	.1524	.1334	.1334	.1029		.12
3	.1029	.1524	.1334	.1334	.1029		.12
4	.12	.1524	.1334	.1334	.12		.1543
5	.1372	.1715	.1334	.1905	.1372		.1886
6	.1715	.2286	.2286	.1905	.1715		.2401
7	.1715	.2286	.2096	.1905	.2058		.1715
8	.1886	.2286	.2286	.2286	.2401		.1715
9	.2058	.2286		.2572	.2401		
10	.2286	.2286	.2286	.2229	.2477		.2096
11	.2286	.2096	.2858	.2058	.2477		.1905
12	.1905	.2096	.2286	.1715	.2477		.2286
13	.1905	.1905	.1905	.1543	.2286		.2667
14	.1715	.2096	.1905	.1715	.2286		.2286
15	.1905	.2096	.1905	.1886	.2667		.2286
16	.1905	.2096	.1905	.1715	.2667		.2286
17	.3048	.2096	.1905		.2667	.2401	.2477
18	.2858	.2096	.2286	.1715		.2915	.2477
19	.3429	.3048	.2858	.0171		.3258	.4191
20	.3429	.3239	.3048			.3772	.4191
21	.2858	.2858	.2858	.2743		.3429	.381
22	.2286	.2477	.2477	.2401		.3086	.3048
23	.1905	.1905	.1524	.1372		.2058	.2286
24	.1372	.1524	.1524	.1334	.12		.1715
Max	.3429	.3239	.3048	.2743	.2667	.3772	.4191
Min	.1029	.1524	.1334	.0171	.1029	.2058	.12
Avg	.2005	.2120	.2038	.1750	.1969	.2988	.2299

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035]

BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 203 / 11 KV NAVALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.381	.381	.4382	.3944	.0381	.3944
2	.3086	.381	.381	.4382	.3944	.4191	.3429
3	.3086	.381	.381	.4382	.3944	.4191	.3429
4	.3772	.381	.381	.4382	.4287	.4191	.3944
5	.4287	.4191	.381	.4382	.463	.4191	.4801
6	.4801	.5335	.6287	.5335	.5144	.6478	.5487
7	.5658	.5716	.5906	.5716	.5487	.724	.5658
8	.5144	.6097	.5525	.6097	.5487	.5906	.5487
9	.5144	.6097	.5716	.583	.5144	.5335	.5487
10	.5716	.6287	.5716	.5487	5.9633	.4973	.4572
11	.5716	.6668	.5335	.4458	.5335	.5316	.4954
12	.5716	.6287	.5716	.4458	.4763	.4287	.6859
13	.6097		.5716	.463	.4572	.3429	.6097
14	.5335	.5716	.5716	.4287	.4572	.3429	.6097
15	.5716	.6478	.5716	.4115	.4763	.3429	.5716
16	.6478	.6859	.5716	.4458	.4954	.6859	.6859
17	.6097	.6859	.5716	.4801		.6344	.6859
18	.5716	.5716	.5716	.5144	.5335	.6344	.724
19	.7621	.8764	.7621	.7716	.5716	.7716	.8764
20	.9145	1.1812	.9526	.8059	.8954	.8916	.9907
21	.8764	.8764	.8573	.6859	.8383	.7888	.8764
22	.7621	.6097	.7621	.6516	.6668	.7202	.8002
23	.5716	.5716	.5716	.4801	.5525	.4801	.5716
24	.4115	.4191	.4572	.4382	.4287	.4763	.4287
Max	.9145	1.1812	.9526	.8059	5.9633	.8916	.9907
Min	.3086	.381	.381	.4115	.3944	.0381	.3429
Avg	.5568	.6039	.5716	.5211	.7629	.5325	.5932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 204 / 11 KV MITHARWADI GAVTHAN GAOTHAN FEEDER  
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1905	.1905	.1905	.1029	.1334	.1029
2	.1029	.1905	.1905	.1905	.1029	.1334	.1029
3	.1029	.1905	.1905	.1905	.1029	.1334	.1029
4	.12	.1905	.1905	.1905	.12	.1334	.1372
5	.1372	.1905	.1905	.1905	.1372	.1334	.1543
6	.1715	.2286	.2477	.2286	.1543	.2096	.1715
7	.2058	.2667	.2858	.2858	.1715	.2096	.1886
8	.2229	.3048	.2477	.2858	.2058	.2286	.2058
9	.2058	.2096	.2477	.2401	.1886	.1905	.1543
10	.2286	.3048	.2477	.2229	.1905	.1372	.1715
11	.2667	.3048	.2286	.1715	.1905	.1715	.1905
12	.0191	.3048	.2477	.1886	.1905	.1715	.2477
13	.1905		.2667	.2058	.2096	.1715	.1905
14	.1905	.2477	.2667	.1543	.1905	.1543	.2096
15	.2286	.2858	.2667	.1715	.1715	.1715	.2286
16	.381	.3048	.2667	.1886	.2286	.2401	.2096
17	.3429	.3429	.2667	.2229	.2477	.2229	.2286
18	.3048	.3429	.3048	.1715	.2667	.2058	.2477
19	.362	.381	.3429	.2401	.2667	.2743	.3239
20	.3429	.381	.362	.2572	.3048	.2743	.3239
21	.3429	.381	.3239	.1886	.2477	.2572	.2858
22	.3048	.3239	.3048	.2229	.2286	.2229	.2286
23	.2286	.2667	.2286	.1372	.1715	.1543	.1715
24	.1372	.1905	.2096	.1905	.1029	.1524	.1372
Max	.381	.381	.362	.2858	.3048	.2743	.3239
Min	.0191	.1905	.1905	.1372	.1029	.1334	.1029
Avg	.2185	.2750	.2548	.2053	.1873	.1870	.1965

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 205 / 11 KV INJOLE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1905	.1334	.1334	.1029	.1143	.1029
2	.1372	.1905	.1334	.1334	.1029	.1143	.1029
3	.1372	.1905	.1334	.1334	.1029	.1143	.1029
4	.1543	.1905	.1334	.1334	.12	.1143	.12
5	.1715	.2096	.1334	.1334	.1372	.1143	.1543
6	.1886	.2286	.2286	.1905	.1543	.2096	.1886
7	.2229	.2667	.2286	.1905	.1886	.2286	.2229
8	.1886	.2477	.2096	.1905	.1886	.2286	.2229
9	.1715	.2858	.2096	.1715	.2058	.2286	.1715
10	.1905	.2477	.2096	.1715	.2477	.2058	.2096
11	.1905	.2286	.1905	.1886	.2096	.2058	.1905
12	.1905	.1715	.1715	.1715	.2096	.2058	.1905
13	.1715	.2286	.1905	.1715	.1905	.1715	.1715
14	.1905		.1905	.1886	.1905	.2058	.1905
15	.1715	.1524	.2286	.1715	.1905	.1715	.1905
16	.2096	.1905	.2096	.1886	.2286	.1886	.2096
17	.1715	.2667	.2096	.1886	.2667	.1715	.2096
18	.2286	.2667	.2096	.1715	.2858	.2229	.2096
19	.3048	.3429	.2477	.2401	.3429	.2572	.3429
20	.381	.381	.3239	.3429	.362	.2915	.381
21	.362	.3429	.3048	.2915	.3429	.2915	.724
22	.3429	.2858	.2858	.2401	.2667	.2743	.2858
23	.2477	.2096	.2477	.1543	.1905	.1715	.2096
24	.1715	.1905	.1715	.1524	.1372	.1334	.12
Max	.381	.381	.3239	.3429	.362	.2915	.724
Min	.1372	.1524	.1334	.1334	.1029	.1143	.1029
Avg	.2097	.2394	.2056	.1851	.2069	.1931	.2177

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 206 / 11kv Broadcast Express NON SHEDDABLE EXPRESS HV FEEDERS  
 feeder Feeder KV- 11 / OUTGOING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.0572	.0572	.0572	.0514	.0572	.0514
2	.0514	.0572	.0572	.0572	.0514	.0572	.0514
3	.0514	.0572	.0572	.0572	.0514	.0572	.0514
4	.0514	.0572	.0572	.0572	.0514	.0572	.0514
5	.0514	.0572	.0572	.0572	.0514	.0572	.0514
6	.0514	.0762	.0572	.0572	.0514	.0762	.0514
7	.0686	.0762	.0762	.0762	.0686	.0762	.0686
8	.0686	.0762	.0762	.0762	.0686	.0762	.0754
9	.0686	.0762	.0762	.0686	.0686	.0762	
10	.0762	.0762	.0762	.0686	.0762	.0686	
11	.0762	.0762	.0762	.0686	.0762	.0686	
12	.0762	.0762	.0762	.0686	.0762	.0686	
13	.0762		.0762	.0686	.0762	.0686	
14	.0762	.0762	.0762	.0686	.0762	.0686	
15	.0762	.0762	.0762	.0686	.0762	.0686	
16	.0762	.0762	.0762	.0686	.0762	.0686	
17	.0762	.0762	.0762	.0686	.0762	.0686	
18	.0762	.0762	.0762	.0686	.0762	.0686	
19	.0762	.0762	.0762	.0686	.0762	.0686	
20	.0762	.0191	.0191	.0686	.0762	.0686	
21	.0762	.0762	.0762	.0686	.0762	.0686	
22	.0762	.0762	.0762	.0686	.0762	.0686	
23	.0762	.0762	.0762	.0686	.0762	.0686	
24	.0514	.0572	.0762	.0572	.0686	.0572	.0514
Max	.0762	.0762	.0762	.0762	.0762	.0762	.0754
Min	.0514	.0191	.0191	.0572	.0514	.0572	.0514
Avg	.0680	.0688	.0691	.0659	.0687	.0670	.0560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 207 / 11Kv Mitharwadi Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.1905	.1905	.1905	.1372	.6668	.5487
2	.3772	.1905	.1905	.1905	.1372	.5335	.5487
3	.3772	.1905	.1905	.1905	.1372	.5335	.5487
4		.1905	.1905	.1905	.1543	.5335	.6859
5	.5487	.2096	.1905	.2286	.1715	.5335	.8059
6	.6859	.2286	.2667	.2667	.2058	.9145	.9431
7	1.5432	.3048	.3048	.2667	.2572	1.3413	1.3717
8	1.0631	.381	.2667	.2667	.3086	1.4022	1.2517
9	1.0288	.3429	.2667	.2743	.2743	1.0669	1.0974
10	.2286	.3429	.2667	.5487	.2286	.2743	.2286
11	.2477	.2667	.2667	1.0974	.1715	.2401	.2286
12	1.0669	1.2193	1.1431	1.2346	.1715	.2401	.2286
13	1.2193		1.1431	1.0974	.1905	.2401	.2286
14	1.1431	.9755	1.1431	1.0288	.2096	.2229	.2286
15	1.0669	.9145	1.105		.2286	.1715	.2286
16	1.1431	.9907	1.1431	1.2346	.2286	.2058	.2667
17	1.2955	1.0669	1.1431	1.3889	.2286	.2743	.3048
18	1.1431	.9145	1.1431	.2058	.2286	.2401	.3429
19	.8383	.6097	.7621	.2572	.2286	.2572	.3429
20	.2477	.2667	.3048	.2401	.2286	.2743	.3048
21	.2667	.2667	.2667	.1886	.2667	.2572	.3048
22	.2667	.2286	.2477	.1886	.2286	.2401	.2667
23	.2286	.1905	.2286	.1886	.1905	.1715	.2667
24	.4115	.2096	.1905	.1905	.1715	.4572	.6001
Max	1.5432	1.2193	1.1431	1.3889	.3086	1.4022	1.3717
Min	.2286	.1905	.1905	.1886	.1372	.1715	.2286
Avg	.7311	.4649	.5231	.4850	.2077	.4705	.5072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 208 / Waghawe Ag.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	1.0288	.0191	.0191	.0171	.884	1.0288
2	.6516	1.0288	.0191	.0191	.0171	.884	1.0288
3	.6516	1.0288	.0191	.0191	.0171	.884	1.0288
4	.7716	1.0288	.0191	.0191	.0171	.884	1.1831
5	.8916	1.1431	.0191	.0191	.0171	.884	1.4575
6	1.0288	1.5242	.0191	.0191	.0171	1.7375	1.5775
7	1.5432	2.1719	.0191	.0191	.0171	2.0119	2.0576
8	1.6118	2.5149	.0191	.0191	.0171	2.1491	2.0576
9	1.5432	2.4006	.0191	.0171	.0171	1.3717	1.749
10	.0191	.0191	.0191	1.7833	.0191	.2572	.0191
11	.0191	.0191	.0191	2.3663	.0191	.2058	.0191
12	.0191	1.829	2.2862	2.3148	.0191	.1886	.0191
13	.0191	1.9357	2.2862	2.3148	.0191	.1886	.0191
14	.0191	1.829	2.2862	2.2805	.0191		.0191
15	.0191	1.829	2.2862	2.1605	.0191		.0191
16	.0191	1.829	2.2862	2.1948	.0191		.0191
17	.0191	1.829	2.2862	2.0576	.0191	.0171	.0191
18	.0191	1.6461	2.0957	.0171	.0191	.0171	.0191
19	.0191	1.7147	1.7718	.0171	.0191	.0171	.0191
20	.0191	.0191	.0191	.0171	.3429	.0171	.0191
21	.0191	.0191	.0191	.0171	.362	.0171	.0191
22	.0191	.0191	.0191	.0171	.3048	.0171	.0191
23	.0191	.0191	.0191	.0171	.2286	.0171	.0191
24	.6859	.9145	.0191	.0191	.0171	.9145	1.0631
Max	1.6118	2.5149	2.2862	2.3663	.362	2.1491	2.0576
Min	.0191	.0191	.0191	.0171	.0171	.0171	.0191
Avg	.4291	1.2225	.7454	.7402	.0667	.6459	.6041



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144004 / PANHALA SUB-STATION

Feeder No / Name : 209 / 11KV INJOLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0171	.0191	.4268	.5716	.5144	.0191	.0171
2	.0171	.0191	.4268	.5716	.5144	.0191	.0171
3	.0171	.0191	.4268	.5716	.5144	.0191	.0171
4	.0171	.0191	.4268	.5716	.5316	.0191	.0171
5	.0171	.0191	.4268	.6287	.5487	.0191	.0171
6	.0171	.0191	.5944	.6859	.583	.0191	.0171
7	.0171	.0191	.5792	.6859	.6173		.0171
8	.0171	.0191	.6401	.7621	.6001		.0171
9	.0171	.0191	.7621	.6516	.6173	.0191	.0171
10	.0191	.0191	.0191	.0171	.4115	.0171	.6478
11	.0191	.0191	.0191	.0171	.4877	.1029	.6859
12	.7621	.0191	.0191	.0171	.4877		.7621
13	.8002		.0191	.0171	.442	.3429	.8002
14	.7621		.0191	.0171	.4572		.8002
15	.7621	.0191	.0191	.0171	.503		.8002
16	.7621	.0191	.0191	.0171	.5335		.7621
17	.7621	.0191	.0191	.0171	.5944	.583	.7621
18	.7621	.0191	.0191	.0171	.0191	.6859	.0191
19	.724	.0191	.0191	.0171	.0191	.6859	.0191
20	.0191	.0191	.0191	.0171	.0191	.0171	.0191
21	.0191	.0191	.0191	.0171	.0191	.0171	.0191
22	.0191	.0191	.0191	.0171	.0191	.0171	.0191
23	.0191	.0191	.0191	.0171	.0191	.0171	.0191
24	.0171	.0191	.4572	.0191	.5144	.0191	.0171
Max	.8002	.0191	.7621	.7621	.6173	.6859	.8002
Min	.0171	.0191	.0191	.0171	.0191	.0171	.0171
Avg	.2659	.0191	.2264	.2483	.3995	.1466	.2628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 201 / 11 KV DIGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1029	.1029	.1132	.0857	.0857	.1132	.1132
2	.1029	.1029	.1132	.0857	.0857	.1132	.1132
3	.1029	.1029	.0943	.0857	.0857	.1132	.1132
4	.12	.1372	.0943	.1029	.1029	.132	.132
5	.12	.1715	.132	.12	.1029	.1509	.132
6	.1372	.2058	.1867	.12	.12		.1494
7	.1372	.2058	.1463	.1372	.1372	.1663	.1463
8	.1543	.2058	.1612	.12	.1372	.1629	.1612
9	.1772	.1543	.1372	.1029	.12	.1772	.1772
10	.1715	.1543	.1029	.1402	.1029	.1715	.1715
11	.1715	.12	.12	.1227	.1029	.1715	.1715
12	.1543	.1029	.12	.1052	.1029	.1715	.1715
13	.1886	.1029	.1372	.0693	.12	.1715	.1715
14	.1715	.1029	.12	.104	.1029	.1715	.3601
15	.1715	.0857	.1029	.1214	.1029	.1886	.1715
16	.1715	.1029	.12	.1029	.1029	.1715	.1715
17	.1715	.1402	.12	.1029	.12	.12	.1372
18	.2058	.1417	.1543	.1372	.1772	.1372	.1372
19	.2058	.2378	.2058	.1715	.2378	.2195	.2229
20	.2229	.2263	.2229	.1715	.2263	.2263	.2058
21	.2058	.2263	.1886	.1715	.2075	.2263	.1886
22	.2058	.2075	.1543	.1372	.1886	.2075	.1543
23	.1715	.1698	.1372	.12	.1509	.1698	.1372
24	.12	.1029	.132	.0857	.1029	.132	.132
Max	.2229	.2378	.2229	.1715	.2378	.2263	.3601
Min	.1029	.0857	.0943	.0693	.0857	.1132	.1132
Avg	.1610	.1506	.1382	.1176	.1302	.1646	.1643

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 202 / 11 KV ALAWE-KOTOLI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4575	1.8861	.1509	.1067	.12	.0549	1.757
2	1.4575	2.0576	.1132	.1067	.12	.0549	1.8067
3	1.5432	2.2291	.1132	.1067	.12	.0549	1.7736
4	1.6289	2.572	.1132	.1219	.12	.0549	1.757
5	1.7147	2.7435	.1509	.1219	.12	.0549	1.757
6	1.8519	2.8807	.1509		.12	.0732	2.2874
7	2.4006	2.9321	.2263	.1524	.1372	.1646	2.9843
8	2.5892	2.8045	.2263		.2058	.1829	3.0514
9	2.7949	2.6063	.2829	.0305	.2229	.2263	2.6189
10	.0343	.1067	.2401		2.0729	.1886	.0343
11	.0343		.2229	2.5194	2.2558	.2058	.0343
12	.2058	2.5301	2.8464	2.8166	2.4387	.2058	.0343
13	.2058	2.6368	3.2236	2.9508	2.713	.2058	.0343
14	.2058	2.652	3.1036	3.0849	2.652	.2058	.0343
15	.1886	2.6673	3.0864	2.9843	2.6825	.1886	.1543
16	.1886	2.5911	3.0864	3.0514	2.6978	.1886	.0343
17	.1886	2.8178	2.6978	3.0007	2.8509	.1494	.1067
18	.2058	2.5194	2.3777	2.7435	.1463	.2241	.1219
19	.2195	2.1216	1.89	.1543	.1097	.1867	.1524
20	.1829	.1494	.1219	.12	.1097	.1509	.1219
21	.2058	.0943	.1067	.12	.1097	.1132	.1219
22	.2058	.1509	.0914	.12	.0732	.1132	.1219
23	.0343	.1132	.0914	.1372	.0566	.1132	.1067
24	1.3717	1.3717	.1509	.1067	.1372	.0549	1.4255
Max	2.7949	2.9321	3.2236	3.0849	2.8509	.2263	3.0514
Min	.0343	.0943	.0914	.0305	.0566	.0549	.0343
Avg	.8798	1.9667	1.0360	1.1741	.9330	.1423	.9347

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 203 / 11 KV GHOTWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.12	.12	.132	.1029	.1029	.1132	.1132
2	.12	.12	.1132	.1029	.1029	.1132	.1132
3	.12	.12	.1132	.0857	.1029	.1132	.1132
4	.1372	.1372	.132	.0857	.12	.1132	.1132
5	.1543	.1715	.1509	.1029	.1372	.1509	.1509
6	.1715	.2058	.1886	.1543	.1543	.1886	.2241
7	.2229	.2058	.2012	.1886	.1543	.2195	.2378
8	.2572	.2058	.2328	.1886	.1543	.2149	.2353
9	.2915	.2572	.2328	.1543	.1543	.2303	.2126
10		.2401	.2572	.2103	.1372	.1886	.2058
11	.2229	.2229	.2572	.1753	.1543	.1715	.1886
12	.1886	.2058	.208	.1214	.1715	.1715	.1715
13	.1715	.1715	.1886	.1029	.1886	.1715	.1715
14	.1715	.1715	.1715	.1543	.1715	.1886	.1715
15	.1715	.1715	.1886	.1715	.1715	.1372	.1372
16	.2572	.2058	.2058	.1543	.1715	.1715	.1715
17	.2743	.2103	.2229	.1886	.2058	.2058	.2058
18	.2743	.2629	.2743	.2572	.2572	.2401	.2229
19	.2835	.4207	.3086	.3258	.362	.3658	.3772
20	.3086	.415	.3429	.3429	.3018	.3961	.3944
21	.3086	.3961	.3086	.3086	.3018	.3395	.3086
22	.2058	.3018	.2743	.2572	.2263	.3018	.2401
23	.1372	.1698	.2401	.1543	.1509	.1509	.2058
24	.1372	.12	.1509	.132	.12	.1132	.1132
Max	.3086	.4207	.3429	.3429	.362	.3961	.3944
Min	.12	.12	.1132	.0857	.1029	.1132	.1132
Avg	.2047	.2179	.2123	.1759	.1781	.1988	.2000

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 204 / 11 kv Digavade Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3658	.3772	.0377	.0152	.0152	.0189	.5079
2	.381	.4115	.0377	.0152	.0152	.0189	.5243
3	.442	.4801	.0377	.0152	.0152	.0189	.5407
4	.5335	.6687	.0377	.0152	.0152	.0189	.5407
5	.6097	1.0288	.0377	.0152	.0152	.0377	.6226
6	.6859	1.0974	.0377	.0305	.0152	.0377	1.0159
7	1.1431	1.0974	.0366	.0305	.0152	.0377	1.6221
8	1.5699	1.5242	.0366	.0305	.0305	.0377	1.6741
9	1.6632	1.7833	.0366	.0305	.0305	.0377	
10	.0343		.0305	1.3108	.0305	.0343	.0343
11	.0343	.0305	.0312	1.7072		.0343	.0343
12	.0343	1.7528	1.7375	1.9393		.0305	.0343
13	.0343	1.7985	1.7071	1.9616	1.7223	.0343	.0343
14		1.7528	1.7528	1.7772	1.89	.0343	.0343
15		1.7223	1.7223	1.6741	1.89		.0305
16		1.6918	1.6309	1.757	1.8747	.0343	.0343
17		1.7859	1.6309	1.5242	2.0056	.0377	.0305
18	.0305	1.5565	1.4632	.0152	1.7901	.0373	.0305
19	.0343	1.2616	1.1888	.0152	.0366	.0377	.0305
20	.0305	.0373	.0305	.0152	.0366	.0377	.0305
21	.0305	.0377	.0305	.0152	.0366	.0377	.0305
22	.0305	.0377	.0305	.0152	.0366	.0377	.0305
23	.0305	.0377	.0152	.0152	.0377	.0377	.0305
24	.3506	.3772	.0377	.0152	.0152	.0189	.4588
Max	1.6632	1.7985	1.7528	1.9616	2.0056	.0377	1.6741
Min	.0305	.0305	.0152	.0152	.0152	.0189	.0305
Avg	.4034	.9717	.5573	.5815	.5259	.0325	.3460

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 205 / 11 KV ALAVE-KOTOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2229	.2058	.2263	.2058	.2058	.2263	.2452
2	.2229	.2058	.2263	.2058	.2058	.2263	.2263
3	.2229	.2058	.2263	.2058	.2058	.2263	.2263
4	.2572	.2229	.2641	.2058	.2401	.2452	.2641
5	.2743	.2915	.2829	.2058	.2743	.2641	.2829
6	.2915	.3086	.3395	.2743	.3258	.3361	.3361
7	.2743	.3086	.3326	.3086	.3086	.3511	.3142
8	.3258	.3391	.3224	.3086	.3258	.3439	.3258
9	.3086	.3429	.3582	.3601	.2915	.3544	.3012
10	.3258	.3601	.3601	.3856	.3258	.3086	.2915
11	.3429	.3601	.3429	.3155		.3601	.3086
12	.3258	.3429	.3258	.2804		.3429	.3601
13	.2915	.3429	.2915	.2804	.4115	.3429	.3429
14	.2572	.3258	.2572	.2454	.3772	.3258	.3429
15	.2572	.3258	.3121	.2804	.3601	.3772	.3429
16	.3086	.3429	.3086	.3121	.3429	.3601	.3429
17		.3856	.3601	.3429	.3814	.3814	.4115
18	.3429	.3544	.3944	.3601	.3856	.3681	.4115
19	.4607	.4572	.4287	.4287	.4525	.4938	.5144
20	.4801	.5281	.4801	.463	.547	.547	.5144
21	.463	.4904	.3944	.3944	.4715	.4904	.463
22	.4801	.415	.3601	.3772	.3961	.4527	.3944
23	.2058	.3018	.3086	.2743	.2641	.3206	.2743
24	.2401	.2058	.2452	.2229	.2229	.2452	.2452
Max	.4801	.5281	.4801	.463	.547	.547	.5144
Min	.2058	.2058	.2263	.2058	.2058	.2263	.2263
Avg	.3123	.3321	.3229	.3018	.3328	.3454	.3368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PANHALA[035] BU 6131

Substation No/ Name :- 144013 / 33/11 KV DIGAWADE

Feeder No / Name : 206 / 11 KV GHOTWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.7177	1.286	1.2346	1.1919	
2		1.7002	1.2689	1.2517	1.1744	
3		1.7177	1.286	1.286	1.1568	
4		1.7177	1.3375	1.3717	1.1568	
5		1.9105	1.3889	1.4575	1.3321	
6		2.1033	2.0405	1.6975	1.4899	
7		2.7286	2.3491	2.1776	2.0595	
8		2.8881	2.5549	2.3834	2.5514	
9		2.6223	2.1434	2.1434	2.5869	
10						1.286
11					2.0919	2.0576
12	2.5892				2.3663	2.6578
13	3.7037				2.4006	2.572
14	3.3951				2.2462	2.7949
15	3.0864				2.1948	2.6749
16	2.8807				2.2977	2.6578
17	2.915				2.1439	2.2805
18	2.7435					
24		1.6827	1.2346	1.2346	1.1744	
Max	3.7037	2.8881	2.5549	2.3834	2.5869	2.7949
Min	2.5892	1.6827	1.2346	1.2346	1.1568	1.286
Avg	3.0448	2.0789	1.6890	1.6238	1.8597	2.3727

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 201 / 11 kv M.Shiroli sheti fdr SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9526		.8764	.0381	.0381	.0381
2	.0381		.9526	.8764	.0381	.0381	.0381
3	.0381	.9526	.9145	.8764	.0381	.0381	.0381
4	.0381	1.1431	.9145	.8764	.0381	.0381	.0381
5	.0381	1.3336	1.105	1.0669	.0381	.0381	.0381
6	.0381	1.5242	1.3717	1.4861	.0381	.0381	.0381
7	.0381	2.1148	1.829	1.9433	.0381	.0381	.0381
8	.0381	2.4958	1.9814	1.9814	.0381	.0381	.0381
9	.0381	2.3815	2.0957	1.9814		.0381	.0381
10	.0381	.0381	.0381	.0381	1.9052	2.5149	
11	.0381	.0381	.0381	.0381	2.7435	2.934	3.0483
12	2.9721	.0381	.0381			2.7625	2.8578
13	3.0674	.0381	.0381	.0381	2.9531	2.9721	3.1055
14	2.9912	.0381	.0381	.0381	3.0864	2.7816	3.0483
15	2.9531	.0381	.0381	.0381	3.0864	2.6673	3.0483
16	2.9912	.0381	.0381	.0381	2.7435	2.7816	2.8006
17	2.7625	.0381	.0381	.0381	2.7435	2.2862	2.6673
18	2.6673	.0381	.0381	.0381	.0381	.0381	.0381
19	1.9052	.0381	.0381	.0381	.0381	.0762	.0381
20	.0381	.0381	.0381	.0381	.0381	.0762	.0381
21	.0381	.0381	.0381	.0381	.0381	.0572	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	.9526	.9907	.9145	.0381	.0381	.0381
Max	3.0674	2.4958	2.0957	1.9814	3.0864	2.9721	3.1055
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.9550	.6254	.5517	.5815	.9015	.9335	.9211



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 202 / 11 kv Chande Sheti Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	.0381	.0381	.0381	2.1338	2.21	2.2862
2	2.2862	.0381	.0381	.0381	2.1338	2.21	2.2862
3	2.2862	.0381	.0381	.0381	2.1338	2.21	2.2862
4	2.3624	.0381	.0381	.0381	2.2862	2.2862	2.2862
5	2.3624	.0381	.0381	.0381	2.3815	2.3815	2.3815
6	2.7625	.0381	.0381	.0381	2.5149	2.5149	2.6292
7	3.2769	.0381	.0381	.0381	2.8578	3.2769	2.9531
8	3.7151	.0381	.0381	.0381	3.0483	3.1817	3.2007
9	3.3532	.0381	.0381	.0381		2.9721	2.8578
10	.0381	.0381	.0381	3.1245	.0381	.0381	
11	.0381	.0381		3.8104	.0381		.0381
12	.0381	3.5056	3.2007	3.9057			.0381
13	.0381	4.1914	3.9438	3.9057			.0381
14		3.9438	3.677	3.4294	.0381	.0381	.0381
15		3.8104	3.658	3.2769	.0381	.0381	.0381
16		3.5627	3.6199	3.2579	.0381	.0381	.0381
17	.0381	3.6199	3.5437	3.1436	.0381	.0381	.0381
18	.0381	3.2769	3.3913	.0381	.0381	.0381	.0381
19	.0381	2.9912	3.1055	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381		.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	2.0957	.0381	.0381	.0381	2.1338	2.21	2.2862
Max	3.7151	4.1914	3.9438	3.9057	3.0483	3.2769	3.2007
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	1.2955	1.2296	1.2483	1.1860	1.1022	1.2320	1.1282

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 203 / 11 Kv Kanchanwadi Sheti SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	1.2193	1.1431	.7621	.0381	.0381	.0381
2	.0381	1.2193	1.1431	.7621	.0381	.0381	.0381
3	.0381	1.2384	1.1431	.7621	.0381	.0381	.0381
4	.0381	1.3336	1.2193	.7621	.0381	.0381	.0381
5	.0381	1.5242	1.3336	.9907	.0381	.0381	.0381
6	.0381	1.7718	1.5623	1.4098	.0381	.0381	.0381
7	.0381	2.0767	2.0767	1.9624	.0381	.0381	.0381
8	.0381	2.553	2.21	1.9052	.0381	.0381	.0381
9	.0381	2.1338	2.2862	1.829		.0381	.0381
10	.0381	.0381	.0381	.0381	1.4098	2.1529	
11	.0381	.0381	.0381	.0381	1.829	2.6673	2.572
12	2.553	.0381	.0381	.0381		2.8006	
13	2.6101	.0381	.0381	.0381	2.7244	2.8387	2.7816
14	2.6673	.0381	.0381	.0381	2.8387	2.6292	2.6673
15	2.8578	.0381	.0381	.0381	2.8387	2.5911	2.6673
16	2.6673	.0381	.0381	.0381	2.553	2.3815	2.5911
17	2.6292	.0381	.0381	.0381	2.3815	2.2672	2.572
18	2.2862	.0381	.0381	.0381	.0381	.0381	.0381
19	1.6575	.0381	.0381	.0381	.0381	.0381	.0381
20	.0381	.0381	.0381	.0381	.0381	.0381	.0381
21	.0381	.0381	.0381	.0381	.0381	.0381	.0381
22	.0381	.0381	.0381	.0381	.0381	.0381	.0381
23	.0381	.0381	.0381	.0381	.0381	.0381	.0381
24	.0381	1.2193	1.105	.2572	.0381	.0381	.0381
Max	2.8578	2.553	2.2862	1.9624	2.8387	2.8387	2.7816
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.8558	.7010	.6565	.4973	.7794	.8724	.7482

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 204 / 11 KV Arale AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144				.5716	.6287	.6478
2	.5144				.5716	.6287	.6478
3	.5144				.5716	.6287	.6478
4					.5716	.6668	.6668
5	.6859				.6668	.7621	.7621
6	.8573				.8383	.9907	1.0098
7	1.1622				1.1622	1.2574	1.1622
8					1.105	1.3336	1.4289
9	1.1431					1.086	1.2765
10				1.0288			
11				1.3336			
12		1.467	1.2384	1.4289			
13		1.467	1.3717	1.4289			
14		1.5432	1.3527	1.2003			
15		1.4861	1.3146	1.2384			
16		1.4098	1.2574	1.105			
17		1.3336	1.2574	1.1431			
18		1.2003	1.1431				.381
19		.9526	.9717				
24	.5144				.5525	.6287	.6478
Max	1.1622	1.5432	1.3717	1.4289	1.1622	1.3336	1.4289
Min	.5144	.9526	.9717	1.0288	.5525	.6287	.381
Avg	.7383	1.3575	1.2384	1.2384	.7346	.8611	.8435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 205 / 11 kv M. Shirolgi Gaothan  
fdr Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2667	.2286	.1905	.2286	.2286	.2667
2	.2286	.2286	.2286	.1905	.2286	.2286	.2667
3	.2286	.2286	.2286	.1905	.2286	.2286	.2667
4	.2286	.2667	.2286	.1905	.2286	.2286	.3048
5	.3048	.3048	.3048	.2667	.2667	.3048	.3429
6	.4191	.4382	.381	.3429	.3048	.381	.4572
7	.4382	.4382	.4572	.4191	.381	.4572	.362
8	.4382	.3239	.381	.381	.381	.4572	.2858
9	.3048	.3239	.3048	.3239		.3429	.3048
10	.3239	.3048	.2858	.2096	.2286	.2667	
11	.3048	.2667	.2858	.2096	.2286	.3048	.3048
12	.3239	.2667	.2858			.3048	.3048
13	.3048	.2667	.2858	.3048	.2286	.3048	.3048
14	.2858	.2667	.2858	.3048	.2667	.3239	.3048
15	.3048	.2667	.2858	.3048	.2667	.2858	.3048
16	.3239	.2667	.2667	.3048	.2667	.3048	.3048
17	.3048	.3048	.2667	.3048	.2667	.2858	.3048
18	.4382	.3429	.3429	.3048	.3429	.3429	.381
19	.5144	.4191	.4191	.381	.4191	.4382	.4191
20	.4763	.5335	.4954	.4191	.4572	.4763	.4572
21	.4572	.5335	.4572	.4191	.381	.4763	.4572
22	.3048	.381	.4191	.381	.3429	.4572	.381
23	.3048	.2667	.2858	.3048	.3048	.381	.2858
24	.2286	.2667	.2286	.2572	.2667	.2286	.2858
Max	.5144	.5335	.4954	.4191	.4572	.4763	.4572
Min	.2286	.2286	.2286	.1905	.2286	.2286	.2667
Avg	.3342	.3239	.3183	.3003	.2961	.3350	.3330

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038]

BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 206 / 11 Kv Chande Gavthan

GAOTHAN FEEDER

Feeder Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	.1143	.1143	.0953	.0953	.0953
2	.1143	.1143	.1143	.1143	.0953	.0953	.0953
3	.1143	.1143	.1143	.1143	.0953	.0953	.0953
4	.1143	.1143	.1143	.1143	.0953		.1143
5	.1143	.1524	.1524	.1334	.0953		.1524
6	.1143	.1905	.1905	.1715	.1524	.4191	.2477
7	.2286	.1905	.2286	.2286	.1905	.1905	.2286
8	.1905	.1524	.1905	.1905	.1905	.1905	.1905
9	.1524	.1524	.1715	.1715		.1524	.1524
10	.1524	.1524	.1524	.1715		.1524	
11	.1143	.1334	.1334	.1715		.1524	.1524
12	.1143	.1334	.1334	.1715			.1524
13	.1143	.1143	.1334	.1715		.1524	.1524
14	.1143	.1143	.1334	.1715	.1524		.1524
15	.1143	.1143	.1334	.1715	.1524	.1524	.1524
16	.1143		.1334	.1715	.1524	.1524	.1524
17	.1143	.1334	.1334	.1715	.1524	.1524	.1524
18	.1524	.1905	.1715	.1715	.1905	.1905	
19	.2477	.2286	.2286	.1905	.2286	.2286	.2286
20	.2286	.2667	.2667	.1905	.2286	.2286	.2286
21	.1905	.2667	.2667	.1905	.1905	.1905	.0381
22	.1524	.1905	.2477	.1524	.1524	.1524	.1905
23	.1143	.1524	.1524	.1143	.0953	.1143	.1524
24	.1143	.1143	.1143	.1715	.1143	.0953	.0953
Max	.2477	.2667	.2667	.2286	.2286	.4191	.2477
Min	.1143	.1143	.1143	.1143	.0953	.0953	.0381
Avg	.1421	.1565	.1635	.1627	.1484	.1677	.1533

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 207 / 11 Kv Kanchanwadi Gavthan

GAOTHAN FEEDER

Feed Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2667	.2858	.2286	.2286	.2667	.2286	.2858
2	.2667	.2667	.2286	.2286	.2667	.2286	.2858
3	.2667	.2667	.2286	.1905	.2667	.2286	.2858
4	.2667	.3048	.2286	.1905	.2667	.2286	.3048
5	.3429	.3429	.3429	.2667	.3048	.3429	.381
6	.4954	.4954	.4191	.3429	.381	.4191	.5335
7	.5335	.4954	.4572	.4191	.4191	.5335	.4763
8	.5335	.4191	.381	.4191	.4191	.5335	.5144
9	.4191	.4191	.3429	.3429		.381	2.8578
10	.4191	.3429	.3048	.3429	.3429	.381	
11	.4001	.3048	.2858	.381	.3429	.381	.381
12	.381	.2667	.2858	.381			.381
13	.381	.2477	.2858	.381	.3429	.381	.381
14	.381	.2477	.3048	.381	.3429	.381	.381
15	.381	.2477	.3048	.381	.3429	.381	.381
16	.381	.2667	.2858	.381	.3429	.381	.381
17	.381	.3048	.2858		.381	.381	.4191
18	.4763	.381	.3429	.381	.4572	.4763	.4382
19	.5716	.4382	.4382	.4382	.5335	.5335	.5716
20	.5335	.5335	.5144	.4763	.5716	.5335	.5716
21	.2096	.5335	.4572	.4763	.4191	.4954	.5716
22	.4191	.381	.381	.4191	.3429	.4572	.4763
23	.3429	.3048	.3048	.3429	.2667	.4191	.381
24	.2667	.2858	.2286	.2286	.2667	.2667	.3048
Max	.5716	.5335	.5144	.4763	.5716	.5335	2.8578
Min	.2096	.2477	.2286	.1905	.2667	.2286	.2858
Avg	.3882	.3493	.3278	.3487	.3585	.3901	.5194

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144009 / 33/11 KV KANCHANWADI

Feeder No / Name : 208 / 11 kv ARALE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	
4	.0572	.0762	.0572	.0572	.0572	.0572	.0762
5	.0762	.0953	.0762	.0762	.0572	.0572	.0953
6	.1334	.1143	.0953	.0953	.0953	.0762	.1334
7	.1334	.1143	.1143	.1143	.0953	.1334	.1143
8	.1334	.0953	.0953	.0953	.0953	.1334	.0953
9	.0953	.0953	.0762	.0762		.0953	.0762
10	.0953	.0953	.0762	.0762	.0572	.0762	
11	.0762	.0953	.0762	.0762	.0572	.0762	.0762
12	.0762	.0953	.0762	.0762		.0762	.0762
13	.0762	.0953	.0762	.0762	.0572	.0572	.0762
14	.0762	.0953	.0572	.0762		.0572	.0762
15	.0953	.0953	.0572	.0762		.0762	.0762
16	.0953	.0762	.0572	1.105	.0762	.0762	.0762
17	.0762	.0762	.0572	.0953	.0762	.0762	.0762
18	.1143	.0762	.0762	.0953	.1334	.1143	.0953
19	.1334	.0953	.0953	.1334	.1334	.1334	.1334
20	.1143	.1334	.1334	.1334	.1334	.1334	.1334
21	.0953	.1334	.1334	.1334	.1334	.1143	.1334
22	.0953	.1143	.0953	.1334	.0953	.1143	.1143
23	.0572	.0762	.0762	.0572	.0572	.0762	.0762
24	.0572	.0572	.0572	.2572	.0572	.0572	.0572
Max	.1334	.1334	.1334	1.105	.1334	.1334	.1334
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0889	.0905	.0786	.1370	.0820	.0850	.0901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 201 / 11 Kv Bachani Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0328	.9602	.8573	1.1694	.0328	.0381	.0377
2	.0328	1.0288	.9945	1.2254	.0332	.0381	.0366
3	.0328	1.0288	1.046	1.1706	.0328	.0381	.0377
4	.0328	1.0974	1.0631	1.1523	.0328	.0381	.0366
5	.0492	1.1317	1.2174	1.1888	.0324	.0381	.0549
6	.0492	1.2003	1.3889	1.3014	.0328	.0381	.0549
7	.0492	1.5775	1.5775	1.8861	.0328	.0381	.0377
8	.0497	1.8519		2.1948	.0332	.0381	.0566
9	.0655	2.037	1.7436	1.7833	.0549	.0762	.0191
10	.0686	.0566	1.5249	.0381	1.8861	1.326	1.4575
11	.0686	.0549	.0332	.0381	.7316	1.9725	1.9719
12	2.2634	.0732		.0381	1.8861	2.0481	1.9204
13	2.4006	.0732	.0332	.0572	2.1502	1.8842	1.869
14	2.4006	.0754	.0328	.0572	2.1948	1.8233	1.8004
15	2.2977	.0732	.0328	.0572	2.3388	1.7368	1.8176
16	2.2291		.0328	.0572	2.1262	1.7901	1.6804
17	2.0576	.0762	.0549	.0572	1.8861	1.8861	1.5402
18	1.8861	.0762	.0566	.0503	.0381	.0566	.0497
19	1.3717	.0572	.0377	.0332	.0381	.0343	.0335
20	.0514	.0572	.0549	.0328	.0381	.0377	.0328
21	.0514	.0572	.0549	.0497	.0381	.0366	.0332
22	.0514	.0572	.0549	.0332	.0381	.0366	.0328
23	.0514	.0572	.0566	.0332	.0381	.0366	.0328
24	.0328	.8916	.8573	1.0974	.0328	.0381	.0366
Max	2.4006	2.037	1.7436	2.1948	2.3388	2.0481	1.9719
Min	.0328	.0549	.0328	.0328	.0324	.0343	.0191
Avg	.7365	.5935	.5821	.6168	.6575	.6302	.6117



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 202 / 11 Kv Nandgaon Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7404	.12	.1334	.128	1.6385	1.6804	1.8656
2	1.6385	.12	.1143	.128	1.6244	1.7147	1.9022
3	1.6057	.12	.1143	.1097	1.6907	1.7147	1.9616
4	1.6244	.12	.1334	.128	1.7238	1.749	1.9993
5	1.6549	.12	.1334	.1463	1.8233	1.8347	2.0119
6	1.6876	.1372	.1715	.1463	1.9006	1.9376	2.0485
7	2.1216	.1372	.1715	.1509	2.3304	2.1776	2.5606
8	2.3371	.1372	.1905	.1646	2.3594	2.4863	2.7915
9	2.1136	.1698	.1823	.1715	2.4897	2.3148	2.0405
10	.1029	.1829	.1802	2.1605	.0732	.0983	.1143
11	.12	.1463	.0983	2.6406		.0995	.1334
12	.12	3.4568	2.7681			.0995	.1334
13	.1372	3.2922	2.6686	2.6063		.0819	.1334
14	.1372	3.2065	2.652	2.572		.1006	.1334
15	.12	2.9264	2.6707	2.6063		.081	.1334
16	.12	3.3573	2.7515	2.4863		.116	.1524
17	.1372	2.8978	3.1121	2.5377			
18	.1372	2.692	2.7801	.0983	.1715		
19	.1372	2.4691	2.6595	.0995	.1905	.2195	.1311
20	.1372	.1143	.1509	.0983	.1715	.1772	.1147
21	.1372	.0191	.1509	.1006	.1715	.1829	.1475
22	.1372	.1334	.1463	.0995	.1524	.1698	.1311
23	.1372	.1334	.1463	.0983	.1524	.1651	.1147
24	1.6956	.12	.1334	.1463	1.6575	1.6804	1.7718
Max	2.3371	3.4568	3.1121	2.6406	2.4897	2.4863	2.7915
Min	.1029	.0191	.0983	.0983	.0732	.081	.1143
Avg	.8349	1.0970	1.0172	.8532	1.1954	.9492	1.0239

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 203 / 11 kv Ispurli Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5546	.2743	.2915	.3584	1.4899	1.4575	1.7924
2	1.5546	.2743	.2743	.3395	1.4899	1.4918	1.7737
3	1.6057	.2743	.2743	.3292	1.5546	1.5604	1.829
4	1.6057	.2915	.2915	.3475	1.5546	1.6118	1.829
5	1.6032	.3086	.2915	.3772	1.5708	1.6804	1.957
6	1.6057	.3258	.3258	.4024	1.587	1.869	1.9845
7	2.2542	.3772	.3601	.439	2.4453	2.3834	2.8481
8	2.4939	.3772	.463	.4527	2.7206	3.0007	2.9264
9	2.4741	.4904	.3887	.4287	2.7618	2.6578	2.3148
10	.1715	.4755	.3353	1.8347	.3658	.3401	.3258
11		.3109	.3239	2.4348	.3658	.3563	.8916
12		3.2922	2.6871		.3292	.2915	.2915
13	.2743	3.3653	2.4291	2.7092	.3292	.2753	.2286
14	.2743	3.2819	2.3967	2.5892	.3292	.2785	.2096
15	.3086	2.9447	2.4777	2.4691	.3292	.2591	.3429
16	.1372	3.219	2.4291	2.6749	.3086	.2591	.3601
17	.2743	2.7606	2.8349	2.7263	.3772	.3658	.3563
18	.3772	2.5892	2.7915	.2591	.3601	.3772	.3932
19	.3772	2.1262	2.3228	.3401	.4115	.4715	.4096
20	.3258	.3429	.3658	.2949	.3772	.4904	.3887
21	.3086	.3429	.3841	.2915	.3429	.4715	.3563
22	.3086	.3258	.3841	.2753	.2743	.4527	.3563
23	.2915	.3086	.2652	.2591	.3048	.3012	.3239
24	1.5384	.2743	.2915	.3841	1.4575	1.4403	1.8107
Max	2.4939	3.3653	2.8349	2.7263	2.7618	3.0007	2.9264
Min	.1372	.2743	.2652	.2591	.2743	.2591	.2096
Avg	.9872	1.2064	1.0700	1.0007	.9765	1.0060	1.0958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 204 / 11 Kv Bachani Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.3944	.4287	.4207	.4572	.4287	.4527
2	.4954	.3772	.4287	.3841	.4763	.4115	.4338
3	.4954	.4115	.463	.3772	.4954		.4207
4	.4763	.4801	.463	.415	.5525	.4458	.5304
5	.5335	.5487	.5144	.547	.6097	.4973	.5853
6	.6859	.6516	.6516	.679	.6859	.6001	.6584
7	.6097	.6173	.583	.6224	.6097	.5658	.6602
8	.6097	.583	.5487	.567	.5335	.5316	.5847
9	.4954	.5304	.5335	.463	.4525	.4801	.463
10		.4572	.5335	.4801	.4527	.4954	.463
11	.4287	.4572	.4572	.4458	.3961		.4458
12	.3772	.443	.4572	.463	.5281	.4763	.4458
13	.4458	.4525	.4572	.4458	.5093	.4954	.4458
14	.4287	.439	.4572	.4458	.4755	.4954	.463
15	.4287	.439	.4954	.4115	.4755	.5335	.4801
16	.4801	.4938	.5335	.4287	.4458	.5716	.4973
17	.4973	.463	.4525	.463	.4458	.567	.5525
18	.5144	.463	.5847	.5335	.5316	.5658	.5716
19	.6516	.6859	.7733	.6097	.6344	.6979	.6859
20	.6859	.6687		.724	.6859	.7682	.7811
21	.6344	.6001	.6979	.6859	.6173	.695	.724
22	.583	.5144	.5853	.6478	.583	.6413	.6478
23	.5144	.463	.5121	.4763	.4973	.5121	.5716
24	.5525	.4115	.4458	.4572	.4572	.4287	.4706
Max	.6859	.6859	.7733	.724	.6859	.7682	.7811
Min	.3772	.3772	.4287	.3772	.3961	.4115	.4207
Avg	.5278	.5019	.5242	.5081	.5253	.5411	.5431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 205 / 11 kv ispurli Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5144	.4801	.4801	.4755	.5525	.463	.4755
2	.5144	.4801	.4801	.4572	.5335	.463	.4572
3	.5335		.5144	.4338	.5335	.4973	.4938
4	.5716	.6516	.5658	.4755	.5716	.5487	.5853
5	.6668	.5487	.6516	.6413	.6097	.6687	.679
6	.8573	.7888	.7373	.8048	.8002	.7545	.9054
7	.8383	.7202	.6859	.6979	.6859	.6687	.7733
8	.8002	.6173	.5658	.6413	.5716	.6344	.679
9	.724	.6219	.6097	.583	.5487	.583	.6001
10	.5144	.5658	.4954	.5487	.5121	.6478	.6173
11	.4801	.5487	.5716	.4801	.3109	.6097	.5316
12	.5144	.5853	.5716	.5144	.3658	.6097	.463
13	.4801	.5121	.362	.4973	.3658	.5716	.463
14	.463	.6036	.4001	.4458		.6097	.4115
15	.2743	.679	.6478	.5144	.3292	.5716	.5144
16	.3429	.6979	.4954	.583	.3429	.6478	.6516
17	.4458	.6516	.679	.583	.3772	.5658	.724
18	.6516	.6516	.6602	.7049	.5487	.6979	.6668
19	.823	.823	.8048	.8002	.6344	.8413	.8383
20	.8573	.7545		.8383	.7888	.8688	.9335
21	.8059	.6687	.7964	.7811	.6859	.8676	
22	.6859	.5487	.8299	.7621	.6687	.7682	.8383
23	.6001	.5144	.5658	.6097	.5487	.5853	.7621
24	.5716	.5144	.4973	.5121	.5906	.4801	.547
Max	.8573	.823	.8299	.8383	.8002	.8688	.9335
Min	.2743	.4801	.362	.4338	.3109	.463	.4115
Avg	.6055	.6186	.5943	.5994	.5425	.6343	.6353

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 206 / 11 KV Renuka & Hanuman PURELY LIS FEEDERS  
Express Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4763	.1886	.4115	.4572	.3258	.4572
4	.4763	.1886	.4115	.4572	.3601	.4725
5	.4763	.1886	.4287		.4287	.4715
6	.4954	.1886	.4287	.4715	.4458	.4572
7	.4763	.1886	.4287	.4572	.4458	.4572
8	.4763	.1886	.4287	.4715	.4287	.4715
9	.4763	.2075	.4763	.4287	.4287	.4287
10	.4287	.2012	.4763	.4458	.4763	.4287
11	.4287	.2075	.4763	.4287	.4763	.4287
12	.4287	.2012	.4763	.4287	.4572	.4287
13	.4287	.2094	.4763	.4287	.4763	.4287
14	.4287	.2641	.4763	.4458	.4572	.2058
15	.4287	.1886	.4763	.4287	.4763	.2286
16	.4287	.3772	.4763	.4458	.4763	.2286
17	.4287	.4801	.4572	.4287	.4715	.4763
18	.4287	.4287	.4572	.4763	.4715	.4763
23		.0191				
Max	.4954	.4801	.4763	.4763	.4763	.4763
Min	.4287	.0191	.4115	.4287	.3258	.2058
Avg	.4507	.2304	.4539	.4467	.4439	.4091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144010 / 33/11 KV WADAKSHIVALE

Feeder No / Name : 207 / 11 KV Kawane Ag Feeder

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.583	.6173	.695		.0191	.0189
2	.0166	.5487	.6344	.7316		.0191	.0171
3	.0164	.5487	.6687	.7316		.0191	.0171
4	.0164	.6173	.6687	.8349		.0191	.0171
5	.0164	.6859	.7373	.9054		.0191	.0171
6	.0164	.7716	.9945	1.0242		.0191	.0171
7	.0164	1.0288	1.1831	1.3957	.0164	.0191	.0183
8		1.406	1.3889	1.4266	.0164	.0191	.0189
9	.0164	1.3717	1.2289	1.3203	.0183	.0191	.0191
10	.0171	1.1595	.0168	.0191	1.3352		1.5604
11	.0171	.0183	.0166	.0191	1.5181	1.5083	1.4746
12	1.406	.0183	.0164	.0191	1.7164	1.5424	1.4403
13	1.5089	.0181		.0191	1.5947	1.5083	1.4403
14	1.5432	.0183	.0164	.0191	1.6975	1.4255	1.4403
15	1.406	.0189	.0164	.0191	1.6461	1.3757	1.3889
16	1.406	.0189	.0164	.0191	1.5432	1.3757	1.3717
17	1.3717	.0191	.0183	.0191	1.4403	1.358	1.1797
18	1.2003	.0191	.0183	.0164	.0191	.0183	.0166
19	.6859	.0191	.0183	.0164	.0191	.0183	.0164
20	.0171	.0191	.0183	.0164	.0191	.0183	.0164
21	.0171	.0191	.0183	.0164	.0191	.0183	.0164
22	.0171	.0191	.0183	.0164	.0191	.0189	.0164
23	.0171	.0191	.0171		.0191	.0183	.0164
24	.0164	.6173	.6173	.679		.0191	.0183
Max	1.5432	1.406	1.3889	1.4266	1.7164	1.5424	1.5604
Min	.0164	.0181	.0164	.0164	.0164	.0183	.0164
Avg	.4686	.3993	.3898	.4339	.7445	.4520	.4822

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 201 / 11 KV BHOGAWATI GAVTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7316	.695	.7095	.439	.3547	.4294	.7316
2	.7316	.695	.7095	.4252	.3547	.4294	.695
3	.7316	.695	.7095	.439	.3361	.4108	.695
4	.7316	.695	.7095	.4344	.3361	.4108	.695
5	.7682	.7316	.7095	.4755	.3696	.4294	.7316
6	.8413	.8779	.6161	.5121	.5359	.5975	.9145
7	.8048	.8413		.5487	.4887	.5544	.8048
8	.8596	.8048	.4805	.5487	.4344	.462	.8048
9	.8413	.8063		.5121	.5304	.5121	.8048
10	.8413	.8413	.5853	.5121		.567	.823
11	.9145	.8322	.5853	.567		.5853	.823
12	.8048	.8322	.4607	.5121		.5487	.9145
13	.8145	.7011	.4755	.4755		.5087	.7964
14	.8413	.724	.439	.5487		.5087	.7964
15	.8779	.7964	.5121	.5304		.5028	.7964
16	.8413	.7712	.5487	.5487		.8048	.8145
17	.9145	.8764	.5487	.4525		.8779	.9231
18	.8596	.9511	.5487	.5373		.8413	.8764
19	.8962	.9694	.6584	.6099	.7316	1.0242	.9816
20	.9511	.9145	.695	.6283	.7947	.9511	1.0029
21	.9145	.9328	.6219	.5788	.7023	.9145	.9465
22	.8413	.9511	.5853	.5601	.6401	.8779	.964
23	.7682	.8871	.5487	.4294	.5175	.8048	.8063
24	.7316	.695	.7655	.4755	.3921	.462	.7682
Max	.9511	.9694	.7655	.6283	.7947	1.0242	1.0029
Min	.7316	.695	.439	.4252	.3361	.4108	.695
Avg	.8273	.8132	.6010	.5125	.5013	.6256	.8296

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 202 / 11 KV RASHIWADE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.4752	.9835	1.0974	.0686	.0343
2	.0514	1.4752	.9945	1.1317	.0692	.0343
3	.0514	1.5261	1.0174	1.1317	.0692	.0343
4	.0514	1.5261	1.0852	1.2003	.0692	.0343
5	.0514	1.5939	1.153	1.5432	.0698	.0343
6	.0514	1.8821	1.56	1.8861	.0692	.0343
7	.0514	2.1365	1.9161	2.1262	.0692	.0343
8	.0514	2.2721	2.0687	4.297	.0692	.0343
9	.0514	2.1795		4.297	.1018	.0852
10	.0509	.0166	.0343	.0852		2.5095
11	.0509	.0166	.0514	.0852		3.1878
12	2.713	.0166		.0852		3.1369
13	2.6452	.0177	.0171	.0852		3.1539
14	2.6621	.0358	.0171	.08		
15	2.5434	.0351	.0171	.0863		.3467
16	2.713	.0351	.0171	.0863		2.9673
17	2.5604	.0351	.0343	.0863		
18	2.4417	.0236	.0514	.0698		
19	2.2382	.0335	.0343	.0703	.0354	
20	.0509	.0335	.0343	.0709	.0354	
21	.0509	.0514	.0343	.0692	.0354	
22	.0509	.0335	.0532	.0692	.0343	
23	.0509	.0343	.0532	.0692	.0343	
24	.0514	1.3735	.5256	.9602	.0715	.0343
Max	2.713	2.2721	2.0687	4.297	.1018	3.1878
Min	.0509	.0166	.0171	.0692	.0343	.0343
Avg	.8890	.7441	.5342	.8654	.0601	.981



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 203 / 11 KV KOULAV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2193	.0347	.0373	.0343	1.1904	1.2209	1.3032
2	1.2193	.0347	.0373	.0343	1.1736	1.2378	1.3375
3	1.2803	.0347	.0373	.0343	1.1904	1.2887	1.3717
4	1.3108	.0347	.0373	.0343	1.1603	1.3226	1.406
5	1.6385	.0347	.0373	.0343	1.2266	1.4582	1.4403
6	1.866	.0347	.0373	.0343	1.4419	1.6461	1.5089
7	1.8976	.0332	.0373	.0343	1.6741	1.933	2.2314
8	1.9662	.0332	.0373	.0343	1.757	1.9161	
9	1.8976	.0377		.0354	1.7238	1.8313	1.8652
10	.0166	.0377	.0354	1.6617		.0332	.0187
11		.056	.0343	2.2891		.0166	.0373
12		2.5194	2.7435	2.5265		.0166	.0373
13	.0166	2.7199	2.5857	2.4417		.0187	.0373
14	.017	2.6155	2.4577	2.3739		.0187	.0373
15	.017		2.572	2.323		.037	.0373
16	.0166	2.6852	2.572	2.2721		.0332	.0373
17	.0166	2.7854	2.4006	2.1195		.0514	.0373
18	.0166	2.5774	2.2291	.0381	.0373	.0514	.0566
19	.0332	2.2891	2.2634	.0377	.0373	.0514	.0566
20	.0497	.0373	.0343	.0377	.0373	.0514	.0566
21	.0332	.0373	.0343	.0377	.0373	.0514	.0566
22	.0332	.0373	.0343	.0377	.0373	.0532	.0566
23	.0332	.0373	.0343	.0377	.0373	.0514	.0373
24	1.3717	.0347	.0373	.0343	1.1401	1.2717	1.2346
Max	1.9662	2.7854	2.7435	2.5265	1.757	1.933	2.2314
Min	.0166	.0332	.0343	.0343	.0373	.0166	.0187
Avg	.7258	.8166	.8855	.7741	.8689	.6526	.6217

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 204 / 11 KV NAGESHWAR GAVTHAN  
VG FD Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2012	.2075	.2054	.1646	.1886	.2075	.2012
2	.2012	.2075	.2054	.1646	.1886	.2075	.2012
3	.2012	.2075	.2075	.1646	.1886	.1886	.2012
4	.2075	.2075	.2075	.1646	.1886	.1867	.2012
5	.2195	.2075	.2054	.1646	.1886	.2075	.2195
6	.2561	.2054	.2054	.1829	.2263	.2241	.2378
7	.2195	.2012	.2241	.2012	.2075	.2241	.2195
8	.2195	.1791	.1848	.1949	.1698	.1848	.1772
9	.2195	.181		.1829	.2054	.1848	.1753
10	.1753	.1772	.1829	.1646		.1629	.1829
11	.1928	.181	.1715	.1829		.1991	.1829
12	.1753	.181	.1772	.1829		.197	.2172
13	.1928	.1448	.1829	.2012		.2012	.2012
14	.197	.1629	.2012	.181		.1991	.2149
15	.197	.2353	.2195	.2012		.197	.2149
16	.2149	.2172	.2378	.197		.197	.2172
17	.2378	.2172	.2378	.2012		.2126	.2561
18	.2328	.2126	.2195	.2058	.2195	.2378	.2303
19	.2865	.2926	.2743	.2987	.3109	.3109	.3018
20	.3658	.3326	.3292	.3361	.3511	.3292	.3734
21	.3109	.3109	.3109	.3018	.3174	.2835	.3206
22	.3018	.2772	.2743	.2263	.2987	.2835	.3018
23	.2452	.2427	.2195	.2452	.2427	.2561	.2641
24	.2012	.2075	.2054	.1829	.2075	.2054	.2195
Max	.3658	.3326	.3292	.3361	.3511	.3292	.3734
Min	.1753	.1448	.1715	.1646	.1698	.1629	.1753
Avg	.2280	.2165	.2213	.2039	.2312	.2203	.2305

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 144078 / 33/11 KV RASHIWADE

Feeder No / Name : 205 / SHAHU LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	03-APR-18
HR	Load (MW)
20	.0566
Max	.0566
Min	.0566
Avg	.0566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 202 / 11 KV COLLAGE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.2486
Max	.2486
Min	.2486
Avg	.2486

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 203 / 11 KV KURDU  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.3429
Max	.3429
Min	.3429
Avg	.3429

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 204 / 11 KV WASHI SHETI  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.5144
Max	.5144
Min	.5144
Avg	.5144

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 205 / 11 KV DEWALE

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.5173
Max	.5173
Min	.5173
Avg	.5173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 206 / 11 KV TULASHI

Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	01-APR-18
HR	Load (MW)
24	.2629
Max	.2629
Min	.2629
Avg	.2629



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 207 / 11 KV HIRAWADE  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	.4287
Max	.4287
Min	.4287
Avg	.4287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 402 / 33 KV Kanchanwadi Feeder  
Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	2.2377
Max	2.2377
Min	2.2377
Avg	2.2377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146011 / 110/11 KV KOTHALI

Feeder No / Name : 403 / Awali

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	8.2179
Max	8.2179
Min	8.2179
Avg	8.2179

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 401 / 33KV Shahumill

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	8.2899
Max	8.2899
Min	8.2899
Avg	8.2899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 405 / 33KV GOKUL SHIRGAON

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	3.1493
Max	3.1493
Min	3.1493
Avg	3.1493

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 406 / Rajiwaji Sut Girani  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.5844
Max	1.5844
Min	1.5844
Avg	1.5844

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 408 / 33 kv Puikhadi incomming  
II Feeder KV- 33 / INCOMINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	2.037
Max	2.037
Min	2.037
Avg	2.037

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PARITE[038] BU 6165

Substation No/ Name :- 146013 / 111/33 kv Puikhadi

Feeder No / Name : 412 / 33 KV KOGE

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.4801
Max	5.4801
Min	5.4801
Avg	5.4801



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 201 / 11 Kv Wakare Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3086	.017	.0166	.0168	.6104	.4409	.4024
2	.362	.017	.0168	.0168	.6104	.4409	.4359
3	.4287	.017	.0166	.0168	.6104	.4409	.4359
4	.463	.017	.0168	.0168	.6443	.4409	.4359
5	.5533		.0166	.0168	.6783	.4409	.57
6	.6036	.017	.0168	.0168	.7461	.5765	.6371
7	.6706	.017	.0168	.0168	.8817	.7122	.7042
8	.7377	.017	.0166	.0166	.9496	.8139	.7712
9	.7042	.017	.0168	.017	.8048	.78	.6783
10	.0168	.0166	.0168	.5243	.0168	.0168	.017
11	.0168	.017	.0168	.8097	.0168	.0168	.017
12	.0168	1.0852	1.2071	.9393	.0168	.0168	.017
13	.0168	1.1191	1.1736	1.1012	.0168	.0168	
14	.0168	1.0174	1.1401	1.1271	.0168	.0166	.017
15	.0166	1.0852	1.153	1.094		.0166	.017
16	.017	1.1401	1.153	1.1603		.0168	.017
17	.017	1.1271	1.0852	1.1022	.017	.0168	.017
18	.017	1.0059	1.0174	.017	.017	.0168	.017
19	.017	.7377	.9496	.017	.017	.0168	.017
20	.017	.0168	.017	.017	.017	.0166	.017
21	.017	.0168	.0168		.017	.0166	.017
22	.017	.0168	.0166	.017	.017	.0166	.017
23	.017	.0171	.0168	.017	.017	.0166	.017
24	.2683	.017	.0168	.0168	.5765	.407	.0168
Max	.7377	1.1401	1.2071	1.1603	.9496	.8139	.7712
Min	.0166	.0166	.0166	.0166	.0168	.0166	.0168
Avg	.2224	.3727	.3811	.3527	.3325	.2387	.2308

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 202 / 11 Kv Mahe Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2865	.2865	.2835	.362	.3224	.3224	.3292
2	.2481	.2507	.2481	.362	.3258	.3224	.3258
3	.2481	.2507	.2481	.362	.3258	.3189	.3258
4	.2481	.2865	.2481	.4344	.3258	.3224	.3258
5	.4298	.3224	.3544	.4344	.362	.3582	.362
6	.5014	.4656	.4961	.4344	.4656	.4656	.4706
7	.5014	.4656	.4607	.4706	.4298	.5014	.4344
8	.5014	.4477	.4961	.4706	.4656	.5373	.4344
9		.4298	.4252	.4607	.362	.5014	.394
10	.4706	.4656	.439	.4755	.362	.4961	.4298
11	.4706	.4656	.4344	.4344	.2926	.5316	.4656
12	.5068	.4298	.362	.4656	.362	.4607	.4656
13	.4706	.4298	.3982	.4607	.3353	.4607	
14	.4656	.3582	.3982	.3544	.3544	.4252	.5068
15	.4298	.394	.3582	.4252		.3898	.3898
16	.4298	.3898	.3582	.4557		.4252	.4607
17	.3982	.3898	.3898	.4298	.3898	.4344	.394
18	.4298	.3898	.4252	.5014	.3898	.4344	.4298
19	.5731	.5316	.4961	.5792	.5316	.5068	.5731
20	.5731	.567	.5316	.5487	.567	.5792	.5792
21	.5068	.5316	.543	.4805	.5316	.4706	.5373
22	.4298	.4961	.5121	.4251	.4961	.4344	.5014
23	.3224	.3544	.4344	.362	.362	.4024	.4298
24	.3224	.2896	.3189	.3772	.3258	.3224	.3258
Max	.5731	.567	.543	.5792	.567	.5792	.5792
Min	.2481	.2507	.2481	.3544	.2926	.3189	.3258
Avg	.4245	.4037	.4025	.4403	.3948	.4343	.4300

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 203 / 11 Kv Bahireshwar Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1448	.1509	.1448	.1463	.1132	.1509	.1463
2	.1463	.1509	.1448	.1463	.1132	.1132	.1097
3	.1463	.1509	.1463	.1463	.1132	.1132	.1097
4	.1448	.1509	.1448	.1463	.1132	.1509	.1463
5	.1829	.1886	.181	.1829	.1509	.1867	.1829
6	.2195	.2641	.2195	.2195	.2263	.2241	.2195
7	.181	.2195	.2172	.2561	.1867	.2172	.1829
8	.2195	.2218	.2195	.1829	.1663	.1772	.2195
9	.1829	.1791	.1463	.2195	.1829	.1417	.2195
10	.1829	.1791	.1341	.1829	.1829	.181	.1433
11	.2195	.1791	.1677	.1753	.1463	.2195	.1478
12	.2195	.1772	.2012	.2126	.1463	.2172	.1791
13	.2195	.1772	.2195	.1772	.1448	.2195	
14	.2218	.181	.2561	.1772	.1448	.2195	.2195
15	.2218	.2149	.2149	.1791		.2172	.1848
16	.2149	.2172	.181	.1791		.1829	.1848
17	.1663	.1829	.1417	.1612	.1433	.1829	.1829
18	.2033	.181	.1791	.181	.1463	.1829	.1829
19	.2587	.2195	.1848	.2218	.2218	.2195	.2587
20	.2427	.2561	.2263	.2587	.2263	.2561	.2614
21	.2054	.2195	.1829	.2641	.2263	.2195	.2427
22	.2263	.181	.1829	.2263	.1886	.2195	.2263
23	.1886	.1448	.1829	.1886	.0189	.1829	.1905
24	.1463	.1509	.1463	.1463	.1509	.1509	.1463
Max	.2587	.2641	.2561	.2641	.2263	.2561	.2614
Min	.1448	.1448	.1341	.1463	.0189	.1132	.1097
Avg	.1961	.1891	.1819	.1907	.1570	.1894	.1864

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 204 / 11 Kv Sangrul Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0164	.6299	.5898	.4973	.0166	.0166	.0166
2	.0164	.663	.5967	.4973	.0166	.0166	.0166
3	.0166	.663	.5967	.5967	.0166	.0166	.0166
4	.0164	.6962	.5967	.5967	.0166	.0166	.0166
5	.0164	.7625	.6299	.7042	.0166	.0166	.0166
6	.0164	.8288	.7956	.9054	.0166	.0166	.0166
7	.0166	1.094	.9945	1.0059	.0166	.0166	.0166
8	.0164	1.2929	1.2929	1.2071	.0166	.0166	.0166
9	.0166	1.1934	1.1934	.9945	.0168	.0166	.0166
10	.0166	.0166	.0166	.0168	1.0059	.9945	1.1603
11	.0166	.0166	.0166	.0168	1.2071	1.4255	1.4918
12	1.094	.0166	.0166	.0168	1.4083	1.5912	1.4586
13	1.1934	.0166	.0166	.0168	1.4083	1.5912	
14	1.1934	.0166	.0166	.0168	1.3763	1.4746	1.4918
15	1.3923	.0166	.0166	.0168		1.4255	1.3923
16	1.3923	.0164	.0166	.0168		1.4255	1.3923
17	1.326	.0164	.0166	.0166	1.1934	1.1934	1.2929
18	1.2266	.0166	.0166	.0166	.0166	.0166	.0166
19	.8951	.0164	.0166	.0166	.0166	.0166	.0166
20	.0166	.0164	.0166	.0166	.0166	.0166	.0166
21	.0166	.0164	.0166	.0166	.0166	.0166	.0166
22	.0166	.0164	.0166	.0166	.0166	.0166	.0166
23	.0166	.0164	.0166	.0166	.0166	.0166	.0166
24	.0166	.5967	.5967	.4973	.0166	.0166	.0166
Max	1.3923	1.2929	1.2929	1.2071	1.4083	1.5912	1.4918
Min	.0164	.0164	.0166	.0166	.0166	.0166	.0166
Avg	.4157	.3605	.3381	.3223	.3575	.4745	.4324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 205 / 11 Kv Mahe Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1088	.0191	.0189	.0168	1.094	.9717	1.0059
2	1.1765	.0191	.0187	.0168	1.094	1.004	1.0395
3	1.267	.0191	.0189	.0168	1.1271	1.004	1.073
4	1.3306	.0191	.0187	.0168	1.1934	1.0486	1.073
5	1.4377	.0191	.0187	.0168	1.2266	1.0814	1.3413
6	1.4937	.0191	.0185	.0168	1.326	1.2929	1.6095
7	1.9404	.0191	.0187	.0168	1.5581	1.8896	1.9448
8	2.1538	.0191	.0187	.0168	1.757	2.1125	2.146
9	1.7772	.0191	.0187	.0191	1.6766	1.7901	1.8107
10	.0168	.0191	.0168	1.3592	.0168	.0187	.0191
11	.0168	.0191	.0168	2.146	.0168	.0185	.0191
12	.0168	2.3472	2.2801	2.4417	.0168	.0189	.0191
13	.0168	2.3807	2.2131	2.3472	.0168	.0189	
14	.0191	2.3472	2.2801	2.2131	.0187	.0187	.0191
15	.0191	2.3472	2.3472	1.989		.0187	.0191
16	.0191	2.3537	2.3472	1.9113		.0187	.0191
17	.0191	2.3371	2.2801	1.8896	.0191	.0168	.0191
18	.0191	2.1714	2.0645	.0191	.0191	.0168	.0191
19	.0191	1.4746	1.7695	.0191	.0191	.0168	.0191
20	.0191	.0187	.0191	.0191	.0191	.0168	.0191
21	.0191	.0187	.0168	.0191	.0191	.0168	.0191
22	.0191	.0166	.0168	.0191	.0191	.0168	.0191
23	.0191	.0187	.0168	.0191	.0191	.0168	.0191
24	1.0829	.0191	.0187	.0472	1.0608	.8962	.9389
Max	2.1538	2.3807	2.3472	2.4417	1.757	2.1125	2.146
Min	.0168	.0166	.0168	.0168	.0168	.0168	.0191
Avg	.6261	.7525	.7447	.6922	.6061	.5558	.6187

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144005 / 33/11 KV KOGE

Feeder No / Name : 206 / 11 Kv bahireshwar Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.6057	.0191	.0185	.0168	1.4255	1.3923	1.3763
2	1.5927	.0191	.0187	.0168	1.4255	1.3923	1.3763
3	1.5775	.0191	.0185	.0168	1.4255	1.4255	1.4091
4	1.6651	.0191	.0187	.0168	1.4586	1.4754	1.4419
5	1.7187	.0191	.0187	.0168	1.4918	1.5089	1.5424
6	1.7375	.0191	.0189	.0168	1.5249	1.643	1.6095
7	2.0058	.0191	.0187	.0168	1.7238	1.989	1.9006
8	2.2502	.0191	.0187	.0168	1.9227	2.1216	2.0972
9	1.9757	.0191	.0189	.0191	1.8778	1.9559	1.8564
10	.0168	.0191	.0168	1.6278	.0168	.0187	.0191
11	.0168	.0191	.0168	2.1125	.0168	.0187	.0191
12	.0168	2.0553	2.4143	2.2542	.0168	.0187	.0191
13	.0168	2.3807	2.3472	2.3137	.0168	.0187	
14	.0191	2.2939	2.3472	2.3137	.0187	.0187	.0191
15	.0191	2.2874	2.3205	2.2131		.0189	.0191
16	.0191	2.2874	2.2801	2.079		.0189	.0191
17	.0191	2.3703	2.2874	1.989	.0191	.0162	.0191
18	.0191	2.2045	2.2043	.0191	.0191	.0162	.0191
19	.0191	1.4255	1.6095	.0191	.0191	.0162	.0191
20	.0191	.0189	.0191	.0191	.0191	.0162	.0191
21	.0191	.0185	.0168	.0191	.0191	.0162	.0191
22	.0191	.0187	.0168	.0191	.0191	.0162	.0191
23	.0191	.0189	.0168	.0191	.0191	.0166	.0191
24	1.5708	.0191	.0187	.0168	1.3923	1.4083	1.3603
Max	2.2502	2.3807	2.4143	2.3137	1.9227	2.1216	2.0972
Min	.0168	.0185	.0168	.0168	.0168	.0162	.0191
Avg	.7482	.7337	.7542	.7162	.7222	.6899	.7051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 201 / 11 kv Nagdevwadi Ag      SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING      DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0974	.823	1.2498	1.286	.061	.061	.0686
2	1.0974	.823	1.2803	1.286	.061	.061	.0686
3	1.0669	.823	1.3239	1.286	.061	.061	.0686
4	1.0974	.884	1.3108	1.3203	.061	.061	.0686
5	1.1279	.945	1.4022	1.3889	.061	.061	.0686
6	1.1279	1.1279	1.5242	1.4403	.061	.061	.0686
7	1.1584	1.2346	1.5546	1.7147	.061	.061	.0686
8	1.2498	1.3565	1.5546	1.749	.061	.061	.0686
9	1.2193	1.2803	1.5851	1.7147	.0305	.061	.0686
10	.061	.061	.061	.061	1.2193	1.387	1.7833
11	.0686	.061	.061	.0305	1.989	2.0729	2.1033
12	.0686	.061	.061	.061	1.989	1.9814	1.9509
13	.0686	.061	.061		1.9204	1.89	
14	.0686	.061	.061	.061	1.9204	1.8595	1.9662
15	.0686	.061	.061	.0305	1.7833	1.89	1.9509
16	.0686	.061	.061		2.0576	1.9814	1.9357
17	.0686	.061	.061	.061	1.989	1.89	1.9052
18	.061	.061	.0686	.061	.0686	.0686	.061
19	.061	.061	.0686	.0305	.061	.0686	.061
20	.061	.061	.0686	.061	.061	.0686	.061
21	.061	.061	.0686	.061	.061	.0686	.061
22	.061			.0305	.061	.0686	.061
23	.061	.061		.061	.061	.0686	.061
24	.9214	.5639	1.2193	1.2346	.061	.061	.0686
Max	1.2498	1.3565	1.5851	1.749	2.0576	2.0729	2.1033
Min	.061	.061	.061	.0305	.0305	.061	.061
Avg	.5030	.4632	.6712	.6832	.6592	.6656	.6368

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 202 / 11 kv Padali Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1372	.12	.1543	.1219	.1372	.1543
2	.1372	.1372	.1067	.1543	.1219	.1372	.1543
3	.1372	.1372	.1372	.1543	.1219	.1372	.1543
4	.1715	.1372	.1372	.1715	.1524	.1372	.1543
5	.1715	.1372	.1372	.1715	.1524	.1372	.1715
6	.1715	.1219	.1524	.1886	.1524	.1715	.1886
7	.1372	.1372	.1543	.1543	.1524	.1715	.1715
8	.1543	.1029	.1543	.1372	.1219	.1372	.1543
9	.1372	.1029	.1715	.12	.1219	.12	.1372
10	.12	.1029	.1543	.1219	.1219	.1029	.1372
11	.1372	.1372	.12	.1219	.12	.12	.1372
12	.1372	.1372	.1372	.1219	.1372	.12	.1219
13	.1372	.1543	.1372	.1219	.12	.12	
14	.12	.1543	.1372	.1219	.12	.1372	.1543
15	.12	.1524	.1372	.1219	.1029	.1543	.1524
16	.1543	.1715	.1715	.1219	.1029	.1543	.1543
17	.1372	.1524	.1543	.1219	.0857	.1715	.1715
18	.1372	.1715	.1543	.1524	.1543	.1543	.1886
19	.1543	.2058	.1886	.1829	.1543	.2229	.1886
20	.2058	.1886	.2058	.1829	.2058	.2229	.1829
21	.2058	.1715	.2229	.1524	.1886	.1886	.2058
22	.1715	.1372		.1524	.1543	.1886	.1677
23	.1372	.1543		.1219	.1372	.1715	.1715
24		.1543	.12	.1715	.1219	.1372	.1543
Max	.2058	.2058	.2229	.1886	.2058	.2229	.2058
Min	.12	.1029	.1067	.12	.0857	.1029	.1219
Avg	.1491	.1457	.1505	.1457	.1353	.1522	.1621



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 203 / 11 kv khupire Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2401	.2572	.2058	.2572	.2572	.2743	.2743
2	.2401	.2572	.2058	.2572	.2572	.2743	.2572
3	.2572	.2572	.2401	.2572	.2572	.2743	.2572
4		.2743	.2743	.2743	.3429	.2743	.2743
5	.3086	.2915	.3429	.3086		.2743	.3429
6	.3772	.3601	.4458	.3429	.3429	.4115	.3944
7	.3772	.3429	.4973	.3601	.381	.3944	.4458
8	.3772	.4115	.4801	.4115	.4268	.3944	.4287
9	.3601	.3601	.4458	.3601	.381	.3601	.3944
10	.3772	.3258	.4115	.3353	.3506	.3429	.4287
11	.3944	.4458	.3944	.3353		.4801	.4115
12	.4287	.5316	.4801	.381		.463	.463
13	.4115	.4287	.463	.3048		.4801	
14	.4115	.4458	.4458	.3353		.4458	.4458
15	.4115	.4801	.4973	.4572	.463	.4973	.3963
16	.3944	.5144	.4973	.4572	.4287	.5487	.463
17	.4287	.463	.5144	.4572	.4287	.5487	.463
18	.4801	.4458	.4458	.4572	.463	.4973	.4801
19	.5144	.5487	.4115	.503	.5144	.583	.4973
20	.4801	.5144	.463	.4572	.5144	.4801	.4973
21	.4458	.3944	.4458	.3506	.4973	.3944	.5144
22	.4115	.3429		.3772	.4115	.3944	.5316
23	.3258	.2915		.2743	.3086	.3258	.3429
24	.2743	.2743	.2401	.2572	.2572	.2743	.2743
Max	.5144	.5487	.5144	.503	.5144	.583	.5316
Min	.2401	.2572	.2058	.2572	.2572	.2743	.2572
Avg	.3795	.3858	.4022	.3570	.3833	.4037	.4034

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 204 / 11 Kv Fulewadi Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8402	.823	.8573	.8573	.7888	.7545
2	.7888	.8402	.7888	.823	.8573	.7888	.7545
3	.823	.8402	.7316	.823	.8573	.7716	.7545
4	.8573	.823	.8573	.823	1.0288	.7888	.7716
5	.9602	.8402	.9259	.8916	.9145	.8059	.8916
6	1.0288	.9945	1.0288	.9259	1.0288		1.0631
7	1.0974	1.0631	1.0974	1.0288	.9145	1.046	1.0288
8	1.0631	1.046	.9945	1.0288	.8535	.9774	.9259
9	.9602	.9945	.8916	1.0288	.7621	.8916	.8573
10	.8916	.9774	.8916	.823	.6859	.8745	.823
11	.8916	.8916	.8916	.9431	.6859	.7716	.8573
12	.9259	.9259	.9088	.9431	.7545	.823	.8745
13		.8916	.8573	.8573	.6859	.9259	
14	.8916	.9259	.8059	.7621	.6859	.8573	1.0117
15	.8916	.9259	.8402	.7716	.6859	.823	.7926
16	.8916	.9602	.8573	.7716		.823	.823
17	.9259	.9602	.8916	.9431	.8573	.8916	.8402
18	.9774	.9259	.8916	.884	.8573	.9259	.9602
19	1.1831	1.3375	1.0974	1.2346	1.0117	1.166	1.2346
20	1.3717	1.3375	1.2346	1.3032	1.2174	1.2346	1.2689
21	1.3375	1.2689	1.166	1.0669	1.166	1.166	1.2003
22	1.3032	1.0059		.9907	1.1317	1.166	1.1317
23	1.0974	.945		.9145	.9945	.8916	.9602
24	.8916	.9088	.9259	.8877	.8916	.7716	.823
Max	1.3717	1.3375	1.2346	1.3032	1.2174	1.2346	1.2689
Min	.7888	.823	.7316	.7621	.6859	.7716	.7545
Avg	.9945	.9779	.9272	.9303	.8863	.9118	.9306

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 206 / 11 KV KUDITRE AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
 Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0305	.0152	.0305	.0343	1.5432	1.4022	1.3717
2	.0305	.0152	.0305	.0343	1.5432	1.4022	1.3717
3	.0305	.0152	.0305	.0343	1.5242	1.3717	1.3717
4	.0305	.0152	.0305	.0343	1.5242	1.3717	1.406
5	.0343	.0152	.0305	.0343	1.5242	1.3717	1.749
6	.0343	.0152	.0305	.0343	1.9719	1.6766	2.1948
7	.0305	.0152	.0305	.0343	2.572	2.332	2.8807
8	.0305	.0152	.0305	.0343	2.4387	2.5911	3.155
9	.0305		.0305	.0343	2.2862	2.3929	2.6063
10	.0305	.0152	.0305	2.0729	.0343	.0152	.0343
11	.0343	.0152	.0305	2.915	.0343	.0152	.0152
12	3.4294	3.2007	1.6613	2.6673	.0343	.0152	.0152
13	3.7037	3.2922	2.8045	3.0864	.0343	.0152	.0152
14	3.6008	3.2007	2.713	1.9814	.0343	.0152	.0152
15	3.4294	3.0483	2.5758	2.8959	.0343	.0152	.0152
16	3.7037	2.8959	1.9204	2.8959	.0343	.0152	.0152
17	3.4294	3.0483	1.6766	2.6673	.0343	.0305	.0152
18	2.8349	2.5606	2.7435	.0343	.0343	.0343	.0152
19	2.3929	1.5546	2.4691	.0343	.0152	.0343	.0152
20	.0152	.0152	.0343	.0343	.0152	.0343	.0152
21	.0152	.0305	.0343	.0343	.0152	.0343	.0152
22	.0152	.0305		.0343	.0152	.0343	.0152
23	.0152	.0305		.0343	.0152	.0343	.0152
24	.0305	.0152	.0305	.0343	1.3413	1.3717	1.3717
Max	3.7037	3.2922	2.8045	3.0864	2.572	2.5911	3.155
Min	.0152	.0152	.0305	.0343	.0152	.0152	.0152
Avg	1.1234	1.0033	.8636	.9055	.7772	.7344	.8213

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 207 / 11 KV FULEWADI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1					.4572	.503	.5792
2					.4572	.4877	.5792
3					.4572	.4877	.5792
4					.4572	.503	.5944
5					.5335	.5182	.6401
6					.5335	.5944	.6706
7					.7621	.7773	.823
8					.9145	.8688	.823
9					.8383	.823	.7468
10				.6401			
11				1.0669			
12	.9297	1.0822	1.2041	1.1431			
13	.9755	1.1126	1.2041	1.1431			
14	.9755	1.0669	1.1126	1.0669			
15	.9755	1.0364	1.0517	1.0669			
16	.9602	1.0059	1.0669	.9907			
17	.8383	1.0059	1.0364	.9907			
18	.8078	.9145	.9755				
19	.7621	.503	.8993				
24					.4572	.5182	.5335
Max	.9755	1.1126	1.2041	1.1431	.9145	.8688	.823
Min	.7621	.503	.8993	.6401	.4572	.4877	.5335
Avg	.9031	.9659	1.0688	1.0136	.5868	.6081	.6569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 208 / 11KV Padali Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.945	.945	1.0059		.0305	.0152	.0152
2	.945	.945	1.0059		.0305	.0152	.0152
3	.9755	.945	1.0669		.0305	.0152	.0152
4	.9828	.9602	1.1279		.0305	.0152	.0152
5	.9755	.9602	1.1685		.0343	.0152	.0152
6	.9755	1.0364	1.2193		.0305	.0152	.0152
7	1.2193	1.2803	1.3413		.0305	.0152	.0305
8	1.2193	1.4022	1.3717		.0305	.0152	.0305
9	1.2498	1.5242	1.4022		.0305	.0152	.0305
10	.0152	.0152	.0152	.0305	1.3717	1.448	1.5546
11	.0305	.0152	.0152	.0305		2.0119	1.7985
12	.0152	.0152		.0305		1.9814	1.829
13	.0152	.0152	.0152	.0305	1.9204	1.89	
14	.0152	.0152	.0152	.0305	1.89	1.829	1.7528
15	.0152	.0152	.0152	.0305	1.768	1.768	1.7528
16	.0152	.0152	.0152	.0305	1.829	1.7071	1.5699
17	.0152	.0152	.0152	.0305	1.768	1.5851	1.5851
18	.0152	.0152	.0152	.0305	.0152	.0152	.0305
19	.0152	.0152	.0152	.0305	.0152	.0152	.0305
20	.0152	.0152	.0152	.0305	.0152	.0152	.0305
21	.0152	.0152	.0152	.0305	.0152	.0152	.0305
22	.0152	.0152		.0305	.0152	.0305	.0305
23	.0152	.0152		.0305	.0152	.0152	.0305
24	.9755	.9145	.9755	1.1431	.0305		.0152
Max	1.2498	1.5242	1.4022	1.1431	1.9204	2.0119	1.829
Min	.0152	.0152	.0152	.0305	.0152	.0152	.0152
Avg	.4455	.4636	.5644	.1047	.4976	.6289	.5315

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 209 / 11KV Khupire Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4268	.4725	.7621	.4572	.0305	.0152	.0305
2	.4572	.4725	.7621	.4572	.0305	.0152	.0305
3	.4877	.4877	.7926	.4725	.0305	.0152	.0305
4	.5182	.5487	.823	.4725	.0305	.0152	.0305
5	.5487	.6687	.9145	.7316	.0305	.0152	.0305
6	.6097	.0914	1.0364	.8535	.0305	.0152	.0305
7	.9755	.0762	1.4797	1.2803	.0305	.0152	.0305
8	1.0974	.823	1.4632	1.2803	.0305	.0152	.0305
9	1.1279	1.1279	1.4327	1.3413	.0305	.0152	.0305
10	.0305	.0152	.0305	.0305	1.0669	.8535	1.0974
11		.0152	.0305	.0305	1.7071	1.4632	1.5546
12		.0152	.0152	.0305	1.7071	1.5242	1.6004
13		.0305	.0152	.0305	1.6461	1.5851	
14	.0305	.0305	.0152	.0305	1.6461	1.4022	1.448
15	.0305	.0343	.0152	.0305	1.4022	1.3108	1.3717
16	.0305	.0305	.0152	.0305	1.4632	1.3413	1.2498
17	.0305	.0305	.0152	.0305	1.2803	1.2498	1.2803
18	.0152	.0305	.0152	.0305	.0686	.061	.0305
19	.0152	.0305	.0152	.0305	.0152	.0305	.0305
20	.0152	.0305	.0152	.0305	.0152	.0305	.0305
21	.0152	.0305	.0152	.0305	.0152	.0305	.0305
22	.0152	.0305		.0305	.0152	.0305	.0305
23	.0152	.0305		.0305	.0152	.0305	.0305
24	.2439	.3048	.7316	.3048	.0305	.0152	.0305
Max	1.1279	1.1279	1.4797	1.3413	1.7071	1.5851	1.6004
Min	.0152	.0152	.0152	.0305	.0152	.0152	.0305
Avg	.3208	.2274	.4732	.3366	.5154	.4623	.4387

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144031 / 33/11 KV Balinga S/Stn

Feeder No / Name : 210 / 11 Kv kuditre Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6173	.5316	.4801	.4801	.4572	.4801	.5487
2	.6173	.5316	.4801	.463	.5144	.4801	.5487
3	.6516	.5316	.5144	.463	.6001	.4801	.5487
4	.6516	.5487	.5487	.4801	.5335	.4801	.5487
5	.6859	.583	.6173	.6001	.5335	.4801	.6516
6	.823	.7888	.7545	.6859	.6859	.6687	.7545
7	.7888	.7373	.7202	.7545	.6859	.703	.6859
8	.7202	.7716	.7202	.6859	.6516	.6173	.6859
9	.6516	.6859	.6859	.6859	.6516	.6516	.6859
10	.7545	.7373	.6859	.6097	.4572	.6687	.6859
11	.7545	.7202	.6516	.5792	.4973	.5487	.6516
12	.6859	.6859	.6516	.6097	.4973	.5487	.6687
13	.6859	.6516	.583	.6516		.5182	
14	.6859	.6344	.5658	.5792	.4287	.6173	.6173
15	.6516	.583	.5658	.6859	.1029	.6516	.5487
16	.6859	.6173	.583	.5792	.4458	.7202	.703
17	.6859	.6516	.6173	.6859	.5144	.7545	.7545
18	.6173	.7545	.6344	.6859	.6173	.6859	.6859
19	.7373	.8573	.6859	.8573	.703	.823	.8916
20	.8573	.8745	.6859	.7716	.7716	.823	.9602
21	.823	.823	.7545	.7716	.703	.7716	.8916
22	.823	.7202	.6859	.6859	.6687	.6859	.7202
23	.6344	.583	.583	.6173	.583	.6344	.5487
24	.6516	.5487	.5144	.4953	.4572	.4801	.5658
Max	.8573	.8745	.7545	.8573	.7716	.823	.9602
Min	.6173	.5316	.4801	.463	.1029	.4801	.5487
Avg	.7059	.6730	.6237	.6318	.5548	.6239	.6762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 201 / 11 KV SANGRUL VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.415	.3961	.415	.415	.3206	.3961
2	.3584	.415	.3961	.3772	.3961	.3206	.3772
3	.3584	.415	.3961	.3584	.3772	.3206	.3772
4	.3584	.4338	.4338	.3395	.3772	.3395	.415
5	.4854	.4904	.4715	.3772	.5228	.4527	.4527
6	.6348	.679	.6979	.6413	.6653	.6535	.6908
7	.6468	.6348	.6348	.6161	.6653	.6161	.6468
8	.5729	.5975	.5487	.6036	.5304	.5415	.5611
9	.5121	.5415	.5304	.5316	.4938	.5544	.5194
10		.5375	.5121	.5014	.4835	.5014	.5249
11		.5373	.5249	.5249	.4477	.5373	.4938
12		.4835	.5014	.5487	.4887	.5373	.5853
13	.6584	.5014	.5194	.4656	.4024	.5014	.5853
14	.6154	.5373	.5068	.5121	.4066	.5194	.5068
15	.5973	.4706	.4887	.5068	.4435	.4656	.543
16	.5731	.543	.4961	.5611	.4572	.5847	.5973
17	.6335	.5784	.5194	.567	.4938	.583	.6201
18	.7316	.6154	.5784	.6036	.6036	.6935	.6379
19	.8869	.8688	.7164	.7392	.7468	.8145	.8501
20	.9335	.8871	.8029	.8589	.8488	.8775	.9055
21		.7922	.7356	.7733	.811	.8299	.7842
22	.6979	.679	.6224	.6413	.6224	.7167	.6602
23	.5658	.5281	.5093	.4715	.4338	.547	.5093
24	.4715	.4527	.4338	.449	.415	.3772	.415
Max	.9335	.8871	.8029	.8589	.8488	.8775	.9055
Min	.3584	.415	.3961	.3395	.3772	.3206	.3772
Avg	.5835	.5681	.5405	.5410	.5228	.5502	.5690



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 202 / 11 KV KHATANGLE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6882	.6718	.502			
2		.7127	.6962	.4858			
3		.7209	.6962	.4858			
4		.7545	.7209	.5182			
5		.8048	.9389	.6554			
6		.9945	1.1271	1.0814			
7		1.6617	1.5581	1.7772			
8		2.0008	2.0287	1.9062			
9		1.7635	1.7939	1.8233			
10					1.4251	1.7974	1.5769
11					2.0622	2.5095	2.2977
12					2.34	2.6452	2.3663
13	2.1262				2.5095		2.4348
14	2.1704				2.3137	2.4587	
15	2.1534				2.4417	2.4587	2.1365
16	2.0576				2.4247	2.3472	2.2291
17	1.9839				2.2291	2.1125	1.933
18	1.21						
19	1.21						
24		.6299	.5735	.4744			
Max	2.1704	2.0008	2.0287	1.9062	2.5095	2.6452	2.4348
Min	1.21	.6299	.5735	.4744	1.4251	1.7974	1.5769
Avg	1.8445	1.0732	1.0805	.9710	2.2183	2.3327	2.1392

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL I DIVISION[504]

PHULEWADI[040] BU 6181

Substation No/ Name :- 144110 / 33/11KV BOLOLI S.ST

Feeder No / Name : 203 / 11 KV UPWADE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191				.6443	.583	.4287
2	.0191				.6443	.5935	.4287
3	.0191				.6613	.5935	.3561
4	.0191				.6613	.6104	.407
5	.0191				.6783	.6952	.4854
6	.0191				.6783	.703	.6783
7	.0191				.78	.9326	.8886
8	.0191				.8478	1.0682	.9221
9	.0191				.6706	.9156	.0671
10				.6613			
11				1.0513			
12		1.2887	1.2071	1.1022			
13		1.2717	1.1904	1.1022			
14		1.2548	1.1869	1.0004			
15		1.2039	1.2209	.9665			
16		1.1401	1.1568	.9665			
17		1.073	1.1233	.9221			
18		1.0513	1.0898				
19		.8817	.9389				
24	.0191				.5935	.4973	.4287
Max	.0191	1.2887	1.2209	1.1022	.8478	1.0682	.9221
Min	.0191	.8817	.9389	.6613	.5935	.4973	.0671
Avg	.0191	1.1457	1.1393	.9716	.6860	.7192	.5091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 202 / 11 KV SHENAGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	1.3527	1.2765	1.1431	.1143	.1143	.1143
2	.1143	1.3527	1.2955	1.1431	.1143	.1143	.1143
3	.1143	1.3336	1.3146	1.1241	.1143	.1143	.1143
4	.1143	1.5242	1.3336	1.1431	.1143	.1143	.1143
5	.1143	1.6194	1.7147	1.5432	.1143	.1143	.1143
6	.1143	1.9052	2.0386	1.829	.1143	.1143	.1143
7	.1143	2.3624	2.6482	2.4387	.1143	.1143	.1143
8	.1143	2.5149	2.7244	2.553	.1143	.1143	.1143
9	.1143	2.2862	2.5339	2.2862	.1143	.1143	.1143
10	3.0674	.0191	.1143	.1143	2.6673	2.7435	2.8006
11	3.8104	.0191	.1143	.1143	3.2769	3.3722	3.6008
12	3.5818	.0191	.1143	.0953	3.3532	3.5246	3.6199
13	3.3532	.0191	.1143	.0953	3.2388	3.5246	3.4675
14	3.2007	.0191	.1143	.0953	3.2007	3.5246	3.4675
15	3.1245	.0191	.1143	.0953	3.0483	3.2769	3.4294
16	2.9721	.0191	.1143	.0953	3.2769	3.3722	3.2579
17	2.5911	.0191	.0762	.0953	3.0483	3.1436	3.0102
18	.0953	.0191	.0762	.1143	.1143	.1143	.1143
19	.0953	.0191	.0762	.1143	.1143	.1143	.1143
20	.0953	.0191	.0762	.1143	.1143	.1143	.1143
21	.0953	.0191	.0762	.1143	.1143	.1143	.1143
22	.0953	.0191	.0953	.1143	.1143	.1143	.1143
23	.0953	.0191	.0953	.1143	.1143	.1143	.1143
24	.1143	1.3717	1.2765	1.2384	.1143	.1143	.1143
Max	3.8104	2.5149	2.7244	2.553	3.3532	3.5246	3.6199
Min	.0953	.0191	.0762	.0953	.1143	.1143	.1143
Avg	1.1423	.7454	.8137	.7470	1.1225	1.1796	1.1868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 203 / 11 KV PIMPALGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621		.6668	.6668	.6668	.7049	.724
2	.724	.6668	.6668	.6668	.6478	.7049	.7049
3	.7049	.6668	.6668	.6668	.6478	.7049	.7049
4	.7049	.6668	.6478	.6859	.6478	.7049	.7049
5	.7049	.6859	.724	.6859	.6478	.724	.724
6	.8002	.7621	.7811	.7049	.7049	.7621	.8002
7	.724	.743	.7621	.724	.7049	.7621	.8002
8	.7811	.7621	.724	.7621	.6859	.724	.6859
9	.7621	.7049	.7049	.724	.6478	.6668	.724
10	.8192	.6859	.7621	.7811	.6668	.7621	.7621
11	.8383	.7621	.7621	.7811	.7621	.7811	.7621
12	.7621	.7811	.7621	.7621	.7621	.8383	.9145
13	.8383	.724	.7621	.7811	.8002	.8192	.8573
14	.8002	.7621	.7621	.7621	.7621	.8002	.8383
15	.8383	.7811	.7621	.743	.7621	.8002	.8002
16	.8383	.8002	.724	.8002	.7621	.7811	.8573
17	.8383	.8192	.7621	.8002	.7621	.9145	.9145
18	.9145	.8573	.7621	.8192	.7621	.9145	.9526
19	1.0669	1.0479	1.1622	1.1812	1.1241	1.2574	1.0479
20	1.1431	1.0669	1.086	1.2003	1.1622	1.2193	1.0669
21	1.0669	1.0479	1.0098	1.0669	1.0669	1.1241	1.086
22	.9907	.9907	.9907	.9907	1.0288	1.0288	1.086
23	.7621	.8954	.7621	.8573	.8192	.9335	1.0479
24	.7811	.7049	.6859	.724	.724		.7621
Max	1.1431	1.0669	1.1622	1.2003	1.1622	1.2574	1.086
Min	.7049	.6668	.6478	.6668	.6478	.6668	.6859
Avg	.8319	.7994	.7859	.8057	.7804	.8449	.8470

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 204 / 11 KV MADILAGE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.381	.3429	.3429	.362	.362
2		.3239	.362	.3239	.3239	.362	.362
3	.3429	.3239	.362	.3239	.3239	.362	.362
4	.381	.3429	.381	.3429	.3429	.362	.381
5	.4191	.362	.4191	.362	.381	.381	.4191
6	.4382	.4382	.4763	.4001	.4191	.4382	.4763
7	.4191	.4001	.4001	.4001	.362	.4191	.4001
8	.362	.362	.362	.4191	.362	.4191	.362
9	.4001	.381	.381	.362	.3048	.362	.3429
10	.3048	.4001	.381	.362	.3048	.3429	.3048
11	.362	.3429	.4001	.362	.3239	.362	.362
12	.3048	.362	.4001	.381		.4001	.381
13	.3429	.362	.3429	.362		.4001	.381
14	.3239	.362	.4001	.362		.381	.362
15	.362	.4001	.4001	.381		.381	.381
16	.4191	.4191	.381	.4001		.4382	.362
17	.4382	.4763	.4191	.4382		.4954	.4001
18	.4191	.4572	.4191	.4001		.4572	.4382
19	.5906	.5906	.6097	.6097		.6097	.5525
20	.5906	.6287	.5906	.6097	.6097	.6287	.5716
21	.5525	.5716	.5525	.5716	.5716	.5716	
22	.5144	.5144	.5335	.5335	.5335	.5335	.5144
23	.4191	.4763	.4191	.4382	.4572	.4382	.4382
24	.381	.3429	.381	.381	.381	.381	.4001
Max	.5906	.6287	.6097	.6097	.6097	.6287	.5716
Min	.3048	.3239	.3429	.3239	.3048	.3429	.3048
Avg	.4100	.4152	.4231	.4112	.3965	.4287	.4051

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 205 / 11 KV GARGOTI PWW EXPRESS NON SHEDDABLE WATER SUPPLY AND  
Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.0572	.0572	.0572	.0572	.0572	.0572
2	.0572	.0572	.0572	.0572	.0572	.0572	.0572
3	.0572	.0572	.0572	.0572	.0572	.0572	.0572
4	.0572	.0572	.0572	.0572	.0572	.0572	.0572
5	.0572	.0572	.0572	.0572	.0572	.0572	.0572
6	.0572	.0572	.0572	.0572	.0572	.0572	.0572
7	.0572	.0572	.0572	.0572	.0572	.0572	.0572
8	.0572	.0572	.0572	.0572	.0572	.0572	.0572
9	.0572	.0572	.0572	.0572	.0572	.0572	.0572
10	.0572	.0572	.0572	.0572	.0572	.0572	.0572
11	.0572	.0572	.0572	.0572	.0572	.0572	.0572
12	.0572	.0572	.0572	.0572	.0572	.0572	.0572
13	.0572	.0572	.0572	.0572	.0572	.0572	.0572
14	.0572	.0572	.0572	.0572	.0572	.0572	.0572
15	.0572	.0572	.0572	.0572	.0572	.0572	.0572
16	.0572	.0572	.0572	.0572	.0572	.0572	.0572
17	.0572	.0572	.0572	.0572	.0572	.0572	.0572
18	.0572	.0572	.0572	.0572	.0572	.0572	.0572
19	.0572	.0572	.0572	.0572	.0572	.0572	.0572
20	.0572	.0572	.0572	.0572	.0572	.0572	.0572
21	.0572	.0572	.0572	.0572	.0572	.0572	.0572
22	.0572	.0572	.0572	.0572	.0572	.0572	.0572
23	.0572	.0572	.0572	.0572	.0572	.0572	
24	.0572		.0572	.0572	.0572	.0572	.0572
Max	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0572	.0572	.0572	.0572	.0572	.0572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 206 / 11 KV PIMPALGAON AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.2096	.2667	.2477	.0381	.0191	.0381
2	.0191	.2096	.2667	.2477	.0381	.0191	.0381
3	.0191	.2096	.2858	.2477	.0381	.0191	.0381
4	.0191	.1905	.2858	.2667	.0381	.0191	.0381
5	.0191	.1905	.2477	.3239	.0381	.0191	.0381
6	.0191	.2477	.2286	.3239	.0381	.0191	.0381
7	.0191	.362	.2858	.4001	.0381	.0191	.0381
8	.0191	.4382	.3239	.4191	.0381	.0191	.0381
9	.0191	.362	.3048	.3239	.0381	.0191	.0381
10	.3429	.0191	.0381	.0381	.2858	.381	.2858
11	.3429	.0191	.0381	.0381	.2858	.4001	.2286
12	.3429	.0191	.0381	.0381	.2858	.3429	.3239
13	.3429	.0191	.0381	.0381	.2858	.3429	.3429
14	.3239	.0191	.0381	.0381	.3239	.3239	.3429
15	.362	.0191	.0381	.0381	.3239	.3239	.362
16	.362	.0191	.0381	.0381		.3239	.381
17	.3429	.0191	.0381	.0381	.3429	.3239	.362
18	.0191	.0191	.0381	.0381	.0191	.0381	.0191
19	.0191	.0191	.0381	.0381	.0191	.0381	.0191
20	.0191	.0191	.0381	.0381	.0191	.0381	.0191
21	.0191	.0191	.0381	.0381	.0191	.0191	.0191
22	.0191	.0191	.0381	.0381	.0191	.0191	.0191
23	.0191	.0191	.0381	.0381	.0191	.0191	.0191
24	.0191	.2096		.2858	.0381	.0191	.0381
Max	.362	.4382	.3239	.4191	.3429	.4001	.381
Min	.0191	.0191	.0381	.0381	.0191	.0191	.0191
Avg	.1278	.1207	.1317	.1508	.1143	.1302	.1302

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 207 / 11 KV GANGAPUR AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	.1905	.2096	.2096	1.3717	1.4289	1.4289
2	1.4289	.1905	.2096	.2096	1.5242	1.4861	1.4861
3	1.4861	.1905	.2096	.2096	1.5242		1.4861
4	1.5242	.1905	.2096	.2096	1.5623	1.5623	1.4861
5	1.5813	.1905	.2096	.2096	1.7528	1.7909	1.5242
6	1.9814	.1905	.2096	.2096	1.9052	1.9052	1.6766
7	2.5911		.2096	.2096	2.5149	2.7054	2.2481
8	2.6673	.1905	.2096	.1905	2.9531	3.0674	2.6673
9	2.4006	.1905	.2286	.1905	2.6101	2.6673	2.3243
10	.3239	2.3053	3.0674	2.0767	.2096	.1905	.1715
11	.3048	2.8959	3.2007	3.3532	.2096	.1905	.1715
12	.3048	2.8197	2.7625	3.3722		.1905	.1715
13	.3048	2.7435	3.0483	2.21		.1905	.1715
14	.3048	3.5056	3.2388	2.9721		.1905	.1715
15	.3048	3.3722	3.1626	2.9531		.1905	.1715
16	.3048	3.3913	3.1626	3.0483		.1905	.1715
17	.3048	3.3722	3.0102	3.0483		.1905	.1715
18	.3048	.2286	.2096	.2096		.1715	.1715
19	.3239	.2286	.2096	.1715	.1905	.1715	.1715
20	.3239	.2286	.1905	.1715	.1905	.1524	.1715
21	.3239	.2286	.2096	.1715	.1905	.1524	.1715
22		.2286	.2096	.1905	.1905	.1524	.1715
23	.3239	.2286	.2096	.1715	.1905	.1524	.1715
24	1.3527	.3239	.2096	.2096	1.2955	1.2574	1.2384
Max	2.6673	3.5056	3.2388	3.3722	2.9531	3.0674	2.6673
Min	.3048	.1905	.1905	.1715	.1905	.1524	.1715
Avg	.9783	1.2011	1.1669	1.0907	1.1992	.8847	.8320



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 208 / 11 KV DARWAD AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0191	.0191	.0191	.0191	.1905	.1524	.1715
2	.0191	.0191	.0191	.0191	.2286	.1715	.1715
3	.0191	.0191	.0191	.0191	.2286	.1715	.1715
4	.0191	.0191	.0191	.0191	.2286	.1905	.1905
5	.0191	.0191	.0191	.0191	.2667	.2286	.2286
6	.0191	.0191	.0191	.0191	.2858	.3048	.2858
7	.0191	.0191	.0191	.0191	.4382	.4763	.362
8	.0191	.0191	.0191	.0191	.4382	.4954	.4191
9	.0191	.0191	.0191	.0191	.4001	.362	.4001
10	.6668	.7811	.0191	.6287	.0191	.0191	.0191
11	.7621	.743	.7049	.7621	.0191	.0191	.0191
12	.8002	.724	.724	.743	.0191	.0191	.0191
13	.8192	.8192	.8192	.6859	.0191	.0191	.0191
14	.7811	.7621	.7811	.6478	.0191	.0191	.0191
15	.7621	.724	.7621	.6859	.0191	.0191	.0191
16	.724	.724	.743	.6287	.0191	.0191	.0191
17	.6859	.6668	.724	.6097		.0191	.0191
18	.0191	.0191	.0191	.0191		.0191	.0191
19	.0191	.0191	.0191	.0191		.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191	.0191	.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.0191	.0191	.0191	.0191	.1715	.1524	.1715
Max	.8192	.8192	.8192	.7621	.4382	.4954	.4191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2628	.2604	.2326	.2374	.1470	.1239	.1183

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144021 / 33/11KV GARGOTI SUBSTATION

Feeder No / Name : 209 / 11KV MADUR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.3429	.3048	.3048	.3048	.2858	.2858
2	.3048	.3429	.2858	.3048	.3048	.2858	.2858
3	.3048	.3239	.2858	.3048	.3048	.2858	.2858
4	.3048	.3429	.3239	.3048	.3048	.3048	.3239
5	.381	.381	.3429	.3239	.3429	.3048	.3429
6	.4382	.4382	.381	.4191	.4191	.4382	.4191
7	.4572	.4572	.381	.4572	.4572	.4572	.4382
8	.4572	.4572	.381	.4001	.381	.4382	.4191
9	.4191	.4191	.381	.4001	.4191	.381	.362
10	.4001	.381	.4001	.381	.381	.4001	.362
11	.4191	.381	.381	.381	.3429	.381	.3429
12	.4382	.381	.4191	.3429	.3429	.3429	.3239
13	.4191	.3048	.3048	.3429	.3429	.3429	.3048
14	.4001	.381	.381	.4191	.3429	.362	.3048
15	.381	.3048	.381	.381	.3429	.4191	.3048
16	.4001	.3048	.4382	.4191	.362	.4191	.3048
17	.4191	.381	.4382	.4763	.3429	.4191	.3048
18	.4763	.4001	.4954	.4763	.4001	.4191	.381
19	.5335	.5906	.6668	.5716	.5716	.5906	.5335
20	.6478	.6287	.6287	.6478	.6287	.6097	.5716
21	.5906	.5716	.5335	.5525	.5906	.5906	.5716
22	.5335	.4763	.4572	.4763	.5335	.5144	.5525
23	.4001	.381	.4191	.381	.4572	.4001	.4001
24	.3429	.3429	.3239	.3048	.3239	.3239	.3239
Max	.6478	.6287	.6668	.6478	.6287	.6097	.5716
Min	.3048	.3048	.2858	.3048	.3048	.2858	.2858
Avg	.4239	.4048	.4056	.4072	.3977	.4048	.3771

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 201 / 11 KV MANGNOOR AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.358		.0019	.0075	1.1949	1.3203	1.1706
2	1.3203		.0019	.0075	1.1576	1.3203	1.1088
3	1.3203		.0019	.0075	1.1576	1.3203	1.1088
4	1.358		.0019	.0075	1.2323	1.358	1.1458
5	1.4335		.0019	.0075	1.307	1.5089	1.2567
6	1.5278		.0019	.0075	1.3817	1.5089	1.39
7	1.8107		.0019	.0075	1.7177	1.7353	1.6461
8	1.9239		.0019	.0075	1.7177	1.9239	1.829
9	1.6787			.0075	1.6804	1.6787	1.6461
10		1.6598	1.4937	1.39	.0019		.0075
11		1.7924	1.6827	1.8298		.0075	
12		1.7177	1.6461	1.7177		.0075	
13		1.5684	1.5364	1.587		.0075	
14		1.4937	1.4998	1.531		.0075	
15		1.5684	1.5546	1.5684		.0075	
16		1.7177	1.6827	1.7177		.0075	
17		1.643	1.7193	1.7551		.0075	
18		.0019	.0075	.0019		.0075	
19		.0019	.0075	.0019		.0075	
20		.0019	.0075	.0019		.0075	
21		.0019	.0075	.0019		.0075	
22		.0019	.0075	.0019		.0075	
23		.0019	.0075	.0019		.0075	
24	1.358		.0019	.0075	1.1949	1.1694	1.2071
Max	1.9239	1.7924	1.7193	1.8298	1.7177	1.9239	1.829
Min	1.3203	.0019	.0019	.0019	.0019	.0075	.0075
Avg	1.5089	.9409	.5599	.5493	1.2494	.6496	1.2288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 202 / 11 KV ARALGUNDI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.9808	.8589	.8779	.0019		.0075
2		.9808	.7842	.8501	.0019		.0075
3		1.0185	.7842	.8501	.0019		.0075
4		1.0562	.8215	.7682	.0019		.0075
5		1.0562	.8215	.7682	.0019		.0075
6		1.0185	.8402	.7392	.0019		.0075
7		1.0562	1.1203	1.0974	.0019		.0075
8		1.358	1.1203	1.134	.0019		.0075
9		1.1694	1.0829	.961	.0019		.0075
10	2.037		.0019	.0075	2.2779	2.037	2.0119
11	2.1125	.0019	.0075	.0019	2.7915	2.9264	2.7073
12	2.1125		.0075	.0019	3.0556	3.0361	2.7446
13	1.8107		.0075	.0019	3.1687	2.9995	2.5206
14	1.5844		.0075	.0019	3.0247	2.9995	2.4646
15	1.5466		.0075	.0019	3.0178	2.963	2.2032
16	1.5278		.0075	.0019	2.9874	2.7435	1.8671
17	1.3203	.0019	.0075	.0019	3.0556	2.7069	1.8484
18		.0019	.0075	.0019		.0075	
19		.0019	.0075	.0019		.0075	
20		.0019	.0075	.0019		.0075	
21		.0019	.0075	.0019		.0075	
22		.0019	.0075	.0019		.0075	
23		.0019	.0075	.0019		.0075	
24		1.0185	.8962	.9145	.0019		.0075
Max	2.1125	1.358	1.1203	1.134	3.1687	3.0361	2.7446
Min	1.3203	.0019	.0019	.0019	.0019	.0075	.0075
Avg	1.7565	.5960	.3846	.3747	1.2999	1.6041	1.0246

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 203 / 11 KV ARALGUNDI VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0943	.0754	.0754	.0934	.0754	.0943	.112
2	.0754	.0754	.0747	.0747	.0754	.0754	.0943
3	.0754	.0754	.0754	.0754	.0754	.0754	.0747
4	.0566	.0754	.0754	.0747	.0754	.0754	.0754
5	.0754	.0943	.0943	.0747	.0943	.0943	.0934
6	.1132	.1132	.1132	.0934	.1132	.1132	.0934
7	.132	.1509	.132	.0934	.1132	.1132	.112
8	.1132	.1132	.1132	.112	.132	.1132	.1307
9	.1132	.1132	.1132	.112	.1132	.1509	.1307
10	.132	.1509	.1132	.112	.132	.1494	.1494
11	.132	.132	.112	.1509	.1132	.1307	.1307
12	.1132	.1307	.0934	.1132	.1132	.1307	.112
13	.1132	.0934	.0934	.132	.1132	.1494	.112
14	.0943	.0747	.0934	.1132	.0747	.1494	.112
15	.1509	.0747	.0934	.1132	.1132	.1494	.112
16	.1509	.112	.112	.132	.112	.1494	.112
17	.1509	.132	.112	.1509	.0943	.1307	.112
18	.132	.1509	.112	.132	.0943	.1494	.1307
19	.132	.1886	.1494	.168	.1509	.1867	.1867
20	.2075	.1886	.2241	.2263	.1698	.2241	.2054
21	.1509	.1509	.168	.1886	.1698	.1867	.1494
22	.132	.132	.1494	.1509	.1509	.1494	.1494
23	.1132	.1132	.112	.1132	.1132	.1494	.112
24	.1132	.0943	.0943	.0943	.0943	.1132	.1132
Max	.2075	.1886	.2241	.2263	.1698	.2241	.2054
Min	.0566	.0747	.0747	.0747	.0747	.0754	.0747
Avg	.1195	.1169	.1125	.1206	.1115	.1335	.1215

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144022 / 33/11KV PIMPALGAON S/S

Feeder No / Name : 205 / 11 KV BARVE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.132	.1509	.1509	.1307	.132	.1509	.1307
2	.1132	.132	.132	.1307	.1132	.132	.132
3	.0943	.132	.132	.112	.1132	.1132	.112
4	.0943	.132	.132	.1307	.1132	.1132	.1307
5	.132	.132	.1509	.1494	.132	.1509	.1494
6	.2075	.1509	.1886	.168	.1698	.2075	.1867
7	.1698	.1886	.2075	.2427	.1886	.2263	.1867
8	.2829	.3395	.2641	.2241	.2452	.2263	.2033
9		.3018	.2452	.2427	.2263	.2263	.2054
10		.3018	.2829	.2427	.2075	.2614	.1867
11	.3018	.2641	.2772	.2829	.1886	.2614	.2241
12	.3772	.2427	.2772	.2829	.0754	.2587	.1867
13	.3018	.2241	.2241	.1886	.1886	.2587	.1494
14	.0943	.1867	.1494	.1509	.0747	.2054	.112
15	.3018	.2241	.2241	.1698	.2452	.2614	.1867
16	.3018	.2241	.2587	.1886	.2054	.2241	.1307
17	.3018	.2452	.2801	.2452	.1698	.2614	.1307
18	.4338	.3018	.3142	.2452	.2641	.2614	.1867
19	.4338	.3584	.3326	.2641	.3772	.2587	.2427
20	.415	.3584	.3511	.3584	.415	.3696	.3734
21	.3395	.2829	.2957	.2641	.3772	.3174	.2987
22	.3018	.2641	.2427	.2452	.3018	.2427	.2614
23	.2263	.2075	.168	.1886	.1509	.2241	.2054
24	.1509	.1698	.1698	.1494	.1509	.1698	.1509
Max	.4338	.3584	.3511	.3584	.415	.3696	.3734
Min	.0943	.132	.132	.112	.0747	.1132	.112
Avg	.2503	.2298	.2271	.2082	.2011	.2243	.1860

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 202 / 11 KV MHASARANG AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686		2.6513	2.3045
2	.0543	2.7435	2.7073	2.3167
3	.0549	2.7801	2.8193	2.3777
4	.056	2.8349	3.0045	2.3777
5	.056	2.9264	3.1312	2.5606
6	.0747	3.1093	3.4208	2.7435
7	.0747	3.2922	3.5475	3.1093
8	.0747	3.0769	3.7647	3.8409
9	.0747	3.0247	2.8978	3.2922
10	4.0329	.056	.0747	.056
11		.0343		.056
12		.0362		.0549
13		.0362		.0549
14		.0362		.0549
15		.0362		.0549
16	4.0238	.0724	.0549	.0549
17	3.9323	.0724	.0554	.0549
18	.0549	.0747	.0554	.0549
19	.0549	.0739	.0554	.0549
20	.0549	.0934	.0554	.056
21	.0549	.0747	.0554	.0549
22	2.9264	.0747	.0554	.056
23	2.8349	.0747	.0554	.056
24	.0724	2.7435	2.5766	2.1948
Max	4.0329	3.2922	3.7647	3.8409
Min	.0543	.0343	.0549	.0549
Avg	.9806	1.1903	1.6336	1.1622

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 203 / 11 KV VENGRUL AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5206	2.2862	2.1845	2.0119
2	2.5953	2.2862	2.1538	2.0119
3	2.7073	2.3777	2.2081	2.0119
4	2.838	2.3777	2.2262	2.0119
5	2.9687	2.4691	2.2624	2.0119
6	3.0807	2.652	2.4086	2.0119
7	3.1367	2.7435	2.4646	2.4272
8	2.9313	2.2862	2.4434	2.6139
9	2.5206	2.1285	2.1357	2.3777
10	2.8567	2.3339	2.8959	
11	3.2114	2.7949	2.7949	
12	3.0178	1.2136	3.0769	
13	2.6337	1.2136	3.0045	
14	2.5606	2.6326	2.9995	
15	2.652	3.0994	3.0727	
16	2.7252	.8326	3.1093	
17	2.4691	.8688	3.0445	
18	.1829	.2801	.2926	.1829
19	.1829	.3174	.3142	.1829
20	.1829	.2801	.2427	.2195
21	.1829	.2801	.2427	.2195
22	.1829	.2614	.2241	.2195
23	.1829	.2172	.1867	.2195
24	2.2291	2.1948	2.1285	2.0119
Max	3.2114	3.0994	3.1093	2.6139
Min	.1829	.2172	.1867	.1829
Avg	2.1147	1.6845	2.0049	1.4216



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 204 / 11 KV DONAWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7842	.0366	.0362	.0554
2	.7783	.0366	.0362	.0554
3	.8589	.0366	.0362	.0554
4	.9335	.0366	.0362	.0554
5	.9896	.0366	.0362	.0554
6	1.0349	.0366	.0543	.0554
7	1.1016	.0549	.0543	.0549
8	1.2136	.0366	.0362	.0549
9	1.1016	.056	.0514	.056
10	.0373	1.0642	1.2127	1.2071
11	.0373	1.2323	1.475	1.4815
12	.0366	1.3256	1.4685	1.4449
13	.0366	1.3443	1.4045	1.3717
14	.0366	1.3443	1.4083	1.3169
15	.0366	1.2489	1.39	1.2071
16	.0366	1.251	1.3535	1.3169
17	.0366	1.1041	1.2936	1.2803
18	.0366	.0373	.037	.0366
19	.0366	.056	.0554	.0366
20		.056	.0554	.0549
21	.0366	.056	.0554	.0549
22	.0366	.056	.0554	.0366
23	.0366	.0373	.0554	.0366
24	.724	.0366	.0373	
Max	1.2136	1.3443	1.475	1.4815
Min	.0366	.0366	.0362	.0366
Avg	.4347	.4424	.4889	.4948

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 205 / 11 KV SHELOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3547		.3361	.3326
2	.3361		.3258	.3142
3	.3361		.3439	
4	.3547		.3547	.2957
5	.3734		.362	
6	.3921		.3921	.3658
7	.4108		.3921	.4024
8	.4108	.3658	.4668	.4024
9	.3734	.4854	.4854	.3841
10	.3734	.3361	.4163	.4108
11		.362	.4481	.3547
12	.3658	.3734	.4207	.3658
13	.3658	.3921	.4066	.3734
14	.3772	.4668	.3658	.2926
15	.3658	.3734	.4024	.2926
16	.3658	.4481	.4024	.3658
17	.3658	.3734	.3658	.439
18	.439	.4294	.3696	.3658
19	.5121	.5415	.4755	.5487
20	.5487	.5228	.6283	.6348
21	.4755	.5041	.5487	.5228
22		.4668	.4755	.439
23	.439	.4108	.3696	.4024
24	.3658		.3734	.3475
Max	.5487	.5415	.6283	.6348
Min	.3361	.3361	.3258	.2926
Avg	.3955	.4282	.4137	.3933

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 206 / 11 KV KARADWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.1097	.112	.1294
2	.112	.1097	.112	.1109
3	.112	.0914	.0934	.1109
4	.1307	.0914	.112	.1294
5	.1307	.1097	.1494	.1478
6	.168	.1463	.168	.1646
7	.1867	.2195	.2054	.1646
8	.1867	.1829	.1867	.1646
9	.168	.1494	.2241	.1463
10	.168	.168	.12	.1829
11	.1307	.1494	.1494	.128
12	.128	.112	.1109	.1097
13	.1463	.112	.1109	.1063
14	.1867	.1509	.1294	
15	.1829	.1307	.1294	.1463
16	.1463	.1307	.1478	.1829
17	.1463	.168	.1463	.1097
18	.1463	.1494	.2195	.1494
19	.2263	.2614	.2195	.2241
20	.3109	.3361	.3658	.3361
21	.2926	.2987	.3292	.2987
22	.2561	.2241	.2195	.2614
23	.1463	.1867	.1663	.1494
24	.112	.128	.1494	.128
Max	.3109	.3361	.3658	.3361
Min	.112	.0914	.0934	.1063
Avg	.1680	.1632	.1698	.1644

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144023 / 33/11 KV KADGAON SUBSTATION

Feeder No / Name : 207 / 11 KV NANDOLI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1307	.1097	.1307	.1109
2	.1307	.0914	.112	.1109
3	.1494	.0914	.1307	.1109
4	.168	.1097	.1494	.1109
5	.168	.1097	.168	.128
6	.1867	.128	.168	.1294
7	.2054	.1448	.1867	.1307
8	.2054	.1463	.1867	.1307
9	.1867	.1867	.1867	.1494
10	.1867	.1867	.181	.1867
11		.0514	.2241	.1307
12	.1829	.0747	.1463	.1494
13	.2012	.0566	.1294	.1307
14	.128	.0566	.1294	.168
15		.056	.1294	.1629
16	.1463	.2241	.1294	.1867
17	.1829	.2427	.1829	
18	.2195	.2054	.1463	.1494
19	.2195	.2801	.1829	.2241
20	.2378	.2987	.2033	.2801
21	.2195	.2801	.1848	.2054
22	.1829	.2241	.1663	.1867
23	.1463		.1478	.1494
24	.1463	.128	.1494	.1097
Max	.2378	.2987	.2241	.2801
Min	.128	.0514	.112	.1097
Avg	.1787	.1514	.1605	.1536

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 201 / 11 KV MINCHE GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.3239	.3226	.3239	.2858	.2858	.3042
2	.2858	.2858	.3042	.2667	.2477	.2667	.2662
3	.2858	.3048	.3039	.2667	.2477	.2667	.2662
4	.3048	.3239	.3042	.362	.2858	.2858	.2659
5	.381	.362	.3613	.381	.3429	.3429	.3423
6	.381	.4001	.4175	.4382	.381	.4001	.4175
7	.4191	.4191	.455	.4572	.4382	.4572	.4554
8	.4382	.4382	.455	.4572		.4572	.4183
9	.362	.4191	.4373	.4572	.4001	.4572	.3613
10	.381	.4179	.4191	.4382	.4191	.4183	.381
11	.381	.3993	.4191	.4382	.4382	.4183	.3239
12	.3239	.3795	.3429	.4001	.362	.3799	.381
13	.3048	.3039	.3429	.3048		.2092	.3429
14	.3429	.3613	.3429	.3048	.3239	.3229	.362
15	.4191		.3429	.2858	.4191	.3993	.362
16	.4382		.362	.3239	.4572	.3613	.3429
17	.4191	.1898	.381	.362	.362		.4191
18	.4763	.5118	.381	.4382	.4191	.5324	.2858
19	.743	.7962	.8383	.6287	.7621	.5509	.724
20	.743	.7499	.724	.6478	.743	.6642	.7621
21	.6859	.6642	.6859	.6287	.6478	.5704	.6097
22	.5525	.5497	.4954	.4954	.4954	.4944	.5525
23	.4001	.3993	.4382	.381	.362	.4183	.4001
24	.381	.3429	.3423	.3239	.3239	.3239	.3547
Max	.743	.7962	.8383	.6478	.7621	.6642	.7621
Min	.2858	.1898	.3039	.2667	.2477	.2092	.2659
Avg	.4247	.4247	.4258	.4088	.4165	.4036	.4042

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 203 / 11 KV NILPAN AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1715	1.1812	1.2644	.9877	.1334	.1524	.1901
2	.1715	1.1622	1.2323	.9694	.1334	.1334	.1901
3	.1715	1.1431	1.2145	1.0242	.1334	.1334	.1901
4	.1715	1.105	1.2169	1.7741	.1334	.1334	.1901
5	.1905	1.2384	1.4232	1.9936	.1334	.1524	.1901
6	.0191	1.6575	1.8595	2.0119	.1524	.1524	.1896
7	.2286	2.191	2.3767	2.1582	.1715	.1524	.2092
8	.2286	2.4196	2.5592	2.2672		.2096	.2282
9	.2286	2.0576	2.1098	2.1529	.2096	.2096	.2279
10	2.3434	.2092		.1905	2.1338	2.3696	2.3053
11	2.6292	.1901	.1829	.1715	2.7625	2.7051	2.9721
12	2.5149	.2092	.2012	.1715	3.0102	2.959	3.0102
13	2.553	.2092	.2012		2.8959	2.9493	2.8197
14	2.2672	.2085	.2012		2.8959	2.6219	2.9531
15	2.2291		.2012		2.8769		2.8006
16	2.21		.2012		2.7435	2.7135	2.6292
17	2.0767	.2054	.2012		2.191		2.4387
18	.2286	.2282	.2012	.0381	.1905		.1905
19	.1715	.2092	.2012	.1715	.1715	.1901	.2096
20	.1715	.1901	.1646	.1524	.1715	.2092	.1905
21	.1905	.1901	.1463	.1524	.1715	.2085	.1905
22	.1905	.1901	.1463	.1334	.1524	.1899	.1905
23	.1715	.1521	.1463	.1334	.1524	.1901	.1715
24	.1715	1.2003	1.2361	.9877	.1334	.1524	.1898
Max	2.6292	2.4196	2.5592	2.2672	3.0102	2.959	3.0102
Min	.0191	.1521	.1463	.0381	.1334	.1334	.1715
Avg	.9042	.8067	.8212	.9285	1.0371	.8994	1.0445

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144082 / 33/11 KV DARWAD SUBSTATION

Feeder No / Name : 402 / 33 KV Shriram LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0572	.1141	.0572		.0572	.1141
2		.0572	.1141	.1143		.0572	.1141
3		.0572	.1141	.1143		.0572	.1141
4		.0572	.1141	.1143		.0572	.1141
5		.0572	.1139	.1143		.0572	.1107
6		.0572	.1141	.1143		.0572	.1141
7		.0572	.1141	.1143		.0572	.1141
8		.0572	.1141	.0572		.0572	
9	.0572	.0572	.1139	.0572		.0572	.1141
10	.0572		.1143	.0572		.1141	.0572
11	.0572		.1143	.0572		.1141	.0572
12	.0572	.1139	.1143	.0572		.1141	.0572
13	.0572	.114	.1143	.0572		.1139	.0572
14	.0572		.1143	.0572			.0572
22	.0572						
23	.0572		.0572		.0572	.1141	.0572
24		.0572	.114	.0572		.0572	.1141
Max	.0572	.114	.1143	.1143	.0572	.1141	.1141
Min	.0572	.0572	.0572	.0572	.0572	.0572	.0572
Avg	.0572	.0667	.1106	.0800	.0572	.0762	.0911

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 201 / 11 KV DASEWADI AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5023	.1143	.1448	.1524	1.6194	1.6004	1.3717
2	1.5546	.1143	.1433	.1334	1.6575	1.5242	1.4289
3	1.6461	.1143	.1433	.1334	1.6575	1.5242	1.4289
4	1.7177	.1143	.1433	.1334	1.7528	1.5242	1.6766
5	1.8298	.1143	.1417	.1334	1.8099	1.6194	1.7909
6	1.9978	.1143	.1417	.1334	1.8861	1.7337	1.8099
7	1.9605	.1143	.1663	.1334	1.9814	1.9814	1.8861
8	1.8671	.1334	.1494	.1334	2.1338	2.0195	2.1719
9	1.7164	.1334	.1698	.1715	2.0005	1.9814	1.9052
10	.132	1.9814	1.9765	2.2672	.1524	.1334	.1715
11	.1524	2.1845	2.3434	2.553	.1334	.1905	.1698
12	.1334	2.1125		2.4958		.1905	.1886
13	.1334	2.0182		2.3434		.1905	.1698
14	.1334	2.0165	2.0957	2.0957		.1715	.1509
15	.1334	1.8298	2.3624			.1715	.1509
16	.1334	1.8781	2.3243			.1715	.1509
17	.1334	1.9136	2.3053	2.0005		.1715	2.037
18	.1334	.1753	2.1719	.1905	.1334	.1715	.1578
19	.1334	.1595	.1715	.1905	.1334	.1715	.1478
20	.1334	.168	.1715	.1905	.1334	.1715	.168
21	.1334	.168	.1715	.1905	.1334	.1715	.1494
22	.1334	.1646	1.6004	1.6194	.1334	.1715	.1294
23	.1334	.1646		1.7718	.1334	.1715	.1267
24	1.448	.1334	.1629	.1524	1.6194	1.6004	1.2384
Max	1.9978	2.1845	2.3624	2.553	2.1338	2.0195	2.1719
Min	.132	.1143	.1417	.1334	.1334	.1334	.1267
Avg	.7969	.7556	.9143	.8781	1.0669	.8137	.8657



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 202 / 11 KV PATGAON VG.

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1267	.1143	.0905	.0953	.0953	.1143	.0953
2	.1097	.1143	.0905	.0953	.0953	.1143	.0953
3	.1097	.1143	.0895	.0953	.0953	.1143	.0953
4	.1307	.1143	.1075	.0953	.1143	.1143	.1143
5	.1494	.1715	.1417	.1143	.1524	.1524	.1524
6	.2054	.2096	.1949	.1524	.1905	.1715	.2286
7	.2241	.2477	.2402	.2286	.2477	.2477	.2667
8	.2427	.2667	.2772	.2667	.2667	.2667	.2667
9	.2641	.2667	.2801	.2286	.2667	.2667	.2667
10	.2452	.2667	.2561	.3239	.3239	.2667	.3048
11	.2858	.2452	.2477	.3239	.3239	.2858	.2452
12	.1905	.2033	.2286	.2667	.1905	.2667	.2263
13	.1905		.2286	.2477	.1524	.2286	.2075
14	.1905	.1867	.2096	.2477	.1524	.2477	.2263
15	.1905	.1848	.2096		.1905	.2286	.2075
16	.1905	.1772	.2096	.2667	.1905	.2286	.2263
17	.1905	.2103	.8192	.2858	.1905	.2286	.2263
18	.1905	.2303	.1334	.3239	.1905	.362	.2103
19	.362	.333	.3429	.381	.3239	.362	.3326
20	.4001	.3772	.4001	.362	.362	.381	.3734
21	.3429	.3734	.362	.362	.362	.381	.3361
22	.3239	.2926	.3048	.3048	.2667	.3429	.2772
23	.2477	.2172		.2286	.2096	.2667	.1991
24	.1629	.1524	.1629	.1524	.1524	.1334	.1524
Max	.4001	.3772	.8192	.381	.362	.381	.3734
Min	.1097	.1143	.0895	.0953	.0953	.1143	.0953
Avg	.2194	.2204	.2447	.2369	.2127	.2405	.2222

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044]

BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 203 / 11 KV SHIVDAV AG.

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1086	1.1812	1.1765	1.2384	.1143	.1143	.1143
2	.1097	1.1812	1.1765	1.3527	.1143	.1143	.1143
3	.1097	1.1812	1.1888	1.3527	.1143	.1143	.1143
4	.112	1.1812	1.267	1.3527	.1143	.1143	.1143
5	.112	1.2955	1.2403	1.5051	.1143	.1143	.1143
6	.112	1.5242	1.2757	1.6194	.1334	.1143	.1143
7	.112	1.7528	1.5708	1.7337	.1334	.1143	.1143
8	.112	1.7337	1.8484	1.7909	.1143	.1334	.1143
9	.0377	1.7337	1.8484	1.8099	.1143	.1334	.1334
10	1.7164		.0876	.0953	1.5432		1.5242
11	2.0195		.1143	.0953	2.0576	2.1719	1.9427
12	1.9052		.0762	.0953	2.0576	1.9814	1.9805
13	1.9814		.0953	.0953	2.0576	1.9814	1.9427
14	2.0005	.0373	.1334	.0953	1.9814	1.9433	1.9427
15	2.0005	.0187	.1143		1.9814	1.9433	1.9427
16	2.0576	.0175	.0953	.0762	1.9814	1.9814	1.9993
17	2.0957	.0175	.0953	.0953	1.9052	2.0195	2.037
18	.1334	.0175	.0953	.0953	.1334	.1334	.1052
19	.1334	.0177	.0953	.0953	.1334	.1334	.1109
20	.1334	.1307	.0953	.1143	.1334	.1334	.1307
21	.1334	.1132	.1334	.1143	.1334	.1334	.112
22	.1334	.1075	.1143	.1334	.1334	.1334	.1109
23	.1334	.1086		.1143	.1334	.1334	.1086
24	.1086	1.1431	1.1765	1.2765	.1143	.1143	.1143
Max	2.0957	1.7528	1.8484	1.8099	2.0576	2.1719	2.037
Min	.0377	.0175	.0762	.0762	.1143	.1143	.1052
Avg	.7338	.7247	.6571	.7107	.7311	.6958	.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

GARGOTI[044] BU 7137

Substation No/ Name :- 144094 / 33/11 KV TAMBALE SUBSTATION

Feeder No / Name : 402 / 33 KV PATGAON SHP  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.1143
Max	.1143
Min	.1143
Avg	.1143

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 201 / SILVER ZONE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.8573	.9036	.823	.7545	.815	.8916
2	.8573	.8573	.9036	.8059	.7545	.815	.8916
3	.8745	.8916	.8682	.8059	.7202	.7973	.8573
4	.8745	.8916	.8505	.8059	.7545	.815	.823
5	.8916	.9088	.8328	.8059	.7545	.815	.823
6	.9088	.9088	.8505	.7467	.7888	.8505	.8745
7	.9602	.9088	.8859	.7467	.7716	.8859	.9088
8	1.0288	.9088	.8682	.8116	.7545	.8505	.8441
9	1.046	1.166	1.1694	.9745	.7202	1.1317	.9415
10	1.7541	1.5432		1.6478	.7373	1.4232	1.3717
11	1.8073	1.7833	.0171	1.6655	.7373	1.5947	1.4575
12	1.7718	1.7318	.0171	1.4706	.7202	1.4918	1.5775
13	1.6301	1.4918	1.0117	1.3289		1.406	1.6804
14	1.5238	1.4122	1.0802	1.2403		1.3203	1.6804
15	1.7187	1.4122	1.0288	1.5592		1.2003	1.5775
16	1.3289	1.5583	1.2517	1.6832		1.2003	1.5432
17	1.5947	1.4122	1.4746	1.5061	.0343	1.0117	1.0974
18	1.2346	1.4284		.9214	.0171		1.1145
19	1.2003	1.5769	1.0226	.8928	.0354	1.1687	1.1145
20	1.2003	.9568	.7792	.9577	.7442	1.2174	.583
21	1.2003	1.1163	.7954	.8573	.7265	1.2003	1.0802
22	.8916	1.0808	.9774	.8059	.7796	1.2517	1.0288
23		.9922	.9602	.7716	.7796	1.3032	.9774
24	.823	.8573	.9391	1.6118	.7716	.7973	.8745
Max	1.8073	1.7833	1.4746	1.6832	.7888	1.5947	1.6804
Min	.823	.8573	.0171	.7467	.0171	.7973	.583
Avg	1.2150	1.1939	.8858	1.0936	.6428	1.1027	1.1089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 202 / HUPARI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.166	1.0288	1.0099	.9431	.9431	1.0277	1.046
2	1.1145	1.0288	.9391	.9088	.9088	.9568	.823
3	1.046	1.0288	.9036	.8916	.9259	.9036	.823
4	1.1203	1.0288	.8682	.8745	1.0288	.9214	.9431
5	1.0117	1.0288	.9391	.8745	1.0631	.9568	1.0117
6	1.0117	1.0288	1.0277	.8765	1.0117	1.0277	1.046
7	1.1145	1.046	1.0099	.909	1.046	1.134	1.0288
8	.9602	.9602	.9391	.8928	.9774	.9745	.9415
9	.9945	1.0974	.9568	1.0099	.9088	.9602	.9252
10	1.2226	1.1831	.9945	1.1694	1.0631	1.1145	1.3717
11	1.3289	1.406	1.0631	1.3998	1.2003	1.1488	1.406
12	1.4883	1.046	1.1145	1.3112	1.3203	1.406	1.5432
13	1.3466	1.4746	1.0288	1.3643		1.3889	1.5432
14	1.2403	1.2661	1.0802	1.1517		1.3375	1.3717
15	1.3112	1.2824	1.1145	1.2757		1.3032	1.3203
16	1.4175		1.0802	1.3466		1.3889	1.3717
17	1.3643	1.5096	.9945	1.3466	1.5261	1.406	1.4232
18	1.3546	1.4122		1.3289	1.4918		1.3546
19	1.3717	1.7896	1.331	1.4447	1.6832	1.5258	1.3546
20	1.3717	1.701	1.3148	1.4986	1.7187	1.3889	1.3717
21	1.3717	1.5061	1.2986	1.4403	1.5061	1.4403	1.3717
22	1.3717	1.2934	1.286	1.3032	1.4352	1.3889	1.3546
23		1.1871	1.0288	1.2003	1.3112	1.3203	1.3032
24	1.2346	1.0288	1.0985	1.0117	.9945	1.134	1.0974
Max	1.4883	1.7896	1.331	1.4986	1.7187	1.5258	1.5432
Min	.9602	.9602	.8682	.8745	.9088	.9036	.823
Avg	1.2320	1.2331	1.0618	1.1572	1.2032	1.1980	1.2145

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 203 / YALGUD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0686	.5144	.3768	.3429	.0343	.0343	.0171
2	.0686	.5144	.3768	.3601	.0343	.0343	.0171
3	.0857	.5144	.3932	.3772	.0171	.0343	.0171
4	.0686	.5144	.3932	.3772	.0171	.0343	.0171
5	.0686	.5144	.3932	.3772	.0171	.0343	.0171
6	.0514	.5144	.4096	.422	.0171	.0343	.0171
7	.0514	.5144	.5079		.0171	.0343	.0171
8	.0686	.5316	.5243	.5194	.0343	.0514	.0162
9	.0514	.5144	.4915	.5316	.0343	.0343	.0162
10	.5735	.0514	.0171	.0343	.5487	.5316	.7373
11	.6226	.0343	.0171	.0343	.6344	.7202	
12	.6226	.0343	.0171	.0514	.6859	.703	.6516
13	.6554	.0343	.0171			.7373	.6516
14	.6718	.0325	.0171			.7202	.6859
15	.6718	.0325	.0171			.703	.6859
16	.6554	.0325	.0343			.6859	.6859
17	.639	.0325	.0343		.6687	.6173	.6859
18	.0514	.0325			.0343		.6344
19	.0514	.0343	.0325	.0325	.0343	.0325	.0171
20	.0343	.0343	.0325	.0325	.0343	.0343	.0171
21	.0343	.0343	.0325	.0343	.0514	.0343	.0171
22	.0343	.0343	.0343	.0343	.0514	.0343	.0171
23		.0343	.0343	.0343	.0514	.0343	.0171
24	.0343	.4115	.3441	.0343	.0343	.0343	.0343
Max	.6718	.5316	.5243	.5316	.6859	.7373	.7373
Min	.0343	.0325	.0171	.0325	.0171	.0325	.0162
Avg	.2580	.2311	.1977	.2135	.1526	.2586	.2474

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 204 / RENDAL

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2003	1.0288	1.5947	1.5432	1.5432	1.7147	1.8861
2	1.2003	1.0288	1.4175	1.3717	1.3717	1.5947	1.5432
3	1.2003	1.0288	1.2803	1.2003	1.3717	1.448	1.2003
4	1.2003	1.0288	1.2803	1.2003	1.2003	1.2803	1.2003
5	1.2003	1.0288	1.4632	1.2003	1.3717	1.4632	1.3717
6	1.3717	1.0288	1.5947	1.2986	1.5432	1.5947	1.3717
7	1.6804	1.2003	1.5947	1.4609	1.7147	1.8442	1.7147
8	1.5432	1.2003	1.8652	1.9479	2.0576	2.1795	1.9479
9	1.5432	2.4006	2.7854	2.6216	2.7435	2.915	2.5972
10	1.6461	2.4006	3.0864	2.9492	3.0864	3.2579	3.0864
11	1.4632	2.915	3.0864	2.9492	3.0864	3.2579	3.2579
12	.9145	2.7435	2.915	2.9492	3.0864	3.0864	3.0864
13	1.0974	1.8861	1.3717	1.6766		1.8861	2.4006
14	1.2803	2.2725	1.7147	1.4175		2.2291	2.572
15	1.2803	2.4348	2.2291	2.4577		2.7435	2.572
16	1.0974	2.4348	.8573	2.9492		3.0864	3.0864
17	1.0974	2.8407	2.915	2.7854	1.0288	3.0864	3.0864
18	1.0288	2.2725		2.7854	2.0576		3.0864
19	1.0288	2.4863	2.5972	2.2725	2.4577	2.5972	2.915
20	1.0288	1.8442	1.9479	1.9479	2.2939	2.4006	2.7435
21	1.3717	1.8442	1.9479	1.8861	2.13	2.0576	2.572
22	1.5432	1.8652	2.0576	1.7147	2.0119	2.0576	2.4006
23		1.7147	1.8652	1.7147	2.0119	2.0576	2.0576
24	1.5432	1.3717	1.7147	1.7147	1.7147	1.8442	1.8861
Max	1.6804	2.915	3.0864	2.9492	3.0864	3.2579	3.2579
Min	.9145	1.0288	.8573	1.2003	1.0288	1.2803	1.2003
Avg	1.2853	1.8459	1.9644	2.0006	1.9942	2.2471	2.3184

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 207 / HUPARI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3546	.0343	.0514	.0514	1.4403	1.0631	1.3375
2	1.3717	.0686	.0514	.0514	1.869	1.1488	1.5604
3	1.4937	.0686	.0514	.0514	1.7833	1.166	1.5604
4	1.3889	.0686	.0514	.0514	1.6461	1.2346	1.6118
5	1.3717	.0686	.0514	.0514	1.6118	1.286	1.6461
6	1.3717	.0686	.0514	.0487	1.5947	1.5089	1.6804
7	1.406	.0686	.0686	.0487	1.6632	1.7147	1.6632
8	1.5261	.0686	.0514	.0487	1.6975	1.6289	1.6232
9	1.5775	.0686	.0343	.0514	1.6461	1.6804	1.607
10	.0343	1.6632	1.8861	1.286	.0343	.0343	.0171
11	.0343	2.0576	2.0233	1.749	.0343	.0343	.0171
12	.0343	1.9547	2.1091	1.6118	.0343	.0171	.0171
13	.0343	2.1434	2.0576	1.9033		.0171	.0171
14	.0343	2.0777	2.0748	2.0748		.0171	.0171
15	.0343	2.094	2.0233	2.0405		.0171	.0171
16	.0343	1.8829	1.9547	2.0748		.0171	.0171
17	.0343	1.8505	1.8347	1.7833	.0171	.0171	.0171
18	.0343	.0325		.0343	.0343		.0171
19	.0514	.0514	.0325	.0325	.0514	.0325	.0171
20	.0514	.0686	.0325	.0325	.0514	.0343	.0171
21	.0514	.0686	.0325	.0343	.0514	.0343	.0171
22	.0514	.0686	.0514	.0343	.0514	.0343	.0171
23		.0686	.0343	.0343	.0514	.0343	.0171
24	1.3546	.0343	.0514	.0343	1.1831	1.0288	1.3032
Max	1.5775	2.1434	2.1091	2.0748	1.869	1.7147	1.6804
Min	.0343	.0325	.0325	.0325	.0171	.0171	.0171
Avg	.6405	.6958	.7244	.6339	.8273	.6000	.6597



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144064 / 33/11 KV HUPARI

Feeder No / Name : 208 / BIRDEV AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.463	.0343	.0343	.0343	.6344	.6226	.3601
2	.4801	.0343	.0343	.0343	.6344	.6226	.3429
3	.5415	.0343	.0514	.0343	.6173	.6718	.4115
4	.5144	.0343	.0514	.0343	.6173	.6718	.4115
5	.5316	.0343	.0514	.0343	.6516		.4458
6	.5658	.0343	.0514	.0325	.6687	.7865	.4458
7	.583	.0343	.0343	.0325	.7202	.852	.4458
8	.7373	.0171	.0343	.0325	1.1317		.422
9	.7716	.0171	.0343	.0343	.7545		.422
10	.0171	.8916	.9431	.8684	.0514		.0171
11	.0171	1.0974	1.2003	1.0322	.0343		.0171
12	.0171	.9945	1.2883	1.065	.0343	.0343	.0171
13	.0171	1.0631	1.0974	.0492		.0343	.0171
14	.0171	1.0389	1.1488	1.0978		.0343	.0171
15	.0171	1.1038	1.1831	1.0978		.0343	.0171
16	.0171	.909	1.0288	1.1797		.0343	.0343
17	.0171	.9739	1.0631	1.0159	.0343	.0343	.0343
18	.0171	.0162		.0343	.0514		.0343
19	.0171	.0514	.0325	.0325	.0514	.0325	.0343
20	.0171	.0514	.0325	.0325	.0514	.0343	.0343
21	.0171	.0514	.0325	.0343	.0514	.0343	.0343
22	.0343	.0514	.0343	.0343	.0343	.0343	.0343
23		.0514	.0343	.0343	.0514	.0343	.0343
24	.463	.0343	.0343	.0343	.583	.6062	.3429
Max	.7716	1.1038	1.2883	1.1797	1.1317	.852	.4458
Min	.0171	.0162	.0325	.0325	.0343	.0325	.0171
Avg	.2561	.3606	.4144	.3311	.3729	.2894	.1845

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 201 / PATTANKODOLI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.6289	1.7661	1.8861	.0514	.0549	.0514
2	.0514	1.5604	1.7661	1.8176	.0514	.0549	.0514
3	.0514	1.5604	1.7661	1.8176	.0514	.0549	.0514
4	.0514	1.5604	1.7661	1.8176	.0686		.0514
5	.0514	1.6461	1.869	1.869	.0686	.0732	.0514
6	.0686	1.7661	2.0748	1.9376	.0686	.0732	.0514
7	.0514	2.0576	2.3148	2.1776	.0686	.0732	.0514
8	.0514	2.0919	2.2977	2.2291		.0732	.0514
9	.0514	2.1262	2.2462	2.2634		.0732	.0514
10	2.452		.0514	.0514		2.9447	
11	2.9492	.0343	.0343		2.572	2.0062	2.8045
12	2.9492	.0343	.0343	.0343	2.5892	2.0062	3.12
13	2.9492		.0343	.0343	2.572	1.989	2.857
14	2.9492	.0343		.0343	1.8861	1.989	2.8045
15	2.5377	.0343	.0343		1.8861	1.9719	
16	2.5377	.0343	.0343	.0343	1.8861	1.9719	2.5789
17	2.5377	.0343	.0343	.0686	1.7147	1.9719	2.561
18	.0343		.0343	.0686		.0343	.0537
19	.0514		.0686	.0686	.0724	.0514	.0716
20	.0686		.0686	.0686	.0732	.0514	.0716
21	.0686		.0686	.0686	.0732	.0514	.0716
22	.0686		.0686	.0514	.0549	.0514	.0724
23	.0686		.0686	.0514	.0549	.0514	.0724
24	.0514	1.5947	1.8176	1.869	.0514	.0549	.0514
Max	2.9492	2.1262	2.3148	2.2634	2.5892	2.9447	3.12
Min	.0343	.0343	.0343	.0343	.0514	.0343	.0514
Avg	.9481	1.1124	.8834	.9236	.7957	.7708	.8024

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 202 / 11 kV INGALI AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8916	.0343	.0343	.0343	1.2346	.5487	1.1145
2	.8916	.0343	.0343	.0343	1.2689	.9145	1.0802
3	.8916	.0343	.0343	.0343	1.1145	.9145	1.0631
4	.9259	.0343	.0343	.0343	1.166	1.0974	1.0631
5	.9945	.0343	.0343	.0343	1.2003	1.1888	1.1488
6	1.1317	.0514	.0343	.0343	1.2689	1.2803	1.3546
7	1.3546	.0343	.0343	.0343	1.3717	1.4632	1.3717
8	1.3375	.0343	.0343	.0343		1.6095	1.3717
9	1.3375	.0343	.0343	.0343		1.6095	1.3717
10	.0343	1.5432	1.6804	1.5775	.0343	.0543	
11	.0343	1.6289	1.6804	1.5775	.0343	.0171	.0362
12	.0343	1.5432	1.5432	1.5775	.0343	.0171	.0543
13	.0343	1.5432	1.5432	1.5432		.0171	.0543
14	.0343	1.6804		1.5089		.0171	.0543
15	.0343	1.6804	1.5089	1.5089	.0343	.0171	.0358
16		1.6804	1.5089	1.5089	.0343	.0171	.0362
17	.0343	1.6289	1.5089	1.5432	.0343	.0171	.0366
18	.0343		1.5089	2.0576		.0171	.0366
19	.0343		.0343	.0343	.0549	.0343	.0181
20	.0514		.0514	.0343	.0549	.0343	.0362
21	.0514		.0514	.0343	.0549	.0343	.0362
22	.0514		.0343		.0549	.0343	.0362
23	.0343		.0343	.0343	.0549	.0343	.0373
24	.8916	.0343	.0343	.0343	1.2346	.4755	1.1145
Max	1.3546	1.6804	1.6804	2.0576	1.3717	1.6095	1.3717
Min	.0343	.0343	.0343	.0343	.0343	.0171	.0181
Avg	.4846	.7383	.5666	.6471	.5442	.4777	.5462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 203 / 11 kV SANGWADE AG

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.1317	1.3032	1.2003	.1372	.0732	.0857
2	.0514	1.1145	1.3032	1.2003	.1372	.0732	.0857
3	.0514	1.0631	1.3032	1.2003	.1372	.0732	.0857
4	.0514	1.0631	1.3717	1.2003	.1029	.0732	.0857
5	.0514		1.3717	1.2689	.1029	.0914	.0857
6	.1029		1.5089	1.3717	.0857	.0914	.0857
7	.1886		1.749	1.749	.0857	.1097	.12
8	.1372		1.6632	1.749		.128	.12
9	.1372		1.6975	1.7833		.1294	.12
10	1.7661		.1029	.0686	1.6118	1.8461	
11	2.0919	1.5432	.1029	.1029	2.2634	1.9547	2.1719
12	2.0919	1.6461	.1029	.1029	2.2634	1.9547	2.2624
13	2.0919	1.3717	.1029	.1029	2.2634	1.9547	2.1357
14	2.0576	.1029		.1029	1.8861	1.9204	1.9909
15	1.9376	.12	.1029	.1029	1.8004	1.8861	1.9879
16	1.9376	.12	.1029	.1029	1.8004	1.869	
17	1.9204	.1372	.1029	.1029	1.7147	1.8519	1.8823
18	.1372		.12	.12		.1029	.1075
19	.1372		.12	.1372	.1267	.1029	.1254
20	.1372		.12	.1372	.128	.1029	
21	.12		.12	.1372	.1097	.12	.1254
22	.12		.12	.1372	.0914	.12	.1075
23	.12		.12	.1372	.0914	.0857	.0905
24	.0857	1.1317	1.3375	1.2174	.1372	.0914	.0857
Max	2.0919	1.6461	1.749	1.7833	2.2634	1.9547	2.2624
Min	.0514	.1029	.1029	.0686	.0857	.0732	.0857
Avg	.7323	.8788	.6978	.6473	.8132	.7003	.6642

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 204 / 11 KV INGALI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1372	.1543	.1372	.1372	.1543	.1097	.1372
2	.1372	.1372	.1372	.12	.1543	.0914	.12
3	.1372	.1372	.1372	.12	.1715	.0914	.12
4	.1372	.1372	.1372	.12	.1886	.0914	.12
5	.1372	.1543	.1543	.1372	.1886	.1829	.1372
6	.2058	.1886	.1886	.1715	.1886	.2378	.1886
7	.1886	.1543	.1886	.1886	.1886	.2195	.1715
8	.1715	.1372	.1543	.1715	.1886	.1829	.1715
9	.1372	.1372	.1372	.1372	.1886	.1829	.1372
10	.12		.1372		.1372	.128	
11	.12	.1029	.1372	.1543	.1029	.12	.1063
12	.12	.12	.12	.1543		.12	.0183
13	.1372	.12	.12	.1543		.12	.1991
14	.1372	.12		.1372		.12	.1629
15	.12	.1372	.1543	.1372	.1715	.1543	.1629
16	.12	.1372	.12	.1372	.1715	.1543	.1629
17	.12	.1372	.12	.12	.1715	.1543	.1448
18	.12		.12	.1372		.1372	.1991
19	.1543		.1715	.1372	.1829	.1886	.2172
20			.1886	.1886	.2012	.1886	.2172
21	.2058		.1715	.1886	.1829	.1886	.2172
22	.1715		.1715	.1886	.1829	.1715	.181
23	.1543		.1543	.1715	.1463	.1543	.1267
24	.1372	.1543	.1543	.1372	.1543	.1097	.1543
Max	.2058	.1886	.1886	.1886	.2012	.2378	.2172
Min	.12	.1029	.12	.12	.1029	.0914	.0183
Avg	.1446	.1392	.1484	.1499	.1708	.1500	.1554

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 205 / 11 KV SANGAWADE VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.406	.4801	.4801	.4801	.4801	.3658	.4458
2	.4801	.4458	.4801	.4458	.4801	.3658	.4458
3	.4801	.4458	.4801	.4458	.5487	.3658	.4458
4	.4801	.4458	.4801	.4458	.5144	.4024	.3944
5	.5144	.4973	.5316	.5144	.5487	.5121	.4287
6	.6173	.6516	.6859	.6344	.823	.6584	.6344
7	.7888	.7202	.7888	.6859	.9259	.7499	.7888
8	.8916	.8916	1.0288	.8916		.7316	.8573
9	.9259	1.2346	1.1831	1.0974		.9511	.9602
10	1.2346	1.2346	1.3889		.4801	1.2308	
11	1.2346	1.2003	1.2003	1.2346		1.2003	1.3756
12	1.2346	1.2003	1.2003	1.2346		1.2003	1.6095
13	1.2346	1.2003	1.2003	1.2346		1.2003	1.4632
14	1.2003	1.2003		1.2003		1.2003	1.086
15	1.2003	1.2003	1.2003	1.2003	.4458	1.2346	1.448
16	1.2003	1.2003	1.2003	1.2003	.4458	1.2346	1.5927
17	1.2003	1.2003	1.2003	1.2689		1.2346	1.3032
18	1.166		1.2003	1.2346		1.2346	1.3253
19	.9259		.823	1.2689	.5853	.6859	.6805
20	.8745		.6859	1.2689	.695	.6859	.7602
21	.7545		.6516	1.2346	.6401	.6344	.724
22	.703		.6001	1.2174	.5487	.6173	.6878
23	.6001		.5316	1.0288	.4572	.5487	.6401
24	.4801	.4801	.4801	.4801	.5144	.3658	.4801
Max	1.406	1.2346	1.3889	1.2689	.9259	1.2346	1.6095
Min	.4801	.4458	.4801	.4458	.4458	.3658	.3944
Avg	.9095	.8850	.8566	.9543	.5708	.8171	.8947

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 206 / 11 KV PATTANKODOLI VLG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6516	.6516	.6516	.6344	.583	.6401	.6859
2	.6516	.6173	.6516	.6173	.6173	.5487	.6344
3	.6516	.6001	.6516	.6173	.6173	.5487	.6344
4	.6516	.6001	.6516	.6173	.6516	.5316	.6344
5	.6859	.6687	.703	.6516	.6859	.6401	.6859
6	.7545	.7545	.823	.6516	.7202	.8413	.823
7	.7888	.823	.823	.7545	.7545	.7865	.823
8	.6859	.7888	.6859	.7545		.7316	.7545
9	.6173	.7545	.6859	.7888		.695	.6859
10	.6859	.6516	.6859	.7545	.6859	.7316	
11	.6516	.6516	.6516	.6859	.6516	.6516	.8326
12	.583	.6516	.6516	.6859	.6516	.6516	.7783
13	.5144	.583	.6516	.6516	.6173	.6516	.7421
14	.5487	.6516		.6516	.583	.6516	.724
15	.5487	.6516	.6516	.6516	.5487	.6173	.8779
16	.5487	.6516	.6516	.6516	.5487	.6173	.8596
17	.583	.6516	.6516	.7545	.6173	.6173	.724
18	.6516		.6859	.8573		.6859	.7602
19	.9602		.8916	.7888	.9511	1.0288	1.0498
20	1.0802		1.0288	.6859	1.0974	1.1145	1.086
21	1.0288		.9945	.7202	1.0059	1.0802	1.0498
22	.9431		.8916	.7545	.823	.7202	.905
23	.7545		.7888	.823	.7682	.6859	.8145
24	.6516	.6516	.6516	.6687	.7202	.7316	.6859
Max	1.0802	.823	1.0288	.8573	1.0974	1.1145	1.086
Min	.5144	.583	.6516	.6173	.5487	.5316	.6344
Avg	.7030	.6697	.7328	.7030	.7095	.7167	.7935

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144065 / 33/11 KV S/ST PATTANKODOLI

Feeder No / Name : 207 / 11 KV Vasagade Ag Feeder SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	.9945	.9945	1.0802	.0514	.0549	.0514
2	.0514	.9945	.9945	1.046	.0514	.0549	.0514
3	.0514	.9431	.9945	1.046	.0514	.0549	.0514
4	.0514	.9431	.9945	1.046	.0514	.0549	.0514
5	.0514	1.0117	1.046	1.1317	.0514	.0549	.0514
6	.0686	1.1145	1.1831	1.2346	.0514	.0549	.0514
7	.0686	1.3546	1.4746	1.4575	.0514	.0549	.0514
8	.0686	1.3375	1.5261	1.4575		.0566	.0514
9	.0686		1.406	1.4403		.0549	.0514
10	1.749	.0343	.0514	.0343	1.0288	1.448	
11	1.7833		.0343	.0343	1.8004	1.9204	2.0633
12	1.7833	.0343	.0343	.0343	1.8004	1.9204	1.9728
13	1.8347	.0343	.0343	.0343	1.7833	1.9204	2.0119
14	1.8347	.0343			1.7147	1.8861	1.9366
15	1.6804	.0343	.0343	.0343	1.6289	1.7147	1.9185
16	1.2003	.0343	.0343	.0343	1.6289	1.6289	1.6991
17	1.6804	.0343	.0343	.0343	1.5432	1.6289	1.8099
18	.0343		.0343	.0343		.0343	.0543
19	.0514		.0514	.0343	.0732	.0514	.0543
20	.0514		.0514	.0343	.0732	.0514	.0543
21	.0514		.0514	.0343	.0732	.0686	.0543
22	.0514		.0514	.0514	.0732	.0514	.0543
23	.0514		.0514	.0514	.0549	.0514	.0543
24	.0514	.0514	1.0117	1.0802	.0514	.0549	.0514
Max	1.8347	1.3546	1.5261	1.4575	1.8004	1.9204	2.0633
Min	.0343	.0343	.0343	.0343	.0514	.0343	.0514
Avg	.6008	.5616	.5293	.5435	.6518	.6220	.6196



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 201 / 11 KV BRAMHANATH AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0747	1.5384	1.4198	1.4586	.0503	.0701	.0671
2	.0747	1.5384	1.6476	1.4754	.0509	.0655	.0671
3			1.643	1.4586	.0492	.0617	.0671
4		1.5546	1.6129	1.4922	.0497	.0633	.0671
5		1.5546	1.8233	1.6095	.0514	.0678	.0671
6		1.587	2.1125	1.7269	.052	.0671	.0838
7		1.6194	2.1313	2.0119	.0566	.0686	.0838
8		2.0748	2.2257	2.0622	.0754	.0701	.0671
9		2.1125	2.1125	1.9616	.0754	.0633	.0671
10		.0754	.0671	.0566	2.2257	2.4291	2.6217
11	.6964	.0754	.0671	.0566	2.5579	2.5149	2.6595
12	2.0081	.0754	.0671	.0566	2.6326	2.6155	
13	2.0729	.0732	.0671	.0566		2.4646	2.6029
14	2.1052		.0671	.0754		2.4646	2.5652
15	2.0729	.0566	.0671	.0754		2.4646	2.5274
16	2.0243	.0754	.0671	.0754		2.4981	2.4897
17	2.0081	.0754	.0671	.0754	2.4646	2.2298	2.4331
18	.0693	.048	.0671	.0492	.0655	.0671	.0655
19	.0701	.0655	.0663	.0486	.0791	.0671	.064
20	.0701	.0671	.0671	.0497	.0838	.0671	.0663
21	.0739	.0701	.0671	.0503	.0876	.0671	.0671
22	.0739	.0701	.0671	.0514	.0686	.0671	.0686
23	.0732	.0701	.0671	.052	.0678	.0671	.0693
24	.0747	1.5223	1.5089	1.4586	.0514	.0671	.0671
Max	2.1052	2.1125	2.2257	2.0622	2.6326	2.6155	2.6595
Min	.0693	.048	.0663	.0486	.0492	.0617	.064
Avg	.8527	.7273	.7990	.7310	.5448	.8645	.8263

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 202 / 11 KV PANCHGANGA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.531				1.5424	1.5424	1.4419
2	1.5684				1.543	1.4582	1.4419
3	1.6057				1.4582	1.3889	1.4419
4	1.643				1.4586	1.4074	1.4419
5	1.6804				1.5432	1.5261	1.4419
6	1.7177				1.595	1.5089	1.5089
7	1.7551				1.6598	1.5432	1.358
8	1.7177				1.7541	1.5424	1.358
9	1.6991				1.8484	1.4074	1.358
10		1.905	1.8107	2.1313			
11		1.9239	1.7436	2.2068			
12		2.037	1.7436	2.2257			
13		2.037	1.8945	2.2445			
14		2.0936	1.8945	2.1691			
15		2.1125	1.861	2.1313			
16		2.0748	1.8275	2.0936			
17		1.905	1.7736	2.0748			
22							.0686
24	1.4937				1.5432	1.4754	1.4754
Max	1.7551	2.1125	1.8945	2.2445	1.8484	1.5432	1.5089
Min	1.4937	1.905	1.7436	2.0748	1.4582	1.3889	.0686
Avg	1.6412	2.0111	1.8186	2.1596	1.5946	1.4800	1.3033

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144076 / 33/11 KV RANGOLI

Feeder No / Name : 203 / 11 KV RANGOLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2987	.2267	.216	.2534	.2012	.2454	.2715
2	.2614	.2429	.2454	.2534	.2035	.1966	.218
3	.2614		.2515	.2353	.2294	.1852	.2172
4	.2801	.2591	.2372	.2743	.2652	.2214	.2172
5	.2987	.2591	.2652	.2715	.3086	.2713	.2172
6	.3361	.2753	.3395	.2926	.3467	.3018	.2715
7	.3547	.2753	.3584	.3439	.3961	.3429	.3688
8	.3361	.3395	.3395	.3439	.3772	.3155	.285
9	.3174	.415	.3772	.4163	.3961	.3479	.543
10	.2591	.415	.3801	.3961	.3206	.3258	.4527
11	.2429	.3772	.3982	.4527	.2987	.3018	.415
12	.2915	.3584	.3982	.4527	.3361	.3258	.3961
13	.2753	.3395	.3077	.4338		.3439	.3772
14	.2915	.3395	.362	.415		.3584	.3584
15	.2915	.3772	.4344	.4338		.3439	.3395
16	.2915	.4338	.4525	.4527		.4706	.4338
17	.2753	.4338	.3258	.4715		.4525	.4715
18	.2915	.4161	.3982	.3932	.2785	.4344	.3768
19	.3641	.3932	.4344	.3725	.3321	.4344	.3201
20	.3681	.3856	.4525	.3481	.3688	.4163	.3149
21	.3696	.4382	.4344	.3185	.3856	.4163	.285
22	.3881	.4207	.4163	.3086	.3772	.4163	.2743
23	.3292	.3856	.3801	.2601	.3222	.4163	.2254
24	.3174	.2267	.3018	.3258	.2229	.3018	.3258
Max	.3881	.4382	.4525	.4715	.3961	.4706	.543
Min	.2429	.2267	.216	.2353	.2012	.1852	.2172
Avg	.3080	.3493	.3544	.3550	.3140	.3411	.3323

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 201 / 11 KV YELGUD VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2572	.2641	.2743	.3206	.2134	.2601	.2543
2	.2229	.2614	.2561	.3206	.2035	.2254	.2374
3	.2058	.2427	.2353	.2641	.2012	.2254	.1844
4	.2058	.2427	.2353	.2452	.2058	.2058	.1865
5	.2401	.2614	.2534	.2614	.2401	.2229	.1844
6	.2915	.2353	.2507	.3174	.2743		.2683
7	.2743	.333	.2507	.3224	.3353	.3052	.3353
8	.3048	.2915	.2601	.3467	.3185	.2321	.2883
9	.3048	.2743	.2774	.3772	.2743	.2347	.285
10	.3258	.3812	.2883	.3561		.373	.3521
11	.4458	.3315	.3688	.4115	.4024	.4748	.3605
12	.4458	.3978	.3688	.4862	.3856	.4748	.3688
13	.4115	.3856	.3932	.4527		.407	.3353
14	.3601	.3688	.3018	.4024		.3688	.3353
15	.3688	.3688	.3688	.4024		.3856	.3201
16	.3688	.3353	.3315	.3353		.3856	.3688
17	.3521	.3812	.39	.39	.333	.3688	.3048
18	.3353	.4191	.4066	.3772	.4207	.3018	.3222
19	.4191	.4382	.4904		.4338	.3688	.3944
20	.4191	.381	.4954	.3292	.415	.381	.0377
21	.381	.381		.4382	.4527	.4382	.4338
22	.4001	.381	.4572	.4191	.415	.4382	.3429
23	.3239	.3429	.381	.362	.3772		.3258
24	.2743	.2829	.2926	.3239	.2883	.2947	.2713
Max	.4458	.4382	.4954	.4862	.4527	.4748	.4338
Min	.2058	.2353	.2353	.2452	.2012	.2058	.0377
Avg	.3308	.3326	.3316	.3592	.3258	.3351	.2957

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 202 / LAXMI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.2829	.3475	.3206	.0305	.0347	.0339
2	.0343	.2614	.3292	.3206	.0339	.0347	.017
3	.0343	.2614	.3258	.3018	.0339	.0347	.017
4	.0343	.2614	.3439	.3206	.0339	.0343	.017
5	.0343	.2801	.3982	.3361	.0343	.0343	.0339
6	.0343	.3258	.4656	.4481	.0343	.0339	.0335
7	.0305	.4207	.5194	.5014	.0335	.0339	.0335
8	.0152	.4973	.5375	.4334	.0335	.0332	.017
9	.0152	.463	.5201	.4115	.0152	.0168	.0168
10	.463	.0166	.0339	.017		.39	.4527
11	.6173	.0166	.0168	.0152	.7042	.6874	.7537
12	.6344	.0166	.0168	.0168	.6874	.8478	.6401
13	.6173	.0168	.0164	.0168		.7122	.5335
14	.5487	.0168	.0168	.0168		.6539	.4877
15	.503	.0168	.0168	.0335		.3688	.503
16	.4694	.0335	.0166	.0335		.503	.5868
17	.4694	.0168	.0339	.0339	.5784	.6371	.0152
18	.0168	.0381	.0185	.0343	.0183	.0168	.017
19	.0191	.0381	.0377		.0377	.0373	.0343
20	.0191	.0381	.0381	.0366	.0377	.0381	.0377
21	.0191	.0381	.0381	.0381	.0377	.0381	
22	.0191	.0381	.0191	.0381	.0377	.0381	.0343
23	.0191	.0381	.0191	.0381	.0377		.0343
24	.0343	.2829	.3475	.3239	.0339	.0347	.0339
Max	.6344	.4973	.5375	.5014	.7042	.8478	.7537
Min	.0152	.0166	.0164	.0152	.0152	.0168	.0152
Avg	.1973	.1548	.1864	.1777	.1312	.2302	.1906

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144085 / 33/11KV YELGUD SUBSTATION

Feeder No / Name : 203 / bajrang ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.0377	.0366	.0754	.7621	.9362	.78
2	.8573	.0373	.0366	.0754	.8648	.9015	.78
3	.8402	.0373	.0362	.0754	.8648	.9015	.8139
4	.8402	.0373	.0362	.0754	.8478	.9088	.8478
5	.8916	.0373	.0362	.0747	.8916	.9602	.9835
6	.9431	.0362	.0358	.0747	.9602	1.0174	1.0395
7	.9145	.0351	.0358	.0358	.9724	1.1361	1.1401
8	1.0974	.0343	.0347		1.0898	1.1105	1.153
9	1.0669	.0343		.0343	1.0212	1.1568	1.1736
10	.0171	1.2597	1.3565	1.1869		.017	.0168
11	.0343	1.4586	1.4586	1.0822		.0168	.017
12	.0171	1.3592	1.5089	1.2071		.017	.0335
13	.0171	1.3748	1.3927	1.1736		.017	.0305
14	.0171	1.3413	1.2071	1.2071		.0168	.0305
15	.0168	1.1736	1.1904	1.2071		.0168	.0305
16	.0168	1.1904	1.1437	1.1401		.0168	.0335
17	.0168	1.1603	1.153	1.2039	.0351	.0168	.0305
18	.0168	.0381	.0554	.0514	.0366	.0335	.017
19	.0381	.0381	.0566		.0377	.0373	.0343
20	.0381	.0381	.0762	.0366	.0377	.0381	
21	.0381	.0381	.0762	.0381	.0377	.0381	
22	.0381	.0381	.0762	.0381	.0377	.0381	.0343
23	.0381	.0381	.0762	.0381	.0377		.0343
24	.823	.0377	.0366	.0762	.8478	.9362	.7461
Max	1.0974	1.4586	1.5089	1.2071	1.0898	1.1568	1.1736
Min	.0168	.0343	.0347	.0343	.0351	.0168	.0168
Avg	.3955	.4546	.4849	.4640	.5519	.4472	.4455

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 201 / GADMUDSHINGI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	1.749	1.7604	1.861	.1524	.1524	.1334
2	.1524	1.7318	1.6766	1.8442	.1524	.1524	.1334
3	.1524	1.7147	1.7604	1.8442	.1524	.1524	.1334
4	.1715	1.7318	1.9281	1.9616	.1524	.1524	.1698
5	.1715	1.8176	2.2634	2.3137	.1524	.1715	.1886
6	.1905	2.0233	2.4646	2.5149	.1524	.1905	.2075
7	.2286	2.5206	2.5316	2.5819	.1524	.1905	.2075
8	.1905	2.3663	2.7018	2.6825	.1715	.1715	.1698
9	.1543	2.5149	2.7328	2.5316	.132	.1524	.1143
10	2.8121	.1132	.1524	.2096	2.1963	2.6658	2.5149
11	2.9492	.1509	.1143	.1715	2.9172		3.0514
12	2.5206	.1509	.1334	.1715		1.6263	2.7496
13	2.692	.1509	.0953	.1334		2.5149	2.6825
14	2.8121	.132	.1143	.1524	2.4143	2.5819	2.9675
15	2.7949	.132	.1143	.1334	2.8334	2.8502	3.0011
16	2.6578	.1509	.1143	.1524	2.8837	2.8669	
17	2.7263	.1698	.1143	.1905	2.9005	2.9005	2.8837
18	.1372	.1132	.1143	.1715	.1715	.1698	.1143
19	.1509	.1886	.1334	.2096	.1905	.2075	.2286
20	.1698	.1509	.1715	.1524	.1905	.1698	.2096
21	.1698	.1715	.1905	.1524	.2096	.1886	.2096
22	.1698	.1905	.1905	.1715	.1905	.2075	.2286
23	.1509	.1886	.1715	.1715	.1715	2.3137	.2096
24	.1905	1.749	1.8107	1.8945	.1524	.1715	.1509
Max	2.9492	2.5206	2.7328	2.6825	2.9172	2.9005	3.0514
Min	.1372	.1132	.0953	.1334	.132	.1524	.1143
Avg	1.0278	.9197	.9814	1.0156	.8542	.9966	.9852

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 202 / KALAMWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1509	.132	.1307	.0943	.1132	.1524
2	.168	.1509	.132	.112	.0943	.112	.1334
3	.168	.1509	.132	.112	.0943	.112	.1334
4	.168	.1509	.132	.112	.0943	.112	.1334
5	.168	.1509	.1509	.1307	.1132	.1307	.1509
6	.168	.1698	.1509	.1494	.132	.1307	.1698
7	.1867	.1509	.1509	.168	.1132	.1307	.1698
8	.1307	.1509	.1698	.168	.1132	.1307	.1698
9	.1509	.1886	.168	.1509	.1509	.1494	.1698
10	.1886	.2263	.1867	.1698	.1509	.1494	.1886
11	.1886	.1886	.1867	.1307	.1698	.168	.1886
12	.1886	.1886	.2241	.1494		.2427	.2075
13	.1886	.1886	.168	.1509		.1867	.1698
14	.2075	.1698	.2054	.1715	.0943	.2241	.1698
15	.1886	.1698	.2054	.1905	.1698	.2054	.2263
16	.2075	.1886	.1867	.1307	.1509	.2614	.2075
17	.2263	.2263	.2054	.1509	.1509	.2641	.2801
18	.2075	.1698	.168	.1509	.1509	.2075	.2241
19	.2263	.2263	.1867	.1509	.1698	.2263	.2054
20	.2075	.2075	.2054	.1509	.1698	.2286	.2054
21	.2075	.1886	.2054	.1509	.1509	.1905	.2241
22	.1698	.1886	.1867	.112	.1509	.1905	.2427
23	.1698	.1698	.1494	.1307	.1307	.1715	.168
24	.168	.1509	.1509	.1494	.1132	.1109	.1905
Max	.2263	.2263	.2241	.1905	.1698	.2641	.2801
Min	.1307	.1509	.132	.112	.0943	.1109	.1334
Avg	.1833	.1776	.1725	.1447	.1328	.1729	.1867



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 203 / GADMUDSHINGI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4481	.5093	.4715	.4481	.5658	.4108	.4715
2	.4481	.5281	.4338	.4294	.5658	.3921	.4527
3	.4668	.5093	.4338	.4294	.5658	.3921	.4527
4	.4668	.5093	.4715	.4108	.6036	.4108	.4904
5	.4854	.547	.5093	.4481	.6036	.4481	.5281
6	.5228	.5847	.5281	.4854	.6036	.4854	.5281
7	.5601	.5093	.4904	.4668	.5228	.4854	.5281
8	.4854	.4527	.4527	.5415	.4481	.4668	.5093
9	.4715	.5093	.4668	.5041	.4904	.5228	.5228
10	.4904	.6224	.4481	.5228	.4338	.4854	.5041
11	.5281	.5658	.5228	.4854	.415	.6535	.6413
12	.5093	.4527	.4668	.4668		.5415	.6413
13	.5281	.4904	.5041	.4668		.6161	.679
14	.5281	.4904	.4854	.6287	.5847	.6161	.6602
15	.547	.6224	.5041	.6097	.5093	.6535	.679
16	.5281	.4904	.4854	.4854	.4527	.5228	
17	.6036	.4904	.4481	.4854	.4108	.5281	.5415
18	.4715	.547	.5041	.4668	.3921	.7733	.6908
19	.5658	.679	.4854	.7733	.5847	.7922	.8029
20	.679	.6979	.5601	.7922	.6036	.811	.8215
21	.6979	.679	.6348	.7733	.5847	.7922	.7842
22	.679	.679	.5975	.679	.5847	.8192	.7468
23	.6602	.5847	.5228	.6979	.5658	.724	.7468
24	.5041	.5281	.5093	.4481	.6036	.4338	.5144
Max	.6979	.6979	.6348	.7922	.6036	.8192	.8215
Min	.4481	.4527	.4338	.4108	.3921	.3921	.4527
Avg	.5365	.5533	.4974	.5394	.5316	.5740	.6060

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

HUPARI[042]

BU 7111

Substation No/ Name :- 144095 / 33/11KV GADMUDSHINGI

Feeder No / Name : 204 / sarnobatwadi ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3721	.0943	.0943	.0953	.394	.4119	.4031
2	.3721	.0943	.0754	.0762	.394	.394	.3856
3	.3898	.0943	.0754	.0762	.394	.394	.3814
4	.4075	.0943	.0943	.0762		.4119	.4161
5	.4252	.0943	.1132	.0953	.4119	.4119	.463
6	.4607	.0943	.132	.0953	.4382	.4382	.5316
7	.5316	.1509	.132	.0953	.5201	.5658	.5487
8	.6024	.1509	.1509	.1715	.4161	.6173	.6173
9	.5784	.1698	.1334	.0953	.3856	.6379	.6001
10	.132	.5609	.6024	.6001	.2075	.1905	.1715
11	.1509	.6241	.7087	.7122	.2075	.1905	.1334
12	.132	.5375	.6201	.6952		.1715	.1334
13	.1509	.5895	.567	.6613		.0762	.1524
14	.132	.5144	.7087	.6274	.2075	.1524	.1524
15	.132	.5201	.6201	.6001	.2075	.1905	.0953
16	.1132	.583	.6201	.6173	.2075	.1905	.1334
17	.132	.5426	.6201	.6133	.1905	.1905	.0953
18	.1509	.1509	.0953	.1334	.1905	.1886	.1905
19	.1509	.0943	.1143	.1524	.1715	.1905	.1905
20	.132	.0943	.0953	.1524	.1715	.1905	.1143
21	.1132	.0943	.0953	.1334	.1334	.1905	.1143
22	.0943	.0943	.0953	.1524	.1334	.1715	.1143
23	.0943	.0754	.0953	.1334	.1334	.1524	.1143
24	.3721	.0943	.0943	.0953	.3761	.4298	.4477
Max	.6024	.6241	.7087	.7122	.5201	.6379	.6173
Min	.0943	.0754	.0754	.0762	.1334	.0762	.0953
Avg	.2634	.2586	.2814	.2898	.2806	.2979	.2792

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 201 / EKONDI Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1433	.112		2.1879	1.9662	.128	.1433
2	.1433	.128		2.2542	1.9662	.128	.1267
3	.1433	.128		2.2542	2.0719	.1265	.1267
4	.1433	.128		2.3205	2.0481	.128	.1254
5	.1417			2.3205	2.13	.128	.1448
6	.1433	.144		2.3594	2.3266	.1457	.197
7	.1433	.144		3.0476	2.6216	.1457	.2149
8	.1595	.1475		3.3813	2.982	.128	.2328
9		.1448	1.7695	3.1459	3.315	.1417	
10			.1417	.1417		2.7526	
11		.1791	.0709	.124			
12		.1991		.124		3.7685	
13		.1791	.1578	.1417		3.6866	
14		.181	.1595	.1417	2.652	3.4408	
15		.181		.1417	2.9504	3.2769	
16				.124	2.9172	3.2769	
17			.1791	.197		3.0498	
18			.2149	.197	.1311	.1734	
19			.2149	.1791	.144		
20	.144		.2328	.2149	.16	.1928	
21	.144		.2507	.2126	.16	.1791	
22			.2328	.2126	.144	.1791	
23			.2149	.2126		.1791	
24	.1417	.112		2.13	1.9662	.128	.181
Max	.1595	.1991	1.7695	3.3813	3.315	3.7685	.2328
Min	.1417	.112	.0709	.124	.1311	.1265	.1254
Avg	.1446	.1505	.3200	1.1569	1.8140	1.1583	.1658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 202 / Siddhanerli- Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0354	.032		.8619	.8848	.0316	.0362
2	.0354	.032		.8619	.8848	.0316	.0362
3	.0358	.032		.8619	.9175	.032	.0362
4	.0358	.0316		.8619	.9175	.0316	.0362
5	.0358	.0316		.8951	.9012		.0362
6	.0358	.0316		1.0277	.9831		.0362
7	.0358			1.2125	1.3108		.0362
8	.0354	.0312		1.2929	1.6575	.032	
9		.0358	1.2125	1.2452	1.9062	.0358	.0358
19			.0358		.032	.0347	
20			.0358	.0358	.0312	.0347	.0358
21			.0362	.0354	.0316	.0358	.0358
22			.0358	.0358	.032	.0358	.0358
23			.0358	.0358		.0358	.0358
24	.0366	.0312		1.7238	.852	.032	.0362
Max	.0366	.0358	1.2125	1.7238	1.9062	.0358	.0362
Min	.0354	.0312	.0358	.0354	.0312	.0316	.0358
Avg	.0358	.0321	.2320	.7848	.8102	.0336	.0360

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 203 / 11KV Shendur Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9831	.9393		.0724	.1075	1.3435	1.1934
2	.9831	.9393		.0716	.1075	1.3763	1.1603
3	.9945	.9717		.0716	.1086	1.4091	1.1603
4	1.065	1.0159		.0724	.1086	1.4091	1.1603
5	1.1469	1.0486		.0724	.1075	1.9662	1.326
6	1.3108	1.1934			.1267	2.2939	1.5249
7	1.9662	1.4419		.1086	.1086	2.652	2.1548
8	2.0481	2.2939		.1267	.1075	2.6543	2.5857
9		2.4531	.1075	.1433	.1433	2.3758	
10		2.4863	1.9062	1.7404		.1075	
11		.1829	2.4577	2.13		.0914	
12		1.9559	2.2939	2.1792		.0886	
13		1.8233	2.1628	2.0481		.0886	
14		1.8233	1.9662	1.8842	.1075	.0886	
15		1.8564	1.8023	1.9662	.0716	.0886	
16			1.8023	2.2939	.0895	.0895	
17			1.6575	1.989		.1086	.1063
18	.112		.0895	.0732	.112	.104	.124
19	.1265		.0905	.0716	.1296	.1063	.1075
20	.1265		.1267	.1433	.128	.124	.1063
21			.0905	.128	.128	.1254	.1075
22			.0905	.1086	.112	.1086	.1097
23			.0905	.1075		.1086	.1097
24	.9831	.9339		.1448	.1075	.9231	1.2597
Max	2.0481	2.4863	2.4577	2.2939	.1433	2.6543	2.5857
Min	.112	.1829	.0895	.0716	.0716	.0886	.1063
Avg	.9872	1.4599	1.1156	.7716	.1118	.8263	.8935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 204 / Sidhnerli Ekondi Gaothan  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068	.5228		.4954	.5121	.5228	.4954
2	.5121	.5175		.4572	.5175	.499	.4572
3	.4938	.5175		.4572	.499	.499	.4572
4	.4755	.4805		.4572	.4805	.4805	.4572
5	.5121	.5228		.5335	.5175	.5601	.5335
6	.6722	.5975		.6036	.6722	.6348	.724
7	.6401	.6348		.6224	.6468	.6036	.6413
8	.5853	.5975		.6036	.5304	.5228	
9		.5601	.6283	.6584	.6036	.5121	
10		.6722	.695	.7133		.6767	
11		.6584	.7133	.695		.5853	
12		.6653	.7316	.6401	.5041	.439	
13		.6653	.5853	.5853	.5601	.6036	
14		.5544	.6219	.5121	.5415	.5304	
15		.462	.5853	.5121	.4481		
16			.5304	.5121	.5093	.5121	
17			.567	.5487		.5175	.3658
18	.5415		.6584	.5415	.4854	.499	.4572
19	.7842		.7095	.7468	.679	.7392	.9709
20	.9054		.7842	.8775	.8865	.9149	.9709
21			.7922	.8029	.7468	.9149	.8962
22			.7922	.7468	.7468	.7922	.7842
23			.6478	.5853		.679	.6722
24	.543	.5601		1.0242	.5121	.5228	.5716
Max	.9054	.6722	.7922	1.0242	.8865	.9149	.9709
Min	.4755	.462	.5304	.4572	.4481	.439	.3658
Avg	.5977	.5743	.6695	.6222	.5800	.5983	.6303

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 205 / 11 kv Shendur Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.394	.3696		.3326	.3982	.3881	.3734
2	.3582	.3734		.3174	.362	.3734	.3361
3	.3582	.3734		.3174	.3761	.3361	.3361
4	.394	.3326		.3174	.3982	.3361	.3361
5	.394	.4108		.3734	.4163	.3734	.3734
6	.4755	.3734		.4435	.4656	.3326	.4481
7	.4656	.3361		.4066	.4298		.439
8	.3582	.3361		.439	.3109	.3292	.3582
9		.298	.3582	.3224	.2957	.3045	
10		.3506	.394	.3761		.3658	
11		.3544	.4119	.394		.3841	
12		.3544	.394	.3982	.4161	.4024	
13		.3721	.4207	.3982	.3856	.4207	
14		.3506	.4024	.394	.3582	.439	
15		.3506	.3658	.394	.3544	.394	
16			.4024	.4119	.3045	.439	
17			.3988	.394		.4508	.2865
18	.3326			.5014	.4108	.4607	.4298
19	.5601		.5258	.5487	.5121	.5611	.6219
20	.5975		.6154	.6099	.6283	.6516	.6219
21			.5544	.5853	.5975	.5853	.6036
22			.5175	.5544	.5228	.5487	.5175
23			.4294	.4656		.4805	.4481
24	.394	.3696		.3734	.3801	.4108	.3881
Max	.5975	.4108	.6154	.6099	.6283	.6516	.6219
Min	.3326	.298	.3582	.3174	.2957	.3045	.2865
Avg	.4235	.3566	.4422	.4195	.4162	.4247	.4324

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 206 / Octega Green

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
16		.0351		
24	.0343		.0702	.0343
Max	.0343	.0351	.0702	.0343
Min	.0343	.0351	.0702	.0343
Avg	.0343	.0351	.0702	.0343



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 207 / 11KV Vitthal Shivaji LIS

PURELY LIS FEEDERS

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.4207	.3563		.4207	.064	.3898
4	.4607	.3932		.4557	.064	.4607
5	.4607	.3887		.4854	.064	.4607
6	.4607	.4534		.4854	.096	.4784
7	.4557	.4588		.4854	.08	.4557
8	.4607	.4588		.4908	.081	.4908
9		.4961	.4908	.4961	.0732	
10		.4908	.4908	.4961	.0732	
11		.4784	.4961	.5138	.4252	
12		.4961	.4961	.4961	.4607	
13		.4961	.4961	.4908	.4961	
14		.4908	.4961	.4908	.4961	
15		.4908	.4961	.4908	.4908	
16			.4961	.5083	.4908	
17			.4681	.4908	.463	
18	.3932		.4733	.5083		
Max	.4607	.4961	.4961	.5138	.4961	.4908
Min	.3932	.3563	.4681	.4207	.064	.3898
Avg	.4446	.4576	.4900	.4878	.2612	.4560

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144015 / 33/11KV SIDHNERLI

Feeder No / Name : 402 / 33 KV Shahu LIS -SDH-  
Feeder KV- 33 / OUTGOING

SHEDDABLE HV(AGRICULTURE)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	2.9767	2.3045		2.8166	1.9433	2.3137
4	3.1579	2.7846		3.1184	2.332	2.9172
5	3.1579	3.0121		3.3813	3.1459	3.4202
6	3.1687	3.2065		3.3813	3.3425	3.3813
7	3.2442	3.3916		4.3759	3.3916	3.083
8	3.1459	3.3036		4.1289	3.3916	3.0476
9		3.4705	4.1289	4.2273	3.3425	
10		3.2648	4.0306	4.2273	3.3425	
11		3.4202	4.2273	4.1289	3.4408	
12		3.4311	4.1289	4.1781	3.4408	
13		3.4311	4.1289	4.0809	3.4568	
14		3.4705	4.1289	4.0329	1.6872	
15		3.4311	4.0306	4.0329		
16			4.0809	4.2273	1.6324	
17			4.177	4.0809	2.3594	3.2648
22	.096					
Max	3.2442	3.4705	4.2273	4.3759	3.4568	3.4202
Min	.096	2.3045	4.0306	2.8166	1.6324	2.3137
Avg	2.7068	3.2248	4.118	3.8946	2.8750	3.0611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 201 / Kagal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	2.4958	2.3624	2.2481	.0953	.0953	.0762
2	.0572	2.4387	2.3815	2.2291	.0953	.0953	.0762
3	.0572	2.4006	2.3815	2.2481	.0953	.0953	.0762
4	.0762	2.4006	2.4006	2.2481	.0953	.0953	.0762
5	.0762	2.4387	2.4577	2.2862	.0953	.1143	.0762
6	.0762	2.5911	2.6101	2.4387	.0953	.1143	.0762
7	.0953	3.2198	2.934	2.8959	.0953	.0953	.0953
8	.0953	3.4675	3.0864	2.915	.0953	.0762	
9	.0762	3.0864	3.0674	2.8769	.0953	.0762	.0953
10	3.4294	.0762	.0572	.0762		1.9624	2.3243
11	3.6199	.0572	.0762	.0762	3.5627	2.4196	1.6766
12	3.5627	.0381		.0572	3.0293	2.4768	3.3722
13	3.5818	.0381	.0762	.0762	3.0674	2.4768	3.6389
14	3.5056	.0381	.0572	.0762	3.0102	2.5339	3.4675
15	3.3722	.0381	.0762	.0762		2.4196	3.296
16	3.4675	.0381	.0762	.0762		2.3243	3.2388
17	3.3722	.0762	.0762	.0762	2.915	.0762	3.0674
18	.0762	.0762	.0953	.0762	.1143	.0762	.0953
19	.0953	.1143	.0762	.0953	.1143	.0953	.0762
20	.0953	.1334	.1334	.0953	.1143	.0953	.1143
21	.0953	.1143	.1143	.0953	.0953		.0953
22	.0953	.0953	.0762	.0953	.0953	.0953	.0762
23	.0762	.0762	.0572	.0953	.0953	.0953	.0762
24	.0572	2.4577	2.3243	2.4006	.0953	.0953	.0762
Max	3.6199	3.4675	3.0864	2.915	3.5627	2.5339	3.6389
Min	.0572	.0381	.0572	.0572	.0953	.0762	.0762
Avg	1.2154	1.1669	1.1763	1.0804	.8174	.7869	1.1017

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 202 / Kagal-Sugar Factory Vg  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.0191	.0191	.0191	.0191	.0191	.0191
2	.362		.0191	.0191	.0191	.0191	.0191
3	.381	.0191	.0191	.0191	.0191	.0191	.0191
4	.381		.0191	.0191	.0191	.0191	.0191
5	.4001	.0191	.0191	.0191	.0191	.0191	.0191
6	.4763	.0191	.0191	.0191	.0191	.0191	.0191
7	.4954	.0191	.0191	.0191	.0191	.0191	.0191
8	.5716	.0191	.0191	.0191	.0191	.0191	
9	.5335		.0191	.0191	.0191	.0191	.0191
10	.5716	.0191	.0191	.0191	.0191	.0191	.0191
11		.0191	.0191	.0191	.0191	.0191	.0191
12	.0381	.0191	.0191	.0191	.0191	.0191	.0191
13	.0381	.0191	.0191	.0191	.0191	.0191	
14		.0191	.0191	.0191	3.0102	.0191	.0191
15	.0381	.0191	.0191	.0191	.0191	.0191	.0191
16	.0381	.0191	.0191	.0191		.0191	
17	.0191	.0191	.0191	.0191		.0191	.0191
18	.0191	.0191	.0191	.0191	.0191	.0191	.0191
19	.0191	.0191	.0191	.0191	.0191	.0191	.0191
20	.0191	.0191	.0191	.0191	.0191	.0191	.0191
21	.0191	.0191	.0191	.0191	.0191		.0191
22	.0191	.0191	.0191	.0191	.0191	.0191	.0191
23	.0191	.0191	.0191	.0191	.0191	.0191	.0191
24	.362	.0382	.0191	.0191	.0191	.0191	.0191
Max	.5716	.0382	.0191	.0191	3.0102	.0191	.0191
Min	.0191	.0191	.0191	.0191	.0191	.0191	.0191
Avg	.2356	.0200	.0191	.0191	.1551	.0191	.0191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 203 / Non Sh MIDC Kagal-Anant SHEDDABLE FEEDER HAVING WEEKLY  
 Roto Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3336	1.3527	1.5623	1.467	1.5432	.7621	1.3527
2	1.2765	1.3717	1.5432	1.5242	1.5623	.8383	1.4861
3	1.4098	1.4098	1.5623	1.5242	1.5623	.9145	1.2384
4	1.5242	1.448	1.5242	1.5432	1.5813	.8764	1.3146
5	1.5813	1.4098	1.5242	1.5051	1.6194	.9145	1.3527
6	1.6194	1.6194	1.6194	1.5432	1.6385	.9335	1.3527
7	1.7528	1.9243	1.8099	1.6575	1.6385	1.2384	1.5242
8	1.8671	1.9243	1.7528	1.6575	1.6004	1.2003	
9	1.6766	1.6385	1.7718	1.6766	.8192	1.2574	1.4098
10	2.2481	2.1719	1.9243	1.9433	.5525	1.4289	1.6766
11	2.3624	2.3624	2.1148	2.3624	.5716	1.7147	1.829
12	2.21	2.2481	2.1148	2.3815	.5906	2.0195	2.0386
13	1.9052	2.0005	1.8671	2.1338	.5906	1.9624	1.829
14	1.7528		2.1148	1.9243	.6097	1.8671	1.9624
15	2.0576	2.1338	2.2862	1.9624	.6097	1.8861	2.0767
16	2.1338	2.2481	2.0957	2.0386		2.0195	2.0195
17	2.0957	1.8099	2.3243	1.9814		2.0386	1.8861
18	1.8861	2.0005	2.1719	2.2481	.4954	1.9814	1.829
19	1.9052	2.2481	2.21	2.2672	.5716	2.0576	1.9814
20	2.3624	2.21	2.1719	2.2481	.724	1.9433	1.9433
21	1.6385	1.7718	1.6956	1.6575	.7621		1.4289
22	1.6004	1.6766	1.4098	1.6766	.724	1.3336	1.5242
23	1.467	1.6004	1.4098	1.4861	.7049	1.2574	1.3527
24	1.3717	1.2955	1.5623	1.3717	1.4289	.6859	1.2574
Max	2.3624	2.3624	2.3243	2.3815	1.6385	2.0576	2.0767
Min	1.2765	1.2955	1.4098	1.3717	.4954	.6859	1.2384
Avg	1.7933	1.8207	1.8393	1.8242	1.0228	1.4405	1.6377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 204 / Laxmi Ind

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.9145	.6097	.5525	.5716	.5335	.7621
2	.7049	.5525	.6859	.5335	.6097	.5144	.7811
3	.7621	.5525	.6097	.5335	.5525	.5716	.5716
4	.8002	.5906	.724	.5525	.5525	.5906	.6859
5	.724	.5716	.7621	.5335	.5335	.724	.7621
6	.8002	.6859	.6859	.5525	.5144	.7811	.6859
7	.8192	.8573	.6859	.5335	.4954	.8383	.7811
8	.6287	.724	.7621	.5335	.4954	.6478	
9	.724	.7811	.6859	.5335	.4572	.9145	.6097
10	.7621	.7811	.6668	.7621	.5335	1.086	1.1812
11	.9907	.7621	.6097	.6859	.4572	1.0288	.9526
12	.9907	.9526	.5906	.7049	.4572	.9907	1.0098
13	.7811	.7621	.6287	.5335	.5525	.9717	.7049
14	.7621	.7621	.6478	.4954	.4763	.7621	.724
15	.9145	.7811	.6097	.5335	.5716	.7621	.743
16	.7621	.7621	.5716	.5335	.5525	.8573	.743
17	.7621	.7621	.5525	.5335		.9145	.9335
18	.6287	.7621	.6097	.5335	.5335	.9145	.7621
19	.7811	.6859	.6097	.5335	.5144	.8954	.7621
20	.6287	.6859	.5906	.5716	.5906	.7811	.8383
21	.7049	.6859	.5335	.6287	.6287		.8383
22	.7621	.6097	.5335	.7049	.5716	.7621	.743
23	.7621	.6859	.5335	.6097	.5525	.7621	.7621
24	.8002	.8573	.6859		.6478	.5335	.7811
Max	.9907	.9526	.7621	.7621	.6478	1.086	1.1812
Min	.6287	.5525	.5335	.4954	.4572	.5144	.5716
Avg	.7716	.7303	.6327	.5749	.5401	.7886	.7878

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 205 / K.Sangaon

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5525	.5525	.5525	.4954	.4954	.6097
2	.5144	.5144	.5144	.4954	.4572	.4572	.5144
3	.5335	.5144	.5144	.5144	.4572	.5144	.5525
4	.5525	.4954	.5335	.5716	.4763	.5525	.6097
5	.6097	.5335	.6478	.6097	.4763	.6287	.6859
6	.6287	.6478	.6859	.6478	.4954	.7049	.724
7	.7811	.7811	.7621	.724	.5335	.8002	.743
8	.6478	.7621	.6097	.724	.4763	.7049	
9	.6478	.6668	.724	.6859	.4572	.7049	.5716
10	.6287	.6097	.6287	.6097	.4572	.7049	.6668
11	.6097	.743	.743	.6668	.4572	.6097	.6668
12	.6478	.5906	.6668	.5716	.4572	.6859	.7049
13	.6478	.7049	.6097	.6287	.4954	.7049	.743
14	.6097	.724	.6287	.6478	.4572	.6668	.724
15	.6478	.6859	.6668	.5716	.4763	.7049	.7049
16	.6478	.6668	.6287	.5716	.4572	.6668	.6668
17	.5335	.6287	.6097	.6097		.6478	.6668
18	.6478	.5525	.5906	.6668	.5335	.6668	.6097
19	.743	.6859	.7049	.743	.5906	.8002	.7621
20	.7811	.7621	.743	.743	.724	.8573	.7811
21	.7811	.7811	.743	.724	.7049		.7621
22	.7621	.724	.6668	.6668	.6097	.8002	.724
23	.6478	.6478	.6097	.6097	.5716	.7811	.6859
24	.5525	.6097	.5716	.5716	.5144	.5144	.6668
Max	.7811	.7811	.7621	.743	.724	.8573	.7811
Min	.5144	.4954	.5144	.4954	.4572	.4572	.5144
Avg	.6391	.6494	.6398	.6303	.5144	.6685	.6759

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 206 / Laxmi-Ag Feeder-

SEPARATED AG FEEDERS HAVING SPECIAL

Feeder KV- 11 / OUTGOING

DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9907	.9717	.9526	.0381	.0381	.0381
2	.0381	.9907	.9526	.9526	.0381	.0381	.0381
3	.0381	.9526	.9526	.9526	.0381	.0381	.0381
4	.0381	.9717	.9526	.9526	.0381	.0381	.0381
5	.0381	.9717	1.0669	1.0288	.0381	.0381	.0381
6	.0381	1.105	1.2003	1.1812	.0381	.0381	.0381
7	.0381	1.3717	1.5242	1.3527	.0381	.0381	.0381
8	.0381	1.3527	1.5432	1.3717	.0381	.0381	
9	.0381	1.3717	1.5242	1.3336		.0381	.0381
10		.0381	.0381	.0381	1.2193	1.2955	1.448
11	1.829	.0381	.0381	.0381	1.6385	1.9814	1.9243
12	1.8671	.0381	.0381	.0381	1.9433	2.0576	2.0005
13	1.7147	.0381	.0381	.0381	1.8861	2.0767	1.9243
14	1.7147	.0381	.0381	.0381	1.9243	2.0005	1.848
15	1.6766	.0381	.0381	.0381	1.829	1.9052	1.7528
16	1.7909	.0381	.0381	.0381	.9907	1.7909	1.7528
17	1.7147	.0381	.0381	.0381		1.7528	1.7528
18	.0381	.0381	.0381	.0381	.0381	.0381	.0572
19			.0381	.0381	.0381	.0572	.0762
20	.0381	.0762	.0381	.0381	.0381	.0572	.0762
21	.0381	.0572	.0381	.0381	.0381		.0762
22	.0381	.0381	.0381	.0381	.0381	.0572	.0762
23	.0381	.0381		.0381	.0381	.0381	.0381
24	.0381	.9717	.9907	.9335	.0381	.0381	.0381
Max	1.8671	1.3717	1.5432	1.3717	1.9433	2.0767	2.0005
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.5854	.5045	.5293	.4811	.5456	.6735	.6585



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 207 / S.Kharkhan Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	1.6787
Max	1.6787
Min	1.6787
Avg	1.6787

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 208 / Kagal Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9335	.9335	.9145	.8764	.9145	.9145	.9526
2	.8954	.8002	.8573	.8383	.8954	.8764	.9145
3	.8764	.7811	.8573	.8192	.8764	.8573	.8764
4	.8383	.7621	.8573	.8383	.8764	.8383	.8764
5	.8573	.7621	.8764	.8383	.8764	.8954	.8764
6	.9145	.9335	.9335	.8573	.9145	.9526	1.0098
7	.9335	.9526	.9526	.8764	.9907	.9526	1.0098
8	.8954	.9335	.8383	.8573	.8573	.8764	
9	.9145	.8954	.7621	.8573	.8573	.8383	.8383
10	.9145	.8383	.8764	.8573	.8192	.8954	.8573
11	.8573	.9145	.9145	.8764	.8954	.8954	1.0288
12	.9335	.8954	.9335	.8954	.8383	.9335	1.086
13	.8954	.9717	.9145	.8764	.9526	.9717	1.0288
14	.9335	.743	.9717	.8573	.9717	.9526	1.0479
15	.8573	.9526	.9145	.9335	.9526	.9907	1.0669
16	.9526	.9526	.9145	.9335	.9717	1.0288	1.0479
17	1.0098	.9717	.9335	.8954		1.0669	1.0098
18	1.0288	.9907	.9907	.9717	.9907	1.0479	1.086
19	1.4098	1.3146	1.2955	1.2765	1.2955	1.4289	1.3146
20	1.448	1.4289	1.3717	1.3717	1.4098	1.448	1.4289
21	1.3717	1.2574	1.2765	1.2193	1.2955		1.2955
22	1.2765	1.1431	1.1622	1.1812	1.1241	1.2193	1.2765
23	1.105	1.0479	1.0479	1.086	1.0479	1.1431	1.105
24	.9717	.9907	.9526	.9145	.9526	.9526	.9907
Max	1.448	1.4289	1.3717	1.3717	1.4098	1.448	1.4289
Min	.8383	.743	.7621	.8192	.8192	.8383	.8383
Avg	1.0010	.9653	.9716	.9502	.9816	.9990	1.0446

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 402 / 33KV Shahu LIS - KGL-

SHEDDABLE HV(AGRICULTURE)

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.5716	.9145	.4572	.6287	.5144	1.086
4	.5144	1.0288	.8573	.6287	.6287	1.086
5	.6287	1.1431	.8573	.9717	.743	1.086
6	1.3146	1.3717	1.3146	1.4289	.8573	1.4289
7	1.3146	1.3717	1.3717	1.4289	1.0288	1.4289
8	1.3146	1.3717	1.3717	1.3717	1.2574	
9	1.2574	1.3146	1.3146	1.3146	1.3717	1.3717
10	1.3146	1.2574	1.3146	1.3146	1.3717	1.4289
11	1.3146	1.3146	1.3146	1.3146	1.4289	1.4289
12	1.3146	1.3146	1.3146	1.3717	1.4289	1.3717
13	1.3146	1.3146	1.3146	1.3146	1.4289	1.3717
14	1.3146	1.3146	1.3146	1.3717	1.4289	1.4289
15	1.3717	1.3146	1.3146	1.3717	1.4289	1.4289
16	1.3717	1.3146	1.3146	1.3717	1.4289	1.4289
17	1.3146	1.3146	1.3146	1.3717	1.4289	1.3717
18	.743	.743	.743	.8002	.8002	.8002
Max	1.3717	1.3717	1.3717	1.4289	1.4289	1.4289
Min	.5144	.743	.4572	.6287	.5144	.8002
Avg	1.1431	1.2324	1.1753	1.2110	1.1610	1.3032

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144016 / 33/11 KV KAGAL SUBSTATION

Feeder No / Name : 403 / 33 KV Padmavati

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

Feeder KV- 33 / OUTGOING

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.2862	2.4006	1.2574	2.4006	1.829	.8002	2.2862
2	2.2862	2.2862	1.4861	2.4006	2.0576	.8002	2.4006
3	2.2862	2.0576	1.829	2.2862	2.2862	.8002	2.1719
4	2.2862	2.2862	2.2862	2.0576	1.9433	.8002	2.2862
5	2.2862	1.829	1.4861	1.3717	2.4006	.8002	2.5149
6	2.5149	2.1719	1.829	2.0576	2.1719	.8002	
7	2.5149	2.6292	2.1719		1.3717	.8002	2.2862
8	1.0288	1.6004	2.1719	.6859	.5716	1.7147	
9	1.3717	2.1719	2.4006	.6859	.6859	1.4861	2.0576
10	1.829	1.4861	1.9433	.6859	.6859	1.829	1.4861
11	1.2574	2.4006	1.0288	.6859	.6859	2.5149	2.5149
12	1.3717	1.4861	1.4861	.6859	.6859	1.4861	1.3717
13	1.3717	1.4861	2.2862	.6859	.6859	1.1431	1.3717
14		.5716	2.4006	.6859	.6859	1.3717	
15	2.0576	.6859	1.1431	.6859	.6859	1.3717	1.4289
16	1.3717	.5716	.5716	.6859	.6859	1.3717	2.2862
17	1.4861	1.4861	1.4861	.6859		1.4861	1.4861
18	1.4861	1.4861	.6859	.6859	.8002	.5716	1.2574
19	1.6004	1.4861	1.4861	.6859	.8002	1.2574	1.829
20	2.2862	2.0576	1.2574	.5716	.8002	1.4861	2.0576
21	2.6292	1.3717	2.2862	.6859	.8002		1.3717
22	2.0576	1.829	2.4006	1.6004	.8002	1.3717	1.2574
23	2.6292	2.0576	2.5149	2.2862	.8002	1.3717	2.1719
24	2.4006	2.4006	1.3717	2.5149	2.1719	.8002	2.4006
Max	2.6292	2.6292	2.5149	2.5149	2.4006	2.5149	2.5149
Min	1.0288	.5716	.5716	.5716	.5716	.5716	1.2574
Avg	1.9433	1.7623	1.7195	1.2376	1.1779	1.2276	1.9188

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 201 / 11KV MIDC

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7909	1.9433	1.6385	1.9814	1.6575	1.6385	2.0957
2	1.6956	1.9052	1.5623	1.9052	1.5623	1.6194	1.7528
3	1.7147	1.7147	1.6004	1.4289	1.6575	1.5813	1.7147
4	1.5813	1.6766	1.5813	1.4289	1.6194	1.6004	1.7147
5	1.6004	1.5813	1.5432	1.4289	1.6385	1.5813	1.6766
6	1.6004	1.5623	1.5623	1.5813	1.5623	1.6004	1.6194
7	1.5242	1.5623	1.5242	1.5242	1.5051	1.6575	1.6575
8	1.6004	1.6194	1.5813	1.5242	1.5813	1.5813	1.6194
9	1.7528	2.0005	2.21	1.6956	1.5242	1.8861	1.6575
10	2.1719	2.2481	2.4768	1.8099	1.5242	2.1719	2.0195
11	2.6292	2.8959	2.3815	1.848	1.5242	2.6863	2.1529
12	2.3815	2.2672	2.3815	2.21	1.5432	2.4577	2.21
13	1.7528	1.8671	1.7909	1.6766		1.6575	1.9243
14	2.6673	2.3243	2.1338	2.191		2.1148	2.4768
15	2.572	2.572	2.0957	2.2481		2.4768	2.4387
16	2.5149	2.5149	2.1338	2.0005		2.0957	2.6292
17	2.191	2.5911	2.3053	1.8861		2.3815	1.9052
18	2.3815	1.9433	1.5623	1.9243	1.5051	1.9052	2.0005
19	1.9052	1.9243	2.1338	1.9624	1.6004	2.0576	2.0767
20	1.8671	1.8099	2.0767	1.8099	1.5623	2.0576	1.9433
21	2.0005	1.5432	1.7528	1.5051	1.6004	2.0767	1.8099
22	1.7718	1.5432	1.7147	1.9433	1.6575	1.8099	1.6004
23	2.0576	1.7718	1.7718	2.0386	1.6004	2.1338	2.1338
24	1.7528	1.9814	1.7528	1.9433	1.7528	1.6385	2.1719
Max	2.6673	2.8959	2.4768	2.2481	1.7528	2.6863	2.6292
Min	1.5242	1.5432	1.5242	1.4289	1.5051	1.5813	1.6004
Avg	1.9782	1.9735	1.8862	1.8123	1.5883	1.9362	1.9584

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 202 / 11KV West Block

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4768	2.2862	2.2862	2.2862	2.3815	2.0386	2.0957
2	2.2862	2.2481	2.4768	2.2862	2.191	2.0005	2.2862
3	2.4768	2.2291	2.0957	2.2862	2.191	1.9814	1.9052
4	2.191	2.2481	2.2862	2.2862	2.2862	1.9624	2.2862
5	2.191	2.191	2.2862	2.2862	2.0957	1.9433	1.9052
6	2.0005	2.0957	2.2862	2.191	2.0957	2.0005	2.0957
7	2.3815	2.0195	2.2862	2.191	1.9052	2.0576	2.2862
8	2.2862	2.0576	2.2862	2.2862	1.9052	1.8671	2.2862
9	2.8578	3.2007	3.2388	2.7435	1.9052	2.6863	2.8578
10	3.4294	4.2105	3.5246	2.8387	1.9052	3.0483	3.9057
11	3.6199	3.7151	4.1914	3.1626	1.9052	3.4294	3.7151
12	3.6199	4.02	3.9057	2.934	2.0957	3.1436	4.0962
13	2.6673	3.315	3.3341	3.0483		3.2388	3.5246
14	4.1914	3.2388	3.9057	3.1436		3.6199	3.9057
15	4.1914	4.2676	3.8104	2.9531		3.6199	4.0962
16	3.4294	3.8104	3.5246	2.7625		3.8104	4.0009
17	3.8104	3.4294	3.6199	2.9531		3.4294	3.7151
18	3.7913	3.2388	3.4294	2.3815	2.0386	3.2388	2.7816
19	3.677	3.4294	3.1436	2.4768	2.0005	2.8578	2.8578
20	2.934	2.4768	2.572	2.2862	1.9814	2.2862	2.4768
21	2.3243	2.2862	2.4768	2.191	2.0386	2.2862	2.5911
22	2.2862	2.6673	2.2862	2.2862	1.9624	2.2862	2.6292
23	2.4006	2.6673	2.572	2.3815	1.9814	2.4768	2.8578
24	2.3815	2.3434	2.6673	2.3815	2.2862	2.0386	2.2862
Max	4.1914	4.2676	4.1914	3.1626	2.3815	3.8104	4.0962
Min	2.0005	2.0195	2.0957	2.191	1.9052	1.8671	1.9052
Avg	2.9126	2.9038	2.9372	2.5426	2.0606	2.6395	2.8935

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 203 / KANERI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8002	1.1431	1.0479	1.3146	.743	.7621	1.1812
2	.8002	1.1622	.9145	.9526	.743	.724	.9907
3	.7621	1.0479	.8383	.7621	.724	.7621	.9145
4	.7811	.9526	.8573	.724	.7049	.8002	.8764
5	.8192	.8192	.8002	.724	.7049	.8192	.8573
6	.8192	.9526	1.2574	.8764	.9335	.9526	1.3146
7	1.2003	1.0479	1.6766	1.2384	.9335	1.0098	1.2955
8	.9907	.9717	1.1812	.9907	.8383	.7049	1.1431
9	.9907	1.5432	1.2765	1.5051	.7049	.8954	1.7147
10	1.105	1.7909	1.0479	1.3146	.724	1.0288	1.7147
11	1.1812	1.3908	1.3527	1.2003		.7049	1.467
12	1.4289	1.3527	1.2765	1.9433		1.0098	1.5242
13	1.4098	1.4861	1.2003	1.1812		1.5432	1.2384
14	2.0957	1.448	.8383	1.2955		1.1431	1.8861
15	1.9052	1.9243	1.5051	1.2574		1.2003	1.7147
16	1.4098	1.2193	1.2193	.9526		1.086	1.2955
17	1.4289	1.467	1.6766	1.2384		1.086	1.8099
18	1.3146	1.7528	1.467	1.1431	.6668	1.105	1.4289
19	1.6004	1.5432	1.4289	1.2384	.8192	1.3336	1.3146
20	1.2574	1.2003	1.1241	1.2193	1.086	1.448	1.7337
21	1.5242	1.105	1.086	1.6004	1.0288	1.1431	1.1431
22	1.4861	.9717	1.3717	1.2384	.9907	1.2765	1.086
23	.9145	1.105	.9335	.9526	.8383	1.086	1.2193
24	.8383	1.2955	1.1431	.9335	.7049	.7621	1.2955
Max	2.0957	1.9243	1.6766	1.9433	1.086	1.5432	1.8861
Min	.7621	.8192	.8002	.724	.6668	.7049	.8573
Avg	1.2027	1.2789	1.1884	1.1582	.8170	1.0161	1.3400

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 204 / 11 KV PANCHAGANGA

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0957	2.0957	2.0957	1.5242	1.1431	1.0479	1.9052
2	2.0005	2.0576	1.9052	1.5242	1.1431	1.0479	2.0957
3	2.0957	2.0005	2.2862	1.5242	1.0479	1.0479	1.7147
4	1.4289	1.9052	1.9052	1.5242	1.0479	1.1431	1.9052
5	1.8099	1.7147	2.0957	1.5242	.9526	1.1431	2.0957
6	1.6194	2.0957	2.0957	1.5242	.9526	1.1431	2.0957
7	1.4289	2.3815	2.6673	2.2862	1.1431	1.2384	2.6673
8	1.4289	1.4289	1.3336	1.4289	1.1431	1.1431	2.4768
9	2.2862	2.0957	2.2862	1.7147	.9526	1.4289	2.6673
10	2.2862	1.7147	2.191	1.3336	.9526	2.4768	2.2862
11	2.4768	1.8099	1.8099	1.3336		1.7147	1.7147
12	2.2862	1.4289	1.2384	1.3336		1.7147	2.191
13	1.5242	2.191	1.3336	1.3336		2.0005	2.0005
14	2.6673	2.3815	1.8099	1.2384		1.9052	2.2862
15	2.6673	1.9052	1.7147	1.3336		1.9052	2.572
16	1.9052	1.9052	1.7147	1.2384		2.4387	2.2862
17	2.8578	2.0957	2.0957	1.2384		2.4768	2.2862
18	1.8099	2.6673	1.9052	1.2384		2.2862	2.3815
19	2.572	2.6673	2.0957	1.1431	1.1431	2.6673	2.6673
20	2.191	1.9052	1.9052	1.1431	1.1431	2.4768	2.3815
21	2.6673	2.2862	1.4289	1.2384	1.3336	2.4768	2.2862
22	2.7054	1.9052	1.9052	1.4289	1.1431	2.2862	2.6292
23	2.6673	1.9052	1.5242	1.2384	1.1431	2.2862	2.6673
24	1.9052	2.0957	2.4768	1.5242	1.1431	1.0479	1.9052
Max	2.8578	2.6673	2.6673	2.2862	1.3336	2.6673	2.6673
Min	1.4289	1.4289	1.2384	1.1431	.9526	1.0479	1.7147
Avg	2.1410	2.0267	1.9092	1.4130	1.0955	1.7726	2.2569



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 205 / 11KV MainRoad

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2384	1.0288	.8573	1.1622	.7811	1.0288	.8764
2	1.1812	1.105	.9145	1.1431	.8002	1.0288	.9145
3	1.1431	1.1431	.9526	1.086	.8002	.9907	.8573
4	.9145	1.2384	.9145	1.086	.7621	1.0288	.8383
5	.9907	1.3527	.8954	1.086	.7811	1.0669	.8764
6	1.086	1.105	.9526	1.1812	.8002	.9526	.8002
7	.8002	.743	.8954	1.2003	.7811	.7811	.8383
8	.8954	.8192	.8573	.8192	.8002	.7811	1.3336
9	.9717	.8764	1.0288	.9717	.7811	1.0288	1.1622
10	1.1812	.9335	1.0479	1.0479	.8002	1.1812	1.7909
11	1.467	1.0669	1.0479	.8383		1.4289	1.7528
12	1.7528	1.1431	1.3336	1.0479		1.1431	1.4289
13	1.467	.9335	1.3908	.9717		1.0669	1.6194
14	1.9052	1.1622	1.0669	.8002		1.2955	1.7147
15	1.6766	1.1622	1.3717	1.0669		1.1431	1.6766
16	1.7147	1.0098	1.3146	1.0479		1.4289	1.3527
17	1.2574	.9145	1.1431	.724		1.3336	.9526
18	1.0288	.9145	1.105	.7621		1.1812	.9145
19	.9526	.8383	1.1241	.8002		.9717	.8192
20	.9717	.8192	.8954	.7621	.724	.9145	.9145
21	.9335	.8383	.8192	.8002	.7621	.7621	.8573
22	.8192	.8192	.9335	.8002	.743	.7811	.8954
23	1.448	.7811	1.2384	.8002	1.086	.7621	1.3336
24	1.2193	.9526	.8192	1.3527	.8002	.9717	.8573
Max	1.9052	1.3527	1.3908	1.3527	1.086	1.4289	1.7909
Min	.8002	.743	.8192	.724	.724	.7621	.8002
Avg	1.2090	.9875	1.0383	.9733	.8002	1.0439	1.1407

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 206 / 11KV Industrial

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.0576	2.0195	2.1338	2.1338	1.9814	1.4098	1.7528
2	1.9814	1.9433	1.9433	2.1338	1.8671	1.4098	1.5242
3	2.0957	1.829	1.8671	2.1719	1.9433	1.448	1.7147
4	1.9814	1.7909	1.829	2.21	1.7909	1.4861	1.8671
5	1.829	1.7528	1.7528	2.21	1.7528	1.4861	2.1338
6	1.7528	1.8671	1.7909	1.9433	1.6385	1.5242	2.1338
7	1.9433	1.829	1.9433	2.0195	1.6004	1.6004	1.7528
8	1.9052	1.5623	1.7909	1.7528	1.4098	1.448	1.7147
9	2.5149	2.4768	2.4006	1.9052	1.4098	2.0195	2.2862
10	2.8578	2.6673	2.6673	2.2862	1.3336	2.4768	2.6673
11	2.934	3.0483	3.2388	2.4006	1.3336	3.0102	2.3624
12	2.8959	2.3624	2.8197	2.2862	1.3717	2.8578	2.1719
13	2.4006	2.2481	2.7054			2.5911	2.1338
14	2.8197	2.6673	2.4387	2.0195		2.4768	2.6673
15	2.5911	2.4387	2.5149	2.0957		2.6673	2.7816
16	2.7054	2.7816	2.6292	2.2862		2.8959	2.0957
17	2.6673	1.9052	2.553	1.7909		2.553	2.5149
18	2.2862	2.3243	2.2862	1.7528	1.3717	2.2862	2.0957
19	2.1719	2.2862	1.9814	1.5432	1.3717	2.0957	2.2862
20	1.5242	1.3336	1.6385	1.448	1.3717	1.5242	1.4861
21	1.829	1.6766	1.829	1.7909	1.3717	1.6766	1.7909
22	1.6385	1.6385	1.6766	1.7909	1.448	1.7909	1.7528
23	1.829	2.1719	1.9052	1.8671	1.4098	1.9052	1.9814
24	1.8671	2.0576	2.0957	2.2862	1.9433	1.4098	1.829
Max	2.934	3.0483	3.2388	2.4006	1.9814	3.0102	2.7816
Min	1.5242	1.3336	1.6385	1.448	1.3336	1.4098	1.4861
Avg	2.2116	2.1116	2.1846	2.0054	1.5643	2.0021	2.0624

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 207 / 11 KV UJALAIWADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5144	.5144	.5335	.5335	.4954	.5335
2	.5335	.4954	.5335	.5335	.5144	.4763	.5335
3	.5144	.4572	.4954	.5144	.5144	.4572	.5335
4	.5144	.4572	.5335	.5144	.5525	.4763	.5335
5	.5525	.4572	.5525	.5144	.5525	.4954	.5335
6	.6287	.5335	.6097	.5716	.5716	.5716	.6097
7	.6478	.5906	.6097	.5906	.5906	.5716	.6287
8	.5525	.5144	.5716	.5716	.5525		.5335
9	.5906	.4954	.5335	.5335	.5335	.5144	.4763
10	.6097	.5716	.6859	.5906	.4572	.6097	.6478
11	.6478	.6097	.7049	.6097	.4763		
12	.6287	.6478	.7811	.6287			
13		.5716	.6859	.5906			
14		.4954	.6478	.5525			
15		.4954	.6859	.5716			
16		.5335	.6287	.6287			
17		.5716	.6478	.6097			
18		.6287	.6478	.6668	.7049		
19	.724	.7811	.743	.743	.7049	.8383	.7621
20	.743	.8192	.7811	.743	.724	.724	.8192
21	.7621	.7811	.743	.7049	.7049	.6668	.7621
22	.6668	.6668	.6859	.6859	.6478	.6478	.6859
23	.5906	.5716	.6287	.5906	.5716	.5716	.5906
24	.5716	.5335	.5716	1.4128	.5335	.4954	.5335
Max	.7621	.8192	.7811	1.4128	.724	.8383	.8192
Min	.5144	.4572	.4954	.5144	.4572	.4572	.4763
Avg	.6118	.5747	.6343	.6336	.5800	.5741	.6073

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 208 / KANERI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1143	.1143	1.7147	1.7147	.362	.1334	.1334
2	.1143	.1143	1.7528	1.7147	.4763	.1334	.1334
3	.1143	.1143	1.8099	1.7147	.4763	.1334	.1334
4	.1143	.1143	1.829	1.7147	.5335	.1524	.1334
5	.1143	.1334	1.8671	1.7337	.5525	.1334	.1334
6	.1334	.1334	2.0767	1.9624	.6859	.1524	.1524
7	.1334	.1524	2.3624	2.3053	.8192	.1715	.1524
8	.1524	.1524	2.4958	2.6101	.8192	.1334	.1524
9	.1524	.1524	2.3243	2.6101	.8573	.1715	.1715
10	2.3243	.1715	.1334	.1334	1.6766	2.2481	2.0386
11	2.5149	.1524	.1334	.1715		1.3146	2.7816
12	2.5149	.1334	.1334	.1334		2.915	2.8387
13	2.4958	.1524	.1524	.1334		3.0293	2.7054
14	2.4958	.1334	.1143	.1334		2.4387	2.7244
15	2.5339	.1524	.1334	.1143		2.7816	2.6482
16	2.6673	.1524	.1334	.1524		2.6292	2.5911
17	2.553	.1715	.1334	.1715		2.6673	2.4387
18	.1334	.1334	.1524	.1905	.0572	.1715	.1143
19	.1524	.1524	.1334	.1905	.1334	.1334	.1143
20	.1334	.1334	.1334	.1524	.1715	.1334	.1334
21	.1143	.1334	.1334	.1524	.1715	.1334	.1334
22	.1334	.1334	.1334	.1334	.1524	.1334	.1334
23	.1143	.1524	.1524	1.4548	.1524	.1334	.1334
24	.1334	.1143	1.6004	1.5775		.1334	.1334
Max	2.6673	.1715	2.4958	2.6101	1.6766	3.0293	2.8387
Min	.1143	.1143	.1143	.1143	.0572	.1334	.1143
Avg	.9232	.1397	.9058	.9615	.5061	.9296	.9566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144017 / 33/11 KV GOKULSHIRGAON

Feeder No / Name : 209 / UJALAIWADI SHETI PUMP  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8383	.0762	.0762	.0381	.9717	.9907
2	.8573	.8383	.0762	.0762	.0381	.9717	1.0288
3	.8573	.8383	.0762	.0762	.0381	.9717	1.0479
4	.8954	.8383	.0762	.0762	.0381	1.0479	
5	.9526	.8383	.0762	.0762	.0381	1.1431	1.0669
6	1.0288	1.3336	.0953	.0953	.0572	1.5242	1.3336
7	1.6766	1.5623	.0953	.1143	.0953	1.7909	1.5432
8	1.8099	1.6004	.1143	.1143	.1334	1.3717	1.8099
9	1.6956	1.5623	.0572		.1524	1.6004	1.7337
10	.0762	1.5623	1.2955	1.3146	.1334	.0953	.0762
11	.0762	1.6194	1.7337	1.9814	.1143	.0572	.0762
12	.0953	1.4861	1.6766	1.829	.1143	.0762	.0762
13	.0953	1.3336	1.5242	1.6766		.0762	.0762
14	.0381	1.2765	1.5051	1.6004		.0953	.0762
15	.0572	1.2955	1.5432	1.5242		.0572	.0762
16	.0572	1.5242	1.6004	1.5051		.0762	.0762
17	.0572	1.4861	1.6766	1.7528		.1143	.0953
18	.0953	.0953	.0953	.0572	.1143	.1334	.0953
19	.0762	.1143	.0953	.0953	.0953	.1143	.1143
20	.0953	.0953	.0953	.0953	.0953	.1143	.0953
21	.0953	.0953	.0762	.0762	.0953	.0953	.0953
22	.0762	.0953	.0762	.0762	.0953	.0572	.0953
23	.0762	.0762	.0953	.0762	.0953	.0762	.0762
24	.8764	.8192	.0762	1.6834	.0381	.9717	.9145
Max	1.8099	1.6194	1.7337	1.9814	.1524	1.7909	1.8099
Min	.0381	.0762	.0572	.0572	.0381	.0572	.0762
Avg	.5247	.9677	.5795	.6978	.0852	.5668	.5509

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 201 / 11KV Randeviwadi Ag  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.7101	.0572	.0486	.0572	1.8399	1.587	
2	1.6598	.0572	.0486	.0572	1.7901	1.5546	1.749
3	1.6095	.0572	.0486	.0572	1.8107	1.5546	1.7661
4	1.7404	.0572	.0486	.0572	1.8399	1.6032	1.749
5	1.7901	.0572	.0486	.0572	1.8399	1.6518	1.7318
6	1.9662	.0572	.0486	.0572	1.917	1.7652	2.0062
7	2.1214	.0572	.0486	.0572	1.9662	2.1052	2.1262
8	2.1376	.0572	.0486	.0572	2.1605	2.2348	2.5034
9	1.917	.0572	.0486	.0572	2.1125	2.2348	2.4691
10	.0572	2.4926		2.4691	.0566	.0486	.0566
11	.0572		3.035	2.6543		.0572	.0566
12	.0572	2.8502	3.035	2.8807		.0572	.0566
13	.0572	2.8664	2.8807	2.9264		.0572	.0566
14	.0572	2.7206	2.6749	2.8704	.0648	.0572	.0566
15	.0572	2.6235	2.8292	2.6092	.0648	.0572	.0566
16	.0572	2.7206	2.8292	2.451	.0648	.0572	.0566
17	.0572	2.7206	2.5549	2.3746		.0572	.0566
18	.0572	.0486	.0572	.0566	.0648	.0572	.0566
19	.0572	.0486	.0572	.0566	.0648	.0572	.0566
20	.0572	.0648	.0572	.0566	.0648	.0572	.0566
21	.0572	.0648	.0572	.0566	.0648	.0572	.0566
22	.0572	.0038	.0572	.0566	.0648	.0572	.0566
23	.0572	.0486	.0572	.0566	.0486	.0572	.0566
24	1.7101	.0572	.0486	1.6476	1.7901	1.6194	
Max	2.1376	2.8664	3.035	2.9264	2.1605	2.2348	2.5034
Min	.0572	.0038	.0486	.0566	.0486	.0486	.0566
Avg	.7985	.8629	.8986	.9891	.9845	.7793	.7679

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 202 / M Sangaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7133	.6516	.6173	.8488	.7522	.6516	
2	.6584	.6154	.6173	.8299	.7059	.6173	
3	.6584	.6154	.6687	.8299	.7133	.6173	.811
4	.7133	.7602	.6859	.8488	.724	.6859	.8865
5	.8145	.8507	.7716	.9054	.7522	.823	.9808
6	1.0517	1.0498	.9602	1.0562	.8939	1.0631	1.1883
7	1.0166	1.0136	1.0288	1.0829	.9465	1.0288	1.0456
8	.9465	.8688	.8745	.961	.8505	.5658	.9709
9	.8505	.8507	.7202	.8413	.7522	.823	.8507
10	.8145	.8145	.2743	.8413	.8145	.7716	.8059
11	.8326		.8779	.6584	.6173	.7133	.7602
12	.8326	.7888	.8688	.8059	.6859	.8596	.7602
13	.8326	.823	.8501	.7522	.6859	.8413	.7602
14	.8326	.823	.8501	.8145	.6173	.7577	.8145
15	.8507	.823	.8413	.8145	.6173	.8779	.9036
16	.8688	.7202	.8413	.724	.6001	.8962	.8413
17	.8507	.7202	.7392	.7316		.8413	.8939
18	.7964	.7888	.8417	.8939	.7888	.9593	.9465
19	1.086	1.0288	1.0903	.9465	.9259	1.1088	1.0402
20	1.1041	1.1145	1.1203	1.0402	1.1317	1.2136	1.0923
21	.9231	.9945	1.1203	.9991	1.1317	1.1883	1.0517
22	.905	.9602	1.094	.8939	1.0288	1.1694	.8939
23	.905	.8916	.8383	.8505	.8573	1.0642	.8939
24	.7133	.8507	.6859	.8744	.7973	.6859	
Max	1.1041	1.1145	1.1203	1.0829	1.1317	1.2136	1.1883
Min	.6584	.6154	.2743	.6584	.6001	.5658	.7602
Avg	.8571	.8443	.8283	.8685	.7996	.8677	.9139

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 203 / Sulkud AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	1.6448		1.8564	.0754	.0648	
2	.0754	1.6278		1.8896	.0754	.0486	.0572
3	.0754	1.6278		1.8679		.0486	.0572
4	.0754	1.6617		1.9006	.0754	.0486	.0572
5	.0754	1.7126		1.989	.0943	.0648	.0762
6	.0943	2.0178		2.1136	.0943	.0648	.0762
7	.0943	2.2891		2.3371	.0943	.0648	.0762
8	.0754	2.323		2.4697	.0754	.0648	.0762
9	.0754	2.1365		2.2708	.0754	.0648	.0762
10	2.8147	.0762		.0762	2.1862	2.4291	2.2834
11	3.12	.0648		.0754	2.8016	3.2047	2.9321
12	3.086	.0648	.0953	.0754	3.0864	3.2556	2.9874
13	2.9673	.081	.0953	.0754	2.7044	3.1369	2.9167
14	2.8487	.0648	.0953	.0754	2.6073	2.9843	2.8395
15	2.7808	.0648	.0953	.0754	2.6397	3.0514	2.7041
16	2.6113	.081	.0953	.0754	2.6235	2.9504	2.6246
17	2.4926	.081	.0953	.1132		2.9172	2.5777
18	.0762	.081	1.7532	.1132	.0972	.0762	.1132
19	.0762	.081	.0953	.0943	.081	.0953	.0943
20	.0762	.081	.0762	.0943	.0648	.0953	.0943
21	.0762	.081	.0762	.0943	.081	.0762	.0943
22	.0762	.0648	.0762	.0943	.081	.0762	.0943
23	.0762	.0648	.0762	.0943	.081	.0762	.0943
24	.0754	1.6617		1.8275	.0754	.0648	
Max	3.12	2.323	1.7532	2.4697	3.0864	3.2556	2.9874
Min	.0754	.0648	.0762	.0754	.0648	.0486	.0572
Avg	.9988	.8223	.2271	.9062	.9032	1.0427	1.0456



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 204 / 11 KV LINGNOOR (VG)

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1132	.0905	.1029	.1132	.0943	.1029	
2	.1132	.0724	.0857	.0943	.0943	.0857	.1143
3	.1132	.0724	.0857	.0934	.0943	.0857	.1143
4	.1132	.1267	.1029	.0934	.0943	.1029	.1132
5	.1132	.1448	.12	.1132	.1132	.12	.132
6	.168	.1448	.1372	.1334	.132	.1372	.1715
7	.168	.1448	.1372	.1334	.1494	.12	.1524
8	.1494	.1086	.1029	.132	.1494	.1029	.112
9	.1132	.0905	.0857	.1307	.0943	.0857	.0934
10	.0905	.0905	.0686	.1097	.1132	.0857	.0754
11	.0848	.0857	.0934	.0943	.0686	.1109	.0943
12	.1086	.1029	.0732	.0943	.0857	.1109	.0943
13	.1267	.1029	.0924	.0943	.0857	.1109	.1132
14	.1086	.1029	.0934	.0914	.0857	.1132	.0943
15	.0905	.1029	.1132	.0943	.0857	.112	.1132
16	.1267	.1029	.112	.0943	.0857	.0924	.1132
17	.0905	.1029	.112	.1132		.1086	.1132
18	.0905	.1029	.1307	.1132	.0857	.1294	.1132
19	.1448	.1543	.1494	.168	.12	.1867	.1867
20	.181	.1886	.1886	.168	.1715	.2286	.1867
21	.181	.1543	.1905	.168	.1715	.1905	.1867
22	.1629	.1543	.1715	.168	.1543	.1905	.1867
23	.1267	.12	.1143	.132	.12	.1524	.168
24	.132	.1086	.1029	.1132	.132	.1029	
Max	.181	.1886	.1905	.168	.1715	.2286	.1867
Min	.0848	.0724	.0686	.0914	.0686	.0857	.0754
Avg	.1254	.1155	.1153	.1189	.1122	.1237	.1292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144067 / 33/11 KV K'SANGAON

Feeder No / Name : 205 / 11 KV RTO Check Post  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0189	.0191		.0191	.0189		
2	.0189	.0191		.0191	.0189		.0191
3	.0189	.0191		.0191	.0189		.0191
4	.0189	.0191		.0191	.0189		.0191
5	.0189	.0191		.0191	.0189		.0191
6	.0189	.0191		.0191	.0189		.0191
7				.0191	.0189		
8					.0189		
19	.0191			.0189		.0191	.0189
20	.0191		.0191	.0189		.0191	.0189
21	.0191		.0191	.0189		.0191	.0189
22	.0191		.0191	.0189		.0191	.0189
23	.0191		.0191	.0189		.0191	.0189
24	.0189	.0191		.0191	.0189		
Max	.0191	.0191	.0191	.0191	.0189	.0191	.0191
Min	.0189	.0191	.0191	.0189	.0189	.0191	.0189
Avg	.0190	.0191	.0191	.0190	.0189	.0191	.019

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 201 / 11KV Arya

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8111	1.9239	1.3146	1.6827	1.8473	.9145	1.2039
2	1.9231	2.0748	1.8099	1.8484	1.6834	.7145	1.7193
3	1.848	2.1879	1.9909	1.8107	1.4243	.5335	1.6461
4	1.7194	2.1125	2.009	1.6095	1.2793	.5716	1.6817
5	1.6655	1.8861	2.0513	1.2452	1.2266	.4938	1.0802
6	1.7372	1.7353	1.9774	1.1706	1.0513	.6811	1.8107
7	1.6297	1.3203	1.6655	1.6827	.9503	.5906	1.8473
8	1.4752	1.5729	1.6651	1.6461	.2401	.4755	1.262
9	2.3525	1.9616	1.9978	2.6406	.2734	1.9993	1.8298
10	2.3815	1.9418	1.4712	2.7349	.2458	2.0538	2.6139
11	2.6292	1.9605	1.4146	2.7625	.2294	2.1502	2.894
12	2.8578	2.5393	1.848	2.7435	.2362	1.6804	2.7633
13	2.452	2.3152	1.3717	1.4861	.1966	2.2068	2.5393
14	2.2822	2.1658	1.7924	1.9616	.1844	2.2634	2.4272
15	2.6482	1.643	1.905	2.1125	.2629	2.1658	2.2405
16	2.037	2.3152	2.2445	2.0559	.2286	1.6289	2.2032
17	2.3152	2.2634	2.037	1.9616	.5121	2.1502	2.2405
18	2.1658	2.7054	1.9239	1.3676	.4755	1.8673	2.2405
19	2.0165	1.7737	1.8107	1.7364	.4755	1.8656	2.1879
20	2.0538	2.0911	1.7193	1.5181	.333	1.9044	2.6972
21	2.2634	1.8296	1.7918	1.5729	.3403	1.3289	2.7726
22	1.9239	1.9589	1.6461	1.5546	.4755		2.0936
23	2.1691	2.7538	1.6461	1.4922	.4481	1.258	2.037
24	1.6832	1.7924	1.9281	1.5089	1.7558	.6859	1.0311
Max	2.8578	2.7538	2.2445	2.7625	1.8473	2.2634	2.894
Min	1.4752	1.3203	1.3146	1.1706	.1844	.4755	1.0311
Avg	2.0850	2.0344	1.7930	1.8294	.6823	1.3993	2.0443

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 202 / 11 KV Managal Metal

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4115	1.2209	.4298	.5548	.2763	.1486	.4294
2	.3841	1.2071	.4298	.5548		.1585	.4763
3	.3506	1.0709	.4287	.4755	.2286	.1882	.4763
4	.333	1.0151	.3658	.4755	.2012	.1684	.4925
5	.3224	.9869	.3048	.4557	.1829	.1981	.5601
6	.3172	1.0136	.4207	.4755	.1981	.2576	.4881
7	.9536	.9069	.8345	.9267	.202	.8779	1.0292
8	1.0494	1.0974	1.1279	1.5565	.1783	1.0715	1.2654
9	1.2929	1.4746	1.6651	1.1469	.2	1.2717	1.3735
10	1.9185	1.8671	1.8551	1.3413	.1905	1.8099	2.2405
11	1.8461	2.0165	1.7896	1.8656	.2136	2.0328	2.2779
12	2.4272		1.9204	2.1253	.2498	1.5432	1.8298
13	2.009	2.0538	1.4582		.1829	1.3279	2.0165
14	2.0883	1.7924	1.4352	1.9204	.1414	1.6301	2.0165
15	2.2361	1.7177	1.6478	2.0452	.1313	1.5775	2.0538
16	2.0668	1.643	1.4563	1.8983	.1153	1.6476	1.9791
17	1.8671	1.5089	1.4632	1.7364	.3909	1.5604	1.8671
18	1.7924	1.2003	1.5729	1.25	.3414	1.1111	1.6124
19	1.4937	1.6289	1.6461	1.0494	.3909	1.1279	1.6651
20	1.0456	.5864	1.3435	.5973	.1543	1.2967	.6811
21	.7362	.5152	.5335	.3906	.1818	.6857	.6462
22	.6539	.4664	.5335	.4191	.1783		.5967
23	.5335	.5647	.5239	.3984	.1715	.4527	.4954
24	.5144	.4207	.583	.5335	.2953	.1715	.5049
Max	2.4272	2.0538	1.9204	2.1253	.3909	2.0328	2.2779
Min	.3172	.4207	.3048	.3906	.1153	.1486	.4294
Avg	1.1935	1.2163	1.0737	1.0519	.2172	.9702	1.2114

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 203 / 11 KV KORGAONKAR

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6908	.6979	.724	.7167	.6722	.7167	.7049
2	.7282	.6979	.724	.7167	.6722	.7167	.724
3	.6535	.6979	.6859	.7167	.6908	.7167	.724
4	.6722	.6979	.6979	.7167	.6838	.7167	.6979
5	.6535	.6979	.6859	.6413	.6653	.7167	.6668
6	.6348	.679	.6979	.6036	.6908	.7167	.6668
7	.7733	.6602	.9145	.6602	.6535	.7545	.743
8	.6602	.7922	.8002	.5853	.7545	.7167	.8192
9	.8865	.7922	.9335	.679	.7545	.8676	.8764
10	.9717	.9335	.9808	.6287	.9054	.9997	1.0456
11	1.0751	.9709	.8676	.724	.9145	1.0562	1.1203
12	.9145	.9431	.8676	.6859	.7811	.9431	1.0456
13	.8954	.9709	.9054	.8488	.8002	.9808	1.0456
14	.9431	.9709	.9619	.9145	.8676	1.0185	1.1203
15	1.086	1.0082	.8865	.9335	1.0185	.8775	1.1203
16	1.0751	1.1203	.9431	.9145	1.0751	1.1203	1.1317
17	.9709	.9907	.9054	.8954	.9511	1.1317	.9709
18	.9709	.9431	.8488	.8865	.9145	.9808	.9619
19	.9709	.9808	.7922	.6602	.8779	.9242	.9431
20	.8962	.9808	.7545	.6602	.8589	.9054	.7545
21	.9808	.7733	.7167	.679	.7167	.8865	.7545
22	.8676	.7049	.679	.6979	.6722		.6979
23	.7167	.7049	.679	.6535	.6602	.6602	.6602
24	.6224	.679	.679	.8676	.6979	.679	.724
Max	1.086	1.1203	.9808	.9335	1.0751	1.1317	1.1317
Min	.6224	.6602	.679	.5853	.6535	.6602	.6602
Avg	.8463	.8370	.8055	.7369	.7896	.8610	.8633

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 204 / 11 KV Silver Zone

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1098	2.1125	2.1125	1.9993	1.8298	1.8427	2.037
2	2.0698	2.1125	2.1125	1.9993	1.7924	1.9022	2.0748
3	1.9959	2.1125	2.0911	1.9993	1.7924	1.8823	2.0748
4	1.9791	2.1125	2.0748	1.9993	1.701	1.8823	1.9978
5	2.0725	2.0748	1.9774	1.9239	1.6832	1.8625	1.905
6	2.0538	2.037	2.1125	1.8861	1.7372	1.9204	2.0182
7	2.0165	1.9616	2.0748	1.7558	1.6991	1.9387	1.8861
8	1.9978	2.2257	2.0936	1.7737	1.46	1.8656	1.7924
9	2.1879	2.3577	2.32	1.6461	1.643	2.1879	2.1125
10	2.6863	2.4272	2.4143	2.1529	1.7551	2.3577	2.2405
11	2.6673	2.6139	2.32	2.2481	1.8671	2.3011	2.3899
12	2.6292	2.3899	2.452	2.191	1.8671	2.3388	2.1845
13	2.4143	2.4272	2.2634	1.9427	1.829	2.2068	2.2405
14	2.4958	2.4272	2.3954	2.0936		2.3954	2.3152
15	2.5339	2.3525	2.3954	2.1529	2.2862	2.3712	2.3152
16	2.5339	2.4272	2.5086	2.0576	2.3045	2.452	2.3899
17	2.5019	2.2862	2.2634	2.0386	2.3045	2.4143	2.4272
18	2.4272	2.3434	2.2257	1.8861	2.3045	2.2481	2.2822
19	2.3525	2.3577	2.1879	1.9616	2.2862	2.3243	2.2634
20	2.3339	2.1313	2.1125	1.8861	1.7718	2.1125	2.1125
21	2.3388	2.0559	2.0748	1.6975	1.9204	2.1125	2.1125
22	2.2634	2.1125	2.1879	1.773	1.7187		2.037
23	2.1502	2.2068	2.0748	1.8298	2.1125	2.1125	2.0748
24	2.0538	2.0748	2.0748	2.037	1.8107	1.8656	2.0182
Max	2.6863	2.6139	2.5086	2.2481	2.3045	2.452	2.4272
Min	1.9791	1.9616	1.9774	1.6461	1.46	1.8427	1.7924
Avg	2.2861	2.2392	2.2050	1.9555	1.8903	2.1260	2.1376

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 205 / 11 kV VILSON ROOFING  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.4355	3.9986	3.4894	4.1118	3.4915	2.7801	4.0741
2	3.6035	4.3439	3.7342	4.4201	3.7346	2.7801	4.357
3	3.2895	4.4201	3.7723	4.489	3.9769	2.8166	4.3381
4	3.4004	4.382	3.4894	4.382	4.0929	2.8166	3.9609
5	3.3608	4.2295	3.0744	4.3439	4.2627	2.5941	3.678
6	3.2819	4.0771	3.5271	4.2295	4.5268	2.3487	3.263
7	2.8858	3.8666	4.0929	3.4894	3.4728	2.1948	3.4728
8	2.4272	2.7349	3.8089	2.5463	2.516	2.1384	2.9687
9	3.1927	2.7915	3.4728	3.4705	2.2862	3.5837	3.3608
10	3.2579	2.9874	4.4324	3.6214	2.5019	4.1118	3.5475
11	2.9721	3.3608	4.5268	3.7157	1.7703	2.3577	3.6408
12	3.6199	3.5848	5.144	3.3341	2.3285	3.3573	4.481
13	4.0175	3.3608	3.2674	3.2007	.6441	2.6783	4.1076
14	3.4139	3.1741	4.1307	3.6199			4.1823
15	3.9043	3.5475	4.3759	4.225		3.6969	4.481
16	3.678	2.8006	3.9609	3.6031	.7964	3.2487	4.1076
17	3.4355	3.7723	3.4328	3.6406	.9659	3.2442	3.6408
18	3.7342	3.8855	4.039	4.0703	.9717	3.546	4.2816
19	3.9209	3.2819	4.1914	3.5475	1.8107	3.9232	4.225
20	3.4355	2.7721	3.546	3.1741	1.1797	3.006	3.2065
21	3.3951	2.8292	2.4897	3.1499	2.2314	2.9424	3.3951
22	3.9986	3.1687	3.3008	3.3951	2.3411		3.1741
23	3.6214	2.7349	3.4894	3.8836	2.652	3.9043	3.5648
24	3.1741	3.0556	2.2262	5.3532	3.5475	2.8292	2.8829
Max	4.0175	4.4201	5.144	5.3532	4.5268	4.1118	4.481
Min	2.4272	2.7349	2.2262	2.5463	.6441	2.1384	2.8829
Avg	3.4357	3.4650	3.7090	3.7924	2.5501	3.0409	3.7663

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144073 / 33/11 KV 5 STAR MIDC

Feeder No / Name : 206 / 11KV Mahalaxmi

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.1098	1.8861	.8413	.9846	.5243	.4755	.6478
2	2.2445	2.4143	1.8099	.9717	.4401	.4755	1.4969
3	2.32	2.4897	2.3529	.9846	.381	.4755	1.4815
4	2.0538	2.452	2.5318	.9328	.333	.4557	1.5384
5	1.9035	2.3011	2.584	.9328	.3048	.4321	1.4449
6	1.8111	2.2257	1.4266	.9069	.3172	.5868	2.6595
7	2.6595	2.1502	1.9239	.9808	.2256	1.4175	2.2445
8	1.4706	.2881	.7811	1.6095	.1406	.4755	.5275
9	2.7349	1.5546	1.6617	1.0136	.2397	2.6406	3.3573
10	3.7913	2.6139	1.8296	1.6461	.2749	2.2779	2.9874
11	4.1495	4.0329	1.8861	1.8484	.2591	2.6406	4.2196
12	3.7532	3.2065	1.9427	1.4784	.2138	2.7073	3.9769
13	3.8295	3.0247	1.3256	1.5339	.285	3.131	2.9127
14	3.4894	3.4541	1.8107	1.7556	.2865	3.2065	3.3234
15	4.0364	3.8836	1.9243	1.7926	.3498	2.9047	4.0889
16	1.9433	1.2696	1.307	1.1096	.3239	2.0351	3.7342
17	2.2405	2.8292	2.3577	1.3169		3.2442	3.2114
18	2.7073	3.1055	2.2634	.8383		2.8292	2.6406
19	3.5475	3.315	2.2257	1.0898	.3521	3.5627	1.8484
20	1.9418	2.8769	1.9239	1.1443	.4359	2.8858	2.3388
21	2.7161	1.307	1.2616	.5106	.381	.9189	1.7177
22	1.9616	2.3388	.6287	.503	.5548		2.8292
23	2.1691	1.4377	.9214	.4978	.9556	2.1879	2.8669
24	.5898	.2881	.5967	1.0105	.4649	.4572	.8817
Max	4.1495	4.0329	2.584	1.8484	.9556	3.5627	4.2196
Min	.5898	.2881	.5967	.4978	.1406	.4321	.5275
Avg	2.5906	2.3644	1.6716	1.1414	.3656	1.8445	2.4573



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 201 / 11 KV Vardhaman Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.5911	2.0957	1.8671	1.9052	1.8671	1.2193	1.9052
2	2.2862	1.9814	2.0005	1.7147	1.6766	1.1812	1.7147
3	2.2481	1.9433	1.7147	1.6956	1.448	1.1812	1.7147
4	2.2481	1.9052	1.8099	1.6956	1.3336	1.2193	1.7147
5	1.9814	1.8671	1.8671	1.7528	1.2003	1.2193	1.7147
6	1.6766	1.7909	1.9052	1.7909	1.467	1.2574	1.7147
7	1.829	1.829	1.829	1.7147	1.4861	1.2574	1.4098
8	1.2574	1.7528	1.3336	1.6575	1.2955	1.3717	1.2384
9	1.848	2.0957		1.5432	1.1812	1.9814	1.7147
10	2.3815	2.8959	2.6482	1.9814	.4382	2.0195	2.8578
11	2.8959	2.934	3.0864	2.553	.4572	2.5911	2.5149
12	2.8387	2.1529	2.9721	2.4768	.4382	2.7816	1.9052
13	2.4577	2.0386	1.8861	2.0957	.4954	2.6482	2.7625
14	3.2388	2.5911	2.553	1.9052	.4954	2.0576	3.0864
15	3.1245	2.8959	2.5149	2.3624		1.8099	2.3434
16	3.3532	2.4768	2.7816	2.6673	.4572	2.8769	2.3434
17	2.4768	2.4387	1.9052	2.4006		2.3815	2.5339
18	1.7909	1.7147	1.7528	2.0957	1.2574	2.0957	1.7909
19	2.3243	2.5339	1.7147	2.3434	1.2574	1.8671	2.0386
20	2.0957	1.6766	2.0767	2.0957	1.2574	1.848	1.9814
21	1.7147	2.0957	1.8099	2.0576	1.2193	2.0767	1.9624
22	2.21	2.4196	2.3815	2.3053	1.2574	1.8099	2.4768
23	2.5149	2.4006	1.9433	2.1719	1.2574	2.0386	2.4006
24	2.4387	2.2862	1.7718	1.9433	1.9052	1.2193	2.5339
Max	3.3532	2.934	3.0864	2.6673	1.9052	2.8769	3.0864
Min	1.2574	1.6766	1.3336	1.5432	.4382	1.1812	1.2384
Avg	2.3259	2.2005	2.0924	2.0386	1.1431	1.8337	2.0989

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 202 / 11 KV Mather & Platt  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.448	1.5242	1.3908	1.5242	1.3717	1.2574	1.4861
2	1.448	1.4861	1.3336	1.3717	1.3336	1.2193	1.448
3	1.4289	1.4098	1.2955	1.3336	1.2955	1.2193	1.448
4	1.4098	1.448	1.2955	1.2955	1.2574	1.2193	1.448
5	1.4289	1.4861	1.3336	1.4098	1.2574	1.2574	1.448
6	1.4098	1.4098	1.3717	1.4289	1.2574	1.2574	1.467
7	1.448	1.448	1.467	1.4289	1.2955	1.2193	1.6385
8	1.2193	1.6385	1.7528	1.3717	1.2574	1.2574	1.6385
9	2.21	2.1719	1.8861	1.448	1.3146	1.7909	1.9243
10	2.0386	2.3434	2.191	1.8671	1.2193	2.191	2.191
11	2.4768	2.21	2.2862	1.829	1.2955	2.2862	2.3624
12	2.0386	2.21	2.1529	1.7528	1.2955	2.0195	1.9814
13	2.0195	2.0767	1.8861	1.7909	1.2765	1.9624	2.0576
14	2.3815	2.3434	2.21	1.829	1.2765	2.21	2.1148
15	2.1338	2.1338	2.4006	1.7528	1.2384	2.0957	2.1148
16	2.2481	2.1529	1.9243	1.7909	1.2574	2.1719	2.3434
17	2.191	2.1338	2.1719	1.7147		2.0957	2.3053
18	2.0957	2.0005	1.6194	1.448	1.2955	1.6766	1.9433
19	1.8671	1.829	1.4098	1.2765	1.2955	1.6194	1.7147
20	1.7147	1.2955	1.3336	1.2574	1.2955	1.3717	1.448
21	1.5242	1.3717	1.2955	1.2955	1.2955	1.3146	1.3336
22	1.6766	1.3908	1.4289	1.2574	1.2955	1.4861	1.6194
23	1.7147	1.4098	1.5242	1.3717	1.2955	1.6766	1.6194
24	1.448	1.6385	1.3908	1.4861	1.3908	1.2574	1.5242
Max	2.4768	2.3434	2.4006	1.8671	1.3908	2.2862	2.3624
Min	1.2193	1.2955	1.2955	1.2574	1.2193	1.2193	1.3336
Avg	1.7925	1.7734	1.6813	1.5138	1.2897	1.6305	1.7758

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 204 / Tamgoan VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1812	1.1431	1.1431	1.1812	1.0669	1.105	1.1812
2	1.0669	1.0669	1.0479	1.1431	.9907	1.0669	1.1431
3	1.0669	1.0288	.9907	1.105	.9907	.9907	1.1431
4	1.0669	1.105	.9907	1.1812	.9907	.9907	1.1431
5	1.105	1.1812	.9526	1.1622	1.0288	1.105	1.2193
6	1.2384	1.2574	1.2765	1.2384	1.2574	1.2574	1.3336
7	1.467	1.448	1.3908	1.3527	1.3336	1.5242	1.4289
8	1.5242	1.3336	1.2574	1.2765	1.3527	1.4861	1.3717
9	1.3527	1.2955	1.2765	1.2574	1.2384	1.3717	1.3336
10	1.3908	1.3146	1.2574	1.2193	1.105	1.448	1.3908
11	1.3717	1.3908	1.2765	1.3717	1.105	2.0957	2.0195
12	1.3336	1.3717	1.3717	1.4098	1.0479	2.21	2.1338
13	1.8099	1.1431	1.2765	1.3336	1.1241	2.0957	1.9052
14	1.8099	1.105	1.2003	1.1812	1.1431	1.9814	2.0767
15	1.9814	1.2193	1.2384	1.2955	1.1241	2.0576	2.1148
16	2.0576	1.2574	1.2574	1.2574	1.1431	2.191	2.1148
17	2.0195	1.3336	1.2384	1.3717		2.3434	2.0957
18	2.1338	1.4098	1.3717	1.3908	.724	2.1338	2.1719
19	1.6004	1.5432	1.6004	1.5242	1.3717	1.6956	1.6766
20	1.6385	1.7147	1.6766	1.5813	1.6004	1.7718	1.7528
21	1.6004	1.5623	1.5242	1.448	1.5242	1.6956	1.6766
22	1.5242	1.448	1.448	1.448	1.4861	1.5432	1.5242
23	1.3717	1.3146	1.2574	1.3336	1.3717	1.448	1.448
24	1.3336	1.2955	1.1812	1.1241	1.1812	1.1812	1.2193
Max	2.1338	1.7147	1.6766	1.5813	1.6004	2.3434	2.1719
Min	1.0669	1.0288	.9526	1.105	.724	.9907	1.1431
Avg	1.5019	1.3035	1.2709	1.2995	1.1870	1.6162	1.6091

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 205 / 11 KV Patel Petro feeder      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3717	1.448	1.1812	.9907	.9526	.6859	1.1431
2	1.3717	1.4098	1.1812	1.1431	.9907	.6859	1.105
3	1.2955	1.3717	1.1431	1.2955	.9907	.6859	1.086
4	1.105	1.448	1.105	1.2384	1.0288	.724	1.086
5	.9526	1.448	1.0479	1.1812	1.0669	.7621	1.086
6	1.0669	1.3717	1.2955	1.2003	.6478	.8002	1.086
7	1.086	1.4098	1.2955	1.2193	.6668	.8764	1.2955
8	1.0669	1.1812	1.2765	1.2193	.6668	1.0288	1.6004
9	1.6575	2.0957	2.3243	2.0576	.6859	1.4098	2.4387
10	1.9433	2.2862	2.1719	2.1719	.6478	2.4577	2.553
11	2.0957	2.3815	2.4768	1.7147	.6668	2.4768	2.1719
12	1.4861	1.7147	1.6766	1.9433	.6668	2.572	2.572
13	1.7147	1.6385	1.5242	1.9052	.5906	1.8099	1.8671
14	1.9433	1.7909	1.6766	1.6385	.7049	2.0767	1.8861
15	1.9624	2.3434	1.6766	1.7147	.7049	2.0576	1.9814
16	2.4768	2.2862	2.2481	2.0957	.6859	2.5149	2.7435
17	1.7718	1.6385	1.467	2.0957		2.4387	2.0767
18	1.2574	1.4861	1.3527	1.3908	.6478	1.6004	1.7147
19	1.105	.9717	1.086	1.2384	.6478	.9907	1.6385
20	1.3336	.8002	1.2003	1.2003	.6478	1.105	1.4289
21	1.5242	.6859	1.1812	1.1812	.6859	.8954	1.3336
22	1.4098	.7621	1.2384	1.1622	.6859	1.5813	.9907
23	1.5242	.8764	1.0288	1.105	.6478	1.1431	1.5432
24	1.105	1.4861	1.1622	1.1241	.7811	.6859	1.467
Max	2.4768	2.3815	2.4768	2.1719	1.0669	2.572	2.7435
Min	.9526	.6859	1.0288	.9907	.5906	.6859	.9907
Avg	1.4845	1.5138	1.4591	1.4678	.7439	1.4194	1.6623

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 206 / 11KV Devi gas

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY

STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.3336	1.105	1.3336	1.3717	.8002	1.3527
2	1.4098	1.2955	1.1431	1.2955	1.0669	.8002	1.3336
3	1.2574	1.2574	1.0479	1.1622	1.0288	.8383	1.3336
4	1.2193	1.3336	1.0479	1.105	1.0669	.8383	1.3336
5	1.2003	1.2574	1.1431	1.086	1.105	.8383	1.4098
6	1.448	1.2193	1.2384	1.1241	1.105	.8764	1.4861
7	1.1622	1.2193	1.2193	1.1431	1.0098	.8764	1.1812
8	1.4098	1.0669	1.0669	.8383	.8383	.8383	1.3336
9	2.1338	1.448	1.1431	.724	.8192	1.2193	1.4861
10	1.9052	1.6385	1.5242	1.448	.7811	1.7147	1.8671
11	1.7528	1.6385	1.7718	1.1431	.8002	1.7909	2.0576
12	2.0005	1.5432	1.3717	1.2193	.8192	1.7337	1.7337
13	1.6766	1.6004	1.5623	1.3717	.8002	1.7528	2.0576
14	2.0005	1.6004	1.6385	1.448	.8002	1.8099	2.0576
15	1.7909	1.5242	1.6575	1.4098	.8192	1.7147	1.7909
16	1.9052	1.6575	1.3336	1.4861	.8192	1.6194	1.6766
17	2.2672	1.6575	1.7909	1.6004		1.4098	2.0195
18	1.9052	1.5623	1.2384	1.4289	.8002	1.3336	1.4289
19	1.6004	1.5242	1.1431	1.3908	.8383	1.2574	1.6385
20	1.5242	1.105	1.0479	1.2955	.8764	1.2193	1.5623
21	1.4861	1.2384	1.2574	1.0479	.8764	1.3336	1.2003
22	1.6385	1.3336	1.0669	1.2955	.8764	1.2765	1.5051
23	1.5242	1.086	1.2955	1.3717	.8383	1.5813	1.3336
24	1.448	1.3717	1.105	1.3146	1.3908	.8002	1.3527
Max	2.2672	1.6575	1.7909	1.6004	1.3908	1.8099	2.0576
Min	1.1622	1.0669	1.0479	.724	.7811	.8002	1.1812
Avg	1.6329	1.3964	1.2900	1.2535	.9369	1.2614	1.5638

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144079 / 33/11 KV MIDC G SHIRGAON

Feeder No / Name : 207 / 11 KV Sunanda Agro

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	30-MAR-18
HR	Load (MW)
24	1.0669
Max	1.0669
Min	1.0669
Avg	1.0669

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 201 / Mhakve AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0381	.9526	1.0288	1.0174	.1143	.0762	.0686
2	.0381	.9526	1.0288	1.0174	.3048	.0762	.0686
3	.0381	.9526	1.0288	1.0174	.1143	.0762	.0686
4	.0381	.9526	1.0288	1.2717	.1143	.0762	.0686
5	.0381	1.0288	1.0974	1.3565	.1143	.0762	.0686
6	.0572	1.1431	1.1831	1.543	.1334	.0762	.0686
7	.0762	1.7147	1.6461	1.6956	.1524	.0953	.0686
8	.0762	1.9624	1.9448	1.7804	.1334	.1143	
9	.0953	1.8671	1.7772	1.8991	.1524	.1524	
10	1.7909	.1143	.1006	.1524	1.9433	2.0386	
11	2.2291	.1029	.1174	.1524	2.7625	2.7092	2.915
12	2.3243	.1029	.1134	.1334	2.9531	2.7092	2.8197
13	2.3053	.12	.1174	.1334	2.8197	2.6749	
14	2.0005	.12	.1174	.1334	2.8959	2.4863	
15	1.9243	.12	.1174	.1334	2.8387	2.4691	2.5911
16	.381	.12	.1006	.1143	2.5911	2.452	2.572
17	1.7528	.12	.1174	.1715	2.6482	2.3663	2.5911
18	.0762	.12	.1341	.1715		.1029	.1334
19	.0762	.1029	.1006	.1524	.1334	.0857	
20	.0762	.12	.1006	.1524	.1143	.0857	.0953
21	.0762	.0857	.1006	.1334	.1143	.0857	
22	.0762	.0857	.0838	.1334		.0686	.0953
23	.0762	.0686	.0838		.0953	.0686	.0953
24	.0381	.9526	.8745	3.245	.1143	.0762	.0686
Max	2.3243	1.9624	1.9448	3.245	2.9531	2.7092	2.915
Min	.0381	.0686	.0838	.1143	.0953	.0686	.0686
Avg	.6541	.5826	.5893	.7700	1.0617	.8874	.8504

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 202 / Mhakve Gavthan

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.2858	.2987	.3109	.3048	.3048	.3174
2	.2858	.2858	.2987	.3109	.3048	.3048	.3174
3	.2858	.2858	.2987	.3109	.3048	.3048	.3174
4	.2858	.2858	.2987	.3109	.3048	.3048	.3174
5		.3239	.3174	.3109	.3429	.3239	.3174
6	.381	.5144	.3734		.381	.381	.3547
7	.3429	.4191	.3734	.3475	.381	.3429	.3547
8	.3239	.381	.3361	.3292	.3048	.3239	
9	.3048	.2858	.2987	.3109	.3048	.3239	
10	.3048	.3048	.2987	.3429	.3048	.3048	
11	.381	.3174	.3174	.3239	.2858	.2987	.3239
12	.381	.3174	.3174	.3048	.3239	.2987	.3239
13	.381	.3361	.3174	.3048	.3239	.3174	
14	.3429	.2987	.2614	.3239	.3048	.3174	
15	.3239	.3174	.3361		.3239		.3429
16	.381	.3361	.3174	.3239	.3239	.3174	.3429
17	.3239	.3361	.3734	.3429	.3048	.3174	.3429
18	.4191	.3547	.3174	.3048		.2987	.381
19	.4954	.5041	.6371	.4572	.5335	.4854	
20	.6097	.5601	.5041	.5716	.5716	.5601	.6097
21	.5335	.5415	.4854	.5335	.5335	.5415	
22	.4954	.5041	.5041	.4572		.5041	.5335
23	.3429	.3547	.3361	.381	.4191	.4668	.4191
24	.3048	.3239	.3086	1.1755	.3048	.3429	.3361
Max	.6097	.5601	.6371	1.1755	.5716	.5601	.6097
Min	.2858	.2858	.2614	.3048	.2858	.2987	.3174
Avg	.3703	.3656	.3552	.395	.3542	.3603	.3678



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144083 / 33/11 KV kenawade

Feeder No / Name : 203 / Kenavade Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.1334	.1029	.116	1.2574	1.2384	1.3375
2	.9907	.1334	.1029	.116	1.2765	1.2384	1.3375
3	.9907	.1334	.1029	.116	1.2955	1.2384	1.3375
4	1.0288	.1334	.1029	.116	1.3146	1.2574	1.3375
5	1.0669	.1524	.1029	.116	1.3527	1.3717	1.3546
6	1.2955	.1715	.12	.1326	1.5813	1.6194	1.4575
7	1.6004		.1543	.1658	1.9052	2.0767	1.9033
8	1.9624	.1905	.1509	.1326	2.0195	2.2862	
9	1.7528	.1905	.1677	.1658	1.8671	2.0957	
10	.1715	1.7147	1.643	1.6575	.1524	.1524	
11	.1524	2.0062	2.1472	2.1719	.1524	.12	.1524
12	.1334	2.1434	1.9616	2.21	.1715	.1029	.1524
13	.1334	2.0919	1.8778	1.9624	.1524	.1543	
14	.1524	1.9547	1.7328	1.8861	.1143	.1372	
15	.1524	2.0062	1.7101	1.8671	.1715	.12	.1334
16	.1715	1.9376	1.8275	1.9814	.1905	.1372	.1334
17	.1905	1.8861	1.6766	1.9243	.2096	.1372	.1334
18	.1905	.1372	.1174	.1524		.1372	.1524
19	.1905	.1543	.1174		.2096	.1715	
20	.1715	.1543	.1341	.1334	.1905	.1715	.1715
21	.1715	.1372	.1341	.1334	.1905	.1715	
22	.1715	.12	.1341	.1334		.1372	.1524
23	.1524	.12	.1341	.1334	.1334	.1372	.1334
24	1.0288		.1029	2.6245	1.2384	1.0669	1.286
Max	1.9624	2.1434	2.1472	2.6245	2.0195	2.2862	1.9033
Min	.1334	.12	.1029	.116	.1143	.1029	.1334
Avg	.6097	.8092	.6899	.876	.7794	.7282	.7451

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144119 / PIMPALGAON KH

Feeder No / Name : 201 / 11 KV PIMPALGAON AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0514	1.2346	1.7147	1.6118
2	.0514	2.7435	1.8004	1.6118
3	.0514	3.0864	1.8004	1.6118
4	.0514	2.6749	1.7147	1.6804
5	.0514	2.6749	1.8861	1.9204
6	.0514	1.869	2.0576	2.0405
7	.0514	2.2119	2.4006	2.4177
8	.0514	2.452	2.4177	2.332
9	.0514	2.452	2.4348	2.4006
10	2.2977	.0514	.0514	.0514
11	2.7949	.0514	.0514	.0514
12	2.6063	.0343	.0514	.0514
13	2.2977	.0514	.0514	.0514
14	2.3491	.0514	.0514	.0514
15	2.1948		.0514	.0514
16	2.3491		.0514	.0514
17	2.5206	.0514	.0514	.0514
18	.0514	.0514	.0514	.0514
19	.0514	.0514	.0514	.0514
20	.0514	.0514	.0514	.0514
21	.0514	.0514	.0514	.0514
22	.0514	.0514	.0514	.0514
23	.0514	.0514	.0514	.0514
24	2.0919	1.4232	1.5947	1.6118
Max	2.7949	3.0864	2.4348	2.4177
Min	.0514	.0343	.0514	.0514
Avg	.9280	1.0646	.8559	.8316

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144119 / PIMPALGAON KH

Feeder No / Name : 202 / 11 KV PIMPALGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3429	.6001	.3944	.4801
2	.3429	.5487	.3772	.4801
3	.3429	.5658	.3944	.4801
4	.3429	.583	.3944	.4801
5	.3772	.4973	.5144	.5144
6	.4801	.6859	.5144	.5144
7	.5144	.5487	.5144	.5487
8	.7716	.4287	.4458	.5487
9		.3429	.7202	.6516
10		.3429	.6687	.823
11	.703	.2915	.6001	.5658
12	.9602	.2743	.6687	.5487
13	.9602	.2743	.6516	.5658
14	.8573	.2915	.5487	.5658
15	1.1488	.3086	.6173	.583
16	1.1317	.3086	.7716	.6001
17	1.0288	.3086	.7716	.6516
18	.7888	.3086	.6344	.6516
19	.7545	.3944	.583	.6344
20	.7373	.4287	.5487	.6516
21	.8573	.463	.5487	.6344
22	.7888	.4287	.5487	.5144
23	.6344	.4287	.4115	.4801
24	.4287	1.4232	.3944	.4115
Max	1.1488	1.4232	.7716	.823
Min	.3429	.2743	.3772	.4115
Avg	.6952	.4615	.5516	.5658

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 144119 / PIMPALGAON KH

Feeder No / Name : 203 / 11 KV Vhannur AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0343	.0343	.7716	.7202	.0343	.0343	.0343
2	.0343	.0343	.7716	.7202	.0343	.0343	.0343
3	.0343	.0343	.8059	.7202	.0343	.0343	.0343
4	.0343	.0343	.7716	.7202	.0343	.0343	.0343
5	.0343	.0343	.8573	.8916		.0343	.0343
6	.0343	.0343	1.286	1.0974		.0343	.0343
7	.0343	.0343	1.3375	1.3375		.0343	.0343
8	.0343	.0343	1.406	1.4232		.0343	.0343
9	.0343	.0343	1.2346	1.2003		.0343	.0343
10	1.5089	.0343	.0343	.0343		1.2346	1.2689
11	1.2689	.0343	.0343	.0343		1.6118	1.5775
12	1.3032		.0343	.0343		1.6461	1.4575
13	1.406		.0343	.0343		1.6289	1.4403
14	1.4232		.0343	.0343		1.5261	1.4232
15	1.3546	.0343	.0343	.0343		1.4746	1.3889
16	1.4232	.0343	.0343	.0343		1.5089	1.406
17	1.4232	.0343	.0343	.0343		1.5089	1.3889
18	.0343	.0343	.0343	.0343		.0343	.0343
19	.0343	.0343	.0343	.0343		.0343	.0343
20	.0343	.0343	.0343	.0343		.0343	.0343
21	.0343	.0343	.0343	.0343		.0343	.0343
22	.0343	.0343	.0343	.0343		.0343	.0343
23	.0343	.0343	.0343	.0343	.0343	.0343	.0343
24	.0343	.0343	.7545	.7202	.0343	.0343	.0343
Max	1.5089	.0343	1.406	1.4232	.0343	1.6461	1.5775
Min	.0343	.0343	.0343	.0343	.0343	.0343	.0343
Avg	.4858	.0343	.4365	.4180	.0343	.5287	.4958

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

Feederwise Load Information for **All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 401 / G.Shirgaon

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	4.8097
Max	4.8097
Min	4.8097
Avg	4.8097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 403 / sidhnerli

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
24	4.7611
Max	4.7611
Min	4.7611
Avg	4.7611

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 404 / 33 KV Samir

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.036
Max	5.036
Min	5.036
Avg	5.036

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 405 / kagal

Feeder KV- 33 / INCOMING

DATE	01-APR-18
HR	Load (MW)
23	.0514
24	8.514
Max	8.514
Min	.0514
Avg	4.2827



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 406 / 33 KV Menon BRG

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.5782
Max	4.5782
Min	4.5782
Avg	4.5782

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 146012 / 110/33 KV G.SHIRGAON

Feeder No / Name : 601 / 110KV Shahu CoGen

Feeder KV- 132 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-APR-18
HR	Load (MW)
24	.4115
Max	.4115
Min	.4115
Avg	.4115

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 403 / 33 kv pattankodoli

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 404 / 33Kv Raymond

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
22	6.4301
Max	6.4301
Min	6.4301
Avg	6.4301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 406 / 33KV Anshul

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.4321
Max	5.4321
Min	5.4321
Avg	5.4321

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 407 / MUDSHINGI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	2.0576
Max	2.0576
Min	2.0576
Avg	2.0576

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148002 / 220/110/33 KV MUDSHINGI

Feeder No / Name : 603 / 110 kV Ichalkaranji NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(Jawahar + Feeder KV- 100 / (CONTINOUS PROCESS)(NO STAGGERING  
INCOMING

DATE	01-APR-18
HR	Load (MW)
23	1.7147
Max	1.7147
Min	1.7147
Avg	1.7147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 401 / 33KV Oswal Feeder NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
22	5.0926
Max	5.0926
Min	5.0926
Avg	5.0926



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 402 / 33KV Metro Feeder  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(NON CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	8.035
Max	8.035
Min	8.035
Avg	8.035

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 404 / 33KV Kirloskar Feeder

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.4887
Max	5.4887
Min	5.4887
Avg	5.4887

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 405 / 33KV Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.1578
Max	5.1578
Min	5.1578
Avg	5.1578

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 406 / 33KV Apple Spong

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.7716
Max	5.7716
Min	5.7716
Avg	5.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 407 / Mantri Metal

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.9954
Max	4.9954
Min	4.9954
Avg	4.9954

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 408 / 33KV KOEL Exp

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	5.5967
Max	5.5967
Min	5.5967
Avg	5.5967

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 409 / 33KV UTP NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.0569
Max	4.0569
Min	4.0569
Avg	4.0569

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043] BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 410 / 33KV GPI NON SHEDDABLE EXPRESS HV FEEDERS  
Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
22	7.3045
24	4.8097
Max	7.3045
Min	4.8097
Avg	6.0571



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

KAGAL[043]

BU 7129

Substation No/ Name :- 148009 / 220/33KV Five Star EHV S/stn

Feeder No / Name : 411 / 33 kv Hupari Feeder

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	01-APR-18
HR	Load (MW)
23	5.6584
Max	5.6584
Min	5.6584
Avg	5.6584

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 201 / 11KV KAPASHI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0572	.381	.4115	.4572	.0381	.0572	.0381
2	.0572	.381	.3944	.4572	.0381	.0572	.0381
3	.0572	.381	.4382	.4572	.0381	.0572	.0381
4	.0572	.381	.4382	.4572	.0381	.0572	.0381
5	.0572	.381	.4115	.4572	.0381	.0572	.0572
6	.0572	.4382	.4287	.4763	.0572	.0572	.0572
7	.0762	.8764	.7373	.8002	.0762	.0572	.0381
8	.0953	1.0479	1.0288	1.0669	.0572	.0762	.0762
9	.0953	.8192	.7888	.8764	.0572	.0762	.0762
10	.7811	.0572	.0762	.0762	.8002	.6344	.6478
11	1.0669	.0572	.0762	.0762			.8764
12	1.0669	.0762	.0762	.0762	1.1431	.9774	.9335
13	1.0669	.0762	.0762	.0762	1.2003	.9945	.8192
14	.9907	.0762	.0953		1.0669	.9088	.6859
15	.8192	.0762	.0762	.0762	.8002	.823	.7049
16	.8002	.0762	.0762	.0762	.8954	.8402	.7621
17	.8383	.0762	.0953	.0762	.7621	.9145	.703
18	.0572	.0953	.0572	.0572	.0762	.0572	.0381
19	.0572	.0762	.0572	.0572	.0762	.0762	.0762
20	.0572		.0572	.0572	.0762	.0572	.0762
21	.0572	.0762	.0572	.0762	.0762	.0762	.0762
22	.0381	.0762	.0572	.0572	.0572	.0572	.0572
23	.0381	.0762	.0572	.0572	.0572	.0572	.0572
24	.0572	.4191	.4115	.4572	1.2407	.0572	.0381
Max	1.0669	1.0479	1.0288	1.0669	1.2407	.9945	.9335
Min	.0381	.0572	.0572	.0572	.0381	.0572	.0381
Avg	.3501	.2816	.2700	.2982	.3811	.308	.2921

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 202 / 11 KV Hasoor Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5487	.0762	.0762	.0953		2.7054	2.0957
2	.3772	.0762	.0762	.0953		2.6673	1.9052
3	.3772	.0762	.0762	.0762		2.6673	1.7147
4	.3429	.0762	.0762	.0953		2.6673	1.6575
5	.3429	.0953	.0762	.0953		2.6101	1.6575
6	.3772	.1524	.0762	.0953		2.4768	1.6766
7	.7888	.1524	.1143	.1334		2.6673	1.8671
8	.8402	.1905	.1715	.2096		2.8578	1.9052
9	.823	.1524	.1524	.1905		2.1434	1.6766
10	.0953	1.1431	1.0288	1.1812		.4572	.2667
11	.0953	.9145	.8573	.8573		.4954	.2286
12	.0953	.8002	.7202	.8192		.4954	.2667
13	.0762	.724	.7202	.7621		.5335	.3048
14	.0953	.724	.6859			.5335	.3048
15		.724	.7545	.6859		.5335	.3429
16	.0953	.7621	.7716	.6668		.4801	.2667
17	.0953	.6859	.7621	.724	.4763	.5335	.2667
18	.1524	.1715	.1334	.1524	.5716	.5144	.2477
19	.1334	.1143	.1334	.1334	.5906	.4763	.3048
20	.0953	.0953	.1143	.1334	.5906		.2667
21	.1143	.0953	.1143	.0953	.6097	.4763	.2286
22	.0953	.0953	.1143	.0381	.6097	.4572	.1715
23	.0953	.0762	.0953	.0381	.6097	.4382	.1905
24	.703	.0762	.0762	.0953		2.4006	2.3434
Max	.8402	1.1431	1.0288	1.1812	.6097	2.8578	2.3434
Min	.0762	.0762	.0762	.0381	.4763	.4382	.1715
Avg	.2980	.3437	.3324	.3247	.5797	1.4038	.9232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 203 / 11 KV MUGALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2858	.5716	.5487	.8002	.2667	.2667	.2667
2	.2858	.5335	.4458	.7621	.2477	.2667	.2286
3	.2858	.5335	.4115	.7621	.2286	.2667	.2286
4	.2858	.5335	.4115	.7621	.2286	.2667	.2286
5	.2858	.6478	.4115	.7621	.2477	.2667	.2477
6	.3239	.7621	.583	.7621	.2477	.2858	.2667
7	.362	1.1241	.6001	1.086	.2477	.3048	.2858
8	.3429	1.105	.9602	1.0479	.2858	.2667	.3239
9	.3429	1.1622	.8916	.9717	.2858	.3429	.3429
10	1.1431	.2096	.3048	.2667	1.1622	1.0974	1.0288
11	1.2003	.2667	.2858	.2667	1.3717	.9945	1.0669
12	1.1622		.3048	.2477	1.1622	.8573	.9717
13	.9717	.2858	.3239	.2477	1.1241	.8916	.9526
14		.2667	.3048	.2286	.9907	.823	.8954
15	.9335	.2667	.2858	.2667	.9526	.7545	.8573
16	1.0479	.2858	.3048	.2667	1.0098	.823	.8573
17	.9907	.3239	.2858	.2858	.9907	.9145	.7888
18	.2477	.3239	.2858	.2858	.1524	.3048	.2096
19	.2858	.3239	.3239	.2667	.3239	.2858	.2667
20	.2858	.3239	.2858	.2667	.3048	.2667	.2858
21	.2858	.3429	.3048	.2477	.2667	.2667	.2858
22	.2858	.3048	.2858	.2477	.2477	.2667	.3048
23	.2667	.3239	.3048	.2477	.2667	.2667	.3048
24		.6097	.6516	.8573	.2667	.2667	.2667
Max	1.2003	1.1622	.9602	1.086	1.3717	1.0974	1.0669
Min	.2477	.2096	.2858	.2286	.1524	.2667	.2096
Avg	.5413	.4970	.4211	.5089	.5366	.4839	.4901

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 204 / 11 KV LINGNOOR AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.823	.0381	.0381	.0381	.8954	.8573	.9717
2	.7888	.0381	.0381	.0381	.8764	.7621	.9717
3	.7888	.0381	.0381	.0381	.8383	.7621	.9717
4	.7888	.0381	.0381	.0381	.8383	.7621	.9907
5	.8573	.0762	.0381	.0381	.8764	.8383	1.0288
6	.8573	.0762	.0381	.0381	.9145	.9907	1.0669
7	1.3032	.0572	.0381	.0381	1.3717	1.2003	1.2955
8	1.286	.0572	.0381	.0381	1.448	1.5242	1.3336
9	1.1831	.0572	.0381	.0381	1.2003	1.166	1.1812
10	.0381	1.4289	1.286	1.2003	.0381	.0381	.0572
11	.0381	1.6766	1.3032	1.3336	.0381	.0381	.0381
12	.0381	1.5242	1.2346	1.2003	.0381	.0381	.0381
13	.0381	1.4861	1.2003	1.3146	.0381	.0381	.0381
14	.0381	1.448	.9602	1.0669	.0381	.0381	.0381
15	.0381	1.4098	.9945	1.3146	.0762	.0381	.0381
16	.0381	1.4098	1.0974	1.3717	.0572	.0381	.0381
17	.0381	1.2003	1.1622	1.2955	.0381	.0381	.0381
18	.0762	.0381	.0762	.0762	.0572	.0381	.0381
19	.0762	.0381	.0381	.0381	.0381	.0381	.0381
20	.0762	.0381	.0381	.0381	.0381	.0762	.0381
21	.0762	.0381	.0572	.0381	.0572	.0762	.0381
22	.0572	.0381	.0381	.0381	.0572	.0762	.0381
23	.0572	.0381	.0381	.0381	.0381	.0762	.0381
24	.8916	.0381	.0381	.0381	.8954	.9526	.9526
Max	1.3032	1.6766	1.3032	1.3717	1.448	1.5242	1.3336
Min	.0381	.0381	.0381	.0381	.0381	.0381	.0381
Avg	.4288	.5136	.4127	.4477	.4501	.4376	.4715

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 205 / 11 KV Arjunwada Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524	.5716	.5658	.7621	.1143	.0572	.1143
2	.1524	.5716	.5487	.7621	.0953	.0572	.0953
3	.1334	.5716	.5487	.7621	.0953	.0572	.0953
4	.1334	.5716	.5487	.7621	.0762	.0572	.1143
5	.1143	.5716	.5316	.7621	.0762	.0572	.1143
6	.1143	.6287	.5316	.7621		.0572	.1143
7	.1334	.8573	.7888	.9335	.1334	.0572	.1334
8	.1524	.9717	.9945	1.086	.1143	.0572	.1334
9	.1334	.9717	.8402	.8954	.1143	.0572	.0953
10	1.0288	.0953	.0953	.1143	1.0479		.8573
11	1.105	.1143	.1143	.1143	.9907		.9526
12	1.105	.0953	.1143	.1143	1.0479	.9088	.9526
13	1.105	.0953	.0953	.1143	.9717	.9088	.9145
14	1.0479	.0953	.0762	.1143	.9526	.8916	.9145
15	1.0288	.1143	.0953	.1143	.8573	.3601	.8192
16	1.0669	.1143	.0953	.1143		.4458	.8002
17	.9717	.1143	.1143	.1143	.4763	.5144	.823
18	.1334	.1143	.1334	.1143		.1524	.1143
19	.1334	.0953	.1334	.1334	.1143	.1334	.1143
20	.1334	.0953	.1143	.1143	.1143	.0953	.0762
21	.1143	.0953	.1143	.0953	.0953	.1143	
22	.0953	.0953	.0953	.1143	.0762	.1143	.0953
23	.0953	.0953	.0953	.1143	.0762	.1143	.0953
24	.1334	.6287	.583	.7621	.1143	.0572	.1143
Max	1.105	.9717	.9945	1.086	1.0479	.9088	.9526
Min	.0953	.0953	.0762	.0953	.0762	.0572	.0762
Avg	.4382	.3477	.3320	.4104	.3693	.2421	.3762

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 206 / 11 KV Vadgaon Vg

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.3429	.2858	.3429	.4191	.381
2	.3048	.2477	.3429	.2858	.3239	.381	.3429
3	.3048	.2477	.3048	.2858	.3048	.381	.3429
4	.3048	.2477	.3048	.2858	.3048	.381	.3429
5	.3048	.2667	.3239	.3048	.3239	.4382	.362
6	.3239	.3239	.362	.3239	.3429	.4763	.381
7	.3429	.362	.362	.362	.381	.4763	.4001
8	.3429	.3429	.381	.362	.4001	.4763	.381
9	.3429		.3239	.3429	.1715	.4572	.362
10	.3239	.3429	.2858	.3239		.4191	.3239
11	.3429	.362	.3048	.2858	.3048	.4382	.3429
12	.2858	.2858	.2858	.3048	.2667	.4382	.3429
13	.3048	.2858	.2858	.2667	.2667	.4572	.3239
14	.3429	.3048	.2858		.3048	.4191	.3239
15	.381	.3239	.3239	.3048	.2858	.4001	.362
16	.381	.3048	.3429	.3239	.3048	.4382	.3429
17	.381	.381	.3239	.3429	.3048	.4382	.3239
18	.4572	.4001	.362	.4001	.4572	.4001	.4191
19	.6287	.6859	.5906	.5525	.6097	.6287	.6478
20	.724	.724	.724	.743	.7811	.8192	.724
21	.6287	.6287	.6668	.6287	.743	.743	.6097
22	.5335	.5525	.5335	.5525	.7049	.5716	.5716
23	.381	.4382	.4001	.381	.5906	.4382	.4382
24	.3429	.3239	.362	.3048	.3429	.5144	.381
Max	.724	.724	.724	.743	.7811	.8192	.724
Min	.2858	.2477	.2858	.2667	.1715	.381	.3239
Avg	.3882	.3769	.3802	.3719	.3984	.4771	.4072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 207 / 11 KV BALEGHOL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2286	.2286	.2667	.2286	.2667	.2667	.2858
2	.2286	.2096	.2667	.2286	.2667	.2286	.2667
3	.2286	.2096	.2477	.2286	.2477	.2286	.2667
4	.2286	.2096	.2477	.2286	.2286	.2286	.2667
5	.2477	.2858	.2667	.2477	.2477	.2858	.2858
6	.2858	.362	.3239	.2858	.3048	.3429	.3048
7	.3429	.2858	.3048	.2667	.3048	.381	.3048
8	.2858	.2858	.2477	.2477	.2667	.3048	.2858
9	.2477	.2667	.2286	.2286	.2286	.2477	.2096
10	.2477	.2667	.2667	.2286		.2286	.2477
11	.2286	.2667	.2667	.2667		.2286	.2667
12	.2477	.2477	.2477	.2477		.2477	.2477
13	.2667	.2477	.2477	.2477		.2667	.2667
14	.2477	.2477	.2477			.2667	.2286
15	.2667	.2477	.2858	.2477	.3429	.2858	.2667
16	.2096	.2667	.2667	.2477	.3429	.2667	.2477
17	.2858	.2858	.2286	.2858	.2858	.3429	.2667
18	.3239	.3239	.2858	.3239	.3429	.362	.2858
19	.4763	.4572	.381	.381	.4382	.4382	.5144
20	.5335	.5144	.4763	.4954	.5335	.4954	.4954
21	.4191	.4191	.4191	.4382	.4572	.4382	.4191
22	.4191	.381	.381	.381	.4001	.3429	.381
23	.3239	.3048	.2858	.3048	.3048	.3048	.2858
24	.2477	.2667	.2667	.2477	.2858	.2667	.2858
Max	.5335	.5144	.4763	.4954	.5335	.4954	.5144
Min	.2096	.2096	.2286	.2286	.2286	.2286	.2096
Avg	.2945	.2953	.2897	.2841	.3209	.3040	.2993



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 208 / 11 KV JAINAL GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.5906	.6097	.6097	.5716	.5716	.6097
2	.6097	.5525	.5716	.6097	.5144	.5335	.6097
3	.6097	.5525	.5716	.6097	.4954	.5335	.5716
4	.6097	.5525	.5716	.6097	.4954	.5335	.5716
5	.6097	.6478	.5716	.6287	.5525	.6478	.6668
6	.6859	.724	.724	.6859	.7049	.8002	.8383
7	.724	.724	.724	.6478	.6668	.7049	.7621
8	.6478	.6097	.5716	.6287	.5906	.6287	.6287
9	.6287	.5716	.5716	.6287	.5525	.6097	.5716
10	.5335	.5716	.5906	.5906	.5335	.5716	.5716
11	.5525	.6859	.6097	.5525	.5144	.5716	.5906
12	.5716	.6478	.6287	.5525	.4382	.6668	.6668
13	.5906	.5716	.6097		.5335	.6097	.6668
14	.5906	.6478	.4763		.6668	.6668	.7049
15	.6478	.724	.6097	.6097	.6478	.7049	.6859
16	.6097	.7621	.6668	.5906	.5906	.7621	.7621
17	.6097	.5906	.6859	.5906	.5906	.6287	.6668
18	.6668	.6097	.5716	.6097	.6478	.6859	.6287
19	.9335	1.0288	.9526	.8764	.8764	.9526	1.0288
20	1.105	1.1622	1.086	1.0479	1.086	1.1622	1.1241
21	1.0288	1.0288	1.0098	.9907	.9717	1.086	1.0669
22	.8954	.8954	.8954	.8764	.8954	.8573	.9335
23	.724	.743	.743	.6859	.6859	.7621	.7621
24	.6287	.6287	.6668	.6287	.6097	.6097	.6668
Max	1.105	1.1622	1.086	1.0479	1.086	1.1622	1.1241
Min	.5335	.5525	.4763	.5525	.4382	.5335	.5716
Avg	.6843	.7010	.6787	.6755	.6430	.7026	.7232

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144018 / 33/11 Kv KAPASHI

Feeder No / Name : 209 / 11 KV Madyal Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.0762	.0381	.0381		1.2955	.8002
2		.0762	.0381	.0381		1.3336	
3		.0762	.0381	.0381		1.3336	.724
4		.0762	.0381	.0381			.7049
5		.0762	.0381	.0381		1.4098	.7049
6	.583	.0762	.0381	.0381		1.448	.724
7	.8402	.1143	.1143	.1143		1.5432	.8954
8	.8573	.1143	.1524	.0953		1.5623	.9526
9	.823	.1143	.1524	.0953		1.3203	.8764
10	.0762	1.0479	.823	.9907		.1715	.0762
11	.1143	1.105	.823	1.0479		.2286	.1143
12	.1143	1.0288	.7888	.9526		.2286	.0953
13	.0953	1.0098		.9145		.2477	.0953
14	.0953	.9907	.7202			.2286	.0953
15	.0762	.9717	.7202	.8383		.2096	.0953
16	.0953	.9145	.8002	.7811		.2096	.0953
17	.1143	.7888	.8954	.8002	.2858	.1905	.1143
18	.1143	.0762	.0381	.0762	.3239	.1334	.1143
19	.0953	.0762	.0762	.0762	.362	.1143	.1143
20	.0953	.0762	.0762	.0762	.3429	.1334	.1143
21	.0953	.0381	.0762	.0762	.3239	.1334	.1143
22	.0953	.0953	.0572	.0762	.2858	.1143	.0953
23	.0953	.0953	.0381	.0762	.2858	.1143	.0953
24		.0762	.0381	.0381		1.3336	.8954
Max	.8573	1.105	.8954	1.0479	.362	1.5623	.9526
Min	.0762	.0381	.0381	.0381	.2858	.1143	.0762
Avg	.2486	.3830	.2878	.3197	.3157	.6538	.3786

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 201 / 11 Kv Sonage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.307	.0181	.0162	.0162		1.2308	1.4377
2	1.3817	.0181		.0162		1.2308	1.4003
3	1.4003	.0181	.0164	.0162	1.2071	1.1946	
4	1.4003	.0181				1.1946	
5	1.475	.0181		.0162		1.3394	1.531
6	1.6057	.0179	.0162	.0162	1.643	1.7737	1.7364
7	1.9791	.0179		.0162		2.1312	2.2405
8	2.1658	.0177	.0164	.0162	2.079	2.2386	2.4272
9	1.893	.0179		.0162	1.8564		
10	.0876	2.8193	2.4615	2.5415	.0164		.0162
11	.0701	3.3421		2.8978			
12	.0876	3.3234	2.7206	2.8635	.0164	.0168	.0162
13	.1029	3.1554		2.7435			.0648
14	.0876	3.1741	2.7854	2.692			.0648
15	.0876	3.1554	2.6155	2.6063	.0164		.0648
16	.0701	3.0807	2.6825	2.5892	.0164	.0168	.0648
17	.0876	2.9874	2.4813	2.4348	.0164	.0168	.0648
18	.1052	.1311	.0648		.0179	.0819	
19	.0895		.0648		.1433		
20	.0895	.0164	.0648		.0179	.0162	
21	.0716		.0162		.0179		
22	.0181	.0164	.0162		.0181	.0164	
23	.0181	.0164	.0162		.0181	.0162	
24	1.2696	.0181	.0164	.0162		1.2489	1.363
Max	2.1658	3.3421	2.7854	2.8978	2.079	2.2386	2.4272
Min	.0181	.0164	.0162	.0162	.0164	.0162	.0162
Avg	.7063	1.1545	.9454	1.2656	.4734	.8602	.8923

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 202 / 11 KV HAMIDWADA AG FEEDER SEPARATED AG FEEDERS HAVING SPECIAL  
Feeder KV- 11 / OUTGOING DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0162	1.2308	1.2696	1.1317		.0181	.0162
2		1.2308	1.251	1.1145		.0181	.0162
3		1.1946	1.2136	1.1145		.0181	
4	.0164	1.1946	1.2136	1.1191		.0181	
5		1.267	1.307	1.1869		.0181	.0162
6	.0162	1.4864	1.4937	1.2517		.0181	.0162
7	.0164	1.9879	1.9605	1.6975		.0179	
8	.0164	2.1085	2.2218	2.0348	.0168	.0179	.0162
9	.0175	1.9105		1.8652	.0168		.0162
10	2.489	.0164	.0324	.0175	2.0351	2.0119	2.1091
11	2.5377	.0164		.0171	2.6139		2.6113
12	2.3487			.0171	2.6139	2.5819	2.5434
13	2.2462			.0171	2.5019		2.4417
14	2.1605			.0171	2.3712	2.1795	2.4078
15	2.452	.0164	.0335	.0175	2.3152		
16	2.4177	.0164		.0175		2.1795	2.3061
17	2.2786	.0164		.0175	2.0725	2.2131	2.3061
18	.0179	.0164	.0324			.0164	
19	.0179		.0324				
20	.0179		.0324		.0181		
21	.0179	.0164			.0181		
22	.0181	.0164	.0162		.0181	.0164	
23	.0181	.0156	.0162		.0181	.0162	
24	.0164	1.2489	1.3443	1.2517	.0168	.0181	.0162
Max	2.5377	2.1085	2.2218	2.0348	2.6139	2.5819	2.6113
Min	.0162	.0156	.0162	.0171	.0168	.0162	.0162
Avg	.9121	.7898	.8419	.7726	1.1890	.6693	1.2028

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 203 / 11 KV ARJUNNAGAR VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2241	.2772	.2427		.2614	.2772
2	.2402	.2241	.2801	.2427		.2614	.2402
3		.2241	.2801	.2452	.2195	.2534	
4	.2587	.2427	.2801	.2641		.2534	
5	.2801	.2801	.2987	.3174		.2801	.2587
6	.3361	.2926	.3174	.2957	.2561	.2957	.3174
7	.2587	.2743	.2987	.3109	.2743	.3109	.2587
8	.2402	.2561	.2587	.2378	.2561	.2743	.2033
9	.1991	.2172		.2561	.2195		.1829
10	.2172	.2033	.2507	.2353	.2402	.2149	.1646
11	.2172	.2033		.2353	.1848		.2012
12	.2149	.2402	.2195		.2033	.2012	.2195
13	.2328			.2328	.2218		.2561
14	.2328	.2772	.2561	.2149	.2218	.2012	.2561
15	.2149	.2987	.2926	.2149	.2772		.2743
16	.2865	.2587	.2926	.2172		.2561	.2561
17	.2896	.2587	.2926	.2353		.3109	.2926
18	.2896	.2987	.2926			.3734	
19	.4207	.3921	.4207			.4108	
20	.439	.4854	.4938		.1829	.4854	
21	.4207	.4668	.4435		.4805	.4668	
22	.4066	.4108	.4066		.4435	.4108	
23	.362	.3511	.2987		.3547	.3326	
24	.2957	.2614	.2957	.2614	.2683	.2614	.2587
Max	.439	.4854	.4938	.3174	.4805	.4854	.3174
Min	.1991	.2033	.2195	.2149	.1829	.2012	.1646
Avg	.2883	.2888	.3117	.2506	.2690	.3058	.2449

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 204 / 11 KV SURUPALI GAOTHAN

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4066	.4108	.4294	.4108		.3734	.4251
2	.4066	.3734	.4066	.4108		.3734	.4066
3		.3734	.4066	.415	.3292	.3734	
4	.4251	.4108	.4066	.4294		.4108	
5	.4668	.4854	.4854	.4854		.4481	.4435
6	.5415	.5853	.5601	.5788	.3658	.6283	.6348
7	.6348	.6036	.5788	.5914		.5304	.5975
8	.5601	.5487	.5228	.567	.4024	.5121	.5415
9	.5068	.5068		.5121	.4207		.5487
10	.5611	.4854	.4049	.4706	.4294	.4755	.5304
11	.5068	.5041		.4344	.4435		
12	.5194	.4668	.5121	.4477	.4066	.4572	.5121
13	.4835	.5041		.3982	.4668		.5121
14	.4656	.4294		.4835	.3881	.4572	.439
15	.4656	.4066	.4024	.4119	.3511		.5487
16	.5194	.4435	.4207	.3582	.3881	.4207	.5304
17	.4706	.5041		.4525	.4668	.4572	.4938
18	.4887	.4294	.439			.4668	
19	.6584	.6535	.5853		.5853	.6348	
20	.7316	.7842	.6767		.7133	.7095	
21	.695	.7095	.6401		.7207	.6908	
22	.6283	.6535	.5914		.6099	.6348	
23	.499	.5601	.4668		.4481	.5228	
24	.4251	.4481	.4294	.4294	.4024	.4108	.4435
Max	.7316	.7842	.6767	.5914	.7207	.7095	.6348
Min	.4066	.3734	.4024	.3582	.3292	.3734	.4066
Avg	.5246	.5117	.4929	.4604	.4632	.4994	.5072

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 205 / 11 KV Banage Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0972	1.5927	1.9231	1.8823		.1448	.1134
2		1.5927	1.8671	1.8625		.1448	.1134
3		1.5565	1.6991	1.8625		.1448	
4	.0983	1.5203	1.7364	1.9909		.1448	
5		1.5384	1.9231	2.1849		.1629	.1147
6	.0983	1.5927	2.0351	2.3167		.1629	.1296
7	.1134	2.0237	2.3339	2.6425		.1433	
8	.1147	2.1971	2.7073	2.8296	.1677	.1612	.1311
9	.1227	2.0858		2.4356	.2012		.1296
10	2.0157	.1147	.1296	.1753	2.7073	2.079	2.2986
11	2.3137	.1134		.1543	3.5662		3.1131
12	2.6467	.1311		.1715	3.5101	2.8837	3.1131
13	2.4006			.1886	3.5288		3.0769
14	2.4348	.1311		.2229	3.3234	2.8166	2.9864
15	2.2977		.1677	.2229	3.1367		2.7873
16	2.2119	.1147		.2279	2.726	2.5484	2.6787
17	2.191	.1311		.2279	2.7446	2.4143	2.5339
18	.1402	.1638	.1619			.1147	
19	.1433		.1619		.2172		
20	.1791	.1311	.1619		.181	.1147	
21	.1612		.1619		.181		
22	.1448	.1311	.1619		.1629	.1296	
23	.1448	.1311			.1448	.1147	
24	.0983	1.6108	1.7551	1.7337	.1509	.1448	.1134
Max	2.6467	2.1971	2.7073	2.8296	3.5662	2.8837	3.1131
Min	.0972	.1134	.1296	.1543	.1448	.1147	.1134
Avg	.9604	.9302	1.1929	1.2963	1.6656	.8094	1.5622

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144019 / 33/11 KV SONAGE S/S

Feeder No / Name : 206 / CHIKHALI AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0456	.0905	.0655	.0486		1.086	1.3443
2	1.0269	.0905		.0486		1.086	1.307
3	.9896	.0905	.081	.0486	1.0395	1.086	
4	.9896	.0905		.0486		1.1584	
5	1.0269	.0905		.0648		1.3032	1.3817
6	1.1016	.0895	.0983	.0648	1.3916	1.5043	1.5497
7	1.4003	.0895		.0648		1.7551	1.7177
8	1.643	.0895	.0819	.0486	1.6095	1.773	1.8298
9	1.5074	.0876		.0324	1.4083		1.5089
10	.0876	1.8858	1.9433	1.5261	.0655	.0503	.0648
11	.0876	2.0538		1.7833			.0648
12	.0876	2.0351	1.8778		.0655		.0648
13	.0175			1.7147			.0648
14	.0175	1.8671	1.6095			.0503	.0648
15	.0175	1.9605	1.6095	1.4746	.0655		.0648
16	.0175	1.9044	1.5424	1.6289		.0335	.0648
17	.0181	1.8484			.0819	.0335	.0648
18	.0716	.0819	.081			.081	
19	.1075		.081				
20	.0895		.0648		.0537	.0819	
21	.1075		.0648		.0724		
22	.0905	.0819	.0648		.0724	.0655	
23	.0905	.0648	.0648		.0724	.0655	
24	1.0642	.0905	.0492	.0486	1.1401	1.1222	1.2323
Max	1.643	2.0538	1.9433	1.7833	1.6095	1.773	1.8298
Min	.0175	.0648	.0492	.0324	.0537	.0335	.0648
Avg	.5293	.7341	.5862	.5764	.5491	.7256	.7744



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 201 / 11 KV MURGUD Ag

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2			.8916	1.046			.1052
4		1.4003	1.3717	1.0117			.1052
6		1.5337	1.7147	1.6118			.0876
7		1.587					
8		1.6004	2.2119	2.0233			.0876
9				1.917			
10	1.7071	.12	.1052	.1029	1.749	2.1262	2.1376
11					2.332		2.4291
12			.1052		2.4006	2.6578	2.4615
13							2.3644
14	2.1072		.1052		2.3148	2.5892	2.3644
15	2.0271				2.4691		2.2996
16			.1052	.1029	2.4006	2.4691	2.3644
17					2.3663	2.2977	2.332
18			.1052		.12	.1052	.1029
20			.1052			.1052	
22			.1052			.1052	
23	.08		.1052	.1029			.0972
24	1.1797	.4001	.6001	1.0802			.1052
Max	2.1072	1.6004	2.2119	2.0233	2.4691	2.6578	2.4615
Min	.08	.12	.1052	.1029	.12	.1052	.0876
Avg	1.4202	1.1069	.5870	.9999	2.0191	1.5570	1.2963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 208 / 11 KV Murgud VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6348				.6348		
2	.6348	.5487	.5487	.5792	.5975	.5487	.5792
3	.5975				.5975		
4	.6348	.4268	.5144	.543	.5975	.6001	.543
5	.6348				.6348		
6	.7468		.4458	.6154	.6722	.5658	.6878
7	.6722	.6516			.7095		
8	.6348	.6173	.6344	.5784	.6722	.6173	.631
9				.6283			
10	.5487	.583	.6135	.6283	.5487	.5784	.695
11		.5658		.6283	.4458		.695
12		.6001	.631	.6584	.5144	.5784	.6219
13		.5658		.6584			.6878
14	.5487	.583	.6135	.6584	.5487	.631	.6878
15	.583	.5487		.6584	.5144		.7316
16		.6001	.6135	.6584	.5487	.6836	.695
17		.6516		.724	.5601	.7011	.7316
18		.7716	.724	.7316	.703	.724	.8413
19		.9088			.8745		.9709
20		.9259	.9955		.9088	1.0136	1.0829
21		.8916			.8573		.8962
22		.823	.8326		.823	.7602	
23	.6516		.724	.6722			.7842
24	.6722	.6173	.6001	.6154		.583	.6335
Max	.7468	.9259	.9955	.7316	.9088	1.0136	1.0829
Min	.5487	.4268	.4458	.543	.4458	.5487	.543
Avg	.6304	.6600	.6532	.6398	.6482	.6604	.7331

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144020 / 33/11 KV MUDHAL THITA

Feeder No / Name : 403 / 33 KV Sonali LIS

PURELY LIS FEEDERS

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
3	.0543			.0549		.0549
4	.2172	.2401	.2801		.168	.1646
5	.4344			.3292		
6	.4344	.3201	.3921		.2801	.2743
7	.4344	.3601		.439		
8	.4344	.3201	.4481	.439	.2801	.3292
9				.4344		.3258
10	.2801	.5041	.439	.4344	.2743	.3258
11		.5041		.3258		.3258
12		.4481	.439	.3258	.2743	.3258
13		.4481		.4344		.3258
14	.3201	.4481	.3841	.4344	.2743	.3258
15	.3201	.4481		.4344		.3258
16		.4481	.439	.4344	.2743	.3258
17		.3921		.4344	.2743	.3258
18		.056		.0543		.0543
Max	.4344	.5041	.4481	.439	.2801	.3292
Min	.0543	.056	.2801	.0543	.168	.0543
Avg	.3255	.3798	.4031	.3578	.2625	.2721

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 201 / Bhadgaon AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8309	.061	.0509	.061	.7373	.8059	.7373
2	.8648	.061	.0509	.061	.7373	.7716	.7373
3	.8648	.061	.0509	.061	.7202	.7545	.7373
4	.8648	.061	.0509	.061	.7545	.7716	.7373
5	.8817	.061	.0678	.061	.823	.8745	.8573
6	1.2378	.061	.0678	.061	.9602	1.046	.9602
7	1.6278	.061	.0509	.061	1.3889	1.5089	1.4575
8	1.9161	.04	.0509	.0457	1.5927	1.7318	1.6118
9	1.7804	.0457	.0509	.0457	1.4754	1.5432	1.4746
10	.0509	1.7833	1.4582	1.3413		.0457	.0486
11	.0343	2.2213	1.7814	2.079		.0509	.0457
12	.0343	2.1534	2.0178	2.1963		.0509	.0305
13	.0286	2.0517	1.8652	2.0287	.061	.0509	.0633
14	.0533	1.8482	1.7635	1.861	.0655	.0509	.061
15	.0533	1.8143	1.8652	1.8347	.0663	.0509	.061
16	.0533	1.9161	1.8143	1.7147	.0648	.0492	.061
17	.0533	1.7126	1.7101	1.7147	.0663	.0509	.0474
18	.061	.0509	.061	.04	.061	.0492	.061
19	.061	.0509	.061	.0457	.061	.0497	.061
20	.061	.0509	.061	.0457	.061	.0497	.061
21	.0533	.0678	.0686	.0457	.061	.0648	.061
22	.061	.0678	.061	.061	.061	.0655	.061
23	.061	.0678	.061	.0686	.061		.064
24	.8139	.061	.061	.061	.7373	.823	.703
Max	1.9161	2.2213	2.0178	2.1963	1.5927	1.7318	1.6118
Min	.0286	.04	.0509	.04	.061	.0457	.0305
Avg	.5168	.6846	.6334	.6524	.5056	.4917	.4500

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 202 / Sonali AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1357	2.0748	1.7974	1.6766	.1372	.1372	.0972
2	.1357	2.0919	1.8143	1.6787	.1372	.1372	.0972
3	.1187	2.0576	1.7974	1.6598	.1372	.1372	.0972
4	.1187	1.9719	1.7804	1.643	.1372	.1372	.0972
5	.1187	1.989	1.7804	1.7804	.1372	.1372	.0972
6	.1357	2.0062	1.95	1.9616	.1543	.1372	.1134
7	.1526	2.4177	2.2891	2.323	.1543	.1543	.1296
8	.1865	2.6235	2.323	2.4813	.1715	.1543	.1457
9		2.332	2.2213	2.4143	.1417	.1543	.1457
10	2.3739	.1372	.1187	.0937		2.2298	2.0576
11	2.7606	.1543	.1219	.1543		2.9673	2.5549
12	2.7606	.1357	.1372	.1715		2.8995	2.7808
13	2.7263	.1526	.1372	.1715	2.5987	2.8826	2.5652
14	2.572	.1696	.1543	.1715	2.915	2.7469	2.3472
15	2.5892		.1715	.1715	2.7435	2.713	2.5652
16	2.572	.1357	.2058	.1543	3.0007	2.5943	2.5484
17	2.5549	.1865	.2572	.1886	2.8121	2.5434	2.4863
18	.1543	.2035		.2229	.1029	.1357	.0686
19	.1715	.1696	.1543	.2229	.1372	.1457	.12
20	.1543		.1543	.1715	.1372	.1457	.1341
21	.1543	.1357	.12	.1715	.1372	.1326	.1372
22	.1543	.1357	.12	.1543	.1372	.1296	.1372
23	.1029	.1526	.096	.1543	.1372		.112
24	.1357	2.0233	1.6004	1.7126	.1543	.1372	.0972
Max	2.7606	2.6235	2.323	2.4813	3.0007	2.9673	2.7808
Min	.1029	.1357	.096	.0937	.1029	.1296	.0686
Avg	1.0017	1.0662	.9262	.9044	.7772	1.0300	.9055

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 203 / Sawarde VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5087	.5906	.5256	.6413	.6097	.6287	.6154
2	.4917	.5716	.5087	.6036	.5906	.6097	.6099
3	.4748	.5525	.4744	.6036	.5716	.5716	.5914
4	.4748	.5716	.4917	.6224	.5906	.5906	
5	.5935	.6097	.5596	.6413	.6478	.6668	.6468
6	.6613	.6722	.6952	.7356	.7468	.7655	.7577
7	.6783	.6908	.7122	.6722	.6535	.7468	.6878
8	.6274	.6722	.6274	.6468	.567	.7023	.7059
9	.4239	.6722	.6104	.6733	.5973	.6653	.6516
10	.6443	.5847	.5765	.567		.5493	.5914
11	.6219	.5426	.6201	.591		.5596	.5611
12	.5304	.5596	.5973	.6268		.5935	.6335
13	.5487	.5426	.5973	.6089	.6584	.5935	.6335
14	.5544	.5426	.5792	.6099	.6283	.5256	.6154
15	.499	.5256	.2374	.5914	.6099	.5087	.5729
16	.5359	.5935	.5792	.6838	.5792	.5087	.5552
17	.5487	.5087	.5304	.6468	.6653		.591
18	.5914	.6104	.5731	.7282	.6348	.6613	.6805
19	.8316	.8648	.8688	.8962	.9425	.9231	.9145
20	1.0642	1.0343	1.1157	1.0642	1.0456	1.1403	1.0534
21	.9709	.8648	1.0164	.9896	.9896	1.0317	.9593
22	.8402	.78	.9522	.8865	.9242	.905	.8962
23	.679	.6104	.7545	.6979	.724		.7167
24	.5256	.6097	.5426	.6602	.6287	.6668	.6335
Max	1.0642	1.0343	1.1157	1.0642	1.0456	1.1403	1.0534
Min	.4239	.5087	.2374	.567	.567	.5087	.5552
Avg	.6217	.6407	.6394	.6954	.6955	.6870	.6902

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 144097 / 33/11KV KURANI

Feeder No / Name : 204 / MALAGE AGRICULTURAL  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5935	.0381	.0339	.0343	.6516	.703	.703
2	.6104	.0381	.0339	.0339	.6344	.6859	.703
3	.6104	.0381	.0339	.0343	.6173	.6859	.703
4	.6274	.0381	.0339	.0343	.6516	.7202	.7373
5	.7122	.0381	.0339	.0343	.7545	.7888	.9088
6	.8817	.0381	.0339	.0343	.8916	.9774	1.1145
7	1.153	.0343	.0339	.0343	1.2517	1.4746	1.5089
8	1.3735	.0343	.0339	.0343	1.4403	1.6804	1.5775
9	1.3904	.0305	.0343	.0514	1.4922	1.5604	1.5261
10	.0509	1.7833	1.7804	1.358		.061	.0486
11	.061	1.9839	1.9662	1.9376		.0678	.0328
12	.0457	1.8991	2.0856	1.8442		.0678	.0343
13	.0457	1.8313	2.0454	1.9784	.0332	.0509	.0514
14	.0305	1.95	1.8107	1.8778	.0328	.0509	.0343
15	.0305	1.8821	1.8143	1.869	.0492	.0509	.0514
16	.0305	1.9161	1.7939	1.8347	.0492	.0678	.0514
17	.0457	1.7974	1.7101	1.6975	.0655	.0509	.0686
18	.0457	.0509	.0663	.0457	.0762	.0509	.0857
19	.0305	.0339	.0686	.0457	.061	.0648	.0686
20	.0305	.0339	.0514	.0457	.061	.0648	.0503
21	.0305	.0509	.0686	.0457	.0457	.0486	.0514
22	.0305	.0339	.0343	.0514	.0514	.0486	.0514
23	.0305	.0339	.0332	.0514	.0514		.0503
24	.5765	.0381		.0335	.6001	.703	.703
Max	1.3904	1.9839	2.0856	1.9784	1.4922	1.6804	1.5775
Min	.0305	.0305	.0332	.0335	.0328	.0486	.0328
Avg	.3778	.6519	.6798	.6267	.4553	.4663	.4548

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045]

BU 7153

Substation No/ Name :- 148020 / 220/33KV Hamidwada S.St.

Feeder No / Name : 401 / 33KV Hamidwada

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.5041
Max	.5041
Min	.5041
Avg	.5041



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

MURGUD[045] BU 7153

Substation No/ Name :- 148020 / 220/33KV Hamidwada S.St.

Feeder No / Name : 405 / SHRI DUTT INDIA INDUSTRIAL NON SHEDDABLE EXPRESS HV FEEDERS  
EXP Feeder KV- 33 / OUTGOING (CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.2801
Max	.2801
Min	.2801
Avg	.2801

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 201 / 11KV WALWA VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5914		.5121			.5731
2	.5415	.5729		.4961	.4854		.5373
3		.5914		.4961			.5544
4	.6161	.6283		.5258	.5228		.6516
5	.7095	.7316		.6344	.6908		.7712
6	1.0082	1.0059		.8328	.8962	1.0974	1.0498
7	.9709	.9328	1.0242	.9134	.7842	1.0608	.8954
8		.7499	.7602	.7973	.5975	.8215	.7011
9	.7095	.6584	.6697	.6984		.8215	.7522
10	.7133	.6584	.5959	.6908		.6767	.6722
11	.6401	.6584	.6733	.5601		.5853	.6535
12	.6036	.5853	.591			.5959	
13	.567	.6219	.6024	.5228		.6201	
14	.6219	.6584	.6335	.6348		.5609	.6535
15	.6036	.6584	.6135			.6379	.6722
16	.6584	.6584	.631			.691	
17	.695	.8048	.6653			.7701	
18	.8048	.7499	.8326			.8505	.7095
19	1.0242	1.0608	.9745	.8775		.9134	.9149
20	1.0425	1.0425	1.0425	1.0082	1.134	1.0208	
21	.8962	.9877	.9328	.9055	1.0974	.9134	.9149
22	.823	.8413	.7164	.7842	.9877	.8764	.8215
23	.7316		.6036			.7186	
24	.5601	.6036	.5304	.543	.5041	.7095	.591
Max	1.0425	1.0608	1.0425	1.0082	1.134	1.0974	1.0498
Min	.5415	.5729	.5304	.4961	.4854	.5609	.5373
Avg	.7319	.7414	.7274	.6907	.7700	.7864	.7272

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 203 / 11 KV THIKPURLI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5601	.5487		.4784	.5228		.5194
2	.5415	.5304		.4938	.5228		.5121
3		.5487		.5014			.5014
4	.5601	.5853		.5138	.5601		.5853
5	.6535	.7133		.6089	.6468		.6485
6	.8775	.9145		.6661	.8402	.9335	.8779
7	.8775	.8962	.7316	.788	.8029	.8589	.7421
8		.7682	.7095	.6556	.6535	.7095	.6626
9	.6468	.5853	.5975	.5731		.6348	.567
10	.5304		.5487	.4108		.567	.5975
11	.543	.5228	.4298	.4668		.5487	.6161
12	.4755	.4854	.567				
13	.5304	.5601	.567	.4854			
14	.543	.3734	.5487	.4854		.5373	.6468
15	.5487	.5487	.567			.5493	.6722
16	.6219	.6219	.5853			.567	
17	.6584	.5601	.6024			.6556	
18	.6584	.5975	.5373	.5601		.6447	.7095
19	.8779	.8402	.7682			.7164	.8962
20	.9145	.8413	.8048	.8215	.9145	.8063	
21	.8779	.8413	.7164	.7842	.8779	.9328	.8215
22	.8413	.7682	.6447	.7842	.8048	.8596	.8215
23	.6767		.5609			.6661	
24	.5601	.5853	.5975	1.6289	.5601	1.195	.5731
Max	.9145	.9145	.8048	1.6289	.9145	1.195	.8962
Min	.4755	.3734	.4298	.4108	.5228	.5373	.5014
Avg	.6625	.6471	.6158	.6504	.7006	.7284	.6650

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 204 / 11 KV ARJUNWADA AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	01-APR-18
HR	Load (MW)
24	2.7435
Max	2.7435
Min	2.7435
Avg	2.7435

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144024 / 33/11KV WALWA S/S

Feeder No / Name : 205 / 11 Kv Gahininath Ag LIS

PURELY LIS FEEDERS

Expres Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
6						.0671
7		.0905			.0762	.0671
8		.0905	.0724	.0663	.0762	.0819
9		.0905	.0781	.0663	.0762	.0819
10	.0905	.0533	.0838		.0905	.0934
11	.0905	.0533	.0663	.0747	.0905	.0934
12	.0905	.0724	.0663		.0838	
13	.0905	.0724	.0829	.0747	.0686	
14	.0905	.0724	.08	.0747	.0686	.0934
15	.0905	.0724	.0671		.0663	.0934
16	.0905	.0724	.0663		.0686	
17	.0905	.0781	.064		.0686	
18			.0655		.0686	.0934
19				.0747		
Max	.0905	.0905	.0838	.0747	.0905	.0934
Min	.0905	.0533	.064	.0663	.0663	.0671
Avg	.0905	.0744	.0721	.0719	.0752	.085

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 201 / 11 KV DHAMOD AG

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0341				.9465		
2	1.0229				.9362	1.0749	
3	1.0517				.9189		
4	1.0517				.9991		
5	1.0867				1.1043	1.3003	
6	1.1043			.0177	1.3321		1.1218
7			.0191	.0177	1.4043	1.3696	1.1919
8	1.4198	.0191	.0191	.0177	1.4548	1.4723	1.2269
9			.0191	.0177			1.2094
10	.0177		1.595	1.4217	.0177	.0173	.0175
11	.0191		1.6297	1.4373	.0191	.0175	.0191
12			1.4548	1.387		.0175	
13	.0191	1.4737	1.4175	1.4548		.0173	.0191
14			1.382	1.4899	.0191	.0177	
15			1.3466	1.3696		.0177	.0191
16	.0191	1.6991	1.2934		.0191	.0177	
17			1.4352	1.3146		.0177	.0191
18	.0191	.0191	.0175	.0177	.0191	.0179	
19	.0191					.0175	
20			.0179	.0177		.0177	
21		.0191	.0177	.0177		.0177	
22			.0177	.0177	.0191	.0177	.0191
23	.0191		.0177	.0177		.8939	
24	.9991	.0191	.0191	.0175	.8764	.9015	
Max	1.4198	1.6991	1.6297	1.4899	1.4548	1.4723	1.2269
Min	.0177	.0191	.0175	.0175	.0177	.0173	.0175
Avg	.5935	.5415	.6894	.5913	.6724	.3811	.4863

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 202 / 11 KV KELOSHI AG  
Feeder KV- 11 / OUTGOINGSEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0177				.0177		
2	.0177				.0177	.0191	
3	.0177				.0175		
4					.0175		
5	.0177				.0175	.0191	
6	.0177			1.3889	.0175		.0173
7			1.8204	1.6991	.0177	.0191	.0173
8	.0175	1.97	1.8551	1.7511	.0177	.0191	.0173
9			1.8204	1.7164			.0171
10	2.6699		.0175	.0173	1.9591	1.9418	2.0285
11	2.6505		.0171	.0177	2.2712	2.4619	2.6353
12			.0171	.0177		2.4691	
13	2.6505	.0191	.0171	.0177		2.3926	2.774
14			.0173	.0177	2.3891	2.3059	
15			.0173	.0175		1.9244	2.5659
16	2.2923	.0191	.0173		3.5715	2.0458	
17			.0173	.0177		1.9071	2.2885
18	.0191	.0191	.0173	.0177	.0191	.0175	
19	.0191					.0171	
20			.0175	.0177		.0175	
21		.0191	.0173	.0177		.0175	
22			.0173	.0177	.0191	.0173	.0191
23	.0191		.0173	.0175		.0175	
24	.0177	1.0387	1.0576	1.9718	.0177	.0191	.0173
Max	2.6699	1.97	1.8551	1.9718	3.5715	2.4691	2.774
Min	.0175	.0191	.0171	.0173	.0175	.0171	.0171
Avg	.7460	.5142	.3987	.5141	.6925	.9289	1.1271

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 203 / 11KV DHAMOD-KELOSHI

GAOTHAN FEEDER

VILLAGE Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1402				.1227		
2	.1227				.1227	.1214	
3	.1227				.1227		
4	.1227				.1227		
5	.1578				.1753	.208	
6	.1928			.2058	.2454		.2601
7			.2947	.2743	.298	.3121	.2774
8	.2804	.3224	.2947	.2572	.2804	.2774	.2572
9			.3121	.2401			.2254
10	.2629		.2601	.2401	.2103	.2254	.1886
11	.2149		.2401		.208	.2058	.2254
12			.2058	.1928		.2058	
13	.197	.1907	.208	.2103		.1907	.208
14			.1734	.1578	.156	.156	
15			.156	.1578		.1578	.156
16	.197	.1734	.1734			.208	
17			.1907	.2279			.208
18	.2686	.2254	.2279	.2454	.1907	.2629	
19	.3582					.3772	
20			.3121	.3506		.3814	
21		.2947	.2629	.298		.2947	
22			.2254	.2279	.3121	.2601	.2254
23	.1612		.1734	.1753		.1907	
24	.1402	.1433	.1387	.1372	.1227	.1387	.156
Max	.3582	.3224	.3121	.3506	.3121	.3814	.2774
Min	.1227	.1433	.1387	.1372	.1227	.1214	.156
Avg	.1960	.2250	.2264	.2249	.1921	.2319	.2170



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144025 / 33/11 KV DHAMOD

Feeder No / Name : 204 / 11 KV BURAMBALI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1568				.9816		
2	1.1568				.9816	1.2483	
3	1.2094				.9816		
4	1.2971				1.0867		
5	1.4022				1.2269	1.3003	
6	1.4723				1.3523		1.4548
7					1.387	1.0343	1.595
8	1.3672				1.3696	1.5604	1.5424
9							1.4899
10			1.3496	1.1789			
11			1.5257	1.4737			
12			1.491	1.4723			
13		1.5257	1.439	1.5777			
14			1.4563	1.5083			
15			1.4043				
16		1.6644	1.3523				
17			1.335	1.4022			
24	1.1393				.9536	1.0229	1.1443
Max	1.4723	1.6644	1.5257	1.5777	1.387	1.5604	1.595
Min	1.1393	1.5257	1.335	1.1789	.9536	1.0229	1.1443
Avg	1.2751	1.5951	1.4192	1.4355	1.1468	1.2332	1.4453

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 201 / 11KV TARALE AG (TARLE)

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5089	1.5091	1.0513			
2		1.5089	1.5592	1.0513			
3		1.5261	1.576	1.0562			
4		1.5261	1.5249	1.1736			
5		1.5261	1.643	1.2239			
6		1.8861	1.861	1.6095			
7		2.3739	2.0178	1.9113			
8		2.2801	2.2801	2.0622			
9		2.1125	2.1963	1.8945			
10	2.1605				2.0178	2.3205	.6321
11	2.4691				2.6852	3.0178	2.4383
12	3.0521				3.0178	3.0167	2.6993
13	3.0178				3.152	2.7393	2.7808
14	2.9843				3.0849	2.7092	2.8837
15	2.8837				3.1855	2.2577	2.8166
16	2.6825				3.1184	2.3922	2.6993
17	2.4863				2.8837	2.1643	2.5774
24		1.2929	1.4413	2.4006			
Max	3.0521	2.3739	2.2801	2.4006	3.1855	3.0178	2.8837
Min	2.1605	1.2929	1.4413	1.0513	2.0178	2.1643	.6321
Avg	2.7170	1.7542	1.7609	1.5434	2.8932	2.5772	2.4409

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144026 / 33/11 KV TARALE SUB STSTION

Feeder No / Name : 202 / 11 KV TARALE

GAOTHAN FEEDER

VILLAGE(TARLE) Feeder KV- 11  
/ OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1791	.2587	.2378	.2328	.2378	.2328	.1991
2	.1791	.2587	.2241	.2328	.2378	.2328	.1829
3	.1791	.2561	.2241	.2328	.2218	.2353	.1829
4	.181	.2561	.2587	.2507	.2353	.2353	.2195
5	.2378	.2957	.2926	.3077	.2686	.2743	.2715
6	.2926	.4668	.4435	.4344	.4066	.4481	.4207
7	.4066	.5041	.4668	.4207	.4207	.5041	.4066
8	.4435	.4572	.3696	.3658	.3511	.3921	.3511
9	.3658	.3841	.2926	.3258	.2865		.3292
10	.3109	.3292	.3294	.3077	.2896	.2957	.3109
11	.2926	.2896	.2804	.3109	.2774	.2926	.2926
12	.3326	.298	.2658	.2957	.3155	.2926	.2926
13	.4066	.2865	.2686	.2601	.3189	.3109	.2743
14	.4066	.2865	.2686	.2865	.3045	.3109	.2715
15	.362	.3155	.2686	.2835	.2896	.3109	.2686
16	.3582	.3467	.2686	.3121	.2896	.3109	.2715
17	.362	.3189	.2686	.3121	.3077	.3292	.2683
18	.3439	.3258		.333	.3658	.3658	.3258
19	.499	.4572	.4887	.5014	.499	.4435	.4572
20	.499	.5175	.5121	.4938	.5228	.499	.5121
21	.4854	.4572	.4572	.462	.4854	.4805	.4854
22	.4108	.3921	.4024	.3881	.3881	.3658	.4066
23	.2957	.2957	.3292	.2957	.3109	.2926	.3174
24	.1991	.2772	.2587	.2353	.2587	.2353	.2353
Max	.499	.5175	.5121	.5014	.5228	.5041	.5121
Min	.1791	.2561	.2241	.2328	.2218	.2328	.1829
Avg	.3345	.3471	.3251	.3284	.3287	.3344	.3147

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 201 / 11 KV SHIRGAON AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.285	.2294	.1492			
2		.285	.2458	.1509			
3		.285	.2458	.1677			
4		.3018	.2713	.1677			
5		.3353	.2846	.1844			
6		.4527	.3163	.1989			
7		.5243	.3605	.2321			
8		.5138	.3932	.2347			
9		.3441	.3605	.2683			
10	.4428				.2343	.3315	.3605
11	.4694				.4359	.5693	.57
12	.5138				.3647	.5571	.5365
13	.503				.431	.5571	.5365
14	.503				.3978	.5571	.5426
15	.503				.3605		.5596
16	.5197				.3932	.5571	.5533
17	.5304				.1311	.5243	.5365
24		.2818		.1658			
Max	.5304	.5243	.3932	.2683	.4359	.5693	.57
Min	.4428	.2818	.2294	.1492	.1311	.3315	.3605
Avg	.4981	.3609	.3008	.1920	.3436	.5219	.5244

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 202 / 11 KV PARITE AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.4915	.5898	.5243			
2		.4915	.6226	.5243			
3		.4915	.6226	.5243			
4		.5967	.6882	.5801			
5		.6133	.7274	.5967			
6		.7293	.759	.7293			
7		.9069	.9282	.852			
8		.9717	1.0486	.9175			
9		.8421	.9831	.852			
10	1.2018				.8124	.9175	.7865
11	1.2929				1.0486	1.1797	1.1271
12	1.094				1.0364	1.1797	1.1271
13	1.2597				1.0364	1.1797	1.0608
14	1.2431				.9602	1.1797	1.1065
15	1.2266				.9602		1.0898
16	1.2071				.7682	.9831	1.0562
17	1.065				.7773	.9831	1.0277
24		.4973	.5898	1.3717			
Max	1.2929	.9717	1.0486	1.3717	1.0486	1.1797	1.1271
Min	1.065	.4915	.5898	.5243	.7682	.9175	.7865
Avg	1.1988	.6632	.7559	.7472	.9250	1.0861	1.0477

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 203 / 11 KV AWALI-RADHANAGARI AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.6962	.5898	.852			
2		.663	.6226	.8619			
3		.663	.6882	.8453			
4		.6464	.7537	.8886			
5		.7293	.7865	.9221			
6		.8383	.852	1.0513			
7		.9339	1.0159	1.2209			
8		.9339	1.0486	1.1797			
9		.8848	.3277	1.0814			
10	1.0753				1.0753	.9831	.9175
11	1.1768				1.3435	1.3108	1.3413
12	1.1233				1.3279	1.3435	1.2742
13	1.2266				1.2955	1.3108	1.2407
14	1.2239				1.2803	1.1797	1.2574
15	1.1401				1.2803		1.2407
16	1.1736				1.2483	1.1961	1.2742
17	1.0814				.9503	1.1797	1.1904
24		.7377	.5243	2.0576			
Max	1.2266	.9339	1.0486	2.0576	1.3435	1.3435	1.3413
Min	1.0753	.6464	.3277	.8453	.9503	.9831	.9175
Avg	1.1526	.7727	.7209	1.0961	1.2252	1.2148	1.2171

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 205 / 11 KV AWALI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.362	.4854	.4527	.4481	.4344	.4108	.415
2	.3326	.4715	.415	.4294	.4024	.4108	.3772
3	.3292	.4715	.3772	.4294	.3658	.3734	.3772
4	.362	.4668	.3395	.4481	.439	.4108	.3772
5	.4805	.5788	.5281	.5281	.5175	.5041	.5281
6	.7602	.8215	.8676	.7468	.7682	.8299	.7468
7	.7682	.8589	.679	.7392	.7392	.7842	.679
8	.6878	.7316	.6413	.6584	.6516	.6348	.5914
9	.5544	.5249	.5544	.543	.4755	.5121	.4854
10	.5068	.4887	.4755	.5068	.439	.4706	.439
11	.4477	.499	.4706	.439	.394	.4755	.3544
12	.4557	.499	.5068	.4024	.394	.439	.394
13	.394	.499	.4344	.3142	.394	.439	.3582
14	.439		.4755	.4344	.4252	.439	.3658
15	.439	.5914	.5068	.4024	.3898		.4066
16	.5375	.6283	.5487	.439	.4252	.5853	.4681
17	.5609	.6283	.5731	.543	.3982	.5853	.4706
18	.5258	.6283	.5548	.5544	.5014	.5487	.4887
19	.823		.8215	.7316	.7762	.6653	.724
20	.9149	.924	.8962	.8501	.8215	.8501	.8488
21	.8775	.8501	.8215	.7842	.7922	.7762	.811
22	.7842		.7468	.6516	.7167	.6722	.6584
23	.6161	.5601	.5601	.5487	.5281	.5228	.4938
24	.4344	.5228	.4904	.4854	.4755	.4527	.4527
Max	.9149	.924	.8962	.8501	.8215	.8501	.8488
Min	.3292	.4668	.3395	.3142	.3658	.3734	.3544
Avg	.5581	.6062	.5724	.5441	.5277	.5562	.5130

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 206 / 11KV KANTHEWADI AG.

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		.3353	.2458	.2347			
2		.3521	.2949	.2543			
3		.3521	.3441	.2543			
4		.3521	.3932	.2883			
5		.4527	.4588	.3429			
6		.6371	.5243	.4801			
7		.7042	.5898	.6173			
8		.7712	.6554	.6706			
9		.7377	.5898	.6371			
10	.6249				.6554	.5365	.5571
11	.7545				.8718	.852	.8383
12	.788				.8718	.852	.8718
13	.8215				.9054	.852	.8383
14	.8718				.8718	.8192	.8551
15	.8383				.9054		.8215
16	.788				.8718	.7865	.788
17	.7377				.3018	.7701	.7209
24		.3353	.1638	.2486			
Max	.8718	.7712	.6554	.6706	.9054	.852	.8718
Min	.6249	.3353	.1638	.2347	.3018	.5365	.5571
Avg	.7781	.5030	.4260	.4028	.7819	.7812	.7864



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144027 / 33/11 KV Aawali

Feeder No / Name : 207 / 11 KV SHIRGAON VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.3018	.2641	.3174	.2896	.3174	.3018
2	.2772	.2829	.2641	.2987	.2534	.2987	.3018
3	.2561	.2829	.2641	.2987	.2561	.2987	.3018
4	.2715	.3206	.2829	.3361	.2926	.3361	.3772
5	.362	.3961	.3961	.3772	.362	.3734	.4904
6	.6099	.5975	.6036	.5847	.5914	.6535	.6036
7	.5304	.5788	.5281	.6283	.5249	.5975	.5228
8	.4805	.4805	.4715	.5121	.4435	.4805	.4805
9	.3841	.4163	.3881	.3982	.362	.4024	.4066
10	.362	.3801	.3841	.362	.3658	.3439	.3292
11	.2507	.3511		.3258	.3045	.3658	.2835
12	.298	.3326	.3258	.3077	.2686	.3109	.2865
13	.3224	.2957	.3403	.3258	.3045	.3292	.3045
14	.2926		.3077	.3292	.3012	.3109	.2957
15	.2926	.3326	.3077	.3258	.3012		.3326
16	.3801	.3881	.3658	.3696	.3189	.3841	.3439
17	.4382	.4805	.394	.4066	.3439	.4207	.3898
18	.4458	.462	.3988	.4251	.3582	.4572	.3856
19	.5611		.5359	.5487	.4805	.499	.567
20	.5914	.5914	.5975	.567	.4854	.6283	.6036
21	.5601	.5544	.5415	.543	.4904	.5601	.5601
22	.5041		.4854	.4755	.4481	.4481	.4435
23	.3734	.3734	.3921	.3982	.3734	.3961	.3696
24	.3077	.3361	.2641	.3361	.3109	.3547	.3395
Max	.6099	.5975	.6036	.6283	.5914	.6535	.6036
Min	.2507	.2829	.2641	.2987	.2534	.2987	.2835
Avg	.3929	.4064	.3958	.4082	.3680	.4160	.4009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 144028 / 33/11KV HASANE SUB-STATION

Feeder No / Name : 201 / 11KV DIGAS FEEDER

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	01-APR-18
HR	Load (MW)
24	.7716
Max	.7716
Min	.7716
Avg	.7716

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 201 / 11 KV SOLANKUR AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.1145	1.0277	.9259			
2		1.1145	1.0277	.9259			
3		1.1145	1.0317	.9602			
4		1.1145	1.0341	1.0117			
5		1.166	1.1218	1.1317			
6		1.6804	1.4529	1.5089			
7		2.4006	2.2961	2.3491			
8		2.7435	2.6755	2.5206			
9		2.572	2.3487	2.4177			
10	2.9492				2.0508		2.2462
11					2.8045	3.2579	3.1207
12	3.0007				3.0476		3.0864
13	3.0693				2.8746	2.8464	2.9492
14	3.0693				2.8349	2.6406	2.9664
15					.5959	2.5377	2.7435
16	3.2579				1.9313	2.4348	2.6235
17	2.9492				2.2805	2.3137	2.3663
18	2.5892						
24		1.1145	.964	1.8861			
Max	3.2579	2.7435	2.6755	2.5206	3.0476	3.2579	3.1207
Min	2.5892	1.1145	.964	.9259	.5959	2.3137	2.2462
Avg	2.9835	1.6135	1.4980	1.5638	2.3025	2.6719	2.7628

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 202 / 11KV KALAMMAWADI

FEEDER SEPERATION/PURE AG

AG(SOLANKUR) Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5068				.4572	.3429	.3012
2	.5068				.4525	.3429	.298
3	.4706				.4024	.3429	.298
4	.4805				.3658	.3429	.3189
5	.5487				.4344	.3772	.3721
6	.543				.4835	.4115	.4908
7	.7164				.7164	.6516	.6024
8	.8238				.7522	.6173	.7011
9	.6626				.7316	.6516	.7442
10		.7712	.8907	.583			
11		.9036	1.0631	.8573			
12		.929	1.0745	.8916			
13		.9465	1.086	.8573			
14		.9114	.9922	.8573			
15		.815	.9671	.823			
16		.8328	.9114	.7545			
17		.7712	.8764	.7202			
24	.5068				.362	.3429	.298
Max	.8238	.9465	1.086	.8916	.7522	.6516	.7442
Min	.4706	.7712	.8764	.583	.362	.3429	.298
Avg	.5766	.8601	.9827	.7930	.5158	.4424	.4425

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 203 / 11KV SOLANKUR VILLEGE

GAOTHAN FEEDER

FEEDER Feeder KV- 11 /  
OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5544	.5144	.5609	.4801	.5487	.4458	.5258
2	.5601	.5144	.5258	.4458		.4458	.4908
3	.5544	.5144	.5373	.4458	.5544	.4458	.4908
4	.5914	.5144	.5434	.4458	.5487	.4801	.5258
5	.7316	.5487	.6836	.6173	.6653	.583	.631
6	.8779	.7888	.8238	.6173	.7762	.823	.8505
7	.9145	.7888	.8589	.7888	.7392	.7888	.7888
8	.8316	.7202	.7362	.6859	.6838	.6516	.6836
9	.7947	.6516	.631	.6516	.1109	.583	.6379
10	.6859	.6661	.6653	.6516	.1052	.6516	.6344
11	.6859	.6661	.7392	.6516	.1052	.6344	.6516
12	.5487	.6556	.5914	.583	.1052	.6001	.6516
13	.5487	.5959	.2957	.6173	.2481	.5487	.6516
14		.5609		.6173	.2454	.583	.6516
15	.6516	.6379	.6653	.583	.7011	.6344	.6516
16	.6859	.6485	.695	.5487	.7011	.6859	.6859
17	.7545	.631	.7392	.6516	.6859	.7087	.7202
18	.7202	.7316	.6173	.7023	.7545	.7362	.7545
19	.9602	.9114	.8916	1.0719	.9945	.9465	.9945
20	1.0631	1.0631	.9945	.9979		1.0517	1.0631
21	.8916	.964	.8573	.924	.9259	.9816	.9259
22	.823	.9114	.7202		.7888	.8764	.7545
23	.6859	.724	.583		.583	.6661	.6173
24	.5544	.5144	.5959	.5144	.5544	.4801	.5258
Max	1.0631	1.0631	.9945	1.0719	.9945	1.0517	1.0631
Min	.5487	.5144	.2957	.4458	.1052	.4458	.4908
Avg	.7248	.6849	.6762	.6497	.5512	.6680	.6900

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144066 / 33/11 KV SOLANKUR S/S

Feeder No / Name : 204 / 11KV AAINI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1848	.1715	.1402	.1372		.1372	.1595
2	.1848	.1715	.1402	.1372	.1663	.1372	.1402
3	.1663	.1715	.1402	.1372	.1663	.1372	.1417
4		.1715	.1595	.1715	.1663	.1372	.1578
5	.2241	.1715	.1928	.2058	.1848	.1715	.1595
6	.2614	.2229	.2629	.2401	.2218	.2058	.2126
7	.2614	.2401	.2629	.2058	.2218	.2401	.2481
8	.2218	.2401	.2454	.2058	.2801	.2058	.1949
9	.2402	.2572	.3155	.2058	.2587	.2058	.3189
10	.2743	.2103	.3696	.1715	.2195	.2058	.2572
11	.2743	.1949	.2743	.1372	.2835	.2401	.3772
12	.2743	.1949	.2587	.1715	.3012	.2401	.2915
13		.1578	.2033	.1715	.1227		.3086
14		.1578		.1372	.2103	.2743	.2401
15		.1949	.2033	.2229		.3086	.2401
16		.2804	.296	.2058	.2804	.2572	.2743
17	.2058	.3012	.3326	.1886	.1715	.3506	.2743
18	.2229	.2804	.2743	.2218	.2743	.3012	.2743
19	.3086	.3681	.3086	.3696	.3086	.3189	.3086
20	.3429	.3506	.3086	.3696	.3429	.3012	.3429
21	.3086	.3109	.3086	.2957	.3086	.2629	.2915
22	.2743	.2804	.2401		.2401	.2454	.2572
23	.2401	.2103	.1715		.1715	.1753	.2058
24	.1848	.1715	.1753	.1372	.1663	.1715	.1578
Max	.3429	.3681	.3696	.3696	.3429	.3506	.3772
Min	.1663	.1578	.1402	.1372	.1227	.1372	.1402
Avg	.2450	.2284	.2428	.2021	.2303	.2274	.2431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 201 / 11 KV KALAMMAVADI VG

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2772	.2587	.2957	.2218	.2402	.2587	.2402
2	.2772	.2587	.2587	.2218	.2402	.2587	.2402
3	.2772	.2587	.2587	.2218	.2402	.2402	.2402
4	.2772	.2587	.2587	.2218	.2402	.2402	.2587
5	.2772	.2957	.2772	.2402	.2587	.2772	.2957
6	.3326	.3326	.3696	.2772	.3142	.3696	.3696
7	.2218	.3696	.4066	.3326	.3326	.3696	.4066
8	.3881	.3696	.3511	.3326	.3142	.3881	.3511
9	.3326	.3511	.3326	.3326	.2587	.3326	.3511
10	.2957	.3142	.2957	.3326	.2587	.3696	.3511
11	.3142	.3696	.3326	.3511	.2587	.3696	.3881
12	.3326	.3142	.3511	.3142		.4066	.4294
13	.3326	.3142	.3696	.3326	.4251	.4251	.3881
14	.3142	.3326	.3142	.3174	.3696	.3881	.4066
15	.3326	.3326	.3045	.3142	.3142	.4251	.3696
16	.3326	.3511	.3881	.3142	.3142	.4251	.3696
17	.3511	.3696	.3326	.3511	.3326	.4435	.3696
18	.3696	.3511	.3696	.3326	.2957	.4251	.3881
19	.4805	.4805	.5359	.4805	.462	.5175	.5914
20	.5544	.5544	.5359	.5729	.499	.5729	.5544
21	.4805	.5175	.4805	.5175	.4435	.5175	.499
22	.4251	.462	.3881	.4251	.4066	.4435	.4251
23	.3511	.2957	.3142	.3326	.3142	.3142	.3142
24	.2957	.2957	.2957	1.8691	.2587	.2587	.2587
Max	.5544	.5544	.5359	1.8691	.499	.5729	.5914
Min	.2218	.2587	.2587	.2218	.2402	.2402	.2402
Avg	.3427	.3504	.3507	.3983	.3214	.3765	.3690

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 202 / 11 KV KUDUTRI VILLAGE

GAOTHAN FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.112	.0924	.112	.0747	.0747	.0747	.0934
2	.0934	.0924	.112	.0747	.0747	.0747	.0934
3	.0934	.0924	.0934	.0747	.0747	.0747	.0934
4	.0934	.0924	.112	.0747	.0747		.0934
5	.112	.1109	.1307	.0934	.0747	.0747	.112
6	.168	.1663	.2054	.168	.168	.1867	.1494
7	.1867	.1848	.2054	.1867	.1494	.1867	.1867
8	.1494	.1848	.1494	.168	.1494	.0168	.168
9	.168	.168	.1848	.168	.1307	.168	.1307
10	.1494	.168	.1663	.168	.1307	.168	.112
11	.168	.1494	.2033	.168	.1307	.112	
12	.1307	.1867	.1663	.1494	.168	.1494	.112
13	.1307	.1494	.1294	.112	.1307	.168	.168
14	.0934	.168	.1294	.1307	.0934	.168	.1494
15	.1494	.1494	.1294	.1494	.0934	.1494	.1307
16	.1494	.1307	.1494	.1494	.1307	.1867	.1867
17	.1663	.1494	.1494	.1494	.112	.1848	.1867
18	.1663	.1307	.168	.168	.1494	.168	.168
19	.2218	.2054	.2614	.2241	.1867	.2241	.2614
20	.2772	.2614	.2801	.2427	.2614	.2801	.2987
21	.2587	.2427	.2427	.2241	.2427	.2614	.2801
22	.2218	.2054	.168	.1867	.2054	.2241	.2241
23	.1478	.112	.0934	.112	.112	.1307	.1307
24	.112	.1109	.112	2.1323	.0934	.0934	.0934
Max	.2772	.2614	.2801	2.1323	.2614	.2801	.2987
Min	.0934	.0924	.0934	.0747	.0747	.0168	.0934
Avg	.1550	.1543	.1606	.2312	.1338	.1533	.1575



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 203 / Fejiwade Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.373	.4239			.5426	.4359
2	.3561	.4239			.5256	.4191
3	.3561	.4239			.5256	.4191
4	.373	.4578			.5256	.4191
5	.373	.4748			.5765	.4359
6	.39	.5426			.6613	.57
7	.6274	.8478			.8478	.6539
8	.6464	.8817			.78	.7209
9	.5967	.8817			.5935	.6539
10		.7712	.8048	.6203		
11		.8215	.8886	.7377		
12		.7712	.8718	.7042		
13		.8048	.8718	.7209		
14		.788	.924	.6874		
15		.6371	.924	.7377		
16		.7042	.8718	.7042		
17		.7042		.7042		
18			.7545			
24	.373	.4239			.5256	.3688
Max	.6464	.8817	.924	.7377	.8478	.7209
Min	.3561	.4239	.7545	.6203	.5256	.3688
Avg	.4465	.6547	.8639	.7021	.6104	.5097

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046]

BU 7145

Substation No/ Name :- 144091 / 33/11 KV RADHANAGARI

Feeder No / Name : 204 / 11 KV PIRAL AG.

Feeder KV- 11 / OUTGOING

SEPARATED AG FEEDERS HAVING SPECIAL  
DESIGN TRANSFORMER

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.4922	1.3426	1.3056		
2		1.4413	1.3426	1.3056		
3		1.4413	1.3426	1.3056		
4		1.4582	1.326	1.3395		
5		1.4582	1.2929	1.4413		
6		1.6617	1.6244	1.4922		
7		2.3304	2.3537	2.0388		
8		2.782	2.4034	2.5857		
9		2.1879	2.2542	2.652		
10	2.6852			2.652	2.3205	2.2708
11	3.1161			1.4752	2.8509	2.9504
12				2.652	3.0001	3.0001
13	3.0167			2.3205	3.1493	2.9835
14	2.7681			2.5194	2.9338	2.9172
15	2.8344			2.5857	2.9338	2.8841
16	2.9007			2.7681	2.8509	2.7681
17	2.652			2.2211	2.6686	2.536
24		1.5091	3.7792	1.2209		
Max	3.1161	2.782	3.7792	2.7681	3.1493	3.0001
Min	2.652	1.4413	1.2929	1.2209	2.3205	2.2708
Avg	2.8533	1.7762	1.9062	1.9934	2.8385	2.7888

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 146004 / 110KV/33KV/11KV RHE

Feeder No / Name : 601 / R.M.MOHITE HYDRO GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.5588
Max	1.5588
Min	1.5588
Avg	1.5588

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR RURAL II DIV.[505]

RADHANAGARI[046] BU 7145

Substation No/ Name :- 148019 / 220/110/33 KV BIDRI

Feeder No / Name : 601 / DVSSK BIDRI CO-GN.

Feeder KV- 100 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	1.5588
Max	1.5588
Min	1.5588
Avg	1.5588

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 201 / 11KV I.T.Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0187	.0187	.0187	.0354	.0373	.0181	.0354
2	.0187	.0187	.0187	.0177	.0373	.0181	.0354
3	.0187	.0187	.0187	.0354	.0373	.0181	.0354
4	.0187	.0187	.0187	.0177	.0373	.0181	.0354
5	.0187	.0187	.0187	.0177	.0373	.0181	.0354
6	.0187	.0187	.0187	.0177	.0373	.0362	.0354
7	.0187	.0187	.0187	.0177	.0373	.0362	.0354
8	.0187	.0187	.0373	.0354	.0373	.0362	.0354
9	.0373	.0187	.0373	.0354	.0373	.0362	.0354
10	.0543	.0532	.0373	.0187	.0354	.0543	.0373
11	.0543	.0532	.0362	.0373	.0532	.0543	.1307
12	.0362	.0532	.0362	.0373	.0532	.0543	.0747
13	.0543	.0532	.0362	.0373	.056	.0543	.056
14	.0543	.0532	.0362	.0373	.0532	.0543	.056
15	.0543	.0532	.0362	.0373	.0532	.0724	.0554
16	.0747		.0362	.0373	.0532	.0543	.056
17	.0747	.056	.0354	.0373	.056	.0532	.0543
18	.0747	.056		.0373	.056	.0532	.0543
19	.056	.0373	.0354	.0373	.0373	.0532	.0543
20	.0373	.0373	.0354	.0373	.0373	.0532	.0362
21	.0373	.0373	.0354	.0373	.0362	.0532	.0362
22	.0187	.0373	.0354	.0373	.0362	.0354	.0362
23	.0187	.0373	.0354	.0373	.0362	.0354	.0181
24	.0187	.0187	.0187	.0354	.0373	.0362	.0354
Max	.0747	.056	.0373	.0373	.056	.0724	.1307
Min	.0187	.0187	.0187	.0177	.0354	.0181	.0181
Avg	.0377	.0350	.0300	.0320	.0427	.0419	.0462

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 202 / HOCKY STADIUM

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1494	.1307	.1307	.1433	.1307	.1478	.1433
2	.1494	.1307	.1307	.1254	.1307	.1294	.1433
3	.1494	.1307	.1307	.1254	.1307	.1294	.1433
4	.1494	.1307	.1307	.1254	.1307	.1294	.1254
5	.1494	.1307	.1307	.1254	.1307	.1294	.1254
6	.1307	.1307	.1307	.1254	.1307	.1478	.1254
7	.112	.0934	.112	.0895	.1307	.1109	.1254
8	.112	.112	.1307	.1075	.1307	.1294	.1075
9	.112	.1307	.112	.1254	.1307	.1294	.1254
10	.1294	.1254	.1307	.1307	.1254	.1294	.1307
11	.1109		.1109	.1307	.9134	.1109	.1307
12	.1109	.1075	.1109	.112	.1254	.0924	.1307
13	.1109	.1254	.1109	.1307	.1307	.0924	.1494
14	.0924	.1075	.1109	.112	.1433	.0739	.112
15	.0924	.1254	.1109	.112	.1075	.1294	.1307
16	.0934		.0924	.112	.1254	.1294	.112
17	.0934	.112	.1254	.112	.0747	.1254	.1109
18	.112	.112		.112	.0934	.1254	.0924
19	.1494	.1494	.1433	.1307	.1494	.1612	.1478
20	.168	.168	.1791	.168	.1867	.1791	.1663
21	.168	.168	.1791	.168	.1848	.1791	.1663
22	.1867	.168	.1791	.168	.1848	.1791	.1848
23	.168	.168	.1433	.168	.1663	.1612	.1663
24	.1494	.1494	.1494	.1433	.1494	.1478	.1612
Max	.1867	.168	.1791	.168	.9134	.1791	.1848
Min	.0924	.0934	.0924	.0895	.0747	.0739	.0924
Avg	.1312	.1321	.1311	.1293	.1682	.1333	.1357

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 204 / RENUKA FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7468	.7282	.7095	.7811	.7468	.9709	1.0098
2	.7095	.6722	.6722	.743	.6908	.8775	.9717
3	.7095	.6535	.6722	.724	.6535	.8775	.9335
4	.7095	.6535	.6722	.724	.6535	.8775	.9145
5	.6908	.6535	.6722	.7049	.6535	.8775	.8954
6	.6348	.6535	.6908	.724	.6535	.9335	.9145
7	.6348	.6161	.7095		.6722	.9522	.9145
8	.6908	.6722	.7282		.6535	.9149	.8764
9	.7842	.7282	.6908	.724	.6535	.9709	.9526
10	.7095	.724	.7282	.6722	.6668	.9896	.9709
11	.6722		.6908	.7282	.9717	.9522	1.0269
12	.7655	.0762	.7095	.6535	.9335	.9896	1.0829
13	.7095		.6722	.6535	.9709	.9896	1.0456
14	.7023		.6535	.5788	.9717	1.0829	1.0082
15	.7095		.6722	.6722	.9907	1.1203	1.1016
16	.7095		.8029	.6535	.9717	1.1389	1.0642
17	.7468	.7095	.7049	.6908	1.0082	.9145	1.0082
18	.7655	.7095		.6348	.9335	1.0669	1.0456
19	1.0269	.8962	.8954	.8775	1.1949	1.2955	1.3443
20	.9896	1.0269	.9717	.9522	1.2696	1.3146	1.3121
21	.9896	.9335	.9145	.9335	1.1763	1.2384	1.2696
22	.9709	.9335	.9145	.8775	1.1763	1.2003	1.2323
23	.9149	.8402	.8954	.8402	1.1576	1.1812	1.1763
24	.8215	.8215	.8029	.7621	.8029	1.0642	1.086
Max	1.0269	1.0269	.9717	.9522	1.2696	1.3146	1.3443
Min	.6348	.0762	.6535	.5788	.6535	.8775	.8764
Avg	.7714	.7212	.7498	.7412	.8845	1.0330	1.0482

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144033 / SHENDA PARK S/STN

Feeder No / Name : 205 / SUBHASH NAGAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8589	.8775	.8589	.8573	.8589	.8589	.9335
2	.7842		.8215	.8383	.8215	.8029	.8954
3	.7842	.8029	.8029	.8192	.8215	.7655	.8573
4	.7842	.8029	.8029	.7811	.8029	.7655	.8573
5	.7842	.8029	.8029	.7811	.8029	.7655	.8383
6	.7842	.8402	.8029	.8383	.8775	.8215	.9145
7	.7655	.7842	.7468	.724	.8775	.9149	.8383
8	.7468	.9149	.8962	.7811	.8775	.8402	.8002
9	.7842	.8962	.8775	.9145	.8962	.8962	.9145
10	.8402	.8383	.7468	.8589	.8002	.8402	.8402
11	.7468		.7282	.8402	.6097	.8029	.8029
12	.6908	.8954	.8029	.8215	.6668	.8402	.7842
13	.6908	.8573	.7655	.8029	.8402	.8215	.7842
14	.7842	.8192	.7655	.8029	.8192	.8131	.8215
15	.7655	.8764	.8029	.8589	.8383	.8589	.8589
16	.7842		.8215	.8589	.8383	.6722	.8589
17	.7655	.6722	.724	.6908	.7282	.7049	.7468
18	.8215	.7468		.8589	.8402	.8764	.8316
19	1.0829	1.0829	1.1622	1.1016	1.1016	1.1622	1.2323
20	1.1016	1.251		1.2696	1.2136	1.2574	1.2883
21	1.1203	1.0829	1.1622	1.1203	1.2323	1.1431	1.1389
22	1.1016	1.0829	1.086	1.0642	1.0642	1.1241	1.1576
23	1.1016	1.0456	1.0479	1.0456	1.0456	1.086	1.1016
24	.9335	1.0082	.9335	.9145	.9522	.9335	.9717
Max	1.1203	1.251	1.1622	1.2696	1.2323	1.2574	1.2883
Min	.6908	.6722	.724	.6908	.6097	.6722	.7468
Avg	.8503	.9038	.8619	.8852	.8845	.8903	.9195



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 201 / SAMBHAJI NAGAR CZ

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0751	.9808	1.0374	.9808	.9808	.9808	1.0562
2	1.0185	.9431	.9431	.8865	.9054	.9431	1.0185
3	1.0185	.9431	.9054	.8865	.8488	.9054	1.0185
4	1.0562	.9054	.9242	.9054	.8676	.9242	1.0751
5	1.094	.8865	.9619	.9431	.9054	.9619	1.1317
6	.9997	1.0374	1.0185	1.0185	.9997	1.094	1.0562
7	.9054	.9997	.9431	.9431	1.0374	1.0185	.9431
8	.8676	.8488	.8865	.8299	.8676	.8865	.8676
9	.9619	.9997	.8865	.9431	.811	.9054	.9242
10	.9431	1.0751	1.0185	.9709		.9242	.9997
11	.9619	.9808	.9997	.9619	.811	.9242	.9808
12	.9054	1.5546	.9054	1.0185	.6602	1.0751	.9808
13	.9431	1.5497	.8488	.8865	.9054	.8488	.8488
14	.9054	1.4712	.8676	.8676	.8676	.9997	.9431
15	.9431	1.6244	.9619	.9431	.8865	.9997	.9808
16	.9997	1.6598	.9431	.9431	.8676	1.0562	.9997
17	.9808	1.0374	.9808	.9808	.8676	.9997	1.0185
18	1.0185	1.0185	.8865	.9997		1.0562	1.094
19	1.358	1.3203	1.3392	1.3203	1.2449	1.4146	1.2637
20	1.358	1.4146	1.358	1.3203	1.3957	1.4335	1.5278
21	1.3392	1.3957	1.3392	1.3392	1.3769	1.3392	1.3957
22		1.3392	1.3014	1.2637	1.358	1.3769	1.3203
23	1.2449	1.2382	1.2071	1.1883	1.2637	1.3014	1.2826
24	1.1506	1.094	1.1506	1.0562	1.094	1.0562	1.1128
Max	1.358	1.6598	1.358	1.3392	1.3957	1.4335	1.5278
Min	.8676	.8488	.8488	.8299	.6602	.8488	.8488
Avg	1.0456	1.1799	1.0256	1.0165	.9919	1.0594	1.0767

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 202 / JAIL KOLHAPUR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3734	.3475	.3734	.3547	.3547	.3511	.3734
2	.3174	.2926	.3361	.3174	.3174	.3326	.3174
3	.3174	.2926	.2987	.3174	.2987	.2957	.3174
4	.3361	.3109	.3174	.3361	.3174	.2957	.3361
5	.3361	.3292	.3361	.3734	.3361	.3326	.3547
6	.3547	.3658	.3921	.3361	.3921	.4251	.3734
7	.3361	.3475	.3547	.3174	.3734	.4066	.3547
8	.3361	.3292	.3547	.3361	.3511	.3142	.3361
9	.4108	.3475	.3174	.3361	.3921	.4435	.4294
10	.3921	.3142	.3547	.3174		.4108	.3921
11	.3734	.2987	.3921	.2801	.3475	.3734	.3921
12	.2987	.2801	.3511	.2987	.2743	.3174	.3174
13	.2987	.3018	.2801	.2801	.3841	.3734	.3921
14	.3547	.2829	.3921	.2614	.4024	.3734	.4108
15	.3174	.2641	.3547	.2614	.3109	.3361	.3174
16	.3696	.2957	.3734	.2801	.3696	.3734	.3547
17	.3921	.2987	.3734	.2801	.3696	.3734	.3734
18	.3475	.2801	.3547	.2801		.4108	.3734
19	.5487	.4668	.5228	.3921	.5175	.5601	.5281
20	.5853	.5228	.5041	.5041	.5729	.5788	.5788
21	.4938	.4854	.5041	.4854	.499	.5228	.5281
22		.4854	.4854	.4668	.5175	.5041	.5041
23	.4572	.4668	.4481	.4481	.4572	.4668	.4668
24	.4108	.4024	.4294	.3921	.3921	.4066	.4108
Max	.5853	.5228	.5228	.5041	.5729	.5788	.5788
Min	.2987	.2641	.2801	.2614	.2743	.2957	.3174
Avg	.3808	.3504	.3834	.3439	.3885	.3991	.3972

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 204 / KALAMBA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2012	1.134	1.1203	1.0534	1.1203	1.0974	1.2012
2	1.1273	1.0974	1.0534	.9979	1.0269	1.0242	1.1273
3	1.1273	1.0242	1.0164	.9979	.9896	1.0059	1.1157
4	1.1827	.9877	1.0719	1.0349	1.0269	1.0059	1.2012
5	1.2382	.9877	1.1088	1.0534	1.0829	1.0242	1.2752
6	1.2936	1.0791	1.2936	1.0903	1.3443	1.2254	1.3306
7	1.3306	1.1706	1.3256	1.0903	1.3817	1.2437	1.3491
8	1.2803	1.1523	1.2382	1.423	1.251	1.134	1.2012
9	1.2567	1.1706	1.1576	1.1523	1.1763	1.0425	1.1273
10	1.1088	1.0679	1.0974	1.0534		1.0425	1.1203
11	1.1016	.985	1.0242	1.0642	.7682	.9877	1.0719
12	1.0719	.9671	.9877	1.0642	.9328	1.0425	1.1389
13	1.0829	.9412	.9877	.9335	.9511	1.0608	1.0534
14	1.0642	.9694	.9694	.9795	.8779	1.0608	1.0534
15	1.0456	1.0534	1.0534	1.0642	.9145	1.0349	1.1203
16	1.0903	1.0719	.9877	.9709	1.0791	1.0608	1.1389
17	1.0349	1.0456	1.0059	1.0082	1.0242	1.0903	1.1273
18	1.134	1.1088		1.1088		1.1157	1.2323
19	1.5181	1.4118	1.5181	1.4377	1.3491	1.5729	1.5524
20	1.5912	1.7002	1.6078	1.6244	1.5912	1.701	1.7551
21	1.4998	1.5708	1.5339	1.531	1.5364	1.6461	1.7177
22		1.5154	1.4784	1.4937	1.4998	1.5912	1.643
23	1.2986	1.3443	1.386	1.4003	1.3352	1.4815	1.4937
24	1.2437	1.2071	1.1763	1.1643	1.2323	1.1706	1.2567
Max	1.5912	1.7002	1.6078	1.6244	1.5912	1.701	1.7551
Min	1.0349	.9412	.9694	.9335	.7682	.9877	1.0534
Avg	1.2141	1.1568	1.1826	1.1580	1.1587	1.1859	1.2668

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 205 / JARAG NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0608	1.0059	.9955	1.0059	1.0136	1.0059	1.1157
2	.9877	.9511	.905	.9328	.9231	.9511	1.0425
3	.9877	.9145	.8326	.9328	.905	.9145	1.0425
4	1.0425	.8779	.8688	.9877	.9231	.9145	1.0791
5	1.0974	.8779	.905	1.0425	.9412	.9511	1.0974
6	1.0242	.9511	.9955	.9694	1.0317	1.1088	1.0242
7	.9145	.9145	.9412	.8413	.9593	.9795	.9511
8	.9145	.9511	.8869	.8779	.905	.961	.9328
9	.8779	.8962	.8507	.823	.8688	.8779	.8596
10	.8507	.8775	.7682	.7964		.823	.7964
11	.8688	.8238	.8316	.8326	.7499	.7316	.8145
12	.905	.8417	.7865	.8507	.7865	.7865	.8326
13	.8326	.7964	.8048	.8326	.8048	.8413	.8507
14	.8688	.8413	.823	.8326	.7947	.8413	.905
15	.8688	.9055	.823	.7964	.695	.8962	.8869
16	.8507	.8688	.7865	.8326	.8779	.8413	.9335
17	.8869	.8145	.823	.8507	.8413	.8596	.8507
18	.9694	.8954	.8596	.8869		.9145	.9231
19	1.3717	1.3394	1.3717	1.3575	1.1888	1.4815	1.3756
20	1.4083	1.5023	1.4266	1.448	1.4632	1.5364	1.5746
21	1.39	1.4299	1.39	1.4118	1.4784	1.5181	1.4842
22		1.4118	1.4083	1.3032	1.4784	1.4632	1.3937
23	1.3169	1.2308	1.2071	1.2127	1.3535	1.3535	1.3213
24	1.1157		1.1041	.9511	1.1041	1.0974	1.1706
Max	1.4083	1.5023	1.4266	1.448	1.4784	1.5364	1.5746
Min	.8326	.7964	.7682	.7964	.695	.7316	.7964
Avg	1.0179	.9965	.9748	.9837	1.0040	1.0271	1.0524

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 206 / 11KV I.T.I.FEEDER  
Feeder KV- 11 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0185	.0189	.0183	.0185	.0183	.0189	.0185
2	.0185	.0189	.0183	.0185	.0183	.0189	.0185
3	.0185	.0189	.0183	.0185	.0183	.0189	.0185
4	.0185	.0189	.0183	.0185	.0183	.0189	.0185
5	.0185	.0189	.0183	.0185	.0183	.0189	.0185
6	.0185	.0189	.0183	.0185	.0183	.0189	.0185
7	.0185	.0189	.0183	.0185	.0183	.0189	.0185
8	.0185	.0189	.0183	.0185	.0183	.0189	.0185
9	.0185	.0189	.0183	.0185	.0183	.0189	.0185
10	.0183	.0152	.0185	.0183		.0185	.0185
11	.0185	.0171	.0185	.0183	.0189	.0185	.0183
12	.0185	.0171	.0185	.0187	.0189	.037	.0183
13	.0185	.0171	.0185	.0183	.0377	.037	.0724
14	.0185	.0171	.0185	.0183	.0566	.0185	.0366
15	.0185	.0171	.0185	.0183	.0377	.037	.0373
16	.0185	.0183	.0185	.0183	.0189	.0185	.0183
17	.0183	.0185	.0185	.0183	.0189	.0185	.0183
18	.9997	.0183	.0183	.0183		.0185	.0183
19	.0189	.0183	.0185	.0183	.0189	.0185	.0181
20	.0189	.0183	.0185	.0183	.0189	.0185	.0181
21	.0189	.0185	.0185	.0185	.0189	.0185	.0183
22		.0183	.0185	.0183	.0189	.0185	.0183
23	.0189	.0183	.0185	.0183	.0183	.0185	.0183
24	.0185	.0189	.0183	.0185	.0183	.0189	.0185
Max	.9997	.0189	.0185	.0187	.0566	.037	.0724
Min	.0183	.0152	.0183	.0183	.0183	.0185	.0181
Avg	.0612	.0182	.0184	.0184	.0220	.0210	.0222

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U. CENTRAL[017] BU 4017

Substation No/ Name :- 144104 / RAMANAND NAGAR

Feeder No / Name : 412 / 33kv Shenda Park out going NON SHEDDABLE EXPRESS HV FEEDERS  
 Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.6037	3.5482	3.4374	3.3265	3.4374	3.4374	4.0472
2	3.3819	3.3265	3.3265	3.1047	3.3265	3.3265	3.8809
3	3.3819	3.3265	3.2156	2.8829	3.1047	3.2156	3.8809
4	3.5482	3.2156	3.271	2.8829	3.1602	3.2156	4.1027
5	3.7146	3.1602	3.3819	3.1602	3.271	3.5482	4.1581
6	3.4928	3.3819	3.5482	3.3265	3.4928	3.9363	3.9363
7	3.4374	3.271	3.4928	2.9938	3.6037	3.8809	3.77
8	3.4928	3.4928	3.4374	3.2156	3.4928	3.6591	3.6591
9	3.4374	3.4374	3.271	3.3265	3.3819	3.6037	3.7146
10	3.271	3.3819	3.1602	3.1602		3.5482	3.6591
11	3.1602	3.3265	2.9938	3.1602	2.384	3.4928	3.6037
12	3.1602	2.7166	3.0493	3.1602	2.4949	3.4374	3.6037
13	3.4374	2.7166	3.0493	2.9938	2.6057	3.4374	3.4928
14	3.271	2.5503	2.9938	2.8829	3.9363	3.4928	3.6037
15	3.271	2.7166	3.0493	3.1602	3.8255	3.6591	3.7146
16	3.3265	2.6612	3.1602	3.1047	3.7146	3.3265	3.6037
17	3.271	3.1047	3.1602	2.9384	3.6037	3.6037	3.7146
18	3.3819	3.1602	3.1602	3.0493		3.77	3.8255
19	4.7125	4.3799	4.5462	4.2135	4.4907	5.1006	4.9897
20	4.7125	4.7125	4.7125	4.6016	5.0452	5.2669	5.4887
21	4.6571	4.4907	4.4907	4.3799	4.8234	5.0452	5.1006
22		4.4907	4.3244	4.3244	4.768	4.9343	5.1006
23	4.269	4.1581	4.1027	4.1027	4.5462	4.768	4.8788
24	3.8255	3.77	3.6591	3.6591	3.77	3.6591	4.2135
Max	4.7125	4.7125	4.7125	4.6016	5.0452	5.2669	5.4887
Min	3.1602	2.5503	2.9938	2.8829	2.384	3.2156	3.4928
Avg	3.6182	3.4374	3.4997	3.3796	3.6491	3.8486	4.0726

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 208 / RAJARAMPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6287	.6979	.6602	.679	.6602	.6979
2	.679	.5906	.6036	.6036	.679	.6602	.6036
3	.6602	.6097	.5658	.5658	.6036	.5847	.5847
4	.6602	.6097	.5847	.5658	.5847	.5847	.5847
5	.6979	.6287	.5658	.5847	.5847	.679	.5847
6	.6979	.6287	.6036	.6036	.6602	.7356	.6224
7	.7356	.6859	.7356	.6979	.7167	.7733	.7167
8	.7545	.724	.7545	.6979	.7545	.7167	.7545
9	.7545	.9907	.7356	.7167	.7545	.7922	.7733
10	.8676	.8488	.9335	.8002	.8865	.9431	.9526
11	1.4523	1.4523	1.2955	1.2193	.8299	1.3203	1.467
12	1.5466	1.4523		1.3336	1.3392	1.3769	1.4861
13	1.4335	1.4712	1.3336	1.2384	1.3957	1.3769	
14	1.4146	1.3957	1.2765	1.1431	1.4335	1.4335	1.3336
15	1.4523	1.3392	1.2955	1.1431	1.3769	1.358	1.2765
16	1.3957	1.4335	1.3336	1.1317	1.4523	1.4146	1.3336
17	1.3527	1.4146	1.4523	1.226	1.3769	1.4335	1.4335
18	1.4289	1.358	1.3769	1.2449	1.4335	1.6032	1.4901
19	1.7909	1.773	1.6975	1.5844	1.7918	1.8296	1.8861
20	1.7147	1.7164	1.5844	1.6409	1.7541	1.8107	1.7918
21	1.3336	1.4335	1.4523	1.3203	1.3957	1.1506	1.4335
22	.9526	1.0562	1.0562	.9997	1.0185	.9997	1.0185
23	.7811	.8865	.8676	.8488	.8676	.8676	.9242
24	.7733	.6668	.7545	.6979	.7545	.7356	.7545
Max	1.7909	1.773	1.6975	1.6409	1.7918	1.8296	1.8861
Min	.6602	.5906	.5658	.5658	.5847	.5847	.5847
Avg	1.0853	1.0748	1.0242	.9695	1.0468	1.0767	1.0654

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 209 / 11 KV VARDHAMAN

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3772	.3429	.3206	.3206	.3395	.3395	.3584
2	.3395	.3048	.3206	.3206	.3018	.3018	.3018
3	.3395	.3048	.3018	.3018	.3018	.3018	.2829
4	.3395	.3048	.3018	.3018	.3018	.3018	.2829
5	.3395	.3239	.3018	.3018	.3018	.3395	.2829
6	.3772	.3239	.3206	.3018	.3395		.3584
7	.3772	.381	.3961	.3395	.3772	.3772	.3772
8	.3772	.362	.3772	.3584	.3772	.415	.3961
9	.3772	.381	.3961	7.5446	.3584	.415	.4904
10		.3961	.4191	.381	.3961	.4338	.4191
11	.3395	.5281	.4954	.4572	1.7164	.5658	.5335
12	.5281	.5281	.5525	.4572	1.6787	.547	.4572
13	.547	.547	.5335	.4954	.7922	.5847	.0191
14	.5093	.5658	.4572	.4191	.4904	.4904	.0191
15	.5093	.4527	.4191	.381	.4715	.5281	.6859
16	.4904	.4904	.4572	.415	.5093	.5093	.5906
17	.5335	.5281	.4904	.415	.5281	.5281	.6224
18	.5525	.5281	.5093	.4338	.5281	.547	.6036
19	.6097	.6413	.6036	.5658	.679	.6036	.6979
20	.6478	.6413	.6224	.5658	.6036	.6979	.6602
21	.5335	.547	.5281	.4904	.5281	.5281	.547
22	.4191	.4338	.4527	.4338	.4527	.4527	.4527
23	.381	.3961	.3772	.3961	.415	.415	.415
24	.3772	.3429	.3395	.3395		.3772	.3772
Max	.6478	.6413	.6224	7.5446	1.7164	.6979	.6979
Min	.3395	.3048	.3018	.3018	.3018	.3018	.0191
Avg	.4444	.4415	.4289	.6974	.5560	.4609	.4263



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 210 / 11 KV SHAHUPURI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7167	.6287	.7545	.6036	.6413	.6413	.6602
2	.6602	.5906	.6224	.5847	.6036	.6036	.5847
3	.6602	.6097	.6036	.547	.6036	.6036	.5658
4	.6224	.6097	.6036	.547	.6036	.6036	.5658
5	.6224	.6287	.6036	.5658	.6036	.6036	.5847
6	.6413	.6668	.6224	.6036	.6602	.6602	.6224
7	.6413	.6478	.6602	.6036	.6602	.6602	.6413
8	.6979	.6859	.6979	.6413	.6979	.6979	.6979
9	.7356	.7621	.7922	.6602	.7922	.8299	.811
10	1.0562	.9808		.7811	.9431	1.2449	1.2193
11	1.3769	1.4335	1.6194	.9717	1.5466	1.6221	1.6004
12	1.4901	1.5655	1.5813	1.1241	1.6032	1.6787	1.6956
13	1.5844	1.6032	1.7337	1.2003	1.6032	1.7353	1.7528
14	1.5844	1.4712	1.6575	1.1812	1.6409	1.7353	1.6194
15	1.5466	1.6221	1.5623	1.1812	1.5844	1.7541	1.6766
16	1.5466	1.6787	1.6575	1.2071	1.7353	1.773	1.8671
17	1.6956	1.5466	1.6975	1.1506	1.7353	1.6409	1.7541
18	1.467	1.4335	1.5655	1.1694	1.6032	1.6598	1.6221
19	1.5432	1.6032	1.6787	1.3392	1.5844	1.6221	1.5844
20	1.4098	1.3769	1.5466	1.3203	1.3957	1.4901	1.3014
21	1.1431	1.1883	1.226	1.0562	1.1883	1.0751	1.0751
22	.9907	.9054	1.0562	.8865	.9242	.9054	.9054
23	.8383	.8676	.8676	.8865	.8676	.8488	.8865
24	.7545	.724	.7922	.7545	.7167	.7356	.7167
Max	1.6956	1.6787	1.7337	1.3392	1.7353	1.773	1.8671
Min	.6224	.5906	.6036	.547	.6036	.6036	.5658
Avg	1.0844	1.0763	1.1392	.8986	1.1058	1.1427	1.1254

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 211 / Takala

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9242	.8192	.9054	.7922	.9054	.9054	.9431
2	.8865	.8192	.8299	.7167	.8488	.8488	.8676
3	.8865	.8002	.7545	.679	.7733	.7733	.7167
4	.8488	.8002	.7733	.679	.7733	.7733	.7167
5	.8865	.8192	.7545	.7167	.7733	.8676	.7167
6	.9242	.8383	.8676	.7733	.8676	.9242	.8865
7	.9431	.8954	.8676	.811	.9431	.9619	.9054
8	.9054	.8954	.9242	.811	.8676	.9619	.9431
9	.9054	1.105	.8865	.811	.9054	.9054	.9242
10		.8299	.8383	.8002	.8676	.8488	.8002
11	.9619	.8865	.8573	.8954	.8299	.8299	.8192
12		.8865	.8764	.8573	.7733	.8865	.8764
13		.8676	.8192	.8002	.7922	.8676	.9335
14	1.2449	.9242	.8192	.8192	.7356	.8676	.8764
15	1.094	.8488	.8573	.8002	.7922	.8865	.9526
16	1.0562	.8488	.8954	.7922	.8676	.8676	.8954
17	.9717	.8676	.8676	.8488	.9808	.8488	.8865
18	.8573	.8676	.8299	.7922	.9808	.9431	.9242
19	1.0479	1.094	.9808	1.0185	1.1128	1.0562	1.094
20	1.2003	1.1317	1.1506	1.1317	1.1883	1.2071	1.1506
21	1.1431	1.0751	1.094	1.0374	1.1883	1.1506	1.1694
22	1.1431	1.1317	1.094	1.0562	1.1506	1.1694	1.1694
23	1.0288	1.094	1.0185	1.094	1.1317	1.1317	1.0751
24	1.0562	.8573	.9808	.8676	.9808	1.0185	.9997
Max	1.2449	1.1317	1.1506	1.1317	1.1883	1.2071	1.1694
Min	.8488	.8002	.7545	.679	.7356	.7733	.7167
Avg	.996	.9168	.8976	.8500	.9179	.9376	.9268

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 212 / 11 KV SHAHUMILL KOP.MAULI

SHEDDABLE URBAN

FEED Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6602	.5716	.5658	.6036	.6036	.6036	.6413
2	.5847	.5716	.547	.5658	.6036	.6036	.6036
3	.5847	.5525	.5281	.547	.5658	.5658	.5847
4	.5847	.5525	.5281	.547	.5658	.5658	.5847
5	.6036	.5525	.5281	.5658	.5658	.6224	.5847
6	.6036	.5906	.6224	.6224	.6413	.6602	.6602
7	.6413	.6478	.6602	.5847	.6602	.6979	.679
8	.5847	.6478	.6979	.5847	.6224	.6224	.5847
9	.5658	.6097	.5658	.5847	.5847	.6036	.5847
10	.5658	.6602	.6287	.6097	.8299	.5658	.6287
11	.6413	.6979	.6478	.6287	.5658	.6413	.6097
12	.7167	.7356	.7049		.5847	.6413	.6287
13	.7167	.7922	.7049	.7049	.6036	.7167	.7621
14	.6979	.6979	.6859	.724	.6036	.7356	.7049
15	.679	.7356	.6668	.743	.5847	.7356	.7621
16	.679	.7356	.6478	.679	.5847	.7167	.743
17	.7621	.679	.7167	.6602	.7733	.679	.6979
18	.7811	.7356	.6979	.7167	.7545	.679	.7545
19	1.0098	.9619	.9431	.9054	.9808	1.0185	.9808
20	1.0669	1.0751	1.0374	.9997	1.0185	1.1128	1.0374
21	.9907	.9997	.9431	.9431	.9619	1.0374	.9997
22	.8764	.8676	.8488	.8299	.8676	.9054	.8865
23	.743	.7922	.7545	.7545	.7545	.8299	.7922
24	.6979	.6287	.679	.6413	.679	.6602	.6979
Max	1.0669	1.0751	1.0374	.9997	1.0185	1.1128	1.0374
Min	.5658	.5525	.5281	.547	.5658	.5658	.5847
Avg	.7099	.7121	.6896	.6846	.6900	.7175	.7164

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 213 / Panjarpol

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0754	.0762	.0943	.0943	.0754	.0754	.0943
2	.0566	.0762	.0754	.0943	.0566	.0566	.0754
3	.0566	.0762	.0754	.0943	.0566	.0566	.0754
4	.0566	.0762	.0754	.0943	.0566	.0566	.0943
5	.0566	.0762	.0754	.0754	.0566	.0566	.0943
6	.0754	.0762	.0943	.0754	.0566	.0754	.0943
7	.0754	.0762	.1132	.1132	.0566	.0754	.0943
8	.1132	.0953	.1132	.132	.0566	.0754	.0943
9	.0943	.0953	.1132	.1132	.0754	.1132	.1132
10	.1886	.1509	.1715	.1524	.132	.1509	.1905
11	.2452	.2452	.2286	.2477	.0189	.2641	.2477
12	.3018	.2641	.2477		.0189	.2263	.3048
13	.2452	.2452	.2096	.2286	.0189	.1886	.2477
14	.1698	.1698	.1334	.1524	.0943	.1509	.1524
15	.1886	.2452	.2096	.2286	.0943	.2263	.2096
16	.2263	.2641	.2286	.1886	.0754	.2829	.2858
17	.2667	.2263	.2263	.2075	.0943	.2452	.2263
18	.2286	.2075	.2075	.1698	.0754	.1886	.2075
19	.2477	.1886	.1886	.1509	.0943	.2263	.2452
20	.1715	.132	.1509	.1132	.0943	.1698	.1698
21	.0953	.132	.1132	.0943	.0943	.1132	.1132
22	.1143	.132	.1132	.0754	.1132	.0943	.1132
23	.0953	.0943	.1132	.0754	.0943	.0943	.1132
24	.0943	.0762	.0943	.0754	.0754	.0943	.0943
Max	.3018	.2641	.2477	.2477	.132	.2829	.3048
Min	.0566	.0762	.0754	.0754	.0189	.0566	.0754
Avg	.1475	.1457	.1444	.1325	.0723	.1399	.1563

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144029 / SHAHU MILL

Feeder No / Name : 411 / 33 KV Incomer No. I MIDC NON SHEDDABLE EXPRESS HV FEEDERS  
 FEEDE Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO  
 STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.6399	4.1152	4.4702	4.1307	4.357	4.0741	4.2438
2	4.357	3.9438	4.0741	3.8477	4.1307	3.9043	3.8477
3	4.3004	3.9438	3.7912	3.678	3.9043	3.678	3.5082
4	4.1872	3.9438	3.8477	3.678	3.9043	3.678	3.5082
5	4.3004	4.0581	3.7912	3.7912	3.9043	3.9609	3.5082
6	4.4136	4.2295	4.1872	3.9609	4.3004	4.1872	4.0175
7	4.5268	4.401	4.5268	4.1307	4.5268	4.4136	4.2438
8	4.5833	4.5725	4.6965	4.3004	4.5268	4.4136	4.3004
9	4.6399	5.0869	4.6965	4.357	4.5833	4.5833	4.5268
10	5.2624	5.0926	5.487	4.7439	5.5453	5.1492	5.2584
11	6.4506	6.677	6.5158	5.7728	5.4887	6.394	6.4586
12	6.0545	6.9599	6.8587	6.1157		6.5638	6.6873
13	6.0545	7.0731	6.8587	6.0014		6.677	6.4586
14	7.1862	6.677	6.5158	5.7728	6.394	6.677	5.9442
15	6.9033	6.7335	6.5158	5.7728	6.2243	6.6204	6.7444
16	6.7335	6.8467	6.7444	5.715	6.394	6.7335	6.8587
17	7.0873	6.7901	7.0165	5.8282	6.7335	6.5072	6.7901
18	7.0302	6.5638	6.7901	5.8848	6.5638	6.8467	6.8467
19	8.1733	8.035	8.035	7.2428	7.7521	7.9218	8.0916
20	8.1162	4.1307	7.9784	7.5257	7.5823	8.1482	7.6955
21	6.9159	7.0165	7.0165	6.5638	6.7335	6.677	6.677
22	5.9442	6.1111	6.0545	5.715	5.715	5.715	5.715
23	5.2012	5.6019	5.2624	5.3755	5.2058	5.2624	5.2624
24	4.9794	4.4582	4.8663	4.5833	4.4136	4.5268	4.5268
Max	8.1733	8.035	8.035	7.5257	7.7521	8.1482	8.0916
Min	4.1872	3.9438	3.7912	3.678	3.9043	3.678	3.5082
Avg	5.7517	5.5442	5.6916	5.1870	5.4038	5.5547	5.4883

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 201 / 11 KV Udymnagar

KOP.INDUSTRIAL Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6859	.6097	.6859	.6859	.6478	.6097	.6859
2	.6859	.6097	.6859	.6859	.6478	.6097	.6859
3	.6478	.6097	.6859	.6859	.6097	.6097	.6478
4	.6859	.6478	.724	.6859	.6097	.6097	.6478
5	.6859	.6859	.724	.724	.6097	.6097	.6859
6	.724	.724	.6859	.6859	.6097	.6097	.6859
7	.6859	.6859	.6859	.6859	.6097	.6478	.724
8	.6859	.8002	.6097	.724	.6097	.724	.724
9	.5716	.6097	.6478	.5716	.6097	.6097	.6859
10	.8002	.8002	.9145	.6859	.6097	.7621	.8383
11	.9145	.8764	.9526	.724	.5716	.8383	.9907
12	.8002	.6859	.7621	.6859	.6097	.724	.8764
13	.6859	.6859	.724	.6859	.5716	.7621	.7621
14	.7621	.8383	.7621	.724	.6097	.7621	.8764
15	.8383	.9526	.7621	.724	.6097	.9145	.9145
16	.8383	.8764	.8383	.6859	.1905	.9526	.9526
17	.8383	.8002	.724	.6097	.6097	.8002	.8002
18	.6859	.6859	.6478	.5335	.6097	.6859	.6478
19	.6097	.6097	.6097	.5716	.6097	.5716	.5716
20	.6478	.6859	.6478	.4954	.6097	.6097	.5716
21	.724	.6097	.6478	.5716	.6478	.6478	.5716
22	.6478	.6859	.6859	.5716	.6478	.6859	.5716
23	.724	.6859	.6859	.4954	.6097	.724	.6478
24	.6859	.6478	.724	.6859	.6097	.6097	.6478
Max	.9145	.9526	.9526	.724	.6478	.9526	.9907
Min	.5716	.6097	.6097	.4954	.1905	.5716	.5716
Avg	.7192	.7129	.7177	.6494	.5954	.6954	.7256

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 202 / 11 KV SAMARAT NAGAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.695	.724	.724	.7621	.7621	.7621
2	.724	.6584	.6859	.6859	.6859	.6859	.724
3	.6478	.6584	.6478	.6478	.6478	.6478	.6859
4	.6478	.6584	.6097	.6097	.6097	.6478	.6478
5	.6478	.6584	.6097	.5716	.6097	.6478	.6478
6	.6859	.6584	.6859	.6097	.6478	.724	.8002
7	.6859	.6283	.6478	.6478	.6478	.7621	.8002
8	.6097	.7023	.7621	.6478	.6097	.724	.724
9	.6859	.6283	.724	.6478	.6478	.724	.6859
10	.6859	.724	.6859	.5544	.6097	.6478	.6348
11	.6097	.6478	.6478	.5975	.5335	.6859	.5975
12	.6097	.6478	.6097	.5975	.5335	.6478	.6348
13	.6097	.5716	.6478	.5975	.5716	.724	.6722
14	.6097	.6478	.6478	.5601	.5716	.6859	.6722
15	.6478	.6478	.6478	.5975	.381	.6859	.7023
16	.6478	.6478	.6859	.6097	.4191	.6097	.6653
17	.5914	.6478	.6097	.5716	.381	.6478	.6478
18	.6283	.6859	.6478	.5716	.6478	.4191	.724
19	.7762	.8383	.8383	.7621	.9145	.9145	.8764
20	.8501	.8383	.8383	.8383	.9145	1.0185	.9526
21	.8131	.8383	.8002	.8383	.9145	.9526	.9526
22	.8501	.8764	.8383	.8383	.9145	.9907	.9145
23	.8871	.8764	.8002	.8764	.9145	.9907	.8764
24	.8383	.7316	.7621	.7621	.8383	.8383	.8002
Max	.8871	.8764	.8383	.8764	.9145	1.0185	.9526
Min	.5914	.5716	.6097	.5544	.381	.4191	.5975
Avg	.6980	.7006	.7002	.6652	.6637	.7410	.7417

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 203 / 11 KV HUTATMA PARK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8764	.8764	.9145	.9145	.9145	.8764	.8764
2	.8764	.8764	.9145	.8764	.9145	.8764	.8764
3	.9145	.9145	.8764	.8764	.9145	.8764	.8383
4	.9145	.9145	.9145	.9145	.9145	.8764	.8383
5	.9145	.9145	.9145	.9145	.9145	.8764	.8764
6	.9145	.9145	.8764	.9526	.9526	.8764	.8383
7	.8764	.8383	.9526	.9145	.8764	.8383	.8383
8	.8764	.8383	.8764		.8764	.9526	.9526
9	.8764	.8383	.9526	.9145	.8764	.8383	.8764
10	1.0669	1.1431	1.105	1.0288	.8764	1.0669	1.1431
11	1.2955	1.1812	1.2955	1.1431	.8383	1.2955	1.3336
12	1.3336	1.2955	1.448	1.1431	.8383	1.2955	1.3717
13	1.1431	1.2955	1.2955	1.0669	.8764	1.2955	1.2955
14	1.3336	1.2955	1.2193	1.105	.8383	1.2955	1.1812
15	1.3717	1.4098	1.2955	1.1431	.8383	1.3717	1.448
16	1.3717	1.4861	1.3336	1.1812	.8383	1.3717	1.3717
17	1.2955	1.2955	1.2955	1.1812	.9145	1.4098	1.3717
18	1.2574	1.1431	1.2955	1.0669	.8764	1.2193	1.2193
19	1.1431	1.105	1.105	.9907	.8383	1.105	1.0669
20	.9526	.8764	.9526	.9145	.8764	.8764	.9145
21	.8383	.8764	.8764	.8383	.8383	.8383	.8383
22	.8764	.8764	.9145	.8764	.8383	.8383	.8764
23	.9145	.8764	.9145	.8764	.8764	.8764	.8764
24	.9526	.9526	.9145	.9145	.8764	.8764	.8764
Max	1.3717	1.4861	1.448	1.1812	.9526	1.4098	1.448
Min	.8383	.8383	.8764	.8383	.8383	.8383	.8383
Avg	1.0494	1.0431	1.0606	.9890	.8764	1.0383	1.0415



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 205 / RADHA KRISHNA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.105	1.1706	1.0669	1.0669	1.0669	1.0669	1.0288
2	1.0288	1.0974	.9907	.9907	.9907	.9526	.9907
3	.9907	1.0242	.9145	.9145	.9145	.9145	.9526
4	.9526	.9511	.9145	.8764	.8764	.9145	.9145
5	.9526	.8779	.9145	.8383	.8764	.9145	.9526
6	.9907	.8779	.9526	.8764	.9145	.9526	.9907
7	.9907	.924	.9526	.9145	.8764	1.0288	.9907
8	1.0288	1.0719	.9526	.9145	.9145	1.0288	1.0669
9	1.1812	1.2936	1.1431	1.0669	1.0669	1.2955	1.448
10	1.6004	1.6766	1.4861	1.2197	1.448	1.6385	1.5684
11	2.1338	1.9814	1.9052	1.419	1.9052	1.7528	2.0538
12	2.2862	2.21	2.1338	1.7177	1.9814	2.1338	2.2405
13	2.2481	2.1338	2.0576	1.5684	2.1338	2.4387	2.3152
14	2.2862	2.1719	2.0957	1.5684	2.0576	2.3624	2.2405
15	2.2862	2.1719	2.0576	1.5684	1.8671	2.2862	2.2916
16	2.2481	2.21	2.0957	1.6004	2.3243	2.4387	2.2916
17	2.2546	2.2862	2.2481	1.829	2.1338	2.3152	2.4006
18	2.2177	2.3624	2.21	1.6766	1.9814	2.3899	2.5149
19	2.3285	2.6673	2.2862	1.9052	2.2862	2.4646	2.553
20	2.2177	2.2862	2.0576	1.829	2.2481	2.2862	2.2481
21	1.7372	1.7909	1.7147	1.5623	1.7147	1.7528	1.7909
22	1.5893		1.5242	1.448	1.5242	1.6004	1.6766
23	1.4415	1.3717	1.3336	1.2193	1.3717	1.448	1.448
24	1.2955	1.2567	1.1812	1.1812	1.1431	1.2193	1.2574
Max	2.3285	2.6673	2.2862	1.9052	2.3243	2.4646	2.553
Min	.9526	.8779	.9145	.8383	.8764	.9145	.9145
Avg	1.6413	1.6463	1.5496	1.3238	1.5257	1.6498	1.6761

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144100 / Y. P. POWAR NAGAR

Feeder No / Name : 411 / 33 KV Incomer no I

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	3.9438	3.9438	3.8866	3.8866	3.8295	3.8295	3.8295
2	3.7723	3.7723	3.7723	3.7151	3.658	3.6008	3.7151
3	3.658	3.7723	3.5437	3.5437	3.4865	3.4865	3.5437
4	3.658	3.7151	3.6008	3.4865	3.4294	3.4865	3.4865
5	3.7151	3.658	3.6008	3.4865	3.4294	3.4865	3.6008
6	3.8295	3.658	3.658	3.6008	3.5437	3.6008	3.7723
7	3.7723	3.6008	3.7723	3.658	3.5437	3.8295	3.8866
8	3.7151	3.9438	3.658	3.7151	3.4294	3.9438	4.0009
9	3.7723	3.8866	3.8866	3.7151	3.658	4.0009	4.2295
10	4.6296	4.8011	4.6868	4.0009	4.0009	4.6296	4.7439
11	5.487	5.2584	5.2584	4.3439	4.3439	5.0869	5.487
12	5.5441	5.3727	5.4298	4.6296	4.2867	5.3155	5.7156
13	5.4298	5.2012	5.2012	4.3439	4.5725	5.7156	5.6013
14	5.5441	5.487	5.2012	4.401	4.4582	5.6584	5.5441
15	5.7156	5.6584	5.3155	4.5153	4.2867	5.8299	5.9442
16	5.6584	5.7156	5.487	4.5153	4.1152	5.8871	5.9442
17	5.5441	5.487	5.3727	4.6296	4.6296	5.7156	5.7156
18	5.3727	5.4298	5.3155	4.2867	4.6868	5.2584	5.6013
19	5.5441	5.8871	5.5441	4.8583	5.3155	5.715	5.7156
20	5.4298	5.3155	5.0869	4.7439	5.3155	5.487	5.3155
21	4.8011	4.7439	4.6868	4.401	4.8011	4.8583	4.8583
22	4.6868	4.5725	4.5725	4.3439	4.5725	4.6868	4.6868
23	4.6296	4.401	4.2867	3.658	4.401	4.6868	4.4582
24	4.3439	4.2295	4.1152	4.0581	4.0009	4.0581	4.1152
Max	5.7156	5.8871	5.5441	4.8583	5.3155	5.8871	5.9442
Min	3.658	3.6008	3.5437	3.4865	3.4294	3.4865	3.4865
Avg	4.6749	4.6463	4.5391	4.1057	4.1581	4.6606	4.7297

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 201 / 11 KV AMBAI DEFENCE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3584	.3613	.3403	.3584	.3613	.3584	.3544
2	.3395	.3613	.3189	.3206	.3423	.3395	.3189
3	.3206	.3423	.3189	.2829	.3423	.3206	.3012
4	.3018	.3232	.3012	.2829	.3232	.3206	.298
5	.3018	.3232	.3189	.3018	.2852	.3395	.3012
6	.3584	.3042	.3403	.3395	.2852	.3584	.3224
7	.3395	.3232	.3258	.3018	.3042	.3206	.2896
8	.3206	.3423	.3258	.3018	.3042	.3584	.3077
9	.2829	.2852	.3077	.2829	.3042	.3018	.2715
10	.2829	.2662	.2534	.2614	.2852	.2829	.2715
11	.2092	.2534	.2614	.2852		.2715	.2427
12	.2472	.2507	.1867	.2662		.2534	.2427
13	.2472	.2534	.2801	.2662		.2534	.2614
14	.2662	.2715	.2614	.2662	.2641	.2534	.2614
15	.2852	.2534	.2614	.2472	.2829	.2534	.2614
16	.2662	.2507	.2614	.2662	.2641	.2534	.2614
17	.2852	.2534	.2801	.2662	.2641	.2534	.2614
18	.2662	.2686	.2614	.2852	.2641	.2686	.2614
19	.4183	.3761	.3921	.3993	.3961	.3582	.3734
20	.4563	.394	.4108	.4373	.415	.4119	.4294
21	.4373	.3982	.4108	.4183	.415	.4163	.4668
22	.4373	.3982	.4294	.4183	.4527	.4119	.4481
23	.4373	.394	.4108	.4373	.4338	.4298	.4294
24	.3961	.3803	.394	.3921	.3993	.3961	.394
Max	.4563	.3982	.4294	.4373	.4527	.4298	.4668
Min	.2092	.2507	.1867	.2472	.2641	.2534	.2427
Avg	.3276	.3178	.3189	.3202	.3328	.3244	.3180

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 202 / 11 KV VIDYAPEETH

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2641	.244	.2294	.2829	.2627	.2641	.2347
2	.2452	.244	.208	.2641	.244	.2452	.213
3	.2452	.2252	.2056	.2452	.2252	.2452	.208
4	.2452	.2252	.208	.2452	.2252	.2641	.208
5	.2641	.2252	.2187	.2641	.2252	.2829	.2401
6	.3018	.244	.2486	.3018	.2627	.3206	.2915
7	.3206	.2627	.2515	.3018	.2627	.3395	.2947
8	.2829	.244	.2401	.2452	.2815	.3018	.2774
9	.2263	.2252	.208	.2263	.2252	.2829	.2481
10	.2452	.2092	.2058	.1867	.2815	.2829	.2865
11	.2252	.1734	.2987	.1877		.3658	.3921
12	.2252	.1791	.3174	.1877		.3801	.4108
13	.2252	.1753	.3174	.1877		.3439	.3734
14	.2252	.1907	.3361	.1877	.3395	.3582	.3547
15	.2252	.1907	.3361	.2064	.3772	.3841	.4108
16	.244	.2279	.3361	.2252	.3961	.4207	.4294
17	.2627	.2454	.3734	.244	.415	.4344	.4668
18	.2815	.2481	.3174	.2662	.3018	.3366	.3547
19	.3003	.2658	.2987	.2815	.3018	.3366	.3547
20	.319	.2896	.3174	.3003	.3206	.3366	.3547
21	.3003	.2515	.3174	.3003	.3018	.3121	.3547
22	.3042	.2458	.3174	.3003	.3018	.2947	.3361
23	.2815	.2658	.2987	.2815	.3018	.2713	.3361
24	.2829	.2627	.2347	.2801	.2627	.2829	.2515
Max	.3206	.2896	.3734	.3018	.415	.4344	.4668
Min	.2252	.1734	.2056	.1867	.2252	.2452	.208
Avg	.2643	.2317	.2767	.2500	.2912	.3203	.3201

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 203 / Siber

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6224	.5894	.5175	.5658	.5324	.5658	.5544
2	.5847	.5704	.5175	.5658	.4944	.547	.5544
3	.547	.5704	.4938	.4904	.4944	.5281	.5175
4	.547	.5324	.5121	.4904	.4753	.5281	.5175
5	.5658	.5514	.5544	.4904	.4753	.5658	.5601
6	.6224	.5894	.5975	.547	.4563	.6413	.6161
7	.5281	.6084	.5601	.5093	.4753	.5658	.5228
8	.5281	.5704	.5041	.4904	.4944	.5281	.5601
9	.4904	.5704	.5415	.4904	.5514	.5658	.5415
10	.4715	.5514	.5601	.4481	.5704	.5847	.6161
11	.5134	.5228	.5415	.4373		.5975	.6161
12	.5134	.5359	.5228	.4183		.6348	.5975
13	.4944	.5175	.5041	.4373		.5601	.5975
14	.5324	.4668	.4854	.4753	.6036	.5788	.5975
15	.5514	.4755	.4854	.4563	.6602	.6099	.6722
16	.5324	.4435	.4854	.4753	.6602	.6535	.6535
17	.5324	.4251	.4854	.4944	.5281	.6161	.6161
18	.5324	.499	.4668	.4183	.4904	.5175	.5041
19	.7606	.6161	.5975	.6084	.6979	.6722	.6722
20	.7986	.6722	.6722	.6655	.6979	.7095	.7468
21	.7796	.6535	.6348	.6465	.6979	.6653	.7468
22	.7415	.6348	.6348	.6465	.6979	.6653	.7468
23	.6845	.6099	.5975		.6979	.6653	.7468
24	.6602	.6275	.5359	.5601	.5704	.6224	.5914
Max	.7986	.6722	.6722	.6655	.6979	.7095	.7468
Min	.4715	.4251	.4668	.4183	.4563	.5175	.5041
Avg	.5889	.5585	.5420	.5142	.5725	.5995	.6111

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(E) S/DN.[016] BU 4016

Substation No/ Name :- 144106 / 33/11 KV SHIVAJI VIDYAPEETH

Feeder No / Name : 411 / 33 KV Incomer no I

NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING

(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.2449	1.1979	1.1203	1.1883	1.1408	1.1883	1.1763
2	1.1317	1.1979	1.1203	1.1317	1.0838	1.1317	1.1203
3	1.1317	1.1408	1.0642	1.0185	1.0838	1.0751	1.0642
4	1.0751	1.0838	1.0534	1.0185	1.0268	1.1317	1.0642
5	1.1317	1.0838	1.1643	1.0751	.9697	1.1883	1.1763
6	1.3014	1.1408	1.2323	1.1883	1.0268	1.3014	1.2883
7	1.1883	1.1979	1.1763	1.1317	1.0268	1.2449	1.1203
8	1.1317	1.1408	1.1203	1.0185	1.0838	1.1883	1.1763
9	1.0185	1.0838	1.0642	1.0185	1.0838	1.1317	1.0642
10	1.0185	1.0268	1.0642	.8962	1.1408	1.1317	1.1763
11	.9697	.9522	1.1203	.9127		1.2323	1.2323
12	.9697	1.0082	1.0082	.8556		1.2883	1.2323
13	.9697	.9522	1.1203	.9127		1.1763	1.2323
14	1.0268	.9522	1.0642	.9127	1.1883	1.2323	1.2323
15	1.0838	.9522	1.0642	.9127	1.3014	1.2883	1.3443
16	1.0268	.9522	1.0642	.9697	1.3014	1.3443	1.3443
17	1.0838	.9522	1.1203	1.0268	1.1883	1.3443	1.3443
18	1.0838	1.0082	1.0642	.9697	1.0751	1.1763	1.1203
19	1.4831	1.2883	1.2883	1.312	1.4146	1.4003	1.4003
20	1.5972	1.4003	1.4003	1.426	1.4146	1.5123	1.5123
21	1.5401	1.3443	1.3443	1.369	1.4146	1.4563	1.5684
22	1.4831	1.3443	1.4003	1.369	1.4712	1.4003	1.5123
23	1.426	1.2883	1.2883	1.312	1.4146	1.4003	1.5123
24	1.358	1.2549	1.2323	1.2323	1.2549	1.3014	1.2883
Max	1.5972	1.4003	1.4003	1.426	1.4712	1.5123	1.5684
Min	.9697	.9522	1.0082	.8556	.9697	1.0751	1.0642
Avg	1.1865	1.1227	1.1566	1.0908	1.1955	1.2611	1.2626

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 201 / 11KV KASABA BAWADA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4118	1.448	1.4118	1.267	1.3937	1.3756	1.3756
2	1.3213	1.3394	1.3032	1.2127	1.3213	1.3213	1.3394
3	1.3213	1.267	1.267	1.2127	1.3213	1.2851	1.3394
4	1.3213	1.267	1.267	1.2127	1.3213	1.2851	1.3394
5	1.3937	1.3032	1.3032	1.2489	1.3756	1.3575	1.4118
6	1.448	1.4118	1.5746	1.3756	1.448	1.5023	1.5384
7	1.448	1.4661	1.5384	1.5023	1.5384	1.5384	1.5746
8	1.5203	1.448	1.5384	1.4661	1.5384	1.5203	1.5203
9	1.4842	1.4299	1.5565	1.448	1.5203	1.4118	1.4299
10	1.4118	1.3937	1.3756	1.3575	1.3756	1.3756	1.4118
11	1.3032	1.2851	1.3213	1.3213	1.3394	1.3394	1.4299
12	1.4118	1.2308	1.3575	1.3394	1.3032	1.4661	1.3575
13	1.3032	1.3032	1.3032	1.3213	1.4118	1.4299	1.4842
14	1.3575	1.267	1.3213	1.3213	1.3756	1.448	1.4118
15	1.3756	1.3394	1.3213	1.3394	1.3756	1.448	1.3937
16	1.3575	1.3756	1.2489	1.3756	1.3213	1.3394	1.3937
17	1.4299	1.3937	1.3213		1.4842	1.4299	1.4661
18	1.448	1.448	1.3937	1.4299	1.4299	1.5384	1.448
19	1.8823	1.8461	1.9547	1.9366	1.9366	1.8642	2.0633
20	2.009	2.0271	1.9185	1.9547	1.9366	1.9547	2.0271
21	1.9547	1.9366	1.8461	1.8823	1.8823	1.828	1.9185
22	1.8461	1.8642	1.7918	1.8461	1.8099	1.828	1.8642
23	1.6832	1.7194	1.6832	1.7375	1.6832	1.7556	1.6651
24	1.5203	1.5565	1.5384	1.4842	1.5384	1.4661	1.4842
Max	2.009	2.0271	1.9547	1.9547	1.9366	1.9547	2.0633
Min	1.3032	1.2308	1.2489	1.2127	1.3032	1.2851	1.3394
Avg	1.4985	1.4736	1.4774	1.4606	1.4992	1.5045	1.5287

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 202 / 11 KV KOLHAPUR SUGAR MILL SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1174	.1457	.2075	.2452	.2075	.2075	.1698
2	.1174	.1543	.2452	.2263	.2452	.2075	.1698
3	.1174	.1698	.2452	.2263	.2452	.2075	.1698
4	.1189	.2641	.2641	.2263	.2452	.2075	.1698
5	.1219	.2829	.2263	.2263	.2075	.1886	.1698
6	.1235	.1543	.1886	.2263	.2075	.1886	.1698
7	.1543	.1372	.1886	.2075	.2075	.1698	.1886
8	.1406	.1115	.2452	.2075	.1886	.1698	.1886
9	.1734	.1372	.2829	.2452	.2477	.1698	.1886
10	.1886		.1753	.2452	.2452	.2263	.1886
11	.2452	.2263	.2012	.2452	.2641	.1848	.2075
12	.1886	.2241	.2033	.2477	.2829	.2075	.2075
13	.1698	.3174	.1696	.2477	.2829	.1886	.2241
14	.1698		.2987	.2263	.3018	.2263	.2241
15	.3395	.3395	.1696	.2641	.2641	.1867	.2075
16	.3018	.1886	.1734	.2667	.3018	.2054	.2263
17	.1928	.2987	.0754	.2096	.2075	.2075	.1698
18	.181	.3547	.0754	.2054	.2075	.2263	.2263
19	.3547	.3395	.2641	.2452	.2075	.1886	.2263
20	.3547	.3395	.2263	.2263	.1698	.2075	.2452
21	.3547	.3961	.2263	.2075	.2075		.1509
22	.3361	.1886	.0754	.2075	.2452	.1629	.1509
23	.1406	.2829	.0754	.2075	.2263	.2075	.1509
24	.1174	.1372	.2641	.2829	.2452	.2075	.1886
Max	.3547	.3961	.2987	.2829	.3018	.2263	.2452
Min	.1174	.1115	.0754	.2054	.1698	.1629	.1509
Avg	.2008	.2359	.1986	.2322	.2359	.1978	.1908



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 203 / 11KV ULAPEMALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1646	.1646	.1463	.1463	.1646	.1463	.1646
2	.1646	.1646	.1463	.128	.1646	.1463	.128
3	.1646	.1646	.1463	.128	.1646	.128	.128
4	.1646	.1463	.1463		.1646	.128	.128
5	.1463	.1463	.1463	.128	.1463	.1463	.128
6	.1463	.1646	.1463	.1463	.1463	.1646	.1463
7	.1463	.1463	.1463	.128	.128	.1646	.1463
8	.1646	.1463	.128	.1463	.1097	.1646	.128
9	.2195	.2195	.1646	.128	.1463	.2012	.1646
10	.2378	.2195	.1646	.128	.1829	.1829	.2012
11	.3109	.2195	.1829	.1097	.2012	.2012	.2378
12	.2195	.1829	.1829	.1097	.2012	.2012	.2195
13	.2012	.1829	.1463	.1097	.2012	.2012	.2195
14	.2378	.2012	.1646	.128	.2012	.2195	.2012
15	.2743	.2195	.1646	.128	.2012	.2012	.2012
16	.2195	.2195	.1646	.128	.1829	.2012	.2012
17	.2012	.2075	.128	.128	.1463	.2195	.2195
18	.1646	.2012	.1463	.128	.2012	.2012	.2012
19	.2012	.2195	.1829	.1463	.1829	.2012	.2195
20	.2012	.2195	.1646	.1463	.2012	.1829	.2012
21	.2195	.2195	.1829	.2012	.2012		.2012
22	.2012	.1829	.1829	.2012	.1829	.1829	.2012
23	.1829	.1829	.1829	.1646	.1829	.1886	.1829
24	.1646	.1829	.1829	.1646	.1646	.1646	.1829
Max	.3109	.2195	.1829	.2012	.2012	.2195	.2378
Min	.1463	.1463	.128	.1097	.1097	.128	.128
Avg	.1966	.1885	.1600	.1391	.1738	.1800	.1814

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 204 / 11 KV WADANAGE GAOTHAN  
Feeder KV- 11 / OUTGOING

GAOTHAN FEEDER

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5914	.5914	.5914	.5914	.6468	.6099	.6099
2	.5544	.5544	.5544	.5544	.6099	.5914	.5914
3	.5544	.5544	.5544	.5544	.6099	.5914	.5914
4	.5544	.5729	.5544	.5729	.5721	.5914	.5914
5	.6099	.5914	.6283	.6099	.6468	.6099	.6283
6	.6468	.6653	.7207	.7023	.6838	.6468	.7023
7	.6468	.6468	.7023	.7392	.6653	.7392	.6838
8	.6283	.6468	.7023	.6468	.6283	.6283	.5729
9	.6099	.7392	.6468	.6653	.5914	.5914	.5729
10	.2033	.7207	.6283	.6838	.5914	.5729	.5914
11	.2587	.7023	.6283	.6468	.5175	.6283	.6099
12	.2402	.5914	.6468	.6468	.499	.6099	.5914
13	.2218	.6468	.5914	.6283	.5175	.6653	.6099
14	.2218	.6838	.5914	.6283	.5914	.6838	.6653
15	.2402	.7023	.6283	.6653	.6099	.6468	.6283
16	.2587	.7392	.5914	.6838	.5914	.6653	.6283
17	.7947	.6653	.6838	.6468	.5729	.7207	.6468
18	.7762	.7392	.6838	.6653	.5544	.6099	.6283
19	.961	.924	.8316	.8686	.8131	.8501	.8316
20	.9979	1.0349	.924	.924	.8686	.9055	.924
21	.924	.9795	.8686	.8871	.8501	.8686	.9055
22	.8686	.9055	.8686	.8871	.8501	.8501	.7577
23	.7762	.7947	.8131	.8316	.7392	.7392	.7577
24	.6283	.6468	.6653	.6653	.7392	.6468	.6468
Max	.9979	1.0349	.924	.924	.8686	.9055	.924
Min	.2033	.5544	.5544	.5544	.499	.5729	.5729
Avg	.5737	.7100	.6792	.6915	.6483	.6776	.6653

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144034 / 33/11 Kv Sugar Mill

Feeder No / Name : 205 / 11 KV Sarwal AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4334					.3121	.3641
2	.4161					.3121	.3641
3	.4161					.3467	.3814
4	.4161					.3467	.3814
5	.4334					.3814	.3988
6	.4854					.4508	.4161
7	.5375					.4681	.4681
8	.5375					.4681	.5201
9	.5721						
10				.5028			
11	.7108	.6516	.6935	.6068			
12	.7108	.7802	.7282	.5721			
13	.7108	.7455	.7108	.5721			
14	.6762	.7282	.7108	.5548			
15	.6935	.7108	.6588	.5548			
16	.6241	.6588	.6241	.5721			
17	.5721	.6588	.6241	.5201			
18	.5201	.6068	.5201				
23					.2947	.3641	.3988
24	.4334					.3121	.3641
Max	.7108	.7802	.7282	.6068	.2947	.4681	.5201
Min	.4161	.6068	.5201	.5028	.2947	.3121	.3641
Avg	.5500	.6926	.6588	.5570	.2947	.3762	.4057

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 201 / 11 KV NAGALA AG

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
2		.104	.0876			
3				.0876		
4		.1052	.0876			
5				.0876		
6		.1417	.1402			
7				.0895		
8			.1402			
12				.1907		
13				.1753		
14					.156	
16						.1214
17				.1734		.1387
18	.1387					
24		.0876	.0701	.0693		
Max	.1387	.1417	.1402	.1907	.156	.1387
Min	.1387	.0876	.0701	.0693	.156	.1214
Avg	.1387	.1096	.1051	.1248	.156	.1301

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 202 / 11KV FILTER HOUSE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.9522
2	.9808	.9335		.9054	.9431		.8775
3			.9431			1.0185	
4	.8589	.8488		.811	.9431		
5			.9054			1.0185	
6	.9242	.8402		.8299			.8962
7	1.0185		.9808		1.0751	1.0562	
8		.9896		.9242			1.0082
9	1.1128				1.0374		1.0456
10	1.0903	.9979					
12	1.1203	1.0082	.9896	1.0082			
13	1.0059	.9335	.9896				
14	.9896		.8676			.9709	
15			.9619				
16	.9896	.9896	.9795	.8962			1.0456
17				.8215	.8488		.9709
18	.9709						
19	1.1389			1.0456			1.1694
21	1.226	1.1576	1.1763	1.094	1.2323	1.1949	
22							1.2071
23	1.1694	1.1694	1.1317			1.226	
24	1.1317	1.1317		1.0374	1.0185	1.0185	1.0751
Max	1.226	1.1694	1.1763	1.094	1.2323	1.226	1.2071
Min	.8589	.8402	.8676	.811	.8488	.9709	.8775
Avg	1.0485	1	.9926	.9373	1.0140	1.0719	1.0248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 203 / 11KV AKASHWANI FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.9335
2	.9478	.8402		.8676		.9808	.8775
3			.9054				
4	.8775	.811		.7733	.9431		
5			.8775			.9808	
6	.9242	.811		.7922			.8589
7	.9619		.9619		.9808	1.0562	1.0082
8		.9431		.8865			
9	1.0456				.9619		1.0185
10	1.0719	1.0269					
12	1.1016	.9896	1.0829	.9335	1.1694		
13	1.0719	1.0269	.8589		1.1506		
14	1.0642					1.1317	
15			1.094				
16	1.0374	.9808	1.1203	.8775			1.1763
17				.8589	1.1883		
18	.9808						
19	1.1763			1.0903			1.3014
21	1.1827	1.1949	1.1203	1.0719	1.1576	1.1763	
22							1.1273
23	1.1128	1.1317	1.1317			1.1576	
24	1.1317	.9431	1.0185	.9997	.9808	1.0185	1.0374
Max	1.1827	1.1949	1.1317	1.0903	1.1883	1.1763	1.3014
Min	.8775	.811	.8589	.7733	.9431	.9808	.8589
Avg	1.0459	.9727	1.0171	.9151	1.0666	1.0717	1.0377

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 205 / 11KV LAXMIPURI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.9522
2	.9897	.9431		.9431		.9431	.8962
3			.9431				
4	.9431	.8676		.8865	.9054		
5			.9335			.9431	
6	.9431	.8676		.8676			.8775
7	.9335		.9242		.8962	.9431	
8		.9431		.8676			.9335
9	1.0269				.9619		.9979
10	1.1273	1.0903					
12	1.6448	1.4969	1.6263	1.3256	1.5684		
13	1.5364	1.423	1.4784		1.6244		
14	1.4969		1.5339			1.6263	
15			1.4784	1.1088			
16	1.475	1.4937	1.5339	1.1203			3.3808
17				1.1576	1.6244		
18	1.5123						
19	1.7187			1.3306			
21	1.363	1.3443	1.4377	1.2752	1.3817	1.4003	
22							1.2883
23	1.2071	1.1694	1.226			1.1949	
24	1.1317	1.094	1.0562	1.0374	1.0648	1.0374	1.0642
Max	1.7187	1.4969	1.6263	1.3306	1.6244	1.6263	3.3808
Min	.9335	.8676	.9242	.8676	.8962	.9431	.8775
Avg	1.2700	1.1575	1.2883	1.0837	1.2534	1.1555	1.2988

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 206 / 11KV USHA TALKIES FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.961
2	.9431	.9431		.9431			.9054
3			.9054			.9431	
4	.8865	.8865		.8676	.9054		
5			.9054			.9242	
6	.9242	.9242		.9054			.8962
7	.9808		.9431		.9335	.9242	
8		1.0185		.9242			.9431
9	1.1016				1.0456		1.0082
10	1.251	1.2696					
12		1.643	1.6221	1.2696	1.6409		
13	2.1068	1.643	1.587		1.6032		
14	1.7737		1.5089			1.6598	
15			1.4937				
16	1.7551	1.6787	1.5684	1.1763			1.7924
17				1.251	1.6975		
18	1.5844						
19	1.7177			1.3957			
21	1.3203	1.2696	1.363	1.1763	1.251	1.251	
23	1.2449	1.2071	1.1763			1.2136	
24	1.1317	1.1317	1.0751	1.0751	1.0562	1.0562	1.0751
Max	2.1068	1.6787	1.6221	1.3957	1.6975	1.6598	1.7924
Min	.8865	.8865	.9054	.8676	.9054	.9242	.8962
Avg	1.3373	1.2377	1.2862	1.0984	1.2667	1.1389	1.0831



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 208 / 11KV BLOOD BANK FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							.6161
2	.6036	.5601		.5281			.5415
3			.6036			.5658	
4	.5658	.5281		.5281	.5281		
5			.5847			.547	
6	.5658	.547		.547			.5415
7	.5658		.5658		.5228	.547	
8		.5847		.5658			.5359
9	.6535	.679			.6036		.6283
10	.7947	.7762					
12	.9055	.8131	.9149	.6535	.9619		
13	.924	.8501	.924		.9808		
14	.924		.9335			.0373	
15			.9522				
16	.9896	.9335	1.0269	.7095			1.0829
17				.7282	1.1016		
18	.9709						
19	1.0903			.8131			
21	.9149	.8962	.9522	.7655	.8402	.9149	
22							.7655
23	.7356	.7545	.7545			.7468	
24	.679	.679	.6602	.6852	.5975	.6036	.6468
Max	1.0903	.9335	1.0269	.8131	1.1016	.9149	1.0829
Min	.5658	.5281	.5658	.5281	.5228	.0373	.5359
Avg	.7922	.7168	.8066	.6524	.7671	.5661	.6698

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 411 / 33 KV NAGALA PARK

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1							5.9374
2	5.7693	5.5453		5.5441			4.8234
3			5.7716			5.9414	
4	5.4321	5.036		5.2624	5.5418		
5			5.7133			5.8848	
6	5.8282	5.6584		5.4887			5.5453
7	5.7133		5.998		5.8162	5.8814	
8		5.8848		5.8282			5.8213
9	6.5295						6.3855
10	7.3377	6.9856					
12		8.682	8.6334	7.8652			
13	9.5913	8.682	8.4705				
14	8.9815		7.1131			8.0904	
15			8.1756				
16	9.0741	8.738	8.4162	7.1136			9.6022
17				7.1331	9.1221		
18	8.5791						
19	9.7737			8.6488			9.273
21	8.0904	8.1219	8.1219	7.6269	8.4019	8.514	
22							7.5617
23	7.1696	7.1696	6.4975			7.2817	
24	6.6095	6.5072	6.4415	6.4415	6.3855	6.3295	6.4975
Max	9.7737	8.738	8.6334	8.6488	9.1221	8.514	9.6022
Min	5.4321	5.036	5.7133	5.2624	5.5418	5.8814	4.8234
Avg	7.4628	7.0010	7.2139	6.6953	7.0535	6.8462	6.8275

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144035 / 33/11KV NAGALA S/S

Feeder No / Name : 412 / 33 KV INCOMER NO. 1

Feeder KV- 33 / INCOMING

DATE	02-APR-18
HR	Load (MW)
12	7.8978
Max	7.8978
Min	7.8978
Avg	7.8978

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 201 / 11KV S.T. STAND FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.094	.9431		.9526	.9431		.9808
2	1.0374	.9054	1.0829	.8954	.9522	.9335	.9431
3	1.0082	.8676		.8573	.8775		.9431
4	.9619	.7922	.9877	.8383	.7655	.8962	.9054
5	.9808	.8299		.8383	.7842		.8865
6	.9709	.8488	.9335	.8573	.8029	.7842	.8764
7	.9896	.8573		.8676	.8488		.8954
8	1.0642	.9907	1.1389	.9431		1.0082	.9808
9	1.1128	1.1128	1.1949		1.0374	1.1576	1.226
10	1.226	1.2071	1.2637	1.1203	1.226	1.1506	1.1203
11	1.226	1.2637	1.226	1.1389	1.094		1.3817
12	1.4146	1.3392	1.4335		1.1128		1.5684
13	1.3957	1.3203	1.3957		1.1506		
14	1.4901	1.3014	1.358	1.2696	1.1128		
15	2.1125		1.4335	1.307	1.226		1.5684
16	1.4901	1.5655	1.4712	1.3443		2.1691	1.5684
17	1.5466		1.4901	1.2637	1.2449	2.2497	1.6787
18	1.5089	1.5123	1.4901	1.3014	1.6804	2.2218	1.5655
19		1.8111	1.6975	1.5655	1.7364	1.7926	
20	1.773		1.7193	1.6221		1.7353	1.7164
21	1.6787	1.643			1.6617	1.5844	1.6032
22	1.6409	1.531	1.3957	1.5089	1.4377	1.5089	
23	1.4335	1.4335	1.3014	1.226	1.307	1.2637	1.358
24	1.1128	1.094	1.1203	.9997	.9997	1.1949	1.0562
Max	2.1125	1.8111	1.7193	1.6221	1.7364	2.2497	1.7164
Min	.9619	.7922	.9335	.8383	.7655	.7842	.8764
Avg	1.3161	1.1986	1.3228	1.1359	1.1429	1.4434	1.2411

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 202 / 11 KV LINE BAZAR FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5121	.4854		.4854	.462		.5228
2	.4805	.4481	.4938	.4715	.4668	.4805	.5068
3	.4572	.4108		.4527	.4294		.5175
4	.462	.4527	.4854	.4527	.4108	.4435	.5041
5	.4854	.4904		.4481	.4668		.5228
6	.4572	.5281	.4854	.5093	.4854	.4805	.5788
7	.4755	.5093		.5788	.5281		.5415
8	.4805	.5041	.4854	.5228	.5601	.499	.5415
9	.4805	.5359	.5228		.5788	.5121	.5359
10	.5304	.4207	.5487	.5041	.5975	.5975	.6161
11	.5249	.4755	.5121	.5041	.5121		.5975
12	.5068	.462	.567		.5611		.5601
13	.4938	.4572	.5121		.5731		
14	.4755	.4207	.5359	.4854	.567		
15	.5121		.5544	.4668	.5914		.567
16	.5121	.4435	.5249	.5415		.5788	.5975
17	.5068		.4163		.6036	.5249	.5788
18	.4887	.5415	.4938	.4854	.5228	.543	.5041
19		.6535	.6335	.6348	.5975	.6516	
20	.7282		.6584	.6219		.724	.6722
21	.6979	.6348			.6908	.6878	.6535
22	.6283	.6161	.5973	.6099	.6722	.6516	
23	.5975		.5975	.5601	.5975	.6154	.5975
24	.5228	.5093	.5175	.5068	.4854	.5041	.5249
Max	.7282	.6535	.6584	.6348	.6908	.724	.6722
Min	.4572	.4108	.4163	.4481	.4108	.4435	.5041
Avg	.5225	.5000	.5338	.5180	.5436	.5663	.5620

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 203 / 11 KV EXCISE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8484	1.6975		1.6787	1.6787		1.5655
2	1.8111	1.6598	1.7737	1.6004	1.6221	1.5497	1.5432
3	1.8111	1.6221		1.4861	1.5278		1.4861
4	1.6804	1.5844	1.7364	1.448	1.5089	1.5123	1.448
5	1.7541	1.6004		1.4289	1.5655		1.4335
6	1.7364	1.6032	1.643	1.4861	1.5844	1.5497	1.5844
7	1.7353	1.7353		1.5432	1.5655		1.6409
8	1.7353	1.6975	1.6804	1.6194	1.6409	1.8111	1.6787
9	1.7337	1.7353	1.6617		1.6221	1.6598	1.7541
10	1.8673		1.8861	1.5497	1.8484	1.7353	1.7177
11	2.0748		1.9427	1.6804	1.9427		1.9978
12	2.037	2.2822	1.9993		.3658		2.1472
13	1.9616	1.9978	1.9616		.3696		
14	1.9805	1.8861	1.905	1.6804	.3772		
15			2.0748	1.6617	2.32		2.0911
16	2.0182	1.9427	2.0165	1.7364		.3772	2.0538
17	1.9616		2.0182		2.2634	.4108	2.0559
18	1.8107	1.9418	1.9616	1.5278	2.0351	.4108	2.0559
19		2.2779	2.3388	1.9805	2.1472	2.3899	
20	2.2779		2.3339	1.9993		2.3388	2.2445
21	2.1658	2.2822			2.2218	2.1879	2.2068
22	2.1691	2.0633	2.1313	1.8861	2.2779	2.0559	
23	2.0182		1.9427	1.8484	1.9231	1.9616	1.9993
24	1.8861	1.8484	1.8111	1.7541	1.0562	1.7364	1.7918
Max	2.2779	2.2822	2.3388	1.9993	2.32	2.3899	2.2445
Min	1.6804	1.5844	1.643	1.4289	.3658	.3772	1.4335
Avg	1.9125	1.8588	1.9378	1.6629	1.6120	1.5791	1.8248

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 204 / 11KV SHAHU COLLEGE FEEDER

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1128	1.0185		.9335	.9997		.9054
2	1.0751	.9808	.9896	.8383	.9431	.8775	.9054
3	1.0642	.9431		.8002	.8865		.8865
4	1.0269	.8962	.9145	.7733	.9054	.8589	.8488
5	.9242	.8589		.7545	.9242		.8488
6	.9431	.8589	.8686	.811	.9431	.9149	.8865
7	.9431	.9054		.8865	.9431		.9619
8	1.0562	.9431	.9979	.8676	.9054	1.0269	.9431
9	1.0185	.9896	.9335		1.0185	.9522	.9149
10	.8775	.9431	.8871	.8962	.8299	.9242	.9522
11	.8402	.8488	.6979	.8962	.5601		.9335
12	.8775	.7842	.6908				.9335
13	.8676	.8865	.8029				
14	.8436	.9522	.7842	.9335	1.0642		
15	.8488			1.0456	1.0456		.9335
16	.8299	.9242	.8589	.7655		2.0559	.9335
17	.7842		.8488		.9896		.8676
18	.8215	.8775	.8316	.8676	.9522		.9242
19		1.1389	1.0642	1.1016	1.0269	1.2883	
20	1.1016		1.1203	1.1317		1.1763	1.2696
21	1.1016	1.1763			1.2136	1.1576	1.2826
22	1.226	1.1763	1.0829	1.1694	1.2136	1.1389	
23	1.2449		1.0751	1.1694	1.1949	1.1016	1.2826
24	1.1317	1.0751	1.0242	.9808	1.0562	1.0829	.9808
Max	1.2449	1.1763	1.1203	1.1694	1.2136	2.0559	1.2826
Min	.7842	.7842	.6908	.7545	.5601	.8589	.8488
Avg	.9809	.9589	.9152	.9275	.9808	1.1197	.9697

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 205 / RAW WATER WORKS

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3174	.1307		.3921	.3174		.3961
2	.2801	.1867	.3921	.3961	.2801	.4294	.3961
3	.2801	.2772		.3921	.2801		.415
4	.2587	.3361	.3361	.3961	.2987	.3921	.3961
5	.2801	.3734		.3772	.3174		.3961
6	.2957	.415	.3734	.3772	.3174	.3547	.3681
7	.2987	.4108		.3734	.3361		.3506
8	.3142	.3961	.4108	.3772	.3361	.4108	.3681
9	.3292	.4338	.4294		.4481	.4481	.4527
10	.1417	.3772	.5093	.4108	.5281	.415	.4715
11	.443	.1509	.5847	.4108	.5658		.6722
12	.1448	.3772	.547		.5658		.5601
13	.1357	.3584	.547		.5847		
14	.1595	.2561	.4904	.112	.5415		
15			.5281	.3961	.5601		.6161
16	.1387	.3772	.547	.4108		.4854	.5975
17	.1341		.5093			.5601	.4904
18	.4338	.4481	.8865	.3206	.5041	.5041	.415
19		.4854	.3326	.3584	.4854	.5041	
20	.4527		.3142			.4294	.3734
21	.3881	.4481		.3584	.4481		.3361
22	.1036	.4294	.2218	.2561	.2614	.3921	
23	.0867		.3961	.3361		.3921	.3395
24	.3142	.1006	.4294	.3921	.3395	.4382	.3921
Max	.4527	.4854	.8865	.4108	.5847	.5601	.6722
Min	.0867	.1006	.2218	.112	.2614	.3547	.3361
Avg	.2605	.3384	.4624	.3602	.4158	.4397	.4401



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 206 / APPLE HOSPITAL.

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.0693	.0709		.0876	.0693		.104
2	.0532	.0724	.0747	.0701	.0693	.0934	.104
3	.0532	.0724		.0701	.052		.1132
4	.0549	.0724	.056	.0701	.0526	.0747	.0876
5	.0739	.0716		.0701	.0526		.0876
6	.0732	.0934	.0747	.0701	.0701	.0732	.1052
7	.0747	.0895		.0886	.0876		.1052
8	.1097	.1294	.112	.0886	.0867	.1307	.1227
9	.0914	.1417	.112	.0876	.0867	.1307	.1075
10	.1494	.1478	.1086	.0934	.1448	.1463	.1307
11	.1867	.1595	.124	.0934	.1267		.1867
12	.1867	.1494	.1086		.1595		.168
13	.1753	.168	.1109		.1227		
14	.1417	.128	.1448	.0934	.1294		
15	.1478		.1848	.0747	.1307		.168
16	.1829	.1086	.1417	.0934		.1417	.1307
17	.1294		.124			.1629	.1478
18	.128	.1307	.1417	.1086	.1307	.112	.112
19		.1307	.1595	.0914	.1307	.1267	
20	.1052		.1006			.1063	.0732
21	.1063	.112		.0709	.0747	.1097	.1254
22	.0876	.112	.1387	.0905		.1075	
23	.0949		.0924	.0693	.0943	.0537	.0732
24	.0732	.0914	.0934	.0693	.0732	.0754	.104
Max	.1867	.168	.1848	.1086	.1595	.1629	.1867
Min	.0532	.0709	.056	.0693	.052	.0537	.0732
Avg	.1108	.1126	.1160	.0826	.0972	.1097	.1178

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(N) S/DN.[019] BU 4019

Substation No/ Name :- 144102 / CIRCUIT HOUSE S/S

Feeder No / Name : 207 / 11 KV STP Express

Feeder KV- 11 / OUTGOING

NON SHEDDABLE EXPRESS HV FEEDERS

(NON-CONTINUOUS PROCESS)(NO

STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3898	.3658		.3669	.3761		.4031
2	.4024	.3258	.5041	.373	.3777	.5847	.3506
3	.3881	.2957		.3721	.3403		.2629
4	.3547	.3361	.3841	.3865	.3109	.4108	.3155
5	.3475	.3982		.3856	.3109		.333
6	.3696	.5611	.415	.3506	.3292	.3921	.2454
7	.3658	.3561		.4161	.3475		.1753
8	.6283	.2515	.7545	.3121	.4572	.2427	.2279
9	.2427	.2629	.7356		.6697	.679	.2614
10	.2241	.362	.4477	.4481	.1991	.2454	.3206
11	.5041	.631	.7362	.3961	.3582		.132
12	.3544	.6135	.6783		.1867		.3584
13	.4161	.4854	.4784		.2054		
14	.7701	.6878	.5121	.5093	.5068		
15			.5194	.6908	.3361		.5093
16	.4961	.6379	.1949	.4904		.4784	.5601
17	.5201		.3467			.2896	.4557
18	.6556	.679	.5028	.6219	.2829	.2042	.0934
19		.4382	.4111	.4527	.2829	.6613	
20	.2454		.2774	.4801		.1505	.4458
21	.2572	.4854			.2452	.2743	.2241
22	.5426	.4001	.4075	.5721	.0754	.6415	
23	.3155		.443	.4481	.4527	.2229	.112
24	.4075	.3988	.6535	.4075	.4024	.3961	.1402
Max	.7701	.6878	.7545	.6908	.6697	.679	.5601
Min	.2241	.2515	.1949	.3121	.0754	.1505	.0934
Avg	.4181	.4486	.4949	.4463	.3359	.3916	.2963

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 202 / 11KV RANKALA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.3203	1.2803	1.3443	1.1888	1.251	1.1949	1.3169
2	1.2826	1.2437	1.3203	1.0608	1.094	1.0829	1.1888
3	1.2826	1.2437	1.3203	1.0608	1.094		1.1888
4	1.3203	1.2437	1.2826	1.0608	1.094	1.1576	1.1888
5	1.3203	1.2254	1.2826	1.0974	1.1694	1.1949	1.2696
6	1.2449	1.1888	1.2826	1.1222	1.2826	1.307	1.3032
7	1.2826	1.2071	1.2696	1.1222	1.2696	1.358	1.3394
8	1.3121	1.262	1.1706	1.2308	1.1706	1.2696	1.2127
9	1.262	1.1888	1.0974	1.1584	1.0974	1.1763	1.267
10	1.1462	1.1584	1.1462	1.1523	1.0974	1.1104	1.0679
11	1.086	1.0923	1.134	1.1706	1.0791	1.0791	.4163
12	1.1584	1.0749	1.0679	1.1157	1.0679	1.1403	1.1041
13	1.086	1.1222	1.0242	1.0425	1.086	1.1946	1.0498
14	1.2437	1.1222	1.1088	1.1317	1.134	1.1765	1.1584
15	1.1827	1.1403	1.0974	1.2567	1.2197	1.1946	1.2254
16	1.1827	1.1403	1.1222	1.1643	1.1403	1.1403	1.1706
17	1.1584	1.1584	1.1827	1.1088	1.1403	1.1765	1.2437
18	1.2127	1.134	1.2012	1.086	1.1403	1.2127	1.2308
19	1.6108	1.6476	1.6461	1.5927	1.5565	1.7737	1.7375
20	1.7737	1.7558	1.6827	1.6827	1.6832	1.8099	1.7918
21	1.6832	1.7741	1.6644	1.6095	1.7556	1.7918	1.7918
22	1.701	1.7002	1.6461	1.6263	1.7375	1.7194	1.7194
23	1.6095	1.5684	1.5729	1.5524	1.6057	1.6651	1.5203
24	1.4563	1.39	1.419	1.3169	1.3443	1.3817	1.3937
Max	1.7737	1.7741	1.6827	1.6827	1.7556	1.8099	1.7918
Min	1.086	1.0749	1.0242	1.0425	1.0679	1.0791	.4163
Avg	1.3300	1.2943	1.2953	1.2380	1.2629	1.3177	1.2874

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 203 / 11KV MAHALAXMI SANEGURUJI SHEDDABLE URBAN  
Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0498	1.0387	1.0829	.905	.961	.9412	1.0242
2	.9774	.9671	1.0269	.8326	.8775	.9412	.9511
3	.905	.8954	.961	.8326	.8775	.905	.9511
4	.905	.9431	.9425	.8326	.8962	.905	.9511
5	.9808	.9145	.961	.8507	.9709	.8688	1.0059
6	.9313	.9412	1.0456	.8596	1.1016	1.0136	1.0498
7	.9671	.8775	1.0082	.8417	1.0534	1.094	1.0136
8	.9313	.9313	.8779	.8775	.9511	.8869	.9593
9	.9671	.8954	.8779	.8954	.8869	.9412	.8688
10	.9412	.8238	.8596	.788	.8688	.8596	.8326
11	.7783	.7619		.8238	.7964	.8316	.7964
12	.823	.7619	.788	.8238	.5068	.8688	.8501
13	.8326	.8059	.7701	.8238	.8775	.8326	.8869
14	.8326	.8328	.788	.7947	.8238	.8688	.8326
15	.823	.8328	.788	.7947	.8507	.8326	.8326
16	.8688	.8328	.788	.8131	.8688	.8507	.8688
17	.8779	.7973	.8238	.8316	.8145	.8326	.8507
18	.8779	.8682	.8596	.8328	.8326	.8869	.8954
19	1.2803	1.3394	1.3073	1.2757	1.2127	1.4118	1.3611
20	1.39	1.3643	1.3432	1.3756	1.4118	1.448	1.4327
21	1.39	1.3611	1.3073	1.3717	1.39	1.4118	1.3969
22	1.3717	1.3032	1.2894	1.3032	1.3717	1.3937	1.3969
23	1.2803	1.2254	1.182	1.2071	1.2308	1.3032	1.2536
24	1.0745	1.0791	1.1203	.985	1.0719	1.0498	1.0679
Max	1.39	1.3643	1.3432	1.3756	1.4118	1.448	1.4327
Min	.7783	.7619	.7701	.788	.5068	.8316	.7964
Avg	1.0024	.9748	.9912	.9405	.9794	1.0075	1.0138

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 205 / PUIKHADI WATER WORKS NON SHEDDABLE WATER SUPPLY AND  
 Feeder KV- 11 / OUTGOING UTILITY

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2263	.2263	.5093	.4904	.5093	.5093	.4904
2	.1886	.1886	.5093	.4715	.5093	.463	.4904
3	.1886	.1886	.5281	.4715	.4904	.4904	.4904
4	.1886	.1886	.5093	.4715	.4904	.4904	.4904
5	.2263	.2263	.547	.5093	.5281	.5281	.5093
6	.2263	.4715	.5658	.5281	.5658	.5658	.5281
7	.2641	.4527	.5847	.4904	.5281	.547	.5281
8	.2263	.5658	.5281	.547	.5658	.5847	.5093
9	.2263	.5281	.4904	.5281	.4904	.547	.5093
10	.2263	.4715	.4904	.5093	.5093	.4904	.4904
11	.2641	.5525	.4904	.5281	.5093	.5335	.5093
12	.2075	.4001	.5281	.4904	.5281	.5335	.5281
13	.2263	.4382	.5281	.5093	.5093	.5335	.5093
14	.1698	.4954	.4904	.4715	.4715	.4954	.4904
15	.2452	.5144	.4904	.4715	.5281	.4763	.4904
16	.2641	.5144	.4904	.5093	.4715	.5335	.5281
17	.2452	.5144	.5281	.5093	.5093	.5335	.5281
18	.1886	.5716	.5281	.5093	.547	.5093	.5281
19	.1886	.4904	.5281	.547	.5658	.5093	.4904
20	.2075	.4904	.5093	.5093	.4904	.5093	.5281
21	.3018	.547	.5281	.4715	.5281	.5093	.5281
22	.3772	.5281	.547	.5847	.5281	.5093	.5281
23	.3395	.4904	.4715	.5281	.5093	.5093	.5281
24	.2263	.2829	.5281	.4904	.547	.5093	.5093
Max	.3772	.5716	.5847	.5847	.5658	.5847	.5281
Min	.1698	.1886	.4715	.4715	.4715	.463	.4904
Avg	.2350	.4308	.5187	.5061	.5179	.5175	.5108

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144032 / 33/11KV PUIKHADI SUBSTATION

Feeder No / Name : 206 / K N Patil

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.4763	.4525	.4572	.3734		.4805	.4668
2	.4191	.3982	.4001	.3361	.3239	.4805	.3734
3	.4191	.4066	.4001	.3361	.3239	.4805	.3734
4	.4572	.3982	.4001	.3361	.3239	.499	.3734
5	.4954	.4435	.4763	.3734	.4191	.499	.4481
6	.5335	.4525	.5335	.4435	.5525	.5175	.5544
7	.6224	.5359	.6036	.5359		.6099	.6283
8	.5788	.5359	.5228	.5175	.5041	.5544	.499
9	.5415	.499	.4668	.499	.4435	.462	.5068
10	.5068	.4805	.4066	.4805	.4435	.4344	1.0679
11	.4024	.4477	.4294	.439	.4251	.3982	.4251
12	.4525	.4298	.4207	.4435	.4066	.3881	.4435
13	.4572	.4298	.4251	.4338	.4251	.4435	.4251
14	.4435	.4298	.4108	.415	.4251	.4435	.4435
15	.4668	.4477	.4207		.4066	.4435	.4251
16	.462	.4477	.4207	.4338	.4435	.462	.4251
17	.4525	.4298	.4481	.4338	.4251	.4805	.4251
18	.4344	.4656	.4108	.4572	.4251	.462	.4477
19	.6154	.6485	.5975	.5853		.6838	.6401
20	.6653	.6908	.6348	.6653	.6653	.7207	.695
21	.6335	.6535	.6161	.6348	.6283	.7023	.6584
22	.4344	.6224	.5975	.6224	.6468	.6838	.6219
23	.5611	.5658		.5658	.5544	.6099	.5487
24	.5144	.4887	.4954	.4668	.5144	.4854	.499
Max	.6653	.6908	.6348	.6653	.6653	.7207	1.0679
Min	.4024	.3982	.4001	.3361	.3239	.3881	.3734
Avg	.5019	.4917	.4780	.4708	.4631	.5177	.5173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 201 / 11 KV MASKUTI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7023	.6838	.6722	.6283	.6468	.6653	.6722
2	.6283	.6283	.6535	.5914	.5914	.6283	.6535
3	.6099	.6099	.6348	.5544	.5544	.5544	.6348
4	.6099	.6099	.6224	.5544	.5544	.5544	.6413
5	.6099	.6099	.6224	.5914	.5544	.5544	.6413
6	.6283	.6283	.6036	.6099	.6653	.5729	.679
7	.6099	.6099	.547	.5914	.6468	.6099	.6535
8	.6653	.6283	.5601		.6036	.6283	.6099
9	.6468	.6838	.567	.6283	.6036	.6283	.6219
10	.2587	.6099	.5611	.6099	.5853	.6099	.5729
11	.2172	.6468	.5853	.5914	.5853	.6653	.6283
12	.6024	.6283	.6401	.6283	.6219	.6653	.6468
13	.7343	.6099	.5914	.6283	.6219	.6653	.6838
14	.7059	.6099	.6283	.6099	.6401	.6468	.6283
15	.6626	.5729	.6283	.5914	.6219	.6653	.6653
16	.6626	.5853	.6283	.6468	.6219	.6468	.6838
17	.6697	.6468	.6468	.6219		.6838	.6653
18	.6838	.7059	.6468	.6653	.7392	.7059	.695
19	.8501	.9671	.9877	.961	.9425	.9568	.9231
20	1.0349	1.0208	1.0242	.9425	.9979	.9955	1.0029
21	.9795	.9231	.5853	.924	.961	.9774	.9412
22	.924	.8962	.8869	.8501	.9425	.9328	.9425
23	.7762	.8686	.8413	.8316	.8501	.8871	.8501
24	.7762	.7207	.7762	.7207	.7023	.7392	.7655
Max	1.0349	1.0208	1.0242	.961	.9979	.9955	1.0029
Min	.2172	.5729	.547	.5544	.5544	.5544	.5729
Avg	.6770	.6960	.6725	.6771	.6893	.7016	.7126

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 202 / 11KV GANGAVES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2054	.2054	.2286	.2075	.2054	.2241	.2263
2	.2054	.1867	.2096	.1848	.2054	.2054	.2096
3	.2054	.1867	.1905	.1886	.2054	.1867	.1905
4	.2054	.1867	.1905		.2054	.1867	.1905
5	.2054	.1867	.1905	.2075	.2054	.1867	.1905
6	.2241	.2054	.2096	.2075	.2054	.2054	.2096
7	.2054	.2054	.2096	.2075	.2054	.2054	.2096
8	.2054	.1867	.2096		.1848	.1867	.2075
9	.2241	.2241	.2263	.2263	.2587	.2614	.2427
10	.2987	.2987	.2987	.2801	.2587	.2801	.3174
11	.3696	.3142	.3921	.3174	.3881	.4108	.4108
12	.4066	.3696	.4108	.3361	.4024	.4481	.4668
13	.3881	.3696	.3734	.3174	.439	.4481	.3921
14	.3734	.2957	.4108	.3174	.4207	.4294	.4481
15	.3696	.3511	.3921	.2987	.439	.4294	.4108
16	.3696	.3696	.4066	.3361	.4207	.4481	.4854
17	.3881	.4251	.3921	.3361		.4481	.4668
18	.4668	.4207	.3921	.3734	.5601	.4706	.4805
19	.5415	.5487	.499	.4668	.6161	.567	.5853
20	.5228	.5121	.4805	.4668	.5788	.5487	.5487
21	.4294	.3982	.3841		.4481	.4024	.4251
22	.2987	.3142	.3109	.2801	.3174	.3142	.3361
23	.2614	.2801	.2743	.2801	.2801	.2801	.2987
24	.2427	.2427	.2641	.2452	.2427	.2427	.2452
Max	.5415	.5487	.499	.4668	.6161	.567	.5853
Min	.2054	.1867	.1905	.1848	.1848	.1867	.1905
Avg	.3172	.3035	.3144	.2896	.3345	.3340	.3414



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 203 / 11KV MAHADWAR

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1706	1.1706	1.1389	1.0791	1.134	1.1157	1.1576
2	1.0974	1.0059	1.1203	1.0349	1.0425	1.0791	1.1389
3	1.0242	.9511	1.1016	1.0349	1.0242	1.0242	1.1203
4	1.0242	.9511	1.0829	.9979	1.0242	1.0242	1.1016
5	1.0242	.9694	1.0829	.9979	1.0242	1.0608	1.1016
6	1.1157	.9877	1.1203	1.0719	1.1157	1.1157	1.1203
7	1.0608	.9877	1.1389	.9795	1.0791	1.1523	1.1763
8	1.1706	1.0974	1.1888	1.0719	1.134	1.1523	1.1827
9	1.2254	1.1706	1.2489	1.2071	1.2254	1.2437	1.2437
10	1.4083	1.2986	1.2536	1.2803		1.3535	1.3717
11	1.4998	1.4083	1.4815	1.3169	.4938	1.5364	1.3717
12	1.4661		1.4998	1.4083	1.4632	1.5364	1.6278
13	1.4864	1.5546	1.4266	1.39	1.4632	1.5364	1.6278
14	1.448	1.4632	1.4083	1.2986	1.4632	1.5729	1.5181
15	1.379	1.4083	1.3717	1.2803	1.4632	1.4632	1.4449
16	1.4148	1.4083	1.3717	1.262	1.4998	1.4632	1.4815
17	1.4661	1.4815	1.4815	1.3169		1.4998	1.5181
18	1.6827	1.5927	1.4998	1.4815	2.2361		1.7187
19	2.0452	2.0953	2.1582	2.1582	2.4764	2.2565	2.2028
20	2.1948	2.2028	2.1582	2.1399	2.396	2.2565	2.2565
21	1.9204	1.9909	1.8839	1.829	2.0302	1.9185	1.9342
22	1.6461	1.7013	1.5729	1.5546	1.6827	1.6108	1.6644
23	1.4815	1.4815	1.4083	1.3717	1.4632	1.4998	1.4998
24	1.2986	1.262	1.2936	1.2254	1.2254	1.2437	1.2936
Max	2.1948	2.2028	2.1582	2.1582	2.4764	2.2565	2.2565
Min	1.0242	.9511	1.0829	.9795	.4938	1.0242	1.1016
Avg	1.4063	1.3757	1.3955	1.3245	1.4164	1.4224	1.4531

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 204 / MIRABAG

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1157	1.0425	1.0719	1.0242	.9877	1.0242	1.0534
2	1.0425	1.0242	1.0534	.9877	.9694	.9511	1.0456
3	1.0242	.9511	1.0456	.9511	.9511	.9511	1.0269
4	1.0242	.9511	1.0269	.9511	.9511	.9511	1.0269
5	1.0242	.9511	1.0269	.9877	.9511	.9877	1.0456
6	1.0608	.9877	1.0456	1.0059	1.0608	1.0059	1.0829
7	1.0242	.9694	.9335	.9145	.9511	1.0425	.9979
8	1.0242	.9877	.9328		.9877	1.0791	.9955
9	1.0059	1.0425	.9694	1.0059	.9328	.9694	.9774
10	1.0242	1.1523	1.0136	1.1157	.9877	1.134	1.1157
11	1.1163	1.1157	1.0791	1.0974	1.0425	1.134	1.0791
12	1.0745	1.134	1.1523	1.134		1.134	1.2986
13	1.086	1.0974	1.0791	1.1157	.9877	1.0974	1.134
14	1.0608	1.0974	1.0791	1.0242	.9145	1.0974	1.0974
15	1.0498	1.0974	1.0425	1.0242	.8779	1.134	1.1157
16	1.1104	1.0974	1.0425	1.0791	1.1157	1.1157	1.1523
17	1.1222	1.1157	1.0974	1.0974		1.1157	
18	1.134	1.1222	1.1523	1.1157	1.3717	1.0631	
19	1.4449	1.5223	1.5729	1.5546	1.6095	1.5043	1.8099
20	1.6095	1.5939	1.5729	1.5546	1.6644	1.6278	1.6834
21	1.5912	1.5181	1.5384	1.5364	1.6095	1.5912	1.6289
22	1.39	1.4045	1.3937	1.39	1.4998	1.4998	1.4998
23	1.262	1.3306	1.2308	1.2803	1.3169	1.3306	1.3169
24	1.1888	1.134	1.1827	1.0974	1.1157	1.1157	1.1273
Max	1.6095	1.5939	1.5729	1.5546	1.6644	1.6278	1.8099
Min	1.0059	.9511	.9328	.9145	.8779	.9511	.9774
Avg	1.1504	1.1433	1.1390	1.1324	1.1298	1.1524	1.1960

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 206 / 11 KV SAKOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.439	.4163	.415	.4108	.4024	.4024	.3921
2	.3841	.3841	.3961	.3734	.3658	.3658	.3734
3	.3841	.3841	.3772	.3734	.3658	.3292	.3584
4	.3841	.3841		.3361	.3658	.3292	.3584
5	.3841	.4024	.3961	.3734	.3841	.3475	.3772
6	.4024	.4207	.4338	.3921	.4024	.3841	.4338
7	.4572	.439	.4854	.3881	.439	.4572	.4435
8	.4938	.4755	.4805	.4066	.4755	.4755	.4477
9	.4938	.5121	.4755	.4435	.4938	.4938	.4706
10	.5304	.5121	.4525	.4572		.4755	.4572
11	.4887	.4755	.4755	.4755	.4755	.4938	.4938
12	.5194	.5121	.5121	.4755	.4755	.5121	.5487
13	.4706	.5304	.4938	.4207	.4938	.5121	.5121
14	.4938	.5121	.4755	.439	.4938	.4755	.4938
15	.4938	.4938	.4755	.4755	.4938	.5121	.4755
16	.4706	.5121	.4572	.439	.4938	.4938	.5121
17	.5121	.4938	.4755	.439		.5121	.4938
18	.5487	.5373	.4938	.439	.7133	.4961	.5194
19	.6767	.6201	.6584	.6219	.7316	.6697	.6516
20	.695	.6516	.6584	.6219	.6767	.6697	.6697
21	.6401	.5973	.5792	.567	.6401	.6401	.5973
22	.6036	.5853	.543	.5304	.6036	.6036	.6036
23	.5121	.5359	.543	.4938	.5304	.5544	.5853
24	.4938	.4572	.5041	.4668	.4572	.4572	.4668
Max	.695	.6516	.6584	.6219	.7316	.6697	.6697
Min	.3841	.3841	.3772	.3361	.3658	.3292	.3584
Avg	.4988	.4935	.4894	.4525	.4988	.4859	.4890

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 207 / SHUKRAWAR GATE

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.695	.695	.6908	.6468	.6767	.6767	.6908
2	.6584	.6584	.6722	.5914	.6219	.6036	.6722
3	.6401	.6401	.6535	.5544	.6036	.5853	.6602
4	.6401	.6401	.6602	.5544	.6036	.5853	.7167
5	.6401	.6401	.6602	.5914	.6219	.5853	.679
6	.6584	.6584	.679	.6283	.6767	.6401	.6979
7	.6767	.6767	.6979	.6468	.695	.6767	.7095
8	.7133	.695	.7282		.6584	.7499	.7392
9	.7499	.7682	.7577	.567	.695	.7133	.7499
10	.7316	.7133	.7316	.7133	.6584	.6767	.695
11	.724	.7316	.6767	.695	.6584	.6767	.7499
12	.7783	.7316	.7133	.7316	.695	.7499	.7682
13	.7522	.7133	.7316	.695	.7499	.7682	.7682
14	.724	.6767	.695	.6767	.7316	.7682	.7499
15	.6878	.7316	.6767	.6401	.7316	.7682	.7133
16	.7059	.7316	.7133	.6767	.7499	.7499	.7316
17	.724	.7865	.7316	.7316		.8048	.7682
18	.8413	.8145	.7682	.7682	1.0059	.8328	.8326
19	1.0608	1.0924	1.0791	1.0425	1.0791	1.1517	1.0566
20	1.1523	1.0985	1.0974	1.0425	1.134	1.1283	1.0924
21	1.0791	1.0208	.9955	.9511	1.0974	1.086	1.0924
22	.9877	.9774	.9231	.8962	1.0059	1.0059	1.0242
23	.8596	.8869	.8507	.8596	.8779	.924	.8962
24	.823	.7682	.7762	.7577	.7499	.7499	.8029
Max	1.1523	1.0985	1.0974	1.0425	1.134	1.1517	1.0924
Min	.6401	.6401	.6535	.5544	.6036	.5853	.6602
Avg	.7793	.7728	.7650	.7243	.7729	.7774	.7940

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 144101 / DUDHALI S/S

Feeder No / Name : 208 / 11 KV LAXTIRTH

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5973	.567	.547	.4938	.5068	.543	.5729
2	.5792	.5121	.5281	.4755	.4706	.4887	.5788
3	.5611	.4961	.5093	.439	.4525	.4344	.5601
4	.5611	.5121	.5093	.439	.4525	.4344	.5658
5	.5611	.5121	.5281	.4755	.4706	.4344	.5601
6	.5611	.5138	.5847	.5121	.5611	.4706	.6224
7	.5068	.5304	.5281	.439	.4835	.5068	.5228
8	.5068	.5487	.462	.4755	.5014	.5068	.5359
9	.5373	.4961	.5249	.5487	.4835	.5068	.5068
10	.5552	.5316	.4835	.5304		.543	.543
11	.5548	.543	.5194	.5068	.4477	.0543	.543
12	.5375	.5249	.5552	.5068	.5014	.6089	.5792
13	.583	.543	.5373	.5249	.5194	.6447	.6154
14	.5201	.5249	.5373	.5611	.5373	.6268	.6335
15	.5609	.5611	.5373	.5611	.5373	.6268	.6335
16	.5487	.5611	.5552	.543	.5552	.6089	.5973
17	.5256	.5792	.5552	.5973		.6089	.5611
18	.5792	.5194	.5552	.5552	.6697		.5914
19	.6379	.6556	.7522	.7343	.7783	.7628	.7522
20	.7619	.7602	.7442	.7164	.8326	.815	.8238
21	.7265	.724	.7265	.7164	.7964	.788	.8145
22	.7265	.7133	.691	.6878	.7602	.7783	.7522
23	.6556	.6653	.6268	.6335	.7059	.7316	.6878
24	.6335	.5847	.5975	.543	.5611	.5973	.6283
Max	.7619	.7602	.7522	.7343	.8326	.815	.8238
Min	.5068	.4961	.462	.439	.4477	.0543	.5068
Avg	.5866	.5700	.5706	.5507	.5720	.5705	.6159

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.(W) S/DN.[018] BU 4018

Substation No/ Name :- 146017 / 110/33KV CHAMBUKHADI

Feeder No / Name : 401 / 33KV DUDHALI

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.0109
Max	.0109
Min	.0109
Avg	.0109

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144030 / 33/11KV GPI S/STN

Feeder No / Name : 201 / 11KV TRYAMBOLI

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5175	.5975	.5228	.5975	.5228	.5228	.5228
2	.5228	.5228	.5175	.5228	.4854	.4805	.5175
3	.5228	.5228	.5175	.5228	.4854	.4854	.5175
4	.5228	.5228	.5228	.5228	.4854	.4854	.5228
5	.5228	.5228	.5228	.5228	.5228	.5975	.5228
6	.5975	.5914	.5975	.5175	.5601	.6348	.5601
7	.5228	.5975	.5228	.4481	.5228	.5228	.4481
8	.5175	.5853	.439	.5121	.439	.4481	.439
9	.4435	.5175	.4344	.4344	.4344	.4481	.439
10	.4344	.439	.4252	.4344	.4344	.4298	.4298
11	.4344	.4344	.4344	.4298	.362	.362	.4298
12	.4298	.4344	.4344	.4344		.439	.4344
13	.4344	.4344	.4344	.4298	.567	.4298	.4755
14	.4344	.439	.4344	.4344	.5014	.4298	.439
15	.439	.439	.4298	.4435	.4656	.4344	.4481
16	.4435	.4435	.4344	.4435	.4656	.4344	.4435
17	.4435	.439	.4344	.4344	.4656	.439	.439
18	.4755	.4207	.4525	.4706	.4344	.4252	.5121
19	.6379	.5731	.5792	.6447	.6653	.6379	.6447
20	.788	.6447	.788	.7087	.8048	.7164	.788
21	.724	.6516	.7164	.6447	.724	.6516	.7964
22	.7316	.6584	.7316	.6584	.6767	.6379	.8048
23	.6653	.5914	.6653	.6283	.6219		
24	.5601	.5914	.5228	.5975	.5601	.5359	.5975
Max	.788	.6584	.788	.7087	.8048	.7164	.8048
Min	.4298	.4207	.4252	.4298	.362	.362	.4298
Avg	.5319	.5256	.5214	.5182	.5307	.5056	.5292

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 201 / 11KV Panchganga Ag

FEEDER SEPERATION/PURE AG

Feeder KV- 11 / OUTGOING

DATE	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)
10			.0838	.1143
11			.1174	.1905
12			.1174	.1715
13			.1006	.1715
14			.1174	.1715
15				.1715
16			.1341	.1715
17		.1334		.1457
24	.0762			
Max	.0762	.1334	.1341	.1905
Min	.0762	.1334	.0838	.1143
Avg	.0762	.1334	.1118	.1635



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 202 / Shirol

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1506	1.1431	1.086	1.0669	1.094	1.0479	
2	1.1317	1.105	1.0669	1.0288	1.0751	1.0098	
3	1.0751	1.0669	1.0669	.9907	1.0562	.9526	
4	1.0751	1.086	1.0669	1.0098	1.0374	.9907	
5	1.094	1.1241	1.1241	1.1241	1.0751	1.0288	
6	1.1694	1.2193	1.2384		1.1694	1.1241	
7	1.226	1.2955	1.2193	1.2003	1.226	1.3146	
8	1.358	1.3957	1.3717	1.2955	1.2071	1.3336	
9	1.6194		1.5089	1.4335			1.8099
10	1.8099	1.7528	1.5844	1.6975		1.9052	1.9814
11	1.9243	2.0195	1.8861	1.8861		2.1148	2.0767
12	1.9243	1.9243	1.6787	1.6975		1.9814	2.0957
13	1.7718	1.829	1.6409	1.5655		.0324	1.848
14	1.7147	1.7718	1.6409	1.6409		2.1148	1.829
15	1.7909	1.848	1.7541	1.6598		2.0182	2.1529
16	1.829	1.9433	1.8861	1.8107		2.1313	2.1338
17	1.9616	1.9433	1.6194	1.7541	1.4712		2.1125
18	1.9243	1.829	1.8671	1.7164	1.4098		2.0182
19	1.7337	1.7718	1.6956	1.7541	1.3908		1.8861
20	1.5813	1.6194	1.6004	1.5466	1.3908		1.6787
21	1.4289	1.5242	1.4289	1.358	1.3336		1.5655
22		1.3717	1.3717	1.3203	1.2955		1.4335
23	1.2449	1.2955	1.2193	1.226	1.1622		1.3769
24	1.1694	1.1622	1.1622	1.1431	1.1506	1.0669	
Max	1.9616	2.0195	1.8861	1.8861	1.4712	2.1313	2.1529
Min	1.0751	1.0669	1.0669	.9907	1.0374	.0324	1.3769
Avg	1.5091	1.5235	1.4494	1.4316	1.2216	1.3854	1.8666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 204 / Tarabai Park

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.8107	1.7541	1.7193	1.6448	1.6644	1.7364	
2	1.7375	1.7147	1.6095	1.6385	1.5546	1.6409	
3	1.6461	1.5813	1.4998	1.5623	1.4632	1.5466	
4	1.5364	1.5623	1.4998	1.5051	1.4083	1.5051	
5	1.5546	1.6004	1.5729	1.5242	1.4083	1.6032	
6	1.6827	1.6448	1.701	1.5123	1.5729	1.7187	
7	1.7375	1.5893	1.5364	1.5154	1.5364	1.7372	
8	1.6461	1.6632	1.6278	1.5524	1.701	1.7187	
9	1.7375		1.6461	1.6461			1.7372
10	1.7375	1.701	1.6095	1.6461		1.6827	1.7556
11	1.7193	1.7558		1.6827		1.7375	1.7372
12	1.7741	1.701	1.9753	1.701		1.8473	1.9959
13	1.7558	1.7741	1.7375	1.7558		1.7924	1.922
14	1.8473	1.6644	1.7741	1.6461		1.829	1.922
15	1.829	1.7375	1.8473	1.7558		1.9204	2.0144
16	1.7924	1.7924	1.7741	1.701		1.8473	1.9035
17	1.7372	1.7375	1.8665	1.7193	2.3101		1.8656
18	1.7372	1.8107	1.848	1.7375	2.2361		1.829
19	2.347	2.268	2.2177	2.0119	2.4949		2.3045
20	2.3655	2.4326	2.4025	2.2131	2.4764		2.4874
21	2.3655	2.3594	2.2731	2.1216	2.4949		2.4143
22		2.1582	1.9959	2.1216	2.2916		2.2314
23	2.1437	2.0119	2.0144	2.0668	2.0883		2.1399
24	2.0119	1.8665	1.8473	1.7926	1.8656	1.922	
Max	2.3655	2.4326	2.4025	2.2131	2.4949	1.922	2.4874
Min	1.5364	1.5623	1.4998	1.5051	1.4083	1.5051	1.7372
Avg	1.8371	1.8209	1.8085	1.7406	1.9104	1.7366	2.0173

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 206 / Vikramnagar

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.167	1.1431	1.094		1.0562	1.0288	
2	1.0829	1.086	1.0751	.9907	1.0082	.9907	
3	1.0185	1.0288	1.0185	.9526	.9709	.9526	
4	.9808	.9907	1.0185	.9526	.9522	.9717	
5	.9997	1.0098	1.0374	.9717	.9522	1.0288	
6	1.094	1.0479	1.0751	1.0098	.9896	1.1241	
7	1.1203	1.0479	1.0185	.9526	1.0269	1.086	
8	1.0374	1.1431	.9997	.9335	1.0456	1.0288	
9	.9619		.9522	.9709			.9808
10	.9054	.9997	.9896	.9709		1.0185	.9054
11	.9619	.9242	.9149	.9335		.9431	.9431
12	.9619	.9054	.9709	1.0269		.9619	1.086
13	.9808	.9054	.9149	.9149		.9431	.9808
14	1.0185	.9808	.8215	.9522		.9896	.9907
15	1.0562	1.0185	.9335	.9522		1.0456	1.0562
16	1.094	1.0374	1.0269	.9522		1.0642	1.0751
17	1.0374	1.0185	.9808	.9709	1.2826		.0943
18	1.086	.9997	.9526	.9709	1.2071		1.1203
19	1.3908	1.3957	1.1883	1.251	1.3527		1.363
20	1.4289	1.4335	1.3908	1.3817	1.5051		1.4003
21	1.4289	1.3957	1.3908	1.363	1.467		
22		1.3957	1.3717	1.3256	1.3717		1.419
23	1.3146	1.3203	1.2955	1.2696	1.2955		1.307
24	1.251	1.2003	1.1888	1.1812	1.1576	1.1431	
Max	1.4289	1.4335	1.3908	1.3817	1.5051	1.1431	1.419
Min	.9054	.9054	.8215	.9149	.9522	.9431	.0943
Avg	1.1034	1.1056	1.0675	1.0500	1.1651	1.0200	1.0516

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 207 / Industrial Bapat Camp MYZ      SHEDDABLE FEEDER HAVING WEEKLY  
 Feeder KV- 11 / OUTGOING      STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5847	.5716	.5716	.5335	.5281	.5335	
2	.5658	.5525	.5525	.5335	.5093	.5144	
3	.5525	.5335	.5335	.4954	.4904	.4954	
4	.5335	.5335	.5335	.4954	.4715	.4954	
5	.547	.5525	.5525		.4904	.5144	
6	.6224	.5716	.5716	.5144	.5281	.5525	
7	.5658	.5525	.5335	.4954	.4715	.5335	
8	.547	.5144	.4954	.4954	.4715	.4954	
9	.6287		.6036	.5093			.6859
10	.8002	.7811	.7167	.6224		.7811	.8383
11	.8764	.7621	.7922	.6979		.8954	.8764
12	.8192	.7811	.811	.7167		.8573	.8954
13	.8573		.8299	.7167		.8002	.8954
14	.8383	.743	.7733	.6413		.8764	.8383
15	.8954	.8573	.8299	.7545		.9242	.9717
16	.9335	.9145	.8299	.7733		.9526	.9335
17	.9145	.8002	.8192	.7356	.7621		.9242
18	.7733	.7049	.6859	.6224	.6668		.7922
19	.7621	.8002	.743	.7356	.6668		.7733
20	.7049	.6668	.6859	.6036	.6287		.6602
21	.6478	.6097	.6478	.5847	.6097		
22		.6287	.6287	.5847	.5906		.6224
23	.6287	.6097	.5906	.5658	.5716		.6224
24	.6036	.6097	.5716	.5716	.547	.5716	
Max	.9335	.9145	.8299	.7733	.7621	.9526	.9717
Min	.5335	.5144	.4954	.4954	.4715	.4954	.6224
Avg	.7045	.6660	.6626	.6087	.5628	.6746	.8093

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144092 / 33/11 KV Bapat Camp

Feeder No / Name : 209 / DYP DF EXPRESS FEEDER

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3018	.2858	.2858	.3239	.2829	.3048	
2	.2452	.2286	.2286	.2286	.2452	.2477	
3	.2263	.1905	.2096	.1905	.2094	.2096	
4	.2263	.1905	.2096	.1905	.2075	.2096	
5	.2641	.2096	.2286	.2286	.2263	.2286	
6	.3395	.2477	.2667	.3048	.2263	.3239	
7	.3772	.381	.3239	.362	.3772	.3429	
8	.415	.4382	.362	.362	.3961	.4001	
9			.4904	.5093			.4954
10	.6097	.6097	.5281	.5281		.5906	.4954
11	.8192	.8192	.6602	.6413		.7621	.724
12	.9145	.9145	.8299	.7922		.8764	.8383
13	.9717	.9335	1.0185	.9242		.8573	.8383
14	.9907		1.0185	.9619		.8764	.8192
15	1.0288		1.0562	.9997		.8954	.8954
16	1.0479	1.0098	.9997	1.0562		.8764	.8383
17	.9717	1.0288	.9907	.9808	1.0098		.9431
18	.9717	1.0098	1.0479	.9619	.9526		1.1317
19	1.0669	1.0669	1.105	1.094	.9717		1.6409
20	1.0098	1.0098	1.0288	1.0562	1.0098		1.0562
21	.8002	.8192	.9717	.9808	.8954		.8865
22		.6668	.6859	.7733	.724		.6979
23	.5906	.5335	.6478	.7167	.6287		.6979
24	.4527	.381	.4001	.4001		.381	
Max	1.0669	1.0669	1.105	1.094	1.0098	.8954	1.6409
Min	.2263	.1905	.2096	.1905	.2075	.2096	.4954
Avg	.6655	.6178	.6498	.6487	.5575	.5239	.8666

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 201 / Kay Industry  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.3048	.2858	.2667	.2667	.2667	.3048	.2614
2	.3048	.2858	.2858	.2858	.2858	.3048	.2614
3	.3048	.2858	.2858	.2858	.2858	.2858	.2801
4	.3048	.3048	.3048	.2858	.2858	.2858	.2801
5	.3048	.3048	.2858	.2858	.2858	.2858	.2614
6	.3048	.2858	.2858	.2858	.2858	.3048	.2801
7	.3048	.2858	.2858	.2858	.2858	.3239	.2801
8	.3048	.2858	.2858	.2858	.2858	.2667	.2614
9	.2858	.2858	.2858	.3048	.2858	.2858	.2614
10	.2614		.2858	.3048	.2858	.2858	.2858
11	.2614	.2801	.2858	.3048	.0381	.2858	.3048
12	.2614	.2987	.2858	.3048	.0381	.2667	.2667
13	.2614	.2987	.2667	.2858	.0381	.2667	.2667
14	.2801	.2801	.2667	.2667	.0381	.3048	.2858
15	.2987	.2614	.2667	.2667	.0381	.3048	.2858
16	.2987	.2614	.2667	.2667	.0381	.3048	.2667
17	.2667	.0572	.2667	.3048	.0373	.3048	.2667
18	.0572	.0572	.2667	.0572	.0373	.3048	.2667
19	.0572	.0572	.2667	.0572	.0373	.0381	.0381
20	.0572	.0572	.0572	.0572	.0373	.0381	.0381
21	.0572	.0572	.0572	.0572	.0373	.0381	.0381
22	.0572	.0572	.0572	.0572	.2987	.0381	.0381
23	.2477	.0572	.0572	.0572	.3048	.2614	.2614
24	.2667	.2858	.0572	.0572	.0572	.2858	.2614
Max	.3048	.3048	.3048	.3048	.3048	.3239	.3048
Min	.0572	.0572	.0572	.0572	.0373	.0381	.0381
Avg	.2381	.2164	.2326	.2199	.1631	.2490	.2333

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 202 / Sakal Press DBlock Shirol  
 Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
 STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0098	1.105	1.2003	1.2955	1.105	1.2574	.9709
2	1.0098	1.1812	1.2955		1.0098	1.2955	1.0082
3	1.0098	.9717	1.086	1.0098	1.0669	1.2384	.9896
4	1.0098	.8383	.8573	.8192	.8764	.9145	.9335
5	1.0098	.7811	.8192	.8002	.8573	.8573	.8962
6	1.0098	.8573	.8192	.8192	.8764	.8573	.8775
7	.8002	.8954	.7811		.8764	.8764	.8775
8	.9717	.8764	.8954	.4954	.8764	.8002	.8589
9	.9526	.7811	.8954	.5144	.7049	.7811	.8402
10	.8402		.7621	.4382	.724	.7621	.9526
11	.7468	.8962	.7621	.4763	.724	.8573	1.0098
12	.7468	.8962	.7621	.4763	.724	.8383	.9335
13	.7655	.8215	.7621	.5716	.7811	.9335	.8192
14	.8962	.8029	.8002	.5716	.7621	.9717	.7621
15	.9335	1.0456	.8383	.6668	.7049	1.1622	.9145
16	.8962	.8402	.8383	.6478	.7049	.8002	.8954
17	.9717	.8954	.8192	.7049	.7842	.8192	.8573
18	.8573	.8192	.8192	.6668	.8402	.8383	.8573
19	.9335	.8192	.743	.7621	.7468	.8383	.8383
20	.8192	.8002	.7049	.6478	.7282	.8383	.8383
21	.7811	.8192	.7049	.6859	.7655	.7811	.8573
22	.7811	.8002	.724	.8764	.8029	.7621	.8573
23	.8383	.724	.8573	.9335	.8573	.7842	.8962
24	1.0098	1.0288	1.086	.9145	1.0288	.9145	.8962
Max	1.0098	1.1812	1.2955	1.2955	1.105	1.2955	1.0098
Min	.7468	.724	.7049	.4382	.7049	.7621	.7621
Avg	.9000	.8824	.8597	.7179	.8304	.9075	.8932

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 203 / Menon Metallics  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6668	.7049	.7811	.724	.724	.4572	.4481
2	.6668	.6859	.7621	.724	.6668	.4763	.4668
3	.6668	.724	.743	.7049	.6859	.4382	.4854
4	.6668	.6859	.7621	.7049	.5716	.4382	.5041
5	.6668	.6668	.7621	.6859	.381	.4191	.5228
6		.6859	.743	.6859	.381	.4001	.5415
7	.743	.743	.6859	.6859	.6668	.4191	.6348
8	.743	.5525	.724	.7049	.362	.5525	.5975
9	.743	.8002	.5716	.5144	.362	.724	.5228
10	.8962		.724	.6097	.362	.8764	.5716
11	.9149	.8029	.7621	.8954	.362	.8383	.8573
12	.8402	.6535	.7621	.7621	.3429	1.1622	.8954
13	.7842	.5601	.7621	.5716	.3429	1.1431	.6668
14	.8962	.8029	.8764	.5716	.3429	.6097	.6287
15	.8775	.8589	.9526	.8573	.381	1.2765	.8954
16	.8215	1.9791	.9526	.8192	.3429	.5144	1.1241
17	.8002	.8192	.8192	1.0098	.3547	.6097	.7621
18	.7049	.743	.6859	.743	.4108	.6097	.7621
19	.743	.724	.6668	.7049	.4108	.6097	.724
20	.743	.6287	.6668	.6668	.3921	.6097	.724
21	.7621	.5144	.6287	.6668	.4108	.4572	.7049
22	.743	.8192	.4954	.7811	.4294	.4572	.6668
23	.7049	.8002	.5906	.743	.4382	.4481	.6535
24	.6668	.724	.743	.7049	.6859	.4382	.4668
Max	.9149	1.9791	.9526	1.0098	.724	1.2765	1.1241
Min	.6668	.5144	.4954	.5144	.3429	.4001	.4481
Avg	.7592	.7687	.7343	.7184	.4504	.6244	.6595



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 204 / Budhale

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9907	1.2003	1.0288	1.0479	.9145	.9526	1.1203
2	.9907	1.1622	.9717	1.0479	.9335	.9335	1.0829
3	.9907	1.0479	.9907	1.0098	.9145	.8954	1.0642
4	.9907	.8764	.9526		.9335	.8954	1.0269
5	.9907	.8764	.9145	1.0479	.9335	.8764	.9335
6	.7811	.8954	.8954	1.2003	.9526	.8954	.9335
7	.9145	.9145	.9145	1.0098	1.1431	.9526	.8775
8	1.105	.9526	.8573	.9526	.9145	.9526	1.4003
9	1.105	1.4861	1.3146	1.4098	.9145	1.1431	1.475
10	1.643		1.5242	1.5242	.8383	1.0479	1.2003
11	1.7737	1.7177	1.5242	1.6194	.8383	1.9814	1.6956
12	1.587	1.4563	1.5813	1.6194	.8383	1.9624	1.6385
13	1.307	1.2323	1.5813	1.5813	.8383	1.7337	1.2955
14	1.6057	1.8111	1.7147	1.5813	.8383	1.6194	1.6766
15	1.643	1.9418	1.7528	1.9052	.8383	1.3527	1.2765
16	1.363	1.9791	1.7337	1.8099	.8383	1.5051	1.7718
17	1.3717	1.7528	1.6194	1.6575	.8775	1.4861	1.7718
18	1.6385	1.7718	1.086	1.0669	.8962	1.4861	1.7718
19	1.4861	1.5432	.9717	1.086	.8775	1.4861	1.7147
20	1.2003	1.2955	.9145	.9335	.8589	1.2955	.9907
21	.9526	.9526	1.0288	.9145	.8589	1.2955	.9717
22	.9335	1.2765	1.1812	.9335	.8589	1.1812	.9907
23	1.1622	1.3527	1.105	.9335	.8954	1.1389	.9709
24	.9717	1.2574	.9526	1.0669	.9145	.9145	1.1203
Max	1.7737	1.9791	1.7528	1.9052	1.1431	1.9814	1.7718
Min	.7811	.8764	.8573	.9145	.8383	.8764	.8775
Avg	1.2291	1.3371	1.2130	1.2591	.8942	1.2493	1.2821

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 205 / Chintamani  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6097	.6478	.6859	.5906	.6478	.5144	.5041
2	.6097	.6668	.6478	.5716	.6097	.5144	.4854
3	.6097	.6097	.6287	.5716	.6097	.4954	.4668
4	.6097	.6668	.6097		.5144	.4763	.4481
5	.6097	.6668	.7621	.5525	.4954	.4763	.5601
6	.6097	.5525	.5716	.5335	.5144	.5144	.5975
7	.6859	.743	.724	.5906	.5335	.5716	.6535
8	.7049	.7811	.7049	.6859	.5144	.6097	.7468
9	.724	.8764	.8002	.743	.4763	.6859	.8029
10	1.0829		.8573	.8573	.4763	.8002	1.2574
11	1.307	1.1576	.8764	1.2193	.4763	1.105	1.1241
12	1.2136	1.0829	.8764	1.2193	.4382	1.0669	1.2193
13	.9149	.8775	.8764	1.1812	.4382	1.1622	.8573
14	1.6244	1.0269	1.2384	1.1431	.4382	1.5623	1.3336
15	1.643	1.1763	1.3527	1.2955	.5144	1.0098	1.448
16	1.5497	.9149	1.7337	1.1812	.5144	1.4861	1.7718
17	1.0479	1.2003	1.2384	.9526	.5041	1.1431	1.5242
18	1.7337	1.1812	1.2003	1.2384	.5041	1.1431	1.3717
19	1.3336	1.4861	1.0288	1.1812	.4854	1.1431	1.3336
20	.9335	1.3908	.7049	.6859	.4854	.743	.4954
21	.6097	.5906	.6478	.6478	.5041	.4954	.5335
22	.5716	.6287	.6287	.6097	.5041	.5144	.5335
23	.8002	.6859	.6097	.7621	.5144	.5041	.5228
24	.6097	.6287	.6287	.5906	.6478	.5144	.5228
Max	1.7337	1.4861	1.7337	1.2955	.6478	1.5623	1.7718
Min	.5716	.5525	.5716	.5335	.4382	.4763	.4481
Avg	.9479	.8800	.8597	.8524	.5150	.8021	.8798

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 206 / Gainmax

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.1431	1.105	1.0479	1.0288	.6097	1.0288	.9522
2	1.1431	1.086	1.105	1.0098	.6287	1.0479	.9709
3	1.1431	1.0479	1.0669	.9717	.6097	1.0098	.9896
4	1.1431	.8573	1.0288		.6287	1.0288	1.0269
5	1.1431	1.0098	.724	1.0669	.6287	1.0288	1.1389
6	1.1431	1.105	1.4861	1.0288	.6287	1.0098	1.2136
7	1.4289	1.105	1.2765	1.105	.6097	.9907	1.4563
8	1.0098	.8002	1.5051	1.2193	.6097	1.0479	1.4377
9	1.0098	1.2384	1.086	1.6194	.5716	1.1812	1.587
10	1.7177		1.1431	1.5623	.5716	1.7528	1.6956
11	1.8671	1.3443	1.2003	1.0669	.5716	1.6575	1.3527
12	1.6617	1.2136	1.2003	1.3336	.5525	1.7528	.7811
13	1.4003	.9896	1.2003	1.5242	.5525	1.6575	1.2574
14	1.587	1.0829		1.6194	.5716	1.7337	1.7528
15	1.6991	1.1576	1.6575	1.6575	.5716	1.7337	1.7528
16	1.0269	.7095	1.6194	1.6194	.5716	1.0479	
17	1.6575	1.105	1.3908	.9145	.5788	1.3336	1.6194
18	1.6385	1.5051	1.1622	.5906	.5975	1.3146	1.5242
19	1.1241	1.3336	1.1241	.5906	.6859	1.3146	1.3336
20	1.086	1.3717	1.0669	.6097	.8215	.6668	.6859
21	1.0669	1.4861	1.086	.6097	.8402	1.0669	1.0479
22	1.105	.7811	1.1622	.5906	.8589	1.0288	1.0669
23	1.1241	1.467	1.086	.6097	.8764	1.0269	1.0269
24	1.0288	.7811	1.5432	.9907	.6097	.9145	1.0082
Max	1.8671	1.5051	1.6575	1.6575	.8764	1.7528	1.7528
Min	1.0098	.7095	.724	.5906	.5525	.6668	.6859
Avg	1.2957	1.1166	1.2160	1.0843	.6399	1.2240	1.2469

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144093 / 33/11 D Block

Feeder No / Name : 411 / 33 KV I/C DBLOCK

Feeder KV- 33 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	4.7439	5.0297	5.0297	4.9154	4.2867	4.5153	4.257
2	4.7439	5.0869	5.0869	4.9154	4.1152	4.5725	4.257
3	4.7439	4.6868	4.8011	4.5725	4.1724	4.3439	4.257
4	4.7439	4.2295	4.5153	1.829	3.8295	4.0581	4.201
5	4.7439	4.2867	4.2867	4.4582	3.6008	3.9438	4.313
6	4.5725	4.401	4.8011	4.5725	3.658	4.0009	4.425
7	4.8011	4.6868	4.6868	3.658	4.1152	4.1152	4.7611
8	4.8583	4.2295	4.9726	4.3439	3.5437		5.2652
9	4.8011	5.487	4.9726	5.0869	3.315	4.8011	5.4893
10	6.4415		5.3155	5.3155	3.2579	5.5441	5.9442
11	6.8336	6.1614	5.4298	5.5441	3.0293	6.7444	6.3443
12	6.2734	5.6013	5.487	5.7156	2.915	7.0302	5.7156
13	5.4332	4.7611	5.4298	5.7156	2.9721	6.9159	5.144
14	6.8896	5.7693	6.4015	5.7728	3.0293	6.8016	6.4586
15	7.0576	6.1614	6.8016	6.6301	3.0293	6.8587	6.5729
16	5.9374	5.4893	6.7444	6.3443	3.0293	5.6584	7.5446
17	6.1157	5.8299	6.1728	5.5441	3.1367	5.7156	6.8016
18	6.6301	6.0585	5.2012	4.3439	3.2487	5.7156	6.5729
19	7.4303	5.9442	4.8011	4.401	3.3048	5.4298	6.0014
20	4.8583	5.5441	4.1152	3.6008	3.3048	4.1724	3.7723
21	4.2295	4.401	4.1724	3.6008	3.4168	4.1152	4.1724
22	4.1724	4.3439	4.2295	3.8295	3.7529	4.0009	4.1724
23	4.8583	5.0869	4.2867	4.0581	3.8866	4.145	4.313
24	4.5725	4.6868	5.0297	4.3439	3.9438	4.0009	4.257
Max	7.4303	6.1614	6.8016	6.6301	4.2867	7.0302	7.5446
Min	4.1724	4.2295	4.1152	1.829	2.915	3.9438	3.7723
Avg	5.4369	5.1288	5.1155	4.7130	3.4956	5.0956	5.2089

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 204 / INDIRA

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.6722		.5975	.5601	.5975	.7282	.6161
2	.5975		.5228	.5228	.5601	.5788	.5601
3	.5601		.4668		.5228	.5788	.5041
4	.4854		.4668	.4481	.4668	.5975	.5041
5	.4481		.4668	.4481	.4668	.5788	.5228
6	.4854		.4854	.4481	.4854	.5601	.5228
7	.5601		.5041	.4668	.5601	.5601	.5415
8	.6161		.5601	.5601	.5601	.5601	.5415
9	.5975	.5975	.5415	.5788		.5788	.5415
10	.6722	.6348	.6535	.6173		.6908	.7468
11	.8215	.8215	.8215	.7282		.8589	.8775
12	.8962	.9335	.9709	.703		1.0829	.9335
13	.9522	.8962	.9335	.7842		1.0829	.9709
14	.8962	.9149	.8962	.7468		.9896	.9709
15	.8962	.9149	.8775	.6535		1.0082	.9522
16	.8962	.9335	.9709	.6722		1.0082	1.0082
17	.8962	.8962	.8775	.6348		.9709	.9335
18	.9709	.8962	.8589	.6535		.9335	.9709
19	1.0456		.9335	.7095		1.0269	1.0456
20	1.0456		.9896	.6908		1.0082	1.0456
21	.961		.8775	.6535		.9335	
22	.7095	.7095	.7095	.6722		.6908	.7842
23	.7023	.6348	.6161	.6722		.6722	.7468
24	.7282		.6348		.6535	.7282	.6348
Max	1.0456	.9335	.9896	.7842	.6535	1.0829	1.0456
Min	.4481	.5975	.4668	.4481	.4668	.5601	.5041
Avg	.7547	.8153	.7181	.6193	.5415	.7920	.7598

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 205 / GANESH TAIKIES

SHEDDABLE URBAN

Feeder KV- 11 / OUTGOING

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.0164		.924	.8871	.924	.9795	.9425
2	.961		.8316	.8316	.8871	.8916	.8871
3	.8871		.7947	.7762	.8131	.961	.8316
4	.8316		.7392	.7762	.5601	.961	.8316
5	.8316		.7762	.7392	.7392	.9896	.8501
6	.8871		.8501	.7392	.7392	.9979	.8871
7	.924		.961	.7577	.924	1.0164	.924
8	.961		.924	.8871	.961	.924	.924
9	1.0164	.9979	.924	.8871		.924	.924
10	1.1088	.961	1.0349	1.0164		.9979	1.0349
11	1.2567	1.1827	1.2012	1.1643		1.2197	1.2752
12	1.3676	1.3306	1.2936	1.1827		1.2936	1.4784
13	1.386	1.386	1.2936	1.1458		1.386	1.4784
14	1.3306	1.3306	1.2936	1.1458		1.3306	1.4784
15	1.3676	1.2936	1.2936	1.1088		1.3306	1.386
16	1.4415	1.2936	1.2936	1.0903		1.2936	1.4045
17	1.4415	1.2936	1.2936	1.0719		1.386	1.3306
18	1.4784	1.3491	1.3121	1.0719		1.423	1.386
19	1.5708		1.4969	1.1088		1.6632	1.6078
20	1.4784	1.4784	1.5154	1.1088		1.6632	1.5708
21	1.3306	1.2936	1.4045	1.1088		1.46	1.386
22	1.1088	1.0719	.9979	.961		1.1088	1.1088
23	1.1088	1.0719	.961	.961		1.0719	1.1088
24	1.0719		1.0164	.924	.961	1.2567	.9979
Max	1.5708	1.4784	1.5154	1.1827	.961	1.6632	1.6078
Min	.8316	.961	.7392	.7392	.5601	.8916	.8316
Avg	1.1735	1.2382	1.1011	.9772	.8343	1.1887	1.1681

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 206 / 11 KV Industrial

GANDHINAGAR Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.1524		.1715	.1905	.0953	.0762	.1905
2	.1524		.1524	.1715	.0953	.0381	.1905
3	.1524		.1524	.1715	.0953	.0381	
4	.1524		.1524	.1524	.0953	.0381	.1715
5	.1524		.1715	.1715	.0953	.0381	.1715
6	.1524		.1905	.1715	.1143	.0381	.1905
7	.1715		.2286	.1905	.1143	.0381	.1905
8	.1524		.1905	.1715	.0762	.1143	.2286
9	.2477	.2477	.2477	.2477		.1905	.1905
10	.3239	.3239	.2667	.2858		.2667	.4191
11	.3429	.3239	.2858	.3239		.381	.4191
12	.362	.3429	.381	.3239		.4763	.381
13	.381	.362	.3048	.2667		.4382	.381
14	.362	.2667	.3429	.2858		.381	.381
15	.381	.3239	.3429	.3048		.381	.4191
16	.3429	.3048	.3429	.2667		.4191	.3239
17	.381	.3048	.3429	.2667		.3429	.3239
18	.3239	.3429	.3048	.2858		.2858	.3429
19	.3239		.3239	.2477		.381	.3429
20	.2858	1.0269	.3048	.2667		.3239	.381
21	.2286	.8962	.2477	.1715		.2858	.2858
22	.1715	.2858	.1334	.1334		.2286	.2667
23	.1715	.1524	.1715	.1143		.2286	.2667
24	.1524		.1905	.1905	.0953	.0762	.2096
Max	.381	1.0269	.381	.3239	.1143	.4763	.4191
Min	.1524	.1524	.1334	.1143	.0762	.0381	.1715
Avg	.2508	.3932	.2477	.2239	.0974	.2294	.2899

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144103 / 33/11 Kv Gandhinagar

Feeder No / Name : 401 / 33KV Gandhinagar I/C  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.4646		2.8235	2.8006	2.1845	3.1367	2.2965
2	2.2405		2.6606	2.7161	2.0725	2.9127	2.2634
3	2.0936		2.5789	2.6029	1.8673	1.8004	2.0936
4	1.9805		2.5252	2.6326	1.8107	2.1285	2.0936
5	1.9239		2.5789	2.6886	1.6975	2.0725	2.0936
6	2.0936		2.7938	2.8006	1.9239	2.1285	2.1845
7	2.32		3.1161	2.9424	2.2068	2.2405	2.2405
8	2.3525		3.1699	3.1367	2.5463	2.1845	2.2965
9	2.4646	3.3048	3.0624	3.095		2.2405	2.1845
10	2.6326	2.4646	2.4394	2.5206		3.3665	3.9769
11	3.0247	2.9687	2.9687	2.7435		4.561	4.481
12	4.4056	3.1927	3.2487	2.7984		4.9411	4.6491
13	4.5668	3.1927	3.1367	2.6337		4.9429	4.5268
14	4.3519	3.0807	3.1367	2.7435		4.7279	4.9291
15	4.4056	3.1367	3.1367	2.6337		4.561	.8402
16	4.4056	3.1927	3.2487	2.5789		4.6696	4.7611
17	4.4593	3.0807	3.0807	2.5766		4.7239	3.8958
18	4.8171	3.2487	3.0247	2.6886		3.3608	3.3608
19	4.7051		3.5288	2.8567		3.9209	3.8089
20	3.4928	3.4728	3.5848	2.8006		3.8649	3.8089
21	3.4374	3.0807	3.2487	2.6326		3.4728	3.3608
22	2.7166	2.5766	2.5463	2.4646		2.7446	2.9127
23	2.6886	2.5206	2.4086	2.4086		2.6326	2.8006
24	2.4086		2.9864	2.9687	2.2965	3.4168	2.4646
Max	4.8171	3.4728	3.5848	3.1367	2.5463	4.9429	4.9291
Min	1.9239	2.4646	2.4086	2.4086	1.6975	1.8004	.8402
Avg	3.1855	3.0367	2.9597	2.7277	2.0673	3.3647	3.0968



**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 201 / 11KV SARALASHKAR  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7621	.8573	.8573	.7621	.6668	.5716	.7621
2	.7621	.7621	.7621	.7621	.6668	.6668	.8573
3	.7621	.7621	.7621	.7621	.5716	.7621	.8573
4	.7621	.7621	.7621	.8573	.5716	.7621	
5	.8573	.7621	.7621	.8573	.6668	.7621	.7621
6	.7621	.7621	.7621	.8573	.6668	.7621	.7621
7	.8573	.8573	.8573	.8573	.6668	.7621	.7621
8	.9526	1.1431	1.2384	1.1431	.6668	.8573	.7621
9	1.1431	1.3336	1.2384	1.3336		1.1431	1.3336
10	1.4289	1.3336	1.7147	1.4289	.5716	1.5242	1.5242
11	1.8099	1.3336	1.7147	1.6194	.6668	1.7147	1.5242
12	1.7147	1.3336	1.6194	1.4289	.6668	1.6194	1.6194
13	1.5242	1.5242	1.1431	1.4289	.6668	1.6194	1.2384
14	1.6194	1.8099	1.5242		.6668	1.6194	1.7147
15	1.6194	1.4289	1.7147		.6668	1.3336	1.7147
16	1.5242	1.4289	1.6194	1.0479	.6668	1.0479	1.3336
17	1.1431		1.3336	1.1431	.6668	1.3336	1.1431
18	1.3336	1.4289		1.1431	.6668		1.3336
19		1.3336		1.0479	.6668		1.3336
20	1.3336	1.3336		.8573			1.3336
21	1.0479	1.1431		.7621	.6668		1.1431
22	.9526	.8573		.7621	.5716		.9526
23	.9526	1.0479		.6668	.6668		.7621
24	.7621	.8573	.9526	.7621	.6668	.6668	.7621
Max	1.8099	1.8099	1.7147	1.6194	.6668	1.7147	1.7147
Min	.7621	.7621	.7621	.6668	.5716	.5716	.7621
Avg	1.1473	1.1390	1.1855	1.0132	.6495	1.0849	1.1431

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 202 / 11 KV MAULI FEEDER MIDC SHEDDABLE FEEDER HAVING WEEKLY  
 Shirol Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.9526	.9526	.8573	.8573	.7621	.7621	.8573
2	.8573	.8573	.8573	.7621	.7621	.7621	.8573
3	.7621	.7621	.7621	.8573	.7621	.8573	.8573
4	.7621	.7621	.8573	.7621	.7621	.8573	.8573
5	.8573	.7621	.8573	.7621	.7621	.8573	.7621
6	.8573	.7621	.8573	.8573	.8573	.8573	.8573
7	.8573	.8573	.8573	.8573	.8573	.7621	.8573
8	.8573	.7621	.8573	.8573	.7621	.8573	.9526
9	1.1431	.8573	.9526	.9526		.9526	1.1431
10	1.2384	.8573	.9526	.9526	.7621	1.1431	1.2384
11	1.1431	.9526	1.0479	1.0479	.8573	1.2384	1.1431
12	1.2384	.9526	.9526		.7621	1.0479	1.1431
13	.9526	.9526	.9526	.9526	.7621	1.1431	.9526
14	1.1431	1.1431	.9526	.8573	.8573	1.2384	1.1431
15	1.2384	1.1431	.8573		.8573	1.2384	1.1431
16	1.0479	1.0479	.9526	.8573	.9526	1.1431	.9526
17	.9526		.9526	.8573	.8573	1.0479	.9526
18	.8573	.9526		.7621	.8573		.9526
19	.9526			.7621	.8573		.9526
20	.7621	.8573		.7621			.9526
21	.8573	.7621		.7621	.8573		.8573
22	.8573	.7621		.8573	.8573		.8573
23	.8573	.6668		.7621	.8573		.8573
24	.9526	.8573	.8573	.8573	.7621	.8573	.8573
Max	1.2384	1.1431	1.0479	1.0479	.9526	1.2384	1.2384
Min	.7621	.6668	.7621	.7621	.7621	.7621	.7621
Avg	.9566	.8747	.8997	.8443	.8184	.9791	.9566

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 203 / G' BLOCK

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.4289	1.4289	1.4289	1.4289	1.3336	1.3336	1.4289
2	1.4289	1.4289	1.5242	1.3336	1.2384	1.4289	1.5242
3	1.6194	1.6194	1.5242	1.4289	1.2384	1.3336	1.4289
4	1.5242	1.5242	1.4289	1.3336	1.3336	1.3336	1.4289
5	1.5242	1.5242	1.3336	1.3336	1.3336	1.3336	1.3336
6	1.4289	1.5242	1.4289	1.4289	1.3336	1.4289	1.3336
7	1.6194		1.4289	1.4289	1.3336	1.5242	1.4289
8	1.6194	1.7147	1.5242	1.4289	1.3336	1.5242	1.6194
9	2.2862	2.2862	2.0005	1.6194		2.191	1.8099
10	2.6673	2.2862	2.0005	1.8099	1.2384	1.9052	2.3815
11	2.572	2.0957	2.2862	2.191	1.1431	2.3815	2.3815
12	2.572	2.191	1.7147	1.8099	1.1431	2.0957	2.2862
13	2.191	2.0005	1.7147	1.6194	1.0479	2.4768	1.9052
14	2.2862	2.4768	2.0005		1.0479	2.3815	2.6673
15	2.2862	1.6194	2.0957		1.1431	2.2862	2.572
16	2.572	2.4768	1.9052	2.0005	1.3336	2.2862	2.2862
17	2.191		1.9052	1.7147	1.3336	1.8099	1.6194
18	2.0005	2.0957		1.4289	1.3336		1.5242
19	1.7147	1.9052		1.3336	1.3336		1.5242
20		1.6194		1.3336			1.5242
21	1.3336	1.4289		1.4289	1.3336		1.5242
22	1.3336	1.4289		1.4289	1.3336		1.5242
23	1.3336	1.4289		1.3336	1.3336		1.3336
24	1.3336	1.3336	1.3336	1.3336	1.3336	1.3336	1.3336
Max	2.6673	2.4768	2.2862	2.191	1.3336	2.4768	2.6673
Min	1.3336	1.3336	1.3336	1.3336	1.0479	1.3336	1.3336
Avg	1.8638	1.7926	1.6988	1.5241	1.2687	1.7993	1.7385

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 204 / 11 KV Maharashtra Feeder  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.8573	.8573	.7621	.8573	.5716	.6668	.7621
2	.8573	.8573	.7621	.8573	.5716	.7621	.7621
3	.8573	.8573	.8573	.7621	.5716	.7621	.7621
4	.7621	.7621	.8573	.6668	.5716	.7621	.7621
5	.7621	.7621	.7621	.6668	.5716	.7621	.8573
6	.8573	.8573	.8573	.7621	.5716	.7621	.7621
7	.9526	.7621	.8573	.6668	.6668	.8573	.8573
8	.9526	.8573	.8573	.6668	.5716	.8573	.8573
9	.9526	.9526	.9526	.7621		.9526	.8573
10	.9526	.9526	.9526	.6668	.4763	.9526	.9526
11	.8573	1.0479	1.0479	.8573	.4763	.8573	.9526
12	.8573	1.0479	1.0479	.8573	.381	1.0479	.9526
13	.8573	.9526	.7621	.6668	.381	1.0479	.9526
14	.9526	1.0479	.7621		.381	1.0479	1.0479
15	1.0479	.7621	.9526		.381	1.0479	1.0479
16	1.0479	.9526	.9526	.7621	.381	1.0479	.9526
17	.8573		.9526	.6668		.9526	.9526
18	.7621	.9526		.5716			.9526
19	.8573	.8573		.5716	.4763		.9526
20	.6668	.9526		.5716	.5716		.9526
21	.8573	.7621		.5716	.6668		.9526
22	.7621	.7621		.5716	.6668		.9526
23	.7621	.7621		.5716	.6668		.7621
24	.7621	.7621	.7621	.8573	.5716	.6668	.7621
Max	1.0479	1.0479	1.0479	.8573	.6668	1.0479	1.0479
Min	.6668	.7621	.7621	.5716	.381	.6668	.7621
Avg	.8613	.8739	.8732	.7015	.5307	.8785	.8891

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 206 / DEVAJI

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1		1.5242	1.6194	1.5242	1.0479	.8573	1.4289
2		1.5242	1.5242	1.6194	1.0479	.8573	1.4289
3		1.3336	1.5242	1.6194	.9526	.9526	1.4289
4		1.3336	1.6194	1.5242	.9526	.9526	1.5242
5		1.5242	1.5242	1.7147	.9526	.9526	1.5242
6		1.7147	1.4289	1.9052	1.0479	.9526	1.4289
7		1.5242	.8573	2.0005	1.0479	.9526	1.5242
8		.8573	1.3336		.5716	.9526	1.1431
9	1.9052	2.2862	2.8578	2.2862		2.4768	1.7147
10	2.0957	2.0957	2.4768	2.8578	.5716	2.0957	2.0957
11	3.1436	2.2862	2.4768	2.3815	.5716	2.2862	2.191
12	2.191	2.4768	2.0005	1.9052	.5716	2.0957	2.0957
13	2.7625	1.5242	2.2862	2.0957	.5716	2.191	1.8099
14	2.2862	2.8578	2.4768		.5716	2.6673	.1905
15	2.3815	2.572	2.7625		.5716	2.6673	1.8099
16	1.8099	1.5242	2.3815	2.0005	.5716		1.7147
17	2.7625		2.191	1.2384	.5716	2.191	1.3336
18	2.2862	2.2862		.8573	.5716		1.2384
19	2.2862	2.2862		.8573	.5716		1.3336
20	1.9052	.8573		.8573			1.5242
21	.8573	1.0479		.9526	.6668		1.7147
22	1.7147	1.4289		1.1431	.6668		1.7147
23	1.7147	1.4289		.9526	.5716		1.3336
24		1.7147	1.5242	1.6194	.9526	.5716	1.4289
Max	3.1436	2.8578	2.8578	2.8578	1.0479	2.6673	2.191
Min	.8573	.8573	.8573	.8573	.5716	.5716	.1905
Avg	2.1402	1.7395	1.9370	1.6149	.7361	1.5690	1.5281

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144105 / 33 KV MIDC

Feeder No / Name : 401 / 33KV MIDC SHIROLI INCOMER NON SHEDDABLE EXPRESS HV FEEDERS

Feeder KV- 33 / INCOMING (NON-CONTINUOUS PROCESS)(NO STAGGERING)

DATE	29-MAR-18	30-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	5.5441	5.6013	5.5441	5.4298	4.401	4.1724	5.2584
2	5.144	5.4298	5.4298	5.3155	4.2867	4.4582	5.4298
3	5.2584	5.3155	5.4298	5.4298	4.1152	4.6868	5.3155
4	5.144	5.144	5.5441	5.144	4.1724	4.6868	5.3155
5	5.3155	5.3155	5.2584	5.3155	4.2867	4.6868	5.2584
6	5.144	5.6013	5.3155	5.8299	4.4582	4.7439	5.144
7	5.5441	4.0009	4.8583	5.8299	4.5725	4.8583	5.4298
8	6.0014	5.3155	5.8299	5.8871	3.8866	5.0297	5.3155
9	7.4303	7.7161	8.0018	6.973		7.7161	6.8587
10	8.4019	7.5446	8.1162	7.7161	3.6008	7.6017	8.1733
11	9.5451	7.7161	8.5734	8.1162	3.7151	8.4591	8.1733
12	8.1733	8.0018	7.316	6.973	3.5437	7.8875	8.1162
13	8.2876	6.973	6.8587	6.6873	3.4294	8.4591	6.8587
14	8.2876	9.3164	7.7161		3.5437	8.9735	6.7444
15	8.5734	7.5446	8.4019		3.6008	8.5734	8.2876
16	8.0018	7.4303	7.8304	6.6873	3.8866	8.1733	7.2588
17	7.8875		7.316	5.6013		7.316	6.0014
18	7.2588	7.7161		4.7439			6.0014
19	5.8299	7.2588		4.5725			6.1157
20	4.6868	5.6013		4.401			6.2872
21	4.9726	5.144		4.4582	4.1724		6.1728
22	5.6013	5.2584		4.7439			6.0014
23	5.6013	5.3155	5.4298	4.2867			10.0594
24	5.5441	5.5441	5.4298	7.4497	4.2867	4.1152	5.144
Max	9.5451	9.3164	8.5734	8.1162	4.5725	8.9735	10.0594
Min	4.6868	4.0009	4.8583	4.2867	3.4294	4.1152	5.144
Avg	6.5491	6.3393	6.5368	5.7996	3.9976	6.3665	6.4467

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 201 / 11KV TOUGH CASTING

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.5335	.5906		.5906	.5716	.5716
2	.4191	.5525		.5716	.5525	.5716
3	.4572	.4763		.5716	.5525	.4763
4	.5144	.5716		.5716	.5335	.5144
5	.5716	.5906		.5716	.5716	.5906
6	.5716	.5906		.5716	.5525	.5525
7	.5525	.6097		.5525	.5335	.6097
8	.5144	.5525		.5525	.5144	.5144
9	.7811	.4572		.5716	.6478	.6668
10	.6668	.9717		.5906	.9907	.8764
11	.6478	.9907		.5716	.8383	.9717
12	.6287	.8764		.5906	.7621	1.0669
13	.724	.6097		.5716	.8192	.9526
14	.7621	.6668		.5906	.9145	1.0669
15	.8002	.9717		.5906	1.1241	1.1431
16	.8573	.8954		.4954	.9907	1.105
17	.8954	.6097		.5525	.9145	1.1812
18	.0953	.6097		.5906	.8954	1.1241
19	.4954	.6287		.5906	.7621	1.2193
20	.5144	.6478		.5906	.5144	1.105
21	.6097	.6097		.6097	.5716	.5906
22	.6478	.6287		.6097	.6287	.6478
23	.5525	.6287		.5716	.6097	.6097
24	.5525	.5906	.6161	.5906	.5716	.6478
Max	.8954	.9907	.6161	.6097	1.1241	1.2193
Min	.0953	.4572	.6161	.4954	.5144	.4763
Avg	.5986	.6637	.6161	.5763	.7057	.8073

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 202 / 11KV ACCURATECH

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	1.5242	1.5242		.6097	.5906	1.4861
2	1.5242	1.467		.6097	.6097	1.4289
3	1.467	1.3336		.5906	.6097	1.4289
4	1.3336	1.086		.5716	.6097	1.448
5	1.4098	1.2384		.6097	.5906	1.3336
6	1.5051	1.3336		.6478	.6097	1.5051
7	1.4861	1.5432		.724	.6478	1.4861
8	1.5242	.7621		.7621	.6287	.7621
9	1.6766	1.1812		.6287	.724	.8954
10	1.7337	1.1812		.6478	1.0098	1.5623
11	1.7909	1.3146		.6478	.9145	1.4861
12	1.8099	1.2193		.6478	1.0098	1.5813
13	1.8671	1.1812		.6097	1.6766	1.6956
14	1.9052	1.1431		.6287	1.5242	1.848
15	1.848	1.2193		.6287	1.3527	1.7147
16	1.7909	1.105		.5906	1.6956	1.8099
17	1.2574	1.1431		.6478	1.2193	1.7718
18		.8002		.5906		1.7909
19	1.6956	.6478		.6478		1.7337
20	1.7147	1.0479		.7049	1.0669	1.8099
21	1.6194	.9907		.6668	1.5242	1.1431
22	1.5432	.9907		.6478	1.5813	1.6004
23	1.6385	.9717		.6287	1.5623	1.5242
24	1.5813	1.4098	.9709	.6097	.6097	1.5242
Max	1.9052	1.5432	.9709	.7621	1.6956	1.848
Min	1.2574	.6478	.9709	.5716	.5906	.7621
Avg	1.6194	1.1598	.9709	.6375	1.0167	1.5154



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 203 / 11KV SHIROLI PULACHI  
(RENUKA-N Feeder KV- 11 /  
OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.2096	.1715		.1905	.1905	.2667
2	.2096	.2096		.1905	.1715	.2286
3	.1905			.1715	.1715	.1715
4	.1715	.1715		.1715	.1715	.1715
5	.1715	.1905		.2096	.1905	.1905
6	.1905	.2286		.2477	.2286	.2096
7	.2477	.2477		.2858	.2667	.2286
8	.2858	.2667		.3048	.3048	.2858
9	.3048	.3048		.2858	.2858	.2477
10	.3048	.2858		.2477	.3048	.3048
11	.2858	.2858		.2477	.3429	.2477
12	.2858	.2477		.2858	.2858	.2667
13	.2858	.2477		.2477		.2858
14	.3048	.2477		.2286	.2667	.2667
15	.3048	.2858		.2667	.2858	.2477
16	.3048	.3048		.2286	.2667	.2286
17	.2286	.2858		.2477	.2858	.2858
18	.2858	.2858		.2286	.2858	.3048
19	.3239	.2286		.2477	.3048	.3048
20	.3048	.3048		.2667	.3239	.2858
21	.3239	.2858		.2477	.3239	.2858
22	.3239	.3048		.2286	.3048	.2858
23	.2858	.2667		.2096	.2858	.2667
24	.2286	.2667	.2241	.2096	.1905	.2858
Max	.3239	.3048	.2241	.3048	.3429	.3048
Min	.1715	.1715	.2241	.1715	.1715	.1715
Avg	.2651	.2576	.2241	.2374	.2626	.2564

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 204 / 11KV SAGAR SHOT BLASTING SHEDDABLE FEEDER HAVING WEEKLY  
Feeder KV- 11 / OUTGOING STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	.7811	.7811			.5906	.724
2	.7621	.7621		.6668	.6097	.6668
3	.743	.724		.6668	.5906	.5525
4	.7049	.6478		.6287	.5906	.5335
5	.6668	.743		.6097	.5716	.6097
6	.7621	.7621		.5906	.6097	.6859
7	.7811	.8002		.5906	.6287	.7621
8	.7621	.8954		.6097	.6859	.8573
9	.8002	1.0669		.5716	.8002	.9907
10	.9907	1.086		.5906	1.6385	1.1431
11	.9526			.5906	.8764	1.105
12	.8954	.8002		.5906	.743	.9907
13	.9526	.9335		.5716	.8383	1.0288
14	.9717	.9907		.5525	.8764	1.105
15	.9526	1.105		.5525	.8954	1.1431
16	.9907			.5906	.8383	1.0479
17	.8764	.8954		.6097	.8573	.9335
18	.8383	.8002		.5906	.7621	.9526
19	.8002	.724		.5906	.8002	.9907
20	.724	.724		.6097	.724	.9526
21	.7621	.7049		.6097	.7621	.9145
22	.8002	.724		.5906	.7811	.9335
23	.7811	.743			.7621	.9526
24	.7621	.8192	.7095	.724	.5716	.7621
Max	.9907	1.105	.7095	.724	1.6385	1.1431
Min	.6668	.6478	.7095	.5525	.5716	.5335
Avg	.8256	.8288	.7095	.6045	.7669	.8891

**MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD****Feederwise Load Information for All Feeders**

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 144121 / 33/11 KV G-BLOCK

Feeder No / Name : 205 / 11KV CHOUGULE FOUNDRY  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	29-MAR-18	31-MAR-18	01-APR-18	02-APR-18	03-APR-18	04-APR-18
HR	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)	Load (MW)
1	2.6101	2.0767		1.7528	.8573	2.191
2	2.4768	2.553		1.5623	.8573	2.6292
3	2.6863	2.4768		1.2384	.8764	2.0005
4	2.0767	2.7435		1.2003	.8192	2.21
5	2.3815	2.6292		1.1431	.9907	2.2672
6	2.4768	2.3053		1.1812	1.2003	2.0767
7	2.6863	2.5149		1.2193	1.3527	2.0005
8	2.6101	2.2291		.9526	1.448	2.1529
9	2.1338	2.4196		.743	1.448	2.4196
10	3.0483	3.1436		.7049	1.8671	3.1245
11	2.7244			.743	1.848	2.6101
12	2.8578	2.5339			1.7147	1.3527
13	2.8197	2.8769		.724	1.6575	1.9814
14	3.0674	2.8387		.7049	1.9433	3.0483
15	2.7625	2.7244		.7049	2.5149	3.1055
16	1.6194	2.2672		.7621	2.4387	3.0483
17	2.9912	2.4387		.724	2.4387	2.9912
18	2.4006	2.6863		.8764	2.553	2.8387
19	2.915	2.21		.8383	2.7054	2.8959
20	2.7625	1.9052		.8192	2.6673	2.8578
21	2.4768	2.2481		.8383	2.8006	2.8006
22	2.0957	2.0386		.8764	2.6863	2.3053
23	1.5242	2.7816		.8573	2.6292	2.6482
24	2.8387	2.8578	2.1472	2.0005	.8002	2.572
Max	3.0674	3.1436	2.1472	2.0005	2.8006	3.1245
Min	1.5242	1.9052	2.1472	.7049	.8002	1.3527
Avg	2.5434	2.5000	2.1472	1.0073	1.7965	2.5053

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 203 / Panchganga

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	.4191
Max	.4191
Min	.4191
Avg	.4191

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 204 / MAHALAXMI EHV Shirolī  
Feeder KV- 11 / OUTGOINGSHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	1.0288
Max	1.0288
Min	1.0288
Avg	1.0288

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 205 / 11KV HIGHWAY

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	2.3434
Max	2.3434
Min	2.3434
Avg	2.3434

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 206 / JUMBO

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
24	2.2291
Max	2.2291
Min	2.2291
Avg	2.2291

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 207 / 11KV SWARAJ

Feeder KV- 11 / OUTGOING

SHEDDABLE FEEDER HAVING WEEKLY  
STAGGERING (MIDC, EQUIVALENT)

DATE	01-APR-18
HR	Load (MW)
23	2.2032
24	2.2032
Max	2.2032
Min	2.2032
Avg	2.2032



## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 401 / 33 KV MPM

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS

(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-APR-18
HR	Load (MW)
24	5.0297
Max	5.0297
Min	5.0297
Avg	5.0297

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 403 / 33KV Shirolī Minor

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.6868
Max	4.6868
Min	4.6868
Avg	4.6868

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 404 / 33KV D Block

Feeder KV- 33 / INCOMING

NON SHEDDABLE EXPRESS HV FEEDERS  
(NON-CONTINUOUS PROCESS)(NO  
STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	4.0009
Max	4.0009
Min	4.0009
Avg	4.0009

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 405 / 33 KV Saroj

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-APR-18
HR	Load (MW)
24	8.0018
Max	8.0018
Min	8.0018
Avg	8.0018

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 406 / 33 KV Kolhapur Steel  
Feeder KV- 33 / OUTGOINGNON SHEDDABLE EXPRESS HV FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING)

DATE	01-APR-18
HR	Load (MW)
24	.2858
Max	.2858
Min	.2858
Avg	.2858

## MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD

## Feederwise Load Information for All Feeders

From 29-MAR-18 and 04-APR-18

KOLHAPUR ZONE[050]

KOLHAPUR CIRCLE[500]

KOLHAPUR URBAN DIVISION[111]

KOLHAPUR U.MARKET Y.[021] BU 4021

Substation No/ Name :- 146010 / 110/33/11KV Shirolī S/stn

Feeder No / Name : 407 / Hind Gear

Feeder KV- 33 / OUTGOING

NON SHEDDABLE EHV INDUSTRIAL FEEDERS  
(CONTINUOUS PROCESS)(NO STAGGERING

DATE	01-APR-18
HR	Load (MW)
24	2.572
Max	2.572
Min	2.572
Avg	2.572